

Office of the Chief Engineer (Dist. Special Project Cell)
Maharashtra State Electricity Distribution Co. Ltd.

“Prakashgad”, 4th Floor, Station Road, Bandra (East), Mumbai - 400 051.

Tel. : 022-2658 2340 (P) 022-2647 4211 (O) Fax : 022-2647 6230 Gram : MUMBAIGRID
www.mahadiscom.in E-mail: ce_dsp@mahadiscom.in

CE/DSPC/LT CAPS/1738

Date: 27.09.2010

Addendum – 3

To,
All prospective bidders of
Tender for 25 & 30 kVAr LT APP Shunt Capacitors

Sub : Tender for 25 & 30 kVAr LT APP Shunt Capacitors

Ref : Tender No. CE/DSPC/LT CAPS/T-6/09-10.

Pursuant to subject Tender for 25 & 30 kVAr LT APP Capacitors, and the clarification issued by MSEDCL after Pre-bid meeting on 18.09.2010, this office has received further queries from prospective bidders accordingly following modifications are made to, and shall form a part of the bidding documents for the said Tender:

1) Volume-I, Clause No. 6.9 of Section-1 (Instruction to bidders) has been revised as follows;

Any partner in JV shall furnish valid type test certificate for 25 KVAR / 30 KVAR, 440 V, 3 Ph APP Shunt Capacitor, as per IS: 13585 carried out from reputed Govt. Lab i.e. CPRI/ or NABL Accredited laboratory within one month after receipt of LOA and the undertaking to that effect shall be submitted alongwith the offer.

The bidders having type test report for above capacitors may submit the same alongwith the bid. However, type Test certificate should not be older than 5 years as on the date of opening the tender. Type test conducted at supplier’s own Lab shall not be considered.

2) Following clause in the bid document stands deleted.

a) Volume – I, Section – 3;

i) Sample Form (Letter of Assured Line of Credit)

3) Volume-I, Section 5, Schedule-II has been revised and attached herewith as **Annexure-I**

This Addendum-3 is available on website www.mahadiscom.in.

Thanking you,
Encl: Annexure-I

Yours faithfully,

Sd/-
Chief Engineer
(Dist.-SPC)

Copy s.w.r. to:

1. Hon. Managing Director, MSEDCL Mumbai
2. Director (Projects), MSEDCL, Mumbai.
3. Director (Finance), MSEDCL Mumbai
4. Executive Director (Projects), MSEDCL, Mumbai

Schedule II**Summary of Qualification Information**

for

Turnkey Contract for 25 kVAr & 30 kVArLT APP Shunt Capacitor Scheme (Fixed)

Circles	Estimated Cost of the Works (Rs. lakhs)	Minimum Qualification Criteria	
		Turn over in any one financial year out of last 5 years (30% of Estimated Cost) (Rs. lakhs)	Net Worth (10% of Estimated Cost) (Rs. lakhs)
Lot 1 :			
Jalgaon, Dhule, Nandurbar	5.88	1.76	0.59
Lot 2 :			
Pune (Rural), Baramati, Satara	6.87	2.06	0.69
Lot 3 :			
Kolhapur, Sangli	10.91	3.27	1.09
Lot 4 :			
Nashik (Urban), Nashik (Rural), Ahmednagar	11.70	3.51	1.17
Lot 5:			
Solapur	16.55	4.96	1.65