

Office of the Chief Engineer (Dist. Special Project Cell)
Maharashtra State Electricity Distribution Co. Ltd.

“Prakashgad”, 4th Floor, Station Road, Bandra (East), Mumbai - 400 051.

Tel. : 022-2658 2340 (P) 022-2647 4211 (O) Fax : 022-2647 6230 Gram : MUMBAIGRID

www.mahadiscom.in

E-mail: ce_dsp@mahadiscom.in

CE/DSPC/SPP/356/6989

Date: 03.03.2011.

To,

All Prospective Bidders of
Tender for Single Phasing left-out villages/wadies.

Sub: Reply to the Queries raised by various prospective bidders of Tender for Single Phasing left-out villages/wadies during pre-bid meeting held on 21st February, 2011.

Ref: Tender No. CE/ DSPC/ SPP/T-9/10-11.

The pre-bid meeting for Tender for Single Phasing left-out villages/wadies has been conducted on dated 21st February, 2011 at “Prakashgad”. The reply to the queries raised by various prospective bidders of Tender for Single Phasing left-out villages/wadies is enclosed herewith as Annexure-I.

Thanking you,

Yours sincerely,

Sd/-
Chief Engineer
(Dist.-SPC)

Copy s.w.r.to:

1. The Director (Projects), MSEDCL Mumbai.
2. The Executive Director (Projects), MSEDCL Mumbai.
3. The Chief General Manager (I/A), MSEDCL Mumbai.

Copy forwarded to:

- 1) M/s Kalpataru Power Transmission Ltd., Gandhinagar.
- 2) M/s Jyoti Structures Limited, Mumbai.
- 3) M/s A2Z maintenance & Engineering Services, Mumbai.
- 4) M/s Bharat Electrical, Sangli.
- 5) M/s Nagarjuna Construction Company Ltd.
- 6) M/s Godrej & Boyce Ltd., Mumbai.
- 7) M/s East Cost & Construction Ltd., Hyderabad.
- 8) M/s PIPL, Mumbai.

PRE BID CLARIFICATION (PRE BID MEETING HELD ON 21/02/2011)
TENDER FOR SINGLE PHASE SCHEME FOR LEFT OUT VILLAGES/WADIES
Tender No. CE/DSPC/SPP/T-9/10-11

Sr. No.	Volume & Section No.	Clause No.	Bidder Queries	Clarifications of MSEDCL
1)	Volume-I, Invitation for Bids	Table	Representatives of M/s A2Z Maintenance & Engg Services Ltd, M/s Bharat Electrical & M/s KPTL submitted that 1) There is variation in the Estimated cost & Bid Security Amount in the NIT & Tender Document 2) Estimated cost of the work is shown as Rs. Lakhs as against Rs. Crs 3) Amount of Bid security shown in Tender documents is only 0.1 % of the estimated cost.	1) The Amount of Bid Security shall be 1 % of the Estimated cost of the Lot. 2) The addendum will be issued correcting all the discrepancies
2)	Volume-I, Section 2			
3)	Volume-V, Cost Data	Activities for 15 kVA DTC	The activity shows 25 kVA Single Phase Transformer instead of 15 kVA Single Phase Transformer	The activity has typographical error, 15 kVA Single Phase Transformer need to be considered, there is no change in the cost provided in the tender document.
4)	Volume-V, Cost Data	Activities for 15 kVA & 25 kVA DTC's	Representatives of M/s Bharat Electrical has pointed out that MS Flat is not considered in the DTC activity	Revised Activity Schedule as well as Lot wise schedules will be issued in the addendum.
5)	Volume-II, Section 6	Clause-14	Representatives of M/s Bharat Electrical & M/s KPTL has queried about the quantity variation	Clause 14 stands deleted and the payment will be made as per actual measurement of work.
6)	Volume-II, Section 6	Clause-8.6	Representatives of M/s KPTL & M/s NCCL has requested to levy, liquidated Damage on balance work only.	Liquidated Damages shall be levied @ 10% maximum on the balance work as on contractual work completion period.
7)	Volume-I, Section 1	Clause 6.1 (e) & 6.3 (e)	M/s Electropath Services submitted that clause 6.1 (c)& 6.3 (c) considers annual turnover of any or both partners together, whereas for network only lead partner is considered, this may be modified to any or both partners	clause 6.1 (e) & 6.3 (e) will be modified and included in the addendum considering any or both partners instead of lead partner

8)	Volume-V, Cost Data	Activity for 11 kV Line	M/s KPTL, M/s NCCL & M/s Godrej & Boyce submitted that it is not clear from activity schedule that which type of conductor to be used i.e ACSR or AAAC	Bidder should use only AAAC conductor.
9)	Volume-IV, Section 10	Technical Specification of 63kVA/100kVA Dist. Box	M/s Sintex Industries Ltd., Mumbai has requested to include SMC 15kVA/25kVA Singl Phase Distribution Boxes in tender specification.	Bidder may use MS or SMC Distribution Boxes.