

MINUTES OF PRE-BID MEETING ON 28.12.2010

Sub:- Supply & Installation of DTC Metering without Meters under Nagpur Rural Circle, Nagpur. (Tender No.SE/NRC/T/DTC-M/10-11/T-26)

Pre-Bid meeting for Tender No.SE/NRC/T/DTC-M/10-11/T-26 was held on 28.12.2010 in the office of the Superintending Engineer, Nagpur Rural Circle, MSEDCL; Nagpur. The following 3 Nos. representatives of the prospective Bidders have attended the meeting.

MSEDCL Representative

- (1) Shri G.N.Nagrle, E.E.(Adm), NRC
- (2) Shri P.N.Patil, Dy.Manager (F&A)
- (3) Shri A.P.Alwani, A.E.

Bidders Representative

- (1) M/s. Shri Gajanan Engineering, Services, Nagpur

In the Pre-Bid meeting, M/s. Shri Gajanan Engineering Services, Nagpur had raised the following points.

- (1) Single Phase DTC Metering Drawings got approved or not.
- (2) L.T. XLPE 120 Sq.mm. Single Core cable is not sufficient for Incomer of 200 KVA X'mer.
- (3) 10 Meters Length of cable is insufficient for single phase X'mer metering.
- (4) Inner diameter of 100/5 Amp. C.T. (Ring Type) not mentioned in the specification.

In this regard, it is clarified as below:

- (1) Single Phase DTC Metering Drawings is approved.
- (2) Required size LT XLPE cable suitable for Incomer of 200 KVA X'mer, if required will be considered, as Extra item and rate will be finalized as per the existing cost data of MSEDCL.
- (3) 10 Meters Length of cable is sufficient for single phase X'mer metering.
- (4) The 100/5 Amp. C.T. (Ring Type) should be utilized as per relevant I.S. amended up to date and from approved vendor list of MSEDCL for this item only.

The other terms & conditions mentioned in Tender No. SE/NRC/T/DTC-M/10-11/T-26 shall remain unchanged.


SUPERINTENDING ENGINEER (NRC),
M.S.ELECT.DIST.CO.LTD; NAGPUR.