

**Maharashtra State Electricity Distribution Co. Ltd.**  
**REQUEST FOR SELECTION (RfS) FOR PROCUREMENT OF 865 MW (AC) SOLAR POWER FROM PROJECTS TO BE DEVELOPED IN**  
**MAHARASHTRA THROUGH**  
**COMPETITIVE BIDDING PROCESS (FOLLOWED BY E-REVERSE AUCTION) UNDER MSKVY**

Sl. No.	Rationale/Remarks/Clarification	MSEDCL's response
1	As per guidelines Module degradation @0.5% per year is allowed. However same is not mentioned in Rfs.	As per RfS clause no 3.12.4 Solar Power Generator shall be allowed for the repowering once for a maximum cumulative period of six (6) months during the entire PPA term of 25 years
2	Is there any Exemption of Tender & Processing fee for MSME registered bidders	There is no exemption of tender & processing fee to MSME registered bidders
3	The time period of 12 months required for commissioning of projects shall be increased to 15 or 18 months	The request is not accepted. The Bidder has to adhere with RFS provisions only.
4	Request you to allow Solar projects to be connected at 33 kV level rather than 11 kV under MSKVY scheme.	The request is not accepted. The Bidder has to adhere with RFS provisions only.