

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 201 / 11 Kv Hutatma

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6099	.6908	.6838	.6838	.6602	.6722	.6584
2	.6099	.6908	.6838	.6838	.6602	.6722	.6584
3	.6283	.6908	.7023	.7095	.6602	.6535	.6767
4	.6838	.6908	.7468	.7392	.6602	.6535	.6401
5	.8686	.7468		.8316	.7545	.7282	.695
6	1.1763	.8589	.8775	.8871	.9149	.8686	.8145
7	1.1203	.8589	.9055	.905	.8589	.9055	.8145
8	.9054	.7468	.6984	.6878	.7421	.724	.5792
9	.6001	.6089	.5784	.6468	.6516	.6697	.4525
10	.6335	.6268	.5493	.6335	.724	.6024	.394
11	.6089	.6268	.6626	.631	.724	.5552	.4163
12	.6089	.6447	.5847		.5973	.7343	
13	.6878	.7522	.6878		.6697	.7522	
14	.6335	.7421	.724	.7059	.6335	.7522	
15	.6335	.6219	.8869	.7059	.5611	.6584	
16	.6516	.6602	.7602	.7059	.6401	.695	
17	.591	.679	.691	.6733	.6401	.6805	
18	.6379	.7186	.6401		.5847	.7133	
19	.9328	.9465	.7762	.905	.8238	.9145	
20	.9412	.9774	.9979	.9694	.8686	.9694	
21	.924	.9328	.924	.9795	.8871	1.0059	
22	.8501	.9979	.8686	.8299	.8686	.9335	
23	.7577	.724	.7468	.7356	.8029	.9335	
24	.7392	.6838	.6838	.7095	.6979	.6722	.6767
Max	1.1763	.9979	.9979	.9795	.9149	1.0059	.8145
Min	.591	.6089	.5493	.631	.5611	.5552	.394
Avg	.7514	.7466	.7418	.7600	.7203	.7550	.6230

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 202 / 11 Kv Walwa Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3739	.1981	1.9989	.181	.2715	.2772	2.4587
2	2.2891	2.1795	2.0317	.181	.2715	.2772	2.3739
3	2.2891	2.1795	2.079	.1991	.2715	.2772	2.3739
4	2.3739	2.1795	2.146	.2172	.2715	.2772	2.3739
5	2.3739	2.1795		.2715	.3077	.2987	2.4078
6	2.3739	2.2131	2.1704	.2715	.3544	.3174	2.4078
7	2.2552	2.2969	2.2291	.3077	.3189	.3258	2.713
8	.2829	.3142	.2454	.3077	.3174	.2801	.3077
9	.2561	.2987	2.5987	2.9675	3.0182	.2353	.2353
10	.2452	.2641	2.8669	2.9675	3.2922	.2263	.2328
11		.2452	2.934	3.0178	.6767	.2075	.2263
12				2.3472	.6767	.2452	
13			2.7469	2.5434	3.4389	.2452	
14			2.8487	2.6282	3.2579	.2452	
15			2.9334	2.6322	2.9492	.2452	
16		.3772	2.7808	2.6155	3.1207	.2452	
17			.2829	.1886	.2172	.2829	
18	.2829	.2686	.2829		.2103	.2641	
19	.3326	.3511	.3206	.2987	.298	.2641	
20	.4024		.3326	.362	.3258	.2641	
21	.4024	.3475	.3658	.3439	.3475	.3109	
22	2.6621	2.3205	.2926	.3258	.3511	3.2007	
23	2.4078	2.146	.2561	.2896	.2801	2.8656	
24	2.3739	2.1963	1.9989	.2561	.2926	.2772	2.713
Max	2.6621	2.3205	2.934	3.0178	3.4389	3.2007	2.713
Min	.2452	.1981	.2454	.181	.2103	.2075	.2263
Avg	1.5281	1.2531	1.6701	1.1183	1.0474	.4981	1.7353

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 203 / 11 Kv.Bawachi LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0748	2.7435		2.1719	2.7435	2.5789	
2	2.0748	2.7435	2.1948		2.7435	2.5972	
3	2.2634	2.7435	2.1582		2.7435	2.5789	
4	2.452	2.7435	2.524	2.3529	2.7435	2.7252	
5	2.8292	2.8349		2.3529	2.7435	2.8349	
6	3.678	3.0361	2.7252	2.6244	3.0178	2.8898	
7	2.9235	2.9264	2.8898	2.9864	2.8715	3.091	
8	3.0556	3.0361	2.963	2.9864	2.9264	3.1642	
9	1.8861	2.963	2.5972	3.0769	3.1824	3.0178	
10	2.9447	2.9447	3.1642	3.1093	3.0178	3.0544	
11	3.0361	2.963	2.8349	3.1276	2.9264	2.9447	.1886
12	2.9995	2.652	2.8166	2.4874	2.9264	2.7435	
13	2.7252	2.9081	2.8532	2.1216	2.8349	2.9264	
14	2.8349	2.8349	3.1459	2.3228	2.8349	2.9264	
15	2.9264	2.8715	3.091	2.7435	2.8669	2.9995	
16	1.9387	2.1399	2.4326	2.4508	2.524	2.9264	
Max	3.678	3.0361	3.1642	3.1276	3.1824	3.1642	.1886
Min	1.8861	2.1399	2.1582	2.1216	2.524	2.5789	.1886
Avg	2.6652	2.8178	2.7422	2.6368	2.8529	2.8750	.1886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 204 / 11 KV Padawalwadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2452		1.9433	1.4746	1.3603	.1886
2	.2075	.2452		1.9433	1.4746	1.3279	.1886
3	.1886	.2452		1.9433	1.4575	1.3279	.1886
4	.2263	.2452		1.9433	1.6194	1.4737	.2452
5	.3018	.3395		2.1052	1.6194	1.5546	.2641
6	.3395	.415		2.1862	1.7814	1.9109	.3395
7	.3772	.3206		2.13	1.8947	1.6842	.3395
8		.3961		.2829	.2686	.2452	.3206
9	2.7435	2.9835	.2452	.2263	.2715	2.3967	2.7206
10	2.753	2.8647	.2075	.2075	.2686	2.3967	2.8121
11	2.5425	2.6726	.2263	.2075	.2507	2.3594	2.6063
12	2.251		.2075	.2452	.2353	2.1956	
13	2.1214		.2075	.2452	.2263	1.9662	
14			.1886	.2452	.2075	1.9662	
15			.1886	.2452	.2075	2.0972	
16	1.9595	2.3644	.2452	.2263	.2452	1.8947	
17	.2263	.2829	.2452	.2263	.2452	.2587	
18	.3961	.2829	.2229	.2829	.2452	.2402	
19	.3961	.3018	.2641	.3206	.2641	.3658	
20	.3206	.3395	.3018	.3395	.2829	.2587	
21	.3206	.3206	.3206	.3206	.2829	.2641	
22	.2829	.2829	2.4291	1.8233	1.6518	.2263	
23	.2263	.2452	2.332	1.6712	1.4899	.2263	
24	.2263	.2452	.2263	2.17	1.5402	1.3765	.2075
Max	2.753	2.9835	2.4291	2.1862	1.8947	2.3967	2.8121
Min	.1886	.2452	.1886	.2075	.2075	.2263	.1886
Avg	.8873	.7819	.5037	.9783	.8127	1.3073	.8684

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 205 / 11 KV Hutatma Dudh Sangh NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1886	.1886	.0943	.1509	.1509	.1509
2	.1132	.1886		.0943	.1509	.1509	.1132
3	.0943	.132		.0943	.1509	.1509	.0943
4	.0943	.132		.0943	.1509	.132	.1132
5	.132	.1132		.0943	.132	.1132	.1132
6	.1698	.1132		.0943	.132	.0943	.1132
7	.1886	.132			.1132	.1132	.0943
8	.1132	.0943			.0943	.0943	.1132
9	.12	.0943		.1132	.132	.1132	.1132
10	.1509	.1698			.1886	.1886	.2075
11	.1886	.1698	.1698		.1886	.1886	.2075
12	.2075	.2641	.2452		.1886	.2263	
13	.1886	.2075	.132		.2829	.2263	
14	.1509	.132	.1698		.2263	.2263	
15	.1509	.1509	.1509	.1132	.1886	.1698	
16	.132	.1132	.1132	.1132	.1509	.1886	
17	.1698	.132	.132	.1132	.2641	.2075	
18	.2452	.1132	.1509	.1132	.1698	.2075	
19	.1886	.1698	.132	.1698	.1698	.2075	
20	.1509	.1886	.132	.1509	.132	.2263	
21	.1886	.2075	.1509	.2829	.1886	.2075	
22	.1698	.1509	.2452	.2075	.1698	.1886	
23	.1698	.132	.2829	.1886	.2452	.1886	
24	.132	.2075	.2263	***	.1886	.1698	.1886
Max	.2452	.2641	.2829	13.3539	.2829	.2263	.2075
Min	.0943	.0943	.1132	.0943	.0943	.0943	.0943
Avg	.1559	.1540	.1748	.9109	.1729	.1721	.1352

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 206 / 11KV Ahirwadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258	.3018		.3077	.3361	.3174	.3077
2	.3077	.3018		.2896	.3361	.3174	.3077
3	.2896	.3018		.2896	.3361	.3174	.3077
4	.3258	.3018		.2896	.3361	.3547	.3258
5	.4344	.3395		.2896	.3734	.3511	.3982
6	.4755	.4527		.3982	.4481	.3696	.4163
7	.439	.4066		.362	.3734	.4066	.3658
8	.3696	.3439		.3077	.3511	.2896	.362
9	.2915	.2534	.3292	.362	.3258	.2658	.2883
10	.2896	.2896	.3045	.3258	.2715	.2515	.285
11	.2601	.2865	.2896	.2835	.2715	.2103	.285
12	.2804	.2686	.3045	.2865	.2896	.2374	
13	.298	.3045	.3077	.2865	.3258	.2715	
14	.2629	.2896	.2896	.2896	.2534	.2715	
15	.2629	.2772	.2614	.2957	.2353	.2587	
16	.2587	.2507	.2427	.3142	.2534	.2804	
17	.2658	.2507	.2804	.2658	.2804	.2804	
18	.2835	.3366	.3429	.2743	.2804	.2774	
19	.462	.4755	.439	.4207	.3982	.3696	
20	.5041	.5729	.5658	.5228	.4481	.4251	
21	.4527	.4854	.5228	.5041	.4668	.439	
22	.4527	.4294	.4938	.4481	.4294	.3658	
23	.3772	.3547	.3772	.3734	.3547	.3292	
24	.3292	.3206	.3206	.3361	.3547	.3174	.3109
Max	.5041	.5729	.5658	.5228	.4668	.439	.4163
Min	.2587	.2507	.2427	.2658	.2353	.2103	.285
Avg	.3458	.3415	.3545	.3385	.3387	.3156	.3300

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 207 / 11KV Nagthane AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478	.7125	.8097	.0377	.0566	.0566	.7287
2	.6478	.7125	.7773	.0377	.0566	.0566	.7287
3	.6478	.7125	.7773	.0566	.0566	.0566	.7287
4	.6478	.7125	.7449	.0566	.0566	.0566	.7287
5	.7287	.7125		.0566	.0566	.0566	.7287
6	.7449	.7287	.7449	.0566	.0566	.0754	.7773
7	.8259	.7611	.7449	.0566	.0754	.0754	.7773
8	.0754	.0566	.0566	.0754	.0566	.0754	.0566
9	.0686	.0754	.9717	1.4146	1.1174	.0566	.0566
10	.0754	.0754	1.085	1.1984	1.1888	.0566	.0566
11		.0754	1.1174	1.1822	1.1336	.0566	.0377
12			1.085		1.2483	.0566	
13			1.004			.0754	
14			1.1012	1.1498	1.0526	.0754	
15			1.0526	1.1498	1.0526	.0754	
16		.0566	1.0202	1.0688	1.0526	.0566	
17		.0754	.0566	.0566	.0566	.0566	
18	.0754	.0754	.0566	.0754	.0754	.0566	
19	.0754	.0754	.0566	.0754	.0754	.0566	
20	.0754	.0754	.0754	.0566	.0754	.0566	
21	.0754	.0754	.0754	.0566	.0754	.0566	
22	.664	.7449	.0566	.0754	.0566	.8478	
23	.6802	.7449	.0566	.0754	.0754	.8478	
24	.6478	.7125	.8097	.0377	.0566	.0566	.6478
Max	.8259	.7611	1.1174	1.4146	1.2483	.8478	.7773
Min	.0686	.0566	.0566	.0377	.0566	.0566	.0377
Avg	.4355	.3986	.6233	.3685	.3854	.1272	.5045

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 208 / 11KV Kisan No 3 LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1535	.0183		.0377	.0183	.0181
2	.1596	.1414		.0566	.0183	.0181
3	.2208	.2324		.0514	.0183	.0181
4	.2193	.232		.0566	.0183	.0181
5	.2197	.2324		.1294	.0183	.0181
6	.2386	.2347		.237	.2149	.1795
7	.2386	.2335		.2566	.2358	.2332
8	.2344	.4508		.4597	.4192	.2305
9	.447	.4645	.2195	.4891	.4611	.2494
10	.4792	.4813	.2378	.4799	.4779	.232
11	.4799	.4801	.2378	.4742	.476	.2305
12	.4561	.4607	.2195	.4735	.4565	.2293
13	.4874	.4542	.2195	.4531	.4538	.2293
14	.373	.4546	.2195	.4599	.463	.2282
15	.3544	.4546	.2195	.4761	.463	.2278
16	.2583	.4713	.1097	.1633	.4748	.2278
24				.0004		
Max	.4874	.4813	.2378	.4891	.4779	.2494
Min	.1535	.0183	.1097	.0004	.0183	.0181
Avg	.3137	.3436	.2104	.2797	.2930	.1618

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 401 / 33KV Walwa LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7187	1.5364	1.5364	1.3306	1.7558	1.5364
2	1.7741	1.6461	1.5364	1.386	1.7558	1.5364
3	1.7187	1.6461	1.701	1.3306	1.7558	1.5364
4		1.6461	1.701	1.7187	1.7558	1.6461
5	1.8296	1.6461		1.7187	1.9753	1.7558
6	1.8107	1.701	1.3169	1.7187	1.9753	1.8656
7	1.8656	1.701	1.701	1.7187	1.8107	1.9753
8	1.9404	1.701	1.5912	1.7187	1.7558	1.9753
9	1.8519	1.701	1.6461	1.7741	2.0302	1.9753
10	2.0302	1.701	1.701	1.7558	2.0851	1.9753
11	2.0302	1.701	1.701	2.0851	2.0302	1.9753
12	1.9753	1.6461	1.6461	1.262	2.0302	1.9753
13	1.9204	1.5912	1.701	1.5364	2.0302	1.9204
14	1.9753	1.5912	1.701	1.701	2.0302	1.9204
15	1.6461	1.5912	1.701	1.8107	1.6461	1.9204
16	1.0425	.9328	1.0425	1.262	1.6461	1.3169
Max	2.0302	1.701	1.701	2.0851	2.0851	1.9753
Min	1.0425	.9328	1.0425	1.262	1.6461	1.3169
Avg	1.8086	1.6050	1.5949	1.6142	1.8793	1.8004

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 201 / 11 Kv. Shigaon AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0402	.9214	.7529	.0394	.04	.0526	1.07
2	1.0402	.9214	.7727	.04	.04	.0533	1.0402
3	1.0402	.9181	.7526	.0423	.04	.0549	1.0235
4	.8573	.9145	.743	.0463	.0343	.0564	.9957
5	.8573	.8916	.7225	.0457	.0343	.0572	.9633
6	.8459	.8916	.743	.0457	.0343	.0594	.9633
7	.8345	.8949	.7977	.044	.0343	.0533	.9755
8	.0419	.0511	.032	.0326	.032	.0434	.0495
9	.0126	.04	1.3426	1.6461	1.4842	.0337	.0309
10	.0244	.0406	1.4685	1.6762	1.5466	.0343	.0549
11	.0389	.04	1.4685	1.5339	1.6004	.0332	.04
12			1.3565	1.358	1.4175	.0297	
13			1.1888	1.406	1.1296	.0332	
14			1.086	1.1584	1.1584	.0337	
15	.0389		1.07	1.1888	1.1279	.0366	
16		.0372	.9332	.9002	1.0536	.0335	
17		.0366	.04	.0686	.04	.0366	
18	.045	.048	.0406	.0457	.0394	.0412	
19	.061	.0457	.0549	.0452	.0777	.0472	
20	.0753	.0332	.0533	.0457	.0766	.0503	
21	.0594	.0332	.0394	.0457	.0629	.0396	
22	1.0002	1.0364	.0406	.0594	.0472	1.3435	
23	.9976	.8471	.0412	.0594	.0465	1.2346	1.2793
24	1.1431	.9556	.7819	.0377	.061	.0419	1.1138
Max	1.1431	1.0364	1.4685	1.6762	1.6004	1.3435	1.2793
Min	.0126	.0332	.032	.0326	.032	.0297	.0309
Avg	.5292	.4799	.6801	.4838	.4691	.1472	.7385

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 202 / 11 Kv. Bhadkambe LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3582	.3734	.3658	.3658	.3734
2	.3734	.3658	.3696	.3881	.3658	.3734
3	.3734	.3841	.3696	.3841	.3658	.3881
4	.3658	.3801	.3734	.3801	.3658	.3881
5	.3658	.3801	.3696	.3801	.3658	.3881
6	.3658	.3801	.3734	.3982	.3658	.4066
7	.3658	.3801	.3734	.4163	.3658	.3841
8	.3658	.3696	.3734	.3898	.3658	.3801
9	.3658	.3734	.3734	.3982		.3881
10	.3658	.3921	.3734	.4207	.3658	.3881
11	.3881	.3696	.3921	.3658	.3658	.3841
12	.3841	.3658	.3696	.3658	.3881	.3841
13	.3881	.3696	.3696	.3658	.3841	.3801
14	.3881	.3734	.3658	.3658	.3696	.3801
15	.3696	.3696	.3881	.3658	.3696	.3761
16	.218	.2303	.2427	.2378	.2427	.218
Max	.3881	.3921	.3921	.4207	.3881	.4066
Min	.218	.2303	.2427	.2378	.2427	.218
Avg	.3636	.3651	.3657	.3743	.3608	.3738

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 203 / 11 Kv.Pokharni Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.1433	.1075	.0914	.0747	.0747	.0914
2	.0934	.1448	.1086	.0914	.056	.0747	.0914
3	.0934	.1448	.1086	.0905	.0747	.0924	.0905
4	.0934	.1612	.1075	.1086	.0747	.0914	.0905
5	.112	.1612	.1267	.1267	.112	.0924	.0895
6	.112	.1595	.1254	.128	.112	.1109	.0905
7	.112	.1578	.1214	.1063	.1307	.1052	.0924
8	.1307	.1227	.104	.0848	.1097	.0474	.0876
9	.1029	.0867	.1029	.0876	.1097	.0648	.0625
10	.1029	.0701	.081	.1075	.1311	.0655	.0663
11	.1006	.0701	.108	.1658	.1029	.0762	.0671
12			.1029	.1029	.096	.0903	
13			.1052	.1029	.1006	.0937	
14			.1029	.1715	.116	.096	
15	.0829		.1492	.1578	.1296	.0949	
16	.1187	.1658	.1387	.1227	.128	.0781	
17	.0995	.1543	.1402	.1052	.1448	.08	
18	.1147	.1387	.1372	.0781	.1097	.08	
19	.1698	.1402	.1402	.1307	.128	.12	
20	.168	.1595	.1433	.112	.1448	.1417	
21	.1663	.1448	.1448	.1494	.1254	.1254	
22	.1448	.1267	.128		.1075	.128	
23	.1448	.1086	.1097	.0934	.0905	.1086	.1086
24	.1463	.1433	.1075	.0905	.0747	.0895	.0905
Max	.1698	.1658	.1492	.1715	.1448	.1417	.1086
Min	.0829	.0701	.081	.0781	.056	.0474	.0625
Avg	.1192	.1352	.1188	.1133	.1077	.0926	.0861

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 204 / 11 Kv Shigaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.3326	.3018	.3326	.2641	.3206	.3018
2	.2641	.3326	.3018	.3326	.2641	.3174	.3018
3	.2641	.3361	.2987	.3361	.2641	.3361	.3206
4	.3018	.3547	.3395	.3584	.3174	.3395	.3206
5	.3361	.3772	.3772	.415	.3361	.3547	.3206
6	.3547	.4481	.4527	.4854	.3511	.3772	.3395
7	.3429	.4294	.4066	.462	.3696	.3881	.3696
8	.3361	.3439	.362	.3045	.3326	.3012	.2865
9	.2686	.298	.2835	.3077	.2686	.2454	.2774
10	.2507	.2658	.2804	.3012	.2743	.2279	.2572
11	.2715	.2454	.2865	.2481	.2561	.2454	.2427
12	.2835	.2254	.3109	.2303	.2481	.2427	
13	.3258	.2481	.3258	.2378	.3224	.2629	.2915
14	.3475	.3109	.362	.2303	.3077	.2686	
15	.3439	.3109	.362	.2303	.2957	.2835	
16	.3258	.2896	.2926	.2328	.2926	.2774	
17	.2774	.3109	.3326	.2534	.2926	.2743	
18	.2743	.3086	.3841	.2713	.3326	.2818	
19	.4481	.4298	.4706	.3721	.3734	.4119	
20	.5041	.4938	.4805	.4119	.4294	.4755	
21	.4854	.4805	.4854	.3734	.4066	.4251	
22	.4527	.415	.4527		.3734	.3772	
23	.3772	.3584	.3584	.3395	.3584	.3018	.3584
24	.2829	.3395	.3018	.3395	.3018	.3206	.3018
Max	.5041	.4938	.4854	.4854	.4294	.4755	.3696
Min	.2507	.2254	.2804	.2303	.2481	.2279	.2427
Avg	.3326	.3452	.3588	.3220	.3180	.3190	.3064

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 205 / 11 Kv Pokharni Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0838	.0686	.888	.6859	.6019	.0716
2	.0754	.0829	.0701	.884	.6859	.5944	.0709
3	.0754	.0838	.0709	.8488	.7649	.5647	.0724
4	.0747	.0848	.0895	.8749	.7859	.5719	.0739
5	.0747	.1029	.0905	.8796	.8573	.5569	.0732
6	.0747	.1006	.0914	.8688	.9328	.5792	.0739
7	.0895	.116	.0867	.8993	.9602	.643	.0716
8	.0876	.0469	.0709	.0532	.0676	.0705	.0671
9	1.2654	1.4083	.0671	.052	.0648	.9957	1.3375
10	1.5432	1.4074	.0474	.052	.0667	1.0822	1.07
11	1.0185	1.406	.0509	.0511	.0533	1.07	1.1439
12	.8802		.0503	.0427	.0503	1.0562	1.0686
13	.8025		.0457	.0457	.0602	.9412	.9065
14	.7225		.0417	.0465	.0678	.9145	
15	.7316		.0503	.0472	.0514	.8741	
16		1.326	.0617	.0457	.0503	.823	
17		.0594	.0663	.0533	.0509	.0556	
18	.061	.0572	.0671	.0267	.0503	.0556	
19	.0895	.064	.0655	.0457	.0671	.0655	
20	.0895	.0686	.0686	.0533	.0829	.0701	
21	.0886	.0686	.0701	.0857	.0819	.0678	
22	.0857	.0724	1.0822	.743	.7133	.0732	
23	.0838	.0701	1.0494	.7145	.6516	.0543	.0655
24	.0686	.08	.0678	.8916	.6222	.5424	.0693
Max	1.5432	1.4083	1.0822	.8993	.9602	1.0822	1.3375
Min	.061	.0469	.0417	.0267	.0503	.0543	.0655
Avg	.3708	.3395	.1496	.3831	.3552	.5385	.4157

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 206 / Hutatma Sureshkumar LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.2427	.2427	.2378	.2241	.2587
2	.0754	.2427	.2587	.2587	.2241	.2587
3	.0754	.2614	.2772	.2587	.2614	.2743
4	.132	.2561	.2772	.2801	.2614	.2743
5	.132	.2561	.2427	.2957	.2801	.2743
6	.132	.2587	.2801	.2957	.2987	.2926
7	.132	.2957	.2772	.2743	.2987	.2715
8	.1132	.2772	.2801	.2743	.2926	.2743
9	.2641	.2801	.2987	.2715	.2926	.2743
10	.2641	.2772	.2987	.2896	.2926	.2715
11	.2641	.2772	.2587	.2926	.2926	.2715
12	.2614	.2614	.2587	.2926	.2743	.2926
13	.2641	.2587	.2743	.2926	.2743	.2743
14	.2641	.2772	.2743	.3658	.2715	.2743
15	.2641	.2801	.2743	.2926	.2715	.2772
16	.2452	.2743	.2743	.2926	.2715	.0189
Max	.2641	.2957	.2987	.3658	.2987	.2926
Min	.0754	.2427	.2427	.2378	.2241	.0189
Avg	.1849	.2673	.2717	.2853	.2739	.2583

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 207 / 11KV Bahadurwadi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001	.3286	.333	.0189	.0175	.0171	.431
2	.4001	.333	.3243	.0187	.0175	.0175	.4214
3	.4054	.3374	.3144	.0187	.0175	.0171	.4108
4	.4254	.3292	.3185	.0185	.0183	.0173	.431
5	.4254	.3807	.2715	.0187	.0183	.0179	.4458
6	.4254	.3978	.2896	.0377	.0183	.0362	.4666
7	.4254	.3894	.2782	.0377	.0183	.0526	.4401
8	.0139	.0271	.0181	.0332	.0183	.0503	.0149
9	.0173	.0171	.5719	.6173	.5117	.0171	.0143
10	.0175	.0177	.535	.703	.5796	.0173	.0154
11	.0158	.0175	.5182	.6481	.5944	.017	.0156
12			.5093	.5418	.5281	.016	
13			.5201	.5792	.4572	.0328	
14			.4858	.4287	.4548	.0332	
15	.016		.5053	.4458	.4489	.0332	
16		.0151	.4108	.3429	.4287	.0162	
17		.0143	.0179	.0171	.0171	.0332	
18	.0154	.0133	.0181	.0166	.0173	.0335	
19	.0187	.016	.0177	.0168	.0175	.0347	
20	.0189	.0173	.0181	.0168	.0171	.0362	
21	.0185	.017	.0183	.0057	.0168	.0347	
22	.3715	.3909	.0185	.0173	.0164	.5401	
23	.3429	.3572	.0187	.0173	.016	.5117	.5135
24	.4287	.3243	.3338	.0183	.0175	.016	.4401
Max	.4287	.3978	.5719	.703	.5944	.5401	.5135
Min	.0139	.0133	.0177	.0057	.016	.016	.0143
Avg	.2212	.1870	.2777	.1931	.1785	.0687	.3123

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 401 / 33KV LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9619	.7922	.7922	.8488	.9619	.7356
2	.9619	.7922	.9054	.8488	.9619	.8488
3	.9619	.8488	.9054	.9054	.9619	.8488
4	.9619	.9619	.9054	.9619	.9619	.9619
5	.9619	.9619	.679	.9619	.9619	.9619
6	.9619	.9619	.679	.9619	.9619	.9619
7	.9619	.9619	.679	.9619	.9619	.9054
8	.9619	.9054	.679	.9054	.9619	.9054
9	.9619	.9619	.679	.9619	.9619	.9619
10	.9619	.9619	.8488	.9619	.9619	.9619
11	1.0185	.9619	.9619	.9619	.9619	.4527
12	.9619	.9054	.9054	.9619	.9054	.4527
13	.9619	.9054	.9619	.9619	.9054	.4527
14	.9619	.9054	.9054	.9619	.9054	.7356
15	.9619	.9054	.9054	.9054	.9054	.743
16	.6859	.7356	.7356	.5658	.7356	.5144
Max	1.0185	.9619	.9619	.9619	.9619	.9619
Min	.6859	.7356	.679	.5658	.7356	.4527
Avg	.9482	.9018	.8205	.9124	.9336	.7753

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 201 / 11 KV Krishnamai AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9015	.9774	.4424				1.2086
2	.9999	.9602	.4424				1.1911
3	.9816	.9404	.4527				1.1567
4	.9732	.9221	.4694				1.1987
5	.9641	.9154	.4588				1.1736
6	.9625	.8978	.4862				1.1729
7	1.0067	.8474	.4321				1.1816
8				.2561	.1661		
9			.5636	1.7048	1.5722		
10			.7545	1.752	1.4609		
11			.8551	1.7833	1.4799		
12			.8453	1.6507	1.4739		
13			.8192	1.7864	1.3515		
14			.8192	1.7978	1.3138		
15			.8122	1.7871	1.3176		
16			.8356	1.7356	1.264		
21	.1821	.1555				.2172	.1959
22	1.059	.9256				1.1845	.618
23	1.0236	.9576				1.2227	1.2629
24	1.0421	.9922	.4588			.644	1.2353
Max	1.059	.9922	.8551	1.7978	1.5722	1.2227	1.2629
Min	.1821	.1555	.4321	.2561	.1661	.2172	.1959
Avg	.9178	.8629	.6217	1.5838	1.2667	.8171	1.0541

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 202 / 11KV Mahalaxmi LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2197	1.1827	1.134	1.2197	.924	.9522
2	1.2197	1.2012	1.1458	1.2567	.924	.9522
3	1.2197	1.2012	1.1458	1.2567	.924	.961
4	1.2752	1.1827	1.1523	1.2567	.924	.961
5	1.2752	1.1706	1.1458	1.2752	.924	.9522
6	1.2752	1.1827	1.1643	1.2752	.924	.9709
7	1.2197	1.134	1.1523	1.2752	.961	1.0719
8	1.2567	1.1827	1.1523	1.262	.961	1.0719
9	1.2696	1.1827	1.2197	1.3169	.9795	1.0534
10	.9877	1.2382	1.1763	1.3676	1.0456	.8131
11	1.2254	1.2752	1.2197	1.3306	1.0456	.9877
12	1.2071	1.1706	1.2197	1.0829	1.0349	1.0059
13	1.2254	1.2071	1.1584	.961	.9877	.9671
14	1.1888	1.2012	1.1584	.961	.9979	1.2851
15	1.2071	1.1827	1.2012	.9709	.9795	1.2851
16	1.2071	1.1706	1.2012	.8478	.9795	1.2308
24				.0257		
Max	1.2752	1.2752	1.2197	1.3676	1.0456	1.2851
Min	.9877	1.134	1.134	.0257	.924	.8131
Avg	1.2175	1.1916	1.1717	1.1142	.9698	1.0326

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 203 / 11KV Yashwant AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9835	.8817	.9221				.8383
2	.9835	.8916	.8987				.8139
3	.9835	.8745	.8619				.7956
4	.9835	.8745	.8551				.7969
5	.9835	.8916	.8648				.788
6	.9835	.8817	.8745				.78
7	.4694	.8383	.8848				.7625
9			1.3203	1.5261	1.3717		
10			1.4403	1.6804	1.406		
11			1.3565	1.6461	1.5089		
12			1.4083	1.4243	1.4582		
13			1.3757	1.4243	1.3735		
14			1.3916	1.4419	1.3226		
15			1.3565	1.4419	1.1869		
16			1.3565	1.3748	1.1191		
22	.9054	.8817				.8478	
23	.8785	.9389				.8987	.9054
24	1.0395	.852	.9389				.8718
Max	1.0395	.9389	1.4403	1.6804	1.5089	.8987	.9054
Min	.4694	.8383	.8551	1.3748	1.1191	.8478	.7625
Avg	.9194	.8807	1.1317	1.4950	1.3434	.8733	.8169

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 204 / 11 KV Ashta PWW

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1471	.1478	.0671	.157	.1563	.157	.157
2	.1493	.1493	.0671	.157	.1577	.1578	.1563
3	.1493	.1493	.0663	.1578	.1577	.1593	.1563
4	.1493	.1486	.0678	.1578	.1577	.1578	.157
5	.1493	.1486	.0686	.1585	.1577	.1578	.1563
6	.1501	.1494	.0686	.1585	.1577	.1585	.1577
7	.1471	.1493	.0686	.1577	.1563	.1585	.1555
8	.1456	.1464	.0693	.1555	.1562	.1562	.1555
9	.1486	.1478	.0686	.1585	.1578	.1555	.1555
10	.1486	.1508	.0693	.1601	.1578	.157	.0854
11	.1494	.1524	.0693	.1601	.1578	.1563	.0587
12	.1493	.1509	.0716	.0869	.1578	.1563	
13	.1494	.1478	.0709	.1555	.1547	.1547	
14	.1089	.1486	.0709	.1562	.1555	.1555	.0038
15	.1478	.1486	.0709	.1562	.1555	.1563	.0869
16	.1463	.1463	.1326	.0846	.1563	.0846	.0846
17	.1479	.1464	.1326	.1547	.1555	.1547	.0838
18	.1456	.1456	.0709	.1547	.1555	.1555	.0838
19	.1456	.1471	.0709	.1562	.157	.1562	.0838
20	.1464	.1463	.0709	.1555	.1555	.1563	.0846
21	.1464	.1471	.0716	.157	.1563	.1563	.0846
22	.1478	.1494	.0716	.1585	.157	.1585	.0854
23	.1471	.1486	.0716	.1585	.1563	.1577	.1563
24	.1471	.1455	.0663	.157	.1563	.1555	.1562
Max	.1501	.1524	.1326	.1601	.1578	.1593	.1577
Min	.1089	.1455	.0663	.0846	.1547	.0846	.0038
Avg	.1462	.1482	.0747	.1513	.1567	.1537	.1157

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 205 / 11KV Tryambkeshwar LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1433	.1753	.0554	.1109	.0739	.0747
2	.1433	.1734	.1772	.1097	.0739	.0739
3	.1433	.1734	.1753	.1267	.0739	.0739
4	.1433	.1753	.1753	.1267	.0739	.0747
5	.1433	.1753	.1772	.1267	.0739	.0747
6	.1433	.1753	.1772	.1267	.0739	.0747
7	.1254	.1715	.1772	.124	.0732	.0747
8	.2229	.2229	.0995	.1734	.1753	.1772
9	.2229	.2254	.2254	.1949	.1753	.2254
10	.2279	.2454	.2427	.1772	.1772	.2254
11	.2279	.2454	.2454	.1772	.1772	.2229
12	.2254	.2254	.2427	.0739	.1772	.2229
13	.2254	.2254	.2401	.1829	.1543	.2204
14	.2254	.2254	.2401	.1848	.2279	.2229
15	.2229	.2254	.2427	.1848	.2279	.2229
16	.2229	.2254	.2229	.1475	.2279	.2229
24				.0019		
Max	.2279	.2454	.2454	.1949	.2279	.2254
Min	.1254	.1715	.0554	.0019	.0732	.0739
Avg	.1881	.2054	.1948	.1382	.1398	.1553

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 206 / 11KV Dhadak LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4144	.6706	.5967	.3688	.4858	.3258
2	.4144	.6706	.7545	.3856	.4858	.3391
3	.4144	.6464	.7545	.3856	.4858	.3391
4	.4144	.6371	.7461	.3856	.5182	.3429
5	.4144	.6464	.7461	.3856	.5182	.3429
6	.4144	.6464	.7461	.3856	.5182	.3391
7	.0995	.8381	.1696	.3637	.8097	.8048
8	.4024	.8951	.6859	.8192	.8097	.8309
9	.9724	.8848	.6613	.7373	.8421	.7956
10	.9282	.9326	.6613	.7545	.8718	.7459
11	.9116	.9835	.6539	.6859	.9724	.8122
12	.8848	.9012	.663	.7042	.9724	.852
13	.8288	.9116	.6316	.7042	.8259	.8162
14	.7209	.9116	.639	.8916	.7865	.8356
15	.6962	.8048	.663	.8916	.6962	.8356
16	.663	.8619	.6167	.9945	.3688	.7865
24				.0716		
Max	.9724	.9835	.7545	.9945	.9724	.852
Min	.0995	.6371	.1696	.0716	.3688	.3258
Avg	.5996	.8027	.6493	.5832	.6855	.6340

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244084 / 33/11KV Falkewadi

Feeder No / Name : 201 / 11KV Bagni AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0366	.056	.0354	1.4373	1.1934	1.1203	.0549
2	.037	.0554	.0362	1.4373	1.0974	1.1012	.0554
3	.037	.056	.0358	1.4022	1.1111	1.085	.0549
4	.0366	.0566	.0351	1.4022	1.1561	1.0562	.0554
5	.037	.0566	.0354	1.4022	1.1702	1.0722	.0549
6	.0554	.0754	.0358	1.3599	1.1843	1.1012	.0739
7	.0739	.056	.0366	1.3763	1.2018	1.1683	.0754
8	.0732	.0537	.0362	.0549	.0895	.0716	.1075
9	2.1948	1.8884	.037	.0554	.0732	1.5684	1.8623
10	1.9433	1.9271	.0554	.0914	.0358	1.8564	1.8343
11	1.7764	1.8679	.0549	.0924	.0554	1.8564	1.7078
12	1.7204		.0739	.0914	.0724	1.7284	1.7166
13	1.6409		.0905	.0924	.0739	1.5023	
14	1.5684		.0895	.0924	.0905	1.5655	
15	1.5655		.0739	.0914	.0895	1.5813	
16		1.6964	.0716	.0739	.0914	1.5339	
17		.064	.0724	.0739	.0724	.0509	
18	.0366	.0537	.0732	.0924	.0532	.048	
19	.0554	.0732	.0739	.0934	.0739	.0648	
20	.0739	.0924	.0747	.0924	.0732	.0905	
21	.0934	.0366	.0747	.0732	.0732	.0732	
22	.0943	.0366	1.5684	1.247	1.2334	.0739	
23	.0747	.0362	1.6324	1.1683	1.2003	.0739	
24	.037	.0754	.0358	1.4373	1.1248	1.1203	.0554
Max	2.1948	1.9271	1.6324	1.4373	1.2334	1.8564	1.8623
Min	.0366	.0362	.0351	.0549	.0358	.048	.0549
Avg	.6028	.4157	.1849	.6180	.5288	.9402	.5930

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244084 / 33/11KV Falkewadi

Feeder No / Name : 202 / 11KV Ashta Chadoli Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0671	.0633	.064	.6097	.6249	.5182	.064
2	.0663	.064	.0633	.6097	.6173	.4801	.0633
3	.0663	.064	.064	.6097	.6097	.4801	.0633
4	.0671	.0633	.0648	.6173	.5792	.4641	.0625
5	.0995	.0625	.0655	.6173	.5719	.4744	.0633
6	.1006	.0949	.081	.5864	.5647	.4744	.0791
7	.0838	.096	.112	.5864	.535	.5761	.1094
8	.0678	.0791	.0819	.0594	.048	.0781	.0972
9	.9116	.8684	.0625	.0474	.0469	.7842	.7562
10	.8684	.8259	.061	.0486	.0474	.8259	.8025
11	.7468	.7865	.061	.048	.064	.7373	.7164
12	.6687		.061	.0648	.064	.7459	.7164
13	.639		.0594	.0663	.0648	.7287	
14	.587		.0594	.064	.064	.6226	
15	.6173		.0743	.0474	.0791	.7459	
16		.8122	.0743	.0663	.0791	.6325	
17		.0663	.0753	.0838	.0781	.048	
18	.0474	.0625	.0753	.0926	.0791	.064	
19	.064	.0791	.0753	.1357	.096	.0625	
20	.0791	.096	.1054	.1296	.0972	.0972	
21	.08	.0972	.0903	.112	.0949	.0995	
22	.08	.0983	.6859	.6962	.6562	.0937	
23	.0633	.0781	.7316	.6718	.6154	.0791	
24	.0663	.0625	.0633	.7869	.6478	.5668	.0633
Max	.9116	.8684	.7316	.7869	.6562	.8259	.8025
Min	.0474	.0625	.0594	.0474	.0469	.048	.0625
Avg	.2790	.2260	.1255	.3107	.2927	.4366	.2813

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244084 / 33/11KV Falkewadi

Feeder No / Name : 203 / 11KV SHIGAON RIVER AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1582	1.922	1.8446	.037	.0183	.0177	1.7364
2	2.1216	1.848	1.825	.037	.0185	.0177	1.7193
3	2.0995	1.7737	1.8267	.037	.0185	.0175	1.7375
4	2.0995	1.8107	1.8461	.037	.0185	.0179	1.7558
5	2.0851	1.829	1.8656	.0366	.0366	.0179	1.7375
6	2.1068	1.829	1.8099	.0366	.037	.0358	1.7013
7	2.0851	1.7924	1.8099	.0366	.037	.0362	1.7193
8	.0366	.037	.0549	.0366	.0366	.0362	.0549
9	.037	.0549	2.364	2.5072	2.3529	.0549	.037
10	.0358	.0554		2.6505	2.5072	.0549	.037
11		.0554	2.4356	2.7221	2.5431	.0549	.037
12			2.364	2.7069	2.4356	.0554	.037
13			2.364	2.4394	2.4434	.0554	
14			2.3282	2.3891	2.364	.0739	
15	.0554		2.2923	2.3282	2.3167	.0732	
16		.0537	2.1719	2.0774	2.2081	.0554	
17		.0537	.394	.0543	.037	.0549	
18	.0549	.0537	.037	.0549	.0366	.0554	
19	.0554	.0537	.0358	.0554	.037	.0554	
20	.056	.0537	.0366	.0549	.0366	.0549	
21	.056	.0514	.0373	.0554	.0362	.0554	
22	1.9909	1.8823	.0373	.0185	.0358	1.9022	
23	1.9753	1.8823	.037	.0185	.0177	1.9022	
24	2.1357	1.9204	1.8625	.037	.0185	.0175	1.8111
Max	2.1582	1.922	2.4356	2.7221	2.5431	1.9022	1.8111
Min	.0358	.037	.0358	.0185	.0177	.0175	.037
Avg	1.1803	.9506	1.3774	.8527	.8186	.1989	1.0862

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244084 / 33/11KV Falkewadi

Feeder No / Name : 205 / 11KV BAGNI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3696	.3292	.3292	.3395	.3696	.3292	.2926
2	.3326	.3142	.3326	.3395	.3696	.3292	.2957
3	.3292	.3174	.3292	.3395	.3292	.3326	.2957
4	.2926	.2987	.3292	.3395	.3292	.3326	.2926
5	.3326	.3174	.3292	.3772	.3696	.3511	.2957
6	.3696	.3881	.3696	.4481	.3696	.3921	.3292
7	.3696	.3921	.4066	.3547	.3696	.3326	.3142
8	.3696	.3361	.3326	.3109	.3109	.3326	.2402
9	.3292	.3696	.2686	.2772	.3142	.3142	.2328
10	.3109	.3326	.3224	.2926	.3142	.2957	.2126
11	.3142	.3326	.3403	.3326	.3361	.3326	.197
12	.3326	.3511	.3403	.3326	.3326	.3511	.197
13	.3511	.3881	.3761	.3361	.3326	.3142	
14	.3658	.3881	.4119	.3658	.3326	.3511	
15	.3696	.3696	.3841	.3696	.3547	.3511	
16	.3696	.3511	.362	.3292	.3361	.3511	
17	.3658	.3511	.3856	.3696	.3326	.3511	
18	.3658	.4066	.3856	.4024	.3326	.3881	
19	.4805	.499	.4344	.499	.4435	.4251	
20	.5175	.5544	.5544	.5175	.5041	.462	
21	.499	.5544	.5228	.5121	.4668	.462	
22	.499	.5359	.5041	.4938	.4435	.462	
23	.3841	.4251	.4527	.4572	.4108	.4066	
24	.3658	.3475	.3511	.3772	.4024	.3696	.3326
Max	.5175	.5544	.5544	.5175	.5041	.462	.3326
Min	.2926	.2987	.2686	.2772	.3109	.2957	.197
Avg	.3744	.3854	.3814	.3797	.3669	.3633	.2714

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 201 / 11 Kv Ashta Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-APR-17
HR	Load (MW)
24	1.6156
Max	1.6156
Min	1.6156
Avg	1.6156

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 202 / 11KV PATOLE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-APR-17
HR	Load (MW)
24	.192
Max	.192
Min	.192
Avg	.192

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 203 / 11 KV Ashta Gaothan 1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17
HR	Load (MW)
24	.8488
Max	.8488
Min	.8488
Avg	.8488

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 204 / 11KV BAWACHI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6867	.3606	.3395	.6573	.711	.356	.6037
2	.6847	.3517	.3174	.6394	.6973	.3446	.5923
3	.695	.3448	.3174	.615	.6534	.3284	.5933
4	.692	.3494	.3018	.6523	.6592	.3261	.5723
5	.7312	.3754	.3018	.7186	.7049	.3377	.5999
6	.8392	.4245	.3961	.8394	.7838	.4102	.6878
7	.8215	.474	.3881	.7712	.7811	.45	.6922
8	.6312	.4379	.2715	.6535	.7034	.4183	.6762
9	.5114	.3555	.2534	.5517	.5853	.3323	.5998
10	1.0265	.2954	.2353	.5221	.5412	.3535	.4862
11	.2896	.4855	.2353	.4969	.2835	.5313	.4412
12	.2766	.4908	.2149	.5224	.2713	.4856	.4298
13	.2576	.4923	.2328	.5125	.2827	.5584	.2393
14	.2629	.5479	.2507	.5213	.2839	.5523	.2446
15	.3126	.5974	.2686	.5617	.2915	.5501	.2606
16	.2882	.589	.2172	.5129	.2745	.5263	.2462
17	.2776	.5974	.2279	.5212	.2713	.5546	.2599
18	.286	.5898	.2601	.546	.2614	.4786	.266
19	.3422	.6417	.3467	.7305	.2958	.634	.2865
20	.4414	.812	.4207	.8757	.4413	.8027	.3628
21	.8162	.7819	.3856	.9023	.5054	.7258	.3742
22	.7613	.3749	.3045	.871	.4589	.6893	.3574
23	.7605	.7426	.3403	.7669	.4335	.6893	.3628
24	.4049	.388	.3547	.6778	.692	.3825	.6417
Max	1.0265	.812	.4207	.9023	.7838	.8027	.6922
Min	.2576	.2954	.2149	.4969	.2614	.3261	.2393
Avg	.5457	.4959	.2993	.6517	.4945	.4924	.4532

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 205 / 11 KV Bawachi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4443	.2204	.1867	2.7435	2.3922	1.2688	.3887
2	.4597	.2227	.2075	2.6943	2.412	1.0067	.4081
3	.4459	.2217	.2075	2.6416	2.3685		.4089
4	.4274	.2278	.1867	2.6174	2.376		.3898
5	.4744	.2486	.2054	2.6585	2.3861		.4081
6	.5354	.286	.2641	2.7709	2.5252		.5324
7	.5537	.2948	.2614	2.9043	2.685		.4977
8	1.233	.8862	.2172	.3593	.3726		1.0845
9	3.7523	2.09	.1791	.3704	.381		3.4514
10	3.8218	2.1339	.197	.3498	.3772	2.0188	3.7344
11	2.2339	3.3981	.1991	.3849	.2004	3.3318	3.7097
12	2.1323	3.4225	.197	.3757	.2119	3.2236	3.6298
13	.8429	3.2366	.1949	.3961	.2383	3.344	1.957
14	1.6954	3.2164	.1949	.3898	.2314	3.2571	1.6255
15	1.8244	3.1527	.1949	.3902	.2121	3.075	1.6743
16	1.8139	2.998	.197	.378	.1986	2.9546	1.2986
17		.3117	.1734	.4214	.2284	.3376	.1951
18	.209	.3428	.1734	.4351	.2259	.342	.2088
19	.2339	.4481	.2254	.4763	.2658	.4213	.2431
20	.2842	.4864		.5502	.2921	.4871	.2507
21	.2814	.4886	.2454	1.0821	.6746	.4664	.2606
22	.2791	.234	1.1904	2.5011	1.44	.4436	.2652
23	.2501	.4134	1.478	2.6216	1.4066	.4228	.2469
24	.2278	.2479	.2054	1.6396	2.2249	.2926	.4054
Max	3.8218	3.4225	1.478	2.9043	2.685	3.344	3.7344
Min	.209	.2204	.1734	.3498	.1986	.2926	.1951
Avg	1.0633	1.2179	.3036	1.3397	1.0970	1.5702	1.1364

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 206 / 11KV Ashta Pump House

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8413	.0896	.7682	.8596	.7602	.076	.7964
2	.823	.0878	.7499	.8413	.724	.0724	.7964
3	.7865	.0841	.7316	.8413	.695	.0742	.7682
4	.7682	.0841	.7316	.8596	.695	.0778	.7316
5	.7865	.086	.7133	.8413	.7133	.0796	.7499
6	.8048	.0914	.7865	.8413	.7316	.0796	.7865
7	.9511	.0951	.823	.8596	.7682	.0814	.8048
8	.8048	.0896	.8413	.823	.7602	.0778	.8048
9	.7499	.0732	.8048	.695	.724		.6335
10	.695	.0786	.8048	.6767	.724	.0688	.7316
11	.0695	.9328		.695	.0742	.8048	.7682
12	.0658	.9328	.8962	.6767	.0706	.8596	.7499
13	.0695	.8779	.823	.6767	.076	.823	
14	.0732	.8596	.7865	.7316	.0833	.7682	
15	.0786	.8413	.823	.7316	.076	.7316	
16	.0823	.8048	.8962	.7499	.076	.7499	
17	.0786	.8596	.8596	.823	.0724	.7421	
18	.0841	.9145	.8413	.8596	.076	.7602	
19	.1079	1.0791	1.0425	.9877	.0887	.9593	
20	.1189	1.1888	1.1706	1.0608	.1032	1.0317	
21	1.1523	1.0974	1.0974	1.0317	.0977	1.0059	
22	1.1157		1.1157	.9412	.0923	1.0608	
23	.1024	.9145	.9694	.8688	.0887	.905	
24	.0786	.0988	.823	.8779	.7964	.0833	.8145
Max	1.1523	1.1888	1.1706	1.0608	.7964	1.0608	.8145
Min	.0658	.0732	.7133	.6767	.0706	.0688	.6335
Avg	.4704	.5331	.8652	.8271	.3820	.5206	.7643

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244124 / 33/11KV KOREGAON SUBSTATION

Feeder No / Name : 201 / 11KV KOREGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8078	.8545	.3961	.8479	.8253	.7712	.7737
2	.7533	.825	.3772	.8047	.7943	.7289	.7465
3	.7503	.7804	.3772	.8002	.7655	.7149	.7396
4	.6975	.7788	.3772	.804	.764	.7499	.757
5	.8042	.8656	.3961	.9206	.8089	.8082	.7669
6	1.0218	1.0379	.5415	1.166	.9259	1.0267	.9815
7	1.1812	1.1315	.5121	1.1416	1.028	1.0692	.9753
8	.9172	.9566	.4119	.9088	.881	.8871	.841
9	.8149	.8577	.3641	.7909	.7865	.713	.7346
10	.8084	.7949	.3429	.807	.7819	.7384	.6366
11	.8072	.8017	.3429	.8122	.7503	.7731	.7121
12	.7834	.9063		.7729	.6732	.6733	.591
13	.4359	.8086	.4031	.7301	.6929	.6893	.3376
14	.8573	.8061	.4252	.7621	.7259	.7428	.3589
15	.8619	.8608	.4298	.7524	.7112	.7636	.4108
16	.8737	.8143	.4207	.7682	.7329	.7382	.3742
17	.8749	.8234	.4207	.7457	.7529	.7361	.3544
18	.9391	.8526	.4161	.8381	.7312	.8512	.4351
19	1.1515	.9469	.543	1.0041	.8882	1.0625	.487
20	1.304	1.3763	.6468	1.1845	1.1715	1.2529	.567
21	1.2178	1.3146	.6348	1.2169	1.1526	1.1816	.5883
22	1.1797	1.2603	.5601	1.1591	1.0579	1.0732	.5914
23	.9924	1.0463	.4854	.9721	.9136	.9309	.5129
24	.8627	.8936	.4338	.8806	.7979	.8184	.8207
Max	1.304	1.3763	.6468	1.2169	1.1715	1.2529	.9815
Min	.4359	.7788	.3429	.7301	.6732	.6733	.3376
Avg	.9041	.9331	.4460	.8996	.8381	.8539	.6289

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244124 / 33/11KV KOREGAON SUBSTATION

Feeder No / Name : 202 / 11KV Bhadurwadi AG
(Koregaon) Feeder KV- 11 /
OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.428	2.1371	.8993	.2206	.2187	.1981	2.1602
2	2.3228	2.0325	.8535	.2214	.2168	.1784	2.0037
3	2.1961	1.9769	.8333	.2423	.1981	.0975	1.8917
4	2.1186	1.9589	.8488	.2484	.192	.096	1.8096
5	2.0775	1.9054	.8642	.2484	.1896	.1292	1.8073
6	2.1979	1.9997	.4374	.2601	.2214	.2057	2.002
7	2.2504	2.1109	.9755	.2819	.2362	.2206	2.1856
8	.2332	.2095	.0503	.4237	.3504	.2789	.2473
9	.1894	.2191	1.3763	3.2709	2.926	.2348	.2489
10	.1973	.2245	1.3435	3.3608	3.0485	.2576	.2511
11	.1948	.2283	1.4074	3.3379	3.0645	.2507	.2386
12		.0861		3.2485	2.9904	.1973	
13			1.174	3.1318	2.8896	.1911	
14	.0114		1.2498	2.9523	2.8041	.1935	
15	.2052		1.3117	2.8262	2.6924	.2225	.093
16	.0122	.2521	1.1443	2.809	2.6888	.2483	.1196
17		.2927	.104	.2092	.1878	.2553	.1212
18	.2829	.2599	.1478	.2182	.2165	.2423	.1273
19	.2934	.2629	.132	.2378	.2256	.237	.1372
20	.3064	.2728	.1307	.2771	.229	.2282	.1456
21	.3734	.381	.1307	.2316	.232	.4064	.192
22	2.324	2.2634	.1307	.1995	.2313	2.5218	1.3451
23	2.3514	2.3053	.128	.2202	.2088	2.4322	1.326
24	2.3369	2.3156	.9568	.2161	.2191	1.3754	2.2329
Max	2.428	2.3156	1.4074	3.3608	3.0645	2.5218	2.2329
Min	.0114	.0861	.0503	.1995	.1878	.096	.093
Avg	1.1859	1.1283	.7230	1.2039	1.1116	.4541	.9850

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244124 / 33/11KV KOREGAON SUBSTATION

Feeder No / Name : 203 / 11KV Koregaon AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0452	.0332	.048	1.7185	1.3441	1.5203	.0282
2	.0463	.0332	.048	1.7185	1.3441	1.5565	.0282
3	.0474	.0335	.0492	1.7236	1.3123	1.7741	.0282
4	.0492	.0335	.0532	1.7444	1.2498	1.6244	.0423
5	.0655	.0503	.0532	1.6804	1.2498	1.6385	.0423
6	.0648	.0509	.0549	1.6484	1.2963	1.6876	.0335
7	.064	.0509	.0716	1.6358	1.3117	1.6762	.048
8	.0753	.0372	.0503	.0492	.0497	.0326	.0486
9	2.2348	2.1285	.048	.0469	.0312	2.1765	2.2558
10	2.3644	2.343	.0434	.0282	.0274	2.3758	2.3525
11	2.4086	2.2184	.044	.0312	.0274	2.3205	2.3482
12	2.4366			.0389	.0372	2.3482	2.3205
13	2.0778		.0394	.0372	.048	2.2834	
14	2.1125		.04	.0236	.0423	2.1765	
15	2.0243		.0406	.0271	.0423	2.1538	
16		2.0485	.0326	.0316	.0406	2.0965	
17		.0251	.04	.0305	.0465	.0423	
18	.0587	.036	.044	.0271	.0349	.04	
19	.0564	.0486	.048	.04	.04	.0297	
20	.04	.0457	.0486	.0389	.0389	.0486	
21	.0452	.0648	.0497	.0316	.0377	.0446	
22	.0328	.0503	1.8343	1.3757	1.5684	.0339	
23	.0332	.0486	1.8027	1.3748	1.4687	.0309	
24	.0446	.0328	.0503	1.7497	1.3426	1.5364	.0282
Max	2.4366	2.343	1.8343	1.7497	1.5684	2.3758	2.3525
Min	.0328	.0251	.0326	.0236	.0274	.0297	.0282
Avg	.7467	.4707	.2015	.7022	.5847	1.3020	.7388

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 201 / 11KV MARDWADI 1PH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.3048	1.4213	1.2041	.2858	.2972
2	.2629	.2782	1.3527	1.1698	.2782	.282
3	.2629	.2896	1.307	1.0936	.282	.282
4	.2667	.2858	1.2917	1.086	.2782	.2743
5	.2705	.2858	1.2689	1.0631	.282	.2667
6	.2934	.2972	1.307	1.0936	.2934	.2743
7	.3086	.3239	1.5813	1.3756	.3125	.2972
8	.2477	.2667	.6744	.4572	.2553	.2362
9	1.8252	1.8861	.1715	.202	1.8519	2.1148
10	2.0767	2.0462	.1638	.1677	2.1605	2.2939
11	2.1338	2.1224	.1715	.1829	2.1872	2.2862
12	2.0652	2.1948	.1753	.1753	2.3358	2.3053
13	2.0805	.6821	.2172	.1905	2.3129	2.2519
14		2.0157	.2172	.2134	2.2405	2.2443
15	1.7528	2.0652	.2134	.2324	2.1643	2.1186
16	.9488	2.0424	.2172	.2248	2.1033	2.0309
17		.5639	.2172	.2096	.6401	.7087
18	.301	.2134	.1981	.2134	.1867	.1905
19	.2782	.2401	.2401	.2058	.1905	.2248
20	.3772	.3391	.3544	.3353	.3315	.3315
21	.3734	.3506	.3696	.3544	.3544	.3544
22	.3772	1.2498	1.1965	.3544	.3582	.3467
23	.3582	1.3375	1.3184	.3544	.3467	.3467
24	.3201	1.2917	1.3146	.3125	.3086	.301
Max	2.1338	2.1948	1.5813	1.3756	2.3358	2.3053
Min	.2477	.2134	.1638	.1677	.1867	.1905
Avg	.7934	.9572	.7067	.5197	.9309	.9442

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 202 / 11KV KARANDWADI 1PH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.644	.6668	1.768	1.3108	.6516	.6668
2	.6211	.6478	1.5813	1.2117	.6401	.6401
3	.6097	.6363	1.4556	1.1812	.6249	.6401
4	.6097	.6249	1.406	1.1355	.6173	.6325
5	.6363	.6478	1.4098	1.185	.6249	.6363
6	.7354	.7392	1.5394	1.3832	.7202	.6744
7	.7545	.7354	1.989	1.9204	.6973	.6668
8	.5258	.5601	.6554	.5563	.5144	.5906
9	2.5682	2.9759	.423	.4839	2.6025	2.713
10	3.2846	3.155	.3925	.4382	2.6558	.0267
11	3.2998	3.2998	.4001	.442	3.315	
12	3.1664	3.1893	.4992	.4649	1.9585	
13	2.774	2.8578	.5296	.522	3.5208	2.4044
14		2.7397	.5487	.5601	3.3379	3.1283
15	2.431	2.5644	.602	.5716	3.2541	3.2884
16	.7964	2.6406	.5944	.5792	3.1436	3.235
17	.0381	.5068	.5525	.5601	.6363	2.7816
18	.6249	.503	.4763	.5487	.4915	2.5758
19	.663	.6135	.6249	.6211	.5868	.5906
20	.9297	.9259	.964	.884	.8764	.8269
21	.9412	.9069	.9259	.8802	.8878	.8497
22	.9145	1.5737	.4954	.9107	.9031	.8269
23	.8535	1.6347	1.4822	.8688	.8459	.7926
24	.7202	1.4937	2.0501	.7011	.7202	.6897
Max	3.2998	3.2998	2.0501	1.9204	3.5208	3.2884
Min	.0381	.503	.3925	.4382	.4915	.0267
Avg	1.2670	1.5350	.9736	.8300	1.4511	1.3581

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 204 / 11 KV FALKEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3734	3.6046	2.9797	.3582	.3887
2	.3658	.3582	3.4827	2.8807	.3506	.3734
3	.3658	.3582	3.0178	2.7664	.3429	.3734
4	.3658	.3582	2.8502	2.6825	.3506	.381
5	.3887	.3734	2.8807	2.7664	.3582	.3887
6	.442	.4725	3.2465	3.0102	.4191	.4572
7	.4649	.4877	3.9476	3.2846	.4572	.4725
8	.4191	.4725	1.1888	.7011	.4115	.4725
9	4.1457	4.6487	.3887	.3277	3.597	3.6656
10	4.9459	2.271	.3125	.3201	3.597	4.8316
11	4.8621	2.2177	.2362	.2896	3.9781	4.4734
12	4.5344	2.0729	.2439	.282	2.7664	1.9814
13	4.1533	1.7299	.2515	.2896		1.6004
14		3.3913	.3048	.3048		3.7494
15	3.3455	4.0543	.3048	.2972	4.2295	3.9095
16	1.4937	4.2143	.2972	.2896	4.3743	4.161
17			.221	.282	.7621	.9983
18	.3201		.2896	.2972	.2743	.282
19	.3582		.3048	.3201	.3429	.3201
20	.5411	.602	.4954	.4877	.4954	.4877
21	.5335	.5944	.503	.4877	.5182	.4877
22	.503	3.4827	3.2541	.4725	.5106	.4801
23	.4649	3.7418	3.5361	.442	.4572	.4572
24	.4191	3.6199	3.8371	.381	.4191	.381
Max	4.9459	4.6487	3.9476	3.2846	4.3743	4.8316
Min	.3201	.3582	.221	.282	.2743	.282
Avg	1.5366	1.8998	1.6250	1.1101	1.3350	1.4822

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 403 / 33 KV Walwa

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	21.5707	24.8286	***	***	29.9383	25.103
2	20.3361	22.4966	***	***	28.6694	23.0795
3	19.3759	21.1591	***	29.2182	19.2044	21.9822
4	19.0672	20.6448	***	29.0124	18.7243	21.2963
5	19.273	21.1934	***	29.3554	18.8271	21.2963
6	21.5021	23.6969	***	***	21.0905	23.4911
7	25.8231	27.8807	***	***	23.6283	26.8862
8	17.5583	19.4788	18.1756	18.3471	16.2209	18.2099
9	***	***	29.561	29.1153	25.1715	***
10	***	***	***	***	***	***
11	***	***	***	29.1839	***	***
12	***	***	***	29.1153	***	***
13	***	24.1427	28.3952	28.1208	***	***
14	29.5954	21.5707	26.9205	25.5144	26.9205	***
15	***	21.605	26.6461	25.2743	***	***
16	***	***	26.3717	25.0001	***	21.6735
17	14.5062	18.3471	18.6557	18.93	16.118	14.9863
18	15.2607	17.7297	17.5927	16.8724	16.7352	13.7174
19	16.9753	18.6901	20.0617	19.273	18.4843	15.6036
20	20.3361	22.3937	22.3594	22.4966	21.7079	18.5186
21	20.6105	21.8451	22.5309	22.085	21.2963	18.1413
22	29.2868	26.6461	***	***	***	27.332
23	29.9726	26.6461	***	***	***	26.6461
24	27.1606	24.1426	***	***	28.1208	23.4568
Max	37.3114	41.0495	37.8602	35.4596	38.889	38.3402
Min	14.5062	17.7297	17.5927	16.8724	16.118	13.7174
Avg	25.7531	25.6145	28.8384	27.5135	26.3775	25.3258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 404 / 33KV Kasbe Digraj

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-APR-17
HR	Load (MW)
24	1.9136
Max	1.9136
Min	1.9136
Avg	1.9136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 405 / 33 KV Nagaon

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-APR-17
HR	Load (MW)
24	1.1694
Max	1.1694
Min	1.1694
Avg	1.1694

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 406 / 33 KV LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	01-APR-17
HR	Load (MW)
24	.7442
Max	.7442
Min	.7442
Avg	.7442

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 407 / 33 KV Kasturi

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.1097	15.0206	15.9465	16.1523	16.5638	16.358
2	3.9438	16.6324	17.4554	16.0837	15.9808	16.701
3	7.3388	14.4719	16.6667	17.2497	17.2154	17.3869
4	6.0014	15.7751	16.6667	17.5583	16.9067	17.1811
5	4.9726	16.6667	16.5981	16.3238	16.5981	16.4266
6	7.6475	14.2318	16.8039	17.1468	17.0439	17.1468
7	9.3279	12.62	17.2497	16.8039	16.9067	17.1125
8	7.9561	14.2318	16.358	16.701	15.0206	16.3923
9	9.3622	15.535	15.9808	16.9067	16.0151	7.5789
10	10.6653	15.6036	15.9465	17.4211	11.8313	2.1948
11	12.6886	15.8436	10.9397	14.9863	14.6091	1.9547
12	14.8834	16.3238	13.2373	16.358	16.4266	1.9204
13	12.4486	14.5405	14.6777	15.9808	14.6091	1.9547
14	12.4486	15.6722	15.9465	16.0151	16.118	1.9547
15	13.2373	16.2209	16.0494	15.3292	15.0892	1.9204
16	11.8656	16.8725	15.8779	14.369	15.4664	1.9547
17	15.2949	15.9465	15.4321	16.7353	16.9753	2.1948
18	14.3347	16.4952	14.952	17.4897	15.535	2.2291
19	15.8436	16.8382	16.5981	16.5638	15.0892	2.2291
20	15.6379	16.941	16.3923	17.0439	14.4033	2.2634
21	14.712	13.8203	15.8093	15.6036	14.9177	2.2634
22	15.8436	15.6036	14.8491	15.6036	15.8436	2.4006
23	16.4952	15.0549	16.2209	14.4033	15.5007	3.7037
24	15.5693	14.0947	19.9452	15.7751	15.0549	3.738
Max	16.4952	16.941	19.9452	17.5583	17.2154	17.3869
Min	3.9438	12.62	10.9397	14.369	11.8313	1.9204
Avg	11.4012	15.4607	15.9417	16.2752	15.6550	7.3817

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 201 / 11 KV ISLAMPUR-I FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8671	1.9044	1.848	1.885	1.9044	1.8671	1.9044
2	1.8111	1.7924	1.7551	1.8671	1.8298	1.8298	1.8298
3	1.7741	1.7177	1.7364	1.8298	1.8298	1.8298	1.7177
4	1.7551	1.7177	1.7177	1.7924	1.8298	1.8107	1.7177
5	1.8298	1.7741	1.7372	1.8656	1.8298	1.7926	1.7551
6	2.0538	1.9387	1.9589	2.0119	1.8671	1.922	1.8671
7	1.9589	1.8823	1.9387	1.9022	1.7924	1.885	1.7551
8	1.829	1.7375	1.7558	1.7372	1.7741	1.6827	1.6804
9	1.8111	1.6827	1.7193	1.7372	1.6263	1.5524	1.5893
10	2.1719	2.1216	2.1357	2.0271	2.0271	2.0485	
11	2.0119	1.3306	1.9185	1.7924	1.8099	1.8656	
12	2.0271	1.9547	2.0633	1.5565	1.9022	1.9387	2.1132
13	2.0633	2.0485	2.0119	1.5893	1.922	2.0119	
14	2.1437	2.1807	2.0633	2.1948	1.9589	2.0119	
15	2.268	2.1849	2.0851	2.2177	1.9959	2.1068	
16	2.1068	2.1285	2.0119	2.1807	1.9387	2.0328	
17	1.2803	1.9791	2.0851	2.1582	1.9753	1.9959	
18	2.0485	2.0328	2.0485	1.9547	1.9022	1.9959	
19	2.7633	2.809	2.6703	2.4143	2.7069	2.6981	2.6612
20	1.2986	2.6242	2.6337	2.6703	2.5873		2.524
21	2.5606	2.524	2.5606	2.5133	2.4272	2.5873	2.3777
22	2.4143	2.3777	2.5606	2.3655		2.4394	2.3655
23	2.2177	2.2177	2.2916	2.2546	2.2032	2.2405	2.2032
24	2.0538	1.9791	1.9589		2.0328	2.0165	1.9791
Max	2.7633	2.809	2.6703	2.6703	2.7069	2.6981	2.6612
Min	1.2803	1.3306	1.7177	1.5565	1.6263	1.5524	1.5893
Avg	2.0050	2.0267	2.0528	2.0225	1.9858	2.0070	2.0025

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 202 / 11 KV Peth Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0456	1.0349	1.0269	1.1203	1.0082		1.0719
2	1.0185	.9979	.9997	1.0456	.9709	.8215	1.0456
3	.924	.924	.961	.9979	.9709	.7842	.961
4	.8779	1.0974	.924	.9979	.9709	.7762	.9709
5	.9877	1.0974	1.0456	1.0349	.9709	.8131	1.0082
6	1.1458	1.2197	1.2197	1.2071	1.0562	1.1203	1.1458
7	.9979	1.1576	1.1088	1.1088	1.0562	1.1203	1.0829
8	.8779	1.0456	.9979	.9979	.9431	.9335	.9709
9	.8954	.9955	.961	.9877	.8688	.8326	.8413
10		.9412	1.086	1.0029	.9568	.8859	
11		.9774	1.086	1.086	.9922	.9568	
12	1.2048	1.0136	1.0136	1.086	.9568	.9568	.9671
13	.9671	1.0387	1.0974	1.1222	.8954	.9774	
14	.9979	1.0349	.9412	1.0242	.8779	.924	
15	1.086	1.134	1.0242	.8589	.9412	1.0608	
16	1.0498	1.0136	1.0136		.8596	.9145	
17	1.134	1.086	.9877	1.0242	.9313	1.0349	
18	1.0349	1.0242	1.0242	1.0719	.905	.961	
19	1.6263	1.39	1.2803	1.3443	1.3535	1.3306	
20	1.6263	1.5524	1.6095	1.3443	1.4998		
21	1.5154	1.4998	1.5364	1.531	1.5154	1.5893	
22	1.4415	1.4266	1.4632	1.419	1.3676	1.4118	
23	1.2323	1.1827	1.2437	1.1949	1.1949	1.2437	
24	1.0829	1.0608	1.0829	1.1088	1.1203	1.094	1.1088
Max	1.6263	1.5524	1.6095	1.531	1.5154	1.5893	1.1458
Min	.8779	.924	.924	.8589	.8596	.7762	.8413
Avg	1.1259	1.1227	1.1139	1.1181	1.0493	1.0247	1.0159

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 203 / 11 KV LIS FEEDER

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.094	.9114	1.0456	1.0166		1.0082
2	1.1317	.9465	1.1694	1.0517		.2743
3	1.1694	1.1462	1.2071	1.0517		.2743
4	1.1694	1.1462	1.2449	1.0974		.2743
5	1.1949	1.1462	1.2323	1.0974		.2774
6	1.2449	1.134	1.2449	.3224		.2774
7	1.2449	1.0867	1.3203	.2865		.2774
8	1.2323	1.1218	1.307	.2896		.3772
9	1.2936	1.2197	1.2696	.2926		1.1576
10	1.2567	1.2567	1.2936	.2987		1.2567
11	1.2936	1.2197	1.2567	.2926		1.1458
12	1.2197	1.1827	1.1827	.2926	1.0719	1.1827
13	1.1088	1.1458	1.1827	.9979	1.2567	1.1827
14	.3429	1.1827	1.1576	1.1458	1.1827	1.1458
15	.3647	1.1827	1.1949	1.1827	1.1827	1.1827
16	.2957	.3856	.0652	.3395	.2641	.4904
Max	1.2936	1.2567	1.3203	1.1827	1.2567	1.2567
Min	.2957	.3856	.0652	.2865	.2641	.2743
Avg	1.0411	1.0884	1.1484	.6910	.9916	.7366

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 204 / 11 KV ISLAMPUR-II FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1848	.1867	.2195	.2054	.1886	.2218
2	.1848	.1848	.1848	.2218	.2054	.1886	.1848
3	.1867	.1829	.1848	.1829	.2054	.1867	.1848
4	.1886	.1829	.1848	.1829	.2054	.1867	.1848
5	.1867	.181	.1867	.1848	.2054	.1867	.1867
6	.2241	.181	.2241	.2195	.2263	.2241	.1848
7	.1867	.181	.2218	.1848	.2075	.1867	.1867
8	.1478	.181	.1848	.1848	.1867	.1867	.1867
9	.1417	.1402	.1629	.1463	.1433	.1772	.1075
10	.1417	.1417	.1417	.1417	.1417	.1417	
11	.1402	.1595	.1772	.1417	.1402	.1402	
12	.1417	.181	.1402		.1402	.1402	.1543
13	.1433	.1402	.1612		.1433	.1402	.1595
14	.1387	.181	.1829		.1463	.1433	.1448
15	.181	.1448	.181		.1463	.1448	.1829
16	.156	.1433	.1791		.1448	.1463	.1463
17	.1791	.1791	.1829	.1448	.181	.1463	.1829
18	.1791	.181	.1829	.1448	.181	.1478	.1478
19	.2195	.2172	.2172	.2587	.2195	.2218	.2587
20	.2561	.2561	.2534	.2587	.2587		.2587
21	.2561	.2614	.2561	.2801	.2587	.2587	.2614
22	.2561	.2614	.2561	.2614	.2587	.2587	.2614
23	.2195	.2241	.2561	.2427	.2241	.2587	.2614
24	.2241	.1848	.2241	.1463	.2241	.2241	.2218
Max	.2561	.2614	.2561	.2801	.2587	.2587	.2614
Min	.1387	.1402	.1402	.1417	.1402	.1402	.1075
Avg	.1861	.1857	.1964	.1973	.1916	.1837	.1941

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 205 / 11 KV ISLAMPUR AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0191	.1974	.3155	.2606	.0377	.0381
2	.0189	.0191	.1669	.2804	.2115	.0189	.0381
3	.0189	.0187	.1669	.2534	.2115	.0189	.0381
4	.0377	.0191	.1669	.2454	.2115	.0187	.0381
5	.0373	.0191	.1692	.2804	.2286	.0187	.0381
6	.0377	.0373	.2256	.3292	.2675	.0373	.0381
7	.0377	.0362	.2256	.3292	.2715	.0373	.0381
8	.0373	.0373	.0351	.0366	.0377	.037	.0572
9	.4111	.3963	.0381	.0179	.0373	.3437	.4428
10	.4012	.3704	.0381	.0181	.0373	.3437	
11	.3963	.3658	.0381	.037	.0179	.3311	
12	.3864	.3567	.0191	.037	.0377	.3353	
13		.2972	.0191	.0377	.0377	.3567	
14	.3086	.2934	.0381	.0377	.0377	.3612	
15		.2675	.0191	.0377	.0943	.3185	
16	.2709	.2256	.0191	.0377	.0373	.2934	.3125
17	.0373	.0183	.0191	.0377	.0377	.0373	.0377
18	.0373	.037	.0191	.0377	.0377	.0373	.0377
19	.0373	.037	.0381	.0377	.0377	.0373	.0373
20	.0373	.0377	.0373	.0377	.0373		.0377
21	.0373	.0373	.0373	.0377	.0373	.0373	.0373
22	.0373	.1947	.3224	.3125	.037	.0373	.0373
23	.0373	.1947	.3544	.2934	.0377	.0373	.0185
24	.0373	.0187	.1974		.2606	.0377	.0373
Max	.4111	.3963	.3544	.3292	.2715	.3612	.4428
Min	.0189	.0183	.0191	.0179	.0179	.0187	.0185
Avg	.1235	.1398	.1086	.1359	.1067	.1378	.0756

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 201 / 11 KV MIDC FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6484	2.3906	1.0288	2.7335	2.9859	2.8212	2.5824
2	1.7437	2.3846	.9145	2.7663	2.8548	2.8037	2.4691
3	1.669	2.3503	.9145	2.7511	2.8205	2.6482	2.4242
4	1.7124	2.399	.9145	2.6337	2.9226	2.6459	2.3076
5	1.6385	2.4006	.9907	2.7343	2.7888	2.633	2.239
6	1.8282	2.3548	1.2574	2.8585	2.8589	2.5728	2.2839
7	1.957	2.5133		2.8075	2.6943	2.7823	2.1674
8	1.9814	2.476	1.1812	2.604	2.7526	2.5636	1.7117
9	2.6818	2.9767	1.6004	3.0804	3.0941	2.8731	1.3649
10	3.5437	3.1993	1.6766	3.9795	3.7159	3.6286	1.1378
11	3.5376	3.36	2.037	4.3918	3.786	3.9746	1.1698
12	3.5947	3.8333	2.037	4.5032	3.9735	4.2494	.6615
13	3.7144	3.6984	1.829	3.9499	3.8241	3.7106	.6562
14	3.6191	3.5094	1.8861	4.2188	3.3836	3.6188	.6523
15	3.6313	3.7647	1.9616	4.3286	3.6252	4.3659	.6584
16	3.6565	3.6153	1.9814	4.2691	3.7358	4.1403	.6607
17	3.469	3.2487	1.7147	4.0958	3.5559	3.8516	.6302
18	3.2053	3.1988	1.6766	3.9864	3.6222	3.2465	.6234
19	2.8418	3.0796	1.6766	2.6943	3.4073	2.9351	.6165
20	2.7313	2.9721	1.4098	2.9785	3.0941	2.8243	.6821
21	2.5179	2.4348	1.4098	2.9454	2.6551	2.4306	.804
22	2.7526	2.4783	1.448	3.0849	2.7382	2.5103	.8276
23	2.6825	2.4577	1.3717	3.062	2.7397	2.4691	1.5691
24	2.0546	2.4402	2.037	1.5806	2.8296	2.7625	2.1513
Max	3.7144	3.8333	2.037	4.5032	3.9735	4.3659	2.5824
Min	1.6385	2.3503	.9145	1.5806	2.6551	2.4306	.6165
Avg	2.6839	2.8974	1.5198	3.2933	3.1858	3.1276	1.3771

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 202 / 11 KV SAKHRALE GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3925	.3483	.1494	.3613	.3756	.3567	.3574
2	.3468	.3407	.1494	.3521	.3657	.3475	.3445
3	.3506	.3361	.1494	.3475	.3634	.3513	.3407
4	.3498	.3399	.1867	.3951	.3641	.3544	.3407
5	.3902	.4321	.2054	.4798	.3817	.3582	.3407
6	.557	.49	.2614	.5293	.4747	.4462	.4199
7	.5366	.5106		.5514	.5067	.5372	.4695
8	.4321	.3955	.1867	.405	.4199	.3963	.3674
9	.3437	.3368	.1494	.3414	.3759	.3269	.3293
10	.3178	.3646	.1494	.3323	.3346	.3231	.3071
11	.2802	.3776	.1494	.3147	.3399	.3208	.3026
12	.2949	.389	.1494	.3361	.3292	.3232	.2942
13	.3232	.3786	.1494	.3185	.3346	.333	.1608
14	.3134	.3536	.1494	.3483	.3361	.3216	.1661
15	.2992	.3361	.1494	.3795	.3285	.3231	.1593
16	.3315	.3277	.1494	.346	.3111	.33	.1616
17	.3346	.3453		.3559	.3407	.3269	.1623
18	.3345	.3384		.3467	.37	.3486	.1715
19	.4222	.4184	.2241	.4618	.4237	.3925	.1791
20	.5399	.5175	.2801	.572	.5128	.5137	.2667
21	.4774	.5099	.2241	.5015	.5045	.5167	.2439
22	.2926	.484	.2241	.4802	.4915	.4878	.2561
23	.4358	.4458	.1867	.4755	.4793	.4534	.4816
24	.4153	.3673	.168	.2202	.3992	.406	.375
Max	.557	.5175	.2801	.572	.5128	.5372	.4816
Min	.2802	.3277	.1494	.2202	.3111	.3208	.1593
Avg	.3797	.3952	.1805	.3980	.3943	.3831	.2916

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 203 / 11 KV BAHE AG FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2104	2.1491	.0171	.0171	.0189	1.9833	2.3799
2	2.1544	2.0873	.0171	.0171	.0185	1.949	2.2771
3	2.0915	2.0553	.0171	.0171	.0185	1.9342	2.2428
4	2.0572	2.0508	.0171	.0171	.0185	1.941	2.221
5	2.0321	2.0668	.0171	.0171	.0185	1.9993	2.2713
6	2.1144	2.1148	.0171	.0171	.0185	2.2736	2.3079
7	2.3899	2.3296		.0171	.0185	2.3845	2.532
8	.3635	.2384	.0171	.0194	.0185	.3253	.4686
9	.0171	.0189	1.6129	1.8278	3.2316	.02	.0171
10	.0183	.0189	1.5813	3.5825	3.2716	.0171	.0185
11	.0183	.0189	1.5497	3.4408	3.2099	.0171	
12			1.4232	2.9801	3.1699	.0171	
13			1.4232	2.8292	2.9459	.0171	
14			1.2651	2.8166	2.8304	.0171	
15	.0189	.0189		2.8212	2.6829	.0171	
16	.0189	.0189		2.7406	2.6566	.0171	
17	.0189	.0925	.0171	.251	.2029	.0194	.008
18	.0646	.088	.0171	.0185	.0189	.0171	
19	.036	.112	.0171	.0185	.0189	.0182	
20	.1069	.1566	.0171	.0185	.0189	.0171	
21	.1355	.1406	.0171	.0185	.0372	.0171	.0011
22	2.4965	.136	.0017	.0185	2.1948	2.6532	1.406
23	2.5491	.0171		.0185	2.2223	2.7355	2.58
24	2.4108	1.0059	.0171	.0171	1.1605	2.2896	2.5503
Max	2.5491	2.3296	1.6129	3.5825	3.2716	2.7355	2.58
Min	.0171	.0171	.0017	.0171	.0185	.0171	.0011
Avg	1.1106	.8064	.4540	.9815	1.2509	.9457	1.5521

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 204 / 11 KV DUDH SANGH FEEDER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8732	1.0042	.381	.7845	1.0597	.9168	.9819
2	.7693	1.0089	.381	.7769	1.0015	.9473	.9417
3	.7329	.9901	.3429	.7304	.9901	.8804	.8849
4	.7266	.9868	.3429	.7217	.9684	.8985	.8899
5	.7249	.9613	.3048	.7053	.8284	.8672	.8036
6	.7159	.9244	.2477	.644	.821	.8167	.8067
7	.6817	.8		.5482	.6886	.7638	.6396
8	.6661	.6588	.2477	.5359	.6047	.6626	.587
9	.7819	.8307	.3429	.959	.8903	.8272	.919
10	1.1132	.904	.4191	1.1704	1.0991	.9896	1.1033
11	1.3333	1.0391	.5525	1.3068	1.2691	1.25	1.2504
12	1.0596	1.1063	.5716	1.2542	1.2973	1.2298	1.1105
13	1.0587	1.0408	.4001	1.1496	1.1991	1.0597	.6129
14	1.0541	.8754	.381	1.0389	1.0722	.981	.57
15	1.0372	.8301	.381	1.0318	1.0343	1.033	.562
16	.9459	.7263	.2858	.9446	.9427	.9358	.4833
17	.9065	.703	.3429	.9511	1.0107	.8411	.4601
18	.9215	.7383	.3429	1.0429	1.09	.9591	.4803
19	.927	.6428	.362	1.0655	1.108	.9844	.4693
20	.8385	.6569	.3429	.8633	1.0882	.8824	.5624
21	.758	.7883	.381	.9755	1.0957	.8379	.5163
22	.9127	.7927	.381	1.0079	.9448	.8659	.5035
23	1.0054	.6794	.362	1.0212	1.0277	1.0831	.9387
24	.9939	.9535	.3429	.5447	1.03	1.0071	.9958
Max	1.3333	1.1063	.5716	1.3068	1.2973	1.25	1.2504
Min	.6661	.6428	.2477	.5359	.6047	.6626	.4601
Avg	.8974	.8601	.3669	.9073	1.0067	.9384	.7530

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 205 / 11 KV NAGARPALIKA PWW
FEEDER Feeder KV- 11 /
OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8169	.4195	.4382	.8375	.8391	.8387	.813
2	.8367	.7979	.4382	.8401	.833	.8372	.8166
3	.8348	.7967	.4382	.8375	.8303	.8353	.8143
4	.8847	.7297	.381	.7758	.8292	.8338	.8135
5	.9069	.7281	.381	.7685	.7697	.8482	.7224
6	.8558	.7888	.4382	.8558	.8366	.8513	.6992
7	.8907	.8791		.8981	.908	.9149	.8634
8	.9219	.8677	.4338	.8827	.9115	.9073	.8935
9	.9214	.8993	.4527	.9103	.9478	.9252	.9305
10	.9275	.9206	.4527	.9179	.9214	.9214	.929
11	.8875	.8856	.4527	.9214	.8945	.6028	.926
12	.8662	.8684	.4572	.8318	.857	.8842	.8681
13	.8562	.8769	.4382	.8769	.8562	.8777	.4496
14	.8662	.8895	.4382	.8903	.8662	.8865	.4588
15	.8909	.3699	.4382	.8907	.8914	.8872	.4599
16	.8875		.4382	.6843	.8899	.8884	.4839
17	.8742		.4382	.1101	.8738	.8947	.4687
18	.8556	.8055	.4382	.8939	.8738	.8888	.4443
19	.8424	.932	.4382	.9111	.8492	.8918	.466
20	.7112	.8962	.381	.9501	.8047	.8156	.4332
21	.5997	.8398	.362	.9188	.7655	.751	.4332
22	.6257	.9015	.362	.7308	.7608	.3654	.2987
23	.7118	.8615	.362	.7598	.7994	.6985	.7091
24	.8151	.7826	.4001	.3989	.8174	.8174	.8145
Max	.9275	.932	.4572	.9501	.9478	.9252	.9305
Min	.5997	.3699	.362	.1101	.7608	.3654	.2987
Avg	.8370	.8062	.4217	.8039	.8511	.8276	.6671

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 206 / 11 KV Kapuskhed Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3178	.2797	.1494	.3251	.3481	.3315	.3425
2	.3136	.2725	.1494	.3235	.3443	.325	.2652
3	.3132	.2702	.1494	.3212	.339	.3273	.3178
4	.3087	.2706	.1494	.3205	.3378	.33	.3155
5	.3296	.381	.1867	.3867	.3512	.3955	.3681
6	.471	.4725	.2801	.5312	.5423	.4765	.4577
7	.4313	.4887		.4695	.5413	.4965	.421
8	.3578	.3645	.1494	.4138	.4016	.4085	.3376
9	.2842	.2997	.168	.3327	.3564	.325	.3193
10	.2591	.2814	.1494	.343	.3107	.2923	.3002
11	.245	.2862	.1494	.2831	.3372	.282	.2846
12	.2737	.3029	.1494	.2553	.317	.311	.2812
13	.2707	.2816	.1494	.3025	.2999	.3171	.1437
14	.2863	.2654	.1494	.2995	.2856	.3132	.1433
15	.2909	.2968	.1494	.3395	.3178	.3357	.1456
16	.3542	.2999	.1494	.3368	.3365	.3437	.1345
17	.3427	.2991	.1494	.3547	.3999	.3795	.1307
18	.277	.3338		.3784	.4195	.3619	.1738
19	.4005	.4756	.2241	.5529	.5308	.4226	.2187
20	.5001	.562	.2614	.5094	.5062	.5197	.2332
21	.4661	.4817	.2241	.4683	.469	.4741	.2374
22	.4134	.4634	.2241	.4333	.4411	.4607	.2286
23	.3737	.3982	.168	.3909	.4085	.4226	.4098
24	.3402	.333	.168	.1814	.3607	.3573	.3452
Max	.5001	.562	.2801	.5529	.5423	.5197	.4577
Min	.245	.2654	.1494	.1814	.2856	.282	.1307
Avg	.3425	.3525	.1749	.3689	.3876	.3754	.2731

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 207 / 11 KV SAKHRALE Ag FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0189	.5441	.5693	.5247	.0189	.0171
2	.0171	.0189	.5441	.5693	.5247	.0189	.0171
3	.0171	.0189	.5441	.5693	.5247	.0189	.0171
4	.0171	.0189	.5441	.5376	.4877	.0189	.0171
5	.0171	.0189	.5441	.5376	.4012	.0189	.0171
6	.0171	.0189	.5761	.5376	.4161	.0189	.0171
7	.0171	.0189		.5693	.4572	.0189	.0171
8	.0171	.0189	.0171	.0171	.0185	.0189	.0171
9	.8642	.8223	.0171	.0171	.0185	.8322	.8962
10	.9602	.8002	.0171	.0189	.0189	.9282	.9602
11	.8962	.8322		.0189	.0189	.9282	.9282
12	.7811		.0171	.0189	.0189	.9282	
13	.679		.0171	.0189	.0189	.8322	
14	.5761		.0171	.0189	.0189	.8322	
15			.0171	.0189	.0189	.7682	
16	.5624	.6958	.0171	.0189	.0189	.7362	
17	.0173	.1494	.0171	.0189	.0189		
18	.0177	.0171	.0171	.0189	.0189	.0171	
19	.0183	.0171	.0171	.0189	.0189	.0171	
20	.0181	.0171	.0171	.0189	.0189	.0171	
21	.0189	.0171	.0171	.0189	.0189	.0171	
22		.6154	.6722	.6478	.0189	.0171	
23	.0189	.6154	.6722	.6478	.0189	.0171	
24	.0158	.0189	.0171		.5851	.0189	.0171
Max	.9602	.8322	.6722	.6478	.5851	.9282	.9602
Min	.0158	.0171	.0171	.0171	.0185	.0171	.0171
Avg	.2537	.2385	.2218	.2368	.1760	.3069	.2449

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 209 / 11 KV Siddhanath LIS
feeder Feeder KV- 11 /
OUTGOING

PURELY LIS FEEDERS

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.064	.064	.3201	.3321	.3812	.3812
2	.0655	.064	.3361	.3479	.3812	.3812
3	.0655	.064	.3361	.3479	.3812	.3812
4	.0655	.064	.3681	.3479	.3812	.3812
5	.0655	.064	.3681	.3479	.3812	.3812
6		.064	.3681	.3479	.3812	.3812
7	.0655	.064		.3479	.3812	.3812
8	.0655	.2105	.3521	.3479	.3812	.3812
9	.0655	.3768	.3637	.3637	.3812	.3812
10	.064	.3768	.3637	.3647	.3978	.3681
11	.064	.3768	.3637	.3812	.3978	.3681
12	.064	.3768	.3637	.3812	.3812	.3681
13	.064	.3768	.3479	.3812	.3812	.3521
14	.064	.3768	.3479	.3812	.3812	.3681
15	.064	.3768	.3479	.3812	.3481	.3681
16	.048	.3768	.3479	.3647	.3277	.3361
Max	.0655	.3768	.3681	.3812	.3978	.3812
Min	.048	.064	.3201	.3321	.3277	.3361
Avg	.0636	.2296	.3530	.3604	.3779	.3725

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 401 / 33 KV EXPRESS FEEDER
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.7494	4.7554	1.2574	5.5327	6.557	6.4661	6.2872
2	3.6809	4.7897	1.1431	5.6356	6.3855	6.4661	6.2872
3	3.6809	4.7897	1.1431	5.2927	6.4884	6.4318	6.0356
4	3.4065	4.7897	1.1431	5.4526	6.4884	6.3975	5.8985
5	3.2693	4.5497	1.1431	5.2469	6.3512	6.3289	5.727
6	3.3493	4.3782	1.1431	5.4869	6.3632	6.3289	5.8299
7	3.1207	4.4468		5.4755	6.0785	6.2946	6.0814
8	3.1436	4.0581	1.086	3.9781	5.6104	6.1351	5.5784
9	4.1495	4.2524	1.1431	5.3498	6.3975	6.4884	5.144
10	4.6068	4.6862	1.2574	5.9071	6.5913	5.0755	4.7548
11	4.9383	5.3035	1.4861	6.8758	6.8656	7.2703	5.4732
12	5.0869	5.1321	1.3717	7.4349	6.9342	7.0188	5.8282
13	4.9268	5.0515	1.3717	7.1845	6.7849	6.7787	4.2524
14	4.401	5.223	1.3717	7.5257	6.6701	6.7444	4.1495
15	4.7096	5.3258	1.3717	7.1845	6.8535	6.8587	4.4582
16	4.9726	5.2349	1.4861	7.2411	6.8313	6.813	4.8011
17	4.7325	5.0412	1.4861	7.1159	6.5227	6.8015	4.4925
18	4.321	4.9726	1.4861	6.6941	5.998	6.0356	4.3553
19	4.0809	4.7325	1.3717	6.557	5.5538	6.0699	4.1838
20	4.4468	4.8125	1.2574	6.557	5.6447	6.1957	4.1495
21	4.3096	4.401	1.2574	6.1112	5.6447	5.9213	3.4294
22	3.1207	4.8011	1.2574	6.3512	6.4198	5.967	3.2922
23	4.3096	5.0297	1.4289	6.4095	6.773	6.2872	5.108
24	4.3096	4.9955	1.2574	5.9213	6.3872	6.3672	5.4413
Max	5.0869	5.3258	1.4861	7.5257	6.9342	7.2703	6.2872
Min	3.1207	4.0581	1.086	3.9781	5.5538	5.0755	3.2922
Avg	4.1176	4.8147	1.2922	6.1884	6.3831	6.3976	5.0433

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244053 / 33/11 KV RETHRE HARNAX STN

Feeder No / Name : 201 / 11 KV RHX & TAKARI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6224	.7095	.679	.7095	.7095	.7095	.6348
2	.6036	.7095	.679	.6908	.6979	.6979	.6161
3	.6036	.6908	.679	.6908	.6979	.6979	.6161
4	.6413	.7095	.679	.7095	.7167	.6979	.6348
5	.6979	.7282	.7167	.7392	.7545	.7095	.6722
6		.9149	.8215	.8775	.8402	.8215	.8215
7	.8596	.9328	.8507	.9231	.8954	.8775	.7964
8	.7442	.8063	.8059	.815	.7888	.6935	.7442
9	.6836	.7796	.7545	.6836	.7202		.6661
10	.6762	.7011	.6859	.7628	.6935	.6783	.6859
11	.7282	.6173	.7282	.7442	.703	.7461	
12	.7377	.6783	.703		.7042	.7291	
13	.7291	.7545	.7628	.7796	.6415	.703	
14	.724	.7442	.7712	.7011	.631	.7011	
15	.7265	.7202	.7796	.5144	.7186	.7362	
16	.7265	.7042	.7802	.7888	.7628	.7202	
17	.6935	.7209		.8322		.6516	
18	.7373	.763				.7461	
19	.9694	1.0029	1.134	1.0631	1.2048	.9391	
20	.0747	1.0608	1.2127	1.086			
21	.9425	.961	1.0679	1.0242	1.0136	.924	
22	.9335	.9522	.9425	.8686	.9425	.8775	
23	.8589	.8402	.8501	.7207	.7947	.7842	
24	.6602	.7282	.7095	.7392	.7207	.7282	.6722
Max	.9694	1.0608	1.2127	1.086	1.2048	.9391	.8215
Min	.0747	.6173	.679	.5144	.631	.6516	.6161
Avg	.7119	.7888	.8088	.7938	.7787	.7532	.6873

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244053 / 33/11 KV RETHRE HARNAX STN

Feeder No / Name : 202 / 11 KV TAKARI AG FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0754	.5407	.6562	.6401	.0754	.0747
2	.0747	.0754	.547	.6562	.6154	.0754	.0747
3	.0747	.0754	.547	.6241	.6154	.0754	.0747
4	.0747	.0754	.5407	.5921	.6154	.0754	.0934
5	.0739	.0934	.5571	.6009	.6478	.0747	.0934
6		.112	.5281	.6964	.6722	.0924	.0924
7	.0934	.112	.6325	.8097	.7682	.1294	.1109
8	.1132	.0943	.0924	.112	.112	.132	.1132
9	1.1633	1.1768	.0943	.1109	.112		1.1012
10	1.2289	1.2452	.0754	.1132	.1463	1.1043	1.2308
11	1.2125	1.1961	.0754	.1109	.1494	1.2323	
12	1.0311	1.1984	.0754		.132	1.1523	
13	1.0031	1.0595	.0943	.0747	.112	1.0753	
14	.8356	.9922	.0754	.0754	.0943	1.0279	
15		.9602	.0934	.0754	.1132	.9804	
16	.7956	.8381	.0943	.0943	.112	.9374	
17	.1132	.0943		.0943		.0943	
18	.1132	.1132				.0943	
19	.112	.1132	.0943	.1307	.1132	.112	
20	.0943	.1307	.1109				
21	.0943		.1132	.0943	.0943	.0934	
22	.0943	.6706	.8848	.7537	.0943	.0934	
23	.0754	.6299	.852	.7449	.0934	.0934	
24	.0747	.0754	.5571	.8097	.7116	.0943	.0747
Max	1.2289	1.2452	.8848	.8097	.7682	1.2323	1.2308
Min	.0739	.0754	.0754	.0747	.0934	.0747	.0747
Avg	.3919	.4873	.3307	.3824	.3221	.4052	.2849

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244053 / 33/11 KV RETHRE HARNAX STN

Feeder No / Name : 203 / 11 KV RETHRE HARNAX AG SEPARATED AG FEEDERS HAVING SPECIAL
FEEDER Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.012	.8697	.0732	.0709	.0514	.9374	.9061
2	.9686	.8539	.0747	.0709	.0526	.933	.8642
3	.9686	.8381	.0747	.0701	.0526	.933	.8333
4	1.012	.8697	.0739	.0701	.0526	.9488	.7926
5	1.0883	.933	.0739	.0693	.0532	1.0242	.8025
6		1.1069	.0747	.0724	.0716	1.1523	.9374
7	1.0311	1.1248	.0686	.0876	.0625	1.2037	1.0311
8	.0469	.0633	.0671	.0848	.0625	.0549	.0678
9	.0655	.0848	1.6356	1.6907	1.6575		.0709
10	.0693	.0648	1.5546	1.8067	1.7368	.048	.0838
11		.0497	1.4575	1.6078	1.7204	.0663	
12			1.3123			.0617	
13					1.5402	.064	
14			1.3916	1.3279		.0347	
15	.0617		1.4083	1.3443	1.3279	.0358	
16			1.358	1.2963	1.4243	.0312	
17		.0655		.0492		.061	
18	.0819	.0648				.08	
19	.0693	.0686	.1017	.0663	.0867	.0867	
20	.0701	.0716	.0867				
21	.0701	.0732	.0701	.0549	.0678	.0867	
22	1.012	.0747	.0724	.0724	1.0437	1.0437	
23	.9804	.0732	.0724	.0686	1.012	.9686	
24	1.0279	.933	1.3123	.0701	.048	.953	.9374
Max	1.0883	1.1248	1.6356	1.8067	1.7368	1.2037	1.0311
Min	.0469	.0497	.0671	.0492	.048	.0312	.0678
Avg	.5668	.4360	.5912	.5026	.6381	.4913	.6661

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244053 / 33/11 KV RETHRE HARNAX STN

Feeder No / Name : 204 / 11KV Bhavaninagar LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4534	.5636	.3239	.5243	.3315	.547
2	.5506	.5636	.5407	.5243	.4973	.547
3	.5571	.5636	.5407	.5243	.4858	.547
4	.5636	.5636	.547	.5243	.5182	.547
5	.5571	.5636	.5407	.5182	.5243	.547
6		.5636	.547	.5304	.5243	.547
7	.5376	.5571	.5407	.5121	.5218	.5407
8	.5506	.5506	.5571	.5636	.5636	.2785
9	.5636	.5868	.5571	.5765	.5636	
10	.5935	.57	.5079	.57	.57	.5344
11	.5935	.5636	.5079	.57	.57	.5407
12	.5506	.5506	.5182		.5344	.5281
13	.5441	.5441	.5121		.57	.5344
14	.5868	.5571	.5506	.4858		.5344
15	.5735	.0061	.5571	.5182	.5636	.5344
16	.5735	.0065	.5441	.5312	.5304	.5281
Max	.5935	.5868	.5571	.5765	.57	.547
Min	.4534	.0061	.3239	.4858	.3315	.2785
Avg	.5566	.4921	.5246	.5338	.5246	.5224

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244112 / 33/11 KV BAHE SUB-STATION

Feeder No / Name : 201 / 11 KV BAHE GOVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.2218	.2218	.2218	.2195	.2195	.2195
2	.2241	.2033	.2218	.2218	.2149	.2218	.1991
3	.2241	.1829	.2195	.2033	.2195	.2033	.2012
4	.2241	.1829	.2218	.2012	.2715	.2012	.2012
5	.2772	.2534	.2561	.3077	.3077	.2957	.2896
6	.3696	.3258	.3511	.3403	.3841	.3511	.2507
7	.2865	.2896	.2629	.2804	.3222	.2686	.2507
8	.2126	.2229	.1989	.2058	.2229	.2103	.1949
9	.1823	.1989	.1989		.1966	.1802	.1619
10	.16	.1739	.1638	.1875	.1823	.1739	.1581
11	.1619	.1823	.1823	.208	.1423	.1718	.1475
12	.1638	.144	.2294	.208	.2012	.1898	.1311
13	.213	.1907	.2155	.2204	.1886	.1898	.156
14	.2126	.2103	.2058	.2229		.1989	
15	.1772	.1791	.1907	.208	.2427	.2012	
16	.1791	.2058	.1715	.2321	.208		
17		.213	.1966	.176	.2035	.2149	
18		.2267	.2105	.1619	.2155	.1943	
19	.3353	.3121	.2481	.3155	.2427	.2229	
20	.3506	.3366	.3403	.3012	.2534	.2865	
21	.3155	.3045	.3077	.2591	.2587	.2715	
22	.2926	.2743	.2926	.2353	.2926	.2772	
23	.2402	.2402	.2561	.2561	.2378	.2427	
24	.2195	.2218	.2195	.2378	.2402	.2402	.2195
Max	.3696	.3366	.3511	.3403	.3841	.3511	.2896
Min	.16	.144	.1638	.1619	.1423	.1718	.1311
Avg	.2383	.2290	.2326	.2353	.2378	.2273	.1986

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244112 / 33/11 KV BAHE SUB-STATION

Feeder No / Name : 202 / 11 KV KHARATWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3321	.253	.216		
2			.2968	.25	.216		
3			.3005	.25	.2214		
4			.2968	.25	.2241		
5			.2968	.253	.2315		
6			.3125	.2591	.2439		
7			.3241	.2526	.2743		
8		.037					
9	.5668	.5281				.5281	.506
10	.4801	.4801				.5441	.5376
11	.4902	.664				.5761	.5761
12	.6241	.6562				.5535	
13	.6009	.6464			.1886	.5624	
14		.6062			.1949	.5761	
15		.6226				.5281	
16	.3932	.6062					
19	.0177			.0179			
22		.3841	.2846	.2372			
23		.3841	.2656	.2372			
24			.3395	.2656			
Max	.6241	.664	.3395	.2656	.2743	.5761	.5761
Min	.0177	.037	.2656	.0179	.1886	.5281	.506
Avg	.4533	.5105	.3049	.2296	.2234	.5526	.5399

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244112 / 33/11 KV BAHE SUB-STATION

Feeder No / Name : 203 / 11 KV HUBALWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7287	.7682	.0566	.0532	.0543	.9282	.9779
2	.7125	.7682	.0566	.0537	.0554	.8592	.9779
3	.6874	.7682	.0566	.0537	.056	.8592	.9779
4	.7125	.7682	.0566	.0532	.056	.8592	.9667
5	.6874	.7907	.0566	.0351	.0566	.8802	.9667
6	.7164	.8124	.0754	.0701	.0566	.9122	1.0059
7	.7968	.8583	.0566	.0532	.0554	.9646	1.0111
8	.0358	.0537	.0566	.0716	.056	.0366	.0554
9	.0362	.037	1.3603	1.4752	1.4091	.0486	.0377
10	.037	.0377	1.5684	1.5083	1.4413	.048	.0377
11	.0554	.0377	1.5043	1.5729	1.4899	.0497	.0377
12		.0377	1.3923	1.5729	1.4899	.0354	
13		.0377	1.4083	1.7926	1.4899	.0354	
14		.0566	1.4723	1.5565	1.4251	.1989	
15		.0377	1.4922	1.5074	1.3279	.0354	
16	.0554	.0377	1.3765	1.4091	1.2944		
17		.0377	.0537	.0377	.0377	.0354	
18		.0377	.0716		.0377	.0358	
19	.1097	.0566	.0724	.0492	.0566	.0486	
20	.0739	.0566	.0709	.0566	.0754	.048	
21	.0914	.0566	.0709	.056	.0566	.048	
22	.8002	.0566	.0526	.056	.9014	.9602	
23	.8482	.0566	.0526	.0566	.933	.9762	
24	.7274	.8065	.0566	.0526	.0566	.8905	1.0111
Max	.8482	.8583	1.5684	1.7926	1.4899	.9762	1.0111
Min	.0358	.037	.0526	.0351	.0377	.0354	.0377
Avg	.4396	.2947	.5228	.5741	.5820	.4258	.6720

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244113 / 33/11 KV YEDEMACHHINDRA

Feeder No / Name : 201 / 11 KV MANCHHINDRANAT

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 /
OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.6036	.5847	.6036	.6036	.6036	.6224
2	.5847	.5847	.5906	.5906	.6036	.6097	.6036
3		.5847	.5906	.5906	.5658	.6097	.6036
4	.6036	.5847	.6036	.6036	.6036	.6036	.6224
5	.6979	.679	.6602	.6859	.679	.679	.679
6		.8676	.8962	.8589	.811	.8962	.6979
7	.7947	.7922	.8501	.8215	.7762	.7682	.7167
8	.6335	.5487	.6089	.5853	.6219	.5611	.5359
9	.5373	.543		.5731		.5373	.4572
10	.5493	.4835		.5316	.5721	.4961	.4161
11	.5731	.4298	.5316	.5434	.5609	.5083	.3506
12	.5434	.4961	.5847		.5493	.5201	.4334
13	.5316	.5014	.567	.5258	.5258	.4557	
14	.4887	.5194	.5014	.5316	.5316	.5258	
15	.5493	.5493	.5316	.4908	.5493	.4908	
16	.4908	.5201	.5609	.5552	.5434	.443	
17	.5144	.5434	.5434	.4694	.5256	.4801	
18	.5721	.5144	.5552		.5087	.5548	
19	.8326	.7602	.8238		.788	.8145	
20	.9795	.9694	.9877		.8596	.8779	
21	.8316	.8871	.924	.924	.8413	.8413	
22	.8131	.8029	.8215	.8316	.7282	.7762	
23	.679	.6602	.6979	.679	.679	.679	.679
24	.6224	.6224	.6036	.6413	.6224	.6224	.6224
Max	.9795	.9694	.9877	.924	.8596	.8962	.7167
Min	.4887	.4298	.5014	.4694	.5087	.443	.3506
Avg	.6376	.6270	.6645	.6318	.6370	.6231	.5743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244113 / 33/11 KV YEDEMACHHINDRA

Feeder No / Name : 202 / 11KV KRISHNA LIS

PURELY LIS FEEDERS

YEDEMACHHINDR Feeder KV- 11 /
OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.004	.5441	.5344	.5535	.5601	.5601
2	.0036	.5441	.5344	.5601	.5601	.5535
3	.0036	.5571	.5121	.5601	.5601	.5535
4	.0036	.5506	.5506	.5601	.5601	.5601
5	.0038	.5441	.5281	.5535	.5601	.5601
6		.5441	.5182	.5601	.5535	.5601
7	.0038	.5506	.5182	.5601	.5668	.5535
8	.0038	.5376	.5121	.5668	.5601	.5601
9	.0038	.5735		.5761	.5668	.5668
10	.2214	.5506		.2187	.5668	.5668
11	.5967	.5571	.4696	.583	.5668	.5668
12	.5441	.5376	.5182		.5376	.5668
13	.5312	.5601	.5601	.5556	.5535	.5535
14	.5668	.4902	.5376	.5601	.5535	.5601
15	.5376	.5121	.5668	.5376	.5535	.5601
16	.5571	.4902	.5201	.5668	.5335	.5668
Max	.5967	.5735	.5668	.583	.5668	.5668
Min	.0036	.4902	.4696	.2187	.5335	.5535
Avg	.2390	.5402	.5272	.5381	.5571	.5605

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244113 / 33/11 KV YEDEMACHHINDRA

Feeder No / Name : 203 / 11KV Kilemachindragad Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1265	.1524	.924	1.2269	1.182	.1423	.1524
2	.1265	.1524	.9145	1.2226	1.134	.1372	.1524
3		.1334	.905	1.2094	1.0631	.1475	.1524
4	.1265	.1524	.9231	1.2226	1.0517	.1475	.1524
5	.1715	.1524	1.0099	1.2226	1.1568	.1475	.1524
6		.1905	1.2934	1.3847	1.3321	.2035	.1905
7	.2012	.1905	1.4529	1.5775	1.5775	.2204	.1905
8	.1783	.2286	.1783	.1638	.1486	.1844	.1905
9	2.1033	2.2436		.1423	.1265	2.2085	1.6004
10	2.2786	2.2885		.1147	.1265	2.3137	1.9765
11	2.2961	2.2085	.0894	.1265	.1311	2.2885	2.1672
12	2.0233	1.869	.1311		.1158	2.2192	
13	1.749	1.7684	.1475		.1082	1.8031	
14	1.3889	1.5775	.1423		.1217	1.7337	
15		1.5604	.1423	.1696	.1475	1.893	
16	1.2811	1.3426	.1581	.1638	.1158	1.7684	
17	.1486	.1488	.1429	.1783	.1217	.1082	
18	.1505	.1217	.1505		.1353	.1353	
19	.1505	.1802	.1905		.1638	.1966	
20	.2096	.1844	.1905		.1844	.1677	
21	.2035	.2035	.2096	.1783	.1844	.1638	
22	.1505	1.1999	1.6301	1.491	.2012	.1619	
23	.1189	1.1403	1.6124	1.4175	.1802	.1524	.1638
24	.1475	.1524	1.0059	1.382	1.3112	.1677	.1905
Max	2.2961	2.2885	1.6301	1.5775	1.5775	2.3137	2.1672
Min	.1189	.1217	.0894	.1147	.1082	.1082	.1524
Avg	.7300	.8143	.6156	.8108	.5050	.7838	.5717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244120 / 33/11 KV Ganeshnager

Islampur

Feeder No / Name : 201 / 11 KV RAJARAM NAGER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3048	.2561	.2858	.2667	.2858	.2667
2	.2667	.2667	.2378	.2858	.2286	.3048	.2477
3	.2667	.2477	.2378	.2667	.2286	.2858	.2477
4	.2667	.2477	.2378	.3048	.2667	.2667	.2477
5	.2667	.2667	.2561	.2667	.2667	.2477	.2667
6	.2667	.3048	.2926	.2667	.2667	.2667	.2477
7	.3429	.3429	.3292	.2858	.3048	.2858	.3048
8	.3048	.3048	.2926	.3048	.2667	.2667	.3048
9	.3048	.2667	.2743	.3239	.2667	.2667	.3239
10	.2926	.2286	.2858	.2858	.2667	.2286	.3048
11	.2561	.2667	.3048	.3048	.2477	.2286	.3048
12	.3109	.3048	.2858	.3239	.2477	.2477	
13		.2667	.3239	.3048	.2858	.2477	
14	.3109	.2667	.3239	.3239	.2667	.2667	
15	.3109	.3048	.3048	.3239	.2667	.2858	
16	.2926	.3048	.3048	.3048	.2858	.2858	
17	.3658	.3429	.3048	.3239	.2667	.2858	
18	.3239	.3292	.3048	.2667	.3048	.2286	
19	.381	.3658	.362	.3048	.3429	.3429	
20	.362	.3658	.3429	.3429	.3239	.362	
21	.3429	.3292	.3429	.3048	.3048	.3429	
22	.362	.3292	.3239	.3048	.3048	.3048	.3048
23	.3239	.3109	.3239	.3048	.2667	.2667	.2667
24	.3048	.3048	.2743	.3048	.2667	.2858	.2667
Max	.381	.3658	.362	.3429	.3429	.362	.3239
Min	.2561	.2286	.2378	.2667	.2286	.2286	.2477
Avg	.3100	.2989	.2970	.3009	.2754	.2786	.2790

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244120 / 33/11 KV Ganeshnager

Islampur

Feeder No / Name : 202 / 11 KV Uran-Islampur

GAOTHAN FEEDER

Gaothan. Feeder KV- 11 /
OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9907	.9717	.9328	1.0479	.9907	1.0288	.9145
2	.9526	.9145	.8962	.9717	.9526	.9717	.8383
3	.9145	.8954	.8962	1.0288	.9145	.9145	.8383
4	.9145	.8954	.8962	1.0288	.9145	.9145	.8764
5	1.0288	1.0098	.9877	1.2003	.9907	.9907	.9526
6	1.2574	1.2574	1.2437	1.2574	1.1431	1.1812	1.1241
7	1.0669	1.1241	1.0242	1.2574	.9907	.9145	.9907
8	.9145	.8764	.8413	1.0288	.8002	.8573	.8383
9	.9145	.8573	.8048	1.0098	.8002	.8192	.8192
10	.9877	.9526	.8573	.9717	.8383	.8764	.8764
11	.9328	.9145	.9145	.9526	.8573	.8383	.4954
12	.9328	.9145	.9335	.9526	.8573	.8764	
13	.9694	.9145	.9717	.9526	.8383	.9145	
14	1.0059	.9907	.9717	.9526	.8383	.9907	
15	.9511	.9526	1.086	.9526	.8383	.9526	
16	1.0608	.9526	1.1812	1.1622	.9145	1.105	
17	.9328	.9526	1.1622	1.0669	.9526	1.0098	
18	1.0288	.9328	1.0098	.9526	1.1622	.9526	
19	1.3717	1.2803	1.4289	1.2955	1.4289	1.3146	
20	1.3908	1.3717	1.3527	1.4098	1.2765	1.2955	
21	1.2955	1.2437	1.3146	1.2574	1.2384	1.2955	
22	1.2765	1.1523	1.2765	1.2193	1.2193	1.2003	.9907
23	1.086	1.0974	1.2003	1.1812	1.1622	1.1431	.9526
24	1.0288	1.0098	.9694	1.1241	1.0288	1.0669	1.0288
Max	1.3908	1.3717	1.4289	1.4098	1.4289	1.3146	1.1241
Min	.9145	.8573	.8048	.9526	.8002	.8192	.4954
Avg	1.0502	1.0181	1.0481	1.0931	.9979	1.0177	.8955

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244120 / 33/11 KV Ganeshnager

Islampur

Feeder No / Name : 203 / 11KV Mahadev Nagar Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.9526	.9145	1.105	.9526	1.0098	.9335
2	.9145	.8954	.8779	1.0288	.8764	1.0288	.8573
3	.8764	.8954	.8779	1.0098	.8383	.9907	.8002
4	.8764	.8954	.9145	1.0098	.8383	.9526	.7621
5	.9145	.9335	.9145	1.2003	.8764	.9717	.7811
6	.9526	.9907	.9511	1.1431	.9145	1.0098	.8383
7	.9907	.9526	.9145	1.0098	.9145	1.1431	.9145
8	.9907	1.0288	.9511	.9717	.9907	.9717	.9145
9	.8002	.8764	.8048	.9717	.8002	.7811	.7621
10	1.1157	1.105	.9717	1.1241	.8383	1.086	.9145
11	.9511	1.0288	1.0479	.9907	.9145	.9145	.8002
12	1.0242	1.0288	1.0479	1.0479	.9717	.9907	
13	.9877	.9907	1.0669	.381	.8954	.9145	
14	1.0242	1.105	1.0669	.381	.8954	.9526	
15	.9694	1.0669	1.0098	1.2384	.9335		
16	1.0059	1.0669	.9907	1.1622	.8383	.9145	
17	1.0242	1.105	.9907	1.105	.9526	.9526	
18	1.105	1.0608	1.1241	1.0669	1.2765	.9335	
19	1.5242	1.4632	1.6194	1.3717	1.5432	1.4098	
20	1.5242	1.4449	1.448	1.448	1.4098	1.3336	
21	1.3336	1.2803	1.448	1.2955	1.3336	1.2003	
22	1.2384	1.134	1.3146	1.2955	1.2384	1.1431	1.1431
23	1.105	1.0608	1.2574	1.2574	1.105	1.0288	1.0669
24	.9526	.9717	.9877	1.1622	1.0669	1.0288	.9717
Max	1.5242	1.4632	1.6194	1.448	1.5432	1.4098	1.1431
Min	.8002	.8764	.8048	.381	.8002	.7811	.7621
Avg	1.0465	1.0556	1.0630	1.0741	1.0090	1.0288	.89

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 201 / 11 KV BORGAON GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

DATE	01-APR-17
HR	Load (MW)
24	.5658
Max	.5658
Min	.5658
Avg	.5658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 202 / 11 KV KHED GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3967	.4012	.3662	***	***	***
2	.389	.3989	.3502	***	***	***
3	.373	.3913	.3406	.3003		
4	.3635	.3791	.3311	***	***	***
5	.3654	.3765	.3307	***	***	***
6	.3719	.3666	.3323	.2442		
7	.3772	.3643	.333	***	***	***
8				***	***	***
9					.3086	.293
10				***	***	***
11				***	***	***
12					.3235	.2995
13				***	***	***
14				***	***	***
15				.1395	.3067	.277
16				***	***	***
17				***	***	***
18				.389		
19				***	***	***
20				***	***	***
21	.1497	.2442	.0751	.3487		
22	.4378	.4332	***	***	***	***
23	.3742	.4371	***	***	***	***
24	.4466	.4348	.8913			
Max	.4466	.4371	24.9715	24.9715	24.9715	24.9715
Min	.1497	.2442	.0751	.1395	.3067	.277
Avg	.3677	.3843	4.8449	19.0936	21.0780	21.0744

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 203 / 11 KV WALWA FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-APR-17
HR	Load (MW)
24	.8669
Max	.8669
Min	.8669
Avg	.8669

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 204 / 11 KV LIS BOR FEEDER

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-APR-17
HR	Load (MW)
24	.543
Max	.543
Min	.543
Avg	.543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 205 / 11 KV KHED AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-APR-17
HR	Load (MW)
24	.9145
Max	.9145
Min	.9145
Avg	.9145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 206 / 11 KV BORGON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-APR-17
HR	Load (MW)
24	1.0311
Max	1.0311
Min	1.0311
Avg	1.0311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 401 / 33 KV Borgaon (from EHV NON SHEDDABLE EXPRESS HV FEEDERS
Borgao Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	04-APR-17
HR	Load (MW)
14	1.829
15	1.829
16	2.9721
17	2.2862
18	2.0576
19	2.7435
20	2.9721
21	2.7435
22	2.7435
23	2.7435
24	2.5149
Max	2.9721
Min	1.829
Avg	2.4941

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 201 / 11 KV Kasegaon Gaothan-
Village Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.3696	.415	.415	.439		.415
2	.381	.3734	.415	.415	.3109		.415
3	.381	.4481	.415	.415	.3174		.415
4	.381	.439	.415	.415	.3734		.415
5	.5335	.5304	.4527	.5228	.4525		.4904
6	.6478	.5914	.6348	.6535	.5249		.5788
7	.5335	.6468	.6653	.6535	.5853		.6161
8	.5716	.5068	.3734	.5228	.5359		.5228
9	.5175	.439	.4481		.4938	.4435	
10	.5175		.4066	.4435	.4706	.4477	.4066
11	.439		.4481	.4805	.5068	.3982	
12	.3801		.4481	.4435	.394	.362	
13	.4344		.4481	.4344	.362	.333	.3361
14	.439		.4066	.4344	.4298	.3681	.3361
15	.4435		.4805	.4344	.3982	.3856	.2987
16	.439		.4805	.4207	.4755		.4066
17	.499			.462	.4755		
18	.5487			.5175			
19	.6653			.6348			
20	.7133			.6697			
21	.6584			.5914			
22	.5914			.5304			
23	.5175			.4755			
24	.4572	.4527	.4252	.4527	.4527	.4435	.4527
Max	.7133	.6468	.6653	.6697	.5853	.4477	.6161
Min	.3801	.3696	.3734	.415	.3109	.333	.2987
Avg	.5046	.4797	.4575	.4973	.4443	.3977	.4361

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 202 / 11 KV Nerle Gaothan feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.6348	.7545	.7545	.6413		.6602
2	.4572	.6348	.6036	.6036	.6283		.5658
3	.4572	.5544	.6036	.6036	.5544		.5658
4	.4572	.5658	.6036	.6036	.5601		.5658
5	.5335	.6036	.6036	.6097	.6348		.6602
6	.6097	.5975	.7095	.6348	.5281		.7095
7	.6478	.5281	.6283	.5228	.5228		.6348
8	.5335	.4854	.4481	.4481	.415		.5228
9	.5658		.5228		.5975	.4066	.4904
10	.6602		.5415	.4904	.7095	.679	.4527
11	.6584		.5914	.679	.8402	.6722	.415
12	.6348		.8501	.7468	.8589	.8215	
13	.6413		.7762	.7468	.7207	.7842	.4805
14	.7842		.7964	.7922	.7392	.8215	.4805
15			.7964	.811	.8501	.8589	.5914
16	.6908		.7964	.7468	.8299		.415
17	.679			.7095			
18	.6722			.7167			
19	.8299			.8589			
20	.9808			.9054			
21	.9242			1.0269			
22	.8215			.8962			
23	.8676			.8865	.8299		
24	.5335	.8299	.4527	.8299	.8299	.4066	.7545
Max	.9808	.8299	.8501	1.0269	.8589	.8589	.7545
Min	.4572	.4854	.4481	.4481	.415	.4066	.415
Avg	.6581	.6038	.6517	.7228	.6828	.6813	.5603

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 203 / 11 KV Tambave Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.3696	.415	.415	.362		.3772
2	.381	.2926	.415	.415	.362		.3772
3	.381	.2987	.415	.415	.3142		.3772
4	.381	.2614	.415	.415	.3142		.3772
5	.4954	.3475	.415	.4854	.3841		.4527
6	.5716	.3841	.4854	.5228	.3841		.5415
7	.5525	.4344	.4805	.4481	.4344		.5228
8	.4954	.3841	.4108	.4108	.3841		.4668
9	.4344		.3734		.362	.3696	
10	.3801		.4066	.3547	.3439	.3658	.4108
11	.4108		.4066	.3881	.3326	.362	.462
12	.4066		.4251	.3881	.3258	.3982	.1478
13			.3696	.3326	.3109	.3506	.2614
14			.3292	.2926	.3292	.298	.2614
15	.3696		.2926	.2926	.2926	.298	.2987
16	.4668		.2926	.3224	.3224		.3772
17	.5304			.3658			
18	.5304			.3658			
19	.5487			.4024			
20	.5914			.439			
21	.4706			.4108			
22	.5121			.3801			
23	.439			.4572			
24	.4572	.4527	.4344	.4527	.415	.3696	.415
Max	.5914	.4527	.4854	.5228	.4344	.3982	.5415
Min	.3696	.2614	.2926	.2926	.2926	.298	.1478
Avg	.4648	.3583	.3989	.3988	.3514	.3515	.3829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 204 / 11 KV Wategaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3658	.3395	.3429	.3439		.3395
2	.3048	.2561	.3395	.3429	.2534		.3018
3	.3048	.2587	.3395	.3429	.2561		.3018
4	.3048	.2534	.3395	.3429	.2561		.3018
5	.381	.3439	.3772	.381	.3045		.3361
6	.4572	.3881	.4108	.4763	.3045		.3734
7	.4763	.4435	.4066	.4191	.3881		.3921
8	.4191	.4066	.3734	.381	.3696		.4108
9	.362	.3696	.3841		.2957	.2957	
10	.2896		.3475	.3658	.3224	.2957	.2772
11	.3077		.3696	.3326	.3403	.2957	.2587
12	.3292		.3696	.3326	.197	.3326	.2587
13	.3258		.3696	.2926	.2865	.2926	.2587
14	.3292		.3511	.3292	.3801	.2195	.2587
15	.3326		.3361	.3292	.3801	.2926	.2957
16	.3696		.3361	.3258	.3841		.2926
17	.362			.3658	.3658		
18	.362	.4481		.4572	.3696		
19	.462						
20	.5304	.4854		.6697			
21	.5068	.5228		.4706			
22	.4938			.439	.4481		
23	.4024			.3921			
24	.381	.3772	.362	.381	.4527	.3326	.3772
Max	.5304	.5228	.4108	.6697	.4527	.3326	.4108
Min	.2896	.2534	.3361	.2926	.197	.2195	.2587
Avg	.3791	.3784	.3619	.3869	.3349	.2946	.3147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 205 / 11 KV KASEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	***	1.166	1.6004	1.5203	***	***
2	***	***	1.1248	1.5242	1.5203	***	***
3	***	***	1.1248	1.5242	1.4232	***	***
4	***	***	1.1385	1.5242	1.4232	***	***
5	***	***	1.1248	1.5623	1.3904	***	***
6	***	***	1.2498	1.6004	1.3904	***	***
7	***	***	1.5935	1.7528	1.3916	***	***
8	.2667	***	.061	***	***		.0914
9	1.9204		.0625	***	***	2.0485	
10	1.9685		.0625	***	***	2.0934	1.5779
11	2.1605		.0625	***	***	2.1376	1.5432
12	1.9845		.0469	***	***	2.0729	
13			.048	***	***	1.9444	.7621
14			.0469	***	***	1.7593	.7621
15			.0469	***	***	1.8056	.7621
16	1.4723		.0625	***	***		1.9907
17	***	***		***	***	***	***
18	***	***		***	***	***	6.8587
19	***	***		***	***	***	
20	***	***		***	***	***	
21	***			.1067	***	***	
22	***			1.5546	***	***	***
23	***			1.6194	***	***	***
24	***	1.1873	1.3443	1.6004	***	***	***
Max	171.5747	187.4717	1.5935	175.3698	166.8955	179.8509	145.6487
Min	.2667	1.1873	.0469	.1067	1.3904	1.7593	.0914
Avg	96.2251	122.4732	.6098	71.0367	97.6745	98.7306	64.7538

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 206 / 11 KV NERLE AG. FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0957	2.1445	.061	***	***	1.7394	2.1125
2	1.9814	2.2245	.061	***	***	1.7394	2.0485
3	1.9814	2.1715	.061	***	***	1.7394	2.0485
4	1.9814	2.1091	.061	***	***		2.0485
5	2.0957	2.1091	.061	***	***	1.7394	2.1125
6	2.2862	2.0645	.061	***	***		2.1765
7	2.4387	2.0645	.061	***	***		2.2405
8	.0762	***	.061	.061	***	***	.0914
9	***	***	2.1296	2.0934	2.2028	***	***
10	***	***	2.1759	2.1559	2.2653	***	***
11	***	***	2.2184	2.1491	2.2994	***	***
12	***	***	2.1403	2.2184	2.2685	***	***
13	***	***	2.0988	2.3122	2.1451	***	***
14	***	***	2.037	2.2994	2.1872	***	***
15	***	***	2.0466	2.4691	2.0934	***	***
16	***	***	2.1376	1.9509	1.9372	***	***
17	***	***		.061	***	***	***
18	***	***		.0914	***		***
19	***	***		***	***		***
20	***	***		***	***	***	***
21	***	***		***			***
22	2.4453	***		***			
23	2.1445	***		***	1.7394		
24	2.2862	***	.061	***	1.7394	2.1125	2.1765
Max	169.2732	174.5163	2.2184	156.3026	181.436	185.9475	189.0421
Min	.0762	2.0645	.061	.061	1.7394	1.7394	.0914
Avg	64.9833	94.1000	1.0314	72.5214	74.8258	93.8498	90.9934

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 207 / 11 KV Wategaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.1543	.8749	1.6385	1.2963		.1524
2	.2286	.1543	.8749	1.6004	1.3443		.1524
3	.2286	.1389	.8749	1.6004	1.3283		.1524
4	.2286	.1372	.8749	1.6004	1.4074		.1524
5	.2286	.1372	1.1873	1.9433	1.3904		.1829
6	.2667	.1677	1.4998	2.0576	1.4685		.1829
7		.1677	1.4998	1.5242	1.5023		.1829
8		.2006	.1219	.1219	.108		.2134
9	1.7604		.061	.061	.0781	2.1765	
10	1.8084	1.6004	.0762	.0781	***	2.1445	1.7528
11	1.7604		.0781	.0781	.0617	2.1125	1.7375
12	1.7924	1.4998	.0926	.0937	.0617	1.7654	
13		1.4998	.0781	***	***	1.5586	.7621
14			.0625	***	.0469	1.4815	.7621
15		1.4373	.0625	.0791	.0625	1.4506	.7621
16	1.2803		.0457	.0648	.0463		1.5089
17	.1543			.1524			
18	.1852			.1852			
19	.1852						
20	.2006			.216			
21	.216			.1852			
22	.1829			1.5708			
23	.1852	.9602		1.4413			
24	.2667	1.1523	1.4083	1.6766	1.2963		.1829
Max	1.8084	1.6004	1.4998	128.0927	185.2323	2.1765	1.7528
Min	.1543	.1372	.0457	.061	.0463	1.4506	.1524
Avg	.5994	.6720	.5749	11.6878	22.2910	1.8128	.5893

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 208 / 11 KV Tambave Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2862	1.9364	.061	.0762	.061		2.1125
2	2.0576	1.9364	.061	.0762	.061		1.9204
3	2.0576	2.0809	.061	.0762	.0617		1.8884
4	2.0576	2.0809	.061	.0762	.0772		1.8884
5	2.0576	1.9044	.061	.0762	.0762		1.8884
6	1.9052	1.8084	.061	.0762	.0762		1.9204
7	1.9052	1.692	.061	.0762	.061		1.9204
8	.1143	.061	.061	2.8487	.061		.0914
9	.061		2.878	2.8487	2.7587	.061	
10	.061		2.9729	2.8807	2.8349	.061	.0463
11	.061		2.9887	2.8433	2.9371	.0648	.0625
12	.061		3.1459		1.6842	.0469	.0781
13			3.0407	2.8622	2.4846	.0469	.0463
14			2.8487	2.8147	2.5617	.0469	.0463
15			2.609	2.5301	2.5621	.0625	.0617
16	.061		2.609	2.359	2.4684		.0617
17	.061			.061			
18	.061			.0762			
19	.0914						
20	.0914			.0762			
21	.0762			.0762			
22	2.0081			.0762			
23	1.9364			.0762			
24	2.4768	1.9364	.061	.0762	1.9204	1.6129	2.2085
Max	2.4768	2.0809	3.1459	2.8807	2.9371	1.6129	2.2085
Min	.061	.061	.061	.061	.061	.0469	.0463
Avg	1.0261	1.7152	1.3907	1.0472	1.3381	.2504	1.0151

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 209 / 11 KV Someshwar

PURELY LIS FEEDERS

Bhairavnath LI Feeder KV- 11 /
OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.4481	.7392	.5716	.4435	
2	.4763	.4435	.7392	.5716	.4435	
3	.5716	.5359	.7207	.5716	.5415	
4	.5716	.5304	.7282	.2858	.5415	
5	.6287	.6401	.7282	.2858	.567	
6	.6287	.8962	.7468	.2858	.567	
7	.8764	.9335	.7577	.3429	.6468	
8	.9145	.8871	.6653	.2743	.6653	
9	.9335		.8316	.5121	.6767	.7655
10	.9709		.8326		.695	.7207
11	.924		.823	.5068	.6697	
12	1.4937		.7499	.6516	.6485	.7095
13	.8962		.7499	.6036	.7011	.6767
14	.8745		.7316	.6036	.7011	.6401
15	.9149		.6516	.1629	.6241	.6767
16	.2218			.1629	.6001	
24	.4763					
Max	1.4937	.9335	.8326	.6516	.7011	.7655
Min	.2218	.4435	.6516	.1629	.4435	.6401
Avg	.7559	.6644	.7464	.4262	.6083	.6982

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 210 / 11 KV Krishna LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.6201	1.543	1.7147	.5895	
2	.1905	.6201	1.543	1.7147	.5895	
3	.1905	.6687	1.543	1.7147	.6687	
4	.2477	.9088	1.543	1.7147	.8916	
5	.2477	1.2656	1.543	1.7147	1.2094	
6	.2477	1.6991	1.7337	1.7337	1.2795	
7	.8383	1.8604	1.7857	1.8671	1.6644	
8	1.3146	1.6975	1.543	1.7193	1.6289	
9	1.7177		1.406	1.7558	1.6461	1.595
10	1.8229		1.3889		1.6289	1.5604
11	1.7878		1.5775	1.7741	1.6461	1.5927
12	1.4723		1.595	1.7926	1.6632	1.5249
13	1.3253		1.2136	1.7741	1.6289	1.5074
14	1.8111		1.2136	1.6827	1.6118	1.4754
15	1.9044		1.2346	1.6827	1.6289	1.1568
16	1.2174		1.0288	.9945	1.7164	
Max	1.9044	1.8604	1.7857	1.8671	1.7164	1.595
Min	.1905	.6201	1.0288	.9945	.5895	1.1568
Avg	1.0329	1.1675	1.4647	1.6900	1.3557	1.4875

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 202 / 11 KV YELUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3961	.415	.3584	.3772	.3772	.3772
2	.0377	.415	.3395	.3584	.3395	.3584
3	.0377	.415	.3395	.3584	.3395	.3395
4	.3961	.415	.3584	.3584	.3395	.3395
5	.4715	.4527	.415	.3772	.415	.415
6	.5658	.5093	.5281	.4715	.4715	.5281
7	.5228	.4527		.5228	.4904	.5093
8	.0407	.0943		.4066	.4066	.4119
9	.0416	.4163		.3841	.3601	.394
10	.3582	.8573		.3429	.3429	.3086
11	.3366	.3086		.3086	.3086	.2915
12	.3506	.3086		.3429	.4458	.1829
13	.3506	.3086		.3429	.2743	.4458
14	.3961	.3429	.2401	.3429	.3086	.2743
15	.3544	.3429	.3429	.3429	.3258	.2743
16	.3841	.3429	.3429	.3944	.3258	.2572
17	.3403	.3429	.3429	.2229	.2743	.2401
18	.4251	.3641	.4119	.3475	.3681	.3898
19	.5175	.5373	.5304	.3658	.5068	.4887
20	.5914	.5914	.6348	.6224	.6283	.5601
21	.5914	.5788	.6224	.5175	.5788	.5415
22	.5975	.5788	.547	.547	.5281	.5281
23	.5281	.4294	.4715	.4715	.4527	
24	.333	.4527	.3961	.415	.3961	.415
Max	.5975	.8573	.6348	.6224	.6283	.5601
Min	.0377	.0943	.2401	.2229	.2743	.1829
Avg	.3735	.4280	.4248	.3976	.4002	.3857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 203 / 11 KV Aitwadi Kh -Gaothan-
Feeder KV- 11 / OUTGOING**GAOTHAN FEEDER**

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3395	.3395	.3584	.2641	.3395
2	.3206	.3395	.3206	.3395	.2641	.3395
3	.3018	.3395	.3206	.3206	.2641	.3206
4	.3018	.3395	.3206	.3018	.2641	.3206
5	.3961	.3772	.3772	.3584	.3395	.3772
6	.5093	.415	.4715	.3961	.4527	.4854
7	.4668	.4904	.4287	.4481	.415	.462
8	.3696	.3734	.3086	.3696	.4108	.3582
9	.2896	.2743	.3086	.3109	.3086	.3077
10	.3224	.3086	.3086	.2743	.3086	.2743
11	.2804	.3086	.3772	.2743	.3086	.2401
12	.298	.3086	.3429	.2743	.3086	
13	.2804	.3086	.3429	.3086	.3429	.3086
14	.3189	.3086	.3429	.3086	.3429	.3086
15	.2804	.3086	.3429	.3429	.3086	.3086
16	.2804	.3086	.3429	.3429	.2804	.3429
17	.2865	.3121	.3086	.3086	.2915	.3086
18	.3982	.3856	.4298	.3506	.3721	.3898
19	.462	.5068	.5487	.3982	.4706	.5068
20	.5175	.6161	.5729	.5281	.5175	.5304
21	.4904	.5788	.5788	.5281	.4854	.5175
22	.4527	.547	.5041	.4904	.4668	.4668
23	.415	.3961	.415	.4158	.3772	
24	.3584	.3429	.3584	1.6651	.3395	.3395
Max	.5175	.6161	.5788	1.6651	.5175	.5304
Min	.2804	.2743	.3086	.2743	.2641	.2401
Avg	.3640	.3806	.3880	.4173	.3543	.3706

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 204 / 11 KV WASHI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3018	.3206	.3395	.2641	.3206
2	.3206	.3018	.3018	.3206	.2641	.3018
3	.3018	.0302	.3018	.3018	.2641	.3018
4	.3018	.3018	.3206	.3018	.2641	.3018
5	.3772	.3395	.3772	.3772	.3395	.3206
6	.4715	.415	.4715	.415	.415	.4668
7	.0467	.4904	.4458	.4668	.4527	.462
8	.0407	.4854	.3772	.3696	.3658	.443
9	.0452	.5281	.3772	.4024	.3772	.2534
10	.3582	.3086	.3429	.3429	.3086	.2743
11	.3155	.2743	.3429	.3086	.2743	.2915
12	.333	.3086	.3429	.3429	.2743	.2572
13	.3506	.3086	.3429	.3429	.2743	.2229
14	.2454	.3429	.3429	.3258	.2743	.2401
15	.2629	.3086	.3429	.3086	.2743	.3258
16	.2454	.3086	.3429	.2915	.3086	.2743
17	.362	.3258	.3429	.2572	.2572	.2743
18	.4066	.3814	.394	.3403	.3189	.3544
19	.4066	.543	.5304	.4435	.4755	.4525
20	.1132	.6161	.5544	.5658	.5544	.499
21	.5175	.5601	.5601	.4715	.5228	.4668
22	.4904	.4715	.4715	.4527	.4481	.4527
23	.4527	.3772	.3961	.415	.3772	
24	.3395	.3395	.3395	.3584	.3395	.3206
Max	.5175	.6161	.5601	.5658	.5544	.499
Min	.0407	.0302	.3018	.2572	.2572	.2229
Avg	.3102	.3737	.3868	.3693	.3454	.3425

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 205 / 11 KV Aitwade Kh Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4413	1.4918	.0566	.0566	.0377	1.5927
2	1.4243	1.4586	.0566	.0566	.0377	1.5424
3	1.406	1.4586	.0566	.0566	.0377	1.4918
4	1.406	1.4586	.0566	.0566	.0377	1.4918
5	1.4575	1.4918	.0754	.0566	.0377	1.543
6	1.5432	1.5581	.0943	.0754	.0754	1.6108
7	1.7147	1.6766	.0686	.0754	.0754	.0914
8	.0377	.0351	.0686	.0754	.0754	.0724
9		.0343	2.0919	1.7635	1.5089	.0366
10	.0038	.0343	2.1948	2.2291	1.6118	.0343
11	.0377	.0343	2.1948	2.2977	1.7833	.0343
12	.0351	.0343	2.2291	2.4006	1.8861	.0343
13	.0377	.0686	1.3717	2.6063	2.0919	.0343
14	.0351	.0686	.0171	2.7778		.0343
15	.0351	.0686	1.6804	2.4006	2.1948	.0343
16	.0351	.0686	1.5775	2.0919	2.6749	.0343
17	.0351	.0566	.0343	1.6118		.0343
18	.0362	.0566	.0566	.0347	1.8176	.0526
19	.0566	.0754	.0566	.0543	.0566	.0754
20	.0754	.0754	.0566	.0754	.0566	.0754
21	1.5939	.0754	.0566	.0754	.0566	.0754
22	1.5939	.0754	.0566	.0566	1.8442	1.95
23	1.5581	.0566	.0566	.0566	1.6766	
24	1.4922	1.4918	.0566	.0566	.0377	1.6263
Max	1.7147	1.6766	2.2291	2.7778	2.6749	1.95
Min	.0038	.0343	.0171	.0347	.0377	.0343
Avg	.7431	.5418	.5967	.8791	.8960	.5914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 207 / 11 KV WASHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	***	.4115	.6964	.8619	***	***
2	***	***	.381	.7045	.7956	***	***
3	***	***	.381	.6718	.7956	***	***
4	***	***	.381	.663	.7956	***	***
5	***	***	.4268	.7712	.9282	***	***
6	***	***	.7716		1.0277	***	***
7	***	***	.8916	.8718	1.094	***	***
8	.0075	.0943	.0686	***	***	.0732	
9		1.3763	.0686	***	***	1.8461	
10	.1707	1.3717	.0686	***	***	1.8861	
11	1.326	1.3546	.0343	***	***	1.8519	
12	1.1603	1.3717	.0514	***	***	1.7147	
13	1.0014	1.3032	.0514	***	***	1.4403	.381
14	.7956	.9602	.0686	***	***	1.2346	.381
15	.7956	.9259	.0857	***	***	1.166	.381
16	.8478	.9602	.0857	***	***	1.0974	
17	***	***	.0857	***	***	***	
18	***	***	.0943	***	***	***	***
19	***	***	.1132	***	***	***	***
20	***	***	.1132	***	***	***	***
21	***	.0943	.1132	.0943	***	***	***
22	***	.6958	1.1203	1.2266	***	***	***
23	***	.5468	.8642	1.1603	***	***	***
24	***	.0566	.442	.7287	***	***	***
Max	123.5513	139.1739	1.1203	131.1864	117.8523	111.7201	120.7897
Min	.0075	.0566	.0343	.0943	.7956	.0732	.381
Avg	58.4261	44.8092	.2989	39.3830	65.4688	58.2390	84.1650

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 208 / 11 KV YELUR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943		.6706	1.3279	1.3765	.0943
2	.0924	.0686	.6401	1.2955	1.3603	.0943
3	.0094	.0686	.6401	1.3108	1.3603	.0943
4	.0943	.0686	.6097	1.3108	1.3603	.0943
5	.0113	.0686	.7164	.4144	1.4255	.0943
6	.0132	.0857	1.2018	1.5912	1.5415	.1132
7	.0113	.0857	1.4746	1.7901	1.5581	.0943
8	.0943	.1029	.0686	.0943	.0895	.1109
9	.2171	2.5549	.0686	.0754	.0857	2.6189
10	2.2283	2.4006	.0686	.0857	.0686	2.572
11	2.0481	2.3491	.0857	.0857	.0686	2.5206
12	1.873	2.4006	.0686	.0686	.0686	2.2291
13	1.6244	2.0748	.0857	.0686	.0857	1.6804
14	1.2809	1.5947	.1029	.0857	.0686	1.5775
15	1.2654		.1029	.0857	.0686	1.5775
16	1.4243	1.5089	.1029	.0857	.0686	1.6289
17	.0905	.0867	.1029	.0686	.0686	.0229
18	.0739	.0876	.132	.0857	.0905	.0905
19	.1109	.1267	.1509	.1109	.1294	.1307
20	.132	.1294	.1509	.133	.1509	.132
21	.132	.112	.132	.132	.132	.132
22	.1132	.9922	1.757	1.9062	.1132	.1132
23	.1132	.8642	1.6575	1.757	.0943	
24	1.873	.0943	.6859	1.3765	1.4089	.0943
Max	2.2283	2.5549	1.757	1.9062	1.5581	2.6189
Min	.0094	.0686	.0686	.0686	.0686	.0229
Avg	.6259	.8148	.4782	.6394	.5351	.7787

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 209 / 11 KV Kundalwadi Ag feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3491	2.2043	.0566	***	***	2.0348	
2	2.2291	2.1795	.0566	***	***	2.0348	
3	2.1434	2.1795	.0566	***	***	1.9784	
4	2.0348	2.1795	.0566	***	***	1.9448	
5	2.0348	2.2131	.0566	***	***	1.9669	
6	2.1195	2.2131	.0754	***	***	2.1195	
7	2.3148	2.146	.0514	***	***	2.1795	
8	***	***	.0514	.0754	.0754	***	***
9	***	***	3.1207	3.0864	3.4979	***	***
10	***	***	3.3265	3.2579	3.0521	***	***
11	***	***	3.1207	3.3265	3.0178	***	***
12	***	***		2.915	3.0864	***	***
13	***	***		2.7778	2.915	***	.381
14	***	***		2.7778	2.8807	***	.381
15	***	***		2.915	2.8121	***	.381
16	***	***	3.4294	3.1207	2.8121	***	
17	***	***	.0343	***	***	***	
18	***	***	.0566	***	***	***	***
19	***	***	.0566	***	***	***	***
20	***	***	.0566	***	***	***	***
21	***	***	.0566	***	.0566	.0754	
22	2.4756	***	.0566	***	2.4417	2.572	
23	2.3868	***	.0566	***	2.3061		
24	2.3491	***	.0566	***	.0377	2.1704	
Max	142.9654	81.9937	3.4294	99.9079	102.9562	86.9525	97.1652
Min	2.0348	2.146	.0343	.0754	.0377	.0754	.381
Avg	39.8286	45.1354	.6945	48.8987	35.0002	34.5845	52.6182

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244067 / 33/11 KV YEDENIPANI STN

Feeder No / Name : 202 / 11 KV ITKARE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9113	1.8176	.1307	.1478	.1494	1.5089	1.8861
2	1.7901	1.7147	.1307	.1294	.1307	1.4746	1.7147
3	1.704	1.7147	.1307	.1294	.1307	1.4746	1.7147
4	1.6575	1.829	.1478	.1478	.1307	1.5729	1.7833
5	1.7368	1.9387	.1848	.2033	.168	1.6095	1.8519
6	1.8023	2.1216	.1829	.2218	.2075	1.6461	2.1365
7	1.9204	2.1948	.1949	.2172	.1848	2.2081	1.9393
8	.1646	.1715	.1848	.1791	.1578	.181	.1463
9	.1294	.1463	2.9767		2.9058	.1372	.1463
10	.1629	.1463	3.4705	3.0178	2.8349	.1372	.1463
11	.1629	.1478	3.083	2.8807	2.5968	.1372	.1612
12	.0554	.128	2.9412	2.572	2.5968	.1372	.1612
13		.1463	2.5659	2.4874	2.1672	.1595	.1612
14	.1663	.1478	2.3579	2.3891	2.1152	.1646	
15	.1646	.1478	2.3579	2.3167	1.8519	.128	
16	.1646	.1463	2.3891	2.1719	1.7833	.1433	
17	.1543	.1494	.1372	.12	.1402	.1463	
18	.2957	.1494	.1578	.1372	.1578	.1663	
19	.1715	.2195	.2534	.1829	.1829	.2012	
20	.2058	.2561	.2561	.2033	.1715	.2587	
21	.2195	.2561	.2241	.1867	.1829	.2402	
22	2.332	.2195	.2241	.1867	2.0119	2.1948	
23	2.3777	.1663	.1867	.1698	1.8461	2.1262	
24	2.0687	2.0233	.1646	.1663	.1698	1.6118	2.0233
Max	2.3777	2.1948	3.4705	3.0178	2.9058	2.2081	2.1365
Min	.0554	.128	.1307	.12	.1307	.128	.1463
Avg	.9356	.7541	1.0431	.8941	1.0406	.8236	1.1409

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244067 / 33/11 KV YEDENIPANI STN

Feeder No / Name : 204 / 11 KV ITKARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.2926	.3326	.3292	.3292	.3326	.3326
2	.2561	.2926	.3326	.3292	.2926	.3326	.3326
3	.2561	.2926	.2957	.2926	.2926	.3326	.3326
4	.2561	.2926	.2957	.2926	.2926	.3326	.3326
5	.3109	.3658	.3326	.3292	.3109	.3696	.3326
6	.3658	.3658	.4024	.3841	.3292	.439	.439
7	.4207	.3658	.3696	.3658	.3841	.4066	.4024
8	.3292	.362	.2987	.3109	.3292	.3326	.2957
9	.3475	.362	.3696		.2743	.3696	.2772
10	.2896	.3326	.4066	.3326	.3326	.3292	.2772
11	.2534	.3326	.3292	.3292	.3734	.3292	.2378
12	.2743	.2957	.3511	.3292	.3734	.2561	.2561
13	.0934	.2957	.2561	.2561	.3361	.3109	.2561
14	.3142	.3109	.3142	.2561	.3361	.3109	
15	.2957	.3109	.3142	.2957	.3547	.2896	
16	.2561	.3142	.3326	.2218	.3361	.3142	
17	.3142	.3174	.3326	.2957	.3142	.3142	
18	.2957	.3361	.3734	.2957	.2957	.3361	
19	.4024	.4024	.4207	.4207	.439	.4207	
20	.4435	.4755	.4755	.4572	.4805	.4572	
21	.4435	.439	.4207	.4572	.439	.439	
22	.4024	.4024	.4207	.4207	.3696	.439	
23	.3658	.4024	.4207	.3841	.3658	.3696	
24	.3292	.3292	.3658	.3658	.3658	.3696	.3696
Max	.4435	.4755	.4755	.4572	.4805	.4572	.439
Min	.0934	.2926	.2561	.2218	.2743	.2561	.2378
Avg	.3155	.3454	.3568	.3370	.3478	.3556	.3196

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244067 / 33/11 KV YEDENIPANI STN

Feeder No / Name : 205 / Shivtirtha Express Feeder NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0617	.0686	.0686	.0686	.0617	.0686	.0686
2	.0465	.0686	.0686	.0693	.061	.0686	.0686
3	.0549	.0686	.0686	.0686	.0602	.0686	.0686
4	.0291	.04	.0686	.0693	.0191	.0229	.0305
5	.0187	.0152	.0271	.0686	.0232	.0152	.0274
6	.0183	.0061	.0171	.0554	.0038	.0042	.0248
7	.0194	.0038	.0114	.0038	.0038	.0038	.0183
8	.0286	.0038	.0244	.0038	.0191	.0038	.0191
9	.0175	.013	.005		.0191	.0061	.0191
10	.0171	.0152	.0038	.0038	.0051	.0091	.0046
11	.0554	.0943	.0118	.0038	.0754	.0747	.0754
12	.0554	.0943	.0762	.0686	.0953	.0754	.0754
13	.037	.0943	.0943	.0857	.0953	.0943	.0754
14	.0343	.0943	.0943	.0686	.0754	.0943	
15	.0943	.0943	.0943	.0686	.0171	.0943	
16	.0934	.0267	.0343	.0229	.0116	.0943	
17	.056	.0248	.0343	.0152	.005	.0943	
18	.056	.0232	.0343	.0038	.0038	.0179	
19	.0343	.013	.0309	.005	.0038	.0137	
20	.0076	.0111	.0286	.0046	.0061	.0152	
21	.0514	.0099	.0114		.0038	.0152	
22	.0076	.0754	.0248	.0465	.0686	.0739	
23	.0686	.0724	.0754	.0762	.0686	.0754	
24	.0686	.0686	.0701	.0701	.0693	.0686	.0754
Max	.0943	.0943	.0943	.0857	.0953	.0943	.0754
Min	.0076	.0038	.0038	.0038	.0038	.0038	.0046
Avg	.0430	.0458	.0449	.0432	.0365	.0489	.0465

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244111 / 33/11 KV Karanjawade S/S

Feeder No / Name : 201 / 11 KV Karanjawade Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2804	.2804	.3155	.3155	.3506	.3506	.3856
2	.2804	.2804	.3155	.3155	.3506	.3506	.3856
3	.2804	.2804	.0602	.3155	.3506	.3155	.3506
4	.2804	.3155	.3155	.3506	.3856	.3506	.3506
5	.2804	.3155	.3506	.3506	.4207	.3856	.3856
6	.3506	.3506	.4207	.3856	.4557	.3155	.4207
7	.2804	.3506	.3506	.3155	.3856	.3155	.3155
8	.3506	.3506	.3856	.3506	.4557	.3506	.3506
9	.3155	.3506	.3506	.3856	.4207	.2804	.3856
10	.3155	.3506	.3506	.3856	.3856	.3155	.3856
11	.3155	.3856	.3856	.3506	.3506	.2804	.2804
12	.3155	.3856	.3856	.3155	.3506	.3506	.3506
13	.2454	.3506	.3506	.3856	.3506	.3506	.2629
14	.2804	.3856	.3506	.3155	.3856	.3155	
15	.3155	.3856	.3506	.3155	.4207	.3155	
16	.3155	.3856	.3506	.3155	.3506	.3506	
17	.2804	.3856	.3506		.3506	.3506	
18	.3155	.5258	.3506	.2987	.3506	.2804	
19	.4207	.5258	.5258	.3856	.4207	.3506	
20	.5609	.5959	.631	.5258	.5258	.4908	
21	.5609	.5959	.5959	.5959	.5258	.4557	
22	.4908	.5258	.5258	.5258	.5258		
23	.3506	.3856	.4908	.4557	.4908	.4207	
24	.3155	.3155	.5258	.3155	.3856	.3856	.4207
Max	.5609	.5959	.631	.5959	.5258	.4908	.4207
Min	.2454	.2804	.0602	.2987	.3506	.2804	.2629
Avg	.3374	.3900	.3911	.3727	.4061	.3490	.3593

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244111 / 33/11 KV Karanjawade S/S

Feeder No / Name : 202 / 11 KV Devarde AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0747	.9877	1.3123	1.2193	.0747	.0747
2	.0747	.0747	.9998	1.2811	1.2193	.0747	.0747
3	.0747	.0747	.9998	1.2811	1.2193	.0747	.0747
4	.0747	.0943	1.012	1.3123	1.2811	.0943	.0747
5	.0747	.0934	1.1069	1.3123	1.3435	.0943	.0747
6	.112	.0934	1.3763	1.3748	1.3272	.112	.0747
7	.112	.0747	1.6004	1.5935	1.1728	.112	.0934
8	.0747	.1132	.0747	.0934	.112	.112	.0934
9	2.3765	2.4371	.0747	.0747	.112	2.5286	2.3434
10	2.4691	2.4996	.0701	.0747	.0934	2.6246	2.1247
11	2.3457	2.2497	.0747	.0747	.112	2.4966	1.9685
12	2.1605	1.9997	.0747	.0747	.112	2.1559	
13	1.9753	1.8747	.0747	.112	.1132	1.8747	
14	1.5432	1.7497	.0934	.112	.1132	1.9372	
15		1.5623	.1132	.112	.1132	1.8747	
16	1.6667	1.4998	.0754	.0747	.1132	1.5623	
17	.0762	.112	.1132		.0943	.112	
18		.112	.1132	.0747	.0754	.112	
19		.112	.1132	.0934	.1509	.112	
20	.0934	.112	.1132	.0934	.0943	.112	
21	.0934	.1494	.0943	.0934	.1307	.112	
22	.0934	1.2193	1.8107	1.5242	.1494		
23	.0934	1.2193	1.4998	1.4632	.112	.112	
24	.0747	.0934	.9633	.0747	1.2498	.0934	.0934
Max	2.4691	2.4996	1.8107	1.5935	1.3435	2.6246	2.3434
Min	.0747	.0747	.0701	.0747	.0754	.0747	.0747
Avg	.7492	.8206	.5679	.5951	.4931	.8073	.5971

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244111 / 33/11 KV Karanjawade S/S

Feeder No / Name : 203 / KARVE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3988	1.0703	.0602	.0602	.0753	.3567	.602
2	1.3172	.9655	.0602	.0602	.0602	.3269	.602
3	1.2456	.9168	.0602	.0602	.0602	.2972	.602
4	1.206	.9232	.0602	.0602	.0903	.3567	.602
5	1.2296	1.0413	.0602	.0753	.0903	.4161	.6321
6	1.5334	1.3534	.0903	.0903	.1204	.535	.6321
7	1.8057	1.6948	.1204	.1204	.1204	.5944	.7526
8	.3658	.4584	.1204	.1204	.1204	.0594	.0753
9	.1753	.2092	.9031	.7526	.6622	.0892	.0753
10	.1934	.2221	.9031	.8128	.6923	.0903	.0892
11	.1949	.2237	.7526	.6923	.6622	.0903	.0743
12	.1196	.1898	.6622	.5117	.6622	.0903	
13		.1669	.602	.5719	.5268	.0903	
14	.0301	.2122	.5418	.5719	.5418	.0753	
15	.1052	.2199	.5719	.602	.5719	.0753	
16	.1469	.2153	.6321	.0602	.5418	.0903	
17	.2122	.2237	.0903		.0753	.0892	
18	.2374	.2675	.0903	.0753	.0753	.0743	
19	.3048	.2858	.1204	.0903	.1189	.0892	
20	.2842	.2633	.0903	.0903	.0892	.0892	
21	.2903	.2473	.1204	.0903	.0892	.1189	
22	1.257	.232	.0903	.0903	.3715		
23	1.3424	.192	.0903	.0903	.3715	.7526	
24	1.3694	.5982	.0602	.4458	.0753	.3715	.6622
Max	1.8057	1.6948	.9031	.8128	.6923	.7526	.7526
Min	.0301	.1669	.0602	.0602	.0602	.0594	.0743
Avg	.7115	.5164	.2897	.2694	.2860	.2269	.4501

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244111 / 33/11 KV Karanjawade S/S

Feeder No / Name : 204 / Ganesh Chikurde LIS Feeder

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1991	.2172	.1629	.1448	.1448	.0905
2	.1991	.2172	.1629	.1448	.1448	.0724
3	.1991	.2172	.1629	.1448	.1448	.0724
4	.1991	.2172	.1629	.1448	.1448	.0724
5	.1991	.2353	.1629	.1448	.1448	.1629
6	.2172	.2353	.1629	.1448	.1448	.1629
7	.2353	.1957	.181	.181	.1629	.2172
8	.2353	.2353	.181	.1629	.1629	.181
9	.2353	.2172	.1629	.1629	.1629	.181
10	.2353	.2353	.1629	.1629	.1629	.181
11	.2353	.2353	.1629	.1629	.1448	.181
12	.2353	.2353	.181	.1629	.1629	.181
13	.2353	.2353	.181	.1629	.1629	.181
14	.2353	.2353	.181	.1629	.1629	.181
15	.2353	.2353	.1629	.1629	.1629	.181
16	.2534	.181	.181		.1629	.1629
18			.181			
21		.181	.181			
Max	.2534	.2353	.181	.181	.1629	.2172
Min	.1991	.181	.1629	.1448	.1448	.0724
Avg	.2240	.2213	.1709	.1569	.1550	.1539

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 248008 / 220 KV PETH SUBSTATION

Feeder No / Name : 401 / 33KV MIDC (FROM PETH EHV) NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	29-MAR-17	30-MAR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	11.797	14.6777	16.118	16.5295	15.9122
2	12.0028	14.5405	15.3635	16.8725	15.4321
3	11.6598	14.2661	15.1578	15.8436	15.0892
4	11.3855	14.1976	15.2949	16.118	14.4033
5	10.8368	13.786	14.5405	16.0494	14.1976
6	11.6598	14.0604	15.2264	16.7353	14.3347
7	12.4143	15.0892	15.3635	17.8327	15.1578
8	9.3279	10.631	12.963	13.786	11.1797
9	13.3745	15.0206	19.6159	17.1468	11.5912
10	15.8436	15.9808	21.6736	19.6159	12.2085
11	17.1468	17.8327	22.3594	20.7819	12.8944
12	16.6667	18.107	22.428	20.8505	12.7572
13	16.118	14.6091	21.8793	19.9589	9.3964
14	12.3457	13.786	20.0275	18.6557	9.1907
15	14.8834	13.2373	20.6447	19.6845	9.6708
16	15.3635	14.952	20.6447	19.8903	11.797
17	12.6886	10.974	14.4033	14.6091	9.5336
18	11.9342	11.8656	14.129	13.0316	9.3279
19	11.1797	11.7284	13.4431	13.2373	9.3964
20	11.5912	12.0028	13.5117	13.3745	10.0137
21	10.5624	10.4938	12.4143	12.3457	9.465
22	14.2661	12.963	15.9122	15.9122	12.4829
23	14.8834	13.1687	16.5981	16.2552	13.6489
24	14.7462	12.8258	15.8436	16.4609	13.5803
Max	17.1468	18.107	22.428	20.8505	15.9122
Min	9.3279	10.4938	12.4143	12.3457	9.1907
Avg	13.1116	13.7832	16.8982	16.7324	12.1942

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 248008 / 220 KV PETH SUBSTATION

Feeder No / Name : 403 / (Kurloop)Shirala

Feeder KV- 33 / INCOMING

DATE	01-APR-17
HR	Load (MW)
24	9.8857
Max	9.8857
Min	9.8857
Avg	9.8857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 248008 / 220 KV PETH SUBSTATION

Feeder No / Name : 405 / 33 KV Dindayal Sut Girani NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING (NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-APR-17
HR	Load (MW)
24	1.2894
Max	1.2894
Min	1.2894
Avg	1.2894

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 248008 / 220 KV PETH SUBSTATION

Feeder No / Name : 406 / 33 KV Echo Board

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-APR-17
HR	Load (MW)
24	3.0087
Max	3.0087
Min	3.0087
Avg	3.0087

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 248008 / 220 KV PETH SUBSTATION

Feeder No / Name : 407 / 33 KV Kasegaon Feeder
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-APR-17
HR	Load (MW)
24	5.2126
Max	5.2126
Min	5.2126
Avg	5.2126

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 201 / 11 KV BIUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.061	.1364	1.861	4.3287	4.2258	.1749	.1688
2	.0617	.1364	1.861	4.1609	3.4751	.1749	.1699
3	.1219	.1356	1.8328	4.1316	3.4244	.1749	.1699
4	.1387	.1372	1.8328	4.0788	3.3482	.1749	.1688
5	.1379	.1356	1.9738	4.2341	3.4294	.1749	.1688
6	.1372	.1676	2.0866	4.3438	3.6789	.1749	.1699
7	.1524	.1676	1.9315	4.3214	3.5734	.1749	.1856
8	.2286	.3307	.0705	.1829	.3951	.2652	.2134
9	4.0695	5.8771	.0655	.1699	.1665	5.7723	5.7247
10	3.277	5.7133	.0819	.1951	.0762	5.964	5.9213
11	5.2446	5.2987	.064	.1341		5.8223	5.6394
12	5.3536	4.984	.0625	.1505		5.5746	2.8959
13	2.8197	4.2867	.0937	.1816	.2652	5.2987	
14	2.5408	5.2004	.0937	.1654	.1749	3.8257	
15	2.8959	5.1357	.0903	.1524	.0762	1.5844	
16	5.1905	5.1006	.0983	.192	.1467	2.8258	2.1338
17	.4702	.596	.0983	.1505	.2652	.5182	.6859
18	.1364	.1467	.0914	.1654	.2793	.1387	.0762
19	.1665	.1608	.0914	.1654	.2652	.1676	.0762
20	.1642	.1467	.0914	.1665	.2652	.1676	.0762
21	.1515	.1467	.0914	.1654	.189	.1688	.0762
22	.1356	4.5508	2.0309	4.7284	.1608	.1676	.0762
23	.1341	4.8019	2.0679	5.0755	.1608	.1534	.0762
24	.1225	2.6513	1.8892	4.6963	2.127	.1749	.1688
Max	5.3536	5.8771	2.0866	5.0755	4.2258	5.964	5.9213
Min	.061	.1356	.0625	.1341	.0762	.1387	.0762
Avg	1.413	2.3394	.8563	1.9349	1.3713	1.6589	1.1925

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 202 / 11 KV SHIRALA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0709	.0294	.2915	.8688	.8261	.0309	.0793
2	.0705	.029	.2949	.8602	.7948	.0309	.0793
3	.0709	.0297	.2591	.8329	.7697	.0008	.0534
4	.0309	.0301	.2622	.82	.7934	.0309	.0709
5	.0305	.029	.3315	.8322	.8051	.0309	.0751
6	.0305	.0316	.431	.8737	.8863	.0728	.0762
7	.0816	.0728	.3978	.9556	.9168	.0724	.0808
8	.1658	.1292	.0305	.0743	.0575	.0576	.117
9	1.2463	1.3005	.029	.0636	.0491	1.1599	1.0131
10	1.201	1.2022	.029	.0758	.0637	1.0932	1.0051
11	1.105	1.1595	.0328	.0766	.0678	1.0642	.9233
12	1.0383	1.1001	.0282	.0777	.0755	1.0086	.4919
13	.57	1.0634	.0286	.0858	.0797	.9389	
14	.9487	1.039	.0286	.0804	.0766	.9275	
15	.5586	1.0825	.0282	.0846	.0785	.8612	
16		1.0882	.0305	.0796	.0717	.8188	.3925
17	.0732	.0496	.0282	.0293	.0682	.0777	.0591
18	.0891	.0888	.0305	.0831	.0758	.0812	.0431
19	.0926	.0926	.0305	.0819	.0861	.0797	.0541
20	.0957	.0968	.0305	.0865	.093	.0858	.0476
21	.0854	.0972	.0305	.1128	.0941	.0842	.0499
22	.061	.7934	.381	.8178	.069	.0774	.0404
23	.0721	.7659	.4062	.8268	.0553	.0838	.0404
24	.0332	.4538	.3277	.8757	.3666	.0823	.0637
Max	1.2463	1.3005	.431	.9556	.9168	1.1599	1.0131
Min	.0305	.029	.0282	.0293	.0491	.0008	.0404
Avg	.3401	.4939	.1583	.4023	.3050	.3688	.2312

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 203 / 11 KV NATH AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6401	.5575	.061	.061	.0579	.5243	.4374
2	.6249	.5647	.061	.061	.0594	.5243	.4374
3	.6249	.5719	.061	.061	.0594	.4915	.4218
4	.6481	.6097	.061	.061	.0579	.4915	.4167
5	.6401	.602	.061	.061	.0594	.5571	.4167
6	.7253	.6241	.061	.0762	.0892	.5898	.4218
7	.7407	.6539	.061	.0781	.0903	.6299	.4687
8	.0772	.0579	.0762	.0937	.0892	.0457	.0772
9	.0617	.0446	1.0467	.9145	.6401	.0457	.0594
10	.0446	.061	1.0311	.9633	.583	.0446	.061
11	.0463	.0671	1.0311	.9031	.9496	.0457	.0594
12	.061	.0594	1.0242	.884	1.0004	.0457	.0602
13		.0914	.9374	.8535	.9614	.029	
14	.0457		.8192	.8322	.9221	.0457	
15		.0594	.7621	.8322	.9221	.0594	
16	.061	.061	.6874	.8025	.7449	.061	
17	.0594	.0579	.0579		.061	.0617	
18	.0903	.0762	.0772	.0743	.0762	.061	
19	.0903	.1143	.0914	.0892	.0762	.0762	
20	.0903	.0762	.0914	.088	.0762	.0762	
21	.088	.0762	.0914	.0734	.0762	.0762	
22	.7011	.061	.0762	.0724	.6062	.5624	
23	.6321	.061	.061	.0587	.5735	.5468	
24	.6859	.602	.061	.0594	.0602	.5506	.0594
Max	.7407	.6539	1.0467	.9633	1.0004	.6299	.4687
Min	.0446	.0446	.0579	.0587	.0579	.029	.0594
Avg	.3400	.2526	.3521	.3502	.3705	.2601	.2613

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 204 / 11 KV KAPARI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8008	2.1499	.7175	1.0181	1.4571	1.4396	1.8306
2	1.6179	2.0538	.7141	1.5012	1.411	1.4007	1.714
3	1.5966	2.0024	.6554	1.4837	1.3606	1.3039	1.5886
4	1.6236	1.9505	.6554	1.4692	1.4435	1.3466	1.6023
5	1.6684	2.1429	.8288	1.512	1.4982	1.5882	1.6446
6	2.0302	2.6128	.9946	1.6092	1.7098	1.9332	2.0358
7	2.4531	3.3481	.9568	1.7756	1.7829	2.4343	2.6528
8	.436	.532	.2157	.5514	.554	.62	.5609
9	2.1074	2.2718	1.7166	3.511	3.3791	1.9806	1.8179
10	2.0248	2.0767	1.5974	3.517	3.1789	1.9158	1.7893
11	1.8807	1.9799	1.6019	3.1078	2.843	1.8732	1.6369
12	1.8415	1.9463	1.4047	2.8205	2.5498	1.7459	.7582
13	.7537	1.8865	1.3062	2.7443	2.2615	1.6849	.1859
14	1.1301	1.8625	1.2738	2.5949	2.1514	1.6225	.2012
15	.7324	1.8541	1.1424	2.5622	2.2192	1.5341	.2065
16		1.8846	1.0204	2.6193	2.2343	1.4091	.4641
17	.4973	.4367	.2233	.472	.5501	.4443	.2309
18	.5518	.4297	.2336	.5354	.4586	.468	.2439
19	.5639	.4741	.2157	.5388	.491	.4889	.2652
20	.628	.5384	.262	.5578	.4817	.5342	.2972
21	.5709	.5231	.2311	.5121	.5079	.5456	.2911
22	2.8392	1.4609	.9122	1.5387	1.7505	2.3777	1.3154
23	2.6932	1.3976	.9244	1.4929	1.6769	2.4638	1.3062
24	2.2023	1.595	.7789	1.5055	1.7292	1.9605	2.0077
Max	2.8392	3.3481	1.7166	3.517	3.3791	2.4638	2.6528
Min	.436	.4297	.2157	.472	.4586	.4443	.1859
Avg	1.4889	1.6421	.8576	1.7313	1.6533	1.4632	1.1103

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 205 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	04-APR-17
HR	Load (MW)
11	.4024
12	.4066
Max	.4066
Min	.4024
Avg	.4045

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 206 / 11 KV BIUR GAOTAHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5955	.6298	.2561	.6192	.5914	.6192	.5447
2	.5388	.5841	.2195	.5765	.5746	.5472	.5503
3	.5311	.5293	.2195	.5342	.5464	.4904	.5218
4	.5289	.5285	.2561	.5681	.5826	.4858	.5391
5	.5432	.5799	.3326	.6138	.6466	.6081	.5811
6	.7232	.6573	.4066	.6942	.703	.7229	.6927
7	.8819	.8299	.3696	.8412	.82	.7811	.8063
8	.8392	.7602	.4066	.7681	.8391	.7685	.8215
9	.6727	.7121	.2561	.6634	.7861	.7076	.6451
10	.5605	.6546	.2587	.6756	.7072	.6976	.6519
11	.5822	.6923	.2957	.5552	.7404	.7491	.6382
12	.5819	.7594	.2587	.4016	.7011	.6771	.6752
13	.6119	.7525	.2957	.5548	.6477	.6306	.3955
14	.5993	.7868	.2957	.5556	.7301	.6661	.285
15	.5971	.6851	.2218	.6302	.7175	.5361	.3025
16	.5449	.6524	.2378	.6919	.6454	.5788	.2831
17	.6134	.6135	.2561	.6272	.6294	.5712	.2686
18	.6189	.7285	.3326	.6741	.7034	.5969	.3528
19	.8097	.8155	.499	.8273	.785	.7771	.3601
20	1.1389	1.0555	.5175	1.0795	.9766	1.017	.5003
21	1.0829	.9591	.4805	.9968	1.0006	1.0239	.5072
22	1.0128	.8981	.4435	.8844	.9176	.8953	.8493
23	.8676	.7369	.3696	.7651	.8223	.8185	.7488
24	.6975	.6832	.2957	.687	.679	.6836	.6274
Max	1.1389	1.0555	.5175	1.0795	1.0006	1.0239	.8493
Min	.5289	.5285	.2195	.4016	.5464	.4858	.2686
Avg	.6989	.7202	.3242	.6869	.7289	.6937	.5479

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 207 / 11 KV NATH GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0554	.0343	.0351	.0554	.0343	.0354	.0549
2	.0549	.0339	.0351	.0554	.0347	.0351	.0549
3	.0549	.0335	.0347	.0554	.0339	.0351	.0554
4	.0554	.0343	.0351	.0554	.0332	.0351	.0554
5	.0554	.0343	.0537	.0739	.0339	.0724	.0554
6	.0732	.0532	.0724	.0739	.0514	.0724	.0554
7	.0732	.0716	.0537	.0739	.0532	.0537	.0554
8	.0554	.0354	.0537	.056	.0514	.0537	.0739
9	.0549	.0366	.0549	.0554	.0354	.0351	.0351
10	.0343	.0686	.0716	.0709	.0351	.0358	.0343
11	.0351	.0686	.0343	.0343	.0537	.0358	.0514
12	.0686	.0701	.0351	.0678	.0724	.0686	.0339
13	.0343	.0343	.0686	.0343	.0347	.0343	
14	.0343	.0351	.0343	.0335	.0351	.0343	
15	.0343	.0343	.0343	.0709	.0351	.0343	
16	.0343	.0339	.0514	.0514	.0532	.0701	
17	.0532	.0686	.0343	.0532	.0351	.0554	
18	.0716	.0716	.0554	.0514	.0351	.0554	
19	.0709	.0895	.0914	.0709	.0895	.0924	
20	.1086	.1086	.1097	.1086	.0895	.1109	
21	.0905	.0895	.0924	.1086	.0905	.0739	
22	.0701	.0716	.0914	.0686	.0716	.0739	
23	.0532	.0537	.0739	.0526	.0537	.0732	
24	.0549	.0343	.0351	.0554	.0335	.0351	.0554
Max	.1086	.1086	.1097	.1086	.0905	.1109	.0739
Min	.0343	.0335	.0343	.0335	.0332	.0343	.0339
Avg	.0575	.0541	.0559	.0620	.0491	.0546	.0516

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 208 / 11 KV SHIRALA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7095	.724	.7392	1.6111	1.5928	1.432	1.5322
2	.6722	.695	.695	1.5733	1.5211	1.3314	1.4674
3	.6722	.7023	.7023	1.5509	1.499	1.3108	1.4484
4	.7095	.695	.7023	1.5162	1.4838	1.2986	1.4485
5	.7468	.695	.7392	1.6099	1.5166	1.4594	1.5173
6	.8029	.7392	.8131	1.7307	1.6309	1.6339	1.6461
7	.8131	.961	.7392	1.9448	1.7886	1.7848	1.7963
8	.7468	.7316	.7392	1.6674	1.6354	1.5173	1.6682
9	.6908	.6653	.6722	1.4937	1.4433	1.294	1.3733
10	.6653	.6653	.7392	1.5401	1.4975	1.3878	1.2818
11	.6653		.8131	1.6926	1.576	1.5295	1.3222
12	.6653	.7392	.8131	1.8054	1.5645	1.6072	1.4259
13	.7316	.8131	.8131	1.7063	1.576	1.6591	.7392
14	.7392	.7316	.7392	1.6887	1.4563	1.6881	.7461
15	.7468	.8871	.8048	1.7055	1.422	1.8137	.7567
16		.8131	.8131	1.5844	1.4518	1.7383	.6927
17	.9511	.8131	.8131	1.6773	1.5112	1.6998	.6607
18	.961	.8131	.8962	1.5958	1.4693	1.6666	.6722
19	1.0456	.8962	1.0456	1.7559	1.8214	1.8422	.7438
20	1.1088	1.1203	1.1949	2.1117	2.0028	2.0473	.9998
21	1.0456	.961	1.0456	1.9951	1.8999	1.938	1.0463
22	1.0349	.9709	1.0082	1.8564	1.7512	1.9173	.9816
23	.8048	.8131	.8589	1.8763	1.6057	1.8846	.8924
24	.7468	.7316	.7392	1.7022	1.6323	1.5493	1.6118
Max	1.1088	1.1203	1.1949	2.1117	2.0028	2.0473	1.7963
Min	.6653	.6653	.6722	1.4937	1.422	1.294	.6607
Avg	.8033	.7990	.8200	1.7080	1.5979	1.6263	1.1863

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 209 / 11 KV KAPARI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2587	.2149	.2195	.4436	.5529	.5682	.5454
2	.2587	.2172	.2195	.4401	.5212	.5335	.5316
3	.2587	.2126	.2195	.4261	.514	.5297	.5427
4	.2587	.2507	.2195	.5285	.5075	.5171	.5452
5	.2957	.2507	.2561	.543	.5582	.5457	.5887
6	.2957	.2926	.3326	.5933	.5567	.6264	.6503
7	.3142	.2534	.2957	.5639	.6371	.6504	.6585
8	.2587	.2172	.2561	.5226	.5514	.6013	.6297
9	.2402	.2218	.2587	.5552	.567	.4858	.5647
10	.2587	.2195	.4066	.8189	.735	.503	.6161
11	.2587		.4066	.9072	.8741	.6386	.5452
12	.2561	.2218	.4435	.7594	.8482	.5891	.4893
13		.2218	.2926	.8337	.8047	.5407	.3018
14	.1478	.2614	.2587	.8554	.6683	.5632	.2911
15	.3292	.2587	.2957	.8825	.9583	.5559	.2869
16	.3326	.2987	.4024	.8246	.7	.6336	.2884
17	.3582	.2561	.2957	.6752	.5704	.5304	.2637
18	.2534	.2195	.1663	.5319	.5701	.4721	.2599
19	.2896	.2587	.2402	.6844	.5579	.5664	.3079
20	.3658	.3734	.4066	.7354	.6988	.7139	.3532
21	.362	.3326	.2957	.6801	.6253	.7666	.3666
22	.3224	.2926	.1848	.7137	.6729	.7601	.3688
23	.2896	.2561	.2218	.5754	.6595	.6893	.3822
24	.2772	.2507	.2561	.5095	.5777	.5724	.5617
Max	.3658	.3734	.4435	.9072	.9583	.7666	.6585
Min	.1478	.2126	.1663	.4261	.5075	.4721	.2599
Avg	.2844	.2545	.2854	.6502	.6453	.5897	.4558

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 401 / 33 KV GLUCOSE EXPRESS

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9156	.6802	.6167	.7956	.7773	.6882	.6539
2		.7459	.583	.8048	.7287	.6316	.5967
3	.503	.6882	.5693	.7459	.6722	.6316	.6036
4	.763	.6036	.5281	.7956	.8139	.583	.639
5	.5533	.6962	.6241	.7956	.6882	.583	.6464
6	.5967	.639	.7773	.8048	.6722	.639	.8453
7	.6464	.7773	.8551	.9054	.763	.639	.7459
8	.7956	.7865	.7373	.8453	.7122	.639	.8551
9	.8453	.9259	.8745	.8951	.7865	.6882	.8551
10	.7716	.8848	.823	.7865	.7373	.7202	.7287
11	.7956	.8848	.7373	.7459	.7373	.7373	.7773
12	.7865	.8453	.6882	.6882	.7373	.7865	.8162
13	.6687	.8453	.6722	.8139	.7459	.7373	
14	.7865	.7459	.639	.763	.6962	.7373	
15	.7373	.6882	.6241	.8951	.6962	.7373	
16	.6316	.6882	.7865	.6882	.639	.7287	
17	.7202	.639	.3441	.6722	.7459	.7545	
18	.7682	.7865	.7042	.8139	.6316		
19	.7459	.8356	.6036	.6882	.6167	.6962	
20	.7287	.7373	.5967	.5596	.6722	.6464	
21	.7373	.6802	.7459	.6539	.7373	.6962	
22	.7865	.7773	.6962	.7202	.7459	.7042	
23	.8259	.7287	.8453	.7287	.7459	.7956	
24	.7459	.7287	.6241	.7956	.8356	.6882	.6539
Max	.9156	.9259	.8745	.9054	.8356	.7956	.8551
Min	.503	.6036	.3441	.5596	.6167	.583	.5967
Avg	.7328	.7516	.6790	.7667	.7223	.6908	.7244

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 201 / 11 KV CHARAN AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0857	.1372	.0686		
2			.0857	.1372	.0686		
3			.0857	.12	.0686		
4			.0857	.12	.0686		
5			.1029	.12	.0686		
6			.1372	.1372	.1029		
7			.1715	.1543	.1029		
9	.3601	.3772				.3429	.3601
10	.3601	.3772				.4115	.3601
11	.3772	.3944				.3772	
12	.3429	.3429				.3429	
13	.3429	.2915				.3601	
14	.2401	.2915				.2743	
15		.2915				.3429	
16	.2401	.2572				.3086	
22		.1886	.1372	.12			
23		.1029	.1543	.1029		.0171	
24			.1029		.1029		
Max	.3772	.3944	.1715	.1543	.1029	.4115	.3601
Min	.2401	.1029	.0857	.1029	.0686	.0171	.3601
Avg	.3233	.2915	.1149	.1276	.0815	.3086	.3601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 202 / 11 KV MANDOOR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.2915	.3086	.3086	.3429	.3429	.3429
2	.3086	.2915	.2915	.2915	.3086	.3086	.3258
3	.2915	.2915	.2915	.2915	.3086	.3086	.2915
4	.2915	.2915	.2915	.2915	.3086	.3086	.2915
5	.3086	.2915	.3086	.2915	.3086	.3429	.2915
6	.3258	.4115	.3772	.3772	.4115	.463	.3086
7	.4458	.4801	.4973	.4801	.5144	.5658	.4973
8	.4801	.4287	.4973	.5487	.5144	.5658	.5487
9	.4458	.4458	.463	.4801	.4801	.5487	.4973
10	.4458	.4801	.4973	.4801	.4801	.4801	.3944
11	.4458	.5144	.4287	.3201	.4801	.4458	.4801
12	.5144	.5487	.4458	.5144	.3944	.4115	.4115
13	.4801	.4973	.3086	.4458	.4287	.4115	.3772
14	.4458	.4801	.4115	.4458	.4115	.3944	
15	.4458	.4973	.4115		.4458	.4287	
16	.4801	.5658	.4801	.5144	.4458	.3944	
17	.5487	.4801	.3772	.5487	.4973	.4287	
18	.583	.6001	.4801	.5487	.6173	.5658	
19	.6859	.703	.583	.6516	.7202	.6516	
20	.7888	.7202	.6859	.6859	.7716	.7202	
21	.6173	.6001	.6344	.6173	.6859	.6344	
22	.5487	.5316	.5487	.5144	.5316	.3772	
23	.3772	.4115	.4801	.4458	.4115	.4115	
24	.3772	.3086	.3429		.3772	.3601	.3429
Max	.7888	.7202	.6859	.6859	.7716	.7202	.5487
Min	.2915	.2915	.2915	.2915	.3086	.3086	.2915
Avg	.4580	.4651	.4351	.4588	.4665	.4530	.3858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 203 / 11 KV CHARAN GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2572	.2743	.2743	.2743	.2743	.2915
2	.2572	.2572	.2572	.2572	.2743	.2743	.2743
3	.2401	.2572	.2572	.2572	.2743	.2743	.2743
4	.2401	.2572	.2572	.2572	.2743	.2743	.2743
5	.2572	.2572	.2743	.2572	.2743	.3086	.2915
6	.3429	.3772	.3601	.463	.3429	.3601	.3086
7	.4801	.5144	.4973	.463	.4458	.4801	.4287
8	.4115	.4458	.4287	.463	.4458	.4973	.4801
9	.4115	.4115	.3772	.3772	.4115	.3944	.3944
10	.3429	.4287	.3772	.4115	.3429	.4115	.3772
11	.4115	.3944	.3944	.3772	.4115	.3772	.3944
12	.4458	.463	.4115	.4115	.3772	.3772	.4115
13		.4801	.4287	.4115	.3429	.3772	.3944
14	.4458	.4287	.4115	.4115	.3772	.3601	
15	.0412	.4287	.3772	.3429	.3429	.3429	
16	.3772	.3429	.3601	.4115	.3086	.3086	
17	.3772	.3258	.3086	.4458	.3601	.3429	
18	.4973	.3772	.4115	.4115	.3772	.3772	
19	.5658	.5487	.583	.5487	.5144	.5316	
20	.6344	.6173	.6516	.583	.583	.6344	
21	.5487	.5487	.5487	.4801	.5316	.5487	
22	.5144	.4801	.5487	.4458	.4801	.4973	
23	.4115	.3944	.4115	.3429	.3944	.3772	
24	.3086	.3086	.3086		.3086	.3258	.3086
Max	.6344	.6173	.6516	.583	.583	.6344	.4801
Min	.0412	.2572	.2572	.2572	.2743	.2743	.2743
Avg	.3835	.4001	.3965	.3959	.3779	.3886	.3503

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 204 / 11 KV MANDOOR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0171	.8573	.7545	.7545	.0171	.0171
2		.0171	.7888	.7202	.6859		.0171
3		.0171	.7888	.7202	.6859	.0171	.0171
4		.0171	.7888	.6859	.6859	.0171	.0171
5		.0171	.7888	.6687	.6516	.0171	.0171
6		.0171	.7888	.6687	.6516	.0171	.0171
7		.0171	.8402	.6859	1.2003	.0171	.0171
8		.0171		.0171		.0171	.0171
9	1.3889	1.3032		.0171		1.3717	1.3375
10	1.3889	1.4918	.0171	.0171		1.3717	1.286
11	1.4403	1.3546		.0171		1.4403	1.0288
12	1.3717		.0171	.0171		1.406	
13	1.3375	1.2517	.0171	.0171		1.4232	
14	1.3032	1.3717	.0171	.0171		.3772	
15		1.3889	.0171	.0171	.0171	.3772	
16	1.3032	1.2003	.0171	.0171	.0171	.9088	
17	.0171			.0171	.0171	.0171	
18	.0171		.0171	.0171	.0171	.0171	
19	.0171			.0171	.0171	.0171	
20	.0171		.0171	.0171	.0171	.0171	
21	.0171			.0171	.0171	.0171	
22	.0171	1.0974	.8402	.8916	.0171	.0171	
23	.0171	.9259	.8573	.823	.0171	.0171	
24		.0171	.9259	.5487	.7888	.0171	.0171
Max	1.4403	1.4918	.9259	.8916	1.2003	1.4403	1.3375
Min	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Avg	.6895	.6411	.4668	.3086	.3681	.3884	.3172

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 401 / 33 KV WARNAWATI

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 33 / OUTGOING

UTILITY

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0617	.072	.0823	.0617	.072	.0617	.0772
2	.0566	.072	.0823	.0669	.072	.0514	.072
3	.0566	.072	.0823	.0617	.072	.0566	.072
4	.0566	.0072	.0823	.0617	.072	.0669	.0669
5	.0566	.072	.0823	.0617	.0874	.0617	.0617
6	.0617	.0617	.0823	.0669	.0772	.0669	.0617
7	.0772	.0772	.0926	.072	.0617	.0823	.072
8	.072	.0669	.0823	.0772	.0566	.0617	.0412
9	.0617	.072	.0874	.072		.072	.0566
10	.0617	.0669	.0669	.0669	.0617	.0617	
11	.0669	.0669	.0617	.0669	.0514	.0669	
12	.0617	.0617	.0617	.072	.0514	.0566	.0514
13	.0514	.0566	.0617	.0669	.0514	.0669	.0514
14	.0669	.0617	.0617	.0669	.0514	.0617	
15	.0566	.0566	.0566	.0669	.0514	.0669	
16	.0617	.0617	.0514	.0617	.0514	.0617	
17	.0514	.0514	.0463	.0617	.0514	.0514	
18	.0566	.0514	.0514	.0617	.0514		
19	.072	.0566	.0617	.0669	.108	.0669	
20	.072	.0669	.072	.0772	.0772	.0772	
21	.072	.0823	.0772	.0977	.072	.072	
22	.072	.0823	.072	.072	.0669	.0823	
23	.072	.0823	.072	.072	.0669	.0772	
24	.0617	.072	.0823	.0669	.072	.0617	.072
Max	.0772	.0823	.0926	.0977	.108	.0823	.0772
Min	.0514	.0072	.0463	.0617	.0514	.0514	.0412
Avg	.0632	.0646	.0714	.0686	.0655	.0658	.0630

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11 KV CHIKHALI S/S

Feeder No / Name : 201 / 11 KV KANDE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0366	.0229	1.2403	1.3279	1.4022	.0362	.0362
2	.0366	.0244	.1867	1.3272	1.326	.0362	.0362
3	.0366	.021	1.2269	1.2654	1.3413	.0362	.0362
4	.0362	.0324	1.2269	1.2803	1.2193	.0343	.0358
5	.0362	.0309	1.4022	1.3117	1.2498	.0343	.0358
6	.0366	.0232	1.5947	1.4582	1.3413	.0343	.0358
7	.0366	.0335	1.4586	1.6409	1.531	.0343	.0351
8	.0343	.0339	.0362	.0351	.0267	.0343	.0362
9	.0366	.0362	.0286	.0362	.0267	.0328	.0324
10	.0362	.0362	.0267	.0358	.0267	.0366	.0366
11	.0362	.0362	.0366	.0354	.0343	.0362	
12	2.1051	1.9989	.0366	.0362	.0343	2.1051	
13	2.0729	2.1628	.0328	.0362	.0343	2.0485	
14	1.9784	2.0645	.0362	.0362	.0343	2.0567	
15		2.0317	.0362	.0362	.0343	1.7924	
16	1.9498	2.0972	.0358	.0351	.0343		
17	1.9826	2.0645	.0362	.0362	.0343	1.8564	
18	2.0317	1.9989	.0354	.0362	.0343	1.989	
19	1.7859	1.757	.0362	.0358	.0343	1.8896	
20	.029	.0362	.0362	.0358	.0343	.0354	
21	.0305	.0328	.0358	.0362	.0343	.0354	
22	.0316	1.4255	1.8298	1.5249	.0343	.0362	
23	.0221	1.326	1.5565	1.6289	.0366	.0362	
24	.037	.0248	1.2407	1.491	1.4685	.0362	.0362
Max	2.1051	2.1628	1.8298	1.6409	1.531	2.1051	.0366
Min	.0221	.021	.0267	.0351	.0267	.0328	.0324
Avg	.6285	.8063	.5604	.6150	.4753	.6219	.0357

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11 KV CHIKHALI S/S

Feeder No / Name : 202 / 11 KV SAGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0267	.021	.9393	.9374	.9717	.0267	.0259
2	.0267	.021	.9393	.9217	.8745	.0267	.0244
3	.0267	.0221	.9393	.9374	.8745	.0267	.0236
4	.0267	.0267		.9686	.8745	.0267	.0229
5	.0267	.0255	.9717	.9877	.8745	.0267	.0202
6	.0267	.0229	1.1336	1.1702	1.086	.0267	.024
7	.0267	.0191	1.1012	1.0595	1.0688	.0267	.0267
8	.0267	.0187	.0305	.0259	.0305	.0267	.0194
9	1.7204	1.749	.0206		.0267	1.8785	2.0317
10	1.7859	1.9433	.021	.0305	.0267	1.8023	1.9498
11	1.6385	1.8461	.0271	.0305	.0267	1.6385	
12	1.5524	1.6518	.1257	.0305	.0267	1.4403	
13	1.4327	1.6057	.032	.0305	.0267	1.5203	
14	1.2955	1.5546	.0301	.0305	.0267	1.5729	
15		1.5364	.0335	.0305	.0267	1.5684	
16	1.3441	1.3927	.0267	.0305	.0267	1.5844	
17	.0141	.0305	.029	.0305	.0267	.0164	
18	.016	.0305	.0179	.0305	.0267	.0175	
19	.0168	.0305	.0206	.0305	.0267	.0255	
20	.0206	.0305	.0225	.0305	.0267		
21	.0221	.0305	.0217	.0305	.0267	.0236	
22	.0286	1.1984	1.2643	1.3279	.0267	.0259	
23	.024	1.1336	1.2643	1.2955	.0267	.0274	
24	.0229	.0259	.9602	1.0623	1.4022	.0229	.0267
Max	1.7859	1.9433	1.2643	1.3279	1.4022	1.8785	2.0317
Min	.0141	.0187	.0179	.0259	.0267	.0164	.0194
Avg	.4847	.6653	.4336	.4809	.3524	.5817	.3814

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11 KV CHIKHALI S/S

Feeder No / Name : 204 / 11 KV KANDE GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.1867	.1886	.1848	.1886	.2263
2	.1886	.1886	.181	.1886	.1829	.1886	.2263
3	.1867	.1886	.1867	.1886	.1848	.1886	.2263
4	.1886	.1886	.1867	.1886	.1848	.1867	.2263
5	.1886	.1886	.2241	.1886	.1848	.1867	.2263
6	.2452	.2263	.2241	.2263	.2218	.2241	.2641
7	.2427	.2218	.2772	.2561	.2218	.2614	.2587
8	.2195	.1829	.2587	.181	.2218	.2353	.2195
9	.181	.1848	.1829	.2195	.2058	.197	.181
10	.1448	.2195	.1791	.2195	.2058	.1991	.1791
11	.1772	.1848	.181	.2218	.181	.2012	
12	.1715	.1848	.1791	.2195	.2058	.181	
13	.1417	.1829	.1791	.2195	.1886	.1753	
14	.1448	.1829	.1433	.2218	.1715	.1372	
15	.1772	.1829	.1433	.2241	.1715	.1715	
16	.1829	.2195	.1715	.2172	.1715	.1715	
17	.1715	.2195	.1402	.2195	.1543	.1372	
18	.2035	.2587	.2058	.2195	.1715	.1753	
19	.2481	.2715	.2172	.2561	.2561	.2195	
20	.2561	.2957	.2957	.2743	.2896	.2587	
21	.2195	.2957	.2614	.2587	.2534	.2587	
22	.2241	.2587	.2614	.2218	.2614	.2614	
23	.1886	.2218	.1886	.2033	.2263	.2614	
24	.1886	.1886	.1867	.1886	.1848	.2263	.2263
Max	.2561	.2957	.2957	.2743	.2896	.2614	.2641
Min	.1417	.1829	.1402	.181	.1543	.1372	.1791
Avg	.1946	.2136	.2017	.2171	.2036	.2038	.2237

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11 KV CHIKHALI S/S

Feeder No / Name : 205 / 11 KV SAGAON GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.1097	.1063	.1097	.1052	.0905	.1086
2	.0924	.1097	.1052	.1097	.1052	.0905	.1109
3	.0914	.1109	.1052	.1097	.1052	.0905	.1109
4	.0934	.1097	.9393	.1097	.1052	.0905	.1109
5	.0934	.1109	.1052	.1086	.1052	.0905	.1086
6	.1478	.1109	.1227	.1097	.1227	.1029	.1086
7	.1448	.1029	.1753	.1372	.1227	.1372	.1387
8	.1372	.1006	.1402	.1029	.1227	.1372	.1006
9	.1562	.1402	.1029	.1052	.1219	.1467	.0972
10	.1543	.1227	.0995	.1052	.1296	.1524	.096
11	.1341	.124	.096	.1052	.1619	.141	
12	.1235	.1174	.0983	.1052	.1524	.1638	
13	.1219	.1147	.1017	.1063	.1372	.1562	
14	.1017	.1402	.1387	.1063	.1219	.096	
15	.0983	.1387	.0983	.1063	.1219	.1562	
16	.1158	.1715	.0914	.1753	.1219	.0937	
17	.088	.1753	.1235	.1791	.1372	.1738	
18	.16	.1802	.1562	.1753	.1677	.1898	
19	.2458	.2149	.1715	.1753	.2058	.1357	
20	.2103	.2534	.2103	.2126	.2229	.208	
21	.1791	.2103	.181	.1949	.2058	.1402	
22	.1478	.1753	.1463	.1753	.1753	.1097	
23	.1097	.1402	.1109	.1417	.1448	.1109	
24	.0924	.1097	.1052	.1097	.1086	.1109	.1109
Max	.2458	.2534	.9393	.2126	.2229	.208	.1387
Min	.088	.1006	.0914	.1029	.1052	.0905	.096
Avg	.1305	.1414	.1596	.1323	.1388	.1298	.1093

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11 KV CHIKHALI S/S

Feeder No / Name : 401 / 33 KV JYOTIRLING LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.547	.5144	.5533	.5144	.5144
2	.5658	.547	.5144	.5533	.5144	.5658
3	.5658	.5533	.5658	.5533	.5144	.5658
4	.5658	.5533	.5144	.5533	.5144	.5658
5	.5658	.5533	.5144	.5533	.5658	.5658
6	.5658	.5533	.5658	.5596	.5658	.5658
7	.5658	.5533	.5144	.5596	.5658	.5658
8	.5658	.5407	.5144	.5344	.5658	.5658
9	.5658	.5658		.5658	.5658	.5533
10	.5658	.5658	.2486	.5658	.5658	.5658
11	.5658	.5658	.5596	.5658	.5658	.5658
12	.5658	.5658	.5596	.5658	.5658	.5658
13	.5533	.5658	.547	.5658	.5658	.5658
14	.5533	.5658	.5533	.5658	.5658	.5658
15	.547	.5658	.5533	.5658	.5658	.5533
16	.5596	.5658	.5533	.5658	.5658	.4212
Max	.5658	.5658	.5658	.5658	.5658	.5658
Min	.5144	.5407	.2486	.5344	.5144	.4212
Avg	.5595	.5580	.5195	.5592	.5530	.5520

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 201 / 11 KV WAKURDE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.2211	3.996	.0934	.1425	.1904	3.3387	3.1569
2	4.192	3.8287	.0934	.141	.1904	3.2697	3.0624
3	3.9979	3.7466	.0934	.1456	.1926	3.1943	2.9264
4	3.9195	3.7268	.08	.1463	.1926	3.1036	2.7617
5	3.9278	3.7687	.08	.1486	.2077	3.0038	2.7542
6	3.8699	3.9243	.1067	.1486	.2092	2.8917	2.9509
7	2.6521	3.9945	.1067	.1593	.2275	2.6372	2.4825
8	.1519	.2088	.08	.1623	.3129	.1387	.1819
9	.2363	.2118	2.5377	4.6228	3.9038	.0907	.1082
10	.223	.2271	2.6749	4.5847	3.8557	.1433	.1486
11	.2164	.1974	2.7092	4.7013	3.7998	.1425	.1493
12		.0793		4.6718	3.2282	.1143	.1113
13			2.2721	4.3698	3.3478	.1356	.1075
14	.003		2.2891	4.1204	3.4058	.1425	.1128
15	.0846		2.4587	4.1838	3.4758	.141	.112
16	.1951	.2225	2.1026	3.7822	3.5856	.1403	.1067
17	.1806	.2354	.0469		.1654	.1448	.1204
18	.2629	.2568	.0469	.1443	.1673	.1958	.1273
19	.2698	.2675	.0606	.1766	.205	.2092	.1395
20	.3105	.2766	.0511	.2201	.2523	.2469	.141
21	.2772	.269	.0511	.2285	.253	.2722	.2439
22	3.8554	.242	.0743	.2382	3.6329	3.3988	1.6644
23	4.3231	.2294	.0743	.198	3.6405	3.4354	1.8961
24	4.2781	2.0586	.0934	.1501	1.9729	3.4179	3.3196
Max	4.3231	3.996	2.7092	4.7013	3.9038	3.4354	3.3196
Min	.003	.0793	.0469	.141	.1654	.0907	.1067
Avg	1.8931	1.5223	.7946	1.6342	1.6923	1.4145	1.2036

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 202 / 11 KV TAKAVE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1075	.1052	.3201	.5144	.5335	.0857	.0848
2	.0895	.104	.3201	.5144	.5401	.0857	.0819
3	.0876	.104	.3658	.5144	.5401	.0686	.0819
4	.0876	.1063	.3201	.535	.5468	.0686	.08
5	.1063	.1075	.3963	.6241	.6405	.0686	.08
6	.1075	.1097	.5335	.6241	.7253	.0829	.0857
7	.116	.128	.7164	.8124	.8436	.1006	.0838
8	.12	.1715	.1029	.0949	.1174	.1029	.1296
9	1.1488	1.1961	.1227	.0701	.1029		
10	.9145	1.1271	.104	.1075	.1029	2.1026	1.7436
11	.8078	.9717	.1029	.1254	.1029	2.1026	1.7436
12	.7011		.0791	.1214	.0857	1.9227	
13		.7316	.0972	.1134	.0857	1.9227	
14	.5487	.7621	.0937		.0762	1.7078	
15		.743	.0937		.0914	1.7695	
16	.5639	.5201	.08	.1134	.0762	1.7901	
17	.1526	.12	.1341	.1619	.0914	.1326	
18	.1387	.1372	.1341	.1492	.1067	.1147	
19	.1448	.1372	.12	.156	.12	.1433	
20	.1433	.12	.1448	.1402	.12	.1254	
21	.1448	.12	.1448	.1417	.12	.1214	
22	.128	.5316	.7316	.8223	.1029	.12	
23	.1267	.4115	.7316	.6249	.0857	.1086	
24	.1075	.1052	.3201	.5487	.5335	.0857	.0857
Max	1.1488	1.1961	.7316	.8223	.8436	2.1026	1.7436
Min	.0876	.104	.0791	.0701	.0762	.0686	.08
Avg	.2997	.3770	.2629	.3468	.2705	.6493	.3891

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 203 / 11 KV PADALI AG.

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4973	.8726	.0305	.0259	.0305	.7106	.8916
2	.4759	.8649	.0305	.0259	.0305	.6931	.8726
3	.4431	.8261	.0305	.0274	.0305	.6802	.8219
4	.4416	.8036	.0305	.0274	.0305	.7129	.7876
5	.4355	.7918	.0305	.0278	.0305	.7488	.7899
6	.4625	.8667	.0305	.0324	.0305	.8145	.8581
7	.6798	1.0419	.0267	.1372	.048	.949	1.0966
8	.0625	.1044	.0267	.1342	.0404	.0995	.1364
9	.0267	.0732	.6154	1.2711	1.0597		.0084
10	.0267	.0335	.6316	1.3163	1.0257	.0206	.0332
11	.0275	.0305	.6554	1.294	.9987	.0206	.0339
12			.5243	1.1545	.9576	.0213	
13			.5407	1.053	.9495	.0213	
14			.5218	1.0147	.9896	.0233	
15			.5506	1.0121	.9656	.0225	
16	.0267	.1318	.5761	.9854	1.0448	.0213	
17	.0526	.1212	.0442	.077	.1006	.0221	.0366
18	.0907	.1066	.0442	.0305	.0686	.09	.0854
19	.1127	.0663	.0533	.0709	.0305	.1531	.0914
20	.032	.0427	.0587	.0419	.0305	.1116	.0922
21	.0305	.0701	.0587	.0305	.0267	.0358	
22	.9572	.0267	.0271	.0305	.889	1.0061	.5655
23	1.0029	.0351	.0271	.0305	.8463	1.059	.5967
24	.7443	.4111	.0267	.0259	.4824	.8646	.9598
Max	1.0029	1.0419	.6554	1.3163	1.0597	1.059	1.0966
Min	.0267	.0267	.0267	.0259	.0267	.0206	.0084
Avg	.3314	.3660	.2163	.4115	.4474	.3870	.4865

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 204 / 11 KV PADALI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1646	.1791	.1715	.181	.1829	.1715	.1791
2	.1629	.1791	.1715	.181	.1829	.1715	.181
3	.1629	.1791	.1715	.0274	.1646	.1715	.181
4	.1629	.181	.1715	.181	.1629	.1715	.1791
5	.1829	.181	.1715	.181	.181	.1886	.1772
6	.197	.2172	.2229	.2353	.2172	.2328	.2303
7	.2126	.2303	.2229	.2374	.1886	.2279	.2279
8	.1844	.1844	.2058	.2374	.2012	.1509	.218
9	.1715	.1677	.1989	.1865	.1886		
10	.1372	.1341	.1492	.1492	.1715	.0903	.125
11	.0857	.1526	.1526	.1372	.1715	.0903	.125
12	.0857	.1492	.1526	.1214	.1543	.0995	
13	.0857	.1341	.1543	.1174	.1543	.0995	
14	.1029	.1526	.1387	.1326	.1543	.1357	
15	.1029	.1311	.1387	.1357	.1543	.1357	
16	.1029	.1326	.1372	.0972	.1372	.1147	
17	.1526	.12	.1865	.0772	.1543	.1147	
18	.1739	.1543	.1865	.0926	.1829	.1718	
19	.2347	.2229	.2035	.2058	.2134	.2254	
20	.2835	.2572	.2743	.181	.2134	.2507	
21	.2534	.2229	.2743	.0114	.2229	.2534	
22	.2378	.2058	.2561	.2012	.1886	.2561	
23	.2012	.1886	.1829	.1848	.1715	.2172	
24	.1646	.181	.1715	.181	.1829	.1715	.1991
Max	.2835	.2572	.2743	.2374	.2229	.2561	.2303
Min	.0857	.12	.1372	.0114	.1372	.0903	.125
Avg	.1669	.1766	.1861	.1531	.1791	.1701	.1839

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 205 / 11 KV WAKURDE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.2353	.2229	.2279	***	.1886	.2012
2	.197	.2149	.2229	.2279	.1663	.1886	.1991
3	.197	.2149	.2229	.2279	.168	.1886	.181
4	.1791	.2149	.2229	.2279	.168	.1886	.1772
5	.197	.2149	.2229	.2534	.1663	.1886	.1772
6	.2402	.2561	.2401	.2534	.1848	.2715	.2172
7	.2534	.2896	.2401	.2454	.2254	.2686	.2303
8	.2401	.2713	.2572	.2454	.218	.2507	.2543
9	.2229	.2543	.2347	.2374	.2229		
10	.2401	.2401	.2321	.2347	.2229	.208	.192
11	.2401	.2155	.2058	.2204	.2058	.208	.192
12	.2229	.2486	.2515	.2321	.1829	.2374	
13		.2294	.2622	.2214	.2058	.2374	
14	.2572	.2515	.2591	.2107	.1981	.1875	
15	.2401	.2429	.2458	.2241	.2134	.1875	
16	.2134	.2343	.2622	.2187	.2401	.2054	
17	.2561	.2286	.3005	.2315	.2572	.2054	
18	.2785	.3086	.3005	.2343	.2915	.2932	
19	.2947	.3772	.3506	.3222	.3429	.3391	
20	.4656	.4115	.362	.362	.3944	.394	
21	.4572	.3772	.362	.3475	.3429	.4075	
22	.3881	.3086	.3475	.2987	.2915	.2957	
23	.2896	.2572	.2743	.2241	.2401	.2402	
24	.2195	.2507	.2229	.2279	.1848	.2058	.2012
Max	.4656	.4115	.362	.362	17.2853	.4075	.2543
Min	.1791	.2149	.2058	.2107	.1663	.1875	.1772
Avg	.2613	.2645	.2636	.2482	.9425	.2429	.2021

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 206 / 11 KV TAKAVE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3749	.3504	.1543	.3421	.358	.3326	.3498
2	.3639	.3413	.1543	.3322	.3489	.3265	.3406
3	.3624	.3341	.1543	.3315	.3232	.322	.3367
4	.3593	.3372	.1543	.3383	.3224	.3174	.3336
5	.3774	.3413	.1543	.679	.3692	.3242	.3306
6	.4893	.4694	.2743	.2972	.501	.4668	.4542
7	.5706	.5786	.2572	.3963	.5843	.5076	.6059
8	.503	.5426	.2058	.3658	.5247	.4435	.5951
9	.495	.4557	.2195	.3311	.4889	.2401	.2698
10	.4149	.4273	.1829	.2904	.4718	.4511	.4256
11	.4085	.4361	.1802	.4012	.4443	.4351	.386
12	.4093	.389	.1886	.3852	.4527	.3986	.2401
13	.1905	.394	.1478	.4443	.4413	.3849	.1936
14	.4626	.3951	.2149	.0572	.4104	.3399	.173
15	.3895	.064	.1928		.378	.3201	.2134
16	.3303	.4039	.1448		.4268	.3742	.192
17	.3364	.4283	.2204	.506	.4291	.3971	.234
18	.3765	.4367	.2204	.4428	.458	.4275	.2667
19	.4858	.5692	.2865	.3963	.5212	.5723	.2782
20	.7426	.7392	.3292	.7819	.6028	.7469	.4009
21	.5651	.6889	.3292	.738	.5959	.7053	.378
22	.6447	.6073	.2587	.6668	.5495	.6108	.3346
23	.4719	.4515	.2218	.4765	.4355	.4752	.2622
24	.381	.3641	.1543	.3498	.3852	.3524	.3605
Max	.7426	.7392	.3292	.7819	.6028	.7469	.6059
Min	.1905	.064	.1448	.0572	.3224	.2401	.173
Avg	.4377	.4394	.2084	.4250	.4510	.4280	.3315

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 201 / 11 KV MANGLE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5807	.5578	.1715	1.3108	1.2986	.5698	.5636
2	.5228	.5125	.1433	1.2346	1.2354	.5476	.5151
3	.5205	.5079	.1387	1.211	1.2148	.5388	.5136
4	.5449	.5572	.1677	1.2094	1.2383	.5662	.5083
5	.5769	.6072	.2204	1.2674	1.251	.6025	.5563
6	.6371	.644	.2401	1.4015	1.374	.665	.6554
7	.807	.696	.2629	1.4658	1.4529	.7257	.6553
8	.7743	.6645	.2743	.8702	.8909	.6756	.6142
9	1.5966	1.8034	.2572	.5443	.6073	1.7042	1.7307
10	1.6933	1.732	.2629	.5617	.5879	1.8122	1.7696
11	1.6562	1.7288	.3189	.6188	.6024	1.776	1.7587
12	1.7237	1.6922	.3658	.6335	.6032	1.8028	1.7482
13	1.403	.6142	.3734	.612	.5984	1.7726	.2789
14	.699	.5826	.3961	.5845	.6108	1.7345	.2881
15	1.4826	.5744	.3734	.5945	.6455	1.749	.2835
16	1.4477	1.5828	.3582	.6398	.6924	1.7478	.9236
17	.9808	.9899	.3681	.7202	.642	.9495	.442
18	.8048	.8028	.3898	.74	.6714	.7674	.3574
19	.8471	.8954	.4557	.8855	.817	.8589	.4245
20	.948	1.0417	.4557	.9838	.9614	.9876	.5037
21	.9762	1.073	.4557	.9298	.8853	.8836	.4877
22	.9071	1.6949	.3856	1.5546	.7821	.7964	.7903
23	.8076	1.6217	.3155	1.5394	.7215	.7293	.6995
24	.6706	1.5578	.1734	1.3481	.6508	.5681	.5967
Max	1.7237	1.8034	.4557	1.5546	1.4529	1.8122	1.7696
Min	.5205	.5079	.1387	.5443	.5879	.5388	.2789
Avg	.9837	1.0306	.3052	.9776	.8765	1.0638	.7360

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 202 / 11 KV DE VWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.439	.4298	1.1317	1.3306	1.3535	.4024	.4435
2	.439	.4344	1.1568	1.2936	1.3306	.4115	.4435
3	.439	.4252	1.1096	1.2936	1.2936	.4207	.4435
4	.439	.4161	1.0395	1.3676	1.2567	.4161	.4435
5	.439	.4207	1.0631	1.4045	1.2567	.4115	.439
6	.439	.4344	1.382	1.4415	1.3491	.4161	.439
7	.439	.4298	1.5604	1.4045	1.3306	.4252	.4435
8	.439	1.5939	.4075	.4435	.4481	.3887	.4251
9	2.1948	1.9006	.439	.4481	.4251	1.9559	2.0302
10	2.1132	2.1262	.4668	.4715	.4031	2.0111	2.0668
11	2.0332	2.0687	.4715	.4481	.3944	1.9204	2.1658
12	1.9204	2.0576	.4572	.4435	.4024	1.8378	
13	1.8482	1.6617	.4481	.4435	.3932	1.8073	
14		1.6118	.4252	.4338	.3841	1.7364	
15		1.4746	.439	.439	.3704	1.6118	
16	1.7269	1.4582	.4435	.4435	.3749	1.4419	
17	.3932	.4207	.4435	.4435	.3841	.4075	
18	.3841	.4115	.439	.4435	.3932	.439	
19	.3795	.4252	.439	.4435	.3841	.439	
20	.3887	.4161	.439	.4435	.3887	.439	
21	.3749	.4075	.439	.4435	.3795	.4207	
22	.3932	1.2934	1.4175	1.6461	.3932	.4207	.4435
23	.439	1.2003	1.4529	1.4632	.4024	.4435	.4481
24	.439	.4252	1.1401	1.3306	1.3535	.3887	.4435
Max	2.1948	2.1262	1.5604	1.6461	1.3535	2.0111	2.1658
Min	.3749	.4075	.4075	.4338	.3704	.3887	.4251
Avg	.8427	.9977	.7771	.8420	.7019	.8755	.7942

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 203 / 11 KV MANGLE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0846	.0707	.7291	1.451	1.3504	.0655	.1059
2	.0857	.0703	.6882	1.414	1.3111	.0651	.1061
3	.0857	.0709	.2427	1.3718	1.3245	.0663	.1061
4	.085	.0713	.6962	1.3638	1.3371	.0661	.1052
5	.0858	.0737	.7045	1.3954	1.3161	.0663	.1056
6	.0846	.0659	.7042	1.4358	1.4597	.0665	.1036
7	.0918	.0688	.78	1.5124	1.4781	.0657	.0926
8	1.0258	1.9136	.0164	.0621	.0785	1.0694	1.2281
9	2.2653	2.2219	.0168	.0754	.0842	2.3918	2.3826
10	2.2493	2.2386	.0171	.093	.0675	2.3166	2.4615
11	2.2908	2.2253	.0366	.0842	.0751	2.2927	2.2588
12	2.1921	.4477	.0537	.0839	.0741	2.162	.4934
13	2.1559		.0366	.074	.0735	2.108	
14	1.0261		.0373	.0777	.0642	2.0512	
15	.5403	.7251	.0373	.0667	.0636	2.0996	
16	1.8499	1.8515	.0324	.0712	.0661	2.1487	.9709
17	.0627	.0892	.0328	.1017	.0699	.088	.0545
18	.0634	.0865	.0324	.1151	.0699	.1211	.0671
19	.077	.0983	.0362	.1169	.0804	.1178	.0739
20	.0846	.0983	.0549	.0839	.0808	.0991	.0743
21	.0855	.8566	.0366	.7355	.0817	.096	.0728
22	.0865	1.8831	.5693	1.5775	.0743	.0979	.1256
23	.0774	1.7692	.6401	1.5135	.0667	.0937	.0861
24	.1073	.9743	.7377	1.4453	.682	.0659	.0792
Max	2.2908	2.2386	.78	1.5775	1.4781	2.3918	2.4615
Min	.0627	.0659	.0164	.0621	.0636	.0651	.0545
Avg	.7018	.8169	.2904	.6801	.4762	.8284	.5311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 204 / 11 KV CHIKHALWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.2533	3.6633	.1966	.583	.543	2.6711	2.4714
2	3.2404	3.4827	.2035	.5433	.5407	2.6147	2.2031
3	3.2145	3.5307	.2427	.5392	.5202	2.5491	2.0199
4	3.2892	3.6107	.285	.5385	.5301	2.6025	2.039
5	3.3143	3.7799	.3086	.5357	.5258	2.7046	2.255
6	3.5497	3.9788	.3391	.5476	.3124	2.8174	2.4333
7	3.2403	3.1687	.3647	.5441	.4679	2.3152	2.2059
8	.6417	.7751	.3391	2.6871	2.6197	.6516	.4268
9	.7392	.8185	1.8778	4.8747	4.7032	.7316	.5228
10	.676	.8566	2.1879	4.8194	4.5458	.679	.5209
11	.6637	.8444	2.17	4.8831	4.3751	.6554	.5285
12	.6298	.9336	2.2085	4.5481	4.1926	.6196	.5461
13	.522	.8897	2.0056	4.4986	4.0459	.6325	.2423
14	.3628	.8341	1.9784	4.4734	3.7662	.6173	.2743
15	.1364	.7841	1.9393	4.3347	3.6118	.6764	.3201
16	.6699	.682	1.9227	3.3398	2.8815	.6672	.2995
17	.7064	.6409	.3353	.6874	.5643	.6912	.2934
18	.7384	.7568	.3647	.7224	.6607	.7057	.3003
19	.7097	.7652	.2984	.6646	.7049	.7057	.2736
20	.6653	.7362	.2984	.6531	.5874	.6044	.2812
21	2.2916	.6767	.2984	.6074	1.797	2.0432	1.5364
22	3.9503	.668	.2622	.5921	3.1124	3.6107	3.1352
23	2.1323	.5982	.2622	.5655	2.9218	2.9736	2.8989
24	3.1566	2.0687	.2035	.5548	1.7281	2.8212	2.6094
Max	3.9503	3.9788	2.2085	4.8831	4.7032	3.6107	3.1352
Min	.1364	.5982	.1966	.5357	.3124	.6044	.2423
Avg	1.7706	1.6477	.8705	1.9724	2.0941	1.5984	1.2766

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 205 / 11 KV DEOWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.0732	.0924	.1143	.1132	.0716	.1132
2	.0943	.0543	.0732	.0953	.0943	.0543	.1132
3	.0943	.056	.0716	.0943	.0943	.0554	.112
4	.1132	.0739	.0905	.1132	.1132	.0732	.112
5	.132	.0934	.1109	.132	.132	.1052	.1307
6	.1886	.128	.1448	.1886	.168	.1417	.168
7	.1791	.1478	.1867	.1772	.156	.1791	.1698
8	.1402	.1075	.1417	.1402	.104	.1595	.1086
9	.1387	.1227	.1387	.1475	.1017	.1387	.1357
10	.12	.12	.116	.1134	.1029	.1448	.1341
11	.1052	.1052	.1341	.1174	.104	.124	.1017
12			.1357	.1029	.1029	.1052	.0663
13		.12	.1341	.104	.1017	.0857	
14		.1402	.12	.1063	.1227	.0829	
15	.104	.1214	.1214	.12	.104	.0983	
16	.124	.12	.1265	.128	.12	.1357	
17	.1629	.1595	.1581		.1829	.125	
18	.1848	.181	.176	.1406	.197	.1372	
19	.2012	.2402	.1949	.2058	.2126	.1886	
20	.2241	.1949	.2353	.2279	.181	.2126	
21	.1829	.1772	.2103	.1829	.168	.181	
22	.1509	.1478	.1867	.1663	.1478	.1494	.1494
23	.1132	.1132	.132	.1307	.1307	.1307	.1307
24	.112	.0924	.0895	.1143	.1132	.0914	.1132
Max	.2241	.2402	.2353	.2279	.2126	.2126	.1698
Min	.0943	.0543	.0716	.0943	.0943	.0543	.0663
Avg	.1418	.1256	.1384	.1375	.1320	.1238	.1239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 206 / 11 KV DHANTAKE WARANA

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.0537			.0716	.0716	
3	.0537	.1433	.2103	.1448	.1433	.1791
4	.0537	.1791	.208	.1433	.1433	.1791
5	.0537	.2149	.2126	.1433	.1433	.2149
6	.0537	.2149	.2172	.1433	.1433	.2149
7	.0537	.2328	.2172	.1433	.1433	.2328
8	.0537	.2328	.2126	.1433	.1433	.2303
9	.0716	.2328	.2172	.1629	.0179	.2303
10	.1433	.2254	.2149	.1612	.2149	.2126
11	.1791	.2279	.2172	.1463	.2149	.2172
12	.1791	.2303	.2149	.1646	.2328	.2126
13	.2149	.2058	.2149	.1698	.2328	.2103
14	.2149	.208	.2378	.1448	.2328	.208
15	.2328	.2172	.2427	.1307	.2149	.2058
16	.2328	.2126	.2149	.0191	.2149	.2126
17	.2149	.208		.0191	.1791	.2058
18	.2149	.2172	.2328	.0191	.1791	.197
Max	.2328	.2328	.2427	.1698	.2328	.2328
Min	.0537	.1433	.208	.0191	.0179	.1791
Avg	.1338	.2127	.2190	.1218	.1686	.2102

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 401 / 33KV INGRUL KAPARI LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6584	.5373	.4344	.6984	.4298	.4344
2	.6653	.5373	.7207	.6984	.4344	.4344
3	.6653	.6447	.7133	.7059	.4887	.543
4	.7207	.6447	.7207	.7059	.4887	.543
5	.7207	.6447	.743	.7522	.4887	.543
6	.7207	.7522	.7207	.7522	.4938	.6516
7	.7207	.7522	.7762	.7362	.4938	.6516
8	.7133	.7522	.7133	.7362	.4887	.6516
9	.7762	.7522	.7282	.7522	.499	.6516
10	.7682	.8145	.7207	.7602	.499	.6379
11	.7602	.8145	.7682	.7602	.4435	.631
12	.7602	.7602	.7522	.7522	.439	.6447
13	.7602	.6984	.7682	.7522	.439	.6447
14	.7602	.6984	.7602	.7133	.4344	.6516
15	.7602	.7059	.7842	.7207	.4344	.6516
16	.6516		.0566		.4298	
Max	.7762	.8145	.7842	.7602	.499	.6516
Min	.6516	.5373	.0566	.6984	.4298	.4344
Avg	.7239	.7006	.6801	.7331	.4640	.5977

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244098 / 33/11 KV KANDUR S/STN.

Feeder No / Name : 201 / 11 KV KANDUR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0446	.048	1.1873	1.1092	1.0155	.0434	.0434
2	.044	.0469	1.1843	1.0437	1.0155	.0429	.0406
3	.0446	.0469	1.1843	1.0402	1.0155	.0429	.0406
4	.0446	.0469	1.1843	1.0722	.9998	.0579	.0417
5	.0452	.0469	1.1561	1.1385	1.0623	.0579	.0417
6	.0446	.0469	1.2651	1.2651		.0572	.0429
7		.0463	1.2498	1.25		.0587	.0406
8	.044	.0429	.0394	.0417		.0556	.0412
9	2.2775	2.3148	.0412	.0324	.0533	2.2531	2.251
10	2.2447	2.4059	.04	.0312	.0564	2.3434	
11	2.1628	2.2725	.0406	.029	.0533	2.1872	2.0243
12	2.13	2.0309		.0293	.0518	2.3365	
13	1.9919	1.8595		.0297	.0518	2.1872	
14		1.9204		.0305	.0518	2.0557	
15		1.8027		.0446	.0518	1.9444	
16	1.8023	1.5623	.0412	.044	.0511	1.906	
17	.0372	.0394	.0434	.0429	.0511	.0394	
18	.0423	.0394	.0556	.0549		.0389	
19	.0469	.0394	.0617	.0463			
20	.044	.0406	.061	.0469	.0587		
21	.0429	.0394	.0594	.0446	.0579		
22	.0497	1.3283	1.3923	1.4327	.0587		
23	.0486	1.2498	1.3603	1.3108	.0594	.0417	.0312
24	.0446	.048	1.2186	1.2334	1.2346	.0587	.0429
Max	2.2775	2.4059	1.3923	1.4327	1.2346	2.3434	2.251
Min	.0372	.0394	.0394	.029	.0511	.0389	.0312
Avg	.6322	.8069	.6433	.5185	.3711	.8904	.3902

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244098 / 33/11 KV KANDUR S/STN.

Feeder No / Name : 202 / 11 KV PUNVAT GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.1478	.132	.1494	.1478	.1478	.1307
2	.128	.1478	.132	.1494	.1494	.1463	.1307
3	.1307	.1478	.132	.1294	.1494	.1478	.1307
4	.1494	.1478	.1294	.1478	.1494	.1663	.1307
5	.1848	.1663	.1886	.1829	.1848	.1848	.1829
6	.2218	.1663	.2149	.2172	.2353	.2195	.2402
7	.2686	.2328	.2328	.2328	.2686	.2229	.2328
8	.2058	.2012	.2149	.208		.2155	.197
9	.218	.1928	.213	.2035	.2012	.2058	.1619
10	.1966	.1734	.2105	.1619	.1739	.1865	.1865
11	.1802	.1578	.1943	.1781	.1562	.1715	.1543
12	.1311	.1595	.1943	.1802	.1543	.1526	.1
13	.1696	.1595	.1638	.1581	.1457	.1526	
14	.1526	.1612	.1492	.1457	.1311	.1543	
15	.1526	.181	.1619	.1509	.1372	.1753	
16	.2267	.1949	.192	.1875	.1635	.1907	
17	.2031	.1949	.25	.1829	.2027	.1928	
18	.1966	.2149	.2187	.192		.2126	
19	.2229	.2658	.2279	.2204			
20	.3189	.2865	.3012	.2686	.2572		
21	.2715	.2715	.2715	.2195	.2303		
22	.2587	.2378	.2378	.2012	.1991		
23	.1848	.1848	.2033	.1646	.1829	.1867	.1848
24	.1848	.1478	.1478	.1663	.1478	.1463	.1494
Max	.3189	.2865	.3012	.2686	.2686	.2229	.2402
Min	.128	.1478	.1294	.1294	.1311	.1463	.1
Avg	.1961	.1892	.1964	.1833	.1794	.1789	.1652

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244098 / 33/11 KV KANDUR S/STN.

Feeder No / Name : 203 / 11 KV SAGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.1509	.1494	.1494	.1307	.1307	.1307
2	.1132	.132	.1494	.132	.1307	.132	.1307
3	.1132	.132	.1494	.132	.132	.132	.128
4	.1132	.132	.0884	.1494	.132	.1494	.128
5	.1494	.1698	.1494	.168	.1509	.1698	.197
6	.1886	.1886	.1991	.2075	.2378	.2054	.2195
7	.048	.2218	.2172	.2172	.2378		.2149
8	.2103	.1772	.1791	.1772		.2507	.1772
9	.1907	.1753	.12	.1715	.1886	.2229	.1696
10	.1658	.156	.1677	.1677	.1943	.1526	.1865
11	.1658	.1715	.1696	.1658	.1739	.1526	.1526
12	.1658	.1753	.1715	.1677	.1562	.1543	
13	.1715	.1595	.1578	.1677	.1619		
14	.1543	.1578	.1595	.1658	.1526	.1578	
15	.1543	.1629	.1715	.1844	.1509	.1886	
16	.1658	.1612	.1696	.2105	.1638	.1928	
17	.1658	.1772	.1677	.1718	.16	.1928	
18	.1658	.197	.1823	.1781		.1791	
19	.2427	.2658	.2743	.2401			
20	.3012	.2865	.2686	.2715	.2629		
21	.2195	.2534	.2743	.2195	.2328		
22	.2402	.2378	.2402	.2033	.2195		
23	.2033	.1901	.1867	.1663	.181	.1829	.168
24	.1494	.1698	.168	.1663	.1494	.1463	.1494
Max	.3012	.2865	.2743	.2715	.2629	.2507	.2195
Min	.048	.132	.0884	.132	.1307	.1307	.128
Avg	.1696	.1834	.1804	.1813	.1762	.1718	.1655

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244110 / 33/11 MIDC SHIRALA

Feeder No / Name : 201 / 11 KV KARMALA AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.3018	.2229	.6401	.6744	.3033	.3002
2	.3182	.2644	.2229	.5487	.6744	.3033	.2644
3	.317	.2656	.2229	.5487	.6744	.3033	.2644
4	.317	.2656	.2229	.6249	.7037	.3033	.2644
5	.3536	.2656	.4214	.6858	.7525	.3033	.2621
6	.3902	.3765	.4877	1.0311	1.0612	.3976	.3353
7	.482	.5212	.6706	1.7743	.9907	.4927	.4847
8	.4847	.4793	.2865	.5243	.5801	.4549	.5151
9	1.5257	1.6918	.197	.3673	.3296	1.8229	1.5089
10	1.4784	1.6613	.1949	.3239	.2987	1.8496	1.3733
11	1.3413	1.4403	.1949	.3452	.2987	1.6575	
12	1.0296	1.2479	.1949	.341	.2987	1.2971	
13	.5335	1.1431	.1949	.3452	.3353	1.1912	
14	.3763	.9001	.1791	.3239	.2987	1.1203	
15	.5335	.9001	.197	.3239	.3353	.9507	
16	1.0205	1.0045	.2103	.3239	.3353	1.0468	
17	.4039	.4058	.2229	.3627	.3599	.3734	
18	.3778	.3494	.2254	.3753	.3787	.3353	
19	.5304	.4688	.2926	.4111	.4542	.3926	.3048
20	.6443	.49	.3326	.5273	.5304	.5273	.3048
21	.6443	.5243	.3326	.5087	.4927	.5087	.3048
22	.5689	.8177	.4062	1.0365	.4927	.49	.3048
23	.4527	.7195	.3704	1.118	.4361	.4527	.2286
24	.3334	.5677	.2229	.8576	.3353	.3222	.3391
Max	1.5257	1.6918	.6706	1.7743	1.0612	1.8496	1.5089
Min	.317	.2644	.1791	.3239	.2987	.3033	.2286
Avg	.6164	.7113	.2803	.5946	.5051	.7167	.4600

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244110 / 33/11 MIDC SHIRALA

Feeder No / Name : 202 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2134	.2949	.2972
2	.2103	.25	.2972
3	.2103	.2378	.2972
4	.1981	.2709	.2934
5	.2012	.2972	.2896
6	.1829	.3201	.2858
7	.1707	.2984	.1486
8	.1829	.2503	.1707
9	.3772	.5014	.3841
10	1.3203	.8299	.5847
11	1.2449	1.0374	.7922
12	1.0185		1.0185
13	1.2071	1.094	.9808
14	.4527	.7468	.8962
15	1.2071	.7842	.6722
16	1.2157	1.094	
17	1.1694	1.094	
18	1.1317	.7922	
19	.8962	.8299	
20	.4557	.8589	
21	.3506	.4477	
22	.3391	.394	
23	.2949	.3521	
24	.2195	.2591	.2972
Max	1.3203	1.094	1.0185
Min	.1707	.2378	.1486
Avg	.6029	.5798	.4816

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244110 / 33/11 MIDC SHIRALA

Feeder No / Name : 203 / 11 KV PADALIWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2672	2.3922	.1147	.1097	.1006	.6081	.7449
2	2.2672	2.3594	.1147	.1075	.1006	.6081	.6802
3	2.2939	2.2283	.1147	.1052	.1006	.6081	.6802
4	2.2672	2.13	.1147	.1052	.1006	.6081	.6802
5	2.251	2.0972	.1147	.1227	.1006	.6401	.7125
6	2.1376	2.0972	.1147	.1387	.1174	.7682	.7773
7	2.2672	2.13	.1311	.1387	.1341	.8002	.8583
8	.1134	.1147	.1311	.1029	.1341	.0934	.1296
9	.081	.1147	2.8837	2.9504	1.2239	.08	.0972
10	.0983	.0983	2.982	2.7854	.6554	.0937	.0791
11	.0983	.0983	2.982	2.73	1.0159	.0972	
12	.0983	.0983	2.7362	2.6282	1.1142	.0972	
13		.0983	2.7526	2.8292	1.0562	.1134	
14	.0819	.0983	2.7526	2.7161	1.0242	.1134	
15		.0983	2.769	2.6749	1.0242	.1134	
16	.0983	.0983	2.6216	2.6235	.9922	.1134	
17	.0983	.0983	.1147	.0503	.0823	.1134	
18	.1311	.0983	.0983	.1006	.096	.1296	
19	.1311	.1147	.0983	.1174	.1067	.1296	
20	.1311	.1311	.1147	.1006	.1067	.1296	
21	.1311	.1311	.0983	.0924	.08	.1134	
22	2.3594	.0983	.1147	.1006	.7202		
23	2.4249	.1147	.132	.1006	.7042	.6802	
24	2.3644	2.4249	.1147	.1132	.1006	.7682	.7773
Max	2.4249	2.4249	2.982	2.9504	1.2239	.8002	.8583
Min	.081	.0983	.0983	.0503	.08	.08	.0791
Avg	1.0996	.8151	1.0132	.9852	.4580	.3313	.5652

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244121 / 33/11 KV BILASHI

Feeder No / Name : 201 / 11 KV MANGRUL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4097	1.2987	.0154	.0166	.0166	1.1045	1.1305
2	1.3241	1.1759	.0154	.0166	.0166	1.0599	1.0462
3	1.286	1.0544	.0154	.0166	.0166	.9783	.9699
4	1.2159	1.0262	.0154	.0166	.0166	.9396	.9088
5	1.2458	1.0655	.0154	.0166	.0166	.9229	.9218
6	1.3155	1.2206	.0154	.0332	.0475	.985	1.0294
7	1.4123	1.2499	.0166	.0484	.0536	1.0534	1.2319
8	.3222	.2725	.0166	.085	.0774	.2329	.2935
9	.0603	.0467	1.0442	2.1173	2.21	.0631	.0453
10	.0606	.0166	.8951	2.1458	2.2447	.0315	.013
11	.0183	.0166	1.0277	2.1199	2.2231	.0193	
12			.9945	2.0507	2.1776	.0166	.0061
13			.9614	1.9507	2.0315	.0166	.017
14			.8453	1.8478	2.0148	.0166	***
15	.0351		.779	1.8864	1.9458	.0166	.0166
16	.0166	.0238	.7293	1.817	1.8363	.0166	***
17	.0774	.0299	.0166	.41	.2871	.028	***
18	.0284	.0326	.0332	.0616	.0332	.0425	.0343
19	.0539	.0583	.0332	.0885	.0332	.0261	***
20	.0315	.0341	.0332	.0885	.0425	.0166	***
21	.0166	.0166	.0332	.0627	.0166	.0166	.0166
22	1.3104	.0414	.0332	.017	1.2808	1.4072	***
23	1.394	.0638	.0166	.0166	1.3134	1.4613	***
24	1.4322	.6186	.0154	.0166	.6952	1.2954	1.3893
Max	1.4322	1.2987	1.0442	2.1458	2.2447	1.4613	25.6345
Min	.0166	.0166	.0154	.0166	.0166	.0166	.0061
Avg	.6698	.4681	.3174	.7061	.8603	.4903	8.0542

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244121 / 33/11 KV BILASHI

Feeder No / Name : 202 / 11 KV KOKARUD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0156	.0156	.3437	.8657	.6135	.0152	.0154
2	.0156	.0156	.3437	.8055	.5937	.0152	.0154
3	.0156	.0156	.3281	.7834	.5677	.0152	.0154
4	.0156	.0156	.3281	.7845	.5221	.0152	.0154
5	.0156	.0156	.3704	.7979	.5388	.0152	.0154
6	.0156	.0156	.4012	.9046	.6097	.0152	.0154
7	.0156	.0156	.4475	.9961	.6006	.0152	.0154
8	.1299	.1162	.0156	.0156	.0156	.1059	.1175
9	1.8453	1.9025	.0156	.0156	.0156	1.8617	1.8732
10	1.936	1.9517	.0156	.0156	.0156	1.7734	1.8481
11	1.9978	1.8751	.0156	.0156	.0156	1.5592	1.8023
12	1.8682	1.0463	.0156	.0156	.0156	1.7844	.9831
13	1.7455	.016	.0156	.0164	.0156	1.7402	
14	.6317		.0156	.0156	.0156	1.6819	
15	.932		.0156	.0152	.0156	1.6803	
16	1.3138	1.6727	.0156	.0156	.0156	1.6534	1.3535
17	.0156	.0158	.0156	.0156	.0156	.0154	.0156
18	.0156	.0158	.0312	.0156	.0156	.0154	.0156
19	.0156	.0158	.0312	.0186	.0156	.0154	.0156
20	.0156	.0158	.0312	.0156	.0156	.0154	.0156
21	.0156	.0989	.0312	.088	.0156	.0154	.0156
22	.0156	1.0823	.4999	.7506	.0152	.0154	.0156
23	.0156	.989	.4687	.7354	.0152	.0154	.0156
24	.0156	.4995	.3906	.7735	.3125	.0152	1.25
Max	1.9978	1.9517	.4999	.9961	.6135	1.8617	1.8732
Min	.0156	.0156	.0156	.0152	.0152	.0152	.0154
Avg	.5264	.5192	.1751	.3538	.1920	.5862	.4497

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244121 / 33/11 KV BILASHI

Feeder No / Name : 203 / 11 KV KOKARUD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3506	.3467	.3641	.3467	.3391	.3681	.3258
2	.333	.3294	.3641	.3467	.3391	.3506	.3258
3	.3155	.3121	.3294	.3467	.3222	.3506	.3086
4	.3155	.3121	.3294	.3814	.3222	.3681	.3086
5	.4733	.4161	.4508	.4334	.39	.4382	.3601
6	.5258	.5548	.5548	.5548	.5256	.5375	.4458
7	.6135	.5895	.5548	.5721	.5426	.5548	.5487
8	.5375	.6068	.5548	.5201	.5087	.5201	.5144
9	.4508	.4733	.5201	.4681	.4409	.4801	
10	.4508	.4733	.4508	.4854	.5087	.4115	
11	.4681	.4908	.5201	.4854	.5087	.4458	.4508
12	.5028	.5434	.5201	.4681	.5087	.4801	.5201
13		.5609	.5201	.4854	.4748	.4973	.4748
14	.5201	.5258	.4854	.5028	.4409	.5144	.5087
15	.5375	.5258	.5548	.4681	.5087	.5487	.4748
16	.4854	.4908	.5895	.5201	.4917	.4801	.4239
17	.5548	.6135	.6241	.5375	.5596	.5144	.4748
18	.5721	.5959	.5548	.5721	.5087	.583	.4801
19	.7282	.7362	.7108	.6588	.6783	.6344	.6173
20	.7975	.8238	.7975	.7282	.7122	.7802	.6859
21	.6935	.7362	.7108	.6104	.6613	.6344	.6173
22	.6241	.6135	.6241	.5258	.5609	.5144	.5487
23	.4681	.4382	.4854	.4207	.4733	.3258	.4287
24	.3856	.3814	.3988	.3814	.3561	.4031	.3258
Max	.7975	.8238	.7975	.7282	.7122	.7802	.6859
Min	.3155	.3121	.3294	.3467	.3222	.3258	.3086
Avg	.5089	.5204	.5237	.4925	.4868	.4890	.4623

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 201 / 11 KV Dafalapur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	.7716		.3142	.3429	.2957	1.2003
2	.8383	.7716		.3142	.3048	.2926	1.2003
3	.8383	.7716		.3142	.3048	.2957	1.2003
4	.9892	.7716		.2915	.3429	.2957	1.3717
5	1.1401	.9602		.462	.3963	.4251	1.5432
6	1.5089	1.5432		.7207	.583	.6653	1.5947
7	1.7101			.6535	.5182	.6468	1.869
8	.5228			.4938	.4458	.4435	.4904
9	.4108	.3277		1.5402	1.4403	.3696	.3584
10	.3547		1.7187	1.5684	1.2763	.3326	.3395
11	.2743	.3292	1.7528	1.4232	1.3289	.3018	.2987
12	.2915	.2926	1.6991	1.0974	1.2757	.2263	.2987
13	.2229	.2743	1.5402	1.0631	1.2715	.3018	.2987
14	.2458	.2772	1.4706	.9012	1.2536	.3206	
15		.2772	1.1576	1.1633	1.3643	.2641	
16	.2915	.2402	1.2894		1.3253	.2641	
17	.2458	.3142	.3841	.3086	.3142	.3584	
18	.3201	.4163	.462		.3696	.4527	
19	.5316	.567	.6283	.4458	.5487	.5847	
20		.6001	.6099	.4588	.5729	.6036	
21	.5079	.5359	.5544	.4287	.5175	.5658	
22	1.0974		.4066	.3605	.4251	1.3717	
23	.8356		.3292	.3086		1.3375	
24	.9389	.7045		.3292	.2915	.3109	1.286
Max	1.7101	1.5432	1.7528	1.5684	1.4403	1.3717	1.869
Min	.2229	.2402	.3292	.2915	.2915	.2263	.2987
Avg	.6798	.5656	1.0002	.6801	.7310	.4719	.9536

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 202 / 11 KV Baj AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0898	1.1469	1.2382	.3511	.2458	.3142	1.5432
2	1.0898	1.0669	1.1999	.3511	.2572	.3142	.1543
3	1.0898	1.2003	1.1744	.3511	.2486	.3142	1.5432
4	1.1568	1.2003	1.2254	.3475	.2401	.3142	1.6289
5	1.358	1.2498	1.262	.462	.3772	.4251	.1835
6	1.7939	1.7985	1.5592	.6099	.4475	.5729	2.0405
7	1.8442		1.8229	.5729	.4807	.5359	2.332
8	.4668		.4435	.4207	.3601	.3511	.415
9	.3361		1.4232	1.9591	1.7833		.3206
10	.3174	.2458	1.5769	1.9418	1.5432		.3206
11	.2572	.2926	1.3756	1.7071	1.5581		.2427
12	.2486	.2772	1.4175	1.3599	1.4685	.3018	.2614
13	.213	.2743	1.1694	1.1431	1.6124	.3395	
14	.1715	.2926	.6468	1.3108	1.576	.3395	
15		.2587	1.576	1.6712	1.7541	.3018	
16	.2743	.2587	1.7147		1.825	.3206	
17	.2743	.2957	.2957			.3772	
18	.3086	.3696	.3696			.415	
19	.3963	.4706	.5121	.4115	.5175	.4715	
20	.4239	.4938	.4938	.3605	.5175	.5093	
21		.4066	.462	.3258	.4024	.4338	
22	1.6461	1.7556	.3881	.2915	.3881	1.8004	
23	1.3108	1.2536	.3511	.2458		1.7147	
24	1.2071	1.0364	1.2308	.3696	.2622	.3086	1.6289
Max	1.8442	1.7985	1.8229	1.9591	1.825	1.8004	2.332
Min	.1715	.2458	.2957	.2458	.2401	.3018	.1543
Avg	.7852	.7450	1.0387	.7888	.8507	.5131	.9704

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 203 / 11KV Mirwad AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2075	.1715	.1829	1.2178	.9907	1.0425	.1698
2	.2054	.1715	.1848	1.2178	.9907	1.0534	.1698
3	.2054	.1715	.1753	1.2178	1.065	1.0099	.1698
4	.2241	.1715	.1772	1.2178	.9907	1.0208	.2263
5	.2801	.2458	.2743	1.5947	1.3032	1.2449	.3018
6	.3547	.3391	.3841	1.9938	1.6409	1.576	.3584
7	.4108		.4024	2.6467	2.1605	1.8073	.3772
8	.2801	.2429	.2743	.2957	.2915	.2402	.2829
9	1.9616	2.0972	.1646	.2195	.1677	1.8031	2.2805
10	1.9448	1.9204	.1698	.1829	.1886	1.8861	2.2977
11	1.8861	2.2028	.1463	.12	.1494	1.5947	2.1293
12	1.6712	2.0748	.1494	.1543	.1494	1.7318	
13	1.5089		.168	.1219	.1509	1.749	
14	1.166	1.9547	.1463	.1543	.1463	1.6632	
15		1.4842	.1294	.1311	.1509	1.8004	
16	1.2346	1.647	.1543		.1663	1.8861	
17	.1715	.181	.1509	.1886	.1848	.2075	
18	.1802	.2012	.1663		.1848	.2452	
19	.3113	.4525		.2743	.3326	.2829	
20	.2785	.3511	.3326	.2294	.3292	.3206	
21	.2622	.2957	.2715	.2572	.2743	.2829	
22	.2263	.2427	1.8604	1.2193	1.6832	.2263	
23	.1802	.2033	1.3611	1.166		.2075	
24	.2054	.1638	.2012	1.2357	1.065	1.0277	.1886
Max	1.9616	2.2028	1.8604	2.6467	2.1605	1.8861	2.2977
Min	.1715	.1638	.1294	.12	.1463	.2075	.1698
Avg	.6677	.7721	.3316	.7753	.6416	1.0796	.7460

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 204 / 11 Kv Baj Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.1509	.0934	.0943	.132	.0857	.1132
2	.1307	.1372	.0934	.0934	.1067	.0943	.1132
3	.1307	.1372	.0953	.0943	.132	.0943	.1132
4	.1307	.1509	.0953	.0943	.116	.0943	.132
5	.1494	.1509	.1698	.1494	.132	.168	.1698
6	.2241	.1311	.2241	.1867		.2218	.2075
7	.2241		.2402	.2452	.1326	.2218	.1886
8	.1307		.1715	.1867	.12	.1543	.1509
9	.112		.168	.1494	.132	.2988	.132
10	.1494		.132	.1307	.1372	.1294	.132
11	.1219	.112	.132	.132	.1307	.132	.0747
12	.1433	.1109	.1132	.12	.112	.132	.112
13	.132	.0934	.0747	.1509	.1307	.1132	.112
14	.1311	.0934	.0943	.1311	.112	.132	
15	.1307	.0924	.0943	.132	.0943	.132	
16	.12	.0934	.1132		.1132	.1132	
17	.12	.1478	.1715	.1372	.1867	.132	
18	.1219	.2054	.168		.2241	.1886	
19	.2263	.2772	.2427	.1886	.2587	.2263	
20	.2035	.2534	.2058	.1886	.2452	.2641	
21	.1638	.2054	.2054	.1886	.2241	.1886	
22	.1524	.1494	.1543	.1311	.1509	.1509	
23	.1509	.112	.112	.1067		.132	
24	.1307	.1372	.1075	.112	.132	.112	.1132
Max	.2263	.2772	.2427	.2452	.2587	.2988	.2075
Min	.112	.0924	.0747	.0934	.0943	.0857	.0747
Avg	.1484	.1471	.1447	.1429	.1480	.1547	.1332

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 205 / 11 KV Dafalapur GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.1372	.112	.1132	.1029	.112	.1132
2	.112	.1509	.112	.112	.1029	.1132	.1132
3	.112	.1372	.1143	.1132	.0983	.112	.1132
4	.112	.1372	.1143	.112	.1132	.112	.132
5	.1307		.1307	.1494	.0914	.168	.132
6	.1494	.1494	.1509	.1698	.1509	.2033	.1509
7	.1494		.1494	.1509	.1372	.2427	.1509
8	.112	.1029	.1307	.1307	.12	.1132	.132
9	.1307		.1307		.12		.1132
10	.168	.1509	.1494	.1307	.1509	.112	.1132
11	.1372	.1294	.1867	.12	.1867	.132	.1307
12	.1433	.1494	.168	.12	.1494	.132	.1307
13	.128	.1494	.1494	.1372	.1867	.1509	.1494
14	.1509	.1848	.1494	.1372	.1494	.1509	
15	.132	.2195	.1646	.132	.1478	.1509	
16	.1372	.2054	.1494		.1494	.1509	
17	.1372	.2033	.2033	.1372	.1867	.2263	
18	.1698	.1867	.2054		.168	.2263	
19	.2263	.2378	.2427	.2075	.2614	.2641	
20		.2427	.2241	.2075	.2427	.2641	
21	.1802	.2054	.2054	.1619	.2075	.2075	
22	.1638	.1663	.168	.1372	.1698	.1886	
23	.1509	.1494	.1307			.1509	
24	.112	.1463	.1307		.132	.1307	.132
Max	.2263	.2427	.2427	.2075	.2614	.2641	.1509
Min	.112	.1029	.112	.112	.0914	.112	.1132
Avg	.1416	.1686	.1572	.1410	.1533	.1658	.1290

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 206 / 11 KV ANKALE DORLI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3174	.2949	.2561	1.7551		1.1871	.2641
2	.3174	.2915	.2587	1.7737		1.1488	.2641
3	.3174	.3086	.2587	1.7364		1.1999	.2641
4	.3361	.3086	.2481	1.7177		1.1871	.3584
5	.3921	.3772	.3511	1.9281		1.3073	.4338
6	.4854	.4458	.5175	2.3834		1.6301	.5093
7	.5415	.6219	.6468	2.8464		2.2018	.5847
8	.3921	.4096	.5175	.4435		2.2539	.4527
9	2.2211	2.6707	.3658	.3511			2.5377
10	2.4697	2.8509		.3326	1.7661	2.7166	2.6235
11	2.4291	2.9767	.2772	.2915	.3326	2.1776	2.5484
12	2.1956	2.6863	.2957	.2915	.3475	2.0919	
13	2.4006	2.489	.2926	.1886	.3696	1.989	
14	1.4737	2.3743	.2033	.2572	.3109	1.9033	
15		2.8921	.2957	.2229	.3475	2.1776	
16	1.7661	1.9342	.3292		.3326	1.9376	
17	.2785	.2926	.439		.2957	.3206	
18	.3944	.3292	.499		.3511	.415	
19	.5041	.4938	.5544		.5304	.4904	
20	.426	.5175	.5359		.5359	.5281	
21	.3401	.4024	.462		.462	.415	
22	.3109	.3142	2.1434		1.7528	.3206	
23	.2622	.2957	.3475			.3018	
24	.3174	.2458	.2743	1.7353		1.2178	.2829
Max	2.4697	2.9767	2.1434	2.8464	1.7661	2.7166	2.6235
Min	.2622	.2458	.2033	.1886	.2957	.3018	.2641
Avg	.9082	1.1176	.4508	1.1409	.5950	1.3530	.9270

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 201 / 11 KV Billur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	31-MAR-17	01-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1696		.9145		.1696
2	.1696		.9145		.1696
3	.1696		.9145		.1696
4	.3052		1.0669		.1696
5	.1696				.1696
6	.2543		1.1431		.2543
7	.1696		.1524		.2543
8	.1696		.1524		.1696
9	1.4918		.1524		1.4918
10	1.326		.1524		1.3413
11		.1524		1.1105	1.1603
12		.1524	.1524	1.1603	
13		.1524	.1524	1.1603	
14		.1524	.1524	1.1603	
15		.1524	.1524	1.326	
16		.1524		1.4918	
17		.1524		.1696	
18		.1524		.1696	
19		.1524		.1696	
20		.2743		.1696	
21				.1696	
22		1.3717		.2204	
23				.1696	
24	.1696		1.0669		.1696
Max	1.4918	1.3717	1.1431	1.4918	1.4918
Min	.1696	.1524	.1524	.1696	.1696
Avg	.4150	.2743	.5171	.6652	.4741

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 202 / 11kv salmalgewadi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	31-MAR-17	01-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.989		1.3717		1.989
2	1.989		1.3717		1.989
3	1.8233		1.3717		1.989
4	1.8233		1.3717		1.989
5	1.989		1.5242		2.3205
6	2.652		1.5242		2.4863
7	2.3205		1.9719		2.652
8	.3315		.0762		.3391
9	1.8233		2.572		1.6575
10	1.8233		2.4006		1.4089
11		2.0576	2.2291	1.3426	1.4089
12		1.9719	2.1434	1.2717	.2543
13		1.9719	1.8623	1.1603	
14		1.9719	2.0576	1.1603	
15		2.0576	2.1434	1.3565	
16		2.2291		1.4918	
17		.0762		.2543	
18		.1524		.2543	
19		.1524		.4239	
20				.5087	
21		.1524		.5087	
22		1.8004		2.652	
23				2.4863	
24	2.3205		1.6461		2.3205
Max	2.652	2.2291	2.572	2.652	2.652
Min	.3315	.0762	.0762	.2543	.2543
Avg	1.8986	1.3267	1.7274	1.1440	1.7542

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 203 / 11 KV Wajrawad ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAR-17	31-MAR-17	01-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1603		.2286		1.326
2	1.1603		.2286		1.326
3	.9945		.2286		1.1603
4	1.1603		.2286		1.1603
5	1.1603		.2286		1.326
6	1.326		.3048		1.4918
7	1.6575		.3048		1.8233
8	.3391		.2286		.2543
9	.2543		1.5242		.1696
10	.1696		1.3717		.1696
11		1.3717	1.3717	.1357	.1357
12		1.2193	1.3717	.1696	.1187
13		1.2193	1.1431	.1696	
14		1.1431	1.1431	.1696	
15		1.2146	1.2193	.1696	
16		1.1431		.1696	
17		.1524		.1696	
18		.1524		.1696	
19		.2286		.2543	
20		.2286		.3391	
21				.2543	
22		.2286		1.989	
23				1.8233	
24	1.4918		.2286		1.6575
Max	1.6575	1.3717	1.5242	1.989	1.8233
Min	.1696	.1524	.2286	.1357	.1187
Avg	.9885	.7547	.7097	.4602	.9322

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 204 / 11 Kv Billur Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	31-MAR-17	01-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0924		.1524		.0924
2	.0924		.1524		.0924
3	.0924		.1524		.0924
4	.0924		.1524		.0924
5	.0924		.1524		.0924
6	.1848		.1524		.1848
7	.0924		.1524		.2772
8	.0924		.1524		.1848
9	.0924		.2286		.0924
10	.0924		.2286		.0924
11		.0762	.1524	.0739	.0739
12		.0762	.1524	.0924	.0739
13		.0762	.1524	.0924	
14		.0762	.0762	.0924	
15		.0762	.1524	.0924	
16		.2286		.0924	
17		.2286		.0924	
18		.1524		.0924	
19		.1524		.1848	
20		.1524		.2772	
21				.1848	
22		.1524		.1294	
23				.0924	
24	.0924		.1524		.0924
Max	.1848	.2286	.2286	.2772	.2772
Min	.0924	.0762	.0762	.0739	.0739
Avg	.1008	.1316	.1572	.1223	.1180

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 205 / 11 kv Wajrwad Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0924			.1524			.1848
2	.0924			.1524			.1478
3	.0924			.1524			.1294
4	.0924			.1524			.1478
5	.0924			1.0669			.1848
6	.1848			.1524			.2772
7	.1848			.1524			.3696
8	.1848			.1524			.2772
9	.1848			.2286			.1848
10	.1848			.2286			.1478
11				.2286		.1478	.1478
12				.2286		.0924	.1478
13			.1524	.2286		.1478	
14			.1524	.2286		.1663	
15			.1524	.2286		.1478	
16						.1478	
17			.1524			.1478	
18			.1524			.1848	
19			.1524			.2772	
20			.1524			.3696	
21						.2772	
22			.1524			.2218	
23						.2402	
24	.2705	.0857	.0857	.1714	.0857	.0857	.2877
Max	.2705	.0857	.1524	1.0669	.0857	.3696	.3696
Min	.0924	.0857	.0857	.1524	.0857	.0857	.1294
Avg	.1506	.0857	.1450	.2441	.0857	.1896	.2027

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 206 / 11 kv Gugwad AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	31-MAR-17	01-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0848		.0762		.0848
2	.0848		.0762		.0848
3	.0848		.0762		.0848
4	.0848		.0762		.0848
5	.0848		.0762		.0678
6	.0848		.0762		.0848
7	.0848		.0762		.0848
8	.0848		.0305		.0678
9	.2486		.0305		.3315
10	.2486		.0152		.2486
11		.0305	.0305	.2652	.2486
12		.0762	.0305	.2543	
13		.0305	.0305	.1696	
14		.0152	.0457	.1658	
15			.0457	.2543	
16				.3315	
17		.0457		.0509	
18		.0152		.0509	
19		.0305		.0848	
20				.0848	
21		.0305		.0848	
22		.0762		.0848	
23				.0848	
24	.0848		.0305		.0848
Max	.2486	.0762	.0762	.3315	.3315
Min	.0848	.0152	.0152	.0509	.0678
Avg	.1146	.0389	.0514	.1513	.1298

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244036 / 33/11 KV SHEGAON

Feeder No / Name : 201 / 11 KV SHEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1966	.2294	.1802	.8848	.5571	.7865	.1966
2	.1966	.2294	.1638	.852	.5571	.7537	.1966
3	.1638	.2294	.1638	.852	.5571	.7537	.1966
4	.1638	.2294	.1802	.9503	.6554	.9175	.1966
5	.213	.3605	.3277	1.4746	1.3108	.9175	.3441
6	.3605	.4588	.4588	1.6876	1.6057	1.1142	.5415
7	.5079	.4915	.3932	2.1464	2.0317	.852	.4588
8	.3113	.3277	.3277	.2622	.3277	.3277	.2949
9	1.1469	1.8515	.2622	.2294	.2622	1.3435	1.6712
10	1.6712	2.0317	.2622	.2294		1.6385	.9012
11	1.6385	1.8842	.2458	.2622	.2294	1.7695	1.6549
12	1.6221	1.7368	.2458	.2622	.2294	1.5729	
13		1.704		.2622	.2294	1.5565	
14		1.5074	.2294	.2785	.2294	1.491	
15	.4588	1.704	.2294	.2622	.2294	1.5729	
16		1.5074	.2294	.2458	.2294	1.5893	
17	.2785	.2458	.2622	.1966	.2294	.1966	
18	.3277	.2622	.2949	.2785	.2622	.2949	
19	.3605	.3932	.3768	.1966	.3277	.4096	
20	.4096	.3932	.3605		.4096	.4096	
21	.3932	.3932	.3605	.2949	.3605	.3441	
22	.2949	.3277	1.3108	.6554	1.1142	.2949	
23	.2458	.1638	1.065	.6226	.9175	.2294	
24	.2458	.2294	.1966	.9012	.6062	.7865	.213
Max	1.6712	2.0317	1.3108	2.1464	2.0317	1.7695	1.6712
Min	.1638	.1638	.1638	.1966	.2294	.1966	.1966
Avg	.5337	.7872	.3533	.6212	.5856	.9134	.5722

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244036 / 33/11 KV SHEGAON

Feeder No / Name : 202 / 11 KV Walekhindi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.116	.213	.1492	.663	.6554	.6882	.1475
2	.116	.213	.1492	.663	.6554	.6554	.1475
3	.116	.213	.1326	.6299	.6554	.5898	.1311
4	.116	.213	.1326	.6962	.6554	.5243	.1311
5	.1658	.2294	.1823	.9116	.8192	.6554	.1475
6	.1989	.2294	.2155	1.0608	1.0159	.7701	.1638
7	.1989	.2294	.1989	1.2266	1.1305	.7209	.1802
8	.1492	.213	.1989	.2155	.2294	.213	.1802
9	.9779	1.0486	.1823	.1989	.1966	.9667	1.065
10	1.2929	1.1633	.1989	.2321	.1966	.9831	1.1633
11	1.0442	1.1142	.2321	.0829	.1966	1.0159	.1341
12	1.1271	1.1142	.2155	.1823	.1638	1.065	
13	1.1934	1.0978	.2321	.2321	.1802	.8848	
14	.8619	1.094	.2321	.2155	.213	.9667	
15	.4144	1.094	.2486	.2155	.2294	.8684	
16	.1638	1.1768	.2321	.1989	.0983	.9667	
17	.1966	.1823	.2155	.2321	.1311	.1475	
18	.1802	.1658	.2155	.2294	.1311	.1475	
19	.213	.1658	.2321	.1966	.2458	.1638	
20	.213	.1989	.2321		.2458	.1638	
21	.213	.1823	.2294	.213	.0983	.1802	
22	.1802	.1823	.9116	.6882	.8029	.1638	
23	.2012	.1658	.7956	.6882	.7701	.1475	
24	.116	.1802	.1658	.6796	.6718	.7045	.1147
Max	1.2929	1.1768	.9116	1.2266	1.1305	1.065	1.1633
Min	.116	.1658	.1326	.0829	.0983	.1475	.1147
Avg	.4069	.5033	.2554	.4588	.4328	.5980	.3088

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244036 / 33/11 KV SHEGAON

Feeder No / Name : 203 / 11 KV SHINGANHALLI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0059	1.1065	.9724	.1844	.2012	.1677	1.0898
2	.9724	1.1065	.9724	.1677	.2012	.1509	1.0562
3	.9724	1.1065	.9724	.1677	.2012	.1341	1.0562
4	1.1736	1.1065	.9389	.1844	.2012	.1341	1.073
5	1.4754	1.5089	1.0898	.2515	.3353	.3018	1.5424
6	1.6766	1.6766	1.3413	.4024	.3688	.4024	1.7604
7	2.0957	1.8778	1.3413	.3185	.285	.3185	2.079
8	.2347	.2683	.2012	.2347	.2347	.218	.2683
9	.1509	.1844	1.5257	1.6933	1.7436	.1677	.218
10	.1677	.1509	1.7772	1.7269	1.7939	.1174	.1677
11	.1341	.1509	1.3077	1.576	1.5257	.112	.1341
12	.1677	.1509	1.576	1.4754	1.4419	.1307	.1677
13	.1844	.1677	1.4083	1.5089	1.3413	.1341	.1677
14	.1509	.1844	1.4754	1.4754	1.3748	.1341	
15		.1677	1.4251	1.3077	1.6095	.1341	
16	.1677	.1677	1.4754	1.4419	1.6766	.1509	
17	.1844	.1844	.2012	.2012	.1509	.1509	
18	.2347	.2012	.2012	.2347	.1677	.218	
19	.2683	.2683	.3353	.2012	.2683	.3353	
20	.3521	.3353	.3018		.3353	.3353	
21	.3018	.3018	.3018	.2683	.3018	.3018	.3018
22	1.5424	1.3413	.2347	.2347	.2347	1.8442	1.7772
23	1.3413	1.2071	.2012	.2012	.2012	1.4922	1.4419
24	1.0562	1.3077	1.0059	.2012	.2012	.2012	.2622
Max	2.0957	1.8778	1.7772	1.7269	1.7939	1.8442	2.079
Min	.1341	.1509	.2012	.1677	.1509	.112	.1341
Avg	.6961	.6762	.9410	.6808	.6832	.3245	.8567

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244036 / 33/11 KV SHEGAON

Feeder No / Name : 204 / 11 Kv Walekhindi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.056	.0373	.0373	.056	.0373	.056
2	.0343	.056	.0373	.0373	.056	.0373	.0373
3	.0373	.056	.0373	.0373	.056	.0373	.0373
4	.0373	.056	.0373	.0373	.056	.0373	.0373
5	.056	.0747	.056	.0747	.0747	.0373	.056
6	.0747	.0934	.0747	.0934	.0934	.0747	.0747
7	.056	.0934	.0934	.0747	.0934	.0747	.056
8	.056	.0934	.056	.056	.056	.056	.056
9	.0373	.0934	.056	.056	.0747	.056	.056
10	.0373	.0934	.056	.0747	.0934	.056	.056
11	.056	.0934	.0373	.0373	.0747	.056	.056
12	.056	.0747	.0373	.0747	.0934	.056	.056
13		.0747	.0373	.0373	.0747	.056	.056
14		.0747	.0747	.0373	.0747	.056	
15		.0747	.056	.0373	.0747	.056	
16	.0747	.0934	.056	.056	.056	.056	
17	.0934	.0747	.0747	.056	.0747		.0747
18	.112	.0747	.0934	.0934	.0747	.0934	.0747
19	.1494	.112	.1307	.0747	.1494	.112	.1307
20	.1307	.0934	.112		.1307	.112	.1307
21	.112	.0934	.112	.0934	.112	.0934	.0934
22	.0747	.0747	.0747	.0747	.0747	.0747	.0747
23	.0747	.056	.056	.0747	.056	.056	.056
24	.056	.056	.056	.056	.0747	.056	.056
Max	.1494	.112	.1307	.0934	.1494	.112	.1307
Min	.0343	.056	.0373	.0373	.056	.0373	.0373
Avg	.0692	.0786	.0646	.0601	.0794	.0625	.0658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244036 / 33/11 KV SHEGAON

Feeder No / Name : 205 / 11 KV SHEGAON GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.1307	.0934	.1494	.1494	.112	.112
2	.112	.1307	.0934	.1494	.1494	.0934	.112
3	.112	.1307	.0934	.1494	.1494	.0934	.112
4	.112	.1307	.0934	.1494	.1494	.0934	.112
5	.1494	.1867	.1307	.3361	.1867	.1307	.1307
6	.1867	.2614	.2427	.2427	.2241	.2241	.2241
7	.2427	.2427	.2427	.2614	.2614	.2241	.2241
8	.2427	.2241	.1867	.2427	.2801	.2241	.2241
9	.2054	.2614	.2427	.2427	.2987	.2801	.3174
10	.2241	.2427	.2801	.2054	.2427	.2241	.2241
11	.2054	.2241	.2427	.2241	.0747	.2054	.2054
12	.2054	.1867	.1867	.2241	.2241	.1867	.1867
13	.2054	.168	.1307	.168	.0373	.168	.168
14	.1494	.168	.1494	.0373	.0373	.168	
15	.112	.1867	.1867	.168	.1494	.1867	
16	.168	.1867	.2054	.2054	.1494	.2241	
17	.1494	.1867	.2054	.2987	.2241	.2241	
18	.2987	.2801	.2054	.2987	.2801	.2614	
19	.3361	.2801	.3361	.2241	.3174	.3547	
20	.2987	.3174	.2987		.3361	.3547	
21	.2614	.2641	.2427	.2427	.2987	.2987	
22	.2241	.1867	.1867	.2054	.2054	.2054	
23	.1494	.1494	.168	.168	.1494	.168	
24	1.6244	.1494	.1307	.168	.1494	.1307	.1307
Max	1.6244	.3174	.3361	.3361	.3361	.3547	.3174
Min	.112	.1307	.0934	.0373	.0373	.0934	.112
Avg	.2536	.2032	.1906	.2070	.1968	.2015	.1774

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244058 / 33/11 KV UMRANI

Feeder No / Name : 202 / 11KV Khojanwadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2926	.439	.3292
2		.2926	.4024	.3292
3		.2743	.4024	.3292
4		.2743	.439	.3292
5		.3292	.462	.3658
6		.439	.5041	.4024
7		.3658	.5601	.5487
8			.5601	.5487
9			.5601	.5121
10			.4854	.5121
11		2.3624	.462	
12		2.3624		
13		2.2862		
14		2.2862		
15		2.21		
16		2.392		
17		.2772		
18	.2926	.3326	2.5911	
19	.3292	.3734	2.5911	
20		.5281	2.4387	
21		.4904	2.2862	
22		.4668	2.2862	
23		.4668	2.2862	
24		.2926	.4435	2.21
Max	.3292	2.392	2.5911	2.21
Min	.2926	.2743	.4024	.3292
Avg	.3109	.9236	1.1222	.5833

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244058 / 33/11 KV UMRANI

Feeder No / Name : 203 / 11 KV SINDUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.253			.9907	.2926
2	.2233	.2583			1.0364	.2926
3	.2446	.2964			1.0494	.2926
4	.2865	.3132			1.0802	.2926
5	.3628	.3772			1.186	.2926
6	.5274	.5525			1.8623	.3292
7	.5708	.6097			2.1605	.3292
8	.5167	.5959			1.9204	.4024
9	.4359	.3513			1.5813	2.0119
10	.3803	.2675			1.5623	1.5089
11	.3384	.2446		.2263	1.4661	
12	.2843	.2454		.2263		
13	.2713	.2759		.2263		
14		.2637		.2263		
15	.1867	.2301		.2241		
16	.2393	.3658		.2241		
17	2.8913	2.6932		.2263		
18	2.8639	2.7915		.2801	.1867	
19	2.6536	2.7039	.2683	.2829	.2801	
20	2.4379	2.3327		.3772	.2743	
21	2.3312	2.2931		.2801	.3292	
22	2.1651	2.1277		.2241	.3292	
23	2.0027	2.0911		.2241		
24	1.9738	1.9639	1.3717		.2218	.2561
Max	2.8913	2.7915	1.3717	.3772	2.1605	2.0119
Min	.1867	.2301	.2683	.2241	.1867	.2561
Avg	1.0615	1.0207	.82	.2499	1.0304	.5728

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244058 / 33/11 KV UMRANI

Feeder No / Name : 204 / 11 Kv Umrani Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0486	.0486
2			.0324	.0486
3			.0324	.0486
4			.0486	.0648
5			.0486	.0648
6			.0972	.081
7			.0648	.0648
8			.0486	.0648
9			.0486	.0648
10			.0486	.0732
11		.0486	.0486	
12		.0486		
13		.0324		
14		.0324		
15		.0324		
16		.0486		
17		.0486		
18	.0972	.0648	.0503	
19	.0972	.081	.081	
20		.0972	.1296	
21		.081	.1457	
22		.081	.1296	
23		.0648	.0648	
24			.0486	.0486
Max	.0972	.0972	.1457	.081
Min	.0972	.0324	.0324	.0486
Avg	.0972	.0586	.0676	.0611

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 201 / 11 KV DEVANAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.8569	3.5675		.2721	.5838	.3628	4.0032
2	3.8386	3.6517		.2721	.5678	.362	3.9628
3	3.8431	3.6631		.2721	.5846	.3658	3.9491
4	3.8938	3.6913		.2721	.6059	.3856	3.946
5	4.0729	3.9022		.3201	.6585	.397	4.5343
6	5.0609	5.2318		.3521	.7994	.4809	5.6386
7	5.6889	5.7614		.3201	.849	.8913	5.7392
8	.5201	.6323	.2343	.3201	1.4106	.785	.5571
9	.4915	.3056	1.8122	2.1125	2.6536	.5761	.5396
10	.5121	.2972	1.9204	2.0965	2.7267	.6116	.5541
11	.5434	.2911	1.8884	2.0805	2.6635	.618	.5777
12	.5571	.2964	1.8564	1.9204	2.5141	.5934	.1562
13	.5396	.3056	1.6804	1.8404	2.3823	.5434	
14	.1128	.2462	1.6804	1.8564	2.412	.5312	
15	.5147	.205	1.9524	2.0805	2.7892	.5228	
16	.5254	.2294	2.0165	2.0325	2.8067	.5091	.5625
17	.5544	.221	.2721	.192	.2561	.5708	.3757
18	.6703	.2888	.3041	.3201	.3125	.5945	.3879
19	.7891	.4047	.2881	.2881	.3917	.6996	.4115
20	.7952	.426	.3041	.2561	.4222	.7446	.4344
21	2.4463	1.8122	.3041	.2241	.4153	2.0424	2.1155
22	4.5688	2.0279	.2881	.2561	.3887	4.132	4.4209
23	4.2536	1.3916	.2881	.2561	.365	4.0311	4.3477
24	4.0131	2.9645		.2721	.6326	2.2123	4.087
Max	5.6889	5.7614	2.0165	2.1125	2.8067	4.132	5.7392
Min	.1128	.205	.2343	.192	.2561	.362	.1562
Avg	2.1943	1.7423	1.0681	.8536	1.2580	.9818	2.4429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 202 / 11 KV PACCHPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.333	.3227		.044	.0587		.3668
2	.333	.3227		.044	.0587		.3668
3	.333	.3227		.044	.0587		.3668
4	.333	.3227		.044	.0587		.3814
5	.3765	.3668		.0734	.0734		.6602
6	.5647	.6455		.088	.0587		.7335
7	.8398	.7188		.0587	.0734	.0869	.6895
8	.124	.0587	.0579	.044		.0579	.0587
9	.0579		.4988	.5135		.0579	.044
10	.0579		.4401	.5575		.0434	.044
11	.0579		.4401	.5428		.0434	.0587
12	.0434		.4694	.5135		.044	
13	.0434		.4401	.5868		.044	
14			.4108	.4694		.044	
15	.0434		.4401	.5135		.044	
16	.0434		.4401	.5135		.044	
17	.0579		.0734	.0587		.044	
18	.0587		.0734	.0587		.044	
19	.0734		.0587	.0587		.0587	
20	.0734		.0734	.0587		.0734	
21	.0734		.0734	.0587		.088	
22	.4401		.0587	.0587		.3227	.4108
23	.4108		.044	.0587		.3668	.4108
24	.333	.3374		.044	.0587		.3668
Max	.8398	.7188	.4988	.5868	.0734	.3668	.7335
Min	.0434	.0587	.044	.044	.0587	.0434	.044
Avg	.2220	.3798	.2558	.2127	.0624	.0887	.3542

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 203 / 11 KV Rawalgundwadi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3401	.3887		2.1052	1.9595		.3401
2	.3401	.3887		2.1052	1.9595		.3401
3	.3401	.3887		2.1052	1.9595		.3401
4	.3563	.3887		2.1052	1.9595		.3401
5	.3887	.4049		2.4615	1.9595		.3887
6	.4534	.4534		2.6073	2.4777		.4534
7	.4049	.4534		2.5911	2.5911	1.7814	.5182
8	.2429	.4049	.4696	.3401		.2267	.3239
9	2.3158		.4049	.3239		1.6194	2.4453
10	2.5101		.3563	.3563		1.8947	2.5587
11	2.4291		.3563	.3401		2.2672	2.4615
12	2.3158		.4049	.3725		2.2996	
13	2.1376		.3887	.3887		2.1628	
14			.3887	.3887		2.1628	
15			.3563	.3887		2.2119	
16	1.5223		.3563	.3887		2.4086	
17	.3077		.3563	.2915		.3277	
18	.3725		.3239	.2591		.2949	
19	.3887		.3401	.2429		.3201	
20	.3887		.4372	.2267		.3201	
21	.3887		.3563	.2267		.4001	
22	.3887		2.2348	2.1862		.426	.5668
23	.3887		2.3158	1.9814		.4588	.5182
24	.3401	.3887		2.1052	2.0243		.3401
Max	2.5101	.4534	2.3158	2.6073	2.5911	2.4086	2.5587
Min	.2429	.3887	.3239	.2267	1.9595	.2267	.3239
Avg	.8664	.4067	.6154	1.1203	2.1113	1.2696	.8525

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 204 / 11 kv Rawalgundwadi Gav

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0886	.0905		.0709	.0886		.0716
2	.0886	.0905		.0532	.0886		.0716
3	.0886	.0905		.0532	.0886		.0716
4	.0886	.0905		.0532	.0886		.1075
5	.1063	.0905		.0532	.1063		.1791
6	.1417	.1448		.0709	.1417		.1254
7	.1417	.1629		.0709	.1417	.1075	.0895
8		.1267	.1075	.1063		.0895	.1433
9	.1086		.0895	.0886		.0716	.1254
10	.1086		.0895	.0886		.0895	.0886
11	.1086		.0895	.0886		.0716	.0709
12	.0905		.0895	.0886		.0895	.1063
13			.0716	.0709		.0895	.1063
14	.0724		.0895	.0709		.0895	
15	.1086		.0716	.0709		.0716	
16	.1086		.0716	.124		.0537	.0905
17	.1448		.0716	.1417		.0537	.0905
18	.181		.0716	.124		.0537	
19	.2172		.0886	.1417		.1791	
20	.2172		.1772	.1417		.1791	.2172
21	.1629		.2303	.1063		.2507	
22	.1086		.1063	.0886		.1075	.1267
23	.0905		.1063	.0886		.1254	.0905
24	.0886	.0905		.2229	.0886		.0716
Max	.2172	.1629	.2303	.2229	.1417	.2507	.2172
Min	.0724	.0905	.0716	.0532	.0886	.0537	.0709
Avg	.1209	.1086	.1014	.0949	.1041	.1043	.1076

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 205 / 11 kv Pachhapur Amrutwadi
gav Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0183	.0181		.0183	.0183		.0185
2	.0183	.0181		.0183	.0183		.0185
3	.0183	.0181		.0183	.0183		.0185
4	.0183	.0181		.0183	.0183		.0185
5	.0183	.0181		.0366	.0366		.037
6	.0549	.0543		.0183	.0549		.037
7	.0549	.0905		.0366	.0732	.0739	.037
8	.0183	.0543	.0185	.0366		.0185	.037
9	.0181		.037	.0183		.0185	.037
10	.0181		.0185	.0183		.037	.0183
11	.0181		.0185	.0183		.0185	.0183
12	.0181		.0185	.0183		.0185	.0183
13			.0185	.0183		.0185	
14	.0181		.0185	.0183		.0185	
15	.0181		.0185	.0183		.0185	
16	.0181		.0185	.0183		.0185	
17	.0181		.0185	.0366		.0185	
18	.0181		.0185	.0183		.0185	
19	.0724		.0183	.0366		.0554	
20	.0905		.0183	.0549		.037	
21	.0543		.0366	.0366		.0185	
22	.0362		.0732	.0183		.0185	.0543
23	.0181		.0914	.0183		.037	.0181
24	.0183	.0181		.0183	.0183		.0185
Max	.0905	.0905	.0914	.0549	.0732	.0739	.0543
Min	.0181	.0181	.0183	.0183	.0183	.0185	.0181
Avg	.0292	.0342	.0287	.0244	.0320	.0272	.0270

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 201 / 11 KV Kosari AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8059	.7888	.6516	.1543	.0514	.1715	.7888
2	.8059	.7545	.6516	.1372	.0514	.1886	.7888
3	.8573	.7545	.6173	.12	.0514	.1886	.823
4	.8916	.7888	.6344	.1715	.0686	.1886	.8916
5	1.2003	.8402	.6859	.2058	.0857	.2229	1.0631
6	1.4575	1.2174	.8745	.2572	.1029	.2743	1.3203
7	1.2517	1.3889	.9602	.2572	.1029	.2743	1.2174
8	.1715	.1886	.2229	.1372		.1715	.1543
9	.1715	.2058	.8916	1.1488		.1715	.1886
10		.1543	1.0117	1.1145	.4287	.2058	.2058
11		.1886	1.0802	1.166	.463	.1886	.2058
12		.1715	1.1145	1.0974	.5487	.1715	.2058
13		.1886	1.0288		.9774	.1715	
14	.1372	.2058	.9602	1.046	1.1488	.1886	
15	.1886	.2572	.9602	1.0802	.8916	.1886	
16	.1543	.2401	1.0631	.9088	.9431	.1715	
17	.1372	.1981	.2058	.1543	.1677	.2058	
18	.1715	.2058	.2229	.1543	.1677	.1715	
19	.2743		.2915	.1543	.2915	.2229	
20	.2915	.2572	.2915		.3086	.2572	
21	.2743	.2229	.2572		.2572	.2401	
22	.9088	.6687	.2229	.0514	.2058	.9431	
23	.9088	.6859	.1886	.0686	.1886	.8402	
24	.8059	.823	.6687	.0686	.0686	.1886	.7888
Max	1.4575	1.3889	1.1145	1.166	1.1488	.9431	1.3203
Min	.1372	.1543	.1886	.0514	.0514	.1715	.1543
Avg	.5933	.4954	.6566	.4597	.3442	.2586	.6648

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 202 / 11 KV Kumbharwadi AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2439	.3086	.2572	1.2651	.5335	1.0288	.2439
2	.2439	.3086	.2572	1.2651	.503	.9431	.2286
3	.2439	.3086	.2572	1.2955	.5182	.9602	.2286
4	.2591	.3258	.2743	1.326	.5487	.9602	.2591
5	.381	.3772	.3429	1.4175	.6097	1.046	.3353
6	.4725	.5316	.4458	1.4937	.9907	1.2174	.4115
7	.4877	.5487	.463	1.7223	1.1431	1.326	.4268
8	.3201	.4115	.3601	.2896	.2743	.3201	.3048
9	2.2291	1.7528	.2591	.3258	.2743	1.3717	1.9719
10		1.7985	.2591	.3429	.2915	1.2041	2.0233
11	1.8004	1.8595	.2896	.3601	.2743	.5335	1.9204
12	1.9033	1.8595	.3353	.3601	.3258	.7164	
13	1.9547	1.8595	.3201		.3086	.9755	
14	1.0974	1.7071	.3506	.3258	.2915	1.4632	
15	.2743	1.7071	.3506	.3086	.2915	1.7985	
16	.9602	1.6918	.3048	.3086	.2743	1.6309	
17	.3601	.2743	.3201	.2591	.2896	.2896	
18	.3772	.3258	.3201	.2591	.3048	.2896	
19	.4801		.381	.2743	.4115	.3963	
20	.4115	.3772	.3658	.2591	.4287	.381	
21	.4115	.3944	.3201	.2743	.3772	.3506	
22	.3429	.3086	1.3565	.5487	1.046	.2896	
23	.3258	.2915	1.2803	.5639	1.0288	.2743	
24	.2743	.3086	.2572	1.2651	.5639	1.046	.2591
Max	2.2291	1.8595	1.3565	1.7223	1.1431	1.7985	2.0233
Min	.2439	.2743	.2572	.2591	.2743	.2743	.2286
Avg	.6893	.8538	.4053	.7004	.4960	.8672	.7178

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 203 / 11 KV Birnal GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.12	.1029	.1029		.1029	.0857
2	.0857	.12	.1029	.0857	.0857	.12	.0686
3	.0857	.12	.1029	.12	.0857	.1029	.0686
4	.1029	.12	.1029	.1372	.1029	.0857	.0857
5	.1543	.1543	.1372	.1715	.12	.1029	.12
6	.2229	.2229	.2058	.2058	.1543	.1543	.1886
7	.2058	.2229	.1886	.1886	.1715	.1886	.2401
8	.1543	.1543	.1543	.1715	.12	.1543	.1715
9	.1715	.1715	.1372	.1372	.1372	.1715	.1372
10		.2229	.1715	.1886	.0857	.1372	.1715
11	.1715	.1543	.1372	.1715	.0857	.1029	.1543
12	.1886	.1715	.1543	.1372	.1029	.1372	.1543
13	.1543	.1715	.1372		.1543	.1543	.12
14	.1372	.1543	.1372	.12	.1715	.12	
15	.1372	.1372	.1372	.12	.1029	.1372	
16	.12	.1715	.1372	.12	.1543	.12	
17	.1543	.1219	.1715	.12	.1715	.1372	
18	.1715	.1715	.1886	.2058	.1524	.1715	
19	.2401		.2401	.1715	.2401	.2401	
20	.2401	.2229	.2572	.1372	.2401	.2572	
21	.2058	.2058	.2058	.12	.2058	.2229	
22	.1715	.1543	.1715	.1372	.1886	.1372	
23	.1543	.1372	.1372	.1029	.1372	.12	
24	.12	.1372	.1029	.12	.1029	.12	.1029
Max	.2401	.2229	.2572	.2058	.2401	.2572	.2401
Min	.0857	.12	.1029	.0857	.0857	.0857	.0686
Avg	.1588	.1626	.1551	.1431	.1423	.1458	.1335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 204 / 11 KV Dhawadwadi GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0686	.0514	.0343	.0686	.0514	.0343
2	.0343	.0686	.0514	.0343	.0686	.0514	.0343
3	.0343	.0686	.0514	.0343	.0686	.0514	.0343
4	.0514	.0686	.0514	.0514	.0686	.0514	.0514
5	.0857	.0686	.0686	.0686	.0857	.0686	.0857
6	.12	.1029	.1029	.1029	.12	.12	.12
7	.12	.1029	.1029	.1029	.0857	.0857	.12
8	.0514	.0514	.0686	.0514	.0514	.0686	.0686
9	.0457	.0514	.0686	.0686	.0171	.0514	.0686
10		.0514	.0514	.0686	.0171	.0686	.0343
11	.0343	.0514	.0514	.0686	.0514	.0686	.0514
12	.0343	.0514	.0514	.0514	.0514	.0686	.1543
13	.0343	.0514	.0686		.0514	.0686	.0686
14	.0343	.0514	.0686	.0514	.0343	.0686	
15	.0514	.0686	.0686	.0514	.0514	.0686	
16	.0514	.0514	.0686	.0514	.0514	.0686	
17	.0686	.061	.0857	.0857	.061	.0686	
18	.0686	.0686	.1029	.0857	.0457	.0857	
19	.12		.0857	.0857	.0857	.1372	
20	.1029	.1029	.1029	.0857	.0857	.12	
21	.1029	.1029	.0857	.0857	.0857	.1029	
22	.0857	.0857	.0686	.0686	.0686	.0857	.0857
23	.0686	.0686	.0514	.0686	.0686	.0686	.0686
24	.0514	.0686	.0514	.0514	.0686	.0514	.0686
Max	.12	.1029	.1029	.1029	.12	.1372	.1543
Min	.0343	.0514	.0514	.0343	.0171	.0514	.0343
Avg	.0646	.0690	.0700	.0656	.0630	.0750	.0718

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 205 / 11 KV Hivare AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.12	.1029	.7926	.2896	.6173	.061
2	.0914	.12	.1029	.7926	.2743	.6001	.061
3	.0914	.12	.1029	.823	.3048	.5658	.061
4	.1067	.12	.1029	.8535	.3353	.583	.0762
5	.1524	.1372	.1029	.945	.4268	.6001	.1067
6	.1981	.2058	.1715	1.0517	.5487	.7545	.1524
7	.1981	.2915	.2058	1.1431	.8688	.9602	.1981
8	.1372	.2229	.1543	.1219	.0914	.0914	.1067
9	.9907	1.1736	.1219	.1372		.9145	1.2003
10		1.2346	.0914	.1543		1.0364	1.3717
11	1.406	1.2955	.1219	.1543		1.1584	1.3375
12	1.3546	1.3108	.1067	.1543	.0343	1.1736	
13	1.4403	1.2498	.1219		.0343	1.1888	
14	.6173	1.3413	.1219	.1372	.0343	1.1279	
15	.3944	1.3413	.1372	.1372	.1029	1.1736	
16	.4973	1.3717	.1524	.1029	.1372	1.1431	
17	.1715	.1067	.1543	.0914	.1219	.0914	
18	.1715	.1029	.1372	.0762	.1067	.1067	
19	.1886		.1677	.0762	.1886	.1219	
20	.2229	.2229	.1677	.0762	.1886	.1372	
21	.1886	.1543	.1524	.0914	.1715	.1067	
22	.1543	.1372	.823	.2591	.703	.0914	
23	.12	.1029	.823	.2743	.6687	.0914	
24	.1067	.12	.1029	.7926	.3048	.6344	.0762
Max	1.4403	1.3717	.823	1.1431	.8688	1.1888	1.3717
Min	.0914	.1029	.0914	.0762	.0343	.0914	.061
Avg	.3953	.5480	.1896	.4017	.2827	.6279	.4007

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 206 / 11 KV Pratapur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4022	1.4575	1.3889	.061	.061	.0857	1.2955
2	1.4022	1.4746	1.3717	.061	.061	.0857	1.2955
3	1.4327	1.4918	1.3375	.061	.061	.0857	1.326
4	1.448	1.5089	1.3546	.0914	.061	.0857	1.3717
5	1.5394	1.5604	1.3889	.1067	.0762	.0857	1.4632
6	1.6309	1.2231	1.5089	.1219	.1067	.1372	1.5851
7	1.6156	1.989	1.5775	.1372	.1067	.1372	1.6309
8	.0914	.1029	.1029	.1067	.0762	.0914	.1067
9	.061	.0762	1.3565	1.7661	1.2689	.0762	.0857
10		.0762	1.7223	1.989	1.4575	.0305	.0686
11	.0686	.0762	1.7985	2.0405	1.6289	.0305	.1029
12	.0686	.0762	1.5242	1.989	1.2346	.061	
13	.0514	.0914	1.7528		1.6118	.0762	
14	.0686	.0762	1.6766	1.9719	1.6804	.061	
15	.1029	.061	1.7071	1.8004	1.5432	.061	
16	.0857	.1219	1.5699	1.5261	1.7147	.0914	
17	.1029	.061	.061	.0762	.061	.0762	
18	.1029	.0686	.0762	.0914	.061	.0914	
19	.1543		.1219	.0914	.1029	.1524	
20	.1543	.1372	.1219	.0762	.1029	.1524	
21	.1372	.1372	.1067	.0762	.12	.1372	
22	1.4746	1.5432	.0914	.061	.0857	1.4175	
23	1.5432	1.4746	.0762	.061	.0857	1.3565	
24	1.4022	1.4575	1.406	.0762	.061	.0857	1.2955
Max	1.6309	1.989	1.7985	2.0405	1.7147	1.4175	1.6309
Min	.0514	.061	.061	.061	.061	.0305	.0686
Avg	.7018	.7106	1.0500	.6278	.5596	.1980	.9689

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244114 / 33/11KV JIRGYAL

Feeder No / Name : 201 / 11 KV JIRGYAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4969	1.5581	1.25	.1715	.1524	.1715	1.4089
2	1.4969	1.5581	1.1574	.1715	.1524	.1715	1.4089
3	1.4969	1.5746	1.1574	.1715	.1524	.1715	1.4089
4	1.5895	1.5746	1.1574	.1905	.1715	.1715	1.4918
5	2.0056	1.5912	1.3441	.2477	.2286	.2667	1.8233
6	2.4531	2.17	1.7976	.362	.381	.4191	2.4863
7	2.4366	2.4777	2.0809	.362	.3429	.3429	2.4034
8	.2477	.2286	.2096	.2286	.2477	.2286	.1905
9	.1715	.1715	1.6604	2.0481	1.8976	.1905	.1905
10	.1524	.1715	1.7869	2.13	1.9364	.1905	.1143
11	.1334	.1524	1.7869	2.13	1.7497		.0953
12	.1143	.1524	1.7236	2.0481	1.8122	.1905	.1143
13	.1143	.1143	1.704	1.8399	1.7966	.1143	.1334
14		.1334	1.7859	1.7404	1.7185	.0953	.1334
15		.1524	1.7204	1.9062	1.9134	.1143	
16	.0762	.1334	2.0317	.3315	2.0399	.1905	
17	.1334	.1524	.1143	.0953	.1334	.1905	
18	.1524	.1715	.1334	.1524	.1524	.1905	
19	.2096	.2858	.2477	.2096	.2286		
20	.3048	.3239	.3048	.2286	.2858	.2858	
21	.2286	.2858	.2477	.1715	.2477	.1905	
22	1.8947	1.6129	.2096	.1715	.2286	1.8233	
23	1.6842	1.4548	.1715	.1524	.1905	1.5746	
24	1.4969	1.5565	1.7869	.1715	.1524	.1715	1.4089
Max	2.4531	2.4777	2.0809	2.13	2.0399	1.8233	2.4863
Min	.0762	.1143	.1143	.0953	.1334	.0953	.0953
Avg	.9132	.8232	1.1488	.7263	.7630	.3389	.9875

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244114 / 33/11KV JIRGYAL

Feeder No / Name : 202 / 11 KV SHINGANAPUR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1715	.5468	.3277	.5079	.1905
2	.1715	.1715	.1715	.5468	.3315	.5079	.1905
3	.1715	.1715	.1715	.5468	.3315	.5079	.1905
4	.1905	.1905	.1715	.578	.3605	.5079	.1905
5	.2286	.2096	.2096	.6481	.4588	.4858	.1905
6	.2858	.2858	.3048	.8796	.6964	.6539	.2858
7	.3048	.2477	.2858	.8642	.8907	.8215	.381
8	.1905	.1715	.1715	.1715	.2286	.1905	.2858
9	.8097	.7125	.1905	.1334	.2477	.6554	.8097
10	.8029	.8097		.1143	.1524	.7373	.7935
11	.6964	.5535	.1334	.0953	.1524	.6554	.7125
12	.5735	.6964	.1334	.1715	.1524	.5735	
13	.5967	.7287	.1143	.1524	.1905	.5735	
14		.6562	.1334	.1334	.1905	.4915	
15		.8453	.1143	.1143	.1524	.5735	
16	.4858	.8619	.1143	.0953	.1905	.6554	
17	.1143	.1905	.1905	.1143	.1524	.1905	
18	.1143	.1143	.1334	.1334	.1524	.1905	
19	.2096	.2477	.1715		.2286		
20	.2667	.2858	.3048		.2858	.2858	
21	.2667	.2858	.2477		.2667	.2858	
22	.2096	.2096	.6562	.3605	.5256	.1905	
23	.1905	.1905	.578	.3887	.3605	.1905	
24	.1715	.1715	.1715	.5468	.3441	.5079	.1905
Max	.8097	.8619	.6562	.8796	.8907	.8215	.8097
Min	.1143	.1143	.1143	.0953	.1524	.1905	.1905
Avg	.3283	.3825	.2193	.3493	.3071	.4757	.3676

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244114 / 33/11KV JIRGYAL

Feeder No / Name : 203 / 11 KV JIRGYAL GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0953	.0953	.0762	.0953	.0953
2	.0953	.0762	.0953	.0953	.0762	.0953	.0953
3	.0953	.0762	.0953	.0953	.0762	.0953	.0953
4	.0953	.0953	.0953	.0953	.0953	.0953	.0953
5	.1143	.0953	.0953	.1143	.0953	.0953	.1334
6	.1524	.1143	.1334	.1524	.1143	.1334	.1334
7	.1524	.1143	.1715	.1143	.1143	.1143	.1905
8	.1143	.1143	.1143	.1143	.0953	.0953	.0953
9	.0572	.0762	.0953	.0572	.0953	.0762	.0762
10	.0572	.0762	.0762	.0572	.0762	.0572	.0381
11	.0381	.0572	.0572	.0572	.0762	.0572	.0572
12	.0572	.0762	.0572	.0953	.0762	.0953	.0762
13		.0762	.0762	.0762	.0762	.0953	.0762
14	.0572	.0572	.0572	.0381	.0572	.0572	.0381
15	.0572	.0381	.0381	.0381	.0572	.0572	
16	.0572	.0381	.0381	.0381	.0572	.0953	
17	.0762	.0572	.0953	.0572	.1143	.0953	
18	.0762	.1143	.1143	.0953	.0953	.1334	
19	.1524	.1715	.1334	.0572	.1715		
20	.1524	.1905	.2096	.0953	.1334	.1524	
21	.1334	.1524	.1715	.1143	.1524	.1524	
22	.0953	.1143	.1143	.0953	.1334	.1143	
23	.0953	.0953	.0953	.0762	.0953	.1905	
24	.0953	.0953	.0953	.0953	.0762	.0953	.0953
Max	.1524	.1905	.2096	.1524	.1715	.1905	.1905
Min	.0381	.0381	.0381	.0381	.0572	.0572	.0381
Avg	.0945	.0945	.1008	.0842	.0953	.1019	.0927

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244114 / 33/11KV JIRGYAL

Feeder No / Name : 204 / 11 KV EKUNDI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.2667	.3048	.4096	.3605	.3637	.2858
2	.2477	.2667	.3048	.4096	.3605	.3637	.2858
3	.2477	.2858	.3048	.4096	.3768	.3637	.2858
4	.2477	.3048	.362	.4096	.4096	.3953	.2858
5	.3239	.3429	.4191	.506	.4696	.4915	.2858
6	.4191	.4382	.4954	.7116	.7125	.639	.4763
7	.4572	.4382	.4382	.7432	.8097	.6706	.4763
8	.362	.362	.362	.362	.3048	.3429	.381
9	.6478	.5735	.2858	.3048	.2286	.4973	.663
10	.5735	.6167	.1905	.2096	.1715	.5801	.5801
11	.5344	.5487	.1715	.1334	.1524	.4973	.5636
12	.4752	.4694	.1143	.0953	.1334	.4973	
13	.4641	.4401	.1524	.1143	.0953	.4144	
14		.4108	.1143	.1143	.1334	.4144	
15		.5792	.1143	.0953	.1143	.4973	
16	.4858	.6562	.1143	.0762	.1334	.4973	
17	.1715	.1334	.1905	.1715	.1715	.1905	
18	.1905	.2096	.2096	.2477	.2096	.1905	
19	.3429	.362	.3429	.2858	.362		
20	.3429	.4382	.4001	.2858	.4001	.2858	
21	.2858	.3429	.381	.2477	.362	.2858	
22	.2477	.3239	.6554	.4858	.5506	.2858	
23	.2667	.3048	.5735	.3887	.4321	.2477	
24	.2477	.2667	.3048	.4096	.3768	.3795	.4763
Max	.6478	.6562	.6554	.7432	.8097	.6706	.663
Min	.1715	.1334	.1143	.0762	.0953	.1905	.2858
Avg	.3559	.3909	.3044	.3178	.3263	.4083	.4205

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 201 / 11 KV TIPPEHALLI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1029	.0857	.0857
2	.1029	.0857	.8916
3	.1029	.1029	.0857
4	.1029	.1029	.0857
5	.1372	.12	.9259
6	.2229	.1715	1.3717
7	.2058	.2058	1.3375
8	1.8861	.2058	.1543
9	1.3203	.1372	.1715
10		.12	.1715
11	1.6118	.1029	.1715
12	1.4575	.12	.1715
13		.1029	.1372
14	1.4232	.12	
15	.2572	.1029	.1372
16	1.1488	.1372	.1372
17	.12	.1543	.1886
18	.1372	.1372	.1543
19	.1543	.1543	.1543
20	.1543	.2058	.2058
21	.1543	1.1317	
22	.0686		.2915
23	.0857	1.0631	.9088
24	1.5604	.0857	.9602
Max	1.8861	1.1317	1.3717
Min	.0686	.0857	.0857
Avg	.5690	.2155	.4045

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 202 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.12	.2743	.2572
2	.1372	.2743	.2401
3	.1029	.2401	.1886
4	.1715	.2401	.2229
5	.1029	.2058	.2572
6	.1029	.2229	.2401
7	.1029	.2572	.2401
8	.1029	.2572	.1886
9	.12	.2058	.1543
10	.2058	.3429	.1715
11	.2058	.3944	
12	.2572	.4115	1.5089
13	.2058	.3601	.2229
14	.1543	.2572	.1715
15	.3258	.2743	.1372
16	.1543	.2229	.1029
17	.2229	.2572	.1029
18	.2572	.2572	.0857
19	.12	.3258	.1029
20	.3429	.3429	.1886
21	.3601	.3601	.2058
22	.2572	.4287	.2058
23	.2572	.3429	
24	.2229	.3258	.3258
Max	.3601	.4287	1.5089
Min	.1029	.2058	.0857
Avg	.1922	.2951	.2510

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 203 / 11 KV MALLAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.1543	.8745
2		.1543	.5144
3		.1543	1.406
4		.1715	
5		.1886	1.4746
6		.2058	2.3148
7		.2229	2.572
8		.1715	2.572
9		.1372	.1543
10		.1543	.1543
11		.1372	.1543
12		.1372	.1372
13		.1372	.1372
14		.1543	.1543
15		.1543	.1715
16		.1372	.1543
17		.1886	.1715
18		.1372	.1715
19		.2058	.2058
20		.2401	.2229
21		.2058	.2229
22		2.0405	1.9376
23		1.8176	1.6118
24	1.3717	.1715	.9774
Max	1.3717	2.0405	2.572
Min	1.3717	.1372	.1372
Avg	1.3717	.3158	.8029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 204 / 11 KV Jath

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.5604	1.6289
2			1.5261	1.6118
3			1.6461	1.5432
4			1.7833	1.5947
5			1.5947	1.6118
6			1.8519	1.7661
7			.1886	1.8347
8			1.6632	1.7661
9			1.406	1.5261
10		1.5604	1.5261	1.5089
11		1.5604	1.5604	.4115
12		1.4918	1.5604	.2229
13		1.5947	1.6975	.1886
14		1.5947	1.6975	1.749
15		1.6289	1.8004	1.749
16		1.6461	1.8176	1.6461
17		1.7147		1.6289
18		1.6804	1.8347	1.8347
19		2.1434	2.2119	
20		2.1776	2.2977	
21		2.0405	2.1948	
22		2.1434	2.0405	
23		1.7147	1.9547	
24	.8573		1.6632	
Max	.8573	2.1776	2.2977	1.8347
Min	.8573	1.4918	.1886	.1886
Avg	.8573	1.7637	1.6990	1.4346

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 205 / 11 KV Rampur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1317	1.3032	.1543
2		1.0288	1.2689	.1543
3		1.0631	1.2346	.1715
4		1.2003	1.2346	.1715
5		1.3717	1.2689	.1715
6		1.869	1.5604	.2058
7		2.0576	1.8861	.1886
8		2.0576	1.8861	.2229
9		.1543	1.8519	1.7318
10		.1029	2.2119	1.9033
11		.1029	2.0405	1.9033
12		.1029	2.0233	1.9033
13		.12	1.869	1.9033
14		.12	1.6975	1.9033
15		.12	1.7833	1.9033
16		.12	1.8861	2.1091
17		.1372	1.8861	.1543
18		.1372		.1543
19		.1543	.2229	.1543
20		.1886	.2058	.1886
21		.2058	.2229	.1715
22		1.4746	.1886	.1715
23		1.3717		.1543
24	1.3717	1.0631	1.3032	.1543
Max	1.3717	2.0576	2.2119	2.1091
Min	1.3717	.1029	.1886	.1543
Avg	1.3717	.7273	1.4107	.7502

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 206 / 11 KV Achakanhalli AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0857	.0857	.9088
2		.0857	.0857	.8573
3		.0857	.0857	.7888
4		.0857	.0857	.9088
5		.0857	.0857	.9602
6		.0857	.0857	1.9204
7		.0857	.0857	.5487
8		.0857	.0857	.5487
9		.0857	.0857	.0857
10		.0857	.0857	.0857
11		1.3546		.0857
12		1.6632	.0857	.0857
13		1.5775	.0857	.0857
14		1.4403	.0857	.0857
15		1.5604	.0857	.0857
16		.0857	.0857	.0857
17		.0857	.0857	.0857
18		.0857	.0857	.0857
19		.0857	.0857	.0857
20		.0857	.0857	.0857
21		.0857	.0857	
22		.0857	1.0974	.0857
23			.9602	.0857
24	1.3717	.0857	.0857	.9259
Max	1.3717	1.6632	1.0974	1.9204
Min	1.3717	.0857	.0857	.0857
Avg	1.3717	.3973	.1677	.4160

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 207 / 11 KV SUGAR FACTORY

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0857	.0857	.0857
2		.0857	.0857	.0857
3		.0857	.0857	.0857
4		.0857	.0857	.0857
5		.0857	.0857	.0857
6		.0857	.0857	.0857
7		.0857	.0857	.0857
8		.0857	.0857	.0857
9		.0857	.0857	.0857
10		.0857	.0857	.0857
11		.0857	.0857	.0857
12		.0857	.0857	.0857
13		.0857	.0857	.0857
14		.0857	.0857	.0857
15		.0857	.0857	.0857
16		.0857	.0857	.0857
17		.0857	.0857	.0857
18		.0857	.0857	.0857
19		.0857	.0857	.0857
20		.0857	.0857	.0857
21		.0857	.0857	.0857
22		.0857	.0857	.0857
23		.0857	.0857	.0857
24	.1086	.0857	.0857	.0857
Max	.1086	.0857	.0857	.0857
Min	.1086	.0857	.0857	.0857
Avg	.1086	.0857	.0857	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 208 / 11 kv Achakanhallii Gav

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857	.0857
2	.0857	.0857	.0857
3	.0857	.0857	.0857
4	.0857	.0857	.0857
5	.0857	.0857	.0857
6	.0857	.0857	.0857
7	.0857	.0857	.0857
8	.0857		.0857
9	.0857		.0857
10	.0857		.0857
11	.0857		.0857
12	.0857		.0857
13	.0857		.0857
14	.0857		.0857
15	.0857		
16	.0857		.0857
17	.0857		.0857
18	.0857		.0857
19	.0857		.0857
20	.0857		
21	.0857		.0857
22	.0857		.0857
23	.0857	.0857	.0857
24	.0857	.0857	.0857
Max	.0857	.0857	.0857
Min	.0857	.0857	.0857
Avg	.0857	.0857	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 201 / 11kv k mahankal

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0642	1.0242	1.0608	1.0166	.9145	1.0059	1.0456
2	1.0349	1.0059	1.0425	1.0608	.9145	1.0059	1.0082
3	1.0349	.9877	1.0059	1.0974	.8779	.9694	.9896
4	1.0534	.9328	1.0425	1.0791	.9511	1.0242	.9896
5	1.0719	1.0425	1.0425	1.0985	.9511	1.0608	1.0082
6	1.1273	1.1523	1.1157	1.2071	.9877	1.1706	1.0269
7	1.2136	1.134	1.0974	1.0791	.9877	1.1157	1.0829
8	1.1016	.9328	.9694	.8962		.9511	.9709
9	.8962	.9694	1.0242	.9328	1.1157	.8779	1.0082
10	1.1157	1.0974	1.134	1.0791	1.0974	1.0059	
11	1.0974	1.2254	1.134	1.1523	1.0608	.9877	
12	1.2437	1.2254	1.2254	1.134	.9877	1.0059	
13		1.1888	1.2567	1.0974	.9694	1.0059	
14	1.1888	1.1888	1.1706	1.0791	.9328	1.0791	
15	1.2071	1.0974	1.134	1.0791	.8962	1.1706	
16	1.134	1.134	1.134	1.0974	.8413	1.0608	
17	1.134	1.0242	1.0242		.8413	1.0608	
18		1.262	1.2986		.9328	1.1706	
19	1.4449	1.4449	1.4969		1.2437	1.4083	
20	1.4815	1.5546	1.4198	1.2803	1.3717	1.4449	
21	1.4083	1.39	1.3146	1.262	1.3717	1.3535	
22	1.2437	1.2254	1.1919	1.1523	1.262	1.1706	
23	1.1157	1.1523	1.1043	1.0059	1.1523	1.1157	
24	1.0829	1.0425	1.0974	1.0517	.9694	1.0608	1.0829
Max	1.4815	1.5546	1.4969	1.2803	1.3717	1.4449	1.0829
Min	.8962	.9328	.9694	.8962	.8413	.8779	.9709
Avg	1.1589	1.1431	1.1474	1.0923	1.0274	1.0951	1.0213

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 202 / 11KV KUCHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.3101	2.0144	.1848	.1578	.1227	1.6827
2	2.4086	2.2916	1.9959	.1867	.1402	.1227	1.6651
3	2.3228	2.2916	2.0144	.2054	.1402	.1052	1.6301
4	2.3594	2.2546	2.0328	.1886	.1578	.1402	1.6827
5	2.396	2.2731	2.0883	.2054	.1578	.1753	1.7353
6	2.4143	2.3101	2.1253	.2218	.1928	.2103	1.858
7	2.5423	2.5873	2.2177	.1848	.1928	.2103	2.1735
8	.1478	.1848	.2033	.2218		.1578	.1753
9	.1478	.1848	2.4209	2.6797	.1928	.1753	.1753
10	.1478	.1478		2.6612	.1578	.1578	
11	.2033	.1663	.7392	2.7166	.1227	.1753	
12	.2033	.2033	2.8829	2.3655	.2103	.1402	
13	.1848	.2033	2.9938	2.4025	.1578	.1578	
14	.1478	.2033	2.9569	2.5503	2.2786	.1753	
15		.2033	2.8829	2.6612	2.0858	.1227	
16	.1848	.1848	2.5318		1.7177	.1578	
17	.2033	.2012	2.3101	2.7721	.1227	.1753	
18		.1848	.168		.1402	.1753	
19	.2218	.2587	.2218		.1753	.2103	
20	.2587	.2587	.2402		.2279	.2454	
21	.2402	.2218	.2402	.1848	.1928	.2454	
22	2.4579	2.1437	.2218	.1753	.1928	1.9456	
23	2.3655	2.0513	.1848	.1753	.1402	1.7528	
24	2.3899	2.3285	2.0328	.1848	.1578	.1402	1.7177
Max	2.5423	2.5873	2.9938	2.7721	2.2786	1.9456	2.1735
Min	.1478	.1478	.168	.1753	.1227	.1052	.1753
Avg	1.1404	1.0687	1.6400	1.1564	.4092	.3082	1.4496

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 203 / 11 KV HINGANGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3856	.4031	.4031	2.3211	.3856	1.5775	.3856
2	.3681	.3856	.4031	2.268	.3856	1.5775	.3506
3	.3681	.3681	.3856	2.3034	.3506	1.5424	.3506
4	.3721	.4031	.3856	2.3388	.4031	1.4899	.3681
5	.3898	.4382	.4207	2.3034	.4207	1.4899	.4382
6	.4557	.4733	.5083	2.4983	.4557	1.4723	.4908
7	.4733	.5434	.5083		.4557	1.6126	.4733
8	.4207	.4908	.3696	.4252		.3856	.4908
9	2.6818	2.1559	.4207	.4382	.4207	2.1384	2.6292
10	2.8746	3.0323		.4207	.4382	2.191	
11	2.5941	2.8045		.4557	.4031	2.3838	
12	2.6467	2.8921		.4733	.4733	2.1209	
13	2.524	2.857		.4557	.4031	2.1735	
14	1.9281	2.6467		.4733	.4031	2.2786	
15		3.0148		.4733	.3856	2.4013	
16	2.1735	2.4364		.4733	.4382	2.3487	
17	.4382	.4207			1.0341	.4031	
18		.4733			.4207	.4382	
19	.4908	.5609	.4207		.4382	.4908	
20	.5258	.5434	.5609		.4908	.5083	
21	.4908	.5258	.5258	.4031	.4908	.5083	
22	.4557	.4733	2.2611	.3856	1.6651	.4557	
23	.4382	.4733	2.3663	.4031	1.6126	.4382	
24	.4031	.4207	.4382	2.3137	.3856	1.6126	.4031
Max	2.8746	3.0323	2.3663	2.4983	1.6651	2.4013	2.6292
Min	.3681	.3681	.3696	.3856	.3506	.3856	.3506
Avg	1.0863	1.2182	.6919	1.1383	.5548	1.4183	.6380

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 204 / 11KV Ranjani Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5912	1.7187	1.46	.2587	.1478	.2402	1.3306
2	1.6057	1.7002	1.4415	.2402	.1294	.2218	1.2936
3	1.6617	1.7002	1.4415	.2402	.1294	.1848	1.2936
4	1.6244	1.6632	1.4784	.2218	.1663	.2587	1.4415
5	2.0485	2.0144	1.6078	.2957	.2218	.3142	1.7002
6	2.3411	2.1807	1.8296	.4066	.3696	.3696	1.9035
7	2.396	2.2916	1.8665	.2957	.3696	.2587	2.3101
8	.2402	.2587	.5359	.2614		.2033	.2402
9	.1848	.2587	1.9774	2.3101	.2402	.2033	.2033
10	.1848	.1663	2.1559	2.5688	.1663	.1663	
11	.2218	.2033	2.191	2.4579	.1848	.1478	
12	.1663	.1848	2.2731	2.3285	.1848	.1478	
13	.2587	.1848	2.0698	2.2177	.2033	.1848	
14	.1848	.2402	2.1098	2.1807	2.2916	.1848	
15		.2033	2.0698	1.9959	2.3101	.2218	
16	.2402	.2218	1.9404	1.7002	1.848	.2218	
17	.2402	.2218	.2402		.2587	.2033	
18		.2587	.2402		.2218	.2772	
19	.3881	.3696	.3475		.3326	.3326	
20	.4251	.3881	.4066		.4435	.3511	
21	.3696	.462	.3326	.2218	.4435	.3326	
22	1.922	1.6632	.2587	.1848	.3326	1.7372	
23	1.7741	1.4969	.2218	.1848	.2957	1.386	
24	1.5912	1.7372	1.4784	1.0059	.1663	.2587	1.3491
Max	2.396	2.2916	2.2731	2.5688	2.3101	1.7372	2.3101
Min	.1663	.1663	.2218	.1848	.1294	.1478	.2033
Avg	.9846	.9079	1.3323	1.0789	.4982	.3504	1.3066

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 205 / 11KV Langerpeth Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.2033	.1663	2.9938	.112	2.2779	.1494
2	.2241	.1848	.1663	2.9938	.112	2.2405	.1307
3	.2427	.1663	.1478	3.0678	.0934	2.2032	.1307
4	.2218	.1848	.1478	3.0247	.1307	2.2405	.168
5	.2587	.2218	.2218	3.2114	.2054	2.2592	.2054
6	.2957	.2957	.3326	3.4743	.3361	2.2592	.2614
7	.2772	.3326	.2957	3.1971	.3361	2.4086	.2614
8	.2033	.2772	.2402	.1867		.1867	.1867
9	3.1047	3.3819	.1848	.1494	.168	2.2779	2.8753
10	3.3265	3.4743	.1753	.168	.168	2.782	
11	3.345	3.1786	.1578	.1867	.168	2.8193	
12	2.9569	3.2341	.1663	.1867	.1307	2.8006	
13	3.1047	3.1971	.1646	.1867	.112	2.5206	
14	2.0328	3.4743	.1463	.168	.1867	2.2032	
15		3.3819	.1463	.168	.1307	2.0538	
16	2.7351	3.1047	.1829	.1494	.1867	2.3712	
17	.1478	.3326	.2402		1.4003	.168	
18		.1848	.2561		.2241	.2054	
19	.2957	.3142	.3326		.2801	.3174	
20	.3881	.3142	.3326	.168	.2987	.2987	
21	.3696	.2772	2.846	.168	.2987	.2614	
22	.2587	.2218	2.846	.1494	2.4086	.2054	
23	.2402	.2218	3.0678	.1307	2.3152	.1867	
24	.2402	.2218	.1848	3.0308	.1307	2.2779	.168
Max	3.345	3.4743	3.0678	3.4743	2.4086	2.8193	2.8753
Min	.1478	.1663	.1463	.1307	.0934	.168	.1307
Avg	1.1132	1.2659	.5479	1.2933	.4319	1.6594	.4537

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 206 / 11KV S.Factory Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.2156	3.1367	2.4272	.2926	.2054	.2054	2.5415
2	3.1786	3.0994	2.3899	.2987	.1867	.1867	2.5065
3	3.2861	3.0807	2.3899	.3174	.1867	.168	2.4539
4	3.2487	3.062	2.4272	.3109	.2427	.2427	2.4539
5	3.3234	3.1741	2.5579	.3292	.3174	.2801	2.6467
6	3.345	3.2861	2.7073	.4108	.3361	.3361	2.9447
7	2.4459	3.0247	2.6886	.3734	.3361	.3174	2.9622
8	.3547	.3734	.3361	.3547		.2241	.3506
9	.3361	.3174	3.2114	3.5288	.2054	.2241	.3506
10	.2801	.2987		3.4355	.3174	.2054	
11	.3174	.2801		3.3608	.2987	.1307	
12	.3361	.2801	3.3981	3.5475	.3174	.168	
13	.2987	.2614	3.1741	3.4541	.2801	.1578	
14	.2054	.2614	3.0807	3.3234	3.0247	.1578	
15		.3361	3.2114	3.0434	3.3608	.1753	
16	.3174	.3174	1.885	3.006	3.062	.1928	
17	.2987	.2801	2.1253		.2054	.1753	
18		.3361	.3292		.2987	.1227	
19	.4481	.5415	.4854		.2801	.298	
20	.4668	.4854	.5093	.2614	.3547	.3155	
21	.4294	.4294	.4572	.2801	.3547	.298	
22	3.2301	2.6886	.3772	.2427	.2987	2.489	
23	3.1741	2.5393	.3086	.2427	.2427	2.6116	
24	3.1786	3.1554	2.4832	.3109	.2241	.2241	2.5766
Max	3.345	3.2861	3.3981	3.5475	3.3608	2.6116	2.9622
Min	.2054	.2614	.3086	.2427	.1867	.1227	.3506
Avg	1.6234	1.4602	1.9527	1.4631	.6494	.4128	2.1787

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 207 / 11 KV Express MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0876	.0886	.0886	.1052	.0526	.0526	.0701
2	.0709	.0709	.0886	.0876	.0526	.0526	.0701
3	.0709	.0709	.0886	.0886	.0526	.0526	.0701
4	.0701	.0532	.0886	.0709	.0526	.0351	.0701
5	.0701	.0532	.0886	.0701	.0526	.0351	.0701
6	.0701	.0532	.0886	.0709	.0351	.0701	.0701
7	.0347	.0532	.1063	.0701	.0351	.0701	.0526
8	.0526	.0709	.0886	.0876		.0526	.0876
9	.0701	.0709	.0886	.0876	.0876	.0701	.0701
10	.1227	.1949	.1052	.1578	.0876	.1578	
11	.1227	.2126	.1402	.1753	.1402	.1052	
12	.1227	.1595	.1402	.1227	.1052	.1227	
13	.1402	.1595	.0876	.1052	.0876	.1052	
14	.124	.1417	.0876	.0876	.0526	.0701	
15	.0532	.124	.0876	.0876	.0526	.0701	
16	.0709	.124	.0876	.1227	.0526	.0876	
17	.124	.0709	.1578		.0526	.0526	
18		.0886	.0876		.0526	.0526	
19	.0532	.0886	.1052		.0701	.0701	
20	.0709	.0886	.0876	.0701	.0701	.0701	
21	.0709	.124	.0876	.0526	.0701	.0701	
22	.1417	.124	.0876	.0701	.1052	.1052	
23	.124	.1063	.1227	.0526	.0876	.1052	
24	.0876	.0886	.0886	.1052	.0526	.0876	.0876
Max	.1417	.2126	.1578	.1753	.1402	.1578	.0876
Min	.0347	.0532	.0876	.0526	.0351	.0351	.0526
Avg	.0881	.1034	.0990	.0928	.0678	.0760	.0719

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 208 / 11KV Langerpeth Gao

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3681	.3155	.2629	.298		.3155	.2629
2	.3856	.2804	.2454	.2804		.2804	.2454
3	.3681	.2629	.2454	.2804		.2279	.2454
4	.4031	.2279	.2804	.2835		.3155	.2804
5	.3856	.298	.3155	.3189		.3506	.3155
6	.4207	.4207	.333	.3856		.3856	.3506
7	.3681	.4207	.333	.4031		.3856	.3856
8	.2804	.3506	.2454	.298		.298	.298
9	.3506	.2804	.298	.298		.3734	.333
10	.3155	.2629	.298	.3155		.1402	
11	.2804	.298	.333	.298	.1227	.1578	
12	.2629	.3155	.3155	.2103	.2103	.1578	
13		.298	.2804	.1928	.1578	.1578	
14	.1753	.2629	.2804	.1753	.1928	.2454	
15	.2279	.2454	.2804	.1753	.2103	.2279	
16	.2103	.2103		.1402	.1052	.1928	
17	.2629	.2279	.3155		.2629	.2279	
18		.2629	.333		.3506	.2454	
19	.4207	.4382	.5083		.4733	.4207	
20	.5083	.4908	.5258		.5609	.4382	
21	.4557	.4382	.5258		.5258	.4382	
22	.4207	.3681	.3856		.4557	.4207	
23	.3856	.3155	.3155		.3506	.333	
24	.3681	.3506	.298	.298		.3155	.298
Max	.5083	.4908	.5258	.4031	.5609	.4382	.3856
Min	.1753	.2103	.2454	.1402	.1052	.1402	.2454
Avg	.3466	.3184	.3284	.2736	.3061	.2938	.3015

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 202 / 11KV Shirdhon Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4835	.3761	.1865	4.1213	1.7802	1.9894	.3953
2	.466	.3894	.1696	4.1126	.8383	1.9827	.3677
3	.4863	.3913	.1715	3.9674	1.6706	1.9471	.3934
4	.4802	.3746	.1734	3.924	2.2666	1.9319	.4054
5	.5007	.4397	.1907	3.9971	.9313	1.9753	.4214
6	.5251	.5201	.2149	4.4483	1.9262	2.292	.4473
7	.6353	.6215	.2623	5.4291	2.447	2.9718	.4538
8	.6569	.6075	.2303	.3677	.1821	.3813	.5764
9	5.7405	6.2886	.2658	.3731		.0015	5.6181
10	6.1726	6.6111	.2012	.3963		2.2604	6.3892
11	5.7267	5.8048	.2254	.4077		2.7092	5.8842
12	5.7221	4.7561	.2058	.3719			1.2559
13	4.2433	5.8528	.2012	.4398		3.7319	.3948
14	2.8779	6.0776	.208	.4652	.3799	5.5133	.5871
15	2.8243	6.2178	.1791	.5708	.4168	3.091	.5216
16	3.7085	6.0252	.2195	.3216	.4138	4.4795	3.7635
17	.0815	.4041	.2534	.3246	.3792	.4389	.2035
18		.4549	.1524		.4511	.4157	.359
19	.5137	.5091	.1907		.5474	.4912	.4679
20	.5384	.5365	.2686	.2058	.527	.5434	.5272
21	.4645	.502	.2534	.2378	.5765	.532	.5317
22	.4778	.2515	2.1971	.7865	3.014	.4626	.3894
23	.4264	.3735	2.1262	1.7303	3.1642	.4451	.3307
24	.4447	.3795	.1823	2.9401	2.037	1.2488	.3581
Max	6.1726	6.6111	2.1971	5.4291	3.1642	5.5133	6.3892
Min	.0815	.2515	.1524	.2058	.1821	.0015	.2035
Avg	1.9216	2.2819	.3721	1.8154	1.2605	1.8190	1.2934

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 203 / 11KV Borgaon Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3178	.3536	.1698	.3679	.3506	.3263	.3391
2	.3155	.3498	.1698	.3468	.1882	.324	.3157
3	.314	.3573	.1509	.346	.3368	.3399	.3141
4	.3517	.3353	.1734	.3445	.3361	.3218	.3353
5	.4054	.3611	.1886	.3733	.3799	.3233	.3573
6	.4542	.4167	.2263	.4656	.4942	.4027	.4201
7	.4985	.4641	.2218	.4203	.4748	.4084	.4115
8	.4005	.3443	.181	.3392	.2469	.3288	.3586
9	.4435	.3768	.2378	.386		.3544	.3822
10	.4178	.3791	.2195	.4148		.3891	.3795
11	.3805	.4194	.2561	.3768		.3696	.4321
12	.3647	.4892	.2926	.4058		.3874	.4588
13	.3852	.478	.2263	.486		.4047	.2347
14	.3898	.4085	.2263	.451	.5013	.3725	.2378
15	.3695	.4207	.2195	.3913	.4809	.3772	.2233
16	.3449	.4565	.2218	.1829	.4079	.3841	.2309
17	.3151	.3734	.2507	.1981	.3637	.3327	.1898
18	.3675	.4451	.2374	.2317	.3563	.4462	.1989
19	.5096	.5538	.2865	.2599	.2446	.4482	.2256
20	.6318	.6059	.362	.2743	.631	.602	.3079
21	.6116	.6097	.3174	.2713	.6289	.559	.3102
22	.4948	.543	.2641	.2606	.4915	.5678	.2637
23	.4137	.4218	.2263	.4271	.422	.4415	.2362
24	.362	.3679	.1886	.6223	.3567	.3294	.3702
Max	.6318	.6097	.362	.6223	.631	.602	.4588
Min	.314	.3353	.1509	.1829	.1882	.3218	.1898
Avg	.4108	.4305	.2298	.3601	.4049	.3975	.3139

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 204 / 11KV Borgaon Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5464	.5096	.2075	4.5351	2.9319	3.6565	.4747
2	.5411	.4877	.1886	4.4307	1.3306	3.4427	.4664
3	.5626	.4824	.1867	4.3119	2.778	3.2596	.4784
4	.5649	.5043	.2241	4.2913	2.5783	3.158	.5161
5	.5906	.5687	.2263	4.3805	2.6355	3.174	.5518
6	.615	.6643	.2452	4.8293	1.6312	3.4896	.6436
7	.6249	.7083	.3395	5.6851	3.9175	3.8287	.5809
8	.6859	.618	.3206	.5759	.253	.3837	.6753
9	6.6423	7.1758	.3018	.6973		5.2397	6.9307
10	7.4221	7.3735	.3018	.711		5.6545	4.3354
11	6.7725	7.2902	.3584	.7339		6.0586	6.6168
12	6.7935	7.4958	.3584	.7065		6.0129	3.4354
13	6.8023	7.3914	.3584	.7251		5.5292	.2484
14	4.3427	7.417	.3584	.8025	.644	5.7567	.2736
15	3.3882	7.5111	.3395	.7171	.6413	6.0968	.2827
16	6.0395	6.3874	.3395	.3711	.5956	6.0228	2.8883
17	.4975	.2484	.3584	.3003	.642	.5914	.3018
18	.7095	.3811	.3109	.2652	.7281	.5449	.3521
19	.7666	.6359	.3734	.2553	.3338	.6112	.3178
20	.812	.652	.3584	.2904	.5712	.7392	.3612
21	.7425	.6409	.3395	.2873	.6154	.7296	.3567
22	.6562	.5506	2.5941	1.6369	3.8731	.644	.3536
23	.5923	.4824	2.4539	3.0581	3.8966	.5522	.3086
24	.5373	.495	.2075	3.8699	3.2885	2.0317	.301
Max	7.4221	7.5111	2.5941	5.6851	3.9175	6.0968	6.9307
Min	.4975	.2484	.1867	.2553	.253	.3837	.2484
Avg	2.4270	2.7780	.4855	2.0195	1.7835	3.2170	1.3355

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 205 / 11KV Shivganga Gao
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2267	.3801	.3582	.3761	.0554	.3366	.3721
2	.2267	.3658	.2507	.3582		.3189	.3224
3	.2743	.3841	.2835	.362	.0549	.3366	.3582
4	.2743	.3841	.2835	.3801	.0549	.3366	.3801
5	.3189	.362	.2835	.3841	.0549	.3366	.3761
6	.3366	.3982	.2835	.4024	.0549	.3582	.3544
7	.1698	.1509	.1829	.1886	.0532	.3467	.1337
8	.0869	.0937	.1097	.1355		.1204	.1492
9	.1389	.1219	.128	.141		.1124	.1158
10	.2155	.1353	.1696	.1677		.2006	.1406
11	.176	.1581	.1867	.1677		.2286	.1183
12	.1852	.1852	.2439	.1677		.2006	.128
13		.1252	.1844	.2012		.1286	
14	.1315	.1947	.218	.2012	.2629	.1437	
15	.1509	.208	.208	.1619	.2804	.1875	
16	.1149	.1844	.2254		.2315	.153	
17	.1823	.1238	.2035		.2534	.1966	
18	.3439	.3366	.1492		.181	.1217	
19	.3292	.362	.1475		.1991	.2896	
20	.4251	.3403	.1907		.439	.4572	
21	.3142	.3361	.1989		.2926	.4207	
22	.4163	.3841	.3881		.362	.4163	
23	.4024	.2033	.3841		.1718	.394	
24	.2267	.3982	.3898	.3366	.0554	.3366	.4075
Max	.4251	.3982	.3898	.4024	.439	.4572	.4075
Min	.0869	.0937	.1097	.1355	.0532	.1124	.1158
Avg	.2464	.2632	.2355	.2583	.1798	.2699	.2582

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 206 / 11KV Shirdhon Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.2241	.2033	.2054		.2218	.2218
2	.1478	.2075	.1867	.1867		.2427	.1829
3	.1478	.2075	.2054	.1886		.2241	.2149
4	.1848	.2241	.2241	.1886		.2103	.2561
5	.1848	.2241	.2614	.2075		.1867	.2561
6	.1848	.2772	.2801	.2641		.2614	.2772
7	.1991	.197	.2629	.2561		.2328	.2561
8	.1715	.1772	.2481	.2254		.2279	.2347
9	.1772	.1791	.2229	.2374		.1886	.1907
10	.2279	.1612	.218	.1509		.2155	.1677
11	.208	.1886	.2683	.1509		.1781	.2012
12	.2515	.2229	.2652	.1509			.1823
13	.2347	.2774	.2883	.2012		.2572	
14	.2629	.2804	.2572	.218	.3258	.2454	
15	.2303	.2658	.2427	.2035	.2713	.2454	
16	.2303		.2427		.2515	.2279	
17		.2486	.2454		.2622	.2058	
18		.2629	.2543		.2743	.208	
19	.4344	.362	.3224		.3012	.3403	
20	.4207	.4024	.4163		.4344	.5487	
21	.4024	.3881	.3696		.3841	.3658	
22	.3292	.3142	.3511		.2957	.3109	
23	.2587	.2587	.2801	.0549	.2743	.2587	
24	.1478	.2241	.2218	.2241		.2218	.2587
Max	.4344	.4024	.4163	.2641	.4344	.5487	.2772
Min	.1478	.1612	.1867	.0549	.2515	.1781	.1677
Avg	.2357	.2511	.2641	.1950	.3075	.2533	.2231

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 207 / 11KV Alkud Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0467	.9602	.9282	.1698	.132	.1698	.9488
2	1.0467	.9602	.8962	.1698		.1886	.9282
3	1.1174	.9282	.9339	.1698	.1494	.1698	.9922
4	1.1822	.9122	.9667	.1886	.1494	.1886	1.1142
5	1.2289	.9122	1.004	.2263	.2054	.2075	1.2125
6	1.2944	1.2146	1.085	.3018	.2801	.2829	1.3763
7	1.4899	1.6518	1.3603	.3018	.2641	.2641	1.6549
8	.2033	.2241	.2614	.2427		.1867	.2218
9	.132	.1867	1.491	1.5565		.1886	.168
10	.132	.1494	1.5203	1.5061		.1494	.1478
11	.112	.1307	1.5384	1.4575		.1848	.1063
12	.1109	.1307	1.3927	1.3279		.1646	.1052
13	.1433	.1109	1.4083	1.3603		.1294	
14	.1494	.112	1.3123	1.3603	.3812	.1109	
15	.168	.132	1.3279	1.2018	1.085	.128	
16	.1698	.1307	1.3279		1.4575	.1494	
17	.1867	.1294	.1109		1.3443	.1646	
18	.1848	.168	.1463		.1478		
19	.2427	.2641	.2054		.2218	.1867	
20	.2641	.2452	.2641		.2829	.2829	
21	.2075	.2263	.2452		.2452	.2263	
22	1.3117	1.1498	.2263		.2075	1.2616	
23	1.1336	1.0402	.2075	.132	.1886	1.0082	
24	1.0467	1.0242	.9172	.1886	.132	.1698	.953
Max	1.4899	1.6518	1.5384	1.5565	1.4575	1.2616	1.6549
Min	.1109	.1109	.1109	.132	.132	.1109	.1052
Avg	.5960	.5456	.8782	.6977	.4044	.2680	.7638

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 201 / 11Kv Dudhebhavi
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6685	2.3198	.9945	.2035	.1677	.218	1.2431
2	2.561	2.1542	.9614	.218	.1509		1.6244
3	2.5171	1.9647	.9724	.2035	.1357	.2012	1.4586
4	2.3693	1.9563	1.0059	.1844	.1357	.2012	
5	2.5172	2.0999	1.0174	.2204	.1341	.2155	
6	3.1167	3.1138	1.0774	.2515	.1677	.2321	
7	4.4166	4.0139	1.2431	.2713	.1677	.2347	
8	.4611	.6181					
9	.4943	.4938	1.3413	1.4251		.2012	
10	.4554	.4702	1.4083	1.3413		.1677	.1677
11	.434	.4123	1.4754	1.4918		.2012	
12	.4304	.4405	1.0059			.1677	.1677
13	.4611	.423	1.1869		1.6766	.1677	
14	.4672	.3773	1.5089		1.5089	.1677	
15	.4152	.3826	1.5261		1.4083	.1677	
16	.422	.3429	1.5089		1.4083	.1341	
17	.5205	.484	.2035	.1677	1.1736	.1341	
18	.5617	.5396	.2035	.2012	.8383		
19	.5687	.5769	.2374	.1677	.2347		
20	.676	.6326	.2347	.1677	.2515		
21	.66	.6386	.2543	.1677	.2515		
22	2.8895	2.4333		.1677			1.0059
23	2.7149	2.3853	.2035	.1696			1.0174
24	2.7161	2.2634	1.0562	.1844	.1677	.218	1.1736
Max	4.4166	4.0139	1.5261	1.4918	1.6766	.2347	1.6244
Min	.4152	.3429	.2035	.1677	.1341	.1341	.1677
Avg	1.4798	1.3140	.9376	.4003	.5870	.1894	.9823

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 202 / 11KV Nagaj

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4694	.4294	.4024	1.3565		.6036	.6464
2	.4748	.3856	.3812	1.4413			.6539
3	.503		.3812	1.4251		.6036	.5197
4	.4748	.3978	.4024	1.3565		.6036	
5	.5365	.431	.3239	1.2574		.7209	
6	.5868	.4862	.4641	1.4413		.8383	
7	.6706	.5365	.4973	1.5089		.9221	
8	.5868	.4527	.4694				
9	1.1142	1.6766	.3688	.3521		1.0059	
10	1.4754		.3688	.3391		.9221	1.291
11	1.1736	1.5089	.3521	.39		.8383	
12	1.0774	1.3413	.373			1.0059	
13	.8619	1.3413	.3521		.7545	.8383	
14	.6299	1.5089	.373		.8383	.8383	
15		1.3413	.373		.7545	1.0059	
16	1.2929	1.1736	.3561		.7545	1.0059	
17	.3521	.3315	.4191		.7042	.5197	
18	.3688	.3647	.5087		.6706	.5365	
19	.4748	.4527	.503		.6371	.5533	
20	.503	.4973	.4748		.6706		
21	.4475	.4862	.4409		.5868		
22	.431	.4359					.4409
23	.4144	.4191	1.5089				.4024
24	.5087	.3978	.4191	1.2717		.6371	.5197
Max	1.4754	1.6766	1.5089	1.5089	.8383	1.0059	1.291
Min	.3521	.3315	.3239	.3391	.5868	.5197	.4024
Avg	.6708	.7453	.4571	1.1036	.7079	.7777	.6391

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 203 / 11KV Chorochi
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1844	.1989	.1989	1.0059		.4973	.1677
2	.1696	.1989	.1844	1.1869			.1823
3	.1844	.1989	.1844	1.0059		.4973	.1677
4	.1696	.2012	.1989	1.0174		.4973	
5	.1844	.2012	.218	1.3413		.503	
6	.2035	.2155	.2321	1.5261		.5304	
7	.2683	.2321	.2321	1.3413		.5801	
8	.2347	.218	.218				
9	.7545	1.0059	.2012	.1677		.6706	
10	.7459	1.0059	.2012	.1823		.6706	.8383
11	.7459	.8383	.2012	.1677		.5868	
12	.7127	.8383	.2204			.6706	
13	.7127		.2347		.8383	.6706	
14	.503	.9221	.2374			.5868	
15		1.0059	.218			.5868	
16	.4973	1.0898	.218			.6706	
17	.1989	.218				.1844	
18	.2155	.218	.2543		.3018	.1823	
19	.2347	.2321	.2347		.2347		
20	.2347	.2321	.2035		.2515		
21	.218	.2347	.2012		.2515		
22	.1989	.218					.2012
23	.1989	.1989	.7545				.2035
24	.2035	.218	.1989	.8383		.5365	.1696
Max	.7545	1.0898	.7545	1.5261	.8383	.6706	.8383
Min	.1696	.1989	.1844	.1677	.2347	.1823	.1677
Avg	.3467	.4409	.2385	.8892	.3756	.5366	.2758

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 204 / 11KV Chorochi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5089	1.6766	1.4918	.3688	.1006	.3688	1.1736
2	1.6108	1.6766	1.5089	.373	.1006		1.2574
3	1.5089	.3978	1.4754	.3561	.1017	.3521	1.4251
4	1.5261	1.7404	1.4754	.3688	.1017	.3521	
5	1.8442	1.8442	1.5089	.3561	.1677	.3812	
6	1.8652	2.0119	1.8442	.4024	.2012	.431	
7	2.0119	2.3472	2.0454	.407	.2012	.4359	
8	.4694	.4191	.4359				
9	.3688	.3353	2.3205	2.4863		.2347	
10	.3561	.3353	2.3205	2.3472		.2012	.1677
11	.3521	.2515	2.5149	2.42		.1677	
12	.3353	.2515	2.1795			.1677	.1677
13	.2683	.2012	2.3739		1.0059	.2012	
14	.1677	.1677	2.3472		1.3413	.2012	
15	.2515	.1677	2.0348		1.5089	.2012	
16	.2515	.1677	2.2043		1.2955		
17	.3688	.3185	.3353		1.4083	.2347	
18	.4191	.3856	.373		1.2574	.2515	
19	.4694	.4973	.407		.4152	.2515	
20	.503	.4694	.4359	.1006	.4359		
21	.431	.3647	.4409	.1006	.4024		
22	1.8442	1.6766		.1006			1.1736
23	1.8233	1.6766	.373				1.3565
24	1.3413	1.7604	1.6244	.3521	.1006	.39	1.1736
Max	2.0119	2.3472	2.5149	2.4863	1.5089	.4359	1.4251
Min	.1677	.1677	.3353	.1006	.1006	.1677	.1677
Avg	.9124	.8809	1.4813	.7528	.5968	.2837	.9869

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 205 / 11KV Nagaj Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1907	.1907	.1734	.208	.0857
2	.1715	.208	.1715	.1907	.0857
3	.1907	.2058	.1715	.1886	.0857
4	.1734	.2103	.1734	.1734	.0857
5	.1907	.2103	.1928	.1886	.1387
6	.2229	.2427	.2254	.2058	.1372
7	.2058	.2601	.2601	.2427	.1372
8	.1907	.1886	.1886		
9	.1715	.1715	.1734	.218	
10	.1734	.1715	.2058	.1886	
11	.1715	.2058	.2229	.208	
12			.2058		
13			.1907		
14		.1715	.2058		
15	.1715	.2058	.1886		
16	.2229	.2058	.1734		
17	.2774	.2254	.208		
18	.3121	.2601	.2743	.0686	
19	.333	.2947	.3086		
20	.3506	.3258	.3086		
21	.3121	.3258	.2743		
22	.2774	.2743	.2743		
23	.2427	.2401	.2058		
24	.1734	.2058	.2103	.1734	.0857
Max	.3506	.3258	.3086	.2427	.1387
Min	.1715	.1715	.1715	.0686	.0857
Avg	.2250	.2273	.2161	.1879	.1052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 206 / 11 KV Dudhebhavi Gao

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2254	.2254	.2229	.2947	.208	.6135	.6001
2	.208	.2254	.208	.2947	.1715		.6588
3	.1886	.2279	.208	.2572	.1715	.6135	.6001
4	.2427	.2279	.2279	.2572	.1715	.5895	
5	.3121	.2658	.2401	.3121	.1734	.6485	
6	.3601	.3155	.2947	.3086	.2743	.6935	
7	.3772	.3155	.3086	.3086	.3429	.6588	
8	.3467	.2427	.208				
9	.2915	.2058	.2058	.3772		.5144	
10	.2601	.1715	.2229	.3944		.5144	.3467
11	.1372	.1715	.1886	.3944		.5144	
12	.12	.1715	.2229			.583	.4801
13	.2229	.1715				.5144	
14	.2058	.1715	.2058		.5375	.6001	
15	.2229	.1715	.2229		.5609	.6001	
16	.208	.2572	.2572		.5609	.503	
17	.2804	.2947	.2601	.2572	.6068	.703	
18	.3294	.333	.2947	.2401	.6588	.663	
19	.4031	.4161	.3086	.2058	.7716	.6539	
20	.2789	.4161	.4115	.2401	.8745		
21	.3429	.3772	.3772	.2743	.7802		
22	.3121	.2743		.2743			.7975
23	.2601	.2601	.3601	.1006			.6001
24	.2774	.2454	.2254	.3467	.2058	.6588	.6001
Max	.4031	.4161	.4115	.3944	.8745	.703	.7975
Min	.12	.1715	.1886	.1006	.1715	.503	.3467
Avg	.2672	.2565	.2583	.2855	.4419	.6022	.5854

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 201 / 11KV Shelkewadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0745	2.8266	.9831	.2772	.1791	.2402	.9922
2	3.0402	1.4579	.9831	.2402	.1791	.2402	1.0082
3	3.0795	2.8879	.9717	.2218	.181	.2772	.9922
4	3.2289	2.9885	1.166	.2614	.181	.3361	1.0364
5	3.5707	3.3752	1.3435	.2614	.2241	.4108	1.2266
6	4.5584	4.379	1.4419	.2641	.4527	.5658	1.9616
7	5.3376	3.9971	1.7695		.3921	.4527	2.0856
8	.8452	.7357	.2926	.3326		.2801	.3772
9	.5989	.6343	1.7695	2.3205		.2402	.2801
10	.5201	.5569	1.8351	2.304	.2454	.2172	.2402
11	.4786	.2827	1.9006	2.2801	.2804	.1949	
12	.4883	.4715	1.757	2.0719	.3155	.1949	
13	.4995	.3719	1.6057	1.0595		.2172	
14	.3418	.5386	1.3923	1.2163	1.1142	.181	
15	.2408	.5929	1.9062	.3567	1.7238	.2218	.2172
16	.4626	.5775		1.9113	1.0437	.2402	.2172
17	.2534	.5792	.3189		.2614	.2561	.2378
18	.3079	.6241	.3658		.3361	.2587	.2743
19	.9263	.7388	.5041		.4108	.3361	.3292
20	1.004	.8535	.5041		.4481	.3961	.4066
21	.969	.9785	.4527		.3734	.3772	.3982
22	4.1606	3.1634			.3174	1.7269	1.704
23	3.5894	2.8255		.1829	.2801	1.2616	1.1012
24	3.0783	2.7054	1.1012	.7287	.1829	.2402	1.0242
Max	5.3376	4.379	1.9062	2.3205	1.7238	1.7269	2.0856
Min	.2408	.2827	.2926	.1829	.1791	.181	.2172
Avg	1.8606	1.6309	1.1602	.9583	.4344	.3901	.8055

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 202 / 11 KV GATHNANDRE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1478	.1448	.6249	.1109	.6481	.168
2	.1494	.1478	.1463	.503	.1109	.6481	.168
3	.1494	.1478	.1448	.4531	.1109	.703	.168
4	.1886	.1867	.181	.5937	.1109	.7811	.1867
5	.2075	.2241	.2012	.8684	.1307	.8907	.2263
6	.2075	.2641	.2218	1.2944	.2054	1.0322	.2829
7			.2195	1.3443	.2263	.933	.2263
8	.1848	.1307	.1086	.1097		.128	.2402
9	1.0883		.0905	.0934		.8065	1.278
10	1.1012		.0914	.104	.1086	.759	1.1984
11	.8097		.0914	.0895	.0876	.6622	
12	.7773	.8097	.0895	.0895	.0678	.7977	
13	.7468	.7865	.0895	.0701		.7164	
14	.5155	.852	.0709	.0686	.0905	.7202	
15		.9831	.0663	.0857	.0905	.9282	
16	.9122	1.2597	.0686	.0724	.0791	1.0082	1.1142
17	.1294	.0895	.0829		.112	.0857	.0895
18		.0914	.1086		.1494	.124	.1075
19	.2054	.1448	.1494		.1867	.2241	.1448
20	.1867	.2195	.1867		.2241	.2263	.2353
21	.168	.181	.1494		.2054	.2241	.2172
22	.1663	.1448			.9602	.2054	.2172
23	.1478	.1448	.9762	.2591	.7343	.1867	.1791
24	.1494	.1478	.1448	.7621	.2968	.6481	.1867
Max	1.1012	1.2597	.9762	1.3443	.9602	1.0322	1.278
Min	.1294	.0895	.0663	.0686	.0678	.0857	.0895
Avg	.3972	.3552	.1663	.4159	.2095	.5870	.3492

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 203 / 11KV Raiwadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056		.0362	.3894	.0543	.443	.056
2	.056		.0362	.3963	.0549	.443	.056
3	.056		.0362	.3201	.0549	.5117	.056
4	.0934		.0366	.3858		.5117	.0566
5	.132		.0543	.4475	.0747	.5624	.0754
6	.1698		.0943	.5401	.1698	.5937	.1698
7			.128	.6562	.1307	.5575	.1509
8	.1109		.0905	.0747		.0739	.0943
9	.7343		.0914	.0754		.5624	.6401
10	.6472		.0724	.0554	.0532	.5312	.6859
11	.6226		.0739	.0554	.0532	.4967	
12	.4793	.5506	.0554	.0549	.0543	.4371	
13	.443	.5898	.0554	.0354		.4572	
14	.3668	.583	.0554	.0358	.0554	.4254	
15		.6154	.0549	.0347	.0543	.4755	
16	.571	.583	.0514	.0543	.0526	.4401	.5937
17	.0724	.0716	.0543		.0732	.052	.0358
18		.0716	.0509		.0924	.0739	.0716
19	.1097	.0905	.112		.1109	.1132	.0905
20	.112	.1267	.112		.112	.1307	.128
21	.0943	.1097	.0943		.0943	.1109	.1097
22	.0747	.0732			.5792	.0754	.0914
23	.0747	.0724	.4967	.4062	.5155	.056	.0724
24	.056		.0732	.3894	.2107	.443	.056
Max	.7343	.6154	.4967	.6562	.5792	.5937	.6859
Min	.056	.0716	.0362	.0347	.0526	.052	.0358
Avg	.2444	.2948	.0876	.2448	.1325	.3574	.1732

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 204 / 11 KV Shelkewadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2427	.2402	.1848	.2075	.1886	.2378	.2241
2	.2427	.2402	.1848	.1886	.1867	.2378	.2241
3	.2801	.2402	.1829	.1886	.1867	.2772	.2241
4	.3395	.2987	.2195	.1886	.2054	.3326	.2241
5	.3772	.3547	.2587		.2263	.3772	.2641
6	.3961	.3961	.3206	.415	.3772	.3961	.3772
7	.3696	.3696	.3547		.3772	.3258	
8	.2658	.2172	.2402	.2686		.2926	.3841
9	.2601		.2195	.1753		.2103	.3142
10	.2601		.1646	.1991	.2328	.1928	.2172
11	.2601		.1829	.1991	.2328	.1612	
12	.2012	.2172	.2033	.2149	.2254	.1791	
13		.2534	.2218	.2481		.1991	
14	.2835	.2149	.2149	.2378	.2303	.2054	
15	.2835	.2172	.2561	.2328	.2126	.2054	.1991
16	.2713	.2172	.1791	.2195	.2229	.1848	.2149
17	.3258	.2507	.1928		.2454	.2195	.2172
18		.2865	.2915		.3045	.2279	.2534
19	.4024	.362	.4435		.3761	.3292	
20	.439	.4163	.4251		.394	.4251	
21	.3881	.3801	.4435		.3658	.3696	.3841
22	.2801	.3109			.3109	.2957	.3109
23	.2561	.2715	.2641	.2075	.2715	.2561	.2534
24	.2427	.2402	.2353	.2452	.2075	.2378	.2241
Max	.439	.4163	.4435	.415	.394	.4251	.3841
Min	.2012	.2149	.1646	.1753	.1867	.1612	.1991
Avg	.3031	.2855	.2558	.2273	.2657	.2657	.2653

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 205 / 11 KV GHATNANDRE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.128	.1267	.1086	.1227	.0943	.1132
2	.1478	.128	.1086	.0905	.1227	.0943	.1132
3	.1848	.128	.1086	.0924	.1227	.132	.1132
4	.2054	.1848	.1097	.0924	.124	.1698	.1132
5	.2241	.2033	.1267	.1307	.1629	.2241	.1509
6	.2427	.2427	.168	.2427	.2614	.2614	.2263
7	.2427	.2402	.2033		.2587	.2054	.2452
8	.1646	.1463	.1463	.1052		.0716	.1509
9	.1463		.1267	.1052		.0716	.128
10	.1052		.0914	.0867	.1294	.0895	.0905
11	.1029		.0914	.0895	.1294	.0895	
12	.1029	.0905	.0914	.1254	.116	.0905	
13		.0914	.0943	.124		.1109	
14	.1214	.0905	.0934	.104	.0995	.0943	
15	.1227	.0905	.0934	.1052	.104	.0754	.0895
16	.1063	.0905	.0943	.124	.1387	.0934	.1267
17	.1417	.0895	.0566		.1387	.0747	.128
18		.1075	.1214		.1753	.1433	.128
19	.2126	.181	.2195		.2279	.2012	.1829
20	.2561	.2561	.2218		.2279	.2427	.2172
21	.2218	.1991	.181		.197	.2054	.181
22	.1663	.181			.181	.132	.1433
23	.1086	.1448	.1097	.1052	.1254	.0943	.1267
24	.1478	.128	.1267	.1075	.1227	.0943	.1132
Max	.2561	.2561	.2218	.2427	.2614	.2614	.2452
Min	.1029	.0895	.0566	.0867	.0995	.0716	.0895
Avg	.1647	.1496	.1266	.1141	.1566	.1315	.1441

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 206 / 11KV Raiwadi Gao

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0724	.0532		.0377	.0678	.1029	.0867
2	.0724	.0532		.0377	.0678	.1029	.0876
3	.0724	.0532		.0377	.0686	.1029	.0857
4	.0924	.0724		.0566	.0701	.1267	.0876
5	.0934	.0924		.0566	.0914	.1629	.1063
6	.0943	.0943		.0943	.1307	.1629	.1494
7	.0934	.0943	.1132	.0943	.1143	.1417	.1334
8	.0716	.0895	.0732	.0747		.1075	.112
9	.0701	.0886	.0905	.0905		.0876	.0914
10	.0848	.0867	.0732	.0709	.104	.0876	.0905
11	.0848		.0732	.124	.1214	.0838	
12	.0829	.0876	.0876	.1063	.1457	.1006	
13	.0655	.0905	.0867	.1017		.1017	
14	.0848	.0914	.0848	.0867	.1357	.1075	
15	.0857	.0905	.0876	.104	.1134	.1063	.0543
16	.0857	.0905	.0867	.0876	.128	.104	.1097
17	.1052	.1075	.0514		.1357	.1187	.1267
18		.1075	.0724		.1543	.124	.1267
19	.1254	.1267	.0566		.1595	.128	.128
20	.1254	.1267	.112		.1772	.128	.1646
21	.1086	.128	.1109		.1753	.1307	.1629
22	.1227	.0905			.124	.1254	.1267
23	.0693	.0543	.0377	.0181	.1029	.0886	.1075
24	.0724	.0532	.0366	.0377	.0671	.1029	.0876
Max	.1254	.128	.1132	.124	.1772	.1629	.1646
Min	.0655	.0532	.0366	.0181	.0671	.0838	.0543
Avg	.0885	.0879	.0785	.0732	.1169	.1140	.1113

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 207 / 11KV Jakhapur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2785	.2785	.2458	.0373	.0377	.0754	.2401
2	.2785	.2785	.2458	.0373	.0377	.0754	.144
3	.3113	.3113	.2429	.0373	.0377	.0754	.144
4	.3647	.3605	.2458	.0566	.0377	.0754	.1943
5	.4641	.4973	.2622	.0754	.0566	.0934	.2622
6	.5868	.6464	.2785	.1307	.1132	.0934	.4807
7	.7545	.7625	.4424		.1132	.112	.5868
8	.1509	.0943	.128	.1307		.0754	.1132
9	.0754		.5182	.639		.0754	.0943
10	.0943		.5407	.639	.0943	.0754	.132
11	.0754		.5571	.6062	.1132	.0566	
12	.0754	.0566	.4144	.4752	.1132	.0566	
13	.0943	.0754	.3521	.4049		.0754	
14	.0566	.0754	.3688	.5243	.3932	.0566	
15		.0754	.4424	.5601	.4424	.0754	.0566
16	.1132	.0566	.4696	.4534	.5079	.0754	.0566
17	.1132	.0934	.1494		.0754	.0943	.0739
18		.1478	.1307		.0943	.132	.1307
19	.1494	.1463	.1307		.0943	.132	.0914
20	.0934	.1097	.1307		.1132	.1698	.0914
21	.1307	.0914	.112		.0754	.0754	.0724
22	.4588	.2353			.0566	.3647	.4534
23	.4096	.2458		.0377	.0566	.2753	.3201
24	.2785	.3113	.2622	.0373	.0377	.0754	.2401
Max	.7545	.7625	.5571	.639	.5079	.3647	.5868
Min	.0566	.0566	.112	.0373	.0377	.0566	.0566
Avg	.2458	.2357	.3032	.2872	.1286	.1059	.1989

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 208 / 11 KV AGALGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1509	.1086	.68	.0934	.5079	.1494
2	.1509	.1509	.1086	.6325	.0934	.5079	.1494
3	.1886	.1509	.1097	.6009	.0934	.5407	.1509
4	.2427	.1886	.181	.6642	.112	.5898	.1698
5	.2801	.2801	.2172	.8065	.1509	.663	.1886
6	.3547	.3361	.3292	1.1227	.3772	.7459	.3206
7			.2743	1.0437	.3206	.7459	.2829
8	.2054	.2614	.1991	.1867		.2614	.2075
9	.9945		.1463	.168		.7701	
10	1.0442		.1086	.168	.1886	.7373	
11	1.0277		.1086	.0934	.1509	.7045	
12	1.0608	1.1469	.1086	.1109	.1132	.6226	
13	.9779	1.0202	.1086	.1086		.6241	
14	.7956	.9831	.1086	.1294		.5571	
15		1.0814	.1267	.1254		.6062	
16	1.1105	1.065	.1267	.2743	.1509	.7373	.6154
17	.132	.1791	.1267		.1509	.1097	.1075
18		.181	.1448		.1867	.1307	.1612
19	.2987	.2172	.2353		.2241	.2075	.2172
20	.2987	.2534	.2715		.2614	.2641	.2926
21	.2054	.2172	.2686		.2241	.2427	.2561
22	.1867	.1829			.7373	.1886	.181
23	.1509	.1612	.9172	.1475	.5898	.1509	.1629
24	.1509	.1509	.1448	.8676	.1423	.5079	.1494
Max	1.1105	1.1469	.9172	1.1227	.7373	.7701	.6154
Min	.132	.1509	.1086	.0934	.0934	.1097	.1075
Avg	.4766	.4179	.1991	.4406	.2295	.4885	.2213

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 201 / 11 KV LONARWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0788	3.0498	1.4083	.7438	.3944	.6654	1.6392
2	2.9628	3.0498	1.3748	.7354	.3891	.6593	1.4952
3	2.9728	3.4134	1.3923	.7374	.4109	.6486	1.448
4	3.1329	3.5673	1.4255	.7661	.4502	.6447	1.4419
5	3.4658	3.9165	1.5089	.8954	.4969	.6844	1.5927
6	4.545	4.9743	1.6956	1.2513	.5967	.9	2.3426
7	5.958	5.9495	1.8482	1.2982	.6992	.9694	3.1878
8	.9185	.8985	.2743	.2073	.6352	.8383	.6805
9	.707	.7277	2.0553	4.8971	.8032	.6438	.7704
10	.5984	.5961		5.5586	1.6743	.5699	.5864
11	.6051	.647	2.0056	5.6781	3.1108	.5167	.4077
12	.6257	.5756	1.989	5.6556	3.1388	.5129	.2743
13	.6341	.631	1.8023	5.3955	3.0279	.5537	
14	.5655	.6074		4.9905	2.7866	.5257	.2286
15	.333	.6121	1.8679	4.8838	3.3997	.5533	.4344
16	.5937	.584	1.8351	2.6116	4.1057	.4958	.3719
17	.6906	.6343	.3052	.3551	.7872	.5647	.426
18	.7393	.7631	.4161		.8025	.6257	.5289
19	.9808	.9774	.4755	.0434	.9534	1.0852	.6882
20	1.1203	1.2918	.5359	.3605	1.0859	1.3237	.868
21	1.3756	1.4243	.462	.6514	1.0417	1.391	.993
22	3.6969	4.1642	.4066	.6207	.9175	4.8478	2.3312
23	3.4721	3.5878	.3696	.4883	.7792	4.4841	3.6949
24	3.2182	3.0885	1.3599	.5944	.5552	2.1418	3.9421
Max	5.958	5.9495	2.0553	5.6781	4.1057	4.8478	3.9421
Min	.333	.5756	.2743	.0434	.3891	.4958	.2286
Avg	1.9580	2.0721	1.2188	2.1487	1.3768	1.1186	1.3206

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 202 / 11KV Kokle Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4942	.5373	.1494	1.4476	.1105	1.4051	.2873
2	.4797	.5106	.1494	1.3664	.093	1.3081	.253
3	.5076	.51	.1494	1.3489	.0892	1.2365	.2423
4	.5765	.4992	.1886	1.4956	.0892	1.3687	.2462
5	.6516	.577	.2641	1.8961	.0991	1.4762	.2797
6	.853	.724	.3395	2.5058	.1242	1.8035	.4443
7	.8089	.729	.2829	2.769	.1288	1.8858	.4725
8	.7029	.8772	.2427	.4726	.0831	.7804	.5609
9	1.7427	1.9719	.1334	.4767	.0793	1.7516	1.7908
10	1.7583	2.1589		.4119	.1044	1.8686	2.127
11	1.8488	1.8092	.0914	.4016	.1326	1.8343	1.0966
12	1.8267	1.8107	.0914	.4169	.0975	1.3001	.2751
13	1.539	1.9798	.0914	.4809	.1806	1.613	
14	1.0704	1.8915	.0914	.426	.112	1.7223	.2454
15	.9229	1.9677	.0914	.4306	1.6949	1.7352	.2728
16	1.3648	2.0248	.0914	.2202	1.23	1.4365	.7156
17	.5125	.2804	.0905	.1471	.5609	.3828	.2827
18	.5584	.4146	.1267		.5594	.462	.3041
19	.6859	.6242	.1848	.0884	.654	.6026	.3948
20	.7537	.7412	.2772	.1593	.7332	.675	.4687
21	.7746	.7272	.2587	.1379	.9377	.6468	.4565
22	.6467	.5969		.1372	1.5747	.5483	.3925
23	.6178	.4618	.7373	.1456	1.5067	.5056	.5535
24	.4896	.5452	.1494	.7629	.804	.9779	.4891
Max	1.8488	2.1589	.7373	2.769	1.6949	1.8858	2.127
Min	.4797	.2804	.0905	.0884	.0793	.3828	.2423
Avg	.9245	1.0404	.1942	.7889	.4908	1.2220	.5501

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 203 / 11 KV IRALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.2561	.2263	.9831		1.3904	.168
2	.2241	.2378	.2263	.9831		1.4575	.1494
3	.2801	.2587	.2452	1.0277		1.4918	.1494
4	.3395	.2587	.2263	1.1603		1.4918	.1494
5	.3772	.2772	.3018	1.576		1.56	.1494
6	.3961	.2801	.4338	2.0348		1.56	.3361
7	.3921	.2614	.3961	2.0687		1.6108	.3326
8	.3018	.2772	.2957	.2075		.2172	.2772
9	1.3435	1.5091	.2427	.1848		1.286	1.4899
10	1.2955	1.4918	.2218	.1848		1.3904	1.5223
11	1.3032	1.4582	.2195	.1848	.2218	1.4754	
12	1.2346	1.2963	.2195		.2012	.8718	
13	1.2003	1.3599	.2012	.1663	.1829	.0838	
14	.6783	1.2323	.1829	.1848	.1991	.8619	
15		1.3443	.1829	.1829	.2172	.9488	
16	1.3717	1.3603	.1829		.2378	.7907	
17	.2401	.1463	.1829		1.3769	.1886	
18	.2743	.181	.2012		1.1041	.2054	
19	.2587	.2561	.3696	.2452	.2534		
20	2.1068	.3696	.3696	.2452	.2353	.2452	
21	.2801	.3361	.3326		.2715	.2452	
22	.2614	.3018	1.3717		1.2717	.2241	
23	.2614	.3018	1.3535		1.406	.2241	
24	.1867	.2402	.2452	.9717	1.2717	.2641	.2054
Max	2.1068	1.5091	1.3717	2.0687	1.406	1.6108	1.5223
Min	.1867	.1463	.1829	.1663	.1829	.0838	.1494
Avg	.6432	.6372	.3513	.7407	.6036	.8733	.4481

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 204 / 11 KV LONARWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1294	.1867	.1494	.132	.1463	.1829	.1494
2	.1294	.1867	.1494	.132	.1478	.1663	.1494
3	.1307	.168	.1509	.1494	.1478	.1663	.1307
4	.1494	.1698	.1509	.1494	.168	.1478	.1307
5	.1886	.1509	.1867	.1867	.1867	.1478	.1294
6	.2075	.168	.2075	.2054	.1867	.1663	.1294
7	.1867	.1494	.1867	.2054	.1867	.1848	.1848
8	.197	.1294	.1867	.1227		.1663	.1867
9	.1612	.1294	.1612	.1595	.1867	.1663	.1629
10	.1433	.1417	.1227	.1595	.132	.1494	
11	.1463	.124	.1174	.1595	.1629	.128	.1372
12	.1478	.1254	.1174	.1595	.1646	.128	
13	.128	.1595	.1174	.1433	.1478	.1448	
14	.128	.1646	.1006	.1433	.1463	.1448	
15	.1086	.1448	.1006	.1433	.1663	.1448	
16	.1097	.1448	.1006		.1867	.1267	
17	.128	.1543	.1006			.1402	
18	.1646	.1823	.156			.1715	
19	.1829	.218	.1829	.2218		.1791	
20	.1867	.2587	.2195	.2378		.1791	
21	.2033	.2054	.2012	.2218		.1791	
22	.1848	.1865	.168	.2033		.1867	
23	.2033	.1494	.132	.1382	.2033	.1867	.168
24	.1294	.2033	.1478	.132	.1646	.1829	.1494
Max	.2075	.2587	.2195	.2378	.2033	.1867	.1867
Min	.1086	.124	.1006	.1227	.132	.1267	.1294
Avg	.1573	.1667	.1506	.1669	.1665	.1611	.1507

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 205 / 11 KV KOKLE GAO

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.112	.1109	.0943	.1097	.1307	.1294
2	.1109	.1109	.1109	.0943		.1307	.1109
3	.1109	.0924	.0924	.0943			.1109
4	.112	.1109	.0943	.1132		.1294	.1109
5	.1307	.1097	.1132	.1132		.1109	.1109
6	.1307	.1294	.132	.1132		.1109	.1294
7	.0943	.1294	.1132	.112		.128	.1294
8	.0934	.1294	.0924	.0934			.1109
9	.0943	.1307	.0943	.0943			.1132
10	.0953	.0754	.1109	.1132		.128	.0953
11	.112	.1029	.128	.1132	.112	.0754	
12	.112	.037	.128		.1132	.0754	
13		.1417	.128	.1132	.112	.0914	
14	.112	.112	.1097	.1075	.112	.0914	
15	.112	.0934	.0914	.1075	.1307	.0739	
16	.112	.0934	.0914		.132	.0747	
17	.1307	.0754	.0914		.1307	.0895	
18	.1307	.0934	.104		.1494	.1086	
19	.1509	.1307	.124	.1478	.1478	.1448	
20	.1494	.1612	.1612	.1646	.1663	.1448	
21	.1494	.1509	.1433	.1494	.168	.1494	
22	.1294	.1509	.132	.132	.1478	.1478	
23	.1294	.132	.1132	.1254	.1478	.1478	.1509
24	.1097	.1294	.1267	.0943	.1097	.1294	.1294
Max	.1509	.1612	.1612	.1646	.168	.1494	.1509
Min	.0934	.037	.0914	.0934	.1097	.0739	.0953
Avg	.1183	.1139	.1140	.1145	.1326	.1149	.1193

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 206 / 11 KV IRALI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.056	.0566	.1132		.0934	.0934
2	.0754	.0739	.0566	.1132		.0747	.0934
3	.0934	.0739	.0566	.1132		.0747	.0934
4	.0934	.0747	.0566	.1307		.0747	.0934
5	.1307	.0747	.0762	.1478		.0747	.112
6	.1307	.0747	.1143	.1663		.0747	.112
7	.1307	.0934	.1132	.1478			.1109
8	.0732	.0747	.0732	.0747		.0739	.0924
9	.0747	.0747	.0924	.0914			.0943
10	.0566	.0566	.0754	.0886		.0924	.0747
11	.056	.0747	.0754	.0886	.112	.0177	
12	.0554	.0566	.0754	.0886	.0754	.0179	
13	.0554	.0566	.0754	.0747	.0747	.037	
14	.0739	.0377	.0754	.0566	.0747	.037	
15	.0747	.0377	.0754	.0566	.0924	.0566	
16	.0747	.056	.0747		.0934	.0351	
17	.0747	.0377	.0747			.0377	
18	.0747	.1075	.1417			.0572	
19	.0924	.1463	.1463	.1132		.1143	
20	.0924	.1629	.1646	.1334		.1132	
21	.0924	.1307	.1463	.132		.1132	
22	.0747	.0762	.1294	.1132		.1132	
23	.056	.0953	.1109			.0934	.0934
24	.0754	.056	.0566	.1109	.0732	.0934	.0934
Max	.1307	.1629	.1646	.1663	.112	.1143	.112
Min	.0554	.0377	.0566	.0566	.0732	.0177	.0747
Avg	.0815	.0775	.0914	.1077	.0851	.0714	.0964

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244099 / 33/11 kv KAROLI

Feeder No / Name : 201 / 11 KV Shindewadi (H) Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.4024	.2241	2.1879		1.5581	.3142
2	.3361	.3658	.1867	2.2542	1.0774	1.6741	.2957
3	.2987	.3475	.168	2.4863	1.1105	1.873	.3142
4	.3547	.4207	.2427	2.5857	1.1437	1.9725	.3511
5	.4108	.4572	.2801	2.7183	1.2266	2.0885	.4435
6	.5041	.4938	.4294	2.967	1.326	2.2211	.5175
7	.5601	.5304	.5415	2.5857	2.4863	2.4531	.4435
8	.3734	.0366	.4108	.3547	.3361	.3174	.2772
9	2.7183	2.8346	.3361	.2987	.2241	2.9172	2.1879
10	.7459	3.2922	.2801	.2801	.2427	3.2156	2.967
11	.6133	3.0498	.2801	.2427	.2614	2.8675	2.9007
12	2.4034		.2614	.2614	.2427	2.6852	
13			.2801	.2427	.2241	2.6852	
14			.2427	.2614	.2054	2.42	
15			.2614	.2987	.2427	2.5857	
16	2.7681	2.9172	.2614	.3361	.2801	2.7846	
17	.4572	.2987	.2801	.2987	.3361	.2033	
18	.5304	.3361	.3361		.3734	.2772	
19	.4938	.4294	.3921		.4854		
20	.5487	.6161	.4268		.5788	.4805	
21	.567	.5228	.4668		.4108	.4251	
22	.4938	.3734	3.2487		1.6244	.3696	
23	.4572	.3361	3.1824		1.5581	.3326	
24	.4294	.4207	.2801	2.0388		1.4918	.3142
Max	2.7681	3.2922	3.2487	2.967	2.4863	3.2156	2.967
Min	.2987	.0366	.168	.2427	.2054	.2033	.2772
Avg	.7828	.9241	.5542	1.2611	.7271	1.7347	.9439

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244099 / 33/11 kv KAROLI

Feeder No / Name : 202 / 11 KV Kuktoli Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.2033	.1307	2.5857		1.8233	.2241
2	.0934	.1848	.0934	2.4863	1.1934	1.6409	.2427
3	.112	.1663	.112	2.42	1.2431	1.5083	.2427
4	.0747	.1848	.1307	2.4531	1.2929	1.9227	.2614
5	.1494	.1848	.1867	2.5857	1.2597	1.989	.2801
6	.2241	.2033	.2241	2.652	1.3592	2.1051	.3174
7	.1867	.1848	.2614	2.7846	2.0388	2.0388	.2801
8	.1307	.1294	.1867	.2054	.1848	.168	.1494
9	2.7681	3.0001	.168	.1307	.1478	2.1879	2.4863
10	3.0333	3.083	.1307	.112	.1478	2.4366	2.5194
11	2.8178	3.0498	.168	.1307	.1294	1.6575	2.9007
12	2.7349	2.8675	.1307	.112	.0924	2.0885	
13		2.7846	.1307	.1372	.0924	2.0553	
14		3.0167	.1494	.1494	.0739	1.8564	
15	2.5692	2.9835	.1494	.168	.1109	2.1051	
16	2.652	2.9338	.1494	.2241	.1294	2.1548	
17	.2033	.1867	.1494	.2054	.2033	.112	
18	.2033	.2054	.1867		.2402	.1494	
19	.2218	.2614	.2427		.3142		
20	.2218	.3547	.3547		.3696	.2987	
21	.2587	.3361	.3361		.3326	.2801	
22	.2218	.2241	2.967	1.326	1.7072	.2801	
23	.2402	.1867	2.7681		1.9559	.2241	
24	.1494	.2218	.168	2.6023		1.8564	.2241
Max	3.0333	3.083	2.967	2.7846	2.0388	2.4366	2.9007
Min	.0747	.1294	.0934	.112	.0739	.112	.1494
Avg	.8817	1.1307	.4031	1.2353	.6645	1.4321	.8440

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244099 / 33/11 kv KAROLI

Feeder No / Name : 203 / 11 KV Kongnoli Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8233	2.2377	1.6741	.2402		.1867	1.326
2	1.6741	2.4034	1.6078	.2402	.1494	.168	1.326
3	1.5415	2.4034	1.8233	.2587	.168	.2054	1.3923
4	1.6409	2.3205	2.0885	.2957	.1867	.2427	1.4586
5	2.0885	2.5029	2.2211	.3326	.2241	.2801	1.5912
6	2.536	2.5692	2.4531	.3881	.2614	.2614	1.8067
7	2.652	2.7349	2.5526	.4251	.2801	.2987	2.0553
8	.3174	.2772	.2241	.2587	.3547	.2054	.2427
9	.2427	.2772	2.4366	2.9835	.6203	.1867	.2241
10	.2054	.2587	2.6355	3.083	.5868	.168	.2241
11	.2054	.2957	2.7349	3.0498	1.9448	.0373	.1867
12	.2427	.2402	2.5194	2.9835	1.8442	.168	.168
13	.1494	.1848	2.304	2.9835	1.3245	.2054	.2054
14	.2427	.2587	2.4366	2.9835	1.358	.168	
15	.2801	.2772	2.7681	2.8841	1.073	.1867	
16	.2801	.3142	2.652	2.3205	1.1736	.2241	
17	.3547	.3511	.2402	.2218	.1867	.2427	
18	.3734	.3696	.3326		.3547	.2241	
19	.4108	.4435	.4066		.4481		
20	.4294	.5544	.4251		.3174	.4481	
21	.4481	.4066	.4066			.4294	
22	2.2211	1.8067	.3142	.1848	.2987	1.5912	
23	2.0719	1.9227	.2957		.2614	1.4255	
24	1.9559	2.1548	1.7238	.2587		.2155	1.3757
Max	2.652	2.7349	2.7681	3.083	1.9448	1.5912	2.0553
Min	.1494	.1848	.2241	.1848	.1494	.0373	.168
Avg	1.0161	1.1486	1.6365	1.3882	.6389	.3378	.9702

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244099 / 33/11 kv KAROLI

Feeder No / Name : 204 / 11 KV Karoli Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561		.2195	.3475		.2195	.3109
2	.2378	.2926	.1829	.3292	.3292	.1829	.3292
3	.2012	.3109	.4755	.3475	.3475	.2012	.3292
4	.1829	.3292	.2012	.3658	.3658	.2378	.3658
5	.2378	.3475	.2378	.439	.3841	.2743	.439
6	.4024	.439	.2926	.4938	.4024	.3292	.5304
7	.3658	.4207	.3841	.4024	.3841	.4024	.4207
8	.4207	.3109	.3292	.3658	.3292	.3292	.3841
9	.3109	.3475	.3658	.3658	.3109	.3475	.3109
10	.2743	.2561	.3109	.2926	.3658	.3109	.2926
11	.2561	.2378	.3109	.3109	.3292	.2353	.2561
12	.2743	.2195	.2561	.2926	.2926	.2926	.2561
13	.2195	.2012	.2172	.2378	.2195	.2353	.2012
14	.2378	.1829	.181	.2195	.1829	.2896	
15	.2743	.2561	.2172	.2378	.2561	.2896	
16	.2926	.3109	.2926	.2561	.2743	.2896	
17	.4024	.3292	.3109	.2195	.3109	.3109	
18	.439	.3658	.439		.3475	.3841	
19	.4572	.5121	.4755		.4207		
20	.4938	.567	.5853		.5304	.5487	
21	.5304	.4938	.5487		.4938	.4938	
22	.439	.3658	.4572	.3658	.3658	.439	
23	.3658	.2926	.4024		.2926	.3292	
24	.2926	.3475	.2561	.3658		.2561	.3292
Max	.5304	.567	.5853	.4938	.5304	.5487	.5304
Min	.1829	.1829	.181	.2195	.1829	.1829	.2012
Avg	.3277	.3364	.3312	.3292	.3425	.3143	.3397

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 201 / 11 KV Deshing GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2683	.2347		.2347		
2	.2515	.1509			.2347	
3	.2347	.2347		.2515	.2012	
4	.285	.2347		.2515	.2012	
5	.3018	.2683		.2515	.1844	
6	.2683	.3018		.2683	.2515	
7	.2683	.3185	.3353	.285	.3185	
8	.2347	.2347	.2515	.218	.3018	
9	.2012	.218		.2012	.2515	.1943
10	.1509			.1844	.2515	.218
11	.1677			.2012	.2347	.1677
12	.2347		.2012	.2347	.218	
13				.218	.1844	
14	.2515		.2012	.2012	.218	
15	.2515			.2347	.2347	
16	.2515		.2515	.218	.2347	
17	.2515			.218	.2515	
18	.2515				.3018	
19					.4191	
20	.4694				.4191	
21	.4359		.4024		.4024	.4024
22	.3353				.3185	.3353
23	.2683				.2515	.3353
24	.3185	.2347	.2683	.2515		
Max	.4694	.3185	.4024	.285	.4191	.4024
Min	.1509	.1509	.2012	.1844	.1844	.1677
Avg	.2705	.2431	.2731	.2308	.2675	.2755

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 202 / 11 KV BANEWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	1.5424		.1174		
2	.8383	1.5424		.1174	.0671	
3	.9221	1.5424		.1341	.0838	
4	1.0059	1.5424		.1509	.0838	
5	1.2574	1.5424		.1509	.0838	
6	1.4251	1.7604		.1341	.1006	
7	1.7269	1.8778	1.576	.1341	.1341	
8	.285	.1174	.1677	.1174	.1341	
9	.1174	.1174		1.5592	1.9113	.1006
10	.1509			2.1795	2.0622	.1174
11	.1006			1.8442	2.0119	.1341
12	.1174		1.9281	1.8442	1.9616	
13	.1174			1.8442	1.9448	
14	.1174		1.9281	1.8442	1.6766	
15	.1174			1.8442	1.5089	
16	.1174		1.861	1.9281	1.7436	
17	.1174			.0838	.1174	
18	.1006				.1174	
19					.1844	
20	.1341				.1844	
21	.1174		.1509		.1509	.1341
22	1.7101				.1341	.5868
23	1.6598				.1006	.7545
24	.7545	1.5424	1.2574	.1174		
Max	1.7269	1.8778	1.9281	2.1795	2.0622	.7545
Min	.1006	.1174	.1509	.0838	.0671	.1006
Avg	.6021	1.3127	1.2670	.8970	.7499	.3046

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 203 / 11 KV MORGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2683	.1509		1.0059		
2	.285			1.0059	.8383	
3	.2012	.1509		1.0898	.8383	
4	.1677	.1509		1.1736	.8383	
5	.1844	.1677		1.4251	1.0562	
6	.2683	.2012		1.6766	1.1401	
7	.3353	.2012		1.6766	1.3916	
8	.3353	.2012	.2012	.1844	.1174	
9	3.3532	1.8945	.1677	.1677	.1174	1.6766
10	3.3532		.1509	.1677	.1509	1.8442
11	3.1855		.1341	.1341	.1509	1.8442
12	3.1017		.1174	.1341	.1174	
13	2.9675		.1174	.1341		
14			.1006	.1341	.1174	
15	2.9508			.1341	.1509	
16			.1677	.1509	.1341	
17				.1509	.1341	
18					.1509	
19					.2347	
20	.218				.2347	
21	.2012		.3018		.1677	.1677
22	.1677				1.3916	.1341
23	.1677				1.3077	.1509
24	.3018	.1509	.218	1.0059		
Max	3.3532	1.8945	.3018	1.6766	1.3916	1.8442
Min	.1677	.1509	.1006	.1341	.1174	.1341
Avg	1.1586	.3633	.1677	.6418	.5134	.9696

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 204 / 11 KV KHARSHING AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6706	1.1736		.1174		
2	.6706	1.1736		.1341	.0671	
3	.6706	1.1736		.1509	.0838	
4	.9221	1.1736		.1174	.0838	
5	1.0059	1.1736		.1341	.0838	
6	1.0898	1.2742		.1341	.0838	
7	1.1401	1.5089	1.1401	.1509	.1341	
8	1.1401	.1341	.1509	.1341	.0838	
9	.1341	.1174	1.1736	1.0898	1.358	.0671
10	.1341		1.1736	1.4922	1.1904	.0838
11	.1341		1.4419	1.5089	1.1736	.1006
12	.1006			1.0898	1.0395	
13	.1174			1.0898	1.1233	
14	.1006		1.3413	1.1401	1.1736	
15	.1174			1.2574	1.1736	
16	.1174		1.4586	1.3748	1.358	
17	.1006			.0671	.1006	
18	.1006				.1006	
19					.1844	
20	.2012				.1844	
21	.2012		.1006		.1677	
22	1.2239				.1174	
23	1.2742				.1006	
24	.5868	1.1736	.7545	.1341		
Max	1.2742	1.5089	1.4586	1.5089	1.358	.1006
Min	.1006	.1174	.1006	.0671	.0671	.0671
Avg	.5197	1.0076	.9706	.6287	.5075	.0838

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 205 / 11 KV SONI LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.0671	
2		.0671	
3		.0838	
4		.0838	
5		.0838	
6		.0838	
7	.0503	.0671	
8	.0503	.0671	.0335
9	.0671	.0838	
10	.0671		
11	.0503		
12	.0503		
13	.0503		
14	.0671		
15	.0671		
24			.0168
Max	.0671	.0838	.0335
Min	.0503	.0671	.0168
Avg	.0578	.0764	.0252

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 201 / KHANDERAJURI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1052	1.5384	1.8442	.2477		.2477	1.9062
2	2.1052	.1538	1.6766	.2286		.2477	1.8515
3	2.0891	1.4899	1.6057	.2286		.2096	1.8515
4	2.1792	1.4899	1.6057	.2667		.2096	1.8351
5	2.2348	1.5708	1.6385	.2858		.2667	1.7859
6	2.3482	1.8351	1.704	.4001		.381	
7	2.4249	2.536	2.1538	.362		.362	2.0885
8	.2858	.3239	.2858	.3048		.3429	.2858
9	.3239	.3048	2.7244	2.3967		.2477	.2286
10		.2477	2.6216	2.4615		.1905	.2286
11	.2286	.2477	2.6397	2.5425		.1905	.2477
12	.1524	.2477	2.3102	2.4615	1.3426	.0953	.2096
13	.1715	.2477	1.8461	2.834	1.4419		
14		.1334	1.7859	2.7692	1.2266		
15	.1334	.1905	2.0729	2.834	1.9113	.1524	
16	.2858	.2667	2.1714	1.1498	1.6766	.1524	
17	.2858	.3048	.2286	.2096	.1143	.1905	
18	.1524	.362	.2477		.1524	.3048	
19	.3239	.4572	.362		.1905	.4191	
20	.362	.4572	.4191		.362	.4382	
21	.3239	.4001	.362			.4191	
22	.2138	2.2634	.3429		.3048	1.491	
23	1.6876	2.0119	.2667		.2858	1.8515	
24	.2667	1.5238	1.8778	.3239		.2667	
Max	2.4249	2.536	2.7244	2.834	1.9113	1.8515	2.0885
Min	.1334	.1334	.2286	.2096	.1143	.0953	.2096
Avg	.9402	.8585	1.4497	1.2393	.8190	.3944	1.1381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 202 / 11 KV Khatav

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.2096	.2096	1.3765		.8848
2	.2477	.2096	.2096	1.4413		.852
3	.2477	.2096	.2096	1.6057		.8192
4	.2858	.2096	.2096	1.6876		.7956
5	.3048	.2096	.2286	1.8023		.8288
6	.3429	.2667	.3048	2.2348		.852
7	.3239	.3239	.3239	2.5263		1.0814
8	.2286	.2477	.2858	.2477		.1524
9	2.4129	2.5194	.2858	.2096		1.1142
10		2.9312	.3048	.1905		1.3592
11	2.3807	2.6882				1.3441
12	2.4863	2.8502				1.4089
13	2.7328	2.9473				1.4251
14		2.3967				1.6385
15		2.5749				1.8896
16	2.1538	2.6073	.3239	.1905		1.8233
17	.2286		.3048	.2286		
18	.2096	.2477	.3429			
19	.3239	.3429	.381		.1905	
20	.3429	.3429	.4001		.2286	
21	.362	.3239	.381		.1905	
22	.2667	.3048	2.1376		.9221	
23	.2286	.2667	2.0481		.9614	
24	2.7349	.2096	.2286	1.3435		.9448
Max	2.7349	2.9473	2.1376	2.5263	.9614	1.8896
Min	.2096	.2096	.2096	.1905	.1905	.1524
Avg	.9092	1.1061	.4800	1.1604	.4986	1.1302

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 203 / 11 KV Mallewadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1715	.1524	1.6575		.6554	.1334
2	.1905	.1524		1.5912		.7127	.1334
3	.1905	.1524	.1524	1.5729		.6226	.1334
4	.2096	.1524	.1715	1.6385		.6371	.1334
5	.2286	.1715	.1905	1.6712		.6874	.1524
6	.2477	.1905	.2286	1.8679		.8684	
7	.2667	.2477	.2667	1.9826			.2096
8	.1715	.1905	.1715	.2096		.1524	.1715
9	2.1216	.1267	.1334	.2096		.663	1.3765
10		2.1464	.1524	.1905		1.4255	1.5384
11	1.9062	2.0645	.1524	.1715		1.6741	1.6964
12	2.0317	2.1464	.1524	.1715		1.6876	
13	1.9757	2.0891	.1715	.1715		1.4899	
14		2.3158	.1715	.1905		1.3599	
15		2.2283	.1715	.1905	.0381	.1376	
16	1.5384	2.0481	.1524	.1905	.0381	1.3765	
17	.1524	.1143	.1524	.1715	.0381		
18	.1715	.1524	.1715		.8192	.1334	
19	.2096	.2477	.2286		.1905	.1715	
20	.2667	.2477	.2477		.2477	.2096	
21	.2477	.2286	.2286		.2096	.2096	
22	.2096	.1715	1.8842			.1524	
23	.2096	.1715	1.8351		.431	.1524	
24	2.1538	.1715	.1524	1.704		.6133	.2096
Max	2.1538	2.3158	1.8842	1.9826	.8192	1.6876	1.6964
Min	.1524	.1143	.1334	.1715	.0381	.1334	.1334
Avg	.7091	.7541	.3257	.8641	.2515	.7178	.5353

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 204 / 11 kv shivganga

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0762	.0762	.0572		.0572	.0572
2	.0572	.0572	.0762	.0572		.0572	.0572
3	.0572	.0572	.0572	.0572		.0572	.0572
4	.0572	.0572	.0572	.0762		.0572	.0572
5	.0572	.0572	.0572	.0762		.0572	.0572
6	.0762	.0572	.0572	.0762		.0762	
7	.0381	.0762	.0572	.0762		.0762	.0572
8	.1715	.0762	.0572	.0762		.0762	.0762
9	.0572	.0762	.0572	.0762		.0572	.0572
10	.0572	.0762	.0762	.1905		.0572	.0953
11	.2667	.0572	.1715	.3048		.0953	.0572
12	.2477	.0572	.1524	.1143		.1524	.0762
13	.0762	.0381	.0572	.0572		.0953	
14	.0762	.0572	.2667	2.7692		.2477	
15	.0762	.0572	.2286	.1524		.0381	
16	.2477	.0572	.1334	.1715	.1715	.2286	
17	.2667	.0572	.0953	.0953	.1715	.1905	
18	.0762	.0381	.1143		.1334	.1524	
19	.0572	.0572	.0572		.0572	.0572	
20	.0762	.0191	.0762		.1905	.0953	
21	.0762	.0572	.0572		.1905	.1524	
22	.0762	.0762	.0572		.0762	.0572	
23	.0762	.0762	.0572		.0572	.0572	
24	.0572	.0762	.0762	.0572		.0762	.0572
Max	.2667	.0762	.2667	2.7692	.1905	.2477	.0953
Min	.0381	.0191	.0572	.0572	.0572	.0381	.0572
Avg	.1016	.0604	.0929	.2523	.131	.0969	.0635

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 205 / 11KV Salgare

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6984	.6226	.547	.0762		.0572	.2713
2	.6733	.5992	.547	.0762		.0572	.2683
3	.6805	.583	.5304	.0762		.0572	.2683
4	.7619	.0551	.4973	.0762		.0762	.2683
5	.7973	.5506	.5365	.1143		.0762	.3018
6	.9134	.7045	.6539	.1715		.1143	.373
7	1.0924	.8288	.7712	.1143		.1143	.7461
8	.1524	.1334	.0762	.0953		.0762	.1334
9	.1334	.1334	.9145	.7619		.0572	.0953
10	.1334	.0953	.9313	.9259		.0572	.0953
11	.1143	.1143	.9568	1.0288		.0572	.0762
12	.0953	.1143	.8063	.9339		.0572	.0953
13	.1143	.1143	.8682	.9503		.1334	
14		.0381	.7973	.9221		.1334	
15	.0762	.0572	.8939	.8848		.1334	
16	.1143	.0572	.8775	.8684	.3224	.0953	
17	.1143	.0762	.0953	.0953	.0762		
18	.1524	.0953	.1143		.0572	.1334	
19	.1524	.0953	.1334			.1715	
20	.1334	.0953	.1524		.0762	.1715	
21	.1143	.0953	.1143		.0762	.1905	
22	.7293	.6859	.0953		.0762	.4696	
23	.6464	.6097	.0762		.0572	.3077	
24	.7087	.6299	.5716	.0762		.0572	.2713
Max	1.0924	.8288	.9568	1.0288	.3224	.4696	.7461
Min	.0762	.0381	.0762	.0762	.0572	.0572	.0762
Avg	.4044	.2993	.5233	.4582	.1059	.1241	.2511

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 206 / Salgare gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1715	.1715	.1524	.1524	.1715	.1905
2	.1905	.1715	.1715	.1715		.1715	.1905
3	.2286	.1715	.1715	.1715	.1524	.1715	.1905
4	.2858	.1715	.1905		.1524	.2096	.1905
5	.2858	.2096	.2286	.2477	.1715	.2286	.2286
6	.2957	.2667	.3048	.3326	.1905	.2858	
7	.3429	.3048	.2477	.2957	.2477	.3511	.3239
8	.2858	.2286	.2667	.2667	.1905	.2858	.2858
9	.2477	.1753	.2477	.2286	.1905	.1905	.2477
10		.0762	.3239	.2286	.1524	.1905	.2477
11	.2286	.1524	.3048	.2477		.2286	.2477
12	.3239	.1524	.2957	.2858	.3239	.1905	.2477
13		.1524	.2054	.2858	.3292	.2477	
14	.2858	.1524	.1905	.2477	.2667	.1905	
15	.3155	.1905	.2286	.2858	.2667	.1524	
16	.3048	.2477	.2858	.2477	.2477	.2286	
17	.2865	.2286	.2667	.2667	.2667	.2328	
18	.2667	.2096	.2587		.2096	.181	
19	.3429	.3048	.2957		.1848	.2096	
20	.3048	.381	.3547		.3547	.3239	
21	.3239	.3239	.3239		.3239	.3048	
22	.0953	.3048	.2858		.2477	.2477	
23		.2286	.2286		.1905	.2286	
24	.3048	.1715	.1715	.1524	.1524	.1905	.2858
Max	.3429	.381	.3547	.3326	.3547	.3511	.3239
Min	.0953	.0762	.1715	.1524	.1524	.1524	.1905
Avg	.2732	.2145	.2509	.2421	.2257	.2256	.2397

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 201 / 11 Kv Arag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	31-MAR-17	01-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10			.1524	.1143
11			.1715	.1715
12			.1905	.2096
13			.2096	
23	.1905			
24		.1715		
Max	.1905	.1715	.2096	.2096
Min	.1905	.1715	.1524	.1143
Avg	.1905	.1715	.181	.1651

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 202 / 11 KV Bedag gav

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2896	.2972			.3201	.3658	.442
2	.2896	.3048			.3048	.3506	.4115
3	.2896	.2972			.3048	.3506	.3963
4	.3201	.3125			.3277	.3582	.4191
5	.3582	.3658			.381	.4191	.4572
6	.3887	.3658			.3963	.442	.4572
7	.3277	.3201			.3353	.3887	.381
8	.3125	.2896			.3125	.3506	.3582
9	.2972	.2591			.3125	.3734	.3658
10	.2896	.2667			.3506	.6958	.8354
11	.3429	.2743			.3506	.6882	.8029
12	.3429	.3125			.3582	.7545	.8551
13	.3582	.3201			.3353	.7796	.8495
14	.3429	.2972			.2972	.4191	.442
15	.3506	.3048			.381	.4191	.442
16	.3734				.381	.4344	.4725
17	.3506				.3734	.4344	.4649
18	.381	.5106			.3658	.4344	.503
19	.4649	.5335			.4954	.5411	.5944
20	.4801	.4954			.4954	.5563	.5716
21	.4496	.4801			.4725	.5487	.5487
22	.4115	.4496			.4725	.5335	.5411
23	.3582	.3582	.381		.4115	.4954	.5182
24				.3048		.7621	
Max	.4801	.5335	.381	.3048	.4954	.7796	.8551
Min	.2896	.2591	.381	.3048	.2972	.3506	.3582
Avg	.3552	.3531	.381	.3048	.3711	.4957	.5274

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 203 / 11 KV Vijaynagar
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	31-MAR-17	01-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
10			.1143
11			.1143
12			.1905
23	.1715		
24		.2477	
Max	.1715	.2477	.1905
Min	.1715	.2477	.1143
Avg	.1715	.2477	.1397

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 204 / 11 KV Bedag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	31-MAR-17	01-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10			.2096	.2477
11			.2096	.2477
12			.1715	.1905
13			.1715	
23	.2667			
24		.2096		
Max	.2667	.2096	.2096	.2477
Min	.2667	.2096	.1715	.1905
Avg	.2667	.2096	.1906	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 205 / 11 KV rade ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3277	.3277		2.5149	1.7375	2.1795	.3582
2	.3277	.3277		2.5072	1.6613	2.1338	.3506
3	.3277	.3201		2.4996	1.6232	2.1033	.3429
4	.3353	.3277		2.492	1.669	2.1338	.3658
5	.3734	.3658		2.5987	1.768	2.1795	.3963
6	.4572	.4115		2.9721	2.4234	2.492	.4268
7	.4725	.4496		1.4251	1.2651	1.166	.3963
8	2.9645	1.768		.3353	.3048	2.0881	2.6901
9	1.608	1.5623		.2058	.3277	2.9492	3.1398
10	2.9797	2.1643		.2134	.3125	5.4047	6.0795
11	3.0331	3.4217		.2362	.282	5.5022	5.3414
12	3.597	3.658		.2515	.2972	5.3803	.588
13	.5487	1.448		.2896	.3048	5.2919	.2591
14		3.3684		.2972	.2743	2.9797	.541
15	1.3336	3.4675		.2515	.282	3.0636	1.5394
16	1.5013			.2515	.2896	2.332	1.6004
17	.3963			.2743	.3125	.2439	.282
18	.4039	.4191		.3125	.3277	.3277	.3277
19	.5716	.6401		.2515	.4115	.4649	.4649
20	.5639	.6478		.2515	.4344	.4725	.4801
21	.5258	.5792		1.8595	2.1719	.442	.4725
22	.4649	.4877		1.8671	2.3396	.3963	.442
23	.3506	.4191	2.5286	1.8442	2.3701	.3582	.4115
24				.7621			
Max	3.597	3.658	2.5286	2.9721	2.4234	5.5022	6.0795
Min	.3277	.3201	2.5286	.2058	.2743	.2439	.2591
Avg	1.0666	1.2658	2.5286	1.1152	1.0083	2.2646	1.1868

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 206 / 11 Kv Bolwad Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	31-MAR-17	01-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10			2.1125	2.2405
11			2.1765	2.5606
12			2.1445	.192
13			2.1445	
23	2.3045			
24		1.9966		
Max	2.3045	1.9966	2.1765	2.5606
Min	2.3045	1.9966	2.1125	.192
Avg	2.3045	1.9966	2.1445	1.6644

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244052 / 33/11 KV MALLEWADI

Feeder No / Name : 201 / 11 kv Erandoli Gav.

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3189		.3395	.3734	.3018	.4024	.3961
2	.3206		.3206	.3772	.2829	.4024	.3961
3	.3155		.3206	.3584	.2829		.3772
4	.3395		.3395	.3584	.3018	.4481	.3961
5	.4119		.4108	.415	.3584		.4338
6	.4527		.5228	.4904	.4854	.4904	.4715
7	.443		.4805	.4525	.4938	.4024	.4066
8	.3982		.2454	.4163	.3898	.4119	.4252
9	.3641		.3361	.4334	.3641	.4031	.3721
10		.4835	.3814		.463	.5138	.4409
11	.5138	.5375	.4908		.5083	.5316	.3988
12	.4835	.4862	.5028		.5552	.4801	.3688
13		.4733	.443		.5014	.3898	.3988
14	.394	.3761	.4031		.4207	.3898	
15	.4251	.3721	.3801		.4435	.4119	
16	.4066	.4031	.3898		.4668	.4161	
17	.4075	.4287	.3856		.5121	.4748	
18	.4656	.4917	.4801		.5731	.5138	
19	.6268	.631	.7011		.57	.6661	
20	.6268	.6556	.7164		.5935	.7164	
21	.6024	.6447	.6626		.6036	.6626	
22		.5041	.5914		.5426	.6401	
23		.4108	.4108			.5175	
24	.3224		.3547	.4683	.3361	.4066	.4294
Max	.6268	.6556	.7164	.4904	.6036	.7164	.4715
Min	.3155	.3721	.2454	.3584	.2829	.3898	.3688
Avg	.4319	.4927	.4421	.4143	.4500	.4860	.4080

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244052 / 33/11 KV MALLEWADI

Feeder No / Name : 203 / 11 KV Takali

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5978	1.7642	1.3441	.5414	.4085	.4534	2.7858
2	3.0061	1.7566	1.358	.5399	.4134	.25	2.6521
3	2.6193	1.7193	1.358	.5371	.4096	.4424	2.6353
4	2.9767	1.7101	1.3765	.5227	.4127	.4764	2.6162
5	2.9451	1.768	1.4403	.5531	.4476	.2484	2.6844
6	3.4392	1.9311	1.5181	.5651	.4878	.5357	3.0856
7	3.4227	1.9288	1.5813	.554	.4817	.4937	3.8851
8	1.0547	1.0311	.2229	.5022	.4298	.4784	1.097
9	.3128	.2904	1.9662	3.8828	2.9912	.4389	.4363
10	.1753	.5392	2.0081	2.383	1.784	.3757	.4184
11	.1631	.5137	2.0645	2.3571	3.4043	.3726	.4436
12	.3727	.4588	1.9109	2.3122	3.5069	.4113	.3963
13	.439	.4695	1.7711	2.3365	3.4947	.4304	.397
14	.463	.4771	1.8056	2.3198	1.8153	.4342	.2233
15	.4449	.5231	1.9757	2.3548	1.8991	.501	.218
16	.474	.5517	1.9292	2.162	4.0017	.5144	.2683
17	.6059	.5913	.2378	.8406	1.5425	.5099	.3094
18	.7221	.6434	.2353	.3437	.4106	.5853	.3384
19	.6832	.7442	.2801	.3574	.4702	.6965	.3711
20	.7773	.8345	.3734	.3246	.6546	.7697	.4031
21	.4153	.852	.3361	.1943	.3445	.7651	.4001
22	1.6865	3.5965	.3206	.2515	.6234	3.2114	1.8816
23	2.0149	3.6037	.2641	.2378	.5251	3.2023	1.989
24	3.4564	1.9082	1.8679	.5804	.4481	1.8723	3.1389
Max	3.4564	3.6037	2.0645	3.8828	4.0017	3.2114	3.8851
Min	.1631	.2904	.2229	.1943	.3445	.2484	.218
Avg	1.4695	1.2586	1.2311	1.1481	1.3086	.7696	1.3781

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244052 / 33/11 KV MALLEWADI

Feeder No / Name : 204 / 11 kv Erandoli

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6022	.3056	.3048	4.6677		4.0945	.5788
2	.587	.5274	.2858	4.4924		3.9565	.5753
3	.5824	.2942	.2858	4.4246		1.9334	.5708
4	.6013	.5365	.3048	4.3393		3.7692	.5731
5	.6359	.3086	.3429	4.5057		1.9265	.6028
6	.6942	.6558	.4001	4.9303		3.8123	.6637
7	.6983	.3597	.3174	5.0592		2.3693	.6497
8	.6002	.3239	.2641	2.2354		2.3948	.5788
9	4.4041	2.5339	.2829	.4567		4.7302	4.5576
10	2.9188	6.3923	.2641	.2248		5.5914	5.602
11	5.6729	6.0416		.2058	.2408	5.2647	5.8823
12	5.8528	2.4486	.3018	.2233	3.6778	5.2845	2.3883
13	2.3746	3.5473	.2829	.2683	1.5944	4.4841	.53
14	2.7349	6.1226	.2829	.282	.458	4.9543	.2667
15	3.1771	3.3105	.2641	.2622	.4396	5.0327	.2507
16	3.309	4.3321	.2641	.2797	.5502	4.4208	.9556
17	1.82	3.2068	.2829	.2629	.2347	1.8107	2.6398
18	.6043	.5913	.2829	.2583	.4434	.5	.2926
19	.7396	.8061	.415	.2462	.2789	.651	.3155
20	.8749	.9934	.4715	.2789	.7377	.8122	.4649
21	.8756	1.0002	.4715		.7415	.8206	.4915
22	.8467	.9412	2.6825	1.3329	4.2324	.7655	.4786
23	.4252	.7963	2.3975	.9465	4.4868	.6912	.4496
24	.6158	.6051	.3239	2.1956	2.4287	2.2531	.6594
Max	5.8528	6.3923	2.6825	5.0592	4.4868	5.5914	5.8823
Min	.4252	.2942	.2641	.2058	.2347	.5	.2507
Avg	1.7603	1.9575	.5120	1.8426	1.4675	3.0135	1.2924

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244052 / 33/11 KV MALLEWADI

Feeder No / Name : 206 / 11 KV VanKochiwadi feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5068	.2515	.2667	3.9754	2.6365	3.4138	.4801
2	.5068	.2439	.2477	3.8553	2.6365	1.6232	.4801
3	.4992	.2439	.2477	3.8378	1.5394	2.2541	.4801
4	.541	.2515	.2667	3.7704	1.9795	1.166	.4877
5	.7049	.3048	.3048	4.1194	2.0881	2.3701	.5639
6	.7735	.3582	.4001	4.0495	2.7854	2.866	.7049
7	.7354	.3201	.4191	3.9228	2.572	1.105	.663
8	2.4996	2.553	.2667	.4687	.442	2.0216	2.1453
9	4.6858	2.7206	.2286	.4077	.3658	4.1266	4.9184
10	1.5851	1.5242	.2096	.2134	.0838	4.7508	5.3448
11	2.8959	5.9404	.2096	.16	.3658	4.2665	5.2588
12	5.4527	6.4832	.2096	.2134	.3582	3.0981	.1372
13	.5487	6.19	.2286	.2134	.4077	4.3286	.3544
14	5.0211	2.9416	.2286	.2362	.4001	4.4963	.1905
15	1.0288	6.0471	.2477	.221	.423	4.7601	1.2346
16	.2515	4.3324	.2667	.2134	.4687	3.2258	1.5013
17	.4816	.4306	.2667	.2362	.2362	.5601	.2286
18	.5312	.5068	.2477	.2134	.4458	.5334	.2515
19	.7747	.8192	.362		.381	.7468	.4115
20	.7865	.8306	.4191	.0914	.8497	.8154	.4115
21	.7747	.8154	.4001	1.0822	1.9433	.7544	.4191
22	.7316	.6554	2.1628	1.1431	3.6564	.644	.3353
23	.2591	.5678	1.9433	.9755	3.7372	.5182	.2743
24	.2477	.2477	.2858	1.8515	1.7372	.2477	.2477
Max	5.4527	6.4832	2.1628	4.1194	3.7372	4.7601	5.3448
Min	.2477	.2439	.2096	.0914	.0838	.2477	.1372
Avg	1.3677	1.8992	.4307	1.5422	1.3558	2.2789	1.1469

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244074 / 33/11 KV LINGNOOR

Feeder No / Name : 201 / 11 KV lignoor gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.33	.3117		.2593	.2585	.3094	.3223
2	.3087	.2694		.2631	.2454	.3041	.3079
3	.3071	.2671		.2616	.2263	.2934	.1562
4	.3071	.2648		.2608	.2271	.2866	.144
5	.3094	.2679		.2646	.2229	.2873	.1524
6	.3201	.3048		.276	.2336	.2926	.1623
7	.3139	.2854		.2454	.2306	.2454	.1349
8	.2252	.2237		.2245	.226	.2282	.1196
9	.2728	.2987		.279	.1494	.2549	.1265
10	.3201	.3318		.3666		.3719	.1905
11	.3254	.3814		.3494		.4199	.1974
12	.3264	.3768		.3314		.4031	.176
13	.3856	.3725		.3119	.2736	.3959	.1959
14	.3588	.379		.317	.2843	.3422	.1738
15	.317	.3277		.2928	.2698	.3231	.157
16	.3132	.2927		.2745	.2218	.3071	.1334
17	.2644	.1784		.3041	.1753	.1448	.1364
18	.2382	.0945		.1776	.4058	.2911	.1296
19	.3677	.4039			.4281	.3892	.1677
20	.5148	.4919	.2614		.4901	.5289	.2522
21	.5258	.5039	.2427		.5465	.4962	.2576
22	.4862	.2667	.2286		.4885	.4732	.2218
23	.4255	.2134	.1509	.2782	.3993	.3856	.1913
24	.1699	.3466	.1267	.1578	.3673	.1875	.3193
Max	.5258	.5039	.2614	.3666	.5465	.5289	.3223
Min	.1699	.0945	.1267	.1578	.1494	.1448	.1196
Avg	.3347	.3106	.2021	.2748	.3033	.3317	.1886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244074 / 33/11 KV LINGNOOR

Feeder No / Name : 202 / 11 KV Shindewadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.193	.1665		2.6635	.1457	.9289	.1639
2	.1853	.1665		2.593	.1457	.823	.1639
3	.1853	.1665		2.5854	.1653	.8154	.061
4	.1853	.1665		2.5778	.1653	.8908	.061
5	.1853	.1676		2.6082	.184	.8603	.061
6	.2271	.2057		2.9024	.184	.913	.061
7	.2042	.2042		2.6353	.1724	.6705	.061
8	1.2218	1.2254		.18	.1444	.9322	1.1355
9	3.6054	3.6224		.1596		1.0974	1.3641
10	3.7921	3.8775		.1284		1.1355	1.4403
11	3.4766	3.8866		.1135		1.7577	1.4098
12	3.6077	3.5829		.1391	.0381	1.3565	.061
13	3.5261	3.6762		.1742	.0457	1.1088	.0686
14	1.2346	3.594		.1818	.0533	1.0845	.0686
15	.3582	2.938		.1894	.0381	1.3359	.0686
16	2.6939	2.7244		.202	.8612	1.3794	.061
17	.1806	.192		.1993	.4191	.0457	.0686
18	.1566	.1859		.0457	.0381	.1665	.0533
19	.246	.2572			.2082	.2158	.0914
20	.2724	.2724	.1886		.2058	.2362	.0991
21	.2724	.0838	.1698		.9779	.2172	.0914
22	.2362	.0762	1.8275	.0076	1.0601	.1981	.0838
23	.2195	.061	1.9616	.1642	1.0403	.1629	.0762
24		.1132	1.6194		.0943		.0943
Max	3.7921	3.8866	1.9616	2.9024	1.0601	1.7577	1.4403
Min	.1566	.061	.1698	.0076	.0381	.0457	.0533
Avg	1.1507	1.3172	1.1534	1.0225	.3041	.7971	.2904

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244074 / 33/11 KV LINGNOOR

Feeder No / Name : 203 / 11Kv Landgewadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0572		.9945	.0381	.7293	.0572
2	.0381	.0572		.9945	.0381	.6962	.0572
3	.0381	.0572		.9945	.0381	.6962	
4	.0381	.0381		.9945	.0572	.6962	
5	.0572	.0381		.9945	.0572	.6962	
6	.0747	.0572		.9779	.0572	.6962	
7	.056	.0381		1.0774	.0572	.779	
8	.0373	.0381		.056	.0381	.0566	
9	1.1437	1.1305		.0572		.8785	
10	1.2163	1.1961		.0381		1.0159	
11	1.1523	1.2266		.0572		.0429	
12	1.1822	1.1305		.0381		.0762	
13	1.2323	1.1336		.0572		.0572	
14		1.0722		.0572		.0572	
15		1.1012		.0762		.0762	
16	1.0883	1.0623		.0762		.9335	
17	.0762	.0328		.0572			
18	.0572	.0572			.0572	.0572	
19	.0572	.0572				.0762	
20	.0762	.0953	.0934		.0747	.0762	
21	.0762		.0934		.0747	.0762	
22	.0762		1.1105		.8453	.0762	
23	.0572		1.1603	.0381	.8122	.0762	
24		.0572	1.0442		.779		.0572
Max	1.2323	1.2266	1.1603	1.0774	.8453	1.0159	.0572
Min	.0373	.0328	.0934	.0381	.0381	.0429	.0572
Avg	.3747	.4635	.7004	.4243	.2160	.3919	.0572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244074 / 33/11 KV LINGNOOR

Feeder No / Name : 204 / 11 kv Lingnoor

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.3359	5.993		.7167	.4398	.4382	.3618
2	6.2887	5.7308		.6879	.4519	.4321	.4144
3	6.1927	5.4344		.6841	.439	.4267	1.7208
4	6.0227	5.4195		.6803	.4436	.4359	1.8724
5	6.5249	5.6181		.6803	.4215	.4671	1.9433
6	2.1719	6.3542		.8802	.4658	.4944	2.1597
7	.1133	6.4983		.4588	.455	.4915	2.6558
8	.1806	.6447		.9789	.4306	.5297	.189
9	.1656	.6089		6.6864		.5348	.1882
10	.2278	.5333		6.1523		.2187	.1875
11	.4992	.5316		6.1283			.1791
12	.679	.5548		6.1702			.048
13	.6371	.5694		5.3803		.3681	
14	.1357	.518		5.9469	.0518	.3993	.0434
15	.6291	.1463		5.9541	1.217	.3852	.2134
16	.6836			6.1827	1.1888	.458	.2263
17	.772			.4451	.0046	.2362	.221
18	.6943	.2774		.2568	.0739	.4054	.2462
19	.881	.8703			1.8287	.4923	.2667
20	.9508	.9017	.4338		.6165	.5716	.3125
21	1.033	.4344	.4527		1.6259	.5731	.3079
22	6.3398	3.3074	.4338		.5112	.4885	.3056
23	6.3426	3.5056	.3772	.032	.4725	.4511	.2774
24	3.5292	6.4401	.3772	.1928	.4557	.2088	.4226
Max	6.5249	6.4983	.4527	6.6864	1.8287	.5731	2.6558
Min	.1133	.1463	.3772	.032	.0046	.2088	.0434
Avg	2.4179	2.7678	.4149	2.7648	.6102	.4321	.6419

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244074 / 33/11 KV LINGNOOR

Feeder No / Name : 205 / 11 KV Khatav ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4918	1.5912		.3772	***	.2987	1.4918
2	1.4918	1.4918		.3772	***	.2987	1.4746
3	1.4918	1.4746		.3772		.2987	
4	1.4586	1.4582		.3772		.2987	
5	1.5912	1.5083		.3772		.0373	
6	2.0222	1.9448		.3961		.4108	
7	1.9757	1.8442		.3395		.3395	***
8	.2241	.2263		.1867		.3395	
9	.2614	.2263		1.8233		.3361	
10	.2452	.2241		1.8564		.2058	
11	.1494			1.8399		.2641	
12	.2829			1.6907		.3547	
13	.3361			2.0645		.2987	
14				1.5402		.2957	
15	.3018			2.0388		.3361	
16	.3018			2.0056		.3361	
17	.3395			.2641			
18	.3584				.1459	.3475	
19	.4715	.5281			.3734	.4338	
20	.5093	.5093	.0448		.4527	.5093	
21	.415		.4481		.4108	.4904	
22	.2286		.415		.3772	1.8399	
23	1.8023		.0305	***	.3395	1.6575	
24		1.7238	.3429	***	.3395		1.4746
Max	2.0222	1.9448	.4481	152.6235	152.6046	1.8399	76.208
Min	.1494	.2241	.0305	.1867	.1459	.0373	1.4746
Avg	.8068	1.1347	.2563	16.9985	34.1622	.4558	20.1623

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 201 / 11 KV Arag gav

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6645	.7049	.3258	.6355	.6611	.6868	.6386
2	.6569	.6868	.3258	.6158	.6354	.6792	.6127
3	.6493	.6645	.3258	.6005	.643	.6459	.6051
4	.6569	.6583	.3109	.5929	.6687	.6459	.5898
5	.6569	.7021	.3109	.2972	.7021	.6973	.5974
6	.3658	.7836	.3881	.3353	.7278	.8124	.6569
7	.8173	.8166	.4251	.6577	.6647	.8061	.6767
8	.7038	.7522	.4163	.7154	.6322	.7757	.6577
9	.7173	.6289		.6618		.694	.6872
10	.8158	.7278	.3544	.7743		.7785	.714
11	.7304	.7213	.394	.908		.8166	.7568
12	.7638	.831	.4887	.9711	.4725	.8375	.76
13	.8824	.8897	.4252	.9431	.9561	.8802	.3658
14	.8602	.8413	.3856	.8124	.8623	.8222	.4039
15	.762	.8413	.3429	.8179	.887	.7819	.4115
16	.8234	.8539	.3294	.8459	.8973	.772	.4344
17	.8687	.8318	.3681	.8516	.8869	.503	.381
18	.9059	.887	.4344	.4039	.9536	.9865	.4191
19	1.1698	1.0298			1.1736	1.1546	.5411
20	1.2222	1.1279	.543		1.2056	1.2479	.5563
21	1.0196	1.0379	.543	.3201	1.1462	1.1751	.5182
22	.9533	.9327	.4344	.9507	.9815	.9533	.4572
23	.8097	.7728	.3439	.8021	.8063	.7903	.4115
24	.3439	.362	.362	.3077	.3439	.3439	.362
Max	1.2222	1.1279	.543	.9711	1.2056	1.2479	.76
Min	.3439	.362	.3109	.2972	.3439	.3439	.362
Avg	.7842	.7953	.3899	.6737	.8051	.8036	.5506

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 202 / Arag mix Laxmiwadi
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6178	.6824	.3018	4.0588	.6824	.988	.5649
2	.599	.6824	.2829	3.8209	.6483	.9726	.5308
3	.599	.6824	.2829	3.7855	.6824	.9726	.5496
4	.6178	.6901	.2829	1.9281	.7582	.9955	.5496
5	.6331	.7166	.3018	1.9281	.7848	1.0183	.5572
6	.7543	.7771	.3018	2.2634	.8983	1.0753	.6443
7	.7506	.7848	.3395	4.9626	.3201	1.1568	.599
8	.5689	.6223	.3018	.6559		.5689	.6331
9	4.2867	5.0582	.3961	.652		4.5435	4.4897
10	5.4321	5.1318		.7013		5.0421	5.0183
11	4.8582	5.1326		.6977		5.063	5.3231
12	4.7257	5.0358		.1067		5.0183	1.8214
13	4.5653	4.4574			.8871	4.7992	
14	1.2269	4.7744		.0305	3.0677	5.0307	
15	1.6994	5.0328		.743	.6828	5.407	
16	4.1217	4.1704		.7659	.7053	5.6023	2.6368
17	.7314	.4814	.3772	.8113	.7053	.2058	.6325
18	.6066	.6291	.415	.4039	.7467	.652	.3353
19	.8185	.8185			.9244	.8148	.381
20	1.0123	.9705	.5093		.723	.9858	.5106
21	.9745	.8987	.4527		1.0199	.891	.5106
22	.891	.7887	2.2939	.739	4.0215	.743	.4801
23	.7318	.6788	2.1628	.6748	4.1511	.6295	.4344
24	.6712	.6596	.3018	2.3998	1.3683	.7305	.6792
Max	5.4321	5.1326	2.2939	4.9626	4.1511	5.6023	5.3231
Min	.5689	.4814	.2829	.0305	.3201	.2058	.3353
Avg	1.7706	2.0982	.5815	1.6065	1.2515	2.2461	1.3277

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 203 / 11 KvAshoknagar

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7652	1.7976	1.7004	.1509	.1132	.1509	2.1464
2	1.7859	1.7124	1.6194	.1509	.1132	.1509	2.0388
3	1.7695	1.6004	1.6194	.1698	.1132	.1509	2.0222
4	1.7695	1.4883	1.5546	.1698	.1132	.1509	2.0222
5	1.7695	1.5546	1.5729	.1698	.132	.1509	1.989
6	1.8679	1.8842	1.8351	.1698	.1509	.1698	2.2874
7	2.251	1.9498	1.989	.1698		.1698	2.5526
8	.132	.132	.132	.1132		.1509	.1509
9	.1132	.0943		2.2186		.1509	.1509
10	.1132	.1132		2.3525		.132	.1698
11	.0754	.132		2.4777		.1509	.1698
12	.132		2.0165	2.2834		.1509	.132
13	.1132		1.9204	1.9919	1.9989	.1509	
14			1.9364	2.1125		.1509	
15	.1132		1.9524	2.0317	1.9433	.1698	
16	.1132		2.0399	1.9919	1.9989	.1509	
17	.132	.132	.1132	.1132	.132		
18	.0943	.1509	.1132			.1509	
19	.1886	.1698			.2263	.1886	
20	.2075	.2263	.1886		.2263	.1886	
21	.1886	.2263	.1886		.2263	.2075	
22	1.8623	1.9662	.1698	.132	.1886	2.2939	
23	1.9498	1.8399	.1698	.1132	.1509	2.4577	
24	1.7814	1.9006	1.6842	.1698	.1132	.1509	2.3266
Max	2.251	1.9662	2.0399	2.4777	1.9989	2.4577	2.5526
Min	.0754	.0943	.1132	.1132	.1132	.132	.132
Avg	.8821	1.0037	1.2258	.9626	.4963	.3518	1.3968

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 204 / railway station Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2748	2.4562	1.004	.2722	.1995	.2344	1.9309
2	2.2317	2.3266	.9717	.2722	.1987	.2139	1.864
3	2.2111	2.1986	.9717	.2715	.1972	.2117	1.8374
4	2.1967	2.082	.9717	.2692	.1964	.2117	1.8052
5	2.2256	2.1424	1.004	.2646	.1979	.2336	1.8181
6	2.4303	2.5385	1.1142	.2852	.229	.192	2.0378
7	2.7543	2.702	1.1142	.2875	.0907	.1949	2.4827
8	.2684	.2757	.132	.2985		.0815	.195
9	.2002	.1684		2.4269		.1585	.1249
10	.161	.1511	1.3272	2.2858		.1038	.1447
11	.0566	.0983	1.2955	2.5242		.065	.17
12	.065		1.2803	2.6782		.0581	.194
13	.0833		1.1984	2.7369	1.4805	.0574	.0823
14	.0213		1.1498	2.6338	.1974	.0754	.0869
15	.1402		1.1203	2.4067	2.2386	.0754	.0884
16	.1008	.0023	1.1069	2.3007	2.3823	.0635	.0907
17	.1623	.1851	.0943	.0868	.1592	.077	.0991
18	.179	.2547	.0943	.093	.1608	.1644	.1128
19	.2972	.2949			.185	.2524	.1257
20	.3239	.3504	.1886		.2965	.3443	.1547
21	.3254	.4129	.1698		.301	.4091	.1654
22	2.5076	2.1293	.132	.2153	.2745	2.1422	1.0852
23	2.6117	2.3201	.132	.2094	.2458	2.1513	1.1767
24	2.4401	2.363	1.004	.2402	.2185	1.2418	2.0553
Max	2.7543	2.702	1.3272	2.7369	2.3823	2.1513	2.4827
Min	.0213	.0023	.0943	.0868	.0907	.0574	.0823
Avg	1.0945	1.2726	.7990	1.0980	.4973	.3756	.8303

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 205 / Malwadi Ag feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3466	.2768	.132	3.9182	.217	2.9492	.2737
2	.3451	.2737	.132	3.8221	.2162	2.87	.2654
3	.3458	.2737	.132	3.7771	.204	2.8418	.2646
4	.342	.2722	.132	3.7689	.2025	2.8395	.2638
5	.3504	.2737	.132	3.8177	.2139	2.8601	.276
6	.3989	.3149	.132	4.3945	.2821	2.9927	.3344
7	.3529	.3573	.1132	5.0138	.1318	3.3882	.3285
8	.3797	.3452	.1886	.4648		.4876	.3003
9	4.3878	4.6472		.4549		3.8409	3.5159
10	5.3445	5.4618		.3399		4.2044	4.5537
11	5.088	4.9469		.3443		4.4122	5.0432
12	4.553	5.4064		.0511		4.446	2.6132
13	4.6372	5.2126			.4706	4.3016	
14	1.2925	5.4799		.0206	2.5975	4.3115	
15	2.0607	5.4819		.3557	.2949	4.3515	
16	4.0861	5.5472		.4392	.2768	4.3279	2.0576
17	.3829	.3247	.1698	.4891	.3186	.3425	.3788
18	.4018	.3624	.2075	.2545	.3399	.1844	.1966
19	.389	.3791			.3397	.3988	.1997
20	.4354	.4081	.2263		.4012	.4709	.2515
21	.4142	.4066	.2263		.4389	.4187	.2378
22	.3634	.3822	2.0153	.3799	2.9885	.371	.208
23	.3134	.3012	1.9334	.2946	3.0739	.3269	.1913
24	.323	.2798	.132	1.9631	1.722	1.4818	.2951
Max	5.3445	5.5472	2.0153	5.0138	3.0739	4.446	5.0432
Min	.3134	.2722	.1132	.0206	.1318	.1844	.1913
Avg	1.5556	1.9756	.4003	1.7182	.7753	2.4758	1.0500

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 202 / 11 KV BHIVARGI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-APR-17
HR	Load (MW)
24	.1905
Max	.1905
Min	.1905
Avg	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 203 / 11 KV ANKALGI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17
HR	Load (MW)
24	.2858
Max	.2858
Min	.2858
Avg	.2858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 204 / 11 KV SANKH GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17
HR	Load (MW)
24	.2858
Max	.2858
Min	.2858
Avg	.2858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 205 / 11 KV ANKALGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-APR-17
HR	Load (MW)
24	.2858
Max	.2858
Min	.2858
Avg	.2858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 206 / 11 KV ASANGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-APR-17
HR	Load (MW)
24	.2858
Max	.2858
Min	.2858
Avg	.2858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 207 / 11 KV SANKH AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-APR-17
HR	Load (MW)
24	.2858
Max	.2858
Min	.2858
Avg	.2858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGI

Feeder No / Name : 201 / 11 KV AKKALWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9602	.9831	.8097	.1524	.0953	.0762	.9717
2	1.0402	1.065	.8192	.1334	.0953	.0762	1.0402
3	1.1469	1.0526	.8322	.1334	.0953	.0762	1.0526
4	1.2125	1.1603	.8907	.1334	.1143	.0953	1.1469
5	1.3413	1.2431	.9221	.1524	.1143	.0953	1.3108
6	1.3717	1.2717	1.0174	.2096	.1143	.0953	1.4413
7	1.3927	1.3927	1.2574	.2096	.1334	.1334	1.4413
8	.1524	.2096	.1334	.1334	.1334		.1524
9	.1334	.1334	.9717	.9116	1.1336	.0953	.1143
10	.1334	.1524	.9831	1.2431	1.1012	.1524	.1334
11	.1143	.1143	1.1142	1.2289		.1524	.1143
12	.1334	.1143	1.065	1.0526		.1334	.0953
13	.1334	.0953	.9602	1.012		.1143	
14		.0953	1.0402	1.0202		.1334	
15			.8907	1.004		.1334	
16	.1334	.0953	1.0526	.9878		.0953	
17	.0953	.1334	.1143	.0953		.1143	
18	.1334	.1524	.1143	.1143		.1334	
19	.1524	.1905	.1524	.1334		.1715	
20	.1715	.1715	.1905	.1715		.1715	
21	.1905	.1715	.1524	.1715		.1524	
22	1.1469	1.0159	.1524	.1524		1.1603	
23	.9717	.9012	.1334	.0953	.0953	.9945	
24	.9602	.9717	.8097	.1334	.0953	.0953	.9717
Max	1.3927	1.3927	1.2574	1.2431	1.1336	1.1603	1.4413
Min	.0953	.0953	.1143	.0953	.0953	.0762	.0953
Avg	.6010	.5603	.6908	.4494	.2768	.2022	.7682

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGI

Feeder No / Name : 202 / 11 KV BORGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1715	1.0517	.9842	1.0753	.1524
2	.1524	.1715	.1715	1.1092	.9998	.9804	.1715
3	.1905	.1524	.1905	1.1574	1.1043	1.085	.1715
4	.2286	.1905	.1905	1.2631	1.2803	1.166	.1905
5	.2858	.2286	.2477	1.5746	1.5364	1.1822	.2286
6	.2858	.3048	.3048	1.9784		1.2163	.2858
7	.2858	.3239	.2667	1.9662	1.9364	1.5684	.2858
8	.2477	.2667	.2286	.2477	.2286	.2096	.2858
9	1.6324	1.6644	.1905	.1905	.1905	1.4083	1.5497
10	1.531	1.6204	.1715	.1715	.1524	1.4723	1.1574
11	1.3279	1.5779	.1905	.1715		1.4089	1.387
12	1.387	1.5546	.1715	.1905		1.4089	.1334
13	1.3717	1.4022	.1905	.2096		1.4175	
14		1.5895	.1715	.2096		1.3108	
15			.1524	.2286		1.326	
16	1.4419	1.6004	.1143	.2096		1.4661	
17	.1715	.1524	.1524	.1905		.1715	
18	.1524	.1524	.1143	.2477		.1905	
19	.2096	.2096	.2286	.2858		.2477	
20	.2286	.2477	.2667	.2667		.2477	
21	.2286	.2286	.2477	.2477		.2096	
22	.1905	.1905	1.3757	1.1405		.1905	
23	.1715	.1715	1.186	.9998	.9962	.1715	
24	.1524	.1715	.1715	1.0802	.9842	.9804	.1524
Max	1.6324	1.6644	1.3757	1.9784	1.9364	1.5684	1.5497
Min	.1524	.1524	.1143	.1715	.1524	.1715	.1334
Avg	.5466	.6228	.2861	.6829	.9448	.9213	.4732

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGI

Feeder No / Name : 203 / 11 KV BALGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5684	1.6876	1.4251	.1524	.1334	.1334	1.5061
2	1.6804	1.7204	1.5565	.1715	.1334	.1334	1.5203
3	1.8842	1.7652	1.5684	.1715	.1334	.1107	1.8623
4	1.9662	1.9062	1.6194	.1905	.3048	.1898	1.9334
5	2.1795	1.989	1.7269	.2477	.3429	.2372	2.13
6	2.3663	2.3739	1.7465	.381	.4001	.362	2.323
7	2.4577	2.3739	2.0454	.3048	.3429	.362	2.4756
8	.2667	.2477	.2477	.2477	.2477	.3048	.2286
9	.2477	.2286	1.8785	2.0388	2.0165	.1905	.1524
10	.2667	.2096	1.8023	2.0719	1.9845	.1524	.1524
11	.2477	.1905	1.9006	2.0481		.1905	.1905
12	.2286	.2096	1.7695	1.9595		.1524	
13	.2286	.2286	1.6484	1.8623		.1334	
14		.1905	1.6004	1.8947		.2096	
15			1.8461	1.8947		.1905	
16	.2477	.1905	1.7814	1.8084		.1905	
17	.2667	.2286	.2286	.1715		.1715	
18	.1905	.2096	.2477	.2477		.1715	
19	.2286	.2286	.3429	.2286		.2667	
20	.2477	.2858	.2858	.2477		.2858	
21	.2286	.2477	.2286	.2096		.2667	
22	1.8515	1.6876	.1715	.1905		1.8564	
23	1.7004	1.5402	.1524	.1715	.1524	1.6244	
24	1.5684	1.6194	1.4251	.1524	.1524	.1334	1.5061
Max	2.4577	2.3739	2.0454	2.0719	2.0165	1.8564	2.4756
Min	.1905	.1905	.1524	.1524	.1334	.1107	.1524
Avg	1.0054	.9374	1.2186	.7944	.5287	.3341	1.3317

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721]

BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGI

Feeder No / Name : 204 / 11 KV AKKALWADI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0572	.0762	.0762	.0762	.0572
2	.0762	.0953	.0572	.0762	.0762	.0762	.0762
3	.0953	.0953	.0762	.0762	.0762	.0762	.0762
4	.0953	.1143	.0762	.0953	.0953	.0953	.0953
5	.1143	.1334	.0953	.1334	.0953	.0953	.0953
6	.1143	.1715	.0953	.1524	.0953	.0953	.0953
7	.0953	.1524	.0953	.1524	.1143	.1334	.1143
8	.0953	.1524	.0953	.0953	.1143	.1334	.0762
9	.0762	.1143	.0762	.0953	.0953	.1334	.0762
10	.0572	.0953	.0762	.0953	.0762	.1143	.0953
11	.0572	.0762	.0762	.0762		.0762	.0762
12	.0762		.0762	.0762		.0953	.0762
13	.0762		.0762	.0953		.0762	
14	.0572		.0762	.0572		.0762	
15	.0762		.0762	.0762		.0762	
16	.0953	.0762	.0953	.0953		.0953	
17	.0953	.0762	.0953	.0953		.0762	
18	.1334	.0953	.1143	.1334		.1143	
19	.1715	.1143	.1715	.1715		.1143	
20	.1715	.1334	.2096	.2096		.1334	
21	.1905	.0953	.1905	.1905		.0953	
22	.1334	.0953	.1143	.1524		.0762	
23	.0762	.0762	.0953	.1143	.0762	.0762	
24	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Max	.1905	.1715	.2096	.2096	.1143	.1334	.1143
Min	.0572	.0762	.0572	.0572	.0762	.0762	.0572
Avg	.0992	.1058	.0977	.1112	.0889	.0953	.0835

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721]

BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGI

Feeder No / Name : 205 / 11 KV BORGI BALGAON
GAVTHAN Feeder KV- 11 /
OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0762	.0762	.0953	.0762	.0762
2	.0762	.0762	.0762	.0762	.0953	.0762	.0762
3	.0953	.0953	.0953	.0953	.1143	.0762	.0953
4	.1334	.1334	.1524	.1143	.1334	.0953	.1334
5	.1715	.1715	.1905	.1334	.1524	.1524	.1715
6	.2096	.2096	.1905	.1905	.1715	.2096	.1905
7	.1905	.1905	.2096	.1715	.1905	.1715	.1524
8	.1334	.1143	.1143	.1334	.1334	.1334	.0953
9	.0762	.0953	.1143	.1143	.0762	.1143	.0953
10	.0762	.0953	.0953	.0953	.0762	.0953	
11	.0762	.0953	.1143	.0953		.0953	.1143
12	.0953		.0953	.0953		.1143	.0953
13	.1143		.0953	.0953		.0953	
14	.0953		.0953	.0953		.0953	
15	.0953		.0953	.1143		.0953	
16	.1143	.1524	.1143	.1524		.1143	
17	.1143	.1334	.1334	.1524		.1334	
18	.1143	.1524	.1715	.1905		.1715	
19	.1715	.1905	.2096	.1905		.1715	
20	.1905	.2096	.2096	.1524		.2096	
21	.1905	.1715	.1715	.1524		.1524	
22	.1143	.1143	.1334	.1143		.1334	
23	.0953	.0953	.0953	.0953	.0953	.0953	
24	.0762	.0953	.0762	.0953	.0953	.0953	.0762
Max	.2096	.2096	.2096	.1905	.1905	.2096	.1905
Min	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Avg	.1207	.1334	.1302	.1246	.1191	.1239	.1143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 201 / 11 KV SUSLAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2918	.3075			1.6892	2.0481	.2987
2		.3217			1.722	2.0485	.2614
3	.3229				1.7506	2.0165	.2614
4		.3772			1.845	2.0965	.2926
5		.3944				2.1538	.3142
6		.369			2.4996	2.3758	.3547
7	.3217	.3541			2.4215		.4481
8	.3075	.3075			.2865	.4207	.4854
9	1.6912	2.9835		.2152	.3045	2.5101	
10	.1823	3.0001		.2303	.3142	2.9014	
11	2.46	2.9492		.2152	.3142	2.7168	
12	2.6105	2.8826		.2303	.2957	2.8166	
13	.2949	3.0849		.2152	.3045	2.6063	
14		3.103		.1991	.3294	2.7168	
15		2.7982		.2147	.2774	2.7759	
16	2.1525		2.7368	.2152	.2103	2.5968	
17	.3229		.2486	.2457	.2804	.4119	
18	.3217		.4527		.3109	.4119	
19	.3429		.3806	.2918	.3475	.4656	
20	.3605		.499	.3229	.4207	.4298	
21	.3265		.432	.3378	.4207	.3403	
22			.439		2.3148	.3582	
23			2.2672		2.1376	.2614	
24	.3075	.3233		2.332	1.6104	2.3122	.2743
Max	2.6105	3.103	2.7368	2.332	2.4996	2.9014	.4854
Min	.1823	.3075	.2486	.1991	.2103	.2614	.2614
Avg	.7886	1.5704	.9320	.4050	.9742	1.7301	.3323

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 202 / 11 KV UMADI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2144	.2306			.2401	.2374	.2454
2		.2451			.2406	.2401	.2507
3	.2303				.2578	.2743	.2534
4		.2764			.2743	.3086	.2534
5		.2921				.3086	.2896
6		.3067			.394	.4298	.3258
7	.3067	.337			.4344	.394	1.0029
8	.3064	.3075			.3506	.394	.3658
9	.2914	.2686		.2058	.3506	.3224	
10	.2451	.2835		.206	.3155	.2865	
11	.2139	.2715		.2406	.333	.2534	
12	.1845	.2454		.2583	.2804	.2561	
13	.1845	.2064		.275	.3155	.3224	
14		.2427		.2401	.3155	.3224	
15		.2601		.206	.2743	.3224	
16	.2451		.2149	.2401	.3292	.2865	
17	.2767		.2454	.275	.2926	.3292	
18	.2457		.3125		.3881	.2896	
19	.3075		.3982	.3772	.639	.4024	
20	.3378		.4306	.412	.4207	.4298	
21	.3075		.4024	.3781	.4024	.4024	
22			.3456		.3155	.3582	
23			.2915		.2713	.3224	
24	.2591	.246		.2865	.2918	.2374	.2743
Max	.3378	.337	.4306	.412	.639	.4298	1.0029
Min	.1845	.2064	.2149	.2058	.2401	.2374	.2454
Avg	.2598	.2680	.3301	.2770	.3360	.3221	.3624

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 203 / 11 KV SONALGI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9963	1.9631	1.6804		.3839	.4435	2.2211
2		1.9963	1.7284		.369	.4755	2.2119
3	2.1445		1.7814		.3839	.4755	2.5101
4		2.1445	1.8138		.3997	.4481	2.6216
5		2.3005	1.9433			.5228	
6		2.4539	2.2348		.4656	.6036	2.6871
7	2.5369	2.46	2.1778		.4298	.5975	2.6216
8	.3064	.3382	.2896			.5544	.3932
9	.369	.4294	1.7718	1.9065	2.2405	.5175	
10	.3993	.421	1.8229	2.1191	2.2809	.5544	
11	.369	.3887	1.8442	2.2085	2.3845	.439	
12	.3839	.3725	1.9559	2.1445	2.3644	.4435	
13	.3993	.3521	1.9656	2.1498	2.3868	.3582	
14		.3841	2.1376	2.1832	2.1052	.4298	
15		.021	2.2672	2.1498	2.0557	.4298	
16	.2921	.4534	2.2672	2.214	2.0309	.4656	
17	.3676	.4372	.583	.0365	.407	.4656	
18		.4858			.3582	.4298	
19	.3685	.4372		.3844	.5373	.4115	
20	.3829	.4534		.3685	.6516	.4656	
21	.3681	.4141		.3997	.6401	.4908	
22		1.6194			.6468	2.2085	
23		1.6518	.421		.5487	2.2291	
24	1.9065	1.8994	1.6842	.4534	.3681	.4805	2.1605
Max	2.5369	2.46	2.2672	2.214	2.3868	2.2291	2.6871
Min	.2921	.021	.2896	.0365	.3582	.3582	.3932
Avg	.8394	1.0381	1.7037	1.4398	1.1108	.6225	2.1784

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 204 / 11 KV UMADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6433	.6449	.6722		2.0705	2.4615	.6089
2		.6765	.6401		2.1191	2.5069	.6089
3	.6433		.6642		2.1525	2.4905	.6268
4		.6765	.7042		2.1805	2.5194	.6984
5		.6893	.7773			2.4615	.7522
6		.7055	.8421		2.9007	2.6871	.7522
7	.6765	.6757	.9717		2.8502	2.5606	1.0029
8	.615	.6457	.8421		.6783	.6554	.9671
9	2.5121	2.9835	.8745	.6457	.6718	2.536	
10	2.5975	2.982	.8962	.6142	.7537	2.5692	
11	2.46	2.9656	.8802	.615	.7293	2.5692	
12	2.3802	2.915	.8322	.6449	.7293	2.5396	
13	2.46	2.9165	.8097	.615	.7625	2.6189	
14		2.8988	.7935	.5835	.6762	2.7183	
15		2.915	.7773	.615	.6859	2.6871	
16	2.1472		.7125	.6142	.6135	2.6216	
17	.615		.6802	.6457	.5959	.5898	
18	.6449		.4902		.5992	.663	
19	.615		.6882	.6112	.639	.663	
20	.6449		.9069	.615	.6783	.6449	
21	.6457		.8421	.6142	.6783	.663	
22			.8097		2.5911	.663	
23			2.5926		2.4939	.6516	
24	.6142	.6127	.7125	2.5911	2.0526	2.4291	.631
Max	2.5975	2.9835	2.5926	2.5911	2.9007	2.7183	1.0029
Min	.6142	.6127	.4902	.5835	.5959	.5898	.6089
Avg	1.3072	1.7269	.8505	.7711	1.3436	1.9238	.7387

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 205 / 11 KV SUSLAD GAVTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1031	.0859			.0515	.0509	.0701
2		.0859			.0686	.0686	.0732
3	.1029				.0858	.0514	.0732
4		.0857			.1029	.0857	.0914
5		.103				.0857	.1254
6		.1203			.1543	.1227	.1417
7	.014	.1375			.1612	.1075	.1595
8	.1375	.012			.1254	.1075	.1063
9	.1375	.0537		.0087	.0914	.0716	
10	.12	.0362		.0069	.0716	.0701	
11	.0105	.0554		.0859	.0895	.0686	
12	.0858	.0934		.0069	.1075	.0686	
13				.0516	.1075	.0686	
14				.0086	.1052	.0732	
15		.0693		.0857	.0876	.0732	
16	.0103		.0687	.0103	.1017	.0716	
17	.0125		.0537	.0123	.1214	.1075	
18	.0123		.0686		.1029	.1663	
19	.0139		.1052	.1373	.1612	.1663	
20	.1375		.1387	.0123	.1463	.1478	
21	.12		.0934	.1206	.1463	.1075	
22			.0739		.0857	.0895	
23			.0739		.0848	.0895	
24	.0125	.0104		.0549	.007	.1075	.0724
Max	.1375	.1375	.1387	.1373	.1612	.1663	.1595
Min	.0103	.0104	.0537	.0069	.007	.0509	.0701
Avg	.0687	.0730	.0845	.0463	.1029	.0928	.1015

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 201 / 11 KV MADGYAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1372	.1578	.6401	.905	.6249	.1402
2	.1372	.1372	.1578	.6401	.905	.6249	.1402
3	.1372	.1372	.1578	.6249	.8764	.6249	.1402
4	.1372	.1372	.1578	.6249	.8573	.6249	.1402
5	.2572	.2401	.2058	.6859	.9835	.6249	.1753
6	.3429	.1715	.2804	1.3603	1.2717		.2804
7	.3429	.3506	.3155	1.4403	1.6108	1.0936	.3506
8	.1715	.2229	.2454	.2279	.3391	.1562	.2804
9	1.0936	1.2193	.2103	.1715	.2629	.7621	
10	1.0155	1.0669	.1402	.1372	.2241	.6687	
11	.9145	1.0402	.1227	.1848	.2241	.8509	
12	.8383	.9412	.1227	.2218	.1372	.7716	
13		.8459	.1227	.2218	.12	.7133	
14		.823	.1227	.2218	.12	.8459	
15		.8916	.1227	.1829	.1227	.8859	
16		.8916	.1543	.1829	.1227	1.0433	
17		.1753	.1753	.2241	.1402	.1402	
18	.1543	.1715	.2103	.2801	.1578	.1402	
19	.298	.2401	.2715	.2801	.2804	.2103	
20	.3155	.2454	.2743	.2241	.3155	.2454	
21	.2629	.2454	.2481	.2241	.2279	.2454	
22	.2058	.1715	.6192	.8402	.8907	.1753	
23			.7621	.924	.6718	.1578	
24	.1372	.1715	.1578	.6859	.905	.6249	.1402
Max	1.0936	1.2193	.7621	1.4403	1.6108	1.0936	.3506
Min	.1372	.1372	.1227	.1372	.12	.1402	.1402
Avg	.3833	.4641	.2298	.4772	.5280	.5589	.1986

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 202 / 11 KV SONYAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3201	.3201	.3201	1.4842	1.2811	1.406	.2846
2	.3201	.3201	.3201	1.4842	1.3435	1.406	.2846
3	.3201	.3201	.3201	1.5023	1.3435	1.406	.2846
4	.3201	.3201	.3201	1.5023	1.3435	1.406	.2846
5	.4049	.421	.3521	1.6804	1.829	1.406	.3521
6	.4858	.4999	.4481	2.5149	1.7814	1.9814	.4481
7	.5247	.5401	.5506	2.1052	2.1052	1.9814	.5535
8	.3772	.3963	.4744	.4111	.6401	.2812	.4012
9	1.9528	2.1091	.3841	.3521	.6401	1.5242	
10	1.8747		.3521	.3201	.4801	1.4861	
11	1.6766	1.7528	.3521	.3953	.5121	1.6347	
12	1.5604	1.6347	.3521	.3953	.3163	1.5146	
13		1.6347	.3163	.3906	.3201	1.4662	
14		1.6347	.3163	.4321	.3201	1.5003	
15		1.709	.3125	.5468	.3201	1.5432	
16	1.6804	1.7833	.125	.6401	.3201	1.8534	
17	.3163	.3086	.3749	.6478	.3163	.3125	
18	.3479	.3395	.4111	.7287	.3479	.3437	
19	.4481	.3521	.4744	.8145	.4161	.3841	
20	.4801	.3841	.4801	.4572	.4161	.4161	
21	.4161	.4161	.3479	.4877	.3125	.3898	
22	.421	.3395	1.2346	1.1717	1.6204	.3201	
23			1.7394	1.2498	1.3889	.2846	
24	.3201	.3521	.3201	1.448	1.2811	1.406	.2846
Max	1.9528	2.1091	1.7394	2.5149	2.1052	1.9814	.5535
Min	.3163	.3086	.125	.3201	.3125	.2812	.2846
Avg	.7284	.8131	.4583	.9651	.8748	1.1522	.3531

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 203 / 11 KV UTAGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.2955	1.3765	.1562	.2401	.1581	1.1888
2	1.3717	1.2955	1.2631	.1619	.2401	.1772	1.1888
3	1.3717	1.2955	1.2631	.1562	.2401	.1581	1.1888
4	1.406	1.3717	1.2631	.1581	.2401	.1581	1.1888
5	1.6194	1.5242	1.3375	.2401	.2915	.2056	1.1888
6	2.0481	2.1338	1.6975	.3563	.4049	.3239	2.0062
7	1.8823	1.829	1.6975	.3239	.4534	.3239	1.8519
8	.2172	.1852	.216	.1875	.2439	.16	.2439
9	.1981	.1875	1.3717	1.6575	1.5242	.1875	
10	.1875		1.3717	1.406	1.6872	.1875	
11	.1189	.1875	1.406	1.2308	1.6872	.2743	
12	.0869	.1852	1.4661	.7964	1.5242	.2229	
13		.1543	1.3717	1.3321	1.448	.2286	
14		.1486	1.1888	1.3032	1.448	.2317	
15		.1829	1.4861	1.4861	1.6347	.2675	
16	.16	.2006	1.467	1.829	1.6651	.2494	
17	.1562	.216	.1829	.3858	.1219	.2187	
18	.1829	.216	.1898	.3858	.1524	.1875	
19	.2187	.2241	.2372	.3953	.25	.2591	
20	.2241	.192	.3125	.3048	.2881	.2591	
21	.1898	.1619	.2439	.2934	.2214	.1581	
22	1.7185	1.5242	.1898	.2778	.1581	1.5242	
23			.1562	.2812	.1581	1.1888	
24	1.3717	1.3717	1.2631	.1562	.2343	.1581	1.1888
Max	2.0481	2.1338	1.6975	1.829	1.6872	1.5242	2.0062
Min	.0869	.1486	.1562	.1562	.1219	.1581	.2439
Avg	.8051	.7310	1.0008	.6359	.6899	.3112	1.2483

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721]

BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 204 / 11 KV SONYAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.0739	.0924	.0934	.0747	.1109	.0747
2	.0934	.0739	.0924	.0934	.0754	.1109	.0747
3	.0934	.0747	.0924	.0934	.0754	.1109	.0747
4	.0943	.112	.1097	.112	.0747	.1109	.0934
5	.2075	.1886	.1867	.1886	.1478	.1867	.1698
6	.3018	.3109	.2801	.2829	.1829	.9374	.2829
7	.3224	.2896	.2614	.2614	.2561	.2427	.2987
8	.2126	.1829	.1991	.2033	.2195	.1848	.2279
9	.181	.1448	.1448	.1646	.1829	.1612	
10	.1448		.1267	.1448	.1097	.1417	
11	.1086	.1097	.1097	.1463	.1097	.1097	
12	.0895		.0914	.1097	.1063	.0895	
13		.1075	.0914	.1097	.0895	.0914	
14		.12	.0914	.1097	.0895	.0895	
15		.104	.0876	.1097	.1075	.1097	
16	.1097	.104	.1387	.128	.1254	.1086	
17	.1227	.1227	.1753	.2195	.1578	.1372	
18	.1509	.1524	.298	.2743	.176	.16	
19	.2454	.2534	.298	.2743	.3045	.2865	
20	.2561	.2743	.3224	.2195	.2926	.2835	
21	.2033	.2241	.2218	.1829	.2012	.1829	
22	.168	.1494	.1478	.1494	.1494	.1478	
23			.1109	.112	.1109	.0924	
24	.0934	.0924	.0924	.0924	.0747	.1109	.0934
Max	.3224	.3109	.3224	.2829	.3045	.9374	.2987
Min	.0895	.0739	.0876	.0924	.0747	.0895	.0747
Avg	.1646	.1555	.1609	.1615	.1456	.1791	.1545

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 205 / 11 KV UTAGI VHASPETH

GAOTHAN FEEDER

GAVTHAN Feeder KV- 11 /
OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0739	.0747	.0914	.056	.0543	.0739	.056
2	.0739	.0747	.0924	.056	.0549	.0739	.056
3	.0739	.0747	.0924	.056	.0549	.0739	.056
4	.0739	.0747	.0924	.056	.0549	.0739	.056
5	.0739	.0934	.112	.0747	.0924	.0732	.056
6	.1109	.112	.112	.0934	.112	.1109	.0554
7	.0732	.1109	.1097	.0747	.112	.0924	.0732
8	.0914	.0924	.0747	.056	.1086	.0554	.0366
9	.1097	.1109	.112	.0732	.1086	.0732	
10	.1097	.1109	.128	.0732	.0905	.0914	
11	.128	.112	.112	.1086	.0905	.0732	
12	.1463	.112	.0934	.1086	.0934	.0701	
13		.112	.112	.1086	.0747	.0857	
14		.0934	.112	.0905	.056	.0876	
15		.1097	.112	.0876	.056	.104	
16	.0914	.128	.112	.1029	.056	.1029	
17		.128	.128	.1029	.0914	.1097	
18	.128	.1294	.1402	.1075	.1109	.0924	
19	.1463	.168	.1753	.1254	.1663	.1294	
20	.1646	.168	.1612	.1254	.1463	.1478	
21	.128	.168	.1494	.1075	.1307	.1463	
22	.1109	.1294	.1052	.0905	.0914	.1097	
23			.0934	.0905	.0739	.0739	
24	.0747	.0747	.0914	.056	.0543	.0739	.056
Max	.1646	.168	.1753	.1254	.1663	.1478	.0732
Min	.0732	.0747	.0747	.056	.0543	.0554	.0366
Avg	.1043	.1114	.1131	.0867	.0890	.0916	.0557

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 201 / 11 KV SIDHANATH AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3108	1.4746	1.3108	.1638	.1638	.1638	1.1469
2	1.3108	1.4746	1.3108	.1638	.1638	.1638	1.1469
3	1.4746	1.4746	1.3108	.1638	.1638	.1638	1.1469
4	1.4746	1.4746	1.3108	.1638	.1638	.1638	1.3108
5	1.4746	1.4746	1.4746	.1638	.1638	.1638	1.3108
6	1.6385	1.6385	1.4746	.1638	.1638	.2458	1.4746
7	1.6385	1.6385	1.4746	.1638	.1638	.2458	1.4746
8	.1638	.1638	.2458	.1638	.1638	.2458	.1638
9							.1638
10							.1638
11							.1638
12							.1638
14							.1638
15							.1638
16							.1638
24	1.3108	1.4746	1.3108	.1638	.1638	.1638	1.1469
Max	1.6385	1.6385	1.4746	.1638	.1638	.2458	1.4746
Min	.1638	.1638	.2458	.1638	.1638	.1638	.1638
Avg	1.3108	1.3654	1.2471	.1638	.1638	.1911	.7168

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 202 / 11 KV DARIKONUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.081	.081	.081	.4049	.4858	.4049	.081
2	.081	.081	.081	.4049	.4858	.4049	.081
3	.081	.081	.081	.4858	.4858	.4049	.081
4	.081	.081	.081	.4858	.6478	.4858	.081
5	.081	.081	.081	.8097	.6478	.6478	.081
6	.081	.1619	.1619	.9717	.8097	.6478	.081
7	.1619	.1619	.1619	.4858	.8097	.6478	.1619
8	.1619	.1619	.1619	.1619	.081	.081	.1619
9							.8097
10							.8097
11							.8097
16							.6478
24	.081	.081	.081	.4049	.4858	.4049	.081
Max	.1619	.1619	.1619	.9717	.8097	.6478	.8097
Min	.081	.081	.081	.1619	.081	.081	.081
Avg	.0990	.1080	.1080	.5128	.5488	.4589	.3052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 203 / 11 KV SHEDYAL GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0566	.0566	.0747	.056	.056
2	.0566	.0566	.0566	.0566	.0747	.056	.056
3	.0566	.0566	.0566	.0566	.0747	.056	.056
4	.0566	.0566	.0566	.0566	.0747	.056	.056
5	.0566	.0566	.0566	.0566	.0747	.056	.056
6	.0566	.0566	.0566	.0566	.0747	.056	.056
7	.0566	.0566	.0566	.0566	.0747	.056	.056
8	.0566	.0566	.0566	.0566	.0747	.056	.056
9							.0566
10							.0566
11							.0566
12							.0566
13							.0566
14							.0566
15							.0566
16							.0566
24	.0566	.0566	.0566	.0566	.0747	.056	.056
Max	.0566	.0566	.0566	.0566	.0747	.056	.0566
Min	.0566	.0566	.0566	.0566	.0747	.056	.056
Avg	.0566	.0566	.0566	.0566	.0747	.056	.0563

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 204 / 11 KV SHEDYAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0848	.0848	.0848	.6783	.6783	.6783	.0848
2	.0848	.0848	.0848	.6783	.6783		.0848
3	.0848	.0848	.0848	.6783	.6783	.6783	.0848
4	.0848	.0848	.0848	.6783	.8478	.6783	.0848
5	.0848	.0848	.0848	1.0174	1.0174	.6783	.0848
6	.1696	.1696	.1696	1.0174	1.3565	.9326	.1696
7	.1696	.1696	.1696	.6783	1.3565	1.0174	.1696
8	.1696	.1696	.1696	.1696	.0848	.0848	.1696
9							.9326
10							.9326
11							.9326
16							1.1022
24	.0848	.0848	.0848	.6783	.6783	.6783	.0848
Max	.1696	.1696	.1696	1.0174	1.3565	1.0174	1.1022
Min	.0848	.0848	.0848	.1696	.0848	.0848	.0848
Avg	.1131	.1131	.1131	.6971	.8196	.6783	.3783

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 205 / 11 KV DARIKONUR GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0377	.0566	.0377	.0747	.056	.056
2	.0377	.0377	.0566	.0377	.0747	.056	.056
3	.0377	.0377	.0566	.0377	.0747	.056	.056
4	.0566	.0377	.0566	.0377	.0747	.056	.056
5	.0566	.0377	.0566	.0377	.0747	.056	.056
6	.0566	.0566	.0566	.0566	.0747	.056	.056
7	.0566	.0566	.0566	.0566	.0747	.0747	.056
8	.0566	.0566	.0566	.0566	.0747	.056	.056
9							.0566
10							.0566
11							.0566
12							.0566
13							.0566
14							.0566
15							.0566
16							.0566
24	.0566	.0377	.0566	.0377	.0747	.056	.056
Max	.0566	.0566	.0566	.0566	.0747	.0747	.0566
Min	.0377	.0377	.0566	.0377	.0747	.056	.056
Avg	.0503	.044	.0566	.044	.0747	.0581	.0563

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 206 / 11 KV SIDDHANATH GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	.0943	.0754	.0943	.0754	.0754
2	.0754	.0754	.0943	.0754	.0943	.0754	.0754
3	.0754	.0754	.0943	.0754	.0943	.0754	.0754
4	.0754	.0754	.0943	.0943	.0943	.0754	.0754
5	.0754	.0754	.0943	.0943	.0943	.0754	.0754
6	.0943	.0943	.1509	.0943	.0943	.0943	.0754
7	.0943	.0943	.1509	.0943	.0943	.0943	.0754
8	.0943	.0754	.1509	.0943	.0943	.0754	.0754
9							.0754
10							.0754
11							.0754
12							.0754
13							.0754
14							.0754
15							.0754
16							.0754
24	.0754	.0754	.0943	.0754	.0943	.0754	.0754
Max	.0943	.0943	.1509	.0943	.0943	.0943	.0754
Min	.0754	.0754	.0943	.0754	.0943	.0754	.0754
Avg	.0817	.0796	.1132	.0859	.0943	.0796	.0754

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 207 / 11 KV DARIBADCHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3108	1.3108	1.3108	.2458	.2458	.2458	1.1469
2	1.3108	1.3108	1.3108	.2458	.2458	.2458	1.1469
3	1.3108	1.3108	1.3108	.2458	.2458	.2458	1.3108
4	1.3108	1.3108	1.3108	.2458	.2458	.2458	1.3108
5	1.4746	1.3108	1.3108	.3277	.2458	.2458	1.4746
6	1.6385	1.6385	1.4746	.3277	.3277	.2458	1.6385
7	1.8023	1.6385	1.4746	.3277	.3277	.2458	1.6385
8	.3277	.3277	.3277	.3277	.3277	.2458	.2458
9							.2458
10							.2458
11							.2458
12							.2458
13							.2458
14							.2458
15							.2458
16							.2458
24	1.3108	1.3108	1.3108	.2458	.2458	.2458	1.1469
Max	1.8023	1.6385	1.4746	.3277	.3277	.2458	1.6385
Min	.3277	.3277	.3277	.2458	.2458	.2458	.2458
Avg	1.3108	1.2744	1.2380	.2822	.2731	.2458	.7662

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 208 / 11 KV MUCHANDI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1638	.1638	.1638	1.1469	.8192	1.1469	.1638
2	.1638	.1638	.1638	1.1869	.8192	1.1469	.1638
3	.1638	.1638	.1638	1.1469	.8192	1.1469	.1638
4	.1638	.1638	.1638	1.3108	1.1469	1.4746	.1638
5	.1638	.1638	.1638	1.8023	1.1469	1.4746	.1638
6	.2458	.1638	.2458	1.9662	1.8023	1.8023	.1638
7	.2458	.1638	.2458	1.4746	1.8842	1.8023	.1638
8	.1638		.2458	.1638	.1638	.1638	.1638
9							1.4746
10							1.6385
11							1.3108
16							1.7204
24	.1638	.1638	.1638	1.1469	.8192	1.1469	.1638
Max	.2458	.1638	.2458	1.9662	1.8842	1.8023	1.7204
Min	.1638	.1638	.1638	.1638	.1638	.1638	.1638
Avg	.1820	.1638	.1911	1.2606	1.0468	1.2561	.5860

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 201 / 11 KV TIKONDI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0671	.0848	.0655	.4372	.3887	.3605	.0819
2	.0678	.0838	.0648	.421	.4096	.3563	.0648
3	.0678	.1017	.0648	.4161	.3932	.3401	.0648
4	.0829	.1187	.08	.4321	.3978	.3563	.081
5	.116	.1658	.08	.4534	.3768	.4096	.0972
6	.1457	.1638	.1457	.6478	.5344	.4588	.1311
7	.1619	.1943	.1619	.6316	.583	.426	.1966
8	.1357	.1677	.1619	.1311	.0995	.1296	.1943
9	.583	.5761	.112	.1475	.1326	.4372	.5182
10	.5506	.5441	.112	.1492	.0995	.5182	.5506
11	.4858	.5121	.081	.1147	.1147	.4049	
12	.4534	.4481	.0648	.0983	.0972	.3841	
13	.421	.4481	.0983	.0655	.081	.3521	
14		.4858	.0819	.0655	.081	.3521	
15		.5182	.0995	.0663	.096	.3563	
16	.3887	.5182	.0829	.0829	.112	.4534	.4534
17	.0848	.096	.1311	.1006	.1134	.0972	.1372
18	.0848	.128	.1492	.1326	.1296	.128	.1357
19	.1187	.1134	.1658	.1492	.1457	.1296	.1187
20	.1341	.0972	.1509	.0829	.1457	.1296	.1187
21	.1341	.0972	.1326	.0655	.1311	.1311	.1187
22	.0995	.0819	.6226	.3887	.4915	.0983	.1174
23	.0848	.0819	.5079	.3887	.4588	.0819	.1174
24	.0671	.0848	.0655	.4372	.3887	.3605	.0819
Max	.583	.5761	.6226	.6478	.583	.5182	.5506
Min	.0671	.0819	.0648	.0655	.081	.0819	.0648
Avg	.2062	.2463	.1451	.2544	.2501	.3022	.1779

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 202 / 11 KV KONTEBOBLAD AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.218	.2374	.1989	.9012	.7287	.8619	.1966
2	.2012	.2347	.1823	.8848	.7537	.8288	.1802
3	.2155	.2347	.1802	.8785	.7956	.8192	.1781
4	.2347	.2652	.1802	.8785	.8288	.852	.1943
5	.2486	.3018	.1966	.8848	.8848	.9012	.2267
6	.2984	.3315	.2818	1.3765	1.1012	1.0442	.2429
7	.3277	.3149	.3647	1.4899	1.2955	1.1603	.2949
8	.2713	.2683	.2949	.2622	.1989	.2652	.2622
9	1.166	1.3603	.2949	.213	.0995	.9831	1.3108
10	1.0883	1.2483	.2429	.2486	.213	1.065	1.1469
11	1.0688	1.1523	.2294	.2486	.1966	1.0486	
12	1.0688	1.0883	.2458	.2652	.1781	1.004	
13	.9393	1.1203	.1492	.2294	.1781	.9878	
14		1.085	.1492	.2294	.176	.9717	
15		1.1174	.1989	.2321	.16	1.004	
16	.8421	1.1498	.213	.2321	.1457	1.1012	1.1142
17	.1844	.112	.1802	.2155	.1943	.1781	.2374
18	.2374	.16	.2321	.1492	.2105	.213	.2374
19	.3185	.2429	.2818	.2347	.2458	.2458	.2713
20	.3185	.2591	.2683	.1341	.2622	.2294	.3052
21	.2683	.2458	.2347	.116	.2458	.2486	.2683
22	.2652	.2294	1.1305	.8848	1.0486	.2155	.2515
23	.2374	.1989	.9503	.7287	.9503	.213	.2155
24	.2155	.2374	.1989	.7859	.7449	.8619	.1966
Max	1.166	1.3603	1.1305	1.4899	1.2955	1.1603	1.3108
Min	.1844	.112	.1492	.116	.0995	.1781	.1781
Avg	.4652	.5498	.2950	.5293	.4932	.7210	.3858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 203 / 11 KV PANDOZARI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.491	1.4413	1.3272	.4807	.3978	.5304	1.5249
2	1.4918	1.3757	1.3108	.4694	.4144	.4973	1.5249
3	1.4575	1.4089	1.2955	.503	.4424	.4915	1.4918
4	1.5546	1.4089	1.2793	.5304	.4752	.5243	1.4746
5	1.7284	1.5223	1.3765	.5636	.5079	.5571	1.5565
6	2.0715	1.7652	1.5074	.6882	.664	.7373	2.0317
7	2.1348	2.1125	1.704	.6718	.7373	.7956	2.2045
8	.5935	.5365	.4475	.5735	.6062	.6796	.547
9	.5801	.4973	1.4918	1.9271	1.9109	.6062	.4096
10	.5182	.5243	1.4091	1.7328	1.8623	.5898	.5407
11	.5506	.5344	1.4575	.8192	1.6712	.5407	
12	.5636	.5668	1.3765	1.4089	1.7695	.5506	
13	.5304	.502	1.4091	1.4413	1.6712	.5992	
14		.5079	1.3435	1.4091	1.5708	.502	
15	.4527	.5243	1.5546	1.6194	1.6842	.4696	.3222
16	.5138	.5243	1.6032	1.7328	1.8138	.5182	.3856
17	.5365	.5668	.3932	.4049	.3768	.5441	.4917
18	.6104	.5735	.4915	.4144	.4588	.5601	
19	.6371	.639	.5898	.5138	.6062	.5992	.7209
20	.6874	.663	.6133	.431	.6554	.5898	.6706
21	.5868	.5636	.5304	.3932	.6133	.5407	.5426
22	1.7004	1.6244	.4973	.4096	.547	1.873	1.7814
23	1.6004	1.4089	.4973	.3978	.5304	1.6244	1.6356
24	1.491	1.5708	1.3272	.4807	.3978	.5304	1.5581
Max	2.1348	2.1125	1.704	1.9271	1.9109	1.873	2.2045
Min	.4527	.4973	.3932	.3932	.3768	.4696	.3222
Avg	1.0471	.9734	1.1181	.8340	.9327	.6688	1.1271

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 204 / 11 KV TIKONDI GAVTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.0747	.1109	.0747	.0934	.0934	.0934
2	.0754	.0754	.112	.0747	.0754	.0943	.0934
3	.0754	.0924	.112	.0754	.0754	.0754	.0747
4	.112	.1307	.112	.0754	.0943	.0943	.0739
5	.1646	.168	.1307	.112	.112	.112	.0924
6	.2012	.1829	.1698	.1867	.1307	.1307	.1294
7	.1463	.1097	.2075	.1867	.1494	.1132	.168
8	.1494	.1307	.1848	.1478	.1478	.0934	.1307
9	.1294	.1294	.1307	.1109	.1109	.0924	.112
10	.1109	.1109	.1109	.1109	.0924	.1109	.1109
11	.1097	.0934	.1109	.1097	.0914	.1097	
12	.1109	.1097	.0924	.128	.1097	.1097	
13		.0914	.1097	.128	.1086	.1086	
14	.1494	.0905	.0914	.1109	.1267	.1086	
15	.0934	.0895	.0914	.1294	.1075	.0895	.0934
16	.1109	.1075	.1097	.1109	.1254	.1075	.0924
17	.112	.1075	.1109	.128	.1254	.1075	.112
18	.1307	.1448	.1109	.128	.1448	.1086	.112
19	.1867	.1629	.1478	.1829	.2172	.1448	.1848
20	.168	.2012	.2054	.1294	.2012	.1646	.1867
21	.1478	.1829	.1867	.1294	.1829	.128	.168
22	.1294	.1463	.1307	.112	.1294	.1109	.1097
23	.1307	.1109	.112	.0934	.112	.0924	.1097
24	.0934	.0934	.1109	.0924	.0934	.0934	.0924
Max	.2012	.2012	.2075	.1867	.2172	.1646	.1867
Min	.0754	.0747	.0914	.0747	.0754	.0754	.0739
Avg	.1274	.1224	.1293	.1195	.1232	.1081	.1170

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 205 / 11 KV PANDOZARI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0381	.0381	.0572	.0381	.0572
2	.0381	.0381	.0381	.0381	.0572	.0381	.0381
3	.0381	.0572	.0381	.0381	.0381	.0572	.0381
4	.0572	.0572	.0572	.0381	.0572	.0572	.0572
5	.0762	.0762	.0572	.0572	.0572	.0762	.0572
6	.1143	.1132	.0953	.0953	.0953	.1143	.0953
7	.168	.112	.1143	.1143	.1143	.1143	.1143
8	.1132	.0943	.0953	.0953	.0762	.0762	.0953
9	.0572	.0572	.0572	.0572	.0572	.0572	.0572
10	.0762	.0381	.0381	.0381	.0381	.0572	.0572
11	.0381	.0381	.0381	.0381	.0572	.0572	
12	.0191		.0381	.0381	.0381	.0381	
13			.0191	.0381	.0191	.0381	
14			.0191	.0381	.0191	.0381	
15	.0381		.0191	.0762	.0191	.0381	
16	.0762	.0572	.0381	.0381	.0381	.0572	.0381
17	.0381	.0572	.0381		.0381	.0572	.0381
18	.0381	.0762	.0572	.0762	.0572	.0953	.0572
19	.1143	.0953	.1143	.1334	.0762	.0953	.0762
20	.1143	.1334	.1524	.1334	.1334	.1334	.0953
21	.0572	.0953	.0953	.1143	.0762	.1143	.0762
22	.0381	.0572	.0762	.0762	.0762	.0762	.0381
23	.0381	.0572	.0572	.0572	.0572	.0381	.0381
24	.0381	.0381	.0572	.0381	.0572	.0381	.0572
Max	.168	.1334	.1524	.1334	.1334	.1334	.1143
Min	.0191	.0381	.0191	.0381	.0191	.0381	.0381
Avg	.0647	.0693	.0604	.0654	.0588	.0667	.0622

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 206 / 11 KV KAGNARI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5223	1.491	1.6095	.3018	.1696	.3353	1.8442
2	1.5083	.7373	1.6095	.3052	.1357	.3185	1.8107
3	1.5249	1.2407	1.5746	.3222	.1509	.3185	1.7404
4	1.6057	1.2742	1.5746	.3391	.1509	.3315	1.757
5	1.7604	1.5074	1.6244	.3521	.1696	.3647	1.9062
6	2.0805	1.7328	1.7939	.3856	.2543	.4807	2.1548
7	2.0081	1.9524	1.861	.4191	.2883	.6203	2.2131
8	.57	.5365	.3353	.407	.3018	.5365	.6371
9	.57	.4534	1.7126	2.2045	1.3094	.503	.5365
10	.5636	.5138	1.9161	2.13	1.8623	.3561	.4527
11	.4641	.4641	1.8442	2.0481	1.917	.39	
12	.4372	.4527	1.8778	2.0405	2.0957	.407	
13	.4475	.4527	1.7604	1.9109	2.0287	.4239	
14		.4527	1.7974	1.9271	1.2763	.4359	
15	.3561	.3688	1.8945	1.5844	1.757	.4191	
16	.3647	.4694	1.7939	1.6964	1.8945	.4191	.2347
17	.4578	.4578	.407	.3768	.3185	.431	.3561
18	.4748	.4239	.4239		.373	.4641	.39
19	.4694	.4748	.407	.2347	.4748	.4641	.4578
20	.4527	.4694	.4359	.2012	.4694	.503	.4694
21	.4024	.3856	.3856	.1696	.4191	.4191	.3688
22	1.7652	1.8143	.3521	.2012	.373	2.0454	1.9364
23	1.668	1.7126	.3391	.1357	.3561	1.9951	1.9271
24	1.5223	1.6385	1.6263	.3018	.1696	.3353	1.8778
Max	2.0805	1.9524	1.9161	2.2045	2.0957	2.0454	2.2131
Min	.3561	.3688	.3353	.1357	.1357	.3185	.2347
Avg	.9998	.8949	1.2899	.8693	.7798	.5549	1.2143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 207 / 11 KV KAREWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1989	.218	.192	.9717	.7682	.8421	.1898
2	.213	.0509	.1739	.9602	.7682	.8002	.1718
3	.1966	.0838	.1739	.9442	.7432	.8002	.1718
4	.2486	.081	.1898	.9282	.7748	.8162	.1718
5	.2915	.1781	.1898	.9282	.8002	.8745	.1898
6	.3239	.2267	.2561	1.1702	.9602	.9717	.2214
7	.2241	.2915	.3041	1.1544	1.0402	.9922	.253
8	.1696	.2347	.2721	.176	.1475	.112	.208
9	1.1702	1.1227	.2688	.2105	.1966	.9488	1.1203
10	1.1227	1.1544	.2372	.2294	.1943	1.0279	.8697
11	1.004	1.1174	.2401	.2294	.2155	.8539	
12	.9922	.9922	.2241	.2458	.2753	.8223	
13	.9282	.9282	.2267	.2321	.2591	.8124	
14		.9602	.1802	.1989	.08	.8436	
15		.9804	.1802	.0829	.144	.3593	
16	.8583	1.0437	.2155	.1475	.176	.7116	.4696
17	.1174	.0791	.2155	.1326	.208	.0949	.1865
18	.1677	.144	.1966	.1326	.192	.1265	.1696
19	.218	.208	.1966	.1147	.208	.2056	.1696
20	.2204	.2241	.213	.1147	.2429	.2561	.2347
21	.2486	.2241	.1966	.0655	.1943	.2401	.285
22	.2486	.2056	1.1822	.9069	1.0526	.2241	.2515
23	.2347	.1898	1.0364	.8421	.9602	.2286	.213
24	.1989	.2347	.192	.9878	.7842	.8421	.1898
Max	1.1702	1.1544	1.1822	1.1702	1.0526	1.0279	1.1203
Min	.1174	.0509	.1739	.0655	.08	.0949	.1696
Avg	.4362	.4656	.2897	.5044	.4744	.6170	.3019

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 201 / 11 KV SANMADI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0953	.0953	.0953	.0953	.0953
2	.0953	.0953	.0953	.0953	.0953	.0953	.0953
3	.0953	.0953	.0953	.0953	.0953	.0953	.0953
4	.0953	.0953	.0953	.0953	.0953	.0953	.0953
5	.0953	.0953	.0953	.0953	.0953	.0953	.0953
6	.1905	.1905	.1905	.1905	.1905	.1905	.1905
7	.1905	.1905	.1905	.1905	.1905	.1905	.1905
8	.1905	.1905	.0953	.1905	.0953	.0953	.1905
9	.0953	.0953	.0953	.0953	.0953	.0953	.0953
10	.0953	.0953	.0953	.0953	.0953	.0953	.0953
11	.0953	.0953	.0953	.0953	.0953	.0953	.0953
12	.0953	.0953	.0953	.0953	.0953	.0953	
13	.0953	.0953	.0953	.0953	.0953	.0953	
14	.0953	.0953	.1905	.0953	.0953	.0953	
15	.0953	.0953	.0953	.0953	.0953	.0953	
16	.0953	.0953	.0953	.0953	.0953	.0953	
17	.0953	.0953	.1905	.0953	.0953	.0953	
18	.0953	.1905	.1905	.0953	.0953	.1905	
19	.1905	.1905	.1905	.1905	.1905	.1905	.1905
20	.1905	.1905	.1905	.1905	.1905	.1905	.1905
21	.1905	.1905	.1905		.1905	.1905	.1905
22	.1905	.0953	.0953	.0953	.1905	.1905	.0953
23	.0953	.0953	.0953	.0953	.0953	.0953	.0953
24	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Max	.1905	.1905	.1905	.1905	.1905	.1905	.1905
Min	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Avg	.1231	.1231	.1270	.1160	.1191	.1231	.1289

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 202 / 11 KV GHOLESHWAR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2075	.1886	.499	.5068	.503	.2241
2	.2075	.1886	.2075	.4915	.543	.5083	.2427
3	.2452	.2075	.2263	.4287	.5373	.4938	.2829
4	.3018	.2452	.2641	.5083	.5258	.5788	.3239
5	.3961	.3018	.3206	.8059	.5258	.7167	.362
6	.5281	.547	.547	1.7372	1.0454	1.0288	.4763
7	.4715	.4904	.3772	1.4045	1.3676	1.0374	.4527
8	.3174	.2801	.2263	.2263	.2427	.3174	.2587
9	.9242	1.0456	.112	.168	.2075	1.0456	.9054
10	1.0562	1.1949	.112	.1494	.1698	1.251	1.0562
11	.9054	1.1128	.112	.1494	.1307	1.0454	.9431
12	.8865	.9054	.112	.1509	.1307	1.0185	
13	.8865	.9619	.112	.1509	.1307	1.0374	
14		1.0082	.1307	.1494	.1494	.743	
15	.7611	1.0456	.168	.1417	.1478	1.0098	
16	.4843	.9149	.1848	.1791	.1294	.9619	
17	.2614	.2075	.2452	.2054	.2033	.2075	
18	.3547	.3018	.3018	.2829	.2378	.3018	
19	.3772	.3584	.3772	.3206	.3547	.3395	.4481
20	.4338	.4338	.4338	.3018	.4338	.3961	.5601
21	.3584	.3584	.3206	.3018	.3584	.3395	.3734
22	.2641	.3018	.5415	.4024	.5281	.2829	.3361
23	.2263	.2452	.4805	.4207	.4915	.2829	.3206
24	.2075	.2263	.2075	.499	.5415	.5079	.2452
Max	1.0562	1.1949	.547	1.7372	1.3676	1.251	1.0562
Min	.1886	.1886	.112	.1417	.1294	.2075	.2241
Avg	.4802	.5454	.2629	.4198	.4016	.6648	.4595

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 203 / 11 KV KONIKUNUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0934	.0934	.427		.2778	.0943
2	.0943	.0934	.0934	.4001		.25	.0943
3	.0943	.0914	.0934	.3768		.2968	.0943
4	.1132	.0934	.0943	.4862		.3201	.0953
5	.1334	.1132	.1132	.663		.3521	.1143
6	.1524	.1715	.1524	1.073		.421	.1524
7	.132	.1463	.1132	.7968		.5201	.132
8	.0905	.0983	.0943	.0924		.0905	.1254
9	.6539	.7125	.0934	.0934		.4862	
10	.6562	.7773	.0924	.0886	.3953	.5407	
11	.6241	.6882	.0924	.0876	.0857	.5992	
12	.5851	.5761	.0905	.0886	.0886	.6241	
13	.5921	.664	.0914	.0914	.0934	.6539	
14		.7042	.0886	.0905	.0934	.6226	
15	.6241	.7362	.0848	.0848	.0943	.6167	
16	.431	.6706	.081	.081	.0943	.5944	
17	.0914	.0914	.0934	.0857	.0934	.0934	
18	.0934	.112	.0934	.0914	.0943	.0934	
19	.0934	.112	.112	.112	.0943	.0924	.1267
20	.1494	.132	.1307	.1132	.0943	.1294	.1463
21	.1307	.1132	.0934		.0943	.1307	.1294
22	.0943	.0943	.3887		.3201	.112	.0934
23	.0943	.0943	.4481		.2968	.0934	.0924
24	.0953	.0943	.0943	.4321		.2932	.0943
Max	.6562	.7773	.4481	1.073	.3953	.6539	.1524
Min	.0905	.0914	.081	.081	.0857	.0905	.0924
Avg	.2571	.3031	.1257	.2788	.1452	.3460	.1132

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 204 / 11 KV SANAMADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0724	.0724	.0724	.0724	.0743	.0734	.0734
2	.0724	.0724	.0724	.0753	.0743	.0734	.0734
3	.0724	.0724	.0724	.0781	.0743	.0734	.0734
4	.0724	.0724	.0724	.0857	.0743	.0734	.0734
5	.1014	.1014	.0724	.0876	.0743	.0734	.1027
6	.1303	.1448	.0869	.0876	.0743	.0734	.1467
7	.1593	.1882	.1158	.0886	.0743	.0734	.176
8	.0724	.0724	.0724	.0762	.0743	.0734	.0734
9	.6539	.0724	.0869	.1372	.1505	.0743	
10	.6562	.0724	.0869	.1677	.1505	.0743	
11	.0724	.0724	.0869	.1739	.1189	.0743	
12	.0724	.0724	.0869	.1372	.104	.0743	
13	.0724	.0724	.0869	.1389	.1174	.0743	
14		.0724	.0869	.1189	.1174	.0743	
15	.0724	.0724	.0869	.1174	.088	.0743	
16	.0724	.0724	.0869	.1027	.0734	.0743	
17	.0724	.0724	.0724	.0734	.0734	.0743	
18	.0724	.0724	.0724	.0734	.0734	.0743	
19	.0724	.0724	.0724	.0734	.0734	.0743	.0734
20	.0724	.0724	.0724	.0753	.0734	.0734	.0734
21	.0724	.0724	.0724	.0753	.0734	.0734	.0734
22	.0724	.0724	.0724	.0753	.0734	.0734	.0734
23	.0724	.0724	.0724	.0743	.0734	.0734	.0734
24	.0724	.0724	.0724	.0724	.0734	.0734	.0734
Max	.6562	.1882	.1158	.1739	.1505	.0743	.176
Min	.0724	.0724	.0724	.0724	.0734	.0734	.0734
Avg	.1306	.0815	.0796	.0974	.0876	.0738	.0881

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721]

BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 205 / 11 KV GHOLESHWAR GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.0876	.0934	.0857	.0857	.0943	.0924
2	.0943	.0895	.0943	.0895	.0895	.0953	.0924
3	.0943	.0905	.0943	.0914	.0914	.0953	.0934
4	.0934	.0914	.0943	.0934	.0934	.0943	.0934
5	.1867	.1867	.1905	.2829	.2829	.0934	.1886
6	.2829	.2829	.2858	.1829	.1829	.1905	.2858
7	.1867	.1829	.1886	.1848	.1848	.1848	.2743
8	.1734	.1562	.1829	.0886	.0886	.1734	.1734
9	.0886	.0886	.0905	.1753	.0857	.0895	.1715
10	.0905	.0905	.0895	.1734	.0848	.0895	.1734
11	.0886	.0905	.0914	.0857	.0867	.0886	.0905
12	.0895	.0905	.0905	.0867	.0857	.0886	
13		.0895	.0876	.0876	.0876	.0867	
14	.0876	.0886	.0886	.0876	.0895	.0867	
15	.0886	.0895	.0857	.0867	.0867	.0876	
16	.0876	.0838	.0838	.1658	.0848	.0886	
17	.0876	.0867	.2686	.1646	.1715	.1734	
18	.1715	.1772		.197	.1753	.2658	
19	.2601	.1791	.2572	.2427	.2601	.2515	.3429
20	.2686	.2743	.2686	.2572	.2715	.2103	.3582
21	.1867	.1867	.1829	.1753	.1829	.2715	.2743
22	.1734	.0934	.1867	.1886	.1867	.181	.1734
23	.0867		.0943	.0886	.0934	.0914	
24	.0934	.0876	.2686	.0867	.0867	.0943	.0914
Max	.2829	.2829	.2858	.2829	.2829	.2715	.3582
Min	.0867	.0838	.0838	.0857	.0848	.0867	.0905
Avg	.1371	.1289	.1504	.1437	.1341	.1361	.1856

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244109 / 33/11 KV LAVANGA

Feeder No / Name : 201 / 11 KV KONTEBOBLAD MIX
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6802	.4744	.7373	.1492
2	.6722	.4744	.7459	.1296
3	.6562	.4744	.8097	.1475
4	.6562	.5668	.8097	.1457
5	.6722	.6478	.9012	
6	.1377	.9389	.8002	.16
7	1.1984	1.0242		.1581
8	.112	.1334	.081	.1619
9	.1334	.1524	.6478	.8907
10	.1143	.1524	.8029	.9717
11	.1143	.0953		.8907
12	.1143	.0572	.9012	
13	.1334	.0953		
14	.0953	.1143	.7459	
15	.1334	.1143	.7116	
16	.1334	.1334	.8002	
17	.1143	.1334		
18	.0762	.1524	.116	
19	.0953	.1715	.1311	.0953
20	.1524	.1524	.1492	.1143
21	.1524	.1715	.1677	.0953
22	.5535	.8192	.1174	.1143
23	.4744	.6478	.1578	.1143
24	.6802	.8192		.1372
Max	1.1984	1.0242	.9012	.9717
Min	.0762	.0572	.081	.0953
Avg	.3357	.3632	.5439	.2797

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244109 / 33/11 KV LAVANGA

Feeder No / Name : 202 / 11 KV JALYAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7611	.6325	.9012	.2458
2	.7611	.6325		.2515
3	.7522	.6325		.2347
4	.7449	.7116		.2035
5	.7611	.7907		.3605
6	1.1305	.9962		
7	.1131	1.0279		.3605
8	.2429	.1886		.3315
9	.2829	.1886		1.1603
10	.3018	.2452		1.0279
11	.2829	.3772	1.2146	1.0279
12	.2829	.3395	1.065	
13	.2829	.1886	1.1069	
14	.2263		1.0279	
15	.2263	.2987	.9602	
16		.2829	1.0526	
17		.3467	.3239	
18		.3361	.3429	
19	.3479	.2858	.362	.3163
20	.3479	.3048	.3429	.3163
21	.3479	.3429	.3277	.3479
22	.6642	.8907	.2915	.3005
23	.6009	.9012	.3277	.2688
24	.7773	.6325	.8192	.2949
Max	1.1305	1.0279	1.2146	1.1603
Min	.1131	.1886	.2915	.2035
Avg	.4876	.5032	.6977	.4406

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244109 / 33/11 KV LAVANGA

Feeder No / Name : 203 / 11 KV GIRGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.0953	.0762	.7287
2	.1334	.0953	.0762	.6478
3	.1334	.0953	.0572	.7287
4	.1334	.0953	.0572	
5	.1334	.1143	.0762	.7202
6	.1715	.1334	.0953	.8002
7	.1334	.1334	.0934	.8907
8	.1524	.0953	.0762	.0486
9	.8322	.6097	.0762	
10	.9069	.703	.0572	
11	.8642	.6325	.0572	.0648
12	.7621	.6325	.0762	
13	.6097	.6325	.0572	
14		.6802		
15	.6097	.6478	.0572	
16	.6173	.7373	.0572	
17	.0762		.0572	
18	.0762	.0762	.0762	
19	.0762		.0572	.1143
20	.0953	.0762	.0762	.1334
21	.1143	.0762	.0503	.1143
22	.1143		.7373	.5716
23	.0953	.0572	.6478	.4572
24	.2858	.0953	.0572	.6554
Max	.9069	.7373	.7373	.8907
Min	.0762	.0572	.0503	.0486
Avg	.3173	.3102	.1220	.4769

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 201 / 11 KV KANKESHWAR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2881	.3134	.1134	2.5953		3.7289	.2385
2	.2559	.3035	.1134	2.5038	1.247	3.6534	.2355
3	.2397	.308	.1134	2.4345	2.7682	3.6534	.234
4	.2481	.3142	.1134	2.4116	2.8326	3.4873	.2504
5	.2481	.3126	.1134	2.4032	3.1028	3.2099	.2736
6	.2689	.1684	.1296	2.537	3.3733	3.3753	.2774
7	.2643	.3271	.1296	2.8418	1.9166	3.7377	.2828
8	.3041	.3578	.1134	.2872	.7764	2.1963	.3087
9	5.3627	5.2703	.1134	.2045	.6964	4.6868	5.0408
10	5.378	5.6971	.0972	.2199	.2529	5.4702	6.0459
11	5.4862	5.3835	.0972	.2376	.2405	5.8776	3.3798
12	5.4839	5.4494	.0972	.166	.2245	5.7872	3.3775
13	2.9338	5.5348	.0972	.226	.2107	5.6611	
14	1.9786	5.2713	.0972	.2298	.2321	5.5888	
15	2.3731	5.3174	.081	.1999	.1976	5.554	
16	3.8967	5.0067	.081	.109	.2008	5.5106	.25
17	.1265	.3931	.0972	.1296	.2422	3.1413	2.4775
18	.2683	.2506	.0972	.2658	.2521	.3113	.1379
19	.3656	.3042	.1457	.2767	.3067	.3342	.1509
20	.3915	.3301	.1457	.1707	.3608	.3658	.1989
21	.4123	.3362	.1619	.1799	.3585	.3642	.2111
22	.3654	.2927	2.1862		3.8958	.3285	.2119
23	.3171	.2904	2.1376		4.0447	.2808	.1905
24	.3049	.2897	.1134	.1311	2.066	1.8705	.2778
Max	5.4862	5.6971	2.1862	2.8418	4.0447	5.8776	6.0459
Min	.1265	.1684	.081	.109	.1976	.2808	.1379
Avg	1.5651	1.9926	.2827	.9437	1.2956	3.2573	1.1453

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 202 / 11 KV MHAISHAL GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2049	1.2559	.5487	.5487		.6219	.5487
2	1.1256	1.1515	.5121	.5487	.6099	.6219	.5121
3	1.1187	1.1439	.4938	.5487	.5304	.6219	.4755
4	1.0791	1.1424	.4755	.5487	.5544	.6219	.5121
5	1.0928	1.1538	.5121	.5853	.5914	.6219	.5487
6	1.2521	1.4106	.6584	.695	.6653	.6584	.6219
7	1.3694	1.3991	.6219	.567	.6283	.6401	.5487
8	1.1621	1.1652	.6767	.5415	.6468	.5487	.5853
9	1.025	1.0989	.6036	.5415	.5729	.5121	.5304
10	1.1226	1.1157	.6401	.5228	.5175	.4938	.5304
11	1.1965	1.1477	.6401	.0678	.6468	.5853	
12	1.3709	1.2056	.6401	.0678	.5359	.567	
13	1.4136	1.3336	.7133	.5914	.5544	.567	
14	1.4479	1.2994	.6584	.5914	.6838	.6584	
15	1.4373	1.2064	.6401	.5914	.6468	.567	
16	1.4769	1.2955	.695	.6283	.7762	.7316	
17	1.5295	1.3322	.7316	.567	.7577	.6584	
18	1.4083	1.2529	.823	.6401	.6838	.7316	
19	1.8313	1.6346	.9877	.8779	.924	.7865	
20	2.1368	1.8328	1.134		1.0242	.9328	
21	1.9936	1.7665	.8962		.9511	.8779	
22	1.8488	1.7276	.823		.823	.823	
23	1.6453	1.4997	.7316		.7499	.6767	
24	1.3558	1.3344	.5853	.6036		.7133	.5853
Max	2.1368	1.8328	1.134	.8779	1.0242	.9328	.6219
Min	1.025	1.0989	.4755	.0678	.5175	.4938	.4755
Avg	1.4019	1.3294	.6851	.5437	.6852	.6600	.5454

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 203 / 11 KV MAHAVEER AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9448	.7459	.8951				1.9027
2	.8619	.7459	.8951	.9012			1.9043
3	.8619	.7459	.8951	.9012			1.8928
4	.8619	.7459	.8785	.9012			1.9033
5	.8619	.7459	.8785	.9012			1.9469
6	.8619	.7625	.8951	.9012			1.9846
7	.8619	.7625	.9282	.8848			2.0237
8							1.9673
9			.8122	.8619	1.5434		
10			.8619	1.0277	1.9547		
11			.9945	1.094	1.9107		
12			.9779	1.0442	2.0451		
13			.9282	.9282	.8901		
14			.9116	.9282	1.176		
15			.9282	1.0774	2.3074		
16		.0972	.9614	1.0442	2.2737		
17					1.2498		
18					1.0277		.0259
19							.0046
20					1.0242		
21	.7625						
22	.779	.8785				1.533	.6744
23	.779	.8951				1.9419	1.105
24	.9448	.779	.8785	.9339		1.073	1.9767
Max	.9448	.8951	.9945	1.094	2.3074	1.9419	2.0237
Min	.7625	.0972	.8122	.8619	.8901	1.073	.0046
Avg	.8529	.7186	.9075	.9554	1.5821	1.5160	1.4856

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 204 / 11 KV NARWAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4533	.4792	.1989	3.8531		6.1454	.4761
2	.3868	.4731	.1658	3.6381	3.1333	6.1423	.455
3	.3868	.4639	.1658	3.5894	4.0661	6.0494	.4504
4	.3868	.4761	.1658	3.5543	4.1362	5.9549	.467
5	.3944	.4853	.1989	3.6031	4.5014	5.9454	.4883
6	.4412	.5428	.2652	3.911	1.9052	6.4952	.5156
7	.5217	.6019	.2652	4.51	6.4578	6.7798	.5639
8	.5385	.6296	.2486	.555	.7153	.0527	.5613
9	7.9092	6.5084	.2321	.5142	.5249	.5426	7.9815
10	8.2049	7.1824	.2321	.5125	.5369	7.4665	7.5164
11	8.184	8.3631	.2155	.5519	.5443	7.5124	8.3101
12	7.7357	1.9692	.1989	.5336	.5083	7.9788	1.2605
13	4.4914	6.5848	.2155	.4074	.4595	7.9329	
14	2.9004	8.1706	.2155	.5671	.4489	8.2244	
15	3.6778	8.179	.2321	.555	.4353	7.9805	
16	6.1405	6.3104	.2486	.5489	.4397	7.7742	3.6168
17	.2042	.6479	.2321	.5914	.5293	.4963	.7697
18	.5441	.6171	.2155	.6005	.6383	.5004	.317
19	.6444	.6927	.3647	.5367	.6639	.6307	.3704
20	.7232	.7459	.3647	.3094	.7362	.7217	.4298
21	.6735	.7385	.3481		.6996	.7066	.4207
22	.6324	.6733	3.3813		6.8816	.6173	.381
23	.5461	.5793	3.3813		7.0493	.5491	.3567
24	.502	.5005	.2321	.2347	3.7464	3.2921	.4944
Max	8.2049	8.3631	3.3813	4.51	7.0493	8.2244	8.3101
Min	.2042	.4639	.1658	.2347	.4353	.0527	.317
Avg	2.3843	2.6090	.4993	1.6037	2.1634	4.4372	1.7239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 205 / 11 KV MHAISHAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.5763	4.819	2.0081	2.0671		.1638	5.2652
2	4.3556	4.7207	1.9757	2.074	.0486	.163	5.1128
3	4.3152	4.6864	1.9433	2.071	.0945	.1638	4.9589
4	4.2916	2.9755	1.9433	2.0725	.1441	.1615	4.8438
5	4.3617	4.5743	1.9433	2.0748	.1433	.163	4.8133
6	4.4966	4.659		2.2035	.0328	.1787	4.8529
7	4.9577	5.0309	2.1214	2.2104	.1456	.2004	5.0359
8	1.6494	1.6463	.081	.2236	.1126	.2187	2.9751
9	.209	.2052	2.3482	5.4466	3.1661	.1798	.1897
10	.1646	.1684	2.5911	6.0257	4.638	.1399	.1741
11	.1732	.1433	2.5587	5.9854	4.1876	.1348	.109
12	.2222	.1662	2.5101	3.4645	4.835	.1684	.1151
13	.2052	.1723	2.4291	5.6432	5.0077	.1653	
14	.1829	.1892	2.3482	5.5677	2.9271	.1684	.1014
15	.1059	.1907	2.4939	5.5476	2.7006	.1924	.125
16	.0015	.1917	2.42	5.4405	5.4948	.1901	.1219
17		.1793	.0663	3.0026	3.1402	.1993	.0854
18	.0486	.1907	.0829	.2195	.2067	.2038	.1036
19	.213	.2138	.0995	.2099	.2248	.2038	.1181
20	.2491	.2207	.0829	.1143	.2195	.189	.1196
21	.2582	.2006	.0829	.1181	.2115	.2092	.125
22	5.1676	4.7756	.0663		.2054	3.7273	1.1683
23	5.4527	4.7207	.0829		.1676	5.4801	2.8418
24	5.0922	4.7401	2.0729	2.1052	.0998	3.0346	5.3094
Max	5.4527	5.0309	2.5911	6.0257	5.4948	5.4801	5.3094
Min	.0015	.1433	.0663	.1143	.0328	.1348	.0854
Avg	2.2065	2.0742	1.4936	2.9040	1.6589	.6666	2.1159

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 206 / 11 KV NARWAD GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2052	.2021	.0924	.2225		.211	.2065
2	.2006	.1968	.0924	.2225	.1623	.1989	.2004
3	.1991	.1945	.0924	.221	.1996	.195	.1989
4	.1983	.1922	.1109	.2187	.1943	.1912	.2156
5	.1991	.1968	.1109	.2408	.2042	.1905	.2126
6	.2113	.2498	.1294	.2812	.253	.2469	.2484
7	.2918	.2519	.1294	.2736	.2499	.2454	.217
8	.2326	.2136	.1109	.2269	.2408	.2164	.1943
9	.2006	.1783	.0739	.1918	.2126	.1014	.1859
10	.1814	.1869	.1109	.1775	.192	.1585	.17
11	.1953	.1593	.0739	.1615	.1973	.1752	.0914
12	.1537	.1869	.0924	.1263	.1973	.1889	.0907
13	.0572	.2059	.1109	.1246	.1943	.1867	
14	.1676	.7347	.0924	.2461	.2034	.1996	.1204
15	.2168	.229	.1109	.2324	.2164	.1867	.1242
16	.2252	.1976	.0924	.2191	.2316	.1958	.1227
17	.2468	.2244	.1109	.2567	.2484	.2522	.1273
18	.2711	.2574	.1294	.3117	.2781	.2377	.1509
19	.3357	.3441	.1663	.2835	.3216	.3033	.1372
20	.3967	.4304	.2218	.1638	.423	.3818	.2004
21	.3759	.4066	.2033		.4092	.397	.208
22	.366	.3683	.1663		.3597	.365	.2004
23	.2793	.2908	.1294		.3315	.3079	.1654
24	.2151	.2397	.1109	.1097	.1372	.2499	.2423
Max	.3967	.7347	.2218	.3117	.423	.397	.2484
Min	.0572	.1593	.0739	.1097	.1372	.1014	.0907
Avg	.2343	.2641	.1194	.2149	.2460	.2326	.1753

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 207 / 11 KV WATER WORKS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0532	.0492	.048	.0492		.0497	.048
2	.0532	.0492	.048	.0492	.0339	.0509	.048
3	.0537	.0492	.048	.0492	.0339	.0509	.048
4	.0537	.0492	.048	.0492	.0339	.0509	.048
5	.0537	.0497	.048	.0492	.0324	.0509	.048
6	.0537	.0503	.048	.0492	.0486	.0503	.048
7	.0537	.0463	.048	.0474	.0486	.0678	.048
8	.0537	.0671	.048	.0503	.0655	.0671	.064
9	.0537	.0655	.048	.0503	.0655	.0678	.064
10	.0716	.0655	.064	.0671		.0678	.064
11	.0716	.0686	.0671	.0678	.0663	.0678	
12	.0716	.0686	.0671	.0678	.0663	.0678	
13	.0716	.0663	.0655	.0678	.0663	.0678	
14	.0716	.0663	.0655	.0663	.0663	.0655	
15	.0716	.0663	.0655	.0663	.0663	.0655	
16	.0716	.0663	.0663	.0648	.0663	.0655	
17	.0716	.0663	.0663	.0648	.0497	.0655	
18	.0537	.064	.0663	.0509	.0497	.0655	
19	.0492		.0492	.0509	.0486	.0655	
20	.0486	.064	.0492		.0486	.0655	
21	.0492	.048	.0492		.0503	.0655	
22	.0492	.048	.0492		.0492	.0655	
23	.0492	.048	.0492		.0492	.064	
24	.0532	.0492	.048	.0492		.0497	.048
Max	.0716	.0686	.0671	.0678	.0663	.0678	.064
Min	.0486	.0463	.048	.0474	.0324	.0497	.048
Avg	.0586	.0579	.0550	.0563	.0526	.0617	.0524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 203 / 11 KV Subhashnagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5403	.5342	.5624	.4595	.5182	.4954
2	.5136	.5129	.5274	.4458	.5068	.4733
3	.4938	.5022	.5213	.4435	.4915	.4679
4	.4801	.4885	.5068	.4306	.4755	.4458
5	.4946	.5167	.5136	.4359	.4832	.4435
6	.6089	.6051	.6036	.4931	.586	.5182
7	.6485	.6562	.6592	.5693	.5914	.5769
8	.5868	.6013	.615	.5754	.5525	.5655
9	.4969	.5159	.5487	.5426	.5114	.4984
10	.5716	.5761	.567	.5632	.4877	.4473
11	.5357	.5723	.5738	.5754	.471	.4656
12	.6188	.6196	.5738	.6287	.4999	.4618
13	.6531	.5998	.6234	.6165	.4969	.4481
14	.5411	.5533	.5609	.5434	.4854	.4435
15	.567	.5777	.6211	.5982	.5274	.4786
16	.5975	.5266	.6013	.6081	.5647	.5144
17	.6462	.6112	.6554	.6371	.5815	.5799
18	.7499	.6828	.6935	.7194	.647	.6043
19	.8169	.8284	.8512	.7834	.7781	.7529
20	.8589	.8421	.7324	.8223	.8269	.7705
21	.8002	.8139	.6424	.7735	.7712	.7164
22	.7743	.7575	.6836	.7331	.7301	.6874
23	.7042	.6965	.5929	.6882	.6546	.6493
24	.5754	.583	.4946	.5792	.5281	.5365
Max	.8589	.8421	.8512	.8223	.8269	.7705
Min	.4801	.4885	.4946	.4306	.471	.4435
Avg	.6198	.6156	.6052	.5944	.5736	.5434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 201 / 11 KV Dhavali Ag

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	2.2192		2.0805	.0191
2	.0191	.0191	.0191	2.2192	1.7337	2.0805	.0191
3	.0191	.0191	.0191	2.2192	1.7337	2.0805	.0191
4	.0191	.0191	.0191	2.2192	1.8204	2.0805	.0191
5	.0191	.0191	.0191	2.2192	1.893	2.0805	.0191
6	.0191	.0191	.0191	2.2885	1.9631	2.1033	.0191
7	.0191	.0191	.0191	2.2018	1.9071	1.9669	.0191
8	.0191	.0191	.0191	.0191	.0191	.0191	.0191
9	2.5139	2.1776	.0191	.0191	.0191	2.3579	2.2885
10	2.6179	2.8045	.0191	.0191	.0191	2.4013	2.4539
11	2.3061	2.4539	.0191	.0191	.0191	2.5486	2.3752
12		2.6292	.0191	.0191	.0191	2.4619	
13		2.6006	.0191	.0191	.0191	2.4619	
14	2.0285	2.5312	.0191	.0191	.0191	2.4619	
15			.0191	.0191	.0191	2.4792	
16	2.2885	1.9839	.0191	.0191	.0191	2.4863	
17	.0191	.0381	.0191	.0191	.0191	.0191	
18	.0191	.0381	.0191	.0191	.0191	.0191	
19	.0191	.0191	.0191	.0191	.0191	.0191	
20	.0191	.0191	.0191		.0191	.0191	
21	.0191	.0191	.0191		.0191	.0191	
22	.0191	.0191	2.2961		2.191	.0191	
23	.0191	.0191	2.2961		2.1672	.0191	
24	.0191	.0191	.0191	2.2192		2.1152	.0191
Max	2.6179	2.8045	2.2961	2.2885	2.191	2.5486	2.4539
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.5743	.7619	.2089	.9017	.7126	1.5167	.6075

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 202 / 11 KV Nilaji Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4489	2.7069	1.2742	.0191	.0191	.0191	2.9237
2	2.492	2.6925	1.2742	.0191	.0191	.0191	2.9256
3	2.4402	2.678	1.2742	.0191	.0191	.0191	2.9088
4	2.425	2.665	1.2742	.0191	.0191	.0191	2.8783
5	2.4486	2.6925	1.073	.0191	.0191	.0191	2.8913
6	2.4874	2.7466	1.0852	.0191	.0191	.0191	2.9317
7	2.5789	2.7047	1.1142	.0191	.0191	.0191	2.9732
8	.0191	.0191	.0191	.0191	.0503	.0191	.0191
9	.0191	.0191	1.8111	3.8192	3.557	.0191	.0191
10	.0191	.0191	1.9753	3.888	3.5976	.0191	.0191
11	.0191	.0191	1.8656	3.9015	3.8569	.0191	.0191
12	.0191	.0191	1.6057	3.5456	3.8714	.0191	.0191
13	.0191	.0191	1.7924	3.6493	3.7197	.0191	.0191
14	.0191	.0191	1.829	3.6128	3.3402	.0191	
15			1.8656	3.5372	3.3235	.0191	
16	.0191	.0191	1.7375	3.7852	2.6776	.0191	
17	.0191	.0191	.0191	.2355	.0206	.0191	
18	.0191	.0191	.0191	.0191	.0191	.0191	
19	.0191	.0191	.0191	.0191	.0191	.0191	
20	.0191	.0191	.0191	.0191	.0191	.0191	
21	.0191	.0191	.0191	.0191	.0191	.0191	.0678
22	2.8197	2.7138	.0191	.0191	.0191		1.5653
23	2.7732	2.8052	.0191	.0191	.0191	2.9652	1.5935
24	2.8189	2.7736	1.2887	.0343		1.6248	2.9435
Max	2.8197	2.8052	1.9753	3.9015	3.8714	2.9652	2.9732
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	1.1296	1.1925	1.0122	1.2615	1.2288	.2170	1.5716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 203 / 11 KV Krishna Ghat

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3224	.3403	.3012	.3189		.3155	.3155
2	.3224	.3403	.3012	.3012	.2715	.3155	.298
3	.3224	.3403	.3012	.3012	.2715	.3155	.298
4	.3224	.394	.3012	.3012	.2715	.3155	.298
5	.3403	.4207	.3012	.3189	.2896	.3155	.3155
6	.4119	.4733	.3012	.3189	.3045	.3189	.3155
7	.4115	.4656	.3315	.3506	.3294	.3441	.3052
8	.4748	.4527	.39	.407	.3856	.373	.3688
9	.5596	.4973	.39	.407	.421	.4321	.5144
10	.6344	.5256	.4915	.503	.4973	.4527	.5658
11	.5967	.5365	.4915	.547	.4641	.503	.5596
12	.6203	.502	.4915	.502	.4475	.5304	.57
13	.5935	.4752	.4915		.4527	.57	.5636
14	.6135	.4588	.4588	.39	.4191	.5935	
15	.5487		.4191	.4578	.4578	.5533	
16	.5365	.3561	.431	.4588	.4191	.5365	
17	.6104	.502	.4641	.4915	.4801	.4915	
18	.5087	.4374	.3978		.4424	.4696	
19	.4973	.4475	.3856	.3772	.4862	.4527	
20	.443	.421	.3814		.4239	.4287	
21	.4477	.4161	.4163		.4207	.4115	
22	.4163	.3045	.394		.3582	.3898	
23	.4119	.3012	.3224		.3403	.3277	.3401
24	.3403	.3582	.298	.3494		.3506	.3401
Max	.6344	.5365	.4915	.547	.4973	.5935	.57
Min	.3224	.3012	.298	.3012	.2715	.3155	.298
Avg	.4711	.4246	.3856	.3945	.3934	.4211	.3979

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 204 / 11 KV Takali Bolwad Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.1646	.1829	2.1628		1.8351	.168
2	.1867	.1646	.1829	2.1879	1.1336	1.8351	.168
3	.1867	.1663	.1829	2.1548	1.2146	1.8351	.168
4	.1867	.1663	.1829	2.1382	1.2146	1.8351	.168
5	.1867	.1848	.1829	2.1382	1.4575	1.8351	.1867
6	.1867	.2054		2.1382	1.7859	1.989	.1867
7	.2103	.2033		2.3537	2.0553	1.9109	.2012
8	.1578	.1844		.1646	.1772	.1629	.1433
9	2.5069	2.4366		.1629	.1509	2.3137	2.0222
10	3.1017	2.3472		.1612	.1387	2.1879	1.9662
11	.141	2.3137		.1595	.1372	2.652	1.9826
12		2.1956	.1402	.1543	.1526	2.5526	
13		2.4249	.1595	.1543	.1509	2.5526	
14	1.6575	2.556	.1612	.1543	.1475	2.5069	
15			.1646	.1543	.1402	2.4577	
16	1.8896	2.5101	.156	.144		2.3482	
17	.1174	.1638	.1578	.1326	.1147	.1372	
18	.1214	.1619	.156	.1526		.1543	
19	.1991	.2427	.2012	.2149	.2012	.2012	
20	.2033	.2561	.2218		.2218	.2218	
21	.2054	.2427	.2241		.2241	.2033	
22	.2033	.2241	2.3304		1.7901	.2054	
23	.1829	.2033	2.304	.0191	1.8842	.168	
24	.2012	.1629	.1829	2.2119		1.8351	.168
Max	3.1017	2.556	2.3304	2.3537	2.0553	2.652	2.0222
Min	.1174	.1619	.1402	.0191	.1147	.1372	.1433
Avg	.5818	.8644	.4152	.9245	.7246	1.4973	.6274

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 206 / 11 KV Dhavali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2858	.2667	.1886		.2641	.2641
2	.2641	.2858	.2667	.1886	.2452	.2641	.2641
3	.2641	.2858	.2667	.1886	.2452	.2641	.2641
4	.2641	.3048	.2667	.1886	.2452	.2641	.2641
5	.2829	.3048	.2858	.1886	.2829	.2641	.2641
6	.3018	.3048	.3018	.2452	.3206	.3018	.2829
7	.2829	.3018	.3018	.2263	.3018	.2641	.2829
8	.2452	.2427	.2452	.1886	.2452	.2452	.2075
9	.2452	.2427	.2075	.132	.2263	.2263	.1886
10	.2241	.2263	.2075	.132	.2263	.1698	.168
11	.2241	.2075	.2263	.132	.2263	.2263	.1524
12	.2614	.2263	.2263	.1509	.2452	.2641	.1524
13	.2614	.2263	.2263	.132	.2452	.2452	.1905
14	.2801	.2452	.2263	.132	.2452	.2452	
15	.2641		.2452	.2075	.2452	.2263	
16	.2263	.132	.1886	.2263	.2263	.2263	
17	.2452	.2263	.1886	.1886	.2263	.2263	
18	.2263	.2263	.1509	.2263	.2452	.2263	
19	.3174	.3395	.2641	.3018	.2829	.3206	
20	.3206	.3395	.2641		.3206	.3206	
21	.3206	.3018	.2452		.3206	.3018	
22	.3239	.3048	.2263	.0191	.3239	.2829	
23	.3048	.2858	.2075	.0191	.3018	.2829	
24	.2641	.2858	.2667	.1886		.2641	.2641
Max	.3239	.3395	.3018	.3018	.3239	.3206	.2829
Min	.2241	.132	.1509	.0191	.2263	.1698	.1524
Avg	.2700	.2666	.2404	.1723	.2633	.2578	.2293

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244052 / 33/11 KV MALLEWADI

Feeder No / Name : 202 / 11 KV Malgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2931	2.1178	.4763	.3277	.3742	2.2878
2	2.2481	2.0439	.4641	.3109	.3719	2.111
3	2.1887	1.9738	.4633	.3102	.3673	1.9875
4	2.2824	2.0058	.4771	.3147	.3711	1.9608
5	2.3495	2.1635	.4931	.3361	.3993	1.9982
6	2.5522	2.3754	.5647	.4199	.4877	2.5286
7	3.3608	2.0127	.5975	.4473	.4999	3.11
8	.5083	.4306	.5815	.4054	.4382	.3849
9	.5068	.474	2.889	2.2763	.4016	.4191
10	.4915	.4839	3.1939	2.7	.3765	.397
11	.5266	.5205	2.7183	2.2009	.4062	.4214
12	.5921	.4115	2.4882	.5548	.4245	.4504
13	.599	.4443	2.8349	2.6459	.4176	.4367
14	.1341	.4527	2.8471	2.5446	.4237	.4268
15	.5037	.4588	2.9477	2.8052	.3635	.4115
16	.5388	.4976	2.3685	2.9005	.3871	.4115
17	.5007	.5624	.3605	.6348	.4374	.1638
18	.5906	.5937	.4397	.4923	.5037	.3254
19	.6714	.6744	.4047	.5281	.5441	.5754
20	.6988	.7026	.4306	.599	.6013	.6257
21	.6683	.7484	.3871	.5853	.5761	.6356
22	2.8212	2.5194	.3856	.5182	2.9005	2.7664
23	3.014	2.6581	.3574	.423	2.9241	2.6185
24	2.1971	2.4897	.3338	.3826	2.5286	2.2931
Max	3.3608	2.6581	3.1939	2.9005	2.9241	3.11
Min	.1341	.4115	.3338	.3102	.3635	.1638
Avg	1.3682	1.2423	1.2294	1.0693	.7303	1.2395

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 201 / Soni Gavathan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.2743	.2641	.6521	.5938	.5771	.5442
2	.2829	.2743	.2452	.6075	.5583	.5778	.2942
3	.2829	.2743	.2452	.6007	.5514	.5755	.2949
4	.2801	.2743	.2452	.5854	.5748	.5641	.2766
5	.2987	.2915	.3206	.6361	.6051	.5883	.2873
6	.3772	.3429	.3772	.7438	.6817	.7303	.3422
7	.3142		.2452	.7038	.5994	.6278	.3498
8	.2149	.2614	.2641	.5583	.5971	.4803	.2713
9	.2172	.1867	.2263	.559	.5677	.4952	.2698
10	.2401	.2054	.2614	.5739	.5546	.479	.253
11	.2401	.2427	.2801	.5672	.5518	.5091	.2423
12	.2572	.3174	.2987	.546	.5491	.5266	.2522
13	.2572	.2801	.2987	.565	.2698	.5289	.2896
14	.2401	.2987	.2987	.6015	.5178	.5636	.2797
15	.2743	.2614	.2801	.5974	.5308	.5662	.2995
16	.2401	.2241	.2801	.5818	.5201	.5605	.2919
17	.2572	.2241	.2801	.529	.5951	.5289	.2683
18	.2915	.2614	.2801	.5791	.6276	.599	.2782
19	.3944	.3921	.4108	.7901	.8529	.8033	.7625
20	.4115	.4527		.4161	.9615	.9461	.9553
21	.3601	.4715			.9168	.8772	.8688
22	.3601	.3584	.4108	.7659	.8358	.7952	.7807
23	.3086	.3206	.3547	.7198	.7251	.6614	.6885
24	.2829	.3174	.2641	.7585	.5999	.631	.5518
Max	.4115	.4715	.4108	.7901	.9615	.9461	.9553
Min	.2149	.1867	.2263	.4161	.2698	.479	.2423
Avg	.2903	.2960	.2923	.6190	.6224	.6164	.4164

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 202 / 11 KV Bhose Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2058	.2641	.6075	.6479	.5994	.5955
2	.2641	.2058	.2263	.4896	.5523	.5551	.3125
3	.2641	.2058	.2263	.546	.5361	.5487	.3113
4	.2641	.2058	.2263	.5452	.5254	.5395	.3025
5	.2829	.2058	.2263	.5426	.4412	.4351	.3025
6	.2075	.1886	.2452	.5594	.4538	.4664	.2233
7	.2054		.2452	.5502	.4717	.4544	.2362
8	.1886	.1867	.2075	.716	.4191	.4149	.2397
9	.2402	.2054	.1886	.8204	.374	.4283	.2801
10	.3429	.3734	.4668	.6432	.3818	.3586	.3338
11	.3086	.4854	.4481	.7921	.7147	.4584	.3147
12	.2572	.4481		.8348	.5247	.7136	.3688
13	.4115	.5601	.4108	.7986	.4176	.7155	.3864
14	.2229	.2241	.2054	.493	.672	.5932	.3551
15	.3601	.2801	.2801	.6557	.6559	.8032	.3414
16	.3429	.2614	.2987	.7804	.9985	.9865	.4256
17	.3086	.2614	.3921	.7446	.6531	.8002	.3399
18	.2401	.2241	.3174	.6644	.539	.7887	.2473
19	.2743	.2987	.2801	.5834	.5759	.5762	.2035
20	.2915	.3174		.3022	.6253	.5423	.2671
21	.3258	.2641			.5007	.5281	.2675
22	.3258	.3772	.4108	.4704	.595	.7114	.2808
23	.2743	.3395	.3361	.6882	.6348	.6969	.6966
24	.2641	.2401	.3734	.6859	.6466	.6506	.6058
Max	.4115	.5601	.4668	.8348	.9985	.9865	.6966
Min	.1886	.1867	.1886	.3022	.374	.3586	.2035
Avg	.2805	.2854	.2988	.6310	.5649	.5986	.3432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 203 / 11 KV Siddhewadi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1539	.1524	.0754	1.2643	.7301	.5506	.0857
2	.1547	.1501	.0754	1.0591	.7141	.5344	
3	.1531	.1494	.0754	.8226	.7118	.5344	
4	.1455	.1509	.0754	.823	.7716	.5344	
5	.1547	.154	.0754	1.0921	.8284	.5668	
6	.2077	.184	.0943	1.3969	1.073	.5992	
7	.2139	.1189	.0943	2.1467	1.4969	.7449	
8	.1593	.2207	.0754	.1963	.1986	.1132	
9	2.3381	2.3602	.1132	.2001	.197	.8907	
10	2.3998	2.5492	.112	.2047	.1986	.9145	
11	2.4447	2.5316	.1494	.1036	.1871	.9907	
12	2.3205	2.4038	.0934		.1932	.945	
13	1.1888	2.2546	.112	.1204	.0983	.8383	
14	.5685	2.1194	.112	.1654	.1864	.8535	
15	.8154	2.2393	.112	.1639	.1887	.884	
16	1.7109	2.516	.112	.197	.208	.9145	
17	.1837	.1608	.0934	.1948	.17	.1029	
18	.2023	.1812	.112	.2138	.2515	.12	
19	.2119	.2313	.112	.2217	.2382	.1372	
20	.2347	.276		.1235	.2466	.1372	
21	.2503	.2496			.2966	.1372	
22	.2023	.2351	.7682	.7118	1.3941	.1029	
23	.1863	.2101	.6722	.8276	1.3859	.1029	.0934
24	.163	.1855	.0754	1.0183	1.0441	.5668	.0857
Max	2.4447	2.5492	.7682	2.1467	1.4969	.9907	.0934
Min	.1455	.1189	.0754	.1036	.0983	.1029	.0857
Avg	.6985	.9160	.1541	.6031	.5420	.5340	.0883

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 204 / Soni AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1543	.1509	1.1336		.7935	.1372
2	.1509	.1372	.1509	.6478		.7935	
3	.1509	.1372	.1509	.7202		.7935	
4	.1509	.1372	.1698	.8097		.7773	
5	.1509	.1715	.1886	.9717		.6478	
6	.1886	.2572	.2075	1.2003		.6802	
7	.1886		.2263	1.4563		.9717	
8	.1307	.2614	.1698	.168		.1698	
9	1.4413	1.587	.1698	.2054		1.2793	
10	1.5851	1.5223	.168	.1867		1.2955	
11	1.5394	1.587	.168		.0754	.945	
12	1.4937	1.0202	.1867			1.0669	
13			.1867			1.2346	
14	.7468	1.4089	.168		.6964	1.3565	
15		1.7004	.168		.1132	1.326	
16	1.0517	1.5223	.168		.1132	1.4632	
17	.12	.1867	.168	.2054	.1698	.1372	
18	.1715	.2054	.1867	.2614	.1509	.1715	
19	.2058	.2427	.2427	.2241	.2075	.2229	
20	.2401	.2054			.2263	.2058	
21	.2058	.2263			.2263	.1543	
22	.2058	.1886	1.3279		.9717	.1715	
23	.1715	.1698	1.2323		.9069	.1543	.1867
24	.1509	.1543	.1509	1.2098		.8259	.1372
Max	1.5851	1.7004	1.3279	1.4563	.9717	1.4632	.1867
Min	.12	.1372	.1509	.168	.0754	.1372	.1372
Avg	.4814	.5992	.2776	.6715	.3507	.7349	.1537

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 206 / 11kv Karoli AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1372	.132	.5506	.2721	.4534	.1715
2	.1698	.1372	.132	.4001	.2561	.4534	
3	.1698	.1372	.132	.5601	.2561	.4534	
4	.1698	.1372	.132	.6478	.2915	.4534	
5	.1886	.1715	.1886	.8802	.3563	.4858	
6	.2641	.2572	.3018	1.1336	.4696	.583	
7	.2641		.2641	1.0722	.8421	.6964	
8	.1867	.1867	.1886	.168	.168	.1698	
9	1.0202	.8322	.132	.1307	.1307	.3077	
10	.8993	.9393	.1494	.1307	.0934	.2743	
11	.8535	.8745	.1494	.1307	.0934	.7164	
12	.823	.4858	.1494	.1307	.112	.7011	
13		.7611	.1494	.1494		.7011	
14	.3658	.8421	.1307	.1307	.112	.7468	
15		1.004	.1307	.1307	.1307	.7773	
16	.6859	.8097	.1307	.1307	.2054	.7773	
17	.1029	.132	.168	.1867	.1494	.1029	
18	.1372	.1886	.1867	.1867	.1698	.1715	
19	.2401	.2829	.2801	.2241	.3018	.2572	
20	.2743	.2641			.3395	.2572	
21	.2401	.2641			.2641	.2401	
22	.2058	.2075	1.1012	.3841	.6316	.2058	
23	.1715	.1886	.5761	.2721	.5506	.2058	.1867
24	.1698	.1372	.1509	.5811	.2881	.4858	.1715
Max	1.0202	1.004	1.1012	1.1336	.8421	.7773	.1867
Min	.1029	.132	.1307	.1307	.0934	.1029	.1715
Avg	.3533	.4077	.2298	.3778	.2819	.4449	.1766

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 207 / 11KV Bhose AG Spare
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7814	1.6766	1.4575	.1132	.0943	.2263	1.5394
2	1.6004	1.6461	1.4575	.1132	.0943	.2075	
3	1.5524	1.6461	1.4251	.1132	.0943	.2075	
4	1.5524	1.6461	1.4251	.1132	.0943	.2075	
5	1.587	1.7071	1.4899	.132	.0943	.2263	
6	2.0243	1.8747	1.6356	.132	.1132	.2452	
7	2.17		1.7814	.1509	.1132	.132	
8	.1307	.0686	.1698	.1307	.0934	.132	
9	.112	.0747	2.2186	2.5606	2.0567	.132	
10	.1029	.0747	2.0805	2.672	2.2672	.12	
11	.1029	.0747	1.8084	2.5911	2.2672	.12	
12	.0686	.1494		2.4777	1.9919	.12	
13	.1372	.168	1.9204	2.2186		.12	.1307
14	.0686	.1494	1.8724	2.2024	1.9919	.12	.112
15	.1372	.168	2.1052	2.3805	2.332	.1029	.112
16	.1543	.168	2.2672	2.1862	2.3482	.1372	.1307
17	.1543	.168	.1307	.1307	.1509	.1372	.1494
18	.1543	.168	.1307	.1307	.132	.1372	.168
19	.1543	.1867	.168	.168	.1698	.1372	.168
20	.1543	.1867			.1509	.1543	.1867
21	.1543	.1698			.1509	.1715	.1494
22	1.7985	1.4899	.168	.0934	.2263	1.89	1.9204
23	1.768	1.4899	.112	.0943	.2263	1.7985	1.8404
24	1.9919	.1692	1.4899	.1132	.0943	.2452	1.7071
Max	2.17	1.8747	2.2672	2.672	2.3482	1.89	1.9204
Min	.0686	.0686	.112	.0934	.0934	.1029	.112
Avg	.8172	.6661	1.3007	.9554	.7543	.3011	.6396

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 201 / 11 KV Savali Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.924	.9808	.7577	.1886	.1886	.1886	.9335
2	.9335	.9335	.7392	.1867	.2054	.1867	.9335
3	.9808	.9431	.7392	.2241	.2075	.1886	.9335
4	1.0269	.9709	.8215	.2218	.2241	.1867	.5601
5	.7659	1.0562	.8871	.1848	.2263	.2241	.5914
6	1.1706	1.2071	.9709	.2241	.2263	.2263	.8131
7	1.4937	.1886	1.2382	.2263		.2241	1.2323
8	.1886	.1886	1.1088	.2241		.1886	.2218
9	.1867	.1867	1.2323	1.3957		.1867	.1848
10	.2263	.1886	1.363	1.531	1.0082	.1886	.1867
11	.1867	.168	1.307	1.4712	1.0349	.1867	.1886
12	.1867	.168	1.2803	1.3817	1.1203	.2075	
13	.1848	.1886	1.2567	1.358	1.1576	.168	
14		.168	1.2382	.9709	.8962	.1698	
15		.1698	1.2437	1.1317	.961	.168	
16	.2033	.1886	1.2936	1.2323	.961	.1886	
17	.2033		.2075	.1886	.1867	.1867	
18	.2033	.2218	.2241	.1867	.1867	.1886	
19	.2263	.2987	.2263	.2427	.2263	.2801	
20	.2614	.2987			.2641	.2772	
21	.3018	.2614			.2614	.2614	
22	1.0082	.8402	.2641	.1132	.2614	.9979	
23	1.0185	.7842	.2241	.1886	.2263	.9335	.8962
24	.9709	.9709	.7842	.1886	.1494	.2241	.9335
Max	1.4937	1.2071	1.363	1.531	1.1576	.9979	1.2323
Min	.1848	.168	.2075	.1132	.1494	.168	.1848
Avg	.5842	.5031	.8822	.6028	.4847	.2678	.6622

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 202 / 11 KV SAIPRASAD

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5281	.5975	.695	.7922	.415	.679	.6535
2	.5041	.6036	.7095	.7468	.4294	.6413	.6535
3	.547	.5601	.7095	.6722	.4481	.6348	.6535
4	.5601	.5658	.6908	.6413	.4715	.6036	.5601
5	.5281	.5975	.6838	.6036	.4668	.5975	.5544
6	.5415	.5658	.6722	.5601	.5041	.5658	.5788
7	.5228	.5228	.6722	.5658		.5228	.5975
8	.5281	.5847	.5544	.5228		.4904	.4805
9	.5415	.6161	.6348	.5658		.5228	.5601
10	.6224	.6722	.7095	.6722	.6722	.7167	.462
11	.8029	.6348	.8488	.679	.8589	.7095	.4338
12	.8402	.6602	.8962	.6348	1.0829	.7167	.4108
13	.8402	.6722	.8676	.6722	1.0642	.7468	
14	.8589	.7095	.8501	.7167	.7282	.8488	
15	.8871	.7545	.8775	.7468	.9522	.8775	
16	.9335	.7468	.8589	.811	.9795	.9054	
17	.7468		.9054	.7842	1.0534	.9149	
18	.5788	.5228	.8589	.6602	.6348	.6348	
19	.6036	.5281	.8299	.7095	.6413	.6348	
20	.5788	.5041			.6161	.6161	
21	.6036	.6348			.6602	.7282	
22	.7468	.8029	.7922		.7282	.8029	
23	.679	.7095	.8215	.3018	.7733	.6908	.679
24	.5601	.6161	.7095	.8488	.4108	.7095	.6722
Max	.9335	.8029	.9054	.8488	1.0829	.9149	.679
Min	.5041	.5041	.5544	.3018	.4108	.4904	.4108
Avg	.6535	.6253	.7658	.6623	.6948	.6880	.5678

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 203 / 11 KV Savali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.3395	.3361	.2614	.2614	.2614	.2987
2	.2452	.2641	.3142	.2263	.2614	.2452	.2957
3	.2402	.2614	.3142	.2263	.2241	.2427	.2987
4	.2614	.2614	.3142	.2241	.2263	.2263	.2587
5	.2829	.2614	.3361	.2614	.2614	.2614	.2772
6	.3174	.3584	.3361	.2641	.3142	.3206	.3174
7	.3018	.3395	.3361	.2614	.3547	.2829	.3142
8	.2587	.2987	.2801	.2641	.2829	.2427	.2427
9	.2987	.2829	.3174	.2987	.2829	.3018	.2402
10	.3206	.3547	.2987	.3361		.3174	.2054
11	.3696	.3584	.4481	.3584	.4066	.3772	.2263
12	.3734	.3361	.4338	.3734	.3734	.3584	.2614
13	.3734	.3395	.3206	.3361	.3696	.2829	
14	.3547	.3361	.3547	.3395	.4108	.3174	
15	.3361	.2987	.415	.3584	.3921	.3395	
16	.3547	1.8484	.4481	.3734	.2957	.3772	
17	.3734	.2614	.415	.415	.3174	.4294	
18	.4481	.5041	.3734	.4481	.3511	.415	
19	.4904	.5228	.3734	.5658	.4338	.499	
20	.5228	.4854			.4668	.4668	
21	.4715	.4481			.4294	.3921	
22	.4294	.4108	.4108	.1307	.415	.3547	
23	.3772	.3511	.3772	.2987	.3395	.3547	.2987
24	.2957	.3361	.3326	.2667	.3018	.2987	.2957
Max	.5228	1.8484	.4481	.5658	.4668	.499	.3174
Min	.2402	.2614	.2801	.1307	.2241	.2263	.2054
Avg	.3483	.4108	.3585	.3131	.3379	.3319	.2736

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 204 / BOTHRA FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6066	1.3596	.6908	1.0765	.7171	.9099	.977
2	.6409	1.3657	.6908	1.2289	.796	.9426	.9053
3	.682	1.3279	.6722	1.1001	.9443	.9862	.9007
4	.6409	1.1325	.6722	1.2525	.9862	.9443	.6767
5	.5662	1.0616	.6535	1.2087	.8638	.7967	.9007
6	.4746	1.0189	.6535	1.214	.7506	.6797	.8268
7	.378	.9485	.6535	1.0951	.7544	.7967	.5864
8	.4549	.7559	.3734	1.1001	.6984	.7544	.6035
9	.5849	.6828	.4668	1.2072	.7617	.8344	.6984
10	.868	1.2445	.7468	1.5166	.5335	1.0189	.8306
11	1.2632	1.2517	1.0185	1.669	1.2834	1.6297	.759
12	1.5105	1.1713	.9335	1.7375	1.2475	1.6225	.6458
13	1.5291	.9443	.7545	1.736	1.19	1.4358	.3048
14	1.4716	1.0616	.7922	1.8199	.7114	1.4788	.2286
15	1.624	1.3222	.9335	1.9631	1.3581	1.5478	.3048
16	1.736	1.4343	.9808	1.8961	1.2773	1.4788	.3048
17	1.6785	1.5089	.7095	1.6613	1.3207	1.5851	.3048
18	1.624	1.5851	.6036	1.5173	1.0967	1.4041	.2286
19	1.3207	1.5478	.5601	1.1153	.7205	.7544	.2286
20	1.1755	1.2491		.4572	.6797	.4134	.2286
21	1.0563	1.0563			.381	.3764	.2286
22	.9862	1.1325	.4715	.112	.3216	.434	.2286
23	1.4343	1.5478	.4527	.5289	1.0616	1.0902	.6782
24	1.0048	1.4796	.6908	.6813	.836	.9816	.8245
Max	1.736	1.5851	1.0185	1.9631	1.3581	1.6297	.977
Min	.378	.6828	.3734	.112	.3216	.3764	.2286
Avg	1.0547	1.2163	.6898	1.2563	.8871	1.0374	.5585

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 205 / 11 KV REX

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4854	.5601	.5788	.2987	.2801	.5281	.6468
2	.5281	.5847	.5788	.2987	.3772	.547	.6348
3	.5041	.5601	.5788	.3395	.415	.5601	.6283
4	.5041	.5788	.5601	.3772	.547	.547	.6348
5	.499	.5658	.5601	.4854	.547	.5228	.6535
6	.5041	.5788	.5228	.5281	.4904	.547	.6468
7	.5658	.547	.5415	.4854	.415	.5415	.5041
8	.4715	.5601	.4108	.3772	.3547	.5281	.5601
9	.5601	.5658	.5041	.4854	.3921	.5788	.5729
10	.4527	.5601	.5415	.5601	.4108	.5281	.5975
11	.5788	.5658	.4854	.5601	.4668	.5415	.5975
12	.5975	.5228	.4715	.5788	.4854	.5658	.6224
13	.5788	.5228	.5415	.3944	.5041	.5601	
14	.5975	.4904	.5281	.5281	.4854	.6099	
15	.5975	.4668	.4854	.5041	.5544	.6348	
16	.5601	.4481	.4904	.6036	.5415	.6602	
17	.5601	.4854	.4854	.5788	.5601	.6348	
18	.5415	.5415	.4527	.6036	.5975	.6602	
19	.547	.5975	.4108	.5788	.5975	.6653	
20	.5601	.5975			.5847	.7095	
21	.5658	.5601			.5415	.6161	
22	.6036	.5729	.3018	.1494	.547	.6535	
23	.5975	.6099	.2641	.132	.5281	.6722	.5601
24	.4715	.5847	.5788	.2263	.1494	.5041	.6468
Max	.6036	.6099	.5788	.6036	.5975	.7095	.6535
Min	.4527	.4481	.2641	.132	.1494	.5041	.5041
Avg	.5430	.5511	.4942	.4397	.4739	.5882	.6076

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244107 / 33/11KV Malgaon

Feeder No / Name : 201 / 11 KV malgaon Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.5975	.362	.6154		.6099	.6287
2	.5175	.5975	.362	.6154		.6099	.6097
3	.5175	.5975	.362	.6219		.5914	.6097
4	.5175	.5601	.4525	.7023		.5914	.6097
5	.5914	.6283	.543	.7023		.5729	.6478
6	.7133	.743	.6335	.7059		.6668	.6653
7	.6767	.6908	.5792	.695		.5973	.6653
8	.5201	.5249	.5792	.543		.5194	.5373
9	.4917	.4854	.543	.4938		.4681	.4835
10	.5087	.4801	.5068	.5611	.6201	.4784	.4477
11	.5316	.5083	.5201	.5792	.6556	.5316	.2896
12	.5256	.5083	.5014	.6668	.6485	.5197	.3681
13	.5144	.5611	.5373	.6335	.6516	.5087	.3721
14	.4917	.5544	.499	.543	.5784	.5087	.3898
15	.4973	.4961	.5194	.5792	.5847	.5144	
16	.567	.4801	.591	.543	.6154	.5087	
17	.5487	.4525	.6335	.6805	.6241	.5426	
18	.6068	.543	.724	.6805	.6539	.6104	
19	.788	.7602	.823	.8326	.815	.8507	
20	.9412	.8145	.9425		.9231	.9425	
21	.8871	.8688	.924		.9055	.9055	
22	.8402	.6335	.8779		.8402	.8029	
23	.7095	.5792	.724			.6859	
24	.5853	.6283	.362	.6154		.6348	.6287
Max	.9412	.8688	.9425	.8326	.9231	.9425	.6653
Min	.4917	.4525	.362	.4938	.5784	.4681	.2896
Avg	.6099	.5956	.5876	.6305	.7012	.6155	.5302

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244107 / 33/11KV Malgaon

Feeder No / Name : 202 / 11 KV Cannal AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.381	.381	1.2811		.945	.381
2	.3048	.362	.3429	1.2811		.9686	.381
3	.3048	.362	.3429	1.2811		.9686	.381
4	.2858	.362	.2858	1.3117		.9374	.4191
5	.2858	.4191	.2858	1.406		.9646	.4572
6	.3048	.4572	.2858	1.4175		1.1203	.4954
7	.3429	.5144	.4763	1.5653		1.186	.362
8	.3239	.4954	.4763	.4001		.3429	.4001
9	1.5242	1.9134	.4191	.4382		1.2803	1.6004
10	1.6762	2.1872	.4572	.4382	.2858	1.5242	1.8138
11	1.6091	1.7869	.4572	.4763	.3048	1.5586	1.7604
12	.679	1.8903	.4954	.5144	.3048	1.2041	
13	1.2651	1.8964	.4572	.5144	.2096	1.2654	
14	.2591	1.8442	.5144	.5144		1.4969	
15		2.0153	.4763	.5335	.5376	1.5466	
16	1.2209	1.4937	.4763	.5335	.4001	1.5586	
17		.4763	.4763	.5144	.4763	.381	
18	.4763	.5335	.3048	.5335	.4954	.5144	
19	.381	.5335	.5335		.5525	.381	
20	.4001	.5525	.5144		.5335	.5335	
21	.4572	.5525	.4954		.5144	.5335	
22	.5144	.5335	1.2955		1.1544	.4954	
23	.4382	.4763	1.3904			.4382	
24	.4763	.381	.4191	1.2654		.9755	.4001
Max	1.6762	2.1872	1.3904	1.5653	1.1544	1.5586	1.8138
Min	.2591	.362	.2858	.4001	.2096	.3429	.362
Avg	.6289	.9342	.5025	.8537	.4808	.9634	.7376

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 201 / 11 KV Anjani AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0924	.0953	.7343	.3401	.217	.1143
2	.0953	.0934	.0953	.7343	.3441	.1981	.0953
3	.0953	.0924	.0953	.6859	.3481	.1981	.0953
4	.1143	.0934	.0953	.7164	.3401	.2195	.1143
5	.1524	.0914	.1143	.7968	.3605	.2469	.132
6	.1886	.1448	.1646	.8592	.5376	.3227	.1698
7	.2054	.2012	.1848	1.1683	.8322	.3462	.168
8	.168	.1629	.1478	.1478	.128	.0953	.128
9	1.0212	1.0159	.112	.1086		.4725	1.1248
10	1.1174	1.0978	.1097	.1075		.8745	1.0753
11	1.1523	1.065	.124	.128	.0924	1.1498	1.1203
12	1.0526	1.0562	.1417	.1254	.1109	1.0562	
13	.9602	1.0623	.12	.0886	.0934	1.0242	
14		.9998	.0943	.0716	.0943	1.0242	
15		1.2289	.0953	.0905	.0762	1.0562	
16	1.0688	1.2452	.1143	.0716	.0572	1.1174	
17	.0914	.0953	.1715	.0905	.0762	.1463	
18	.0905	.1143	.1143	.1109	.0953	.1294	
19	.1646	.128	.1494	.0905	.1143	.112	
20	.1267	.1646	.1494	.1254	.0953	.1509	
21	.1433	.1307	.132		.0762	.132	
22	.0895	.0934	1.0486	.3441	.2401	.1143	
23	.0905	.0943	.9282	.3361	.2401	.0953	
24	.1143	.0914	.0953	.7842	.3441	.2202	.1143
Max	1.1523	1.2452	1.0486	1.1683	.8322	1.1498	1.1248
Min	.0895	.0914	.0943	.0716	.0572	.0953	.0953
Avg	.3817	.4440	.1955	.3703	.2289	.4466	.3710

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 202 / 11 KV Bastavade Ag

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7068	.7773	.578	.1867	.1698	.1867	.6573
2	.727	.6882	.5285	.1867	.1698	.1867	.631
3	.7716	.6722	.5285	.1886	.1663	.1886	.6344
4	.8109	.6802	.5285	.2263	.1829	.1886	.6573
5	.8619	.7625	.5639	.2641	.181	.2075	.743
6	.9214	.8482	.7375	.2829	.2507	.2829	.8383
7	1.4815	1.5023	.9568	.3206	.3258	.3206	1.2809
8	.2587	.2561	.2614	.2402	.2195	.2241	.2241
9	.1867	.2218	1.0648	1.1288		.1867	.1867
10	.1848	.1886	.9755	1.0562		.1494	.168
11	.1829	.1886	.7977	.7373	.9414	.1463	.1663
12	.1663	.1663	.7676	.8097	.8768	.1829	.1663
13	.168	.1867	.7133	.9282	.8619	.1417	.1494
14	.168	.1478	.5213	.8583	.8069	.1448	
15	.1663	.168	.6602	1.0082	.8619	.1629	
16	.1494	.168	.7922	1.0883	1.0822	.1463	
17	.1848	.1848	.2033	.1463	.1848	.1646	
18	.2241	.2218	.1629	.1829	.181	.1848	
19	.2378	.2402	.2427	.1663	.2378	.2218	
20	.2534	.2829	.2614	.2195	.2614	.2641	
21	.2561	.2829	.2614		.2427	.2641	
22	1.1984	.945	.2263	.2033	.2263	1.0385	
23	1.0202	.7727	.2075	.168	.2075	.9659	
24	.7545		.643	.1867	.168	.1867	.6767
Max	1.4815	1.5023	1.0648	1.1288	1.0822	1.0385	1.2809
Min	.1494	.1478	.1629	.1463	.1663	.1417	.1494
Avg	.5017	.4588	.5493	.4689	.4003	.2641	.5128

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 203 / 11 KV Dongarsoni AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7375	1.6842	.7499	.2614	.2195	.2743	1.7375
2	1.6644	1.6712	.7499	.2614	.2218	.2743	1.7375
3	1.6644	1.6518	.7499	.2987	.2172	.2772	1.7497
4	1.9814	1.6712	.7907	.415	.2507	.2772	2.1052
5	2.3805	1.7924	.8745	.5281	.3366	.499	2.4249
6	2.5692	2.4291	1.1603	.6413	.4835	.679	2.5692
7	2.9675	2.8018	1.1768	.6224	.4607	.6224	2.9338
8	.4344	.394	.2715	.3077	.2686	.4338	.4435
9	.3142	.3366	1.1012	2.1538		.3326	.2896
10	.0373	.2957	1.2163	2.1285		.2402	.2686
11	.181	.2195	2.2045	1.945	1.8623	.2012	.2534
12	.2743	.2353	2.0891	1.9364	1.7284	.2328	.2507
13	.2715	.2353	1.9204	1.8623	1.8564	.1677	.2279
14	.1646	.2378	1.9364	1.8564	.8025	.2058	
15	.1848	.2218	2.3922	2.0729	1.2176	.2126	
16	.1829	.2926	2.3967	2.2405	1.4883	.2328	
17	.2896		.4805		.2507	.3439	
18	.3841	.0532	.333	.2865	.4805	.3439	
19	.5973	.0554	.4435	.3077	.6348	.5788	
20		.4066	.5041	.3403	.5788	.5975	
21	.4298	.3361	.4294		.4668	.4854	
22	2.5606	1.1469	.2987	.2012	.3174	2.8509	
23	2.1376	1.0082	.2987	.2012	.2772	2.17	
24	1.768		.8124	.2743	.2172	.2743	1.8122
Max	2.9675	2.8018	2.3967	2.2405	1.8623	2.8509	2.9338
Min	.0373	.0532	.2715	.2012	.2172	.1677	.2279
Avg	1.0946	.8717	1.0575	.9610	.6653	.5337	1.3431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 204 / 11 KV Jarandi AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2334	1.1797	.9065	.1905	.128	.1905	1.2018
2	1.2018	1.1934	.9065	.1905	.1311	.1905	1.2018
3	1.2452	1.1633	.9065	.2286	.1311	.1905	1.2498
4	1.5242	1.1498	1.0364	.2858	.1475	.2286	1.4529
5	1.656	1.2963	1.2029	.3429	.2241	.3048	1.6404
6	1.7869	1.7185	1.7166	.4382	.3277	.4572	1.9685
7	2.2138	2.1765	1.6004	.4382	.3201	.4572	1.9204
8	.3239	.2785	.3048	.3429	.2486	.2477	.3239
9	.2858	.2858	1.6004	1.2809		.2096	.3239
10	.2286	.2667	1.5684	1.1843		.1905	.2477
11	.1715	.1905	1.5364	.8539	1.3923	.1715	.1905
12	.1905	.1715	1.3123	1.0155	1.5203	.1905	.1905
13	.1905	.1715	1.1717	1.0517	1.4373	.1905	.2096
14	.1905	.1715	1.1574	1.0936	1.3923	.1905	
15	.1905	.1524	1.6129	1.3603	1.4723	.1715	
16	.2096	.1905	1.7869	1.2342	1.7532	.1715	
17	.2286	.2858	.2477	.1475	.2477	.2096	
18	.2622	.3429	.1715	.208	.2667	.2667	
19	.3201	.4001	.2096	.1966	.3429	.362	
20	.2968	.4191	.3429	.192	.362	.3429	
21	.2721	.3239	.2667		.2858	.2858	
22	1.7497	1.8623	.2477	.116	.2286	1.9524	
23	1.4403	1.3592	.1905	.128	.2096	1.5364	
24	1.2631	1.1843	1.0059	.1905	.1296	.1905	1.2793
Max	2.2138	2.1765	1.7869	1.3603	1.7532	1.9524	1.9685
Min	.1715	.1524	.1715	.116	.128	.1715	.1905
Avg	.7782	.7473	.9587	.5526	.5772	.3708	.9572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 205 / 11 KV Savalaj Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.546	.5602	.3734	.5757	.471	.5467	.5387
2	.5437	.5419	.3772	.57	.4681	.5399	.533
3	.5463	.5479	.3772	.6097	.469	.5413	.5326
4	.5855	.5552	.3961	.6693	.4685	.5643	.5922
5	.7154	.6382	.4481	.7472	.5132	.5996	.6712
6	.8781	.8756	.5847	.9234	.7072	.8739	.8141
7	.921	.9126	.5975	.951	.7735	.8589	.8741
8	.6746	.6634	.394	.6747	.6824	.6314	.5845
9	.5228	.5495	.3982	.6078	.197	.5384	.498
10	.5708	.5552	.362	.5567		.4687	.5049
11	.5552	.5809	.4024	.5518	.6699	.5098	.4786
12	.1551	.5853	.3801	.5866	.6521	.5203	.4523
13		.6184	.3841	.5841	.6561	.5243	.4569
14		.5979	.4024	.6218	.5937	.5057	.1886
15		.6177	.3881	.5857	.5805	.5268	.1894
16	.8113	.6188	.4024	.5464	.5651	.5277	.1669
17	.7019	.575	.3982	.6184	.6093	.5007	.1875
18	.6973	.7556	.3982	.6215	.6264	.5578	.2237
19	.9667	.8613	.5544	.6721	.8046	.8303	.2656
20	.987	1.0372	.6838	.7232	1.0372	1.0109	.3216
21	.9336	.9834	.6283	.2397	.9286	.916	.3155
22	.8402	.8676	.2987	.663	.7991	.7947	.2743
23	.7295	.7362	.4481	.5651	.6535	.6539	.234
24	.5978	.5897	.3921	.5742	.5085	.5757	.5506
Max	.987	1.0372	.6838	.951	1.0372	1.0109	.8741
Min	.1551	.5419	.2987	.2397	.197	.4687	.1669
Avg	.6895	.6844	.4362	.6266	.6276	.6299	.4354

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 207 / 11 KV Savlaj Water Supply NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1779	.0564	.0316	.1715	.0145	.0149	.0118
2	.1601	.0286	.0309	.1761	.0149	.0149	.0114
3	.1646	.029	.0316	.17	.0143	.0143	.0143
4	.1798	.0297	.0309	.1909	.0145	.0143	.0149
5	.1996	.029	.0305	.1604	.0143	.0154	.0149
6	.2088	.1196	.0492	.1775	.0145	.0156	.0156
7	.1784	.1356	.0332	.0759	.0147	.0158	.016
8	.2111	.1006	.064	.0518	.0297	.0151	.0301
9	.2402	.1135	.0772	.1677		.0316	.0312
10	.2477	.1395	.0655	.1669		.0655	.0305
11	.2431	.0484	.0663	.154	.032	.0312	.0297
12	.1539	.0328	.0324	.0625	.032	.0259	.1196
13	.1486	.0324	.032	.061	.0312	.029	.1273
14	.0579	.0312	.0316	.0297	.0305	.0267	.0808
15	.1196	.0316	.0324	.029	.0149	.0282	.08
16	.1387	.0324	.0316	.029	.1718	.0301	.08
17	.1615	.1471	.0312	.0297	.0152	.0282	.0914
18	.1532	.1448	.0625	.029	.0305	.0301	.0983
19	.16	.1433	.08	.0282	.1319	.0152	.1082
20	.1532	.0339	.0983	.029	.0457	.0152	.1082
21	.1417	.0309	.1107		.0309	.0139	.0884
22	.0564	.0312	.08	.0297	.0309	.0137	.0244
23	.0572	.0312	.081	.029	.0312	.0133	
24	.0743	.0579	.0316	.08	.0297	.0301	.0122
Max	.2477	.1471	.1107	.1909	.1718	.0655	.1273
Min	.0564	.0286	.0305	.0282	.0143	.0133	.0114
Avg	.1578	.0671	.0519	.0925	.0359	.0228	.0539

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 209 / 11 KV Savlaj Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.2896	.2801	1.1736	.7042	.9998	.2427
2	.2987	.2926	.2801	1.1584	.7209	.945	.2427
3	.3018	.2926	.2801	1.1873	.7125	.945	.2452
4	.3772	.3258	.3547	1.4883	.7042	1.0722	.2829
5	.4527	.394	.4108	1.7124	.7449	1.1203	.3772
6	.5658	.5068	.5304	1.8023	1.1797	1.4083	.5281
7	.5847	.5121	.4938	1.8404	1.6004	1.749	.5041
8	.439	.4435	.3403	.2926	.3658	.3475	.4251
9	2.1214	2.2405	.2561	.2402		1.4998	1.8818
10	2.0317	2.1445	.2561	.2378		1.4723	1.8976
11	1.7284	2.0557	.1949	.2195	.2033	1.0669	1.3603
12	1.6004	1.9925	.1791	.2195	.1991	1.2793	
13	1.6842	1.6004	.1928	.2218	.1829	1.3496	
14		1.6004	.1753	.2195	.1991	1.3756	
15		1.9204	.181	.2218	.2149	1.4784	
16	1.7284	2.0081	.197		.197	1.6446	
17	.2926	.2353	.2658	.1494	.2561	.2328	
18	.3696	.3077	.2328	.1478	.2743	.197	
19	.4755	.3696	.3326	.2241	.3475	.3921	
20	.4656	.4481	.4294	.2218	.4481	.4481	
21	.4252	.3921	.3361		.3547	.3734	
22	.3658	.3361	1.7284	.7377	1.3283	.3361	
23	.3258	.2987	1.4403	.7209	1.1248	.2614	
24	.3109		.2957	1.2191	.7125	1.0311	.2587
Max	2.1214	2.2405	1.7284	1.8404	1.6004	1.749	1.8976
Min	.2926	.2353	.1753	.1478	.1829	.197	.2427
Avg	.7838	.9134	.4027	.7116	.5807	.9594	.6872

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789] BU 4789

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 203 / 11 KV Manjarde Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-17	30-MAR-17
HR	Load (MW)	Load (MW)
1	.2084	.2181
2	.2067	.2061
3	.2079	.2035
4	.2256	.2298
5	.2486	.2639
6	.3121	.3361
7	.3406	.3485
8	.277	.293
9	.2172	.1926
10	.1844	.1892
11	.1987	.1663
12	.2153	.1865
13	.2328	.2402
14	.2151	.2498
15	.1997	.2359
16	.2296	.2101
17	.1696	.2075
18	.2458	.2431
19	.3677	.3184
20	.439	.4199
21	.4188	.3949
22	.3452	.3599
23	.3294	.3227
24	.2296	.2599
Max	.439	.4199
Min	.1696	.1663
Avg	.2610	.2623

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789] BU 4789

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 205 / 11 KV Manjarde Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1425	.1631	.5205	.8314	.1501
2	.1471	.16	.5197	.804	.1555
3	.1509	.1692	.5136	.7819	.1547
4	.1494	.1722	.5205	.8017	.1578
5	.1456	.1928	.5472	.8421	.1715
6	.1875	.2347	.5959	.8901	.2073
7	.2652	.2904	.8101	1.1325	.2614
8	.269	.2591	.2591	.4275	.2606
9	1.9852	2.0187	.1486	1.1904	1.6347
10	2.079	2.1552	.1189	1.1355	1.7474
11	2.1353	2.258	.1036	1.089	1.752
12	2.0622	2.1765	.0975	1.0037	1.7886
13	1.8198	1.9486	.1014	1.0128	.2103
14	1.2948	1.9265	.1204	.9457	.1745
15	1.6133	1.9243	.1029	1.3954	.1738
16	.4466	2.0149	.1044	1.5165	1.4784
17	.4321	.6089	.1135	.1196	.2705
18	.1318	.1608	.1509	.1174	.1471
19	.173	.1677	.1677	.1494	.1837
20	.2149	.2058	.2157	.1989	.2027
21	.2172	.2202	.2103	.1997	.1981
22	.1936	.1966	.9938	.1738	.1814
23	.1821	.1837	.9206	.1623	.1745
24	.1707	.1608	.8657	.157	.1608
Max	2.1353	2.258	.9938	1.5165	1.7886
Min	.1318	.16	.0975	.1174	.1471
Avg	.6920	.8320	.3676	.7116	.4999

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 201 / 11 KV Manerajuri Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5912	1.2483	1.4083	.394		.3547	1.4918
2	1.4737	1.2616	1.3748	.443		.3206	1.2803
3	1.5402	1.2574	1.4413	.4733		.3361	1.3108
4	1.5384	1.2717	1.4232	.5068		.3395	1.326
5	1.5655	1.3413	1.4918	.5373		.3734	1.6766
6	1.9662	1.7939	1.6194	.567		.7167	1.8778
7	2.3045	1.9989	1.8027	.6447		.6036	2.2552
8	.5415	.4715	.4607	.5249		.5249	.4607
9	.415	.394	1.7924	1.4685		.3921	.4527
10	.4481	.3696	1.6404	2.1538		.415	
11	.4066	.3658	1.5971	1.9281	1.7695	.3696	
12	.3511	.3326	1.7236	1.8945	1.7814	.3326	
13	.4338	.2926	1.7284	1.7695	1.8623	.3772	
14	.3696	.2835	1.6872	1.8442	1.9227	.3045	
15	.3511	.3224	1.6804	1.8821	1.9006	.3189	
16	.3881	.3544	1.7654	2.0622	1.9109	.3721	
17	.4066	.3224		.394	1.6057	.4119	.3544
18	.4527	.443	.3544		.5281	.4706	.3982
19	.5228	.5973	.4382		.6722	.6201	.4298
20	.5658	.5731	.5373		.6036	.7164	.4887
21	.4961	.5175	.5611		.5281	.6878	.5194
22	1.8778	1.5912	.5014		.4854	1.9281	1.166
23	1.7284	1.5061	.4525		.415	1.7804	1.2963
24	1.6004	1.3108	1.5249	.3761		.3772	1.6385
Max	2.3045	1.9989	1.8027	2.1538	1.9227	1.9281	2.2552
Min	.3511	.2835	.3544	.3761	.415	.3045	.3544
Avg	.9723	.8425	1.2612	1.1036	1.2297	.5602	1.0837

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 202 / 11 KV Yogewadi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2427	.181	.2149	1.3441	.5087	.9503	.2195
2	.2263	.1829	.2126	1.4373	.4915	.8907	.2218
3	.2241	.1848	.2103	1.5586	.4801	.8951	.2241
4	.2263	.2241	.2126	1.8404	.5668	.8962	.2772
5	.2614	.2587	.2865	1.866	.7209	.9667	.3142
6	.3961	.2926	.3189	1.7604	.8886	1.085	.3544
7	.3658	.3696	.3696	1.7078	1.3395	1.1683	.3403
8	.2772	.3326	.3292	.3224	.2641	.2075	.3012
9	1.1203	1.5729	.3155	.3224		1.1683	1.5844
10	1.8484	1.6766	.3366	.3224		1.4089	
11	1.848	1.6194	.3224	.2829	.1886	1.3927	
12	1.5912	1.6712	.3045	.2658	.1867	1.3599	
13	.3772	1.4918	.2896	.3045	.1698	1.5089	
14	.8478	1.4723	.2658	.2686	.1698	1.4922	
15	.3921	1.6956	.2629	.2896	.168	1.4922	
16	1.1128	1.6129	.2658	.2614	.1698	1.576	
17	.3189	.2804		.2835	.2075	.2829	.2149
18	.3224	.2658	.3012		.2614	.3012	.2534
19	.3045	.333	.3224		.3174	.3366	.2686
20	.3395	.3189	.3366		.3206	.3206	.3109
21	.2957	.2804	.333		.2987	.2835	.3439
22	.2743	.2865	1.0155	.6371	1.1469	.2829	.3224
23	.2378	.2534	1.1702	.5407	1.0688	.2328	.2835
24	.2452	.2149	.2378	1.2643	.503	.9922	.2172
Max	1.8484	1.6956	1.1702	1.866	1.3395	1.576	1.5844
Min	.2241	.181	.2103	.2614	.168	.2075	.2149
Avg	.5707	.7113	.3580	.8440	.4744	.8955	.3560

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 203 / 11 KV Bhosalenagar Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2218	.1772	1.3757	.5735	.9945	.2218
2	.2241	.2195	.1753	1.4883	.547	.9282	.1829
3	.2263	.2218	.1753	1.5708	.5533	.8907	.1848
4	.2241	.1848	.2149	1.6964	.6443	.9339	.1867
5	.2614	.2033	.2686	1.7394	.6796	.9878	.2075
6	.3206	.2427	.2896	1.6716	.8139	1.1437	.1949
7	.3174	.2743	.3326	1.6804	1.291	1.1683	.3045
8	.3206	.2865	.3292	.2896	.1417	.2452	.2686
9	1.917	1.6876		.2686		1.5023	1.4563
10	1.6484	2.0957		.2279		1.4998	
11	1.6876	1.7284		.2686	.1867	1.6057	
12	1.6766	1.2955			.1886	1.6385	
13	.1886	1.3443			.2241	1.5592	
14	.8139	1.4746		.2452	.2241		
15	.2058	1.6907		.2126	.2587	1.4523	
16	1.3748	1.5181		.2149	.2801	1.5061	
17	.3012	.2126		.2865	.2829	.2328	.1928
18	.3224	.2103			.3174	.2896	.2328
19	.3772	.3224			.3961		.2658
20	.415	.3012			.3547	.2686	.2865
21	.3658	.2896			.3018	.2896	.3366
22	.3109	.2481		.6203	1.1797	.2507	.3045
23	.2772	.2149		.6104	1.1469	.2328	.2715
24	.2452	.2427	.2172	1.2498	.5935	1.0402	.2172
Max	1.917	2.0957	.3326	1.7394	1.291	1.6385	1.4563
Min	.1886	.1848	.1753	.2126	.1417	.2328	.1829
Avg	.5937	.6971	.2422	.8732	.5082	.9391	.3127

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 204 / 11 KV Manerajuri Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.3189	.2957	.3772	.128	.3206	.362
2	.2801	.2865	.3018	.3361	.1294	.3018	.3292
3	.2987	.2534	.2801	.3292	.1307	.2987	.2957
4	.3018	.2561	.2957	.3696	.1132	.3018	.2987
5	.3361	.3326	.3395	.3982	.124	.3174	.3395
6	.3841	.3898	.3734	.4251	.1254	.3658	.4119
7	.4163	.3403	.3174	.4481	.1075	.3511	.3761
8	.4024	.3761	.3018	.3881		.3961	.3761
9	.3696	.3696	.5281	.3109		1.5023	.4119
10	.567	.6089	.5093	.3077		.362	
11	.499	.4527	.4854	.4252	.3511	.4207	
12	.4805	.4108	.5281	.4252	.439	.4251	
13	.3511	.3395	.5544	.4252	.462	.3721	
14	.3142	.5228	.5973	.394	.5041	.394	
15	.3761	.6602	.6401	.362	.5249	.591	
16	.3224	.3361	.6348	.3366	.6283	.4835	
17	.3403	.5658		.394	.462	.543	.6413
18	.4477	.4668	.6535		.6036	.567	.5975
19	.6224	.6036	.6653		.8402	.6268	.6099
20	.6224	.5658	.6697		.7468	.6697	.567
21	.5493	.4854	.6838		.6036	.695	.6099
22	.5316	.4527	.6535	.1254	.4668	.6613	.5658
23	.4458	.3696	.5658	.1254	.4108	.4607	.3734
24	.3772	.3467	.3361	.3841	.1267	.3584	.4477
Max	.6224	.6602	.6838	.4481	.8402	1.5023	.6413
Min	.2801	.2534	.2801	.1254	.1075	.2987	.2957
Avg	.4141	.4213	.4874	.3544	.3823	.4911	.4479

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 205 / 11 KV AG LIS Feeder

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.0537		.0362		.0362
2	.0543	.0543	.0543	.0366	.0179	.0358
3	.0532	.0549	.0537	.0358	.0181	.0732
4	.0543	.0554	.0532	.0543	.0183	.0732
5	.0532	.056	.0532	.0549	.0185	.0724
6	.0747	.0754	.0716	.0532	.0189	.0732
7	.0732	.0709	.0701	.0554		.0747
8	.0709	.0716	.0724	.0732		.0754
9	.0732	.0537		.0724		.056
10	.0739	.0709		.0732		.0566
11	.0709	.0716		.0739	.0366	.0537
12	.0709	.0724		.0747	.0362	.0543
13	.0739	.0354		.0739	.0366	.0543
14	.0739	.0701		.0709	.037	.0724
15	.0739	.0709		.0716	.0373	.0739
16	.0709	.0351		.0709		.0739
24				.0905		
Max	.0747	.0754	.0724	.0905	.0373	.0754
Min	.0532	.0351	.0532	.0358	.0179	.0358
Avg	.0669	.0608	.0612	.0630	.0275	.0631

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 206 / Yogewadi Gaothan Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168	.112	.1478	.1646	.1254	.168	.1307
2	.1698	.1109	.1494	.1509	.1267	.132	.132
3	.1494	.1097	.1463	.1478	.128	.132	.1063
4	.1509	.112	.181	.1867	.1294	.1307	.1254
5	.1494	.1294	.1886	.2218	.1478	.1509	.1463
6	.1509	.1612	.1848	.2263	.2149	.2075	.197
7	.1646	.1791	.2195	.2378	.197	.168	.1612
8	.1478	.1063	.415	.2452	.3224	.2263	.1612
9	.1132	.1075	.4024	.2012		.2896	.3012
10	.0934	.3012	.3658			.3547	
11	.1791	.3582	.3361	.2835	.1646	.4119	
12	.1791	.4163	.2743	.2865	.181	.3582	
13		.1086	.2587	.1433	.2957	.1063	
14	.1595	.3734	.2241	.2149	.362	.1791	
15	.197	.5281	.2075	.2715	.4024	.4784	
16	.1417	.2218	.3361	.1791	.4066	.3721	
17	.1433	.3734		.2686	.4435	.3189	.3734
18	.1433	.1294	.2801		.3696	.2865	.3326
19	.1612	.5281	.2587		.2896	.2865	.2743
20	.1629	.3734	.2241		.2614	.2686	.1848
21	.1646	.2957	.2075		.2075	.2534	.168
22	.1663	.2241	.1829	.1791	.2054	.1949	.1698
23	.1494	.1867	.1663	.1612	.2263	.1612	.1478
24	.1698	.1294	.168	.1698	.1417	.1886	.1478
Max	.197	.5281	.415	.2865	.4435	.4784	.3734
Min	.0934	.1063	.1463	.1433	.1254	.1063	.1063
Avg	.1554	.2365	.2402	.2074	.2431	.2427	.1918

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244089 / 33/11 KV WAIFALE

Feeder No / Name : 201 / 11 KV Waifale Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572		.3361	.4715	.1715		.4191
2	.4572		.3361	.3772	.1715		.4191
3	.4572		.3734	.3772	.5093		.4191
4	.4572		.3734	.4715	.4715		.4191
5	.5716		.4108	.5658	.2286		.4191
6	.6413		.4668	.6224	.3429		.5335
7	.5335		.5415	.4715	.3361		.4668
8	.4191		.4338	.4294	.2614		.4191
9	.381		.3961	.3584	.4715	.6602	.2829
10	.381	.3206	.4527	.362		.5228	.2858
11	.4191	.415	.5281	.381		.5228	
12	.4763	.5093	.4527	.5144		.3921	
13	.3429	.4338	.4904	.4954	.5335	.4294	.2858
14	.4191	.4527	.4904		.4904	.4525	
15	.4763	.415	.5281	.4954		.5175	
16	.4763	.4904	.4338	.5144		.4805	
17	.4382	.5658	.4904	.4763	.5658	.4954	
18	.5415	.2829			.547	.5716	
19	.5788	.5975	.6602		.5847	.6859	
20	.6838	.6535	.7167	.3048	.5658	.6859	
21	.6722	.6722		.2858	.5847	.5716	
22	.6224	.3921		.2477		.5144	
23	.4954	.3734		.1905		.4763	
24	.4572	.4572	.3734	.3772	.1715		.4191
Max	.6838	.6722	.7167	.6224	.5847	.6859	.5335
Min	.3429	.2829	.3361	.1905	.1715	.3921	.2829
Avg	.4940	.4688	.4642	.4186	.4122	.5319	.3990

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244089 / 33/11 KV WAIFALE

Feeder No / Name : 202 / 11 KV Waifale Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0348	1.7002	1.8861	.381	.0953		1.9719
2	2.0348	1.7002	1.7147	.381	.0953		1.9719
3	2.0348		1.7147	.3772	1.7147		1.9719
4	2.0348		1.7147	.4715	2.2977		1.9719
5	2.1195		1.8004	.5335	.1905		1.9719
6	2.3472		1.8519	.6224	.3048		2.5819
7	2.4531		2.1091	.5847	.3772		2.652
8			.362	.3772	.2614		.4191
9	.3048		1.7939	2.0062	1.3375	.2667	.3048
10	.2667	.2829	1.8004	1.9071		.2667	.2667
11	.2286	.1886	1.6461	1.8229		.2477	
12	.2286	.1905	1.5261	.9945		.2286	
13	.2096	.2286	1.4746	1.5424	1.406	.2286	.2096
14	.2096	.2286	1.7147	1.7528	1.6804	.2286	
15	.2477	.2477	1.8519	1.8519		.2286	
16	.2286	.2286	1.9719	1.9204		.2096	
17	.3239	.2641	.2829	.2801	.3018	.3048	
18	.381	.3018		.3326	.3772	.381	
19	.4108	.4715	.415		.4527	.4763	
20	.5175	.4904	.4904		.415	.4763	
21	.4668	.4715		.1334	.415	.4763	
22	2.2969	2.3491		.0953		2.4863	
23	1.8176	2.3148				2.2291	
24	2.0348	1.7002	2.0576	.381	.0953		1.9719
Max	2.4531	2.3491	2.1091	2.0062	2.2977	2.4863	2.652
Min	.2096	.1886	.2829	.0953	.0953	.2096	.2096
Avg	1.0971	.7858	1.5090	.8928	.6952	.5823	1.5221

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244089 / 33/11 KV WAIFALE

Feeder No / Name : 203 / 11 KV Biranwadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905		.2858	1.0288			.2286
2	.1905		.2858	1.0288	.7316		.2286
3	.1905		.2858	1.0288	.1524		
4	.1905		.1905	1.0288	.1334		.2286
5	.2858		.3429	1.0288	.8596		.2286
6	.4001		.3961	1.0288	1.1999		.381
7	.4191		.4338	1.4918	1.8404		.5144
8	.2858		.2829	.1905	.2829		.381
9	2.6101		.2096	.1334	.1905	.6001	1.6461
10	2.0957	2.1948	.2096	.1143		1.5432	
11	1.9161	1.7147	.1905	.1143		1.5775	
12	1.8143	1.8004	.1715	.1715		1.5432	
13		1.5604	.1715	.1143	.1334	1.5432	
14	.8413	1.8004	.1715		.1334	1.6289	
15		1.9547	.1715	.1905		1.7974	
16	1.9204	2.1605	.2096	.1905		1.8652	
17	.2075	.2096	.2286	.1524	.1905	.2286	
18	.2241	.2096			.2286	.2858	
19	.3174	.3429	.2858		.2858	.3429	
20	.3326	.2858	.3048	.2477	.3239	.3429	
21	.2801	.3239		.2477	.3048	.2477	
22	.2263	.2477		.8063		.2477	
23	.2286	.3772		.7522		.2286	
24	.1905	.1905	.2829	1.0288	.7316		.2286
Max	2.6101	2.1948	.4338	1.4918	1.8404	1.8652	1.6461
Min	.1905	.1905	.1715	.1143	.1334	.2286	.2286
Avg	.6981	1.0249	.2556	.5771	.4827	.9349	.4517

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244089 / 33/11 KV WAIFALE

Feeder No / Name : 204 / 11 KV Agrani agro express NON SHEDDABLE EXPRESS HV FEEDERS
 fdr Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0133	.0229	.0152	.04		.0476
2	.0381	.0095	.0419	.04	.0381		.0476
3	.0381	.0229		.04	.04		.0476
4	.0381	.0171	.0038	.0648	.0381		.0476
5	.0381	.0152	.0476	.04	.0171		.0495
6	.0381	.0133	.0476	.0095	.0438		.0495
7	.0038	.0095	.0438	.0533	.0057		.0038
8	.04	.0648	.0419		.021		.0191
9	.0095	.0553	.0438	.0152	.0705	.0533	.0095
10	.0191	.04		.0133		.0381	.0095
11	.0057	.0095	.0457	.0381		.0248	
12	.0057	.0419	.04	.0362		.0419	
13	.0057	.0133	.04	.04		.0419	.04
14	.0057	.0133	.0419	.0419	.0381	.0381	
15	.0057	.0019	.0381	.0381		.0229	
16	.0057	.0419	.04	.0152		.0553	
17	.0114	.0419	.0152	.0362	.0152	.04	
18	.0038	.0152		.0229	.0362	.0495	
19	.0057	.0152	.0114	.0133	.0343	.0495	
20	.0038	.0133	.0152	.0152	.0324	.0495	
21	.0038	.0114		.0171	.0381	.0152	
22	.0038	.0152		.0229		.0152	
23	.0191	.0133		.0705		.0495	
24	.0381	.0171	.0114	.0152	.0724		.0476
Max	.04	.0648	.0476	.0705	.0724	.0553	.0495
Min	.0038	.0019	.0038	.0095	.0057	.0152	.0038
Avg	.0177	.0219	.0329	.0310	.0363	.0390	.0349

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244108 / 33/11 KV Koulage

Feeder No / Name : 201 / 11 KV Savarde Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7859	.6171	.5792	.1848	.1494	.2427	
2	.7819	.6097	.5575	.1848	.1663	.2241	.6626
3	.7922	.6173	.5498	.1663	.1494	.2241	.6344
4	.8173	.6173	.5647	.1848	.1886	.2075	.6259
5	.8916	.6562	.6097	.2241	.1886	.2614	
6	1.0385	.9374	.7316	.3206	.2452	.3174	
7	1.2191	1.2029	.9907	.3584	.2829	.3395	
8	.2402	.2614	.2614	.2772	.2054	.3174	
9	.2614	.2587	.9374	1.1888		.2054	
10	.2801	.2587	.8916	1.0837		.168	
11	.2743	.2587	.8429	1.0084	.8482	.1829	
12	.2715	.2218	.7716	.8859	.9442	.2172	
13	.2561	.2033	.7232	.8288	.8482	.2172	
14	.2402	.2033	.7674	.7876	.8259	.2172	
15	.2587	.1848	.7775	.9259	.8097	.2378	
16	.2587	.2033	.9859	1.0883	1.1174	.2402	
17	.2772	.2534		.2218	.2561	.2587	
18	.2957	.2926	.3292		.2774	.2987	
19	.3142	.2987	.2957		.2801	.3734	
20	.3174	.3206	.3174		.2987	.3361	
21	.3174	.3174	.2772		.2829	.3174	
22	1.1458	.9842	.2427	.1867	.2452	.8173	
23	.6287	.7282	.2427	.1494	.2241	.7628	
24	.7859	.6321	.6687	.2033	.1494	.2241	.7002
Max	1.2191	1.2029	.9907	1.1888	1.1174	.8173	.7002
Min	.2402	.1848	.2427	.1494	.1494	.168	.6259
Avg	.5313	.4641	.6050	.5230	.4083	.3004	.6558

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789] BU 4789

Substation No/ Name :- 244108 / 33/11 KV Koulage

Feeder No / Name : 202 / 11 KV Khujgaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1995	1.9618	.8688	.3334	.2069	.3578	2.2637
2	2.1216	1.8709	.8398	.3153	.2069	.3578	2.1195
3	2.1338	1.8823	.8253	.3153	.2256	.3976	2.0955
4	2.1582	1.8938	.8802	.3334	.2082	.3787	2.0955
5	2.2738	2.0728	.9362	.4319	.3222	.3787	2.0972
6	2.8346	2.5591	1.0997	.5877	.341	.5304	1.2955
7	4.0613	4.0011	1.2763	.6066	.4927	.5877	1.829
8	.4664	.4458	.2012	.8292	.5102	.5289	.3048
9	2.0799	.4115	1.3523	3.8062		.3204	.2286
10	.434	.3002	1.3466	3.598		.3187	.2286
11	.434	.3391	1.3032	3.3501	2.9316	.3812	
12	.322	.3315	1.3003	3.1827	3.1169	.305	
13	.1837	.3334	.9023	3.0312	2.2557		.1524
14	.2599	.3187	1.2742	2.8496	2.6368	.1648	.1524
15	.261	.3204	1.3203	3.4555	2.4234	.2957	.1524
16	.2804	.3353	1.4118	3.653	2.8655	.442	.1524
17	.3749	.482		.3494	.2972	.5182	.2286
18	.3932	.3795	.2454	.2286	.4504	.5212	.381
19	.5791	.4873	.2957		.49	.5974	.381
20	.5791	.619	.2587		.5849	.5791	.381
21	.5944	.6397	.2561		.4738	.6424	.4572
22	2.8045	3.0346	.2614	.2831	.4527	2.7877	1.829
23	2.5256	2.5658	.2218	.2069	.434	2.7797	1.6766
24	2.2207	2.117	.9412	.2774	.2831	1.6347	2.3399
Max	4.0613	4.0011	1.4118	3.8062	3.1169	2.7877	2.3399
Min	.1837	.3002	.2012	.2069	.2069	.1648	.1524
Avg	1.3573	1.2376	.8530	1.5250	1.0095	.6872	1.0383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 201 / 11 KV KUMTHE NAGAON

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 /
OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5658	.6348	.6413		.8002	.6224
2		.547	.5975	.6036		.7621	.5847
3		.5281	.5975	.5975		.7621	.5847
4		.547	.5975	.6099		.6097	.5975
5		.6036	.6161	.6838		.6097	.6099
6		.7356	.6161	.7499		.6478	.6584
7		.6036	.6161	.6908		.6478	.567
8		.5041	.5014	.567		.5014	.4525
9	.5487	.4344	.5014	.5194	.5487	.4854	
10	.427	.4382			.4908	.4908	
11	.5083	.4115	.5014		.5373	.463	
12	.5201	.5731	.567		.5014	.4908	
13	.5548	.5847	.5847		.5083	.5028	.4557
14	.5609	.5258	.5548		.5249	.5258	.4961
15	.5548	.5548	.567		.5014	.5201	.5014
16	.5792	.567	.5258		.543	.5083	.4755
17	.5258	.5201	.5258		.5316	.4656	
18	.6201	.5087	.5784		.5487	.591	
19	.8869	.7602	.8145		.6878	.8145	
20	.9511	.7602	.924		.8316	1.0059	
21	.8871	.7602	.8686		.9522	.9145	
22	.8299	.7468	.8573		.9145	.8402	
23	.7095	.7468	.724		.9145	.7207	
24		.6224	.6722	.6413		.8002	.6535
Max	.9511	.7602	.924	.7499	.9522	1.0059	.6584
Min	.427	.4115	.5014	.5194	.4908	.463	.4525
Avg	.6443	.5896	.6323	.6305	.6358	.6450	.5584

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 202 / 11 KV KAVALAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1509	.1698	.1478		.1578	.1612
2		.132	.1509	.1478		.1417	
3		.132	.1509	.1307		.1478	.1448
4		.1307	.1494	.132		.1417	.1463
5		.1663	.1494	.1509		.1448	.1478
6		.1829	.168	.168		.1646	.1663
7		.1629	.168	.1629		.1629	.1509
8		.1402	.124	.124		.1509	.1448
9	.1307	.104	.1478	.116	.1294	.1147	
10	.112	.1227	.1227		.1214	.1341	
11	.1267	.124	.1372		.1715	.1526	
12	.1086	.1075	.1448		.1543	.1677	
13	.0943	.0905	.0914		.1132	.1402	.0886
14	.112	.1075	.0924		.0943	.0914	.0924
15	.1109	.0876	.1075		.0943	.0895	.0934
16	.0934	.0943	.1132		.112	.0876	.1109
17	.1029	.1147	.104		.0943	.1509	
18	.1052	.1147	.1086		.0943	.1578	
19	.1595	.1267	.1097		.132	.1595	
20	.2149	.1663	.2328		.1698	.2075	
21	.1006	.1829	.1991		.1886		
22	.1509	.1867	.1886		.1791	.2033	
23	.1478	.1698	.1646		.181	.1629	
24		.1509	.1698	.1478		.1595	.1595
Max	.2149	.1867	.2328	.168	.1886	.2075	.1663
Min	.0934	.0876	.0914	.116	.0943	.0876	.0886
Avg	.1247	.1354	.1444	.1428	.1353	.1475	.1339

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 203 / 11 KV Nagaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8749	.4999	.1143		.1143	.6773
2		.8421	.4687	.1143		.0953	.6554
3		.8029	.4744	.1143		.0953	.6173
4		.6802	.5376	.1143		.0953	.6097
5		.7748	.6249	.1143		.0953	.6321
6		.9374	.7202	.1334		.1143	.6308
7		.9602	.8025	.1334		.1143	.7926
8		.0762	.1143	.1334		.0953	.1143
9	.1143	.0953	1.0526	1.1523	.7316	.0953	
10	.1715	.1143	1.0753		.8951	.1143	
11	.1524	.1334	1.0031		.9172	.1143	
12	.1715	.1143	.9907		.9568	.1143	
13	.1905	.1143	1.0385		.7876	.1143	.1334
14	.1524	.1143	1.0031		.8535	.1143	.1524
15	.1334	.1143	.9145		.8579	.1334	.1715
16	.0953	.1143	.8078		.8177	.1524	.1524
17	.1143	.0762	.1143		.1334	.0953	
18	.1334	.1143	.1143		.1334	.1143	
19	.1334	.1334	.1334		.1334	.1334	
20	.1334	.1334	.1524		.1143	.1334	
21	.1334	.1143	.1524		.1143	.1143	
22	.9877	.3795	.1143		.1143	.7274	
23	1.0235	.4374	.1334		.1143	.7842	
24		.9145	.4938	.1143		.1143	.7253
Max	1.0235	.9602	1.0753	1.1523	.9568	.7842	.7926
Min	.0953	.0762	.1143	.1143	.1143	.0953	.1143
Avg	.2560	.3819	.5640	.2238	.5117	.1662	.4665

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 204 / 11 KV Kumthe Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0722	.6249	1.4098	.9526	1.4289	6.311
2		1.0242	.6009	1.4098	.9526	1.4098	5.7952
3		1.0814	.5937	1.4098	.9526	1.4098	5.6598
4		1.1305	.6642	1.486	1.0669	1.486	5.5327
5		1.1544	.8905	1.7719	1.1812	1.5813	5.8352
6		1.2346	1.0082	1.9814	1.3336	1.7719	8.4477
7		1.6156	1.3123	1.7909	1.2574	1.7719	***
8		.2286	.2667	6.6111	3.5437	1.4479	1.2384
9	.1905	.2286	1.6876	***	7.0317	1.0669	.6859
10	.1715	.2286	1.5623	***	6.1881	.7431	.6478
11	.1715	.2286	1.5466	9.6403	6.4632	.8383	.8383
12	.1905	.2286	1.4815	9.4879	6.7949	.9907	.7621
13	.1905	.2286	1.4969	8.0399	6.1668	1.105	.9907
14	.1905	.2286	1.5181	8.6115	7.465	1.1431	1.0288
15	.1905	.2286	1.4685	9.2212	7.0934	1.105	1.2003
16	.2096	.2096	1.448	8.9544	9.1297	1.0288	1.0098
17	.2667	.2667	.2096	.6478	1.1431	1.1431	1.0288
18	.2096	.3048	.2096	.9145	1.2955	1.2955	1.1812
19	.3048	.381	.2858	1.2955	1.4479	1.8481	1.5242
20	.3048	.3239	.3429		1.7338	2.3815	1.9814
21	.3239	.3239	.3239	1.1431	1.7909	5.3536	4.1152
22	1.2809	.6081	.3239	1.0669	1.7146	8.6504	6.4396
23	1.1883	.6401	.2477	1.0288	1.5051	8.079	6.2491
24		1.0936	.6325	1.1812	1.1431	6.0776	6.3245
Max	1.2809	1.6156	1.6876	12.0476	9.1297	8.6504	10.1299
Min	.1715	.2096	.2096	.6478	.9526	.7431	.6478
Avg	.3589	.5956	.8645	4.4038	3.3061	2.2982	3.5399

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 205 / 11 KV Kavalapur Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1698	.2075	.8488		.6325	.1886
2		.1509	.1886	.8025		.5937	.1698
3		.1524	.1886	.8124		.5864	.1698
4		.1334	.1886	.8697		.6642	.1509
5		.1509	.1886	.933		.8905	.1698
6		.1905	.2075	.9998		.9602	.1886
7		.2241	.2075	1.3565		.9602	.2241
8		.1848	.2054	.1867		.168	.1886
9	1.07	1.2498	.1478	.168	.168	1.0957	
10	1.4403	1.3123	.1402		.1254	1.0494	
11	1.3283	1.4232	.1417		.1294	.9877	
12	1.1561	1.3426	.1267		.1448	.9536	
13	.1612	1.2041	.1433		.1433	.9808	.1254
14	.1307	1.2498	.3658		.1463	.9829	.1463
15	.1109	1.2651	.1294		.1267	1.0669	.1478
16	.8436	1.25	.1448		.1294	1.1294	.8745
17	.1254	.1075	.1448		.1417	.128	
18	1.2254	.1629	.1448		.1448	.1294	
19	.2241	.2241	.2241		.1848	.2614	
20	.2075	.2263	.2452		.2263	.2641	
21	.2075	.2263	.2075		.2263	.2641	
22	.1698	.2263	1.0437		.7202	.2263	.1886
23	.168	.2263	.9145		.68	.1886	.1886
24	.2075	.3961	.2075	.8535		.6478	.1886
Max	1.4403	1.4232	1.0437	1.3565	.7202	1.1294	.8745
Min	.1109	.1075	.1267	.168	.1254	.128	.1254
Avg	.5485	.5604	.2523	.7831	.2292	.6588	.2207

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077] BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 201 / 11 KV PED AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3365	2.4425					2.1102
2	2.2573	2.3007	1.7695				1.9685
3	2.1445	2.2184					1.874
4	2.1232	2.1917	1.704				1.7749
5	2.2436	2.2481	1.704				1.8503
6	5.3726	2.7724	1.9006				2.4394
7	3.4545	2.2253	2.0317				3.0224
8		.0015	.1646	.2385	.2073		
9			2.2024	2.9005	2.1674		
10			2.2939	2.9843	2.1201		
11				2.8723	1.9235		
12			1.9845	2.9355	1.9624		
13			1.9845	2.5248	2.0294		
14			1.9845	2.5057	1.9456		
15			1.9845	2.6848	2.2138		
16			1.9845	2.854	2.3525		
19			.1829				
20			.1829				
21	.5723	.3734	.168			.2522	.2233
22	3.0498	2.8174	.1267			2.7618	2.8212
23	3.0857	2.6467	.128			2.6909	2.2847
24	4.715	2.3495	1.989	.1543		2.4691	2.1925
Max	5.3726	2.8174	2.2939	2.9843	2.3525	2.7618	3.0224
Min	.5723	.0015	.1267	.1543	.2073	.2522	.2233
Avg	2.8505	2.0490	1.3932	2.2655	1.8802	2.0435	2.0510

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077] BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 202 / 11 KV HATNUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1212	.1174		1.3702	.7019	.7019	
2	.1265	.1181	.0819	1.2727	1.2727	.6958	
3	.1204	.1181		1.2056	1.2056	.6912	
4	.1174	.1311	.1097	1.1805	1.1805	.6981	
5	.1296	.1387	.1463	1.2399	1.2399	.7164	
6	.3239	.176	.1646	1.6065	1.6065	.9938	
7	.2012	.2065	.1753	1.9364	1.9364	1.2155	
8	1.0456	1.2559	.1463	.1486	.1486	.1417	
9	1.8237	2.0508	.1097	.1517	.1517	.1364	
10	1.9829	2.0622	.1097	.1257	.1257	.1158	
11	3.642	2.0713		.1212	.1212	.1029	
12	1.5752	1.7398		.1219	.1219	.1151	.1486
13	2.6429	1.6949	.1097	.125	.125	.109	.1692
14	2.1574	1.6682	.1097	.1288	.1288	.1067	.1456
15	1.6167	1.861	.1097	.1326	.1326	.1097	.1562
16	1.4731	1.9524	.1097	.1463	.1463	.1059	1.8404
17	.0975	.1212		.1417	.1417	.1326	.5312
18	.1387	.1219		.1539	.1539	.1509	.1844
19	.1608	.1715	.1646	.1478	.1478	.1677	.1783
20	.173	.1692	.1829			.1738	.1951
21	.1722	.1692		.1075	.1075	.823	.1753
22	.1677	.1646		.7781	.7781	1.2742	.1684
23	.1433	.1334	1.3108	.7522	.7522	1.2254	.1517
24	.2286	.1097	1.3763	.711	.711	1.1225	.1113
Max	3.642	2.0713	1.3763	1.9364	1.9364	1.2742	1.8404
Min	.0975	.1097	.0819	.1075	.1075	.1029	.1113
Avg	.8492	.7718	.2823	.6003	.5712	.4928	.3197

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 204 / 11KV HATNUR GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	31-MAR-17
HR	Load (MW)	Load (MW)
2		.2263
4		.2075
5		.2829
6	.3206	
7		.3174
8		.2353
9		.181
10		.1629
11	.1829	
12		.2012
13		.2033
14	.2033	.2012
15	.1663	.1829
16	.1829	.1829
19		.2957
20		.4251
22		.3696
23		.2801
24	.2263	.2641
Max	.3206	.4251
Min	.1663	.1629
Avg	.2137	.2482

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 206 / 11 KV PED GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0876	.0903		.0964	.0922	.0972	.0926
2	.0884	.0892		.096	.0907	.0941	.0918
3	.0876	.0869		.0979	.0911	.0895	.0914
4	.088	.0911		.0975	.0876	.0934	.0907
5	.1075	.1094	.0943	.117	.1151	.104	.1036
6	.269	.1555	.132	.1646	.1547	.1654	.1475
7	.1677	.184	.1867	.1749	.1722	.1627	.1604
8	.1261	.1372	.1463	.1257	.1501	.1269	.1231
9	.0873	.101	.0914	.0991	.0918	.0987	.0945
10	.0834	.0987	.0739	.1048	.0876	.0949	.0987
11	.1635	.1055		.1006	.0861	.0956	.0743
12	.0793	.0991	.0747	.1044	.0854	.0979	.0865
13	.0762	.1055	.0747	.1002	.0899	.1067	.0899
14	.2126	.1147	.0716	.0914	.1029	.0907	.0934
15	.1827	.1109	.0526	.0972	.1082	.0934	.0758
16	.1642	.0922		.104	.0995	.0922	.0739
17	.0895	.0945		.0998	.0941	.0979	.0777
18	.1216	.1139		.1151	.1223	.1181	.0979
19	.1604	.1867	.1612	.1299	.1715	.1699	.1551
20	.1566	.1772	.2012	.1246	.1818	.1772	.1688
21	.1459	.1642	.1494	.1517	.1623	.1661	.1482
22	.1288	.1322	.1494	.1254	.1368	.1417	.1398
23	.1155	.0979	.0943	.1075	.1261	.1166	.1113
24	.184	.0926	.0754	.2145	.1094	.1002	.1002
Max	.269	.1867	.2012	.2145	.1818	.1772	.1688
Min	.0762	.0869	.0526	.0914	.0854	.0895	.0739
Avg	.1322	.1179	.1143	.1183	.1171	.1163	.1078

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 208 / VIJAYNAGAR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	31-MAR-17
HR	Load (MW)	Load (MW)
2		.7537
4		.7209
5		.8718
6	1.1843	1.0059
7		1.1271
8		.2012
9		1.1203
10		1.1203
11	.12	
12		1.1385
13	.1134	1.1702
14	.1296	1.1843
15	.1134	1.1843
16	.1134	1.2163
19		.2378
20		.2926
21		.2926
22		.2012
23		.1448
24	1.1012	.9717
Max	1.1843	1.2163
Min	.1134	.1448
Avg	.4108	.7871

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 201 / 11 KV PANMALEWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3049	.3193	.1509	3.7768	3.6054	3.395	.3481
2	.3033	.2875	.1509	3.5642	3.5147	3.2091	.3293
3	.2789	.2875	.1334	3.2944	3.3989	3.1585	.3315
4	.2951	.3125	.1334	2.7569	3.3501	3.0449	.3138
5	.3372	.3178	.1698	2.8189	3.4286	3.0171	.3075
6	.3822	.3906	.2096	3.051	3.5932	3.0826	.3871
7	.4123	.418	.2075	3.9841	4.1023	3.4061	.4736
8	.6486	.4687	.2218	.3806	.3681	.4968	.5137
9	5.1265	5.5857	.1463	.4064	.4481	4.2404	3.0392
10	4.8163	5.9004	.1848	.4634	.535	5.1643	6.0852
11	4.8225	5.8726	.2427	.4965	.5357	5.0213	6.046
12	2.8784	5.816	.2614	.5489	.518	4.3709	2.9414
13	4.6266	4.8133	.2587	.4779	.5125	4.9974	.1654
14	2.188	5.8983	.2054	.4397	.4174	4.971	.1722
15	2.7557	5.6531	.2218	.4687	.4435	5.0615	.1783
16	3.6066	5.4371	.2149	.4611	.4914	2.7397	2.7816
17	.7194	.3731	.2172	.4626	.5026	.4389	.2484
18	.4382	.3791	.2378	.3818	.3677	.4992	.2561
19	.5007	.4119	.2614	.3595	.3782	.5142	.2492
20	.5155	.4081	.2427	.3353	.4565	.4898	.2667
21	.468	.4267	.2427	.3789	.3842	.4664	.4703
22	.3959	.4087	2.0222	4.0185	4.1979	.4195	.4369
23	.3407	.3664	2.0622	4.0718	4.0066	.3951	.4035
24	.3262	.3277	.1698	4.0106	3.8432	1.7699	.3573
Max	5.1265	5.9004	2.0622	4.0718	4.1979	5.1643	6.0852
Min	.2789	.2875	.1334	.3353	.3677	.3951	.1654
Avg	1.5620	2.1200	.3571	1.7254	1.8083	2.6821	1.1293

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 202 / 11 KV BORGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.132	.1494	.1509	.1715	.2033	.1867
2	.1334	.132	.1509	.1494	.1524	.1867	.1698
3	.1334	.1132	.132	.132	.1334	.1829	.1463
4	.1698	.1509	.168	.1698	.1509	.1663	.1294
5	.2075	.2075	.2075	.2054	.1848	.2241	.1307
6	.2614	.2614	.2452	.2614	.2378	.2801	.168
7	.2743	.2033	.2614	.2614	.2402	.2402	.2402
8	.197	.181	.1991	.2172	.181	.1848	.2088
9	.1791	.1663	.1646	.1629	.1646	.1595	.1829
10	.1791	.1478	.1478	.1463	.1612	.1448	.1612
11	.1612	.1494	.1463	.1402	.1629	.1629	.1578
12	.1612	.1646	.152	.1612	.1629	.1646	.1402
13		.1829	.1463	.1829	.1629	.1646	
14	.1829	.1663	.1646	.2149	.1463	.168	
15	.1646	.168	.1478	.2012	.1663	.1612	
16	.1848	.1589	.1663	.1629	.1663		
17	.1848	.1478	.1867	.1829	.1433	.1629	
18	.2033	.1522	.1829	.1991	.1595	.181	
19	.2241	.2012	.2534	.2195	.2534	.2149	
20	.2614	.2772	.2587	.2587	.2561	.2402	
21	.2614	.2801	.2587	.2561	.2402	.2218	.2587
22	.2614	.2427	.2427	.2353	.2334	.2195	.2427
23	.2241	.2054	.2263	.1867	.2218	.2054	.2054
24	.1698	.1698	.1867	.1698	.1698	.2033	.1867
Max	.2743	.2801	.2614	.2614	.2561	.2801	.2587
Min	.1334	.1132	.132	.132	.1334	.1448	.1294
Avg	.1970	.1817	.1894	.1928	.1843	.1932	.1822

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 203 / 11 KV SHIRGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.2667	.3429	.3429	.3429	.3048	.2858
2	.3239	.2286	.3048		.3048	.2858	.2667
3	.2667	.2286	.2667	.3048	.3048	.2667	.2667
4	.2286	.2667	.3429	.3429	.2858	.2667	.2477
5	.3048	.3239	.4191	.381	.3048	.3048	.2477
6	.4001	.4001	.4572	.4382	.3239	.4001	.2858
7	.4191	.3429	.4382	.4382	.362	.4191	.3239
8	.3429	.2858	.362	.362	.2667	.4001	.2667
9		.2096	.2667	.362		.2286	.2858
10	.2858	.3048	.2858	.2477	.381	.3239	.2667
11	.2858	.2667	.3048	.2667	.3048	.2858	.2667
12	.3048	.2572	.3239	.2858	.3239	.2858	.2667
13		.2667	.3048	.3048	.2667	.2858	
14	.2286	.2553	.2858	.3239	.2858	.2477	
15	.2477	.2667	.2858	.3429	.3239	.3048	
16	.2477	.2667	.2667	.3239	.362		
17	.2667	.2572	.2858	.3048	.3239	.3048	
18	.3239	.3048	.3239	.3429	.3429	.3239	
19	.4572	.381	.4572	.4572	.4572	.362	
20	.5144	.5335	.5144	.362	.5335	.4954	
21	.4763	.5335	.5144	.4382	.4763	.4954	.4763
22	.4382	.4954	.4954	.4001	.4191	.4191	.4572
23	.4001	.4382	.4382	.4001	.381	.362	.381
24	.362	.362	.381	.381	.362	.1905	.3429
Max	.5144	.5335	.5144	.4572	.5335	.4954	.4763
Min	.2286	.2096	.2667	.2477	.2667	.1905	.2477
Avg	.3395	.3226	.3612	.3545	.3496	.3289	.3084

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 204 / 11 KV BORGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.8897	3.7098	1.7404	.4137	.391	.455	4.1426
2	3.8142	3.5512	1.6575	.4088	.378	.4369	3.9483
3	3.655	3.517	1.6057	.3751	.3567	.4153	3.7258
4	3.8256	3.4903	1.6907	.4091	.3742	.398	3.7136
5	3.9925	3.7784	1.757	.4923	.4184	.4695	3.6229
6	4.1434	4.087	1.8778	.6074	.4997	.5952	3.7898
7	4.5748	4.4132	1.9393	.5976	.5419	.567	4.0196
8	.4504	.4527	.2054	.8692	.9339	.5112	.5148
9	.4089	.4428	2.3537	5.0416	4.5542	.4965	.5445
10	.4104	.4451	2.5029	5.3879	5.041	.4771	.5396
11	.4066	.4001	2.5149	5.5247	4.7018	.4596	.5411
12	.4289	.4866	2.3868	5.3292	5.3689	.3248	.533
13	.3984	.4643	2.3922	5.3156	5.2315	.2172	.234
14	.4113	.3842	2.3266	5.3285	4.8559	.4068	.1555
15	.4298	.4031	2.3205	5.2729	4.9204	.4911	.2172
16	.4558	.4218	2.2447	5.2241	4.9527	.2629	.2233
17	.4832	.4203	.2241	.4085	.4596	.5555	.2309
18	.4794	.272	.2587	.5112	.5033	.5487	.2576
19	.4995	.3227	.2772	.5099	.6131	.0412	.2538
20	.5315	.4794	.2641	.5234	.6384	.5743	.2759
21	.7927	.7892	.2641	.503	.5826	.9381	.8154
22	4.2669	4.144	.2641	.4664	.4967	4.542	4.2244
23	4.1084	4.0672	.2452	.4401	.4929	4.5538	4.1804
24	3.847	3.8356	1.7939	.427	.4233	2.6124	4.1244
Max	4.5748	4.4132	2.5149	5.5247	5.3689	4.5538	4.2244
Min	.3984	.272	.2054	.3751	.3567	.0412	.1555
Avg	1.9460	1.8658	1.4628	2.0995	1.9888	.8896	1.8679

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 205 / 11 KV SHIRGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1132	.132	1.917	1.3599	1.5546	.1448
2	.0953	.1132	.1132	1.8299	1.3123	1.4746	.1294
3	.0953	.1132	.1143	1.7814	1.3108	1.4243	.1307
4	.1132	.1132	.1334	1.7394	1.2483	1.4419	.1294
5	.1494	.1494	.1698	1.8351	1.3272	1.4575	.1463
6	.1829	.2012	.2075	1.8138	1.3763	1.4548	.168
7	.1791	.1718	.2241	2.0972	1.7284	1.3441	.2058
8	.1448	.1783	.1829	.1341	.1646	.124	.1543
9	2.5286	2.8018	.1433	.1595		1.8244	2.769
10	2.5606	2.7018	.1448	.0914	.1698	2.4086	2.6558
11	2.4646	2.672	.128	.0895	.128	2.3758	2.5425
12	2.3685	2.6882	.124	.1097	.1254	2.5069	.1166
13	2.3045	2.6235	.1254	.1075	.1578	2.2672	
14	1.7604	2.5425	.116	.1267	.1402	2.3644	
15		2.5396	.112	.1097	.1254	2.3967	
16	2.0153	2.271	.1029	.1086	.1646		
17	.1753	.1867	.112	.0905	.1372	.1174	
18	.1753	.1406	.1294	.1097	.1543	.1029	
19	.1886	.1867	.0732	.1448	.1886	.12	
20	.2058	.1791	.2012	.1829	.1629	.2195	
21	.181	.181	.2033	.1646	.1791	.2033	.2172
22	.168	.1848	2.13	1.3763	1.7976	.1867	.1848
23	.1494	.1494	2.0809	1.4419	1.7532	.1478	.1494
24	.1132	.1132	.1307	1.9989	1.3603	1.6004	.1433
Max	2.5606	2.8018	2.13	2.0972	1.7976	2.5069	2.769
Min	.0953	.1132	.0732	.0895	.1254	.1029	.1166
Avg	.8015	.9715	.3056	.8150	.7205	1.2660	.6242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 206 / 11 KV PANMALEWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2005	.1957	.1132	.2509	.2214	.2225	.1951
2	.1779	.176	.1132	.2279	.202	.2006	.1741
3	.1859	.1779	.0934	.2298	.1764	.2005	.1794
4	.2038	.1912	.1132	.2538	.2075	.2014	.1814
5	.2259	.2143	.132	.2591	.2267	.2255	.2063
6	.261	.2726	.168	.3029	.272	.2719	.2699
7	.293	.301	.1646	.3336	.3086	.269	.3246
8	.2675	.2795	.1543	.3468	.2678	.2288	.2812
9	.1953	.1883	.1254	.2869	.2267	.1961	.1976
10	.1962	.1692	.1075	.2233	.1778	.1982	.1907
11	.1928	.1493	.0914	.2038	.1916	.1685	.1714
12	.1783	.1733	.0895	.198	.154	.1922	.1859
13	.1926	.1869	.0905	.2293	.1586	.1835	.096
14	.1949	.1958	.1132	.221	.1855	.248	.0983
15	.2069	.2151	.1097	.2053	.1945	.2214	.096
16	.2034	.2218	.1267	.226	.1968	.1059	.0903
17	.205	.2172	.128	.2221	.1741	.2149	.0876
18	.2424	.2282	.1086	.2271	.184	.2218	.0956
19	.3628	.3452	.1433	.3326	.306	.2821	.1551
20	.4079	.4755	.2281	.3574	.4011	.3145	.1955
21	.3803	.4477	.2033	.3223	.3765	.3536	.3265
22	.335	.3887	.1698	.3063	.2892	.2799	.2928
23	.2466	.3167	.1509	.2564	.2477	.2405	.2431
24	.2071	.2235	.1307	.2429	.2471	.2271	.2031
Max	.4079	.4755	.2281	.3574	.4011	.3536	.3265
Min	.1779	.1493	.0895	.198	.154	.1059	.0876
Avg	.2401	.2479	.1320	.2611	.2331	.2279	.1891

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 207 / 11KV NIMBLAK CHIKAL GOTHAN SEPARATED AG FEEDERS HAVING SPECIAL
AG Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8182	2.1376	2.4034	.1494	.1334	.168	1.989
2	2.6246	1.8461	2.2874	.1494	.1143	.1509	1.9498
3	2.451	1.9662	2.1548	.1509	.1143	.1494	1.7924
4	2.284	1.9334	2.0119	.1886	.1509	.1307	1.8351
5	2.3434	1.9989	2.0454	.2263	.1646	.1698	1.9989
6	2.4905	2.1051	2.1051	.2641	.1791	.2075	2.0243
7	2.4074	2.1628	2.4863	.2241	.1829	.1867	2.13
8	.2743	.1848	.1867	.1494	.1448	.1698	.2054
9	.2353	.1867		2.8837		.1448	.2054
10	.2012	.1867	3.0346	3.2217		.1494	.2241
11	.2012	.2033	3.0498	3.0476	2.2542	.168	.2241
12	.1663	.2241	2.8166	3.0001	2.5194	.1848	.2427
13	.1848	.2218	2.8509	3.0476	2.5692	.2033	
14	.1848	.2427	2.8166	2.8487	2.4531	.2054	
15	.2033	.2402	2.4863	2.8346	2.8837	.2241	
16	.2402	.2427	2.2045	2.7206	2.6355		
17	.2402	.2218	.2241	.1753	.2218	.2402	
18	.2614		.2427	.2012	.2801	.2241	
19	.2829	.2054	.2614	.1791	.2402	.2452	
20	.2829	.2241	.2452	.1463	.2641	.2641	
21	.2452	.2241	.2427	.1402	.2427	.2452	.2452
22	2.6993	2.7496	.2241	.1646	.2263		2.8837
23	2.5857		.2075	.1663	.1867	1.9725	2.7183
24	2.8807	2.3967	2.5484	.1698	.1509	.1698	1.9989
Max	2.8807	2.7496	3.0498	3.2217	2.8837	1.9725	2.8837
Min	.1663	.1848	.1867	.1402	.1143	.1307	.2054
Avg	1.1995	1.0048	1.7016	1.1021	.8324	.2715	1.4167

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 208 / 11kv VISAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.132	.132	1.5565	.7842	1.0883	.1294
2	.1334	.132	.1143	1.5061	.7701	1.085	.112
3	.1143	.1132	.1143	1.4575	.7449	1.065	.0943
4	.1509	.1132	.1334	1.5074	.7522	1.0526	.0934
5	.1646	.132	.132	1.5223	.7907	1.0242	.1109
6	.1991	.1698	.1698	1.5546	.852	1.0467	.1463
7	.2195	.1612	.2378	1.7859	1.1043	.9962	.1701
8	.181	.1753	.1991	.1791	.1448	.1791	.2195
9	2.1285	2.0719	.168	.1463		1.3603	1.8351
10	2.1765	2.4034	.1494	.1254		1.6712	1.9662
11	2.0081	2.2939	.132	.1267	.0747	1.8564	1.9662
12	1.9433	2.1464	.128	.1463	.1254	1.8023	.1457
13	1.9757	2.1382	.1294	.1267	.1267	1.704	
14	1.3927	2.0481	.1207	.1463	.1052	1.8515	
15		1.9595	.1294	.1448	.112	1.8842	
16	1.6221	1.8278	.1382	.1646	.1463		
17	.112	.1463	.1307	.1629	.1267	.1254	
18	.112	.1376	.1463	.1829	.1646	.1267	
19	.1494	.1463	.1629	.1991	.1848	.1646	
20	.2054	.1646	.1663	.1433	.1848	.168	
21	.1867	.1848	.1478	.1267	.1756	.168	.168
22	.1509	.1698	1.5729	.8642	1.2631	.1494	.1698
23	.1509	.1509	1.704	.8065	1.1843	.1433	.1509
24	.1509	.132	.132	1.6385	.8002	1.0911	.1294
Max	2.1765	2.4034	1.704	1.7859	1.2631	1.8842	1.9662
Min	.112	.1132	.1143	.1254	.0747	.1254	.0934
Avg	.6861	.8021	.2704	.6800	.4872	.9480	.4755

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 209 / WASUMBE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6706	.5754	.5639	.5868
2	.6097	.5449	.5449	.5754
3	.602	.5258	.5335	.5601
4	.5944	.5182	.5182	.5373
5	.522	.5182	.4496	.4649
6	.5639	.4915	.4992	.5068
7	.6173	.503	.5258	.5144
8	.4954	.5258	.5335	.5144
9	.5296	.5563	.4954	.4954
10	.5639	.6401	.5258	.4763
11	.6249	.6935	.6668	.5335
12	.5982	.6973	.6211	.5335
13	.5487	.5754	.6173	.583
14	.4725	.5449	.5373	.5182
15	.4877	.5601	.4839	.4725
16	.583	.6554	.442	.4458
17	.5754	.644	.4725	.4763
18	.5944	.6401	.5335	.4763
19	.3086	.6859	.5792	.4839
20	.4534	.8078	.7202	.6554
21		.7545	.7506	.6783
22	.4344	.6783	.7202	.6783
23	.6325	.6287	.6706	.6668
24	.5639	.5792	.6097	.602
Max	.6706	.8078	.7506	.6783
Min	.3086	.4915	.442	.4458
Avg	.5498	.6060	.5673	.5432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 210 / KAWATHE EKAND INDUSTRIAL
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.423	.7011	.7659
2	.7202	.4344	.6859	.7164
3	.724	.4268	.6783	.6287
4	.7011	.4115	.6783	.5982
5	.663	.362	.6706	.5982
6	.644	.3391	.6706	.5373
7	.583	.3163	.644	.4725
8	.4572	.2515	.4915	.3887
9	.3925	.2362	.5258	.3163
10	.3772	.2324	.5144	.3163
11	.4382	.2743	.5068	.4725
12	.6516	.7011	.6706	.5868
13	.7392	.7735	.8421	.6173
14	.7392	.6859	.8421	.4801
15	.7316	.6401	.7964	.5373
16	.6592	.7049	.8154	.5411
17	.6668	.6859	.7888	.442
18	.7011	.6973	.5944	.3925
19	.6287	.7125	.4611	.4572
20	.5373	.5525	.6059	.503
21	.2934	.5411	.6287	.4763
22	.1715	.5106	.6135	.5373
23	.2096	.4306	.6478	.6059
24	.4039	.6859	.743	.7049
Max	.7392	.7735	.8421	.7659
Min	.1715	.2324	.4611	.3163
Avg	.5633	.5012	.6590	.5289

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 208 / 11 KV MATKUNKI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.221	.221	2.4387	1.4632	1.768	.221
2	.2134	.221	2.3472	1.3565	1.6918	.221
3	.2134	.2134	2.2329	1.3336	1.6842	.2134
4	.2134	.221	2.1643	1.326	1.6156	.2134
5	.2286	.2286	2.1338	1.3032	1.5851	.221
6	.2896	.2972	2.4539	1.5394	1.6232	.2515
7	.3353	.3582	3.0255	1.8671	1.8823	.3125
8	.3277	.381	.6249	.282	1.6842	.3353
9	3.315	3.4979	.221	.2134	2.1795	2.4768
10	3.597	3.5742	.221	.1829	3.0407	3.315
11	3.4522	3.3532	.2362	.2286	3.0636	3.3074
12	3.3303	3.4751	.2058	.2439	3.0712	3.155
13	3.1321	3.3455	.2591	.2058	2.9797	
14	.6783	3.315	.2591	.2058	2.1795	
15	2.5377	3.2998	.2591	.2058	2.5758	
16	2.2177	3.4446	.2362	.221	2.7054	.602
17	.2972	.2515	.2743	.221	2.4539	2.0881
18	.2896	.3125	.2972	.2591	.2439	.3048
19	.3734	.3429	.3277	.282	.2058	.3582
20	.3887	.3734	.2972	.3734	.282	.3658
21	.3887	.381		.3658	.3353	.381
22	.282	.282	.9755	1.7147	.3125	.3506
23	.2667	.2591	1.5546	2.0119	.2591	.3353
24	.2439	.2515	1.4937	1.9662	.2439	.2743
Max	3.597	3.5742	3.0255	2.0119	3.0712	3.315
Min	.2134	.2134	.2058	.1829	.2058	.2134
Avg	1.1180	1.3292	1.0669	.8072	1.6528	.9192

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 201 / 11 KV ANKALKHOP GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.1715	.1715	.2058	.2058	.2058
2		.1715	.1715	.1715	.2058	.1715	.2058
3		.1715	.2058	.1372	.2058	.1715	.2058
4	.1715	.2058	.2058	.1372	.2058	.2058	.2058
5	.1715	.2058	.2058	.1715	.2401	.2401	.2401
6	.2743	.2058	.2743	.2058	.3086	.2743	.2743
7	.1715	.2058	.2058	.2401	.2401	.2058	.2401
8	.1715	.1715	.1715	.1715	.2058	.1715	.1715
9	.1715	.2058	.1715	.1715		.1715	.1715
10	.1372	.1372	.1715	.1715		.1715	.3086
11	.1372	.2058	.1715	.1715	.1715	.1372	.1715
12		.2058	.1372	.2058	.2058	.2401	.1715
13	.1715		.1372	.2401	.2401	.2058	.1715
14	.2058	.2058	.1715	.2058	.2743	.2058	
15	.1715	.2058	.1715	.2058	.2058	.2058	
16	.1715	.2058	.1715	.2058	.2058	.2743	
17	.1715	.2058	.2058	.2058	.2058	.1715	
18	.1715	.2058	.2401	.2058	.2058	.2058	
19	.2401	.2743	.3086	.3086	.2401	.3086	
20	.2743	.2401	.3429	.3429	.3086	.3772	
21	.3429	.2401	.3086		.3772	.3429	
22	.3086	.3086	.3086	.3429	.3429	.3429	.2743
23	.2743	.2743	.2743	.2743	.2743	.3086	.2401
24	.1715	.2058	.2058	.2058	.2058	.2058	.2058
Max	.3429	.3086	.3429	.3429	.3772	.3772	.3086
Min	.1372	.1372	.1372	.1372	.1715	.1372	.1715
Avg	.2041	.2103	.2129	.2117	.2401	.2301	.2165

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 202 / 11 KV AUDUMBER GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.1715	.2058	.1372	2.2805	4.2524	.2058
2	.2401	.1715	.2058	.1372	2.2805	4.2524	.1886
3	.2401	.1715	.2058	.1372	2.2805	4.2524	.1886
4	.2401	.1886	.2058	.1372	2.2977	4.2867	.1886
5	.2744	.1886	.2401	.1372	2.332	4.6982	.2401
6	.3086	.1886	.2743	.1372	2.5034	4.9726	.2915
7	.2744	.1886	.2401	.1372	2.1776	5.1783	.2058
8	.2058	.1372	.1715	.1372	.1715	.2401	.1715
9	6.6873	.1715	.1372	.1372		6.1385	3.1722
10	7.2359		.1372	.1372		6.0699	6.3436
11	.1715	7.3559	.1372	.1372	.1715	3.6351	6.5329
12	3.3436	7.9713	.1543	.1543	.2058	3.5665	.1715
13	.1372		.1543	.1715	.2058	3.6523	.1715
14	.1372	8.5048	.1715	.2058	.2058	3.6008	
15	.1543	8.7513	.1372	.205	.2058	3.5494	
16	.1715	7.3731	.1715	.1886	.2401	3.3608	
17	.1715	6.4449	.2743	.1886	.2401	.1715	
18	.1886	.2401	.2743	.1886	.2058	.1886	
19		.3086	.2915	.2401	.2401	.2743	.2744
20	.2572	.3086	.2743	.2915	.2744	.2743	.2744
21	.2572	.3086	.2572		.3086	.2572	.2744
22	.2401	.3086	.1372		.2743	.3258	.2744
23	.2058		.1372	2.4006	3.9094	.2229	.2401
24	.2401	.1715	.2401	2.8464	2.332	4.2867	.2058
Max	7.2359	8.7513	.2915	2.8464	3.9094	6.1385	6.5329
Min	.1372	.1372	.1372	.1372	.1715	.1715	.1715
Avg	.9401	2.3631	.2015	.3905	1.1520	2.9878	1.0324

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 203 / 11 KV BHILAWADI GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.5144	.5144	.5487	.4801	.5144	.4458
2	.5144	.5144	.5144	.5144	.4801	.4801	.4458
3	.5144	.5144	.4801	.4458	.4801	.4801	.4458
4	.5487	.5487	.5144	.4115	.4458	.4801	.4458
5	.6516	.583	.5487	.5144	.4801	.5487	.4458
6	.7202	.6173	.6859	.6173	.6516	.6173	.6859
7	.6859	.6516	.6859	.6516	.6516	.5144	.6173
8	.4115	.4115	.4458	.4458	.4115	.4458	.4115
9	.4115	.4115	.3429	.4458		.3772	.4115
10	.4115	.3772	.4458	.4115		.4115	.3429
11	.4115	.4458	.4458	.4115	.4115	.3772	.3429
12	.4458	.4801	.4801	.4458	.4458	.4115	.3772
13	.4115		.4801	.4458	.4801	.4115	.4115
14	.4458	.5487	.5144	.4801	.5144	.4115	
15	.4458	.5487	.4801	.5487	.5144	.4458	
16	.4458	.5144	.4458	.5144	.5144	.4801	
17	.5487	.4458	.4801	.4801	.5487	.3772	
18	.6173	.4801	.583	.5144	.5144	.3772	
19	.6859	.6173	.6516	.6516	.6173	.6859	
20	.6859	.6859	.6859	.7202	.7202	.6859	
21	.6859	.6859	.7202		.6859	.6516	
22	.6859	.6516	.6516	.6173	.6516	.6516	.6516
23	.6516	.583	.583	.5487	.6173	.5487	.583
24	.5487	.5487	.5144	.583	.4801	.5487	.5144
Max	.7202	.6859	.7202	.7202	.7202	.6859	.6859
Min	.4115	.3772	.3429	.4115	.4115	.3772	.3429
Avg	.5473	.5383	.5373	.5204	.5362	.4973	.4737

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 204 / 11 KV NAGATHANE GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3086	.3429	.2401	.3429	.3429	.3429
2	.2743	.2743	.3429	.2401	.3429	.2743	.3429
3	.2743	.2743	.3086	.2058	.3429	.2058	.3429
4	.2743	.2743	.3429	.2058	.3429	.3429	.3429
5	.3086	.3429	.3772	.2743	.4458	.3429	.4115
6	.3429	.3429	.3772	.3429	.5144	.3772	.4458
7	.3429	.3772	.4801	.4115	.4115	.4458	.4801
8	.3429	.2401	.2743	.2743	.3429	.4458	.3772
9	.3086	.2401	.2401	.2401		.2058	.3429
10	.2058	.2401	.2743	.2058		.1715	.4801
11	.2743	.2058	.2401	.2058	.2743	.1715	.2401
12	.3086	.1715	.2743	.1715	.3086	.3086	.2401
13			.2743	.2743	.3086	.3086	.2401
14	.3086	.2743	.2743	.2743	.3086	.3086	
15	.2058	.2058	.3086	.3429	.2743	.3429	
16	.2743	.2058	.3086	.2743	.3086	.3429	
17	.3086	.3429	.3772	.3086	.3429	.2743	
18	.3429	.3772	.4115	.3429	.3086	.2401	
19	.3772	.4115	.4458	.3772	.3429	.4458	
20	.3772	.3772	.4801	.4458	.3772	.5144	
21	.4115	.3772	.4801		.4115	.4801	
22	.4115	.3772	.4115	.4801	.2743	.4115	.3772
23	.4115	.3772	.3429	.4115	.2743	.4115	.3772
24	.1715	.3429	.3429	.2743	.3772	.2401	.3048
Max	.4115	.4115	.4801	.4801	.5144	.5144	.4801
Min	.1715	.1715	.2401	.1715	.2743	.1715	.2401
Avg	.3117	.3027	.3472	.2967	.3445	.3315	.3555

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 205 / 11 KV ANKALKHOP AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0343	.0343	1.9875	1.5745	1.7262	.0343
2		.0343	.0343	1.909	1.5486	1.6949	.0343
3		.0343	.0343	1.8815	1.5112	1.6957	.0343
4	.0343		.0343	1.9044	1.4609	1.7002	.0343
5	.0343	.0343	.0343	1.8983	1.4152	1.7025	.0343
6	.0343	.0343	.0343	1.9623	1.4617	1.7306	.0343
7	.0587	.0351	.0343	2.0789	1.6317	2.0065	.0495
8	.0716	.0831	.0343	1.1812	.9618	1.009	.0724
9	2.4394	2.1688	.0343	.0343		2.1026	2.0652
10	2.902	3.1474	.0343	.0343		2.87	2.9302
11	2.8334	3.2205	.0343	.0343	.0343	3.139	2.9309
12	3.2167	3.139	.0343	.0343	.0343	3.1592	1.5691
13	1.6392	1.6209	.0343	.0343	.0343	3.1547	.1852
14	1.5059	3.0269	.0343	.0343	.0358	3.0689	
15	1.0181	2.9782	.0343	.0343	.0343	2.9774	
16	2.2352	2.8769	.0343	.0343	.0343	2.7999	
17	.7979	1.5143	.0343	.0343	.0343	1.5318	1.0601
18	.0343	.0351	.0343	.0343	.0343	.0343	
19	.0343	.0373	.0343	.0008	.0358	.0343	.0023
20	.0343	.0427	.0343	.0343	.0373	.0358	
21	.0343	.0556	.0343	.0244	.0366	.0343	
22	.0343	.0404	.8573	.7995	1.4693	.0343	.0343
23	.0343	.0343	.9945	1.6225	1.7261	.0351	.0343
24	.0343	.0343	.0343	1.7901	1.6713	.8573	.0343
Max	3.2167	3.2205	.9945	2.0789	1.7261	3.1592	2.9309
Min	.0343	.0343	.0343	.0008	.0343	.0343	.0023
Avg	.9077	1.0549	.1086	.8091	.7645	1.6306	.6208

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 206 / 11KV AUDUMBER AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0335		2.649	2.1262		.0343
2		.0343		2.5819	2.0919		.0343
3		.0335		2.5484	2.1262		.0343
4		.0335		2.5484	2.1434		.0343
5		.0335		2.5149	2.1434		.0343
6		.0335		2.4813	2.3148		.0343
7		.0335		2.431	2.0576		.0343
8		.0343		.0335	.0343	.0343	.0343
9		2.2298		.0335	.0343	2.9835	3.0178
10				.0335	.0343	2.9492	
11	3.4294			.0343		3.5151	
12	3.3436		.0335	.0343		3.4294	
13			.0343	.0335		3.5151	
14			.0305	.0343		3.4294	
15			.0335	.0343		3.3779	
16	2.7435		.0335	.0343		3.1893	
17	.0343		.0335	.0343		.0343	
18	.0335		.0335	.0343		.0229	
19			.0335	.0343		.0343	
20	.0335		.0335	.0343		.0343	
21	.0335		.0335			.0343	
22	.0335		2.649	2.2634		.0343	
23	.0335		2.9675	2.2634	1.8861	.0343	
24		.0335		2.6406	2.2291	2.0576	.0343
Max	3.4294	2.2298	2.9675	2.649	2.3148	3.5151	3.0178
Min	.0335	.0335	.0305	.0335	.0343	.0229	.0343
Avg	1.0798	.2533	.4958	1.1028	1.6018	1.6888	.3327

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 207 / 11 KV BHILAWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4746	1.5089	2.0576	.0343	.0343	.0343	1.4746
2	1.4746	1.5089	2.0233	.0343	.0343	.0343	1.4403
3	1.4403	1.4746	2.0233	.0343	.0343	.0343	1.4403
4	1.3032	1.4746	1.989	.0343	.0343	.0343	1.4403
5	1.406	1.4403	2.1262	.0343	.0343	.0343	1.4403
6	1.5089	1.5775	1.989	.0343	.0343	.0343	1.4403
7	1.5775	1.5775	2.0576	.0343	.0343	.0343	1.4575
8	.0343	.0343	.0343	.0343	.0343	.0343	.0343
9	.0343	.0343	2.7435	2.8807		.0343	.0343
10	.0343	.0343	3.0864	3.0864		.0343	.0343
11	.0343	.0343	3.1207	3.155		.0343	.0343
12	.0343	.0343	3.155	3.0864	2.2634	.0686	.0343
13	.0343		3.0864	2.9492	2.332	.0686	.0343
14	.0343	.0343	3.0178	2.9492	2.1948	.0686	
15	.0343	.0343	2.8807	2.8121	2.4006	.0686	
16	.0343	.0343	2.7435	2.6749	2.4006	.0686	
17	.0343	.0343	.0343	.0343	2.2634	.0686	
18	.0343	.0343	.0343	.0343	.0343	.0686	
19	.0343	.0343	.0343	.0343	.0343	.0686	
20	.0343	.0343	.0343	.0343	.0343	.0686	
21	.0343	.0343	.0343		.0343	.0686	
22	1.5432	2.1262	.0343	.0343	.0343	1.6461	1.6461
23	1.5775	2.0919	.0343	.0343	.0343	1.7147	1.6804
24	1.5089	1.5432	2.0576	.0343	.0343	.0343	1.5775
Max	1.5775	2.1262	3.155	3.155	2.4006	1.7147	1.6804
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.6373	.7291	1.6847	1.0482	.6843	.1858	.9527

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 208 / 11 KV NAGTHANE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9204	1.869	1.8519	.1029	.1372	.1372	2.0576
2	1.7833	1.8176	1.7147	.1029	.1372	.1372	1.8861
3	1.7147	1.8176	1.6804	.1029	.1372	.1372	1.7147
4	1.7147	1.7833	1.6461	.1372	.1372	.1372	1.7147
5	1.9547	1.7833	1.7833	.1372	.1372	.1715	1.7147
6	2.0576	1.9204	1.9204	.1372	.2058	.1715	1.9204
7	2.0576	1.989	2.2634	.1372	.2058	.1715	2.0576
8	.1372	.1029	.1715	.1372	.1372	.2058	.1372
9	.1372	.1029	2.9492	3.2922	2.6063	.2058	.1715
10	.0686	.1029	3.2236	3.4294		.1372	.2058
11	.1029	.1372	3.2579	3.6351	3.4979	.1372	.2058
12	.1029	.1372	3.2579	3.6008	3.2236	.1372	.2058
13			3.3951	3.155	3.0864	.1372	.1715
14	.1029	.1372	3.2579	3.155	2.7778	.1372	
15	.1029	.1372	2.915	2.8121	2.915	.1372	
16	.1029	.0686	2.6235	2.8121	2.8121	.1372	
17	.1029	.2058	.1372	.1372	.1372	.1372	
18	.1029	.2058	.1372	.1372	.1372	.2058	
19	.1029	.2058	.1372	.1372	.1715	.0914	
20	.1029	.1715	.1372	.2058	.1715	.1372	
21	.1029	.1715	.1372		.1372	.1372	
22	2.1605	2.0576	.1372	.1372	.1372	2.332	2.0576
23	2.1948	1.989	.1372	.1372	.1372	2.332	2.0919
24	2.0576	1.9204	1.9204	.1029	.1372	.1372	2.1948
Max	2.1948	2.0576	3.3951	3.6351	3.4979	2.332	2.1948
Min	.0686	.0686	.1372	.1029	.1372	.0914	.1372
Avg	.9125	.9058	1.6997	1.2122	1.0139	.3311	1.2817

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 201 / 11 KV YELAVI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3147	.2892	.1509	1.6217	1.3794	1.3322	.2852
2	.2933	.2861	.132	1.5386	1.3229	1.2041	.2629
3	.2705	.2675	.1509	1.5245	1.2903	1.1507	.2652
4	.2887	.2854	.1886	1.5158	1.3161	1.1652	.2831
5	.3416	.2922	.2075	1.5493	1.371	1.1507	.314
6	.4144	.3825	.2263	1.7315	1.5731	1.213	.4068
7	.3979	.4009		1.9974	1.8454	1.2784	.4129
8	.4229	.3925	.2241	.3418	.3563	.3932	.4487
9	1.9757	2.063	.2241	.3508	.2876	1.7764	1.9109
10	2.0797	2.1506	.2054	.3599	.3014	1.9463	2.0107
11	2.2299	2.1735	.168	.3338	.3437	2.1071	1.9974
12	2.1871	1.9254	.1867	.3035	.2758	2.0157	.5426
13	.9275	1.9151	.1663	.302	.2591	1.9246	
14	1.1176	1.925	.1494	.2913	.2968	1.6499	
15	.759	2.0621	.168	.2953	.2968	1.7093	
16	1.5013	1.9612	.168	.2882	.2922	1.6488	.5647
17	.3147	.2156	.2054	.2644	.3147	.2294	.141
18	.3281	.2268	.2218	.3212	.3391	.2873	.141
19	.3578	.3788	.2641	.4226	.3525	.3239	.1821
20	.4159	.3826	.3206	.4309	.3803	.3788	.176
21	.4008	.3826	.2641	.2065	.4252	.3834	.1722
22	.3909	.363	1.0562	1.3717	1.4312	.3557	.1669
23	.6737	.3311	1.0562	1.5882	1.3386	.3367	.1425
24	.3155	.3044	.1886	1.6042	1.4369	.9509	.3105
Max	2.2299	2.1735	1.0562	1.9974	1.8454	2.1071	2.0107
Min	.2705	.2156	.132	.2065	.2591	.2294	.141
Avg	.7800	.8899	.2736	.8565	.7844	1.1213	.5303

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 202 / 11 KV Laxmi LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0182	2.3765	1.9231	2.452	1.9044	2.2405
2	1.9805	2.3765	2.1879	2.4143	1.848	2.3011
3	2.2068	2.3577	2.3765	2.452	1.848	2.3577
4	2.2634	2.3765	2.3954	2.4709	1.8858	2.3577
5	2.4709	2.3954	2.452	2.5086	1.9044	2.3765
6	2.4143	2.4897	2.5463	2.584	1.9044	2.4897
7	1.1643	2.4331	2.6406	2.6595	1.9993	2.5652
8	2.3577	2.7726	2.9235	2.6972	2.7349	1.3611
9	2.7538		2.9047	2.9235	2.6783	2.0182
10	2.6972	2.5652	2.9613	2.9235	2.8292	2.1691
11	2.8104	2.9613	2.9235	2.9235	2.7349	2.4897
12	2.6972	2.8292	2.8292	2.8292	2.5463	2.6595
13	2.6217	2.8481	2.7538	2.6783	2.5463	2.5652
14	2.7161	2.8292	2.7538	2.6783	2.5086	2.584
15	2.4897	2.9047	2.8669	2.4331		2.5652
16	2.1125	1.6598	1.9427	1.7375		2.0936
Max	2.8104	2.9613	2.9613	2.9235	2.8292	2.6595
Min	1.1643	1.6598	1.9231	1.7375	1.848	1.3611
Avg	2.3609	2.5450	2.5863	2.5853	2.2766	2.3246

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 203 / 11 KV Yelavi Bu'wadi

GAOTHAN FEEDER

Gaonthan Feeder KV- 11 /
OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.886	.9297	.415	.9583	.9267	.8611	.9027
2	.8141	.8935	.3772	.9313	.8935	.804	.8344
3	.8284	.892	.3584	.9621	.8927	.7785	.8337
4	.9235	.9364	.4527	1.0014	.9614	.8165	.9077
5	1.0993	1.0904	.5658	1.1532	1.1191	1.1027	1.0478
6	1.464	1.4247	.7545	1.4815	1.4071	1.3225	1.3835
7	1.3759	1.44	.6602	1.3694	1.4061	1.3904	1.4072
8	1.025	1.0547	.4572	.9488	1.022	.9907	.9648
9	.8139	.234	.3544	.8108	.8711	.7483	.7611
10	.7043	.8908	.3544	.7038	.8219	.6722	.6817
11	.687	.8608	.3544	.6839	.6984	.663	.6685
12	.7484	.7979	.3366	.7207	.7689	.7156	.6725
13	.394	.8002	.3366	.7747	.8063	.7023	.7085
14	.8524	.8303	.3761	.7198	.7751	.7423	.3917
15	.301	.8223	.4024	.8568	.5556	.759	.3986
16	.8589	.8393	.3189	.8652	.4725	.7476	.4024
17	.7663	.8444	.3856	.8665	.7903	.7507	.4199
18	.95	.945	.4458	.9211	.9061	.7665	.4435
19	1.2509	1.0738	.6516	1.2685	1.0311	1.2666	.5502
20	1.4899	1.5211	.7316	1.5794	1.5577	1.499	.7575
21	1.4609	1.4514	.7392	.7575	1.4758	1.4583	.7225
22	1.3714	1.3531	.6722	1.246	1.3527	1.3252	.6851
23	1.1728	1.1275	.5228	1.1077	1.1949	1.1535	.6036
24	.9865	.9774	.4715	.9968	.9957	.9983	.969
Max	1.4899	1.5211	.7545	1.5794	1.5577	1.499	1.4072
Min	.301	.234	.3189	.6839	.4725	.663	.3917
Avg	.9677	1.0013	.4790	.9869	.9876	.9598	.7549

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 204 / 11 KV Burungwadi

Industrial Feeder KV- 11 /
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5342	.3521	.2006	.548	.5142	.4641	.5052
2	.4843	.4595	.1829	.5493	.5605	.4423	.4938
3	.5121	.4935	.1698	.5121	.4977	.5085	.4923
4	.4885	.4759	.2031	.5346	.5018	.5232	.4961
5	.5373	.5151	.2214	.596	.4998	.631	.5491
6	.5777	.5886	.25	.6087	.4199	.618	.5834
7	.4176	.667	.3206	.3711	.33	.6253	.6135
8	.6306	.687	.3961	.7289	.4736	.671	.6074
9	.8219	1.1717	.462	.9507	.5468	.9022	.7652
10	.8939	1.4219	.4715	.7991	.5982	.9925	.7751
11	.8985	1.4055	.5281	.8835	.5346	.9084	.7847
12	.7864	1.379	.4854	.9054	.2385	.9012	.7377
13	.7024	1.3881	.4715	.8958	.5464	.9739	.6992
14	.807	1.5349	.7545	.8297	.9537	1.1439	.3757
15	.719	1.1789	.3142	.9267	.9606	1.2662	.3849
16	.6883	1.3234	.4715	.7857	.7568	1.3622	.3452
17	.8	.7524	.5975	.7411	.562	1.4102	.2949
18	.7364	.7948	.4108	.6421	.4452	.8818	.3117
19	.7298	.9926	.4481	.6977	.5258	.9248	.4047
20	.6735	.8682	.4024	.4841	.5498	.7301	.3414
21	.7449	.9622	.4108	.1974	.5159	.7636	.3681
22	.7834	.9576	.4251	.4386	.529	.683	.3041
23	.5464	.5906	.3841	.5533	.551	.6066	.3201
24	.4824	.5792	.2372	.6562	.4835	.555	.509
Max	.8985	1.5349	.7545	.9507	.9606	1.4102	.7847
Min	.4176	.3521	.1698	.1974	.2385	.4423	.2949
Avg	.6665	.8975	.3841	.6598	.5456	.8120	.5026

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 205 / 11Kv Express Feeder

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.1049	1.3397	1.5278	3.1084	2.9612	2.8553	2.911
2	3.2731		1.5089	3.0986	3.122	2.7987	3.0694
3	3.0788		1.5089	2.9434	3.027	2.6812	3.0677
4	3.1028		1.5278	2.9283	2.7978	2.7067	2.9541
5	3.0056		1.5089	2.8957	2.8534	2.7678	3.0855
6	3.0512		1.3769	3.0447	3.014	2.8835	2.9394
7	3.0032		1.4712	3.0632	2.9837	3.0045	2.8125
8	3.48		1.7353	3.1655	3.2777	3.312	3.257
9	3.0023		1.0562	3.0024	2.8418	3.0653	2.9816
10	2.6033	1.5061	1.2826	2.6086	2.367	2.5252	2.6271
11	2.6503	2.9698	1.3203	2.9419	2.6206	2.8251	2.7681
12	2.6662	2.8646	1.358	3.0529	1.9549	2.7751	2.6521
13	3.0578	2.8054	1.8107	3.6936	2.9279	3.5806	3.3507
14	3.1291	3.1211	1.9239	4.0625	3.7971	3.7418	1.8511
15	3.2977	3.5521	1.8861	3.9775	3.5965	3.7798	1.8168
16	3.7854	3.3036	1.6975	3.7709	3.5651	3.5523	1.7825
17	3.533	3.5679	1.7353	3.7277	3.5521	3.8009	1.7276
18	3.0213	3.042	1.226	3.4126	3.2773	3.2773	1.7177
19	2.4405	2.5542	1.1317	2.7843	2.4322	2.6471	1.2475
20	2.2184	2.3884	.9896	2.6022	2.3672	2.5368	1.1736
21	2.0042	1.8763	.8316	.7575	2.1986	2.2556	1.0387
22	2.2672	2.0283	1.1317	2.3384	2.1563	2.4838	1.0669
23	3.0771	2.9847	1.5278	3.4307	3.0655	3.2561	1.5623
24	2.7802	3.0194	1.5466	3.0925	2.9942	3.0327	2.8558
Max	3.7854	3.5679	1.9239	4.0625	3.7971	3.8009	3.3507
Min	2.0042	1.3397	.8316	.7575	1.9549	2.2556	1.0387
Avg	2.9431	2.6827	1.4426	3.0627	2.9063	3.0061	2.3465

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 206 / Yelavi Ag -2

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3334	.3361	.032	3.0003	2.6557	1.8918	.3227
2	.3243	.3224	.0286	2.8227	2.5674	1.8642	.309
3	.316	.3235	.0229	2.74	2.4409	1.8336	.3026
4	.3258	.3258	.0291	2.7579	2.4486	1.8805	.3134
5	.3631	.378	.0309	2.8243	2.5293	1.9866	.343
6	.4761	.4256	.0377	3.4576	3.1774	2.2658	.4248
7	.5477	.5302	.0838	4.3751	4.1663	2.5758	.5457
8	.4649	.4761	.0429	.4961	.4572	.6064	.5015
9	3.4446	4.1124	.0644	.3185	.3307	3.7963	3.7227
10	3.6061	4.4726	.0768	.2912	.2866	3.8317	3.7986
11	3.0719	3.9428	.0545	.2932	.2648	3.6969	3.6885
12	3.486	3.706	.0718	.2814	.2824	3.4888	1.874
13	1.7612	3.7075	.0732	.2972	.2614	3.3867	
14	1.2022	3.5155	.064	.2978	.2645	3.2823	
15	2.577	3.5208	.0503	.2761	.2774	3.3097	
16	2.738	3.6626	.0663	.2635	.2659	2.8266	1.3733
17	.3452	.3047	.064	.2987	.2953	.2039	.2934
18	.2446	.3624	.0914	.3364	.2785	.3258	.2538
19	.2659	.3846	.0713	.3458	.3609	.3815	.3086
20	.4795	.476	.0533	.4214	.4527	.4419	.3948
21	.4473	.4587	.0629	.365	.4275	.4229	.3849
22	.4317	.4104	1.9006	2.9599	2.7364	.4075	.3734
23	.3902	.365	1.6842	3.0983	2.6078	.3185	.3483
24	.3572	.3491	.0429	3.0582	2.5057	.3406	.3506
Max	3.6061	4.4726	1.9006	4.3751	4.1663	3.8317	3.7986
Min	.2446	.3047	.0229	.2635	.2614	.2039	.2538
Avg	1.1667	1.5362	.2000	1.4865	1.3476	1.8903	.9632

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244063 / 33/11KV KHATAV

Feeder No / Name : 201 / 11 KV VASAGADE GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3035	.3178	.1463	.3308		.3163	.3186
2	.3025	.2974	.1463	.3098		.3307	.2938
3	.2974	.2979	.1463	.3067		.2978	.3102
4	.2995	.2951	.1463	.3262		.294	.3291
5	.3063	.3246	.1991	.3471		.3063	.3329
6	.3317	.3734	.1097	.343		.3669	.3489
7	.3147	.3759	.181	.3247		.3795	.3178
8	.2598	.3323	.1097	.3026	.0991	.3052	.2561
9	.2309	.2697	.1097	.2534		.2729	.2382
10	.2461	.2766	.1097	.2713		.2565	.2298
11	.2669	.2371	.112	.2603		.2646	.2591
12	.2854	.2633	.1307	.2903	.3558	.2652	.3005
13	.2959	.2759	.1307	.3079	.3716	.2934	.3046
14	.2896	.2686	.1494	.3134	.3704	.3009	.2964
15	.3043	.2957	.1494	.3101	.3414	.3071	
16	.2877	.2911	.1307	.2629	.3274	.2774	
17	.2875	.2667	.1254	.0937	.3172	.287	.2938
18	.3327	.302	.1417	.1959	.386	.3406	.2965
19	.4552	.4412	.1848	.269	.4968	.4527	.4173
20	.4786	.4451	.2427	.2705	.5283	.4954	.2683
21	.4715	.4822	.2263		.4894	.4686	.4397
22	.4619	.4624	.2263	.1067	.4416	.4119	.4801
23	.3849	.4222	.1886		.3883	.3664	.4243
24	.33	.1867	.1097	.1698	.1852	.3231	.333
Max	.4786	.4822	.2427	.3471	.5283	.4954	.4801
Min	.2309	.1867	.1097	.0937	.0991	.2565	.2298
Avg	.3260	.3250	.1522	.2712	.3642	.3325	.3222

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244063 / 33/11KV KHATAV

Feeder No / Name : 202 / 11KV KHATAV GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3155	.3087	.1463	.3201		.3147	.2907
2	.3125	.289	.2195	.2984		.3079	.2869
3	.3162	.288	.1448	.2991		.2894	.3033
4	.3717	.1997	.1463	.3506		.3307	.3626
5	.3833	.3795	.2172	.4552		.4064	.4119
6	.4439	.4569	.2378	.4801		.4626	.4687
7	.4321	.4519	.2561	.4458		.4527	.471
8	.3376	.375	.128	.378		.3685	.3613
9	.2709	.3178	.128	.3048		.3033	.3351
10	.2354	.2934	.1097	.3087	.1776	.2578	.3216
11	.2723	.2515	.1063	.3066	.3334	.2736	.3033
12	.2636	.2496	.1402	.3193	.334	.2732	.2964
13	.2311	.2644	.1402	.3014	.362	.2911	.2381
14	.2923	.2968	.1463	.2641	.3605	.3299	.2363
15	.2534	.3376	.1478	.2801	.3742	.2995	.1052
16	.2432	.2835	.128	.2961	.3552	.2622	
17	.2694	.2461	.1029	.1196	.3378	.2424	.2485
18	.3146	.256	.1187	.0914	.3258	.2835	.257
19	.4565	.4489	.2378	.2553	.458	.41	.2454
20	.5113	.4916	.2402	.2759	.5083	.4725	.2774
21	.4721	.4715	.2241		.5041	.4466	.4683
22	.4428	.4533	.2263		.4519	.4035	.4462
23	.378	.3368	.1886		.3799	.3603	.4222
24	.3178	.3344	.1086	.1698	.1799	.3117	.3178
Max	.5113	.4916	.2561	.4801	.5083	.4725	.471
Min	.2311	.1997	.1029	.0914	.1776	.2424	.1052
Avg	.3391	.3367	.1662	.3010	.3628	.3398	.3250

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244063 / 33/11KV KHATAV

Feeder No / Name : 203 / 11 KV SUKHWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	.852	.8619	.0171		.0181	.8962
2	.8288	.8619	.8718	.0171		.0179	.9069
3	.8383	.8383	.8619	.0175		.0181	.9069
4	.7956	.8288	.8718	.0175		.0183	.8962
5	.7712	.8002	.8619	.0177		.0183	.9172
6	.7293	.8421	.8619	.0177		.0181	.9374
7	.7042	.8962	.9389	.0177		.0179	.9686
8	.0181	.1991	.0179	.0175		.0181	.016
9	.0181	.0183	1.2742	1.4754		.0183	.0162
10	.0183	.0175	1.2929	1.576		.0181	.0164
11	.0181	.0177	1.4083	1.5581	1.3123	.0179	.0164
12	.0179	.0179	1.3923	1.6095	1.2955	.0177	.0114
13	.0181	.0181	1.3763	1.5581	1.2803	.0177	.0145
14	.0179	.0183	1.326	1.5424	1.4548	.0175	.0143
15		.0183	1.3413	1.5581	1.3443	.0175	.0143
16		.0183	1.3413	1.6095	1.2003	.0171	
17		.0183	.0168		.017	.0171	.0179
18	.0181	.0183	.0168		.0175	.0171	.0181
19	.0181	.0183	.0175		.0175	.0173	.0177
20	.0183	.0181	.0177		.0179	.0181	
21	.0183	.0183	.0179		.0177	.0183	.0181
22		.7956	.0179		.0181	1.1142	1.1142
23	.8848	.8288	.0177		.0181	1.0688	1.1271
24	.8288	.8785	.8288	.0175		.0179	1.0242
Max	.8848	.8962	1.4083	1.6095	1.4548	1.1142	1.1271
Min	.0179	.0175	.0168	.0171	.017	.0171	.0114
Avg	.3709	.3691	.7438	.7438	.6163	.1073	.4494

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244063 / 33/11KV KHATAV

Feeder No / Name : 204 / 11 KV WASAGADE AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.181	.1829	1.5223		1.094	.1848
2	.181	.1791	.1829	1.4723		1.0486	.1848
3	.1829	.181	.2172	1.4723		1.0608	.2054
4	.1629	.1612	.2195	1.4548		1.0159	.2054
5	.1829	.1829	.2172	1.4685		1.004	.2054
6	.181	.2149	.2378	1.5623		1.1142	.2033
7	.1829	.2303	.1991	1.6762		1.1984	.2218
8	.181	.197	.2378	.2427		.2012	.2427
9	2.2298	2.4036	.2926	.2614		1.8084	1.8976
10	2.3472	2.8178	.2561	.2402		1.9919	1.9608
11	2.2874	2.5911	.2587	.2561		1.8679	1.9845
12	2.2283	2.4326	.2587	.2772	.1791	1.8679	
13	2.1714	2.2672	.2957	.2743	.2126	1.7814	
14	1.6766	2.1792	.2957	.2743	.1612	1.7814	
15		2.2542	.2957	.2743	.181	1.7368	
16	1.8842	2.3137	.2926	.2534	.1791	1.668	
17		.0362	.2561		.181	.2218	.2353
18	.2353	.1791	.2587		.197	.2427	.2195
19	.2378	.2172	.2987		.1991	.2452	.2715
20	.2507	.2195	.2987		.197	.2452	
21	.2534	.2195	.2957		.1991	.2452	.3077
22	.2328	.2172	1.7604		1.1843	.2263	.2926
23	.2172	.1829	1.7284		1.1336	.1886	.2715
24	.1629	.2012	.181	1.7004		1.0814	.1867
Max	2.3472	2.8178	1.7604	1.7004	1.1843	1.9919	1.9845
Min	.1629	.0362	.181	.2402	.1612	.1886	.1848
Avg	.8115	.9275	.3757	.8637	.3503	1.0391	.5156

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 201 / 11 KV Tasgaon I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9522	.9896	1.0082	.9709	1.0082	.9425	.9335
2	.9335	.961	.9795	.9808	.924	.924	.9335
3		.9425	.961		.8871	.8871	.9149
4	.9149	.9328	.9425		.8779	.9055	.8962
5	.9522	.9694	.961		.924	.9149	.8962
6	1.0534	1.0269	1.0349	1.0456	.9335	.9795	.9522
7	.924	.9328	.9425	.9231	.9313	.8238	.8962
8	.8596	.9231	.9036		.8596	.8059	.8326
9	.8417	.8954	.8688	.905	.8238	.8238	.7964
10	.985	.9774	.9134	.9991	.7973	.9492	.8688
11	1.0498	1.0631	1.0498	1.0745	.8145	1.0099	
12	1.0454	1.0631	1.0924		.8859	.9568	
13	1.0029	1.086	1.0974	1.1218	.9036	1.0099	
14	1.1157	1.1041	1.0791		.9231	1.0387	
15	1.1523		1.0974	1.1157	.9412	1.0679	
16	1.2012		1.1888	1.1403	1.0099	1.1403	
17	1.1088	1.0208	1.2197	1.0631	.964	1.0099	
18	.9955	1.134	1.3443	.964	.9991	.964	
19	1.2803	1.4266	1.3575	1.2308	1.2536	1.1765	
20	1.3717	1.4083	1.39		1.3756	1.3491	
21	1.2936	1.3717	1.386		1.2986	1.2936	
22	1.2883	1.3443	1.3443	1.2936	1.2752	1.2696	
23	1.1763	1.251	1.251	1.2696	1.1576	1.1949	
24	1.0164	1.0456	1.0534	1.0642	1.0642	.9795	1.0456
Max	1.3717	1.4266	1.39	1.2936	1.3756	1.3491	1.0456
Min	.8417	.8954	.8688	.905	.7973	.8059	.7964
Avg	1.0659	1.0850	1.1028	1.0726	.9930	1.0174	.9060

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 202 / 11 KV Tasgaon II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9774	.985	1.0029		1.0136	.985	2.1003
2	.9313	.9671	.985		.9774	.9568	2.0237
3		.9391	.9568		.8954	.9214	1.945
4	.8859	.9391	.9391		.9214	.9036	1.945
5	.9036	1.0242	.9568		.9313	1.8869	1.945
6	1.0425	1.0791	1.0791		.9671	2.0606	1.9652
7	.9511	1.0534	.9979	.9979	.9328	2.0704	2.0302
8	.8413	.8596	.7522		.7701	1.7204	1.7383
9	.8145	.7522	.788	.7343	.7602	1.5013	1.6236
10	.8871	.8871	.823	.823	.7343	1.6194	1.5448
11	.9425	.9149	1.0082	.823	.8048	1.7341	.3353
12	.9709	.9709	1.0269		.8145	1.7558	
13	.9795	1.0456	.8775	1.0751	.8596	1.8229	
14	.9694	1.0349	.961		.9328	1.8995	
15	.9877		1.0642	1.1203	.8688	1.9854	
16	.9694		1.0456	1.1016	.8962	1.9955	
17	1.0242	1.0269	1.1203	1.0269	.8871	1.9464	
18	1.1694	1.1128	1.2567	1.0751	.9808	2.0361	
19	1.4523	1.3392	1.4098	1.358	1.1883	2.5207	.9755
20	1.5278	1.5278	1.5089		1.3957	2.946	1.4327
21	1.3392	1.358	1.3957		1.3203	2.8401	1.6461
22	1.2883	1.307	1.3443	1.3769	1.307	2.6848	1.5546
23	1.1088	1.1827	1.2637	1.2637	1.1949	2.5119	1.4632
24	.9955	1.0498	1.0498	1.0679	1.0608	2.2205	2.3301
Max	1.5278	1.5278	1.5089	1.3769	1.3957	2.946	2.3301
Min	.8145	.7522	.7522	.7343	.7343	.9036	.3353
Avg	1.0417	1.0617	1.0672	1.0649	.9756	1.8969	1.6823

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 203 / 11 KV WATER SUPPLY
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6645	.7133	.3018	.3048	.5761	.7205	.69
2	.6645	.7133	.2829	.3048	.6035	.6679	.6714
3	.6645	.7011	.3018	.2743	.6409	.6679	.6714
4	.6645	.7011	.3018	.3048	.6409	.6679	.7019
5	.7154	.7011	.3018	.3353	.7289	.7354	.7697
6	.7804	.7884	.3395	.3658	.7844	.7884	.7884
7	.7804	.7621	.3921	.7926	.6792	.7659	.7697
8	.7621	.7579	.3696	.3963	.6748	.7659	.7884
9	.7169	.743	.3547	.7547	.6714	.6981	.6981
10	.6984	.7019	.3547	.7205	.7019	.6254	.5906
11	.6495	.7053	.3361	.7019	.7205	.5689	.5949
12	.6125	.6066	.2987	.3353	.5994	.5195	.5334
13	.5475	.4611	.3547	.5239	.5384	.4306	.2134
14	.4866	.5106	.3696	.1829	.4287	.3475	.1829
15	.7011	.2439	.132	.5106	.3715	.508	.2439
16	.7019	.2743	.0743	.6222	.7049	.6222	.3048
17	.6527	.629	.2427	.6714	.7354	.6595	.3353
18	.6527	.7205	.3584	.7205	.7659	.4542	.3353
19	.5689	.6615	.3547	.7205	.7205	.7884	.3658
20	.4535	.4896	.3547	.3658	.7205	.7392	.3963
21	.6104	.6066	.3547	.061	.6135	.7019	.3658
22	.5715	.5081	.3326	.0953	.4916	.6409	.3353
23	.643	.4891	.2614	.5277	.6401	.4167	.2439
24	.643	.6595	.2829	.6066	.6487	.629	.6104
Max	.7804	.7884	.3921	.7926	.7844	.7884	.7884
Min	.4535	.2439	.0743	.061	.3715	.3475	.1829
Avg	.6503	.6187	.3087	.4666	.6417	.6304	.5084

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 204 / 11KV NEW TASGAON

INDUSTRIAL FE Feeder KV- 11 /
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1734	.1143	.0343	.1029	.1631	.1585	.0915
2	.4763	.1143	.0309	.1029	.0914	.1577	.0286
3	.0938	.1105	.0343	.1105	.0953	.1577	.0286
4	.0366	.1143	.088	.1105	.1539	.1692	.0991
5	.1589	.1143	.0869	.1067	.08	.2039	.1814
6	.2278	.2294	.0914	.1029	.1768	.1877	.1806
7	.2162	.2328	.0869	.2096	.1791	.1905	.2225
8	.2313	.2248	.0914	.1181	.2004	.2515	.1753
9	.2835	.322	.1448	.304	.3296	.3421	.2001
10	.3677	.402	.168	.3867	.4497	.4321	.1962
11	.3867	.4642	.1492	.461	.3856	.5167	.2039
12	.6325	.378	.2667	.2629	.4001	.4946	.2616
13	.5049	.4009	.1578	.4706	.3281	.4858	.1334
14	.3612	.4054	.1578	.2096	.3901	.4248	.1296
15	.4965	.2286	.2012	.4565	.4572	.5346	.1219
16	.4702	.2439	.1829	.5575	.4058	.5311	.1181
17	.4477	.4515	.1478	.5537	.4321	.4625	.1372
18	.3552	.3726	.1829	.4763	.4344	.4816	.1181
19	.3444	.3029	.1829	.4115	.4095	.3597	.1334
20	.3155	.341	.1494	.2172	.3505	.2507	.1372
21	.2553	.3829	.1187	.0953	.2997	.2618	.1372
22	.1997	.2945	.132	.2504	.2542	.2126	.1334
23	.1997	.2744	.0953	.2035	.2389	.1973	.1181
24	.1516	.1982	.0766	.2058	.1867	.1738	.1334
Max	.6325	.4642	.2667	.5575	.4572	.5346	.2616
Min	.0366	.1105	.0309	.0953	.08	.1577	.0286
Avg	.3078	.2799	.1274	.2703	.2872	.3183	.1425

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 205 / 11 KV NIMANI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641		.2263			.2641	.2263
2	.2641		.2263			.2667	.2263
3	.2641		.2263			.2667	.2263
4	.2641		.2263		.2195	.2667	.2263
5	.3048		.3018		.2987	.3395	.3018
6	.3961	.3582	.3772		.3429	.3772	.3772
7	.3395	.3395	.3772	.1509	.3206	.3584	.3018
8	.2241	.2241	.2241		.2263	.2241	.2263
9	.1478	.1867	.1494	.2218	.2054	.2195	.2218
10	.1463	.1867	.1663	.1463	.1848	.1494	.1494
11	.1494	.2241	.2218	.1463	.2218	.1463	.1494
12		.2195	.2587		.1867	.1463	.1646
13		.2126	.2218	.2218	.2218	.2218	
14	.2195	.1132	.2218		.2218	.2218	
15	.2218		.2218	.1463	.2402	.2218	
16	.2218		.2241	.1478	.2218	.1478	
17	.1478	.1478	.2241	.1478	.2218	.1494	
18	.112	.2126	.3696	.2172	.2172	.2195	
19	.3772	.2926	.4481	.4066	.3511	.3696	
20	.4481	.5175	.4854		.4481	.4435	
21	.4338	.4527	.4527		.4338	.4527	
22	.3772	.4527	.3734	.3772	.415	.3018	
23	.3395	.3018	.3395	.3772	.3206	.3018	
24	.2829	.3018	.2263	.3018	.3048	.2829	.2263
Max	.4481	.5175	.4854	.4066	.4481	.4527	.3772
Min	.112	.1132	.1494	.1463	.1848	.1463	.1494
Avg	.2703	.2791	.2829	.2315	.2774	.2650	.2326

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 208 / 11 KV NIMANI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9662	1.768	.141	.1143	.1257	1.4822
2	1.8633	1.7109	.1372	.1143	.1257	1.4137
3	1.8061	1.6804	.1334		.1257	1.3908
4	1.7718	1.6728	.1334		.1219	1.3679
5	1.7604	1.6613	.1334		.1181	1.3603
6	1.7833	1.7071	.141		.1181	1.3717
7	1.9662	1.9243	.1334		.1181	1.7147
8	1.8671	1.9319	.1448		.1257	1.4365
9	.1257	.1372	2.0805	1.5966	.1334	.1105
10	.1029	.1105	2.5796	1.8861	.0991	.0762
11	.1105	.1105	2.5225	2.0538	.0876	.0991
12	.1143	.1296	2.5568	2.0995	.0838	.0914
13	.0305	.1372	2.3091	2.0462	.1029	
14	.1296	.1372	2.3015	1.7147	.1105	
15	.1296	.1372	2.1681	1.7528	.1143	
16	.1181	.0838	2.1948	1.7718	.1067	.0533
17	.1181	.0191	1.6956	1.246	.1181	.1448
18	.1181	.0876	.1524	.1334	.1296	.1524
19	.1562	.1067	.1562	.1448	.1296	.1524
20	.1638	.1791	.1753	.1638	.1562	.1715
21	.1829	.1867		.1715	.1715	.1638
22	1.688	1.467	.1448	.1715	1.4403	1.7223
23	1.8633	1.5966	.1372	.1524	1.5089	1.7871
24	1.8442	1.5623	.1181	.1296	1.5318	1.8633
Max	1.9662	1.9319	2.5796	2.0995	1.5318	1.8633
Min	.0305	.0191	.1181	.1143	.0838	.0533
Avg	.9075	.8435	.9735	.9702	.2918	.8631

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244087 / 33/11 KV TURACHI

Feeder No / Name : 201 / 11 KV NIMANI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5123	1.2018	1.3717	.1905
2		1.2003	1.358	.1715
3		1.1717	1.3757	.1715
4		1.2498	1.326	.1715
5		1.3283	1.3748	.1905
6		1.4548	1.3889	.2096
7		1.6842	1.4685	.2096
8		.1905	.1905	.2286
9		.1524	2.0466	2.1925
10		.1524	1.9925	
11		.1524	1.9204	
12		.1524	1.9766	
13		.1524	1.7654	
14			1.8404	
15		.1524	1.7711	
16	.1905	.1524	1.7394	
17	.1905	.1524		.4191
18	.1905	.1905		
19	.2286	.2096	.2096	.2477
20	.2477	.2477	.2286	.2667
21	.1715	.2477	.2096	.2286
22	1.4723	1.7553	.2096	.2286
23	1.4251	1.5154	.2096	.1905
24	1.5432	1.2631	1.439	.1905
Max	1.5432	1.7553	2.0466	2.1925
Min	.1715	.1524	.1905	.1715
Avg	.7172	.7013	1.2460	.3442

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244087 / 33/11 KV TURACHI

Feeder No / Name : 202 / 11 KV TURACHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.787	.6636	.7432	.0762	.0572	.0572	.8592
2	.8453	.5944	.7186	.0762	.0572	.0572	.8488
3	.787	.5937	.7011	.0762	.0572	.0572	.8333
4	.7907	.6173	.7343	.0572	.0572	.0572	.8436
5	.8162	.7099	.759	.0572	.0762	.0762	.8697
6	.8619	.8065	.7621	.0572	.0953	.1143	.8697
7	.7907	.9172	.8749	.0572	.0953	.1143	.9217
8	.0762	.0953	.0953	.0572	.0953	.1143	.0953
9	.0762	.0953	.8539	1.0774	.9259	.0953	.0953
10	.0572	.0953	.8905	1.0185	1.0155	.0762	
11	.0762	.0762	.9568	1.0311	.9755	.0762	
12	.0762	.0762	1.0277	1.0595	.8124	.0572	
13	.0762	.0762	1.0111	1.0311	.9602	.0572	
14	.0762	.0762	.9259	1.0467	.933	.0572	
15	.0762	.0953	.8962	1.034	.9374		
16	.0762	.0953	.9448	1.0155	.9686	.0572	
17	.0953	.0953	.0572		.0953	.0762	
18	.0953	.0953	.0572		.0953	.0762	
19	.1143	.0953	.0572	.0953	.0953	.0953	
20	.1143	.0953	.1143	.0953	.0953	.0953	
21	.0953		.0953	.0953	.0953	.0953	
22	.8855		.0762	.0762	.0953	.8642	
23	.8436		.0572	.0762	.0572	.8642	
24	.8223	.7499	.7562	.0572	.0572	.0572	.8592
Max	.8855	.9172	1.0277	1.0774	1.0155	.8642	.9217
Min	.0572	.0762	.0572	.0572	.0572	.0572	.0953
Avg	.3921	.3245	.5903	.4238	.3669	.1456	.7096

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244087 / 33/11 KV TURACHI

Feeder No / Name : 203 / 11 KV Dhavali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3721	.4191	.4001	.3734	.4294	.4191	.4572
2	.3121	.4001	.381	.3121	.4191	.4191	.4382
3	.3109	.4001	.381	.3045	.4191	.3961	.4191
4	.3121	.4191	.3921	.3366	.4382	.4191	.4191
5	.3898	.4763	.3921	.439	.4763	.4382	.4572
6	.5014	.6097	.4294	.4706	.6097	.5335	.5906
7	.6099	.6668	.6219	.5895	.6668	.6097	.6478
8	.4607	.5121	.4306	.4382	.4706	.4668	.5144
9	.394	.5121	.4163	.3898	.4298	.3801	.3982
10	.3582	.4298	.3721	.3761	.3856	.4024	
11	.443	.4252	.3988	.3601	.3856	.4477	
12		.4163	.443	.4207	.3582	.4031	
13		.4031	.3761	.4477	.3641	.4207	
14	.4298	.3681	.3988	.4656	.3898	.3944	
15	.4382	.4163	.3856	.4706	.3898		
16	.4607	.4075	.3721	.499	.4163	.4656	
17	.4477	.4075	.3544	.4572	.4207	.4755	
18	.4572	.4572	.3988	.3761	.4298	.5068	
19	.5906	.5068	.6661	.543	.543	.6099	
20	.724	.6584	.7087	.7207	.6767	.6283	
21	.6859		.6379	.5601	.6535		
22	.6097	.5415	.5375	.5175	.5847	.567	
23	.5144		.4607	.4668	.4954	.5175	
24	.3814	.4572	.4066	.4298	.4251	.4572	.4435
Max	.724	.6668	.7087	.7207	.6767	.6283	.6478
Min	.3109	.3681	.3544	.3045	.3582	.3801	.3982
Avg	.4638	.4687	.4484	.4485	.4699	.4717	.4785

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244091 / 33/11 KV Bhilwadi (Malwadi)

Feeder No / Name : 201 / 11 KV MALWADI INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1021	.1063	.08	.0977	.104	.061	.0914
2	.0827	.0977	.08	.0869	.0894	.061	.0914
3	.0693	.0838	.08	.0793	.0894	.0503	.0914
4	.0503	.0793	.08	.0693	.0827	.0503	.0914
5	.0667	.0579	.08	.076	.06	.0762	.0914
6	.084	.0549	.08	.0894	.0667	.0762	.0914
7	.0747	.0549	.0914	.0894	.0762	.0838	.0914
8	.08	.1134	.12	.0857	.0667	.0838	.1372
9	.1406	.1524	.1715	.1021	.1715	.1524	.1372
10	.1543	.1886	.1715	.1406	.2286	.1715	.0838
11		.2058	.2286	.1739	.2286	.2058	.0838
12		.2229	.2477	.1949	.2858	.2401	
13		.2229	.2667	.2858	.3077	.2229	
14	.2667	.2229	.2858	.2686	.2686	.2058	
15	.2667	.2229	.2667	.2667	.2096	.2058	
16	.2286	.2229	.2667	.2477	.2096	.1886	
17	.2286	.1543	.2667	.1905	.2096	.1715	
18	.1905	.12	.2286	.1905	.1905	.1715	
19	.0914	.1543	.1715	.1905	.1524	.1543	.0457
20	.0838	.1715	.1715	.1905	.1524	.1543	
21	.0838	.1543	.1187	.1715	.1524	.1715	
22	.1183	.1372	.1113	.0667	.0914	.1715	.0914
23	.1781	.12	.1406	.1149	.1406	.1543	
24	.1406	.1315	.08	.1149	.1143	.0914	.1543
Max	.2667	.2229	.2858	.2858	.3077	.2401	.1543
Min	.0503	.0549	.08	.0667	.06	.0503	.0457
Avg	.1325	.1439	.1619	.1493	.1562	.1407	.0981

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244091 / 33/11 KV Bhilwadi (Malwadi)

Feeder No / Name : 203 / 11 KV MALWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7362	.8173	.6401	.1334	.0953	.1143	.7621
2	.6642	.7628	.6401	.1334	.0953	.1143	.7621
3	.6481	.7628	.6401	.1334	.0953	.1143	.7621
4	.6009	.724	.6401	.1524	.1143	.1334	.7621
5	.6401	.724	.6401	.1905	.1143	.1524	.7621
6	.828	.7827	.6401	.2096	.1334	.1715	.7621
7	.9181	.873	.6401	.1905	.1334	.1905	.7621
8	.1334	.1543	.0857	.1524	.1143	.1905	.12
9	.1524	.1143	1.286	1.5223	1.0235	.1334	.0857
10	.1524	.1543	1.3117	1.5844	1.2029	.1029	.1143
11	.1334	.1372	1.4089	1.4403	1.1544	.12	.1143
12	.1334	.1372	1.3125	1.2346	1.0802	.12	
13		.1372	1.1717	1.2967	.9877	.12	
14	.0953	.12	1.2186	1.1111	.9414	.1372	
15		.12	1.1728	1.0059	.9259	.1372	
16		.12	.9962	.9831	.8128	.12	
17		.1372	.0762	.1334	.1143		
18	.1715	.1543	.1143	.1334	.1143	.1372	
19	.2096	.1715	.1715	.1715	.1334	.1543	
20	.2286	.1715	.1905	.1524	.1715		
21	.2286	.1543	.1715	.1715	.1524	.1715	
22	1.0957	.9602	.1524	.1143	.1524	1.0288	.9414
23	1.0059	.6859	.1334	.1143	.1334	.8573	
24	.8333	.8173	.6097	.1334	.1524	.1334	.8573
Max	1.0957	.9602	1.4089	1.5844	1.2029	1.0288	.9414
Min	.0953	.1143	.0762	.1143	.0953	.1029	.0857
Avg	.4805	.4122	.6693	.5249	.4229	.2116	.5821

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 201 / 11 KV ARWADE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0885		1.5249			.2652	1.6575
2	2.0222		1.5912			.2652	1.5912
3			1.5912			.2652	1.5581
4	1.989		1.5581			.2652	1.5912
5	1.989		1.5249			.2984	1.6244
6	2.1548		1.4586			.2984	1.9559
7	2.652	2.4863	1.7901	.2267	.2105	.3149	2.1879
8	.2984	.2915	.2622	.2374	.1619	.2984	.2622
9	.2622	.2267	2.2542	2.7778	1.5249	.1638	.2321
10	.2622		2.4863	2.9007	1.6575	.1966	.2155
11	.1966	.2641	1.757	2.9835	2.0885	.1311	
12	.1638	.2641	1.7901		2.0056	.1638	
13	.1989	.2241		2.652	1.5912	.1326	
14	.1989	.1848	2.5194		2.0719	.1326	
15	.1989		2.8841	2.6852	1.989	.0995	
16	.1989		2.3868	2.4577	2.0719	.1311	
17		.1966	.1677	.2561	.2321	.1311	
18	.3239	.2294	.2374	.3041	.2155	.2622	
19	.3725	.2949	.3018		.2652		
20	.3563	.3277	.3605		.3647	.1638	
21	.3563	.2622	.3391		.3481	.1311	
22	2.3205	1.989	.3018	.1658	.2984	1.989	
23	2.1548	1.8896	.2713	.1619	.2818	1.989	
24	2.1879	2.0153	1.757	.2267	.16		1.757
Max	2.652	2.4863	2.8841	2.9835	2.0885	1.989	2.1879
Min	.1638	.1848	.1677	.1619	.16	.0995	.2155
Avg	1.0430	.7431	1.3529	1.3874	.9744	.3676	1.3303

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 204 / 11 KV DHAVLI Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.197		.0514			2.1506	.0503
2	.197		.0514			1.9509	.0503
3			.0476			1.9204	.0503
4	.197		.0476			1.9204	.0503
5	.2303		.0476			1.9444	.0503
6	.2481		.0533			2.0622	.0533
7	.2507	.2172	.0503	2.4966	2.5606	2.3087	.08
8	.1886	.2172	.0724	.0591	.0819	.0857	.0667
9	2.5133	3.0087	.0533		.064	2.915	3.1093
10	1.8747		.0446	.0396	.0629	2.6882	2.9127
11	2.4006	3.3981	.0572	.0457	.0549	2.753	2.8487
12	1.7924	3.1093	.0533		.0572	2.0165	
13	.1715	3.0178	.061	.0591	.0686	2.2455	
14	1.2003	2.9797	.0572		.0566	2.4326	
15	.1509		.0446	.0572	.0566	2.7206	
16	2.1605		.061	.0724	.0533	2.4996	
17		.0876	.0686	.0781	.1006	.0164	
18	.2172	.1029	.0732	.1006	.1006	.1143	
19	.3292	.0854	.0709	.088	.0827	.0907	
20	.3258	.1029	.0774		.0886	.0914	
21	.3258	.0914	.0693		.0857	.0914	
22	.2149	.0457	2.5587	2.0309	2.372	.0686	
23	.2149	.0526	2.8166	2.0557	2.4036	.0457	
24	.1991	.1772	.0514	2.6246	2.0557	2.2497	.0457
Max	2.5133	3.3981	2.8166	2.6246	2.5606	2.915	3.1093
Min	.1509	.0457	.0446	.0396	.0533	.0164	.0457
Avg	.7091	1.1129	.2767	.7544	.5781	1.5576	.7807

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 401 / 33KV Hatnoor

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	15.7374	11.6598	3.5082	16.2918	15.1098	15.794	15.9774
2	15.4064	11.2483	3.5082	15.7031	14.4125	15.4064	14.8937
3	11.2483	11.1454	3.5082	15.2572	14.0604	14.8715	14.5062
4	14.3005	10.8711	3.3951	15.1098	13.7518	14.8594	14.4033
5	14.6759	10.8711	3.3951	15.3361	14.1049	14.8577	14.2319
6	15.9414	15.998	3.8477	16.3957	14.2753	15.7922	14.7325
7	16.3461	15.99	3.3951	16.3238	14.3827	16.2638	14.952
8	13.1413	13.4466	3.0247	13.9369	12.6864	13.9483	13.1722
9	12.7607	12.8293	3.1121	13.5357	12.5103	13.4911	12.2719
10	14.0261	14.1599	3.3048	14.481	12.6818	13.8443	12.5669
11	15.176	15.0572	3.9209	15.072	14.7102	15.6002	8.2922
12	15.9785	15.5659	4.257	10.3567	16.0391	16.3638	6.7707
13	15.8528	16.2484	3.9363	16.8702	14.9269	16.3215	5.0069
14	16.5752	16.6781	3.6969	12.4829	14.9726	15.6962	4.6639
15	17.2016	12.8601	3.8089	16.8439	15.2469	16.6438	4.8011
16	17.2452	13.2373	3.8089	17.3731	16.8244	16.1706	4.6639
17	16.9022	16.5433	4.145	16.9891	16.4404	15.7522	4.5953
18	16.4747	16.8793	4.6571	16.6724	16.7341	15.6219	4.5953
19	18.1002	13.2374	4.9291	15.9237	17.947	17.7183	11.8999
20	20.2492	19.081	4.9291	14.6434	20.6751	20.8848	14.9863
21	19.64	18.4888	4.6091	1.6461	19.9783	20.4116	15.2949
22	18.6369	18.0521	4.6571	13.7975	18.5769	19.0466	15.2264
23	18.1911	17.5515	4.257	16.7033	17.915	17.9389	14.4033
24	16.9016	16.5261	3.8477	16.2037	16.6507	16.9359	17.3011
Max	20.2492	19.081	4.9291	17.3731	20.6751	20.8848	17.3011
Min	11.2483	10.8711	3.0247	1.6461	12.5103	13.4911	4.5953
Avg	16.1129	14.7594	3.8941	14.7479	15.6506	16.2598	11.4254

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 406 / 33 KV Sut Girani

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-APR-17
HR	Load (MW)
24	1.6004
Max	1.6004
Min	1.6004
Avg	1.6004

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 407 / 33kv punadi LIS

PURELY LIS FEEDERS

Feeder KV- 33 / INCOMING

DATE	01-APR-17
HR	Load (MW)
24	1.7353
Max	1.7353
Min	1.7353
Avg	1.7353

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 201 / 11 KV Kasabe Digraj

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4715	.5093	.5281	.5093	.4527	.4527	.4338
2	.4715	.5093	.5281	.5093	.4527	.4338	.4338
3	.4715	.547	.5281	.5093	.4527	.4338	.4338
4	.4715	.547	.5281	.5093	.4527	.4338	.4338
5	.5093	.547	.5281	.5093	.4904	.4715	.4338
6	.5847	.5847	.5847	.5658	.547	.4904	.4715
7	.5093	.4904	.4904	.4715	.4338	.4338	.3772
8	.4338	.4527	.4338	.3961	.3961	.415	.3961
9	.4338	.6413	.6838	.4527	.415	.3772	.3772
10	.4435	.6602	.7167	.4715	.547	.6224	.4527
11	.7947	.6979	.6036	.547	.6653	.6036	.6413
12	.8131	.7545	.7282	.5658	.7577	.5093	.4338
13	.6838	.7733	.8962	.6036	.6283	.5093	.5175
14	.7577	.7733	.7842	.6413	.6653	.5359	.6468
15	.7392	.7733	.7282	.811	.7947	.695	
16	.7947	.5658	.5788	.7922	.6283	.695	
17	.7023	.5175	.7282	.7095	.6283	.7207	
18	.5228	.5729	.7842	.695	.5359	.6161	
19	.9522	.5658	.8215	.7842	.8215	.8029	
20	.8589	.6413	.7468	.9709	.8029	.8589	
21	.7842	.6036	.7095	.5415	.6036	.5601	
22	1.0642	.6224	.7842	.811	.5847	.5788	
23	.9619	.6979	.811	.547	.5281	.5093	.4904
24	.5281	.7167	.5658	.7167	.4715	.4527	.4715
Max	1.0642	.7733	.8962	.9709	.8215	.8589	.6468
Min	.4338	.4527	.4338	.3961	.3961	.3772	.3772
Avg	.6566	.6152	.6592	.6100	.5732	.5505	.4653

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 202 / 11 KV NANDRE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.5596	.4527	.6173	
2				.5596	.4527	.6173	
3				.5596	.4527	.6173	
4			.0457	.5596	.4527	.6173	
5				.5596	.4578	.6516	
6				.6001	.4973	.6516	
7				.583	.5144	.6687	
9	.7545	.78				.7802	.763
10	.7716	.8139				.9536	.8309
11	.7373	.7969				.9362	.8402
12	.7545	.6952				.9536	
13		.7122				.9362	
14	.7545	.7291				.9015	
15		.7122				.9015	
16	.6241	.6783				.7975	.6952
22			.5316	.463	.6173		
23			.5487	.463	.6173		
24				.5596	.463	.6173	
Max	.7716	.8139	.5487	.6001	.6173	.9536	.8402
Min	.6241	.6783	.0457	.463	.4527	.6173	.6952
Avg	.7328	.7397	.3753	.5467	.4978	.7637	.7823

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 203 / 11 KV TUNG VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1698	.1698	.1698	.1698	.1698	.1698
2	.1698	.1698	.1698	.1698	.1698	.1698	.1698
3	.1698	.1698	.1698	.1698	.1698	.1698	.1698
4	.1698	.1698	.1698	.1698	.1698	.1698	.1698
5	.1886	.1886	.1886	.3395	.1886	.2641	.1886
6	.3206	.3206	.3018	.3395	.2829	.3018	.2829
7	.3018	.3018	.2641	.3018	.2641	.2829	.2452
8	.2641	.2641	.2452	.2641	.2641	.2263	.1886
9	.2263	.2452	.2263	.2263	.2452	.2149	.2452
10	.2452	.2263	.2829	.2452	.2452	.2507	.2452
11	.2641	.1886	.2263	.2263	.1886	.1753	.2075
12	.2641	.2641	.2452	.2641	.2263	.2328	.2641
13	.2263	.2075	.2641	.2452	.2263	.2328	.2012
14	.2641	.2452	.2641	.2452	.2075	.2075	.2058
15	.0754	.2263	.2263	.2263	.2452	.1886	
16	.0943	.2641	.2075	.2263	.1509	.2075	
17	.1698	.2241	.2263	.2267	.2263	.2641	
18	.2641	.2401	.2829	.2458	.2452	.2452	
19	.3206	.2947	.3395	.2896	.3018	.3395	
20	.3584	.3292	.3584	.3292	.3395	.3584	
21	.3018	.3292	.3395	.3109	.3206	.3206	
22	.3018	.3206	.3206	.2829	.3018	.3018	
23	.2641	.2641	.2829	.2452	.2641	.2452	.2641
24	.2075	.1698	.1886	.1886	.1886	.1698	.1698
Max	.3584	.3292	.3584	.3395	.3395	.3584	.2829
Min	.0754	.1698	.1698	.1698	.1509	.1698	.1698
Avg	.2334	.2414	.2483	.2478	.2334	.2379	.2117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 205 / 11 KV TUNG AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.1961	.8907	1.153	
2				1.1961	.852	1.153	
3				1.1961	.852	1.0852	
4				1.1961	.852	1.0174	
5				1.1961	.852	1.0174	
6				1.1961	.9717	.9835	
7				1.2452	1.085	1.0343	
9		1.4582				1.4419	1.5402
10		1.3763				1.2597	1.6385
11		1.3927				1.5581	1.5729
12		1.2763				1.5581	
13		1.1633				1.5912	
14		1.1012				1.3927	
15		1.1142				1.3603	
16		.9995				1.4091	
17	.0492						
22			1.3435	.9717	1.2209		
23			1.4746	1.0202	1.1869		
24				1.5382	.9282	1.17	
Max	.0492	1.4582	1.4746	1.5382	1.2209	1.5912	1.6385
Min	.0492	.9995	1.3435	.9717	.852	.9835	1.5402
Avg	.0492	1.2352	1.4091	1.1952	.9691	1.2616	1.5839

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 206 / 11 KV Vasant LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.3018	.3018	.2829	.3018	.2452
2	.1698	.3018	.3018	.2829	.3018	.2452
3	.1698	.3018	.3018	.2829	.3018	.2452
4	.1698	.3018	.3018	.2829	.3018	.2452
5	.1698	.3018	.3018	.2829	.3018	.2452
6	.3395	.3018	.3206	.3395	.3395	.2452
7	.4527	.5544	.4338	.415	.3395	.2641
8	.4338	.4338	.4338	.4338	.2452	.2829
9	.5975	.5093	.4904	.5093	.2829	.3772
10	.6161	.5093	.5281	.5093	.3018	.3772
11	.6348	.5093	.5093	.4904	.3395	.3772
12	.5975	.4527	.5093	.4715	.3395	.3772
13	.6161	.4904	.4904	.415	.3395	.3772
14	.6161	.4904	.4904	.3772	.3395	.3584
15	.6161	.4904	.5093	.3772	.3395	.3584
16	.4904	.5093	.5281	.3772	.3395	.3772
Max	.6348	.5544	.5281	.5093	.3395	.3772
Min	.1698	.3018	.3018	.2829	.2452	.2452
Avg	.4287	.4225	.4220	.3831	.3159	.3124

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 202 / 11 KV KAVALAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1555	.1578	.1574	.1673	.1642	.1703
2	.1467	.1536	.157	.1677	.157	.16
3	.1536	.1543	.157	.1612	.1539	.157
4	.1494	.1555	.1547	.16	.1528	.1562
5	.1486	.1623	.1513	.1547	.1425	.1517
6	.1574	.1898	.1795	.1669	.1619	.1452
7	.1814	.1833	.1825	.1867	.1749	.1677
8	.165	.1696	.1486	.1844	.1791	.1802
9	.1322	.1398	.1265	.1749	.1478	.157
10	.1372	.1414	.1395	.1543	.1547	.141
11	.1379	.1448	.1558	.1661	.1661	.1501
12	.1437	.1448	.141	.1787	.1814	.1509
13	.0918	.1025	.1151	.1814	.1985	.1017
14	.1063	.101	.1494	.1734	.1951	.0922
15	.1135	.0953	.1517	.1044	.1109	.1006
16	.1158	.1105	.1482	.1082	.093	.0968
17	.1075	.1284	.1326	.1059	.1608	.093
18	.1223	.1417	.1113	.1075	.1871	.0972
19	.1642	.1452	.1646	.0949	.1715	.1669
20	.2416	.2267	.2187	.1814	.2324	.2248
21	.2237	.2096		.2138	.2282	.2145
22	.1471	.1951	.1478	.2065	.2187	.2084
23	.1555	.1837	.2039	.2134	.2023	.208
24	.1528	.1524	.1837	.1829	.1703	.1749
Max	.2416	.2267	.2187	.2138	.2324	.2248
Min	.0918	.0953	.1113	.0949	.093	.0922
Avg	.1479	.1537	.1556	.1624	.1710	.1528

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 205 / 11 KV Kavalapur Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.192	.1715	.9995	.6523	.8524	.1852
2	.1882	.1669	.9564	.6375	.8078	.1753
3	.1871	.1665	.916	.6546	.7884	.1741
4	.1863	.1669	.9137	.6847	.7903	.1718
5	.1661	.1734	.9701	.7019	.8169	.1791
6	.2	.2054	1.1927	.8459	.9343	.1955
7	.2244	.2382	1.4883	1.1142	1.0833	.2157
8	.3246	.3593	.2176	.2077	.2709	.3178
9	1.454	1.5386	.1753	.1879	1.3146	1.5337
10	1.6941	1.7551	.1818	.1528	1.2734	1.5604
11	1.6305	1.7589	.141	.1315	1.3413	1.5947
12	1.5211	1.7227	.1067	.1417	1.1789	.3456
13	1.4392	1.6419	.1376	.1406	1.3058	.1391
14	.2713	1.5394	.1501	.1456	1.3207	.1909
15	.9149	1.4986	.1593	.1494	1.302	.1856
16	.8097	1.5455	.1562	.1326	1.4666	.7735
17	.1334	.1208	.1345	.1524	.149	.1475
18	.1677	.1543	.1772	.1558	.2065	.2
19	.2241	.2088	.1718	.1989	.25	.2134
20	.229	.2416	.2084	.2427	.3006	.2401
21	.2111	.2416	.3071	.3304	.2858	.2244
22	.2119	.2328	.7766	.9587	.2458	.2084
23	.1802	.2073	.7651	.9187	.2145	.1959
24	.1741	.1802	.6466	.8848	.1939	.1734
Max	1.6941	1.7589	1.4883	1.1142	1.4666	1.5947
Min	.1334	.1208	.1067	.1315	.149	.1391
Avg	.5390	.6765	.5021	.4385	.7789	.3975

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 201 / 11 KV Mouje Digraj

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0158	.0274	.0168	.0019
2	.0191	.0191	.0191	.0158	.0282	.0168	.0019
3	.0191	.0191	.0191	.0158	.0282	.0168	.0019
4	.0191	.0191	.0191	.0158	.029	.0168	.0019
5	.0191	.0191	.0191	.0158	.029	.0168	.0019
6	.0191	.0191	.0191	.016	.029	.0168	.0019
7	.0191	.0191	.0191	.0141	.0286	.0168	.0019
8	.0191	.0191	.0191	.0191	.0191	.0191	.0019
9	.0312	.0316	.0191	.0191			
10	.0312		.0019	.0191	.0191	.0312	
11	.0312	.0332	.0019	.0191	.0191	.0474	
12	.0271	.0332	.0019	.0191	.0191	.0474	
13	.0271	.0339	.0019	.0191	.0191	.0474	
14	.032	.0339	.0019	.0191	.0191	.0474	
15		.0343	.017	.0191	.0191	.0474	
16	.032	.0343	.0019	.0191	.0191	.0474	
17		.0191	.0019	.0191	.0191	.0019	
18	.0191	.0191	.0019	.0191	.0191		
19	.0191	.0191	.0019	.0191	.0191	.0019	
20	.0191	.0191		.0191	.0191	.0019	
21	.0191	.0191	.0019	.0191	.0191	.0019	
22	.0191	.0191	.0162	.0274	.0164	.0019	
23	.0191	.0191	.0162	.0274	.0164	.0019	
24		.0191	.0019	.0162		.0168	.0019
Max	.032	.0343	.0191	.0274	.029	.0474	.0019
Min	.0191	.0191	.0019	.0141	.0164	.0019	.0019
Avg	.0228	.0235	.0105	.0186	.0218	.0218	.0019

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 203 / 11 kv PWV Bramhnal

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3497	.0339	.1677	.4036	.3831	.5006	.3646
2	.3488	.0339	.1341	.3978	.3981	.4997	.3659
3	.3487	.1595	.1372	.398	.4016	.493	.3656
4	.4022	.1595	.1372	.3973	.4015	.4935	.3648
5	.4023	.1595	.1372	.4448	.4551	.4929	.3651
6	.404	.1595	.1372	.4854	.4557	.4942	.4485
7	.4048	.1595	.1372	.5278	.4735	.4968	.461
8	.0675	.1679	.1387	.5474	.3307	.4937	.4668
9	.1478	.1712	.1417	.4658	.4343	.1997	.2124
10	.1578		.1433	.4658	.4988	.3296	.2157
11	.1595	.181	.1772	.3675	.5176	.1423	
12	.0753	.181	.1791	.2658	.4016	.0867	
13	.0753	.1829	.037	.2328	.4614	.0867	.0111
14	.0919	.1829	.1943	.2328	.2754	.0857	.012
15	.0879	.0914	.3361	.0526	.08	.0893	.0116
16	.0929	.0914	.2267	.0526	.08	.0857	.0109
17	.0831	.0956	.2515	.0154	.0817	.087	.001
18	.0819	.0958	.2515	.2764	.0625	.0838	.0101
19	.0509	.098	.2429	.2767	.0474	.1341	.0106
20	.0509	.1455		.2767	.2214	.2686	.0006
21	.0503	.2328	.2486	.3763	.3077	.2694	
22	.0514	.2721	.2321	.317	.4668	.2893	.2076
23	.0339	.3715	.2012	.2395	.3792	.3698	.2052
24		.2345	.2486	.4038	.2026	.3684	.3702
Max	.4048	.3715	.3361	.5474	.5176	.5006	.4668
Min	.0339	.0339	.037	.0154	.0474	.0838	.0006
Avg	.1747	.1592	.1843	.3300	.3257	.2892	.2134

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 204 / 11 KV Express LIS Feeder

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2957	.2987	.2743	.2987	.3174	.3045
2	.2957	.2987	.2743	.2987	.3174	.3045
3	.2987	.2987	.2743	.2987	.3361	.3045
4	.2987	.2987	.2743	.2987	.3361	.3045
5	.2987	.2987	.2743	.2987	.3361	.3045
6	.2941	.2987	.2743	.2987	.3361	.3045
7	.3174	.2987	.2743	.2987	.3361	.3045
8	.3174	.2987	.2801	.3361	.2801	.3045
9	.3174	.2987	.2987	.3361	.3361	
10	.2987		.2987	.3361	.3361	.3361
11	.2987	.2987	.3361	.3361	.3361	.3361
12	.2987	.2987	.3361	.3361	.3326	.3361
13	.2772	.2987	.3361	.3361	.3142	.3361
14	.3174	.2987	.3361	.3361	.3142	.3361
15	.2987	.2987	.3361	.3361	.3142	.3361
16	.2987	.2987	.3361	.3361	.2328	.3361
Max	.3174	.2987	.3361	.3361	.3361	.3361
Min	.2772	.2987	.2743	.2987	.2328	.3045
Avg	.3014	.2987	.3009	.3197	.3195	.3192

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 205 / 11 KV Yeshwant Express

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.42	1.0952	.6341	2.2403	1.1862	2.4467	
2	2.4558	1.0932	.6341	2.2632	1.1961	2.4482	
3	2.4519	1.0913	.6341	2.2681	1.2144	2.4086	
4	2.4493	1.0913	.6341	2.2654	1.2106	2.4017	
5	2.5605	1.0898	.6341	2.2839	1.211	2.4094	
6	2.5927	1.0948	.6687	2.2961	1.246	2.4238	
7	2.2835	1.1508	.6687	.8379	2.0812	2.4551	
8	2.3564	1.3618	.7183	2.4768	1.691	2.2017	
9	2.314	1.4167	1.0562	2.4734	2.3628	.775	
10	1.8941	.6234	1.5089	2.4486	2.5827	2.1616	
11	1.8907	1.5733	1.5089	2.4128	2.5793	2.0027	
12	1.8404	1.5527	1.5089	2.4207	2.0248	2.4615	
13	1.8255	1.6884	1.2346	2.4211	2.2333	2.4851	
14	1.8644	1.6842	1.4403	2.4097	2.3529	2.4947	
15	1.8598	1.7379	1.4403	2.2992	2.3339	2.4974	
16	1.8598	1.739	1.166	2.3019	2.0176	2.1952	
24	.0652	.0876		.072	.0922		.109
Max	2.5927	1.739	1.5089	2.4768	2.5827	2.4974	.109
Min	.0652	.0876	.6341	.072	.0922	.775	.109
Avg	2.0579	1.2454	1.0056	2.1289	1.7421	2.2668	.109

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 206 / 11 KV NAWARASWADI

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.2103	.2035	.2012	.0838	.1957
2	.0191	.2103	.2035	.2012	.0838	.1957
3	.0191	.2103	.2035	.2012	.0838	.1957
4	.0191	.2103	.2035	.2012	.0838	.1957
5	.0191	.2103	.2035	.1844	.1017	.1957
6	.0191	.2103	.2035	.1753	.1017	.1957
7	.0191	.2103	.2035	.1907	.3012	.1957
8	.0191	.2279	.2035	.1865	.1357	.1806
9	.0191	.2103	.2035	.1865	.1844	
10	.0366		.3506	.1715	.2126	.3086
11	.0366	.2353	.1017	.1715		.3086
12	.2058	.2353	.1017	.1715	.2126	.3086
13	.2058	.2353	.0029	.1734	.2012	.3086
14	.2328	.2353	.0312	.1734	.2012	.3086
15	.2328	.2195	.2058	.208	.2012	.3086
16	.2328	.2172	.2035	.208	.1806	.3086
Max	.2328	.2353	.3506	.208	.3012	.3086
Min	.0191	.2103	.0029	.1715	.0838	.1806
Avg	.0847	.2192	.1768	.1878	.1580	.2474

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244037 / 33/11 KV PRAKASH AGRO

Feeder No / Name : 201 / 11 KV Haripur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9231	.8907	.9602	.0377	.0373	.0377	1.004
2	.9116	.8907	.9555	.0377	.0377	.0377	.9602
3	.9012	.9012	.9393	.0377	.0377	.0377	.9442
4	.8785	.9012	.9393	.0377	.0377	.0377	.9172
5	.8684	.9012	.9555	.0377	.0377	.0377	.9014
6	.8785	.9175	.9667	.0377	.0377	.0377	.9282
7	.9503	.9069	.9831	.0377		.0377	.9646
8	.0377	.0377	.032	.0377			
9	.0377		1.1797	1.3599	1.3279	.0189	
10	.0189	.0189	1.2929	1.4918	1.3757	.0189	.0179
11	.0189	.0185	1.5089	1.6095	1.4255	.0377	.0177
12	.0377	.0189	1.5249	1.5729	1.4089	.0189	
13	.0377	.0189	1.3765	1.5249	1.3763	.0187	
14	.0189	.0189	1.4582	1.5074	1.3426	.0373	
15		.0187	1.4586	1.5424	1.3094	.0189	
16		.032	1.4586	1.5089	1.278	.0187	
17		.0286	.0377	.0154	.0189	.0324	
18	.0189	.0286	.0377	.016	.0377	.0145	
19	.0377	.0469	.0377	.0366	.0377	.0362	
20	.0377	.0362	.0377	.0362	.0377	.0366	
21	.0377	.0362	.0377	.0362	.0377	.0362	
22	.8951	.9995	.0377	.0189	.0377	.9762	
23	.9503	1.004	.0377	.0189	.0377	.9762	
24	.9503	.9231	.9922	.0377	.0373	.0377	.9686
Max	.9503	1.004	1.5249	1.6095	1.4255	.9762	1.004
Min	.0189	.0185	.032	.0154	.0189	.0145	.0177
Avg	.4498	.4172	.8019	.5265	.5160	.1130	.7624

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 201 / 11 kv Dudhgaon AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9181	1.8435	.8535	.0171	.0171	.0171	2.1909
2	1.8347	1.7602	.8535	.0171	.0171	.0171	2.1353
3	1.848	1.7571	.8535	.0171	.0171	.0171	2.0896
4	1.8328	1.7189	.8535	.0171	.0171	.0171	2.0576
5	1.7947	1.7044	.8535	.0171	.0171	.0171	1.9958
6	1.7802	1.6937	.823	.0175	.0171	.0175	2.0218
7	1.8434	1.6834	.9145	.0171	.0171	.0171	2.0218
8	.2149	.3501	.0133	.0175	.0145	.0171	.2625
9	.0171	.0149	1.1961	2.761	2.8056	.0171	
10	.0171	.0133	1.406	3.0504	2.9165	.0152	
11	.0171	.0133	1.3717	3.1764	2.9629	.0152	
12		.0133	1.406	3.0878	2.9157	.0152	
13	.0154	.0133	1.3375	2.9789	2.7915	.0152	
14	.0175	.0133	1.2346	2.9157	2.5774	.0152	
15	.0151	.0133	1.1736	2.8842	2.4364	.0152	
16	.0135	.0133	1.0277	2.8204	2.3617	.0152	
17	.0137	.0133	.0171	.5125	.4244	.0152	
18	.0152	.0133	.0152	.0162	.0133	.0152	
19	.0164	.0133	.0156	.016	.0164	.0152	
20	.0171	.0133	.0152	.016	.0171	.0152	
21	.0179	.0133	.0164	.016	.0171	.0152	
22	1.8728	1.8694	.0175	.0173	.0171	2.2832	1.086
23	1.921	1.9722	.0171	.0171	.0171	2.2421	2.0041
24	1.9646	1.9761	.8535	.0342	.0171	1.318	2.0347
Max	1.9646	1.9761	1.406	3.1764	2.9629	2.2832	2.1909
Min	.0135	.0133	.0133	.016	.0133	.0152	.2625
Avg	.8269	.7710	.7141	1.0191	.9351	.2575	1.8091

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 202 / 11 KV Kavathe Piran
 Village Feeder KV- 11 /
 OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7499	.7186	.3772	.7205	.6996	.7072	.7596
2	.7133	.7186	.3772	.7015	.6885	.6996	.7436
3	.7079	.7217	.3772	.7091	.6851	.6939	.7398
4	.7156	.7179	.3772	.7422	.6847	.6806	.7322
5	.7945	.8208	.3772	.8082	.7342	.7506	.7497
6	.9888	.9191	.5093	.9995	.9663	.9358	.9066
7	.8269	.934	.4527	.9203	.9404	.8371	.8562
8	.7453	.8154	.3018	.7449	.7832	.7019	.7335
9	.5669	.586	.2801	.6455	.6604	.6158	.3216
10	.5925	.5822	.2641	.5311	.5898	.5621	.3025
11	.6111	.5944	.3361	.5611	.5792	.6157	.3094
12	.5936	.5723	.3395	.5799	.6504	.6203	.2926
13	.6409	.6515	.3395	.6137	.6539	.5822	.301
14	.7141	.6432	.3361	.6577	.6272	.6127	.3437
15	.6912	.6249	.3361	.6561	.6486	.6172	.3513
16	.6211	.586	.3395	.6051	.6463	.6481	.3056
17	.6287	.6272	.3018	.691	.6097	.6481	.1829
18	.7436	.6546	.3361	.748	.5944	.6219	
19	.9884	.8115	.4527	.9687	.8725	.8261	.4138
20	1.0641	1.0345	.5281	1.1012	1.0753	1.0463	.6074
21	1.0786	1.0101	.4854	1.0692	1.0113	1.0345	.5883
22	.9911	1.036	.4904	.9638	.9473	1.0003	.5228
23	.9171	.9246	.4108	.9345	.9149	.8757	.894
24	.7689	.7872	.3772	.7678	.7677	.788	.8015
Max	1.0786	1.036	.5281	1.1012	1.0753	1.0463	.9066
Min	.5669	.5723	.2641	.5311	.5792	.5621	.1829
Avg	.7689	.7538	.3793	.7684	.7513	.7384	.5548

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 203 / 11 KV Kavathe Piran Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2916	2.2741	1.1145	.0114	.0091	.0114	1.0802
2	2.26	2.2138	1.1145	.0114	.009	.0114	1.0802
3	2.2325	2.162	1.1145	.0118	.0093	.0114	1.0802
4	2.223	2.149	1.1145	.0118	.0095	.0114	1.0802
5	2.1505	2.1483	1.1145	.0114	.0097	.0114	1.0802
6	2.2588	2.1818	1.0802	.012	.0099	.0107	.9945
7	2.1635	2.1198	1.0974	.0114	.0097	.0114	.9774
8	.0088	.0186	.0114	.0107	.0088	.0103	.0114
9	.0095	.0086	1.3889	1.3565	1.3226	.0088	
10	.0093	.0095	1.4419	1.3889	1.3717	.0095	
11	.0086	.0095	1.4403	1.4232	1.3717	.0095	
12	.0086	.0095	1.406	1.406	1.4746	.0095	
13	.0086	.0095	1.3748	1.3904	1.4083	.0095	
14	.0088	.0095	1.4403	1.358	1.4746	.0095	
15	.0088	.0095	1.406	1.3717	1.406	.0095	
16	.0088	.0095	1.3717	1.3546	1.3717	.0095	
17	.0093	.0114	.0088	.0128	.0095	.0114	
18	.0105	.0114	.0095	.013	.0088	.0114	
19	.0114	.0114	.0095	.0114	.0114	.0114	
20	.0112	.0114	.0095	.0114	.0114	.0114	
21	.0406	.0114	.0095	.0114	.0107	.0114	
22	2.2276	2.3696	.0118	.0088	.0114	1.1831	
23	2.2946	2.3605	.0114	.0095	.0114	1.1145	.9665
24	2.2664	2.3099	1.1145	.0114	.0093	.0107	1.0802
Max	2.2946	2.3696	1.4419	1.4232	1.4746	1.1831	1.0802
Min	.0086	.0086	.0088	.0088	.0088	.0088	.0114
Avg	.9388	.9350	.8423	.4680	.4733	.1054	.9431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 204 / 11 KV samdoli Village

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2481	.2454	.2641	.2534	.2378	.2012	.2263
2	.2427	.2481	.2641	.2507	.2402	.2012	.2263
3	.2401	.2401	.2641	.2534	.2378	.2058	.2263
4	.2427	.2454	.2641	.2481	.2353	.2204	.2263
5	.2401	.2454	.2641	.2629	.2303	.2401	.2263
6	.298	.2804	.2987	.3077	.2715	.2629	.2452
7	.2328	.2402	.2614	.2172	.2172	.2149	.1886
8	.197	.2172	.2054	.2195	.2172	.1991	.1698
9	.181	.2075	.1867	.1848	.1848	.2012	
10	.1829	.2054	.1991	.2218	.2195	.2012	
11	.1867	.2241	.2195	.2427	.2195	.2012	
12	.2218	.2241	.2378	.2378	.2353	.2012	
13	.2378	.2241	.2378	.2587	.2561	.2012	
14	.2481	.2241	.2534	.2534	.2378	.2012	
15	.2378	.2427	.2534	.2561	.2195	.2012	
16	.0185	.2614	.2172	.2454	.2195	.2195	
17	.2801	.2801	.2195	.2629	.1991	.2195	
18	.3142	.2987	.2587	.3045	.2218	.2378	
19	.3696	.3361	.3292	.3326	.3292	.3292	
20	.3544	.3547	.4066	.3292	.3982	.3734	
21	.3582	.3547	.3801	.3224	.3658	.3734	
22	.3258	.3734	.362	.3961	.3403	.3734	
23	.3012	.3206	.3224	.3174	.2743	.3018	.298
24	.2804	.2804	.2641	.2686	.2987	.2401	.2263
Max	.3696	.3734	.4066	.3961	.3982	.3734	.298
Min	.0185	.2054	.1867	.1848	.1848	.1991	.1698
Avg	.2517	.2656	.2681	.2686	.2544	.2426	.2259

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 205 / 11 KV Samdoli Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0189	.0189	.7167	.5658	.9054	.0189
2	.0189	.0189	.0189	.679	.5658	.9054	.0189
3	.0189	.0189	.0189	.6602	.5658	.9054	.0189
4	.0189	.0189	.0189	.6602	.5658	.9054	.0189
5	.0189	.0189	.0189	.6602	.5658	.8865	.0189
6	.0189	.0189	.0189	.679	.5658	.9054	.0189
7	.0189	.0189	.0189	.7167	.6224	1.0185	.0189
8	.0189	.0189	.0189	.0189	.0189	.0189	.0189
9	1.3957	1.4901	.0189	.0189	.0189	1.5655	
10	1.5089	1.6032	.0189	.0189	.0189	1.6032	
11	1.5655	1.6409	.0189	.0189	.0189	1.6032	
12	1.4901	1.4523	.0189	.0189	.0189	1.5655	
13	1.4146	1.3769	.0189	.0189	.0189	1.5089	
14	.0189	1.3203	.0189	.0189	.0189	1.5089	
15	.0189	1.2449	.0189	.0183	.0189	1.5089	
16	1.1317	1.226	.0189	.0189	.0189	1.4146	
17	.0189	.0189	.0189	.0189	.0189	.0189	
18	.0189	.0189	.0189	.0189	.0189	.0189	
19	.0189	.0189	.0189	.0189	.0189	.0189	
20	.0189	.0189	.0189	.0189	.0189	.0189	
21	.0189	.0189	.0189	.0189	.0189	.0189	
22	.0189	.0189	.811	.5847	.9431		
23	.0189	.0189	.7545	.5847	.9619	.0189	.0189
24	.0189	.0189	.0189	.7167	.5658	.9431	.0189
Max	1.5655	1.6409	.811	.7167	.9619	1.6032	.0189
Min	.0189	.0189	.0189	.0183	.0189	.0189	.0189
Avg	.3686	.4857	.0826	.2884	.2814	.8603	.0189

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 206 / 11 KV Shaurya Industries NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343	.0343	.0343	.0343	.0343
2	.0343	.0343	.0343	.0343	.0343	.0343	.0343
3	.0343	.0343	.0343	.0343	.0343	.0343	.0343
4	.0343	.0343	.0343	.0343	.0343	.0343	.0343
5	.0343	.0343	.0343	.0343	.0343	.0343	.0343
6	.0343	.0343	.0343	.0343	.0343	.0343	.0343
7	.0343	.0343	.0343	.0343	.0343	.0343	.0343
8	.0343	.0343	.0343	.0343	.0343	.0343	.0343
9	.0701	.0343	.0686	.0724	.0343	.0537	
10	.0686	.0686	.0724	.0739	.0724	.0514	
11	.0686	.0686	.0914	.0732	.0724	.0686	
12	.0686	.0686	.0914	.0686	.0724	.0686	
13	.0686	.0686	.0905	.0686	.0362	.0686	
14	.0857	.0686	.0905	.0686	.0914	.0686	
15	.0686	.0857	.0905	.0686	.0914	.0686	
16	.0686	.0857	.0343	.0514	.0724	.0686	
17	.0343	.0686	.0343	.0343	.0905	.0514	
18	.0343	.0686	.0343	.0343	.0343	.0514	
19	.0343	.0686	.0343	.0343	.0343	.0514	
20	.0343	.0514	.0343	.0343	.0343	.0343	
21	.0189	.0343	.0343	.0343	.0343	.0343	
22	.0343	.0343	.0343	.0343	.0343	.0189	
23	.0343	.0343	.0343	.0343	.0343	.0343	.0343
24	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Max	.0857	.0857	.0914	.0739	.0914	.0686	.0343
Min	.0189	.0343	.0343	.0343	.0343	.0189	.0343
Avg	.0459	.0507	.0491	.0456	.0478	.0459	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 201 / 11 KV Budhgaon Village

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.5801			.4915	.663		
6						.1475	
7			.5735	.4096	.7209		.7865
9	.7127		.5801		.6554		.5138
10			.5801				
11		.7537		.7865			
12	.6882		.7373		.5735		
13		.6226		.663			.431
14						.8192	
15	.6718		.7701		.4973		
16		.7459		.6962			
19				.9231	.9012		
20							.6718
21		.8288	.7865		.9503		
22				.9012			
23		.6554	.7209			.8192	
24	.5079		.6022	1.3516	.7537	.7537	.8192
Max	.7127	.8288	.7865	1.3516	.9503	.8192	.8192
Min	.5079	.6226	.5735	.4096	.4973	.1475	.431
Avg	.6321	.7213	.6688	.7778	.7144	.6349	.6445

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 202 / 11 KV Kaleran (Kavalpur) SEPARATED AG FEEDERS HAVING SPECIAL
 AG Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2492	.2583		1.6575	1.121	1.291	.2766
2	.2462	.2538		1.5813	1.1233	2.0843	.2568
3	.2462	.2515		1.5257	1.1058	.9983	.2561
4	.2477	.2401		1.4685	1.0959	1.028	.2561
5	.2984	.2522		2.7709	2.1087	1.044	.2583
6	.3003	.3079		1.656	1.2109	1.9585	.2797
7	.3163	.3406	.0663	3.3928	3.0931	1.278	.3597
8	.2705	.2888		.3201	.6203	.4679	.2492
9	4.322	2.5354	.0663	.2705	.2941	1.925	4.4721
10	2.6071	2.793	.0663	.2378	.237	2.1651	2.5888
11	2.46	4.8124		.2667	.2271	2.079	2.5934
12	4.2338	2.6315	.0332	.2195	.2027	2.0774	2.1171
13	2.4082	2.258		.3117	.2065	1.7779	
14	.9945	2.415		.2477	.2073	3.4499	
15	2.0386	2.3655	.0655	.2477	.288	2.1826	
16	1.6758	4.1316		.2854	.2218	2.1971	1.5653
17	.8947	.9777		.2263	.2233	.6531	.7987
18	.2637	.2507		.2561	.2126	.2279	.2629
19	.3132	.2355		.3668	.3296	.2797	.25
20	.365	.3346		.3353	.317	.3414	.4169
21	.3658	.4016		.2195	.381	.3391	.3384
22	.3475	.3353		2.2862	1.3009	.3376	.3109
23	.3307	.3963	1.3108	1.2369	1.4335	.4039	.3048
24	.3557	.301	.0663	2.505	2.3297	1.3005	.3353
Max	4.322	4.8124	1.3108	3.3928	3.0931	3.4499	4.4721
Min	.2462	.2355	.0332	.2195	.2027	.2279	.2492
Avg	1.0896	1.2237	.2392	.9955	.8288	1.3286	.8832

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 203 / 11 KV Bisur village

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2267	.2244		.2248	.2237	.2141	.2157
2	.2187	.2153		.2206	.2202	.3993	.21
3	.2107	.213		.2157	.2134	.2046	.2065
4	.2088	.2092		.2191	.2084	.4106	.2027
5	.354	.2168		.5095	.4142	.2107	.2149
6	.2591	.2656		.2843	.2328	.4487	.245
7	.2656	.2747	.1867	.463	.4573	.2667	.4481
8	.2256	.2382		.234	.234	.237	.2294
9	.3398	.1707	.1326	.1829	.3529	.1768	.3305
10	.1459	.1635	.112	.1608	.173	.1383	.1616
11	.141	.2698		.2961	.1619	.1311	.1429
12	.2698	.16	.1494	.1562	.2987	.1471	.1322
13	.1673	.3125		.2854	.1787	.1505	.2943
14	.2119	.1776		.1806	.1859	.2947	.1509
15	.2881	.1715	.1307	.1913	.3369	.1715	.1722
16	.192	.3178		.2809	.1989	.168	.1734
17	.1566	.1635		.1848	.366	.1635	.1597
18	.1738	.165		.1699	.189	.1692	.1654
19	.2237	.2309		.5095	.4593	.2229	.192
20	.3121	.322		.317	.3227	.3372	.5674
21	.3064	.5159	.2801	.2286	.58	.3083	.2919
22	.3056	.3185		.5727	.2923	.3052	.29
23	.2877	.5137	.2801	.2884	.2808	.5614	.2915
24	.4016	.2393	.2263	.4653	.4401	.4453	.5298
Max	.4016	.5159	.2801	.5727	.58	.5614	.5674
Min	.141	.16	.112	.1562	.1619	.1311	.1322
Avg	.2455	.2529	.1872	.2851	.2925	.2618	.2508

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 204 / 11 KV Budhgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2						.0497	
5	.3481			.0655	.0492		
6						.0332	
7			.4144	.0655	.0492		.0131
9	.0492		.5801		.6316		.0492
10			.5801				
11		.0324		.7293			
12	.0492		.6299		.6554		
13		.0324		.663			.0492
14						.0497	
15			.5506		.5304		
16		.0328		.5967			
19				.0648	.0497		
20							.0497
21		.0328	.0648		.0663		
22				.0492			
23		.3277	.0648				
24	.4144		.3315	.0648	.0486	.4144	.3277
Max	.4144	.3277	.6299	.7293	.6554	.4144	.3277
Min	.0492	.0324	.0648	.0492	.0486	.0332	.0131
Avg	.2152	.0916	.4020	.2874	.2601	.1368	.0978

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 205 / 11 KV Express college
feeder Feeder KV- 11 /
OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2						.2033	
4						.1478	
5	.0943			.1463	.1698		
6						.1478	
7			.1372	.112	.1698		.132
9	.1132		.1307		.1886		.0934
10			.1372				
11		.1509		.168			
12	.0943		.1494		.1494		
13		.1698		.0747			.0934
14						.1294	
15			.2229		.1109		
16		.1509		.1307			
19				.0943	.0739		
20							.0934
21		.1132	.2572		.0924		
22				.1886			
23		.0934	.1372			.0943	
24	.112		.0857	.1372	.1698	.1663	.1867
Max	.1132	.1698	.2572	.1886	.1886	.2033	.1867
Min	.0943	.0934	.0857	.0747	.0739	.0943	.0934
Avg	.1035	.1356	.1572	.1315	.1406	.1482	.1198

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 207 / 11 KV Jyptirling LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2						.1109
5	.0943			.0686	.0943	
6						.0924
7			.0663	.0747	.0189	
9	.1132		.132		.0754	
10			.0943			
11		.0754		.1132		
12			.0934		.0754	
13		.132		.0943		
14						.0754
15	.1132		.0934		.0739	
16		.0934		.0943		
21			.0655			
24	.1132		.0566	.0754		
Max	.1132	.132	.132	.1132	.0943	.1109
Min	.0943	.0754	.0566	.0686	.0189	.0754
Avg	.1085	.1003	.0859	.0868	.0676	.0929

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 208 / 11 KV Bisur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0137	.0823		.8421	.5205	.628	.0914
2		.0808		.7773	.49	1.0875	.0907
3	.0008	.0815		.7644	.4915	.5914	.0907
4	.08	.0861		.7369	.4954	1.0425	.0975
5	.1318	.0937		1.5912	.8787	.5799	.1052
6	.1265	.1135		.8192	.5517	1.1934	.128
7	.128	.1364	.0579	.9396	1.1957	.6523	.1798
8	.1608	.5784		.0975	.1235	.3978	.378
9	2.2975	1.2071	.0724	.1448	.2046	.9915	1.9952
10	1.2864	1.2948	.0724	.112	.1097	.9777	1.118
11	1.2925	2.4821		.1799	.0884	1.057	1.1325
12	1.6289	.4252	.0579	.1006	.1227	1.086	.1738
13	1.1401	1.8168		.1456	.0472	1.0715	
14	.6546	1.2513		.0861	.0594	1.9083	
15	1.1043	1.1965	.0743	.0854	.1288	1.0532	
16	.6226	2.1418		.1433	.0899	1.028	.4321
17	.0838	.1326		.0053	.1075	.0754	.0975
18	.0594	.1463		.093	.1257	.1097	.0998
19		.1494		.1863	.2073	.1227	.1166
20		.0937		.1044	.0975	.1265	.1662
21		.144	.0743	.3437	.3506	.1036	.1059
22	.0914	.0937		.5617	.647	.1021	.1021
23	.0884	.1486	.743	.5662	.6935	.1577	.0914
24	.1288	.0846	.0579	1.4273	1.1018	.599	.1659
Max	2.2975	2.4821	.743	1.5912	1.1957	1.9083	1.9952
Min	.0008	.0808	.0579	.0053	.0472	.0754	.0907
Avg	.5560	.5859	.1513	.4522	.3720	.6976	.3313

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244088 / 33/11 kV Dudhgaon S/Stn

Feeder No / Name : 201 / 11 kV Dudhgaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3547	.381	.3429	.4382	.4382	.362	.381
2	.3547	.362	.3429	.4191	.4572	.362	.362
3	.3547	.362	.362	.381	.4572	.3429	.362
4	.3547	.381	.4001	.381	.381	.381	.381
5	.3734	.381	.4191	.4001	.381	.4001	.362
6	.4294	.381	.4572	.4191	.4001	.4382	.3429
7	.4108	.381	.4024	.362	.362	.3429	.3429
8	.3174	.3239	.3224	.362	.3429	.3429	
9	.2987	.3142	.3439	.3239	.3429	.439	
10	.3547	.3801	.3292	.3429	.3292	.4207	
11	.3511	.394	.3475	.3239	.3142	.4207	
12	.3511	.4251	.3439	.4001	.3258	.439	
13	.3511	.4163	.362	.4001	.3366	.4024	
14	.439	.4075	.4163	.381	.3467	.4572	
15	.4525	.4382	.3841	.381	.3761	.4163	
16	.3982	.4287	.3658	.362	.3506	.3982	
17	.4344	.4207	.4163	.362	.3721	.5304	
18	.4525	.4961	.4656	.462	.4119	.4207	
19	.6036	.5194		.5792	.4706	.6335	
20	.5121	.5609	.6447	.591	.5175	.5973	
21	.4572	.463	.5792	.5068	.5121	.4572	
22	.4251	.4252	.5525	.5068	.4656	.4435	
23	.4066	.4024	.4954	.5144	.4024	.3881	
24	.3734	.381		.9716	.4763	.4001	.381
Max	.6036	.5609	.6447	.9716	.5175	.6335	.381
Min	.2987	.3142	.3224	.3239	.3142	.3429	.3429
Avg	.4005	.4094	.4134	.4405	.3988	.4265	.3644

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244088 / 33/11 kV Dudhgaon S/Stn

Feeder No / Name : 202 / 11 kV Sawalwadi Ag

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0381	.6481	.5944	.8002	.0381
2	.0381	.0381	.0381	.6481	.5647	.7748	.0381
3	.0381	.0381	.0191	.6097	.5418	.7748	.0381
4	.0381	.0381	.0191	.6097	.5487	.8002	.0381
5	.0381	.0381	.0381	.5944	.5182	.7935	.0381
6	.0381	.0381	.0381	.5944	.5247	.7748	.0381
7	.0381	.0381	.0381	.6327	.5155	.8482	.0381
8	.0381	.0381	.0381	.0191	.0381	.0381	.0381
9	1.1012	1.0279	.0191	.0381	.0381	1.0494	
10	1.1012	1.0322	.0191	.0381	.0381	1.1498	
11	1.1336	.9804	.0191	.0381	.0381	1.1498	
12	1.0364	.945	.0191	.0191	.0381	1.166	
13	.9878	.8905	.0191	.0381	.0381	1.1336	
14		.8697	.0191	.0191	.0381	1.0883	
15		.8381	.0191	.0381	.0381	1.0562	
16	.8488	.7468	.0191	.0381	.0191	1.0082	
17	.0191	.0191	.0191	.0381	.0191	.0381	
18	.0191	.0191	.0381	.0381	.0191	.0381	
19	.0191	.0191	.0381	.0381	.0191	.0381	
20	.0191	.0191	.0381	.0381	.0191	.0381	
21	.0191	.0191	.0381	.0381	.0191	.0381	
22	.0381	.0381	.6249	.6249	.7362	.0381	
23	.0381	.0381	.6481	.6249	.7748	.0381	
24	.0381	.0191		.6481	.5944	.7935	.0381
Max	1.1336	1.0322	.6481	.6481	.7748	1.166	.0381
Min	.0191	.0191	.0191	.0191	.0191	.0381	.0381
Avg	.3056	.3261	.0810	.2796	.2639	.6444	.0381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244088 / 33/11 kV Dudhgaon S/Stn

Feeder No / Name : 203 / 11 kV Dharan Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9448	.9221	.9175	.5761	.4481	.4858	1.0059
2	.8192	.8718	.9282	.5761	.4481	.4915	.9779
3	.8192	.8288	.9221	.5601	.4428	.4696	.9779
4	.8029	.8029	.9175	.5376	.4744	.4641	.9282
5	.8122	.8029	.9282	.5376	.4744	.4641	.852
6	.7935	.7537	.9221	.5441	.4801	.4534	.852
7	.7682	.7373	.9779	.5668	.4961	.5079	.8356
8	.0381	.0191	.0191	.0191	.0191	.0191	.0191
9	.6802	.7362	1.1736	1.1568	1.1797	.7274	
10	.7125	.7865	1.1869	1.2452	1.2407	.7865	
11	.7287		1.2378	1.2308	1.1105	.7537	
12	.6964	.7773	1.2071	1.2452	1.1305	.7045	
13	.6478	.759	1.2209	1.1984	1.1768	.7209	
14		.7362	1.1736	1.1961	1.1012	.7373	
15		.7116	1.1271	1.2125	.5801	.6226	
16	.6958	.6882	1.0322	1.2125	.9878	.6226	
17	.0381	.0191	.0191	.0381	.0191	.0381	
18	.0381	.0191	.0381	.0381	.0191	.0381	
19	.0381	.0381	.0381	.0381	.0381	.0381	
20	.0381	.0381	.0381	.0381	.0381	.0381	
21	.0381	.0381	.0381	.0381	.0381	.0381	
22	.8785	.8453	.5601	.4161	.4801	1.1022	
23	.8619	1.0004	.5761	.4858		1.0852	
24	.9282	.9556		.5761	.4973		1.0059
Max	.9448	1.0004	1.2378	1.2452	1.2407	1.1022	1.0059
Min	.0381	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.5827	.6038	.7478	.6368	.5618	.4960	.8283

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244088 / 33/11 kV Dudhgaon S/Stn

Feeder No / Name : 205 / 11 KV A1 PPS Express

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4854	.4854	.4481	.4108	.4527	.4527
2	.4668	.4904	.4715	.4108	.4527	.4668
3	.4668	.4904	.462	.4481	.4904	.4715
4	.4668	.4904	.4527	.4854	.5658	.4435
5	.4715	.5601	.4668	.5601	.4904	.4715
6	.4715	.6348	.4715	.6348	.6413	.4715
7	.4572	.6722	.5121	.6348	.5975	.6161
8	.4938	.6413	.6535	.6722	.6908	.6584
9	.6722	.6161	.6535	.6099	.6908	.6468
10	.679	.6224	.5729	.6767	.7282	.7095
11	.679		.6468	.6535	.7468	.6908
12	.6535	.5975	.6468	.6535	.7392	.6979
13	.7468	.4805	.6335	.6722	.7468	.6979
14	.6602		.6516	.6535	.7468	.6979
15	.6413	.6219	.6584	.6535	.7468	.7167
16	.6602	.6348	.6584	.6535	.7545	.7167
Max	.7468	.6722	.6584	.6767	.7545	.7167
Min	.4572	.4805	.4481	.4108	.4527	.4435
Avg	.5733	.5742	.5663	.5927	.6426	.6016

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244090 / 33/11KV Nandre S/Stn

Feeder No / Name : 201 / 11 KV Nandre Village

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8488	1.0185	.9431	1.0185	.9619	.9808	.9997
2	.8488	.9709	.9054	.9431	.9431	.9431	.9619
3	.8488	.8573	.8676	.9431	.9054	.9431	.9619
4	.8488	.9619	.8871	.9431	.9054	.9619	.8865
5	.9431	.9896	.9997	.9511	1.0082	1.0185	.8865
6	1.1643	1.1458	1.1643	.9795	1.1389	1.0751	1.0829
7	.8775	.9774	.9231	.9694	.9055	.9242	.9431
8	.7164	.8682	.8131	.823	.8779	.8215	.8596
9	.7499	.815	.8063	.8131	.7973	.8328	.8962
10	.7712		.8596	.8059		.7783	.823
11	.815		.8326	.8669	.8688	.8145	
12	.8507	.0189	.9231	.9774	.9134		
13	.8954		.9313	.8589	.8145	.8131	
14	.9214	1.2254	.8954	.8842	.8596	.8501	.6468
15	1.0099	1.1283	.8688	.8682	.8413	.8779	
16	.5487	1.0425	.8688	.8238	.8326	.7783	
17	.9134	1.0349	.8413	.8145	.8417	.7202	
18	.8059	.9412	.8413	.823	.8402	.7619	
19	1.1163	1.1888	1.1458	1.1458	1.1517	1.0745	
20	1.2851	1.3676	1.3306	1.2936	1.2308	1.262	
21	1.262	1.3392	1.3121		1.2536	1.2382	
22	1.2012	1.3014	1.2696	.5601	1.2127	1.2449	
23		1.1317	1.1128	.6979	1.0387	1.1317	
24	.9808	.9997	1.0185	2.1124	.6099	.9896	1.0374
Max	1.2851	1.3676	1.3306	2.1124	1.2536	1.262	1.0829
Min	.5487	.0189	.8063	.5601	.6099	.7202	.6468
Avg	.9228	1.0154	.9734	.9529	.9458	.9494	.9155

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244090 / 33/11KV Nandre S/Stn

Feeder No / Name : 202 / 11 kV Nandre Ag

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0566	.4458	.3161	.333	.0377
2	.0566	.0566	.0566	.4344	.3241	.3418	.0377
3	.0566	.0566	.0566	.4401	.3121	.3418	.0377
4	.0566		.0566	.463	.3081	.3286	.0377
5	.0754	.0566	.0754	.4515	.3041	.333	.0566
6	.0754	.0754	.0754	.4572	.3241	.3429	.0377
7		.0943	.0754	.463	.3269	.3243	.0566
8	.0754	.0566	.0566	.0566	.0377	.0566	.0566
9	.5792	.6401	.0549	.0566	.0566	.5007	.5268
10	.4988	.6081	.0566	.0566		.4858	.571
11	.5937	.6327	.0566	.0566	.0566	.5428	.5498
12	.5716	.5944	.0943	.0566	.0754		
13			.0943	.0566	.0754	.543	
14	.5068	.5575	.0754	.0754	.0754	.5428	
15		.5796	.0754	.0566	.0754	.5213	
16	.5201	.587	.0566	.0566	.0754	.5001	
17	.0943	.0566	.0566	.0566	.0754	.0549	
18	.0754	.0754	.0754	.0566	.0754	.0566	
19	.0566	.0566	.0377	.0566	.0566	.0566	
20	.0754	.0566	.0377	.0754	.0566	.0566	
21	.0566	.0566	.0377		.0754	.0754	
22	.0566	.0754	.431	.3185	.3311	.0566	
23		.0566	.4401	.3121	.3418	.0377	
24	.0566	.0543	.0566	.8802	.3144	.3612	.0377
Max	.5937	.6401	.4401	.8802	.3418	.543	.571
Min	.0566	.0543	.0377	.0566	.0377	.0377	.0377
Avg	.2097	.2336	.0936	.2365	.1770	.2954	.1703

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244090 / 33/11KV Nandre S/Stn

Feeder No / Name : 203 / 11 KV Malbhag Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.2641	.2641	.0377	.0566	.0566	.2641
2	.3018	.2641	.2641	.0377	.0566	.0566	.2452
3	.2829	.2641	.2452	.0377	.0566	.0566	.2075
4	.2829	.2641	.2452	.0377	.0566	.0566	.2075
5	.2641	.2829	.2452	.0377	.0566	.0566	.2263
6	.2641		.2452	.0377	.0566	.0566	.2075
7	.2829	.3395	.2829	.0377	.0566	.0754	.2452
8	.0566	.0754	.0566	.0566	.0566	.0754	.0566
9	.0566	.132	.4527	.5093	.4338	.0754	.0754
10	.0754	.132	.4527	.5658		.1132	.0943
11	.1132	.132	.4715	.5658	.5281	.132	.0943
12	.1132	.132	.5093	.4904	.4904	.132	.0943
13		.132	.4904	.4715	.4338	.0943	.0566
14	.0754	.1132	.4715	.4527	.4338	.0943	.0754
15		.1132	.4527	.4338	.3961	.0943	
16	.0754	.132	.4527	.4338	.3395	.0943	
17	.0943	.0943	.1132	.0943	.0943	.0754	
18	.1132	.0943	.0943	.1132	.0943	.0943	
19	.0943	.0377	.0943	.0754	.0566	.0377	
20	.0754	.0377	.0754	.0566	.0377	.0377	
21	.0566	.0377	.0754	.0566	.0566	.0377	
22	.3206	.2452	.0566	.0566	.0566	.2641	
23		.2829	.0377	.0566	.0566	.3206	
24	.3395	.2829	.2641	.0377	.0566	.0566	.2829
Max	.3395	.3395	.5093	.5658	.5281	.3206	.2829
Min	.0566	.0377	.0377	.0377	.0377	.0377	.0566
Avg	.1733	.1689	.2672	.1996	.1747	.0935	.1622

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 246001 / 110/33/11 KV VISHRAMBAG S/SN

Feeder No / Name : 206 / 11 KV DATNAGAR

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8954	.865	.9069	.8459	.8497	.8383
2	.8307	.7926	.8307	.7811	.7888	.7735
3	.7811	.7621	.7888	.743	.7392	.724
4	.7506	.7278	.7697	.7125	.7087	.7049
5	.7278	.7049	.7392	.6821	.6783	.6821
6	.7354	.7545	.7392	.6973	.7049	.7049
7	.7849	.7964	.7583	.6859	.7202	.7049
8	.7926	.7583	.7506	.6897	.7087	.743
9	.6516	.644	.6325	.644	.602	.602
10	.6097	.602	.5677	.6135	.5563	.5754
11	.5792	.583	.5487	.5639	.5563	.5335
12	.5716	.5639	.5563	.5792	.5639	.5411
13	.5677	.5982	.5716	.5792	.5411	.5563
14	.5944	.6287	.6173	.5906	.583	.5677
15	.5906	.6401	.6173	.6287	.5868	.5639
16	.6097	.6249	.6287	.6363	.602	.583
17	.6135	.6478	.6211	.6325	.6249	.6097
18	.6249	.6554	.6401	.6173	.6173	.6059
19	.7735	.7697	.7583	.7316	.7278	.6706
20	.9526	.9297	.884	.884	.8993	.8421
21	.9526	.9335	.865	.884	.9297	.8573
22	.9412	.9145	.8612	.8993	.9107	.8688
23	.9717	.9412	.8802	.9259	.9297	.9069
24	.9526	.9297	1.2544	.8993	.9297	.8878
Max	.9717	.9412	1.2544	.9259	.9297	.9069
Min	.5677	.5639	.5487	.5639	.5411	.5335
Avg	.7440	.7403	.7412	.7145	.7108	.6937

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 246001 / 110/33/11 KV VISHRAMBAG S/SN

Feeder No / Name : 210 / 11 KV Dhamni

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17
HR	Load (MW)
1	1.3306
2	1.2936
3	1.2567
4	1.2696
5	1.2936
6	1.3717
7	1.3717
8	1.3169
9	1.4998
10	1.5364
11	1.4632
12	1.9204
13	1.7558
14	1.7193
15	1.6827
16	1.6461
17	1.6289
18	1.6651
19	1.6289
20	1.3611
21	1.3253
22	1.3253
23	1.3432
24	1.4784
Max	1.9204
Min	1.2567
Avg	1.4785

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 246001 / 110/33/11 KV VISHRAMBAG S/SN

Feeder No / Name : 401 / 33KV KASABE DIGRAJ

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-APR-17
HR	Load (MW)
1	7.9818
2	7.9012
3	7.7103
4	7.7103
5	7.9012
6	8.3402
7	8.6877
8	4.7239
9	10.0995
10	10.631
12	9.4616
13	10.0463
14	9.7805
15	9.8337
16	8.9723
17	2.0416
24	6.0357
Max	10.631
Min	2.0416
Avg	8.1093

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 246001 / 110/33/11 KV VISHRAMBAG S/SN

Feeder No / Name : 404 / 33 KV MADHAVNAGAR(EHV)

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / INCOMING

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	23.2854	***	***	29.6983	***	27.8121
2	23.3197	***	***	29.2868	29.8011	26.3376
3	22.668	29.3896	***	28.7037	28.9094	25.2058
4	22.1194	28.8066	***	28.155	28.258	24.7942
5	21.5707	28.498	***	27.5035	27.6749	24.2799
6	22.4623	29.2867	***	27.7436	29.1838	23.9713
7	21.7764	29.5611	***	28.0521	29.561	23.594
8	20.9534	27.1606	29.424	27.0577	28.3265	22.0851
9	24.8628	***	***	***	***	20.0617
10	26.3718	***	***	***	***	19.7188
11	29.6297	***	***	***	***	14.9178
12	***	***	***	***	***	13.546
13	***	***	***	***	***	14.7119
14	***	***	***	***	***	13.2031
15	***	***	***	***	***	19.7188
16	***	***	***	***	***	20.5762
17	25.7201	***	***	***	***	20.7477
18	***	29.1838	***	***	***	21.3306
19	***	29.6982	***	29.4582	***	25.1372
20	***	***	***	***	***	29.1839
21	***	***	21.9479	***	***	28.9438
22	***	***	26.9204	***	***	28.7723
23	***	***	29.0467	***	***	29.1153
24	***	***	29.1496	29.7668	***	27.915
Max	35.6996	37.8601	41.461	38.7861	40.9809	29.1839
Min	20.9534	27.1606	21.9479	27.0577	27.6749	13.2031
Avg	28.2265	31.9845	33.5134	31.6073	33.2419	22.7367

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 246001 / 110/33/11 KV VISHRAMBAG S/SN

Feeder No / Name : 405 / 33KV SANGLI CITY -NEW

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / INCOMING

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	***	***	***	***	***
2	***	***	***	***	***	***
3	***	***	***	***	***	***
4	***	***	***	***	***	***
5	***	***	***	***	***	***
6	***	***	***	***	***	***
7	***	***	***	***	***	***
8	***	***	***	***	***	***
9	***	***	***	***	***	***
10	***	***	***	***	***	***
11	***	***	***	***	***	***
12	***	***	***	***	***	***
13	***	***	***	***	***	***
14	***	***	***	***	***	***
15	***	***	***	***	***	***
16	***	***	***	***	***	***
17	***	***	***	***	***	***
18	***	***	***	***	***	***
19	***	***	***	***	***	***
20	***	***	***	***	***	***
21	***	***	***	***	***	***
22	***	***	***	***	***	***
23	***	***	***	***	***	***
24	***	***	***	***	***	***
Max	65.3979	65.7752	65.4322	58.8821	63.306	59.4994
Min	37.8944	38.1345	38.8203	36.6256	37.4829	35.8025
Avg	48.8927	49.7743	48.9070	45.7348	47.3437	44.6160

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 203 / 11 KV WATER WORKS
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3887	.3986	.3856	.3856	.3887	.3887
2	.3917	.4001	.3909	.3917	.3879	.3925
3	.3788	.3993	.3887	.3925	.3871	.3536
4	.3567	.3978	.3871	.3909	.3574	.3536
5	.3612	.397	.3536	.3559	.3574	.3528
6	.3589	.3978	.3597	.3574	.362	.3574
7	.3628	.3681	.362	.3605	.3643	.3567
8	.3818	.3262	.378	.3833	.3841	.3894
9	.3894	.3955	.3849	.3955	.4016	.4039
10	.346	.4047	.3986	.3727	.4039	.3978
11		.4024	.4024	.3483	.3948	.397
12	.0267	.4077	.4024	.397	.3948	.3871
13	.3765	.3818	.3894	.3871	.3849	.3795
14	.3742	.3719	.3871	.3818	.3673	.3788
15	.3856	.3856	.3879	.3856	.3757	.3772
16	.381	.3902	.3871	.3856	.3795	.3849
17	.3871	.3864	.2614	.3765	.3742	.3849
18	.3826	.378	.3742	.3772	.381	.3788
19	.3879	.3887	.3871	.378	.3818	.3871
20	.3925	.394	.3909	.3871	.3879	.3955
21	.3871	.3909	.3597	.3833	.3864	.3909
22	.4062	.4092	.0282	.3955	.3909	.4001
23	.4024	.4085	.4024	.3963	.3894	.3643
24	.3917	.4047	.3894	.3955	.3871	.3978
Max	.4062	.4092	.4024	.397	.4039	.4039
Min	.0267	.3262	.0282	.3483	.3574	.3528
Avg	.3651	.3910	.3641	.3817	.3821	.3813

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 205 / SANGLI COLLEGE CORNER
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4327	1.4777	1.5554	1.3938	1.3725	1.3458
2	1.2902	1.3527	1.4159	1.2742	1.2605	1.2216
3	1.233	1.2788	1.3298	1.2026	1.1835	1.1454
4	1.1797	1.2056	1.2864	1.1538	1.1203	1.1073
5	1.1431	1.166	1.2384	1.1271	1.0959	1.0738
6	1.102	1.1782	1.2277	1.089	1.0639	1.044
7	1.105	1.1454	1.2315	1.0989	1.0745	1.0684
8	.9938	1.0204	1.0669	.961	.9671	.9526
9	.8893	.9297	.9404	.9099	.8619	.8627
10	.9244	1.0776	1.0966	1.0059	.9587	.8566
11	1.1454	1.1378	1.1759	1.0402	1.0707	
12	1.1911	1.1416	1.1431	1.0501	1.1256	
13	.9938	1.1096	1.134	1.0364	1.1195	
14	.9267	1.0837	1.1416	.9717	1.0677	
15	1.2483	1.1736	1.2483	1.0776	1.1721	
16	1.275	1.214	1.2727	1.1294	1.2384	
17	1.2536	1.2033	1.2361	1.1035	1.1904	
18	1.1797	1.1363	1.1546	1.041	1.1759	.1357
19	1.249	1.2224	1.2932	1.0753	1.198	1.5463
20	1.515	1.4937	1.4594	1.3001	1.454	1.6575
21	1.4922	1.5051	1.3321	1.3161	1.4114	1.6019
22	1.5287	1.4853	1.3535	1.3817	1.435	1.5966
23	1.6209	1.5234	1.4091	1.467	1.4868	1.6621
24	1.5722	1.5463	1.454	1.4678	1.4868	1.6171
Max	1.6209	1.5463	1.5554	1.4678	1.4868	1.6621
Min	.8893	.9297	.9404	.9099	.8619	.1357
Avg	1.2285	1.2420	1.2582	1.1531	1.1913	1.2056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244080 / 33/11KV RISALA ROAD

Feeder No / Name : 201 / 11KV GYMKHANA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6172	1.6825	.823	1.7239	1.656	.8391	1.5368
2	1.5562	1.6095	.7682	1.6069	1.5653	.7857	1.4373
3	1.5143	1.5352	.7682	1.5303	1.5272	1.4415	1.419
4	1.4514	1.5139	.7316	1.5097	1.4754	1.4141	1.3793
5	1.4756	1.5312	.7316	1.5524	1.451	1.4442	1.3485
6	1.5461	1.5884	.7316	1.6256	1.5006	1.5044	1.3537
7	1.6349	1.576	.7522	1.56	1.4442	1.5059	1.4099
8	1.553	1.4931	.7164	1.4578	1.4251	1.4205	1.4243
9	1.5051	1.4929	.7783	1.4052	1.4596	1.4647	1.4136
10	1.7328	1.6537	.8688	1.5855	1.5528	1.6541	1.5158
11	1.9738	1.9525	.9774	1.8869	1.6644	1.7517	1.6629
12	2.0051	2.0428	1.0136	2.0912	1.8039	1.9386	1.579
13	2.0751	2.2222	1.0498	2.0256	1.7566	1.8789	.9092
14	1.9951	2.0976	.9774	2.015	1.7223	1.8965	.8848
15	1.8846	2.095	.9774	2.015	1.8084	1.9637	.9069
16	2.1041	2.1019	.9955	2.0556	1.7067	2.0011	.9412
17	2.0195	2.0969	1.0136	2.0664	.9015	1.9394	.9617
18	2.1125	2.1475	1.0387	2.1483	1.7173	1.8998	.9579
19	2.5933	2.6772	1.2894	2.67	2.1727	2.3624	1.1218
20	2.7206	2.6242	1.3321	1.4457	2.3015	2.5941	1.3024
21	2.5477	1.4129	1.2894	2.6006	2.2558	2.4974	1.2658
22	2.3091	2.2339	1.1584	2.2077	2.0611	2.1346	1.1385
23	2.087	1.9692	1.0136	2.0256	1.8923	1.9856	1.0227
24	1.8995	1.842	.823	1.8328	1.7932	.9595	1.6499
Max	2.7206	2.6772	1.3321	2.67	2.3015	2.5941	1.6629
Min	1.4514	1.4129	.7164	1.4052	.9015	.7857	.8848
Avg	1.9131	1.8830	.9425	1.8602	1.6923	1.7199	1.2726

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244080 / 33/11KV RISALA ROAD

Feeder No / Name : 202 / 11KV RAJWADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3236	2.4879	.8417	2.6669	2.4997	2.7363	2.6711
2	2.191	2.3933	.8059	2.6962	2.4597	2.6314	2.5107
3	2.1291	2.3497	.8238	2.6798	2.3609	2.5427	2.4955
4	2.0802	2.3371	.8059	2.6299	2.3522	2.4923	2.3009
5	2.0984	2.3307	.788	2.6799	2.3137	2.4527	2.284
6	2.1796	2.3369	.8059	2.7206	2.4413	2.5073	1.9738
7	2.1234	2.258	.7716	2.558	2.532	2.6532	1.7231
8	2.0191	2.1878	.6859	2.5499	2.3704	2.6516	1.5684
9	2.3739	2.2253	.7783	2.604	2.5332	2.7893	1.5177
10	2.6879	2.5221	.9231	2.8966	2.6269	3.0913	1.5524
11	2.9089	3.0255	.9593	3.4165	2.7178	3.4179	1.8566
12	3.065	3.1671	1.1946	3.5273	2.7552	3.5801	2.0576
13	3.2198	3.2259	1.1222	3.5504	2.7982	3.5769	1.464
14	3.142	3.2193	1.0317	3.6723	2.9119	3.6036	1.4056
15	3.0432	3.155	1.086	3.5845	2.9091	3.5414	1.4129
16	3.0263	3.1044	1.1765	3.5383	2.9006	3.7071	1.4453
17	2.8315	3.1135	.9922	3.5319	2.0347	3.6292	1.4605
18	2.8544	3.0826	1.0288	3.4461	2.966	3.528	1.4331
19	3.2057	3.554	1.2483	3.8935	3.0872	3.682	1.5851
20	3.4575	3.7715	1.2483	2.8072	3.4332	3.9757	1.8549
21	3.2476	2.6002	1.0745	2.0491	3.3415	3.7662	1.991
22	2.8955	3.2718	1.0498	2.3518	3.1192	3.3661	1.8473
23	2.7797	3.1017	1.0029	2.6932	2.9996	3.0665	1.7814
24	2.5859	2.8057	.8596	2.8125	2.7911	2.7614	1.7093
Max	3.4575	3.7715	1.2483	3.8935	3.4332	3.9757	2.6711
Min	2.0191	2.1878	.6859	2.0491	2.0347	2.4527	1.4056
Avg	2.6862	2.8178	.9627	2.9815	2.7190	3.1563	1.8293

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244080 / 33/11KV RISALA ROAD

Feeder No / Name : 203 / 11KV VAKHARBAG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.479	1.5779	.7392	1.5249	1.4811	1.4845	1.47
2	1.3763	1.4373	.7023	1.3641	1.3946	1.3801	1.3672
3	1.3451	1.3805	.7023	1.3496	1.304	1.3005	1.3527
4	1.3247	1.3895	.7095	1.3248	1.3005	1.243	1.289
5	1.3306	1.3946	.6722	1.3382	1.2453	1.2239	1.2262
6	1.351	1.3365	.6722	1.3798	1.2437	1.262	1.246
7	1.4202	1.3687	.7164	1.3847	1.2573	1.3169	1.2866
8	1.375	1.3409	.6878	1.4312	1.2544	1.2902	1.2155
9	1.3725	1.4289	.6878	1.4003	1.2973	1.3424	1.2319
10	1.5288	1.5096	.7964	1.4568	1.4426	1.6125	1.454
11	1.9894	2.0439	.9955	2.0744	1.7273	2.0376	1.8641
12	2.364	2.3217	1.2127	2.4927	2.1009	2.3505	2.2505
13	2.2877	2.3335	1.086	2.308	2.164	2.2611	1.1713
14	2.345	2.4173	1.0136	2.3098	2.0687	2.1693	1.1485
15	2.2985	2.4299	1.1403	2.2218	2.0777	2.1506	1.1606
16	2.3327	2.3396	1.1584	2.4672	2.0249	2.2023	1.2132
17	2.4577	2.3473	1.1088	2.3751	1.0669	2.2863	1.2026
18	2.4593	2.4185	1.1706	2.3659	2.058	2.2381	1.1568
19	2.5339	2.5888	1.3169	2.7125	2.4612	2.481	1.1591
20	2.7389	2.582	1.2308	1.4449	2.4855	2.5949	1.3222
21	2.5316	1.4403	1.1827	2.5844	2.4911	2.4459	1.3161
22	2.1765	2.1528	1.1088	2.1765	2.1658	2.1879	1.1797
23	1.8907	1.8705	.961	1.8062	1.768	1.8383	.9496
24	1.8363	1.6859	.7392	1.7699	1.6065	1.6248	1.6095
Max	2.7389	2.5888	1.3169	2.7125	2.4911	2.5949	2.2505
Min	1.3247	1.3365	.6722	1.3248	1.0669	1.2239	.9496
Avg	1.9227	1.8807	.9380	1.8777	1.7286	1.8469	1.3268

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244122 / 33/11 KV BALAJI MANDIR

Feeder No / Name : 201 / 11 KV Balaji Mill Road

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6838	.7095	.7468	.7842	.7545	.7023	.6653
2	.6767	.6908	.7282	.7468	.7167	.6838	.6535
3	.6401	.6468	.6908	.7468	.7167	.6767	.6348
4	.6468	.6283	.6908	.7468	.6908	.695	.6348
5	.6348	.6348	.6908	.7167	.6535	.6838	.6348
6	.6099	.6602	.7095	.6602	.6468	.7023	.6535
7	.5914	.5544	.6161	.5975	.5544	.5975	.6036
8	.3887	.4938	.4458	.4835	.5487	.6283	.5249
9	.4694	.5121	.463	.5853	.5487	.7282	.543
10	.6348	.5028	.6653	.7922	.7023	.7468	.5847
11	.7392	.6468	.8488	.8299	.8299	.7545	.6335
12	.7922	.7655	.7733	.8676	.9808	.8299	
13	.7922	.7167	.811	.8299	.9054	.8488	
14	.7733	.8299	.8299	.8299	.9808	.8676	
15	.7733	.8299	.9054	.8865	.9054	.7655	
16	.7842	.8676	.9242	.8865	.8676	.8299	
17	.7167	.8865	.8865	.8865	.7842	.7468	
18	.6979	.6348		.8676	.7733	.8029	
19	.6413	.7356		.8488	.7356	.7733	
20	.6979	.7282			.7282	.811	
21	.7922	.8488		.7167	.8215	.8029	
22	.811	.8865		.8299	.8676	.8299	
23	.7922	.8488		.8488	.8865	.7922	
24	.7023	.7392	.7922		.7922	.7095	.7545
Max	.811	.8865	.9242	.8865	.9808	.8676	.7545
Min	.3887	.4938	.4458	.4835	.5487	.5975	.5249
Avg	.6868	.7083	.7344	.7722	.7663	.7504	.6267

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244122 / 33/11 KV BALAJI MANDIR

Feeder No / Name : 202 / 11 KV Circuit House

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3326	.3361	.3174	.3547	.3584	.3018	.2614
2	.3361	.3206	.2987	.3361	.3206	.3018	.2641
3	.2772	.2641	.2614	.3018	.2829	.2614	.2263
4	.2402	.2452	.2641	.3018	.2829	.2614	.2263
5	.2427	.2263	.2641	.3018	.2452	.2452	.2263
6	.2263	.2263	.2218	.2641	.2263	.2263	.2263
7	.2263	.2241	.2218	.2263	.2263	.2075	.2195
8	.2075	.2075	.2263	.2263	.2075	.2075	.2075
9	.2241	.1886	.2829	.2614	.2829	.2075	.2427
10	.2241	.1886	.2452	.2263	.2641	.2263	.2263
11	.2427	.2452	.2641	.3018	.3206	.2452	.2427
12	.2402	.2452	.2829	.2641	.3018	.2263	
13	.2427	.3292	.2641	.2641	.3206	.2641	
14	.2427	.3206	.3018	.3018	.3018	.2641	
15	.3734	.3206	.3206	.3206	.3395	.2829	
16	.2829	.3018	.3206	.3206	.3584	.2614	
17	.3018	.2829	.3206	.3018	.2263	.2829	
18	.2452	.2241	.3018	.2641	.2263	.2427	
19	.3361	.3326	.3696	.3584	.2427	.3696	
20	.3658	.4024	.4854		.2801	.3326	
21	.3174	.3547	.4668	.3511	.3206	.3326	
22	.4108	.4294	.4854	.3696	.3395	.3881	
23	.4294	.4251	.5228	.4715	.415	.4294	
24	.3696	.3921	.3511	.4294	.4527	.3734	.3326
Max	.4294	.4294	.5228	.4715	.4527	.4294	.3326
Min	.2075	.1886	.2218	.2263	.2075	.2075	.2075
Avg	.2891	.2931	.3192	.3095	.2976	.2809	.2418

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244019 / 33/11 KV MADHAVNAGAR

Feeder No / Name : 201 / 11 KV MADHAVNAGAR FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6224	.7811	.6602	.8299	.8383	.7095	.7167
2	.5658	.7621	.6036	.6979	.7621	.679	.6602
3	.5658	.743	.6036	.6979	.7621	.6224	.6602
4	.5658	.7049	.6036	.6979	.724	.6161	.6602
5	.5658	.6668	.6036	.6979	.724	.6036	.6602
6	.5847	.6668	.5847	.7167	.6668	.6161	.6979
7	.547	.6668	.5847	.7167	.7621	.6224	.679
8	.5281	.6859	.5847	.6602	.8002	.5658	.4904
9	.679	.7783	.7621		.7602	.7621	
10	.7545	.9231	.9335		.7783	.8573	
11	.8299	.9593	1.0669		.8145	.9717	
12	.9431	.905	.9526		.8688	.8954	
13	.8676	.7783	.8954		.7133	.7811	
14	.8299	.9231	.9526		.8145	.8573	
15	.7922	1.086	1.105		.9774	.9335	
16		.9955	1.0288		.9231	.9335	
17		1.0185	.9593		.9328	.9593	
18	.9335	1.0562	.905	.9526	.9619	.905	
19	.9907	1.0185	1.1041	1.4098	.9328	1.1041	
20	1.2574	.9808	1.0498	1.7528	.9242	1.0136	
21	1.2765	.9431	.9877	.8002	.811	.8688	
22	1.2955	.8676	.9328		.7922	.8596	.724
23	1.3336	.7922	.9145	.8002	.7545	.8316	.724
24	.679	.8573	.7545	.8676	.8954	.7468	.8299
Max	1.3336	1.086	1.105	1.7528	.9774	1.1041	.8299
Min	.5281	.6668	.5847	.6602	.6668	.5658	.4904
Avg	.8185	.8567	.8389	.8785	.8206	.8048	.6821

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244019 / 33/11 KV MADHAVNAGAR

Feeder No / Name : 203 / 11 KV SIE FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1524	.1509	.132	.1524	.1509	.1524
2	.1132	.1524	.1509	.132	.1524	.1509	.1715
3	.1132	.1524	.1509	.132	.1334	.1509	.1334
4	.1132	.1524	.1509	.132	.1334	.132	.1524
5	.1132	.1524	.1509	.132	.1334	.1509	.1524
6	.1509	.1715	.132	.1509	.1334	.1509	.1715
7	.1509	1.1431	.132	.1698	.1334	.1509	.1509
8	.0943	1.0669	.1132	.1132	.1524	.132	.1132
9	.9335	.5182	.5525	.4515	.3567	.5716	
10	1.0829	.5792	.743	.4877	.4012	.6668	
11	1.1949	.5487	.6668	.5335	.2824	.7049	
12	1.307	.4988	.6478	.5182	.3418	.6287	
13	.5117	.3374	.6097	.4877	.3418	.5716	
14	.301	.4108	.5716	.4515	.3567	.5144	
15		.3961	.5716	.4365	.3715	.4572	
16	.3913	.4108	.5525		.3715	.5335	
17	.1143	.1698	.0943	.0953	.1132	.0943	
18	.1143		.1132	.0762	.1132	.132	
19	.1524	.1698	.1509		.132	.1509	
20	.1715	.1886	.1698		.132	.1698	
21	.1524	.1886	.1698	.1524	.1509	.1509	
22	.1524	.1646	.1509	.1524	.1509	.1509	
23	.1524	.1698	.1509	.1524	.1509	.1509	
24	.132	.1524	.1698	.1509	.1524	.1509	.1524
Max	1.307	1.1431	.743	.5335	.4012	.7049	.1715
Min	.0943	.1524	.0943	.0762	.1132	.0943	.1132
Avg	.3403	.3499	.3007	.2495	.2101	.2904	.1500

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244019 / 33/11 KV MADHAVNAGAR

Feeder No / Name : 205 / 11 KV COTTON MILL FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1883	1.2765	1.2071	1.3203	1.2193	1.2826	1.2826
2	1.1883	1.2765	1.2071	1.3203	1.2193	1.2449	1.2826
3	1.1883	1.2765	1.1694	1.3203	1.2193	1.2449	1.2826
4	1.1883	1.2765	1.1694	1.3203	1.2384	1.1694	1.2826
5	1.1883	1.2955	1.1694	1.3203	1.2384	1.1694	1.2826
6	1.1883	1.2955	1.1694	1.3014	1.2574	1.1694	1.2826
7	1.1317	1.2955	1.1694	1.2449	1.2574	1.1694	1.1883
8	1.1317	1.2574	1.1694	1.2071	1.2574	1.2826	
9	1.3203	1.4901	1.4289		1.3769	1.3336	
10	1.5278	1.5466	1.5623		1.5278	1.5051	
11	1.4335	1.6409	1.6004		1.5844	1.5432	
12	1.3957	1.4712	1.4289		1.4901	1.4289	
13	1.4335	1.3769	1.3717		1.3957	1.3336	
14	1.5089	1.4523	1.5242		1.4712	1.4289	
15	1.5844	1.5466	1.5813	1.7147	1.4901	1.5242	
16	2.2257	1.5278	1.448		1.4523	1.467	
17	1.4098	1.4712	1.4712		1.4335	1.4335	
18	1.4098	1.4335	1.4146	1.3717	1.3957	1.4146	
19	1.3336	1.4146	1.4523	1.4098	1.3392	1.4146	
20	1.2574	1.3769	1.2826		1.358	1.226	
21	1.0479	1.3014	1.2637	1.2955	1.3203	1.2826	
22	.8383	1.2826	1.358	1.2574	1.3203	1.3014	1.1812
23		1.2826	1.3203	1.2574	1.3203	1.3014	1.2003
24	1.1883	1.3336	1.2449	1.3203	1.1812	1.3203	1.2826
Max	2.2257	1.6409	1.6004	1.7147	1.5844	1.5432	1.2826
Min	.8383	1.2574	1.1694	1.2071	1.1812	1.1694	1.1812
Avg	1.3177	1.3833	1.3410	1.3321	1.3485	1.3330	1.2548

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 201 / 11 KV OM COLD

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6691	1.0136	1.0288	2.1653	1.0151	1.0517	2.1868
2	.663	1.0242	1.0098	2.1047	.9846	.9526	2.1505
3	.6371	1.0151	.9907	2.1178	1.0334	1.041	1.9693
4	.6478	.9983	.9717	1.9907	1.0578	.9511	1.8347
5	.6341	.9998	1.0098	1.9785	.9297	.9267	1.7223
6	.6584	1.0532	1.086	1.9791	1.0181	.852	1.4472
7	1.8534	1.0913	1.0288	2.13	1.102	1.1142	1.3698
8	1.877	1.0029	.9907	2.2167	2.3548	1.0578	1.3929
9	2.37	2.3648	1.1812	2.4569	2.2204	1.169	.7727
10	2.7305	2.7663	1.3527	2.8172	2.6494	1.4022	1.6041
11	2.8532	2.9762		2.9336	2.7027	1.5287	.8093
12	2.7968	3.0931	1.2574	2.8955	2.5627	2.9531	.7819
13	2.7404	2.7843		2.5547	2.6886	1.5059	.6889
14	2.5956	2.6546	1.2003	2.5416	2.3806	1.23	.6965
15	2.8144	2.9807		2.9653	1.8983	1.4784	.7087
16	2.8181	2.9531		3.0996	2.2742	1.5165	.7148
17	1.419	1.4251	1.2826	1.4342	1.23	2.8336	.7057
18	2.7875	2.5743	1.4712	1.5684	1.3032	1.419	.7179
19	2.6456	2.6657	1.3203	2.4364	1.2696	2.5939	.7194
20	2.3898	2.3465	1.2071	1.2071	1.1599	1.2818	.6996
21	1.0989	2.0843	1.3392		.9938	2.0636	.6645
22	1.1126	1.0608	1.2449	.381	1.0105	2.1435	.6508
23	1.1309	2.2992	1.1128	1.9677	1.0928	2.2252	1.2102
24	1.7117	1.1782	1.094	.9877	1.1142	2.2054	.5898
Max	2.8532	3.0931	1.4712	3.0996	2.7027	2.9531	2.1868
Min	.6341	.9983	.9717	.381	.9297	.852	.5898
Avg	1.8190	1.9336	1.159	2.1274	1.5853	1.5624	1.1170

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 202 / 11 KV KVC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8657	1.3131	1.1812	2.2136	.5136	1.1164	1.8534
2	.8711	1.3192	1.1431	2.2298	.9381	1.1393	1.7951
3	.8421	1.243	1.105	2.1737	.932	1.1683	1.7116
4	.833	1.2048	1.0669	2.1691	1.1614	1.1606	1.7181
5	1.0875	1.2094	1.086	2.1734	1.1751	1.1515	1.624
6	.8924	1.2437	.9717	2.2674	1.1446	1.1111	1.6164
7	1.816	1.2971	1.1812	2.311	1.1507	1.1233	1.6729
8	1.8907	1.3527	1.2955	2.2613	2.588	1.2536	1.62
9	2.3137	3.0098	1.1431	2.5787	2.7781	1.1111	.7971
10	2.9973	3.8126	1.9052	3.4768	3.244	1.4091	1.4922
11	5.5007	4.2501		3.4286	3.2274	1.4739	.7377
12	4.3515	3.8044	1.9052	3.4149	3.3181	2.8486	.7506
13	3.2534	3.1293		3.3358	3.2293	1.4205	.7674
14	3.4172	3.6585	1.9052	3.3771	3.1965	1.3794	.7499
15	4.0101	3.8899		3.5928	3.6526	1.5325	.7895
16	4.0169	3.8773		3.5008	3.7466	1.4998	.8017
17	1.957	2.0614	1.5278	1.7749	1.7924	2.6699	.8002
18	3.3089	3.4416	1.4901	1.4289	1.5859	1.3481	.7926
19	2.8445	3.1946	1.5278	2.7366	1.4655	2.2321	.8032
20	2.6947	2.761	1.2071	1.2209	1.2673	1.0128	.8093
21	1.406	2.2443	1.1128	.003	1.2239	1.9544	.788
22	1.3001	1.2963	1.0562	.3041	1.2483	1.9068	.759
23	1.3314	2.5644	1.1128	.9831	1.1317	1.7785	1.5105
24	2.0683	1.2605	1.0374	.5098	1.1546	1.8052	.7788
Max	5.5007	4.2501	1.9052	3.5928	3.7466	2.8486	1.8534
Min	.833	1.2048	.9717	.003	.5136	1.0128	.7377
Avg	2.3279	2.4350	1.2981	2.2278	1.9527	1.5253	1.1475

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 203 / 11 KV DIAMOND

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.599	1.5882	1.3336	2.4057	1.3893	1.4502	2.2228
2	.6203	1.419	1.4098	2.3083	1.2376	1.3474	2.1716
3	.5563	1.4746	1.3717	2.2954	1.4411	1.3763	2.247
4	.3727	1.4701	1.3908	2.4482	1.4388	1.3984	2.2764
5	.5563	1.4868	1.3908	2.5855	1.4502	1.2521	2.2668
6	.6447	1.3573	.6668	2.7936	1.3702	1.2734	2.7551
7	.8543	1.4624	1.3717	2.68	1.4601	1.3466	2.6071
8	.4443	1.5059	1.2193	2.6975	3.1611	1.4319	2.1567
9	1.6704	1.5844	1.448	2.6421	3.3632	1.3367	1.1332
10	3.1169	2.5671	1.6194	2.8743	3.1377	1.4007	.4618
11	3.3432	3.2081		2.979	3.9855	1.5043	.2446
12	3.4598	3.4873	1.2193	2.6117	4.0842	2.6086	.2477
13	2.7336	3.2718		2.4169	3.8753	1.4098	.2393
14	2.8799	2.9683	1.448	2.7688	3.3164	1.4609	.2462
15	3.1017	3.3082		2.9751	3.8759	1.1767	.2454
16	3.2099	2.7274		3.0205	3.9003	1.2628	.2454
17	1.3154	1.6004	1.4335	1.4457	1.7962	2.7856	.2462
18	2.8814	3.1208	1.3392	1.5242	1.8564	1.4617	.2614
19	3.075	3.1939	1.4523	2.4364	1.6598	2.9696	.266
20	2.8833	2.3869	.9242	1.4083	1.5348	1.4662	.266
21	1.4594	2.9957	1.3957	1.2574	1.3618	2.6164	.2576
22	1.4746	1.5272	1.0751	1.1767	1.3832	2.6823	.4557
23	1.6606	2.9012	1.4146	2.1399	1.5318	2.8271	.8276
24	1.7376	1.4975	1.4523	1.3184	1.3801	2.2851	.6249
Max	3.4598	3.4873	1.6194	3.0205	4.0842	2.9696	2.7551
Min	.3727	1.3573	.6668	1.1767	1.2376	1.1767	.2393
Avg	1.8604	2.2546	1.3188	2.3004	2.2913	1.7555	1.0405

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 204 / 11KV NATRAJ

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7385	1.2376	1.2955	2.5535	1.1744	1.1629	2.5246
2	.7377	1.2148	1.2193	2.3499	1.1972	1.1652	2.508
3	.7461	1.1965	1.2574	2.4348	1.137	1.1401	2.4169
4	.743	1.1911	1.2193	2.3575	1.0905	1.0768	2.3838
5	.7491	1.1972	1.1812	2.2386	1.0174	1.07	2.3049
6	.7781	1.1858	1.2193	2.3212	1.0517	1.1058	2.475
7	1.4861	1.1827	1.0669	2.2377	1.0349	1.1157	2.2445
8	1.5318	1.0997	1.086	2.0824	1.9395	1.038	1.8128
9	2.5697	2.7648	1.3336	2.4744	2.4318	1.2483	.7872
10	3.2053	3.1881	1.8099	2.9424	3.301	1.72	1.4152
11	3.8463	3.9765		3.7102	3.5159	1.8	.7194
12	3.5756	4.5231	2.0386	4.095	3.5181	3.3517	.7095
13	3.5955	3.882		3.5784	3.3223	1.7132	.7583
14	3.821	4.1667	2.3053	3.4866	3.4501	1.861	.8192
15	4.5451	4.5041		3.8098	3.8222	1.9646	.7933
16	4.0261	3.6687		4.1148	3.7043	1.8892	.7964
17	2.005	2.0378	2.3765	2.1338	1.9364	3.954	.7895
18	3.4871	3.3714	1.7353	2.1003	1.9608	1.858	.7971
19	2.8327	2.8693	1.5278	2.6269	1.6659	3.1567	.8391
20	2.6008	2.7343	1.4146	1.3588	1.6362	1.5905	.833
21	1.2323	2.6299	1.3203	.0221	1.3824	2.8376	.8833
22	1.294	1.3961	1.4146	.1936	1.2155	2.6069	.7819
23	1.2811	2.7008	1.2826	1.3664	1.2071	2.5524	1.4198
24	2.0157	1.2993	1.1506	1.1264	1.1294	2.5206	.7743
Max	4.5451	4.5231	2.3765	4.1148	3.8222	3.954	2.5246
Min	.7377	1.0997	1.0669	.0221	1.0174	1.038	.7095
Avg	2.2268	2.4674	1.4627	2.4048	2.0351	1.8958	1.3578

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 205 / 11 KV OMKAR

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9099	2.0889	1.7909	3.954	1.7139	1.7703	3.5425
2	.9922	1.8564	1.7528	3.8243	1.973	2.0744	3.7662
3	1.0326	2.0081	1.7147	3.2575	1.454	1.8732	3.1828
4	1.0471	1.7345	1.6766	3.6092	1.6507	1.9014	3.4945
5	1.0661	1.954	1.5432	3.6774	1.7436	1.9906	3.2107
6	1.1385	1.6636	1.8099	3.1969	1.9006	1.9707	3.5738
7	2.0081	1.3199	1.8099	3.0969	1.8915	2.0203	2.4969
8	2.2519	1.3504	1.1431	3.2722	3.4316	1.8328	1.4097
9	2.5545	3.5036	1.4289	2.7476	3.7722	1.275	.6683
10	3.892	4.3069	1.9243	3.1209	3.5654	1.7452	1.2528
11	4.3645	3.7975		3.5219	3.9624	2.3602	.6325
12	3.9193	4.0142	1.5242	3.0569	4.296	4.35	.6188
13	3.0574	4.312		4.3057	3.8956	2.2885	.5822
14	3.8721	3.3621	1.9052	4.369	4.0043	1.9951	.6607
15	4.2357	4.5749		3.5359	4.0703	2.4341	.647
16	4.4163	4.5479		4.8615	4.2666	2.5225	.6356
17	1.9486	1.7939	1.9616	2.4227	1.9928	2.7193	.6356
18	3.1384	3.722	1.5655	1.8031	1.8755	1.8069	.6562
19	3.4438	3.3951	2.0748	3.5071	1.8145	3.4859	.6592
20	3.5126	3.5726	1.8296	1.7436	1.7993	1.4914	.6554
21	1.704	3.2915	1.7918	1.2955	1.643	3.4399	.6996
22	2.0919	1.6179	1.7541	1.7017	1.8915	3.3869	.8253
23	1.5036	3.7235	1.9239	3.7334	1.7749	3.2708	1.4472
24	2.3342	1.8503	1.6598	1.7444	2.0782	3.3913	.9678
Max	4.4163	4.5749	2.0748	4.8615	4.296	4.35	3.7662
Min	.9099	1.3199	1.1431	1.2955	1.454	1.275	.5822
Avg	2.5181	2.8901	1.7292	3.1400	2.6026	2.3915	1.5384

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 206 / 11 kv Adimaya

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.2955	1.2449			1.1694
2			1.2574	1.2071			1.1317
3			1.2193	1.2071			1.1317
4			1.1812	1.1883			1.094
5			1.1431	1.1694			1.094
6			1.086	1.1506			1.0751
7	1.0479		1.2003	1.1694			1.0562
8	1.0098		1.2765	1.1883	.1524		1.0374
9	1.6004	1.4335		1.5089			
10	1.7909	1.8107	1.6766	1.8484	.3772		.8573
11	1.9243	1.8107		1.7353	.3206		
12	1.9243	1.6975	1.7528	1.5466	.1509	1.6194	
13	1.7909	1.5844		1.6409	.1509		
14	1.8099	1.7918	1.6385	1.6032	.3772		
15	1.9624	1.9616		1.5089	.3395		
16	1.9814	1.8484		1.6032	.3206		
17			1.5466			1.773	
18	1.226	1.5242	1.3392				
19	1.3203	1.3908	1.2826	1.467		1.3392	
20	1.1883	1.2193	1.1317				
21		1.2574	1.1694			1.1317	
22			1.3392			1.3014	
23		1.2574	1.4335	.1524		1.2826	.9145
24	.9907		1.226			1.1506	
Max	1.9814	1.9616	1.7528	1.8484	.3772	1.773	1.1694
Min	.9907	1.2193	1.086	.1524	.1509	1.1317	.8573
Avg	1.5405	1.5837	1.3261	1.3411	.2737	1.3711	1.0561

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 207 / 11 kv mandhana

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7042	1.259	1.2193	2.6541	1.012	1.2163	2.6706
2	.6996	1.2475	1.1812	2.544	.9587	1.1835	2.5964
3	.7209	1.1538	1.105	2.5436	1.1187	1.1888	2.5107
4	.7453	1.0456	1.0669	2.4211	1.1584	1.1485	2.3152
5	.7689	1.1477	1.1431	2.4046	1.1843	1.1873	2.311
6	.8154	1.1218	1.0479	2.2233	1.1934	1.1706	2.2167
7	1.6263	1.1507	.9907	1.9629	1.1881	1.1706	1.7973
8	1.5966	1.0639	1.3908	2.7008	2.3678	1.153	1.4272
9	3.0209	2.8906	1.4098	3.3665	3.3107	1.5485	.6683
10	3.3494	3.8136	2.0005	3.4238	3.6685	1.8503	1.2773
11	3.8957	3.8605		3.6339	4.1002	2.0309	.5502
12	3.8279	4.0301	1.6575	3.6033	4.1825	3.9613	.4489
13	3.2647	3.6279		3.2209	3.468	1.8473	.471
14	3.3258	3.915	1.829	3.5498	3.5011	1.6179	.4626
15	3.8234	3.7998		3.646	3.5858	2.0911	.6744
16	3.6008	3.9233		3.8927	3.6675	1.8183	.6783
17	1.7269	1.7177	1.5655	1.6446	1.9479	3.2446	.695
18	3.3518	3.5025	1.8861	1.9464	1.7734	1.6545	.6981
19	3.2537	3.3501	1.4901	3.0072	1.7467	3.3147	.6889
20	2.7601	3.1779	1.4901	1.5257	1.643	1.4182	.695
21	1.3801	2.8478	1.2826	.0343	1.5821	2.6919	.6615
22	1.4419	1.5203	1.5844	1.0601	1.3862	2.519	.618
23	1.2483	2.4829	1.6598	1.9845	1.4182	2.4182	1.2262
24	1.9997	1.2887	1.5089	1.0197	1.2262	2.1567	.6386
Max	3.8957	4.0301	2.0005	3.8927	4.1825	3.9613	2.6706
Min	.6996	1.0456	.9907	.0343	.9587	1.1485	.4489
Avg	2.2062	2.4558	1.4255	2.5006	2.1829	1.9001	1.2082

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 208 / 11 KV Devika

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2393	.1936	.1905	.3906	.1791	.1905	.3588
2	.2393	.2012	.1905	.3974	.1814	.1974	.3535
3	.2439	.1943	.1715	.4035	.1867	.1905	.3535
4	.2416	.1859	.1905	.405	.1783	.1974	.3527
5	.2347	.1981	.2096	.4572	.1928	.1913	.3542
6	.2393	.202	.2286	.4822	.2058	.205	.3806
7	.4542	.2088	.2286	.5051	.2218	.2218	.4624
8	.4817	.2515	.2477	.4801	.4916	.2454	.4816
9	.5304	.4666	.2477	.4681	.4801	.25	.2545
10	.4732	.4929	.2477	.4508	.5438	.2774	.4458
11	.5441	.5165		.494	.5992	.2873	.25
12	.5205	.5075	.2667	.5106	.556	.5243	.2096
13	.5701	.5603		.5113	.5793	.2987	.2241
14	.5433	.5438	.2477	.4537	.5499	.2995	.2263
15	.5236	.543		.4765	.5793	.2865	.2263
16	.5441	.4976		.4652	.5712	.314	.2126
17	.2736	.2797	.2641	.2797	.3193	.5636	.2126
18	.4742	.5555	.2452	.2964	.3307	.2873	.218
19	.4801	.5022	.2641	.519	.2919	.4892	.2187
20	.4259	.4786	.1886	.2561	.2469	.2462	.2263
21	.2225	.4367	.1886	.2004	.1898	.3618	.2263
22	.2042	.2134	.1886	.1844	.1882	.3685	.2233
23	.189	.4192	.1886	.3514	.1875	.3504	.4138
24	.4245	.2073	.1886	.1791	.1905	.3519	.2309
Max	.5701	.5603	.2667	.519	.5992	.5636	.4816
Min	.189	.1859	.1715	.1791	.1783	.1905	.2096
Avg	.3882	.3690	.2192	.4007	.3434	.2998	.2965

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 402 / 33 KV Shah Presicast Unit NON SHEDDABLE EXPRESS HV FEEDERS
 III Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9602	.8573	.2972	1.0493	.8573	.823	1.0836
2	.9602	.8573	.2972	1.1059	.8916	.823	1.0493
3	.9602	.823	.2915	1.1745	.9259	.8573	1.1745
4	.9602	.8916	.2629	1.1745	.9602	.9259	1.1745
5	.9602	.8916	.2972	1.1402	.9259	.8916	1.2088
6	.9259	.8916	.2858	1.1745	.9602	.8916	1.2088
7	1.2688	.8916	.2972	1.1745	.9602	.8916	1.2088
8	1.2003	.823	.8116	1.1745	1.1774	.823	1.2088
9	1.0403	1.0151		1.072	3.3179	.7888	.9259
10	1.0174	1.0151	.5716	1.0604	4.3878	1.9204	1.2231
11	1.0517	.9465		1.1059	5.0858	3.4294	.9945
12	1.0973	1.0151	1.2003	1.0607	5.1201	5.0869	.9945
13	.9831	.9808		1.1063	3.8494	3.738	.9602
14	.8573	3.7175	.9717	1.0836	1.7009	2.7092	.9945
15	.9374	4.4016		1.1059	1.1059	2.2634	.9945
16	1.0631	4.9365		1.1063	4.2181	4.4239	.9945
17	.7888	3.8409	.2263	.7545	3.6694	4.88	.9945
18	1.0607	4.2753	.2263	.8916	3.6694	1.3717	1.0288
19	1.0374	7.7732	.2263	1.1774	3.738	1.0836	.9945
20	1.0607	1.0517	.2263	.8916	1.5775	.8573	.9945
21	.8916	1.2117	.2829		.8916	1.2088	.9945
22	.8573	.8573	.2829	.7545	.8573	1.1745	.9945
23	.8573	1.0973	.2829	1.1545	.8573	1.1402	1.3146
24	1.1774	.8573	.2263	.9259	.8916	1.0493	.9945
Max	1.2688	7.7732	1.2003	1.1774	5.1201	5.0869	1.3146
Min	.7888	.823	.2263	.7545	.8573	.7888	.9259
Avg	.9990	1.9133	.3981	1.0617	2.1915	1.8355	1.0712

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244043 / 33/11 KV CHAKAN

Feeder No / Name : 202 / DATTANAND FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.6859	.7621	.7621
2	.7621	.7621	.7621	.7621
3	.7621	.7621	.8383	.7621
4	.8383	.7621	.8383	.7621
5	.8383	.7621	.8383	.7621
6	.8383	.7621	.8383	.7621
7	.7621	.7621	.8383	.7621
8	.8383	.7621	.8383	.7621
9	.8383	.8383	.8383	.8383
10	.9145	.9145	.9145	.8383
11	.9145	.9907	.9907	.7621
12	.9907	.9907	.9907	.7621
13	.9145	.9145	.8383	.7621
14	.8383	.9145	.8383	.7621
15	1.0669	.9907	.9145	.7621
16	.9907	.8383	.9145	.7621
17	.9907	.8383	.9145	.7621
18	.9145	.7621	.7621	.7621
19	.8383	.7621	.7621	.7621
20	.7621	.7621	.7621	.7621
21	.7621	.7621	.7621	.6859
22	.6859	.7621	.7621	.7621
23	.6859	.7621	.7621	.7621
24	.6859	.7621	.7621	.7621
Max	1.0669	.9907	.9907	.8383
Min	.6859	.6859	.7621	.6859
Avg	.8415	.8161	.8351	.7653

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244043 / 33/11 KV CHAKAN

Feeder No / Name : 203 / 11 KV Godavari

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0669	.7621	1.2193	.9145	1.2193
2	.9145	.7621	1.2193	.9145	1.2193
3	.9145	.7621	1.2193	.9145	1.2193
4	.9145	.6097	1.2193	.7621	1.2193
5	.9145	.6097	1.2193	.9145	1.2193
6	.9145	.7621	1.2193	.9145	1.2193
7	.9145	.7621	.9145	.9145	.9145
8	.9145	.9145	.9145	.9145	.6097
9	1.2193	1.0669	1.0669	1.0669	.6097
10	1.5242	1.3717	1.2193	1.3717	.6097
11	1.5242	1.3717	1.6766	1.3717	.6097
12	1.6766	1.5242	1.829	1.3717	.6097
13	1.6766	1.5242	1.6766	1.2193	.6097
14	1.5242	1.3717	1.2193	1.0669	.6097
15	1.3717	1.5242	1.6766	1.2193	.6097
16	1.5242	1.5242	1.6766	1.2193	.6097
17	1.829	1.3717	1.6766	1.3717	.6097
18	1.3717	1.3717	1.2193	1.2193	.4572
19	1.2193	1.0669	1.0669	1.0669	.4572
20	1.0669	1.0669	.9145	1.0669	.4572
21	.9145	.6097	.7621	.7621	.4572
22	.9145	.9145	.7621	.7621	.6097
23	1.2193	.9145	.9145	1.2193	.6097
24	1.3717	1.2193	.9145	1.3717	.6097
Max	1.829	1.5242	1.829	1.3717	1.2193
Min	.9145	.6097	.7621	.7621	.4572
Avg	1.2257	1.0733	1.2257	1.0796	.7494

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244043 / 33/11 KV CHAKAN

Feeder No / Name : 401 / 33 KV Parvati Agro Plast NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.4691	1.2174	1.286	2.1091	.7545
2		2.4691	1.406	1.3203	1.8347	.7888
3		2.5206	1.3546	1.1145		.7373
4		2.3663	1.3546	1.5261	.8059	.7716
5	.2743	2.2291	1.4575	1.1317	1.2174	.7545
6	.3944	2.0233	1.5604	1.0117	1.5947	.6687
7		2.0405	1.2003	.8745	1.5432	.6344
8		1.8176	.9088	.8402	1.3717	.463
9	.1886	1.8519	.9259	.6859	1.3717	
10	.6001	2.0233	1.1317	.8059	1.2346	
11	1.2689	2.1434	1.0631	.9431	1.2517	
12	1.406	2.2462	1.3375	1.0631	1.4575	
13	1.406	2.1605	1.9376	1.0117	1.4746	
14	1.2346	2.3148	1.8519	1.1145	1.3717	
15	1.406	2.4863	1.7318	1.1145	1.3717	
16	1.9204	2.1091	1.8004	1.4403	1.2003	
17	1.9719	1.9204	1.5432	1.3717	1.4403	
18	1.8004	1.9033	1.4746	1.3717	.0171	
19	1.7661	1.8519	1.3203	1.1145	1.0117	
20	1.7661	2.1605	1.1145	1.5432	1.1831	
21	1.8861	2.1262	.4458	1.4403	.9945	
22	2.0748	2.1776	.6516	1.5432	.8059	
23	2.0405	2.6235	.8745	1.5947	.703	
24	2.0062	2.5034	1.1317	1.7833	.7545	
Max	2.0748	2.6235	1.9376	1.7833	2.1091	.7888
Min	.1886	1.8176	.4458	.6859	.0171	.463
Avg	1.4117	2.1891	1.2832	1.2103	1.2226	.6966

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 201 / 11 KV Ankur

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7209	1.0631	.2835	.8882	.6493	.8627	.8841
2	.7164	.9854	.2926	.8748	.6363	.7773	.9137
3	.6707	.9145	.3109	.8474	.6477	.7156	.8871
4	.6257	.8353	.4401	.8428	.6668	.6851	.6066
5	.6272	.7887	.423	.82	.692	.708	.8672
6	.6287	.8132	.4268	.7949	.8405	.6897	.8535
7	.6416	.8117	.4085	1.0836	.8764	.8535	.7819
8	.6943	.7514	.5117	1.1248	1.0223	1.0547	.6858
9	1.0837	1.435	.9808	1.7528	1.4331	1.6324	.6882
10	1.464	1.7238	1.0562	1.9494	1.797	2.0706	.7088
11	1.5402	1.9136	1.1203	1.8305	1.0204	1.906	.6889
12	1.5547	1.89	.8871	1.8054	.0869	2.034	.8078
13	.8444	1.6308	.9412	1.7832	1.5547	1.6102	.6973
14	.8139	1.9548	.9511	1.8353	1.6842	1.8053	.644
15	1.6979	1.9052	.788	2.0645	2.1079	1.6903	.6714
16	1.7352	1.7246	1.0456	1.0936	2.2162	2.1902	.631
17	1.6652	1.8804	.8322	.913	1.6941	1.5569	.6539
18	1.5623	1.3497	.8322	1.6179	1.7155	1.6317	.628
19	1.4898	1.4754		1.5455	1.3641	1.5867	.6234
20	1.3546	1.3313	.5182	.8032	1.0311	1.3195	.615
21	1.2002	1.1614	.3628	.4337	.8879	1.2787	.5929
22	1.0821	1.1454	.3734	.8085	.8429	.7484	.5807
23	1.1367	1.0928	.4115	.8231	.887	1.1873	.5769
24	.6698	1.0879	.2972	.8018	.682	1.0554	.9412
Max	1.7352	1.9548	1.1203	2.0645	2.2162	2.1902	.9412
Min	.6257	.7514	.2835	.4337	.0869	.6851	.5769
Avg	1.0925	1.3194	.6302	1.2141	1.1265	1.3188	.7179

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 202 / 11 KV LOKMAT

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.852	1.0345	.5365	1.0775	.9225	.9937	.9282
2	.8215	.9411	.503	1.0304	1.0121	.9252	.4908
3	.7788	.8756	.4973	.9907	1.0135	.8848	.8319
4	.7377	.8536	.431	.9031	1.0059	.8695	.8017
5	.82	.8322	.4161	.8871	1.006	.8756	.817
6	.9092	.8489	.4161	.865	.9061	.9076	.767
7	.8596	.9004	.4111	.999	.9236	1.0193	.7095
8	1.0384	1.1538	.5895	1.0356	.9481	.9762	.6893
9	1.6065	1.842	.924	1.829	1.6057	1.7879	.6828
10	2.1228	2.4188	1.1317	2.415	2.0675	2.2824	.4633
11	2.4699	2.5644	1.358	2.7435	1.1043	2.4683	.4717
12	2.622	2.2901	1.2449	2.5389	.0084	2.6422	.7941
13	1.1858	2.2238	1.0608	2.2923	1.3893	2.2931	.8117
14	1.1896	1.9078	1.1203	2.2893	2.066	1.201	.4458
15	2.439	2.3628	1.2071	2.6741	2.1124	2.5301	.4588
16	2.4912	2.2265	1.2071	1.3801	2.2085	2.5682	.4847
17	2.4112	2.3129	1.0829	1.2681	2.0226	2.4097	.4748
18	2.1121	1.9974	1.0456	2.21	2.0092	2.0515	.4664
19	1.7604	1.7375		1.8809	1.6049	1.7406	.4649
20	1.4906	1.3672	.7468	.8642	1.3901	1.528	.4725
21	1.4068	1.2064	.5975	.8909	1.1614	1.3489	.4542
22	1.2716	1.0989	.5975	.8973	1.0539	.6706	.4291
23	1.1877	1.2475	.5792	1.0517	1.0349	1.1641	.4679
24	.9907	1.1256	.583	1.105	1.0349	1.7002	.7171
Max	2.622	2.5644	1.358	2.7435	2.2085	2.6422	.9282
Min	.7377	.8322	.4111	.8642	.0084	.6706	.4291
Avg	1.4823	1.5571	.7951	1.5049	1.3172	1.5766	.6081

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 206 / 11 KV MIDC Water Supply

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0377	.0377	.0377		.0377	.0377
2	.0377	.0377	.0377	.0377		.0377	
3	.0377		.0377	.0377		.0377	.0377
4	.0377	.0377	.0377	.0377		.0377	.0377
5	.0377	.0377	.0377	.0377		.0377	
6	.0377	.0377	.0377	.0377		.0377	.0377
7	.0377	.0377	.0377	.0377		.0377	
8	.0377	.0377	.0377	.0377		.0377	.0377
9		.0377	.0377			.0377	.0377
10	.0377		.0377		.0377	.0377	
11	.0377	.0377	.0377		.0377	.0377	
12		.0377	.0377		.0377	.0377	.0377
13		.0377	.0377		.0377	.0377	.0377
14		.0377	.0377	.0377	.0377	.0377	
15		.0377	.0377	.0377	.0377	.0377	
16	.0377	.0377	.0377	.0377	.0377	.0377	
17	.0377	.0377		.0377	.0377	.0377	
18	.0377	.0377	.0377	.0377	.0377	.0377	
19	.0377	.0377		.0377	.0377	.0377	
20		.0377	.0377		.0377	.0377	
21	.0377	.0377	.0377		.0377	.0377	
22	.0377	.0377	.0377		.0377		
23	.0377	.0377	.0377		.0377	.0377	
24	.0377	.0377	.0377	.0377		.0377	.0377
Max	.0377	.0377	.0377	.0377	.0377	.0377	.0377
Min	.0377	.0377	.0377	.0377	.0377	.0377	.0377
Avg	.0377	.0377	.0377	.0377	.0377	.0377	.0377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 207 / 11 KV Bharat Steel
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.25	.2343		.2972	.2424	.2324	.237
2	.2355	.2343		.3018	.2393	.2423	.2347
3	.2278	.237		.3033	.237	.2446	.2431
4	.2256	.2377		.3087	.2386	.2446	.2362
5	.2347	.2377		.2896	.2386	.253	.2362
6	.2363	.2339		.2934	.2584	.2565	.234
7	.25	.2393		.3543	.2374	.2466	.2385
8	.256	.2507	.0046	.5038	.5796	.4854	.2492
9	.2325	.2286	.0019	1.0997	2.6178	1.4625	.2324
10	.237	.2203	.0023	2.6901	2.7012	2.6543	.2416
11	.2248	.2278	.0114	2.7892	2.4729	2.7046	.2279
12	.2237	.2278	.021	1.9814	2.6817	2.9066	.2363
13	.2202	.2248	.0133	2.4882	2.6414	2.5621	.2408
14	.2431	.253	.0023	2.428	2.6497	2.6314	.237
15	.237	.2263	.0023	2.652	2.7275	2.7892	.2362
16	.2423	.2206	.0133	1.1843	2.5651	2.0347	.2317
17	.2317	.0526		2.6612	2.5979	2.1391	.2416
18	.2294	.2469	.0005	2.652	1.3039	2.1201	.2446
19	.2393	.2317		2.6394	2.4143	2.5721	.2507
20	.2389	.2446	.0533	2.5179	2.7062	2.3674	.2309
21	.2412	.2412	.0526	.2424	2.4562	1.0403	.2408
22	.2241	.2317	.0457	.2378	.663	.2462	.2583
23	.2366	.2317	.0244	.2294	.2362	.2393	.2568
24	.2652	.2366	.0231	.2363	.221	.2454	.2652
Max	.2652	.253	.0533	2.7892	2.7275	2.9066	.2652
Min	.2202	.0526	.0005	.2294	.221	.2324	.2279
Avg	.2368	.2271	.0181	1.3076	1.4970	1.3717	.2409

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244095 / 33/11 KV KUPWAD CITY

Feeder No / Name : 208 / 11 KV Ashtavinayak

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17
HR	Load (MW)
15	.3772
Max	.3772
Min	.3772
Avg	.3772

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 201 / 11 KV MIRAJ CITY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.3532	3.4286	1.5729	3.6088	3.1604	3.1572	3.1514
2	3.2541	3.2906	1.5364	3.4355	3.0171	3.0133	3.0422
3	3.1828	3.0811	1.5181	3.3445	2.9157	2.9439	2.9447
4	3.0659	3.0295	1.4449	3.2658	2.8745	2.8967	2.8584
5	3.1249	2.9948	1.4815	3.1863	2.8209	2.8075	2.7862
6	3.1893	3.1348	1.5708	3.2914	2.9016	2.9515	2.8391
7	3.308	3.3021	1.5524	3.3722	2.9569	2.966	2.9939
8	3.1995	3.373	1.3969	3.1505	2.9887	3.1626	2.9454
9	3.1626	3.2435	1.4529	3.1176	3.017	3.0918	2.8775
10	3.3714	3.2874	1.5043	3.3196	3.0337	2.9582	3.0118
11	3.4048	2.9858	1.4148	3.206	2.9668	2.7587	2.9278
12	3.2565	3.1931	1.4899	3.2304	3.0009	2.6315	2.8418
13	3.1249	3.2179	1.5769	3.2221	3.0208	2.6116	2.773
14	3.1133	3.1355		3.1543	2.9876	2.5629	2.719
15	3.0247	3.1252	1.5415	3.2015	2.8281	2.6048	1.403
16	3.1665	2.8555	1.4352	3.2159	2.9567	2.8062	1.4251
17	3.3288	3.0339	1.5249	3.1795	2.9942	2.9592	1.733
18	3.4385	3.1046	1.6476	3.2091	3.1016	2.9653	1.6972
19	3.9019	3.7174	2.0595	1.829	3.5531	3.6786	1.8252
20	4.2691	4.1103	2.1437	1.9944	3.8961	3.4766	2.0858
21	4.2168	4.1324	2.1216	3.7317	3.9146	3.6065	2.05
22	4.1225	4.0489	2.0416	3.7129	3.8639	3.6976	1.9669
23	4.004	3.8584	1.9936	3.5917	3.7237	2.4486	1.9456
24	3.5753	3.5856	1.6827	3.6149	3.3158	3.4049	3.3275
Max	4.2691	4.1324	2.1437	3.7317	3.9146	3.6976	3.3275
Min	3.0247	2.8555	1.3969	1.829	2.8209	2.4486	1.403
Avg	3.4233	3.3446	1.6393	3.2161	3.1588	3.0067	2.5071

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 204 / 11 KV MEDICAL COLLEGE
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1612	.1829	.1646	.3677	.1646	.1448	.1448
2	.1646	.1646		.1612	.1463	.1463	.128
3	.1448	.1463	.1646	.1629	.1463	.128	.1254
4	.1402	.1294	.1646	.1448	.1463	.128	.1063
5	.168	.1294	.1646	.1578	.1294	.128	.1227
6	.1646	.1478	.1848	.1991	.1478	.2033	.1612
7	.1848	.1848	.2033	.2561	.1829	.2195	.181
8	.1991	.1848	.1791	.2353	.1629	.2195	.1433
9	.2149	.2218	.2126	.2926	.1928	.2378	.1991
10	.3224	.2353	.2328		.1991	.3142	.2378
11	.2303	.2561	.2149	.2926	.2103	.3109	.2303
12	.2254	.2454	.2454	.2743	.2126	.2896	.1543
13	.1886	.2835	.2126	.2561	.1928	.2507	.1417
14	.2172	.2865	.2126	.2195	.1448	.1991	.1991
15	.197	.3982		.2743	.1646	.2378	
16	.1791	.197	.2126	.2012	.1448	.2126	
17	.1578	.1578	.1578	.181	.1612	.1578	
18		.156	.197	.1753	.1543	.181	
19	.1772	.1928	.2012		.1595	.1829	
20	.1949	.2149	.2218		.1595	.1791	
21	.1949	.2328	.2378	.181	.1595	.1629	
22	.1949	.2012	.197	.1829	.1595	.1402	
23	.1829	.1829	.2012	.1829	.1629	.1402	
24	.1629	.1829	.1646	.181	.1829	.1448	.1417
Max	.3224	.3982	.2454	.3677	.2126	.3142	.2378
Min	.1402	.1294	.1578	.1448	.1294	.128	.1063
Avg	.1899	.2048	.1976	.2181	.1662	.1941	.1611

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 205 / 11KV Dairy Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0702	2.1475	1.0185	2.1788	2.0502	1.9639	2.0131
2	2.013	2.0382	.9619	2.0325	1.937	1.8503	1.8827
3	1.9489	1.9102	.9242	1.9571	1.8657	1.7901	1.8279
4	1.8808	1.8382	.9242	1.8919	1.8208	1.713	1.7775
5	1.7799	1.8002	.9431	1.8076	1.7772	1.6659	1.7406
6	1.7714	1.9189	.9808	1.8431	1.7894	1.7549	1.736
7	1.7336	1.8202	.9242	1.8282	1.6381	1.7065	1.6692
8	1.6097	1.7162	.8145	1.6674	1.5996	1.5636	1.635
9	1.7116	1.8313	1.0562	1.8027	1.7158	1.6758	1.6882
10	2.0073	1.9936	1.1128	2.1104	1.6711	1.9318	1.752
11	2.2161	2.183	1.2449	2.1995	1.7867	1.8656	1.8645
12	2.3834	2.2161	1.2449	2.2779	1.8119	2.0671	2.0058
13	2.4156	2.3228	1.226	2.328	1.8523	2.2017	2.1342
14	2.4634	2.2948	1.2071	2.3365	1.9698	2.2626	1.1195
15	2.3921	2.3434	1.226	2.3453	1.922	2.2503	1.0654
16	2.372	2.435	1.1883	2.3596	1.8892	2.2268	1.0319
17	2.3023	2.332	1.1128	2.1894	1.8275	2.243	1.0707
18	2.2337	2.2454	1.1088	1.9483	1.769	2.1588	1.0585
19	2.6238	2.6033	1.4083	.9938	2.0709	2.3937	1.0166
20	2.796	2.7896	1.2986	1.2833	2.2931	2.6017	1.2696
21	2.6986	2.6642	1.2308	2.4438	2.3263	2.5281	1.2574
22	2.6048	2.5855	1.3253	2.4723	2.2893	2.4355	1.2178
23	2.4709	2.5497	1.267	2.4066	2.3529	2.3022	1.2026
24	2.2177	2.3169	1.094	2.2584	2.2409	2.1765	2.0972
Max	2.796	2.7896	1.4083	2.4723	2.3529	2.6017	2.1342
Min	1.6097	1.7162	.8145	.9938	1.5996	1.5636	1.0166
Avg	2.1965	2.2040	1.1185	2.0401	1.9278	2.0554	1.5472

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 206 / Vidya nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6134	1.6511	.7733	1.7	1.583	1.6111	1.5421
2	1.5533	1.5478	.7356	1.5509	1.5148	1.5615	1.4884
3	1.4929	1.4704	.7356	1.5469	1.4813	1.4937	1.4571
4	1.4766	1.3948	.7167	1.5097	1.4347	1.4346	1.4071
5	1.4655	1.3494	.7167	1.5219	1.4308	1.4036	1.4093
6	1.4941	1.5021	.8299	1.7412	1.4898	1.456	1.4163
7	1.4674	1.5016	.7356	1.5234	1.4674	1.4695	1.3697
8	1.3316	1.3032	.6335	1.3538	1.3207	1.3049	1.2422
9	1.1462	1.1873	.6036	1.1799	1.2456	1.1309	1.1816
10	1.1088	1.112	.6036	1.1399	1.1218	1.0326	1.1797
11	1.1104	1.0791	.6224	1.1313	1.1195	1.0181	1.114
12	1.1771	1.1645	.6224	1.2083	1.138	1.0384	1.1119
13	1.1403	1.1904	.6224	1.2237	1.129	1.0683	1.1085
14	1.1927	1.2241	.6036	1.2706	1.1511	1.1401	1.1652
15	1.2681	1.2453	.6602	1.3074	1.1311	1.1721	.6241
16	1.2784	1.2531	.5847	1.2151	1.2186	1.1927	.6089
17	1.2445	1.2056	.5281	1.2437	1.1828	1.1688	.602
18	1.2894	1.2519	.6653	1.2857	1.1921	1.2152	.5723
19	1.6141	1.6356	.9328	.7933	1.6133	1.5718	.7011
20	1.9525	1.8648	.9877	.9114	1.8171	1.664	.8916
21	1.9418	1.9384	.9593	1.7233	1.8614	1.8288	.9214
22	1.9201	1.9829	.9671	1.8913	1.8721	1.8218	.9122
23	1.9141	1.9224	.9231	1.8182	1.8711	1.8023	.9214
24	1.7505	1.7612	.8299	1.7071	1.7267	1.7154	1.6134
Max	1.9525	1.9829	.9877	1.8913	1.8721	1.8288	1.6134
Min	1.1088	1.0791	.5281	.7933	1.1195	1.0181	.5723
Avg	1.4560	1.4475	.7330	1.3958	1.4214	1.3882	1.1067

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 401 / 33 KV Bedag outgoing(
Crossove Feeder KV- 33 /
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	20.7248	22.284	10.6967	23.083	15.2664	19.616	23.7254
2	20.8322	21.6119	10.1538	22.6337	14.7006	18.7357	21.948
3	20.2133	20.9883	9.9909	22.1822	14.6463	17.7413	20.4024
4	20.0504	21.3763	10.0995	21.5621	15.0806	17.0153	19.8932
5	20.5339	21.8805	10.2624	22.1582	15.8939	16.8541	21.0334
6	24.6182	23.9198	11.797	25.1304	18.1802	19.7028	23.6809
7	23.9192	21.2763	12.6749	24.2159	19.9961	20.0103	25.5087
8	7.636	8.8181	2.7641	8.0933	7.6886	6.9365	8.1458
9	19.1952	20.942	13.5391	27.4166	22.1046	23.2237	26.0831
10	20.5099	21.9651	14.2261	29.1838	26.106	27.9104	27.6727
11	20.6814	21.3627	14.3987	25.0286	24.8606	27.2886	25.2378
12	22.4394	23.8044	9.4022	26.5403	21.1374	20.6991	15.272
13	11.2426	21.2649	13.1402	28.4591	19.7394	24.1381	5.1623
14	9.6456	20.9672	8.0361	28.5322	26.2375	25.6945	5.2687
15	11.3032	20.8877	14.1718	29.9669	26.1363	26.5387	2.7435
16	17.0965	15.0263	11.3483	26.1832	26.4232	25.9431	9.6022
17	7.3291	4.92	2.552	7.0159	8.8454	8.0636	5.9442
18	5.5076	3.2693	2.8475	5.7082	5.5127	5.6756	2.7435
19	6.7764	7.3508	3.6534	2.2862	6.39	6.7124	3.2007
20	7.796	8.1018	3.8552	1.829	7.204	7.8761	3.658
21	7.7297	7.9424	3.0727	3.7357	7.1131	7.8618	3.658
22	23.1573	25.6716	13.5391	16.9182	23.1253	26.0174	12.8029
23	22.5709	25.6945	13.059	16.7238	22.748	26.637	12.8029
24	22.2851	23.694	11.2397	20.1761	18.7386	22.4737	24.0078
Max	24.6182	25.6945	14.3987	29.9669	26.4232	27.9104	27.6727
Min	5.5076	3.2693	2.552	1.829	5.5127	5.6756	2.7435
Avg	16.4081	18.1258	9.6050	19.3651	17.2448	18.7236	14.5916

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 203 / 11 KV Krishna Ghat

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3254	.3696	.3688		.3948	.3536
2	.317	.349	.3102	.2766	.3452	.333
3	.314	.3483	.3071	.3155	.3391	.333
4	.3513	.3879	.3506	.3125	.3803	.3719
5	.3589	.423	.3582	.3285	.3856	.3742
6	.458	.5144	.3826	.3422	.3765	.3727
7	.4908	.5228	.3826	.3452	.394	.3757
8	.5556	.554	.4489	.4466	.4077	.423
9	.6531	.5952	.4748	.5098	.5205	.5685
10	.7072	.6165	.583	.5601	.5578	.6455
11	.7377	.6493	.6577	.5944	.6142	.6592
12	.7339	.6386	.631	.5777	.6188	.6699
13	.7141	.6081	.522	.57	.6112	.7026
14	.6882	.5556	.1082	.5205	.6523	.6676
15	.6592	.5632	.5266	.5228	.5944	.6508
16	.6295	.4313	.5761	.5289	.6089	.6203
17	.6889	.6051	.6112	.567	.6287	.6371
18	.6897	.6203	.3422	.5838	.6158	.6295
19	.583	.5556	.4329	.5388	.5632	.5815
20	.5342	.5129	.4443	.5357	.5327	.5472
21	.5098	.4999		.5304	.4748	.5365
22	.4976	.4443		.4877	.4611	.4809
23	.4649	.3445		.4146	.4146	.4176
24	.4481	.3498		.4009	.4054	.3688
Max	.7377	.6493	.6577	.5944	.6523	.7026
Min	.314	.3445	.1082	.2766	.3391	.333
Avg	.5463	.5025	.4410	.4700	.4957	.5134

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 205 / 11 KV JACKWELL

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 11 / OUTGOING

UTILITY

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2012	.2061	.2054		.1985	.1974
2	.2012	.2065	.2046		.197	.2012
3	.3109	.3589	.3666	.3746	.2545	.2862
4	.3681	.3711	.3658	.3742	.3719	.3677
5	.37	.3711	.3673	.3734	.3685	.3681
6	.3719	.3799	.378	.3776	.3719	.37
7	.3768	.3681	.3871	.3795	.3791	.3746
8	.3536	.3567	.3612	.3807	.3624	.3711
9	.3837	.3788	.3673	.3666	.37	.3883
10	.3708	.3837	.3788	.3647	.3807	.3837
11	.3688	.3879	.3723	.3647	.3871	.3837
12	.3685	.3841	.3662	.3681	.3795	.3715
13	.357	.3635	.3631	.3685	.3719	.3639
14	.3666	.3624	.3673	.3647	.3635	.3631
15	.3647	.3654	.3647	.3643	.3708	.3643
16	.3799	.365	.3673	.3692	.3708	.3662
17	.3681	.3559	.2237	.3681	.3681	.3841
18	.3708	.3608	.3586	.3601	.3605	.3643
19	.3696	.3666	.3628	.3601	.3616	.362
20	.3639	.3631	.3673	.3631	.3658	.3673
21	.3574	.3582	.3647	.3589	.3654	.3681
22	.3746	.3685		.3711	.3799	.3723
23	.2012	.2824		.3772	.3772	.3677
24	.2012	.1966		.3688	.3083	.2023
Max	.3837	.3879	.3871	.3807	.3871	.3883
Min	.2012	.1966	.2046	.3589	.197	.1974
Avg	.3384	.3442	.3457	.3690	.3494	.3462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244070 / 33/11 KV KRIPAMAI

Feeder No / Name : 201 / 11 KV KRIPAMAYA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1032	1.0321	1.1755	.4899	1.1233	1.0753
2	1.0259	.9951	1.0804	.9865	1.0455	1.0037
3	.9911	.9625	1.0835	.9578	1.0113	.9953
4	.9832	.9469	1.0688	.9202	.9784	.9778
5	.9731	.9031	1.0229	.8945	.94	.9501
6	.9876	.935	1.0583	.8922	.9928	.9318
7	1.0132	.9848	1.0846	.9368	1.0705	.9627
8	1.0687	.9427	1.1294	.986	1.0545	1.013
9	1.1247	1.1016	1.1488	1.1563	1.1146	1.068
10	1.3879	1.3538	1.3228	1.341	1.3094	1.1392
11	1.5604	1.4552	1.4583	1.4609	1.372	1.2563
12	1.6598	1.5331	1.5133	1.5263	1.4712	.6811
13	1.5639	1.4436	1.4941	1.5024	1.3702	.728
14	1.4171	1.3033	1.4418	1.3245	1.1614	.687
15	1.451	1.5096	1.5415	1.3609	1.3118	.5969
16	1.4006	1.4922	1.5243	1.4024	1.3287	1.2187
17	1.459	1.4678	1.5148	1.4465	1.4156	1.2595
18	1.3703	1.35	1.4399	1.4491	1.3807	1.2475
19	1.3243	1.3039	1.3399	1.3176	1.3033	1.2262
20	1.2834	1.3628	1.4395	1.3525	1.3668	1.2879
21	1.2905	1.323	.9362	1.3091	1.2925	1.2472
22	1.2989	1.3311	1.1563	1.2916	1.286	1.1814
23	1.29	1.2798	1.1315	1.2927	1.2582	1.1721
24	1.1332	1.2168	1.195	1.2321	1.1848	1.1113
Max	1.6598	1.5331	1.5415	1.5263	1.4712	1.2879
Min	.9731	.9031	.9362	.4899	.94	.5969
Avg	1.2567	1.2304	1.2626	1.2012	1.2143	1.0424

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244070 / 33/11 KV KRIPAMAI

Feeder No / Name : 202 / 11 KV GMIE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1904	1.419	1.1728	1.2384	1.5661	1.6194
2	1.2521	1.435	1.2651	1.0402	1.5463	1.6232
3	1.2102	1.4982	1.4876	1.0273	1.5295	1.4548
4	1.2231	1.5203	1.5745	1.0021	1.6347	1.4868
5	1.2894	1.4144	1.4975	1.454	1.5409	1.3626
6	1.3161	1.4419	1.5318	1.4426	1.3855	1.3443
7	1.4868	1.4053	1.4746	1.5737	1.48	1.3839
8	1.4129	1.233	1.3649	1.3763	1.4327	1.3733
9	1.688	1.4419	1.4411	1.669	1.4373	1.1241
10	1.9517	1.874	1.7505	1.8953	1.4899	1.2445
11	2.1201	2.098	1.8717	1.9563	1.8016	.961
12	2.0241	2.1293	2.0363	2.0698	1.5493	.7247
13	1.9342	1.8404	1.9357	1.7139	1.8557	.7651
14	1.8054	1.6347	1.8298	1.8198	1.8633	.9747
15	1.8854	2.0172	1.8198	1.973	1.8557	.7689
16	2.1247	1.9517	1.7421	1.8778	1.9227	.8063
17	1.9311	1.7574	1.7909	1.8755	1.8237	.7849
18	2.0348	1.643	1.8404	1.9288	1.7985	.6554
19	1.5028	1.4495	1.7002	1.7132	1.5501	.6866
20	1.5447	1.4708	1.7124	1.07	1.5554	.7583
21	1.3855	1.4975	.961	1.0143	1.5569	.7727
22	1.4205	1.4929	1.4655	1.028	1.6408	.8032
23	1.6248	1.6484	1.7208	1.656	1.7368	.9114
24	1.6674	1.5143	1.2384	1.6941	1.7421	.9099
Max	2.1247	2.1293	2.0363	2.0698	1.9227	1.6232
Min	1.1904	1.233	.961	1.0021	1.3855	.6554
Avg	1.6261	1.6178	1.5927	1.5462	1.6373	1.0542

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244070 / 33/11 KV KRIPAMAI

Feeder No / Name : 203 / 11 KV INDIAN OIL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8589	.8505	.9076	.6737	.8147	.8246
2	.804	.804	.8459	.6432	.7697	.8055
3	.7697	.7788	.8055	.6158	.727	.7575
4	.7667	.7598	.7933	.5967	.7141	.7438
5	.7552	.7491	.7804	.5891	.7004	.7225
6	.7895	.7987	.8032	.5914	.7301	.708
7	.8185	.82	.8147	.5838	.7506	.7316
8	.8192	.9114	.7994	.5624	.836	.7743
9	.9884	1.105	.9236	.5617	1.028	.9503
10	1.1279	1.1774	1.0517	.5914	1.0959	1.0433
11	1.2704	1.1645	1.1576	.5266	1.2978	1.1325
12	1.201	1.1896	1.0265	.4854	1.3344	1.2155
13	1.3664	1.3862	1.0555		1.3214	1.2102
14	1.3001	1.3146	1.1698	.9351	1.2399	1.1546
15	1.2376	1.3298	1.2186	.9084	1.2826	1.1317
16	1.2117	1.3161	1.2155	.8482	1.2216	1.1515
17	1.1599	1.2757	1.182	.8596	1.1782	1.1416
18	1.0905	1.1972	1.1164	.8436	1.1203	1.054
19	1.2795	1.2643	1.1881	.9511	1.1896	1.0951
20	1.3367	1.3519	1.0776	1.07	1.2193	1.1675
21	1.3016	1.2856	.9694	1.0898	1.2079	1.1812
22	1.2041	1.1942	.9351	1.038	1.0989	1.1081
23	1.1043	1.0745	.8109	.9808	1.0014	1.0021
24	.9656	.9945	.7255	.8733	.9114	.9015
Max	1.3664	1.3862	1.2186	1.0898	1.3344	1.2155
Min	.7552	.7491	.7255	.4854	.7004	.708
Avg	1.0636	1.0872	.9739	.7574	1.0330	.9879

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244070 / 33/11 KV KRIPAMAI

Feeder No / Name : 204 / 11KV WATER FILTER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2256	.2126	.2317	.173	.2164	.2202
2	.2256	.2119	.2324	.1715	.2134	.2187
3	.2568	.2858	.2705	.2827	.253	.2583
4	.2904	.301	.2934	.3132	.2827	.2858
5	.2873	.2949	.2934	.298	.2812	.3003
6	.2926	.2949	.2858	.2751	.2751	.3208
7	.2843	.2873	.2835	.2751	.2728	.285
8	.2614	.253	.2446	.234	.237	.2416
9	.3102	.25	.2507	.2416	.2423	.2439
10	.3445	.2896	.2743	.2309	.2881	.2881
11	.3551	.3338	.2865	.2812	.3086	.3033
12	.3589	.2789	.2995	.301	.2904	.2843
13	.3079	.3224	.3193	.3467	.3292	.3262
14	.3041	.2957	.2728	.3467	.3155	.3117
15	.2934	.3079	.2782	.3353	.3224	.314
16	.2721	.314	.3216	.3102	.2827	.3086
17	.3338	.3292	.3071	.2957	.3292	.3353
18	.3201	.3277	.3384	.301	.3262	.3246
19	.3094	.3163	.3399	.2919	.3307	.3292
20	.314	.3246	.3628	.317	.3422	.3224
21	.3132	.3208	.3323	.3071	.317	.3147
22	.301	.3102	.1067	.2987	.2835	.3102
23	.2614	.2728	.1242	.2568	.2652	.2507
24	.266	.2423	.1753	.2644	.237	.2545
Max	.3589	.3338	.3628	.3467	.3422	.3353
Min	.2256	.2119	.1067	.1715	.2134	.2187
Avg	.2954	.2907	.2719	.2812	.2851	.2897

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244070 / 33/11 KV KRIPAMAI

Feeder No / Name : 205 / 11KV SIDHIVINAYAK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		***		
2		***	***	***
3	***	***	***	***
4	***	***	***	***
5	***	***	***	***
6	***	***	***	***
7	***	***	***	***
8	***	***	***	***
9	***	***	***	***
10	***	***	***	***
11	***	***	***	***
12	***	***	***	
13	***	***	***	
14	***	***	***	
15	***	***	***	
16	***	***	***	
17	***	***	***	
18	***	***	***	***
19	***	***	***	
20	***	***	***	
21	***	***	***	
22	***	***	***	
23	***	***		
24	***			
Max	152.416	152.416	152.416	152.416
Min	76.208	76.208	76.208	76.208
Avg	145.488	132.5357	148.7870	138.56

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244070 / 33/11 KV KRIPAMAI

Feeder No / Name : 206 / 11KV GULMOHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2111	.2088	.2218	.1997	.2012	.2058
2	.1997	.208	.2126	.1974	.1981	.192
3	.1981	.1951	.2096	.1905	.1913	.1898
4	.1943	.1898	.2012	.1875	.1859	.1821
5	.1974	.1951	.2035	.1859	.1859	.1821
6	.2065	.2088	.2119	.1882	.1966	.1776
7	.2263	.221	.2271	.1859	.2119	.1844
8	.2058	.202	.202	.1913	.1829	.1905
9	.2187	.2164	.2271	.2042	.2119	.1707
10	.2477	.2172	.2553	.2187	.2401	.173
11	.266	.2469	.2637	.2301	.2347	.1661
12	.25	.2568	.2469	.2317	.208	.1738
13	.2431	.2294	.2522	.205	.2271	.1722
14	.2705	.2378	.2728	.2187	.2378	.1638
15	.2591	.2401	.2576	.2263	.2218	.1661
16	.221	.2515	.2629	.2233	.218	.1715
17	.2058	.2401	.237	.2241	.2149	.1738
18	.2172	.237	.2164	.2233	.2027	.1814
19	.2545	.2873	.2713	.2462	.2324	.2065
20	.285	.3064	.2919	.2774	.2637	.2492
21	.266	.2622	.2385	.253	.2576	.2401
22	.2599	.2561	.2393	.2355	.2515	.2393
23	.2484	.2431	.2263	.2332	.2469	.221
24	.2195	.221	.205	.2126	.2218	.2058
Max	.285	.3064	.2919	.2774	.2637	.2492
Min	.1943	.1898	.2012	.1859	.1829	.1638
Avg	.2322	.2324	.2356	.2162	.2185	.1908

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 201 / 11KV Jagdish IRON

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7602	4.7294	1.4335	1.8846	1.7169	.7634	.7533
2	.7484	4.0926	1.6004	1.7863	1.7063	.7246	.7678
3	.7529	4.5237	1.8107	1.7332	1.7459	.7605	.743
4	.7729	4.7097	1.7164	1.7787	1.4723	.7583	.769
5	.801	4.1103	1.8296	1.6637	1.4418	.7521	.7575
6	.7853	4.622	1.9052	1.7158	1.384	.6637	.7319
7	.6901	3.3124	1.0029	1.5682	.7729	.6622	.6538
8	.7506	2.6985	1.0242	.9926	.8086	.6599	.6573
9	1.0783	1.025	.2675	1.5375	.7155	.6203	.6173
10	2.4211	2.2211	.3315	.9511	1.0844	.7665	.6584
11	3.4612	2.7568	.5093	1.7414	1.1195	1.1064	.6523
12	3.5426	1.8016	.9431	1.4089	1.0515	.8619	.7285
13	3.3939	3.1604	.9054	1.2475	1.2727	.7529	.5502
14	3.5601	3.1581	.9808	.5952	1.8011	.7911	.5609
15	3.4679	2.9066		1.1172	1.7348	.7533	.554
16	3.9224	2.6932	.8288	1.0588	1.2165	.7216	.5586
17	2.2157	2.3335	.7748	1.7588	.8322	.7304	.5563
18	4.2448	1.5501	.643	1.041	.5586	.74	.5617
19	3.8553	2.0651	.7468	.8863	.7514	.5914	.5677
20	2.8946	2.3624	.6722	.5845	.8311	.7464	.57
21	3.183	1.6476	.852	.7903	.7389	.6996	.5738
22	3.5494	1.6705	.787	.8261	.7331	.6977	.5738
23	4.4971	3.2432	.8539	1.5753	.7267	.7564	.7031
24	2.4528	4.3484	1.1431	1.7947	1.3679	.762	.733
Max	4.4971	4.7294	1.9052	1.8846	1.8011	1.1064	.769
Min	.6901	1.025	.2675	.5845	.5586	.5914	.5502
Avg	2.4084	2.9893	1.0244	1.3349	1.1494	.7434	.6481

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 202 / 11 KV Mahabal

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4196	2.5476	1.2696	1.7147	2.7495	2.6916	2.4497
2	1.7124	2.6949	1.358	1.8496	2.4188	2.4546	2.5377
3	2.6295	2.5482	1.1763	2.2978	2.7046	2.7313	2.6242
4	2.4676	2.713	1.3392	2.1392	2.2351	2.669	2.5202
5	2.5953	2.6471	1.2752	2.1816	2.5087	2.5745	2.6347
6	2.0332	2.6236	1.358	2.1536	2.6338	2.6478	2.6236
7	2.6706	2.7484	1.1883	2.1674	2.5377	2.7151	1.3412
8	2.668	3.3668	1.6004	2.5245	2.7865	2.8921	.6584
9	3.475	1.6629	.7095	3.4619	3.77	1.5127	.4931
10	3.432	3.5035	.3048	1.813	3.368	2.6924	.6698
11	2.6193	3.3336	.3772	3.5383	3.848	2.0418	.6615
12	2.6096	2.063	.5281	3.0224	3.0193	3.2183	.6684
13	2.2834	3.1185	.5093	3.0689	3.1687	3.0765	.5144
14	2.4859	2.9649	.4904	3.1078	2.9356	2.9821	.5144
15	2.9064	3.2636	.547	3.6441	3.5105	3.3456	.5258
16	3.3684	3.8258	1.2574	3.0917	3.2335	2.5328	.5289
17	2.6865	3.6193	1.6409	3.7974	3.6402	2.8645	.5258
18	3.3387	3.3531	1.4861	3.5094	1.4403	1.7629	.5129
19	2.4307	3.0742	.9054	2.8102	2.5353	1.2529	.5213
20	2.5823	2.9752	.9335	1.0616	2.6833	2.9576	.5197
21	2.9911	2.9691	1.094	1.15	2.3312	2.4737	.5251
22	2.38	1.4647	.9055	1.8747	2.1281	2.1536	.5182
23	2.0584	2.2197	.8686	2.5308	2.2998	1.9905	.6322
24	2.5481	2.167	.7964	2.3468	2.7038	2.8235	1.929
Max	3.475	3.8258	1.6409	3.7974	3.848	3.3456	2.6347
Min	1.7124	1.4647	.3048	1.0616	1.4403	1.2529	.4931
Avg	2.6413	2.8112	.9966	2.5357	2.7996	2.5441	1.1521

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 203 / 11KV Shreeji

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3138	.6199	.2721	.6264	.5913	.6192	.6005
2	.3167	.5693	.2949	.6276	.6115	.5883	.5982
3	.3106	.5465	.2949	.596	.6428	.658	.63
4	.3073	.5769	.2469	.6451	.6463	.6733	.6409
5	.3068	.5876	.3018	.6074	.6455	.6518	.6287
6	.3106	.5533	.2883	.6143	.6603	.674	.6405
7	.3248	.562	.2286	.6444	.663	.6306	.6104
8	.6104	.5883	.3353	.6268	.6927	.7559	.4085
9	.8945	.5578	.5281	.5632	1.1569	.6249	.2911
10	1.061	1.1912	.6097	1.3839	1.4277	1.4356	.3522
11	1.089	1.3123	.6478	1.4849	1.5152	1.5004	.3863
12	1.2415	.7125	.679	1.4261	1.4179	1.4844	.3263
13	.9293	1.0976	.5975	1.4015	1.3679	1.4785	.2888
14	1.1709	1.2088	.547	1.3805	1.3619	1.3769	.25
15	1.2316	1.3011	.6224	1.318	1.286	1.4809	.2667
16	1.2082	1.3514	.6348	1.2933	1.3325	1.5088	.2644
17	1.2582	1.309	.5658	1.3121	1.3153	1.5453	.2942
18	1.23	1.1172	.5359	1.209	.6516	1.3951	.3018
19	1.1828	1.0845	.5281	1.0261	1.0631	.6676	.3109
20	.9213	.8703	.3475	.4992	.8184	.8386	.3056
21	.7701	.7291	.2572	.589	.5983	.6674	.3147
22	.5464	.3422	.1511	.5898	.5239	.5295	.3201
23	.6687	.551	.2012	.6219	.5872	.5921	.3909
24	.4195	.6698	.3018	.6213	.5936	.6058	.6089
Max	1.2582	1.3514	.679	1.4849	1.5152	1.5453	.6409
Min	.3068	.3422	.1511	.4992	.5239	.5295	.25
Avg	.776	.8337	.4174	.9045	.9238	.9576	.4179

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 204 / 11KV JK ICE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5356	1.85	.8718	1.8669	1.8572	1.8782	1.7526
2	1.5676	2.0064	.8192	1.8473	1.9056	1.7768	1.805
3	1.5166	1.9761	.823	1.7319	1.9102	1.7162	1.7993
4	1.5829	1.9277	.7621	1.7737	1.8808	1.7107	1.77
5	1.4853	1.7764	.719	1.7025	1.8549	1.7318	1.8698
6	1.5097	1.6568	.5811	1.6294	1.8976	1.5961	1.8703
7	1.5524	1.7162	.7773	1.8284	1.8053	1.7177	1.792
8	1.609	1.9165	.8215	1.9433	1.9349	1.826	1.5175
9	2.4562	1.2894	1.2437	1.2376	2.1072	1.1126	.961
10	2.9246	2.8349	1.358	1.3009	2.3079	3.0273	1.502
11	3.0472	2.8764	1.3392	2.9694	2.9062	3.1703	1.392
12	3.2842	1.5889	1.4712	2.9206	2.868	3.1226	1.4653
13	2.9112	2.29	1.3203	2.7949	2.7541	2.9477	.9496
14	2.6822	2.4501	1.5089	2.7069	2.5851	2.8407	.9419
15	2.7599	2.6833	1.5278	2.8816	3.0435	3.0941	.9534
16	3.0743	2.8694	1.4523	2.7648	3.3789	2.9465	.9419
17	3.8539	2.8766	1.4901	2.6995	3.1436	3.1615	.9358
18	3.0784	2.6763	1.1462	2.4463	1.4022	2.7355	.9724
19	2.5674	2.3655	1.1104	2.0352	2.3541	1.3199	.9793
20	1.9746	1.89	.8697	1.0921	1.9265	2.3213	.9785
21	1.0829	1.8153	.8482	1.8839	2.1148	1.8938	.9892
22	2.2104	1.1088	.7788	1.9037	1.9884	1.8069	.993
23	2.2273	2.1388	.7545	1.9632	2.1111	1.7796	1.4753
24	1.7143	1.9845	.8648	1.9166	2.0325	1.8948	1.7093
Max	3.8539	2.8766	1.5278	2.9694	3.3789	3.1703	1.8703
Min	1.0829	1.1088	.5811	1.0921	1.4022	1.1126	.9358
Avg	2.2587	2.1068	1.0525	2.0767	2.2529	2.2137	1.3465

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 205 / 11KV Shakti

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0274	1.2083	.5895	2.9158	1.2944	1.3706	1.374
2	1.0151	1.2488	.5375	2.729	1.3771	1.374	1.2586
3	.9406	1.206	.4578	2.7027	1.3679	1.2726	1.3401
4	1.012	1.2683	.5658	2.7861	1.3184	1.26	1.2161
5	.9869	1.1659	.5201	2.8711	1.3138	1.3077	1.2399
6	.9974	1.1557	.583	2.8807	1.3626	1.3398	1.3023
7	1.0743	1.1247	.6805	1.1896	1.4136	1.393	1.0715
8	1.1233	1.656	.7499	1.4784	1.5317	1.6661	.7061
9	2.2992	1.1104	1.2637	1.0288	2.2039	1.086	.4466
10	2.5385	2.6677	1.8673	1.2155	2.187	2.6744	.6162
11	2.7214	3.9642	1.8673	2.2807	2.8538	2.6086	.5918
12	2.7694	2.0317	1.9993	2.3144	2.5512	2.979	.5868
13	2.4638	3.1339		2.4451	2.6356	3.3497	.4527
14	2.1948	3.4442	1.6975	2.4596	2.0927	3.2854	.4161
15	2.601	3.6778	1.4712	2.6934	2.6008	3.6973	.439
16	2.8069	3.1954	1.905	2.4004	2.5756	4.0084	.4458
17	2.6111	4.0085	2.2068	2.6117	2.636	3.4802	.442
18	2.1701	2.798	1.0082	2.2131	1.1927	2.7366	.4633
19	2.495	2.2285	1.0185	2.2511	2.1589	1.0707	.4885
20	2.0683	1.7312	1.3203	1.0341	2.0706	1.989	.5053
21	1.8383	1.6501	1.4523	.003	1.8736	1.696	.519
22	1.448	.8337	1.5623	.9457	1.5516	1.435	.5167
23	1.4662	1.6773	1.6956	1.2315	1.6701	1.7985	.7266
24	1.0485	1.2708	.567	2.1384	1.318	1.3681	1.1635
Max	2.8069	4.0085	2.2068	2.9158	2.8538	4.0084	1.374
Min	.9406	.8337	.4578	.003	1.1927	1.0707	.4161
Avg	1.8216	2.0607	1.1994	2.0342	1.8813	2.0936	.7637

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 206 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6479	1.4022	.6401	1.0246	1.1972	.9811	.9595
2	.804	1.294	.5373	1.0913	1.2498	.7581	1.0978
3	.868	1.1663	.4835	.9214	1.1926	.6573	1.1492
4	1.0697	1.1263	.5121	.9469	1.0288	.7013	1.1507
5	.8734	1.1439	.3681	.855	.9496	.6162	1.0372
6	1.148	1.0783	.1787	.8436	1.1309	.6281	1.1515
7	1.0637	1.097	.16	.9884	.9206	.6261	1.0692
8	1.0563	.7964	.4239	.9385	1.0997	.5183	.6272
9	1.2917	.5388	.6979	.5243	1.2605	.3102	.3216
10	1.4573	1.1617	.4904	.5784	1.1808	.8872	.5578
11	1.8579	.6965	.8573	1.6042	1.1616	1.0547	.5927
12	1.592	.8695	.9054	1.814	1.4117	1.0216	.4725
13	1.8235	1.3514	1.226	1.8686	1.4015	1.0199	.3025
14	1.6509	1.3527	.8299	1.73	1.4108	.9897	.2942
15	1.5669	1.3939	.8488	1.7048	1.512	.9176	.3109
16	1.9096	1.7972	.4904	1.4952	1.5819	.893	.3292
17	1.6798	1.7435	.5847	1.5726	1.6592	.9925	.3224
18	1.6011	1.3457	.4805	1.5501	.8543	.8055	.3056
19	1.5219	1.3401	.4805	1.2978	1.1473	.4222	.3285
20	1.1706	1.3104	.2721	.6622	1.2483	.8802	.362
21	1.4407	1.2902	.2947	.7339	1.2239	1.0288	.3597
22	1.403	.599	.3361	.9984	1.074	1.0555	.3833
23	1.3947	1.3093	.6516	1.1607	1.2575	1.1	.9282
24	.9467	1.4582	.6099	1.0623	1.3374	1.0412	1.0922
Max	1.9096	1.7972	1.226	1.8686	1.6592	1.1	1.1515
Min	.6479	.5388	.16	.5243	.8543	.3102	.2942
Avg	1.3266	1.1943	.5567	1.1653	1.2288	.8294	.6461

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071] BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 207 / 11 KV Priyanka

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1573	2.3652	.6882	1.7995	.9656	1.7802	1.4739
2	2.1277	2.3077	.6718	1.7353	1.1774	1.7829	1.3991
3	2.1467	2.3556	.6097	1.6271	1.1858	1.7252	1.4095
4	2.1033	2.2725	.6562	1.6034	1.2331	1.5989	1.4693
5	2.1632	2.3145	.5647	1.5524	1.211	1.4853	1.3782
6	2.1635	2.3375	.5498	1.4979	1.2925	1.3344	1.2976
7	2.1454	2.5194	.8048	1.7482	1.3177	1.4291	1.2148
8	2.4234	2.6795	.7907	1.3862	1.2879	1.6179	1.1946
9	3.0315	2.1368	.9214	1.07	1.659	.9724	.7034
10	3.43	3.32	.985	1.1332	2.0595	2.1634	1.3245
11	2.8987	3.6007	1.0566	2.4973	2.1431	2.5078	2.2147
12	2.7347	2.3868	1.0751	2.5404	2.4282	2.512	.7827
13	2.4781	3.0921	1.1317	2.3918	2.4772	2.5663	.4824
14	3.1539	3.1913	1.1576	2.3784	2.3049	2.543	.7606
15	3.9859	3.5181	1.226	2.4908	2.5288	2.6109	.8109
16	3.7608	3.9232	1.1883	2.3693	2.5312	2.4444	.804
17	3.8904	3.957	1.1694	2.5394	2.5661	2.5804	.7918
18	3.0491	3.2753	.961	2.2973	1.2369	2.0755	.7888
19	2.4083	2.9295	.7282	1.877	2.0561	1.0791	.759
20	2.5911	2.5041	.8842	.8756	1.9479	1.7444	.7423
21	2.4962	2.4264	.8215	.434	1.8374	1.563	.7247
22	2.798	1.7307	.8939	.4412	1.8724	1.4857	.7308
23	2.8643	2.4334	.788	.5014	1.8976	1.5185	1.2155
24	2.5156	2.452	.6642	1.3779	1.2628	1.699	1.3525
Max	3.9859	3.957	1.226	2.5404	2.5661	2.6109	2.2147
Min	2.1033	1.7307	.5498	.434	.9656	.9724	.4824
Avg	2.7299	2.7512	.8745	1.6735	1.7700	1.8675	1.0761

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 210 / 11KV Saptrang

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3269	.8962	1.0924	.9619	.8676	1.1389	.5014
2	.3041	.6653	1.0099	.8589	.8383	1.0185	.4805
3	.3311	.9055	.7975	.7343	.8383	.788	.5729
4	.3437	.8238	.9328	.8048	.7922	.8779	.3544
5	.3269	.5959	.5731	.6836	.7922	.7186	.4298
6	.08	.5028	.4475	.5853	.7468	.5068	.4706
7	.3201	.4784	.1829	.3429	.5175	.4755	.5175
8	.0667	.1814	.2526	.4344	.3696	.5121	.3725
9	.7468		.7733		.7621		
10	.7922	.7922	.9808		1.6221	.7545	.0693
11	.8299	1.2449	.9808	.8676	1.5844	.9054	.061
12	.6097		.8676	1.3957	1.2449	.8299	.0747
13	.8299	.8676		1.5089	1.3203	.7545	
14	.9808	.9431	.9808	1.5089	1.1694	.5658	
15	1.5089	.9808	1.5844	1.5466	1.4712	.6036	
16	1.2826	.9808	1.358	1.5466	1.5089	.4904	
17	.7095	.5544	1.4335	.9431	1.4712	.8299	
18	.6838	.7733	.7545	1.5242		.3582	
19	.6401	.4835	.373	1.4098	.7468		
20	.6219	.591	.5544		.6161	.5249	
21	.5415	.5258	.3429	.4854	1.1506	.3224	
22	1.2071		1.0456	.5658	1.2071	.3658	
23	1.2449	1.226	.8215	.7545	1.1883	.3149	.3521
24	.3395	.9522	1.2071	1.0269	.8676	1.226	.6348
Max	1.5089	1.2449	1.5844	1.5466	1.6221	1.226	.6348
Min	.0667	.1814	.1829	.3429	.3696	.3149	.061
Avg	.6529	.7602	.8412	.9757	1.0302	.6765	.3763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 401 / 33KV Super Craft Foundry NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3392	2.4622	1.4712	.056	1.3306	5.5881	4.6457
2	1.3272	2.0164	1.358	.04	1.2895	5.9465	4.2678
3	1.3306	1.9433	1.4146	.0377	1.2895	5.6447	5.8574
4	1.3392	4.824	.1738	.056	1.2895	4.8388	5.3189
5	1.3312	5.919	.2012	.048	1.2757	5.2178	5.3823
6	1.3563	5.4298	1.4712	.04	1.2757	4.521	4.4411
7	1.3443	5.2949	1.358	.032	1.2889	5.4287	4.0106
8	1.689	5.7637	.14	.136	1.306	4.169	4.6685
9	1.7678	3.6866	.112		1.6369	3.738	3.5322
10	3.2082	5.1972	.124		1.6872	5.775	1.4883
11	5.8882	5.7099	.072	.12	3.3134	4.6793	1.4255
12	7.0028	4.8354		.156	2.9698	5.555	1.3683
13	7.5617	5.2538	.0377	.044	4.6159	5.5127	1.3546
14	6.7444	4.3279	.048	.04	5.2726	5.8385	1.4232
15	6.3186	4.3965	.056	.028	4.9125	5.1012	1.4232
16	6.9359	6.1471	.076	.0309	4.4187	4.4856	1.3889
17	6.7987	6.1523	.044	.3961	5.4509	4.3141	1.3717
18	7.0336	3.8706	.0995	.096	4.3553	1.9593	1.3203
19	6.9673	5.4218	.0789	.096	2.8464	1.3717	1.3546
20	5.4732	5.2966	.0857		1.3032	1.4329	1.3717
21	7.196	4.6313	.1097		1.3392	1.4197	1.3546
22	6.9925	3.7209	.072	.02	1.4129	2.6338	1.3203
23	5.5578	5.0446	.048	.024	2.8653	1.905	1.3969
24	5.2446	4.2895	1.358	.0412	1.8107	4.7336	2.7863
Max	7.5617	6.1523	1.4712	.3961	5.4509	5.9465	5.8574
Min	1.3272	1.9433	.0377	.02	1.2757	1.3717	1.3203
Avg	4.4895	4.6515	.4352	.0769	2.5232	4.2421	2.6780

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244118 / 33/11 KV SHANIVAR PETH MIRAJ

Feeder No / Name : 201 / 11 KV Shivaji Road Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3048	.3048	.3048	.3048	.3048
2	.2286	.2286	.2286	.2286	.2286	.2286
3	.2286	.2286	.2286	.2286	.2286	.2286
4	.2286	.2286	.2286	.2286	.2286	.2286
5	.2286	.2286	.2286	.2286	.2286	.2286
6	.2286	.2286	.2286	.2286	.2286	.2286
7	.3048	.2286	.2286	.2286	.2286	.2286
8	.2286	.2286	.2286	.2286	.2286	.2286
9	.2286	.2286	.2286	.2286	.2286	.2286
10	.2286	.2286	.2286	.2286	.2286	.2286
11	.3048	.3048	.3048	.2286	.3048	.2286
12	.3048	.3048	.3048	.2286	.3048	.3048
13	.3048	.3048	.3048	.2286	.3048	.3048
14	.3048	.3048	.3048	.2286	.3048	.3048
15	.3048	.3048	.3048	.2286	.3048	.3048
16	.3048	.3048	.3048	.2286	.3048	.3048
17	.3048	.3048	.3048	.2286	.3048	.2286
18	.3048	.3048	.3048	.2286	.3048	.2286
19	.4572	.381	.381	.381	.381	.381
20	.4572	.4572	.381	.381	.4572	.381
21	.4572	.4572	.381	.381	.4572	.381
22	.381	.381	.381	.381	.381	.381
23	.381	.381	.381	.381	.381	.381
24	.3048	.3048	.3048	.3048	.3048	.3048
Max	.4572	.4572	.381	.381	.4572	.381
Min	.2286	.2286	.2286	.2286	.2286	.2286
Avg	.3048	.2985	.2921	.2667	.2985	.2826

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244118 / 33/11 KV SHANIVAR PETH MIRAJ

Feeder No / Name : 203 / 11 KV Darga Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.448	1.448	1.6004	1.5242	1.5242	1.448
2	1.3717	1.3717	1.448	1.3717	1.448	1.3717
3	1.2955	1.2955	1.448	1.3717	1.3717	1.2955
4	1.2955	1.2955	1.448	1.3717	1.3717	1.2955
5	1.3717	1.3717	1.448	1.3717	1.3717	1.2955
6	1.448	1.448	1.5242	1.448	1.448	1.3717
7	1.5242	1.5242	1.5242	1.3717	1.448	1.3717
8	1.3717	1.3717	1.448	1.3717	1.3717	1.2955
9	1.3717	1.3717	1.448	1.3717	1.3717	1.3717
10	1.3717	1.448	1.448	1.448	1.3717	1.3717
11	1.448	1.448	1.448	1.448	1.3717	1.3717
12	1.448	1.448	1.448	1.3717	1.3717	1.3717
13	1.448	1.448	1.2955	1.3717	1.448	1.2955
14	1.448	1.448	1.2955	1.3717	1.448	1.448
15	1.3717	1.448	1.3717	1.448	1.3717	1.3717
16	1.3717	1.448	1.448	1.3717	1.3717	1.2955
17	1.448	1.5242	1.448	1.448	1.448	1.3717
18	1.448	1.5242	1.448	1.448	1.448	1.3717
19	1.7528	1.7528	1.7528	1.6766	1.7528	1.5242
20	1.9052	1.9814	1.9052	1.829	1.9814	1.7528
21	1.9052	1.9814	1.7528	1.9052	1.9814	1.7528
22	1.9052	1.9052	1.6766	1.829	1.9052	1.7528
23	1.829	1.7528	1.6766	1.7528	1.7528	1.6766
24	1.6766	1.6766	1.6004	1.6766	1.6004	1.5242
Max	1.9052	1.9814	1.9052	1.9052	1.9814	1.7528
Min	1.2955	1.2955	1.2955	1.3717	1.3717	1.2955
Avg	1.5115	1.5305	1.5147	1.4988	1.5146	1.4321

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244118 / 33/11 KV SHANIVAR PETH MIRAJ

Feeder No / Name : 204 / 11 KV Laxmi Market

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.829	1.829	1.9052	1.7528	1.7528	1.7528
2	1.6766	1.7528	1.829	1.6766	1.6766	1.6004
3	1.6766	1.6766	1.7528	1.6004	1.6004	1.6004
4	1.6004	1.6004	1.6766	1.6004	1.6004	1.5242
5	1.6004	1.6004	1.6766	1.6004	1.5242	1.5242
6	1.6766	1.6766	1.7528	1.6004	1.6766	1.6004
7	1.6766	1.6766	1.6766	1.5242	1.6004	1.5242
8	1.6004	1.6004	1.6004	1.5242	1.448	1.448
9	1.5242	1.5242	1.5242	1.5242	1.448	1.448
10	1.6004	1.6766	1.6766	1.6004	1.5242	1.448
11	1.829	1.9052	1.9052	1.6766	1.7528	1.3717
12	1.9814	1.9814	1.9814	1.7528	1.7528	1.6766
13	1.9814	2.0576	1.829	1.7528	1.9052	1.6766
14	2.0576	2.0576	1.9052	1.7528	1.9052	1.6766
15	1.9052	1.9814	1.9052	1.6766	1.829	1.6766
16	1.9052	1.9052	1.829	1.7528	1.7528	1.6004
17	1.9814	1.9052	1.9052	1.7528	1.9052	1.6766
18	2.0576	1.9814	1.9052	1.7528	1.9052	1.6766
19	2.5149	2.4387	2.4387	2.1338	2.3624	2.1338
20	2.7435	2.6673	2.6673	2.3624	2.5911	2.4387
21	2.6673	2.5911	2.5149	2.3624	2.5911	2.3624
22	2.4387	2.3624	2.21	2.21	2.2862	2.21
23	2.2862	2.2862	2.1338	2.1338	2.21	2.0576
24	2.0576	2.0576	1.9814	2.0576	1.9814	1.9052
Max	2.7435	2.6673	2.6673	2.3624	2.5911	2.4387
Min	1.5242	1.5242	1.5242	1.5242	1.448	1.3717
Avg	1.9528	1.9497	1.9243	1.7973	1.8576	1.7338

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244118 / 33/11 KV SHANIVAR PETH MIRAJ

Feeder No / Name : 205 / 11 KV Shivneri Chowk

SHEDDABLE URBAN

Feeder Feeder KV- 11 /
OUTGOING

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193	1.2955	1.2955	1.2193	1.2193	1.2193
2	1.1431	1.2193	1.2193	1.1431	1.1431	1.1431
3	1.1431	1.1431	1.2193	1.1431	1.1431	1.1431
4	1.0669	1.1431	1.2193	1.1431	1.0669	1.0669
5	1.0669	1.1431	1.2193	1.0669	1.0669	1.0669
6	1.2193	1.2193	1.2955	1.1431	1.1431	1.1431
7	1.2193	1.2193	1.2955	1.1431	1.1431	1.1431
8	1.2193	1.1431	1.2193	1.1431	1.1431	1.1431
9	1.2193	1.0669	1.2193	1.2193	1.1431	1.1431
10	1.2955	1.1431	1.2955	1.2955	1.2193	1.1431
11	1.2955	1.2193	1.3717	1.2193	1.2193	1.1431
12	1.2955	1.2193	1.3717	1.2193	1.1431	1.0669
13	1.2955	1.1431	1.2955	1.2193	1.1431	1.0669
14	1.2193	1.1431	1.2193	1.0669	.9907	.9907
15	1.1431	1.2193	1.2193	1.0669	1.0669	.9907
16	1.2193	1.2193	1.2193	1.1431	1.0669	1.0669
17	1.2955	1.1431	1.2193	1.2193	1.1431	1.1431
18	1.2955	1.2955	1.2193	1.2955	1.2193	1.1431
19	1.448	1.5242	1.448	1.448	1.448	1.2955
20	1.5242	1.6004	1.5242	1.5242	1.6004	1.448
21	1.6004	1.5242	1.5242	1.5242	1.5242	1.448
22	1.5242	1.5242	1.448	1.448	1.448	1.0669
23	1.5242	1.448	1.3717	1.448	1.448	1.3717
24	1.3717	1.3717	1.2955	1.2955	1.2955	1.2193
Max	1.6004	1.6004	1.5242	1.5242	1.6004	1.448
Min	1.0669	1.0669	1.2193	1.0669	.9907	.9907
Avg	1.2860	1.2638	1.3019	1.2415	1.2161	1.1590

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 248004 / 220 KV MIRAJ

Feeder No / Name : 401 / 33 KV SAHYADRI STARCH
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.4527	5.3841	5.4527	5.4527	5.5213	5.4527
2	5.4184	5.3841	5.727	5.2812	5.727	5.5556
3	5.3155	5.3841	5.3498	5.2126	5.5213	5.2126
4	5.144	5.3155	5.3498	5.2812	4.9383	5.3498
5	5.2812	5.3155	5.4184	5.1097	5.2126	5.4184
6	5.2126	5.4527	5.4184	5.1783	5.3841	5.487
7	5.4527	5.4184	5.4527	5.1783	5.4527	5.5899
8	5.2126	5.3155	5.3155	5.0412	5.2469	5.3841
9	4.8697	5.6242	5.2812	4.9726	4.904	5.487
10	5.1783	5.6584	5.3841	5.0755	5.2469	5.2469
11	5.2812	5.9328	5.4184	5.3841	5.2469	5.144
12	5.3498	6.1043	5.1783	5.2812	5.1097	5.1097
13	5.144	5.8642	5.3498	5.4184	5.144	5.0755
14	5.144	5.9671	5.3841	5.3155	4.9726	5.0755
15	5.3498	5.6242	5.3155	5.4184	5.2126	5.487
16	5.144	5.8299	5.2812	5.3155	5.3155	5.5899
17	5.0755	5.7956	4.8697	5.3498	5.2126	5.5556
18	5.0755	5.4527	5.2126	5.3155	5.0412	5.4184
19	5.3841	5.6927	5.487	5.2812	5.0412	5.5213
20	5.144	5.3155	5.4527	5.2126	5.1097	5.487
21	5.487	5.487	1.6461	5.3498	5.2469	5.4184
22	5.5899	5.7956	3.8066	5.8299	5.5213	5.4527
23	5.5899	5.727	5.2469	6.0014	5.5899	5.5899
24	5.3841	5.5899	5.3498	5.6927	5.5899	5.5899
Max	5.5899	6.1043	5.727	6.0014	5.727	5.5899
Min	4.8697	5.3155	1.6461	4.9726	4.904	5.0755
Avg	5.2784	5.6013	5.1312	5.3312	5.2712	5.4041

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071] BU 1228

Substation No/ Name :- 248004 / 220 KV MIRAJ

Feeder No / Name : 402 / 33KV SONI

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-APR-17
HR	Load (MW)
24	.4572
Max	.4572
Min	.4572
Avg	.4572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071] BU 1228

Substation No/ Name :- 248004 / 220 KV MIRAJ

Feeder No / Name : 403 / 33 KV MIRAJ

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	***	***	***	***	***
2	***	***	***	***	***	***
3	***	***	***	***	***	***
4	***	***	***	***	***	***
5	***	***	***	***	***	***
6	***	***	***	***	***	***
7	***	***	***	***	***	***
8	***	***	***	27.1605	28.9438	29.081
9	***	***	***	***	***	***
10	***	***	***	***	***	***
11	***	***	***	***	***	***
12	***	***	***	***	***	***
13	***	***	***	***	***	20.3018
14	17.9698	***	***	***	***	20.1646
15	***	***	***	***	***	19.9589
16	***	***	***	***	***	***
17	29.081	26.749	***	***	***	25.7888
18	22.7024	19.4788	21.9479	21.3992	22.0165	21.0563
19	25.1715	25.583	21.3992	23.1139	24.0741	23.1825
20	***	***	23.1825	27.915	29.2181	28.2579
21	***	***	15.9122	28.0522	28.2579	27.9836
22	***	***	***	***	***	***
23	***	***	***	***	***	***
24	***	***	***	***	***	***
Max	58.985	60.974	65.638	59.6709	62.963	60.4939
Min	17.9698	19.4788	15.9122	21.3992	22.0165	19.9589
Avg	42.1125	43.9530	46.5564	42.1268	45.4276	39.8520

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 248004 / 220 KV MIRAJ

Feeder No / Name : 404 / 33 KV Madhavnagar

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	8.1619	18.5643	16.3923	16.8038	17.0096	16.941
2	8.0933	18.0156	16.5295	16.8038	16.5295	17.0096
3	8.0247	17.4211	16.3923	17.0782	14.632	16.8724
4	7.8875	17.2154	15.2492	17.0782	15.0435	16.5981
5	8.2305	17.0096	15.5236	16.7352	15.455	17.7641
6	8.8477	17.3525	15.9351	16.1865	16.3923	18.4271
7	9.1221	17.4211	15.9122	15.1121	16.5981	14.9063
8	8.642	16.941	15.5922	15.1806	16.3237	12.9401
9	11.0425	18.8386	17.6955	15.7293	17.6955	9.2821
10	15.9122	22.6338	22.428	19.5931	21.0105	9.968
11	17.1468	24.8743	23.1139	22.5194	21.6278	10.0366
12	16.5981	26.1546	23.1596	24.3256	24.1884	9.625
13	18.7929	25.1258	24.4627	22.6338	21.1249	9.2821
14	17.5583	22.428	21.2849	20.8733	20.279	8.6191
15	18.45	22.5652	23.4568	24.8743	20.1189	9.4879
16	18.1756	24.3942	24.1198	23.5025	22.771	9.2135
17	17.9013	25.1486	22.428	22.7024	22.1537	8.4134
18	18.3128	23.7769	23.8455	19.8445	20.3932	7.9333
19	17.2154	22.2223	22.3595	18.4957	20.4618	7.3388
20	17.2154	22.0851	20.5304	19.3187	20.1189	7.8189
21	15.3635	20.1875	11.7056	17.0096	17.5355	7.9561
22	14.6777	20.3932	17.8556	17.5583	16.4609	8.0933
23	14.3347	21.7422	18.4957	17.4211	17.5583	7.5446
24	13.7174	21.3306	19.0444	17.2839	17.947	7.3388
Max	18.7929	26.1546	24.4627	24.8743	24.1884	18.4271
Min	7.8875	16.941	11.7056	15.1121	14.632	7.3388
Avg	13.7260	20.9934	19.3130	18.9443	18.7262	11.2254

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 248004 / 220 KV MIRAJ

Feeder No / Name : 405 / 33 KV Kupwad MIDC

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-MAR-17
HR	Load (MW)
1	5.8299
2	5.6927
3	5.487
4	5.3498
5	5.2812
6	5.4184
7	5.3498
8	4.8697
9	4.5268
10	4.2524
11	4.321
12	4.0466
13	4.321
Max	5.8299
Min	4.0466
Avg	4.9805

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 248004 / 220 KV MIRAJ

Feeder No / Name : 406 / 33KV KRIPAMAAI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	22.8053	23.4225	22.9425	13.7517	23.6626	24.0056
2	22.0851	23.2853	23.3539	18.1756	22.771	23.2167
3	21.5707	23.3196	24.3142	18.7243	23.1139	22.5995
4	21.605	23.0795	24.2455	18.4157	23.3196	22.8739
5	21.605	22.2908	24.0741	21.5707	22.1193	22.2222
6	22.7366	22.6338	23.937	21.5364	21.8793	21.262
7	22.9424	22.6681	23.8341	21.7422	22.5309	21.605
8	22.771	21.0905	22.5652	20.3361	22.4966	21.3649
9	26.9548	26.166	24.4514	23.7312	25.1372	21.9822
10	***	***	28.0865	25.3772	26.989	23.4225
11	***	***	***	26.7833	29.6639	21.7765
12	***	***	***	26.2346	29.7668	16.8724
13	***	29.6296	29.904	21.3992	29.9726	17.0096
14	***	29.4239	29.8354	28.2237	28.738	18.4843
15	***	***	***	27.9836	***	17.8327
16	***	***	***	28.5323	***	19.6846
17	***	***	29.9726	28.6008	***	19.1358
18	***	28.9095	28.498	27.4692	28.5322	18.6215
19	27.9493	27.8464	29.6983	25.8231	27.6406	19.5131
20	29.4239	29.8354	29.1496	24.2113	29.4925	21.3992
21	27.9836	28.9095	21.2277	23.8684	28.6351	20.9534
22	28.5666	28.8752	23.9712	23.7312	27.6063	20.5762
23	28.7037	27.6749	24.6228	27.7435	27.8121	21.0905
24	25.7202	26.3375	20.7134	25.3773	26.0632	19.856
Max	33.7106	32.4075	31.0014	28.6008	30.6242	24.0056
Min	21.5707	21.0905	20.7134	13.7517	21.8793	16.8724
Avg	27.4106	27.3391	26.3318	23.7226	26.6290	20.7233

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 248004 / 220 KV MIRAJ

Feeder No / Name : 407 / 33KV MIDC MIRAJ

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	15.0892	***	29.2181	25.2172	***	24.8743
2	14.952	***	28.6694	25.1486	26.7719	27.572
3	15.5007	***	28.8752	25.2172	26.9777	26.4975
4	15.8436	***	28.6008	23.7312	26.6347	26.5661
5	15.5693	***	28.0521	22.3595	27.572	26.5661
6	15.5007	***	26.2232	24.5313	25.0114	24.8057
7	15.7065	***	25.3544	23.2511	25.6745	25.9489
8	15.0206	***	22.8396	22.2223	24.8057	22.2909
9	21.262	***	27.9836	28.1893	***	17.0782
10	***	***	***	***	***	17.1468
11	***	***	***	***	***	15.9351
12	***	***	***	***	***	15.8665
13	***	***	***	***	***	14.632
14	***	***	***	***	***	15.7293
15	***	***	***	***	***	16.5981
16	***	***	***	***	***	16.6667
17	***	***	***	***	***	16.5295
18	***	***	***	***	***	16.3923
19	***	***	***	***	26.4975	17.0782
20	***	***	28.3951	27.9836	26.5661	17.2839
21	28.1893	***	9.4879	24.7371	25.0114	17.5583
22	27.915	***	19.9817	26.429	24.6685	17.7641
23	***	***	25.423	26.3604	26.7033	18.7015
24	27.3663	***	26.0174	***	27.8464	18.7015
Max	38.2031	51.1661	39.5748	42.9584	39.6434	27.572
Min	14.952	30.7042	9.4879	22.2223	24.6685	14.632
Avg	26.3146	38.7956	29.8669	30.4785	30.2965	19.7826

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 201 / 11KV JACKWELL LIS
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6141	1.3973	.7282	1.5822	1.395	1.4769	1.6682
2	1.6735	1.2999	.7282	1.6473	1.4041	1.5256	1.6057
3	1.6485	1.3081	.7282	1.6447	1.379	1.5147	1.5565
4	1.6478	1.5207	.6979	1.644	1.3573	1.556	1.5519
5	1.645	1.5718	.7095	1.6179	1.3672	1.5333	1.5425
6	1.6496	1.6417	.7468	1.5025	1.3432	1.557	1.4457
7	1.4965	1.4586	.5788	1.3676	1.3268	1.3698	1.337
8	1.3348	1.3263	.6224	1.3642	1.2523	1.2662	1.3325
9	1.3478	1.3666	.6036	1.3816	1.1591	1.2747	1.4091
10	.7537	1.528	.6602	1.2934	1.0921	1.5404	.7118
11	.7773	1.7237		1.4385	1.3832	1.5881	.7522
12	1.4888	1.4703	.6413	1.4788	1.3741	1.6164	.7606
13	1.4788	1.5105	.4904	1.5063	1.5421	1.5039	.7446
14	1.525	1.571	.5658	1.2487	1.6248	1.3954	.692
15	1.3837	1.5966	.7655	1.3536	1.4781	1.251	.6074
16	1.1484	1.467	.5788	.6424	1.3531	1.1801	.6516
17	1.0867	1.3363	.6348	1.1885	1.3478	1.2426	.6173
18	1.4971	1.3592	.6348	1.487	1.3401	1.3344	.6081
19	1.5009	1.6363	.7842	1.5061	1.6313	1.592	.6066
20	1.2313	1.608	.7733	.7743	1.449	1.4167	.6112
21	.9356	1.6019	.6348	.0015	1.318	1.1498	.6059
22	1.0715	1.2763	.679	1.0242	1.0924	1.3383	.7004
23	1.1808	.9374	.6722	1.267	1.2725	1.4884	.695
24	1.2563	1.0882	.5975	1.3543	1.2833	1.3078	1.3378
Max	1.6735	1.7237	.7842	1.6473	1.6313	1.6164	1.6682
Min	.7537	.9374	.4904	.0015	1.0921	1.1498	.6059
Avg	1.3489	1.4417	.6633	1.3049	1.3569	1.4175	1.0063

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 202 / 11KV GANPATI MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1028	2.1199	.9816	2.1704	2.1031	2.0557	2.1167
2	1.9669	1.9984	.929	2.0717	1.9303	1.9393	1.9174
3	1.9158	1.9349	.8939	2.0332	1.8404	1.8633	1.8678
4	1.905	1.8724	.8669	1.9909	1.7767	1.8206	1.8362
5	1.8813	1.8899	.929	1.9588	1.7415	1.8138	1.7954
6	1.9128	1.9468	.9114	2.0191	1.781	1.845	1.8008
7	1.9037	1.9372	.8842	1.9364	1.7275	1.7873	1.6762
8	1.8412	1.8259	.8417	1.813	1.727	1.7338	1.6991
9	1.753	1.6979	.8589	1.8459	1.7878	1.676	1.6853
10	1.9273	2.0199	1.0745	2.1203	1.9911	1.7089	.9663
11	2.5979	2.4771		2.5528	2.3809	1.9052	1.1401
12	2.6647	2.6124	1.2715	2.7077	2.4916	2.0957	1.2536
13	2.7698	3.1253	1.2048	2.7603	2.5163	2.1773	1.3032
14	2.6843	2.9828	1.2536	2.8299	2.4867	2.2238	1.3176
15	2.5282	2.7187	1.3032	2.7077	2.4722	2.2336	1.291
16	2.6386	2.5941	1.2715	2.6296	2.4532	2.2175	1.2605
17	2.7315	2.7526	1.2934	2.662	2.489	2.3617	1.2582
18	2.8353	2.8631	1.379	2.7641	2.545	2.393	1.3184
19	3.6121	3.5972	1.7528	3.3895	3.2948	2.9376	1.6575
20	3.8161	3.9061	1.8404	2.0889	3.5422	3.147	1.9364
21	3.3407	3.3796	1.5939	2.9236	3.2845	3.0173	1.8686
22	2.7905	2.7296	1.3289	2.8227	2.6732	2.5916	1.4106
23	2.5971	2.535	1.1919	2.469	2.4166	2.4516	2.4195
24	2.3251	2.3091	1.0692	2.357	2.1956	2.2321	2.2131
Max	3.8161	3.9061	1.8404	3.3895	3.5422	3.147	2.4195
Min	1.753	1.6979	.8417	1.813	1.727	1.676	.9663
Avg	2.4601	2.4927	1.1707	2.4010	2.3187	2.1762	1.6254

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 203 / 11KV SANGLI WADI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8519	1.8382	.8413	1.7225	1.7105	1.6995	1.6476
2	1.7764	1.7865	.7964	1.6812	1.6598	1.6233	1.6053
3	1.7421	1.7221	.7682	1.6613	1.6758	1.6029	1.5493
4	1.7269	1.7067	.7964	1.6408	1.6621	1.5851	1.531
5	1.7444	1.723	.8413	1.7764	1.5874	1.5817	1.5135
6	1.8038	1.8297	.8779	1.9929	1.6995	1.7048	1.6446
7	1.8442	1.8008	.8238	1.8991	1.7166	1.6575	1.6613
8	1.7429	1.7455	.7964	1.8236	1.6465	1.608	1.595
9	1.6952	1.7036	.8413	1.7164	1.6383	1.688	1.6095
10	1.8678	1.8844	1.0631	1.9073	1.8515	1.7749	.865
11	2.0904	2.0098		2.0012	1.8475	1.8084	.8817
12	2.0795	1.9782	.9214	2.0023	1.8176	1.7924	.8695
13	2.0435	1.8545	.8859	1.9479	1.7665	1.7968	.8665
14	1.6574	1.8838	.8954	1.9702	1.7254	1.8671	.8634
15	1.8251	1.9453	.9231	1.9614	1.7063	1.8446	.8551
16	1.8831	2.0056	.8859	1.9353	1.7063	1.7985	.8573
17	2.0077	1.9334	.9391	1.8671	1.7238	1.7524	.8375
18	2.0805	2.0062	.9036	1.8533	1.7524	1.8316	.8566
19	2.3663	2.3129	1.1517	2.2809	2.2517	2.1603	.9877
20	2.4809	2.488	1.267	1.3077	2.4128	2.2904	1.2338
21	2.472	2.3893	1.1517	2.1278	2.3373	2.1811	1.1767
22	2.441	2.3785	1.1641	2.1064	2.2275	2.2512	1.1462
23	2.1567	2.1362	.985	2.1114	2.0127	1.9845	1.0966
24	1.9651	1.9237	.8688	1.8741	1.7619	1.8244	1.8103
Max	2.4809	2.488	1.267	2.2809	2.4128	2.2904	1.8103
Min	1.6574	1.7036	.7682	1.3077	1.5874	1.5817	.8375
Avg	1.9727	1.9577	.9299	1.8820	1.8291	1.8212	1.2317

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 403 / 33 KV- BALAJIMANDIR

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9036	.9568	1.0099	1.1043	1.1163	.9671	.9671
2	.9036	.9036	.9991	1.0631	1.1043	.9671	.9036
3	.7888	.8939	.9465	1.0099	1.0402	.9568	.8939
4	.7973	.8413	.9362	.9465	.9362	.8413	.8505
5	.7973	.9036	.8413	.9465	.9671	.9134	.8505
6	.8059	.9134	.9036	.9134	.9134	.9231	.8688
7	.7042	.7716	.7888	.7716	.7888	.7802	.8059
8	.6173	.6836	.691	.6836	.7362	.7802	.7522
9	.7122	.7362	.7282	.7888	.8139	.8939	.8413
10	.8322	.7973		.9991	.9882	1.0099	
11	.9991	.9036		1.1043	1.0517	.9991	
12	.9259	.9882		1.0802	1.1963	1.0402	
13	.9259	.9362		1.0402	1.2094	1.0174	
14	1.0208	1.0923	1.0099	1.1043	1.2226	1.0402	
15	1.0745	1.1163	1.182	1.0802	1.2894	1.0517	
16	1.0208	1.1283	1.1568	1.0562	1.262	1.0402	
17	.9568	1.0174	1.1568	1.1317	1.0402	.9665	
18	.8842	.8139	1.0802	1.0631	.9259	1.0288	
19	.9259	1.0288	1.0288	1.0745	.9259	1.0802	
20	1.0288	1.0402	1.1963		10.5584	1.0288	
21	1.1043	1.0923	1.2346	.9556	1.0802	1.1163	
22	1.1694	1.2226	1.3289	1.1317	1.2357	1.1694	
23	1.1043	1.2226	1.3969	1.262	1.2357	1.1694	
24	.9465	1.0517	1.1694	1.2226	1.1443	1.0745	1.0631
Max	1.1694	1.2226	1.3969	1.262	10.5584	1.1694	1.0631
Min	.6173	.6836	.691	.6836	.7362	.7802	.7522
Avg	.9146	.9607	1.0393	1.0232	1.4493	.9940	.8797

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 404 / 33 KV -MJP SHERINALA STAGE NON SHEDDABLE EXPRESS HV FEEDERS
 NO- Feeder KV- 33 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1595	.1595	.1595	.1578	.331	.3327	.3327
2	.1595	.1595	.1578	.1595	.3293	.3327	.331
3	.1578	.1578	.1578	.1595	.3275	.331	.3293
4	.1595	.1578	.156	.3155	.6602	.487	.331
5	.3189	.1595	.1578	.3258	.6687	2.9116	.331
6	.1612	.3761	.1595	.3224	.3327	.7259	.7259
7	.1509	.3086	.3681	.1543	.3293	.7122	.7225
8	.1543	.1578	.1595	.1578	.3293	.3275	.551
9	.1526	.1578	.156	.1578	.4767	.3293	.7156
10	.3121	.1595	.1595	.1578	.7122	.331	.4001
11	.3681	.1595	.1595	.3155	.5007	.3293	.2286
12	.3086	.156	.2629	.0514	.3275	.5979	.4001
13	.1543	.3121	.3121	.1029	.3293	.5527	.4001
14	.1612	.3121	.1595	.1052	.719	.326	.4001
15	.1612	.1595	.1612	.1543	.7225	.487	.4001
16	.1612	.1612	.1578	.3521	.7156	.7122	.4001
17	.1595	.3052	.3155	.1543	.4989	.4955	.4001
18	.156	.3052	.3086	.2658	.4801	.3829	.4001
19	.3601	.1543	.1543	.2686	.6515	.5944	.4001
20	.3086	.156	.156		.7122	.7087	.4001
21	.1578	.156	.1543	.3018	.6515	.5024	.1715
22	.1595	.1595	.3189	.1543	.3327	.331	.1715
23	.1578	.1595	.3224	.1578	.3327	.6618	.4001
24	.1578	.1578	.3189	.1595	.3275	.5613	.5596
Max	.3681	.3761	.3681	.3521	.7225	2.9116	.7259
Min	.1509	.1543	.1543	.0514	.3275	.326	.1715
Avg	.2008	.1987	.2106	.2005	.4916	.586	.4126

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244080 / 33/11KV RISALA ROAD

Feeder No / Name : 204 / 11 KV Shivaji Mandai

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.522	.4954	.5152	.5335	.471	.4649
2	.4633	.4451	.474	.49	.4466	.423
3	.4557	.4321	.4588	.4458	.4351	.4191
4	.4458	.4306	.4565	.4367	.4222	.4054
5	.4351	.4291	.4504	.4291	.4207	.4031
6	.4428	.4397	.4626	.4237	.4169	.4009
7	.4778	.458	.4717	.423	.4237	.423
8	.4908	.4992	.4595	.4367	.4275	.4367
9	.4877	.4954	.4816	.4572	.4633	.4031
10	.5815	.5578	.538	.5037	.5144	.4504
11	.7606	.7476	.7064	.6287	.5944	.5601
12	.8002	.7895	.7849	.6562	.6569	.6112
13	.7979	.8032	.7758	.6386	.7034	.628
14	.7697	.8863	.7682	.6257	.7049	.6592
15	.7727	.8139	.7369	.6127	.6485	.6028
16	.775	.7385	.7446	.5281	.6699	.5906
17	.7659	.772	.7316	.6767	.6843	.6013
18	.772	.7819	.7956	.6432	.7034	.6219
19	.881	.8642	.8954	.7598	.7819	.7164
20	1.0113	1.0273	.9915	.865	.9328	.9099
21	.9694	.9823	.0015	.8756	.9099	.8825
22	.7628	.7628	.0838	.711	.7423	.6935
23	.6196	.6081	.6958	.5731	.5853	.5708
24	.5624	.5594	.6341	.5228	.5304	.5175
Max	1.0113	1.0273	.9915	.8756	.9328	.9099
Min	.4351	.4291	.0015	.423	.4169	.4009
Avg	.6593	.6591	.5881	.5790	.5954	.5581

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 201 / 11KV RAMMANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.4118	1.448	1.5844		1.5623	1.4118
2		1.3535	1.4118			1.5242	1.3032
3		1.3032	1.3394			1.5242	1.2308
4		1.3032	1.3394			1.448	1.2308
5		1.3394	1.3756			1.3717	1.2308
6		1.3394	1.3394			1.2574	1.1403
7		1.1946	1.1765			1.2193	1.1222
8		1.1946		1.2071		1.105	
9		1.1765				1.0669	
10		1.226				1.105	
11		1.358		1.448	1.1403	1.2071	1.2955
12		1.4335		1.5623	1.2127	1.358	1.2955
13		1.4712		1.448	1.2127	1.358	1.3336
14		1.5089		1.4861	1.2308	1.3957	
15		1.5089		1.5242	1.2127	1.358	
16		1.4712		1.5242	1.2127	1.358	
17		1.3957		1.5242	1.1765	1.3957	
18			1.4712	1.4861			
19	1.8099		1.9239		1.5623	1.6108	
20	1.9728	2.0452	2.0748		1.8671	1.9366	
21	1.9004	1.9004	1.9805		1.9433	1.9387	
22	1.9231		1.8484		1.829	1.7737	
23			1.8484		1.829		1.6598
24		1.6651	1.5927	1.6598		1.6766	1.6108
Max	1.9728	2.0452	2.0748	1.6598	1.9433	1.9387	1.6598
Min	1.8099	1.1765	1.1765	1.2071	1.1403	1.0669	1.1222
Avg	1.9016	1.4300	1.5836	1.4959	1.4524	1.4341	1.3221

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 202 / 11KV SHAMRAO NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1667	2.0675	.9511	2.1475	1.1233	2.0302	1.9776
2	1.0486	1.8892	.9145	1.057	1.0151	1.9151	1.8046
3	.9762	1.8183	.8779	.9884	.9473	1.8641	1.7604
4	.948	1.7852	.8871	.9541	.9122	1.8183	1.7276
5	.9214	1.7558	.9145	.9389	.8909	1.7665	1.6911
6	.9244	1.8015	.9328	.9579	.8878	1.7231	1.6587
7	.9511	1.7147	.8048	.9686	.8825	1.688	1.5905
8	.8848	1.6164		1.5699	.8269	1.5173	.7865
9	.8162	1.5653		.7842	.7781	1.4518	.7621
10	.8299	1.6386		.8391	.8101	1.4434	.7217
11	.8573	1.6758		1.7383	1.6134	1.3908	.9526
12	.9374	1.7783		1.858	1.6971	1.3691	1.0555
13	.9694	2.0431		1.9258	1.6787	1.3744	1.0852
14	.9701	2.1064		1.9479	1.6889	1.4251	.5594
15	.9503	1.9037		1.9944	1.6964	1.661	.5716
16	1.0029	1.903		1.9723	1.7223	1.8682	1.0532
17	.9549	1.0052		1.9784	1.698	1.7581	.9404
18	.9511	.98	.8676	1.9121	.8833	.9282	.9305
19	2.0965	1.0608	1.2071	1.0334	1.864	2.024	.945
20	2.6093	2.6559	1.3203	1.3458	2.3853	2.5278	1.2056
21	2.4806	2.6269	1.2826	1.3123	2.4059	2.5293	1.2247
22	2.5103	1.3344	1.2826	1.2102	2.3693	2.46	1.2026
23	1.31	1.2993	1.2071	1.1957	2.3403	1.2689	2.3419
24	1.2902	2.3144	1.0242	2.2428	1.1606	2.2618	2.2291
Max	2.6093	2.6559	1.3203	2.2428	2.4059	2.5293	2.3419
Min	.8162	.98	.8048	.7842	.7781	.9282	.5594
Avg	1.2232	1.7642	1.0339	1.4530	1.4282	1.7527	1.2824

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 204 / 11KV CIVIL HOSPITAL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0427	.3593		.3667	.0476	.3955	.3845
2	.0438	.3605	.3174	.045	.0472	.3951	.3845
3	.0423	.3402	.3174	.0457	.0469	.3947	.365
4	.0415	.3399	.3361	.0442	.0472	.3947	.3658
5	.0423	.3574	.3174	.0446	.0431	.3955	.3856
6	.0427	.3361	.3174	.0438	.0507	.357	.4222
7		.3547	.3734		.0164	.3722	.3639
8		.3547		.2309		.2427	
9	.0465	.3178		.0255	.0194	.4675	.0156
10	.0625	.4748		.0705	.0446	.5705	.0495
11	.0652	.5205		.493	.4012	.4924	.3913
12		.4775		.4111	.3726	.4062	.2054
13	.0027	.2107		.3562	.2168	.418	.3048
14	.003	.3395		.3867	.3795	.4187	
15		.3772		.3867	.354	.3814	
16	.0004	.3772		.157	.1898	.3449	
17	.0053			.1143	.3204	.3938	.0255
18	.0518	.0488	.3395	.3357	.0579	.0545	.0503
19	.4222	.0514	.3206	.0545	.4001	.4012	.0476
20	.3719	.4267	.1698	.0556	.3242	.2904	.0145
21	.3361	.4019	.3395		.3429	.3547	
22	.2054		.2075		.3048	.2054	
23			.3395		.2286		.1886
24	.0248	.3433		.3608	.0332	.338	.3646
Max	.4222	.5205	.3734	.493	.4012	.5705	.4222
Min	.0004	.0488	.1698	.0255	.0164	.0545	.0145
Avg	.0975	.3414	.3080	.2014	.1865	.3689	.2405

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 205 / Hanuman Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7644	1.3782	.6219	1.4609	.7438	1.4571	1.3568
2	.7194	1.3279	.6219	.743	.708	1.3824	1.304
3	.6897	1.2719	.5853	.7247	.6805	1.3573	1.2613
4	.679	1.2636	.5853	.7057	.6714	1.304	1.2415
5	.6767	1.305	.6219	.6943	.6653	1.3017	1.2323
6	.7179	1.3984	.695	.7514	.6699	1.2788	1.2803
7	.6866	1.3215	.6099	.6904	.6287	1.2171	1.1187
8	.6043	1.0517		1.1538	.5944	1.0692	.5738
9	.5327	.9937		.5456	.5365	.9526	.5091
10	.487	.9282		.5114	.5068	.8847	.4755
11	.4786	.8982		.9602	.9934	.8593	.9205
12	.4885	.9035		1.0106	1.0594	.8047	.8725
13	.5197	1.0707		1.0304	1.0601	.8192	.932
14	.519	1.0536		1.115	1.0829	.9663	.4976
15	.5594	1.0326		1.1653	1.0966	.9953	.5159
16	.522	1.0452		1.1066	1.1189	.9884	.5327
17	.5053	1.0505		1.099	1.0486	.9587	.5098
18	.5357	.5632	.5281	1.0944	.5426	.5182	.5037
19	1.5196	.7606	.8299	.807	1.4998	1.5333	.7057
20	1.8359	1.8229	.9054	.945	1.8191	1.7688	.8672
21	1.7458	1.8105	.9054	.8497	1.8267	1.8351	.8741
22	1.8358	.932	.9054	.8787	1.784	1.6466	.8825
23	.9427	.9153	.8299	.8886	1.6781	.8947	1.5885
24	.8391	1.4373		1.5436	.8078	1.5326	1.3718
Max	1.8359	1.8229	.9054	1.5436	1.8267	1.8351	1.5885
Min	.4786	.5632	.5281	.5114	.5068	.5182	.4755
Avg	.8085	1.1473	.7112	.9365	.9926	1.1803	.9137

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 206 / 11KV TRIMURTI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0197	1.8274	.8215	1.8934	.9747	1.8671	1.77
2	.9358	1.701	.8215	1.0037	.8954	1.7673	1.6217
3	.8932	1.6118	.7842	.9694	.8619	1.7101	1.5927
4	.8482	1.5798	.7842	.9183	.8261	1.6484	1.5287
5	.8284	1.589	.8215	.8916	.8078	1.5912	1.5082
6	.8185	1.6149	.7762	.8855	.8109	1.6057	1.467
7	.7979	1.5482	.7468	.8787	.7628	1.5394	1.4011
8	.7956	1.4449		1.5527	.7689	1.5272	.7385
9	.8772	1.6857		.8741	.7659	1.5684	.759
10	1.0433	2.1144		.993	.788	1.7962	.8345
11	1.2711	2.5072		2.5971	1.954	2.3933	2.1727
12	1.3542	2.5961		2.6337	2.0835	2.4249	2.303
13	1.3763	2.7621		2.716	2.0611	2.4181	2.2481
14	1.3824	2.7919		2.7213	2.13	2.4238	1.1767
15	1.4091	2.7191		2.7328	2.1598	2.4588	1.1965
16	1.4152	2.7652		2.7617	2.119	2.5385	1.2277
17	1.4365	2.7648		2.7465	2.1	2.6113	1.1911
18	1.3885	1.4441	1.3203	2.6596	1.0562	1.3222	1.1568
19	2.9408	1.5021	1.5466	1.4243	2.242	2.7908	1.1805
20	3.1603	3.2556	1.6004	1.5562	2.636	2.9751	1.3748
21	2.7999	3.0113	1.358	1.4007	2.6467	2.8704	1.3672
22	2.6852	1.4815	1.3203	1.2681	2.4272	2.4276	1.2864
23	1.2513	1.3085	1.2071	1.1492	2.2656	1.2338	2.0927
24	1.1888	2.0854	.8589	1.089	1.1104	2.1346	1.9033
Max	3.1603	3.2556	1.6004	2.7617	2.6467	2.9751	2.303
Min	.7956	1.3085	.7468	.8741	.7628	1.2338	.7385
Avg	1.4132	2.0713	1.0548	1.6799	1.5522	2.0685	1.4625

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 403 / 33 KV RISALA ROAD

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	9.7051	22.5663	2.9012	23.9747	19.5816	22.3023	21.9639
2	8.882	20.5236	2.9012	18.7929	17.764	21.0334	20.3521
3	8.5048	19.9749	2.7938	18.4157	16.7695	20.4504	19.5839
4	8.3676	19.6273	2.7938	18.107	16.461	19.7874	19.1381
5	8.2991	19.4215	2.6863	17.9698	16.2209	19.4444	18.8295
6	8.3676	19.6468	2.7401	17.9355	16.4266	19.4787	15.878
7	9.0535	20.3726	2.5789	18.4843	16.941	20.7476	17.356
8	8.6763	19.7897		20.5487	16.7695	19.9818	14.8834
9	8.5048	19.4662		17.6612	16.8038	20.2676	13.9575
10	9.9794	22.0422		18.69	17.5583	22.3481	15.1578
11	11.6255	26.9273		27.1149	23.4911	26.8382	21.022
12	13.0316	***		***	25.7099	28.594	24.2341
13	13.3745	***		***	26.317	29.5096	24.5427
14	12.7229	***		***	26.3809	29.8183	20.5762
15	12.4143	***		***	25.814	29.6228	20.0274
16	12.5858	29.6571		***	25.0698	***	20.6105
17	12.7915	26.3032		***	26.3958	***	21.1591
18	12.62	26.6118	4.3004	***	23.011	26.3032	21.1934
19	18.0841	27.8121	5.0926	28.9095	28.898	***	22.0508
20	20.2972	***	4.9794	***	***	***	27.1606
21	19.2885	***	4.3004	23.2167	***	***	26.9205
22	16.8073	27.9493	3.9609	20.9534	***	***	24.8286
23	11.6255	23.8683	3.7346	22.5995	26.2346	23.9369	24.705
24	10.5967	24.5599	4.3004	25.5728	21.0563	24.4971	23.0167
Max	20.2972	37.3161	5.0926	32.9218	33.1161	36.0232	27.1606
Min	8.2991	19.4215	2.5789	17.6612	16.2209	19.4444	13.9575
Avg	11.9252	25.5756	3.576	24.5795	22.7631	25.8177	20.7978

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 404 / 33KV KOLHAPUR ROAD

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	***		***	***	***	***
2	29.561	***		***	29.2182	***	***
3	28.6694	***	4.9291	***	27.8464	***	***
4	28.1894	***	4.7051	29.8354	28.0522	***	***
5	29.0124	***	4.7051	29.3553	28.1208	***	***
6	29.7668	***	4.7051	***	27.2292	***	***
7	29.7668	***	4.481	***	26.8176	***	***
8	26.8862	***		***	25.9946	29.904	25.3087
9	25.3086	28.9987		25.9946	24.8286	29.8811	26.1318
10	26.3375	***		28.8067	29.4239	***	27.1605
11	***	***		***	***	***	***
12	***	***		***	***	***	***
13	***	***		***	***	***	***
14	***	***		***	***	***	***
15	***	***		***	***	***	***
16	***	***		***	***	***	***
17	***	***		***	***	***	***
18	***	***	6.0585	***	***	***	***
19	***	***	6.7901	***	***	***	***
20	***	***	7.0165	***	***	***	***
21	***	***	6.5638	29.7668	***	***	***
22	***	***	6.5638	***	***	***	***
23	***	***	6.1111	***	***	***	***
24	***	***		***	***	***	***
Max	50.4801	50.2928	7.0165	43.8958	46.1363	48.5597	41.8382
Min	25.3086	28.9987	4.481	25.9946	24.8286	29.8811	25.3087
Avg	33.7674	37.6185	5.6936	35.8192	34.5803	36.3664	33.6291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244092 / 33 / 11 KV KOLHAPUR ROAD

Feeder No / Name : 201 / 11 KV SHASTRI CHOWK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0666	2.0477	.9431	1.0669	1.0669	1.8961	1.8772
2	1.8387	1.8387	.8865	.9907	.9145	1.7633	1.7633
3	1.8387	1.8387	.8865	.9907	1.7633	1.6871	1.6682
4	1.8199	1.8387	.8865	.9145	1.6871	1.6871	1.6682
5	1.8387	1.7814	.9054	.9145	1.6871	1.7437	1.6871
6	1.8764	1.8953	.9997	.9907	1.8199	1.8576	1.6305
7	1.9338	1.9149	.9242	.9907	1.7059	1.7059	1.6305
8	1.7633	1.8199	.8299	.9145	1.6305	1.5928	1.6305
9	1.7059	1.6682	.9054	.8383	1.6305	1.5543	.7621
10	2.0092	1.8576	.9431	.9907	1.6682	1.7814	.8383
11	2.142	2.1609	1.1317	1.1431	1.9715	1.8576	.8383
12	2.2748	2.2937	1.1883	1.2193	1.9715	2.1043	.9907
13	2.3699	2.7486	1.1883	1.2193	1.9338	2.1043	.9907
14	2.3321	2.5223	1.1506	1.2193	1.9526	2.2182	.9907
15	2.2559	2.3887	1.1694	1.2193	2.0092	2.149	.9907
16	2.3699	2.3887	1.0631	1.2193	2.0854	2.2182	.9907
17	2.3887	2.5026		1.2193	2.0477	2.2559	.9907
18	2.3314	2.4642		1.2193	2.0854	2.2559	.9907
19	2.7674	3.0135		1.3717	2.388	2.7478	1.1431
20	3.0905	3.2421		1.5242	2.6731	2.9765	1.3717
21	2.9199	3.0339		1.448	2.6166	2.8822	1.3717
22	2.806	2.7683		1.3717	2.5026	2.6731	1.2955
23	1.3717	2.56		1.2955	2.3321	2.4461	1.2193
24	2.3321	2.2567	1.0374	1.2193	1.1431	2.0862	2.105
Max	3.0905	3.2421	1.1883	1.5242	2.6731	2.9765	2.105
Min	1.3717	1.6682	.8299	.8383	.9145	1.5543	.7621
Avg	2.1851	2.2852	1.0023	1.1463	1.8869	2.0935	1.3098

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244092 / 33 / 11 KV KOLHAPUR ROAD

Feeder No / Name : 202 / 11 KV FRUIT MARKET

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1132	.1132	.12	.1132	.1132	.132
2	.1132	.1132	.1132	.12	.1132	.1132	.132
3	.1132	.1132	.1132	.12	.1132	.1132	.1132
4	.1132	.1132	.1132	.12	.1132	.1132	.1132
5	.1132	.1132	.1132	.12	.1132	.1132	.1132
6	.1132	.1132	.1132	.12	.1132	.1132	.132
7	.0943	.0943	.0754	.0686	.0754	.0754	.1132
8	.0754	.0754	.0754	.1029	.0754	.0943	.0754
9	.0943	.1132	.0943	.1132	.0754	.1132	
10	.1162	.1734	.1132	.1438	.0973	.1019	.0042
11	.008	.2056	.132	.1821	.135	.1159	.0084
12	.2404	.216	.1698	.168	.1185	.117	.0171
13	.164	.1594	.1509	.0278	.0985	.1392	.0107
14	.157	.1916	.1132	.0084	.132	.0973	.0038
15	.1915	.2003	.1698	.0232	.1517	.1732	.021
16	.2475	.2164	.1698	.0549	.1585	.206	.0286
17	.1842	.2193	.1543	.0503	.1383	.2385	.0488
18	.2239	.17	.1372	.17	.1046	.2266	.0572
19	.1927	.2198	.1715	.2115	.1509	.2132	.045
20	.1706	.1886	.1715	.1886	.1698	.1896	.003
21	.1698	.1698	.1715	.1509	.1698	.1698	
22	.1698	.1886	.1543	.1509	.1509	.1698	
23		.1509	.1543	.1509	.1509	.1509	
24	.132	.132	.1132	.12	.1132	.132	.132
Max	.2475	.2198	.1715	.2115	.1698	.2385	.132
Min	.008	.0754	.0754	.0084	.0754	.0754	.003
Avg	.1439	.1568	.1321	.1169	.1227	.1418	.0652

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244092 / 33 / 11 KV KOLHAPUR ROAD

Feeder No / Name : 402 / 33KV SHERINALA

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.7912	3.7346	3.8477	3.6523	3.9609	3.6214	3.7346
2	3.678	3.6214	3.7346	3.6008	3.7346	3.5082	3.6214
3	3.678	3.6214	3.7346	3.6008	3.6214	3.3951	3.6214
4	3.6214	3.6214	3.6214	3.6008	3.6214	3.3951	3.6214
5	3.8477	3.7346	3.6214	3.6008	3.6214	3.3951	3.6214
6	4.0175	3.8477	3.8477	3.7037	3.7346	3.6214	3.678
7	3.4517	3.7346	3.5082	2.9835	3.5082	3.1687	3.3951
8	3.2253	3.0556	3.1121	3.1379	3.0556	2.8292	3.3951
9	2.8292	3.1687	3.2253	3.4517	3.4517	3.2819	
10	3.7346	3.8477	3.7912	3.7912	3.8477	3.9043	
11	4.1307	4.3004	4.1872	4.6399	3.9609	3.9609	
12	4.5833	4.1872	4.5268	4.357	4.1872	4.3004	
13	4.1872	4.5833	4.4136	4.4136	4.357	4.0741	
14	4.0175	4.8097	4.357	4.3004	4.5268	4.0741	
15	4.0175	4.4136	4.4136	4.4702	4.4136	4.2438	
16	3.9609	4.2438	4.3004	4.0741	4.2438	4.2438	
17	4.0175	4.3004	4.2181	4.3004	3.9043	4.1307	
18	4.357	4.2438	4.2181	4.6399	4.0741	3.6763	
19	5.2624	5.0926	4.6811	5.4887	5.036	5.036	
20	5.0926	5.2058	4.9897		4.9228	5.036	
21	4.6399	4.7531	4.4753	4.0741	4.8097	4.4136	
22	4.4136	4.5268	4.6811	4.357	4.357	.2829	
23		4.2438	4.4239	4.5268	4.1872	4.3004	
24	3.9043	3.9043	4.0175	3.858	4.2438	3.9609	4.0175
Max	5.2624	5.2058	4.9897	5.4887	5.036	5.036	4.0175
Min	2.8292	3.0556	3.1121	2.9835	3.0556	.2829	3.3951
Avg	4.0200	4.1165	4.0812	4.0271	4.0576	3.7439	3.6340

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244094 / 33\11 KV VIJAYANAGAR

Feeder No / Name : 201 / 11 KV Government Colony

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6838	.6516	.6468			.6468	.6468
2	.6348	.6036	.5975			.6161	.6283
3	.6348	.6036	.5975			.6161	.6099
4	.6283	.6036	.5975			.6161	.6099
5	.6348	.5853	.6224			.6224	.6161
6	.6161	.6584	.6979			.6413	.6099
7	.6348	.6584	.6979	.6348		.6413	.6036
8	.5068	.567	.5175			.5228	.5914
9	.4755	.5121				.4755	.4854
10	.4572	.462			.4525	.4066	.4668
11	.439	.462			.4525	.4066	.4525
12	.4207	.4572			.5068	.4344	.4706
13	.4706	.4572			.5068	.4755	
14	.4706	.499			.5249	.4572	
15	.5068	.5359			.5068	.4805	
16	.4706	.4755			.5249	.4805	
17	.4887	.4755			.5304	.4706	
18	.5194	.5121			.4835	.5194	
19	.6661					.7468	
20	.7888	.8048			.7602	.8501	
21	.7442				.8059	.8507	
22	.7888	.823			.823	.8048	
23	.7442	.7392			.7682		
24	.7023	.6516	.6838			.7023	.6838
Max	.7888	.823	.6979	.6348	.823	.8507	.6838
Min	.4207	.4572	.5175	.6348	.4525	.4066	.4525
Avg	.5887	.5818	.6288	.6348	.5882	.5863	.575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244094 / 33\11 KV VIJAYANAGAR

Feeder No / Name : 202 / 11 KV Vijaynagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.5304	.5359	.5544	.5175	.5175	.5544
2	.5175	.4938	.5041	.5544	.5175	.4854	.5121
3	.5228	.4938	.5041	.5175	.4805	.4854	.4854
4	.5228	.4805	.4854	.5041	.4805	.4854	.4854
5	.5228	.462	.4904	.499	.4481	.4904	.462
6	.5041	.499	.4715	.4854	.4481	.4904	.4668
7	.4904	.4805	.4715	.4715	.4251	.5281	.4572
8	.4887	.462	.4805		.4435	.4481	.4481
9	.5121	.4805	.4938		.462	.4805	.462
10	.439	.5041	.4481	.439	.4435		
11	.439	.4854	.5175	.4572	.4572		
12	.4887	.499	.5175	.4755	.439	.4755	
13	.4887	.5175	.5359	.4755	.439	.4938	
14	.4887	.4938	.5359	.4938	.4938	.4251	
15	.5068	.4938	.5415	.4755	.4755	.499	
16	.4887	.4755	.5175	.4938	.4572	.4066	
17	.4572	.5175	.499	.4435	.4207	.4435	
18	.4938	.5175	.5175	.4938	.4525	.4344	
19	.591		.6516	.6089		.6154	
20	.7087	.7133	.724		.6878	.7095	
21	.7087		.7316	.7087	.6805	.6584	
22	.7265	.7316	.7577	.6653	.6878	.7023	
23	.7087		.7023	.6653	.6584	.6838	
24	.5914	.5487	.5914	.4938	.5914	.6099	.5729
Max	.7265	.7316	.7577	.7087	.6878	.7095	.5729
Min	.439	.462	.4481	.439	.4207	.4066	.4481
Avg	.5403	.5181	.5511	.5227	.5047	.5258	.4906

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244094 / 33\11 KV VIJAYANAGAR

Feeder No / Name : 203 / 11 KV BHARTI VIDYAPITH

Feeder KV- 11 / OUTGOING

DATE	31-MAR-17
HR	Load (MW)
11	.5175
Max	.5175
Min	.5175
Avg	.5175

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244094 / 33\11 KV VIJAYANAGAR

Feeder No / Name : 205 / 11 KV CENTRAL BUILDING

FEEDER Feeder KV- 11 / OUTGOING

DATE	30-MAR-17
HR	Load (MW)
10	.462
Max	.462
Min	.462
Avg	.462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244094 / 33\11 KV VIJAYANAGAR

Feeder No / Name : 402 / 33 KV KUPWAD CITY FEEDER NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 33 / INCOMING UTILITY

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		16.1866	1.8673	17.508	15.5476	16.0323	16.2986
2		14.9989	1.6975	16.47	14.7028	14.9468	14.9691
3		14.6434	1.6975	16.1272	14.257	14.501	14.5708
4		14.4502	1.6975	15.7842	13.9301	14.158	14.4159
5		14.7588	1.7364	15.3853	13.7929	13.5751	13.9535
6		15.6687	1.6804	15.4322	13.9644	14.4204	13.9015
7		15.3887	1.5524	15.4612	13.702	14.0763	13.2459
8		13.826	1.4003	12.1056	13.051	12.1251	11.8719
9		12.352	1.3306	10.8368	11.2117	11.0962	10.7785
10		12.1811	1.3306	11.9959	10.9717	10.5944	10.5292
11		11.8941	1.3443	11.8244	10.9248	10.3544	10.0584
12		12.3057	1.386	11.9959	10.6973	10.5258	10.0024
13	9.7188	12.4429	1.4415	12.1753	11.0962	11.2551	10.6287
14	12.2571	12.7515	1.4003	11.8273	10.6596	11.7353	9.6708
15	12.7389	12.8104	1.5684	13.7208	12.5361	12.0656	10.0823
16	12.867	13.0505	1.4146	13.0476	11.7936	12.0313	10.2195
17	11.0631	13.0522	1.4415	12.867	12.0222	12.1068	10.7682
18	13.0522	12.9767		12.9973	12.1948	12.3515	11.0083
19	15.4807	11.6942	2.0199	15.735	12.7229	14.8777	11.8655
20	19.8903	19.9217	2.2497	16.3581	17.7841	18.6832	15.8093
21	19.321	20.0715	2.2731	15.1829	17.6812	18.6626	15.7408
22	19.1942	19.4593	2.2177	16.23	17.723	17.7024	15.9122
23	18.9919	18.6272	2.1285	16.6724	17.687	18.2374	16.0494
24	15.4321	17.2119	1.7924	16.9811	17.2245	17.8138	17.6577
Max	19.8903	20.0715	2.2731	17.508	17.7841	18.6832	17.6577
Min	9.7188	11.6942	1.3306	10.8368	10.6596	10.3544	9.6708
Avg	15.0006	14.6968	1.6812	14.3634	13.6616	13.9137	12.9170

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244119 / 33/11 VISHRAMBAG STORES

Feeder No / Name : 203 / 11 KV VISHRAMBAG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.524	2.4394	2.4434	2.6337			2.2805
2	2.1216	2.1622	2.1719	2.3285			2.0851
3	2.1216	2.1068	2.1719	2.3285			2.0633
4	2.1216	2.1068	2.1719	2.3285			2.0633
5	2.1216	2.1622	2.1719	2.3285			2.0851
6	2.2497	2.2177	2.2262	2.3594			2.0633
7	2.1948	2.1491	2.1719	2.2262			1.9547
8	1.9185	1.9879	1.9547	2.009			1.7918
9	1.9004	1.9404	1.9404	1.9004		1.8107	1.7918
10	1.9547	1.9204	1.9404	1.9004		1.8656	1.885
11	1.8461	2.0851	2.1948	1.9204		1.9204	1.8656
12	2.1176	2.1948	2.1068	2.009		1.9753	1.8804
13	2.1176	2.524	2.2731	2.009		2.1399	1.9004
14	2.1176	2.3045	2.1622	2.3891		2.0851	1.9204
15	2.2805	2.2497	2.2965	2.3891		2.0851	
16	2.2805	2.3045	2.2965	2.3348		2.0851	
17	2.2262	2.3045	2.2405	2.2805		2.1719	
18	2.1719	2.3348	2.2916	2.3594			
19	2.8778	3.0407	3.1459	3.1276		2.7149	
20	2.9864	3.2036	3.3653			3.0407	
21	2.963	3.1493	3.1093	3.2373		2.8778	
22	2.963	3.095	3.1093			2.8778	
23	2.9384	3.0407	3.1093	2.6337		2.7692	2.5789
24	2.7069	2.6337	2.6606	2.8166	2.6337		2.552
Max	2.9864	3.2036	3.3653	3.2373	2.6337	3.0407	2.5789
Min	1.8461	1.9204	1.9404	1.9004	2.6337	1.8107	1.7918
Avg	2.3259	2.4024	2.4053	2.3568	2.6337	2.3157	2.0476

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 246001 / 110/33/11 KV VISHRAMBAG S/SN

Feeder No / Name : 201 / 11 KV WALCHAND

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.6668	.7468	.6592	.6554	.6554
2	.583	.6401	.6363	.6173	.6097	.644
3	.5601	.5982	.6097	.5754	.5677	.6287
4	.5335	.6097	.583	.5639	.5563	.583
5	.5373	.5982	.5716	.5677	.5373	.5449
6	.5906	.663	.5906	.602	.5944	.6783
7	.6516	.743	.7659	.7011	.6668	.663
8	.7011	.7202	.7735	.6325	.7583	.7773
9	.8154	.8612	.8497	.663	.8688	.9031
10	1.0212	1.1393	1.0326	.6706	1.0402	.9755
11	1.2803	1.3527	1.3108	.6744	1.166	.964
12	1.2651	1.3336	1.2651	.644	1.1812	1.0059
13	1.2574	1.1698	1.2612	.6592	1.1203	.945
14	1.0479	1.0326	1.1164	.6478	1.0402	.823
15	1.2117	1.1698	1.2117	.6554	1.185	.945
16	1.2003	1.2384	1.2346	.6592	1.2155	1.0555
17	1.1126	1.1355	1.0517	.6859	1.105	.8802
18	.8993	.9183	.9259	.6325	.9221	.7278
19	.8116	.823	.8307	.6859	.7964	.7659
20	.8383	.8573	.8269	.7545	.7926	.8078
21	.804	.8078	.4458	.6783	.6401	.7621
22	.7583	.8078	.6554	.7125	.6783	.743
23	.7735	.7964	.6744	.6821	.7354	.7202
24	.7202	.7354	.6592	.6706	.6744	.7011
Max	1.2803	1.3527	1.3108	.7545	1.2155	1.0555
Min	.5335	.5982	.4458	.5639	.5373	.5449
Avg	.8580	.8924	.8596	.6540	.8378	.7875

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 246001 / 110/33/11 KV VISHRAMBAG S/SN

Feeder No / Name : 207 / 11 KV DOORDARSHAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.105	1.0745	1.1164	1.086	1.0288	.9983
2	1.0136	.9831	1.0326	.9755	.9488	.9107
3	.9374	.9145	.9755	.9183	.8916	.8688
4	.884	.884	.9221	.8726	.8535	.8192
5	.8573	.8345	.8802	.8383	.804	.7811
6	.8612	.8497	.8573	.823	.8078	.7849
7	.9145	.9335	.9183	.8078	.8383	.8269
8	.8726	.8535	.865	.8078	.8116	.8269
9	.7545	.7583	.7545	.7811	.7316	.7164
10	.7506	.7392	.7506	.7697	.6897	.6973
11	.7811	.7583	.7659	.8002	.7087	.7392
12	.8078	.7697	.823	.7621	.7164	.7125
13	.7849	.8116	.8345	.7811	.7392	.7316
14	.8269	.8078	.7888	.8002	.7392	.7316
15	.804	.8269	.8269	.8345	.743	.7545
16	.8116	.8535	.8307	.8535	.7697	.7506
17	.8154	.8459	.8421	.8421	.7964	.7392
18	.8383	.8459	.8116	.8269	.7964	.7545
19	1.0212	.9793	1.0326	.9412	.9564	.8688
20	1.1469	1.1469	1.1393	1.0517	1.1241	1.0707
21	1.1507	1.1469	1.0364	1.0822	1.1164	1.0631
22	1.2041	1.1774	1.0479	1.0822	1.1355	1.0707
23	1.2574	1.2269	1.1355	1.1431	1.1431	1.1241
24	1.2041	1.2041	1.1279	1.1241	1.1203	1.0974
Max	1.2574	1.2269	1.1393	1.1431	1.1431	1.1241
Min	.7506	.7392	.7506	.7621	.6897	.6973
Avg	.9335	.9261	.9215	.9002	.8754	.8516

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 246001 / 110/33/11 KV VISHRAMBAG S/SN

Feeder No / Name : 209 / 11 KV INDUSTRIAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9814	1.989	2.0729	1.9357	1.9433	1.9357
2	1.829	1.8519	1.9357	1.829	1.829	1.8138
3	1.7528	1.7833	1.8595	1.7375	1.7452	1.7452
4	1.6918	1.7071	1.7985	1.6766	1.6766	1.669
5	1.6537	1.6994	1.7528	1.6309	1.6385	1.6156
6	1.6842	1.7299	1.7756	1.6766	1.6537	1.6309
7	1.7299	1.7528	1.7909	1.6537	1.6613	1.5699
8	1.5699	1.5699	1.6156	1.5318	1.5165	1.5089
9	1.387	1.4175	1.4251	1.3717	1.3717	1.3794
10	1.4403	1.5165	1.5089	1.3946	1.3641	1.3717
11	1.7452	1.7452	1.6918	1.4327	1.6309	1.4784
12	1.8519	1.8214	1.8747	1.4861	1.7375	1.5546
13	1.9281	1.9662	1.9204	1.547	1.7756	1.608
14	1.9814	1.9509	1.89	1.5165	1.7833	1.6156
15	1.89	1.9281	1.9281	1.5623	1.7985	1.6842
16	1.9662	1.9662	1.9052	1.608	1.829	1.6918
17	1.9281	1.989	1.9509	1.608	1.8442	1.6994
18	1.829	1.9585	1.8519	1.5546	1.829	1.6613
19	2.2405	2.3091	2.2329	1.8214	2.111	1.9433
20	2.5377	2.6139	2.4996	2.1338	2.4387	2.3472
21	2.4768	2.553	1.9662	2.2024	2.431	2.2939
22	2.3091	2.3548	2.1338	2.1795	2.2481	2.1643
23	2.3015	2.3091	2.0805	2.1719	2.2329	2.1643
24	2.1872	2.1872	2.0348	2.0805	2.1186	2.0348
Max	2.5377	2.6139	2.4996	2.2024	2.4387	2.3472
Min	1.387	1.4175	1.4251	1.3717	1.3641	1.3717
Avg	1.9122	1.9446	1.8957	1.7226	1.8420	1.7576

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 201 / 11 KV Madgule AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4806	2.3282	2.1948	.2103	.3658	.2172	2.6337
2	2.7221	2.2923	2.1582	.7973	.3982	.2172	2.5606
3	2.8597	2.2443	2.1582	.2126	.4298	.2195	2.5606
4	2.963	2.2443	2.1719	.2126	.4344	.2195	2.5701
5	3.0407	2.2805	2.1719	.2328	.4024	.2507	2.5339
6	3.1824	2.3529	2.1719		.3982		2.5339
7	2.4977	2.4253	2.3891	.2507	.3582	.2926	2.7149
8	.2926	.2172	.2507	.2481	.1629	.2926	.2149
9	.2561	.2172	2.5339	.985	2.4714	.2534	.2454
10	.2561	.2172	2.0485	1.7375	2.3998	.2534	.2715
11	.2195	.181	1.9022	2.1357	2.4714	.2172	.2686
12	.2172	.2172	1.8839	2.3102		.2507	
13	.1829	.197	1.8099	2.1719	2.2386	.2149	
14		.1791	1.7737	2.4714	2.2207	.2149	
15	.181	.181	1.7375	2.4691	2.1357	.2126	
16	.181	.181	1.7737	2.1719	2.0452	.1772	
17	.181	.2743		.2865	.2743	.1715	
18	.2896	.2804		.2172	.2743	.2427	
19	.3258	.3544		.2686	.3292	.2835	
20	1.7194	.3582		.3012	.3292	.3898	
21	.2896	.3258		.3045	.2896	.2865	
22		2.5339		1.5123	.2534	2.9683	
23		2.1948		.2561	.2534	2.8959	
24	2.364	2.3819	2.1948	.1829	.2896	.2534	2.8166
Max	3.1824	2.5339	2.5339	2.4714	2.4714	2.9683	2.8166
Min	.181	.1791	.2507	.1829	.1629	.1715	.2149
Avg	1.2715	1.1108	1.9603	.9542	.9229	.4781	1.8271

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 202 / 11 KV Atpadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.086	1.0608	1.2803	1.1458	.9877	1.1462	1.2437
2	1.2071	1.0608	1.2437	1.1203	1.0136	1.0745	1.2071
3	1.267	1.0608	1.2308	1.1576	1.0387	1.0608	1.2071
4	1.3535	1.0974	1.2308	1.1949	1.1222	1.0608	1.2308
5	1.3756	1.1584	1.2536	1.2696	1.3032	1.1827	1.267
6	1.4266	1.3394	1.2894		1.39		
7	1.4118		1.4118	1.3306	1.4118	1.3306	1.2308
8	1.1706	1.3394	1.2894	1.2936	1.4118	1.3676	1.182
9	1.2437	1.3394	1.3756	1.3032	1.4118	1.39	1.1765
10	1.2803	1.3032	1.3535	1.3535	1.4327	.4755	1.1641
11	1.3169	1.448	1.3169	1.3575	1.4327	1.448	1.1765
12	1.267	1.448	1.2308	1.379		1.448	
13		1.4327		1.4266	1.4327	1.3969	
14	1.3169	1.3611		1.3937	1.4685	1.3611	
15	1.267	1.3756		1.4266	1.4327	1.3466	
16	1.3032	1.448		1.4299	1.3969	1.3466	
17	1.5203	1.5089		1.4148	1.4327	1.3717	1.1765
18	1.6108	1.6126		1.4118	1.4685	1.5424	1.2071
19	1.8099	1.6655		1.4266	1.576	1.701	1.2127
20	1.6289	1.7193		1.4118	1.5927	1.7718	1.2437
21	1.5364	1.6651		1.4327	1.5565	1.576	1.2489
22		1.3756		1.4118	1.4327	1.5203	1.2803
23		1.3535		1.3253	1.2894	1.3756	1.2489
24	1.0608	1.0974	1.2803	1.1827	.9412	1.182	1.3169
Max	1.8099	1.7193	1.4118	1.4327	1.5927	1.7718	1.3169
Min	1.0608	1.0608	1.2308	1.1203	.9412	.4755	1.1641
Avg	1.3553	1.3596	1.2913	1.3304	1.3468	1.3251	1.2234

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 203 / 11 KV Pujarwadi AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905	.0549	.0549	.2353	.2561	.2172	.0366
2	.0914	.0549	.0549	.2172	.2896	.181	.0366
3	.0905	.0549	.0543	.2172	.2926	.181	.0366
4	.1075	.0549	.0724	.2507	.3258	.181	.0362
5	.1086	.0543	.0716	.2865	.3292	.181	.0362
6	.1097	.0543	.0716		.3258		.0362
7	.1086	.0543	.0724	.3224	.3582	.2378	.0358
8	.0732	.3258	.0716	.0895	.0543	.0543	.0358
9	.3292	.3258	.0362	.0905	.0537	.1829	.2896
10	.3658	.3801	.0362		.0537	.1829	.3224
11	.3841	.3982	.0362	.1267	.0537	.1448	.3544
12	.3658	.362	.0362	.1254		.2534	
13	.3292	.2865		.0905	.1433	.2865	
14		.3224		.0716	.1433	.2865	
15		.3258		.0543	.1433	.2835	
16	.1991	.362		.0537	.1433	.2303	
17	.0905			.0543	.0716	.0514	
18	.0905	.0526		.0549	.0716	.052	
19	.1086	.0709		.0905	.0716	.0532	
20	.1086	.0895		.0914	.0716	.0709	
21	.1086	.0905		.0905	.0716	.0716	
22		.0724		.2534	.2172	.0543	
23		.0549		.2865	.2172	.0543	
24	.0914	.0549	.0549	.2353	.2534	.2172	.0549
Max	.3841	.3982	.0724	.3224	.3582	.2865	.3544
Min	.0732	.0526	.0362	.0537	.0537	.0514	.0358
Avg	.1676	.1720	.0556	.1540	.1744	.1613	.1093

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 204 / 11 KV Pujarwadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1075	.1791	.1463	.1791	.1433	.1829	.1829
2	.1086	.1791	.1463	.1791	.1448	.1829	.1829
3	.1463	.1791	.1448	.1791	.1829	.1829	.1829
4	.1448	.2172	.1448	.1791	.181	.181	.181
5	.1829	.2172	.1791	.181	.1829	.2172	.181
6	.181	.2534	.2149		.181		.181
7	.2195	.2534	.2172	.2172	.2149	.2172	.181
8	.181	.2534	.2149	.2172	.1448	.2172	.1791
9	.181	.2172	.181	.181		.2172	.1991
10	.181	.2149	.1829	.1829	.1448	.2172	.2012
11	.181	.181	.1829	.1448	.1448	.181	.1991
12	.181	.181	.181	.1463		.181	
13		.1791		.181	.1448	.1433	
14	.181	.1791		.181	.1448	.1433	
15	.1791	.1448		.1433	.1448	.1417	
16	.1791	.1448		.1448	.1448	.1417	
17	.1791	.1715		.1791		.1372	
18	.2126	.1753		.181	.1448	.1753	
19	.2126	.2126		.1791	.2172	.1772	
20	.2126	.2507		.2172	.2172	.2126	
21	.2126	.2172		.2195	.2195	.2149	
22		.181		.181	.2195	.2172	
23		.1829		.1829	.1829	.181	.1829
24	.1063	.1791	.1829	.1791	.1448	.1829	.1829
Max	.2195	.2534	.2172	.2195	.2195	.2172	.2012
Min	.1063	.1448	.1448	.1433	.1433	.1372	.1791
Avg	.1748	.1977	.1784	.1807	.1710	.1846	.1859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 205 / 11 KV Madgule Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1791	.2149	.2195	.181	.2172	.2172	.1829
2	.2172	.2149	.2195	.181	.2507	.1791	.1829
3	.2195	.2149	.2172	.181	.2534	.1791	.1829
4	.2534	.2172	.2534	.1791	.2195	.2149	.181
5	.2561	.2534	.2865	.2149	.3258	.2534	.2534
6	.2896	.362	.394		.3582		.362
7	.3224	.362	.362	.3224	.2715	.3292	.362
8	.2534	.3658	.2865	.3582	.2865	.2926	.2865
9	.2507	.3292	.2534	.3258	.2507	.2896	.2715
10	.2149	.3292	.2507	.3258	.2149	.2534	.2743
11		.181	.2149	.3292	.2149	.181	.2172
12	.1791	.181	.2172	.2534		.1791	
13		.1791		.2195	.2172	.1791	
14	.1791	.2149		.1791	.2172	.1791	
15	.181	.2172			.2195	.1772	
16	.181	.181		.2149	.2195	.1772	
17	.1791	.1715		.2534	.2172	.1715	.2353
18	.2149	.2103		.2865	.2534	.2103	.2353
19	.2534	.3544		.2715	.3292	.2835	.2561
20	.3258	.3582		.2743	.3292	.3898	.2534
21	.3258	.3258		.2896	.3292	.3582	.2378
22		.2896		.2507	.2561	.2896	.2353
23		.2926		.2534	.2172	.2534	.2195
24	.181	.2149	.2561	.181	.2195	.2172	.2195
Max	.3258	.3658	.394	.3582	.3582	.3898	.362
Min	.1791	.1715	.2149	.1791	.2149	.1715	.181
Avg	.2328	.2598	.2639	.2512	.2560	.2372	.2447

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 206 / 11 KV Atpadi AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1791	.181	.1829	1.2178	1.9909	1.1584	.1829
2	.1772	.181	.1829	1.1641	1.9879	1.086	.1829
3	.2149	.181	.1829	1.1641	1.9004	1.0498	.1829
4	.2172	.181	.181	1.267	1.6461	1.0608	.181
5	.2743	.2149	.1791	1.9004	1.5927	1.0974	.181
6	.2534	.2149	.2149		1.5729		.2172
7	.2561	.2149	.2172	1.9909	1.9728	1.3032	.2172
8	.1848	.2149	.2149	.2534	.2149	.2172	.2149
9	2.0633	2.2923	.181	.2195	.2149	.2534	1.448
10	2.1357	2.3998	.181	.181	.2149	.2534	1.5223
11	2.0995	1.8099	.181	.1791	.2149	1.7375	1.5384
12				.1448		1.7375	
13		1.576	.181	.1433	.2172	1.6834	
14		1.6476	.181	.181	.2172	1.6118	
15		1.7375		.1829	.2195	1.6655	
16	1.4327	1.7375		.1478	.2195	1.0631	
17	.1791	.1715		.1829	.2195	.1715	
18	.2149	.1753		.181	.2195	.208	
19	.2149	.2481		.2172	.2561	.2481	
20	.2172	.2865		.2149	.2561	.2835	
21	.2172	.2534		.2481	.2534	.2507	
22		.2534			1.448	.2534	
23		.2195		1.9909	1.3032	.2172	
24	.181	.181	.1829	1.2178	1.7909	1.2308	.1829
Max	2.1357	2.3998	.2172	1.9909	1.9909	1.7375	1.5384
Min	.1772	.1715	.1791	.1433	.2149	.1715	.181
Avg	.5951	.7206	.1888	.6632	.8758	.8627	.5210

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 401 / 33 KV Soot Girani

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9012	3.0727	3.6214	3.1161	3.2579	3.0407	3.0727
2	3.083	3.1824	3.8409	3.1161	3.4019	3.1493	3.0727
3	3.2236	3.1824	3.8409	3.2236	3.3665	3.1493	2.9321
4	3.2579	3.0727	3.6923	3.2579	3.4385	2.963	2.9321
5	3.4019	3.1161	3.5837	3.1493	3.5294	3.0727	3.0087
6	3.3665	3.1161	3.546		3.6214		2.9012
7	3.4568	3.0087	3.2579	3.2579	3.638	3.0727	3.1161
8	3.1493	3.0087	2.9012	3.2579	2.5789	3.0727	2.8704
9	2.963	3.1493	3.2579	3.1493	2.6337	3.0087	3.0178
10	2.8532	3.1493	3.1493	3.1824	2.6886	3.1161	3.0178
11	2.7435	2.4434	3.0407	3.0407	2.7149	2.6606	3.0407
12	2.7149	2.4977	3.0407	3.0727		2.7149	
13	2.7149	3.4922	3.0407	3.0407	2.9012	2.6863	
14	2.7149	3.4385	3.0407	3.0407	2.7938	2.7938	
15		3.0407	3.1493	3.1824	3.0087	3.0298	
16	3.4019	3.4751	3.1493	2.9864	3.0087	2.6046	
17	3.2922	2.8807		3.0727	1.2894	2.5206	
18	3.1824	2.524		3.0407	1.3432	2.4966	
19	3.1824	2.8704		2.8235	1.3432	2.5514	
20	3.0727	2.9012		2.6863	3.0087	2.9767	
21	3.0407	2.9321		2.6063	2.9321	3.0624	
22		3.8009		3.0087	3.1493	2.9321	
23		3.5665		3.4208	3.0407	3.1493	
24	2.8235	3.0727	3.5117	.1629	3.2922	3.0407	3.0727
Max	3.4568	3.8009	3.8409	3.4208	3.638	3.1493	3.1161
Min	2.7149	2.4434	2.9012	.1629	1.2894	2.4966	2.8704
Avg	3.0734	3.0831	3.3332	2.952	2.8687	2.9072	3.0046

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,

KHARSUNDI

Feeder No / Name : 201 / 11 KV Nelkaranji AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3961		1.1694		
2		.3961		1.134		
3		.3961		1.2071		
4		.3961		1.226		
5		.415		1.3957		
6		.4527		1.6221		
7		.4527		1.9993		
8		.415		.0943		
9		.3801				
10	2.2148	.3772			2.2611	
11	2.2325		.1448		2.2611	
12	2.2786	.3961	.1267		2.2786	
13	2.2436		.1086		2.191	
14	2.191		.0905		2.0858	
15	2.1262		.1086		2.0683	
16	2.0908		.0905		2.0508	
17	.3721					
18	.3898					
19	.4527					
20	.4904					
21	.4715				.4382	
22	.4527				.4527	
23	.415					
24		.415	1.3392	1.1883		.415
Max	2.2786	.4527	1.3392	1.9993	2.2786	.415
Min	.3721	.3772	.0905	.0943	.4382	.415
Avg	1.3158	.4074	.2870	1.2262	1.7875	.415

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,

KHARSUNDI

Feeder No / Name : 202 / 11 KV Zare AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL

DESIGN TRANSFORMER

DATE	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7468		.0762		
2		.7316		.0762		
3		.7316		.0762		
4		.7011		.0762		
5		.6706		.0762		
6		.7011		.0914		1.0669
7		.945		.1067		
8		.2134		.0762		
9		1.1431				
10	.0762	1.2041			.061	
11	.061		1.326		.061	
12	.061	1.2193	1.2955		.061	
13	.061		1.2651		.061	
14	.0762		1.2955		.061	
15	.0762		1.3565		.061	
16	.061		1.1431		.061	
17	.0762					
18	.0762					
19	.1067					
20	.1219					
21	.1067				.0914	
22	.7621				.9907	
23	.8078					
24		.7926	.061	.0762		1.0212
Max	.8078	1.2193	1.3565	.1067	.9907	1.0669
Min	.061	.2134	.061	.0762	.061	1.0212
Avg	.1807	.8167	1.1061	.0813	.1677	1.0441

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,

KHARSUNDI

Feeder No / Name : 203 / 11 KV Zare Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3439		.3258		
2		.3258		.3077		
3		.3258		.2896		
4		.362		.2715		
5		.4163		.362		
6		.4344		.362		.4706
7		.4525		.3856		
8				.3801		
9		.4344				
10	.3982	.3801			.3258	
11	.4163		.362		.3258	
12	.3801	.362	.3982		.3077	
13	.3801		.4344		.3077	
14	.3801		.4163		.3077	
15	.3439		.4163		.3361	
16	.3439		.362		.362	
17	.4344					
18	.4706					
19	.5973					
20	.6154					
21	.543				.543	
22	.4706				.4706	
23	.4344					
24		.3982	.3258	.362		.362
Max	.6154	.4525	.4344	.3856	.543	.4706
Min	.3439	.3258	.3258	.2715	.3077	.362
Avg	.4435	.3850	.3879	.3385	.3652	.4163

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,

KHARSUNDI

Feeder No / Name : 204 / 11 KV Nelkaranji Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0724		.0905		
2		.0724		.0905		
3		.0905		.0905		
4		.1086		.1086		
5		.181		.1267		
6		.1991		.1629		
7		.2353		.2172		
8		.181		.1448		
9		.1086		.1267		
10	.1448	.1086			.1448	
11	.1448				.1629	
12		.1629			.181	
13	.1267				.1448	
14	.1086				.1629	
15	.1448				.1448	
16	.1629				.1448	
17	.1629					
18	.1629					
19	.1629					
20	.1629					
21	.1629				.1629	
22	.1267				.1448	
23	.1086					
24		.0905	.1086	.0876		.1086
Max	.1629	.2353	.1086	.2172	.181	.1086
Min	.1086	.0724	.1086	.0876	.1448	.1086
Avg	.1448	.1342	.1086	.1246	.1549	.1086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,

KHARSUNDI

Feeder No / Name : 205 / 11 KV Mitaki AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0724		.8063		
2		.0724		.8145		
3		.0724		.8145		
4		.0709		.8326		
5		.0905		.8688		
6		.0905		1.0136		
7		.0905		1.267		
8		.1086		.0905		
10	1.4118	.0905			1.448	
11	1.448		.0724		1.3575	
12		.0724	.0905		1.267	
13			.0905		1.267	
14			.0905		1.267	
15			.0905		1.2489	
16	1.4842				1.1946	
17	.1267					
18	.1267					
19	.1448					
20	.1267					
21					.1086	
22	.0905				.0905	
23	.0724					
24		.0724	.8326	.8326		.0724
Max	1.4842	.1086	.8326	1.267	1.448	.0724
Min	.0724	.0709	.0724	.0905	.0905	.0724
Avg	.5591	.0821	.2112	.8156	1.0277	.0724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,

KHARSUNDI

Feeder No / Name : 206 / 11 KV Walvan AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6097		.0762		
2		.5792		.0762		
3		.5792		.0762		
4		.5944		.0914		
5		.6401		.1067		
6		.7011		.0914		
7		.884		.0914		
8		.1219		.0762		
9		1.1584		1.1431		
10	.0914	1.2651			.0914	
11	.1067		1.3565		.0914	
12	.1067	1.2193	1.2803		.0914	
13	.1067		1.2193		.1067	
14	.1219		1.2346		.1067	
15	.1219		1.2498		.1067	
16	.1219		1.0974		.0914	
17	.1219					
18	.1219					
19	.1372					
20	.1372					
21	.0914				.1219	
22	.6097				.7011	
23	.6249					
24		.6249	.0762	.0762		.6859
Max	.6249	1.2651	1.3565	1.1431	.7011	.6859
Min	.0914	.1219	.0762	.0762	.0914	.6859
Avg	.1872	.7481	1.0734	.1905	.1676	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244041 / 33/11 KV ZARE SUBSTATION

Feeder No / Name : 201 / 11 KV Zare (Zare) AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.602	.4729	.4108	.1463	.1254	.1478	.4729
2	.5944	.4664	.3666	.1463	.1254	.1478	.4664
3	.5502	.4329	.3788	.1478	.1029	.1463	.5075
4	.5502	.5213	.4512	.1663	.1029	.1463	.5144
5	.5868	.6622	.5053	.1867	.1829	.1867	.5575
6	.9181	.9659	.6249	.2614	.2218	.2218	1.0936
7	1.0669	1.0562	.7335	.2241	.1829	.2126	1.0425
8	.1417	.1417	.1989	.1867	.1907	.1823	.2126
9	.1417	.156	.9568	.945	.7316	.1433	.1187
10	.2361	.1052	.9907	.9031	.9259	.104	
11	.12	.1052	.9907	.9214	.9332	.0876	
12	.1311		.884	.7282	.9214	.0867	
13	.1204		.8383	.8025	.9976	.1341	
14			.8383	.8619	.9701	.1389	
15		.1696	.9145	.8802	.9412	.1357	
16	.1928	.1387	.945	.8253	.8833	.1341	
17	.1781	.144	.1562	.1389	.128	.1326	
18	.1677	.1492	.1619	.1658	.1677	.1457	
19	.2507	.2172	.2629	.2454	.2126	.1753	
20	.3647	.2172	.2686	.2353	.2804	.3012	
21	.2561	.2561	.2353	.2172	.2481	.2534	
22	.8128	.5268	.1848	.2012	.2172	.7926	
23	.6308	.4572	.1478	.1448	.1829	.7316	
24	.6321	.5213	.4054	.1433	.1448	.1478	.5868
Max	1.0669	1.0562	.9907	.945	.9976	.7926	1.0936
Min	.12	.1052	.1478	.1389	.1029	.0867	.1187
Avg	.4202	.3754	.5355	.4094	.4217	.2098	.5573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244041 / 33/11 KV ZARE SUBSTATION

Feeder No / Name : 202 / Vibhutwadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0867	.0709	.0693	.0701	.0867	.0867	.0895
2	.0867	.0526	.052	.0693	.0867	.0867	.0709
3	.0857	.0537	.0347	.0701	.0867	.0867	.0526
4	.0867	.0914	.1052	.0876	.0686	.0867	.0895
5	.104	.1267	.1448	.1227	.104	.0867	.1086
6	.156	.1478	.2054	.1387	.1402	.1734	.2012
7	.1214	.1646	.1463	.156	.1214	.1387	.1254
8	.0693	.1063	.0857	.1402	.0867	.104	.1254
9	.052	.104	.1134	.1052	.1214	.104	.1029
10	.1387	.0876	.0857	.1214	.0693	.0693	
11	.0867	.1475	.0857	.0693	.1387	.0857	
12	.1052	.0995		.1387	.0867	.0995	
13		.0829	.0857	.104	.0867	.1017	
14	.0701	.0876	.1715	.0867	.0867	.1147	
15	.1052	.1052	.1372	.0867	.0867	.1174	
16	.104	.0926	.1029	.0867	.1734	.1475	.1227
17	.1227	.1753	.1029	.1387	.104	.1326	.1928
18	.1402	.0648	.12	.104	.0867	.1134	.1753
19	.1753	.1402	.1578	.156	.1907	.1526	.1402
20	.1448	.1734	.1753	.156	.1734	.197	.1928
21	.1829	.1578	.1402	.1214	.1387	.2195	.1402
22	.1267	.128	.1227	.0867	.1214	.1463	.1052
23	.1097	.1097	.0876	.0867	.104	.1097	.0876
24	.104	.0895	.0895	.0876	.104	.0867	.1075
Max	.1829	.1753	.2054	.156	.1907	.2195	.2012
Min	.052	.0526	.0347	.0693	.0686	.0693	.0526
Avg	.1115	.1108	.1140	.1079	.1106	.1186	.1239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244041 / 33/11 KV ZARE SUBSTATION

Feeder No / Name : 203 / 11 KV PIMPARI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0762	.0953	.9374	1.0242	.9503	.0953
2	.0953	.0572	.0762	.9061	1.0242	.9069	.0762
3	.0953	.0572	.0572	.9061	.9488	.8962	.0762
4	.0953	.0953	.0572	.9488	.9488	.8962	.0762
5	.1143	.1143	.0953	1.0279	1.1012	.8962	.0953
6	.1524	.1524	.1334	1.2483	1.2809	.9922	.1334
7	.1715	.1715	.1524	1.5203	1.4723	1.2003	.343
8	.1334	.1524	.1143	.1143	.1143	.1715	.2204
9	1.5546	1.7238	.0762	.1143	.1143	1.5223	1.5074
10	1.5074	1.5249	.1143	.1334	.1143	1.5893	
11	1.3443	1.5746	.0953	.1143	.0953	1.5364	
12	1.2651		.0953	.0953	.0953	1.4899	
13	1.1873		.0953	.0953	.0953	1.4251	
14			.0953	.0953	.0953	1.4251	
15		1.6194	.0953	.0953	.0953	1.4899	
16	1.1012	1.6575	.0953	.1143	.1143	1.2803	1.3435
17	.1524	.1265	.1143	.1143	.1143	.1143	.1715
18	.1334	.1265	.2286	.1715		.1143	.1715
19	.1715	.1524		.1715	.1905	.3048	.1905
20	.1524	.1715	.1715	.1905	.1905	.1715	.1905
21	.1524	.1715	.1715	.1524	.1715	.1524	.1715
22	.1143	.1143	1.0562	1.2763	.9962	.1143	.1143
23	.1143	.0953	1.1069	1.1305	.9762	.0953	.0762
24	.1143	.0953	.1143	1.0155	1.0688	.9667	.0953
Max	1.5546	1.7238	1.1069	1.5203	1.4723	1.5893	1.5074
Min	.0953	.0572	.0572	.0953	.0953	.0953	.0762
Avg	.4554	.4776	.1960	.5287	.5410	.8626	.2860

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 201 / 11 KV Hivtad AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1227	.1372	.1326	1.3123	.7621	1.2631	.1387
2	.124	.1372	.1147	1.2963	.8573	1.2631	
3	.1433	.1372	.1147	1.3443	.8097		
4	.1629	.1372	.1341	1.2955	.7621	1.3603	
5	.1829	.1772	.1715	1.3599	.9175	1.4586	
6	.2587	.2229	.2454	1.704	1.1279		
7	.2218	.1991	.2126	2.0317	1.7737	1.9662	
8	.2058	.1189	.1753	.08	.1715	.1357	
9	2.2283	2.4863	.1235	.0724	.1107	1.9524	
10	2.1338	2.4034	.1107	.0914	.0926	1.9109	
11	2.4034	2.1628	.1128	.096	.0655	1.8176	
12	2.2283	2.2611	.096	.1067	.0857	1.8176	
13	2.2939	2.2672	.1113	.0934	.0876	1.6446	
14		2.1125	.096	.1067		1.7604	
15	1.9662	1.9433	.0987	.1067	.0983	1.8027	
16	.7621	1.7185	.1082	.1341	.1134	1.9433	
17	.08	.1311	.1128		.128	.1311	
18	.1715	.1341	.1143	.141		.1509	
19	.2058	.213	.1981	.2774		.2601	
20	.2401	.2743	.2401	.2401		.2804	
21		.2401	.2374	.1715		.2374	
22	.2229	.1677	1.3717	.6706		.1907	
23	.1372	.1372	1.3443	.7811		.1595	
24	.1372	.1372	.1341	1.3443	.7907	1.2483	.1387
Max	2.4034	2.4863	1.3717	2.0317	1.7737	1.9662	.1387
Min	.08	.1189	.096	.0724	.0655	.1311	.1387
Avg	.7560	.8357	.2463	.6460	.5150	1.1252	.1387

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 202 / 11 KV Shetphale AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8124	.7621	.5792	.1791	.1543	.1829	
2	.7621	.9335	.5719	.1772	.1543	.1791	
3	.7716	.7621	.5498	.1791	.1543	.1848	
4	.7655	.8573	.5647	.1646	.1543	.2012	
5	1.0883	.8383	.7316	.1829	.2229	.2218	
6	1.3108	.9145	.9374	.2801	.2915	.2801	
7	1.5415	1.2955	1.1069	.3018	.2572	.2987	
8	.2229	.1886	.2401	.1753	.1715	.1829	
9	.1772	.12	1.1584	1.2803	1.1069	.1829	
10	.1372	.1254	1.1574	1.2193	1.1561	.181	
11	.1029	.1254	1.1683	1.2254	1.2334	.1612	
12	.12	.1417	1.1227	1.1431	1.2498	.1772	
13	.12	.1402	1.1561	1.1584	1.2597	.1543	
14		.1578	1.1385	1.1736		.1526	
15	.1372	.1595	1.0936	.1147	1.2717	.1677	
16	.1543	.1677	1.0494	.8802	1.2334	.1658	
17	.1829	.1865	.197		.176	.1844	
18	.2401	.2058	.1966	.1143		.2204	
19	.2915	.2507	.2427	.2401		.2686	
20	.2572	.3326	.3224	.2915		.3475	
21		.2957	.2896	.2743		.2926	
22	.2572	.7407	.2561	.1663		1.0395	
23	.9431	.7099	.1848	.1715		.9602	
24	.8749	.7621	.6097	.1848	.1543	.181	.9061
Max	1.5415	1.2955	1.1683	1.2803	1.2717	1.0395	.9061
Min	.1029	.12	.1848	.1143	.1543	.1526	.9061
Avg	.5123	.4656	.6927	.4903	.6119	.2737	.9061

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 203 / 11 KV Banpuri AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5898		.4755	.1772	.1372	.1433	
2	.5571	.6325	.4344	.1734	.1372	.1448	
3	.5121	.6859	.4344	.1715	.1372	.1463	
4	.5218	.6859	.4904	.1865	.0137	.1267	
5	.6401	.6554	.5792	.2103	.1543	.1646	
6	.9831	.6097	.6249	.2328	.1715	.2218	
7	1.0688	1.1949	.7682	.2614	.2229	.2587	
8	.2012	.1829	.2683	.2035	.1753	.1612	
9	.1372	.1029	.8855	.8482	.8322		
10	.12	.1052	.8002		.8322	.1578	
11	.12	.12	.6802	.6325	.8697	.1772	
12	.12	.1341	.5719	.6249		.1509	
13	.1029	.1658	.4793	.6401	.8192	.1524	
14		.1677	.4858	.5864	.7682	.16	
15	.1029	.1715	.4778	.5335	.6316	.1406	
16	.1219	.2012	.4633	.4572	.5487	.1581	
17	.1334	.2058	.192		.192	.192	
18	.1372	.2303	.213	.1524		.213	
19	.1543	.2058	.2058	.2401		.2401	
20	.1715	.2835		.2229		.2896	
21		.2629	.2835	.2058		.2507	
22	.2229	.6097	.2427	.1715		.7282	
23	.7716	.5335		.1543		.6249	
24	.583	.6097	.4755	.1753	.1372	.1417	.3292
Max	1.0688	1.1949	.8855	.8482	.8697	.7282	.3292
Min	.1029	.1029	.192	.1524	.0137	.1267	.3292
Avg	.3669	.3807	.4787	.3301	.3988	.2237	.3292

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 204 / 11 KV Hivtad Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.124	.1029	.1052	.1307	.1595	.1294	
2	.1052	.1029	.1052	.1294	.1543	.128	
3	.1063	.1097	.124	.128	.1543	.1294	
4	.1227	.1029	.1254	.1075	.1543	.1097	
5	.1417	.1372	.1646	.1267	.1543	.1478	
6	.2328	.1724	.1829	.2195	.1715	.2241	
7	.2149	.1829	.2218		.1715	.4108	
8	.1753	.12	.1677	.2254	.1372	.1326	
9	.1402	.128	.1372	.1086	.1052	.1134	
10	.1074	.1254	.1311	.1029	.1063	.112	
11	.0914	.1214	.112	.1029	.1254	.0949	
12	.1147	.1372	.1107	.1134	.124	.0934	
13	.1029	.1311	.108	.1067	.1052	.1097	
14	.1067	.1341	.128	.012		.1128	
15	.0914	.1402	.1296	.124	.208	.1303	
16	.0914	.1578	.1475	.1372	.2629	.1219	
17	.1372	.1772	.1734		.1715	.1638	
18	.1715	.1753	.181	.0177		.1844	
19	.2058	.2103	.2195	.1715		.2279	
20	.2126	.2172	.2149			.2172	
21		.181	.1829			.1991	
22	.1715	.1433	.1629	.1372		.1772	
23	.1029	.1267		.1715		.1402	
24	.1254	.1097	.1063	.1307	.1543	.2957	.1214
Max	.2328	.2172	.2218	.2254	.2629	.4108	.1214
Min	.0914	.1029	.1052	.012	.1052	.0934	.1214
Avg	.1390	.1436	.1496	.1252	.1541	.1627	.1214

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 205 / 11 KV Shetphale Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.2987	.2987	.3174	.2058	.2926
2	.2987	.1715	.2987	.3109	.2058	.2957
3	.2987	.2743	.2987	.3142	.2218	.2987
4	.2641	.2743	.3395	.2896	.2241	.3326
5	.3772	.3258	.4527	.3292	.3395	.3109
6	.5281	.3772	.5658	.4805	.4338	.4152
7	.4904	.4115	.5281	.4715	.3772	
8	.3258	.3086	.3982	.2926	.3429	.3326
9	.3109	.2572	.3544	.2534	.3109	.2743
10	.2743	.2987	.3582	.2658	.2896	.2353
11	.2743	.2715	.3475	.2572	.2686	.2328
12	.2058	.2865	.3326	.0287	.2481	.2481
13		.3189	.3224	.2835	.2454	.2686
14	.2561	.3189	.2865	.2743	.2658	.2865
15	.2353	.3224	.298	.2743	.2865	.3189
16	.181	.3224	.3012	.2401	.2896	.3012
17	.2572	.3155	.3224		.3224	.3189
18	.4287	.3467	.362	.3429		.3856
19	.5144	.4755	.4755	.4207		.463
20	.4458	.5853	.5914	.4607		.567
21		.4854	.499	.3772		.5228
22	.4458	.4108	.439	.034		.4435
23	.1372	.3361		.2401		.3734
24	.3361	.2987	.3174	.3045	.2058	
Max	.5281	.5853	.5914	.4805	.4338	.567
Min	.1372	.1715	.2865	.0287	.2058	.2328
Avg	.3283	.3372	.3821	.2984	.2824	.3417

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 206 / 11 KV Banpuri Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1578	.1646	.1417	.1629	.1543	.1612	
2	.1402	.0165	.1433	.1612	.1543	.1629	
3	.1372	.1663	.1612	.1646	.1543	.1646	
4	.1387	.1543	.1829	.1478	.1543	.1848	
5	.1772	.1715	.2033		.1886	.1829	
6	.2195	.1886	.2402	.2402	.2058	.2149	
7	.2402	.1886	.2218	.2402	.2195	.1991	
8	.1772	.12	.1772	.1772	.1595	.1311	
9	.1448	.1595	.1989	.1865	.1646	.1372	
10	.12	.1629	.1886	.1715	.1595	.1214	
11	.12	.1734	.1791	.1543	.1402	.1417	
12	.1543	.1753	.1734	.1715	.1595	.1402	
13	.1372	.1715	.1612	.1715	.1417	.1595	
14	.12	.1677	.1612	.1886	.1629	.1753	
15	.12	.1715	.1402	.156	.1433	.1734	
16	.12	.1638	.1417	.1715	.1612	.1844	
17	.1543	.1844	.197		.1791	.1658	
18	.1715	.1886	.1991	.2058		.1865	
19	.2062	.2427	.2507	.2195		.208	
20	.1372	.2378	.2378	.2561		.2303	
21		.2149	.2353	.1886		.2149	
22	.12	.1886	.197	.1886		.1734	
23	.1372	.1772		.0181		.1612	
24	.1595	.1543	.1578	.1646	.1543	.1595	.1387
Max	.2402	.2427	.2507	.2561	.2195	.2303	.1387
Min	.12	.0165	.1402	.0181	.1402	.1214	.1387
Avg	.1526	.1710	.1865	.1776	.1643	.1723	.1387

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244081 / 33/11 KV Lingiware

Feeder No / Name : 201 / 11 KV Palaskhel

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9114	1.0242	.7888	.3049	.362	.362	3.7532
2	.9114	1.0751	.7973	.3048	.362	.3811	3.5246
3	.9015	1.0277	.7975	.2858	.381	.362	3.2388
4	.9745	.1334	.8063	.2858	.381	.2858	3.1245
5	1.0056	1.0745	.8413	.3049	.4001	.362	3.4484
6	.9816	.1143	.8495	.3811	.4192	.4573	3.9247
7	1.1218	1.0985	1.0117	.5334	.4763	.5906	5.8318
8	.1524	.1143	.1715	.5716	.8505	.5334	.5525
9	.1143	.0686	1.1517	4.4391	6.0753	.4001	.4573
10	.0953	1.7372	1.0208	5.2195	6.1484	.343	.3429
11	.0953	.0762	1.0631	5.7065	6.1024	.362	.2858
12	.0762	.0762	1.1744	5.6547	6.0736	.343	.4001
13	.0762	.0762	.9362	5.3184	5.567	.3811	.4382
14		.0572	1.0166	5.1685	5.4722	.4382	.4382
15		.0572	1.0056	4.8926	5.0949	.4382	.4382
16	.0381	.0762	1.0277	5.0869	5.4193	.4191	.3429
17	.1143	.0953	.1143	.4382	.4192	.4192	.4191
18	.0953	.0953	.1143	.4191	.4382	.4763	.4382
19	.1334	.1143	.0762	.4763	.4953	.4953	.4573
20	.1143	.1334	.1334	.4763	.5715	.5715	.5144
21	.1334	.1524	.1334	.5334	.5525	.5906	.9526
22	1.1827	1.0745	.1143	.4382	.4763	4.3248	5.5175
23	.1143	.9465	.1143	.362	.3811	4.6106	5.6289
24	.9568	1.0867	.8328	.362	.343	4.3439	5.5152
Max	1.1827	1.7372	1.1744	5.7065	6.1484	4.6106	5.8318
Min	.0381	.0572	.0762	.2858	.343	.2858	.2858
Avg	.4682	.4827	.6705	1.9985	2.2193	.9288	2.0827

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244081 / 33/11 KV Lingiware

Feeder No / Name : 202 / 11 KV Rajewadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1143	.1715	4.8806	5.1132	4.8781	.4763
2	.1524	.1143	.1715	4.7234	4.8979	3.4484	.4191
3	.1524	.1334	.1524	4.5054	4.7331	4.4734	.4191
4	.1524		.1524	4.4161	4.8245	3.296	.4382
5	.1524	.1334	.1715	4.784	4.8297	4.3934	.4572
6	.1524		.1715	5.5582	5.5982	4.454	.4763
7	.1715	.1143	.1715	6.3634	6.5194	4.7493	.6669
8	.1715	.0876	.1715	.4572	.4382	1.5432	1.4098
9	1.3073	1.6827	.1715	.4953	.5716	5.7567	6.2971
10	1.3672	1.6834	.1715	.362	.6287	5.9324	5.7476
11	1.4563	1.5729	.1715	.4763	.5715	5.9614	5.5557
12	1.4175	1.4118	.1715	.5335	.5144	6.0654	1.4289
13	1.2689	1.3169	.1715	.1143	.4954	5.6565	.0572
14		1.8111	.1715	.6097	.4573	5.3509	
15		1.7737	.1715	.5525	.5144	5.7428	
16	1.2757	1.829	.1715	.6669	.5715	5.8154	3.8581
17	.0953	.1524	.1715	.7049	.5906	.6096	.362
18	.1334	.1524	.1715	.705	.5525	.5144	.5716
19		.1715	.1715	.7621	.5906	.6669	.6097
20	.1524	.1715	.1715	.6859	.6668	.743	.724
21	.1143	.1715	.1715	2.0004	1.6766	.7621	.724
22	.1143	.1715	1.0923	5.9892	5.0976	.5335	.6288
23		.1524	1.134	5.6905	4.9959	.4954	.6288
24	.1524	.0953	.1524	5.0579	5.3555	1.6156	.5906
Max	1.4563	1.829	1.134	6.3634	6.5194	6.0654	6.2971
Min	.0953	.0876	.1524	.1143	.4382	.4954	.0572
Avg	.5056	.6826	.2476	2.5456	2.5335	3.4774	1.4794

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244081 / 33/11 KV Lingiware

Feeder No / Name : 203 / 11 KV Dhole Mala,
Dighanchi Feeder KV- 11 /
OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8316	.9088	.7023	.0572	.0762	.0572	
2	.823	.9328	.695	.0572	.0762	1.0923	
3	.823	.9114	.7133	.0381	.0762	.0572	
4	.8688	.9391	.7059	.0381	.0572	.0572	
5	.924	.8916	.7577	.0381	.0572	.0572	
6	.8869	.9955	.7577	.0572	.0762	.0762	
7	.6219	1.0456	.9145	.0953	.0762	.0953	.9134
8	.1143	.0953	.0953	.0572	.0857	.1143	.0953
9	.0572		1.0242	1.0903	1.0166	.0953	.0953
10	.0572	.0381	.924	.9694	.7973	.0953	.0762
11	.0572	.0381	.9511	.9816	.9945	.0762	.0572
12	.0381	.0572	1.0679	1.0924	.9816	.0381	.0572
13	.0381	.0572	.8779	.9335	.7973	.0572	.0572
14		.0572	.924	1.0498	.8775		.0572
15		.0572	.9335	1.0099	.8573	.0381	.0572
16	.0381	.0381	.8871	.9991	.8063	.0572	.0762
17	.0762	.0381	.0381	.0572	.0572	.0762	.0762
18	.0762	.0572	.0381	.0572	.0953	.0953	.0762
19	.0953	.0953	.0381	.0572	.0953	.0762	.0762
20	.0762	.0953	.0953	.0762	.0953	.1143	.0762
21	.0762	.0953	.0953	.0572	.0953	.0953	.0953
22	1.0229	.9425	.0572	.0762	.0762		1.0924
23	1.0425	.8402	.0572	.0762	.0572		1.0277
24	.8589	1.0208	.7468	.0572	.0762	.0572	.8573
Max	1.0425	1.0456	1.0679	1.0924	1.0166	1.0923	1.0924
Min	.0381	.0381	.0381	.0381	.0572	.0381	.0572
Avg	.4320	.4456	.5874	.3783	.3482	.1228	.2733

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244081 / 33/11 KV Lingiware

Feeder No / Name : 204 / 11 KV Rajewadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.0876	.1267	.1254	.0895	.0716	
2	.1109	.1029	.128	.1075	.104	.0686	
3	.1109	.1052	.1086	.1097	.1052	.0701	
4	.112	.1063	.1097	.1086	.1097	.052	
5	.1294	.1214	.128	.128	.1254	.0724	
6	.1294	.0924	.1629	.1463	.12	.1478	
7	.1463	.0905	.1478	.1448	.132	.112	.0924
8	.1448	.1063	.1387	.1187	.1227	.0876	.0747
9	.0895	.0867	.0895	.0857	.0747	.0537	.0537
10	.0693	.0754	.0701	.0857	.0732	.0526	.0701
11	.0693	.0686	.0857	.0867	.0716	.0537	.0857
12	.0724	.0848	.1017	.1086	.052	.0537	.0732
13	.0716	.0838	.104	.1075	.0709	.0347	.0895
14	.0724	.0686	.1029	.1132	.0732	.0537	.0934
15	.0747	.0686	.104	.0914	.0716	.0514	.0693
16	.0934	.0857	.0838	.0895	.0693	.0526	.0724
17	.1029	.0848	.0857	.1097	.0724	.0537	.0857
18	.1267	.0838	.0867	.1029	.0701	.0686	.104
19	.1254	.1372	.1227	.1433	.0732	.1097	.1227
20	.1463	.1578	.1595	.168	.1612	.1867	.1463
21	.1478	.1612	.1612	.1109	.1612	.1848	.1433
22	.1075	.1629	.1629	.0876	.1629		.112
23	.1132	.1267	.1448	.0857	.124		.0914
24	.1097	.0914	.1267	.1267	.12	.0857	.0732
Max	.1478	.1629	.1629	.168	.1629	.1867	.1463
Min	.0693	.0686	.0701	.0857	.052	.0347	.0537
Avg	.1077	.1017	.1184	.1122	.1004	.0808	.0918

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244106 / 33/11 KV Pujarwadi

Feeder No / Name : 201 / 11 KV Kauthuly

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5089	1.6655	1.3717	.1448	.1448	
2	1.5089	1.6476	1.3717	.1448	.1448	
3	1.5089	1.6118	1.3717	.1448	.1448	
4	1.5089	1.7718	1.3717	.1448	.1448	
5	1.5089	2.1209	1.3717	.2172	.1448	
6	2.5377	2.3926	1.8519	.2172	.2172	
7	2.7435	2.5377	1.989	.2172	.2172	
8	.2149	.1715	.2149	.2865	.2149	
9	.1402	.1696	2.0576	3.0178		.1254
10	.1715	.1372	.1372	2.5484		.1254
11	.1187	.1372		2.0119		.1372
12	.1526	.1372	1.6244	2.0119		.1791
13	.1372	.1372	1.5074	1.6766		.1829
14	.1715	.1372	1.3763	1.6766		.1612
15	.1402	.1372	1.4586	1.4754		.1463
16	.12	.1372	1.9559	1.6095		.1433
17	.1543	.1433	.1696	.1433		.1829
18	.1907	.2149	.2058	.1433		.1829
19	.2454	.2149	.2149	.2149		.2195
20	.2835	.2865	.2149	.2149		.2058
21	.2507	.2865	.2149	.2149		.197
22	2.7046	2.7435	.2172	.2172		
23	2.3487	2.0576	.1448	.2172		
24	1.6461	1.5089		.1448	.1448	.2172
Max	2.7435	2.7435	2.0576	3.0178	.2172	.2195
Min	.1187	.1372	.1372	.1433	.1448	.1254
Avg	.9174	.9377	1.0188	.7940	.1687	.1719

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244106 / 33/11 KV Pujarwadi

Feeder No / Name : 202 / 11 KV Nimbawade

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1448	.1629	.1086	1.0631	1.0288	
2	.1448	.1463	.1086	1.0631	1.0288	
3	.1448	.1478	.1086	1.0631	1.0288	
4	.1448	.1478	.1086	1.0631	1.0288	
5	.1448	.181	.1086	1.1317	1.0974	
6	.181	.2126	.2172	1.4403	1.4403	
7	.2149	.1907	.2172	1.6461	1.5775	
8	.1791	.1715	.1791	.1433	.1433	
9	1.9204	2.0454	.1052	.1029		1.6461
10	1.7604	2.1795	2.2291	.1029		1.4582
11	1.6575	1.8442		.1029		1.8233
12	1.6385	1.8442	.1341	.1029		1.6385
13	1.4998	1.6095	.116	.1029		1.5912
14		1.6095	.116	.1029		1.6057
15		1.6095	.0819	.1029		
16	1.1603	1.6095	.0829	.1029		1.6655
17	.1357	.1075	.1526	.1075		.1478
18	.1372	.1433	.1543	.1075		.1829
19	.1928	.1791	.1791	.1791		.1791
20	.1949	.1791	.1791	.1791		.1646
21	.1791	.1791	.1433	.1433		.1791
22	.1612	.181	1.3394	1.448		.1433
23	.1629	.1448	1.2689	1.3394		.1463
24	.1448	.1086		1.166	1.166	
Max	1.9204	2.1795	2.2291	1.6461	1.5775	1.8233
Min	.1357	.1075	.0819	.1029	.1433	.1433
Avg	.5566	.7056	.3381	.5878	1.0600	.8980

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244106 / 33/11 KV Pujarwadi

Feeder No / Name : 203 / 11 KV Kauthuly Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2172	.1448	.0905	.0905	.0905	
2	.2172	.128	.0905	.0905	.0905	
3	.2172	.128	.0905	.0905	.0905	
4	.2172	.1478	.0905	.0905	.0905	
5	.2172	.1629	.0905	.0905	.0905	
6	.1629	.1772	.181	.1267	.1448	
7	.197	.1907	.2172	.181	.1629	
8	.1791	.12	.1791	.1791	.1254	
9	.1753	.2374	.2103	.1715		.0709
10	.1029	.2743		.1029		.1029
11	.1865	.2572		.1029		.1772
12	.2012	.2572	.0848	.1029		.1612
13	.2012	.2229	.0838	.0857		.1097
14	.1823	.2229	.0838	.0857		.1433
15	.2012	.2229	.0995	.0857		.124
16	.2204	.2058	.1341	.0857		.1543
17	.2401	.1791	.0848	.0895		.1791
18	.2947	.197	.1372	.1791		.2058
19	.1928	.197	.1791	.2149		.2865
20	.2126	.197	.1791	.2149		.2743
21	.2149	.197	.1791	.1791		.2534
22	.197	.181	.181	.181		.2378
23	.181	.181	.1086	.1448		.1829
24	.2534	.1086		.1086	.0905	.2172
Max	.2947	.2743	.2172	.2149	.1629	.2865
Min	.1029	.1086	.0838	.0857	.0905	.0709
Avg	.2034	.1891	.1321	.1281	.1085	.1800

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244106 / 33/11 KV Pujarwadi

Feeder No / Name : 204 / Nimbawade Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2715	.2353	.2715	.2172	.181		.2401
2	.2715	.2195	.2715	.2172	.181		.2865
3	.2715	.2218	.2715	.2172	.181		.2743
4	.2715	.2402	.2715	.2172	.181		.2507
5	.2715	.2172	.2715	.2172	.181		.2507
6	.2715	.3012	.5068	.2715	.181		.2572
7	.3582	.3641	.362	.2715	.2172		
8	.2507	.2743	.2507	.2149	.2149		
9	.1753	.218	.1753	.1715		.1734	
10	.1715	.2058		.1715		.1612	
11	.1526	.2058		.1715		.1791	
12	.2012	.2058	.1509	.1715		.1595	
13		.2058	.1492	.1715		.3155	
14	.1658	.2058	.1658	.1715		.1433	
15	.2012	.2058	.1802	.1715			
16	.2204	.2058	.1823	.1715		.1791	
17	.2229	.2149	.2012	.1791		.2835	
18	.2427	.2507	.2401	.1791		.3086	
19	.2454	.2507	.2865	.2149		.3658	
20	.2658	.2865	.2865	.2507		.3258	
21	.3045	.2865	.2865	.2507		.2926	
22	.2865	.2896	.2896	.2534		.3086	
23	.2534	.2896	.2896	.2172		.2865	
24	.2896	.2896		.2896	.2172	.2172	.2743
Max	.3582	.3641	.5068	.2896	.2172	.3658	.2865
Min	.1526	.2058	.1492	.1715	.181	.1433	.2401
Avg	.2451	.2454	.2553	.2104	.1928	.2466	.2620

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 246012 / 110/33/11 KV DIGHANCHI

Feeder No / Name : 201 / 11 KV Vithalapur

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-APR-17
HR	Load (MW)
24	.0732
Max	.0732
Min	.0732
Avg	.0732

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 246012 / 110/33/11 KV DIGHANCHI

Feeder No / Name : 202 / 11 KV Dighanchi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-APR-17
HR	Load (MW)
24	.2378
Max	.2378
Min	.2378
Avg	.2378

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 246012 / 110/33/11 KV DIGHANCHI

Feeder No / Name : 203 / 11 KV Rajewadi AG

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17
HR	Load (MW)
24	.2012
Max	.2012
Min	.2012
Avg	.2012

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 246012 / 110/33/11 KV DIGHANCHI

Feeder No / Name : 204 / 11 KV Rajewadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17
HR	Load (MW)
24	.0554
Max	.0554
Min	.0554
Avg	.0554

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 246012 / 110/33/11 KV DIGHANCHI

Feeder No / Name : 205 / 11 KV Dighanchi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17
HR	Load (MW)
24	.1109
Max	.1109
Min	.1109
Avg	.1109

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 201 / 11 KV Gorewadi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1006	.1052	.1075	.7461	.703	.823	.1075
2	.1029	.1052	.1075	.7122	.6588	.823	.1075
3	.12	.1029	.1075	.7122	.8573	.8215	.1075
4	.1433	.1029	.1075	.7122	1.0229	.6706	.1075
5	.1402	.12	.1075	.78	1.2548	.8478	.1254
6	.1509	.1578	.1433	1.2717	1.5089	1.1065	.1595
7	.1658	.1715	.1595	1.7974	1.5769	1.1022	.1949
8	.1677	.1696	.124	.1578	.1341	.1509	.1578
9	.1492	1.8111	.1214	.124	.1326	1.1022	1.5769
10	1.4251	1.8107	.1052	.0857		1.2239	1.6108
11	1.1869	1.3245	.1052	.1017		1.2239	1.4582
12	1.0227	1.2929	.1227	.1341		1.0562	
13	.9326	1.21	.1227	.1187	.1187	1.0898	
14		1.1271	.1227	.1174	.1187	1.0774	
15		1.3923	.1227	.0995	.1187	1.326	
16		1.5249	.1052	.1174	.1187	1.3592	
17	.1543	.1341	.1052	.0995		.12	
18	.1543		.1402	.1311	.1187	.1402	
19	.1886	.1753	.1928	.1457	.2012	.1772	.1928
20	.1928	.2103	.2103	.1638	.2058	.197	
21	.2058	.1949		.1619	.2229	.1791	
22	.1543	.1595		1.1022	1.1022	.1791	
23	.1227	.124		.7712	.9835	.1075	
24	.1017	.1029	.1075	.7461	.7291	.8478	.1075
Max	1.4251	1.8111	.2103	1.7974	1.5769	1.3592	1.6108
Min	.1006	.1029	.1052	.0857	.1187	.1075	.1075
Avg	.3373	.5926	.1261	.4629	.5944	.7397	.4626

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 202 / 11 KV Bhivghat AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6443	.5365	.5087	.0709	.0514	.0671	.6613
2	.6173	.4973	.4917	.0709	.0343	.0678	.6443
3	.6415	.503	.4748	.0709	.0686	.0671	.6443
4	.6588	.5087	.4917	.0709	.0838	.0678	.6613
5	.6687	.5935	.5087	.0709	.1006	.0838	.6952
6	.7888	.8501	.6104	.0886	.1017	.1017	.8478
7	.9724	1.0227	.8309	.1063	.0671	.1017	1.0852
8	.0678	.0848	.0867	.0701	.0663	.1006	.1017
9	.0838	.0671	.9665	1.1191	.9724	.0678	.0838
10	.0678	.0503	.8478	.9724		.0671	.0857
11	.0678	.0503	.7969	.8987		.0671	.0857
12	.0848	.0671	.8309	.8383			.1227
13	.0838	.0838	.7461	.8817	.8987	.0838	.0876
14		.0671	.78	.8648	.9221	.0663	
15		.0671	.78	.9556	1.0004	.0829	
16		.0671	.7969	.9945	.9892	.0838	
17	.0838	.0838	.0876	.1006		.1029	
18	.0848	.0686	.0876	.0995	.1357	.1052	
19	.1017	.1052	.0876	.0671	.1006	.124	.1227
20	.1029	.1227	.1052	.0829	.1017	.1063	
21	.1174	.1052			.1006	.1063	
22	.8648	.7291		.0678	.0848	.8987	
23	.6036	.6104		.0503	.0678	.763	
24	.6613	.5426	.5087	.0709	.0509	.0671	.6783
Max	.9724	1.0227	.9665	1.1191	1.0004	.8987	1.0852
Min	.0678	.0503	.0867	.0503	.0343	.0663	.0838
Avg	.3842	.3118	.5441	.3776	.2999	.1500	.4405

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 203 / 11 KV Khanapur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0802	.8478	.8478	.0709	.0671	.0838	.9665
2	1.0513	.8478	.8139	.0709	.0678	.0848	.9496
3	1.1317	.8478	.8139	.0709	.0848	.0838	.9496
4	1.1736	.9221	.7969	.0709	.1029	.0848	.9835
5	1.2378	.9556	.8139	.0709	.1174	.0838	1.0174
6	1.3203	1.0513	.8478	.0709	.1017	.1017	1.1869
7	1.6108	1.3904	1.0682	.0886	.1174	.1017	1.56
8	.1006	.0838	.12	.0876	.0829	.1174	.1017
9	.0829	.0848	1.0513	1.17	1.2616	.1187	.0838
10	.0671	.0848	1.0004	1.1488		.1006	.1029
11	.0838	.0678	1.0004	.8718		.1174	.12
12	.0848	.0848	1.0852	1.1022	1.2574	.1006	.1402
13	.0838	.0838	1.1361	1.291	1.3565	.1006	.1052
14		.0838	1.0852	1.387	1.3413	.1006	
15		.0838	1.153	1.4575	1.3748	.0995	
16		.0838	1.2039	1.3565	1.5091	.1006	
17	.1174	.1017	.0876	.0848		.1017	
18	.1017		.1052	.1187	.1174	.1372	
19	.1006	.1052	.1052	.0857	.1187	.1227	
20	.1017	.1052	.1227		.1174	.1227	
21	.1006	.0876	.0709	.0838	.1187	.1052	
22	1.2209	1.1022	.0701	.0848	.0838	1.2717	
23	1.0174	.9156		.0829	.0848	1.1191	
24	1.0852	.8551	.8478	.0709	.081	.0848	.9835
Max	1.6108	1.3904	1.2039	1.4575	1.5091	1.2717	1.56
Min	.0671	.0678	.0701	.0709	.0671	.0838	.0838
Avg	.6169	.4729	.7064	.4782	.4555	.1936	.6608

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 204 / 11 KV Khanapur Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2427	.2515	.2507	.2804	.2401	.3052	.3045
2	.2279	.2515	.2328	.2629	.2401	.2515	.2865
3	.2835	.2543	.2328	.2629	.3429	.2543	.2865
4	.3121	.2347	.2328	.2629	.3814	.2515	.2865
5	.3601	.2713	.2507	.2804	.4287	.3052	.3045
6	.3467	.3222	.3224	.3189	.4115	.4287	.3366
7	.3601	.4024	.3582	.3721	.4508	.4191	.3856
8	.3121	.3688	.2481	.2804	.3601	.39	.333
9	.298	.2683	.2279	.3012	.3429	.3052	.2743
10	.2543	.2543	.2279	.1734		.3222	.2915
11	.2683	.2883	.3155	.2743		.2713	.2915
12	.3052	.2713	.3506	.2743	.39	.3052	.2743
13	.3018	.2883	.3155	.2883	.3391	.2683	.298
14	.3052	.3052	.3155	.2915	.3391	.2515	
15	.3018	.2883	.298	.3258	.3391	.3018	
16	.2374	.2883	.2279	.2743	.3561	.3185	
17	.3391	.3561	.3155	.3258		.3391	
18	.373	.3222	.3681	.3391	.4748	.3601	
19	.4239	.4031	.4207	.3601	.5256	.4508	.4382
20	.4748	.443	.5083		.5426	.5493	.5083
21	.4191	.4119	.4382	.463	.4694	.5194	
22	.3561	.394		.4161	.4239	.4656	
23	.3052	.3045		.3429	.373	.3582	.3544
24	.2572	.2713	.2507	.2804	.2915	.3391	.3045
Max	.4748	.443	.5083	.463	.5426	.5493	.5083
Min	.2279	.2347	.2279	.1734	.2401	.2515	.2743
Avg	.3194	.3131	.3049	.3066	.3839	.3471	.3270

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 205 / 11 KV Bhivghat Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1227	.1341	.1433	.1772		.1341	.1433
2	.104	.1357	.1254	.1772		.1372	.1433
3	.1052	.1357	.1254	.1772		.1372	.1433
4	.124	.1372	.1254	.1772		.1509	.1433
5	.1227	.12	.1433	.1772		.1677	.1433
6	.1907	.1677	.1612	.1772		.1865	.1595
7	.1886	.1696	.1928	.2126		.1696	.1578
8	.2058	.1677	.1772	.1928		.1865	.1753
9	.1734	.1715	.1578	.1772		.1715	.1715
10	.1696	.1715	.1753			.2035	.1928
11	.1677	.1372		.1886		.1865	.1753
12	.1865	.1696	.1753	.1886		.1865	.2103
13		.1526	.1928	.1543	.2683	.1509	.2103
14	.1357	.1526	.1753	.1543	.2204	.1341	
15	.1341	.1677	.1753	.1526	.2035	.1677	
16	.1017	.1509	.1753	.1509	.1844	.1696	
17	.1543	.1865	.1753	.1734		.1865	
18	.1715	.1715	.1753	.1943	.2713	.1886	
19	.2401	.1753	.1928	.2204	.3086	.2103	.2103
20	.2454	.2126	.2279		.3086	.2303	
21	.2401	.2328			.2229	.2303	
22	.1886	.2149			.2035	.1949	
23	.1543	.1612			.1886	.1595	
24	.1387	.1543	.1433	.1772		.1696	.1417
Max	.2454	.2328	.2279	.2204	.3086	.2303	.2103
Min	.1017	.12	.1254	.1509	.1844	.1341	.1417
Avg	.1637	.1646	.1668	.1790	.2380	.1754	.1681

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 206 / 11 KV Balawadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.104	.1187	.1433	1.1191	1.166	1.0288	.1433
2	.1063	.12	.1433	1.1022	1.166	1.0288	.1433
3	.1214	.12	.1254	1.1022	1.3717	1.0288	.1254
4	.1402	.1402	.1433	1.1022	1.5257	1.0395	.1433
5	.1715	.1543	.1612	1.1869	1.6461	1.1022	.1612
6	.2035	.1865	.1949	1.6278	1.9161	1.2717	.2126
7	.2012	.1886	.197	2.2382	2.1293	1.4413	.2303
8	.1357	.1886	.1595	.1227	.1696	.1844	.1753
9	1.9448	1.989	.12	.1063	.1174	1.8107	1.9669
10	1.8991	2.0454	.1227	.1075		1.8442	1.8482
11	1.8652	2.0454	.1052	.1174		1.6263	1.7295
12	1.6766	1.576	.0876	.1174		1.5424	
13	1.5261	1.6095	.1052	.1187		1.3916	
14		1.6263	.1052	.1174		1.4419	
15		1.8107	.1052	.1326		1.576	
16		2.0119	.1052	.1341		1.7939	
17	.1341	.1341	.1227	.1326		.1715	
18	.1677	.1509	.1402	.1475	.2713	.1578	
19	.1865	.1715	.1753	.1658	.2401	.1949	.2454
20	.1715	.1928	.2103	.1677	.2229	.2328	
21	.2035	.1949	.2103	.1823	.2229	.2328	
22	.1509	.1772		1.4091	1.4575	.1791	
23	.1174	.1612		1.2239	1.2209	.1612	
24	.1187	.1341	.1433	1.1191	1.1904	1.0562	.1433
Max	1.9448	2.0454	.2103	2.2382	2.1293	1.8442	1.9669
Min	.104	.1187	.0876	.1063	.1174	.1578	.1254
Avg	.5403	.7187	.1421	.6292	1.0021	.9808	.5591

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 207 / 11 KV GOREWADI gaovthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0526	.0503	.0537	.0709	.0701	.0503	.0532
2	.0526	.0335	.0537	.0709	.0709	.0509	.0532
3	.0686	.0339	.0358	.0709	.0701	.0503	.0532
4	.0693	.0335	.0358	.0709	.0693	.0509	.0532
5	.0857	.0503	.0537	.0886	.0857	.0671	.0532
6	.1052	.0848	.0895	.0886	.0686	.1017	.0709
7	.0686	.0838	.0886	.1063	.0867	.1017	.0876
8	.0693	.1017	.0709	.1052	.1372	.0838	.0876
9	.0526	.1174	.0876	.0876	.0857	.0848	.0686
10	.1187	.0838	.0876	.052		.0848	.0686
11	.1017	.0678	.0701	.0343		.0678	.0686
12			.0701	.0693	.0848	.0678	.0686
13		.0509	.0701	.0686	.0503	.0671	.0701
14		.0509	.0701	.0514	.0509	.0671	
15	.0838	.0509	.0526	.052	.0509	.0503	
16	.0848	.0678	.0526	.0686	.0503	.0678	
17	.1017	.0678	.0526	.0686		.0857	
18	.1017	.0347	.0701	.0857	.0339	.0701	
19	.1187	.0886	.0876	.0867	.1187	.1063	.1052
20	.1174	.1063	.0876	.0686	.1006	.0886	
21	.1017	.0895		.0857	.0848	.0886	
22	.0671	.0716		.0693	.0678	.0709	
23	.0671	.0537		.0686	.0503	.0532	
24	.0693	.0678	.0537	.0886	.0693	.0509	.0537
Max	.1187	.1174	.0895	.1063	.1372	.1063	.1052
Min	.0526	.0335	.0358	.0343	.0339	.0503	.0532
Avg	.0837	.0670	.0664	.0741	.0741	.0720	.0677

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244117 / 33/11 KV Hiware Substation

Feeder No / Name : 201 / PALASHI AG

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1696	.1629	.6718	.4801	.6562	.1696
2	.1905	.1715	.1612	.6483	.4374	.6478	.1677
3	.1905	.1696	.1595	.6483	.4218	.6401	.1677
4	.1905	.1844	.1791	.6483	.4218	.6405	.1715
5	.2286	.1865	.2353	.6554	.502	.6636	.2103
6	.3258	.3052	.3224	1.0623	.9556	.8223	.3052
7		.2429	.2715	1.3108	1.5424	1.078	.285
8	.2286	.1928	.2427	.2012	.2058	.2402	.2454
9	1.0848	1.3226	.181	.2096	.1991	1.0059	1.1904
10	1.2193	1.3123	.1595	.1715	.1791	.9877	1.1961
11	1.2037	1.1431	.1791	.1646	.1402	.9602	1.0082
12	1.3108	.945	.1663	.1595	.1595	1.0031	
13		.9602	.1905	.197	.1791	.9172	
14	.5571	.9181	.1448	.2149	.1578	1.0155	
15		1.1883	.1848	.1772	.1417	1.0822	
16	1.1361	1.1561	.1715	.1772	.1612	1.3123	
17	.2103	.1928	.1715	.2328	.1646	.1372	
18	.197	.2427		.2149	.2772	.1715	
19	.3077	.2987	.2486	.2534	.2801	.2804	
20	.3224	.3547	.3429	.2561	.3174	.3224	
21	.3045	.3361	.3429	.2561	.3174	.3077	
22	.2149	.2353	.9659	.6173	.9259	.2454	
23	.1753	.1791	.7926	.5365	.7164	.1715	
24	.2096	.1715	.1629	.7186	.4801	.6718	.1715
Max	1.3108	1.3226	.9659	1.3108	1.5424	1.3123	1.1961
Min	.1753	.1696	.1448	.1595	.1402	.1372	.1677
Avg	.4761	.5241	.2669	.4335	.4068	.6659	.4407

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244117 / 33/11 KV Hiware Substation

Feeder No / Name : 202 / 11 KV HIVARE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4755	.547	.5121	.2667	.2103	.2149	.6036
2	.4755	.5243	.502	.2667	.1928	.197	.5801
3	.4755	.5243	.4858	.2667	.1928	.2172	.5868
4	.4755	.5533	.4961	.2667	.1928	.2172	.6133
5	.503	.583	.5218	.3048	.1949	.2328	.6687
6	1.0595	1.2407	.703	.362	.2865	.362	1.2289
7		1.5203	1.0155	.381	.362	.3582	1.3603
8	.2804	.2454	.3547	.2926	.3681	.2772	.2686
9	.2195	.2401	.463	1.0269	1.2689	.2534	.2804
10	.2402	.2105	.6401	.8573	1.0227	.2481	.2629
11	.2402	.1981	.6706	.7282	.8745	.2149	.2601
12	.3077	.285	.7375	.8124	.828	.2486	.2835
13		.2321	.6447	.8065	.8179	.2515	.2835
14	.2401	.2279	.7282	.9488	.7225	.2267	
15	.333	.0686	.7145	1.1012	1.0669	.208	
16	.2572	.2947		.9503	1.1883	.2753	
17	.3224		.2321	.3086	.2957	.2229	
18	.3258	.4108		.2804	.3547	.2804	
19	.362	.4668	.3391	.3012	.3734	.4298	
20	.4119	.5041	.4572	.3045	.4108	.4252	
21	.3801	.4481	.4001	.3045	.3734	.4207	
22	.8916	.7343	.3429	.2481	.3077	.9774	
23	.78	.5556	.2667	.2279	.2534	.6687	
24	.5135	.5868	.3391	.2667	.2103	.2172	.6274
Max	1.0595	1.5203	1.0155	1.1012	1.2689	.9774	1.3603
Min	.2195	.0686	.2321	.2279	.1928	.197	.2601
Avg	.4350	.4870	.5258	.4950	.5154	.3186	.5649

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244117 / 33/11 KV Hiware Substation

Feeder No / Name : 203 / 11 KV HIVARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.0366	.0351	.0543	.0351	.0354	.056
2	.0362	.0362	.0347	.0549	.0351	.0351	.0358
3	.0362	.0362	.0351	.0549	.0351	.0347	.0351
4	.0362	.0358	.0354	.0549	.0351	.0351	.0351
5	.0366	.0351	.052	.0549	.0351	.0343	.0537
6	.0537	.0514	.0514	.0537	.0532	.052	.0343
7		.0509	.0526	.0537	.0724	.0686	.0509
8	.1086	.0537	.0343	.0532	.0701	.0895	.0716
9	.0716	.0514	.0347	.0343	.0543	.0351	.0886
10	.0716	.0671	.0857	.0829	.0537	.0514	.1029
11	.0701	.0469	.0848	.0829	.0886	.0693	.0701
12	.0543	.0335	.0693	.0686	.0526	.0943	.104
13		.0324	.1086	.0526	.0347	.0514	.0497
14	.0701	.0339	.0701	.0886	.0514	.0503	
15	.0895	.0503	.0701	.0701	.0339	.0663	
16	.0526	.0678	.0905	.0354	.0343	.0857	
17	.0537	.0339	.0709	.0537	.0351	.0351	
18	.0914	.052		.0537	.0354	.0537	
19	.056	.0526	.0857	.0543	.0716	.0724	
20	.0762	.0709	.0701	.0543	.0701	.0934	
21	.0943	.0532	.0701	.0543	.0709	.0762	
22	.0543	.0526	.0693	.0358	.0526	.0747	
23	.0537	.0514	.0537	.0354	.052	.0549	
24	.0895	.0358	.0857	.0543	.0351	.0351	
Max	.1086	.0709	.1086	.0886	.0886	.0943	.104
Min	.0362	.0324	.0343	.0343	.0339	.0343	.0343
Avg	.0642	.0467	.0630	.0561	.0499	.0577	.0606

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244003 / 33/11 KV K'WADI S/S

Feeder No / Name : 201 / 11 KV BURLI FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0943	.0943	4.2981	3.4933	3.4476	.0943
2	.0943	.0086	.0943	4.1301	3.4293	3.3104	.0943
3	.0943	.0943	.0943	4.0409	3.4019	3.1493	.0943
4	.0943	.0943	.0943	4.0409	3.3836	3.1493	.0943
5	.0943	.1132	.0943	4.0409	3.5265	3.1207	.1132
6	.0943	.1132	.0943	4.2067	3.7357	3.283	.132
7	.0943	.1132	.0943	4.3896	4.161	3.4202	.1132
8	.0943	.1132	.0943	.9631	1.0545	.6887	.1132
9	5.9716	6.1728	.0943	.0943	.0943	5.0298	5.703
10	6.3798	6.4255	.0943	.0943	.0943	6.2986	6.3557
11	6.2002	6.6747	.0943	.0943	.0943	6.8781	3.4294
12	5.855	6.438	.0943	.0943	.0943	6.6758	3.3836
13	5.8242	6.1225	.1132	.0943	.0943	6.3466	
14	.823	5.7042	.0943	.0943	.0943	6.0768	
15	2.3777	5.1875	.1132	.0943	.0943	6.1637	
16	2.4143	4.7074	.1132	.0943	.0943	5.7042	
17	.8259	.8259	.1132	.0943	.0943	.9631	1.0974
18	.0943	.0943	.1132	.1132	.1132	.1132	
19	.132	.0943	.1132	.1132	.1132	.132	
20	.132	.1132	.1132	.0943	.132	.132	
21	.132	.1132	.1132	.0943	.1132	.1132	
22	.132	.1132	2.1125	3.9232	3.9689	.1132	
23	.1132	.0943	2.2131	3.9598	3.9598	.0943	
24	.0943	.1132	.0943	4.0466	2.1519	1.5912	.0943
Max	6.3798	6.6747	2.2131	4.3896	4.161	6.8781	6.3557
Min	.0943	.0086	.0943	.0943	.0943	.0943	.0943
Avg	1.5940	2.0724	.2730	1.8043	1.5661	3.1665	1.4937

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244003 / 33/11 KV K'WADI S/S

Feeder No / Name : 202 / 11 KV RAMANANDNAGAR 1

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0172	2.0477	1.0456	2.2787	2.1536	2.0172	2.0477
2	1.9113	1.8809	.9709	2.0279	1.0364	1.8809	1.8809
3	1.8504	1.8504	.9709	1.9974	1.9867	1.8504	1.8504
4	1.8199	1.8504	.9709	1.9974	1.9867	1.8199	1.8504
5	1.8953	1.9563	1.0456	2.1018	1.9867	1.8953	1.9258
6	2.4105	2.3655	1.0974	2.5194	2.2787	2.1872	2.1986
7	2.4006	2.4325	1.1317	2.5591	2.2976	2.2748	2.2519
8	2.1201	2.1826	1.0136	2.2329	2.2862	1.9357	2.1506
9	2.3046	2.3655	1.1584	2.2444	2.3655	1.8138	2.0683
10	2.3472	2.4676	1.2048	2.396	2.4692	1.8626	1.9379
11	2.2497	2.4676	1.2894	2.4692	2.6025	1.8961	1.0059
12	2.2725	2.335	1.1462	2.3891	2.4387	1.8579	1.0059
13	1.0669	2.2131	1.1706	2.2741	2.2253	1.7497	.9145
14	2.5765	2.6002	1.3032	2.5416	2.5545	2.4676	.9755
15	2.5461	2.4631	1.2308	2.5721	2.5545	2.4814	1.0059
16	2.5286	2.4082	1.2178	2.5111	2.4387	2.5728	.823
17	2.4204	2.4897	1.0745	2.4326	2.3015	2.4082	.823
18	2.2375	2.3472	1.166	2.3777	2.2984	2.1796	.7926
19	2.8197	2.774	1.4022	2.7588	2.3892	2.6445	1.0669
20	3.168	3.152	1.6651	3.1825	1.7985	2.8982	1.4632
21	2.8989	2.9157	1.5203	2.8852	2.6414	2.7328	1.4327
22	2.7465	2.777	1.5684	2.6109	2.6856	2.6109	1.3413
23	2.5484	2.5666	1.2696	2.5484	2.5484	2.4425	1.3108
24	2.204	2.2344	1.0456	2.3837	2.204	2.1841	2.2146
Max	3.168	3.152	1.6651	3.1825	2.6856	2.8982	2.2519
Min	1.0669	1.8504	.9709	1.9974	1.0364	1.7497	.7926
Avg	2.3067	2.3810	1.1950	2.4288	2.2720	2.1943	1.5141

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244003 / 33/11 KV K'WADI S/S

Feeder No / Name : 203 / 11 KV SAWANTPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0734	.0753	.0724	3.6199	3.5437	1.3337	.1014
2	.0714	.0743	.0724	3.4436	3.4417	1.2956	.1
3	.0743	.0743	.0724	3.3493	3.2912	1.1793	.1
4	.0753	.0743	.0869	3.3112	3.3093	1.1279	.1014
5	.0724	.0914	.0869	3.3493	3.3722	1.1346	.1189
6	.108	.0937	.0892	3.5246	3.5056	1.1613	.1219
7	.093	.0914	.0854	3.8123	3.7961	1.2422	.0812
8	.092	.0907	.1021	.7728	.9088	.2972	.1174
9	4.1724	4.5439	.0638	.0903	.0926	2.1214	4.944
10	4.4773	4.8154	.0676	.0869	.108	2.311	5.4736
11	4.5011	4.7344	.0541	.08	.104	2.5768	2.934
12	4.4011	4.6335	.0714	.0657		2.4749	2.934
13	4.2371	4.5535	.0857	.088	.1	2.229	
14	.4191	4.3591	.0892	.0686	.088	3.4132	
15	1.6004	4.1647	.0903	.0869	.0892	4.4676	
16	2.9683	4.0466	.088	.0987	.0789	4.6697	
17	.4753	.7602	.0894	.0934	.0823	.7972	.3429
18	.1	.0947	.1067	.0907	.0789	.0789	
19	.1067	.0857	.1027	.1	.104	.1027	
20	.1219	.1014	.1389	.1189		.689	
21	.1094	.104	.1372	.104		.1067	
22	.108	.0892	1.9433	3.5437	1.4775	.1204	
23	.0903	.0892	1.8623	3.7599	1.5708	.1067	
24	.0724	.0892	.0846	3.6999	2.4768	.5716	.104
Max	4.5011	4.8154	1.9433	3.8123	3.7961	4.6697	5.4736
Min	.0714	.0743	.0541	.0657	.0789	.0789	.0812
Avg	1.1925	1.5804	.2393	1.5566	1.5057	1.4837	1.2553

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244003 / 33/11 KV K'WADI S/S

Feeder No / Name : 204 / 11 KV RAMANANDNAGAR 2

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	02-APR-17
HR	Load (MW)
2	.9808
Max	.9808
Min	.9808
Avg	.9808

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 201 / 11 KV Dudhondi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1418	.0876	.6093	1.6476	1.3672	.1577	.1471
2	.1402	.0625	.6093	1.5725	1.3222	.1732	.1479
3	.1402	.0625	.5937	1.5413	1.3032	.1608	.1524
4	.1448	.0694	.6093	1.5462	1.3443	.1578	.1726
5	.1787	.1673	.6405	1.6354	1.4008	.1981	.1779
6	.2233	.1878	.7186	1.8023	1.5767	.2271	.2034
7	.237	.2278	.8436	1.9864	1.6064	.2233	.2202
8	.3299	.2659	.0937	.2031	.1821	.3459	.2922
9	2.1597	2.5332	.0781	.2031	.1768	2.5675	2.6345
10	2.2745	2.6452	.0937	.1848	.1684	2.761	2.8403
11	2.3319	2.5491	.0781	.1639	.184	2.8128	2.8723
12	2.3419	2.4608	.0781	.1692	.1532	2.7389	1.5638
13	2.2405	2.2714	.0781	.1707	.1486	2.5903	
14	2.1026	2.1071	.0819	.1824	.0686	1.3763	
15	1.9129	1.9967	.0781	.1709	.0876	2.4051	
16	1.8472	1.9227	.0781	.1616	.1554	2.3716	.9579
17	.0861	.1616	.0781	.2004	.1993	.141	.0998
18	.1539	.1578	.0781	.1977	.176	.1631	.109
19	.1802	.2118	.0781	.2187	.2046	.1878	.1181
20	.2103	.2156	.0781	.2229	.2359	.2118	.1273
21	.2004	.2648	.0781	.2796	.2191	.1966	.1135
22	.1886	1.512	.8592	1.6309	.1953	.1772	.1052
23	.157	1.507	.8436	1.6019	.1669	.1741	.1006
24	.1181	.8794	.6249	1.6651	.8005	.1479	.0876
Max	2.3419	2.6452	.8592	1.9864	1.6064	2.8128	2.8723
Min	.0861	.0625	.0781	.1616	.0686	.141	.0876
Avg	.8351	1.0220	.3367	.8066	.5601	.9445	.6306

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 202 / 11 KV Nagrale Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5863	1.7513	.0492	.0655	.0671	1.8115	1.8678
2	1.5394	1.4708	.0655	.0655	.0671	1.752	1.7955
3	1.5451	1.4578	.0655	.0655	.0671	1.6957	1.7566
4	1.531	1.5074	.0819	.0655	.0671	1.6751	1.6986
5	1.6483	1.5509	.0819	.0819	.0671	1.6362	1.7886
6	1.7726	1.6362	.0655	.0678	.0671	1.7482	2.0149
7	1.9491	2.1255	.0819	.0777	.0717	1.832	2.223
8	.1348	.131	.0819	.1356	.1121	.0778	.1067
9	.0492	.0655	1.4582	3.1718	3.3971	.0671	.0671
10	.0655	.0492	1.4582	3.2982	3.5139	.0671	.0503
11	.0655	.0655	1.491	3.3235	3.4072	.0671	.0816
12	.0655	.0492	1.5074	3.3017	3.4332	.0671	.0671
13	.0655	.1201	1.2452	3.3395	3.3387	.0572	.0069
14	.0655	.0838	1.3108	3.2896	3.3471	.0671	
15	.0492	.0492	1.3599	3.2362	3.2306	.0503	
16	.0492	.0492	1.3108	2.7438	3.1085	.1006	.0015
17	.067	.0492	.0655	.0747	.0671	.0846	
18	.0655	.0492	.0655	.1326	.0671	.1227	
19	.0655	.0655	.0655	.1699	.0671	.1135	.0008
20	.0819	.0492	.0655	.208	.0838	.0838	
21	.0655	.0655	.0655	.186	.1075	.0671	.0008
22	1.8747	.0655	.0655	.0838	1.9814	2.0165	1.0387
23	1.8648	.0655	.0655	.0671	1.9571	1.9632	1.0905
24	1.8008	.8192	.0492	.0655	1.0654	1.9212	1.0372
Max	1.9491	2.1255	1.5074	3.3395	3.5139	2.0165	2.223
Min	.0492	.0492	.0492	.0655	.0671	.0503	.0008
Avg	.7528	.5580	.5093	1.1382	1.3650	.7977	.8786

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 203 / 11 KV Takari Exps

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1622	1.044	.4508	.9584	1.1927	1.1048	1.0745
2	1.186	.9122	.4161	.852	1.1687	1.1108	.9731
3	1.1271	.9001	.3856	.791	1.1096	1.1279	.9507
4	1.0425	.8154	.4557	.7651	1.0787	1.0535	.9335
5	1.1622	.8776	.4908	.8977	1.1403	1.1622	.9785
6	1.1727	1.03	.4252	.8261	.9831	1.0993	1.0135
7	1.223	.8383	.4557	.8566	1.025	1.1218	.9731
8	1.2232	.9176	.5201	.8824	1.1157	1.2298	1.0498
9	1.3134	1.1222	.5731	.9838	1.2121	1.387	1.1523
10	1.278	1.2011	.4854	1.145	1.3184	1.4838	1.2308
11	1.2665	1.134	.4557	1.0307	1.2407	1.4049	1.1584
12	1.339	1.0753	.4382	.961	1.2056	1.3695	1.1413
13	1.3134	.9484	.5609	1.0364	1.2056	1.2665	.3963
14	1.3085	.9533	.4961	1.0419	1.2232	1.3695	.3048
15	1.1012	1.0448	.4908	.9533	1.2056	1.2376	.3353
16	1.2425	.9838	.4656	1.086	1.2056	1.2384	.3048
17	1.3424	.9129	.4656	1.0193	1.1693	1.1767	.2439
18	1.1157	.9773	.4477	1.0913	1.1557	1.2121	.2439
19	1.0803	1.0852	.5316	.9915	1.1279	1.2902	.4877
20	1.0448	.9739	.4908	.8776	1.1965	1.4175	.5487
21	.9407	1.1077	.4961	1.0163	1.1793	1.3085	.4877
22	.9533	1.2758	.5258	1.2277	1.1622	1.1751	.6097
23	1.0135	1.1728	.5258	1.1816	1.134	1.2121	.6706
24	1.1401	1.0486	.4801	1.105	1.186	1.262	.5792
Max	1.3424	1.2758	.5731	1.2277	1.3184	1.4838	1.2308
Min	.9407	.8154	.3856	.7651	.9831	1.0535	.2439
Avg	1.1705	1.0147	.4804	.9824	1.1642	1.2426	.7434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 204 / 11 KV Nagrale Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5268	1.5543	.7947	1.6724	1.5436	1.5356	1.4872
2	1.47	1.4815	.7762	1.6125	1.4807	1.5028	1.4535
3	1.4655	1.4716	.7577	1.6472	1.4662	1.4762	1.4296
4	1.4578	1.5462	.8316	1.6766	1.4987	1.4967	1.4621
5	1.5642	1.7463	.9055	1.7752	1.6762	1.6735	1.6007
6	2.207	2.1711	1.0903	2.1971	2.0039	2.1658	2.0679
7	2.2402	2.2318	.9795	2.2112	1.8682	2.2098	2.1079
8	1.7288	1.691	.7762	1.5752	1.6072	1.6623	1.7021
9	1.2765	1.3458	.7207	1.3813	1.363	1.2618	1.3382
10	1.331	1.2441	.7207	1.2633	1.3519	1.2414	1.2296
11	1.2803	1.3847	.7023	1.3325	1.1593	1.3165	1.1584
12	1.3054	1.6276	.462	1.4556	1.4085	1.4022	1.2742
13	1.2761	1.5127	.7392	1.4693	1.451	1.3435	.6196
14	1.3554	1.4396	.7023	1.4357	1.4664	1.344	.6158
15	1.4148	1.4459	.7762	1.4464	1.487	1.4263	.6089
16	1.4464	1.5053	.7023	1.1763	1.4738	1.4723	.6104
17	1.3275	1.4123	.6468	1.097	1.4891	1.2822	.6165
18	1.3954	1.1186	.7392	1.4526	1.4457	1.3184	.644
19	1.8755	1.744	1.0164	2.0744	1.8001	1.832	.8147
20	2.149	2.1826	1.1088	2.2634	2.1887	2.1689	1.025
21	2.1502	2.0652	1.0719	2.1304	2.1285	2.0908	1.0021
22	2.0557	2.0969	1.0719	2.013	2.0888	1.9886	1.0105
23	1.9307	1.8796	.924	1.872	1.8618	1.8469	.9023
24	1.6712	1.6415	.8316	1.7132	1.7033	1.571	.7667
Max	2.2402	2.2318	1.1088	2.2634	2.1887	2.2098	2.1079
Min	1.2761	1.1186	.462	1.097	1.1593	1.2414	.6089
Avg	1.6209	1.6475	.827	1.6643	1.6255	1.6096	1.1478

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 205 / Satteshwar LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4854	.4904	.5658	.6224	.6413	.5788
2	.5041	.4904	.6036	.6224	.6224	.5975
3	.5093	.5281	.6036	.6036	.6413	.6224
4	.5093	.5281	.6036	.6224	.6224	.6224
5	.5041	.5658	.6036	.6413	.6036	.6224
6	.4854	.5847	.6036	.6413	.3734	.6036
7	.5601	.5847	.6036	.6602	.6161	.6413
8	.6224	.6224	.6036	.6413	.6413	.6413
9	.6224	.6036	.6224	.6602	.6602	.6413
10	.6413	.6602	.6224	.6602	.6413	.6413
11	.6036	.6602	.6224	.6348	.6413	.6036
12	.6036	.6413	.5847	.6224	.6224	.5658
13	.6036	.6036	.5847	.6224	.6224	.5658
14	.4338	.6036	.6224	.6161	.6036	.6036
15	.415	.6036	.6224	.6036	.5658	.5847
16	.415	.6036	.6036	.5847	.5658	.6036
24			.6036			
Max	.6413	.6602	.6224	.6602	.6602	.6413
Min	.415	.4904	.5658	.5847	.3734	.5658
Avg	.5324	.5859	.6047	.6287	.6053	.6087

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 202 / 11 KV MIDC PALUS FEEDER SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2437	1.2248	.6224	.5601	.5847	.6036	.5415
2	1.2437	1.1755	.5847	.5175	.5847	.5847	.5415
3	1.1944	1.1682	.6036	.5359	.6036	.6036	.5228
4	1.1944	1.1682	.5847	.5304	.6036	.5658	.5281
5	1.2248	1.1871	.5658	.5121	.6036	.5847	.5658
6	1.2248	1.2059	.5847	.543	.6036	.5847	.5415
7	1.2248	1.2059	.6224	.5601	.6036	.6413	.5228
8	1.3119	1.4744	.6602	.6722	.6413	.6979	.5658
9	1.8082	1.9661	.9619	.8029	.6979	.9619	.6036
10	2.0877	2.5568	.8775	.7455	.7655	1.363	.5847
11	2.2922	2.8875	.9709	.9114	.7796	1.7164	.5847
12	2.5175	2.7473	1.0642	.9877	.7545	1.3375	
13	2.4326	2.4021	1.307	1.0269	.7545	1.1065	
14	3.1436	3.3078	1.4937	1.0269	1.1443	1.1488	
15	3.3593	3.4119	1.4563	1.4523	1.475	1.1616	
16	3.0407	3.4844	1.419	1.6598	1.0751	1.2936	
17	2.4901	3.7022	.9896	1.094	.7922	.8688	
18	1.8169	2.3425	.9054	.9054	.6036	.7373	
19	1.6457	1.4716	.6224	.6979	.6036	.583	
20	1.5166	1.3918	.6036	.5847	.6036	.567	
21	1.4788	1.3801	.6036	.5847	.5658	.5601	
22	1.3801	1.4223	.5847	.6224	.6036	.5847	
23	1.3308	1.3613		.6224	.5847	.5847	
24	1.2437	1.3235	.6413	.5658	.5847	.5847	.5658
Max	3.3593	3.7022	1.4937	1.6598	1.475	1.7164	.6036
Min	1.1944	1.1682	.5658	.5121	.5658	.5601	.5228
Avg	1.8103	1.9571	.8404	.7801	.7174	.8344	.5557

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 203 / 11 KV GONDILWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3174	.2926	.3206	1.3757	1.4575	.8768	.3361
2	.3142	.2987	.3018	1.2266	1.442	.8025	.3361
3	.3142	.2772	.2829	1.1401	1.442	.7628	.3206
4	.3142	.2801	.3018	1.0774	1.4089	.7775	.3206
5	.3511	.2957	.3395	1.1469	1.4251	.8429	.3206
6	.3696	.3547	.3961	1.5729	1.4737	.9259	.3361
7	.3696	.3292	.3921	2.0891	1.8785	1.0911	.3547
8	.3326	.2561	.3292	.2785	.2957	.2835	.3258
9	2.3205	2.6882	.2587	.2743	.2534	2.1822	2.7515
10	2.4291	.9282	.2587	.2561	.2772	2.2996	2.4741
11	2.2996	2.5549	.2587	.2772		1.9204	2.3967
12	2.0005	2.3472	.2534		.2561	1.866	
13	1.7966	2.0645	.2534		.2149	1.781	
14		2.1216	.2534		.2195	1.7553	
15		2.1714	.2534		.2534	1.7604	
16	1.7394	2.1948	.2587	.3045	.2896	1.6872	
17	.2629	.2743	.2587	.3258	.2835	.2835	
18	.3012	.2772	.3109	.3658	.3012	.3511	
19	.3475	.3658	.3734	.3841	.3658	.3841	
20	.3696	.3547	.4338	.4207	.3921	.4294	
21	.3511	.3547	.415	.3511	.3921	.4108	
22	.3361	.3734	2.452	1.7004	1.3435	.3961	
23	.3361	.3361		1.4575	1.1702	.3734	
24	.3174	.3174	.3174	1.5708	1.4575	.9907	.3734
Max	2.4291	2.6882	2.452	2.0891	1.8785	2.2996	2.7515
Min	.2629	.2561	.2534	.2561	.2149	.2835	.3206
Avg	.8132	.9212	.4032	.8798	.7954	1.0514	.8872

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 204 / 11 KV MINI MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1698	.2452	.1886	.1886	.1886	.1886
2	.1509	.1698	.2452	.1886	.1886	.1886	.1698
3	.1081	.1509	.2263	.1698	.1886	.1886	.1698
4	.1509	.1509	.2452	.1509	.1886	.1698	.1509
5	.1216	.1886	.2263	.1509	.2075	.1886	.1509
6	.1886	.2075	.2263	.1509	.2075	.2075	.1698
7	.1698	.2263	.2263	.1509	.2075	.1886	.1698
8	.1886	.3584	.3584	.2263	.3395	.3961	.1698
9	.3772	.3982	.415	.4338	.3584	.3772	.2075
10	.3961	.4207	.3584	.3982	.3734	.3772	.3206
11	.4338	.4207	.3961	.4066		.2656	.3584
12	.415	.3841	.3772	.3734	.3601	.3258	
13	.3772	.3547	.3395	.3395	.3294	.3294	
14	.3961	.3772	.3961	.3772	.3429	.3086	
15	.3772	.3961	.3961	.3961	.3429	.285	
16	.3772	.3961	.3772	.3961	.3641	.2721	
17	.3584	.3734	.3584	.3961	.3772	.3395	
18	.3206	.415	.3206	.3772	.3206	.3018	
19	.3206	.3584	.3018	.3961	.2452	.2452	
20	.2829	.3961	.2641	.3395	.2263		
21		.3395	.2427	.2641	.1698		
22	.2263	.3018	.2075	.2075	.1698		
23	.1886	.2641		.2263	.1698	.1886	
24	.2641	.1886	.2452	.2075	.1886	.1886	.1886
Max	.4338	.4207	.415	.4338	.3772	.3961	.3584
Min	.1081	.1509	.2075	.1509	.1698	.1698	.1509
Avg	.2765	.3086	.3041	.2880	.2633	.2629	.2012

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 205 / 11 KV MAHADA COLONY

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.168	.1307	.1578	.1478	.1494	.1433
2	.1307	.1494	.1307	.1578	.1494	.1478	.132
3	.1307	.1294	.1132	.1433	.1494	.1294	.1267
4	.1294	.1463	.1307	.1433	.1494	.1307	.1448
5	.1663	.1463	.1494	.1646	.1663	.1509	.1646
6	.2033	.1629	.2054	.1991	.1663	.168	.1791
7	.2218	.181	.2218	.2328	.1791	.2012	.1928
8	.1715	.1612	.197	.1928	.1612	.1543	.1886
9	.1402	.1387	.1715	.1715	.1791	.1543	.1578
10	.156	.1372	.1029	.1492	.1402	.1254	.156
11	.156	.1543	.1753	.1543		.1402	.1214
12	.1357	.1677	.156	.156	.156	.1372	
13	.1578	.1492	.1387	.156	.1543	.1326	
14	.1417	.1492	.1753	.156	.156	.156	
15	.1543	.1677	.1402	.1715	.1387	.1372	
16	.1543	.1715	.1715	.1715	.1372	.1543	
17	.1696	.1715	.2058	.1989	.1526	.1214	
18	.1802	.1526	.2058	.2035	.1492	.1715	
19	.1907	.2303	.2058	.2126	.1734	.1886	
20	.2012	.2033	.2103	.1753	.1829	.2058	
21	.1867		.1886	.1663	.1848	.1886	
22	.1886		.1715	.1663	.2033	.1677	
23	.1698	.1867		.1478	.168	.1715	
24	.168	.1698	.1494	.1543	.1478	.1494	.1578
Max	.2218	.2303	.2218	.2328	.2033	.2058	.1928
Min	.1294	.1294	.1029	.1433	.1372	.1214	.1214
Avg	.1647	.1634	.1673	.1709	.1605	.1556	.1554

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 206 / 11 KV M.I.D.C. JAWAHAR SHEDDABLE FEEDER HAVING WEEKLY
 VIDYLAY Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4034	1.3657	.6413	.7545	1.4295	1.6457	1.5586
2	1.2814	1.3279	.6224	.7167	1.3685	1.5963	1.5702
3	1.3119	1.3279	.6224	.7356	1.4788	1.5963	1.5702
4	1.3076	1.3396	.6036	.7167	1.4788	1.5775	1.5702
5	1.338	1.3584	.5847	.679	1.4788	1.5848	1.5586
6	1.2466	1.415	.6036	.679	1.5471	1.6152	1.608
7	1.2044	1.4034	.7167	.7167	1.4905	1.634	1.608
8	.9143	1.3845	.6602	.9808	1.4483	1.6152	1.6036
9	2.247	1.8589	.6602	1.5655	1.5397	1.5775	1.5397
10	2.6239	2.692	1.094	1.6032	2.7052	2.6921	1.4483
11	2.4919	2.8498	1.2449	1.6221	3.2188	3.0788	1.3424
12	3.1622	2.4596	.9619	1.5278	3.1129	2.8685	.7011
13	3.2178	2.319	.7356	1.3957	1.1888	1.949	.7011
14	3.469	2.5701	1.0082	1.3957	2.7778	2.7052	.7011
15	3.2606	2.4033	1.0082	.7975	2.2651	2.7341	.7011
16	3.2823	2.2857	1.0829	.6009	2.553	2.6616	.7011
17	2.8734	2.5745	1.0082	1.6975	2.9388	2.0958	.7316
18	2.3497	2.1653	.811	.9808	2.7153	1.608	.7316
19	1.7211	1.7604	.6979	.679	2.1291	1.608	.7316
20	1.695	1.4411	.7545	.679	1.7255	1.5775	.7926
21	1.608	1.4528	.7356	.6602	1.6573	1.5775	.823
22	1.4295	1.3729	.7733	.7167	1.6385	1.5586	.8535
23	1.3235	1.4106		.6979	1.6645	1.5397	.823
24	1.3729	1.3235	.679	.7468	1.5514	1.634	1.5702
Max	3.469	2.8498	1.2449	1.6975	3.2188	3.0788	1.608
Min	.9143	1.3235	.5847	.6009	1.1888	1.5397	.7011
Avg	2.0056	1.8276	.7961	.9727	1.9626	1.9305	1.1475

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 201 / 11KV ASAD

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.8288	1.9391	2.1567	.0343	.0335
2	.0857	.0343	.7545	1.8233	2.0721	.0343	.0335
3	.0343	.0343	.6706	1.6728	2.0096	.0343	.0335
4	.0343	.0343	.663	1.6941	1.9822	.0343	.0335
5	.0343	.0514	.7373	1.7387	1.9125	.0343	.0335
6	.0343	.0343	.7373	1.9121	1.9872	.0343	.0335
7	.0343	.0514	.9012	1.989	1.9018	.0343	.0335
8	.0335	.0554	.0549	.0343	.0343	1.523	1.6407
9		1.5565	.0514	.0343	.0343	3.0963	3.1176
10		1.5565	.0343	.0343	.0343	3.3006	3.0849
11		1.5746	.0343	.0343	.0343	3.3653	2.9012
12	1.3592	1.4918	.0343	.0343	.0343	3.3368	.5258
13	1.326	1.4918	.0514	.0351	.0343	3.1028	
14		1.2431	.0686	.0343	.0343	2.6814	
15		1.2431	.0686	.0343	.0343	2.5614	
16	1.2574	1.1603	.0514	.0419	.0343	2.8102	1.3984
17	.0366	.0366	.0514	.0343	.0343	.0503	
18	.0366	.0366	.0514	.0343	.0514	.0671	
19	.0549	.0549	.0514	.0343	.0514	.0671	
20	.0549	.0549	.0514	.0343	.0514	.0671	
21	.0549	.0549	.0514	1.1096	.0514	.0671	
22	.0343	.9831	.9995	2.4203	.0514	2.4905	
23	.0343	.9945	.9667	2.3708	.0514	2.4905	
24	.0343	.0343	.8288	2.154	1.0486	.0514	.0335
Max	1.3592	1.5746	.9995	2.4203	2.1567	3.3653	3.1176
Min	.0335	.0343	.0343	.0343	.0343	.0343	.0335
Avg	.2425	.5791	.3664	.8866	.6551	1.3070	.9240

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 202 / 11KV MOHITE VADGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.7458	4.4239	.12	.3658	.3056	3.1843	4.7265
2	4.5934	4.0577	.0857	.33	.3079	3.0136	4.5001
3	4.4418	3.9856	.0857	.3285	.3026	2.942	4.1884
4	4.2778	3.7426	.12	.3463	.1631	2.9789	3.4645
5	4.1454	3.9373	.12	.3674	.3071	3.1211	4.1381
6	4.2288	4.2189	.1715	.442	.3696	3.5269	4.2288
7	4.5969	4.6178	.1715	.453	.4248	3.8721	4.4216
8	.3951	.4134	.1829	.6752	.6707	.3605	.4652
9	.3856	.3319	3.2579	7.1224	6.358	.3254	.3773
10	.3067	.3224	2.7435	6.6849	7.0427	.3082	.3498
11	.277	.3098	2.8464	6.3763	6.3816	.28	.3585
12	.3204	.3468	2.8292	6.2391	6.131	.2995	.4055
13	.312	.3425	3.0864	5.9808	6.081	.3407	.2225
14	.3235	.3463	3.1036	5.6394	5.8566	.3361	.2111
15	.2976	.3387	3.0178	5.5876	5.5773	.298	.2035
16	.3501	.3326	2.7778	4.7851	5.3193	.3453	.2126
17	.3688	.333	.1715	.3841	.3029	.4317	.2073
18	.4108	.3452	.2058	.4161	.3209	.434	.1951
19	.423	.349	.2058	.487	.3319	.439	.1875
20	.4374	.4489	.2401	.4869	.3479	.4596	.2301
21	.5593	.4473	.2229	.4588	.575	.4748	.4611
22	5.6227	.423	.2058	.4123	4.3614	3.1238	2.8372
23	5.2351	.3601	.2058	.3338	3.908	3.3036	3.1771
24	5.0938	2.4503	.12	.3491	2.1529	3.9762	5.0869
Max	5.6227	4.6178	3.2579	7.1224	7.0427	3.9762	5.0869
Min	.277	.3098	.0857	.3285	.1631	.28	.1875
Avg	2.1729	1.5510	1.0957	2.2938	2.6625	1.5906	1.8690

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 203 / 11 KV 4TH SONSAL FEEDER NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0857	.0857	.0343	.0686	.0686	.0686
2	.0343	.0514	.0514	.0343	.0686	.0514	.0686
3	.0514	.0514	.0514	.0343	.0686	.0514	.0686
4	.0514	.0857	.0514	.0343	.0686	.0514	.0686
5	.0514	.0857	.0857	.0686	.0686	.0514	.0686
6	.0514	.1029	.0857	.0686	.0686	.0514	.0686
7	.0686	.12	.0857	.0857	.0686	.0514	.0686
8	.0686	.0732	.0914	.0857	.0686	.1029	.0686
9	.0686	.0514	.0343	.0343		.0343	.0686
10	.0686	.0343	.0343	.0686	.0343	.0343	.0686
11	.0857	.0514	.0343	.0686	.0343	.0343	.0514
12	.0857	.12	.0343	.0686	.0343	.0343	.0857
13	.0514	.0857	.0343	.0686	.0343	.0514	
14	.0514	.0857	.0343	.0686	.0343	.0514	
15	.0514	.0857	.0686	.0686	.0686	.0514	
16	.0857	.0857	.0686	.0686	.0857	.0514	
17	.0914	.0857	.0686	.0686	.0686	.0686	.0008
18	.1097	.0914	.0686	.0686	.0343	.0686	
19	.0914	.0366	.0343	.0686	.0343	.0686	
20	.0518	.0549	.0343	.0686	.0514	.0686	
21	.0549	.0914	.0343	.0686	.0514	.0686	
22	.0857	.0857	.0686	.0686	.0514	.0686	
23	.0857	.0857	.0686	.0686	.0686	.0686	
24	.0343	.0857	.0857	.0686	.0686	.0686	.0686
Max	.1097	.12	.0914	.0857	.0857	.1029	.0857
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0008
Avg	.0652	.0780	.0581	.0629	.0567	.0571	.0638

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 204 / 11KV MOHITE VADGAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7548	.844	.3429	.9549	.969	.9282	.8379
2	.7396	.7411	.2572	.8715	.9903	.9145	.8356
3	.7803	.7377	.2572	.868	.9796	.8802	.8257
4	.812	.82	.3429	.9297	.9651	.9099	.8905
5	.8524	1.0151	.5144	1.0131	.9769	1.0235	.9724
6	1.1542	1.1801	.6001	1.2193	1.1771	1.233	1.0696
7	.0751	1.3229	.6001	1.3618	1.3078	1.3428	1.198
8		1.3248	.6401	1.1286	1.1538	1.0916	1.1553
9		.9766	.4572	.9072	1.0295	.9141	.9225
10	.0023	.9481	.4755	.9115	.926	.9067	.8634
11	.6284	.8981	.4938	.8802	.9172	.9124	.7876
12	.4473	.4169	.4938	.9228	.9842	.9016	.833
13		.1715	.4835	.9317	1.0547	.9103	.4378
14		1.1138	.4477	.9812	1.0314	.8604	.4492
15	.9103	.9137	.4656	.9012	1.0536	.8432	.4519
16	1.3233	1.0844	.3982	.884	1.0692	1.0193	.4641
17	1.3111	1.1321	.4298	1.0356	1.0669	.916	.4988
18	1.361	1.1641	.5373	1.1378	1.1694	1.1001	.5415
19	1.438	1.3542	.6447	1.2905	1.3271	1.2373	.5845
20	1.4407	1.4894	.7164	1.4963	1.5208	1.4895	.8078
21	1.4517	1.468	.6805	1.4541	1.4449	1.4746	.7998
22	1.283	1.3496	.6089	1.2849	1.3169	.7198	.7335
23	1.1915	1.2151	.5373	1.2197	1.2114	1.1625	.6882
24	.8832	.8954	.3429	1.0414	1.0612	.9907	.9359
Max	1.4517	1.4894	.7164	1.4963	1.5208	1.4895	1.198
Min	.0023	.1715	.2572	.868	.9172	.7198	.4378
Avg	.9420	1.0240	.4903	1.0678	1.1127	1.0284	.7744

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 205 / 11 KV RAMAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.5784	5.2774	.0086	.0514	.0671	4.7015	5.8337
2	5.2432	4.6792	.0857	.0514	.0671	4.372	5.2736
3	4.9478	4.1876	.0857	.0686	.0671	4.1368	4.8964
4	4.8258	3.9742	.0857	.0686	.0671	4.1228	4.6106
5	4.4372	4.222	.0857	.0857	.0671	4.1228	4.2943
6	4.563	4.2448	.0857	.1029	.0671	4.1865	4.2829
7	4.5715	4.5991	.0857	.1029	.0671	4.386	4.4658
8	.1646	.0924	.0914	.1029	.0671	.0857	.0686
9	.0905	.0857	2.9492	3.4507	6.2033	.0983	.1029
10	.0857	.0857	2.3758	3.5894	6.7238	.0655	.0983
11	.0857	.0857	2.2283	3.5285	6.6282	.0655	.0983
12	.0857	.0857	2.2119	3.5285	6.2064	.0819	.0983
13	.0857	.0857	1.5729	5.609	5.5037	.0819	
14	.0914	.0857	1.5565	5.6699	5.1193	.0819	.2134
15	.0914	.0857	1.5402	5.6561	4.9155	.0655	
16	.0857	.0857	1.3108	5.3094	4.8217	.0983	
17	.0914	.0914	.0514	.0857	.0686	.1006	
18	.0914	.0914	.0686	.0686	.0857	.1029	
19	.0914	.0914	.0686	.0686	.1029	.1006	
20	.0914	.0914	.0686	.0686	.12	.1006	
21	.0914	.0914	.0686	.0686	.1029	.1006	
22	6.2719	.0857	.0686	.0686	5.2245	6.7711	3.5056
23	6.169	.0857	.0686	.0686	5.233	6.954	3.597
24	5.8691	.1829	.0857	.0514	2.8426	5.7764	6.2109
Max	6.2719	5.2774	2.9492	5.6699	6.7238	6.954	6.2109
Min	.0857	.0857	.0086	.0514	.0671	.0655	.0686
Avg	2.2417	1.3656	.7045	1.5635	2.5183	2.1150	2.9782

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 206 / 11 KV CHINCHNI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0857	.9945	2.4684	2.4272	.0514	
2	.0686	.0686	.8383	2.3106	2.3357	.0514	.0686
3	.0686	.0686	.8383	2.2304	2.1929	.0514	.0686
4	.0686	.0857	.9116	2.1999	2.1872	.0514	.0686
5	.0857	.0857	.9945	2.3298	2.1567	.0686	.0686
6	.0857	.0857	.9831	2.2967	2.1567	.0686	.0686
7	.128	.0857	1.1469	2.3743	2.2424	.0857	.0686
8	.0857	.0914	.0914	.2076	.0671	.0686	.0686
9	3.0998	3.5285	.0857	.0857	.0655	2.5983	3.294
10	3.1607	3.8752	.0819	.0857	.0838	2.9169	3.4183
11	3.2426	3.7114	.0983	.0686	.0819	3.1089	3.3341
12	3.2903	3.6694	.0983	.0686	.0655	3.5307	1.829
13	3.1302	3.416	.0655	.0686	.0655	3.5261	
14	.0914	3.2903	.0655	.0686	.0655	3.3036	
15	1.5546	3.2598	.0819	.0686	.0655	2.875	
16	3.0855	3.1626	.0655	.0686	.0655	2.8467	
17	.0914	.0732	.0686	.0686	.0686	.253	
18	.0914	.0914	.0686	.0686	.0686	.1029	
19	.0914	.0914	.0857	.0686	.0857	.1029	
20	.0914	.0924	.0857	.0686	.0857	.1006	
21	.0914	.0914	.0686	.0686	.0686	.1006	
22	.0857	2.2843	1.2431	2.4623	.0686	.0671	
23	.0857	2.3577	1.21	2.6147	.0686	.0671	
24	.0655	1.2879	.9945	2.5651	1.1797	.0514	.0686
Max	3.2903	3.8752	1.2431	2.6147	2.4272	3.5307	3.4183
Min	.0655	.0686	.0655	.0686	.0655	.0514	.0686
Avg	.9170	1.4558	.4694	1.0411	.7508	1.0854	1.0354

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 201 / 11 KV Wine Park 1

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0629	.0985	.0857	.2172	.1257	.1006	.08
2	.0686	.08	.0838	.1949	.1257	.1166	.108
3	.0734	.0781	.0943	.197	.1143	.1349	.1036
4	.0914	.0724	.0734	.2172	.1257	.1132	.0838
5	.1486	.0629	.0754	.2378	.1086	.1105	.0777
6	.1734	.0713	.0482	.2172	.1086	.1189	.0869
7	.0823	.0869	.2263	.5194	.4854	.6535	.0625
8	.3086	.2267	.7545	.0972		.2534	.072
9	1.1317	.9717	.7545	1.2826	.6979	1.0185	.1536
10	1.1317	1.1317	.7922	1.8107	.9907	1.0374	
11	1.1317	.9431	.811	1.1694	1.226	1.2826	
12	.7922	.8488	.3961	1.6221	1.0751	1.0185	
13	.6602	.2705	.1635	1.9616	.7356	.7356	
14	.8299	.8488	.7468	1.9805	1.226	.7545	
15	1.1128	1.1317	.8029	1.5089	.9054	.7733	
16	1.1128	.9431	.3475	1.1128	.7545	.7545	
17	.7922	.7545	.5415	.7545	.3395	1.2071	
18	.6413	.5601	.6602	.5658	.6413	.9619	
19	.1797	.4572	.5415	.3772	.6979	.7733	
20	.1867	.1257	.4251	.2641	.1806	.1677	
21	.1006	.1048	.5041	.2263	.1115	.2587	
22	.1006	.1166	.3601	.2075	.1395	.156	.0503
23	.1027	.1048	.1189	.1886	.1029	.1404	.0476
24	.0686	.1006	.5415	.08	.1886	.1153	.1257
Max	1.1317	1.1317	.811	1.9805	1.226	1.2826	.1536
Min	.0629	.0629	.0482	.08	.1029	.1006	.0476
Avg	.4619	.4246	.4145	.7088	.4873	.5315	.0876

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 202 / 11 KV Andhali Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9919	2.0081	.415	.3258	.3734	1.8442	2.0485
2	1.9919	2.0081	.415	.3395	.3734	1.8275	2.0567
3	2.0153	2.0165	.415	.3206	.3772	1.8107	2.0567
4	2.0153	2.0165	.415	.3206	.3772	1.8515	2.0567
5	2.0081	2.1052	.4338	.3584	.415	2.0056	2.0645
6	2.0005	2.2283	.4527	.4527	.4715	2.2298	2.2024
7	2.2405	2.2939	.5658	.5281	.5847	2.3975	2.3266
8	.4338	.3961	.4904	.415		.5093	.4527
9	.415	.3772	2.1862	2.6886	2.8509	.4338	.547
10	.3961	.4527	2.556	2.9504			
11	.3961	.4715	3.0312	2.8509	2.5943	.3395	
12	.4527	.4338	3.0121	2.8673	2.8656	.3584	
13	.4715	.415	2.8016	2.8673	2.7999	.3584	
14	.4527	.415	2.4166	2.6719	2.7854	.3395	
15	.4527	.415	2.3967	2.6216	2.8673	.3206	
16	.4527	.415	2.2297	2.4905	3.0498	.3206	
17	.4715	.5093	.3961	.3277	.5281	.4715	
18	.4715	.5658	.415	.3605	.4904	.4904	
19	.4904	.5658	.5658	.3978	.547	.4715	
20	.5093	.6036	.5658	.4854	.5658	.4904	
21	.4676	.5281	.547	.4854	.547	.4904	
22	2.3765	.5093	.4527	.4481	2.3304	2.2405	2.2565
23	2.1925	.415	.3961	.4108	2.0645	2.1285	2.0557
24	1.9685	2.0317	.3961	.3584	.3734	1.8623	2.0485
Max	2.3765	2.2939	3.0312	2.9504	3.0498	2.3975	2.3266
Min	.3961	.3772	.3961	.3206	.3734	.3206	.4527
Avg	1.1306	1.0082	1.1653	1.1810	1.3742	1.1127	1.8477

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 203 / 11Kv Andhali Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2715	.2987	.3361	.3018	.2427	.2829	.3361
2	.2743	.2987	.3361	.2829	.2427	.2829	.3547
3	.2926	.2829	.3547	.2641	.2427	.3206	.3734
4	.3206	.2641	.3772	.2641	.2801	.3584	.3921
5	.3584	.2641	.3961	.2829	.3361	.4527	.3921
6	.4527	.3206	.3772	.2641	.3734	.5281	.4481
7	.5281	.5093	.4904	.3772	.4163	.5281	.4854
8	.3961	.4024	.3772	.3511		.4298	.3881
9	.3772	.3258	.3584	.3544	.3077	.3294	.3224
10	.3189	.3475	.2801	.3544	.2303	.333	
11	.2835	.3772	.2303	.3475	.2865	.3155	
12	.3012	.3174	.2507	.3292	.2947	.3224	
13	.3189	.2629	.3403	.2957	.2835	.3045	
14	.3224	.2481	.3403	.2987	.3189	.2865	
15	.3439	.2378	.3189	.3361	.3077	.3045	
16	.3258	.2427	.3189	1.1128	.3189	.3045	
17	.3258	.2614	.3544	.4108	.2686	.3155	
18	.3391	.3012	.3681	.4481	.1886	.4607	
19	.3391	.4706	.5014	.4854	.394	.4607	
20	.3721	.5847	.5544	.4854		.5359	
21	.3921		.3702	.4854	.6224	.499	
22	.3734	.4338	.3319	.4481	.4904	.4904	.415
23	.3584	.3772	.2841	.3734	.3772	.3584	.2829
24	.3018	.3174	.3544	.3395	.2427	.3395	.3174
Max	.5281	.5847	.5544	1.1128	.6224	.5359	.4854
Min	.2715	.2378	.2303	.2641	.1886	.2829	.2829
Avg	.3453	.3368	.3584	.3872	.3212	.3810	.3756

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 204 / 11KV BAMBAWADE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.144	.144	.4801	1.6636	1.9783	.352	.3459
2	.144	.128	.4801	1.6042	1.8937	.3322	.3246
3	.144	.128	.4801	1.6339	1.88	.3277	.3193
4	.144	.128	.4801	1.5951	1.8686	.3437	.3178
5	.176	.144	.4801	1.7688	2.0272	.3612	.3239
6	.2241	.16	.7042	2.2124	2.2908	.4503	.4031
7	.2401	.192	.8642	3.0247	2.5407	.4778	.445
8	.192	.144	.112	.3444	.4138	.4283	.3292
9	1.1363	1.5524	.08	.2324	.2835	2.7275	2.5111
10	1.0883	1.4403	.096	.192	.1829	2.5797	1.4944
11	1.0883	1.0402	.096	.2355	.1913	2.4714	1.4106
12	.8642	1.1203	.096	.2484	.2141	2.2976	1.2582
13	.8002	1.1203	.096	.2454	.2423	2.0721	
14		1.1043	.096	.2301	.2286	2.1003	
15	.8002	1.1043	.112	.2477	.2469	2.0386	
16	.7202	.8002	.112	.2477	.2446	1.97	1.0037
17		.128	.128	.3132	.2926	.2095	.2012
18		.144	.16	.3688	.2774	.2408	.2088
19	.16	.16	.176	.4084	.3696	.3239	.2233
20	.1532	.192	.176	.4427	.2507	.4267	.2545
21	.176	.176	.176	.4244	.4221	.4511	.2545
22	.16	.5601	.7682	2.0203	.4199	.2624	.4671
23	.16	.5441	.9122	2.0858	.4016	.4054	.4427
24	.144	.144	.4961	1.2795	.9862	.3581	.394
Max	1.1363	1.5524	.9122	3.0247	2.5407	2.7275	2.5111
Min	.144	.128	.08	.192	.1829	.2095	.2012
Avg	.4219	.5208	.3274	.9612	.8395	1.0003	.6159

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 205 / 11 KV MORALE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.096	.08	1.2803	3.014	2.7427	.1562	.1859
2	.096	.08	1.2803	2.9698	2.6802	.1593	.1669
3	.096	.08	1.2803	2.9294	2.646	.1646	.1715
4	.096	.08	1.2803	2.937	2.5955	.1654	.1676
5	.096	.08	1.2803	2.995	2.7793	.1661	.1905
6	.112	.112	1.2963	3.062	2.8928	.2118	.205
7	.128	.112	1.3443	3.2473	3.1138	.2263	.221
8	.128	.08	.096	.2545	.2248	.4527	.2454
9	1.9204	1.8564	.08	.2225	.1821	4.0458	4.5893
10	1.9204	1.7604	.08	.2141	.1829	3.9598	2.5316
11	1.9524	1.7284	.08	.0945	.189	4.0329	2.5865
12	1.7764	1.7284	.08		.2141	4.1655	2.4364
13	1.6964	1.6964	.096	.1154	.2149	4.215	
14		1.6804	.08	.1532	.1943	4.1731	
15	1.5524	1.6324	.08	.1593	.2057	4.1305	
16	1.4723	1.5524	.096	.0991	.2004	4.087	2.0538
17	.112	.096	.112	.064	.2164	.1852	.1349
18	.08	.112	.112	.1615	.2195	.1943	.1288
19	.08	.096	.112	.2339	.189	.2111	.1364
20	.096	.096	.096	.2317	.2004	.2233	.1364
21	.096	.08	.096	.2454	.2073	.2035	.1395
22	.096	1.3123	1.4563	2.8883	.1897	.205	.2225
23	.08	1.2803	1.4883	2.9592	.1852	.2141	.1882
24	.096	.08	1.2483	2.9043	1.3489	.1676	.1875
Max	1.9524	1.8564	1.4883	3.2473	3.1138	4.215	4.5893
Min	.08	.08	.08	.064	.1821	.1562	.1288
Avg	.6032	.7288	.6055	1.3981	1.0006	1.5048	.8107

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 401 / 33 KV SOOTGIRANI

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6975	1.5684	1.6975	1.9547	1.8427	1.8759	1.7306
2	1.5844	1.6804	1.5844	1.9547	1.8256	1.8587	1.8427
3	1.5844	1.5684	1.5844	1.8427	1.8245	1.9718	1.8599
4	1.5844	1.5684	1.5278	1.8085	1.8073	1.8073	1.8427
5	1.6975	1.6804	1.5278	1.7913	1.8073	1.8587	1.9547
6	1.6975	1.6804	1.5278	1.7913	1.8587	1.8587	1.9547
7	1.4146	1.5684	1.5844	1.8085	1.7284	1.8587	2.0667
8	1.6975	1.5684	1.5844	1.7306	1.8587	1.9718	2.0667
9	1.5278	1.4563	1.4146	1.7306	.2743	1.5192	1.7306
10	1.4563	1.4563	1.4563	1.8256	1.7135	1.9547	.2743
11	1.4563	1.4146	1.5684	1.6186	1.7306	1.9376	.2743
12	1.4712	1.5684	1.5684	1.9205	1.5021	1.9204	.2401
13	1.4563	1.6804	1.6804	1.7913	1.8245	1.9204	.2401
14	1.5684	1.5123	1.5684	1.7913	1.7113	1.7925	.2572
15	1.6975	1.5684	1.4563	1.9033	1.8073	1.9033	.2229
16	1.8107	1.6975	1.4563	1.9205	2.085	2.085	.2572
17	1.8107	1.5278	1.5684	1.9033	1.6152	2.0496	.2743
18	1.6804	1.4146	1.5684	1.3432	1.8416	1.8427	.2743
19	1.5684	1.4712	1.4563	1.7742	1.5021	1.8427	.2915
20	1.5524	1.358	1.4563	1.3261	1.5021	1.8427	.2743
21	1.4415	1.5278	1.4563	1.7913	1.5021	1.8427	.2915
22	1.5684	1.5844	1.6804	1.7913	1.7284	1.8427	1.8427
23	1.7924	1.5844	1.7924	1.757	1.8416	1.8427	1.8599
24	1.6975	1.8107	1.5684	2.0667	1.8427	.2743	1.7478
Max	1.8107	1.8107	1.7924	2.0667	2.085	2.085	2.0667
Min	1.4146	1.358	1.4146	1.3261	.2743	.2743	.2229
Avg	1.6048	1.5632	1.5556	1.7890	1.6907	1.8115	1.0697

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 203 / 11 KV PALUS

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	04-APR-17
HR	Load (MW)
24	.9335
Max	.9335
Min	.9335
Avg	.9335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 201 / KADEPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905	.2195	1.8351	1.9662	1.9109	.2241	.2195
2	.0914	.2195	1.7695	1.7695	1.8623	.2241	.2195
3	.0905	.2195	1.8564	1.704	1.7814	.2241	.2218
4	.1254	.2195	1.9227	1.749	1.7814	.2263	.2195
5	.124	.2195	1.9662	1.7695	1.7814	.2263	.2561
6	.1214	.2195	2.0081	1.8351	1.7394	.2263	.2957
7	.1214	.2926	1.9433	1.9433	1.9524	.2987	.3326
8	.1227	.3658	.2957	.3326	.2926	.2987	.3658
9	.2785	2.9492	.2957	.2987	.2926	2.5911	2.8182
10	2.7526	3.1161	.2987	.2926	.2957	2.9835	
11	2.8182	3.0498	.2926	.2926	.2241	3.0498	
12	2.7854	2.9492	.2957	.2926	.2218	3.0803	
13		2.7206	.3696		.2241	2.915	
14		2.5263	.3696		.2241	2.8182	
15	2.7206	2.4615	.3696	.2926	.2987	2.6871	
16	.0366	2.3045	.2957		.2987	2.5911	
17		.2172	.3326		.2987	.2926	
18		.2957	.3326	.2926	.2241	.2561	
19	.3658	.2957	.2987	.3658	.2987	.2896	
20	.2926	.2987	.2614	.2926	.2241	.2957	
21	.2926	.2263	.2641	.2926	.2263	.2957	.1829
22	.2926	2.0317	2.2672	2.1052	.2263	.2587	.1829
23	.2561	1.989	2.2283	2.0243	.2241	.2561	.1267
24	.0934	.2561	1.9006	2.0729	1.9433	.2241	.2218
Max	2.8182	3.1161	2.2672	2.1052	1.9524	3.0803	2.8182
Min	.0366	.2172	.2614	.2926	.2218	.2241	.1267
Avg	.6936	1.2360	1.0029	1.0992	.7853	1.1181	.4356

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 203 / 11 KV Wangi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9602	.7499	.112	.0747	.0366	.535	.4816
2	.8962	.7499	.0754	.0366	.0366	.4816	.4816
3	.9069	.7499	.0754	.0366	.0366	.4816	.4816
4	.9175	.7499	.0754	.0366	.0366	.535	.4877
5	.8962	.7316	.0747	.0747	.0366	.5868	.5487
6	.8855	.823	.1494	.0747	.0366	.6173	.6173
7	.9374	.9755	.1494	.0747	.0366	.7316	.7133
8	.0716	.1463	.1478	.0747	.0366	.0724	.0732
9	.0716	.1463	1.1873	1.2803	1.2193	.1478	.0747
10	.0366	.1478	1.4083	1.2803	1.0974	.0739	
11	.0366	.1463	1.3283	1.1385	1.0494	.1463	
12	.0366	.1448	1.2018	1.1248	.9755	.1478	
13		.1463	1.1873	1.1248	.9145	.0732	
14		.1448	1.1248	.9755	.8215	.0724	
15	.0366	.1463	1.0623	.9755	.8322	.0709	
16	.0366	.1433	1.1385	.9755	.7529	.0716	
17	.0366	.1478	.0709	.0366	.0739	.0724	
18	.1463	.1448	.0724	.0366	.0732	.0739	
19	.0732	.1478	.0739	.0358	.0739	.0747	
20	.0366	.1494	.1478	.0366	.0747	.0739	
21	.1463	.1494	.0739	.0366	.1494	.0739	.0934
22	.9488	.1494	.0732	.0366	.5868	.7407	.0924
23	.8002	.112	.0747	.0366	.5418	.6706	1.0456
24	.9602	.7907	.112	.0747	.0366	.535	.6097
Max	.9602	.9755	1.4083	1.2803	1.2193	.7407	1.0456
Min	.0366	.112	.0709	.0358	.0366	.0709	.0732
Avg	.4488	.3597	.4665	.4037	.3986	.2983	.4462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 204 / 11 KV AMARAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.128	.1132	.112	.1646	.1132	.1097
2	.1294	.128	.0943	.1097	.1646	.1132	.0914
3	.128	.128	.0943	.128	.1646	.1132	.0905
4	.1294	.128	.1132	.128	.1646	.1307	.112
5	.1829	.128	.1307	.1494	.1646	.1294	.1307
6	.2054	.1829	.132	.168	.1646	.1663	.1307
7	.2402	.2195	.2218	.2218	.2378	.2218	.2195
8	.1478	.1646	.1433	.1646	.1646	.1417	.181
9	.1402	.1097	.1214	.1387	.128	.12	.1433
10	.1463	.1063	.1029	.1097	.0848	.1006	
11	.1402	.1227	.104	.104	.0937	.1029	
12	.128	.1029	.1052	.1052	.1187	.1017	
13	.128	.1029	.128	.1052	.12	.116	
14	.128	.1029	.1448	.1646	.1052	.1029	
15	.12	.1063	.1578	.1463	.1402	.0857	
16	.1097	.1029	.1372	.1463	.1029	.128	
17	.1463	.1174	.1463	.1463	.0995	.1448	
18	.1463	.1658	.0848	.1463	.1311	.128	
19	.1753	.1928	.2103	.1646	.1734	.168	
20	.2195	.2012	.2378	.2378	.2172	.1646	.2172
21	.1829	.1663	.2033	.2195	.197	.2054	.2218
22	.1829	.168	.168	.2012	.1494	.1848	.2218
23	.1646	.132	.132	.2012	.1494	.1494	.1829
24	.1307	.1463	.1132	.1307	.1829	.1307	.1494
Max	.2402	.2195	.2378	.2378	.2378	.2218	.2218
Min	.1097	.1029	.0848	.104	.0848	.0857	.0905
Avg	.1534	.1397	.1392	.1520	.1493	.1360	.1573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 205 / 11 KV Wangi Gaothan Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.1829	.1494	.1829	.2195	.168	.1646
2	.1829	.1829	.1494	.1646	.2195	.1494	.1463
3	.181	.1829	.132	.1463	.2195	.132	.1494
4	.1829	.1829	.1509	.1478	.2195	.1698	.168
5	.2218	.1829	.1698	.2054	.2743	.1867	.1867
6	.2801	.2561	.2263	.2614	.2743	.2427	.2241
7	.2241	.2743	.2561	.2957	.3109	.2427	.3109
8	.1848	.2378	.1928	.2012	.2012	.1848	.2378
9	.2149	.2012	.1629	.2033	.1886	.1791	.1829
10	.2378	.1772	.1772	.2378	.1823	.1578	
11	.2012	.1734	.1772	.2378	.1886	.1612	
12	.2195	.1509	.1772	.1463	.1629	.1696	
13		.1781	.2402	.1463	.2058	.1875	
14	.1829	.1898	.2195	.2012	.2058	.2058	
15	.2743	.1966	.1867	.2012	.2204	.2012	
16	.2195	.192	.2058	.2195	.2267	.208	
17	.2561	.1417	.2614	.2378	.1696	.1943	
18	.2195	.1753	.1943	.2561	.176	.1791	
19	.2195	.2303	.2149	.2012	.2172	.2507	
20	.2378	.2561	.2561	.2743	.2507	.2561	.2195
21	.2561	.2241	.2427	.2561	.2378	.2378	.1848
22	.2378	.2427	.2241	.2561	.2241	.2534	.1848
23	.2195	.1698	.2241	.2378	.2054	.2195	.1646
24	.1867	.2012	.1867	.2054	.2378	.1848	.1829
Max	.2801	.2743	.2614	.2957	.3109	.2561	.3109
Min	.181	.1417	.132	.1463	.1629	.132	.1463
Avg	.2185	.1993	.1991	.2135	.2183	.1968	.1934

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 206 / 11 KV CHIKHALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0924	.128	1.3592	1.4419	1.5402	.112	.1097
2	.0914	.128	1.278	1.3763	1.5402	.112	.1097
3	.0924	.128	1.278	1.4251	1.5402	.112	.1097
4	.0934	.128	1.2597	1.4419	1.5402	.112	.1109
5	.112	.128	1.2597	1.5074	1.5546	.112	.1097
6	.1132	.1463	1.3763	1.5729	1.5546	.1494	.112
7	.1132	.1463	1.3603	1.6385	1.6385	.1494	.1478
8	.1132	.1372	.0937	.1097	.0732	.1075	.1017
9	2.1628	2.2939	.0949	.1109	.0914	2.2542	2.1879
10	2.1628	2.5484	.1006	.0732	.1075	2.6155	
11	1.9662	2.4143	.104	.0732	.104	2.4143	
12	1.9662	2.0553	.1052	.0886	.1063	2.3205	
13	1.9433	1.9006	.1097	.0914	.1052	2.3205	
14		1.8351	.1097	.0914	.1052	2.2283	
15	1.9433	1.8351	.1086	.0914	.1063	2.1628	
16	.0914	1.749	.1086	.0914	.104	2.0317	
17	.0914	.1017	.1097	.0914	.096	.1235	
18	.0732	.1075	.1052	.0914	.0983	.1463	
19	.0732	.1109	.1463	.0914	.1402	.1075	
20	.1463	.1086	.1097	.0914	.1478	.1463	.1075
21	.1463	.1075	.1086	.0914	.1463	.1448	.0905
22	.1463	1.6095	1.704	1.6385	.112	.1109	.0895
23	.1463	1.4754	1.6766	1.6057	.112	.1109	.0709
24	.0924	.1463	1.3923	1.4586	1.5729	.112	.1109
Max	2.1628	2.5484	1.704	1.6385	1.6385	2.6155	2.1879
Min	.0732	.1017	.0937	.0732	.0732	.1075	.0709
Avg	.6075	.8945	.6441	.6827	.5932	.8465	.2549

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 207 / KADEPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.2829	.3772	.2263	.3772	.2641	.3018
2	.2195	.2641	.3395	.2641	.3772	.2452	.2641
3	.2218	.2452	.3018	.2829	.3772	.2452	.3018
4	.2241	.2452	.3206	.3018	.3772	.2452	.3395
5	.2587	.2452	.2829	.3395	.3961	.2452	.3772
6	.3395	.3772	.5093	.3961	.4527	.3584	.4338
7	.4338	.4904	.3961	.4527	.4715	.415	.5093
8	.2641	.3395	.415	.3018	.3772	.3018	.2641
9	.2263	.3395	.3584	.2641	.3018	.2829	.2452
10	.2829	.3395	.2829	.3395	.3206	.3018	
11	.3206	.3772	.3395	.3772	.3547	.3772	
12	.3772	.2452	.3395	.3772	.3921	.3772	
13	.3395	.3361	.3584	.3772	.3547	.3961	
14	.3395	.3961	.3584	.3961	.3772	.3584	
15	.3206	.3961	.3584	.3961	.3921	.3206	
16	.3206	.3772	.3206	.3961	.3395	.3018	
17	.3395	.3961	.3206	.3772	.3395	.2829	
18	.3772	.3584	.3395	.3584	.3584	.3018	
19	.3395	.4338	.3772	.3961	.415	.3206	
20	.3961	.4338	.3206	.3961	.3018	.3395	
21	.3772	.415	.3395	.3772	.3018	.3584	.3018
22	.415	.4338	.3018	.415	.3174	.3772	.2987
23	.3772	.3772	.2829	.3961	.2829	.3395	.2772
24	.2241	.3395	.3961	.2452	.3772	.2641	.3018
Max	.4338	.4904	.5093	.4527	.4715	.415	.5093
Min	.2195	.2452	.2829	.2263	.2829	.2452	.2452
Avg	.3148	.3535	.3474	.3521	.3639	.3175	.3243

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 201 / Kadegaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7762		.8775	.9335	.8865	.8402	.8962
2	.7392	.7842	.8589	.9335	.8501	.8029	.8871
3	.7468	.6036	.8589	.9335	.8589	.811	.9054
4	.7842	.7468	.8402	.9335	.8865	.811	.9149
5	.8299	.924	.8402	.9709	.8962	.8488	.9619
6	1.1317	1.226	.9335	1.2136	1.0829	1.1317	.9877
7	1.3443	1.4563	1.2136	1.4937	1.2567	1.2936	1.1949
8	1.1706	1.1888	1.1706	1.1765	1.2696	1.0974	1.1462
9	.9877	1.0719	.9593	.9955	.9877	.9412	.9877
10	.9313	1.0242	.9955	.985	1.0029	.985	
11	.905	1.0059	.9955	.9671	.9511	.8954	
12	.9145	.9955	.985	1.1576	.924	.9134	
13	.9412	1.0136	1.0745	1.0029	.9149	.9671	
14	.8779	1.0136	.9955	.9774	.8859	.9955	
15	.8131	1.0136	1.0059	.9328	.8954	.9671	
16	.8871	.9774	.985	.9412	.8954	.9412	
17	.8131	1.0029	1.0745	.788	.8764	.9465	
18	.9145	.0886	.9745	.9816	.7973	.9134	
19	1.086		1.1765	1.1462	1.1765	1.1827	
20	1.2696		1.4632	1.3169	1.2803	1.3535	1.307
21	1.3769		1.386	1.2752	1.2012	1.3306	
22	1.3203		1.2936	1.1576	1.2012	1.1827	
23	1.1203		1.1576	1.0082	1.0269	1.0642	
24	.8501	1.0242	.8775	1.0269	.9149	.8962	.9328
Max	1.3769	1.4563	1.4632	1.4937	1.2803	1.3535	1.307
Min	.7392	.0886	.8402	.788	.7973	.8029	.8871
Avg	.9805	.9534	1.0414	1.0520	.9966	1.0047	1.0111

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 202 / MIDC No.1

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1622	2.1437	2.2032	2.0328	2.1502	2.2405	2.2445
2	2.1437	2.0165	2.2032	2.0119	2.1845	2.1437	2.1845
3	2.1658	1.922	2.1582	2.0119	2.1622	2.0119	2.1845
4	1.922	1.9239	2.1216	2.0119	2.1253	1.9185	2.2257
5	1.8656	2.0748	2.1216	2.0119	2.0883	1.9185	2.0328
6	1.8625	1.9753	2.0814	1.9753	2.1068	1.8823	2.0144
7	1.9022	1.922	2.0814	1.9959	2.0698	1.8461	2.0513
8	1.9185	1.7909	1.9387	1.8823	2.0119	1.8823	1.7193
9	1.9387	1.9387	2.0698	2.0328	2.2032	2.0119	.9202
10	1.9404	2.1285	2.1068	2.1658	2.0883	2.0328	
11	1.922		2.3152	2.2822	2.0328	2.1437	
12	1.9418		2.1285	2.3765	2.0165	2.1845	
13	1.8861		1.7528	2.1285	2.037	1.9204	
14	1.9791	2.2257	2.0911	2.1622	1.9022	2.0725	
15	2.0538	2.2257	2.2405	2.2822	1.9959	2.1098	
16	2.0698	2.2445	2.2405	2.2822	2.0698	2.1285	
17	2.0538	2.1285	2.2405	2.2405	2.0698	2.1472	
18	1.9959	2.1472	2.0328	2.2634	2.0911	2.0911	
19	2.1658		2.2634	2.2822	2.0911	2.0698	
20	2.1285		2.1658	2.1098	2.1658	2.1845	
21	2.2177		2.1658	2.2257	2.1658	2.2218	
22	2.1437		1.8983	2.1658	2.0119	2.1807	
23	2.0485		1.9185	2.0698	1.701	2.0144	
24	2.0328	2.0538	2.2445	2.0911	2.2257	2.0538	2.2032
Max	2.2177	2.2445	2.3152	2.3765	2.2257	2.2405	2.2445
Min	1.8625	1.7909	1.7528	1.8823	1.701	1.8461	.9202
Avg	2.0192	2.0539	2.1160	2.1289	2.0736	2.0588	1.9780

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 203 / Shalgaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.6085	3.5574	.0914	.2374	.2321	3.0243	3.6389
2	3.5355	3.4328	.0914	.2389	.2301	2.907	3.4914
3	3.3391	3.2754	.0914	.2256	.2108	2.8068	3.3288
4	3.28	3.2167	.0914	.2374	.2133	2.7778	3.2129
5	3.2434	1.9471	.112	.2435	.2405	2.8083	3.2373
6	3.5761	3.7041	.132	.289	.2776	3.1333	3.484
7	4.1623	4.2013	.132	.3231	.3171	3.0636	3.8679
8	.2859	.2728	.124	.5575	.8069	.2985	.3042
9	.2029	.2296	2.4249	5.5655	5.8611	.2542	.2424
10	.221	.1746	2.5857	5.5451	5.7171	.2488	.1417
11	.2031	.1928	2.5692	5.7739	5.4397	.2514	.0838
12	.1676	.1974	2.5692	5.3477	5.3117	.2492	.0671
13	.1715	.2035	2.4863	5.4897	5.1387	.213	.1174
14	.0244	.1791	2.2377	5.3182	4.935	.2171	.1425
15	.1958	.189	2.0481	5.0568	4.7163	.2256	.1379
16	.1049	.2438	1.9433	4.7531	4.7104	.2446	.1456
17	.2134	.2104	.1029	.2576	.2348	.2542	.1501
18	.2351	.2595	.061	.2599	.2271	.2889	.3246
19	.2791	.2515	.1417	.2927	.2496	.271	.141
20	.3208	.2629	.128	.314	.3125	.3177	.16
21	.5948	.2636	.1307	.2788	.5108	.5318	.4291
22	4.0036	.2306	.112	.2542	3.6631	3.9999	2.3312
23	4.0619	.2292	.112	.2412	3.5635	4.1055	2.4364
24	3.7965	1.883	.0914	.2389	1.912	3.5799	4.0947
Max	4.1623	4.2013	2.5857	5.7739	5.8611	4.1055	4.0947
Min	.0244	.1746	.061	.2256	.2108	.213	.0671
Avg	1.6595	1.2003	.8587	1.9725	2.2930	1.5030	1.4880

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 204 / Kadegaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1294	.1097	2.4034	2.3205	.9488	.1478	.1294
2	.1294	.0905	2.3868	2.1879	.8539	.1463	.128
3	.132	.0732	2.3868	2.0972	.8124	.1463	.128
4	.1294	.0924	2.3205	2.0317	.8223	.1478	.1267
5	.168	.1307	2.0481	2.0317	.8223	.1848	.1448
6	.2033	.1494	.1372	2.2542	.9922	.1886	.2012
7	.2012	.1698	1.9334	2.3205	1.0402	.1791	.2402
8	.1663	.1494	.1578	.181	.197	.2149	.1663
9	2.7496	2.2634	.1478	.181	.1829	3.2861	2.9835
10	2.8178	2.9874	.1663	.1829	.128	3.1855	
11	1.6385	2.7778	.12	.1478	.1109	2.7349	
12	1.5912	3.0521	.12	.1052	.0934	2.9504	
13	1.6057	3.1017	.1772	.1075	.0943	2.7681	
14		3.219	.181	.128	.1848	1.6324	
15	1.6575	2.8502	.1463	.1029	.1848	1.4864	
16	1.5565	2.9005	.1791	.1075	.1829	1.3916	
17	.0716	.1772	.0972	.1372	.2195	.1772	
18	.1097	.1578	.1372	.1928	.2172	.197	
19	.1448		.1772	.2012	.2614	.2378	
20	.1646		.1829	.2012	.2614	.2195	
21	.1478		.1791	.1848	.1867	.2054	
22	.128		2.5857	2.3868	.1494	.1663	
23	.1307		2.5857	2.42	.1448	.1494	
24	.1478	.1086	2.4034	2.3205	1.0242	.1478	.1494
Max	2.8178	3.219	2.5857	2.42	1.0402	3.2861	2.9835
Min	.0716	.0732	.0972	.1029	.0934	.1463	.1267
Avg	.6922	1.2927	.9733	1.0222	.4215	.9288	.4398

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082] BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 205 / MIDC No.2

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17
HR	Load (MW)	Load (MW)
1	2.0336	2.1189
2	1.9974	2.127
3	1.9737	2.0508
4	1.9433	1.9715
5	1.9212	1.7696
6	1.9738	1.8542
7	2.0698	2.015
8	2.0108	1.9761
9	1.0982	2.1826
10		2.6932
11	2.0793	1.0883
12	2.8479	
13	2.6562	
14	2.3723	
15	2.4337	
16	2.5477	
17	2.5621	
18	2.6715	
19	2.5282	
20	2.359	
21	2.2116	
22	2.079	
23	2.0112	
24	2.0931	.961
Max	2.8479	2.6932
Min	1.0982	.961
Avg	2.1945	1.9007

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 206 / SHALGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3584	.2172	.2987	.3326	.3142	.3696	.3018
2	.3174	.1829	.2801	.3326	.2957	.3326	.3174
3	.3174	.2218	.2801	.3361	.2987	.3361	.3174
4	.3584	.2614	.2743	.3361	.3142	.3361	.3395
5	.3921	.3326	.2926	.3734	.3361	.3734	.3547
6	.4668	.4481	.4024	.5228	.462	.5228	.4715
7	.4854	.4527	.567	.4656	.4755	.4572	.5175
8	.4755	.4481	.3475	.4656	.4656	.4344	.5014
9	.3439	.394	.3155	.3814	.4298	.4207	.4572
10	.3601	.3155	.2915	.3506	.3681	.3467	
11	.3582		.3429	.3761	.3224	.2835	
12	.3856		.3429	.3582	.2926	.3395	
13		.3086	.3121	.3292	.3696		
14		.3561	.3506	.3045	.3856		
15	.3658	.3391	.3189	.2804	.2561	.3045	
16	.3881	.3544	.2835	.3224	.2835	.3224	
17	.3772	.39		.2915	.3353	.3185	
18	.4108	.407	.4115	.3772	.3772	.3521	
19	.4527		.5316	.5194	.4961	.5194	
20	.4805		.6219	.567	.5973	.567	
21	.4481		.5544	.5415	.5544	.5415	
22	.3696		.4805	.5175	.4805	.4715	
23	.3258		.4108	.3921	.4066	.3921	
24	.3326	.2561	.2987	.3734	.3292	.3696	.3174
Max	.4854	.4527	.6219	.567	.5973	.567	.5175
Min	.3174	.1829	.2743	.2804	.2561	.2835	.3018
Avg	.3896	.3344	.3743	.3936	.3853	.3960	.3896

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 207 / 11 KV KHAMBALE-A AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.3481	4.1762	.0934	.0377	.2362	3.7761	4.3993
2	4.0638	3.9826	.0934	.0377	.2347	3.6077	4.2814
3	3.8796	3.629	.0934	.0377	.2336	3.375	4.2448
4	3.6942	3.4606	.0934	.0377	.2162	3.2236	4.2267
5	3.5663	3.3204	.0943	.0377	.2336	3.1931	3.9354
6	3.6843	3.4573	.1132	.1533	.301	3.5174	4.1888
7	4.2197	3.8929	.132	.1623	.3224	3.677	4.6867
8	.2658	.2561	.1097	.3292	.9084	.2976	.2854
9	.1996	.2286	2.9504	2.2061	6.1248	.2385	.2466
10	.205	.2159	2.9007	2.5538	6.0456	.2024	.1311
11	.2268	.1894	2.7349	5.8608	6.0669	.2103	.1219
12	.246	.1921	.1951	6.438	5.6958	.2389	.1143
13	.2529	1.8084	2.4863	6.6422	5.2812	.2724	.1143
14	.0206	.1676	2.8509	6.377	5.5733	.2724	.1189
15	.2377	.1874	2.7664	5.9564	5.2039	.2408	.1158
16	.1742	.2034	2.6216	5.6847	4.5791	.2435	.1151
17	.2522	.2271	.0671	.2172	.2321	.2293	.1113
18	.26	.1962	.0678	.1539	.2301	.2324	.1181
19	.2648	.2061	.0905	.294	.2686	.2704	.125
20	.2932	.2591		.3909	.3209	.3209	.1433
21	.6832	.274	.0566	.3867	.6478	.6429	.5777
22	4.5046	.2477	.0566	.3479	4.3132	5.0827	2.4478
23	4.7386	.2169	.0377	.3208	1.5508	4.9652	2.8075
24	4.4443	2.1811	.0934	.1848	2.1693	4.2196	4.7893
Max	4.7386	4.1762	2.9504	6.6422	6.1248	5.0827	4.7893
Min	.0206	.1676	.0377	.0377	.2162	.2024	.1113
Avg	1.8636	1.3823	.9043	1.8687	2.3746	1.7729	1.7686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / BELAWADE S/STN

Feeder No / Name : 201 / 11 KV Tondoli

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2195	2.713	2.6543	2.7199	.3361	.181
2	.2218	.2033	2.6825	2.556	2.6379	.3361	.1848
3		.2195	2.5606	2.556	2.556	.3361	.1886
4		.2218	2.6216	2.5069	2.4741	.3361	.1886
5		.2218	2.5911	2.5069	2.4741	.3547	.2195
6		.2772	2.652	2.7349	2.6871	.462	.2507
7		.3511	2.6825	2.8509	2.9165	.499	
8	.2534		.3018	.3361	.3292	.3142	.2865
9	3.9567	3.3813	.2561	.3547	.2561		
10	3.2769	3.7388	.2987	.2926	.2772	3.4252	3.4572
11	3.408	3.5608	.3174	.2743	.3142	3.2007	3.1786
12		2.8166	.2614	.2772	.2641	3.1878	
13	3.195	2.8959	.2987	.3142	.3696	2.9172	
14		3.1184	.2987		2.9384	2.9504	
15	3.0967	2.9835	.3142	.3511	.3511	2.6825	
16		2.6825	.2957	.3326	.4251	2.2862	
17	.3109	.3018	.3142	.3881		.1509	
18	.3292	.2987	.3547	.4251	.4435		
19	.3658	.3772	.4481	.4251	.4805		
20	.4024	.362	.4108	.3881	.462		
21	.3841	.3361	.3361	.3326	.4108	.4435	
22	.3109	2.9127	3.0346	3.0333	.3734	.3326	
23	.2772	2.9001	2.8837	2.9835	.3361	.2926	
24	.2195	.2587	2.6852	2.8178	2.8182	.3547	.2218
Max	3.9567	3.7388	3.0346	3.0333	2.9384	3.4252	3.4572
Min	.2195	.2033	.2561	.2743	.2561	.1509	.181
Avg	1.2647	1.5061	1.3172	1.3779	1.2746	1.2599	.8357

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / BELAWADE S/STN

Feeder No / Name : 202 / 11 KV Raigaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9504	2.6216	.1698	.1307	.0732	2.6355	2.8807
2	2.8178	2.556	.0724	.112	.0554	2.4863	2.9492
3		2.4905	.0732	.112	.0732	2.4531	3.0178
4		2.3922	.0934	.112	.0924	2.4034	2.6558
5		2.4577	.1075	.112	.0924	2.4034	2.6452
6		2.5396	.1294	.1307	.0732	2.5692	2.3868
7		2.5888	.1509	.1494	.0914	2.536	
8	.1886		.1478	.1494	.1097	.1494	.1132
9	.1886	.1097	3.315	2.9675	2.6707	.1848	
10	.1294	.1132	2.9172	3.0967	3.1161	.1132	.1448
11	.1109	.1109	3.1855	3.3425	3.1659	.0924	.128
12		.132	2.8344	2.8182	3.0333	.0943	
13	.1109	.1075	2.8178	3.1459	3.0498	.0914	
14		.0943	2.8509	3.2114	2.6852	.0943	
15	.1109	.0924	2.7846	3.0476	2.8344	.0924	
16		.1075	2.7515	2.6871	2.6686	.0943	
17	.0914		.0934	.0914		.0924	
18	.1097		.112	.128	.168		
19	.128	.1612	.1307	.128	.1663		
20	.1463	.1886	.168	.1463	.1478		
21	.128	.168	.168	.128	.1478	.0924	
22	2.9329	.1509	.168	.1097	3.2819	3.12	
23	2.9492	.1086	.1494	.1097	3.2322	3.2769	
24	2.9172	2.7199	.112	.1307	.0914	2.9007	3.12
Max	2.9504	2.7199	3.315	3.3425	3.2819	3.2769	3.12
Min	.0914	.0924	.0724	.0914	.0554	.0914	.1132
Avg	1.0006	1.0481	1.0626	1.0957	1.3531	1.3322	2.0042

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / BELAWADE S/STN

Feeder No / Name : 203 / SOHOLI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5175	.5014	.5788	.5304	.5788	.4527
2	.4755	.462	.5281	.5601	.5175	.5788	.439
3		.439	.5068	.5601	.5304	.5601	.4435
4		.4805	.543	.5788	.5175	.5788	.4805
5		.5487	.6653	.5975	.5544	.5975	.5487
6		.7316	.7468	.7947	.7316	.7468	.6154
7		.7762	.8299	.8316	.823	.7842	
8	.5544		.5788	.5544	.6401	.6348	.6089
9	.4904	.5544	.5014	.6219	.4805	.5975	
10	.4805	.6036	.4477	.5487	.5601	.4656	.5544
11	.4435	.5373	.5068	.5068	.5792	.5175	.6468
12		.5175	.5121	.5373	.6036	.5658	
13		.4904	.4755	.5611	.5853	.5487	
14		.4755	.4572	.5487	.6219	.6036	
15	.5544	.4904	.5853	.6584	.5853	.5121	
16	.5544	.5373	.5729	.6036	.6154	.5601	
17	.6838	.6413	.5304	.6099	.5853	.6089	
18	.6767	.5373	.6219	.6283	.5853		
19	.7682	.7164	.8316	.7316	.8048		
20	.9145	.8048	.8596	.8131	.8131		
21	.6219	.7922	.8686	.7762	.7207	.8299	
22	.6653	.7392	.7468	.6653	.6653	.7164	
23	.5914	.6535	.6161	.5729	.4805	.6283	
24	.5658	.5487	.5487	.5788	.5544	.5914	.5014
Max	.9145	.8048	.8686	.8316	.823	.8299	.6468
Min	.4435	.439	.4477	.5068	.4805	.4656	.439
Avg	.6027	.5911	.6076	.6258	.6119	.6098	.5291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / BELAWADE S/STN

Feeder No / Name : 204 / 11 KV UPALE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2496	.3064	2.2405	4.683	5.1646	.2286	.2531
2	.2443	.2877	2.2611	4.5374	4.8522	.2283	.2545
3	.1334	.2831	2.3137	4.494	4.6567	.2283	.2595
4	.128	.301	2.2348	4.5363	4.5267	.2252	.2489
5	.1364	.3087	2.3739	4.6041	4.6247	.2321	.3064
6	.1875	.3802	2.4078	4.936	4.8209	.1471	.3829
7	.2362	.5121	2.3205	5.3261	5.1631	.4778	.2591
8	.9267	.8711	.1509	.3959	.3563	1.0145	.4487
9	5.8964	2.8601	.1848	.3483	.3411	5.4816	2.649
10	3.0918	5.9153	.1052	.3163	.3437	6.4472	5.2573
11	3.2232	5.9347	.1886	.274	.3216	6.6427	5.4519
12	3.0643	5.675	.181	.3205	.2949	6.5017	1.9685
13	4.9215	5.2393	.128	.2911	.2991	6.124	
14	.0465	5.0377	.1478	.2957	.2705	6.1035	
15	5.0537	5.3125	.1663	.3274	.3086	5.9	
16	.0488	5.5526	.1663	.3178	.3132	5.6905	1.8458
17	.3757	.3875	.1646	.3764	.3224	.3064	.2301
18	.3779	.3875	.1254	.3449	.3597	.1882	.2279
19	.4054	.431	.1307	.3806	.4194	.1989	.2195
20	.4466	.4664	.1867	.4382	.4407	.2309	.2561
21	.4572	1.0555	.1867	.8474	.4415	.4275	.2332
22	.4195	5.4992	2.8193	5.5769	.3794	.3789	.2073
23	.3639	5.5072	2.3266	5.6302	.2804	.3346	.1578
24	.2934	2.9718	2.3102	5.1048	2.5628	.2797	.2736
Max	5.8964	5.9347	2.8193	5.6302	5.1646	6.6427	5.4519
Min	.0465	.2831	.1052	.274	.2705	.1471	.1578
Avg	1.2803	2.5618	1.0759	2.2793	1.7443	2.2508	1.0186

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / BELAWADE S/STN

Feeder No / Name : 205 / 11 KV BOMBALEWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7804	1.8023		.1109	.0655		2.2043
2	1.7204	1.7368	.1132	.0934	.0655		2.1795
3		1.6549	.1132	.0934	.0655		2.13
4		1.5893	.1478	.0934	.0819		2.0972
5		1.5565	.1448	.0934	.0983		2.1704
6		1.704	.1753	.1307	.1147		2.0222
7		1.7695	.1886	.1595	.1638	.0312	
8	.1254		.1433	.1254	.1311		.1254
9	.132	.0819	2.4531	2.6658	2.5724		
10		.0943	2.5029	2.8018	2.5029		.0983
11		.0895	2.7664	2.6707	2.4478		
12		.1132	2.649	2.556	2.3371		
13	.0983	.1075	2.5484	2.4086	2.2874		
14		.0905	2.5149	2.2283	2.1051	.1294	
15	.0983	.0895	2.4697	2.3102	2.1051	.1254	
16		.1509	2.2874	2.13	1.8623	.132	
17	.1147	.1478	.1029	.0983		.1294	
18	.0983	.1494	.1063	.1311	.1463		
19	.1147	.1612	.1463	.1311	.1294		
20	.1311	.1698	.1478	.1475	.1663		
21	.1311	.1612	.1478	.1311	.1663	.1509	
22	2.0972	.1494	.1132	.1311	1.8399	2.5434	
23	2.0317	.132	.112	.0983	.0554	2.2405	
24	1.7604	1.8351	.1294	.1097	.0819		2.2211
Max	2.0972	1.8351	2.7664	2.8018	2.5724	2.5434	2.2211
Min	.0983	.0819	.1029	.0934	.0554	.0312	.0983
Avg	.7453	.6755	.9662	.9021	.9388	.6853	1.6943

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / BELAWADE S/STN

Feeder No / Name : 206 / 11 KV LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.5914	.4024	.6413	.5175	.679	.7316
2		.5914	.415	.679	.5544	.7356	.724
3		.6099	.415	.679	.5914	.7356	.7468
4		.6468	.4854	.679	.6653	.7356	.7522
5		.6468	.543	.679	.6653	.9242	.8676
6		.6653	.6283	.4338	.6838	.4715	.8779
7		.7207	.7545	.8676	.9979	.7167	
8	.9431		.9431	.7356	.499	.7167	
9	.4755	.7947	.8048	.7733	.7392	.9619	
10		.7922	.8048	.7392	.9795	.7733	.7762
11	.7762	.7682	.8029	.6653	.7282	.7468	.7392
12		.7167	.7468	.7023	.7095	.7545	
13	.7207	.6805	.3921	.7207	.6908	.9054	
14	.7207	.7167	.7095	.7207	.7468	.9313	
15	.7577	.7023	.7842	.7207	.7282	.7545	
16	.2587	.2641	.012	.2772	.0122	.1848	
Max	.9431	.7947	.9431	.8676	.9979	.9619	.8779
Min	.2587	.2641	.012	.2772	.0122	.1848	.724
Avg	.6335	.6605	.6027	.6696	.6568	.7330	.7769

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 201 / 11 KV WANGI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1267	.128	1.9006	1.9433	1.8023	.181	.128
2	.1097	.128	1.9006	1.9433	1.8399	.1646	.1296
3	.1097	.128	1.8679	1.8842	1.757	.1829	.1457
4	.1267	.1097	1.8679	1.8785	1.6575	.1448	.1457
5	.1463	.1463	1.8138	1.8351	1.7368	.1829	.1387
6	.1829	.2195	1.8244	1.8623	1.8187	.2378	.2126
7	.2378	.2149	1.8785	1.9334	1.9433	.2402	.2126
8	.2378	.1791	.2012	.1492	.2012	.2172	2.5396
9	2.6139	2.5069	.1772	.1475	.1646	2.4531	2.5396
10	2.2119	2.304	.1402	.1543	.1433	2.2939	2.5857
11	2.2211	2.2874	.1372	.1402	.1433	2.343	2.42
12	2.2939		.1492	.1372	.1646	2.3102	
13	2.13	2.3594	.1296	.1387	.1867	2.343	
14		2.1956	.1357	.1402	.1646	2.0809	
15	2.1051	2.1382	.1372	.1402	.1646	2.1792	
16	2.0222	1.9662	.1235	.1753	1.5927	2.13	
17	.1475	.1311	.1492		.2195	.1113	
18	.1526	.156	.1147	.1791	.2012	.1311	
19	.1715	.1886	.1907	.1886	.2012	.156	
20	.1886	.2058	.2058	.1791	.1867	.1387	
21	.1734	.1865	.1734	.1612	.1829	.156	
22	.156	2.0388	1.8138	2.0885	.1463	.144	
23	.1433	1.989	2.0481	2.0809	.1463	.144	
24	.1267	.1433	1.9559	2.0243	1.9662	.1629	.128
Max	2.6139	2.5069	2.0481	2.0885	1.9662	2.4531	2.5857
Min	.1097	.1097	.1147	.1372	.1433	.1113	.128
Avg	.7885	.9587	.8765	.9350	.7805	.8679	.9438

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 202 / 11 KV TADSAR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3441	2.3777	.1269	.4382	.4115	2.1839	2.5553
2	2.1864	2.1445	.1269	.4515	.4268	2.0531	2.2634
3	2.1342	2.0477	.1143	.4664	.4192	1.9806	2.2173
4	2.0995	2.056	.1286	.4801	.3887	1.9757	2.1601
5	2.0881	2.103	.1572	.5033	.431	2.0133	2.2371
6	2.2054	2.3152	.2115	.5472	.4946	2.3064	2.4059
7	2.8906	2.8178	.2715	.541	.623	2.3628	3.0262
8	.8086	.8521	.2286	.5247	.6234	.6965	.8817
9	.5137	.5156	1.5638	3.4203	2.7328	.5517	.683
10	.4526	.5053	1.4769	3.3128	.9892	.6117	.6095
11	.4426	.5578	1.4769	3.328	.0312	.5904	.6087
12	.4533	.5777	1.4861	3.1321	3.3927	.582	.615
13	.4382	.5199	1.4003	2.9417	3.5003	.2957	.6287
14	.1844	.4902	1.286	2.8456	3.088		.3559
15	.4862	.5161	1.3146	2.8388	3.2632		.3475
16	.3117	.4896	1.2574	2.7485	3.0422	.3805	.3513
17	.5784	.5077	.2	.346	.7232	.653	.3513
18	.5632	.5405	.0486	1.4289	.7209	.4161	.3064
19	.6279	.5305	.2317	.6882	.7735	.7198	.3521
20	.6645	.5739	.2027	.7445	.7484	.7173	.3871
21	.6227	.53	.2027	.8505	.6851	.6927	.3536
22	2.7622	.4728		.7869	2.3479	2.6231	1.8061
23	2.793	.4338	.1932	.5007	2.4196	2.7588	1.8435
24	2.6216	1.3756	.1429	.4222	1.4525	2.8612	2.5294
Max	2.8906	2.8178	1.5638	3.4203	3.5003	2.8612	3.0262
Min	.1844	.4338	.0486	.346	.0312	.2957	.3064
Avg	1.3030	1.0771	.6021	1.4287	1.4054	1.3648	1.2448

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 203 / 11 KV YERALA AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7907	.7842	.0924	.1097	.1307	.7449	.8025
2	.759	.7042	.0732	.1097	.1097	.7287	.8025
3	.7343	.7042	.0747	.1267	.1463	.7125	.8025
4	.7773	.6722	.0934	.1294	.128	.7202	.7968
5	.7522	.7537	.112	.1294	.1494	.7042	.7773
6	.7432	.8356	.1509	.1646	.168	.7611	.8322
7	.8642	.9175	.1698	.1829	.168	.8421	.8802
8	.1457	.1052	.1187	.1307	.1463	.1463	.144
9	.1147	.1075	1.1069	.1086	.9012	.1494	.128
10	.1326	.128	1.0753	1.1203	.9282	.1254	.1433
11	.1433	.0924	1.0753	1.1385	.9503	.1254	.1433
12	.1254	.128	1.078	1.0911	.9503	.1254	.1433
13	.128	.1227	1.1265	1.1203	1.0486	.1267	.1254
14		.1254	1.1248	1.0911	.9717	.128	
15		.1075	1.0911	1.0753	.9339	.1086	
16	.128	.1052	1.0494	1.0562	.9555	.1267	
17	.1646	.1029	.1052	.1147	.1267	.128	
18	.1463	.1214	.1254	.12	.1097	.1448	
19	.197	.1463	.1646	.1543	.1463	.1867	
20	.1791	.1494	.1663	.1715	.1463	.168	
21	.1075	.1294	.168	.1612	.128	.168	
22	.8802	.1132	.1086	.1463	.8192		
23	.9339	.0934	.1097	.128	.7935	.8025	
24	.8322	.8642	.0924	.1086	.128	.7537	.8025
Max	.9339	.9175	1.1265	1.1385	1.0486	.8421	.8802
Min	.1075	.0924	.0732	.1086	.1097	.1086	.1254
Avg	.4445	.3381	.4439	.4162	.4660	.3794	.5231

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 204 / 11 KV AMBAK AG FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0895	.08	.8002	.8029	.7202	.0724	.08
2	.0732	.0655	.759	.7449	.7202	.0732	.08
3	.0732	.0655	.759	.7449	.6401	.0914	.08
4	.0886	.08	.7274	.7611	.6241	.0905	.08
5	.0895	.08	.7274	.7125	.6081	.0732	.08
6	.0876	.08	.7432	.7537	.6882	.0914	.08
7	.1075	.0819	.8962	.8684	.8029	.1267	.08
8	.1075	.0972	.0914	.1134	.0819	.1307	.096
9	1.065	1.2289	.0739	.112	.1147	1.1069	.9442
10	.9995	1.1797	.0747	.096	.112	1.1043	1.094
11	.8802	1.4091	.0732	.096	.0983	.144	1.0402
12		1.1984	.08	.096	.081	1.0402	
13	.9442	1.166	.096	.112	.0655	.9922	
14		1.1174	.096	.112		.9762	
15	1.0978	1.1498	.1174	.096	1.3717	.8802	
16	1.0978	.9282	.096	.112	.1086	.8802	
17		.112	.112	.1147	.1097	.144	
18	.0983	.1109	.112	.1147	.128	.096	
19	.08	.0732	.1134	.1147	.128	.096	
20	.08	.0747	.0983	.1147	.128	.096	
21	.081	.0739	.0983	.096	.128	.096	
22	.0819	.8002	.0972	.8848	.1097	.08	
23	.08	.8642	.1134	.852	.0732	.08	
24	.0886	.096	.8322	.852	.8002	.0732	.08
Max	1.0978	1.4091	.8962	.8848	1.3717	1.1069	1.094
Min	.0732	.0655	.0732	.096	.0655	.0724	.08
Avg	.3519	.5089	.3245	.3949	.3671	.3598	.3179

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 205 / 11 KV HINGANGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / INCOMING DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3333	2.4715	.1463	.4258	.3985	1.9033	2.3602
2	2.2556	2.428	.128	.4077	.3658	1.89	2.303
3	2.2376	2.364	.1294	.4348	.3666	1.8835	2.2535
4	2.2058	2.3747	.1494	.4422	.4119	1.8763	2.0934
5	2.197	2.3806	.1848	.4923	.4607	1.9567	2.2771
6	2.3784	2.6193	.2743	.6012	.5495	2.1302	2.3579
7	2.7016	2.833	.2218	.6195	.5674	2.3117	2.5042
8	.4437	.4671	.168	.5136	.4618	.3483	.3886
9	.3679	.3818	1.6164	3.3791	3.3219	.354	.3223
10	.3071	.376	1.6004	3.6054	3.171	.3124	.3246
11	.3124	.3963	1.6164	3.5841	3.4195	.1852	.3284
12	.381	.4329	1.6164	3.2708	3.4362	.3292	.3558
13	.3612	.5089	1.3443	3.1196		.3353	.1791
14	.0846	.5076	1.4243	1.5417	2.8155	.3139	.1799
15	.3867	.4965	1.4746	.0038	2.937	.2819	.1882
16	.2602	.4748	1.2003	2.7199	2.7843	.304	.2073
17	.4035	.5056	.208	.0213	.4368	.3444	.221
18	.4374	.4794	.2401	.5095	.4321	.2979	.2187
19	.4618	.4955	.2401	.6203	.4504	.2819	.202
20	.5343	.5239	.3045	.6044	.4717	.397	.2309
21	.5259	.511	.3045	.5815	.5556	.3825	.2362
22	2.8506	.4672	.2743	.5213	2.1636	2.5515	1.4007
23	2.9001	.4081	.2172	.4549	2.0942	2.6048	1.4396
24	2.5863	1.4236	.1494	.4359	1.2605	2.2487	1.4708
Max	2.9001	2.833	1.6164	3.6054	3.4362	2.6048	2.5042
Min	.0846	.376	.128	.0038	.3658	.1852	.1791
Avg	1.2464	1.0970	.6347	1.2046	1.4492	1.0760	1.0018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 206 / 11 KV WANGI GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6348	.6058	.2957	.6287	.6393	.6195	.622
2	.6138	.57	.2614	.6398	.6325	.6096	.6144
3	.6092	.6111	.2561	.6554	.5403	.5894	.6213
4	.6241	.5464	.2987	.6504	.5224	.6081	.6236
5	.7111	.7011	.3326	.7133	.5734	.6817	.6258
6	.9156	.9728	.567	1.0067	.9678	.9389	.8434
7	1.0814	1.0967	.5415	1.1188	1.0871	1.0535	.9842
8	1.0075	.9511	.4207	1.0803	.9423	.9435	.9533
9	.7838	.7712	.3326	.7099	.708	.7018	.7774
10	.7164	.6756	.3041	.689	.6256	.6679	.6426
11	.5175	.6264	.3224	.6233	.5704	.6872	.5445
12	.3471	.317	.3224	.6516	.578	.5405	.538
13	.1334	.6409	.362	.6977	.6261	.6281	.5422
14	.301	.6495	.3403	.6821	.6429	.615	.2721
15	.4473	.618	.3366	.623	.649	.5722	.2804
16	.6608	.6112	.3045	.6175	.6413	.5821	.2843
17	.7191	.7161	.3224	.7171	.6612	.6226	.3048
18	.7834	.7766	.394	.727	.7335	.6297	.3582
19	.9392	1.0174	.5373	.8939	.8745	.7968	.4199
20	1.0761	1.1256	.5552	1.1012	.9922	.9865	.4931
21	.9869	1.0967	.5373	1.0052	.9575	.9835	.4862
22	.945	.9473	1.0029	.94	.828	.9739	.4481
23	.7674	.8246	.3403	.82	.7381	.7386	.423
24	.6672	.7331	.3292	.6711	.6722	.6487	.6464
Max	1.0814	1.1256	1.0029	1.1188	1.0871	1.0535	.9842
Min	.1334	.317	.2561	.6175	.5224	.5405	.2721
Avg	.7079	.7584	.4007	.7776	.7252	.7258	.5562

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 201 / 11KV BHIKWADI-KH GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3584	.4435	.415	.4108	.3734	.415	.3881
2	.3395	.4108	.3772	.3734	.3326	.3772	.3881
3	.3206	.3734	.3772	.3734	.3658	.3772	.3881
4	.3206	.4066	.415	.3734	.4108	.3772	.3881
5	.3584	.5228	.4527	.4668	.4904	.415	.3881
6	.5093	.5601	.6036	.5601	.5975	.5093	.3881
7	.6224	.6722	.5658	.5993	.6283	.6224	.0554
8	.5729	.5729	.5228	.4668	.5611	.5304	.4805
9	.462	.5415	.5014	.5611	.5175	.5788	.3881
10	.6335	.5175	.394	.5415	.4835	.5316	.4251
11	.6099	.4163	.3982	.6653	.4706	.567	.5194
12		.4477	.5973	.6161	.4938	.4755	.6036
13		.3582	.5068	.4668	.3982	.4805	
14	.499	.4119	.5249	.4481	.4572	.499	
15	.2218	.5552	.5121	.5359	.4435	.5185	
16	.5544	.5014	.5121	.5041	.4854	.4805	
17	.5175	.6268	.4572	.7282	.4344	.499	
18	.5041	.4835	.499	.5729	.5552	.6468	
19	.6722	.5731	.5729	.7282	.6154	.6468	
20	.7133	.7095	.6535	.7655	.7356	.6653	
21	.695	.5658	.5788	.679	.7356	.5729	
22	.5792		.5228	.5359	.6348	.5544	.5847
23	.4755	.4904	.4481	.4854	.5041	.462	.4527
24	.3772	.4525	.4338	.4108	.4294	.4527	.3881
Max	.7133	.7095	.6535	.7655	.7356	.6653	.6036
Min	.2218	.3582	.3772	.3734	.3326	.3772	.0554
Avg	.4962	.5049	.4934	.5362	.5064	.5106	.4151

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 202 / 11 KV NEWARI AG FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168	.1433	1.326	2.1795	1.6108	.168	.1629
2	.132	.1448	1.3077	1.9281	1.5432	.132	.1629
3	.132	.1448	1.2742	1.9281	1.5424	.132	.1629
4	.132	.1629	1.3032	1.8442	1.5384	.132	.1629
5	.1698	.1629	1.4083	1.6766	1.4752	.132	.1629
6	.1698	.1646	1.5592	1.6766	1.6118	.168	.1629
7	.168	.1612	1.5089	1.7269	1.5089	.168	.1663
8	.1646	.1629	.1646	.1595	.1629	.1646	.1753
9	2.3594	2.6749	.1646	.1595	.1791	2.6852	2.8349
10	2.2708	2.4926	.1646	.1595	.1663	2.7183	2.713
11	2.323	2.6322	.1629	.1254	.168	2.5692	2.42
12		2.2775	.1629	.1629	.1848	2.4863	
13	2.1534	2.2611	.1629	.1629	.1848	2.4863	
14		2.13	.1629	.1612	.1663	2.4863	
15	2.2291	1.9989	.1644	.1629	.1294	2.3205	
16	1.869	1.8679	.1629	.1433	.1294	2.2708	
17	.1715	.1612	.1075	.1629	.1663	.1086	
18	.1715	.156	.1629	.1629	.1629	.1448	
19	.1629	.1543	.1478	.1646	.1629	.1629	
20	.1829	.1307	.1578	.1629	.1698	.181	
21	.1829	1.5746	.181	.1829	.1886	.181	.1848
22	.1629		2.2805	2.0957	.1867	.1629	.1791
23	.1663	1.4754	2.0454	1.9161	.1867	.1457	.168
24	.168	.1629	1.3592	1.8442	1.643	.168	.1457
Max	2.3594	2.6749	2.2805	2.1795	1.643	2.7183	2.8349
Min	.132	.1307	.1075	.1254	.1294	.1086	.1457
Avg	.7186	1.0173	.7334	.8771	.6320	.9364	.6643

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 203 / 11 KV DHANEWADI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0119	1.8861	.1509	.1629	.1629	1.6078	1.8442
2	1.9839	1.8176	.1509	.1629	.1629	1.5746	1.8442
3	1.95	1.7635	.1509	.168	.1646	1.5565	1.8442
4	1.8991	1.8442	.1698	.181	.1646	1.5565	1.8442
5	1.8652	1.9281	.1886	.181	.1829	1.6221	1.8442
6	2.2634	2.0348	.1886	.181	.2172	1.6741	1.8778
7	2.3868	2.0481	.1886	.1991	.2454	1.9227	2.0119
8	.1829	.181	.1619	.1991	.181	.1629	.1755
9	.1526	.181	2.6825	2.9508	2.6981	.1595	.1753
10	.1734	.181	3.0521	3.0178	2.6155	.1629	.1753
11	.1578	.1629	2.9675	2.8016	2.7161	.1216	.1734
12		.1578	2.8502	2.8018	2.6155	.1629	.1543
13	.1715	.1578	2.7183	2.7368	2.4981	.1629	
14		.1715	2.9007	2.769	2.4478	.1629	
15	.1543	.1543	2.8344	2.8502	2.304	.1629	
16	.181	.1543	2.2186	2.4981	2.3304	.1629	
17	.2172	.1772	.1357	.1629	.1734	.181	
18	.2328	.1475	.1402	.1791	.1696	.1629	
19	.2534	.2572	.1791	.1629	.1991	.1629	
20	.2378	.2561	.1928	.2378	.2587	.181	
21	.2012	.168	.1991	.1867	.2195	.1991	.2561
22	2.0957		.1991	.181	1.9227	2.0814	2.1956
23	2.0348	.1698	.181	.1612	1.8067	2.0814	2.1628
24	2.0454	2.0062	.1698	.1457	.1629	1.6409	1.9909
Max	2.3868	2.0481	3.0521	3.0178	2.7161	2.0814	2.1956
Min	.1526	.1475	.1357	.1457	.1629	.1216	.1543
Avg	1.0387	.7829	1.0405	1.0533	1.1092	.8178	1.2856

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 204 / 11 KV YETGAON AG FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.6115	3.1886	.0754	.243	.1976	2.8578	3.4701
2	3.4833	3.079	.0754	.2437	.1806	2.7318	3.3657
3	3.3079	3.0171	.0754	.2768	.166	2.7105	3.3192
4	3.2081	3.0613	.0943	.2745	.1652	2.7516	3.3131
5	3.2495	3.1036	.104	.2844	.2014	2.9639	3.3192
6	3.3746	3.3578	.1509	.1661	.2513	3.2777	3.4693
7	3.7824	3.6207	.1698	.3251	.3049	3.5597	3.1223
8	.3103	.2892	.1698	.5958	.3152	.2765	.3155
9	.242	.2244	2.2542	4.7924	4.641	.2199	.255
10	.1999	.1935	2.3205	5.0498	4.8032	.2161	.2245
11	.1825	.2252	2.3205	4.9711	4.8741	.1753	.2199
12	.2199	.2233	2.42	4.7207	4.6601	.1951	.2229
13	.2744	.2195	2.251	4.6039	4.4494	.1882	.1311
14	.0472	.2241	2.2186	4.4876	4.2168	.1852	.1364
15	.2344	.2279	2.1862	4.4852	4.2042	.1898	.1288
16	.181	.2442	2.0405	4.296	4.1238	.1867	.1196
17	.2451	.2479	.0972	.2344	.2184	.1982	.1326
18	.2473	.1212	.081	.2271	.243	.202	.1265
19	.3069	.2352	.1457	.2729	.2637	.2683	.1471
20	.3416	.381	.1619	.3555	.3555	.3071	.2035
21	.6693	.3414	.1619	.3578	.69	.6159	.6245
22	3.7574	.1699	.1457	.3079	3.2791	3.9871	3.6321
23	3.6301	.2527	.1134	.242	3.2591	3.7182	3.5103
24	3.496	.2591	.1132	.2361	1.7688	2.0744	3.3825
Max	3.7824	3.6207	2.42	5.0498	4.8741	3.9871	3.6321
Min	.0472	.1212	.0754	.1661	.1652	.1753	.1196
Avg	1.6084	1.1045	.8311	1.7521	1.9930	1.4190	1.5372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 206 / 11 KV YERALA AG FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0486	.0324	1.576	1.6194	1.6385	.0324	.0324
2	.0486	.0324	1.5089	1.4899	1.326	.0324	.0324
3	.0324	.0324	1.5089	1.4899	1.2944	.0325	.0324
4	.0324	.0328	1.5424	1.4575	1.278	.0324	.0324
5	.0324	.0328	1.6095	1.4575	1.2631	.0324	.0324
6	.0486	.0328	1.6598	1.4413	1.326	.0324	.0324
7	.0486	.0328	1.6598	1.6032	1.3435	.0486	.0324
8	.081	.0648	.1509	.0486	.0324	.0324	.0489
9	1.9109	1.9845	.0549	.0486	.048	2.0729	2.0405
10	1.9271	2.0729	.0549	.0486	.0486	2.251	2.1214
11	1.9271	1.989	.0549	.048	.0324	1.7535	2.1376
12	1.917	1.8461	.0486	.0648	.0486	2.2348	
13	1.9109	1.9433	.0486	.0648	.0324	2.1538	
14		1.668	.0486	.0819	.0486	2.1052	
15	1.7814	1.8138	.0486	.0655	.0324	2.1077	
16	1.5708	1.7652	.0486	.0648	.0324	2.0243	
17	.0492	.1417	.0486	.0648	.0324	.0324	
18	.0492		.0486	.0648	.0486	.0486	
19	.0486	.1433	.0648	.0486	.0486	.0486	
20	.0492	.156	.0648	.0486	.0486	.0486	
21	.0492	1.7295	.0648	.0486	.0486	.0486	
22	.0324		1.7814	1.7652	.0486	.0324	.0486
23	.0328	1.8004	1.7328	1.7695	.0324	.0324	.0486
24	.0486	.0328	1.6766	1.6404	1.7166	.0324	.0324
Max	1.9271	2.0729	1.7814	1.7695	1.7166	2.251	2.1376
Min	.0324	.0324	.0486	.048	.0324	.0324	.0324
Avg	.5947	.8809	.7128	.6894	.4937	.7209	.4789

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA

Feeder No / Name : 201 / 11 KV VITA(U)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8524	3.0049	1.5242	3.1154	3.1299	3.0362	3.0952
2	2.7168	2.8799	1.5242	2.9851	2.905	2.8799	2.9645
3	2.6947	2.7694	1.4098	2.9317	2.8006	2.7092	2.9042
4	2.62	2.7358	1.448	2.8463	2.8623	2.7043	2.8357
5	2.6733	2.7473	1.4861	2.9363	2.8692	2.7782	2.7518
6	2.7427	2.9112	1.5242	3.0243	2.8661	2.9218	2.7046
7	2.9531	3.0453	1.4712	3.1116	2.8882	3.0392	2.7747
8	2.9394	3.152	1.5089	3.0811	2.9805	2.9561	2.5735
9	3.0872	2.9454	1.5466	3.1035	3.027	2.9287	2.4965
10	3.4785	3.3341	1.6598	3.3733	3.264	3.272	2.7183
11	3.7167	3.7582	1.8671	3.8317	3.4766	3.2366	2.8722
12	3.7502	3.608	1.8107	3.7769	3.3631	3.4054	1.5089
13	3.4682	3.416	1.773	1.0052	3.0689	3.4213	1.4464
14	3.706	3.6511	1.8484	1.4529	3.2697	3.6119	1.4388
15	3.7368	3.9171	1.9044	4.0207	3.408	3.7818	1.4662
16	3.5848	3.7064	1.9993	4.0672	3.4286	3.7711	1.483
17	3.6473	3.8378	2.0328	4.1666	3.5551	3.7914	1.4883
18	3.5246	3.7197	1.9044	3.9568	3.5292	3.7144	1.4678
19	4.2478	4.3016	2.0911	4.1502	3.9735	4.2048	1.7223
20	4.4026	4.5546	2.1879	4.3095	4.0642	4.4997	1.9776
21	3.9522	4.148	1.8861	3.7868	3.8013	4.0996	1.8785
22	3.5787	3.7372	1.7909	3.5353	3.5208	3.6572	1.7574
23	3.4058	3.6153	1.7528	3.4461	3.4683	3.6489	1.6598
24	3.1131	3.2739	1.6385	3.3357	3.3151	3.9312	3.0956
Max	4.4026	4.5546	2.1879	4.3095	4.0642	4.4997	3.0956
Min	2.62	2.7358	1.4098	1.0052	2.8006	2.7043	1.4388
Avg	3.3580	3.4488	1.7329	3.3063	3.2848	3.4167	2.2117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA

Feeder No / Name : 202 / 11 KV LENGARE (U)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8671	2.1102	1.1694	2.649	2.9188	2.7489	2.7534
2	1.8458	2.1689	1.1431	2.7252	2.9858	2.8631	2.7858
3	1.5874	2.1955	1.0669	2.6978	2.7884	2.6452	2.7218
4	1.784	2.1163	1.094	2.5103	2.6154	2.6059	2.7961
5	1.8191	2.0896	1.1317	2.537	2.6215	2.5667	2.4329
6	1.8199	2.0275	1.1694	2.4474	2.5801	2.4665	2.2066
7	1.845	2.3495	1.2696	2.5888	2.556	2.697	1.9906
8	2.1407	2.7226	1.448	2.7698	2.9424	2.9614	1.8884
9	2.7374	2.9515	1.6126	3.142	3.3341	3.3539	1.8496
10	3.1771	3.6458	1.7337	3.6206	3.6702	3.618	1.7779
11	3.5985	3.653	1.8031	3.8356	3.8577	3.9003	1.7734
12	3.3608	3.1261	1.2696	3.658	3.4751	3.5208	.8871
13	2.4036	2.5461	1.1317	2.5793	2.5004	2.6368	.3064
14	3.2785	3.5041	1.6644	3.5449	2.9984	3.6172	
15	3.5429	3.6622	1.7177	3.7799	3.6226	3.7582	
16	3.3676	3.5948	1.7193	3.5266	3.6565	3.562	.9998
17	3.232	3.3783	1.6644	3.3379	3.4073	3.256	.9968
18	3.0217	3.2107	1.4723	3.323	3.2998	3.1299	.9496
19	2.6912	3.128	1.576	3.3227	3.2937	3.2979	.9244
20	2.8476	3.1283	1.4998	3.3319	3.264	3.3189	1.086
21	2.2581	2.5983	1.1431	2.6756	2.7336	2.793	1.0669
22	2.418	2.862	1.5524	3.0392	3.0209	3.0925	1.0608
23	2.7267	3.1927	1.5364	3.3177	3.3821	3.4637	1.1279
24	2.3503	2.8844	1.2696	3.12	3.384	3.1474	2.4722
Max	3.5985	3.6622	1.8031	3.8356	3.8577	3.9003	2.7961
Min	1.5874	2.0275	1.0669	2.4474	2.5004	2.4665	.3064
Avg	2.5717	2.8686	1.4108	3.0867	3.1212	3.1259	1.6752

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA

Feeder No / Name : 203 / 11 KV BHALWANI(U)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5264	1.8983		2.0439	2.0089	2.0706	2.0264
2	1.5051	1.7992	.8859	2.0203	1.983	1.9944	1.9581
3	1.4586	1.7421	.7975	1.9833	1.9311	1.9646	1.9097
4	1.4357	1.7421	.8413	1.9707	1.9029	1.9708	1.8377
5	.7362	1.7947	.8916	1.989	1.9372	1.9456	1.7764
6	1.4342	1.9052	.9015	1.9989	1.9997	1.9669	1.8126
7	1.733	2.0896	.9015	1.9799	1.9898	2.1121	1.8244
8	1.9296	2.1422	.9069	2.0446	2.1818	2.0873	1.6941
9	2.3251	2.2162	1.012	2.1453	2.335	2.1239	1.9185
10	2.5324	2.3453	1.0753	2.4455	2.4744	2.2249	1.8538
11	2.732	2.5957	1.1523	2.5633	2.6216	2.3121	1.7726
12	2.5629	2.3944	.9393	2.5865	2.572	2.2115	1.0044
13	2.1582	2.2116	.8288	2.1186	2.1281	1.9257	.9587
14	2.2558	2.3388	1.0608	2.2626	2.2207	2.0104	.964
15	2.3739	2.3232	1.1271	2.3914	2.3827	2.0596	.9191
16	2.3247	2.4219	1.2266	2.5194	2.5888	2.1362	1.0014
17	2.3937	2.4867	1.1984	2.6048	2.5781	2.2028	1.0593
18	2.4463	2.4104	1.0688	2.4951	2.5218	2.1472	1.041
19	2.5007	2.3644	1.1271	2.582	2.3914	2.2436	.9137
20	2.5031	2.5606	1.1869	2.6227	2.4592	2.255	1.0395
21	2.2265	2.2966	1.0166	2.2657	2.2839	2.1986	1.0181
22	2.1513	2.2283	1.182	2.2375	2.1479	2.2779	1.0029
23	2.1925	2.2733	1.1218	2.268	2.3	2.2642	.9838
24	1.8526	2.1125	.9496	2.2093	2.1986	2.2264	1.8892
Max	2.732	2.5957	1.2266	2.6227	2.6216	2.3121	2.0264
Min	.7362	1.7421	.7975	1.9707	1.9029	1.9257	.9137
Avg	2.0538	2.1956	1.0174	2.2645	2.2558	2.1222	1.4241

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA

Feeder No / Name : 204 / 11 KV PARE (U)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4068	2.1308	1.2071	2.3769	2.3639	2.4402	2.5042
2	1.4076	2.1933	1.1431	2.3476	2.4043	2.4265	2.4897
3	1.3519	1.89	1.0562	2.2389	2.3845	2.3426	2.4622
4	1.2818	2.3205	1.094	2.1277	2.1963	2.3251	2.3152
5	1.2666	2.3556	1.105	2.1437	2.1369	2.3053	2.1627
6	1.4304	2.4386	1.2193	2.2287	2.2108	2.4302	2.0686
7	1.5912	2.383	1.2071	2.4782	2.431	2.5034	2.0485
8	1.9506	2.5564	1.2936	2.6391	2.6067	2.6223	1.7665
9	2.2123	2.8091	1.4712	2.7435	2.7687	2.7313	1.6636
10	2.372	2.9172	1.3611	2.6413	2.8383	2.6902	1.5341
11	2.4943	3.0225	1.4327	2.7313	2.9896	2.668	1.3478
12	2.3224	2.5019	1.094	2.777	2.726	2.529	.6607
13	.1456	2.0119	.9808	2.0964	1.9208	1.8678	.0221
14		2.5332	1.1827	2.6002	2.6841	2.5156	
15		2.809	1.3535	2.9713	2.9462	2.8281	
16	2.8601	2.8361	1.39	2.8525	3.0079	2.7519	.692
17	2.8098	2.7961	1.3969	2.6864	2.836	2.6498	.7644
18	2.8144	2.7786	1.3253	2.5278	2.8129	2.5804	.7697
19	2.8285	2.7409	1.4842	3.027	2.8563	2.9051	.8421
20	2.902	2.9767	1.4415	2.9924	3.0353	3.0917	2.0085
21	2.4364	2.4551	1.1431	2.4341	2.5667	2.7427	1.9185
22	2.5506	2.5549	1.358	2.6955	2.6978	2.7481	1.8343
23	2.6871	2.7267		2.8433	2.8258	3.0556	1.7109
24	1.9639	2.6025	1.1431	2.3201	2.7694	2.838	2.0344
Max	2.902	3.0225	1.4842	3.027	3.0353	3.0917	2.5042
Min	.1456	1.89	.9808	2.0964	1.9208	1.8678	.0221
Avg	2.0494	2.5559	1.2558	2.5634	2.6257	2.6079	1.6191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA

Feeder No / Name : 403 / 33KV NAGEVADI

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	17.4897	15.8436	12.4486	12.2428	13.9232	15.0549
2	16.5638	15.0549	11.6598	12.2085	13.3059	13.7174
3	16.3923	14.6777	11.4541	11.7627	12.8944	13.1344
4	16.3923	14.4376	11.3169	11.4884	12.62	13.0659
5	16.2209	14.9177	11.4884	11.4884	13.1687	13.2716
6	16.6667	16.2895	12.62	12.3114	14.5748	14.5405
7	22.771	19.856	15.7751	14.712	18.4843	19.3416
8	19.6845	16.6324	13.1687	12.3114	14.2661	16.2209
9	16.9067	18.5185	23.8683	23.8341	18.0727	14.7805
10	18.2785	18.8958	27.1605	25.8917	19.1701	14.712
11	18.0041	18.8615	26.3375	27.7092	18.7586	15.3635
12	18.2099	18.5871	27.0919	27.6749	18.107	14.0604
13	16.6324	17.7298	23.4568	25.7202	17.5583	4.9383
14	12.1056	16.4952	24.3142	24.7257	15.9808	4.6639
15	15.9465	16.6667	24.9657	24.2113	15.7408	4.6296
16	10.0823	17.9356	24.9657	24.3142	14.8148	10.8711
17	12.5858	13.8889	18.1756	18.3128	12.5858	10.7682
18	8.0933	8.5048	7.8532	7.9904	7.6475	5.0412
19	8.2991	8.4362	8.2991	8.2305	8.7449	5.8642
20	8.6077	9.7394	9.6365	9.1221	9.3279	6.7215
21	8.6763	9.0878	9.808	9.0878	9.3964	7.6475
22	18.3814	13.4774	13.3402	17.0096	18.0727	17.4554
23	19.3416	13.8203	14.0947	16.4609	19.4445	17.6612
24	16.8382	17.9424	12.963	19.1999	16.4266	16.3238
Max	22.771	19.856	27.1605	27.7092	19.4445	19.3416
Min	8.0933	8.4362	7.8532	7.9904	7.6475	4.6296
Avg	15.3821	15.2624	16.5109	17.0009	14.7120	12.0771

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/S

Feeder No / Name : 201 / 11 KV ALSAND AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2481	.2534	.2149	3.1459	2.8673	2.7846	.1753
2	.2328	.2534	.2103	3.1131	2.8018	2.7349	.1715
3	.2172	.2534	.2103	3.0498	2.6235	2.6852	.1715
4	.2195	.2561	.2303	2.9835	2.4806	2.5888	.1865
5	.2378	.2561	.2328	2.9843	2.2725	2.4577	.1865
6	.2561	.2561	.2561	2.9172	2.3482	2.4741	.2454
7	.2926	.2865	.2865	2.8182	2.6216	2.4615	.2454
8	.2865	.2865	.3086	.2035	.2481	.2343	.2429
9	2.8178	2.8178	.2715	.1949	.2804	2.982	3.2007
10	2.8178	3.315	.2686	.2481	.2622	3.2114	3.2007
11	2.652	3.0498	.2896	.2507		2.8673	
12		2.8178	.2865	.2507		3.195	
13		2.8182	.3258	.2279		3.2769	
14		2.8182	.3224	.208	.2481	3.1131	
15		2.6216	.3224	.2303	.2865	3.1131	
16	2.652	2.6216	.3224	.2629		2.9797	
17	.3224	.0857	.3224	.2572	.0351	.1858	
18	.2896	.2804	.3582	.2713	.2103	.1715	
19	.2896	.2835	.3582	.2686	.2865	.2347	
20	.2896	.2835	.3224	.2658	.2865	.2401	
21	.3258	.2629	.3189	.2401	.2835	.2374	
22	.2896	.2534	3.3316	3.0312	2.8509	.2507	
23	.2534	.2353	3.2819	3.1493	2.7854	.2303	
24	.2534	.2534	.2328	3.2156	2.9492	2.769	.2103
Max	2.8178	3.315	3.3316	3.2156	2.9492	3.2769	3.2007
Min	.2172	.0857	.2103	.1949	.0351	.1715	.1715
Avg	.7622	1.1217	.5369	1.4078	1.4514	1.9783	.7488

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/S

Feeder No / Name : 202 / 11 KV BHALWANI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2955	1.1385	1.0155			.0686	1.0957
2	1.2289	1.1069	.945			.0701	1.0364
3	1.2003	1.0753	.9145			.0716	1.0364
4	1.1069	1.0753	.873		.0351	.0716	.9783
5	1.0957	.9488	.8278		.0701	.0701	.9332
6	1.0031	.9488	.8592	.0739	.0739	.0876	1.0364
7	1.1069	.0671	1.1126	.0739	.1109		1.0517
8	.0693	.0671	.0903		.0867	.0594	.061
9	.1433	.0709	1.5684	1.5813	1.4232	.0686	.0716
10	.0709		1.6004	1.5813	1.4232	.0587	.08
11		.0739	1.5364	1.6004	1.2967	.0678	
12		.0716	1.4864	1.6004	1.3441		
13		.081	1.4548	1.5497	1.2963	.0671	
14		.0829	1.3435	1.4842	1.2346	.0663	
15		.1017	1.3916	1.3916	1.1728	.0663	
16		.0895	1.2498	1.3117	1.1574	.0701	
17	.064	.0819	.0648	.0926	.061	.081	
18	.064	.1029	.0655	.0791	.1715	.0834	
19	.0663	.0625	.0655	.0886	.208	.0983	
20	.0678	.0867	.0663	.0886	.2279	.0886	
21	.0678	.0848	.0838	.0876	.0867	.0838	
22	1.3279	1.2186	.0905	.0724	.0876	1.3123	
23	1.2955	1.1385			.0701	1.3123	
24	1.2809	1.1702	1.0311			.064	1.1702
Max	1.3279	1.2186	1.6004	1.6004	1.4232	1.3123	1.1702
Min	.064	.0625	.0648	.0724	.0351	.0587	.061
Avg	.6975	.4759	.8581	.7973	.5819	.1858	.7774

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/S

Feeder No / Name : 203 / 11 KV KAMLAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.3536	4.4369	1.5546	.4885	.4626	.5037	4.3537
2	4.1046	4.1914	1.4899	.4847	.4411	.4695	4.1099
3	3.9613	4.0627	1.4232	.4458	.4466	.4694	3.8965
4	3.876	3.9289	1.4232	.4405	.4578	.4694	3.6778
5	3.8161	3.7133	1.3283	.4466	.487	.5227	3.6
6	3.9312	3.9244	1.4083	.5385	.5773	.591	3.9742
7	4.3237	4.2486	1.6004	.6112	.6512	.663	4.2966
8	2.3636	.6127	.2481	.5914	.8223	.6105	.6294
9	.7735	.7075	2.0972	5.3483	5.6511	.7819	.7468
10	.7478	.7567	2.0119	5.394	5.6108	.8245	.7705
11	.3993	.7912	2.1719	5.1387	5.215	.8185	.3826
12	.397	.7619	1.9433	4.215	5.0327	.7811	.3666
13	.1875	.7587	2.9813	4.1915	5.0198	.6302	.3666
14	.2818	.7903	1.989	4.5735	4.9977	.5373	.365
15	.1738	.6653	2.0222	4.9353	4.3915	.5258	.3772
16		.7499	1.9559	4.6895	4.4607	.4777	.3833
17	.6538	.696	.2652	.5239	.6059	.5571	.3727
18	.722	.6771	.2652	.5007	.6706	.6318	.3818
19	.7228	.785	.3018	.5824	.7072	.6332	.3307
20	.7194	.7384	.3018	.6218	.7346	.6524	.6363
21	.9344	1.0326	.3018	.5521	.6828	.9463	2.7001
22	5.3601	4.0063	.3018	.5887	.6082	5.016	4.7604
23	5.0643	3.8965	.2683	.4687	.5365	5.0777	4.7089
24	4.654	4.0824	1.6194	.477	.4992	2.8925	4.4414
Max	5.3601	4.4369	2.9813	5.394	5.6511	5.0777	4.7604
Min	.1738	.6127	.2481	.4405	.4411	.4694	.3307
Avg	2.2835	2.1256	1.3031	1.9520	2.0738	1.0868	2.1095

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/S

Feeder No / Name : 204 / BHALWANI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.156	.1417	.1372	.1097	.128	.1052	.1227
2	.1387	.1417	.1372	.1109	.1109	.1052	.12
3	.1448	.1417	.1341	.1109	.1086	.0905	.1341
4	.1463	.1417	.1341	.1109	.1075	.0905	.1341
5	.1463	.1448	.1326	.1463	.124	.1086	.1311
6	.1448	.1448	.1791	.1463	.1448	.1254	.1372
7	.1433	.1429	.1265	.1791	.124	.1417	.1387
8	.1355	.1429	.1238	.1113	.125	.1219	.1046
9	.1029	.1006	.1265	.0926	.1143	.0995	.1017
10	.1417	.0903	.0617	.1158	.1143	.096	.1014
11	.0987	.1006	.1143	.1158	.104	.0819	
12			.096	.1158	.104	.1006	
13			.0937	.1219	.0974	.108	
14			.1036	.1189	.1158	.1054	
15	.141		.1463	.1219	.0892	.108	
16	.125	.1505	.1107	.1257	.1054	.0937	
17	.1265	.1532	.1619	.0914	.0991	.084	
18	.1311	.1181	.1943	.0663	.1486	.0945	
19	.1311	.1204	.213	.128	.1898	.1524	
20	.1715	.2267	.213	.218	.213	.1966	
21	.1715	.213	.2105	.218	.1943	.1966	
22	.181	.1753	.1791	.181	.1753	.1772	
23	.1448	.1433	.1463	.1478	.1433	.1448	
24	.1734	.1417	.1387	.1097	.128	.1214	.1227
Max	.181	.2267	.213	.218	.213	.1966	.1387
Min	.0987	.0903	.0617	.0663	.0892	.0819	.1014
Avg	.1427	.1438	.1423	.1298	.1295	.1187	.1226

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/S

Feeder No / Name : 205 / ALSAND / KAMALAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6485	.6413	.3326	.631	.642	.6264	.6264
2	.6165	.6595	.3326	.6226	.6059	.5864	.6157
3	.5964	.62	.3326	.598	.6249	.5757	.6142
4	.5632	.6935	.3361	.5818	.6524	.5731	.618
5	.727	.8108	.4481	.6493	.7346	.628	.7453
6	1.0483	1.0662	.5601	.9206	.9629	.8695	1.0421
7	1.2338	1.1031	.5228	1.1595	1.0936	1.105	1.1282
8	.9915	.9903	.4075	.9541	.9907	.9282	.9952
9	.7888	.8687	.3429	.825	.8133	.7545	.7754
10	.7613	.8089	.362	.7393	.6908	.7011	.7787
11	.678	.793	.3761	.6527	.6497	.5895	.3887
12	.6409	.7963	.3658	.4893	.6666	.5516	.3559
13	.2164	.6259	.3582	.634	.6536	.6942	.3132
14		.746	.3761	.6642	.6696	.7338	.3437
15	.7589	.7339	.3045	.7201	.6553	.746	.3422
16	.6909	.618	.2865	.668	.6668	.724	.3711
17	.7762	.7693	.3658	.7239	.6771	.74	.4016
18	.8227	.7598	.4572	.7789	.7499	.8151	.4466
19	1.0174	1.0014	.543	.919	.8802	.9335	.5434
20	1.0661	1.1248	.5068	1.0707	1.0624	1.1519	.5723
21	1.0219	1.0928	.4706	1.0532	1.0257	1.0845	.5548
22	.9411	.9503	.3982	.8844	.9046	.9533	.4854
23	.8154	.8284	.362	.6809	.7544	.7682	.4603
24	.666	.7304	.3696	.6642	.4874	.6748	.6996
Max	1.2338	1.1248	.5601	1.1595	1.0936	1.1519	1.1282
Min	.2164	.618	.2865	.4893	.4874	.5516	.3132
Avg	.7864	.8264	.3966	.7619	.7631	.7712	.5924

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/S

Feeder No / Name : 206 / 11 KV Umar Kanchan

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.1448	.1387	2.7664	2.4291	1.8244	.128
2	.1267	.1448	.1387	2.7161	2.3205	1.8679	.128
3	.1494	.1448	.1402	2.652	2.2939	1.8351	.1267
4	.1307	.1509	.1402	2.5029	2.0805	1.8023	.1267
5	.1109	.1509	.1402	2.3205	2.0005	1.7859	.1254
6	.1307	.1509	.1463	2.1628	2.0325	1.8461	.1402
7	.1294	.1526	.1791	2.0891	2.1862	1.9204	.1402
8		.1526	.1475	.1341	.1526	.1214	.1475
9	2.4577	2.6216	.1227	.1402	.1187	2.3594	2.8675
10	2.4577	2.7199	.1227	.1372	.1387	2.5069	2.6052
11	2.2939	2.672	.124	.1357	.1387	2.5888	
12		2.8673	.1227	.1357	.1387	2.5396	
13		2.5101	.1492	.1147	.1357	2.6558	
14	2.2939	2.5587	.1492	.0995	.1387	2.5263	
15		2.5101	.1526	.1357	.1372	2.5587	
16		2.4291	.156	.1475	.1526	2.4291	
17	.1017		.1753	.1372	.1187	.144	
18	.1696	.1387	.1753	.1526	.1402	.1457	
19	.181	.1372	.1734	.1734	.1433	.1433	
20	.1829	.1417	.2804	.1949	.1629	.181	
21	.2012	.1595	.3155	.1578	.1629	.181	
22	.168	.1417	2.3967	2.4939	2.1548	.1663	
23	.168	.124	2.982	2.4577		.1294	
24		.1448	.1387	2.7362	2.4086	1.8785	.128
Max	2.4577	2.8673	2.982	2.7664	2.4291	2.6558	2.8675
Min	.1017	.124	.1227	.0995	.1187	.1214	.1254
Avg	.6424	1.0030	.3711	1.1206	.9516	1.5057	.6058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/S

Feeder No / Name : 207 / VITA WATER SUPPLY,ALSAND NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2267	.2321	.1966	.218	.2347	.2155	.1989
2	.213	.2321	.1966	.2155	.218	.2155	.1989
3	.2155	.2321	.1966	.2155	.1989	.2155	.1989
4	.1989	.2321	.1966	.2155	.213	.2155	.1989
5	.2155	.2321	.1966	.218	.2294	.2155	.1943
6	.2321		.2321	.218		.2155	.1966
7	.1989	.1966			.2321	.2294	.1966
8	.1326	.1966	.192	.2294	.2294	.2294	.2241
9	.2321	.2321	.2321	.2321	.2294	.2321	.2321
10	.2321	.2347	.2321	.1989	.2294	.2321	.2155
11	.2321	.218	.2321	.1989	.213	.2321	
12	.2321	.2155	.2294	.1966	.2321	.2321	
13	.2294	.213		.1823	.213	.2818	
14	.2321		.213	.1966		.116	
15	.2321	.2155	.2155		.213	.213	
16		.2056	.1966	.2105	.213	.213	
17	.2155	.1966	.2321	.213	.213	.213	
18	.1989	.1989	.2321	.213	.2294	.1966	
19	.1989	.2321	.2294	.2294	.2294	.1966	
20	.1966	.1966	.2294	.2105	.2267	.1966	
21	.1966	.1943	.2105	.2105	.2105	.1943	
22	.2321		.2155	.2294	.2105	.1989	
23	.2321	.1989	.1357		.1341		
24	.2267	.2321	.1966	.2155	.2321	.213	.1989
Max	.2321	.2347	.2321	.2321	.2347	.2818	.2321
Min	.1326	.1943	.1357	.1823	.1341	.116	.1943
Avg	.2153	.2161	.2109	.2127	.2175	.2136	.2049

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/S

Feeder No / Name : 201 / 11 KV GARDI FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.989	1.7204	.1075	.1097	.1227	1.6575	1.8023
2	1.8233	1.704	.0895	.1097	.1063	1.6575	1.7368
3	1.7404	1.704	.1063	.1097	.1075	1.6385	1.7532
4	1.6575	1.7532	.1448	.112	.1254	1.6385	1.7695
5	1.7404	1.7814	.1463	.1307	.1629	1.6385	1.749
6	1.8233	1.8461	.1663	.168	.181	1.8023	1.8461
7	2.0885	1.9989	.1848	.2054	.2033	1.8351	1.8673
8	.1326	.1448	.1677	.1823	.1677	.1311	.1296
9	.0995	.128	2.8012	2.7515	2.7854	.1311	.1134
10	.1063	.1109	3.0664	2.8509	3.1327	.1372	.0886
11	.112	.0934	3.2358	.2652	3.0996	.1372	.0914
12	.1478	.1029	3.1131	2.7681	3.0498	.128	.12
13	.1478	.0983	2.9656	2.9338	2.8509		
14		.12	2.9656	2.8675	2.652	.0926	
15		.1029	3.0167	2.9007	2.652	.096	
16	.1054	.1227	2.7035	2.4741	2.3537	.092	
17	.0886	.12	.1029	.1402	.116	.0823	
18	.1433	.1311	.1372	.1475	.116	.104	
19	.1629	.1791	.1417	.1629	.116	.1578	
20	.1848	.2012	.1402	.1772	.1326	.181	
21	.1848	.2172	.1753	.1734	.1326	.1294	
22	1.9559	.1478	.1307	.1463	1.7901	2.0481	
23	1.8679	.1478	.128	.128	1.7404	1.9662	
24	2.0553	1.7695	.1417	.1097	.1227	1.6575	1.8351
Max	2.0885	1.9989	3.2358	2.9338	3.1327	2.0481	1.8673
Min	.0886	.0934	.0895	.1097	.1063	.0823	.0886
Avg	.9253	.6852	1.0866	.9219	1.1675	.8321	1.1463

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/S

Feeder No / Name : 202 / 11kv prabhat steel

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1672	.1619	.0046	.1624	.1722	.3147	.1639
2	.1665	.1624	.003	.1619	.1711	.3147	.1684
3	.1668	.1635	.0046	.1646	.1707	.3151	.1669
4	.1668	.1624	.0061	.1634	.1761	.3151	.1669
5	.1657	.1596	.0152	.1639	.1864	.314	.1684
6	.16	.1593	.0229	.1608	.1822	.3075	.165
7	.1562	.1913	.0198	.1772	.181	.314	.189
8	.3898	.4405	.0152	.615	.3948	.4938	.1844
9	1.102	.4679	.2829	.7077	1.1079	.7053	.1669
10	1.877	.9541	.5658	1.0519	.7011	1.4903	.1696
11	.9747	.6834	.1886	1.19	1.0353	.8962	.1665
12	.7204	.6561	.4904	1.4502	1.0535	.7606	.1787
13	.7354	.4489	.1886	.58	.5884	.804	.1783
14	.6692	.7015	.1886	.6253	.8566	.751	.1768
15	.7954	.6893	.1886	1.2519	1.0764	.5014	.1749
16	.7869	1.3121	.2075	.5849	1.7581	.77	.168
17	.7324	.7201	.2263	.6543	.6909	.7384	.1703
18	1.6754	1.0518	.3961	.7348	.5405	1.1974	.1696
19	.274	.6725	.2218	1.1879	.5908	.6409	.1673
20	.1707	.98	.3395	.5981	.4733	.639	.1692
21	.1719	.1726	.0061	.1771	.3136	.4218	.1684
22	.1604	.1688	.0061	.168	.3109	.1601	.1623
23	.1593	.1619	.0061	.1615	.2983	.1612	.1585
24	.1619	.1662	.0061	.1578	.1734	.3098	.1658
Max	1.877	1.3121	.5658	1.4502	1.7581	1.4903	.189
Min	.1562	.1593	.003	.1578	.1707	.1601	.1585
Avg	.5294	.4837	.1500	.5438	.5501	.5682	.1702

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/S

Feeder No / Name : 203 / 11 kv Yetgaon AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.399	.4664	1.6244	1.6766	1.8233	.2058	.1886
2	.3967	.4603	1.5729	1.643	1.7204	.2058	.1886
3	.3643	.4587	1.5402	1.6617	1.6385	.2058	.1509
4	.3793	.458	1.6078	1.6956	1.7204	.2058	.1509
5	.4275	.4534	1.7939	1.7939	1.7901	.2058	.1886
6	.4833	.4534	2.4247	2.146	1.873	.2058	.2452
7	.6086	.5853	2.4247	2.0119	2.1795	.2743	.2587
8	.5689	.5961	.2263	.2477	.2641	2.0576	.2218
9	5.1446	6.0059	.2263	.2477	.2452	2.915	2.5149
10	5.5182	6.3123	.2263	.2286	.2452	3.1036	2.8837
11	6.0943	6.3763	.2096	.2286	.2328	2.7435	2.7831
12	5.8798	6.121	.2286	.2477	.2229	2.5987	
13	5.3185	5.9724	.2286	.1886	.1715	2.5484	
14	1.7543	5.6135	.2096	.1905	.1886	2.5819	
15	2.7069	5.612	.2096	.2286	.2058	2.5265	
16	2.4863	5.7697	.2263	.2263	.2401	2.3205	
17	1.6842	1.9359	.2263	.2641	.2401	.2263	
18	.4981	.492	.3018	.2641	.2267	.3174	
19	.58	.5142	.2641	.2829	.3395	.3361	
20	.5694	.5512	.2641	.3018	.2915	.3018	
21	.5552	.5445	.2263	.2641	.2743	.3018	
22	.5445	3.9163	2.1365	2.0287	.2743	.2641	
23	.5066	4.1777	2.079	2.0287	.2507	.2075	
24	.4504	2.4302	1.6575	1.7436	1.8564	.2058	.1886
Max	6.0943	6.3763	2.4247	2.146	2.1795	3.1036	2.8837
Min	.3643	.4534	.2096	.1886	.1715	.2058	.1509
Avg	1.8300	2.7615	.9223	.9100	.7715	1.1277	.8303

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/S

Feeder No / Name : 204 / 11 KV SALSHINGE FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5708	1.3923	.1494	.1848	.3967	2.7324	2.8471
2	1.387	1.3592	.1478	.1867	.3734	2.5818	2.6063
3	1.46	1.3272	.1494	.1848	.3528	2.5088	2.5714
4	1.386	1.3599	.1698	.1867	.3883	2.536	2.6219
5	1.4784	1.4582	.1886	.1867	.4321	2.5545	2.7865
6	1.4737	1.6712	.2452	.2772	.4885	3.1996	3.2476
7	1.8111	1.8023	.2987	.2957	.6565	4.0882	4.0017
8	.2587	.1448	.2507	.3429	.6256	1.1332	1.2765
9	.156	.2587	2.2801	2.6242	5.0705	.442	.4368
10	.2241	.2218	2.431	2.7166	5.2903	.4092	.4413
11	.2033	.1848	2.4143	2.4034	5.2721	.3967	.3803
12	.2218	.181	1.4754	2.3807	5.1067	.3696	.4489
13	.1848	.181	2.3137	2.3137	4.7432	.0526	.2462
14		.1829	2.4813	2.4813	5.266	.3647	.1905
15		.2218	2.4813	2.4143	4.984	.4497	.2248
16	.1867	.1848	2.3472	2.2801	4.6312	.4726	.2294
17	.2218	.1829	.2241	.2103	1.2452	.538	.1989
18	.2218	.197	.2241	.2347	.4167	.4969	.2256
19	.2772	.2378	.2587	.1075	.3986	.5708	.285
20	.2587	.2587	.2218	.3258	.4919	.5167	.3155
21	.2772	.2587	.2218	.3189	.4908	.5274	.2964
22	1.576	.2427	.2033	.2614	2.8776	3.3608	1.7574
23	1.5257	.1867	.1848	.2241	2.9498	3.2347	1.7962
24	1.5893	1.4419	.1867	.7716	1.8717	2.9336	3.0917
Max	1.8111	1.8023	2.4813	2.7166	5.2903	4.0882	4.0017
Min	.156	.1448	.1478	.1075	.3528	.0526	.1905
Avg	.8159	.6308	.8979	.9964	2.2842	1.5196	1.3552

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/S

Feeder No / Name : 206 / 11 kv salshinge Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2149	.2103	.2477	.2481	.2263	.2614	.2103
2	.2328	.2103	.2286	.2172	.2096	.2614	.2103
3	.2686	.2126	.1905	.2149	.1905	.2587	.2103
4	.2149	.2303	.2286	.2507	.2286	.2614	.2279
5	.2686	.2629	.3048	.3155	.2667	.2561	.2658
6	.3403	.3856	.415	.4481	.381	.3582	.3544
7	.4835	.4908	.4481	.4119	.5093	.3841	.443
8	.3045	.3506	.3361	.3403	.3921	.3174	.3155
9	.3439	.298	.3475	.3761	.3801	.3584	.2804
10	.3012	.298	.3582	.3582	.3258	.3361	.2804
11	.3403	.2743	.3224	.3258	.3292	.3109	.2835
12	.3045	.2915	.298	.3052	.2957	.2987	.2743
13		.2572	.2804	.2572	.3174	.2957	
14	.2454	.3018	.3189	.2915	.3361	.3045	
15	.2835	.3189	.3155	.3052	.3142	.298	
16	.2629	.3601	.298	.3506	.2926	.2835	
17	.3155	.3721	.3155	.3224	.3077	.2328	
18	.3155	.3224	.298	.3258	.3475		
19	.3856	.4344	.4733	.4854	.3841	.4119	
20	.4382	.4668	.3681	.5281	.4668	.4477	
21	.4075	.4481	.4031	.4527	.4108	.4119	
22	.3506	.3961	.3681	.415	.3584	.3582	
23	.2804	.3174	.2804	.3018	.2829	.2865	
24	.2149	.2454	.2858	.2804	.2829	.3045	.2454
Max	.4835	.4908	.4733	.5281	.5093	.4477	.443
Min	.2149	.2103	.1905	.2149	.1905	.2328	.2103
Avg	.3095	.3232	.3221	.3387	.3265	.3173	.2770

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/S

Feeder No / Name : 207 / 11 kv yetgaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0754	.0739	.1109	.0747	.0709	.0747
2			.0747	.1109	.0754	.0716	.0739
3				.0924	.0754	.0724	.0739
4				.0747	.0943	.0716	.0747
5		.0754	.0754	.0934	.0934	.0716	.0747
6		.0934	.1132	.1307	.0934	.0895	.112
7		.1086	.1433	.1448	.1294	.0895	.1387
8		.1029	.1174	.1387	.124	.0895	.0857
9	.0895	.1063	.1387	.1075	.0886	.0895	.0867
10	.1029	.1063		.0895	.1063	.0716	.0867
11	.1052	.1052	.1227	.0876	.104		
12	.0709	.1052	.1214	.0886	.0857		
13			.1052	.0716	.0838	.0678	
14			.1063	.0716	.0895	.0686	
15	.0876		.1227	.0724		.0678	
16	.1052	.0876	.1227	.0716	.0895	.0995	
17	.0876	.1387	.1402	.1063	.0895	.0678	
18	.1753	.1029	.1417	.0886	.0895	.1029	
19	.1086	.1075	.1387	.1267	.1063	.1227	
20	.1267	.1109	.1387	.1307	.0895	.1267	
21	.0934	.1097	.1402	.1307	.0716	.1267	
22	.0934	.0934	.1463	.112	.0716	.0924	
23	.0754	.0747	.1097	.0943	.0716	.0924	
24		.0754	.0739	.1109	.0934	.0732	.0739
Max	.1753	.1387	.1463	.1448	.1294	.1267	.1387
Min	.0709	.0747	.0739	.0716	.0716	.0678	.0739
Avg	.1017	.0989	.1175	.1024	.0909	.0862	.0869

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV STN LENGRE

Feeder No / Name : 201 / 11 KV Lengare Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8755	1.8473	.0754	.0566	.0566	.695	.9282
2	1.8419	1.8381	.0754	.0566	.0566	.695	.9282
3	1.8305	1.8549	.0754	.0566	.0754	.695	.9602
4	1.832	1.9189	.0754	.0566	.0754	.695	1.0242
5	1.8857	2.0523	.0754	.0566	.0943	1.0084	1.1203
6	2.0538	2.3411		.0566	.0943	1.0686	1.2018
7	3.259	1.7619	.0693		.0754		1.2811
8	.8481	1.0257		.0566	.0943	.0754	.0566
9	.0754	.0943	1.2498	1.2498	1.2018	.0754	.0566
10		.0943	1.2498	1.3123	1.1149	.0754	.0566
11	.0754	.0943	1.3123	1.1873	1.0562	.0566	.0566
12	.0754	.0943	1.2811	1.0709	.9976	.0566	.0566
13	.1132	.0943	1.2498	1.1288	1.0136	.0566	
14		.0943	1.3443	1.1591	.9587	.0566	
15		.0943	1.2811	1.174	.8901	.0566	
16		.0943	1.2498	1.1574	.9328	.0566	
17	.1509	.0943	.0566	.1132	.0754	.0566	
18	.132	.0943	.0566	.1132	.0754	.0566	
19	.132	.0754	.0566	.1132	.0754	.0566	
20	.1132	.0754	.0566	.132	.0754	.0566	
21	.1132	.0754	.0566	.1132	.0754	.0566	
22	2.4158	.0754	.0566	.0943	.7529		
23	2.2746	.0754	.0566	.0754	.695	.9282	.8215
24	1.9265	.8025	.0754	.0566	.0754	.695	.9122
Max	3.259	2.3411	1.3443	1.3123	1.2018	1.0686	1.2811
Min	.0754	.0754	.0566	.0566	.0566	.0566	.0566
Avg	1.1512	.6984	.5062	.4629	.4453	.3331	.6758

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV STN LENGRE

Feeder No / Name : 202 / 11 KV VEJEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2286		1.6057	3.5978	.4443	.4176
2	.2263	.2286		1.5402	3.4957	.4443	.4435
3	.2263	.2286		1.5402	3.4568	.4435	.4836
4	.2263	.2286		1.5729	3.4576	.4668	.4721
5	.2641	.2667		1.6057	3.5817	.4721	.4902
6	.3018	.3048		2.2939	3.7312	.5259	.5169
7	.3395		1.8778		4.1053	.3109	.6381
8	.2829	.362		.1886	.916	.7095	.5854
9	2.146	2.8317	.415	.2263	.5007	5.0793	6.1423
10	3.0182	3.3573	.3395	.2263	.5313	3.4537	6.0585
11	2.7949	2.6452	.3584	.2801	.5194	4.2841	5.8154
12	2.2969	2.3739	.3772	.2801	.5224	5.0772	2.7686
13	2.6452	2.3739	.3395	.2829	.5415	5.0815	
14		2.34	.3772	.2801	.5453	4.582	
15		2.3061		.3395	.543	4.6388	
16		2.3061	.3395	.3395	.599	5.0519	2.1224
17	.1715	.2641	.3584	.1509	.5392	.4923	.3216
18	.3395	.3395	.3772	.0943	.445	.4755	.2827
19	.3395	.3018	.3772	.3048	.461	.5516	.2522
20	.3429	.2641	.3395	.3239	.5217	.317	.2964
21	.3239	.2641	.3395	.2858	.527	.5354	.285
22	.2667	1.6095	1.9006	1.95	.2423	.2202	.266
23	.2477	1.6278	1.6057	2.0178	.4603	.429	.5263
24	.2263	.2286		1.6057	2.0652	.4214	.4412
Max	3.0182	3.3573	1.9006	2.2939	4.1053	5.0815	6.1423
Min	.1715	.2286	.3395	.0943	.2423	.2202	.2522
Avg	.8216	1.1862	.6481	.8407	1.4961	1.8545	1.4108

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV STN LENGRE

Feeder No / Name : 203 / 11 KV SALSHINGE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6707	2.6966		.3002	.3769	2.3686	2.7492
2	2.6653	2.6528		.3018	.3769	2.3511	2.7221
3	2.6691	2.6086		.3221	.3814	2.3313	2.7214
4	2.7465	2.6448		.3259	.3845	2.3489	2.7066
5	2.8845	2.7261		.3433	.389	2.4486	2.745
6	3.4469	3.0659		.3456	.3921	2.8889	3.1848
7	3.8119	2.0469	.2103	.2149	.367	1.7924	3.7186
8	.4245	.4558		.692	.8383	.4093	.407
9	.3833	.3003	2.146	4.4917	4.3141	.2835	.3506
10	.4107	.2563	2.1628	4.7127	4.1652	.2835	.3235
11	.3287	.2551	1.9662	4.1655	4.0128	.3346	.3315
12	.352	.3334	1.9334	4.1117	4.0009	.3262	.3926
13	.3345	.3677	1.9498	4.135	3.9841	.3521	.2096
14	.003	.3704	1.9662	4.2048	3.805	.3658	.1852
15	.1433	.3574	1.9334	4.4681	3.9155	.3591	.1905
16		.3792	1.9006	4.2527	4.0055	.3561	.1654
17	.3898	.3673	.208	.4092	.3948	.3765	.1799
18	.4264	.4024	.1928	.4797	.4458	.2477	.2286
19	.503	.4127	.2103	.5056	.4908	.4657	.2705
20	.5616	.4306	.208	.5308	.4962	.4862	.269
21	.8173	.4534	.2254	.524	.7754	.583	.7545
22	2.987	.3742	.1753	.4289	2.5347	1.7307	1.7147
23	2.9558	.3471	.1402	.386	1.4114	2.9812	2.9454
24	2.8185	1.4079		.3353	1.4944	2.6399	2.8575
Max	3.8119	3.0659	2.1628	4.7127	4.3141	2.9812	3.7186
Min	.003	.2551	.1402	.2149	.367	.2477	.1654
Avg	1.5102	1.0714	1.0955	1.7078	1.8230	1.2130	1.3468

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV STN LENGRE

Feeder No / Name : 204 / 11 KV Lengare Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5567	.538		.2614	.3292	.3658	.3658
2	.551	.5361		.2614	.3292	.3658	.3475
3	.546	.5281		.2427	.3292	.3224	.3292
4	.5605	.5348		.2427	.3326	.3224	.2801
5	.5894	.571		.2614	.3326	.3582	.2054
6	.6744	.6826		.2987	.3326	.3582	.3361
7	.7476	.4188	.394		.3982		.4024
8	.7182	.7617		.3361	.3222	.4024	.362
9	.66	.5807	.3086	.2103	.3113	.2915	.2614
10	.5247	.6641	.2774	.2103	.213	.2294	.2614
11	.4786	.5872	.2427	.3086	.2058	.2561	.3544
12	.2435	.2431	.2103	.3429	.2058	.2561	.3772
13			.208	.3185	.208	.2103	
14			.208	.3258	.2743	.2103	
15	.6825	.0263	.1886	.3294	.3086	.2561	
16	.6283	.7887	.1886	.3086	.3185	.2561	
17	.6306	.6322	.2507	.3277	.285	.2801	
18	.6606	.612	.2865	.2126	.2652	.2614	
19	.8015	.7705	.4024	.4382	.333	.2987	
20	.9932	.9694	.3658	.4887	.3506	.3361	
21	.9625	.9778	.3658	.4887	.5014	.4024	
22	.8299	.8402	.3361	.4435	.439		
23	.6969	.7209	.2614	.3511	.3658	.3841	1.3443
24	.5624	.5982		.2614	.3475	.3658	.3658
Max	.9932	.9778	.4024	.4887	.5014	.4024	1.3443
Min	.2435	.0263	.1886	.2103	.2058	.2103	.2054
Avg	.6500	.6174	.2809	.3161	.3183	.3086	.3995

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV STN LENGRE

Feeder No / Name : 205 / 11 KV SALSHINGE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.1715	.1905	.1905	.1524	.1905	.2477
2	.2286	.1524	.1905	.1905	.1524	.1905	.2286
3	.2286	.1524	.1905	.2096	.1524	.1905	.2286
4	.2477	.1715	.1905	.2096	.1524	.2096	.2096
5	.2477	.1715	.2096	.2286	.1715	.2096	.2096
6	.2477	.1905	.2286	.2286	.1905	.2286	.2477
7	.2286		.2477		.2096		.2286
8	.1905	.2096	.2286	.1905	.1715	.2286	.362
9	.1334	.2286	.2096	.1524	.2096	.1524	.2477
10	.0762	.1905	.1905	.1905	.0953	.0953	.2477
11	.1905	.1524	.2286	.1905	.1905	.1905	.1905
12			.2096	.1524	.2477	.2096	.1715
13		.2096	.1905	.1905		.1905	
14		.2096	.1905	.1715		.1905	
15	.2477	.2096	.1905	.1715		.2286	
16	.2096	.2096	.2096	.1715		.2477	
17	.1905	.1524	.2477	.1715		.2286	
18	.1905	.1524	.4382	.1715		.1905	
19	.2858	.1905	.2667	.2667	.2286	.2286	
20	.3239	.2286	.2667	.3048	.2477	.2667	
21	.3239	.2858	.2858	.3048	.2858	.3239	
22	.3048	.2858	.2286	.2858	.3048		
23	.2477	.2286	.2096	.2477	.2477	.2667	.2286
24	.2667	.1715	.1905	.1905	.1905	.2477	.2477
Max	.3239	.2858	.4382	.3048	.3048	.3239	.362
Min	.0762	.1524	.1905	.1524	.0953	.0953	.1715
Avg	.2304	.1966	.2262	.2079	.2001	.2139	.2354

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV STN LENGRE

Feeder No / Name : 206 / 11 KV VEJEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2286	.2286	.2286	.2858	.2667	.2858
2	.2286	.2286	.2286		.2858	.2667	.2858
3	.2286	.2286	.2286	.2667	.2858	.2667	.2667
4	.2477	.2286	.2286	.2667	.2858	.2858	.2667
5	.2477	.2477	.2286	.3048	.2858	.2858	.2858
6	.2477	.2667	.2667	.3048	.2667	.3048	.2667
7	.2667		.2858		.2667		.2858
8	.2477	.2477	.2477	.3429	.3239	.3239	.3048
9	.2667	.2858	.2858	.2286	.3429	.2858	.2286
10	.1905	.2858	.2477	.2858	.381	.3048	.2286
11	.2858	.2858	.2286	.3048	.2286	.2667	.2667
12	.1715	.2858	.2096	.3048	.2477	.2667	.3048
13		.2096	.2096	.2858		.2096	
14	.2858	.2096	.2096	.3048		.2096	
15	.2286	.2096	.2096	.3048		.2667	
16	.2858	.2096	.2096	.2096		.2858	
17	.2477	.1905	.2286	.3048		.2667	
18	.4001	.1905	.2667	.3048		.2477	
19	.3048	.2286	.362	.381	.3048	.2858	
20	.381	.3048	.3429	.4572	.3429	.3239	
21	.362	.381	.362	.4382	.381	.381	
22	.3048	.3239	.3048	.381	.362		
23	.2667	.2667	.2286	.3429	.3048	.3048	.2858
24	.2667	.2286	.2286	.2286	.3048	.3048	.3048
Max	.4001	.381	.362	.4572	.381	.381	.3048
Min	.1715	.1905	.2096	.2096	.2286	.2096	.2286
Avg	.2692	.2510	.2532	.3083	.3048	.2823	.2762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV STN LENGRE

Feeder No / Name : 207 / 11KV KANDESARWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566		.2705	.2498	.0566	.0566
2	.0566	.0566		.2976	.2498	.0566	.0566
3	.0566	.0566		.3384	.2534	.0566	.0566
4	.0566	.0566		.3948	.2667	.0566	.0566
5	.0566	.0566	.3292	.423	.3292	.0566	.0566
6	.0566	.0566	.439	.4664	.3666	.0566	.0566
7	.0566		.5335		.4801		.0566
8	.0566	.056	.0754	.0566	.0554	.0566	.0566
9	.2317	.6241	.0754	.0566	.0549	.6622	.6539
10	.4161	.535	.0754		.0543	.6097	.6161
11	.5053	.5213	.0566		.0554	.6401	.4401
12	.4451	.5144	.0566		.056	.6401	
13	.447	.5075	.0566			.6706	
14		.4729	.0566			6.7673	
15		.4729	.0566	.056		.5639	
16		.4729		.0554		.5357	
17	.056	.0566	.0566	.056		.0566	
18	.0554	.0566	.0566	.0549		.0566	
19	.056	.0566	.0566	.0554	.0566		
20	.0566	.0566	.0566	.056	.0566		
21	.0566	.0943	.0566	.0566	.0943		
22	.0566	.2782	.2961	.2858	.0754		
23	.0566	.2435	.2976	.2782	.0754	.0566	.0566
24	.0754	.0566		.2705	.257	.0754	.0566
Max	.5053	.6241	.5335	.4664	.4801	6.7673	.6539
Min	.0554	.056	.0566	.0549	.0543	.0566	.0566
Avg	.1413	.2355	.1493	.1960	.1715	.6174	.1751

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244077 / 33/11 KV KARVE MIDC

Feeder No / Name : 201 / 11 KV TEXTILE PARK

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.631	.7011	.5487	.8048
2		.6089	.7011	.5487	.6805
3		.6805	.7282	.5144	.6733
4		.631	.7442	.5144	.6733
5		.6154	.6516	.5201	.6878
6		.6584	.6661	.5201	.724
7		.6626	.6935	.5201	.6935
8		1.0985	.6859	.5375	.7796
9			.8764	.6762	.9015
10		.9412	.8322	.7455	.9214
11	.9362	1.0719	.8322	.7628	.8596
12	.9015	1.1458	.8669	.7282	
13	.6036	.6697	.7282		
14	.9054	.6447	.8322	.7455	
15	.9054	.631	.8669	.7975	
16	1.0185	.7455	.8495	.8048	
17	.8488	.6859	.8149	.7802	
18	.2452	.7011	.7802	.7108	
19	.8573	.7011	.7282	.6241	
20	.9114	.6859	.6935	.6154	
21	.583	.7011	.6588	.6173	
22	1.0185	.6859	.5548	.6413	
23	.7922	.6516	.5548	.8596	
24		.6516	.6516	.5548	.4024
Max	1.0185	1.1458	.8764	.8596	.9214
Min	.2452	.6089	.5548	.5144	.4024
Avg	.8098	.7348	.7372	.6473	.7335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244077 / 33/11 KV KARVE MIDC

Feeder No / Name : 202 / 11 KV PARE FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1326	.1698	.0693	1.4083	1.3599	1.3283	.1478
2	.1311	.1612	.0693	1.4083	1.3279	1.2498	.1086
3	.1265	.1629	.0693	1.4746	1.3283	1.2498	.1075
4	.1311	.1478	.1052	1.4746	1.2803	1.1873	.1086
5	.1296	.1494	.1402	1.5424	1.1873	1.1111	.1063
6	.144	.1848	.1402	1.4922	1.4403	1.1111	.1387
7	.1475	.181	.1402	1.3916	1.4685	1.1111	.1715
8	.1006	.1677	.1509	.1372	.0754	.1341	.1638
9	1.989	2.0972		.1402	.1075	1.8461	1.6842
10	1.9662	2.1956	.128	.1372	.0972	1.8785	1.8233
11	1.8351	2.0972	.1715	.1387	.0709	1.6194	1.9334
12	1.656	1.9109	.1658	.1402	.0709	1.6842	
13	1.6872	1.8564	.1677		.1341	1.6604	
14		1.8564	.1696	.1372	.1341	1.7166	
15	1.7166	1.8138	.1326	.1387	.1372	1.7166	
16		1.6644	.1696	.1387	.1357	1.8107	
17	.1696	.1296	.1526	.1372	.128	.1158	
18	.1526	.1341	.1619	.1402	.128	.125	
19	.1791	.1372	.8987	.1433	.1372	.1715	
20	.1791	.1772	.1715	.1463	.1402	.1402	
21	.1772	.1772	.1696	.1402	.1387	.1772	
22	.181	.1448	1.6194	1.4746	1.3283	.181	
23	.1867	.1387	1.7436	1.4685	1.3283	.1433	
24	.1357	.1848	.1387	1.4575	1.5043	1.3283	.1311
Max	1.989	2.1956	1.7436	1.5424	1.5043	1.8785	1.9334
Min	.1006	.1296	.0693	.1372	.0709	.1158	.1063
Avg	.6025	.7517	.3063	.7134	.6329	1.0332	.5521

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244077 / 33/11 KV KARVE MIDC

Feeder No / Name : 203 / 11 KV WAZAR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1795	2.6825		.1132
2	2.0957	2.7161		.1132
3	2.0957	2.6322		.1132
4	1.9784	2.5987		.1132
5	1.9784	2.5484		.1132
6	1.8442	2.4813		.1132
7	2.0957	2.2801		.1132
8	.1132			.1132
9	.1132			
10	.1006		2.6825	
11			2.7664	
12			3.2693	
14			2.6155	
15			2.3807	
16			2.3472	
17			.1132	
18			.1132	
19			.1132	
20			.1132	
21			.1132	
22	2.7496		.1132	
23	2.8166		.1132	
24	2.2801	2.7328	2.7435	.1132
Max	2.8166	2.7328	3.2693	.1132
Min	.1006	2.2801	.1132	.1132
Avg	1.7262	2.5840	1.3998	.1132

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244078 / 33/11 KV GARDI

Feeder No / Name : 201 / Yashodhan Garment

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1524	.1132	.112	.1307	.1143	.112
2		.1524	.1143	.0953	.132	.1143	.112
3		.1334	.1143	.0953	.1143	.0953	.112
4		.1143	.0953	.0953	.1132	.0953	.112
5		.1143	.0953	.1143	.1307	.0953	.0943
6		.1143	.0943	.1143	.1132	.0953	.0914
7		.1143	.1109	.1143	.1132	.0953	.0924
8		.1143	.1132	.0953	.112	.1143	
9	.1143	.1334	.112	.1294	.1097	.1334	
10	.1334	.1524	.1307	.1307	.1267	.1448	
11	.1334	.1448	.1463	.132	.1524	.1267	
12	.1334	.1254	.1282	.1267	.1715	.1448	
13	.1524	.0867	.0739	.1294	.1524	.128	
14	.1334	.124	.0762	.128	.1524	.1267	
15	.1524	.1433	.1294	.128	.1524	.124	
16	.1524	.1109	.1254	.124	.1715	.1254	
17	.1334	.1463	.124	.128	.1905	.1254	
18	.1334	.1267	.1254	.1097	.1715	.1052	
19	.1334	.1463	.1267	.1294	.1524	.1433	
20	.1524	.1109	.1267	.1267	.1524	.1448	
21	.1524	.1294	.128	.1267	.0953	.1109	.0953
22	.1524	.1132	.1307	.1294	.1334	.128	.1143
23	.1524	.1132	.1307	.1307	.1143	.1294	.1143
24		.1524	.0943	.1109	.132	.1143	.128
Max	.1524	.1524	.1463	.132	.1905	.1448	.128
Min	.1143	.0867	.0739	.0953	.0953	.0953	.0914
Avg	.1410	.1279	.1150	.1190	.1371	.1198	.1071

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244078 / 33/11 KV GARDI

Feeder No / Name : 202 / Gardi Textile

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2286	.2263	.2096	.2054	.2477	.2263
2	.2427	.2286	.2218	.2096	.2012	.2286	.2263
3	.2402	.2096	.2241	.2096	.2033	.2286	.2263
4	.2402	.2096	.2241	.2096	.2075	.2286	.2263
5	.2218	.2286	.2054	.2096	.2241	.2286	.2263
6	.2054	.2286	.2218	.2096	.2075	.2286	.2452
7	.2286	.2286	.2195	.1886	.2096	.2286	.2263
8	.2477	.2286	.2241	.1905	.2054	.2286	.0777
9	.2096	.2286	.2241	.2263	.2075	.2286	.0274
10	.2286	.2477	.2402	.2241	.2058	.2614	.2477
11	.2286	.2743	.2378	.2218	.2286	.2427	.1524
12	.2286	.2241	.2218	.2427	.2096	.2241	.1334
13	.1905	.2241	.2054	.2058	.2286	.2427	
14	.2096	.2241	.2378	.2263	.2286	.2263	
15	.2286	.2402	.2587	.2241	.2286	.2427	
16	.2477	.2218	.2263	.2241	.2286	.2241	
17	.2477	.2378	.2427	.2172	.2477	.2241	
18	.2286	.2241	.2263	.2054	.2477	.2587	
19	.2286	.2534	.2263	.2263	.2477	.2614	
20	.2477	.2402	.2263	.2075	.2477	.2263	
21	.2477	.2218	.2263	.2263	.2286	.2263	
22	.2477	.2241	.1886	.2263	.2477	.2452	
23	.2477	.2263	.1886	.2241	.2477	.2263	
24	.2218	.2286	.2241	.2096	.2195	.2477	.2263
Max	.2477	.2743	.2587	.2427	.2477	.2614	.2477
Min	.1905	.2096	.1886	.1886	.2012	.2241	.0274
Avg	.2308	.2305	.2237	.2156	.2235	.2357	.1898

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244078 / 33/11 KV GARDI

Feeder No / Name : 203 / GHANWAD GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4938	.6859	.5975	.5544	.4973	.5716	.4525
2	.499	.6478	.5853	.5415	.4784	.5144	.4207
3	.5041	.6478	.567	.5415	.4755	.4954	.4207
4	.5175	.6097	.5731	.5487	.5068	.4954	.4344
5	.5487	.6859	.591	.5973	.5975	.5716	.4835
6	.6653	.724	.7602	.6767	.5658	.6668	.6268
7	.7811	.8002	.7373	.6626	.6733	.7049	.6379
8	.5906	.7621	.6661	.6516	.6613	.724	.6104
9	.6287	.7049	.7108	.6133	.663	.6859	.6203
10	.6478	.724	.7042	.5935	.7186	.5487	.6274
11	.6287	.6201	.6344	.5658	.6859	.5304	.5571
12	.6097	.6783	.6344	.6036	.5906	.5571	.583
13	.6097	.6415	.6874	.5548	.5906	.4862	
14	.4954	.6379	.6344	.6371	.5716	.4801	
15	.6097	.6485	.6001	.5765	.5716	.5144	
16	.6097	.6344	.6203	.5801	.5906	.4748	
17	.6287	.6415	.6203	.5765	.6097	.4694	
18	.724	.5935	.6443	.5197	.6668	.4372	
19	.8764	.8596	.7537	.6661	.743	.6068	
20	.9526	.8688	.8417	.7973	.8002	.7619	
21	.9145	.8688	.8145	.7164	.7621	.691	
22	.8573	.7577	.8048	.6767	.6668	.6036	
23	.8002	.6584	.6516	.6401	.6097	.5068	
24	.5121	.7049	.6099	.567	.5731	.5716	.4656
Max	.9526	.8688	.8417	.7973	.8002	.7619	.6379
Min	.4938	.5935	.567	.5197	.4755	.4372	.4207
Avg	.6544	.7003	.6685	.6108	.6196	.5696	.5339

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244102 / 33/11 KV pare sub-station

Feeder No / Name : 201 / 11 KV PARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3908	1.3527	.3547	1.3043	1.2574	1.2955	1.2955
2	1.3527	1.3336	.362	1.2955	1.2193	1.2574	1.2574
3	1.3527	1.3527	.3239	1.2574	1.2002	1.2384	1.2383
4	1.3146	1.3336	.3048	1.2383	1.2574	1.2193	1.2193
5	.8764	1.3908	.3048	1.2879	1.2574	1.2002	1.2269
6	1.3199	1.5432	.3734	1.0098	1.3819	1.3717	1.355
7	1.312	1.6575	.3921	1.5768	1.4621	1.5242	1.4305
8	1.1641	.1715	.3239	1.5242	1.4567	1.3908	1.3832
9	1.0279		.381	1.4289	1.3501	1.2738	.8192
10	1.1867	1.2624	.4572	1.2803	1.1822	1.0888	.9904
11	1.3868	1.3587	.4954	1.0631	1.3096	1.1079	1.145
12	.8764	1.3851		1.4173	1.281	1.126	1.2765
13		.9351		1.2613	1.0025	1.2593	1.2167
14		1.5585	.5335	.9853	1.3106	1.2403	.8764
15	1.7833	1.5394	.5335	1.3836	1.4248	1.165	.9145
16	1.7059	1.6328	.5335	1.4261	1.3717	1.1294	.8573
17	1.6106	1.4587	.5335	1.4451	1.3337	1.1149	.8954
18	1.5638	1.3248	.4382	1.4503	1.3146	1.105	.8573
19	1.679	1.3504	.5716	1.6457	1.4289	1.3336	.9526
20	2.2287	1.8911	.6287	1.3229	2.0386	1.8648	1.4289
21	2.21	1.9483	.5906	1.9414	1.9623	1.8141	1.4098
22	1.9624	1.7901	.5228	1.8517	1.7337	1.7009	1.3527
23	1.6766	1.5638	.4066	1.5242	1.5432	1.4971	1.4479
24	1.463	1.4099	.3921	1.3679	1.3337	1.3908	1.2765
Max	2.2287	1.9483	.6287	1.9414	2.0386	1.8648	1.4479
Min	.8764	.1715	.3048	.9853	1.0025	1.0888	.8192
Avg	1.4747	1.4150	.4435	1.3871	1.3922	1.3212	1.1718

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244102 / 33/11 KV pare sub-station

Feeder No / Name : 202 / 11 KV PARE AG FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0381	.503	.4938	.5155	.0381	.0381
2	.0572	.0381	.503	.4744	.506	.0381	.0381
3	.0381	.0381	.4694	.4744	.4877	.0381	.0381
4	.0381	.0381	.4862	.5401	.5535	.0381	.0381
5	.0381	.0381	.5304	.578	.5921	.0381	.0572
6	.0381	.0381	.7842		.4725	.0381	.0572
7	.0572	.0381	.9877	.953	.7468	.0381	.0762
8	.0572	.0572	.0381	.0381	.0381	.0381	.0572
9	.9842	1.0517	.0381	.0381	.0381	.9877	
10	.6401	.9722	.0381	.0381	.0381	.8905	1.0936
11	1.004	1.0031	.0572	.0381	.0381	.6958	1.0669
12	.8697	.9877	.0572	.0381	.0381	.6483	
13	.8749	1.0212	.0381	.0381	.0381	.9414	
14		1.0212	.0381	.0572	.0381	.9907	
15	.9842	1.0059	.0381	.0381	.0381	1.0517	
16		1.0364	.0572	.0572	.0381	1.0517	
17	.0381	.0762	.0572	.0572	.0572	.0572	
18	.0572	.0762	.0572	.0572	.0572	.0572	
19	.0572	.0572	.0572	.0572	.0381	.0572	
20	.0572	.0572	.0572	.0572	.0572	.0572	
21	.0572	.0572	.0572	.0572	.0381	.0572	
22	.0572	.5967	.6718	.6019	.0381	.0572	
23	.0572	.5636	.6642	.578	.0381	.0572	.0572
24	.0572	.0572	.5365	.5468	.5247	.0381	.0381
Max	1.004	1.0517	.9877	.953	.7468	1.0517	1.0936
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.2808	.4152	.2843	.2568	.2111	.3334	.2213

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244102 / 33/11 KV pare sub-station

Feeder No / Name : 203 / 11 KV GHOTI (BK) AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1143	.503	.5535	.4374	.1143	.1143
2	.1143	.1143	.4527	.4902	.4534	.1143	.0953
3	.1143	.0953	.4287	.4938	.4321	.0953	.0953
4	.1334	.1143	.4458	.4999	.4531	.0953	.0953
5	.1334	.1334	.4359	.6401	.506	.0953	.1143
6	.1524		.6062		.6249	.1715	.1524
7	.0953	.1524	.7682	.7716	.7432	.1715	.1715
8	.0953	.1524	.1143	.1334	.1334	.1524	.1524
9	.953	.9877	.1143	.1334	.1715	.9842	
10	.7562	.9568	.1143	.0953	.1334	.9014	.933
11	.8619	.9259	.0953	.0762	.1143	.9014	.8642
12	.9555	.9217	.0953		.1143	.9172	
13	.9555	.8905	.1334		.1143		
14		.8539	.1143		.0953	.8697	
15	.9014	.8381	.1334	.1143	.0953	.8539	
16		.8592	.1334		.0953	.9722	.5468
17	.0953	.1334	.1334	.1524	.1143	.7682	.1334
18	.1334	.1334	.1334	.1905	.1334	.1524	.1143
19	.1905	.2096	.4001	.1524	.1524	.1715	.2096
20	.2096	.2286	.2286	.1905	.2096	.2286	.2096
21	.2096	.2286	.2477	.1905	.2096	.2096	.2096
22	.1905	.547	.8764	.6167	.1715	.1905	.1715
23	.1524	.5365	.6718	.5155	.1334	.1334	.1334
24	.1334	.1334	.5197	.5921	.4586	.1334	.1143
Max	.9555	.9877	.8764	.7716	.7432	.9842	.933
Min	.0953	.0953	.0953	.0762	.0953	.0953	.0953
Avg	.3486	.4461	.3292	.3475	.2625	.4086	.2437

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244123 / 33/11 kv 5MVA VITA NEW S/STN

Feeder No / Name : 201 / 11 KV Harewadi URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5375	.4908	.5959	.4508	.4681	.4207	.4801
2	.5258	.4784	.5959	.4382	.4784	.4207	.4854
3	.4961	.4656	.5959	.4252	.4656	.3988	.4557
4	.5138	.4784	.5784	.4252	.4557	.037	.4508
5	.5375	.4908	.5609	.4382	.463	.3988	.463
6	.5434	.5028	.5784	.4382	.4854	.3988	.4681
7	.6036	.5316	.6203	.5935	.503	.4049	.5079
8	.6081	.5535		.5535	.5967	.4374	.5344
9	.6081	.6539	.6009	.4915	.6081	.502	.547
10	.6371	.6443	.7291	.5636	.6299	.547	.6613
11	.6952		.7042	.7373	.7291	.663	.6371
12		.6516	.6687	.6859	.6299	.6299	
13		.4801	.5087	.6464	.5407	.6133	
14		.6516	.5868	.6613	.6796	.7209	
15	.663	.6274	.6539	.703	.663	.6706	
16	.7459	.7969	.6443	.6796	.6464	.7045	
17	.7209	.7625	.5533	.788	.6299	.2241	
18	.6962	.6962	.583	.7362	.6299	.6562	
19	.6962	.6539	.663	.7377	.5407	.6299	
20	.6464	.703	.6274	.6274	.3688	.6371	
21	.6464	.6783	.5636	.583	.4557	.5935	
22	.5959	.6733	.5201	.5895	.4607	.5959	
23	.5609	.6733	.5083	.5609	.4784	.5375	
24	.5316	.4908	.5959	.4733	.4854	.4382	.4973
Max	.7459	.7969	.7291	.788	.7291	.7209	.6613
Min	.4961	.4656	.5083	.4252	.3688	.037	.4508
Avg	.6100	.6013	.6016	.5845	.5455	.5117	.5157

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-17 and 04-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 248001 / 220/33 Vita Karve

Feeder No / Name : 401 / 33KV VITA INCOMING

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	27.7092	29.9726	28.4637	27.8464	29.5611	***
2	26.5432	29.4925	28.0522	28.5323	29.1496	29.4925
3	26.3375	29.081	27.8464	27.9836	28.8066	28.738
4	25.7202	28.6009	27.2291	27.2291	28.1208	28.1208
5	24.9657	29.081	27.3663	26.749	28.2579	27.6406
6	27.7092	***	29.1496	27.0919	***	29.6983
7	***	***	***	***	***	***
8	23.7312	24.4856	25.583	24.2113	24.8972	21.5364
9	***	***	***	***	***	26.3375
10	***	***	***	***	***	25.3087
11	***	***	***	***	***	25.7888
12	***	***	***	***	***	25.583
13	29.4925	***	***	***	***	11.5226
14	19.7531	***	***	***	***	11.0425
15	***	***	***	***	***	11.1797
16	***	***	***	***	***	24.76
17	27.7778	28.6009	29.081	29.9726	27.0234	17.6955
18	27.7778	28.3265	29.3553	28.6694	26.2003	16.3923
19	27.5035	28.8752	28.9438	26.8176	27.9836	18.3814
20	29.3553	***	***	***	***	21.5364
21	27.1605	28.0522	27.915	27.0919	28.8752	21.6736
22	***	***	***	***	***	***
23	***	***	***	***	***	***
24	***	***	***	***	***	29.3553
Max	40.2607	41.0151	50.0001	50.0687	39.6434	33.059
Min	19.7531	24.4856	25.583	24.2113	24.8972	11.0425
Avg	30.2069	32.8075	34.7223	34.6080	32.5018	24.0884