

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054007 / 33/11KV S/S AMBAJOGAI

Feeder No / Name : 201 / 11 KV HOSPITAL FEEDER
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3086	.3086	.3086	.3086		.3086
2		.3086	.3086	.3086	.3086		.2743
3		.3086	.3086	.3086	.3086		.2401
4		.3086	.3429	.3429	.3429		.2401
5		.3258	.3601	.3601	.3429		.2401
6		.3258	.3601	.3601	.3429		.2743
7	.3086	.3772	.3772	.3772	.3772		.3429
8	.2915	.4115	.3772	.3772	.3772	.3429	.3772
9	.3601	.4115					.3429
10	.3601	.4115	.4458		.4458	.4458	.3086
11	.3429	.3944					
12	.3429	.3944		.4115	.3772	.3944	.3772
13	.3086	.4115	.4287				
14	.3086	.3258		.3258	.4115	.4115	.2572
15	.2743	.3086					
16		.3429	.3944	.3429		.3601	.2743
17	.2915	.3258	.3601	.3258		.3429	.2743
18	.2572	.3429	.3772	.3258		.3258	.2743
19	.3258	.3601	.3772	.3601		.3258	.3086
20	.3429	.3429	.4115	.3429		.3601	.3429
21	.3429	.3772	.3944	.3772		.3429	.3429
22	.3258	.3772	.3772	.3601	.4115	.3429	
24	.3258	.3429	.3086	.3086	.3086	.3772	.3086
Max	.3601	.4115	.4458	.4115	.4458	.4458	.3772
Min	.2572	.3086	.3086	.3086	.3086	.3258	.2401
Avg	.3193	.3541	.3677	.3458	.3587	.3644	.3005

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054007 / 33/11KV S/S AMBAJOGAI

Feeder No / Name : 202 / 11 KV YOGESHWARI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0631	1.0631	1.0631	1.0631		1.0974
2		1.0631	1.0631	1.0631	1.0631		1.0974
3		1.0631	1.0631	1.0631	1.0631		1.0974
4		1.0631	1.0974	1.0974	1.0974		1.0974
5		1.0974	1.0974	1.1317	1.0974		1.166
6		1.1317	1.0974	1.1317	1.0974		1.166
7	1.166	1.0631	1.1317	1.0974	1.1317		1.166
8	1.0288	1.0974	1.1317	1.0974	1.0974	1.0974	1.2346
9	.9259	.9945					1.0974
10	.9259	.9945	1.0288		1.0974	1.0974	.8916
11	.8573	1.0288					
12	1.0288	1.0288	1.0974	1.0974	1.0288	1.0288	1.166
13	1.0974	1.0974					
14	1.0974	1.0631	1.0974	1.166	1.166	1.0974	1.0288
15	1.1317	1.0631					
16		1.0974	1.1145	1.166	1.0288	1.2346	1.0974
17	1.0974	1.0288	1.166	1.0974	1.0974	1.2346	1.0288
18	1.0288	1.0974	1.2003	1.166	1.2003	1.2346	1.0288
19	1.2689	1.2003	1.2689	1.2003	1.3717	1.3717	
20	1.3717	1.3375	1.3717	1.3375	1.4403	1.3717	1.2689
21	1.3717	1.3032	1.3717	1.3717	1.3717	1.3717	1.166
22	1.3032	1.2346	1.3032	1.3375	1.3717	1.3717	
24	1.166	1.2346	1.0631	1.0974	1.0631	1.0974	1.0974
Max	1.3717	1.3375	1.3717	1.3717	1.4403	1.3717	1.2689
Min	.8573	.9945	1.0288	1.0631	1.0288	1.0288	.8916
Avg	1.1167	1.1063	1.1488	1.1546	1.1551	1.2174	1.1107

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054007 / 33/11KV S/S AMBAJOGAI

Feeder No / Name : 204 / 11 KV LOKHANDI FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7316		.7316			
2		.7316		.7316	.4877		.4877
3		.7316	.6401	.7316	.4877		.6097
4		.7621	.7011	.7316	.7316		.6097
5		.7926	.7011	.7621	.7621		.6401
6		.7926	.7011	.7926	.7926		.7316
7	.8535	.823	.8535	.7926	.823		.823
8	.8535	.823	.4877	1.8861	.823	.823	.823
9		.823					.6097
21			.061				
24	.3658	.4877		.3658			
Max	.8535	.823	.8535	1.8861	.823	.823	.823
Min	.3658	.4877	.061	.3658	.4877	.823	.4877
Avg	.6909	.7499	.5922	.8362	.7011	.823	.6668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054007 / 33/11KV S/S AMBAJOGAI

Feeder No / Name : 205 / 11 KV MOREWADI-SAIGAON-

SHEDDABLE URBAN

FEEDER Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5775	1.5432	1.6118	1.6118		1.5775
2		1.5775	1.5432	1.6118	1.6118		1.5775
3		1.6118	1.5432	1.6118	1.6118		1.5775
4		1.6118	1.5432	1.6461	1.6461		1.5775
5		1.6804	1.5775	1.6804	1.6804		1.6804
6		1.7147	1.6461	1.8004	1.7147		1.7147
7	1.5089	1.749	1.749	1.8861	1.8861		1.8861
8	1.5775	1.8861	1.8861		1.8004	1.8519	1.8519
9	1.5775	1.6461					1.7147
10	1.5775	1.6461	1.7833		1.7147	1.7833	1.7147
11	1.5775	1.7147					
12	1.5089	1.5775	1.6461	1.5775	1.8519	1.6461	1.8519
13	1.5089	1.5775					
14	1.5089	1.5775	1.6461	1.5089	1.7833	1.5775	1.5089
15	1.5775	1.5775					
16		1.6461	1.7147	1.5775	1.7147	1.6461	1.6461
17	1.5432	1.5432	2.8121	1.6461	1.6461	1.6461	1.6461
18	1.7147	1.6461	1.7147	1.5432	1.8004	1.9204	1.6461
19	1.8519	1.8861	1.8861	1.8861	1.9204	1.989	1.7147
20	1.9204	1.8861	1.9204	1.8861	1.9204	1.989	1.8519
21	1.8861	1.8519	1.8861	1.8861	1.8861	1.9204	1.7147
22	1.8519	1.7147	1.7147	1.7147	1.7147	1.7833	
24	1.7147	1.5775	1.5432	1.6118	1.6118	1.5775	1.5775
Max	1.9204	1.8861	2.8121	1.8861	1.9204	1.989	1.8861
Min	1.5089	1.5432	1.5432	1.5089	1.6118	1.5775	1.5089
Avg	1.6504	1.6729	1.7526	1.6874	1.7436	1.7776	1.6858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054007 / 33/11KV S/S AMBAJOGAI

Feeder No / Name : 206 / 11 KV WAGHALE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	1.0455	1.0417	.8253		1.4616	1.076	.7331
11	2.6635	2.7763	1.4723	1.3336	1.7078	1.608	1.6339
12	2.6909	2.8982	2.6566	2.6521	3.1344	2.9896	2.9774
13	2.7374	2.8365	1.4556	1.624	1.7253	1.7924	1.7406
14	1.5569	2.5362	2.4303	2.7588	2.7656	2.6924	2.787
15	1.6286	2.4333	1.4327	1.6293	1.4441	1.4685	1.4899
16	1.5889	2.3106	2.665	.4801	2.1033	1.8991	2.5743
17	2.7816	2.7191	2.1613		2.3837	2.5286	3.0956
18	1.6575	1.6324	.7042	.8429	1.515	1.5371	1.7589
Max	2.7816	2.8982	2.665	2.7588	3.1344	2.9896	3.0956
Min	1.0455	1.0417	.7042	.4801	1.4441	1.076	.7331
Avg	2.0390	2.3538	1.7559	1.6173	2.0268	1.9546	2.0879

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054007 / 33/11KV S/S AMBAJOGAI

Feeder No / Name : 207 / 11 KV SHIVAJI CHOWK FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7545	.7545	.7202	.8573		.8573
2		.7545	.7202	.7202	.823		.823
3		.7545	.7202	.7202	.823		.7202
4		.7888	.7202	.7888	.823		.7202
5		.7888	.7545	.7888	.823		.7202
6		.7888	.7545	.7888	.8573		.7202
7	.7545	.823	.8916	.823	.823		.9602
8	.823	.8916	.9602	.823	.823	.7888	.9945
9	.7545	.823					.8916
10	.7545	.823	.9602		.8916	.8916	.823
11	.823	.9602					
12	.8916	1.0288	1.0288	.8916	1.0288	.8916	.9602
13	.8916	1.0288					
14	.8916	.9602	1.0288	.8916	1.0288	.9602	.8916
15	.8916	.9602					
16		.8916	.9602	.823	1.0288	.9602	.823
17	.8916	.9602	.9602	.8916	1.0288	.9602	.7545
18	.8573	.9602	1.0974	.9602	1.0974	.9602	.823
19	1.166	1.0288	1.3032	1.0974	1.2346	1.166	.9602
20	1.2003	1.3375	1.3375	1.3032	1.2003	1.0974	1.0974
21	1.166	1.2003	1.3032	1.0288	1.0974	1.0288	1.0288
22	1.0288	1.166	1.2003	1.0288	1.0288	1.0288	
24	.7545	.7545	.823	.8916	.8916	.8916	.9259
Max	1.2003	1.3375	1.3375	1.3032	1.2346	1.166	1.0974
Min	.7545	.7545	.7202	.7202	.823	.7888	.7202
Avg	.9088	.9229	.9620	.8878	.9584	.9688	.8682

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054007 / 33/11KV S/S AMBAJOGAI

Feeder No / Name : 208 / 11 KV WATER WORKS FEEDER NON SHEDDABLE WATER SUPPLY AND
 Feeder KV- 11 / OUTGOING UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.061	.061	.061	.061		
2			.061	.061	.061		
3			.061	.061			
4			.061		.061		.061
5			.061		.061		.061
6			.061		.061		.061
7		.0533	.061		.061		.061
8			.061	.061	.061	.061	.061
9							.061
10			.061		.061	.061	.061
11	.061	.061					
12	.061	.061	.061	.061	.061	.061	.061
13	.061	.061					
14	.061	.061	.061	.061	.061	.061	.061
15	.061	.061					
16		.061	.061	.061	.061		.061
17	.061	.061	.0762	.061	.061		.061
18	.0762	.061	.0762	.061	.061	.061	.0762
19	.0762	.061	.0762	.061	.061	.061	.0762
20	.0762	.061	.061	.061	.061	.061	.0762
21	.061	.061	.0762	.061	.0762	.061	.061
22	.0762	.061	.061	.061	.061	.061	
24	.061	.061			.061		.061
Max	.0762	.061	.0762	.061	.0762	.061	.0762
Min	.061	.0533	.061	.061	.061	.061	.061
Avg	.0661	.0605	.0644	.061	.0618	.061	.0639

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054007 / 33/11KV S/S AMBAJOGAI

Feeder No / Name : 209 / 11KV GFSS JOGAIWADI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1905	.1143	.1524	.1143		.1524
2		.1905	.1524	.1524	.1143		.1524
3		.1905	.1524	.1905	.1524		.1524
4		.1905	.1905	.1905	.1524		.1143
5		.1905	.2286	.2286	.1905		.1143
6		.1905	.2286	.2286	.1905		.1524
7	.1524	.2286	.2286	.2286	.2286		.2286
8	.1524	.2286	.2286	.2286	.2286	.1905	.2286
9	.1143	.1524					.2286
10	.1524	.1524	.2286		.1905	.1524	.1524
11	.1143	.1524					
12	.1905	.1524	.1905	.1905	.0762	.2286	.1524
13	.1905	.1524					
14	.1905	.1524	.1524	.1524	.1524	.2286	.2286
15	.1905	.1524					
16		.1524	.1905	.1524	.1524	.2286	.2286
17	.2096	.2096	.2286	.1905	.2286	.1905	.2096
18	.1715	.2286	.2286	.1905	.2286	.1524	.1905
19	.1524	.2286	.2286	.1524	.1334	.1905	.1905
20	.2286	.1524	.2286	.1143	.1334	.1905	.1143
21	.2286	.1524	.1905	.1143	.1143	.1905	
22	.1524	.1143	.1524	.1143	.1143	.1905	
24		.1905	.1143	.1524	.1143	.1143	.1905
Max	.2286	.2286	.2286	.2286	.2286	.2286	.2286
Min	.1143	.1143	.1143	.1143	.0762	.1143	.1143
Avg	.1727	.1781	.1925	.1736	.1584	.1873	.1767

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054014 / 33 KV BARDAPUR

Feeder No / Name : 201 / 11 KV MORWAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1522	.5318	.1578	.4472		.1486	.1871
2	.716	.5929	.184		.3705	.332	.4572
3	1.1388	.6722	.2893	.2032	.4927	.4134	.5327
4	.6013	.7325	.335	.1024	.5768	.5578	.6454
5	.8316	.8774	.3029	.2239	.6405	.5988	
6	.1067	.9389	.2741	.8882	.642	.6173	1.1389
7	.7006	.9898	.2614	.184	.7816	.767	1.3443
8	.7489	1.0002	.2467	.2716	.5772	.8295	.7999
9	.8889			.8978	1.0494		.8169
10	.1439	.1495	.0941	.1124	.1427	.1056	.1422
11	.1135		.1189	.1139	.1111	.1124	.1387
12	.1129		.1183	.094	.1478	.1402	.1314
13	.1134	.1485	.1135	.0939	.1483	.1492	.1306
14	.1141		.0966	.1117		.1436	.1323
15	.1319		.1084	.1302	.1475	.1404	.1489
16	.1326	.1485	.0202	.1299	.1694	.1041	.1125
17	.1434	.1492	.0187	.1084		.111	.1104
18	.1445		.1696	.1279	.1507	.1722	.1468
19	.222		.2048	.1485	.1512		.1734
20	.225		.2254	.2231	.208	.242	.2181
21	.2247		.0281	.2254	.1994	.2236	.2603
22	.2273	.2263		.1886	.1962	.2241	.2245
23	.2218	.2268	.0734				.2261
24	.4086	.3487	.1895		.1898	.1875	.1884
Max	1.1388	1.0002	.335	.8978	1.0494	.8295	1.3443
Min	.1067	.1485	.0187	.0939	.1111	.1041	.1104
Avg	.3569	.5155	.1650	.2393	.3546	.3010	.3655

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054014 / 33 KV BARDAPUR

Feeder No / Name : 202 / 11 KV BARDAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2538	.5975	.407	.563	.3909		.4829
2	.4431	.629	.5079		.4319	.2833	.3702
3	.0907	.6447	.5184	.3213	.4769	.3521	.4176
4	.5226	.6588	.5182	.4952	.5475	.4444	.4159
5	.6834	.7154	.5801	.28	.6283	.556	
6	.5457	.7625	.6219	.4545	.7087	.6036	.5451
7	.5083	.7856	.6783	.7866	.6413	.6994	.5496
8	.9798	.7901	.6465	.9848	.7673	.8571	.8999
9	.9887		.6196	.3296	.6036		.924
10	.4252	.3839		.4006	.3001	.3676	.4118
11	.4054	.4372		.4122	.4615	.4086	.3206
12	.4129			.3874	.4682	.3858	.4342
13	.4236	.3905	.203	.3539	.4774	.4332	.4369
14	.4161		.4822	.4182		.422	.4668
15	.4022		.3185	.3932	.7138	.4172	.431
16	.398		.4726		.398	.3788	.4188
17	.4693	.3184	.1969		.4065	.4871	.4561
18	.5121	.5227	.1762	.3406	.569	.4865	.4698
19	.6405		.5591	.6859	.5416		.6409
20	.6639		.6941	.5918	.4912	.5918	.7248
21	.6027		.3243	.5213	.439	.674	.6328
22	.6508	.5505		.5197	.4024	.6027	.6153
23	.6588	.522	.078				.6249
24		.4522	.0484		.4134	.4184	.5155
Max	.9887	.7901	.6941	.9848	.7673	.8571	.924
Min	.0907	.3184	.0484	.28	.3001	.2833	.3206
Avg	.5260	.5726	.4326	.4863	.5127	.4935	.5307

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054014 / 33 KV BARDAPUR

Feeder No / Name : 203 / 11 KV JAWALGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1664	.12	.1029	.0886	.1164	.0956	.0814
2	.1024	.1079	.107	.1923	.1171	.1131	.0963
3	.0373	.1161	.1439		.1331		.0988
4	.2635	.1201	.1317	.1296	.149	.0781	.1179
5	.2881	.1566	.1318	.0328	.1656	.0873	.1329
6	.2853	.1773	.1635	.0979	.1824	.0992	.1612
7	.221	.1557	.1379	.2625	.1349	.1085	.1597
8	.3392	.107		.2864	.1265	.118	.1128
9	.1262			.1824	.1832	.0796	.1174
10	.6017	.6244	.4854	.8383	.5068	.3818	.4814
11	.9261		1.0311	1.0883	.5326	.5441	.7868
12	.8619			.551	.4805	.5954	.5943
13	.8392	.8554	.6374	.7801	.4419	.6795	.4369
14	.8194		.7289	.3905		.6592	.6136
15	.8992		.8989	.57		.5756	.6094
16	.9006		.6301	.6145		.5463	.7997
17	1.0242	.9328	.4729	1.0828		.4243	.9588
18	.0835	.0244	.1299	.0678		.0348	.0823
19	.1073		.3307	.2858	.1627		.2536
20	.1467		.2088	.1166	.2233	.1326	.2794
21	.139		.0991	.1254	.1749	.1113	.1345
22	.1337	.1119		.1228	.1445	.0994	.1349
23	.1223	.1146	.219				.1463
24		.125	.1934		.1131	.0928	.092
Max	1.0242	.9328	1.0311	1.0883	.5326	.6795	.9588
Min	.0373	.0244	.0991	.0328	.1131	.0348	.0814
Avg	.4102	.2566	.3492	.3765	.2271	.2694	.3118

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054020 / 33 KV GHATNANDUR

Feeder No / Name : 201 / 11 KV POOS

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9955					
2	1.4632	.9955	1.6461	1.307	1.267	1.2536	1.5775
4	1.922	1.386	2.0538	1.643	1.8671	1.386	1.8823
6	2.2405	2.0538	2.2405	2.0538	2.2405	2.0165	2.0538
7	2.2405			1.643		2.2634	
8					1.9418		
9		1.6804		1.4937			
10	1.829	2.0485	2.5911	1.8747	2.0241		2.2138
11		2.0005					
12	2.0557	2.0485	2.5911	1.4901			2.2771
14	1.9997	1.5935	2.5911	1.8362	2.1872		2.0833
16	1.9753	1.829	2.5301		2.4006	2.2653	2.0833
17			2.5301		2.5911	2.2653	
18	1.4083	1.4632	1.4632	2.1948	1.4175	1.9281	1.3003
19		1.7375		1.8427		2.0485	
20	2.0576			2.1948	2.1948	2.1216	1.9753
21			1.6461	1.7194	1.6289	1.7194	1.8099
22	1.4327		1.6289			1.5947	
23	1.2403		1.448			1.387	
24	1.0974		1.0745	1.267	1.1096	1.2136	1.1145
Max	2.2405	2.0538	2.5911	2.1948	2.5911	2.2653	2.2771
Min	1.0974	.9955	1.0745	1.267	1.1096	1.2136	1.1145
Avg	1.7663	1.6527	2.0027	1.7354	1.9059	1.8048	1.8519

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054020 / 33 KV GHATNANDUR

Feeder No / Name : 202 / 11 KV GHATNANDUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4858					
2	.5967	.4858	.8421	.3772	.5258	.4801	.9114
4	.6706	.5426	.7682	.4359	.6661	.4801	.7796
6	.6783	.6068	.7956	.503	.7362	.631	.7087
7	.6859					.631	
8	.7287	.6859	.8139		.7122		.663
9	.5898			.6241			
10	1.0745	1.1765	.8688	.7122	1.086		1.1641
12	.9955	1.086	.724	.583	1.1104		.8779
14	.905	1.0136	.724	.4752	1.1765		1.1584
16	1.086	1.086	1.0277		1.1765	1.1765	1.086
17				.9907	1.1765	1.2536	
18	1.2308	1.1641		1.2536	1.1706	1.4327	1.0974
19		1.448		1.5223		1.6118	
20	1.5203			1.5223	1.6095	1.7909	1.576
21				1.5947	1.5384	1.4327	1.4327
22	1.3432					1.4175	
23	1.2536					1.3146	
24	.4973		1.1765		1.2048	1.2178	1.2269
Max	1.5203	1.448	1.1765	1.5947	1.6095	1.7909	1.576
Min	.4973	.4858	.724	.3772	.5258	.4801	.663
Avg	.9237	.8892	.8601	.8829	1.0684	1.1439	1.0568

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054020 / 33 KV GHATNANDUR

Feeder No / Name : 203 / 11 KV HATOLA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7011					
2	1.1523	.7011	.8413	1.1736	.9602	.9602	1.1385
4	1.4662	1.0974	1.6461	1.4662	1.1843	1.1279	1.5623
6	1.6137	1.4937	1.8519	1.7833	1.8747	1.6049	1.7185
7	1.6556	1.4937				1.8747	
8	1.6556		1.8747	1.8061	1.8519		1.8976
9	1.6347	.0158		1.5851			
10	.6447		.7392	.6874	.6653		.6335
12	.543		.7392	.5792	.6268		.4298
13					.7125		
14	.5373	.9389	.7392	.4784			.4382
16	.6447		.7682	.5765	.6516	.6447	.5373
17			.823	.5243	.724	.7087	
18	.8413	1.829	.8779	.724	.7865	.905	.7459
19		1.0745		1.0631		1.0059	
20	1.2209			1.134	1.1218	1.0974	1.2536
21			.8859	.9326	.9496	.9496	.9326
22	.8383		.8478			.8192	
23	.7459		.8478			.759	
24	.9469		.7716	.7773	.7125	.6478	.7116
Max	1.6556	1.829	1.8747	1.8061	1.8747	1.8747	1.8976
Min	.5373	.0158	.7392	.4784	.6268	.6447	.4298
Avg	1.0761	1.0384	1.0181	1.0194	.9863	1.0081	1

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054031 / 33 KV DHANORA S/S

Feeder No / Name : 201 / 11 KV RADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	.5967	.6478		.5535	.663	.5281	.5335
11	.779	.8619	.8488	.8583	1.0277	.9221	.852
12	.8029	.8383	.8768	.7316	.9945	.8886	.7865
13	.7537	.7712	.6562	.5201	.8951	.759	.7202
14	.7042	.8383	.7202	.6097	.8288	.679	
15	.7522	.8383	.7968	.6718	.8097	.759	.4784
16	.7748	.8383			.8097	.8162	.7432
17	.8482	.9054	.6316		.9503	.8482	.8907
Max	.8482	.9054	.8768	.8583	1.0277	.9221	.8907
Min	.5967	.6478	.6316	.5201	.663	.5281	.4784
Avg	.7515	.8174	.7551	.6575	.8724	.7750	.7149

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054031 / 33 KV DHANORA S/S

Feeder No / Name : 202 / 11 KV AKOLA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2858	.3429	.2477	.2286		.3048
2	.3239	.2667	.3429	.2858	.2667		.3239
3	.362	.2858	.3429	.3239	.3239		.3429
10	.9667	.6325		.9922	.5761	1.3748	1.2186
11	1.3592	1.1843	1.174	1.1984	1.3123	1.3748	1.1683
12	1.3923	1.1523	1.2186	1.2492	1.2163	1.3763	1.1523
13	1.3599	1.1203	1.2003	1.2803	1.1523	1.3916	1.0753
14	1.3283	1.0562	1.1843	1.2334	1.1523	1.2809	
15	1.3603	1.1203	1.1363	1.1873	1.1523	1.2651	.9259
16	1.3927	1.1523			1.2803	1.2809	1.2018
17	1.2483	1.2803	1.1591		1.3123	1.3283	1.3441
18	.2477	.4191	.3429	.3239		.2987	.2477
19	.4382	.4954	.4382	.5335		.4191	.4763
20	.5906	.5335	.5716	.5906		.6668	.6097
21	.5525	.4954	.4954	.5525		.4763	.5144
22	.4382	.4191	.4382	.4001		.4191	
23	.3429	.381	.381	.362		.3429	.381
24	.2667	.2477	.381	.3239	.3239		.3239
Max	1.3927	1.2803	1.2186	1.2803	1.3123	1.3916	1.3441
Min	.2477	.2477	.3429	.2477	.2286	.2987	.2477
Avg	.7910	.696	.6969	.6928	.8581	.9497	.7257

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054031 / 33 KV DHANORA S/S

Feeder No / Name : 203 / 11 KV MAMDAPUR PATODA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8131	.8871	.2641	.8215	.8402		.7922
2	.8501	.8775	.2641	.8402	.8589		.7922
3	.961	.8962	.2641	.8775	.8775		.9054
10	1.4754	1.1797		1.3272	1.4918	1.5074	1.4083
11	1.5581	2.0119		1.757	1.9448	1.9559	1.6741
12	1.3599	1.9448		1.6604	2.0119	1.9393	1.8564
13	1.5581	1.9448	1.6004	1.6248	1.9448	1.8785	1.7204
14	1.4548	1.8778	1.7604	1.4883	1.9448	1.2955	
15	1.5203	1.8778	1.8138	1.3765	2.0119	1.4746	1.4575
16	1.587	1.9784			2.079	1.5074	1.6221
17	1.5415	2.0119	1.6644		2.079	1.5402	1.8067
18	.6268	1.2449	.7499	.8048		.6626	.6878
19	1.0242		1.0349	1.0719		1.0082	.9979
20	1.4377		1.4937	1.386		1.3443	1.4563
21	1.2323	.2641	1.2567	1.2567		1.251	1.1763
22	1.1016	.2641	1.0349	1.0903		.9709	
23	.9149	.2641	.8686	.8871		.8962	.8775
24	.7762	.8402	.2641	.8029	.8215		.811
Max	1.587	2.0119	1.8138	1.757	2.079	1.9559	1.8564
Min	.6268	.2641	.2641	.8029	.8215	.6626	.6878
Avg	1.2107	1.2728	1.0239	1.1921	1.5755	1.3737	1.2526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054045 / 33/11 KV UJANI

Feeder No / Name : 201 / 11 KV DHARMAPURI FEEDER

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	02-MAY-17
HR	Load (MW)
9	.5357
Max	.5357
Min	.5357
Avg	.5357

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054045 / 33/11 KV UJANI

Feeder No / Name : 204 / 11 KV GFSS DHARMAPURI
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAY-17	04-MAY-17
HR	Load (MW)	Load (MW)
13	.5126	.4194
15	.5398	
18	.6734	
23	.4225	
Max	.6734	.4194
Min	.4225	.4194
Avg	.5371	.4194

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054046 / 33 KV APEGAON

Feeder No / Name : 201 / 11 KV APEGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0743	.0742	.0742	.0743	.0742	.0743	
2	.0743	.0742		.0743	.0742	.0743	.0742
3	.0743	.0742	.0742	.0743	.0742	.0743	
4	.0743	.0742		.0743	.0742	.0743	.0742
5	.0743	.0742		.0743	.0742	.0743	
6	.0743	.0742	.0742	.0743	.0742	.0743	.0742
7		.0742		.0743	.0742	.0743	
8	.0743	.0742		.0743	.0743	.0743	.0742
9	.0743	.0742	.0742	.0743	.0743	.0743	.0742
10	.9288	.7794	.7423	.9278	.8359	.8359	
11	1.5232	1.2963	.9288	1.5216	.9288	1.6701	
12	1.5975	1.2963	1.3003	1.4845	1.3003	1.6718	.5567
13		1.4815	1.3003	1.3732	1.3932	1.6718	.6309
14	1.3746	1.4845	1.3932	1.4103	1.3932	1.299	1.0021
15	1.5975	1.5216	1.1145	1.299	1.4861	1.3003	1.0763
16	1.4861	1.4845	.9288		1.3932	1.299	1.1134
17	1.6347	1.5216	1.0217		1.3003	1.299	1.1505
18	.0743	.0742	.0743	.0742	.0743	.0928	.0742
19	.0743		.0743		.0743	.0742	.0742
20	.0742		.0743	.0742	.0743	.0742	.0742
21	.0742		.0743	.0742	.0743	.0742	.0742
22	.0742		.0743	.0742	.0743	.0742	.0742
23	.0742	.0742	.0743	.0742	.0743	.0742	.0742
24	.0743	.0742	.0741	.0743	.0742	.0743	.0742
Max	1.6347	1.5216	1.3932	1.5216	1.4861	1.6718	1.1505
Min	.0742	.0742	.0741	.0742	.0742	.0742	.0742
Avg	.5117	.5878	.5025	.4348	.4675	.5106	.3567

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054046 / 33 KV APEGAON

Feeder No / Name : 202 / 11 KV TATBORGAEON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1152			.0603	.06	
2		1.2358			.74	.7497	1.0509
3		1.3563	1.0496		.8741	1.0496	1.0509
4		1.5372	1.4994	1.0469	1.1152	1.3495	1.0509
5	1.4956	1.6577	1.4994	1.4956	1.2358	1.4244	1.5013
6	1.7947	1.9979	1.9492	1.7947	1.8386	1.4994	2.1018
7		1.8499	2.549	2.0938	2.0991	1.7993	
8		1.5673	2.549	2.1686	2.1741	2.399	2.5522
9		1.2056	2.549	2.2434	2.1741	2.399	2.5522
10		.0603			.06	.06	.0601
11		.06			.06		.0604
12					.06	.06	.0604
13					.06		.0604
14		.06			.06		.0604
15					.06		.0604
16					.06	.06	.0604
17					.06		.0604
18	.0603	.06		.0603	.06	.075	.0604
19	.0603			.0603	.06	.06	.0604
20	.0603			.0603	.06	.06	.0604
21	.0603			.0603	.06	.06	.0604
22	.0603			.0603	.06	.06	.0604
23	1.0549	.06		.0603	.06	.0601	.0604
24	.673	1.0549		.673	.0603	.06	.0601
Max	1.7947	1.9979	2.549	2.2434	2.1741	2.399	2.5522
Min	.0603	.06	1.0496	.0603	.06	.06	.0601
Avg	.5911	.9919	1.9492	.9137	.5505	.7024	.5803

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054046 / 33 KV APEGAON

Feeder No / Name : 203 / 11KV GFSS APEGAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1553	.1553	.1558	.1553	.1553	.1553	.1558
2	.1553	.1553	.1499	.1553	.1553	.1553	.1558
3	.1553	.1553	.1499	.1553	.1553	.1553	.1558
4		.1863	.2182	.1863	.1553	.1863	.1558
5	.2174	.2484		.2329	.2174	.2174	.2182
6	.2174	.2795	.2494	.2329	.2795	.2174	.2494
7		.3105	.2494	.2484	.3105	.2329	.2494
8	.2329	.3105	.2494	.2484	.2795	.2329	
9	.1863	.2795	.2494	.2174	.2174	.2174	.187
10	.1553	.2484	.2182	.1553	.1863	.1863	.1558
11	.1553	.1555	.1553	.1553	.1553	.1555	.1553
12	.1553	.1244	.1242	.1553	.1242	.12	.1553
13	.1553	.0935	.0932	.1242	.1242	.0751	.1553
14	.1553	.0933	.0932	.1242	.0932	.0777	.1553
15	.1553	.0933	.0776	.1553	.0932	.0777	.1242
16	.1553		.1553	.1553	.1553	.12	.1553
17	.1553		.1553	.1553	.1553	.1244	.1553
18	.1863	.1247	.1863	.1553	.1553	.1555	.1553
19	.1863		.1863	.1553	.1863	.2182	.1863
20	.1553		.2174	.1863	.1863	.2182	.1863
21	.1553		.2174	.1863	.2174	.187	.1553
22	.1553		.1863	.1553	.2174	.1558	.1553
23	.1553	.1555	.1553	.1553	.1863	.1558	.1553
24	.1553	.1553	.1558	.1553	.1553	.1553	.1558
Max	.2329	.3105	.2494	.2484	.3105	.2329	.2494
Min	.1553	.0933	.0776	.1242	.0932	.0751	.1242
Avg	.1687	.1847	.1760	.1734	.1799	.1647	.1691

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054064 / 33 KV SAIGAON

Feeder No / Name : 201 / 11 KV SAIGAON FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2629	.2957	.2987	.2785	.3326	.3326	.2957
2	.2629	.2957	.2801	.285	.3326	.3361	.2957
3	.2658	.3326	.2801	.285	.3326		.2957
4	.2835	.3326	.2801	.2883	.3696	.3326	.3326
5	.2835	.3696	.2926	.3174	.4066	.3511	.3511
6	.3475	.4066	.3045	.3582	.4066	.3881	.3511
7	.4207	.4066	.3721	.4163	.5121	.499	.499
8	.3658	.3696	.4508	.4572	.5359	.4887	.5359
9	.181	.2896	.4607	.4805	.499	.4784	.499
10	.1581	.3366	.2984	.2881	.3401	.3201	.3605
11	.2881	.4557		.3521	.3479	.4111	.3479
12	.2721	.426	.3479		.3479		.3361
13	.2561	.3315	.3681	.3361	.2688	.3361	.2812
14	.2241	.3121	.3005	.3163	.253		.25
15	.2241	.3121	.3005	.2881	.25		.253
16	.2401	.3155			.253	.3201	.2812
17	.2561	.3506	.3239		.2812	.4525	.3749
18	.3696	.2835	.3125	.3521	.3898		.4557
19	.4435	.4207	.3801	.5359	.4572	.5729	.4607
20	.4805	.4024	.3467	.499	.4572	.5544	.4835
21	.4251	.362	.3467	.4435	.439	.499	.4607
22	.3696	.3475	.373	.4066	.3898	.4251	.439
23	.3326	.3142	.3391	.3696	.3696	.3696	.3841
24	.2835	.2957	.2957	.285	.3696	.3696	.3326
Max	.4805	.4557	.4607	.5359	.5359	.5729	.5359
Min	.1581	.2835	.2801	.2785	.25	.3201	.25
Avg	.3040	.3485	.3342	.3638	.3726	.4125	.3732

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054064 / 33 KV SAIGAON

Feeder No / Name : 202 / 11 KV SUGAON FEEDER
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2075	.2054	.1886	.2241	.2218	.2075	.2218
2	.2075	.2054	.1886	.2241	.2218	.1886	.2241
3	.2075	.2054	.1886	.2241	.2241	.1886	.2241
4	.2263	.2241	.2075	.2263	.2241	.2075	.2427
5	.2263	.2241	.2241	.2263	.2427	.2452	.2427
6	.2452	.2241	.2614	.2641	.2614	.2263	.2427
7	.2075	.1867	.2427	.2452	.2241	.1829	.2241
8	.1629	.1867	.1867	.1698	.168	.181	.1494
9	.1494	.1848	.112	.1494	.1494	.1791	.1463
10	.3963	.5552	.104	.3506	.3978	.5335	.5967
11	.503		.104	.2439	.4696	.7316	.6249
12	.4725				.4696		.578
13	.4801			.3353	.6062	.6097	.5535
14	.5601			.3353	.5801		.4687
15	.4725			.3353	.5735		.4687
16	.5601				.6226	.5792	.4999
17	.5792		.6481		.5535	.6859	.5556
18	.112		.6481	.4572	.1448		.1063
19	.1494		.5792	.679	.1629	.2054	.1791
20	.1867	.6135	.4468	.2427	.2378	.2614	.2402
21	.2427	.2614	.2427	.2427	.2402	.2427	.2378
22	.2241	.2427	.2427	.2241	.2427	.2427	
23	.2054	.2241	.2263	.2241	.2241	.2427	
24	.2263	.2054	.2054	.2241	.2241	.2263	.2427
Max	.5792	.6135	.6481	.679	.6226	.7316	.6249
Min	.112	.1848	.104	.1494	.1448	.1791	.1063
Avg	.3004	.2633	.2762	.2785	.3203	.3184	.3305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054064 / 33 KV SAIGAON

Feeder No / Name : 203 / 11 KV POKHARI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3761	.4207	.4066	.394	.439	.3734	.4024
2	.3761	.4207	.4108	.394	.439	.3361	.4024
3	.3761	.4572	.4481	.394	.4755	.3361	.4572
4	.3982	.5487	.5415	.4344	.5121	.3734	.5121
5	.4344	.6401	.5914	.4344	.5487	.4854	.5487
6	.5853	.7316	.7164	.6653	.6036	.5601	.567
7	.695	.7499	.7442	.6401	.6584	.695	.6767
8	.7133	.7682	.7164	.7133	.7865	.6767	.695
9	.5487	.695	.6836	.4755	.6401	.6401	.6401
10	.4858	.7973	.8539	.8421	.9717	.8684	.7682
11	.9878	.9221		.9069	.9945	1.1999	.8718
12	.9488	.8785	.7316		.9945		.8223
13	.9488	.8478	.8333	.8097	.8288	.8539	.7522
14	.8065	.8764	.0274	.7682			.7907
15	.7907	.8859	.787	.7125	.7287		.7811
16	.759	.985			.7287	1.0745	.9259
17	.8065	1.0517	.8951		.7811	1.0722	1.0385
18	.4755	.4477	.8592	1.004	.5487		.4908
19	.6335	.5258	.6401	.6584	.6401	.6767	.5847
20	.695	.6588	.6516	.5853	.5487	.6401	.6516
21	.5487	.5914	.5731	.5304	.5544	.5121	.5792
22	.4755	.5544	.5304	.4938	.5041	.4755	.5544
23	.4207	.5175	.4477	.4572	.4481	.439	.4805
24	.3898	.4207	.462	.4119	.439	.4294	.439
Max	.9878	1.0517	.8951	1.004	.9945	1.1999	1.0385
Min	.3761	.4207	.0274	.394	.439	.3361	.4024
Avg	.6115	.6830	.6160	.6060	.6441	.6359	.6430

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054064 / 33 KV SAIGAON

Feeder No / Name : 204 / Dudhdairy Express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1267	.0549	.1417	.1086	.1448	.0037	.1086
2	.1267	.0543	.1341	.1086	.1448	.0037	.1086
3	.1267	.0549	.1341	.1086	.1463	.0037	.1086
4	.181	.0543	.0829	.1448	.1448	.0037	.1086
5	.181	.0543	.0701	.1629	.1448	.0037	.1086
6	.1267	.0543	.052	.1267	.1086	.0037	.1086
7	.1991	.0543	.0532	.1086	.1646	.0032	.1097
8	.1267	.0549	.0351	.1086	.1267	.0032	.1097
9	.0181	.0549	.1063	.0037		.0031	.1097
10	.0036	.0543	.0543	.0072		.0072	
11	.0036	.0362	.1448	.0037		.0362	
12	.0036	.0362	.0724				
13	.0036	.0362	.0036	.0037		.0362	
14	.0036	.0362	.0543	.0036		.0362	
15	.0036	.0724	.0362	.0036		.0036	
16	.0036	.0724		.0036		.0036	.0324
17	.0036	.0354	.0362	.0036		.0072	.0032
18	.0036	.0532	.0362	.0036			.0022
19	.0036	.0179	.0724	.0036	.0036	.0362	.0026
20	.0036	.0876	.0724	.1267	.0036	.0543	.0026
21	.128	.1109	.0362	.1448	.0035	.0905	.029
22	.128	.1294	.1086	.1448	.0035	.1086	.1227
23	.128	.1612	.1086	.1448	.0035	.1086	.1267
24	.1448	.0914	.1629	.0905	.1448	.0037	.1086
Max	.1991	.1612	.1629	.1629	.1646	.1086	.1267
Min	.0036	.0179	.0036	.0036	.0035	.0031	.0022
Avg	.0742	.0634	.0786	.0726	.0920	.0256	.0784

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054067 / 33/11 KV PATHAN MANDVA

Feeder No / Name : 201 / 11 KV NAGAZARI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	2.9569	3.1375	1.5546	3.0178	3.0849	3.2419
2	1.3108	2.9264	3.0766	1.5242	2.9264	3.024	3.033
3	1.2803	2.8806	3.0156	1.4327	2.9691	3.0178	3.0461
4	1.2803	2.973	2.9416	1.4022	2.9386	3.0422	3.0461
5	1.3413	3.1329	2.9721	1.4327	3.0895	3.2124	3.1375
6	1.6156	3.5367	3.5299	1.6766	3.3943	3.4877	3.616
7	1.829	4.0383	4.0078	2.0119	3.5772	3.9773	4.1214
8	3.4987	3.823	3.8294	2.0424	3.1985	3.8958	3.8409
9	2.7862	1.4022	3.5357	3.5604	3.2556	1.9814	3.7608
10	3.1215	1.8595	3.53	3.2693	3.3775	1.6156	3.7122
11	2.9417	3.4874	3.5608	3.2998	2.729	1.6766	3.597
12	2.8807	1.7234	3.4512	3.1054	3.2739	1.6461	3.476
13	2.8693	2.6197	3.4026	3.0026	3.1359	.7926	3.2759
14	2.8083	1.4022	3.2998	3.014	3.1054	.7926	1.6461
15	2.7938	1.4327	3.1664	3.014	3.091	1.7375	3.2874
16	3.2388	1.5851	1.7071	3.1054	3.1215	1.9204	3.3189
17	3.3959	3.5894	1.768	3.2831	3.2846	3.9766	1.768
18	3.8394	3.6199	1.829	3.5178	3.4995	4.0574	1.9509
19	4.0383	3.7829	1.9204	3.6999	3.8694	3.8348	2.0119
20	4.2341	3.9994	2.0424	4.0786	4.1091	4.2311	2.0729
21	3.8655	3.8904	1.9509	3.8599	3.9154	3.9513	2.0119
22	1.89	3.6511	1.829	1.8595	3.762	3.6945	1.829
23	3.4019	3.4858	1.7985	3.4385	1.8595	3.5597	1.7985
24	1.6766	3.2373	3.1985	3.2861	3.2435	3.2921	3.3029
Max	4.2341	4.0383	4.0078	4.0786	4.1091	4.2311	4.1214
Min	1.2803	1.4022	1.7071	1.4022	1.8595	.7926	1.6461
Avg	2.6379	2.9598	2.8542	2.7280	3.2393	2.8959	2.9126

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054067 / 33/11 KV PATHAN MANDVA

Feeder No / Name : 202 / 11 KV RAVIVAR PETH FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	1.9299	1.9669	1.0669	1.9875	2.018	2.0584
2	.884	1.8995	1.9365	1.0364	1.957	1.9509	1.9974
3	.8535	1.8016	1.8321	.9755	1.8534	1.89	1.893
4	.823	1.8107	1.8016	.945	1.8229	1.906	1.893
5	.8535	1.8107	1.8016	.945	1.8321	1.9429	1.9365
6	.945	1.8717	1.9464	1.0059	2.0073	2.0104	1.9974
7	.9755	2.0446	1.9464	1.0669	2.1018	2.0343	2.1018
8	1.8321	2.0073	2.1125	1.0974	2.1018	1.9974	1.954
9	1.6888	.9755	2.0464	1.893	2.0279	1.0059	1.8717
10	1.6583	.945	1.8995	1.8229	1.9669	1.0059	1.8229
11	1.6278	1.7341	1.8412	1.7619	1.8321	.9755	1.7619
12	1.5242	1.6948	1.7833	1.6804	1.7924	.945	1.7253
13	1.5546	1.7314	1.8014	1.4861	1.7833	.9145	1.6583
14	1.5242	.8535	.884	1.5775	1.7924	.884	.8535
15	1.5546	.8535		1.6583	1.8961	.9755	1.7802
16	1.7406	.884		1.6888	1.9266	.945	1.7253
17	1.6888	1.6888		1.7528	1.8862	1.6888	.8535
18	1.7436	1.7314		1.7528	1.8458	1.7833	.8535
19	1.9529	1.9891		2.0301	2.0072	2.05	.945
20	2.2558	2.3167	1.3413	2.3167	2.3776	2.3167	1.1279
21	2.2487	2.2862	1.4022	2.2558	2.3716	2.2862	1.1584
22	1.1279	2.2558	1.3108	2.2558	2.3594	2.2192	1.0974
23	2.1138	2.1628	1.2498	2.1826	1.1888	2.1563	1.1279
24	1.0669	2.0851	2.1194	1.9753	2.1521	2.1521	2.0584
Max	2.2558	2.3167	2.1194	2.3167	2.3776	2.3167	2.1018
Min	.823	.8535	.884	.945	1.1888	.884	.8535
Avg	1.4647	1.7235	1.7381	1.5929	1.9529	1.6689	1.5939

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054067 / 33/11 KV PATHAN MANDVA

Feeder No / Name : 203 / 11 KV MUKUNDRAJ FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.945	1.8995	1.9365	.9755	1.9875	1.9875	2.0648
2	.9145	1.8321	1.8321	.945	1.9266	1.9204	1.9974
3	.884	1.7646	1.8016	.9145	1.8229	1.8229	1.9365
4	.8535	1.7831	1.7711	.9145	1.8656	1.82	1.906
5	.884	1.7711	1.8016	.9145	1.8755	1.8385	1.906
6	.9145	1.82	1.8854	.945	1.9464	1.906	2.0408
7	.9755	1.9651	2.0408	1.0364	2.1125	2.1388	2.0713
8	1.9365	2.1006	2.2062	1.0364	2.2482	2.2182	2.2367
9	1.9669	1.0669	2.1998	2.1452	2.2801	1.1888	2.1628
10	2.0038	1.0669	2.2192	2.0911	2.3411	1.1584	2.0911
11	2.1643	1.0364	2.1765	1.9875	2.2558	1.0974	2.0728
12	2.05	1.0059	2.1887	2.0195	2.2862	1.0669	2.0058
13	2.05	1.9814	2.2192	2.0805	2.2862	1.0669	1.9266
14	2.0386	1.0364	2.1472	2.05	2.1521	1.0974	1.0059
15	2.018	1.0059	2.2139	2.0195	1.9875	1.0974	1.9652
16	1.957	1.0364	1.0669	2.0195	2.018	1.0669	1.9652
17	2.0138	2.0195	1.0669	1.9372	2.0929	2.1948	1.0364
18	2.1414	2.1338	1.1279	2.1834	2.1235	2.2558	1.0974
19	2.4501	2.5362	1.3717	2.4935	2.5484	2.5416	2.4987
20	2.7008	2.7252	1.4022	2.6886	2.7191	2.7069	1.3717
21	2.5119	2.4814	1.3108	2.4814	2.5667	2.6459	1.2803
22	1.1888	2.3167	1.1888	2.2862	2.4021	2.4509	1.1584
23	2.1216	2.1521	1.0974	2.2558	1.1888	2.3167	1.1279
24	1.0669	1.9875	2.018	1.0974	2.1216	2.1461	2.0953
Max	2.7008	2.7252	2.2192	2.6886	2.7191	2.7069	2.4987
Min	.8535	1.0059	1.0669	.9145	1.1888	1.0669	1.0059
Avg	1.6980	1.7719	1.7621	1.7299	2.1315	1.8230	1.7925

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054067 / 33/11 KV PATHAN MANDVA

Feeder No / Name : 204 / 11KV KALWATI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3239		.1219	.0076	.0762	.0076
2	.1219	.3239		.1219	.1402	.1402	.1357
3	.1219	.3582	.2218	.1219	.3277	.1402	.2881
4	.1219	.3582	.3132	.0914	.3627	.2934	.2576
5	.1524	.3951	.3067		.4267	.3277	.322
6	.2134	.5213	.4561		.5868	.4535	.5525
7	.2743	.5963	.5486	.3048	.6744	.6371	.6405
8	.5791	.6405	.4497	.3048	.6744	.7011	.6066
9	.4778	.3353	.5563	.5064	.6096	.3658	.5203
10	.2477	.2743	.3124	.2819	.3303	.2743	.2706
11	.0038		.0381	.0076	.056		.0554
12	.0038		.0381	.0038	.056		.0554
13	.0038		.0381	.0038	.056		.0554
14	.0076		.0366	.0038	.0566		
15	.0076		.0572	.0038	.0566		.0572
16	.0038				.0566		.0381
17	.0572	.0057			.0572	.0057	
18	.0554	.0076		.0057	.0572	.0076	
19	.0762	.0076		.0747	.0572	.0076	
20	.0762	.0747		.0747	.0762	.0076	
21	.0762	.0747		.0747	.0762	.0076	
22		.0747		.0747	.0762	.0076	
23	.0762	.0747		.0076		.0076	
24		.1357		.1187	.0076	.0762	.0076
Max	.5791	.6405	.5563	.5064	.6744	.7011	.6405
Min	.0038	.0057	.0366	.0038	.0076	.0057	.0076
Avg	.1313	.2546	.2595	.1154	.2124	.1965	.2419

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054067 / 33/11 KV PATHAN MANDVA

Feeder No / Name : 205 / 11 KV WATER SUPPLY EXPRESS NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1243	.061	.0305	.1265	.061	.1258
2			.1273		.061	.0305	.061
3			.1258		.061		.061
4			.1258				
5		.1265	.1265		.0663	.0663	
6		.1265	.1281		.1273	.2469	.0663
7		.2179	.1258	.061	.2576	.2804	.1281
8		.1265	.1265	.061	.2896	.282	.1281
9		.0305	.1273	.1273	.2896	.1524	.1258
10	.0655	.061	.1265	.1273	.2881	.1524	.125
11	.1577	.061	.1265	.1273	.2881	.0914	.1273
12	.1273	.061	.1265	.1273	.2881	.061	.1265
13	.1273	.061	.1265	.1273	.2881	.061	.1265
14	.1265	.061	.1258	.1273	.2865	.061	.061
15	.2187	.061	.1265	.1273	.2865	.0305	.1258
16	.2187	.061	.061	.1281	.285		.1258
17	.2172	.1562	.061	.1281	.2743	.0625	.061
18	.122	.1724	.061	.1273	.2743	.2804	.061
19	.122	.125	.061	.125	.2759	.2804	.061
20	.2438	.1258	.061	.1281	.2759	.1227	.061
21	.2728	.1281	.061	.1273	.2141	.1227	.061
22	.1524	.1281	.061	.1273	.1235	.1235	.061
23	.2759	.1281	.061	.1281	.061	.125	.061
24	.0914	.1243	.061	.061	.1281	.1235	.125
Max	.2759	.2179	.1281	.1281	.2896	.282	.1281
Min	.0655	.0305	.061	.0305	.061	.0305	.061
Avg	.1693	.1080	.0992	.1118	.2138	.1342	.0939

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054067 / 33/11 KV PATHAN MANDVA

Feeder No / Name : 404 / 33 KV DAWAKHANA

Feeder KV- 33 / INCOMING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0208	.9671		.9671	1.0745	1.0208
2		1.0745	.9134		1.0745	1.1283	1.0208
3		1.0745	.9134		1.0745	1.1283	1.0208
4		1.1283	.9134		1.0745	1.1283	1.0208
5		1.1283	.9134		1.0974	1.1283	1.1283
6		1.182	1.2894			1.2894	1.3432
7		1.3969	1.4506		1.3969	1.182	1.5043
8	1.2894	1.3969	1.3432		1.2357	1.2894	1.3432
9	1.182		1.182	1.182	1.182		1.2894
10	1.0745		1.0745	1.0745	1.1283		1.2357
11	1.0745		1.0745	1.0745	1.1283		1.2357
12	1.0745	1.0208	1.0208	1.0208	1.0745		1.1283
13	1.0208		.9134	.9671	1.0208		.9671
14	1.0208		1.0745	.9671	1.0208		
15	1.0208		1.0745	.9774	1.0745		1.182
16	1.0745			1.0745	1.0208		1.182
17	1.182	1.0208		1.2357	1.0745	1.182	
18	1.0208	1.0745		1.0745	1.1283	1.2894	
19	1.2357	1.1283		1.2894	1.2357	1.3969	
20	1.3432	1.182		1.2357	1.2357	1.3969	
21	1.1283	1.182		1.1283	1.0923	1.2894	
22		1.0745		1.0745	1.1283	1.182	
23	1.0745	1.0208		.9671		1.182	
24		1.0208	.9671		.9134		1.1283
Max	1.3432	1.3969	1.4506	1.2894	1.3969	1.3969	1.5043
Min	1.0208	1.0208	.9134	.9671	.9134	1.0745	.9671
Avg	1.1211	1.1251	1.0678	1.0895	1.1081	1.2178	1.1719

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054100 / Girwali 33/11 kkv

Feeder No / Name : 201 / Warwati

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	05-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6859			
2		.6859			
3		.7621			
4		.7621			
5		.9145			
6		.9907			
7		1.1126	.9755		1.0517
8					1.0822
9			1.1126	.9602	
12	.7773				
13	.9907				
14	.9907				
24		.5858			
Max	.9907	1.1126	1.1126	.9602	1.0822
Min	.7773	.5858	.9755	.9602	1.0517
Avg	.9196	.8125	1.0441	.9602	1.0670

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054100 / Girwali 33/11 kkv

Feeder No / Name : 202 / Express Water Supply
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1844					
2	.1844					
3	.1844					
4	.1844					
5	.1844					
6	.1844					
7	.1844					
10			.1457		.0162	.1457
11	.1509				.1457	
12	.1677				.1457	
13	.1844			.1457		
14	.1844	.1457			.0162	
15	.1844					
17					.0162	
18						.0162
19		.1619				
20			.1457		.1296	
22		.1619				
24	.1844					
Max	.1844	.1619	.1457	.1457	.1457	.1457
Min	.1509	.1457	.1457	.1457	.0162	.0162
Avg	.1805	.1565	.1457	.1457	.0783	.0810

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054100 / Girwali 33/11 kkv

Feeder No / Name : 203 / Girwali

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3334	.3734					
2	.3334	.3734					
3	.3334	.3734					
4	.3858	.3734					
5	.4458	.4001					
6	.5182	.4401					
7	.4725	.4816	.442				.442
8	.4572						.4115
9	.3601		.3201		.4268		
10	.6859		.6554	.5944		.7773	.6554
11	.5487		.7926			.7621	
12	.7621	.7621				.7926	
13	.8688	.7316	.7773				
14	.8383	.7164	.7621			.7773	
15	.8383	.7011					
16		.7468					
17		.6859				.8078	
18	.2286	.2439					.381
19	.3715	.3353	.442				
20	.4694	.5335		.5335		.5487	
21	.4458						
22	.3734		.4268	.4877			
23	.3734	.4268					
24	.3429	.3734					
Max	.8688	.7621	.7926	.5944	.4268	.8078	.6554
Min	.2286	.2439	.3201	.4877	.4268	.5487	.381
Avg	.4903	.5040	.5773	.5385	.4268	.7443	.4725

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054100 / Girwali 33/11 kkv

Feeder No / Name : 204 / Warwati GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.021	.021					
2	.021	.021					
3	.021	.021					
4	.021	.0343					
5	.0343	.0457					
6	.0503	.0503					
7	.0503	.0495	.0591				.0591
8	.0503						.0591
9	.0343		.0354		.0354		
10	.0229			.0236			.0354
11	.0229						
12	.021	.0236					
13	.021	.0236					
14	.021	.0354	.0472			.0472	
15	.021	.0236					
16		.0236					
17		.0354		.0354		.0472	
18	.0332	.0354					.0354
19	.0503	.0472	.0472				
20	.0503	.0472		.0472		.0472	
21	.0503						
22	.0343		.0236	.0354			
23	.0221	.0236					
24	.021	.021					
Max	.0503	.0503	.0591	.0472	.0354	.0472	.0591
Min	.021	.021	.0236	.0236	.0354	.0472	.0354
Avg	.0316	.0324	.0425	.0354	.0354	.0472	.0473

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054100 / Girwali 33/11 kkv

Feeder No / Name : 205 / T V center

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572					
2	.0381	.0381					
3	.0381	.0381					
4	.0381	.0381					
5	.0381	.0381					
6	.0381	.0572					
7	.0572	.0762	.0572				.0572
8	.0762						.0572
9	.0762		.0762		.0572		
10	.0762		.0572	.0762			.0572
11	.0762		.0572			.0762	
12	.0762					.0762	
13	.0762	.0762	.0572				
14	.0762	.0762	.0762			.0762	
15	.0762	.0762					
16		.0572					
17		.0572		.0762		.0762	
18	.0762	.0572					.0572
19	.0762	.0572	.0762				
20	.0762	.0762		.0762		.0572	
21	.0762						
22	.0762		.0572	.0572			
23	.0762	.0572					
24	.0762	.0762					
Max	.0762	.0762	.0762	.0762	.0572	.0762	.0572
Min	.0381	.0381	.0572	.0572	.0572	.0572	.0572
Avg	.0658	.0594	.0643	.0715	.0572	.0724	.0572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054100 / Girwali 33/11 kkv

Feeder No / Name : 206 / Yogeshwari Hatchries
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191					
2	.0191	.0191					
3	.0191	.0191					
4	.0191	.0191					
5	.0191	.0191					
6		.0191					
7	.0191	.0191	.0191				
8	.0191						.0381
9	.0572		.0572		.0572		
10	.0572		.0953	.0572			.0762
11	.0572		.0953			.0953	
12	.0572					.0953	
13	.0572	.0381	.1143				
14	.0572	.0381	.0762			.0762	
15	.0572	.0572					
16		.0572					
17		.0762		.0572		.0762	
18	.0381	.0381					.0953
19	.0381	.0572	.0762				
20	.0572	.0572		.0572		.0572	
21	.0572						
22	.0381		.0762	.0762			
23	.0381	.0381					
24	.0191	.0191					
Max	.0572	.0762	.1143	.0762	.0572	.0953	.0953
Min	.0191	.0191	.0191	.0572	.0572	.0572	.0381
Avg	.0390	.0359	.0762	.0620	.0572	.0800	.0699

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054106 / DONGAR PIMPALA 33/11 KV

Feeder No / Name : 201 / 11 kv sonawala

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.2829			.3018	.0377	
2	.3018	.2641			.3206	.0377	
3	.2829	.2641	.3018		.3018	.0377	
4	.3018	.2641	.3018		.3018	.0377	
5	.3772	.2641	.3018		.3206	.0566	.0622
6	.4338	.4715	.4904	.3772	.4715	.0566	.066
7	.4338	.5281	.5658	.5093	.547	.0566	
8	.3961	.5658	.547	.4527	.5093	.0377	
9	.4338	.5281	.5281	.415	.5281	.0377	
10	.4338	1.0374	1.0562	.8676	.7545	1.5089	1.3033
11	.6979	1.1317	1.1506	.9431	1.0374	1.1317	
12	.6979	1.1317	1.094	.9997	1.0374	1.4901	
13	.3772	1.1317	1.1506	.8865	.9808	1.3957	
14	.6224	1.0185	1.1317	.8299	.9619	1.3203	
15	.5847	1.0562	1.094	.811	.9242	1.358	
16	.9619	1.1128	1.094		.9808	1.4146	
17	1.0562	1.1317	.9997		1.0751		1.4335
18	.0377	.0377	.0754	.0377	.0566		.0377
19	.0566	.0566	.0943	.0566	.0566		.0566
20	.0566			.0754	.0754		.0754
21	.0566	.0566	.0943	.0566	.0566		
22	.0566		.0943	.0566	.0566		.0566
23	.0566		.0943	.0566			.0566
24	.2641	.2743	.3018	.2829	.2829	.0566	
Max	1.0562	1.1317	1.1506	.9997	1.0751	1.5089	1.4335
Min	.0377	.0377	.0754	.0377	.0566	.0377	.0377
Avg	.3859	.6005	.5982	.4538	.5191	.5925	.3498

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054106 / DONGAR PIMPALA 33/11 KV

Feeder No / Name : 203 / 11 KV D.PIMPALA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.1494		.1463	.156	.1715	
2	.1109	.1494		.1509	.156	.1753	
3	.128	.1494	.128	.1494	.1646	.1734	
4	.132	.1509	.1448	.1698	.1663	.181	
5	.1867	.1698	.1698	.1886	.1848	.2172	.1102
6	.2452	.2641				.3326	.1288
7	.2195	.2641			.2241	.2195	
8	.2033	.2241	.2561	.2452	.1848	.1867	
9	.168	.1448	.2075	.1646	.1663	.1663	
10	.1448	.1294	.168	.1267	.1267	.1267	.0754
11	.1097	.112	.1307	.1086	.056	.056	
12	.1433				.0566		
13	.124				.0554		
14	.1075				.0554		
15	.1086	.1307	.1463	.0886	.0377	.0739	
16	.1097	.1463	.1448	.1063	.0549	.0905	
17	.1448	.128	.1578	.1372	.0543		.1417
18	.1402	.1326	.1907	.1509	.0503		.0995
19	.1829	.1949	.2195	.1907	.1791		.1715
20	.2195			.2481	.2658		.2058
21	.1848	.181	.1829	.208	.2254		
22	.1463		.1595	.1865	.1844		
23	.1448		.1463	.1677			.1052
24	.1294	.1494	.1463	.1494	.1715	.1696	
Max	.2452	.2641	.2561	.2481	.2658	.3326	.2058
Min	.1075	.112	.128	.0886	.0377	.056	.0754
Avg	.1519	.1650	.1687	.1623	.1353	.1672	.1298

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054133 / 33/11KV DAWAKHANA S/S

Feeder No / Name : 201 / 11KV KRANTI NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8843	.8614	.8843	.9212	.8843	.9193	.9212
2	.8843	.8448	.8843	.9212	.8843	.9193	.8843
3	.8843	.8448	.8475	.8843	.8843	.8825	.8843
4	.9212	.8816	.8475	.958	.958	.8825	.8843
5	.958	.955	.958	.9949	1.0317	1.0296	.9406
6	.9949	1.1215	1.0686	1.1607	1.1054	1.1399	1.0686
7	1.0317	1.2699	1.2344	1.2528	1.2712	1.2318	1.2159
8	1.0915	1.3251	1.2712	1.1975	1.2344	1.1583	1.3081
9	1.087	1.1779	1.1422	1.1054	1.1791	1.1779	1.1238
10	.9938	.9764	1.0133	1.0317	1.0847	1.0133	1.0317
11	.865	.9396	.9027	.8659	.8825	.9949	.958
12	.8282	.9212	.8475	.829	.9744	.9396	.958
13	.8282	.8106	.8106	.8106	.956	.8659	.9212
14	.7906	.7738	.8106	.8475	.8641	.8659	.9212
15	.7722	.829	.7922	.8659	.8089	.8843	.958
16	.8089	.8659	.8843	.7922	.8457	.9212	.958
17	.8641	.9027	.9212	.9949	.9376	1.0133	.9949
18	.9018	.9949	1.0133	.9949	1.0112	1.1238	
19	1.1767	1.087	1.2344	1.2159	1.195	1.2344	
20	1.2673	1.3265	1.2344	1.3449	1.3237	1.2896	
21	1.1203	1.1607	1.1607	1.1607	1.1767	1.1791	
22		1.087	1.0686	1.0686	1.1203	1.1422	
23	.956	.9949	1.0133	.958	1.0663	1.0317	.9744
24	.9027	.8632	.9396	.958	.9396	.956	.958
Max	1.2673	1.3265	1.2712	1.3449	1.3237	1.2896	1.3081
Min	.7722	.7738	.7922	.7922	.8089	.8659	.8843
Avg	.9484	.9923	.9910	1.0056	1.0258	1.0332	.9929

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054133 / 33/11KV DAWAKHANA S/S

Feeder No / Name : 202 / 11KV DAGADWADI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0496	.049	.0332	.0496	.0497	.0492	.0995
2	.0496	.049	.0332	.0331	.0497	.0492	.1326
3	.0496	.049	.0497	.0331	.0497	.0492	.1492
4	.0496	.0655	.0497	.0496	.0663	.0655	.1492
5	.1984	.0983	.0829	.0496	.0663	.1147	.1492
6	.2315	.1483	.2155	.0496	.0663	.1475	.2321
7	.2315	.2142	.2652	.0661	.0663	.1638	.2486
8	.2315	.1978	.2579	.0827	.0829	.0655	.2486
9	.0827	.1978	.2155	.0661	.0995	.0493	.2486
10	.1475	.0497	.0661	.0995	.0492	.0829	.0827
11	.1638	.0332	.1488	.0497	.0985	.2486	.1659
12	.0494	.0332	.1654	.1658	.0659	.2486	.1659
13	.214	.0332	.1654	.0663	.0989	.2652	.1493
14	.2305	.0663	.1819	.0995	.1318	.1989	.1328
15	.2472	.0663	.1819	.116	.1978	.2652	.1328
16	.2307	.0497	.1984	.1989	.2142	.3315	.0996
17	.1978	.0332	.1984	.2155	.1975	.1989	.083
18	.2469	.0497	.1984	.0829	.2463	.1658	
19	.0655	.0663	.1158	.116	.0983	.0995	
20	.0819	.0829	.0992	.116	.0655	.2321	
21	.0654	.0663	.0992	.0995	.0819	.2321	
22	.0817	.0663	.0496	.0829	.0493	.1823	
23	.0654	.0497	.0496	.0497	.0552	.1823	.0492
24	.0496	.049	.0497	.0496	.0497	.0492	.0995
Max	.2472	.2142	.2652	.2155	.2463	.3315	.2486
Min	.0494	.0332	.0332	.0331	.0492	.0492	.0492
Avg	.1380	.0777	.1321	.0870	.0957	.1557	.1483

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054141 / PATTIWADGAON SUBSTATION

Feeder No / Name : 201 / MURTI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1052	.1052	.0701	.1227	.0876	.1227	.1227
2	.1052	.1052	.0876	.1052	.0876	.1227	.1402
3	.1052	.1052	.1052	.1052	.1052	.1052	.1052
10	.3155	.2454	.2103		.2103	.2103	.2103
11	.2804	.2454	.2534	.1402			.2454
12	.2279	.1753		.1402			.1753
13	.1753	.2103		.1227			.1753
14	.1402	.1341		.1052			.1753
15	.1753	.1448		.1052			.1753
16	.2103	.1753		.1052			.1753
17	.2454	.2103		.1753			.2454
18	.0701	.0701		.0701			.0701
19	.1402	.1402		.0701			
20		.1753	.1402	.1052			
21	.1402	.1402	.1052	.1052			
22	.1227	.1052	.1753	.1052			.1052
23	.1052	.0701	.1578	.1052			.1052
24	.1052	.1052	.0876	.1052	.1052	.1052	.1052
Max	.3155	.2454	.2534	.1753	.2103	.2103	.2454
Min	.0701	.0701	.0701	.0701	.0876	.1052	.0701
Avg	.1629	.1479	.1393	.1114	.1192	.1332	.1554

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054141 / PATTIWADGAON SUBSTATION

Feeder No / Name : 202 / PATTIWADGAON FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.3018	.3185	.3521	.3018	.3521	.3688
2	.3185	.3353	.3018	.3688	.3353	.3856	.4024
3	.4024	.4024	.3856	.3856	.3856	.3856	.3856
10	.503	.4694	.503		.3856	.4862	.4862
11	.503	.4694	.5365	.4694			.4191
12	.4527	.4024		.4694			.4359
13	.3688	.4024		.4024			.4024
14	.285	.3856		.4024			.3688
15	.3185	.3688		.3856			.3688
16	.3185	.4024		.4024			.3688
17	.4024	.4527		.4024			.4191
18	.2012	.2347		.1677			
19	.3018	.3688		.3353			
20		.503	.4694	.4024			
21	.4359	.4191	.4191	.4527			
22	.4024	.3688	.4024	.4024			.3688
23	.3353	.3521	.3353	.3521			.3018
24	.3353	.3018	.3185	.3185	.3018	.3353	.3353
Max	.503	.503	.5365	.4694	.3856	.4862	.4862
Min	.2012	.2347	.3018	.1677	.3018	.3353	.3018
Avg	.3639	.3856	.3990	.3807	.3420	.3890	.3880

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054141 / PATTIWADGAON SUBSTATION

Feeder No / Name : 203 / BHABALGAON FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.285	.285	.3018	.3353	.285	.3185	.3185
2	.285	.3185	.285	.3353	.3018	.3353	.285
3	.3018	.3353	.3185	.3185	.3353	.3185	.3018
10		.6706	.7209		.6706	.7042	.6874
11		.6874	.8048	.6203			.7545
12		.7209		.8215			.7209
13		.7712		.7042			.6706
14	.503	.7042		.7042			.5868
15	.5182	.6706		.7042			.6706
16	.6706	.7042		.8048			.7545
17	.7712	.7712		.8551			.788
18	.285	.2347		.2515			
19	.3856	.4191		.4359			
20		.6036	.5533	.5365			
21	.4359	.503	.5197	.4527			
22	.3688	.3856	.3688	.3856			.3521
23	.3185	.3018	.3185	.3353			.3018
24	.3018	.285	.3018	.3018	.285	.3018	.3018
Max	.7712	.7712	.8048	.8551	.6706	.7042	.788
Min	.285	.2347	.285	.2515	.285	.3018	.285
Avg	.4177	.5207	.4493	.5237	.3755	.3957	.5353

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054005 / 33/11 KV DHARUR

Feeder No / Name : 204 / EXPRESS JINING

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0286	.0762	.0762			
2		.0229	.0762	.061			
3	.1029	.0286	.061	.061			
4		.0171	.061	.061			
5		.0229	.061	.0762			
6	.1715	.0076		.0914			
7	.1143	.0171	.061	.0762			
8				.061			
9	.0762		.0476	.0381			.0457
10	.0914		.0457	.0229			.0457
11	.0762	.0914	.0381	.0229		.061	.0305
12	.0457	.08	.0381	.0305		.061	.0305
13	.0457		.0305	.0381		.0457	.0457
14	.0762		.0457	.0305			.0762
15	.0686		.0457	.0229			.061
16	.0914						.0914
17	.0381	.0762	.0762		.0514	.061	
18	.0457	.0762	.061		.0152	.0762	
19	.0457	.0762	.0457		.0152	.061	
20	.0457		.061		.0305	.061	
21	.0381		.0762		.0457	.061	
22	.0381		.0762		.0457		
23	.0305	.0762	.0762		.0457		
24		.0381	.0762	.0762			.0914
Max	.1715	.0914	.0762	.0914	.0514	.0762	.0914
Min	.0305	.0076	.0305	.0229	.0152	.0457	.0305
Avg	.0702	.0471	.0589	.0529	.0356	.0610	.0576

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054005 / 33/11 KV DHARUR

Feeder No / Name : 205 / GFSS Avargaon

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.2858	.463	.4287			
2		.3048	.4801				
3		.4001	.5144				
4		.4572	.5658				
5		.5487	.6687				
6	.4287	.6935					
7	.4572	.6535					
9	.3429		.4001	.1372			.6001
10			.4115	.2763			.5144
11		.381	.2	.2191		.463	.4801
12		.3353					.4458
13	.4801						.3944
14	.4115						.3601
15	.4801		.2382	.1372		.6687	.3601
16	.4287	.4287					.3944
17	.2858	.4287	.5144		.5144	.463	
18	.362	.5144	.3601		.5658	.5144	
19	.5373	.5487	.7888		.7202	.6344	
20	.4801		.7202		.7373	.6516	
21	.4115	.703	.6516		.583		
22	.3658		.5487		.5144		
23	.2667	.4973	.4801		.4973		
24		.2477		.463			.463
Max	.5373	.703	.7888	.463	.7373	.6687	.6001
Min	.2667	.2477	.2	.1372	.4973	.463	.3601
Avg	.4130	.4643	.5004	.2769	.5903	.5659	.4458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054005 / 33/11 KV DHARUR

Feeder No / Name : 206 / GFSS Aranwadi

Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	03-MAY-17	05-MAY-17	06-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
17			.5335
20		.583	
24	.4801		
Max	.4801	.583	.5335
Min	.4801	.583	.5335
Avg	.4801	.583	.5335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054005 / 33/11 KV DHARUR

Feeder No / Name : 207 / Gopalpur Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2382					
2		.2286					
3			.5944				
4		.2096	.6097	.2286			
5		.1524	.6401	.5182			
6		.3334	.7164	.6706			
7		.1677	.6097	.5792			
11						.4572	.503
12						.4877	.5316
13						.5639	.4268
14							.3963
15							.3963
16							.4268
17					.463		
18					.6516	.5639	
21			.3201				
22	.5068	.503	.3658				
23	.3239	.5182	.3963				
24		.2858		.3658			
Max	.5068	.5182	.7164	.6706	.6516	.5639	.5316
Min	.3239	.1524	.3201	.2286	.463	.4572	.3963
Avg	.4154	.2930	.5316	.4725	.5573	.5182	.4468

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054005 / 33/11 KV DHARUR

Feeder No / Name : 208 / 11 Kv Dharur Urban

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003	.9335	1.2174	1.1488			
2		.9602	1.2174	1.1488			
3		1.1431	1.2003	1.1317			
4	1.286	1.2193	1.286	1.0974			
5		1.4232	1.3889	1.2346			
6	1.3203	1.4746	1.3889	1.3546			
7	1.3717	1.6461	1.7318	1.6118			
8				1.5261			
9	1.6289		1.6804	1.5775			1.2346
10	1.2689		1.5432	1.4918			1.2517
11	1.2517	1.2003	1.3375	1.0822		1.3717	1.3032
12	1.1831	1.1888	1.0669	1.0517		1.406	1.2346
13	1.0802		1.0364	.8669		1.1145	1.1317
14	1.1488		1.1126	.9335			1.1145
15	1.286		1.1736	1.4232			1.0974
16	1.3375	1.3375					1.166
17	1.2955	1.3546	1.4403		1.4403	1.3717	
18	1.5432	1.3717	1.5089		1.5089	1.4746	
19	1.6804	1.5604	1.5775		1.6118	1.3717	
20	1.6118	1.5604	1.4746		1.5775	1.5432	
21	1.4918	1.5261	1.406		1.5775	1.5604	
22	1.4575	1.3546	1.3375		1.3889		
23	1.2041	1.2346	1.2689		1.2689		
24		1.1126	1.2689	1.2346			1.2517
Max	1.6804	1.6461	1.7318	1.6118	1.6118	1.5604	1.3032
Min	1.0802	.9335	1.0364	.8669	1.2689	1.1145	1.0974
Avg	1.3499	1.3112	1.3484	1.2447	1.4820	1.4017	1.1984

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054017 / 33 KV. ADAS S/S

Feeder No / Name : 201 / 11 KV. ADAS FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6783	1.0174	.5087		.6737	.724	.724
2	.6783		.5098		.6737	.905	.905
3	.6783	1.0174	.8497		.844	.905	.905
4	.8478	1.0174	.8516	.6798	.844	.905	.905
5	1.0197	1.0174	.8478	1.0219	1.0128	1.086	1.086
6	1.1046	1.0174	1.0898	1.1963	1.0997	1.3575	1.267
7	1.1896	1.5104	1.3489	1.1869	1.2689	1.448	1.448
8	1.1896	1.358	1.3626	1.1829	1.1843	1.448	1.267
9	1.1896	1.0185	1.1869	1.1829	1.1843	1.267	1.267
10	.6798	.8488	.5098	.676	.8459	.724	.543
11		.4973	.511	.6722	.5287	.724	.543
12	.5098	.5001	.5087	.5041	.1762	.724	.543
13	.5098	.503	.507	.5041		.724	.543
14	.6798	.5058	.5087	.5041	.5316	.724	.543
15	.6798	.5115	.5098	.5041	.543	.724	.543
16	.6798	.5087	.5127		.543	.724	.543
17		.5098	.5087		.543	.724	
18	.6798	.8516	.845	.8402	.6335	.724	
19		1.0139	1.0105	1.0082	.905	1.086	
20	1.0197	1.0174	1.0139	1.0082	1.086	1.086	
21	1.0197	1.0197	1.0174	1.0082	1.086	1.086	1.086
22	1.0197	.8516	.8497	.8402	1.086	.905	1.086
23	.8497	.511	.511	.8402	.905	.905	.905
24	.6798	.8478	.5115	.8478	.6737	.724	.724
Max	1.1896	1.5104	1.3626	1.1963	1.2689	1.448	1.448
Min	.5098	.4973	.507	.5041	.1762	.724	.543
Avg	.8373	.8466	.7663	.8531	.8205	.9314	.8688

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054017 / 33 KV. ADAS S/S

Feeder No / Name : 202 / 11 KV. KHODAS FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.341	.341	.1709		.3399	.3803	.3803
2	.341	.341	.1703		.3399	.3803	.3803
3	.341	.341	.1699		.3399	.3803	.3803
4	.341	.341	.1638	.3406	.3399	.3803	.3803
5	.341	.3296	.2472	.3418	.3399	.5704	.5704
6	.5115	.341	.3315	.4234	.3399	.5704	.5704
7	.5115	.3391	.3342	.5053	.511	.5704	.5704
8	.5115	.3391	.3391	.5127	.3406	.5704	.3803
9	.341	.3391	.3399	.3418	.3406	.3803	.3803
10	.6821	.6783	.8478	.6836	.6813	.7606	.7606
11	.9378	.9378	1.0025	.6836	.511	.9507	.7606
12	.9378	1.1071	1.0059	.6836	.1703	.9507	.9507
13	.9378	1.0219	.8478	.6836		.9507	.7606
14	.8526	1.0197	.9368	.6836	.511	.5704	.7606
15	.8526	1.1084		.6836	.9335	.5704	.7606
16	.9378	.8545			.9335	.7606	.7606
17	1.0231	1.0277			.9368	.7606	
18		.1709	.3315	.3418	.3406	.3803	
19		.341	.5001	.3418	.5704	.3803	
20		.3418	.503	.5127	.5704	.5704	
21	.5115	.511	.421	.5127	.4753	.5704	.5704
22	.5115	.341	.3372	.3418	.4753	.5704	.4753
23	.341	.1699	.338	.3418	.3803	.3803	.3803
24	.341	.341	.5115	.3406	.3418	.3803	.3803
Max	1.0231	1.1084	1.0059	.6836	.9368	.9507	.9507
Min	.341	.1699	.1638	.3406	.1703	.3803	.3803
Avg	.5927	.5427	.4690	.4895	.4810	.5704	.5657

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054017 / 33 KV. ADAS S/S

Feeder No / Name : 203 / 11 KV ASARDON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3304	.4944	.1652		.1652	.1652	.1652
2	.3304	.4944	.1652		.4955	.3304	.3304
3	.3304	.4944	.413		.4955	.3304	.3304
4	.3304	.4944	.413	.3304	.4955	.4955	.4955
5	.4955	.4944	.413	.4955	.4955	.4955	.4955
6	.4955	.4944	.4955	.4955	.4955	.4955	.4955
7	.4955	.4944	.4955	.4955	.4955	.4955	.4955
8	.4955	.4944	.4955	.4955	.4955	.4955	.4955
9	.4955	.4955	.4955	.4955	.4955	.4955	.4955
10	.1652	.3304	.1652	.1652	.1652	.1652	.1652
11	.1652	.2478	.1652	.1652	.1652	.1652	.1652
12	.1652	.1652	.1652	.1652	.1652	.1652	.1652
13	.1652	.1652	.1652	.1652		.1652	.1652
14	.1652	.1652	.1652	.1652	.1652	.1652	.1652
15	.1652	.1652	.1652	.1652	.1652	.1652	.1652
16	.1652	.1652	.1652		.1652	.1652	.1652
17	.1652		.3304		.1652	.1652	
18		.1652	.3304	.1652	.1652	.1652	
19	.2478	.3304	.4955	.3304	.3304	.3304	
20	.4955	.4955	.4955	.4955	.4955	.4955	
21	.4955	.4955	.413	.4955	.3304	.4955	.2478
22	.3304	.3304	.1652	.4955	.2478	.3304	.2478
23	.3304	.1652	.1652	.3304	.1652	.3304	.1652
24	.3304	.3296	.1652	.413	.3304	.1652	.1652
Max	.4955	.4955	.4955	.4955	.4955	.4955	.4955
Min	.1652	.1652	.1652	.1652	.1652	.1652	.1652
Avg	.3196	.3551	.3028	.3434	.3196	.3097	.2891

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054063 / 33/11 KV HOAL S/S

Feeder No / Name : 201 / HOAL SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	05-MAY-17	06-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	2.2291	2.572		
6	2.915	3.0864	3.4294	
7		3.4294		
10				2.2291
Max	2.915	3.4294	3.4294	2.2291
Min	2.2291	2.572	3.4294	2.2291
Avg	2.5721	3.0293	3.4294	2.2291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054063 / 33/11 KV HOAL S/S

Feeder No / Name : 202 / LADEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	06-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2058	
3		.2058	
5	.8573	1.0288	
6	1.0288	1.2003	
7		1.286	
9			1.2003
10			1.2003
12			.1715
15			.1715
24	.2058	.2058	
Max	1.0288	1.286	1.2003
Min	.2058	.2058	.1715
Avg	.5744	.6888	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054063 / 33/11 KV HOAL S/S

Feeder No / Name : 203 / BHATUMBA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	06-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.6859		
2		.6859	
3	.6859	.7716	
14			.6516
15			.6859
24	.6859	.6859	
Max	.6859	.7716	.6859
Min	.6859	.6859	.6516
Avg	.6859	.7145	.6688

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054063 / 33/11 KV HOAL S/S

Feeder No / Name : 204 / CHANDANSAVARGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	06-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.5144		
5	1.2003	1.2003	
6	1.5432	1.5432	
7		1.5432	
14			.3772
24	.5144		
Max	1.5432	1.5432	.3772
Min	.5144	1.2003	.3772
Avg	.9431	1.4289	.3772

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054072 / 33/11 KV AMBEWADGAON S/S

Feeder No / Name : 202 / AMBEWAGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2926		.2894				.3189
2	.3364		.5316				.3189
3	.3158		.273				.3349
4	.3364		.273				.3508
5	.429	.4001	.3694	.3832			.3668
6	1.6924	1.6804	1.8309				1.9933
7			1.9296				2.0571
8		1.7688	1.8309				
9				1.7583			
10					1.9182		
11					.3832		
12					.2235		
14					.2235		
15					.2714		
16		.2409					
17		.2894				.2392	
18	.3144	.3538				.3508	
19	.4727	.4502				.4465	
20	.5048	.5146				.4943	
21	.3953	.4342				.4146	
22	.3471	.3538				.3827	
23		.2894	.2714			.3508	
24	.2691		.2894				.3189
Max	1.6924	1.7688	1.9296	1.7583	1.9182	.4943	2.0571
Min	.2691	.2409	.2714	.3832	.2235	.2392	.3189
Avg	.4755	.6160	.7889	1.0708	.6040	.3827	.7575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054072 / 33/11 KV AMBEWADGAON S/S

Feeder No / Name : 203 / SONIMOHA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716		.5316				.5032
2	.5889		.5316				.487
3	.5883		.5316				.5194
4	.668		.6645				.5194
5	.7963		.7984	.7382			.5363
6	1.3361	1.1763	1.0312				1.1051
7			1.0312				.9101
8		1.0128	1.0002				
9				.6569			
10					.6219		
11					.1637		
12					.1638		
14					1.2765		
16		1.4838			1.1783		
17		1.6505				1.6289	
18	1.8799	1.8484				1.743	
19	1.8526	1.6077				1.627	
20	1.6766	1.3321				1.3001	
21	1.6594	1.3275				1.2986	
22	.6638	.6683				.5681	
23	.5868	.5808	.5243			.5357	
24	.5716		.5316				.5194
Max	1.8799	1.8484	1.0312	.7382	1.2765	1.743	1.1051
Min	.5716	.5808	.5243	.6569	.1637	.5357	.487
Avg	1.0338	1.2688	.7176	.6976	.6808	1.2431	.6375

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054113 / ASARDOH

Feeder No / Name : 201 / Morphali

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3506	.3048	.0953	.2743	.0762	.0953	.0953
2	.3506	.3658	.0953		.3506	.3353	.3353
3	.3658	.3963	.3353		.4115	.4115	.381
4	.4115	.4268	.381	.3658	.4572	.4268	.4268
5	.4572	.4268	.442	.4268	.4877	.4725	.4572
6	.5182	.4572	.4725	.4572	.503	.5335	.503
7	.5335	.4877	.5639	.5182	.6249	.5792	.5182
8	.5335	.4572	.5639	.5487	.5944	.5335	.5487
9	.5487	.442	.0122	.503	.503	.5639	.4877
10	.0381	.0572	.0305	.0572	.0381	.0762	.0572
11	.0381	.0572	.0381	.0572	.0381	.0572	.0572
12	.0381	.0381	.0381	.0572	.0381	.0572	.0572
13	.0381	.0381	.0381	.0572		.0572	.0572
14	.0381	.0381	.0381	.0572	.0381	.0572	.0381
15	.0381	.0572	.0381	.0572	.0572	.0572	.0572
16	.0381	.0572	.0381	.0762	.0572	.0572	.0572
17	.0381	.0762	.0381	.0762	.0572	.0572	.0572
18	.0381	.0762	.0762	.0762	.0572	.0762	
19	.0762	.1143	.1143	.0953	.1334	.1143	
20	.0762	.1143	.1143	.1334	.1334	.1334	
21	.1143	.1143	.1143	.1143	.1143	.1143	.1334
22	.0762	.0762	.0762	.0953	.1143	.1143	.1143
23	.0381	.0953	.0381	.0953	.1143	.0953	.1143
24	.3048	.2743		.3048	.0762	.0953	.0953
Max	.5487	.4877	.5639	.5487	.6249	.5792	.5487
Min	.0381	.0381	.0122	.0572	.0381	.0572	.0381
Avg	.2124	.2104	.1649	.2047	.2207	.2155	.2214

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054113 / ASARDOH

Feeder No / Name : 202 / Asardoha

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2286	.2667	.1905	.2286	.2667	.2667
2	.2667	.1905	.2667		.2477	.2667	.2477
3	.2858	.1905	.3239		.2858	.2858	.2858
4	.362	.3429	.4382	.3429	.362	.362	.3239
5	.4001	.4191	.4954	.4191	.4382	.4191	.4001
6	.4572	.4572	.5335	.4954	.4763	.4763	.4763
7	.4954	.4191	.5335	.4572	.5335	.4954	.5144
8	.4191	.4572	.4572	.4954	.4191	.4191	.4191
9	.4001	.3048		.4001	.2858	.381	
10	.3658	.4268	.3963	.3353	.3963	.4268	
11	.4572	.442	.4268	.3506	.1219	.442	
12	.5182	.442	.4268	.381	.0762	.442	
13	.4877	.4572	.4877	.442		.4572	
14	.4268	.4115	.5182	.3658	.3353	.4572	
15	.3963	.3506		.3658	.442	.4572	
16	.4877	.381	.3963		.4877	.4572	
17	.5182	.3963	.4877	.1334	.4572	.5639	
18	.1524	.1524	.1905	.1715	.1905	.3429	
19	.3048	.4763	.4572	.2667	.4382	.381	
20	.381	.4763	.4954	.362	.4191	.4572	
21	.4191	.381	.4191	.381	.381	.362	.381
22	.3429	.362	.3429	.2858	.3239	.3239	
23	.2667	.3048	.3048	.2667	.3239	.2858	
24	.2667	.2286	.2667	.2286	.2286	.2667	.2667
Max	.5182	.4763	.5335	.4954	.5335	.5639	.5144
Min	.1524	.1524	.1905	.1334	.0762	.2667	.2477
Avg	.3810	.3624	.4060	.3398	.3434	.3956	.3582

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054113 / ASARDOH

Feeder No / Name : 203 / Rui dharur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.2134	.2286	.1829	.2096	.2286	.2477
2	.1677	.2439	.2096		.2439	.1524	.1715
3	.1981	.2743	.2439		.2591	.2743	.1829
4	.2439	.2743	.2743	.2439	.3048	.3048	.2286
5	.2896	.3048	.3048	.2743	.3201	.3658	.2896
6	.3201	.3353	.3353	.3353	.3506	.3963	.3963
7	.3506	.3963	.4115	.3048	.4115	.3963	.442
8	.2591	.3658	.4115	.3658	.3963	.381	.4725
9	.1981	.3048	.4268	.3506	.3201	.3506	
10	.1905	.1715	.1219	.1524	.2477	.2096	
11	.1524	.1715	.1524	.1715	.1334	.1905	
12	.1524	.1905	.1143	.1715	.1334	.1715	
13	.1143	.1715	.0762	.1524		.1905	
14	.1143	.1905	.0762	.1524	.1715	.2096	
15	.1524	.2096	.1143	.1715	.1905	.2096	
16	.1524	.2096	.1524	.1905	.1715	.2286	
17	.1905	.2286	.1905	.1715	.2286	.2286	
18	.1524	.2286	.2286	.2096	.2286	.381	
19	.3429	.4572	.4191	.3239	.4954	.4382	
20	.4191	.4763	.4572	.4191	.4382	.5144	
21	.4572	.4382	.4191	.381	.381	.381	.362
22	.381	.4001	.3048	.3239	.362	.3239	.3048
23	.1905	.2858	.2667	.2858	.2858	.2667	.3048
24	.1524	.1829		.1524	.2286	.2667	.2477
Max	.4572	.4763	.4572	.4191	.4954	.5144	.4725
Min	.1143	.1715	.0762	.1524	.1334	.1524	.1715
Avg	.2289	.2802	.2583	.2494	.2831	.2942	.3042

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054002 / KAIJ

Feeder No / Name : 201 / Town-I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	1.2803		1.1888	1.2803			
7	1.3717						
9							1.3661
12					1.3477		
14	1.3306	1.5524					
18	1.5546		1.5546			1.0059	1.4815
19				1.2986			
20	1.4632						
24	.9145		.8779	.9145			
Max	1.5546	1.5524	1.5546	1.2986	1.3477	1.0059	1.4815
Min	.9145	1.5524	.8779	.9145	1.3477	1.0059	1.3661
Avg	1.3192	1.5524	1.2071	1.1645	1.3477	1.0059	1.4238

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054002 / KAIJ

Feeder No / Name : 202 / Tambva

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	03-MAY-17	04-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.2743		.2743		
7	.2743				
9					.1524
18	1.3717	1.2803		.0747	.084
20	1.2803				
24	.1829	.1646	.1829		
Max	1.3717	1.2803	.2743	.0747	.1524
Min	.1829	.1646	.1829	.0747	.084
Avg	.6767	.7225	.2286	.0747	.1182

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054002 / KAIJ

Feeder No / Name : 204 / Massajog Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	02-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)
9		.7033
14	.5487	
Max	.5487	.7033
Min	.5487	.7033
Avg	.5487	.7033

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054002 / KAIJ

Feeder No / Name : 205 / Town-II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	1.8671		1.8484	2.0538			
7	1.8671						
9							2.0682
12					2.0019		
14	1.8484	1.587					
17				1.8858			
18	2.0538		2.0538			1.9589	1.6817
20	1.9605						
24	1.4937		1.531	1.4937			
Max	2.0538	1.587	2.0538	2.0538	2.0019	1.9589	2.0682
Min	1.4937	1.587	1.531	1.4937	2.0019	1.9589	1.6817
Avg	1.8484	1.587	1.8111	1.8111	2.0019	1.9589	1.8750

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054002 / KAIJ

Feeder No / Name : 206 / Water supply

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.5487			.3658			
7	.5487						
9							.2229
12					.5668		
14	.3521	.1021					
17				.5138			
18	.4572		.0914			.6036	.2915
20	.5487						
24	.3658		.2012	.3658			
Max	.5487	.1021	.2012	.5138	.5668	.6036	.2915
Min	.3521	.1021	.0914	.3658	.5668	.6036	.2229
Avg	.4702	.1021	.1463	.4151	.5668	.6036	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054002 / KAIJ

Feeder No / Name : 207 / GFS sonijawalla

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	03-MAY-17	04-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.3658	.3292	.1829		
7	.3658				
9					.2761
14	.2686				
17			.3189		
18		.1829		.2686	.3155
20	.3658				
24	.1829	.1829	.1829		
Max	.3658	.3292	.3189	.2686	.3155
Min	.1829	.1829	.1829	.2686	.2761
Avg	.3098	.2317	.2282	.2686	.2958

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054002 / KAIJ

Feeder No / Name : 208 / GFS Tambva

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	03-MAY-17	04-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.5487		.1829		
7	.4572				
9					.1905
14	.2075				
17			.2075		
18	.2743	.2743		.2477	.1905
20	.3658				
24	.1829	.1463	.1829		
Max	.5487	.2743	.2075	.2477	.1905
Min	.1829	.1463	.1829	.2477	.1905
Avg	.3394	.2103	.1911	.2477	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054015 / BANSAROLA

Feeder No / Name : 201 / Bansarola SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2						.5975	
6							1.1088
8			.8589	.8871		.8215	
10							.4012
12		.5243		.3521	.5121		
14					.4816		
15		.3658					
16				.5975	.5624		
17		.5624					
18					.5075		
20			1.1317	1.1576			
22				.9054			
24	.5975	.5601	.5415	.5415	.5658	.5658	
Max	.5975	.5624	1.1317	1.1576	.5658	.8215	1.1088
Min	.5975	.3658	.5415	.3521	.4816	.5658	.4012
Avg	.5975	.5032	.8440	.7402	.5259	.6616	.755

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054015 / BANSAROLA

Feeder No / Name : 202 / Isthal

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2					.8962	
6						1.8564
8		1.4413	1.4083		1.6712	
10						.2229
12	.2035		.2926			
14				.1753		
15	.1372					
16			.1715	.1677		
17	.2103					
18				.2804		
20		.3772	.3772			
22			.2652			
24	.2058	.1753	.1753	.2058	.2058	.1772
Max	.2103	1.4413	1.4083	.2804	1.6712	1.8564
Min	.1372	.1753	.1715	.1677	.2058	.1772
Avg	.1892	.6646	.4484	.2073	.9244	.7522

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054015 / BANSAROLA

Feeder No / Name : 203 / Kaudgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2					.3048	
6						.5906
8		.4954	.5093		.4954	
10						.6485
12	.7682		.6954	.7133		
14				.8322		
15	.8802					
16			.2286	1.0753		
17	1.0753					
18				1.1126		
20		.5175	.4481			
22			.3582			
24	.2801	.2987	.2987	.2987	.3048	.3048
Max	1.0753	.5175	.6954	1.1126	.4954	.6485
Min	.2801	.2987	.2286	.2987	.3048	.3048
Avg	.7510	.4372	.4231	.8064	.3683	.5146

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054015 / BANSAROLA

Feeder No / Name : 205 / Awasgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2					.8962	
6						1.5927
8		1.4403	1.21		1.4419	
10						.3048
12	.2614		.2286	.2641		
14				.2587		
15	.2263					
16			.2195	.2667		
17	.2614					
20		.5415	.5601			
22			.3921			
24	.3361	.3361	.2858	.3429	.3429	.3239
Max	.3361	1.4403	1.21	.3429	1.4419	1.5927
Min	.2263	.3361	.2195	.2587	.3429	.3048
Avg	.2713	.7726	.4827	.2831	.8937	.7405

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054015 / BANSAROLA

Feeder No / Name : 206 / Borisavargaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2					.3429	
6						.5906
8		.3429	.4191		.4572	
10						1.0494
12	.8962		1.0974	1.2955		
14				1.2651		
15	1.1523					
16			.3018	1.4419		
17	1.5912					
18				1.4815		
20		.5658	.4854			
22			.4668			
24	.3429	.3429	.0191	.3429	.3429	.3429
Max	1.5912	.5658	1.0974	1.4815	.4572	1.0494
Min	.3429	.3429	.0191	.3429	.3429	.3429
Avg	.9957	.4172	.4649	1.1654	.381	.6610

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054040 / YUSUFWADGAON

Feeder No / Name : 201 / Yusufwadgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2096	.2557	.2172	.2347	.2401	.2195
2		.2096		.2431	.2347	.2172	.1943
3		.2096		.2652	.2347	.2172	.2429
4		.2263		.3372	.2827	.2172	.2526
5		.2469		.3692	.3467	.3041	.2915
6		.3837		.4275	.4733	.2934	.3635
7		.4218			.4527	.4039	.3772
8	.4039	.3757		.3963	.4115	.3877	
9	.3414	.2987		.3353	.3563	.3521	
10	.8768	.9991	1.046	.9892	1.0166	.9122	
11	1.0566	1.1403	1.2045	1.1578	1.2163	1.0968	
12	1.0974	1.1511	1.1603	1.1622	1.1294	1.2155	
13	1.1161		1.094	1.1353	1.1077		
14	1.1431		1.0387	1.0974	1.086	.9945	
15	1.1915		1.0166	1.0974	1.2376		
16	1.2028		.9922		1.1077	1.1728	
17	1.2045						
18			.2324	.3829			
19			.2934	.4496			
20	.4268		.4344	.4862	.4572		
21	.3584			.3757			
22	.326			.3372			
23	.2652			.2873			
24		.2096		.2172	.2743	.2521	.2439
Max	1.2045	1.1511	1.2045	1.1622	1.2376	1.2155	.3772
Min	.2652	.2096	.2324	.2172	.2347	.2172	.1943
Avg	.7865	.4678	.7971	.5603	.6478	.5518	.2732

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054040 / YUSUFWADGAON

Feeder No / Name : 202 / Sadola

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0117	.0667	.0787	.9145	.0732	.0613
2		1.0117		.0679	1.1157	.8655	.9802
3		1.0745		.064	1.1622	.9145	1.2574
4		1.1203		1.2574	1.2203	1.0745	1.3717
5		1.166		1.4289	1.2203	1.3717	1.4289
6		1.2346		1.5224	1.1088	1.6503	1.5689
7		1.4876		1.4388	1.2574	1.5224	1.5922
8	1.3717	1.4527		1.2435	1.3016	1.5224	
9	1.326	1.29	1.3146	.084	1.0402	1.4527	
10	.0754	.0667	.0922	.084	.0762	.0754	
11	.0429	.0606	.0514	.0655	.0587	.0671	
12	.0419	.0495	.0469	.0537		.0467	
13	.0391		.0282	.0335			
14	.04		.0282	.0533	.0419	.0457	
15	.0476			.0419	.052	.0583	
16	.0486		.0412	.0533	.0514	.0583	
17	.0549		.0533	.0438			
18			.0671	.0572			
19			.096	.1048			
20	.109		.1227	.109			
21	.109			.0823			
22	.084			.0737			
23	.0732						
24		.9779		.8431	.8318	.0732	.0613
Max	1.3717	1.4876	1.3146	1.5224	1.3016	1.6503	1.5922
Min	.0391	.0495	.0282	.0335	.0419	.0457	.0613
Avg	.2474	.9234	.1674	.3863	.7635	.6795	1.0402

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054043 / 33/11 KV H.PIMPRI SS

Feeder No / Name : 201 / Pimpri borgaon Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	05-MAY-17
HR	Load (MW)
4	.6602
Max	.6602
Min	.6602
Avg	.6602

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054043 / 33/11 KV H.PIMPRI SS

Feeder No / Name : 202 / Borgaon AG

Feeder KV- 100 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	03-MAY-17
HR	Load (MW)
24	1.6454
Max	1.6454
Min	1.6454
Avg	1.6454

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054043 / 33/11 KV H.PIMPRI SS

Feeder No / Name : 204 / GFSS H.pimpri

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6			1.1203	.9335
24	.2075	.443	.5068	.5601
Max	.2075	.443	1.1203	.9335
Min	.2075	.443	.5068	.5601
Avg	.2075	.443	.8136	.7468

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054043 / 33/11 KV H.PIMPRI SS

Feeder No / Name : 205 / 11 Kv GFS Borgaon
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
4			.3772
6		.6468	.7392
24	.1829	.1867	.2801
Max	.1829	.6468	.7392
Min	.1829	.1867	.2801
Avg	.1829	.4168	.4655

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054077 / DHANEGAON

Feeder No / Name : 202 / Water supply
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	07-MAY-17
HR	Load (MW)
4	.1524
6	.1562
9	.16
Max	.16
Min	.1524
Avg	.1562

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054077 / DHANEGAON

Feeder No / Name : 203 / Dhanegaon Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	02-MAY-17	03-MAY-17	06-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
11	2.2485	2.753	2.2458
14	2.7627		
17			2.6307
Max	2.7627	2.753	2.6307
Min	2.2485	2.753	2.2458
Avg	2.5056	2.753	2.4383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054077 / DHANEGAON

Feeder No / Name : 204 / GFSS Dhanegaon

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	02-MAY-17	03-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4				.5144
5			.503	
6				.5935
8	.4668			
9		.5087		.3429
11	.3353			
17			.3429	
Max	.4668	.5087	.503	.5935
Min	.3353	.5087	.3429	.3429
Avg	.4011	.5087	.4230	.4836

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054077 / DHANEGAON

Feeder No / Name : 205 / GFSS Pathra

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	02-MAY-17	03-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4				.7011
5			.8573	
6				.8573
9		.8764		.7011
11	.5258			
17			.5258	
Max	.5258	.8764	.8573	.8573
Min	.5258	.8764	.5258	.7011
Avg	.5258	.8764	.6916	.7532

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054079 / MASSAJOG

Feeder No / Name : 201 / Massajog SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	03-MAY-17	04-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	1.5775			
13	.4973		1.9662	1.8564
14		.6478		1.8233
15			1.6575	
16				1.8233
17			1.6385	
18	.663			
Max	1.5775	.6478	1.9662	1.8564
Min	.4973	.6478	1.6385	1.8233
Avg	.9126	.6478	1.7541	1.8343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054079 / MASSAJOG

Feeder No / Name : 202 / Sangvi

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	03-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
4	.6335		
9			1.6194
13	1.3927		
16			.4144
17		.0079	
18	1.4089		
Max	1.4089	.0079	1.6194
Min	.6335	.0079	.4144
Avg	1.1450	.0079	1.0169

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054079 / MASSAJOG

Feeder No / Name : 203 / SHINDE

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	03-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
4	.0905		
13	.4049	.2429	.2972
14			.2972
15		.2372	
16			.4049
17		.3239	
Max	.4049	.3239	.4049
Min	.0905	.2372	.2972
Avg	.2477	.268	.3331

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054080 / KUMBEPHAL

Feeder No / Name : 201 / Dakephal

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	03-MAY-17
HR	Load (MW)
22	2.5548
Max	2.5548
Min	2.5548
Avg	2.5548

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054080 / KUMBEPHAL

Feeder No / Name : 202 / Janegaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	03-MAY-17
HR	Load (MW)
22	.0376
Max	.0376
Min	.0376
Avg	.0376

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054080 / KUMBEPHAL

Feeder No / Name : 203 / Kumbephal
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	03-MAY-17
HR	Load (MW)
22	.0376
Max	.0376
Min	.0376
Avg	.0376

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054080 / KUMBEPHAL

Feeder No / Name : 205 / Kumbhefal Gfss

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	03-MAY-17
HR	Load (MW)
22	.2254
Max	.2254
Min	.2254
Avg	.2254

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054104 / 33/11 KV S/S RAJEGAON

Feeder No / Name : 201 / NAHOLI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	05-MAY-17	06-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
8	.9231		1.0227
9			1.0059
16		.1086	
18		.104	
24	.5502		.1214
Max	.9231	.1086	1.0227
Min	.5502	.104	.1214
Avg	.7367	.1063	.7167

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054104 / 33/11 KV S/S RAJEGAON

Feeder No / Name : 202 / RAJEGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	05-MAY-17	06-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
8	.3142		.6344
9			.5548
10	.128		
18		.9122	
24	.1086		.6371
Max	.3142	.9122	.6371
Min	.1086	.9122	.5548
Avg	.1836	.9122	.6088

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054104 / 33/11 KV S/S RAJEGAON

Feeder No / Name : 203 / SHIRURGHAT SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	05-MAY-17	06-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
10	.8573		.7716
13		.7274	
14		.7343	
16		.7537	
24			.2353
Max	.8573	.7537	.7716
Min	.8573	.7274	.2353
Avg	.8573	.7385	.5035

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054132 / Devgoan

Feeder No / Name : 201 / Devgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3605		.3277	.3277		.2622
2	.3605		.3605	.3277		
3	.3932		.3277	.3605		.2622
4	.3605		.3605	.3277		
5	.4588		.5243	.4588		.4588
6	.5571		.6554	.5898		.4915
7						.4915
8						.5898
9						.3277
13	.8192	.7865	.852			
14	.6226		.7865			
15	.7537	.6226	.8192			
16	.7537	.4915	.7865		.0983	
17		.6882	.8192			
18	.852	.7865	.8192		.1638	
19		.8848	.8848			
20		.8192	.5243			
21		.3932	.3932			
22		.3932	.3605			
23	.852	.3605	.3605			
24	.3605		.3277	.3277		
Max	.852	.8848	.8848	.5898	.1638	.5898
Min	.3605	.3605	.3277	.3277	.0983	.2622
Avg	.5773	.6226	.5717	.3886	.1311	.4120

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054132 / Devgoan

Feeder No / Name : 202 / Limbachiwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0594		.0594	.0594		.0297
2	.0594		.0594	.0594		
3	.0594		.0594	.0594		.0297
4	.0594		.0594	.0594		.0297
5	.3567		.2972	.3567		
6	.4458		.4161	.4755		
7	.4755		.5647	.5053		
8	.5053		.535	.535		
9	.5647		.4755	.5053		
10	.5944	.5647	.535	.4755	.3864	
11		.535	.535	.4458	.4458	
12	.4458	.208	.5053	.4161	.5053	
13					.4755	
14					.4458	
15					.5053	
16					.5053	
17					.535	
18					.0297	
19	.0594	.1189	.1189			
20		.1189	.1189			
21		.0892	.0892			
22		.0892	.0892			
23		.0594	.0594			
24	.0594		.0594	.0594		
Max	.5944	.5647	.5647	.535	.535	.0297
Min	.0594	.0594	.0594	.0594	.0297	.0297
Avg	.2880	.2229	.2576	.3086	.4260	.0297

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054132 / Devgoan

Feeder No / Name : 203 / Dahiphal SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1326		.1658	.1326		
2	.1658		.1326	.1658		
3	.1326		.1326	.1326		.0995
4	.1326		.1658	.1658		.0995
5	.1658		.1658	.1989		
6	.1658		.1989	.2321		
7	.2652		.3315	.3315		
8	.2652		.2984	.2984		
9	.2984		.2984	.3315		
10	.2652	.2321	.2652	.2652	.1326	
11		.2652	.2652	.2984	.1989	
12	.2486	.2321	.2321	.2321	.2321	
13					.2652	
14					.2652	
15					.2321	
16					.2321	
17					.2652	
18					.0332	
19		.2321	.1326			
20		.1989	.2321			
21		.2321	.1989			
22		.1989	.1989			
23		.1658	.1989			
24	.1326		.1658	.1658		.0995
Max	.2984	.2652	.3315	.3315	.2652	.0995
Min	.1326	.1658	.1326	.1326	.0332	.0995
Avg	.1975	.2197	.2100	.2270	.2063	.0995

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054132 / Devgoan

Feeder No / Name : 204 / Express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0179		.0179	.0179		
2	.0179		.0179	.0179		.0158
3	.0179		.0179	.0179		
4	.0179		.0179	.0179		.0158
5	.0179		.0179	.0179		
6	.0179		.0179	.0179		.0158
7	.0179		.0179	.0179		.0158
8	.0179		.0179	.0179		.0158
9	.0179		.0179	.0179		.0158
10	.0179	.0179	.0179	.0179	.0158	
11		.0179	.0179	.0179		
12	.0158	.0179	.0179	.0179	.0158	
13		.0179	.0179		.0158	
14			.0179			
15		.0179	.0179		.0158	
16	.0158	.0179	.0179			
17		.0179	.0179			
18	.0158	.0179	.0179		.0158	
19		.0179	.0179			
20		.0179	.0179			
21		.0179	.0179			
22		.0179	.0179			
23		.0179	.0179			
24	.0179		.0179	.0179		.0158
Max	.0179	.0179	.0179	.0179	.0158	.0158
Min	.0158	.0179	.0179	.0179	.0158	.0158
Avg	.0175	.0179	.0179	.0179	.0158	.0158

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054136 / Waghebabulgaon

Feeder No / Name : 202 / Bandewadi
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAY-17	05-MAY-17	06-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
24	.6775	.6619	.6619
Max	.6775	.6619	.6619
Min	.6775	.6619	.6619
Avg	.6775	.6619	.6619

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054136 / Waghebabulgaon

Feeder No / Name : 203 / Waghebabulgaon

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAY-17	05-MAY-17	06-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
24	.208	.16	.144
Max	.208	.16	.144
Min	.208	.16	.144
Avg	.208	.16	.144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

MAJALGAON S/DN.[423] BU 2593

Substation No/ Name :- 054001 / MAJALGAON

Feeder No / Name : 202 / 11KV GANGAMASALA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	07-MAY-17
HR	Load (MW)
24	.188
Max	.188
Min	.188
Avg	.188

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

MAJALGAON S/DN.[423] BU 2593

Substation No/ Name :- 054001 / MAJALGAON

Feeder No / Name : 205 / 11 KV Express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	07-MAY-17
HR	Load (MW)
24	.035
Max	.035
Min	.035
Avg	.035

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

MAJALGAON S/DN.[423] BU 2593

Substation No/ Name :- 054001 / MAJALGAON

Feeder No / Name : 206 / 11 KV Gangamasala Gaothan

GAOTHAN FEEDER

GFS Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6164	1.6682	1.6804	1.7177	1.7383	1.7619	1.7856
2	1.5417	1.611	1.6408	1.6629	1.6865	1.7139	1.7193
3	1.4952	1.5836	1.608	1.6286	1.6369	1.6735	1.6804
4	1.5051	1.5958	1.5836	1.6316	1.6423	1.6629	1.6728
5	1.6514	1.7002	1.7139	1.733	1.7414	1.7604	1.7977
6	1.8831	1.9456	1.9319	1.9593	1.9334	1.9349	1.9288
7	1.9654	2.0012	2.0584	1.3634	2.0104	2.0492	2.0332
8	1.8854	2.0645	2.0851	2.0576	2.0561	2.1117	2.0073
9	1.813	1.9006	2.0241	1.9311	1.9852	1.922	1.893
10	1.8511	1.9052	1.9639	1.9044	1.9768	1.9425	1.877
11	1.7878	1.9532	1.9532	1.816	1.9875	1.9303	1.8023
12	1.8473	1.8359	1.8488	1.7734	2.0111	1.8793	1.701
13	1.7154	1.8054	1.7878	1.7322	1.9303	1.8785	1.6857
14	1.7032	1.8359	1.8259	1.6636	1.8214	1.8694	1.7093
15	1.7802	1.9075	1.8976	1.8054	1.8625	1.5127	1.8305
16	1.8549	1.893	1.8762	1.8191	1.8907	1.9464	1.8602
17	1.9166	1.9113	1.9761	.9816	.9267	1.9364	1.8801
18	2.0363	1.9624	2.1087	2.0027	1.5463	2.1613	1.9243
19	2.2779	2.2337	2.1948	2.2893	2.4249	2.3518	2.0965
20	2.2177	2.207	2.2215	2.2131	2.3137	2.2276	2.079
21	2.1529	2.1216	2.069	2.1209	2.1895	2.1216	1.9243
22	2.0515	2.0774	2.0256	2.0614	2.1064	2.1072	2.0005
23	1.8968	1.9243	1.9486	1.9121	1.9791	1.9608	1.9281
24	1.7665	1.784	1.7894	1.7993	1.8511	1.8671	1.829
Max	2.2779	2.2337	2.2215	2.2893	2.4249	2.3518	2.0965
Min	1.4952	1.5836	1.5836	.9816	.9267	1.5127	1.6728
Avg	1.8422	1.8929	1.9089	1.8158	1.8854	1.9285	1.8602

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

MAJALGAON S/DN.[423] BU 2593

Substation No/ Name :- 054001 / MAJALGAON

Feeder No / Name : 207 / 11 KV Kalegaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.681	.3132	2.5636	2.6665	2.899	3.1169	3.5292
2	2.6757	.3864	2.7122	2.6901	2.9332	3.0224	3.5886
3	2.6307	.3269	2.713	2.7389	2.9759	3.0087	3.5711
4	2.5796	.3201	2.6688	2.6719	2.9172	3.027	3.5414
5	2.5309	.3307	2.5941	2.5385	2.7831	2.8227	3.4537
6	2.4844	.2987	2.6757	2.6947	2.8647	3.0674	3.4476
7	2.4448	.3765	2.7054	2.6558	2.8479	2.8723	3.4195
8	.5411	1.9342	2.6056	2.5865	2.8662	2.9363	2.1399
9	.3849	2.303	2.7244	2.7702	2.8654	3.0338	1.733
10	.3231	2.5568	3.0453	3.1664	3.1664	3.3196	1.3649
11	.3788	2.8166	3.1474	3.0125	3.2998	3.3562	1.2346
12	.4054	2.8936	3.0719	3.0537	3.1421	3.4255	1.089
13	.3833	2.7976	3.0262	3.0095	3.0224	3.2419	1.0524
14	.3856	2.7846	3.0392	3.1032	3.1992	3.1931	1.0288
15	.3574	2.9462	3.1085	3.0773	3.2366	3.1268	1.054
16	.3567	3.1047	3.1756	3.1085	3.2419	3.2457	1.0791
17	.3544	2.9835	3.2068	3.1939	3.2419	3.2106	1.0204
18	.3467	3.0963	3.2015	3.1482	3.0849	3.296	.993
19	.3567	3.0529	3.1466	3.187	3.3074	3.1939	.9808
20	.346	2.8669	2.9774	3.0239	3.1984	3.1497	1.0273
21	.362	2.8197	2.9904	3.107	2.9424	3.2358	.8909
22	.3711	2.7984	2.7793	2.9843	3.0567	2.8913	.8794
23	.3582	2.8753	2.9782	3.136	3.1626	3.0117	.8909
24	.3353	2.7389	3.011	3.0826	3.1337	2.947	.8672
Max	2.681	3.1047	3.2068	3.1939	3.3074	3.4255	3.5886
Min	.3231	.2987	2.5636	2.5385	2.7831	2.8227	.8672
Avg	1.0156	2.0717	2.9112	2.9336	3.0579	3.1147	1.8282

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

MAJALGAON S/DN.[423] BU 2593

Substation No/ Name :- 054001 / MAJALGAON

Feeder No / Name : 208 / Manjarth GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	07-MAY-17
HR	Load (MW)
24	1.4373
Max	1.4373
Min	1.4373
Avg	1.4373

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

MAJALGAON S/DN.[423] BU 2593

Substation No/ Name :- 054023 / MALIPARGAON

Feeder No / Name : 207 / SAWARGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717		1.4575		1.7204		.4915
2	1.5384		1.7004		1.8842		1.5565
3	1.7004		1.7814		2.0481		1.8842
4	1.7814		1.8623				2.0481
5	1.8623		2.0243				2.13
6	2.1052		2.0243	2.3053	2.0481		
7	2.1052			2.5339	2.13		1.7204
8	1.8623			2.452	2.13		
9				2.13	2.1628		1.8842
10		.6478	.4854	.4915		.5243	
11		.6478		.4588		.5735	
12		.6154		.426		.6554	
13		.583				.5898	.5083
14		.583					.5258
15		.4858					.5083
16		.4534					.4508
17		.4858	.7011			.6554	
18		.6478	.7602			.6554	
19		.6478		.7865		.7373	.7455
20		.6478	.7888	.7373		.7373	
21		.6478	.8328	.7209		.6554	
22				.6882		.6226	
23		.5668		.6226		.5735	
24	1.0059		1.4575		1.6385		.4915
Max	2.1052	.6478	2.0243	2.5339	2.1628	.7373	2.13
Min	1.0059	.4534	.4854	.426	1.6385	.5243	.4508
Avg	1.7036	.5892	1.323	1.1961	1.9703	.6345	1.1496

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

MAJALGAON S/DN.[423] BU 2593

Substation No/ Name :- 054102 / 33/11 KV Kesapuri

Feeder No / Name : 201 / 11 KV Sadolla

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	05-MAY-17	06-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7					.2286
10			.176	.1905	
11				.2286	.2195
12		.2058		.2286	.2515
13		.1677			
14		.1677			.2743
15		.1524			.2629
16		.2286	.285		
17	.2	.2382	.2785	.1677	
Max	.2	.2382	.285	.2286	.2743
Min	.2	.1524	.176	.1677	.2195
Avg	.2	.1934	.2465	.2039	.2474

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

MAJALGAON S/DN.[423] BU 2593

Substation No/ Name :- 054102 / 33/11 KV Kesapuri

Feeder No / Name : 206 / Govindwadi GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2174	.9602	1.1416	1.2483	.9907	1.1683
2	1.2003	.9145	1.1256	1.2003	.9907	1.1616
3	1.2003	.9145	1.2349	1.2136	1.0364	1.1899
4	1.3032	1.2003	1.3427	1.2689	1.0669	1.3347
5	1.3375	1.5089	1.6213	1.2803		1.4058
6	1.3717		1.704		1.4022	
7	1.406		1.6525		1.2193	
8			1.6404		1.1888	
9		1.4403			1.1584	
10		1.2632		1.2193	1.2453	1.1888
11				1.1279	1.3235	1.3123
12					1.3715	1.4255
15	.9755			.9755	1.0669	1.4754
16	1.166	1.6205		.9755		1.4403
17	1.3717	1.562		1.2041		1.5023
18	1.5089	1.6461		1.2803	1.6309	1.5432
19	1.6118	1.6297		1.3717	1.7833	
20		1.6015		1.3717	1.7912	
21		1.5631		1.3108	1.6297	
22	1.2346	1.2559		1.0974	1.3047	
23		1.1149		1.0669	1.1256	
24	1.2517	1.0802	1.1349	1.2689	.9907	1.1016
Max	1.6118	1.6461	1.704	1.3717	1.7912	1.5432
Min	.9755	.9145	1.1256	.9755	.9907	1.1016
Avg	1.2969	1.3297	1.3998	1.2048	1.2798	1.3269

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

MAJALGAON S/DN.[423] BU 2593

Substation No/ Name :- 054108 / 33/11 KV Mogara

Feeder No / Name : 202 / 11 KV Dake Pimpari SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		1.1576	1.0269	1.3817	1.4632	1.1949
8	1.7002	1.6263	1.1016	1.5524	1.6632	
12			.1478	.3077		.4207
16	.2957	.2427		.2561	.2033	.3142
20	.5601	.2801	1.3121	.4572	.4668	.6401
24	1.1016	1.0456	.6908	1.0719	.4024	.4108
Max	1.7002	1.6263	1.3121	1.5524	1.6632	1.1949
Min	.2957	.2427	.1478	.2561	.2033	.3142
Avg	.9144	.8705	.8558	.8378	.8398	.5961

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

MAJALGAON S/DN.[423] BU 2593

Substation No/ Name :- 054108 / 33/11 KV Mogara

Feeder No / Name : 203 / 11 KV Shukla-Tirtha SINGLE PHASING
 Limgaon Feeder KV- 11 /
 OUTGOING

DATE	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.4668	.462	.5041	.5121	.4481
8	.5359	.462	.5788	.6161	.5359	
11		1.2136				
12	1.9589		1.9791	2.0814	1.922	1.4815
16	1.7556	1.1883			1.6078	1.6078
18				1.6461		
20	.6722	.5601	.6908	.5304	.6161	.6767
24	.4108	.4108	.4481	.4668	.4938	.4668
Max	1.9589	1.2136	1.9791	2.0814	1.922	1.6078
Min	.4108	.4108	.4481	.4668	.4938	.4481
Avg	1.0667	.7169	.8318	.9742	.9480	.9362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

MAJALGAON S/DN.[423] BU 2593

Substation No/ Name :- 054135 / GANGAMASLA

Feeder No / Name : 201 / GANGAMASLA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353			.8048	.8383		
2	.3688			.8383	.8718	.8225	.7889
3	.4862		.705	.8718	.9389	.856	.8392
4	.503			.9556	.9724	1.091	.9232
5	.9892			1.0059	1.1233	1.1582	1.0071
6	1.2574			1.0898	1.2574	.7889	
7	1.6263		1.4938	1.3413	1.3077	1.7288	
8	1.7604		1.8967	1.5927	1.6095	1.6449	
9		1.4938	1.796	1.5257	1.4922	1.5946	
10		.4532	.4868		.6043	.4364	
11		.7217			.7217	.6714	
12		.6882		.6036	.6378	.6714	.5371
13		.6546		.6036	.6714	.705	.6714
14		.5203		.5868	.6043	.6546	.7553
15		.5203		.6371	.5539	.4868	.6714
16		.5539	.47		.5707	.5203	.6043
17		.5371	.4532		.5875	.5539	.6714
20				.8048			
24	.3185		.7385	.7712	.788		
Max	1.7604	1.4938	1.8967	1.5927	1.6095	1.7288	1.0071
Min	.3185	.4532	.4532	.5868	.5539	.4364	.5371
Avg	.8495	.6826	1.005	.9355	.8973	.8990	.7469

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

MAJALGAON S/DN.[423] BU 2593

Substation No/ Name :- 054135 / GANGAMASLA

Feeder No / Name : 203 / GANGAMASLA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0608		1.1492	1.1669	1.0962	1.273	1.2023
2	1.0431		1.0962	1.2023	1.0608	1.1315	1.0785
3	.9901		1.1669	1.2376	1.1492	1.0431	1.1492
4	1.0431		1.2199	1.326	1.1846	1.1139	1.2023
5	1.326		1.2907	1.3437	1.3967	1.2199	1.2376
6	1.6443		1.6973	1.4144	1.6796	1.3791	
7	1.6619		1.6266	1.5028	1.8034	1.6796	
8	1.5735		1.4675	1.5912	1.3791	1.5205	
9		.884	1.3614	1.326	1.2376	1.4675	
10		.9724		1.1139	1.0608	1.273	
11		.831		.9901	1.0962	1.2023	
12				.9017			1.2376
13				.884			1.2023
14				.9901			1.1492
15		1.0785		1.0078	1.0255	1.1315	1.2376
16		1.0608	1.2199		1.0962	1.2199	.7249
17		1.0255	1.273		1.2376	1.2199	.7779
18		1.2553	1.4144		1.3791	1.3967	1.3614
19		1.3791	1.6266		1.6443	1.5028	1.6619
20		1.326	1.5735	1.6443	1.5028	1.5912	1.326
21		1.3967	1.4144		1.4321	1.4144	1.2023
22		1.2553	1.3967		1.326	1.2553	1.1492
23		1.1846			1.2376	1.326	1.0255
24	1.1315		1.1139	1.2376	1.0785	1.2376	
Max	1.6619	1.3967	1.6973	1.6443	1.8034	1.6796	1.6619
Min	.9901	.831	1.0962	.884	1.0255	1.0431	.7249
Avg	1.2749	1.1374	1.3593	1.2283	1.2907	1.3142	1.1721

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054042 / 33/11 KV OPH PARLI S/S

Feeder No / Name : 201 / 11kv CHANDAPUR AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11				.7602
16		.7545		
18	.3185		.0716	
19			.0905	
20			.1227	
Max	.3185	.7545	.1227	.7602
Min	.3185	.7545	.0716	.7602
Avg	.3185	.7545	.0949	.7602

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054042 / 33/11 KV OPH PARLI S/S

Feeder No / Name : 202 / 11 KV GANESHPAR FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		1.6655		
11				1.8446
16		1.9879		
18	2.4893		2.2862	
19			2.371	
20			2.2081	
Max	2.4893	1.9879	2.371	1.8446
Min	2.4893	1.6655	2.2081	1.8446
Avg	2.4893	1.8267	2.2884	1.8446

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054042 / 33/11 KV OPH PARLI S/S

Feeder No / Name : 204 / 11 KV GFSS CHANDAPUR
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAY-17	02-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.0914		
11				.1595
16		.1698		
18	.1734		.3366	
19			.197	
20			.2195	
Max	.1734	.1698	.3366	.1595
Min	.1734	.0914	.197	.1595
Avg	.1734	.1306	.2510	.1595

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054042 / 33/11 KV OPH PARLI S/S

Feeder No / Name : 205 / 11 KV Kalratri Devi Feeder SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3535	1.2704	1.4213		1.5539	1.4807	1.5211
2	1.3123	1.2772	1.3794		1.4914	1.4487	1.4579
3	1.2811	1.2308	1.358		1.4579	1.4152	1.4114
4	1.2673	1.2087	1.3382		1.4647	1.4038	1.4083
5	1.3291	1.246	1.4137	1.3748	1.5554	1.454	1.5051
6	1.6187	1.3923	1.6209	1.6697	1.7474	1.6781	1.7261
7	1.816	1.7055	1.8541	2.0172	2.0241	1.9204	1.9669
8	1.9052	3.421	1.9997	2.0104	2.0972	2.0027	2.0165
9	1.7307	1.669	1.9936	1.9928	2.1094	2.0203	1.9913
10	1.5554	1.5935	1.858	1.7924	1.9479	1.8496	1.7741
11	1.4967	1.3931	1.6659	1.8023	1.7932	1.7604	3.1062
12	1.4396	1.4518	1.5021	1.6095	1.7147	1.5859	1.5493
13	1.2917	1.3809	1.4259	1.4571	1.7231	1.5485	1.3885
14	1.3954	1.2955	1.3656	1.4228	1.5089	1.4807	1.3656
15	1.4228	1.3367	1.4304	1.4739	1.4746	1.4373	1.3588
16	1.4335	2.6963	1.3877	1.448	1.5249	1.4609	1.4525
17		1.4723	1.5653	1.5821	1.5767	1.5036	1.6095
18	3.7357	1.5813	1.5219	1.7139	1.6309	3.4202	1.6751
19	2.0218	1.8572	1.8061	1.9319	1.8503	3.6214	1.8633
20	2.0523	2.0294	1.8351	1.9944	2.0759	3.5277	1.9334
21	1.9243	1.8198	1.6811	1.9006	1.9753	1.8404	1.813
22	1.7665	1.7284	1.6819	1.7977	1.7528	1.752	1.7375
23	1.627	1.6484		1.7139	1.6789	1.7185	1.6674
24	.4283	1.5074		1.6491	1.6011	1.6057	1.5859
Max	3.7357	3.421	1.9997	2.0172	2.1094	3.6214	3.1062
Min	.4283	1.2087	1.3382	1.3748	1.4579	1.4038	1.3588
Avg	1.6176	1.6339	1.5957	1.7177	1.7221	1.8724	1.7035

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054048 / 33/11 KV NATHRA S/S

Feeder No / Name : 201 / 11 KV PANGRI FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0039		.0333	.0356	.0333		
2	.0348		.0333	.0356	.0333		
3	.0348	.0364	.0333	.0356	.0333		.0364
10	1.39	1.2503		.9836	1.0553		1.31
11	2.1106	1.3489	1.7776	1.267	1.8922		1.6739
12	2.0677	1.5504	1.742	1.317	1.8195	1.8195	1.7467
13	1.8863	1.6671	1.7064	1.3336	1.6375		1.5284
14	1.8195	1.6018	1.7064	1.367	1.492		1.4192
15	1.6375	1.5003	1.6887	1.3336	1.4192		1.3828
16	1.7467		1.5998		1.4192	1.492	1.3828
17	1.7467	1.4837	1.422		1.492		1.4192
18	.0182			1.0002	.0182		.0182
19		1.467		1.1336	.0182		
20		.0333		.0333		.0364	
21	.0364	.0333		.0291			
22	.0364	.0333	.0356	.0291	.0182		
23		.0333		.0333	.0182		.0182
24	.0348	.0364	.0333		.0333	.0182	.0364
Max	2.1106	1.6671	1.7776	1.367	1.8922	1.8195	1.7467
Min	.0039	.0333	.0333	.0291	.0182	.0182	.0182
Avg	.9736	.8625	.9843	.6645	.7771	.8415	.9977

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054048 / 33/11 KV NATHRA S/S

Feeder No / Name : 203 / 11 KV GFSS Nathra Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2037	.2225	.2222	.2037	.1852	.2225	
2	.2222	.2225	.2778	.2222	.1852	.2225	
3	.2593	.2225	.3333	.2593	.3704	.2225	
4	.3519	.3708	.5556	.3333	.6481	.5561	.3151
5	.5741	.6488	.8333	.7407	.7778	.5561	
6	.6667	.7786				.6859	
10	.3704	.2769		.3704	.4078		.3708
11	.2595			.2407	.2781	.2781	.3337
12	.2225	.4259					.2595
13	.2225		.2778				.2225
14	.1854						.2225
15	.1854	.2778	.1852	.2407	.2225		.2225
16	.2225	.2593		.2407	.2225	.241	.2225
17	.2966	.2222		.2407			.2225
18	.3337	.3519		.4074	.2225		.2966
19	.5191	.5185		.5185	.6303		.482
20	.4634	.5185	.4074	.4815	.5561	.5932	
21	.3337	.4815		.3333	.4634		
22	.2781	.4259	.2778	.2778	.2966		.3337
23	.2595	.3519	.2222	.2222	.2781	.2781	.2781
24	.2037	.2225	.2222	.2037	.1852		.2225
Max	.6667	.7786	.8333	.7407	.7778	.6859	.482
Min	.1854	.2222	.1852	.2037	.1852	.2225	.2225
Avg	.3159	.3777	.3468	.3257	.3706	.3856	.2860

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054048 / 33/11 KV NATHRA S/S

Feeder No / Name : 204 / 11 KV Pangri GFSS Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5376	.5113		.4924	.4825	
2	.5207	.5561	.5681	.5201	.5681	.4825	
3	.4304	.5567	.7954	.5573	.7764	.5567	
4	.8925	.7423	1.0984		.909	.8907	.8916
5	1.1529	1.0763	1.212	1.1145	1.0226	1.0763	1.1505
10	.9669	.8704	.8916	.8143	.8944		.7794
11	.7267	.7407		.5871	.6521		.5932
12	.6708	.7037	.5944	.5303	.6309	.5938	.5561
13	.5963	.5926	.5573	.5113	.5938		.5561
14	.559	.5741	.5944	.4924	.5567		.5561
15	.6335	.5556	.5944	.5871	.5196		.5561
16	.6335	.5926	.5944	.6249	.5822	.4109	.5561
17	.7453	.6628	.5944	.6628	.6309		.5561
18	.7826	.8143	.8916	.8143	.7052		.6303
19	1.0227	.9279		1.0226	.9835		
20	.9316	1.0226	.9659	1.0037		.8907	
21	.7639	.909		.8143	.7423		
22		.7575	.6687	.6818	.6124		
23	.6488	.6818	.5573	.5303	.5567		.6488
24	.4835	.5376	.5113		.4924	.4825	.483
Max	1.1529	1.0763	1.212	1.1145	1.0226	1.0763	1.1505
Min	.4304	.5376	.5113	.4924	.4924	.4109	.483
Avg	.7312	.7206	.7177	.6982	.6801	.6518	.6549

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054048 / 33/11 KV NATHRA S/S

Feeder No / Name : 205 / Wadkhel AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5713	.355		.0319	.0337	.0323	.0323
2	.5713	.355			.5058	.355	.355
3	.6049	.355	.725	.0319	.5564	.355	.4034
4	.6385	.4034			.5901	.4841	
5	.6722	.4841			.6239	.5648	
6	.773	.5487			.6913	.6455	.7746
7	.941	.71	1.0622	.8919	.7756	.9037	1.0005
8	.8738	.8069	1.0285		.8431	.9037	.8875
9	.5377	.8875	.9948	.9442	.8093	.8391	.8391
18	.0161	.0337		.0325			
19		.0337		.0337	.0323		.0161
20		.0337	.0319	.0337		.0323	
21	.0484	.0337	.0319	.0337	.0323		
22	.0323	.0337	.0319	.0337			
23	.0323	.0337	.0319	.0337		.0323	.0484
24	.5209	.355	.6744		.0337	.0323	.0323
Max	.941	.8875	1.0622	.9442	.8431	.9037	1.0005
Min	.0161	.0337	.0319	.0319	.0323	.0323	.0161
Avg	.4881	.3414	.5125	.2101	.4606	.4317	.4389

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054048 / 33/11 KV NATHRA S/S

Feeder No / Name : 206 / Pimpalgaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686		.173	.1463	.1211	.2197	
2	.1097		.173	.1646	.1557	.2197	
3	.1829		.2595	.2195	.2595	.2197	
4	.3292		.3114	.2926	.2941	.2746	.2746
5	.4755			.5121	.3633	.4577	
9		.4082	.173				
10	.3658	.3114	.4024	.2595	.4028		.3113
11	.2197	.2595	.2561	.173	.2746		.2197
12	.2014	.2422	.1829	.173	.2197	.2197	.2197
13	.1831	.2076	.1829	.1903	.2197		.2014
14	.1831	.1903		.1903	.2014		.2014
15	.1831	.173	.2195	.173	.2197		.1831
16	.1831	.1557	.2195	.173	.2014	.2197	.1831
17	.1648	.1384		.173	.2014		.2197
18		.2076		.2076	.2197		.2197
19	.2929	.346	.3292	.2422	.3285		.3296
20	.2929	.4152	.2926	.346	.3296	.4028	
21	.3113	.346		.2941	.2783		
22	.2746	.3114		.2249	.2412		.3296
23	.2746	.2768	.1463	.1211	.238	.2563	.2563
24	.1097	.1465	.173		.1211	.2197	.2197
Max	.4755	.4152	.4024	.5121	.4028	.4577	.3296
Min	.0686	.1384	.1463	.1211	.1211	.2197	.1831
Avg	.2319	.2585	.2330	.2251	.2445	.2710	.2406

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054048 / 33/11 KV NATHRA S/S

Feeder No / Name : 207 / Pimpalgaon AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0334	1.3332		.1749	.1166	.1778	
2	1.0893	1.3332		.1457	.9474	1.422	1.1021
3	1.1172	1.3903	1.2097	.1457	1.0931	1.5109	
4	1.1451	1.422		1.166	1.2826	1.7064	1.2443
5	1.1731	1.7776		1.1951	1.3555	1.7064	
6	1.2848			1.3846	1.4721	1.8664	
7	1.4384	2.0975	1.6907	1.6615	1.6032	2.1331	
8	1.4943	2.0442	1.6907	1.6615	1.6907	2.1331	1.5998
9	1.4663	1.9553	1.7052	1.5741	1.6324	1.9909	1.9375
18		.0874		.0874			
19	.1067	.102		.1166	.1955		.1422
20		.2186		.1895			
21	.1778	.1749		.1603		.1778	
22		.1457	.1867	.1457	.1778		
23	.1778	.1457	.1867	.1457			.1778
24	.9496	1.3332	1.1514		.1166	.1778	.1778
Max	1.4943	2.0975	1.7052	1.6615	1.6907	2.1331	1.9375
Min	.1067	.0874	.1867	.0874	.1166	.1778	.1422
Avg	.9734	1.0374	1.1173	.6636	.9736	1.3639	.9116

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054065 / 33/11 KV DAUTPUR S/S

Feeder No / Name : 203 / 11 KV Wadgaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9659	.8916					
2	.9412	.8916			1.0235	1.0364	1.0837
3	.9267	.9095	.9659		1.0669	1.0517	1.1138
4	.9267	.9095	.9808	.9633	1.0669	1.0686	1.1888
5	1.0105	.9511	1.2193	1.2498	1.1111	1.2193	1.2346
6	1.2346	1.2967	1.3748	1.4232	1.439	1.3735	1.4864
7	1.5278	1.3272	1.7078	1.7236	1.6762	1.5813	1.7869
8	1.326	1.6248	1.5655	1.8027	1.656	1.7553	1.866
9	1.4327	1.6446	1.6248	1.6604	1.5623	1.4529	1.7497
24	.9511	.8471	.9659	.9214			
Max	1.5278	1.6446	1.7078	1.8027	1.6762	1.7553	1.866
Min	.9267	.8471	.9659	.9214	1.0235	1.0364	1.0837
Avg	1.1243	1.1294	1.3006	1.3921	1.3252	1.3174	1.4387

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054065 / 33/11 KV DAUTPUR S/S

Feeder No / Name : 204 / 11 KV GFSS Dautpur

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.3361	.3547	.4294	.3734	.5415	.4294
2	.3921	.3361	.3547	.4108	.3361	.5041	.4294
3	.3921	.3361	.3734	.3921	.3361	.4668	.4294
4	.3921	.3361	.3734	.3921	.3734	.4108	.4481
5	.5041	.4294	.5228	.5601	.4108	.6161	.5601
6	.7468	.5228	.6161	.7468	.5975	.7282	.7655
7	.7282	.5601			.6722	.6722	.7095
8	.6908	.4481		.7468	.6348	.5788	.6722
9	.6535	.5228	.6535	.6722	.5788	.5601	.5788
10	.5041	.5601	.7282	.7095	.7095	.7842	.6722
11	.4481	.5975	.6535	.5415	.6348	.6535	.5975
12				.5228	.5788	.5601	.5975
13	.3734	.5228					.4854
14							.4854
15	.4108						.5601
16	.4481	.6161		.7095	.7842	.7842	.5415
17	.5041			.6908	.8589	.8589	.6161
18	.5041	.6348		.6348	.7655	.9335	.8402
19	.5228	.6535		.5601		.8215	.8215
20	.5601	.6413	.7282	.6722	.7095	.7095	.7468
21	.5228	.5601	.6908	.5975	.5601	.6908	.6161
22	.4481	.4294	.5228	.4481	.5601	.5601	
23	.3734	.3921	.4854	.4108	.5975		.5601
24	.5228	.3361	.3547	.4108	.4108	.6161	.4668
Max	.7468	.6535	.7282	.7468	.8589	.9335	.8402
Min	.3734	.3361	.3547	.3921	.3361	.4108	.4294
Avg	.5024	.4886	.5294	.5629	.5741	.6526	.5926

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054065 / 33/11 KV DAUTPUR S/S

Feeder No / Name : 205 / 11 kv GFSS Wadgaon

GAOTHAN FEEDER

Dadahari Feeder KV- 11 /
OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2829	.3018	.3018	.2829	.2829	.3018
2	.2641	.2829	.2829	.2829	.2829	.2829	.3018
3	.2641	.2829	.2829	.2829	.2829	.2829	.3206
4	.2829	.2829	.2641	.2829	.3018	.2829	.3395
5	.3584	.3772	.4715	.4904	.3772	.5093	.4527
6	.6413	.6602	.6036	.6979	.6979	.6413	
7	.6413	.6413	.679	.7167	.7356	.679	.6979
8	.5281	.5847	.679	.7356	.6979	.6413	.6979
9	.5093	.4715	.5847	.547	.5847	.547	.547
10	.3961	.3584	.3772	.3206	.4338	.3772	.415
11	.2829	.2829			.2829		.3206
12	.3018						.3018
13	.3018						.2829
14	.2987	.3772	.3961	.3206	.415	.3961	.3018
15	.2641	.3584	.3961	.3772	.3961	.3961	.3584
16	.3206	.3961	.4904	.415	.3584	.415	.3584
17	.3961		.4904	.415	.4338	.4715	
18	.415			.4338	.4904	.547	.4527
19	.4527	.6602	.6224	.547	.6036	.6224	.5847
20	.4715	.6413	.5658	.5281	.5847	.6036	.5658
21	.3772	.4338	.4527	.3772	.4527	.4527	.5093
22	.3395	.3584	.3584	.3584	.3961	.3584	
23	.3206	.3206	.3206	.3395	.3584		.3584
24	.2641	.2829	.3018	.3018	.2829	.2829	.3206
Max	.6413	.6602	.679	.7356	.7356	.679	.6979
Min	.2641	.2829	.2641	.2829	.2829	.2829	.2829
Avg	.3732	.4168	.4461	.4320	.4424	.4536	.4186

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054095 / 33/11 KV SARADGAON S/S

Feeder No / Name : 201 / 11 KV SARADGSON FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4572	.5487		.9602
2		.4572	.6173		1.0288
3		.4268	.6516		1.166
4		.4268	.6859		1.166
5		.4268	.7202		1.0974
6		.6097	1.0288		1.0974
7		.8535	1.1145		1.2346
8	.4268	.8535	1.0288		1.2346
9	.4877	.9755	.9602		1.166
10	.5487				
11	.4877				
12	.3963				
20	.4268				
21	.4572				
22	.5182				
23	.5487			.9602	
24		.5487	.4458		.9602
Max	.5487	.9755	1.1145	.9602	1.2346
Min	.3963	.4268	.4458	.9602	.9602
Avg	.4776	.6036	.7802	.9602	1.1111

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054095 / 33/11 KV SARADGAON S/S

Feeder No / Name : 204 / 11 KV GFSS Mandwa Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	04-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)
11		.4115
12	.3429	.6516
13		.3944
14		.3772
19		.583
20		.6859
21		.5144
22		.4115
23		.3258
Max	.3429	.6859
Min	.3429	.3258
Avg	.3429	.4839

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054099 / 33/11 KV DHARMAPURI

Feeder No / Name : 201 / 11KV Dharmapuri SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	02-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)
14	1.9204	1.7604
20		.9602
Max	1.9204	1.7604
Min	1.9204	.9602
Avg	1.9204	1.3603

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054099 / 33/11 KV DHARMAPURI

Feeder No / Name : 203 / 11KV Halam SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	02-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)
14	.6401	.4801
20		1.2803
Max	.6401	1.2803
Min	.6401	.4801
Avg	.6401	.8802

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054099 / 33/11 KV DHARMAPURI

Feeder No / Name : 204 / 11 KV EXPRESS SALIM

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	02-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)
14	.009	.009
20		.009
Max	.009	.009
Min	.009	.009
Avg	.009	.009

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054105 / 33/11 KV MOHA S/S

Feeder No / Name : 201 / 11 KV MOHA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4861	1.4289	1.3336	1.4289
2	.381	1.4289	1.4289	1.4289
3	.381	1.4289	1.4289	1.5242
4	.381	1.5242	1.6194	1.6385
5	1.6194	2.0957	2.2481	1.8099
6	2.0005	2.7625	2.7625	2.0005
7	2.0957	2.7625		2.4768
8	2.191	2.2862	2.5339	2.1338
17	.2858	.381	.2858	.3239
18	.2858	.4572	.4572	.4001
19	.6097	.5716	.5906	.5525
20	.6097	.6668	.6478	.6097
21	.5716	.4763	.4763	.4763
22	.4763	.4763	.4763	.4763
23	.2858	.381	.3239	.2858
24	.2858	.2858	.3048	.3239
Max	2.191	2.7625	2.7625	2.4768
Min	.2858	.2858	.2858	.2858
Avg	.8716	1.2134	1.1279	1.1181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054105 / 33/11 KV MOHA S/S

Feeder No / Name : 202 / 11KV BODHEGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0381	.0381
2	.0381	.0381	.0381	.0381
3	.0381	.0381	.0381	.0381
4	.0381	.0381	.0381	.0381
5	.0381	.0381	.0381	.0381
6	.0381	.0381	.0381	.0381
7	.0381	.0381	.0381	.0381
8	.0381	.0381	.0381	.0381
17		2.4768	2.572	2.0005
18	2.6673	2.7435	2.4577	2.3243
19	2.6673	2.4387	2.4577	2.0386
20	2.2862	2.1148	2.2862	2.0386
21	2.0957	2.191	2.191	1.9052
22	2.0005	2.191	1.9052	1.9052
23	1.9052	2.1529	1.9243	1.9052
24	1.9052	1.9052	2.0767	1.9243
Max	2.6673	2.7435	2.572	2.3243
Min	.0381	.0381	.0381	.0381
Avg	1.0555	1.1574	1.1360	1.0217

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054119 / 33/11 KV ACHARYA TAKLI

Feeder No / Name : 201 / A.Takali SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4641	.4733	.3647	.4973	.421		.4268
2	.4807	.4733	.3647	.4973	.4372	.4372	.4268
3	.5304	.4908	.3605	.4973	.4534	.4641	.4268
4	.5636	.5144	.3605	.5138	.4696	.4641	.442
5	.5735	.5487		.5138	.4858		
11						1.9966	1.8623
12						2.0119	2.1052
13						2.0271	2.1052
14	2.2634	2.0243	2.13	2.17	2.2634	2.0119	2.1052
15	2.2977	2.2024	2.1862		2.2977	1.6613	2.1052
16	2.3838		2.2405		2.3838	1.8061	2.1052
17	2.332		2.2885		2.5034	1.9509	2.0567
18	2.2436	1.9559	2.1052	2.0729	2.2725		
19	2.2611	2.1538	1.7695	2.1214	2.2245		
20	2.2436	2.1052	1.8623	2.1216	2.0243	.5182	
21	2.226	2.0405	1.8461	2.0553	1.6194	.5487	
22	.5194	.3887	.431	.4534	.4144	.5335	.4858
23	.4835	.3887	.4475	.4534	.4475	.503	.4372
24	.4475	.4835	.3605	.4641	.4372	.4641	.4725
Max	2.3838	2.2024	2.2885	2.17	2.5034	2.0271	2.1052
Min	.4475	.3887	.3605	.4534	.4144	.4372	.4268
Avg	1.3946	1.1603	1.2745	1.1101	1.3222	1.1599	1.2545

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054119 / 33/11 KV ACHARYA TAKLI

Feeder No / Name : 202 / kandi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0709	.1006		.064		.061
2	.1006	.0716	.1326		.064	.2012	.2134
3	.1341	.0876	.1658		.08	.1989	.1981
4	.1341	.1052	.1823		.08	.213	.2743
5	.1341	.1029			.08	.2294	.3201
6	.4534	.4801		.4534			.4877
7	.4858	.4973	.4858	.4534	.4915		.5335
8	.502	.5316	.4858	.4858	.5304		.503
9	.5182	.5144	.4858	.4858	.5138	.5801	.503
10	.5434	.4858	.502	.4858	.5316		
11	.5144	.4858	.502	.4858	.5316		
12	.5434	.4858	.5182	.502	.5316		
13	.5434	.4534	.5079	.502			
20	.12	.0995	.1823	.1134	.1006	.1677	
21	.1029	.0972	.0995	.1296	.112	.0914	
22	.1029	.0829	.0838	.096	.0995	.0762	.0838
23	.0716	.0671	.0671	.096	.0829	.061	.0671
24	.0838	.0701	.0663		.064	.0671	.061
Max	.5434	.5316	.5182	.502	.5316	.5801	.5335
Min	.0716	.0671	.0663	.096	.064	.061	.061
Avg	.2993	.2661	.2855	.3574	.2473	.1886	.2755

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054119 / 33/11 KV ACHARYA TAKLI

Feeder No / Name : 203 / Kaudgaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10						.3481	.4915
11						.4572	.5243
12						.4365	.5182
13						.4725	.5243
14	.5258	.4588	.4973	.5735	.7202	.4572	.5079
15	.5609	.5243	.4588	.7865	.7202	.3353	.4915
16	.631		.4588		.7545	.3864	.4752
17	.631		.4588		.6859	.381	.5304
18	.5487	.4858	.4534		.5735		
19	.4973	.4858	.4588	.7865	.4915		
20	.4801	.4752	.8288	.7209	.4752		
21	.4557	.4534	.7865		.4588		
Max	.631	.5243	.8288	.7865	.7545	.4725	.5304
Min	.4557	.4534	.4534	.5735	.4588	.3353	.4752
Avg	.5413	.4806	.5502	.7169	.6100	.4093	.5079

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054121 / 33 KV NEW TPS S/S

Feeder No / Name : 201 / Express TPS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0937	.0914	.1134			.0937
2	.0926	.0937	.0914	.1134			.0949
3	.0926	.0926	.0926	.1134			.1107
4	.0914	.0926	.0914	.1134			.112
5	.0914	.0937	.108	.1134			.112
6	.0914	.0914	.0983	.1134			.112
7	.0914	.0937		.112			.0625
8	.0914		.112	.1107	.0949	.0926	.0762
9	.0914	.0914	.112		.0937	.0937	.1067
10	.0914	.0937	.1134		.0949	.1067	.1204
11	.0914	.1147	.1134		.0949		.1219
12	.0914	.1134	.1265		.0949	.108	.1219
13	.0937	.1107	.1107		.0949	.1094	.1067
14	.0937	.0781	.1265		.0937	.0914	.1054
15	.0937	.0625	.128		.0937	.0914	.104
16	.096	.0937	.1296		.0937	.1094	.104
17	.0949		.1296		.0949	.104	.1
18	.0791	.0914	.1134		.0937	.1094	.1
19	.0937		.112		.0926	.108	.1
20	.0926		.112		.0937	.1067	.1143
21	.0937	.108	.112		.0937	.1067	.1143
22	.0781	.108	.112		.0937		.1067
23	.0937		.1134		.0937		.1067
24	.0914	.0937		.1134		.0937	
Max	.096	.1147	.1296	.1134	.0949	.1094	.1219
Min	.0781	.0625	.0914	.1107	.0926	.0914	.0625
Avg	.0914	.0953	.1113	.1129	.0941	.1022	.1047

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054137 / 33/11 KV KALRATRI PARLI S/S

Feeder No / Name : 201 / 11 KV KANYA SHALA FEEDER SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.633		1.6862	1.6495	
2		1.6414		1.5546	1.4998	
3		1.5844		1.5611	1.5123	
4		1.5556		1.6615	1.5154	
5		1.826	1.8423	1.9424	1.6667	
6		2.0475	2.1089	2.2268	2.0847	
7		2.4595	2.4223	2.4223	2.4148	
8		2.4247	2.5979	2.4247	2.385	
9		2.2405	2.2987	2.4419		2.1068
10	1.9279	1.963	1.9121			1.7723
11	1.6701	1.7705	1.7575			1.8111
12	1.4754	1.6246	1.5795			1.5611
13	1.5154	1.5045	1.3746			1.3846
14	1.5138	1.538	1.2856			1.3278
15	1.4723	1.5138	1.4662			1.443
16	1.586	1.6827	1.5514			1.546
17		1.8092	1.6341			1.7412
18	2.1155	2.057				2.0119
19	2.1852	2.2662	2.3901			2.2085
20	2.1852	2.1852	2.2062			2.1253
21	2.0391	1.918	2.1209			2.0591
22	1.9339		1.9835			1.8714
23			1.9244			1.7961
24		1.7072		1.7522	1.7558	
Max	2.1852	2.4595	2.5979	2.4419	2.4148	2.2085
Min	1.4723	1.5045	1.2856	1.5546	1.4998	1.3278
Avg	1.8017	1.8615	1.9142	1.9674	1.8316	1.7844

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054137 / 33/11 KV KALRATRI PARLI S/S

Feeder No / Name : 202 / 11 KV KASARWADI FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1127		.1126	.1494	
2		.1128		.1125		
3		.1129		.1125	.1494	
10	1.4519	1.2467				
11	1.757	1.3451	1.4952			1.6632
12	1.8115	1.4435	1.6337			1.5249
13		1.3467	1.4952			1.6613
14	1.6313	1.4469	1.5819			1.6613
15	1.5407	1.4238	1.5821			1.6262
16	1.6804	1.4729				1.7404
17		1.4502				1.8338
18	.1056	.0355	1.4091			.1097
19	.1111	.0335	1.3911			.1492
20	.1131	.0516	.1103			.2075
21	.1129	.0703	.1129			.1879
22	.1129		.1127			.1497
23			.1125			.1494
24		.1125		.1125	.1491	
Max	1.8115	1.4729	1.6337	.1126	.1494	1.8338
Min	.1056	.0335	.1103	.1125	.1491	.1097
Avg	.9480	.7386	1.0033	.1125	.1493	.9742

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 057006 / 132 KV GCR PARALI

Feeder No / Name : 402 / 33 KV TPS COLONY -2

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6495	1.6975	1.6975	1.7147	1.7507	1.8158	1.7713
2	1.6152	1.6255	1.6718	1.6512	1.713	1.7901	1.713
3	1.5792	1.6032	1.6067	1.6221	1.6598	1.6615	1.5929
4	1.5484	1.5466	1.5226	1.5947	1.6015	1.6049	1.5638
5	1.5038	1.4712	1.4815	1.5312	1.5364	1.5501	1.5021
6	1.4592	1.3889	1.3803	1.454	1.4335	1.4318	1.3975
7	1.4043	1.3615	1.4112	1.4403	1.4815	1.3752	1.3272
8	1.3254	1.3717	1.3923	1.3546	1.3992	1.3289	1.3083
9	1.1574	1.1917	1.1231	1.1248	1.142	1.1077	1.142
10	1.1608	1.1283	1.1317	1.202	1.1797	1.13	1.1403
11	1.1728	.9945	1.1437	1.1728	1.0631	1.0751	1.0802
12	1.082	1.0562	1.1231	1.0837	1.0802	1.0511	1.0957
13	1.046	1.046	1.0802	1.0408	1.1437	1.0957	1.0974
14	1.1883	1.1814	1.118	1.2003	1.3066	1.2209	1.2586
15	1.2534	1.178	1.238	1.2466	1.3803	1.37	1.2809
16	1.1231	1.1077	1.2071	1.2363	1.2671	1.3306	1.2243
17	1.106	1.1043	1.1128	1.1385	1.1454	1.1728	1.25
18	.9877	1.0168	1.19	1.1197	1.1197	1.1317	1.1368
19	1.3289	1.3923	1.5535	1.4901	1.4009	1.4695	1.4129
20	1.5878	1.7301	1.713	1.665	1.6684	1.7078	1.6992
21	1.7215	1.7781	1.7335	1.7644	1.7387	1.7095	1.7301
22	1.7558	1.8158	1.8364	1.7936	1.821	1.8519	1.7627
23	1.7867	1.7816	1.8433	1.8484	1.8741	1.893	1.8553
24	1.7524	1.7953	1.7455	1.8244	1.8244	1.8484	1.8347
Max	1.7867	1.8158	1.8433	1.8484	1.8741	1.893	1.8553
Min	.9877	.9945	1.0802	1.0408	1.0631	1.0511	1.0802
Avg	1.3873	1.3902	1.4190	1.4298	1.4471	1.4468	1.4241

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054039 / 33 KV S/S LONGAON

Feeder No / Name : 201 / 11 Kv Belura

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054039 / 33 KV S/S LONGAON

Feeder No / Name : 202 / 11 Kv Anandgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054039 / 33 KV S/S LONGAON

Feeder No / Name : 203 / 11 Kv DEWALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.6001
Max	.6001
Min	.6001
Avg	.6001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054039 / 33 KV S/S LONGAON

Feeder No / Name : 204 / 11 Kv PATHRUD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
23	.3048
Max	.3048
Min	.3048
Avg	.3048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054041 / 33 KV S/S MOHIKHED

Feeder No / Name : 201 / 11 Kv Hingani

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17
HR	Load (MW)
24	.3429
Max	.3429
Min	.3429
Avg	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054041 / 33 KV S/S MOHIKHED

Feeder No / Name : 202 / 11 Kv Mohikhed

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054041 / 33 KV S/S MOHIKHED

Feeder No / Name : 203 / 11 Kv Mohikhed Gaothan

GAOTHAN FEEDER

feeder Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.2743
Max	.2743
Min	.2743
Avg	.2743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054049 / 33 KV S/S DEWADI

Feeder No / Name : 201 / 11 kv Dewadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		1.0031					
4	1.0212	1.1717	.9659		1.0936		.7733
5				1.5927			
6	1.3599	1.3117	1.3117	1.6766	1.4251	1.3748	
8							1.2037
11							1.0155
12							.9686
13	.5975	.6161			.6722		
14	.5601			.5601	.6348		
15			.6602				
16	.5228			.5973	.5658		
17					.5847		
18	.7392	.7762			.7842		
19					.9709		1.0269
20	1.0164	1.0269		.9335	1.0829		
21		.924		.9335			
22	.8316	.8145	.924	.8686	.9145		.8316
23		1.1591		1.2643			.7392
24	1.0911	1.0802	1.1138		1.1888	1.0709	.7468
Max	1.3599	1.3117	1.3117	1.6766	1.4251	1.3748	1.2037
Min	.5228	.6161	.6602	.5601	.5658	1.0709	.7392
Avg	.8600	.9884	.9951	1.0533	.9016	1.2229	.9132

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054049 / 33 KV S/S DEWADI

Feeder No / Name : 202 / 11 kv Kadiwadgaon
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-MAY-17
HR	Load (MW)
24	.6401
Max	.6401
Min	.6401
Avg	.6401

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054049 / 33 KV S/S DEWADI

Feeder No / Name : 203 / 11 Kv Khalwat Limbgaon SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
23	.6859
Max	.6859
Min	.6859
Avg	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054049 / 33 KV S/S DEWADI

Feeder No / Name : 204 / w/w kadiwadgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.6516
Max	.6516
Min	.6516
Avg	.6516

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054052 / 33 KV S/S WADWANI

Feeder No / Name : 202 / 11 Kv Salimba

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	1.6156
Max	1.6156
Min	1.6156
Avg	1.6156

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054052 / 33 KV S/S WADWANI

Feeder No / Name : 203 / 11 Kv Pusara

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.503
Max	.503
Min	.503
Avg	.503

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054068 / 33 KV S/S DINDRUD

Feeder No / Name : 201 / 11 Kv Dindrud

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
21		1.2136	
24	1.1488	1.0229	1.0562
Max	1.1488	1.2136	1.0562
Min	1.1488	1.0229	1.0562
Avg	1.1488	1.1183	1.0562

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054068 / 33 KV S/S DINDRUD

Feeder No / Name : 202 / 11 Kv FakirJawala
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
21		.2241	
23	.5944		
24		.5201	.1867
Max	.5944	.5201	.1867
Min	.5944	.2241	.1867
Avg	.5944	.3721	.1867

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054068 / 33 KV S/S DINDRUD

Feeder No / Name : 203 / 11 Kv DevDahiphal
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
21		.1372	
24	.6687	.1166	.1105
Max	.6687	.1372	.1105
Min	.6687	.1166	.1105
Avg	.6687	.1269	.1105

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054090 / 33 KV S/S LAUL

Feeder No / Name : 201 / 11 Kv Laul

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.639	.7316		.3479	.3715	
2	.7968	.7011	.8002	.7133	.7186	.7628	
3	1.1523	.7655	.7935	.8436	.7655	.8173	
4	.8223	.8322	.8583	.9922	.9374	.884	
5	.8745	.8322	.9116	1.0159	1.0486	.9602	
6	.9282	.9503	1.0562	1.0395	1.17	1.1142	
7	.9012	.9995	1.0608		1.17	1.1469	
8	.8642	1.0486	1.0774	1.1401	1.1271	1.0202	
9	.9069	.9717	1.0688	.9448	1.1271	1.0623	
10	.2949	.2347	.253	.2629		.2343	.6767
11	.2515	.3978	.2572	.2658		.2561	.8025
12	.2058	.4096	.2709	.2303	.2713	.2652	.8025
13	.2204	.3887	.2743	.2686	.2683	.2683	
14	.2347	.3563	.2591	.2865	.2818	.2743	.7716
15	.2486		.2785	.2378	.2743	.2774	.823
16	.2561		.2818	.2378	.2804	.2572	.8855
17	.2622	.3121			.3077	.2401	.3239
18	.3286	.3765			.3227	.3292	.3239
19	.3715	.4428			.4917	.3429	
20	.4054	.4801			.4374	.743	.4287
21	.3807	.4428			.4001	.7788	
22	.3572	.4321			.4144		.4115
23	.3102	.3864			.3948		.4115
24	.7316	.4801	.7316	.9448	.3479	.3948	
Max	1.1523	1.0486	1.0774	1.1401	1.17	1.1469	.8855
Min	.2058	.2347	.253	.2303	.2683	.2343	.3239
Avg	.5366	.5855	.6450	.6283	.5866	.5819	.6056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054090 / 33 KV S/S LAUL

Feeder No / Name : 202 / 11 Kv Pathrud SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2328	.4251	.2686		.439	.2629	
2	.2534	.4481	.2715	.2896	.4435	.2743	
3	.2743	.4715	.2402	.3292	.4435	.2534	
4	.2987	.4805	.2987	.3658	.5121	.2926	
5	.3206	.5041	.3361	.5175	.5601	.3361	
6	.3734	.5281	.4527	.5281	.6224	.4108	
7	.2957	.4755	.3696		.5596	.3584	
8	.2561	.4435	.2957	.4024	.3696	.2427	
9	.2241	.3696	.2587	.3142		.2149	
10	1.9753	2.5263	2.3122	2.5069		2.4352	
11	2.4939	2.9165	2.7161	2.9504		2.7206	
12	3.0498	2.834	2.7161	3.1824	2.9492	2.915	
13	2.9492	2.8346	2.7006	3.1824	2.915	2.8509	
14	2.7846	2.8673	.2656	2.967	2.7854	2.753	.2241
15	2.7206		2.6246	2.8349	2.753	2.7526	.2241
16	2.7854		2.7349	.1595	2.769	2.5911	.2218
17	2.9001	3.0498			2.8344	2.4615	.3772
18	.2187	.1875			.218	.2401	.3772
19	.4252	.3944			.4656	.2713	
20	.394	.4334			.4252	.3814	.4908
21	.4115	.3814			.3506	.5014	
22	.4031	.2778			.3681		.4382
23		.2743			.3429		.4207
24	.2195	.4334	.2507	.2715	.439	.2743	
Max	3.0498	3.0498	2.7349	3.1824	2.9492	2.915	.4908
Min	.2187	.1875	.2402	.1595	.218	.2149	.2218
Avg	1.1417	1.0708	1.1243	1.3868	1.1222	1.1725	.3468

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054090 / 33 KV S/S LAUL

Feeder No / Name : 203 / 11 Kv Pardi Mategaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2597	1.3756	1.1574				
2	1.3413	1.3535	1.1717	1.3889	1.1888	1.1683	
3	1.3203	1.4415	1.1717	1.4815	1.2483	1.1702	
4	1.3226	1.475	1.2323	1.5181	1.3889	1.1873	
5	1.5261	1.4784	1.2631	1.4074	1.4232	1.2176	
6	1.387	1.475	1.3094	1.4074	1.4403	1.2643	
7	1.4661	1.46	1.4449		1.5424	1.3413	
8	1.5466	1.4449	1.4815	1.5364	1.6651	1.3565	
9	1.5699	1.3847	1.4937	1.5364	1.6301	1.2887	
10							1.3535
11							1.4449
12							1.4937
14							1.5242
15							1.5051
16							1.4937
17							1.5051
23	.394						
24	1.2574	1.3717	1.1405	1.3352			
Max	1.5699	1.4784	1.4937	1.5364	1.6651	1.3565	1.5242
Min	.394	1.3535	1.1405	1.3352	1.1888	1.1683	1.3535
Avg	1.3083	1.4260	1.2866	1.4514	1.4409	1.2493	1.4743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054092 / 33 KV S/S TELGAON

Feeder No / Name : 201 / 11 Kv Mohikhed

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.6516
Max	.6516
Min	.6516
Avg	.6516

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054092 / 33 KV S/S TELGAON

Feeder No / Name : 202 / 11 Kv Wadwani

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.8383
Max	.8383
Min	.8383
Avg	.8383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054092 / 33 KV S/S TELGAON

Feeder No / Name : 203 / 11 Kv Nitrud

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054109 / 33kv Chinchala

Feeder No / Name : 201 / 11kv chinchala

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.7716
Max	.7716
Min	.7716
Avg	.7716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054109 / 33kv Chinchala

Feeder No / Name : 202 / 11kv Tigaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.7202
Max	.7202
Min	.7202
Avg	.7202

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054109 / 33kv Chinchala

Feeder No / Name : 203 / 11kv Kuppa

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.5792
Max	.5792
Min	.5792
Avg	.5792

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054130 / 33 KV Kuppa Sub-station

Feeder No / Name : 201 / 11kv kuppa SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6874	.4525		.3795	.4062	.4144	.4706
2	.7186	.543		.3795	.4374	.4973	.4706
3	.7811	.543		.4744	.4687	.4973	.543
7				.3795			
9		1.1574			1.3123	1.4089	
10		1.5432		1.4998			
11	1.1336	1.5432		1.6872		1.6004	
12		1.5432		1.656	1.9662	1.6766	
13		1.5432	1.6446	1.6248	1.7814	1.5851	
14	1.6194	1.5432	1.5813	1.406	1.7814	1.5242	
15		1.5432	1.6129	1.3123		1.4632	
16	1.7004	1.5432	1.5497		1.6194	1.5242	
17	1.6194	1.2346	1.6129		1.6194	1.4198	
18	.5506	.5792			.5506	.6335	
19		.6516	.6325	.8124	.663	.8145	
20	.6882	.7964	.6958	.6562	.663	.8326	
21			.6325	.5937		.6335	
22			.506	.4999		.543	
23			.4428	.4374	.4973		
24	.7186	.4359	.4706	.4111	.4062	.4641	.4706
Max	1.7004	1.5432	1.6446	1.6872	1.9662	1.6766	.543
Min	.5506	.4359	.4428	.3795	.4062	.4144	.4706
Avg	1.0217	1.0748	1.0347	.8881	1.0123	1.0313	.4887

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054130 / 33 KV Kuppa Sub-station

Feeder No / Name : 202 / 11KV UPALI SINGLE PHASING

Feeder KV- 11 / INCOMING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0486		3.5627	2.2024	2.6707	2.4577	3.0445
2	1.0814		.6516	2.17	2.6543	2.4577	3.0445
3	1.1469		3.2388	2.17	2.6216	2.2939	2.9797
4	1.1797		3.8866	2.1052	2.6216	2.3758	2.9797
5	1.2452		3.8866	2.1376	2.8346	2.4034	2.9797
6	1.3108			2.332	3.0148	2.4413	2.9797
7	1.2452			2.4777	2.8837		
14				.4588			
15				.5243			
16			.583		.5243		
17	.6036		.8097	.5243			
18	.7125	.9412	2.0729		1.8976		
19		.8688	2.332	3.0148	2.4577		
20		1.0136	2.5911	2.7526	2.4577	1.3603	
21			3.3036	2.7526		2.332	
22			2.2024	2.7199		3.1093	
23			2.2672	2.6871	2.2672		
24	.0655	3.3208	3.2388	2.2024	2.6871	2.2672	3.0445
Max	1.3108	3.3208	3.8866	3.0148	3.0148	3.1093	3.0445
Min	.0655	.8688	.583	.4588	.5243	1.3603	2.9797
Avg	.9639	1.5361	2.4734	2.0770	2.4302	2.3499	3.0075

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054130 / 33 KV Kuppa Sub-station

Feeder No / Name : 203 / 11KV RAJEWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9054	.7964		.7042	.7377	.7377	.8145
2	.9389	.724		.7042	.8048	.8383	.8688
3	1.0059	.724			.8718	.8192	.9412
4	1.0395						
5	1.1736						
6	1.4083						
7	1.0059						
9		1.186			1.3077	.9945	
10		1.5813		1.6095			
11	1.1336	1.5813		1.5424		1.5181	
12		1.3599	1.6095	1.5089	1.4251	1.4232	
13		1.2651	1.5089	1.4754	1.3123	1.3283	
14	1.3916	1.2334	1.4419	1.3077	1.2811	1.2651	
15		1.2651	1.3748	1.2407		1.2334	
16	1.3765	1.3599	1.4754		1.3765	1.2651	
17		.9488	1.4754		1.2955	1.4548	
18		.6516	.6706		.5898	.6878	
19		1.086	1.0059	.9389	.8619	1.086	
20		1.2308	1.1401	1.1401	1.1065	1.2308	
21			1.0059	1.0395		1.0498	
22			.9054	.9724		.9412	
23			.8048	.8383	.8192		
24	.9054		.7964	.8048	.7377	.7209	.8145
Max	1.4083	1.5813	1.6095	1.6095	1.4251	1.5181	.9412
Min	.9054	.6516	.6706	.7042	.5898	.6878	.8145
Avg	1.1168	1.1329	1.1704	1.1305	1.0377	1.0938	.8598

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 057008 / 132 KV TELGAON SUB STATION

Feeder No / Name : 401 / 33 KV WADAWANI FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	.1029
Max	.1029
Min	.1029
Avg	.1029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 057008 / 132 KV TELGAON SUB STATION

Feeder No / Name : 402 / 33 KV KADIWADGAON FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	.1029
Max	.1029
Min	.1029
Avg	.1029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 057008 / 132 KV TELGAON SUB STATION

Feeder No / Name : 404 / 33 KV MOHIKHED FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	.1543
Max	.1543
Min	.1543
Avg	.1543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

ASHTI (R) S/DN[415] BU 2551

Substation No/ Name :- 054027 / 33/11 KV. S/S DHANORA

Feeder No / Name : 201 / 11 KV. KADA FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	04-MAY-17
HR	Load (MW)
7	2.0576
Max	2.0576
Min	2.0576
Avg	2.0576

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

ASHTI (R) S/DN[415] BU 2551

Substation No/ Name :- 054120 / Ashti

Feeder No / Name : 201 / Ashti Urban

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4289	1.6194	1.4289	1.467	1.3717	1.5813	1.6385
2	1.4289	1.5242	1.4098	1.448	1.3717	1.5242	1.5623
3	1.4861	1.5242	1.3717	1.4289	1.3527	1.4861	1.5623
4	1.448	1.4289	1.3336	1.4098	1.3717	1.448	1.5813
5	1.5432		1.3908	1.448	1.4098	1.4289	1.6575
6	2.0386	1.8099		1.848	1.6766	1.9243	1.7718
7	1.9814	1.9433	1.9433	2.0576	1.8099	1.9433	1.8861
8	1.9624	2.0767	1.9433	2.1148	1.8671	2.0576	1.9433
9	2.0576	2.1338	1.9814	2.1529	1.9052	2.0005	
10	1.9624	2.0767	2.0576	2.0386	1.829	2.0005	1.8671
11	1.6956	1.7528	1.8671	1.8671		1.8099	1.6766
12	1.6194	1.6956	1.3908	1.7147	1.6004	1.6956	1.6004
13	1.6004	1.6385	1.829	1.6385	1.6766	1.7147	1.5623
14	1.6194	1.5813	1.7528		1.7909	1.5242	1.467
15	1.6385	1.6194	1.6194	1.6575	1.6766	1.6194	1.5623
16	1.6194	1.6956	1.7147	1.5813	1.6194	1.6766	1.6194
17	1.7147	1.7528	1.6575	1.6575		1.7718	1.7147
18	1.9052	1.8099	1.8099	1.1431	1.8099	1.8099	2.0005
19		2.1529	2.191	1.848	2.0386	2.1338	
20		2.2862	2.3434		2.2672		
21		1.848	2.0195		2.0005		1.9814
22	1.7909	1.7337	1.7909				
23	1.5623			1.448	1.7147	1.8099	1.6385
24	1.6385	1.6004	1.6194		1.5051		1.7147
Max	2.0576	2.2862	2.3434	2.1529	2.2672	2.1338	2.0005
Min	1.4289	1.4289	1.3336	1.1431	1.3527	1.4289	1.467
Avg	1.7020	1.7866	1.7484	1.6826	1.6983	1.7480	1.7004

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

ASHTI (R) S/DN[415] BU 2551

Substation No/ Name :- 054120 / Ashti

Feeder No / Name : 203 / BHRAMAGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.4572	.4572	1.0288	.1715	.381	
2	.4191	.381	.4763	.0381	.1715	.381	
3	.4763	.4191	.4191	.4382	.1715	.362	
4	.5716	.4763	.4954	.5525	.1905	.362	
6					.1715		
11	1.7718	1.6956			.8954	.8573	1.4289
12	1.6194	1.2955				.9717	1.3717
13	1.467	1.2955			.9145	.4191	1.2574
14	1.4289	1.2955			.724	1.7147	1.4861
15	1.4289	1.3146			.6478	1.5813	1.2574
16	1.3717	.4001	1.6575		.7811		1.2574
17	1.448	1.3908	1.7718		.743		1.5813
18		1.3527	1.7147		.5716		.6097
19	1.448	.7621	.8002		.5716		
20		.8002	.8383		.5906		
21		.6287			.5335		.5144
22	.5144	.5335					
23	.4763			.5716			.5335
24	.4572	.4763	.5335		.1715		
Max	1.7718	1.6956	1.7718	1.0288	.9145	1.7147	1.5813
Min	.381	.381	.4191	.0381	.1715	.362	.5144
Avg	1.0186	.8809	.9164	.5258	.5013	.7811	1.1298

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

ASHTI (R) S/DN[415] BU 2551

Substation No/ Name :- 054124 / TAKALI AMIYA

Feeder No / Name : 201 / 11 TAKALI AMIYA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.763	.6783	1.0288	.9326	.8573	.9221	.964
2	.8764	.9326	1.0174	1.0174	1.0288	1.0059	.964
3	1.0517	1.0174	1.2717	1.2717	1.0517	1.0898	1.0288
4	1.0402	1.1869	1.3565	1.3565	1.2269	1.1603	.9831
5	1.2136	1.5927	1.5089	1.5927	1.4575	1.4918	1.1469
6	1.9071	1.8442	1.8442	1.8442	1.7147	1.8023	1.8623
7	2.0576	2.0119	2.0119	2.0119	2.0348	2.13	2.2672
8	1.8861	2.1795	2.3472	2.1795	2.2634	2.13	2.2119
9	1.7147	2.0119	2.2634	1.6575	2.1795	2.2043	2.13
16	.4334	.3467	.3467	.503	.4508		.4239
17	.4334	.4334	.5201	.6783	.5201		.5935
18	.6068	.6068	.5201	.763	.7716		
19	1.0174	1.0402	.9536	1.0288	.9431	1.0174	
20	1.1022	1.1145	1.0402	1.1145	1.0174	1.153	
21	1.0174	1.1145	1.1145	1.1145	1.1022	1.1145	.6935
22	1.0059	1.0288	.9431	1.0174	1.0174	1.0288	1.0402
23	.8383	.8573	.8573	.8478	.8478	.8669	.8669
24	.6554	.763	.9431	.9431	.8192	.9221	.9326
Max	2.0576	2.1795	2.3472	2.1795	2.2634	2.2043	2.2672
Min	.4334	.3467	.3467	.503	.4508	.8669	.4239
Avg	1.0900	1.1534	1.2160	1.2152	1.1836	1.3359	1.2073

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

ASHTI (R) S/DN[415] BU 2551

Substation No/ Name :- 054124 / TAKALI AMIYA

Feeder No / Name : 202 / 11 KV CHOBHA NIMGAON SINGLE PHASING

Feeder KV- 11 / INCOMING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4641	.5258	.5144	.5144	.4239	.5201	.503
2	.4748	.4908	.4801	.4287	.4239	.4287	.5087
3	.5373	.4382	.4287	.4287	.5144	.5144	.5426
10	1.6766	1.6956	1.7404	2.2043	1.8652	2.0805	2.0576
11	2.5396	2.3472	2.2377	2.3739	2.4587	2.2043	2.3739
12	2.4577	2.4577	2.2939		2.5149		2.4863
13	2.4577	2.13	2.1795		2.1795		2.3205
14	2.4034	2.2119	2.0119	2.13	2.2119		2.3758
15	2.3205	2.13	1.9062	2.2377	2.13		2.2377
16	2.3205	1.8023	1.8023	2.3205	2.0481		1.989
17	2.5396	2.1862	1.9719	2.2939	1.6385		2.0957
18	.2543	.2629	.1715	.3391	.1753		
19	.5144	.5258	.5258	.5935	.4382	2.5434	
20	.6001	.6135	.6135	.6859	.6135	.7011	
21	.7716	.7011	.6935	.6859	.6935	.7362	.6135
22	.7011	.6935	.6935	.5087	.6935	.6935	.7011
23	.5258	.5201	.6068	.503	.5201	.6001	.6135
24	.4801	.5258	.5201	.5258	.4144	.5201	.5087
Max	2.5396	2.4577	2.2939	2.3739	2.5149	2.5434	2.4863
Min	.2543	.2629	.1715	.3391	.1753	.4287	.503
Avg	1.3355	1.2366	1.1884	1.1734	1.2199	1.0493	1.4618

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

ASHTI (R) S/DN[415] BU 2551

Substation No/ Name :- 054126 / 33/11 KV WAHIRA SUB STATION

Feeder No / Name : 201 / 11 KV NIMGAON BODKHA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3927		1.9662		1.065	
2			1.9989		1.1469	
3	1.5565	1.4746	2.2283	1.9498	1.2289	
4			2.2939		1.3108	
5			2.0317		1.4746	
6	1.7204	1.6385	2.3266		1.5565	
7		1.7204	2.2775		1.8842	1.9334
8		1.8023	2.4249		2.13	
9	1.8842	1.7368	2.3594	2.2447	2.2119	2.1136
12				.2458		
13				.2294		
14				.213		
15				.213		
16				.2294		
17		.2622		.213		
18	.3277	.3932		.3277		
19	.3277	.426		.4096		
20	.3277	.3605		.3277	.5243	
21	.3277	.3768		.3277		
22	.2949	.3277		.3277		
23	.2458	.2949		.2785		
24	1.4746	1.2289	2.0809	1.9989	.7373	1.8351
Max	1.8842	1.8023	2.4249	2.2447	2.2119	2.1136
Min	.2458	.2622	1.9662	.213	.5243	1.8351
Avg	.8982	.9264	2.1988	.6357	1.3882	1.9607

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

ASHTI (R) S/DN[415] BU 2551

Substation No/ Name :- 054126 / 33/11 KV WAHIRA SUB STATION

Feeder No / Name : 202 / 11 KV WAHIRA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1619		.2591		.2429	
2			.2429		.2429	
3	.2429	.2429	.2753	.3239	.3239	.2915
10	1.2955	1.3765		1.2955		
11		1.085		1.3765		
12	1.6194	1.1984		1.4575		
13	1.6194	1.0526		1.6194		
14	1.5384	1.1012		1.6194		
15	1.4575	1.0202		1.5384		
16	1.4575	1.0526		1.6194		
17	1.5384	.9555		1.5384		
18	1.2955	.3239		.2429		
19	.2429	.3401		.2429		
20	.2429	.2915		.2429	.3077	
21	.2429	.3077		.2429		
22	.2429	.2915		.2429		
23	.1943	.2753		.2429		
24	.9069	.1943	.3239	.3725	.2267	.3239
Max	1.6194	1.3765	.3239	1.6194	.3239	.3239
Min	.1619	.1943	.2429	.2429	.2267	.2915
Avg	.8937	.6943	.2753	.8886	.2688	.3077

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

ASHTI (R) S/DN[415] BU 2551

Substation No/ Name :- 054126 / 33/11 KV WAHIRA SUB STATION

Feeder No / Name : 203 / 11 KV PIMPALGAON DANI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1562		.1562		.2343	
2			.1718		.2343	
3	.2343	.1875	.1718	.253	.2812	
7						.2214
10	.7811	.9374		.7811		
11		.5601		.8592		
12	1.2498	.5921		.9374		
13	1.0936	.5441		.9374		
14	.9374	.7522		.8592		
15	1.1717	.6882		1.0936		
16	1.0936	.8322		1.2498		
17	1.0155	.8162		1.1717		
18	.9374	.2401		.2343		
19	.2343	.2561		.2343		
20	.1875	.2561		.2343	.253	
21	.2031	.208		.2343		
22	.1875	.2241		.2343		
23	.1562	.192		.1875		
24	.5441	.1562	.208	.2372	.1875	.253
Max	1.2498	.9374	.208	1.2498	.2812	.253
Min	.1562	.1562	.1562	.1875	.1875	.2214
Avg	.6365	.4652	.1770	.6087	.2381	.2372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

ASHTI (R) S/DN[415] BU 2551

Substation No/ Name :- 054127 / 33/11 KV DAULAWADGAON SUB

STAT

Feeder No / Name : 201 / 11 KV SALEWADGAON

SINGLE PHASING

Feeder KV- 11 / INCOMING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.4534	.5506	.4858	.4372	.4858	1.5384
9	.4424						
12	1.9334	1.2308	1.0688	1.1336	1.668	1.4089	.3887
16	1.8067	1.5223	1.6518	1.2146	1.7976	.8259	
20	.4534	.4372	.3725	.3401	.4534	.3725	
24	.3605	.426	.4372	.4696	.3239	.3401	.3401
Max	1.9334	1.5223	1.6518	1.2146	1.7976	1.4089	1.5384
Min	.3605	.426	.3725	.3401	.3239	.3401	.3401
Avg	.9993	.8139	.8162	.7287	.9360	.6866	.7557

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

ASHTI (R) S/DN[415] BU 2551

Substation No/ Name :- 054127 / 33/11 KV DAULAWADGAON SUB

STAT

Feeder No / Name : 202 / 11 KV DAULAWADGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.6316	.4694	.4527	.503	.4694	.788
9	.5571						
12	1.1797	.6203	.8215	.6706	.8886	.6874	.2515
16	1.1012	.6371	.8048	.6371	.9724	.8048	
20	.5571	.4862	.4359	.4024	.5365	.4049	
24	.3932	.4588	.503	.5197	.3688	.3856	.4191
Max	1.1797	.6371	.8215	.6706	.9724	.8048	.788
Min	.3932	.4588	.4359	.4024	.3688	.3856	.2515
Avg	.7577	.5668	.6069	.5365	.6539	.5504	.4862

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

ASHTI (R) S/DN[415] BU 2551

Substation No/ Name :- 054127 / 33/11 KV DAULAWADGAON SUB

STAT

Feeder No / Name : 203 / 11 KV PIMPALGAON GHAT SINGLE PHASING

Feeder KV- 11 / INCOMING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			1.6288	1.5497		1.7078	.5535
12		.2372	.253	.2372	.3321		1.5971
16		.3321	.3637	.3321	.3637	.3953	
20		.4902	.427	.4586	.5693	.506	
24	.5735	.7045	.5376	.6009		.506	.5376
Max	.5735	.7045	1.6288	1.5497	.5693	1.7078	1.5971
Min	.5735	.2372	.253	.2372	.3321	.3953	.5376
Avg	.5735	.441	.6420	.6357	.4217	.7788	.8961

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

ASHTI (R) S/DN[415] BU 2551

Substation No/ Name :- 055001 / pargaon jogeshwari

Feeder No / Name : 201 / Takalsingh

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5906	.6097	.5335	.4954	.5716	.6287	1.3527
2	.6287	.6478	.5144	.4572	.5906	.6668	1.2955
3	.6859	.6859	.4954	.5525	.5525	.7049	1.4098
4	.7621	.7621	.5906	.5716	.6097	.7621	1.5432
5	.8573	.8573	.6478	.6097	.6478	.8192	1.8099
6	.9526	1.0669	.7811	.7049	.6859	.8764	2.1148
7	.9717	.7621	.9335	.7811	.8764	.8764	2.3243
8	.8002		.7621	.724	.7049	.7811	2.0767
17	2.7054	2.7625	2.0957	2.2862	2.6101	2.934	.5906
18	2.6863	2.6673	2.4006	2.7054	2.4196	2.572	.5525
19	2.6673	2.4768	2.3624	2.6863	2.4577	2.4577	
20	2.4006	2.3434		2.6673	2.1148	2.2481	
21	2.2672		1.8861	2.3815	2.0195	1.9243	.4572
22	2.1338	2.1719	2.0957	2.4196	1.9052	1.6956	.5144
23	1.9624	2.0767	1.7147	2.4577	1.7909	1.5813	.4954
24	1.829	1.8671	1.7528	1.5432	2.4768	1.6385	1.4861
Max	2.7054	2.7625	2.4006	2.7054	2.6101	2.934	2.3243
Min	.5906	.6097	.4954	.4572	.5525	.6287	.4572
Avg	1.5563	1.5541	1.3044	1.5027	1.4396	1.4479	1.2874

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054050 / 33/11 KV. MALIVES S/S, BEED

Feeder No / Name : 201 / 11 KV. TILAK ROAD FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6297	1.6118	1.6476	1.9366	1.8461	1.9366	1.9547
2		1.576	1.6118	1.7737	1.7375	1.7737	1.7375
3	1.576	1.5402	1.576	1.7013	1.7013	1.7193	1.7013
4	1.5402	1.5043	1.5402	1.647	1.7013	1.7013	1.5927
5	1.5223	1.4864	1.6655	1.647	1.6832	1.7013	1.5746
6	1.5223	1.5043	1.7193	1.7013	1.7194	1.6832	1.6289
7	1.4864	1.5402	1.773	1.7375	1.8099	1.6289	1.6289
8	1.4685	1.5939	1.7013	1.7013	1.7737	1.7013	1.7013
9	1.5565	1.647	1.7372	1.7551	1.8983		1.9342
10	1.7194						1.7013
11	1.8823	2.2443			2.1849		1.9879
12	1.8823						
13	1.9547	2.7149				2.9729	1.8625
14	2.0814	2.4615		2.5339		2.6863	1.97
15	2.0814	2.3529		2.5701		2.6326	
16	2.1357		3.1093		2.8296		2.0774
17	1.9521	2.6863	2.9995	2.7149	2.8898	2.9995	2.1948
18	2.1132	2.524	2.8898	2.6425	2.7149	2.8898	2.2916
19	2.3998	2.7511	3.0361	2.8898	2.9264	3.0727	
20	2.364	2.7511	3.0678	2.7873	2.8532	3.0769	2.6703
21	2.3282	2.5606	2.7511	2.5606	2.7801	2.7149	
22	2.2565	2.1033	2.19		2.4615	2.2805	2.0271
23	1.8267	1.8625	2.0814		2.1357	2.1176	1.9547
24	1.7193	1.6834	.7316	1.9728	1.9909	1.9547	2.009
Max	2.3998	2.7511	3.1093	2.8898	2.9264	3.0769	2.6703
Min	1.4685	1.4864	.7316	1.647	1.6832	1.6289	1.5746
Avg	1.8695	2.0333	2.1016	2.1337	2.1915	2.276	1.9100

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054050 / 33/11 KV. MALIVES S/S, BEED

Feeder No / Name : 202 / 11 KV. JALNA ROAD FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8289	1.8168	1.9509	2.2748	1.086	2.2444	2.172
2	.945	1.768	1.8023	1.0498	1.0136	2.1415	2.1358
3	1.701	1.7109	1.7803	.9774	.9774	2.0443	1.9928
4	1.6888	1.6442	1.701	.9774	.8688	1.9448	1.9662
5	1.5912	1.6318	1.7132	.9774	.8507	1.8472	1.8747
6	1.5546	1.6417	1.6112	.905	.8413	1.8168	1.8351
7	1.6297	1.5133	1.6482	.8507	1.7558	1.7951	1.7193
8	1.4266	1.5318	1.6112	.8048	1.7863	1.7646	1.6948
9	1.384	1.5108	1.6217	.7421	1.7132	.9145	1.6583
10	1.4499	1.547	.7926	.8596	.9145	1.7423	1.6636
11	1.4861	1.608		.8417	2.1767	1.9109	1.6013
12	1.5166	1.7863			1.0669	1.0364	.823
13	1.6442	1.0136			2.0287	1.9719	1.6261
14	1.6804	1.9167		.9313	1.1279	2.0443	1.8595
15	1.8443	1.9776	2.2253	1.0608	2.0058	2.0929	.9755
16	1.7833	2.0138	2.5842		2.0485	1.9967	1.8168
17	1.7253	1.9719	2.5305	.9955	2.018	1.869	1.7414
18	1.729	1.9204	2.3663	.9877	2.0058	1.8443	1.6522
19	1.9109	2.0423	2.439	1.0608	2.2082	2.2558	1.8404
20	1.9719	2.3415	2.5721	1.0974	2.3243	2.3167	.9774
21	2.0024	2.2633	2.4387	1.134	2.3167	2.2748	1.0974
22	1.9662	2.2082	2.372		2.3415	2.3053	2.1777
23	2.1053	2.1765	2.4025		2.372	2.3053	2.2082
24	2.0241	2.0634	2.1338	1.1222	2.372	2.3358	2.2386
Max	2.1053	2.3415	2.5842	2.2748	2.372	2.3358	2.2386
Min	.945	1.0136	.7926	.7421	.8413	.9145	.823
Avg	1.6912	1.8175	2.0149	1.0342	1.6759	1.9507	1.7228

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054050 / 33/11 KV. MALIVES S/S, BEED

Feeder No / Name : 203 / 11 KV MONDHA ROAD FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3836	1.3775	1.4015	.7442	1.6282	1.6459	1.6587
2	.7011	1.3474	1.3718	.6805	1.5546	1.5699	1.5268
3	1.2616	1.2803	1.2498	.6089	1.4305	1.4373	1.395
4	1.2498	1.2374	1.274	.6154	1.371	1.4068	1.395
5	1.2498	1.2012	1.2559	.6154	1.3584	1.3832	1.4068
6	1.3832	1.2559	1.3535	.6516	1.4388	1.4022	1.4876
7	1.3899	1.225	1.3535	.7602	1.3352	1.384	1.5302
8	1.2679	1.1576	1.311	.6584	1.2681	1.323	1.4205
9	1.1401	1.0441	1.1888		1.201		1.2071
10	1.1111	1.086		.567	.6401	1.4189	1.1649
11	1.1236	1.0269		.5373	1.1888	1.3047	1.0395
12	1.1057	1.1111			.6401	.7011	.6401
13	1.0704				1.4319		1.1107
14	1.1717	.5373			.7316		1.2498
15	1.2199	1.3531	1.797	.5316	1.3169		.6706
16	1.2563	.6626	.945	.7202	.7316	.8682	1.2864
17	1.1288	1.3535	.7682	.6767		1.6888	1.2559
18	1.2384	1.3479	1.7109	.6878	1.6156	1.5851	1.2498
19	1.4498	1.4985	1.8168	1.5851	1.6442	1.6499	.7011
20	1.487	1.5013	1.8865	1.5775	1.7357	1.6827	1.518
21	1.4261	1.4499	1.7246	1.4937	1.547	1.5775	.7621
22	1.408	1.451	1.6587	.884	1.6282	1.6282	1.5394
23	1.4677	1.4746	1.6972	.9145	1.6764	1.6667	1.6667
24	1.4731	1.4746	1.5299	1.6846	1.6587	1.6892	1.7246
Max	1.487	1.5013	1.8865	1.6846	1.7357	1.6892	1.7246
Min	.7011	.5373	.7682	.5316	.6401	.7011	.6401
Avg	1.2569	1.2372	1.4366	.8597	1.3379	1.4507	1.2753

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054050 / 33/11 KV. MALIVES S/S, BEED

Feeder No / Name : 204 / 11KV VIJAY TALKIES

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8871	.8596	.961	1.0498	1.0136	1.0136	1.0498
2		.8688	.8871	.9774	.9671	1.0136	.9774
3	.8871	.8048	.8962	.9412	.9671	.9774	.905
4	.8871	.8871	.9335	.9412	.9671	.9774	.905
5	.9145	.961	.961	.9511	.9774	.9774	.9774
6	1.1088	1.0349	1.1088	1.0974	1.1706	1.0608	1.134
7	1.1949	1.1949	1.2696	1.3169	1.39	1.2071	1.1706
8	1.2567	1.2696	1.2696	1.4415	1.4998	1.3169	1.3169
9	1.3169	1.3306	1.4045		1.3306		1.4045
10	1.2437	1.3169		1.4784		1.4784	1.2567
11	1.1584	1.1706		1.3306	1.2437	1.3306	1.1827
12	1.0242	1.0974					
13	.905				1.1706		1.0719
14	.905	.9774		1.0242			.9511
15	.8688	.905	1.1694		.9511		
16	.905	1.1222		1.086		1.1584	1.0242
17	1.0349	1.1088	1.3394	1.1458		1.2308	1.0719
18	1.1088	1.2197	1.4842	1.2536	1.2803	1.3169	1.2071
19	1.2567	1.39	1.4784	1.3535	1.3394	1.4415	1.3169
20	1.1827	1.2536	1.4045	1.3169	1.3535	1.3535	1.3169
21	1.1088	1.1222	1.3032	1.1462	1.1706	1.2071	
22	1.0349	1.0387	1.3032		1.086	1.1584	1.086
23	1.0136	1.0349	1.1584		1.086	1.0974	1.0498
24	.9412	.9412	.9774	1.0608	1.0136	1.0498	1.0498
Max	1.3169	1.39	1.4842	1.4784	1.4998	1.4784	1.4045
Min	.8688	.8048	.8871	.9412	.9511	.9774	.905
Avg	1.0498	1.0830	1.1839	1.1618	1.1567	1.1772	1.1155

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054050 / 33/11 KV. MALIVES S/S, BEED

Feeder No / Name : 205 / 11 KV Jillha Parishad

SHEDDABLE URBAN

Feeder Feeder KV- 11 /
OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9593	1.0136	1.0136	1.1765	1.086	1.1584	1.086
2		.9774	.9774	1.086	1.0029	1.0498	1.086
3	.905	.9412	.9412	1.0136	.9412	1.0136	.9774
4	.8688	.905	.9593	1.0136	.9412	.9412	.9774
5	.8326	.9412	.9774	1.0136	1.0136	.9412	1.086
6	.9412	.9593	1.0317	1.0136	1.0498	.9412	1.086
7	.905	.9774	1.0136	1.0059	1.0317	.9774	1.086
8	.905	.9593	.9412	.9877	.9231	1.0136	1.0242
9	.8413	.823	.905	.905	.9774		.9774
10	.8326	.905					.9412
11	.8869	.905					.8688
12	.8688						
13	.8688	1.1584				1.419	.8688
14	.905	1.0498		1.0498		1.1584	.8688
15	.9412	1.0498		1.1827		1.2308	
16	.9412		1.3756		1.3032		.9412
17	1.0136	1.2437	1.4632	1.2803	1.3756	1.39	.9511
18	.9774	1.0277	1.2803	1.2437	1.3169	1.2803	.9511
19	1.086	1.2071	1.4266	1.2567	1.2803	1.2803	
20		1.2536	1.4937	1.2936	1.267	1.39	1.1706
21	1.1765	1.267	1.3969	1.2803	1.3394	1.3756	
22	1.1403	1.2437	1.3432		1.3213	1.3937	1.3032
23	1.1946	1.086	1.267		1.3213	1.1946	1.1584
24	1.0498	1.0498	1.0498	1.2127	1.1765	1.1946	1.1946
Max	1.1946	1.267	1.4937	1.2936	1.3756	1.419	1.3032
Min	.8326	.823	.905	.905	.9231	.9412	.8688
Avg	.9564	1.0429	1.1587	1.1185	1.1482	1.1760	1.0302

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054061 / 33/11 KV. DHANORA ROAD S/S

Feeder No / Name : 201 / 11 KV. DHANORA ROAD FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7727		.8025			.8619	.8619
2	.7282		.8025			.8025	.8619
3	.7282		.7579			.8025	.8025
4	.7282		.7579			.8025	.7727
5	.8173		.7727			.8322	.8173
6	.9065		.8916			.9431	.9065
7	1.0402		.9659			.9957	.9362
8	.9214		.8322			.9065	.9214
9		.7727	.8655	.8362	.8322	.8069	.8173
10	.743	.7133	.7922	.7775	.7282	.8069	
11	.6241	.643	.7042	.7775	.6687	.6895	
12	.743	.6144	.6748	.6836	.6241	.7042	
13	.7282	.643	.7282	.7188	.6241	.7188	
14	.6836	.6371	.6836	.7188	.639	.7628	
15	.6984	.6687	.7579	.743	.639	.7922	
16	.7133	.7282	.6984	.8173	.6539	.8362	.7579
17		.6984	.743		.6687	.8802	
18		.7282	.9134		.6687	.9536	
19		.9362	.9214		1.1016	.9976	
20		1.1591			1.3256	1.0856	
21		1.0254			1.0254	1.0416	
22		.9214			.9659	.9829	
23		1.1576			.9659	.9536	
24	.7582		.8025			.8768	
Max	1.0402	1.1591	.9659	.8362	1.3256	1.0856	.9362
Min	.6241	.6144	.6748	.6836	.6241	.6895	.7579
Avg	.7709	.8031	.7934	.7591	.8087	.8682	.8456

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054061 / 33/11 KV. DHANORA ROAD S/S

Feeder No / Name : 202 / 11 KV. NAGAR ROAD FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8579	.6226	1.5406	.6706	.6897	1.7372	1.9448
2	1.7292	.5853	1.5101	.6318	.6462	1.6674	1.9128
3	1.7124	.5624	1.3824	.6196	.6043	1.5745	1.8115
4	1.6591	.5586	1.3458	.6005	.615	1.5783	1.7216
5	1.6148	.5357	1.3782	.5845	.5952	1.5207	1.7193
6	1.6933	.5342	1.2906	.5868	.5959	1.5367	1.765
7	1.6293	.5754	1.3359	.615	.442	1.5946	1.7307
8	1.6255	.6005	1.5093	.5998	.7324	1.4349	1.6095
9	.5693	1.502	1.7421	1.7559	1.6023	1.6514	1.633
10	1.3107	1.2486	1.6438	.2881	1.51	.3064	.5525
11	.5114	1.1679	1.4784		1.4792		.4923
12	1.2213	.4969	1.4586		1.454		.522
13	1.2803	1.3866	.5624	2.0249	.5586	1.9098	.5014
14	1.2868	1.3458		2.0218		1.8099	.5098
15	1.3439	1.2243		1.9631		1.813	.5289
16	1.3398	.5479	1.403	.6737	1.0589	.7217	1.6147
17	.4748	.9861	2.1338	.4862	1.5333		.5906
18	.519	1.4342	2.0881	.7103	1.6553	1.5059	.5944
19	.5807	1.4414	2.0264	.6615	1.6442	2.2405	.5982
20	.6592	1.7428	.7346	.708	1.8644	2.2916	.6554
21	.6836	1.7745	.7308	.7011	.8922	2.2619	
22	.679	1.7864	.7453	.7369	1.7432	2.1316	
23	.6897	1.7745	.7362	.7377	1.885	1.8841	.8383
24	1.9263	1.6743	1.6987	.7316	.7606	1.8613	.8391
Max	1.9263	1.7864	2.1338	2.0249	1.885	2.2916	1.9448
Min	.4748	.4969	.5624	.2881	.442	.3064	.4923
Avg	1.1916	1.0879	1.3852	.8686	1.1165	1.6683	1.1221

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054061 / 33/11 KV. DHANORA ROAD S/S

Feeder No / Name : 204 / 11 kv Express Civil NON SHEDDABLE EXPRESS HV FEEDERS
hospital F Feeder KV- 11 / (CONTINOUS PROCESS)(NO STAGGERING)
OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1281	.0823	.1635	.0633	.0922	.1642	.1658
2	.1467	.0812	.1532	.0617	.0846	.141	.1646
3	.1338	.0796	.1318	.0613	.0819	.1608	.1612
4	.1254	.0804	.1303	.0602	.0808	.1604	.1624
5	.117	.0789	.1482	.0583	.08	.1688	.1601
6	.1155	.0674	.1521	.0579	.0796	.1864	.1631
7	.1162	.0648	.1681	.0735	.077	.194	.1463
8	.1212	.0636	.1562	.0766	.0815	.1681	.1585
9	.1669	.1643	.1559	.1874	.1654	.2156	.1665
10	.1707	.2271	.1954	.1928	.1764	.2762	.0918
11	.1658	.2226	.2042	.1181	.2214	.2701	.1036
12	.1802	.2595	.2171	.0004	.2237	.2728	.0937
13	.1833	.2359	.2118	.179	.1882	.2728	.0922
14	.1604	.1806	.1768	.2099	.1734	.2324	.0907
15	.1353	.186	.17	.2065	.1619	.2061	.0808
16	.133	.1562	.1958	.1943	.1551	.2095	.1455
17	.0754	.1596	.1969	.1185	.165	.1939	.0815
18	.0793	.1669	.2149	.1254	.2111	.1916	.0831
19	.1017	.2001	.2053	.1086	.2009	.1502	.0983
20	.1006	.1772	.1059	.1196	.2161	.1973	.1017
21	.0998	.1768	.0972	.1029	.2073	.1768	
22	.1014	.1612	.0808	.1048	.1776	.1757	
23	.1021	.1593	.069	.0972	.1764	.1958	.0991
24	.1296	.096	.1406	.0983	.101	.1841	.0972
Max	.1833	.2595	.2171	.2099	.2237	.2762	.1665
Min	.0754	.0636	.069	.0004	.077	.141	.0808
Avg	.1287	.1470	.1600	.1115	.1491	.1985	.1231

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054061 / 33/11 KV. DHANORA ROAD S/S

Feeder No / Name : 205 / 11 KV BALEPEER FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4842		1.6057			1.7551	1.7013
2	1.448		1.5684			1.6804	1.6289
3	1.448		1.531			1.643	1.5927
4	1.3756		1.531			1.6057	1.5565
5	1.4842		1.531			1.643	1.6289
6	1.5203		1.6804			1.7924	1.8099
7	1.8099		2.0165			2.0165	1.9909
8	1.8461		2.0538			2.1658	2.1719
9		1.9044	1.8461	1.9185	2.0538		1.9753
10	1.4937	1.5497		1.9185	1.3672	1.9909	
11	1.3394	1.4563		1.5565	1.531	1.6108	
12	1.3443						
13	1.3443						
14	1.3443	1.6804	1.6651	1.6651	1.2483		
15	1.3443	1.531	1.6651	1.5927	1.5684		
16	1.4118	1.6057		1.7375		2.009	
17		1.643	1.9387			1.9909	1.5364
18		1.7551	2.0633		2.0538	1.9366	
19		2.0538	2.0271		2.1658	2.0271	
20		2.0165			2.2405	2.1719	
21		1.9044			2.0538	2.0271	
22		1.8671			2.0165	2.0271	
23		1.8671			1.9418	1.9185	
24	1.5384		1.4266			1.8671	
Max	1.8461	2.0538	2.0633	1.9185	2.2405	2.1719	2.1719
Min	1.3394	1.4563	1.4266	1.5565	1.2483	1.6057	1.5364
Avg	1.4736	1.7565	1.7433	1.7315	1.8401	1.8884	1.7593

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054061 / 33/11 KV. DHANORA ROAD S/S

Feeder No / Name : 206 / 11KV COLLECTOR OFFICE NON SHEDDABLE EXPRESS HV FEEDERS
 EXPRESS Feeder KV- 11 / (CONTINOUS PROCESS)(NO STAGGERING)
 OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.019		.0187			.0187	.0191
2	.0191		.0187			.0187	.0191
3	.0191		.0187			.0187	.0191
4	.0191		.0187			.0187	.0191
5	.0191		.0187			.0187	.0191
6	.0191		.0187			.0187	.0191
7	.019		.0187			.0187	.0191
8	.019		.0187			.0187	.0191
9		.0187	.0191	.0191	.0187	.0379	.0191
10	.0373	.0187	.0758	.0191	.0934	.0943	
11	.0373	.1494	.1517	.1517	.1494	.1888	
12	.0187	.1494	.1517	.1706	.1494	.1706	
13	.0187	.1494	.1517	.1698	.168	.1886	
14	.0187	.1307	.1327	.1509	.1494	.1706	
15	.0187	.1307	.1517	.1509	.168	.1517	
16	.0187	.1494	.1517	.1517	.1494	.1517	.0191
17		.1494	.1517		.056	.1509	.0191
18		.1494	.1327		.056	.0943	
19		.056	.0381		.0934	.0566	
20		.0373			.056	.0191	
21		.0187			.0187	.0191	
22		.0187			.0187	.0191	
23		.0187			.0189	.0191	
24	.0191		.0187			.0187	
Max	.0373	.1494	.1517	.1706	.168	.1888	.0191
Min	.0187	.0187	.0187	.0191	.0187	.0187	.0191
Avg	.0212	.0896	.0738	.1230	.0909	.0709	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054061 / 33/11 KV. DHANORA ROAD S/S

Feeder No / Name : 207 / 11 KV Natyagruh feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0271		2.2032			2.3339	2.1176
2	1.9185		2.0538			2.2965	2.0271
3	1.7918		1.9231			2.1845	1.9728
4	1.7194		1.9044			2.1098	1.8642
5	1.7194		1.9231			2.0538	1.828
6	1.8099		1.9605			2.0538	1.7737
7	1.8099		2.0165			2.0911	1.7556
8	1.7375		2.0165			1.9774	1.7737
9	1.7177	1.7924	1.828	1.8823	2.3712	1.9004	1.7375
10	1.7364	1.7924	1.828	1.8823	2.1658	1.9366	
11	1.7364	1.643	.4344	1.828	2.1098	1.8823	
12	1.7364	1.7924	.3258	1.8823	2.0911	2.009	
13	1.7551	1.8484	.3801	1.9004		1.9547	
14	1.8111	1.9231	2.2624	1.9004	1.9978	2.1357	
15	1.9044	1.9231	2.2986	2.0814	2.2218	2.1719	
16	1.9605	1.9044	2.1538	1.9366	2.2218	2.1719	2.0302
17		1.8484	2.2262		2.0538	2.1719	
18		1.8671	2.1176		2.1285	2.1538	
19		2.2779	2.2443		2.3152	2.3167	
20		2.4272			2.4646	2.3529	
21		2.4272			2.5206	2.4072	
22		2.4272			2.6242	2.4796	
23		2.4086			2.7073		
24	2.1377		2.2779			2.5206	
Max	2.1377	2.4272	2.2986	2.0814	2.7073	2.5206	2.1176
Min	1.7177	1.643	.3258	1.828	1.9978	1.8823	1.7375
Avg	1.8252	2.0202	1.8189	1.9117	2.2853	2.1594	1.8880

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054082 / 33/11 KV. MIDC S/S, BEED

Feeder No / Name : 201 / 11 KV. GORE FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601	.3086	.4801	.3429	.4287	.5144	.5658
2	.3601	.3086	.463	.3258	.4287	.4801	.5144
3	.3601	.3258	.5144	.3258	.4287	.463	.4458
4	.3601	.3258	.7545	.3258	.4287	.4801	.4115
5	.3772	.3429	.463	.3258	.4287	.4973	.4115
6	.3944	.3601	.4801	.3601	.4458	.5487	.463
7	.3944	.3772	.4458	.3429	.4287	.5658	.4801
8	.4287	.3772	.4115	.2572	.3601	.6001	.4287
9	.4287	.3361	.1886	.3944	.4481	.583	.5601
10	.5658	.4294	.1715	.5144	.5658	.5487	.5975
11	.583	.499		.6516	.5975	.583	.6413
12	.5658	.5788		.5144	.5658	.5487	.5975
13		.4854		.4115	.547	.4973	.5658
14	.5487	.6224		.5316	.7095	.4801	.5975
15	.6344	.6348	.2058	.5658	.6036	.6516	.5601
16	.6001	.5658	.2058	.5658	.6535	.6001	.5658
17	.6173	.506	.2058	.583	.6535	.583	.6036
18	.5658	.5218	.1886	.5487	.6908	.5316	.6535
19	.5658	.5155	.2572	.5144	.6413	.6173	.5658
20	.5658	.5228	.2572	.3086	.7095	.6173	.3772
21	.3772	.5601	.2915	.9602	.6908	.5658	.6413
22	.3429	.5658	.2743	.4801	.631	.583	.5975
23	.3258	.5601	.2743		.6979	.5658	.5601
24	.3601	.3258	.5415	.3429	.4458	.6908	.5658
Max	.6344	.6348	.7545	.9602	.7095	.6908	.6535
Min	.3258	.3086	.1715	.2572	.3601	.463	.3772
Avg	.4644	.4565	.3537	.4562	.5512	.5582	.5405

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054082 / 33/11 KV. MIDC S/S, BEED

Feeder No / Name : 202 / 11 KV. N.K. FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3544	.7316	.9907	1.0288	.9335	1.1202	.8687
2	.3544	.7164	.9907	1.0288	.964	1.1584	.8383
3	.3544	.6859	1.0593	1.0593	.964	1.0898	.8383
4	.3544	.6706	1.0212	1.0898	.964	1.1241	.8687
5	.3544	.7316	1.1279	1.1241	.9983	1.1584	.8687
6	.4535	.8078	1.1965	1.1241	1.0974	1.1888	.8687
7	.4668	.8382	1.1888	1.1584	1.025	1.0593	.964
8	.4877	.823	1.1279	1.1888	1.0631	1.0974	.9469
9	1.0669	.9556	.9393	1.1545	1.2635	1.2193	.9251
10	1.5089	1.2879	.7392	1.2879	1.3717	1.1888	1.1485
11	1.8595	1.5013	.3658	1.4137	1.5394	1.4442	1.2909
12	1.9052	1.406		1.5089	1.6034	1.4785	1.2193
13	1.6156	1.3108		1.2899	1.4365	1.2727	1.124
14	1.6614	1.3184		1.0898	1.2841	1.1545	1.14
15	1.7071	1.3245	.5963	1.0898	1.3813	1.2498	1.1393
16	1.829	1.3923	.5963	1.0936	1.5394	1.3108	1.0852
17	1.5852	1.4175	.6782	1.1279	1.4792	1.4137	.9251
18	1.5546	1.3946	.8078	1.2669	1.4784	1.4785	1.0486
19	1.5546	1.3756	.9755	1.305	1.3245	1.427	.9587
20	1.4327	.9541	.8001	1.1679	1.1766	1.1507	.7758
21	.9449	.8459	.8383	.9602	1.0829	1.0212	1.0791
22	.8536	.8718	1.0212	.985	.9069	.964	1.1461
23	.8535	.9633	.9869	.4877	1.2467	.8001	1.1583
24	.6287	.9755	1.0021	.9678	1.0859	.9571	.9602
Max	1.9052	1.5013	1.1965	1.5089	1.6034	1.4785	1.2909
Min	.3544	.6706	.3658	.4877	.9069	.8001	.7758
Avg	1.0726	1.0542	.9071	1.1249	1.2171	1.1886	1.0078

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054082 / 33/11 KV. MIDC S/S, BEED

Feeder No / Name : 203 / 11KV POLYTECHNIC COLLEGE FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.484	.4267	.3849	.3715	.402	.4497	.4497
2	.484	.3963	.402	.3715	.3544	.402	.4497
3	.484	.4116	.3849	.3715	.2934	.3849	.4192
4	.484	.4268	.3849	.3715	.2934	.4192	.4192
5	.5011	.4877	.3849	.3715	.2762	.4535	.4192
6	.6306	.5792	.3048	.2134	.0914	.5658	.5829
7	.8555	.6859	.3658		.2896	.804	.6611
8	.903	.6859	.2401	.7869	.6096	.5925	.6268
9	.7773	.6619	.7221	.7221	.3658	.3048	.5334
10	.8078	.7469	.2134	.0914	.6619		.5273
11	.6859	.6956			.6314		.5115
12	.4725	.2439			.3048		.4337
13	.4572						.4641
14	.442	.2187		.2286	.1619	.3086	.4314
15	.442	.5315	.6134	.5639	.4618	.6439	.4032
16	.5792	.3048	.7087	.5792	.4774	.7087	.4626
17	.5792	.5079	.7087	.5944	.493	.6744	.5555
18	.6554	.6321	.7087	.7621	.6346	.7087	.5704
19	.6859	.7244	.6916	.8212	.6041	.6364	.5391
20	.7011	.6735	.6744	.7774	.6165	.6916	.5243
21	.6554	.5853	.5754	.7221	.5639	.623	.4706
22	.5944	.4774	.5144	.6096	.493	.5144	.4641
23	.5182	.4337	.4668	.6992	.4799	.484	.4314
24	.5144	.3963	.3915	.4629	.4668	.4337	.484
Max	.903	.7469	.7221	.8212	.6619	.804	.6611
Min	.442	.2187	.2134	.0914	.0914	.3048	.4032
Avg	.5998	.5189	.4921	.5246	.4359	.5402	.4931

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054082 / 33/11 KV. MIDC S/S, BEED

Feeder No / Name : 204 / 11 KV BAHIRWADI FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0138	1.7985	.823	.6706	.8916	1.8594	1.9814
2	2.0138	1.768	.7926	.5792	.8916	1.7985	1.9662
3	1.9833	1.8747	.7621	.4572	1.8975	1.8328	1.9204
4	1.9833	2.0119	.7926	.4572	1.928	1.7985	1.8899
5	2.0233	2.3472	.823	.4572	1.608	1.9814	1.9814
6	2.4996	2.6063		.3658	2.4691	2.4691	2.3624
7	2.6368	2.5301			1.0517	2.6216	2.4844
8	2.3472	2.1338	1.0974		1.0059	2.4387	2.3624
9	.8383	.9374	1.1317	.2743	.9374		.9145
10	.7621	1.8793	.6401		.8421	1.0974	.8124
11	1.6614	1.8077		.2286	.6249	.8535	1.9708
12	.6706	1.6019		.7202	1.4404	.8916	1.8168
13	.6097	1.6339		.8573	1.6156	.7316	1.704
14	.6401	1.5242		.7621	.5693	.7316	1.704
15	.6706	.7316	.884	.7316	1.6232	.7316	.6325
16			.8688		.9145		.6958
17	1.7071	.6478	.8535	.7545			.8124
18	.8535	1.7879	.884		.9717	2.0424	.9488
19	.9755	2.1452	.7316	.9907	1.0753	.9755	.8436
20	2.4996	2.5073	1.0364	1.1317	2.3411	1.0364	2.2237
21	2.1034	2.3472	.6097	1.0802	2.4463	2.2862	2.1567
22	1.9814	2.149	.6097	1.046	2.2832	2.3873	2.1605
23	1.9205	2.0119	.5792		2.1704	2.1033	2.0348
24	2.0748	1.8595	.8124	1.8595	2.0843	2.1376	1.9509
Max	2.6368	2.6063	1.1317	1.8595	2.4691	2.6216	2.4844
Min	.6097	.6478	.5792	.2286	.5693	.7316	.6325
Avg	1.6291	1.8540	.8184	.7458	1.4645	1.6574	1.6804

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054082 / 33/11 KV. MIDC S/S, BEED

Feeder No / Name : 205 / 11 KV MAULI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.4287	.5144	.583	.5487	.5487	.5144
2	.5487	.4287	.5316	.5487	.5487	.5144	.4801
3	.5487	.4287	.5144	.5144	.5487	.5487	.4458
4	.5487	.4973	.5144	.5144	.5487	.5144	.4458
5	.5316	.4973	.4973	.5144	.5316	.4973	.4287
6	.5658	.5144	.463	.6173	.6001	.5658	.463
7	.6001	.5144	.4973	.6344	.6687	.583	.4973
8	.6173	.5487	.4973	.6687	.583	.6001	.5487
9	.703	.7602	.4115		.6878	.6173	.5959
10	.7202	.7362	.4801		.7362	.703	.6697
11	.7202	.6836			.7619	.6516	.6201
12	.7202	.7796			.7282	.6344	.6089
13	.6859	.7783			.7011	.6344	.6379
14	.6859	.7964			.6935	.6173	.6415
15	.6859	.7712	.4801		.2103	.6687	.6135
16	.6859	.8145	.5487	.7888	.7442	.6859	.6556
17	.7202	.8326	.5144	.7545	.7888	.6859	.6722
18	.0754	.788	.4973	.703	.8775	.6859	.5959
19	.7545	.8417	.5316	.7716	.7167	.7545	.5548
20	.7373	.7011	.5487	.6173	.7095	.7202	.5847
21	.5658	.6805	.583	.6516	.7356	.6344	.4733
22	.5144	.5959	.583	.6516	.631	.5487	.5258
23	.4801	.6135	.5658		.6068	.5144	.5611
24	.5487	.463	.5611	.583	.6173	.5959	.5144
Max	.7545	.8417	.583	.7888	.8775	.7545	.6722
Min	.0754	.4287	.4115	.5144	.2103	.4973	.4287
Avg	.6047	.6456	.5168	.6323	.6469	.6135	.5562

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054116 / 33/11 KV BARSHI ROAD S/ST

Feeder No / Name : 201 / 11 KV DOODH DAIRY FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.7097	.3658	.7097	.3658	.3963	.3963
2	.3353	.3353	.3353	.7097	.3658	.3658	.3963
3	.3353	.3353	.3353	.7316	.3353	.3658	.3963
4	.3353	.3353	.3353	.7278	.3353	.3353	.3963
5	.3353	.3658	.3658	.7682	.3658	.3658	.3963
6	.5182	.4877	.4877	1.0307	.5182	.4572	.4572
7	.6401	.6706	.5487	.2439	.6097	.5792	.6097
8	.6706	.6401		1.3473	.5792	.5792	.6097
9	.6401	.5487	.6706	1.1774	.5487	.5487	.6097
10	.5182	.5487	.4268	.5792	.5182		.5487
11	.5487	.4877		.5249	.5182		.5182
12	.4572	.4877	.5487	.5182	.4877	.6097	.4572
13	.4572	.4268	.5182	.4877	.4268	.5487	.4572
14	.3963	.3353	.4572	.4268	.4268	.4877	.4572
15	.3963	.3048	.4572	.3658	.4268	.4268	.3658
16	.3048	.061	.2743	.3048	.0914	.3048	.3353
17	.4268						.3658
18	.4268	.4572	.5487	.4572	.4572	.4572	.4268
19	.5182	.5487	.5487	.5792	.5792	.6401	.4877
20	.5792	.5792	.6097	.6097	.6097	.6706	
21	.5487	.5792	.5487	.5792	.5487	.6401	
22	.4572	.4877	.4877	.5182	.4877	.5182	.5487
23	.4268	.4268	.4572	.4268	.4572	.4572	.4572
24	.7545	.7366	.3963	.7621	.4268	.3963	.3658
Max	.7545	.7366	.6706	1.3473	.6097	.6706	.6097
Min	.3048	.061	.2743	.2439	.0914	.3048	.3353
Avg	.4896	.4737	.4630	.6342	.4559	.4834	.4572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054116 / 33/11 KV BARSHI ROAD S/ST

Feeder No / Name : 202 / 11KV Somesher feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5301	2.5362	2.5605	2.7069	1.5242	1.5546	1.4632
2	1.2498		1.3413	2.5368	1.4327	1.4327	1.3717
3	1.1888		1.2498	2.3243	1.3413	1.3717	1.3108
4	1.1584		1.2193	2.3167	1.3108	1.3413	1.2498
5	1.1888		1.2498	2.3606	1.3108	1.3413	1.2498
6	1.3108		1.3108	1.4022	1.4022	1.3413	1.2803
7	1.4632		1.4632	2.7845	1.4632	1.5242	1.4632
8	1.4632		1.5242	2.9179	1.5242	1.5242	1.4937
9	1.4327		1.4022	2.8207	1.5242	1.5242	1.4632
10	1.4327		1.3717	2.8594	1.4937	1.5242	1.4632
11	1.4022		1.3413	2.7178	1.4022	1.4327	1.3717
12	1.3108		1.3717	1.3717	1.3717	1.4022	1.2803
13	1.2498	1.2498	1.3108	1.3413	1.4022	1.3108	1.2193
14	1.4022	1.2193	1.3413	1.3413	1.3413	1.4022	1.2498
15	1.3413	1.1888	.7316	2.5606	1.3717	1.3717	1.2193
16	1.3108	1.2803		1.3413	1.4022	1.4022	1.0974
17	1.3413	1.3413	1.6766	1.3717	1.4022	1.4327	1.3413
18	1.3413	1.3108	1.5546	1.4327	1.4327	1.4327	1.4022
19	1.4632	1.4022	1.5851	1.4632	1.5242	1.5546	1.4022
20	1.6156	1.6461	1.6766	1.6156	1.5851	1.5851	
21	1.6461	1.6461	1.7071	1.6156	1.6156	1.6156	
22	1.5851	1.5851	1.7071	1.5546	1.5851	1.5546	1.5851
23	1.5851		1.6766	1.7071	1.6766	1.5851	1.7985
24	2.7679	2.694	1.5851	2.9176	1.6156	1.5242	1.7985
Max	2.7679	2.694	2.5605	2.9179	1.6766	1.6156	1.7985
Min	1.1584	1.1888	.7316	1.3413	1.3108	1.3108	1.0974
Avg	1.4909	1.5917	1.4764	2.0576	1.4607	1.4619	1.3898

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054116 / 33/11 KV BARSHI ROAD S/ST

Feeder No / Name : 204 / 11 KV Jyotiba Feeder
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0362	.0457	.0419	.04
2				.0381
3				.0419
4				.0476
5				.0553
6				.061
9				.0686
11				.1029
12				.0895
16				.0667
24	.0381	.0457		.0476
Max	.0381	.0457	.0419	.1029
Min	.0362	.0457	.0419	.0381
Avg	.0372	.0457	.0419	.0599

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054125 / 33/11 KV JALANA ROAD S/STN

Feeder No / Name : 201 / 11 KV WASANWADI AG FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0895		.0886	.0857		
2	.0857	.0895		.0886	.0857		
3	.0857	.0895		.0886	.1029		
4	.1029	.0895		.1063	.0857		
5	.1372	.1254		.1417	.12		
6	.1715	.2149				.197	
7		.2328					
8	.12	.2658	.2149	.2303	.2401	.2507	
9	.1595		.2126		.2481	.2572	.197
10		.2328	.2126		.2126	.2058	.1772
11				.2149	.1772	.2058	
12							.1417
13	.1595						.124
14							.124
15		.1075	.1227	.1791	.124	.1029	.1063
16	.1595		.1772	.2507	.2103		.1063
17	.1417		.2126			.2103	.12
18	.2126		.2103		.2686	.2103	.1543
19	.2126	.197	.2126			.1928	.1463
20	.1791		.1772			.1949	.12
21	.1612		.1595		.1612	.1417	.1029
22	.1254		.1417				.1029
23	.1075	.0895	.124		.1254		.1029
24	.0857	.0895		.0886	.1029		
Max	.2126	.2658	.2149	.2507	.2686	.2572	.197
Min	.0857	.0895	.1227	.0886	.0857	.1029	.1029
Avg	.1385	.1472	.1815	.1477	.1567	.1972	.1304

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054125 / 33/11 KV JALANA ROAD S/STN

Feeder No / Name : 202 / 11 KV SHANTAI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3679	1.2056	.6775	1.3985	1.4053	.7537	.804
2	1.2833	1.1736	.6645	1.3642	1.374	.6981	.7796
3	1.2643	1.1553	.6302	1.3128	1.2993	.6714	.7567
4	1.2513	1.1287	.6272	1.2839	1.2688	.647	.7316
5	1.1889	1.1538	.5998	1.2365	1.2232	.6562	.6927
6	1.2216	1.2502	.6615	1.3645	1.2811	1.4465	.7019
7	.6401	1.2258	1.3313	1.4926	1.3024	.7552	.7057
8	1.3267	1.2416	1.3005	1.4754	1.2773	1.4804	.6798
9	1.218	.6615	1.3659	.6897	1.3462	1.3664	1.2967
10	.6325	1.3077	1.4074	.7049	1.2707	1.5684	1.1954
11	.618	.6729	.756	1.4178	1.3009	1.6781	.6546
12	.6295	.6889		.7026	.4976	1.7718	1.2485
13	1.3337	.6996		.663		1.7184	1.237
14	.6737	.695	1.2035	.7019		1.6271	1.2454
15	.7171	1.4739	1.8244	1.4087	1.2034	1.675	1.2553
16	1.3352	.7758	1.8145	.5091	1.9585	.8779	1.3132
17	1.4165	.7735	1.7249	1.7337	.9564	1.6346	1.384
18	1.4112	.8032	1.6057	1.7131	1.9033	1.5821	.4214
19	1.4615	3.1573	1.7269	1.6057	.9374	1.6994	
20	1.4971	.8162	1.683	1.6057	.9518	.8711	
21	1.4285	.7491	1.5859	1.5318	1.688	1.4914	.0511
22	1.3732	.7484	1.3801	1.5798	.8863	.8086	1.826
23	1.3771	1.5341	1.459	1.4678	1.6792	.8383	1.919
24	1.3763	1.3386	.7811	1.3714	1.5592	.7247	.852
Max	1.4971	3.1573	1.8244	1.7337	1.9585	1.7718	1.919
Min	.618	.6615	.5998	.5091	.4976	.647	.0511
Avg	1.1685	1.1013	1.2187	1.2640	1.2987	1.2101	.9887

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054125 / 33/11 KV JALANA ROAD S/STN

Feeder No / Name : 203 / Ambika Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.3331	4.3678	2.3617	4.6319	5.1212	2.4996	2.6277
2	3.9674	3.9247	2.1681	4.4054	4.9711	2.4714	2.4554
3	3.8424	3.7575	2.098	4.1697	4.7935	2.3503	2.2862
4	3.8431	3.6466	2.0576	3.9784	4.4658	2.2756	2.2253
5	3.8005	3.6652	2.066	3.9285	4.3926	2.1872	2.1719
6	3.988	3.842	2.0431	4.0188	4.5184	4.3938	2.1483
7	2.0386	3.9578	4.2337	4.145	2.5713	2.3381	2.2009
8	3.7929	3.852	4.1774	4.0272	4.3934	4.3644	2.1552
9	3.3903	1.9784	4.0851	2.0972	4.3283	4.2593	3.954
10	1.7185	3.6523	3.6791	2.0828	4.2238	2.162	3.9051
11	1.8176	1.89	2.114		4.1185		1.9883
12	1.8564	1.7711			2.1468		3.6748
13	3.5711				2.0022		3.5871
14	1.9182	2.476		2.8266		5.5365	3.9241
15	1.9555	4.5828	5.8108	5.4851		5.596	4.0596
16	3.9666	2.303	5.7629	2.7587	5.8909	2.9119	4.0209
17	4.0238	1.4281	5.4218	5.2599	2.998		4.0763
18	4.0185	2.585	5.186	5.1465	5.3422	5.4504	4.1541
19	4.502	4.7051	5.0762	5.2149	2.7465	5.6867	4.5069
20	4.7592	2.6962	5.3703	5.5668	2.9851	6.016	4.5687
21	4.7211	2.6703	5.4336	5.4767	5.6508	5.8484	4.8194
22	4.787	2.6437	5.1806	5.4323	2.8982	2.9835	5.362
23	4.8018	5.0255	5.0126	5.3412	5.5605	2.9035	5.4222
24	4.5862	4.7596	2.6071	4.9487	5.4009	2.7831	2.7138
Max	4.8018	5.0255	5.8108	5.5668	5.8909	6.016	5.4222
Min	1.7185	1.4281	2.0431	2.0828	2.0022	2.162	1.9883
Avg	3.5833	3.3122	3.9022	4.3306	4.16	3.7509	3.4587

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054125 / 33/11 KV JALANA ROAD S/STN

Feeder No / Name : 204 / 11 KV Vitthal Mandir

SHEDDABLE URBAN

Feeder Feeder KV- 11 /
OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258	.2686		.2835	.362		
2	.3077	.2686		.2658	.362		
3	.2715	.2686		.2658	.362		
4	.2715	.2686		.2658	.3258		
5	.2534	.2686		.2658	.2896		
6	.2896	.2328		.3544	.3077	.3403	
7		.3045	.3045	.3721			
8	.2534	.2658	.3045	.3721	.3258	.3045	
9	.2126		.2481	.3012	.2835	.3077	.2507
10		.2328	.2481		.2303	.2534	.2481
11				.2686	.1949	.2715	
12					.2229	.2896	.2658
13	.2126				.2572	.3077	.2658
14			.2481		.2572	.3077	.2658
15		.2686	.2804	.2865	.3012	.3077	.2658
16	.2481		.3189	.2865	.298		.2658
17	.2126		.3544	.2715		.2629	.2715
18	.1595		.3155	.2896	.2686	.2629	.2926
19	.1595	.2865	.3544	.3258		.2804	.3439
20			.3898	.3801		.3544	.3439
21	.3761		.3898	.362	.3761	.3544	.362
22	.3761		.3544	.3801			.3982
23	.3224	.3582	.3366	.3801	.4477		.3801
24	.3258	.3224		.3012	.3801		
Max	.3761	.3582	.3898	.3801	.4477	.3544	.3982
Min	.1595	.2328	.2481	.2658	.1949	.2534	.2481
Avg	.2693	.2780	.3177	.3139	.3080	.3004	.3014

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054125 / 33/11 KV JALANA ROAD S/STN

Feeder No / Name : 205 / 11 kv Jain Patra Feeder SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3378	.3639	.2412	.4424	.415	.2218	.2271
2	.3083	.3548	.2374	.4321	.4058	.208	.2115
3	.301	.3643	.2176	.4073	.3866	.1993	.1985
4	.3207	.3673	.2134	.3616	.2774	.1947	.1936
5	.3448	.3879	.2164	.3692	.254	.2122	.2031
6	.4157	.5018	.2862	.4664	.3292	.517	.2431
7	.2397	.5079	.5159	.5354	.2336	.3338	.3056
8	.4565	.5321	.5452	.5407	.5811	.7293	.3258
9	.4835	.3083	.5523	.2545	.5484	.6762	.6017
10	.2789	.5483	.5485	.2915	.4969	.5119	.5539
11	.2766	.2964	.2801	.6406	.5419	.5756	.3128
12	.3102	.2355		.3399	.538	.5251	.5245
13	.5142	.1612		.3189	.5457	.5495	.4574
14	.2774	.2747	.2658	.2945	.5106	.5556	.4548
15	.2618	.4553	.3475	.4946	.4856	.5091	.4633
16	.5678	.2301	.4519	.2603	.5715	.2991	.4786
17	.5447	.306	.4962	.542	.3048	.5864	.5222
18	.679	.2801	.7422	.7167	.6851	.5361	.2968
19	.6504	.3944	.5998	.7127	.365	.5178	.0011
20	.5136	.3273	.6742	.667	.3601	.5085	.0156
21	.4081	.3567	.6266	.6083	.6245	.5093	.3509
22	.4603	.2884	.6468	.5531	.2961	.269	.4475
23	.4233	.5346	.5706	.5036	.5281	.2747	.4193
24	.3854	.4474	.2702	.4969	.486	.2519	.2046
Max	.679	.5483	.7422	.7167	.6851	.7293	.6017
Min	.2397	.1612	.2134	.2545	.2336	.1947	.0011
Avg	.4067	.3677	.4339	.4688	.4488	.4280	.3339

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 057002 / 132/11 KV S/S, BEED

Feeder No / Name : 201 / 11 KV BARSHI NAKA FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.4387	2.7435	1.5242	1.5242	1.5242	1.5242
2		2.1338	2.4387	1.5242	1.5242	1.5242	1.5242
3		2.1338	2.4387	1.5242	1.5242	1.5242	1.5242
4		2.1338	2.4387	1.5242	1.5242	1.5242	1.5242
5		2.4387	2.4387	1.5242	1.5242	1.5242	1.5242
6		2.7435	3.0483	1.829	1.829	1.829	1.829
7		3.9628	1.5242	.6097	.6097	2.4387	2.4387
8		4.2676				2.7435	2.7435
9		4.2676	4.5725	3.0483	3.0483	6.3649	2.7435
10		3.658	2.7435			1.5339	2.4387
11		3.0483			2.1338	1.5912	2.1338
12		2.7435	1.5242	2.4387	1.829	3.8324	1.829
13		2.7435		2.1338	1.829	3.4949	1.829
14		2.4387		1.829	1.829	5.8333	1.5242
15		2.4387		1.829	1.829	5.9042	1.5242
16		.9145		.6097	.6097	.6097	1.5242
17							1.829
18	2.4387	3.9628			2.4387	2.4387	2.1338
19	2.4387	4.2676	3.0483		2.7435	3.0483	2.4387
20	4.6468	4.2676	3.3532		2.7435	2.7435	2.4387
21	5.4889	5.9625	2.7435		2.4387	2.4387	2.1338
22	3.0483	5.1334	2.1338		2.1338	2.1338	1.829
23	2.7435	4.6982	1.829		1.829	1.829	1.829
24	2.4387	2.1338	1.829	2.1338	1.5242	1.829	1.5242
Max	5.4889	5.9625	4.5725	3.0483	3.0483	6.3649	2.7435
Min	2.4387	.9145	1.5242	.6097	.6097	.6097	1.5242
Avg	3.3205	3.2579	2.5530	1.7201	1.8580	2.6199	1.9306

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 057002 / 132/11 KV S/S, BEED

Feeder No / Name : 202 / 11 KV. KANKALESHWAR

SHEDDABLE URBAN

FEEDER Feeder KV- 11 /
OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.9145	.9145	.9145	1.2193	1.2193	1.2193
2	.9145	.9145	.9145	.9145	.9145	.9145	.9145
3	.9145	.9145	.9145	.9145	.9145	.9145	.9145
4	.9145	.9145	.9145	.9145	.9145	.9145	.9145
5	.9145	.9145	.9145	.9145	.9145	.9145	.9145
6	1.2193	1.2193	1.2193	1.2193	1.5242	1.2193	1.2193
7	1.5242	1.5242	1.5242	.3048	1.5242	1.5242	1.5242
8	1.5242	1.5242	1.829	1.829	1.829	1.5242	1.5242
9	1.5242	1.5242	1.829	1.829	1.829	1.829	1.5242
10	1.2193	1.2193			1.5242		1.5242
11	1.2193	1.2193			1.2193		1.2193
12	.9145	.9145		1.5242	1.2193	1.5242	1.2193
13	.9145	.9145		1.2193	1.2193	1.2193	.9145
14	.9145	.9145		1.2193	.9145	.9145	.9145
15	.9145	.9145	1.2193	1.2193	.9145	.9145	.9145
16	.6097	.6097	.3048	.3048	.3048	.3048	.9145
17							1.2193
18		1.2193	1.5242	1.5242		1.5242	1.2193
19		1.5242	1.5242	1.5242	1.5242	1.829	1.2193
20		1.5242	1.5242	1.5242	1.5242	1.5242	1.5242
21		1.5242	1.5242	1.2193	1.5242	1.5242	1.2193
22		1.2193	1.2193	1.2193	1.2193	1.2193	1.2193
23		1.2193	1.2193	1.2193	1.2193	1.2193	1.2193
24	1.2193	1.2193	1.2193	1.2193	1.2193	1.2193	1.2193
Max	1.5242	1.5242	1.829	1.829	1.829	1.829	1.5242
Min	.6097	.6097	.3048	.3048	.3048	.3048	.9145
Avg	1.0759	1.1531	1.2363	1.1758	1.2332	1.2338	1.1812

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 057002 / 132/11 KV S/S, BEED

Feeder No / Name : 203 / 11 KV. INDUSTRIAL FEEDER SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4572	.7621	.7621	.7621	.9145	.9145
2	.4572	.4572	.7621	.6097	.7621	.9145	.9145
3	.4572	.4572	.6097	.6097	.7621	.7621	.9145
4	.4572	.4572	.6097	.6097	.7621	.7621	.7621
5	.4572	.4572	.6097	.6097	.7621	.7621	.9145
6	.4572	.4572	.6097	.7621	.7621	.9145	.9145
7	.7621	.7621	.7621	.9145	.7621	.9145	.9145
8	.7621	.7621	.7621	.9145	.9145	.9145	.9145
9	.9145	.9145	.7621	1.0669	1.0669	.9145	.9145
10	1.0669	1.0669	1.0669	1.2193	1.2193	1.2193	.9145
11	1.3717	1.3717	1.0669	1.2193	1.3717	1.2193	.9145
12	1.2193	1.2193	1.3717	1.2193	1.2193	1.2193	.7621
13	1.0669	1.0669	1.2193	1.0669	1.2193	1.2193	.7621
14	1.2193	1.2193		.9145	1.2193	1.0669	.6097
15	1.0669	1.0669		.7621	.9145	.9145	.6097
16	1.0669	1.0669		.9145	1.2193	.9145	.6097
17	1.3717	1.3717		1.0669	1.3717	1.0669	.7621
18		1.3717	1.5242	1.0669	1.5242	1.3717	.7621
19			1.5242	1.0669	1.3717	1.0669	.9145
20			1.2193	.7621	1.0669	1.0669	.7621
21		.7621	.9145	.7621	1.0669	.9145	.7621
22		.9145	.9145	.7621	.9145	1.0669	.7621
23		.9145	.9145	.7621	.9145	.9145	.7621
24	1.3717	.9145	.7621	.7621	.9145	.9145	.7621
Max	1.3717	1.3717	1.5242	1.2193	1.5242	1.3717	.9145
Min	.4572	.4572	.6097	.6097	.7621	.7621	.6097
Avg	.8891	.8868	.9374	.8828	1.0352	.9971	.8129

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 057002 / 132/11 KV S/S, BEED

Feeder No / Name : 204 / 11 KV. PANGRI ROAD FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145		1.0669	.9145	1.0669	1.0669
2	.7621		.9145	.9145	.9145	1.0669
3	.7621		.9145	.9145	.9145	.9145
4	.7621		.9145	.9145	.9145	.9145
5	.9145		.9145	1.0669	.9145	1.0669
6	1.0669		1.2193	1.3717	1.0669	1.2193
7	1.3717		.4572	1.5242	1.3717	1.5242
8	1.5242		1.6766	1.6766	1.5242	1.5242
9	1.5242		1.6766	1.6766	1.3717	1.5242
10	1.2193			1.3717		1.2193
11	1.0669			1.2193		1.2193
12	.9145		1.2193	1.0669	1.2193	1.0669
13	.9145		1.2193	1.0669	1.2193	.9145
14	.7621		1.0669	.9145	1.0669	.9145
15	.9145		1.0669	.9145	1.0669	.9145
16	.7621		.3048	.3048	.4572	.9145
17						1.0669
18			1.5242		1.3717	1.2193
19			1.6766	1.5242	1.6766	1.3717
20		.7621	1.5242	1.5242	1.6766	1.3717
21		1.5242	1.3717	1.5242	1.5242	1.2193
22		1.3717	1.2193	1.2193	1.2193	1.2193
23		1.2193	1.0669	1.2193	1.2193	1.0669
24	1.2193	1.0669	1.0669	1.0669	1.0669	1.0669
Max	1.5242	1.5242	1.6766	1.6766	1.6766	1.5242
Min	.7621	.7621	.3048	.3048	.4572	.9145
Avg	1.0221	1.1888	1.1467	1.1778	1.1830	1.1495

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 057002 / 132/11 KV S/S, BEED

Feeder No / Name : 407 / 33 KV Incomer JALNA ROAD SHEDDABLE URBAN
Feeder KV- 33 / INCOMING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	20.6819	19.7703	10.974	16.6958	24.2261	11.5226	12.0713
2	19.5788	18.6729	10.4253	15.8813	23.1653	11.5226	11.5226
3	18.546	18.51	9.8766	14.6777	22.3949	10.974	10.974
4	18.8204	17.7984	9.8766	14.2353	20.7317	10.4253	10.4253
5	18.1071	18.1242	9.8766	14.0227	20.4602	10.4253	10.4253
6	19.7532	20.0361	10.4253	13.7569	20.4665	22.0508	10.974
7	10.4253	20.259	20.6448	14.0759	12.0713	12.0713	11.5226
8	19.2593	20.6448	15.7951	15.775	21.7832	23.311	11.5226
9	18.1842	10.974	15.0669	10.4253	15.9876	12.0713	20.7477
10	9.3279	19.8812	14.6246	10.974	15.775	9.8766	19.7737
11	9.3279	10.4253	10.974	9.9938	15.1733	5.487	10.4253
12	9.8766	9.3279		4.9383	11.6427	5.487	18.6472
13	18.7535	3.2922		3.2922	3.1379	4.3896	18.5803
14	9.8766	10.974		11.5226	2.3148	12.0713	19.0639
15	9.8766	20.9592	18.8706	24.0523	5.8454	12.62	19.7737
16	20.1527	10.974	19.5285	12.7829	14.8726	13.1687	19.6126
17	20.6448	9.8766	13.7706	25.8436	14.8148	6.1706	19.9275
18	20.9672	12.62	18.6077	25.8745	21.6507	13.77	17.6784
19	22.4828	23.1967	18.2716	26.3146	14.2661	13.77	16.5227
20	22.1708	12.62	18.8734	27.4348	14.8148	14.3193	16.5758
21	22.7623	12.62	18.8203	26.3374	27.4606	18.9266	17.8156
22	23.1481	12.0713	17.9527	25.8436	14.2661	13.7174	24.4456
23	22.7137	24.3484	17.3508	25.24	26.6947	18.9266	25.7665
24	21.1797	22.3337	12.62	17.2445	26.2083	13.1687	13.1687
Max	23.1481	24.3484	20.6448	27.4348	27.4606	23.311	25.7665
Min	9.3279	3.2922	9.8766	3.2922	2.3148	4.3896	10.4253
Avg	17.7757	15.8463	14.9155	16.9681	17.0927	12.5102	16.1651

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 057002 / 132/11 KV S/S, BEED

Feeder No / Name : 408 / 33 KV Incomer MALIVES

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.0503	5.104	5.3212	6.0814	5.9728	6.0814	5.8642
2	4.9429	4.8868	5.2126	5.8642	5.5384	5.647	5.647
3	4.8868	4.9954	5.104	5.5384	5.4298	5.5384	5.4298
4	4.7782	4.8868	5.2126	5.4298	5.4298	5.4298	5.2126
5	4.6696	4.8868	5.2126	5.4298	5.4298	5.4298	5.4298
6	4.9954	4.9954	5.4298	5.7065	5.7065	5.4298	5.5384
7	5.2126	5.2126	5.647	5.9259	5.8162	5.4298	5.5384
8	5.104	5.104	5.5384	5.8162	5.8162	5.647	5.647
9	5.048	5.1578	5.647	3.5837	5.8642		5.8642
10	5.2126	3.5837		2.9012		2.9321	5.3212
11	5.3212	5.7556			5.8642	2.8235	5.5384
12	5.2126	2.6337				2.7149	
13	5.2126	4.8868			2.9321	5.4298	5.3212
14	5.4298	6.0814		5.9728		5.104	5.647
15	5.5384	5.9728	3.1493	4.8868	2.6063	5.104	
16	5.647	2.8235	5.647		5.4298	3.1493	5.647
17	5.4298	6.8039	7.8189	6.8416	5.2675	7.2428	5.647
18	5.8642	6.4072	7.6818	6.9502	7.1331	7.2074	5.8642
19	6.733	7.2428	8.0361	7.3525	7.4623	7.6818	
20	6.6244	7.1674	8.011	7.3525	7.1994	7.7915	6.9856
21	6.4072		7.4932	6.9136	7.0588	7.1674	
22	6.19		6.9502		6.9136	6.9502	6.2986
23	5.3212	5.8642	6.5158		6.6244	6.6244	6.0814
24	5.3727		5.4298	6.3649	6.2986	6.2986	6.4072
Max	6.733	7.2428	8.0361	7.3525	7.4623	7.7915	6.9856
Min	4.6696	2.6337	3.1493	2.9012	2.6063	2.7149	5.2126
Avg	5.4252	5.2596	6.0557	5.8284	5.7997	5.6024	5.7465

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 057002 / 132/11 KV S/S, BEED

Feeder No / Name : 409 / 33 KV Incomer DHANORA ROAD

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	18.0367		18.1482			20.2767	19.0059
2	17.1388		17.588			19.9406	18.8043
3	16.8702		16.6918			19.4365	18.6431
4	16.2792		17.7561			19.0444	17.5686
5	16.9776		18.0361			19.2684	17.9984
6	18.2133		19.1004			21.0048	19.6102
7	19.2879		21.1729			22.5732	20.5773
8	17.3537		20.2206			20.8928	20.7922
9	18.3722	19.7165	19.4904	19.975	22.2371	14.0764	19.2879
10	16.1877	16.4118	12.3571	14.9897	18.8763	15.8494	
11	12.0428	15.5716	7.7904	13.8615	17.588	14.345	
12	15.6276	9.1861	7.4143	9.0991	11.6507	10.2081	
13	15.9077	12.2668	4.8995	13.3242	9.9143	13.754	
14	15.8516	17.42	15.1831	18.2133	14.3393	13.5928	
15	16.5238	16.6358	15.6139	18.5894	15.0115	13.9152	
16	16.8599	14.4513	13.4602	15.0435	12.8269	16.7627	17.0313
17		17.1399	20.2442		12.4349	16.8702	
18		17.7561	20.2442		19.6045	20.0938	
19			20.8903		21.621	21.9742	
20		7.9538			23.7495	23.0487	
21		22.2371			22.6852	22.4577	
22		21.565			22.5172	22.0279	
23		21.3969			22.7972	14.345	
24	18.6828		20.3887			21.621	
Max	19.2879	22.2371	21.1729	19.975	23.7495	23.0487	20.7922
Min	12.0428	7.9538	4.8995	9.0991	9.9143	10.2081	17.0313
Avg	16.8361	16.4078	16.3345	15.3870	17.8569	18.2241	18.9319

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054003 / 33/11 KV. CHOUSALA

Feeder No / Name : 201 / 11 KV. CHOUSALA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3138		.6371	.4039	.3029		
2	.3361		.5441	.4268	.3601		
3	.4134	.7087	.6192	.4268	.3029		
4	.6276	.8859	.7072	.5335	.3534		
5	.5975	1.0387	.7087	.5335	.4544		
6	.6508	1.1043	.8421	.5655	.5049		
10	.8573	.5697	.4268	.6554	.4268		
11		.6737	.4039	.4268		.7659	
12			.6188	.7274		.6811	
13	.8682	.8478		.6554	.7802	.8383	.4268
14	.7455	.6783		.4694	.7186		.5335
15		.6144		.4039			.3414
16	.7712	.5441		.4694	.3174		.5049
17	.7282	.6081	.4268	.5441	.6201		.3934
18	.8059		.3201	.3938			.6192
19		.7461	.8697	.4268			.6478
20	.7628	.8817	.5335	.4374	.8417		
21		.8478	.4801	.4039	.9391		
22	.6805	.4481	.3734	.3841			
23	.695	.6706	.3201	.032	.7164		.4954
24	.3574	.6036	.6274	.4744	.3029	.6219	.2743
Max	.8682	1.1043	.8697	.7274	.9391	.8383	.6478
Min	.3138	.4481	.3201	.032	.3029	.6219	.2743
Avg	.6382	.7336	.5564	.4664	.5295	.7268	.4707

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054003 / 33/11 KV. CHOUSALA

Feeder No / Name : 202 / 11 KV. SULTANPUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0269		.9156	.3201	.3029		
2	1.0002		.9496	.3201	.6059		
3	1.086	1.4327	1.0174	.3201	.6401		
4	1.1584	1.387	1.2717	1.0669	.7068		
5	.9816	1.6289	1.3413	1.0669	.8078		
6	1.1736	1.9281	1.6956	1.1736	1.0098		
7	1.0098	1.0669	1.95	1.0669	1.2803		
8		1.0669	1.8652	1.0669	.9602		
9	1.7147	1.6766	1.1736	1.0669	.9088	2.1262	
10	.7011	.6516	.4268	.4268			
11		.3963	.3734	.3029	.6401	.4054	
12	.5316	.3096	.3201	.3201		.3887	
13	.5316	.362		.3201	.5258	.4923	1.2803
14	.5258	.2667		.2524	.5201		1.6804
15		.3715		.2667			.2322
16	.5258	.3286		.3029			.1052
17	.5258	.3096	.4496	.4915	.5487		
18	.7442	.4451	.5335	.4268	.6401		.6192
19		.7145	.5335	.4268			.6478
20	1.2003	.7125	.7373	.4801	1.086		.4268
21		.724	.4801	.3734	.9145		.3734
22	.823	.3414	.3734	.3734			.3096
23	.7392	.4344	.3201	.3201	.724		.3239
24	1.1888	1.4327	.8478	.4268	.3029	.6535	
Max	1.7147	1.9281	1.95	1.1736	1.2803	2.1262	1.6804
Min	.5258	.2667	.3201	.2524	.3029	.3887	.1052
Avg	.9047	.8176	.8788	.5408	.7292	.8132	.5999

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054003 / 33/11 KV. CHOUSALA

Feeder No / Name : 203 / 11 KV. S. BORGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2008		.1852	.2949	.1515		
2	.2008		.2126	.192	.1515		
3	.204	.3292	.2134	.192	.16		
4	.2092	.362	.2972	.3163	.202		
5	.3544	.4733	.3096	.2134	.3201		
6	.4801	.7343	.583	.4039	.4443		
7	.4481	.4268	.5316				
8		.4054	.4706	.3029	.3201		
9	.5316	.3715	.3201	.3201	.2477	.6268	
10	.3366	.2724	.2347	.2134	.3277	.202	
11		.1296	.2134	.1238	.3366	.192	
12			.16	.1638		.2073	
13	1.647	1.6956		1.0669	.2835	1.7804	
14	1.8347	1.7147		1.0602	1.9839		
15		1.5261		1.6385			1.5813
16	1.7465	1.8861					1.1736
17	1.6817	1.6956	1.1203		1.7337		1.5718
18	1.7328	1.9161	1.0669	.0808	1.9938		1.3622
19		.3048	.3201	.3201			1.4251
20	.6135	.3372	.3029		.6036		.3715
21		.3368	.2667	.2524	.4938		.3715
22	.3582	.2667	.2423	.3001			.2724
23	.3258	.1867	.2827	.2134	.3658		.2477
24	.1976	.2896	.2477	.3005	.1515	.3292	
Max	1.8347	1.9161	1.1203	1.6385	1.9938	1.7804	1.5813
Min	.1976	.1296	.16	.0808	.1515	.192	.2477
Avg	.7280	.7457	.3791	.3985	.5706	.5563	.9308

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054003 / 33/11 KV. CHOUSALA

Feeder No / Name : 204 / 11 KV. HINGNI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5144	.0854	.101		
2	.6043		.7059	.0854	.4039		
3	.6481	.985	1.0174	.1067	.6059		
4	.767	1.0631	1.1869	.8078	.6866		
5	.8886	1.3289	1.2717	.8078	.9088		
6	.2221	1.5424	1.6108	.8962	1.439		
7	.3441	.4096	.2724	.2372	.2949		
8		.3768	.2724	.2458	.1494		
9	.2865		.202	.2458	.16	.3658	
10	.2454		.1734	.128	.0854	.1067	
11		.144	.1494	.1638	.1791	.1238	
12	.1595	.1067		.1802		.1238	
13	.1753			.1067	.1928	.1238	
14	.1753	.1067		.1311	.0867		
15		.1276		.101			.7573
16	.1734	.1296		.0854			.7573
17	.2454	.1296	.096	.0854	.181		.7468
18	.2401	.1555	.1067	.1802	.1417		1.6842
19		.2134	.192				1.2269
20	.3366	.2235	.2058	.1494	.1848		
21		.16	.192	.128	.2715		
22	.1991	.1966	.192	.101			
23	.1791	.0876		.1067	.1848		.2
24	.0814	.2686	.1296	.1475	.0953	.1848	
Max	.8886	1.5424	1.6108	.8962	1.439	.3658	1.6842
Min	.0814	.0876	.096	.0854	.0854	.1067	.2
Avg	.3317	.4082	.4717	.2310	.3343	.1715	.8954

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054003 / 33/11 KV. CHOUSALA

Feeder No / Name : 205 / 11 KV ANJANWATI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286		.2503	.2423	.2667		
2	.1715		.2538	.2423	.2524		
3	.1715	.4572	.2195	.2322	.3029		
4	.2092	.443	.2439	.3201	.3201		
5	.2134	.6401	.282	.3201	.3029		
6	.4096	.6379	.2858	.3534	.3534		
7	.2667	.3734	.3765	.2667			
8		.4915	.3384	.4096	.3201		
9	.3506	.3628	.2667	.3029	.3201	.3734	
10	1.3717	1.3565	.9088	1.3108	1.3108	.9069	
11		1.6956	1.7695	1.0669	1.9071	1.6385	
12		1.8652	1.6385	1.0669		1.6108	
13	1.7909	1.7147		.8535	1.7147	1.6108	
14	1.6804	1.5089		.8535	1.5089		1.0669
15		1.5261		.8535			1.0098
16	1.6766	1.6956					1.2955
17	1.5432	1.6956	.8078		1.7528		.3163
18		.2027	.2667	.2134	.3696		
19		.3475	.3201	.2667			.3887
20	.7011	.3887	.3201	.2561	.4572		.3715
21		.4287	.2534	.3734	.5544		.3096
22	.5373	.192	.3201	.3734			.3096
23	.3696	.2538	.3201	.3601	.4668		.2401
24	.2362	.3734	.2896	.2667	.2667	.3696	
Max	1.7909	1.8652	1.7695	1.3108	1.9071	1.6385	1.2955
Min	.1715	.192	.2195	.2134	.2524	.3696	.2401
Avg	.7017	.8478	.4866	.4911	.7082	1.085	.5898

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054009 / 33 KV. S/S NATHPUR

Feeder No / Name : 201 / 11KV RANJEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
6		1.3123	
9	.3353		
11	2.6825		
13		3.3608	
14			2.5621
15			3.0483
17	3.1398		3.0994
24	.2134		
Max	3.1398	3.3608	3.0994
Min	.2134	1.3123	2.5621
Avg	1.5928	2.3366	2.9033

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054009 / 33 KV. S/S NATHPUR

Feeder No / Name : 202 / 11 KV. NATHAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
6		.2267	
9	.1524		
11	.0122		
13		.1509	
14			.1981
15			.1372
17	.1524		
24	.1524		
Max	.1524	.2267	.1981
Min	.0122	.1509	.1372
Avg	.1174	.1888	.1677

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054009 / 33 KV. S/S NATHPUR

Feeder No / Name : 203 / 11 KV. SANDARWAN FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
6		1.1523	
9	.2439		
11	.3963		
13		2.2382	
15			.4586
17	.3704		.5376
24	.7316		
Max	.7316	2.2382	.5376
Min	.2439	1.1523	.4586
Avg	.4356	1.6953	.4981

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054009 / 33 KV. S/S NATHPUR

Feeder No / Name : 204 / 11 KV. RAMPURI FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
9	.9145		
13		.3353	
14			.1174
15			.6009
17	.2286		.2214
21			.3688
24	.5487		
Max	.9145	.3353	.6009
Min	.2286	.3353	.1174
Avg	.5639	.3353	.3271

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054009 / 33 KV. S/S NATHPUR

Feeder No / Name : 205 / 11 KV. GUNDA FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
6		.5693	
9	.3048		
11	.7621		
13		.6371	
14			.506
15			.503
17	.7164		.5535
21			.4096
24	.6097		
Max	.7621	.6371	.5535
Min	.3048	.5693	.4096
Avg	.5983	.6032	.4930

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054016 / 33/11 KV, YALLAMB GHAT

Feeder No / Name : 203 / 11 kv. TANDELWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2						.2675	
3							.0381
4						.3841	
6						.8413	
7						.9069	
8						.7796	
9						.6996	
10							.6737
12							.7468
15							.6893
16	.6554				.5449		.679
17		.7846	.852		.8116		.6935
18	1.1469		.8192	.9556	.0381	.0381	.0381
19	1.1336	.7324	1.1012	.8402	.0572		.0572
20					.0762	.0381	
21							.0381
22				.6516			
23		.6859			.0381		
24		.0693	.0572	.0509	.0381		
Max	1.1469	.7846	1.1012	.9556	.8116	.9069	.7468
Min	.6554	.0693	.0572	.0509	.0381	.0381	.0381
Avg	.9786	.5681	.7074	.6246	.2292	.4944	.4060

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054016 / 33/11 KV, YALLAMB GHAT

Feeder No / Name : 204 / 11 KV W. BHABHULGAON SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.1787					.2462	
3							.0381
4						.2332	
5	.3086						
6	.3829		.5068			.4344	
7		.4588	.4801	.5898	.4652	.5144	
8						.3894	
9						.3382	
10							.2572
12							.2841
15							.3525
16							.3517
17							.3368
18	.0701		.0701	.0829	.0509	.0381	.0324
19	.0514	.0886	.1052	.0724	.052		.0532
20					.0537	.0511	
21							.064
22				.032			
23		.0492			.0301		
24	.216	.2949	.2332	.2915	.0293		
Max	.3829	.4588	.5068	.5898	.4652	.5144	.3525
Min	.0514	.0492	.0701	.032	.0293	.0381	.0324
Avg	.2013	.2229	.2791	.2137	.1135	.2806	.1967

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054016 / 33/11 KV, YALLAMB GHAT

Feeder No / Name : 205 / 11 KV. CHAKARWADI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2							.8124
4							.9374
5							.945
6							1.0669
7							1.0669
8			1.0822	1.1336	.9755		1.1584
9	1.1561	1.1873	1.1469	1.3117	1.2346		1.0364
10		1.0822		1.2041	1.1279	1.1111	
11	1.0155	1.1279	1.2186	1.2193	1.1888	1.2346	
12				1.2346	1.1888	1.25	
13		1.0822			1.2193		
14					1.1279		
15	1.0997	1.0562		1.1584	1.0669	1.3735	
17						1.5432	
Max	1.1561	1.1873	1.2186	1.3117	1.2346	1.5432	1.1584
Min	1.0155	1.0562	1.0822	1.1336	.9755	1.1111	.8124
Avg	1.0904	1.1072	1.1492	1.2103	1.1412	1.3025	1.0033

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054016 / 33/11 KV, YALLAMB GHAT

Feeder No / Name : 208 / 11 KV. KAREGAVAN FEEDER - GAOTHAN FEEDER
G- Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.381						.1905
4							.2286
5	.724						.6287
9	.5898	.5735	.6952	.639	.7811	.5716	.4001
10		.5906		.5525	.5716		.5335
11	.4915	.5144	.4915	.4763	.5525		
12							.3429
15	.3605	.4763		.5525	.2191	.1619	.181
16	.3391			.5906	.3189		.1257
17		.4954	.5243		.4191	.4191	
18	.4917		.6802	.5525	.4763	.3525	.5525
19	.6718	.8573	.639	.6478	.8002		.8192
20					.4287	.8383	
21							.743
22				.5144			
23		.4572			.4763		
24	.4191	.373	.4572	.3768	.4191		.4191
Max	.724	.8573	.6952	.6478	.8002	.8383	.8192
Min	.3391	.373	.4572	.3768	.2191	.1619	.1257
Avg	.4965	.5422	.5812	.5447	.4966	.4687	.4304

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054016 / 33/11 KV, YALLAMB GHAT

Feeder No / Name : 209 / 11 KV. YELLAMB GHAT -G- GAOTHAN FEEDER
FEEDER Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.3391					.4359	.407
4						.5493	.5316
5	.4641						.823
6	.4858						
9	.7522	.905	.9412	1.0136	.9313	.8869	.823
10		.7087		.7011	.7455	.7122	.6733
11	.5144	.583	.5487	.5765	.5935	.6516	
12							.4115
15	.4409	.503		.5197	.5087	.4374	.3704
16	.3932			.5247	.5243	.5468	.4115
17		.4681	.7122		.5138		.4641
18	.5609		.8764	.6226	.6562	.6405	.5851
19	.7011	.6783	.8764	7.9024	.7108	.7186	.7545
20					.929	.7602	
21						.6443	.5801
22				.4409			
23		.4096			.4428	.4115	
24	.3086	.4334	.3978	.4382	.4218		.3772
Max	.7522	.905	.9412	7.9024	.9313	.8869	.823
Min	.3086	.4096	.3978	.4382	.4218	.4115	.3704
Avg	.4960	.5861	.7255	1.4155	.6343	.6163	.5548

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054016 / 33/11 KV, YALLAMB GHAT

Feeder No / Name : 210 / 11KV NEKNOOR -G-FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.9945					.8495	.8939
4						.7975	.9593
5	1.1641						1.1765
9	1.2308	1.6289	1.647	1.5023	1.387	1.3523	1.5565
10		1.2309		1.2309	1.4327		1.2136
11	1.086	1.182	1.3073	1.1443	1.3003		
12							1.1616
15	.8326	1.182		1.1269	1.1963	.6878	.9536
16	1.086			1.283	1.1443		.9362
17		1.0924	1.5927		1.1443	1.1222	.9536
18	1.086		1.3937	1.1963	1.1443	1.3937	1.1096
19	1.2308	1.3969	1.5023	1.283	1.2656		1.1789
20					1.283	1.448	
21						1.3394	1.3176
22				1.1443			
23		1.1283			1.0749	1.1222	
24	.9774	.8507	.9709	.9231	.9536		.9259
Max	1.2308	1.6289	1.647	1.5023	1.4327	1.448	1.5565
Min	.8326	.8507	.9709	.9231	.9536	.6878	.8939
Avg	1.0765	1.2115	1.4023	1.2038	1.2115	1.1236	1.1028

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054034 / 33/11 KV. S/S PENDGAON

Feeder No / Name : 201 / 11 KV. SIDDOD FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	06-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.6382	1.1869	
8				1.7147
24	.8573	.7459	.9389	
Max	.8573	.7459	1.1869	1.7147
Min	.8573	.6382	.9389	1.7147
Avg	.8573	.6921	1.0629	1.7147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054034 / 33/11 KV. S/S PENDGAON

Feeder No / Name : 203 / 11 KV. PENDGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	06-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		1.0898	1.2003	
8				2.0576
16	.5868			
24	.8573	.8288	1.0059	
Max	.8573	1.0898	1.2003	2.0576
Min	.5868	.8288	1.0059	2.0576
Avg	.7221	.9593	1.1031	2.0576

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054034 / 33/11 KV. S/S PENDGAON

Feeder No / Name : 204 / 11 KV. MIDC PENDGAON
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	06-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.7459	1.0288	
8				.5144
16	.4973			
24	.7716	.663	.9945	
Max	.7716	.7459	1.0288	.5144
Min	.4973	.663	.9945	.5144
Avg	.6345	.7045	1.0117	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054034 / 33/11 KV. S/S PENDGAON

Feeder No / Name : 205 / 11 KV KUMSHI NEW FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
16	.8173		
24	.2486	.1067	.2058
Max	.8173	.1067	.2058
Min	.2486	.1067	.2058
Avg	.5330	.1067	.2058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054034 / 33/11 KV. S/S PENDGAON

Feeder No / Name : 206 / 11 KV KUKKADGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
16	.3315		
24	.1677	.1067	.1357
Max	.3315	.1067	.1357
Min	.1677	.1067	.1357
Avg	.2496	.1067	.1357

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054036 / 33/11 KV. PIMPALNER S/S

Feeder No / Name : 201 / 11 KV. TADSONA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4403	1.5947	1.4232	1.6461	1.5424	1.5432	1.7193
2	1.4746	1.6651	1.6301	1.6461	1.5775	1.5432	1.7193
3	1.4746	1.7528	1.7364	1.6461	1.6651	1.5432	1.7909
4	1.5089	1.9281	2.0416	1.6804	1.7528	1.6118	1.9342
5	1.6118	2.0157		1.7147	1.9281	1.6804	2.1262
6	1.8861	2.2325	2.1491	1.7833	2.1033	2.0233	2.1971
10	1.8233	1.8138		1.9559	1.8991	1.9204	2.0805
11	2.6235	2.2405		2.6871	2.4078	2.2672	2.2672
12	2.6235	2.0805		2.6216	2.3739		2.0729
13	2.4006	1.8747		2.4939	2.1216	1.8976	1.9204
14	1.9608	1.7497		2.2024	2.0317	1.8976	1.7604
15	1.9292	1.866		2.1052	1.9662	1.8976	1.8343
16	2.0241	1.8747		2.2672	1.9334	1.866	1.8976
17	2.2455	1.8976		2.2672	2.0317	1.9433	2.0873
18	1.2197	1.2437		1.4784	1.406	1.086	
19	1.848	1.8099		1.6461	1.6118	1.6651	1.6632
20	2.0119	2.1719	2.1262	1.8099	1.8861	2.1719	2.0328
21	1.8461	1.97	2.0576	1.9136	1.8861	1.9909	1.829
22	1.7718	1.8099	1.989	1.7528	1.893	1.97	1.7737
23	1.5947	1.7013	1.9342	1.5775	1.8229	1.8781	1.8099
24	1.4746	1.5424	1.6289	1.6461	1.5074	1.7147	1.7718
Max	2.6235	2.2405	2.1491	2.6871	2.4078	2.2672	2.2672
Min	1.2197	1.2437	1.4232	1.4784	1.406	1.086	1.6632
Avg	1.8473	1.8493	1.8716	1.9306	1.8737	1.8056	1.9144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054036 / 33/11 KV. PIMPALNER S/S

Feeder No / Name : 202 / 11 KV. GHATSAWALI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7888	.9012	.9221	.9259	.3772	.3429	.3982
2	.823	.9831	1.0059	.9945	.5668	.6516	.6783
3	.9259	1.0526	1.0174	1.0974	.8097	.8573	.8573
4	1.1317	1.1336	1.0852	1.1317	.9717	.9945	1.0631
5	1.3717	1.2146	1.1736	1.3375	1.3765	1.4746	1.2346
6	1.5432	1.3765	1.2574	1.7661	1.4737	1.8519	1.7147
7	1.6461		1.9719	1.9719	1.8138		1.6956
8	1.6804	1.3117	2.0233	1.8861	1.7328		1.6804
9		1.3603		1.7147	1.7328	1.749	
10	.3429	.2896		.3258	.3086	.2896	.3086
11	.2915	.2534		.2915	.2743	.2686	.2572
12	.3258			.3258		.2353	.2229
13	.2572			.2743	.2058	.2353	.2572
14	.2229	.2195			.2572	.2507	.2572
15	.2229	.2561		.2915	.2572	.0905	.2401
16	.2572	.2743		.2915	.2572	.2715	.2915
17	.2572	.2743		.3734	.3086	.2715	.2743
18	.2915	.2743		.4287	.3772	.2896	
19	.3429	.439		.4801	.463	.5121	.4115
20	.5144	.695	.6173	.4458	.5487	.6401	.463
21	.463	.5304	.583	.4287	.4458	.4572	.4287
22	.4287	.439	.4458		.3601	.439	.4115
23	.3772	.4207	.4119	.3772	.3429	.4207	.3772
24	.5487	.3441	.8383	.8573	.3772	.3429	.4163
Max	1.6804	1.3765	2.0233	1.9719	1.8138	1.8519	1.7147
Min	.2229	.2195	.4119	.2743	.2058	.0905	.2229
Avg	.6546	.6687	1.0272	.8190	.6799	.5880	.6336

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054036 / 33/11 KV. PIMPALNER S/S

Feeder No / Name : 203 / 11KV GUNDHA NEW FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.4108	.3772	.3086	.1867	.1715	.1791
2	.4801	.4481	.4115	.3429	.4108	.3086	.3506
3	.4801	.4854	.4115	.3772	.4481	.3772	.3506
4	.5144	.5601	.4287	.4115	.4668	.4458	.3814
5	.5487	.5975	.4748	.4801	.5228	.4801	.4115
6	.6173	.6348	.5426	.6859	.5415	.5487	.5487
7	.6516	.7468	.6001	.7202	.6348	.6859	.6173
8	.6516	.6908	.6001	.7202	.7842	.7202	.6135
9		.7842		.6516	.7842	.6859	
10	.0934	.1646		.1494	.12	.1294	.1307
11	.0934	.1097		.1494	.12	.0924	.1307
12	.0934	.0914			.12	.0924	.112
13	.0934	.0924		.112	.12	.0905	.112
14	.1307	.0924		.1307	.12	.0914	.112
15	.112	.0924		.1307	.12	.0924	.1307
16	.0934	.0924		.1307	.12	.0924	.0934
17	.0934	.1086		.1307	.1372	.0924	.112
18	.1307	.1086		.1494	.1715	.0924	.112
19	.2241			.2241	.2058	.1848	.2054
20	.2241	.2957	.1715	.2427	.2743	.2926	.1867
21	.2427	.2218	.2058	.2801	.2401	.2378	.1867
22	.2241	.1829	.1715	.2241	.2058	.1848	.2054
23	.2054	.1663	.1715	.1867	.2058	.1848	.2054
24	.3086	.3921	.3391	.3086	.2054	.2058	.181
Max	.6516	.7842	.6001	.7202	.7842	.7202	.6173
Min	.0934	.0914	.1715	.112	.12	.0905	.0934
Avg	.2921	.3291	.3774	.3151	.3027	.2742	.2465

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054053 / 33/11 KV. S/S SHIVNI

Feeder No / Name : 201 / 11 KV. BORPHADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1068	.1566	.1486	.1187	.1589	.1486	.1543
2	.1068	.1591	.1486	.1187	.1703	.1486	.1662
3	.1187	.1851	.1734	.1424	.2016	.1734	.2374
4	.1424	.196	.1858	.1662	.228	.1981	.2858
5	.1662	.2119	.1981	.1899	.2582	.2477	.2858
6	.2136	.2248	.2229	.2255	.2701	.2972	.3345
7							.3584
8							.3464
9							.3708
10	.2913	.2477		.1324	.2229	.2724	.1064
11	.384	.3467		.4508		.3323	.0797
12	.4263	.3715		.4176	.3715	.3917	
13	.3915	.322		.3654	.3715	.3561	.1059
14	.3601	.2972		.3178	.3467		.0794
15	.3654	.322	.2849	.3178	.3344		.0783
16	.3858	.3467	.451	.3132	.322		.0914
17	.4237	.3467	.3798	.3458	.3467	.2849	.0994
18	.1589	.1486	.1187	.1324	.1486	.095	.1589
19	.1986	.2105	.1662	.1986	.2229	.1191	.2119
20	.2219	.2105	.1899	.238	.2724	.1667	.2261
21	.1986	.1981	.1899	.2088	.2477	.1905	.2129
22	.1987	.1734	.178	.1987	.1981	.1667	.2008
23	.1845	.1486	.1543	.1854	.1734	.1548	.1995
24	.1504	.1566	.1486	.1424	.1495	.1734	.178
Max	.4263	.3715	.451	.4508	.3715	.3917	.3708
Min	.1068	.1486	.1187	.1187	.1486	.095	.0783
Avg	.2473	.2372	.2087	.2346	.2508	.2176	.1986

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054053 / 33/11 KV. S/S SHIVNI

Feeder No / Name : 202 / 11 MOCHI PIMPALGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5892	.7499	.6316	.5878	.6921	.583	.5892
2	.5892	.7826	.6802	.5551	.6899	.6154	.6546
3	.6546	.8273	.7287	.5551	.7225	.6802	.7856
4	.7856	.9008	.7773	.5878	.8182	.7773	.7856
5	.9165	.9659	.8745	.7184	.8743	.8421	.9143
6	1.0474	1.0928	.9393	.9282	.8825	.9069	.9819
7							1.1129
8							1.1429
9							1.1839
10	.956	.9393		.5217	.9069	.8421	.3378
11	1.2385	1.1012		1.2346	1.1012	.8817	.4371
12	1.02	.9069		1.1657	1.0364	.9143	.3601
13	1.0112	.9069		1.0837	.9069	.9143	.4189
14	.9753	.8745		1.0018	.9069	.8817	.4229
15	1.052	.9069	.7837	1.02	.8421		.4176
16	1.0564	.9717	1.045	1.0476	.8421		.4681
17	1.1399	1.0526	.9797	1.0928	.9393	.851	.4335
18	.3753	.421	.3919	.4007	.2915	.3273	.4721
19	.8825	.6802	.5231	.6193	.583	.5219	.7202
20	.9835	.8907	.7184	.8014	.8097	.5871	.8014
21	.9107	7.8866	.7837	.8014	.7287	.7176	.7562
22	.8632	.7287	.7184	.7802	.6478	.685	.7506
23	.7225	.6802	.6531	.7131	.6154	.6204	.6936
24	.5237	.7285	.6316	.5878	.6557	.583	.6531
Max	1.2385	7.8866	1.045	1.2346	1.1012	.9143	1.1839
Min	.3753	.421	.3919	.4007	.2915	.3273	.3378
Avg	.8711	1.1902	.7413	.8002	.7854	.7228	.6789

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054053 / 33/11 KV. S/S SHIVNI

Feeder No / Name : 203 / 11 KV Indestrial feeder SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0183	.0183	.0181	.0365	.0364	.0181	.0182
2	.0183	.0188	.0181	.0365	.0373	.0181	.0183
3	.0182	.0186	.0181	.0365	.036	.0181	.0183
4	.0182	.0188	.0181	.0365	.0375	.0181	.0183
5	.0182	.0182	.0181	.0365	.0559	.0181	.0183
6	.0182	.0186	.0181	.0365	.0545	.0362	.0183
7	.0548	.0184	.0181	.1095	.0558	.0362	.0183
8	.1095	.0938	.0181	.1643	.0911	.1267	.0913
9	.1095	.0929		.126	.1086	.1267	.0908
10	.0908	.1267		.1089	.1086		.0929
11	.0908	.1086		.1626	.1267	.1278	.0903
12	.0929	.1086		.1586	.1267	.1278	.1089
13	.0919	.0905		.1471	.1086	.1095	.1084
14	.0938	.0905		.1314	.1086	.0913	.0903
15	.0729	.1086	.0365	.1089	.1086		.0557
16	.0722	.1086	.0365	.0913	.1267		.0923
17	.0751	.0905	.0365	.1089	.1086	.1093	.09
18	.0751	.0905	.0238	.1264	.0905	.0914	.09
19	.0367	.0362	.0365	.126	.0905	.0912	.0911
20	.0181	.0181	.0365	.09	.0724	.0729	.0182
21	.0182	.0181	.0365	.0751	.0543	.0546	.0186
22	.0188	.0181	.0182	.0743	.0362	.0551	.0181
23	.0184	.0181	.0183	.0743	.0362	.0018	.0186
24	.0183	.0186	.0181	.0365	.036	.0362	.0182
Max	.1095	.1267	.0365	.1643	.1267	.1278	.1089
Min	.0181	.0181	.0181	.0365	.036	.0018	.0181
Avg	.0528	.0569	.0246	.0933	.0772	.0660	.0547

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054059 / 33/11 KV. S/S/ MHALASJAWALA

Feeder No / Name : 203 / 11KV MHALASJAWALA -G- GAOTHAN FEEDER
 FEEDER Feeder KV- 11 /
 OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1187		.1905	.1923	.1715	.1562	.1457
2	.1341		.2096	.195	.1524	.1581	.1457
3	.1526		.2667	.2219	.1715	.1562	.1638
4	.1658		.3239	.2206	.2096	.1829	.192
5	.2105	.1875	.362	.2338	.2477	.2315	.2187
6	.3005					.2824	
7	.2134	.2503			.2858	.3144	.1562
8		.2286	.3429	.3239	.2858	.2709	.1677
9		.1738		.3012	.3048	.2286	.2374
10		.2096		.1647	.1715	.1562	.1806
11	.1296	.2096		.2477		.1718	.1355
13	.1326	.2477					.1372
14							.1562
15		.2096		.1715	.1311	.1581	.1406
16	.1619	.1905		.1715	.1619	.1739	.1406
17		.2096		.1715	.16	.1698	.1943
18	.2204	.2096		.1715	.16	.1581	
19	.3201	.2858		.362	.3125	.1875	.2881
20	.2881			.4001	.2743		
21		.4191		.2286	.2408		
22	.192	.2667	.3182	.2477	.2031		
23	.2267	.2096	.2922	.1905			.1524
24		.1094	.1715	.1765	.2096	.1581	.1581
Max	.3201	.4191	.362	.4001	.3125	.3144	.2881
Min	.1187	.1094	.1715	.1647	.1311	.1562	.1355
Avg	.1978	.2261	.2753	.2312	.2141	.1950	.1728

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054059 / 33/11 KV. S/S/ MHALASJAWALA

Feeder No / Name : 204 / 11KV KALEGAON -G- FEEDER GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	04-MAY-17
HR	Load (MW)
9	.3052
Max	.3052
Min	.3052
Avg	.3052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054081 / 33/11 KV. RAJURI (N) S/S

Feeder No / Name : 204 / 11KV Rajuri-Gaonthan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.6161		
15	.2772			
16				.3174
17			.4294	
18	.3961			
24		.2427		.2829
Max	.3961	.6161	.4294	.3174
Min	.2772	.2427	.4294	.2829
Avg	.3367	.4294	.4294	.3002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054081 / 33/11 KV. RAJURI (N) S/S

Feeder No / Name : 205 / 11kv Charhata-gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	05-MAY-17
HR	Load (MW)
16	.3174
Max	.3174
Min	.3174
Avg	.3174

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054103 / 33/11 KV NALWANDI SUB-

STATION

Feeder No / Name : 201 / 11 KV Nalwandi (New)

SINGLE PHASING

Feeder Feeder KV- 11 /
OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4534	.4513	.4534	.5121	.3887
2	.583		.3887	.4513	.4534	.5182	.3887
3	.6478			.4835	.4858	.5182	.3887
4	.7125		.3887		.5182	.583	.4534
5	.8097		.4534		.583	.6478	.5182
6	.9069		.5182	.5158	.7125	.7125	.583
7	.9069			.7092	.7125	.8421	.6478
8	.7125			.6455	.5182	.6478	.6478
9	.6478			.4518	.5182	.5182	.5182
10	1.0349				.6478	1.0364	.6516
11	1.3717			1.2955	.9069	1.166	1.1728
12	1.4586	1.2651		1.3603	.8421	1.2955	1.238
13	1.326	1.1385		1.0364	.8421	1.2955	1.238
14	1.2803	1.2651		.9069	.9069	1.2955	1.1728
15	1.1523	1.2955		1.0364	.9602	1.2308	.9069
16	1.2498		1.3491		1.0242	1.2955	1.0425
17	1.3123	1.2955	1.6363		1.0883	1.4251	1.1077
18	.4374	.3887	1.4723	.4534	.3887	.6478	.4561
19	.6249	.583	.6386	.6478	.3887		.5864
20	.759	.583		.5182	.4534	.583	
21	.6325	.5182	.5121	.5182	.5121	.4534	
22	.5693	.5182	.5761	.6478	.5761	.4534	
23		.4534	.5121	.583	.5761	.4534	.3258
24	.5182		.4534	.4534	.5182	.5121	.3887
Max	1.4586	1.2955	1.6363	1.3603	1.0883	1.4251	1.238
Min	.4374	.3887	.3887	.4513	.3887	.4534	.3258
Avg	.8934	.8458	.7194	.6929	.6495	.8106	.7058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054103 / 33/11 KV NALWANDI SUB-

STATION

Feeder No / Name : 202 / 11 KV Jarud

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6722	.6722	.7468	.7514	.5975	.5975	
2	.7468	.7468	.7468	.8266	.7468	.5975	.8215
3	.8215	.8215	.7468	.9017	.8215	.6722	.8215
4	.9335	.8962	.8215	.9017	.8962	.8215	.8962
5	1.0082	1.0456	.8962	1.052	.9709	1.1203	.8962
6	1.0456	1.1949	1.1203	1.1271	1.0456	1.2696	1.1949
7	1.1203	1.3443		1.2774	1.3443	1.3443	1.3443
8	1.1203	1.2696		1.1283	1.1949	1.1949	1.3443
9	1.1203	1.1203		.9768	1.0456	.9709	.7468
10	.4572			.4481	.5175	.5228	.5249
11	.4572			.5228	.4481	.5228	.4499
12	.4527	.3734		.3734	.4481	.4481	.4499
13	.3772	.3734		.4481	.4481	.4481	.4499
14	.4527	.4481		.4481	.4481	.4481	.4504
15	.4527	.3734		.4481		.4481	.4481
16	.4527		.4449	.5228	.3734	.5228	.4504
17	.5281	.3734	.5975		.5228	.5228	.5255
18	.6036	.4481	.8215	.6722	.5975	.7468	.5255
19	.9054	.7468	.8989	.8215	.8215	.8215	.7506
20	1.1203	.8215		.8962	.8962	.8962	.9758
21	.8962	.7468	.8615	.8215	.8215	.8215	
22	.8215	.6722	.8215	.7468	.7468	.6722	
23		.5975	.7468	.6722	.7468		.6756
24	.5975	.5975	.6722	.6348	.5228	.6722	.6722
Max	1.1203	1.3443	1.1203	1.2774	1.3443	1.3443	1.3443
Min	.3772	.3734	.4449	.3734	.3734	.4481	.4481
Avg	.7462	.7468	.7817	.7574	.7401	.7436	.7340

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054123 / 33/11KV PIMPALWADI S/Sn

Feeder No / Name : 201 / 11 KV DOKEWADA TALAV SINGLE PHASING

FEEDER Feeder KV- 11 /
OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2883	.2743	.3052	.3018	.3121	.3052	.3018
2	.285	.2572	.3052	.285	.3294	.2883	.285
3	.285	.2572	.3052	.285	.3294	.3052	.285
4		.3086	.3222	.285	.3641	.3391	.285
5	.3222	.3429	.3561	.3018	.3467	.3561	.3018
6	.3391	.3086	.407	.3018	.2774	.3561	.3353
7	.3052	.2915	.3052	.285	.3121		.285
8	.3018	.2572	.2543	.2515	.2601	.285	.2683
9	.2347	.2058	.2204	.2347	.2427	.2374	.2515
10	2.0919	2.2939		2.2712	2.1152	2.0119	2.0645
11	2.6235	2.8837			2.7831	2.8669	2.556
12		2.3102		2.5139	2.7664	2.6658	2.6379
13	2.7092	2.2611		2.5312	2.6825	2.2801	2.6379
14	2.8121	2.1956		2.826		2.4143	2.4413
15	2.7435	2.1628		2.6873	2.3304	2.4813	2.4577
16	2.5377	2.2283		2.9127	2.431	2.4478	2.4086
17	3.0007	2.5232	2.934	2.9127	2.5149	2.5484	2.4249
18	.1886	.2035	.218	.208	.2204	.2347	
19	.2229	.2543	.3018	.2427	.2543		
20	.3772	.3391	.3353	.3294	.3391	.3521	
21	.3258	.3391	.3185	.3294	.3561	.3353	
22	.3429	.3222	.3018	.3121		.3353	.2713
23	.3258	.3052	.3018	.3121		.3353	.2543
24	.2743		.3052	.3121		.3222	.3185
Max	3.0007	2.8837	2.934	2.9127	2.7831	2.8669	2.6379
Min	.1886	.2035	.218	.208	.2204	.2347	.2515
Avg	1.0426	1.0055	.4587	1.0101	1.0784	1.0956	1.1536

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054123 / 33/11KV PIMPALWADI S/Sn

Feeder No / Name : 202 / 11 KV BHALWANI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.643	1.6598	1.6575	1.9616	1.9784	.3391	.3353
2	1.6766	1.7269	1.7901	2.0957	2.1125	1.7295	1.7604
3	1.7772	1.8442	1.9393	2.1125	2.1125	1.8442	1.9281
4	1.861	2.0454	2.0481	2.2969	2.2634	2.431	1.9616
5	2.0119	2.431	2.2611	2.649	2.431	2.6825	2.2969
6	2.3472	2.8334	2.5724	2.8669	2.6155	2.8502	2.8502
7	2.7664	3.0849	3.0476	2.9843	3.2023		3.2358
8	2.5316	3.0346	2.769	3.0681	3.1184	3.2693	2.8334
9	2.364	2.5484	2.5149	2.4813	2.8166		2.9005
10	.3018	.2401		.2683	.285	.3018	.3258
11	.2683			.2515	.2347	.2683	.2572
12		.2572		.2347	.2515	.2515	.2572
13	.218	.2401		.2347	.2374	.2347	.2572
14	.218	.2401		.2347	.2374	.2347	.2572
15	.2012	.2229		.218	.2204	.2347	.2572
16	.2012	.2401		.218	.2374	.2515	.2572
17	.1844	.2401	.2683	.2347	.2347	.285	.3258
18	.2012	.2743	.3353	.3018	.2515	.3353	.3601
19	.285	.4115	.4024	.3688	.373	.3856	
20	.503	.4917	.4862	.4694	.5256	.503	
21	.503	.4801	.4527	.4694	.4239	.4694	
22	.4694	.3944	.4694	.4359		.4024	.4801
23	.4191	.3601	.3688	.3688		.3856	.4287
24	1.6263	.2572	1.6263	1.7772		.3561	.3353
Max	2.7664	3.0849	3.0476	3.0681	3.2023	3.2693	3.2358
Min	.1844	.2229	.2683	.218	.2204	.2347	.2572
Avg	1.0686	1.1112	1.4711	1.1918	1.2459	.9112	1.1382

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054123 / 33/11KV PIMPALWADI S/Sn

Feeder No / Name : 203 / 11 KV PIMPALWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0429	.0429	.0526	.052	.0429	.0429	.0526
2	.0429	.0429	.0526	.0351	.0429	.0429	.0537
3	.0429	.0429	.0526	.0351	.0429	.0572	.0532
4	.0429	.0572	.0701	.0354	.0572	.0714	.0701
5	.0572	.0714	.0867	.0716	.0714	.0714	.0693
6	.0857	.0857				.0857	.1174
7	.1	.1					.1029
8	.0857	.0857	.1227	.0709		.1	.0857
9	.0714	.0857	.0876	.0537	.0714	.0857	.0838
10	.0572	.0701			.0714	.0514	.0876
11	.0429	.0526			.0572	.052	.0526
12							.0351
13	.0286						.0351
14	.0286						.0351
15	.0286	.0526			.0572	.0503	.0351
16	.0429	.0526			.0572	.0693	.0526
17	.0572	.0701	.0867	.0714	.0572	.0867	.0526
18	.0714	.0876	.0867	.0857	.0714	.0701	.0701
19	.0857	.1227	.0857	.0857	.0714	.104	
20	.0857		.0686	.1	.1	.0876	
21	.0572	.0701	.0867	.0714	.0572	.0686	
22	.0429		.052	.3121		.0709	.0701
23	.0429	.0526	.052	.0572		.0532	.0526
24	.0429		.0526	.0429		.0429	.0532
Max	.1	.1227	.1227	.3121	.1	.104	.1174
Min	.0286	.0429	.052	.0351	.0429	.0429	.0351
Avg	.0559	.0692	.0731	.0787	.0619	.0682	.0629

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 057002 / 132/11 KV S/S, BEED

Feeder No / Name : 205 / 11 KV. NALWANDI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
13	.7621	.7621		.7621	.7621	.7621	.6097
14	.7621			.7621	.7621	.7621	.6097
15	.6097			.6097	.4572	.6097	.6097
16	.6097			.6097	.4572	.6097	.6097
17	.7621			.6097	.6097	.6097	.6097
18	.7621	1.0669		.7621	.6097	.7621	.7621
19		1.0669	1.0669	.6097	.6097	.7621	.6097
20		.9145	1.0669	.6097	.6097	.7621	.1524
21	.6097	.7621	.9145	.6097	.6097	.6097	
22	.7621	.7621	.7621	.6097	.6097	.6097	
23	.7621	.7621	.7621	.6097	.6097	.6097	
24	.6097	.7621	.6097	.6097	.4572	.6097	
Max	.7621	1.0669	1.0669	.7621	.7621	.7621	.7621
Min	.6097	.7621	.6097	.6097	.4572	.6097	.1524
Avg	.7011	.8574	.8637	.6478	.5970	.6732	.5716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054012 / 33/11 KV. UMAPUR S/S

Feeder No / Name : 201 / 11 KV. UMAPUR FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4668	.4024	.4572	.4572	.4854	
2	.3881	.4294	.3658	.439	.439	.4481	.462
3		.4108	.5175	.4755	.4755	.4854	.5914
4	.5415	.4854	.6908	.5228	.5975	.5415	
5		.7842	.9709	.7733	.7733	.8589	.7392
6	1.0534	1.0456				1.0829	
7	1.2197	1.1389				1.0456	
8	1.1088	1.0642				1.0642	
9	.961	.9055	1.0642	1.1506	1.0751	.9709	1.0829
10		.7392	.8962	.9054		.7842	.9896
11	.7095	.6838	.7356	.6979	.7922	.6468	.7392
12	.5975	.5175					.6283
13	.5228	.462					.5729
14	.5228	.4435					.5544
15		.4251	.6602	.6036	.6535	.5729	.5359
16	.4854	.4805	.6979	.6602	.6722	.5359	.5544
17	.5975	.7207		.7545	.7842	.7023	
18	.8775	.8501	.9431	.8865	.9602	1.0642	
19	1.0082	1.0642	1.1128	1.1128	1.1016	1.0751	
20	.7842		.9431		.8589	.8131	
21	.6535	.8589	.7167		.7282	.6838	
22	.5975	.6161	.5544	.6979	.5975	.5544	.5544
23	.4854	.5175	.5228	.5975	.5415	.5487	.4938
24	.4251	.4668	.4572	.4755	.5041	.5041	.4887
Max	1.2197	1.1389	1.1128	1.1506	1.1016	1.0829	1.0829
Min	.3881	.4108	.3658	.439	.439	.4481	.462
Avg	.7126	.6772	.7207	.7006	.7066	.7366	.6419

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054012 / 33/11 KV. UMAPUR S/S

Feeder No / Name : 202 / 11 KV. DHONDRAI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2286	.1524	.2286	.2286	.2096	.1905
2	.2667	.1905	.1524	.2096	.2477	.2286	.2286
3		.2286	.1334	.2477	.2667	.2286	.2477
4	.3429	.2286	.1143	.2667	.2858	.2477	
5		.3429	.381	.3048	.2858	.381	
6	.4001	.4191	.4382	.5144	.4191	.4382	
7	.3239	.381	.4001	.4382	.4382	.4001	
8	.3048	.3429	.381	.381	.3429	.381	
9	.2286		.4382	.2858	.2858		.3048
10	.2096	.1905	.2477	.2096	.2667	.1905	.2477
17	.7122	1.1361	1.2574	1.1904	.78	1.0682	
18	1.2378	1.2039	1.2071	1.2239	1.2717	1.1022	
19	1.0852	1.1361	1.1736	1.2071	1.2039	1.1065	
20	1.0159	1.0442		1.1401	1.0852	1.0562	
21	.9339	1.0277	.8718	1.073	.9835	1.0059	
22	.9496	1.0059	.8718	.9892	.9496	.9448	.8619
23	1.0269	.9724	.8551	.9724	.9156	.9054	.8383
24	.2096	.8648	.9448	.8383	.9389	.9496	.8619
Max	1.2378	1.2039	1.2574	1.2239	1.2717	1.1065	.8619
Min	.2096	.1905	.1143	.2096	.2286	.1905	.1905
Avg	.6165	.6438	.5894	.6512	.6220	.6379	.4727

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054012 / 33/11 KV. UMAPUR S/S

Feeder No / Name : 203 / 11 KV. KHALEGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0572	.0762	.0953	.0762	.0762
2	.0953	.0572	.0572	.0762	.0953	.0762	.0762
3	.0953	.0572	.0762	.0762	.0953	.0762	.0762
4	.1143	.0762	.0762	.0762	.0953	.0762	
9	.1362	.16	.3094	.0453	.0551	.1696	.1086
10	.1337	.1337	.1768	.0389	.0453	.1696	.1547
11	.2204	.1132	.0453	.0356	.0486	.1105	.1547
12	.2035	.1132	.0518	.0324	.2035	.1086	.1437
13	.2035	.1132	.0486	.0356	.1696	.1303	.1437
14	.2035	.1048	.0421	.1677	.1357	.1326	.1303
15	.2035		.0453	.0389	.1865	.1326	.1086
16	.2204	.1132	.0453	.0389	.2035	.1086	.1216
19	.0762	.1715	.1524	.1715	.1524	.1905	
20	.0762	.1143	.1524	.1524	.1143	.1334	
21	.0572	.0953	.1143	.1524	.0953	.0953	
22	.0762	.0762	.1143	.1334	.0762	.0762	.0762
23	.0572	.0762	.0953	.1143	.0762	.0762	.0762
24	.0762	.0762	.0762	.0762	.0953	.0762	.0762
Max	.2204	.1715	.3094	.1715	.2035	.1905	.1547
Min	.0572	.0572	.0421	.0324	.0453	.0762	.0762
Avg	.1292	.1016	.0965	.0855	.1133	.1119	.1088

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054012 / 33/11 KV. UMAPUR S/S

Feeder No / Name : 204 / 11 KV. MALEGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.8679	1.5339	2.3624	.5144	1.8351	2.5873
2	1.0098	2.1956	2.0538	2.4387	.4763	2.3922	2.6513
3		2.2119	2.5766	2.934	.4572	2.3266	2.7446
4	1.1622	2.3758	2.8292	3.0674	.4572	2.8006	
5		2.8182	3.263	3.2769	.4954	2.9165	1.9605
6	1.2574	3.2861	3.4168	.9526	.6478	3.2442	3.2065
7	1.4861	2.9492	3.7342	1.0479	.8573	.0246	3.5271
8	1.5432	2.982	3.0994	.8383	.743	2.13	3.1367
15		.0381		.0381		.0381	.0762
16		.0381	.0381	.0381	.0572	.0381	.0762
17	.0572	.0381	.0381	.0572	.0953	.1143	
18	.0762	.0381	.0572	.0762		.1334	
19	.0762	.1334	.1715	.1524		.1524	
20	.0953	.0953	.1715	.1334	.0953	.1143	
21	.0953	.0953	.1334	.1334	.1524	.1143	
22	.0762	.0762	.1143	.1143	.0953	.1143	.0953
23	.0747	.0762	.0953	.0762	.0572	.0762	.0953
24		.0762	.0762	.0762	.0572	.0572	.0762
Max	1.5432	3.2861	3.7342	3.2769	.8573	3.2442	3.5271
Min	.0572	.0381	.0381	.0381	.0572	.0246	.0762
Avg	.5842	1.1884	1.3766	.9897	.3506	1.0346	1.6861

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054012 / 33/11 KV. UMAPUR S/S

Feeder No / Name : 205 / 11 KV TALNEWADI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4001	.4572	.4763	.4763	.4382	.4572
2	.4382	.4191	.4572	.4954	.4572	.4572	.4572
3	.5144	.4572	.4382	.5335	.4954	.4191	.5335
4	.5716	.4954	.4572	.5525	.5525	.4763	
9	3.3573	3.5608	1.4922	3.1017	3.0178	2.5232	3.3951
10	3.3196	3.476	2.0348	3.4202	3.4034	3.2606	3.6763
11	3.1786	3.5376	3.3029	3.5208	3.4034	3.8592	3.5437
12	3.1459	3.5208	3.152	3.2693	3.5848	3.658	3.5791
13	3.195	3.3234	3.2693	3.1855	3.5227	3.5837	3.658
14	3.1459	3.2693	3.3699	3.3364	3.5947	3.4206	3.3608
15			3.0681	3.6885		3.6214	3.0521
16	3.2114	3.1493	3.152	3.1855	3.1786	3.6397	2.9334
19	.6097	.6668	.6668	.6668	.6859	.7049	
20	.6287	.6859	.724	.6478	.6478	.6097	
21	.6478	.6668	.6859	.5716	.5716	.5716	
22	.5716	.5335	.6097	.5144	.5335	.5716	.6097
23	.5144	.4954	.5716	.4954	.4954	.5144	.6097
24	.4763	.4954	.4763	.5144	.5144	.4763	.4763
Max	3.3573	3.5608	3.3699	3.6885	3.5947	3.8592	3.6763
Min	.4382	.4001	.4382	.4763	.4572	.4191	.4572
Avg	1.6461	1.7149	1.5770	1.7876	1.7138	1.8225	2.1673

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054021 / 33/11 KV. TALWADA S/S

Feeder No / Name : 201 / 11 KV. CHAVANWADI FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.9616		1.7737
2		2.0538		1.7737
3		2.1098		1.8111
4		2.2032		1.8296
5		2.2779		1.885
6		2.3525		2.0883
7		2.7536		2.1992
8		2.6242		
15	.2286		.2286	
16	.2477		.2477	
17	.2858		.2858	
18	.3239		.362	
19	.4382		.4763	
20	.4572		.5335	
21	.4763		.5144	
22	.4572		.4763	
23	.4191		.4382	
24		.4001		.4001
Max	.4763	2.7536	.5335	2.1992
Min	.2286	.4001	.2286	.4001
Avg	.3704	2.0819	.3959	1.7201

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054021 / 33/11 KV. TALWADA S/S

Feeder No / Name : 202 / 11 KV. ANTARWALI FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	04-MAY-17
HR	Load (MW)	Load (MW)
23	.0191	.0191
Max	.0191	.0191
Min	.0191	.0191
Avg	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054021 / 33/11 KV. TALWADA S/S

Feeder No / Name : 203 / 11 KV. RAMPURI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	04-MAY-17
HR	Load (MW)	Load (MW)
23	.0191	.0191
Max	.0191	.0191
Min	.0191	.0191
Avg	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054021 / 33/11 KV. TALWADA S/S

Feeder No / Name : 204 / 11 KV. NEW TALWADA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	04-MAY-17
HR	Load (MW)	Load (MW)
23	.0191	.0191
Max	.0191	.0191
Min	.0191	.0191
Avg	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054021 / 33/11 KV. TALWADA S/S

Feeder No / Name : 205 / 11 KV DEVI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.381		.4572
2		.3429		.4382
3		.3429		.4382
4		.362		.4954
5		.381		.5716
6		.5906		.6668
7		.6859		.743
10	.4382			
17	3.6214		3.2739	
18	3.658		3.3484	
19	3.4385		3.1276	
20	3.1786		3.0678	
21	2.9938		2.809	
22	2.6612		2.7351	
23	2.7073		2.5579	
24		2.5766		2.4209
Max	3.658	2.5766	3.3484	2.4209
Min	.4382	.3429	2.5579	.4382
Avg	2.8371	.7079	2.9885	.7789

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054021 / 33/11 KV. TALWADA S/S

Feeder No / Name : 206 / 11 KV RAHERI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.2032		2.2032
2		2.1845		2.2405
3		2.2032		2.2546
4		2.2218		2.3655
5		2.2546		2.4579
6		1.8671		1.8298
7		2.0538		1.922
11	.6668			
12	.5716		.6287	
13	.5144		.4763	
14	.4001		.4954	
15	.4382		.4954	
16	.4763		.5144	
17	.5335		.724	
18	.8192		.743	
20	.8573		.1334	
21	.8954		.9526	
22	.9335		.8764	
23	.8573		.7811	
24		2.1658		2.1472
Max	.9335	2.2546	.9526	2.4579
Min	.4001	1.8671	.1334	1.8298
Avg	.6636	2.1443	.6201	2.1776

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054035 / 33/11 KV. SIRASMARG S/S

Feeder No / Name : 201 / 11 KV. SIRASMARG FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1423						
2		.1543					.168
4		.1543				.1715	.168
5				.2534			
6	.3321	.2401		.3258		.2572	.2241
7	.2846	.3086		.3086	.3163		
8	.2846	.2743		.2804	.2846	.3086	.3258
9			.2715				.2149
10		.2058				.2614	.128
11		.1867		.0762	.2058	.2614	.1109
12	.1543	.1867			.1715	.1494	.0924
13	.1543	.1867			.1543	.1478	.1109
14	.1543	.1867				.1494	.0924
15	.1372			.1898	.1543		.0924
16	.1372	.1867	.1848	.1423	.1543	.1494	.011
17	.1543		.1478		.1543	.1494	.112
18	.2058			.253	.2058		.2058
19	.2401		.3077	.253	.2401	.2587	
20	.2572			.2214	.2743		.2321
21	.2401				.2572		
22	.2058		.1478		.2401		.1294
23			.1753		.2058	.1886	.1294
24		.1543	.1494	.0747	.1524	.1715	.168
Max	.3321	.3086	.3077	.3258	.3163	.3086	.3258
Min	.1372	.1543	.1478	.0747	.1524	.1478	.011
Avg	.2056	.2021	.1978	.2162	.2114	.2019	.1509

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054035 / 33/11 KV. SIRASMARG S/S

Feeder No / Name : 202 / 11 KV. UKHADPIMPRI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524						
2						.1829	.2378
4						.1829	.2286
5				.4687			
6	.5182			.6622		.5335	.2984
7	.6097			.7819	.6097		
8	.5792		.3239	.7287	.5792	.7716	.602
9				.6249			.5418
10				.1981		.2439	.2591
11				.1829	.1829	.1852	.1875
12				.1524	.1524	.1829	.2006
13	.1829			.1524	.1524	.1829	.1981
14	.1524					.1829	.1829
15	.1524			.1829	.1677		.1852
16	.1829		.1852	.1981	.1524	.1852	.1829
17	.1981		.1981		.1829	.1852	.1646
18				.1829	.1981		.3286
19	.1981		.4365	.3658	.2743	.4161	
20				.3963	.4572		.4214
21					.4268		
22					.3658		.2494
23			.2559		.3353	.2408	.2439
24		.1981	.1235	.2606	.1829	.1829	.2378
Max	.6097	.1981	.4365	.7819	.6097	.7716	.602
Min	.1524	.1981	.1235	.1524	.1524	.1829	.1646
Avg	.2926	.1981	.2539	.3693	.2947	.2756	.2750

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054035 / 33/11 KV. SIRASMARG S/S

Feeder No / Name : 203 / 11 KV. SHAJANPIMPRI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.1715				.1715	.1524
4		.1715				.1715	.1783
5				.2915			
6	.3163	.3429		.3637		.4287	.2972
7	.3479	.4287		.5201	.4586		
8	.3005	.5144	.4858	.4214	.0949	.4801	.362
9			.3647				.2187
10		.2229				.1867	.0754
11		.0934		.0633	.0857	.0943	
12	.2058			.0633		.0754	
13	.2058	.112		.0633		.0754	
14	.1715			.0633		.0648	
15	.1715			.0633			.0566
16	.1715		.1646	.0633	.0857	.0497	.0566
17			.1478		.1029	.0724	.0943
18	.1715			.0633	.12		.0934
19	.2229		.1886	.1265	.1715	.1509	.168
20	.2401			.1265	.1715		.1494
21	.2229				.1715		.132
22	.2229				.1715		.132
23			.1848		.1715	.0762	.132
24	.0949	.1715	.1021	.1219	.0949	.1715	.041
Max	.3479	.5144	.4858	.5201	.4586	.4801	.362
Min	.0949	.0934	.1021	.0633	.0857	.0497	.041
Avg	.219	.2476	.2341	.1725	.1584	.1621	.1462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054035 / 33/11 KV. SIRASMARG S/S

Feeder No / Name : 204 / 11 KV. TAKALGAVAN FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.1829				.1677	.2241
4		.1829				.1677	.2241
5				.3361			
6	.381	.3048		.4294		.1829	.3696
7	.3353	.3944		.415	.3048		
8	.3048	.2743	.3734	.3584	.2439	.2134	.4108
9			.2987	.1981			.2452
10		.4572				.2881	.3591
11		.4344		.7316	.7316	.482	.5258
12	.884	.4374		.6325	.7316	.4268	.5487
13	.7621	.4296		.6554	.6859	.4572	.503
14	.6859	.4496				.423	.4344
15	.6401			.5487	.6516		.4115
16	.6706	.4496	.4687	.6401	.5335	.4321	.4458
17			.5258		.5944	.5144	
18	.1829			.1067	.1829		
19	.2134		.3921	.2439	.2286		
20	.2743			.2743	.2743		
21					.2591		
22	.2134				.2286		.3109
23			.2587		.1981	.3018	.2587
24	.1829	.1829	.2241	.2614	.1829	.1829	.2241
Max	.884	.4572	.5258	.7316	.7316	.5144	.5487
Min	.1829	.1829	.2241	.1067	.1829	.1677	.2241
Avg	.4408	.3483	.3631	.4165	.4021	.3262	.3664

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054055 / 33/11 KV. GULJ S/S

Feeder No / Name : 201 / 11 KV. GULJ FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6			.1006	.1006		.0995
9	2.8978					
17		2.9721				
19			.0995			
20					.116	
23					.1017	
24			.1006	.1006		.6443
Max	2.8978	2.9721	.1006	.1006	.116	.6443
Min	2.8978	2.9721	.0995	.1006	.1017	.0995
Avg	2.8978	2.9721	.1002	.1006	.1089	.3719

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054055 / 33/11 KV. GULJ S/S

Feeder No / Name : 202 / 11 KV. MALEGAON FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.9998	1.1603	1.1603		1.0774
19		.0663			
20				.0663	
24		.8048	.7712		.7545
Max	.9998	1.1603	1.1603	.0663	1.0774
Min	.9998	.0663	.7712	.0663	.7545
Avg	.9998	.6771	.9658	.0663	.9160

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054055 / 33/11 KV. GULJ S/S

Feeder No / Name : 203 / 11KV GFS MALEGAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6			2.3537	2.1879		2.1548
9	.7059					
17		.3439				
18			.6962			
19			1.989			
20					.7956	
24			1.4754	1.5424		1.5927
Max	.7059	.3439	2.3537	2.1879	.7956	2.1548
Min	.7059	.3439	.6962	1.5424	.7956	1.5927
Avg	.7059	.3439	1.6286	1.8652	.7956	1.8738

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054055 / 33/11 KV. GULJ S/S

Feeder No / Name : 204 / 11 KV GULAJ GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		1.0774	1.094		.9945
8	.8859				
9	.4805				
18		.8383			
19		.9282			
20				.9116	
24		.6036	.7545		.6443
Max	.8859	1.0774	1.094	.9116	.9945
Min	.4805	.6036	.7545	.9116	.6443
Avg	.6832	.8619	.9243	.9116	.8194

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054085 / 33/11KV DHONDRAI S/S

Feeder No / Name : 201 / 11KV RAJPIMPRI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5544	.5853	.3887	.3563	.5121
2	.5228	.5792	.3887	.3887	.5121
3	.4298	.5792	.3887	.3887	.5228
4	.3982	.5853	.3887	.3887	.5228
5	.4024	.6516	.421	.3887	.5121
6	.3658	.6584	.4534	.421	.5792
7	.3696	.6516	.5182	.4534	.6516
8	.3361	.6379	.3887	.3887	.5853
9	.3258	.3239	.3563	.3887	.439
10		.3239			.4108
16	.8688	.3887	.421	.2896	
17	1.5424	1.2955	1.1336	1.2437	1.576
18	1.5257	1.2955	1.2955	1.3032	1.6289
19	1.3321	1.3279	1.2955	1.3169	1.5893
20	1.3032	1.2308	1.2631	1.1919	1.4937
21	1.3169	1.1984	1.247	1.3169	
22	1.3169	1.166	1.2308	1.4045	
23	1.2308	1.1336	1.2308	1.419	
24	.5914	.5853	.3563	.3239	.4481
Max	1.5424	1.3279	1.2955	1.419	1.6289
Min	.3258	.3239	.3563	.2896	.4108
Avg	.8185	.7999	.7314	.7429	.7989

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054085 / 33/11KV DHONDRAI S/S

Feeder No / Name : 202 / 11KV DHONDRAI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2936	1.0974	1.086	1.0288	1.1706
2	1.3817	1.086	1.086	1.2003	1.2437
3	1.3253	1.1584	1.1222	1.2346	1.2696
4	1.4118	1.1706	1.1222	1.2346	1.2696
5	1.4632	1.3443	1.1946	1.286	1.2437
6	1.531	1.39	1.2308	1.3717	1.1584
7	1.6263	1.3032	1.1946	1.406	1.3756
8	1.531				
14	.5121	.362	.3982	.4344	
15	.5792	.3982	.4344	.5853	.6024
16	.724	.362	.4706	.6516	.7522
17	.7011	.3982	.3772	.6584	.788
18	.6935	.4706	.4801	.6516	.7602
19	.9816	.905	.6516	1.0242	1.1694
20	1.1584	.6859	.8573	.9114	1.1694
21	1.1706	.7888	.7888	.9511	
22	1.0974	.7545	.6859	1.0456	
23	.9412	.6859	.6516	1.0456	
24	1.2567	.9511	.8573	.8573	.9709
Max	1.6263	1.39	1.2308	1.406	1.3756
Min	.5121	.362	.3772	.4344	.6024
Avg	1.1252	.8507	.8161	.9766	1.0674

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054085 / 33/11KV DHONDRAI S/S

Feeder No / Name : 204 / 11 KV MAHALAXMI INDESTRIAL SHEDDABLE FEEDER HAVING WEEKLY
 FEE Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5175	.7316	.6478	.1296	.5121
2	.5601	.7602	.6478	.0972	.439
3	.5731	.7602	.04	.0972	.4108
4	.4706	.7682	.6802	.0972	.4108
5	.4938	.7602	.6478	.081	.3292
6	.5228	.8048	.6478	.0648	.3258
7	.4435	.7964	.6478	.0648	.2896
8	.3734	.3544	.421	.1296	.2926
9	.1448	.2915	.0972	.1296	.5281
10	.1463	.3239	.0648	.2926	.4668
11	.1448	.3239	.0324	.3658	.4251
12	.2195	.3563	.0324	.3982	.3921
13	.1448	.3887	.0324	.3658	.3326
14	.1829		.0486	.362	.3658
15	.181	.3239	.0648	.4024	.543
16	.3258	.2591	.0648	.5068	.5853
17	.3155	.3239	.0648	.6878	.5792
18	.3467	.3563	.0648	.6878	.7095
19	.3856	.421	.0972	.3658	.6036
20	.2896	.4534	.1296	.1753	.3395
21	.695	.3239	.1296	.3658	
22	.6584	.3563		.5914	
23	.6516	.3239	.1296	.5975	
24	.5175	.695	.3239	.1296	.5228
Max	.695	.8048	.6802	.6878	.7095
Min	.1448	.2591	.0324	.0648	.2896
Avg	.3877	.4894	.2503	.2994	.4478

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054008 / 33/11 KV. PATODA S/S

Feeder No / Name : 201 / 11 KV. PATODA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2							1.0288
4			1.166				1.1317
5						1.3003	
6		1.595	1.543	1.595	1.595	1.5775	1.6263
7		1.7661		1.6651	1.8519		1.5424
8	1.5927	1.6804	1.5091		1.6632	1.5257	
9	1.4582			1.5775			
10				1.4899			
11				1.3643			
15				1.3643			
17			1.3146	1.3466	1.3146		1.2403
18	1.3289	1.286	1.387		1.406		1.3289
19	1.5424	1.4083	1.406	1.4548	1.5775	1.643	1.4022
20	1.6297	1.5083	1.595	1.6289	1.6832	1.5927	1.6289
21	1.4175	1.4243		1.4548		1.4582	1.3643
22	1.2934	1.2039		1.3289		1.3375	
23					1.2269		
24		1.0277	1.0631		1.0985		
Max	1.6297	1.7661	1.595	1.6651	1.8519	1.643	1.6289
Min	1.2934	1.0277	1.0631	1.3289	1.0985	1.3003	1.0288
Avg	1.4661	1.4333	1.3730	1.4791	1.4908	1.4907	1.3660

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054008 / 33/11 KV. PATODA S/S

Feeder No / Name : 203 / 11 KV. MAJARSUMBHA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			1.0174				.9945
4			1.3717				1.1488
5						1.7337	
6		1.749		1.4899	1.595	1.7833	
7		1.3643			1.595		
8		1.2226			1.3672		
18		.6173					
19	1.258	1.1869	1.3717	1.5089		1.576	
20	1.5257	1.6095	1.6289	1.7147	1.7528	1.4074	1.4899
21	1.4175	1.3565		1.4723			1.3672
22	1.258	1.0974		1.2757		1.2717	
23					1.0341		
24		.9922	.9431		1.1163		.9088
Max	1.5257	1.749	1.6289	1.7147	1.7528	1.7833	1.4899
Min	1.258	.6173	.9431	1.2757	1.0341	1.2717	.9088
Avg	1.3648	1.2440	1.2666	1.4923	1.4101	1.5544	1.1818

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054008 / 33/11 KV. PATODA S/S

Feeder No / Name : 204 / 11 KV. TALE PIMPALGAON SINGLE PHASING

FEEDER Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2							.4801
4			.6344				.6859
5						.7362	
6		.9391	.9602	1.2656	1.0099	1.0867	.9602
7		1.134		1.0288	1.0631		1.0974
8	.78	1.0631	.8139		.9214	.9945	
9	.7202			.9114			
10				.5959			
11				.4784			
13				.567			
15				.4252			
17				.567	.5959		.567
18	.6201	.4115	.823		.6661		.6379
19	1.0631	.7461	1.1831	.9922	.9114	1.046	1.134
20	1.134	1.073	1.1145	1.134	.9114	1.046	.9922
21	.9391	.8745		.8682		.8573	.8505
22	.8328	.823		.7796		.7716	
23					.8764		
24		.4961	.4801		.6379		.6859
Max	1.134	1.134	1.1831	1.2656	1.0631	1.0867	1.134
Min	.6201	.4115	.4801	.4252	.5959	.7362	.4801
Avg	.8699	.8400	.8585	.8011	.8437	.9340	.8091

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054008 / 33/11 KV. PATODA S/S

Feeder No / Name : 206 / MAHASANGVI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2							.3944
4			.4973				.6173
5						.4908	
6		.815	.6516		.7796	.6588	.9774
7		.9391		.7888	.8859		.9431
8	.6859	.8505	.8916		.9568	.7888	
9	.6687			.6859			
10				.3506			
11				.2149			
13				.2149			
15				.2149			
17			.2229	.2149	.2401		.197
18	.2149	.2058	.2774		.1387		.2149
19	.3898	.2743	.3944	.443	.2629	.4115	.3544
20	.4961	.4115	.9536	.4784	.4908	.3772	.3898
21	.3898	.3429		.4252		.3601	.3721
22	.3544	.3086		.3544		.3429	
23					.2947		
24		.3898	.3258		.3012		.2915
Max	.6859	.9391	.9536	.7888	.9568	.7888	.9774
Min	.2149	.2058	.2229	.2149	.1387	.3429	.197
Avg	.4571	.5042	.5268	.3987	.4834	.4900	.4752

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054044 / 33/11 KV. KUSLAMB S/S

Feeder No / Name : 201 / 11 KV. KUSLAMB FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.0288		.6001	
11		.7716		
13				.4115
Max	1.0288	.7716	.6001	.4115
Min	1.0288	.7716	.6001	.4115
Avg	1.0288	.7716	.6001	.4115

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054044 / 33/11 KV. KUSLAMB S/S

Feeder No / Name : 202 / 11 KV. SAUTADA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.8916	1.2346	1.1317	1.0117	1.0631
11			.3429		
16				.3601	
Max	.8916	1.2346	1.1317	1.0117	1.0631
Min	.8916	1.2346	.3429	.3601	1.0631
Avg	.8916	1.2346	.7373	.6859	1.0631

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054044 / 33/11 KV. KUSLAMB S/S

Feeder No / Name : 203 / 11 KV. CHINCHOLI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.1715	.2058	.1715	.1886	.1543
11			.1886		
13					.1715
Max	.1715	.2058	.1886	.1886	.1715
Min	.1715	.2058	.1715	.1886	.1543
Avg	.1715	.2058	.1801	.1886	.1629

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054056 / 33/11 KV. BHAYALA S/S

Feeder No / Name : 201 / 11 KV. BHAYAL FEEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1094	.1107	.1067	.0914
2		.1094	.1107	.1067	.0914
3		.125	.1265	.1067	.0914
4		.1852	.1562	.1372	.1067
5		.2286	.1875	.1829	.1829
6		.2591	.2343	.2286	.2439
7		.2591	.2656	.2743	.2743
8	.1981	.2315	.2343		.2439
9	.1677	.2006	.2031	.1677	.1829
10	.4268	.4401	.3668	.381	.381
11		.5068		.5335	.5182
12		.4344		.4572	.4877
13	.3963	.3668	.4572	.4572	.442
14	.3658	.3668	.4572	.4268	.4268
15	.381	.3668	.4877	.4268	
16	.381	.2641	.5182	.4572	
17	.4344	.4401	.4572	.4572	
18	.1094	.1265		.1067	
19	.2439	.2469	.1829	.2439	
20	.2006	.2187	.1981	.2286	
21	.1562	.1875	.1372	.1829	
22	.125	.1562	.1372	.1219	
23	.1094	.1265	.1067	.1067	
24	.1219	.1094	.1107	.1067	.0914
Max	.4344	.5068	.5182	.5335	.5182
Min	.1094	.1094	.1067	.1067	.0914
Avg	.2545	.2527	.2498	.2611	.2571

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054057 / 33/11 KV ROHATWADI

Feeder No / Name : 201 / 11 KV NAIGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3353		.2439	.3429	.4115	.3772
2	.3048	.3506	.3429	.3429	.3086	.3048	.3048
3	.3353	.381	.3658	.4115	.2743	.3353	.4572
4	.3658	.4268	.4268	.3048	.3048	.3658	.5487
5	.3963	.503	.4877	.3658	.3658	.4572	.6097
6	.6097	.7011	.7011	.4572	.7926	.7773	.7621
7	.7316	.9297	.7773	.6097	.9755	.8993	.9145
8	.7926	.884	.7011	.7926	.8535	.823	.7316
9	.6097	.823	.7316	.9145	.7011	.7773	.6706
16	.4458	.4287	.7545	.3429	.4801	.3429	.3258
17	.5487	.5144	.4801	.583	.5487	.6173	.5144
18	.6516	.5658	.823		.6173	.6859	.6001
19	.9259	.8059	.8916	.7888	.8916	.8916	.583
20	.9945	.823	.9602	.8916	.9945	1.0288	.9602
21	.6687	.6516	.6173	.6859	.7373	.8573	
22	.5144	.5487	.5487	.5144	.5487	.5487	
23	.4458	.4458	.4115	.4458	.4801	.4115	.4458
24	.2743	.3429	.2439	.2439	.3772	.4287	.4115
Max	.9945	.9297	.9602	.9145	.9945	1.0288	.9602
Min	.2743	.3353	.2439	.2439	.2743	.3048	.3048
Avg	.5511	.5812	.6038	.5258	.5886	.6091	.5761

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054057 / 33/11 KV ROHATWADI

Feeder No / Name : 202 / 11 KV ROHATWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.583		.5487	.6173	.6173	.583
2	.6173	.5487	.5487	.5144	.6173	.6001	.5487
3	.6859	.6001	.6173	.583	.6859	.6173	.6859
4	.823	.7202	.7888	.8573	.7545	.7202	.8573
5	1.0974	1.0802	1.0974	1.0288	.8916	.9945	1.0288
10	.7926	.7316	.6401	.6706	.5335	.7621	.5487
11	.7621	.7926	.8535	.6706	.6401	.7621	.6097
12	.6401	.7011	.823	.6706	.6097	.7316	.6401
13	.5335	.6401	.6706	.6401	.6401	.6706	.5182
14	.6554	.6097	.6706	.5182	.6401	.6097	.5487
15	.6401	.6706	.6097	.5182	.5487	.5487	.5792
16	.8078	.7011	.6706	.6401	.6401	.6097	.5487
17	.8535	.7011	.8535	.7316	.7621	.7316	.7773
18	.4801	.5487	.6859		.5144	.5487	.583
19	.8402	.7202	.6859	.823	.7545	.823	.5658
20	1.046	.9945	1.0288	1.0288	1.1317	1.0288	1.0802
21	.8745	.823	.823	.8916	.8573	.9602	
22	.6859	.7888	.7545	.7545	.7888	.7545	
23	.6859	.6516	.6173	.6859	.7202	.6859	.6173
24	.6173	.583	.583	.5487	.6173	.6173	.6173
Max	1.0974	1.0802	1.0974	1.0288	1.1317	1.0288	1.0802
Min	.4801	.5487	.5487	.5144	.5144	.5487	.5182
Avg	.7378	.7095	.7380	.7013	.6983	.7197	.6632

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054057 / 33/11 KV ROHATWADI

Feeder No / Name : 203 / 11 KV DOMRI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.3506		.3048	.3429	.3086	.3429
2	.3353	.3658	.3772	.3772	.3429	.3201	.3048
3	.3658	.3963	.381	.4115	.3429	.3658	.3963
4	.3963	.4268	.3963	.3963	.3048	.4115	.4572
5	.4268	.4877	.4725	.4268	.3048	.5182	.6097
6	.7316	.823	.8535	.6097	.7926	.884	.7316
7	.7621	1.0517	1.0059	.8535		.9602	.7926
8	.8383	.945	.823	.9145	.9755	1.0059	.8535
9	.7926	.9297	.8383	.9145	.7621	.884	.7926
16	.2915	.2572	.2743	.2743	.3429	.2743	.3086
17	.3429	.2743	.3086	.3086	.3601	.3086	.4115
18	.3772	.3258	.4801		.3772	.3429	.3772
19	.6173	.6173	.5487	.6859	.5487	.6859	.3944
20	.8402	.6859	.6859	.823	.7545	.823	.6173
21		.583	.5144	.5487	.583	.6173	
22	.4458	.4115	.4115	.4115	.4801	.4801	
23	.3429	.3772	.3429	.3772	.3772	.4115	.3429
24	.3048	.3201	.3506	.3048	.3429	.3086	.3429
Max	.8402	1.0517	1.0059	.9145	.9755	1.0059	.8535
Min	.2915	.2572	.2743	.2743	.3048	.2743	.3048
Avg	.5027	.5349	.5332	.5260	.4903	.5506	.5048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054069 / 33/11 KV. DONGARKINNI S/S

Feeder No / Name : 201 / 11 KV. NALWANDI FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5144					
2		.6001			.4287	.5335	.3391
3		.6859	.4287		.5144		
4	.6859	.823	.6859	.7316	.6859	.4572	.5335
5		.9431	.7716		.823		
6	1.1022	1.0288	.8573	1.2574	.9602	.6097	.7621
7	1.166	1.1145		1.0898			.8478
8	1.2003	1.0774	.9145		1.0288	.7621	.9326
9	1.2003	1.0288		.7865	1.0288		.9326
10	.1886	.2801	.4268	.1867	.2263	.2012	.1867
11	.1886	.2801		.2241			.1867
12	.1886	.2614	.2743	.2241		.2012	
13	.2263	.2641					
14	.2829	.2641	.1829	.1867		.2515	
15	.2829	.2641					.2957
16	.2926	.2829	.1696				.2801
17	.2926	.2987					.2801
18	.3772		.3018				.3174
19	.4715		.3239				.3734
20	.5228						.4668
21	.4715		.4588				.5228
22	.3395						.3734
23	.2641		.2743	.1886		.2195	.3361
24	.5335	.4287	.2743	.381	.1867	.5935	.1829
Max	1.2003	1.1145	.9145	1.2574	1.0288	.7621	.9326
Min	.1886	.2614	.1696	.1867	.1867	.2012	.1829
Avg	.5139	.5800	.4532	.5257	.6536	.4255	.4528

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054069 / 33/11 KV. DONGARKINNI S/S

Feeder No / Name : 202 / 11 KV. DONGARKINHI FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2572					
2		.3086			.3086	.3048	.2543
3		.3429	.4287		.4287		
4	.3052	.4287	.6001	.381	.5144	.381	.3391
5		.6001	.6859		.6001		
6	.2572	.7716	.7545	.6859	.6859	.5335	.4572
7		.6859		.6859			.5487
8	.3052		.6706		.5533	.6859	.5487
9	.3429			.6036	.5868		.5144
10	.1509	.2801	.1696	.1494	.1509	.2572	.168
11	.3018	.2829		.168			.168
12	.3395			.168		.1715	
13	.3018	.2829		.1494			
14	.3018	.2829	.1433	.1494		.2058	
15	.3018	.2801					.1867
16	.3174	.3018	.1372			.1357	.1698
17	.3361						.168
18	.3772		.2241			.1372	.1867
19	.3772		.3353				.2829
20	.4715						.3734
21	.2829	.3734	.4239	.2801		.3429	.2801
22	.2829	.3361		.2241			.2801
23	.2452	.2801	.2229	.1867		.1715	.2241
24	.1734	.1715	.2743	.2439	.1867	.3353	.1715
Max	.4715	.7716	.7545	.6859	.6859	.6859	.5487
Min	.1509	.1715	.1372	.1494	.1509	.1357	.168
Avg	.3038	.3686	.3900	.3135	.4462	.3052	.2957

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054069 / 33/11 KV. DONGARKINNI S/S

Feeder No / Name : 203 / 11 KV. JATNANDUR FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2829	.4481		.4108		
2		.2829	.4481	.407	.3734	.3391	.4287
3		.3734	.4668		.5601		
4		.5228	.5228	.4694	.6535	.4191	.6535
5		.6535	.5601		.7468		
6	.6859		.9335		.8402	.6783	.7316
10	.663		.8383	.6554	.9602	.6859	.6706
11	1.326	1.4243		1.065			.9221
12	1.2929	1.4083	1.2955	1.1142		.8383	.9831
13	1.2763	1.2574		1.1469			
14	1.1603	1.2003	.9907	.8192		.9145	
15	1.0277	1.1145					.8097
16	1.0159	.9431	.9259			.945	.8848
17	.9995	1.286					.9012
18		.4715	.381				
19		.7842		.4668		.6859	
20		.9335		.6535			
21		.8962		.7468		.6859	.5487
22	.3772	.7095		.7468			.7316
23	.3395	.6535	.5868	.4668		.5144	.5853
24		.2829	.4481	.3658	.4481	.4239	.4287
Max	1.326	1.4243	1.2955	1.1469	.9602	.945	.9831
Min	.3395	.2829	.381	.3658	.3734	.3391	.4287
Avg	.9240	.8148	.6804	.7018	.6241	.6482	.7138

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054091 / 33/11 KV. KOTAN S/S

Feeder No / Name : 201 / 11 KV. AMALNER FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	04-MAY-17
HR	Load (MW)
9	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054091 / 33/11 KV. KOTAN S/S

Feeder No / Name : 202 / 11 KV. HATOLA FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0686		.0305
2		.0686		.0305
3		.0514		.0267
4		.0514		.0305
5		.0514		.0305
6		.0514		.0305
7	.0514	.0514		.0305
8		.0514		.0305
9			.1524	.0305
10	.12			
11	.1543			
12	.1886			
13	.1372			
14	.1715			
15	.1543			
16	.1715			
17	.1372			
18	.0514			
24	.0514	.0857		.0305
Max	.1886	.0857	.1524	.0305
Min	.0514	.0514	.1524	.0267
Avg	.1263	.0590	.1524	.0301

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054091 / 33/11 KV. KOTAN S/S

Feeder No / Name : 203 / 11 kv Amalner

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.3772		.4001
2	.4973	.5144		.4134
3	.5144	.5144		.4268
4	.5487	.6001		.4877
5	.5487	.5144		.4268
6	.5487	.4801		.4668
7	.5144	.583		.4668
8	.5487	.4801		.4668
9	.3429		.0591	.4668
10	.2229			
11	.2401			
12	.2058			
13	.2401			
14	.2572			
15	.2915			
16	.2915			
17	.2743			
18	.2401			
24	.5487	.4115		.4001
Max	.5487	.6001	.0591	.4877
Min	.2058	.3772	.0591	.4001
Avg	.3836	.4972	.0591	.4422

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054091 / 33/11 KV. KOTAN S/S

Feeder No / Name : 204 / 11 kv Hatola

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17
HR	Load (MW)	Load (MW)
1	.0171	.0343
2	.0171	.0343
3	.0343	.0343
4	.0343	.0343
5	.0343	.0343
6	.0343	.0171
7	.0171	.0171
8	.0171	.0171
9	.0171	
10	.0171	
11	.0171	
12	.0171	
13	.0171	
14	.0171	
17	.0171	
18	.0171	
24	.0171	.0343
Max	.0343	.0343
Min	.0171	.0171
Avg	.0211	.0286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054096 / 33/11 KV. DASKHED S/S

Feeder No / Name : 201 / 11 KV. DASKHED FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.0179	.0179
2						.0179	.0179
3						.0179	.0179
4						.0179	.0179
5						.0179	.0179
6						.0179	.0179
7						.0179	
8						.0179	
9						.0179	
10	.1059	.0806	.1443	.0647	.1086	.1059	.0714
11	.1107	.1263	.1259	.1448	.1448	.0979	.1086
12	.1085		.1012	.1448	.1086	.0967	.1267
13	.0931	.1443	.09	.1448		.0802	.1267
14	.09	.1083	.092	.1267		.092	.1086
15	.0776	.1263	.093	.1267		.0772	.1086
16	.0737	.1804	.0902	.1448	.1355	.072	.1267
17	.0948	.1985	.0823	.1086	.1204	.1068	.1267
20					.0169	.0179	
21					.0169	.0179	
22					.0169	.0179	.0181
23						.0179	.0181
24						.0179	.0179
Max	.1107	.1985	.1443	.1448	.1448	.1068	.1267
Min	.0737	.0806	.0823	.0647	.0169	.0179	.0179
Avg	.0943	.1378	.1024	.1257	.0836	.0445	.0627

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054114 / 33/11Kv Lambarwadi S/s

Feeder No / Name : 201 / Lambarwadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0848	.4287		.2408	.0848	.3772	
2	.0848	.4973		.0678	.0848		.2743
3	.0848	.5316	.4287	.0678	.3311		
4	.1505	.5658	.6001	.2258	.3763		
5	.3311	.6344	.7716	.5569	.4666		
6	.4816	.6859	.823	.6622	.587		
7	.4666	.7716	.8916	.7676	.8278		
8	.587	.6344	.8059	.8128	.7827	.6859	.8745
9	.5569	.5487	.7716	.6773	.6773	.7888	
10	.0848		.0857		.1017	.1029	
11		.12	.1017				
12		.0857	.0678		.0686		
13		.0857	.0678			.0857	
14		.0686	.0678				
15		.0686	.0678				.0686
16			.0848		.1029	.0857	
17		.0686	.1187		.1029		
18		.0857	.1526				
19		.1543	.2374				
20		.1543	.2204	.3052	.2401		
21		.1372	.1696	.2035			
22		.12	.1357	.1357			
23		.12	.1017	.1017	.1029		
24	.1505	.3429	.2915	.2709	.1017		
Max	.587	.7716	.8916	.8128	.8278	.7888	.8745
Min	.0848	.0686	.0678	.0678	.0686	.0857	.0686
Avg	.2785	.3141	.3211	.364	.3150	.3544	.4058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054114 / 33/11Kv Lambarwadi S/s

Feeder No / Name : 202 / Chincholi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4214	.5487	.5487	.5087	.5087	.5144	
2	.4748	.5487	.5316	.5087	.5087		.4973
3	.4578	.5487	.5144	.5087	.5087		
4	.5426	.6001	.6859	.5935	.6274		
5	.8987	.6516	.7373	1.0343	1.0174		
6		.7202	.7545		1.5746		
7	1.17	.7716	.7716				
8	1.1869	.8916	.7202		.9156		
9	.763	.7202	.6859	.8122	.8478		
10	.2709	.463	.5144	.3311	.4214	.2743	
11		.5316	.4458	.4515			
12		.5658	.4064	.5268	.4458		
13		.583	.3763	.5268		.3944	
14		.6001	.3763	.5418			
15		.583	.3763	.3311			.3258
16			.3763			.3086	
17		.6859	.4515		.4115		
18		.7202	.6783				
19		.7716	1.1361				
20		.7716	1.1869	.8648	.9259		
21		.7716	1.1022	.8139			
22		.7545	.6443	.763			
23		.7202	.5935	.6443	.6001		
24	.5087	.5487	.583	.5087	.5596		
Max	1.1869	.8916	1.1869	1.0343	1.5746	.5144	.4973
Min	.2709	.463	.3763	.3311	.4115	.2743	.3258
Avg	.6695	.6553	.6332	.6041	.7052	.3729	.4116

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054114 / 33/11Kv Lambarwadi S/s

Feeder No / Name : 203 / Muggoan SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2543	.3772		.2709	.2883	.2915	
2	.2543	.3944		.2035	.2883		.2401
3	.2543	.3944	.4287	.2035	.2258		
4	.2709	.3944	.463	.2559	.2258		
5	.2709	.3944	.463	.301	.2709		
6	.3913	.3944	.4973	.4214	.3311		
7	.3913	.4287	.5144	.4967	.4064		
8	.3763		.4973	.4365	.4515	.4287	
9	.3763	.4287	.463	.3161	.4214	.4287	
10	.2543	.3429	.2572		.2883	.2572	
11		.3258	.2204				
12		.3086	.2204				
13		.2915	.2204			.1886	
14		.2572	.2204				
15		.2058	.2204				.1886
16			.2204		.1543	.2572	
17		.2401	.2374		.1715		
18		.2915	.3222				
19		.4115	.4578				
20		.3772	.5087	.5765	.5487		
21		.3601	.4578	.4409			
22		.3086	.3391	.3561			
23		.2915	.3391	.3052	.3086		
24	.2408	.3772	.2572	.2107	.3052		
Max	.3913	.4287	.5144	.5765	.5487	.4287	.2401
Min	.2408	.2058	.2204	.2035	.1543	.1886	.1886
Avg	.3032	.3453	.3557	.3425	.3124	.3087	.2144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

SHIRUR(KASAR) S/DN.[802] BU 4802

Substation No/ Name :- 054013 / 33 KV RAIMOHA

Feeder No / Name : 201 / 11 KV AMALNER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1486		.1932	
2		.1783		.2972	
3		.3715		.2972	
4		.3864		.5201	
5		.4161		.6241	
6		.2229		.8025	
7		.6241		.6836	
8			.9945	.5053	.8573
9	.4607	1.6271	.9945	.5053	
10	.2675		.1337		
11	.1635		.0297		
12	.1783				.1486
13	.1932		.0743		
14	.2229		.208		
15	.2378		.208		
16	.2378		.2229		
17	.2675		.2675		
18	.3864		.0297		
19	.5647	.3772	.6241		
20	.5944	.4115	.5796		
21	.3715	.4458	.4458		
22	.2972	.3429			
23	.2229	.2229			
24		.1486			
Max	.5944	1.6271	.9945	.8025	.8573
Min	.1635	.1486	.0297	.1932	.1486
Avg	.3111	.4231	.3702	.4921	.5030

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

SHIRUR(KASAR) S/DN.[802] BU 4802

Substation No/ Name :- 054013 / 33 KV RAIMOHA

Feeder No / Name : 202 / SHIRUR AG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0876		.0709	
2		.1052		.0876	
3		.124		.0876	
4		.1772		.124	
5		.2126		.2103	
6		.2279		.2804	
7		.1949		.2743	
8				.2172	.2858
9				.1646	
10	.1372		.1581		
11	.1852		.25		
12	.1981		.2429		.1387
13	.1981		.2294		
14	.1829		.1802		
15	.1677		.1581		
16	.2439		.2214		
17	.2134		.1981		
18	.1029		.1097		
19	.2103		.2195		
20	.2195		.1463		
21	.1097				
22	.1097				
23	.1063				
24		.0732			
Max	.2439	.2279	.25	.2804	.2858
Min	.1029	.0732	.1097	.0709	.1387
Avg	.1704	.1503	.1922	.1685	.2123

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

SHIRUR(KASAR) S/DN.[802] BU 4802

Substation No/ Name :- 054013 / 33 KV RAIMOHA

Feeder No / Name : 203 / 11KV KHOKARMOHA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0572		.1012	
2		.0991		.1905	
3		.1143		.1905	
4		.1429			
5		.1524		.2279	
6				.2827	
7		.3536		.2987	
8		.2881		.2241	.724
9	.1905			.2248	
10	.0533		.0476		
11	.0286		.0606		
12	.0286		.0707		
13	.0286		.0381		
14	.0229				
15	.04		.0372		
16	.0457		.0297		
17	.0381		.048		
18	.0823		.0533		
19	.0934		.0669		
20	.12		.1219		
21	.0846				
22	.08				
23	.08				
24		.048			
Max	.1905	.3536	.1219	.2987	.724
Min	.0229	.048	.0297	.1012	.724
Avg	.0678	.1570	.0574	.2176	.724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

SHIRUR(KASAR) S/DN.[802] BU 4802

Substation No/ Name :- 054013 / 33 KV RAIMOHA

Feeder No / Name : 204 / 11 KV ARVI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3696		.3696	
2		.415		.3696	
3		.4715		.3881	
4		.6602		.6584	
5		.7733		.7316	
7				.6584	
10	.5975		.4572		
11	1.1431		1.0517		
12	.9503		1.086		.7773
13	.8993		.9717		
14	.8655		.9374		
15	.8993		.9145		
16	.0225		.9145		
17	1.0679		.9374		
18	.3696		.3696		
19	.037		.924		
20	1.0349		.8871		
21	.7392				
22	.5175				
23	.462				
24		.3696			
Max	1.1431	.7733	1.086	.7316	.7773
Min	.0225	.3696	.3696	.3696	.7773
Avg	.6861	.5099	.8592	.5293	.7773

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

SHIRUR(KASAR) S/DN.[802] BU 4802

Substation No/ Name :- 054013 / 33 KV RAIMOHA

Feeder No / Name : 205 / 11 KV RAIMOHA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2686		.2561	
2		.2658		.2658	
3		.2804		.2658	
4		.3155		.3045	
5		.3506		.3898	
10	.298		.2865		
11	.3439		.3045		
12	.2658		.3258		.3361
13	.2658		.2629		
14	.2658		.2103		
15	.2658		.2629		
16	.3012		.2804		
17	.3403		.2804		
18	.2507		.3506		
19	.3582		.3506		
20	.4572		.3155		
21	.4207				
22	.2507				
23	.2507				
24		.2686			
Max	.4572	.3506	.3506	.3898	.3361
Min	.2507	.2658	.2103	.2561	.3361
Avg	.3096	.2916	.2937	.2964	.3361

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

SHIRUR(KASAR) S/DN.[802] BU 4802

Substation No/ Name :- 054013 / 33 KV RAIMOHA

Feeder No / Name : 206 / 11Kv Tagadgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5058		.4572	
2		.5525		.4496	
3		.5335		.4241	
4		.6188			
5		.6828		.6563	
6				.8535	
7		.8993		.9061	
8		.9145		.8916	1.448
9	.8535			.6893	
10	.0747		.0857		
11	.0709		.0772		
12	.0724		.1124		
13	.0743		.0857		
14	.0594		.0613		
15	.0743		.0686		
16	.0823		.0754		
17	.0823		.064		
18	.0171		.1029		
19	.0171		.1905		
20	.2		.1829		
21	.141				
22	.1587				
23	.1475				
24		.3353			
Max	.8535	.9145	.1905	.9061	1.448
Min	.0171	.3353	.0613	.4241	1.448
Avg	.1417	.6303	.1006	.6660	1.448

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

SHIRUR(KASAR) S/DN.[802] BU 4802

Substation No/ Name :- 054024 / 33/11 KV. BR. YALLAM S/S

Feeder No / Name : 201 / 11 KV SHIRUR URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.166	.0412	1.3375	.0383	.0274	1.286
2		1.1831	.0133	1.3203	.0638	.0383	1.2003
3	.0168	1.2689	.0133	1.3889	.0629	.0629	1.166
4	.0526	1.6289	.0781	1.5432	.0766	.0274	1.286
5	.1143	1.7833	.0934	1.8347	.0274	.1627	1.5432
6	.4706	2.0748		2.0748	.1627	.2315	1.8347
7	.4321	2.3148		2.2634	.2315	.5083	2.0748
8	.3292	2.2634	1.709	2.3148	.3515	.3984	1.8004
9	.1177	2.1091	.1654	1.8347	.1076	2.2119	1.7318
10	.0192	.1143			.0429	1.9547	1.6632
11	.1578	.1075			.0492	1.749	1.4575
12	1.5089						1.3717
13	1.4918						1.3203
14	1.4575					1.6632	1.2003
15	1.4232	.1086	1.749		.1132	1.5432	1.2346
16	1.406	.1076	1.8861		.0777	1.5089	1.3375
17	1.5432	.0404	1.869	.1524	.0785	1.749	1.3546
18	1.749	.0634	2.0062	.1627	.0469	1.869	1.749
19	2.1091	.262	2.2634	.2315	.164	2.2291	
20	2.2291	.0953	2.0405	.2997	.1667	2.1776	1.8861
21	1.8004	.0934	1.6289	.1166	.0793	1.749	1.6289
22	1.5432		1.5432	.017	.0895	1.5775	1.3717
23	1.3889	.0781	1.5261		.1543	1.3889	1.286
24		1.3375	.0556	1.3717	.0274	.1423	1.3375
Max	2.2291	2.3148	2.2634	2.3148	.3515	2.2291	2.0748
Min	.0168	.0404	.0133	.017	.0274	.0274	1.166
Avg	1.0172	.9100	1.0989	1.1415	.1053	1.1350	1.4836

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

SHIRUR(KASAR) S/DN.[802] BU 4802

Substation No/ Name :- 054024 / 33/11 KV. BR. YALLAM S/S

Feeder No / Name : 203 / 11 KV RALESANGAVI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.5906	.5335	.5716	.4954	.5716	.5716
2	.4763	.6478	.5335	.6859	.4954	.5335	.5335
3	.5335	.6478	.4763	.724	.4191	.5335	.5716
4	.6668	.6859	.4572	.7621	.4191	.4954	
5	.7621	.724	.5335	.8573	.5335	.4763	
6	.8383	.7621	.5716	.8954		.6097	
7	.7621	.8573	.6859	.9145		.5335	
8	.5335	.7621	.5525	.7621		.5335	
9	.4191	.724	.5525	.724	.4763		
10	.8954	1.0479			1.1431	1.105	1.0479
11	1.3717	1.105	1.2955		1.0669	1.467	1.2384
12	1.2955	.9526	1.3146	.3429	1.0479	1.0479	.9335
13	1.1812	.9907	1.0479	.362	1.0669	.9526	.9335
14	1.1241	.9145	.7621		.9526	.8954	.8954
15	1.0479	.8192	.9335		.9145	.8573	.8002
16	.9907		.8954		.9526	.8002	.7621
17	.9526		.7621	.8383	.9907	.8954	.724
18	.9335	.362	.8002	.4191		.7621	.5716
19	.7621	.5525	.8192	.4572	.6478	.8002	
20	.724	.6097	.7202	.5525	.8002	.8002	.7621
21	.6668	.6859	.703	.6859	.7621	.7621	.724
22	.6287	.6859	.6516	.5906	.6859	.724	.6859
23	.6097	.5906	.6001	.5716	.6097	.6668	.6668
24	.4954	.5716	.5525	.5144	.5144	.6097	.6097
Max	1.3717	1.105	1.3146	.9145	1.1431	1.467	1.2384
Min	.4191	.362	.4572	.3429	.4191	.4763	.5335
Avg	.7986	.7404	.7285	.6438	.7497	.7580	.7666

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

SHIRUR(KASAR) S/DN.[802] BU 4802

Substation No/ Name :- 054024 / 33/11 KV. BR. YALLAM S/S

Feeder No / Name : 205 / 11Kv sawargaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.2543	.1149	.2258	.0762	.1696	.1677
2	.1543	.3391	.1947	.2526	.0667	.1174	.1677
3	.2401	.3401	.1947	.2896		.1187	.2058
4	.3086	.4641	.2709	.3041		.2347	.2229
5	.2743	.5487	.1991	.3286		.2347	.2229
6	.2743	.6001	.2096	.3864		.3086	.2915
7	.3258	.5487	.2667	.4365		.39	.4115
8	.2229	.4115	.2328	.4214		.3772	.3353
9	.2743	.3429		.5487	.2715	.3772	.3086
10	.1029		.0667		.0497		
11	.032		.1357	.0229	.0227		
12	.048		.1174	.0229	.0227		
13	.0754		.1017	.0229	.0227		
14	.0629		.081	.0238	.0227		
15	.0754		.0838		.0227		
16	.084		.0857			.1543	.1189
17	.064		.1029			.1865	.12
18	.0774		.1372		.0442	.1543	.1372
19	.1814	.048	.2572	.048	.072	.2572	
20	.1494	.0461	.2572	.0471	.072	.2743	.2572
21	.1212	.0461	.2915	.0297	.0686	.2401	.2058
22	.1174	.0419	.2058	.0248	.0629	.2374	.2229
23	.1029	.0497	.1715	.0061	.0629	.2229	.2229
24	.1021	.2035	.1581	.1372	.0213	.0629	.1844
Max	.3258	.6001	.2915	.5487	.2715	.39	.4115
Min	.032	.0419	.0667	.0061	.0213	.0629	.1189
Avg	.1503	.2857	.1712	.1884	.0613	.2288	.2237

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

SHIRUR(KASAR) S/DN.[802] BU 4802

Substation No/ Name :- 054051 / 33 KV PIMPLNER

Feeder No / Name : 201 / PIMPALNER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0139		.8788	.9669	.4744	.4015	
2	1.0477	.467	.9126	.9991		.7727	
3	1.1816		.9453	1.1989		1.1963	
4	1.2477		.979	1.2626		1.4339	
5	1.3137		1.0117	1.3607		1.4681	
6	1.3779	1.2974		1.4255	1.122	1.5687	1.0425
7	1.3474	1.5466	1.6199	1.4089	1.4607	1.6028	1.3458
8	1.3166	1.5466	1.6424	1.5158	1.3565	1.6054	1.5398
9	1.3139	1.4413	1.6271	1.4517	1.2699	1.1788	1.2331
10	.3388	.3409		.4682	.3398	.4874	.3385
11	.189	.263			.2643		.3791
12	.2275	.225		.1886	.2829		.3012
13	.2273	.1795		.1879			.2826
14	.1886	.2513		.2275			.2815
15		.2158			.2638	.2254	.2638
16	.188	.2259		.1877	.2829	.1846	.3009
17	.1882	.2662		.2259	.2268	.2243	.2824
18	.2273	.2849		.2649	.3027	.2617	
19	.3727	.4894	.8273		.6584	.5212	.4607
20	.8436	.5228	.8148	.7537	.6024	.8224	.4049
21	.5556	.5596	.6694	.4859	.5676	.5883	.4412
22		.5249	.5963		.4966		.4775
23	.333	.4731	.5228	.3337	.4439	.362	.5504
24	.7186	.2917	.6987	.5597	.2936	.4271	.4572
Max	1.3779	1.5466	1.6424	1.5158	1.4607	1.6054	1.5398
Min	.188	.1795	.5228	.1877	.2268	.1846	.2638
Avg	.7163	.5706	.9819	.7737	.5950	.8070	.5768

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

SHIRUR(KASAR) S/DN.[802] BU 4802

Substation No/ Name :- 054051 / 33 KV PIMPLNER

Feeder No / Name : 202 / 11 KV GOMALWADA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.644		.6923	.7727	.5152	.5796	
2	.5796	.4508	.7406	.6762		.5474	
3	.6762		.7727	.644		.5635	
4	.7406		.8049	.8693		.5957	
5	.7727		.8371	.8371		.5796	
6	.8693	1.0947	.8854	.9337	1.0303	.6762	.9659
7	.9337	.8049	.6762	.9015	.8049	.7406	.8049
8	.644	.644	.644	.7727	.644	.644	.644
9	.5152	.5152	.5796		.5152	.6118	.5796
10		1.4489			1.6099	1.5455	1.4489
11		1.925			2.0929	1.9319	2.0124
12	2.0929	2.0213		2.1734	2.1251	1.8031	1.8514
13	2.3343	1.9319		2.0929	2.0124	1.6743	1.6904
14	1.9319	1.9892		1.9319	1.9319	1.6099	1.6099
15		2.0213			1.7709	1.8031	1.7065
16	1.8031	1.925	2.5758	1.9319	1.8997	1.9319	1.7709
17	2.0929		2.3343	1.8031	2.0607	1.9319	1.8514
18	2.0929	1.9319	2.1251	.4025	.483	1.8031	.9015
19	.5152	.7727	1.1269		.9337	.8371	.9337
20	1.0303	.8371	1.0464	.9659	.8049	1.0303	.8693
21	.7727	.8693	.9981	.7727	.7727	.6762	.8049
22		.8049	.8693		.6762		.7727
23	.5152	.7245	.8049	.5474	.6601	.6118	.8371
24	.8049	.5152	.644	.8371	.5152	.644	.5796
Max	2.3343	2.0213	2.5758	2.1734	2.1251	1.9319	2.0124
Min	.5152	.4508	.5796	.4025	.483	.5474	.5796
Avg	1.1181	1.2225	1.0643	1.1037	1.1929	1.1032	1.1913

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

SHIRUR(KASAR) S/DN.[802] BU 4802

Substation No/ Name :- 054054 / 33 KV KHALAPURI

Feeder No / Name : 201 / Khalapuri Agri

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7888	.2743	.7545	.7716	.5487	.2439	.1715
2	.8402	.5487	.7888	.823	.7716	.5487	.583
3	.8745	.6516	.8402	.8573	.8916	.6516	.6859
4	.9602	.7888	.7716	.8745		.823	.7888
5	1.0288	.9602	.8059	.8916	1.1145	1.0631	.8573
6	1.1831	1.166	.6173	1.0974	1.166	1.2003	1.1317
7	1.2003	1.2346	1.2689	1.2174	1.2174		1.3032
8	1.046	1.2003	1.2003		1.2174	1.2689	
9		1.1145	1.166		1.0288	.4801	1.3375
10	.2058	.3429		.2572	.2743	.3429	.2572
11		.1886		.2401	.2401	.2743	.2401
12		.1715		.2058	.2058	.2401	.2058
13	.1372	.1715		.1715	.2058	.2058	.1886
14	.2058	.1886		.1886	.2058	.1886	.1715
15	.2058	.2058		.2058	.1715	.1715	.1886
16	.1715	.2229		.1886	.1886	.2401	.2058
17	.1715	.2401	.2401	.2058	.2401	.3086	.2401
18	.3086	.3086	.3429	.2915	.2743	.3429	.3429
19	.3429	.5487		.463	.4458	.4287	
20	.3772	.4973		.4801	.4287	.4801	
21	.4115	.4115		.4115	.4115	.3772	.4458
22	.3601	.3086		.3429	.3772	.3086	.3944
23	.3086			.2743	.3429		.2572
24	.7888	.2743	.6859	.7545	.2743	.2439	.2401
Max	1.2003	1.2346	1.2689	1.2174	1.2174	1.2689	1.3375
Min	.1372	.1715	.2401	.1715	.1715	.1715	.1715
Avg	.5675	.5226	.7902	.5097	.5323	.4742	.4875

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

SHIRUR(KASAR) S/DN.[802] BU 4802

Substation No/ Name :- 054115 / manoor

Feeder No / Name : 202 / Loni

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3429	.2477	.2286
2	.3429	.2096	.2286
3	.3429	.2096	.2858
4	.4572	.2286	.2858
5	.4763	.2858	.381
6	.5716	.5144	.4763
7	.5335	.4954	.4191
8	.3048	.4191	.3239
9	.3048	.4001	.2858
10	.2477	.2858	.3429
11	.2096	.2286	.3429
12	.1905	.1905	.3429
13	.1905	.1905	.1905
14	.1905	.1905	.1905
15	.1905	.1905	.1905
16	.2096	.1905	.3429
17	1.8652	.1905	1.2696
18	2.0454	2.0119	1.4045
19	1.9393	2.0957	
20	1.7072	2.0119	1.3717
21	1.5746	1.7604	1.3717
22	1.4419	1.4737	1.386
23	1.2346	1.2136	1.386
24	1.4403	1.2041	1.2136
Max	2.0454	2.0957	1.4045
Min	.1905	.1905	.1905
Avg	.7648	.6850	.6200