

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

GANGAKHED (R) S/DN[440] BU 2330

Substation No/ Name :- 204011 / 33 KV GANGKHED S/S

Feeder No / Name : 201 / 11 KV GANGKHED TOWN 1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8215	.7655	.7762		.7392	.695	
2	.8215	.7468	.7682		.7095	.695	
3	.8589	.7842	.7682		.7468	.695	
4	1.0082	.8215	.8779		.7842	.8048	
5	1.1203	.9335	1.0242		.823	.9412	
6	1.1949	1.2567	1.1946		1.2803	1.1222	
7	1.6057	1.5546	1.4327		1.4998	1.3969	
8	1.643	1.5364	1.576		1.4815	1.5402	
9	1.3756	1.5912	1.5912	1.3969	1.4266	1.4937	1.4998
10	1.267	1.4632	1.4632	1.2536	1.3169	1.3443	1.2437
11	1.134	1.262	1.2752	1.1462	1.2071	1.2323	1.1888
12	1.0974	1.2437	1.2437	1.1104	1.1706	1.0456	1.1584
13	1.0974		1.1706	1.0745	1.1222	.9709	1.0425
14	1.086		1.0242	1.0029	1.1041	.9335	.9877
15	1.086		1.0242	1.086	1.0608	.8215	1.0608
16	1.1222		1.1157	1.1104	1.0974	.8215	1.0974
17	1.1706	1.0745	1.1584	1.0608	1.1104	.8962	1.1203
18	1.3352	1.182	1.1946	1.2308	1.0745	1.0456	1.1949
19	1.4083	1.448	1.2308	1.3352	1.182	1.1203	1.2696
20	1.3169	1.3169	1.1584	1.2437	1.1104	1.1949	1.307
21	1.1706	1.2071		1.0974	.9774	1.0456	1.1203
22	1.0349	1.0974		.9511	.905	.9335	.9335
23	.9335	.8413		.9335	.8048	.7842	.8215
24	.8215	.7842	.7682		.7316	.695	.7095
Max	1.643	1.5912	1.5912	1.3969	1.4998	1.5402	1.4998
Min	.8215	.7468	.7682	.9335	.7095	.695	.7095
Avg	1.1471	1.1455	1.1351	1.1356	1.0611	1.0112	1.1097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

GANGAKHED (R) S/DN[440] BU 2330

Substation No/ Name :- 204011 / 33 KV GANGKHED S/S

Feeder No / Name : 202 / 11 KV GANGKHED TOWN 2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5975	.5601	.5487		.5304	.4755	
2	.5975	.5601	.5544		.5788	.4755	
3	.5975	.5975	.5487		.6161	.4755	
4	.5975	.6348	.6219		.6348	.5487	
5	.7468	.7468	.7682		.7095	.695	
6	.9335	.9979	.905		1.0059	.7964	
7	1.1203	1.2803	1.0631		1.2071	1.0029	
8	1.1203	1.2071	1.182		1.2803	1.0745	
9	1.086	1.134	1.1576	1.0029	1.134	1.0829	.9511
10	.9145	.9145	.9145	.8954	.9511	1.0082	.7865
11	.8413	.7865	.7865	.788	.8779	.9335	.7682
12	.7316	.7133	.7133	.724	.8145	.8589	.7682
13	.6283		.6767	.6878	.7682	.7842	.7682
14	.695		.6036	.6154	.7316	.7468	.7316
15	.6154		.5853	.5792	.724	.6348	.695
16	.6154		.6219	.5792	.8326	.5601	.695
17	.7316	.6878	.6878	.7421	.8238	.7095	.7468
18	.9145	.7964	.724	.7316	.8238	.7468	.8215
19	.9694	.9412	.7964	.9877	.8954	.7842	.8999
20	.9511	.905	.8688	.8779	.7164	.8215	.9709
21	.8779	.8048		.7577	.6878	.7468	.7468
22	.7577	.7316		.6584	.6154	.6722	.6722
23	.7095	.6219		.6283	.5487	.5601	.6348
24	.5975	.5975	.5544		.5415	.5487	.4481
Max	1.1203	1.2803	1.182	1.0029	1.2803	1.0829	.9709
Min	.5975	.5601	.5487	.5792	.5304	.4755	.4481
Avg	.7895	.8110	.7563	.7504	.7937	.7393	.7566

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

GANGAKHED (R) S/DN[440] BU 2330

Substation No/ Name :- 204011 / 33 KV GANGKHED S/S

Feeder No / Name : 203 / 11 KV MOSICAL

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5947	2.0683	1.9631		1.701	1.701	
2	1.7909	2.1735	2.1616		1.7177	1.701	
3	2.1491	2.2611	2.1971		1.7528	1.8073	
4	2.3034	2.3487	2.1262		1.7878	2.0553	
5	2.4539	2.4188	2.1971		1.8229	2.2325	
6	2.6642	2.7168	2.3137		2.1735	2.5591	
7	3.155	3.12	2.6353		2.6467	2.878	
8	3.2251	3.3303	2.8464		2.5415	3.1893	
9	3.3608	2.6993	2.6993	2.6353	2.6642	3.0445	2.5766
10	2.878	2.5766	2.5766	2.6063	2.7168	2.5072	2.3137
17	1.2269	1.2757	1.4022	1.3112	1.379	1.2437	1.086
18	1.4373	1.4175	1.4723	1.2269	1.4883	1.448	1.1222
19	1.7177	1.5947	1.4529	1.3321	1.4373	1.4842	1.1462
20	1.5592	1.5592	1.4022	1.1999	1.3466	1.448	1.1946
21	1.4352	1.382		1.1283	1.3112	1.3032	1.086
22	1.3466	1.2757		1.0498	1.1694	1.2308	1.0136
23	1.2178	1.134		.985	1.0985	1.1584	.9774
24	1.1584	1.182	1.0387		.9412	.9671	1.0136
Max	3.3608	3.3303	2.8464	2.6353	2.7168	3.1893	2.5766
Min	1.1584	1.134	1.0387	.985	.9412	.9671	.9774
Avg	2.0375	2.0297	2.0323	1.4972	1.7609	1.8866	1.3530

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

GANGAKHED (R) S/DN[440] BU 2330

Substation No/ Name :- 204011 / 33 KV GANGKHED S/S

Feeder No / Name : 204 / 11 KV KODRI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5731	.6268	.5373		.5731	.5373	
2	.5792	.6556	.5373		.6089	.5373	
3	.5792	.7316	.6805		.6516	.6024	
4	.6154	.7783	.7442		.7316	.7087	
11	2.0332	1.893	1.893	1.9418	2.822	2.8959	2.2085
12	2.1845	1.9806	1.9806	1.9631	3.3653	3.2579	1.893
13	2.5312		2.1033	1.8031	3.5231	3.2236	2.489
14	2.3579		1.8229	1.8031	2.8433	3.2156	2.6642
15	2.1845		1.8755	1.8031	3.1034	3.0769	2.5766
16	2.1845		1.893	1.7684	3.4705	2.8654	2.7519
17	2.2977	2.2977	1.9071		3.1379	2.9012	2.8654
18	2.191	2.1605	1.8378	2.2192	2.7778	2.8654	2.5072
19	1.1517	2.1948	.7796	2.1033	2.6406	.7964	2.4714
20	.9816	2.0805	.7442	1.0745	2.6006	.7762	2.3891
21	.8859	.8859		.9412	.788	.724	.724
22	.7265	.7087		.7682	.7087	.695	.543
23	.6626	.6805		.6697	.6089	.5792	.5068
24	.5792	.6219	.6089		.5792	.5731	.439
Max	2.5312	2.2977	2.1033	2.2192	3.5231	3.2579	2.8654
Min	.5731	.6219	.5373	.6697	.5731	.5373	.439
Avg	1.4055	1.3069	1.3297	1.5716	1.9741	1.7129	1.9307

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

GANGAKHED (R) S/DN[440] BU 2330

Substation No/ Name :- 204011 / 33 KV GANGKHED S/S

Feeder No / Name : 206 / 11 KV RAILWAY STATION

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7842	.7282	.7316		.7392	.6219	
2	.7842	.7095	.7316		.7655	.6219	
3	.7842	.7468	.7316		.7762	.6219	
4	.9335	.8029	.8413		.7762	.7316	
5	1.1203	.9149	1.0498		.8131	.9412	
6	1.1949	1.2696	1.267		1.2803	1.1946	
7	1.4937	1.6244	1.4327		1.4815	1.3253	
8	1.6804	1.5729	1.5043		1.4266	1.4327	
9	1.448	1.6095	1.6095	1.3253	1.39	1.3817	1.4632
10	1.267	1.4632	1.4632	1.2536	1.2437	1.307	1.3352
11	1.1706	1.3169	1.3169	1.182	1.3169	1.2323	1.1157
12	1.0974	1.1888	1.1888	1.0745	1.267	1.1203	1.1041
13	1.0242		1.1523	.9412	1.134	1.0082	.9877
14	.9412		.9511	.8326	1.0242	.9335	.9511
15	1.0136		.9412	.8688	1.0242	.8215	.9511
16	1.0136		1.0059	.8688	1.0974	.8029	1.0242
17	1.2254	1.1104	1.0136	1.1706	1.1462	1.0082	1.1203
18	1.3169	1.182	1.0498	1.2803	1.1462	1.1949	1.3443
19	1.5546	1.4118	1.1222	1.39	1.2536	1.2323	1.307
20	1.3169	1.267	1.1584	1.2986	1.0745	1.1203	1.307
21	1.2071	1.2071		1.1827	.9412	1.0082	1.1203
22	1.0164	1.0974		.9511	.8326	.7842	.9709
23	.9522	.8413		.8962	.7316	.7468	.7468
24	.7842	.7655	.7316		.7499	.7316	.6722
Max	1.6804	1.6244	1.6095	1.39	1.4815	1.4327	1.4632
Min	.7842	.7095	.7316	.8326	.7316	.6219	.6722
Avg	1.1302	1.1415	1.0950	1.1011	1.0597	.9969	1.0951

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

GANGAKHED (R) S/DN[440] BU 2330

Substation No/ Name :- 204011 / 33 KV GANGKHED S/S

Feeder No / Name : 207 / 11 kv Prasd Fiber

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.1494	.1478		.1494	.0747	
2	.128	.1494	.1478		.1478	.0747	
3	.128	.1494	.1478		.1463	.0747	
4	.1294	.0914	.1478		.1463	.0747	
5	.1294	.0914	.1109		.1463	.0747	
6	.1294	.0905	.1478		2.1735	.0739	
7	.1478	.0876	.1463		.0914	.0732	
8	.0924	.0701	.0732		.0857	.0732	
9	.0739	.1402	.1463	.1463	.1829	.0543	.0732
10	.0739	.1448	.1463	.1463	.1753	.0554	.168
11	.0739	.1448	.1448	.1463	.1463	.0549	.1494
12	.0739	.1448	.1463	.1463	.1402	.0543	.1494
13	.0739		.1463	.1097	.1448	.0549	.1463
14	.0739		.0895	.1097	.1448	.0362	.1463
15	.0739		.0701	.1097	.1448	.0366	.1494
16	.0739		.0709	.1463	.0716	.0366	.1478
17	.0686	.0739	.0739	.1433	.0732	.0358	.1463
18	.0686	.0732	.0732	.0867	.0732	.0366	.1463
19	.0857	.037	.0732	.0857	.0732	.0366	.1463
20	.0857	.037	.0732	.1578	.0732	.0366	.1463
21	.0857	.0373		.1629	.037	.0366	.1463
22	.0857	.1478		.1646	.0739	.0366	.1463
23	.0857	.1478		.1646	.0739	.0366	.1463
24	.0914	.1494	.1494		.1448	.0747	.0366
Max	.1478	.1494	.1494	.1646	2.1735	.0747	.168
Min	.0686	.037	.0701	.0857	.037	.0358	.0366
Avg	.0927	.1079	.1178	.1351	.2025	.0545	.1369

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

GANGAKHED (R) S/DN[440] BU 2330

Substation No/ Name :- 204011 / 33 KV GANGKHED S/S

Feeder No / Name : 208 / 11KV Water works Express NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1646	.181	.1478		.2126	.0373	
2	.1663	.2126	.1494		.1448	.0373	
3	.1663	.1829	.1478		.1448	.0373	
4	.1646	.1848	.2218		.0549	.0373	
5	.1663	.1829	.2218		.0537	.1478	
6	.1663	.1829	.2195		.2012	.1478	
7	.2218	.2561	.2195		.2378	.2195	
8	.1848	.2172	.2195		.2328	.2195	
9	.2218	.2195	.2195	.3292	.2195	.2218	.197
10	.2218	.2195	.2195	.2195	.2149	.2218	.1829
11	.2218	.2195	.2195	.1829	.2353	.2195	.2195
12	.1478	.3109	.3142	.4344	.2353	.2195	.2195
13	.1478		.2195	.3292	.2149	.1478	.2195
14	.1463		.1448	.2896	.2195	.1478	.2012
15	.1463		.2926	.2926	.2126	.1463	.2012
16	.1463		.2896	.2926	.2149	.1463	.2012
17	.1595	.1463	.2587	.2865	.2195	.1097	.2195
18	.1227	.1463	.2561	.1595	.1463	.1097	.1463
19	.1543	.1848	.2743	.1578	.1463	.1097	.1463
20	.2058	.2218	.2926	.1578	.2195	.112	.1494
21	.2103	.2218		.2378	.2218	.1829	.1463
22	.2058	.2218		.2353	.1848	.1829	.1463
23	.2103	.1478		.2195	.1848	.1829	.2012
24	.1646	.1715	.1478			.0373	.1829
Max	.2218	.3109	.3142	.4344	.2378	.2218	.2195
Min	.1227	.1463	.1448	.1578	.0537	.0373	.1463
Avg	.1764	.2016	.2236	.2549	.1901	.1409	.1863

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

GANGAKHED (R) S/DN[440] BU 2330

Substation No/ Name :- 204095 / 33 KV ISSAD S/S

Feeder No / Name : 201 / Issad

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.491	1.3599	1.3125	1.3432	1.4045	.8215	.9055
2	1.6244		1.4419	1.5223	1.4864	.8779	1.0242
3	.4012		1.6095	1.829	1.7558	.9313	1.1706
4	1.9839		1.9669	2.0683	1.749	1.0277	1.2536
5	2.2119	2.5377	2.0978	2.2291	2.2436		
6	2.4348		2.4188	2.489	2.4539		
7	3.034		2.5591	2.6932	2.758		
8	3.1727		3.12	2.9235	2.982		
9	3.2594		2.7949	2.6063	2.6749		
10	2.7606	2.7778	2.5774	2.3834	2.6873		
11						2.5415	
12						2.8953	
13						2.1948	
14						2.6113	
15						2.6282	
16						2.6621	
17						2.7808	
19	1.4045	1.4563	1.5123	.9875	1.3256		
20		1.2449	1.2883	1.251	1.1694		
21		1.1128	1.0829	1.226	1.0082		
22		.9997	.9335	1.0185	.8962		
23	.9054	.8865	.8589	.8865	.8589		
24	.8865	.8299	.7922	.8029	.8299	.7842	.8686
Max	3.2594	2.7778	3.12	2.9235	2.982	2.8953	1.2536
Min	.4012	.8299	.7922	.8029	.8299	.7842	.8686
Avg	1.9669	1.4673	1.7729	1.7662	1.7677	1.8964	1.0445

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

GANGAKHED (R) S/DN[440] BU 2330

Substation No/ Name :- 204095 / 33 KV ISSAD S/S

Feeder No / Name : 202 / limbewadi

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3521	.3963	.631	.5144	.463	.8916	.8993
2	.3462		.583	.5609	.5316	1.2498	1.1873
3	.4012		.5344	.6661	.567	1.531	1.4243
4	.506		.5312	.7164	.591	1.6324	1.5402
5						2.0481	1.7124
6						2.2119	2.2024
7						1.8778	2.5774
8						2.4577	2.7831
9						2.6216	2.6852
10						2.2672	2.4615
11	2.0325	2.3868	2.0481	1.5181	2.0885		
12	2.3758		2.4291	2.3805	2.6246		
13			2.3685	2.3365	2.7035		
14			2.3644	1.7185	2.652		
15		2.8502	2.2771	1.9925	2.4863		
16			2.2297	2.1285	2.6189		
17	2.6379		2.0934	2.17	2.5484	.4161	
18	2.372		2.0881	2.2497	2.6246		
19	.5556	.4833	.8356	.5937	.5716		
20		.9412	.578	.6348	.4534		
21		.8326	.5312	.6036	.3319		
22		.8139	.4801	.5658	.3334		
23	.3841	.6344	.4801	.5281	.3567		
24	.3517	.3715	.8192	.4527	.4904	.3765	.431
Max	2.6379	2.8502	2.4291	2.3805	2.7035	2.6216	2.7831
Min	.3462	.3715	.4801	.4527	.3319	.3765	.431
Avg	1.1196	1.0789	1.3279	1.2406	1.3909	1.6318	1.8095

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

GANGAKHED (R) S/DN[440] BU 2330

Substation No/ Name :- 204096 / 33 KV MAHATPURI S/S

Feeder No / Name : 201 / Mahatpuri gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1867	.1646	.1829	.168	.1867	.2195
2	.168	.1867	.1829	.2561	.168	.1867	.2561
3	.1867	.2241	.2195	.2926	.1867	.1867	.3109
4	.2241	.3361	.2195	.3511	.2054	.2614	.3475
5		.4481	.5121	.4435	.2801	.3361	.3658
6		.5228	.6036	.499	.4668	.4481	.439
7		.5975	.7133	.5729	.5975	.5853	.499
8	.567	.5853	.6036	.6283	.6535	.5853	.5544
9	.4755	.5228		.5175	.5228	.5487	.4938
10	.2801	.3658	.4163	.4066	.4854	.439	.3292
11	.2614	.2378	.3077	.2614	.3734	.3475	.2195
12	.1867	.1829	.2561	.2012	.2987	.2926	.2012
13	.168	.1829	.2012	.1663	.3361	.2561	.2012
14	.168	.1646	.1646	.1829	.3734	.2561	
15	.1867	.1646	.1086	.1829	.3921	.2195	
16	.2241	.2561	.1646	.2218	.4481	.2743	.2195
17	.2614	.3292	.2012	.2957	.4668	.3292	.2561
18	.3361	.3658	.2561	.4572	.4755	.3658	.3292
19	.4481	.4938	.3292	.4435	.4481	.4435	.3475
20	.4108	.3658	.4024	.3292	.3734	.3475	.3841
21	.2987	.2561	.2957	.2587	.2987	.2926	.3292
22	.2614	.2012	.2218	.2012	.2614	.2743	.2743
23		.1829	.1829	.2241	.2241	.2195	.2012
24	.1829	.1867	.1646	.1448	.2054	.1867	.1829
Max	.567	.5975	.7133	.6283	.6535	.5853	.5544
Min	.168	.1646	.1086	.1448	.168	.1867	.1829
Avg	.2741	.3144	.2997	.3217	.3629	.3279	.3164

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

GANGAKHED (R) S/DN[440] BU 2330

Substation No/ Name :- 204096 / 33 KV MAHATPURI S/S

Feeder No / Name : 202 / Khali Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.2987	.2561	.3696	.2801	.8573	1.3169
2	.2641	.2987	.3292	.4251	.2801	.9259	1.4415
3	.2829	.3361	.3658	.499	.2614	1.0288	1.5339
4	.3921	.4108	.4024	.5175	.3734	1.0631	1.6078
5						1.1065	1.6632
6						1.1736	1.7372
7						1.4083	1.8298
8						1.4083	1.6448
9						1.3748	1.7551
10						1.3413	1.6991
11	1.6095	1.7833	1.0608	1.7926	1.4419		
12	1.7436	1.8176	1.6448	1.7551	1.4419		
13		1.8519	1.7741	1.7013	1.6766		
14		1.7604	1.9044	1.7193	1.7436		
15		1.8107	2.0328	1.7737	1.6766		
16	1.7772	1.7604	1.922	1.7187	1.7436		
17	1.7772	1.8442	1.8111	1.7541	1.6766	.2772	.2012
18	1.7436	1.7772	1.9418	1.9404	1.643	.3109	.2743
19	1.6766	.4755	.2033	.3841	.4854	.3292	.3292
20	1.5089	.439	.2772	.3582	.4108	.3109	.3881
21	.4481	.3658	.3142	.3547	.3361	.3658	.3292
22	.4108	.3475	.3326		.2987	.3292	.2926
23		.2561	.3142	.3077	.2987	.3109	.2743
24	.2896	.3361	.2561	.3511	.2987	.2987	.2561
Max	1.7772	1.8519	2.0328	1.9404	1.7436	1.4083	1.8298
Min	.2641	.2561	.2033	.3077	.2614	.2772	.2012
Avg	1.0148	.9983	.9524	1.0425	.9093	.7900	1.0319

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

GANGAKHED (R) S/DN[440] BU 2330

Substation No/ Name :- 204096 / 33 KV MAHATPURI S/S

Feeder No / Name : 203 / Mahatpuri Ag

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8442	1.8442	2.0287	2.1068	1.2346	1.0456	1.0791
2	2.0957	2.0119	2.0287	2.347	1.2574	1.0456	1.1706
3	2.1125	2.1795	2.079	2.5503	1.291	1.1203	1.2936
4	2.2634	2.5149	2.0957	2.7536	1.3748	1.3443	1.4415
5	2.431	2.6825	3.1855	3.062	1.4251		
6		2.7831	3.6035	3.3234	1.5927		
7		2.8502	3.7342	3.6222	1.7604		
8	3.2236	3.0849	3.81	3.7723	2.0287		
11				.1494		1.8111	
12						2.5318	
13						2.7905	1.4632
14						3.2895	
15	.9709	.8962	.8779		1.1203	3.3981	
16	1.1203	.9991	.9877	1.0242	1.1949	2.7166	1.3306
17	1.2323	1.0867	1.134	1.134	1.2323	2.1622	1.6095
18	1.2696	1.1744	1.2012	1.262	1.4266	2.1253	1.7372
19	1.531	1.4373	1.3676	1.4998	1.6057	1.0719	1.9774
20	1.3817	1.2445	1.2567	1.267	1.3443	1.2197	2.4209
21	1.2323	1.1641	1.1827	1.1458	1.2323	1.2936	.8779
22	1.1203	1.1393	1.1458	1.0059	1.1203	1.1458	.9425
23		1.7101	1.5524	1.1041	1.0829	1.0534	.9979
24	1.8804	1.576	1.9951	2.1068	1.2136	1.0456	.9425
Max	3.2236	3.0849	3.81	3.7723	2.0287	3.3981	2.4209
Min	.9709	.8962	.8779	.1494	1.0829	1.0456	.8779
Avg	1.7139	1.7988	1.9592	1.9576	1.3632	1.7895	1.3775

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

GANGAKHED (R) S/DN[440] BU 2330

Substation No/ Name :- 204097 / 33 KV MIDC S/S GANGAKHED

Feeder No / Name : 201 / 11 KV NEW TOWN GANGAKHED SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9412	.924	.924	.8688	.8871	.8316	.8507
2	.9412	.924	.924	.8688	.8871	.8316	.8507
3	.9412	.924	.924	.8688	.8871	.8316	.8507
4	.9955	.9979	1.0164	.905	.961	1.0164	.905
5	1.3575	1.4784	1.4784	1.3575	1.1827	1.2012	1.267
6	2.0814	2.0698	2.1253	1.8099	1.6263	1.4784	1.7194
7	2.4434		2.3101	2.2986	2.0513	1.7556	2.0814
8	2.3529	2.5503	2.4025	2.1538	2.1807	1.9404	2.2262
9	2.0633	1.9404	2.0328	1.8823	2.2177	1.848	1.9728
10	1.9004	1.7556	1.6632	1.5927	1.848	1.848	1.7375
11	1.4784	1.5708	1.386	1.3491	1.4784	1.7556	1.6289
12	1.3676	1.2012	1.3575	1.0903	1.4784	1.5339	1.1765
13	1.1458	1.0164	1.1765	.9795	1.2936	1.2567	1.0317
14	1.1458	.924	.9774	.961	1.2012	1.1827	1.0317
15	1.1458	.9955	1.0136	.961		1.1088	.9593
16	1.1458	1.1088	1.0498	1.0349	1.386	1.0719	1.0498
17	1.2752	1.2012	1.3032	1.1827	1.4784	1.1088	1.1222
18	1.423	1.386	1.4118	1.2936	1.4784	1.386	1.3394
19	1.6078	1.6632	1.7918	1.7002	1.2936	1.5708	1.3756
20	1.7002	1.5708	1.4661	1.6263	1.2012	1.386	1.4842
21	1.2382	1.2936	1.2936	1.2567	1.1088	1.1088	1.1765
22	1.1273	1.1088	1.1458	1.1088	1.0164	1.0349	.9955
23	1.0349	.924	1.0164	.961	.924	.9795	.905
24	.9955	.9979	.924	.961	.924	.8316	.924
Max	2.4434	2.5503	2.4025	2.2986	2.2177	1.9404	2.2262
Min	.9412	.924	.924	.8688	.8871	.8316	.8507
Avg	1.4104	1.3272	1.3798	1.2947	1.3475	1.2875	1.2776

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

GANGAKHED (R) S/DN[440] BU 2330

Substation No/ Name :- 204097 / 33 KV MIDC S/S GANGAKHED

Feeder No / Name : 202 / 11 KV MARGALWADI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.7716	.7716	.463	.4801	.6001	.6859
2	.6859	.7716	.7716	.463	.4801	.6001	.6859
3	.6859	.7716	.7716	.463	.463	.6001	.6859
4	.7545	.7888	.7716	.4973	.4973	.6001	.7202
5	.8573	.823	.823	.5658	.5487	.6859	.7716
6	.9431	.8916	.8573	.6859	.6344	.7716	.8573
7	1.0117	.9431	.9431	.823	.7888	.7716	.9088
8	1.1145	1.0974	.9431	.7716	.8916	.9431	.9602
9	1.0631	1.0974	.9431	.8059	.8402	.9431	.9945
10	.9945	1.0631	.9431	.7716	.823	.9431	1.0288
11	1.0117	1.0288	.8573	.7202	.823	1.0288	.9602
12	.9774	.8573	.8573	.7202	.7716	1.0974	.9774
13	.9774	.9088	.8573	.5316	.8573	1.0631	.8573
14	1.0288	.8573	.6173	.6001	.9431	1.0288	.8573
15	1.0288	.8573	.6859	.6001		.9774	.8402
16	.9945	.823	.7202	.6344	.9431	.9431	.823
17	.9774	.823	.7716	.7373	.9431	.9774	.8573
18	1.0117	.8573	.7888	.7545	.9431	1.0288	.823
19	.9259	.9431	.7545	.7716	.8573	.9431	.8059
20	.9431	.823	.7888	.7373	.8573	.9088	.8059
21	.8573	.8573	.6516	.6516	.7716	.8059	.7716
22	.823	.7716	.6001	.6344	.6859	.7545	.6859
23	.7888	.7716	.5658	.5487	.6859	.7202	.6859
24	.7545	.7888	.7716	.5144	.5316	.6001	.7202
Max	1.1145	1.0974	.9431	.823	.9431	1.0974	1.0288
Min	.6859	.7716	.5658	.463	.463	.6001	.6859
Avg	.9124	.8745	.7845	.6444	.7418	.8473	.8238

From 08-MAR-17 and 14-MAR-17

Feeder No / Name : 201 / Itoli Feeder (single
Phasing Feeder KV- 11 /
OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	2.2862	1.9052	1.7147	2.191	1.7147	2.2481
2	1.6956	2.2862	1.9052	1.9052	2.2862	1.6766	2.3243
3	1.5242	2.2862	.7621	2.0005	2.2862	1.7528	2.6292
4	.7621	.7621	.7621	.5716	.4763	.5716	.4382
5	.8573	.8573		.6668	.5716	.6097	.4763
6	.8573	.7621	.7621	.7621	.6668	.6097	.6859
10	2.2862	2.4387	2.3815	2.3815	2.6673	1.8099	1.9052
11	2.8578	2.4577	2.191	2.4768	2.8578	1.9433	2.0957
12		2.4387	2.2862	2.6673	2.8959	1.9624	2.0957
13	2.7625	2.3815	2.3243	2.572	2.6673	1.9052	1.9052
14	2.6673	2.2862	2.191	2.4768	2.4768	1.9052	2.0005
15	2.7625	2.2481	2.4768	2.572	2.572	1.5623	1.9052
16	2.8578	2.2481	2.5149	2.3815	2.4768	1.5242	2.0005
17	2.6673	2.2862	2.572	2.3815	2.572	1.5242	2.0957
18	2.191	1.9433	2.0957	2.191	2.0957	3.0102	2.9531
19	2.2862	2.0005	2.0005	2.2862	2.0957	2.8578	2.8578
20	2.4768	2.0957		2.2862		2.4958	2.8578
21	2.2862	1.9052	1.7147	2.191	2.0005	2.2862	2.7625
22	2.2862	1.7147	1.8099	2.191	1.9052	2.2862	2.7625
23	2.3815	1.9052		2.2862	1.7147	2.2481	2.6673
24	1.9052	2.3815	1.9052	1.8099	2.4768	1.7147	2.2481
Max	2.8578	2.4577	2.572	2.6673	2.8959	3.0102	2.9531
Min	.7621	.7621	.7621	.5716	.4763	.5716	.4382
Avg	2.1043	1.9986	1.9200	2.0368	2.0976	1.8081	2.0912

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

JINTUR (R) S/DN[452] BU 2372

Substation No/ Name :- 204010 / 33/11KV Itoli Sub-station

Feeder No / Name : 202 / Digras Feeder (Single SINGLE PHASING
Phasing Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.33	.33	.412	.396	.4125	.363	2.3099
2	.33	.4125	.412	.4125	.4125	.528	2.2274
3	.4125	.33	.3296	.495		.5775	2.2274
4	.4125	.4125	.412	.5775	.495	.594	.3135
5	.4125	.4125	.412	.594	.495	.6105	.3465
6	.396	.5775	.4614	.6105	.5775	.594	.3795
10	2.1449	1.9469	2.5544	2.2274	2.2274	.429	.33
11	2.0624	2.0624	2.06	2.0624	2.3429	.33	.2475
12		2.0954	1.9799	2.0624	2.4584	.264	.2475
13	2.2274	1.8479	1.9964	2.0624	2.6728	.264	.2475
14	2.3099	2.1449	2.0624	2.1449	2.5079	.2475	.2475
15		2.3924	2.1119	2.1449			.33
16	2.2274	2.1944	2.1449	2.1449	2.4749	.264	
17	2.3924	2.2769	2.1779	2.1449	2.5409	.33	.33
18	.412	.3135	.297	.4125		2.5738	2.4749
19	.4944	.33	.4125	.5775	.495	2.4914	2.4749
20	.4125	.33		.495		2.3924	2.5573
21		.3296	.396	.495	.528	2.3759	2.4749
22	.4125	.3296	.429	.495	.429	2.3924	2.3924
23	.495	.3296	.363	.495	.396	2.4419	2.3924
24	.3445	.495	.412	.363	.4125	.363	2.4254
Max	2.3924	2.3924	2.5544	2.2274	2.6728	2.5738	2.5573
Min	.33	.3135	.297	.363	.396	.2475	.2475
Avg	1.0127	1.0425	1.0918	1.1149	1.2870	1.0213	1.3488

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

JINTUR (R) S/DN[452] BU 2372

Substation No/ Name :- 204010 / 33/11KV Itoli Sub-station

Feeder No / Name : 203 / Gadad-Gavhan Feeder (SINGLE PHASING
 Single P Feeder KV- 11 /
 OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7557	3.014	3.1341	2.9624	2.9279	2.6179	.3617
2	2.7557	2.7557	3.1001	3.1863	2.9279	2.7557	.3789
3	2.7557	2.6696	.5167	3.1863	2.7557	2.8418	.3789
4	.6889	.6028	.4478	.6028	.3445	.5511	.3789
5	.4822	.6028	.4306	.6889	.4306	.6028	.3961
6	.4822	.5167	.4306	.7234	.5167	.62	.4478
10	.3445	.2928	.4306	.6028	.1722	2.7901	2.4629
11	.2583	.2756	.2756	.1722	.2239	2.8935	2.5835
12		.3048	.2239	.2583	.2411	2.7729	2.7557
13	.2583	.2583	.2411	.2583	.2756	3.0483	2.5835
14	.2583	.2756	.2067	.3445	.3445	2.7729	2.4973
15	.2583	.2756	.2411	.3445		2.8418	2.5835
16	.2583	.2583	.2756		.4478	2.6868	2.6696
17	.3445	.2928	.31	.4306	.4478	2.6351	2.7557
18	3.1792	2.704	3.1863	2.9279	3.1346	.3789	.3445
19	3.0933	2.8418	3.2551	3.3585	2.9279	.3445	.4306
20	3.1863	2.9279		3.1001		.3789	.4306
21		3.1001	3.1001	3.1001	2.6868	.3961	.4306
22	3.1001		3.1001	3.1863	2.5835	.3961	.3445
23	3.1001	3.1001	3.014	3.1001	2.4973	.3789	.3445
24	2.7557	2.9279	3.014	2.9279	3.014	2.5835	.3617
Max	3.1863	3.1001	3.2551	3.3585	3.1346	3.0483	2.7557
Min	.2583	.2583	.2067	.1722	.1722	.3445	.3445
Avg	1.5956	1.4999	1.4467	1.7731	1.5211	1.7756	1.2343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

JINTUR (R) S/DN[452] BU 2372

Substation No/ Name :- 204022 / 33/11 KV BORI S/STN

Feeder No / Name : 204 / Bori Gaothan Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17
HR	Load (MW)
19	1.0288
20	1.0288
21	.8573
22	.8573
23	.6335
24	.9326
Max	1.0288
Min	.6335
Avg	.8897

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

JINTUR (R) S/DN[452] BU 2372

Substation No/ Name :- 204033 / 33/11 Kv Yeldari -Sawangi

(Mha

Feeder No / Name : 201 / Yeldari AG feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17
HR	Load (MW)
9	1.3003
10	1.3413
11	1.3565
12	1.3717
13	1.3565
14	1.3717
15	1.3413
16	1.3717
Max	1.3717
Min	1.3003
Avg	1.3514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

JINTUR (R) S/DN[452] BU 2372

Substation No/ Name :- 204033 / 33/11 Kv Yeldari -Sawangi

(Mha

Feeder No / Name : 202 / Sawali AG feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17
HR	Load (MW)
1	2.2148
2	2.2386
3	2.3282
4	2.4177
5	2.5072
6	2.2386
7	2.2386
8	2.2624
9	1.0536
10	1.0536
11	.8916
12	.8688
13	.8802
14	.7964
16	1.2793
17	2.13
18	2.2634
19	2.2891
24	1.9433
Max	2.5072
Min	.7964
Avg	1.7840

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

JINTUR (R) S/DN[452] BU 2372

Substation No/ Name :- 204033 / 33/11 Kv Yeldari -Sawangi

(Mha

Feeder No / Name : 203 / Yeldari Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17
HR	Load (MW)
1	.1848
2	.1848
3	.1848
4	.2772
5	.3696
6	.6468
7	.924
8	.8316
10	.8316
11	.5544
12	.462
13	.3696
14	.2772
15	.3696
16	.3696
17	.462
18	.5544
19	.6468
24	.2772
Max	.924
Min	.1848
Avg	.462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

JINTUR (R) S/DN[452] BU 2372

Substation No/ Name :- 204043 / 33/11 Kv Charthana S/s.

Feeder No / Name : 202 / CHARTHANA AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17
HR	Load (MW)
15	1.7372
18	.5415
19	.5601
20	.5544
21	.5914
Max	1.7372
Min	.5415
Avg	.7969

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

JINTUR (R) S/DN[452] BU 2372

Substation No/ Name :- 204043 / 33/11 Kv Charthana S/s.

Feeder No / Name : 203 / CHARTHANA GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING GAOTHAN FEEDER

DATE	08-MAR-17
HR	Load (MW)
17	1.2566
18	.7655
19	.7282
20	.6653
21	.5914
Max	1.2566
Min	.5914
Avg	.8014

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

JINTUR (R) S/DN[452] BU 2372

Substation No/ Name :- 204043 / 33/11 Kv Charthana S/s.

Feeder No / Name : 204 / PIMPARI AG FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	08-MAR-17
HR	Load (MW)
15	.7095
Max	.7095
Min	.7095
Avg	.7095

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

JINTUR (R) S/DN[452] BU 2372

Substation No/ Name :- 204053 / 33 /11 KV JINTUR

Feeder No / Name : 201 / 11KV Nimgiri

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2803	1.3717	1.2803	1.2803		
2	1.2803	1.2803	1.2803	1.2803		
3	1.2803	1.2803	1.2803	1.2803		
4		1.3717	1.2803	1.2803		
5	1.4632	1.5546	1.5546	1.2803		
6	2.0119	2.0119	2.1033	1.829		
7	2.4691	2.5606	2.8349	2.5606		
8	2.4691	2.2862	2.5606	2.1948		
9	2.2862	2.1033	2.5606	2.0119	2.2862	
10	2.0119	1.829	2.5606	1.829	2.0119	
11	1.6461	1.6461	2.3777	1.6461	1.829	
12	1.6461	1.5546	1.7261	1.5546	1.7375	
13	3.1092	1.4632	3.2922	1.4632	1.7375	
14	1.4632	1.4632	1.4632	1.4632	1.6461	
15	1.4632	1.4632	1.5546	1.5546	1.6461	
16	1.4632	1.2803	1.5546	1.5546	1.6461	1.4632
17		1.4632				1.6461
18	2.0119	2.0119				1.829
19	2.1948	1.829				1.829
20	1.829	1.6461				1.5535
21	1.6461	1.4632				1.5546
22	1.5546	1.4632				
23	1.4632	1.3717				
24	1.2803	1.4146	1.2803	1.2803		
Max	3.1092	2.5606	3.2922	2.5606	2.2862	1.829
Min	1.2803	1.2803	1.2803	1.2803	1.6461	1.4632
Avg	1.7874	1.6326	1.9144	1.6084	1.8176	1.6459

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

JINTUR (R) S/DN[452] BU 2372

Substation No/ Name :- 204053 / 33 /11 KV JINTUR

Feeder No / Name : 202 / 11KV Shevadi

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.4458	.4458	.5144		
2	.4115	.4458	.4458	.5144		
3	.463	.4287	.4458	.5487		
4		.463	.4973	.5487		
5	.5144	.5487	.5487	.5487		
6	.6173	.6859	.6173	.6001		
7	.6859	.6859	.7373	.6001		
8	.6859	.583	.7545	.6859		
9	.6516	.6173		.7545	.6859	
10	.6687	.7202		.7202	.6516	
11	.6859			.7202	.6859	
12	.6516			.6859	.7202	
13	.6173	.6516		.6001	.6859	
14		.6516	.6001	.6001		
15	.6173	.7202	.5144	.5487		
16	.6859	.7545	.4458	.5487		.6173
17	.7716	.7716				.6859
18	.8059	.7716				.6687
19	.583	.6859				.6001
20	.583	.6173				.5316
21	.5658	.5487				.5316
22	.5487	.5144				
23	.4973	.4973				
24	.4458	.463	.4801	.5144		
Max	.8059	.7716	.7545	.7545	.7202	.6859
Min	.4115	.4287	.4458	.5144	.6516	.5316
Avg	.5986	.6033	.5444	.6032	.6859	.6059

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

JINTUR (R) S/DN[452] BU 2372

Substation No/ Name :- 204053 / 33 /11 KV JINTUR

Feeder No / Name : 203 / 11 KV CHANDRAGIRI FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	.0754	.0566	
2	.0754	.0754	.0754	.0566	
3	.0754	.0754	.0754	.0566	
4	.0094	.0754	.0754	.0566	
5	.1132	.1132	.1132	.0566	
6	.132	.1509	.1509	.0943	
7	.1886	.2075	.2075	.1698	
8	.1698	.1886	.2075	.1886	
9	.1698	.1698	.2075	.1886	
10	.1509	.1698	.2075	.1886	
11	.1509	.1698	.2075	.1698	
12	.1509	.1509	.1132	.1698	
13	.132	.1509	.1509	.132	
14	.132	.132	.1886	.1509	
15	.1132	.132	.1509	.1509	
16	.1132	.132	.1509	.1509	.1509
17	.1509	.1698			.1509
18	.1886	.2075			.1886
19	.1698	.1886			.1698
20	.132	.132			.132
21	.1132	.132			.1132
22	.1132	.1132			
23	.0943	.0943			
24	.0943	.0754	.0943	.0566	
Max	.1886	.2075	.2075	.1886	.1886
Min	.0094	.0754	.0754	.0566	.1132
Avg	.1254	.1367	.1442	.1232	.1509

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

JINTUR (R) S/DN[452] BU 2372

Substation No/ Name :- 204053 / 33 /11 KV JINTUR

Feeder No / Name : 204 / Warud Mix Feeder

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9945	.9602	.9602	.7716	
2	.9945	.9602	.9431	.7716	
3	1.0288	.9774	.9431	.7202	
4	1.0288	1.0117	.9774	.7202	
5	1.1317	1.0802	1.0117	.8573	
6	1.2003	1.2174	1.046	.8573	
7	1.3203	1.4746	1.3032	1.1145	
8	1.5089	1.3203	1.406	1.2003	
9	1.4918	1.3889	1.406	1.3203	
10	1.5261	1.4403	1.406	1.286	
11	1.5261		1.3375	1.286	
12	1.5089		1.2346	1.286	
13	1.4746	.9431	1.2003	1.2346	
14	1.3546	1.3203		1.2003	
15	1.3889	1.4232		1.2003	
16	1.3889	1.4232			1.1145
17	1.406	1.4403			1.2003
18	1.4918	1.3717			1.3889
19	1.286	1.2689			1.2689
20	1.2003	1.1145			1.0288
21	1.1145	.9774			.9259
22	1.0802	.9602			
23	1.046	.9945			
24	1.0288	1.0117	.9774	.823	
Max	1.5261	1.4746	1.406	1.3203	1.3889
Min	.9945	.9431	.9431	.7202	.9259
Avg	1.2717	1.1855	1.1538	1.0406	1.1546

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

JINTUR (R) S/DN[452] BU 2372

Substation No/ Name :- 204055 / 33/11 Kv Adgaon S/s.

Feeder No / Name : 201 / Adgaon feeder

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	1.3717	1.2003	1.0517	1.3717	.9431	.9431
2	1.0288	1.3717	1.286	1.2269	1.3717	.9431	.9431
3	1.2003	1.3717	1.3717	1.4022	1.3717	.9431	.9808
4	1.5432	1.3717	1.4575	1.5074	1.3717	.9431	.9808
5	1.6476	2.0576	1.6289	1.7528	1.5432		
6	1.7528	2.572	1.8861	1.9204	1.5432		
7	2.1384	2.572	2.2291	2.2291	2.572		
8	2.5766	2.8292	2.6578	2.4006	2.572		
9	2.3148	2.8292	2.3148	1.8347	2.572		
10	2.0576	.9431	1.9719	1.8004	2.4863		
11						2.1033	1.8004
12						2.3838	2.0576
13						2.0332	1.5432
14						1.8404	1.5432
15						1.8755	1.5432
16						1.9281	1.5432
17	1.7146		.9431	.8573	.9431	1.9281	1.6289
18	1.7146	.9431		.8573	1.0374	1.893	1.6289
19	1.7146	1.0374		.8573	1.0374	1.094	.8573
20	.8573	1.0374	1.094	.8573	.9808	1.094	.8573
21	.8573	.9431	1.0374	.8573	.9431	1.0374	.8573
22	.8573	.9431	.9808	.8573	.9431	.9808	.8573
23	.8573	.9431	.9431	.8573	.9431		.8573
24	.9431	.8573	.9431	.9431	.8573	.9431	.9431
Max	2.5766	2.8292	2.6578	2.4006	2.572	2.3838	2.0576
Min	.8573	.8573	.9431	.8573	.8573	.9431	.8573
Avg	1.4892	1.5291	1.4966	1.3372	1.4700	1.4651	1.2426

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

JINTUR (R) S/DN[452] BU 2372

Substation No/ Name :- 204055 / 33/11 Kv Adgaon S/s.

Feeder No / Name : 202 / Takalkhopa feeder SHEDDABLE RURAL
Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.1886	.2263	.2096	.1886	1.9719	
2	.2096	.1886	.2263	.2096	.1886	2.0576	
3	.2477	.1886	.2452	.2286	.1886	2.1434	
4	.2858	.1886	.2829	.2858	.1886	2.2291	
5						2.3148	
6						2.4006	
7						2.4863	
8						1.0117	
9						1.1317	
10						.9774	
11	2.572	2.3148	2.2131	2.0576	2.1434		
12	2.572	2.6749		2.572	2.4863		
13	2.7435	2.7092	2.5149	2.572	3.0007		
14	2.8292	2.6749	2.5987	2.572	2.8292		
15	2.8292	2.7092	2.4813	2.572	2.692		
16	2.8292	2.7435	2.5819	2.572	2.915	.2667	
17	2.572	2.915	2.7664	2.572	3.1722	.1715	.1886
18	2.572	2.4863	2.5149	2.572	2.3148	.2477	.1886
19	.1886	.2829	.2858	.1886	.3206	.3048	.1886
20	.1886	.3584	.2477	.1886	.2829	.2858	.1886
21	.1886	.2829	.2286	.1886	.2452	.2667	.1886
22	.1886	.2452		.1886	.2263	.2286	.1886
23	.1886	.2263	.2286	.1886	.2075		.1886
24	.2286	.1886	.2286	.2096	.1886	.2075	
Max	2.8292	2.915	2.7664	2.572	3.1722	2.4863	.1886
Min	.1886	.1886	.2263	.1886	.1886	.1715	.1886
Avg	1.3135	1.3093	1.2420	1.2304	1.3211	1.1502	.1886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

JINTUR (R) S/DN[452] BU 2372

Substation No/ Name :- 204080 / 33 KV S/s Bhogaon

Feeder No / Name : 201 / 11kv LIMBALA FEEDER (SINGLE PHASING
 Single P Feeder KV- 11 /
 OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8676	.8402	.8865	.8215	.8488	.5544	.5093
2	.9431	.9522	.9431	.8589	.9054	.5729	.5093
3	1.1694	1.1949	1.1883	.8962	.9431	.6099	.6224
4	1.3203	1.307	1.3121	.9335	1.0374	.6468	.6468
5	1.4712	1.363	1.5023	1.1458	1.2567		
6	1.531	1.5497	1.6632	1.3491	1.4784		
7	1.4937	1.643	1.7147	1.4632	1.6057		
8	1.6804	1.7364	1.8004	1.9022	1.9978		
9	1.8298	1.5123	1.6289	1.9204	1.7364		
10	1.587	1.5746	1.6975	1.5524	1.8298		
11						1.647	1.6095
12						1.7661	1.5384
13						1.7147	1.4266
14						1.7147	1.386
15						1.6632	1.2936
16						1.5746	1.3717
17	.7762	.7059	.5658	.5281	.5359	1.5384	1.39
18	.7947	.7059	.6224	.6979	.5914	1.4661	1.3676
19	.7207	.7947	1.0374	.9054	.6283	.6602	.811
20	.9795	.7733	.9997	.8488	.6099	.6224	.8676
21	.9425	.7545	.7167	.6979	.5729	.6224	.7733
22	.8871	.7356	.679	.6413	.5544	.6224	.6979
23	.8131	.6979	.6413	.6036	.5359	.4715	.7167
24	.5658	.7392	.6602	.6224	.5658	.5359	.4715
Max	1.8298	1.7364	1.8004	1.9204	1.9978	1.7661	1.6095
Min	.5658	.6979	.5658	.5281	.5359	.4715	.4715
Avg	1.1318	1.0878	1.1255	1.0216	1.013	1.0558	1.0005

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

JINTUR (R) S/DN[452] BU 2372

Substation No/ Name :- 204080 / 33 KV S/s Bhogaon

Feeder No / Name : 202 / 11KV PUNGALA FEEDER SINGLE PHASING
 (single Ph Feeder KV- 11 /
 OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6224	.5914	.6224	.6036	.5847	.4481	.6602
2	.6602	.7023	.7167	.6413	.6602	.4854	.6602
3	.7922	.7762	.7922	.679	.7545	.5228	.7733
4	.9054	1.0164	.9795	.8676	.9242	.5601	.924
5						.5788	.9774
6						.7468	1.1145
7						1.1016	1.1145
8						1.307	1.3546
9						1.1203	1.2517
10						1.0317	1.2437
11	1.2136	1.1041	1.0679	1.1706	1.0642		
12	1.2136	1.1145	1.1488	1.1458	1.2696		
13	1.0829	1.046	1.1283	1.1706	1.2136		
14	.9522	1.046	1.0425	1.0349	.9522		
15	.9709	1.0288	1.0242	.9709	.9896		
16	1.0082	.9774	1.0534	1.0164	1.0456		
17	1.0829	1.0288	.9425	1.0829	1.0456	.5729	.5658
18	1.1949	1.046	1.0164	1.0349	1.0642	.6838	.6979
19	.9795	.9055	.9431	.9997	.9055	.7733	.8676
20	.9425	.8865	.9619	.9054	.7947	.7545	.9054
21	.7947	.7733	.6979	.7922	.6838	.6602	.7922
22	.6468	.6602	.6979	.7167	.6468	.6224	.679
23	.5544	.5847	.6413	.6413	.5914	.5847	.6036
24	.6036	.5359	.6224	.5847	.5658	.5544	.5281
Max	1.2136	1.1145	1.1488	1.1706	1.2696	1.307	1.3546
Min	.5544	.5359	.6224	.5847	.5658	.4481	.5281
Avg	.9012	.8791	.8944	.8921	.8753	.7283	.8730

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

JINTUR (R) S/DN[452] BU 2372

Substation No/ Name :- 204080 / 33 KV S/s Bhogaon

Feeder No / Name : 203 / 11KV BHOGAON FEEDER SINGLE PHASING
 (Single Ph Feeder KV- 11 /
 OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4338	.4435	.4715	.4527	.415	.3361	.4715
2	.4715	.462	.5093	.4904	.4715	.3734	.4715
3	.5658	.5359	.7356	.5281	.5658	.3921	.5093
4	.7167	.6653	.8316	.6036	.7167	.3921	.499
5						.4108	.6001
6						.6161	.703
7						.6722	.6344
8						.6908	.6687
9						.7468	.6516
10						.6335	.6219
11	.6161	.6335		.4108	.7468		
12	.6161	.5658	.5316	.5359	.7095		
13	.6348	.5658	.5373	.4435	.7282		
14	.6348	.5658	.4938	.5175	.6722		
15	.5601	.5316	.4572	.4668	.6908		
16	.5788	.5316	.4938	.4481	.5975		
17	.5415	.5658	.5487	.5228	.7468	.462	.415
18	.6535	.6001	.5975	.5359	.7095	.5359	.5658
19	.6468	.7207	.6602	.6224	.6099	.5847	.6224
20	.6099	.6979	.679	.6602	.5359	.5658	.6036
21	.5544	.6602	.5847	.5093	.499	.5093	.5658
22	.5175	.5847	.547	.4715	.4435	.4715	.4527
23	.462	.5093	.4904	.415	.4066	.4338	.4527
24	.4338	.4066	.4715	.4527	.3961	.3696	.3961
Max	.7167	.7207	.8316	.6602	.7468	.7468	.703
Min	.4338	.4066	.4572	.4108	.3961	.3361	.3961
Avg	.5693	.5692	.5671	.5048	.5923	.5109	.5503

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

JINTUR (R) S/DN[452] BU 2372

Substation No/ Name :- 207010 / 33/11 Kv MIDC Jintur S/s.

Feeder No / Name : 201 / 11 Kv Industrial Feeder SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3507	.8238	.3788	.8749	.5815	.3658	.1677
2	1.3268	1.3797	.7549	1.3872	1.1457	.3635	.2997
3	.7796	.807	.3772	.6965	.5754	.3635	.1677
4	.7712	1.2715	.3346	1.2927	1.1267	.3589	.3186
5	.7225	.7392	.3734	.7057	.4763	.3704	.1692
6	.711	1.1065	.3803	1.4254	1.1419	.378	.3186
7	.7141	.7423	.5022	.711	.5563	.2721	.3428
8	1.0764	.7724	.9776	1.5133	1.242	.4081	.671
9	.5731	.4397	.5228	.8436	1.2293	.2035	.6958
10	1.3519	.4413	1.2674	1.7934	1.1953	.173	1.3695
11	.7407	.4445	.7225	.9511	1.2828	.1631	.6744
12	1.6838	.2378	1.3479	1.8812	1.1999	.3481	.7948
13	.8619	.2385	.6325	1.9729	1.2338	.1799	.7087
14	.8276	.2439	1.62	1.9569	.8922	.1654	.695
15	.6775	.2111	.8467	1.9336	1.0306	.1608	.7026
16	1.4089	.4053	1.3683	1.9709	.9424	.3042	1.3712
17	.7598	.2347	.8261	1.6019	.4633	.1654	.8573
18	1.612	.4187	1.7231	1.5036	.7697	.1768	.8749
19	1.4752	.1867	.6447	.6805	.2561	.1753	.865
20	1.6211	.4893	1.7701	1.401	.4875	.3481	.7705
21	1.6497	.3239	.9617	.5944	.3353	.1661	.8368
22	.8733	.3688	1.858	1.2235	.6834	.1631	.8398
23	1.5981	.3551	.9343	.5944	.3658	.1677	.8291
24	1.5518	1.0924	.9305	.8364	.9362	.4867	.9421
Max	1.6838	1.3797	1.858	1.9729	1.2828	.4867	1.3712
Min	.5731	.1867	.3346	.5944	.2561	.1608	.1677
Avg	1.1133	.5739	.9190	1.2644	.8396	.2678	.6785

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

JINTUR (R) S/DN[452] BU 2372

Substation No/ Name :- 207010 / 33/11 Kv MIDC Jintur S/s.

Feeder No / Name : 202 / 11 Kv Paghari Feeder

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561						
2	.2561	.2743	.2641	.2561	.2561		.2012
4		.2561		.2926	.2743		.2195
6		.3292		.3475	.3841		.3841
7							.3841
8	.4207	.3841	.4572	.3658	.4024	.4024	.4572
9		.4207			.4024		
10	.4207	.3658	.3841	.3292	.4024		.2926
11		.3841			.439		
12	.3841		.2926	.2743	.439	.3475	
13				.2926	.4207		
14					.4024		
15					.4207		
16	.3841	.3841	.3109	.2561	.3658	.3109	.6401
18	.3841	.4207	.3292	.2561	.3475		
19	.4207						
20	.3658	.3292	.3475	.2926	.2561	.4024	
21	.3292						
22			.2743	.2926	.2378		
23	.2926						
24	.2561	.2926		.2561	.2561	.2378	.2012
Max	.4207	.4207	.4572	.3658	.439	.4024	.6401
Min	.2561	.2561	.2641	.2561	.2378	.2378	.2012
Avg	.3475	.3492	.3325	.2926	.3567	.3402	.3475

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

JINTUR (R) S/DN[452] BU 2372

Substation No/ Name :- 207010 / 33/11 Kv MIDC Jintur S/s.

Feeder No / Name : 203 / Town -Shivaji nagar SHEDDABLE URBAN
 Feeder Feeder KV- 11 /
 OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7375	.8756	.8101	.7971	.7308	.6706	.695
2	1.6902	1.6416	1.6041	1.5112	1.4365	.6562	1.4144
3	.823	.8261	.772	.7628	.6973	.6462	.6729
4	.8368	1.6857	.7979	1.5957	1.5234	.6546	1.4914
5	.9518	.9648	.9244	.868	.7865	.7484	.8177
6	1.2628	2.3548	1.3077	2.4592	2.1094	.9549	2.3442
7	1.608	1.5699	1.6811	1.6133	1.4419	1.3359	3.1717
8	2.9439	3.107	3.0056	2.9386	2.9088	2.8197	3.1367
9	1.3557	1.4426	1.5485	1.435	2.7999	1.3977	1.4777
10	2.3564	2.5133	2.4226	2.3106	2.7107	1.3154	2.3045
11	1.1378	2.1643	1.1728	1.1111	2.4181	1.2003	1.0936
12		.9907	1.8617	1.8236	2.1475	1.8961	.9785
13	.8695	.9671	.9335	1.6926	2.0241	1.0212	.9114
14	1.0448	.9541	1.6736	.8375	1.8069	.9541	.8665
15	.9838	.9137	.8215	.8581	1.7405	.8505	.8154
16	1.8923	1.8763	1.4556	1.5546	1.8229	1.5226	1.6012
17	1.0661	.9473	.7636	.7179	1.0235	.8909	.9587
18	1.7886	2.0934	2.0127	2.0583	2.1955	.9648	1.0067
19	3.0727	1.3024	1.3382	1.3542	1.1721	1.1911	1.2292
20	2.8746	2.383	2.3267	2.2908	2.1506	2.2245	1.2658
21	2.5537	1.2056	1.2209	1.1759	1.0204	1.0235	1.1302
22	1.2224	1.0791	1.9822	1.9982	1.7521	.9145	1.0585
23	2.0119	.9968	.9724	.9145	.8299	.823	.9206
24	1.8656	1.6713	.8657	1.5661	1.5455	1.4579	1.5302
Max	3.0727	3.107	3.0056	2.9386	2.9088	2.8197	3.1717
Min	.823	.8261	.7636	.7179	.6973	.6462	.6729
Avg	1.6500	1.5219	1.4281	1.5102	1.6998	1.1723	1.3705

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

MANWAT SUB-DIVISION[801] BU 4801

Substation No/ Name :- 204009 / 33 KV Sub. Manwath

Feeder No / Name : 201 / MANWAT TOWN 1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6859	.6001	.6859	.6001	.6859	.6859
2	.6859	.6859	.6001	.6859	.6859	.6859	.6859
3	.7716	.6859	.5144	.6859	.6859	.6859	.6859
4	.8573	.6859	.7621	.6859	.7716	.6859	.8573
5	.8573	.6097	.6001	.6859	.8573	1.0288	1.0288
6	.8573	.8573	1.0288	.6859	1.3717	1.2003	1.2003
7	1.3717	1.0288	1.4575	.6859	1.0288	1.2003	1.2003
8	1.3717	1.0288	.3429	1.3717	1.0288	1.0288	1.3717
11	.7716	.6859	1.0288	.6859	.8573	.6859	.8573
12	.7716	.6859	.8573	.6001	.8573	.6859	.6859
13	.6859	.8573	.6859	.6001	.8573	.6859	.6859
14	.6859	.6859	.6859	.6859	.7716	.6859	.6859
15	.6859	.6859	.6859	.6859	.7716	.6859	.6859
16	.6859	.6859	.6859	.6859	.7716	.8573	.6859
17	.6859	.6859	1.0631	1.0288	.8573	.8573	.8573
18	.8573	.8573	.8573	1.0288	.8573	1.0288	1.0288
19	.8573	1.0288	.8573	1.0288	1.2003	1.2003	1.0288
20	1.0288	1.1145	.8573	1.0288	1.2003	1.2003	1.0288
21	.8573	.8573	.6859	1.0288	1.0288	.9431	1.0288
22	.8573	1.0288	.6859	.8573	.6859	.8573	1.0288
23	.8573	.9431	.6859	.8573	.8573	.7716	1.0288
24	.8573	.5144	.6859	.6859	.905	.6001	.5144
Max	1.3717	1.1145	1.4575	1.3717	1.3717	1.2003	1.3717
Min	.6859	.5144	.3429	.6001	.6001	.6001	.5144
Avg	.8456	.7993	.7688	.8028	.8868	.8612	.8885

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

MANWAT SUB-DIVISION[801] BU 4801

Substation No/ Name :- 204009 / 33 KV Sub. Manwath

Feeder No / Name : 202 / Ambegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.9145	.9145	.4572	1.0288	.6097	.5335
2	.9145	1.0669	.9145	.9145	1.0288	.6097	.6097
3	.9145	1.0669	.9145	1.2193	1.0288	.9145	.5335
4	1.2193	1.0669	1.0669	1.2193	1.0669	1.0669	.6097
5	1.2193	1.829	1.0669	1.5242	1.5242		
6	1.5242	1.9814	1.3717	1.7528	1.829		
7	1.5242	1.9814	1.829	1.7528	1.829		
8	1.5242	1.9814	1.829	1.7528	1.3717		
9	2.1338	1.9052	2.1338	1.829	1.829		
10	2.1338	1.9052		1.829	1.7985		
11	2.1338					2.1338	1.2193
12						2.1338	1.6766
13						2.7435	1.5242
14						1.6766	1.5242
15						1.6766	1.5242
16						1.6766	1.5242
17	.6097	.6097	.6859	.6097	.6859	1.829	1.5242
18	.7621	.7621	.6097	.9145	1.1431	1.829	1.5242
19	.9145	.8383	.6097	.9145	.9145	.6097	.6097
20	.7621	.9145	.6097	.9145	.9145	.6097	.6097
21	.7621	.9145	.4572	.9145	.6859	.6859	.7621
22	.5335	.6097	.4572	.9145	.6097	.6859	.6097
23	.6097	.6097	.4572	.9145	.6097	.6859	.6097
24	.7621	.9145	.9145	.4572	.9145	.6097	.5335
Max	2.1338	1.9814	2.1338	1.829	1.829	2.7435	1.6766
Min	.5335	.6097	.4572	.4572	.6097	.6097	.5335
Avg	1.1512	1.2151	.9907	1.1558	1.1563	1.2659	1.0034

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

MANWAT SUB-DIVISION[801] BU 4801

Substation No/ Name :- 204009 / 33 KV Sub. Manwath

Feeder No / Name : 203 / Ratnapur

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193	1.3717	1.448	1.2193	1.2193	1.5242	1.448
2	1.2193	1.3717	1.448	1.2193	1.2193	1.5242	1.448
3	1.3717	1.2955	1.448	1.2193	1.2193	1.3717	1.448
4	1.3717	1.2955	1.448	1.2193	1.2193	1.3717	1.4022
15	2.1338	2.1338	1.5242	1.9814	1.5242	1.829	1.6766
16	2.1338	2.1338	1.6766	2.1338	1.9814	1.5242	1.829
17	2.1338	2.1338	1.5242	2.1338	1.829	1.829	1.829
18	1.829	1.829	1.5242	1.829	1.829	1.5242	1.829
19	1.829	1.5242	1.5242	1.829	1.829	1.5242	1.5242
20	1.9814	1.5242	1.5242	1.5242	1.6766	1.5242	1.5242
21	1.9814	1.5242	1.2193	1.3717	1.5242	1.4022	1.3717
22	1.5242	1.5242	1.2193	1.3717	1.5242	1.448	1.3717
23	1.3717	1.448	1.2193	1.2193	1.5242	1.448	.6097
24	1.2193	1.2193	1.3717	1.2193	.9145	1.3717	1.3717
Max	2.1338	2.1338	1.6766	2.1338	1.9814	1.829	1.829
Min	1.2193	1.2193	1.2193	1.2193	.9145	1.3717	.6097
Avg	1.6657	1.5949	1.4371	1.5350	1.5024	1.5155	1.4774

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

MANWAT SUB-DIVISION[801] BU 4801

Substation No/ Name :- 204009 / 33 KV Sub. Manwath

Feeder No / Name : 204 / Manoli

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193	.6097	.6097	.381	1.0669	.4572	.381
2	1.2193	.6097	.9145	.6097	1.0669	.6097	.4572
3	1.2193	.6097	.9145	.9145	1.0669	.6097	.4572
4	1.2193	.6097	1.0669	1.2193	1.0669	.6097	
5	1.829	.6097	1.0669	1.2193	1.0669		
6	1.829	.6097	1.3717	1.2193	1.829		
7	1.829	.6097	1.3717	1.3717	1.829		
8	.9145	2.1338	1.3717	1.3717	2.1338		
9	.9145	2.1338	1.3717	1.3717	1.6766		
10	.9145	2.1338		1.2193	1.5242		
11						2.1338	1.2193
12						2.1338	1.2193
13						1.9814	1.2193
14						1.9814	1.2193
15						1.829	1.2193
16						1.5242	1.2193
17	.4572	.4572	.4572	.6097	.4572	1.5242	1.2193
18	.4572		.4572	.6097		.381	.6097
19	.4572	.4572	.4572	.6097	.6097	.381	.6097
20	.4572	.4572	.4572	.6097	.6097	.4572	.6097
21	.4572	.4572	.381	.6097	.4572	.4572	.6097
22	.381	.4572	.381	.6097	.4572	.3048	.6097
23	.3048	.381	.381	.6097	.4572	.3048	.6097
24	.8764	.4572	.4572	.4268	.9145	.3048	.381
Max	1.829	2.1338	1.3717	1.3717	2.1338	2.1338	1.2193
Min	.3048	.381	.381	.381	.4572	.3048	.381
Avg	.9420	.8114	.7934	.8662	1.0759	.9992	.8159

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

MANWAT SUB-DIVISION[801] BU 4801

Substation No/ Name :- 204009 / 33 KV Sub. Manwath

Feeder No / Name : 205 / Katruwar

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.1829	.1524	.0762	.1219	.0762	.0305
2	.0762	.1829	.1524	.0762	.1219	.0762	.0305
3	.0762	.1829	.1829	.0762	.1219	.0762	.0457
4	.0762	.1829	.1829	.1524	.1219	.0762	.061
5	.0762	.1524	.1524	.1524	.1219	.0762	.0476
6	.1524	.1524	.1524	.0762	.1219	.0762	.0305
7	.1524	.1524	.1524	.1524	.1219	.0762	.0762
8	.1524	.1524	.2286	.1524	.1219	.0762	.0762
9	.1524	.1524	.1524	.2286	.1219	.0762	.0914
10	.1524	.1524	.2743	.2286	.1524	.1219	.1524
11	.0762	.1524	.2743	.2286	.1219	.1219	.1524
12	.1524	.0762	.1524	.2286	.1524	.1219	.1524
13	.1524	.0762	.1524	.2286	.1524	.1219	.1524
14	.1524	.0762	.1524	.3048	.1524	.1219	.1524
15	.1524	.0762	.1524	.2286	.1524	.1219	.0762
16	.1524	.0762	.1524	.2286	.1524	.0762	.0914
17	.1524	.0762	.1524	.1524	.1524	.0762	.0914
18	.1524	.0762	.1524	.1524	.1524	.0762	.0914
19	.1524	.1067	.1524	.1524	.1524	.0762	.0572
20	.1524	.0762	.1524	.0914	.1524	.0762	.0667
21	.1524	.1219	.0762	.0914	.0762	.0762	.1067
22	.1524	.1067	.0762	.0914	.0762	.0762	.1067
23	.1524	.1219	.0762	.0914	.0762	.061	.1067
24	.0762	.1524	.1524	.0762	.0914	.0762	.0305
Max	.1524	.1829	.2743	.3048	.1524	.1219	.1524
Min	.0762	.0762	.0762	.0762	.0762	.061	.0305
Avg	.1302	.1257	.1588	.1549	.1276	.0870	.0865

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

MANWAT SUB-DIVISION[801] BU 4801

Substation No/ Name :- 204009 / 33 KV Sub. Manwath

Feeder No / Name : 206 / Sant Bhagatram

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0457	.1829	.0305	.0305	.0305	.0305	.0457
2	.0457	.0305	.0305	.0305	.0305	.0305	.0457
3	.0457	.0305	.0457	.0305	.0305	.0305	.0457
4	.0457	.0305	.0457	.0305	.0305	.0305	.0457
5	.0457	.0305	.0457	.0305	.0305	.0305	.0305
6	.0457	.0457	.0457	.0305	.0305	.0305	.0305
7	.0457	.0457	.0457	.0457	.0305	.0305	.0457
8	.0457	.0305	.0457	.0457	.0305	.0305	.0457
9	.0457	.0457	.0305	.0457	.0305	.0305	.0457
10	.0457	.0457	.0305	.0457	.0457	.0305	.0457
11	.0457		.061	.0457	.061	.0305	.061
12	.0457		.0457	.0457	.061	.0305	.0762
13	.0457	.0572	.0457	.0762	.061	.0305	.0762
14	.0457	.0457	.0457	.0762	.0305	.0305	.061
15	.0457	.0457	.0457	.0457	.0305	.0305	.061
16	.0305	.0457	.0305	.0457	.0305	.0305	.061
17	.0457	.0457	.0305	.0457	.0305	.0305	.061
18	.0305	.0305	.0305	.0457	.0305	.0305	.061
19	.0305	.061	.0305	.0457	.0305	.0762	.061
20	.0305	.0305	.0305	.061	.0305	.0305	.0457
21	.0305	.0305	.0305	.061	.0305	.0305	.0457
22	.0457	.0457	.0305	.061	.0305		.0305
23	.0457	.0457	.0305	.061	.0305	.0305	.0457
24	.0305	.0305	.0305	.0305	.0305	.0305	.0305
Max	.0457	.1829	.061	.0762	.061	.0762	.0762
Min	.0305	.0305	.0305	.0305	.0305	.0305	.0305
Avg	.0419	.0469	.0381	.0464	.0349	.0325	.0502

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

MANWAT SUB-DIVISION[801] BU 4801

Substation No/ Name :- 204009 / 33 KV Sub. Manwath

Feeder No / Name : 207 / Bhagwati

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.4268	.381	.0762	.381	.2286	.1524
2	.3048	.4572	.4268	.0762	.381	.2286	.1524
3	.3048	.4877	.381	.0762	.381	.2286	.1524
4	.3048	.4877	.4268	.0457	.381	.2286	.2286
5	.3048	.4877	.381	.1524	.381	.2439	.2286
6	.3048	.4268	.3048	.2286	.3048	.2439	.2286
7	.3048	.3048	.2286	.2591	.3048	.2439	.2286
8	.4572	.3048	.3048	.3048	.381	.2439	.2286
9	.3048	.2286	.0457	.5335	.4572	.2286	.3048
10	.3048		.4572	.5335	.4572	.2134	.2286
11	.2743		.4877	.4572	.4572	.2134	.2286
12	.2286	.2286	.3658	.4572	.4572	.2286	.1429
13	.2743	.2286	.3658	.381	.4572	.2439	.3658
14	.4572	.2286	.442	.4572	.4572	.2439	.3658
15	.4572	.2286	.5335	.4572	.4572	.2286	.3353
16	.4572	.3048	.4572	.4572	.3353	.2439	.1905
17	.3658	.2286	.4572	.6097	.2743	.2286	.3048
18	.3658	.3048	.4572	.6097	.2743	.2286	.3048
19	.2743	.3048	.1524	.6097	.2439	.2286	.3048
20	.2286	.3048	.1524	.5335	.2439	.2286	.3048
21	.3658	.3048	.0762	.5335	.2286	.2286	.3048
22	.3658	.4572	.0762	.381	.2286	.2286	.3048
23	.3353	.4572	.0762	.381	.2286	.2286	.3048
24	.3048	.3658	.3734	.0762	.3048	.1524	.1524
Max	.4572	.4877	.5335	.6097	.4572	.2439	.3658
Min	.2286	.2286	.0457	.0457	.2286	.1524	.1429
Avg	.3315	.3436	.3255	.3620	.3524	.2286	.2520

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

MANWAT SUB-DIVISION[801] BU 4801

Substation No/ Name :- 204009 / 33 KV Sub. Manwath

Feeder No / Name : 208 / Town-II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.381	.3201	.4287	.4572	.3429	.5144
2	.6859	.4287	.5144	.4287	.4572	.3429	.6001
3	.6859	.4287	.6097	.4287	.5144	.3429	.5335
4	.6859	.5144	.6097	.4287	.4572	.3429	.6859
5	.6859	.5144	.6097	.5144	.5144	.3429	.6859
6	.6859	.5144	.8573	.5144	.6859	.6859	.6859
7	.8573	.6859	.8573	.7716	.6859	.6001	.6859
8	.8573	.6001	.9431	.7716	.6859	.5144	.6859
11	.5792		.6859	.6001	.6859	.6001	.6859
12	.6001		.5144	.6001	.6859	.6001	.6001
13	.6859	.6859	.5144	.6001	.6859	.6001	.6001
14	.6001	.6859	.5144	.6001	.6859	.6001	.5144
15	.5144	.6859	.3429	.6001	.6001	.5144	.5144
16	.5144	.6859	.4287	.6001	.6001	.5144	.5144
17	.6516	.6859	.4287	.8573	.6001	.6001	.6859
18	.6859	.8573	.5144	.8573	.6001	.6859	.6859
19	.6859	1.0288	.5144	.8573	.6859	.6859	.6859
20	.6859	1.3717	.4287	.8573	.6859	.6859	.6859
21	.6859	1.2003	.4287	.8573	.6001	.6001	.7716
22	.6859	1.0288	.4287	.6859	.6001	.6001	.6859
23	.5144	1.0288	.4287	.6001	.5144	.6001	.6859
24	.5144	.3429	.3048	.4287	.5144	.3429	.5144
Max	.8573	1.3717	.9431	.8573	.6859	.6859	.7716
Min	.5144	.3429	.3048	.4287	.4572	.3429	.5144
Avg	.6526	.7178	.5363	.6313	.6001	.5339	.6322

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

MANWAT SUB-DIVISION[801] BU 4801

Substation No/ Name :- 204047 / 33 KV KOLHA

Feeder No / Name : 202 / 11 KV IRLAD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2614	.2614	.2402	.2452	.2241	.2263
2	.1867	.2614	.2241	.2957	.2427	.1886	.2263
3	.2614	.3174	.2614	.3361	.2801	.2263	.2263
4	.3734	.415	.3361	.4854	.3584	.3018	.2829
5	.5658	.5658	.5228	.6348	.4338	.5601	.5281
9	.0572						
10	.4066	.3841	.3734	.5041	.4481	.3361	.3547
11	.2402	.2987	.2614	.2587	.3734	.2987	.1848
12						.2987	
13						.2614	
14						.2801	
15						.2987	
16	.2561	.2614	.1848	.1867	.3734	.2614	.1867
17	.2957	.3361	.2587	.2614	.3734	.2427	.2054
18	.2987	.3361	.3326	.2987	.3361	.2801	.2587
19	.4527	.3734	.4435	.4108	.3734	.4108	.4668
20	.4251	.4108	.462	.3547	.3361	.3547	.4108
21	.3881	.4481	.4251	.3547	.2987	.3174	.3734
22	.3361	.3734	.3881	.3361	.2614	.3018	.3395
23	.3018	.2987	.3142	.2829	.2614		.2641
24	.2241	.2614	.2987	.2587	.2452	.2614	.2263
Max	.5658	.5658	.5228	.6348	.4481	.5601	.5281
Min	.0572	.2614	.1848	.1867	.2427	.1886	.1848
Avg	.3114	.3502	.3343	.3437	.3276	.3003	.2976

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

MANWAT SUB-DIVISION[801] BU 4801

Substation No/ Name :- 204047 / 33 KV KOLHA

Feeder No / Name : 203 / 11 KV KOLHA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.1898	.0926
2						.2187	.1524
3						.25	.1505
4						.25	.1806
5						.2187	.1957
6						.2846	.2408
7						.3125	3.2693
8						.3201	.4458
9						.4481	.5647
10						.4801	.5498
11	.4108	.5376	.4755	.4572	.4054		
12	.6602	.6874	.5647	.4458	.6081		
13	.6161	.506	.6836	.4161	.5944		
14	.6308	.4999	.4755	.3269	.4755		
15	.5575	.5312	.535	.3269	.4923		
16	.6161	.4687	.4108	.3269	.4755		
17	.5868	.5693	.4458	.3864	.4161		
18	.6015	.4687	.431	.3374	.3269		
24	.4547						
Max	.6602	.6874	.6836	.4572	.6081	.4801	3.2693
Min	.4108	.4687	.4108	.3269	.3269	.1898	.0926
Avg	.5705	.5336	.5027	.3780	.4743	.2973	.5842

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

MANWAT SUB-DIVISION[801] BU 4801

Substation No/ Name :- 204047 / 33 KV KOLHA

Feeder No / Name : 204 / 11KV IRLAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.192	.125	.16	.0781	.108		
2	.2241	.125	.1898	.0781	.108		
3	.2561	.125	.2846	.0937	.1235		
4	.2812	.1562	.3163	.1094	.1235		
5	.2214	.1562	.2846	.125	.1389		
6	.3163	.2031	.2846	.125	.1698		
7	.3125	.2812	.3163	.2031	.1698		
8	.3479	.4374	.3479	.3125	.3395		
9	.4161	.4843	.4428	.4062	.3086		
10	.3338	.3437	.3841	.4999	.4321		
11						.2881	.2932
12						.3201	.3549
13						.3841	.3395
14						.3201	.3549
15						.3521	.3704
16						3.2007	.4012
17						.4167	.4167
18						.2623	.4321
Max	.4161	.4843	.4428	.4999	.4321	3.2007	.4321
Min	.192	.125	.16	.0781	.108	.2623	.2932
Avg	.2901	.2437	.3011	.2031	.2022	.6930	.3704

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

MANWAT SUB-DIVISION[801] BU 4801

Substation No/ Name :- 204058 / 33 KV RAMPURI

Feeder No / Name : 202 / 11 KV MANGRUL BK

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0348	.7468	.6348	.7468	.7392	.9335	.695
2	.6653	.8316	.5975	.7842	.7468	.905	.6584
3	.6283	.8507	.6535	.8029	.8402	.9231	.7207
4	.6348	.8775	.7392	.8316	.9149	.9522	.7095
5	.6722	.8775	.8869	.924	.9149	.8954	.6859
6	.7316	.9412	.9795	.9694	.924	.9425	.8316
7	.8059	1.0136	.8779	.9694	.9511	.9709	.7202
8						2.5941	2.0388
9						2.5766	2.2634
10						2.5034	2.713
11						2.696	2.5987
12						2.6379	2.5194
13						2.652	2.4247
14						2.6322	
15						2.6063	1.6787
16	2.9504	3.1369	2.6658	2.672	3.0514		
17	3.1579	3.2065	2.8826	2.8334	3.1369		
18	2.6825	2.7854	2.649	2.9007	3.103		
19	2.7161	2.5892	2.4413	2.7183	3.0864	.8326	.6878
20	2.6825	2.4364	2.1548	2.5265	2.9622	.8413	.7095
21	2.6621	2.4274	2.2382	2.3739	2.3663	.8145	.6516
22	2.572	2.3034	2.1293	2.3405	2.1776	.8145	.6219
23	.6908	2.2207	2.1091	2.1262	2.1434	.8238	.6283
24		.6908	.6468	.6908	.6767	.9522	.8402
Max	3.1579	3.2065	2.8826	2.9007	3.1369	2.696	2.713
Min	.6283	.6908	.5975	.6908	.6767	.8145	.6219
Avg	1.7525	1.7460	1.5804	1.7007	1.7959	1.5476	1.2699

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

MANWAT SUB-DIVISION[801] BU 4801

Substation No/ Name :- 204058 / 33 KV RAMPURI

Feeder No / Name : 203 / 11 KV HAMDAPUR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.0747	.0747	.056	.0747	.056	.0747
2	.0739	.0747	.0747	.056	.0747	.0747	.056
3	.0739	.0924	.0747	.0747	.056	.0747	.0747
4	.0747	.0934	.056	.0747	.056	.0442	.0739
5	.0914	.1086	.0747	.056	.056	.0747	.0747
6	.0924	.112	.0934	.0934	.0747	.0553	.0739
7	.0924	.112	.112	.0747	.0747	.0934	.0747
8	.8145	.7316	.6335	.7316	.5853		
9	.788	.695	.7282	.7865	.7865		
10	.8648	.6036	.7762	.8316	.9055		
11	.8764	.8316	.8596	.7865	.924		
12	.8596	.8573	.8402	.7392	.8589		
13	.7602	.9149	.8029	.8048	.8501		
14	.7701	.8962	.8029	.7762	.8402		
15	.7783	.8413	.7762	.7392	.8501		
16						.724	.7716
17						.8326	.905
18						.823	.9145
19	.0934	.056	.0373	.0373	.056	.7762	.7682
20	.0747	.056	.056	.056	.0747	.7577	.7316
21	.056	.0934	.056	.056	.0747	.7421	.6401
22	.0373	.112	.056	.056	.0747	.7522	.6401
23	.056	.112	.0373	.056	.0747	.7682	.5544
24	.0934	.056	.0934	.056	.056	.056	.0739
Max	.8764	.9149	.8596	.8316	.924	.8326	.9145
Min	.0373	.056	.0373	.0373	.056	.0442	.056
Avg	.3578	.3583	.3389	.3333	.3561	.4191	.4064

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

MANWAT SUB-DIVISION[801] BU 4801

Substation No/ Name :- 204058 / 33 KV RAMPURI

Feeder No / Name : 204 / 11 kv Rampuri Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4833						
8	.3978	.3315	.4199	.431	.431	.5967	.5746
9	.4089	.3978	.4641	.442	.4199	.5857	.5304
10	.4862	.3757	.4973	.4531	.431	.652	.5415
11	.5525	.4089	.5304	.4862	.4089	.652	.663
12	.5857	.431	.5304	.4862	.4641	.6078	.6741
13	.5525	.4752	.5525	.4752	.4862	.5967	.6851
14	.5525	.5304	.5415	.4752	.4973	.6409	
15	.5525	.431	.4973	.4199	.5083	.5304	.7183
16	.8951	.8509	.9393	.8067	.8177	.4641	.6851
17	.8951	1.0056	.9393	.8619	.8177	.4087	.652
18	.7404	.7514	.7956	.8619	.8288	.431	.442
19	.5194	.7514	.6188	.5525	.7514	.3757	.3757
20	.5304	.6741	.5083	.5525	.7404	.3757	.3868
21	.5415	.663	.5194	.5525	.5857	.4199	.3868
22	.5525	.5967	.5415	.5525	.5857	.3757	.3757
23	.4752	.5967	.4752	.4641	.5636	.3757	.3647
24	.5058						
Max	.8951	1.0056	.9393	.8619	.8288	.652	.7183
Min	.3978	.3315	.4199	.4199	.4089	.3757	.3647
Avg	.5682	.5795	.5857	.5546	.5836	.5055	.5371

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

MANWAT SUB-DIVISION[801] BU 4801

Substation No/ Name :- 204092 / 33 KV PALODI

Feeder No / Name : 201 / 11 KV PALODI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8						.8288	.7459
16	.1715	.1524	.1619	.1619	.1524		
24	.7716	.7621		.5087		.1619	.1619
Max	.7716	.7621	.1619	.5087	.1524	.8288	.7459
Min	.1715	.1524	.1619	.1619	.1524	.1619	.1619
Avg	.4716	.4573	.1619	.3353	.1524	.4954	.4539

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

MANWAT SUB-DIVISION[801] BU 4801

Substation No/ Name :- 204092 / 33 KV PALODI

Feeder No / Name : 202 / 11 KV SAWARGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.6859	.4144		.4049	.4191		
16						.1677	.4049
24	.1715		.6478	.1658	.1715	.181	.1619
Max	.6859	.4144	.6478	.4049	.4191	.181	.4049
Min	.1715	.4144	.6478	.1658	.1715	.1677	.1619
Avg	.4287	.4144	.6478	.2854	.2953	.1744	.2834

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

MANWAT SUB-DIVISION[801] BU 4801

Substation No/ Name :- 204092 / 33 KV PALODI

Feeder No / Name : 203 / KINHOLA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.3258				
16	1.749	1.3435	1.3443	1.1717	1.6263	.2155	.1928
24	.3429	.3239	.3681	.2683	.2458	.8907	.7287
Max	1.749	1.3435	1.3443	1.1717	1.6263	.8907	.7287
Min	.3429	.3239	.3258	.2683	.2458	.2155	.1928
Avg	1.0460	.8337	.6794	.72	.9361	.5531	.4608

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

PALAM SUB-DIVISION[800] BU 4800

Substation No/ Name :- 017474 / 33kv/11kv sub station Penoor

Feeder No / Name : 204 / 11 kv Sharda construction NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	08-MAR-17	11-MAR-17
HR	Load (MW)	Load (MW)
13		.0381
16	.0381	
18	.0381	
Max	.0381	.0381
Min	.0381	.0381
Avg	.0381	.0381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

PALAM SUB-DIVISION[800] BU 4800

Substation No/ Name :- 204023 / 33 KV PALAM S/S

Feeder No / Name : 201 / 11 KV ANJANWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.181			.181	.2858
2		.181			.181	.5716
3		.2715			.181	.5716
4		.2715			.2715	.7621
5						.7621
6						.7621
8						.7621
9						.8573
10						.7621
11	1.1765	.5716		.543	.724	
12	.8145	.8573	.543	.543	.724	
13	.724	.8573	.724	.543	.6335	
14	.7621	.8573	.724	.543	.543	
15	.724	.7621		.543	.543	
16	.724			.543	.543	
17	.543	.7621		.543		
18	.5716	.7621		.6668		.2715
19		.381		.2858	.381	.2715
20	.2715	.381		.2858	.381	.2715
21	.2715	.2858			.2858	.2715
22	.181	.2858	.2858		.2858	
23	.181	.2858	.2858		.2858	
24		.181			.181	.2858
Max	1.1765	.8573	.724	.6668	.724	.8573
Min	.181	.181	.2858	.2858	.181	.2715
Avg	.5787	.4785	.5125	.5039	.3953	.5335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

PALAM SUB-DIVISION[800] BU 4800

Substation No/ Name :- 204023 / 33 KV PALAM S/S

Feeder No / Name : 202 / 11 KV PALAM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.905			.905	.9526
2		.905			.905	1.1431
3		.905			1.086	1.1431
4		1.448			1.267	1.3336
5		1.6289			1.6289	1.5242
10	1.8099	1.8099		1.448	1.9909	1.7147
11	1.6289	1.6289		1.267		1.5242
12	1.267	1.3336	1.448	1.267	1.6289	1.5242
13	1.267	1.3336	1.267	1.267	1.448	1.3336
14	1.267	1.2384	1.267	1.267	1.3575	1.3336
15	1.1765	1.2384		1.1765	1.267	1.2384
16	1.1765			1.1765	1.267	1.2384
17	1.3575	1.3336		1.1765		1.2384
18				1.5242		1.267
19		1.7147		1.7147		1.3575
20	1.7194	1.5242		1.5242	1.3336	1.267
21	1.448				1.1431	1.086
22	1.086	1.1431	.9526		1.1431	
23	.9955	1.0479	.9526		.9526	
24		.0905		.9526	.905	.9526
Max	1.8099	1.8099	1.448	1.7147	1.9909	1.7147
Min	.9955	.0905	.9526	.9526	.905	.9526
Avg	1.3499	1.2487	1.1774	1.3134	1.2643	1.2873

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

PALAM SUB-DIVISION[800] BU 4800

Substation No/ Name :- 204023 / 33 KV PALAM S/S

Feeder No / Name : 203 / 11 KV PETHPIMPALGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.448			1.448	.5716
2		1.448			1.448	.5716
3		1.448			1.448	.7621
4		1.6289			1.8099	.7621
5		1.8099			1.8099	
6		2.1719			1.9909	
7		2.3529			2.1719	
8		2.3529				
9		2.3529				
11						1.9052
12						1.9052
13						2.3815
14						2.0957
15						2.0005
16						1.9052
17						1.9052
18	.6668	.5716		.8573		1.8099
19		.5716		.8573	.7621	.6335
20	.724	.7621		.7621	.7621	.6335
21	.6335	.7621			.7621	.543
22	.6335	.5716	.5716		.7621	
23	.543	.5716	.5716		.5716	
24		1.448			1.448	.5716
Max	.724	2.3529	.5716	.8573	2.1719	2.3815
Min	.543	.5716	.5716	.7621	.5716	.543
Avg	.6402	1.392	.5716	.8256	1.3227	1.3098

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

PALAM SUB-DIVISION[800] BU 4800

Substation No/ Name :- 204023 / 33 KV PALAM S/S

Feeder No / Name : 204 / 11 KV KERWADI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	13-MAR-17
HR	Load (MW)
8	.1524
Max	.1524
Min	.1524
Avg	.1524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

PALAM SUB-DIVISION[800] BU 4800

Substation No/ Name :- 204024 / 33KV BANWAS

Feeder No / Name : 201 / 11KV BANWAS

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2286	.2477	.2477	.4572	.3239	.3239
2	.3429	.3048	.2667	.2286	.5144	.3048	.3239
3	.381	.381	.3048	.2667	.5716	.3239	.381
4	.4763	.5335	.3429	.2858	.6859	.3239	
5	.5335	.5716	.4001	.3429	.724		
6	.5906	.6668	.5525	.5144	.8383		
7	.9717	.8573	.8573	.9145	.9526		
8	.9526	1.0098	.9907	.9526	1.0288		
9	.9145	.9717	.8764	.6097			
10				.6097		.381	.3429
11						.6668	
12					.1905	.8383	
13					.2286	.8192	
14					.381	.8002	
15					.381	.7621	
16	.2477	.1905	.1715	.2286	.3429	.7621	
17	.3048	.2858	.2667	.2667	.362	.7621	
18	.4191	.362	.381	.381	.4001	.4001	
19	.5144	.5144	.4572	.4001	.4382	.5525	
20	.4191	.4572	.4954	.4572	.4572	.4763	
21	.3429	.362	.4763	.381	.4382	.4382	
22		.3429	.3429	.362	.4191	.381	
23	.2667	.2858	.3048	.2858	.3239	.3429	
24	.2096	.2286	.2667	.2858	.3429	.3048	.3239
Max	.9717	1.0098	.9907	.9526	1.0288	.8383	.381
Min	.2096	.1905	.1715	.2286	.1905	.3048	.3239
Avg	.4808	.4752	.4445	.4221	.4990	.5244	.3391

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

PALAM SUB-DIVISION[800] BU 4800

Substation No/ Name :- 204024 / 33KV BANWAS

Feeder No / Name : 202 / 11KV TANDULWADI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2096	.2096	.1905	.1715	.3048	.4763
2	.1905	.2286	.1905	.2286	.1715	.381	.5716
3	.2286	.2477	.2286	.2286	.1905	.4954	.5716
4						.6478	.6859
5						.7811	.7621
6						1.0288	.8954
7						1.0669	1.0288
8						1.086	1.0479
9							1.0288
10	.5335	.4572	.5525	.5144	.6287		
11	.9526	.8954	.7811	.8383	.9145		
12	.9907	1.0288	.8192	.8192	.9717		
13	1.0288	1.0288	.7621	.8002	.9526		
14	.9907	.9717	.8573	.8383	1.086		
15	1.0288	.9907	.9335	.8002	1.1431		
16	.9717	.9717	.8192	.9907	1.1622	.1334	
17	.9907	.9335	.7621	.9526	1.105	.1905	
18	.1905	.1905	.1715	.1905	.2096	.2286	
19	.2667	.2858	.2667		.2477	.362	
20	.2858	.2667	.2858	.2858	.2667	.2858	
21	.2667	.2477	.2667	.2286	.2477	.2286	
22		.2286	.2286	.2096	.2286	.2096	
23	.2096	.2096	.2096	.1905	.2096	.1905	
24	.1905	.2096	.1905	.2477	.1715		.4763
Max	1.0288	1.0288	.9335	.9907	1.1622	1.086	1.0479
Min	.1905	.1905	.1715	.1905	.1715	.1334	.4763
Avg	.5592	.5335	.4742	.5032	.5599	.4763	.7545

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

PALAM SUB-DIVISION[800] BU 4800

Substation No/ Name :- 204024 / 33KV BANWAS

Feeder No / Name : 203 / 11KV CHORWAD

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.5716	.5716	.6097	.4954	.7621	.4572
2	.5716	.6097	.5906	.6287	.5144	.9145	.4954
3	.6668	.6668	.6097	.6668	.5335	1.1431	.5335
4						1.3527	.6097
5						1.448	.724
6						1.5432	.8573
7						1.3717	1.0479
8						1.2384	1.0098
9						1.2955	.9526
10	.8764	.6097	.7621	.9145	1.2955		
11	1.2384	1.0288	1.0288	1.1622	1.2955		
12	1.0669	1.1241	1.0098	1.3336	1.3336		
13	1.2003	.9526	.9526	.8573	1.448		
14	1.0669	.9145	.9145	1.2955	1.3336		
15	.9526	.9526	.8573	1.0669	1.2955		
16	.9907	1.0288	.9717	.8383	1.3336	.381	
17	.7811	1.0669	.9907	.9526	1.448	.5716	
18	.4763	.4954	.4001	.6478	.6859	.6859	
19	.8764	.8192	.8383	.724	.724	.8383	
20	.7811	.7811	.8764	.743	.743	.7049	
21	.5906	.6859	.8002	.7049	.7049	.6478	
22		.5716	.6859	.5906	.6097	.5716	
23	.5716	.5525	.6097	.5525	.5716	.5335	
24	.5906	.5716	.5906	.5716	.5335	.7621	.381
Max	1.2384	1.1241	1.0288	1.3336	1.448	1.5432	1.0479
Min	.4763	.4954	.4001	.5525	.4954	.381	.381
Avg	.8159	.7780	.7811	.8256	.9388	.9314	.7068

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

PALAM SUB-DIVISION[800] BU 4800

Substation No/ Name :- 204037 / 33 KV FARKANDA S/S

Feeder No / Name : 201 / 11 KV FARKANDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17
HR	Load (MW)
18	.2858
Max	.2858
Min	.2858
Avg	.2858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

PALAM SUB-DIVISION[800] BU 4800

Substation No/ Name :- 204037 / 33 KV FARKANDA S/S

Feeder No / Name : 202 / 11 KV DIGRAS

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	11-MAR-17
HR	Load (MW)	Load (MW)
13		2.1529
16	2.0386	
17	2.0767	
18	.381	
Max	2.0767	2.1529
Min	.381	2.1529
Avg	1.4988	2.1529

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

PALAM SUB-DIVISION[800] BU 4800

Substation No/ Name :- 204077 / 33KV PETHSHIVANI

Feeder No / Name : 201 / 11KV PETHSHIVANI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17
HR	Load (MW)
17	.8507
18	1.0098
Max	1.0098
Min	.8507
Avg	.9303

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

PALAM SUB-DIVISION[800] BU 4800

Substation No/ Name :- 204077 / 33KV PETHSHIVANI

Feeder No / Name : 202 / 11KV PARWA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	11-MAR-17
HR	Load (MW)	Load (MW)
13		.9907
16	1.1431	
17	1.0136	
18	.9526	
Max	1.1431	.9907
Min	.9526	.9907
Avg	1.0364	.9907

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

PALAM SUB-DIVISION[800] BU 4800

Substation No/ Name :- 204077 / 33KV PETHSHIVANI

Feeder No / Name : 203 / 11KV GODAVARI AG

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	11-MAR-17
HR	Load (MW)	Load (MW)
13		1.7909
16	1.8861	
17	1.9909	
18	1.7147	
Max	1.9909	1.7909
Min	1.7147	1.7909
Avg	1.8639	1.7909

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204008 / 33 KV SAILU

Feeder No / Name : 202 / 11KV Town-2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171					.823
2	.0171					.823
3	.0206					.823
4	.024					.823
5	.0257					
6	.0274					
7	.0309					1.0974
8						1.0974
9	.0223	.0189				.0223
14		.0171				
15	.0189	.0171				
16		.0171				
17		.0189	.0171	.0171	.0154	
18		.0171	.0154		.0154	
19		.0206			.0189	
20	.0223	.0206			.0189	
21	.0223	.0206			.0189	
22	.024	.0206			.0171	
23					.6173	
24	.0171				.6173	.6173
Max	.0309	.0206	.0171	.0171	.6173	1.0974
Min	.0171	.0171	.0154	.0171	.0154	.0223
Avg	.0223	.0189	.0163	.0171	.1674	.7658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204008 / 33 KV SAILU

Feeder No / Name : 203 / 11KV Rajwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.012				1.2346
2					1.2346
3					1.2346
4					1.2346
5					1.3717
6					1.5775
7					1.5775
8					1.7147
9	.0514	.0446			.0137
10	.0514	.0429			
11	.0034	.0446			
12	.0514				
13	.0497	.036			
14		2.4691			
15		.0069			
16		.0069	.036		
17		.0069	.0069		
18		.0069	.0086		
19		.012		.0154	
20	.0154	.0137		.0137	
21	.0154	.0137		.0137	
22	.0154	.0137		.0137	
23				.4801	
24	.012			.4801	.4801
Max	.0514	2.4691	.036	.4801	1.7147
Min	.0034	.0069	.0069	.0137	.0137
Avg	.0278	.2091	.0172	.1695	1.1674

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204008 / 33 KV SAILU

Feeder No / Name : 204 / 11Kv Waki SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.024			1.2346
2	.0257			1.2346
3	.0274			1.2346
4	.0291			1.2346
5	.0309			
6	.0394			
7	.0446			
8	.0429			
18			.0274	
19		.0154	.0171	
20	.0171	.0171	.0171	
21	.0171	.0171	.0154	
22	.0171	.0154	.0137	
23			1.0974	
24	.0223		.0326	1.0974
Max	.0446	.0171	1.0974	1.2346
Min	.0171	.0154	.0137	1.0974
Avg	.0281	.0163	.1744	1.2072

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204008 / 33 KV SAILU

Feeder No / Name : 205 / 11KV Moregaon (KHUPSA) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0154				1.166
2	.0171				1.166
3	.0154				1.166
4	.0154				1.166
5					1.3032
6					1.3717
7					1.3717
8					1.5775
9					.0429
11		.0069			
12		.0103			
13	.0137	.0103			
14		.0566			
15		.0532			
16		.0549			
17		.0514	.0446		
18		.0463	.0429		
19		.0206		.0189	
20	.024	.0206		.0189	
21	.0223	.0206		.0171	
22	.0223	.0189		.0171	
23				.5487	
24	.0171			.6173	.5487
Max	.024	.0566	.0446	.6173	1.5775
Min	.0137	.0069	.0429	.0171	.0429
Avg	.0181	.0309	.0438	.2063	1.0880

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204008 / 33 KV SAILU

Feeder No / Name : 206 / 11 KV Industrial -I
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0137					.3429
2	.024					.3429
3	.024					.3429
4	.024					.3429
5	.0257					.3429
6	.0257					.4115
7	.0223					.4115
8	.0257					.4115
9	.0223	.0069				.0137
10	.0206	.0069				
11	.0206	.0069				
12	.0206	.0069				
13		.0069				
14		.0069				
15	.0223	.0069				
16		.0069				
17		.0038	.0206	.0189	.0048	
18		.0038			.0048	
19		.0038			.0048	
20	.0189	.0038			.0048	
21	.0137	.0103			.0048	
22	.0154	.0076			.0086	
23					.3429	
24	.0154				.5144	.3429
Max	.0257	.0103	.0206	.0189	.5144	.4115
Min	.0137	.0038	.0206	.0189	.0048	.0137
Avg	.0209	.0063	.0206	.0189	.1112	.3306

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204008 / 33 KV SAILU

Feeder No / Name : 207 / 11KV Town 3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17
HR	Load (MW)
21	.0137
Max	.0137
Min	.0137
Avg	.0137

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204008 / 33 KV SAILU

Feeder No / Name : 208 / 11 KV Industrial -II
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-17	09-MAR-17	10-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.024				.4801
2	.024				.4801
3	.024				.4801
4	.0257				.4801
5	.0274				.4801
6	.0291				.5144
7	.0257				.5144
8	.0274				.5144
9	.0137	.0137			.0137
10	.0257	.0154			
11	.0291				
12	.0291				
13	.0291				
16		.024			
17		.0206	.0291	.0091	
18		.0189	.0309	.0137	
19		.0206		.0091	
20	.0223	.0183		.012	
21	.0206	.0206		.0069	
22	.0206	.0223		.008	
23				.4801	
24	.012			1.0974	.4801
Max	.0291	.024	.0309	1.0974	.5144
Min	.012	.0137	.0291	.0069	.0137
Avg	.0241	.0194	.03	.2045	.4438

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204046 / 33KV WALOOR

Feeder No / Name : 201 / 11KV WALUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7						.6401	
8	.8745					.6401	
9		.8097			.7045		
10					.7701		
11					.8962		
12				.9762	1.0883		
13					1.0402		
14					.9922		
15					.9172		
16	.9145	1.0822	.6478	.884	.9602		.6097
23					.5441		.6097
24						.5218	
Max	.9145	1.0822	.6478	.9762	1.0883	.6401	.6097
Min	.8745	.8097	.6478	.884	.5441	.5218	.6097
Avg	.8945	.9460	.6478	.9301	.8792	.6007	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204046 / 33KV WALOOR

Feeder No / Name : 202 / 11KV HATNUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7						.6401	
8						.5906	
9					.8002		
10					.4334		
11					1.0745		
12				.884	1.0745		
13					1.0227		
14					.953		
15					.9145		
16	1.5242	.8619	.7956	.7183	.8688		.9145
23					.5316		.823
24						.5197	
Max	1.5242	.8619	.7956	.884	1.0745	.6401	.9145
Min	1.5242	.8619	.7956	.7183	.4334	.5197	.823
Avg	1.5242	.8619	.7956	.8012	.8526	.5835	.8688

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204046 / 33KV WALOOR

Feeder No / Name : 203 / 11KV WALUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.6653
2							.6535
3							.6348
4							.6468
5	.9955	.9335				.9425	.9425
10	.8145				.8688	.8779	
11					.9774		
12				.6653	.823	.6401	
17	.905	.8779			.9694	.8048	.724
18		.8871				.7865	
20						.961	
21						.8501	
22						.7392	
23	.7602	.7392	.6722	.6535	.7023	.6653	.6878
24	.6878	.7468	.7167	.679		.6908	.6722
Max	.9955	.9335	.7167	.679	.9774	.961	.9425
Min	.6878	.7392	.6722	.6535	.7023	.6401	.6348
Avg	.8326	.8369	.6945	.6659	.8682	.7958	.7034

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204046 / 33KV WALOOR

Feeder No / Name : 204 / 11KV HATNUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.3696
2							.3696
3							.3511
4							.3881
5	.543	.4382				.5914	.5792
10					.7621	.5792	
11					.7316		
12				.3772	.5853	.543	
17	.362	.4784			.7316	.6516	
18		.5609				.5792	
20						.5914	
21						.5175	
22						.4435	
23	.3258	.3544	.3982	.3856	.4435	.3696	.3982
24	.362	.4607	.362	.3982	.4075	.4251	.3696
Max	.543	.5609	.3982	.3982	.7621	.6516	.5792
Min	.3258	.3544	.362	.3772	.4075	.3696	.3511
Avg	.3982	.4585	.3801	.387	.6103	.5292	.4036

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204046 / 33KV WALOOR

Feeder No / Name : 205 / 11KV TIRUPATI EXPRESS
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINOUS PROCESS)(NO STAGGERING)

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.0724	.1143		.0754		
9					.0953	
10					.0953	
11					.1524	
12				.132	.0953	
13					.0953	
16		.0754	.0754			.0724
17		.0762				
18		.112				
23	.0905	.0754	.0754	.0953		1.0498
24	.0905	.0943		.0754	.1132	
Max	.0905	.1143	.0754	.132	.1524	1.0498
Min	.0724	.0754	.0754	.0754	.0953	.0724
Avg	.0845	.0913	.0754	.0945	.1078	.5611

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204046 / 33KV WALOOR

Feeder No / Name : 206 / 11KV RAWA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5						.3241	
8		1.2146	1.5623	.7042	.1715		
9						.7682	
13					.3978		
14					.9831		
15					1.0486		
16	.9717				.9175	1.1469	.8745
17	.9717						
20						.3125	
21						.3086	
22						.3048	
23	1.0526	1.0669	.7287	.1486	.2743	.2743	.2591
24		1.0526	1.0936	.7287	.1425	.2743	.2134
Max	1.0526	1.2146	1.5623	.7287	1.0486	1.1469	.8745
Min	.9717	1.0526	.7287	.1486	.1425	.2743	.2134
Avg	.9987	1.1114	1.1282	.5272	.5622	.4642	.449

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204048 / CHIKHALTHAN

Feeder No / Name : 201 / 11KV CHIKALTHANA BK

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3856	.3898	.381	.3258	.3768	.4191	.394
2	.4115	.4382	.4191	.298	.439	.4572	.3856
3	.5138	.4954	.4572	.2947	.439	.4763	.5373
4	.5028	.6287	.5335	.3544	.5304	.4954	.567
5						.5716	.5658
6						.8383	.5895
7						.9526	.6443
8						1.2003	.7716
9						1.3717	.6653
10						1.3336	.5041
11	1.1812	.8421	.8322	.7621	.5375		
12	1.2955	.9442		.8573	1.0513		
13	1.3336	.9105	.9012	.8192	.9526		
14	1.1431	.8002	.8478		.9717		
15	1.105	.7968	.7373	.8573	1.0288		
16	1.0479	.8592	.5792	.8764	1.086		
17	.9105	1.086	.6562	.8029	1.105	.5304	.7888
18	1.0185	1.105	.6562	.884	.9717	.6805	1.0682
19	.6099	.6859	.4784	.5973	.6478		.9156
20	.567	.6478	.4031	.5316	.5335	.5716	.7011
21	.5788	.4954	.4119	.3429	.4954	.567	.5493
22	.4854		.3429	.4938	.4572	.5373	.5028
23	.4763	.4572	.298	.4382	.4382	.4557	.439
24	.3944	.4294	.4001	.3045	.4024	.381	.439
Max	1.3336	1.105	.9012	.884	1.105	1.3717	1.0682
Min	.3856	.3898	.298	.2947	.3768	.381	.3856
Avg	.7756	.7066	.5491	.5788	.6925	.6964	.6127

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204048 / CHIKHALTHAN

Feeder No / Name : 202 / 11KV MOREGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3391	.3353	.2286	.3315	.3163	.4572	.3549
2	.3185	.3401	.2667	.3353	.3241	.4954	.3353
3	.3185	.3361	.2858	.373	.3605	.4954	.4214
4	.3429	.3605	.3048	.431	.3605	.5144	.4344
5	.3338	.4481	.3239	.5344	.39		
6	.4967	.5155	.3429	.639	.3795		
7	.7377	.7773	.3429	.6802	.7865		
8	.8745	.8333		.7407	.8951		
9	1.0479	.8322	.759	.9907	.945		
10	.9717	.7449	.8381	.8002	.852		
11						.8573	.427
12						.9145	.3201
13						.7042	.2622
14						.7274	.503
15						.639	.5735
16						.6944	.5312
17	.3953	.4191	.543	.3658	.5335	.639	.6062
18	.4915	.4191	.431	.442	.5906	.6622	.6802
19	.5609	.6287	.583	.506	.6097		.5914
20	.5434	.6097	.6097	.5079	.5716	.6287	.6287
21	.5975	.5716	.5087	.5716	.4763	.5335	.5906
22	.4854	.5335	.4908	.4954	.4572	.3913	.4359
23	.4572	.4954	.3641	.439	.4382	.3593	.3688
24	.3944	.39	.4191	.3641	.3605	.4191	.3768
Max	1.0479	.8333	.8381	.9907	.945	.9145	.6802
Min	.3185	.3353	.2286	.3315	.3163	.3593	.2622
Avg	.5393	.5328	.4495	.5304	.5360	.5960	.4690

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204048 / CHIKHALTHAN

Feeder No / Name : 203 / 11KV JAWALA J

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.124	.1524	.1334	.1052	.1147	.1524	.128
2	.1214	.1524	.1524	.104	.124	.1715	.1227
3	.1734	.1715	.1905	.1387	.1448	.1905	.1214
4	.1949	.1905	.2096	.1829	.1663	.2096	.1372
5	.2477	.2286	.2667	.2507	.1595		
6	.3048	.2667	.3429	.4001	.1867		
7	.4001	.3292	.381	.4572	.407		
8	.4525	.4024		.381	.3277		
9	.4763	.4477	.3361	.4191	.3721		
10	.3429	.2374	.3142	.362	.298		
11						.4001	.197
12						.3429	.1417
13						.2804	.0886
14						.2328	.1524
15						.1865	.168
16						.2507	.2033
17	.1578	.1524	.1753	.1715	.2667	.2858	.3012
18	.2303	.1524	.1595	.1715	.2096	.3239	.3012
19	.2804	.2286	.2667	.2303	.2286		.2667
20	.2667	.2096	.1905	.2054	.2096	.2286	.1844
21	.2286	.1905	.1905	.1595	.1905	.1905	.1677
22	.2286	.1905	.1612	.1463	.1715	.1578	.1526
23	.1905	.1715	.1417	.1267	.1524	.1417	.1387
24	.1433	.1715	.1524	.1433	.1134	.1334	.1214
Max	.4763	.4477	.381	.4572	.407	.4001	.3012
Min	.1214	.1524	.1334	.104	.1134	.1334	.0886
Avg	.2536	.2248	.2214	.2309	.2135	.2282	.1719

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204049 / 33KV NANDGAON

Feeder No / Name : 201 / 11WAGHI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.168	.1494	.1494	.1307	.1829	.1715
2	.1494	.168	.1494	.1494	.1307	.1829	.1715
3	.1867	.1867	.1867	.1867	.1494	.2195	.2058
4	.1867	.2241	.2241	.2241	.1867	.2561	.2058
5						.2561	.2572
6						.3292	.3429
7						.3658	.4115
8						.5487	.5144
9						.6401	.583
10						.5487	.4458
11	.6401	.5853	.4024	.5487	.5487		
12	.7316	.6584	.5121	.7316	.6584		
13	.567	.5487	.4024	.7316	.6401		
14	.5487	.5487	.4024	.5853	.5121		
15	.5487	.5121	.3658	.6036	.5121		
16	.5853	.4024	.4207	.567			
17	.5487	.5853	.2743	.6584		.2054	.2172
18	.6401	.5853	.4344	.6401	.362	.2241	.2401
19						.1867	.2058
22	.2054	.2241	.2241	.1867	.1867	.168	.1372
23	.1867	.1867	.2241	.1715	.1494	.168	.1715
24	.168	.1867	.1494	.1867	.1494	.1494	.1372
Max	.7316	.6584	.5121	.7316	.6584	.6401	.583
Min	.1494	.168	.1494	.1494	.1307	.1494	.1372
Avg	.4028	.3847	.3014	.4214	.3320	.2895	.2762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204049 / 33KV NANDGAON

Feeder No / Name : 202 / 11 GANESHPUR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1494	.1867	.3734	.1867	.1463	.3429
2	.1867	.1494	.1867	.1867	.1867	.1463	.3429
3	.2054	.168	.2241	.2241	.1867	.1829	.3429
4	.2241	.1867	.2614	.2614	.2241	.2241	.4115
5	.2801	.2614	.2801	.2987	.2987	.2926	.4458
9	.4572	.5975	.5601	.4481	.3921	.2926	.3429
10	.4755	.4854	.4668	.7468	.3361	.2926	.3086
11	.3658	.3921		.2614	.2378	.1867	.1372
12		.112		.112			.12
13		.112		.112			.1029
14		.1097		.0934			
15	.4572	.2926	.1463	.0934	.3292	.1867	.0183
16	.5487	.3292	.1867	.0934	.3658	.1867	.1829
17	.3361	.2743	.1494	.0747	.0732		.2614
18	.2012	.1829	.1097	.0747	.1097		
19	.2241	.1829	.1097	.0747	.112		
20	.2743	.2801	.2987	.2427	.2241	.2614	.2987
21	.2427	.2614	.2614	.2241	.2241	.2241	.2012
22	.168	.2241	.2241	.2241	.1867	.4668	.4801
23	.168	.2241	.2241	.2241	.1867	.4115	.5144
24	.2054	.168	.1867	.1867	.2241	.1463	.3772
Max	.5487	.5975	.5601	.7468	.3921	.4668	.5144
Min	.168	.1097	.1097	.0747	.0732	.1463	.0183
Avg	.2893	.2449	.2390	.2205	.2269	.2432	.2907

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204049 / 33KV NANDGAON

Feeder No / Name : 203 / 11 KV DEVGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.0183	.0171
2						.0183	.0171
3						.0183	.0171
4						.0183	.0171
5						.0183	.0171
6						.0183	.0171
7						.0366	.0343
8						.0366	.1029
9						.0366	.0686
10						.0366	.0686
11	.0914	.128	.0934	.0914	.0914		
12	.1097	.1646	.0732	.0732	.0914		
13	.0914	.128	.0747	.0366	.0732		
14	.0914	.128	.0549	.0747	.0732		
15	.1097	.0914	.0366	.0366	.0549		
16	.1463	.0914	.056	.0549	.0914		
17	.128	.1097	.0549	.0549	.0732		
18	.1097	.1097	.1097	.0549	.0549		
Max	.1463	.1646	.1097	.0914	.0914	.0366	.1029
Min	.0914	.0914	.0366	.0366	.0549	.0183	.0171
Avg	.1097	.1189	.0692	.0597	.0755	.0256	.0377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204051 / 33 KV DASALA

Feeder No / Name : 201 / 11 DASALA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1372	.1372	.1715	.1543	.5144	.5316
2	.1715	.1372	.1372	.1715		.4287	.4287
3	.1715	.1372	.1372				
8						1.3375	1.5432
9						1.286	1.3889
11	1.6975	1.6804		1.166	1.166		
16	2.0748	1.8519	1.3203		1.989		
17	2.1262	1.7147	1.2174	1.4403	1.8004		
18			1.3375	1.3889			
24	.1715	.1372	.1372	.1715	.1543	.4458	.4287
Max	2.1262	1.8519	1.3375	1.4403	1.989	1.3375	1.5432
Min	.1715	.1372	.1372	.1715	.1543	.4287	.4287
Avg	.9406	.8280	.632	.7516	1.0528	.8025	.8642

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204051 / 33 KV DASALA

Feeder No / Name : 202 / 11 KV DEVALGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.583	.4801	.5144	.3601	.12	.1029
2	.5144	.6001	.6344	.5144	.4115		
3	.5144	.6344	.6516				
8	1.2346	1.2346					
9	1.0802	1.1831					
10						.9088	
16						.9259	
17						.8745	
24	.5144	.5144	.3772	.5144	.3944	.12	.0857
Max	1.2346	1.2346	.6516	.5144	.4115	.9259	.1029
Min	.5144	.5144	.3772	.5144	.3601	.12	.0857
Avg	.7287	.7916	.5358	.5144	.3887	.5898	.0943

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204051 / 33 KV DASALA

Feeder No / Name : 203 / 11KV DASALA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2401	.3086	.2572	.3086	.2743	
2	.2401	.2401	.3429	.2572	.3086	.2743	
3	.2401	.2572	.4287				
6							.4115
8			.5144				
10	.2743	.2401	.2401	.2401	.5487		
11	.2058	.1372			.4287		
12				.2401			
16	.2058	.3086			.3086	.3086	
17	.2401		.2572	.2743	.3944	.2743	
24	.2401	.2401	.3086	.2572	.2743	.2743	.3097
Max	.2743	.3086	.5144	.2743	.5487	.3086	.4115
Min	.2058	.1372	.2401	.2401	.2743	.2743	.3097
Avg	.2358	.2376	.3429	.2544	.3674	.2812	.3606

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204051 / 33 KV DASALA

Feeder No / Name : 204 / 11KV DEVALGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2401	.2401	.2401	.2743	.2401	.2401
2	.2401	.2401	.2743	.2401	.2743	.2743	
3	.2401	.2058	.3258				
10	.2401	.1715	.1715	.2915	.4287	.4115	.3086
11	.2058	.1372		.1886	.3086		
16	.1886	.1372	.1715			.1886	
17	.2058	.1543	.2229	.2401	.2743	.2743	
24	.2401	.2401	.2401	.2401	.2401	.2401	.2058
Max	.2401	.2401	.3258	.2915	.4287	.4115	.3086
Min	.1886	.1372	.1715	.1886	.2401	.1886	.2058
Avg	.2251	.1908	.2352	.2401	.3001	.2715	.2515

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204086 / 33/11 KV MIDC SUB-STATION

Feeder No / Name : 203 / 11KV MIDC EXPRESS FEEDER SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-17	09-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173				.5144	
7		.0472				.0224
8	.7716			.0373	.4287	
9	.7716			.0377		.0321
11					.3944	
12	.0434					
13		.0205				
14	.0472			.0472		
16		.0207			.3772	.0415
17			.0434			.703
19					.3944	
21			.0377	.0317		.6173
23	.034				.0226	
24		.0358		.0396		
Max	.7716	.0472	.0434	.0472	.5144	.703
Min	.034	.0205	.0377	.0317	.0226	.0224
Avg	.3809	.0311	.0406	.0387	.3553	.2833

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 207009 / 132 KV PATHRI

Feeder No / Name : 401 / 33 KV SAILU

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	18.2099					18.3128
2	20.2675					18.3128
3	23.0453					18.3128
4	23.0453					18.3128
5	20.9877					15.7408
6	23.6626					16.8725
7	24.4856					19.3416
8	24.6914					20.679
9	.0154	13.6831	15.7408			19.4445
10	.0103	7.8189				
11		7.3045				
12	.0103	2.0576				
13	.0154	6.3786			18.3128	
14		15.6379				
15		15.4321				
16		15.8436	16.358			
17		.0154	.0154	.0154	.0154	
18		.0154	.0154	.0154	.0154	17.284
19		.0154			.0154	
20	19.9589	.0154			.0154	
21	18.9301	.0154			.0154	
22	18.7243	.0154			.0154	
23					12.8601	
24	16.821				15.4321	12.8601
Max	24.6914	15.8436	16.358	.0154	18.3128	20.679
Min	.0103	.0154	.0154	.0154	.0154	12.8601
Avg	15.8051	6.0178	8.0324	.0154	5.1886	17.7703

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SONPETH SUB-DIVISION[799] BU 4799

Substation No/ Name :- 204041 / 33 KV KHADKA S/S

Feeder No / Name : 202 / 11 KV KANHEGAON MIX

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.6001						
16	2.2291	1.5432	.4458	2.4006	3.0864	3.155	
17							2.0233
24	2.0062	.6859	1.4918	2.2634	2.2291		1.8861
Max	2.2291	1.5432	1.4918	2.4006	3.0864	3.155	2.0233
Min	.6001	.6859	.4458	2.2634	2.2291	3.155	1.8861
Avg	1.6118	1.1146	.9688	2.332	2.6578	3.155	1.9547

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SONPETH SUB-DIVISION[799] BU 4799

Substation No/ Name :- 204041 / 33 KV KHADKA S/S

Feeder No / Name : 203 / 11 KV SAYKHEDA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.9088	1.0288	1.046	.12	1.0288	.8573	.9602
24	.1029	.0686	.0857	.1029	.1029	.0514	.0857
Max	.9088	1.0288	1.046	.12	1.0288	.8573	.9602
Min	.1029	.0686	.0857	.1029	.1029	.0514	.0857
Avg	.5059	.5487	.5659	.1115	.5659	.4544	.5230

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SONPETH SUB-DIVISION[799] BU 4799

Substation No/ Name :- 204041 / 33 KV KHADKA S/S

Feeder No / Name : 204 / 11 KV KHADKA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.0748	1.7147	1.7147	1.5775	1.4403	1.3717	1.3032
24	.3429	.2915	.3086	.2058	.3429	.2572	.2058
Max	2.0748	1.7147	1.7147	1.5775	1.4403	1.3717	1.3032
Min	.3429	.2915	.3086	.2058	.3429	.2572	.2058
Avg	1.2089	1.0031	1.0117	.8917	.8916	.8145	.7545

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SONPETH SUB-DIVISION[799] BU 4799

Substation No/ Name :- 204041 / 33 KV KHADKA S/S

Feeder No / Name : 206 / 11 KV SAYKHEDA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.9774	1.0288	1.286		1.0288	1.286	1.2689
12	.6668						
16	.4572	.6859	.5487	.7716	.8573	.6859	
24	.3772	.6859	.3944	.4115	.3944	.6859	.6859
Max	.9774	1.0288	1.286	.7716	1.0288	1.286	1.2689
Min	.3772	.6859	.3944	.4115	.3944	.6859	.6859
Avg	.6197	.8002	.7430	.5916	.7602	.8859	.9774

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SONPETH SUB-DIVISION[799] BU 4799

Substation No/ Name :- 204042 / 33 KV SONPETH S/S

Feeder No / Name : 203 / 11 KV LASINA-I

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.1886
2				.7468	.9335	.1886
4				1.0164	1.0269	
6				1.2936	1.386	
8					1.7556	
9	1.6804	1.9281	1.1827	1.6632	1.829	
10	1.6804		1.1827	1.4784	1.7556	
17		.2614	.1886	.1886		
18		.2614				
19		.2987		.2801		
20	.1886	.2987	.1867			
21		.2987		.2829		
22		.1867				
23			.1886	.2829		
24		.1867		.1886	.2829	.3018
Max	1.6804	1.9281	1.1827	1.6632	1.829	.3018
Min	.1886	.1867	.1867	.1886	.2829	.1886
Avg	1.1831	.4651	.5859	.7422	1.2814	.2263

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SONPETH SUB-DIVISION[799] BU 4799

Substation No/ Name :- 204042 / 33 KV SONPETH S/S

Feeder No / Name : 204 / 11 KV SHELGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.6722
2				.2829	.3772	.7468
4				.2829	.4668	
9	1.5684					
11			1.2936	1.2936	.7468	
12			1.5708	1.3491	1.1088	
13			1.5546	1.386	1.4784	
14			1.5708	1.386	1.4784	
15			1.4784	1.386	1.4784	
16			1.4784	1.2936	1.4784	
17	1.307	1.4937	1.4784	1.2936		
18		1.4937				
19	.4854	.3734		.4668		
20	.4854		.3734			
21				.3734		
22		.4108				
23			.2829	.3772		
24		.3174		.2829	.3772	.3018
Max	1.5684	1.4937	1.5708	1.386	1.4784	.7468
Min	.4854	.3174	.2829	.2829	.3772	.3018
Avg	.9616	.8178	1.2313	.8811	.9989	.5736

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SONPETH SUB-DIVISION[799] BU 4799

Substation No/ Name :- 204042 / 33 KV SONPETH S/S

Feeder No / Name : 205 / 11 KV SONPETH TOWN-II

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.4527
2				.3772	.4715	.4854
4				.4715	.5601	
6				.924	.9979	
8					1.1888	
9	.9335	.8954	.924	.924	1.2012	
10	.8962		.8589	.7468	1.0164	
11			.6535	.6535	.9979	
12			.6535	.6535	.8962	
13			.6535	.6535	.5601	
14				.6535	.6348	
15			.6535	.6535	.6722	
16			.5601	.6535	.6908	
17	.7733	.5601	.6535	.7468		
18	.9114	.7842				
19	.9465	1.0456		.924		
20	.8413	.9335	.924			
21		.8589		.7468		
22		.7095				
23			.5601	.5601		
24		.547	.5228	.4715	.5093	.4527
Max	.9465	1.0456	.924	.924	1.2012	.4854
Min	.7733	.547	.5228	.3772	.4715	.4527
Avg	.8837	.7918	.6925	.6759	.7998	.4636

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SONPETH SUB-DIVISION[799] BU 4799

Substation No/ Name :- 204042 / 33 KV SONPETH S/S

Feeder No / Name : 206 / 11 KV LASINA-II

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.3395
2				.8402	1.1203	.3395
4				1.1088	1.2136	
6				1.3717	1.4784	
8					1.829	
9	1.5684	1.9281	1.6461	1.6632	1.9204	
10	1.4937		1.6632	1.5708	1.848	
17	.4338	.3734	.2829	.2829		
18	.5601	.3734				
19	.6584	.4481		.4668		
20	.5601	.4854	.2801			
21		.4854		.4668		
22		.4481				
23			.2829	.3772		
24		.3772		.2829	.3772	.3395
Max	1.5684	1.9281	1.6632	1.6632	1.9204	.3395
Min	.4338	.3734	.2801	.2829	.3772	.3395
Avg	.8791	.6149	.8310	.8431	1.3981	.3395

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SONPETH SUB-DIVISION[799] BU 4799

Substation No/ Name :- 204042 / 33 KV SONPETH S/S

Feeder No / Name : 207 / 11 KVKAUDGOAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.1886
2				.6535	.5228	.2263
4				.7392	.6535	
6				.924	.9979	
8					1.2936	
9	1.5684	1.2178	1.1827	1.2936	1.386	
10	1.4937		1.1827	1.2936	1.3306	
16		.2614				
17	.3174	.1867	.1886	.1886		
18	.3658	.2614				
19	.3506	.3174		.3174		
20	.3734	.2614	.1867			
21		.2614		.3174		
22		.1867				
23			.1886	.2829		
24		.2427		.1886	.2452	.1886
Max	1.5684	1.2178	1.1827	1.2936	1.386	.2263
Min	.3174	.1867	.1867	.1886	.2452	.1886
Avg	.7449	.3552	.5859	.6199	.9185	.2012

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204001 / 33 KV PEDGAON

Feeder No / Name : 206 / 11KV HASNAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857				
2	.12	.12				
3	.1372	.12				
4	.1715	.1029				
5	.2058	.1372	.1753			
6	.2401	.2058				
7	.2915	.0274				
8	.3086	.3086				
9	.2743	.3086				
10	.3429		.2804	.2279		
16					.3772	
17	.0514			.0514		
18	.0514					
23	.0686					
24	.0514	.0686	.0701		.0514	.0514
Max	.3429	.3086	.2804	.2279	.3772	.0514
Min	.0514	.0274	.0701	.0514	.0514	.0514
Avg	.1715	.1485	.1753	.1397	.2143	.0514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204001 / 33 KV PEDGAON

Feeder No / Name : 207 / 11 KV DEVKRUPA EXPRESS
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINOUS PROCESS)(NO STAGGERING)

DATE	10-MAR-17
HR	Load (MW)
8	.105
24	.114
Max	.114
Min	.105
Avg	.1095

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204002 / 33KV POKHARANI

Feeder No / Name : 202 / 11KV POKHARNI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.7545	.6602	.6036	.5658	.0381	.0377
2	.7545	.8488	.7545	.7356	.6602	.0381	.0377
3	.7922	.8488	.7545	.7922	.8402		.0377
4	.7922	.9431	.8488	.811	.7468	.0381	.0377
5	.8488	1.0374	.9431	.9808	.7468	.0381	
6	.9431	1.1203	1.1317	.9808	.8402		
7	1.4146	1.307	1.5089	1.226	1.1088		
8	1.6975	1.4937	1.5089	1.3203	1.4784		
9	1.7918	1.6632	1.6032	1.5655	1.6804		
10	1.6032	1.6804	1.6975	1.3769	1.6032		
11						1.5089	1.6032
12						2.2068	1.8861
13						2.0538	1.7918
14						1.8671	1.7918
15						1.8858	1.8861
16						1.8484	1.8861
17						1.8861	1.8861
18						1.7924	1.7918
19	.0566	.0566	.0566	.0377	.0381	.0377	.0377
20	.0566	.0566	.0943	.0377	.0381	.0377	.0377
21	.0377	.0566	.0566	.0377	.0381	.0373	.0377
22	.0377	.0566	.0566	.0377		.0377	.0377
23	.0377	.0566	.0566	.0377	.0381	.0377	.0377
24	.0381	.0377	.0566	.0566	.0377	.0381	
Max	1.7918	1.6804	1.6975	1.5655	1.6804	2.2068	1.8861
Min	.0377	.0377	.0566	.0377	.0377	.0373	.0377
Avg	.7191	.7511	.7368	.6649	.6974	.8571	.8743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204002 / 33KV POKHARANI

Feeder No / Name : 203 / 11KV SINGNAPUR GT

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0377	.0377	.0377	.0381	
2	.0572	.0566	.0377	.0377	.0377	.0381	.0377
3	.0572	.0566	.0377	.0377	.0566	.0381	.0377
4	.0572	.0754	.0566	.0377	.0754	.0381	.0377
5	.0572	.0754	.0377	.0566	.0943	.0377	.0566
6		.0943	.0943	.0943	.0943	.0754	.0754
7	.0572	.0943	.0943	.0754	.0943	.0943	.0943
8	.0566	.0754	.1132	.0566	.0943	.0943	.0943
9	.0566	.0754	.0943	.0566	.0566	.0953	.0934
10	.0566	.0566	.0754	.0566	.0566	.0934	.0943
11	.0566	.0566	.0566	.0566	.0566	.0566	.0566
12	.0566	.0189	.0566	.0566	.0566	.0566	.0377
13	.0377	.0189	.0377	.0377	.0566	.0571	.0377
14	.0377	.0189	.0377	.0377	.0566	.0566	.0377
15	.0377	.0189	.0189	.0377	.0566	.0566	.0377
16	.0377	.0189	.0171	.0566	.0566	.056	.0377
17	.0566	.0189	.0377	.0566	.0572	.0566	.0377
18	.0566	.0189	.0566	.0754	.0572	.056	.0377
19	.0754	.0566	.0754	.0754	.0754	.0754	.0566
20	.0943	.0754		.0754	.0754	.0754	.0754
21	.0754	.0566	.0566	.0566	.0566	.056	.0377
22	.0566	.0566	.0566	.0566	.0566	.0566	.0377
23	.0566	.0566	.0566	.0566	.0572	.0566	.0377
24	.0572	.0566	.0377	.0377	.0377	.0381	.0377
Max	.0943	.0943	.1132	.0943	.0943	.0953	.0943
Min	.0377	.0189	.0171	.0377	.0377	.0377	.0377
Avg	.0567	.0527	.0557	.0550	.0629	.0605	.0532

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204002 / 33KV POKHARANI

Feeder No / Name : 204 / 11KV POKHARNI GT

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5544	.5658	.5601	.5658	.5658	.543	.0377
2	.5544	.5601	.5601	.5658	.7545	.543	.5658
3	.5544	.8488	.5601	.5658	1.0374	.543	.5658
4	.6468	1.226	.6535	.6602	1.226	.6468	.6602
5	.924	1.4146	.9335	.9431	1.5089	.924	.9431
6	1.386	1.5089	1.1203	1.4146	1.6032	1.386	1.3203
7	1.587	1.5089	1.307	1.6032	1.5089	1.4146	1.1317
8	1.4937	1.3203	1.4003	1.4146	1.4146	1.386	1.5089
9	1.307	1.1317	1.307	1.3203	1.1317	1.2136	1.307
10	1.0269	.8488	1.0269		1.1317	1.1203	1.0374
11	.6602	.6535	.6602	.7545	.924	.7545	.6535
12	.5658	.5601	.5658	.5658	.924	.5658	.5601
13	.5658	.5601	.5658	.5658	.924	.5658	.5601
14	.5658		.5658	.5658	.924	.5658	.5601
15	.5658		.5658	.5658	1.0164	.5658	.4668
16	.5658	.6535	.5658	.5658	1.1088	.6535	.5601
17	.7545	.7468	.6602	.6535	1.1088	.7545	.7468
18	.9431	.9335	.8488	.7468	1.1088	.7545	.9335
19	1.0374	1.1203	1.226	1.226	1.2012	1.1317	1.0269
20	1.1317	1.0269	1.1317	.9431	.924	1.0374	1.1203
21	.8488	.8402	.8488	.7545	.924	.7468	.9335
22	.5658	.7545	.7545	.5658	.5975	.6602	.7468
23	.5658	.6535	.6602	.5658	.5487	.5658	.6535
24	.5544	.5658	.5601	.5658	.5658	.543	.5658
Max	1.587	1.5089	1.4003	1.6032	1.6032	1.4146	1.5089
Min	.5544	.5601	.5601	.5658	.5487	.543	.0377
Avg	.8302	.9092	.8170	.8112	1.0284	.8161	.7986

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204003 / 33KV DAITHANA

Feeder No / Name : 201 / 11KV Dhondi-Malsonna AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0886	.0886	.0914	.0895	.8954	.8669
2	.0914	.0905	.0886	.0914	.0914		.905
3	.0914	.0362	.0886	.0914	.0876		1.0631
4		.0876	.0867	.0914	.0886		1.0745
5	.0914		.0876				1.2003
6							1.2803
7							1.4022
8							1.3717
9						1.2803	1.4784
10						1.3146	1.5432
11	1.5223	1.0288	1.4899	1.4022	1.3717		
12	1.97	1.0631	1.5432		1.8004		
13	1.949	1.4632	1.3717		1.8861		
14	1.7909	1.5775	1.2003		1.8861		
15	1.8404	1.4175			1.7147		
16	1.6289	1.6118	1.5432		1.7147		
17	1.9281	1.5604	1.286	.2715	1.6289		
18	1.9909	1.8099		1.8671	1.6289		
19				1.5775			
20	.0934	.0867	.0914	.0351	.0914	.0886	
21	.0876	.0876	.0914	.0905	.0914	.0351	
22	.0905	.0895	.0914	.0876	.0914	.0895	
23	.0895	.0886	.0914	.0914	.0914		
24	.0914	.0934	.0857	.0914	.0905	.0914	.0857
Max	1.9909	1.8099	1.5432	1.8671	1.8861	1.3146	1.5432
Min	.0876	.0362	.0857	.0351	.0876	.0351	.0857
Avg	.9081	.7224	.5829	.4523	.8497	.5421	1.1156

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204003 / 33KV DAITHANA

Feeder No / Name : 202 / 11KV Daithana AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.543	.7087	.5487	.3467	.0914	.0914
2	.3658	.543	.724	.5373	.3467	.0914	.0876
3	.5373	.5487	.7164	.5373	.3734	.0914	.0905
4	.5373	.5601	.6859	.7164	.362	.0914	.0895
5	.5373	.5316	.6935	.7164	.4668		
6	.7164	.7011	1.086	.7011	.7545		
7	.7164	.9335	1.0517	.8573	.9145		
8	.8764	1.2269	1.448	1.0288	1.0269		
9	.8573	1.5604	1.3717	.8573	1.1203		
10	.8573	1.3717	1.2803	1.0288	1.1203		
11						.8573	
12						1.0974	
13						1.2536	
14						1.2003	
15						1.4632	
16						1.4175	
17						1.6289	
18						1.5604	
20	.0905	.0886	.0914	.0905	.0914	.0914	
21	.0876	.0914	.0914	.0914	.0914	.0857	
22	.0905	.0895	.0914	.0876	.0914	.0914	
23	.0886	.0905	.0914	.0886	.0914		
24	.0914	.0876	.0914		.0886	.0914	.0857
Max	.8764	1.5604	1.448	1.0288	1.1203	1.6289	.0914
Min	.0876	.0876	.0914	.0876	.0886	.0857	.0857
Avg	.4544	.5978	.6815	.5634	.4858	.7003	.0889

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204003 / 33KV DAITHANA

Feeder No / Name : 203 / 11KV DAITHNA Gauthan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.2686	.1715	.1829	.2743	.1829	.1715
2	.1829	.2629	.2715	.1829	.2801	.1829	.2743
3	.2686	.2629	.2686	.2743	.2801	.2686	.3429
4	.2686	.3544	.3582	.2743	.3658	.2686	.3429
5	.3582	.362	.4572	.3582	.3772	.3582	.4525
6	.4477	.543	.4334	.4477	.5601	.4477	.5373
7	.5373	.6335	.4477	.5373	.5658	.5373	.5144
8	.5373	.6068	.4334	.5373	.6602	.5373	.4525
9		.5316	.4572	.4477	.5716	.4572	.4287
10	.3658	.3544	.3544	.3658	.5716	.4525	.3658
11	.2715	.3658		.2629	.3658	.2601	.2858
12		.2715			.2743	.2658	
13	.2801	.2572	.2743	.2801	.2743	.2572	
14	.2801	.2601	.1829	.2715	.3658	.2686	
15	.2629	.2686	.1829	.2743	.3658	.2715	
16	.2715	.2715	.2743	.2772	.3658	.2572	
17	.3734	.2686	.3658	.3544	.3582	.3582	
18	.3658	.3467	.3658	.3544	.4477	.3658	
19	.443	.4382	.4572	.4477	.4477	.3582	
20	.4525	.4525	.4572	.443	.3658	.3467	
21	.3734	.3658	.3658	.3506	.3658	.2686	
22	.3734	.2629	.2589	.3658	.2743	.2743	
23	.2801	.2743	.2743	.3506	.2743		
24	.1829	.2715	.181	.1829	.2601	.1829	.1715
Max	.5373	.6335	.4572	.5373	.6602	.5373	.5373
Min	.1829	.2572	.1715	.1829	.2601	.1829	.1715
Avg	.3345	.3565	.3315	.3402	.3880	.3230	.3617

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204004 / 33 Kv PIMPARI DESHAMUKH

Feeder No / Name : 201 / 11KV Babhali AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	09-MAR-17
HR	Load (MW)
16	.5601
Max	.5601
Min	.5601
Avg	.5601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204004 / 33 Kv PIMPARI DESHAMUKH

Feeder No / Name : 202 / 11KV PIMPARI (D) AG SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	09-MAR-17
HR	Load (MW)
16	1.848
Max	1.848
Min	1.848
Avg	1.848

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204004 / 33 Kv PIMPARI DESHAMUKH

Feeder No / Name : 203 / 11KV PIMPARI (D) GT

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	09-MAR-17
HR	Load (MW)
16	.3734
Max	.3734
Min	.3734
Avg	.3734

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204004 / 33 Kv PIMPARI DESHAMUKH

Feeder No / Name : 204 / 11KV BABALI GT

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	09-MAR-17
HR	Load (MW)
16	.2801
Max	.2801
Min	.2801
Avg	.2801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204006 / 33KV BOBADE(TAKALI)

Feeder No / Name : 201 / 11KV SADEGAON SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-MAR-17
HR	Load (MW)
24	1.448
Max	1.448
Min	1.448
Avg	1.448

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204007 / 33 KV ZARI

Feeder No / Name : 201 / 11KV WADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	09-MAR-17
HR	Load (MW)
11	1.1269
12	1.2651
16	1.3032
Max	1.3032
Min	1.1269
Avg	1.2317

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204007 / 33 KV ZARI

Feeder No / Name : 202 / 11KV NANDAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	09-MAR-17
HR	Load (MW)
10	1.7337
Max	1.7337
Min	1.7337
Avg	1.7337

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204007 / 33 KV ZARI

Feeder No / Name : 204 / 11kv Venkateshwara Ginning NON SHEDDABLE EXPRESS HV FEEDERS
Exe Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	09-MAR-17
HR	Load (MW)
12	.1267
13	.112
16	.1448
Max	.1448
Min	.112
Avg	.1278

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204071 / 33KV JAMB

Feeder No / Name : 201 / 11KV Jamb

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3281	.2286	.2372	.1677	.1829	.2134	.2561
2	.3749	.2286	.2372	.2439	.2134	.2134	.2561
3	.3749	.2896	.2688	.2896	.2896	.2439	.2721
4	.3953	.3658	.3041	.442	.4115	.3437	.3521
5	.3953	.442	.4001	.5944	.5182		
6	.5535	.5944	.5761	.6706	.6554		
7	.8642	.884	.6562	.7164	.7621		
8	1.0526	.9907	.8162	.7926	.884		
9	1.065	.7011	.7926	.7316	.7926		
10	.7773	.5921	.6401	.6626	.9054		
11						.7042	.5639
12						.6401	.5792
13						.6401	.5335
14						.6241	.4572
15						.6081	.4572
16						.6562	.503
17	.2743	.3005		.3224	.442	.7202	.5487
18	.3658	.3637	.3201	.5087	.381	.6562	.5335
19	.4572	.4586	.3906	.503	.4268	.4641	.3506
20	.2896	.3479	.2968	.3688	.3353	.4001	.3506
21	.2896	.2372	.2623	.3185	.2591	.3521	.2743
22	.2591	.253	.2439	.2721	.2439	.3201	.2439
23	.2439	.253	.2286	.2623	.2286	.2561	.1981
24	.2286	.2286	.2214	.2134	.1829	.2134	.2561
Max	1.065	.9907	.8162	.7926	.9054	.7202	.5792
Min	.2286	.2286	.2214	.1677	.1829	.2134	.1981
Avg	.4772	.4311	.4054	.4489	.4508	.4594	.3881

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204071 / 33KV JAMB

Feeder No / Name : 202 / 11KV Sonna

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.503	.4725	.506	.4572	.4725	.3125	.3201
2	.503	.5182	.506	.5639	.5792	.3125	.3521
3	.5792	.5944	.5535	.5944	.5944	.3795	.4001
4	.6859	.6859	.6562	.7011	.6249	.4801	.4696
5						.5601	.5992
6						.7287	.9555
7						.8802	1.1012
8						1.2308	1.5223
9						1.2146	1.2193
10						.8855	1.2193
11		.9804	.9755	1.0387	1.1142		
12	1.2955	1.3125	1.0517	1.2178	1.3765		
13	1.2803	1.1385	.9012	.5792	1.3283		
14	1.2041	1.0437	.852	1.0269	1.2651		
15	1.0517	1.0911	.8684	1.0387	1.166		
16	1.1279	1.0437	1.0159	1.2178	1.2003		
17	1.1888	1.2334		1.3073	1.2803	.4641	.3353
18	1.1584	1.0911	.9922	.7291	1.1126	.5441	.3963
19	.6859	.7274	.7811	.7209	.4877	.7362	.5944
20	.6249	.6483	.6562	.6874	.4572	.5921	.6249
21	.6249	.6167	.571	.6796		.5761	.5792
22	.5792	.5851	.5639	.5761	.5182	.5281	.5182
23	.5182	.5693	.503	.5401	.4877	.5121	.4725
24	1.0517	.4725	.5535	.4725	.503	.2134	.5121
Max	1.2955	1.3125	1.0517	1.3073	1.3765	1.2308	1.5223
Min	.503	.4725	.503	.4572	.4572	.2134	.3201
Avg	.8625	.8236	.7357	.7860	.8569	.6195	.6773

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204071 / 33KV JAMB

Feeder No / Name : 203 / 11KV Parawa

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1562	.1829	.1718	.1372	.1219	.1829	.2105
2	.125	.1677	.1739	.1524	.1372	.1829	.208
3	.1562	.1829	.1739	.1829	.1677	.1981	.2267
4	.1581	.2134	.176	.1981	.1981	.2286	.2561
5	.2214	.2896	.192	.2591	.2591		
6	.253	.3201	.2881	.3201	.2896		
7	.3201	.3506	.3201	.381	.3048		
8	.421	.4115	.3841	.4115	.3353		
9	.4424	.4115	.4115	.3658	.3353		
10	.381	.3637	.381	.394	.3353		
11						.3681	.2743
12						.3041	.2439
13						.3361	.2591
14						.3521	.2591
15						.3005	.2286
16						.2688	.3048
17	.1524	.1875		.197	.2286	.3005	.2896
18	.1829	.1581	.208	.2883	.2134	.2846	.1524
19	.2591	.253	.2656	.285	.2591	.2721	.2591
20	.2286	.253	.25	.2515	.2286	.2688	.2591
21	.2286	.2372	.2315	.2155	.2286	.2721	.2591
22	.2134	.2056	.1981	.208	.2134	.2372	.2439
23	.1981	.2056	.1981	.2006	.2134	.2214	.2134
24	.1829	.1829	.1875	.1829	.1829	.1981	.2743
Max	.4424	.4115	.4115	.4115	.3353	.3681	.3048
Min	.125	.1581	.1718	.1372	.1219	.1829	.1524
Avg	.2378	.2543	.2477	.2573	.2362	.2654	.2457

From 08-MAR-17 and 14-MAR-17

Feeder No / Name : 201 / 11KV BHARASWADA AG	SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING	DESIGN TRANSFORMER

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.5021	1.1385	1.3441	.4744	1.0279		
16						1.3441	1.1069
Max	1.5021	1.1385	1.3441	.4744	1.0279	1.3441	1.1069
Min	1.5021	1.1385	1.3441	.4744	1.0279	1.3441	1.1069
Avg	1.5021	1.1385	1.3441	.4744	1.0279	1.3441	1.1069

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204081 / 33KV BRAMHPURI (SALAPURI)

Feeder No / Name : 202 / BRAMHAPURI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8						1.0155	1.1717
16	1.2811	1.2498	1.3441	1.1069	1.406		
24		.0324	.0633	.0328	.0324	.0492	.0492
Max	1.2811	1.2498	1.3441	1.1069	1.406	1.0155	1.1717
Min	1.2811	.0324	.0633	.0328	.0324	.0492	.0492
Avg	1.2811	.6411	.7037	.5699	.7192	.5324	.6105

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204081 / 33KV BRAMHPURI (SALAPURI)

Feeder No / Name : 203 / 11KV BRAMHPURI GT

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.8996	.9831	1.0513	.4239	.9012	.9431	1.0059
16	.7042	.6443	.5868	.5735	.9221	.6001	.6001
24	.8462	.6226	.5735	.503	.5087	.5087	.5144
Max	.8996	.9831	1.0513	.5735	.9221	.9431	1.0059
Min	.7042	.6226	.5735	.4239	.5087	.5087	.5144
Avg	.8167	.75	.7372	.5001	.7773	.6840	.7068

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204082 / 33KV Takali Kumbhkarn

Feeder No / Name : 201 / 11KV Aarvi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.663	.7459	.6783	.5761	.663	.9054	.823
2	.663	.7459	.7202	.583	.663	.9808	.823
3	.6962	.7625	.763	.6478	.7209	1.0185	.8573
4	.7209	.7865	.7716	.6802	.7127	1.2826	1.1888
5	.7537	.7865	.8573	.7935	.8288		
6	.9503	.7865	.9496	.9602	.9282		
7	1.0322	1.0883	1.1191	.9442	.9779		
8	1.2717	1.1984	1.3717	1.0722	1.4089		
9	1.4752	1.2955	1.4575	1.2163	1.4255		
10	1.2431		1.3717	1.2452	1.4582		
11						1.1603	.9945
12						1.1271	1.1271
13					.0514	1.2597	1.1142
14						1.2631	1.065
15						1.065	.9503
16						1.1336	1.065
17	.7468	.7716	.7545	.8589	1.086	1.2125	1.1142
18	.8676	.7783	.7922	.8962	1.1016	1.0631	1.0486
19	1.251	1.0974	1.3014	1.2323	1.2323	1.2803	1.226
20	1.307	1.0425	1.2449		1.1016	1.1888	1.2637
21	1.1506	1.0242	1.1506	1.0751	1.1203	1.0974	1.1694
22	1.1128	1.0425	1.0456	1.0562	1.094	.9511	1.1317
23	1.1128	1.0059	1.0082	.9997	.9808	.9511	1.0374
24	1.0374	1.0374	1.0059	.9896	.9808	.9054	.8779
Max	1.4752	1.2955	1.4575	1.2452	1.4582	1.2826	1.2637
Min	.663	.7459	.6783	.5761	.0514	.9054	.823
Avg	1.0031	.9409	1.0202	.9310	.9756	1.1025	1.0487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204082 / 33KV Takali Kumbhkarn

Feeder No / Name : 202 / 11KV Takali SINGLE PHASING

Feeder KV- 11 / INCOMING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3256	1.3957	1.3717	1.3443	1.1317	.6401	.6783
2	1.4563	1.4146	1.3717	1.5089	1.1317	.6802	.6859
3	1.6057	1.4901	1.4632	1.6804	1.2826	.6802	.6859
4	1.9044	1.7164	1.829	1.8298	1.4146	.7125	.7716
5						.8259	.8478
6						.8322	1.0288
7						.9602	1.2887
8						1.2125	1.6766
9						1.3094	1.6078
10		1.491				1.3108	1.5581
11	1.6078	1.491	1.5261	1.6712	1.8233		
12	1.8564	1.7328	1.6108		1.989	1.0562	
13	1.9669		1.1022	1.2944	1.9662	1.0185	
14	1.8652	1.7404	1.4089	1.7368	1.9393	1.094	
15	1.7404	1.4413	1.286	1.6549	1.9062	1.0374	
16	1.8461	1.6804	1.3565	1.6804	1.9719	1.0751	
17	1.8842	1.7974		1.8138		1.1694	1.307
18	1.8564	1.7465	1.2146	1.8187	1.1405	1.3575	.2427
19	1.8298	1.6461	1.7737	1.643	1.8111	1.7924	1.8861
20	1.8484	1.829	1.8484	1.7541	1.6617	1.6827	1.8296
21	1.6598	1.6461	1.7164	1.6221	1.4937	1.5546	1.6975
22	1.5655	1.5546	1.5684	1.531	1.4003	1.3169	1.6975
23	1.4335	1.4632	1.419	1.3014	1.307	1.2437	1.3769
24	1.3256	1.3957	1.3575	1.3256	1.2323	1.2323	1.1888
Max	1.9669	1.829	1.8484	1.8298	1.989	1.7924	1.8861
Min	1.3256	1.3957	1.1022	1.2944	1.1317	.6401	.2427
Avg	1.6988	1.5929	1.4838	1.6006	1.5649	1.1215	1.2253

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204082 / 33KV Takali Kumbhkarn

Feeder No / Name : 203 / AKASHAWANI EXP.

SHEDDABLE RURAL

Feeder KV- 11 / INCOMING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.0526	.0351	.0514	.0526	.0532	.0532	.0514
7	.0526	.0526	.0514	.0526	.0532	.0532	.0514
8	.0514	.0532	.0514	.0532	.0532	.0532	.0514
9	.0514	.0532	.0514	.0526	.0532	.0532	.0514
10	.0526	.0532	.0514	.0532	.0514	.0532	.0532
11	.0514	.0532	.0514	.0532	.0514	.0532	.0532
12	.0514	.0532	.0514	.0532	.0514	.0532	.0532
13	.0514	.0532	.0514	.0532	.0514	.0526	.0532
14	.0514	.0514	.0514	.0532	.0514	.0354	.0354
18	.0526	.0514	.0526	.0532	.0526	.0686	.0532
19	.0532	.0514	.0526	.0532	.0526	.0526	.0526
20	.0532	.0514	.0526	.0532	.0526	.0514	.0526
21	.0532	.0514	.0526	.0532	.0526	.0514	.0526
22	.0532	.0514	.0526	.0532	.0526	.0532	.0532
23	.0532	.0514		.0532	.0532	.0532	.0526
Max	.0532	.0532	.0526	.0532	.0532	.0686	.0532
Min	.0514	.0351	.0514	.0526	.0514	.0354	.0354
Avg	.0523	.0511	.0518	.0531	.0524	.0527	.0514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204082 / 33KV Takali Kumbhkarn

Feeder No / Name : 204 / 11KV Express-Success Cotton NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.0943	.2126	.2987	.0943	.112	.0686
2	.2614	.0377	.2126	.1867	.0943	.112	.0686
3	.2587	.0943	.2126	.1867	.1132	.112	.0686
4	.2614	.0943	.2481	.1867	.1132	.112	.0686
5	.2587	.0943	.2279	.1867	.0943	.112	.0686
6	.2614	.0943	.2229	.2241	.1132	.0747	.0686
7	.2614	.0943	.2401	.2614	.1132	.0747	.0686
8	.2303	.0943	.1372	.2801	.2263	.0943	.12
9	.2103	.0943		.2801	.2614	.0943	.1029
10	.2058	.0943	.2058	.2614	.2401	.0754	.1698
11	.3366	.1698	.2058	.2987	.2454	.0754	.1698
12	.2103	.1698	.2629	.2987	.2658	.0943	.1698
13	.2103	.1509	.2279	.3174	.2401	.0943	.1698
14	.2401	.1543	.2103	.112	.2401	.0754	.1698
15	.2572	.1543	.2229	.1132	.2279	.0566	.2427
16	.2614	.1372	.2401	.1509	.2401	.0566	.2641
17	.2241	.1543	.1867	.0943	.2401	.0566	.2427
18	.2241	.1417	.1867	.1494	.2801	.0686	
19	.2241	.1595	.3734		.0747	.0686	.2452
20	.1132	.0709	.1867	.0943	.0747	.0709	.1132
21	.0943	.2126	.2987	.1132	.112	.0709	.2452
22	.0943	.2481	.2427	.1509	.112	.0701	.2614
23	.0943	.2481	.2801	.2614	.112	.0701	.2614
24	.3734	.0943	.2303	.2801	.1132	.112	.0686
Max	.3734	.2481	.3734	.3174	.2801	.112	.2641
Min	.0943	.0377	.1372	.0943	.0747	.0566	.0686
Avg	.2262	.1313	.2293	.2081	.1684	.0839	.1520

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204083 / 33KV Tradhara (Rahati)

Feeder No / Name : 201 / 11KV Aasola AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / INCOMING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5668		1.1803	.7552		.472	.6775
2	.5668		1.1763	.5297		.5138	.6752
3	.6878		1.1803	.6048		.5664	.8411
13	1.3216	1.1336	1.2839	1.2272	1.0395		.756
14	.945	1.2574	1.2297	1.2865	1.1133		.944
16							.756
20					.5664		
21		1.2646	.567		.5641	.8431	1.0395
22		1.2631	.6048		.4282		.944
23		1.2631	.5664		.473		.9459
24	.5668		1.0898	.756		.378	.6752
Max	1.3216	1.2646	1.2839	1.2865	1.1133	.8431	1.0395
Min	.5668	1.1336	.5664	.5297	.4282	.378	.6752
Avg	.7758	1.2364	.9865	.8599	.6974	.5547	.8254

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204083 / 33KV Tradhara (Rahati)

Feeder No / Name : 202 / 11KV Tridhara AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0492			.1136		.0944	.0945
2	.0486			.0945		.0944	.0943
3	.0724			.0947		.0944	.0945
8	1.4091			2.1546		1.9905	1.8442
9				2.3412		2.268	
10	1.9951	2.1845	2.1924	2.3837	2.2266		2.1778
11	1.985	2.2231	2.209	2.268	2.2657		2.1546
12			2.2868				
15	2.141	2.2043	1.9636	2.1778	2.268		1.9069
16	2.3952	2.2634	2.3861	2.3837			2.0621
17	2.6406	2.2762	2.2915	2.3978	2.4569		2.1924
18	2.7377	2.3605	2.1924	2.3672	2.268		2.1924
19			2.1567	2.3081	2.0769		2.1589
20			.1136		.188	.0914	
21			.0947		.1126		.0758
22			.0758		.0914		.0944
23			.0946		.0942		.0946
24	.0648			.0755		.0944	.0943
Max	2.7377	2.3605	2.3861	2.3978	2.4569	2.268	2.1924
Min	.0486	2.1845	.0758	.0755	.0914	.0914	.0758
Avg	1.4126	2.252	1.5048	1.6277	1.4048	.6754	1.1554

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204083 / 33KV Tradhara (Rahati)

Feeder No / Name : 203 / 11KV Express-Omkar Ginning NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1296			.152			.019
2	.1296			.1903			.019
3	.1448			.1899			.019
4	.1448			.1898			.019
5	.1311			.1141			.019
6	.1457			.2277			.019
7	.1448			.2279			.057
8	.1296			.0761			.019
9	.1311			.038			
10	.0379	.019	.038	.019	.0189		.019
11	.0379	.038	.019	.019	.019		.019
12	.0189	.019	.019	.019	.019		.019
13	.0189	.019	.019	.019	.019		.019
14	.019	.019	.019	.038	.019		.019
15	.019	.019	.019	.019	.019		.019
16	.0189	.019	.019	.019	.019		.038
17	.019	.019	.0378	.019	.019		.019
18	.0189	.019	.019	.019	.0189		.019
19			.019	.019	.019		.019
20			.1518		.019	.019	.019
21			.2284		.0189		.1523
22			.1521		.0189		.152
23			.1518		.019		.1521
24	.1296			.1141			.0189
Max	.1457	.038	.2284	.2279	.019	.019	.1523
Min	.0189	.019	.019	.019	.0189	.019	.0189
Avg	.0826	.0211	.0651	.0864	.0190	.019	.0388

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204083 / 33KV Tradhara (Rahati)

Feeder No / Name : 204 / 11KV Tridhara Gauthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8097		.9263	1.2839		1.1351	.9221
2	.8097		1.0082	1.1718		.9072	1.0117
3	.905		.9305	1.0405		.944	1.0128
4	.905		1.0082	1.0762		1.0395	1.1736
5	.9503		.9274	1.134		1.0384	1.096
12	1.0395	1.0117	1.173	.9459	1.1647		.8703
13	.8496	1.0128	1.0206	.9818	.6548		.8307
14	.7186	1.0105	.9063	.8694	1.2248		.8127
15	.8513	.9221	.9081	.8685	1.2272		.9063
16	.944	.9263	.6048	.793	1.134		.9459
17				.7946			
18				.5287			
19				1.0206			
20		.9284	1.2852		1.2272	1.266	1.3608
21		1.0128	1.0784		1.1989		1.0962
22		1.0059	1.1351		1.323		.944
23		.9274	1.134		1.134		1.0216
24	.8097		1.0094	1.2297		1.134	.9284
Max	1.0395	1.0128	1.2852	1.2839	1.323	1.266	1.3608
Min	.7186	.9221	.6048	.5287	.6548	.9072	.8127
Avg	.8720	.9731	1.0037	.9813	1.1432	1.0663	.9955

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204084 / 33KV PIMPALGAON THOMBRE

Feeder No / Name : 201 / 11Kv Umari GT

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.2241	.2241	.2614	.2987	.2614	.3361	.4481
5	.6348	.3361	.3361	.2614	.6348	.4481	.2987
8						.4854	
10	.2614	.1867	.2614	.3734			.4854
11						.1395	
12							.3361
13	.1867	.1494	.1867	.3734			
14						.2241	.2401
16							.2241
17	.2241	.2614	.2614	.3361		.4108	
19			.4481	.5601			.4854
20	.2241	.2987				.3361	
21			.2614	.4108			.3734
22						.4854	
23	.1494	.1867	.1867	.2614		.3361	.2614
24	.2614	.1494	.1867	.1867	.2614	.2614	.3734
Max	.6348	.3361	.4481	.5601	.6348	.4854	.4854
Min	.1494	.1494	.1867	.1867	.2614	.1395	.2241
Avg	.2708	.2241	.2655	.3402	.3859	.3463	.3526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204084 / 33KV PIMPALGAON THOMBRE

Feeder No / Name : 202 / 11Kv Umari AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
14	1.1622	1.0924	.9995	1.1041	1.1622	1.2087	1.6804
16		1.2784	1.1854	1.5689	2.2405	1.1157	1.2784
17	1.6842	1.3946					
18			1.0924	2.2405	1.8671	1.1157	
19	1.1622						1.1622
20		.9297	.8368	1.046		.8833	
21	.9762				1.2323	.9762	.8368
Max	1.6842	1.3946	1.1854	2.2405	2.2405	1.2087	1.6804
Min	.9762	.9297	.8368	1.046	1.1622	.8833	.8368
Avg	1.2462	1.1738	1.0285	1.4899	1.6255	1.0599	1.2395

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204084 / 33KV PIMPALGAON THOMBRE

Feeder No / Name : 203 / 11Kv Surpimpri Ag
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3					.2614		
5					.6348		
6	.3109	.2073	.2073	.2073	.2073	.2241	.2591
7					.3887		
8		.4146	.3887	.4405			.3628
9	.5182				.5601	.4146	
10			.4146	.57	.2987		.4405
11	.5182	.5182			.7468	.4664	
12			.4664	.5441			.5182
13	.4923	.4405			.7468	.8291	
16					.3734		
19					.3734		
21					.2614		
23					.2614		
24					.2614		
Max	.5182	.5182	.4664	.57	.7468	.8291	.5182
Min	.3109	.2073	.2073	.2073	.2073	.2241	.2591
Avg	.4599	.3952	.3693	.4405	.4135	.4836	.3952

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204029 / 33 KV VIDYANAGAR

Feeder No / Name : 201 / 11 KV SHIVAJI CHOWK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6595	1.8605	1.8137	1.6233	1.5745	1.5897	1.528
2	1.6328	1.7943	1.7558	1.5661	1.5166	1.56	1.5291
3	1.6869	1.7692	1.7276	1.5771	1.5352	1.5379	1.5289
4	1.7139	1.7789	1.7505	.884	1.5554	1.528	1.5703
5	1.773	1.8064	1.8946	1.6717	1.6137	1.6186	1.6107
6	2.0302	1.9329	2.2383	1.8568	1.7856	1.8412	1.8629
7	2.3793	2.4534	2.5644	2.2196	1.8835	1.9997	2.239
8	2.3777	2.4713	2.6848	2.4014	2.2257	2.0964	2.3842
9	2.4536	2.504	2.766	2.3831	2.4703	2.1582	2.4318
10	2.5194	2.4246	2.6845	2.3625	2.5446	2.4332	2.493
11	2.601	2.57	2.8857	2.4782	2.4825	2.2562	2.6936
12	2.4783	2.5247	2.9722	1.2818	2.4059	2.0952	2.5761
13	2.5141	2.4958	2.6048	2.8761	2.3754	1.9113	2.5027
14	2.5011	2.3777	1.4174	2.6459	2.242	1.8273	2.4387
15	2.4406	2.351	2.2687	2.4074	2.1201	1.7248	2.3913
16	2.4536	2.3915	2.364	2.3518	2.0934	1.6377	2.2739
17	2.5961	2.5278	2.2787	2.2693	2.2192	2.0283	2.364
18	2.7584	2.6879	2.5279	2.4999	2.3808	2.1795	2.5625
19	3.3809	3.2793	3.3512	3.4487	2.902	2.5941	2.9642
20	3.3773	3.3032	3.2954	3.5013	2.7458	2.3747	2.9828
21	3.0017	2.9851	3.032	3.1718	2.4767	2.1429	2.9142
22	2.5612	2.6475	2.4654	2.5446	2.0866	1.9887	2.4097
23	2.2108	2.1613	2.0919	2.1655	1.957	1.8446	1.9894
24	1.9087	1.9542	1.9258	1.8233	1.6576	1.6682	1.7082
Max	3.3809	3.3032	3.3512	3.5013	2.902	2.5941	2.9828
Min	1.6328	1.7692	1.4174	.884	1.5166	1.528	1.528
Avg	2.3754	2.3772	2.3901	2.2505	2.1188	1.9432	2.2479

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204029 / 33 KV VIDYANAGAR

Feeder No / Name : 202 / 11 KV PARDESHWAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5106	.5331	.5465	.4561	.4333	.4588	.2684
2	.4847	.497	.5274	.4648	.4218	.4489	.4488
3	.494	.4917	.4847	.4603	.4119	.4458	.4597
4	.5057	.4687	.4771	.4749	.4397	.439	.4521
5	.5563	.5401	.5221	.5034	.4496	.4779	.4767
6	.6146	.6228	.7042	.5655	.5118	.5479	.5202
7	.6847	.7324	.7522	.7255	.6397	.6226	.7172
8	.7568	.8173	.8261	.7083	.753	.6988	.7659
9	.7545	.7144	.7735	.7137	.6984	.7346	.7022
10	.6691	.6226	.6661	.6691	.6824	.6678	.6662
11	.5602	.5644	.572	.5564	.628	.6135	.5575
12	.4931	.5297	.543	.2812	.5525	.5706	.497
13	.4542	.4878	.4946	.679	.487	.5683	.478
14	.484	.4115	.4188	.5663	.4923	.4885	.478
15	.4828	.4466	.4374	.5114	.4557	.422	.4481
16	.4726	.4893	.4073	.4413	.4496	.4106	.4427
17	.4795	.5167	.4389	.4765	.4824	.4744	.4671
18	.5609	.5601	.5226	.5064	.5221	.5236	.5031
19	.7108	.7171	.6795	.7051	.6889	.6981	.6566
20	.7743	.8029	.7789	.7137	.7209	.7339	.7392
21	.7367	.7766	.7388	.6931	.6706	.6653	.7873
22	.707	.7468	.7251	.6386	.618	.6081	.7213
23	.6655	.647	.6447	.5705	.5548	.5621	.5862
24	.5598	.5735	.5625	.5423	.4824	.5234	.5136
Max	.7743	.8173	.8261	.7255	.753	.7346	.7873
Min	.4542	.4115	.4073	.2812	.4119	.4106	.2684
Avg	.5905	.5963	.5935	.5676	.5520	.5585	.5564

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204029 / 33 KV VIDYANAGAR

Feeder No / Name : 203 / 11 KV POLICE QUARTER SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9016	.8758	.8703	.8063	.7842	.7972	.8406
2	.9141	.8372	.8947	.8349	.7697	.7842	.8638
3	.9789	.8318	.8429	.8535	.7922	.7827	.9339
4	1.0159	.801	.8787	.8821	.8615	.7766	.9694
5	1.0955	.9318	1.0456	.9873	.9397	.8452	1.0368
6	1.3169	1.2639	1.4823	1.1698	1.1123	1.0639	1.2696
7	1.6499	1.6484	1.7749	1.6278	1.4994	1.3412	1.5318
8	1.656	1.6656	1.9471	1.6214	1.7734	1.608	1.7178
9	1.6507	1.5638	1.7231	1.6252	1.7722	1.5181	1.741
10	1.4677	1.3779	1.6313	1.4319	1.7258	1.4922	1.3371
11	1.2658	1.203	1.3864	1.3344	1.4388	1.4127	1.3236
12	1.073	.9618	1.2864	.5975	1.3512	1.2422	1.114
13	.9853	.9176	1.1172	1.2026	1.1942	1.1891	.9993
14	.9191	.8261	.9397	1.0852	1.0875	1.0275	.9427
15	.8993	.8726	.844	.9312	1.086	.9336	.9025
16	.9	.9222	.8326	.9419	1.0387	.8985	.8934
17	.9835	1.0212	.9282	.9688	1.1507	1.1149	.9061
18	1.1005	1.278	1.1222	1.1258	1.2415	1.2011	1.0665
19	1.4428	1.4388	1.4103	1.4291	1.3915	1.4182	1.2834
20	1.4234	1.4182	1.4642	1.4364	1.2788	1.3642	1.3516
21	1.3967	1.3245	1.2977	1.219	1.1492	1.2376	1.352
22	1.2336	1.2376	1.1717	1.1165	1.0364	1.1176	1.1915
23	1.0633	1.0349	1.0155	1.001	.8924	.964	1.0391
24	.932	.9254	1.4358	.8669	.8288	.8589	.8551
Max	1.656	1.6656	1.9471	1.6278	1.7734	1.608	1.741
Min	.8993	.801	.8326	.5975	.7697	.7766	.8406
Avg	1.1777	1.1325	1.2226	1.1290	1.1748	1.1246	1.1443

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204030 / 33KV MIDC

Feeder No / Name : 201 / 11 KV Super Market Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			.6516		.788	.6878	
3				1.1041			.7522
4			.8688			.724	
5		1.1946		1.2851	.9671		
6			1.3213	.3403	1.1104	.905	1.3969
7				1.5402	1.576	1.2308	
8			1.3969	1.3432	1.4327	1.2308	1.4327
9				.9671			
10	.8775		.9671			1.0387	.7522
11	.788	.8238		.8954			
12			.7164	.8596		1.0745	
13				.8238	.8688		
14		.7164	.6984	.8059		.8145	
15				.788	1.267		.6984
16		.788	.6805			.7602	
17				.788	1.0498		
18		1.0498	.9774	.8954			.8596
19		1.2308		1.3611			1.3253
20		1.3032	1.3969		1.3213		
21		1.2308					1.1462
22			1.1104		.9231	.8688	1.1104
24		.9671	.8688	.9955	.7602		.8238
Max	.8775	1.3032	1.3969	1.5402	1.576	1.2308	1.4327
Min	.788	.7164	.6516	.3403	.7602	.6878	.6984
Avg	.8328	1.0338	.9712	.9862	1.0968	.9335	1.0298

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204030 / 33KV MIDC

Feeder No / Name : 202 / 11KV SHIVAJI COLLEGE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			1.182		1.0974	1.1104	
3				1.2894			
4			1.2178			1.0387	
5		1.3253		1.4148	1.0608		1.39
6			1.379		1.134	1.0387	1.4632
7					1.4266	1.2536	
8			1.5181		1.5729	1.2178	1.5364
10	1.2803		1.3169			1.134	1.4266
11		1.4266			1.2536		
12			1.3169			1.1157	1.2803
13					1.182		
14		1.2803	1.2071			1.0029	
15					1.0745		
16		1.3169	1.2803			.9313	1.2803
17				1.2071	1.1104		
18		1.4148	1.4685	1.2437			1.4998
19		1.7551		1.6095			1.8473
20		1.7193	1.4864	1.6461	1.4327		
21		1.6118					1.6095
22				1.4632	1.2536	1.3073	1.4998
23				1.39			
24		1.3352	1.2308	1.3253	1.2803	1.182	1.2254
Max	1.2803	1.7551	1.5181	1.6461	1.5729	1.3073	1.8473
Min	1.2803	1.2803	1.182	1.2071	1.0608	.9313	1.2254
Avg	1.2803	1.4650	1.3276	1.3988	1.2399	1.1211	1.4599

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204030 / 33KV MIDC

Feeder No / Name : 203 / 11KV PINGALI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			.8322		.7392	.7164	
3				1.0059			
4			1.2483			.8322	
5		1.643		1.5089	1.0349		
6			1.595		1.4415	1.1789	1.5893
7					1.7741	1.6297	1.7741
8			1.7002		1.922	1.5604	1.3306
10	1.2197		1.1088			1.2936	1.3306
11		1.1827			1.387		
12			.8871			1.1088	.9979
13					1.1443		
14		1.0349	.7392			.9189	
15					1.1443		
16		1.1088	1.1088			.9189	1.0719
17				1.1827	1.2483		
18		1.3413	1.1736	1.4784			1.4784
19		1.4754		1.5524			1.6632
20		1.4403	1.3748	1.5154	1.4563		
21		1.3523					1.1827
22				1.0349	.9536	.9709	1.1088
24		1.0349	1.0056	.9054	.961	.8322	.961
Max	1.2197	1.643	1.7002	1.5524	1.922	1.6297	1.7741
Min	1.2197	1.0349	.7392	.9054	.7392	.7164	.961
Avg	1.2197	1.2904	1.1612	1.273	1.2672	1.0874	1.3171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204030 / 33KV MIDC

Feeder No / Name : 204 / 11 KV MIDC Feeder

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			.8402		.7282	.7095	
3				1.0082			
4			.8962			.6722	
5		.8962		1.1203	.7282		
6			1.0082		.7628	.6908	.3641
7					.8322	.4854	.5548
8			1.0402		1.0056	.3361	.6935
10	1.8031		1.6297			.3121	1.1443
11		.8238			1.4563		
12		1.0402	1.9071			.3121	1.387
13					1.6057		
14		1.1096	1.6991			.3547	1.3389
15					1.307		
16		.9015	1.6644			.3734	1.6297
17				1.6644	.9709		
18		.7282	1.3443	1.3523			1.387
19		.5601		1.2136			1.2483
20		.4854	1.1576	.9362	.8962		
21		.6722					.9362
22			1.1576	1.0056	.7842	.3734	1.0056
24		.9709	.7468	1.0082	.9362	.7468	.3121
Max	1.8031	1.1096	1.9071	1.6644	1.6057	.7468	1.6297
Min	1.8031	.4854	.7468	.9362	.7282	.3121	.3121
Avg	1.8031	.8188	1.2576	1.1636	1.0011	.4879	1.0001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204030 / 33KV MIDC

Feeder No / Name : 205 / 11KV Laxmi Ginning Express

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2					.0189	.0362	
3				.0754			
5		.0189		.0377	.0189		
6			.0362			.0362	.0377
7					.0189		
8					.0189		.0943
10	.0566					.1509	
11		.0566					
12						.1509	
14		.1509	.0754			.1086	
15		.1132			.0543		
16			.0754			.1448	.0943
17				.0943	.0724		
18		.0377	.0377	.0754			.1132
19		.0362		.0566			.0943
20		.0362	.1509	.0943	.0724		
21							.0943
22				.0943	.0362	.0181	.0754
23				.0754			
24		.0189		.1132	.0754	.0362	
Max	.0566	.1509	.1509	.1132	.0754	.1509	.1132
Min	.0566	.0189	.0362	.0377	.0189	.0181	.0377
Avg	.0566	.0586	.0751	.0796	.0429	.0852	.0862

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204030 / 33KV MIDC

Feeder No / Name : 206 / 11KV Water Supply
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.3429		.3772	.3429	
3			.3521			
4		.3429			.3429	
5	.4024		.3521	.3944		.3601
6		.3429	.3772	.3944	.3429	.3601
7			.3772	.3944	.3429	
8		.3429	.3772	.3429	.3429	.3601
9			.4115			
10		.4115	.3772		.3429	.3429
11			.3772			
12		.4115	.3772		.3429	.3429
13				.3429		
14		.3772			.3601	.2058
15				.3601		
16		.3772			.3601	.3429
17			.3429	.3601		
18	.3688	.3521	.0686			.3944
19	.3856		.3772			.3944
20	.3772	.3688	.3772	.3601		
21	.3772					.4115
22		.2012	.3944	.2058	.3944	.4115
23			.4115			
24	.4115	.3601	.3353	.2058	.3429	.3944
Max	.4115	.4115	.4115	.3944	.3944	.4115
Min	.3688	.2012	.0686	.2058	.3429	.2058
Avg	.3871	.3526	.3554	.3398	.3507	.3601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204030 / 33KV MIDC

Feeder No / Name : 207 / ADM-EXPRESS(MKV)

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			.0351		.0347	.0175	
3				.0347			
4			.0351			.0351	
5		.0358			.0347		.0347
6			.0351			.0351	.0347
7					.0347	.0351	
8					.0347	.0351	.0347
10						.0347	.052
11					.0175		
12						.0347	.052
13					.0175		
14			.0347			.0351	
15					.0175		.0347
16			.0347			.0175	.0347
17				.0347	.0351		
18		.0173	.0347	.0347			.0347
19		.0351		.0347			.0347
20		.0351	.052	.0347			
21		.0343					.0347
22			.052	.0347	.0351	.0351	.0347
24	.052		.0351	.0347	.0347	.0351	.0347
Max	.052	.0358	.052	.0347	.0351	.0351	.052
Min	.052	.0173	.0347	.0347	.0175	.0175	.0347
Avg	.052	.0315	.0387	.0347	.0296	.0318	.0376

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204057 / 33 KV MKV -1

Feeder No / Name : 201 / 11KV SAKHALA PLOT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4344	.4706	.439	.362	.5121	.3292
2		.4344	.3982	.439	.362	.439	.3292
3	.3658	.4344	.3982	.439	.4706	.439	.3292
4		.4887	.3982	.4938	.4706	.439	.439
5		.5792	.5068	.5487	.5249	.5121	.4938
6	.6584	.6335	.8688	.7316	.9412	.5487	.6584
7		.8326	1.0136	1.0059	1.0498	.9511	.8779
8		.6878	.9412	.9328	1.0136	.9877	.8779
9	.905	.7316	.9412	.7964	.9145	.9145	.8145
10	.8688	.6219	.905	.7964	.823	.695	.724
11	.5792	.567	.7964	.6878	.7316	.6584	.543
12	.5792	.4572	.5068	.5792	.6584	.6401	.4887
13	.5068	.3475	.4525	.5068	.5487	.567	.4668
14	.5068	.2926	.4525	.4706	.5121	.439	.4525
15		.2926	.362	.4344	.439	.4572	.4163
16		.3475	.4706	.5068	.5853	.4938	.362
17	.4344	.3982	.6401	.5792	.5853	.4938	.4572
18	.6335	.724	.5853	.6335	.8779	.6036	.7316
19	1.0136	.9412	.9145	.8145	.8779	.7682	.9145
20	.7783	.7964	.9877	.6516	.8048	.6036	.7316
21	.5973	.6878	.7316	.4163	.695	.4938	.823
22	.543	.5792	.695	.4163	.6219	.439	.5487
23	.4887	.543	.5487	.4163	.5853	.3841	.4572
24		.4887	.5068	.4938	.3982	.5487	.3292
Max	1.0136	.9412	1.0136	1.0059	1.0498	.9877	.9145
Min	.3658	.2926	.362	.4163	.362	.3841	.3292
Avg	.6306	.5559	.6455	.5929	.6606	.5845	.5665

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204057 / 33 KV MKV -1

Feeder No / Name : 203 / 11 KV S.T. WORKSHOP FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.7737	1.8461	1.9204	1.6832	1.9204	1.8656
2		1.7737	1.8461	1.9204	1.6832	1.8656	1.8656
3	1.7375	1.7737	1.8461	1.9204	1.7375	1.8656	1.8656
4		1.8461	1.8461	2.0302	1.6651	1.8839	1.9753
5		2.19	2.0814	2.1948	1.828	2.1033	2.2497
6	2.9264	2.8416	2.7511	2.6155	2.914	2.268	2.524
7		3.3484	3.1855	3.4019	3.2036	2.8532	3.2556
8		3.2217	2.9683	3.3288	3.2398	2.8166	3.2922
9	2.8959	2.7801	2.7873	2.7873	3.0544	2.9264	2.8597
10	2.3891	2.5789		2.4253	2.7252	2.9995	2.5158
11	2.2805	2.396	2.6787	2.2443	2.3594	2.7435	2.19
12	2.0995		2.19	2.0814	2.2314	2.4874	2.0814
13	1.9004	1.9204	1.8099	1.9004	2.1033	2.3228	2.0271
14	1.9004	2.0851	1.8099	1.7375	1.7924	2.1216	2.009
15	1.9004	1.9936	1.8823	1.7375	1.957	2.0668	1.8642
16	1.9004	2.0485	2.0271	1.9004	2.4143	2.1765	1.9909
17	2.0814	2.2624	2.268	1.9004	2.6703	2.4508	2.268
18	2.6968	2.3529		2.5158	2.6703	2.7435	2.9264
19	3.2217	2.8959	2.3411	3.1493	2.7069	3.1276	2.9264
20	2.5339	2.4977	2.6155	2.8416	2.4508	2.6886	2.652
21	2.19	2.2805	3.1093	2.9502	2.3411	2.3045	2.4691
22	2.2443	1.9909	2.3045	2.6787	2.268	2.2131	2.1948
23	2.1719	1.9004	2.0302	2.4253	2.1582	2.0485	2.0119
24	2.0119	2.0452	1.9004	1.9204	2.0633	2.1033	1.9753
Max	3.2217	3.3484	3.1855	3.4019	3.2398	3.1276	3.2922
Min	1.7375	1.7737	1.8099	1.7375	1.6651	1.8656	1.8642
Avg	2.2824	2.2955	2.2784	2.3553	2.3300	2.3792	2.3273

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204057 / 33 KV MKV -1

Feeder No / Name : 205 / 11KV G & P EXPRESS FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4344	.1086	.439	.3982	.1463	.0549
2		.4344	.1086	.439	.3982	.1097	.0549
3	.4572	.4344	.1086	.439	.3982	.1097	.0549
4		.4344	.1086	.4938	.4525	.1097	.0549
5		.4525	.1086	.5487	.4525	.0914	.0549
6	.5487	.4525	.1448	.5304	.362	.1097	.0549
7		.362	.181	.5853	.362	.1463	.0549
8		.181	.181	.5487	.181	.1463	.0549
9	.724	.0914	.3258	.543	.1829	.1463	.4163
10	.8688	.0914	.724	.724	.2195	.181	.5249
11	.724	.0914	.724	.7964	.3109	.1646	.543
12	.6878	.0914	.905	.7964	.3292	.0732	.8145
13	.7964	.0914	.7964	.6516	.3292	.0366	.7421
14	.7964	.0914	.6878	.724	.2561	.0549	.6878
15	.6878	.0914	.8326	.7964	.3292	.0366	.724
16	.7964	.0914	.8326	.6154	.2378	.0549	.8869
17	.7964	.1448	.8413	.6154	.2378	.0549	.9145
18	.724	.181	.7316	.6154	.2378	.0549	.9145
19	.724	.181	.6767	.543	.2378	.0549	.4572
20	.6335	.181	.6036	.543	.1829	.0549	.3658
21	.543	.181	.3658	.4525	.1829	.0549	.5487
22	.3801	.1448	.4572	.4525	.1829	.0549	.5487
23	.3801	.1448	.4938	.4311	.1829	.0549	.6201
24	.5487	.3801	.1448	.4938	.4163	.1829	.0549
Max	.8688	.4525	.905	.7964	.4525	.1829	.9145
Min	.3801	.0914	.1086	.4311	.181	.0366	.0549
Avg	.6565	.2273	.4664	.5757	.2942	.0952	.4251

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204057 / 33 KV MKV -1

Feeder No / Name : 402 / 33KV O/G MKV-MIDC Link

SHEDDABLE RURAL

Line Feeder KV- 33 / INCOMING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.7375	1.5364	1.6461	1.6289	1.5364	1.5364
2		1.7375	1.5364	1.6461	1.6289	1.5364	1.5364
3	1.9204	1.7375	1.5364	1.6461	1.6289	1.5364	1.5364
4		1.9004	1.5364	1.7558	1.9004	1.5364	1.6461
5		2.1719	1.6461	1.8656	2.1719	1.6461	1.6461
6	2.4691	2.4434	1.6461	10.3156	2.7149	1.6461	1.7558
7		2.7149	1.7558	13.1688	1.5718	1.7558	1.8656
8		2.7149	2.1948	13.2785	3.1493	1.8656	1.8656
9	2.1948	2.5789	2.1719	10.4253	2.1948	1.9753	1.7375
10	2.1948	1.7558	2.4434	9.9863	1.6461	1.8656	1.9547
11	2.1948	1.3717	2.6063	7.2428	1.4266	1.7558	2.1719
12	2.1948	1.3169	2.3891	7.2428	1.3169	1.7558	2.0633
13	2.0851	1.3169	2.1719	7.2428	1.3169	1.6461	1.9753
14	2.0851	1.3169	2.009	7.1331	1.4266	1.5364	1.8461
15	2.0851	1.3717	1.9004	7.1331	1.4266	1.4266	1.7375
16	2.0851	1.4266	1.9004	7.1331	1.4266	1.3717	1.6289
17	2.0633	1.5364	1.9204	7.1159	1.5364	1.5364	1.6461
18	2.2805	1.8656	1.5912	7.6589	1.5364	1.8656	2.1948
19	2.6063	1.8656	1.8107	8.4734	1.7558	1.9753	2.4691
20	2.1719	1.8656	1.7558	10.9454	1.7558	2.0851	2.1948
21	2.0633	1.8656	1.7558	8.0933	1.8107	1.9753	2.1948
22	2.0633	1.7558	1.7558	7.9304	1.7558	1.8656	2.1948
23	1.9547	1.6461	1.6461	7.6589	1.6461	1.7558	2.1948
24	1.9204	1.8461	1.6461	7.1331	1.9004	1.6461	1.6461
Max	2.6063	2.7149	2.6063	13.2785	3.1493	2.0851	2.4691
Min	1.9204	1.3169	1.5364	1.6461	1.3169	1.3717	1.5364
Avg	2.1463	1.8275	1.8693	7.2446	1.7614	1.7124	1.8850

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204061 / 33KV KHANDOBA

Feeder No / Name : 201 / 11 KV NATRAJ FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1203	1.0631			1.0164	1.0745
2		1.1203	1.0745			.9145	1.086
3		1.1203	1.086			.9145	1.086
4		1.1203	1.1765			.9145	1.1765
5		1.2136	1.267			1.0164	1.2936
6		1.3717	1.4784			1.1088	1.4784
7		1.829	1.848			1.4632	1.7556
8	1.8099	1.829	1.829	1.7194		1.5546	1.7556
9	1.6289	1.7375	1.829	1.6289		1.587	1.5546
10	1.448			1.448			1.4632
11			1.6632	1.3575			1.3717
12	1.267		1.4632	1.1145			1.1888
13	1.1765		1.386	1.086			1.1888
14			1.2936	.9955			1.0974
15			1.2012	1.0164			1.0974
16		1.086	1.1088	.9955		1.1888	1.1088
17	1.4632	1.267		.0165	1.3717	1.267	
18	1.6804	1.448			1.4937	1.4784	
19	1.8671	1.7375			1.2936	1.6289	
20	1.7737	1.7194			1.2936	1.5546	
21	1.587	1.5384			1.2936	1.2803	
22	1.4632	1.448			1.2012	1.1888	
23	1.307	1.267			1.2012	1.1765	
24		1.2136	1.1517			1.1088	1.0745
Max	1.8671	1.829	1.848	1.7194	1.4937	1.6289	1.7556
Min	1.1765	1.086	1.0631	.0165	1.2012	.9145	1.0745
Avg	1.5393	1.3993	1.3700	1.1378	1.3069	1.2423	1.2854

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204061 / 33KV KHANDOBA

Feeder No / Name : 202 / 11 KV LOKMANYA NAGAR
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4572	.443			.4525	.443
2		.3658	.4477			.4525	
3		.3658	.4477			.4525	
4		.4572	.5373			.4525	
5		.5487	.6335			.4525	
6		.6401	.8145			.543	
7		.7316	1.0059			.7316	.7316
8	.724	.7316	.9145	.724		.7316	
9	.724	.7316	.823	.6335		.6401	.823
10	.6335			.6335			.7316
11	.543		.6401	.543			.6401
12	.543		.5487	.4525			.6401
13	.4525		.5487	.4525			.5487
14			.4572	.4525			.5487
15			.4572	.4525			.4572
16		.543	.4572	.4572		.4572	.4572
17	.6401	.5487		.5487	.4572	.5544	
18	.7316	.4001		.7316	.543	.6401	
19	.8145	.724		.7316	.7316	.7316	
20	.7316	.724		.7316	.6401	.7316	
21	.7316	.724			.6401	.6335	
22	.7316	.724			.6401	.6335	
23	.6401	.6335			.5487	.543	
24		.5601	.5316			.4572	.443
Max	.8145	.7316	1.0059	.7316	.7316	.7316	.823
Min	.4525	.3658	.443	.4525	.4572	.4525	.443
Avg	.6647	.5895	.6067	.5804	.6001	.5717	.5877

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204061 / 33KV KHANDOBA

Feeder No / Name : 203 / 11KV DHAR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7973			.724	
2		.8059			.724	
3		.8059			.724	
4		.905			.724	
15			1.286			1.5546
16	1.9909	1.9959	1.8099		1.6461	1.7375
17	1.9909				1.267	
18	2.0119			1.6289	1.0059	
19	1.7375			1.6461	.823	
20	1.5384			1.6289	.9955	
21	1.448			1.2803	.9955	
22	1.3575			1.0059	.9955	
23	.8145			.823	.8145	
24		.7888			.724	
Max	2.0119	1.9959	1.8099	1.6461	1.6461	1.7375
Min	.8145	.7888	1.286	.823	.724	1.5546
Avg	1.6112	1.0165	1.5480	1.3355	.9356	1.6461

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204061 / 33KV KHANDOBA

Feeder No / Name : 204 / 11 KV Sarnath Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3734	.5373			.362	.443
2		.3658	.5373			.362	.4525
3		.3658	.5373			.362	.4477
4		.4572	.6335			.362	.543
5		.5487	.724			.4525	.6401
6		.7316	.823			.543	.8316
7		.823	.924			.823	.905
8	.905	.9145	.9145	.8145		.9145	.905
9	.724	.9145	.9145	.823		.823	.9145
10	.724			.724			.823
11	.6335		.7316	.724			.7316
12	.6335		.7316	.724			.6401
13	.6335		.5487	.6335			.6401
14			.5487	.543			.5487
15			.5487	.543			.5487
16		.6335	.6401	.6335		.5487	.5487
17	.9145	.7316			.7316	.823	
18	.9145	.8145			.823	.9145	
19	.9145	.905			.823	.823	
20	.9145	.823			.823	.7316	
21	.7316	.724			.7316	.6335	
22	.6401	.6335			.543	.543	
23	.5487	.543			.543	.5487	
24		.4572	.5373			.4525	.443
Max	.9145	.9145	.924	.823	.823	.9145	.9145
Min	.5487	.3658	.5373	.543	.543	.362	.443
Avg	.7563	.6533	.6770	.6847	.7169	.6124	.6474

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204061 / 33KV KHANDOBA

Feeder No / Name : 205 / 11KV RAJARANI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.4937	1.6118			1.2803	1.4175
2		1.4937	1.6118			1.2803	1.448
3		1.4937	1.6289			1.2803	1.448
4		1.6804	1.7194			1.4784	1.5546
5		1.8671	1.9404			1.6632	1.7194
6		2.1948	2.5873			1.848	2.4691
7		2.4691	3.1417			2.3777	2.8349
8	2.7149	2.652	3.2007	2.5339		2.4691	2.8645
9	2.4272	2.7435	3.2007	2.4434		2.5606	2.652
10	2.1719			2.1719			2.1948
11	2.0814		2.9264	2.0814			2.1033
12	1.8099		2.8349	1.9004			1.9605
13	1.7194		2.2862	1.6461			1.829
14			2.1948	1.5546			1.6804
15			1.9204	1.5546			1.5546
16		1.6289	1.6804	1.5546		1.7556	1.4632
17	2.6139	1.9004			2.4025	2.1948	
18	2.8006	2.5339			2.894	2.4949	
19	2.9874	2.5339			2.3777	2.7149	
20	2.652	2.3777			2.0328	2.2177	
21	2.3777	2.0814			1.848	1.9004	
22	2.1033	1.9004			1.7556	1.8099	
23	1.829	1.7194			1.6632	1.6289	
24		1.6461	1.5947			1.4784	1.4175
Max	2.9874	2.7435	3.2007	2.5339	2.894	2.7149	2.8645
Min	1.7194	1.4937	1.5947	1.5546	1.6632	1.2803	1.4175
Avg	2.3299	2.0228	2.2550	1.9379	2.1391	1.9130	1.9183

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204061 / 33KV KHANDOBA

Feeder No / Name : 206 / 11 KV HUDCO FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4572	.5316			.4525	.443
2		.3658	.5373			.4525	.4477
3		.3658	.5373			.4572	.4525
4		.4572	.6335			.4525	.543
5		.5487	.724			.4572	.6335
6		.6401	.8145			.5487	.8145
7		.823	.9145			.7316	.905
8	.8145	.9145	.9145	.724		.823	.905
9	.724	.823	.9145	.724		.823	.9145
10	.724			.724			.9145
11	.724		.7316	.6335			.823
12	.6335		.7316	.6335			.6401
13	.543		.6401	.543			
14			.5487	.4525			.4525
15			.5487	.4572			.5487
16		.5487	.5487	.543		.5487	.5487
17	.6897	.6401			.6401	.6401	
18	.8145	.7316			.8145	.8316	
19	.8145	.8145			.823	.905	
20	.823	.8145			.7316	.7316	
21	.5487	.724			.7316	.724	
22	.6401	.6335			.6335	.6335	
23	.6401	.6335			.543	.543	
24		.5487	.5316			.543	.443
Max	.823	.9145	.9145	.724	.823	.905	.9145
Min	.543	.3658	.5316	.4525	.543	.4525	.443
Avg	.7026	.6380	.6752	.6039	.7025	.6277	.6518

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204061 / 33KV KHANDOBA

Feeder No / Name : 207 / DESHMUKH Ag

SHEDDABLE URBAN

Feeder KV- 11 / INCOMING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2743	.1772			.1791	
2		.2715	.1791			.1791	
3		.2715	.2715			.1791	
4		.2715	.2715			.1791	
5		.2715	.2715			.1791	
15			.4525	.2715			.0362
16		.5487	.4525	.2715		.2743	.0366
17		.4525			.1791	.2743	
18	.2686	.3658			.2743	.2743	
23	.2743	.181			.181	.0886	
24		.2715	.1772			.543	
Max	.2743	.5487	.4525	.2715	.2743	.543	.0366
Min	.2686	.181	.1772	.2715	.1791	.0886	.0362
Avg	.2715	.3180	.2816	.2715	.2115	.235	.0364

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204069 / 33 KV MKV II

Feeder No / Name : 201 / 11KV RAILAY STATION
EXPRESS Feeder KV- 11 /
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINOUS PROCESS)(NO STAGGERING)

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.112	.0934	.112	.0093	.112	.0934
2	.0934	.112	.0934	.0934	.0093	.112	.0747
3	.0934	.112	.0934	.112	.0093	.0934	.0747
4	.0934	.112	.0934	.0934	.0093	.0747	.0747
5	.0934	.112	.1027	.1307	.0093	.0747	.0747
6	.0934	.1086	.112	.112	.0093	.0747	.112
7	.0934	.0934	.1064	.0934	.0075	.0747	.0934
8	.0934	.0934	.0934	.112	.0075	.0934	.112
9	.0934	.112	.0934	.0747	.112	.1307	.0934
10	.1251	.112	.0093	.0934	.0934	.1307	.0934
11	.1158	.1307	.0093	.1307	.112	.0907	.1307
12	.112	.112	.0093	.1307	.0934	.112	.0131
13	.1083	.0934	.0093	.0934	.0934	.112	.112
14	.1232	.112	.0112	.112	.112	.112	.112
15	.112	.0905	.0112	.0934	.0934	.0934	.112
16	.1083	.0934	.0934	.0093	.0934	.0934	.0747
17	.0934	.0934	.1307	.0112	.0934	.0934	.0934
18	.0934	.0934	.0934	.0112	.0747	.056	.0934
19	.0934	.112	.112	.0112	.112	.0934	.112
20	.112	.112	.1307	.0112	.0934	.112	.112
21	.1307	.112	.1307	.0112	.112	.112	.112
22	.1176	.112	.112	.112	.0934	.0934	.0934
23	.112	.1008	.112	.0934	.0934	.0934	.112
24	.112	.112	.0934	.112	.0093	.0934	.112
Max	.1307	.1307	.1307	.1307	.112	.1307	.1307
Min	.0934	.0905	.0093	.0093	.0075	.056	.0131
Avg	.1046	.1066	.0812	.0821	.0648	.0971	.0955

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204069 / 33 KV MKV II

Feeder No / Name : 202 / 11KV RAM KRISHNA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.6335	.6878	.724	.0597	.6516	.724
2	.6878	.6335	.6697	.6878	.0579	.6516	.6878
3	.7095	.6335	.6584	.6516	.0652	.6878	.6516
4	.6878	.6335	.724	.5792	.067	.724	.6516
5	.724	.7059	.8145	.724	.0652	.7964	.724
6	.724	.905	.9694	.8688	.076	.8145	.8688
7	1.0136	1.0317	1.1222	.9955	.0941	.8326	.9955
8	1.0136	.9593	1.0498	.9412	.0977	.8688	.9335
9	.8962	.8688	.8507	.8688	.905	.8145	.8507
10	.8048	.8145	.0742	.7964	.8145	.7783	.0796
11	.7682	.6516	.0724	.724	.724	.7602	.067
12	.7499	.5792	.0724	.6878	.6335	.6878	.0724
13	.7316	.695	.0688	.6335	.6154	.6516	.0688
14	.6584	.6584	.0633	.6335	.6335	.6516	.0633
15	.6697	.6767	.0688	.6154	.5973	.6335	.0688
16	.6878	.7133	.6335	.0633	.6154	.6697	.0688
17	.7783	.823	.5792	.0724	.6516	.6878	.7059
18	.8688	.8962	.724	.0814	.724	.724	.8145
19	1.086	.9877	.905	.1068	.7842	1.1576	.9955
20	1.0498	.9694	1.0136	.112	.8145	1.086	1.0317
21	.9955	.9511	.9774	.0977	.7783	.9412	.8869
22	.905	.9511	.9231	.8688	.7602	.8688	.9145
23	.8326	.823	.8145	.7421	.7059	.8145	.7783
24	.7602	.6516	.7316	.7602	.0633	.6697	.905
Max	1.086	1.0317	1.1222	.9955	.905	1.1576	1.0317
Min	.6584	.5792	.0633	.0633	.0579	.6335	.0633
Avg	.8136	.7853	.6362	.5848	.4751	.7760	.6087

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204069 / 33 KV MKV II

Feeder No / Name : 203 / 11 KV MKV

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4344	.4163	.4075	.439	.0351	.3658	.3658
2	.3982	.3982	.3898	.439	.0351	.3658	.3658
3	.3982	.3982	.3721	.4755	.0386	.4024	.3658
4	.3982	.3982	.443	.4755	.0421	.439	.4024
5	.4163	.4706	.4784	.5121	.0491	.4755	.4755
6	.6878	.724	.6733	.5487	.0596	.5304	.5487
7	.7421	.7964	.567	.6767	.0701	.5853	.6036
8	.724	.6516	.7602	.695	.0473	.6219	.6219
9	.7619	.6219	.8507	.7316	.6219	.6516	.6401
10	.8505	.5853	.0876	.6584	.6767	.6335	.0859
11	.7796	.7316	.0876	.6219	.6401	.5792	.0806
12	.7087	.7316	.0771	.5487	.6036	.5068	.0701
13	.6379	.5847	.0631	.5121	.5487	.5068	.0596
14	.6201	.567	.0578	.4572	.4755	.4887	.0526
15	.6335	.5316	.0561	.4207	.4572	.4525	.0526
16	.6697	.443	.5487	.0456	.4755	.4706	.0596
17	.5973	.4961	.5121	.0473	.4755	.4938	.543
18	.5249	.5493	.5487	.0526	.5121	.5121	.543
19	.6154	.5847	.5853	.0578	.543	.6036	.543
20	.543	.5493	.6219	.0526	.4938	.5487	.543
21	.543	.5316	.5853	.0504	.4755	.4755	.5068
22	.4887	.4961	.5487	.4908	.4572	.439	.4887
23	.4525	.443	.5121	.4207	.4024	.4207	.4525
24	.4525	.4344	.4252	.4755	.0386	.3658	.4887
Max	.8505	.7964	.8507	.7316	.6767	.6516	.6401
Min	.3982	.3982	.0561	.0456	.0351	.3658	.0526
Avg	.5866	.5473	.4275	.4127	.3448	.4973	.3733

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204070 / 33 KV DARGA

Feeder No / Name : 201 / 11KV DARGA ROAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.829	1.8099	1.9909	1.7013	1.7194	3.1154	1.5947
2	1.7375	1.7194	1.9909	1.5223	1.5384	3.0042	1.5223
3	1.7375	1.7194	1.9909	1.3441	1.5384	2.9767	1.4175
4	2.0119	1.7194	1.9909	1.6118	1.6289	2.9386	1.4327
5	2.1719	1.8099	2.1719	1.9909	1.6289	3.1576	1.5947
6	2.5339	2.3529	2.8959	2.3282	2.1719	3.7665	2.1491
7	3.2007	2.9864	3.2579	2.6863	2.6244	4.7104	2.8349
8	3.1093	2.8959	3.2579	2.7759	3.0178	5.7165	3.0445
9	2.7435	2.6578	2.8959	2.5968	2.8898	5.8873	2.6244
10	2.3529	2.1491	2.5339	2.5339	2.4691	5.9412	2.3529
11	2.1719	1.97	2.7149	2.0814	2.4274	5.4024	2.1719
12	1.9909	1.8604	2.8054	1.8099	2.2148	4.9394	1.9004
13		1.8804	2.5339	1.8461	2.0058	4.6812	1.9004
14	2.1719	1.6289	2.0814	1.8099	1.8107	4.2055	1.6289
15	1.9909	1.7194	1.7909	1.7194	1.7924	3.8431	1.7194
16	1.9909	1.7194	1.7909	1.8099	1.8839	3.706	
17	2.2624	2.1719	1.97	2.0814	2.1719	4.2661	2.5339
18	2.8054	2.7149	2.5968	2.5339	2.7149	4.9147	2.7149
19	3.2579	3.0769	2.8959	3.0769	2.8054	5.7337	3.2579
20	2.7149	2.7149	2.5968	2.3529	2.5339	5.7152	2.7149
21	2.3529	2.3529	2.1262	2.1719	2.1719	4.9089	2.3529
22	2.2624	2.2624	1.97	2.0814	1.9909	4.3229	2.1719
23	2.0814	2.1719	1.97	1.8099	1.8099	4.0266	1.9909
24	1.8099	1.8099	1.9909	1.9004	1.6289	3.5189	1.6832
Max	3.2579	3.0769	3.2579	3.0769	3.0178	5.9412	3.2579
Min	1.7375	1.6289	1.7909	1.3441	1.5384	2.9386	1.4175
Avg	2.3170	2.1614	2.3671	2.0907	2.1329	4.3916	2.1439

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204070 / 33 KV DARGA

Feeder No / Name : 203 / 11KV CIVIL HOSPITAL
EXPRESS Feeder KV- 11 /
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0343	.0543	.0526	.0343	.0903	.0354
2	.0343	.0343	.0543	.052	.0343	.0892	.0354
3	.0343	.0343	.0543	.0351	.0362	.088	.0354
4	.0514	.0514	.0543	.0354	.0343	.0873	.0354
5	.0514	.0514	.0543	.0351	.0343	.0861	.0358
6	.0514	.0514	.0543	.0532	.0343	.0854	.0537
7	.0549	.0514	.0543	.0532	.0514	.0827	.0526
8	.0514	.0362	.0543	.0701	.0492	.0793	.0709
9	.0905	.0886	.0724	.0895	.0543	.0663	.0857
10	.0905	.1063	.0857	.0543	.0492	.1137	.0514
11	.0905	.1075	.0686	.0543	.0537	.1145	.0514
12	.0905	.0886	.0857	.0543	.0537	.1059	.0686
13	.0905	.0716	.0857	.0543	.0354	.0861	.0543
14	.0905	.0724	.0686	.0543	.0164	.0827	.0492
15	.0905	.0724	.0709	.0543	.0328	.0804	.0492
16	.0857	.0724	.0716	.0543	.0328	.0983	.0492
17	.0857	.0543	.0895	.0514	.0362	.1059	.0655
18	.0686	.0543	.0537	.0686	.0543	.1013	.0492
19	.0514	.0543	.0537	.0514	.0543	.1044	.0686
20	.0514	.0543	.0709	.0686	.0543	.105	.0686
21	.0514	.0543	.0716	.0514	.0543	.1112	.0514
22	.0514	.0543	.0701	.0514	.0362	.1149	.0514
23	.0514	.0509	.0532	.0514	.0362	.1104	.0543
24	.0514	.0514	.0543	.0526	.0328	.0888	.0354
Max	.0905	.1075	.0895	.0895	.0543	.1149	.0857
Min	.0343	.0343	.0532	.0351	.0164	.0663	.0354
Avg	.0651	.0605	.0650	.0543	.0415	.0949	.0524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 207002 / 132 KV Parbhani

Feeder No / Name : 207 / 11 KV Town I Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	14-MAR-17
HR	Load (MW)
2	.6097
3	.6097
4	.6097
5	.6097
6	.9145
7	1.2193
8	1.2193
9	1.2193
10	.9145
11	.9145
12	.6097
13	.6097
14	.6097
15	.6097
16	.6097
17	.6097
18	.6097
19	.9145
20	1.2193
21	1.2193
22	.9145
23	.9145
24	.6097
Max	1.2193
Min	.6097
Avg	.8217

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 207002 / 132 KV Parbhani

Feeder No / Name : 406 / 33 KV DARGA

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	09-MAR-17
HR	Load (MW)
1	6.0357
2	5.607
3	5.4355
4	5.4012
5	5.4698
6	6.4986
7	8.179
8	10.1852
9	9.8594
10	8.9335
11	8.2305
12	7.0988
13	6.5844
14	6.0185
15	5.8814
16	6.0357
17	6.653
18	7.3217
19	8.8649
20	9.8766
21	9.0878
22	7.9733
23	7.4932
24	6.7901
Max	10.1852
Min	5.4012
Avg	7.3131

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204012 / 33/11 KV PATHRI

Feeder No / Name : 201 / 11KV PATHRI 1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4632			1.4632		1.4632
2	1.4632			1.4632		1.3717
3	1.4632			1.6461		1.6461
4	1.6461			1.829		1.6461
5	1.829			1.829		1.829
6	1.829			1.829		1.829
7	2.1948			2.0119		
8	2.1948	1.829		2.1948		
9	2.0576				2.3777	
10					2.2862	
11					1.829	
12					1.7718	1.2955
13					1.6461	
14					1.5546	
15					1.6461	
16			1.5546		1.4632	
17					1.7375	
18			2.4691		1.7147	
19	1.7528		2.3777		1.7718	
20			2.3777		1.7718	
21			2.0119		1.3717	
22			1.5432		1.4632	
23			1.3717		1.4632	
24	1.4632	1.2193				1.4632
Max	2.1948	1.829	2.4691	2.1948	2.3777	1.829
Min	1.4632	1.2193	1.3717	1.4632	1.3717	1.2955
Avg	1.7597	1.5242	1.9580	1.7833	1.7246	1.5680

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204012 / 33/11 KV PATHRI

Feeder No / Name : 202 / 11 KV WADI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288			1.0402		.3429
2	1.0288			1.0402		.3429
3	1.0288			1.0402		.3429
4	1.0288			1.0402		
5	1.0288			1.0402		
6	1.0288			1.0402		
7	1.3717			1.3717		
8	1.3717	1.3717		1.6289		
9	1.2193					
10					1.0288	
11					1.3717	
12					1.3717	1.2193
13					1.7147	
14					1.3717	
15					1.4575	
16					1.4575	
17					1.3717	
20			.3429		.3429	
21			.3429		.3429	
22			.3429		.3429	
23			.3429		.3429	
24	.8573	.6097		.8573		.3429
Max	1.3717	1.3717	.3429	1.6289	1.7147	1.2193
Min	.8573	.6097	.3429	.8573	.3429	.3429
Avg	1.0993	.9907	.3429	1.1221	1.0431	.5182

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204012 / 33/11 KV PATHRI

Feeder No / Name : 203 / 11KV PATHRI AG

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	10-MAR-17	11-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0848		.0857		.3429
2	.0848		.0857		.3429
3	.0848		.0857		.3429
4					.3429
5					.3429
6					.3429
9				.7716	
12	.9145				
13	.9145				
15				.0343	
16		1.0288		.0343	
17		1.0288		.0343	
18				.0343	
19				.0857	
20		.0857		.0857	
21		.0857		.0857	
22		.0857		.0857	
23		.0857		.0857	
24			.0857		.1715
Max	.9145	1.0288	.0857	.7716	.3429
Min	.0848	.0857	.0857	.0343	.1715
Avg	.4167	.4001	.0857	.1337	.3184

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204012 / 33/11 KV PATHRI

Feeder No / Name : 204 / 11 KV RENAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5258			.3429		1.3717
2	.5258			.3429		1.5432
3	.5258			.3429		1.5432
4						1.5432
5						1.5432
6						1.5432
9					1.8861	
16			1.7147			
17			1.7147			
18			.3429		.3429	
19	.4572		.5144		.5144	
20			.5144		.5144	
21			.5144		.6859	
22			.5144		.5144	
23			.5144		.5258	
24	.5144	.4572		.5144		.8573
Max	.5258	.4572	1.7147	.5144	1.8861	1.5432
Min	.4572	.4572	.3429	.3429	.3429	.8573
Avg	.5098	.4572	.7930	.3858	.7120	1.4207

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204012 / 33/11 KV PATHRI

Feeder No / Name : 205 / 11 KV DEVNANDRA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717			2.2291		.5144
2	1.3717			2.2786		.5144
3	1.3717			2.2786		.5144
4	1.3717			2.2291		
5	1.3717			2.2291		
6	1.3717			2.2291		
7	2.6292			2.2291		
8	3.0864	3.0864		2.7435		
9	2.7435					
10					1.7147	
11					3.0864	
12					3.0864	2.5149
13					3.4294	
14					3.0864	
15					3.0864	
16					3.0864	
17					3.0864	
18			.5144		.3429	
19	.4572		.5144		.5144	
20			.3429		.5144	
21			.3429		.5144	
22			.3429		.5144	
23			.3429		.5144	
24	1.0288	1.0669		.6859		.5144
Max	3.0864	3.0864	.5144	2.7435	3.4294	2.5149
Min	.4572	1.0669	.3429	.6859	.3429	.5144
Avg	1.6523	2.0767	.4001	2.1258	1.8984	.9145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204012 / 33/11 KV PATHRI

Feeder No / Name : 206 / 11 KV PATHRI-II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0631			1.4022		.8764
2	1.4175			1.4022		.8573
3	1.3717			1.4022		1.3717
4	1.949			1.5432		1.5432
5	1.949			1.9281		1.5432
6	1.949			1.9281		1.5432
7	2.0576			1.9719		
8	2.0576	1.829		2.0805		
9	1.829				1.4575	
10					1.3717	
11					1.4022	
12					1.1393	.9145
13					1.1145	
14					.8573	
15					.8573	
16					.8573	
17			1.5432		1.0402	
18			1.5432		1.2136	1.3717
19	1.6766		1.5432		1.5604	
20			1.5432		1.5604	
21			1.3717		1.3717	
22			1.1145		1.2003	
23			1.1145		.8764	
24	1.0631	.9145		1.0288		.8573
Max	2.0576	1.829	1.5432	2.0805	1.5604	1.5432
Min	1.0631	.9145	1.1145	1.0288	.8573	.8573
Avg	1.6712	1.3718	1.3962	1.6319	1.1920	1.2087

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204012 / 33/11 KV PATHRI

Feeder No / Name : 207 / 11KV EXPRESS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1402			.1372		.1372
2	.1402			.1372		.1372
3				.1372		.1372
4	.1402			.1372		.1372
5	.1402			.1372		.1402
6	.1402			.1372		.1372
7	.0857			.1372		
8	.0857	.1524		.1372		
9	.0762				.2058	
10					.1715	
11					.1715	
12					.1715	.1067
13					.1715	
14					.1715	
15					.1715	
16					.1715	
17					.1715	
18			.12		.1715	
19	.1524		.1143		.1715	
20			.1715		.1715	
21			.1715		.1372	
22			.12		.1372	
23			.12		.1372	
24	.1715	.1524		.0857		.1402
Max	.1715	.1524	.1715	.1372	.2058	.1402
Min	.0762	.1524	.1143	.0857	.1372	.1067
Avg	.1273	.1524	.1362	.1315	.1669	.1341

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204012 / 33/11 KV PATHRI

Feeder No / Name : 208 / 11KV DHALEGAON
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859			1.0288		.8573
2	.6859			1.0288		.8573
3	.6859			1.0288		.8573
4	.8573			1.0288		.8573
5	.8573			1.0288		.8573
6	.8573			1.0288		.9431
7	.8573			.1715		
8	.8573	.6097		.1715		
9	.7621				.6859	
10					.9431	
11					1.2003	
12					1.2003	.9145
13					1.2003	
14					1.0288	
16			.8573		.6859	
17					.9431	
18			.9431		.8573	
19	.6097		.8573		1.0288	
20			.8573		1.0288	
21			.8573		.8573	
22			.8573		.8573	
23			.8573		.8573	
24	.5144	.4572		.8573		.8573
Max	.8573	.6097	.9431	1.0288	1.2003	.9431
Min	.5144	.4572	.8573	.1715	.6859	.8573
Avg	.7482	.5335	.8696	.8192	.9553	.8752

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204025 / 33/11 KV HADGAON

Feeder No / Name : 201 / 11KV HADGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7						.811	
8						1.0374	
9						1.2637	
11							1.3203
12							1.3957
13							1.2071
14							1.2071
15	1.3203	1.2346		1.2449	1.4335		
16		1.2003		1.1883	1.4901		
17		1.2346		1.4523			
18		1.3203	1.226	1.5278	1.3769		
19		.8573			1.2071		
20		.8573	1.226	1.2826	1.1128		
21		.8573		1.1694	1.1128		
22			1.1506	1.1506	1.0751		
24		.5144					
Max	1.3203	1.3203	1.226	1.5278	1.4901	1.2637	1.3957
Min	1.3203	.5144	1.1506	1.1506	1.0751	.811	1.2071
Avg	1.3203	1.0095	1.2009	1.2880	1.2583	1.0374	1.2826

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204025 / 33/11 KV HADGAON

Feeder No / Name : 202 / 11 KVA NATHRA AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.5335	.9779	.7459	.8535	.7621	
8	.7468	1.0277	.9779	.945	.884	
9	.9145	1.0608	1.0774		1.0059	
10		1.166	1.1831	1.0669	1.2346	
11	1.1271	1.1934			1.4232	
12	.9779	1.3094	1.0822	1.0059	1.4232	
13	1.0608	1.21			1.4232	
14	.9282	.8619	.7926	.7468	1.2689	
15						1.2517
16						1.3203
19						.8402
20						.9242
21						.7373
22						.7373
Max	1.1271	1.3094	1.1831	1.0669	1.4232	1.3203
Min	.5335	.8619	.7459	.7468	.7621	.7373
Avg	.8984	1.1009	.9765	.9236	1.1781	.9685

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204025 / 33/11 KV HADGAON

Feeder No / Name : 203 / 11KV Gopegaon 1 PH SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5144	.3429			.5658	
2		.5144	.3429			.5658	
3		.5144	.5144			.5658	
4	.7545	.5144	.5144	.5658		.7545	
5			.5144			.7545	
6		.8573	.6859	1.3203		.9431	
7		1.3717	.12		1.1317	2.6406	
8	.9431	1.5432	.12	1.3203	1.3203	3.2065	
9		1.5432	.12		1.5089	3.3951	
10	1.6975	1.7147	.12	1.5089	1.5089		
11		1.5432			.132		2.8292
12		1.5432		1.8861	.1132		2.8292
13		1.5432					
14	2.0576	1.3717		1.3203	1.2003		2.6406
15		2.915		3.0178	3.2065		1.6975
16	2.7435	2.7435		2.452	3.5837		1.8861
17		2.915		3.2065	3.3951		1.8861
18		2.7435	3.0178	3.2065	3.0178		1.5089
19		2.7435			2.8292		1.8861
20	2.7435	2.7435		3.0178	2.8292		1.5089
21		2.7435			2.8292		1.5089
22		2.572	3.0178	2.8292	2.6406		1.3203
23	.5144				.5658		.5658
24	.5658	.5144		.3772	.3772	.5658	
Max	2.7435	2.915	3.0178	3.2065	3.5837	3.3951	2.8292
Min	.5144	.5144	.12	.3772	.1132	.5658	.5658
Avg	1.5025	1.7147	.7859	2.0022	1.8935	1.3958	1.8390

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204074 / 33/11 KV KASAPURI

Feeder No / Name : 201 / 11KV NATHRA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9774	1.1269	.9774	1.0802	1.0208	.8842	.8916
2	.9816	1.1789	1.1568	1.0208	.9465	.8939	.9816
3	1.1163	1.2269	1.3375	1.262	1.1568	1.0517	1.1517
4	1.4299	1.4506	1.4506	1.4918	1.5043	1.4506	1.448
5	1.701	1.7013	1.5203	1.7013	1.6289	1.5364	1.6644
9	1.8229	1.8054	1.6827	1.8404	1.8804	1.8804	1.7896
10	1.7164	1.6632	1.5432	1.6827	1.6651	1.9281	
11	1.4403	1.2517	1.4403	1.4922		1.6644	1.2483
19	1.701	1.6827	1.6118	1.6301	1.5947	1.6478	
20	1.6301	1.5775	1.5249	1.5775	1.5083	1.56	
21	1.4217	1.286	1.4506	1.4723	1.3003	1.2483	
22	1.2689	1.2209	1.2071	1.1568	.9156	1.0117	.4024
23	1.1831	1.1317	1.1317	1.0923	.8648	.9431	.4024
24	1.046	1.1616	1.0174	1.0517	1.0402	.8745	.9088
Max	1.8229	1.8054	1.6827	1.8404	1.8804	1.9281	1.7896
Min	.9774	1.1269	.9774	1.0208	.8648	.8745	.4024
Avg	1.3883	1.3904	1.3609	1.3966	1.3097	1.3268	1.0889

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204074 / 33/11 KV KASAPURI

Feeder No / Name : 202 / 11KV PATHARGAVAN AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11	1.3443	1.1092	1.2483	1.3123	1.5223	1.3279	1.0437
12	1.5339	1.1092	1.3123	1.6004	1.749	1.4706	1.1111
13	1.5181	1.4998	1.1888	1.5844	1.6288	1.4352	1.1584
14	1.4548	1.4883	.5144	1.2651	1.4998	1.0837	1.1439
15	1.4243			1.3283	1.5364	1.406	1.0974
16	1.4074	1.4632		1.4403	1.4706	1.4352	1.1265
17	1.3279	1.5364			1.406	1.3757	1.1883
18	1.2193	1.2346	.6481	1.3757	1.0517	1.0957	.8429
24		1.0311					
Max	1.5339	1.5364	1.3123	1.6004	1.749	1.4706	1.1883
Min	1.2193	1.0311	.5144	1.2651	1.0517	1.0837	.8429
Avg	1.4038	1.3090	.9824	1.4152	1.4831	1.3288	1.0890

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204075 / 33/11 KV GUNJ

Feeder No / Name : 201 / 11KV GUNJ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4954	.4641	.5144	.4763	.362	.2743
2		.4954	.4917	.5716	.4954	.3721	.2932
3		.5335	.5365	.6668	.5335	.3944	.3239
4		.6668	.6133	.7049	.724	.4458	.3277
5						.4973	.373
6						.6203	.3887
7						.6802	.4915
8						.7116	.5426
9						.7253	.5624
10						.7287	.6001
11	.7865	.7716	.5937	.7373	.7611		
12	.8745	.7773	.6401	.703	.7164		
13		.8059	.68	.6478	.6173		
14		.7291	.7202	.6874	.5658		
15	.8583	.6443	.6325	.6097	.5487		
16		.6952	.6167	.6249	.5182		
17	.7545	.7209	.664	.6859	.5792	.4049	.3772
18	.7773	.7545	.6642	.6958		.4954	.3944
19		.6001	.6097	.6097	.724	.6859	.5487
20	.6668	.6274	.6097	.724	.6668	.4763	.6173
21	.6097	.583	.5906	.6668	.6097	.4954	.5144
22	.5716	.5365	.4763	.5906	.5335	.4191	.4458
23	.4763	.4748	.5144	.5335	.4763		.3944
24	.4572	.4954	.4527	.4763	.4954	.4763	.381
Max	.8745	.8059	.7202	.7373	.7611	.7287	.6173
Min	.4572	.4748	.4527	.4763	.4763	.362	.2743
Avg	.6833	.6337	.5872	.6361	.5907	.5289	.4361

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204075 / 33/11 KV GUNJ

Feeder No / Name : 202 / 11KV UMRA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3239	.2984	.362	.3048	.3258	.3658
2		.3429	.3353	.4191	.3239	.3582	.3749
3		.381	.4239	.5144	.362	.3856	.4111
4		.6478	.4527	.5716	.5906	.4334	.426
5						.463	.4372
6						.6001	.4475
7						.6371	.6226
8						.6478	.6478
9						.5898	.6371
10						.5525	.5256
11	.5155	.6154	.5401	.5611	.6001		
12		.5868	.5468	.583	.5761		
13		.5868	.571	.5144	.5144		
14		.5533	.5268	.5487	.583		
15	.5487	.5256	.431	.463	.6001		
16		.5426	.4458	.463	.583		
17	.6173	.5596	.4938	.5658	.5316	.3239	.2401
18	.5658	.6104	.5418	.583	.6344		.2915
19		.503	.6478	.5906	.6287	.6097	.6001
20	.6097	.5533	.5716	.5906	.4572	.5525	.5487
21	.5144	.39	.4191	.5335	.381	.4191	.3258
22	.4572	.3052	.3239	.362	.3048	.2858	.2915
23	.3429	.2683	.2858	.3239	.2858		.2572
24	.3048	.3239	.2683	.3048	.3048	.2858	.2667
Max	.6173	.6478	.6478	.5906	.6344	.6478	.6478
Min	.3048	.2683	.2683	.3048	.2858	.2858	.2401
Avg	.4974	.4789	.4513	.4919	.4759	.4669	.4287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204075 / 33/11 KV GUNJ

Feeder No / Name : 203 / 11KV ANDHAPURI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1524	.1341	.1524	.1334	.168	.1467
2		.1524	.1509	.1524	.1334	.2012	.1486
3		.1524	.1526	.1715	.1524	.2353	.1635
4		.1715	.1509	.1715	.1905	.2686	.1783
5						.3189	.1806
6						.3467	.2743
7						.3601	.381
8						.3944	.3858
9						.4191	.1562
10						.3374	.0972
11	.3429	.4163	.3429	.3982	.3772		
12		.4287	.3814	.4344	.4115		
13		.4409	.3668	.3944	.3944		
14		.4359	.3521	.3429	.3772		
15	.4801	.4527	.3185	.3944	.3601		
16		.4359	.3102	.3772	.3944		
17	.4287	.4527	.3227	.4801	.4115	.1143	.0857
18	.3429	.4641	.3961	.3772	.4115	.1143	.1029
19		.1696	.2286	.1905	.2286	.1905	.2058
20	.2286	.1844	.1905	.1905	.1905	.2096	.1543
21	.2096	.1526	.1715	.1905	.1715	.1715	.12
22	.1905	.1357	.1715	.1524	.1524	.1715	.12
23	.1524	.116	.1334	.1524	.1334		.12
24	.1334	.1524	.116	.1334	.1334	.1334	.1524
Max	.4801	.4641	.3961	.4801	.4115	.4191	.3858
Min	.1334	.116	.116	.1334	.1334	.1143	.0857
Avg	.2788	.2815	.2439	.2698	.2643	.2444	.1763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204090 / 33/11 KV BABHALGAON

Feeder No / Name : 201 / 11 KV BABHALGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5144	.5373		.6268	.5373
2		.6335	.5144	.5373	.6335	.6447	.5373
3	.5373		.5144	.5373		.6805	.5373
4		1.1403	.6859	1.2403	1.086	.7522	.5373
5			1.0288	1.5775		.7522	.5373
6	1.4022	1.2826	1.2003	1.7528	1.6289		
7			1.5432	1.8204			
8		2.5086		2.1948	2.452		
9	1.5424	2.5274		2.2462			
10		2.7161	1.9719	2.3148	2.3529		
11	1.6975	2.2262	2.1033	2.3148			
12						2.6006	2.371
13						2.7435	
14						2.572	2.2634
15						2.572	2.2624
16						2.572	2.3388
17						2.4863	2.5652
18			.7164			2.4006	2.3011
19		.6859	.8954			2.2291	2.2634
20			.8954			.8954	.6878
21			.8954			.8954	.7545
22			.8954			.7164	.7545
23		.5144	.7164			.5373	
24	.5373	.6602	.5144	.5373	.6602	.6268	.5373
Max	1.6975	2.7161	2.1033	2.3148	2.452	2.7435	2.5652
Min	.5373	.5144	.5144	.5373	.6335	.5373	.5373
Avg	1.1433	1.4895	.9753	1.4676	1.4689	1.5169	1.3616

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204090 / 33/11 KV BABHALGAON

Feeder No / Name : 202 / 11 KV GUNJ SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2572	.2686		.2686	.2686
2	.2686	.2715	.2572	.2686	.2715	.2686	.2686
3			.2572	.2686		.2686	.2686
4	.2686	.362		.2686	.2715	.7973	.8859
5	.2686			.2686		.8764	1.0517
6						1.1269	1.0402
7						1.0576	1.1145
8						1.1145	1.1145
9						1.1145	1.1145
10						1.1145	1.1041
11						1.0631	.9774
12			1.0631		1.1584	.2686	
13	1.3203	1.0288	.9922			.2686	
14			1.0517		1.1222	.2686	
15	1.1222		.964		1.1128		
16			.964		1.1222		
17	1.1506	1.0288	.8764	1.0288	1.2071		
18	1.2127		.8764			.2686	.2829
19		1.0288	.8764			.3582	.2715
20			.3582			.3582	.2715
21			.3582			.3582	.3018
22			.3582			.2686	.2715
23		.2572	.2686			.2686	
24	.2686	.2829	.2572	.2686	.2829	.2686	.2686
Max	1.3203	1.0288	1.0631	1.0288	1.2071	1.1269	1.1145
Min	.2686	.2572	.2572	.2686	.2715	.2686	.2686
Avg	.7350	.6086	.6273	.3772	.8186	.5726	.6398

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204090 / 33/11 KV BABHALGAON

Feeder No / Name : 203 / 11 KV LIMBA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6859	.7164		.724	.7164
2		.6335	.6859	.7164	.543	.6335	.7164
3	.7164		.6859	.7164		.6878	.7164
4		.6335		.7164	.543	1.7718	1.5775
5	.7164			.7164		1.8229	1.7337
6						2.1672	1.9719
7						2.1605	2.1605
8						2.2634	2.1434
9						2.3148	2.1091
10						2.2291	2.2634
11						2.2291	2.2068
12			3.1722		3.5113		
13	3.1121	2.572	3.0864				
14			2.4006		3.5475		
15	3.6923				3.678		
16			2.7435		3.4751		
17	3.5113	3.0864	2.982	2.7435	3.3665		
18	3.4894		.8954			.8954	.7964
19						1.0745	.8299
20			.8954			1.0745	.724
21			1.0745			1.0745	.9997
22			1.0745			.8954	.905
23		.6859	.8954			.7164	
24	.7164	.6335	.6859	.7164	.6335	.724	.7164
Max	3.6923	3.0864	3.1722	2.7435	3.678	2.3148	2.2634
Min	.7164	.6335	.6859	.7164	.543	.6335	.7164
Avg	2.2792	1.3741	1.5688	1.0060	2.4122	1.4144	1.3698

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204090 / 33/11 KV BABHALGAON

Feeder No / Name : 204 / 11 KV TURA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2572	.2686		.362	.2686
2		.2715	.2572	.2686	.2715	.3582	.2686
3	.2686		.2572	.2686		.3582	.2686
4		1.1088	.9431	1.0631	.8145	.3582	.2686
5			1.0288	1.2269		.3582	.2686
6	1.3146	1.5089	1.1145	1.4022	1.4146		
7			1.2003	1.5257			
8		1.8642		1.8004	1.6289		
9	1.8755	1.9185					
10		2.1125	1.286	1.9719	1.448		
11	1.8461	1.2127	1.3672	1.9204			
12						1.5432	1.4299
13						1.6118	1.4661
14						1.6289	1.3937
15						1.6289	1.5089
16						1.5432	1.4118
17						1.4575	1.5655
18			.2686			1.3717	1.5655
19		.2572	.3582			1.2003	1.5278
20			.3582			.3582	.5093
21			.3582			.3582	.5281
22			.3582			.3582	.4525
23		.2572	.2686			.2686	
24	.2686	.362	.2572	.2686	.2715	.362	.2686
Max	1.8755	2.1125	1.3672	1.9719	1.6289	1.6289	1.5655
Min	.2686	.2572	.2572	.2686	.2715	.2686	.2686
Avg	1.1147	1.0874	.6212	1.0895	.9748	.8603	.8806

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204014 / 33KV WAZOOR

Feeder No / Name : 202 / 11KV LIMLA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17
HR	Load (MW)
1	.5335
2	.4954
3	.4572
4	.4572
24	.6097
Max	.6097
Min	.4572
Avg	.5106

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204015 / 33KV CHUDAWA

Feeder No / Name : 201 / 11KV CHUDAWA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8652	1.6956	1.6956	1.7337	1.7804	1.8652	1.9281
2	1.7804	1.6956	1.6956	1.7337	1.7804	1.8652	1.9281
3	1.7804	1.6956	1.6956	1.7337	1.6956	1.8652	1.9281
4	1.6956	1.8652	1.6766	1.8204	1.8861	1.8652	1.9281
14		2.4587	2.572	2.3472	2.713	2.713	2.5149
15		2.4587	2.4863	2.2634	2.5434	2.6282	2.2634
16			2.0576	2.0957	2.3472	2.5434	
17		1.8652					
21	2.1795	1.8442	1.9071	2.2043	2.0348	2.0157	2.1795
22	1.8442	1.8442	1.9071	2.0348	2.0348	2.0157	2.0119
23	1.8652	1.6766	1.8204	1.8652	1.8652	2.0157	1.8442
24	1.8652	1.8652	1.6956	1.8204	1.6956	2.0157	2.1033
Max	2.1795	2.4587	2.572	2.3472	2.713	2.713	2.5149
Min	1.6956	1.6766	1.6766	1.7337	1.6956	1.8652	1.8442
Avg	1.8595	1.9059	1.9281	1.9684	2.0342	2.1280	2.0630

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204015 / 33KV CHUDAWA

Feeder No / Name : 202 / 11KV GOUR FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1022	.8478	.9326	.9536	.7545	.8573	1.0517
2	1.1022	.8478	.9326	.9536	.7716	.8478	.964
3	1.0174	.8478	.9326	.8669	.763	.8478	.964
4	1.0174	.8478	.9326	.8669	.8478	.8383	.8764
9		1.3413	1.3717	1.3717	1.4251	1.3565	1.1869
10		1.3916	1.3717	1.2717	1.4251	1.3565	1.2574
11		1.3904	1.286	1.2717	1.3077	1.3565	1.1869
12		1.3565	1.2003	1.1869	1.3413	1.2717	1.1869
13		1.2209	1.1145	1.1869	1.0059	1.1869	1.0174
14			.1715				
15			.1715				
16			.1715				
20	.362	.3391	.2601	.362	.3391	.2601	.362
21	.2715	.3391	.2601	.362	.3429	.2629	.2715
22	.2715	.3429	.2601	.2715	.3429	.2629	.2743
23	.2743	.3429	1.0402	.2715	.3429	.2629	.2743
24	.8478	.9221	.9326	1.0402	.8478	.8573	1.0517
Max	1.1022	1.3916	1.3717	1.3717	1.4251	1.3565	1.2574
Min	.2715	.3391	.1715	.2715	.3391	.2601	.2715
Avg	.6963	.8841	.7848	.8741	.8470	.8447	.8518

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204015 / 33KV CHUDAWA

Feeder No / Name : 204 / 11KV SONNA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1022	.8478	1.0288	.8669	.7716	.8573	.964
2	1.0174	.8478	1.0288	.8669	.7716	.8573	.8764
3	.9326	.8478	1.0288	.8669	.7716	.8573	.8764
4	.9326	.8478	1.0174	.8669	.7716	.8573	.8764
9		1.3413	1.1869	1.3565	1.3413	1.3717	1.3565
10		1.3413	1.1869	1.1736	1.5089	1.3717	1.1736
11		1.3413	1.1869	1.1736	1.3413	1.3717	1.1736
12		1.3413	1.1022	1.1869	1.3413	1.286	1.1736
13		1.2717	1.1022	1.1869	1.1736	1.286	1.0898
20	.362	.3353	.2601	.362	.3391	.2572	.3658
21	.2715	.3391		.2715	.2572	.2572	.2715
22	.2715	.3429	.2601	.2715	.2572	.2601	.2715
23	.2715	.3429	.2601	.2715	.2572	.1734	.2715
24	1.0174	1.0174	1.0288	.9536	.763	.9431	1.0402
Max	1.1022	1.3413	1.1869	1.3565	1.5089	1.3717	1.3565
Min	.2715	.3353	.2601	.2715	.2572	.1734	.2715
Avg	.6865	.8861	.8983	.8339	.8333	.8577	.8415

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204016 / 33KV KATNESHWAR

Feeder No / Name : 201 / 11KV KATNESHWAR FEEDER
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.2193	1.2803	1.2146	1.186	1.2146	1.2193
2	1.1431	1.2193	1.2803	1.186	1.2003	1.2003	1.2193
3	1.1431	1.2193	1.2803	1.2146	1.186	1.186	1.2193
4	1.1431	1.2193	1.3603	1.2955	1.2803	1.2955	1.2955
9	1.1431						
11							1.2955
13	1.5242	1.6604	1.6804	1.5813	1.6604	1.7394	1.5623
14	1.3717	1.5813	1.6004	1.1717	1.6004	1.5813	1.4842
20	1.5242	1.5023	1.5203	1.2803	1.3603	1.5384	1.3717
21	1.5242	1.4232	1.3603	1.2651	1.3279	1.4403	1.2955
22	1.448	1.3279	1.3765	1.2651	1.3441	1.2955	1.2193
23	1.3717	1.3441	1.3603	1.2803	1.1717	1.2955	1.2651
24	1.2955	1.3717	1.2955		1.2651		1.2193
Max	1.5242	1.6604	1.6804	1.5813	1.6604	1.7394	1.5623
Min	1.1431	1.2193	1.2803	1.1717	1.1717	1.186	1.2193
Avg	1.3146	1.3716	1.3995	1.2755	1.3257	1.3787	1.3055

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204016 / 33KV KATNESHWAR

Feeder No / Name : 202 / 11KV ERRANDESHWAR FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.0669	1.1336	1.0402	1.1469	1.1203	1.0669
2	1.1431	1.0669	1.1736	1.0526	1.1603	1.0936	1.0669
3	1.1431	1.0669	1.1736	1.0402	1.1736	1.1336	1.0669
4	1.1431	1.0669	1.2574	1.0402	1.2431	1.2146	1.1431
9	1.1431						
13	1.448	1.5746	1.6385	1.5746	1.7814	1.6091	1.4842
14	1.2193	1.4251	1.5384	1.0774	1.5384	1.3279	1.4232
20	1.2955	1.3927	1.3765	1.5089	1.2651	1.2146	1.3717
21	1.2955	1.326	1.2146	1.4089	1.2651	1.2146	1.2955
22	1.2193	1.326	1.2146	1.3108	1.1717	1.2146	1.2193
23	1.1431	1.2574	1.2146	1.2431		1.1431	1.326
24	1.2193	1.1431	1.0936		1.1203		1.0669
Max	1.448	1.5746	1.6385	1.5746	1.7814	1.6091	1.4842
Min	1.1431	1.0669	1.0936	1.0402	1.1203	1.0936	1.0669
Avg	1.2130	1.2466	1.2754	1.2297	1.2866	1.2286	1.2301

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204019 / PURNA URBAN

Feeder No / Name : 203 / 11 KV D. TAKALI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.166	1.3717	1.1145	.9602		
2		1.5432	1.166	1.0288		
3	1.3717		1.3717	1.1145		
4		1.5947	1.1145	1.2003		
5	1.5089		1.1145			
6		1.7147	1.2346			
7	2.1948		1.6118			
8	1.7833	1.8004				
9					1.2003	1.6118
10						1.7833
11						1.7833
12					1.9547	1.7147
14						1.5775
16					1.6289	1.4575
Max	2.1948	1.8004	1.6118	1.2003	1.9547	1.7833
Min	1.166	1.3717	1.1145	.9602	1.2003	1.4575
Avg	1.6049	1.6049	1.2468	1.0760	1.5946	1.6547

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204019 / PURNA URBAN

Feeder No / Name : 204 / 11KV NEELA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						1.8632	2.1757
2						1.0059	1.2498
3						1.0364	1.2498
4						1.0364	1.3108
5						1.0669	1.4022
6						1.1888	1.3717
7						1.4632	1.6461
8						2.8349	3.4065
9	3.376	1.6461	3.0864	3.376	1.7985		
10	3.7952	1.7375	3.6961	3.5361	3.4751		
11	1.9814	3.6656	3.7513	3.5665	3.3112		
12	3.3722	3.7647	3.5589	3.5665	1.7985		
13	1.6766	2.0424	1.5775	3.437	3.2007		
14	1.3717	3.7876	3.376	1.829	1.829		
15	1.6461	1.8595	3.4751	3.4065	1.768		
16	3.2198	1.3717	2.8959	3.437	3.3417		
24		1.5432					
Max	3.7952	3.7876	3.7513	3.5665	3.4751	2.8349	3.4065
Min	1.3717	1.3717	1.5775	1.829	1.768	1.0059	1.2498
Avg	2.5549	2.3798	3.1772	3.2693	2.5653	1.4370	1.7266

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204019 / PURNA URBAN

Feeder No / Name : 205 / 11KV BARBADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11		1.2003	1.2003	1.5432	1.1317	1.0288
12		1.3717	1.1488			1.2003
13	1.3032	1.2517	1.1145			
14	1.3032	1.1145	1.046	1.3717	1.0974	.9945
15		1.1145				
16	1.286	1.0974		1.2003		1.0288
17		1.1488	1.166			
18	1.2174		1.0802	1.0288	.9602	.9088
Max	1.3032	1.3717	1.2003	1.5432	1.1317	1.2003
Min	1.2174	1.0974	1.046	1.0288	.9602	.9088
Avg	1.2775	1.1856	1.1260	1.286	1.0631	1.0322

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204019 / PURNA URBAN

Feeder No / Name : 206 / 11KV D.TAKLI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3429	.3429	.2572		
2	.2572		.3429	.3429	.2572		
3		.2572	.3429	.3429	.2572		
4	.3429		.3601	.3772	.3086		
5	.4115	.3429	.4458	.4115	.4115	.3429	.5144
13	.3429	.2743	.2915	.2743	.3429	.3086	.2743
14		.2229	.2572	.2058			
15	.3429		.12	.2058	.3429		.2229
16			.1715	.2229	.3429		
17	.6859	.7202	.6859	.6516		.7716	.583
18	.8573	.8059	.7545	.7888	.6859		
19	.7716	.9602	.9088	.8059			.8573
20		.8573		.8745			
21	.6859	.7716		.7888			
22		.7373	.7545			.9945	.7373
23	.7716	.6859	.6859				
24	.7373	.8573	.6687	.6859	.6516	.6859	.8573
Max	.8573	.9602	.9088	.8745	.6859	.9945	.8573
Min	.2572	.2229	.12	.2058	.2572	.3086	.2229
Avg	.5643	.6244	.4755	.4881	.3858	.6207	.5781

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204019 / PURNA URBAN

Feeder No / Name : 207 / 11KV NEELA GFSS Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2915	.2572	.3429	.6859	
2	.3086		.2915	.2572	.3429		
3		.2572		.2572	.3429		
4	.4458		.3772	.3086	.4801		
5	.5316	.3429	.4801	.3429	.5658	.3429	.5144
13	.3429	.2743	.2229	.3086	.2572	.3086	.2915
14			.2229	.2572			
15	.3429	.2743	.1715	.2743	.2572		
16			.6173	.2743	.3429		.2572
17	.8573	.583		.6859			
18			.583	.703	.6859	.6001	
19	.6859	.9088	.8402	.823			.9088
20		.8059		.823	.7716		
21	.6001	.703		.7716			.8573
22			.6859			.583	.8059
23	.7716	.6859	.6859		.6859		
24	.6516	.7716	.6516	.6687	.6516		.5144
Max	.8573	.9088	.8402	.823	.7716	.6859	.9088
Min	.3086	.2572	.1715	.2572	.2572	.3086	.2572
Avg	.5538	.5607	.4709	.4675	.4772	.5041	.5928

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204019 / PURNA URBAN

Feeder No / Name : 208 / 11KV BARBADI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372		.1886	.1372	.1372		
2			.1715	.1372	.1372		
3	.1543	.0857	.1715	.1372	.1372		
4				.1715	.1372		
5	.2743	.0857	.2401	.1886	.1715	.0857	.1715
13	.1715	.1029	.0686	.1372	.0857	.1372	.12
14			.0686	.0857			
15	.1715	.0857	.0857	.0857	.0857		.0857
16			.0857	.0857	.0857		.12
17	.1715	.3086	.1715	.1543			
18			.1715	.2058	.1715	.2058	
19	.1715	.3086	.2401	.2572			
20		.2743		.2229	.1715		.2401
21	.1715	.2401		.2401			
22		.2401	.2572			.2401	.1886
23	.1715	.2229	.2229		.1715		
24	.1715	.1715	.2229	.2229	.2058	.1715	.2229
Max	.2743	.3086	.2572	.2572	.2058	.2401	.2401
Min	.1372	.0857	.0686	.0857	.0857	.0857	.0857
Avg	.1766	.1933	.1690	.1646	.1415	.1681	.1641

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204019 / PURNA URBAN

Feeder No / Name : 209 / 11KV RAILWAY EXPRESS
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINOUS PROCESS)(NO STAGGERING)

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0838	.0838	.1962	.1715	.1715	.0686	.0762
2	.2114	.2134	.1962	.1791	.1867	.0762	.0762
3	.0762	.0838	.1867	.1791	.1791	.0762	.0762
4	.1962	.2038	.1867	.1791	.1867	.2134	.0762
5	.0762	.0838	.0914	.1791	.1962	.0686	.0838
6	.2038	.0991	.2096	.221	.1867	.0762	.0991
7	.0991	.261		.2191	.221	.0686	.0914
8	.2114	.0991	.2363	.2457	.2363	.2286	.2706
9	.0991	.2363	.2706	.261	.261	.221	.2706
10	.2782	.2343	.2534	.261	.2534	.0838	.3029
11	.1067	.2363	.2363	.2114	.2668	.0991	.0991
12	.2286	.2114	.2191	.1791	.0991	.1143	.0838
13	.0838	.1791	.0914	.1867	.2114	.2363	.1962
14	.2229	.1791	.1619	.1791	.0838	.0838	.0762
15	.0686	.1867	.1543	.1639	.2477	.0762	.1639
16	.181	.0838	.1543	.1639	.2477	.1886	.061
17	.0686	.1619	.1639	.1543	.0686	.2305	.0686
18	.1982	.0762	.0686	.1715	.1715	.0686	.1715
19	.0838	.2534	.2114	.2457	.0914	.0991	.0914
20	.2286	.1067	.0914	.2534	.2363	.0991	.261
21	.0991	.261	.0991	.2363	.0991	.1067	.1067
22	.0914	.2363	.2457	.0914	.0914	.2114	.2363
23	.2381	.221	.1867	.0762	.1962	.0914	.0914
24	.1962	.2457	.1962	.1962	.1886	.221	.2038
Max	.2782	.261	.2706	.261	.2668	.2363	.3029
Min	.0686	.0762	.0686	.0762	.0686	.0686	.061
Avg	.1513	.1765	.1786	.1919	.1824	.1295	.1389

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204019 / PURNA URBAN

Feeder No / Name : 211 / 11KV ALLIED FEED EXPRESS SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0514	.0514	.0343		
2	.0514	.0857	.0514	.0514	.0514		
3			.0514	.0514	.0343		
4	.0514			.0514	.0514	.0514	
5		.1372	.0514	.0514	.0514		
6	.0514		.0514	.0514	.0343		
7		.1715	.0343	.0343	.0343		
8	.0343		.0343	.0343	.0343	.0686	.0343
9		.1543	.0514	.0514	.0514	.0686	.0343
10	.0343	.1372	.0514	.0514	.0343		.0686
11		.0514	.0343	.0514	.0514		.0514
12	.0686		.0514	.0514			.0343
13		.0514	.0343	.0514	.0686	.0686	
14	.0514	.0514	.0343	.0514			.0514
15				.0857	.0514		
16	.0686	.0514	.0514	.0857	.0514	.0514	.0514
17		.0343	.0343	.12		.0514	
18	.0686	.0514		.12	.0686		.0514
19	.0686	.0514	.0343	.0514			
20				.0514	.0514		.0514
21	.0514			.0343			
22			.0857			.1029	.0514
23	.0686		.12		.0343		
24	.12	.0686	.1372	.1029	.0343	.0343	.12
Max	.12	.1715	.1372	.12	.0686	.1029	.12
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.0607	.0844	.0550	.0608	.0457	.0622	.0545

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204040 / MATEGAON

Feeder No / Name : 201 / 11KV MATEGAON GFSS Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.101			1.8347		
9	1.046		.6173	1.0802	.9259	.823	1.0288
15			.2743				
16	.6173				.7716	.6516	.5144
24	.9088	.0953	.6516	.823	.0686	.7545	.7202
Max	1.046	.101	.6516	1.0802	1.8347	.823	1.0288
Min	.6173	.0953	.2743	.823	.0686	.6516	.5144
Avg	.8574	.0982	.5144	.9516	.9002	.7430	.7545

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204040 / MATEGAON

Feeder No / Name : 203 / 11KV AHERWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5				.0686	.0686		
8						1.0288	1.2174
17	1.3375		1.2003				
20						.0857	
24		.7716	.9945	.8402	.8573	.6859	.0686
Max	1.3375	.7716	1.2003	.8402	.8573	1.0288	1.2174
Min	1.3375	.7716	.9945	.0686	.0686	.0857	.0686
Avg	1.3375	.7716	1.0974	.4544	.4630	.6001	.643

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204040 / MATEGAON

Feeder No / Name : 204 / 11KV NAWAKI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.5432	1.9719	1.8176	1.8347		
9					1.7147	1.9376
16					1.9376	1.749
24	.1029	.0686	.0686	.0686	.0686	.0686
Max	1.5432	1.9719	1.8176	1.8347	1.9376	1.9376
Min	.1029	.0686	.0686	.0686	.0686	.0686
Avg	.8231	1.0203	.9431	.9517	1.2403	1.2517

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204052 / TADKALAS

Feeder No / Name : 202 / 11KV DHANORA KALE GFSS

GAOTHAN FEEDER

Feeder Feeder KV- 11 / OUTGOING

DATE	11-MAR-17	12-MAR-17
HR	Load (MW)	Load (MW)
5	.8478	1.0513
12	1.418	
20	1.3565	
23	.9556	
Max	1.418	1.0513
Min	.8478	1.0513
Avg	1.1445	1.0513

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204052 / TADKALAS

Feeder No / Name : 203 / 11KV TADKALAS AG Feeder
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	11-MAR-17	12-MAR-17
HR	Load (MW)	Load (MW)
9		1.7974
15	2.2891	
Max	2.2891	1.7974
Min	2.2891	1.7974
Avg	2.2891	1.7974

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204052 / TADKALAS

Feeder No / Name : 204 / 11KV DHANORA KALE AG

FEEDER SEPERATION/PURE AG

Feeder Feeder KV- 11 /

OUTGOING

DATE	11-MAR-17	12-MAR-17
HR	Load (MW)	Load (MW)
9	1.8958	1.7974
18	2.0178	
Max	2.0178	1.7974
Min	1.8958	1.7974
Avg	1.9568	1.7974

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204054 / KAWALGAON

Feeder No / Name : 201 / 11KV KAWALGAON FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	10-MAR-17	11-MAR-17	12-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	3.0483	3.0483	3.1436	
10		3.0483		1.7194
11			2.8921	
12	2.6673	2.8578		
14		2.6673		
Max	3.0483	3.0483	3.1436	1.7194
Min	2.6673	2.6673	2.8921	1.7194
Avg	2.8578	2.9054	3.0179	1.7194

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204054 / KAWALGAON

Feeder No / Name : 202 / 11 KV DHANORA MOTYA
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	10-MAR-17	11-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)
9		3.8104	
10		3.8104	
12		3.6199	
14		3.4294	
24	3.5246		.1048
Max	3.5246	3.8104	.1048
Min	3.5246	3.4294	.1048
Avg	3.5246	3.6675	.1048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204054 / KAWALGAON

Feeder No / Name : 203 / 11KV PENOOR FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	10-MAR-17	11-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)
9	.5716	1.3336	
10		1.1431	2.9874
12	.381	.5716	
14		.381	
Max	.5716	1.3336	2.9874
Min	.381	.381	2.9874
Avg	.4763	.8573	2.9874

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204078 / 33KV PIMPLA (L)

Feeder No / Name : 201 / 11KV PIMPLA(L)

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.1402		.1753	.1402	.1402	.1402	.1715
9			1.0517	.964	1.0166		.9259
10				1.0692	1.0867		
11					1.0517		
12					1.0517		
13		.8764	.8939	.7716			
24	.7011		.631	.6836	.1402	.6485	.6661
Max	.7011	.8764	1.0517	1.0692	1.0867	.6485	.9259
Min	.1402	.8764	.1753	.1402	.1402	.1402	.1715
Avg	.4207	.8764	.6880	.7257	.7479	.3944	.5878

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204078 / 33KV PIMPLA (L)

Feeder No / Name : 202 / 11KV WAI FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.4908		.5258	.4908	.3506	.5258	.3772
10				.7537	.7888		
11					.9465		
12					.8238		
13		.8063		.7716			
14		.4908	.6836				
24	.5959		.5609	.5784	.4382	.631	.6173
Max	.5959	.8063	.6836	.7716	.9465	.631	.6173
Min	.4908	.4908	.5258	.4908	.3506	.5258	.3772
Avg	.5434	.6486	.5901	.6486	.6696	.5784	.4973

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204078 / 33KV PIMPLA (L)

Feeder No / Name : 203 / 11KV PANGRA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	1.1043		1.0166	1.0166	.7362	.964	1.0631
14		1.5074	1.4198				
18		1.3321	.9114				
24	.3506		.2804	.3681	.1753	.1928	.3772
Max	1.1043	1.5074	1.4198	1.0166	.7362	.964	1.0631
Min	.3506	1.3321	.2804	.3681	.1753	.1928	.3772
Avg	.7275	1.4198	.9071	.6924	.4558	.5784	.7202

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204079 / PURNA URBAN-2

Feeder No / Name : 201 / 11KV Koliwada Feeder
(Purna To Feeder KV- 11 /
OUTGOING

SHEDDABLE URBAN

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3326	.2957	.2772	.2772	.2587	.2772	.2957
2	.3696	.2772	.2772	.3326	.2772	.2772	.3326
3	.3696	.3696	.3142	.3696	.3696	.2772	.3696
4	.462	.4435	.4435	.3696	.4805	.4251	.4435
5	.6099	.5544	.5544	.6468	.5544	.5359	.5914
6	.7023	.7023	.6838	.7392	.7023	.6283	.7392
7					.4805	.5729	
8					.4805	.5544	
9					.5175	.5544	
10					.5729	.5544	
11	.5175	.499		.5121	.5544	.499	.543
12	.4435	.4435	.5359	.4344	.499	.5175	.4755
13	.4066	.3881	.462	.3292	.4435	.462	.4435
14	.3326	.2957	.3881	.3077	.4066	.4066	.4024
15	.2587	.2772	.3326	.2926	.4066	.3511	.3292
16	.2772	.2772	.3142	.2896	.4251	.3696	.2926
17		.2402	.3326	.3292	.4435	.4066	.2957
18	.3696	.5175	.3696	.4066	.5175	.462	.4066
19	.5175	.6099	.4435	.5175	.5914	.5544	.5121
20	.4805	.5359	.5175	.462	.462	.462	.4805
21	.4435	.3881	.462	.3696	.4066	.4251	.4066
22	.3696	.3696	.3326	.2957	.3511	.3696	.3224
23	.3326	.3142	.3326	.2772	.3326	.3326	1.2178
24	.3326	.2957	.2772	.2772	.2587	.3142	.2957
Max	.7023	.7023	.6838	.7392	.7023	.6283	1.2178
Min	.2587	.2402	.2772	.2772	.2587	.2772	.2926
Avg	.4173	.4047	.4027	.3918	.4497	.4412	.4598

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204079 / PURNA URBAN-2

Feeder No / Name : 202 / 11 KV Anand Nagar (Purna
Town) Feeder KV- 11 / OUTGOING SHEDDABLE URBAN

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0745	.985	1.0029	.985	.8954	.8686	.8954
2	1.0387	.8954	.985	1.0387	.8871	.8596	.985
3	1.1462	1.0029	1.0208	1.0745	.9671	.8954	1.0387
4	1.2536	1.2536	1.4864	1.1641	1.2536	1.2536	1.1641
5	1.7013	1.7013	1.6297	1.7013	1.5223	1.3611	1.7013
6	1.97	2.0058	1.8804	1.9342	1.7909	1.4327	1.8804
7					1.1462	1.1283	
8					1.0745	1.0745	
9					1.1104	1.1999	
10	1.6118	1.6118			1.2178	1.1999	
11	1.3253	1.4685	1.7909	1.5947	1.2894	1.1283	1.6289
12	1.2894	1.5223	1.576	1.4327	1.5043	1.1104	1.6289
13	1.2894	1.4327	1.4327	1.2536	1.2178	1.0745	1.5043
14	1.2536	1.2178	1.2894	1.1946	1.1104	1.0387	1.2894
15	1.182	1.1104	1.0745	1.086	1.0745	.9671	1.1462
16	.985	1.0745	1.0029	.9671	1.1104	.9313	1.0136
17		1.0208	1.0387	.9955	1.0387	.8596	1.0136
18	1.3253	1.4327	1.1104	1.0745	1.1999	1.0029	1.1584
19	1.6632	1.5043	1.5402	1.4327	1.4685	1.3969	1.5203
20	1.5043	1.4864	1.4685	1.3778	1.2536	1.2536	1.4685
21	1.4327	1.3432	1.3969	1.2536	1.1462	1.1104	1.2894
22	1.2894	1.2178	1.2178	1.1462	1.0745	1.0387	1.1641
23	1.1462	1.0924	1.0566	.985	.9671	.9492	1.0029
24	1.0924	1.0745	.985	.985	.9313	.8775	.8954
Max	1.97	2.0058	1.8804	1.9342	1.7909	1.4327	1.8804
Min	.985	.8954	.985	.9671	.8871	.8596	.8954
Avg	1.3287	1.3073	1.2993	1.2338	1.1772	1.0839	1.2694

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204079 / PURNA URBAN-2

Feeder No / Name : 203 / 11 KV Suki Ag.Feeder
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	1.6288	1.2651	1.2176	1.8343	1.7078	1.692	1.7394
8	1.8976	1.4918	1.7711	1.866	1.7394	2.0083	1.866
9	1.6129	1.5023	1.6762	1.9631	1.7711	2.0873	1.7078
10	.8855	1.4232	1.6604	2.0683	1.8818	2.0873	1.6832
11	.7907	1.3283	1.5813	1.5604	1.7236	2.0873	1.6832
16	1.1069	1.6129	1.7711	1.6604	1.9292	1.866	1.5604
17	1.1069	1.7078	1.8185	1.989	2.0083	1.9608	1.5775
18	1.3599	1.6762	1.6129	1.8976	1.7711	1.866	1.7337
Max	1.8976	1.7078	1.8185	2.0683	2.0083	2.0873	1.866
Min	.7907	1.2651	1.2176	1.5604	1.7078	1.692	1.5604
Avg	1.2987	1.5010	1.6386	1.8549	1.8165	1.9569	1.6939

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAR-17 and 14-MAR-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204079 / PURNA URBAN-2

Feeder No / Name : 204 / 11KV Express Vaibhav
Jinning Feeder KV- 11 /
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-17	09-MAR-17	10-MAR-17	11-MAR-17	12-MAR-17	13-MAR-17	14-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0332	.0332	.0166	.0332	.0332	.0166	.0332
2	.0332	.0332	.0166	.0332	.0332	.0166	.0332
3	.0332	.0332	.0166	.0332	.0332	.0166	.0332
4	.0332	.0332	.0166	.0332	.0332	.0166	.0332
5	.0332	.0332	.0166	.0332	.0332	.0166	.0332
6	.0332	.0332	.0166	.0332	.0027	.0166	.0332
7	.0332	.0332	.0166	.0332	.0332	.0166	.0332
8	.0332	.0332	.0166	.0332	.0332	.0166	.0332
9	.0332	.2321	.2652	.0343	.0995	.0166	.0332
10	.0332	.2652	.2486	.2058	.3647	.0332	.0343
11	.0332	.2652	.2652	.2774	.3149	.0332	.0343
12	.0332	.2818	.2486	.208	.2818	.0332	.0343
13	.0332	.2652	.2486	.208	.3481	.0332	.0339
14	.0332	.2818	.0332	.1734	.3315	.0332	.0343
15	.0332	.2818	.2486	.1715	.1492	.0332	.0343
16	.0332	.2818	.2486	.1715	.2652	.0332	.0347
17	.0332	.3149	.2652	.2572	.0166	.0332	.0343
18	.0332	.3149	.2652	.1989	.0166	.0332	.0343
19	.0332	.1658	.0332	.1989	.0166	.0332	.0343
20	.0332	.0166	.0332	.0332	.0166	.0332	.2401
21	.0166	.0166	.0332	.0332	.0166	.0332	.2401
22	.0332	.0166	.0332	.0332	.0166	.0332	.2229
23	.0305	.0166	.0332	.0332	.0166	.0332	.2401
24	.0332	.0332	.0166	.0332	.0332	.0166	.0332
Max	.0332	.3149	.2652	.2774	.3647	.0332	.2401
Min	.0166	.0166	.0166	.0332	.0027	.0166	.0332
Avg	.0324	.1382	.1105	.1057	.1058	.0263	.0674