

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 314016 / 33/11KV KALIMATI

Feeder No / Name : 201 / KATTIPAR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.945	1.0631	1.0562	1.0517	.9962	1.1641	1.1043
2	.9646	1.0288	.9998	1.0623	.9568	1.1088	1.0688
3	.9145	.9991	.9755	1.0364	.9145	1.0924	.9877
4	.9172	1.0059	1.0985	1.0467	.8951	1.1283	.9602
5	.7811	1.0745	.933	1.0364	.8905	1.1641	.9686
6	.7316	1.065	.9374	1.0437	.9145	1.1222	.9686
7	.8951	1.0682	.9061	.9686	.9282	1.1273	.9722
8	.9297	.9088	.9217	.9722	.9282	1.1283	.9414
9	1.1283	.9945	.8951	.6455	.953	1.182	.9686
10	.8436	.884	1.0608	.6706	.9297	.985	.9804
11	.8697	.6944	.9945	.7186	.9297	.8488	.9145
12	.933	.7926	1.0136	.8535	.953	.8905	.8688
13	.9488	.8749	.9431	.8488	.9259	.9259	.8459
14	.7811	.823		.8333	.9488	.9568	.6062
15	.8642	.8749	1.0534	.8951	.8905	.9755	.6773
16	.8993	.8488	1.0387	.933	.8796	.7099	.7716
17	1.0425	.884	.9217	.7968	1.1157	.8749	.8322
18	1.1523	.9602	.9259	.7621	1.0456	1.0425	1.0719
19	1.1043	1.0978	1.1271	.8796	1.182	1.1437	1.2637
20	1.166	1.1271	1.1768	1.0608	1.1946	1.1797	1.0814
21	1.2094	1.1305	1.1498	1.0031	1.2178	1.1797	1.1963
22	1.1043	1.0562	1.1523	1.0526	1.1361	1.1336	1.1105
23	1.2003	1.0814	1.0802	.9842	1.0402	1.1305	1.0517
24	.9686	1.2254	1.0402	1.0911	1.0082	1.182	1.1012
Max	1.2094	1.2254	1.1768	1.0911	1.2178	1.182	1.2637
Min	.7316	.6944	.8951	.6455	.8796	.7099	.6062
Avg	.9706	.9818	1.0175	.9269	.9906	1.0574	.9714

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 314016 / 33/11KV KALIMATI

Feeder No / Name : 202 / SITEPAR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3073	1.3032	1.5061	1.4815	1.2574	1.2803	1.0082
2	1.258	1.2357	1.5238	1.4175	1.1961	1.2178	1.1706
3	1.2803	1.2308	1.4548	1.4449	1.1934	1.2012	1.1222
4	1.2536	1.2536	1.4352	1.4148	1.1498	1.0924	1.0974
5	1.3032	1.3432	1.4373	1.4352	1.21	1.1706	1.1273
6	1.283	1.3321	1.4883	1.4529	1.1469	1.1462	1.134
7	1.387	1.5769	1.4746	1.1393	1.3748	1.4148	1.1946
8	1.6617	1.5223	1.4563	1.5947	1.5091	1.5181	1.5402
9	1.6804	1.5581	1.595	1.3998	1.4563	1.5746	1.3756
10	1.439	1.4864	1.6301	1.858	1.1827	1.576	1.6278
11	1.5043	1.7718	1.5729	1.6301	1.3306	1.8296	1.423
12	1.4706	1.7353	1.6832	1.6118	1.5565	1.7375	1.6461
13	1.4198	1.3032	1.576	1.3496	1.5729	1.4045	1.5893
14	1.1616	1.3643	1.5947	1.3032	1.1283	1.2986	1.0317
15	1.5775	1.701	1.5203	.7455	1.7558	1.1576	1.4937
16	1.6476	1.8823	1.5364	1.2003	1.7924	1.7558	1.6078
17	1.9366		1.335	1.5424	1.4083	1.8298	1.4045
18	1.6832		1.3203	1.3112	1.3073	1.7556	1.3756
19	1.4083	1.8267	1.5415	1.448	1.2012	1.4415	1.1576
20	1.1203	1.5947	1.5415	1.2266	1.262	1.2567	1.1576
21	1.2803	1.5775	1.5249	1.3203	1.2752	1.2752	1.1273
22	1.3321	1.543	1.4723	1.2616	1.267	1.262	1.1763
23	1.3432	1.5592	1.4685	1.2742	1.2803	1.2012	1.1458
24	1.283	1.3575	1.5249	1.4043	1.2289	1.2883	1.1888
Max	1.9366	1.8823	1.6832	1.858	1.7924	1.8298	1.6461
Min	1.1203	1.2308	1.3203	.7455	1.1283	1.0924	1.0082
Avg	1.4176	1.5027	1.5089	1.3862	1.3351	1.4036	1.2885

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 314016 / 33/11KV KALIMATI

Feeder No / Name : 203 / BHOSA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3535	1.2803	1.2803	1.267	1.262	1.3676	1.0829
2	1.3169	1.2382	1.2567	1.2752	1.2308	1.2803	1.0269
3	1.3032	1.2803	1.1888	1.2489	1.2071	1.2986	.961
4	1.2936	1.3306	1.2197	1.2567	1.2012	1.3676	.9979
5	1.2986	1.3575	1.2437	1.2254	1.2071	1.2803	1.0164
6	1.2851	1.2986	1.2437	1.2437	1.065	1.2986	1.0164
7	1.2851	1.2308	1.1765	1.1706	1.1827	1.2178	1.1157
8	1.2715	1.1088	1.1946	1.2127	1.2254	1.2536	1.1523
9	1.3611	1.2197	1.1888	1.182	1.2127	1.2437	1.0425
10	1.1104	1.2012	1.0486	1.2254	.9877	1.2752	1.0608
11	1.2178	1.1765	1.1145	.9979	1.1157	1.2071	1.0608
12	1.267	.1907	1.086	.9979	1.2012	1.2071	1.0679
13	1.262	.9522		.961	1.1088	1.1888	.8413
14	1.0608	.9795	.8145	.9979	.961	1.1946	.9511
15	1.0164	.9145	.8417	.961	1.0791	1.1765	
16	1.134	.8871	.9412	1.1706	1.0608	1.2071	1.0425
17	1.2178	1.0059	1.0791	1.1523	1.1706	1.267	.7842
18	1.2894	1.2357	1.086	.961	1.2071	1.0974	.961
19	1.4449	1.3306	1.423	1.2803	1.4045	1.386	.9231
20	1.4937	1.3306	1.4045	1.2936	1.3847	1.3676	1.2136
21	1.2763	1.386	1.3121	1.3535	1.475	1.3306	1.0688
22	1.3321	1.3352	1.3535	1.3306	1.3969	1.2986	1.2197
23	1.3575	1.3306	1.3306	1.2986	1.3717	1.0456	1.2012
24	1.3394	1.2795	1.2936	1.2803	1.2936	1.3756	1.0242
Max	1.4937	1.386	1.423	1.3535	1.475	1.386	1.2197
Min	1.0164	.1907	.8145	.961	.961	1.0456	.7842
Avg	1.2745	1.1617	1.1792	1.1810	1.2089	1.2597	1.0362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 314022 / 33kv amgaon sub station

Feeder No / Name : 201 / 11 KV irri

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7558	1.6448	1.5684	1.6644	1.8473	1.6817	1.7558
2	1.7375	1.6263	1.5466	1.6095	1.829	1.6632	1.701
3	1.7375	1.6448	1.5466	1.5729	1.7558	1.7002	1.6632
4	1.7372	1.6078	1.4632	1.5708	1.6827	1.6632	1.6448
5	1.7002	1.6263	1.4266	1.5524	1.7193	1.6804	1.6078
6	1.6817	1.7364	1.419	1.5708	1.7924	1.643	1.4937
7	1.7375	1.7924	1.3169	1.5708	1.7741	1.6804	1.4937
8	1.7558	1.7002	1.0802	1.6827	1.6461	1.6804	1.423
9	1.829	.924	.7167	1.6278	1.3717	1.4784	1.4937
10	1.7375	1.2936	1.3969		1.3169	1.5708	1.4377
11	1.6032	1.6057	1.5402	1.5893	1.5655	1.6617	1.3676
12	1.7353	1.643	1.7551	1.6827	1.5089	1.0751	1.2936
13	1.5466	1.46	1.5581	1.6827	1.4335	1.5708	1.2071
14	1.6409	1.4784	1.701	.7392	1.3957	1.5708	1.2567
15	1.9239	1.5708	1.5912	1.2567	1.5844	1.4784	1.3717
16	1.9427	1.4415	1.5181	1.3306	1.3203	1.7002	1.4083
17	1.9404	1.4415	1.7741	.6348	1.5278	1.829	1.4449
18	1.885	1.6221	1.6827	1.7193	1.6787	1.8473	1.6032
19	2.1622	1.358	1.9204	1.829	1.8656	1.8839	1.2071
20	2.0144	1.226	1.7926	1.7375	1.7741	1.9753	1.4523
21	1.8665	1.5278	1.8107	1.7193	1.8107	1.7558	1.6095
22	1.7372	1.4864	1.7193	1.7558	1.7375	1.8473	1.6032
23	1.6632	1.6598	1.8107	1.7375	1.6827	1.7924	1.4523
24	1.8107	1.6632	1.6057	1.701	1.8656	1.7002	1.7741
Max	2.1622	1.7924	1.9204	1.829	1.8656	1.9753	1.7741
Min	1.5466	.924	.7167	.6348	1.3169	1.0751	1.2071
Avg	1.7867	1.5325	1.5525	1.5451	1.6453	1.6721	1.4903

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 314022 / 33kv amgaon sub station

Feeder No / Name : 202 / Anjora

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1437	2.0485	2.1948	1.8473	2.2314	2.0698	2.0698
2	2.1068	1.9387	2.2081	1.829	2.1437	2.0328	2.0328
3	2.0328	2.0119	2.2634	1.7924	2.1068	1.9959	1.9589
4	2.0698	2.0851	2.2032	1.6632	2.0698	2.0328	1.9589
5	2.1437	2.1948	2.0119	1.5893	2.0698	2.0538	1.9589
6	2.1807	2.268	1.9022	1.6263	2.1068	1.9791	1.848
7	2.1437	2.3525	1.9239	1.7741	2.1437	2.0538	1.7741
8	2.2314	2.2546	1.5364	1.848	2.0851	2.0538	1.922
9	1.9959	2.1807	1.8656	1.7741	1.9387	2.0328	.9979
10	2.1437	2.2546	1.9022	1.7372	1.8861	1.6632	1.3676
11	2.1125	2.3777	2.1948	1.9589	1.8107	1.2449	1.848
12	2.3388	2.1807	1.6461	2.1068	1.1317	1.9791	1.885
13	2.2257	2.3045	1.5729	2.0485	1.4712	1.7924	1.8656
14	2.0748	2.1068	1.3169	1.7924	.9808	1.9959	1.7741
15	2.1502	2.268	1.4632	1.9022	1.7353	1.7924	1.7193
16	2.2257	2.1068	1.5893	2.0119	1.7353	1.9791	1.7558
17	2.1502	2.4508	1.7002	2.268	1.6598	2.2314	1.9387
18	2.2916	2.3388	1.9022	2.1807	1.9993	2.2314	1.7558
19	2.4025	2.3765	2.0485	2.2314	2.1216	2.2314	1.9616
20	2.0698	2.2634	2.2177	2.1437	1.9387	2.1068	2.0119
21	2.1582	2.3011	1.848	2.2314	1.9387	2.1068	2.0485
22	2.0485	2.1216	1.7558	2.3411	1.9387	1.9959	1.9993
23	2.1068	2.3388	1.9022	2.3045	2.0485	2.0328	2.0119
24	2.1948	2.1437	2.1132	1.8473	2.3045	2.1068	2.1068
Max	2.4025	2.4508	2.2634	2.3411	2.3045	2.2314	2.1068
Min	1.9959	1.9387	1.3169	1.5893	.9808	1.2449	.9979
Avg	2.1559	2.2195	1.8868	1.9521	1.8999	1.9915	1.8571

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 314022 / 33kv amgaon sub station

Feeder No / Name : 203 / Amgaon

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9054	.961	.9808	1.0136	1.1088	1.0456	1.0456
2	.9054	.8871	.9808	.9412	1.0456	.9709	.9808
3	.9054	.8871	.9808	.9511	1.0082	.9709	.9808
4	.8299	.8871	.9808	1.0242	1.0082	.9808	.9808
5	.9054	.9709	.9808	1.0242	1.0456	.9808	.9808
6	.9709	.9709	1.2071	1.1088	1.1088	1.0562	1.0456
7	1.0456	.9709	1.2071	1.1827	.9808	1.0562	1.0456
8	1.1827	1.0456	1.0974	1.1706	1.0456	.9808	.9709
9	.9709	1.0456	1.0974	1.0242	1.0456	.9709	1.1203
10	.9709	.9709	1.0974	1.0974	.9054	.9709	.9709
11	.9808	1.0456	1.1706	1.1088	1.0562	.9709	.8962
12	.9054	1.0456	1.1706	1.1203	1.4712	.9709	.8962
13	.9054	1.1088	1.1706	1.1088	1.1317	.9709	.8871
14	.8299	.9709	.9511	.961	1.6598	.9054	.8215
15	.9054	1.1088	1.0242	1.0349	.9808	.9709	.8131
16	.9054	1.1088	1.0974	1.0349	1.0562	.9054	.961
17	1.0562	1.0456	1.0349	1.0349	1.0562	1.0456	.961
18	1.0349	1.2826	1.0242	1.1706	1.2071	1.1827	1.1317
19	1.4045	1.4335	1.39	1.39	1.4784	1.39	1.358
20	1.3306	1.4335	1.4632	1.39	1.3306	1.3169	1.2437
21	1.1706	1.358	1.3169	1.3169	1.2567	1.2437	1.2071
22	1.1706	1.2437	1.2308	1.3169	1.2567	1.1827	1.2071
23	1.1088	1.1317	1.1584	1.1706	1.1088	1.0456	1.0242
24	.9709	.961	.9808	1.0136	1.1088	1.0456	1.0456
Max	1.4045	1.4335	1.4632	1.39	1.6598	1.39	1.358
Min	.8299	.8871	.9511	.9412	.9054	.9054	.8131
Avg	1.0113	1.0781	1.1164	1.1129	1.1442	1.0471	1.0240

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 314022 / 33kv amgaon sub station

Feeder No / Name : 204 / 11 KV Salekasa

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3306	1.3491	1.4266	1.267	1.4998	1.1949	1.4083
2	1.3676	1.3306	1.4266	1.267	1.4266	1.1576	1.3169
3	1.4415	1.3491	1.4335	1.2127	1.2936	1.1949	1.2936
4	1.4449	1.3352	1.3253	1.2437	1.2936	1.1763	1.2567
5	1.4449	1.2986	1.3352	1.2437	1.2936	1.1317	1.2197
6	1.4632	1.386	1.3392	1.2803	1.3121	1.1317	1.3352
7	1.423	1.423	1.262	1.2803	1.3491	1.2637	1.1643
8	1.2752	1.3491	1.2489	1.2254	1.2197	1.2826	1.2936
9	1.2567	1.2986	1.3014	1.2437	1.2012	1.1763	***
10	1.1949	1.1273	.9593	1.2071	1.1317	1.0269	1.0269
11	1.0562	.6602	.9955	.2054	1.0374	1.0269	.8215
12	1.0374	.9054	.8507	1.1088	1.0751	1.1016	.8215
13	1.0562	1.0829	.905	1.2936	1.0751	1.2136	1.1643
14	1.2071	1.0642	1.1584	1.1273	.7733	1.2136	.5709
15	1.2449	1.1827	1.1706	1.2567	.9054	1.2136	1.0456
16	1.3957	1.4083	1.3169	1.2382	.9808	1.2936	1.2323
17	1.3817	1.3121		1.3306	1.0374	1.4266	1.2936
18	1.4563	1.4335	1.3535	1.423	1.1317	1.4083	.6224
19	1.6617	1.5278	1.5181	1.4632	1.386	1.5912	1.2637
20	1.6244	1.5466	1.4998	1.4815	1.2567	1.5181	1.2826
21	1.5154	1.4712	1.4449	1.386	1.2382	1.4449	1.2071
22	1.4784	1.2715	1.3213	1.2382	1.2197	1.3717	1.1128
23	1.4045	1.4335	1.3756	1.5546	1.2567	1.4083	1.2803
24	1.7964	1.386	1.46	1.3169	1.4998	1.2136	1.4815
Max	1.7964	1.5466	1.5181	1.5546	1.4998	1.5912	11.2026
Min	1.0374	.6602	.8507	.2054	.7733	1.0269	.5709
Avg	1.3733	1.2889	1.2795	1.2456	1.2039	1.2576	1.5716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 317007 / 132/33 KV AMGAON S/S

Feeder No / Name : 207 / 33/11 kv 10 MVA T/R

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.1361	4.6742	3.4019	3.095	3.4751	3.083	3.2236
2	3.083	4.4593	3.2956	2.8172	3.2819	3.0298	3.1699
3	3.083	4.4056	3.2425	2.9012	3.4385	3.0298	3.083
4	3.0298	4.3519	3.0476	2.7401	3.2236	3.0298	3.0087
5	3.0298	4.3439	3.2773	2.6863	3.1493	3.0624	3.0087
6	3.1699	3.7071	3.3311	2.7938	3.3122	3.0087	2.955
7	3.2425	3.6677	3.2236	2.9767	3.2579	3.1699	2.9235
8	3.2956	3.3128	2.7641	2.9973	3.3311	3.1893	2.9235
9	3.0167	3.2956	2.9235	2.8607	3.0298	2.9973	2.3388
10	3.155	3.2076	2.9235	2.8607	2.8704	2.7343	2.4188
11	3.5614	3.4019	3.3488	3.0498	3.1161	2.8172	3.0298
12	4.6245	3.4019	3.0407	3.2956	2.6863	2.9447	2.9767
13	3.1893	3.4551	2.7641	3.155	2.6863	2.9647	2.955
14	2.9973	3.4551	2.4983	2.8921	2.6578	2.7109	2.7778
15	3.0298	3.4551	2.6326	3.083	2.6818	2.7869	2.8395
16	3.0298	3.5997	2.7692	3.4019	2.8395	3.2956	2.9447
17	3.1161	3.7071	2.7869	3.3653	2.8395	3.4179	2.8607
18	3.4019	3.774	3.2425	3.5231	3.1893	3.3653	2.7869
19	4.0295	3.8009	3.7466	3.9638	3.7071	3.8009	3.638
20	3.638	3.7466	4.0055	3.638	3.4385	3.6534	3.4568
21	3.5837	3.7466	3.4019	3.638	3.3848	3.4385	3.4208
22	3.3488	3.5294	3.2579	3.7071	3.3311	3.2425	3.4208
23	3.2425	3.4385	3.2579	3.7466	3.2236	3.2236	3.2236
24	3.2425	4.561	3.3311	3.095	3.5837	3.1699	3.1699
Max	4.6245	4.6742	4.0055	3.9638	3.7071	3.8009	3.638
Min	2.9973	3.2076	2.4983	2.6863	2.6578	2.7109	2.3388
Avg	3.3032	3.7708	3.1464	3.1785	3.1556	3.1319	3.0231

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 317007 / 132/33 KV AMGAON S/S

Feeder No / Name : 208 / 33/11 KV 5 MVA T/R

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0407	3.1824	3.0178	2.9012	3.2236	2.7692	3.1699
2	2.9864	3.0727	2.963	2.9321	3.1493	2.8235	3.1699
3	3.0087	3.0727	2.1068	2.9321	3.0624	2.7938	2.9127
4	2.9864	2.963	2.2177	2.7984	2.9864	2.7692	2.8235
5	2.8778	3.1824	2.6326	2.7984	3.0178	2.7692	2.7401
6	2.9864	3.0178	1.2894	2.7166	3.0727	2.6886	2.7149
7	3.0624	2.7692	1.2357	2.7984	2.7984		2.6337
8	2.9321	3.0407	2.524	2.7435	2.2405	2.2731	2.8235
9	3.0087	2.9012	1.8073	2.7149	2.4714	2.6606	2.5789
10	2.7692	2.2497	2.384	2.5789	2.6063	2.5252	2.524
11	2.4714	2.1068	2.524	1.7541	2.3891	2.7641	2.2805
12	2.7149	2.2731	2.4691	2.6057	1.7924	2.1491	2.1719
13	2.6063	2.4394	2.4143	2.7721	2.3285	2.6863	2.0851
14	2.6326	2.384	2.6057	1.6409	2.1068	2.6235	2.0851
15	3.0407	2.7166	2.6612	2.4143	2.5206	2.6006	2.3594
16	3.3665	2.8532	2.8235	2.6326	2.3594	2.9235	2.6606
17	3.1493	2.6886	2.7932	1.8604	2.3891	3.095	2.9321
18	3.095	2.7401	2.8235	2.9321	2.7109	3.1893	2.7692
19	3.638	2.8275	3.2922	3.2579	3.1493	3.3122	2.7435
20	3.5117	2.6886	3.2156	3.1493	2.9321	3.4208	2.5503
21	3.2579	2.8532		3.1493	3.0407	3.2579	5.2675
22	2.9864	2.7149	3.0178	3.0407	1.5203	3.2036	2.5789
23	2.9321	2.8235	2.963	3.2036	2.9321	3.1161	2.6606
24	3.095	3.2156	2.8532	2.9081	3.3311	2.2731	3.1893
Max	3.638	3.2156	3.2922	3.2579	3.3311	3.4208	5.2675
Min	2.4714	2.1068	1.2357	1.6409	1.5203	2.1491	2.0851
Avg	3.0065	2.7824	2.5493	2.7182	2.6721	2.8125	2.7677

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 317007 / 132/33 KV AMGAON S/S

Feeder No / Name : 401 / 33 KV SALEKASA FDR

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9204	2.0645	9.9932	2.0645		2.1879	2.0388
2	1.8947	2.0405	1.5238	2.0405	1.9393	2.1879	2.0388
3	1.9204	2.0405	1.4089	2.0405	1.8896	8.7574	2.0119
4	1.9204	.9482	1.4089	2.0405	1.8519	2.0645	1.989
5	1.9685	1.0059	1.4255	2.1136	1.9033	2.1382	1.9662
6	2.1382	2.0622	1.5912	2.2131	2.0576	2.2382	2.4863
7	2.3594	2.4366	2.2634	2.4646	2.2891	2.3371	2.7035
8	2.2611	2.4777	2.4863	2.3868	2.2891	2.6355	2.7846
9	2.2834	2.2611	2.2874	1.8461	2.0153	2.2377	2.2834
10	2.6235	2.672	2.7692	1.7764	2.7526	2.6235	2.3868
11	1.5238	2.7035	2.9001	2.4577	2.8841	2.7692	2.3594
12	1.2431	2.556	2.8509	2.5749	2.536	2.8664	1.2346
13	1.2631	2.6235	2.7206	2.4577	2.3868	3.095	1.6804
14	1.3443	2.6235	1.9433	2.5749	2.2834	2.3805	2.364
15	9.7737	2.7526	1.5546	2.6235	2.4777	2.4006	2.0405
16	2.7035	3.2373	2.4291	2.556	2.5749	2.3525	2.3102
17	2.8018	2.7526	2.4291	2.672	2.6235	2.5749	2.4966
18	2.8664	2.4366	2.7692	2.332	2.2348	1.4746	2.1628
19	3.4494	2.6292	2.8921	3.0687	3.0384	2.8172	2.7343
20	3.2065	2.7343	2.8395	2.9447	2.8607	2.7641	2.7046
21	3.2047	2.6006	2.6235	2.8086	2.6235	3.3288	2.1033
22	2.3137	2.3148	2.3137	2.5434	2.5943	2.3137	1.9839
23	2.1628	2.1125	2.1382	1.4083	2.2634	2.1382	1.7901
24	1.9919	2.0645	2.1365	2.0645	1.9113	2.2377	2.0622
Max	9.7737	3.2373	9.9932	3.0687	3.0384	8.7574	2.7846
Min	1.2431	.9482	1.4089	1.4083	1.8519	1.4746	1.2346
Avg	2.5474	2.3396	2.5708	2.3364	2.3600	2.7051	2.1965

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 317007 / 132/33 KV AMGAON S/S

Feeder No / Name : 402 / 33 KV INCOMING DEORI

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	9.2078	10.2081	9.9932	9.9394	9.6022	9.2033	10.0452
2	9.2078	10.0469	9.9394	9.7245	9.2181	8.9438	9.9366
3	9.0535	10.0469	9.9932	9.5633	9.1632	9.0369	9.8823
4	8.9506	9.9394	9.9932	9.2307	9.4376	8.9815	9.9909
5	9.105	10.1543	10.1543	9.3936	9.6022	9.1478	10.0452
6	10.0383	11.2289	10.9602	10.4796	10.0412	8.9815	10.6996
7	7.3045	11.4815	11.2689	10.9499	10.9602		10.6967
8	7.8847	11.4975	11.5112	11.294	11.2826	10.6967	10.7453
9	9.7668	11.7661	11.5655	10.6424	8.0916	10.3121	10.0823
10	11.0265	10.8596	11.2397	8.8889	9.9794	10.4253	10.7002
11	10.9682	11.1854	10.5881	10.0452	9.4102	10.0412	10.3167
12	10.6379	10.6424	10.751	9.2181	10.0903	10.096	10.535
13	9.5473	10.3167	10.3704	8.3179	10.5339	10.2566	10.2566
14	9.7737	10.0412	9.2587	8.3459	9.9794	9.9794	7.3937
15		8.682	9.273	8.85	9.7022	9.9794	6.5381
16	10.371	10.3704	7.8464	9.6902	9.8131	10.3155	9.0535
17	11.0768	10.3155	8.7597	10.7002	9.8131	10.9191	9.6651
18	11.4026	11.5112	10.9139	10.9191	8.6694	11.4569	10.5841
19	13.8615	13.9003	14.1838	13.1396	9.8583	13.9003	12.4343
20	13.5746	13.5528	13.4117	13.0287	12.5852	13.498	12.3457
21	12.5103	12.5652	12.5103	12.3228	11.809	12.4743	11.0288
22	11.4678	11.6981	11.2483	11.0906	10.4801	10.9219	8.059
23	10.6916	10.7002	10.5841	10.535	9.7119	10.7556	6.4472
24	9.3622	10.5841	10.4253	9.7737	19.4239	9.7119	10.3167
Max	13.8615	13.9003	14.1838	13.1396	19.4239	13.9003	12.4343
Min	7.3045	8.682	7.8464	8.3179	8.0916	8.9438	6.4472
Avg	10.2953	10.9706	10.6976	10.2535	10.3858	10.4363	9.9083

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 317007 / 132/33 KV AMGAON S/S

Feeder No / Name : 403 / 33 KV Tedha feeder

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.4095	8.5905	7.9578	8.7814	8.79	8.4659	8.9461
2	6.3077	8.5391	7.9058	8.582	8.79	8.4659	8.79
3	7.5446	8.4877	7.7498	8.53	8.634	8.3608	8.53
4	7.4943	8.4877	7.6458	8.4259	8.7289	8.203	8.4779
5	7.4943	8.5391	5.9975	8.53	8.6763	8.203	8.53
6	7.7829	8.8992	8.0979	8.6763	9.0969	8.4134	8.834
7	8.1899	6.4603	8.5185	8.702	9.2061	9.5702	9.2061
8	8.546	7.1777	9.6708	7.8155	6.0597	9.5702	9.3622
9	6.3077	6.7833	9.1541	9.0998	9.1021	8.9461	9.2581
10	8.9026	7.1256	8.79	8.8015	9.7737	8.5185	9.5182
11	4.3982	6.0997	6.2872	9.1993	9.6194	8.79	9.5702
12	8.6963	2.6389	8.8512	9.0998	9.5679	8.738	6.4152
13	8.9529	3.9283	8.53	8.3608	8.1659	8.7449	4.6296
14	8.0453	4.6742	8.842	8.3082	7.8875	5.8642	3.3333
15	10.3264	4.9228	8.4134	7.4143	7.9927	6.0334	5.3315
16	10.6825	5.4201	8.9392	8.7814	8.79	6.1214	6.9959
17	7.0445	6.685	8.4134	6.9845	9.4136	9.1021	6.7021
18	9.2901	6.9182	8.686	9.1993	8.842	7.7498	6.9119
19	7.3251	7.1725	8.9392	7.1422	10.0435	10.5584	7.9864
20	7.5286	8.7517	10.2012	9.6651	8.1664	10.2464	8.4779
21	9.5182	9.2021	9.3073	9.4125	9.2547	8.4134	3.035
22	8.7963	8.9403	8.4951	9.1495	8.6643	9.1021	7.7161
23	8.8477	6.8233	8.894	8.834	8.3082	9.1021	7.376
24	8.3425	8.5905	8.0453	8.9981	8.9461	8.4659	8.9981
Max	10.6825	9.2021	10.2012	9.6651	10.0435	10.5584	9.5702
Min	4.3982	2.6389	5.9975	6.9845	6.0597	5.8642	3.035
Avg	8.0323	7.0774	8.4305	8.6039	8.7717	8.4895	7.6222

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 317007 / 132/33 KV AMGAON S/S

Feeder No / Name : 405 / 33/0.4 KV substation

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

Feeder KV- 33 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5396	.2915	.6161	.5521	.3155	.6127	.5121
2	.5316	.5144	.5201	.5281	.3292	.6219	.5053
3	.4961	.4967	.4527	.5281	.3018	.7042	.4458
4	.4755	.4744	.423	.3772	.3601	.6321	.3292
5	.4595	.5761	.3155	.3944	.2921	.4115	.3086
6	.4338	.5533	.3549	.4024	.2961	.3121	.2629
7	.4458	.3201	.3155	.3978	.3567	.3161	.2469
8	.2606	.2641	.3109	.3601	.2921	.3281	.2641
9	.2743	.2721	.2801	.3161	.2801	.2841	.192
10	.2926	.2641	.2801	.3081	.3018	.3384	.3521
11	.3498	.3064	.2698	.3567	.2926	.4115	.1829
12	.4115	.3292	.2698	.4064	.2321	.3429	.1858
13	.4401	.3549	.3018	.4115	.2263	.4001	.2263
14	.4001	.3601	.3018	.4218	.3201	.4527	.2023
15	.4058	.4464	.3064	.4458	.3246	.459	.2401
16	.439	.4115	.3561	.4401	.2515	.4372	.2801
17	.4115	.459	.3601	.4001	.3258	.4115	.2126
18	.6481	.6161	.4652	.5681	.5487	.4401	.3086
19	.8065	.5573	.5521	.583	.6379	.4252	.3658
20	.8579	.7613	.5281	.6413	.6299	.5144	.4252
21	.7716	.7482	.5853	.583	.6516	.5396	.3601
22	.7385	.487	.5658	.5761	.6407	.607	.3658
23	.719	.8025	.6127	.2606	.6173	.8779	.3544
24	.5733	.4801	.8573	.583	.2641	.679	.5316
Max	.8579	.8025	.8573	.6413	.6516	.8779	.5316
Min	.2606	.2641	.2698	.2606	.2263	.2841	.1829
Avg	.5076	.4645	.4251	.4517	.3787	.4816	.3192

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 317007 / 132/33 KV AMGAON S/S

Feeder No / Name : 406 / 33 KV KALIMATI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	10.6733	11.2346	7.8441	7.1108	7.2742	7.3434	7.0416
2	10.5681	10.8276	7.7904	7.1605	6.9959	7.3434	7.0416
3	10.5298	10.6579	7.8464	7.0611	6.9473	7.1422	6.7901
4	10.1371	10.8425	6.9799	6.9616	6.7833	7.0919	6.7398
5	10.1852	11.0688	6.9307	6.9616	6.685	7.0416	6.6895
6	10.2686	11.3049	7.1108	6.8124	6.8816	7.0416	6.8404
7	11.1911	11.6667	7.4091	6.6632	6.6358		7.0416
8	11.358	11.5741	7.324	7.0611	7.4589	7.9973	6.4266
9	11.4906	11.0426	7.3594	6.8124	7.0919	7.6452	14.5336
10	10.8157	11.7095	7.1274	6.6135	6.8404	6.9616	8.802
11	11.1745	10.7596	7.2257	6.5386	7.3434	7.6578	6.9182
12	11.7233	10.9511	5.5384	4.8788	6.8673	6.2369	7.4943
13	11.4769	11.2895	6.713	5.8676	6.9182	7.608	7.1216
14	7.2348	9.8228	6.8124	6.5867	6.1363	7.376	6.713
15	8.3419	11.1671	6.9307	6.3409	7.3594	7.1605	6.8673
16	9.3073	11.2077	7.8189	7.4589	7.3097	11.8073	10.2195
17	9.8028	9.8874	7.2628	7.4714	7.2102	7.7572	7.2931
18	10.5762	10.5104	7.0782	6.8016	5.8299	7.2428	7.0919
19	8.8735	12.2983	7.6303	7.6452	7.7321	7.5617	6.6055
20	11.9028	12.4115	7.8847	7.1925	7.5286	7.6303	7.7161
21	12.0085	12.3229	7.8338	7.26	8.538	7.7321	7.5617
22	12.0851	11.7381	7.5949	7.4091	12.1234	11.9696	11.9777
23	11.773	11.7593	7.26	7.0782	7.2931	7.1422	7.444
24	10.8676	11.3546	7.3097	7.1108	7.1274	7.444	7.0416
Max	12.0851	12.4115	7.8847	7.6452	12.1234	11.9696	14.5336
Min	7.2348	9.8228	5.5384	4.8788	5.8299	6.2369	6.4266
Avg	10.5986	11.2254	7.2757	6.8691	7.2880	7.7363	7.7505

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 317007 / 132/33 KV AMGAON S/S

Feeder No / Name : 407 / 33 KV KAWARABANDH

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8004	1.7684	1.9547	1.8724	1.9839	1.8204	1.9033
2	1.8204	1.749	1.8519	1.8724	1.9839	1.749	1.8519
3	1.8519	1.5769	1.7804	1.8519	1.8821	1.749	1.8204
4	1.7295	1.6461	1.5089	1.8004	1.8204	1.701	1.749
5	1.8004	1.6461	1.6301	1.8724	1.7164	1.5947	1.8004
6	1.8724	1.7164	1.8204	1.7684	1.8204	1.5775	1.7684
7	1.8519	1.6975	1.8519	1.8519	1.6975	1.6598	1.8724
8	1.6787	7.0988	1.8004	1.6975	1.9616	1.6409	2.009
9	8.7517	1.6598	1.6787	1.4586	1.6278	1.4255	.439
10	1.4083	1.5769	1.8004	1.4243	1.6598	1.278	1.1963
11	1.6278	1.5261	1.6975	1.2071	1.6787	1.5415	1.4403
12	1.6278	1.5769	1.7804	.9945	1.6598	1.6221	1.5432
13	1.5592	1.6301	1.7604	1.17	1.6598	1.358	1.5089
14	1.8107	1.6461	1.6787	1.0442	1.5415	1.5089	.9556
15	1.7295	1.6461	1.7295	1.3889	1.6409	1.7101	1.0322
16	1.933	1.3923	1.9342	1.5083	1.4752	1.9113	1.1934
17	1.8821	1.5261	1.6095	1.6461	1.5592	1.9033	1.749
18	1.9113	1.8821	1.8107	1.7295	1.861	1.9033	1.5947
19	2.1605	2.2611	2.0508	2.0508	2.0622	2.1033	1.8673
20	2.0805	2.1033	2.1033	1.9982	2.0805	2.0285	1.7541
21	1.7353	2.0576	2.0285	1.8204	1.8404	2.1559	1.7353
22	1.6461	1.8313	1.8519	1.9547	1.9244	1.8004	1.4918
23	1.8724	1.9667	1.9547	1.9033	1.7164	1.8519	1.5604
24	1.8004	1.8656	1.9244	1.9244	1.9547	1.7684	1.8004
Max	8.7517	7.0988	2.1033	2.0508	2.0805	2.1559	2.009
Min	1.4083	1.3923	1.5089	.9945	1.4752	1.278	.439
Avg	2.0809	1.9603	1.8163	1.6588	1.7837	1.7234	1.5682

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

DEORI S/DN.[389]

BU 0389

Substation No/ Name :- 314004 / 33/11 KV CHICHGAD

Feeder No / Name : 201 / 11 KV Chichgad

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5887	.5372	.6026	.7335	.6729	.6403	.6977
2	.5678	.5141	.5956	.7228	.6493	.6154	.6723
3	.5678	.4923	.5927	.7247	.626	.6143	.6505
4	.522	.5308	.5708	.7266	.626	.6357	.6862
5	.5529	.578	.6567	.7453	.7087	.6733	.7434
6	.6642	.6775	.7643	.8299	.8562	.7666	.8527
7	.8528	.8011	.7731	.853	.8886	.7811	.9008
8	.9282	.8998	.8658	.9046	.8981	.7819	.8616
9	.9271	.9039	.8879	.9831	.8657	.7834	.8444
10	.8932	.8221	.823	1.0261	.7735	.7259	.8242
11	.8494	.8733	.9062	.9854	.7762	.679	.9613
12	.8452	.8962	.7681	.9331	.7872	.7543	.9221
13	.2607	.8311	.7074	.8665	.7964	.7312	.7845
14	.271	.7449	.8139	.9526	.7632	.8074	.7083
15	.2725	.7278	.9389	.8856	.7148	.8145	.6946
16	.5815	.7804	.9394	.8109	.7987	.8086	.7796
17	.7476	.8429	1.0216	.634	.8265	.8615	.8935
18	.9621	1.0452	1.1787	.7777	.878	.9034	.8528
19	1.3465	1.3512	1.387	1.2772	1.1564	1.2373	1.1912
20	1.2559	1.3477	1.2976	1.262	1.1522	1.2595	1.1344
21	1.0676	1.1772	1.1187	1.1092	1.0168	1.0969	1.0094
22	.8558	.9377	.8939	.897	.844	.8848	.8429
23	.7141	.7068	.7673	.7304	.7	.7784	.6794
24	.6477	.6436	.6664	.6851	.6752	.6902	.6598
Max	1.3465	1.3512	1.387	1.2772	1.1564	1.2595	1.1912
Min	.2607	.4923	.5708	.634	.626	.6143	.6505
Avg	.7393	.8193	.8557	.8773	.8104	.8052	.8270

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

DEORI S/DN.[389]

BU 0389

Substation No/ Name :- 314004 / 33/11 KV CHICHGAD

Feeder No / Name : 202 / 11 KV Ganutola Feeder

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1915	1.1705	1.153	1.1903	1.1698	1.1915	1.1275
2	1.1713	1.1332	1.1652	1.1911	1.166	1.1677	1.0902
3	1.1599	1.1004	1.1446	1.1884	1.1405	1.1631	1.0602
4	1.1493	1.1429	1.1237	1.2285	1.1287	1.1797	1.0791
5	1.1717	1.2155	1.1614	1.2457	1.1744	1.2285	1.1496
6	1.2418	1.3167	1.1755	1.3489	1.2251	1.2914	1.2091
7	1.118	1.2188	1.0798	1.2105	1.1804	1.1382	1.0776
8	1.1039	1.1256	1.0951	1.1549	1.086	1.0738	1.068
9	1.0549	1.1412	1.1206	1.1117	1.1244	1.1012	1.0882
10	1.0097	1.1202	1.0555	.4599	1.036	1.0936	1.132
11	1.004	1.0496	.9907	.2625	1.0408	1.0841	1.0402
12	.993	.9773	1.0463	1.0241	1.0166	.9987	1.0776
13	1.0455	.9846	1.0985	1.0074	1.0574	.9724	1.0565
14	1.049	.9892	1.0726	.9968	1.0967	1.0013	1.0658
15	1.0437	.9804	1.0151	1.0669	1.0048	1.0063	1.05
16	1.0577	1.0135	1.0995	1.0562	1.078	1.0116	1.0854
17	1.0665	1.065	.9561	1.0869	.9941	1.07	1.1028
18	1.1949	1.2251	1.2555	1.1138	1.0974	1.1927	1.214
19	1.5223	1.571	1.5822	1.3929	1.4918	1.4708	1.4278
20	1.5257	1.5234	1.6027	1.4038	1.4697	1.5283	1.3927
21	1.3988	1.3863	1.4777	1.3475	1.4011	1.4635	1.2003
22	1.2963	1.276	1.1429	1.2373	1.2948	1.2079	1.2749
23	1.2197	1.1033	1.2369	1.2037	1.1781	1.2091	1.1742
24	1.2464	1.1778	.9816	1.1816	1.1607	1.1697	1.1732
Max	1.5257	1.571	1.6027	1.4038	1.4918	1.5283	1.4278
Min	.993	.9773	.9561	.2625	.9941	.9724	1.0402
Avg	1.1681	1.1670	1.1597	1.1130	1.1589	1.1673	1.1424

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

DEORI S/DN.[389]

BU 0389

Substation No/ Name :- 314004 / 33/11 KV CHICHGAD

Feeder No / Name : 203 / 11 KV Palandur

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.2054	.0934	.1886		.2075	.1886
2	.2286	.1867	.0934	.1867		.1886	.168
3	.2286	.168	.0943	.1867		.1886	.1698
4	.2096	.1478	.0943	.1867		.2075	.2075
5	.2477	.2241	.1886	.1886		.2241	.2427
6	.2858	.3018	.2829	.2641		.2614	.2801
7	.2667	.2641	.2075	.2263	.2218	.2263	.2427
8	.2286	.2427	.2075	.2614	.2427	.2614	.2427
9	.2452	.2241	.1646	.2829	.2241	.2452	.2075
10	.1829	.2075	.1463	.2054	.1991	.2054	.2075
11	.1829	.1698	.1646	.1629	.1829	.2054	.1867
12	.2195	.1646	.1886	.1646	.2195	.1698	.2054
13	.2378	.1646	.2263	.1646	.2195	.1698	.2054
14	.2149	.1646	.1698	.1646	.2012	.1886	.1698
15	.2149	.1267	.168	.1829	.2012	.1867	.1867
16	.1791	.1646	.1886	.2012	.2378	.1886	.1867
17	.2402	.1829	.2054	.1829	.2263	.2241	.2241
18	.2801	.2195	.2427	.1663	.2926	.2614	.2801
19	.4338	.3772	.3772	.3547	.415	.4294	.4066
20	.3961	.3584	.3584	.3361	.3547	.3772	.3921
21	.3174	.2829	.2801	.2987	.2987	.3206	.3142
22	.2614	.2241	.2241	.2614	.2427	.2614	.2614
23	.2241	.2075	.2075	.2241	.2241	.2263	.2075
24	.2477	.2241	.2054	.2075		.2054	.2075
Max	.4338	.3772	.3772	.3547	.415	.4294	.4066
Min	.1791	.1267	.0934	.1629	.1829	.1698	.168
Avg	.2509	.2168	.1991	.2187	.2473	.2346	.2330

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

DEORI S/DN.[389]

BU 0389

Substation No/ Name :- 314008 / 33/11 KV DEORI SUB STATION

Feeder No / Name : 201 / 11KV AMGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.2033	3.7052	3.6396	3.8493	3.3813	3.6587	3.3949
2	3.2099	3.6983	3.5039	3.7746	3.2286	3.5673	3.3501
3	3.1634	3.7273	3.5292	3.7197	3.2062	3.6328	3.3025
4	3.1034	3.7841	3.4347	3.6922	3.3196	3.4926	3.3524
5	3.2183	3.9183	3.8877	3.7205	3.5225	3.4119	3.3806
6	3.5536	4.2159	4.1305	4.0878	3.7616	2.7884	3.4568
7	3.8238	4.5081	4.0085	4.2486	4.1899	3.9193	3.4564
8	3.8112	4.5045	4.395	4.5683	4.4094	4.0901	3.9712
9	4.1259	4.6958	4.4155	4.4834	3.6839	4.0076	3.9716
10	4.1999	4.3591	4.4704	4.3926	2.9713	3.9205	3.8302
11	3.8409	4.3509	4.4246	4.4657	3.7326	3.607	3.2581
12	3.9133	3.9834	4.4673	1.9913	3.6207	3.2995	3.6672
13	4.0208	3.4534	4.2562	2.5156	3.8636	3.7041	3.3707
14	4.0632	3.424	1.9799	2.5576	2.5955	3.6294	2.2215
15	3.5585	2.3007	1.9494	2.6975	2.5012	3.5555	2.5707
16	3.8325	3.2503	2.1246	3.5407	2.527	3.7937	3.1207
17	4.3126	3.7163	3.1489	3.9823	3.1039	4.0939	2.6185
18	4.6624	4.3271	4.478	4.1758	3.8994	4.3175	3.5643
19	5.1898	4.6849	4.8788	4.5991	4.5138	4.8956	3.9407
20	4.9101	4.5938	4.6372	4.287	4.1198	4.7344	3.8392
21	4.4326	4.4326	4.1937	4.0596	4.183	4.2078	3.6637
22	4.2681	4.1534	4.116	3.737	3.7037	3.6938	2.6292
23	3.8443	3.8828	2.0241	3.5315	3.8696	3.803	2.4038
24	3.498	3.7951	3.7216	3.687	2.4585	3.6489	2.8258
Max	5.1898	4.6958	4.8788	4.5991	4.5138	4.8956	3.9716
Min	3.1034	2.3007	1.9494	1.9913	2.4585	2.7884	2.2215
Avg	3.9067	3.9777	3.7423	3.7652	3.5153	3.8114	3.2984

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

DEORI S/DN.[389]

BU 0389

Substation No/ Name :- 314008 / 33/11 KV DEORI SUB STATION

Feeder No / Name : 202 / 11 KV DEORI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4956	1.4853	1.5371	1.563	1.5554	1.6177	1.5417
2	1.4444	1.4468	1.494	1.5127	1.5272	1.5748	1.5024
3	1.3883	1.4394	.7628	1.5051	1.4571	1.5227	1.4798
4	1.3784	1.4074	1.3828	1.4891	1.4461	1.5272	1.4704
5	1.3788	1.4358	1.446	1.4731	1.468	1.6411	1.4612
6	1.5222	1.5131	1.565	1.6122	1.5013	1.7023	1.5112
7	1.6271	1.6415	1.7303	1.6562	1.5188	1.7535	1.707
8	1.7463	1.6682	1.856	1.6667	1.7445	1.7048	1.6892
9	1.7598	1.7585	1.7004	1.629	1.7505	1.6881	1.6118
10	1.8124	1.7909	1.6979	1.5786	1.8881	1.6865	1.6907
11	2.0884	2.0376	2.0096	1.8272	1.656	1.7961	1.7173
12	2.1048	2.0477	1.9326	2.0413	1.7291	1.8576	1.9601
13	1.9601	1.9665	1.925	1.8665	1.6465	1.84	1.7589
14	1.7307	1.8976	1.7231	1.6537	1.8212	1.7414	1.6768
15	1.7614	1.7834	1.6628	1.792	1.8618	1.7589	1.8154
16	2.0485	1.9351	1.7322	1.9075	1.7799	1.768	1.8463
17	2.0241	2.1274	1.8237	1.9689	1.7615	1.8034	1.7764
18	2.0259	2.2763	1.9289	1.9913	1.9033	1.8991	1.7658
19	2.2977	2.308	2.2755	2.2371	2.2314	2.3402	2.2331
20	2.348	2.3488	2.3602	2.2845	2.2976	2.329	2.3344
21	2.1352	2.2331	2.172	2.1301	2.1327	2.1917	2.2836
22	1.9473	2.0493	1.9669	1.9334	1.9913	2.0211	2.0698
23	1.7471	1.7947	.9595	1.7705	1.7802	1.7742	1.8073
24	1.6167	1.6675	1.632	1.6492	1.625	1.7017	1.5882
Max	2.348	2.3488	2.3602	2.2845	2.2976	2.3402	2.3344
Min	1.3784	1.4074	.7628	1.4731	1.4461	1.5227	1.4612
Avg	1.8079	1.8358	1.7198	1.7808	1.7531	1.8017	1.7625

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

DEORI S/DN.[389]

BU 0389

Substation No/ Name :- 314008 / 33/11 KV DEORI SUB STATION

Feeder No / Name : 203 / 11 KV KAKODI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2389	.2744	.2766	.2724	.2601	.1934	.2496
2	.2363	.276	.258	.2537	.2667	.1878	.25
3	.2313	.2779	.2591	.2991	.2671	.1918	.2522
4	.2351	.2787	.2442	.2949	.2662	.1715	.2694
5	.2416	.3052	.2652	.2964	.258	.1918	.2892
6	.296	.3155	.3086	.3479	.2987	.2294	.3291
7	.3186	.3443	.3974	.3409	.325	.1983	.3347
8	.3348	.3174	.3559	.3082	.3423	.1737	.3464
9	.3231	.334	.2782	.2976	.3359	.1539	.3174
10	.3144	.2827	.277	.2934	.3302	.1231	.2993
11	.2934	.2722	.3052	.2953	.326	.1749	.3029
12	.3147	.2342	.285	.3022	.2955	.2191	.2875
13	.3033	.2494	.2949	.3311	.2721	.2309	.2917
14	.3056	.2588	.3079	.3151	.3037	.2598	.2508
15	.3719	.2721	.296	.2942	.3343	.2869	.2626
16	.3398	.3033	.3551	.3078	.3559	.2835	.261
17	.365	.2846	.3471	.2898	.3704	.3715	.2641
18	.3891	.3246	.3677	.3174	.407	.3508	.3288
19	.5379	.491	.4618	.4818	.5304	.4928	.439
20	.5081	.4632	.4325	.4891	.5045	.4683	.4093
21	.4195	.3837	.3757	.4336	.3407	.4289	.3838
22	.3517	.3296	.3376	.3464	.2439	.351	.3441
23	.2991	.298	.1604	.2576	.2114	.3151	.3075
24	.1661	.289	.2869	.2823	.2241	.2425	.2362
Max	.5379	.491	.4618	.4891	.5304	.4928	.439
Min	.1661	.2342	.1604	.2537	.2114	.1231	.2362
Avg	.3223	.3108	.3139	.3228	.3196	.2621	.3044

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

DEORI S/DN.[389]

BU 0389

Substation No/ Name :- 314008 / 33/11 KV DEORI SUB STATION

Feeder No / Name : 204 / 11 KV KOHAMARA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.686	5.6028	5.1345	5.4046	5.1776	5.1921	5.1928
2	4.676	5.4009	5.0463	5.2454	5.1013	5.0937	5.0976
3	4.6517	5.1204	5.034	4.763	5.1421	5.0337	4.9703
4	4.6205	5.0785	4.9181	4.151	5.1532	4.9815	4.8735
5	4.6803	5.3003	4.912	4.1967	5.2294	5.1719	5.1365
6	5.0023	6.0586	5.5601	4.5367	5.5137	5.2759	5.5273
7	2.7412	6.4571	6.431	5.5677	6.3417	6.025	6.1889
8		6.941	6.8496	6.0696	6.9143	6.2643	6.4983
9	3.048	6.941	6.3727	6.1313	5.5556	6.2933	6.278
10	6.8099	6.6583	6.4807	6.1988	5.6623	6.324	6.3461
11	6.8911	6.5607	6.3809	6.4079	5.8779	6.2224	6.3382
12	6.8159	6.5729	6.3626	6.4815	5.7008	6.5175	6.3817
13	5.6897	6.5834	6.4305	4.5988	6.1664	5.7004	5.9839
14	6.2285	6.3553	6.4129	4.2021	6.1949	5.958	4.2995
15	6.5394	5.8932	6.4944	4.3911	6.283	6.0548	4.5119
16	5.5569	6.2156	5.0747	4.7653	6.2045	6.3196	4.7447
17	6.6278	6.0742	5.3749	5.7339	6.0593	6.4991	5.3618
18	5.6249	5.6874	5.6912	6.4499	4.3717	6.4903	5.4953
19	6.6503	6.3969	6.8892	6.3984	1.3999	6.9227	5.445
20	6.5306	6.3558	6.6659	6.3458	5.2416	6.7284	5.3586
21	5.9694	6.1643	6.2666	5.9957	5.4197	6.3756	5.0251
22	6.0318	5.586	5.8902	5.6744	5.4887	5.5882	4.5206
23	5.9122	5.3075	2.8708	5.3948	5.0854	5.3825	4.2859
24	3.0258	5.5281	5.2967	5.4176	5.2012	5.3839	4.6487
Max	6.8911	6.941	6.8892	6.4815	6.9143	6.9227	6.4983
Min	2.7412	5.0785	2.8708	4.151	1.3999	4.9815	4.2859
Avg	5.4352	6.0350	5.7850	5.4384	5.4369	5.9083	5.3546

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

DEORI S/DN.[389]

BU 0389

Substation No/ Name :- 314008 / 33/11 KV DEORI SUB STATION

Feeder No / Name : 205 / 11 KV EXPRESS FEEDER MBCP NON SHEDDABLE EXPRESS HV FEEDERS
 SIRP Feeder KV- 11 / INCOMING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.11	.1088	.1136	.1092	.1105	.1139	.1119
2	.1086	.1082	.112	.1088	.1094	.1118	.1113
3	.1082	.1096	.1109	.1073	.1107	.112	.1101
4	.1079	.1102	.1105	.1088	.1067	.0933	.1095
5	.1075	.0896	.1105	.1093	.1095	.093	.1101
6	.1052	.0899	.0896	.088	.1048	.0895	.1107
7	.0705	.0373	.0522	.0591	.0434	.0423	.0686
8	.0389	.0515	.0351	.0567	.0388	.037	.0575
9	.0351	.0407	.0351	.0378	.0362	.0423	.0381
10	.0373	.0534	.051	.0374	.0518	.0381	.0351
11	.0362	.0495	.0449	.0659	.0743	.0343	.0351
12	.0388	.0462	.0434	.0495	.0389	.0343	.0365
13	.0362	.0439	.0632	.0572	.0488	.0358	.0359
14	.0377	.0411	.0594	.0358	.0423	.0359	.0351
15	.0384	.048	.0419	.0366	.04	.0388	.0351
16	.0377	.0358	.0354	.0343	.0651	.0366	.0351
17	.0373	.0373	.0354	.0423	.0613	.037	.0351
18	.054	.0351	.0354	.0381	.0793	.0415	.0351
19	.1174	.1602	.113	.1157	.1206	.1218	.1189
20	.1227	.181	.1149	.1199	.117	.124	.1554
21	.1173	.1193	.1134	.1158	.1143	.1187	.1194
22	.1118	.114	.1092	.1096	.1144	.1135	.1086
23	.113	.1145	.0545	.1098	.1096	.1122	.0886
24	.1086	.1172	.1071	.1085	.114	.1128	.1145
Max	.1227	.181	.1149	.1199	.1206	.124	.1554
Min	.0351	.0351	.0351	.0343	.0362	.0343	.0351
Avg	.0765	.0809	.0747	.0776	.0817	.0738	.0771

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

DEORI S/DN.[389]

BU 0389

Substation No/ Name :- 314008 / 33/11 KV DEORI SUB STATION

Feeder No / Name : 403 / 33KV OUTGOING KORCHI

NON SHEDDABLE EXPRESS HV FEEDERS

FEEDER Feeder KV- 33 /

(CONTINUOUS PROCESS)(NO STAGGERING)

INCOMING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5123	1.9239	1.7924	1.9805	1.6804	1.9805	1.9239
2	1.4563	1.8484	1.6975	1.9239	1.6975	1.9044	1.9239
3	1.4712	1.8673	1.9204	1.9805	1.6409	1.9044	1.9239
4	1.4146	1.7924	1.7924	1.9605	1.5278	1.9605	1.9239
5	1.6804	2.037	1.7924	2.037	1.6804	2.0165	1.9805
6	2.0165	2.1845	2.1285	2.2634	1.7924	2.0851	2.0936
7	1.7364	2.1285	1.9044	2.0936	1.7924	2.1502	1.7541
8	1.8484	2.1845	2.0725	2.2068	1.9239	1.9805	1.9805
9	1.6409	2.1502	1.9805	1.6409	1.5844	1.9805	1.6409
10	1.9239	1.9044	1.9805	1.5278	1.9044	1.8673	1.8484
11	1.8296	1.8484	1.8673	1.4146	1.6804	1.7924	1.8484
12	1.9239	1.8673	1.8673	1.8673	1.9044	1.7924	1.8673
13	1.6804	1.8673	1.8673	1.7541	1.9605	1.7924	1.7364
14	1.6804	1.7924	1.8673	1.8107	1.9044	1.7924	1.6975
15	1.6975	1.2449	1.8673	1.8484	1.8484	1.8484	1.8484
16	1.7924	1.7924	1.8107	1.7924	1.9044	1.8673	1.7924
17	1.9239	1.9044	2.2634	1.8107	1.9239	1.8673	1.8484
18	2.2634	2.0165	2.4331	1.9805	1.9239	2.037	2.2405
19	3.1121	3.1927	3.1121	2.9424	3.1121	2.999	3.0247
20	3.1121	3.0556	2.7161	2.999	3.0556	3.0556	3.0556
21	2.2405	2.8292	2.7161	2.7161	2.7726	2.8858	
22	2.4086	2.4646	2.4897	2.4331	2.2405	2.4897	2.1845
23	1.9239	2.2405		1.8107	2.1502	2.2634	1.7924
24	1.6804	1.9239	1.7924	1.9239	1.7541	1.9239	1.9805
Max	3.1121	3.1927	3.1121	2.999	3.1121	3.0556	3.0556
Min	1.4146	1.2449	1.6975	1.4146	1.5278	1.7924	1.6409
Avg	1.9154	2.0859	2.0753	2.0300	1.9733	2.0932	1.9961

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

MORGAON ARJUNI S/DN.[565] BU 0565

Substation No/ Name :- 314010 / 33/11KV KESHORI

Feeder No / Name : 201 / 11 KV Keshori

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3411	2.268	2.8166	2.4253	2.7618	2.3167	2.5882
2	2.0851	2.2497	2.7618	2.3348	.9145	2.2443	2.5701
3	2.0851	2.2314	2.7618	2.3348	2.7435	2.2443	2.5701
4	2.0851	2.2314	2.7618	2.371	2.7435	2.2443	2.5882
5	2.1033	2.2314	2.7618	2.4072	2.7801	2.2624	2.5882
6	2.1765	2.3045	2.8166	2.4615	2.8898	2.2805	2.6968
7	2.2497	2.3228	2.6337	2.5701	2.8898	2.4253	2.6606
8	2.4508	2.4508	2.9081	2.5339	3.0178	2.4977	2.6787
9	2.3594	2.5972	2.8166	2.7252	2.9264	2.6244	2.3891
10	2.0485	2.396	2.6886	2.6703	2.7252	2.371	2.371
11	2.1765	2.7435	2.5972	2.5882	2.5789	2.552	2.4072
12	2.4508	2.9081	2.6886	2.7873	2.3891	2.4253	2.2443
13	2.5057	2.652	2.4508	2.8166	2.2805	2.4615	2.19
14	2.4874	2.5057	1.7924	2.8416	2.3167	2.4796	2.3529
15	2.268	2.7252	1.8473	2.8054	2.2624	2.3167	2.3891
16	2.4508	2.7801	2.5423	2.8235		2.4615	2.4072
17	2.3411	2.7618	2.5158	2.8597	2.2443	2.4615	2.2805
18	2.3411	2.652	2.5701	2.8054	2.4615	2.4796	2.371
19	2.8166	2.9813	2.8416	2.9321	2.8235	2.7149	2.4796
20	2.6337	2.9995	2.8597	2.8597	2.8416	2.6606	2.3167
21	2.4508	3.0178	2.7511	2.8898	2.733	2.5882	2.2805
22	2.3045	2.9995	2.4253	2.9264	2.4796	2.6244	2.19
23	2.3045	2.9813	2.4253	2.7801	2.4434	2.5701	2.1176
24	2.3594	2.2862	2.9264	2.4434	2.7801	2.371	2.5882
Max	2.8166	3.0178	2.9264	2.9321	3.0178	2.7149	2.6968
Min	2.0485	2.2314	1.7924	2.3348	.9145	2.2443	2.1176
Avg	2.3281	2.5949	2.6234	2.6664	2.5664	2.4449	2.4298

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

MORGAON ARJUNI S/DN.[565] BU 0565

Substation No/ Name :- 314010 / 33/11KV KESHORI

Feeder No / Name : 202 / 11 KV Mahagaon Feeder
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4807	.4144	.5138	.431	.5636	.5138	.5138
2	.3978	.4144	.5138	.3812	.5636	.5138	.5138
3	.3978	.4144	.4973	.3812	.5636	.5138	.5138
4	.3978	.3978	.4973	.3812	.547	.5138	.5138
5	.4144	.4144	.4973	.3812	.5801	.547	.5138
6	.431	.431	.4973	.3978	.5801	.5636	.5138
7	.4475	.4475	.4973	.4144	.5801	.5636	1.1401
8	.4973	.4973	.4973	.4475	.6133	.5801	1.2534
9	.547	.4807	.547	.547	.6133	.5967	1.2202
10	.4807	.3978	.5138	.4641	.5967	.6133	1.2507
11	.5801		.5138	.5138	.6464	.547	1.3144
12	.5801	.5138	.5801	.5636	.6464	.5801	1.2647
13	.5801	.5801	.5304	.6133	.6299	.5967	1.0572
14	.5801	.4807	.5636	.6133	.5967	.5967	1.046
15	.5967	.547	.5304	.6133	.5967	.5304	1.046
16	.5967	.5636	.4475	.5636		.5801	1.0128
17	.5967	.5636		.5636	.4475	.5636	.9962
18	.5304	.3978	.4641	.5967	.5967	.5636	.855
19	.5636	.547	.4807	.6133	.6299	.5801	.9657
20	.4641	.547	.5138	.6133	.6299	.5636	.9657
21	.4475	.547	.4973	.6133	.5967	.5636	.9187
22	.431	.547	.4807	.6133	.5801	.5304	.8689
23	.431	.5304	.4641	.5801	.5801	.5138	.7915
24	.4973	.431	.5304	.431	.5636	.5636	.5138
Max	.5967	.5801	.5801	.6133	.6464	.6133	1.3144
Min	.3978	.3978	.4475	.3812	.4475	.5138	.5138
Avg	.4986	.4829	.5074	.5138	.5888	.5580	.8985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

MORGAON ARJUNI S/DN.[565] BU 0565

Substation No/ Name :- 314010 / 33/11KV KESHORI

Feeder No / Name : 203 / 11 KV Bondgaon

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6874	.7865	.6062	.7968	.5312	.6958	.8097
2	.6009	.7865	.5898	.703	.5155	.68	.8097
3	.6009	.7682	.583	.703	.4999	.6642	.8097
4	.6167	.7611	.583	.7186	.4999	.6483	.7935
5	.6325	.7865	.6478	.7186	.5155	.68	.7935
6	.68	.7935	.664	.7343	.5312	.6958	.8097
7	.7116	.8192		.7499	.5218	.7042	.7773
8	.8162	.8322	.5944	.7968	.5312	.7362	.8583
9	.8482	.8802	.7133	.7968	.5312	.8482	.7287
10	.7274	.7274	.7375	.8749	.5312	.7362	.7125
11	.8381	.8381	.6836	.4843	.68	.7682	.8259
12	.8381	.6483	.7282	.4843	.8905	.8642	.8745
13	.9014	.6483		.4843	.7907	.9122	.6154
14	.8855	.6958	.7876	.3749	.7748	.7116	.8097
15	.9448	.7116	.8128	.3953	.7748	.8802	.8421
16	.9488	.7274	.8579	.4843		.8697	.9069
17	.9172	.7099	.8579	.4843	.5693	.8482	.8907
18	.9172	.4458	.7827	.5155	.8223	.9122	.9069
19	.8065	.5796	.7827	.5468	.8381	.8962	.9717
20	.9014	.6321	.8383	.6154	.8381	.8482	.9555
21	.8962	.679	.8124	.5624	.8223	.8802	.9717
22	.8583	.6722	.8592	.5937	.8223	.8482	.8097
23	.8356	.6478	.8436	.5624	.7907	.8162	.8097
24	.8059	.8029	.6062	.8124	.5468	.7274	.8162
Max	.9488	.8802	.8592	.8749	.8905	.9122	.9717
Min	.6009	.4458	.583	.3749	.4999	.6483	.6154
Avg	.8007	.7242	.7260	.6247	.6595	.7863	.8296

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

MORGAON ARJUNI S/DN.[565] BU 0565

Substation No/ Name :- 314015 / 33/11 KV NAVEGAON/BANDH

Feeder No / Name : 201 / 11 KV BHIVKHIDKI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8048	.9054	.8551	.9882	1.0117	.9724	1.0576
2	.8048	.9054	.8288	.9709	.9945	.9945	1.0576
3	.8139	.8718	.8573	.9362	.9724	.9835	1.0402
4	.7956	.8718	.8764	.9189	.9389	.9709	1.0229
5	.7956	.8551	.8669	.9015	.9326	.964	.9882
6	.8048	.8718	.8648	.9015	.9556	.9389	.9709
7	.8886	.9156	.8309	.9189	.9614	.9602	.9189
8	.8029	.8745	.7888	1.0229	.9724	.9774	.9602
9	.8048	.8745	.8573	.9362	.9326	.9189	.8916
10	.8309	.9116	.8383	.9221	.9892	.9015	.9015
11	.9259	1.0059	.8745	.8383	1.0513	.9709	.9015
12	.8573	.788	1.0117	.8402	1.0974	1.0576	.8551
13	.8402	.8215	.9431	.7545	1.0343	1.0749	.6036
14	.9602	.9556	.8478	.7455	.9282	1.0749	.7122
15	.9709	.9724	.9259	.7455	.9779	1.0631	.7127
16	.9709	.8785	.9602	.964	1.0227	.9602	.7545
17	.9069	.8916	.9602	.9835	1.0852	1.1317	.8215
18	.9069	.8642	.8745	.9556	1.0486	1.0608	.8785
19	1.0004	.9496	1.1022	1.1145	1.1065	1.1789	.9496
20	.9503	.9724	1.0402	1.0974	1.0898	1.1361	.9431
21	.9389	.9556	1.0056	1.046	1.0852	1.0802	.9431
22	.9156	.9259	.9709	1.0117	1.0608	1.046	.8916
23	.8916	.9088	1.0288	1.0004	1.046	1.0749	.8669
24	.823	.9114	.8916	1.0402	.9892	.9945	1.0749
Max	1.0004	1.0059	1.1022	1.1145	1.1065	1.1789	1.0749
Min	.7956	.788	.7888	.7455	.9282	.9015	.6036
Avg	.8752	.9025	.9126	.9398	1.0119	1.0203	.9049

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

MORGAON ARJUNI S/DN.[565] BU 0565

Substation No/ Name :- 314015 / 33/11 KV NAVEGAON/BANDH

Feeder No / Name : 202 / 11 KV PAUNI/DHABE

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6706	.7975	.78	.8495	.6952	.7545	.7455
2	.6783	.7975	.7712	.8589	.7108	.7628	.7455
3	.6859	.7888	.7802	.8413	.6952	.7209	.7282
4	.6706	.7888	.7802	.8413	.7108	.7537	.7282
5	.663	.7888	.7975	.8238	.7011	.7628	.7186
6	.7122	.7969	.788	.8589	.7291	.763	.7712
7	.7459	.8059	.8573	.8589	.8886	.7888	.7888
8	.7293	.8402	.9259	.8495	.8745	.8322	.7628
9	.6706	.8059	.8669	.9189	.6836	.7282	.9015
10	.7291	.8648		.8916	.823	.7802	.8059
11	.8573	.7956		.8745	.823	.7802	.8059
12	.823	.8453	.9496	.5365	.9088	.7802	.7122
13	.823	.8951	.8309	.5087	.8478	.8322	.6415
14	.823	.9116	.6754	.8059	.788	.8495	.7377
15	.7373	.8482	.8139	.823	.8215	.8149	.7888
16	.823	.7209	.9259	.7975	.823	.8322	.7373
17	.8059	.788	.9259	.8383	.8551	.9259	.7969
18	.8402	.7701	.8453	.8215	.8551	.9496	.8383
19	.9362	.9882	.9709	.9816	.9362	1.0749	.964
20	.9015	.9709	.9015	.8505	.8987	.9882	.9114
21	.8495	.8573	.8669	.9036	.8402	.9362	.8589
22	.8238	.8059	.8322	.8413	.763	.9015	.8328
23	.8063	.7975	.8059	.8059	.7455	.9362	.8063
24	.663	.8063	.7975	.8149	.7202	.7628	.7628
Max	.9362	.9882	.9709	.9816	.9362	1.0749	.964
Min	.663	.7209	.6754	.5087	.6836	.7209	.6415
Avg	.7695	.8282	.8404	.8248	.7974	.8338	.7871

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

MORGAON ARJUNI S/DN.[565] BU 0565

Substation No/ Name :- 314015 / 33/11 KV NAVEGAON/BANDH

Feeder No / Name : 203 / 11 KV NAVEGAON/BANDH
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7318	1.7684	1.6118	1.9244	1.7465	1.7511	1.7703
2	1.7147	1.749	1.5581	1.9281	1.7126	1.7147	1.7528
3	1.7164	1.7295	1.6476	1.9281	1.6766	1.6804	1.7528
4	1.6787	1.7126	1.595	1.893	1.6095	1.7164	1.7177
5	1.643	1.7126	1.5604	1.7353	1.5947	1.8054	1.6476
6	1.6289	1.5947	1.5432	1.6827	1.6766	1.6632	1.5775
7	1.4918	1.5947	1.647	1.6126	1.5927	1.647	1.4373
8	1.4083	1.6289	1.647	1.7002	.5256	1.6301	.4681
9	1.5261	1.6632	1.7177	1.7177	.6173	1.335	.6241
10	1.5257	1.7974	1.8519	1.8204	.78	1.7164	.7362
11	1.8724	1.7814	.7108	1.8898	1.9719	1.9071	.7888
12	1.283	1.8947	2.0748	1.869	2.0631	1.9765	1.7661
13	1.3176	1.8461	1.3375	1.4586	1.9547	1.9418	1.4043
14	2.0805	1.7976	1.2689	1.7164	1.9113	1.8031	1.439
15	1.9071	1.7166	1.0802	1.9071	1.8564	1.8724	1.6278
16	1.9376	1.7404	1.9938	.7362	1.8724	1.8724	1.7147
17	1.7661	1.869	2.0233	.7975	2.0405	1.9244	1.6278
18	1.1744	1.6032	1.6448	1.8107	1.8399	1.749	1.5604
19	1.7857	1.9719	1.8031	1.8378	1.7974	1.7353	1.647
20	1.8204	1.8861	1.8031	1.8229	1.8176	1.6651	1.6124
21	1.7528	1.7684	1.7164	1.7177	1.7436	1.5775	1.595
22	1.9631	1.7164	1.9418	1.8519	1.8861	1.5108	1.6476
23	1.9806	1.6827	1.9071	1.7126	1.8004	1.8054	1.6301
24	1.6933	1.9136	1.6651	1.9244	1.7465	1.8054	1.7878
Max	2.0805	1.9719	2.0748	1.9281	2.0631	1.9765	1.7878
Min	1.1744	1.5947	.7108	.7362	.5256	1.335	.4681
Avg	1.6833	1.7558	1.6396	1.7081	1.6597	1.7419	1.4722

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

MORGAON ARJUNI S/DN.[565] BU 0565

Substation No/ Name :- 314027 / 33/11 KV Arjuni/Morgaon

Feeder No / Name : 201 / 11KV ARJUNI MOR FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.5047	4.4976	5.0023	5.9404	7.6547	1.4659	1.9136
2	4.4373	4.4316	4.9288	5.9074	7.5329	1.4152	1.8665
3	4.3324	4.4266	4.8945	5.7884	7.4975	1.3974	1.9019
4	4.3507	4.4405	4.8553	5.692	7.3872	1.3936	1.8981
5	4.3538	4.5521	4.783	5.6487	7.2818	1.3506	1.8892
6	4.3873	4.6954	4.5711	5.7794	7.1373	1.2681	1.9056
7	4.2981	4.6485	4.5115	5.4868	7.0523	1.2948	1.8831
8	4.3953	4.8245	4.7219	5.7577	7.7586	1.1742	1.7714
9	4.7573	5.1288	4.8625	5.5706	4.483	1.3466	1.7333
10	5.1117	5.2404	4.8476	6.201	1.2161	1.5455	1.9666
11	5.0976	5.067	5.0488	6.4819	1.5076	1.8917	1.8194
12	5.0907	4.393	5.0555	7.4933	1.5064	1.8502	1.4232
13	5.1216	4.7054	3.883	6.6135	1.4898	1.779	.8936
14	5.0179	4.6739	3.9268	6.7343	1.4773	1.6432	1.1108
15	5.133	4.67	4.2297	7.2946	1.5354	1.675	1.2428
16	5.1803	4.6066	4.3528	5.6921	1.5762	1.7941	1.4441
17	2.6863	4.6447	4.4821	6.0264	1.5432	1.8499	1.5915
18		4.7259	2.2634	6.7356	1.5988	1.641	1.5153
19	4.8887	5.1503	7.2141	8.2574	1.7726	1.7143	1.8208
20	4.8411	5.1189	7.219	8.1304	1.7524	1.7156	1.8435
21	4.667	5.1174	6.8825	7.946	1.7143	1.808	1.6369
22	4.7786	5.2555	6.624	8.3217	1.6712	2.2582	2.1454
23	4.8095	5.3357	6.2513	8.1279	1.7143	2.1987	2.0858
24	4.6452	4.8438	5.5495	6.9756	4.5261	1.7821	1.7114
Max	5.1803	5.3357	7.219	8.3217	7.7586	2.2582	2.1454
Min	2.6863	4.393	2.2634	5.4868	1.2161	1.1742	.8936
Avg	4.6472	4.7998	5.0400	6.6085	3.7661	1.6355	1.7089

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

MORGAON ARJUNI S/DN.[565] BU 0565

Substation No/ Name :- 314027 / 33/11 KV Arjuni/Morgaon

Feeder No / Name : 202 / 11 KV Gothangaon

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			7.0866	6.7379
2			6.9801	6.7252
3			6.8303	6.6252
4			6.7554	6.4563
5			6.6845	6.336
6			6.6442	6.2436
7			6.6668	6.2205
8	.1341		6.7758	4.8272
9		3.8897	7.0258	5.5363
10		6.1103	5.5458	4.3947
11		5.9623	5.4268	5.4565
12		5.907	6.7377	5.6453
13		6.4499	6.7758	3.0095
14		3.4065	6.8001	4.5911
15		2.0933	5.8065	4.5376
16		2.5143	5.6994	5.0387
17		6.3973	5.8362	5.4394
18		6.7469	5.2182	5.8082
19	.1448	7.5518	7.3135	7.0637
20	.0838	7.8549	7.4897	7.2776
21	.0114	7.7639	7.3719	6.9193
22		7.4013	7.1995	6.6836
23		7.065	6.9193	6.4577
24		3.6466	6.9227	5.704
Max	.1448	7.8549	7.4897	7.2776
Min	.0114	2.0933	5.2182	3.0095
Avg	.0935	5.6726	6.6047	5.8223

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

MORGAON ARJUNI S/DN.[565] BU 0565

Substation No/ Name :- 314027 / 33/11 KV Arjuni/Morgaon

Feeder No / Name : 203 / 11 KV Sangadi

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.1326	3.3762	3.6222	3.7106	3.8927	3.9811	3.5315
2	3.0841	3.3703	3.5825	3.7029	3.8813	3.9545	3.466
3	3.0803	3.3814	3.5932	3.6709	3.8623	3.8546	3.3806
4	3.0893	3.3529	3.5406	3.6145	3.8172	3.7891	3.3539
5	3.0945	3.3716	3.469	3.5901	3.7723	3.7205	3.3257
6	3.158	3.4534	3.4507	3.6725	3.7929	3.6907	3.3219
7	3.2217	3.4474	3.5345	3.6557	3.6991	3.7639	3.3295
8	3.3501	3.5691	3.5162	3.7159	3.8721	3.7669	3.4355
9	3.4026	3.55	3.3783	3.9385	3.8858	3.7677	3.6077
10	3.8797	3.7201	3.7402	3.7966	3.6572	3.639	3.7791
11	3.7582	3.4368	3.6396	3.6983	3.3676	3.9042	3.8561
12	3.6924	3.7241	3.8248	3.7617	3.5467	4.0588	3.9201
13	3.7715	3.9868	3.4667	3.5887	3.8112	4.1007	1.2765
14	3.9672	4.0811	3.3669	3.6648	3.7532	4.0307	1.5577
15	3.8536	3.9676	3.4804	3.581	3.4293	3.9804	3.395
16	3.5984	3.5488	3.4187	3.5277	3.4484	4.0489	2.3975
17	1.2498	3.4528	3.4469	3.706	3.4187	3.853	1.2346
18		3.6668	1.97	3.8478	3.3387	3.6344	2.3457
19	4.4658	4.0718	3.8828	4.0543	3.6626	4.0604	3.5901
20	4.1916	4.1724	3.8447	4.0817	3.8264	3.9994	3.4568
21	3.8146	4.0474	3.7357	3.8729	3.722	3.8058	3.3265
22	3.682	3.8287	3.536	3.6755	3.6671	3.6077	3.1382
23	3.5065	3.6747	3.3714	3.5566	3.5201	3.5353	2.9683
24	3.3219	3.4033	3.5261	3.5978	3.661	3.7342	3.1443
Max	4.4658	4.1724	3.8828	4.0817	3.8927	4.1007	3.9201
Min	1.2498	3.3529	1.97	3.5277	3.3387	3.5353	1.2346
Avg	3.4507	3.6523	3.4974	3.7201	3.6794	3.8451	3.0891

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

MORGAON ARJUNI S/DN.[565] BU 0565

Substation No/ Name :- 314027 / 33/11 KV Arjuni/Morgaon

Feeder No / Name : 204 / 11 KV Mahagaon

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.4883	1.7896	1.6301
2	1.4529	1.7364	1.5947
3	1.4175	1.7187	1.5947
4	1.3998	1.701	1.5592
5	1.3998	1.701	1.5415
6	1.4883	1.6655	1.5415
7	1.3998	1.5947	1.4529
8	1.4706	1.7364	1.4175
9	1.5947	1.7896	1.2757
10	1.6124	1.701	1.4883
11		1.701	1.5947
12		1.4883	.7087
13		1.5769	.8682
14	1.6301	1.6478	.9391
15	1.6832	1.7187	
16	1.7364	1.8073	
17		1.6124	
18		1.5415	
19	2.1262	1.9136	
20	2.1262	1.9313	
21	2.1085	1.8073	
22	1.949	1.7541	
23	1.8073	1.6832	
24	1.4883	1.8073	1.6124
Max	2.1262	1.9313	1.6301
Min	1.3998	1.4883	.7087
Avg	1.6515	1.7135	1.3879

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SADAK ARJUNI S/DN.[811] BU 4811

Substation No/ Name :- 314003 / 33/11KV DAWWA S.stn

Feeder No / Name : 201 / 11 KV DAWWA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2045	2.2382	1.491	2.1176		2.2565	2.3388
2	2.2466	2.2213	1.4737	2.0633		2.1849	2.2325
3	2.2801	2.2213	1.4563	2.0271	2.1439	2.2028	2.1794
4	2.2634	2.1874	1.387	2.0271	2.1439	2.1849	2.1439
5	2.2634	2.1874	1.4217	2.0814		2.167	2.2148
6	2.2801	2.2213	1.5083	2.1719	2.3211	2.1719	2.2857
7	2.2969		1.6301	2.2744		2.3102	2.3388
8	2.5774	.5895	2.4539	1.2407		2.3998	2.3743
9	2.3807	.5548	2.6467	2.3819	2.6223	2.3282	2.0199
10	2.4247	.5548	2.7694	2.2744	2.6932	2.0633	2.4806
11		1.7684		2.2721	2.516	2.073	2.4806
12	2.4078		2.1971	2.5337	2.2386	1.949	2.1971
13	2.4813		2.0774	2.3034	2.364	2.268	
14	2.1963		2.0858	2.3388	2.4356		
15	2.3807		1.9185	2.2744	2.4893		
16	2.4646		2.0271	2.4274	2.3102		1.2226
17	.6036		1.9728	2.364	2.6223	2.3211	1.1871
18	2.2211		1.9728	2.5692	2.3819	1.3643	1.2757
19	2.7995	.3294	1.5261		2.2986	2.8704	1.4529
20	2.3838	1.5777	2.4188	2.3388	2.4253	2.7286	1.6632
21	2.4274	1.6124	2.1538	2.3211	2.3348	2.5514	1.5061
22	2.2721	1.5604	2.0271	2.2325	2.2986	2.4097	1.4529
23	2.2891	1.491	2.1357	2.2325	2.0908	2.4097	1.3998
24	2.2466	2.2891	1.4737	2.2565	2.392	2.1491	2.3565
Max	2.7995	2.2891	2.7694	2.5692	2.6932	2.8704	2.4806
Min	.6036	.3294	1.387	1.2407	2.0908	1.3643	1.1871
Avg	2.2779	1.6003	1.9228	2.2228	2.3749	2.2554	1.9430

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SADAK ARJUNI S/DN.[811] BU 4811

Substation No/ Name :- 314003 / 33/11KV DAWWA S.stn

Feeder No / Name : 202 / 11 KV SADAK ARJUNI FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4419	2.0008	1.9185	2.19	2.1033	2.2081	2.1538
2	1.4251	2.0008	1.9185	2.0271		2.2032	2.1176
3	1.4419	2.0008	1.9728	2.1357	2.0485	2.1357	2.0452
4	1.4582	1.8945	1.9185	2.1719	2.0668	2.0995	2.0814
5	1.3904	1.8945	1.9753	2.1719	2.1033	2.0995	2.0814
6	1.4403	2.0517	2.0119	2.2443	2.1948	2.1719	2.1357
7	1.4243	1.9559	2.2081	2.2986		2.3529	2.2624
8	1.3735	2.1051	2.5339	2.3891	2.0953	2.3348	2.2805
9		2.2382	1.8473	2.2443	2.4253	2.3348	2.1357
10	2.1091	2.2721	2.0119	2.3891	2.561	2.2986	2.3167
11	1.4899		2.1176	2.5339	2.6505	2.3167	2.4253
12	1.8519		2.4177	2.3998	2.6147	2.3167	
13	2.3405	1.9909	2.2862	2.1765	2.5158	2.19	
14	1.989	2.2805	2.4253	2.1719	2.1357	1.9136	
15	2.2119	2.1357	2.2624	2.0814	2.1719	1.9342	1.8099
16	2.3148	2.3348	2.3529	2.2262	2.1765	2.0995	1.9204
17	2.2977	2.5158	2.371	2.0814	2.3167	2.2923	2.0452
18	2.3148	2.2262	2.2081	2.3282	2.19	2.19	2.0452
19	2.6223	2.2314	2.4796	2.2081	2.4326	2.6787	2.268
20	.5906	2.3777	2.5789	2.5339	2.2314	2.4796	2.268
21	2.0805	2.2314	2.3411	2.3411	2.3348	2.2497	2.1216
22	2.0178	2.1216	2.3167	2.1719	2.19	2.2262	2.0119
23	2.0178	2.0698	2.2262	2.1948	2.19	2.1719	1.9936
24	1.4752	2.0348	1.9753	2.2262	2.1582	2.19	2.1538
Max	2.6223	2.5158	2.5789	2.5339	2.6505	2.6787	2.4253
Min	.5906	1.8945	1.8473	2.0271	2.0485	1.9136	1.8099
Avg	1.7878	2.1348	2.1948	2.2474	2.2685	2.2287	2.1273

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SADAK ARJUNI S/DN.[811] BU 4811

Substation No/ Name :- 314003 / 33/11KV DAWWA S.stn

Feeder No / Name : 203 / 11 KV PANDHRI FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6874	.7461	.9175	.9156		.8322	.8048
2	.7042	.7461	.9221	.8817		.8402	.8048
3	.6874	.7291	.8785	.8817		.823	.7956
4	.7042	.7293	.8785	.8551	.8619	.7888	.7459
5	.7042	.7293	.9054	.8648	.8648	.823	.7545
6	.763	.779	.9326	.9189	.8745	.8573	.8573
7	.7461	.9014	.9665	.7975		.8817	.823
8	.8048	.9172	1.0229	.823	.8381	.8987	.8048
9	.759	.8684	.9221	.8495	.9088	.8383	.8097
10	.7716	.8848	.9816	.8149	.8859	.8048	.6874
11	.6706	.8162	.8684	.9036	.8842	.779	.7545
12	.6762		.9214	.9214	.9015	.8785	.7449
13	.6379	.8162	.9156	.7802	.9431	.779	
14	.7373		.9326	.703	.8886	.7133	.6316
15	.7619		.8551	.7611	.8288	.6984	.6062
16	.7975		.8745	.7545	.8288	.7449	.7545
17	.8059	.9945	.8215	.7773	.8322	.7969	.6706
18	.8413	1.0898	.8886	.8764	.823	.8097	.7202
19	1.0387	1.0867	1.134	1.0517	1.0566	1.0056	.905
20	1.0099	1.1403	1.0608	1.1041	1.0277	.9955	.9593
21		1.0454	.9774	.9816	.9922	.929	.905
22	.8817	.9835	.8939	.8916	.8669	.8413	.7973
23	.8402	.9945	.9665	.8745	.8573	.8402	.7712
24	.7712	.8048	.8951	.9326	.8745	.8402	.823
Max	1.0387	1.1403	1.134	1.1041	1.0566	1.0056	.9593
Min	.6379	.7291	.8215	.703	.823	.6984	.6062
Avg	.7740	.8901	.9305	.8715	.8920	.8350	.7796

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SADAK ARJUNI S/DN.[811] BU 4811

Substation No/ Name :- 314019 / 33/11KV Saundad S/stn.

Feeder No / Name : 201 / 11KV KOKANA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.893	1.8755	1.7857	1.8755	1.6632	2.1956
2	1.8378	1.9105	1.8755	1.7857	1.8204	1.6644	2.1628
3	1.8204	1.9281	1.858	1.7857	1.8031	1.6651	2.1277
4	1.8031	1.9281	1.8229	1.8073		1.6297	2.0905
5	1.7511	1.9105	1.8204	1.7703		1.6478	2.0905
6	1.7878	1.8724	1.8404	1.8031		1.6476	2.1452
7	1.8031	1.893	1.858	1.8004		1.6297	2.2119
8	1.8724	1.8755	1.9591	1.8551	1.8724	1.7318	2.2062
9	1.7684	1.8031	2.0458	1.9033	1.8031	1.7857	2.2445
10	1.9982	1.8229	1.9547	1.9456	1.893	1.7318	2.1274
11	1.9105	1.8724	1.9982	1.6832	2.0157	1.8204	2.2792
12	2.0683	1.8755	1.9631	1.9281	2.0111	1.8204	2.2362
13	1.8404	1.9806	1.8378	1.8073	1.9982	1.8378	.1829
14	1.9631	1.8031	1.9456	1.8625	1.8724	1.8551	
15	2.0332	1.8755	2.0157	1.7737	1.8724	1.7528	
16	2.1384	1.8031	1.9071	1.5775	1.9806	1.8054	1.9119
17	1.9136	1.9806	1.9806	1.869	2.0332	1.893	1.8999
18	1.8378	1.8347	1.8313	1.9418	1.9376	1.9105	2.0729
19	2.0858	1.9982	1.9631	1.9982	1.9071	1.9281	2.1024
20	2.0683	1.9631	1.9105	2.0199	1.869	1.9281	2.0548
21	1.9376	1.9105	1.8551	1.9456	1.8551	1.9071	1.9909
22	1.9456	1.8378	1.8031	1.858	1.6644	1.8755	1.2441
23	1.869	1.8378	1.8031	1.858	1.6289	2.1426	1.8623
24	1.8204	1.893	1.9313	1.8229	1.858	2.0203	1.8755
Max	2.1384	1.9982	2.0458	2.0199	2.0332	2.1426	2.2792
Min	1.7511	1.8031	1.8031	1.5775	1.6289	1.6297	.1829
Avg	1.9076	1.8876	1.9023	1.8412	1.8786	1.8039	1.9689

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SADAK ARJUNI S/DN.[811] BU 4811

Substation No/ Name :- 314019 / 33/11KV Saundad S/stn.

Feeder No / Name : 202 / 11KV TIDKA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9069	.8802	.8383	.8592	.8025	.8179
2	.9717	.8962	.8642	.8278	.8179	.7773	.8124
3	.9717	.8802	.8907	.8436		.7773	.8381
4	.9717	.7811	.8802	.8749		.8124	.8078
5	.9259	.7499	.8745	.8796		.8381	.8179
6	.9602	.7748	.8592	.8796			.823
7	.9488	.9122	.8642	.884		.8383	.8128
8	.8951	.9555	.828	.884	.8951	.8951	.8173
9	.9414	.9503	.8333	.9217	.8333	.884	.8429
10	.9488	.9393		.8951	.9804	.8579	.8688
11	.8905	.9831	.6167	.7655	.9488	.9105	.8535
12	.9105	.884	.9122	.8223	.8905	.888	.8383
13	.9217	.8951	.9069	.7907	.8796	.8535	
14	1.3441	.8749	.8223	.6562	.8796	.9259	.1334
15	.9555	.9105	.5441	.9061	.8642	.9105	.1334
16	.9945	.8749	.9217	.8642	.8796	.9105	.7716
17	.9995	.9442	.8951	.8579	.9667	.8993	.8322
18	.9014	.1158	.8796	.9105	1.004	.9105	.8592
19	.9231	.9217	.8796	.8962	.8855	.8642	.8436
20	.9172	.9172	.9665	.8962	.8749	.8383	.8436
21	.9393	.9172	.8579	.8905	.8855	.8796	.787
22	.9175	.8592	.873	.8592	.8962	.8642	.7907
23	.9069	.8592	.8471	.8488	.8583	.8535	.7811
24	.9602	.9069	.8697	.8642	.8592	.8421	.8078
Max	1.3441	.9831	.9665	.9217	1.004	.9259	.8688
Min	.8905	.1158	.5441	.6562	.8179	.7773	.1334
Avg	.9573	.8588	.8507	.8565	.8926	.8623	.7624

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SADAK ARJUNI S/DN.[811] BU 4811

Substation No/ Name :- 314019 / 33/11KV Saundad S/stn.

Feeder No / Name : 203 / 11 KV FUTALA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5028	.5895	.6097	.5014	.4917	.5935
2	.5658	.6135	.5609	.587	.4681	.4586	.583
3	.5487	.6836	.5201	.5719	.4854	.4917	.5596
4	.5487	.6687	.5028	.5937		.4862	.5256
5	.5609	.6001	.5083	.5256		.4586	.5256
6	.5434	.5316	.4908	.5765		.828	.5487
7	.5721	.6068	.5609	.5765		.4961	.5721
8	.6135	.6001	.5784	.6001	.5434	.4917	.5658
9	.583	.5375	.5434	.5426	.5609	.4687	.5487
10	.631	.5316	.5609	.5571	.5344	.4687	.6173
11	.5721	.5895	.6024	.5218	.5601	.5121	.5868
12	.5144	.6068	.7537	.5535	.5609	.6241	.5426
13	.6241	.6443	.7186	.5468	.6241	.6588	.5258
14	.5609	.6001	.7186	.5535	.6241	.583	.4835
15	.5434	.6274	.5895	.6167	.5765	.5028	.5201
16	.5544	.583	.5721	.5937	.6104	.6001	.5487
17	.6024	.5609	.5959	.6133	.6001	.6135	.5596
18	.6447	.6104	.5304	.6001	.6001	.5487	.6415
19	.6516	.5658	.6379	.5959	.6001	.6104	.6001
20	.6584	.6274	.571	.5792	.6173	.6001	.6588
21	.6024	.5765	.5569	.5434		.5765	.6068
22	.5493	.5144	.5792	.5784	.4973	.5316	.5721
23	.5548	.5256	.5792	.5487	.5201	.5087	.5609
24	.5083	.4382	.6241	.6171	.5083	.4973	.5658
Max	.6584	.6836	.7537	.6171	.6241	.828	.6588
Min	.5083	.4382	.4908	.5218	.4681	.4586	.4835
Avg	.5786	.5811	.5852	.5751	.5575	.5462	.5672

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SADAK ARJUNI S/DN.[811] BU 4811

Substation No/ Name :- 314030 / 33/11KV KOHMARA S.STN

Feeder No / Name : 201 / 11KV CHIKHLI FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3592	1.2654	1.4969	1.4842	1.5779	1.6091	1.5023
2	1.3592	1.2654		1.4685	1.5935	1.6091	1.4864
3	1.3748	1.2654	1.4661	1.4529	1.5779	1.668	1.4864
4	1.3748	1.2654	1.4815	1.4373	1.5623	1.5895	1.4864
5	1.3592	1.2654	1.4815	1.4373	1.531	1.6288	1.4706
6	1.3592	1.3117	1.4815	1.4373	1.5466	1.5935	1.4706
7	1.4373	1.4352	1.5432	1.5466	1.656	1.6288	1.5023
8	1.4998	1.4198	1.5741	1.5623	1.6872	1.5779	1.5339
9	1.4842	1.3889	1.5779	1.6248	1.6248	1.5779	1.5339
10	1.4685	1.3889	1.4352	1.6248	1.6404	1.5623	1.4251
11	1.5623	1.4661	1.4506	1.7029	1.5432	1.5432	1.6404
12	1.5432	1.4815	1.4529	1.6404		1.5497	1.5623
13	1.5432	1.4352	1.4217	1.656		1.5497	1.3435
14	1.4661	1.3889	1.4373	1.6091		1.5181	1.3592
15	1.4661	1.4661	1.4685	1.531	1.3748	.3281	1.3748
16	1.5432	1.4815		1.5466	1.406	1.5154	1.4529
17	1.5432	1.5432		1.6248	1.5623	1.5497	1.4998
18	1.4661	1.5123		1.5154	1.5779	1.2967	1.4529
19	1.4661	1.5586	1.5935	1.6872	1.8187	1.6129	1.4529
20	1.4661	1.5586	1.6248	1.7029	1.6872	1.5623	1.4373
21	1.3889	1.5586	1.5779	1.656	1.7328	1.4998	1.406
22	1.3117	1.5123	1.5466	1.6091	1.6248	1.4842	1.3592
23	1.3889	1.5123	1.5154	1.6091	1.6842	1.4864	1.3435
24	1.3748	1.2809	1.5123	1.4685	1.5935	1.668	1.3765
Max	1.5623	1.5586	1.6248	1.7029	1.8187	1.668	1.6404
Min	1.3117	1.2654	1.4217	1.4373	1.3748	.3281	1.3435
Avg	1.4419	1.4178	1.5070	1.5681	1.6001	1.5087	1.4566

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SADAK ARJUNI S/DN.[811] BU 4811

Substation No/ Name :- 314030 / 33/11KV KOHMARA S.STN

Feeder No / Name : 202 / 11KV DUGGIPAR FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3108	1.278	1.2616	1.3279	1.0978	1.0526	1.3765
2	1.3272	1.278		1.3279	1.0978	1.0526	1.3765
3	1.3272	1.278	1.2452	1.2955	1.0814	1.1174	1.3603
4	1.3108	1.278	1.2452	1.2955	1.0814	1.1142	1.3765
5	1.3108	1.278	1.2452	1.2955	1.065	1.1869	1.3765
6	1.3272	1.3108	1.2944	1.3272	1.0814	1.2289	1.4091
7	1.4091	1.3435	1.3272	1.4255	1.5402	1.543	1.4413
8	1.4091	1.2654	1.3763	1.4091	1.5729	1.5565	1.4575
9	1.4419	1.3599	1.4091	1.4575	1.3763	1.5729	1.4737
10	1.4255	1.4419	1.278	1.4746	1.3927	1.5238	1.4251
11	1.6385	1.4255	1.2944	1.6057	1.3927	1.491	1.4575
12	1.6385	1.3763	.9393		1.233	1.4575	1.4413
13	1.6385	1.2944	.9717		1.3735	1.3441	1.1822
14	1.5565	1.3108	.9555	1.4746	1.3565	1.0486	.9069
15	1.3927	1.3108	.9555	1.491	1.2955	1.0364	.9555
16	1.3927	1.3435	1.004	1.4582	1.4091	1.004	1.3279
17	1.3927	1.4419	.9878	1.5402	1.3108	1.4251	1.3765
18	1.4091	1.4255	1.4737	1.1469	1.3272	1.4251	1.4251
19	1.4419	1.0814	1.1336	1.2289	1.1869	1.1174	1.4089
20	1.065	1.065	1.1469	1.2125	1.1469	1.1174	1.3765
21	1.0322	1.065	1.1305	1.1469	1.17	1.1174	1.5061
22	1.3108	1.2944	1.3927	1.1305	1.1191	1.4089	1.3117
23	1.3108	1.278	1.3435	1.1142	1.1022	1.3765	1.2955
24	1.3272	1.278	1.278	1.3435	1.1142	1.1022	
Max	1.6385	1.4419	1.4737	1.6057	1.5729	1.5729	1.5061
Min	1.0322	1.065	.9393	1.1142	1.065	1.004	.9069
Avg	1.3811	1.2959	1.2039	1.3422	1.2469	1.2675	1.3498

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SADAK ARJUNI S/DN.[811] BU 4811

Substation No/ Name :- 314030 / 33/11KV KOHMARA S.STN

Feeder No / Name : 203 / 11KV SAWANGI FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8328	.8238	.8413	.8505	.8859	.8764	.8505
2	.815	.8063		.815	.8682	.8764	.8328
3	.815	.8063	.8238	.7973	.8505	.8669	.8328
4	.8328	.8063	.8413	.7973	.8505	.8764	.8238
5	.8328	.8063	.8413	.8238	.8328	.8669	.8413
6	.8505	.8764	.8589	.8764	.8505	.9036	.8413
7	.9214	.8939	.8939	.8764	.9391	.9114	.9114
8	.9745	1.0692	.929	.8764	.9922	.929	.9465
9	.9391	.9114	.9465	.9114	.9214	.929	.9114
10	.9568	.9816	.929	.9568	1.0631	.9036	.9465
11	1.1269	.9991	1.0517	.9568	1.1517	.964	1.0099
12	1.0517	1.0867	1.0454	.9745	1.086	.9991	.9745
13	1.0517	.9991	.9922	.9922	.9465	.9991	.8328
14	.964	.9114	.9214	.9568	.964	.9114	.8505
15	.9816	.9991	.8859	.9214	1.0277	.9114	.8328
16	.964	1.0166	.9391	.9568	1.0136	.929	.8328
17	1.0517	.9991	.9745	.9745	.9955	.8764	.8328
18	.8939	.8764	.9745	.9568	1.0099	.9816	.8859
19	.9816	1.0341	1.0631	1.0454	1.1041	1.1218	.9922
20	.9991	1.0166	.9991	1.0454	1.0277	.9922	.9568
21	.9816	1.0166	.929	.9745	.964	.9922	.9568
22	.8764	.929	.9114	.9568	.9412	.9391	.9214
23	.8764	.8939	.8764	.9036	.905	.8859	.8682
24	.8328	.8238	.8589	.8779	.8859	.8764	.8505
Max	1.1269	1.0867	1.0631	1.0454	1.1517	1.1218	1.0099
Min	.815	.8063	.8238	.7973	.8328	.8669	.8238
Avg	.9335	.9326	.9273	.9198	.9615	.9300	.8890

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SALEKASA S/DN.[812] BU 4812

Substation No/ Name :- 314005 / 33/11 KV SALEKASA

Feeder No / Name : 201 / 11 KV Salekasa

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5668	.7316	.6036	.6539	.6516	.6316	.502
2	.5668	.724	.5868	.6443	9.7013	.6316	.4858
3	.5668	.7421	.5765	.6154	.6335	.6316	.4858
4	.5668	.724	.57	.6154	.6335	.5992	.4858
5	.5668	.7499	.5868	.6316	.6335	.6478	.5182
6	.583	.7602	.6036	.6478	.6516	.6154	.5182
7	.6154	.8145	.6539	.664	.6516	.6478	.5668
8	.502	.8507	.6706	.664	.724	.6964	.4049
9	.583	.7127	.6767	.4049	.7133	.6316	.4344
10	.5506	.6371	.695	.5506	.7059	.6154	.1629
11		.5868	.7059	.3077	.6697	.6478	.2534
12		.547	.6878	.4696	.6401	.6478	.4706
13		.6371	.6516	.502	.5611	.583	.362
14		.6203	.6335	.5668	.5304	.4049	.3077
15	.4858	.6036	.3982	.5506	.5121	.421	.3077
16	.6154	.6036	.5304	.4534	.5249	.5344	.2896
17	.7682	.6036	.4359	.5506	.5668	.5344	.4862
18	.9145	.6706	.6874	.7783	.6154		.6104
19	.9231	.7042	.8551	.8869	.7773	.5668	.7545
20	.8097	.7377	.8383	.8688	.7611	.6316	.7712
21	.8688	1.2574	.788	.8326	.7287	.5992	.5967
22	.7602	.6133	.7042	.724	.6964	.5668	.4694
23	.724	.6203	.6874	.6335	.6478	.5668	.4527
24	.0171	.7059	.6036	.663	.6516	.6316	.502
Max	.9231	1.2574	.8551	.8869	9.7013	.6964	.7712
Min	.0171	.547	.3982	.3077	.5121	.4049	.1629
Avg	.6277	.7066	.6430	.6200	1.0243	.5950	.4666

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SALEKASA S/DN.[812] BU 4812

Substation No/ Name :- 314005 / 33/11 KV SALEKASA

Feeder No / Name : 202 / 11 KV Tirkhedi

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0202	1.1222		1.073	.9955	1.0688	1.085
2	1.004	1.1222	.4359	1.0562	.9877	1.0526	1.085
3	1.004	1.1222	.4694	1.004	.9877	1.0526	1.085
4	1.004	1.1222	.4694	1.0202	.9774	1.0364	1.085
5	1.0364		.503	1.0364	.9694	1.0688	1.085
6	1.085	1.086	.5365	1.085	.9774	1.1012	1.1012
7	1.1498	1.2437	.9556	1.1498	1.1222	1.1174	1.1498
8	1.1984	1.262	1.2548	1.166	1.0136	1.166	1.166
9	1.166	1.1401	1.2489	.9717	1.1946	1.085	1.267
10	1.1336	1.1568	1.3756	1.004	1.2437	1.1174	1.2127
11	1.166	1.1869	1.4299	1.1174	1.262	1.1174	1.267
12	.8745	1.2071	1.3032	1.1012	1.0608	1.1336	2.353
13	.9717	1.1065	1.2851	1.0202	1.0136	1.1012	2.0805
14	.9878	1.1401	1.1946	1.004	.9231	.9555	2.1053
15	.9555	1.1736	.9774	1.004	1.1041	.9231	1.789
16	1.004	1.0852	1.1041	1.004	1.134	.664	2.0986
17	1.1584	1.1904	1.0898	1.1403	1.0364	.9069	2.1033
18	1.2254	1.2407	1.1904	1.267	1.1174	1.0526	2.4676
19	1.5746	1.1191	1.3077	1.5565	1.4089	1.3927	2.9904
20	1.2955	1.291	1.3395	1.5203	1.3441	1.3927	2.9416
21	1.3937	1.2717	1.2548	1.4299	1.2308	1.3117	2.6338
22	1.2489	1.1065	1.1736	1.3032	1.1822	1.2146	2.306
23	1.1584	1.1065	1.1401	.4572	1.1336	1.166	2.2252
24	1.0364	1.1584	1.073	1.0898	1.0498	1.1012	2.2758
Max	1.5746	1.291	1.4299	1.5565	1.4089	1.3927	2.9904
Min	.8745	1.0852	.4359	.4572	.9231	.664	1.085
Avg	1.1188	1.1635	1.0484	1.1076	1.1029	1.0958	1.7900

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SALEKASA S/DN.[812] BU 4812

Substation No/ Name :- 314005 / 33/11 KV SALEKASA

Feeder No / Name : 203 / 11 KV Darekasa

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1619	.2378	.2515	.2347	.2561	.1619	.3915
2	.1619	.2218	.2515	.218	.2534	.1619	.3915
3	.1619	.2218	.2515	.1943	.2353	.1619	.3915
4	.1619	.2172	.2543	.1943	.2378	.1781	.3915
5	.1781	.2402	.2543	.2105	.2534	.1619	.4239
6	.1781	.2715	.2515	.2267	.2715	.1781	.4077
7	.2105	.2587	.2347	.2429	.2715	.1781	.4848
8	.1781	.2353	.2347	.2267	.2378	.1943	.422
9	.1457	.218	.2561	.2105	.2195	.1619	.378
10	.1296	.2012	.2218	.1619	.1991	.1457	.3658
11	.1619	.1844	.1781	.1457	.1646	.1134	.2987
12	.1619	.1509	.1619	.1457	.1848	.1296	.2804
13	.1619	.1823	.1663	.1457	.1848	.1457	.2972
14	.1619	.1658	.1097	.1457	.181	.1296	.2818
15	.1296	.1677	.1294	.1457	.1848	.1296	.3002
16	.1457	.1341	.1294	.1457	.1629	.1457	.2987
17	.1457	.1492	.116	.1629	.1619	.1619	.285
18	.2915	.1989	.1326	.2172	.1781	.2105	.3347
19	.2915	.3521	.3353	.3077	.2915	.3077	.5866
20	.3239	.3481	.3149	.3109	.2915	.2915	.6203
21	.3292	.3353	.2818	.3258	.2591	.2591	.5534
22	.2896	.285	.2683	.2896	.2267	.2105	.4619
23	.2534	.2652	.2515	.2572	.2105	.1943	.4451
24	.1619	.2402	.2591	.2347	.2534	.2105	.4077
Max	.3292	.3521	.3353	.3258	.2915	.3077	.6203
Min	.1296	.1341	.1097	.1457	.1619	.1134	.2804
Avg	.1949	.2284	.2207	.2125	.2238	.1801	.3958

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SALEKASA S/DN.[812] BU 4812

Substation No/ Name :- 314005 / 33/11 KV SALEKASA

Feeder No / Name : 204 / 11 KV Water Works
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0162	.0143	.0168	.0168	.0446	.0162	.0619
2	.0162	.0149	.0168	.0162	.0286	.0162	.0619
3	.0162	.0151	.0166	.0162	.0297	.0162	.0619
4	.0162	.0297	.0166	.0162	.0297	.0162	.0772
5	.0162	.0297	.0168	.0162	.0297	.0168	.0772
6	.0648	.0753	.0335	.0486	.0594	.0648	.0924
7	.0972	.1054	.116	.1134	.0892	.1134	.2506
8	.1134	.104	.1174	.1134	.104	.1134	.2506
9	.1134	.1174	.104	.1134	.104	.1134	.2412
10	.1134	.1174	.104	.1134	.1014	.1134	.2412
11	.1134	.1174	.1134	.1134	.104	.1134	.2426
12	.1134	.1174	.1134	.1134	.1014	.1134	.2412
13	.0972	.0838	.104	.1134	.104	.0972	.1191
14	.1134	.1174	.0594	.0486	.0434	.1134	.2564
15	.1134	.1187	.104	.0486	.104	.1134	.2564
16	.1134	.1174	.104	.0324	.104	.1134	.2412
17	.104	.1174	.116	.0286	.1134	.2658	.1174
18	.116	.1174	.1174	.104	.1134	.2506	.1174
19	.104	.0335	.1174	.104	.1134	.2506	.0503
20	.0446	.0168	.1174	.0594	.1134	.1696	.0335
21	.0143	.0168	.0335	.104	.0162	.0619	.0168
22	.0143	.0168	.0166	.104	.0162	.0619	.0168
23	.0149	.0168	.0168	.104	.0162	.0619	.0168
24	.0162	.0149	.0168	.0168	.104	.0772	.0162
Max	.116	.1187	.1174	.1134	.1134	.2658	.2564
Min	.0143	.0143	.0166	.0162	.0162	.0162	.0162
Avg	.0698	.0686	.0712	.0699	.0745	.1027	.1316

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SALEKASA S/DN.[812] BU 4812

Substation No/ Name :- 314005 / 33/11 KV SALEKASA

Feeder No / Name : 211 / 11 kv Salekasa AGP Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2429	.2454	.2515	.2347	.2743	.2591	.2591
2	.2429	.2401	.2683	.2105	.2743	.2591	.2591
3	.2429	.2229	.2683	.2105	.2629	.2591	.2591
4	.2429	.2353	.2515	.2105	.2572	.2429	.2591
5	.2429	.2454	.2347	.2105	.2454	.2429	.2591
6	.2429	.2743	.2155	.2267	.2743	.2753	.2591
7	.2591	.3155	.3018	.2429	.2915	.2267	.583
8	.2429	.2058	.285	.2429	.2743	.2915	.7125
9	.2267	.2012	.2804	.1943	.2229	.2753	.7716
10	.6478	.5636	.5784	.5344	.6516	.5992	.8059
11		.6443	.583	.664	.6859	.7449	.5647
12		.5868	.664	.6964	.6687	.7449	.6516
13		.6539	.6687	.7449	.6687	.6478	.6344
14		.7042	.0526	.7449	.6687	.6964	.5784
15	.6802	.6874		.7611	.6173	.7125	.6001
16	.7449	.7377	.6516	.7611	.703	.7449	.7362
17	.7888	.6874	.6874	.7888	.7125	.7611	.6539
18	.6874	.2155	.6874	.2401	.2429	.2105	.7377
19	.7362	.285	.2683	.2915	.2915	.2915	.2683
20	.7202	.3018	.2683	.3109	.2915	.2915	.2683
21	.7202	.2515	.2515	.2915	.2591	.2915	.2515
22	.2454	.2683	.2347	.2743	.2591	.2753	.2543
23	.2229	.2683	.2347	.2743	.2753	.2591	.2012
24	.2429	.2401	.2683	.2347	.2743	.2753	.2591
Max	.7888	.7377	.6874	.7888	.7125	.7611	.8059
Min	.2229	.2012	.0526	.1943	.2229	.2105	.2012
Avg	.4312	.3867	.3676	.3999	.4020	.4116	.4620

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SALEKASA S/DN.[812]

BU 4812

Substation No/ Name :- 314018 / SAKHRITOLA 33KV S/S

Feeder No / Name : 205 / 11KV SAKHRITOLA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6783	.6874	.6706	.6783	.6104	.5087	.6783
2	.6783	.6706	.6706	.6783	.6104	.5087	.6613
3	.6613	.6371	.663	.6613	.6001	.4862	.6274
4	.6613	.6371	.663	.6613	.583	.4807	.6274
5	.6443	.6539	.6783	.6443	.5765	.4917	.6104
6	.6539	.6539	.6783	.6274	.5765	.5087	.6443
7	.7042	.6706	.6274	.6783	.5596	.5765	.6443
8	.7042	.7042	.6371	.6783	.5596	.6443	.6613
9	.6796	.6539	.6274	.6371	.5596	.6104	.4578
10	.7377	.6706	.5868	.3353	.5596	.6274	.4917
11	.6796	.7042	.5765	.4917		.6783	.5426
12	.663	.6706	.4409	.5087	.5596	.6783	.5426
13	.6299	.6371	.5365	.5426	.5256	.6241	.5765
14	.663	.5868	.5197	.39	.5426	.3391	
15	.6299	.6203	.503	.5256	.5935	.5087	.373
16	.6133	.3521	.5596	.5426	.6104	.5596	.39
17	.5967	.5533	.5868	.6203	.5935	.6104	.4917
18	.6962	.6539	.7209	.6539	.6613	.6443	.6104
19	.779	.8048	.8048	.763	.7888	.8139	.763
20	.788	.8589	.788	.7545	.7461	.8309	.7122
21	.7712	.7712	.7712	.7291	.7461	.8139	.6783
22	.7209	.7291	.7291	.6783	.7461	.78	.6274
23	.7209	.7122	.6952	.6443	.6952	.7461	.6274
24	.0171	.7042	.6706	.6783	.6274	.5087	.7122
Max	.788	.8589	.8048	.763	.7888	.8309	.763
Min	.0171	.3521	.4409	.3353	.5256	.3391	.373
Avg	.6572	.6666	.6419	.6168	.6188	.6075	.5979

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SALEKASA S/DN.[812] BU 4812

Substation No/ Name :- 314018 / SAKHRITOLA 33KV S/S

Feeder No / Name : 206 / 11 KV SONEKHARI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.073	1.1271	1.2239	1.1568	.9835	1.1271	1.0898
2	1.0852	1.1105	1.2239	1.1568	.9496	1.1142	1.0608
3	1.0682	1.0774	1.21	1.1271	.9431	1.1105	1.0442
4	1.0682	1.1065	1.1934	1.1271	.9156	1.0486	1.0774
5	1.0974	1.1736	1.2071	1.1437	.9259	1.0202	1.1233
6	1.1191	1.2887	1.2717	1.1904	.9431	.9614	1.1568
7	1.1568	1.2239	1.3226	1.2548	1.0802	1.1191	1.1233
8	1.1568	1.1603	1.0227	1.2071	1.0852	1.0774	1.1271
9	1.1934	1.3592	1.2574	1.0978		.9393	.8785
10	1.291	.8619	1.1904	1.0322	1.1736	.9503	.9779
11	1.0442	1.1022	.9496	.9221	1.1736	.9995	1.0111
12	1.1401	1.0608	1.0898	.9945	1.2209	.9831	.9995
13	1.0442	1.1105	1.0059	.9339	1.17	1.094	.9762
14	1.0814	1.0898	1.0277	.9503	1.1603	1.0814	.6874
15	1.0526	.9945	1.0608	1.0343	1.1142	1.1305	.8192
16	1.0814	1.0111	1.1105	1.0111	1.1271	.9221	.7956
17	1.1105	1.0059	.8785	.9945	1.065	.9614	.9614
18	1.1022	1.1736	1.073	.9945	1.0749	1.1603	1.0682
19	1.4373	1.3672	1.4723	1.2269	1.1218	1.2656	1.1871
20	1.2795	1.4723	1.4022	1.2269	1.2656	1.3146	1.2795
21	1.2346	1.335	1.3032	1.1963	1.3546	1.1145	1.1218
22	1.1401	1.2717	1.2378	1.0682	1.1736	1.0343	1.0852
23	1.1012	1.2407	1.1736	.9724	1.1142	1.0898	1.0682
24	1.0779	1.1271	1.2239	1.1736	.9892	1.1105	1.1233
Max	1.4373	1.4723	1.4723	1.2548	1.3546	1.3146	1.2795
Min	1.0442	.8619	.8785	.9221	.9156	.9221	.6874
Avg	1.1348	1.1605	1.1722	1.0914	1.0924	1.0721	1.0351

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SALEKASA S/DN.[812] BU 4812

Substation No/ Name :- 314018 / SAKHRITOLA 33KV S/S

Feeder No / Name : 207 / 11KV HETI SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.5935	.6036	.3294	.6068		.5658
2	.6516	.5868	.6104	.3814	.6068		.5487
3	.6344	.5636	.5935	.4287	.5895		.5138
4	.6344	.5636	.5935	.4287	.5765		.4973
5	.6173	.5801	.5935	.4801	.6068		.5304
6	.6173	.6062	.6344	.5144	.6415		.6274
7	.7291	.6371	.6762	.583	.6241		.5935
8	.7291	.6443	.7373	.5256	.703	.3601	.3391
9	.4024	.639	.7291	.5506	.5144	.4287	.4854
10	.5256	.6226	.663	.3441	.5426	.4191	.5487
11	.583	.4527	.6133	.407	.6173	.4917	.5256
12	.4681	.4239	.6036	.4359	.5765	.4915	.5596
13	.407	.4694	.5935	.3149	.5868	.503	.503
14	.5316	.3561	.5765	.4359	.5735	.3052	.3906
15	.5079	.4409	.6036	.4915	.5571	.3561	.431
16	.5571	.5256	.6274	.5658	.5138	.373	.5304
17	.5801	.5197	.6952	.5426	.5868	.5596	.5365
18	.6344	.6613	.6588	.5658	.6687	.583	.6173
19	.7628	.7461	.8059	.7362	.7888	.6485	.7619
20	.7545	.7373	.7796	.7628	.703	.691	.7442
21	.6952	.7011	.7455	.7362	.6783	.6836	.6762
22	.6371	.6516	.6859	.6344	.3521	.6344	.6344
23	.6274	.6104	.6274	.6173		.6173	.6001
24	.0171	.6104	.6036		.6001		.6001
Max	.7628	.7461	.8059	.7628	.7888	.691	.7619
Min	.0171	.3561	.5765	.3149	.3521	.3052	.3391
Avg	.5815	.5810	.6523	.5136	.6006	.5091	.5567

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SALEKASA S/DN.[812]

BU 4812

Substation No/ Name :- 314021 / kawarabandh 33kv/11kv

Feeder No / Name : 208 / 11kv kawarabandh

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8596	.7762	.8779	.8775	.8215	.7316	.7468
2	.8413	.7392	.8048	.8589	.8402	.8048	.7095
3	.8413	.7023	.823	.8589	.8326	.7682	.7095
4	.8413	.7207	.3841	.8215	.8326	.823	.7095
5	.8686	.7762	.6401	.8589	.8029	.6767	.7842
6	.8962	.7762	.7316	.7468	.8029	.6401	.7499
7	.9149	.7392	.7682	.7655	.7282	.567	.7682
8	.7468	.5765	.7655	.7655	.7093	.6219	.7095
9	.7095	.6104	.8215	.7207	.6722	.4854	.1267
10	.5973	.5596	.8215	.5596	.6348	.4681	.4344
11	.8145	.6335	.7468	.3841	.6348	.5721	.4887
12	.8145	.5973	.8589	.3475	.6535	.8682	.5792
13	.724	.6697	.8962	.499	.6697	.5493	.5792
14	.7602	.7842	.8962	.3696	.5611	.6024	.2401
15	.8326	.6161	.8215	.7023	.6878	.8326	.2267
16	.8596	.7468	.9149	.6468	.7499	.9231	.2591
17	.9231	.8029	.7499	.8589	.7865	.9425	.6535
18	.8507	.8589	.7499	.7468	.8682	.9145	.6161
19	.7783	.9709	.7468	.7842	.7796	.7865	.6535
20	.7842	.7468	.7842	.8029	.8328	.7499	.6348
21	.7468	.7468	.7655	.6722	.8507	.8048	.6908
22	.6722	.8238	.7282	.8215	.8145	.8048	.499
23	.8962	.7316	.8775	.7545	.7602	.6401	.5729
24	.823	.8589	.8596	.8589	.8775	.8048	.6653
Max	.9231	.9709	.9149	.8775	.8775	.9425	.7842
Min	.5973	.5596	.3841	.3475	.5611	.4681	.1267
Avg	.8082	.7319	.7848	.7118	.7585	.7243	.5753

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SALEKASA S/DN.[812]

BU 4812

Substation No/ Name :- 314021 / kawarabandh 33kv/11kv

Feeder No / Name : 209 / 11kv sonpuri

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3944	.4908	.5258	.4801	.4694	.3772	.5144
2	.3944	.4733	.5434	.4748	.4527	.3772	.4973
3	.3944	.4733	.5258	.4578	.4527	.3601	.4801
4	.3944	.463	.5083	.4694	.4359	.3429	.5144
5	.3772	.4458	.5083	.4694	.4694	.3429	.5316
6	.373	.4801	.5083	.4694	.4359	.3429	.5144
7	.39	.4801	.5083	.4527	.4359	.4458	.5144
8	.373	.463	.4694	.4359	.4359	.4191	.4801
9	.3772	.4458	.3932	.285	.3978	.4359	.0648
10	.2347	.4287	.4096	.2984	.3978	.4359	.2294
11	.2515	.3932	.3768	.3521	.4144	.4191	.3113
12	.285	.4096	.426	.2683	.4475	.3932	.253
13	.3018	.3605	.426	.2683	.4475	.12	.3201
14	.3353	.3688	.3688	.2347	.4475	.3258	.2688
15	.3353	.4024	.3605	.3018	.431	.3932	.3201
16	.4694	.4191	.4527	.4024	.2915	.3768	.3401
17	.4024	.4481	.3953	.3353	.3601	.4096	.3315
18	.4527	.4801	.4917	.4024	.4144	.4694	.3315
19	.5533	.5601	.5765	.5365	.4973	.6062	.5194
20	.5658	.5441	.5847	.503	.5138	.5533	.5194
21	.5434	.5441	.5658	.5197	.3185	.57	.5014
22	.5083	.5609	.5316	.503	.3856	.5658	.4508
23	.4908	.5609	.4973	.503	.3856	.5365	.4334
24	.3944	.4908	.5083	.4801	.5197	.4024	.5079
Max	.5658	.5609	.5847	.5365	.5197	.6062	.5316
Min	.2347	.3605	.3605	.2347	.2915	.12	.0648
Avg	.3997	.4661	.4776	.4126	.4274	.4176	.4062

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SALEKASA S/DN.[812]

BU 4812

Substation No/ Name :- 314021 / kawarabandh 33kv/11kv

Feeder No / Name : 210 / 11KV NAVEGAON FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7362	.6226	.8048	.6802	.823	.7545	.7716
2	.7202	.6062	.7712	.6802	.7888	.7712	.7888
3	.7202	.5898	.823	.6802	.7545	.7377	.7716
4	.7202	.5898	.7545	.6722	.7545	.7545	.7545
5	.7202	.6062	.7545	.6562	.7373	.7377	.7716
6	.7202	.6226	.7545	.6722	.6718	.6706	.7373
7	.7682	.6718	.788	.6964	.703	.7545	.7293
8	.7522	.7682	.6722	.6964	.7712	.6554	.7545
9	.7522	.7373	.6722	.664	.6958	.6483	
10	.7449	.6687	.6562	.6154	.6483	.4744	.5249
11	.7449	.5344	.6882	.6226	.68	.5376	.6335
12	.7125	.6478	.6722	.5079	.68	.5535	.6516
13	.6964	.664	.6401	.5243	.6642	.5441	.6878
14	.7125	.6554	.6241	.4752	.6483	.5468	.3725
15	.6964	.6882	.6613	.4915	.6562	.5468	.5182
16	.7125	.7045	.6241	.5243	.5281	.4999	.5658
17	.7287	.6401	.6478	.6878	.5601	.6093	.6081
18	.7773	.6882	.7125	.7202	.6874	.6964	.6882
19	.8907	.7682	.7449	.8059	.759	.7811	.7209
20	.9221	.8162	.788	.8059	.759	.8097	.7461
21	.6371	.8002	.7712	.8059	.7611	.8097	.7461
22	.6706	.788	.7545	.8507	.7449	.8215	.6882
23	.6371	.788	.7209	.8573	.7449	.7449	.6882
24	.7202	.639	.7712	.7209	.8573	.7537	.703
Max	.9221	.8162	.823	.8573	.8573	.8215	.7888
Min	.6371	.5344	.6241	.4752	.5281	.4744	.3725
Avg	.7339	.6794	.7197	.6714	.7116	.6756	.6792

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314001 / 33 KV RAWANWADI S/STN

Feeder No / Name : 201 / 11kv Kamtha

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8004	1.8378	1.9631	1.8519	1.6956	1.8378	1.8755
2	1.7661	1.8378	1.9281	1.8519	1.6617	1.8176	1.8404
3	1.7684	1.8004	1.8378	1.8724	1.6461	1.8004	
4	1.7684	1.7833	1.8378	1.8898	1.6289	1.7833	
5	1.7661	1.7661	1.8004	1.9071	1.6461	1.7661	
6	1.8143	1.7147	1.8004	1.8724	1.6448	1.8347	
7	1.8652	1.6617	1.9244	1.7833	1.6766	1.8176	
8	1.9161	1.7635	1.8176	1.6278	1.7269	1.7804	
9	1.933	1.8143	1.8896	1.6448	1.7269	1.7269	
10	1.7804	1.7465	1.8442	1.6617	1.7804	1.7269	
11	1.8652	1.6448	1.8107	1.8652	1.7974	1.643	1.5939
12	1.9559	1.6766	1.7604	1.8482	1.7804	1.4419	1.6108
13	1.8945	1.7101	1.8107	1.4582	1.8519	1.4754	1.5261
14	1.7436	1.7295	1.8107	1.7147	1.8143	1.56	1.5939
15	1.8945	1.7465	1.8107	1.6632	1.7604	1.4413	1.6448
16	1.933	1.7939		1.5947	1.8107	1.56	.8478
17		1.8313	1.7465	1.4419	1.7101	1.6448	1.6956
18	1.7974	1.8004	1.7465	1.8107	1.6787	1.6461	1.8313
19	2.0576	1.9938	1.8652	.9054	1.9204	2.0111	2.1026
20	1.9456	2.0508	1.8945	1.7772	1.869	2.0332	2.0856
21	1.9982	2.0285	1.8945	1.8778	2.0508	1.9456	2.0233
22	1.8404	2.0332	1.8861	1.8945	1.9982	1.9418	2.0919
23	1.9456	2.0553	1.9204	1.8275	1.9456	1.8861	2.0233
24	1.8143	1.8755	2.0157	1.869	1.7101	1.8551	1.8724
Max	2.0576	2.0553	2.0157	1.9071	2.0508	2.0332	2.1026
Min	1.7436	1.6448	1.7465	.9054	1.6289	1.4413	.8478
Avg	1.8637	1.8207	1.8529	1.7296	1.7722	1.7490	1.7662

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314001 / 33 KV RAWANWADI S/STN

Feeder No / Name : 202 / 11kv Rawanwadi

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.869	1.1616	1.2536	1.1744	1.0974	1.1744	1.1104
2	1.8724	1.1616	1.2178	1.1393	1.0749	1.1443	1.1104
3	1.8378	1.1443	1.1641	1.1096	1.0576	1.1443	
4	1.8378	1.1443	1.134	1.0923	1.0402	1.1269	
5	1.8724	1.1789	1.1517	1.1488	1.0576	1.1096	
6	1.9418	1.1789	1.1317	1.1616	1.0631	1.1145	
7	1.9765	1.1616	1.1393	1.0682	1.0682	1.0802	
8	1.9669	1.0974	1.0631	1.0341	.9835	1.0802	
9	1.9547	1.0117	1.0692	.9945	.8987	1.0004	1.0166
10	1.9033	1.0631	1.0056	.9774	.9326	1.0004	.9774
11	1.869	1.0402	.9945	1.0117	.9945	1.4413	1.0288
12	2.0454	1.0692	.9835	.7888	.9156	.9326	1.0117
13	2.0119	1.0631	.9156	.8573	1.0117	.8987	.7202
14	1.9616	1.0343	.763	.9156	.9221	.9496	.8987
15	.639	1.0174	.7888	.9496	.9556	.8987	
16	.9012	1.046	.7969	.9665	1.0004	.78	.9054
17		1.0343	1.0117	1.0343	1.0288	.9665	1.0174
18	1.094	1.0749	1.0682	1.0174	1.0288	.9556	1.0852
19	1.3032	1.3672	1.2003	1.2689	1.2971	1.3073	1.2887
20	1.3289	1.382	1.3253	1.2174	1.2971	1.3032	1.3056
21	1.2757	1.3969	1.2894	1.2517	1.2934	1.3032	1.286
22	1.2757	1.3756	1.2715	1.2003	1.2403	1.2536	1.2517
23	1.2226	1.3394	1.2048	1.166	1.2226	1.2357	1.2174
24	1.9033	1.2048	1.3073	1.1488	1.1317	1.2048	1.134
Max	2.0454	1.3969	1.3253	1.2689	1.2971	1.4413	1.3056
Min	.639	1.0117	.763	.7888	.8987	.78	.7202
Avg	1.6463	1.1562	1.0938	1.0706	1.0672	1.1003	1.0803

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314001 / 33 KV RAWANWADI S/STN

Feeder No / Name : 203 / 11kv Kati

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	1.1616	1.258	1.1963	1.1065	.9189	1.1517
2	.9389	1.1443	1.2403	1.1789	1.1022	.9088	1.1517
3	.8215	1.1443	1.1963	1.166	1.0852	.8916	
4	.8215	1.1145	1.2136	1.1831	1.0852	.8745	
5	.8288	1.0974	1.2269	1.1869	1.0898	.8745	
6	.9012	1.0682	1.262	1.2071	1.1105	.9774	
7	.9231	1.0059	1.2209	1.1904	1.1142	1.0802	
8	.9667	1.1142	.8817	1.2574	1.1797	1.0978	
9	1.0322	1.1822	1.1904	1.2125	1.1797	1.1633	
10	1.0111	1.1961	1.3245	1.1961	1.2929	1.3094	
11	1.0774	1.0802	1.326	1.3272	1.326	1.3757	.8583
12	1.004	1.0288	1.2431	1.3435	1.1797	1.0442	1.0486
13	1.1174	.4578	1.21	1.3592	.9945	1.1603	1.1469
14	1.1797	1.2209	1.2266	1.2431	1.1105	1.2071	.9831
15	1.2378	1.3565	1.1934	1.2597	1.065	1.0898	1.0898
16	1.1361	1.4403	1.1934	1.2266	1.1961	1.2407	1.0562
17		1.3592	1.1934	1.1271	1.1961	1.2742	1.0898
18	1.153	1.2597	1.2742	1.1603	1.1401	1.2346	1.291
19	1.2346	1.2944	1.2717	1.2597	1.2689	1.3496	1.3077
20	1.262	1.3056	1.2656	1.21	1.2971	1.258	1.291
21	1.2094	1.3321	1.2136	1.21	1.262	1.2403	1.2742
22	1.1919	1.3112	1.1963	1.1768	1.2795	1.1744	1.2378
23	1.1218	1.258	1.1789	1.1568	1.2445	1.1568	1.17
24	.8551	1.1744	1.258	1.1963	1.1401	.9362	1.1568
Max	1.262	1.4403	1.326	1.3592	1.326	1.3757	1.3077
Min	.8215	.4578	.8817	1.1271	.9945	.8745	.8583
Avg	1.0375	1.1712	1.2191	1.2180	1.1686	1.1183	1.1440

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314001 / 33 KV RAWANWADI S/STN

Feeder No / Name : 204 / Banther

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.78	.9362	.8063	.8215	.8573	.8669	.9465
2	.7716	.9189	.7802	.823	.823	.8669	.9465
3	.7545	.9015	.7802	.823	.7888	.8842	
4	.7545	.8916	.8149	.8059	.7628	.8495	
5	.78	.8916	.8916	.7969	.7888	.8149	
6	.8478	.9259	.8916	.8139	.7716	.7716	
7	.8987	.8745	.9156	.823	.763	.7716	
8	.9326	.8745	.9362	.8916	.7291	.7716	
9	1.0004	.8059	.9015	.8573	.8478	.78	
10	.8987	.9189	.7373	.8402	.6783	.763	
11	1.0117	.7712	.823	.7545	.7969	.78	.8059
12	.8383	.8413	.8402	.6104	.7545	.6613	.9259
13	.788	.8573	.8817	.8139	.8573	.78	.9088
14	.763	.8478	.8478	.7461	.7969	.763	.763
15	.8288	.8648	.8478	.8309	.6859		.6443
16	.8048	.8817	.8648	.6952	.8139	.7122	.8478
17		7.2017	.8987	.7969	.8478	.8648	.9088
18	.78	.9088	.8916	.8139	.8059	.8916	.763
19	.9088	.9114	.9259	.9602	.8669	1.0576	.8987
20	.964	.8745	.9835	.9088	.9189	.964	.9156
21	.9816	1.0166	.9665	.9259	.929	1.0029	.9156
22	.9816	.929	.9556	.9259	.9114	1.0056	.8987
23	.9816	.8149	.8048	.929	.8939	.9536	.8745
24	.7969	.9465	.8063	.8215		.8939	.9536
Max	1.0117	7.2017	.9835	.9602	.929	1.0576	.9536
Min	.7545	.7712	.7373	.6104	.6783	.6613	.6443
Avg	.8630	1.1503	.8664	.8262	.8126	.8466	.8698

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314001 / 33 KV RAWANWADI S/STN

Feeder No / Name : 205 / Katangi Industrial

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2054	.2075	.2641	.1886	.112	.1698
2	.2641	.2054	.1867	.2829	.2075	.1307	.1698
3	.2641	.1867	.1886	.3018	.2075	.112	
4	.2829	.168	.2054		.1886	.112	
5	.2641	.168	.2241	.3206	.1886	.1307	
6	.2641	.2987	.3018	.3206	.1886	.1307	
7	.2452	.2801	.2427	.3174	.1698	.1307	
8	.2829	.2614	.2829	.2829	.2263	.1307	
9	.2075	.2614	.3018	.2427	.2075	.1307	.2452
10	.2054	.2241	.2452	.2614	.132	.1509	.1867
11	.0373	.2987	.415	.3734	.2241	.2263	.2427
12	.3961	.4854	.4527	.4108	.1886	.2263	.3547
13	.3174	.5041	.415	.2987	.2829	.3395	.0187
14	.2801	.5228	.3961	.3734	.2427	.2452	.3361
15	.2801	.4527	.2641	.3174	.1494	.2452	.2054
16	.2452	.5093	.2641	.2614	.2641	.2641	.4294
17		.4294	.2641	.3395	.168	.4527	.415
18	.132	.3881	.2452	.2641	.1867	.3921	.3018
19	.1867	.2987	.1886	.2075	.168	.2801	.2263
20	.2614	.2075	.1698	.1698	.1307	.2075	.2263
21	.2054	.2641	.1886	.1509	.1307	.1509	.2075
22	.2614	.2452	.2075	.1509	.112	.1132	.1886
23	.2427	.2452	.2075	.1509	.112	.0943	.1886
24	.2452	.2241	.2263	.2641	.1509	.1494	.1698
Max	.3961	.5228	.4527	.4108	.2829	.4527	.4294
Min	.0373	.168	.1698	.1509	.112	.0943	.0187
Avg	.2450	.3056	.2621	.2751	.1840	.1941	.2379

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314006 / 33 kv fulchur s/stn

Feeder No / Name : 201 / Fulchur

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8299	1.0185	.9619	.9335	.9709	1.8225	.9335
2	.8299	.9997	.9431	.9335	.8962	1.7429	.8775
3	.811	.9997	.9242	.8962	.8775	1.6819	
4	.811	.9808	.9431	.8962	.8775	1.6937	.8589
5	.7922	.9808	.9808	.9709	.8962	1.675	.8775
6	.9054	.9808	1.0374	.9522	.8962	1.7429	.8962
7	.9808	1.0374	1.0562	.9335	.8962	1.7055	.8589
8	.9808	.9242	.9431	.811	.8775	1.7124	.8962
9	.8299	.8865	.8488	.7655	.8215	1.6819	.9149
10	.811	.8676	.8488	.811	.8029	1.6328	.7655
11	1.0374	1.0562	1.1317	1.1317	1.0642	2.1125	.8775
12	1.0374	1.2071	1.3014	1.0751	1.2136	1.9955	1.0642
13	.9997	1.1883	1.1949	1.094	1.1203	2.1193	.8775
14	1.0185	.9808	1.0185	.811	.8775	1.8344	.7842
15	.9242	1.0562	1.1694	1.0374	.9149	1.9346	.7468
16	1.094	1.226	1.0751	1.1883	.9149	1.9021	1.2323
17	1.2637	1.2826	1.226	1.2071	1.1203	2.1125	1.2323
18		1.2071	1.3392	1.226	1.0642	2.2058	1.0829
19	1.4335	1.3014	1.4563	1.3392	1.1389	2.3837	1.2696
20	1.1506	1.1694	1.3014	1.2826	1.0456	2.2717	1.1576
21	1.1883	1.1128	1.2136	1.226	1.0456	2.2668	1.2696
22	1.1883	1.1694	1.1203	1.1128	1.0456	2.2855	1.2136
23	1.094	1.094	1.0829	1.094	.9709	2.1616	1.1203
24	.8299	1.0185	1.0185	1.0082	.9997	1.9513	1.0082
Max	1.4335	1.3014	1.4563	1.3392	1.2136	2.3837	1.2696
Min	.7922	.8676	.8488	.7655	.8029	1.6328	.7468
Avg	.9931	1.0727	1.0890	1.0307	.9729	1.9429	.9920

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314006 / 33 kv fulchur s/stn

Feeder No / Name : 203 / 11kv Adasi
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974	1.2929	1.4255	1.3226	1.4074	1.1934	2.8959
2	1.0974	1.2929	1.4089	1.3546	1.3413	1.1934	2.9131
3	1.0974	1.2763	1.3757	1.3546	1.2574	1.1768	1.5242
4	1.1145	1.2929	1.3923	1.3546	1.2887	1.1603	2.3643
5	1.1317	1.3094	1.4089	1.3375	1.2209	1.1603	2.3643
6	1.166	1.3094	1.4255	1.3413	1.2039	1.1934	2.4291
7	1.2689	1.3592	1.3426	1.3032	1.2039	1.1603	2.6711
8	1.3032	1.2763	1.3592	1.3546	1.153	1.1768	2.8014
9	1.2346	1.2597	1.3757	1.3375	1.153	1.2431	2.6231
10	1.0802	1.094	1.3094	1.2929	1.1145	1.2517	2.5317
11	1.0814	.663	1.2929	1.2431	1.1065	1.2689	2.6973
12	1.1603	1.21	1.2431	1.1934	1.0395	.9774	2.5317
13	.9779	1.2266	1.1934	1.2266	1.2883	1.0974	2.2268
14	1.094	1.1603	1.1437	1.1105	1.17	.9774	1.9203
15	1.1768	1.2597	1.1437	1.1934	1.153	1.166	1.9509
16	1.1934	1.2763	1.1437	1.21	1.0442		2.3033
17	1.0978	1.3094	1.1934	1.2929	1.1437	1.1831	2.5111
18		1.3094	1.2929	1.3592	1.2763	1.2763	2.6406
19	1.4091	1.5775	1.4918	1.5249	1.21	1.4754	3.2027
20	1.4091	1.5083	1.4586	1.5083	1.2597	1.5432	3.1817
21	1.3763	1.5249	1.4918	1.4752	1.2763	1.5089	3.1512
22	1.3599	1.4918	1.4403	1.4255	1.2431	1.4746	3.1036
23	1.3272	1.4255	1.3889	1.4089	1.2266	1.3757	3.1036
24	1.1393	1.3094	1.4089	1.3565	1.4089	1.21	2.9111
Max	1.4091	1.5775	1.4918	1.5249	1.4089	1.5432	3.2027
Min	.9779	.663	1.1437	1.1105	1.0395	.9774	1.5242
Avg	1.1910	1.2923	1.3396	1.3284	1.2163	1.2367	2.6064

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314006 / 33 kv fulchur s/stn

Feeder No / Name : 204 / 11 KV Bambleshwari

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1905	.2427	.0953	.1715	.1698	.1886
2	.1867	.1715	.2241	.1143	.2096	.1886	.1886
3	.168	.1715	.2427	.197	.1905	.1698	
4	.1509	.1715	.2241	.2149	.1715	.1698	.1646
5	.1698	.1905	.2054	.2103	.1715	.1698	.1829
6	.1509	.1715	.2054	.2096	.1524	.1698	.128
7	.1509	.1905	.2241	.2286	.1334	.1509	.1509
8	.1509	.1715	.1867	.1905	.1905	.0754	.1132
9	.1132	.1905	.112	.1334	.0953	.0754	.0934
10	.3584	.4572	.2054	.2987	.2286	.1698	.2054
11	.5228	.5281	.3174	.4294	.4572	.2829	.3174
12	.6161	.6224	.4481	.4854	.5093	.3018	.4668
13	.5601	.547	.4668	.5415	.4527	.3961	.5601
14	.5228	.5788	.3547	.4481	.4527	.2641	.4481
15	.5415	.3206	.4294	.3734	.415	.1698	.5415
16	.5415	.4338	.4854	.4668	.4715	.3395	.4108
17	.5093		.3734	.3921	.4338	.3961	.4294
18		.4338	.3361	.4108	.2075	.4527	.4668
19	.4527	.3961	.3395	.2801	.1886	.3772	.2667
20	.3395	.2829	.2987	.2801	.1132	.3961	.0953
21	.1886	.1715	.112	.0762	.0943	.1524	.1334
22	.1698	.2858	.0934	.168	.1698	.1715	.1524
23	.1509	.2667	.0934	.1867	.1132	.1886	.1715
24	.1867	.1905	.3174	.0953	.2096	.1509	.2096
Max	.6161	.6224	.4854	.5415	.5093	.4527	.5601
Min	.1132	.1715	.0934	.0762	.0943	.0754	.0934
Avg	.3082	.3102	.2724	.2719	.2501	.2312	.2646

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314006 / 33 kv fulchur s/stn

Feeder No / Name : 205 / Maheshwari industrial
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.3429	.3429	.3429	.1905	.1905	.1905
2	.2858	.3239	.3239	.362	.2096	.1715	.1905
3	.2858	.3048	.3048	.3429	.2477	.1715	
4	.2667	.3239	.3239	.3429	.2286	.1524	.1905
5	.1905	.3429	.3048	.3239	.1905	.1715	.1715
6	.1905	.3429	.2858	.362	.2096	.1715	.1715
7	.1905	.3429	.2858	.381	.1905	.1715	.1524
8	.1905	.3239	.3239	.381	.1905	.1905	.1905
9	.2858	.3429	.362	.3429	.1715	.1715	.1715
10	.2858	.3429	.362	.381	.1905	.1905	.1905
11	.4001	.2477	.381	.381	.1715	.2096	.2096
12	.4382	.4191	.4001	.4001	.1715	.2477	.2096
13	.4001	.4001	.4001	.4001	.1905	.2286	.2096
14	.381	.362	.4001	.381	.1905	.2477	.1905
15	.4001	.4191	.4001	.4001	.1715	.2477	.2286
16	.4001	.4191	.4191	.4001	.1905	.2477	.2667
17	.381	.3239	.381	.381	.1715	.2286	.2477
18		.381	.3429	.362	.1905	.2286	.2096
19	.3429	.381	.381	.3048	.1905	.2096	.1905
20	.3239	.381	.362	.362	.1905	.1715	.1715
21	.3429	.362	.362	.362	.2096	.1905	.1905
22	.3429	.3429	.362	.362	.1715	.1715	.1905
23	.3429	.3429	.3429	.381	.1715	.1715	.1905
24	.362	.3429	.3429	.362	.2667	.1905	.1905
Max	.4382	.4191	.4191	.4001	.2667	.2477	.2667
Min	.1905	.2477	.2858	.3048	.1715	.1524	.1524
Avg	.3214	.3524	.3540	.3667	.1945	.1977	.1963

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314006 / 33 kv fulchur s/stn

Feeder No / Name : 206 / Saha Industrial feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9795	.8764	.8962	.9709	.7468	.4108	.7842
2	.9425	.7459	.8402	.8865	.8029	.4108	.7468
3	.8775	.811	.8962	.9149	.7095	.3921	
4	.8215	.7733	.8402	.8402	.7655	.3921	.7282
5	.679	.7356	.9335	.8029	.6348	.4108	.8589
6	.7167	.8299	.8029	.8215	.6161	.4108	.8029
7	.6668	.8488	.9145	.9145	.6722	.5041	.7842
8	.8383	.9431	.9522	.9335	.7282	.4668	.5788
9	.8002	.9619	.9997	1.0642	.7468	.5093	.7282
10	.8383	1.0374	1.1812	1.0829	.8029	.5847	.7655
11	1.3256	1.2003	1.5242	1.251	.9522	.9979	1.251
12	1.363	1.3717	1.5623	1.3443	.9709	1.1576	1.2323
13	1.3443	1.1437	1.6385	1.363	.8775	1.6078	1.251
14	1.1763	1.4146	1.448	1.0829	.7655	1.3121	1.0562
15	1.0456	1.3146	1.3146	.9522	.7545	1.1203	1.3014
16	1.2696	1.251	1.3908	1.1576	.7468	1.0669	1.3203
17	1.1812	1.2136	1.1949	.9709	.7842	1.3908	1.358
18		1.1949	1.0456	.7842	.6908	1.2323	1.2637
19	.3429	1.2449	.8002	.7095	.9522	1.0269	1.1317
20	.8383	1.0829	.9522	.6478	.5415	.4572	.9431
21	.8002	.8962	1.0751	.6668	.5228	.4954	.8865
22	.8573	.8962	1.0562	.6722	.4108	.743	.7545
23	.8954	.9522	1.1883	.7049	.4294	.8215	.7545
24	1.0164	.9145	.8775	1.0829	.7282	.4108	.8215
Max	1.363	1.4146	1.6385	1.363	.9709	1.6078	1.358
Min	.3429	.7356	.8002	.6478	.4108	.3921	.5788
Avg	.9398	1.0273	1.0969	.9426	.7230	.7639	.9610

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314006 / 33 kv fulchur s/stn

Feeder No / Name : 207 / Civil Line

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5281	.5601	.5975	.5975	.6535	.6413	.5975
2	.5281	.5601	.5788	.5847	.6161	.6413	.547
3	.4904	.5415	.5601	.5847	.5975	.6224	
4	.4904	.5228	.5788	.6036	.6224	.6224	.5658
5	.4904	.5415	.6161	.6224	.6602	.6036	.5847
6	.6036	.6348	.6722	.6908	.6722	.6224	.6224
7	.6602	.6908	.7282	.7545	.6722	.6224	.7468
8	.679	.7095	.7095	.7167	.6908	.6224	.6535
9	.7167	.7468	.7095	.6908	.7468	.6979	.6722
10	.6602	.6348	.6535	.7095	.7468	.6602	.6722
11	.6161	.6908	.6161	.6722	.7095	.6348	.5788
12	.5601	.5975	.5975	.6348	.6722	.5415	.5601
13	.5041	.5228	.5601	.5228	.6722	.5228	.5228
14	.4668	.5093	.4854	.4854	.5788	.5228	.4481
15	.4108	.4715	.4854	.5228	.5228	.4481	.4294
16	.4854	.5228	.5041	.5228	.4904	.5041	.4854
17	.4854	.5788	.5228	.5601	.5847	.5228	.499
18		.6348	.5975	.6161	.6036	.5975	.6099
19	.7655	.8029	.8215	.8215	.7922	.8029	.7023
20	.7655	.7842	.8215	.8402	.7733	.7545	.7392
21	.7282	.7842	.8029	.8215	.7545	.7356	.7468
22	.6722	.7468	.7655	.7842	.7545	.7356	.7095
23	.6348	.7095	.6908	.7468	.6979	.6908	
24	1.0562	.5788	.6348	.6224	.6722	.6602	.6348
Max	1.0562	.8029	.8215	.8402	.7922	.8029	.7468
Min	.4108	.4715	.4854	.4854	.4904	.4481	.4294
Avg	.6086	.6282	.6379	.6554	.6649	.6263	.6058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314011 / DASGAON

Feeder No / Name : 201 / 11KV Dasgaon

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9672	3.3668	3.3714	3.4995	3.5414	3.5958	3.5391
2	2.9401	3.2937	3.3551	3.4382	3.4995	3.5181	3.4796
3	2.9241	3.2723	3.317	3.3917	3.4248	3.4929	3.4682
4	2.8826	3.235	3.3295	3.3448	3.3513	3.4107	3.3936
5	2.8745	3.2297	3.347	3.2068	3.3097	3.4054	3.3639
6	3.0201	3.2426	3.4179	3.2015	3.1276	3.4214	3.3615
7	2.8445	3.1189	2.9417	2.9568	2.9028	3.1013	3.0026
8	3.0864	3.189	3.0716	3.3882	3.0422	3.0975	3.2103
9	3.3105	2.9614	3.2167	3.4065	3.4896	3.3752	3.3539
10	3.0464	2.931	3.2354	3.5071	3.5223	3.3692	3.2836
11	3.4355	3.1318	3.1148	3.6854	3.3109	3.549	3.107
12	3.5665	3.3318	3.1872	3.6428	3.501	3.4688	3.344
13	3.3996	2.4442	3.2522	3.1481	3.4853	3.3372	3.3185
14	3.453	2.6415	3.3076	3.5071	3.6141	3.4811	3.2394
15	3.4063	3.0109	3.2499	3.4722	3.6268	3.5125	2.7559
16	2.024	3.3629	3.2426	3.4027	3.5471	1.9586	3.0916
17	3.5696	3.5418	3.5507	3.2213	2.9599	1.9768	3.3726
18	3.3089	3.4034	3.5791	3.4614	3.2121	3.1222	3.2745
19	3.5216	3.5263	1.8945	3.5269	3.5135	3.9415	3.6846
20	3.7388	3.7194	3.8207	3.7701	3.573	3.9925	3.7351
21	3.7937	3.8906	3.7978	3.8211	3.7513	3.898	3.9549
22	3.5993	3.7625	3.6976	3.7338	3.7269	3.8348	3.8028
23	3.4195	3.6307	3.6431	3.6412	3.6687	3.7129	3.7544
24	3.1596	3.4606	3.4141	3.5326	3.6404	3.6362	3.5985
Max	3.7937	3.8906	3.8207	3.8211	3.7513	3.9925	3.9549
Min	2.024	2.4442	1.8945	2.9568	2.9028	1.9586	2.7559
Avg	3.2205	3.2791	3.3065	3.4545	3.4309	3.3837	3.3954

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314011 / DASGAON

Feeder No / Name : 202 / Dangurli Express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	06-MAR-17
HR	Load (MW)
11	1.8111
Max	1.8111
Min	1.8111
Avg	1.8111

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314011 / DASGAON

Feeder No / Name : 203 / 11kv Birsola

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4685	1.749	1.937	1.8097	2.1088	2.021	2.2197
2	1.4756	1.7221	1.9143	1.7886	2.0705	1.9614	2.229
3	1.4726	1.7191	1.9097	1.7509	2.0576	1.95	2.306
4	1.4741	1.7161	1.8863	1.6731	2.03	1.925	2.3334
5	1.5261	1.7299	1.8787	1.6232	2.0285	1.9711	2.4667
6	1.6299	1.7665	1.9439	.8627	2.0047	2.0294	2.5867
7	2.0249	2.2234	2.3373	2.2245	2.3303	2.3994	3.2814
8	2.2933	2.5476	2.5526	2.4805	2.5444	2.6883	3.1291
9	2.4173	2.6307	2.6094	2.6516	2.8406	2.83	4.5241
10	2.4978	2.6063	2.9238	2.9173	2.9114	2.8551	4.7611
11	3.0513	3.2248	2.9325	3.0575	3.2583	2.6579	4.1469
12	2.807	2.6513	2.8078	1.5059	3.2668	2.8511	2.5964
13	2.6911	2.702	2.6095	3.022	3.3307	2.7967	2.3493
14	2.8302	2.8245	2.8003	2.8667	3.3436	2.7668	2.3541
15	2.9221	2.9043	3.1224	3.1811	3.3394	2.729	2.392
16	2.8343	2.8918	3.3542	3.2601	3.2946	2.7563	2.0511
17	3.0532	2.9987	3.2935	3.5121	3.336	2.7424	1.9992
18	2.5177	2.4577	3.3358	3.2946	2.6962	2.7479	2.4417
19	2.3567	2.3158	1.2704	2.8712	2.3781	2.7883	2.7155
20	2.4558	2.3701	2.4292	2.5846	2.4589	2.7885	2.6724
21	2.33	2.2897	2.1378	2.5026	2.3339	2.6107	2.5965
22	2.117	2.1541	1.9386	2.3194	2.159	2.5229	2.4688
23	1.9494	1.9947	1.8856	2.2321	2.0617	2.2893	3.7912
24	1.6901	1.8785	1.9162	1.9872	2.0931	2.1658	2.3902
Max	3.0532	3.2248	3.3542	3.5121	3.3436	2.8551	4.7611
Min	1.4685	1.7161	1.2704	.8627	2.0047	1.925	1.9992
Avg	2.2453	2.3362	2.4053	2.4158	2.5949	2.4935	2.7834

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314011 / DASGAON

Feeder No / Name : 204 / 11kv Dasgaon AGP

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.1943
2						.1943
3						.1943
4						.1943
5						.1943
6						.1943
7						.1943
8						.1943
9						.1943
10	.1296		.1781	.1134	.0972	.2105
11	.1619	.0972	.1943	.1296	.1296	.1943
12	.1619	.0972	.1943		.1781	
13	.0972	.0972	.1943	.1781	.1781	
14	.0972	.0972	.1296	.1781	.1781	
15	.1134	.1296		.1781	.1619	
16	.1619	.1296	.2105	.1943	.1619	
17	.1943	.1619	.2105		.1943	
24						.1943
Max	.1943	.1619	.2105	.1943	.1943	.2105
Min	.0972	.0972	.1296	.1134	.0972	.1943
Avg	.1397	.1157	.1874	.1619	.1599	.1957

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314012 / 33 KV SURYATOLA S/STN

Feeder No / Name : 205 / 11kv Tumkheda Industrial SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	1.1538	.8505	.7712	.9236	1.0395	1.1538
2	.9907	1.1827	.7697	.7758	.8749	1.0959	1.1827
3	.9907	1.1599	.7819	.788	.8307	1.0928	1.1111
4	.9968	1.1965	.7834	.8322	.8962	1.102	1.1736
5	.9435	1.1157	.8109	.7956	.9175	1.1157	1.073
6	.9861	1.1675	.7514	.7362	.9114	1.0578	1.0319
7	1.0029	.9694	.6783	.6874	.8139	1.0181	.8093
8	.9877	.7362	.6447	.6005	.8093	.7788	.6432
9	.9724	.8581	.6843	.5152	.8444	.6417	.6706
10	.7407	.8596	.6401	.538	.6737	.6539	.7697
11	.9526	1.0212	.7514	.8368	.9755	.7651	.9175
12	1.0578	1.1675	.9633	.9358	1.0791	.8474	.8932
13	1.0898	1.3001	1.0273	1.1934	1.0471	.9998	.9556
14	1.1462	1.3382	1.0151	1.2148	1.0791	1.0532	1.0151
15	1.0669	1.323	.8794	1.0303	1.0181	1.2346	1.1309
16	.9816	.5213	.9922	1.0669	1.0136	1.2727	1.1553
17	1.0212		.9877	.9678	.9343	1.3565	1.1812
18	1.041	.7865	1.2224	1.0029	.9465	1.3596	1.1385
19	.9526	.7987	1.0014	.9587	.8886	.9739	.8337
20	.8109	.8596	.8505	.6904	.9709	1.0029	.884
21	.8215	.9084	.7209	.6493	.8307	1.0151	.8551
22	.8352	.7651	.6935	.6691	.8459	.9541	.8794
23	1.1888	.8474	.8672	.7331	1.0014	1.0806	1.1843
24	1.2041	.9206	.8185	.8169	1.0319	1.1218	1.1706
Max	1.2041	1.3382	1.2224	1.2148	1.0791	1.3596	1.1843
Min	.7407	.5213	.6401	.5152	.6737	.6417	.6432
Avg	.9873	.9981	.8411	.8253	.9233	1.0264	.9922

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314012 / 33 KV SURYATOLA S/STN

Feeder No / Name : 206 / 11kv Kuradi

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2207	2.463	2.7054	2.6444	2.6124	2.5926	2.5972
2	2.1171	2.4112	2.6337	2.6063	2.5774	1.39	2.524
3	2.114	2.1643	2.6383	2.6139	2.5789	1.3611	2.5225
4	2.1689	2.1277	2.6688	2.6337	2.5697	1.3489	2.5149
5	2.1887	2.1597	2.7084	2.6307	2.5789	1.355	2.5149
6	2.2542	2.2512	2.745	2.6993	2.5926	1.3565	2.5408
7	2.3259	2.3091	2.71	2.6139	2.5453	1.2559	2.4844
8	2.4204	2.3198	2.6078	2.3777	2.4006	.9602	2.3868
9	2.3503	2.335	2.4265	2.2573	2.3716	.8535	2.21
10	2.2161	2.2375	2.2847	2.239	2.3	1.6156	2.0043
11	2.1704	2.2969	2.143	2.1948	2.332	1.8747	2.018
12	1.9585	2.2908	2.2161	2.2314	1.4236	1.9982	1.8275
13	1.6019	2.2771	2.2619	2.2344	2.1293	2.0835	1.9067
14	1.6629	2.2725	2.2451	2.1475	2.2116	2.0683	1.9387
15	1.643	2.1887	2.1628	1.893	2.1308	1.9951	1.9784
16	1.6217		2.21	2.1186	2.2619	2.1414	2.1247
17	1.9906	1.419	2.3	2.1445	2.268	2.2573	2.2024
18	2.1795	2.489	2.3045	2.2161	2.3152	2.3716	2.3122
19	2.6734	2.9904	2.873	2.8624	2.8639	2.6978	2.8654
20	2.7191	3.1047	2.8822	2.9371	2.905	2.8151	2.9218
21	2.7191	2.9752	2.8441	2.8715	2.8349	2.7221	2.8669
22	2.6459	2.8959	2.8639	2.7999	2.8029	2.6993	2.8197
23	2.5636	2.8182	2.7648	2.7374	2.6749	2.6703	2.7831
24	2.5118	2.7587	2.6947	2.6444	2.649	2.6261	2.6536
Max	2.7191	3.1047	2.8822	2.9371	2.905	2.8151	2.9218
Min	1.6019	1.419	2.143	1.893	1.4236	.8535	1.8275
Avg	2.2099	2.4155	2.5373	2.4729	2.4554	1.9629	2.3966

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314017 / 33 kv Zilmilli

Feeder No / Name : 201 / Kamtha-Birsi Feeder
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	8.7154	7.3389	9.6632	8.6706	9.0112	8.8573	8.8935
2	8.6592	7.2387	9.608	8.543	8.9163	8.802	8.7563
3	8.69	7.1787	9.5908	8.4523	8.9731	8.7087	8.9253
4	8.8021	7.2778	9.5366	8.4692	8.8325	8.6386	8.86
5	8.8783	7.2969	9.4437	8.5201	8.8645	8.6555	8.9045
6	8.8409	7.2336	9.5869	8.6801	8.8969	8.7792	8.9308
7	9.4269	7.5833	9.9852	8.7201	8.7716	9.2135	9.3278
8	9.688	7.9226	***	9.0792	9.0383	9.7909	8.7251
9	***	8.6635	***	9.0352	9.0718	***	9.7432
10	***	8.4316	***	9.0727	9.6465	9.6609	8.7895
11	***	***	***	9.968	9.9048	***	9.1274
12	***	***	***	***	9.5534	***	9.2632
13	***	***	***	***	9.3076	***	8.5902
14	***	***	***	9.2364	9.0893	9.3347	8.521
15	***	***	***	9.4642	8.8859	9.5317	9.0705
16	***	***	***	9.477	7.5237	***	9.1754
17		***	***	9.6297	8.1304	9.6594	8.6386
18	6.6015	9.8872	***	9.6465	8.9987	9.0832	9.8324
19	9.0363	***	8.8401	***	***	9.9421	9.6461
20	9.1964	***	9.948	***	***	9.3537	***
21	8.8737	***	9.9692	9.4593	***	9.8705	***
22	8.36	***	9.3941	9.3621	9.9299	9.4322	9.8156
23	7.7199	***	8.9026	9.1583	9.2345	9.1489	9.4421
24	7.4783	9.4216	8.9564	9.1434	8.991	9.0649	8.9262
Max	11.5569	10.7123	10.8597	10.5426	10.1884	10.667	10.2435
Min	6.6015	7.1787	8.8401	8.4523	7.5237	8.6386	8.521
Avg	9.4064	9.1589	9.9984	9.3037	9.1629	9.4622	9.1776

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314017 / 33 kv Zilmilli

Feeder No / Name : 202 / 11kv Girola

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7907	5.0137	4.0086	4.4277	.7291	4.3515	4.7782
2	2.3415	4.9337	3.9533	4.4277	4.7051	4.3343	4.7235
3	2.3205	4.862	3.8599	4.441	4.6043	4.3515	4.7384
4	2.3815	4.9154	3.8323	4.4262	4.5953	4.393	4.6833
5	2.4577	4.9916	3.8111	4.4144	4.5515	4.3549	4.6696
6	2.5453	5.0388	3.9494	4.4441	4.6277	4.4485	4.7249
7	2.4348	5.17	4.7897	4.6022	4.675	4.7893	4.651
8	2.3586	4.8239	4.8232	4.2905	4.1966	3.4722	2.6246
9	1.7909	4.0619	4.4216	4.1427	4.6456	3.6865	3.9117
10		4.7136	4.2532	4.0737	4.5988	3.9048	3.524
11		4.2315	3.988	4.4803	4.819	4.5066	.6478
12		4.5904	3.9106	3.1626	.724	4.4734	3.0937
13		4.7851	4.3542			4.1499	4.297
14	1.2146	4.1381	4.3023	3.9758		4.4048	4.5694
15	4.8826	4.5056	4.052	4.1458	4.5694	4.4875	4.6919
16	4.8992	4.747	4.0497	4.2905	4.6211	3.8069	4.5226
17	5.2919	4.2524	3.9065	4.9626	4.7005	4.2183	4.4353
18	5.1942	4.7047	4.1446	4.3972	4.3913	4.27	4.9078
19	5.2609	4.8247	3.315	5.1296	4.6563	4.7001	3.4294
20	5.5156	4.9215	4.5527	5.2069	4.7734	4.3732	5.0183
21	5.5918	5.0478	4.6673	4.691	4.8053	4.8742	5.1502
22	5.5516	4.9363	4.6673	4.9249	4.542	5.0517	5.2641
23	5.3653	4.73	4.5496	4.8868	4.2924	4.9123	5.0735
24	4.2676	4.5816	4.4829	4.9078	4.222	4.7877	4.9337
Max	5.5918	5.17	4.8232	5.2069	4.819	5.0517	5.2641
Min	1.2146	4.0619	3.315	3.1626	.724	3.4722	.6478
Avg	3.7228	4.7301	4.1935	4.4718	4.2294	4.3793	4.2943

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314017 / 33 kv Zilmilli

Feeder No / Name : 203 / 11kv Sirpur Feeder
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6057	1.7004	1.7635	1.6617	1.5089	1.8313	1.6598
2	1.5746	1.6712	1.7465	1.6632	1.4586	1.7974	1.6617
3	1.7528	1.6575	1.7126	1.6278	1.5089	1.7635	1.6804
4	1.7147	1.9433	1.6766	1.6278	1.4255	1.7295	1.7318
5	1.7528	2.0005	1.6933	1.6975	1.4586	1.7269	1.749
6	1.4737	1.7939	1.7126	1.6956	1.4251	1.7101	1.7635
7	1.6032	1.7859	1.7101	1.6712	1.3565	1.7604	1.8107
8	1.7532	1.8442	1.7772	1.7532	1.4752	1.8275	1.6244
9	1.6221	1.6617	1.6598	1.7772	1.5091	1.7974	1.5402
10	1.7238	1.7269	1.6095	1.0442	1.4922	1.5927	1.5729
11	1.7532	1.6263	1.6448	1.1271	1.6108	1.6549	1.5746
12	.8036	1.6278	1.326	1.0608	1.7101	1.6741	1.4918
13	1.873	1.7269	1.2597	1.4586	1.7939	1.7101	1.4752
14		1.3916	1.4922	1.5249	1.7404	1.7604	1.5074
15		1.4419	1.6598	1.5746	1.6575	1.7238	1.6244
16		1.358	1.704	1.7101	1.6933	1.7772	1.6263
17	1.8067	1.7269	1.491	1.643	1.7404	1.9161	1.6598
18	1.543	1.7436	1.7695	1.6575	1.9113	1.7901	1.7604
19	.5935	1.7337	1.5565	1.4217	1.9033	1.5581	1.8004
20	1.8755	1.8229	1.7269	1.491	1.8724	1.6712	1.7804
21	1.9033	1.7147	1.7939	1.5089	1.8176	1.704	1.8176
22	1.8945	1.6617	1.7238	1.4575	1.8004	1.7238	1.9161
23	1.8442	1.7804	1.7736	1.6118	1.8143	1.6907	1.8652
24	1.7695	1.7695	1.7804	1.5769	1.5769	1.8652	1.6933
Max	1.9033	2.0005	1.7939	1.7772	1.9113	1.9161	1.9161
Min	.5935	1.358	1.2597	1.0442	1.3565	1.5581	1.4752
Avg	1.6303	1.7046	1.6568	1.5435	1.6359	1.7399	1.6828

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314024 / 33/11 kv Hiwra ss

Feeder No / Name : 402 / 33 kv Gondia ckt-1

Feeder KV- 33 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	11.1071	14.6754	14.7348	15.0824	15.1715	14.6571	14.6571
2	11.0449	14.0147	14.1919	14.8228	14.6788	14.2347	13.9015
3	10.8364	13.0842	13.7254	14.5473	14.461	14.1266	13.5803
4	10.8913	14.201	12.1698	13.9621	14.1884	14.0226	13.5477
5	11.4401	14.2541	14.3581	15.1121	14.568	13.908	13.8009
6	12.2485	16.3718	15.3538	15.719	15.0383	14.398	14.3953
7	12.8396	15.3841	16.1247	16.1014	14.7119	15.2999	15.93
8	13.1653	15.0772	15.4277	15.771	15.4098	15.1365	16.046
9	13.2209	14.868	15.0994	11.2312	11.4061	14.6879	15.4687
10	13.0032	15.0662	14.8402	11.1214	11.3478	14.3355	14.9511
11	13.3341	15.7162	15.3544	11.9977	15.8414	14.8698	15.598
12	13.1174	16.3786	15.7526	11.9994	16.0116	15.2418	16.286
13	12.693	15.343	15.4285	10.8128	15.8819	14.7145	15.0732
14	12.4207	15.499	15.1745	10.5596	14.8257	14.2936	13.4648
15	10.3338	15.0754	15.335	10.0166	14.2267	14.0818	13.9689
16	10.2291	15.2818	15.7117	10.2852	12.0906	5.9808	14.3941
17	14.4857	15.6282	15.7847	15.2538	14.1847	14.6137	14.4411
18	16.5278	16.8301	16.5477	16.4335	14.6674	15.0864	16.0792
19	17.6681	19.9846	19.7096	20.0949	6.877	19.4422	18.9129
20	19.5057	20.0023	19.5079	19.7022	6.9182	18.6987	18.1631
21	17.843	19.2284	18.2025	18.9861	6.8101	17.7818	17.4669
22	16.845	17.7498	17.5212	18.2037	6.6466	16.7016	16.0311
23	15.8282	16.3226	16.2598	16.7203	6.3723	15.7916	15.1223
24	4.2639	14.8971	14.8268	15.2688	16.2981	15.5761	15.3492
Max	19.5057	20.0023	19.7096	20.0949	16.2981	19.4422	18.9129
Min	4.2639	13.0842	12.1698	10.0166	6.3723	5.9808	13.4648
Avg	13.1205	15.8722	15.7143	14.5752	12.8597	14.9034	15.2762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 317014 / 132 KV GONDIA

Feeder No / Name : 203 / 11 KV Gangazari

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4355	.5461	.5304	.631	.6287	.5693	.5369
2	.434	.5388	.4761	.631	.621	.5468	.5327
3	.4325	.538	.4558	.6535	.6081	.5665	.5125
4	.431	.5353	.4679	.6355	.5912	.5665	.5049
5	.4325	.5461	.4702	.6256	.5943	.5552	.5043
6	.4348	.5517	.4837	.6409	.615	.5853	.5459
7	.4911	.5022	.555	.6821	.6365	.5672	.5756
8	.4869	.4359	.6414	.65	.627	.4752	.5525
9	.4999	.4369	.5933	.6355	.5973	.4488	.5396
10	.4877	.43	.6066	.5891	.5644	.4894	.5472
11	.5091	.5041	.6256	.5203	.5904	.4946	.5506
12	.5137	.6079	.6449	.5674	.6142	.5251	.5619
13	.5123	.5407	.6255	.5659	.6156	.5403	.586
14	.4961	.5369	.5053	.5889	.5666	.5573	.5548
15	.4854	.5323	.449	.579	.5722	.3155	.5761
16	.5217	.5573	.5362	.576	.5843	.4214	.4862
17	.5161	.5604	.5161	.5975	.5866	.4939	.4725
18	.5331	.571	.5818	.5874	.6281	.5451	.5159
19	.6081	.6566	.7194	.6772	.6618	.589	.5982
20	.6416	.6742	.7438	.7275	.7068	.6332	.6241
21	.6401	.6696	.6675	.7121	.6638	.6123	.6233
22	.6148	.6137	.6561	.6723	.6348	.5659	.6066
23	.5811	.6007	.6314	.6424	.6057	.5575	.5825
24	.5125	.5603	.6099	.6161	.6114	.5668	.5644
Max	.6416	.6742	.7438	.7275	.7068	.6332	.6241
Min	.431	.43	.449	.5203	.5644	.3155	.4725
Avg	.5105	.5519	.5747	.6252	.6136	.5328	.5523

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 317014 / 132 KV GONDIA

Feeder No / Name : 205 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.358	1.2826	1.3957	1.4712	1.4901	1.3769	1.4335
2	1.3203	1.3203	1.3769	1.4335	1.4146	1.358	1.1694
3	1.2826	1.1694	1.3203	1.3957	1.4146	1.3392	1.5466
4	1.2637	1.1694	1.2826	1.5089	1.3014	1.3203	1.358
5	1.226	1.1317	1.226	1.1694	1.3014	1.4712	1.4712
6	1.0117	1.2449	1.1883	1.1128	1.5466	1.358	1.4146
7	1.1883	1.3203	1.1317	1.1694	1.6409	1.226	1.2826
8	1.1317	1.2449	1.094	1.2826	1.0562	1.0185	1.1317
9	1.1883	1.1694	1.1317	1.5089	1.4377	1.3203	1.358
10	1.1317	1.6032	1.5089	1.6787	1.6804	1.8484	1.5089
11	1.1317	1.9239	2.037	2.1658	1.6804	2.037	1.8861
12	1.358	2.1313	2.2634	2.2032	2.2405	1.9616	1.9993
13		1.7353	2.1313	1.8671	1.9978		1.8861
14		1.6975	1.773	1.8484	1.9231	1.773	1.6409
15		1.6598	2.2445	2.1125	1.9791	2.1125	1.9993
16		1.7918	2.2822	2.2445	1.8861	1.8673	2.1879
17	1.4146	1.5089	1.8484	2.037	1.8107	1.7353	1.8484
18	1.2826	1.358	1.5466	1.9993	1.6975	1.6975	1.8861
19	1.5089	1.2826	1.2637	1.773	1.4146	1.4712	1.6598
20	1.6598	1.2071	1.3769	1.5844	1.3203	1.4712	1.5844
21	1.5466	1.5813	1.3957	1.3769	1.5844	1.358	1.4901
22	1.5844	1.4289	1.4146	1.5844	1.4335	1.4335	1.3957
23	1.3957	1.3957	1.5278	1.5655	1.3957	1.358	1.5089
24	1.358	1.358	1.3957	1.5089	1.4712	1.3769	1.5089
Max	1.6598	2.1313	2.2822	2.2445	2.2405	2.1125	2.1879
Min	1.0117	1.1317	1.094	1.1128	1.0562	1.0185	1.1317
Avg	1.3171	1.4465	1.5482	1.6501	1.5883	1.5343	1.5899

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 317014 / 132 KV GONDIA

Feeder No / Name : 206 / 11KV Water Works

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.2195	.2427	.2218	.2378	.2686	.2172
2	.2195	.2149	.2427	.2218	.2195	.2658	.2303
3	.2012	.2126	.2427	.2218	.2195	.2454	.2279
4	.2195	.2126	.2402	.2218	.2218	.2454	.2103
5	.2012	.197	.2378	.2218	.2587	.2126	.2126
6	.2012	.2149	.2378	.2033	.2957	.2481	.2126
7	.2195	.2149	.197	.2033	.3326	.2149	.2172
8	.2012	.1629	.2172	.2033	.2012		.181
9	.2012	.181	.2012	.1646	.1829	.2279	.2149
10	.2012	.1991	.1829	.1463	.2012	.2378	.1991
11	.2012	.1991	.1829	.1829	.2012	.2195	.181
12	.2033	.2195	.2012	.1829	.1949	.2561	.2172
13	.2033	.2402	.2012	.1478	.2195	.2561	.2012
14	.2033	.2218	.1829	.1097	.1402	.2172	.2012
15	.1848	.1848	.2012	.181	.1949	.2172	.1829
16	.2033	.2033	.2587	.2353	.2303	.2378	.2218
17	.1848	.2402	.2402	.2378	.2303	.2561	.2172
18	.2218	.2402	.2772	.2218	.2658	.2402	.2172
19	.2987	.2926	.3174	.2957	.3045	.2715	.2743
20	.2801	.2926	.2772	.2772	.3045	.2743	.2587
21	.2614	.2658	.2587	.2561	.2926	.2801	.2587
22	.2402	.2507	.2402	.2534	.2926	.2402	.2587
23	.2218	.2378	.2218	.2587	.2743	.2402	.2507
24	.2195	.2033	.2378	.2033	.2254	.2743	.2195
Max	.2987	.2926	.3174	.2957	.3326	.2801	.2743
Min	.1848	.1629	.1829	.1097	.1402	.2126	.181
Avg	.2172	.2217	.2309	.2114	.2392	.2455	.2201

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 317014 / 132 KV GONDIA

Feeder No / Name : 401 / 33 KV RAWANWADI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	15.4042	13.7243	14.8857	14.6942	14.4319	13.5231	14.1083
2	15.3733	13.0681	14.6091	14.7073	14.4907	13.1368	13.9345
3	15.2435	13.0087	14.1815	14.4159	14.4582	13.1345	1.4975
4	15.1453	13.1014	14.3942	14.2484	14.1518	13.0716	
5	15.0583	13.3842	14.4582	14.385	13.642	13.2625	
6	15.9357	13.6855	14.9635	14.8583	13.1767	13.578	
7	16.1849	13.9964	15.0891	15.1692	13.1224	13.6569	
8	16.4552	13.9455	14.1633	14.1484	13.2133	13.2373	
9	16.2541	13.7037	13.9912	13.7945	13.1481	13.0967	
10	14.7782	14.0998	14.2404	13.8683	13.6717	12.8938	
11	15.2708	13.8203	16.0345	16.0837	14.904	14.4696	4.9646
12	15.8288	15.3749	16.4615	15.8528	14.488	13.1664	5.1012
13	15.7185	14.7142	15.9025	15.4259	14.5405	14.565	4.7051
14	14.5223	14.3112	14.533	15.0041	13.4671	13.4808	9.8942
15	14.417	14.3387	14.373	3.2259	12.6497	13.2488	9.7394
16	15.4801	15.7293	13.3333	15.0618	13.7231	13.7409	6.4815
17	1.406	15.0612	15.3664	15.4584	13.7517	15.0692	14.6319
18	10.4384	15.7539	15.4527	15.1698	13.8072	15.2789	15.3132
19	17.0999	17.5743	16.9902	15.4275	15.4527	16.6187	16.6553
20	16.2272	16.929	16.9605	16.6941	15.1166	15.6035	16.0311
21	15.7237	16.4055	17.0771	16.0838	15.1051	15.4892	16.1615
22	15.1977	16.3191	16.4335	15.7191	14.3656	15.3955	15.8299
23	14.6845	15.6174	15.7682	15.9002	14.2101	14.8995	15.3024
24	15.511	14.2936	15.3201	15.3361	14.8766	13.5448	14.6754
Max	17.0999	17.5743	17.0771	16.6941	15.4527	16.6187	16.6553
Min	1.406	13.0087	13.3333	3.2259	12.6497	12.8938	1.4975
Avg	14.7233	14.6650	15.2076	14.6139	14.0819	14.0484	11.4722

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 317014 / 132 KV GONDIA

Feeder No / Name : 404 / 33 KV GONDIA CKT-II

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	8.0767	9.6634	9.3021	9.4885	9.7365	7.4789	9.7273
2	8.0784	9.3433	9.0895	9.2204	9.5148	7.0502	9.3553
3	7.9184	9.0764	8.9152	9.0684	9.3553	7.0514	9.3896
4	8.075	8.9701	8.642	9.1736	9.6302	7.0616	9.5564
5	8.4876	9.0718	8.7535	9.3461	9.4159	6.9004	9.4433
6	9.0815	9.0226	8.9666	9.5148	9.249	6.9359	9.3553
7	9.1873	8.8621	8.5448	8.7603	8.8209	6.3015	8.7666
8	9.337	8.8529	8.9101	8.3419	8.6643	5.6722	8.5877
9	8.2739	8.5437	7.7452	4.8354	4.8371	4.0713	7.9224
10	8.2887	8.9066	8.546	4.8868	5.2012	7.2359	7.9224
11	8.2871	9.2238	8.6397	4.8868	9.3405	7.9212	8.2379
12	7.0244	9.2742	8.3322	5.1492	5.475	8.2899	7.7109
13	7.6035	9.3279	8.8512	5.2584	8.9186	8.3402	7.5092
14	7.6361	3.7071	7.8561	4.8903	8.8066	7.8224	7.5063
15	4.317	8.3225	7.9584	4.4753	8.6488	8.4979	7.9755
16	4.5748	2.7469	8.2225	4.8354	8.7551	8.7661	8.2836
17	8.394	7.9515	8.8444	8.3402	8.5477	9.2895	8.4997
18	8.6934	8.8981	8.9003	8.4819	8.9643	8.6076	8.5477
19	12.652	11.0139	10.8528	10.1017	10.6842	9.9297	10.4418
20	10.3824	10.9677	10.595	9.7805	10.7002	10.3756	10.3704
21	9.9931	10.5933	11.4975	10.1114	10.4184	10.3789	10.4938
22	10.0909	10.3652	10.3023	9.5376	10.2057	10.3652	10.6841
23	10.0904	9.94	9.768	9.7805	10.0995	10.1412	9.8771
24	8.3454	9.6034	9.4616	9.5451	9.6125	9.94	9.94
Max	12.652	11.0139	11.4975	10.1114	10.7002	10.3789	10.6841
Min	4.317	2.7469	7.7452	4.4753	4.8371	4.0713	7.5063
Avg	8.4537	8.8437	9.0624	7.8254	8.9001	8.1010	9.0043

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 317014 / 132 KV GONDIA

Feeder No / Name : 405 / 33 KV GOREGAON

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8351	8.6838	9.9314	9.3227	8.5574	8.9335	8.9335
2	6.1729	8.2859	9.5439	7.9024	8.7088	8.5871	8.9054
3	6.4472	8.5163	9.3759	8.822	8.2665	8.4751	8.5797
4	6.5037	8.1859	9.1032	8.6008	8.2116	8.6751	14.2158
5	6.6701	8.2968	9.2164	8.4877	8.095	8.3247	14.6525
6	7.1674	8.462	9.3261	9.0432	5.4973	8.6557	15.4956
7	7.5343	8.9574	9.8251	9.2969	8.091	8.5459	15.7997
8	7.2108	8.9574	9.5953	9.2346	8.5911	6.3941	15.1749
9	7.7852	9.1599	8.9712	8.9506	8.6791	8.8186	14.3067
10	8.235	9.3804	9.2426	8.8604	9.2404	8.5689	14.1936
11	9.2673	9.7565	9.7085	9.6577	10.0731	9.1626	16.0214
12	9.4793	10.4041	9.7594	9.6908	9.4685	9.3775	15.8763
13	8.7666	9.9148	9.2701	10.1561	9.6839	9.2592	15.5453
14		8.8231	8.7865	9.8783	9.5141	9.2164	8.8181
15	1.0751	8.7185	9.6319	9.7451	8.7449	8.7243	7.5823
16	1.1317	9.0975	10.2487	7.2451	8.6677	9.058	9.892
17	13.9923	9.2587	10.7407	9.0467	7.8464	8.6569	9.2192
18	9.4999	9.796	10.012	9.8491	9.2558	9.9263	9.6273
19	10.3418	10.4681	11.2878	10.5933	10.1938	10.4578	9.9743
20	9.824	1.6409	11.2518	10.3487	9.8262	9.1358	9.5405
21	9.5479	10.3103	10.535	9.568	8.9552	9.5937	9.5668
22	9.6319	10.2246	10.064	9.7908	8.4591	9.2969	9.4016
23	8.8443	10.0663	9.7382	9.3462	7.3663	9.1295	8.9934
24	.3395	8.5186	9.8491	9.6816	8.9318	9.0998	8.9124
Max	13.9923	10.4681	11.2878	10.5933	10.1938	10.4578	16.0214
Min	.3395	1.6409	8.7865	7.2451	5.4973	6.3941	7.5823
Avg	7.2306	8.9118	9.7923	9.2966	8.7052	8.9197	11.6345

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 317014 / 132 KV GONDIA

Feeder No / Name : 406 / 33 KV GAYATRI AIPL

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.6797	3.8803	2.556	3.1327	3.8786	4.1152	4.481
2	3.7037	3.786	2.6715	3.0333	3.9232	4.1027	4.3004
3	3.9529	3.8146	2.7366	3.1184	3.7294	4.2135	4.2438
4	4.0049	4.0398	3.1687	2.9338	3.9735	4.3799	4.357
5	3.9529	4.0181	3.187	3.2693	3.9735	4.5931	4.425
6	3.9438	4.2353	3.0727	3.3813	3.8289	4.537	4.481
7	3.9438	4.2353	3.0727	3.1327	3.6797	4.3347	4.257
8	3.9866	3.8272	3.1687	3.1459	3.6717	4.1581	4.313
9	4.1993	4.1015	3.187	3.0933	3.6008	4.3244	4.6491
10	4.0929	3.9009	3.0727	2.915	3.9963	4.4353	4.3799
11	3.9758	4.1541	3.558	3.2808	3.4848	4.4353	4.537
12	4.3982	3.8729	3.255	2.9835	3.8912	4.4993	4.4353
13	4.1015	3.4808	3.1944	3.1579	4.1541	4.3799	4.4353
14	4.0929	3.2322	3.1482	3.2007	3.7643	4.3799	4.537
15	3.9095	1.945	3.1579	2.8349	3.9529	4.425	4.1581
16	4.2444	2.0153	3.0607	3.0476	3.7609	4.5931	4.3244
17	4.3519	2.1605	3.1459	3.1687	3.8272	4.6491	4.3244
18	4.0724	1.9433	2.915	3.0681	3.6408	4.4907	4.4907
19	4.137	2.0165	3.2065	3.3425	4.0569	4.537	4.3244
20	4.1267	1.9662	3.0967	3.4088	3.9438	4.5268	4.3347
21	4.0724	2.556	3.1579	3.5048	3.9438	4.4702	4.4353
22	3.786	2.5263	3.0247	3.2819	3.6808	4.6153	4.357
23	3.7334	2.5446	3.0727	3.3522	3.2442	4.269	4.5833
24	3.63	3.9335	2.5446	3.0476	3.5305	4.0238	4.4353
Max	4.3982	4.2353	3.558	3.5048	4.1541	4.6491	4.6491
Min	3.63	1.9433	2.5446	2.8349	3.2442	4.0238	4.1581
Avg	4.0039	3.2578	3.0597	3.1598	3.7972	4.3953	4.4000

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314012 / 33 KV SURYATOLA S/STN

Feeder No / Name : 201 / Town - I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.332	2.3342	2.5675	2.6437	2.6787	2.5181	2.5671
2	2.2939	2.247	2.4166	2.4522	2.5194	2.3865	2.4539
3	2.2283	2.2519	2.3366	2.3601	2.4432	2.3545	2.3506
4	2.2726	2.2767	2.3107	2.3418	2.3762	2.3453	2.3161
5	2.3308	2.3182	2.4547	2.5482	2.361	2.3916	2.307
6	2.3598	2.4022	2.5541	2.6355	2.4486	2.5421	2.399
7	2.4924	2.6507	2.8437	2.7928	2.5156	2.7073	2.7343
8	2.7404	2.7879	2.8299	2.8471	2.6574	2.8014	2.7236
9	2.7374	2.8235	3.037	2.9507	2.6487	2.8191	2.7568
10	2.8677	2.8372	3.0979	2.9811	2.7031	2.9782	3.0001
11	3.368	3.336	3.5663	3.7289	3.127	3.5105	3.4291
12	3.8956	3.9943	4.2652	4.2543	3.4116	3.8692	3.9495
13	3.8933	4.0212	4.3366	4.2352	3.5858	3.9748	3.8877
14	3.7207	3.9624	4.1387	4.1732	3.5025	3.9228	3.8003
15	1.8747	3.7524	4.0302	4.0169	3.1867	4.0577	3.718
16	1.8488	3.9236	4.1501	4.0699	2.9434	4.0104	3.7856
17	3.6627	4.0257	4.0851	4.0882	2.8426	4.0212	3.8386
18	3.9018	4.2684	4.2498	4.2421	2.8071	4.0794	4.0276
19	4.7952	5.0709	5.2749	5.1006	3.2064	4.9536	5.0015
20	4.6838	5.0004	5.143	5.0365	3.1321	4.9002	4.944
21	4.1692	4.4692	4.6093	4.5469	2.9916	4.4552	4.5023
22	3.4018	3.6465	3.7183	3.735	2.9256	3.6877	3.7467
23	2.8824	3.0293	3.0704	3.0932	2.823	3.0536	3.0948
24	2.5438	2.7149	2.736	2.8382	2.7713	2.7826	2.7475
Max	4.7952	5.0709	5.2749	5.1006	3.5858	4.9536	5.0015
Min	1.8488	2.247	2.3107	2.3418	2.361	2.3453	2.307
Avg	3.0540	3.3394	3.4926	3.4880	2.8587	3.3801	3.3367

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314012 / 33 KV SURYATOLA S/STN

Feeder No / Name : 202 / Town - II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4815	1.5154	1.5497	1.5524	1.829	1.6057	1.6804
2	1.4083	1.4969	1.4632	1.5524	1.5708	1.5893	1.5684
3	1.3535	1.4784	1.4784	1.5339	1.5893	1.5708	1.4937
4	1.3535	1.5339	1.5524	1.5339	1.4969	1.5339	1.5339
5	1.4632	1.6078	1.643	1.6263	1.5339	1.6263	1.6632
6	1.6095	1.6448	1.7924	1.8111	1.7551	1.8111	1.7177
7	1.9044	1.922	2.0538	1.9774	1.7364	2.0328	1.8298
8	1.9418	1.9589	2.0351	1.9959	1.8858	1.885	1.9418
9	2.0165	2.0698	2.0351	1.9791	1.7737	1.848	1.8858
10	1.7926	1.9044	1.7556	1.9605	1.7737	1.6095	1.7556
11	1.7558	1.9044	1.848	1.922	1.9605	1.7926	1.922
12	1.701	1.8656	1.885	1.9774	1.885	1.7926	1.8665
13	1.5912	1.848	1.8296	1.848	1.7741	1.6632	1.8111
14	1.5729	1.6632	1.8111	1.7193	1.6632	1.6632	1.5708
15		1.4969	1.7372	1.6278	1.4784	1.5893	1.6263
16		1.6817	1.7558	1.6278	1.4784	1.6817	1.7187
17	1.4815	1.7187	1.7558	1.6278	1.423	1.6461	1.5729
18	1.5893	1.8111	1.8296	1.829	1.6448	1.6278	1.7741
19	2.1622	2.2361	2.3101	2.3045	2.1807	2.2177	2.1992
20	2.1285	2.2032	2.2731	2.1216	2.0513	2.1845	2.0538
21	1.9959	2.0328	2.1807	2.0119	2.0328	2.0538	1.9978
22	1.9035	1.9791	2.0513	1.957	1.9791	1.9404	1.9959
23	1.7926	1.7924	1.8296	1.829	1.8671	1.8111	1.8671
24	1.4998	1.6078	1.6078	1.6632	2.4874	1.7551	1.7187
Max	2.1622	2.2361	2.3101	2.3045	2.4874	2.2177	2.1992
Min	1.3535	1.4784	1.4632	1.5339	1.423	1.5339	1.4937
Avg	1.7045	1.7906	1.8360	1.8162	1.7854	1.7721	1.7819

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314012 / 33 KV SURYATOLA S/STN

Feeder No / Name : 203 / Town - III

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2064	1.181	1.2424	1.2761	1.3098	1.2638	1.3063
2	1.2203	1.1427	1.1706	1.2239	1.2546	1.244	1.1698
3	1.1672	1.1397	1.1671	1.1932	1.2639	1.2394	1.1637
4	1.1733	1.1721	1.1309	1.1993	1.2255	1.2148	1.1919
5	1.1892	1.238	1.1778	1.2684	1.2563	1.2194	1.2486
6	1.4602	1.3283	1.307	1.4065	1.3296	1.3681	1.3496
7	1.5287	1.523	1.5165	1.518	1.3925	1.5061	1.4594
8	1.5206	1.5779	1.5691	1.5348	1.4736	1.469	1.5241
9	1.4794	1.5013	1.5676	.7392	1.3997	1.4245	1.4822
10	1.352	1.3584	1.401	1.3481	1.3601	1.3325	1.3401
11	1.1736	1.3066	1.281	1.2681	1.4339	1.2132	1.2403
12	1.1751	1.2468	1.2224	1.193	1.3662	1.1828	1.1881
13	1.0368	1.1242	1.1172	1.0989	1.2344	1.134	1.0673
14	.9678	.9861	1.0528	1.0425	1.1671	1.0212	.9461
15	.4679	.9358	.9945	.9708	1.017	.9815	.884
16	.4877	1.0079	1.0109	.9861	1.0845	.9465	.9914
17	.9827	1.0723	1.1277	1.0181	1.1014	.9476	.9621
18	1.0734	1.1808	1.1673	1.1751	1.2196	1.1073	1.1305
19	3.7734	1.5439	1.6331	1.605	1.5672	1.5489	1.5356
20	1.6069	1.6346	1.6819	1.6477	1.6391	1.6084	1.5768
21	1.5302	1.6103	1.6345	1.6477	1.5686	1.6088	1.5748
22	1.4659	1.5733	1.6101	1.5577	1.5178	1.5211	1.5195
23	1.3938	1.4376	1.4672	1.4998	1.4413	1.423	1.4446
24	1.2178	1.2851	1.3329	1.3601	1.3549	1.3311	1.3451
Max	3.7734	1.6346	1.6819	1.6477	1.6391	1.6088	1.5768
Min	.4679	.9358	.9945	.7392	1.017	.9465	.884
Avg	1.3188	1.2962	1.3160	1.2824	1.3324	1.2857	1.2767

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314012 / 33 KV SURYATOLA S/STN

Feeder No / Name : 204 / Town - IV

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6291	2.3697	2.838	2.8589	3.2236	2.9531	2.9747
2	2.5057	2.2454	2.7054	2.8658	3.1756	2.8765	2.8799
3	2.4501	2.2534	2.5736	2.8185	2.9998	2.6619	2.8202
4	2.3297	2.2534	2.449	2.6471	2.6757	2.6661	2.7571
5	2.255	2.423	2.4943	2.6913	2.782	2.6345	2.7187
6	2.2088	2.5092	2.6925	2.8906	2.9089	2.8323	2.8471
7	2.3022	2.9031	3.0754	3.0247	2.9931	3.0049	3.0895
8	2.3651	2.9847	3.2591	3.0152	3.0094	3.1733	3.1291
9	2.4534	3.0791	3.2987	2.9523	3.0986	2.9622	3.2305
10	2.3616	3.0488	3.1756	2.9146	3.3277	3.0467	3.1359
11	2.4307	2.785	3.1404	2.9736	3.2555	3.1511	3.0064
12	2.3591	2.7439	3.0304	2.8121	3.2056	3.0232	2.8981
13	2.2726	2.7404	2.9253	2.7519	2.9965	2.8293	2.7183
14	2.1659	2.5617	2.6383	2.6806	2.6528	2.6002	2.6752
15	1.3855	2.6226	2.6741	2.7183	2.7466	2.5736	2.6532
16	1.3443	2.6252	2.7428	2.7732	2.7271	2.6939	2.6947
17	2.047	2.6513	2.7755	2.7823	2.8593	2.7701	2.7542
18	2.213	2.9059	2.8738	2.7792	2.8636	2.8364	2.9199
19	1.4571	3.3071	3.2895	3.4202	3.2312	3.3516	3.4773
20	2.8692	3.4027	3.4034	3.4896	3.3681	3.5604	3.4096
21	2.8841	3.4802	3.4168	3.373	3.1176	3.381	3.2404
22	2.7877	3.3562	3.259	3.3325	3.0536	3.3551	3.1501
23	2.7233	3.3329	3.1981	3.352	3.1157	3.3551	3.194
24	3.2498	3.0022	2.9214	3.2982	3.072	3.2167	3.0647
Max	3.2498	3.4802	3.4168	3.4896	3.3681	3.5604	3.4773
Min	1.3443	2.2454	2.449	2.6471	2.6528	2.5736	2.6532
Avg	2.3354	2.8161	2.9521	2.9673	3.0192	2.9796	2.9766

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314025 / 33/11 kv Parwatigath

Feeder No / Name : 202 / Urban industrial

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1307	.2241	.1509	.1509	.2241	.2241
2		.112	.1867	.1509	.132	.1867	.1867
3		.112	.1494	.132	.112	.168	.168
4		.1307	.168	.1509	.112	.168	.168
5		.0934	.1494	.1509	.0934	.168	.1494
6		.056	.1307	.132	.0934	.1494	.1494
7		.0747	.1307	.132	.0934	.168	.1307
8	.1132	.056	.168	.1698	.168	.1867	.1494
9	.0934	.1886	.1698	.1698	.1494	.2263	.2263
10	.112	.2452	.2075	.2829	.1867	.2641	.2452
11	.112	.2829	.3395	.3584	.3174	.2829	.4338
12	.3547	.3395	.3395	.3772	.3921	.3018	.5658
13	.2801	.3395	.4527	.3961	.3921	.3772	.5093
14		.3206	.3772	.415	.2987	.4338	.4527
15	.2241	.3772	.415	.4527	.2987	.3395	.4715
16	.2054	.415	.4527	.4527	.3921	.4668	.547
17	.2054	.3734	.4715	.547	.2987	.4854	.4715
18	.1867	.3361	.3961	.4527	.3174	.4481	.4338
19	.1307	.2987	.3018	.3395	.2241	.2987	.3772
20	.0934	.2241	.2987	.2641	.2054	.2614	.2263
21	.056	.1867	.1867	.2641	.2241	.2241	.2075
22	.1494	.2241	.1867	.1698	.2241	.2614	.2075
23	.112	.2614	.168	.1509	.2427	.2427	.2263
24	.6859	.0934	.3174	.1698	.1509	.2427	.2054
Max	.6859	.415	.4715	.547	.3921	.4854	.5658
Min	.056	.056	.1307	.132	.0934	.1494	.1307
Avg	.1947	.2197	.2662	.2680	.2196	.2740	.2972

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314025 / 33/11 kv Parwatigath

Feeder No / Name : 203 / Manohar Chowk

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6828	.7827	.7369	.7704	.7659	.7918
2		.6101	.7037	.7059	.7311	.7118	.7281
3		.6398	.679	.6771	.7023	.6615	.6928
4		.5845	.7072	.6725	.6905	.703	2.4905
5		.6398	.7461	.7044	.6889	.7255	2.4844
6		.7045	.8326	.7499	.7483	.7731	2.6475
7		.8554	.8752	.8412	.8254	.849	2.9009
8		.9347	.9355	.9153	.9187	.9587	2.966
9		.9116	.929	.8819	.8882	.9275	2.786
10	.5255	.8284	.8192	.7989	.8272	.829	2.5814
11	.7297	.716	.7659	.8098	.8166	.775	2.5294
12	.6393	.6681	.7433	.7794	.8414	.7341	2.511
13	.6443	.6463	.759	.7189	.7514	.6826	2.3715
14	.3102	.6666	.6939	.7316	.6718	.615	2.0523
15	.7499	.6143	.6338	.723	.6882	.6422	1.9845
16	.6558	.6053	.6452	.6521	.6439	.5784	2.1363
17	.6763	.6294	.6786	.6634	.6268	.735	1.0168
18	.6691	.7098	.6893	.7383	.6664	.7476	.6719
19	.8246	.8722	.8985	.9257	.8432	.9747	.816
20	.8288	.8985	.8958	.9282	.8612	.9308	.8448
21	.8391	.8993	.9107	.9008	.8836	.916	.8229
22	.8482	.8806	.9004	.8811	.9286	.9561	.8613
23	.7956	.876	.862	.9008	.8932	.9057	.9059
24	.3772	.8151	.7952	.8381	.8335	.8379	.8162
Max	.8482	.9347	.9355	.9282	.9286	.9747	2.966
Min	.3102	.5845	.6338	.6521	.6268	.5784	.6719
Avg	.6742	.7454	.7867	.7865	.7809	.7890	1.7254

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314028 / Civiline (Bhimghat)

Feeder No / Name : 201 / Chotta Gondia

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.12	.0581	.0377	.0566	.1253	.1488
2	.0377	.1162	.0377	.0377	.0566	.133	.148
3	.0377	.1086	.0377	.0377	.1115	.1511	.0892
4	.0377	.1253	.0385	.0377	.1473	.148	
5	.0377	.1276	.065	.0377	.1496	.1676	
6	.0377	.1023	.1577	.0566	.1534	.1623	
7	.0377	.0574	.1084	.0377	.0566	.1691	
8	.0377	.0377	.0377	.0566	.0566	.1775	
9	.0377	.0377	.0377	.0377	.1458	.1116	
10	.0189	.0377	.0377	.0377	.0787	.0598	
11	.0189	.0377	.0377	.0377	.0377	.1162	
12	.0189	.0377	.0574	.0438	.0438	.1343	
13	.0189	.0703	.0619	.0552	.0377	.1089	
14	.0189	.0865	.0392	.0377	.0377	.0757	.0566
15	.0189	.0377	.0377	.0377	.0189	.0735	.0566
16	.0227	.0407	.0596	.0189	.0566	.1008	.0574
17	.0053	.0917	.1016	.0377	.128	.1054	.0377
18	.0204	.0955	.113	.0377	.1333	.1423	.1682
19	.1172	.16	.0657	.1476	.1752	.204	.2002
20	.1949	.2054	.1979	.1995	.1737	.1987	.1798
21	.1676	.1412	.1722	.1668	.1442	.1903	.163
22	.1413	.0703	.1519	.1661	.1465	.1676	.1585
23	.1608	.1298	.0377	.1404	.0635	.0635	.1646
24	.1208	.0423	.0566	.0407	.1229	.12	.1646
Max	.1949	.2054	.1979	.1995	.1752	.204	.2002
Min	.0053	.0377	.0377	.0189	.0189	.0598	.0377
Avg	.0585	.0882	.0753	.0659	.0972	.1336	.1281

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314028 / Civiline (Bhimghat)

Feeder No / Name : 202 / Govindpur

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2557	1.3913	1.7214	1.775	1.8093	1.807	1.7541
2	2.1983	1.3531	1.6998	1.7345	1.7168	1.7519	1.716
3	2.1599	1.3032	1.68	1.7038	1.676	1.6826	.8261
4	2.2523	1.3417	1.7069	1.7239	1.6107	1.6802	
5	2.3632	1.3508	1.7206	1.8057	1.5295	1.7948	
6	2.5669	1.4316	1.8131	1.9065	1.4866	1.9497	
7	2.8243	1.6567	1.9075	2.0075	1.581	1.9924	
8	2.7555	1.6749	1.9111	1.8568	1.6467	1.8941	
9	2.5202	1.5495	1.6689	1.6688	1.6071	1.7534	
10	2.017	1.5446	1.5899	1.5794	1.727	1.563	
11	1.6636	1.7722	1.6981	1.6485	1.6879	1.5802	
12	1.6803	1.657	1.8666	1.8686	1.853	1.4995	
13	1.6229	1.6473	1.842	1.7886	1.7692	1.5835	
14	1.4167	1.596	1.4647	1.676	1.5337	1.5508	
15	1.2346	1.5036	1.4413	1.7803	1.3235	1.459	
16	1.4348	1.6124	1.6383	1.652	1.408	1.6472	
17	.6836	1.6752	1.6592	1.6928	1.4731	1.6067	1.6025
18	1.9756	1.7349	1.6922	1.627	1.4415	1.4637	1.7036
19	2.1287	1.9749	2.1127	1.9288	1.8271	2.0279	2.1001
20	1.9776	1.9917	1.9957	1.8633	1.9334	2.0479	1.9404
21	1.7362	1.858	2.0999	1.7894	2.0442	1.9923	1.9479
22	1.7149	1.9589	2.1003	1.8291	2.0856	2.0167	2.0053
23	1.5661	1.9347	1.9858	1.9601	1.9974	1.8993	1.9462
24	1.882	1.6659	1.8067	1.8888	1.8776	1.8522	1.8359
Max	2.8243	1.9917	2.1127	2.0075	2.0856	2.0479	2.1001
Min	.6836	1.3032	1.4413	1.5794	1.3235	1.459	.8261
Avg	1.9430	1.6325	1.7843	1.7815	1.6936	1.754	1.7616

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314028 / Civiline (Bhimghat)

Feeder No / Name : 203 / Vijaynagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8467	.9837	1.0201	.9799	1.0464	.9542	.9781
2	.7819	.9543	.9907	1.0454	.9873	.9161	.9484
3	.7369	.9145	.9172	.9787	.9304	.8795	.4824
4	.7712	.857	.925	.935	.9358	.8383	
5	.7682	.8816	.9113	.9083	.935	.8063	
6	.7994	.8923	.9865	.9205	.9373	.8421	
7	.8147	.8837	.9619	.949	.8939	.8749	
8	.9236	.9314	.9068	.9566	.916	.878	
9	.9434	.9816	.8575	.8444	.8829	.8543	
10	.9175	1.0337	1.0071	.9103	.9939	.9457	
11	1.0562	1.1523	1.3422	1.4954	1.3963	1.243	
12	1.0113	1.1927	1.3523	1.4752	1.4385	1.3054	
13	1.0989	1.2239	1.2494	1.4074	1.3217	1.2346	
14	.9084	1.032	1.1065	1.2683	1.1689	1.2354	.4694
15	.8985	.9924	1.02	1.2849	1.0818	1.1576	1.0546
16	.9724	1.1866	1.3062	1.5442	1.2285	1.2407	1.0898
17	.4915	1.2517	1.4004	1.4112	1.1972	1.3753	1.1338
18	1.0151	1.2546	1.4248	1.3066	1.2491	1.221	1.1044
19	1.1858	1.326	1.36	1.4157	1.329	1.1346	1.126
20	1.3557	1.2597	1.3085	1.3621	1.2018	1.1961	1.2247
21	1.2773	1.1772	1.2216	1.2552	1.1134	1.1618	1.141
22	1.2499	1.1919	1.215	1.213	1.089	1.1382	1.1841
23	1.174	1.1357	1.1242	1.1372	1.0311	1.0728	1.102
24	1.0509	1.1035	1.0548	1.0898	1.0526	.9922	1.0286
Max	1.3557	1.326	1.4248	1.5442	1.4385	1.3753	1.2247
Min	.4915	.857	.8575	.8444	.8829	.8063	.4694
Avg	.9604	1.0748	1.1238	1.1706	1.0982	1.0624	1.0048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GOREGAON S/DN.[810] BU 4810

Substation No/ Name :- 314002 / 33 KV GOREGAON

Feeder No / Name : 201 / 11 KV GOREGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.362	.4024	.3982	.4108	.4024	.3881
2	.3734	.3403	.4251	.3982	.3696	.4207	.3696
3	.3547	.3439	.4251	.3982	.3696	.4207	.3547
4	.3547	.3224	.4481	.3982	.3696	.439	.3511
5	.3547	.3439	.4294	.4163	.3696	.439	.3658
6	.3696	.3582	.4294	.4344	.3921	.439	.3982
7	.3696	.3582	.4066	.3801	.4108	.4207	.3681
8	.3475	.3721	.3881	.362	.3658	.4024	.4024
9	.362	.3582	.3801	.3439	.3658	.362	.3292
10	.3582	.3582	.394	.3761	.3898	.3547	.362
11	.3439	.3856	.4119	.3544	.4075	.3681	.3658
12	.4024	.3898	.4298	.4207	.4075	.4287	.3801
13	.362	.3641	.4344	.3772	.3544	.5121	.4207
14	.3189	.3506	.362	.394	.333	.4207	.3856
15	.333	.3506	.3982	.4075	.3544	.3814	.3544
16	.3189	.394	.4344	.4458	.4031	.4706	.3982
17	.4252	.394	.4163	.4115	.443	.4557	.462
18	.4961	.499	.4525	.4207	.4656	.6135	.4458
19	.5373	.543	.4525	.5544	.543	.6935	.5601
20	.4961	.5544	.543	.5544	.5228	.5028	.5228
21	.4835	.5121	.5068	.5228	.5041	.4557	.5041
22	.4298	.4525	.4706	.4854	.4854	.4207	.4668
23	.394	.4207	.4344	.4298	.4435	.3681	.4294
24	.3734	.3761	.3982	.3982	.4294	.4024	.3506
Max	.5373	.5544	.543	.5544	.543	.6935	.5601
Min	.3189	.3224	.362	.3439	.333	.3547	.3292
Avg	.3888	.3960	.4281	.4201	.4129	.4414	.4057

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GOREGAON S/DN.[810] BU 4810

Substation No/ Name :- 314002 / 33 KV GOREGAON

Feeder No / Name : 202 / 11 KV Mundipar

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9662	5.7793	6.0891	5.2775	5.3793	5.7524	5.7279
2	4.1918	5.6836	6.0642	5.2454	5.3227	5.7026	5.7392
3	4.1614	5.6386	6.079	5.2202	5.256	5.5931	5.7266
4	4.221	5.5978	6.0797	5.2019	5.3193	5.5281	5.7068
5	4.313	5.5335	6.0706	5.1951	5.2747	5.4873	5.679
6	4.7352	5.415	6.0395	5.2522	5.4179	5.4744	5.4184
7	5.0004	5.4927	5.9641	5.2918	4.1472	5.3399	5.4862
8	5.2311	5.6448	6.0184	4.8026	4.88	5.2214	4.7241
9	5.4497	5.74	6.0494	5.1242	5.1017	4.9002	4.8967
10	5.3724	5.7362	5.8833	5.5266	5.3689	4.8028	4.6612
11	5.4754	5.7852	5.8886	5.5484	5.2412	5.2637	4.6388
12	5.5053	5.8009	5.7739	5.397	5.5693	5.3269	4.6951
13	5.519	5.8349	5.7335	5.2884	5.4797	5.0671	5.1581
14	3.0034	5.5679	5.6276	5.3052	5.623	5.3027	5.0709
15		5.2492	5.5888	5.3239	5.6316	5.3934	1.8557
16		5.1417	5.4874	2.8548	5.3483	5.4649	4.6281
17	5.2347	5.6241	6.0189	5.3101	5.5997	5.8792	4.8973
18	5.7362	5.9084	5.9054	5.4464	5.8467	6.0591	4.9032
19	5.9915	6.2917	5.5918	5.4683	6.2666	6.304	5.8406
20	5.8543	6.5333	5.4459	5.7106	6.2613	5.9461	5.9648
21	6.0593	6.4994	5.41	5.82	6.1378	5.9539	5.7926
22	5.953	6.2974	5.3582	5.7781	6.0429	5.9131	5.748
23	5.7994	6.2128	5.3483	5.6592	5.8246	5.9123	5.586
24	3.1032	5.8856	5.8132	5.3796	5.5979	5.7301	5.6554
Max	6.0593	6.5333	6.0891	5.82	6.2666	6.304	5.9648
Min	1.9662	5.1417	5.3483	2.8548	4.1472	4.8028	1.8557
Avg	4.9035	5.7873	5.8054	5.2678	5.4974	5.5549	5.1750

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GOREGAON S/DN.[810] BU 4810

Substation No/ Name :- 314002 / 33 KV GOREGAON

Feeder No / Name : 203 / 11 KV Industrial Milltoli SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.7023	.7468	.7922	.7282	.8145	.4024
2	.8775	.7468	.7392	.7545	.7545	.823	.4525
3	.924	.7468	.7392	.7167	.8002	.8501	.439
4	.8779	.7762	.7468	.7167	.7049	.8413	.4207
5	.823	.7468	.7095	.7545	.6668	.8596	.4163
6	.7947	.7023	.6535	.7922	.6859	.8596	.4024
7	.8316	.8779	.8131	.8299	.7811	.8775	.3881
8	.2987	.9145	.7865	.8962	.8299	.7682	.8596
9	.7762	.8131	.6878	.7655	.7356	.8507	.7133
10	1.0059	.7468	.7865	.6036	.8962	.8688	.9231
11	1.2197	1.0349	.9431	1.086	.9055	1.1403	1.2254
12	1.2197	1.0791	.9431	1.2437	.9694	1.2536	1.1765
13	1.1744	.9593	.9335	1.2127	.9412	1.1104	1.2071
14	1.0631	.9671	.8676	1.0642	.7682	.9877	1.086
15	1.0517	.9593	1.0374	.9877	.7783	.7922	.8688
16	.9991	1.1584	1.2071	.9412	.8596	.7133	1.1041
17	1.2094	1.1157	1.307	.9955	.3326	.6838	1.1706
18	1.1871	1.1643	1.0829	1.0136	.9335	.7133	1.2696
19	1.1393	.8413	1.0269	1.0642	.961	.7316	.8488
20	1.2536	.7947	.9896	.7762	.924	.5853	.8192
21	.788	.695	.9335	.5853	.6154	.3841	.7621
22	.9313	.724	.9997	.6535	.695	.4024	.8488
23	.7059	.7499	.8488	.7865	.6335	.5544	.8215
24		.7133	.7762	.7922	.695	.8048	.439
Max	1.2536	1.1643	1.307	1.2437	.9694	1.2536	1.2696
Min	.2987	.695	.6535	.5853	.3326	.3841	.3881
Avg	.9337	.8637	.8877	.8677	.7748	.8029	.7944

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GOREGAON S/DN.[810] BU 4810

Substation No/ Name :- 314002 / 33 KV GOREGAON

Feeder No / Name : 205 / 11KV Hirdamali

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6201	1.0679	.8859	.9465	.8842	.7975	.9328
2	.6135	1.0745	.8954	.9114	.8764	.7888	.9511
3	.5959	1.0808	.905	.9114	.8764	.7619	.9231
4	.583	1.0566	.9511	.9114	.8495	.788	.9511
5	.6516	1.0745	.9511	.8063	.8402	.8238	.9511
6	.7282	1.0808	.9412	.8063	.8745	.8417	.9694
7	.8682	1.1043	.9511	.8764	.8817	.8505	.905
8	.9114	1.1163	.9593	.8939	.8551	.8682	.7442
9	.8573	1.134	.9015	.7537	.823	.788	.7442
10	.8573	1.0277	.7537	.7265	.779	.7625	.7164
11	.823	1.0056	.7202	.7087	.7545	.7712	.7265
12	.823	.9602	.7059	.7712	.7956	.7127	.7164
13	.8059	.9326	.6516	.7712	.7373	.7461	.7011
14		.9556	.7059	.788	.8288	.78	.6935
15		.9054	.7059	.7712	.8288	.7545	.6001
16		.9259	.7783	.7973	.788	.7545	.6344
17	.8764	.9774	.7964	.7186	.763	.7628	.6344
18	1.0277	1.0288	.7888	.7209	.7888	.9114	.7202
19	1.1393		.8764	.9816	.8987	.9536	.8326
20	1.1871	.9114	1.0166	1.0631	.9221	.9465	.8688
21	1.1999	.9391	.9816	.9816	.9088	.9568	.8417
22	1.1641	.9313	.9816	.9465	.8573	.9568	.7888
23	1.0924	.8859	.964	.8916	.823	.9492	.7373
24	.4287	1.0745	.8954	.9465	.8745	.8238	.9313
Max	1.1999	1.134	1.0166	1.0631	.9221	.9568	.9694
Min	.4287	.8859	.6516	.7087	.7373	.7127	.6001
Avg	.8502	1.0109	.8610	.8501	.8379	.8271	.8006

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GOREGAON S/DN.[810]

BU 4810

Substation No/ Name :- 314002 / 33 KV GOREGAON

Feeder No / Name : 206 / 11 KV Katangi Feeder

SHEDDABLE RURAL

Feeder KV- 11 / INCOMING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9313	1.1283	1.2071	1.2269	1.0974	1.1222	1.1584
2	.8764	1.1584	1.1765	1.1919	1.0631	1.0974	1.1403
3	.8764	1.1283	1.1641	1.1393	1.046	1.0974	1.134
4	.8842	1.1222	1.1584	1.1393	1.0059	1.086	1.1222
5	.9189	1.1283	1.1888	1.1393	1.0631	1.0745	1.1283
6	.9922	1.2048	1.1888	1.1043	1.0631	1.0745	1.1517
7	1.1462	1.2795	1.2851	1.2094	1.0974	1.0517	1.182
8	1.2226	1.2403	1.2437	1.1393	1.0343	1.0924	1.0498
9	1.1616	.9745	.7783	1.1393	1.0802	.9774	.9313
10	.929	1.0208	.9326	1.0277	1.0395	.9602	1.0136
11	1.0517	1.0631	.9602	1.0566	1.0059	.9326	1.0425
12	.9991	1.1022	.9945	.9328	.9282	.9389	1.0317
13	1.0341	1.1568	1.046	1.0164	.9614	.9496	1.0059
14		1.0852	.9774	1.0903	.8848	.9665	.9745
15		1.0562	1.0402	.8682	.8987	.9774	.9745
16		1.0117	1.1041	.985	.9665	.9431	.9362
17	.9745	1.0288	1.0749	1.0099	.9536		1.0562
18	1.2178	1.1443	.964	1.0059	1.0166	1.2269	1.0117
19	1.448	1.262	1.3146	1.3643	1.2689	1.3847	1.3432
20	1.3466	1.382	1.4373	1.3969	1.2548	1.2269	1.3575
21	1.2715	1.3253	1.3321	1.2971	1.2174	1.2226	1.3032
22	1.1999	1.2308	1.3321	1.2094	1.1999	1.1641	1.2403
23	1.1871	1.2437	1.2445	1.166	1.1584	1.1584	1.1568
24		1.1641	1.2127	1.2269	1.1096	1.1523	1.1283
Max	1.448	1.382	1.4373	1.3969	1.2689	1.3847	1.3575
Min	.8764	.9745	.7783	.8682	.8848	.9326	.9313
Avg	1.0835	1.1517	1.1399	1.1284	1.0589	1.0816	1.1073

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GOREGAON S/DN.[810] BU 4810

Substation No/ Name :- 314009 / 33KV TEDHA

Feeder No / Name : 201 / 11KV Tedha
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8947	1.749	1.9919	1.7814	1.917	1.5384	2.0405
2	1.9109	1.749	2.0081	1.8138	1.8785	1.5546	2.0567
3	1.8947	1.7814	1.9433	1.7976	1.8785	1.5546	2.0729
4	1.8947	1.7652	1.9595	1.7814	1.8785	1.5384	2.0405
5	1.9109	1.7814	1.9433	1.8023	1.8623	1.5384	2.0405
6	1.9433	1.8299	1.9595	1.7814	1.9109	1.5546	1.9433
7	1.9757	1.9757	1.9109	1.6194	1.9109	1.668	2.0891
8	1.9595	1.9109	1.9595	1.9662	1.8623	1.6518	2.0405
9	1.7004	1.7328	2.0405	1.9662	1.749	1.668	1.9919
10	1.749	1.9109	1.5546	1.7368	1.9109	1.7328	1.8299
11	1.9109	1.8299	1.7652	1.9334	1.8947	1.8785	1.9433
12	1.9109	1.4575	1.7695	1.9334	1.9757	1.8138	1.8299
13	1.8785	1.749	1.8515	1.4746	1.8461	1.8785	1.9757
14	1.4575	1.8138	1.873	1.6712	1.9271	1.9595	1.668
15	1.6842	1.5546	1.6712	1.8187	1.749	1.8785	1.4251
16	1.7976	1.7976	1.917	1.4746	1.8461	1.9433	1.7166
17	1.7004	1.6842	1.6518	1.9006	1.9757	1.9433	1.6194
18	1.9109	1.7166	1.6032	1.9006	1.7976	1.9595	1.5384
19	2.1285	1.7976	1.6032	2.0481	1.9109	2.2348	1.9433
20	2.0005	1.8785	1.9919	1.7695	1.9433	2.1052	1.9595
21	1.9845	1.9919	1.9989	1.9559	1.6518	2.2024	1.9433
22	1.6804	1.9271	1.8623	1.873	1.2308	2.1376	1.8138
23	1.7284	2.0405	1.8842	1.9227	1.5546	2.1052	1.8299
24	1.8947	1.7652	1.9919	1.7859	1.9393	1.5384	2.0567
Max	2.1285	2.0405	2.0405	2.0481	1.9757	2.2348	2.0891
Min	1.4575	1.4575	1.5546	1.4746	1.2308	1.5384	1.4251
Avg	1.8542	1.7996	1.8627	1.8129	1.8334	1.8158	1.8920

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GOREGAON S/DN.[810] BU 4810

Substation No/ Name :- 314009 / 33KV TEDHA

Feeder No / Name : 202 / 11KV Chopra

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3717	1.286	1.3203	1.286	1.3375	1.1317
2	.7716	1.3546	1.2689	1.3032	1.2689	1.3203	1.1317
3	1.0288	1.3546	1.2517	1.286	1.2517	1.3203	1.1317
4	1.0631	1.3375	1.2689	1.286	1.2517	1.3032	1.1145
5	1.0802	1.3717	1.286	1.286	1.2517	1.286	1.1317
6	1.166	1.3603	1.3203	1.3032	1.2689	1.3203	1.1831
7	1.3717	1.406	1.4232	1.2346		1.3375	1.2689
8	1.4918	1.4232	1.4232	1.286	1.2689	1.3375	1.2689
9	1.4575	1.3889	1.3546	1.2003	1.3032	1.3203	1.2003
10	1.4575	1.3889	1.3375	1.2003	1.3032	1.2689	1.2517
11	1.3889	1.3375	1.2174	1.1488	1.3032	1.286	1.2517
12	1.406	1.2003	1.3032	1.1145	1.3375	1.2689	1.2517
13	1.4232	.463	1.1831	1.0974	.2058	1.2689	1.2174
14	1.4232	.4287	1.2517	1.0802	.2229	1.2003	1.1317
15	1.3203	1.1317	1.3032	.2401	.2229	1.2174	1.1145
16	1.3546	1.2003	1.3375	1.0974	1.2003	1.2003	1.166
17	1.3375	1.2517	1.166	1.1831	1.3203	1.2689	1.0631
18	1.3375	1.3203	1.4575	1.1488	1.3375	1.286	1.166
19	1.4746	1.3203	1.4575	1.3889	1.4575	1.3717	1.3546
20	1.5089	1.4575	1.4918	1.4575	1.4403	1.406	1.4232
21	1.4918	1.4403	1.3717	1.3889	1.4232		1.3717
22	1.3889	1.3889	1.3546	1.3546	1.3717	1.1831	1.3375
23	1.3889	1.3203	1.3203	1.3203	1.3375	1.1831	1.286
24	1.1831	1.286	1.286	1.3032	1.3032	1.3203	1.1488
Max	1.5089	1.4575	1.4918	1.4575	1.4575	1.406	1.4232
Min	.7716	.4287	1.166	.2401	.2058	1.1831	1.0631
Avg	1.3181	1.2627	1.3217	1.2096	1.1712	1.2875	1.2124

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIORORA S/DN.[392]

BU 0392

Substation No/ Name :- 314007 / 33KV DHAPEWADA

Feeder No / Name : 201 / 11KV Dhapewada

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.17	1.6766	1.9662	1.8679	1.989	1.9559	1.9334
2	2.1538	1.6766	1.9498	1.8515	1.989	1.9559	1.9334
3	2.1376	1.6575	1.9498	1.8351	1.9662	1.917	1.917
4	2.0567	1.6575	1.9334	1.8351	1.9498	1.917	1.9006
5	2.0891	1.6385	1.9334	1.8515	1.9498	1.9006	1.989
6	2.13	1.6385	1.8023	1.7859	1.9725	1.8842	1.9559
7	2.1214	1.5546	1.8023	1.8187	1.7404	1.8515	1.9006
8	2.1376	1.5844	1.749	1.8138	1.587	1.8351	1.8842
9	2.2447	1.3763	1.6356	1.8138	1.704	1.8351	3.8119
10	.9686	1.5729	1.3763	1.8351	1.6575	1.6484	3.9457
11	2.4034	1.6907	1.8023	1.8896	1.8399	1.6484	4.0253
12	2.8166	1.8067	1.7736			1.6324	3.9338
13	2.8837	1.7695	1.9559	1.6057	1.3094	1.668	3.8927
14	2.8166	1.8067	1.7859	1.6575	1.7204	1.5524	3.9537
15		1.7901	.7811	1.6876	1.7072	1.7652	4.1259
16		1.5402	.7186	1.7238	1.6876	1.8461	1.704
17		1.704	1.8515	1.7695	1.8351	1.8138	3.7243
18	1.4403	1.7814	1.8623	1.7328	1.9334	1.7604	4.2295
19	1.9376	2.1534	2.0687	2.079	2.146	2.1704	4.5786
20	1.8482	2.2043	2.1704	2.1195	2.146	2.2043	4.6361
21	1.7804	2.1628	2.1125	2.0957	2.1125	2.0454	4.5207
22	1.6712	2.0388	1.9725	2.0957	2.0056	2.0553	4.5648
23	1.6385	1.989	1.9006	1.989	1.917	1.9662	4.3972
24	2.1376	1.6766	1.989	1.8842	1.989	1.9559	4.2587
Max	2.8837	2.2043	2.1704	2.1195	2.146	2.2043	4.6361
Min	.9686	1.3763	.7186	1.6057	1.3094	1.5524	1.704
Avg	2.0754	1.7562	1.7851	1.8538	1.8632	1.8660	3.3215

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314007 / 33KV DHAPEWADA

Feeder No / Name : 203 / 11kv MIDC jackwell water NON SHEDDABLE WATER SUPPLY AND
works Feeder KV- 11 / OUTGOING UTILITY

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0537	.0537	.0532	.0543	.0543	.0537	.0549
2	.0537	.0537	.0532	.0537	.0543	.0532	.0543
3	.0537	.0537	.0532	.0537	.0537	.0532	.0543
4	.0537	.0537	.0532	.0537	.0537	.0532	.0532
5	.0543	.0537	.0532	.0532	.0532	.0532	.0537
6	.0526	.0537	.0532	.0829	.0532	.0838	.0537
7	.0532	.0574	.0537	.1333	.1191	.1345	.1336
8	.0537	.0532	.056	.133	.1347	.1347	.1351
9	.0537	.0537	.1208	.1333	.1347	.1356	.134
10	.0537	.0554	.1349	.1345	.1359	.1333	.1349
11	.0554	.056	.1366	.1349	.1375	.1337	.137
12	.0897	.0554	.1368	.1349	.137	.134	.1347
13	.1352	.0867	.1375	.1355	.139	.134	.1336
14	.1349	.1362	.1356	.1352	.1356	.133	.1317
15	.1333	.137	.1352	.1341	.1352	.1322	.1333
16	.1332	.0438	.1352	.1362	.1352	.1318	.1352
17	.1326	.0554	.1359	.1359	.1046	.1029	.1044
18	.1029	.0001	.1341	.133	.0543	.0549	.0543
19	.0554	.0019	.1052	.1337	.0543	.0549	.0537
20	.0543	.0549	.0778	.1046	.0543	.0543	.0543
21	.0543	.0543	.0549	.0543	.0549	.0543	.0543
22	.0537	.0543	.0543	.0543	.0537	.0543	.0543
23	.0537	.0543	.0543	.0543	.0532	.0537	.0537
24	.0537	.0537	.0549	.0543	.0543	.0537	.0549
Max	.1352	.137	.1375	.1362	.139	.1356	.137
Min	.0526	.0001	.0532	.0532	.0532	.0532	.0532
Avg	.0741	.0577	.0905	.1009	.0896	.0904	.0896

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314007 / 33KV DHAPEWADA

Feeder No / Name : 204 / 11 KV AGP Dhapewada
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.1109	.1097	.1097	.1086	1.0722	2.3838
2	.0549	.1097	.1097	.1086	.0905	1.0562	1.0911
3	.0543	.1097	.1097	.1086	.0895	1.0722	1.0911
4	.0543	.1109	.1097	.1086	.0895	1.0562	1.0911
5	.0549	.1109	.1097	.1086	.0886	.9488	1.0911
6	.0549	.1109	.1097	.1097	.0905	.9602	1.1363
7	.0739	.1097	.1109	.0914	.1097	.9442	1.0753
8	.0366	.1097	.0191	.0924	.0924	1.1363	1.0883
9	.0549	.1097	.1086	.0914	.0924	1.2308	1.1702
10	.096	1.085	1.1822	1.1984	1.1961	.1109	1.2308
11	.2056	1.1822	1.2944	1.2146	1.3108	.0914	1.2308
12	.2056	1.3435	1.3599	1.2146	1.3108	.0924	.0924
13	.1898	1.2308	1.3763	1.1498	1.3599	.0924	.0914
14	.2031	1.3272	1.2955	1.2289	1.2308	.0924	.0914
15		1.1683	1.1984	1.2146	1.3435	.0924	.0914
16		1.3763	1.1797	1.3272	1.1984	.0924	.0934
17		1.1498	.9762	1.3435	1.0364	.0924	.0924
18	.4843	.0905	.0914	.0724	.0905	.0924	.1109
19	.8482	.1109	.1097	.1109	.1294	.1307	.1109
20	.8749	.1109	.1097	.1109	.128	.1097	.1097
21	.8592	.1294	.1097	.1097	.128	.1109	.1097
22	.0937	.1097	.1097	.1097	.1097	.1097	.1086
23	.1109	.1097	.1086	.1086	.1097	.1097	.1109
24	.0543	.1109	.1097	.1097	.1086	.1097	1.0883
Max	.8749	1.3763	1.3763	1.3435	1.3599	1.2308	2.3838
Min	.0366	.0905	.0191	.0724	.0886	.0914	.0914
Avg	.2247	.4845	.4795	.4814	.4851	.4586	.6659

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314013 / 33KV TIRORA S/STN

Feeder No / Name : 201 / 11KV Tirora-U-

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3169	1.3756	1.4842	1.4661	1.5154	1.4118	1.3575
2	1.2986	1.3756	1.448	1.448	1.4784	1.3756	1.3394
3	1.2803	1.3756	1.448	1.448	1.4266	1.3394	1.3213
4	1.262	1.3575	1.4299	1.3937	1.386	1.3394	1.3032
5	1.2437	1.3394	1.4299	1.4118	1.39	1.3213	1.2851
6	1.2071	1.3394	1.4118	1.4118	1.386	1.3213	1.2851
7	1.1888	1.3575	1.3032	1.3394	1.267	1.3032	1.3032
8	1.1584	1.2851	1.2851	1.2851	1.2127	1.267	1.2308
9	1.1765	1.2308	1.2308	1.1706	1.1403	1.1946	1.0791
10	1.1946	1.1946	1.1765	1.2254	1.2127	1.1041	1.1273
11	1.2308	1.2851	1.2308	1.2986	1.1946	1.1403	1.1827
12	1.2489	1.4118	1.3394	1.2936	1.3213	1.267	1.2437
13	.0362	1.3756	1.3394	1.2936	1.2851	1.3394	1.1888
14	1.3213	1.3213	1.3575	1.3121	1.2489	1.1222	1.1523
15	1.3937	1.2127	1.3394	1.3491	1.2127	1.267	1.1157
16	1.448	1.3213	1.3394	1.2071	1.267	1.3032	.9694
17	1.3032	1.3394	1.2851	1.2437	1.1584	1.3394	1.1523
18	1.2851	1.4661	1.4842	1.4415	1.3032	1.4661	1.3491
19	1.9547	1.9728	1.9185	1.9605	1.8099	1.9185	1.8111
20	1.9185	1.8823	1.8823	1.9044	1.7918	1.8099	1.8111
21	1.7194	1.8461	1.7556	1.9044	1.7013	1.7556	1.6632
22	1.6651	1.7194	1.7013	1.7187	1.6289	1.5927	1.6078
23	1.5203	1.6289	1.5565	1.6263	1.5384	1.5023	1.4815
24	1.3535	1.4118	1.5203	1.3889	1.5339	1.4118	1.3756
Max	1.9547	1.9728	1.9185	1.9605	1.8099	1.9185	1.8111
Min	.0362	1.1946	1.1765	1.1706	1.1403	1.1041	.9694
Avg	1.3219	1.4344	1.4457	1.4393	1.3921	1.3839	1.3223

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314013 / 33KV TIRORA S/STN

Feeder No / Name : 202 / 11KV Mangezari

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4755	.4887	.6335	.6335	.7023	.5792	.5792
2	.4572	.4706	.6154	.6335	.695	.5792	.5792
3	.439	.4706	.6154	.6335	.6767	.543	.5611
4	.4755	.4706	.6154	.5973	.6584	.543	.5792
5	.5121	.5068	.6154	.6516	.6767	.5792	.5792
6	.5487	.5792	.6335	.724	.7023	.6335	.5792
7	.4572	.5973	.5611	.6335	.6335	.5611	.5792
8	.5792	.5792	.543	.6219	.6335	.5611	.543
9	.5792	.5792		.5853	.6335	.5068	.5304
10	.543	.5249	.1448	.4572	.6335	.4525	.4938
11	.543	.5792	.1448	.5729	.6154	.4887	.439
12	.543	.543	.5249	.5914	.6154	.4706	.4572
13	.4706	.5611	.6516	.6099	.6135	.5249	.4938
14	.4887	.4525	.6154	.4938	.5792	.5249	.4938
15	.4887	.5611	.6154	.5729	.5792	.543	.5304
16	.5249	.5792	.5792	.6468	.5068	.5611	.5121
17	.5792	.5973	.6335	.6653	.4887	.5611	.5304
18	.5792	.6335	.6335	.6468	.5249	.5973	.5729
19	.7602	.8326	.8145	.8775	.7421	.7964	.8131
20	.8145	.8688	.8145	.8775	.7602	.7964	.8131
21	.6878	.8326	.8145	.8589	.7164	.7421	.7577
22	.5973	.724	.724	.8131	.6878	.6697	.6838
23	.543	.6516	.6697	.7392	.6516	.6154	.6219
24	.4755	.5249	.6335	.6335	.7023	.6154	.5973
Max	.8145	.8688	.8145	.8775	.7602	.7964	.8131
Min	.439	.4525	.1448	.4572	.4887	.4525	.439
Avg	.5484	.5920	.6020	.6571	.6429	.5852	.58

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314013 / 33KV TIRORA S/STN

Feeder No / Name : 203 / 11KV Mandvi

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8848	1.0491	1.0329	1.084	1.0525	1.0645	1.1208
2	.8471	1.0438	1.0138	1.0465	1.0246	1.0658	1.1193
3	.8097	1.0153	1.0136	1.0456	1.005	1.0477	1.1005
4	.8273	.9881	.9952	.9712	.9669	1.0465	1.0995
5	.8436	.9889	1.014	.9895	.9859	1.0252	1.1211
6	.8666	.9942	1.0577	.9982	.9969	1.0428	1.1225
7	.964	1.0497	1.0221	1.0318	.8976	1.023	1.0332
8	.8216	1.0106	.9993	.97	.9214	.9856	.9924
9	.7813	.9952	.9522	.9918	.9668	.7251	1.0373
10	.8398	.6854	1.0585	1.0705	1.0082	.8672	1.1022
11	.9081	.8544	1.0456	1.1026	1.0404	.9548	1.0565
12	1.0146	.9827	1.1085	1.0668	1.0074	1.0086	1.0619
13	.9466	1.0034	1.0349	1.0285	1.046	1.0286	.9742
14	1.0065	.9807	1.0183	1.0688	.1026	1.0284	.8576
15	1.0079	.9081	.9595	1.0114	.9928	.9735	.9046
16	.9576	.8184	.918	.9285	1.017	.7765	.9037
17	.8513	.8437	.8776	.7825	1.0387	.8595	.9124
18	.9341	1.0298	1.019	.9383	1.1071	.8422	1.0585
19	1.2048	1.2181	1.0315	1.1319	1.2237	1.1186	1.2139
20	1.1522	1.1131	1.1293	1.1594	1.1374	1.1444	1.1282
21	1.1533	1.0692	1.0376	1.1737	1.1402	1.1598	1.1673
22	1.1564	1.1171	1.0373	1.0686	1.1886	1.2096	1.1998
23	1.1124	1.078	1.0271	1.1002	1.1292	1.1443	1.1583
24	1.6007	1.0706	1.0758	1.0805	1.1067	1.1038	1.1474
Max	1.6007	1.2181	1.1293	1.1737	1.2237	1.2096	1.2139
Min	.7813	.6854	.8776	.7825	.1026	.7251	.8576
Avg	.9788	.9962	1.0200	1.0350	1.0043	1.0103	1.0664

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314013 / 33KV TIRORA S/STN

Feeder No / Name : 204 / 11KV Paldongri

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.128	.1448	.1448	.1448	.1478	.1448	.1448
2	.1097	.1448	.1448	.1448	.1478	.1267	.1267
3	.0914	.1267	.1448	.1448	.128	.1086	.1267
4	.0914	.1267	.1267	.1267	.1478	.1086	.1267
5	.1097	.1267	.1267	.1267	.1478	.1086	.1267
6	.1097	.1267	.1267	.1267	.1294	.1267	.1267
7	.0914	.1086	.1086	.0905	.1086	.1086	.0724
8	.0724	.0905	.0724	.0905	.0905	.0905	.0724
9	.0724	.0905	.0905	.0732	.0905	.0905	.0732
10	.0724	.0724	.0724	.0732	.0724	.0905	.0549
11	.0724	.0543	.0724	.0732	.0724	.0724	.0732
12	.0543	.0724	.0724	.0732	.0905	.0543	.0732
13	.0724	.0724	.0724	.0732	.0905	.0724	.0914
14	.0724	.0724	.0724	.0732	.0724	.0724	.0732
15	.0724	.0724	.0724	.0732	.0724	.0724	.0732
16	.0724	.0724	.0724	.0732	.0724	.0724	.0732
17	.0724	.0724	.0724	.0732	.0543	.0724	.0732
18	.0905	.1086	.0905	.1109	.0905	.0905	.0924
19	.181	.181	.181	.1867	.181	.1629	.1848
20	.181	.181	.181	.2054	.181	.181	.1848
21	.181	.181	.181	.2054	.181	.181	.1848
22	.1629	.1629	.1629	.1848	.181	.1629	.1663
23	.1448	.1448	.1448	.1663	.1629	.1448	.1646
24	.128	.1448	.1448	.1448	.1478	.1448	.1448
Max	.181	.181	.181	.2054	.181	.181	.1848
Min	.0543	.0543	.0724	.0732	.0543	.0543	.0549
Avg	.1044	.1146	.1146	.1191	.1192	.1109	.1127

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314013 / 33KV TIRORA S/STN

Feeder No / Name : 205 / 11 kv mandvi AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / INCOMING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.0181
2						.0181
3						.0181
4						.0181
5						.0181
6						.0181
7						.0181
8						.0181
9						.0187
10	.0181	.0181	.0181	.0187	.0181	.0187
11	.0181	.0181	.0181	.0187	.0181	.0187
12	.0181	.0181	.0019	.0187	.0181	
13	.0181	.0362	.0181	.0187	.0181	
14	.0181	.0362	.0181	.0187	.0181	
15	.0181	.0362	.0181	.0187	.0181	
16	.0181	.0362	.0181	.0187	.0181	
17	.0181	.0181	.0181	.0187	.0181	
20			.0181			
24						.0181
Max	.0181	.0362	.0181	.0187	.0181	.0187
Min	.0181	.0181	.0019	.0187	.0181	.0181
Avg	.0181	.0272	.0163	.0187	.0181	.0183

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIORORA S/DN.[392]

BU 0392

Substation No/ Name :- 314020 / 33KV EKODI SUBSTATION

Feeder No / Name : 201 / 11KV DAWNIWADA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.439	.5228	.6219	.6036	.5853	.5788	.5487
2	.439	.4784	.6219	.5731	.567	.5487	.5487
3	.439	.5041	.6219	.5731	.5487	.5487	.5487
4	.4525	.5601	.6219	.5914	.5487	.5194	.5487
5	.4572	.5601	.6219	.5731	.567	.5487	.5487
6	.4755	.567	.6584	.5658	.6219	.567	.5658
7	.5249	.567	.567	.6099	.6401	.567	.5658
8	.5068	.4294	.567	.5729	.6219	.5853	.583
9	.4525	.4207	.4973	.5487	.567	.5788	
10	.4938	.5304	.4973	.4805	.5853	.6219	.567
11	.5415	.6161	.6219	.5304	.6401	.5658	.5487
12	.5304	.5788	.3841	.5304	.6584	.5316	.543
13	.5304	.547	.4115	.5249	.5853	.5487	.5304
14	.5601	.6161	.5658	.499	.5853	.4801	.543
15	.0168	.6224	.5658	.4938	.6036	.5144	.5973
16	.5601	.6535	.6001	.5487	.5487	.5658	.5792
17	.5788	.6908	.583	.4572	.5304	.5316	.5853
18	.5975	.6908	.5658	.567	.6036	.5658	.5853
19	.7282	.7733	.6859	.6283	.695	.6173	.724
20	.7282	.7499	.6859	.6838	.6767	.6516	.695
21		.7316	.6516	.695	.6767	.6516	.6767
22	.6219	.6767	.6001	.7095	.6722	.6173	.6401
23	.5975	.6767	.583	.6219	.6036	.583	.6401
24	.4572	.5601	.6584	.5658	.6161	.5975	.6036
Max	.7282	.7733	.6859	.7095	.695	.6516	.724
Min	.0168	.4207	.3841	.4572	.5304	.4801	.5304
Avg	.5099	.5968	.5858	.5728	.6062	.5703	.5877

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314020 / 33KV EKODI SUBSTATION

Feeder No / Name : 202 / 11KV DONGARGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7865	.8962	1.0059	1.0974	1.0829	1.1157	.8916
2	.7783	.8596	1.0059	1.1203	1.0456	1.0829	.8916
3	.7783	.8775		1.1016	1.0242	1.0534	.8916
4	.7964	.9149	1.0059	1.1016	1.0269	1.0136	.8916
5	.823	.9335	1.0242	1.0791	1.0456	1.0425	.8573
6	.8507	.9896	1.0242	1.0791	.9335	1.0642	.8745
7	.9896	1.1203	.9511	1.0608	.9511	1.0425	.9259
8	.8779	1.1016	.9328	1.0425	.9149	1.0642	.9602
9	1.0608	1.1888	.9259	1.0642	.9709	.9774	.9694
10	1.0791	1.1157	.8916	1.0456	1.0425	1.0608	1.0059
11	1.0642	1.2136	1.0791	1.0317	1.0425	.9945	1.0425
12	1.0829	1.1763	1.0791	1.0456	1.0974	1.0117	1.0791
13	1.1203	1.1506	1.0117	1.0317	1.0791	.9774	1.0242
14	1.0642	1.1016	.9431	.9774	1.0974	.823	1.0242
15	.9896	1.094	.6344	.9896	1.1157	.8573	.9877
16	1.1203	1.1203	.6173	.9795	1.0242	.9602	1.0791
17	1.1203	1.1203	.9602	1.0164	1.134	.823	1.0242
18	1.1576	1.0829	.2572	1.0317	1.1016	.9602	1.1041
19	1.3443	1.3203	1.286	1.2752	1.3169	.8745	1.2986
20	1.251	1.2254	1.2174	1.2382	1.2851	1.0117	1.262
21		1.1888	1.1831	1.1946	1.2883	1.046	1.1765
22	1.1203	1.1523	1.1317	1.2012	1.2696	.9945	1.1523
23	.9088	1.0608	1.0802	1.1763	1.1523	.9431	1.0974
24	.8048	.9335	1.0317	1.0288	1.1203	1.1104	.9259
Max	1.3443	1.3203	1.286	1.2752	1.3169	1.1157	1.2986
Min	.7783	.8596	.2572	.9774	.9149	.823	.8573
Avg	.9987	1.0808	.9687	1.0838	1.0901	.9960	1.0182

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314020 / 33KV EKODI SUBSTATION

Feeder No / Name : 203 / 11KV KACHEWANI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2614	.2743	.3292	.3077	.2987	.2743
2	.2561	.2427	.2561	.3361	.2987	.2926	.2743
3	.2378	.2195	.2561	.3174	.2801	.2926	.2743
4	.2561	.2195	.2561	.3174	.2743	.2378	.2743
5	.2534	.2614	.2561	.3174	.2987	.2378	.2743
6	.2534	.2353	.2743	.3174	.3109	.2715	.2572
7	.2353	.2241	.2378	.2743	.2012	.2534	.2401
8	.2353	.2054	.2195	.2614	.168	.2534	.2229
9	.2195	.2054	.2058	.2614	.2241	.2427	.2195
10	.2378	.2427	.2572	.2743	.2195	.2561	.2378
11	.2241	.2054	.2561	.2743	.2378	.1715	.2561
12	.2241	.2427	.2743	.2561	.2614	.1715	.2896
13	.3109	.2829	.2572	.3109	.2561	.1715	.2561
14	.2987	.2241	.2743	.2715	.2561	.1715	.2353
15	.2614	.2641	.2572	.2378	.2561	.1715	.2534
16	.2801	.2427	.2572	.2378	.2378	.1543	.2534
17	.2427	.2801	.2743	.2987	.2378	.2229	.2353
18	.2801	.2801	.2572	.3109	.2378	.2401	.2378
19	.3547	.3395	.3429	.3439	.3361	.3258	.3292
20	.3547	.3109	.3429	.3734	.3258	.3258	.3292
21		.3109	.3429	.3547	.3174	.3086	.3292
22	.2896		.3258	.3547	.3174	.3086	.3109
23	.2987	.3109	.3258	.3547	.3174	.2915	.3109
24	.2743	.2801	.2926	.3086	.3292	.3174	.2743
Max	.3547	.3395	.3429	.3734	.3361	.3258	.3292
Min	.2195	.2054	.2058	.2378	.168	.1543	.2195
Avg	.2675	.2562	.2739	.3039	.2711	.2495	.2687

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314023 / 33 KV Birsi (Satona)

Feeder No / Name : 201 / 11 KV Sukadi (Dak)

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.086	1.2003	.9149	1.4175	1.4575	1.5203	1.3253
2	1.0317	1.2003	.9335	1.382	1.4403	1.5384	1.3443
3	.9955	1.166	.9335	1.3643	1.4575	1.5023	1.3203
4	1.1222	1.1145	.9522	1.3289	1.4232	1.5384	1.3203
5	1.2357	1.2003	.9522	1.382	1.4403	1.5023	.415
6	1.3253	1.3717	.9896	1.4883	1.4403	1.5203	.4481
7	1.2894	1.2517	.8962	1.3998	1.3032	1.3937	.3961
8	1.1999	1.2174	.5975	1.2934	1.3203	1.2489	.3361
9	.8402	1.0631	.5415	1.2934	1.286	1.166	
10	.8573	1.2637	.4481	1.2757	1.3032	1.2308	1.1576
11	.7888	1.2637	.4163	1.1163	1.2689	1.1946	1.2136
12	.9431	1.1203	.3224		1.2346	1.2127	1.1763
13	1.1488	1.251	1.0498	.5258	1.2517	1.1765	1.2637
14	1.2003	.2427	1.182	.5258	1.2517	1.1222	1.0751
15	1.1831	.5415	1.1871	1.0099	1.3032	1.086	.9808
16	1.1831	.5228	1.182	1.3496	1.2689	1.1946	1.1317
17	1.1488	.1494	1.3937	1.4706	1.3203	1.2178	1.226
18	1.2346	.5975	1.448	1.4352	1.3546	1.3032	1.4146
19	1.8004	.7545	1.9521	1.9667	1.8347	1.8267	1.8484
20	1.7833	.8048	1.9728		1.8176	1.8267	1.8107
21	1.6289	.8299	1.9004		1.6975	1.7013	1.7918
22	1.3889	1.0456	1.6655		1.5775	1.5043	1.6032
23	1.286	.9431	1.5384		1.5565	1.379	1.5089
24	1.1104	1.2346	.9054	1.4864	1.4575	1.5023	1.3611
Max	1.8004	1.3717	1.9728	1.9667	1.8347	1.8267	1.8484
Min	.7888	.1494	.3224	.5258	1.2346	1.086	.3361
Avg	1.2005	.9729	1.0948	1.2901	1.4195	1.3921	1.1943

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314023 / 33 KV Birsi (Satona)

Feeder No / Name : 203 / 11 KV Gangla Navezari

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.788	.7202	.8589	.567	.8916	.9114	.8954
2	.7343	.6859	.8488	.5316	.8916	.8413	.9054
3	.6805	.6859	.8402	.5316	.8916	.8589	.8775
4	.7964	.6516	.8488	.4961	.8916	.8939	.8488
5	.8326	.6859	.8402	.5316	.8745	.7888	.7655
6	.8417	.7545	.8402	.5847	.8745	.7712	.2241
7	.8326	.7545	.8402	.567	.8402	.7537	.2241
8	.8869	.7373	.8029	.7442	.823	.6836	.5281
9		.7545	.8215	.8328	.8059	.6859	
10		.8215	.7282		.8402	.8145	.7356
11		.9709	.9231	1.0277	.9088	.8413	.8775
12	.8059	.9431	.8507	.9114	.9259	.7362	.9619
13	.823	.9709	.8417	.9745	.8059	.7362	.9242
14	.7888	.9149	.8775	.8328	.8059	.7712	.6859
15	.7888	.9335	.9412	.8328	.8402	.7537	.811
16	.7545	.9335	.9412	.9465	.8059	.7701	.8676
17	.8573	.9149	.8059	.9745	.7888	.8059	.7842
18	.8573	.9709	.9313	.9391	.7716	.788	.9242
19	1.0631	.9896	1.182	1.1694	.9602	1.0924	1.1317
20	1.0631	1.0456	1.0136		1.0288	1.0745	1.094
21	.9259	1.0456	1.0387		.9602	1.0029	1.0751
22	.8573	.9335	.9955		.8745	1.3756	1.0562
23	.7888	.8775	.905		.8589	.9313	.9997
24	.8417	.7716	.8589	.6201	.9259	.8238	.8954
Max	1.0631	1.0456	1.182	1.1694	1.0288	1.3756	1.1317
Min	.6805	.6516	.7282	.4961	.7716	.6836	.2241
Avg	.8385	.8528	.8907	.7692	.8703	.8544	.8301

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314023 / 33 KV Birsi (Satona)

Feeder No / Name : 204 / 11 Kv Tirora Urban AG

FEEDER SEPERATION/PURE AG

Feeder Feeder KV- 11 /
OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0716	.1029	.112		.12	.12	.1837
2	.0716	.0857	.112	.0886	.12	.12	.1882
3	.0724	.0857	.1132	.124	.12	.1029	.1132
4	.0724	.0857	.112	.124	.12	.1029	.1132
5	.0716	.0857	.1132	.124	.12	.0857	.112
6	.0716	.0857	.112	.124	.12	.0857	
7	.0724	.0857	.1307	.124	.1372	.12	
8	.0724	.0686		.1417	.0686	.1254	
9	.0686	.0686			.0686	.1029	
10	.1029	.112		.1417	.1029	.1029	.1132
11	.1029	.1307		.1417	.12	.12	.0934
12	.12	.1307	.1267	.1417	.12	.12	.1132
13	.12	.1307	.1448	.1417	.0857	.1029	.1509
14	.12	.1307	.1433		.0857	.1075	.132
15	.12	.1494	.1463	.1052	.12	.1029	.1132
16	.12	.1494	.1448	.124	.12	.1254	.132
17	.1029	.1494	.124	.124	.12	.1433	.1509
18	.0857	.112	.1254	.1448	.1029	.1254	.1509
19	.0857	.112	.1267	.1417	.12	.1254	.1509
20	.0857	.1307	.1629		.12	.1075	.1509
21	.0857	.112	.1086		.12	.1086	.1509
22	.0857	.1132	.1086		.12	.1075	.132
23	.1029	.1132	.1267		.12	.0895	.132
24	.0724	.1029	.112	.1267	.12	.12	.1075
Max	.12	.1494	.1629	.1448	.1372	.1433	.1882
Min	.0686	.0686	.1086	.0886	.0686	.0857	.0934
Avg	.0899	.1097	.1253	.1284	.1122	.1114	.1342

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314026 / PARASWADA S/STN

Feeder No / Name : 201 / KARTI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5784	.6485	.6379	.6687	.7296	.5493
2		.5784	.6485	.631	.6661	.728	.5493
3		.5847	.6485	.6379	.6661	.7225	.5493
4		.5847	.631	.6024	.6661	.7296	.5316
5		.591	.6135	.5959	.6588	.6999	.5138
6		.591	.631	.6201	.6344	.6999	.5316
7		.5375	.5959	.5493	.5658	.6281	.5138
8		.5375	.5434	.4961	.583	.7296	.5316
9		.6068	.5258	.443	.5197	.7034	.5138
10	.583	.5847	.5221	.4287	.5895	.691	.4801
11	.6344	.5609	.535	.4854	.5609	.7087	.4801
12	.6001	.567	.4993	.5258	.5721	.6733	.463
13	.6274	.6024	.3745		.6068	.567	.4801
14	.6104	.6135	.4045		.5935	.815	.4578
15	.5868	.567	.4815		.5765	.4557	.39
16	.5868	.567	.4784	.5083	.5596	.5138	.4239
17	.6203	.5609	.4607	.5375	.5596	.5316	.4115
18	.6001	.5609	.4961	.5895	.5426	.4557	.57
19	.7108	.7537	.691	.6588	.749	.6733	.6955
20	.7282	.5258	.7087	.7202	.7034	.6379	.6858
21	.6661	.7362	.7087	.6859	.7922	.6135	.6747
22	.691	.7011	.6661	.6836	.8016	.5609	.6406
23	.6379	.6661	.6379	.7186	.7133	.6024	.6057
24	.6584	.6068	.6485	.6379	.6836	.7386	.5434
Max	.7282	.7537	.7087	.7202	.8016	.815	.6955
Min	.583	.5258	.3745	.4287	.5197	.4557	.39
Avg	.6361	.5985	.5750	.5902	.6347	.6504	.5328

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314026 / PARASWADA S/STN

Feeder No / Name : 202 / ARJUNI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7127	.5898	.8328	.7701	.7846	.6201
2		.663	.5898	.8328	.7737	.7737	.6135
3		.663	.5898	.8238	.7701	.7846	.6135
4		.663	.5898	.8328	.7701	.7737	.6135
5		.663	.6062	.815	.7865	.7668	.6201
6		.7127	.6226	.8328	.7865	.7668	.6201
7		.7045	.5407	.815	.8029	.7304	.6024
8		.7127	.6226	.8505	.7701	.963	.6201
9		.7701	.6226	.7973	.7537	.7668	.6201
10	.3258	.5258	.6591	.7611	.8192	.6556	.6062
11	.3437	.6836	.7034	.6802	.7865	.6379	.4641
12	.3429	.6661	.6241	.6802	.7045	.6733	.5898
13	1.0322	.6733	.6955		.6882	.8328	.583
14	1.0242	.6733	.7133		.6962	.6201	.5992
15	.7362	.691	.7386		.6962	.6201	.6154
16	.7449	.691	.7442	.6226	.7127	.5847	.6062
17	.7449	.5243	.7442	.9012	.7127	.6024	.6226
18	.7209	.5735	.7442	.7773	.6962	.6135	.6955
19	.8288	.6718	.9036	.8097	.8025	.7186	.7668
20	.8192	.6882	.9036	.8356	.8738	.7442	.8194
21	.7865	.6554	.8859	.8029	.8738	.7619	.7562
22	.779	.6226	.8682	.7865	.8203	.6556	.7311
23	.7373	.6226	.8328	.8029	.8089	.6201	.7133
24	1.0654	.7459	.5898	.8328	.7701	.7846	.6201
Max	1.0654	.7701	.9036	.9012	.8738	.963	.8194
Min	.3258	.5243	.5407	.6226	.6882	.5847	.4641
Avg	.7355	.6655	.6969	.7965	.7686	.7182	.6388

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314026 / PARASWADA S/STN

Feeder No / Name : 203 / SONEGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8785	.8848	.9568	.8745	.9362	1.0277
2		.8785	.8848	.9465	.8745	.9273	1.0166
3		.8785	.8848	.9568	.8745	.9233	1.0277
4		.8785	.8848	.9568	.8583	.9164	.9922
5		.8619	.8848	.9568	.8907	.9085	.9922
6		.8122	.8684	.8505	.8583	.9075	1.0099
7		.8785	.8029	.9568	.8745	.9095	.9745
8		.8785	.8029	.964	.9231	.9619	.9568
9		.9231	.8356	.9391	.8097	1.0521	.9568
10	.8583	.9745	.8916	.8259	.6802	1.0277	.852
11	.9069	1.0277	.8523	.8907	.8745	.6733	.9175
12	.9393	.9465	.7668	.8907	.8745	1.0099	.8745
13	.9231	.9745	.8738		.8192	.8328	.6081
14	.9393	.9214	.8441		.852	.815	.583
15	.9717	.9214	.9095		.9175	.815	.5735
16	.9602	.9214	.8682	.9393	.8848	.8328	.8192
17	.9717	.8356	.8859	.9717	.9503	.8859	.8097
18	.9762	.8684	.8859	.9555	.9339	1.0166	1.0903
19	1.0229	.8684	1.0277	.9762	.973	1.0808	1.1254
20	.9831	.9175	.9922	1.004	1.0177	1.0631	1.1079
21	.9555	.9175	.9745	1.004	.9848	1.0454	1.0727
22	.9339	.9175	.9922	.9069	.9496	1.0454	1.0727
23	.9175	.8848	.9568	.8907	.963	1.0277	1.0551
24	.9787	.8848	.8848	.9465	.8848	.932	1.0277
Max	1.0229	1.0277	1.0277	1.004	1.0177	1.0808	1.1254
Min	.8583	.8122	.7668	.8259	.6802	.6733	.5735
Avg	.9492	.9021	.8892	.9374	.8916	.9394	.9393

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314026 / PARASWADA S/STN

Feeder No / Name : 204 / 11 KV AGP Parawada
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4298	.4435	.4382	.362	1.1666	1.4575
2		.3982	.462	.4115	.3582	1.1566	1.4575
3		.3982	.462	.4115	.362	1.0192	1.4575
4		.3982	.462	.4115	.362	1.0192	1.4575
5		.3982	.4435	.4115	.3761	1.1666	1.4575
6		.3801	.462	.4287	.394	1.0855	1.4746
7		.4525	.4805	.4458	.4477	.9704	1.6289
8		.4887	.499	.3429	.4784	1.1711	1.6118
9		.499	.4251	.463	.4252	1.2423	1.6632
10	.8259	1.3717	1.206	1.1683	1.3592	.3944	1.5779
11	1.0277	1.4232	1.2849	1.4083	1.5415	.4458	1.4998
12	.9995	1.4403		1.4723	1.5249	.4458	.5014
13	1.0202	1.5432			1.4752		.5373
14	1.0322	1.5432			1.4752		.567
15	1.2651	1.3546	1.2544		1.5415		.5611
16	1.2651	1.5432	1.5432	1.4413	1.5249		.5611
17	1.2176	1.6078	1.4746	1.3927	1.5249		.5973
18	.3224	.4251	1.3375	1.3927	.499		.2672
19	.3856	.4251	1.3203	.3801	.5138		.214
20	.3856	.4251	1.2689	.3801	.4815		.211
21	.4252	.4435	.3772	.3982	.4924		.214
22	.4252	.462	.4115	.4344	.4414		.2138
23	.443	.4435	.4287	1.2003	.4458		.2131
24	.3589	.4298	.4435	.4382	.362	.9875	1.4575
Max	1.2651	1.6078	1.5432	1.4723	1.5415	1.2423	1.6632
Min	.3224	.3801	.3772	.3429	.3582	.3944	.211
Avg	.7599	.7802	.7853	.7272	.7820	.9439	.9525

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 318002 / 220KV KAWALEWADA S/STN

Feeder No / Name : 402 / 33KV LIS Dhapewada

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1946	1.6832	.1086	1.1946	1.6832	1.7375	.543
2	1.1403	1.6832	.1086	1.1831	1.6832	1.7375	.5258
3	1.1946	1.6832	.1086	1.1946	1.6301	1.7375	.5258
4	1.1946	1.6832	.1086	1.1946	1.6832	1.7375	.5258
5	1.1946	1.6832	.1086	1.1946	1.6301	1.7375	.5258
6	1.1946	1.086	.1086	1.1946	1.6832	1.7375	.5258
7	1.1946	.1086	.1086	1.7375	1.6832	1.7375	.9991
8	1.1946	.1086	.1086	1.6832	1.6832	1.0402	1.0402
9	1.6832	.1086	.1086	1.6832	1.7375	1.0923	1.6644
10	1.6832	.1052	.1086	1.6832	1.7375	1.2094	1.6644
11	1.7375	.1086	.1029	1.6832	1.7918	1.0923	1.7353
12	1.7375	.1086	.1086	1.6301	1.7375	1.1043	1.6827
13	1.7375	.1086	.1086	1.6832	1.7375	1.1043	1.6301
14	1.7375	.1086	.1086	1.7375	1.7375	1.0402	1.5604
15	1.6832	.1086	.1086	1.7375	1.7375	1.0402	1.6124
16	1.7375	.1086	.1086	1.7918	1.6827	1.0402	1.6124
17	1.7375	.1029			1.7918	1.0923	1.6832
18	1.6832	.1086			1.6832	1.0517	1.6832
19	1.9004	.1086			1.6832	1.0517	1.6832
20	1.6832	.1086			1.7918	.5258	1.6832
21	1.7918	.1086			1.6832	.5258	1.7375
22	1.6832	.1086			1.6832	.543	1.7375
23	1.6832	.1029			1.6832	.543	1.7375
24	.1086	1.6832	.1029			1.7375	.543
Max	1.9004	1.6832	.1086	1.7918	1.7918	1.7375	1.7375
Min	.1086	.1029	.1029	1.1831	1.6301	.5258	.5258
Avg	1.4796	.5424	.1079	1.5129	1.7069	1.2082	1.2859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 318002 / 220KV KAWALEWADA S/STN

Feeder No / Name : 403 / 33 KV Tirora

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.8325	5.1583	4.6696	5.3224	5.7065	5.4801	5.3727
2	4.7239	5.104	4.7239	5.3224	5.6516	5.4264	5.1006
3	4.7239	4.9954	4.3056	5.104	5.487	5.2652	5.2126
4	4.7239	4.784	4.3056	5.104	5.4321	5.1578	4.9429
5	4.7782	4.9434	4.3587	4.9966	5.4321	5.2115	3.8386
6	4.9411	5.2092	4.6776	5.2092	5.6516	5.3727	4.1015
7	5.0497	5.3212	4.417	4.9966	5.2126	4.8903	3.9963
8	4.9954	5.1578	2.6006	4.8903	4.9966	4.7325	3.786
9	4.6696	4.473	3.3128	4.7851	4.8903	4.7325	2.6292
10	4.8325	4.317	3.4551	5.0497	4.7851	4.417	4.5222
11	4.561	4.4119	3.774	5.0497	5.4298	4.6799	4.6273
12	4.7239	5.3212	4.3056	4.1461	5.4298	4.5748	4.6776
13	3.7209	5.0497	4.2524	4.5182	5.1029	4.7325	4.6776
14	5.0497	4.0398	3.774	2.6578	5.3212	4.5713	4.6776
15	5.0497	3.5368	5.0497	3.7209	4.5182	4.6245	4.3982
16	4.9954	3.774	3.2956	5.1578	4.8903	4.5713	4.2593
17	5.104	4.3056	5.1583	4.7817	5.156	4.9429	4.4525
18	5.2669	4.6776	5.7065	5.5967	5.1006	5.104	4.7782
19	7.1331	6.0357	7.54	7.5172	6.7873	6.7696	5.4841
20	7.0233	5.8711	7.2074	7.1519	6.749	6.6621	6.2986
21	6.4746	5.5418	6.9302	6.9856	6.5158	6.3935	6.4072
22	6.0357	5.5418	6.5421	6.653	6.1128	6.0174	6.2986
23	5.5967	5.0497	6.0905	6.2649	5.8025	5.6413	6.2443
24	4.9411	5.3772	4.8868	5.5418	5.8162	5.5876	5.4264
Max	7.1331	6.0357	7.54	7.5172	6.7873	6.7696	6.4072
Min	3.7209	3.5368	2.6006	2.6578	4.5182	4.417	2.6292
Avg	5.1644	4.9166	4.8058	5.2718	5.4991	5.2316	4.8421

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 318002 / 220KV KAWALEWADA S/STN

Feeder No / Name : 406 / 33/0.4 KV Station

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

Transformer Feeder KV- 33 /

(NON CONTINUOUS PROCESS)(NO

OUTGOING

STAGGERING)

DATE	01-MAR-17
HR	Load (MW)
24	.0543
Max	.0543
Min	.0543
Avg	.0543