

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194059 / 33/11 KV WALWAD S/S

Feeder No / Name : 201 / 11 KV WALWAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.0424	2.0729	2.17		1.2803	2.1538	1.9433
16					.0486		
18	.0457						
19			.0762				
24	.9755	1.0059	.8097	1.0974	.0305	.9717	1.0202
Max	2.0424	2.0729	2.17	1.0974	1.2803	2.1538	1.9433
Min	.0457	1.0059	.0762	1.0974	.0305	.9717	1.0202
Avg	1.0212	1.5394	1.0186	1.0974	.4531	1.5628	1.4818

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194059 / 33/11 KV WALWAD S/S

Feeder No / Name : 203 / Walwad GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.2667	.2667	.2401		.3048	.2267	.2429
10	.2667	.2667		.2667			
16	.2286				.1543	.1696	.2286
18	.2286						
19			.2667				
24	.1905	.1905	.1524	.1905	.1524	.1372	.1543
Max	.2667	.2667	.2667	.2667	.3048	.2267	.2429
Min	.1905	.1905	.1524	.1905	.1524	.1372	.1543
Avg	.2362	.2413	.2197	.2286	.2038	.1778	.2086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194068 / 33/11 KV SUKTA S/S

Feeder No / Name : 201 / 11 KV SUKTA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0124	.9722	1.3413	1.4861	.0162	1.4098	1.2037
2	.0133	1.1717	1.6289	1.6004	.0162	1.5242	1.2651
3	.017	1.3757	1.7147	1.829	.0171	1.6385	1.4217
4	.0181	1.5684	1.9719	1.9814	.0194	1.7528	1.5123
5	.0208	1.7652	2.2786	2.2862	.0213	1.9814	1.7029
6	.0232	2.0567	2.3663	2.6482	.0229	2.2862	2.0729
7	.0242	2.1792	2.5339	2.8959	.0238	2.5911	2.0972
8	.025	2.1538	2.5339	2.915	.0135	2.6292	2.3102
9	.0246	2.2672	2.7054	2.5911	.0238	2.3053	2.4434
10	.0034	.3048	.3429	.381	.0038	.4191	.3429
11	.2743	.381	.362	.0019	.381	.3353	.3429
12	.2743	.3429	.1715	.0017	.4001	.2896	.3429
13	.2439	.3429	.1715	.003		.2591	.3429
14	.2134	.3429	.3429	.003	.3429	.2439	.3048
15	.2439	.3429	.3239	.003	.3048	.2743	.2858
16	.2591	.2858	.362	.0032	.2858	.2743	.2858
17	.2896	.3048	.362		.3239	.2743	.381
18	.3048	.3429	.3429		.381	.2896	.4382
19	.3658	.8002	.6478	.0067	.6859	.4572	.7621
20	.5792	.7049	.8192		.743	.5487	.8002
21	.5182	.5335	.6478		.6097	.4877	.724
22	.4268	.4763	.5335		.4954	.4115	.6097
23	.3048	.4191	.4191		.381	.3048	.4763
24	.0072	.8025	1.166	1.3717	.0133	1.2955	.945
Max	.5792	2.2672	2.7054	2.915	.743	2.6292	2.4434
Min	.0034	.2858	.1715	.0017	.0038	.2439	.2858
Avg	.1870	.9266	1.0871	1.2227	.2403	1.0118	.9756

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194068 / 33/11 KV SUKTA S/S

Feeder No / Name : 203 / GhatNandur SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0021	.1829	.2286	.1905	.0021	.2096	.1524
2	.0021	.1677	.2667	.1715	.0021	.1905	.1677
3	.0029	.1829	.3048	.2286	.0029	.2286	.2134
4	.0044	.2439	.381	.4191	.0036	.3429	.3048
5	.0053	.3353	.4763	.4191	.0046	.4572	.3658
6	.0061	.4572	.5716	.6478	.0057	.6478	.5487
7	.0072	.5639	.6668	.724	.0067	.6859	.5335
8	.0057	.503	.6097	.5525	.0055	.6287	.4725
9	.0053	.3963	.381	.4191	.0048	.4954	.4763
10	.0027	.3201	.6859	.4954	.0021	.4572	.381
11	.4784	.4572	.6478	.0055	.5335	.3963	.381
12	.4012	.4725	.6097	.0057	.6478	.4115	.381
13	.381	.4401	.5335	.0055	.6859		.381
14	.1524	.4108	.5335	.0053	.5716	.3506	.3506
15	.3658	.4108	.5335	.0053	.5335	.3185	.3353
16	.4374	.4268	.5335	.0051	5.5441	.3201	.3353
17	.4877	.4572	.6097	.0051	.5716	.3658	.3506
18	.1981	.1905	.2667		.2286	.2439	.1905
19	.3048	.5716	.4763	.0051	.4001	.3658	.5716
20	.381	.5335	.6287		.4382		.6097
21	.3048	.4763	.4572		.381	.3658	.5335
22	.2439	.4382	.2858		.3048	.2743	.4763
23	.2134	.3429	.2286		.2667	.2134	.4191
24	.0025	.1981	.2286	.2096	.0023	.2286	.1677
Max	.4877	.5716	.6859	.724	5.5441	.6859	.6097
Min	.0021	.1677	.2286	.0051	.0021	.1905	.1524
Avg	.1832	.3825	.4644	.2379	.4646	.3727	.3791

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194070 / 33/11 kv Antargaon

Feeder No / Name : 201 / ANTARGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0526	1.4746		1.1469	1.6078	1.3717	1.531
2	1.1469	1.7901		1.2289	1.7404	1.4861	1.6129
3	1.2289	2.1051		1.2289	2.0222	1.8861	1.692
4	1.2289	2.5987		1.5565	2.2969	2.2291	1.9204
5	1.6385	2.713		1.9662	2.5774		2.0243
6	1.7814	2.9165		2.2119	2.8826	2.4086	2.0729
7	2.1862	3.3573		2.536	3.1369	3.0007	2.7854
8	2.6216	3.3303			3.086	2.8502	2.8178
9	2.4577	3.3829	2.5377	2.4577	1.8652	2.7999	2.713
10	.2858	.0032	.3086		.0023	.0038	
11		.2683	.3429				.2858
12			.3048				.2858
13		.2294	.2858		.1677		.2858
14		.1966	.2858		.2652		.3048
15					.2949		.3048
16		.2294	.2858		.2949		.3429
17					.2321		.3429
18		.3429					.381
19		.7049	.6097		.583		.4763
20			.7621		.724		.5716
21			.6859		.8002		.5716
22			.6287		.7621		.5716
23			.5716		.7621		.4572
24	.9602	1.065		.9116	1.1469	1.3717	1.0623
Max	2.6216	3.3829	2.5377	2.536	3.1369	3.0007	2.8178
Min	.2858	.0032	.2858	.9116	.0023	.0038	.2858
Avg	1.5081	1.5711	.6341	1.6938	1.2977	1.9408	1.1050

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194071 / 33/11 kv warud sub-station

Feeder No / Name : 201 / 11 KV Warud SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.2667		.2667	.2858	.362	.2858
2	.2858	.2477		.2667	.2858	.3429	.2858
3	.2858	.2477		.2667	.2667	.3429	.3048
4	.2858	.2667		.3048	.2858	.3429	.3239
5	.3239	.3429		.381	.3429	.4001	.3239
6	.4572	.4954		.4954	.5335	.4572	.4954
7	.5144	.5716		.4572	.5716	.4763	.6287
8	.4001	.5335		.4954	.5335	.4763	.4954
9	.3429			.381		.381	.381
10	.4877			.4458		.4666	.4464
11	.6481			.6722		.6093	.6539
12	.5357			.6371		.4489	.5944
13	.3477			.5868		.3763	.4054
14	.3429			.4858		.3429	.3429
15	.3601			.4161		.3715	.4401
16	.5721					.4694	.5624
17			.5573		.381		
18			.2477				
19			.4191		.4763		
20			.5335		.5716		
21			.4763		.4954		
22			.4382		.4191		
23			.381		.362		
24	.3239	.2858		.3048		.362	.2858
Max	.6481	.5716	.5573	.6722	.5716	.6093	.6539
Min	.2858	.2477	.2477	.2667	.2667	.3429	.2858
Avg	.4011	.362	.4362	.4290	.4151	.4134	.4268

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194072 / 33/11 KV PATHRUD S/S

Feeder No / Name : 201 / 11 KV PATHRUD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8488	.8488	1.0402	.7716		1.1574
2	1.0936	.9488	.9374	1.186	.8592		1.0536
3	1.0802	1.0155	1.0402	1.2346	.9602		1.3279
4	1.2793	1.1336	1.1069	1.2793	1.1603		1.2803
5	1.4403	1.1717	1.2346	1.3765	1.3108		1.0802
6	1.2955	1.2651	1.406	1.406	1.4089		1.3441
7	1.3279	1.406	1.6004		1.3889		1.0402
8	.8002	1.2651	1.5813	1.5432	1.2955		
9			1.3279		1.1736	1.1469	1.0155
10		.5335			.7716	.7811	.583
11						1.2003	.9602
12						1.0155	.7716
13			1.186			1.0802	.8002
14			1.3889			1.3117	.7116
15			1.2803			1.2498	.6249
16			1.2803			1.2003	.7116
17	.8697		1.1717	.6763		1.0279	.8802
18	.4868	.602	.7716	.5573		.7811	.7811
19	.5401	.6097	1.0936	.5468		1.0402	1.0402
20	.6249	.5944	1.0402	.5601		.9488	1.0936
21	.6401	.6097	1.1069	.5468		1.0802	
22	.5258	.5106	.9374	.4468		1.0402	
23	.4468	.4334	.9259	.4934		1.0936	
24	1.0402	1.1717	.8383	.8592	.6173		1.0402
Max	1.4403	1.406	1.6004	1.5432	1.4089	1.3117	1.3441
Min	.4468	.4334	.7716	.4468	.6173	.7811	.583
Avg	.8994	.8825	1.1478	.9168	1.0653	1.0665	.9649

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194072 / 33/11 KV PATHRUD S/S

Feeder No / Name : 203 / 11 KV Pathrud Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 /
OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1753	.1791	.181	.1696	.2743		.1734
2	.1734	.181	.1772	.2686	.2686		
3	.1696	.1772	.1791		.2658		
4	.181	.181	.181	.2658	.2715		.1753
5	.2686	.1791	.2658	.2658	.3658		.2686
6	.2629	.2743	.2743	.2629	.3658		.2601
7	.1791	.362	.362	.2686	.362		.1772
8	.1734	.2743	.3582	.2601	.3582		
9		.2686	.3658		.3658	.2686	.2715
10						.1753	.2658
11						.1905	.2743
12						.2601	.2715
13			.2686			.2543	.2743
14			.2601			.1772	.2686
15			.2658			.181	.2715
16			.1734			.2601	.2743
17	.2715		.1696	.2743		.1772	.2629
18	.2743	.3582	.1791	.2715		.1753	.1734
19	.2715	.362	.1753			.1696	.1753
20	.4477	.4477	.1696	.4525		.1753	.1734
21	.3658	.4572	.1696	.3658		.1791	
22	.2715	.362	.1791	.3582		.1734	
23	.1791	.2658	.1753	.2743		.1791	
24	.1734	.181	.1791	.1734	.2715		.1753
Max	.4477	.4572	.3658	.4525	.3658	.2686	.2743
Min	.1696	.1772	.1696	.1696	.2658	.1696	.1734
Avg	.2399	.2819	.2242	.2808	.3169	.1997	.2326

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194072 / 33/11 KV PATHRUD S/S

Feeder No / Name : 204 / JAMB GFSS FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.0191	.0095	.1905	.0191		.1905
2	.1905	.0191	.0095	.1905	.0191		.1905
3	.1905	.0191	.0095	.1905	.0191		.1905
4	.1905	.0191	.0191	.1905	.0191		.1905
5	.1905	.0191	.0191	.1905	.0191		.1905
6	.1905	.0191	.0191	.1905	.0191		.1905
7	.1905	.0191	.0191		.0191		.1905
8	.1905	.0191	.0191	.1905	.0191		
9		.0191	.0286		.0191	.1905	.0191
10						.1905	.0191
11						.1905	.0191
12						.1905	.0191
13			.1905			.1905	.0191
14			.1905			.1905	.0191
15			.1905			.1905	.0191
16			.1905			.1905	.0191
17	.0191		.1905	.0191		.1905	.1905
18	.0191	.0191	.1905			.1905	.1905
19	.0191	.0191	.1905			.1905	.1905
20	.0191	.0286	.1905			.1905	.1905
21	.0191	.0191	.1905	.0191		.1905	
22	.0191	.0191	.1905	.0191		.1905	
23	.0191	.0191		.0191		.1905	
24	.1905	.0191	.0191	.1905	.0191		.1905
Max	.1905	.0286	.1905	.1905	.0191	.1905	.1905
Min	.0191	.0191	.0095	.0191	.0191	.1905	.0191
Avg	.1155	.0197	.1038	.1334	.0191	.1905	.1219

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194004 / 33/11 KV SUB-STATION YERMALA

Feeder No / Name : 201 / 11 KV YERMALA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.3086	
2	.1334	.3506	.3353		.3506	.3052	
3						.3052	
4		.3582	.3353		.3506	.3018	.3582
5						.3052	
6		.4298	.3353		.3582		
7			.3353		.3856	.463	.3506
8	.4191	.4298	.4024	.4191	.4207	.4024	.4298
9					.4115	.3018	
10		.4954			.3429		
11					.3429		
12		.4191			.3429		
13					.3429		
14					.3429		
15		.381			.4191		
16			.381		.4191		
17					.4572		
18					.5335		
19					.5716		
20					.4954		
21					.5335		
22					.4572		
23					.381	.3371	
24	.1334	.3429	.3048	.381	.394	.3353	.4298
Max	.4191	.4954	.4024	.4191	.5716	.463	.4298
Min	.1334	.3429	.3048	.381	.3429	.3018	.3506
Avg	.2286	.4009	.3471	.4001	.4121	.3366	.3921

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194004 / 33/11 KV SUB-STATION YERMALA

Feeder No / Name : 202 / 11 KV UMRA PANGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.3681	.4001		.3521	.4001	
4		.4588	.381		.5571	.4191	.6226
6		.7522	.8383		.6882		
7			.9526		.8322	.8954	.8192
8	.7621	.6882	.8383	.5716	.7865	.7621	.6882
9					.6287	.6478	
10		.8383			.5868		
11					1.1191		
12		.9221			1.073		
13					1.0227		
14					1.0898		
15		.9892			1.073		
16			1.0479		1.0059		
17					1.0227		
18					.2667		
19					.6859		
20					.8573		
21					.6478		
22					.5716		
23					.4572		
24	.4763	.3521	.4001	.381	.3277	.4001	.3277
Max	.7621	.9892	1.0479	.5716	1.1191	.8954	.8192
Min	.4763	.3521	.381	.381	.2667	.4001	.3277
Avg	.6192	.6711	.6940	.4763	.7453	.5874	.6144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194004 / 33/11 KV SUB-STATION YERMALA

Feeder No / Name : 203 / 11 KV RATNAPUR FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.3521	
2		.4382	.4359		.5258	.3521	
3						.3521	
4		.4733	.503			.373	.5434
5						.4191	
6		.6447	.6371		.394	.5197	
7			.6706		.5258	.6104	.7522
8	.6097	.7701	.6706	.6668	.5784	.6371	.7011
9					.5765	.503	
10		.2286			.2286		
11					.2286		
12		.1905			.2096		
14					.2096		
15		.1715			.2096		
16			.1905		.1905		
17					.2286		
18					.2286		
19					.2858		
20					.3429		
21					.3429		
22					.3429		
23					.3429		
24	.4382	.3601	.4359	.4954	.4908	.3521	.3856
Max	.6097	.7701	.6706	.6668	.5784	.6371	.7522
Min	.4382	.1715	.1905	.4954	.1905	.3521	.3856
Avg	.5240	.4096	.5062	.5811	.3412	.4471	.5956

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194004 / 33/11 KV SUB-STATION YERMALA

Feeder No / Name : 205 / 11 KV BANGARWADI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.3506	.4191		.4656	.3688	
4		.394	.4748		.5014	.3856	.394
5						.4191	
6		.5373	.5365		.5373	.5868	
7			.5868		.6836	.5868	.6984
8	.6097	.6447	.6203	.5716	.6626	.503	.6447
9					.5868	.5087	
10		.1143			.1334		
11					.1143		
12		.1334			.0953		
14					.1143		
15		.0762			.1143		
16			.5716		.1143		
17					.1334		
18					.1334		
19					.2286		
20					.2477		
21					.2286		
22					.2286		
23					.2286		
24	.4954	.3944	.4191	.4763	.3772	.3688	.3086
Max	.6097	.6447	.6203	.5716	.6836	.5868	.6984
Min	.4954	.0762	.4191	.4763	.0953	.3688	.3086
Avg	.5526	.3306	.5183	.5240	.2965	.4660	.5114

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194004 / 33/11 KV SUB-STATION YERMALA

Feeder No / Name : 206 / 11 KV CHORAKHALI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.2858	
2		.3201	.2286		.192	.2667	
3						.2286	
4		.3605	.3048		.2949		.3277
5						.3048	
6		.4588	.5335		.4481		
7			.4954		.4481	.4572	.4588
8	.381	.4588	.4572	.4763	.426	.381	.3605
9					.4572	.2286	
10		.3353			.407		
11					.407		
12		.6706			.4024		
13					.4024		
14					.5365		
15		.5426			.6036		
16					.6036		
17					.6036		
18					.2286		
19					.3048		
20					.4572		
21					.381		
22					.381		
23					.3429		
24	.3048	.2949	.2286	.2286	.192	.3048	.1966
Max	.381	.6706	.5335	.4763	.6036	.4572	.4588
Min	.3048	.2949	.2286	.2286	.192	.2286	.1966
Avg	.3429	.4302	.3747	.3525	.4057	.3072	.3359

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430]

BU 2666

Substation No/ Name :- 194006 / 33/11 KV SUB-STATION KALLAM

Feeder No / Name : 203 / 11 KV KALLAM URBAN FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0576		2.0119	1.8099	2.2291	2.2405	2.5873
2	2.0576	2.0538	1.829	1.8099	2.0576	1.8671	2.3282
3	2.0576	2.0538	1.829	1.8099	2.2291	1.8671	1.97
4	2.0576	2.0538	1.8099	2.0119	2.2291	2.2405	1.9909
5	2.0576	2.0538	1.97	2.0119	2.2291	2.2405	1.9909
6	2.0576	2.2405	2.2177	2.2177	2.2291	2.2405	2.1719
7	2.0576	2.2405	2.2177	2.2177	2.4006	2.2405	
8	2.0576	2.0576	2.6139	2.4272	2.6139	2.2405	
9	2.2291	2.0576	2.6139	2.3777	2.3777	2.2291	2.2405
10	2.2291	2.2291	2.2405	2.5873	2.3282		2.2405
11	2.1434	2.0576	2.2405	2.5339	2.5606	2.4006	2.2405
12	2.1434	2.1948	2.2405	2.5606	2.3282	2.572	2.2405
13		2.0576	2.2405	2.3777	2.1948	2.572	2.2405
14		2.1434	2.2405	2.3777	1.97	2.4006	2.2405
15		2.2291	2.2405	2.3777	2.1719	2.3148	2.4272
16		1.848	2.2405	2.3777		2.6139	2.4272
17	3.0807	2.1948	1.8671	1.8861	2.4272	2.6139	2.4272
18	3.0807	2.4025	2.2405	1.8861	2.2405	2.6139	2.6139
19	3.1741	2.6139	2.6139	2.7435	2.2405		2.894
20	2.9874	2.8292	2.6139	2.915	2.6139	3.5294	
21	3.3608	2.8292	2.6139	2.7435	2.6139	3.3484	2.894
22	3.1741	2.8292	2.6139	2.7435	2.9874	2.9264	2.9874
23	2.9874	2.6139	2.4272	2.572	2.6139	2.7435	2.9874
24	2.2291	2.6139	2.1948	2.2177	2.4006	2.2405	2.5606
Max	3.3608	2.8292	2.6139	2.915	2.9874	3.5294	2.9874
Min	2.0576	1.848	1.8099	1.8099	1.97	1.8671	1.97
Avg	2.4640	2.2825	2.2492	2.3164	2.3603	2.4680	2.4143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430]

BU 2666

Substation No/ Name :- 194006 / 33/11 KV SUB-STATION KALLAM

Feeder No / Name : 205 / 11 KV EXPRESS JINNING

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715		.1334	.1143	.1715	.0267
2	.1715	.0191	.1524	.1334	.1715	.0191
3	.1715	.0191	.1524	.1524	.1715	.0191
4	.1715	.0191	.1524	.1905	.1715	.0191
5	.1715	.0762	.1905	.1715	.1715	.0191
6	.1715	.0762	.1905	.1905	.1715	.0191
7	.1715	.0762	.1524	.1905	.1715	.0191
8	.1715	.1715	.1334	.1524	.1905	.0191
9		.1715		.1334	.1905	
10	.1715	.1715		.1334	.1905	
11	.1715	.1715		.1334	.1905	
12	.1715	.1715		.1334	.1905	
13		.1715		.0953	.1524	
14		.1715		.1334	.1334	
15		.1715		.1334	.1334	
16		.1905		.1334		
17	.0381	.1334		.1715	.0267	
18	.0191	.1524		.1715	.0267	
19	.0191	.1524		.1715	.0267	
20		.1524		.1715	.0267	
21	.0191	.1143		.1715	.0267	
22	.0191	.1334	.1905	.1715	.0267	
23	.0191	.1334	.1905	.1715	.0267	
24	.1715	.0191	.1143	.1905	.1715	.0267
Max	.1715	.1905	.1905	.1905	.1905	.0267
Min	.0191	.0191	.1143	.0953	.0267	.0191
Avg	.1218	.1234	.1593	.1548	.1274	.0208

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194018 / 33/11 KV SUB-STATION

DAHIPHAL

Feeder No / Name : 201 / 11 KV BARATEWADI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6							1.0669
8		1.2631		1.0526		1.1584	1.1736
9			1.3003		1.2631		
10	.2587				.3658		
11	.2195		.1848				
12	.1991					.1677	
16		.1219					
17					.2033		
19				.3772		.1543	
20			.5014				
24			.5639		.6706		.6249
Max	.2587	1.2631	1.3003	1.0526	1.2631	1.1584	1.1736
Min	.1991	.1219	.1848	.3772	.2033	.1543	.6249
Avg	.2258	.6925	.6376	.7149	.6257	.4935	.9551

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194018 / 33/11 KV SUB-STATION

DAHIPHAL

Feeder No / Name : 203 / 11 KV DAHIPHAL FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6							.3353
8		.2713		.3018		.2286	.2286
9			.3582				
10	.8025				.2279		
11			.8421				
12	1.1012					.8993	
13	.9686						
16		.8535					
17					.9667		
19				.2286		.1943	
20			.3353				
24			.1886		.1886		.1524
Max	1.1012	.8535	.8421	.3018	.9667	.8993	.3353
Min	.8025	.2713	.1886	.2286	.1886	.1943	.1524
Avg	.9574	.5624	.4311	.2652	.4611	.4407	.2388

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194018 / 33/11 KV SUB-STATION

DAHIPHAL

Feeder No / Name : 204 / 11 KV GAUR FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.4409		.4578		.463	.4287
9					.373		
10	1.3395				1.17		
11	1.6108		1.7126				
12						1.4575	
13	1.6617						
16		1.5089					
17					1.6278		
19				.5144		.4115	
20			.6274				
24			.3772		.3772		.3601
Max	1.6617	1.5089	1.7126	.5144	1.6278	1.4575	.4287
Min	1.3395	.4409	.3772	.4578	.373	.4115	.3601
Avg	1.5373	.9749	.9057	.4861	.887	.7773	.3944

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194018 / 33/11 KV SUB-STATION

DAHIPHAL

Feeder No / Name : 206 / 11 KV SAPNAI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6							1.0974
8		1.2323		1.2955		1.1279	1.1736
9			.9602		1.2643		
10	.2241						
11	.192		.192				
12	.1696					.1981	
16		.1219					
17					.176		
19				.4287		.2591	
20			.4372				
24			.6097		.6097		.6249
Max	.2241	1.2323	.9602	1.2955	1.2643	1.1279	1.1736
Min	.1696	.1219	.192	.4287	.176	.1981	.6249
Avg	.1952	.6771	.5498	.8621	.6833	.5284	.9653

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430]

BU 2666

Substation No/ Name :- 194021 / 33/11 KV SUB-STATION MOHA

Feeder No / Name : 201 / 11 KV MOHA FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4687	.2849	.3475	.4572	.2743	.3384	.2689
2	.4687	.2858	.3384	.4572	.2743	.3018	.2689
3	.4744	.2858	.3338	.4572	.2753	.2972	.5778
4	.6173	.4438	.5068	.6874	.3688	.4275	.6472
5	.759	.5466	.6219	.8223	.5013	.5853	.5706
6	.743	.702	.9755	.8749	.638	.7773	.6412
7	.8322	.6935	.8048	.8855	.6836	.7316	.6401
8	.8749	.8916	.7468	.759	.6607	.6935	.6551
9	.5487	.6173	.6481	.7682	.695	.5944	.5487
10	2.4384	.9374	1.2498	2.4006	2.3205	2.406	2.5377
11	2.8378	.8573	2.8841	2.7496	2.7496	2.6978	2.7496
12	2.5114	2.4615	2.9835	2.9722	2.5095	2.8807	2.5606
13	2.7334	2.4966	2.8182	2.6795	2.4249	2.8121	2.4531
14	2.6749	2.1052	1.6575	2.6063	2.5095	2.6469	2.4249
15	2.6734	2.3122	2.7846	2.4139	2.6825	2.7195	2.4577
16	2.71	2.3403	2.7846	2.5803	2.5774	2.8152	2.5526
17	2.9776		1.989	2.7046	2.6825	2.8935	2.7846
18	.3615	.4572	.4755	.3887	.4923	.3402	.4515
19		.8642	.6622	.642	.4923	.6618	.6097
20	.5487	.8124	.8749	.6668	.631	.7138	.8642
21		.6562	.7499	.5679	.5944	.544	.7907
22	.4344	.6009	.6562	.5399	.5117	.4424	.6401
23	.4042	.506	.5624	.4619	.4054	.3371	.583
24	.4572	.3323	.4161	.4687	.3429	.3567	.2689
Max	2.9776	2.4966	2.9835	2.9722	2.7496	2.8935	2.7846
Min	.3615	.2849	.3338	.3887	.2743	.2972	.2689
Avg	1.3432	.9779	1.2030	1.2922	1.1791	1.2506	1.2311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194021 / 33/11 KV SUB-STATION MOHA

Feeder No / Name : 202 / 11 KV KHERDA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3336	1.2955	1.6766	1.6004	1.7528	1.3717	1.7528
2	1.5242	1.4861	1.7909	1.7147	1.7528	1.5242	2.1719
3	1.5242	1.5242	1.9052	1.9052	1.8671	1.6766	2.2481
4	1.829	1.7528	2.0957	2.2862	2.21	1.8671	2.4387
5	1.9052	1.9433	2.6673	2.5911	2.6292	2.2862	2.7054
6	2.5149	2.7435	2.6673	2.8959	3.0483	2.7435	3.0483
7	2.7435	2.6673	3.0483	2.8959	1.9052	2.8578	2.4387
8	2.5911	2.6673	2.7435	2.9721	2.5149	2.8959	2.2862
9	2.4387	2.6292	2.7435	2.934	2.4387	2.5149	2.2862
10	.1905	.2667		.2667	.3048	.3048	.3048
11	.1524	.1905		.1905	.2667	.2286	.2667
12	.1524	.1905			.2286	.1905	.0191
13	.1524			.1905	.1905	.1905	
14	.1524	.1905		.1905		.1905	.2667
15	.1524	.1905	.1905	.1524		.1905	.2667
16	.1524	.1905	.1905	.1905		.1905	.2667
17	.1524	.1905	.1905	.1524		.1905	.3048
18	.2667		.2667	.2286		.2286	.3429
19		.6097	.4572	.5716		.4572	.4191
20	.5335	.5335	.6478	.6097	.5716	.5335	.5335
21		.5335	.5335	.5335	.4954		.5335
22	.3429	.4572	.4572	.4191	.381	.381	.381
23	.3429	.3048	.381	.3429	.3048	.3048	.3048
24	1.2955	1.2193	1.2955	1.3336	1.2955	.9526	1.105
Max	2.7435	2.7435	3.0483	2.9721	3.0483	2.8959	3.0483
Min	.1524	.1905	.1905	.1524	.1905	.1905	.0191
Avg	1.0201	1.0808	1.3657	1.1812	1.3421	1.0553	1.1605

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430]

BU 2666

Substation No/ Name :- 194021 / 33/11 KV SUB-STATION MOHA

Feeder No / Name : 203 / 11 KV NAGZARWADI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9511	.6813	1.3413	.9633	1.0209	.7819	.9602
2	.9998	.6904	1.3763	1.0669	1.0364	1.3108	.9659
3	1.0936	.7926	1.4403	1.1069	1.1001	1.3108	1.0973
4	1.2651	.9282	1.5043	1.1069	1.155	1.326	1.1303
5	1.2498	.9659	1.7394	1.2803	1.1913	1.3927	1.1674
6	1.3435	1.096	1.8884	1.4251	1.2803	1.5729	1.3932
7	1.406	.9694	1.6644	1.4723	1.3987	1.5364	1.6022
8	1.4232	1.2455	1.5813	1.4723	1.3812	1.4373	1.4943
9	1.4083	1.1888	1.5043	1.5492	1.1797	1.5337	1.6057
10	.1524	.1848		.1524	.1867	.1905	.181
11	.1143	.1509		.1143		.1524	.1829
12	.1143			.1143		.1143	
13	.1143	.1494		.1143	.1494	.1143	
14	.1143	.1478		.1143		.1143	
15	.1143	.1478	.1143	.1143		.1143	
16	.1143	.1478	.1143	.1143		.1143	
17	.1143	.1494	.1143	.1143		.1143	.1143
18	.1524	.3224	.1524	.1524		.1524	.1524
19		.3292	.2667	.3429		.3048	.2286
20	.381	.3292	.4191	.4191	.3582	.3429	.4191
21		.2926	.3429	.3429	.2926	.3048	.3429
22	.1905	.2481	.2667	.2667	.2561	.2667	.2667
23	.1905	.2195	.1905	.1905	.2195	.2286	.2286
24	.8573	.8383	1.0631	.9511	.9608	.823	.8312
Max	1.4232	1.2455	1.8884	1.5492	1.3987	1.5729	1.6057
Min	.1143	.1478	.1143	.1143	.1494	.1143	.1143
Avg	.6302	.5311	.8992	.6276	.8229	.6523	.7560

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194024 / 33/11 KV SUB-STATION ITKUR

Feeder No / Name : 201 / 11 KV MANDAWA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953		.0953	.0953	.0953	.0953
2	.0953	.0953		.0953	.0953	.0953	.0953
3	.0953	.0953		.0953	.0953	.0953	.0953
4	.0953	.0953		.0953	.0953	.0953	.0953
5	.0953	.0953		.0953	.0953	.0953	.0953
10	1.4289	1.5242	1.1431		1.1431	1.5242	1.7147
11	1.9052		1.6194	1.8099	1.2384	1.9052	1.9052
12			1.7147	1.7147	1.4289	1.9052	2.0957
13	1.8099		1.6194	1.6194	1.4289	1.8099	1.7147
14	1.7147		1.6194	1.7147	1.5242	1.7147	1.3336
15	1.7147		1.5242	1.8099	1.6194	1.5242	1.3336
16	1.9052		1.7147	1.9052	1.6194		1.7147
17	1.9052		1.9052	1.5242	1.7147		2.0005
18	.0953					.0953	
19	.0953		.0953		.0953	.0953	.0953
20	.0953		.0953		.0953	.0953	.0953
21	.0953		.0953		.0953	.0953	.0953
22	.0953		.0953		.0953	.0953	.0953
23	.0953		.0953	.0953	.0953	.0953	.0953
24	.0953			.0953	.0953	.0953	.0953
Max	1.9052	1.5242	1.9052	1.9052	1.7147	1.9052	2.0957
Min	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Avg	.7120	.3335	1.0259	.9118	.6719	.6404	.7822

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194024 / 33/11 KV SUB-STATION ITKUR

Feeder No / Name : 202 / 11 KV ITKUR AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8916	.9659	.9659	.8916	.9659	.743	.8173
2	.8916	1.0402	.9659	.8916	1.0402	.8173	.8173
3	.9659	1.0402	1.0402	.8916	1.0402	.8173	.8916
4	1.0402	1.1145	1.1145	.8916	1.0402	1.0402	.9659
5	1.1145	1.1888	1.1888	.9659	1.1145	1.1888	1.1145
6	1.4118	1.5604	1.4118	1.3375	1.4861	1.3375	1.4118
7	1.4118	1.7833	1.7833	1.6347	1.5604	1.4118	1.6347
8	1.4861	1.7833	1.8576	1.709	1.4861	1.3375	1.3375
9	1.4118	1.6347	1.8576	1.6347	1.4861	1.2631	1.4861
18	.0743					.0743	
19	.0743	.0743	.0743		.0743	.0743	.0743
20	.0743	.0743	.0743		.0743	.0743	.0743
21	.0743		.0743		.0743	.0743	.0743
22	.0743		.0743		.0743	.0743	.0743
23			.0743		.0743	.0743	.0743
24	.8916	.9659	.8916	.8916	.9659	.743	.743
Max	1.4861	1.7833	1.8576	1.709	1.5604	1.4118	1.6347
Min	.0743	.0743	.0743	.8916	.0743	.0743	.0743
Avg	.7926	1.1022	.8966	1.1740	.8371	.6966	.7727

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430]

BU 2666

Substation No/ Name :- 194024 / 33/11 KV SUB-STATION ITKUR

Feeder No / Name : 203 / 11 KV KOTHALWADI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1638	.2772	.1715	.1715	.1715	.1638
2	.1715	.1638	.2801	.1715	.1715	.1715	.1638
3	.1715	.1638	.2772	.1715	.1715	.1715	.1638
4	.1715	.1638	.2743	.1715	.1715	.1715	.1638
5	.1715	.1638	.2743	.1715	.1715	.1715	.1638
10		2.7035	3.0864		2.8292	2.7035	2.8292
11	4.0143	3.9438	3.9438	4.0143	3.3436	3.6046	3.2579
12		3.8561	4.201	3.9323	3.3436	3.6046	3.7723
13	3.9323	3.9438	4.1838	3.8504	3.6866	3.195	3.858
14	3.8504	3.2693	4.201		3.6008	3.0312	3.7723
15	3.7685	3.94	4.2867	3.9323	3.4294	2.9492	3.7723
16	3.9323	4.119	4.201		3.7723	3.195	3.9438
17	3.9323	3.9438	4.2867	3.8504	4.1152	3.4408	3.9438
18						.1638	
19	.1638		.1715		.1715	.1638	.1715
20	.1638	.2801	.1715		.1715	.1638	.1715
21	.1638		.1715		.1715	.0164	.1715
22	.1638		.1715		.1715	.1638	.1715
23	.1638		.1715		.1715	.1638	.1715
24	.1715	.1638		.1715	.1715	.1715	.1638
Max	4.0143	4.119	4.2867	4.0143	4.1152	3.6046	3.9438
Min	.1638	.1638	.1715	.1715	.1715	.0164	.1638
Avg	1.4869	2.0655	1.9239	1.8735	1.5793	1.3794	1.6310

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194024 / 33/11 KV SUB-STATION ITKUR

Feeder No / Name : 204 / 11 KV ADHALA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3953	.3953	.3201	.3163	.4744	.3163	.3953
2	.3953	.4744	.3239	.3163	.4744	.3953	.3953
3	.3953	.4744	.3201	.3163	.5535	.3953	.3953
4	.4744	.5535	.3239	.3163	.5535	.4744	.3163
5	.4744	.6325	.4001	.4744	.6325	.4744	.3163
6	.5535	.6325	.5601	.5535	.6325	.5535	.3953
7	.6325	.7116	.8097	.6325	.7116	.6325	.4744
8	.7907	.7116	.7202	.7116	.6325	.6325	
9	.7907	.6325	.7287	.5535	.6325	.7116	
18	.0791					.0791	
19	.0791	.08	.0791		.0791	.0791	.6325
20	.0791	.08	.0791		.0791	.0791	.0791
21	.0791		.0791		.0791	.0791	.0791
22	.0791		.0791		.0791	.0791	.0791
23	.0791		.0791		.0791	.0791	.0791
24	.3953	.3953	.3239	.3163	.3953	.3163	.3163
Max	.7907	.7116	.8097	.7116	.7116	.7116	.6325
Min	.0791	.08	.0791	.3163	.0791	.0791	.0791
Avg	.3608	.4811	.3484	.4507	.4059	.3360	.3041

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430]

BU 2666

Substation No/ Name :- 194024 / 33/11 KV SUB-STATION ITKUR

Feeder No / Name : 205 / 11 KV ITKUR GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6535	.7545	.543	.6268	.5601	.6535
2	.6859	.6535	.7468	.543	.6268	.5601	.6535
3	.8573	.6535	.7468	.543	.6268	.5601	.6535
4	1.0288	.7468	.8316	.543	.7164	.6535	.8402
5	1.0288	1.226	1.1088	.9955	1.0374	.7468	1.0374
6	1.286	1.4146	1.4784	1.267	1.4146	1.0269	1.4146
7	1.3717	1.3203	1.4003	1.267	1.3203	1.2136	1.3203
8	1.3717	1.1393		1.1765	1.2136	1.1203	1.226
9	1.307	1.0164	1.307	.9955	1.1088	1.1203	1.0269
10	.7468	.6535	1.086	.7392	.7468	.7392	.8962
11	.5544		.6335	.6468	.6468	.6468	.6535
12			.543	.5544	.6468	.5544	.5544
13	.5544		.543	.5544	.5544	.5544	.5544
14	.5544		.543	.5544	.5544	.5544	.5544
15	.5544	.5544	.543		.5544	.5544	.5544
16	.5544	.5601	.543		.5544	.543	.6468
17	.5544	.6468	.5144		.5544	.6201	.6468
18	.6201	.6535	.5144		.7392	.6068	.6468
19	.8859	1.0164	1.0288		1.2012	.905	.924
20	1.3575	1.2136	1.286		1.307	1.3575	1.2012
21	1.1641		1.0288		1.0269	1.1765	1.2936
22	.905		.9431		.9335	.8954	.924
23	.8316		.905		.8402	.7468	.7392
24	.6859	.6535	.7468	.543	.7164	.7468	.6335
Max	1.3717	1.4146	1.4784	1.267	1.4146	1.3575	1.4146
Min	.5544	.5544	.5144	.543	.5544	.543	.5544
Avg	.8759	.8692	.8598	.7644	.8445	.7818	.8437

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194032 / 33/11 KV SUB-STATION

GOVINDPUR

Feeder No / Name : 201 / 11 KV GOVINDPUR GAOTHAN

GAOTHAN FEEDER

(NEW) Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.0844		.1715		.181	.1715
2	.1715	.0854	.1715	.1715		.181	.1715
3	.1715	.051	.1715	.1715		.1791	.1715
4	.1715	.0879	.1715	.1715		.1791	.1715
5	.1715	.1738	.1715	.1715		.181	.1715
6	.1715	.1688	.1715	.1715		.2715	.1715
7	.2572	.1705	.2572	.2572		.2715	.1715
8	.2572	.0869	.1715	.2572		.1791	.1715
9	.1715	.085	.1715	.1715		.1791	.1715
10	.1688	.1791	.1715	.0843	.1791	.1715	.0834
11	.1701	.1791	.0857	.0774	.0905	.0857	.0869
12	.0879	.0905	.0857	.0854	.0905	.0857	.0843
13	.0854	.0905	.0857		.0905	.0857	.083
14	.0879	.0905	.0857		.0914	.0857	.0869
15	.085	.0905	.0857		.0895	.0857	.0843
16	.0834	.0362	.0857		.0895	.0857	.0854
17	.0834	.0905	.0857		.0895	.0857	.085
18	.085	.181	.0857		.1791		.1699
19	.1707	.2715	.1715		.2715	.1715	.1686
20	.1699	.2715	.1715		.2715	.1715	.1686
21	.1755	.181	.1715		.181	.1715	.168
22	.1707	.1791	.1715		.1791	.1715	.1688
23	.1758	.1791	.1715		.181	.1715	.1694
24		.1738	.1715			.1715	
Max	.2572	.2715	.2572	.2572	.2715	.2715	.1715
Min	.0834	.0362	.0857	.0774	.0895	.0857	.083
Avg	.1528	.1366	.1454	.1635	.1481	.1566	.1407

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194032 / 33/11 KV SUB-STATION

GOVINDPUR

Feeder No / Name : 202 / 11 KV DEODHANORA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0703	.0953	.0953		.0953	.0953
2	.0953	.0677	.0953	.0953		.0953	.0953
3	.0953	.0703	.0953	.0953		.0953	.0953
4	.0953	.0702	.0953	.0953		.0953	.0953
5	.0953	.0869	.1524	.0953		.0953	.0953
6	.0953	.1043	.1524	.0953		.1524	.0953
7	.0953	.0869	.1524	.0953		.1524	.0953
8	.0953	.0695	.1524	.0953		.0953	.0953
9	.0953	.0528	.0953	.0953		.0953	.0953
10	1.1046	1.5051	1.3336	1.1949	.9031	.4763	.7587
11	3.1475	2.915	1.9052	3.0007	2.5911		2.8372
12	3.0727	2.7435	2.2862	3.2036	2.753	1.5242	2.8664
13	2.889	2.8807	2.4768		2.8826	1.7147	2.8307
14	2.5292	2.5606	2.6673		2.753	2.0957	2.8988
15	2.889	2.7854	2.8578		2.6216	1.9052	2.954
16	2.9573	2.7854	3.2388		2.9492	2.0957	2.9507
17	3.035	2.915	3.4294		2.9492	2.0957	
18	.0508	.0953	.0953		.0953	.0953	.0693
19	.0703	.0953	.0953		.1524	.0953	.0676
20	.0851	.0953	.0953		.1524	.0953	.0869
21	.0869	.0953	.0953		.1524	.0953	.0854
22	.0868	.0953	.0953		.1524	.0953	.0847
23	.0881	.0953	.0953		.0953	.0953	.085
24		.0868	.0953			.0953	
Max	3.1475	2.915	3.4294	3.2036	2.9492	2.0957	2.954
Min	.0508	.0528	.0953	.0953	.0953	.0953	.0676
Avg	.9978	.9345	.9145	.6881	1.5145	.5890	.8833

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194032 / 33/11 KV SUB-STATION

GOVINDPUR

Feeder No / Name : 203 / 11 KV KHAMASWADI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3336	.8688	1.1431	1.3336		1.0288	1.5242
2	1.3336	1.1949	1.1431	1.5242		1.0288	1.7147
3	1.6194	1.3032	1.5242	1.5242		1.0288	1.7147
4	1.6194	1.3656	1.5242	1.7147		1.3717	1.8099
5	1.7147	1.4332	1.5242	1.7147		1.448	1.8099
6	1.3717	1.7337	1.7147	1.9052		1.5384	1.9052
7	1.9052	1.7052	1.9052	1.9052		1.6194	1.9052
8	1.9052	1.6994	1.9052	2.0005		1.6194	1.9052
9	1.2384	1.6217	1.7147	2.0005		1.6956	1.9052
10	.0879	.0953	.0953	.0348	.0953	.0953	.0348
11	.0682	.0953	.0953	.0348	.0953	.0953	
12	.0521	.0953	.0953	.0348	.0953	.0953	.0348
13	.0521	.0953	.0953		.0953	.0953	
14	.0521	.0953	.0953		.0953	.0953	
15	.051	.0953	.0953		.0953	.0953	
16	.0512	.0953	.0953		.0953	.0953	.0337
17		.0953	.0953		.0953	.0953	
18		.0953	.0953		.0953		
19	.0528	.0953	.0953		.0953	.0953	
20	.0683	.0953	.0953		.0953	.0953	.052
21	.0869	.0953	.0953		.0953	.0953	.0695
22	.0854	.0953	.0953		.0953	.0953	.0693
23	.0869	.0953	.0953		.0953	.0953	.068
24		.8335	.9526			.8573	
Max	1.9052	1.7337	1.9052	2.0005	.0953	1.6956	1.9052
Min	.051	.0953	.0953	.0348	.0953	.0953	.0337
Avg	.7065	.6289	.6827	1.3106	.0953	.6294	1.0348

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194032 / 33/11 KV SUB-STATION

GOVINDPUR

Feeder No / Name : 204 / 11 KV JAWALA AG FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL

DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0675	.0762	.0762		.081	.0762
2	.0762	.0695	.0762	.0762		.081	.0762
3	.0762	.0703	.0762	.0762		.081	.0762
4	.0762	.0695	.0762	.0762		.081	.0762
5	.0762	.0695	.0762	.0762		.081	.0762
6	.0762	.0869	.0945	.0762		.081	.0762
7	.0762	.0695	.0762	.0762		.081	.0762
8	.0762	.0528	.0762	.0762		.081	.0785
9	.0762	.0512	.0762	.0762		.081	.0762
10	3.0452	3.1413	3.238	2.7576	2.6864	2.6155	2.7153
11	4.3865	3.9	3.8348	4.0718	3.6686	1.6972	3.8287
12	4.3961	3.8847	4.0527	3.8432	3.9213	3.2914	4.0299
13	4.0893	3.5787	4.1495	1.848	3.2602	3.3601	3.663
14	2.9545	3.4396	4.2349	1.7817	3.2305	3.3837	3.4793
15	3.775	3.7601	8.9727	1.8922	3.3158	3.4637	3.65
16	4.0973	3.767	4.5184	2.1148	3.3722	3.7959	3.7457
17	4.097	3.7464	4.8309	2.2016	3.4552	3.9011	3.7476
18	.8258	1.257	.9945	.7674	1.3095	.7971	.8369
19	.0887	.081	.0762		.081	.0762	.0674
20	.0854	.0819	.1219	.0175	.081	.0762	.084
21	.0879	.0819	.0762		.081	.0762	.0844
22	.0853	.081	.0762		.081	.0762	.0843
23	.0879	.081	.0762		.081	.0762	.0683
24		.094	.0762			.0762	.9953
Max	4.3961	3.9	8.9727	4.0718	3.9213	3.9011	4.0299
Min	.0762	.0512	.0762	.0175	.081	.0762	.0674
Avg	1.4256	1.3159	1.6681	1.1569	2.0446	1.1455	1.3237

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194032 / 33/11 KV SUB-STATION

GOVINDPUR

Feeder No / Name : 205 / 11 KV BORGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-MAY-17	24-MAY-17	25-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.5242	1.5242		1.6194
2	1.3336	1.5242	1.7147		1.8099
3	1.4289	1.9052	1.9052		1.9052
4	1.7147	1.9052	1.9052		1.9052
5	1.9052	2.0957	2.0957		2.0957
6	2.0957	2.2862	2.2862		2.2862
7	2.2862	2.2862	***		2.2862
8	2.0957	***	2.4768		2.191
9	1.8099	2.0957	2.2862		2.191
10		.0953		.0953	
11		.0953		.0953	
12		.0953		.0953	
13		.0953		.0953	
14		.0953		.0953	
15		.0953		.0953	
16		.0953		.0953	
17		.0953		.0953	
18		.0953		.0953	
19		.0953		.0953	
20		.0953		.0953	
21		.0953		.0953	
22		.0953		.0953	
23				.0953	
24		.8573		.9526	
Max	2.2862	21.967	24.8248	.9526	2.2862
Min	1.1431	.0953	1.5242	.0953	1.6194
Avg	1.757	1.7255	4.5577	.1525	2.0322

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194032 / 33/11 KV SUB-STATION

GOVINDPUR

Feeder No / Name : 206 / 11 KV DEODHANORA GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1738	.1715			.1791	.1715
2	.1715	.1667	.1715	.1715		.1791	.1715
3	.1715	.1738	.1715	.1715		.1791	.1715
4	.1715	.1758	.1715	.1715		.1791	.1715
5	.1715	.2601	.2572	.1715		.2686	.1715
6	.3429	.1688	.6859	.1715		.4477	.1715
7	.3429	.2561	.4287	.3429		.4477	.3429
8	.3429	.1629	.3429	.381		.4477	.3429
9	.3429	.1758	.2572	.3429		.3582	.0343
10	.1738	.181	.1715	.1758	.181	.1715	.3475
11	.1738	.181	.1715	.1736	.181	.1715	.2638
12	.1758	.181	.1715	.1738	.181	.1715	.1736
13	.1758	.181	.1715		.1791	.1715	.1705
14	.1738	.181	.1715		.181	.1715	.1686
15		.181	.1715		.181	.1715	.1705
16	.1705	.1829	.1715		.1791	.1715	.1686
17	.2561	.1829	.1715		.1791	.1715	.1705
18	.2561	.1791	.2572		.2686	.1715	.2549
19	.3517	.4525	.3429		.4477	.3429	.2561
20	.3399	.4525	.3429		.4477	.3429	.3414
21	.3475	.3582	.3429		.4477	.3429	.3387
22	.2606	.3658	.3429		.362	.3429	.338
23	.2606	.362	.1715		.362	.1715	.3414
24		.2549	.1715			.1715	
Max	.3517	.4525	.6859	.381	.4477	.4477	.3475
Min	.1705	.1629	.1715	.1715	.1791	.1715	.0343
Avg	.2430	.2329	.2501	.2225	.2699	.2477	.2284

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194032 / 33/11 KV SUB-STATION

GOVINDPUR

Feeder No / Name : 207 / 11 KV ADLERS EXPRESS

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

Feeder KV- 11 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0869	.0953	.0953		.0953
2		.0869	.0953	.0953		.0953
3			.0953	.0953		.0953
4		.0879	.0953	.0953		.0953
5		.0879	.0953	.0953		.0953
6		.0869	.0953	.0953		.0953
7		.0879	.0953	.0953		.0953
8		.0877	.0953	.0953		.0953
9	.0953	.0877	.0953	.0953		.0953
10	.085		.0953	.0879	.0953	.0869
11	.0869		.0953	.0871	.0953	.0871
12	.0869		.0953	.0869	.0953	.0879
13	.085		.0953		.0953	.0869
14	.0869		.0953		.0953	.0879
15	.0876		.0953		.0953	.0881
16	.0869		.0953		.0953	.0869
17	.0869		.0953		.0953	.0869
18	.0908		.0953		.0953	.0881
19	.0881		.0953		.0953	.0881
20	.0879		.0953		.0953	.0869
21	.0348		.0953		.0953	.0341
22	.0879		.0953		.0953	.0854
23	.0879		.0953		.0953	.0869
24		.0869	.0953		.0953	
Max	.0953	.0879	.0953	.0953	.0953	.0953
Min	.0348	.0869	.0953	.0869	.0953	.0341
Avg	.0843	.0874	.0953	.0933	.0953	.0881

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194054 / 33/11 KV SUB-STATION MASSA

Feeder No / Name : 202 / 11 KV MASSA AG-II FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3203		1.3203		1.3717
2	1.4146		1.4146		1.3717
3	1.6032		1.5089		1.3717
4	1.6975		1.6975		1.3717
5	1.8861		1.9805		1.7147
6	2.0748		2.2634		1.8861
7			2.3577		2.0576
9				1.7147	
10				.0857	
11				.0857	
12				.0857	
19		.0943		.0857	
20		.0943		.0857	
21		.0943		.0857	
22				.0857	
23		.0943		.0857	
24	1.1317	.0943	1.1317		1.2003
Max	2.0748	.0943	2.3577	1.7147	2.0576
Min	1.1317	.0943	1.1317	.0857	1.2003
Avg	1.5897	.0943	1.7093	.2667	1.5432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194054 / 33/11 KV SUB-STATION MASSA

Feeder No / Name : 203 / 11 KV MASSA GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048		.2286		.2572
2	.3429		.2641		.2572
3	.381		.3048		.2572
4	.381		.381		.2572
5	.4191				.3429
6	.4572		.4572		.4287
7			.4572		.4287
9				.4287	
10				.2572	
11				.2058	
12				.2058	
13				.2058	
14				.2058	
15				.2572	
16				.3429	
17		.3429		.3429	
18		.2286		.3429	
19		.381		.4287	
20		.4572		.4287	
21		.4954		.4287	
22		.381		.3429	
23				.2572	
24	.3429		.2667		.2572
Max	.4572	.4954	.4572	.4287	.4287
Min	.3048	.2286	.2286	.2058	.2572
Avg	.3756	.3810	.3371	.3121	.3108

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194057 / 33/11 KV SUB-STATION

RAIGHAVAN

Feeder No / Name : 202 / 11 KV RANJANI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1336	1.267	1.0688		1.6289		.7287
2	1.1336	1.2851	1.1336	1.2955	1.6289		.7287
3	1.2146	1.267	1.1336		1.6289		.7287
4	1.2146	1.3575	1.0526	1.7147	1.6289		.7287
5	1.5384	1.448			1.7375		1.2955
6	1.7814	1.7147		1.448	1.7194		1.2955
7	1.9433	1.8861		1.7147	1.6289		1.2955
8	2.0243	1.9719		1.8861	1.2346		1.2146
9	1.6518	1.6108		1.8004	1.1145		1.085
10	1.3765	1.0174		1.5432	1.3717		1.2955
11	1.8861	1.5384	1.8861	1.9719		1.6194	1.8004
12	1.9033	1.3765	1.6194	1.6289		1.7004	1.6956
13	1.8861	.3239	1.8861	1.6289		1.6194	1.8861
14	1.6956	1.6194	1.8004	1.6289		1.6194	1.8519
15	1.5261	1.7004	1.9719	1.6289		1.7004	1.8004
16	1.5261	1.8623	1.8861	1.7147		1.7004	1.8861
17	1.6108	1.8623		1.7147		1.6194	1.9204
18	.4287	1.7814				1.6194	.0905
19	.4525			.4572		.1326	.128
20		.2915		.4525		.1326	.1646
21	.4024	.2486		.4525		.1326	.1463
22	.4525	.2753		.4525		.1326	.1646
23	.4525	.2429		.4525		.1492	.1646
24	.9878	1.3575	1.0688	.9717	1.3575		.7287
Max	2.0243	1.9719	1.9719	1.9719	1.7375	1.7004	1.9204
Min	.4024	.2429	1.0526	.4525	1.1145	.1326	.0905
Avg	1.3140	1.2742	1.5007	1.3279	1.5163	1.0675	1.0344

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194057 / 33/11 KV SUB-STATION

RAIGHAVAN

Feeder No / Name : 203 / 11 KV RAIGAVHAN GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4858	.2715	.4858		.362		.2429
2	.4858	.2715		.2286	.362		.2429
3	.4858	.2715			.362		.2429
4	.4858	.2715		.2286	.4525		.2429
5	.4858	.362			.4525		.2429
6	.4858	.543		.3239	.6335		.2429
7	.4858	.6001		.3239	.724		.3239
8	.4858	.5087		.3239	.6001		.4049
9	.4858	.5087		.2286	.5144		.4049
10	.4534	.4239			.4287		.4049
11	.3772	.2429	.2286	.4287		.2429	.3429
12	.3429	.2429	.2286	.3429		.2429	.3391
13	.3391	.2429	.2286	.3429		.2429	.3429
14	.3391	.2429	.2286	.3429		.2429	
15	.3052	.2429	.2286	.3429		.2429	.4287
16	.3052	.2429	.2286	.4287		.2429	.4287
17	.39	.2429		.3429		.2429	.4287
18	.4239	.2429		.362		.2429	.5249
19	.4287			.543		.2486	.5487
20		.2429		.5792		.2486	.5487
21	.3658	.5182		.543		.2486	.5487
22	.362	.5182		.4525		.2486	.4572
23	.362	.5182		.4163		.2486	.3658
24	.4858	.2715	.4858	.2286	.3658		.2429
Max	.4858	.6001	.4858	.5792	.724	.2486	.5487
Min	.3052	.2429	.2286	.2286	.362	.2429	.2429
Avg	.4197	.3498	.2929	.3677	.4780	.2451	.3715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194058 / 33/11 KV SUB-STATION PADOLI

Feeder No / Name : 201 / 11 KV PADOLI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3776		.3381			.3765
2	.4175		.3765			.3768
3			.3772			.4899
4	.5292		.811			.7552
5	.9099		.9649			.9629
10		1.5422		1.5833	1.6137	1.8785
11				1.9083	1.9502	2.0217
12				1.8589	1.8229	1.861
13				1.6099	1.7966	1.7604
14		1.6149		1.5642	1.5165	1.5244
15		1.6704		1.6	1.6208	1.5021
16		1.9159		1.7206	1.729	1.6
17		1.8816		1.732		1.6747
18		.4307	.48		.5164	.4933
19					.5975	
20				.9946	.9571	1.0321
21		.64		.9412	.8232	.9063
22		.6174	.5212	.8641	.5601	
23		.5255		.4615	.5041	
24	.4154		.3381			.3953
Max	.9099	1.9159	.9649	1.9083	1.9502	2.0217
Min	.3776	.4307	.3381	.4615	.5041	.3765
Avg	.5299	1.2043	.5259	1.4032	1.2314	1.1536

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194058 / 33/11 KV SUB-STATION PADOLI

Feeder No / Name : 203 / 11 KV NAIGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3545		1.5674			1.5261
2			1.5674			1.5565
3	1.3757		1.5728			1.5687
4	1.4787		1.6613			1.5993
5	1.5424		1.8359			1.617
6	2.207		2.4112			2.32
7			2.5863			2.4946
8			2.4726	2.3979		2.3423
9			2.4267	2.0053		2.2068
10		.7499		.789	.944	.7545
11		.4658		.7138	.6776	.7514
12		.4435			.4133	.6575
13				.473	.3753	.4715
14		.4344		.3727	.0372	.4739
15		.4066		.412	.3347	.4725
16		.4087		.5956	.3925	.472
17		.4606		.4677	.3677	.4501
18			.5159		.4736	.452
19					.7461	
20		1.4046		1.319	1.3429	1.5059
21		1.1191		1.3203	1.0103	1.1248
22		.7818		1.1305	.7491	.7438
23		.6568		.7484	.526	
24	1.3549		1.5674			1.5518
Max	2.207	1.4046	2.5863	2.3979	1.3429	2.4946
Min	1.3545	.4066	.5159	.3727	.0372	.4501
Avg	1.5522	.6665	1.8350	.9804	.5993	1.2324

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194063 / 33/11 KV SUB-STATION

KHAMASWAD

Feeder No / Name : 202 / 11 KV KHAMASWADI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3343	.421	.3071	.4973	.3075	.4915	.3374
2	1.3036	.4096	.3067	.4641	.3075	.4807	.3067
3	1.2269	1.3279	1.2269	1.065	1.0455		.9509
4	1.3069	1.4746	1.3036	1.1336	1.107	1.3032	.9994
5	1.3069	1.6385	1.3803		1.1531	1.3904	1.23
6	1.3376	1.8515	1.6104	1.3108	1.4606	1.8275	1.599
7	1.382	1.9559	1.6104	1.7444	1.5375	1.9448	1.4606
8	1.382	1.9281	1.5337	1.8623	1.5375	1.933	1.5375
9	1.4588	1.6451	1.6194	1.5384	1.3343	1.9271	1.5702
10	1.5061	1.6124	1.6604	1.5375	1.3803		1.6766
11	.3086		.2561	.2761		.2303	.2591
12	.2883		.2785	.3067	.246	.2761	.2401
13	.3018	.3071	.3521	.3374	.2458	.3067	.253
14	.583	.3075	.2321		.2458	.3374	.25
15	.2743	.3382	.2486		.2214	.3075	.2883
16	.2058	.3071	.2683		.2187	.3075	.2743
17	.2515	.2457			.2241	.2761	.2743
18	.2591			.4305	.2469	.3075	
19	.2881	.492	.2721	.4612	.3403	.492	.373
20	.4096		.57	.4618	.5609	.492	.695
21			.6588	.3849	.583	.4305	.7059
22	.5121		.6173	.3844	.5596	.3834	.5316
23				.3382	.5182	.3834	
24	1.4127	.4321	.3378	.5365	.502		.3378
Max	1.5061	1.9559	1.6604	1.8623	1.5375	1.9448	1.6766
Min	.2058	.2457	.2321	.2761	.2187	.2303	.2401
Avg	.8473	.9820	.7929	.7932	.6906	.7537	.7341

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194063 / 33/11 KV SUB-STATION

KHAMASWAD

Feeder No / Name : 203 / 11 KV BANJARA FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1227	1.2651	1.107	1.2498	1.1084	1.1439	1.1531
2	.1075	1.2334	1.0749	1.2186	1.107	1.0957	1.1546
3	.1075	.112	.1227	.0894	.1227	.1094	.1537
4	.1228	.1107	.1534	.0894	.1227	.1107	.1537
5	.1524	.1619	.1534	.0907	.1536	.16	.1847
6	.1536	.1802	.1534	.12	.1537	.2096	.1539
7	.123	.1966		.1734	.1537	.2286	.1232
8	.1228	.1739	.1227	.2096	.123	.1905	.1537
9		.1532	.1296	.1905	.1074	.1734	.1228
10	.128	.1225	.1389	.1537	.1074	.123	.1311
11	.1492	.1075	.1265	.123	.1076	.123	.112
12	.128	.1074	.128	.123	.1227	.1076	.1107
13	.1296	.1075	.1021	.1074	.0926	.1228	.092
14	.128	.1075	.1021		.0926	.1228	.0907
15	.0907		.0766		.0857	.1537	.0766
16	.0894		.0777		.0987	.1537	.0766
17	.1006	.092	.0638	.1076	.1	.1537	.0766
18	.0894	.092	.0638	.123	.1082	.1847	.0686
19			1.4083	1.3069	1.8244	1.5682	1.6604
20			1.5432	1.3872	1.4815	1.4606	1.4842
21			1.4998	1.2639	1.3717	1.3239	1.4998
22	1.3735		1.1431	1.233	1.2342	1.3085	1.2483
23				1.1546	1.1584	1.3069	
24	.1227	1.3592	1.1685	1.2809	1.1288		1.2607
Max	1.3735	1.3592	1.5432	1.3872	1.8244	1.5682	1.6604
Min	.0894	.092	.0638	.0894	.0857	.1076	.0686
Avg	.1864	.3343	.4845	.5617	.5111	.5059	.4931

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194064 / 33/11 KV SUB-STATION

WAGHOLI(G

Feeder No / Name : 202 / 11 KV HALADGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3							.1905
4	.2286	.1905	.1905	.1905			
5							.2477
6	.381		.3048				
7						.1715	
8	.2858	.3048	.3239	.381	.362		.3048
10						.2896	
12	.8488	.8488	.5944			.8173	.7335
13					.679		
14						.6398	
15					.7186		
16	.9374	.743	.9031			.7385	.4801
18					.1715		
20		.381				.381	.381
23					.1905		
24	.1905	.1524	.1905	.1905	.1905	.1905	.1905
Max	.9374	.8488	.9031	.381	.7186	.8173	.7335
Min	.1905	.1524	.1905	.1905	.1715	.1715	.1905
Avg	.4787	.4368	.4179	.254	.3854	.4612	.3612

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194064 / 33/11 KV SUB-STATION

WAGHOLI(G

Feeder No / Name : 203 / 11 KV WAGHOLI-(G) FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3							.884
4	.9145	.9259	.8322	1.0031			
5							.9808
6	1.3272		1.2955				
7						1.5043	
8	1.1591	1.5051	1.3847	1.5623			1.5546
10						.1905	
12	.1905	.1905	.2858			.2096	
13					.5624		
14						.2477	
15					.2667		
16	.1905	.2286	.1905			.2477	.1905
18					.2667		
20		.381				.4191	.4572
23					.2667		
24	.7621	.7526	.9031	.8173		.4365	.8749
Max	1.3272	1.5051	1.3847	1.5623	.5624	1.5043	1.5546
Min	.1905	.1905	.1905	.8173	.2667	.1905	.1905
Avg	.7573	.6640	.8153	1.1276	.3406	.4651	.8237

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194066 / 33/11 KV SUB-STATION BHOGJI

Feeder No / Name : 201 / 11 KV BHOGJI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							1.1717
2							1.1717
3	1.0082						1.2492
4							1.2963
5							1.3592
6	1.3435			1.6667	1.9204		1.866
7				2.0241	2.0622		2.1214
8					1.6446		1.8724
9	1.9271			1.9925	1.6667		
10			1.7185				
13		1.1069					
16				.0762			
17			.0572	.0762		.0762	
18						.0762	
19						.1334	
20						.2286	
21						.1524	
22						.1143	
24	.9998			.578			1.1138
Max	1.9271	1.1069	1.7185	2.0241	2.0622	.2286	2.1214
Min	.9998	1.1069	.0572	.0762	1.6446	.0762	1.1138
Avg	1.3197	1.1069	.8879	1.0690	1.8235	.1302	1.4691

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194066 / 33/11 KV SUB-STATION BHOGJI

Feeder No / Name : 202 / 11 KV BHOGJI GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	23-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1143	.0953		.0953
2	.0953		.0953		.0953
3			.0953		.0953
4		.1905	.1524		.1524
5			.2286		.2858
6	.3429	.2858	.3239		.362
7			.3048		.362
8		.2477	.3048		.2286
9			.3048		
10	.1715	.1524			
12	.0953				
13		.1143			
15	.0953	.0953			
16				.0953	
17		.0953		.1143	
18				.1334	
19				.2096	
20				.2858	
21				.2286	
22				.1715	
24	.1143	.1143	.0953		.0953
Max	.3429	.2858	.3239	.2858	.362
Min	.0953	.0953	.0953	.0953	.0953
Avg	.1524	.1567	.2001	.1769	.1969

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194066 / 33/11 KV SUB-STATION BHOGJI

Feeder No / Name : 203 / 11 KV PIMPALGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1905			.1334		.0953
2	.1334			.1334	.1334		.0953
3		.1715			.1334		.1143
10	.9717	.8697	1.2029	1.0536			
11		1.4251					
12	1.3592	1.5074					
13			1.3592	1.2654			
14	1.2651	1.0686					
15		1.1265		1.2018			
16	1.2651			1.0802		1.3757	
17			1.3441	1.0279		1.3889	
18						.2667	
19						.3048	
20						.2477	
21						.2667	
22						.2858	
24	.1334	.1905		.1334	.1334		.0953
Max	1.3592	1.5074	1.3592	1.2654	.1334	1.3889	.1143
Min	.1334	.1715	1.2029	.1334	.1334	.2477	.0953
Avg	.8547	.8187	1.3021	.8422	.1334	.5909	.1001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194083 / 33/11 KV SUB-STATION MANGRUL

Feeder No / Name : 202 / 11 KV BHATSHIRPURA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4973	.3353	.3772	.3201	.2881	.6882	.4191
2	.3953	.3429	.3688	.373	.3201	.6882	.4334
3	.6464	.3582	.3647	.4586	.3521	.6962	.5201
4	.6062	.5258	.3932	.4527	.4534	.6962	.6268
5	.6962	.6068	.426	.6299	.4858	.6962	.7011
6	.7802	.7455	.6706	.6554	.5571	.6962	.7888
7	.823	.8402	.8573	.6401	.6554	.8383	.8886
8	.7461	.8573	.5935	.7127	.663	.7373	.6203
9	.6405	.7209	.5601	.5868	.6706	.6405	.5921
10	.1905	.1334		.1524		.1334	.1715
11	.1715			.1524	.1524	.1143	
12	.1334	.1143		.1524	.1143	.1143	
13	.1334	.1143	.0953	.1524	.1524	.1143	.1524
14	.1334	.1143	.0762	.1524	.1524	.0953	.1715
15	.1334	.1143		.1143	.1334	.0953	.1334
16	.1334	.1143	.0762	.1143	.1334	.1334	.1715
17	.1524	.1143	.0953	.0762	.1524	.1715	.1334
18	.1715	.1715	.1334	.1524	.1905	.1334	.1905
19	.2477			.1905	.3429	.2286	.2858
20		.381	.1524	.1524	.4001	.381	.3429
21	.2858	.3048	.1334	.1524		.2477	.4001
22	.2477	.2858	.1143	.1143		.1905	.1905
23	.1905	.2286	.0762	.253	.2667	.1715	.1715
24	.4588	.3018	.3467	.2713		.2753	.3277
Max	.823	.8573	.8573	.7127	.6706	.8383	.8886
Min	.1334	.1143	.0762	.0762	.1143	.0953	.1334
Avg	.3745	.3557	.3111	.2993	.3318	.3740	.3833

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194083 / 33/11 KV SUB-STATION MANGRUL

Feeder No / Name : 203 / 11 KV PIMPALGAON (D) SINGLE PHASING
 FEEDER Feeder KV- 11 /
 OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	.8288	.7545	.8886	.7682	.7545	.8097
2	.9391	.8478	.8383	1.166	.8421	.8383	.8288
3	.9448	.8478	.9221	.9779	.9069	.8383	1.2003
4	1.1022	1.0288	.9945	1.2887	.9717	.9221	1.4575
5	1.4403	1.2003	1.1603	1.4918	1.1934	1.1736	1.8176
6	1.7177	1.5432	1.7147	1.7857	1.4754	1.6289	1.9204
7	1.8054	1.7511	1.9071	1.8519	1.5939	1.8861	
8	1.6385	1.6991	1.4754	1.7635		1.8004	1.6124
9	1.4752	1.4922	1.4918	1.3077	1.2887	1.7147	1.576
10	1.1431	1.2003	1.3123	1.1065		1.012	1.2651
11	1.5935	1.3443	1.2742	1.4091	.0572	1.4083	1.3226
12	1.4842	1.3603	.9722	1.4251	.0572	1.3123	1.4413
13	1.358	1.2803	1.1523	1.3443	.7621	1.2308	1.2967
14	1.2346	1.2003	1.2003	1.0364	1.4883	1.1271	1.1873
15	1.2186	1.1523	1.1561	1.3123	1.4403	1.1111	1.1265
16	1.4403	1.2003	1.2334	1.3916	1.4403	1.1728	1.2003
17	1.358	1.406	1.2378	1.358	1.5203	1.3272	1.1883
18	.4268	.3498	.5144	.4161	.3628	.3612	.4409
19	.5864		.6485	.5548	.6485	.4915	.4588
20		.7087	.7522	.5144	.7087	.7522	.4586
21	.6379	.7011	.6733	.4973	.6733	.5935	.6274
22	.4588	.6516	.5921	.3887	.631	.5121	.4915
23	.426	.5144	.4752	.3239	.4458	.4801	.5087
24	.7122	.6478	.7122	.7202		.6882	.7116
Max	1.8054	1.7511	1.9071	1.8519	1.5939	1.8861	1.9204
Min	.426	.3498	.4752	.3239	.0572	.3612	.4409
Avg	1.1289	1.0851	1.0486	1.0967	.9179	1.0474	1.0847

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194019 / 33/11 KV Takali-B

Feeder No / Name : 201 / 11 Takali B.

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1311			.1696	.1715	.1753	.1526
2	.1658			.1823	.1715	.1734	.1543
3	.1989			.1696	.208	.208	.1886
4	.2321			.1844	.2427	.2743	.1928
5	.2294			.2058	.3121	.3121	.1696
6	.1989			.2035	.3086	.3086	.1696
7	.1526				.2743	.2743	.156
8	.1296		.2401	.2012	.2601	.2401	.1509
9	.0995		.208	.1715	.2427	.1658	.1063
10	.5426		.6379	.6859	.823	.5487	
11	.8669		.7522		1.0056	.7087	.815
12	.9431		.8413	.823	1.0631	.964	.9412
13	1.0749		.8745	.9945	1.1789	1.0745	.8859
14	1.0749		.9088	1.0288	1.1317	1.0166	.8063
15	.9362		.9816	1.0631	1.1096	1.0517	.823
16	1.1145		.9745	1.0402	1.0974		.763
17	1.1145		.9602	.9259		.8505	.9259
18	1.0402		.2155	.208		.2543	.285
19	.2267		.2347	.3155		.218	.2984
20				.3121		.218	.3391
21				.2774		.2035	.2984
22			.2012	.2427		.213	.285
23		.2774	.1989	.208	.2103	.2204	.2818
24	.1658		.2427	.1696	.208	.1734	.1844
Max	1.1145	.2774	.9816	1.0631	1.1789	1.0745	.9412
Min	.0995	.2774	.1989	.1696	.1715	.1658	.1063
Avg	.5319	.2774	.5648	.4447	.5566	.4281	.4075

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194019 / 33/11 KV Takali-B

Feeder No / Name : 203 / 11 KV Borkheda

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0829			.0671	.0686	.0686	.0503
2	.0829			.0678	.0693	.0693	.0509
3	.0995			.0678	.0693	.0693	.0995
4	.0983			.0829	.0867	.0857	.1006
5	.1147			.1006	.104	.12	.0848
6	.1187			.1357	.104	.12	.0857
7	.1187				.1214	.104	.1006
8	.0819		.1029		.1029	.1029	.1174
9	.0848		.1029	.0514	.0857	.0671	.0671
10	.4973		.583	.5487	.6173	.4801	.5144
11	.7455		.6443		.8916	.5721	.7537
12	.8495		.7373	.823	.9259	.691	.703
13	.8149		.7442	.9709	1.0056	.6516	.6762
14	.8149		.7716	.9945	.9945	.6556	.6104
15	.547		.823	.9945	.9709	.6001	.6516
16	.7373		.8954	.9709	.8916	.6001	.6443
17			.0829	.9259		.6556	.7545
18	.7291		.1174	.104		.1174	.0848
19	.1134		.1357	.1214		.116	.116
20			.1357	.1214		.1029	.1357
21			.116	.104		.1147	.1341
22				.1214		.0857	.1147
23		.1029	.1006	.104	.1052	.0838	.1174
24	.0663		.0867	.0848	.0867	.0876	.0655
Max	.8495	.1029	.8954	.9945	1.0056	.691	.7545
Min	.0663	.1029	.0829	.0514	.0686	.0671	.0503
Avg	.3578	.1029	.3862	.3601	.4056	.2676	.2847

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194026 / 33/11 KV POHNER SUB-STATION

Feeder No / Name : 203 / 11 KV RAGHUCHIWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
 FEEDER Feeder KV- 11 / DESIGN TRANSFORMER
 OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	1.2126	.9945	1.1948	1.2252	1.2372	1.2163	1.2698
11	1.2967	1.3923	1.4201	1.4209	1.4209	1.4266	1.3625
12	1.5565	1.3923	1.4403	1.5721	1.4689	1.533	1.4113
13	1.5418	1.3923	1.4636	1.5524	1.4618	1.5833	1.444
14	1.5203	1.4255	1.3347	1.5181	1.4805	1.5833	1.4009
15	1.4232	1.4255	1.3198	1.5089	1.4751	1.5833	1.4009
16	1.3832	1.4255	1.3069	1.4823	1.4751	1.587	1.387
17	1.4232	1.4255	1.2955	1.5524	1.5033	1.5546	1.3975
Max	1.5565	1.4255	1.4636	1.5721	1.5033	1.587	1.444
Min	1.2126	.9945	1.1948	1.2252	1.2372	1.2163	1.2698
Avg	1.4197	1.3592	1.3470	1.4790	1.4404	1.5084	1.3842

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194026 / 33/11 KV POHNER SUB-STATION

Feeder No / Name : 205 / 11 KV GAOSUD GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.132	.1132	.129	.1867	.1319	.1494
2	.1323	.1323	.1132	.1481	.1478	.1323	.1494
3	.112	.1128	.1132	.1304	.1478	.1132	.1494
4	.1303	.1314	.0943	.1307	.1867	.1307	.1886
5	.128	.1498	.0943	.1694	.1867	.1456	.2263
6	.1472	.1501	.0943	.1846	.2263	.1646	.2275
7	.1478	.1504	.0943	.2035	.1867	.1675	.2474
8		.1318	.0943	.1662	.1478	.1494	.2275
9	.1506	.132	.0943	.1483	.1478	.1268	.1886
10	.1092	.1132	.1029	.0919	.1264	.1079	.0912
11	.0905	.1132	.0916	.1095	.1101	.0915	.0926
12	.0722	.1132	.0922	.1068	.0894	.1108	.0879
13	.072	.1132	.0914	.1068	.0895	.1109	.0886
14	.072	.0943	.1039	.1063	.09	.0924	.0886
15	.0899	.0943	.1029	.0886	.0725	.0924	.1064
16	.0899	.0943	.1027	.0892	.0729	.1109	.1067
17	.0899	.0943	.0903	.1075	.1176	.1109	.1069
18		.0943	.1555	.1478	.1295	.1494	.1886
19	.1991	.1509	.1778	.2263	.1692	.2284	.2284
20	.1829	.1509	.198	.2263	.1791	.2284	.2284
21	.1839	.1509	.2001	.1867	.1655	.1867	.1886
22	.1667	.132	.1829	.1867	.1677	.1886	.1665
23	.168	.1132	.1641	.1867	.1498	.1867	.1498
24	.1507	.1498	.1132	.1471	.1867	.1506	.1494
Max	.1991	.1509	.2001	.2263	.2263	.2284	.2474
Min	.072	.0943	.0903	.0886	.0725	.0915	.0879
Avg	.1281	.1248	.1198	.1469	.1450	.1420	.1593

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194026 / 33/11 KV POHNER SUB-STATION

Feeder No / Name : 207 / 11 KV WALGUD GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0953	.0953	.0762	.0953	.0762
2	.0953	.0953	.0953	.0762	.0953	.0953	.0762
3	.0762	.0953	.0953	.0762	.0953	.0762	.0953
4	.0762	.0762	.0953	.0953	.1143	.0762	.1143
5	.0953	.0762	.0762	.0953	.1143	.0953	.1143
6	.0953	.1143	.0762	.0953	.1334	.0953	.1334
7	.0953	.1143	.0762	.0953	.1334	.1143	.1524
8		.1143	.0762	.0953	.1143	.0953	.1143
9	.1143	.0953	.0762	.0762	.0953	.0953	.0953
10	.0762	.0953	.0953	.0953	.0762	.0572	.0572
11	.0762	.0953	.0762	.1143	1.4209	.0572	.0762
12	.0572	.0762	.0762	.0762	.0572	.0762	.0762
13	.0572	.0762	.0762	.0762	.0572	.0762	.0762
14	.0762	.0762	.0762	.0762	.0762	.0762	.0762
15	.0762	.0762	.0762	.0762	.0762	.0762	.0762
16	.0762	.0762	.0762	.0762	.0762	.0762	.0762
17	.0762	.0762	.0762	.0762	.0762	.0762	.0762
18	.0953	.0762	.0953	.0953	.0953	.0953	.0953
19	.1334	.1143	.1334	.1143	.1334	.1334	.1334
20	.1143	.1143	.1334	.1334	.1143	.1524	.1524
21	.1143	.1143	.1143	.1143	.1143	.1334	.1334
22	.1143	.1143	.1143	.1143	.0953	.1334	.1143
23	.0953	.1143	.0953	.0953	.0953	.1143	.0953
24	.0953	.0953	.1143	.0953	.0762	.0953	.0953
Max	.1334	.1143	.1334	.1334	1.4209	.1524	.1524
Min	.0572	.0762	.0762	.0762	.0572	.0572	.0572
Avg	.0903	.0945	.0913	.0929	.1505	.0945	.0992

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194026 / 33/11 KV POHNER SUB-STATION

Feeder No / Name : 208 / 11 KV POHNER GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.2858	.3429	.2858	.1905	.2858	.1905
2	.2667	.2858	.3429	.3048	.1905	.2858	
3	.2667	.3048	.3429	.2858	.1905	.3048	.2286
4	.3239	.3429	.3429	.3429	2.2862	.3429	.2667
5	.381	.4191	.3048	.4001	.2667	.362	.3048
6	.4382	.4382	.3048	.4572	.3048	.4001	.3429
7	.4382	.4572	.3048	.5144	.2667	.4763	.3429
8		.381	.3048	.4572	.2286	.4382	.3048
9	.2858	.3048	.3048	.381	.1905	.2477	.2286
10	.1905	.3048	.1524	.1524	.1905	.2096	.1905
11	.1524	.2667	.1143	.1524	.1524	.2096	.1524
12	.1524	.2667	.1524	.1524	.1524	.1905	.1524
13	.1524	.2667	.1524	.1143	.1524	.2286	.1524
14	.1524	.2286	.1524	.1143	.1524	.2286	.1524
15	.1524	.2286	.1524	.1524	.1524	.2286	.1524
16	.1524	.2286	.1524	.1524	.1524	.2286	.1524
17	.1524	.2286	.1905	.1524	.1905	.2286	.1524
18	.2858	.2286	.362	.2286	.381	.2667	.3429
19	.4382	.381	.4763	.3048	.4763	.3429	.4382
20	.4763	.381	.5144	.3429	.5144	.3429	.5144
21	.4382	.381	.4763	.3048	.4572	.3048	.4763
22	.4001	.381	.4001	.2667	.4382	.2667	.4382
23	.362	.381	.362	.2286	.362	.2286	.381
24	.3429	.3239	.381	.3239	.1905	.3239	.1905
Max	.4763	.4572	.5144	.5144	2.2862	.4763	.5144
Min	.1524	.2286	.1143	.1143	.1524	.1905	.1524
Avg	.2916	.3207	.2953	.2739	.3429	.2905	.2717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194027 / 33/11 KV BEMBALI S/SN

Feeder No / Name : 201 / 11 KV BEMBALI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.6668	.5716	.5716	.5716	.724	.5716
2	.6097	.6668	.5716	.5716	.7049	.7621	.5716
3	.5716	.7621	.5716	.5716	.8002	.7621	.5716
4	.5525	.7621	.5716	.5716	.8192	.8002	.5716
5	.6478	.8002	.6478	.6668	.8573	.8573	.6668
6	.6668	.8573	.724	.7621	.9526	.8573	.7621
7	.743	.9145	.7621	.8764	1.0479	.8764	.8573
8	.8383	.9526	.8002	1.0098	1.0479	.9145	.9145
9	.8954	.9717	.8573	1.0288	1.0669	.9145	.9526
10	.4954	.6668		.381		.381	.381
11	.4954	.381	.381	.4763	.5335	.4191	.4239
12	.4954	.381	.5716	.5335	.5335	.4763	.4917
13	.5144	.381	.4763	.5144	.5144	.5144	.5087
14		.381	.381	.5335	.5335	.381	.5087
15		.4763	.381	.5716	.5335	.381	.4917
16		.5335	.381	.5716	.5335	.381	.4917
17		.5716	.4572	.5716	.4763	.4191	.4917
18		.5335	.5716	.6097	.4954	.4954	.5426
19	.8573	.6097	.6478	.7049		.4763	.6274
20	.8573	.6668	.724	.8002		.6097	.6952
21	.8573	.724	.7621	.8002		.724	.7461
22	.7621	.7621	.7621	.7811		.7621	.7122
23	.6668	.6668	.6668	.7811		.6668	.6783
24	.5335	.5716	.5716	.5716	.4763	.6668	.5716
Max	.8954	.9717	.8573	1.0288	1.0669	.9145	.9526
Min	.4954	.381	.381	.381	.4763	.381	.381
Avg	.6648	.6525	.6006	.6597	.6944	.6343	.6168

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194027 / 33/11 KV BEMBALI S/SN

Feeder No / Name : 205 / 11 KV Ambewadi GaothAn

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0572	.0572	.0572	.0572	.0572
2	.0572	.0572	.0572	.0572	.0572	.0572	.0572
3	.0572	.0572	.0572	.0572	.0572	.0572	.0572
4	.0572	.0572	.0572	.0572	.0572	.0572	.0572
5	.0762	.0762	.0762	.0762	.0762	.0762	.0762
6	.0762	.0953	.0762	.0953	.0953	.0953	.0953
7	.0762	.0953	.0572	.0762	.0762	.0953	.0762
8	.0572	.0762	.0381	.0762	.0762	.0762	.0762
9	.0762	.0572	.0381	.0572	.0762	.0762	.0572
10	.0381	.0572	.0381	.0191	.0381	.0381	.0381
11	.0381	.0381	.0381		.0381	.0381	.0339
12	.0381	.0381	.0381	.0572	.0381	.0381	.0339
13	.0381	.0381	.0381	.0572	.0381	.0381	.0339
14		.0381	.0381	.0572	.0381	.0381	.0339
15		.0381	.0381	.0572	.0381	.0381	.0339
16		.0381	.0381	.0572	.0381	.0381	.0509
17		.0572	.0381	.0762	.0381	.0381	.0509
18		.0572		.0762	.0572	.0381	.0678
19	.0953	.0762	.0572	.0762		.0953	.0678
20	.0953	.0762	.0762	.0762		.0953	.0848
21	.0953	.0762	.0762	.1143		.0762	.0848
22	.0762	.0572	.0762	.0762		.0762	.0678
23	.0762	.0572	.0572	.0762		.0572	.0509
24	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Max	.0953	.0953	.0762	.1143	.0953	.0953	.0953
Min	.0381	.0381	.0381	.0191	.0381	.0381	.0339
Avg	.0652	.0596	.0530	.0671	.0552	.0603	.0584

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194027 / 33/11 KV BEMBALI S/SN

Feeder No / Name : 207 / 11 KV Vtthalwadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.381	.381	.381	.4382	.381	.381
2	.4572	.381	.381	.381	.4572	.381	.381
3	.4763	.4191	.381	.381	.4763	.4001	.381
4	.4382	.4191	.381	.381	.4763	.4191	.381
5	1.8099	.4572	.4191	.4572	.4763	.4572	.4763
6	.4191	.4572	.4572	.4954	.4763	.4763	.5335
7	.4763	.5335	.4763	.5335	.5525	.4954	.5716
8	.5525	.5716	.5144	.5906	.5906	.4763	.5716
9	.5716	.5716	.5144	.6097	.4572	.4763	.5716
10	.0572	.0572		.0572	.0572	.0572	.0762
11	.0572	.0381		.0762	.0572	.0572	.0678
12	.0572	.0381	.0572	.0762	.0572	.0572	.0678
13	.0572	.0381	.0381	.0572	.0762	.0762	.0678
14		.0381	.0381	.0762	.0762	.0572	.0678
15		.0381	.0381	.0572	.0762	.0381	.0678
16		.0572	.0572	.0572	.0762	.0381	.0678
17		.0572	.0762	.0762	.0762	.0381	.0678
18		.0953	.0953	.0953	.0762	.0762	.0678
19	.1334	.1143	.1143	.1334		.1334	.0678
20	.1524	.1334	.1524	.1905		.1524	.1357
21	.1524	.1524	.1334	.1334		.1334	.1696
22	.1334	.1143	.1334	.1143		.1143	.1357
23	.1334	.0953	.0953	.1143		.0953	.1017
24	.3239	.381	.381	.381	.1905	.4763	.381
Max	1.8099	.5716	.5144	.6097	.5906	.4954	.5716
Min	.0572	.0381	.0381	.0572	.0572	.0381	.0678
Avg	.3620	.2350	.2416	.2461	.2747	.2318	.2441

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194036 / 33/11 KV KESHEGAON S/S

Feeder No / Name : 201 / 11 KV KESHEGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	23-MAY-17	25-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16		1.4232	1.0212	1.166
18	.6097			
Max	.6097	1.4232	1.0212	1.166
Min	.6097	1.4232	1.0212	1.166
Avg	.6097	1.4232	1.0212	1.166

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194036 / 33/11 KV KESHEGAON S/S

Feeder No / Name : 202 / 11 KV KESHEGAON GOATHAN
FEEDER Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	23-MAY-17	24-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.4374		.3963
16			.176	
18	.2401			
23	.3437		.3841	
24		.3437		.3437
Max	.3437	.4374	.3841	.3963
Min	.2401	.3437	.176	.3437
Avg	.2919	.3906	.2801	.37

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194036 / 33/11 KV KESHEGAON S/S

Feeder No / Name : 203 / 11 KV BAMNI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.8004	2.0195	1.7985	1.8176	1.9624	1.7528
18		.048				
23		.048			.048	
24		1.1812	.7621	1.2174	1.3375	.8002
Max	1.8004	2.0195	1.7985	1.8176	1.9624	1.7528
Min	1.8004	.048	.7621	1.2174	.048	.8002
Avg	1.8004	.8242	1.2803	1.5175	1.1160	1.2765

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194047 / 33 KV WADGAON (S)

Feeder No / Name : 203 / 11 KV BAVI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9078		.4676	.8688	.8551	.9069	.8642
2	.9078		.4697	.9335	.8878	.9088	.8596
3	.8897		.4619	.9383	.8743	.9521	.8363
4	.8697		.4956	.9659	.9164	1.0501	.8733
5	.9714		.5975	.9451	1.0387	1.118	.9193
6	1.4509		.8847	1.4509	1.5451	1.4103	1.3003
7	1.5089			1.4638	1.773	1.5608	1.5828
8	1.3471	1.4435	.6691	1.4075	1.4578	1.3457	1.4306
9	1.6718	1.267	1.5796	1.2124	1.2111	1.3003	
10		1.1285	1.4578	.4701	.3353	.476	
11	.4266	.2993	1.3553	.4353		.4237	
12	.3769	.3521	1.1106	.418		.4011	
13	.3737	.3179	1.0259	.4185	.2718	.399	
14	.1757	.3009	.3915	.3999	.2729	.3677	
15	.1608	.3025	.415	.399	.3961	.4141	
16	.3574	.3737	.4563	.4376	.4284	.4362	
17		.1212	.4871	.4785	.4492	.4549	
18		.1581	.5804	.6845		.5148	
19		.8229	.8145	.6791	.749	.724	
20		.8707	.8368	.8551	.9105	.9204	
21		.6331	.695	.7362	.6168	.757	
22		.5664	.6344	.6201	.5652	.6368	
23		.535	.4784	.5247	.5149	.5601	
24	.8816		.1958		.8532	.904	.9097
Max	1.6718	1.4435	1.5796	1.4638	1.773	1.5608	1.5828
Min	.1608	.1212	.1958	.399	.2718	.3677	.8363
Avg	.8299	.5933	.7200	.7714	.8058	.7893	1.0640

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194052 / 33 KV S/SN ,RUIBHAR

Feeder No / Name : 203 / 11 KV Ruibhar Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2058	.2241	.2241	.2058	.2241	.2134
2	.1886	.2058	.2218	.1867	.2058	.1867	.2134
3	.1867	.2058	.2241	.1867	.2058	.1867	.1829
4	.2241	.2401	.2218	.2241	.2401	.2241	.1829
5	.2587	.2743	.2241	.2614	.2401	.2614	.1829
6	.3018	.3086	.2587	.2987	.2743	.2987	.2439
7	.2926	.3086	.2957	.2987	.3086	.2987	.2439
8	.2561	.2401	.2614	.2241	.2743	.2987	.2439
9	.2195	.2058	.2614	.2241	.2241	.2614	.1829
10	.1543	.1886	.2241	.1372	.1867	.1524	.1867
11	.1543	.1886	.1867	.1372	.1494	.1524	.1867
12		.1509	.1867	.1372	.1494	.1524	.1867
13	.1715	.1494	.1494	.1372	.1494	.1524	.1867
14		.1509	.1494	.1715	.1494	.1524	.1494
15		.1867	.1494	.1715	.1494	.1524	.1494
16		.1886	.1867	.1715	.1867	.1524	.1494
17		.1886	.1867	.2058	.1867	.1524	.1867
18		.2263	.2241	.2058	.2614	.1829	.1867
19	.3086	.2561	.2987	.1715	.2987	.2134	.2614
20	.3086	.2987	.2987	.3086	.3361	.2743	.2987
21	.2743	.2614	.2614	.3086	.2987	.2439	.2987
22	.2572	.2614	.2614	.2743	.2614	.2134	.2987
23	.2743	.2241	.2241	.2401	.2241	.2134	.2614
24	.2218	.2401	.2241	.2241	.2058	.2241	.2134
Max	.3086	.3086	.2987	.3086	.3361	.2987	.2987
Min	.1543	.1494	.1494	.1372	.1494	.1524	.1494
Avg	.2356	.2231	.2252	.2138	.2238	.2094	.2121

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194067 / 33/11 KV Ambejawalga

Feeder No / Name : 201 / 11 KV Ambejawalge Ag SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.5706	.721	.7856	.6459	.6348	.5792
2	.5487	.6087	.7926	.8221	.6459	.6363	.5792
3	.5487	.542	.7888	.9501	.6459	.7219	.5792
4	.5624	.9069	.8282	.678	.6459	.721	.6226
5	.6573	.9922	1.1619	.9854	.775	.7983	.8398
6	.6859	1.3184	1.2971	.9177	.8784	1.1591	1.1294
7	.8573	1.4617	1.4318	1.3611	1.0334	1.3443	1.2498
8		1.1241	1.2849	1.2746	1.0334	1.3062	1.2963
9	.8573	1.6251	1.3062	.8267	1.0334	1.2023	1.1873
15						.0381	
18	.0102	.0661		.0258	.0641	.0762	
19	.0424	.0604		.0517	.065	.0762	.0726
20		.063		.0517	.0656	.0762	
21		.0635		.0517	.0651	.0572	
22		.0642		.0517	.0657	.0762	
23	.0423	.0656	.066	.0517	.0658	.0762	.0682
24	.5144	.7983	.6738	.6592	.6459	.6569	.5792
Max	.8573	1.6251	1.4318	1.3611	1.0334	1.3443	1.2963
Min	.0102	.0604	.066	.0258	.0641	.0381	.0682
Avg	.4896	.6457	.9411	.5966	.5234	.5681	.7319

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194067 / 33/11 KV Ambejawalga

Feeder No / Name : 202 / 11 KV Ghatangri Ag.

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0457	.0736	.0604	.0484	.0635	.0648	.0419
2	.0457	.0479	.0601	.0636	.0635	.065	.0419
3	.0457	.0682	.0614	.0662	.0635	.0658	.0419
10		1.5693			.7142	1.1309	1.1736
11	1.587	1.6703	1.6683	1.587	1.7016	1.6446	1.3641
12	1.6664	1.4688	1.648	1.7775	1.6208	1.6446	1.3154
13	1.587	1.5583	1.6113	1.8251	1.568	1.6446	1.3811
14	1.5553	1.5674	1.0726	1.7457	1.3347	1.5851	1.4519
15	1.5077	1.6118	1.7218	1.6664	1.4435	1.5851	1.5232
16	1.4283	1.6703	1.8075	1.6664	1.2986	1.5851	1.7071
17	1.7457	1.6347	1.7798	1.6664	1.6137	1.5851	2.0288
18	.0108	.0637	.0431	.0321	.0648	.0305	.066
19		.0657		.0635	.0641	.0328	.0678
20		.0631		.0635	.0639	.0328	
21		.0638		.0635	.0642	.0328	
22		.0642		.0635	.0631	.0419	
23	.0658	.0652	.0657	.0635	.0654	.0419	.0731
24	.0457	.0648	.065	.0658	.0635	.066	.0404
Max	1.7457	1.6703	1.8075	1.8251	1.7016	1.6446	2.0288
Min	.0108	.0479	.0431	.0321	.0631	.0305	.0404
Avg	.8721	.7440	.8973	.7369	.6630	.7155	.8212

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194067 / 33/11 KV Ambejawalga

Feeder No / Name : 203 / 11 KV Sonegaon Ag. SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7926	.6622	.9037	.7385	.2409	.7227	1.3717
2	.7926	.8861	.909	.4661	.2409	.7262	1.3717
3	.823	.8535	.9774	.8194	.2409	.8126	1.3717
4	.823	.8899	.9854	.7838	.2409	.849	1.4022
5	.945	.9488	1.1469	1.2825	.2409	.9694	1.3717
6	1.1888	1.2236	1.3715	.9678	.2409	1.2221	1.3717
7	1.1888	1.3427	1.4469	1.5821	.2409	1.3138	1.4232
8		1.6028	1.5127	1.1258	.6746	1.3062	1.4419
9	1.2955	.9877	1.4351	1.044	.7709	1.3016	1.278
18	.0165	.0325	.0727	.0161	.0635	.0381	
19		.0325		.0321	.0316	.0381	.0751
20		.0322		.0321	.032	.0381	
21		.0328		.0321	.0327	.0381	
22		.0369		.0321	.0328	.0381	
23	.759	.0328	.005	.0321	.0327	.0381	.0341
24	.8124	1.0951	.925	.6104	.2409	.6531	1.3717
Max	1.2955	1.6028	1.5127	1.5821	.7709	1.3138	1.4419
Min	.0165	.0322	.005	.0161	.0316	.0381	.0341
Avg	.8579	.6683	.9743	.5998	.2249	.6316	1.1571

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194067 / 33/11 KV Ambejawalga

Feeder No / Name : 204 / 11 KV Ambejawalga Gaothan

GAOTHAN FEEDER

Fee Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.0987	.1121	.1004	.1126	.1131	.1132
2	.1132	.0989	.112	.1318	.1126	.1129	.1132
3	.1132	.1318	.1124	.057	.1126	.1133	.1132
4	.1132	.1425	.1126	1.3184	.1314	.1137	.1132
5	.1509	.1701	.1131	1.0044	.1501	.1135	.1509
6	.2075	.1637	.1507	.1021	.1877	.1886	.1886
7	.1886	.1591	.1498	.2042		.1501	.1886
8		.0867	.1483	.2142		.1495	.1494
9	.132	.1488	.1483	.1126	.1314	.1129	.1109
10			.1123	.1126	.1124	.112	.0934
11	.1126		.112	.1126	.1111	.0934	.0989
12	.0751		.0993	.0938	.1112	.0914	.0989
13	.1126	.1124	.1021	.0938	.1121	.0914	.132
14	.1126	.1121	.1024	.0938	.112	.0914	.1318
15	.1126	.1119	.1097	.0938	.0748	.0914	.1366
16	.1126	.1126	.1318	.0938	.0751	.0914	.1021
17	.1126	.1128	.0989	.0938	.1127	.0914	.1471
18	.1154	.1121	.1318	.1126	.1124	.1029	.1259
19	.1154	.1497	.1648	.1501	.1867	.1494	.1839
20	.1648	.1863	.2193	.2252	.1884	.1867	.1873
21	.1648	.1869	.1707	.1877	.1856	.1867	.1498
22	.1318	.1501	.1318	.1501	.1494	.1698	.1021
23	.1318	.1504		.1126	.1121	.132	.1024
24	.132	.102	.1131	.1	.1126	.1132	.1132
Max	.2075	.1869	.2193	1.3184	.1884	.1886	.1886
Min	.0751	.0867	.0989	.057	.0748	.0914	.0934
Avg	.1290	.1333	.1287	.2113	.1276	.1234	.1311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194067 / 33/11 KV Ambejawalga

Feeder No / Name : 205 / 11 KV Ghatangri Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0799	.0742	.132	.0534	.0745	.0566
2	.0747		.0742	.1103	.0534	.0748	.0566
3	.0747	.099	.0745	.0987	.0534	.0747	.0566
4	.0747	.0733	.0742	.1069	.0713	.0748	.0566
5	.112	.1024	.1118	.1468	.0891	.1118	.0943
6	.1509	.121	.1495	.1096	.1425	.1495	.132
7	.1509	.0802	.1126	.0181	.1781	.1494	.1509
8		.132	.0748	.1648	.1069	.1107	.1307
9	.0754	.111	.0741	.0713	.0713	.073	.0934
10		.0373	.0747	.0534	.0534	.0371	.0566
11	.0713	.0369	.0373	.0534	.0363	.0701	.0495
12	.0713			.0356	.0361	.0732	.0546
13	.0534	.0368	.048	.0356	.0363	.0549	.0368
14	.0356	.0369	.0512	.0356	.0373	.0549	.0562
15	.0356	.037	.0512	.0356	.0369	.0549	.0728
16	.0356	.0372	.0512	.0534	.0368	.0732	.0751
17	.0534	.0711	.0683	.0713	.0732	.0732	.0751
18	.0892	.0703	.0993	.1425	.1091	.0905	.0936
19	.1328	.1072	.1471	.1425	.143	.1097	.1456
20	.102	.1459	.1656	.1425	.1445	.1267	.1024
21	.1324	.1466	.1364	.1069	.148	.1267	.1503
22	.111	.0737	.1318	.0713	.0738	.0914	.1096
23	.1119	.0738		.0534	.0745	.0739	.0659
24	.0747	.099	.074	.1004	.0534	.0745	.0754
Max	.1509	.1466	.1656	.1648	.1781	.1495	.1509
Min	.0356	.0368	.0373	.0181	.0361	.0371	.0368
Avg	.0863	.0822	.0889	.0872	.0797	.0866	.0853

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194067 / 33/11 KV Ambejawalga

Feeder No / Name : 206 / 11 KV Sonegaon Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0895	.0624	.1104	.1477	.0885	.0751	.0895
2	.0895	.076	.1107	.1472	.0885	.0748	.0895
3	.0895	.0759	.111	.1296	.0885	.0747	.0895
4	.0895	.1318	.1118	.1315	.1062	.0754	.0895
5	.1097	.1471	.1478	.1787	.1416	.1133	.1075
6	.1867	.1648	.1867	.2213	.177	.1504	.1433
7	.2054	.1648	.185	.1529	.2124	.1884	.1791
8		.1265	.1863	.2373	.177	.1861	.1867
9	.1494	.1469	.1453	.1416	.1416	.1115	.1294
10		.074	.1109	.1062	.1239	.0745	.0934
11	.0708	.0735	.0742	.0708	.0359	.0532	.0821
12	.0354		.0659	.0531	.0358	.052	.1453
13	.0531	.037	.066	.0531	.036	.0347	.1457
14	.0531	.0368	.0659	.0708	.0361	.052	.1477
15	.0531	.037	.0989	.0708	.0359	.052	.1069
16	.0708	.0739	.0989	.0708	.036	.0693	.1103
17	.0708	.0729	.0494	.0708	.0363	.0686	.1103
18	.0765	.0717	.0824	.1239	.0713	.0753	
19	.0754	.143	.1318	.1416	.1791	.1307	.132
20	.1909	.1804	.1648	.2124	.2144	.1265	.1978
21	.1257	.181	.132	.177	.1749	.1311	.1846
22	.1318	.1454	.0956	.1416	.1065	.12	.1318
23	.0956	.1104		.0885	.1107	.1029	.1127
24	.0895	.0743	.1071	.1324	.0885	.0738	.0895
Max	.2054	.181	.1867	.2373	.2144	.1884	.1978
Min	.0354	.0368	.0494	.0531	.0358	.0347	.0821
Avg	.1001	.1047	.1147	.1280	.1059	.0944	.1258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194088 / 33/11 KV CHILWADI SUB-STATION

Feeder No / Name : 201 / 11 KV CHILWADI AGRL.

FEEDER SEPERATION/PURE AG

FEEDER Feeder KV- 11 /
OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8666	.8193	.8351	.9454	.8981	.9454	.9454
2	.9454	.9454	.9454	.9454	1.0084	.9454	.9454
3	1.0557	1.0557	.9454	.9769	1.0714	.9769	.9454
4	1.1344	1.0872	.9454	1.0241	1.1659	1.0241	1.0714
5	1.2132	1.2762	1.1187	1.1029	1.229	1.1029	1.1029
6	1.292	1.3235	1.1975	1.2447	1.3077	1.2447	1.0714
7	1.355	1.2762	1.3865	1.418	1.4023	1.4338	1.418
8		1.4968	1.4653	1.4968	1.4811	1.4496	1.3708
9	1.2605	1.292	1.4811	1.4338	1.3393	1.2132	1.3708
24		.6618	.8351	.9296	.7878	.9296	
Max	1.355	1.4968	1.4811	1.4968	1.4811	1.4496	1.418
Min	.8666	.6618	.8351	.9296	.7878	.9296	.9454
Avg	1.1404	1.1234	1.1156	1.1518	1.1691	1.1266	1.1379

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194001 / 33KV S/S AAMRAI O'BAD

Feeder No / Name : 202 / 11 KV NEHARU CHOWK FEEDER SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.9156	.9503	.9175	.8848	.8688	.6554	.8078
16	.9012	.9503	.8192	.8848	.945	.9667	.8993
19	.9907	.9995	1.0978	1.2125	1.0059	1.1584	.9602
24	.8535	.8535	1.0212	1.065	.8535	.8383	.884
Max	.9907	.9995	1.0978	1.2125	1.0059	1.1584	.9602
Min	.8535	.8535	.8192	.8848	.8535	.6554	.8078
Avg	.9153	.9384	.9639	1.0118	.9183	.9047	.8878

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194001 / 33KV S/S AAMRAI O'BAD

Feeder No / Name : 203 / 11KV DARGA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	1.1142	1.0814	1.065	1.1305	1.0669	1.0212	1.0852
16	.9297	1.0159	1.0814	1.1633	1.0562	1.17	1.1305
19	1.2616	1.1736	1.4255	1.2944	1.3108	1.3717	1.3599
24	1.1797	1.1961	1.1797	1.2125	1.1736	1.0669	1.1797
Max	1.2616	1.1961	1.4255	1.2944	1.3108	1.3717	1.3599
Min	.9297	1.0159	1.065	1.1305	1.0562	1.0212	1.0852
Avg	1.1213	1.1168	1.1879	1.2002	1.1519	1.1575	1.1888

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194001 / 33KV S/S AAMRAI O'BAD

Feeder No / Name : 204 / 11KV TER FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	1.0229	.9145	.9012	.9339	.8993	.9389	.8688
16	.7209	.6554	.6554	.6554	.5639	.7045	.6401
19	.9326	.9831	.8684	.9012	.9221	.884	.8688
24	.6706	.6401	.7045	.7209	.5487	.7209	.7373
Max	1.0229	.9831	.9012	.9339	.9221	.9389	.8688
Min	.6706	.6401	.6554	.6554	.5487	.7045	.6401
Avg	.8368	.7983	.7824	.8029	.7335	.8121	.7788

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194001 / 33KV S/S AAMRAI O'BAD

Feeder No / Name : 205 / 11KV UPLA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	1.0822	1.0978	1.0978	1.0517	1.1142	1.0517	.9755
16	1.2289	1.1469	1.2289	1.3904	1.0974	1.2289	
19	1.2616	1.2717	1.3565	1.2452	1.1469	1.3599	1.3077
24	1.3927	1.4419	1.4255	1.4255	1.3748	1.3927	1.326
Max	1.3927	1.4419	1.4255	1.4255	1.3748	1.3927	1.326
Min	1.0822	1.0978	1.0978	1.0517	1.0974	1.0517	.9755
Avg	1.2414	1.2396	1.2772	1.2782	1.1833	1.2583	1.2031

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194001 / 33KV S/S AAMRAI O'BAD

Feeder No / Name : 206 / 11 KV VIP FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.4588	.4572	.4268		.4268	.3963	.4557
16	.4572	.5079			.442	.4725	.442
19	.381	.5407		.5407	.4752	.5639	.5895
24		.4725	.4424		.4268	.4268	.4915
Max	.4588	.5407	.4424	.5407	.4752	.5639	.5895
Min	.381	.4572	.4268	.5407	.4268	.3963	.442
Avg	.4323	.4946	.4346	.5407	.4427	.4649	.4947

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194001 / 33KV S/S AAMRAI O'BAD

Feeder No / Name : 209 / 11 kv New Shivaji Chouk

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	1.9006	1.7985	1.9498	1.7071	1.7833	1.7528	1.7071
16	2.4247	2.271	2.3266	2.5232	2.5095	2.2447	2.2552
19	2.6818	2.6052	2.5888	2.4082	2.3777	2.3167	2.364
24	2.2939	2.271	2.343	2.3594	2.1948	2.2253	2.271
Max	2.6818	2.6052	2.5888	2.5232	2.5095	2.3167	2.364
Min	1.9006	1.7985	1.9498	1.7071	1.7833	1.7528	1.7071
Avg	2.3253	2.2364	2.3021	2.2495	2.2163	2.1349	2.1493

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194001 / 33KV S/S AAMRAI O'BAD

Feeder No / Name : 211 / New CollecTtor Office

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.0572	.0271	.0406	.0492	.0457	.0429	.0572
16	.2294	.1858	.2134	.2286	.1829	.0714	.0457
19	.0934	.1	.1082	.1	.1143	.0724	.0572
24	.0564	.0406	.0492	.0541	.0429	.0286	.0714
Max	.2294	.1858	.2134	.2286	.1829	.0724	.0714
Min	.0564	.0271	.0406	.0492	.0429	.0286	.0457
Avg	.1091	.0884	.1029	.1080	.0965	.0538	.0579

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194033 / 33 KV MIDC S/S O'BAD

Feeder No / Name : 201 / 11 KV MIDC _I

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914		.1578	.1791	.1478
2	.0914		.1402	.181	.1478
3	.0905		.1402	.1448	.1478
4	.0914		.1402	.1448	.1478
5	.0914		.1753	.1448	.1463
6	.1086		.1949	.1448	.1478
7	.1629		.1949	.181	.1829
8	.181		.2103	.2534	.2534
9	.181		.2172	.2926	
10	.2353		.2896	.3658	
11	.2896		.362	.3696	
12	.2896		.362	.3696	
13	.2353		.2896	.3395	
14	.2172		.2534	.3292	
15	.2896		.2896	.3475	
16	.3258		.3258	.3511	
17		.2686	.2896		
18		.2427	.2353		
19		.298	.181		
20		.1886	.1448	.2054	
21		.1753	.1448	.1848	
22		.1772		.1463	
23		.1578	.1448		
24	.0924		.1578	.181	.1646
Max	.3258	.298	.362	.3696	.2534
Min	.0905	.1578	.1402	.1448	.1463
Avg	.1803	.2155	.2192	.2428	.1651

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194033 / 33 KV MIDC S/S O'BAD

Feeder No / Name : 202 / 11 KV DNYANESHWAR TEMPLE SHEDDABLE URBAN
TOWN Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5203		1.5203	1.5402	1.4842
2	1.3575		1.5203	1.5043	1.4118
3	1.3213		1.5203	1.5043	1.3575
4	1.3213		1.448	1.4327	1.3575
5	1.3213		1.4118	1.3969	1.267
6	1.2517		1.3756	1.3611	1.2178
7	1.3213		1.3575	1.3073	1.267
8	1.267		1.3756	1.3073	1.267
9	1.2894		1.4327	1.267	
10	1.3253		1.3611	1.1946	
11	1.3253		1.3253	1.267	
12	1.3611		1.3253	1.3032	
13	1.3611		1.3611	1.267	
14	1.3611		1.3611	1.3756	
15	1.3969		1.4327	1.448	
16	1.4685		1.5043	1.448	
17		1.4118	1.5043	1.3756	
18		1.448	1.4327		
19		1.6289	1.576		
20		1.8099	1.7193	1.6832	
21		1.7737	1.6476	1.7194	
22		1.7737		1.7013	
23		1.6655	1.6118		
24	1.5565		1.5927	1.576	1.5565
Max	1.5565	1.8099	1.7193	1.7194	1.5565
Min	1.2517	1.4118	1.3253	1.1946	1.2178
Avg	1.3604	1.6445	1.4660	1.4276	1.3540

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194033 / 33 KV MIDC S/S O'BAD

Feeder No / Name : 204 / 11KV MIDC -II FEEDER
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3582		.3544	.3582	.362
2	.3582		.3544	.3582	.3403
3	.3045		.2835	.3224	.3475
4	.3045		.2835	.3224	.3439
5	.3045		.2303	.3224	.3224
6	.3224		.2303	.2865	.3045
7	.3224		.2835	.3224	.3582
8	.3582		.3544	.3582	.394
9	.4298		.2865	.3582	
10	.5014		.3224	.3582	
11	.5014		.394	.4656	
12	.5731		.4298	.5014	
13	.5014		.3224	.3582	
14	.4298		.3224	.4298	
15			.4298	.4656	
16	.5014		.5014	.4835	
17		.4656	.5014		
18		.4252	.394		
19		.4252	.3224		
20		.4656	.2865	.4298	
21		.4298	.3582	.4477	
22		.4298		.4656	
23		.0351	.394	.4435	
24	.362		.4119	.3582	.394
Max	.5731	.4656	.5014	.5014	.394
Min	.3045	.0351	.2303	.2865	.3045
Avg	.4021	.3823	.3501	.3912	.3519

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194033 / 33 KV MIDC S/S O'BAD

Feeder No / Name : 205 / 11 KV AMBEJAWALAGA AG

FEEDER SEPERATION/PURE AG

FEEDER Feeder KV- 11 /
OUTGOING

DATE	22-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4062	.4938	.4938	.4321
2	.4012	.4938	.4938	.4321
3	.4012	.4938	.4938	.4374
4	.4012	.4938	.5556	.4321
5	.4012	.5401	.5556	.4938
6	.5401	.5864	.5864	.6173
7	.679	.7407	.6173	.6173
8	.679	.7407	.6481	.5401
9	.7099	.6944	.6481	
24	.4508	.4475	.4167	.4012
Max	.7099	.7407	.6481	.6173
Min	.4012	.4475	.4167	.4012
Avg	.5070	.5725	.5509	.4893

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194033 / 33 KV MIDC S/S O'BAD

Feeder No / Name : 206 / 11 KV CKT HOUSE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0648		.0648	.0663	.0648
2	.0648		.0648	.0663	.0648
3	.081		.0648	.0497	.0648
4	.081		.0648	.0497	.0648
5	.0648		.0648	.0497	.0648
6	.0648		.0648	.0497	.081
7	.0648		.0648	.0663	.081
8	.081		.0648	.0829	.081
9	.0663		.0829	.081	
10	.0497		.0829	.0972	
11	.0663		.0829	.081	
12	.0663		.0663	.0648	
13	.0663		.0829	.0492	
14	.0497		.0995	.081	
15	.0663		.0995	.081	
16	.0663		.116	.081	
17		.081	.1326	.081	
18		.081	.1492		
19		.1296	.116		
20		.1134	.0995	.0972	
21		.0972	.116	.0972	
22		.081		.0972	
23		.081	.0829		
24	.0648		.061	.0663	.0648
Max	.081	.1296	.1492	.0972	.081
Min	.0497	.081	.061	.0492	.0648
Avg	.0664	.0949	.0865	.0731	.0702

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194060 / 33KV TAMBARI SUB_STATION

O'BAD

Feeder No / Name : 201 / 11 KV TAMBARI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17
HR	Load (MW)	Load (MW)
12	.0171	
17		.0152
18		.0152
Max	.0171	.0152
Min	.0171	.0152
Avg	.0171	.0152

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194089 / 33/11 KV BEMBALI CORNER

OSMANA

Feeder No / Name : 201 / 11 KV wadaga Ag

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5249	.6193	.5153	.6786	.5745	.6273	.5377
2	.5361	.677	.5057	.7314	.5441	.6626	.5825
3	.5905	.5361	.5249	.7506	.6049	.6802	.653
4	.669	.5567	.6433	.7602	.5409	.6978	.6754
5	.6081	.5761	.6866	.7954	.685	.7346	.6978
6	.7506	.8418	.7794	.8066	.7426	.7458	.7298
7	.7938	.8706	.8034	.8274	.8338	.7618	.749
8		.8738	.877	.8946	.8386	.7778	.7714
9	.7042	.8898	.7362	.9378	.7922	.7794	.8066
10	.0096	.016	.0128	.0192	.0096	.0192	.0384
11	.0064	.0128	.0128	.0224	.0064	.0192	.0192
12	.0064	.0224	.0096	.0128	.0064	.0192	.0227
13	.0096	.0192	.0064	.016	.0064	.0192	.0192
14	.0096	.0128	.0064	.0192	.0064	.016	.016
15	.0096	.016	.0096	.0064	.0064	.016	.0096
16	.0064	.0192	.0096	.0048	.0096	.016	.0096
17	.0096	.0128	.0096	.0069	.0096	.016	.0064
18	.0128	.0096	.0128	.0192	.0224	.016	.0096
19	.016	.0096	.016	.016	.0352	.016	.016
20	.0192	.016	.0192	.0256	.0352	.0176	.0288
21	.0224	.0224	.0224	.0224	.0384	.0192	.0192
22	.0224	.0224	.0224	.0227	.0384	.0192	.0224
23	.0224	.0256	.0224	.032	.0384	.0192	.0224
24	.4993	.5185	.5121	.5073	.5057	.5393	.4641
Max	.7938	.8898	.877	.9378	.8386	.7794	.8066
Min	.0064	.0096	.0064	.0048	.0064	.016	.0064
Avg	.2547	.2999	.2823	.3306	.2888	.3023	.2886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194089 / 33/11 KV BEMBALI CORNER

OSMANA

Feeder No / Name : 202 / 11 KV Express WW

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 11 / OUTGOING

UTILITY

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0046	.0251	.0046	.0251	.0011	.0251	.0034
2	.0046	.024	.0263	.0251	.0023	.0034	.0023
3	.0023	.0229	.0274	.0251	.0023	.0034	.0023
4	.0057	.0229	.0274	.024	.0011	.0023	.0011
5	.0034	.0229	.0251	.024	.0034	.0023	.0011
6	.0023	.0229	.0217	.0229	.0011	.0023	.0011
7	.0206	.0217	.0217	.0023	.0011	.0023	.0011
8		.0023	.0011	.0011	.0217	.0011	.0251
9	.0246	.0023	.0011	.0011	.0206	.0011	.0217
10	.0229	.0046	.0217	.0023	.0206	.0023	.024
11	.0229	.0023	.0217	.0023	.0206	.0023	.0274
12	.0229	.0069	.0217	.0206	.0217	.0023	.0034
13	.0217	.0046	.0217	.0217	.0217	.0023	.0023
14	.0217	.0217	.0217	.0023	.0217	.0206	.0229
15	.0217	.0217	.0023	.0229	.0206	.0091	.0217
16	.0011	.0023	.0023	.0274	.0206	.0023	.0217
17	.0023	.0023	.0023	.0263	.0023	.0023	.0217
18	.0023	.0023	.0034	.0286	.0251	.0023	.0057
19	.0034	.0263	.0046	.0286	.0263	.0206	.0034
20	.0034	.0274	.0034	.0286	.0251	.0206	.0023
21	.0251	.0064	.0251	.0274	.0251	.0229	.0274
22	.0263	.0069	.0263	.0286	.0251	.0251	.0286
23	.0263	.0046	.0263	.0274	.0251	.0251	.0274
24	.0023	.0251	.0023	.0263	.0286	.0251	.0034
Max	.0263	.0274	.0274	.0286	.0286	.0251	.0286
Min	.0011	.0023	.0011	.0011	.0011	.0011	.0011
Avg	.0128	.0139	.0151	.0197	.0160	.0095	.0126

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 198002 / 220 KV OSMANABAD S /

STATION

Feeder No / Name : 401 / 33 KV OSMANABAD

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / INCOMING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	6.685	6.9696	6.3557	6.4392	7.0199	6.941	5.807
16	7.4269	7.2257	6.9799	7.0416	6.5844	6.4015	5.3041
19	7.8647	8.2579	7.2245	7.4531	8.139		7.0416
24	7.0782	7.029	7.0782	6.6758	6.5844	7.6189	7.0416
Max	7.8647	8.2579	7.2245	7.4531	8.139	7.6189	7.0416
Min	6.685	6.9696	6.3557	6.4392	6.5844	6.4015	5.3041
Avg	7.2637	7.3706	6.9096	6.9024	7.0819	6.9871	6.2986

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 198002 / 220 KV OSMANABAD S /

STATION

Feeder No / Name : 405 / 33 KV POHNER

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0463	.0457	.0457	.0457	.0463	.0457	.0457
2	.0463	.0457	.0457	.0457	.0463	.0457	.0457
3	.0463	.0457	.0457	.0457	.0463	.0457	.0457
4	.0463	.0457	.0457	.0457	.0463	.0457	.0457
5	.0463	.0457	.0457	.0457	.0463	.0457	.0457
6	.0463	.0457	.0457	.0457	.0463	.0457	.0457
7		.0457	.0457	.0457	.0463	.0514	.0457
8		.0457	.0457	.0457	.0463	.0457	.0457
9		.0457	.0463	.0514	.0463	.0463	.0457
10		.0457	.0463	.0457	.0457	.0463	.0457
11	.0457	.0457	.0463	.0457	.0457	.0463	.0457
12	.0457	.0457	.0463	.0457	.0457	.0463	.0457
13	.0514	.0457	.0463	.0457	.0457	.0463	.0457
14	.0514	.0457	.0463	.0457	.0457	.0463	.0457
15	.0457	.0457	.0463	.0457	.0457	.0463	.0457
16	.0457	.0514	.0463	.0463	.0457	.0463	.0457
17	.0457	.0457	.0457	.0463	.0457	.0457	.0463
18	.0457	.0457	.0457	.0463	.0457	.0457	.0463
19	.0457	.0457	.0457	.0463	.0457	.0457	.0463
20	.0457	.0457	.0457	.0463	.0457	.0457	.0463
21	.0457	.0457	.0457	.0463	.0457	.0457	.0463
22	.0457	.0457	.0457		.0457	.0457	.0463
23	.0457	.0457	.0457		.0457	.0457	.0463
24	.0463	.0457	.0457	.0457	.0463	.0457	.0457
Max	.0514	.0514	.0463	.0514	.0463	.0514	.0463
Min	.0457	.0457	.0457	.0457	.0457	.0457	.0457
Avg	.0465	.0459	.0459	.0461	.0460	.0461	.0459

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 198002 / 220 KV OSMANABAD S /

STATION

Feeder No / Name : 407 / 33 kV MIDC

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			2.5069	
9		2.6052		
10	3.0121			
12	3.3425	3.1579		
16		3.3425		
24		1.4295	2.4291	1.6524
Max	3.3425	3.3425	2.5069	1.6524
Min	3.0121	1.4295	2.4291	1.6524
Avg	3.1773	2.6338	2.468	1.6524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194003 / 33/11 PARANDA SUB-STATION

Feeder No / Name : 201 / PARANDA SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193	1.2193	1.3523	1.4723	1.2193	1.4022	1.3672
2	1.1431	1.0669	1.3523	1.4373	1.1431	1.3847	1.3321
3	1.1279	1.0669	1.283	1.4022	1.1431	1.3321	1.3146
4	1.1126	1.1126	1.3003	1.4022	1.1584	1.3146	1.3146
5	1.1126	1.1431	1.335	1.4022	1.1736	1.3321	1.3146
6	1.1431	1.2193	1.3696	1.4198	1.2193	1.2795	1.2971
7	1.1126	1.1584	1.387	1.5249	1.2346	1.3672	1.3672
8	1.1279	1.1736	1.335	1.4373	1.2955	1.2795	1.2971
9	1.1736	1.1584	1.387	1.4899	1.2193	1.2971	1.3496
10	1.3321	1.4373	1.4022	1.5249	1.3176	1.335	1.3696
11	1.4899	1.4373	1.5424	1.5249	1.387	1.3523	1.491
12	1.3496	1.4548	1.5775	1.5249	1.491	1.4217	1.5083
13	1.4899	1.4548	1.595	1.5775		1.491	1.5604
14	1.5249	1.5249	1.56	1.4373		1.4563	1.5777
15	1.4373	1.5249		1.4373	1.543	1.439	1.5257
16	1.5074	1.4723		1.5074		1.4563	
17	1.543	1.4737	1.6124	1.2803	1.4937	1.5249	
18	1.4737	1.4737	1.6817	1.3717	1.4022	1.4723	1.7353
19	1.6124	1.8031	1.7337	1.4022	1.4632	1.5424	1.7353
20	1.7511	1.7511	1.8204	1.4175	1.5546	1.8054	1.7878
21	1.6644	1.6991	1.7337	1.3565	1.4632	1.6301	1.6827
22	1.4175	1.6297	1.7177	1.3565	1.5775	1.56	1.5775
23	1.3717	1.5257	1.595	1.2803	1.5424	1.4899	1.4899
24	1.2498	1.2803	1.4563	1.5074	1.2346	1.4548	1.4548
Max	1.7511	1.8031	1.8204	1.5775	1.5775	1.8054	1.7878
Min	1.1126	1.0669	1.283	1.2803	1.1431	1.2795	1.2971
Avg	1.3536	1.3859	1.5059	1.4373	1.3465	1.4342	1.4750

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194003 / 33/11 PARANDA SUB-STATION

Feeder No / Name : 202 / LONI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.2286	.2429	.2027	.2896	.2286	.2462
2	.1524	.2286	.2105	.2027	.2896	.2572	.2462
3	.1829	.2439	.2267	.2172	.3048	.2858	.2462
4	.2134	.2743	.2753	.2143	.3048	.3144	.2572
5	.2439	.3048	.3077	.2572	.3048	.3429	.2896
6	.2591	.3353	.3563	.3475	.4268	.3858	.3429
20	.1509	.1698	.1698	.1543	.1372	.1509	.1886
21	.1698	.1698	.1698	.1029	.1543	.132	.1132
22	.1029	.132	.1029	.1029	.1357	.12	.1029
23	.2896	.3077	.2606	.3201	.2	.2606	.2751
24	.0686	.2591	.2753	.1882		.2143	.2317
Max	.2896	.3353	.3563	.3475	.4268	.3858	.3429
Min	.0686	.132	.1029	.1029	.1357	.12	.1029
Avg	.1805	.2413	.2362	.21	.2548	.2448	.2309

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194003 / 33/11 PARANDA SUB-STATION

Feeder No / Name : 203 / WAGEGAVAN SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2955	1.5242	2.0081	2.0891	1.5242	1.8623	1.7368
2	1.2955	1.5242	1.9595	2.1538	1.6004	1.8785	1.749
3	1.3717	1.6004	1.9757	2.1862	1.6004	1.8785	1.7814
4	1.448	1.6766	2.0729	2.2672	1.6766	1.8947	1.7976
5	1.5546	1.7528	2.2348	2.3158	1.7223	1.8947	1.8138
6	1.5546	2.1033	2.3805	2.3482	2.1033	1.9109	2.3482
7	1.9052	2.1186		2.1862	2.1434	1.8785	2.2996
8	1.6918	1.6918		1.9919	1.7223	1.6032	1.7166
9	1.5089	1.5242	1.6032	1.3927	1.3565	1.1822	1.3603
10	1.9757	1.5546	1.5708	1.4251	1.4575		1.3441
11	1.4251	1.4575	1.5384	1.3603	1.3927	1.2955	1.3441
12	1.4575	1.4251	1.3765	1.3117	1.2793	1.1822	1.2631
13	1.4089	1.3603	1.2793	1.2146	1.1822	1.1012	1.1012
14	1.3603	1.247	1.1984	1.1336	1.085	1.004	1.1336
15	1.3765	1.3279	1.247	1.0202	1.0526	1.0526	1.1174
16	1.4089	1.3441	1.2146			1.085	1.0688
20	.1886	.1698	.2075	.1715	.1715	.2241	.16
21	.1698	.1698	.1886	.1372	.1543	.176	.16
22	.1372	.1509	.1543	.1372	.1372	.1543	.1372
23	.12	.132	.1543	.12	.1372	.1715	.12
24	.12	.12	.132	.12	.12	.12	.12
Max	1.9757	2.1186	2.3805	2.3482	2.1434	1.9109	2.3482
Min	.12	.12	.132	.12	.12	.12	.12
Avg	1.1797	1.2369	1.2893	1.3541	1.1809	1.1775	1.2225

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194003 / 33/11 PARANDA SUB-STATION

Feeder No / Name : 204 / KHASAPURI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.829	2.21	.421	2.7854	2.5911	2.8502	2.8826
2	1.829	2.21	.421	2.753	2.5911	2.834	.2753
3	1.9814	2.2862	.4534	2.7206	2.5149	2.8178	2.7854
4	2.0576	2.332	.4696	2.672	2.4996	2.8178	2.7206
5	2.3834	2.3624	.4858	2.6235	2.4691	2.8502	2.6397
6	2.3777	2.5606		2.6235	2.7892	2.8664	2.8016
7	2.0424	2.0424	2.0405	2.1052	1.829	1.9433	1.9271
8	1.9662	2.1033	2.0891	2.0567	1.9966	1.749	1.9271
9	1.6309	1.9966	2.0405	2.0081	1.9204	1.8947	2.0405
10	2.0729	2.0405	1.9919	1.9433	1.7328	2.0081	1.9433
11	2.0243	1.9433	1.9109	1.9757	1.8138	1.9433	1.9433
12	1.9433	1.9109	1.7976	2.0081	1.7166	1.9109	1.7976
13	2.0405	1.8785	1.7166	1.9433	1.587	1.8623	1.5546
14	1.8785			1.8947			
20	.6036	.5093	.4904	.6001	.583	.679	.6413
21	.6224	.4904	.6413	.5144	.5316	.6224	.5847
22	.4801	.3961	.4748	.4801	.5144	.4458	.4801
23	2.271	2.4129	2.6558	2.4234	2.834	2.753	1.668
24	.4115	2.2862	.421	2.8826	2.6063	2.8502	2.9473
Max	2.3834	2.5606	2.6558	2.8826	2.834	2.8664	2.9473
Min	.4115	.3961	.421	.4801	.5144	.4458	.2753
Avg	1.7077	1.8873	1.2071	2.0534	1.9511	2.0944	1.8645

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194003 / 33/11 PARANDA SUB-STATION

Feeder No / Name : 205 / DONJA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3429	.415	.3725	.2743	.3944	.3601
2	.3086	.3429	.3772	.407	.2743	.4287	.3772
3	.3429	.3601	.3961	.4115	.3086	.4458	.3772
4	.3429	.3772	.4338	.4287	.3429	.4458	.4115
5	.3772	.3772	.4527	.4458	.3772	.4801	.4458
6	.4115	.4287		.4801	.4115	.5144	.5487
7	.8078	.9145	1.085	.9069	.7621	.8097	.9555
8	.8535	.9145	1.1012		.8535	.8421	1.1012
9	.8535	.8535	1.004	.9555	.8535	.8421	.9878
10	.9069	.9717	1.0526	.9717	.8421	.8259	1.0202
11	.8421	.9069	.9717	.9231	.8259	.8583	1.0364
12	.8097	.8583	.9393	.8583	.7449	.8583	.9069
13	.8097	.8421	.8907	.8097	.6154	.8421	.7611
14	.7287	1.3603	1.9433	.7773	1.9757	1.2793	1.7814
15	2.332	1.7004	2.3158	1.6842	2.0081	1.7166	2.0243
16	2.0567	1.8785	2.2672	1.4413		1.6842	1.9595
17	2.2996	1.9109	2.332	1.2803	1.8442	1.8564	2.0119
18	2.251	1.9271	2.1214	1.3717	2.1338	1.8067	2.2045
19	2.2024		2.0567	1.3413	1.9509	1.8896	2.1051
20	2.332	2.1052	2.4777	1.5851	1.9052	2.0809	2.2119
21	2.2024	1.6194	2.4939	1.5242	1.9509	1.9433	1.8724
22	2.0119	1.5708	2.4291	1.4022	2.1052	1.8947	1.7166
23	.4115	.4527	.4287	.2743	.3772	.4115	.3086
24	1.829	.3772	.4338	.3772	.2743	.3601	.3429
Max	2.332	2.1052	2.4939	1.6842	2.1338	2.0809	2.2119
Min	.3086	.3429	.3772	.2743	.2743	.3601	.3086
Avg	1.1930	1.0171	1.3226	.9143	1.0440	1.0630	1.1595

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194014 / 33/11KV ANALA SUB-STATION

Feeder No / Name : 201 / ANALA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1658	.2562	.216	.2858	.3048	.2286	.3239
2	.1505	.192	.1912	.2858	.3048	.2286	.3048
3	.1391	.192	.1912	.2858	.3048	.2667	.3048
4	.1477	.192	.1849	.2858	.3048	.2667	.3048
5	.2858	.2667	.1962	.0271	.0646	.0577	.0789
6	.381	.2667	.1867	.0244	.0384	.0257	.0862
7	.381	.3048	.1969	.1749	.0554		.0674
8	.381	.3048	.2515	.1656	.2069	.2069	.1452
9	.381	.2286	.2567	.153	.1728	.3071	.2374
10	.2667	.2286	.2578	.3127	.225	.2892	.2298
11		.2286	.2382	.3178	.1736	.2561	.2166
12	.2667	.2286	.2195	.2251		.2519	.2985
19	.3048	.3048	.381	.4572	.2667	.4954	.4763
20	.3048	.3048	.381	.4572	.2667	.4954	.4382
21	.1969	.1898	.381	.4191	.2286	.4572	.4382
22	.1832	.3158	.381	.362	.2286	.4572	.381
23	.2401	.186	.2858	.3048	.2286	.3239	.381
24	.1672	.2562	.2195	.2858	.3048	.2286	.3239
Max	.381	.3158	.381	.4572	.3048	.4954	.4763
Min	.1391	.186	.1849	.0244	.0384	.0257	.0674
Avg	.2555	.2471	.2565	.2683	.2165	.2849	.2798

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194014 / 33/11KV ANALA SUB-STATION

Feeder No / Name : 203 / CHINCHPUR KD SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5324	.5335	.5716	3.0521	3.2129	3.0453	2.9394
2	.4949	.5335	.5716	3.0453	3.2164	3.0418	2.8583
3	.4934	.4954	.5335	2.8696	2.9763	2.6886	2.8583
4	.4944	.571	.7233	2.8631	2.7526	2.6856	2.6382
5	.7621	.6845	.7233	.6635	.9145	.7218	.8954
6	.6845	.7606	.7606	.9488	.9697	.8349	.9516
7			.797	.8565	.8383		.9127
8			.6622	.759	.7613	.8711	.8192
9			.4758	.2855	.5335	.5525	.724
10			.3803			.4572	.5335
11			.2846		.5303	.4001	.4382
12			.2855		.4924	.3048	.381
13		2.7008					
14	2.6194	2.8262					
15	2.6194	2.8262					
16	2.6046	2.8599					
17	2.6886	2.661					
18	2.8006	2.9474					
19	2.512	2.9474	.6859	.8954	.7423	.9145	.9335
20	2.5463	2.5006	.9507	.9717	.8545	1.0669	1.0479
21	.8002	.8383	3.3176	3.6661	2.6673	3.4197	3.4537
22	.8002	.7994	3.1964	3.5218	3.0418	3.376	3.4044
23	.724	.7613	3.2036	3.4027	3.3629	3.3536	3.2108
24	.5329	.6859	.6859	3.2072	3.3154	3.2145	2.8935
Max	2.8006	2.9474	3.3176	3.6661	3.3629	3.4197	3.4537
Min	.4934	.4954	.2846	.2855	.4924	.3048	.381
Avg	1.4535	1.6074	1.0450	2.0672	1.8343	1.8205	1.7719

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194030 / 33 KV JAWALA SUBSTATION

Feeder No / Name : 203 / 11 KV SHIRSAV SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	28-MAY-17
HR	Load (MW)
9	1.4746
11	2.4577
12	2.6216
13	2.2939
14	2.3758
15	1.5565
16	1.4746
17	1.4746
18	1.5565
19	1.3927
20	1.3108
21	1.3108
22	1.1469
23	.1619
Max	2.6216
Min	.1619
Avg	1.6149

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194037 / 33/11 KV SHELGAON SUBSTATION

Feeder No / Name : 202 / 11 Kv Chinchpur AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0781	1.7185	1.5242	1.467	1.3717
2	.0781	1.5623	1.2193	1.467	1.3717
3	.0781	1.406	1.3717	1.467	1.6347
4	.0781	1.406	1.3717	1.467	1.5242
5	.0781	.0781	.0914	.0734	.0914
6	.0781	.0781	.0914	.0734	.0914
7		.0781			
20	.0781	.0781	.0734	.0914	
21	1.0936		1.467	1.5242	
22	1.406		1.467	1.3717	
23	1.5623		1.467	1.3546	
24	.0781	2.0309	1.6766	1.467	1.5242
Max	1.5623	2.0309	1.6766	1.5242	1.6347
Min	.0781	.0781	.0734	.0734	.0914
Avg	.4261	.9373	1.0746	1.0749	1.0870

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194037 / 33/11 KV SHELGAON SUBSTATION

Feeder No / Name : 203 / 11 Kv Tandulwadi AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0686		.0914	.0686	.0914
2	.0686	.0686		.0914	.0686	.0914
3	.0686	.0686		.0914	.0686	.0914
4	.0686	.0686		.0914	.0686	.0914
5	.0686	.0686		.0914	.0686	.0914
6	.0686	.0686			.0686	.0914
13	1.2346	.9602	1.7833	1.2346	1.6004	1.5242
14	1.3717	1.3717	1.4861	1.3717	1.4861	1.7833
15	1.3717	1.3717	1.2193		1.2193	1.3717
16	1.3717	1.5089	1.3717	1.3717	1.2193	1.4861
17	1.5089	1.5089	1.3717	1.3717	1.3546	1.3717
18	1.5089	1.3717	1.5242	1.3717	1.3717	1.5242
19	1.5089	1.3717		1.3717	1.3889	
20	1.3717	1.5089		1.3717	1.5432	
21	.0686			.0686	.0914	
22	.0686			.0686	.0914	
23	.0686			.0686	.0914	
24	.0686	.0686		.0914	.0686	.0914
Max	1.5089	1.5089	1.7833	1.3717	1.6004	1.7833
Min	.0686	.0686	1.2193	.0686	.0686	.0914
Avg	.6630	.7636	1.4594	.6387	.6632	.7462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194037 / 33/11 KV SHELGAON SUBSTATION

Feeder No / Name : 204 / 11 KV SHELGAON GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	26-MAY-17	27-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2204	.1638		.3121
2	.1638	.1658		.3124
3	.3113	.3222		.3467
4	.4239	.3944		.3467
5	.463	.4784		.4161
6	.567	.5316		.5028
11	.362	.3658	.3988	
12	.362	.4207	.3121	
13	.3258	.3224	.3641	
20	.543	.5552	.5201	
21	.4252		.5028	
22	.3544		.4161	
23	.1715		.3121	
24	.2652	.213		.3121
Max	.567	.5552	.5201	.5028
Min	.1638	.1638	.3121	.3121
Avg	.3542	.3576	.4037	.3641

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194037 / 33/11 KV SHELGAON SUBSTATION

Feeder No / Name : 205 / 11 KV CHINCHPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1696	.1966		.1829	.1543	.1463
2	.2155	.1638		.1646	.1543	.1646
3	.2572	.1658		.2012	.1543	.1829
4	.2658	.2204		.181	.1543	.1646
5	.2835	.2204		.1463	.1543	.2195
6	.2835	.2835		.1829	.1543	.2561
11	.2303	.2658	.1829	.1852	.1646	.2195
12	.2658	.2629	.1646	.1852	.1463	.1829
13	.2481	.2279	.1646	.1543	.1829	.168
20	.2658	.2715		.216	.2195	
21	.2804			.1543	.2561	
22	.2835			.1543	.1829	
23	.2279			.1543	.1646	
24	.2229	.1989		.1646	.1543	.1646
Max	.2835	.2835	.1829	.216	.2561	.2561
Min	.1696	.1638	.1646	.1463	.1463	.1463
Avg	.2500	.2252	.1707	.1734	.1712	.1869

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194044 / 33/11 KV SUB-STATION

WARADWADI

Feeder No / Name : 201 / WAKADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	2.2138	2.1052	1.9608
2	2.6092	2.6235	1.9845
3	2.7206	2.753	2.0557
4	2.6566	2.753	2.17
5	2.8502	2.8178	2.332
6	2.8464	2.8826	2.8487
7	2.9254	2.5263	2.8502
8	2.8464	2.915	2.7664
9	2.878	2.915	
17	.1898	.1943	
18	.2267	.2214	
20		.3086	
21	.3163	.3086	
22	.3239	.2713	
24	1.2018	1.2308	1.9433
Max	2.9254	2.915	2.8502
Min	.1898	.1943	1.9433
Avg	1.9147	1.7884	2.3235

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194044 / 33/11 KV SUB-STATION

WARADWADI

Feeder No / Name : 202 / ASSU

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1581		.1734
2	.1581		.1734
3	.1581		.1715
4	.1581		.1734
5	.1581		.1734
6	.1581	.1619	.1734
10	1.1873	2.1052	1.643
11	2.372	2.4615	2.649
12	2.8147	2.4291	2.4143
13	2.4291	2.2024	2.3137
14	2.2771		2.1795
15	1.8976	1.9433	2.1795
16	2.3045	2.332	2.2634
17	2.2771	2.332	
18		.1619	
21	.1898	.1715	
22	.1943	.1715	
24	.1581	.1619	.1715
Max	2.8147	2.4615	2.649
Min	.1581	.1619	.1715
Avg	1.1206	1.3862	1.2037

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194044 / 33/11 KV SUB-STATION

WARADWADI

Feeder No / Name : 203 / WAKADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2372		.2591
2	.2372		.2561
3	.2372		.253
4	.2372		.2561
5	.253		.2591
6	.253	.2591	.2591
17	.1423	.1619	
18		.1943	
20		.2743	
21	.2372		
22	.2429	.2591	
24	.253	.2591	.2591
Max	.253	.2743	.2591
Min	.1423	.1619	.253
Avg	.2330	.2346	.2574

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427] BU 2623

Substation No/ Name :- 194007 / 33/11 KV YEDASHI S/STN.

Feeder No / Name : 201 / 11 kv Ambejawalaga SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	27-MAY-17
HR	Load (MW)
11	2.6673
Max	2.6673
Min	2.6673
Avg	2.6673

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194007 / 33/11 KV YEDASHI S/STN.

Feeder No / Name : 202 / 11kv Yedashi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.326	1.1603			1.0526	
2	1.4255	1.1603			1.166	
3	1.1603	1.2431			1.166	
4	1.1934	1.2431			1.2803	
5	1.2431	1.326			1.5043	
6	1.2431	1.5083			1.4899	
7	1.1603	1.757			1.692	
8	1.1105	1.6078			1.6164	
9	.8059	1.1317			1.1269	
10	.7545	1.1317	1.1488		1.1043	
11	.7545	.6859			1.1043	
12	.7716	.7202	.7373		1.0867	
13	.7888				1.1043	
14	.7716	.7545		1.0974	1.0974	
15	.7545	.7545			.9088	
16	.7888				1.0749	
17	.7888					
18	.7888	.7545		.7202		
19	.9088					
20	.9259					
21	.9088					
22	.9088					
23	.8573					.8573
24	1.3094	.8402				
Max	1.4255	1.757	1.1488	1.0974	1.692	.8573
Min	.7545	.6859	.7373	.7202	.9088	.8573
Avg	.9770	1.1112	.9431	.9088	1.2234	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194007 / 33/11 KV YEDASHI S/STN.

Feeder No / Name : 203 / JAWALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3429			.3155	
2		.3258			.2481	
3		.3258			.2481	
4		.3258			.2481	
5		.3429			.2481	
6		.3944			.2507	
7		.3944			.2804	
8		.3429			.2804	
9		1.2763			.9012	
10		1.3321	1.2452		1.2146	
11		1.1305			1.1984	
12		1.1568	1.1633		1.1305	
13					.9995	
14		1.0814			.9831	
15		1.2944			.9995	
16					.9945	
18		.3856		.3856		
19				.3856		
23						.3429
24	.3429	.3601				
Max	.3429	1.3321	1.2452	.3856	1.2146	.3429
Min	.3086	.3258	1.1633	.3856	.2481	.3429
Avg	.3258	.6758	1.2043	.3856	.6588	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427] BU 2623

Substation No/ Name :- 194010 / 33/11 KV DHOKI S/STN

Feeder No / Name : 202 / 11 kv Khamgao SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	23-MAY-17
HR	Load (MW)
9	1.7985
Max	1.7985
Min	1.7985
Avg	1.7985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427] BU 2623

Substation No/ Name :- 194010 / 33/11 KV DHOKI S/STN

Feeder No / Name : 206 / 11 kv Dhoki SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	23-MAY-17
HR	Load (MW)
9	.9602
Max	.9602
Min	.9602
Avg	.9602

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194011 / 33/11 KV KAMEGAON SUBSTATION

Feeder No / Name : 202 / chikali

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3336		1.6289	1.6975	1.5775	1.8861	1.4289
2	1.4289		1.7147	2.0748	1.5775	2.0748	1.6194
3	1.5623		1.7833	2.0748	1.7147	2.0748	1.6575
4	1.7147		1.8861	2.0748	1.7147	2.2257	1.7147
5	1.829		2.0576	2.2634	1.8861	2.2634	1.7718
6	2.3815	2.3663	2.2119	2.3954	1.9376	2.3388	2.3243
7	2.1148	2.4348	2.2291		1.989	2.4387	2.4387
8	2.3243		2.2291		1.989	2.4958	2.1338
9	2.0957	2.2291				2.3053	1.9433
10					.2401	.2286	.2477
11			.1715			.2096	.1848
12	.2096				.1715	.2096	.1658
13	.1905		.1886			.2096	.2218
14	.1715	.2058				.1905	.1848
15	.1715	.2058		.2401	.1543	.1905	.1829
16		.2058	.1886	.2401	.1715	.2096	.1829
17	.1715	.2401	.2218	.2401	.1848	.2096	
18		.2915	.2155	.3086	.1696	.2667	.3086
19	.2229	.3429	.3315	.3429	.3222	.3239	
20		.3944	.3978	.3772	.4239	.381	
21		.3772	.3315	.3429	.3561	.381	
22			.2984	.3429	.3391	.362	
23	.2915	.3258	.2984	.3086	.2883	.3239	.2229
24	1.2765	1.4918	1.5432	.5847	1.5432	1.2765	1.2765
Max	2.3815	2.4348	2.2291	2.3954	1.989	2.4958	2.4387
Min	.1715	.2058	.1715	.2401	.1543	.1905	.1658
Avg	1.1465	.8547	1.0488	.9943	.9375	1.0448	1.0637

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194011 / 33/11 KV KAMEGAON SUBSTATION

Feeder No / Name : 203 / Kamegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6004		1.4575	1.6975	1.5775	1.1603	1.3717
2	1.6766		1.6118	1.6975	1.5775	1.2266	1.448
3	1.7528		1.7147	1.4918	1.6804	1.326	1.5242
4	1.829		1.7147	1.5249	1.7147	1.3923	1.6004
5	1.9052		1.7833	1.5249	1.7833	1.3923	1.829
6	2.4387	2.1262	2.0576	1.4723	1.8519	1.3923	2.4387
7	2.5149		2.2634		1.989	1.7238	2.4387
8	2.4387		2.2634	2.1262	2.0576	1.9052	2.4387
9	1.989	1.5432		1.5089		1.9052	1.4586
10		1.7833		1.2003	1.166		1.5912
11	.7625	1.7833	1.5775			1.829	1.5912
12	1.8564	1.8861	1.7833	1.7833	.8916	1.829	1.326
13	1.4586	1.7833	1.5775	1.7833		1.6004	1.3923
14	1.4586	1.7147		1.7833		1.5242	1.326
15	1.4586	1.4403	1.5089	1.8519	1.5089	1.5242	1.326
16		1.4403	1.9204	1.8861	1.5432	1.6766	1.4586
17	1.5432	1.3717	1.7238	1.9204	1.5912	1.6766	
18		.3429	.5304	.3429		.4572	.3086
19	.7545	.4801	.4641	.6173	.8619	.6097	
20		.5144	.3978	.6173	.3315	.5335	
21		.6173	.3978	.6173	.407	.5335	
22		.6173	.3978	.5144	.3315	.4572	
23	.5144	.5144	.3978	.5144	.3052	.4572	.4115
24	1.5242	1.166	1.2003	1.6598	1.5089	1.2955	1.2955
Max	2.5149	2.1262	2.2634	2.1262	2.0576	1.9052	2.4387
Min	.5144	.3429	.3978	.3429	.3052	.4572	.3086
Avg	1.6376	1.2426	1.3688	1.3698	1.2989	1.2795	1.5039

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194011 / 33/11 KV KAMEGAON SUBSTATION

Feeder No / Name : 204 / Rajuri Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362		.3086	.3206
2	.3429		.3086	.3206
3	.3429		.3086	.3206
4	.3429		.3258	.3206
5	.3429		.3258	.3772
6	.381		.3258	.4338
7	.362		.3429	
8	.362	.3601	.3429	.2915
9		.2743		.2401
11	1.5813	1.286	1.4918	
12	1.8671	1.3375	1.6461	
13	1.7147	1.3032		
14	1.5242	1.286		
15	1.4098	1.2689	1.5432	
16		1.2689	1.5947	
17	1.5432	1.2003	1.8296	
18		.2915	.2321	
19	.3086	.3429	.3315	
20		.3772	.4475	
21		.3601	.3647	
22		.3429	.3315	
23	.3086	.3086	.2818	
24	.362	.3086	.3086	.3206
Max	1.8671	1.3375	1.8296	.4338
Min	.3086	.2743	.2321	.2401
Avg	.7917	.7448	.6496	.3273

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194011 / 33/11 KV KAMEGAON SUBSTATION

Feeder No / Name : 205 / Raje borgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524			.1509	.2743	.3584	.362
2	.1524		.12	.1509	.2743	.3584	.362
3	.1715		.1372	.1509	.2915	.3584	.362
4	.1715		.1543	.1886	.3086	.3584	.362
5	.1715		.1543	.1886	.3086	.3772	.362
6	.2096	.2058	.1715	.2075	.3086	.4338	.4572
7	.2096	.1543	.1715		.3601		.4382
8	.1715		.1543	.1372	.3601		.4001
9	.1715	.1372		.1372		.2667	.3429
10		1.1831				2.0576	1.6004
11	1.5242	1.2174	1.3546		2.572	2.6673	3.0678
12	1.3908	1.2174	1.5089	2.0576	2.8464	2.7625	
13	1.2955	1.2003	1.4746	2.7092		2.6292	2.9199
14	1.3336	1.166		2.6406			3.0123
15	1.3336	1.1317	.3772	2.7092	2.5892	.7049	2.9813
16		1.1317	1.3889	2.7092	2.5892	2.9531	3.0544
17	1.3717	1.0288	1.4415	2.7092	3.1417	2.9912	
18			.0829	.2915		.3048	.3086
19	.1543		.1658	.3772	.3647	.4191	
20		.1543	.1989	.4115	.4917	.4572	
21		.1543	.1658	.3772	.4409	.4763	
22		.1372	.1326	.3429	.407	.4572	
23	.12	.12	.1326	.3429	.3391	.4191	.3772
24	.1524		.12	.1509	.3086	.362	.362
Max	1.5242	1.2174	1.5089	2.7092	3.1417	2.9912	3.0678
Min	.12	.12	.0829	.1372	.2743	.2667	.3086
Avg	.5699	.6893	.4804	.9115	.9777	1.0558	1.1740

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194020 / 33/11 TER SUBSTATION

Feeder No / Name : 201 / TER Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.0065		
4				.0066		
6	.0857		.0095	.0065		
7					.0095	
8		.0095	.0095	.0066	.0095	
9	.0905			.0064	.0095	
10	.3269			.3593	.503	.503
11	.5647				.5365	.5243
12	.5117			.506	.503	.5571
13	.4344				.5197	.4424
14	.4115			.3887	.503	.4458
15	.4458				.4725	.4801
16	.5068	.6009		.506	.5243	.3772
17	.5647			.5624	.5079	.4287
18	.0072			.0095	.0857	.4115
19				.0095		.0857
20	.0077			.0095		.0905
21				.0095		
22					.0857	
23						.3391
24	.0187	.0095	.0095	.0078	.0095	
Max	.5647	.6009	.0095	.5624	.5365	.5571
Min	.0072	.0095	.0095	.0064	.0095	.0857
Avg	.3059	.2066	.0095	.1601	.3057	.3905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427] BU 2623

Substation No/ Name :- 194020 / 33/11 TER SUBSTATION

Feeder No / Name : 202 / 11 Kv Ramwadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086			.1406		
2	.1715			.1802		
3	.3429			.1781		
4	.4409			.3795		
5	.4694			.3953		
6	.4694		.4527	.4111		
7	.4527			.4161	.6036	
8	.4862	.4338	.4904	.4161	.5658	
9	.39			.3887	.4527	
10	.253			.2587	.3429	.3429
11	.1562				.3018	.3258
12	.1265			.1463	.2683	.3086
13	.096				.1543	
14	.0949			.1448	.1372	
15	.0949				.1543	
16	.125	.1448		.1848	.4862	
17	1.1248			1.3435	.7209	1.0059
18	1.2651			1.2452	.788	1.0814
19	1.0155			1.1069	.9667	1.0978
20	.7716			1.0311	1.0174	.2743
21				.9374	.9995	.9069
22						.9175
23						.7045
24	.2229	.8905	.9374	.9061	.535	
Max	1.2651	.8905	.9374	1.3435	1.0174	1.0978
Min	.0949	.1448	.4527	.1406	.1372	.2743
Avg	.4228	.4897	.6268	.5374	.5309	.6966

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194020 / 33/11 TER SUBSTATION

Feeder No / Name : 203 / 11 Kv Wagholi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1799	.1806	.1646	.3258	.1562	.173	.1623
2	.2363	.1814	.1661	.3233	.1593	.1715	.1608
3	.1715	.1806	.1661	.3216	.1578	.1692	.1616
4		.1814	.1669	.3742	.1585	.1692	.1753
5	.2058	.1928	.1768	.4263	.1692	.1715	.1905
6	.1715	.2408	.3982	.4397	.192	.1959	.205
7	.4973	.2484	.2195	.4546	.4965	.234	.2111
8	.4706	.3898	.4268	.4044	.4157	.2141	.205
9	4.3701	2.1094	1.6926	4.4231	4.3812	1.8168	2.079
10	4.9036	2.6619	2.2977	4.8529	4.454	2.4768	4.2379
11	4.9215	2.7168	2.4669	2.5979	4.4917	2.5423	4.2013
12	4.7043	2.6017	2.5309	4.9631	4.4342	2.4646	4.3061
13	4.7085	2.4066	2.4798	2.6124	4.4414	2.3868	4.3979
14	4.5397	2.2649	2.4745	4.4837	4.4624	2.3236	4.3422
15	4.4323	2.2961	1.832	1.893	4.4468	2.0942	4.2639
16	4.5447	4.2791	1.9425	4.4475	4.3477	1.957	4.3248
17	2.1014	2.0675	1.6369	2.2954	2.1692	1.6804	1.9632
18	.205	.1097	.1235	.2713	.2313	.1181	.362
19	.2968	.1318	.1539	.3345	.3468	.1257	.2744
20	.4073	.2576	.2522	.4958	.4619	.2416	.4352
21	2.4398	.285	.282	.4831	.5193	.2622	.4824
22	.2256	.237	.2301	.2462	.2385	.2149	.4096
23	.2027	.2103	.208	.2119	.1997	.1943	.3651
24	.3425	.3466	.3391	.3304	.2553	.176	.176
Max	4.9215	4.2791	2.5309	4.9631	4.4917	2.5423	4.3979
Min	.1715	.1097	.1235	.2119	.1562	.1181	.1608
Avg	1.9686	1.1157	.9512	1.5838	1.7411	.9406	1.5872

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194020 / 33/11 TER SUBSTATION

Feeder No / Name : 204 / 11 Kv Panwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1305			.8855		
2	1.1305			1.0467		
3	1.1469			1.1717		
4	1.2289			1.2654		
5	1.2289			1.5023		
6	1.2944		1.4083	1.5779		
7	1.3599			1.4998	1.6575	
8	1.3927	1.4746	1.5074		1.5402	
9	.2058			.1406	.2641	
10	.1852			.0724	.2401	.1543
11	.061				.2058	.1372
12	.0617			.0724	.2401	.1543
13	.0625				.1715	.1543
14	.061			.0747	.1543	.1543
15					.1543	.1372
16	.0625	.0701		.0724	.12	.0857
17	.0937			.0732	.12	.1543
18	.0949			.1086	.1029	.1543
19	.1898			.2263	.1543	.2572
20	.2688			.3018	.1886	.2401
21				.1478	.2058	.2401
22					.1543	.2058
23						.1372
24	.9556	.128	.1086	.1718	.0732	
Max	1.3927	1.4746	1.5074	1.5779	1.6575	.2572
Min	.061	.0701	.1086	.0724	.0732	.0857
Avg	.6108	.5576	1.0081	.5784	.3381	.1690

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194020 / 33/11 TER SUBSTATION

Feeder No / Name : 205 / 11 kv Mulewadi _Ag

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857			.0076		
2				.0076		
3	.0857					
4	.0857			.0076		
5				.0076		
6	.0857		.0088	.0119		
7					.009	
8	.0857	.009	.009	.0078	.0091	
9	.0857			.0078	.0088	
10	.759			.9804		.8215
11	1.2955					1.3272
12	1.2651			1.278		1.3108
13	1.2186				1.247	1.2803
14	1.2483			1.0562	1.278	1.3279
15	1.2186				1.278	1.3283
16	1.2498	1.3927		1.2631	1.3272	1.3435
17	1.2955			1.2452	1.3108	1.3763
18	.008			.009	.0857	1.3763
19				.0091	.0857	.0857
20	.0127			.0091	.0857	.0857
21				.009	.0857	.0857
22						.0857
23						.0857
24	.0857	.0086	.0086	.0077	.0086	
Max	1.2955	1.3927	.009	1.278	1.3272	1.3763
Min	.008	.0086	.0086	.0076	.0086	.0857
Avg	.5983	.4701	.0088	.3485	.5246	.8515

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194020 / 33/11 TER SUBSTATION

Feeder No / Name : 206 / MULEWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543			.1254		
2	.1715			.1267		
3	.1715			.124		
4	.1715			.1433		
5	.2058			.1791		
6	.2229		.1829	.2126		
7	.2058			.2103	.2402	
8	.1886	.2402	.2218	.2328	.2402	
9	.1715			.1991	.1829	
10	.1086			.1433	.1715	.1715
11	.1017				.1372	.1715
12	.0895			.1227	.12	.12
13	.1017				.12	.12
14	.1086			.1029	.1372	.12
15	.1075				.12	.1372
16	.1063	.1052		.1075	.1029	.12
17	.1267			.1267	.12	.1886
18	.1254			.1629	.0686	.1715
19	.1772			.2218	.1372	.1886
20	.2303			.2218	.1543	.1715
21				.1829	.1543	.1543
22						.1543
23						.12
24	.12	.1227	.1254	.1267	.0857	
Max	.2303	.2402	.2218	.2328	.2402	.1886
Min	.0895	.1052	.1254	.1029	.0686	.12
Avg	.1508	.1560	.1767	.1617	.1433	.1506

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194020 / 33/11 TER SUBSTATION

Feeder No / Name : 207 / TER WATER WORKS

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 11 / OUTGOING

UTILITY

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***			.013		
2	***			.0156		
3	***			.0131		
4	***			.0156		
5	***			.0149		
6	***		.0004	.0149		
7	***			.0151	.0002	
8	***	.0002	.0004	.0156	.0002	
9	***			.0152	.0002	
10	***	***		.0004	.0181	***
11	.0152	***				***
12	.0274	***		.0004	.0187	***
13		***	***		.0171	***
14	.0267	***	***	.0004		***
15	.0139	***	***		.0181	***
16		***	***	.0004	.0181	.0171
17	.0135	***	***	.0002	.0171	.0171
18	.0274	***	***	.0002	.0171	.0171
19	.0139	***	***	.0002	.0187	.0171
20	.0274	***	***	.0002	.0187	.0181
21		***	***	.0002	.0181	
22						.0181
23						.0181
24	.1715	.0002	.0002	.013	.0002	
Max	152.5875	152.5875	152.416	.0156	.0187	152.5703
Min	.0135	.0002	.0002	.0002	.0002	.0171
Avg	76.3013	130.6546	114.3121	.0078	.0129	70.4226

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194020 / 33/11 TER SUBSTATION

Feeder No / Name : 208 / MINOR DRIP IRRIGATION
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.013		
3				.0128		
4				.013		
6			.0116	.013		
7	.0181			.0128	.0128	
8	.0187	.0116	.0111	.0156	.0114	
9	.0181			.013	.0124	
10	.013			.0118	.0187	
11	.0124				.0187	
12				.0103		.0187
13	.0124					
14	.0124			.0099		
15					.0181	
16	.0128	.0124		.0111		.0181
17				.0118		.0181
18	.013			.013	.0181	
19	.013			.0139	.0187	.0181
20	.0255			.0149		
21				.0154	.0181	
23						.0181
24	.0181	.0122	.0126	.013	.012	
Max	.0255	.0124	.0126	.0156	.0187	.0187
Min	.0124	.0116	.0111	.0099	.0114	.0181
Avg	.0156	.0121	.0118	.0128	.0159	.0182

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194020 / 33/11 TER SUBSTATION

Feeder No / Name : 209 / TER GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4694					
2	.503					
3	.5197					
4	.5365					
5	.5533					
6	.5365		.6283			
7	.4862				.6283	
8	.503	.6283	.5914		.5914	
9	.4694				.5487	
10	.5068			.5487	.4915	.4915
11	.4835				.4915	.4862
12	.4784			.4706	.4694	.463
13	.4784				.4527	.4458
14	.4887			.4298	.4458	.463
15	.4656				.4359	.4458
16	.4706	.4706		.5068	.4694	.4458
17	.4477			.5121	.4694	.4862
18	.5014			.5487	.503	.4862
19	.5973			.6283	.5571	.5365
20	.6805			.7095	.5571	.5197
21				.7095	.5898	.503
22						.4862
23						.4862
24	.4359	.5068	.4755		.4755	
Max	.6805	.6283	.6283	.7095	.6283	.5365
Min	.4359	.4706	.4755	.4298	.4359	.4458
Avg	.5053	.5352	.5651	.5627	.5110	.4818

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194035 / 33/11 kv JAGAJI SUBSTATION

Feeder No / Name : 201 / JAGJI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10						.1296	
17	1.6194	2.2672	2.0233	2.1605	1.9919	1.9433	
18	1.5384	2.17	2.1091	2.1262	1.8138	1.8623	.9717
19		1.9757	1.9547	2.0233	1.7814	1.7328	
20		1.9433		1.6842	1.7166	1.6194	.9393
21		1.5546	1.749	1.7166	1.5384	1.3279	.8745
22		1.5384	1.6804	1.6842	1.4575	1.3279	.8907
23		1.6194	1.5775	1.7147	1.5927	1.3279	.9259
24			1.6194	1.6289	1.6632	1.4575	1.3765
Max	1.6194	2.2672	2.1091	2.1605	1.9919	1.9433	1.3765
Min	1.5384	1.5384	1.5775	1.6289	1.4575	.1296	.8745
Avg	1.5789	1.8669	1.8162	1.8423	1.6944	1.4143	.9964

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194035 / 33/11 kv JAGAJI SUBSTATION

Feeder No / Name : 202 / Palsap Ag With SDT

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.749	1.2955	1.2955	1.749	1.7833	1.3717	1.4575
2	1.8004	1.4754	1.2955	1.8347	1.8519	1.6194	1.4575
3	1.8861	1.2308	1.2955	1.9204	1.8861	1.5384	1.4575
4	1.749	1.1336	1.2955	2.0576	1.9204	1.5223	1.4575
5	1.8861	1.2071	1.2955	2.0233	1.989	1.2955	1.6194
6	1.8347		1.4575	2.1262	2.1262	1.7147	1.7814
7	1.9204		1.7004	.3772	2.0576	1.7147	1.8623
8	1.749		1.5384	2.1948	1.6461	1.7833	1.4251
9							1.4251
17			.1372				
21			.1372				
22			.1372				
23		.0324	.1372			.0324	
24	1.3032		.0324	.1372			
Max	1.9204	1.4754	1.7004	2.1948	2.1262	1.7833	1.8623
Min	1.3032	.0324	.0324	.1372	1.6461	.0324	1.4251
Avg	1.7642	1.0625	.9042	1.6023	1.9076	1.3992	1.5493

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194035 / 33/11 kv JAGAJI SUBSTATION

Feeder No / Name : 203 / 11 KV Sumbha Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	1.9204		1.7147	1.7833	1.749	1.9109	1.8299
10	1.8623	1.8947	1.7833	1.9033		1.9919	1.989
11	1.7976	1.9919	1.749	1.8347		1.9919	1.9547
12	1.8623	.4858	1.8176	1.8861		1.8623	2.0919
13	1.8785	1.8623	1.8347	1.8861	1.9433	1.749	2.0233
14	1.8785	1.8623	1.8004	1.8519	1.749	1.8947	1.9547
15	1.8461	1.8623	1.869	1.8519	1.7004	1.8299	1.9547
16	1.9433	1.9433	1.8347	1.869	1.7814	1.8623	1.989
Max	1.9433	1.9919	1.869	1.9033	1.9433	1.9919	2.0919
Min	1.7976	.4858	1.7147	1.7833	1.7004	1.749	1.8299
Avg	1.8736	1.7004	1.8004	1.8583	1.7846	1.8866	1.9734

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194035 / 33/11 kv JAGAJI SUBSTATION

Feeder No / Name : 204 / KOND GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3239	.362	.2058	.3086	.2591	.2715
2	.2743	.3887	.362	.2401	.3429	.2591	.2715
3	.3429	.3563	.362	.3086	.3772	.2915	.2715
4	.4115	.3563	.4525	.4115	.4115	.3239	.362
5	.5487	.421	.543	.5487	.4458	.3887	.4525
6	.6344		.6335	.5144	.4801	.6859	.543
7	.6173		.6335	.5487	.5144	.5487	.543
8	.583		.6335	.5144	.4801	.4458	.4887
9	.463		.3429	.5144	.4801	.3982	.543
10	.2915	.3239	.3601	.3429	.421	.2172	.2743
11	.2267	.3239	.3086	.2401	.2915	.3077	
12	.2591		.2743	.1715	.1943	.2715	
13	.2267	.2429	.3086	.1715	.1296	.2172	.2401
14	.2267	.2429	.3429	.2058	.1619	.181	.2401
15	.2267	.2429	.2401	.2058	.1943	.2172	.2058
16	.2591	.1134	.2401	.2401	.2267	.2715	.2058
17	.2591	.3563	.3086	.2743	.2591	.2105	.2743
18	.3239	.3563	.3429	.3772	.3239	.3239	.3429
19	.4858	.5182	.4801	.4801	.4858	.3239	
20	.5506	.5506	.583	.5506	.4858	.3239	.5487
21	.4858	.4858	.4115	.4858	.421	.3563	.4801
22	.4534	.4858	.4801	.3401	.4049	.3239	.3772
23	.3887	.362	.3772	.3086	.3239	.2534	.3772
24	.3772	.3563	.362	.2915	.2743	.4458	.2534
Max	.6344	.5506	.6335	.5506	.5144	.6859	.5487
Min	.2267	.1134	.2401	.1715	.1296	.181	.2058
Avg	.3844	.3583	.4060	.3539	.3516	.3269	.3603

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194035 / 33/11 kv JAGAJI SUBSTATION

Feeder No / Name : 205 / PALSAP JAGJI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.2915	.362	.4115	.4115	.3563	.4525
2	.3429	.3563	.362	.4801	.3772	.3563	.4525
3	.3086	.3887	.362	.5487	.4458	.3887	.4525
4	.4115	.503	.362	.6516	.4801	.4534	.543
5	.5487	.6097	.543	.6001	.5487	.5182	.543
6	.6859		.724	.6859	.6173	.6859	.6335
7	.4801		.6335	.703	.6173	.6859	.6335
8	.6516		.6335	.6516	.6859	.6173	.6697
9	.5487		.6001	.583	.5487	.5792	.543
10	.4858	.3563	.4801	.4115	.503	.3982	.3429
11	.3239	.2915	.3429	.2058	.4858	.362	.2743
12	.2915		.3429	.1372	.3563	.2715	.2743
13	.3239	.2429	.3086	.2058	.503		.2401
14	.2915	.2591	.3429	.2743	.2683		.2401
15	.3239	.2286	.2743	.2743	.2683	.2715	.2743
16	.3239	.2429	.2743	.3086	.3239	.362	.2743
17	.4858	.2429	.3772	.2401	.3563	.3239	
18	.4858	.2429	.3772	.4115	.4534	.4191	
19		.5668	.6516	.5487	.6478	.5868	
20	.6478	.6154	.6859	.6154	.6478	.5668	
21	.5182	.5668	.5487	.5182	.6478	.5182	
22	.4858	.4858	.4801	.4534	.5868	.4534	
23	.4694	.4525	.5144	.4458	.6154	.4525	.4458
24	.4115	.0366	.362	.5487	.4115	.6173	.4525
Max	.6859	.6154	.724	.703	.6859	.6859	.6697
Min	.2915	.0366	.2743	.1372	.2683	.2715	.2401
Avg	.4415	.3674	.4561	.4548	.4920	.4657	.4301

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194035 / 33/11 kv JAGAJI SUBSTATION

Feeder No / Name : 206 / 11 KV KOND AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	2.1948		1.8004	1.8861	1.6461	1.9433	1.9433
10	2.2672	1.668	2.2291	1.9204	1.7814	1.668	1.8519
11	1.9433	1.7328	2.1605	2.0576	1.7814	1.7814	1.8519
12	2.1052	1.7814	2.1262	2.0576	1.7814	1.8623	1.8519
13	1.9433	1.5384	2.0233	1.989	1.6518	2.0243	1.8176
14	1.7814	1.6842	2.0576	1.8519	1.9433	1.7814	1.8176
15	1.6194	1.6518	2.0233	1.8519	1.6766	1.8623	1.8519
16	1.9433	1.7004	2.1262	1.8861	2.0119	1.7814	1.8519
17	1.1336	1.2146	.9945	1.406	1.1336	1.4575	1.2955
18	1.1336	.9717	1.166	1.3717	1.2955	1.2146	1.2955
19	1.2071	1.2146	1.1145	1.3717	1.0364	1.2146	1.1336
20	1.166	1.2146	1.0288	1.1336	1.1174	1.2146	.9717
21	1.0059	1.0526	1.0288	1.1336	.9717	1.1012	.9555
22	.9717	1.1336	.9945	1.0526	.9221	1.0059	.9717
23	.8907	.9717	1.0631	.9945	.8097	.8421	1.0288
24		.8097	.9717	.9602	.9602	.8745	.8097
Max	2.2672	1.7814	2.2291	2.0576	2.0119	2.0243	1.9433
Min	.8907	.8097	.9717	.9602	.8097	.8421	.8097
Avg	1.5538	1.3560	1.5568	1.5578	1.4075	1.4768	1.4563

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194035 / 33/11 kv JAGAJI SUBSTATION

Feeder No / Name : 207 / bhikar sarola ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9259	.9717	.9717	.8916	.8916	.9717	.9717
2	.9259	.8907	.9717	.9259	.9259	.8907	.9717
3	.8916	.8718	.9717	.8916	.9602	.9069	.9717
4	.8916	.9717	.9717	.9602	1.0288	.8745	.9717
5	.8573	.8097	1.0526	.9945	1.0631	.8097	.9717
6	.9259		1.0526	1.166	1.1145	1.0288	1.166
7	.8916		1.2146	.9259	1.406	1.2517	1.3117
8	.9602		1.2146	1.166	1.2517	1.0288	1.166
10			.1372				
21			.0686				
23		.0324				.0324	
24	.8916		.0324	.823			.0324
Max	.9602	.9717	1.2146	1.166	1.406	1.2517	1.3117
Min	.8573	.0324	.0324	.823	.8916	.0324	.0324
Avg	.9068	.758	.7872	.9716	1.0802	.8661	.9483

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194038 / 33 / 11 KV Wahgoli

Feeder No / Name : 203 / SUT-MILL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621		.6401	.4877	.823	.7621	.4572
2	.7926	.7621	.6706	.5182	.823	.7621	.5182
3	.823	.7926	.6859	.5335	.9145	.823	.5487
4	.884		.6097	.5639	.9145	.823	.6097
5	.9145	.8383	.6401	.5944	.945	.8535	.6859
6	.945	.8535	.9145	.6097	.945	.9145	.7621
7	.9755	1.0212	.8688	.6401	.9145	.9145	.7926
8			.8383	.6706	.9145	.945	.7621
9	.9145	.6097	.0305		.8535	.823	.7926
10	.0762	.061	.0305	.061	.0762	.061	.0457
11	.061	.061	.0305	.061	.061	.0457	.0762
12	.0457	.0457	.0305	.0457		.0305	.061
13	.0305	.0457		.0305	.0457	.0305	.061
14	.0305	.0457	.0305	.0305	.0457	.0457	
15	.0305	.0457	.0305	.0305	.0457	.0457	
16	.0305	.061	.0305	.0305	.061	.0457	.061
17		.0457	.0457	.0305	.061	.061	.0762
18	.0457	.0457	.061		.061	.061	.061
19	.0762	.0457	.0762		.061	.0762	.061
20	.0762	.0457	.0914	.061	.061	.0914	.061
21	.0762	.0457	.0762	.061	.061	.0914	.061
22	.061	.0457	.0762	.061	.061	.0762	.0305
23	.061	.0305	.061	.0305	.061	.0762	.0305
24	.7316	.7621	.6097	.4572	.3658	.6706	.381
Max	.9755	1.0212	.9145	.6706	.945	.945	.7926
Min	.0305	.0305	.0305	.0305	.0457	.0305	.0305
Avg	.3838	.3005	.3121	.2671	.3989	.3804	.3180

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194038 / 33 / 11 KV Wahgoli

Feeder No / Name : 206 / 11 Kv Wanewadi

SINGLE PHASING

Feeder KV- 11 / INCOMING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1829	.1372	.1524	.1524	.1829	.1524
2	.1829	.1829	.1524	.1829	.1524	.1829	.1677
3	.2134	.1829	.1524	.2134	.1524	.1829	.1981
4	.2134	.1981	.2134	.2286	.2134	.2134	.2439
5	.2134		.2439	.2286	.2439	.2439	.2743
6	.2439	.2134	.2743	.2591	.2743	.2439	.2896
7	.2591	.2743	.2591	.2286	.3048	.3963	.2896
8	.2743	.3048	.2286	.2439	.3048	.2134	.2439
9	.3048	.1829	.1524	.2134	.2134	.1829	.2286
10	1.2193	1.1888	1.0059	1.2346	1.0974	1.0974	.9907
11	1.387	1.4632	1.4632	1.4175	1.2955	1.3413	1.5242
12	1.3717	1.4022	1.4937	1.4175		1.3717	1.5089
13	1.2803	1.3108	1.4937	1.3717	1.4327	1.326	1.4937
14	1.3108	1.1888	1.4632	1.2803	1.4632	1.3717	
15	1.2803	1.1431	1.4937	1.2498	1.4022	1.2955	
16	1.2346	1.2498	1.4937	1.2193	1.3565	1.387	1.2955
17	1.2193	1.2193	1.4632	1.3108	1.3717	1.5546	1.2193
18	.1219	.1219			.1219	.1067	.1524
19	.1524	.1524	.2439		.2439	.1829	.2134
20	.2896	.2743	.2896	.2134	.2439	.2743	.2439
21	.2286	.2286	.2591	.2743	.2439	.2439	.2439
22	.2134	.1981	.2286	.2743	.2134	.2286	.2134
23	.2134	.1677	.2134	.2134	.1829	.1981	.2134
24	.1981	.1981	.1524	.1829	.2134	.1829	.1829
Max	1.387	1.4632	1.4937	1.4175	1.4632	1.5546	1.5242
Min	.1219	.1219	.1372	.1524	.1219	.1067	.1524
Avg	.5754	.5752	.6335	.6187	.5606	.5919	.5265

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194038 / 33 / 11 KV Wahgoli

Feeder No / Name : 207 / 11 Kv Sarola

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8688	.6401	.7316	.7926	.823	.7621	.6554
2	.884	.9145	.7926	.823	.823	.823	.6859
3		.9602	.8383	.8688	.8535	.823	.7011
4	.945	.9755	.945	.945	.8535	.8535	.7316
5	.9755	.9907	1.0364	1.0059	.9145	.8535	.823
6	.9907	1.0364	1.0669	1.0364	.9755	.9145	.8535
7	1.0364		1.0974	1.0669	1.0364	.9145	.9297
8		1.0669	.8688	1.0517	1.0364	1.0364	.9755
9	.9297	1.0364	.8535	.9907	.9145	.945	.9907
10	.381	.4268	.3048	.4572	.4268	.3658	.4877
11	.3201	.3658	.2134	.4725	.3658	.3353	.4572
12	.2591	.3048	.2439	.3658		.2743	.442
13	.2134	.3048	.2743	.2896	.2591	.2286	.4268
14	.2286	.2896	.2439	.1524	.2896	.2743	.4115
15	.2134	.2591	.2134	.1524	.2743	.2439	
16	.1829	.2743	.2134	.1372	.2896	.2134	.3048
17	.2134	.2439	.1677	.1524	.3353	.3048	.3963
18	.381	.3506	.3658		.3353	.381	.4572
19	.6097	.4572	.5792		.6097	.4877	.4572
20	.6097	.5487	.5335	.3048	.5487	.5487	.4572
21	.6097	.503	.4572	.6706	.5487	.4572	.3963
22	.5792	.4115	.4268	.6097	.4572	.4115	.3658
23	.3963	.3048	.3658	.5487	.4572	.3658	.3353
24	.8383	.7926	.6859	.7316	.4572	.7621	.6249
Max	1.0364	1.0669	1.0974	1.0669	1.0364	1.0364	.9907
Min	.1829	.2439	.1677	.1372	.2591	.2134	.3048
Avg	.5757	.5851	.5633	.6194	.6037	.5658	.5812

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194049 / 33 KV UPLA

Feeder No / Name : 201 / 11 Kv Upla feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305			.0351		.0358	
2	.0305		.0305	.0354		.0358	.0305
3	.0305			.0358			
4	.0305		.0305	.0358		.0358	.0305
5	.0305			.0351			
6	.0305		.0305	.0351		.0354	.0305
7	.0305			.0351			
8	.0305		.0305	.0351		.0351	.0305
9	.0354		.0305			.0305	.0305
10	.0354	.0457	.0351		.0354	.0343	
11	.0354		.0354		.0354	.0305	
12		.0305			.0354	1.448	
13			.0532			1.3717	
14		.0305	.0532			.0305	
15	.0351		.0532			.0305	
16	.0351	.0305	.0532			.0305	
17	1.7204		1.6644			1.9052	
18		2.1338	1.8976			1.9814	
19			2.0873			1.9814	
20		2.1338	2.1052		.9831	1.9814	
21			2.13			1.9814	
22		2.0576	2.0972		1.065	1.9052	
23		2.0576	2.0243			1.829	
24	.0305		1.9814	1.9433		.9614	1.7528
Max	1.7204	2.1338	2.13	1.9433	1.065	1.9814	1.7528
Min	.0305	.0305	.0305	.0351	.0354	.0305	.0305
Avg	.1448	1.065	.8644	.2473	.4309	.8434	.3176

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194049 / 33 KV UPLA

Feeder No / Name : 202 / 11 Kv Shingoli

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.945			.9945			.7621
2	.945		.9145	.9831		.9282	
3	.9755			1.0277			.8383
4	.9755		1.0669	1.0277		.9614	
5	1.0059			1.1142			.945
6	1.0364		1.1431	1.1822		1.2289	
7	1.0669			1.278			1.0059
8	1.0364		.9907	.7373		1.1336	.9755
9	.0526		.0457			.0457	.0457
10	.0526	.0457	.0343		.0526	.0457	
11	.0343		.0514		.0526	.0457	
12	.0347	.0457	.0351		.0532	.0457	
13	.0343		.0526		.0526	.0457	
14	.0343	.0457	.0526		.0526	.0457	
15	.0343		.0532		.0686	.0457	
16	.0347	.0457	.0701		.0701	.0457	
17	.0351		.0701		.0701	.0457	
18		.0457	.0686		.0472	.0457	
19			.0686		.0701	.0457	
20		.0457	.0701		.0701	.0457	
21			.0701				
22		.0457	.0701		.0701		
23		.0457	.0709				
24	.945		.0457	.0532		.0701	.0457
Max	1.0669	.0457	1.1431	1.278	.0701	1.2289	1.0059
Min	.0343	.0457	.0343	.0532	.0472	.0457	.0457
Avg	.5155	.0457	.2522	.9331	.0608	.2865	.6597

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194049 / 33 KV UPLA

Feeder No / Name : 203 / UPALA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229			.2401			
2	.2058		.2229	.2401		.2058	.2229
3	.2058			.2454			
4	.2401		.2401	.2804		.2035	.2229
5	.2743			.3052			
6	.3429		.3429	.3601		.2984	.3601
7	.3772			.3647			
8	.3429		.3429	.3605		.3647	.3429
9	.2984		.3086			.2743	.3429
10	.2652	.3429	.2683		.3052	.2401	
11	.2321	.2401	.2321		.2652	.2401	
12	.1326		.2012		.1989	.2401	
13	.2012		.1886		.1696	.2401	
14	.1696		.1715		.1715	.2401	
15	.1696	.2058	.2035		.2058	.2401	
16	.1823		.2035		.2058	.2401	
17	.1865	.2401	.2204		.2058	.2401	
18			.2652		.2713	.2743	
19		.3944	.3315		.3353	.3429	
20			.3978		.3856	.3429	
21		.4115	.3688			.3429	
22			.2984		.3052	.3086	
23		.2743	.2683			.2401	
24	.2229		.2401	.2572		.2401	.2401
Max	.3772	.4115	.3978	.3647	.3856	.3647	.3601
Min	.1326	.2058	.1715	.2401	.1696	.2035	.2229
Avg	.2374	.3013	.2658	.2949	.2521	.2680	.2886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194049 / 33 KV UPLA

Feeder No / Name : 204 / 11 KV SHINGOLI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886			.2058			
2	.1886		.1886	.2103		.1696	.1715
3	.1886			.2058			
4	.2058		.1886	.2103		.1886	.1715
5	.2229			.2103			
6	.2572		.2401	.2481		.2204	.2572
7	.2229			.2321			
8	.2058		.2058	.2321		.2012	.2229
9	.1715		.1715			.2058	.2229
10	.1715	.2229	.2155		.2035	.1715	
11	.1326	.1715	.1989		.1865	.1715	
12	.1341		.1989		.1402	.1715	
13	.1341		.2155		.1372	.1715	
14	.1526		.1989		.1357	.1715	
15	.1526	.1372	.2155		.1677	.1543	
16	.1696		.2347		.1715	.1372	
17	.1658	.2058	.2321		.1715	.1715	
18			.2347		.2035	.2401	
19		.2743	.2347		.2204	.2401	
20			.2515		.2374	.2229	
21		.2401	.2454			.2229	
22			.2279		.2058	.2229	
23		.2058	.2321			.2058	
24	.1829		.1829	.2401		.1886	.1886
Max	.2572	.2743	.2515	.2481	.2374	.2401	.2572
Min	.1326	.1372	.1715	.2058	.1357	.1372	.1715
Avg	.1804	.2082	.2157	.2217	.1817	.1925	.2058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194049 / 33 KV UPLA

Feeder No / Name : 205 / 11 KV WARUDA AG FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0716			
2	.0914		.0762	.0724		.0701	.1067
3				.0724			
4	.0914		.0762	.0732		.0895	.1067
5				.0724			
6	.0914		.0762	.0914		.0886	.1067
7	.1029			.0857			
8	.0914		.0762	.0876		.1227	
9	1.587		1.4937			1.448	1.3717
10		1.3717	1.6032		1.4723	1.5775	
11		1.448	1.5524		1.4232	1.2193	
12	1.4089		1.5364		1.4083	1.2193	
13	1.4746	1.5089	1.5547		1.3279	1.2193	
14	1.4723		1.5061		1.2651	1.2193	
15	1.6078	1.2955	1.4899		1.3283	1.3717	
16	1.7124		1.6032		1.4706	1.4327	
17	.0857	.0762	.0686		.0857	.061	
18			.1029		.0876	.0762	
19		.0762	.12		.1227	.1219	
20			.1227		.124	.1219	
21		.0762	.1063			.1219	
22			.1063		.1063		
23		.0762	.1063			.1067	
24	.0914		.0762	.0886		.0886	.1067
Max	1.7124	1.5089	1.6032	.0914	1.4723	1.5775	1.3717
Min	.0857	.0762	.0686	.0716	.0857	.061	.1067
Avg	.7622	.7411	.6727	.0795	.8518	.6198	.3597

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194050 / 33/11 KV KHED S/STN

Feeder No / Name : 201 / 11 Kv Khed

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1984	.9907	1.1961	1.286	1.0688	1.2955	1.2944
2	1.166	1.0669	1.2452		1.1012	1.3717	1.3108
3	1.1984	1.2003	1.278	1.3717	1.1174	1.3717	1.3927
4	1.2955	1.286	1.4586		1.2793	1.448	1.5238
5	1.5061	1.4575	1.5912		1.6057	1.5242	1.6712
6	1.668	1.6975	1.861	1.9204	1.9919	1.6766	1.873
7	1.7004	2.1262	2.1216		1.9757	1.7985	2.0317
8	1.749	1.9719	2.0719	1.829	1.9109	1.6766	1.8023
9	.3563		.3401	.3353	.3163	.2105	.503
10		.407	.2753	.2896	.3222	.2591	.3048
11	.9116	.2743	.2105	.2134	.2458	.2267	.1677
12	.1823	.2204	.1943	.2134	.2294		.1829
13	.1658	.2204	.2429	.1981	.1966	.1781	.1677
14	.1802	.2374			.2204		.2134
15	.1581		.2591		.2204		.1677
16	.1823	.2347	.2429		.2204		.1677
17		.3258		.3077	.3048	.2294	.2429
18	.3048	.3391		.4096	.3048	.407	.3401
19	.3506	.4207			.3506	.2543	.3563
20	.4877	.4748		.583	.5182	.5426	.4372
21	.4268	.4578		.4588	.4268	.4527	.4534
22	.3353	.3561		.4096	.3658	.3561	.3887
23	.3353	.2743		.3725	.3048	.3113	.3401
24	1.2955	.2743	.3052	.3772	.3401	.3048	.2949
Max	1.749	2.1262	2.1216	1.9204	1.9919	1.7985	2.0317
Min	.1581	.2204	.1943	.1981	.1966	.1781	.1677
Avg	.7797	.7416	.9309	.6610	.7058	.7948	.7345

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194050 / 33/11 KV KHED S/STN

Feeder No / Name : 202 / ALNI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.2743	.3052	.3086	.285	.3086	.3052
2	.3018	.2743	.3052		.3018	.3086	.373
3	.3353	.2743	.4239	.3429	.3185	.3429	.4024
4	.4694	.4287	.5365		.4024	.3429	.4694
5	.5533	.6001	.6371		.4862	.5487	.5571
6	.6371	.7373	.6554	.7202	.6036	.6344	.6539
7	.6203	.7373	.7122		.6203	.6859	.6241
8	.6036	.6859	.6613	.5792	.6371	.6097	.5407
9	2.0454		1.9989	1.9204	2.0557	2.2969	1.89
10	2.1434		1.917	1.9509	2.0809	2.146	1.4937
11	2.0481	2.2977	1.9006	1.9814	2.1026	2.1293	1.8442
12	2.1365	2.0153	2.0153	1.9357	1.7869		2.0576
13	2.0856	2.0348		1.9814	2.0348	1.8778	1.6309
14	1.9662	2.0178	1.8351		2.0233	1.8945	1.7375
15	1.989	1.95	1.9006		1.95	1.9784	1.7833
16	2.0715	1.8991	2.1136		1.9161	.2347	1.8595
17	.2915	.1886		.3113		.2622	.2785
18	.3601	.3772		.4424	.3429	.3353	.3856
19	.4801	.503		.5735	.463	.4586	.4694
20	.6344	.7087		.5898	.6516	.5693	.6706
21	.5487	.4917		.4915	.5487	.4424	.5365
22	.4287	.3605		.4096	.4115	.3768	.3768
23	.3429	.3052		.3277	.3429	.2949	.3185
24	.2949	.3086	.2743	.2915	.3018	.3086	.2713
Max	2.1434	2.2977	2.1136	1.9814	2.1026	2.2969	2.0576
Min	.2915	.1886	.2743	.2915	.285	.2347	.2713
Avg	.9871	.8850	1.1370	.8916	.9855	.8429	.8971

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194050 / 33/11 KV KHED S/STN

Feeder No / Name : 203 / VIMANTAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.2286	.1505	.1886	.2134	.1829	.1505
2	.16	.2286	.1204		.1981	.1829	.1505
3	.1734	.2286	.1204	.1543	.1829	.1829	.1158
4	.1867	.2286	.1448		.1829	.1981	.1158
5	.2	.2667	.1448		.2286	.2134	.1806
6	.1867	.2858	.1669	.2058	.2439	.2286	.2172
7	.2	.2858	.2107		.2286	.2286	.2229
8	.1734	.2858	.1981	.2134	.2134	.2439	.2408
9	.1334		.16	.2477	.1957	.2286	.1829
10	.1448		.1734	.2286	.1614	.1829	.2134
11	.1204		.1334		.1739	.1524	.1981
12	.0869	.1372	.0934	.1524	.1303		.1829
13	.1067		.1334	.1334		.1219	.1829
14	.1158		.1067		.1189	.1524	.1524
15	.0903		.1334		.1355	.1829	.1524
16	.1158	.1067	.12		.1524	.1524	.1524
17	2.0767	1.6255		1.347	2.0576	1.475	1.6766
18	1.8671	1.4784		1.347	2.0957	1.6406	1.6309
19	2.0386	1.5804		1.4137	2.0195	1.6049	1.6004
20	2.0767	1.5653		1.3603	2.0576	1.5158	1.5009
21	1.9624	1.4624		1.267	2.0195	1.3998	1.448
22	1.9052	1.386		1.2003	1.9052	1.4148	1.3717
23	1.6385	1.4118		1.1336	1.7528	1.3546	1.2334
24	.2	1.7337	1.3847	1.4918	1.2498	1.6956	1.2793
Max	2.0767	1.7337	1.3847	1.4918	2.0957	1.6956	1.6766
Min	.0869	.1067	.0934	.1334	.1189	.1219	.1158
Avg	.6728	.8070	.2174	.7553	.7790	.6494	.6064

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194050 / 33/11 KV KHED S/STN

Feeder No / Name : 204 / 11 KV KINI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3887	.3467	.4572	.5487	.3201	.3334	.4877
2	.3628	.3201	.506		.2934	.3334	.5182
3	.3239	.3429	.4586	.583	.3334	.3334	.6009
4	.3757	.4001	.5693		.3868	.4001	.6325
5	.4275	.381	.6642		.4668	.5335	.6483
6	.4923	.4801	.7432	.7202	.6401	.6135	.6874
7	.5182	.7316	.852		.6535	.4801	.7045
8	.5571	.6859	.7701	.7316	.6401	.5335	.7209
9	.013		.0114	.0114	.0152	.0145	.0095
10	.0147		.0114		.0152	.0145	.0095
11	.017		.0114	.0114	.0151	.0145	.0114
12	.0164	.017	.0114	.0095	.0152		.0095
13	.0164		.0114	.0095	.0162	.0145	.0095
14	.0164	.017	.0114		.0168	.0145	.0095
15	.0164	.017	.0114		.0152	.0145	.0095
16	.0166	.0168	.0114		.017	.0145	.0095
17	.0114	.0164		.0114	.0114	.0152	.0076
18	.0114	.0168		.0114		.0152	.0076
19	.0114	.0158		.0114	.0095	.0152	.0076
20	.0114	.0152		.0114	.0095	.0152	.0076
21	.0095	.0164		.0114	.0095	.0152	.0076
22	.0095	.0164		.0114	.0095	.0152	.0076
23	.0095	.0158		.0114	.0095	.0166	.0095
24	.4405	.0076	.0152	.0171	.013	.0095	.0152
Max	.5571	.7316	.852	.7316	.6535	.6135	.7209
Min	.0095	.0076	.0114	.0095	.0095	.0095	.0076
Avg	.1703	.1938	.3016	.1701	.1710	.1643	.2145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194062 / 33 kv Padoli-A

Feeder No / Name : 201 / Padoli-A

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3757	.439	.4129	.3658	.4141	.3506	.396
2	.3742	.4024	.4129	.3658	.3953	.3658	.4129
3	.4508	.439	.4894	.3658	.3753	.3658	.3753
4	.4889	.5121	.5255	.4024	.4879	.439	.3475
5	.5442	.6219	.5255	.5853	.5255	.5658	.5025
6	.5818	.6584	.5613	.6584	.6005	.5658	.5794
7	.6381	.6219	.563		.6381		.6017
8	.4884		.4879	.4755	.5636		.6005
9	.4316	.439	.4504	.439			
10	1.3096	1.8004	2.0119	1.1283	1.5364	1.8004	1.3565
11	2.0668	2.104	2.0119		1.9204	1.9183	1.4413
12	2.0851	2.0288	2.0119	2.0329	2.0182	1.9517	1.56
13	2.0851	2.008	2.0668	2.1459	2.0559	1.8766	1.5261
14	2.0485	1.9349	1.9022	2.0706	1.9805	1.8089	1.5546
15	1.7924	1.9517	1.9022	1.9892	1.6598	1.841	1.5181
16	2.1948	1.9872	1.957	2.0706	1.6221		1.4998
17	2.0485	1.8766	2.0485	2.0954	1.905	1.8766	1.4998
18	.4024	.3003		.3003	.3109	.2635	.2987
19		.5647	.4115	.4518	.439	.4504	.3734
20	.5853	.6011	.4801	.6011	.5121	.6005	.5228
21	.5487	.563	.4801	.563	.5121	.5624	.5601
22	.5121	.5271	.4115	.5255	.4755	.5239	.4854
23	.4755	.4508	.3772	.5255	.5121	.4894	.4668
24	.4504	.4755	.4513	.4024	.4495	.4207	.4508
Max	2.1948	2.104	2.0668	2.1459	2.0559	1.9517	1.56
Min	.3742	.3003	.3772	.3003	.3109	.2635	.2987
Avg	.9991	1.0134	.9980	.9346	.9526	.9519	.8230

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194062 / 33 kv Padoli-A

Feeder No / Name : 202 / Mendha

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.319	.2926	.3378	.3658	.3753	.2561	.3423
2	.3003	.2926	.3003	.3658	.3003	.2561	.3378
3	.2993	.2926	.3003	.3292	.3003	.2926	.3003
4	.3003	.4024	.4884	.3292	.4504	.3292	.2993
5	.5255	.4755	.4854	.4755	.563	.5658	.5249
6	.563	.4755	.526	.6219	.6005	.6036	.531
7	.6005	.4755	.563		.5835	.6413	.556
8	.4129		.4692	.4024	.5647	.4755	.5812
9	.3753	.2926	.3003		.3368	.3086	.2445
10	1.1647	1.0288	1.3535	.8632	.9383	1.0974	.7122
11	1.6461	1.4825	1.5364			1.4262	1.2887
12	1.6461	1.4967	1.5364	1.3887		1.1949	1.3565
13	1.6461	1.3699	1.7193	1.5373	1.3203	1.0277	1.2887
14	1.6827	1.126	1.4632	1.4262	1.2449	1.3915	1.363
15	1.3535	1.3713	1.4632	1.3136	1.2449	1.4262	1.2803
16	1.4632	1.4638	1.4998	1.4277	1.1694	1.4262	1.3169
17	1.3717	1.4682	1.5364	1.5013	1.4146	1.3136	1.5123
18	.1829	.2627	.1372	.2058	.2195	.2259	.0747
19		.4518		.3753		.2993	
20	.439	.5228		.5255	.4024	.4504	.4854
21	.4572	.4504	.4115	.4879	.439	.5255	.5228
22	.3658	.4129	.4115	.4879	.439	.4097	.4294
23	.2926	.4137	.3429	.4504	.4024	.4129	.4108
24	.3381	.2195	.3753	.3658	.4141	.2454	.3753
Max	1.6827	1.4967	1.7193	1.5373	1.4146	1.4262	1.5123
Min	.1829	.2195	.1372	.2058	.2195	.2259	.0747
Avg	.7716	.7191	.7981	.7260	.6535	.6917	.7015

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194062 / 33 kv Padoli-A

Feeder No / Name : 203 / Ghugi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0643	1.6827	2.2332	1.3535	2.0706	1.3169	2.3317
2	2.4959	1.8656	2.4021	1.6095	2.4771	1.6461	2.6353
3	2.5548	2.4874	2.6273	1.8107	2.6648	2.0119	2.7774
4	2.9935	2.963	2.6729	2.1033	3.0117	2.7161	2.7266
5	3.2487	3.1824	3.0589	2.9264	3.3506	3.0556	3.0026
6	3.3404	3.2373	3.1903	2.9447	3.46	3.0178	3.0777
7	3.3848		3.2653		3.5764	2.9424	2.6702
8	2.9711		3.3029		3.3779	2.7801	2.8337
9	2.7023	3.1093	2.9335	2.6337	2.7996	2.572	2.6193
10	.2625	.3429	.2561	.1871	.2728	.1029	.2035
11		.319	.1097	.1873	.1097	.2252	.1526
12		.1689	.1097	.1501	.0377	.188	.0848
13	.1097	.1501	.1097	.1497	.0377	.1504	.1097
14	.1097	.1497	.1097	.131	.0377	.1172	.0183
15	.1097	.1501	.1097	.1315	.0377	.1314	.0183
16	.1097		.1097	.1126	.0377	.1126	.112
17	.1097	.1867	.1097	.1126	.0377	.2259	.1307
18	.1097	.319	.1097	.2252	.0732	.3003	.1494
19		.563	.3086	.4316	.0732	.4879	.2054
20	.3292	.6023	.3772	.6005	.1829	.563	.2987
21	.3292	.563	.3772	.5641	.3292	.5956	.3361
22	.3292	.5255	.3429	.4889	.3292	.5138	.3547
23	.2926	.5255	.3086	.4894	.3292	.4879	
24		1.0974	1.4075	.7682	1.5764	1.0517	1.6188
Max	3.3848	3.2373	3.3029	2.9447	3.5764	3.0556	3.0777
Min	.1097	.1497	.1097	.1126	.0377	.1029	.0183
Avg	1.3978	1.1519	1.2476	.9142	1.2621	1.1380	1.2377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194062 / 33 kv Padoli-A

Feeder No / Name : 204 / Swami Agro Industry
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.0188	.0183					.0364
9		.0183	.0188		.0188	.0171	
10	.0187	.0171	.0183		.0343	.0343	.017
11	.0366	.0375	.0183		.0183	.0375	.017
12	.0366	.0188	.0183	.0188	.0189	.0374	.017
13	.0549	.0188	.0183	.0374	.0189	.0374	.0187
14	.0183	.0188	.0183	.0375	.0189	.0375	.0183
15	.0549	.0188	.0183	.0375	.0189	.0375	.0183
16	.0366	.0188	.0183		.0377	.0375	.0183
17	.0183		.0183	.0375	.0189		.0187
18	.0183		.0171		.0189		
19			.0171			.0375	.0187
Max	.0549	.0375	.0188	.0375	.0377	.0375	.0364
Min	.0183	.0171	.0171	.0188	.0183	.0171	.017
Avg	.0312	.0206	.0181	.0337	.0223	.0349	.0198

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194065 / 33 kv Takli-D

Feeder No / Name : 201 / Yeoti

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1372	.1143		.1372	.1715	.0762
2	.1372	.1372	.1143		.1372	.1715	.0762
3	.1372	.1372	.1143	.1372	.1372	.1715	.0762
4	.1715	.1715	.1334	.1715	.1372	.2058	.1143
5	.2058	.2401	.2667		.2058	.2229	.2286
6	.3772	.3429	.381		.2743	.3944	.3048
7	.4115	.3429	.3048		.3086	.4115	.3048
8		.2743	.3048		.2743	.3429	.3048
9	2.572	2.8197	2.6673	2.3594	2.2634		2.6673
10	2.5377	2.8197		2.4249	2.2291	2.6673	2.3205
11	2.5377	2.8197		2.3594	2.2634		
12	2.6749	2.6673		2.332	2.2291	2.4387	
13	2.332	2.6673		2.0405	2.1948	2.3624	
14	2.0576	2.7625		2.0119	2.1434	2.2862	
15	2.2939			2.0972	2.4006	2.4387	
16	2.2725	2.0957	2.2939	2.2131	2.4348	2.4387	
17	.0648		.1372	.1029		.0762	
18	.1029	.0762	.1372	.1372	.1715	.0762	
19	.1372	.2286	.1372	.2058	.2572	.2286	.128
20	.2058	.3048	.2058	.2058	.3086	.3048	.253
21	.1372	.2286	.2058	.1372	.2572	.1524	.192
22	.1372	.1524	.1372	.1372	.2058	.1143	.128
23		.1524	.1372	.1372	.1715	.0762	.0972
24	.1372	.1143		.1372	.1372	.0762	
Max	2.6749	2.8197	2.6673	2.4249	2.4348	2.6673	2.6673
Min	.0648	.0762	.1143	.1029	.1372	.0762	.0762
Avg	.9899	.9860	.4584	1.0749	.9252	.8104	.4848

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194065 / 33 kv Takli-D

Feeder No / Name : 202 / Irla

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.1524		.1372	.1715	.1715
2	.1715	.1715	.1524		.1372	.1715	.1715
3	.1715	.1715	.1524	.1372	.1715	.1715	.1715
4	.2058	.1715	.1905	.1715	.1715	.2058	.1905
5	.2229	.1886	.2286		.2058	.2058	.2286
6	.1715	.2058	.3048		.2401	.2229	.2667
7	.2572	.3086	.2667		.3086	.2572	.2477
8	.2401	.2401	.2667		.2743	.2572	.3239
9	.1886	.2096	.2667	.2743	.2572		.2667
10	.1372	.1905		.1886	.1715	.1905	.2105
11	.1029	.1715		.1372	.1715	.1715	.1619
12	.1029	.0381		.1029	.12	.1524	
13	.1029	.1143		.1029	.12	.1524	.1296
14	.1029	.1143		.1029	.12	.1524	.1296
15	.1029	.1143		.1029	.1372	.1524	.1296
16	.1029	.1524	.1029	.1029	.12	.1524	.1457
17	2.0553		2.3304	2.3137	2.4863	2.7435	2.2211
18	2.2801	2.6673	2.2611	2.3663	2.452	2.7244	2.2542
19	2.0919	2.6292	2.1956	2.146	2.2805	2.4958	2.1879
20	1.8861	2.3624	2.1795	2.079	2.2291	2.3243	2.0553
21	1.8107	2.3243	2.0622	2.0119	2.0576	2.2291	1.989
22	1.7532	2.3624	2.0119	2.0119	2.0233	2.2291	1.9725
23	1.7833	2.2862	1.9784	2.0119	2.0233	2.2291	1.9062
24	.1886	2.2672		1.9281	1.9448	2.2291	
Max	2.2801	2.6673	2.3304	2.3663	2.4863	2.7435	2.2542
Min	.1029	.0381	.1029	.1029	.12	.1524	.1296
Avg	.7058	.8536	1.0061	1.0162	.8484	.9562	.7969

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194065 / 33 kv Takli-D

Feeder No / Name : 203 / Takali-D

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003	1.3717	1.7147		1.4403	1.3375	1.6194
2	1.2003	1.3717	1.7147		1.4403	1.3717	1.6194
3	1.2003	1.406	1.7147	1.5089	1.4746	1.3717	1.6194
4	1.2174	1.406	1.7147	1.5432	1.5089	1.4575	1.6766
5	1.3546	1.4746	1.8861		1.6804	1.5089	1.7147
6	1.5947	1.6118	1.9624		1.7833	1.7833	1.829
7	1.7833	1.7101	2.0386		1.8442	1.9033	1.9052
8	1.749	1.7833	1.8671		1.861	1.7833	1.848
9	.12	.0953	.0762	.0857	.0857		.0381
10		.0572		.0686	.0686	.0762	.081
11	.0686	.0381		.0514	.0171		.0486
12	.0343	.0381		.0343		.0381	
13	.0171	.0381		.0343		.0572	.0324
14	.0171	.0381		.0343		.0572	.0324
15	.0171	.0381		.0343	.0171	.0381	.0324
16	.0343	.0381	.0514	.0343	.0343	.0572	.0486
17	.0343	.0572	.0514	.0343	.0343	.0572	.0486
18	.0514	.0572	.0514		.0514	.0572	.0486
19	.0686	.1143	.0686	.1029	.0686	.1143	.08
20	.1029	.0953	.1029	.12	.1029	.1143	.112
21	.0857	.1143	.0857	.0857	.1029	.0953	.08
22	.0686	.0762	.0686	.0514	.0686	.0762	.064
23	.0686		.0514	.0514	.0514	.0762	.0486
24	1.2174	.0572		.0514	.0514	.0572	
Max	1.7833	1.7833	2.0386	1.5432	1.861	1.9033	1.9052
Min	.0171	.0381	.0514	.0343	.0171	.0381	.0324
Avg	.5785	.5690	.8953	.2310	.6565	.6131	.6649

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

WASHI S/DN.[820] BU 4820

Substation No/ Name :- 194053 / 33/11 KV Terkheda

Feeder No / Name : 202 / 11 KV INDAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAY-17	24-MAY-17	25-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	.3429	.5258		.6135
11			.7011	
12	.7011			
13		.8192		
14	.6001			
16	.7888	.3391	.8764	.7888
Max	.7888	.8192	.8764	.7888
Min	.3429	.3391	.7011	.6135
Avg	.6082	.5614	.7888	.7012

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

WASHI S/DN.[820] BU 4820

Substation No/ Name :- 194053 / 33/11 KV Terkheda

Feeder No / Name : 204 / 11 KV WADJI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	25-MAY-17	26-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.381		.381	.5716	
4		.381	.4763	.6668	
5	.4382				
6			.6268		
8	.7164	.7164	.7011	.7164	
9					.6201
24		.7621	.381	.381	
Max	.7164	.7621	.7011	.7164	.6201
Min	.381	.381	.381	.381	.6201
Avg	.5119	.6198	.5132	.5840	.6201

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758] BU 4758

Substation No/ Name :- 194008 / YENEGUR

Feeder No / Name : 201 / 11KV DALIMB AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8519	1.6804	1.989	1.7833	1.6766	1.5089	
2	1.989		2.2291	1.8519	1.6766	1.6004	
3	1.989		2.2634	1.8519	1.6766	1.6004	
4	2.0576	1.406	2.4006	2.1262		1.7985	
5	2.4006	1.4403	2.7435	2.4006	1.829		
6	2.7092		3.0693	2.9321	2.4996	2.4387	
7	2.915		3.275	3.1036	2.774	2.5911	
8	2.3663	2.4177	3.1379	3.0693	2.713	2.2253	
9	2.6235	2.915	3.1379	2.9321	2.713	2.4387	
10							2.1033
11							2.5758
12							2.5758
13							2.692
14							2.572
15							2.4863
16							2.7435
17							3.0521
24	1.406	1.6632		1.6632	1.7661	1.5775	
Max	2.915	2.915	3.275	3.1036	2.774	2.5911	3.0521
Min	1.406	1.406	1.989	1.6632	1.6766	1.5089	2.1033
Avg	2.2308	1.9204	2.6940	2.3714	2.1472	1.9755	2.6001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758] BU 4758

Substation No/ Name :- 194008 / YENEGUR

Feeder No / Name : 202 / 11KV SALEGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4973	.4458	.4973	.4115	.4458	.4973	.3086
2	.5144		.5144	.4115	.4458	.4973	.2915
3	.5144	.3429	.5487	.4115	.4458	.5144	.3086
4	.6173	.3601	.6516	.4458	.4801	.5144	
5	.7202	.4801	.7202	.5487	.6344	.6687	
6	.8916	.6859	.8059	.9259	.8916	.8573	
7	.9602	.9602	.9945	.9774	.9774	.9774	
8	.7373	.8745	.8573	.9088	.7888	.9602	
9	.7888		.8916	.9088	.823	.7716	
10							.4458
11							.5144
12							.6859
13							.7716
14							.703
15							.6516
16	.2229	.2915	.2743	.2743	2.1948	.2058	.7202
17	.3086	.3429	1.0631	.3258	2.2805	.3086	.8402
18	.3429	.4115	.4115	.4115	.2743	.3601	.2572
19	.5144	.6001	.4801	.4801	.5658	.5144	.4115
20	.6516	.6173	.6859		.6516	.703	.4801
21	.5316	.5487	.5487	.5487	.5144	.5487	.6173
22	.4801	.463	.4458	.4458	.4801	.4801	.5144
23		.3944	.4115	.3601	.4458	.4115	.3944
24	.4458	.4458	.4458	.4115	.4115	.5144	.3429
Max	.9602	.9602	1.0631	.9774	2.2805	.9774	.8402
Min	.2229	.2915	.2743	.2743	.2743	.2058	.2572
Avg	.5729	.5165	.6249	.5416	.7640	.5725	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758] BU 4758

Substation No/ Name :- 194008 / YENEGUR

Feeder No / Name : 203 / 11KV TUGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2401	.2743	.3429	.2401	.2401	.8573
2	.2401		.2743	.3429	.2401	.2401	.9431
3	.3772	.3086	.3086	.3772	.2572	.2572	.9431
4			.3429				1.0288
5			.3772				.9907
6							1.2193
7							1.6804
8							1.5242
9							1.7528
10	1.1317	1.046	1.3717	1.3375	1.2689	1.0059	
11	1.3717	1.4746	1.7833	1.5432	1.749	1.2193	
12	1.6461	1.1831	1.6461	1.6004	1.7147	1.5432	
13	1.7661	1.4918	.823		1.8176	1.0288	
14	1.6975	1.5775	1.5947	1.6004	1.4746	1.0059	
15	1.6632	1.5432		1.5546	1.5089	1.2346	
16	1.6632	1.5261	1.2689	1.6004	1.7147	1.3717	.2229
17	1.6118	1.6118	1.2689	1.6004	1.6118	1.4937	.2915
18	.2058	.2401	.2572	.2572	.2572	.2058	.3258
19	.2572	.3601	.3258	.3258	.3772	.2401	.3601
20	.2743	.4115	.4115		.3429	.3772	.4458
21	.3772	.3944	.4115	.3429	.3086	.3429	.4287
22	.3772	.3944	.3772	.3086	.2915	.3086	.4115
23		.3772	.3772	.2743	.2743	.2743	.3944
24	.2743	.2401		.3601		.2572	.7888
Max	1.7661	1.6118	1.7833	1.6004	1.8176	1.5432	1.7528
Min	.2058	.2401	.2572	.2572	.2401	.2058	.2229
Avg	.8926	.8483	.7497	.8606	.9088	.7026	.8116

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758] BU 4758

Substation No/ Name :- 194008 / YENEGUR

Feeder No / Name : 204 / 11KV YENEGUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	1.0288	1.1831	1.0974	1.0802	1.1317	.7888
2	1.2003		1.3032	1.0974	.9602	1.0974	.7888
3	1.2346	1.0288	1.3717	1.0974	.9602	1.0364	.7888
4	1.5089	1.0631	1.6804	1.166	.9755	1.0974	
5	1.5432	1.166	1.7833	1.4403	1.0669	1.3717	
6	1.5947	1.6804	1.9547	1.8519	1.6766	1.5242	
7	2.0233	1.9547	2.1948	2.0233	1.89	1.6004	
8	1.6632		2.0062	1.989	1.829	1.4632	
9	1.8347		1.8861	1.9204	2.1262	1.4632	
10							1.3717
11							1.7071
12							1.8442
13							1.5604
14							1.6118
15							1.7147
16	.7202	.8745	.6859	.823	.7545	.6859	1.6461
17	.7202	.8745	.8916	.823	.7545	.6859	1.6118
18	.7545	.9431	.8916	.9602	.823	.823	.6687
19	1.0288	1.0802	1.0974	1.0974	1.1145	.4115	.9088
20	1.2689	1.2346	1.3032		1.3717	1.3032	1.166
21	1.166	1.2174	1.166	1.2346	1.166	1.2346	1.1831
22	1.0288	1.0117	1.0288	1.0288	1.0288	1.0974	1.0288
23	.9602	.9088	.9602	.9602	.8916	.8916	.8745
24	1.0288	1.0288	1.1831	1.0288	1.0974	1.0288	.823
Max	2.0233	1.9547	2.1948	2.0233	2.1262	1.6004	1.8442
Min	.7202	.8745	.6859	.823	.7545	.4115	.6687
Avg	1.2451	1.1397	1.3651	1.2729	1.1982	1.1082	1.2271

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758]

BU 4758

Substation No/ Name :- 194008 / YENEGUR

Feeder No / Name : 205 / 11 KV Nalwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601	.4115	.3601	.3601	.3086	.3086	1.6766
2	.3601		.3772	.3601	.2915	.3086	1.6766
3	.4458	.4458	.3944	.3772	.3086	.3429	1.7071
4			.4115				1.6118
5			.4458				1.7528
6							1.9509
7							2.1186
8							1.829
9							1.7985
10	2.1262		1.869	2.0062	2.0233	1.7071	
11	2.1948	1.8176	2.2977	2.2119	2.2977	2.4006	
12	2.1948	1.9204	2.2634	2.1338	2.3834	1.9814	
13	2.1776	2.0405	2.0576	2.0881	2.0233	1.9662	
14	2.1091	2.2119	2.1091	1.9204	2.0919	1.8595	
15	2.1262	2.2805		1.9204	2.1605	1.6309	
16	2.3663	2.3663	2.1948	1.9204	2.1948	1.8747	.2401
17	2.3148	2.2291	2.4006	1.9814		2.1338	.2915
18	.2743	.3944		.3086		.3086	
19	.4801	.4973	.463	.4801	.4287	.4458	.4458
20	.6516	.5658	.6173		.6001	.583	.5487
21	.5316	.5487	.463	.5144	.5487	.5144	.5144
22		.4287	.4115	.3601	.4458	.3772	.4287
23		.4115	.3772	.3944	.3944	.3772	.3772
24	.3772		.3772	.3601	.3429	.3429	1.5851
Max	2.3663	2.3663	2.4006	2.2119	2.3834	2.4006	2.1186
Min	.2743	.3944	.3601	.3086	.2915	.3086	.2401
Avg	1.3182	1.238	1.1050	1.1587	1.1778	1.0813	1.2090

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758]

BU 4758

Substation No/ Name :- 194008 / YENEGUR

Feeder No / Name : 206 / 11 KV Dalimb Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.4115	.3944	.3772	.3944	.3601	.3429
2	.3601		.3772	.3772	.3944	.3601	.3429
3	.3429	.4115	.3772	.3772	.4115	.3772	.4115
4	.3772	.4115	.3944	.4115	.4458	.4458	.5487
5	.4458	.4801	.4458	.4801	.5487	.4973	.5658
6	.6173		.6173	.6516	.6516	.6173	.6516
9	.5316		.5658	.6516	.6173	.5487	.6173
10	.5316	.6516	.5487	.5144	.583	.5487	.5487
11	.4458	.5144	.5144	.5144	.4801	.4801	.4801
12	.3429	.3944	.4115	.4115	.4801	.3429	.4115
13	.3429	.4287	.4115	.4115	.3772	.3086	.3258
14	.3086	.3601	.3772	.3429	.3429	.2915	.3086
18	.4115	.5487		.3772		.4801	.5144
19	.583	.6001	.6173	.583	.6516		.5144
20	.6859	.583	.6173		.6859	.583	.6173
21	.583	.5658	.5144	.6173	.5487	.6173	.583
22	.4801	.5144	.4801	.5144	.5487	.4801	.4973
23		.463	.4458	.4458	.4458	.4458	.4458
24	.4287	.4115	.4287	.4115	.4115	.4115	.4115
Max	.6859	.6516	.6173	.6516	.6859	.6173	.6516
Min	.3086	.3601	.3772	.3429	.3429	.2915	.3086
Avg	.4553	.4844	.4744	.4706	.5011	.4553	.4810

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758]

BU 4758

Substation No/ Name :- 194008 / YENEGUR

Feeder No / Name : 207 / 11KV ASHTA (KASAR)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3086	.3258	.3086	.3086	.2915	.3944
2	.3429		.3429	.3086	.3086	.2915	.3944
3	.4458	.3601	.4115	.3429	.3086	.2915	.3944
4			.4458				.4115
5			.4973				.4458
6							.6859
7							.9259
8							.9602
9							.6859
10	.6516	.7888	.703	.6344	.5487	.6173	
11	.7888	.9088	.8916	.6859	.7888	.8573	
12	.7716	.7373	.823	.6859	.8402	.9602	
13	.7716	.8745	.5487	1.5699	.8402	.9259	
14	.7716	.8573	.6516	.7716	.7888	.8573	
15	.7202	.8573		.6401	.823	.6859	
16	.7716	.9602		.7545	.8573	.9259	.3258
17	.6516	.8916		.823	.7888	.8916	.3772
18	.2915	.3429	.3429		.2743	.2743	.3772
19	.463	.4287	.4115	.4115	.4287	.4458	.463
20	.5487	.4973	.5144		.5487	.4801	.4801
21	.4801	.4801	.4115	.4115	.4801	.4801	.463
22	.4115	.4287	.3772	.4115	.4458	.4115	.3944
23		.3601	.3429	.3772	.3429	.4801	.3601
24	.3772	.3086	.3429	.3086	.3429	.3086	.3772
Max	.7888	.9602	.8916	1.5699	.8573	.9602	.9602
Min	.2915	.3086	.3258	.3086	.2743	.2743	.3258
Avg	.5648	.6112	.4932	.5904	.5592	.5820	.4954

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758] BU 4758

Substation No/ Name :- 194016 / LOHARA

Feeder No / Name : 201 / 11 KV LOHARA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.5639	.4725	.4725	.6001	.4572	.4572
2	.583	.5944	.4572	.4572	.583	.4877	.4268
3	.5487	.6097	.4877	.4877	.5487	.503	.4572
4	.583	.6097	.5335	.5182	.6001	.5182	.4877
5	.6344	.6249	.6097	.5792	.6173	.5335	.5792
6	.6859	.6401	.6401	.6706	.6173	.5487	.6401
7	.6859	.6097	.6249	.6401	.6859	.5639	.5792
8	.6859	.5639	.5487	.5335	.6173	.5335	.503
9	.6516	.4725	.4572	.503	.6173	.4725	.4268
10	1.1145	.6859	.9145	1.0288	1.0288		.3963
11	.8535	.945	.9145	1.0631	.9145	.7926	.9755
12	.9145		.9145	1.0631	.9907	.8383	.945
13	.9145		.8688	1.0631	.9907	.9145	.9145
14	.9755	.9145	.8383	1.0802	.9907	.8383	.884
15	.8535	.884	.7926	1.0288	.8535	.7926	.8535
16	.945	.8383	.8535	1.0288	.7926	.823	.9145
17	.9907	.8078	.884	1.0631	.8383	.9602	.945
18	.4268	.4572	.442	.4287	.4572	.4115	.1829
19	.5487	.503	.5487	.823	.5639	.503	.5792
20	.6706	.5487	.6859	.823	.7316	.5792	.7316
21	.6097	.5792	.7011	.8059	.6706	.6706	.6706
22	.5792	.5792	.6097	.6859	.6097	.6097	.6097
23	.5487	.5487	.5639	.6173	.5487	.5487	.5335
24	.6173	.5335	.4877	.5335	.6173	.503	.503
Max	1.1145	.945	.9145	1.0802	1.0288	.9602	.9755
Min	.4268	.4572	.442	.4287	.4572	.4115	.1829
Avg	.7176	.6415	.6605	.7499	.7119	.6262	.6332

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758] BU 4758

Substation No/ Name :- 194016 / LOHARA

Feeder No / Name : 202 / 11 KV Mogha SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0576	2.0576	2.1948	2.0576	2.4006	2.2634	1.9052
2	2.2291	2.4863	2.3624	2.4691	2.5892	2.4691	2.0271
3	2.4863	2.8464	2.5149	2.6578	2.8292	2.7092	2.1948
4	2.7435	3.2236	2.6216	2.8292	2.9492	2.8978	2.2862
5	2.9492	3.3608	2.713	2.9492	3.1722	3.0178	2.8654
6	3.2236	3.4294	2.8197	3.0864	3.3608	3.2922	3.0483
7	3.1722	2.8654	2.7435	2.0576		3.4294	3.1398
8	3.1893	3.1207	2.8197	3.2236		3.2236	2.9721
9	2.915	2.7435	2.8959	3.0864		2.8807	2.8349
10	.4973	.3353	.4801	.3772		.3201	.061
11	.2743	.2439	.3429			.2743	
12	.2439		.2058	.3429		.2591	.4115
13	.2058		.2058	.3258	2.572	.2439	.3429
14	.2058	.2286	.2058	.3258	.2743	.2439	.2401
15	.2058	.2286	.2743	.1029	.2743	.2439	.2058
16	.2058	.2743	.3086	.1029	.2743	.2743	.2401
17	.2058	.3048	.3429	.1029	.3429	.3048	.2743
18	.4115	.4877	.4115	.4973	.4115	.3658	.4115
19	.6859	.5335	.6516	.7545	.6173	.4115	.6173
20	.823	.6097	.7545	.7888	.7545	.4572	.6706
21	.7202	.4877	.6859	.7716	.6173	.5182	.6859
22	.6173	.4268	.583	.583	.5144	.4572	.6173
23	.4115	.3658	.4115	.4458	.4115	.381	.4115
24	1.7147	1.9204	1.829	1.9204	2.0576	2.0576	1.7375
Max	3.2236	3.4294	2.8959	3.2236	3.3608	3.4294	3.1398
Min	.2058	.2286	.2058	.1029	.2743	.2439	.061
Avg	1.3498	1.4809	1.3074	1.3852	1.4680	1.3748	1.3131

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758] BU 4758

Substation No/ Name :- 194016 / LOHARA

Feeder No / Name : 203 / 11 KV Hiperga SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0152	.0305	.0152	.0171	.0152	.0152
2	.0171	.0152	.0305	.0152	.0171	.0152	.0152
3	.0171	.0305	.0305	.0152	.0171	.0152	.0152
4	.0171	.0305	.0457	.0305	.0171	.0152	.0152
5	.0171	.061	.061	.0305	.0343	.0152	.0305
6	.0343	.061	.061	.0457	.0514	.0305	.0305
7	.0514	.061	.061	.061	.0686	.061	.0457
8	.0514	.0305	.0457	.061	.0686	.0305	.0457
9	.0514	.0305	.0457	.0305	.0686	.0305	.0457
10	.12	.0457	.0914	.12	.1372	.1219	.0305
11	.061	.061	.0914	.12	.0914	.0914	.061
12	.061		.0914	.12	.0914	.0762	.061
13	.061		.1067	.12	.1029	.061	.061
14	.0914	.0914	.1219	.12	.0914	.061	.061
15	.0914	.0457	.061	.1029	.0914	.061	.061
16	.0914	.0457	.0762	.12	.0914	.0914	.061
17	.0914	.1067	.0914	.12	.0914	.1067	.061
18	.0914	.1219	.0914	.1029	.0914	.1067	.1219
19	.1067	.1524	.1067	.1543	.0914	.1372	.1219
20	.1219	.1524	.1219	.1543	.1219	.1524	.1219
21	.1219	.1372	.1067	.1543	.1219	.1524	.1067
22	.1067	.1219	.0914	.1372	.1219	.1219	.0914
23	.0914	.1219	.0914	.1029	.1219	.1067	.0914
24	.0171	.0152	.0305	.0152	.0171	.0152	.0152
Max	.1219	.1524	.1219	.1543	.1372	.1524	.1219
Min	.0171	.0152	.0305	.0152	.0171	.0152	.0152
Avg	.0667	.0707	.0743	.0862	.0765	.0705	.0578

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758] BU 4758

Substation No/ Name :- 194048 / JEWALI

Feeder No / Name : 201 / 11 KV Jewali

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3114	.2768		.251	.2768	.278	
2	.2595	.2768	.2601	.2457	.2768	.2439	.3003
3	.2595	.2768	.2951	.2902	.2768	.2743	.2942
10	.5006	.6387		.6776	.6732	.5487	.618
11	.692		.7981	.6904			.8803
12	.8285	.6316	.7981	.7077	.7981	.9743	.8976
13	.8458			.8659	.9432		.8612
14	.8113		.7171	.8113	.8525	.7922	.8285
15	.794	.8825		.8659	.7981		.794
16	.8631	.956	.7618	.8976	.7897	.8457	.8631
17	.8285		.834	.8803	.8706		.9989
18	.1903	.2181		.1384		.2206	.2076
19	.3114				.278		.2595
20	.381	.3753	.3446	.3979	.2358	.3861	
21	.3633		.3128	.346	.2439		
22	.346	.2942	.3475	.3114	.3158	.3309	.2768
23	.3107		.2865	.2768	.2804		.2422
24	.2595	.2768	.2627	.278	.2768	.2433	.3042
Max	.8631	.956	.834	.8976	.9432	.9743	.9989
Min	.1903	.2181	.2601	.1384	.2358	.2206	.2076
Avg	.5087	.4640	.5015	.5254	.5117	.4671	.5751

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758] BU 4758

Substation No/ Name :- 194048 / JEWALI

Feeder No / Name : 202 / 11 KV Hipparga (syd) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2076	.8631		.8688	.2941	.7468	
2	.2076	.8631	1.1283	.9976	.2941	.9259	
3	.2076	.8659		1.0425	.2941	.9945	1.5046
4	.2076	.8631		1.2163	.2941	1.1145	
5	.2422	1.0357	1.6358	1.5793	.2941	1.2346	1.6032
6	.3114	1.2917		1.6505	.346	1.2193	
7	.8976	1.6534	1.1248	1.6644	.4156	1.6289	1.8017
8	1.1712	1.6498		.5258		1.6461	
9	1.3118	1.6498	1.5091	1.6845	1.3748	1.7412	1.7228
10	1.2083						
11	1.2373				1.1608		
16	.173	.1818	.2172	.2249	.1451	.1437	.2249
17	.2076		.2715	.2417	.1991		.2422
18	.2422	.3374				.1875	
19	.346		.4031	.4152	.399		.3114
20	.4833	.5201	.4865	.519	.5804	.6393	
21	.4488		.4518	.4844	.5908		
22	.3797	.4472	.4344	.4152	.556	.5567	.4152
23	.3114		.3823	.3114	.3628		.346
24	.2076	.762	.5533	.8162	.2941	.6097	.7438
Max	1.3118	1.6534	1.6358	1.6845	1.3748	1.7412	1.8017
Min	.173	.1818	.2172	.2249	.1451	.1437	.2249
Avg	.5005	.9274	.7165	.8622	.4644	.9563	.8916

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758]

BU 4758

Substation No/ Name :- 194048 / JEWALI

Feeder No / Name : 203 / 11 KV Rudrawadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4661	.4661		.6711	.4671	.4801	.6735
2	.4661	.4661	.7802	.653	.4671	.3429	
3	.4661	.4671	.8624	.695	.4671	.3814	.6936
10	.7768	.794		.7124	.6904	.6516	.7263
11	.8956		.8785	.7447			.8631
12	.8631	.8457	.834	.7768	.7618	.8797	.8458
13	.8113			.8631	.8887		.7422
14	.7768		.7799	.8285	.8343	.765	.6041
15	.7422	.8724		.8285	.8162		.725
16	.6927	.8878	.7124	.8458	.8343	.8361	.7274
17	.6055		.7819	.8458	.8706		.7768
18		.5573		.5536		.5987	.4833
19	.7785			.71	.7618		.6559
20	.9839	.959		.9817	.9955	.9784	
21	.8976			.8631	.8688		
22	.7768	.8448		.692	.5639	.8624	.6387
23	.6559		.695	.4844	.4877		.4671
24	.4671	.4661	.7706	.6813	.4671	.543	.6749
Max	.9839	.959	.8785	.9817	.9955	.9784	.8631
Min	.4661	.4661	.695	.4844	.4671	.3429	.4671
Avg	.7131	.6933	.7883	.7462	.7027	.6654	.6865

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758]

BU 4758

Substation No/ Name :- 194079 / 33/11 KV KANEGAON

Feeder No / Name : 201 / 11 KV BHATANGALI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2858	.2858	.2477	.2477	.2858	.2477
2	.2667	.2858	.2858	.2477	.2477	.2858	.2477
3	.3048	.2858	.2858	.2477	.2477	.2858	.2477
4	.3429	.2858	.381	.2477	.2858	.2858	.2667
5	.381	.3048	.381	.2667	.3048	.381	.2667
6	.4001	.3048	.381	.2858	.362	.381	.2858
7		.2667	.3239	.3048	.2858	.2858	.2667
8		.2286	.2286	.2667	.2096	.2858	.2096
9	.2286	.2096	.1905	.2096		.2858	.1715
10	.6097	.7621	.9145	.945	.9145	.9145	.7621
11	.9145	1.1431	1.1736	1.1431	1.0669	1.1279	1.0669
12	1.0212	1.2193	1.2498	1.1736	.9145	1.2041	1.2346
13	1.0669	1.2193	1.3413	1.0974	1.0669	1.0059	1.2651
14	.945	1.2193	1.387	1.0212	.9907	1.0517	1.2651
15	1.0669	1.0669	1.2346	1.2193	1.0669	1.0212	1.2498
16	1.2498	1.2955	1.3717	1.2193	1.0669	1.1584	1.2955
17	1.3108	1.2955	1.3565	1.2803	1.0669	1.1431	1.3108
18	.1334	.1905	.1905	.1524	.1905	.1715	.1334
19	.2858	.2858	.2477	.2477	.2858	.2286	.2667
20	.381	.381	.362	.362	.381	.381	.3429
21	.3429	.381	.362	.381	.381	.381	.3048
22	.3239	.2858	.3239	.3429	.381	.3048	.3048
23	.3048	.2858	.3239	.3048	.2858	.2667	.2858
24	.2667	.2858	.2858	.2667	.2477	.2858	.2477
Max	1.3108	1.2955	1.387	1.2803	1.0669	1.2041	1.3108
Min	.1334	.1905	.1905	.1524	.1905	.1715	.1334
Avg	.5643	.5739	.6195	.5617	.5434	.5587	.5644

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758]

BU 4758

Substation No/ Name :- 194079 / 33/11 KV KANEGAON

Feeder No / Name : 202 / 11 KV NAGUR FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5394	1.5242	1.829	1.6766	1.0974	1.5242	1.448
2	1.6004	1.5242	1.829	1.7528	1.0974	1.5242	1.4937
3	2.0957	2.0957	1.829	1.829	1.1431	1.5242	1.5242
4	2.2862	1.7528	1.829	1.9052	1.2193	1.5242	1.829
5	1.9814	1.9814	1.829	2.0576	1.448	1.6766	1.9814
6	2.1033	2.1338	2.4387	2.21	1.6004	1.829	2.4234
7	2.2253	2.2558	2.2862	2.0576	1.9357	2.2862	2.4844
8	2.1491	2.2862	2.2862	2.2253	.3963	2.2862	2.3624
9	2.0424	2.1338	2.2862	2.2558	1.7985	1.829	2.1491
10	.2858	.2858	.3239	.2858	.381		.2858
11	.2477	.2858	.2667	.1715	.381	3.3341	.2667
12	.2858	.2858	.2667	.1524	.381	.2667	.2667
13	.2667	.2858	.3048	.1524	.2858	.2667	.3048
14	.2858	.2858	.2858	.1715	.2858	.2858	.3048
15	.2858	.2858	.3048		.2858	.3048	.3048
16	.3048	.2858	.2858	.362	.2858	.2858	.2858
17	.2096	.2858	.3429	.362	.2858	.2858	.3239
18	.2477	.381	.3239	.4001	.2858	.3048	.3239
19	.4001	.4763	.4763	.4572	.5716	.4954	.4763
20	.6097	.5716	.6478	.6287	.6668	.6097	.6287
21	.5716	.5716	.5716	.6287	.5716	.5525	.5716
22	.5144	.4763	.5335		.4763	.4763	.4763
23	.4763	.381	.4382	.4763	.4763	.4001	.362
24	1.5394	1.4784	1.5242	1.5242	.945	1.3717	1.448
Max	2.2862	2.2862	2.4387	2.2558	1.9357	3.3341	2.4844
Min	.2096	.2858	.2667	.1524	.2858	.2667	.2667
Avg	1.0231	1.0129	1.0558	1.0792	.7626	1.0976	1.0136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758]

BU 4758

Substation No/ Name :- 194079 / 33/11 KV KANEGAON

Feeder No / Name : 203 / 11 KV KANEGAON FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.4382	.4763	.381	.381	.4191	.381
2	.381	.4382	.4763	.381	.381	.4191	.381
3	.4191	.4763	.4763	.381	.381	.4191	.381
4	.4954	.4763	.4763	.381	.4191	.4763	.4191
5	.5335	.5144	.5716	.4191	.4763	.5716	.4763
6	.5525	.5335	.5716	.5335	.5144	.5716	.5335
7	.4954	.5335	.5716	.5335	.5716	.4763	.5716
8	.4191	.4572	.4763	.4572	.4763	.381	.4763
9	.4191	.4001	.381	.4382	.4572	.4763	.4382
10	1.2193	1.0669	1.4022	1.0822	1.5242	1.3565	1.3565
11	1.4937	1.5242	1.6766	1.3717	1.829	1.448	1.4784
12	1.5089	1.5242	1.6309	1.4937	1.6766	1.5089	1.6004
13	1.4632	1.829	1.6613	1.4632	1.6766	1.4632	1.3413
14	1.4022	1.5242	1.6156	1.2955	1.829	1.4175	1.3565
15	1.4784	1.5242	1.5242	1.2346	1.6766	1.3565	1.387
16	1.4632	1.6766	1.6766	1.6004	1.5242	1.4175	1.5242
17	1.6766	1.829	1.7528	1.6766	1.829	1.3413	1.6156
18	.3239	.381	.3239	.2858	.381	.362	.2667
19	.5525	.4763	.5525	.5144	.5716	.4954	.4763
20	.6287	.5716	.7049	.6478	.6668	.7049	.5906
21	.6478	.6668	.6668	.6859	.6668	.6668	.5906
22	.6478	.5716	.5525	.5525	.5716	.4763	.4763
23	.5716	.4763	.4763	.4954	.4763	.4382	.362
24	.381	.4382	.4382	.4001	.4191	.4191	.381
Max	1.6766	1.829	1.7528	1.6766	1.829	1.5089	1.6156
Min	.3239	.381	.3239	.2858	.381	.362	.2667
Avg	.8148	.8478	.8805	.7794	.8907	.7951	.7859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758]

BU 4758

Substation No/ Name :- 195000 / Tawshigad

Feeder No / Name : 201 / 11kv tawshigad

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1905	.1905	.1905		.1905
2	.1905	.1905	.1905	.2858	.1905		.1905
3	.1905	.1905	.1905	.1905	.1905		.1905
5		.1905					
10	.6097	.8383	.9145	.7621			.9431
11	1.3717	.8383	1.0669	.9907			1.4575
12	1.3717	.9145	1.3717	1.0669		1.1431	1.4575
13	1.2193	1.2193	1.2955	1.2955		1.0669	1.4575
14	1.2193	1.2193	1.2193	1.2955		.9145	1.2003
15	1.2955	1.2955	1.2955	1.2955		.9145	1.1145
16	1.2193	1.2955	1.2955	1.3717		.9907	1.1145
17	1.2955	1.3717	1.3717	1.448		1.2193	1.1145
18	.1905	.1905	.1905	.1905		.1905	.1905
19	.381	.2858	.2858	.2858		.2858	
20		.381	.381	.381		.381	
21	.2858	.2858	.381	.2858		.381	
22	.1905	.2858	.2858	.1905		.2858	
23	.1905	.1905	.1905	.1905		.1905	
24	.1905	.1905	.1905	.1905	.1905		.1905
Max	1.3717	1.3717	1.3717	1.448	.1905	1.2193	1.4575
Min	.1905	.1905	.1905	.1905	.1905	.1905	.1905
Avg	.6825	.6086	.6837	.6615	.1905	.6636	.8317

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758] BU 4758

Substation No/ Name :- 195000 / Tawshigad

Feeder No / Name : 202 / 11kv dhanuri SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6766	1.448	1.448	1.3717	1.448		1.448
2	1.6766	1.6766	1.5242	1.5242	1.5242		1.5242
3	1.829	1.829	1.6766	1.6766	1.6766		1.6766
4	1.9814	2.0576	1.9052	1.829	1.9814		1.9052
5	2.0576	2.21	1.9814	2.0576	2.0576		1.9814
6	2.1338	2.2862	2.0576	2.2862	2.21		2.0576
7	2.3624	2.21		2.21	2.3624		2.0576
8	2.21	2.2862		2.0576	2.21	2.1338	2.1338
9	2.0576	2.3624	2.2862	1.9814			2.1338
16	.381	.381	.2858	.2858		.2858	
17	.381	.4763	.381	.381		.381	.2858
18	.4763	.4763	.5716	.381		.381	.381
19	.6668	.5716	.5716	.4763		.4763	
20	.7621	.6668	.6668	.6668		.6668	
21	.7621	.6668	.6668	.6668		.6668	
22	.6668	.5716	.5716	.5716		.5716	
23	.6668	.5716	.5716	.5716		.5716	
24	1.3717	1.2955	1.2955	1.2193	1.2955		1.2955
Max	2.3624	2.3624	2.2862	2.2862	2.3624	2.1338	2.1338
Min	.381	.381	.2858	.2858	1.2955	.2858	.2858
Avg	1.3400	1.3358	1.1538	1.2341	1.8629	.6816	1.5734

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758]

BU 4758

Substation No/ Name :- 195000 / Tawshigad

Feeder No / Name : 203 / 11kv harali

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381	.381	.381	.381		.381
2	.381	.381		.381	.381		.381
3	.4763	.381	.381	.4763	.4763		.4763
10	.6097		.6097	.6097		.7621	.6859
11	.9145	.6859	.7621	.6859		.8383	.9431
12	.9145	.6097	.8383	.6859		.9145	1.0288
13	.9145	.6859	.8383	.8383		.8383	1.0288
14	.8383	.8383	.7621	.8383		.7621	1.0288
15	.8383	.8383	.7621	.8383		.7621	1.0288
16	.7621	.9145	.7621	.9145		.7621	1.0288
17	.7621	.8383	.8383	.9907		.9145	.9431
18	.3048		.2858			.2858	.2858
19	.4763	.5716	.381			.381	
20	.5716	.7621	.5716	.7621		.5716	
21	.5716	.6668	.5716	.6668		.6668	
22	.4763	.5716	.4763	.5716		.4763	
23	.381	.4763	.4763	.4763		.381	
24	.381	.381	.381	.381	.381		.381
Max	.9145	.9145	.8383	.9907	.4763	.9145	1.0288
Min	.3048	.381	.2858	.381	.381	.2858	.2858
Avg	.6086	.6240	.5929	.6561	.4048	.6655	.7401

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194012 / 33/11KV MURUM S/S

Feeder No / Name : 201 / 11KV MURUM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	.9526	1.0479	1.0479		.9526	
2	1.0479	.9526	1.0479	1.0479		.9526	1.1431
3	1.0479	.9526	1.0479	1.0479		.9526	1.0479
4	1.1431	.9526	1.1431	1.0479		.9526	1.0479
5	1.1431	1.1431	1.1431	1.2384		1.2384	1.2384
6	1.2384	1.2384	1.0479	1.2384		1.2384	1.2384
7	1.2384	1.1431		1.2384		1.1431	1.2384
8	1.0479	1.1431	.9526	1.1431		1.1431	1.1431
9	1.0479	1.0479	.9526	1.0479		.9526	1.0479
10			.9526	1.0479		.9526	.9526
11	1.0479		.9526	1.0479		.9526	
12	1.0479		.9526	1.0479		.9526	
13	1.0479		.9526	1.0479		.9526	
14			.9526	1.0479		.9526	
15	1.0479		.9526	1.1431	1.0479	.9526	
16	1.0479		.9526	1.1431	1.0479	.9526	
17			.9526			.9526	
18	1.1431		1.0479		1.0479	1.0479	
19	1.2384		1.2384	1.2384	1.2384	1.2384	
20	1.2384		1.2384	1.3336	1.1431	1.2384	
21	1.1431		1.2384	1.3336	1.1431	1.2384	
22	1.0479		1.1431	1.2384	1.1431	1.2384	
23	1.0479		1.0479	1.1431	1.0479	1.1431	
24	.9526	.9526	1.0479	1.0479		1.0479	1.1431
Max	1.2384	1.2384	1.2384	1.3336	1.2384	1.2384	1.2384
Min	.9526	.9526	.9526	1.0479	1.0479	.9526	.9526
Avg	1.0932	1.0479	1.0437	1.1345	1.1074	1.0558	1.1241

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194012 / 33/11KV MURUM S/S

Feeder No / Name : 202 / 11KV KOTHSALI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.4763	.2858	.5716		.8573	1.0479
2	.2858	.4763	.2858	.381		.8573	1.0479
3	.2858	.4763	.381	.381		.8573	1.0479
4	.2858	.4763	.4763	.381		.9526	1.1431
5	.2858	.5716	.4763	.6668		1.1431	1.5242
6	.1905	.6668	.4763	.6668		1.8099	1.9052
7	.1905	.5716		.5716		2.0005	
8	.1905		.381	.4763		1.9052	1.8099
9	.1905		.2858	.381		1.9052	1.7147
10				.9526		.2858	.2858
11	1.6194		1.8099	1.5242			
12	1.7147		.6668	1.7147		.2858	
13	1.6194		1.9052	1.8099		.2858	
14			1.8099	1.7147		.2858	
15	1.3336			1.7147	.1905	.2858	
16	1.6194		1.9052	1.8099	.1905	.2858	
17	1.6194		1.7147	1.7147		.2858	
18	1.2384		.4763	.2858	.2858	.381	
19	.5716		.5716	.381	.5716	.6668	
20	.6668		.6668	.5716	.6668	.6668	
21	.5716		.6668	.5716	.6668	.6668	
22	.5716		.6668	.4763	.5716	.6668	
23	.5716		.5716	.381	.5716	.6668	
24	.2858	.4763	.381	.5716		.8573	.8573
Max	1.7147	.6668	1.9052	1.8099	.6668	2.0005	1.9052
Min	.1905	.4763	.2858	.2858	.1905	.2858	.2858
Avg	.7361	.5239	.8029	.8613	.4644	.8201	1.2384

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194012 / 33/11KV MURUM S/S

Feeder No / Name : 203 / 11KV BELUMB (ACHALER) SINGLE PHASING

FEEDER Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	.8573	.9526	1.0479		.381	.381
2	.9526	.8573	.9526	.9526		.381	.381
3	1.0479	.8573	.9526	.9526		.381	.381
4	1.0479	.8573	1.0479	.9526		.381	.4763
5	1.0479	.9526	1.2384	.9526		.6668	.6668
6	1.0479	1.0479	1.2384	1.5242		.7621	.6668
7	1.0479	1.3336		1.5242		.6668	.6668
8		1.2384	1.6194	1.7147		.4763	.4763
9	.9526	1.2384	1.7147	1.4289		.381	.381
10			.2858	.1905		.9526	.9526
11	.2858		.2858	.1905		1.2384	
12	.2858			.1905		1.5242	
13	.2858		.2858	.1905		1.5242	
14			.2858	.1905		1.6194	
15	.2858		.2858	.1905	1.5242	1.5242	
16	.2858		.2858	.1905	1.4289	1.5242	
17	.2858		.2858	.2858		1.4289	
18	.381		.381		.381	.381	
19	.6668		.5716	.381	.5716	.6668	
20	.6668		.6668	.7621	.6668	.6668	
21	.6668		.6668	.7621	.6668	.6668	
22	.5716		.6668	.5716	.5716	.6668	
23	.5716		.5716	.381	.4763	.5716	
24	.5716	.7621	.7621	.8573		.381	.381
Max	1.0479	1.3336	1.7147	1.7147	1.5242	1.6194	.9526
Min	.2858	.7621	.2858	.1905	.381	.381	.381
Avg	.6623	1.0002	.7275	.7124	.7859	.8256	.5282

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194012 / 33/11KV MURUM S/S

Feeder No / Name : 204 / 11KV ALOOR FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	1.0669	1.4575	1.5242		.381	.381
2	.9526	1.0669	1.4575	1.2193		.381	.381
3	1.3336	1.1431	1.6766			.381	.381
4	1.5242	1.2193	1.6766	1.2193		.381	.381
5	1.7147	1.3717	1.829	1.3717		.381	.4572
6	1.7147	1.5242	1.829	1.6766		.4572	.4572
7	1.7147	1.829		1.9814		.4572	.4572
8	2.0957	2.0576	2.1338	2.0576		.4572	.4572
9	2.6673	2.1338	1.829	2.1338		.4572	.4572
10				.3048			.9145
11	.4572		.4572	.381		2.0576	
12	.4572			.381		2.0576	
13	.4572		.5335	.381		2.0576	
14			.5335	.381		1.9814	
15	.4572		.5335	.381	2.2862	1.9814	
16	.4572		.5335	.381	2.1338	1.9052	
17	.4572		.5335	.381		1.9814	
18	.4572						
23	.9145						
24	.9526	1.0669	1.1336	1.2193		.381	.381
Max	2.6673	2.1338	2.1338	2.1338	2.2862	2.0576	.9145
Min	.4572	1.0669	.4572	.3048	2.1338	.381	.381
Avg	1.0965	1.4479	1.2098	1.0221	2.21	1.0669	.4641

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194028 / 33KV S/S NARANGWADI S/S

Feeder No / Name : 201 / 11KV MADAJ FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	23-MAY-17	24-MAY-17	25-MAY-17	27-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.483	.6035	
2		.5635	.6783	
3		.644	.663	
4		.7898	.7773	
5		.8543	.9602	
6		1.0142	1.2186	
7			1.3889	
8			1.2793	
9			1.2346	
16		.0594		
17		.1204		
18		.1235		
19		.2401		
20		.2753		
21		.2458		
22		.2321		
24	.6035	.1932	.5375	.5862
Max	.6035	1.0142	1.3889	.5862
Min	.6035	.0594	.5375	.5862
Avg	.6035	.4170	.9341	.5862

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194028 / 33KV S/S NARANGWADI S/S

Feeder No / Name : 202 / 11KV MATOLA (BORI) FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	23-MAY-17	24-MAY-17	25-MAY-17	27-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2898	.3448	
2		.322	.39	
3		.4025	.4191	
10			1.406	
11		1.6432		
12		1.579		
13		1.7309		
14		1.5804		
15		1.4861		
16		1.5604		
17		1.5954		
18		.2932		
19		.5601		
20		.6478		
21		.5668		
22		.4915		
23		.3391		
24	.2747	.2415	.2601	.2578
Max	.2747	1.7309	1.406	.2578
Min	.2747	.2415	.2601	.2578
Avg	.2747	.9017	.564	.2578

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194028 / 33KV S/S NARANGWADI S/S

Feeder No / Name : 203 / 11 kv naichakur feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	23-MAY-17	24-MAY-17	25-MAY-17	27-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2894	2.2415	
2		1.4489	2.3739	
3		1.6118	2.5149	
4		1.8031	2.652	
5		2.1734	3.0312	
6		2.3343	3.1207	
7			3.1173	
8		2.3371	2.935	
9			2.9321	
16		.3567		
17		.4515		
18		.4938		
19		.8002		
20		.8745		
21		.7373		
22		.663		
23		.5935		
24	2.0262	.8049	1.9938	2.0045
Max	2.0262	2.3371	3.1207	2.0045
Min	2.0262	.3567	1.9938	2.0045
Avg	2.0262	1.1733	2.6912	2.0045

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194028 / 33KV S/S NARANGWADI S/S

Feeder No / Name : 204 / 11KV Kawtha Gaonthan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	23-MAY-17	24-MAY-17	25-MAY-17	27-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2254	.2069	
2		.2415	.2035	
3		.2737	.2652	
4		.3059	.2949	
5		.3385	.3239	
10			.2006	
11		.2143		
12		.1974		
13		.1806		
14		.1882		
15		.1783		
16		.1783		
17		.1656		
21		.2622		
22		.2785		
23		.2713		
24	.2237	.2093	.2427	.1892
Max	.2237	.3385	.3239	.1892
Min	.2237	.1656	.2006	.1892
Avg	.2237	.2318	.2482	.1892

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194028 / 33KV S/S NARANGWADI S/S

Feeder No / Name : 205 / 11kv narangwadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	23-MAY-17	24-MAY-17	25-MAY-17	27-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1379	
2		.1288		
3		.1449	.1326	
10			.463	
11		.4287		
12		.4512		
13		.4967		
14		.5068		
15		.5213		
16		.5201		
17		.4967		
18		.1852		
19		.2241		
20		.2429		
21		.2294		
22		.2012		
23		.1696		
24	.1203	.1127	.1387	.1373
Max	.1203	.5213	.463	.1373
Min	.1203	.1127	.1326	.1373
Avg	.1203	.3163	.2181	.1373

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194041 / 33/11KV S/STN. TURORI

Feeder No / Name : 202 / 11KV MULAJ FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7318	.6859	1.2174	.4115	1.3717	
2	1.8004	1.3336	1.2003	.4115	1.3889	
3	1.8004	.7621	1.3032	.3963	1.3375	
4	2.0233	.9145	1.749	.3963	1.8004	
5	2.5549	1.0669	2.1948	.4572	2.2291	
6	2.8121	1.2193	2.5377	.4668	2.7092	
7	2.3834	1.2346		.5068	3.3436	
8	2.5034	1.2574	2.9835	1.7147	2.4691	
9	2.7092	1.2193	2.8807		2.8464	
17						1.648
22					1.3375	
24	1.7833	.6097			1.2346	
Max	2.8121	1.3336	2.9835	1.7147	3.3436	1.648
Min	1.7318	.6097	1.2003	.3963	1.2346	1.648
Avg	2.2102	1.0303	2.0083	.5951	2.0062	1.648

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194041 / 33/11KV S/STN. TURORI

Feeder No / Name : 203 / 11KV TALMOD FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.7888
2						.7888
3						.7373
4						.9602
5						1.2517
6		.8669				2.0233
7						2.2634
8						2.2119
9						2.1776
10	.4954	.3048			1.0631	
11	1.6671	2.1776	1.3717	1.406	2.0233	
12	.945	2.4006	1.5432	2.2119	2.2805	
13		2.2119	1.5432	2.2977	2.1091	
14	.6859	2.1605	1.3375	2.2119	2.0233	
15	.8383	2.3663	1.4403	2.1262	1.869	
16	1.5337	2.332	1.5089	2.2805	2.1434	
17		1.3546	1.6004	2.4006	2.1776	
22				1.4918		
24						.7545
Max	1.6671	2.4006	1.6004	2.4006	2.2805	2.2634
Min	.4954	.3048	1.3375	1.406	1.0631	.7373
Avg	1.0276	1.7972	1.4779	2.0533	1.9612	1.3958

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194041 / 33/11KV S/STN. TURORI

Feeder No / Name : 204 / 11KV Mulaj Gaothan Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3868	.2439	.2953		.4115	.3868	.3601
2	.3868	.2439	.2667		.4115	.3734	.3734
3	.4001	.2667	.4001		.4115	.4668	.3734
4	.5068	.381	.362		.5182	.5201	.4668
5	.6401	.381	.4287		.8535	.4572	.5601
6	.7868	.8669	.6573		.8535	.8802	.7068
7	.7468	.4954			.8669	.7735	.8135
8	.6802	.503	.8269		.8002	.7468	.8002
9	.7068	.381	.7868			.6668	.7335
10	.3201	.3429				.6001	
11	.5335			.4344	.4801	.5335	
12	.2667	.4268		.4344	.4268	.4268	
13	.2286	.3201		.4115	.4134	.4001	
14	.2134	.2801		.3887	.4534	.4134	
15	.1524			.3772	.4268	.3601	
16	.16	.3048		.4115	.4534	.4268	
17		.2858		.3429	.4668	.4534	.3144
18	.221	.6668		.5068	.4668	.4801	
19	.381	.7468		.7621	.6001	.5868	
20		.7868		.8383	.6935	.7735	
21		.7602		.7621	.6401	.6935	
22		.6802		.7316	.5601	.5335	
23		.6135		.5639	.2858	.4668	
24	.4134	.2362	.4534		.4287	.4001	.4001
Max	.7868	.8669	.8269	.8383	.8669	.8802	.8135
Min	.1524	.2362	.2667	.3429	.2858	.3601	.3144
Avg	.4280	.4643	.4975	.5358	.5419	.5342	.5366

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194041 / 33/11KV S/STN. TURORI

Feeder No / Name : 205 / P.B.A.INFRA EXPRESS FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
KAR Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.1524	.0381		.12	.0381	.0381
2	.0381	.1524	.0381		.12	.0381	.0381
3	.0381	.1524	.0381		.1029	.0381	.0381
4	.0381	.1524	.0381		.1029	.0381	.0381
5	.0381	.1524	.0381		.1029	.0381	.0381
6		.3772	.0381		.1029	.0381	.0381
7	.0381	.1524			.1029	.0381	.0381
8	.0381	.1524	.0381		.0686	.0381	.0381
9	.0381	.1524				.0381	.0381
10		.1143			.0953	.0953	
11	.1067			.0686	.0953	.0953	
12	.1067	.1429		.2058	.0953	.0953	
13	.1143	.1429		.2058	.0953	.0953	
14		.1429		.2743	.1429	.0953	
15	.1143	.1429		.2743	.1429	.1429	
16	.1372	.1429		.3658	.1429	.1429	
17	.1372	.1429		.2134	.1429	.0381	.0762
18	.1372	.1429		.0686	.1429	.1429	
19	.1524	.1429		.12	.1429	.1429	
20	.3429	.1429		.12	.1429	.1429	
21		.0953		.3601	.1429	.1429	
22		.0953		.3506	.0953	.1429	
23		.0953		.3506	.0381	.0381	
24	.0381	.1524	.0381			.0381	.0381
Max	.3429	.3772	.0381	.3658	.1429	.1429	.0762
Min	.0381	.0953	.0381	.0686	.0381	.0381	.0381
Avg	.0940	.1494	.0381	.2291	.1128	.0806	.0416

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194056 / 33KV CHOURASTHA OMERGA S/S

Feeder No / Name : 201 / 11 kv Chourasta gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.4024	.439	.2667	.2477	.439	.2477
2	.2477	.4024	.439	.2667	.2477	.439	.2667
3	.2667	.4024	.4572	.2477	.2858	.4755	.2667
4	.2667	.439	.4755	.2477	.2858	.4755	.2858
5	.2858	.4572	.4755	.2667	.2667	.5121	.2858
9					.3658		
10	.5121	.3658	.3201	.2667	.4024	.2667	.2667
11	.4755	.439	.2858	.2477	.4755	.2667	.4534
12	.439	.4572	.2667	.2477	.4572	.2382	.399
13	.439	.4572	.2477	.2286	.4572	.2286	.3628
14	.4024	.439	.2286	.2286	.439	.2286	.3265
15	.4024	.439	.2096	.2096	.439	.2096	.3265
16	.439	.439	.2096	.2096	.439	.2096	.3265
17	.439	.439	.2286	.1905	.439	.1905	.3265
18	.4572	.4572	.2286	.2286	.439	.1905	.2902
19	.5121	.4755	.2858	.2477	.4572	.2477	.4353
20	.4755	.5487	.2667	.2667	.5121	.2667	.5441
21	.439	.5121	.2477	.2477	.5121	.2286	.5804
22	.439	.4755	.2286	.2477	.5121	.2286	.5079
23	.4024	.4572	.2286	.2286	.439	.2096	.4353
24	.2286	.4024	.439	.2286	.2286	.439	.2096
Max	.5121	.5487	.4755	.2667	.5121	.5121	.5804
Min	.2286	.3658	.2096	.1905	.2286	.1905	.2096
Avg	.3908	.4454	.3104	.2410	.3975	.2995	.3572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194056 / 33KV CHOURASTHA OMERGA S/S

Feeder No / Name : 203 / 11 kv EKURGA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6523	.4572	.4344	.7316	.4572
2			.8154	.5716	.5487	1.0974	.4572
3			.9785	.5716	.5716	1.2803	.5716
4			.9785	.6859	.5716	1.1416	.5716
5			1.1416	.6859	.5716	1.2394	.6859
6			1.2068	.7773	.6859	1.2394	.6859
7				.8002	.6859	1.3047	.6859
8			1.3047		.8459	.9145	.9145
9			.9145	.9145	1.4632	.7621	.9145
10	.4893						
11	.8154						
12	.8154	.848					
13		.9785					
14		1.1416					
15		1.2721					
16		1.3047					
17		1.3047					
23			.3429				
24			.6523	.3429	.3429	.5487	.3429
Max	.8154	1.3047	1.3047	.9145	1.4632	1.3047	.9145
Min	.4893	.848	.3429	.3429	.3429	.5487	.3429
Avg	.7067	1.1416	.8988	.6452	.6722	1.0260	.6287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194056 / 33KV CHOURASTHA OMERGA S/S

Feeder No / Name : 205 / 11 KV STONE CRUSHER NON SHEDDABLE EXPRESS HV FEEDERS
 EXPRESS FE Feeder KV- 11 / (CONTINOUS PROCESS)(NO STAGGERING)
 OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.1097	.0732	.0572	.0381	.1097	.0476
2	.0572	.0914	.0732	.0572	.0038	.0914	.0476
3	.0667	.0914	.0732	.0667	.0476	.0914	.0476
4	.1143	.0914	.0732	.0667	.0476	.0914	.0476
5	.1143	.1097	.0914	.0953	.0476	.1097	.0572
6	.0953	.1097	.0914	.0953		.1097	.0476
7	.1334			.1143	.0572	.128	.0572
8	.1524		.1097	.1143	.0572	.0667	.0572
9	.1524		.1097	.1334	.1829	.0762	.0572
10	.1715		.1143	.1524	.2195	.0953	.0762
11	.3292		.1524	.1524	.2561	.1143	.1814
12	.3658		.1715	.1143	.2926	.1143	.2539
13	.3658		.1905	.0953	.3292	.1334	.2177
14	.3292		.1905	.1429	.3658	.1524	.1451
15	.2926		.1524	.0953	.3658	.1715	.1054
16	.2926		.1334	.0762	.3292	.1143	.1451
17	.2561		.1524	.1143	.2926	.1143	.0726
18	.2195		.1715	.1334	.3658	.1048	.1814
19	.1829		.1143	.0667	.3292	.0953	.2539
20	.1463		.0953	.0572	.2926	.0762	.2539
21	.1097		.0667	.0476	.1829	.0572	.2539
22	.1097		.0667	.0476	.128	.0572	.1088
23	.1097		.0572	.0476	.128	.0476	.1088
24	.0572	.1097		.0572	.0381	.1097	.0476
Max	.3658	.1097	.1905	.1524	.3658	.1715	.2539
Min	.0572	.0914	.0572	.0476	.0038	.0476	.0476
Avg	.1784	.1019	.1147	.0917	.1912	.1013	.1197

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194073 / 33/11 KV SUBSTATION BEDGA

Feeder No / Name : 201 / 11 KV BEDGA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3086	.2915	.3086	.3086	.3086	.2915
2	.3429	.3429	.2915	.3086	.3086	.3086	.3086
3	.4458	.4287	.3086	.3429	.3258	.3429	.3258
4	.4801	.4801	.3258	.4287	.3601	.4287	.3944
5	.5487	.5487		.5144	.4458	.4801	.463
6	.7202	.6859	.6001	.6001	.6173	.583	.7888
7	.5316	.7373		.7545	.7373	.7716	.7716
8	.5144	.6173	.6859	.583	.6173	.7202	.6859
9	.4801	.5316	.6001	.6344	.4801	.5144	.5407
10	.3772	.3429	.4287	.5144	.3429	.463	
11	.3429	.3429	.3429	.4115	.2743	.3772	
12	.2572	.3258	.3086	.3429	.2401	.3429	
13	.1886	.2915	.3086	.3086	.2401	.3086	.2429
14	.2229	.2743	.3086	.3086	.2743	.3086	.1943
15	.2743	.2743	.3086	.3086	.5144		
16	.3086	.3258	.3086	.3258	.3086	.2915	
17	.3086		.3601	.3772	.3429	.3429	.3201
18	.3429	.3601	.4287	.4801	.4458	.3772	.4372
19	.5487	.4801	.5144	.5144	.5144	.4801	.5243
20	.5144	.5144	.6001	.5144	.5487	.6001	.5601
21	.4458	.4458	.5487	.4973	.5144	.5144	.4588
22	.3772	.3601	.4287	.3429	.4801	.4458	.3201
23	.3429	.3086	.3258	.3086	.3429	.2915	.3077
24	.3086	.3086	.2915	.3086	.3086	.3086	.2915
Max	.7202	.7373	.6859	.7545	.7373	.7716	.7888
Min	.1886	.2743	.2915	.3086	.2401	.2915	.1943
Avg	.3972	.4190	.4053	.4308	.4122	.4309	.4330

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194073 / 33/11 KV SUBSTATION BEDGA

Feeder No / Name : 202 / 11 KV BEDGA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							1.5775
2							1.6289
3							1.7147
4							1.8176
5							1.9033
6							2.4006
7							2.452
8							2.3663
9							2.251
10	1.8176	1.9719	2.1434	1.7147	1.8176	1.6804	
11	1.9376	2.0576	2.4863	2.572	2.2977	2.452	
12	1.989	2.2291	2.572	2.4863	2.5377	2.5377	
13	2.0576	2.3148	2.4863	2.5377	2.6235	2.4348	
14	2.2634	2.332	2.452	2.572	2.6578	2.5034	
15	2.3148	2.332	2.4863	2.572	2.4863		
16	2.3148	2.3663	2.4863	2.572	2.5377	2.3834	
17	2.1091		2.572	2.6578	2.5377	2.4006	
24							1.4575
Max	2.3148	2.3663	2.572	2.6578	2.6578	2.5377	2.452
Min	1.8176	1.9719	2.1434	1.7147	1.8176	1.6804	1.4575
Avg	2.1005	2.2291	2.4606	2.4606	2.437	2.3418	1.9569

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194073 / 33/11 KV SUBSTATION BEDGA

Feeder No / Name : 203 / 11 KV CHENDKAL AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	1.7147	1.7147	1.5432	1.6289	1.7661	
2	1.8004	1.8519	1.8004	1.7147	1.7147	1.7661	
3	1.8004	1.8861	1.8861	1.7147	1.8861	1.8519	
4	1.8519	1.8861	1.8861	1.7833	1.9719	1.8861	
5	1.8861	2.0405	2.1434	1.7833	2.0576	1.8861	
6	1.8861	2.1434	2.2291	1.8004	2.0576	1.8861	
7	1.9033	2.1948		1.8004	2.1948	1.9376	
8	1.9719	2.2291	2.0576	1.8861	1.9547	1.9376	
9	1.9719	2.2462	1.9719	1.9376	2.0576	1.9204	
13							.1943
14							.2429
15							.1943
24	1.6804	1.6289	1.5432	1.4575	1.5432	1.6289	
Max	1.9719	2.2462	2.2291	1.9376	2.1948	1.9376	.2429
Min	1.6804	1.6289	1.5432	1.4575	1.5432	1.6289	.1943
Avg	1.8467	1.9822	1.9147	1.7421	1.9067	1.8467	.2105

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194074 / 33/11 KV SUBSTATION BALSOOR

Feeder No / Name : 201 / 11 KV BALSUR GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3932	.4428	.3906	.3887	.4062	.3563	.4096
2	.3932	.4481	.4428	.3887	.3906	.3605	.4096
3	.3932	.5068	.4428	.5506	.3906	.3768	.4096
4	.4372	.543	.4801	.421	.4374	.4144	.4424
5	.4858	.5761	.4858	.4858	.4687	.4424	.5121
6	.5898	.6154	.503	.5921	.5468	.5093	.5624
7					.427		
9							.381
10	.427	.4744	.4321	.4218	.5121	.4999	.4268
11	.426	.4321	.4475	.4687	.426	.3441	.4572
12	.3932	.3549	.426	.4687	.4588	.502	.4572
13	.3549	.3593	.4111	.4687	.3637	.4641	.4268
14	.3812		.427	.4374	.3749	.4374	.381
15	.3605	.3704	.3795	.3906	.3681	.463	.381
16	.3437	.3506	.4161	.3437	.3479	.4321	.4268
17		.3715	.4062	.3906	.3795	.4111	.4268
18	.4096	.4096	.4534	.4374	.4144	.4372	.4572
19	.5721	.5847	.5959	.4374	.547	.4784	.6706
20		.4877	.7602	.4687	.7602	.7783	.5335
21	.6733	.4572	.7316	.4999	.7011	.7421	.4572
22	.4687	.4572	.591	.5468	.567	.6516	
23	.4687	.4268	.5068	.4687	.5138	.543	.4268
24	.4239	.4374	.3858	.3978	.4374	.3481	.4191
Max	.6733	.6154	.7602	.5921	.7602	.7783	.6706
Min	.3437	.3506	.3795	.3437	.3479	.3441	.381
Avg	.4419	.4553	.4817	.4511	.4654	.4758	.4512

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194074 / 33/11 KV SUBSTATION BALSOOR

Feeder No / Name : 202 / 11 kv BALSOOR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.7499	1.6194	1.4251	1.2308	1.6385
2			1.6004	1.7004	1.6842	1.5238	
3			1.8623	1.7004	1.7814	1.6876	1.7204
4			1.8976	1.7814	1.9109	1.7368	1.7204
5			2.2138	1.8623	2.0243	1.9528	1.7604
6			2.2929	2.0005	2.2024	1.9753	1.9372
7				2.5126	2.5425	2.4684	2.3611
8			2.5101	2.1845	2.2996		2.1272
9			2.5587	1.917	2.2186	2.1674	
10	1.6446	1.8501					
11	2.1464	2.3457					
12	2.1464	1.9599					
13	1.9753						
14	2.4531						
15	2.343	1.9753					
16	2.2809	2.21					
17		2.1251					
24			.5247	1.21	1.0526	1.442	1.3245
Max	2.4531	2.3457	2.5587	2.5126	2.5425	2.4684	2.3611
Min	1.6446	1.8501	.5247	1.21	1.0526	1.2308	1.3245
Avg	2.1414	2.0777	1.8012	1.8489	1.9142	1.7983	1.8237

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194074 / 33/11 KV SUBSTATION BALSOOR

Feeder No / Name : 203 / 11KV RAMPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0481	1.7394					
2	2.0481	1.8185					
3	2.0481	2.0485					
4	2.0243	2.1052					
5	2.1052	2.13					
6	2.3594	2.4274					
7	2.4684	2.5934					
8	2.1824	2.5911					
9	1.7869	2.5587					
10			1.6964	1.749	1.7604	1.6716	1.2631
11			2.4863	2.3482	2.2283	2.3266	1.6194
12			2.3102	2.2672	2.3266	2.3482	2.1862
13			2.3878	2.3158	1.8343	2.1765	2.2672
14			2.2138	2.3967	2.0778	2.2028	2.4615
15			2.4352	2.4291	2.0165	2.1605	2.4615
16			2.5766	2.4939	2.198	2.3205	2.4291
17			2.5152	2.4615	2.234	2.451	2.4615
24	.8139	.703					
Max	2.4684	2.5934	2.5766	2.4939	2.3266	2.451	2.4615
Min	.8139	.703	1.6964	1.749	1.7604	1.6716	1.2631
Avg	1.9885	2.0715	2.3277	2.3077	2.0845	2.2072	2.1437

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194075 / 33/11 KV SUBSTATION GUNJOTI

Feeder No / Name : 202 / 11 KV AURAD FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8669	.7468	1.2483	1.2971	.9602	.7573	
2	.9054	.9602	1.2136	1.3321	1.1145	.8619	
3	1.0974	1.1469	1.3176	1.3032		.8619	
4	1.1233	1.4937	1.406	1.4563	1.7528	.9755	
5	1.643	1.7528	1.576	1.6827	2.0405	1.1431	
6	2.2885	1.8442	2.3059	2.5652	1.9966	1.7394	
7	2.2539	2.5587		2.6397	2.3967	2.2672	
8	2.2539	2.3482	2.4966	2.4453	2.4291	2.2672	
9	2.0233	2.1376	2.4863	2.2024	2.2024	2.0567	
10							1.335
11							1.8204
12							2.2712
13							2.1125
14							2.2192
15							2.2119
23			1.3003				
24	.6485	.2858	1.2269	1.0749	.7145	.643	
Max	2.2885	2.5587	2.4966	2.6397	2.4291	2.2672	2.2712
Min	.6485	.2858	1.2136	1.0749	.7145	.643	1.335
Avg	1.5104	1.5275	1.6578	1.7999	1.7341	1.3573	1.9950

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194075 / 33/11 KV SUBSTATION GUNJOTI

Feeder No / Name : 203 / 11 KV KHASGI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.6097
2						.6097
3						.6097
4						.6836
5						.8619
6						1.1294
7						1.4003
8						1.4098
9						***
10	.7087			.884	.7385	
11	1.0136	.2858	.5601	1.4255	1.1431	
12	.8002	.8459		1.4586	1.2717	
13	.7202	1.1431		1.7072	1.2407	
14	.7468		.4001	1.6933	1.1797	
15	.6935		.743	1.6766	1.1984	
16	.8002		.743	1.7101	1.2239	
17	.8669		1.6004	1.7436	1.2517	
18			1.6004			
19			1.5242			
20		.4382	.9145			
21		.463	.9145			
22		.4681				
23		.4858				
24						.5668
Max	1.0136	1.1431	1.6004	1.7436	1.2717	12.8744
Min	.6935	.2858	.4001	.884	.7385	.5668
Avg	.7938	.5900	1.0000	1.5374	1.1560	2.0755

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194080 / 33/11 KV ALOOR

Feeder No / Name : 201 / 11 KV ALOOR FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4575	1.4575	.1509	.1543	1.5432	1.4575	1.286
2	1.5432	1.5432	.1509	.1646	1.6289	1.4575	1.5432
3	1.6289	1.6289		.1646	1.8004	1.5432	1.6289
4	1.7147	1.7147	.1715	.1852	1.8861	1.5432	1.8861
5	1.8861	1.7147	.1818	.2058	1.9719	1.6289	1.9719
6	1.9719	1.7147			2.0576	1.9719	2.0576
7	2.2291	2.2291	.1886	.2263	2.1434	1.9719	1.8861
8	1.3717	1.9719	.1886	.2229	1.9719	1.8861	1.8347
10	.5144	.6687		.6001	.6001	.5487	
11		.0579	.0549	.6173	.6001	.6001	
12	.583	.0564	.0518		.6001	.5144	.0518
13	.5316		.5182				.0518
14	.5144	.0549	.0518	.5658	.6001	.5144	.0518
15	.583	.0549	.0518	.5658	.6001	.5658	.0518
16	.5316	.0549	.0549	.5487	.6001	.5144	.0518
17	.5487	.0579	.061	.5316	.6001	.6001	.0549
18	.583	.061	.061		.6001	.6001	.0625
19	.703	.0716	.0854	.9088	.9431	.8745	
20	1.0288	.0793	.0884	1.0631	1.0288	1.0802	.0884
21	1.0288	.0884		1.0631	1.0288	1.0631	.0884
22	.9431	.884		1.0288	.9431	.9259	.0884
23	.8059	.0884	.0518	.9431	.8573	.8916	.0884
24	1.4575	.7373	.0884	.0884		.7716	.8573
Max	2.2291	2.2291	.5182	1.0631	2.1434	1.9719	2.0576
Min	.5144	.0549	.0518	.0884	.6001	.5144	.0518
Avg	1.0982	.7723	.1251	.5183	1.1717	1.0693	.7841

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194080 / 33/11 KV ALOOR

Feeder No / Name : 203 / 11 KV KESARJAWLGA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2572	.0274	.0244	.2743		.2058
2	.2572	.2572	.0244	.0244	.2743	.2572	.2058
3	.2572	.2572	.0244	.0244	.3086	.2572	.2743
4	.3429	.3429	.0244	.0274	.3086	.3429	.3429
5	.3429	.3429	.0274	.0305	.3429	.3429	.3429
6	.4287	.2572	.0274		.3429	.4287	.3429
7	.3429	.2572		.0305	.3429	.4287	.3429
8			.0305		.3429	.4287	.3429
9	.9431	1.0288	.1372	1.4746	1.2003	1.1145	1.2003
10	1.0288	1.0288		1.4575	1.286	1.2003	.1406
11	1.286	.1337	.1406	1.3717	1.286	1.286	.1406
12	1.286	.1337	.1372		1.286	1.2003	.1372
13	1.2003	.1337	.1372	1.2003	1.286		.1372
14	1.1145		.1372	1.2003	1.286	1.2003	.1337
15	1.1145	.1269	.1372	1.2003	1.286	1.2003	.1303
16	1.1145	.12	.1406	1.3717	1.2003	1.1145	.1269
17	.1715	.0274	.0244	.3086	.1715	.2743	.0305
18	.1715	.0305	.0274		.1715		.0396
19	.2572	.0335	.0305	.3429	.3429	.3429	
20	.3429	.0335	.0305	.3429	.4287	.3429	.0366
21	.4287	.0305	.0274	.3429	.4287	.3429	.0366
22	.4287	.0305	.0274	.3429	.3429	.3086	.0366
23	.3429	.0305	.0244	.3086	.3429	.2572	.0366
24	.2572	.2572	.0274	.0244		.2572	.1715
Max	1.286	1.0288	.1406	1.4746	1.286	1.286	1.2003
Min	.1715	.0274	.0244	.0244	.1715	.2572	.0305
Avg	.5964	.2341	.0624	.5726	.6471	.6156	.2146

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194009 / 33/11 TULJAPUR S/S

Feeder No / Name : 201 / 11 kv URBAN TULJAPUR SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4842	1.406	1.4373	1.406	1.448	1.4723	1.5203
2	1.4842	1.3717	1.4022	1.3889	1.448	1.4373	1.4842
3	1.5927	1.3546	1.3672	1.3717	1.448	1.4022	1.448
4	1.3717	1.3889	1.3672	1.3889	1.4842	1.4022	1.448
5	1.406	1.406	1.4022	1.3889	1.5203	1.4198	1.4842
6	1.406	1.4575	1.4899	1.406	1.5203	1.4548	1.5384
7	1.3717	1.406	1.4373	1.3032	1.448		1.4842
8	1.2517	1.3546	1.4373	1.2346	1.3756	1.3146	1.4118
9	1.267	1.2346	1.262	1.1831	1.267	1.2269	1.2308
10	1.1831	1.262		1.2308	1.2445	1.1946	1.2517
11		1.2795		1.267	1.262	1.2308	1.2689
12		1.3672		1.267	1.3146	1.2851	1.286
13		1.2971		1.3032	1.262	1.2489	1.3032
14		1.3321		1.3575	1.262	1.267	1.3375
15		1.3672		1.3032	1.262	1.2308	1.3717
16		1.4022		1.1946	1.2971	1.2517	1.3375
17		1.2971		1.3756	1.2971	1.286	
18		1.4022		1.3575	1.2795	1.3032	
19		1.4723		1.4118	1.4022	1.5023	
20		1.6126		1.6108	1.6126	1.6289	
21		1.5775		1.5927	1.6126	1.6289	
22		1.5775		1.5927	1.6126	1.6289	
23		1.5775		1.5746	1.595	1.5927	
24	1.5203	1.4403	1.5074	1.4232	1.4842	1.5424	1.5565
Max	1.5927	1.6126	1.5074	1.6108	1.6126	1.6289	1.5565
Min	1.1831	1.2346	1.262	1.1831	1.2445	1.1946	1.2308
Avg	1.3944	1.4018	1.411	1.3722	1.4066	1.3892	1.3978

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194009 / 33/11 TULJAPUR S/S

Feeder No / Name : 202 / 11 kv APSINGA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.166	1.1888	.2241	.1829	.2743	.192	.2572
2	1.3032	1.2498	.2241	.1829	.2896	.192	.2572
3	1.5089	1.1203	.2241	.1829	.2896	.192	.2401
4	1.6461	1.1736	.2241	.1829	.1372	.192	.2401
5	1.749	1.2536	.2241	.1829	.1029	.192	.2229
6	1.8176	1.4403	.2241	.1829	.1029	.192	
7	1.9547	1.8004					
8	2.1948	1.7337					
9	1.6289	1.5337					
10				1.3717	1.0242	1.3375	.2743
11				2.0919	1.7124	1.9376	.3353
12				2.1434	1.8084	1.9376	1.387
13				2.0576	1.9022	1.6975	1.427
14				1.6461	1.829	1.6804	1.3736
15				1.6118	1.6004	1.6461	1.3603
16				1.9719	1.6004	1.5432	1.387
17				1.749	1.7604	1.8176	
18		.128		.1372	.096	.1543	
19		.2241		.2058	.144	.2572	
20		.2241		.2229	.16	.2743	
21		.2241		.2229	.192	.2915	
22		.2241		.2743	.192	.3086	
23		.2241		.2743	.2241	.3086	
24	1.0631	.9145	.2241	.1981	.2743	.192	.2572
Max	2.1948	1.8004	.2241	2.1434	1.9022	1.9376	1.427
Min	1.0631	.128	.2241	.1372	.096	.1543	.2229
Avg	1.6032	.9161	.2241	.8227	.7484	.7874	.6938

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194009 / 33/11 TULJAPUR S/S

Feeder No / Name : 203 / 11 KV KAKRAMBA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8663	1.7757	.1448	.1524	.1829	.1471	
2	1.986	1.7101	.1448	.1524	.1829	.1448	
3	2.0416	1.7238	.1448	.1524	.1829	.1448	
4	2.1193	1.8293	.1448	.1524	.1829	.1448	
5	2.1666	1.8846	.2279	.2355	.2667	.1669	
6	2.3251	2.1197	.2309	.2546	.2705	.2469	
7	2.9591	1.0349					
8	2.9812	2.3879					
9	2.8182	2.2702					
10	1.0905	.9335	.2858	1.6682	1.5577	1.5493	
11			.8604	2.3487	2.4844	1.6469	.9877
12			1.0029	2.4128	2.4204	2.0813	1.0181
13			1.0166	2.2428	2.3479	2.0539	1.0014
14			1.0189	2.0286	2.3098	1.951	.9511
15			.8772	2.1795	2.3129	1.8343	.868
16			1.0151	2.3572	2.3136	1.9868	2.2214
17			1.0319	2.261	2.505	2.1819	.9831
18	.0663	.1158	.7788	1.0151	1.0173	1.0128	.9061
19	.1196	.1539	.0716	.2766	.2065	.2667	.0221
20	.1235	.2103	.1082	.2644	.2439	.2812	.0846
21	.1219	.2286	.0899	.2614	.2324	.266	.0831
22	.1166	.2073	.0229	.2614	.2218	.253	
23	.1059	.1448		.192	.1448	.1852	
24	1.2643	1.0669	.1448	.1524	.1837	.1738	.1829
Max	2.9812	2.3879	1.0319	2.4128	2.505	2.1819	2.2214
Min	.0663	.1158	.0229	.1524	.1448	.1448	.0221
Avg	1.4278	1.1645	.4682	1.0010	1.0367	.8914	.7758

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194009 / 33/11 TULJAPUR S/S

Feeder No / Name : 204 / HANGARGA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305	.0343	1.1828	1.3779	1.3946	1.3462	1.5417
2	.0305	.0343	1.1629	1.4159	1.448	1.3629	1.544
3	.0305	.0343	1.1927	1.4921	1.4708	1.3942	1.5394
4	.0305	.0343	1.2148	1.4586	1.5364	1.4221	1.5638
5	.0305	.0343	1.3238	1.438	1.5821	1.4247	1.5745
6	.0305	.0343	1.541	1.4822	1.669	1.6788	1.6072
7		.0008	.9656	2.1437	2.159	2.0934	2.2092
8			.1745	2.3807	1.906	2.295	2.3228
9			.5517	2.2421	1.9776	2.1864	2.114
10		.823	.996	1.3146	1.1393	1.1088	1.0631
11	1.1477	1.7672	.2332	.0236	.1158		.0907
12	1.2521	1.8366					
13	1.1637	1.8114					
14	1.0677	1.8					
15	.9838	1.8069					
16	.8878	2.1231					
17	1.1469	2.1795					
18	1.3088	.9145		.0305	.0343	.0305	
19	.1547	.1418	.0015	.0419	.0351	.0305	.0023
20	.0008	.0514		.0473	.0529	.0305	
21		.0514	.0015	.0511	.056	.0305	
22		.0514	.0015	.0305	.0529	.0305	
23		.0544		.0457	.0514	.0305	
24	.0305	.0343	.4542	.5792	.6097	.6173	.6554
Max	1.3088	2.1795	1.541	2.3807	2.159	2.295	2.3228
Min	.0008	.0008	.0015	.0236	.0343	.0305	.0023
Avg	.5487	.7115	.7332	.9775	.9606	1.0066	1.3714

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194009 / 33/11 TULJAPUR S/S

Feeder No / Name : 205 / 11 KV VIP FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5844	1.4746	1.6598	1.4746	1.6221	1.6975	1.6975
2	1.5466	1.4403	1.5844	1.4403	1.6221	1.6221	1.6289
3	1.5089	1.406	1.5089	1.406	1.5844	1.5364	1.6221
4	1.5089	1.4403	1.4712	1.406	1.5844	1.5844	1.6221
5	1.4712	1.4575	1.4712	1.406	1.6032	1.5844	1.6221
6	1.4712	1.4575	1.5466	1.4232	1.6032	1.6787	1.6221
7	1.4712	1.4232	1.5089	1.4232	1.5089		1.6221
8	1.2826	1.3375	1.3957	1.3032	1.4901	1.4335	1.4146
9	1.2826	1.3375	1.358	1.3032	1.3957	1.3717	1.358
10		1.5089		1.4335	1.358	1.358	1.2346
11		1.5466		1.4712	1.4712	1.358	1.3375
12		1.5089		1.5089	1.5844	1.3769	1.3717
13		1.5844		1.5466	1.5089	1.3957	1.3546
14		1.6032		1.5844	1.6221	1.358	1.406
15				1.6032	1.6221	1.4712	1.406
16		1.6221		1.6032	1.6598	1.4901	1.4403
17		1.5466		1.5655	1.6598	1.4632	
18		1.5844		1.4146	1.5089	1.4523	
19		1.6221		1.6032	1.6787	1.5655	
20		1.8296		1.8484	1.9616	1.7918	
21		1.8296		1.773	1.9239	1.7918	
22		1.8107		1.773	1.8861	1.7918	
23		1.8107		1.773	1.8484	1.773	
24	1.6221	1.5089	1.6975	1.5089	1.6598	1.773	1.7541
Max	1.6221	1.8296	1.6975	1.8484	1.9616	1.7918	1.7541
Min	1.2826	1.3375	1.358	1.3032	1.358	1.358	1.2346
Avg	1.4750	1.5518	1.5202	1.5248	1.6237	1.553	1.5008

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194009 / 33/11 TULJAPUR S/S

Feeder No / Name : 206 / 11 KV SALAGARA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0457	1.4632	1.6804	1.8062	.5517	1.393
2	.0514	.0457	1.4869	1.7413	1.9441	.0008	1.4662
3	.0514	.0457	1.5051	1.7909	2.1186		1.5112
4	.0514	.061	1.5645	1.7993	2.2908		1.611
5	.0514	.0762	1.6636	1.7181	2.3544		1.6514
6	.0514	.0857	1.9525	1.8792	2.5663		1.6674
7			2.7427	2.4729	3.2461	.0968	2.6205
8			2.5698	2.3137	2.6909	.993	3.0498
9			1.5363	2.226	2.2592	1.0147	1.9864
10	.0038	1.3817	.7118	.9	.7781	.4252	.7217
11	.9648	2.5118					
12	1.0684	2.4836					
13	1.0052	2.4112					
14	.916	2.2976					
15	.9229	2.085					
16	.8779	2.4226					
17	1.0326	2.7473					
18	1.0936	1.0544		.0716	.0469	.0457	
19		.0469		.0686	.0469	.0514	
20	.0152	.0469		.0686	.1109	.0514	
21		.0469		.0514	.1094	.0514	
22		.0469		.0514	.0469	.0514	
23		.0469		.0514	.0469	.0514	
24	.0514	.0983	1.11	1.0037	1.1991	1.0021	.884
Max	1.0936	2.7473	2.7427	2.4729	3.2461	1.0147	3.0498
Min	.0038	.0457	.7118	.0514	.0469	.0008	.7217
Avg	.4859	.9566	1.6642	1.1699	1.3919	.3375	1.6875

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194009 / 33/11 TULJAPUR S/S

Feeder No / Name : 207 / 11 KV KAKRAMBA GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3467	.4115	.4001	.2972	.3734	.4268	.3734
2	.3467	.2743	.4001	.2972	.3734	.4268	.3734
3	.3734	.2743	.4001	.2972	.4268	.4001	.4001
4	.5068	.3429	.4268	.3315	.6401	.4268	.5068
5	.6135	.4572	.5335	.4572	.7202	.4801	.6401
6	.6935	.583	.6935	.6059	.7735	.6401	.7335
7	.6935	.6287	.7468	.6287	.7468	.6935	.7335
8	.6935	.5487	.6935	.8078	.7468	.6401	.7335
9	.5868	.4572	.6401	.4801	.6401	.5868	.6401
10		.4801		.4268	.5335	.5601	.5373
11		.4268		.4268	.4801	.4668	.3887
12				.4268	.4268	.3734	.3201
13		.2667		.3734	.3734	.2934	.3315
14		.2667		.2667	.3201	.3467	.4877
15		.2667		.3201	.2934		.3887
16		.2934		.3734	.3201		.3429
17		.3201		.4268	.4001	.4801	
18		.3734		.5068	.4268	.4801	
19		.5335		.5868	.5335	.5868	
20		.6935		.6935	.6935	.6401	
21		.5868		.6401	.6401	.6401	
22		.5335		.5335	.5868	.5335	
23		.4268		.4268	.4801	.3734	
24	.3467	.2858	.4268	.3086	.3734	.4534	.3734
Max	.6935	.6935	.7468	.8078	.7735	.6935	.7335
Min	.3467	.2667	.4001	.2667	.2934	.2934	.3201
Avg	.5201	.4231	.5361	.4558	.5135	.4977	.4885

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194009 / 33/11 TULJAPUR S/S

Feeder No / Name : 208 / 11 KV APSINGA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3982	.3601	.3658	.3258	.3258	.3658	.362
2	.3982	.3601	.3658	.3258	.3258	.3292	.362
3	.4344	.3601	.3658	.3258	.362	.3292	.3982
4	.4706	.3772	.4024	.3601	.4344	.3658	.4344
5	.5068	.4115	.439	.3944	.5068	.4024	.5068
6	.5068	.4801	.5121	.4287	.543	.439	.543
7	.5068	.3944		.2915	.4706	.439	.4706
8	.4344	.3772	.3658	.3601	.3982	.439	.5068
9	.3982	.3258	.4024	.2229	.1086	.3658	.362
10		.439		.362	.1097	.362	.3429
11		.3658		.362	.3658	.3077	.3086
12				.362	.3292	.3258	.3086
13		.2926		.3258	.3292	.3258	.2743
14		.2561		.3258	.2926	.2896	.2915
15		.2561		.2896	.2926	.3258	.3086
16		.2743		.3258	.3292	.3982	.2915
17		.3292		.3258	.3658	.3258	
18		.3658		.362	.3658	.3258	
19		.4755		.362	.4755	.3982	
20		.5853		.362	.5853	.5792	
21		.5121		.5068	.5487	.5792	
22		.4755		.4706	.5121	.5068	
23		.439		.3982	.439	.4344	
24	.3982	.3772	.3658	.3429	.3258	.4024	.3429
Max	.5068	.5853	.5121	.5068	.5853	.5792	.543
Min	.3982	.2561	.3658	.2229	.1086	.2896	.2743
Avg	.4453	.3865	.3983	.3549	.3809	.3901	.3773

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194009 / 33/11 TULJAPUR S/S

Feeder No / Name : 209 / TIRTH GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7271	.6687	.726	.6962	.7118	.71	.6664
2	.6965	.6451	.7032	.6954	.6973	.6793	.6588
3	.7232	.6264	.7232	.6924	.7681	.6771	.682
4	.7986	.6901	.8063	.7373	.8314	.7156	.7903
5	.865	.7956	.897	.8463	.8848	.7777	.8688
6	1.0021	1.0894	1.1008	1.0707	1.0337	1.038	1.0381
7	1.0974	1.2559	1.2273	1.2292	1.1622	1.2639	1.1448
8	1.1248	.6645	1.2303	1.118	.993	1.1455	1.0585
9	1.0254	.9549	1.0265	.9583	1.0113	.9716	.8478
10	.4946	.8535	.4466	.8821	.8611	.876	.7316
11	.3833	.663	.3963	.7567	.679	.6965	.6935
12	.3208	.282	.2881	.6774	.6036	.6318	.6302
13	.2957	.4523	.2942	.5891	.6611	.5115	.5788
14	.2926	.4896	.2888	.5464	.6371	.481	3.392
15	.2919	.5559	.2896	.5609	.5719	.5057	.6211
16	.2904	.6226	.2881	.6397	.5475	.4869	.6005
17	.2957	.692	.3071	.642	.6099	.5171	.2949
18	.3231	.8151	.3803	.6844	.7034	.572	.3559
19	.3909	.9096	.4199	.9221	.897	.8233	.4207
20	.6158	1.2229	.615	1.2317	1.2039	1.0562	.5571
21	.6981	1.2022	.6661	1.1725	1.2407	1.1839	.6744
22	.6165	1.0503	.6249	1.046	1.0917	1.0501	.5937
23	.5045	.8936	.5266	.8669	.8575	.5574	.5373
24	.7621	.7079	.7697	.7221	.7469	.7621	.714
Max	1.1248	1.2559	1.2303	1.2317	1.2407	1.2639	3.392
Min	.2904	.282	.2881	.5464	.5475	.481	.2949
Avg	.6098	.7835	.6267	.8327	.8336	.7788	.7980

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194009 / 33/11 TULJAPUR S/S

Feeder No / Name : 405 / 33KV YEOTI

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.1209	4.1152	2.6063	2.5605	3.1207	2.9379	3.2293
2	4.5667	4.2066	2.7092	2.5605	3.5551	2.9379	3.3379
3	4.8925	4.7097	2.9379	2.8807	3.5551	2.9379	3.1092
4	5.5556	4.8926	3.0407	2.8807	3.6637	2.9379	3.4465
5	6.0014	5.0755	3.1436	2.9721	3.7723	3.0407	3.5551
6	6.6758	5.6241	3.8066	3.8866	4.4581	4.3438	4.1209
7	7.1331	6.5844	4.4696	4.5268	5.2412	5.0069	4.904
8	7.0245	6.6301	4.3668	5.2126	5.1326	4.6754	4.6868
9	6.5787	4.7097	4.0352	4.1953	4.7954	4.5725	4.3495
10	3.4294	4.161	2.0576	5.0126	4.4467	4.7839	4.2524
11	2.5149	4.9795	2.9721	6.2414	5.4184	6.2414	5.0297
12	2.5149	3.0293	3.2007	6.6873	6.0814	6.35	5.3498
13	2.5149	1.4289	3.4294	6.6873	6.2871	6.2414	5.6698
14	2.2862	2.5834	3.2007	4.6639	6.1842	6.0242	5.4412
15	2.0576	4.2409	3.2007	2.9321	6.1842	5.7956	5.3498
16	2.0576	4.1381	3.2007	3.1493	5.7499	5.4698	5.5784
17	2.0576	3.9095	3.2007	3.0407	5.647	5.2412	2.9721
18	1.829	2.6749	2.9721	.543	2.7207	3.1779	2.9721
19	.2286	1.3032	1.829	.7602	1.3032	1.2289	.6859
20	.9145	1.8633	1.1431	.9774	1.9661	1.6747	.9145
21	.9145	1.5318	.9145	.7602	1.6347	1.6747	.9145
22	.9145	1.3032	.6859	.6516	1.3032	1.3375	.6859
23	.6859	1.2003	.6859	.6516	1.2003	1.1203	.6859
24	2.7606	2.332	1.8176	1.0974	2.2177	2.252	2.0977
Max	7.1331	6.6301	4.4696	6.6873	6.2871	6.35	5.6698
Min	.2286	1.2003	.6859	.543	1.2003	1.1203	.6859
Avg	3.3429	3.6345	2.7344	3.1472	3.9850	3.8335	3.4725

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194023 / 33/11 IEETKAL S/S

Feeder No / Name : 201 / 11 KV ITKAL AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.2384	1.2384	1.6194	1.2955	1.4289
2			1.3336	1.2384	1.829	1.448	1.4289
3			1.7909	1.2384	1.9052	1.448	1.4289
4			1.829	1.3336	2.0576	1.5623	1.4861
5			1.9052	1.5242	2.1338	1.7147	1.4861
6			2.0005	2.0005	2.191	1.9814	1.7147
7			2.0957	2.4768	2.2862	2.0957	1.9052
8			2.0005	2.3815	2.0957	2.0195	2.0005
9			2.0005	1.9814	1.9624	1.8671	1.7147
10	1.6194	1.5242					
11	2.0957	2.191					
12	2.21	2.1719					
13	2.191	2.0957					
14	2.0005	2.0005					
15	1.9052	2.2291					
16	1.7147	1.2384					
17	2.191	1.6575					
24			1.0479	1.1812	1.1812	1.105	1.0479
Max	2.21	2.2291	2.0957	2.4768	2.2862	2.0957	2.0005
Min	1.6194	1.2384	1.0479	1.1812	1.1812	1.105	1.0479
Avg	1.9909	1.8885	1.7242	1.6594	1.9262	1.6537	1.5642

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194023 / 33/11 IEETKAL S/S

Feeder No / Name : 202 / 11 KV KESHEGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0957	1.9052	.1143	.1905	.1143	.1524	.1524
2	2.0957	1.9052	.1143	.1905	.1143	.1524	.1524
3	2.0957	1.9052	.1143	.1905	.1524	.1524	.1905
4	2.2862	2.2862	.1524	.1905	.1524	.1524	.1905
5	2.4768	2.8578	.1524	.2286	.1905	.1905	.1905
6	1.8671	3.0483	.1524	.2286	.1905	.1905	.1905
7	2.7435	3.4294					
8	1.5242	3.3341					
9	3.0864	2.8578					
10			2.1529	2.3624	2.0957	2.2862	2.191
11			3.1626	2.915	3.0864	2.7625	2.8578
12			3.2388	2.8578	3.2388	2.9531	3.0483
13			3.0102	2.6673	3.0483	2.8578	3.0483
14			2.8197	2.4387	2.7816	2.7625	2.8578
15			2.7054	2.7244	2.934	2.9531	2.9531
16			3.1245	3.0102	2.9721	2.9531	2.9531
17			3.2007	2.7625	3.0864	2.7625	2.8578
18	.1524	.1143	.1905	.1143	.1524	.1905	.1905
19	.1905	.1524	.2286	.1524	.2667	.2286	.1905
20	.1905	.1524	.2286	.1524	.2286	.1905	.1905
21	.1905	.1524	.2286	.1524	.1905	.1905	.1905
22	.1905	.1524	.1905	.1524	.1905	.1905	.1905
23	.1905	.1524	.1905	.1524	.1524	.1905	.1524
24	1.6385	1.5242	.1524	.1905	.1524	.1524	.1524
Max	3.0864	3.4294	3.2388	3.0102	3.2388	2.9531	3.0483
Min	.1524	.1143	.1143	.1143	.1143	.1524	.1524
Avg	1.4384	1.6206	1.2202	1.1440	1.2139	1.1721	1.1948

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194023 / 33/11 IEETKAL S/S

Feeder No / Name : 203 / 11 KV ITKAL GAONTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5792	.5525	.6401	.5731	.6878	.5731	.5373
2	.5792	.5335	.695	.5731	.7499	.5853	.5121
3	.5731	.5335	.6878	.5792	.8413	.5853	.5121
4	.6089	.6478	.7421	.6154	.8326	.6219	.7762
5	.7087	.7621	.7964	.6584	.8688	.7316	.8686
6	.8859	.8764	.8596	.8779	.8775	.9145	.8962
7	.8131	.7316	.8869	.7964	.8596	.905	.8688
8	.695	.6584	.5973	.7602	.8688	.7796	.8059
9	.788	.6697	.6584	.7442	.7783	.7973	.7796
10	.6805	.6584	.6401	.6447	.7087	.7545	.7712
11	.6805	.6516	.5959	.591	.6733	.394	.7202
12	.6661		.5548	.6268	.6447	.5426	.6588
13	.6859	.5853	.5487	.6335	.6447	.6068	.6485
14	.6668	.6219		.6335	.6379	.6068	.6068
15	.4508	.6401	.5201	.6154	.6379	.6135	.6068
16	.6478	.5792	.6173	.5487	.631	.6588	.6415
17	.6287	.5792	.6935	.7682	.631	.6762	.6516
18	.724	.5973	.815	.7865	.6588	.6613	.7545
19	.8764	.8869	.9134	.8688	.9313	.7975	.8859
20	.9907	.8869	.8505	.9955	.8954	.8059	.8954
21	.8383	.8145	.7442	.8596	.7522	.8145	.8775
22	.724	.6878	.6447	.7343	.6447	.8145	.7964
23	.6478	.6154	.5731	.6878	.5731	.7522	.6805
24	.6447	.5525	.6219	.567	.6805	.5731	.6268
Max	.9907	.8869	.9134	.9955	.9313	.9145	.8962
Min	.4508	.5335	.5201	.5487	.5731	.394	.5121
Avg	.6993	.6662	.6912	.6975	.7379	.6902	.7241

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194023 / 33/11 IEETKAL S/S

Feeder No / Name : 204 / 11 KV VAISHNODEVI FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3429	.2286	.3429	.4382	.4191	.381
2	.3048	.3429	.3048	.3429	.4191	.4191	.3429
3	.3048	.3429	.3048	.3429	.381	.4191	.3429
4	.3048	.3429	.3429	.3429	.381	.4191	.3429
5	.381	.2858	.362	.3429	.4191	.4191	.381
6	.381	.2477	.362	.3429	.4382	.4191	.381
7	.3429	.3048	.4001	.3429	.3239	.381	.3429
8	.2667	.2858	.4191	.2667	.2858	.3429	.3429
9	.3048	.3048	.381	.1905	.2477	.3429	.362
10	.3429	.2286	.3239	.1905	.3429	.3048	.381
11	.362	.3239	.3048	.2286	.4191	.1905	.4191
12	.362	.2858	.2667	.2477	.3048	.1905	.4191
13	.381	.2858	.2667	.2477	.3048	.1905	.4191
14	.4572	.2858	.2667	.3239	.3429	.4191	.362
15	.4382	.1715	.1524	.362	.381	.4191	.3048
16	.4572	.1715	.1905	.4001	.3429	.4191	.3048
17	.4191	.1715	.2667	.2858	.3429	.381	.2667
18	.3429	.2477	.1905	.2096	.381	.4191	.381
19	.4191	.3048	.1905	.2286	.4572	.5144	.3048
20	.4763	.3239	.2286	.2477	.381	.5144	.3429
21	.4382	.3239	.2286	.2858	.381	.381	.3239
22	.381	.3239	.1905	.3239	.381	.381	.3048
23	.381	.2667	.1905	.3429	.381	.381	.3239
24	.3048	.2858	.2096	.3048	.4382	.4191	.381
Max	.4763	.3429	.4191	.4001	.4572	.5144	.4191
Min	.2667	.1715	.1524	.1905	.2477	.1905	.2667
Avg	.3691	.2834	.2739	.2953	.3715	.3794	.3524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194029 / 33 KV TAMALWADI S/S

Feeder No / Name : 201 / 11 KV TAMALWADI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6226	.407	.8333	.8535	.9114	.9945	.9717
2	.6478	.407	.8436	.9717	.9465	1.073	1.0277
3	.6962	.4748	.9488	1.0364	.9259	1.1401	1.0688
4	.7773	.4748	.9804	1.1271	.9945	1.153	1.1336
5	.8288	.5426	1.0562	1.1203	.9835	1.1869	1.1934
6	.8745	.6344	1.166	1.1203	1.1191	1.2689	1.1984
7	.9069	.7461	1.2631	1.1984		1.3717	1.2929
8	.9945	.7888	1.3603	1.3603	1.2689	1.406	1.2742
9	.8288	.6773	1.326	1.3717	1.2887	1.4255	1.2308
10	.8817	.6401	.5121	.6104	.4115	.6554	.6802
11	1.2003	.9602	.7125	.7122	.6516	.7773	.7625
12	1.5091	1.0936	.6882	.9259	.9259	.6802	.7956
13	1.4403	1.0936	.583	1.0174	.9362	.7682	.759
14	1.3565	1.0936	.4801	1.0288	.8669	.7865	.7625
15	1.3565	1.0936	.421	.9945	.8573	.8097	.7625
16	1.3565	1.0936	.7537	.9991	.823	.8192	.7956
17	1.3904	1.0936	.6958	.9835	.823	.8322	.852
18			.0754	.0686	.0686	.0739	
19	.0671	.0724	.0747	.0678	.0686	.0732	
20	.0678	.0724	.0739	.0678	.0686	.0739	
21	.0678	.0739	.0747	.0678	.0678	.0739	.0739
22	.0678	.0739	.0747	.0678	.0678	.0747	.0739
23	.0678	.0739	.0747	.0678	.0686	.0747	.0739
24	.583	.3429	.7926		.823	.8619	.8951
Max	1.5091	1.0936	1.3603	1.3717	1.2887	1.4255	1.2929
Min	.0671	.0724	.0739	.0678	.0678	.0732	.0739
Avg	.8083	.6097	.6610	.7756	.6942	.7689	.8418

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194029 / 33 KV TAMALWADI S/S

Feeder No / Name : 202 / INDUSTRIAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1017	.0724	.1029	.1017	.0995	.1029
2	.1029	.1017	.0724	.1029	.1029	.1006	.1029
3	.1029	.1017	.0724	.1296	.1017	.1006	.1029
4	.1029	.1017	.0716	.1296	.1029	.1006	.1029
5	.1029	.1029	.0724	.1029	.1187	.1017	.1029
6	.1029	.1017	.0724	.1296	.1187	.1017	.1296
7	.1296	.1017	.1372	.1296	.1187	.1017	.1296
8	.1296	.0848	.1372	.1296	.1187	.1017	.1296
9	.1524	.0876	.1524	.1696	.1187	.1296	.1296
10	.1696	.0876	.1524	.2035	.1357	.1524	.1524
11	.1696	.0724	.1524	.2035	.2058	.2	.1524
12	.2035	.0724	.2347	.2035	.2058	.1524	.176
13	.2058	.0724	.176	.2035	.2374	.1219	.1524
14	.1696	.0724	.176	.2035	.2058	.0972	.176
15	.1696	.0724	.176	.1696	.2401	.1219	.1524
16	.1715	.0724		.1715	.2035	.1296	.1524
17	.1357	.0724	.1296	.2058	.2035	.1296	.176
18	.1017	.0724	.1174	.2035	.1357	.1296	.176
19	.1017	.0724	.1174	.2035	.1341	.1029	.1524
20	.1029	.0724	.0972	.1696	.1341	.1029	.1524
21	.1017	.0724	.0972	.1372	.0995	.1029	.1296
22	.1029	.0724	.0972	.1357	.0995	.1029	.1296
23	.1017	.0724	.0972	.1372	.0995	.1029	.1296
24	.1029	.1017	.0724	.1296	.1017	.0995	.1029
Max	.2058	.1029	.2347	.2058	.2401	.2	.176
Min	.1017	.0724	.0716	.1029	.0995	.0972	.1029
Avg	.1308	.084	.1197	.1586	.1435	.1161	.1373

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194029 / 33 KV TAMALWADI S/S

Feeder No / Name : 203 / 11 KV TAMALWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5948	.5472	.5346	.5738	.5282	.532	.5049
2	.5861	.5068	.5289	.6005	.5205	.5057	.4995
3	.5487	.5007	.5319	.6002	.5163	.5079	.5323
4	.5601	.5015	.5712	.5658	.5194	.5434	.5418
5	.6627	.6329	.6146	.586	.6477	.599	.5967
6	.7971	.7258	.8668	.7937	.7762	.8482	.7267
7	.737	.7591	.8161	.8116	.7883	.799	.7506
8	.6863	.7296	.7023	.6981	.6961	.679	.6619
9	.6268	.6886	.6409	.5719	.5876	.6569	.652
10	.6017	.6756	.6569	.7316	.5712	.6615	.6486
11	.6626	.6402	.6264	.7163	.5929	.6695	.655
12	.5788	.6515	.6726	.6824	.5792	.6253	.6455
13	.5606	.6169	.623	.0038	.5929	.586	.6295
14	.5769	.5476	.5815	.6611	.5766	.6272	.644
15	.5636	.5308	.5483	.599	.5903	.6017	.6272
16	.6101	.6303	.5548	.5746	.6124	.6181	.6402
17	.6889	.6828	.6638	.6752	.6931	.7243	.6641
18	.8513	.7773	.7323	.6866	.7125	.7857	.7552
19	.8333	.8143	.7617	.8059	.7197	.8001	.7948
20	.8078	.8802	.8135	.7914	.8527	.7808	.8119
21	.815	.8131	.7629	.7407	.7956	.7167	.7328
22	.7144	.7376	.6809	.7133	.7567	.6809	.6718
23	.6992	.6344	.6409	.6131	.6646	.5826	.6169
24	.6474	.5875	.567	.6024	.6165	.5517	.5285
Max	.8513	.8802	.8668	.8116	.8527	.8482	.8119
Min	.5487	.5007	.5289	.0038	.5163	.5057	.4995
Avg	.6671	.6588	.6539	.6416	.6461	.6535	.6472

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194042 / 33/11 SALAGARA SUBSTAION

Feeder No / Name : 201 / 11 KV SALGARA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4755	.5792	.5792		.6878	.6516	.695
2	.4572	.5792	.5792		.724	.6878	.695
3	.4938	.5784	.6335		.7783	.724	.7316
4		.5973	.6516		.8688	.7602	.7499
5			.6516		.9412	.7964	.9877
6			.905		1.0679	1.086	1.0974
7			1.0679		1.1403	1.2127	1.1706
8			1.1222		1.1403	1.0679	1.0974
9			1.0498		1.086		
10		.905					
11	.9412	1.0498					
12	.9231	1.0136					
13	.9412	.9955					
14	.905	.9412					
15	.905	.9231					
16	.9774	1.0136	.4024	.3982	.5068	.3292	.4525
17	.9412	.6335		.5068	.5249		.4706
18	.543	.5792		.5973	.5611		.543
19	.5434	.6878		.6878	.5611	.6401	.724
20	.5792	.6335		.6697	.8326	.7865	.7964
21	.6335	.6154		.6878	.724	.7316	.724
22	.5792	.543		.5611	.6516		.6516
23	.543	.543		.4887	.6516		.543
24	.4938	.543	.5792		.6335	.6516	.3658
Max	.9774	1.0498	1.1222	.6878	1.1403	1.2127	1.1706
Min	.4572	.543	.4024	.3982	.5068	.3292	.3658
Avg	.6986	.7344	.7474	.5747	.7823	.7789	.7350

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194042 / 33/11 SALAGARA SUBSTAION

Feeder No / Name : 203 / 11 KV DEVSINGA TUL SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	.7059	.2534		.2534	.2534	.2743
2		.724	.2534		.2534	.2534	
3		.7602	.2534		.2534	.2715	.2561
4	1.2803	.7964			.2534		
5	1.7375	1.4118					
6	1.9204	1.448					
7	1.9753	1.7013	.2534				
8	1.829	1.6651					
9	1.5364	1.6289					.2561
10				.7421	1.1946	1.3535	
11				1.7194	1.6289	1.6644	1.7737
12				1.8099	1.7737	1.6095	1.7013
13				1.828	1.7194	1.6461	1.5565
14				1.8823	1.6289	1.6461	1.4842
15					1.5746	1.6644	1.448
16	.1448	.1086		1.4118	1.6289	1.6827	1.4118
17		.2896		1.5203	1.5927		1.5565
18		.3258		.181	.2172		.1086
19	.3258	.362		.3258	.2172		.1448
20	.3361	.362		.2896	.4706	.4755	.3258
21		.3258		.3258	.362	.2926	.2896
22	.3258			.3628	.3258		.2715
23	.2896	.2534		.2896	.2715	.2743	.2534
24	.6401	.6878	.2534		.2534	.2534	
Max	1.9753	1.7013	.2534	1.8823	1.7737	1.6827	1.7737
Min	.1448	.1086	.2534	.181	.2172	.2534	.1086
Avg	1.0126	.7974	.2534	.9760	.8354	.9529	.8195

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194042 / 33/11 SALAGARA SUBSTAION

Feeder No / Name : 204 / 11 KV WADGAON DEV SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2715	.6335		.5792	.6335	.5853
2	.2926	.2896	.6335		.7059	.6878	.7316
3	.2743	.2896	.6878		.724	.724	.7682
4		.2896	.7421		.7602	.8145	.8596
5			1.1765		.9593	.8869	1.2254
6			1.267		1.3575	1.267	1.2803
7			1.4842		1.5203	1.4118	1.4632
8			1.4842		1.4883	1.267	1.5364
9			1.267		1.3575		
10		.8326					
11	1.1946	1.3394					.1357
12	1.1946	1.3756					.1187
13	1.1765	1.3575					
14	1.2127	1.3937					
15	1.2489	1.4118					
16	1.3937	1.2489		.1629	.181	.128	.1187
17	1.3394	1.2127		.1991	1.9909		.1357
18	.1991	.2172		.2353	.1991		.1865
19	.3077	.3258		.3801	.2715		.2713
20	.2896	.3258		.362	.3258	.3475	.3222
21	.2896	.2896		.3801	.3258	.2926	.2883
22	.2896	.2896		.3174	.2715		.2713
23	.2715	.2896		.2353	.2715	.2926	.2543
24	.2743	.2715	.5792		.5792	.5611	.2743
Max	1.3937	1.4118	1.4842	.3801	1.9909	1.4118	1.5364
Min	.1991	.2172	.5792	.1629	.181	.128	.1187
Avg	.7030	.7011	.9955	.2840	.7705	.7165	.5698

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194042 / 33/11 SALAGARA SUBSTAION

Feeder No / Name : 205 / 11 KV GANDHORA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2378	.2092	.5611		.6154	.724	.6219
2	.2378	.2172	.5792		.6154	.7602	.7316
3	.2195	.2172	.5973		.6878	.7602	.7316
4		.2172	.8145		.724	.7964	.8048
5			.8145		.8238	.8326	.9511
6			1.0679		1.0631	1.1765	1.0059
7			1.0679		1.4118	1.3213	1.134
8			1.1765		1.3394	1.1584	1.1888
9			1.0317		1.2269		
10		.7964					
11	1.0136	1.086					
12	1.0136	1.086					
13	1.0136	1.0679					
14	1.0136	1.0498					.1696
15	.9955	1.0498					.1526
16	.9955	1.1222		.1629	.0724	.1646	.2035
17	.9774	1.0136		.2715	.2353		
18	.2353	.2896		.3258	.2715		.2883
19	.3506	.3982		.3982	.4525		.4239
20	.3856	.3982		.4706	.4706	.5121	.4578
21	.3982	.3439		.4706	.4706	.5121	.373
22	.362	.3439		.3439	.362		.3391
23	.3258	.5611		.2896	.362	.4024	.2713
24	.2195	.2172	.5611		.5847	.6878	.4938
Max	1.0136	1.1222	1.1765	.4706	1.4118	1.3213	1.1888
Min	.2195	.2092	.5611	.1629	.0724	.1646	.1526
Avg	.5879	.6150	.8272	.3416	.6550	.7545	.5746

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194042 / 33/11 SALAGARA SUBSTAION

Feeder No / Name : 206 / 11 KV KILAJ SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.7602	.3258		.3258	.3258	.3292
2	.695	.7602	.3258		.3258	.3258	.2743
3	.8048	.7964	.3258		.3258	.3258	.2926
4	.8596	.8326			.3439		
5	1.2437	1.1222					
6	1.4266	1.267					
7	1.4632	1.4842					
8	1.3717	1.307					
9	1.0974	1.2308					
10				.6878	.905	.8048	
11				1.1584	1.086	.8413	.6783
12				.905	1.1403	.8779	.8987
13				1.0679	1.086	.9511	1.1191
14				1.086	1.0498	.9328	1.0682
15				1.1222	1.0317	.9511	1.0174
16	.1991	.3077		1.1765	1.1041	.9145	.8309
17	.2715	.3077		1.1946	1.2489		1.1869
18	.2715	.3258		.2353	.2715		.1865
19	.4525	.4163		.4706	.4525		.4409
20	.4163	.4163		.4706	.4887	.4908	.4917
21	.4163	.3982		.362	.4525		.4239
22	.362	.362		.3439	.362	.4024	.3391
23	.7059	.362		.3439	.3258	.3475	.3052
24	.3658	.7059	.3439		.3258	.3258	.3109
Max	1.4632	1.4842	.3439	1.1946	1.2489	.9511	1.1869
Min	.1991	.3077	.3258	.2353	.2715	.3258	.1865
Avg	.7206	.7313	.3303	.7589	.6659	.6298	.5996

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194043 / 33/11 KV SAWARGAO S/S

Feeder No / Name : 201 / 11 KV GANJEWADI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3336	1.4098		.0953		.0103
2	1.4289	1.4861		.0953		.0103
3	1.4289	1.5242		.0953		.0137
4	1.5242	1.5623		.0953		.0154
5	1.6194	1.6004		.0953		.0171
6	1.7147	1.6194		.1905		.0171
7	1.7147	1.6766		.1905		.0137
8	1.8099	1.7147		.0953		.0137
9	1.9052	1.6766				.0103
10	.1905	.0762				.1063
11	.0953	.0762				.1372
12	.0953	.0762	.144			.1457
13	.0953		1.6194		.1646	1.5242
14	.1143		1.7147		.1663	1.5242
15	.0953		1.6194		.168	1.4289
16	.1143		1.7147		.1663	1.4289
17	.1143		1.7147		.1578	1.3336
18	.1905		.0953		.0086	.0953
19	.1905		.1905		.0137	
20	.1905		.1905		.0154	.1905
21	.1524		.0953		.0171	.1905
22	.1524		.0953		.0154	.0953
23	.1143	.0137	.0953		.0137	
24	1.3336		.0137	.0953		.0137
Max	1.9052	1.7147	1.7147	.1905	.168	1.5242
Min	.0953	.0137	.0137	.0953	.0086	.0103
Avg	.7383	1.1163	.7156	.1165	.0824	.3789

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194043 / 33/11 KV SAWARGAO S/S

Feeder No / Name : 202 / 11 KV SAWARGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381		1.8099		.1663
2	.381	.381		1.9052		.168
3	.381	.5716		2.0957		.18
4	.5716	.724		2.2862		.1852
5	.7621	.7621		2.2862		.1886
6	.7621	.7621		2.3815		.1955
7	.5716	.6097		2.6673		.2486
8	.4763	.5716		2.7625		.2383
9	.381					.2212
10						.0343
11	2.3815	2.5149				.0343
12	2.4768	2.7054	.0223			.0274
13	2.0005		.2858		.0309	.2858
14	2.2481		.2858		.0309	.2858
15	2.5149		.2858		.0291	.2858
16	2.4387				.0291	.2858
17	2.4768		.2858		.0291	.381
18			.5716		.0583	.381
19	.6097		.7621		.0617	.6668
20	.8573		.8573		.0566	.8573
21	.8573		.8573		.048	.8573
22	.7621		.7621		.036	.7621
23	.5335	.0549	.6668		.0377	
24	.4954		.1595	1.8099		.1646
Max	2.5149	2.7054	.8573	2.7625	.0617	.8573
Min	.381	.0549	.0223	1.8099	.0291	.0274
Avg	1.1509	.9126	.4835	2.2227	.0407	.3087

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194043 / 33/11 KV SAWARGAO S/S

Feeder No / Name : 203 / 11 KV WADGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0957	2.2862		.381		.0291
2	2.3815	2.6292		.381		.0291
3	2.3815	2.6673		.381		.0343
4	2.6673	2.7435		.381		.048
5	3.0483	2.7435		.4763		.0514
6	3.2388	2.7435		.5716		.0583
7	3.3341	2.6673				.0446
8	2.9531	2.6673		.381		
9	2.8578	2.7435				
10	.2858	.2667		.5716		.2281
11	.2858	.3048				.2538
12	.2858	.3048	.2949			.2641
13	.2858		3.2388		.3018	2.6673
14	.3048		3.2388		.2949	2.572
15	.3048		3.0483		.3018	2.6673
16	.3048		3.1436		.2829	2.4768
17	.3429		2.9531		.2726	2.3815
18	.4954		.2858		.024	.381
19	.5335		.5716		.048	.4763
20	.5335		.6668		.0412	.5716
21	.5716		.5716		.0412	.5716
22	.4954		.4763		.0343	.4763
23	.4191	.0394	.381		.0326	
24	2.0005		.036	.381		.0291
Max	3.3341	2.7435	3.2388	.5716	.3018	2.6673
Min	.2858	.0394	.036	.381	.024	.0291
Avg	1.3503	1.9082	1.4544	.4339	.1523	.7767

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194043 / 33/11 KV SAWARGAO S/S

Feeder No / Name : 205 / 11 KV KEMWADI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905		1.1431		.1337
2	.1905	.2286		1.5242		.1372
3	.1905	.2667		1.7147		.1457
4	.2858	.3048		1.7147		.168
5	.4763	.3429		1.9052		.1852
6	.381	.3429		2.0957		.1989
7	.381	.3048		2.2862		.2006
8	.2858	.2667		2.2862		.192
9	.1905	.1905				.1835
10	1.7147	1.5242				.0206
11	2.2862	2.0957				.0206
12	2.0005	1.9814	.0137			.0206
13	1.5242		.1905		.0206	.1905
14	2.2862		.1905		.0309	.1905
15	2.4768		.1905			.1905
16	2.2862		.1905		.0343	.1905
17	2.2862		.1905		.0343	.1905
18	.381		.1905		.0377	.2858
19	.4763		.4763		.0412	.381
20	.381		.4763		.0412	.381
21	.381		.4763		.0446	.381
22	.3048		.381		.0309	.2858
23	.2286	.024	.2858		.0223	
24	.1905		.1149	.4763		.1303
Max	2.4768	2.0957	.4763	2.2862	.0446	.381
Min	.1905	.024	.0137	.4763	.0206	.0206
Avg	.9073	.6203	.2590	1.6829	.0338	.1915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194045 / 33/11 KV BORAGAO SUB STATION

Feeder No / Name : 201 / 11 KV HANGARGA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.7147	1.6289	.5487	.5658	.5658	.6001
2	1.326	1.6289	1.6289	.5487	.5487	.583	.6516
3	1.2651	1.5261	1.6118	.5487	.5658	.5658	.6001
4	1.2498	1.4403	1.5775	.5144	.5658	.5487	.5487
5			1.869	1.8004	1.8861	1.7147	1.5432
6			2.0233	2.0233	1.9547	2.1434	1.2803
7			2.1776	2.1434	2.3148	2.2291	2.2291
8			1.6118	2.3148	2.4691	2.1434	2.4863
9			1.9547	2.2291	2.3834	2.0576	2.4006
10			2.0062	2.1605	2.2462	1.9204	2.1948
11	.4801	.4458	1.9719	2.1948	2.0576	2.0576	2.2634
12	.4287	.3772	1.8347	2.0576	1.8861	2.0062	2.1948
13	.3944	.3601					
14		.3601					
15	.3944	.3601					
16	.3772	.3772					
17	.4115	.4458					
18	.5487	.5658					
19	.6001	.6516	.6859	.5658	.6859	.6859	.7373
20	.7545	.7373	.7888	.6344	.7888	.8402	.6687
21	1.9719	1.9204	.6859	.6687	.6516	.7202	.7202
22	1.9033	1.8519	.6001	.6344	.6001	.6516	
23	1.8004	1.7833	.5144	.6001	.583	.6001	.5487
24	1.448	1.7833	1.6461	.5144	.583	.5487	
Max	1.9719	1.9204	2.1776	2.3148	2.4691	2.2291	2.4863
Min	.3772	.3601	.5144	.5144	.5487	.5487	.5487
Avg	.9839	1.0183	1.4899	1.2612	1.2965	1.2546	1.3542

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194045 / 33/11 KV BORAGAO SUB STATION

Feeder No / Name : 202 / 11 KV SINDGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4877	.5144	.5144	3.0864	2.8292	2.915	2.9492
2	.5182	.5144	.4801	3.1207	2.5892	2.8292	2.915
3	.5335	.5487	.4458	3.0007	2.5377	2.9492	2.8807
4	.5335	.5487	.4458	2.7435	2.452	2.915	2.8292
5	.5792	.583					.4287
6	.5487	5.7442					.6001
11			.3429	.3601	.3429	.3772	.3944
12				.2915	.3944	.4115	.3944
13	3.2922	3.1379	.3772		.3772	.4287	.3944
14	3.4294	3.0178	.3944	.3429	.3429	.4458	.3772
15		3.4294	.3772	.3258	.4115	.4287	.3601
16		3.275	.3772	.3429	.4287	.4115	.3429
17	3.3951		.4115	.3944	.4287	.4287	.3772
18	3.155	3.1379	.4287	.4287	.4287	.4287	.3429
19	3.0693	2.9664	.5144	.5658	.5144	.6001	.6344
20	2.9492	2.7435	.6344	.6859		.6859	.6516
21	.6516	.6001	3.2579	3.1722	3.2579	3.2579	3.2579
22	.6687	.6001	3.0864	3.0864	3.1722	3.1722	3.275
23	.5144	.5658	3.0864	3.0007	3.0864	3.0864	3.1722
24	.4725	.583	.5658	***	2.9321	3.0007	2.9835
Max	3.4294	5.7442	3.2579	30.0069	3.2579	3.2579	3.275
Min	.4725	.5144	.3429	.2915	.3429	.3772	.3429
Avg	1.5499	1.9124	.9259	3.2327	1.5604	1.5985	1.4781

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194051 / 33/11 KV HORTI SUBSTATION

Feeder No / Name : 201 / 11 KV HORTI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2622	.333	.394	.2949	.3113	.3258	.2713
2	.3018	.3721	.4344	.3018	.3052	.3189	.3018
3	.3277	.3982	.4755	.3391	.3052	.3109	.3277
4	.3688	.439	.5068	.3887	.3561	.362	.3932
5	.3932	.4706	.5487	.5243	.4031	.4207	.4588
6	.5407	.499	.6099	.5571	.4207	.4748	.5243
7	.4694	.4706	.5611	.5243	.426	.4424	.5571
8			.5373	.57	.3856	.4733	.5365
9		.3856	.4075	.4588	.3506	.4409	.4096
10	.3189	.3467	.3932	.3277	.3155	.3506	.3856
11	.2915	.2572	.3185	.2804	.2572	.2785	.3467
12			.2622	.2601	.2427	.2683	.3258
13			.2622	.2279	.2454	.2622	.2883
14			.213	.2401	.2229	.213	.218
15	.25	.3222	.1677	.2534	.2658	.2458	.2429
16	.2688	.3429	.1966	.2279	.2774	.2785	.2785
17	.3086	.3814	.2294		.333	.2949	.3315
18	.3641	.4031	.3277	.3077	.4252	.3856	.3521
19	.543	.5373		.3641	.2279	.503	.5083
20	.5611	.5138	.5735	.4207	.4557	.4588	.5201
21	.4755	.4382	.4191	.3944	.4161	.3239	.3185
22		.3544	.3688	.3772	.3681	.3222	
23	.362	.3681		.3429	.3391	.3018	.3052
24	.2683	.3121	.3544	.3018	.2949	.3155	.285
Max	.5611	.5373	.6099	.57	.4557	.503	.5571
Min	.25	.2572	.1677	.2279	.2229	.213	.218
Avg	.3709	.3973	.3892	.3602	.3313	.3488	.3690

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194051 / 33/11 KV HORTI SUBSTATION

Feeder No / Name : 202 / 11 HORTI AG FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2955	1.4243	1.7976	1.6766	.1638	1.8842	1.6385
2	1.3108	1.4251	1.8233	1.6385	.1823	2.0687	1.8023
3	1.3108	1.4746	1.9334	1.7204	.1753	2.1293	1.8351
4	1.4091	1.5061	1.8461	1.8023	.1844	2.1052	1.8842
5		1.5203	1.7924	1.8351	.1715	2.1052	2.0119
6		1.5708	1.7652	1.8351	.1715	2.2382	2.2119
7			1.7328	1.8442	2.0348	1.3603	2.2119
8			1.6484	1.6385	1.8861	1.4251	1.9662
9			1.439	1.4746	1.643	1.5432	1.4746
10			1.5238	1.5089	1.4918	1.4737	1.3108
11			1.5729	1.4754	1.3763	1.4419	1.3603
12	.2774		1.6385	1.4918	1.3108	1.5074	1.3923
13	.2572		1.4746	1.4746	1.4413	1.4746	1.4232
14	.2427		1.5074	1.491	1.4243	1.5089	1.4548
15	1.866	1.7185					
16	1.9524	1.8027					
17	2.0243	2.0005					
18	2.0645	1.9826					
19	1.9216	1.9559					
20	1.9204	1.8842					
21	1.9271	1.8299					
22		1.8278					
23	1.3441	1.8027	1.5089	1.4752	1.7318	1.6385	1.7711
24		1.3592	1.8404	1.6766	1.5939	1.8404	1.8442
Max	2.0645	2.0005	1.9334	1.8442	2.0348	2.2382	2.2119
Min	.2427	1.3592	1.439	1.4746	.1638	1.3603	1.3108
Avg	1.4083	1.6928	1.6778	1.6287	1.0614	1.7341	1.7246

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194051 / 33/11 KV HORTI SUBSTATION

Feeder No / Name : 203 / 11 KV MURTA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	1.8023	1.6842					
8	1.2452						
9		1.7078					
10	1.7004	1.7185					
11	1.7764	1.8185					
12	1.8785						
13	1.8724						
14	1.8185						
15				1.8991	2.1209	1.8842	1.7328
16			.9831		2.0576	2.0622	1.7814
17				1.9765	2.2192	2.1795	1.8027
18			1.1469		1.9989	2.1052	1.8122
19				1.7204	2.0056	1.8842	1.9109
20			1.5729	1.6876	1.8461	2.13	1.8404
21			1.5729	1.4582	1.7814		1.7869
22			1.5729	1.2323	1.7078	1.9281	1.7341
Max	1.8785	1.8185	1.5729	1.9765	2.2192	2.1795	1.9109
Min	1.2452	1.6842	.9831	1.2323	1.7078	1.8842	1.7328
Avg	1.7277	1.7323	1.3697	1.6624	1.9672	2.0248	1.8002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194076 / 33/11 KV YEOTI SUB STATION

Feeder No / Name : 201 / 11 KV NANDURI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7109	.638	.2452	.2286		.1713	
2	.7774	1.0829	.2452	.2286		.1757	.1886
3	.8749	1.1203	.2452	.2286		.2222	.1512
4	.9328	1.1763	.2829	.2286		.2513	.1513
5	1.0175	1.1763	.3018			.3278	.189
6	1.0447		.3388	.3426		.3262	.1892
7	1.0674	.9456	.3388	.1521		.3262	.1509
8		1.3687	.1524	.1331	.1387	.3024	.1457
9	.9378	1.3345			.1387	.2646	.1451
10	.1892	.0762	.7545	.7279	1.1096	1.037	.4769
11	.1795		.8962		1.5927	.8299	.8752
12			1.0306		1.6095	.9481	1.0718
13	.189	.1715	1.0065			1.0596	.9707
14	.1795	.1905	.9953		1.5775	1.0888	1.0082
15		.1905	.9919		1.5432	1.12	.9087
16	.1704					1.0519	.9825
17	.1892	.1703			.9328	.9422	.9831
18	.2477	.2263				.1512	.8341
19	.3048	.2729				.189	
20		.2689	.1711			.2268	.2665
21	.2667	.251				.2641	.2566
22	.2665	.2282	.1507			.3015	
23	.2464	.2263	.2286			.3027	.2809
24	.5281	1.0552		.2286		.1631	.189
Max	1.0674	1.3687	1.0306	.7279	1.6095	1.12	1.0718
Min	.1704	.0762	.1507	.1331	.1387	.1512	.1451
Avg	.5160	.6085	.4927	.2776	1.0803	.5018	.4960

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194076 / 33/11 KV YEOTI SUB STATION

Feeder No / Name : 202 / 11 KV KATGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1509	.0838		.1299	.1457
2			.1509	.0838		.1299	.2177
3			.1677	.2014		.1648	.2499
4			.1677	.2347		.2597	.2804
5			.2707	.235		.2946	.3083
6			.3018	.3525		.3414	.3387
7			.3189			.3246	.3701
8			.2182	.3353	.3467	.3262	.2922
9					.4334	.3052	.2898
10	.2323	.2515					
11	.3517						
13	.3349	.285					
14	.3349	.3185					
15		.3185					
16	.3185						
21	1.432						
24			.1341	.0838		.0979	.1129
Max	1.432	.3185	.3189	.3525	.4334	.3414	.3701
Min	.2323	.2515	.1341	.0838	.3467	.0979	.1129
Avg	.5007	.2934	.2090	.2013	.3901	.2374	.2606

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194076 / 33/11 KV YEOTI SUB STATION

Feeder No / Name : 203 / 11 KV ARALI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8989	.7146	.8954	.8509		.848	1.0867
2	.9364	.7267	.9902	.9282		.9133	1.1789
3	.9768	.7453	1.0951	.9282		1.0928	1.1989
4	1.0895	.8385	1.1864	.9614		1.1783	1.4323
5	1.1283	.913	1.3176	.9774		1.3747	1.658
6	1.167	1.1799	1.4118	1.4311		1.4553	1.7873
7	1.0594	1.1117	1.6393			1.5908	1.7496
8			1.2813	1.7493	1.595	1.4163	1.6347
9	.5788			1.1979	1.595	1.3468	1.6709
10	.6048	1.2748	.4277	.6465	.5895	.64	.3588
11	1.4553		.4242		.4359	.6048	
12			.4057		.4191	.5704	.3262
13	1.3529		.4467			.5281	.3756
14	1.1741	1.3567	.484		.4801	.5287	.3896
15		1.2832	.4053		.463	.5653	.424
16	1.2025				.424	.6048	.4609
17		1.1079			.424	.6426	.476
18	1.1801	.6775				.679	.0845
19	.9402	1.0553				1.0973	.9743
20		1.0458	1.1871			1.1588	.9562
21	1.3785	1.0268				1.1901	.9562
22	1.0363	.7164	.8937			1.1111	
23	.8176	.7701	.8441			.964	.7922
24	.9355	.6894	.8775	.9496		.8451	1.0413
Max	1.4553	1.3567	1.6393	1.7493	1.595	1.5908	1.7873
Min	.5788	.6775	.4053	.6465	.4191	.5281	.0845
Avg	1.0480	.9574	.9007	1.0621	.7140	.9561	.9551

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194076 / 33/11 KV YEOTI SUB STATION

Feeder No / Name : 204 / 11 KV YEOTI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6783	.4899		.3768		.2963	.3768
2	.7167	.5653	.3803	.3768		.2936	.3392
3	.7922	.5653	.4753	.3768		.3288	.3392
4	.9421	.5647	.4753	.4334		.3754	.3768
5	1.0552	.6595	.5704	.4334		.4561	.4522
6	1.0929	.9798	.5841	.5087		.487	.5276
7	1.1305	1.1117	.5464	.4711		.487	.4894
8			.4899	.4711	.4334	.4522	.4077
9	.8479	.716			.3467	.3757	
10	.2638	.245	.7349	.6406	.5201	.677	.7792
11	.7725		.9044		.8048	.8668	.7718
12			.9044		.788	.9044	.7142
13	.2261	.2092				.9421	.7142
14	.4145	.1882	.8102		.703	.9044	.6818
15		.2261	.8102		.6859	.8668	.6417
16	.245				.6523	.8291	.6866
17		.3042			.6523	.7914	.4785
18	.245	.3803				.3392	.2826
19		.5894				.4899	.4711
20	.5841	.3803				.5276	
21	4.9282	.4753				.603	.4711
22	.358	.3582	.4145			.5636	
23	.358	.3224	.3392			.4899	.3569
24	.603	.4899	.3395	.3392		.3033	.4145
Max	4.9282	1.1117	.9044	.6406	.8048	.9421	.7792
Min	.2261	.1882	.3392	.3392	.3467	.2936	.2826
Avg	.8555	.4910	.5853	.4428	.6207	.5688	.5130

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194081 / 33/11 KV KATI SUBSTATION

Feeder No / Name : 201 / 11 KV DAHIWADI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5087	.503	.5898	.5087	.4915
2			.5087	.5243	.6226	.5087	.4915
3			.5087	.5243	.6554	.5935	.4915
4			.5087	.5571	.7209	.5935	.6554
5			.5935	.5735	.7865	.6783	.7545
6			.6783	.9012	.852	.763	.9724
7			.763	.9503	.9175	.8478	.9389
8			.763	.8356	.8684	.8478	.9389
9			.763	.7537	.7701	.8192	.9724
10	.6706	.6783					
11	.9393	.9326					
12	.9717	.9326					
13	.9717	.8478					
14	.8907	.8478					
15	.9231	.8478					
16	.9555	.8478					
17	.9012	.763					
24			.5087	.4915	.5801	.5087	.4915
Max	.9717	.9326	.763	.9503	.9175	.8478	.9724
Min	.6706	.6783	.5087	.4915	.5801	.5087	.4915
Avg	.9030	.8372	.6104	.6615	.7363	.6669	.7199

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194081 / 33/11 KV KATI SUBSTATION

Feeder No / Name : 202 / 11 KV WANEWADI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0174	1.065	.5716	.4694	.4904	.5716	.3353
2	1.0174	1.1469	.5716	.4694	.4904	.5716	.3353
3	1.1869	1.2289	.5716	.503	.4904	.5716	.3353
4	1.1869	1.3927	.5716	.503	.5281	.5716	.3353
5	1.5261	1.4746	.6668	.5365	.5658	.6668	.4694
6	1.8652	1.6385	.6668	.5365	.5658	.6668	.5365
7	1.95	1.7814	.6668	.503	.5658	.6668	.5365
8	2.0348	1.9433	.6668	.4191	.4715	.6668	.4024
9	2.0348	1.8623	.5716	.4191	.3772	.4915	.3353
10	.2829	.2858	1.6385	1.4089	1.1869	1.1736	1.5432
11	.2829	.2858	1.7772	1.5565	1.7804	1.7604	1.7635
12	.2829	.2858	1.7101	1.6356	1.8652	1.9281	
13	.2641	.2858	1.6766	1.749	1.8652	1.9281	1.8143
14	.2641	.2858	1.5089	1.7204	1.7804	1.9281	1.8482
15	.2829	.2858	1.5089	1.704	1.6956	1.9281	1.8482
16	.3018	.2858	2.0119	1.8138	1.6956	2.0119	1.8143
17	.3018	.381	1.9448	1.8023	1.7804	2.0119	1.8652
18	.3206	.381	.3018	.3584	.381	.2683	
19	.415	.6668	.4694	.5281	.5716	.3353	.5093
20	.4904	.6668	.503	.5658	.6668	.4191	.6036
21	.5658	.6668	.6668	.6224	.6668	.503	.547
22	.6036	.6668	.503	.547	.6668	.5365	.4527
23	.5658	.5716	.4694	.5281	.5716	.503	.415
24	1.0174	1.0059	.5716	.4694	.4904	.5716	.503
Max	2.0348	1.9433	2.0119	1.8138	1.8652	2.0119	1.8652
Min	.2641	.2858	.3018	.3584	.3772	.2683	.3353
Avg	.8359	.8559	.9495	.8904	.9254	.9688	.8704

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194081 / 33/11 KV KATI SUBSTATION

Feeder No / Name : 203 / 11 KV KHUNTEWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.5335	.6783	.8192	.7209	.6783	.8192
2	.381	.5335	.6783	1.0174	.7865	.6783	.8192
3	.381	.4763	.6783	.9831	.852	.8478	.8383
4	.381	.5335	.8478	.9831	.9831	.8478	.9012
5	.381	.5716	.8478	1.3108	1.1142	1.0174	1.3413
6	.4763	.6097	1.0174	1.3927	1.2452	1.1869	1.5089
7	.4763	.6478	1.0174	1.4746	1.3279	1.2717	1.5089
8	.381	.4572	1.1022	1.3927	1.4089	1.2717	1.5089
9	.381	.4763	1.1022	1.4746	1.3599	1.1736	1.4251
10	1.1822	.8478	.3429	.4001	.1905	.381	.4763
11	1.3765	1.1869	.3429	.4382	.1905	.4191	.381
12	1.4251	1.1869	.381	.381	.1905	.381	
13	1.3927	1.1869	.3429	.381	.1905	.3429	.4382
14	1.3279	1.2717	.381	.362	.1905	.3429	.4191
15	1.2955	1.2717	.381	.4382	.1905	.3429	.4191
16	1.3765	1.1869	.381	.381	.1905	.3429	.4382
17	1.2955	1.0174	.381	.4191	.1905	.3429	.4572
18	.4382	.381	.381	.4954	.381	.381	
19	.5716	.381	.5716	.6097	.381	.5335	.6097
20	.6668	.381	.6668	.6859	.4763	.6097	.7811
21	.6668	.381		.6859	.4763	.6097	.743
22	.6478	.381	.6097	.6097	.381	.5716	.6859
23	.6287	.381	.5716	.5716	.381	.5716	.5906
24	.381	.5716	.6783	.6554	.6796	.6783	.7373
Max	1.4251	1.2717	1.1022	1.4746	1.4089	1.2717	1.5089
Min	.381	.381	.3429	.362	.1905	.3429	.381
Avg	.7622	.7022	.6253	.7651	.6033	.6594	.8113

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194082 / 33/11 KV SHAHAPUR SUBSTATION

Feeder No / Name : 201 / 11 KV SHAHAPUR AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1984	1.1405	.0324	.0312	.0312	.0312	.0312
2	1.2631	1.1873	.0324	.0312	.0312	.0312	
3	1.3765	1.3279	.0324	.0312	.0324	.0312	.0312
4	1.4575	1.4529					
5	1.7814	1.8903					
6	2.0243	1.8591					
7	2.1376	2.0622					
8	2.2834	2.0622					
9	1.9109	1.8903					
10			1.8122	1.781	1.9109	1.7654	1.9372
11			2.2028	2.17	1.8747	2.2653	2.234
12			2.0778	2.0729	2.2809	2.3746	2.0934
13			2.2184	2.1862	2.3278	2.2809	2.1715
14			2.2497	2.2348	2.1559	2.234	2.0778
15			2.2653	2.234	2.1247	2.2653	2.0153
16			2.2028	2.1715	1.9528	2.2965	2.1715
17			2.0309	2.1214	2.359	2.2497	2.2184
18	.0156	.0324	.0156	.0324	.0312	.0312	.0312
19	.0312	.0324		.0324	.0312		.0312
20	.0312	.0324	.0312	.0324	.0312	.0312	.0312
21		.0324	.0312	.0324	.0312	.0312	.0312
22	.0312	.0324	.0312	.0324	.0312	.0312	.0312
23	.0312	.0324		.0324	.0312		.0312
24	1.166	1.0936	.0324	.0312	.0324	.0312	.0312
Max	2.2834	2.0622	2.2653	2.2348	2.359	2.3746	2.234
Min	.0156	.0324	.0156	.0312	.0312	.0312	.0312
Avg	1.1160	1.0100	1.0812	.9606	.9612	1.1238	1.0118

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194082 / 33/11 KV SHAHAPUR SUBSTATION

Feeder No / Name : 202 / 11 KV SHAHAPUR GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4706	.4755	.2534	.4024	.3801	.3841	.3109
2	.4525	.4938	.2172	.439	.3887	.3658	.3292
3	.543	.4938	.1991	.4755	.4062	.4207	.4024
4	.5792	.5121	.2353	.5121	.4534	.439	.4207
5	.6154	.6401	.3801	.5853	.5182	.4755	.4024
6	.6516	.695	.4163	.6219	.583	.6036	.4938
7	.6516	.8048	.3077	.7316	.724	.6584	.2378
8	.6335	.7133	.543	.7499	.6878	.695	.2926
9	.5611	.6584		.7133	.6697	.7499	.2926
10	.362		.5853	.7133	.6154	.6401	.5853
11	.4163	.3439	.5487			.4755	.567
12	.4024		.1646		.4207	.5121	.1646
13	.3841	.2353	.2743	.1086	.439	.4755	.1097
14	.4024	.4706	.439	.1267	.439	.4755	.3841
15	.3658	.5068	.5121	.1086		.5121	.4938
16	.439	.4525	.5487			.567	.5121
17	.5121	.1991	.6401	.1991		.6036	.5487
18	.6219	.2353	.4755	.1991	.128	.3658	.3841
19	.695	.3439	.5487	.4525	.3292	.7133	.5853
20	.6584	.3258	.6584	.6516	.5304	.6584	.6584
21	.6401	.3077	.6219	.5611	.5304	.6219	.6219
22	.5487	.3077	.6036	.5068	.5121	.4938	.5304
23	.4938	.2715	.4207	.4525	.3658	.439	.4572
24	.5068	.439	.2172	.3841	.4163	.3658	.4024
Max	.695	.8048	.6584	.7499	.724	.7499	.6584
Min	.362	.1991	.1646	.1086	.128	.3658	.1097
Avg	.5253	.4512	.4266	.4617	.4769	.5296	.4245

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194082 / 33/11 KV SHAHAPUR SUBSTATION

Feeder No / Name : 203 / 11 KV DAHITANA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0312	.6802	.6562	.7449	.6718	.6718
2		.0312	.7287	.7343	.7773	.703	.7343
3		.0312	.7773	.8124	.8421	.7655	.7499
4			.8097	.7811	.8907	.7811	.7343
5			.8745	.9374	.9217	.7968	.7968
6			1.1012	.9998	1.0311	1.0623	1.0311
7			1.166	1.1248	1.3279	1.2654	1.1248
8			1.1336	1.1405	1.1336	1.0623	1.1717
9				1.1248	1.1012	.7499	1.0467
10	1.0364						
11	1.2631	1.2308					
12	1.2186	1.1174					
13	1.2498	1.2793					
14	1.2186	1.2146					
15	1.1873	1.2308					
16	1.1873	1.0688		.1296			
17	1.2186						
18	.0156	.0324	.0156	.0324	.0312		.0312
19	.0312	.0324	.0312	.0324	.0312	.0312	.0312
20	.0312	.0324	.0312	.0324	.0312	.0312	.0312
21		.0324	.0312	.0312	.0312	.0312	.0312
22	.0312	.0324	.0312	.0324	.0312	.0312	.0312
23	.0312	.0324		.0324	.0312		.0312
24		.0312	.6154	.5624	.6802	.6718	.6249
Max	1.2631	1.2793	1.166	1.1405	1.3279	1.2654	1.1717
Min	.0156	.0312	.0156	.0312	.0312	.0312	.0312
Avg	.7477	.4663	.5734	.5410	.6024	.6182	.5546

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194086 / 33/11 KV MANGRUL

Feeder No / Name : 201 / 11 KV KUMBHARI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6783	.724	.0509	.0339	.0362	.0362	.0339
2	.6952	.8145	.0509	.0339	.0362	.0362	.0339
3	.7042	.8688	.0509	.0339	.0362	.0362	.0339
4	.7291	.905	.0509	.0339	.0362	.0362	.0339
5	.763	.905				.0362	.0339
6	.8478	.9412					
7	.8817	1.0498					
8	.9221	1.086			.0362		
9		1.1222					
10			.7865	.9593	.9955	.6783	.8029
11			.9393	1.2851	1.0498	1.1022	.9717
12			.9831	1.3575	1.0679	1.0486	1.0978
13			.9831		1.1946	1.004	1.0486
14			.9667	1.267	1.1222	.9878	.9831
15			.9614	.905	1.1765	.9831	.9503
16			.9339	1.086	1.1041	.9175	.9995
17			.9156	1.267	1.0679	.9326	.9995
18	.0362	.1357	.0339	.0543	.0543	.052	
19	.0362	.0848	.0339	.0543	.0543	.0509	
20	.0362	.0086	.0339	.0543	.0543	.0509	
21	.0362	.0686	.0339	.0543	.0362	.0509	
22	.0362	.0678	.0339	.0543	.0362	.0509	
23	.0362	.0509	.0339	.0543	.0362	.0339	
24	.6371	.6335	.0509	.0343	.0362	.0362	.0339
Max	.9221	1.1222	.9831	1.3575	1.1946	1.1022	1.0978
Min	.0362	.0086	.0339	.0339	.0362	.0339	.0339
Avg	.4717	.5917	.4172	.4790	.4634	.4080	.5755

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194086 / 33/11 KV MANGRUL

Feeder No / Name : 202 / 11 KV MANGRUL AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0678	.0724	.5138	.5426	.724	.6878	.5967
2	.0678	.0724	.6443	.5636	.7964	.724	.5801
3	.0678	.0724	.6443	.6299	.8326	.724	.6299
4	.0848		.6952	.6962	.8688	.9593	.663
5			.7373	.7537	.905	.905	.7461
6			.8309	.8987	.9412	.905	.779
7			1.1022	1.3226		1.0498	1.1105
8			1.1022	1.2289		1.1765	1.0688
9			.9667	1.3213		1.1271	1.0442
10		.763					
11	1.0498	.8684					
12	.9955	.9667					
13	1.1765	.9779					
14	1.086	.9326					
15		.9389					
16	.9955	.9555					
17	.8688	.9835					
18	.0905	.1147	.1017	.0905	.0905	.1387	.1017
19	.0905	.1017	.1017	.0905	.0905	.1187	.1017
20	.0905	.1017	.1187	.1086	.0905	.1187	.1017
21	.0905	.1187	.1187	.1086	.0905	.1187	.1017
22	.0905	.1147	.1017	.0905	.0724	.1187	.1017
23	.0905	.1187	.1017	.0905	.0724	.1187	.1017
24	.0678	.0905	.4748	.5426	.6335	.6335	.5868
Max	1.1765	.9835	1.1022	1.3226	.9412	1.1765	1.1105
Min	.0678	.0724	.1017	.0905	.0724	.1187	.1017
Avg	.4159	.4647	.5222	.5675	.4776	.6015	.5260

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194086 / 33/11 KV MANGRUL

Feeder No / Name : 203 / 11 KV MANGRUL GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2883	.2353	.2713	.2883	.2715		.3052
2	.3391	.2715	.2713	.3052	.2896	.3077	.3052
3	.373	.3258	.2883	.3222	.3258	.3258	.3185
4	.407	.4163	.3222	.3561	.3982	.362	.3812
5	.4409	.4706	.3391	.373	.4344	.5068	.4748
6	.4239	.5068	.4239	.3353	.5068	.543	.5596
7	.4409	.2715	.3222	.3052	.4706	.2715	.1865
8	.4578	.3258	.3277	.3561	.4706	.2896	.2035
9		.2896	.3521	.4525		.407	.2543
10	.362	.2204	.3391	.3801	.3801	.3391	.373
11	.2896		.2883	.3258	.2896	.2883	.3561
12	.2896		.2374	.2715	.2534	.2543	.3052
13	.2715	.2883	.2294	.2534	.2353	.2035	.2543
14	.2534	.2713	.2543	.2353	.2172	.2347	.2883
15	.2353	.2458	.3222	.2172	.2353	.2458	.3222
16	.2896	.2883	.3561	.2534	.2534	.2543	.3391
17	.2896	.3222	.373	.2715	.2896	.2713	.2883
18	.362	.3561	.3561	.362	.3258	.2947	.373
19	.3982	.4578	.4917	.5068	.4706	.4748	.4409
20	.4706	.4239	.5256	.4887	.4525	.4409	.39
21	.4525	.39	.407	.4706	.4163	.4239	.3391
22	.3258	.3391		.362	.3258	.3561	
23	.2534	.3052	.3052	.2896	.2896	.3391	.3052
24	.2883	.2172	.2883	.2883	.2534	.3077	.3052
Max	.4706	.5068	.5256	.5068	.5068	.543	.5596
Min	.2353	.2172	.2294	.2172	.2172	.2035	.1865
Avg	.3479	.3290	.3344	.3363	.3415	.3366	.3334