

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154073 / 33/11 KV MIDC

Feeder No / Name : 201 / 11 KV CHAITANYA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.6478	.8002	.4954	.5335	.5335	.5335
2	.5335	.6478	.7621	.4954	.5335	.5716	.6097
3	.5335	.6478	.724	.4572	.5716	.6097	.6478
4	.5716	.6478	.6859	.4572		.6478	.6097
5	.381	.6097	.6478	.4572	.5335	.6859	.6859
6	.6859	.5716	.6097	.4954	.5716	.7621	.7621
7	.4954	.5716	.5716	.5335	.5716	.9145	.8002
8	.4763	.7621	.5716	.6097	.5335	1.0288	.8764
9	.5716	.8954	.7811	1.1812	.6097	.9907	.9526
10	.6859	.8764	.7621	1.2193	.6097		1.0288
11	.8002	.8573	.6097		.6287	1.0669	1.0669
12	1.1241	.8383	.5716		.6478	1.1431	1.105
13	.9145	.8192	.5716		.6478	.9907	1.1812
14	.362	.8192	.5335		.6668	1.1431	.9717
15	.4954	.9145		1.1431	.6668	1.2955	1.105
16	.8002	.9907	.5335	1.2574	.6478	1.5051	1.0669
17	.8383	1.2003	.4954	1.1431	.6478	1.1431	1.1812
18	.9145	.9907	.4001	.3429	.6287	1.0098	1.2765
19	.9145	.9717	.4572	.9526	.6287	.9907	1.105
20	.8764	.9526	.4572	.9145	.6478	1.0288	1.0288
21	.8573	.9526	.4954	.9145	.6478	.8002	.9526
22	.8573	.9145	.4954	.9145	.5716	.4191	.9145
23	.7621	.8764	.4954	.7621	.5335	.724	.8002
24	.5335	.6859	.8383	.4954		.5335	.5716
Max	1.1241	1.2003	.8383	1.2574	.6668	1.5051	1.2765
Min	.362	.5716	.4001	.3429	.5335	.4191	.5335
Avg	.6899	.8192	.6031	.7621	.6036	.8930	.9097

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154073 / 33/11 KV MIDC

Feeder No / Name : 202 / 11 KV N. DATTA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.4572	.4191	.381	.5716	.3048	.3429
2	.4572	.381	.381	.3429	.5716	.3048	.3048
3	.381	.381	.381	.3429	.5335	.381	.381
4	.3429	.381	.3429	.3429	.381	.381	.4191
5	.3429	.381	.3429	.3429	.4191	.4191	.4572
6	.381	.381	.3048	.3429	.3429	.4191	.4954
7	.4191	.381	.3048	.381	.381	.4572	.5335
8	.4572	.4572	.3048	.4572	.381	.4572	.5335
9	.724	.4572	.381	.5716	.4572	.5335	.5716
10	.7621	.5335	.381		.5335	.5716	.6097
11	.8002	.6859	.381		.6097	.6097	.7621
12	.9145	.6859	.381		.6859	.724	.8002
13	.8002	.7621	.381		.6859	.8002	.9145
14	.6859	.8383	.381		.7621	.8002	.7621
15	.6859	.8383	.381	.9145	.7621	.8383	.8002
16	.7621	.9145	.381		.7621	.8383	.8764
17		.8383	.381	.9526	.6859	.9145	.9145
18	.7621	.7621	.381	.9145	.6097	.8383	.9145
19	.6859	.6097	.381	.7621	.4191	.8002	.8002
20	.724	.5716	.4191	.724	.4191	.724	.7621
21	.5716	.5335	.4572	.6097	.381	.5716	.6097
22	.5335	.5335	.4572	.5335	.381	.5335	.6097
23	.5335	.4572	.4572		.381	.5335	.5335
24	.5716	.5335	.4572	.4572	.5335	.3048	.381
Max	.9145	.9145	.4572	.9526	.7621	.9145	.9145
Min	.3429	.381	.3048	.3429	.3429	.3048	.3048
Avg	.6014	.5731	.3842	.5514	.5271	.5859	.6287

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154073 / 33/11 KV MIDC

Feeder No / Name : 203 / 11 KV OLD SHASHAKIYA  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.5716	.4572	.5335	.4191	.4191	.4954
2	.4191	.5716	.4572	.5716	.381	.381	.4191
3	.381	.6097	.4191	.5716	.3429	.381	.381
4	.4191	.6097	.381	.5716	.381	.4572	.4191
5	.4954	.6097	.4572	.5716	.3429	.5335	.4572
6	.5335	.5716	.5335	.6097	.381	.5716	.4572
7	.5335	.6097	.6097	.6097	.4191	.6097	.4572
8	.4954	.9145	.6097	.6859	.3429	.6859	.4572
9	.5335	.9907	.6859	.6859	.4191	.7621	.5716
10	.8002	.9907	.6859		.4572	.8002	.9145
11	1.2384	1.105	.8002		.5335	.9526	1.0669
12	1.448	1.1431	.8383		.5716	.9907	1.3717
13	1.105	1.2193	.8383		.5716	1.1431	1.448
14	1.1431	1.1431	.8383	.9526	.6097	1.1812	1.448
15	1.0669	1.2193	.8383	1.0669	.6097	1.2193	1.3336
16	.9907	1.3717	.8002		.6097	.9907	1.2955
17	.9145	1.3717	.7621	.9526	.5335	.9526	1.2193
18	.8383	1.2193	.7621	.8002	.4572		1.1431
19	.8002	.9907	.6859	.7621	.4572	.724	1.105
20	.7621	.9145	.5716	.724	.5335	.6097	.9526
21	.6859	.5716	.6478	.6097	.5335	.5716	.6478
22	.5335	.5716	.5335	.5335	.4572	.5335	.5335
23	.5335	.5335	.4954		.4572	.5335	.5335
24	.5335	.5335	.5335	.4954	.5335	.4191	.6478
Max	1.448	1.3717	.8383	1.0669	.6097	1.2193	1.448
Min	.381	.5335	.381	.4954	.3429	.381	.381
Avg	.7359	.8732	.6351	.6838	.4731	.7140	.8240

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154073 / 33/11 KV MIDC

Feeder No / Name : 204 / 11 KV NEW SHASHAKIYA  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.1905	.1905	.2096	.2286	.1905	.3048
2	.3048	.1715	.1905	.1905	.2667	.1905	.2286
3	.3048	.1715	.2286	.1905	.2667	.2286	.2286
4	.3048	.1715	.2667	.1905	.3048	.2286	.3048
5	.3048	.1715	.2858	.2286	.3048	.2477	.3048
6	.3048	.2286	.3048	.2477	.3048	.2667	.2286
7		.3048	.3239	.3239	.3048	.2667	.2667
8	.3429	.3048	.3429	.3048	.3048	.2667	.2667
9	.3048	.3429	.3048	.2858	.2858	.2858	.2667
10	.3048	.3239	.3048	.3048	.2858	.2667	.2667
11	.2667	.2858	.2667		.2667	.2667	.2667
12	.2667	.2667	.2667		.2667	.3048	.2477
13	.2286	.2477	.2286	1.3336	.2477	.3048	.2477
14	.2096	.2286	.1905		.2286	.2286	.2667
15	.2286	.2477	.1905	.3048	.2096	.3048	.3048
16	.2667	.2667	.1905		.2286		.3048
17	.2667	.2858	.1905	.2858	.2858	.3048	.3048
18	.2667	.3048	.2477	.3048	.3048	.3048	.3048
19	.2667	.3048	.2667	.3048	.3239	.2667	.3048
20	.2286	.2858	.2858	.3429	.3239	.2858	.3429
21	.2096	.2858	.2667	.3048	.3048	.3048	.3048
22	.2096	.2286	.2858	.2667	.2667	.3048	.2858
23	.2096	.2286	.2096		.2286	.2858	.2667
24	.2667	.1905	.2286	.2096	.2667	.2286	.2667
Max	.3429	.3429	.3429	1.3336	.3239	.3048	.3429
Min	.2096	.1715	.1905	.1905	.2096	.1905	.2286
Avg	.2667	.2516	.2524	.3229	.2754	.2667	.2786

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154073 / 33/11 KV MIDC

Feeder No / Name : 205 / 11 KV TEXTILE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8764	.9907	.9145	.8383	.8002	.8383	.8383
2	.7621	1.0288	.8383	.8383	.9145	.7621	.7621
3	.724	1.0288	.8383	.8383	.8764	.7621	.7621
4	.8002	.9526	.7621	.8764	.8002	.6859	.724
5	.8764	.9145	.7621	.8383	.7621	.7621	.7621
6	1.0669	.9145	.8383	.8764	.8764	.8383	.8002
7	.6097	.9145	.9145	.9145	.724	.9907	.724
8	.5716	.9907	1.0669	.9907	.8002	1.0669	.9526
9	.6097	1.2193	1.1812	1.2193	1.1812	1.0669	.9907
10	.724	1.3717	1.6575	1.1812	1.2193		1.448
11	1.5242	1.4861	1.105		1.3717	1.3717	1.6766
12	1.5242	1.6385	1.0669			1.5242	1.8671
13	1.3336	1.4861	1.0669			1.6766	1.9814
14	.9145	1.3717	1.0669			1.7528	1.829
15	.9907	1.3717	1.0669	1.5242		1.9814	1.8671
16	1.0669	1.6766	1.0288	1.5242		1.9814	1.8671
17	1.2955	1.6766	.9526	1.3717		1.5623	1.8671
18	1.3717	1.3717	.9145	1.3336	.6097	1.3717	1.829
19	1.3336	1.3717	.9145	1.2574	.7621	1.3336	1.7147
20	1.2955	1.2193	.9145	1.1812	.9907	1.2955	1.4861
21	1.0288	1.2193	.9145	1.1431	1.0669	1.1812	1.448
22	1.0669	.9907	.9145	1.2193	.9907	.9526	1.2955
23	.9526	.9145		.9526	.9145	.9145	1.2193
24	.8192	.9526	.9145	.8002	.8002	.8383	.7621
Max	1.5242	1.6766	1.6575	1.5242	1.3717	1.9814	1.9814
Min	.5716	.9145	.7621	.8002	.6097	.6859	.724
Avg	1.0058	1.2114	.9832	1.0860	.9145	1.1961	1.3114

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154073 / 33/11 KV MIDC

Feeder No / Name : 206 / 11 KV SHIVAJI CHOWK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7909	1.8671	2.0005	1.7528	1.6766	1.9052	2.0576
2	1.5623	1.829	1.9433		1.4861	1.8671	1.8671
3	1.5051	1.7147	1.9052	1.7147	1.3717	1.829	1.7528
4	1.5242	1.7147	1.8671	1.7147	1.3336	1.8099	1.6766
5	1.6766	1.7147	1.829	1.7147	1.2955	1.7909	1.3336
6	1.7909	1.7147	1.7909	1.7528	1.3717	1.7909	1.3717
7		1.7147	1.7528	1.6956	1.5242	1.7718	1.4861
8	.381	1.7147	1.7147	1.6004	1.829	1.7718	1.5242
9	1.5623	1.7147	1.6766	1.848	1.7528	1.7528	1.6766
10	1.8671	1.7528	1.7147		1.7909	1.7147	1.829
11	2.0957	1.829	1.7528		1.829	2.1338	1.9433
12	2.2862	1.9433	1.829	1.9433	1.8671	2.0005	2.21
13	.6097	2.0957	1.7147		1.9052	2.191	2.3815
14	.6859	2.1719	1.7528	2.1338	1.9433	2.2481	2.3053
15	.724	2.1719	1.6956	2.21	1.9433	2.191	2.4006
16	.8764	2.191	1.7909		2.0957	2.21	2.3624
17	1.829	2.21	1.8861	2.2862	2.2862	1.9433	2.3624
18	2.21	2.2862	1.8861	2.3243	2.4768	2.0576	2.2862
19	2.4387	2.5149	2.0005	2.3434	2.5339	1.9433	2.4387
20	2.2862	2.6292	2.2481	2.4387	2.5149		2.4387
21		2.572	2.0767	2.0576	2.3053	2.21	2.4006
22	2.1148	2.4768	2.0005	1.9433	2.2862	1.7528	2.3815
23	2.0005	2.2862	1.8671		2.0957	1.7147	2.2291
24	1.9433	1.9052	2.0957	1.8671	1.7147	1.9433	1.9433
Max	2.4387	2.6292	2.2481	2.4387	2.5339	2.2481	2.4387
Min	.381	1.7147	1.6766	1.6004	1.2955	1.7147	1.3336
Avg	1.6255	2.0306	1.8663	1.9634	1.8846	1.9367	2.0275

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154075 / 33/11 KV ARVI

Feeder No / Name : 201 / 11 KV MEDICAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6							.0075
7		.0055		.0075		.0075	
8	.0075	.0055	.0074	.0075	.0075	.0074	.0074
9						.0055	
12	.0055				.0055		
16		.0055			.0055	.0074	.0055
17	.0055						
18				.0052		.007	
20					.0074		
23					.0075	.0075	
24	.0057		.0056	.0057	.0057	.0056	.0057
Max	.0075	.0055	.0074	.0075	.0075	.0075	.0075
Min	.0055	.0055	.0056	.0052	.0055	.0055	.0055
Avg	.0061	.0055	.0065	.0065	.0065	.0068	.0065

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154075 / 33/11 KV ARVI

Feeder No / Name : 202 / 11 KV DWARAKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6							.0226
7		.0222		.0226		.0222	
8	.0217	.0222	.0222	.0224	.0224	.0222	.0224
9						.0222	
11						.0199	
12	.0222				.0222		
15						.0203	
16		.0222		.0222	.0219		.0203
17	.0203					.0219	
18				.0215		.0197	
20					.0259		
23					.0243	.0243	
24	.0187	.0205	.0205	.0187	.0207	.0224	.0224
Max	.0222	.0222	.0222	.0226	.0259	.0243	.0226
Min	.0187	.0205	.0205	.0187	.0207	.0197	.0203
Avg	.0207	.0218	.0214	.0215	.0229	.0217	.0219



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154075 / 33/11 KV ARVI

Feeder No / Name : 204 / 11 KV SWAMI SAMARTH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6							.7669
7		.7207		.8029		.8871	
8	.8048	.5729	.6908	.7095	.7316	.8131	.6967
9						.7392	
11						.6099	
12	.5544				.6099		
16		.5415			.6099		.6036
17	.5175						
18		.6838		.6535		.6425	
19						9.0901	
20					.8871		
23					.7655	.8141	
24	.6908	.5415	.6348	.6161	.6602	.7282	.7282
Max	.8048	.7207	.6908	.8029	.8871	9.0901	.7669
Min	.5175	.5415	.6348	.6161	.6099	.6099	.6036
Avg	.6419	.6121	.6628	.6955	.7107	1.7905	.6989

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154075 / 33/11 KV ARVI

Feeder No / Name : 205 / 11 KV SIDDESHWAR MANDIR SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3071	.1715	.2027	.2522	.2789	.3094	.2812
2	.3018	.1699	.1997	.2385	.2759	.3033	.2904
3	.298	.1699	.1989	.2355	.2606	.2987	.2881
4	.2957	.1677	.1966	.2355	.2614	.2964	.2896
5	.2934	.1707	.1791	.2378	.2561	.3155	.2919
6	.3018	.1859	.1517	.2385	.2622	.3224	.3111
7	.3742	.2352	.2111	.2808	.3178	.3547	.3399
8	.2743	.2841	.3015	.3602	.435	.424	.428
9	.2576	.2759	.3147	.4115	.4832	.4149	.4588
10	.3605	.3025	.3086	.413	.3902	.4519	.5289
11	.3993	.3368	.3376	.3765	.4031	.4896	.5319
12	.4344	.365	.3193	.381	.4858	.5133	.506
13	.455	.3559	.2987	.3605	.4938	.5235	.474
14	.189	.2644	.3506	.4062	.4923	.3757	.3185
15	.2134	.2385	.3521	.4298	.503	.3691	.3406
16	.2195	.2521	.346	.4435	.4851	.4475	.4026
17	.2378	.2545	.3498	.4245	.4374	.4612	.4656
18	.2233	.2042	.3178	.4274	.4412	.4691	.5251
19	.2263	.2759	.3292	.4054	.4481	.4275	.5235
20	.2545	.3239	.3216	.4214	.4178	.3589	.3605
21	.2797	.2987	.3437	.3917	.3742	.3826	.3025
22	.1882	.3079	.3132	.3635	.3917	.3879	.3429
23	.2263	.2705	.2721	.3399	.3666	.4056	.2911
24	.2041	.1797	.2841	.3262	.34	.3201	.2881
Max	.455	.365	.3521	.4435	.503	.5235	.5319
Min	.1882	.1677	.1517	.2355	.2561	.2964	.2812
Avg	.2840	.2526	.2834	.3500	.3876	.3926	.3825

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154077 / 33/11 KV KOLPA

Feeder No / Name : 204 / 11 KV URBAN/SOS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3216	.2027	.221	.2218	.2644	.2294	.2667
2	.3147	.192	.2035	.2088	.2439	.2157	.2553
3	.3064	.1951	.2065	.205	.2378	.2126	.2507
4	.3033	.1936	.205	.2065	.2385	.205	.2477
5	.3117	.2111	.221	.2157	.2515	.2119	.2538
6	.3582	.2576	.2393	.2614	.2667	.2469	.2919
7	.4344	.3208	.2766	.3353	.3239	.317	.3597
8	.3483	.3384	.3589	.3628	.3467	.3582	.3788
9	.3391	.362	.3544	.3353	.3719	.3582	.3917
10	.3132	.3269	.2873	.3346	.378	.349	.426
11	.33	.3513	.2957	.333	.3681	.4245	.4108
12	.3346	.3742	.2911	.3429	.333	.4024	.4077
13	.3406	.3597	.2911	.3429	.3246	.3795	.474
14	.2797	.3353	.2766	.317	.2987	.3681	.439
15	.2804	.2957	.2484	.3132	.2858	.3178	.3742
16	.3513	.3262	.2553	.3132		.3193	.4092
17	.2858	.3269	.2835	.3102	.2972	.3681	.4519
18	.2949	.3307	.2896	.3353	.3673	.4473	.4329
19	.3041	.3567	.3262	.3849	.3742	.413	.4534
20	.3003	.3765	.3269	.4161	.3269	.4359	.4252
21	.2667	.314	.3216	.3528	.3086	.3765	.3727
22	.2416	.2812	.2995	.3071	.2957	.3361	.3399
23	.237	.2652	.2751	.2782	.2667	.2904	.3208
24	.2248	.2423	.2385	.2675	.2462	.2705	.2942
Max	.4344	.3765	.3589	.4161	.378	.4473	.474
Min	.2248	.192	.2035	.205	.2378	.205	.2477
Avg	.3093	.2973	.2747	.3042	.3051	.3272	.3637

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154116 / 33/11 KV OPH S/S

Feeder No / Name : 201 / 11 KV Vivekanand Chowk

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.7888	.823		.8573	
2			.7888			.8573	
3			.7888			.9602	
4			.7545			.823	
5			.7545			.823	
6			.7545			.8573	
7			.823			.8573	
8	1.1576		.8916	.8823		.8573	
9	.8573	.7545	.9145	.7888			
10	.8745	.583		.7716			
11	.6859	.6173		.7373			
12	.6687	.6516		.6687			
13	.6859	.6516		.703			
14	.703	.6516		.703			
15	.6859	.6859		.6859			
16	.7282		.6859	.6344	.6859		
17	.7716	.7888			.6859		
18	.8402	.823			.823		
19		.9602			.8573		
20		.9945			.9259		
21		.9945			1.1317		
22		.9945			1.0288		
23		.9259	.8573		.8916		
24	.9335	.6767	.8573	.8573	.8326	.8916	.823
Max	1.1576	.9945	.9145	.8823	1.1317	.9602	.823
Min	.6687	.583	.6859	.6344	.6859	.823	.823
Avg	.7994	.7836	.8050	.7505	.8736	.8649	.823

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154116 / 33/11 KV OPH S/S

Feeder No / Name : 203 / 11 KV Gandhi Chowk

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.8573			.9259	
2			.7888			.8573	
3			.7888			.823	
4			.7545			.823	
5			.7545			.823	
6			.7888			.823	
7			.823			.8573	
8	1.2696		.9709	.8823		.9709	
9	1.166	.9431		1.1145			
10	1.166	1.1317		1.2174			
11	1.3717	1.3717		1.6289			
12	1.749	1.5775		1.7318			
13	1.7318	1.5432		1.7147			
14		1.5432		1.5604			
15		1.6118		1.5775			
16	1.9738	1.6118	.8573	1.6289	1.1317		
17	1.9376	1.6804			1.1317		
18	1.9376	1.8519			1.1317		
19		2.0919			1.166		
20		1.749			1.2346		
21		1.5089			1.2689		
22		1.2003			1.2003		
23		.9945	.9431		.9602		
24	.9335		.9259		.905	.9602	.8573
Max	1.9738	2.0919	.9709	1.7318	1.2689	.9709	.8573
Min	.9335	.9431	.7545	.8823	.905	.823	.8573
Avg	1.5237	1.4941	.8412	1.4507	1.1256	.8737	.8573

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154116 / 33/11 KV OPH S/S

Feeder No / Name : 204 / 11 kV Subhash Chowk

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3772			.4115	
2			.3429			.3772	
3			.3429			.3772	
4			.3429			.3429	
5			.3429			.3429	
6			.3429			.3429	
7			.3772			.3772	
8	.5228		.4527			.5228	
9	.583	.5144		.583			
10	.6001	.583		.6173			
11	.9259	.6859		.9945			
12	1.0117	.823		1.0802			
13	.9945	.9602		1.0974			
14	.9945	.9945		1.0974			
15		1.0288		1.0974			
16	1.3817	1.0631	.5144	1.0802	.823		
17	1.2003	1.0974			.823		
18	1.2174	1.2003			.7888		
19		1.3375			.8573		
20		1.2003			.7888		
21		1.0631			.7202		
22		.6859			.6173		
23		.4458	.4325		.4801		
24	.4668		.4115		.4344	.4458	.4287
Max	1.3817	1.3375	.5144	1.0974	.8573	.5228	.4287
Min	.4668	.4458	.3429	.583	.4344	.3429	.4287
Avg	.8999	.9122	.3891	.9559	.7037	.3934	.4287

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154116 / 33/11 KV OPH S/S

Feeder No / Name : 205 / 11 KV Hattenagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6859			.7202	
2			.6516			.6859	
3			.6516			.6859	
4			.6173			.6859	
5			.6173			.6859	
6			.6173			.6859	
7			.583			.7202	
8	.7468		.6348			.7842	
9	.6516	.6516		.6173			
10	.6344	.6859		.6173			
11	.6173	.6859		.583			
12	.6344	.6516		.5658			
13	.6001	.5487		.5487			
14		.5144		.5658			
15	.583	.4801		.583			
16	.5658	.4115	.5144	.6173	.3772		
17	.6516	.4801			.4458		
18	.6859	.5487			.6516		
19		.7545			.7888		
20		.7888			.8573		
21		.7545			.823		
22		.7202			.7545		
23		.7202	.6055		.7202		
24	.6535		.6859		.6697	.7202	.6859
Max	.7468	.7888	.6859	.6173	.8573	.7842	.6859
Min	.5658	.4115	.5144	.5487	.3772	.6859	.6859
Avg	.6386	.6264	.6241	.5873	.6765	.7083	.6859

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154116 / 33/11 KV OPH S/S

Feeder No / Name : 206 / 11 KV SALE GALLI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.583			.6516	
2			.5487			.6173	
3			.5144			.6173	
4			.5144			.583	
5			.5144			.583	
6			.583			.6173	
7			.6173			.6173	
8	.7468		.6516			.6173	
9	.6859	.583		.6516			
10	.6001	.5487		.5658			
11	.5144	.5487		.5144			
12	.4973	.5487		.463			
13	.4801	.5487		.4801			
14	.3944	.5487		.4973			
15	.4115	.5144		.4973			
16	.3944	.4458	.5144	.463	.5487		
17	.6001	.5144			.5487		
18	.6344	.583			.5487		
19		.7202			.6173		
20		.7202			.7888		
21		.6859			.7545		
22		.6516			.7202		
23		.6173	.6001		.6516		
24	.6535		.583		.5973	.6516	.6001
Max	.7468	.7202	.6516	.6516	.7888	.6516	.6001
Min	.3944	.4458	.5144	.463	.5487	.583	.6001
Avg	.5511	.5853	.5658	.5166	.6418	.6173	.6001



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 157004 / 132 KV S/S MIDC

Feeder No / Name : 201 / 11 KV MAROTI FERTOCHM  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	16-MAR-17	17-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	1.1812	.6668		
9			.8573	.9145
12	1.2193	.6668	1.3336	1.2193
15		.6668	1.2765	1.3336
Max	1.2193	.6668	1.3336	1.3336
Min	1.1812	.6668	.8573	.9145
Avg	1.2003	.6668	1.1558	1.1558

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 157004 / 132 KV S/S MIDC

Feeder No / Name : 206 / 11 KV KIRTI GOLD

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	16-MAR-17	17-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	1.9052	2.0195		
9			1.9243	1.2955
12	1.6766	1.9433	1.7528	1.4098
15			1.829	1.6575
Max	1.9052	2.0195	1.9243	1.6575
Min	1.6766	1.9433	1.7528	1.2955
Avg	1.7909	1.9814	1.8354	1.4543

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 157004 / 132 KV S/S MIDC

Feeder No / Name : 401 / 33 KV MIDC FEEDER

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	16-MAR-17	17-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	7.7732	4.6296		
9			5.9442	6.0014
12	7.8875	4.8583	8.1733	8.7449
15			8.1162	8.1733
Max	7.8875	4.8583	8.1733	8.7449
Min	7.7732	4.6296	5.9442	6.0014
Avg	7.8304	4.7440	7.4112	7.6399

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 157004 / 132 KV S/S MIDC

Feeder No / Name : 402 / 33 KV MEDICAL COLLEGE

SHEDDABLE URBAN

FEEDER Feeder KV- 33 /  
INCOMING

DATE	16-MAR-17	17-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	4.0009	4.0581		
9			5.2012	5.3727
12	4.1724	4.3439	4.8011	4.9154
15			4.8011	4.8011
Max	4.1724	4.3439	5.2012	5.3727
Min	4.0009	4.0581	4.8011	4.8011
Avg	4.0867	4.201	4.9345	5.0297

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 157004 / 132 KV S/S MIDC

Feeder No / Name : 404 / 33 KV ADM AGRO. INDUSTRIES NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	16-MAR-17	17-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	2.0005	1.9433		
9			2.0576	2.1148
12	2.1148	2.0005	1.9433	2.1719
15			2.0005	2.0005
Max	2.1148	2.0005	2.0576	2.1719
Min	2.0005	1.9433	1.9433	2.0005
Avg	2.0577	1.9719	2.0005	2.0957

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154013 / 33/11 KV HARANGUL

Feeder No / Name : 202 / 11KV MIDC SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.39	.2401	.3601	.4144	.3429	.5335	.5281
2	.4239	.2401	.4115	.4694	.3944	.6097	.5658
3	.4694	.2629	.4458	.503	.4287	.6859	.6036
4	.5868	.2629	.5144	.5304	.5144	.7167	.7545
5	.6371	.3155	.583	.57		.415	.8676
6	.6874	.3856	.6516	.6443	.5256	.8488	.9431
7	.57	.463	.703	.8551	.7122	.9054	.9997
8	.8048	.4748	.5087	.8122	.788	.8488	.7733
9	.8048	.6613	.6613	.7625	.7209	.5847	.6602
10	.5281	.1698	.5847	.5281	.5228	.3601	.4694
11	.4527	.1524	.5281	.4904	.5281	.6274	.503
12	.3772	.1524	.4904	.4338	.3584	.7042	.6299
13		.1524	.4527	.415	.415	.6706	.6299
14		.6224	.4715	.3772	.415	.6371	.5868
15		.5093	.4527	.415	.4527	.6371	.5533
16		.5281	.4904	.4527	.415	.6464	.6299
17	.4904	.4338	.4715	.415	.4527	.6802	.7209
18		.547	.5281	.3961	.415	.5281	.3772
19	.7095	.679	.7356	.7167	.7167	.7167	.6602
20	.6722	.7922	.7545	.7545	.8488	.7922	.811
21	.6224	.7167	.6413	.7545	.7545	.7545	.7733
22	.5093	.6478	.6036	.679		.6413	.7167
23	.415	.5525	.5658	.5847		.6036	
24	.3601	.2401	.2915	.3647	.2915	.5716	.5658
Max	.8048	.7922	.7545	.8551	.8488	.9054	.9997
Min	.3601	.1524	.2915	.3647	.2915	.3601	.3772
Avg	.5532	.4251	.5376	.5558	.5244	.6550	.6662

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154013 / 33/11 KV HARANGUL

Feeder No / Name : 203 / 11KV NANDGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.5335	.6097	.6036	.5658	.9389	1.0059
2	.5658	.5335	.6478	.6036	.5658	1.073	1.0608
3	.6413	.5716	.724	.679	.6036	1.1934	1.1271
4	.7167	.6668	.8002	.7545	.7167	1.2929	1.2071
5	.8488	.8002	.8764	.8676	.8488	1.3923	1.2597
6	1.0185	.9907	.9526	.9997	.9242	1.4746	1.3413
7	1.0374	.9808	.9619	1.0562	1.0562	1.5402	1.873
8	1.0185	.8402	.8299	.9054	.8676	1.7204	1.9062
9	.7545	.7167	.6602	.6224	.6602	1.643	1.8233
10	1.0898	.407	.9556	1.0682	1.21	.4338	.4108
11	1.3748	.9892	1.358	1.2209	1.4746	.3395	.3584
12	1.6095	1.1934	1.4586	1.291	1.5074	.3395	.2263
13		1.1768	1.4419	1.2742	1.5249	.3206	.2263
14		1.2071	1.4083	1.2742	1.4918	.3206	.2829
15		1.2597	1.4251	1.3413	1.278	.3584	.3206
16		.7042	1.0852	1.4083	1.5402	.3206	.3584
17	.9431	1.073	1.21	1.5424	1.4091	.3584	.3772
18	.5658	.415	.4527	.415	.4338	.3961	.3206
19	.8962	.7167	.8488	.811	.8676	.7167	.679
20	.8402	.8865	.8676	.9242	.9997	.9242	.9054
21	.7922	.8299	.7545	.811	.9054	.8299	.8299
22	.6224	.7621	.679	.7733	.7049	.7545	.7922
23	.5658	.6859	.6224	.6413	.7049	.679	.679
24	.6036	.5335	.6287	.6036	.6224	.8383	.8886
Max	1.6095	1.2597	1.4586	1.5424	1.5402	1.7204	1.9062
Min	.5658	.407	.4527	.415	.4338	.3206	.2263
Avg	.8535	.8114	.9275	.9372	.9785	.8416	.8442

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154013 / 33/11 KV HARANGUL

Feeder No / Name : 204 / 11KV NAGZARI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8048	.3772	.5487	.5243	.5426	.1905	.2263
2	.9054	.373	.6173	.5636	.5935	.1715	.2263
3	.9724	.373	.7545	.5636	.6443	.2096	.2641
4	1.0277	.3944	.8573	.6036	.6783	.2641	.2641
5	1.0774	.4115	.9496	.6299	.7377	.2641	.3018
6	1.1934	.4239	1.0174	.7209	.8048	.3018	.3206
7	.8619	.6036	1.0562	1.1271	1.1568	.3018	.3395
8	1.2597	.7042	1.1904	1.2616	.3391	.2641	.2452
9	1.4419	1.1568	1.1736	1.2289	.8745	.2075	.2075
10	.1698	.1509	.1509	.1698	.1509	.7545	.852
11	.1698	.1886	.132	.1509		1.1568	1.1271
12	.1509	.1715	.1509	.132	.2075	1.2763	1.2955
13		.1524	.1698	.1509	.1886	1.326	1.2955
14		.1509	.1698	.1698	.1509	1.4255	1.3435
15		.1509	.1698	.1509	.1698	1.0277	1.3599
16		.1509	.2075	.132	.1886	1.3108	1.5581
17		.1509	.1698	.132	.1698	1.4243	1.5415
18	.2641	.1509	.1886	.1509	.0019	.1509	.132
19	.2987	.2263	.2829	.2452	.2641	.2641	.2452
20	.2987	.3018	.3018	.3018	.3584	.3395	.2829
21	.2641	.3018	.3018	.3206	.3206	.3018	.2829
22	.2263	.2858	.2641	.3018	.2829	.2641	.2829
23	.1886	.2667	.2452	.2452	.2477	.2263	.2452
24	.7545	.3944	.4801	.4752	.5256	.2286	.2263
Max	1.4419	1.1568	1.1904	1.2616	1.1568	1.4255	1.5581
Min	.1509	.1509	.132	.132	.0019	.1509	.132
Avg	.6490	.3338	.4813	.4355	.4173	.5688	.6027



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154013 / 33/11 KV HARANGUL

Feeder No / Name : 205 / Rajeshwari Feeder

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0018	.0018	.0018	.0018	.0018	.0018	.0018
2	.0018	.0018	.0018	.0018	.0018	.0018	.0018
3	.0018	.0018	.0018	.0018	.0018	.0018	.0018
4	.0018	.0018	.0018	.0018	.0018	.0018	.0018
5	.0018	.0018	.0018	.0018	.0018	.0018	.0018
6	.0018	.0018	.0018	.0018	.0018	.0018	.0018
7	.0018	.0018	.0018	.0018	.0018	.0018	.0018
8	.0018	.0018	.0018	.0018	.0018	.0018	.0018
9	.0018	.0018	.0018	.0018	.0018	.0018	.0018
10	.0018	.0018	.0018	.0018	.0018	.0018	.0018
11	.0018	.0018	.0018	.0018	.0018	.0018	.0018
12	.0018	.0018	.0018	.0018	.0018	.0018	.0018
13		.0018	.0018	.0018	.0018	.0018	.0018
14		.0018	.0018	.0018	.0018	.0018	.0018
15		.0018	.0019	.0018	.0018	.0018	.0018
16		.0018	.0018	.0018	.0018	.0018	.0018
17	.0018	.0018	.0018	.0018	.0018	.0018	.0018
18	.0018	.0018	.0018	.0018	.0018	.0018	.0018
19	.0018	.0018	.0018	.0018	.0018	.0018	.0018
20	.0018	.0018	.0018	.0018	.0018	.0018	.0018
21	.0018	.0018	.0018	.0018	.0018	.0018	.0018
22	.0018	.0018	.0018	.0018	.0018	.0018	.0018
23	.0018	.0018	.0018	.0018	.0018	.0018	.0018
24	.0018	.0018	.0018	.0018	.0018	.0018	.0018
Max	.0018	.0018	.0019	.0018	.0018	.0018	.0018
Min	.0018	.0018	.0018	.0018	.0018	.0018	.0018
Avg	.0018	.0018	.0018	.0018	.0018	.0018	.0018

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154013 / 33/11 KV HARANGUL

Feeder No / Name : 206 / harangul SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6443	.1494	.168	.4694	.463	.3429	.381
2	.6783	.1509	.1886	.503	.5144	.3429	.4572
3	.7712	.1886	.2263	.5636	.5487	.4954	.4954
4	.8718	.2286	.2987	.6371	.6516	.7621	.5716
5	.9221	.2858	.3326	.6783	.7122	.9145	.8764
6	1.0059	.381	.3696	.7716	.763	1.0288	1.0098
7	1.1488	.439	.4024	.9431	.9326	1.086	1.086
8	1.3565	.5175	.4572	.8987	.9835	.9526	1.0098
9	1.2209	.3506	.3429	.8648	.9221	.7621	.8002
10	.5144	.6097	.6097	.6478	.5716	.6443	.8192
11	.381	.4191	.4572	.4572	.4763	.9389	.9503
12	.2667	.3048	.4191	.3429	.4382	.9724	.8907
13		.3048	.3429	.3048	.3429	.9945	.9503
14		.3048	.3239	.2667	.3429	.9724	.9175
15		.3429	.381	.2667	.3048	.8886	.8745
16		.3048	.3429	.2477	.3048	.9945	.9831
17	.4954	.362	.381	.3048	.381	1.0082	1.1736
18	.5716	.5525	.4191	.3239	.381	.4191	.4191
19	.8383	.6478	.6859	.7621	.6097	.6859	.7049
20	.6478	.7049	.724	.7049	.6859	.7621	.7049
21	.5716	.6097	.6668	.6287	.6097	.6859	.6668
22	.4001	.4954	.5335	.5335	.5335	.5716	.5716
23	.3429	.4001	.4001	.4191	.4191	.4191	
24	.5935	.1494	.1543	.431	.4287	.381	.381
Max	1.3565	.7049	.724	.9431	.9835	1.086	1.1736
Min	.2667	.1494	.1543	.2477	.3048	.3429	.381
Avg	.7122	.3835	.4012	.5405	.5551	.7511	.7693

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154022 / 33/11 KV MAMDAPUR

Feeder No / Name : 201 / 11KV BHADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0686	.0686			.2743	.2229
2		.0686	.0514			.2743	.2229
3		.1029	.0514			.2743	.3086
4		.1372	.0857			.2915	.3772
5		.1543	.1029			.3086	.4458
6		.2401	.2572			.4458	.5316
7	.1715	.2915	.3258		.3258	.6001	.6001
8		.2229	.2743		.3086	.6687	
9	.1543	.1715	.1886		.3086		
10	.0686	.2915	.3086	.3429	.4801	.1543	.12
11		.3258			.5144		
12		.3429			.5487		.0686
13	.0514	.3429			.5316		.0514
14	.0857	.3086	.0343		.5144		
15	.3429	.3944		.3601			
16	.3258	.4458			.5487		.0686
17	.4115	.5144			.5658	.0343	.0686
18	.0857	.0686		.0514	.0686	.0343	.0686
19	.2058	.1715			.1715	.1715	.1029
20	.1886	.1886		.2229	.1886	.2058	
21		.1372			.1372	.1543	
22	.1029	.12			.12	.12	
23	.0857	.1029			.0857	.1029	
24	.0686	.0686	.0857		.0857	.2229	.2229
Max	.4115	.5144	.3258	.3601	.5658	.6687	.6001
Min	.0514	.0686	.0343	.0514	.0686	.0343	.0514
Avg	.1678	.2201	.1529	.2443	.3238	.2552	.2320

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154022 / 33/11 KV MAMDAPUR

Feeder No / Name : 202 / 11KV MAMDAPUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1886	.1715			.12	.12
2		.1886	.1715			.12	.12
3		.2572	.1886			.12	.12
4		.3086	.2229			.1372	.1543
5		.3601	.2743			.1372	.1715
6		.3429	.3258			.2401	.1886
7		.3086	.4458		.4458	.2229	.2743
8	.4458	.2743	.3772		.3772	.2401	
9	.3086	.2401	.3086		.3086		
10	.1543	.1372		.1543	.1543	.2401	.2229
11	.1543	.1372			.1715	.1715	
12	.1543	.1715			.1715		.1372
13	.1029	.1715			.1543		.1715
14	.1029	.1372			.1715		
15	.12	.1372				.1715	
16	.12	.1715		.1372	.1372		.1543
17	.12	.1715			.1715	.1715	.1543
18	.2743	.2229		.1886	.1886	.1715	.1543
19	.3601	.3086			.2915		.1886
20	.3086	.3601		.2915	.3601		
21	.2743	.3086			.2743	.2915	
22	.2058	.2743			.2572	.2572	
23	.1886	.2229			.2229	.2401	
24	.1543	.1886	.2058		.1886	.1372	.1372
Max	.4458	.3601	.4458	.2915	.4458	.2915	.2743
Min	.1029	.1372	.1715	.1372	.1372	.12	.12
Avg	.2088	.2329	.2692	.1929	.2380	.1876	.1646

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154022 / 33/11 KV MAMDAPUR

Feeder No / Name : 203 / 11KV BHADGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3429	.3429			.2572	.3429
2		.3429	.3601			.2401	.3429
3		.3429	.3601			.2401	.3429
4		.3601	.3944			.2743	.4115
5		.3772	.4287			.3086	.463
6		.463	.6687			.463	.4973
7		.5316	.8573		1.1145	.5316	.5487
8	.3772	.6173	.7545		1.2517	.4801	
9	.6859		.6001		1.046		
10	.2743	.2915	.2572	.2058	.3772		.7545
11	.2401	.2058			.2572	.9774	
12	.1372	.1372			.2229		1.1488
13	.1029	.1543			.1886		1.2174
14	.1543				.2229	1.0974	
15	.1543					.9431	
16	.2058	.0686		.0857	.0686		1.1488
17	.2058	.0686				1.0974	1.166
18	.2229	.2915		.2401	.2743	.2229	.2572
19	.3429	.4115			.4115	.4801	.3429
20	.3601	.4287		.583	.463	.5487	
21	.3429	.3944			.3772	.5487	
22	.2743	.3429			.3944	.4458	
23	.2401	.3429			.3429	.3772	
24	.4287	.3429	.3772		.3601	.2572	.3429
Max	.6859	.6173	.8573	.583	1.2517	1.0974	1.2174
Min	.1029	.0686	.2572	.0857	.0686	.2229	.2572
Avg	.2794	.3266	.4910	.2787	.4608	.5153	.6218

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154022 / 33/11 KV MAMDAPUR

Feeder No / Name : 204 / 11KV SOLVANT

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4287	.3086	.2229	.1886	.2572	.1715
2		.4115	.3086	.2058	.1886	.2572	.1715
3		.4287	.2915	.2058	.1886		.1715
4		.3944	.2743	.2058	.1886		.1715
5		.3429	.2743	.2058	.1886	.2743	.1715
6		.3601	.2743	.2401	.1886		.1886
7		.3601	.2743	.2401	.1886	.2743	.1543
8		.2915	.2058	.2229	.1886	.2743	
9		.3258	.2058	.2058	.1886	.2572	
10		.3601	.2058	.2058	.1715	.2229	.1543
11		.3944	.2058	.2058	.1715	.2915	
12		.4458	.1886	.2058	.1715		.0686
13		.4458	.1715	.2058			.0686
14	.3601	.4458	.1886	.2058		.2743	
15	.3086	.4115	.1886	.2058		.3258	
16	.3086	.4458	.1886	.2058	.1715	.3258	.0686
17	.3258	.4115	.1886	.2058	.1715	.3258	.0857
18	.3944	.4115	.1886	.2058		.1886	.1029
19	.3944	.4287	.1886	.2058		.1715	.0857
20	.3258	.4287	.2058	.2058		.1543	
21	.3944	.4115	.2058	.2058		.1715	
22	.3772	.3772	.2058	.1886		.1715	
23	.4458	.3429	.2058	.1886	.2229	.1715	
24	.3258	.4287	.3601	.2229	.1886	.2572	.1715
Max	.4458	.4458	.3601	.2401	.2229	.3258	.1886
Min	.3086	.2915	.1715	.1886	.1715	.1543	.0686
Avg	.3601	.3972	.2293	.2094	.1854	.2446	.1338

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154033 / 33/11 KV BABHALGAON

Feeder No / Name : 201 / BARRAGE SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	19-MAR-17
HR	Load (MW)
22	.2469
Max	.2469
Min	.2469
Avg	.2469

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154033 / 33/11 KV BABHALGAON

Feeder No / Name : 204 / PTS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0343	.0381	.0377	.0343	.0381	
2	.0377	.0343	.0381	.0377	.0343	.0381	
3	.0377	.0343	.0381	.0377	.0343	.0381	
4	.0377	.0343	.0377	.0377	.0343	.0377	
5	.0377	.0343	.0377	.0377	.0343	.0377	
6	.0377	.0343	.0377	.0377	.0343	.0377	
7		.0343	.0377	.0377	.0343	.0377	
8		.0343	.0366	.0377	.0343		
9			.0343	.0354	.0377	.0343	.0366
10			.0343	.0366	.0377	.0343	.0377
11			.0343	.0366	.0377	.0343	.0377
12			.0343	.0373	.0377	.0343	.0373
13			.0343	.0373	.0377	.0343	.0373
14			.0343	.0377	.0377	.0343	
15			.0343			.0343	
16			.0343			.0343	
17	.0343	.0373	.0377	.0343	.0373		.0377
18	.0343	.0373	.0377	.0343	.0373		.0377
19			.0377	.0343			.0377
20	.0343		.0377	.0343	.0381		.0377
21	.0343		.0377	.0343	.0381		.0377
22	.0343		.0377	.0343	.0381		.0377
23	.0343		.0377	.0343	.0381		.0377
24	.0377	.0343	.0381	.0377	.0343	.0377	
Max	.0377	.0373	.0381	.0377	.0381	.0381	.0377
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0366
Avg	.0361	.0348	.0366	.0364	.0363	.0361	.0375



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154033 / 33/11 KV BABHALGAON

Feeder No / Name : 205 / 11KV BABHALGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8589	.583	.6478	.7468	.6516	.4207	
2	.9709	.583	.6478	.8215	.6859	.4801	
3	1.1203	.583	.7167	.9335	.7202	.5765	
4	1.2323	.6173	.8764	1.0082	.7716	.6241	
5	1.307	.6859	.9145	1.1203	.8573	.6661	
6	1.3443	1.0802	1.2574	1.1576	1.046	.7087	
7		1.5947	1.448	1.6804	1.4403	.9774	
8		1.3375	1.4098	1.587	1.3375		
9			1.046	1.6004	1.307	.8916	.9526
10			.4287	1.2757	.6203	.9431	1.0185
11			.5658	.6104	.6802	.6173	.7167
12			.6173	.57	.7773	.5658	.6859
13			.6173	.5487	.7449	.5316	.6287
14			.4973	.5487	.7449	.5316	
15			.5658	.5535		.4801	
16			.6516			.4801	
17	.3601	.6024	.6802	.7373	.9808		
18	.7202	.8299	.6722	.6344	.8676		
19			1.1203	1.046			1.2696
20	1.1317		1.1949	1.166	1.1812		1.251
21	.6687		1.0082	.9945	1.0669		1.2136
22	.6687		.8775	.8059	.8764		.9709
23	.6001		.7842	.7202	.8002		.8215
24	.7095	.5658	.6668	.6908	.6516	.3429	
Max	1.3443	1.5947	1.448	1.6804	1.4403	.9774	1.2696
Min	.3601	.5658	.4287	.5487	.6203	.3429	.6287
Avg	.8994	.8239	.8297	.9373	.8957	.6149	.9529

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154033 / 33/11 KV BABHALGAON

Feeder No / Name : 206 / 11KV DHANEGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.1715	.5658	.5601	.463	.5647	
2	.6348	.1886	.5658	.6722	.4801	.5647	
3	.7842	.1886	.7545	.7842	.5144	.6539	
4	.9335	.2058	.8764	.8589	.5487	.9054	
5	1.0456	.2572	.9526	.9335	.6173	1.1065	
6	1.1203	.4115	.9907	1.0456	.9602	1.3395	
7		.4458	1.1431	.9522	.7716	1.6956	
8		.3429	.9907	.8215	.5144		
9			.5144		.3734	1.4784	1.9006
10			.884		1.0059	.3944	
11			1.2651		1.4899	.2743	.4572
12			.5182	1.2378	1.656	.2401	.1905
13			1.4632	1.4746	1.4998	.1715	.1905
14			1.4022		1.4529	.1715	
15			1.4022	.9488		.2572	
16			1.3717			.2401	
17		1.186	1.5466	.5944	1.5971		.3547
18	.2229	.5658	.4294	.3772	.4904		.3547
19			.8029	.6344			.6908
20	.3429		.9149	.8573	.8383		.9149
21	.1029		.7842	.8059	.8002		.7655
22	.1886		.6535	.5658	.6859		.6722
23	.1715		.5601	.5144	.5716		.5601
24	.5041	.1715	.4954	.5041	.463	.6203	
Max	1.1203	1.186	1.5466	1.4746	1.656	1.6956	1.9006
Min	.1029	.1715	.4294	.3772	.3734	.1715	.1905
Avg	.5510	.3759	.9103	.7970	.8473	.6674	.6411

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154033 / 33/11 KV BABHALGAON

Feeder No / Name : 207 / 11KV SHELU SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8192	.0514	.3765	.5487	.5792	.1524	
2	.9175	.0514	.4054	.57	.6097	.1524	
3	1.0159	.0514	.4458	.6371	.6401	.1905	
4	1.0562	.0686	.4755	.6882	.6859	.2096	
5	1.1248	.0686	.535	.7373	.7316	.2286	
6	1.1873	.1029	.5937	.7701	.8078	.2477	
7		.463	1.0437	1.2146	1.1736	.2477	
8		.6249	1.1069	1.2308	1.2346		
9			.884		1.2967	.1715	.1905
10			.1029		.1886	.7621	.7876
11			.1029		.132	1.1584	1.0402
12			.1715		.0943	1.1888	1.1385
13			.1715		.1698	1.4232	1.1544
14			.1029	.1524	.2829	1.1126	
15			.1029	.1524		.884	
16			.1029			.9755	
17	.0857	.0953		.1372	.2858		1.3435
18	.1372	.0953	.0943	.0857	.1905		.0754
19			.132	.1543	.1524		.1132
20	.1715		.2263	.1886	.1905		.1886
21	.1372		.1886	.1715	.1905		.2263
22	.0514		.1698	.1715	.1524		.1886
23	.0686		.132	.1543	.1524		.1698
24	.7042	.0686	.3199	.4801	.5182	.1524	
Max	1.1873	.6249	1.1069	1.2308	1.2967	1.4232	1.3435
Min	.0514	.0514	.0943	.0857	.0943	.1524	.0754
Avg	.5751	.1583	.3473	.4580	.4754	.5786	.5514

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154040 / 33/11 KV TAKALI

Feeder No / Name : 201 / TAKLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6					.9054		.7377
7	1.2189	.8886	.8436	1.0167			
8						.6706	
10	.3772	.2622					
11						.8535	.9465
12	.1524						
13		.081					.8655
14							.8655
16				.1029			
17	.1928	.1457					.8655
18			.1564	.2035		.1715	
19						.3944	
20			.5475				
21	.2743						
22	.2641		.3128				.284
24							.1844
Max	1.2189	.8886	.8436	1.0167	.9054	.8535	.9465
Min	.1524	.081	.1564	.1029	.9054	.1715	.1844
Avg	.4133	.3444	.4651	.4410	.9054	.5225	.6784

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154040 / 33/11 KV TAKALI

Feeder No / Name : 202 / KATGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6					.8916		1.7368
7	.7253	.9259	.4744	.7916			
8						1.1069	
10	1.0898	.8048					
11						.2883	.1646
12	2.1262						
13		.9614		1.6263			.1317
14						.2058	.1317
16				1.6448			
17	1.3889	.0832	1.4937				.1646
18	.8848		.2614	.2715		.2715	
19						.5243	
20			.475				
21	.4115						
22	.3801		.3166				.2469
24							.8139
Max	2.1262	.9614	1.4937	1.6448	.8916	1.1069	1.7368
Min	.3801	.0832	.2614	.2715	.8916	.2058	.1317
Avg	1.0009	.6938	.6042	1.0836	.8916	.4794	.4843

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154040 / 33/11 KV TAKALI

Feeder No / Name : 203 / RAMESHWAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	21-MAR-17
HR	Load (MW)
6	.4858
Max	.4858
Min	.4858
Avg	.4858

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154040 / 33/11 KV TAKALI

Feeder No / Name : 204 / 11 KV BHOISAMUDRA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6					1.2717		.5716
7	1.5718	1.251	1.5623	.905			
8						.1955	
10	.2241	.2286					
11							.6859
12	.1715						
13							.4763
14							.4763
16				.2263			
17	.2667	.1572	.1715				.5239
18			.1905	.2858		.2286	
19						.3772	
20			.3319				
21	.3547						
22	.3395		.1915				.2281
24							.2667
Max	1.5718	1.251	1.5623	.905	1.2717	.3772	.6859
Min	.1715	.1572	.1715	.2263	1.2717	.1955	.2281
Avg	.4881	.5456	.4895	.4724	1.2717	.2671	.4613

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154040 / 33/11 KV TAKALI

Feeder No / Name : 205 / 11 KV GANJUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6					.3721		.6908
7	.3429	.4001	.381	.4001			
8						.7287	
10	.6001	.3086					
11							.1334
12	.7045						
13		.381					.0953
14							.0953
17	.1865	.6668					.0953
18				.0762		.132	
19						.2641	
20			.2858				
21	.1886						
22	.1524		.1524				.1905
24							.4294
Max	.7045	.6668	.381	.4001	.3721	.7287	.6908
Min	.1524	.3086	.1524	.0762	.3721	.132	.0953
Avg	.3625	.4391	.2731	.2382	.3721	.3749	.2471



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154040 / 33/11 KV TAKALI

Feeder No / Name : 206 / 11 KV JEWALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6					.4938		.0876
7	.4287	.4763	.6478	.8002			
8						.0953	
10	.0953	.0381					
11							.9526
12	.0381						
13		.0381					.4763
14							.5239
17	.0572		.0381				.5239
18			.0572	.0377		.0366	
19						.0762	
20			.0572				
21	.0762						
22	.0572		.0286				.0762
24							.0543
Max	.4287	.4763	.6478	.8002	.4938	.0953	.9526
Min	.0381	.0381	.0286	.0377	.4938	.0366	.0543
Avg	.1255	.1842	.1658	.4190	.4938	.0694	.3850

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154050 / 33/11 KV BORI

Feeder No / Name : 201 / 11KV BORI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2743	.5868				
2	.2572		.381		.3429	.5144	
3	.2743	.3429	.2743		.3429		
4	.2743				.4115	.6859	
5	.3944	.4801	.4458		.5487		
6	.6859	.6173	.6859		.6859	.9259	
7	.7888		.8573				
8	.6516	.6859	.823			1.6118	
9			.6516	.4801	.6859		1.4403
10		.5144		.7545			.4801
11		.6859		1.166			.2743
12		.823		.9945		.2401	.2743
13	.7545	1.0288		1.3375	1.3375		.2058
14	.823	1.0631		1.4403			.2058
15	1.0288	1.2346			1.406		.2743
16		1.3375		1.4403	1.2346		.2743
17	.7545			1.5089			.2743
18	.4115	.3086		.2743	.3772		.3429
19		.5487		.5487			.4801
20	.5487			.6173	.583		.6173
21	.4801	.4458		.5487			
22	.4115			.4801	.3772		.4115
23		.2743					
24	.2401	.3429	.2572		.2743	.4801	
Max	1.0288	1.3375	.8573	1.5089	1.406	1.6118	1.4403
Min	.2401	.2743	.2572	.2743	.2743	.2401	.2058
Avg	.5316	.6475	.5514	.8916	.6621	.7430	.4273

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154050 / 33/11 KV BORI

Feeder No / Name : 202 / 11KV MUSHIRABAD SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1372	.12				
2	.1543				.1372	.4115	
3	.1543	.1715	.1715		.1715		
4	.1886				.2058	.5144	
5	.2743	.3086	.3086		.3086		
6	.5144	.4115	.3772		.4115	.7545	
7	.6173		.6516				
8	.5144	.5487	.5144			1.0631	
9			.3429	.3429	.5144		.9945
10	.4115	.4115		.4801			
11		.4458		.5487			.2058
12	.6859	.5144		.6173			.1372
13	.6173	1.6289			.823		.1372
14	.6173	.4801					.1372
15	.6173	.4801			.8059		.1372
16		.5487		.7545	.7888		.1372
17	.2058			.7545			.1372
18	.3086	.2058		.1372	.1715		.2058
19		.3086		.3086			.2743
20	.4115			.4801	.3772		.3429
21	.3429	.3086		.3086			
22	.2058			.2058	.2058		.2743
23		.1715					
24	.1372	.1372	.1372		.1715	.3772	.9945
Max	.6859	1.6289	.6516	.7545	.823	1.0631	.9945
Min	.1372	.1372	.12	.1372	.1372	.3772	.1372
Avg	.3745	.4246	.3279	.4489	.3917	.6241	.3166

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154050 / 33/11 KV BORI

Feeder No / Name : 203 / 11KV SALGARA

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	16-MAR-17	17-MAR-17	20-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)
8		.1372	
14	.0686		
24			.1029
Max	.0686	.1372	.1029
Min	.0686	.1372	.1029
Avg	.0686	.1372	.1029

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154050 / 33/11 KV BORI

Feeder No / Name : 204 / 11 KV SALGARA II

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4403	.4801	.7888				
2	1.4746				1.166	.7888	
3	1.5432	.5487	.9259		1.2346		
4	1.7147				1.3032	.8573	
5	1.9547	.6173	1.166		1.6461		
6	2.1948	.6859	1.2003		1.8519	1.2346	
7	2.4006		1.6461				
8	1.9547	.823	1.8861		1.8519	1.3375	
9	2.1262		1.8519	1.7833	1.8519		.6859
10		.7545		.6173			1.6461
11		.5487					2.1262
12	.2743	.4458		.4115			1.989
13	.2743	.4115		.4115	.4115		2.332
14	.2743	.2743		.3429			2.1262
15	.3429	.3429			.3086		2.1262
16				.3429	.3429		2.1948
17	.4115			.4115			2.1948
18	.4801	.4458		.4115	.4115		.2743
19		.8573		.6173			.7545
20				.823	.9259		.9602
21	.4801	.7888		.7545			
22	.4115			.6859	.7545		.7545
23		.6859					
24	1.3032		.6859		.9602	.7545	
Max	2.4006	.8573	1.8861	1.7833	1.8519	1.3375	2.332
Min	.2743	.2743	.6859	.3429	.3086	.7545	.2743
Avg	1.1698	.5807	1.2689	.6344	1.0729	.9945	1.5511

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154052 / 33/11 KV KAWA

Feeder No / Name : 201 / 11KV KAWA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1143	.1334	.1524	.1524	.3749	.3841
2	.1524	.1143	.1334	.1524	.1524	.3841	.4001
3	.1905	.1334	.1334	.1905	.1905	.3841	.421
4	.1905	.1524	.1715	.2477	.2286	.4534	.4534
5	.2477	.1334	.2096	.2477	.2096	.5182	.4915
6	.2667	.1905	.2667	.2858	.2477	.6154	.5636
7	.2858	.1905	.3048	.3239	.2667	.7125	.8288
8	.2667	.2286	.2858	.2667	.2667	.7773	.8785
9	.2667	.1905	.1715	.2286	.2286	.7125	.8029
10	.5376	.3239	.3441	.3841		.1715	.1715
11	.8381	.4534	.5079	.6154	.4858	.0762	.0953
12	.8855	.5344	.6316	.6316	.7125	.0953	.0762
13	.933	.664	.6154	.6478	.7449	.0953	.0762
14	.7968	.6964	.6316	.6081	.7449	.0762	.0762
15	.7116	.5668	.6154	.5921	.7611	.0762	.0762
16	.5146	.5506	.6718	.6802	.8421	.0953	.0762
17	.4967	.5992	.6882	.8097	.8421	.0953	.0762
18		.1334	.0953	.0953	.1334	.0953	
19		.2286		.2096	.2096	.1905	
20		.2286	.1905	.2096	.2096	.2477	
21	.1905	.2096	.1715	.1905	.2286	.2096	
22	.1715	.1905	.1715	.1905	.1905	.1715	.2096
23	.1334		.1524	.1715	.1715	.1715	.1715
24	.1524	.1143		.1524	.1524	.3281	.3086
Max	.933	.6964	.6882	.8097	.8421	.7773	.8785
Min	.1334	.1143	.0953	.0953	.1334	.0762	.0762
Avg	.3991	.3018	.3317	.3452	.3640	.2970	.3319

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154052 / 33/11 KV KAWA

Feeder No / Name : 202 / 11KV KHOPEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.1629	.104	.156	.1734	.1629	.1387
2	.2572	.1802	.1134	.156	.1734	.1448	.1387
3	.2401	.2149	.1214	.156	.1734	.1629	.156
4	.3086	.1976	.1214	.208	.208	.1448	.156
5	.3086	.1976	.1387	.2601	.2427	.1578	.1734
6	.3944	.2911	.156	.3294	.2774	.1715	.2254
7	.3772	.3778	.2601	.3294	.3121	.1886	.2427
8	.4458	.4366	.2947	.3294	.3467	.2058	.2254
9	.4458	.454	.2601	.3294	.3814	.1543	.1387
10	.1214	.3143	.104	.0693	.104	.2743	.2591
11	.104	.2044	.0867	.0693	.0867	.3641	
12	.104	.1629	.0693	.0693	.0867		.3725
13	.0867	.0693	.0867	.052	.0867	.2774	.2753
14	.052	.104	.0867	.052	.0867	.3814	.3401
15	.0693	.052	.0867	.0693	.0867	.3641	.3563
16	.0867	.052	.0693	.0693	.0867	.4161	.4001
17	.104	.0693	.0693	.0693	.0526	.4161	.4049
18	.104	.0693	.104	.1387	.0905	.104	
19	.1734	.208		.2254	.2075	.1907	
20	.1907	.2254	.2254	.208	.2075	.2254	.208
21	.156	.208	.208	.208	.2263	.2254	.208
22	.156	.1907	.1734	.1907	.2263	.1907	
23	.1387	.156	.1734	.1734	.1886	.1734	.1907
24	.2058	.0867	.1214	.156	.1734	.181	.156
Max	.4458	.454	.2947	.3294	.3814	.4161	.4049
Min	.052	.052	.0693	.052	.0526	.104	.1387
Avg	.2015	.1952	.1406	.1697	.1786	.2295	.2383

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154052 / 33/11 KV KAWA

Feeder No / Name : 203 / 11KV RAJIV NAGAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9416	.5594	.447	.5998	.6192	.2745	.2706
2	.9458	.5557	.4647	.6013	.6662	.2715	.2774
3	.9755	.5946	.467	.6127	.711	.2913	.2904
4	1.0121	.5851	.4739	.6119	.7217	.3041	.3072
5	1.1285	.5945	.4807	.6725	.7994	.4001	.3551
6	1.2586	.6334	.5234	.8309	.8821	.5525	.5495
7	1.1786	.804	.6567	1.0852	1.1262	.6074	.6173
8	1.4554	.8806	.5533	1.3127	1.2475	.5441	.5365
9	1.7141	.9455	.8935	1.4369	1.3388	.4885	.4573
10	1.3199	.7667	.7103	1.0418	1.0204	1.0865	1.1431
11	.231	.2705	.3161	.2492	.2949	1.2845	1.7768
12	.1883	.1829	.277	.1692	.1662	1.2908	1.8389
13	.1144	.1821	.2046	.1487	.1624	1.2746	1.8934
14	.1395	.1662	.1945	.1395	.1669	1.3228	1.9094
15	.1357	.173	.1978	.1357	.0191	1.4703	1.8324
16	.1494	.1563	.1985	.1464		1.5605	1.9368
17	.1304	.1586	.1825	.1448	.0191	1.6032	1.864
18	.2279	.2584	.1799	.1631	.1654	1.1386	1.259
19	.3429	.4436	.2782	.4077	.4077	.4077	.2888
20	.3529	.4618	.4131	.4239	.4892	.4671	.3612
21	.2443	.3742	.3521	.378	.4153	.3727	.3978
22	.2206	.3338	.346	.3117	.3452	.3452	.3277
23	.2107	.2965	.2881	.3033	.3011	.3406	.2973
24	.6405	.4756	.493	.5695	.392	.282	.2835
Max	1.7141	.9455	.8935	1.4369	1.3388	1.6032	1.9368
Min	.1144	.1563	.1799	.1357	.0191	.2715	.2706
Avg	.6358	.4522	.3997	.5207	.5425	.7492	.8780



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154071 / 33/11 KV GANGAPUR

Feeder No / Name : 201 / 11KV WASANGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1827	.6576	.8321	.9328	1.0494	.3021	.3217
2	1.382	.666	.8413	.9869	1.1465	.2945	.3082
3	1.3828	.7019	.8762	1.0266	1.2361	.3029	.3148
4	1.416	.7362	.8911	1.0597	1.3085	.2976	.3239
5	1.4956	.775	.9237	1.1622	1.4559	.314	.3528
6	1.6454	.8329	.9199	1.3294	1.5881	.3586	.3719
7	1.8141	.945	1.5027	1.7299	1.9612	.4031	.4016
8	2.1578	1.1911	1.892	2.0332	2.3045	.3639	.3273
9	2.1868	.7667	2.0492	2.3841	2.1509	.1517	.255
10	1.1435	.8548	1.2441	1.2742	1.3649	.9703	1.0784
11	.2077	.1933	.2252	.1631	.2199	.993	2.2359
12	.1905	.1964	.1833	.0865	.1993	1.5056	1.7912
13	.1493	.1556	.162	.155	.1753	1.6185	2.0873
14	.083	.0852	.1814	.123	.1676	1.6169	2.1471
15	.115	.137	.1597	.1913	.1775	2.2708	1.9639
16	.1097	.0876	.1608	.1688	.1764	2.2851	2.0724
17	.0274	.1427	.1559	.1459	.1513	2.3255	2.1875
18	.1482	.1351	.1665	.1634	.1597	1.4945	1.3412
19	.2652	.2903	.3006	.2846	.2614	.275	.2538
20	.2805	.3467	.3494	.3338	.354	.3782	.3624
21	.2835	.3433	.341	.3567	.354	.395	.3532
22	.2869	.3354	.3293	.3643	.3563	.3923	.3601
23	.2945	.3331	.3399	.3635	.3597	.3725	.3669
24	.4668	.5205	.6323	.6615	.6733	.3369	.3616
Max	2.1868	1.1911	2.0492	2.3841	2.3045	2.3255	2.2359
Min	.0274	.0852	.1559	.0865	.1513	.1517	.2538
Avg	.7798	.4762	.6525	.7284	.8063	.8341	.9142

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154071 / 33/11 KV GANGAPUR

Feeder No / Name : 202 / 11KV GANGAPUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.5487	.6471	.6173	.6344	.7373	.7888
2	.6516	.583	.6471	.583	.6516	.823	.8916
3	.7202	.6173	.7233	.583	.7545	.8916	1.0974
4	.9431	.6516	.7994	.6516	1.0631	1.0288	1.5089
5	1.046	.8402	1.2181	.7373	1.1831	1.2003	1.5432
6	1.3203	1.046	1.3133	1.2003	1.2346	1.4232	1.6461
7		1.2174	1.4275	1.286	1.3203	1.6461	1.8004
8	1.1488	1.046	1.3133	1.1317	1.0802	1.086	1.8004
9	.8402		1.0468	.6516	.9088		1.749
10	1.046	.571	.6173	.7373	.8573	.6091	.5658
11	1.6289	.9897	.6173	.8916	1.0802	.4568	.2743
12	.2572		1.0117	.9774		.3426	.2229
13	1.2346		1.0288	1.0631	.4115	.3045	.3601
14	1.2003		1.0631	1.0288	1.3717	.3426	.2801
15	.463	1.142	1.2003	1.0802	1.4918	.3045	.2801
16			1.2517	1.2174	1.5775	.3236	.2915
17		1.2942	1.2346	1.2517	1.5432	.3426	.2667
18		.6091	.463	.3429	.4115	.3426	.4973
19	.6173	.9897	.8916	.7202	.8745	.9897	.9774
20	.9602	1.0658	.9602	.9431	.9774	1.0658	.7468
21	.3944	.9707	.823	.8745	.8916	1.0087	.8402
22	.6001	.6852	.7373	.7373	.8059	.9136	.7716
23	.5658		.6516	.6859	.6173	.7233	.703
24	.6516	.5487	.6852	.6344	.6344	.6859	.7613
Max	1.6289	1.2942	1.4275	1.286	1.5775	1.6461	1.8004
Min	.2572	.5487	.463	.3429	.4115	.3045	.2229
Avg	.8471	.8565	.9322	.8595	.9729	.7649	.8610

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154071 / 33/11 KV GANGAPUR

Feeder No / Name : 203 / 11KV PETH SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2056	.5281	.445	.474	.7633	.7522	.7057
2	1.2315	.5327	.4745	.4855	.8505	.7331	.7308
3	1.278	.5426	.5016	.5403	.9453	.7841	.7712
4	1.582	.5975	.5374	.6371	1.0654	.8832	.9533
5	1.7596	.7049	.6141	.7567	1.2133	1.0113	1.1675
6	1.9978	.7979	.6804	1.0364	1.4267	1.2567	1.4128
7	2.2211	.993	1.0943	.5822	1.683	1.6263	1.6095
8	2.5251	1.2208	1.2348	1.4715	1.9963	1.7841	1.3389
9	2.5518	.7392	1.2382	1.5752	1.7268	1.1302	1.1507
10	1.5264	1.0129	1.0128	.9328	1.4075	1.2832	1.3481
11	.6744	.221	.5258	.8128	.7583	1.1744	1.7589
12	.5434	.0838	.3277	.6047	.5586	1.1229	1.7368
13	.4572	.6101	.6515	.6143	.5426	1.1158	1.7802
14	.4275	.521	.5487	.5396	.5251	.3844	1.3435
15	.3787	.3874	.3818	.5011	.4969	1.2251	.8642
16		.6124	.5518	.5533	.2896	1.1543	1.4266
17	.5792	.5642	.5586	.6006	.3048	.8659	2.1147
18	.7026	.7767	.7156	.6413	.6486	.7158	1.4601
19	.9435	1.2125	1.15	1.1401	1.0715	1.1196	1.0501
20	.9899	1.2552	1.2384	1.3767	1.3031	1.3303	1.2658
21	.8718	1.2721	1.1202	1.1827	1.1873	1.1943	1.1759
22	.695	1.0533	.9534	.9698	.9823	1.0168	.9915
23	.6462	.8513	.8055	.791	.8208	.8995	.8299
24	.7804	.6341	.6203	.6203	.7129	.7552	.7647
Max	2.5518	1.2721	1.2384	1.5752	1.9963	1.7841	2.1147
Min	.3787	.0838	.3277	.474	.2896	.3844	.7057
Avg	1.1552	.7385	.7493	.81	.9700	1.0549	1.2396

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154071 / 33/11 KV GANGAPUR

Feeder No / Name : 204 / K R REFINARY

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0191	.0191	.0191	.0171	.0191	.0191
2	.0171	.0191	.0191	.0191	.0171	.0191	.0191
3	.0171	.0191	.0191	.0191	.0171	.0191	.0191
4	.0171	.0191	.0191	.0191	.0171	.0191	.0191
5	.0171	.0191	.0191	.0191	.0171	.0191	.0191
6	.0171	.0191	.0191	.0191	.0171	.0191	.0191
7	.0171	.0191	.0191	.0191	.0171	.0191	.0191
8	.0171	.0191	.0191	.0191	.0171	.0191	.0191
9	.0171		.0191	.0171	.0191		.0191
10	.0191	.0191	.0191	.0171	.0191	.0191	.0191
11	.0191	.0191	.0191	.0171	.0191	.0191	.0191
12	.0191	.0191	.0191	.0171	.0191	.0191	.0191
13	.0191	.0191	.0191	.0171	.0191	.0191	.0191
14	.0191	.0191	.0191	.0171	.0191	.0191	.0191
15	.0191	.0191	.0191	.0171	.0191	.0191	.0191
16	.0191	.0191	.0191	.0171	.0191	.0191	.0191
17	.0191	.0191	.0191	.0171	.0191	.0191	.0191
18	.0191	.0191	.0191	.0171	.0191	.0191	.0191
19	.0191	.0191	.0191	.0171	.0191	.0191	.0191
20	.0191	.0191	.0191	.0171	.0191	.0191	.0191
21	.0191	.0191	.0191	.0171	.0191	.0191	.0191
22	.0191	.0191	.0191	.0171	.0191	.0191	.0191
23	.0191	.0191	.0191	.0171	.0191	.0191	.0191
24	.0171	.0191	.0191	.0191	.0171	.0191	.0191
Max	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0171	.0191	.0191	.0171	.0171	.0191	.0191
Avg	.0183	.0191	.0191	.0179	.0184	.0191	.0191

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154076 / 33/11 KV MANJARA KARKHANA

Feeder No / Name : 201 / 11KV CHINCHOLIRAOWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3334	.4287	.3048	.3601	.3086		.4973
2	.3601	.4287	.3353	.3772	.3772		.5487
3	.4877	.4458	.4287	.4287	.3944		.6859
4	.5639	.463	.5144	.6001	.4287		.8916
5	.6554	.4801	.6344	.9431	.463	.9145	1.0288
6	.7621	.463	.7373	1.166	.5144	1.0364	1.166
7	.7926	.4458	.7202	.9945	.5316	1.1736	1.286
8	.7888	.5144	.6001	.9602	.463	1.1126	1.0631
9	.5144	.4287	.5144	.743	.4458		
10	.8745	.3258	.3086	.5335	.7373	.2401	.2401
11	.6001	.4115	.3944	.5487	.9431		.2401
12	.6173	.3772	.4973	.5639	.9431		.2401
13	.6001	.3772	.5658	.6401	.9088		.2401
14	.5144			.6859	.823		.2401
15	.463	.5316	.5144	.7316	.7202		.2401
16	.4287	.703	.5658	.7926	.4458		.2058
17		.6401	.6516	.9088	.6249		
18	.463	.5335	.2915	.2572	.381		
19	.3944	.5639	.463		.5182	.5487	.6001
20	.4115	.5335	.5316	.2915	.5639	.6344	.503
21	.4115	.503	.6687	.3086	.4572	.4801	.4572
22	.3944	.3601	.5316	.3086	.3467	.4287	.3868
23	.4287	.2743	.0171	.2229	.3067	.3944	.3734
24	.3601	.4458	.2801	.3772	.2229	.4001	.463
Max	.8745	.703	.7373	1.166	.9431	1.1736	1.286
Min	.3334	.2743	.0171	.2229	.2229	.2401	.2058
Avg	.5313	.4643	.4814	.5976	.5362	.6694	.5523

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154076 / 33/11 KV MANJARA KARKHANA

Feeder No / Name : 202 / 11KV KHANDAPUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1145	.6001	.7716	.7716	.9945		.8745
2	1.2003	.6687	.9945	.9431	1.2174		.9431
3	1.3375	.703	1.1145	1.1145	1.3375		.9774
4	1.5261	.7716	1.3546	1.286	1.4575		1.166
5	1.9204	.8745	1.5775	1.4575	1.869	1.1831	1.286
6	2.1434	.9774	1.6289	1.5432	2.1776	1.3203	1.4575
7	2.1948	1.0288	1.6632	1.8861	2.3663	1.4575	1.6804
8	2.5206	1.1317	2.2805	2.2462	2.6578	1.4918	1.5089
9	2.4691	1.2003	2.0748	2.3491	2.6235		1.1488
10	.9602	.8745	1.1317	1.0802	.5487	1.1317	1.8004
11	.7202		1.0288	.8745	.7202		2.2462
12	.7716	.0857	.9259	.7202			1.3717
13	.5316	.0857	.823	.7373	.823		1.7147
14		.0857	.7888	.6859	.823		1.8176
15		.7202	.7716	.6516	.7202		2.3663
16		.9774	.7373	.6516	.6687		1.9204
17		.9774	.8059	.703	.823		2.572
18		1.2174	.9945	.8573	1.0288	.8573	1.286
19		1.286		1.1317	1.3717	1.2346	1.3717
20		1.3375	1.3546	1.3375	1.4403	1.4918	1.3889
21	.4801	1.3203	1.2689	1.406	1.3203	1.406	1.3203
22	.5658	1.166	1.166	1.3717	1.2003	1.2517	1.286
23	.6001	1.046	1.0631	.8573	1.1317	1.166	1.2517
24	.9945	.583	.703	.6687	.8916	1.0288	.9945
Max	2.5206	1.3375	2.2805	2.3491	2.6578	1.4918	2.572
Min	.4801	.0857	.703	.6516	.5487	.8573	.8745
Avg	1.2971	.8573	1.1749	1.1388	1.3136	1.2517	1.4896

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154076 / 33/11 KV MANJARA KARKHANA

Feeder No / Name : 203 / 11KV AGRAWAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1372	.1886	.12	.1543		.1372
2	.1543	.1372	.1715	.12	.1543		.1372
3	.1543	.1372	.1372	.12	.1715		.1372
4	.1715	.12	.12	.12	.1886		.1372
5	.1886	.12	.1372	.12	.2058	.1715	.1543
6	.2058	.12	.12	.1372	.2058	.1886	.1543
7	.2229	.12	.12	.1543	.1715		.1715
8	.2058	.12	.1372	.1372	.1715	.2058	.1886
9	.1886	.1886	.1029	.1886	.1543		.2058
10	.1886	.2229	.12	.2229	.1543	.1543	.2401
11	.2572	.2401	.12	.2229	.1543		.2915
12	.2743	.2572	.12	.2401	.1715		.2743
13	.2572	.2572	.1372	.2229	.1715		.2572
14	.2401	.2743	.1372	.2229	.1715		.2401
15	.2058	.2915	.1372	.2058	.1543		.2743
16	.1715	.2743	.1372	.2572	.1543		.2915
17	.1715	.3086	.12		.1715		.2229
18	.1715	.2229	.1372	.2229	.1715	.1886	.2229
19	.1715	.2058	.1372	.2058	.1886	.1715	.2058
20	.1372	.2229	.1372	.1715	.2058	.1715	.2229
21	.1372	.2229	.1372	.1543	.1886	.1543	.2058
22	.1543	.2058	.1372	.1372	.1886	.1543	.1886
23	.1372	.1886	.1372	.1715	.1886	.1372	.1715
24	.1886	.1372	.2058	.2058	.1715	.1886	.1372
Max	.2743	.3086	.2058	.2572	.2058	.2058	.2915
Min	.1372	.12	.1029	.12	.1543	.1372	.1372
Avg	.1886	.1972	.1372	.1774	.1743	.1715	.2029

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154076 / 33/11 KV MANJARA KARKHANA

Feeder No / Name : 204 / PANAN MAHASANGH NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0171	.0171	.0171	.0171		.0171
2	.0171	.0171	.0171	.0171	.0171		.0171
3	.0171	.0171	.0171	.0171	.0171		.0171
4	.0171	.0171	.0171	.0171	.0171		.0171
5	.0171	.0171	.0171	.0171	.0171	.0171	.0171
6	.0171	.0171	.0171	.0171	.0171	.0171	.0171
7	.0171	.0171	.0171	.0171	.0171	.0171	.0171
8	.0171	.0171	.0171	.0171	.0171	.0171	.0171
9	.0171	.0171	.0171	.0171	.0171		.0171
10	.0171	.0171	.0171	.0171	.0171	.0171	.0171
11	.0171	.0171	.0171	.0171	.0171	.0171	.0171
12	.0171	.0171	.0171	.0171	.0171	.0171	.0171
13	.0171	.0171	.0171	.0171	.0171	.0171	.0171
14	.0171	.0171	.0171	.0171	.0171		.0171
15	.0171	.7202	.0171	.0171	.0171		.0171
16	.0171	.0171	.0171	.0171	.0171		.0171
17	.0171	.0171	.0171	.0171	.0171	2.5206	.0171
18	.0171	.0171	.0171	.0171	.0171	.0171	.0171
19	.0171	.0171	.0171	.0171	.0171	.0171	.0171
20	.0171	.0171	.0171	.0171	.0171	.0171	.0171
21	.0171	.0171	.0171	.0171	.0171	.0171	.0171
22	.0171	.0171	.0171	.0171	.0171	.0171	.0171
23	.0171	.0171	.0171	.0171	.0171	.0171	.0171
24	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Max	.0171	.7202	.0171	.0171	.0171	2.5206	.0171
Min	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Avg	.0171	.0464	.0171	.0171	.0171	.1736	.0171



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154077 / 33/11 KV KOLPA

Feeder No / Name : 201 / 11KV MALVATI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4			.3658		
7					1.5851
8		.5228	.4268		
9			.3048		
10	1.0164				
11	1.3756				
12	1.6095	.9145			
16		.9145			
17					.362
19	.3772				
20	.415				
21	.415				
22	.415				
23	.415	.4458		.4801	
24	.3125				
Max	1.6095	.9145	.4268	.4801	1.5851
Min	.3125	.4458	.3048	.4801	.362
Avg	.7057	.6994	.3658	.4801	.9736

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154077 / 33/11 KV KOLPA

Feeder No / Name : 202 / 11KV KOLPA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4			.6097		.2743
7					.3658
8			.9145		
9			.7926		
10	.2263				
11	.2263				
12	.2263	.2134			
16		.1829			
17					.8954
19	.3395				
20	.3395				
21	.3395				
22	.3395				
23	.3395	.3429		.3772	
24	.2629				
Max	.3395	.3429	.9145	.3772	.8954
Min	.2263	.1829	.6097	.3772	.2743
Avg	.2933	.2464	.7723	.3772	.5118

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154077 / 33/11 KV KOLPA

Feeder No / Name : 203 / 11KV BHATKHEDA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4			.4572		.1829
7					.3048
8		.3772	.6706		
9			.5487		
10	.2263				
11	.1886				
12		.061			
16		.1219			
17					.9412
22	.2587				
23	.2263	.2401		.2401	
24	.2629				
Max	.2629	.3772	.6706	.2401	.9412
Min	.1886	.061	.4572	.2401	.1829
Avg	.2326	.2001	.5588	.2401	.4763

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154094 / 33/11 KV BHATANGALI

Feeder No / Name : 201 / 11KV BHATANGALI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0343	.0343	.0377	.0381	.373	.1981
2	.0377	.0343	.0343	.0377	.0381	.373	.1981
3	.0377	.0343	.0343	.0377	.0381	.3814	.2286
4	.0377	.0343	.0343	.0377	.0377	.407	.2439
5	.0377	.0343	.0343	.0377	.0377	.4854	.3048
6	.0377	.0335	.0343	.0377	.0373	.4681	.3658
7	.0377	.0316	.0343	.0377	.0373	.5548	.4268
8	.0377	.032	.0343	.0377	.0366	.5548	.4877
9	.0305	.0377	.0362	.0366	.0343	.5087	.3864
10	.3353	.0446	.2782	.2934	.3353		.0373
11	.3506	.044	.3913	.4401	.4877		.0373
12	.442	.3963	.4401	.4401	.5182		.0373
13	.0343	.4268	.4344	.4633	.5335		.037
14	.381	.3763	.4199	.4633	.5182		
15	.381	.3353	.423	.4633	.503		
16	.3963	.3658	.4572	.4988	.5335		
17	.3338	.381	.4458	.5335	.5935		.0373
18	.037	.0343	.0373	.0324	.0339		.0377
19	.0377	.0343	.0377	.0381	.0339	.0343	.0377
20	.0377	.0343	.0377	.0377		.0343	.0377
21	.0377	.0343	.0373	.0377	.0347	.0343	.0377
22		.0343	.0377	.0377	.0347	.0343	.0377
23	.0358	.0343	.0377	.0377	.0347	.0343	.0377
24	.0377	.0339	.0343	.0377	.0381	.3467	.1829
Max	.442	.4268	.4572	.5335	.5935	.5548	.4877
Min	.0305	.0316	.0343	.0324	.0339	.0343	.037
Avg	.1396	.1215	.1608	.1747	.1986	.3083	.1636

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154094 / 33/11 KV BHATANGALI

Feeder No / Name : 202 / 11KV CHIKHALTHANA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3906	.1981	.2286	.3841	.3887		
2	.421	.1981	.2286	.4001	.3887		
3	.4481	.1981	.2439	.421	.4049	.017	
4	.4801	.1981	.2591	.4481	.4049		
5	.5441	.2134	.2743	.4481	.426	.0173	
6	.5761	.216	.3048	.4961	.3932		
7	.6081	.2915	.3353	.4801	.5636		
8	.3201	.3361	.4268	.4961	.5601		
9	.3658	.3281	.2812	.4877	.5335		
10		.0152				.4321	.3963
11		.0152					.4725
12							.5639
13		.0152					.5944
14		.0152					
15		.0152					
16		.0152					
17			.0152			.5792	.6405
18			.0152				.0152
19			.0152				.0152
20			.0152				.0152
21			.0152				.0152
22			.0152				.0152
23			.0152				.0152
24	.3795	.1981	.2439	.3563	.0171	.017	
Max	.6081	.3361	.4268	.4961	.5636	.5792	.6405
Min	.3201	.0152	.0152	.3563	.0171	.017	.0152
Avg	.4534	.1542	.1725	.4418	.4081	.2125	.2508

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154094 / 33/11 KV BHATANGALI

Feeder No / Name : 203 / 11KV BAMNI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2056	.2286	.2591	.2458	.104	.1029
2	.3201	.2134	.2286	.2915	.2818	.1017	.1029
3	.3521	.2267	.2439	.3887	.285	.104	.1372
4	.4858	.2267	.2743	.4858	.285	.0133	.1372
5	.502	.2321	.3048	.5182	.3018	.1357	.1715
6	.5571	.3149	.4268	.5344	.4359	.1387	.1886
7	.5967	.4694	.5487	.5506	.6036	.1734	.2058
8	.2949	.5571	.5335	.4858	.5182	.1907	.2229
9	.3963	.4641	.4725	.503	.4725	.1907	.1543
10	.12	.0876	.052	.0514	.12	.381	.3395
11	.1029	.0709	.0509	.0514	.1029		.4902
12	.1029	.0701	.0351	.0343	.1029		.4999
13	.0686	.0537		.0343	.1029		.1715
14	.0686	.0543	.0554		.0686		
15	.0686	.0543	.0554	.0362	.0686		
16	.0857	.0543	.0549	.0537	.0686	.506	
17	.0532	.0514	.056	.0366	.1017	.503	.5441
18	.0886	.12	.0914	.0543	.1187	.1029	.0709
19	.1595	.1543	.1417	.1227	.1214	.1543	.1402
20	.1063	.1715	.1578	.1387	.1357	.1715	.1595
21	.1063	.1543	.1402	.1227	.1387	.1543	.1402
22	.1063	.1543	.1227	.0876	.1387	.1543	.1227
23	.0724	.1372	.1063	.0701	.1187	.1372	.1052
24	.2591	.1562	.2134	.2214	.2458	.1017	.1029
Max	.5967	.5571	.5487	.5506	.6036	.506	.5441
Min	.0532	.0514	.0351	.0343	.0686	.0133	.0709
Avg	.2228	.1856	.1998	.2232	.2160	.1852	.2052

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 201 / 11KV DOOT

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.2572			.1715		
4		.2572			.2058		
6		.2572		.2926	.2401		
7			.2926	.2378		.2926	
8	.3113	.3086	.3658	.2561	.2915	.3292	
9	.3277	.3658	.3429				
10	.4748		.3601				
11	.724	.5487			.3841		
12	.743	.6401	.3944				
13					.0914		
14		.4938	.3944				
15					.4572		
16	.4458	.567	.1715	.6859	.4938		
17		.5853			.4572		
18	.4115	.5121	.2195	.6173	.3658		.6584
19							.6219
20	.4458	.4755	.2378	.6001	.2743		
21			.2561				.3841
22	.2743	.3658			.2195		
23		.2926	.1829		.1829		.2926
24	.2713	.2572	.2743	.1646	.1886		.3391
Max	.743	.6401	.3944	.6859	.4938	.3292	.6584
Min	.2713	.2572	.1715	.1646	.0914	.2926	.2926
Avg	.4430	.4123	.2910	.4078	.2874	.3109	.4592

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 202 / 11KV AIRPORT

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.4287			.5487		
4		.4287			.583		
6		.5658		.7343	.6516		
7			.8059	.9313		.8954	
8	1.1241	.6516	.8954	.9492	.9945	.9313	
9	1.105	.6089	.9945				
10	1.3717		.8573				
11	1.2193	.8059			.9134		
12	1.2765	.7522	.7888				
13					.7522		
14		.4656	.7373				
15					.5373		
16		.8238	.823	.8402	.7164		
17					.6268		
18	.2058	.7522	.7701	1.046	.5373		.8596
19							.9671
20	.4287	.8059	1.0745	.9602	.8779		
21			.8596				.8238
22	.4287	.6447			.6805		
23		.4656	.4477		.5373		.5731
24	.5079	.4287	.394	.4656	.5316		
Max	1.3717	.8238	1.0745	1.046	.9945	.9313	.9671
Min	.2058	.4287	.394	.4656	.5316	.8954	.5731
Avg	.8520	.6163	.7873	.8467	.6778	.9134	.8059



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 203 / 11KV KALANTRI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.2058			.1029		
4		.2401			.1029		
6		.2401		.1886	.1372		
7			.2641	.1886		.1905	
8	.1638	.2743	.2263	.1509	.1715	.1905	
9	.2294	.3395	.2743				
10	.3658		.3086				
11	.2374	.415			.1886		
12	.3391	.6036	.2743				
13					.1509		
14		.415	.1715				
15					.1886		
16	.4115	.6036	.2401	.4115	.2641		
17					.2286		
18	.3772	.6413	.2263	.3772	.1905		.2641
19							.2263
20	.3086	.415	.2263	.2401	.1905		
21			.2263				.1509
22	.2401	.2641			.1524		
23		.3395	.1886		.1524		.2641
24	.061	.2401	.2641	.1509	.1029		.0949
Max	.4115	.6413	.3086	.4115	.2641	.1905	.2641
Min	.061	.2058	.1715	.1509	.1029	.1905	.0949
Avg	.2734	.3741	.2409	.2440	.166	.1905	.2001

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 204 / SHANKARSHETH POLYMERS  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.0171			.0343		
4		.0171			.0343		
6		.0171		.0171	.0514		
7			.0171	.0171		.0164	
8	.0791	.0171	.0171	.0171	.0343	.0164	
9	.0633	.0171	.0171			.0171	
10	.0819		.0171				
11	.0848	.0171			.0171		
12	.0633	.0171	.0171				
13					.0171		
14		.0171	.0171				
15					.703		
16	.0343	.0171	.0171	.0171	.0171		
17		.0171			.0164		
18	.0171	.0171	.0171	.0171	.0164		.0171
19							.0171
20	.0171	.0171	.0171	.0343	.0164		
21			.0171				.0171
22	.0171	.0171			.0164		
23		.0171	.0171		.0164		
24	.0762	.0171	.0171	.0171	.0343		.0655
Max	.0848	.0171	.0171	.0343	.703	.0171	.0655
Min	.0171	.0171	.0171	.0171	.0164	.0164	.0171
Avg	.0534	.0171	.0171	.0196	.0732	.0166	.0292

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 205 / KANHAIYA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.12			.1372		
4		.12			.1372		
6		.1372		.1463	.1372		
7			.1463	.1463		.1463	
8	.1475	.12	.128	.128	.1029	.1646	
9	.1423	.128	.1372				
10	.2713		.1372				
11	.3189	.2012			.1463		
12	.443	.2012	.1372				
13					.1463		
14		.1463	.1372				
15					.1646		
16	.12	.1829	.1543	.3086	.1463		
17					.1463		
18	.1543	.1646	.1646	.2401	.1463		.2378
19							.2012
20	.12	.128	.1463	.1543	.1463		
21			.128				.1463
22	.1372	.1463			.1463		
23		.1646	.128		.1463		.1829
24	.1372	.12	.1646	.128	.1372		
Max	.443	.2012	.1646	.3086	.1646	.1646	.2378
Min	.12	.12	.128	.128	.1029	.1463	.1463
Avg	.1992	.1486	.1424	.1788	.1419	.1555	.1921

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 206 / Gajraj

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.6859			.0343		
4		.703			.8059		
6		.7373		.8775	.703		
7			.8962	.8215		.8775	
8	.9145	.703	.8589	.8402	.3258	.8962	
9	.9717	.7655	.7545			.823	
10	.8779		.7716				
11	.8779	.8775		.7122	.0377		
12	.9717	.9149	.7716				
13					.0377		
14		.8215	.7716	.7545			
15					.7655		
16	.7202	.8402	.7716	.7545	.8402		
17		.8029			.7842	.9145	
18	.8573	.8029	.7655	.8059	.7655		.9149
19							.8402
20	.7373	.7468	.8215	.823	.7655		
21			.7842				.8962
22	.2743	.8215			.7468		
23		.7095	.8402		.7468		.8962
24	.8596	.703	.8215	.8402	.8059		.8779
Max	.9717	.9149	.8962	.8775	.8402	.9145	.9149
Min	.2743	.6859	.7545	.7122	.0343	.823	.8402
Avg	.8062	.7757	.8024	.8033	.5832	.8778	.8851

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D(SOUTH)[640] BU 4640

Substation No/ Name :- 154113 / MEDICAL COLLEGE

Feeder No / Name : 201 / 11KV MEDICAL COLLEGE  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1753	.1387	.1463	.1387	.1372	.1372	.156
2	.1734	.1214	.1463	.1341	.1372	.1357	.1357
3	.1734	.12	.1494	.1341	.1372	.1357	.1341
4	.1543	.12	.1478	.1174	.1372	.1357	.1341
5	.1543	.1372	.168	.1341	.1372	.1357	.1357
6	.1886	.1372	.1478	.1478	.1372	.1848	.1357
7		.1478	.1646	.1646	.1417	.168	.1612
8		.1478	.1867	.1886	.1402	.2054	.2075
9		.2241	.1848	.1867	.1646	.2263	.2218
10	.2561	.2452	.2033	.2218	.1848	.2641	.2172
11	.2772	.2452	.2033	.2218	.1494	.2452	.2427
12	.2926	.2641	.2328	.2195	.1463	.2641	.2033
13	.2715	.2641	.197	.2218	.1612	.2263	.2033
14	.1867	.1829	.1612	.1646	.1448	.2263	.1848
15	.2033	.1791	.1629	.1494	.1433	.1848	.1829
16	.1829	.1848	.1829	.1646	.1646	.2012	.1791
17	.1829	.1663	.1402	.1463	.1629	.1612	.197
18	.1829	.1867	.1463	.1433	.1663	.1629	.1791
19		.1829	.1772	.1387	.181	.1612	.2012
20	.1612	.1848	.1543	.156	.1867	.1791	.181
21	.1629	.168	.181	.1629	.1848	.1791	.2012
22	.1629	.1663	.1612	.1372	.181	.1629	.1829
23	.1417	.168	.156	.1372	.1578	.1772	.1791
24	.1949	.1417	.1478	.1326	.1372	.1595	.1578
Max	.2926	.2641	.2328	.2218	.1867	.2641	.2427
Min	.1417	.12	.1402	.1174	.1372	.1357	.1341
Avg	.1940	.1760	.1687	.1610	.1551	.1842	.1798

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D(SOUTH)[640] BU 4640

Substation No/ Name :- 154113 / MEDICAL COLLEGE

Feeder No / Name : 202 / 11KV MARKET YARD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9997	.8676	.9328	.9431	1.0185	1.0374	1.1506
2	.9619	.8299	.924	.9054	.9808	1.0185	1.0751
3	.9619	.8299	.8779	.8676	.9431	.9808	1.0751
4	.9431	.8488	.8316	.8865	.9431	.9997	1.0751
5	.9997	.8676	.8596	.9054	.9997	1.0562	1.1128
6	1.1694	1.0374	1.0059	1.0751	1.0456	1.1883	1.2637
7		1.1389	1.1041	1.251	1.0829	1.2826	1.2449
8		1.0719	1.086	1.0059	1.0456	1.1203	1.1157
9		1.0903	.8962	1.0242	.9877	1.0534	1.0903
10	1.4864	.9412	.9709	.9774	1.0136	1.0288	1.086
11	1.4299	1.0059	1.0349	1.0924	1.0242	1.0517	1.1104
12	1.2536	.8869	1.1273	1.0924	.9745	1.1041	1.182
13	1.2071	.905	.964	1.0974	.9774	1.0208	1.0387
14		1.0903	.9979	1.0349	.9214	1.0498	1.0208
15	1.2308	1.0719	.9979	1.0791	.985	1.1157	1.0208
16	1.2071	1.0425	1.0082	1.0791	.9774	1.0791	1.1523
17	1.2197	1.1041	.9979	1.0745	.9511	1.1765	1.3032
18		1.3717	1.0631	1.0631	.9774	1.1641	1.3213
19		1.4998	1.3306	1.5203	1.2803	1.6289	1.7193
20	1.4784	1.448	1.2567	1.4998	1.1999	1.6278	1.6461
21	1.423	1.3121	1.307	1.386	1.2851	1.5339	1.5154
22	1.1458	1.1706	1.2136	1.307	1.3392	1.46	1.4784
23	.9522	1.0498	1.0751	1.1763	1.226	1.3443	1.3817
24	1.0374	.8962	.9774	1.1523	1.094	1.1128	1.1694
Max	1.4864	1.4998	1.3306	1.5203	1.3392	1.6289	1.7193
Min	.9431	.8299	.8316	.8676	.9214	.9808	1.0208
Avg	1.1726	1.0574	1.0350	1.1040	1.0531	1.1765	1.2229

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D(SOUTH)[640] BU 4640

Substation No/ Name :- 154113 / MEDICAL COLLEGE

Feeder No / Name : 203 / 11KV KANHERI ROAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6224	.5281	.5304	.547	.6036	.5658	.6036
2	.6036	.5093	.5304	.5281	.5121	.5281	.5847
3	.6036	.5093	.5068	.5093	.5281	.5093	.5847
4	.5847	.5093	.499	.5093	.5658	.4904	.5847
5	.6413	.5093	.5487	.5281	.5658	.6036	.6602
6	.7733	.6979	.5973	.6413	.7167	.7733	.8488
7		.7545	.695	.7733	.6979	.811	.8488
8		.7167	.6468	.7468	.7356	.6979	.7282
9		.6413	.5847	.6653	.6653	.679	.6722
10	.9593	.5729	.5658	.6036	.6722	.6626	.6447
11	.8048	.6283	.4715	.5601	.6878	.6468	.7602
12	.724	.6653	.4904	.6401	.591	.6099	.6335
13	.7577	.6468	.4954	.4805	.6584	.6036	.6697
14	.5304	.6224	.4904	.4805	.6268	.6468	.724
15		.5847	.5281	.6767	.6697	.6838	.7421
16	.724	.5975	.5281	.6468	.6024	.695	.7133
17	.6401	.7023	.5847	.6154	.5611	.6767	.7865
18	.695	.8048	.5729	.5847	.6468	.7316	.8413
19		.961	.8215	.905	.7602	.9328	1.0425
20	.8131	.8779	.7545	.8779	.823	.8871	.9795
21	.7023	.7783	.7545	.7762	.7783	.8316	.8962
22	.6535	.695	.6979	.7922	.7356	.7733	.8402
23	.5788	.6468	.5847	.679	.679	.7167	.7356
24	.6224	.5658	.5729	.547	.6413	.5847	.5847
Max	.9593	.961	.8215	.905	.823	.9328	1.0425
Min	.5304	.5093	.4715	.4805	.5121	.4904	.5847
Avg	.6860	.6552	.5855	.6381	.6552	.6809	.7379

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D(SOUTH)[640] BU 4640

Substation No/ Name :- 157001 / 132 KV KOYANA

Feeder No / Name : 207 / 11 KV SAI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	19-MAR-17	20-MAR-17
HR	Load (MW)	Load (MW)
1	.5068	.5068
2	.4801	.4763
3	.4572	.4649
4	.4496	.4572
5	.4534	.4725
6	.4839	.5068
7	.5563	.5677
8	.6173	.5982
9	.6478	.602
10	.5982	.6059
11	.5525	.4458
12	.503	.4115
13	.4839	.381
14	.4458	.3925
15	.3772	
16	.3887	
17	.3772	
18	.4191	
19	.4915	
20	.663	
21	.644	
22	.5906	
23	.5868	
24	.5601	
Max	.663	.6059
Min	.3772	.381
Avg	.5139	.4921



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 201 / 11 KV MURUD URBAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.823
2							.7926
3							.8535
5	1.448	1.1949		1.2955	1.1389		
6	1.448	1.6991		1.4937			
7	1.6461	1.885		1.6766	1.848		
8	1.5699	1.8111		1.5546	1.8665		1.4327
9				1.3717		1.1584	
10	1.3969		1.423	1.1431			1.922
11		.8688	1.251	1.1431			
12				.945			1.1827
13	1.2445	.9145		.9602		.945	
14				.945			1.0719
15				.8688		.9145	
16		.9145	1.0642	.9755		.9297	1.1763
17	1.0642	.7522	.884	1.1643			.9602
18	1.3957						
19	1.6617			1.773		1.647	
20		1.957	1.4175	1.7551		1.7556	1.5546
21	1.363					1.1431	
22	1.1317			1.0642		1.0212	
23	1.0751	.8962				.9297	
24	1.0751	.8215		.9431			.884
Max	1.6617	1.957	1.423	1.773	1.8665	1.7556	1.922
Min	1.0642	.7522	.884	.8688	1.1389	.9145	.7926
Avg	1.3477	1.2468	1.2079	1.2396	1.6178	1.1605	1.1503

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 202 / 11 KV MURUD RURAL FEEDER FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

DATE	16-MAR-17	17-MAR-17	18-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.4115
2				.381
3				.4877
8				.7926
10			.4115	
11	.503	.4481	.4877	
12			.6097	
13	.7011		.6249	
14			.6401	
15			.6401	
16	.7773	.7577		
17	.7907	.6401	1.0534	
24				.2743
Max	.7907	.7577	1.0534	.7926
Min	.503	.4481	.4115	.2743
Avg	.6930	.6153	.6382	.4694

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 203 / 11 KV DHORALA FEEDER  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.3048
2							.3201
3							.3048
5	.7773			.2286	.3734		
6	.8078						
7	.8383			.2286	.5601		
8	1.0059			.0152	.6908		.4725
9				.3048		.3506	
10	.6401			.4115			.6099
11				.3201			
12				.3048			1.1949
13	.9061			.3353			
14				.381			.8688
15				.442		.7316	
16		.3353	.4066	.4725		.7621	.9979
17		.4218	.381	.6161		.8688	.823
24				.3734			.2286
Max	1.0059	.4218	.4066	.6161	.6908	.8688	1.1949
Min	.6401	.3353	.381	.0152	.3734	.3506	.2286
Avg	.8293	.3786	.3938	.3411	.5414	.6783	.6125

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 204 / 11 KV Gumphwadi FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.0457
2							.0457
3							.061
5	.0914	.0739		.0914	.0924		
6	.1067	.0739		.1067			
7	.1067	.0739		.1219	.1109		
8	.0914	.0739		.1677	.1629		.0914
9				.1677		.1372	
10	.0747		.1494	.1219			
11		.1219	.1294	.1067			
12				.1372			.1848
13	.0747	.1219		.1219			
14				.2286			.1086
15				.1372			
16		.3174	.2614				.1267
17		.1494	.2591	.2614			.0762
18	.0934						
19	.0747			.1867		.0934	
20		.1294	.1219	.1307		.2054	.1219
21	.1132					.1372	
22	.112					.1219	
23	.0934	.0924				.0762	
24		.0724		.0754			.061
Max	.1132	.3174	.2614	.2614	.1629	.2054	.1848
Min	.0747	.0724	.1219	.0754	.0924	.0762	.0457
Avg	.0938	.1182	.1842	.1442	.1221	.1286	.0923

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 205 / 11 KV WATAWADA FEEDER  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	17-MAR-17
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 206 / 11 KV KARKATTA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.0914
2							.0914
3							.1372
5	.1524	.168		.1524	.1494		
6	.1677	.2241		.1829			
7	.2286	.2957		.2591	.2772		
8	.1677	.2402		.2134	.2614		.2134
9						.1372	
10	.1494		.1848	.1219			
11		.0305	.168	.0457			
12				.0914			.1086
13	.0747	.061		.0914			
14				.0762			.1267
15				.1524			
16		.0754	.1267				.0724
17		.1646	.1677	.1848			.0762
18	.0943						
19	.1494			.0934		.2054	
20		.2195	.1981	.2054		.2218	.1981
21	.112					.1677	
22	.0183					.1524	
23	.0747	.1109		.1132		.0914	
24		.0747		.0934			.0762
Max	.2286	.2957	.1981	.2591	.2772	.2218	.2134
Min	.0183	.0305	.1267	.0457	.1494	.0914	.0724
Avg	.1263	.1513	.1691	.1385	.2293	.1627	.1192

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 207 / 11 KV KARKATTA-AG-FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-17	16-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.0762
2						.0914
3						.0762
5	1.3717	.8215	.0914	.8775		
6	1.4784	.8402	.0914			
7	1.5699	1.1389		.924		
8	1.6918	1.2012	.1067	1.386		
9			.1067			
12						1.7013
14						1.3213
16						1.4415
17					1.5581	1.2193
21	.0943				.0914	
22	.0934				.0762	
23	.0934				.0762	
24		.6908	.8402			.0762
Max	1.6918	1.2012	.8402	1.386	1.5581	1.7013
Min	.0934	.6908	.0914	.8775	.0762	.0762
Avg	.9133	.9385	.2473	1.0625	.4505	.7504

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 208 / 11 KV GUMPHAWADI -AG-

FEEDER SEPERATION/PURE AG

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.2286
2						.2439
3						.2286
8						.4268
9					.3658	
10	.4858			.6859		
11			.1494	.2286		
12				.2591		
13	.6874			.3048		
14				.381		
15				.2743		
16		.2286	.2772			
17		.2458	.2286	.3174		
24						.1829
Max	.6874	.2458	.2772	.6859	.3658	.4268
Min	.4858	.2286	.1494	.2286	.3658	.1829
Avg	.5866	.2372	.2184	.3502	.3658	.2622



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 209 / 11 KV HOSPITAL (SEPERATE) NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	16-MAR-17
HR	Load (MW)
17	.0187
20	.0189
23	.0185
Max	.0189
Min	.0185
Avg	.0187

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154005 / 33/11 KV MURUD-AKOLA

Feeder No / Name : 201 / 11 KV MURUD AKOLA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2631		.4115			.3772	
2	1.2955		.4207			.3772	
3	1.3603		.4115			.3772	
4	1.4251		.4287			.5144	
5	1.4251		.5144			.7202	
6	1.8138		.6173				
7	2.1376		.6516			1.0288	
8	2.2672		.6516		1.0883		.8421
9	.7773	.1886	.6783		1.1271	.2058	.583
10	.6478	.1886	.6104		1.0277	.1029	.1296
11	.2614	.1543		.2401	.3944	.4049	1.3279
12	.3077	.2915		.2743	.3429		1.5546
13	.2926	.3429			.2915		1.5546
14		.4287			.2743		1.4251
15		.3086			.1029		1.4251
16		.3601			.2743		1.3927
17		.4287			.3086		1.4251
18					.3772		1.3603
19					.5487		.6802
20		.5144			.7716		.6802
21		.5144			.6516		.6478
22		.4458			.5144		.4858
23					.4458		.4534
24	.4534						
Max	2.2672	.5144	.6783	.2743	1.1271	1.0288	1.5546
Min	.2614	.1543	.4115	.2401	.1029	.1029	.1296
Avg	1.1234	.3472	.5396	.2572	.5338	.4565	.9980

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154005 / 33/11 KV MURUD-AKOLA

Feeder No / Name : 202 / 11 KV BHOYRA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2058		.1372	
2	.5967		.2058		.1372	
3	.6962		.2401		.1372	
4	.7956		.3258		.1715	
5	.8288		.3772		.2401	
6	.8951		.3772			
7	.9945		.4115		.3086	
8	1.1271		.4801	.6443		.2652
9	1.0608	.1372	.5087	.6859	.2058	.1658
10	.9282		.4458	.6588	.1372	.1326
11	.0754	.3772		.0857		.7956
12	.0934	.4801		.0857		.7625
13	1.5684	.4458		.0686		.7293
14		.4287		.0686		.7293
15		.4458		.0857		.7293
16		.4801		.0857		.7293
17		.4115		.1029		.7956
18				.1372		.7956
19		.1372		.2229		.2652
20		.2401		.2572		.2652
21		.2229		.2401		.2321
22		.2229		.2058		.1989
23				.1715		.1989
24	.1658					
Max	1.5684	.4801	.5087	.6859	.3086	.7956
Min	.0754	.1372	.2058	.0686	.1372	.1326
Avg	.7558	.3358	.3578	.2379	.1844	.4869

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154005 / 33/11 KV MURUD-AKOLA

Feeder No / Name : 203 / 11 KV RAMEGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2058	
2				.2401	
3				.2572	
4				.3086	
7				.4287	
8					.503
9				.4115	.4877
10				.4287	.4572
11	.5636				
12	.5967				
13	.663		.2743		
14		.2401	.2743		
15		.2743	.3086		
16		.2915	.3086		
17		.3086	.3086		
18			.4801		
Max	.663	.3086	.4801	.4287	.503
Min	.5636	.2401	.2743	.2058	.4572
Avg	.6078	.2786	.3258	.3258	.4826

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154017 / 33/11 KV GADWAD S/S

Feeder No / Name : 201 / 11 KV GADWAD SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.905	.724	.7164		.362
2		.362	1.0745	.905	.8954		.362
3		.362	1.086	1.0745	1.0745		
4			1.0745	1.0745	1.0745		
5		.543	1.2536	1.2536	1.2536		
6		.543	1.2536	1.2536	1.2536		
7		.543	1.2536	1.2536	1.4327		
8			1.2536	1.5223	1.4327	.543	
9	1.97		1.2536	1.4327	1.4327		.543
10	.3086		.4477	.3582	.3086		.724
11	.3086		.362	.3582	.3086		1.7909
12	.362		.362	.3582	.3086		1.6004
13	.2715		.362	.3582			1.7909
14				.3582			1.97
15		.1619	.362	.3582			1.97
16		1.086	.2715	.3582		1.3575	1.97
17		.4525		.3582			1.7909
18				.3582			.4525
19		.543		.5373			.543
20	.2715	.543		.5373			.6335
21		.543		.5373			.543
22	.2686	.4525		.5373			.543
23	.2715	.4525		.4477			.4525
24		.2715	.6335	.543	.5373	.362	.362
Max	1.97	1.086	1.2536	1.5223	1.4327	1.3575	1.97
Min	.2686	.1619	.2715	.3582	.3086	.362	.362
Avg	.5040	.4899	.8255	.7024	.9253	.7542	1.0224

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154017 / 33/11 KV GADWAD S/S

Feeder No / Name : 202 / 11 KV JAWALA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.081	.081	.081	.08		.2429
2		.081	.081	.081	.08		.3239
3		.081	.0781	.081	.08		
4			.3239	.081	.08		
5		.081	.0781	.081	.08		
6			.081	.081	.08		
7		.081	.081	.081			
8		.081	.081	.08	.08	.4858	
9	.08	.081	.081	.08			.3239
10	.1543		.081	.3201			.081
11	.5468		.1619	.3201			.081
12	.6401	.1619	.081	.3201			.081
13	.6401		.3239	.3201			.081
14		.1619		.3201			.081
15			.3239	.3201			.081
16		.1619	.3239	.3201		.081	.081
17		.1619		.3201			.081
18	.081	.081		.08			.081
19	.081	.081		.08			
20	.081	.081		.08			.081
21		.081		.08			.081
22	.081	.081		.08			.081
23	.081	.081		.08			.081
24		.081	.081	.08	.08	.1619	.1619
Max	.6401	.1619	.3239	.3201	.08	.4858	.3239
Min	.08	.081	.0781	.08	.08	.081	.081
Avg	.2466	.0990	.1464	.1603	.08	.2429	.1239

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154017 / 33/11 KV GADWAD S/S

Feeder No / Name : 203 / 11 KV MASLA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2429	.2401	.3201		.6478
2			.2429	.3239	.4001		.1619
3			.3201	.4001	.4801		
4				.4801	.4801		
5				.6478	.6401		
6			.4858	.6401	.6401		
7			.4687	.8002	.8002		
8			.4858	.8002	.8002	.1619	
9	1.7604		.4049	.8002	.8002		
10	.1543		.1619	.16	.1543		.3239
11	.1543		.1619	.16			1.1336
12	.1619		.1619	.16			1.1203
13	.1619			.16			1.1203
14		.2429		.16			1.1203
15		.2401		.16			1.2003
16		.16	.1619	.16		1.2146	1.2003
17		.1619		.16			1.2003
18							.081
19		.1619		.16			.1619
20		.1619		.16			.1619
21		.16		.16			.1619
22		.1619		.16			.1619
23		.1619		.16			.1619
24			.1429	.1619	.2401	.1619	.1619
Max	1.7604	.2429	.4858	.8002	.8002	1.2146	1.2003
Min	.1543	.16	.1429	.16	.1543	.1619	.081
Avg	.4786	.1792	.2868	.3206	.5232	.5128	.6048

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154017 / 33/11 KV GADWAD S/S

Feeder No / Name : 204 / 11 KV WANJARKHEDA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1619	.1619	.16		.9488
2		.1619	.1619	.1619	.16		1.2803
3		.1619	.1619	.1619	.16		
4			.1619	.1619	.16		
5		.1619	.1619	.1619	.16		
6			.1619	.1619	.16		
7		.1619	.1619	.1619	.16		
8		.1619	.1619		.16	1.2955	
9	.16	.1619	.1619	.16			1.7604
10	.6249		.8097	.8002			.1619
11	1.1203		1.1336	.9602	.9488		.1619
12	.9717	.1619	1.2003	1.1203	1.2803		.1619
13	1.2803		1.2003	1.2003			.1619
14		.9602	1.1203	1.2003			.1619
15		.9602	.9907	1.1203			.1619
16		1.1203	1.0402	.9602		.1619	.1619
17		1.1203		.8002			.1619
18	.1619	.1619		.16			.1619
19	.1619	.1619		.16			
20	.1619	.1619		.16			.1619
21	.1619	.1619		.16			.1562
22	.1619	.1619		.16			.1619
23	.1619	.1619		.16			.1619
24		.1619	.1619	.1619	.16	.8097	.8097
Max	1.2803	1.1203	1.2003	1.2003	1.2803	1.2955	1.7604
Min	.16	.1619	.1619	.16	.16	.1619	.1562
Avg	.4662	.3571	.5361	.4599	.3336	.7557	.4058



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154028 / 33 KV S/S BOPLA

Feeder No / Name : 201 / 11 KV BOPLA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1296		
2		.1296		
3		.1296		
4		.1943		
5		.2267		
6		.2105		
7		.1943		
8		.1943		
9		.8097		
10		.8907		
11	.8097	.8097		
12	.8421			
17	.1619		.4858	
18	.1781		.6478	
19	.1943		.7773	
20	.2267		.8097	
21	.1943			
22	.1781			
23	.1457			
24		.1296		.6478
Max	.8421	.8907	.8097	.6478
Min	.1457	.1296	.4858	.6478
Avg	.3257	.3374	.6802	.6478

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154028 / 33 KV S/S BOPLA

Feeder No / Name : 202 / 11 KC CHATA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1781		
2		.1457		
3		.1457		
4		.2267		
5		.2591		.8421
6		.2267		
7		.2267		
8		.1943		
9		.1943		
10		.1943		
11	.1875	.1943		
17	1.1336		.1781	
18	.9717		.2105	
19	1.166		.2429	
20	1.2146		.2591	
21	1.0526			
22	.8097			
23	.6154		.1943	
24		.6154		.1943
Max	1.2146	.6154	.2591	.8421
Min	.1875	.1457	.1781	.1943
Avg	.8939	.2334	.2170	.5182

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154028 / 33 KV S/S BOPLA

Feeder No / Name : 203 / 11 KV EKURGA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6478		
2		.8097		
3		1.004		
4		1.1012		
5		1.0526		
6		1.1336		
7		1.166		
8		1.1012		
9		.2267		
10		.2267		
11	.2267			
17	.2267		.1943	
19	.2591		.2915	
20	.2915		.2915	
21	.2591			
22	.2267		.2267	
23	.1943			
24	.1943	.1619		.2105
Max	.2915	1.166	.2915	.2105
Min	.1943	.1619	.1943	.2105
Avg	.2348	.7847	.251	.2105

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154028 / 33 KV S/S BOPLA

Feeder No / Name : 204 / 11kv MBF Express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0324		
2		.0324		
3		.0324		.0324
4		.0324		
5		.0324		
6		.0324		
7		.0324		
9		.0324		
10		.0324		
11	.0324			
17	.0324		.0324	
18	.0324			
19	.0324		.0324	
20	.0324		.0324	
21	.0324		.0324	
22	.0324			
23	.0324			
24	.0324	.0324		.0324
Max	.0324	.0324	.0324	.0324
Min	.0324	.0324	.0324	.0324
Avg	.0324	.0324	.0324	.0324

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154045 / 33/11 KV SHIRALA S/S

Feeder No / Name : 201 / 11 KV Shirala Feeder SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3506	.3506	.3655	.3987	.3201	1.1962	1.0965
2	.3658	.3506	.3655	.3987	.3353	1.1962	1.1463
3	.442	.4115	.3821	.4486	.3353	1.1629	1.1962
4	.5335	.4268	.6313	.5482	.3658	1.2626	1.2958
5	.7926	.5944	.9636	.8639	.6706	1.4287	1.3623
6	.9297	.7164	1.0799	.9802	.7468	1.6779	1.5284
7		.8383	1.0466	.947	.7926	1.7776	1.8275
8		.7468	.9636	.8141	.7621	1.9271	1.9271
9			.5815	.6249		1.5783	
10	1.4454			.9907			
11	1.8607		1.2792		1.8275		
12	1.8275		1.3955		1.7444		
13	1.8939	.7773		1.5242	1.7776	.2658	.3157
14	1.7112	1.1584	1.4454		1.6779	.3157	.2824
15	1.3623	1.2193	.6147		1.6613	.2326	.2824
16		1.2651	1.6447	1.4632	1.5284	.2326	.2824
17		1.5284	1.4786	1.5851	1.7444		.2658
18		.4818	1.03	.2439	.2658	.3489	.299
19			.9968	.7164	.6479	.6811	.5981
20		.731	1.03	.6706	.7974	.7476	.7642
21	.5639	.5316	.9303	.503		.6645	.4984
22	.4268	.4652	.8473	.4572		.5981	.4652
23			.7974	.3963		.4984	.4652
24		.3201				1.1629	1.03
Max	1.8939	1.5284	1.6447	1.5851	1.8275	1.9271	1.9271
Min	.3506	.3201	.3655	.2439	.2658	.2326	.2658
Avg	1.0361	.7174	.9462	.7671	1.0001	.9478	.8464

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154045 / 33/11 KV SHIRALA S/S

Feeder No / Name : 202 / 11 KV Chincholi B Feeder SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.0032	.0762	.0063	.0047
2	.3353	.0032	.0762	.0047	.0047
3	.3506	.0032	.0762	.0047	.0047
4	.3658	.0032	.0762	.0047	.0047
5	.3963	.0032	.0914	.0047	.0063
6		.0032	.1067	.0063	.0063
7		.0032	.1067	.0047	.0063
8		.0081	.1219	.0047	.0079
9	.6301		.11	.0047	.0079
10	.0065			.1257	.4401
11	.0065			.2829	.6602
12	.0048			.4401	.6916
13	.0048			.5973	.6916
14	.0048	.0061		.6287	.6602
15		.061		.613	.6444
16			.0943	.7073	.6444
17		.1981		.6759	.6602
18				.0047	.0063
19		.2439	.1572	.0063	.0063
20		.1829	.1886	.0063	.0079
21		.1524		.0063	.0079
22		.1067		.0063	.0063
23		.0762		.0063	.0063
24	.3201			.0063	.0047
Max	.6301	.2439	.1886	.7073	.6916
Min	.0048	.0032	.0762	.0047	.0047
Avg	.2301	.0661	.1068	.1733	.2163

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154045 / 33/11 KV SHIRALA S/S

Feeder No / Name : 203 / 11 KV Wadiwagholi Feeder SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3413	.2743	.2753	.3887	.2286	.1134	.1134
2	1.3413	.2743	.2753	.3887		.1296	.1134
3	1.4632	.2743	.2591	.421	.2439	.1457	.1296
4	1.6309	.2743	.2915	.4858	.2439	.1619	.1457
5	1.7375	.2743	.3077	.6154	.3048	.2591	.2753
6	1.9357	.2743	.3401	.7125	.3353	.3077	.3563
7		.2743	.5668	.9878	.3963	.3433	.3401
8		.3201	.5668	1.085	.3658	.2753	.3077
9	1.9757	.1219	.4372			.1777	.1943
10	.1134		.2105	.1677		.8421	1.177
11	.0032		.1296			1.3441	1.6194
12			.1134			1.5061	1.5546
13	.081				.8907	1.6356	1.587
14	.081		.081		1.004	1.6194	1.7004
15		.0914	.0972	.0762	.0648	1.7166	1.7814
16		.0914	.081	.061	.081	1.7814	1.8138
17		.1296		.0762		1.8785	1.8461
18		.1943		.0762		.081	.0648
19		.2915	.2915	.2896	.2591	.2753	.1943
20	.1219	.2753	.2753	.2591	.3401	.3077	.2915
21	.1067		.2429	.1981		.2429	.2591
22	.0762		.1619	.1372		.1457	.1619
23			.1134	.1067		.1296	.1296
24	1.3108	.2743				.1134	.1296
Max	1.9757	.3201	.5668	1.085	1.004	1.8785	1.8461
Min	.0032	.0914	.081	.061	.0648	.081	.0648
Avg	.8880	.2319	.2559	.3629	.3660	.6472	.6786

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154045 / 33/11 KV SHIRALA S/S

Feeder No / Name : 204 / 11 KV WATER WORKS  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	15-MAR-17
HR	Load (MW)
1	.003
2	.003
3	.003
4	.003
5	.003
6	.003
7	.003
9	.0038
10	.0038
11	.0038
12	.0038
13	.0038
14	.0038
15	.0038
24	.003
Max	.0038
Min	.003
Avg	.0034



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154045 / 33/11 KV SHIRALA S/S

Feeder No / Name : 205 / 11kv AADI AGRO Exp Fed NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0457	.0579	.0803	.0625	.0488	.0571	.0642
2	.0457	.0579	.0732	.0607	.0488	.0624	.0535
3	.0472	.0549	.0875	.0589	.0457	.0606	.0749
4		.0579	.0928	.0571	.0457	.0588	.0713
5	.0518	.061	.0928	.0607	.0518	.0624	.0642
6	.0343	.061	.0857	.0607	.0579	.0713	.0588
7	.0701	.061	.0821	.0714	.061	.0642	.0624
8	.0732	.064	.0821	.0571	.0671	.0642	.0802
9	.1392	.064		.0549	.0909	.0713	.0927
10	.0839			.0427	.0927	.0802	.0981
11	.1535		.0803	.0732	.1569	.0856	.148
12	.1642	.1021	.0928	.125	.1587	.1569	.1534
13	.1392	.128		.128	.1052	.1658	
14	.1339	.1341	.0893	.0701	.1641	.1623	
15	.0821	.0857	.091	.08	.1516	.1712	
16	.0625	.1341	.0928	.0854	.1658	.1783	
17		.1535	.1214	.0926	.1052	.1641	
18		.0161	.0893	.0732	.0999	.0927	
19		.1285	.0893	.0732	.0945	.0892	
20		.1339	.0928	.0701	.0981	.0874	
21		.1214	.0964	.0701		.0802	
22		.0964	.0803	.0701		.0767	
23		.0821	.0785	.0488		.0571	.0856
24	.0488	.0381				.0588	.0553
Max	.1642	.1535	.1214	.128	.1658	.1783	.1534
Min	.0343	.0161	.0732	.0427	.0457	.0571	.0535
Avg	.0860	.0861	.0885	.0716	.0955	.0950	.0830

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154060 / 33/ 11 KV TANDULJA S/S

Feeder No / Name : 201 / 11 KV Takalgaon Feeder SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	19-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)
8	.6097		
16		.7621	
24			1.6766
Max	.6097	.7621	1.6766
Min	.6097	.7621	1.6766
Avg	.6097	.7621	1.6766

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154060 / 33/ 11 KV TANDULJA S/S

Feeder No / Name : 202 / 11 KV Pimpalgaon Feeder SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	16-MAR-17	17-MAR-17	19-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)
8			.2439
16	.7716		
24		.2543	.0762
Max	.7716	.2543	.2439
Min	.7716	.2543	.0762
Avg	.7716	.2543	.1601

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154060 / 33/ 11 KV TANDULJA S/S

Feeder No / Name : 203 / 11 KV Tandulja Feeder SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8				2.5149
16	.7621	.6097	.5335	
24		.7621		1.1336
Max	.7621	.7621	.5335	2.5149
Min	.7621	.6097	.5335	1.1336
Avg	.7621	.6859	.5335	1.8243

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154061 / 33/ 11 KV CHIKURDA S/S

Feeder No / Name : 202 / 11 KV Chikurda Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6802		.1943	.2949		.192
2	.6802		.2267	.3277		.16
3	.7865		.2267	.3605		.16
4	.9393		.2622	.3932		.192
5	1.004		.2949	.4588		.2721
6	1.1469		.3277	.5243		.2561
7	1.1984		.3563	.6226		.2881
8	1.1336		.3725	.583		.2561
9	1.166		.4372	.5243		
10	.128		.081	.0819		.4801
11	.08	.1311	.096	.0819		.7042
12				.0819	.096	.7842
13	.0648	.1966	.0648	.0819	.08	.8162
14		.213		.0819	.08	.8322
15				.0655	.08	.8642
16			.0648	.0655	.064	.8802
17		.2294	.081	.0819	.064	.8962
18		.1311	.2105	.0655	.0791	.08
19		.1638	.1943	.1311	.112	.2401
20		.1943	.1943	.1966	.2561	
21		.1943	.1943	.1966	.2401	
22		.1619	.1475	.1638	.192	
23		.1457	.2591	.1311	.16	
24	.7125		.1311	.2622		.192
Max	1.1984	.2294	.4372	.6226	.2561	.8962
Min	.0648	.1311	.0648	.0655	.064	.08
Avg	.7477	.1761	.2103	.2441	.1253	.4498

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154061 / 33/ 11 KV CHIKURDA S/S

Feeder No / Name : 203 / 11 Kv Samangaon Feeder SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	18-MAR-17
HR	Load (MW)
18	.0972
Max	.0972
Min	.0972
Avg	.0972

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154061 / 33/ 11 KV CHIKURDA S/S

Feeder No / Name : 204 / 11 KV Natural FEEDER  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-17	19-MAR-17	20-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)
1			.0191
2			.0191
3			.0191
4			.0191
5			.0191
6			.0191
7			.0191
8			.0191
9			.0191
10			.0191
11			.0191
12			.0191
13			.0191
14			.0191
15			.0191
16			.0191
17			.0191
18			.0191
22	.1524		
23		.0191	
24			.0191
Max	.1524	.0191	.0191
Min	.1524	.0191	.0191
Avg	.1524	.0191	.0191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S

Feeder No / Name : 201 / 11 KV Ankoli Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6						.9724
7		1.153	.4748	1.7295	2.2131	
8	2.7808					
13		.1865				
15			.1357		.2035	
17	.1696					
20				.663		
21					.7122	
22		.4748	.5087			
24				.2035		
Max	2.7808	1.153	.5087	1.7295	2.2131	.9724
Min	.1696	.1865	.1357	.2035	.2035	.9724
Avg	1.4752	.6048	.3731	.8653	1.0429	.9724



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S

Feeder No / Name : 202 / 11 KV Utti Tawarja Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6						.6706
7		.2543	.1696	.407	.3688	
8	.3391					
9	.2543					
13		.5765		.6783		
15			.7122		.8478	
20				.3149		
21					.2204	
22		.1696	.1526			
24					.2204	
Max	.3391	.5765	.7122	.6783	.8478	.6706
Min	.2543	.1696	.1526	.3149	.2204	.6706
Avg	.2967	.3335	.3448	.4667	.4144	.6706

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S

Feeder No / Name : 203 / 11 KV SAWARGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6						1.3077
7		.6783	.6952	.6783	.7042	
8	.5426					
13		1.4243		1.4074		
15			1.4582		1.7974	
20				.5304		
22		.2713	.3391			
24					.3391	
Max	.5426	1.4243	1.4582	1.4074	1.7974	1.3077
Min	.5426	.2713	.3391	.5304	.3391	1.3077
Avg	.5426	.7913	.8308	.8720	.9469	1.3077

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S

Feeder No / Name : 204 / 11 KV WATER WORKS EXP NON SHEDDABLE WATER SUPPLY AND  
Feeder KV- 11 / OUTGOING UTILITY

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6						.0168	
7		.017	.0168	.017	.0168		
8	.017						
13		.017		.017			
15			.017		.017		
17							.017
20				.0166			
22		.017	.017				
24					.017		
Max	.017	.017	.017	.017	.017	.0168	.017
Min	.017	.017	.0168	.0166	.0168	.0168	.017
Avg	.017	.017	.0169	.0169	.0169	.0168	.017

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154086 / 33 KV S/S NIVALI

Feeder No / Name : 201 / 11 KV KARKHANA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8023		.3361		1.1736	.3361	.3326
2	1.8842		.3361	1.0059	1.1736	.3361	.3361
3	2.0243		.3174	.9831	1.1603	.3734	.3696
4	2.1052		.3696	1.065	1.2574	.4435	.4066
5	2.2672		.439	1.1469	1.2431	.5544	.5601
6	2.4291		.6401	1.7147	1.3108	.823	.7762
7	2.5101		.6584	1.6385	1.7204	.7682	.6838
8	2.7854		.6335	1.7404	1.7204	.7316	.5487
9	2.7035			1.8023	1.8842		
10	.4287		.3429	.4287	.4578	1.2803	
11		.6335	.3429	.3258	.3658	1.5893	1.8564
12				.2172		1.9334	2.4034
13				.2195		2.0481	2.3472
14		1.0279		.2195			1.989
15		.4207		.2561		2.0481	2.1434
16		.2926				2.2119	2.2377
17		.3696			.3658	2.1795	2.3205
18				.6535	.4108	.2591	.2915
19		.6535	.6859		.6535	.5601	.5144
20		.6535	.6001	.7392	.6468	.6908	
21		.5601	.5959	.5601	.6535	.6468	.5144
22		.4715	.5784	.3696	.5975	.5544	.5144
23		.2829	.3856	.3734	.5228	.5228	.4287
24	1.8023		.3734	.8288	1.17	.3734	2.0957
Max	2.7854	1.0279	.6859	1.8023	1.8842	2.2119	2.4034
Min	.4287	.2829	.3174	.2172	.3658	.2591	.2915
Avg	2.0675	.5366	.4772	.8144	.9731	.9666	1.1272

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154086 / 33 KV S/S NIVALI

Feeder No / Name : 202 / 11 KV NIVALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572		.2641		.2772	.7202	.8288
2	.2572		.2452	.2572	.2772	.7186	.8192
3	.2572		.2829	.3086	.3658	.7499	.9116
4	.3429		.415	.4287	.4108	.7716	.9831
5	.4287		.5601	.6859	.6099	.8697	1.0486
6	.5144		.7468	.7716	.8048	1.0526	1.166
7	.6859		.8402	.7716	.8962	1.2146	1.4918
8	.6344		.6161			1.3108	1.5083
9	.5144			.5144	.3696	1.065	1.5432
10	1.1469			.3353		.415	
11		.7742	.5144	.663			
12		.8048		.4915			.12
13		.8745	.4096	.6882	1.0774		.1029
14		.8907		.6554	1.1336	.1867	.1372
15		.8097	.5487	.6554	1.1469		.1372
16		.703	.5144	.7209	1.2431	.1463	.1029
17		.8421	.4287	.7373	1.2717	.1848	.0686
18				.5914	.3772		
19		.3772	.6344		.6602	.5601	.4287
20		.6602	.6135	.7392	.7468	.6908	.4287
21		.5281	.5487	.5175	.5658	.6468	.1029
22		.415	.5609	.4066	.4715	.4435	.3944
23		.2829	.2629	.3174	.3772	.2957	.3429
24	.298		.2641	.2572	.2801	.7202	.7969
Max	1.1469	.8907	.8402	.7716	1.2717	1.3108	1.5432
Min	.2572	.2829	.2452	.2572	.2772	.1463	.0686
Avg	.4852	.6635	.4879	.5483	.6682	.6717	.6411

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154086 / 33 KV S/S NIVALI

Feeder No / Name : 203 / 11 KV DHAKNI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857		.0754		.0924	.4687	.4973
2	.0857		.0747	.0514	.0924	.463	.5087
3	.0857		.0934	.0686	.0924	.4572	.5365
4	.1029		.1109	.12	.1109	.4877	.5304
5	.1372		.168	.1372	.1663	.5155	.5735
6	.2058		.2241	.2058	.2241	.506	.6226
7	.2572		.2587	.2915	.2195	.5601	.8907
8	.2572		.2561		.2012	.7202	.9116
9	.1886				.1494	.6478	.8573
10	.9012				.5765	.0747	.0514
11		.2715		.6554	.6859	.0724	.0497
12		.779		.6718	.8192	.0554	.0514
13		.8383		.6478	.7773	.0549	.0514
14		.7045	.4287	.663	.7432	.0549	.0514
15		.6706	.4191	.663	.7202		.0514
16		.6554	.4287	.663	.7287	.0549	
17		.6783	.4287	.6962	.7545	.056	
18			.0686	.1478	.1132	.0934	.0514
19		.1886	.2058		.2829	.1478	.1372
20		.1886	.1753	.1829	.1698	.2218	.1372
21		.1509	.12	.1294	.1509	.1494	
22		.0943	.1029	.1294	.1132	.1109	.1029
23		.0754	.0724	.1109	.0943	.0747	.0857
24	.0857		.0754	.0514	.0934	.4744	.5087
Max	.9012	.8383	.4287	.6962	.8192	.7202	.9116
Min	.0857	.0754	.0686	.0514	.0924	.0549	.0497
Avg	.2175	.4413	.1993	.3309	.3405	.2836	.3456

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154102 / 33/11 KV RAMEGAON

Feeder No / Name : 201 / 11 KV RAMEGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.9191		.685		.2144	
8			.7109			
9	.9191					
10	.9033	.5109		.7659		
11		.1451		.1532		
12	.112	.0729				
13	.1101			.0613		
14		.1099			.9603	
15		.0754				
17		.1077		.0153	.894	
18		.1509				
24			.2134			.3048
Max	.9191	.5109	.7109	.7659	.9603	.3048
Min	.1101	.0729	.2134	.0153	.2144	.3048
Avg	.5927	.1675	.5364	.2489	.6896	.3048

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154102 / 33/11 KV RAMEGAON

Feeder No / Name : 202 / 11 KV CHINCHOLI (B) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.4289		.5658		1.0416	
8			.4894			
9	.3064					
10	.2617	.2555		.1838		
11		.3285		.9191		
12	1.5766	.2026				
13	1.5724			1.0722		
14		.5231			.0951	
15		.6333				
17		.7695		1.1642	.1711	
18		.7478				
19				.3064		
24			.3353			.3658
Max	1.5766	.7695	.5658	1.1642	1.0416	.3658
Min	.2617	.2026	.3353	.1838	.0951	.3658
Avg	.8292	.4943	.4635	.7291	.4359	.3658



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154102 / 33/11 KV RAMEGAON

Feeder No / Name : 203 / 11 KV GONDEGAN SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	1.2224		.9946		.306	
8			1.1069			
9	1.2254					
10	1.3064	.8663		1.1488		
11		.0369		.2144		
12		.0183				
13				.0613		
14		.0735			2.2211	
15		.0566				
17		.0942			2.3013	
19				.1838		
24			.1524			.2439
Max	1.3064	.8663	1.1069	1.1488	2.3013	.2439
Min	1.2224	.0183	.1524	.0613	.306	.2439
Avg	1.2514	.1910	.7513	.4021	1.6095	.2439

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154007 / 33/11 KV RENAPUR S/S

Feeder No / Name : 201 / 11 Kv Renapur-I SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.8573			.8573	.7716	.8573	.6859
16		.8573			.8573	.7716	.7716
24	.5144		.3429	.4287	.3429		.4287
Max	.8573	.8573	.3429	.8573	.8573	.8573	.7716
Min	.5144	.8573	.3429	.4287	.3429	.7716	.4287
Avg	.6859	.8573	.3429	.643	.6573	.8145	.6287

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154007 / 33/11 KV RENAPUR S/S

Feeder No / Name : 202 / 11 Kv Mahapur SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8				.9431	.8573	1.7147	1.8861
16		1.8004			1.5432		.4287
24	.6001		.4287	.5144	.6001		.7716
Max	.6001	1.8004	.4287	.9431	1.5432	1.7147	1.8861
Min	.6001	1.8004	.4287	.5144	.6001	1.7147	.4287
Avg	.6001	1.8004	.4287	.7288	1.0002	1.7147	1.0288

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154007 / 33/11 KV RENAPUR S/S

Feeder No / Name : 203 / 11 KV HANMANTWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.0288			1.8861	1.6289	.9431	.8573
16		.7716			.7716		2.0576
24	.7716		.9431	.8573	.4287		.5144
Max	1.0288	.7716	.9431	1.8861	1.6289	.9431	2.0576
Min	.7716	.7716	.9431	.8573	.4287	.9431	.5144
Avg	.9002	.7716	.9431	1.3717	.9431	.9431	1.1431

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154007 / 33/11 KV RENAPUR S/S

Feeder No / Name : 204 / 11 Kv Samsapur SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.9431			.9431	.8573	1.8861	1.8861
16		1.7147			1.6289		.4287
24			.3429	.4287	.0429		.7716
Max	.9431	1.7147	.3429	.9431	1.6289	1.8861	1.8861
Min	.9431	1.7147	.3429	.4287	.0429	1.8861	.4287
Avg	.9431	1.7147	.3429	.6859	.8430	1.8861	1.0288

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154007 / 33/11 KV RENAPUR S/S

Feeder No / Name : 205 / 11 Kv Phata SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8				.3429	.3429	.3429	.4287
16		.1715			.3429		.2572
24	.1715		.2572	.2572	.2572		.2572
Max	.1715	.1715	.2572	.3429	.3429	.3429	.4287
Min	.1715	.1715	.2572	.2572	.2572	.3429	.2572
Avg	.1715	.1715	.2572	.3001	.3143	.3429	.3144

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154007 / 33/11 KV RENAPUR S/S

Feeder No / Name : 206 / 11 Kv Renapur-II SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.8573			.7716	.7716	.8573	.8573
16		.2572			.2572		.2572
24	.6859		.7716	.6001	.6001		.7716
Max	.8573	.2572	.7716	.7716	.7716	.8573	.8573
Min	.6859	.2572	.7716	.6001	.2572	.8573	.2572
Avg	.7716	.2572	.7716	.6859	.5430	.8573	.6287

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154047 / 33/11 KV POHAREGAON S/STN

Feeder No / Name : 201 / 11 Kv Poharegaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1528					
4							1.3375
6	.4904		.5144	.5487	.5281		
8							1.768
10			1.0364	1.3546		.2172	.2427
11				1.5061	1.5352		
12	1.7113		1.5394				
13	1.6808	1.2498				.1867	
16		1.2498	1.6049	1.531	1.475	.1886	.1222
17	.6723			1.6644			.1222
18	.2139	.2915					.1834
19			.5415				
20		.4801					
21				.3772	.4024	.4854	
24	.2075	.1528	.2454	.2561		.945	1.0867
Max	1.7113	1.2498	1.6049	1.6644	1.5352	.945	1.768
Min	.2075	.1528	.2454	.2561	.4024	.1867	.1222
Avg	.8294	.5961	.9137	1.0340	.9852	.4046	.6947



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154047 / 33/11 KV POHAREGAON S/STN

Feeder No / Name : 202 / 11 Kv Shera SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4							.1578
6	.3961		.4458	.4294	.3547		
8						.8951	.823
10			.5426			.1867	.1698
11				.8097	.8583		
12	.5221		.8436				
13	.5528	.663					
16		.6962	.7926	.7375	.7956	.0943	.0307
17	.4607			.8124		.1132	.0461
18	.1843	.1629					.0005
19			.3206				
20		.3045					
21				.2829	.2987	.2614	
24	.1509	.1228	.181	.1494	.132	.2543	.3403
Max	.5528	.6962	.8436	.8124	.8583	.8951	.823
Min	.1509	.1228	.181	.1494	.132	.0943	.0005
Avg	.3778	.3899	.5210	.5369	.4879	.3008	.2240

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154047 / 33/11 KV POHAREGAON S/STN

Feeder No / Name : 203 / 11 Kv Bhokaramba SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5511					
4							1.094
6	2.2725		1.873	2.0809	2.1052		
8		1.8084	2.0405	2.4387	2.5126		
10			.7964			1.8623	1.7747
11					.4706		
12			.4904				
13		.4163					
14	.5511						
16		.3801	.3961	.4338	.4706	2.1795	2.1529
17	.62			.3961		2.2253	2.2045
18		.6516					.8267
19			1.475				
20		1.3375					
21				1.3014	1.2308	1.2437	
24	1.4083	.9645	1.1869	1.3321	1.2631	.6516	.7167
Max	2.2725	1.8084	2.0405	2.4387	2.5126	2.2253	2.2045
Min	.5511	.3801	.3961	.3961	.4706	.6516	.7167
Avg	1.2130	.8728	1.1798	1.3305	1.3422	1.6325	1.4616

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154049 / 33/11 KV KHALAGRI S/STN

Feeder No / Name : 201 / 11kv Khalangri SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	17-MAR-17	18-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.5123		1.6991	.4884	
16		.2241			
24	.8215				.2442
Max	1.5123	.2241	1.6991	.4884	.2442
Min	.8215	.2241	1.6991	.4884	.2442
Avg	1.1669	.2241	1.6991	.4884	.2442

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154049 / 33/11 KV KHALAGRI S/STN

Feeder No / Name : 202 / 11 Kv Karepur SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.0082				2.8435	
16		1.4003		3.3553		
24			.0549			3.3743
Max	1.0082	1.4003	.0549	3.3553	2.8435	3.3743
Min	1.0082	1.4003	.0549	3.3553	2.8435	3.3743
Avg	1.0082	1.4003	.0549	3.3553	2.8435	3.3743

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154049 / 33/11 KV KHALAGRI S/STN

Feeder No / Name : 203 / 11 Kv Ghodala SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8					.5398	
16		.1254		.1219		
24	.5729		.5975			.4353
Max	.5729	.1254	.5975	.1219	.5398	.4353
Min	.5729	.1254	.5975	.1219	.5398	.4353
Avg	.5729	.1254	.5975	.1219	.5398	.4353

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154049 / 33/11 KV KHALAGRI S/STN

Feeder No / Name : 204 / 11KV W/W NON SHEDDABLE WATER SUPPLY AND  
 Feeder KV- 11 / OUTGOING UTILITY

DATE	15-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.037			.0314	
16			.0314	.0472	
24	.0358	.052			.0472
Max	.037	.052	.0314	.0472	.0472
Min	.0358	.052	.0314	.0314	.0472
Avg	.0364	.052	.0314	.0393	.0472

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154051 / 33/11 KV SINDHGAON S/STN

Feeder No / Name : 201 / 11 Kv Sindhgaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			1.3546	1.3203	1.5432	.6344	.5658
10	.8573	.2572					
16		.1029		.12	.12	1.4232	1.3375
17	.1886		.1372				
18						.1543	
24	.8573	.5658		.703	.7716	.2058	
Max	.8573	.5658	1.3546	1.3203	1.5432	1.4232	1.3375
Min	.1886	.1029	.1372	.12	.12	.1543	.5658
Avg	.6344	.3086	.7459	.7144	.8116	.6044	.9517

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154051 / 33/11 KV SINDHGAON S/STN

Feeder No / Name : 202 / 11 Kv Niwada SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.6687		.7716	1.4918	1.6804
10	.9945	.6344					
16		1.5432		1.5432	1.4918		.2229
17	.9259		1.5947			.2229	
18						.3086	
24	.3429	.2743		.3772	.2515	.7202	
Max	.9945	1.5432	1.5947	1.5432	1.4918	1.4918	1.6804
Min	.3429	.2743	.6687	.3772	.2515	.2229	.2229
Avg	.7544	.8173	1.1317	.9602	.8383	.6859	.9517



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154051 / 33/11 KV SINDHGAON S/STN

Feeder No / Name : 203 / 11 KV Express Feeder

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	16-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	.12				
16	.1029	.0171	.1372		.0857
18				.0514	
Max	.12	.0171	.1372	.0514	.0857
Min	.1029	.0171	.1372	.0514	.0857
Avg	.1115	.0171	.1372	.0514	.0857

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154057 / 33/11 KV PALSI S/S

Feeder No / Name : 201 / 11 Kv Palsi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6828	.4763	.6249	.6943	.6805	.3711	.362
2	.7049	.5106	.6211	.7766	.692	.365	.3628
3	.7331	.5327	.628	.7735	.6965	.3902	.3909
4	.7743	.551	.6706	.7948	.7118	.4291	.4565
5	.8497	.5906	.8002	.8604	.8009	.5952	.6691
6	1.1233	.7354	.9564	1.137	1.0105	1.1271	1.0334
7	1.6598	1.041	1.3611	1.7193	1.5127	1.3016	1.3618
8	1.4144	1.1439	1.5287	1.7269	1.6469		1.1401
9	1.1972	1.0692	1.4632	1.7383	1.4098		.1608
10	.9168	.7232	.5799	1.5455	1.3001	.5609	.849
11	.6485	.4169	.7324	.5472	.4313	1.3169	1.2003
12	.3528	.3521	.4664	.4024	.3551	1.4342	1.2109
13	.2439	.2759	.3704	.2812	.2743	1.4281	1.0593
14	.2408	.2058	.2949	.2408	.3086	1.3214	1.0692
15	.2202	.2058	.2644	.2515	.2934	1.1241	1.0837
16	.2888	.2462	.2599	.2629	.3102	1.134	1.2407
17	.3246	.2561	.0168	.2957	.2751	1.2003	1.3786
18	.6462	.3445	.3932	.3391	.4001	1.1835	1.3245
19	.7057	.6752	.788	.5441	.5723	.6363	.6478
20	.8551	.9808	1.0562	1.0433	.977	.9503	.9877
21	.7164	.9137	.9214	.9648	.9488	.9252	.9252
22	.5075	.6965	.6615	.6356	.6645	.6577	.663
23	.4062	.4946	.4687	.4847	.4999	.4832	.5014
24	.4656	.4176	.4816	.4862	.4199	.4024	.4359
Max	1.6598	1.1439	1.5287	1.7383	1.6469	1.4342	1.3786
Min	.2202	.2058	.0168	.2408	.2743	.365	.1608
Avg	.6949	.5773	.6837	.7728	.7163	.8790	.8548

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154057 / 33/11 KV PALSI S/S

Feeder No / Name : 203 / 11 Kv Garsoli SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3807	.2393	.2625	.2782	.2728	.1597	.1616
2	.3753	.2431	.2679	.2774	.3022	.1684	.1604
3	.3841	.2442	.266	.2824	.3056	.1715	.1768
4	.3849	.2519	.2679	.3022	.3216	.1966	.2267
5	.4435	.2713	.2976	.3075	.3563	.2534	.3067
6	.4889	.3079	.3658	.3521	.4298	.362	.3487
7	.6238	.3681	.4973	.5327	.5632	.3711	.3616
8	.6047	.3829	.5376	.5632	.5765		.3182
9	.5376	.3647	.4984	.5232	.479		.2675
10	.1135	.3624	.4489	.3643	.4599	.1608	.3281
11	.0667	.0758	.0972	.0819	.0918	.6318	.623
12	.0507	.0225	.061	.061	.0648	.7305	.4942
13	.0541	.0591	.0545	.0652	.0633	.7217	.7396
14	.0457	.0591	.053	.0587	.0293	.7487	.7758
15	.0537	.0556	.0575	.0564	.1094	.7068	.7667
16	.0575	.0362	.0659	.0572	.1158	.74	.8032
17	.0606	.0652	.0545	.0572	.093	.78	.852
18	.117	.0762	.069	.0774	.1059	.7693	.8238
19	.1467	.1486	.1566	.149	.2164	.2023	.2195
20	.1825	.1978	.2279	.234	.2949	.3121	.3254
21	.1764	.2016	.218	.2359	.2858	.2987	.2934
22	.1391	.1745	.1543	.1802	.2481	.2473	.2561
23	.1158	.1437	.1471	.1467	.1962	.1981	.1886
24	.2492	.1962	.1966	.2324	.1753	.1684	.1802
Max	.6238	.3829	.5376	.5632	.5765	.78	.852
Min	.0457	.0225	.053	.0564	.0293	.1597	.1604
Avg	.2439	.1895	.2218	.2282	.2565	.4136	.4166

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154070 / 33/11 KV KHAROLA S/S

Feeder No / Name : 201 / 11 Kv Kharola SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.1749	1.4575	.2606	1.166	1.1584	1.3565
16	.16	.6001	.5144		.1486	.1139	
24	.6554	.381	.5144	.6001		.5441	.8764
Max	.6554	.6001	1.4575	.6001	1.166	1.1584	1.3565
Min	.16	.1749	.5144	.2606	.1486	.1139	.8764
Avg	.4077	.3853	.8288	.4304	.6573	.6055	1.1165

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154070 / 33/11 KV KHAROLA S/S

Feeder No / Name : 202 / 11 Kv Kumbharwadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			1.0288	1.0185	1.1145	.3201	.2743
16	.1132	.12	.1372				
24	.381		.2743	.4115		.1698	.1509
Max	.381	.12	1.0288	1.0185	1.1145	.3201	.2743
Min	.1132	.12	.1372	.4115	1.1145	.1698	.1509
Avg	.2471	.12	.4801	.715	1.1145	.2450	.2126

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154070 / 33/11 KV KHAROLA S/S

Feeder No / Name : 203 / 11 Kv Selu ( J ) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.6001	.6413	.6859	1.1584	1.2193
16	.961	.8573	1.2003		1.0235	.2241	
24	.2743	.3048	.3429	.3086		.4816	.6173
Max	.961	.8573	1.2003	.6413	1.0235	1.1584	1.2193
Min	.2743	.3048	.3429	.3086	.6859	.2241	.6173
Avg	.6177	.5811	.7144	.4750	.8547	.6214	.9183

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154110 / 33KV/11KVDARJI BORGAON S/S

Feeder No / Name : 201 / 11 KV DARJI BORGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372			.1372			.2401
2	.1372			.1372			.2572
3	.1372			.1372			.2572
4	.1715			.1715			.3086
5	.2401			.2058			.3086
6	.3086			.2572			.3772
7	.3772			.3086			.4458
8	.2743		.2743	.3086		.4115	.4458
9	.12	.192	.1886	.2058		.5144	.4458
10			.3086			.1029	
11			.3429			.0857	
12						.0857	
13			.2743			.0857	
14			.3086			.0857	
15			.3086			.0857	
16		.3429	.3429		.4115	.0857	.064
17			.3772			.0857	
18			.1029			.0857	
19			.1715	.176		.1715	
20			.2401			.2401	
21			.2401			.2058	
22						.1715	
23						.1372	
24	.1372		.1372	.1372			.2401
Max	.3772	.3429	.3772	.3086	.4115	.5144	.4458
Min	.12	.192	.1029	.1372	.4115	.0857	.064
Avg	.2041	.2675	.2584	.1984	.4115	.1650	.3082

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154110 / 33KV/11KVDARJI BORGAON S/S

Feeder No / Name : 202 / 11 KV BHRAMWADI -Ghavan SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543			.1543			.4801
2	.1543			.1543			.5144
3	.1543			.1543			.5144
4	.2058			.1543			.6173
5	.2572			.2058			.7716
6	.2572			.2572			1.0288
7	.3086			.3086			1.1831
8	.2572		.2572	.2058		1.1831	1.1831
9	.1543	.1063	.1543	.1543		1.1831	1.1317
10			.7202			.0514	
11			1.0288			.0514	
12			1.0288			.0514	
13			.9774			.0514	
14			1.0288			.0514	
15			.9774			.0514	
16		.7716	1.0802		1.0802	.0514	.0701
17			1.2346			.0514	
18			.0514			.0514	
19			.2058	.0995		.1543	
20			.2572			.2058	
21			.2058			.2058	
22						.2058	
23						.1543	
24	.1543		.1543	.1543			.463
Max	.3086	.7716	1.2346	.3086	1.0802	1.1831	1.1831
Min	.1543	.1063	.0514	.0995	1.0802	.0514	.0701
Avg	.2058	.4390	.6241	.1821	1.0802	.2347	.7234



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154110 / 33KV/11KVDARJI BORGAON S/S

Feeder No / Name : 203 / 11 KV INDARTHANA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429			.2572			.2229
2	.3429			.2572			.2229
3	.3772			.2572			.2229
4	.4287			.2743			.2572
5	.5144			.3086			.3086
6	.6516			.3772			.4287
7	.7373			.4287			.6001
8	.6344		.7373	.4287		.463	.463
9	.463	.4694	.6516	.4287		.3086	.3429
10			.3429			.4287	
11			.2058			.6001	
12			.1715			.6516	
13			.1715			.6516	
14			.1715			.6001	
15			.1372			.6001	
16		.1029	.1372		.1372	.6001	.5304
17			.1372			.6859	
18			.1715			.1715	
19			.3086	.39		.3086	
20			.4115			.4287	
21			.3772			.3601	
22						.3086	
23						.2401	
24	.3429		.2229	.2572			.2229
Max	.7373	.4694	.7373	.4287	.1372	.6859	.6001
Min	.3429	.1029	.1372	.2572	.1372	.1715	.2229
Avg	.4835	.2862	.2904	.3332	.1372	.4630	.3475

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154002 / 33KV AUSA

Feeder No / Name : 203 / 11KV Khanapur(AG)

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	1.2696			1.0642	1.1016	.2218	.2054
4	1.531			1.1763	1.5497		
6	1.6632			1.5497			
7	2.3655						
8				1.7551			
10							1.2696
11				1.1949		1.9418	
12							2.1068
14		1.1203					1.3676
16							2.0328
18		.1867			.1848		.2987
20		.1867					.3734
21					.2241		
22					.2241		.3361
24		1.2696	.4854		.2241		.2241
Max	2.3655	1.2696	.4854	1.7551	1.5497	1.9418	2.1068
Min	1.2696	.1867	.4854	1.0642	.1848	.2218	.2054
Avg	1.7073	.6908	.4854	1.3480	.5847	1.0818	.9127

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154002 / 33KV AUSA

Feeder No / Name : 204 / 11kv Borphal AG Feeder      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.0373			.0373	.0373	.7468	.8775
4							1.1016
6						1.0829	1.363
7						1.1203	
8						1.5684	1.922
9						1.6263	
10			.6653				
12			1.0719				
14	2.3525		1.0719				
15				1.4937			
16			1.3306	.7468			
18		.2054			.0373		
20							.0373
21					.0373		
22					.0373		.0373
24			.0373	.037	.0373		.0373
Max	2.3525	.2054	1.3306	1.4937	.0373	1.6263	1.922
Min	.0373	.2054	.0373	.037	.0373	.7468	.0373
Avg	1.1949	.2054	.8354	.5787	.0373	1.2289	.768

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154002 / 33KV AUSA

Feeder No / Name : 205 / 11kv Utti w/w express  
feeder Feeder KV- 11 /  
OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.1494			.0747	.056	.0373	.0373
4	.1494			.1109	.056		.0934
6	.1494			.112		.112	.1307
7	.1494					.112	
8						.112	.1294
10			.1109				.1307
12	.1494		.1109				
14	.1494	1.1203	.112				.1307
15				.1867			
16			.1478		.1867		.1307
18		.112			.1867		.0373
20	.037	.112					.0373
21					.0373		
22					.037		.112
24	.1494	.1307	.1494	.1867			.0373
Max	.1494	1.1203	.1494	.1867	.1867	.112	.1307
Min	.037	.112	.1109	.0747	.037	.0373	.0373
Avg	.1354	.3688	.1262	.1342	.0933	.0933	.0915

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154002 / 33KV AUSA

Feeder No / Name : 206 / 11kv MIDC Feeder

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.168			.112	.0934	.1494	.1307
4	.1867			.112	.1494		.1307
6	.1867			.1307		.1494	.168
7	.2033					.1494	
8				.168		.2801	.2957
10							.1867
11				.3734			
12			.1294				.3511
13			.1663				
14	.4108	.1867	.1867				.2402
16			.168	.3361	.2378		.0185
18		.2801			.2241		.2801
19				.2054			
20		.0934					.1494
21					.168		
22					.1867		.112
24	.3734	.1867	.112	.0934			.168
Max	.4108	.2801	.1867	.3734	.2378	.2801	.3511
Min	.168	.0934	.112	.0934	.0934	.1494	.0185
Avg	.2548	.1867	.1525	.1914	.1766	.1821	.1859

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154002 / 33KV AUSA

Feeder No / Name : 207 / 11kv Khanapur(ALMALA)  
gaothan Feeder KV- 11 /  
OUTGOING

GAOTHAN FEEDER

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.1867			.1494	.0934	.1867	.2241
4	.2614			.2054	.1494		.2614
6	.2801			.2241		.2614	.3174
7	.2614					.2801	
8				.1663		.1867	.168
10			.1109				.112
12	.168		.1307				
14	.1867	.112	.1109				.112
15				.1307			
16			.1307		.1463		
18		.0747			.1494		.1867
20	.0554	.0934					.2241
21					.2614		
22					.2427		.2241
24	.168	.1494	.1494	.168			.2054
Max	.2801	.1494	.1494	.2241	.2614	.2801	.3174
Min	.0554	.0747	.1109	.1307	.0934	.1867	.112
Avg	.1960	.1074	.1265	.1740	.1738	.2287	.2035

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154002 / 33KV AUSA

Feeder No / Name : 208 / 11 KV KARAJGAON GAOTHAN GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.2801			.2054	.2054	.3361	.2054
4	.3361			.2614	.2614		.2427
6	.5041			.3174		.4108	.5788
7	.5228					.4108	
8				.2801		.3734	.3921
10			.3326				.2801
12	.2427		.3734				.2614
14	.2054		.3734				.2241
16			.2957		.2772		.2427
18		.3734			.3361		.3174
20		.1494					.4108
21					.4108		
22					.3361		.3734
24	.2427		.2427	.168			.2614
Max	.5228	.3734	.3734	.3174	.4108	.4108	.5788
Min	.2054	.1494	.2427	.168	.2054	.3361	.2054
Avg	.3334	.2614	.3236	.2465	.3045	.3828	.3159

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154021 / 33KV Bhada S/S

Feeder No / Name : 201 / 11KV Bhada Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.2891					
3	.322					
4					1.2833	
5	.3542					
6	.4181					
7	.4813					
8	.4813				.9659	
9	.385					
10		.3529				
11		.5441				.1861
12	1.3475	.5921				
13	1.2833	.5121				
14	1.1229	.5281				
15		.4813				
16				.9304		
22			.385			
24	.2894			.2576	.7379	
Max	1.3475	.5921	.385	.9304	1.2833	.1861
Min	.2891	.3529	.385	.2576	.7379	.1861
Avg	.6158	.5018	.385	.594	.9957	.1861



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154021 / 33KV Bhada S/S

Feeder No / Name : 202 / 11KV Warwada Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.1646						
3	.1973						
4						.7892	
5	.2634						
6	.2634						
7	.2795						
8	.2628				.2631	.823	
9	.1973						
10	.559						
11		.2631					.1315
12	1.0523	.2622					.0987
13	.9865						
14	.8221						.0987
16					.6906		
18			.148				
20				.2302			
22				.3946			
23				.3951			
24	.1315				.3461		
Max	1.0523	.2631	.148	.3951	.6906	.823	.1315
Min	.1315	.2622	.148	.2302	.2631	.7892	.0987
Avg	.4316	.2627	.148	.3400	.4333	.8061	.1096

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154021 / 33KV Bhada S/S

Feeder No / Name : 203 / 11KV Baranpur Feeder SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	1.0852				
3	1.3565				
4				.5087	
5	1.7635				
6	2.1728				
7	2.5803				
8	2.3765		1.1869	.679	
9	2.3061				
10	.4753				
11					1.6296
12	.1528				1.2222
13	.1528				1.4938
14	.1528				1.6636
16			.1696		
22		.5426			
23		.7461			
24	.7122		.7122	.5087	
Max	2.5803	.7461	1.1869	.679	1.6636
Min	.1528	.5426	.1696	.5087	1.2222
Avg	1.2739	.6444	.6896	.5655	1.5023

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154021 / 33KV Bhada S/S

Feeder No / Name : 204 / korangala SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.1341					
3	.1341					
4					.8383	
5	.2374					
6	.4024					
7	.4024					
8	.4409	.2667		.1844	1.643	
9	.4191	.2477				
10	.6859					
11	1.8652					.1619
12	2.2382					.0486
13	2.1026					.0648
14	.407					
16				1.4083		
20			.2012			
21			.2012			
23			.1677			
24	.1696			.1357	.57	
Max	2.2382	.2667	.2012	1.4083	1.643	.1619
Min	.1341	.2477	.1677	.1357	.57	.0486
Avg	.7415	.2572	.1900	.5761	1.0171	.0918

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154021 / 33KV Bhada S/S

Feeder No / Name : 206 / kalmatha SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.9774				
3	1.0745				
4					.2507
5	1.7737				
6	1.8823				
7	2.3282				
8	2.3998			1.9185	.2896
9	2.2634				.2534
10	.1715				
11	.0762				
12	.0381	.3982			
13	.0381	.543			
14	.0381				
16				.0724	
20			.2896		
21			.2865		
22			.3258		
23			.2896		
24	.5731			.362	.1791
Max	2.3998	.543	.3258	1.9185	.2896
Min	.0381	.3982	.2865	.0724	.1791
Avg	1.0488	.4706	.2979	.7843	.2432

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154030 / 33KV YERANDI S/S

Feeder No / Name : 201 / 11KV Yerandi Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8					.2591		
9	.1829			.1524	.1677	.503	.6249
12			.3658				.061
15	.5182						
16				.4572			
17			.442		.503	.0457	
18		.4115					
19				.2134			
20							.2134
23				.1067			
24	.1067		.1067	.0914	.1067	.1981	.2286
Max	.5182	.4115	.442	.4572	.503	.503	.6249
Min	.1067	.4115	.1067	.0914	.1067	.0457	.061
Avg	.2693	.4115	.3048	.2042	.2591	.2489	.2820

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154030 / 33KV YERANDI S/S

Feeder No / Name : 202 / 11KV Kaneri Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8					.884		
9	1.1126			.6249	.9297	.1981	.1981
12			.0914				1.0974
15	.0762						
16				.0762			
17			.1067			1.0364	
18		.4572					.0762
19				.2286			
20							.2286
23				.1829			
24	.442		.1829	.2229	.1677	.1981	.12
Max	1.1126	.4572	.1829	.6249	.9297	1.0364	1.0974
Min	.0762	.4572	.0914	.0762	.1677	.1981	.0762
Avg	.5436	.4572	.127	.2671	.6605	.4775	.3441

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154032 / 33kv Matola

Feeder No / Name : 201 / 11KV Matola

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3395	.9431	1.226
2				.3772	1.094	1.2826
3			1.5089	.4338	1.1317	1.3203
4			1.5089	.5281	1.1883	1.358
5			1.5089	.679	1.2826	1.4146
6			.0943	.8299	1.358	1.4523
7		.3772		.9054	1.7541	1.6032
8		.415	.8488	.8488	1.8296	1.7541
9		1.226		.8299	1.7541	1.6032
10				1.1694	.4715	
11				1.5089	.3206	
12				1.6975	.3018	
13				1.6598	.3018	.3018
14				1.6975	.3206	.2829
15			.8488	1.7353	.2829	.2263
16		1.773	1.358	1.6975	.3018	.1886
17			1.6598	1.6032	.3395	.2452
18			1.6032	.4715	.3772	
19	1.0374		1.3203		.7167	.7545
20			1.2826	.7545	.7545	.7545
21	.7545		1.226	.7922	.7922	.6602
22			1.1317	.7545	.6602	.6036
23			1.094	.6979	.4715	.4715
24				.3772	.8488	.7922
Max	1.0374	1.773	1.6598	1.7353	1.8296	1.7541
Min	.7545	.3772	.0943	.3395	.2829	.1886
Avg	.8960	.9478	1.2139	.9734	.8165	.9148

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154032 / 33kv Matola

Feeder No / Name : 202 / 11kv water works express NON SHEDDABLE WATER SUPPLY AND  
feede Feeder KV- 11 / OUTGOING UTILITY

DATE	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0754	.0754	.0943
2				.0754	.0754	.0943
3			.0754	.0754	.0754	.0943
4			.0754	.0754	.0754	.0943
5			.0754	.0754	.0754	.0943
6				.0754	.0754	.0943
7		.0943		.0754	.0754	.0943
8		.3206		.0754	.0754	.0754
9		.0943		.0754	.0754	.0754
10				.0754		.0754
11				.0754	.0189	.0754
12				.0754	.0754	.0754
13				.0754		.0754
14				.0754		.0754
15			.0189	.0754		.0754
16		.0943	.0754	.0754	.0754	.0754
17			.0754	.0189	.0754	.0754
18			.0754	.0754	.0754	
19	.1886	.0754	.0754	.0943	.0754	.0754
20			.0754	.0754	.0754	.0754
21	.1886		.0754	.0754	.0754	.0754
22			.0754	.0754	.0754	.0754
23			.0754	.0754	.0754	.0943
24				.0754	.0754	.0943
Max	.1886	.3206	.0754	.0943	.0754	.0943
Min	.1886	.0754	.0189	.0189	.0189	.0754
Avg	.1886	.1358	.0707	.0738	.0726	.0828



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154032 / 33kv Matola

Feeder No / Name : 204 / Devtala Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.7922	.9431	1.1317
2				.8299	1.0374	1.1694
3			.7545	.8865	1.1694	1.226
4			.7545	.9431	1.226	1.358
5			.7545	.9619	1.3203	1.5089
6			.7545	.9431	1.4146	1.6975
7				1.1317	1.6221	1.8107
8				.7545	1.7353	1.9239
9				.6036	1.4523	1.8107
10				.1886		.8488
11				.9054	.6602	.8488
12				.9431	.9431	.9431
13				.9431		.9431
14				.9808		.9808
15			.5658			.7922
16		.3772	1.0374		.9431	1.1317
17			.4904	1.0185	1.226	1.226
18			.4715	.3772	1.3203	
19	.415		.9808	.4904	1.358	.4715
20			1.3203	.5658	.5093	.5093
21			1.2826	.5658	.5658	.4715
22			1.226	.4904	.4715	.4338
23			.9431	.3772	.3772	.3772
24				.7545	.6602	.6602
Max	.415	.3772	1.3203	1.1317	1.7353	1.9239
Min	.415	.3772	.4715	.1886	.3772	.3772
Avg	.415	.3772	.8720	.7476	1.0478	1.0554

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154032 / 33kv Matola

Feeder No / Name : 205 / Kavli Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1886	.1132	.0943
2				.2263	.0943	.1509
3			1.5586	.2263	.1509	.1886
4			.1886	.2829	.1886	.1886
5			.3018	.2829	.1886	.1886
6			.3018	.3018	.1886	.1886
7				.4338	.1886	.2829
8		.2829	.4715	.5658	.1886	.1886
9		.2829		.4715	.1886	.1509
10				.132	.415	
11				.1132	.5658	.7545
12				.0943	.679	.9054
13				.0943	.7167	.9431
14				.0943	.7545	.9054
15			.0943	.0943	.7922	.8865
16		.1886	.132	.0943	.7545	.9431
17			.132	.1132	.7545	.9808
18			.132	.132	.1509	
19	.2641		.1886		.1886	.1886
20			.1886	.1886	.1886	.2263
21			.132	.1886	.1886	.1886
22			.0943	.1886	.1886	.1509
23			.0943	.1132	.1509	.1132
24				.7922	.1132	.0943
Max	.2641	.2829	1.5586	.7922	.7922	.9808
Min	.2641	.1886	.0943	.0943	.0943	.0943
Avg	.2641	.2515	.2865	.2353	.3372	.4047

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154034 / 33/11 Kv Belkund S/S

Feeder No / Name : 201 / 11kv Belkund SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858			.3048	.2858	.6158	.381
2	.2858			.2858	.2858	.6927	.381
3	.3429			.2667	.3429	.7697	.5335
4	.3429			.2667	.3429	.8467	.6097
5	.381			.2667	.4763	.7697	.6097
6	.4763			.2858		.6927	.6401
7	.4763			.3048	.4268	.6158	.6401
8	.7621			.3239	.381	.5388	.6859
9	.381			.2858	.3429	.4618	.5335
10	.6668			.381	.4763	.6158	.1905
11	.8446			.5335	.4618		.2286
12	.7697			.5335	.5388		.2667
13	.6465				.6158		.2286
14			.2771		.6927		.1905
15			.2463	.381	.7697	.1905	.1905
16			.2463	.381	.8467		.2667
17			.2309	.3353	.7697		.2667
18		.1539	.2309	.4268	.6158	.2858	.2667
19		.1847	.2463	.4572	.3079	.381	.381
20		.2463	.2617	.381	.2771	.4191	
21		.2771	.2771	.3429	.2309	.381	.381
22		.2463	.2309	.3429	.2771	.381	.3067
23			.2771	.3429	.2771	.3429	.3429
24	.2858		.3079	.3239	.3429	.4618	.4191
Max	.8446	.2771	.3079	.5335	.8467	.8467	.6859
Min	.2858	.1539	.2309	.2667	.2309	.1905	.1905
Avg	.4963	.2217	.2575	.3525	.4515	.5257	.3887

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154034 / 33/11 Kv Belkund S/S

Feeder No / Name : 203 / 11 kv Karkhana Feeder NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0186			.0186	.0186	.0191	.0186
2	.0381			.0186	.0186	.0191	.0186
3	.0186				.0186	.0191	.0186
4	.0186			.0186	.0186	.0191	.0186
5	.0186			.0186	.0186	.0095	.0186
6	.0093			.0186	.0093	.0191	.0093
7	.0093			.0093	.0093	.0095	.0093
8	.0093			.0093	.0093	.0095	.0093
9	.0093			.0093	.0093	.0095	.0093
10	.0093			.0093	.0093	.0095	.0093
11	.0095			.0093	.0095	.0095	.0095
12	.0095			.0093	.0095	.0093	.0095
13	.0095		.0095		.0095	.0093	.0095
14			.0095		.0095	.0093	.0095
15			.0095	.0093	.0095	.0093	.0095
16			.0095	.0093	.0095	.0093	.0095
17			.0095	.0093	.0095	.0093	.0095
18			.0095	.0093	.0095	.0093	.0095
19		.0095	.0095	.0093	.0095	.0093	.0095
20		.0191	.0286	.0093	.0191	.0093	.0191
21		.0191	.0286	.0093	.0191	.0093	
22		.0191	.0286	.0093	.0191	.0186	.0191
23			.0286	.0093	.0191	.0186	.0191
24	.0093		.0191	.0286	.0093	.0191	.0186
Max	.0381	.0191	.0286	.0286	.0191	.0191	.0191
Min	.0093	.0095	.0095	.0093	.0093	.0093	.0093
Avg	.0141	.0167	.0167	.0124	.0129	.0126	.0131

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154034 / 33/11 Kv Belkund S/S

Feeder No / Name : 204 / Gukheda Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2955		.5668	.4858	.2448	.2915
2	1.4575		.6478	.5668	.2601	.2915
3	1.6194		.7287	.5668	.2754	.2915
4	1.9433		.8097	.5668	.2601	.2915
5	1.9433		.8907	.6478	.2448	.3239
6	2.1052		.9717	.8097	.0237	.3239
7	2.2672		1.0526	.8097	.2448	.3563
8	2.1052		.9717	.7287	.2601	.3239
9	2.1052		.9717	.6478	.2448	.2429
10	.1619		.1619	.1619	.2295	.4049
11	.153		.1619	.2295	.7649	.7649
12	.2295		.1619	.2601		.7649
13	.2295	.2295		.2448	.3239	
14		.2754		.2754	.6478	.7649
15		.2601	.1619	.2601	.5668	.7649
16		.2448	.1619	.2448	.6154	.5355
17		.2295	.1619	.2295	.6478	.7649
18		.2754	.1619	.153		.2295
19		.306	.2915	.2295	.2429	.3064
20		.306	.2915	.2448	.2915	.3829
21		.2754	.2915	.2295	.3239	.3849
22		.306	.2915	.2754	.3239	.3064
23		.2601	.2915	.2601	.2915	.306
24	.8097		.459	.4049	.2295	.2915
Max	2.2672	.306	1.0526	.8097	.7649	.7649
Min	.153	.2295	.1619	.153	.0237	.2295
Avg	1.3161	.2698	.4846	.3972	.3435	.4221

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154034 / 33/11 Kv Belkund S/S

Feeder No / Name : 205 / Malumbra Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2949			.2785	.2949	.6135	.5668
2	.2949			.2622	.2949	.6902	.6554
3	.2949			.2458	.3277	.7668	.7373
4	.3277			.2294	.3605	.8435	.8192
5	.3277			.2458	.3605	.9202	.9831
6	.3277			.2622	.4096	.9969	1.1469
7	.3277			.2785	.4096	.9202	1.3108
8	.3605			.2622	.3605	.8435	1.3108
9				.2458	.3277	.7668	1.3108
10					.3605	.7668	.1638
11	1.5337				.4601		
12	1.8404				.5368		
13	.2105		.1534		.6135		
14			.184		.7668	.1638	
15			.2607	.8192	.7668	.1638	
16			.2454	.7373	.9202	.1638	
17			.2301	.9012	.8435	.1638	.0162
18		.2454	.2454	.9012	.7668	.2458	.2301
19		.2761	.2607	.9831	.2301	.3277	.3067
20		.2607	.2761	.9012	.2454	.3605	.4601
21		.2301	.2914	.3277	.2301	.3605	.4601
22		.3067	.2301	.3277	.2301	.3277	.4601
23			.2607	.3277	.2607	.3277	.3834
24	.2949		.3067	.2785	.3277	.4601	.4096
Max	1.8404	.3067	.3067	.9831	.9202	.9969	1.3108
Min	.2105	.2301	.1534	.2294	.2301	.1638	.0162
Avg	.5363	.2638	.2454	.4640	.4460	.5330	.6517

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154041 / 33KV Jawalga S/S

Feeder No / Name : 201 / 11 KV Jawalga Feeder SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1715	.2743	.3048	.3125	.2984
2	1.2651		.1715	.3086	.3048	.3163	.2949
3			.1715	.3086	.3048	.3125	.3315
4	1.5813		.1715	.3429	.3963	.3906	.3277
5			.3429	.4115	.5182	.4687	.4534
6	2.2862		.4115	.6173	.8676	.5468	.5601
7			.4458	.6859	.7621	.703	.5535
8	2.4387		.463	.6859	.6859	.6249	.5535
9			.4458	.5144	.5487	.4687	.4001
10	.4144		.3429	.3772	.3048	.4687	1.0936
11	.2321		.2058	.3353	.2343	1.0774	1.3279
12	.2429		.1886	.3658	.1581	.9717	1.5432
13			.1715		.1581	.9012	1.5432
14	.1966				.1562		1.5432
15	.1524					1.1336	1.6204
16			.463		.1562	1.406	1.6667
17				.2439	.1581	1.406	1.6766
18			.3429	.2439	.2372	.2321	.2622
19			.4801	.3963	.5535	.4858	.4858
20			.4458	.4572	.5535	.6958	.6401
21			.4458	.3963	.506	.6478	.5182
22			.4458	.3658		.4049	.4049
23		.1334	.4115	.2439		.3224	.3239
24	.6325		.1905	.2401	.3048	.3125	.2984
Max	2.4387	.1334	.4801	.6859	.8676	1.406	1.6766
Min	.1524	.1334	.1715	.2401	.1562	.2321	.2622
Avg	.9442	.1334	.3300	.3908	.3892	.6352	.7801

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154041 / 33KV Jawalga S/S

Feeder No / Name : 203 / 11 KV Haregaon Feeder SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0381	.0377	.2829	.2686
2	.0905		.0381	.0377	.2801	.3582
3			.0381	.0381	.3734	.362
4	.0905		.0381	.0754	.3696	.4298
5			.0762	.0754	.3696	.4298
6	.1448		.1143	.1132	.5544	.6379
7			.1143	.1132	.7392	.7973
8	.2715		.1143	.1132	.7468	.8859
9			.0953	.0754	.7545	.815
10	.462		.2858	.1886	.0943	.0732
11	.924		.415	.462		.0924
12	.9955		.415	.5601		.0924
13			.3772	.5716		.0924
14	.9511	.2286	.3772	.6668		.0914
15	.7468	.3429	.3772	.6668		
16		.381	.415	.6668		
17		.381	.4715	.6668		
18		.3429	.0377	.0953		
19		.1524	.0377	.1905	.181	.0924
20		.1143	.1132	.1905	.181	.1829
21		.0762	.0754	.1143	.181	.1829
22		.0762	.0566		.1097	.1463
23		.0572	.0377		.0914	.1463
24	.0905	.0191	.0191	.0381	.0914	.1829
Max	.9955	.381	.4715	.6668	.7545	.8859
Min	.0905	.0191	.0191	.0377	.0914	.0732
Avg	.4767	.1974	.1741	.2617	.3375	.318



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154054 / 33KV BUDHODA

Feeder No / Name : 201 / 11kv budhoda

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6859	.7716			
2	1.1145	.6927					
3					1.2003		
4						.6859	
5	2.0576			1.3717			
6		.9005					
7	2.572				1.8861		
8	2.572	1.1257	1.5432	1.8861	.6859	.6936	.8573
9	2.3148	1.3508			1.8861		
10	.6859	.3464		.2572	.6859	1.7147	
12			.3429				
14	.3079			.2572			
15					.3079		
16			.1715	.3429		1.8861	
17					.3048		
18				.3429	.433	.5144	
19	.6927						
21				.8573	.8313		
22	.6927		.6859			.6859	
24	.7716			.7716	.7716	.6061	
Max	2.572	1.3508	1.5432	1.8861	1.8861	1.8861	.8573
Min	.3079	.3464	.1715	.2572	.3048	.5144	.8573
Avg	1.3782	.8832	.6859	.7621	.8993	.9695	.8573

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154054 / 33KV BUDHODA

Feeder No / Name : 202 / 11kv Selu SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1372	.12		
2	.0857	.0866				
3					.0857	
4						.6927
5	.0857			.1029		
6		.1039				
7	.1372				.12	
8	.0857	.0866	.1372	.1029	.0857	.9871
9	.0857	.0866			.0857	
10	.9431	.2425		.6859	.8573	.0514
12			.6859		.8005	
14	.8768			1.2003		
15					.8467	
16			.7716	1.2003		.0857
17					.7621	
18				.0857		.0857
21				.12	.1039	
22	.0866		.1372			.1372
24	.0857			.1372	.0857	.5195
Max	.9431	.2425	.7716	1.2003	.8573	.9871
Min	.0857	.0866	.1372	.0857	.0857	.0514
Avg	.2747	.1212	.3738	.4172	.3833	.3656

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154054 / 33KV BUDHODA

Feeder No / Name : 203 / 11kv Almala

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0857		
2	.0857				
3				.0857	
4					1.3855
5	.0857		.0857		
7	.0857			.0857	
8	.0857		.0857	.0857	2.2489
10	.7716		1.3717	.8573	.0857
12		1.5432		1.8496	
14	1.8858		1.7147		
15				2.0759	
16		1.7147	1.8861		
17				1.5242	
18			.0857	.0866	.0857
21			.0857	.0866	
22		.0857			.1372
24	.0857		.0857	.0857	.6061
<b>Max</b>	<b>1.8858</b>	<b>1.7147</b>	<b>1.8861</b>	<b>2.0759</b>	<b>2.2489</b>
<b>Min</b>	<b>.0857</b>	<b>.0857</b>	<b>.0857</b>	<b>.0857</b>	<b>.0857</b>
<b>Avg</b>	<b>.4408</b>	<b>1.1145</b>	<b>.6096</b>	<b>.6823</b>	<b>.7582</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154058 / 33KV Nagaarsoga S/S

Feeder No / Name : 201 / 11KV Tungi Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2347				
2	2.0119			.6882	.8048	.2883	1.8652
4	2.3205			.8192	1.1401	.3688	
6	2.4863			.9945	1.6575	.6001	
8	2.5434			1.2266	1.6095	.5087	
9							1.6575
10	.2374			.1989	.2774	1.1401	
12				.1658	.1658	1.5424	1.989
13			.8288				
14					.1509	1.576	1.9062
15			.2347	.1658			
16				.1658	.1341	1.56	1.9062
17			.2374				
18				.2012	.2294		
19			.4973				
20				.4359	.3647	.3121	.3978
22				.3688	.4144	.373	.4973
23		.1677		.3353			.426
24	.2607		.2347	.2949	1.5089	.3353	.3052
Max	2.5434	.1677	.8288	1.2266	1.6575	1.576	1.989
Min	.2374	.1677	.2347	.1658	.1341	.2883	.3052
Avg	1.6434	.1677	.3779	.4662	.7048	.7823	1.2167

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154058 / 33KV Nagaarsoga S/S

Feeder No / Name : 202 / 11 KV Nagarsoga Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3688				
2	.3353			.426	.3353	.3391	.373
4	.3647			.4915	.6706	.4191	
6	.5801			.6554	.6706	.7202	
8	.6443			.5967	.6796	.5935	
10	1.153			1.1271	1.3176	.4191	.3978
12					1.2929		.2984
13			.3315	1.0277			
14				.9945	1.3077	.2347	.1989
15			1.2071				
16				.9945	1.1401	.2374	.1989
17			.3052				
18				.2652	.2949	1.7878	1.5912
19			.7625				
20				.4024	.4973	1.595	1.4918
22					.4641	1.4582	1.2266
23				.3353			1.1469
24	.3887	.3353	.3688	.3932	.3353	.3688	1.3904
Max	1.153	.3353	1.2071	1.1271	1.3176	1.7878	1.5912
Min	.3353	.3353	.3052	.2652	.2949	.2347	.1989
Avg	.5777	.3353	.5573	.6425	.7505	.7430	.8314

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154058 / 33KV Nagaarsoga S/S

Feeder No / Name : 203 / 11KV Gadavewadi Feeder SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.2515		.2622	.2683	1.6108	1.8652
4	.2984			.4359	1.5089	
6	.4144			.4694	1.9719	
8	.5087		.3978	.3315	1.8991	
10	.2374			.2774	.2347	.2321
12			.0995		.1341	.1326
14			.1326	.1174	.1341	.0829
15		.1677				
16			.1658	.1341	.1357	.0829
17		1.0174				
18			1.6766	1.8842	.1753	
19		1.0159				
20			1.6244	1.9062	.3467	.2984
22			1.5424	1.8233	.373	.3277
23			1.5089			.2294
24	2.3482		.6554		1.6766	.2374
Max	2.3482	1.0174	1.6766	1.9062	1.9719	1.8652
Min	.2374	.1677	.0995	.1174	.1341	.0829
Avg	.6764	.7337	.8066	.7648	.8501	.3876

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154065 / 33KV Bheta S/S

Feeder No / Name : 201 / 11 KV Andhora feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3756	.0837	.4934	.2641	.4133	1.2058	.9671
2	.3791	.1005	.4563	.2665	.4884	1.2727	.9888
3	.4077	.1005	.5308	.3036		1.3397	1.0999
4	.527	.134	.6048			1.3732	
5	.5992	.134	.6811	.5287		1.4235	
6	.6921	.134	.7606	.6054		1.6077	1.7013
7	.8256	.1675	.9108	.7575	.8513	2.0264	2.1899
8	.8014	.201	.8341	.8324	.8513	1.8756	2.2583
9	.4007	.134	.7146	.5313	.7196	.5191	.6072
10	.3014	.0624	.4108	.319	.3684		.3738
11	.201		.2243	.075	.2512		.2268
12	.134		.1905	.0761	.1842		.2277
13	.134		.1524		.1675	.1884	.1898
14	.134			.1518	.1507	.2261	.1901
15	.134			.1898	.1675	.1513	.152
16			.1898	.1898	.1507		.1518
17		.6938	1.2016	1.3504	1.9259	.2641	.1859
18	.201		1.3397	1.4104	1.8421	.3206	.2598
19	.2177	.5944	1.1413	1.4066	1.7584	.5882	.415
20	.201		1.1083	1.2498	1.4737	.6615	.5249
21	.2177		.9535	1.1815	1.4235	.4472	.4133
22	.2177		1.0181	1.1111	1.4067	.4099	.3784
23	.201	.4731	.9556	1.1193	1.3397	.3402	.378
24	1.8568	.201	.427	.8344	1.0936		.3402
Max	1.8568	.6938	1.3397	1.4104	1.9259	2.0264	2.2583
Min	.134	.0624	.1524	.075	.1507	.1513	.1518
Avg	.4164	.2296	.6954	.6707	.8514	.8548	.6464

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154065 / 33KV Bheta S/S

Feeder No / Name : 202 / 11 KV Bheta Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0601	.1927	.3548	.3246		.2409	.2286
2	1.0973	.2249	.3844	.3649		.257	.2284
3	1.1866	.2249	.4134	.364		.2891	.2665
4	1.2088	.2409	.4424			.3212	.3042
5	1.383	.257	.4418	.4532		.3855	
6	1.574	.3212	.4731	.6059		.4818	.4563
7	1.6743	.3533	.5596	.7974	1.1416	.5782	.6452
8	1.4025	.3052	.5295	.7414	.5058	.4818	.4954
9	.3993	.3373	.3371	.4191	.4183	.8352	1.0157
10	.1445	.1875	.1905	.2469	.1767	.8215	.9937
11	.0964				.1606		.945
12	.0803	.1143			.0964	1.0218	1.1917
13	.0642	.1143			.0803	1.1509	1.1888
14	.0642					1.1866	1.1547
15	.0642					1.1866	1.1385
16			.1524				1.1772
17		.1139	.181		.1285		.1463
18			.2167	.1732	.1445	.1324	.1835
19		.2667	.5676	.3957	.4818	.3795	.3409
20	.3212		.5297	.3743	.4336	.4744	.4924
21	.2409		.378	.3784	.3855	.3791	.4158
22	.2249		.3027	.3398	.3212	.321	.3803
23	.1927	.3042	.2268	.3048	.2891	.2667	.3048
24	.2457	.1767	.2654	.2282	.2667	.2409	.4183
Max	1.6743	.3533	.5676	.7974	1.1416	1.1866	1.1917
Min	.0642	.1139	.1524	.1732	.0803	.1324	.1463
Avg	.6363	.2334	.3656	.4070	.3354	.5444	.6136



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154065 / 33KV Bheta S/S

Feeder No / Name : 203 / 11Kv Borgaon feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1524		.2662	.2515	
2			.1143		.3688	.2515	
3			.1129		.4463	.3018	
4			.1524		.5271	.3018	
5			.1905			.3521	
6			.2662			.4191	
7			.3033		.2422	.4694	
8			.3042		.1898	.4024	
9		.2347			1.3047	.3353	
10	2.1795		.8535		1.4083	.2277	
11	2.431		.8307		1.7604		
12	2.4143				1.7101		.1524
13	2.0119				1.3413		.1143
14	1.7604		1.4287		1.2071		.0762
15	1.6766				1.5089		.1141
16			1.4091		1.643		.1141
17			.263				1.8023
18			.3388		.2515		1.9662
19			.2701		.5868		1.8275
20					.4694		1.704
21			.3677	.3795	.3353		1.6057
22				.303	.3018		1.56
23				.2286	.3018		
24			.1905		.2286	.2515	
Max	2.431	.2347	1.4287	.3795	1.7604	.4694	1.9662
Min	1.6766	.2347	.1129	.2286	.1898	.2277	.0762
Avg	2.0790	.2347	.4440	.3037	.7809	.3240	1.0033

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154067 / 33KV SHIVALI S/S

Feeder No / Name : 201 / 11KV Shivali Feeder SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3277	.3277		.3277	.3048	.3048
2	.3277	.3277	.3277	.3277	.3048	.3048
3	.3277	.3277		.3277	.3048	.3048
4	.3277	.3277		.4096	.3048	.3048
5	.4096	.3277		.4915	.381	.3048
6	.4915	.3277		.4915	.381	.3048
7	.4915	.3277		.5735	.381	.3048
8	.4915			.5735	.381	.4915
9	2.0481			.9831	.3048	.4915
10	2.3758			.7621	.2286	.4096
11				.8383	.2286	.2458
12				.8383	.2286	.2458
13		.4096		.9145	.2286	.2458
14		.5735		.7621	.2286	.1638
15		.6554		.8278	.2286	
16		.6554	.9831	.8383	.2286	
17			.9831	.7621	1.2193	
18			.8192	.1524	1.2193	.9774
19		.4096	.9831	.3048	1.2193	1.3765
20		.5735	.4915	.381		1.3765
21		.4915	.4915	.381		1.3765
22		.4096	.4096	.3048		1.2955
23		.3277	.3277	.3048		1.2955
24	.3277	.3277	.3277	.3277	.3048	1.2193
Max	2.3758	.6554	.9831	.9831	1.2193	1.3765
Min	.3277	.3277	.3277	.1524	.2286	.1638
Avg	.7224	.4193	.6144	.5502	.4305	.6355

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154067 / 33KV SHIVALI S/S

Feeder No / Name : 202 / 11KV Jaifal Feeder SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3277	.3277		.3277	.6859	1.2193
2	.3277	.3277	.4096	.3277	.6859	1.2193
3	.3277	.3277	.3277	.3277	.7621	1.2193
4	.3277	.3277	.3277	.3277	.7621	1.2193
5	.4096	.3277	.3277	.4096	.8383	1.3717
6	.4096	.3277		.4096	.9145	1.5242
7	.4096	.3277	.3277	.3277	.9145	1.5242
8	.4096	.2458		.3277	.9145	1.6194
9	.3277	.2458		.2458	.1524	.3277
10	.3277	.2458		.2286	.1524	.3277
11		.3277			.1524	.1638
12		.3277		.5335	.1524	.1638
13		.0819		.1524	.1524	.1638
14		.0819			.1524	.1638
15		.0819		.1524	.1524	.1638
16		.0819	.3277	.1524	.1524	.1638
17		.9831	1.1469	.7621	.1524	.1638
18		.6554	.9831	.8383	.1524	.1638
19		.7373	1.3108	.6859	.2286	.3277
20		.8192	1.1469	.7621		.3277
21		.6554	1.1469	.7621		.3277
22		.5735	.8192	.7621		.3277
23		.5735	.8192	.6859		.3277
24	1.4746	.5735	.5735	.1524	.6859	.1905
Max	1.4746	.9831	1.3108	.8383	.9145	1.6194
Min	.3277	.0819	.3277	.1524	.1524	.1638
Avg	.4617	.3994	.7139	.4392	.4458	.6130

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154067 / 33KV SHIVALI S/S

Feeder No / Name : 203 / 11KV Warwada Feeder SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3108	.3277	.1638	.2458	.1524	.3048
2	1.3108	.3277	.1638	.2458	.1524	.3048
3	1.382	.1638	.1638	.3277	.1524	.3048
4	1.4746	.1638	.2458	.3277	.2286	.3048
5	1.6385	.1638	.3277	.3277	.381	.3048
6	1.6385	.1638		.4096	.4572	.3048
7	1.9662	.1638	.3277	.5735	.4572	.3048
8	1.9662	.1638		.5735	.381	.3277
9	.3277	.1638		.2458	.5335	.8192
10	.2458			.2286	.5335	.9831
11				.1524		1.0588
12				.1524		.9774
13				.1524	.4572	1.0588
14				.1524	.4572	.9774
15				.1524		.9831
16			.3277	.1524	.4572	1.0588
17			1.1469	.0762	.6097	.0819
18		.3277	.2458	.0762	.6097	.0819
19		.2458	.2458	.2286	.6097	.2458
20		.2458	.3277	.2286		.3277
21		.2458	.3277	.2286		.2458
22		.2458		.2286		.2458
23		.1638	.1638	.1524		.1638
24	.1638	.3277	.1638	.1638	.1524	.3048
Max	1.9662	.3277	1.1469	.5735	.6097	1.0588
Min	.1638	.1638	.1638	.0762	.1524	.0819
Avg	1.2204	.2253	.3101	.2418	.3990	.5031

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154074 / 33KV DHANORA

Feeder No / Name : 201 / 11KV Gondri

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.703	.7316	.6097	.8299	.8535	1.1279
2	.7468	.6859	.7926	.6706	.8299	.9755	1.0822
3	.7468	.6516	.823	.7468	.811	1.0669	1.2803
4	.8402	.6859	.884	.8078	.8676	1.2041	1.4022
5	.8402	.7545	.823	.8535	.9242	1.3413	1.5851
6		.084	.9145	.884	.9808	1.3717	2.1491
7		.9259	.884	.8383	1.0185	1.6766	2.3624
8		.9602	.7926	.7926	1.0562	1.7985	2.271
9	.9088	.823	.7621	.7621	.9242	1.8747	2.21
10	1.448	.7011	.6859	.884	1.2239	.442	.5792
11	2.1643	1.0669	1.0212	1.4251	1.4327	.3048	.3584
12	2.1643	1.1888	.9297	1.2742	1.7071	.2743	.3206
13	2.2862	1.2498	.9907	1.5257	1.6766	.2439	.3206
14		1.1888	1.0974	1.6095	1.448		
15		1.0974	1.0059	1.6263			.3018
16		1.0974	1.0669	1.643	1.0364	.3353	.3206
17		1.0974	1.1279	1.6095		.3048	.3395
18		.5487	.503	.4527	1.4022	.4115	.3772
19		.5792	.7621	.8299	.6401	.5182	.8865
20		.6097	.884	.9808	.6706	.884	.9808
21		.6401	.8383	1.0562	.5792	.8383	1.0562
22	.6344	.7316	.7926	1.0374	.5335	.7926	.9431
23	.7202	.7621	.7164	.9431	.4877	.7621	.8299
24	.8215	.703	.6706	.6401	.8676	.7316	1.0364
Max	2.2862	1.2498	1.1279	1.643	1.7071	1.8747	2.3624
Min	.6344	.084	.503	.4527	.4877	.2439	.3018
Avg	1.1591	.814	.8542	1.0210	.9976	.8639	1.0487

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154074 / 33KV DHANORA

Feeder No / Name : 202 / 11KV Dhanora

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4937			.9145	.7421	.5182	.4572
2	1.6804			.884	.8859	.5487	.503
3	1.8671			.9297	1.0867	.5792	.5792
4	2.0538			.9907	1.283	.6097	.6249
5	2.1472			.945	1.4232	.6401	.6706
6	2.2218			1.0517	1.6108	.7316	.7011
7				1.6918	1.8107	.6706	.7316
8	2.4272			1.89	1.9448	.6554	.6859
9	2.21	.503		1.7985	1.9784	.5487	.503
10	.4458	.9145	.3048	.4572	.547	1.1888	1.0974
11	.3429	.884	1.2651	.3206	.3658	1.448	1.9784
12	.2401	.8078	1.1279	.2452	.2743	1.6613	2.0287
13	.2401	.6706	1.2955	.2075	.3201	1.7528	2.1628
14		.4877	1.2955	.2641	.3353	1.6613	1.89
15		.2439	.2591	.2452		1.7985	2.1125
16		.2591	.3048	.2641	.2743	1.829	2.146
17		.2439	.3353	.2641	.3048		2.1293
18		.3048	.381	.2641	.3048	.3201	.3018
19		.3353	.5335	.5658	.6097	.4572	.547
20		.3963	.6706	.679	.5792	.6859	.7545
21		.4268	.6401	.6602	.5639	.6401	.6979
22		.4877	.6097	.6413	.5487	.5792	.5658
23		.5182	.5335	.5658	.5182	.5182	.5847
24	.9709			.9602	.5792	.4877	.4725
Max	2.4272	.9145	1.2955	1.89	1.9784	1.829	2.1628
Min	.2401	.2439	.2591	.2075	.2743	.3201	.3018
Avg	1.4108	.4989	.6826	.7375	.8213	.8926	1.0386

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154092 / 33KV Wanwada S/S

Feeder No / Name : 201 / 11KVBorfal Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-MAR-17	18-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2321		
2		.2321		
3		.2785		
4		.3277		.3277
5		.3768		
6		.426		.4641
7		.4915		.5407
8		.7537		.3932
9		.7209		.2949
10		.852		.1989
14			.0995	
15	.852			
16	.1658			
17	.1865		.431	
18	.1865		1.4255	
19	.3315		1.2616	
20	.4144		1.2597	
21	.3315		1.2289	
22	.3315		1.1437	
23	.3018		1.1105	
24		.2652		
Max	.852	.852	1.4255	.5407
Min	.1658	.2321	.0995	.1989
Avg	.3446	.4506	.9951	.3699

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154092 / 33KV Wanwada S/S

Feeder No / Name : 202 / 11KV Shindala(L)Feeder SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	20-MAR-17
HR	Load (MW)
20	.3315
Max	.3315
Min	.3315
Avg	.3315



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154112 / 33 KV MIDC SUB-STATION AUSA.

Feeder No / Name : 201 / 11 KV NEW MIDC FEEDER.

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.1886	.2452	.1698	.2829	.2829	.2829
2	.2263	.2075	.2452	.1698	.2829	.2829	.2641
3	.2263	.2075	.2452	.1698	.2829	.2641	.2641
4	.2263	.2075	.2641	.1698	.2829	.2829	.2641
5	.2452	.2075	.2641	.1886	.2829	.2829	.2829
6	.2452	.2452	.2641	.1886	.2641	.2829	.2829
7	.2641	.2075	.2641	.2263	.2829	.3018	.3018
8	.2641	.2263	.2829	.2263	.2641	.3018	.3018
9	.2641	.2263	.2075	.2263	.2263	.2829	.3018
10	.7167	.4338	.2075	.3772	.3206	.3395	.4715
11	.8676	.679	.6036	.3772	.3206	.5658	.5847
12	.7733	.7356	.1886	.6413	.3395	.6224	.5658
13	.7356	.6413	.2075	.4715	.3395		.5658
14	.6602	.5847	.1886	.4715	.3772	.6036	.679
15		.5281	.1698	.4904	.3772		.6413
16	.3206	.415	.1886	.3018	.3584	.6413	.7356
17	.3961	.3961	.1886		.3395		.5281
18	.3395	.5281	.1886	.3772	.2829	.5658	.5281
19	.2829	.4715	.2075	.4715	.3018		.4904
20	.3584	.4904	.1886	.547	.2829	.3772	.4338
21	.2075	.2829	.1886	.3395	.2641	.3018	
22	.2075	.2641	.1886	.2829	.2829	.3018	
23	.1886	.2452	.1698	.2641	.2829	.3395	.132
24	.2452	.2075	.2452	.1698	.2641	.2829	.3018
Max	.8676	.7356	.6036	.6413	.3772	.6413	.7356
Min	.1886	.1886	.1698	.1698	.2263	.2641	.132
Avg	.3690	.3678	.2334	.3182	.2994	.3753	.4184

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418]

BU 5185

Substation No/ Name :- 154112 / 33 KV MIDC SUB-STATION AUSA.

Feeder No / Name : 202 / 11 KV CHOWRASTA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0494	.8379	1.0471	.9806	.9765	1.0823	1.0669
2	1.0111	.8303	1.0318	.9707	.9858	1.0379	1.0532
3	1.0004	.8057	1.0196	.9669	.9728	1.0257	1.0379
4	1.0296	.8442	1.048	.9861	.9751	1.0457	1.0625
5	1.0831	.9454	1.1009	.8604	1.0296	1.1292	1.0831
6	1.2486	1.0701	1.2811	1.0945	1.1896	1.2447	1.203
7	1.5118	1.1668	1.366	1.1959	1.4078	1.4543	1.2915
8	1.515	1.2656	1.4325	1.3712	1.3704	1.5131	1.3075
9	1.4247	1.207	1.2422	1.2799	1.2776	1.3857	1.2869
10	.6249	1.1458	1.1349	1.2182	1.2608	1.2079	1.1618
11	1.2737	1.128	1.211	1.1372	1.3017	1.219	1.2473
12	1.4245	1.162	1.2113	.9673	1.3207	1.1955	1.2134
13	1.4333	1.2235	1.2517	1.2267	1.3189	.6988	1.5269
14	1.3012	1.2763	1.1626	1.4211	1.3704	1.3654	1.4895
15	.6127	1.1704	1.0003	1.3773	1.3567	.7034	1.4609
16	.9252	.583	1.0351	1.2938	1.3576	1.3005	1.3935
17	.9964	1.4011	.9313	1.27	1.3499	.727	1.4898
18	1.2151	1.372	1.029	1.3576	1.3029	1.3098	1.5474
19	1.4319	1.6449	1.7181	1.6396	1.713	.8596	1.9001
20	1.3329	1.6636	1.6282	1.6758	1.7934	1.6019	1.9304
21	1.2823	1.6072	1.4369	1.5564	1.6811	1.5316	1.715
22	1.126	1.3852	1.3098	1.4314	1.4803	1.3977	1.5564
23	1.0111	1.2367	1.139	1.2198	1.3372	1.2588	1.4085
24	1.0448	1.0189	1.0541	1.0937	1.1372	1.155	1.1809
Max	1.515	1.6636	1.7181	1.6758	1.7934	1.6019	1.9304
Min	.6127	.583	.9313	.8604	.9728	.6988	1.0379
Avg	1.1629	1.1663	1.2009	1.2330	1.3028	1.1854	1.3589

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154112 / 33 KV MIDC SUB-STATION AUSA.

Feeder No / Name : 203 / 11 KV SAMTA NAGER SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6694	1.4377	1.6234	1.5962	1.6644	1.7509	1.7707
2	1.629	1.4413	1.6006	1.5537	1.5964	1.6947	1.7288
3	1.5993	1.439	1.5958	1.5522	1.6008	1.6871	1.7115
4	1.6181	1.455	1.5859	1.5695	1.6174	1.7263	1.6993
5	1.7162	1.6257	1.6924	1.66	1.7357	1.8433	1.8321
6	2.1133	2.1209	2.0889	2.0192	2.03	2.3772	2.1643
7	2.6445	2.361	2.417	2.3806	2.4029	2.5599	2.448
8	2.5439	2.5585	2.5728	2.5065	2.4877	2.6349	2.6174
9	2.3684	2.1119	2.4198	2.3602	1.2849	2.3547	2.4718
10	2.1863	2.0937	2.1723	2.1628	2.5599	2.111	1.8873
11	2.168	1.9123	2.1089	1.8246	2.3568	1.9651	2.0192
12	2.0056	1.7917	1.9353	1.8248	2.3528	1.8728	2.0087
13	1.9965	2.0519	1.7	1.7187	2.1858	1.0258	2.0344
14	1.9125	2.0125	1.7298	1.8879	2.2449	1.9045	2.1316
15	.9762	1.9723	1.7818	1.6793	2.1573	1.0174	2.0443
16	1.5067	1.9904	1.7035	.8455	2.0357	1.8309	1.893
17	1.4558	1.9681	1.6722	.9071	1.9247	1.0197	1.9856
18	1.8126	2.1653	1.7322	1.3529	1.9776	1.8744	2.1055
19	1.0181	2.3972	2.4486	2.9703	2.7148	1.3527	2.8255
20	2.2472	2.7163	2.4878	2.9615	2.8899	2.779	2.9076
21	2.2423	2.5557	2.3792	2.6452	2.7121	2.6288	2.759
22	1.8847	2.2162	2.1481	2.4139	2.3989	2.4648	2.4991
23	1.648	1.9317	1.8357	2.0775	2.126	2.1746	2.1556
24	1.5972	1.585	1.6964	1.7759	1.9117	1.881	1.9281
Max	2.6445	2.7163	2.5728	2.9703	2.8899	2.779	2.9076
Min	.9762	1.4377	1.5859	.8455	1.2849	1.0174	1.6993
Avg	1.8567	1.9963	1.9637	1.9269	2.1237	1.9388	2.1512

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 157009 / 132 KV AUSA S/S

Feeder No / Name : 403 / 33 KV BHADA

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.6296	3.8923	4.3038	4.1152	4.561	4.6125	5.1097
2	4.3896	3.738	4.1838	4.0124	4.4067	4.4239	4.8697
3	4.3553	3.7209	4.0981	3.9781	4.321	4.3381	4.6296
4	4.321	3.7723	4.1324	3.9609	4.1838	4.3553	4.5953
5	4.6982	4.1667	4.441	4.1667	4.4582	4.6296	4.784
6	5.5384	5.1269	5.2298	5.024	5.0755	5.6756	5.8299
7	6.3615	5.727	5.9671	5.4184	5.9671	6.2929	6.2757
8	6.5501	6.0185	6.3786	6.6187	6.3958	6.7044	6.8759
9	6.4301	5.7956	6.1043	6.4643	6.19	6.3443	6.4129
10	6.2071	6.0871	5.8299	6.2071	6.773	6.2586	6.7215
11	6.9102	6.1214	5.8299	6.0185	6.5158	6.4472	6.5844
12	7.6818	6.5501	5.607	6.0871	6.4986	6.8416	6.7558
13	7.6818	6.9616	5.0926	5.7442	6.5158	7.0988	7.1159
14	7.2874	6.7558	5.0412	6.773	6.3958	6.9616	7.3045
15	6.4815	6.6873	4.8868	6.6358	6.2071	6.9273	7.0988
16	4.7497	6.4129	4.9897	4.6125	6.1043	6.8416	6.9102
17	4.4582	5.6756	4.8868	3.5665	5.8299	7.1845	6.7558
18	5.5384	6.6358	4.9211	4.3896	5.7442	6.9102	6.7044
19	6.1214	7.3217	6.8244	8.179	7.013	8.0933	8.1104
20	5.3327	7.9218	7.0816	8.8649	7.6303	8.4362	8.7277
21	6.19	7.5617	6.3443	7.9218	7.3903	8.059	7.8532
22	5.4527	6.2243	5.8471	6.5672	6.4815	6.8759	6.6187
23	4.7668	5.4698	5.1269	5.9499	5.8814	6.4301	5.8299
24	4.1838	4.7325	4.3724	5.1269	5.0926	5.6242	5.0755
Max	7.6818	7.9218	7.0816	8.8649	7.6303	8.4362	8.7277
Min	4.1838	3.7209	4.0981	3.5665	4.1838	4.3381	4.5953
Avg	5.6799	5.7949	5.3134	5.6834	5.9014	6.3486	6.3979

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154008 / 33 kv s/s killari

Feeder No / Name : 202 / 11 kv Yelawat AG feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.4801	.4801
2						.4458	.4801
3						.3429	.5144
4						.3429	.5316
5						.4115	.5487
6						.4458	.6173
7						.4458	.6516
8						.4115	.6859
9						.4115	.8573
10	.4801	.1715	.2058	.2058	.2572		
11	.583	.1715	.3086	.3086	.5144		
12	.6516		.3772	.3772	.6001		
13	.7545		.4287	.5144	.7888		
14	.8573	.2058	.5144	.5487	.8573		
15	.9431	.3429	.6001	.6516	.823		
16		.3772	.5658	.5658	.9431		
17		.4287	.6001	.6859	.583		
24						.3086	.4458
Max	.9431	.4287	.6001	.6859	.9431	.4801	.8573
Min	.4801	.1715	.2058	.2058	.2572	.3086	.4458
Avg	.7116	.2829	.4501	.4823	.6709	.4046	.5813

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154008 / 33 kv s/s killari

Feeder No / Name : 203 / 11 kv Old Killari Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.463	.4115	.4115	.5144	.9259	.4458
2	.5487	.4801	.4115	.4458	.5487	.9945	.4115
3	.6001	.4458		.4801	.4801	.9259	.4287
4	.5658	.463		.463	.4458	.8573	.4458
5	.5487	.4973		.5144	.4115	.7888	.4801
6	.6516	.4801		.583	.3429	.7888	.5144
7	.6001	.3429		.4287	.4115	.7545	.6001
8	.7373	.1886		.3429	.4115	.7888	.7202
9	.7716	.1372	.3429	.1715	.4458	.7545	
10	.8916	.1886	.2915	.3601	.6001	.3429	.3086
11	1.1488	.2915	.3601	.5144	.7545	.3772	.3429
12	1.3546	.3258	.5144	.6687	.9259	.4287	.4287
13	1.4575	.1715	.6001	.6344	1.0288	.463	.3944
14	1.406	.4801		.6001	.7888	.4801	
15	1.2003	.5316		.6516	.8573	.5144	.4287
16		.5658	.5487	.3429	.823	.4801	.5144
17		.6001	.5144	.3086	.8573	.4458	
18	.2915	.1715	.2915	.3429	.4115	.3429	.1715
19	.3601	.2058	.3601	.3429	.4115	.3601	
20	.4287	.2401	.4115	.2743	.4458	.3772	.2401
21	.463	.2058	.4458	.2401	.5144	.3944	
22	.4115	.1715	.4115	.2401	.4115	.4287	.2058
23	.3601	.2058	.3601	.2058	.3429	.4115	.2743
24	.5144	.4287	.583	.3944	.6516	.8916	.4287
Max	1.4575	.6001	.6001	.6687	1.0288	.9945	.7202
Min	.2915	.1372	.2915	.1715	.3429	.3429	.1715
Avg	.7178	.3451	.4287	.4151	.5765	.5966	.4097

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154008 / 33 kv s/s killari

Feeder No / Name : 204 / 11 KV Talani Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.3429	.4115	.3429	.5144	.7545	.4801
2	.4458	.3258	.4458	.3258	.5487	.7202	.4458
3	.5144	.2915	.4458	.3601	.6173	.6859	.463
4						.6516	.4801
5						.6859	.5144
6						.7202	.583
7							.6516
8						.7202	.7716
9				.2572			.9431
10	.6001	.3772	.4115	.2572	.5144		
11	1.0288	.3258	.4287	.3429	.6001		
12	1.1317	.3429	.4458	.3772	.6859		
13	.9431	.3772	.4801	.5144	.8573		
14	.9774	.3429	.4287	.6516	.6001		
15	.9259	.2915	.3429	.6859	.6173		
16		.3429	.5144	.4287	.6516	.1715	.1715
17		.3772	.4287	.5144	.6859	.2401	
18	.3772	.3086	.3429	.5144	.3086	.2915	.3086
19	.4458	.2743	.4115	.583	.3429	.3601	
20	.4801	.2743	.4801	.583	.3772	.4115	.3429
21	.5487	.2401	.5144	.5144	.4115	.4458	
22	.4973	.2743	.4801	.4801	.4458	.5144	.2401
23	.4287	.2743	.4287	.4458	.4115	.4801	.2058
24	.4458	.3601	.4115	.3429	.4115	.7888	.463
Max	1.1317	.3772	.5144	.6859	.8573	.7888	.9431
Min	.3772	.2401	.3429	.2572	.3086	.1715	.1715
Avg	.6419	.3191	.4363	.4485	.5334	.5401	.4710

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154026 / 33/11 KV LAMJANA SUBSTATION

Feeder No / Name : 201 / 11 KV Jawali Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7373			.5487	.6001	.2572	.2743
2	.8002			.6135	.6135	.2572	.2715
3	.7907			.6135	.6859	.3429	.3658
4	.8802			.7011	.7011		
5	.9488			.6859	.7973		
6	1.1469			.8573	.8859		
7	1.4746			1.0288	1.2269		
8	1.4746	.3315		.9831	1.2431		
9	1.4089	.3315		.9831	1.286		
10		.3315				.5144	.7202
11		.3429	.2743			1.0402	.8288
12			.6135			1.1469	.9945
13			.7716			1.0669	1.0774
14			.7716			1.1069	1.0774
15			.7716		.1715	1.1069	1.1603
16		.0905	.2801	.1581	.1715	1.0155	1.2431
17		.1715	.3772	.1581	.1677	1.0936	1.1603
18		.2515	.4763	.1581	.1715	.1867	.1867
19		.3429	.5658	.2401	.3353	.4572	.2801
20			.5716	.4001	.503	.3429	.3734
21			.4572	.4096	.4287	.3467	.5601
22			.4668	.3239	.3353	.3658	.5601
23			.381	.2372	.2572	.2743	.3734
24	.703			.4382	.503	.2572	.2743
Max	1.4746	.3429	.7716	1.0288	1.286	1.1469	1.2431
Min	.703	.0905	.2743	.1581	.1677	.1867	.1867
Avg	1.0365	.2742	.5214	.5299	.5834	.6211	.6545



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154026 / 33/11 KV LAMJANA SUBSTATION

Feeder No / Name : 203 / 11 KV Kharosa Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2515			.2858	.2515	.2572	.5258
2	.2486			.2743	.2515	.3429	.6001
3	.3353			.3506	.3353	.3353	.6001
4						.4096	.6859
5						.4687	.6783
6						.5335	.7373
7						.6097	.7621
8						.6097	.7811
9						.5335	.7621
10	.503			.2743	.2515		
11	.8288		.1829	.1581	.3429		
12	.9945	.1677	.3429	.3353	.4191		
13	.9945	.3239	.4572	.3353	.4858		
14	.9116	.3906	.2743	.2515	.4572		
15	.8288	.381	.3658	.3353	.5335		
16		.381	.3429	.2515	.6097	.0857	.0934
17			.4668	.3353	.6097	.0905	.2801
18	.1867			.1677	.0857	.1715	.4668
19	.3734		.5716	.4191	.3353	.5087	.6535
20			.5658	.503	.5868	.503	.6535
21			.4572	.503	.4191	.4915	.5601
22			.3734	.4191	.3429	.4382	.4668
23			.3658	.3353	.2572	.362	.3734
24	.2515			.2743	.2515	.2572	.362
Max	.9945	.3906	.5716	.503	.6097	.6097	.7811
Min	.1867	.1677	.1829	.1581	.0857	.0857	.0934
Avg	.5590	.3288	.3972	.3227	.3792	.3894	.5579

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154026 / 33/11 KV LAMJANA SUBSTATION

Feeder No / Name : 204 / 11 KV Lamjana II SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.2486		.5487	.443	.3429	.5487
2	.6859	.2801		.6335	.4477	.3429	.5144
3	.6783	.3734		.7164	.5316	.4287	.5144
4	.7716	.3315		.7888	.5373		
5	.8573	.4973		.8573	.6201		
6	1.0288	.5801		.8573	.7164		
7	1.4575	.5801		.9221	.8859		
8	1.5432	.5801		.9431	1.0288		
9	1.4089	.663		.8592	.9116		
10							.8697
11			.7011			.9145	.9945
12			.8573			.8802	1.0774
13			.6859			.9488	1.0774
14			.6859			.9374	1.0774
15						.9374	1.1603
16		.3429		.5716	.4287	.9602	1.0774
17		.4287	.7011	.6668	.5668	1.0402	.9945
18		.503	.823	.4763	.6001	.7287	.3734
19	.3734	.6001	.9335	.7621	.7287	.7287	.5601
20	.5601		.9431	.9526	.9221	.7545	.6535
21	.5601		.7621	.8573	.6859	.8192	.7468
22	.5601		.7545	.6668	.6001	.6859	.6535
23	.4668		.6535	.4763	.4287	.5258	.4668
24	.5801	.3315		.381	.3544	.3506	.5144
Max	1.5432	.663	.9431	.9526	1.0288	1.0402	1.1603
Min	.3734	.2486	.6535	.381	.3544	.3429	.3734
Avg	.8145	.4529	.7728	.7187	.6354	.7251	.7708

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154026 / 33/11 KV LAMJANA SUBSTATION

Feeder No / Name : 206 / 11 KV Chalburga SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2429	.2801		.3772	.2458	.5144	.6001
2	.2458	.2801		.3734	.2429	.6001	.6859
3	.3277	.3734		.3658	.3315	.6706	.6859
4						.7545	.7373
5						.8097	.7811
6						.9145	.9145
7						.9907	1.0669
8						.9907	1.0669
9						.9145	.9145
10	.7202	.3315		.5487	.4687		
11	1.0774	.5601	.4572	.6325	.8573		
12	1.1603	.5535	.5144	.4744	.9145		
13	1.1603	.5868	.6001	.2372	.9145		
14	1.0774	.6859	.6001	.08	.9145		
15	1.0774	.7545	.6001	.4049	.9145		
16		.7202	.6001	.5468	.9145	.0876	.0934
17		.7545	.6001	.5601	.8383	.0914	.1867
18		.1619	.2829	.1562	.1715	.1772	.2801
19	.2801	.2572	.3772	.2343	.2515	.3429	.3734
20	.3734		.4572	.2429	.4191	.3391	.4668
21	.3734		.381	.2429	.4287	.4191	.4668
22	.4668		.2858	.2458	.3429	.362	.4668
23	.3734		.2858	.2429	.2629	.2801	.3734
24	.2572	.3734		.3658	.2858	.5144	.5144
Max	1.1603	.7545	.6001	.6325	.9145	.9907	1.0669
Min	.2429	.1619	.2829	.08	.1715	.0876	.0934
Avg	.6142	.4767	.4648	.3518	.5400	.5430	.5931

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154055 / 33 KV SUB STATION KHAROSA

Feeder No / Name : 201 / 11 KV Tambarwadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	.4287	.5144	.6001	.7716	.3048	.3048
2	1.0669	.5144	.5144	.6859	.6859	.3429	.3048
3	1.4575	.5144	.6001	.6859	.8573	.4287	.3048
4	1.7147	.6001	.6001	.7621	.9907		
5	1.7147	.6001	.6859	.8573	1.1145		
6	1.8861	.6001	.7716	1.0288	1.2003		
7	1.829	.6859	.8573	1.1145	1.3717		
8	1.829	.4572	1.1145	1.1145	1.4575		
9	2.0576	.3429	1.1331	1.5432	1.5432		
10						.6097	.7845
11						1.2193	1.3074
12						1.2955	1.3946
13						1.2955	1.4818
14						1.2193	1.3074
15						1.2955	1.4818
16		.3048	.3487	.3429	.3487	1.2955	1.4952
17	.3487	.3048	.3487	.3429	.3738	1.5432	1.4818
18	.3487	.381	.3738	.3429	.3487	.3048	.3487
19	.4358	.4572	.3487	.2572	.4358	.3048	.3487
20		.4572	.4358	.5144	.523	.381	.523
21	.2572	.381	.3487	.4572	.4358	.381	.4673
22	.3429	.3048	.3429	.4287	.4287	.3048	.381
23	.3429	.3429	.3429	.3429	.3429	.3048	.3429
24	.5144	.3429		.5144	.381	.3048	
Max	2.0576	.6859	1.1331	1.5432	1.5432	1.5432	1.4952
Min	.2572	.3048	.3429	.2572	.3429	.3048	.3048
Avg	1.0734	.4456	.5695	.6631	.7562	.7298	.8271

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154055 / 33 KV SUB STATION KHAROSA

Feeder No / Name : 202 / 11 KV Shivani-Luc SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1715	.1524	.1524	.2286	.3048
2	.1524	.1524	.1715	.1715	.1524	.4287	.3048
3	.1524	.1524	.1715	.1524	.1524	.381	.3048
4						.5335	.381
5						.6097	.4572
6						.7621	.5335
7						.7621	.6097
8						1.0288	.6944
9						.9981	.6173
10	.4572		.3086	.2286	.3048		
11	.5401	.381	.3086	.3048	.3086		
12	.6173	.381	.3086	.3048	.3858		
13	.6173	.4572	.3086	.5355	.7716		
14	.5401	.4572	.3086	.6097	.463		
15		.4572	.3086		.463		
16		.4572	.3086	.6097	.463	.0762	.0772
17	.1543	.4572	.3086	.6097	.463	.0762	.0772
18	.0772	.0762	.0772	.0762	.0772	.0762	.0772
19	.1543	.2286	.1543	.0762	.1543	.1524	.1543
20	.1524	.2286	.1543	.1524	.1543	.2286	.1543
21	.1524	.2286	.1543	.1524	.1543	.2286	.1543
22	.1524	.1524	.1524	.1524	.1524	.1524	.1524
23	.1524	.1524	.1524	.1524	.1526	.1524	.1524
24	.1524	.1524		.1524	.3086	.3048	
Max	.6173	.4572	.3086	.6097	.7716	1.0288	.6944
Min	.0772	.0762	.0772	.0762	.0772	.0762	.0772
Avg	.2736	.2779	.2252	.2702	.2908	.3989	.3063

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154055 / 33 KV SUB STATION KHAROSA

Feeder No / Name : 203 / 11 KV Kharosa SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.5335	.4287	.5335	.5335	.6859	.6097
2	.6859	.5335	.4287	.6097	.6097	.6859	.6097
3	.6859	.6097	.4287	.6127	.6859	.7621	.6859
4						.7621	.6859
5						.9145	.8383
6						.9907	1.0669
7						.9907	1.2193
8						1.2193	1.2955
9						1.5242	1.2894
10	.8383		.5641		.6097		
11	.4835	.5335	***		.8865		
12	.9671	.5335	.5641	.7621	.8059		
13	1.4506	.5335	.6447	.9145	.8865		
14	1.37	.5335	.4835	.9145	.8059		
15		.6097	.6447	.9907	.8059		
16		.6097	.6447	1.0669	.8059	.0305	.2418
17		.6097	.6447	.9907	.8059	.4572	.4029
18		.5335	.4029	.7621	.2418	.5335	.4835
19	.7253	.6097	.6447	.4572	.6447	.6097	.7253
20	.6097	.6859	.7253	.6859	.7253	.6859	.8059
21	.6097	.6097	.6447	.6097	.6447	.6859	.7253
22	.5335	.5335	.6097	.6097	.6097	.6097	.6097
23	.5335	.5335	.6097	.5335	.5335	.6097	.6097
24	.6097	.381		.9145	.5335	.5335	
Max	1.4506	.6859	57.9119	1.0669	.8865	1.5242	1.2955
Min	.4835	.381	.4029	.4572	.2418	.0305	.2418
Avg	.7652	.5604	3.9427	.7480	.6764	.7384	.7591

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154055 / 33 KV SUB STATION KHAROSA

Feeder No / Name : 204 / express feeder

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.2572	.0857	.2572	.0857	.1715	.3429
2	.3429	.2572	.0857	.2572	.0859	.1715	.3429
3	.3429	.2572	.0857	.2572	.0857	.1715	.3429
4	.3429	.2572	.0857	.2572	.0857	.1715	.3048
5	.3429	.2572	.0857	.2572	.0857	.1715	.3429
6	.3429	.2572	.0857	.2572	.0857	.1715	.3429
7	.3429	.2572	.0857	.2572	.0857	.1715	.3429
8	.3429	.2572	.0857	.2572	.1715	.0857	.3738
9	.3429	.1715	.0935	.3429	.1715	.0857	.2804
10	.3429		.0935	.3429	.1715	.0857	.3738
11	.2804	.1715	.0935	.0857		.0857	.3738
12	.2804	.0857	.0935	.0857	.1869	.0857	.3738
13	.2804	.0857	.0935	.1715	.1869	.1715	.3738
14	.2804	.0857	.0935	.1715	.1869	.1715	.3738
15		.0857	.0935	.2572	.1869	.1715	.1869
16		.0857	.0935	.2572	.1869	.1715	.1869
17	.0935	.0857	.0935	.2572	.1869	.1715	.2804
18	.0935	.0857	.0935	.2572	.0935	.1524	.0935
19	.0935	.0857	.0935	.0857	.0935	.1715	.0935
20	.0857	.0857	.0935	.0857	.0935	.1524	.0935
21	.0857	.0857	.0935	.0857	.0935	.1715	.0935
22	.0857	.0857	.0857	.0857	.1715	.1715	.0857
23	.2572		.0857	.1715	.1715	.2572	.1715
24	.3429	.0857		.0857	.0561	.2572	
Max	.3429	.2572	.0935	.3429	.1869	.2572	.3738
Min	.0857	.0857	.0857	.0857	.0561	.0857	.0857
Avg	.2586	.1559	.0901	.2036	.1308	.1592	.2683

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154068 / 33 KV SUB STATION YELLI

Feeder No / Name : 201 / 11 KV Yelli SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5569		.8925	1.0413	1.4704	.6701	
2	1.6434		.9288	1.1157	1.5569	.7073	
3	1.6434		1.8947	1.1157	1.5569	.7446	.8359
4	1.9029		.9845	1.2644	1.7299		
5	2.0759		1.0031	1.3388	2.0759		
6	2.3277		1.1901	1.4876	2.1624		
7	2.5949		1.709	1.562	2.4219		
8	2.7587			1.4876	2.4219		
9	2.4219		1.5248	1.562	2.2489		
10						1.8947	1.9339
11						2.8948	.181
12		.1457				2.2291	2.2314
13		.1486					2.5103
14		.4458				2.6749	2.4545
15							2.5289
16		.3715	.3719	.2619	.2978	2.5263	2.5289
17	.484	.4082	.4463	.3114	.3723	1.9319	2.4545
18		.5938	.5207		.4467	.4472	.3719
19			.7438	.692	1.0796	.9659	.6694
20		1.0402	1.0413	1.038	1.1168	1.0763	1.1157
21		1.0217	.9669	.9515	1.0424	1.0774	1.0413
22		.9278	.8182	.7785	.9307	1.0402	.8925
23		.743	.6694	.5882	.819	.9297	.7438
24		.7794	.8925	1.3839		.7423	.6694
Max	2.7587	1.0402	1.8947	1.562	2.4219	2.8948	2.5289
Min	.484	.1457	.3719	.2619	.2978	.4472	.181
Avg	1.9410	.6023	.9764	1.0577	1.3971	1.4095	1.4477



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154068 / 33 KV SUB STATION YELLI

Feeder No / Name : 202 / 11 KV Kinnithot SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2768	.2234	.2972	.3347	.2768	.2978	.668
2	.3437	.2606	.3344	.3719	.346	.335	.8359
3	.4152	.2978	.3719	.2975	.4152	.3723	.8907
4						.4467	.9659
5						.5584	1.0763
6						.9307	1.1134
7						1.1168	1.2619
8						1.1168	1.2619
9						.9297	1.0402
10	.781	.2969	.4463	.692	.7446		
11	.8182	.3711	.5207	.7266	.7446		
12	.8925	.4087	.5207	.7266	.7818		
13	.8935	.4082	.595	.7266	.7446		
14	.781	.3711	.595	.6401	.7446		
15	.6322	.3711	.595	.692	.7446		
16	.2234	.4082		.7785	.6701	.0929	.1488
17	.2606	.4087	.6694	.7785	.6329	.1485	.1859
18	.2978		.1488	.1557	.2606	.2227	.2231
19	.3723	.4087	.2975	.3114	.3723	.4087	.3719
20	.4467	.4458	.3719	.4498	.484	.3711	.3347
21	.4095	.4082	.3719	.3806	.4467	.3715	.3719
22	.3723	.3711	.3719	.3633	.3723	.3715	.3347
23	.335	.3711	.3347	.3633	.335	.334	.3719
24		.3347	.3719	.346		.5201	
Max	.8935	.4458	.6694	.7785	.7818	1.1168	1.2619
Min	.2234	.2234	.1488	.1557	.2606	.0929	.1488
Avg	.5030	.3627	.4244	.5075	.5363	.4970	.6739

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154068 / 33 KV SUB STATION YELLI

Feeder No / Name : 203 / 11 KV Tupadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.173	.1489	.1858	.2231	.173	.4467	.5567
2	.2422	.1861	.2231	.2603	.2422	.4467	.6495
3	.2768	.1861	.2601	.2231	.2768	.5584	.8359
4						.7446	.9288
5						.9307	1.0031
6						1.0424	1.0774
7						1.1168	1.1331
8						1.1541	1.1876
9						.7438	1.1145
10	.8368	.4412	.595	.7612	1.0796		
11	.8925	.5201	.7438	.8304	1.1168		
12	1.0041	.5196	9.0742	.8996	1.1541		
13	1.0785	.2229	.8925	.9688	1.1913		
14	1.0041	.8173	.9669	.6228	1.2285		
15	.9297	.8545	.9669	.8304	1.2285		
16		.7616		.9688	1.1913	.0743	.0744
17		.8907	.9669	.9342	1.1168	.0743	.0744
18	.1861	.1113	.1116	.4325	.1861	.0932	.0744
19	.2978	.3715	.1859	.1557	.2978	.0557	.2231
20	.2606	.334	.2231	.3806	.335	.1858	.2603
21	.2234	.334	.1859	.346	.2978	.3344	.2603
22	.1861	.2972	.2231	.2249	.2606	.2969	.2231
23	.1861	.2206	.2231	.2076	.2234	.2972	.2603
24		.1471	.1859	.2076		.483	.595
Max	1.0785	.8907	9.0742	.9688	1.2285	1.1541	1.1876
Min	.173	.1113	.1116	.1557	.173	.0557	.0744
Avg	.5185	.4092	.9538	.5265	.6823	.5044	.5851

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154069 / 33 / 11 KV MANGROOL

Feeder No / Name : 201 / 11 KV Limbala Feeder SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	21-MAR-17
HR	Load (MW)
19	.362
20	.362
21	.362
22	.362
23	.362
Max	.362
Min	.362
Avg	.362

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154069 / 33 / 11 KV MANGROOL

Feeder No / Name : 202 / 11 KV Mangrool SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0802		.5201	.8145	.5401	.5401	.823
2	1.0802		.5316	.823	.4624	.463	.823
3	1.2346		.5258	.8059	.6165	.463	
4	1.2346		.4382	.5316	.6165		
5	1.3889		.6068	.5316	.6165		
6	1.3889		.6935	.6135	.6936		
7	1.5432		.6859	.6135	.6936		
8	1.5432		.7716	.6935	.6936		
9			.7802	.7202	.7716		
10			.7802	.2401		.503	.5144
11			.7802			.6706	.8573
12			.4973			.8383	.8573
13			.5935			.503	.8573
14			.5868			.7545	.6859
15			.5087			.8383	
16		.3906	.4049			.8383	
17		.5468	.503		.4624	.8383	.6859
18		.3858	.4477	.2315	.4624		
19		.4744	.6135	.463	.4624		.3544
20		.5601	.7802	.463	.6165	.7011	.4525
21		.463	.8764	.3858	.463	.7087	.4525
22		.3858	.6268	.3858		.6268	.4525
23		.3201	.5373	.2529	.463	.5487	.362
24	.7716		.3953	.7164	.6173	.3086	.7316
Max	1.5432	.5601	.8764	.823	.7716	.8383	.8573
Min	.7716	.3201	.3953	.2315	.4624	.3086	.3544
Avg	1.2517	.4408	.6036	.5462	.5782	.6340	.6364

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154093 / 33 KV SUB STATION KARLA

Feeder No / Name : 201 / 11 KV Karla SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2292	.3201		.1966
2				.3056	.4801		.1943
3					.4915		.2267
4				.3056	.5735		
5				.4296	.5735		
6					.6554		
7				.5155	.6554		
8				.5517	.7373		
9							.7956
10							.7956
11						.7125	.0876
12			.4296				.8592
13		.1524				.7287	.843
14		.3353	.0917			.7373	.8276
15	.0762	.4161	.1534			.7373	.8449
16	.0305	.4915	.1718	.1524		.6882	.7759
17	.0305	.0762	.4296	.1524			
18	.0762	.1696	.0917	.1524			.0917
19				.1524		.2458	
20				.1829		.2429	.1718
21				.1524		.2458	
22				.1524		.2294	.189
23				.1524		.1943	
24				.1524			.1943
Max	.0762	.4915	.4296	.5517	.7373	.7373	.8592
Min	.0305	.0762	.0917	.1524	.3201	.1943	.0876
Avg	.0534	.2735	.2280	.2493	.5609	.4762	.4729

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154093 / 33 KV SUB STATION KARLA

Feeder No / Name : 202 / 11 KV Kumtha SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.1524		.1524
2				.1681	.3048		.1524
3				.2292	.381		.1524
4							.2267
5							.2439
6							.3048
7							.3277
8							.2949
9				.2598	.4001		
10				.3201	.4001		
11	.4801			.3201			
12	.5601		.1536	.3201			
13	.4801		.2295	.3521			
14	.4801		.3056	.3361			
15	.4001		.3056	.3521			
16	.3201		.3056	.4001			
17		.1638				.6554	.0228
18	.0762	.4096	.1724	.0762		.6554	.1681
19				.3048		.6226	.1718
20				.3048		.4915	.1718
21				.2286		.421	
22				.1524		.4588	.4828
23				.1524		.426	
24				.1524			.426
Max	.5601	.4096	.3056	.4001	.4001	.6554	.4828
Min	.0762	.1638	.1536	.0762	.1524	.421	.0228
Avg	.3995	.2867	.2454	.2606	.3277	.5330	.2356

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154093 / 33 KV SUB STATION KARLA

Feeder No / Name : 203 / 11 KV Sirsal SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0762		.1528	.1524		.2458
2		.1524		.1524	.3048		.2883
3		.2286		.2292	.3048		.3052
4		.2286		.3056	.381		.3391
5		.3048		.3056	.381		.407
6		.381		.4584	.4572		.6783
7		.4572		.5348	.4572		.763
8		.3048		.5155	.4572		.8139
9		.2286		.306	.381		
10		.1524		.1524	.1524		
15							.0306
16							.3514
17	.08	.4239	.3437	.3361		.1638	.0306
18	.16	.5243	.3093	.3521		.2035	.0687
19	.2401			.3201		.4409	
20	.2401			.3201		.407	.4296
21	.08			.3201		.373	
22				.3201		.3052	.1834
23				.2401		.2543	
24		.08		.2401			.2543
Max	.2401	.5243	.3437	.5348	.4572	.4409	.8139
Min	.08	.0762	.3093	.1524	.1524	.1638	.0306
Avg	.1600	.2725	.3265	.3090	.3429	.3068	.3459

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154099 / 33 / 11 Tapse - Chincholi

Feeder No / Name : 201 / 11 KV Chincholi (T) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9332			.1524	.2058
2	1.2803			.1829	.1638
3	1.3123			.1875	.1753
4	1.286				
5	1.3998				
6	1.5339				
7	1.5935				
8	1.7652				
10					.2134
11		.3658		.7316	.6554
12		.4268		.7621	.8535
13				.7621	1.1126
14				.7926	1.0669
15				.8535	1.0517
16				.9061	.9907
17				.9175	.9907
18			.1947		.0762
19			.2743	.4001	.1429
20			.2915	.4763	.1905
21			.3391		.1905
22			.2743	.381	.1286
23			.184	.2515	
24	.5944		.1715	.4001	
Max	1.7652	.4268	.3391	.9175	1.1126
Min	.5944	.3658	.1715	.1524	.0762
Avg	1.2998	.3963	.2471	.5438	.5130



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154099 / 33 / 11 Tapse - Chincholi

Feeder No / Name : 202 / 11 KV Utka SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2126	.1829		.6562	1.3748
2	.2012	.2058		.9488	1.4706
3	.1905	.2058		.9907	1.5935
4				1.0936	1.866
5				1.186	1.9685
6				1.3603	2.0243
7				1.3717	2.0309
8				1.186	
9					1.5699
10					.2134
11	2.0576				
16					.0914
17				.0953	.0762
18			.3125	.1905	.1143
19			.3437	.2858	.0953
20	.463			.4763	.1143
21	.4252		.4096	.381	.1429
22	.3772		.4024	.381	.1429
23	.3258		.3048	.2858	.0762
24	2.0576	.1772	1.4403	.3096	.6249
Max	2.0576	.2058	1.4403	1.3717	2.0309
Min	.1905	.1772	.3048	.0953	.0762
Avg	.7012	.1929	.5356	.6999	.8661

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154003 / 33/11 KV NILANGA

Feeder No / Name : 201 / 11 KV SHINDKHED GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.4973				.3467		
8	.1658						.5335
10							.4144
12	.4144	.2486					
16		.3315	.3391	.4915			
18				.6401			
20				.503			.4973
24	.2543		.1638	.1524	.2629	.2543	.2543
Max	.4973	.3315	.3391	.6401	.3467	.2543	.5335
Min	.1658	.2486	.1638	.1524	.2629	.2543	.2543
Avg	.3330	.2901	.2515	.4468	.3048	.2543	.4249

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154003 / 33/11 KV NILANGA

Feeder No / Name : 204 / 11 KV HADGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4				1.2803		
8	2.3205	1.3565	2.2043	2.3205		
14						2.1605
16					2.4387	1.9204
18			.2429			
20			.5801			.663
24	.3391	.4144	.4144	.4477	.2572	.5144
Max	2.3205	1.3565	2.2043	2.3205	2.4387	2.1605
Min	.3391	.4144	.2429	.4477	.2572	.5144
Avg	1.3298	.8855	.8604	1.3495	1.3480	1.3146

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154003 / 33/11 KV NILANGA

Feeder No / Name : 205 / 11 KV Express COMC  
WW/Hospital Feeder KV- 11 /  
OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	15-MAR-17
HR	Load (MW)
8	.0339
Max	.0339
Min	.0339
Avg	.0339

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154003 / 33/11 KV NILANGA

Feeder No / Name : 206 / 11 KV DHANORA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4					.8764	
8						2.5434
10						2.13
12	2.13	1.4918				
16		1.6385	1.8233	1.7604		
18				1.7604		
20				.8383		.6783
24	.5335		.5735	.5087	.5201	.4572
Max	2.13	1.6385	1.8233	1.7604	.8764	2.5434
Min	.5335	1.4918	.5735	.5087	.5201	.4572
Avg	1.3318	1.5652	1.1984	1.2170	.6983	1.4522

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154009 / 33/11 KV KASAR SHIRSHI

Feeder No / Name : 201 / 11 KV KASAR SHIRSHI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.6733		
2					.6516	.7392	
3					.5144		
4					.6783		.8002
5					.7802	.8059	.8935
6					.6783		.823
7						1.5432	
8							.9145
9							.9335
11	1.3077			.7316	1.0745		
12		.2515	.3144		1.5061		
13					1.5061		
14		.08	.423		1.3289		
15		.3467		.5373	1.3523		
16			.503				
17					1.3717	.1143	.0762
18			.5487	.924	1.2269	.1143	.1372
19			.4001			.2858	.3048
20							.3334
21						.3334	.381
22						.3144	
24		.301	.3334	.7316	.6335	.6602	.4268
Max	1.3077	.3467	.5487	.924	1.5061	1.5432	.9335
Min	1.3077	.08	.3144	.5373	.5144	.1143	.0762
Avg	1.3077	.2448	.4204	.7311	.9983	.5456	.5476

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154009 / 33/11 KV KASAR SHIRSHI

Feeder No / Name : 204 / 11 KV RAMLING MUDGAD SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.7087		
2					.6859	.5914	
3					.6516		
4					.7461		.8669
5	.9114				.8322	.8059	
6	.8817				.8139		.8002
7						1.5089	
8							.9526
9							.6478
10							.6478
11	1.5089			.7964	.9313		
12		.1715	.3429		1.0631		
13	1.7772				1.134		
14		.2058	.4572		1.2048		
15		.2934		.9313	1.2483		
16			.5716				
17					1.3375	.2286	.1524
18			.5716	.8131	.8413	.2515	.2286
19			.5487				.3277
20							.4287
21						.5144	.4763
22						.4572	
24		.3763	.4287	.3658	.7316	.679	.5335
Max	1.7772	.3763	.5716	.9313	1.3375	1.5089	.9526
Min	.8817	.1715	.3429	.3658	.6516	.2286	.1524
Avg	1.2698	.2618	.4868	.7267	.9236	.6296	.5511

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154009 / 33/11 KV KASAR SHIRSHI

Feeder No / Name : 205 / 11 KV HASORI AG FEEDER      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.2804		
2					.2743	.037	
3					.3086		
4					.3052		.0667
5	.4287				.3086	.0358	.0667
6	.5087				.3391		.0572
7						.0686	
8	.8916		.1524		.57		
9	.8916						
11							.2858
12		.2286					.4001
14		.1715					
15		.2667					
17					.0351	.4572	.381
18			.0572	.037	.0709		.3429
19			.0572			.0476	.0381
20						.0476	.0476
21						.0572	.0476
22						.0572	
24	.462			.9145	.0732	.0263	.0667
Max	.8916	.2667	.1524	.9145	.57	.4572	.4001
Min	.4287	.1715	.0572	.037	.0351	.0263	.0381
Avg	.6365	.2223	.0889	.4758	.2565	.0927	.1637



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154016 / 33/11 KV HALGARA

Feeder No / Name : 202 / 11 KV HALGARA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3429					
7	.8573	.7716			.8573		
8		.6859	.7716	.8573	.8573	.8573	.7716
13							.2572
14							.2572
15							.2572
16	.3429	.2572	.2572	.2572	.2572	.2572	.2572
18	.4287			.3429			
19	.6001						
24	.2572		.3429	.3429	.3429	.3429	.2572
Max	.8573	.7716	.7716	.8573	.8573	.8573	.7716
Min	.2572	.2572	.2572	.2572	.2572	.2572	.2572
Avg	.4972	.5144	.4572	.4501	.5787	.4858	.3429

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154016 / 33/11 KV HALGARA

Feeder No / Name : 203 / 11 KV SAWARI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2572					
7		.3429			.9431		
8		.5144	.6859	.7716	.8573	.7716	.6859
9		.6859					
13							.2572
14							.2572
15							.2572
16	.1905	.2572	.1715	.2572	.2572	.2572	.2572
18	.3429						
19	.6001						
24	.2572		.2572	.2572	.2572	.2572	.2572
Max	.6001	.6859	.6859	.7716	.9431	.7716	.6859
Min	.1905	.2572	.1715	.2572	.2572	.2572	.2572
Avg	.3477	.4115	.3715	.4287	.5787	.4287	.3287

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154016 / 33/11 KV HALGARA

Feeder No / Name : 204 / 11 KV SHIRSHI HANGARGA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2572					
7		.5144			.5144		
8		.5144	.5144	.5144	.5144	.4287	.5144
9		.4287					
13							.2572
14							.2572
15							.2572
16	.1715	.1715	.2572	.2572	.1715	.2572	.2572
18	.2572			.2572			
19	.4287						
24	.2572		.2572	.2572	.2572	.2572	.2572
Max	.4287	.5144	.5144	.5144	.5144	.4287	.5144
Min	.1715	.1715	.2572	.2572	.1715	.2572	.2572
Avg	.2787	.3772	.3429	.3215	.3644	.3144	.3001

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154016 / 33/11 KV HALGARA

Feeder No / Name : 205 / 11 KV SAWARI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0086					
8						1.1145	1.3717
16	1.3717	1.2003	.8573	1.0288	1.1145	.0086	
18	.0086			.0086			
19	.0086						
24	.0857		.0857	.0086	.0086	.3429	.4287
Max	1.3717	1.2003	.8573	1.0288	1.1145	1.1145	1.3717
Min	.0086	.0086	.0857	.0086	.0086	.0086	.4287
Avg	.3687	.6045	.4715	.3487	.5616	.4887	.9002

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154016 / 33/11 KV HALGARA

Feeder No / Name : 206 / 11 KV HALGARA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	1.8004				2.0576		
8			.6859	1.7147	2.0576		
9		.8573					
13							2.0576
14							2.0576
15							2.0576
16	.0086	.0857			.0857	2.0576	2.0576
17				.0086			
18	.0086			.0086			
19	.0086						
24	.0086		.0686	.8573	.8573	.0857	.0086
Max	1.8004	.8573	.6859	1.7147	2.0576	2.0576	2.0576
Min	.0086	.0857	.0686	.0086	.0857	.0857	.0086
Avg	.3670	.4715	.3773	.6473	1.2646	1.0717	1.6478

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154016 / 33/11 KV HALGARA

Feeder No / Name : 207 / 11 KV TAGARKHEDA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4287					
7		.5144			.6859		
8		.6859	.6001	.6859	.6859		
9		.6001					
13							1.0288
14							.9431
15							.9431
16	.0086	.0857		.0086	.0857	1.0288	.9431
18	.0086			.0086			
19	.0086						
24	.5144		.4287	.3429	.3429	.0857	.9431
Max	.5144	.6859	.6001	.6859	.6859	1.0288	1.0288
Min	.0086	.0857	.4287	.0086	.0857	.0857	.9431
Avg	.1351	.4630	.5144	.2615	.4501	.5573	.9602

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154016 / 33/11 KV HALGARA

Feeder No / Name : 209 / 11 KV SHIRSHI HANGARGA AG FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8						1.6289	1.7147
16	1.0288	2.4006	1.3717	1.3717	1.5432		
24						.4287	.5144
Max	1.0288	2.4006	1.3717	1.3717	1.5432	1.6289	1.7147
Min	1.0288	2.4006	1.3717	1.3717	1.5432	.4287	.5144
Avg	1.0288	2.4006	1.3717	1.3717	1.5432	1.0288	1.1146

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154027 / 33/11 KV PANCHINCHOLI

Feeder No / Name : 201 / 11 KV PANCHINCHOLI SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	17-MAR-17
HR	Load (MW)
21	.9503
24	.9503
Max	.9503
Min	.9503
Avg	.9503



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154027 / 33/11 KV PANCHINCHOLI

Feeder No / Name : 202 / 11 KV TUPADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3				.0347	.017		
8							2.0508
11	1.7974		1.2717				
12	1.7833	1.0004		1.8004			
13	1.8054		1.5604	1.656			
15				1.9281			
16			1.7337	1.9105			
17			1.7318				
20							.0526
21			.0171				
22							.0175
23			.0173				
24		.0177	.0177		.0177	.0177	1.9161
Max	1.8054	1.0004	1.7337	1.9281	.0177	.0177	2.0508
Min	1.7833	.0177	.0171	.0347	.017	.0177	.0175
Avg	1.7954	.5091	.9071	1.4659	.0174	.0177	1.0093

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154027 / 33/11 KV PANCHINCHOLI

Feeder No / Name : 204 / 11 KV GOUR FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3				1.0631			
4		.6859					
6				1.286			
7		.8842					
8	1.7177	1.0923		1.6126	1.7177		
9	1.6263			1.7177			
10							1.3321
14							1.6126
16				.2629			
17			.2427			1.6297	
21			.4207				
22	.4115						
23	.4681		.3988				
24	.5487	.5083	1.1163		.4382	1.7002	
Max	1.7177	1.0923	1.1163	1.7177	1.7177	1.7002	1.6126
Min	.4115	.5083	.2427	.2629	.4382	1.6297	1.3321
Avg	.9545	.7927	.5446	1.1885	1.0780	1.6650	1.4724

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154027 / 33/11 KV PANCHINCHOLI

Feeder No / Name : 205 / 11KV SHARADA CON.EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS  
 FDR Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3				.1397			
4		.0543					
7		.0104					
8	.0102			.0106	.017		
10							.1797
11	.023						
12		.1379	.1931	.1683			
13	.0159		.206	.0086			
14				.0086			
15				.0183			
16			.1754	.0085			
17			.163			.1364	
21			.0638				
22	.0248						
23	.0412		.1612				
24	.2392	.0173	.0087		.2289	.0884	.0104
Max	.2392	.1379	.206	.1683	.2289	.1364	.1797
Min	.0102	.0104	.0087	.0085	.017	.0884	.0104
Avg	.0591	.0550	.1387	.0518	.1230	.1124	.0951

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154029 / 33/11 KV MADANSURI

Feeder No / Name : 202 / 11 KV MADANSURI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.7061			.9462		.9967	1.0655
16		.4984	.4134		.3437	.2931	
24	.3448	.3437	.4124	.3966	.3653	.4468	.3445
Max	.7061	.4984	.4134	.9462	.3653	.9967	1.0655
Min	.3448	.3437	.4124	.3966	.3437	.2931	.3445
Avg	.5255	.4211	.4129	.6714	.3545	.5789	.705

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154029 / 33/11 KV MADANSURI

Feeder No / Name : 203 / 11 KV RAMTIRTH SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.3304			.2643		.8817	.5947
16		.4572	.5267		.7837	.0496	
24	.2147	.1633	.2123	.1817	.1548	.3755	.2977
Max	.3304	.4572	.5267	.2643	.7837	.8817	.5947
Min	.2147	.1633	.2123	.1817	.1548	.0496	.2977
Avg	.2726	.3103	.3695	.223	.4693	.4356	.4462

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154035 / 33/11 KV KASAR BALKUNDA

Feeder No / Name : 201 / 11 KV KASAR BALKUNDA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8					.8421	.6554
16				.7373	.9503	
24	.763	.8192	.6478		.7287	.8848
Max	.763	.8192	.6478	.7373	.9503	.8848
Min	.763	.8192	.6478	.7373	.7287	.6554
Avg	.763	.8192	.6478	.7373	.8404	.7701

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154035 / 33/11 KV KASAR BALKUNDA

Feeder No / Name : 202 / 11 KV TAMBALA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8					1.0629
16			.9088	1.1374	
24	.3782	.9845		.3033	
Max	.3782	.9845	.9088	1.1374	1.0629
Min	.3782	.9845	.9088	.3033	1.0629
Avg	.3782	.9845	.9088	.7204	1.0629

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154035 / 33/11 KV KASAR BALKUNDA

Feeder No / Name : 203 / 11 KV TAKLI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8				1.1323	1.0514
16			.7279	.8088	
24	.7279	.628	1.0514	.8896	
Max	.7279	.628	1.0514	1.1323	1.0514
Min	.7279	.628	.7279	.8088	1.0514
Avg	.7279	.628	.8897	.9436	1.0514



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154046 / 33/11 KV ZARI

Feeder No / Name : 201 / 11 KV LAMBOTA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6401			1.1641	1.1431	1.0288
2		.5487			1.0745		.9431
3	1.3336				1.0288	1.1431	.9431
4	1.3336	.6401	.7621		.7716	1.2384	.9431
5	1.5242	.5487			.8573	1.5242	1.1145
6	.8402	.6401			.8573	2.0005	1.7147
7	.9335	.8316			.6859	2.3339	2.2291
8	.9335	.724				2.2405	2.4006
9	.6135	.7468	.9431	.7087	.6535	1.9982	2.2291
10	.543						
12	.7316	.7468	.5653	.724	.8059		
13	1.4327	1.307	1.2235	1.4575	1.5242		
14	1.5775	1.4937	1.1883	1.6108			
15	1.5775	1.6804	1.3474	1.7528	1.8671		
16	1.1517	1.7737	1.5226	1.8861	2.1472		
17			1.4316	1.8861			
18	.9145		1.5175	1.9719			
19	1.0059		1.2186	1.8204		1.6872	
20			.9393	1.6651		1.689	1.2003
21	.5487		.944	1.4327		1.5043	1.2003
22	.7316		.945	1.4327		1.3163	1.0288
23	.7316		.9431	1.3432		1.2235	1.2003
24	1.3336	.6401			1.267	1.1294	1.0288
Max	1.5775	1.7737	1.5226	1.9719	2.1472	2.3339	2.4006
Min	.543	.5487	.5653	.7087	.6535	1.1294	.9431
Avg	1.0417	.9258	1.1065	1.5148	1.1311	1.5837	1.3718

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154046 / 33/11 KV ZARI

Feeder No / Name : 204 / 11 KV KATE JAWALGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431				.5373	.2858	.3429
2	1.1431				.6268	.2858	.3429
3	1.1431				.7973		.4287
4	1.3336				.8859		
5	1.5242				1.2269		
6	1.8671				1.7147		
7	1.9605	.7316			2.2377		
8	2.1472	1.7909			2.1548		
9	1.5604	1.8671		1.4175	1.1393		
10		1.7737	.9431			1.1305	
11			1.3519			2.005	
12						2.1721	1.8861
13							2.0576
14						1.9982	2.1434
15						2.1672	2.2291
16		.1494		.1753	.1867	2.2402	2.2291
17			.1888	.1753		2.1672	2.2291
18			.2835	.2629		.189	.1715
19	.5487		.472	.443		.3776	.3429
20			.5653	.5316		.5658	.4287
21			.4725	.4477		.4715	.5144
22			.378	.3582		.3772	.5144
23				.2686		.3772	.4287
24					.3582		.3429
Max	2.1472	1.8671	1.3519	1.4175	2.2377	2.2402	2.2291
Min	.5487	.1494	.1888	.1753	.1867	.189	.1715
Avg	1.4371	1.2625	.5819	.4533	1.0787	1.1207	1.0395

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154046 / 33/11 KV ZARI

Feeder No / Name : 205 / 11KV KELGAON SPP

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5242				.724	.9526	.9431
2					.8102	.9526	1.0374
3					.985		
4					1.0745		
5	1.9052				1.3289		
6	2.191				1.5775		
7	2.4272				2.3739		
9	2.2119	1.9605	1.7684	1.9281	2.2539		
10		1.9605				.8479	.3429
11		1.8671				1.8526	2.0576
12						2.0165	2.0576
13						1.8338	2.0576
14						1.8463	1.8861
15						2.0073	1.8861
16	.3506	.3734	.1894	.3506	.4382	2.0073	2.0576
17			.5647	.3506		2.0142	2.0576
18			.7537	.6201		.5664	.2572
19			1.5089	1.2403		1.2248	.6859
20			1.4146	1.2403		1.5089	1.1145
21			1.0353	.9745		1.4146	.8573
22			.756	.8859		1.3203	
23				.8059		1.2272	
24			.756		.543	.9526	
Max	2.4272	1.9605	1.7684	1.9281	2.3739	2.0165	2.0576
Min	.3506	.3734	.1894	.3506	.4382	.5664	.2572
Avg	1.7684	1.5404	.9719	.9329	1.2109	1.4439	1.3785

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154056 / 33/11 KV AURAD

Feeder No / Name : 201 / 11 KV AURAD

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2						.0943	
8	.6859			.4801	.6001		
12						.6859	
13						.6706	
14							.8402
16	.0943	.0905		.0905	.0943	.5935	.6602
18						.0934	
19			.0924			.0905	
24	.6859		.1715	.0905	.181	.0943	.0943
Max	.6859	.0905	.1715	.4801	.6001	.6859	.8402
Min	.0943	.0905	.0924	.0905	.0943	.0905	.0943
Avg	.4887	.0905	.1320	.2204	.2918	.3318	.5316

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154056 / 33/11 KV AURAD

Feeder No / Name : 202 / 11 KV SHELGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2					.823	
4					1.3375	
6					1.6289	
8					1.6057	1.8138
12		.9831				
16	1.0288	1.1469		1.5432		.0514
18					.0554	
19		.0362			.0739	
24	.0943		.0754			.3772
Max	1.0288	1.1469	.0754	1.5432	1.6289	1.8138
Min	.0943	.0362	.0754	1.5432	.0554	.0514
Avg	.5616	.7221	.0754	1.5432	.9207	.7475

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154056 / 33/11 KV AURAD

Feeder No / Name : 203 / 11 KV SHELGI GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2						.5281	
4						.6722	
6						.9431	
8	.9955			.8402	.905	.8962	.7762
12			.2614				
14							.5228
16	.3018	.2715	.2241	.2715	.3772		.3772
18						.3174	
19			.5601			.7095	
24	.415		.4525	.415	.362	.3961	.4338
Max	.9955	.2715	.5601	.8402	.905	.9431	.7762
Min	.3018	.2715	.2241	.2715	.362	.3174	.3772
Avg	.5708	.2715	.3745	.5089	.5481	.6375	.5275

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154056 / 33/11 KV AURAD

Feeder No / Name : 204 / 11 KV AURAD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2						.5544	
4						.6468	
6						.823	
8	.7392		.8145	.8145	.8145	.8316	.8059
12			.5487				
14							.5487
16	.6468	.4525		.4525	.6468		.6468
18						.5487	
19			.7392			.7316	
24	.4668		.4525	.4668	.4525	.462	.4668
Max	.7392	.4525	.8145	.8145	.8145	.8316	.8059
Min	.4668	.4525	.4525	.4525	.4525	.462	.4668
Avg	.6176	.4525	.6387	.5779	.6379	.6569	.6171

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154056 / 33/11 KV AURAD

Feeder No / Name : 205 / 11KV GRAM PANCHYAT AURAD

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2						.5601	
4						.6335	
6						1.0164	
8	.905		.905	.905	.905	.8145	.724
14							.4572
16	.4572	.362	.3696	.362	.3658	.2743	.362
18						.462	
19			.6535			.5487	
24	.2829		.4525	.2801	.362	.2743	.2829
Max	.905	.362	.905	.905	.905	1.0164	.724
Min	.2829	.362	.3696	.2801	.362	.2743	.2829
Avg	.5484	.362	.5952	.5157	.5443	.5730	.4565



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154063 / 33/11 KV MASALGA

Feeder No / Name : 201 / 11 KV MUGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3						.1621	.1638
4	.6859						
6					.6001		
7		.1638	.5087	.6554			
8	1.0288			.8192	.9431		
9		.1638	.6783	.8573			
10						.6554	
11							1.0174
16				.1715			
17			.1638		.1524	.9831	.8669
20						.2429	
23	.1638						
24	.3429	.1638	.3353		.1621		.1638
Max	1.0288	.1638	.6783	.8573	.9431	.9831	1.0174
Min	.1638	.1638	.1638	.1715	.1524	.1621	.1638
Avg	.5554	.1638	.4215	.6259	.4644	.5109	.5530

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154063 / 33/11 KV MASALGA

Feeder No / Name : 203 / 11 KV MASALGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3						.1905	.1905
4	.7716						
6					.7716		
7		.9526	.7011				
8	1.0288			1.1431	.9431		
9		.9526	.8764	1.0288			
10						.5716	
14						1.1431	
16			.1905	.1715			
17					.1905	1.1431	1.0631
20						.1905	
21		.2486					
23	.1905						
24	.3429	.4763		.5716	.1905		.2858
Max	1.0288	.9526	.8764	1.1431	.9431	1.1431	1.0631
Min	.1905	.2486	.1905	.1715	.1905	.1905	.1905
Avg	.5835	.6575	.5893	.7288	.5239	.6478	.5131

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154063 / 33/11 KV MASALGA

Feeder No / Name : 204 / 11 KV WATER WORKS  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	18-MAR-17
HR	Load (MW)
16	.1524
Max	.1524
Min	.1524
Avg	.1524

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154072 / 33/11 KV BORSURI

Feeder No / Name : 201 / 11 KV SONKHED

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.078	.0954	.8573	.7716	.6859	
2	.8573	.078	.104	.9431	.7716	.6859	
3	.8573	.0867		.9431	.9431	.8573	
4		.104				.8573	
5						1.0288	
6						1.3717	
7						1.5432	1.7337
8						1.7147	1.8204
9						1.7147	1.8204
10	1.1145	.0693	.0693	.6859	3.5837		
11	.9431	.104		.6935	.7716		
12		.104	.6859	.7802	.8573		
13		.104	.7716	.7802	.6859		
14		.104	.8573	.7802	.8573		
15		.1214	.8573	.7802	.9431		
16		.1214	.7716	.8669	1.1145	.1734	
17		.13		.7802	1.2003	.1734	
18		.0433	.3429	.7802	.3429		.0433
19		.078	.7716	.8669	.6859		.0693
20		.0954	.9431	.8669	.9431		.0867
21		.0954	.9431	.7802	.9431		.0867
22		.0867	.8573		.8573		.0867
23		.0867	.8573		.8573		.0693
24	.8573	.078	.0954	.8573	.7716	.6859	
Max	1.1145	.13	.9431	.9431	3.5837	1.7147	1.8204
Min	.8573	.0433	.0693	.6859	.3429	.1734	.0433
Avg	.9145	.0931	.6015	.8151	.9945	.9577	.6463

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154078 / 33/11 KV NITUR

Feeder No / Name : 201 / 11 KV NITUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	2.2481			1.2967		.8962	.8112
6		.5487			1.8778		
7					3.3234		
8	3.4355	.8686		2.8235			
9					2.95		
16			2.8006	.4024			
17		.4191					
18	.381				.5601		
20					1.1694		1.386
21						1.1317	
22	.6478			.8192	.9054		
24	1.0479	.3429		.9145	1.0688	.7468	
Max	3.4355	.8686	2.8006	2.8235	3.3234	1.1317	1.386
Min	.381	.3429	2.8006	.4024	.5601	.7468	.8112
Avg	1.5521	.5448	2.8006	1.2513	1.6936	.9249	1.0986

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154078 / 33/11 KV NITUR

Feeder No / Name : 202 / 11 KV SHEND FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.724			.6325		.8962	.9464
8						1.8107	
9							1.8671
11	1.2955			.8131			
12				1.3306			
15	1.2323						
16			.4481	1.4083	1.4937		
17		1.2955					
18					.4108		
20					.9808		1.1088
21						.9054	
22	.4435			.724	.7167		
24	.5335	.3292		.5906	.4858	.5601	
Max	1.2955	1.2955	.4481	1.4083	1.4937	1.8107	1.8671
Min	.4435	.3292	.4481	.5906	.4108	.5601	.9464
Avg	.8458	.8124	.4481	.9165	.8176	1.0431	1.3074

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154078 / 33/11 KV NITUR

Feeder No / Name : 203 / 11 KV BASPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.5335			.5376		1.1949	1.2505
8	.9709					2.1502	
9							2.0911
11	1.6766						
12				1.7741			
15	1.587						
16			1.7551	1.9022	2.0911		
17		1.6004					
18	.4435				.2241		
20					.7545		.8871
21						.6036	
22	.3696			.5525	.4527		
24	.381	.2469		.362	.2915	.6348	
Max	1.6766	1.6004	1.7551	1.9022	2.0911	2.1502	2.0911
Min	.3696	.2469	1.7551	.362	.2241	.6036	.8871
Avg	.8517	.9237	1.7551	1.0257	.7628	1.1459	1.4096

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154104 / 33/11 KV NANAND

Feeder No / Name : 201 / 11 KV NANAND

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3612	.3163	.4334	.3353	.3437	.8573	.7621
2	.3658	.3163	.443	.3658	.3749	.7907	.7621
3	.4572	.3795	.5087	.4268	.463	.9116	.8535
4	.5487	.4744	.6478	.4877	.6173	.9031	.9145
5	.5792	.5312	.763	.6097	.7621	1.3032	1.3413
6	.6401	.6249	.7811	.7621	.945	1.3213	1.4937
7	.6097	.6249	.8436	.7926	.7526	1.5059	1.6766
8	.4877		.7499	.7621	.535	1.6918	1.6766
9	.506			.7011	.4687	1.7665	1.5242
10	1.2498	1.0136	.743	.9145	1.1279		
11	1.8747	1.1288	1.1248	1.3599	1.5348		
12	1.9204		1.2193	1.4373			
13	1.9204	1.2811	1.4632	1.4327	1.3717		.1875
14	1.406	1.2963	1.4632	1.1888	1.6575		.1875
15	1.4373	1.0494	1.4632	1.4266	1.7086	.1524	.1875
16		1.4464	1.3717	1.6613	1.7086	.1829	.1875
17	.1562	1.4464	1.2193	1.6766	1.3321	.2134	.25
18		.2743	.3048	.2812	.2225	.2439	.3437
19	.6562	.6443	.5792	.5624	.7202	.7011	.5312
20	.4999	.7621	.6097	.6874	.8048	.6706	.6562
21	.4374	.5601	.4572	.5937	.5975	.4877	.5312
22	.3437	.4572	.3963	.4374	.5716	.4268	.4687
23	.2812	.381	.3353	.3437	.4572	.3353	.3437
24	.3353	.2812	.3544	.3048	.3125	.7716	.6401
Max	1.9204	1.4464	1.4632	1.6766	1.7086	1.7665	1.6766
Min	.1562	.2743	.3048	.2812	.2225	.1524	.1875
Avg	.7761	.7281	.7946	.8146	.8430	.8020	.7390



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154104 / 33/11 KV NANAND

Feeder No / Name : 202 / 11 KV JEWRI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4515	.2846	.5144	.4268	.3125	.2622	.2439
2	.4877	.3163	.5853	.4572	.3906	.3391	.2439
3	.5792	.3163		.5792	.463	.3521	.3048
4	.7621	.3795		.7621	.5247		.4572
5	.9145	.4687		.9145	.6097	.7526	.6401
6	1.0059	.6249		.9145	.7011	.8916	.884
7	1.0669	.7727		.9145	.8429	.9145	.9145
8	1.1279			.9145	.8916	.7526	.9145
9	1.1069			.945	.8124		.7316
10	.4062	.176		.945	.3292	.4877	.6249
11	.25	.1524		.1265	.2286	.6706	.6249
12	.1829	.1355	.1829	.125		.7011	.6874
13	.1219	.1235	.1829	.1219	.108	.7011	.7499
14	.125	.1543	.1524	.1189	.1107	.7011	.7186
15	.125	.125		.1189	.128	.7011	.6874
16		.1614	.1829	.1219	.1406	.7011	.7499
17	.2812	.1932	.2286	.1829	.1467	.7011	.7499
18	.3125	.2656	.2591	.2187	.2241	.1829	
19	.5937	.5304	.4877	.5937	.6173	.5487	.4687
20	.3749	.6478	.5487	.5937	.7023	.6097	.5937
21	.2812	.4066	.381	.4687	.4715	.4268	.4687
22	.2187	.3696	.3048	.3749	.4001	.3048	.3125
23	.1562	.3429	.2286	.1875	.2858	.2286	.2187
24	.3963	.25	.4334	.3353	.25	.2427	.1981
Max	1.1279	.7727	.5853	.945	.8916	.9145	.9145
Min	.1219	.1235	.1524	.1189	.108	.1829	.1981
Avg	.4925	.3271	.3338	.4776	.4214	.5534	.5734

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154104 / 33/11 KV NANAND

Feeder No / Name : 203 / 11 KV MALEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4515	.1581	.5316	.4572	.4062	.2812	.3048
2	.5182	.2214	.6135	.4877	.4687	.3277	.3048
3	.6097	.253	.5801	.6097	.463	.381	.381
4	.9145	.3163	.503	.7621	.5556	.4588	.6097
5	1.0669	.3749	.5868	1.0669	.6097	.7133	.7316
6	1.1888	.4374	.5864	1.0364	.7316		
7	1.2193	.6173	.6642	1.0364	1.1138		
8	1.3717		.7716	.9145	.9511		
9	1.4232			1.0364	.9374		
10	.3437	.1486	.3227	.3353	.2675	.7621	.9374
11	.1875	.1505	.2187	.1898	.1806	.9145	.9686
12	.1524	.1486	.1829	.125		1.0669	1.0623
13	.1219	.1562	.1219	.1219	.1505	1.0364	1.0311
14	.125	.1875	.1219	.1189	.1505	.9755	1.0311
15	.1562	.1562	.1219	.1189	.125	.9755	1.0311
16		.1486	.1524	.1524	.1235	.9755	1.0936
17	.25	.2107	.1524	.1524	.1505	1.0669	1.0623
18		.2622	.2439	.25	.25	.2134	.25
19	.2187	.5087	.4572	.6249	.6516	.5792	.6249
20	.1562	.6097	.5182	.6562	.7842	.6401	.6874
21	.1562	.3696	.4572	.5312	.679	.4877	.5312
22	.125	.3658	.3353	.3749	.4572	.3353	.3749
23	.125	.3048	.2134	.2187	.3429	.2743	.25
24	.3963	.1562	.4854	.3048	.2812	.2743	.2743
Max	1.4232	.6173	.7716	1.0669	1.1138	1.0669	1.0936
Min	.1219	.1486	.1219	.1189	.1235	.2134	.25
Avg	.5126	.2847	.3888	.4868	.4709	.6370	.6771

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154105 / 33/11 KV MUDGAD EKOJI

Feeder No / Name : 201 / 11 KV SARWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.1905	.2096	.2858	.1905	.3125	
2	.3429	.2286	.2096	.3429	.1905	.3239	.2743
3	.381	.2667	.2096	.381	.2096	.3563	.3906
4	.5335	.362	.2096	.4763	.2667	.4024	.4481
5	.5716	.4382	.2096	.6668	.3429	.503	.5735
6	.6097	.6097	.4001	.724	.5335	.503	.6706
7	.6478	.724	.5906	.7621	.7049	.5868	.8322
8	.5716	.6097	.5525	.724	.6097	.6371	.8745
9		.4572	.4572	.2286	.6097	.6249	.7209
10		.2347	.2683	.2343	.3005	.4001	.2477
11	1.1401	.2229	.3185	.3048	.3605	.1905	.1143
12	1.1065	.2858	.2683	.3749	.5365	.1334	
13	1.153	.2347	.2458	.3795	.3963	.1334	.0953
14	1.1065	.2683	.2294	.3953	.4694	.1143	.0953
15	.9221	.4191	.2458	.4481	.4428	.1524	.0953
16		.431	.2294	.4858	.427	.1143	.1143
17		.3932	.2458	.4372	.4527	.1334	.1334
18		.1715	.3429	.1524	.2286	.1334	.1524
19		.3429	.362	.2858		.2858	.2858
20	.362	.4572	.381	.4382		.5144	.4954
21		.381	.3429	.3048		.4572	.362
22		.3048	.2858	.2667		.381	.2286
23	.2667	.1905	.2286	.2286	.3048	.3429	.1905
24	.2096	.1905	.1905	.2096	.1905	.2641	.1524
Max	1.153	.724	.5906	.7621	.7049	.6371	.8745
Min	.2096	.1715	.1905	.1524	.1905	.1143	.0953
Avg	.6382	.3506	.3014	.3974	.3884	.3334	.3431

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154105 / 33/11 KV MUDGAD EKOJI

Feeder No / Name : 202 / 11 KV MUDGAD EKOJI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.2915	.2743
2						.3563	.3395
3						.3563	.4374
4						.426	.4801
5						.4534	.4999
6						.503	.5535
7						.6203	.5921
8						.6706	.6964
9						.5937	.6554
10	.3353	.218	.1823	.2073	.2134		
11	.7773	.1886	.2458	.2401	.2812		
12	.6019	.218	.2294	.2743	.4694		
13	.8718	.2515	.3277	.2606	.57		
14	.8192	.2515	.3441	.2782	.57		
15	.7373	.2458	.3277	.3666	.503		
16		.2622	.3277	.4001	.6036		
17		.2294	.3113	.3525	.5533		
24						.2054	.1524
Max	.8718	.2622	.3441	.4001	.6036	.6706	.6964
Min	.3353	.1886	.1823	.2073	.2134	.2054	.1524
Avg	.6905	.2331	.287	.2975	.4705	.4477	.4681

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154105 / 33/11 KV MUDGAD EKOJI

Feeder No / Name : 203 / 11 KV KOKALGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3353	.2439	.2134	.3637	.1905	
2	.3125	.3395	.2949	.2812	.4481	.1905	.381
3	.4588	.3437	.3277	.3201	.5601	.381	.5335
4	.5868	.4062	.3932	.5335	.6154	.4191	.5716
5	.7545	.4374	.4424	.5868	.7293	.5525	.6668
6	1.1022	.5243	.4973	.763	.7969	.7621	.7621
7	1.3226	.6539	.5533	.9602	.9015	.9145	.9335
8	1.4083	.7122	.5596	.7716	.9536	.6478	.7811
9	1.2308	.6203		.7461	.6344	.4763	.5525
10	.3429	.2667	.1715	.4572	.3239	.2286	.4915
11	.3048	.1524	.1334	.3048	.1905	.9374	.7537
12	.1905	.1334	.1334	.1905	.1524	.5601	.852
13	.1524	.1143	.1334	.1524	.0953	.6401	.8192
14	.0762	.1143	.1334	.1524	.0953	.7701	.8122
15	.0762	.1143		.1524	.1524	.7625	.8356
16		.1143	.1147	.1524	.1524	.8048	.7865
17		.1143	.1334	.1715	.1715	.8048	.7537
18		.1524	.381	.381	.1715	.4763	.1905
19		.362	.4382	.4954		.381	.4382
20	.5335	.5144	.4572	.6097		.5906	.5906
21		.4382	.4191	.4191		.5335	.4382
22		.3239	.381	.3048		.4572	.3239
23	.2667	.2477	.3429	.2477	.3048	.381	.2667
24	.1524	.2787	.1715	.1829	.1875	.1905	.2667
Max	1.4083	.7122	.5596	.9602	.9536	.9374	.9335
Min	.0762	.1143	.1147	.1524	.0953	.1905	.1905
Avg	.5454	.3256	.3117	.3979	.4000	.5439	.6001

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154107 / 33/11 KV HARIJAWALGA

Feeder No / Name : 201 / 11 KV HARIJAWALGA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143		.4458	.0434		.3334	.5716
2	.1372			.0747			.6668
3	.1219						.9145
4	.1543	.2858				.4954	1.0098
5	.1677	.3048				.6188	1.0288
6	.192	.381	.1829			.5906	1.0479
7	.1905		.2143			.6935	1.5242
8	.1585		.1698		.362	.7514	1.5813
9	.1067		.1532			.6859	1.105
10	.6001		.2241			.0914	
11		.3429	.5716	.7621			
12		.4034	.7621	.9907			
13				1.0669			
14		.5144	.8383	1.105			
15		.5268	.9145	1.1431			
16		.4163	.9717	1.1431	.884		
17		.4001	.8192	1.1622		.0206	
18		.1143	.064	.1334		.0305	
19	.3048	.1372	.0838	.362		.0453	
20	.381	.1677	.0876			.0838	.4382
21	.2667	.16	.0446	.2858		.0838	.381
22		.144	.0457		.1543	.0648	.381
23	.2286	.1225	.0453		.1219	.0421	.2286
24	.1157	.1219	.1143	.0457		.2858	.4954
Max	.6001	.5268	.9717	1.1622	.884	.7514	1.5813
Min	.1067	.1143	.0446	.0434	.1219	.0206	.2286
Avg	.216	.2839	.3554	.6399	.3806	.3073	.8124

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154107 / 33/11 KV HARIJAWALGA

Feeder No / Name : 202 / 11 KV BHOOTMUGLI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.1905	.2667	.3048	.2286	.4525	.2439
2	.2667	.2286	.2667	.3429	.2286		.3201
3	.3018	.2286		.381	.2667	.5144	.3353
4	.2743	.2667		.381	.2667	.5487	.4111
5	.3086	.3048		.4382	.3239	.5735	.4111
6	.3429	.362	.381	.4763	.4191	.5857	.4161
7	.3772	.4572	.3772	.5144	.4572	.7122	.6952
8	.3018	.2858	.3117	.4572	.381	.7545	.8697
9	.2058	.3048	.2829	.3048	.2858	.7449	.7907
10	.4801	.2743	.381			.1886	.2858
11	.8535	.3772	.4694	.5716			.1524
12	.4287	.4527	.6081	.4668			.1143
13	.6249	.4359	.3734	.5068		.0953	
14	.663	.426	.4012	.5668		.1334	.0953
15	.6802	.4424	.4458	.5182		.1143	.1143
16		.4801	.4572	.6173	.6001	.1143	.0953
17		.5658	.4967	.5792		.1334	.1143
18	.1715	.1715	.3429	.1524		.1334	.0953
19	.2858	.2858	.381			.3429	.3048
20	.381	.3429	.4572			.381	.4191
21	.3048	.3429	.3239			.362	.381
22	.2286	.3048	.2858		.2743	.3048	.3429
23	.2096	.2667	.2667		.2572	.2667	.2667
24	.2743	.2743	.2667	.2477	.1905	.4287	.0953
Max	.8535	.5658	.6081	.6173	.6001	.7545	.8697
Min	.1715	.1715	.2667	.1524	.1905	.0953	.0953
Avg	.3730	.3363	.3735	.4349	.3215	.3755	.3204

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154107 / 33/11 KV HARIJAWALGA

Feeder No / Name : 203 / 11 KV USTURI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6878	.381	.4458	.4481	.4801
2	.7888	.381	.5144	.6722	.3734
3	.9431	.4191		.7468	.5468
4	1.1145	.4191		1.0288	.5487
5	1.2071	.4382		1.153	.6859
6	1.1431	.4763	.823	1.2136	.6535
7	1.3765	.5144	.8573	1.1822	1.0526
8	1.3413	.4115	.8916	1.1736	1.0669
9	1.3053	.4801	.9012	1.1736	
10	.2058		.2058	.2591	
11	.2096	.1886	.4191	.2858	
12	.1905	.1715	.381	.2286	
13			.2858	.2667	
14	.1715	.1886	.2096		
15	.1715	.1867	.2096	.2286	
16	.1905	.1715	.2096	.1905	
17		.2058	.2286	.2477	
18		.2425	.4954	.2858	
19	.4191	.381	.5906	.5335	
20	.6097	.4115	.5716	.4954	
21	.4954	.415	.4954	.5335	
22	.4191	.381	.4382		
23	.4001	.3429	.3429		
24	.5975	.1886	.4763	.2477	.1524
Max	1.3765	.5144	.9012	1.2136	1.0669
Min	.1715	.1715	.2058	.1905	.1524
Avg	.6661	.3362	.4758	.5998	.6178



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154108 / 33/11 KV AMBULAGA

Feeder No / Name : 201 / 11KV AMBULGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6036					
2		.6036					
3		.6371					
4	1.1469	.6706					
5	1.1797	.6706			1.6289		
9	2.0553	1.56		1.3748		1.3592	1.5249
10	1.9113	1.8442	1.3592	2.146	2.2466	2.3137	3.0498
11	1.8442	1.4575		1.1469	1.2929	2.1795	
12	1.9113	1.2616	1.1012	1.1797	1.6095	1.9784	1.6766
13		1.4089		1.3108			1.6876
14	1.8244	1.3108	.9922	1.2003	2.2131		1.7004
15	.8916	1.2597		1.3108			1.8724
16		1.2483	1.8442	1.3413	2.4813		1.989
17	1.286	1.4815	1.8107	1.3927		2.4078	1.587
18	1.166	1.5203	2.146			2.2348	
19	.2743		.3041	.6923	.2606		.8573
20							.9156
21	.2557	.2675		.6882			.4967
22	.5304	1.2597	1.073	1.4403		1.9559	
23	.6036	1.3748		1.4548	1.1233	1.8233	
24	1.142	.6036		1.0936	1.5927	1.643	1.7238
Max	2.0553	1.8442	2.146	2.146	2.4813	2.4078	3.0498
Min	.2557	.2675	.3041	.6882	.2606	1.3592	.4967
Avg	1.2015	1.1076	1.3288	1.2695	1.6054	1.9884	1.5901

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154115 / 33/11 KV ASHOK NAGAR NILANGA

Feeder No / Name : 201 / NEW BANK COLONY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		1.0608				1.1949	
8	1.0867		1.2445	.9145	1.0517		1.086
10		1.1393					
11				.9991			
14		.929					
16			.7888		.8619		1.0166
17				.9795	.9114		
18		1.1043	.8383	.9816			
19	1.643						1.3146
22	1.0059						
24	.8764	.8779	.9114	.9114	.8939	.9511	.9114
Max	1.643	1.1393	1.2445	.9991	1.0517	1.1949	1.3146
Min	.8764	.8779	.7888	.9114	.8619	.9511	.9114
Avg	1.153	1.0223	.9458	.9572	.9297	1.073	1.0822

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154115 / 33/11 KV ASHOK NAGAR NILANGA

Feeder No / Name : 202 / ASHOK NAGAR SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		.6722				.6653	
8	.7947		.6099	.7468	.6653		.7468
10		.4435					
11				.3326		.2987	
14		.1848					
16			.2427		.2012		.1848
17				.2218	.2507		
18		.2957	.3696	.2587			
19	.6602						.5359
22	.2241						
24	.1848	.1867	.1848	.1928	.1848	.2241	.1734
Max	.7947	.6722	.6099	.7468	.6653	.6653	.7468
Min	.1848	.1848	.1848	.1928	.1848	.2241	.1734
Avg	.4660	.3566	.3518	.3505	.3255	.3960	.4102

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154014 / 33/11 KV UJED

Feeder No / Name : 201 / 11KV SYED ANKULGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3353	.3353	.4572		.2858	.0286
2				.6706	1.0974	.2858	.0286
3		.3688				.2858	.0286
4					1.1831		
6	1.1145	.7042					
7		.8383					
8		.8718		1.0059	1.166		
9		.8048					
10						.503	.503
11						.503	.5335
12						.503	.6706
13						.5365	.6859
14						.5868	.7545
15						.5868	.8383
16		.0191			.1905	.5868	.8383
17	.1905	.0286			.1905		.8383
18		.0286	.2858		.2858	.0191	.2858
19		.0286	.2858		.381	.0191	.3429
20		.0229	.3429			.0286	.381
21		.0229	.381		.4572	.0381	.381
22	.1905	.0229	.2858		.4763	.0381	.381
23		.0229	.2858			.0286	.381
24	.724	.2515	.3353	.503	.6097	.2858	.0286
Max	1.1145	.8718	.381	1.0059	1.1831	.5868	.8383
Min	.1905	.0191	.2858	.4572	.1905	.0191	.0286
Avg	.5549	.2914	.3172	.6592	.6038	.3012	.4405

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154014 / 33/11 KV UJED

Feeder No / Name : 202 / 11 KV BIBRAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4191	.8383	1.1736		.4763	.0476
2				1.3413	1.7295	.4763	.0476
3		.6371		1.8861		.4763	.0572
4					1.7974		
6	2.34	.8383					
7		.8718					
8		1.2574		2.9835	1.6766		
9		2.1365					
10						1.0059	1.0059
11						1.3565	2.0119
12						1.3565	2.2634
13						1.5261	2.431
14						1.6956	
15						1.6956	2.3472
16		.0381				.0381	2.5149
17	.381	.0381	1.3413		.381	2.0348	2.5149
18		.0476	.6668		.4191	.0476	.5716
19		.0572	.7621		.5716	.0476	.6668
20		.0572	.7621			.0572	.7621
21		.0572	.7621		.5335	.0533	.7621
22	.4763	.0476	.7621		.5335	.0533	.7621
23		.0476	.7621			.0533	.6668
24	1.3717	.4191	.8383	1.0059	1.2955	.4763	.0476
Max	2.34	2.1365	1.3413	2.9835	1.7974	2.0348	2.5149
Min	.381	.0381	.6668	1.0059	.381	.0381	.0476
Avg	1.1423	.4647	.8328	1.6781	.9931	.7181	1.1459

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154014 / 33/11 KV UJED

Feeder No / Name : 203 / 11 KV Ujed

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2286	.0953	.381		.3353	.3353
2				.381	.3429	.3688	.4191
3		.2667		.381		.373	.4191
4						.4694	.4191
5						.5087	.503
6						.6706	.5868
7						.6706	.5868
8						.7545	.6706
9						.7042	.6706
10	.3185	.6036		.5716			
11	.4359	.6036			.503		
12	.503	.6706			.5365		
13		.6706		.4527	.503		
14		.6706		.373	.4191		
15		.5868		.3086	.4191		
16		.5868				.0381	.2858
17	.503	.5868	.6706		.4694	.0381	.381
18		.0038	.381		.2858	.0381	.4191
19		.0381	.381		.4191	.0381	.4763
20		.0476	.381			.0438	.4763
21		.0381	.381		.381	.0533	.381
22	.4763	.0381	.381		.3429	.0381	.381
23		.0381	.381			.0343	.381
24	.381	.2286	.0381	.381	.362	.2515	.3353
Max	.503	.6706	.6706	.5716	.5365	.7545	.6706
Min	.3185	.0038	.0381	.3086	.2858	.0343	.2858
Avg	.4363	.3475	.3433	.4037	.4153	.3016	.4515

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154024 / 33/11 KV YEROL

Feeder No / Name : 201 / 11 KV DIGOL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.3772	.4527	.3734	.4287	.8097	.9907
2	.5601	.3429	.5281	.5601	.4801	.9717	1.1012
3	.5601	.4287	.6036	.6535	.5144	1.0526	1.2431
4	.6535	.6001	.7545	.6535	.6001	1.0526	1.1888
5	.7468	.6859	.7882	.7392	.6516	1.1336	1.2193
6	.7468	.8573	.8632	.8316	.6859	1.2955	1.2498
7						1.7004	1.829
8						1.9433	1.8595
9						1.7004	1.989
10	1.1145	1.3375	1.2146	1.3717	1.166		
11	1.3717	1.4403	1.4575	1.7004	1.5089		
12	1.3717	1.5432	1.6194	1.3717	1.6461		
13	1.4575	1.4403	1.4575	1.3375			
14		1.1145	1.3765	1.1145	1.6289		
15	1.5089	1.2689	1.4575	1.406	1.3717		
16	1.3717	1.406	1.4575	1.6289	1.3717		.2263
17	1.3032	1.7833	1.3765	1.8004	1.4575	.2058	.2229
18	.3429	.3018	.2801	.2058	.2987	.3086	.3086
19	.5487	.6036	.4668	.4287	.5601	.5487	.5487
20	.5487	.6602	.6535	.5487	.5601	.5487	.5487
21	.5487	.6036	.5601	.5144	.5601	.5487	.5144
22	.4801	.5281	.4668	.4801	.3734	.4458	.4458
23	.4973	.4527	.4668	.4287	.3734	.3429	.4115
24	.4108	.4287	.3772	.3734	.4801	.7287	.823
Max	1.5089	1.7833	1.6194	1.8004	1.6461	1.9433	1.989
Min	.3429	.3018	.2801	.2058	.2987	.2058	.2229
Avg	.8277	.8669	.8895	.8820	.8359	.9022	.9289

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154024 / 33/11 KV YEROL

Feeder No / Name : 202 / 11 KV YEROL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4049		.5068	.3391	.6001	.3395	.3086
2	.4858		.6335	.503	.6859	.3395	.3601
3	.4858		.6516	.503	.6516	.3772	.3429
4	.5668		.6878	.5087	.7202	.3772	.4287
5	.5668		.7164	.6783	.7716	.4715	.5487
6	.6478		.7164	.6783		.5658	.5765
7	.8097		.9259	.9326	.8573		
8	.8907		.9774	.9326	.8573		
9	.9431		.8745	.8097	.9431		
10		.5487				.8962	.5792
11		.543					.7545
12		.543				.7545	.6268
13						.7716	.7202
14						.7888	.7545
15						.823	.7202
16	.2058	.1698	.1886	.1715	.1715	.823	.703
17	.2058	.2263	.1867		.1848	.6859	.6401
18	.1715	.2641	.2241	.2058	.1848	.2401	.2058
19	.4287	.5281	.4668	.2058	.462	.4115	.3944
20	.4801	.5847	.4668	.5144	.5601	.4973	.4801
21	.4287	.5658	.4668	.4287	.5601	.463	.463
22		.3961	.3772	.3772	.4668	.4115	.3772
23		.3772	.3018	.3086	.4108	.3086	.3086
24	.4858		.3018	.3353	.3429	.3395	.3086
Max	.9431	.5847	.9774	.9326	.9431	.8962	.7545
Min	.1715	.1698	.1867	.1715	.1715	.2401	.2058
Avg	.5130	.4315	.5373	.4960	.5548	.5343	.5048



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154024 / 33/11 KV YEROL

Feeder No / Name : 203 / 11 KV SAKOL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.543		.5281	.543	.4801	1.1336	1.4251
2	.543		.5281	.6335	.6001	1.2955	1.4251
3	.724		.5658	.724	.5487	1.2955	1.3765
4	.724		.6036	.724	.6001	1.2955	1.3717
5	.724		.6602	.8145	.6516	1.4575	1.9052
6	.8145			.905	.6859	1.7004	1.829
7						2.1052	2.0576
8						2.1862	2.1338
9						2.0481	2.4006
10	1.6804		1.2955	1.6289	1.4575		
11	1.9109	1.6804	1.6194	2.1357	2.0233		
12		2.1434	1.8623	1.8861	2.0576		
13	2.2977	2.0919	1.9433	2.0576	2.3148		
14	2.3148	2.1948	1.9433	2.0576	2.0576		
15	2.0233	2.1262	1.9433	2.1948	2.1434		
16	2.0233	2.1434	2.0243	2.0919	2.3148	.2452	.2641
17		2.2805	1.8623	2.1434	2.1862	.1715	.2572
18	.3772	.2829	.2715	.2572	.181	.1715	.2572
19	.6001	.6413	.4525	.6001	.543	.5144	.4973
20		.7319	.6535	.7202	.543	.5487	.6001
21	.5487	.679	.6335	.6173	.543	.583	.583
22		.5847	.543	.5487	.4525	.5144	.5144
23		.5658	.543	.4801	.4887	.4801	.463
24	.543		.5093	.543	.4458	1.1336	1.3108
Max	2.3148	2.2805	2.0243	2.1948	2.3148	2.1862	2.4006
Min	.3772	.2829	.2715	.2572	.181	.1715	.2572
Avg	1.1495	1.3959	1.0493	1.1575	1.1104	1.0489	1.1484

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154024 / 33/11 KV YEROL

Feeder No / Name : 204 / 11 KV DHAMANGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5089	.4801	1.2003	1.3413	1.0288	.3772	
2	1.6766	.5144	1.5223	1.5089	1.166	.3772	
3	1.6766	.6001	1.5775	1.6766	1.286	.415	
4	2.0119	.7716	1.7147	2.0119		.4338	
5	2.0957	.8573	1.8861	2.0348		.4338	
6	2.4587	.9945	2.1434	2.2891		.4715	
7	2.4587	1.4575	2.5377	2.713			
8	2.5434		2.572	2.8147			
9	2.4863	1.4403	2.5987	2.8464			
15							.6001
16			.132				2.3061
17			.1307	.1715			1.9509
18	.1715		.1494	.1715			.2401
19	.4287		.3772	.4973			.3772
20	.4973	.547	.5658	.4287	.4715		.4973
21		.4715	.5658		.4338		.4801
22	.4287	.415	.4715	.4525	.3772		.463
23	.3429	.415	.4715	.3772	.415		.463
24	1.3413	.3429	.7282	1.3413	.8573	.3772	.2401
Max	2.5434	1.4575	2.5987	2.8464	1.286	.4715	2.3061
Min	.1715	.3429	.1307	.1715	.3772	.3772	.2401
Avg	1.4751	.7159	1.1858	1.4173	.7545	.4122	.7618

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154064 / 33/11KV SHIRUR ANANTPAL

Feeder No / Name : 201 / 11KV SHIRUR ANANTPAL

GAOTHAN FEEDER

GAOTHAN F Feeder KV- 11 /  
OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4287	.4287	.4287		.3429
2			.4287				
3	.5144			.5144	.5144	.5144	
4							.5144
5					.7716		
7							1.0288
8	.8573	.8573			1.0288		.9431
9	.6859	.7716		.8573		.7716	
10	.6859	.6859		.6859	.7716		
11							.6001
12	.5144			.5144		.5144	
13		.4287			.5144		
14	.4287						
16	.5144	.5144		.4287	.3429	.4287	
17	.5144	.5144	.6001			.5144	.5144
18		.6001	.6859		.6001		
19						.6859	
20							.6859
21		.5144					
22			.6001		.6001		.5144
23	.5144	.5144		.4287		.5144	
24	.4287	.4287	.4287	.5144	.4287	.4287	.4287
Max	.8573	.8573	.6859	.8573	1.0288	.7716	1.0288
Min	.4287	.4287	.4287	.4287	.3429	.4287	.3429
Avg	.5659	.5830	.5287	.5466	.6001	.5466	.6192

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154064 / 33/11KV SHIRUR ANANTPAL

Feeder No / Name : 202 / 11KV BHINGOLI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3429	.1715	.2572		.6001
2			.3429				
3	.2572			.2572	.3429	.6859	
4							.7716
7							1.286
8							1.3717
9						.7716	
10	.5144	.6001		.7716	.6859		
12	.8573			1.0288			
13		.7716			.8573		
14	.9431						
16	.8573	1.0288		.9431	.6859	.1715	
17	.6859	1.2003	1.2003			.1715	.2572
18		.1715	.2572		.1715		
19						.2572	
20							.2572
21		.3429					
22			.3429		.2572		.2572
23	.2572	.2572		.3429		.2572	
24	.2572	.2572	.2572	.2572	.3429	.5144	.5144
Max	.9431	1.2003	1.2003	1.0288	.8573	.7716	1.3717
Min	.2572	.1715	.2572	.1715	.1715	.1715	.2572
Avg	.5787	.5787	.4572	.5389	.4501	.4042	.6644

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154064 / 33/11KV SHIRUR ANANTPAL

Feeder No / Name : 203 / 11KV ARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.0288	1.286	1.286		.6001
2			1.286				
3	1.2003			1.3717	1.3717	.5144	
5					1.5432		
8	2.0576	1.8004			1.8861		
9	2.2291	1.8861		2.572			
11							1.9719
12	.3429			.2572		2.3148	
13		.2572					
14	.3429						
16	.3429	.1715		.3429	.3429	2.4006	
17	.3429	.3429				2.572	2.0576
18		.5144			.3429		
19						.5144	
20							.6859
21		.6859					
22			.6859		.2572		.7716
23	.4287	.5144		.5144		.5144	
24	1.0288	.8573	.9431	1.4575	1.2003	.2572	.5144
Max	2.2291	1.8861	1.286	2.572	1.8861	2.572	2.0576
Min	.3429	.1715	.6859	.2572	.2572	.2572	.5144
Avg	.9240	.7811	.9860	1.1145	1.0288	1.2983	1.1003

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154064 / 33/11KV SHIRUR ANANTPAL

Feeder No / Name : 204 / 11KV WATER WORKS

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 11 / OUTGOING

UTILITY

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0343	.0343	.0343		.0343
3	.0343			.0343	.0343	.0343	
4							.0343
5					.0343		
7							.0343
8	.0343	.0857			.0343		.0343
9	.1715	.0857		.0857		.0857	
10	.1715	.0857		.1715	.0343		
11							.0343
12	.0343			.1715		.0857	
13		.1715			.0343		
14	.0343						
16	.1715	.0857		.1715	.0343	.0343	
17	.0343	.0857				.0343	
18		.0857			.0343		
19						.0857	
21		.0857					
22			.0857		.0343		
23	.0343	.0857		.0343		.0857	
24	.0343	.0343	.0857	.0857	.0343	.0343	.0857
Max	.1715	.1715	.0857	.1715	.0343	.0857	.0857
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.0755	.0891	.0686	.0986	.0343	.06	.0429

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154064 / 33/11KV SHIRUR ANANTPAL

Feeder No / Name : 205 / 11KV SHIRUR ANANTPAL AG      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6001	.6859	.6859		.0343
2			.6859				
3	1.0288			.7716	.7716	.0343	
5					.9431		
8	1.3717	1.1145			1.1145		
9	1.3717	1.0288		1.7147			
11							1.4575
12						1.5432	
16	.0343	.0343		.0343	.0343	1.6289	
17	.0343	.0343	.6859			1.7147	1.3717
18		.0343	.0343		.0343		
19						.0857	
20							.0343
21		.0857					
22			.0343		.0343		.0343
23	.0343	.0343		.0343		.0343	
24	.5144	.5144	.6001	.7716	.6859	.0343	.0343
Max	1.3717	1.1145	.6859	1.7147	1.1145	1.7147	1.4575
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.6271	.3601	.4401	.6687	.5380	.7251	.4944

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154064 / 33/11KV SHIRUR ANANTPAL

Feeder No / Name : 206 / 11 KV LAKKAD JAWALGA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2572	.3429	.3429		1.1145
2			.2572				
3	.2572			.4287	.4287	1.2003	
4							1.3717
7							1.8004
8							2.1434
9						2.0576	
10	1.0288	1.0288		1.286	1.5432		
12	1.5432			1.7147			
13		1.4575			2.0576		
14	1.4575						
16	1.3717	1.7147		1.7147	2.0576	.1715	
17	1.2003	1.8861	2.1434			.2572	.2572
18		.1715	.4287		.2572		
19						.3429	
20							.3429
21		.4287					
22			.4287		.2572		.2572
23	.3429	.3429		.3429		.2572	
24	.2572	.2572	.3429	.3429	.3429	.8573	.8573
Max	1.5432	1.8861	2.1434	1.7147	2.0576	2.0576	2.1434
Min	.2572	.1715	.2572	.3429	.2572	.1715	.2572
Avg	.9324	.9109	.6430	.8818	.9109	.7349	1.0181



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154066 / 33/11 KV SAKOL

Feeder No / Name : 201 / 11 KV TALEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.4525	.4287	.4108	.3898	1.3413	1.2631
2	.4115	.4706	.4458	.3734	.4252	1.3413	1.6057
3	.4115	.4706	.4458	.4805	.4252	1.3717	1.6385
4						1.4327	1.7901
5						1.5242	1.9559
6						1.6156	2.1216
7						2.0729	2.3472
8						2.0424	2.0972
9						2.0576	2.0645
10	1.1401	1.1888	1.0486	1.4175	1.4327		
11	1.989	1.829	1.3108	2.0111	2.0729		
12		1.9204	1.6194	1.8031	2.1795		
13		1.9814	1.6842	1.9418	2.0119		
14	2.1216	2.0729	1.8351	2.0576	1.7375		
15	1.989	2.1033	1.9662	2.2291	1.5851		
16	1.6575	2.1033	1.9989	2.2634	1.2193		.0876
17	1.7238	2.1033	2.0317	2.4006	2.0119		.1052
18	.2896	.1715	.1341	.1372	.12		.181
19	.4344	.3429		.3696	.3086		.3658
20	.5544	.5144		.4805	.463		.5487
21	.4805	.4973		.3326			.4805
22	.4805	.463		.3696	.4115		.4066
23	.4805	.4287		.3696	.3772		.3658
24	.4115	.4525	.4287	.4481	.3898	1.2193	1.0364
Max	2.1216	2.1033	2.0317	2.4006	2.1795	2.0729	2.3472
Min	.2896	.1715	.1341	.1372	.12	1.2193	.0876
Avg	.9367	1.0870	1.1829	1.1053	1.0330	1.6019	1.1367

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154066 / 33/11 KV SAKOL

Feeder No / Name : 202 / 11 KV SAKOL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.3963	.5087
2						.3963	.5765
3						.4268	.6443
4						.4572	
5						.5487	
6						.6706	.8139
7						.7011	.8478
8						.7011	.852
9							.8192
10	.6104	.6173	.6935	.7011	.7316		
11	.7042	.6401	.6516	.7282	.7011		
12	.6706	.7011	.583	.6859	.6401		
13	.5365	.7011	.6241	.6859	.6097		
14	.5967	.6706	.5487	.7202	.5792		
15	.6299	.6554	.5182	.6859	.5792		
16	.6706	.6706	.4877	.6859	.4268		
17	.5636	.6706	.5556	.6859	.6097		
24						.3963	.4748
Max	.7042	.7011	.6935	.7282	.7316	.7011	.852
Min	.5365	.6173	.4877	.6859	.4268	.3963	.4748
Avg	.6228	.6659	.5828	.6974	.6097	.5216	.6922

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154066 / 33/11 KV SAKOL

Feeder No / Name : 203 / 11 KV GHUGI SANGVI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5182	.3582		.5487	.5609	
2	.5487	.4298		.5144	.1296	
3	.6097	.4961		.583	.6935	
4	.7468	.567		.6516	.8322	
5	.7926	.6024		.6783	.9015	
6	.8688	.8413		.7122	.9709	
7		.9816		.7293	1.0402	
8		.9114		.7956	1.1096	
9		.9114		.7377	.5144	
10			.3544			.2774
11						.2774
12						.6859
13						.8916
14						1.0174
15						1.0288
16				.0709		1.0288
17	.2195			.0177		1.0288
18	.2195			.1267		.1086
19	.2926			.2926		.2957
20	.3326			.3292		.2587
21	.1848			.2218		.2218
22	.1848			.1848		.1848
23	.1478			.1848		.1463
24	.4268	.3258		.2804	.4961	
Max	.8688	.9816	.3544	.7956	1.1096	1.0288
Min	.1478	.3258	.3544	.0177	.1296	.1086
Avg	.4352	.6425	.3544	.4255	.7249	.5323

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154111 / 33KV/11KV HIPPALGAON

Feeder No / Name : 201 / 11 KV SHIVPUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	1.0288	1.0562	.8676			
2	.8962	1.0288	1.166	1.1317			
3	1.0242	1.5432		1.3032			
4	1.1706	1.5432		1.4403			
5	1.39	1.5432		1.6461			
6	1.3717	1.6289		1.6461			
7	1.5364	1.6289		1.7147			
8	1.5402	1.6289		1.7147			
9		1.6289		1.6461			
12							1.3717
16	.1905	.2858	.362	.3395			
17	.3048	.2858	.3772	.3772			
18	.4382	.3048	.415				
19	.4191	.3429	.4527				
20	.4191	.381	.415				
21	.381	.415	.4527				
22	.381	.4527	.4527				
23	.381	.4572	.4527		.3086		
24	.6097	.823	.6401	.6602	.7716	.3429	.3429
Max	1.5402	1.6289	1.166	1.7147	.7716	.3429	1.3717
Min	.1905	.2858	.362	.3395	.3086	.3429	.3429
Avg	.7765	.9417	.5675	1.2073	.5401	.3429	.8573

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154111 / 33KV/11KV HIPPALGAON

Feeder No / Name : 202 / 11 KV HIPPALGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.2743	.2286	.2614			
2	.2614	.2829	.2286	.2263			
3	.2667	.2858		.2241			
10		.6668					
11	.7621	.823		.7316			
12	.8779	.823		.823			
13	.9145	.9335		.9145			
14	.9709	.9335		.8779			
15	.9877	.9335		.823			
16	.9145	.9335	.6535	.9145			
17	.8962	.9709	.7545	.9145			
18	.2667	.2667	.2667				
19	.2858	.3048	.2667				
20	.2858	.3429	.2641				
21	.2858	.3429	.3018				
22	.2858	.3429	.3018				
23	.2858	.2641	.3018		.3429	.5144	
24	.381	.2858	.2263	.2641	.2572	.5144	.6001
Max	.9877	.9709	.7545	.9145	.3429	.5144	.6001
Min	.2614	.2641	.2263	.2241	.2572	.5144	.6001
Avg	.5431	.5562	.3449	.6341	.3001	.5144	.6001

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154111 / 33KV/11KV HIPPALGAON

Feeder No / Name : 203 / 11 KV GANESHWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.0934	.0953	.1132			
2	.1143	.0914	.0953	.1132			
3	.1143	.0953		.1132			
10		.2829					
11	.2667	.2743		.2743			
12	.3048	.3658		.2926			
13	.3429	.3658		.2926			
14	.3429	.3734		.2926			
15	.3429	.3734		.2743			
16	.2926	.3734	.2241	.3292			
17	.2614	.3734	.381	.3239			
18	.1143	.0953	.1132				
19	.1143	.1143	.1334				
20	.1143	.1143	.132				
21	.1143	.1143	.132				
22	.0953	.1143	.132				
23	.0953	.1132	.132		.1715	.0857	
24	.1334	.0943	.0953	.1132	.0857	.2572	.2572
Max	.3429	.3734	.381	.3292	.1715	.2572	.2572
Min	.0953	.0914	.0953	.1132	.0857	.0857	.2572
Avg	.1928	.2124	.1514	.2302	.1286	.1715	.2572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154004 / 33/11 KV AHMEDPUR

Feeder No / Name : 202 / 11 KV Nandura AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4937	1.4937		.8478	.9431		
2	1.8671	1.4937		.9335	.9431		
3	1.8671	1.6804		1.1203	.9431		
4	2.0348	1.8671		1.1203	.9335		
5	2.6139	2.2405		1.307	1.1203		
6	2.8006	2.2405		1.3565	1.4632		
7	2.713	2.2405		1.4632	1.8099		
8	2.713			1.4632	1.829		
9	2.713			1.4632			
10			.9145				1.8671
11			1.2803				2.8006
12			1.2803				2.8006
13			1.2803				2.8035
14			1.3203				2.9874
15							2.713
16						3.3608	2.9874
24	1.5089	1.4003		.9335	.5658		
Max	2.8006	2.2405	1.3203	1.4632	1.829	3.3608	2.9874
Min	1.4937	1.4003	.9145	.8478	.5658	3.3608	1.8671
Avg	2.2325	1.8321	1.2151	1.2009	1.1723	3.3608	2.7085

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154004 / 33/11 KV AHMEDPUR

Feeder No / Name : 203 / 11 KV THODAGA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1867	.1867	.1867	.1886	.5601	
2	.1886		.1867	.1867	.1886	.5601	
3	.1886	.1867	.1867	.1696	.1867	.7468	
4	.1867	.1867	.1867	.1696	.1867	.7468	
5	.1867	.1867	.1696	.1867	.1867	.7468	
6	.2829	.1867	.2801	.2801	.1829	.9335	
7	.2829	.1867	.2801	.2801	.181	.9335	
8	.2801	.1867	.2543	.2801	.1753	.9335	1.1203
9	.1867		.2801	.1829		.1867	1.1203
10	.5087		.5487	.7468			.1867
11	1.0269		.9145	1.1203			.1829
12	1.0174		1.0974	1.2136			.1829
13	.5601		1.086	1.1203			.1829
14			1.0974	1.1203			.1848
15	.8478		1.086	1.0164			.1829
16	.8478	.9335		.8907	.9335	.1867	.1867
17		.9335		.8192			
18		.1867		.1886			
19		.1867		.1696	.1867		
20		.2543		.1715	.1867		
21		.2801		.1753	.1867		
22		.2543		.1829	.1867		
23		.1867		.1867	.1867		
24	.1886	.1867	.1867	.1867	.1886	.5601	.5601
Max	1.0269	.9335	1.0974	1.2136	.9335	.9335	1.1203
Min	.1867	.1867	.1696	.1696	.1753	.1867	.1829
Avg	.4355	.2943	.5017	.4680	.2355	.6450	.4091



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154004 / 33/11 KV AHMEDPUR

Feeder No / Name : 204 / 11 KV NANDURA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1867	.1867	.1867	.1886	.1867	
2	.1867	.1867	.1867		.1886	.1867	
3	.1867	.1867	.1867	.1867	.1867	.1867	
4	.1867	.1867	.1867	.1867	.2801	.1867	
5	.2801	.2801	.2801	.2801	.362	.2801	
6	.3734	.3734	.3391	.3734	.4382	.4668	
7	.4239	.5601	.4572	.5601	.5258	.5601	
8	.4096		.5487	.5601	.4287	.3734	.3734
9	.3315		.3658	.3658			.3772
10	.1696		.2715	.2801			.1867
11			.2715				.1867
12			.1829				.1867
13			.1829				.1867
14			.1829				.1867
15	.1696		.1829				.1867
16	.1696	.1696			.1867	.1867	.1867
17		.1867		.1638	.1867		
18		.2801		.1677	.1867		
19	.3734	.3734		.2543	.2801		
20	.2801	.4668		.4287	.3734		
21	.2801	.3734		.4572	.3734		
22		.2801		.3734			
23		.2801		.2801	.2801		
24	.1886	.1867	.2801	.1867	.1886	.1867	.1867
Max	.4239	.5601	.5487	.5601	.5258	.5601	.3772
Min	.1696	.1696	.1829	.1638	.1867	.1867	.1867
Avg	.2623	.2848	.2683	.3113	.2909	.2801	.2244

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154004 / 33/11 KV AHMEDPUR

Feeder No / Name : 205 / 11 kv Kalegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.2801	.2801	.3361	.2829	.7468	
2	.2801	.2801	.2801	.2801	.2829	.9335	
3	.2801	.2801	.2801	.2801	.2829	1.1203	
4	.2801	.2801	.2801	.2543	.3734	1.1203	
5	.3734	.2801	.3734	.3391	.4668	1.307	
6	.4668	.2801	.4572	.4668	.5487	1.4937	
7	.5087	.2801	.5487	.5487	.5487	1.4937	
8	.503		.5487	.5601	.4287	1.4937	1.7737
9	.4915		.4525	.3658			1.7918
10			.9145	1.1203			.2801
11	1.307		1.2803	1.3565			.3391
12	1.1869		1.4632	1.3565			.3734
13	1.3565		1.4784				
14	1.3565		1.4632				
15	1.4937		1.307				.3734
16	.4668	1.1869	1.4632		1.4937	.3734	.2801
17		1.1869		1.3108	1.307		
18		.2801		.3391	.1867		
19				.4239	.3734		
20		.4239		.5144	.5601		
21	.2801	.5601		.5487	.5601		
22		.4668		.4668	.4668		
23		.3734		.3734	.3734		
24	.2829	.2801	.2801	.2801	.2829	.7468	.7468
Max	1.4937	1.1869	1.4784	1.3565	1.4937	1.4937	1.7918
Min	.2801	.2801	.2801	.2543	.1867	.3734	.2801
Avg	.6585	.4479	.7736	.5761	.5188	1.0829	.7448

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154018 / 33/11 KV KINGAON

Feeder No / Name : 201 / 11 KV KINGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516		.6368	.6361	.5453	.9097	.727
2			.6368	.5453	.6543	1.0007	
3	.7023	.4275		.727	.7634	1.0007	.9877
4			.7278	.8179	.9088		
5			.8188	1.0542	1.1814		
6			.9097	1.3632	1.454		
7			1.0917		1.5086		
8				1.6358			
9		.7278	.8906	1.7267			
10							1.2178
11							1.2723
12							1.2723
13							1.1269
14							1.0905
15							1.0542
16		.5458					1.1451
17			.7997	.8179			1.0724
18		.6368	.9088	.9633			.8906
19		.7278	1.1814	1.2178			
20		.7278	1.2905	1.2541			1.2723
21		1.0917	1.0905	1.0905			1.2723
22		1.0917		.9451			1.1814
23		1.0917	.7997	.7247			.9088
24	.5853	1.0745	.6361	.9451	.6361	.7682	1.2723
Max	.7023	1.0917	1.2905	1.7267	1.5086	1.0007	1.2723
Min	.5853	.4275	.6361	.5453	.5453	.7682	.727
Avg	.6464	.8143	.8871	1.0290	.9565	.9198	1.1102

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154018 / 33/11 KV KINGAON

Feeder No / Name : 203 / 11 KV KOPARA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823		.7316	.8325	.777		3.0618
2			.6401	.9649	.888	3.2407	
3	1.0242	.9709	.7316	1.0948	.835	3.0493	3.3665
4						3.1093	
5						3.2922	
6						3.4751	
7						3.6111	
8						3.658	
10		.9145	2.2199	2.5899	1.4632		
11		2.0119	2.9599	3.3402			
12		2.7435	3.0618				
13		2.9264	2.932	3.3402	3.8409		
14		3.2922	2.7835	3.5258			
15		3.1093	2.5979	3.6742			
16		3.658		3.6742			.2041
17			2.9691	3.6928			.2041
18		.3658	.4268	.3711			.4825
19		.5487	.8536	1.0206			
20			1.2619	1.0392			.835
21		.9145	1.0206	.9278			.7423
22		.7316		.8165			.6495
23		.823	.7794	.777			.5567
24	.7207		.7423	.8165	.7423	2.6425	.7423
Max	1.0242	3.658	3.0618	3.6928	3.8409	3.658	3.3665
Min	.7207	.3658	.4268	.3711	.7423	2.6425	.2041
Avg	.8560	1.7700	1.6695	1.9117	1.4244	3.2598	1.0845

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432] BU 5151

Substation No/ Name :- 154018 / 33/11 KV KINGAON

Feeder No / Name : 204 / 11 KV KINGAON EXPRESS

FEEDER Feeder KV- 11 /

OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	21-MAR-17
HR	Load (MW)
24	3.1855
Max	3.1855
Min	3.1855
Avg	3.1855

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154043 / 33/11 KV UJANA

Feeder No / Name : 201 / 11 KV UJANA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.531		1.4784	.7164	.5014
2			1.6804		1.4632	.7164	.5014
3			1.7737		1.4022	.7164	.4656
4			1.8099		1.5432		
5			1.848		1.7147		
6			2.0119		2.0576		
7			1.893		2.0576		
8			1.8004		1.8861		
9			1.8519		1.949		
10				1.1576		1.4022	
11						1.9909	1.6476
12						2.4253	1.7147
13						2.4764	1.7833
14						2.4615	1.8229
15						2.5339	1.7528
16		.4066		.4801	.4481	2.5606	1.7147
17		.6154		.6161	.4481	2.5606	1.6991
18		.7468		.6722	.5068	.5731	.5975
19		.8962			.6268	.5731	.7468
20		.9808			.8954	.6154	.9054
21		.8316			.8954	.6516	.8215
22		.7468			.7164	.6516	.7468
23		.5731			.7164	.6447	
24	1.6118	.8316	1.3957	1.1576	1.307	.724	.5731
Max	1.6118	.9808	2.0119	1.1576	2.0576	2.5606	1.8229
Min	1.6118	.4066	1.3957	.4801	.4481	.5731	.4656
Avg	1.6118	.7365	1.7596	.8167	1.2285	1.3886	1.1247

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154043 / 33/11 KV UJANA

Feeder No / Name : 202 / 11 KV SANGHAVI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			2.6787		1.8099	.7164	.6733
2			2.8807		2.1719	.7164	.5731
3			2.9492		2.0576	.7164	.567
4			3.0864		2.1719	.0358	
5			3.2236		2.5339		
6			3.2579		2.9797		
7			3.2217		3.1741		
8			3.1539		2.9797		
9			3.2956		3.0769		
10						1.829	1.7558
11						2.9569	2.915
12						3.0308	3.2251
13						3.2895	3.0864
14						3.5852	2.982
15						3.8439	3.1901
16				.543		3.6961	3.2236
17				.6535		3.5482	3.2579
18				.7095	.7468	.9313	.6722
19		1.0185			.8954	.9412	
20		1.1203			.8954	.8954	1.1203
21		1.0829			.8059	.8954	1.0374
22		.9808			.8059	.8596	.9709
23		.8215			.7164	.8596	
24	2.2634	1.829	1.9022	1.5684	1.8099	.724	.7087
Max	2.2634	1.829	3.2956	1.5684	3.1741	3.8439	3.2579
Min	2.2634	.8215	1.9022	.543	.7164	.0358	.567
Avg	2.2634	1.1422	2.9650	.8686	1.8520	1.7932	1.8724

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154043 / 33/11 KV UJANA

Feeder No / Name : 203 / 11 KV GANGA HIPPARGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3326		.3734	1.6118	1.9753
2			.4024		.362	1.6118	2.2177
3			.4525		.3734	1.7909	2.268
4						2.1491	2.268
5						2.1491	2.3777
6						2.5072	2.4394
7						2.5873	2.5133
8						2.5606	2.5873
9						2.4025	2.5873
10		1.3717	1.4723	2.4006	1.307		
11		2.6578		2.7092			
12		2.4691		2.8121			
13		2.6749		2.8121	2.7092		
14		2.7435		2.7435	2.8807		
15		2.8121		2.7435	2.8807		
16		2.8807		2.9321	2.8807		.1417
17		2.7435		2.9264	2.8121		.1867
18		.5068		.5228	.415	.4298	.3018
19		.543			.4477	.3429	.3772
20		.6535			.4477	.2804	.4287
21		.5121			.4477	.2103	.3361
22		.4066			.3582	.2058	.2987
23		.3361			.3582	.1772	
24	.2172	.362	.2686	.1829	.3734	1.4327	1.6461
Max	.2172	2.8807	1.4723	2.9321	2.8807	2.5873	2.5873
Min	.2172	.3361	.2686	.1829	.3582	.1772	.1417
Avg	.2172	1.5782	.5857	2.2785	1.2142	1.4031	1.4677



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154043 / 33/11 KV UJANA

Feeder No / Name : 204 / 11 KV UJANA EXPRESS FEEDER NON SHEDDABLE WATER SUPPLY AND  
Feeder KV- 11 / OUTGOING UTILITY

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0187		.181	.181	.197
2			.0187		.1829	.1791	.197
3			.0187		.181	.1791	.1991
4			.0185		.1772	.1791	.181
5			.0187		.1867	.1791	.1772
6			.0187		.1848	.1753	.1772
7			.0181		.181	.1753	.1772
8			.0181		.1715	.1753	.1791
9			.0183		.1715	.1753	.1791
10		.0187	.0185	.1772	.1715	.1734	.1791
11		.0187		.1772		.1734	.1791
12		.0171		.1715		.1753	.1715
13		.0175		.181	.1829	.1753	.1829
14		.0181		.1715	.1829	.1772	.1772
15		.0187		.1848	.181	.1791	.1715
16		.0171		.1867	.1886	.1791	.1753
17		.0171		.1791	.1867	.1791	.2075
18		.0171		.1867	.1886	.1772	.2075
19		.0171			.1791	.1772	.2033
20		.0171			.1791	.197	.2033
21		.0187			.1791	.197	.1867
22		.0189			.1791	.197	.1867
23		.0187			.1791	.197	
24	.1715	.0185	.0187	.1848	.1867	.181	.197
Max	.1715	.0189	.0187	.1867	.1886	.197	.2075
Min	.1715	.0171	.0181	.1715	.1715	.1734	.1715
Avg	.1715	.0179	.0185	.1801	.181	.1806	.1866

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154043 / 33/11 KV UJANA

Feeder No / Name : 205 / 11KV BALGHAT KARKHANA NON SHEDDABLE EXPRESS HV FEEDERS  
FEEDER Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0362		.0362	.0358	.0347
2			.0366		.0362	.0358	.0347
3			.0362		.0362	.0358	.0347
4			.0373		.0366	.0358	.0347
5			.0373		.037	.0358	.0347
6			.0566		.0358	.0351	.0347
7			.056		.0343	.0347	.0347
8			.0543		.0343	.0351	.0347
9			.0366		.0343	.0343	.0347
10		.0362	.0343	.0362	.0351	.0343	.0351
11		.0362		.0351		.0343	.0362
12		.0366		.0362		.0347	.0366
13		.0362		.0362	.0343	.0347	.0354
14		.0358		.0362	.0354	.0351	.0351
15		.0343		.0362	.0366		.0343
16				.0362	.0362	.0347	.0343
17				.0366	.0358	.0343	.0377
18		.0343		.0373	.0373	.0343	.0377
19		.0377			.0358	.0347	.056
20		.056			.0358	.0347	.056
21		.0566			.0358	.0347	.056
22		.037			.0358	.0347	.0377
23		.0366			.0358	.0347	
24	.0532	.0362	.0377	.0366	.037	.0362	.0347
Max	.0532	.0566	.0566	.0373	.0373	.0362	.056
Min	.0532	.0343	.0343	.0351	.0343	.0343	.0343
Avg	.0532	.0392	.0417	.0363	.0358	.0350	.0380

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154081 / 33/11 KV ANDHORI

Feeder No / Name : 201 / 11 KV DHALEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1033	1.1765	1.7147	2.1033	1.8861	1.0517	1.2003
2	2.1033	1.1765	1.8861	2.2786	1.9719	1.0517	1.1145
3	2.2786	1.1765	1.9719	.0223	2.1434	.964	1.1145
4	2.572	1.267	2.1434	2.4539	2.2291		
5	2.6292	1.267	2.2291	2.6292	2.4006		
6	2.6292	1.3575	2.3148	2.8045	2.572		
7			2.4863	2.8921	2.4006		
8	2.2786		2.2291	2.6292	2.3148		
10		1.448				2.6578	2.4863
11		1.7194				2.572	
12		1.286					2.5415
13		1.6289					2.4539
14						2.4006	2.3663
15		1.6289	.6859	.6135	.6859		2.3663
16	.964	1.7147	.6859	.6135	.6859		2.3405
17		.7716	.6859	.6135			
18		1.1145		.7802			
19		1.4575	.8573	1.2003			1.4575
20		1.1145	1.2269	1.2003			
21		1.4575	1.2269				1.286
22	1.3575	1.4575	1.1393	1.2003		1.4575	1.4575
23	1.267	1.3717	.964	1.1145		1.6289	1.4575
24	1.4899	1.1765	1.3717	.964	1.0288	1.0517	1.5432
Max	2.6292	1.7194	2.4863	2.8921	2.572	2.6578	2.5415
Min	.964	.7716	.6859	.0223	.6859	.964	1.1145
Avg	1.9702	1.3384	1.5188	1.5361	1.8472	1.6484	1.7990

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154081 / 33/11 KV ANDHORI

Feeder No / Name : 202 / 11 KV ANDHORI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6135	.4525	.5144	.7011	.6859	1.3146	1.2003
2	.7011	.4525	.5144	.7011	.7716	1.1393	1.2003
3	.7011	.543	.5144	.7011	.8573	1.0517	1.2003
4	.7888	.543	.6001	.8764	.9431	1.3146	1.286
5	.7888	.6335	.6859	.964	1.0288	1.4022	1.4575
6	1.3146	.724	.7716	1.0517	1.1145	1.4899	1.5432
7			1.0288	1.1393		1.5775	1.7147
8			1.0288	.8764	.6859	1.4899	1.8004
9			.9431	.9431	.8764		
10			.9431	.7011	1.6289		
15							.5258
16						.5144	.6068
17		1.0288	1.6289	1.4022		.6859	.6859
18		1.0288	1.8004	1.8204		.7716	.6859
19			1.8004	1.8861		1.1145	.8573
20		1.286	1.8404	1.8004		1.0288	1.0288
21		1.2003	1.5775	1.7147		.9431	.8573
22	.362	1.0288	1.4022	1.5432		.7716	.6859
23	.362	1.0288	1.3146	1.4575	1.4022	.6859	.6859
24	1.3717	.362	.9431	.012	1.3717	1.4022	.6001
Max	1.3717	1.286	1.8404	1.8861	1.6289	1.5775	1.8004
Min	.362	.362	.5144	.012	.6859	.5144	.5258
Avg	.7782	.7932	1.1029	1.1273	1.0333	1.0999	1.0346

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154081 / 33/11 KV ANDHORI

Feeder No / Name : 203 / 11 KV KENDREWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5258		.6001	.5258	.5144	.7011	.6001
2	.5258		.6001	.5258	.5144	.7011	.6001
3	.5258		.6859	.5258	.6001	.7011	.6001
4						.7011	.6859
5						.7011	
6						.8764	.8573
7						1.0517	.9431
8						.964	.7716
9	1.9281		1.4575	1.4575	1.5775		.0686
10			1.286	1.2269	1.6289	.8573	.5144
11	1.7147			1.3289	1.4575		
12	1.6651			1.3289	1.5432		
13	1.5775			1.3289	1.5432		
14	1.5775	.8573		1.2403	1.4575		
15	1.4899	1.0288	1.1145	1.2269	1.4575		
16	1.4899	1.0288	.9431	1.2269	1.5432		
17						1.5432	1.6289
18		.6859	.5144	.3467		1.7147	1.7147
19		.7716		.6001		1.7147	1.8004
20		.8573		.7716		1.4575	
21		.7716	.7011			1.3717	1.5432
22		.7716	.7011	.6001		1.5432	1.4575
23		.7716	.6135	.6001	.7011	1.3717	1.3717
24	.5258		.6859	.5258	.5144	.7011	1.3717
Max	1.9281	1.0288	1.4575	1.4575	1.6289	1.7147	1.8004
Min	.5258	.6859	.5144	.3467	.5144	.7011	.0686
Avg	1.2314	.8383	.8253	.9051	1.1579	1.0984	1.0331

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154083 / 33/11 KV ROKADA SAWARGAON

Feeder No / Name : 201 / 11 KV ROKADA SAWARGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2572	.2572	.2572	.3086	.3429	.6859
2	.2572	.2572	.3429	.3429	.4287	.5144	.9431
3	.3429	.3429	.4287	.4287	.4801	.5144	1.1145
4						.6859	1.2003
5						1.0288	1.2003
6						1.0288	1.2003
7						1.3717	1.286
8						1.3717	1.3717
9						1.286	1.3717
10	1.5432	1.3717	1.7147	1.6289	1.7147		
11	2.1434	1.7147	2.0576	2.0576	2.3148		
12	2.1434	1.7147	1.9719	2.1434	.7716		
13	2.0576	1.5432	1.9719	2.1434	1.8861		
14	1.8861	1.4575	1.9719	2.1434	1.9719		
15	1.7147	1.5432	1.9719	2.1434	1.9719		
16	1.5432	.5144	2.0576	2.1434	1.9719		.1715
17	1.0288	1.7833	2.1434	2.1434	1.9719	.1715	.0857
18	.2572	.3429	.2572	.2401	.2572	.2058	.1715
19	.3429	.4287	.2572	.3086	.3429	.2743	1.0288
20	.3429	.4287	.2572	.3429	.3429	.3086	.2572
21	.2572	.4115	.2572	.3772	.2572	.3086	.2572
22	.2572	.3772	.2572	.3772	.2572	.2743	.2572
23		.3429	.2572	.3429	.2572	.2572	.2572
24	.2572	.2572	.2572	.2572	.2572	.3429	.5144
Max	2.1434	1.7833	2.1434	2.1434	2.3148	1.3717	1.3717
Min	.2572	.2572	.2572	.2401	.2572	.1715	.0857
Avg	.9784	.8383	1.0383	1.1012	.9869	.6052	.7430

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154083 / 33/11 KV ROKADA SAWARGAON

Feeder No / Name : 202 / 11 KV TAKALGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2572	.2572	.2572	.2572	.5144	.5144
2	.2572	.2572	.3429	.3429	.3429	.5144	.6859
3	.3429	.3429	.3772	.5144	.4287	.5144	.8573
4						.6001	.9431
5						.6859	1.0288
6						1.0288	1.0288
7						1.0288	1.1145
8						1.1145	1.2003
9						1.0288	1.2003
10	.7716	.6859	.7716	.8573	.7716		
11	1.0288	.6859	1.0288	.8573	1.1145		
12	1.2003	.7716	.9431	.9431	1.1145		
13	1.2003		.8573	1.0288	.9431		
14	1.1145		.8573	1.0288	.9431		
15	.8573	.4287	.7716	1.0288			
16	.6859	.9431	.8573	1.0288	.9431	.1029	.1715
17	.3429	.9431	1.0288	1.0288	1.0288	.1372	.1715
18		.1715	.2572	.2572		.1715	.1715
19	.3429	.3429	.3429	.3086	.3429	.4287	.4287
20	.4287	.3772	.4287	.3429	.5144	.4801	.4287
21	.3429	.3429	.4287	.4287	.3429	.4458	.4287
22	.2572	.3429	.3429	.3772	.3429	.3772	.4287
23		.3429	.2572	.3429	.2572	.3429	.3429
24	.2572	.2572	.2572	.2572	.2572	.3429	.3429
Max	1.2003	.9431	1.0288	1.0288	1.1145	1.1145	1.2003
Min	.2572	.1715	.2572	.2572	.2572	.1029	.1715
Avg	.6055	.4683	.5782	.6239	.6216	.5477	.6383

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154083 / 33/11 KV ROKADA SAWARGAON

Feeder No / Name : 203 / 11 KV KAJAL HIPPARGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5144	.6859	.5144	.8573	.6001	.6001
2	.6001	.4287	.8573	.4287	.8573	.6001	.6859
3	.6859	.4287	1.3717	.5144	.9945	.7716	.7545
4	.8573	.5144	1.6289	.6859	1.5432		
5	1.0288	.6859	1.8861	.6859	2.0576		
6	1.7147	.8573	2.0576	.6859	2.0576		
7	2.4006		2.1434	2.0576	2.4006		
8	2.6578		2.2291	2.2291	2.4863		
9	2.7435		2.1434	2.2291	2.4006		
10							1.8861
11							2.8292
12						2.2291	3.0864
13						2.572	2.7435
14						2.6578	
15						2.7435	
16	.3429	.2572	.2572	.2572	.2572	2.7435	
17		.3086	.2572	.3429			3.0007
18		.3772	.3429	.4287	.4287		.4287
19	.5144	.3429	.6001	.6001	.7716	.823	.6859
20	.6859	.8573	.6859	.7202	.8573	.8573	.6859
21	.6859	.823	.6859	.7716	.7716	.6859	.7716
22	.5144	.6173	.6859	.6859	.6859	.6001	.6859
23		.6001	.5144	.6001	.6001	.6001	.6859
24	.3429	.5144	.5144	.5144	.5144	.6001	.6001
Max	2.7435	.8573	2.2291	2.2291	2.4863	2.7435	3.0864
Min	.3429	.2572	.2572	.2572	.2572	.6001	.4287
Avg	1.0860	.5418	1.0860	.8307	1.2083	1.3632	1.3420



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154106 / 33/11KV THODAGA

Feeder No / Name : 201 / 11KV Thodga GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4805	.4481		.4854	.4805
2			.4805	.4481		.5228	.4805
3	.6653		.4805	.4854	.5544	.5415	.5175
4			.5175	.5228		.5601	.5914
5			.5914	.5975	.8131	.6516	.7023
6	.8686		.7762	.7842		.8775	.8316
7	.9979		.924	.9335	.9979	1.0269	1.0719
8	.9425		.8501	.8402	.9425	.8962	.6653
9	.7762	.2595			.8686	.7468	.7392
10	.6283	.3075	.6468	.6535	.7023	.5175	.5729
11	.369	.2957	.5228		.4668	.4251	.3075
12	.246	.3881	.3734	.2957	.3734	.3326	.2595
13	.246	.3696			.3547	.3142	
14	.2306	.2957	.3174	.2957	.3361	.2772	.2422
15	.2152	.3142	.2987		.3174	.2187	.2309
16	.2768	.3326	.2987	.3326	.2987	.3696	.2306
17		.3696	.2801		.3734	.3696	.2614
18		.4251	.3734	.4805	.4668	.4435	
19		.6653	.5415		.5601	.6099	.6574
20		.6283	.6908	.7762	.7842	.7392	.692
21		.5914	.5788		.6908	.6653	.6055
22		.5544	.4854	.5544	.5601	.5914	.519
23		.5175	.4481		.5415	.5359	.4671
24	.462		.4805	.4108	.4251	.4668	.4805
Max	.9979	.6653	.924	.9335	.9979	1.0269	1.0719
Min	.2152	.2595	.2801	.2957	.2987	.2187	.2306
Avg	.5326	.4210	.5199	.5537	.5714	.5494	.5276

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154106 / 33/11KV THODAGA

Feeder No / Name : 202 / 11KV MOGHA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1244	.7186	1.1984			
2		1.2109	.7499	1.2955			
3	1.906	1.2801	.7811	1.3279	1.6004		
4		1.1992	.8124	1.3927			
5		1.4185	.8436	1.4575	2.4764		
6	2.2809	1.3837	.8749	1.6194			
7	2.5309	1.599	1.781	1.7004	2.3765		
8	2.4684	1.9894	2.1247	1.9433	2.5926		
9	2.5309	1.845	2.4059	2.1376	2.5149		
10						2.0934	2.4985
11						2.6246	2.7675
12						2.7183	3.0442
13						2.8121	3.0018
14						2.9371	3.0135
15						2.9683	2.3062
16						2.7808	2.7675
17						2.7808	2.8444
24	1.7185	.9225	.6562	1.1336	1.0974		
Max	2.5309	1.9894	2.4059	2.1376	2.5926	2.9683	3.0442
Min	1.7185	.9225	.6562	1.1336	1.0974	2.0934	2.3062
Avg	2.2393	1.3973	1.1748	1.5206	2.1097	2.7144	2.7805

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154106 / 33/11KV THODAGA

Feeder No / Name : 203 / 11KV TEMBHURNI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						1.749	1.8747
2						1.7814	1.9997
3						1.8623	2.0934
4						1.9433	2.1872
5						2.2672	2.3122
6						2.4291	2.4684
7						2.5911	2.5934
8						2.753	
9						2.753	2.3122
10	1.9753		.9374	1.1336	1.2955		
11	2.7675		1.2955		2.4129		
12	2.6137	.9374	1.4575	1.0059	2.834		
13	2.9212	1.1248			2.753		
14	3.1139	1.1248	1.4575	1.829	2.5911		
15	2.46		1.4251		2.753		
16	1.9987	1.0936	1.4899	1.6766	2.915		
17		1.1873	1.5223		2.753		
24						1.7004	1.7497
Max	3.1139	1.1873	1.5223	1.829	2.915	2.753	2.5934
Min	1.9753	.9374	.9374	1.0059	1.2955	1.7004	1.7497
Avg	2.5500	1.0936	1.3693	1.4113	2.5384	2.1830	2.1768

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154114 / 33/11KV URBAN AHMADPUR SUB

ST

Feeder No / Name : 201 / 11KV BUSTAND FEEDER.

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6118	1.576	1.7551		1.6118	1.6476	1.7551
2	1.6834	1.5402	1.7193		1.6118	1.7193	
3	1.7193	1.5402	1.6476		1.6118	1.7551	1.7193
4	1.8099	1.576	1.7551		1.6118	1.8099	1.5775
5	1.9342	1.6118	1.8099		1.7013	1.9547	1.6651
6	1.9909	1.6651	1.9909		1.829	1.9909	1.7193
7	2.0271	1.7375	2.0995		1.9418	2.0633	1.9993
8	2.0271	1.9185	2.0633		1.9547	1.8823	1.9993
9	1.6827	1.7375		1.7375	1.8625		1.9239
10	1.5775	1.6118		1.5947	1.7551		1.7558
11	1.5089	1.5402		1.4746	1.6476		1.4998
12	1.4403	1.4685		1.406	1.6118		1.4685
13	1.4403	1.4327		1.4403	1.576		1.4685
14		1.4327		1.4403	1.576		1.406
15		1.4327		1.4746	1.5402		1.4403
16	1.5402	1.4327		1.5089	1.5043		1.4403
17		1.7909		1.6651			1.5074
18		1.8267		1.8107			1.7737
19		2.2805		1.8861			2.1502
20		2.2443		2.2257	2.1719		2.2634
21		2.0271		2.1879			2.0748
22		1.9547		2.037			.1829
23		1.8823		1.7737			1.8671
24	1.7551	1.6118	1.8099	1.7375	1.6118	1.7551	1.7177
Max	2.0271	2.2805	2.0995	2.2257	2.1719	2.0633	2.2634
Min	1.4403	1.4327	1.6476	1.406	1.5043	1.6476	.1829
Avg	1.7166	1.7030	1.8501	1.7125	1.7073	1.8420	1.6685

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154114 / 33/11KV URBAN AHMADPUR SUB

ST

Feeder No / Name : 202 / 11KV TELEPHONE FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8596	.8238	.9313		.9221	1.0029	.8097
2	.8954	.8238	.8954		.9221	.9671	.7274
3	.9671	.788	.9313		.9221	1.0387	.759
4	1.0136	.8238	.9774		.9221	1.0387	.7011
5	1.0498	.8596	1.0029		.7964	1.0136	.759
6	1.086	.8954	1.0498		1.0288	1.0498	.8192
7	1.1222	.9313	1.086		1.0288	1.0745	.8223
8	1.0498	1.0136	1.0498		1.086	.9671	.9175
9	.905	.8326	.9671	.852	.985		.8223
10	.724	.8596		.8718	.9774		.7907
11	.724	.8954		.8192	.8954		.7316
12	.724	.8596		.8192	.9313		.7011
13	.7529	.8954		.8478	.9671		.6401
14	.7529	.8954		.8192	.9671		.7011
15	.7529	.8954		.8383	.9313		.7316
16	.724	.9313		.8383	.9671		.7316
17		.9313		.8421	1.0029		.8097
18		.9412		.8745	1.0387		.8421
19		1.1584		.9503	1.1222		1.073
20		1.3032		1.0059	1.1946		1.1022
21		1.1946		1.0852			1.1022
22		1.086		.9393			1.0059
23		1.0387		.9503			.9012
24	.8954	.8596	1.0029	.8421	.9221	1.0387	.8097
Max	1.1222	1.3032	1.086	1.0852	1.1946	1.0745	1.1022
Min	.724	.788	.8954	.8192	.7964	.9671	.6401
Avg	.8823	.9390	.9894	.8872	.9776	1.0212	.8255

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154114 / 33/11KV URBAN AHMADPUR SUB

ST

Feeder No / Name : 203 / 11KV EXPRESS FEEDER

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 11 / OUTGOING

UTILITY

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2035	.1341	.1006		.1486	.1006	.1067
2	.1677	.1006	.0671		.1189	.0671	.141
3	.1677	.1006	.1006		.1189	.0671	.1067
4	.2012	.1006	.0671		.0892	.1006	.08
5	.1677	.1006	.0671		.0869	.1006	.08
6	.2012	.1006	.1006		.0724	.1341	.08
7	.1677	.1341	.0671		.0724		.08
8	.2012	.1341	.1006		.1341	.1341	.08
9	.2012	.0671	.1006	.1619	.1341		.1097
10	.0914	.1006		.1619	.1341		.1429
11	.0914	.1006		.1989	.1341		.1738
12	.0914	.1006		.1966	.1677		.1067
13	.0914	.1006		.1966	.1677		.0526
14	.0587	.1341		.1966	.1341		.08
15	.0914	.1006		.1966	.1341		.1067
16	.0914	.0671		.1966	.1006		.1692
17		.1006		.2134	.0671		.1692
18		.1006		.2134	.0671		.1715
19		.1006		.2134	.0671		.1738
20		.1341		.1829	.2035		.1715
21		.0671		.1829			.1715
22				.1829			.1715
23				.1829			.1715
24	.2035	.1341	.0671	.1219	.1486	.1341	.1715
Max	.2035	.1341	.1006	.2134	.2035	.1341	.1738
Min	.0587	.0671	.0671	.1219	.0671	.0671	.0526
Avg	.1465	.1052	.0839	.1875	.1191	.1048	.1278

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON

Feeder No / Name : 201 / 11KV Khandsari SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1219	.1296			.0914		
2	.1219	.1619	.1219	.0343	.0914		
3	.1219	.1619	.1219		.0914		
4	.1219	.1524	.1219	.0343	.0914		
5	.1219	.1524	.1219		.1219		
6	.1219	.1524	.1219	.0686	.1219		
7	.1334	.1524	.1219		.1219		
8	.1524	.1524	.1219	.0686	.1219		
9	.1524	.1524	.1219	.0648	.1219		
10						.1219	
11						.1219	
12						.1219	
13						.1219	.3048
14						.1219	.3048
15						.1219	.3048
16						.1219	.2743
17						.1219	.2439
24	.061	.1296	.1219		.0914		
Max	.1524	.1619	.1219	.0686	.1219	.1219	.3048
Min	.061	.1296	.1219	.0343	.0914	.1219	.2439
Avg	.1231	.1497	.1219	.0541	.1067	.1219	.2865

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON

Feeder No / Name : 202 / 11KV Sugaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9755	1.1336	1.0669		1.3717		.0914
2	1.0974	1.2631	1.1279	1.2346	1.7185		.0914
3	1.2193	1.3279	1.1888		1.7375		.0914
4	1.2803	1.3927	1.3108	1.2346	1.7985	.1029	.0914
5	1.3717	1.3413	1.5546		1.829		.0914
6	1.6766	1.3717	1.768	1.5775	1.8595		.0914
7	1.6537	1.4937	1.7985		1.89		.0914
8	1.4327	1.5546	1.89	2.0576	2.0424	.1029	.0914
9	1.5851	1.5851	1.6766	1.8519	1.9204		.0914
10	.0914	.0972	.0914	.0972	.0972	1.5242	1.2803
11	.0972	.0914	.0914	.1029	.0914	2.0729	
12	.0983	.0914	.0914	.1006	.0914	2.0729	
13	.0972	.0914	.0914	.1006	.0914	2.1033	2.332
14	.0972	.0914		.1006	.0914	2.1338	2.0729
15	.0972	.0914	.1029	.1006	.0914	2.0729	2.1338
16	.0983	.0914	.0914	.0972	.0914	2.0424	2.1338
17	.1029	.0914		.1006	.0914	2.0119	2.1643
18	.1029	.0914	.0914	.1029	.0914	.0914	.0914
19	.1006	.0914		.1029		.0914	
20	.1006	.0914		.1006		.0914	.1029
21	.1006	.0914		.1006		.0914	
22	.1006	.0914		.1006		.0914	
23	.1006	.0914		.1006		.0914	
24	.7621	.9831	.945	1.0288	1.2193	.1029	.0914
Max	1.6766	1.5851	1.89	2.0576	2.0424	2.1338	2.332
Min	.0914	.0914	.0914	.0972	.0914	.0914	.0914
Avg	.6017	.6138	.8811	.5197	.9587	.9936	.7347



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON

Feeder No / Name : 203 / 11KV Chakur SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0972	.0914		.0972		.5792
2	.0914	.0972	.0914	.1029	.0972		.6097
3	.0914	.0972	.0914		.0972		.7316
4	.0914	.0983	.0914	.1029	.0972	.823	.7621
5	.0914	.0983	.0914		.0972		1.0974
6	.0914	.0972	.0914	.1029	.0914		1.0669
7	.0914	.0972	.0914		.0937		1.1203
8	.0914	.0972	.0914	.1029	.0972	1.0974	1.0669
9	.0914	.0983	.0914	.1029	.0972		1.2498
10	.7621	.6097	.7926	.6478	.4858	.0914	.0914
11	1.0669		1.0669	1.1336	1.0364	.0914	
12	.945	1.1279	1.2193	.7926	1.2193	.0914	
13	.9145	1.0669	1.1888	.884	1.0669	.0914	.0914
14	.884	1.0364		.9145	1.0669	.0914	.0914
15	.884	1.0059	1.1279	.9145	1.1279	.0914	.0914
16	.884	.9755	1.1888	.9145		.0914	.0914
17	.8745	1.0974		1.1279	1.2193	.0914	.0914
18	.1029	.0914	.0914	.1029	.0914	.0914	
19	.1006	.0914		.1006		.0914	
20	.1006	.0914		.1006		.0914	.1029
21	.1017	.0914		.1006		.0914	
22	.1006	.0914		.1006		.0914	
23	.1006	.0914		.1006		.0914	
24	.0914		.0914	.1029	.0972	.5487	.5487
Max	1.0669	1.1279	1.2193	1.1336	1.2193	1.0974	1.2498
Min	.0914	.0914	.0914	.1006	.0914	.0914	.0914
Avg	.364	.3794	.4465	.4276	.4598	.2205	.5579

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON

Feeder No / Name : 204 / 11KV Lohara SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.1006	.0914		.0972		.4572
2	.0914	.1006	.0914	.1029	.0972		.5182
3	.0914	.1006	.0914		.0972		.5487
4	.0914	.0972	.0914	.1029	.0983	.6859	.6401
5	.0914	.0972	.0914		.0972		.8535
6	.0914	.0972	.0914	.1029	.0972		.8002
7	.0914	.1006	.0914		.0972		.8802
8	.0914	.1457	.0914	.1029	.0937	1.0288	.9755
9	.0914	.0983	.0914	.0914	.0914		.9755
10	.6706	.6478	.6401	.6478	.6478	.0914	.0914
11	.7316		.9145	.7926	.8535	.0914	
12	.9755	1.0364	1.1279	.9145	1.0059	.0914	
13	.9145	1.1279	.3963	.9755	1.0364	.0914	.0914
14	.884	1.0974		.945	.9755	.0914	.0914
15	.7926	1.0669	.9755	.9755	.9145	.0914	.0914
16	.7926	1.0364	1.0364	.9145	.9145	.0914	.0914
17	.8097	1.0669		9.8308	.9755	.0914	.0914
18	.1029	.0914	.0914	.1029	.0914	.0914	.0914
19	.1029	.0914		.1006		.0914	
20	.1006	.0914		.1006		.0914	.1029
21	.1006	.0914		.1006		.0914	
22	.0972	.0914		.1006		.0914	
23	.1006	.0914		.0972		.0914	
24	.0914	.1006	.0914	.1029	.0983	.5144	.4268
Max	.9755	1.1279	1.1279	9.8308	1.0364	1.0288	.9755
Min	.0914	.0914	.0914	.0914	.0914	.0914	.0914
Avg	.3371	.3768	.3586	.8602	.4410	.2064	.4344

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON

Feeder No / Name : 205 / 11KV Nalegaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.6154	.4572		.4858		.4572
2	.4572	.4858	.4877	.5487	.4858		.4268
3	.4877	.4534	.5182		.4268		.4572
4	.5487	.4534	.5487	.5487	.4268	.5487	.5182
5	.6097	.4572	.6097		.5182		.6097
6	.6401	.5487	.6401	.6859	.6401		.6135
7	.7011	.5792	.7011		.7011		.6706
8	.5487		.6706	.7545	.7316	.7545	.5868
9		.4858					.5487
10						.4877	.4572
11	.4588	.4877	.4572	.6478		.4572	
12	.4858	.4572	.5487	.583	.6097	.4572	
13	.4268	.4268	.5182	.583	.6097	.4877	.4877
14	.4268	.4572		.5506	.5792	.4268	.5182
15	.4268	.4268			.5487	.3963	.5182
16						.4268	.4877
17						.4268	.4877
18				.3887		.5182	.3658
19	.8048	.7621		.8097		.6706	
20	.6706	.823		.7712		.7621	.823
21	.6859	.7316		.6478		.6706	
22	.4915	.6097		.6154		.6097	
23	.6226	.4877		.583		.5182	
24	.4572	.583	.4572	.5487	.5182	.5487	.4572
Max	.8048	.823	.7011	.8097	.7316	.7621	.823
Min	.4268	.4268	.4572	.3887	.4268	.3963	.3658
Avg	.5478	.5438	.5512	.6178	.5601	.5393	.5273

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON

Feeder No / Name : 206 / 11KV Atola SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.8745	.7621		1.0364		.0914
2	.945	.884	.7926	1.2003	1.4022		.0914
3	.9755	.9686	.8535		1.5242		.0914
4	1.0669	1.0059	.9755	1.2003	1.5851	.1029	.0914
5	1.2803	1.1888	1.2498		1.6766		.0914
6	1.4632	1.6842	1.6766	1.5775	1.829		.0914
7	1.5851	1.5851	1.7071		1.89		.0914
8	1.5242	1.6156	1.7375	2.0576	1.89	.0914	.0914
9	1.2803	1.4632	1.5546	1.7147	1.1279	.1029	.0914
10	.0914	.0983	.0914	.0914	.0972	.5487	.8535
11	.1006	.0914	.0914	.1029	.0914	.6097	1.5546
12	.0972		.0914	.1029	.0914	.6706	1.4632
13	.0972	.0914	.0914	.1006		1.0974	1.6461
14	.0972	.0914		.1006	.0914	1.5546	1.4327
15	.0972	.0914	.0914	.1006		1.5242	1.4327
16	.1029	.0914		.0972		1.4937	1.4327
17	.0972	.0914		.0972	.0914	1.5851	1.8595
18	.1029	.0914		.1029	.0914	.0914	.0914
19	.1006	.0914		.1006		.0914	
20	.0972	.0914		.1006		.0914	.1029
21	.1017	.0914		.1006		.0914	
22	.1006	.0914		.1006		.0914	
23	.1006	.0914		.0983		.0914	
24	.7926	.6478	.6706	1.0288	.7621	.1029	.0914
Max	1.5851	1.6842	1.7375	2.0576	1.89	1.5851	1.8595
Min	.0914	.0914	.0914	.0914	.0914	.0914	.0914
Avg	.5505	.5701	.8291	.5088	.9549	.5574	.6392

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON

Feeder No / Name : 207 / 11 KV GILDA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305	.0229	.0305		.0229		.0305
2	.0305	.0229	.0305	.0343	.0229		.0305
3	.0305	.0229	.0305		.0229		.0305
4	.0305	.0229	.0305	.0343	.0229	.0343	.0305
5	.0305	.0229	.0305		.0229		.0305
6	.0305	.0229	.0305	.0343	.0229		.0305
7	.0305	.0229	.0305		.0229		
8	.0305	.0229	.0305	.0343	.0229	.0343	
9		.0229	.0305	.0343	.0229		
10		.0267	.0305	.0229	.0229	.0305	
11			.0305	.0229	.0305	.0305	
12	.0229	.0305	.0305		.0305	.0305	
13	.0229	.0305	.0305		.0914	.0305	
14	.0229	.061			.0305	.0305	
15	.0229	.061	.0343	.0229	.0914	.0305	
16	.0267	.061	.0305	.0229	.0305	.0305	
17	.0259	.061	.0343	.0259	.0305	.0305	
18	.0259	.061	.0305	.0251	.0305	.0305	
19	.0229	.061		.0229		.0305	
20	.0229	.061		.0229		.0305	
21	.0229	.0305		.0259		.0305	
22	.0251	.0305		.0229		.0305	
23	.0267	.0305		.0229		.0305	
24	.0305	.0259	.0305	.0343	.0229	.0343	.0305
Max	.0305	.061	.0343	.0343	.0914	.0343	.0305
Min	.0229	.0229	.0305	.0229	.0229	.0305	.0305
Avg	.0269	.0364	.0309	.0274	.0325	.0312	.0305

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154011 / 33KV ZARI S/N

Feeder No / Name : 201 / 11KV Chapoli

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		1.2003		1.4575		
16	.1715		.1715	.1715		1.2003
24		.1715			.2572	
Max	.1715	1.2003	.1715	1.4575	.2572	1.2003
Min	.1715	.1715	.1715	.1715	.2572	1.2003
Avg	.1715	.6859	.1715	.8145	.2572	1.2003

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154011 / 33KV ZARI S/N

Feeder No / Name : 202 / 11KV Jadhala

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.9431		1.0288	1.1145	
16	.7716		1.0288	1.0288		2.2291
24		.6859			.8573	
Max	.7716	.9431	1.0288	1.0288	1.1145	2.2291
Min	.7716	.6859	1.0288	1.0288	.8573	2.2291
Avg	.7716	.8145	1.0288	1.0288	.9859	2.2291

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154011 / 33KV ZARI S/N

Feeder No / Name : 203 / 11 KV MAHALANGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8					2.2291	
16	1.8861		1.9719	2.4006		.1715
24		.4287			1.2003	
Max	1.8861	.4287	1.9719	2.4006	2.2291	.1715
Min	1.8861	.4287	1.9719	2.4006	1.2003	.1715
Avg	1.8861	.4287	1.9719	2.4006	1.7147	.1715



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154019 / 33/11 KV CHAKUR S/S

Feeder No / Name : 201 / 11KV Chakur

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		1.5242	1.7147			1.7113
9					1.5211	
12	1.3336	1.3336				
16	1.1431			1.3336		
17	1.3336					
24			.9526		1.1408	
Max	1.3336	1.5242	1.7147	1.3336	1.5211	1.7113
Min	1.1431	1.3336	.9526	1.3336	1.1408	1.7113
Avg	1.2701	1.4289	1.3337	1.3336	1.3310	1.7113

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154019 / 33/11 KV CHAKUR S/S

Feeder No / Name : 204 / 11KV Tivghal SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		3.6199	2.9721			2.6619
9					.1901	
16				.381		
17	2.6673					
24			1.6289	2.1434	2.6619	
Max	2.6673	3.6199	2.9721	2.1434	2.6619	2.6619
Min	2.6673	3.6199	1.6289	.381	.1901	2.6619
Avg	2.6673	3.6199	2.3005	1.2622	1.426	2.6619

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154019 / 33/11 KV CHAKUR S/S

Feeder No / Name : 205 / 11KV Bothi Express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.0814			.0951
9				.0953		
12	.0953	.0953				
15						.0762
16	.0953	.0953		.0953		
17	.0953					
24			.0762		.0951	
Max	.0953	.0953	.0814	.0953	.0951	.0951
Min	.0953	.0953	.0762	.0953	.0951	.0762
Avg	.0953	.0953	.0788	.0953	.0951	.0857

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154038 / 33/11 KV WADWAL

Feeder No / Name : 201 / 11KV Wadwal

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5684	.5684	.6028				
2	.5684	.5511	.6028				
3	.6028		.5856				
4	.62		.62				
5	.6373	.6717	.6717				
6	.8095		.8267				
7	.93	.9473	.9128				
8	.9989	.7578	.9817				
9	.9128	.9817	.7578	.9817	1.2917		.6583
10	.9817	.6028	.7578	1.0334	1.2401		.5064
11	1.0506	1.0334	.8784	1.1023	1.2228		.4051
12	1.085	1.0334	1.0506	1.1539			.4051
13	1.1884	.9645	1.1712	1.2573			.422
14	1.2056	1.085	1.2056	1.1884			.422
15	1.2228	1.2056	1.2056				.4389
16	.3961	.3961	.4306	.465			.9284
17			.4478				1.4179
18			.4995				1.4517
19			.7406				1.1816
20			.8612				1.1478
21			.8095			.9959	1.0297
22			.7234			.979	.9115
23			.6717			.9959	.7427
24							.5908
Max	1.2228	1.2056	1.2056	1.2573	1.2917	.9959	1.4517
Min	.3961	.3961	.4306	.465	1.2228	.979	.4051
Avg	.8611	.8307	.7833	1.026	1.2515	.9903	.7912

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154038 / 33/11 KV WADWAL

Feeder No / Name : 202 / 11KV Janwal

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0133	.829	.9027			
2	1.1054	.8843	.9212			
3	1.1422		.958			
4	1.1975		1.0133			
5	1.3265	.9949	1.1607			
6	1.4923		1.566			
7	2.0266	1.7134	1.8792			
8	.7185	.7185	.6817			
9	.6448	.5895	.7369	.5159	.5895	
10	.3869	.3132	.4974	.2579	.4606	
11	.3132	.2948	.2948	.2211	.3316	
12	.0921	.2763	.3132	.2948	.3132	
13	.0921	.2763	.129	.2763	.2763	
14	.0921	.2948	.3132	.2763	.3132	
15	.3132	.2763	.2948		1.2896	
16	.3132	.2763	.2027	1.0133	1.3817	
17			.2763		.2579	
18			.2579		.3685	
19			.5343		.6264	
20			.6817			
21			.608			.6155
22			.479			.5596
23						.5144
Max	2.0266	1.7134	1.8792	1.0133	1.3817	.6155
Min	.0921	.2763	.129	.2211	.2579	.5144
Avg	.7669	.5952	.6683	.4079	.5644	.5632

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154038 / 33/11 KV WADWAL

Feeder No / Name : 203 / 11KV Gharola

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.1905				
5	.2096				
6	.2286				
7	.2286				
8	.2477				
9	.1905	.1524	.2096		.1905
10	.1334	.0953	.1905	.0762	.1334
11	.0953	.0762	.1143		.0572
12	.1143	.0953	.0762		.0572
13	.0953	.0953	.0953		.0762
14	.0953	.0762	.0953		.0762
15	.0953		.0953		.1143
16	1.1812	.9145	1.3717	.0762	.0762
17	1.6004		1.8671	.0762	.0953
18	1.2574		1.829	.0953	.0762
19	1.3336		1.3717	.1524	.1715
20	1.2193		1.2765	.2286	.2096
21	1.1622		1.2384	.1715	.2096
22	1.1622		.6097	.1715	.1905
23	1.1622			.1524	.1524
24				.7621	.6097
Max	1.6004	.9145	1.8671	.7621	.6097
Min	.0953	.0762	.0762	.0762	.0572
Avg	.6001	.2150	.7458	.1962	.156

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154048 / 33/11kv chapoli

Feeder No / Name : 201 / 11KV Chapoli

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8						1.5775	1.6766
16	1.0517	1.4022		1.2003	1.2269	.4915	
24	.5258		.5258		.503	.7011	.6554
Max	1.0517	1.4022	.5258	1.2003	1.2269	1.5775	1.6766
Min	.5258	1.4022	.5258	1.2003	.503	.4915	.6554
Avg	.7888	1.4022	.5258	1.2003	.8650	.9234	1.166

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154048 / 33/11kv chapoli

Feeder No / Name : 202 / 11KV Ajansonda

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8						2.0348	2.1434
16	1.3565	1.6956		1.8442	1.7804	.3429	
24	.5144		.5087		.5144	.6783	.8573
Max	1.3565	1.6956	.5087	1.8442	1.7804	2.0348	2.1434
Min	.5144	1.6956	.5087	1.8442	.5144	.3429	.8573
Avg	.9355	1.6956	.5087	1.8442	1.1474	1.0187	1.5004



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154048 / 33/11kv chapoli

Feeder No / Name : 203 / 11KV Naigaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.7404	1.4918	1.7404		1.6575		
16	.2486	.2486		.2458	.2515	1.5089	
24	.663		.6706		.663	.4191	.4973
Max	1.7404	1.4918	1.7404	.2458	1.6575	1.5089	.4973
Min	.2486	.2486	.6706	.2458	.2515	.4191	.4973
Avg	.884	.8702	1.2055	.2458	.8573	.964	.4973

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154048 / 33/11kv chapoli

Feeder No / Name : 204 / 11KV BSF

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.04	.04	.04		.04	.04	.04
9						.04	
16	.04	.0429		.0429	.0391		
24	.04		.04		.04	.04	.0429
Max	.04	.0429	.04	.0429	.04	.04	.0429
Min	.04	.04	.04	.0429	.0391	.04	.04
Avg	.04	.0415	.04	.0429	.0397	.04	.0415

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154080 / 33/11 KV SHIVANKHED

Feeder No / Name : 201 / 11KV Ganjur SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.6001	.6001	.8573	.6859	.181	.1715
2	.8573	.6859	.6859	.8573	.6859	.181	.1715
3	.8573	.7716	.6859	.8573	.8573	.181	.1715
4	.8573	.7716	.7716	.9431	.8573	.181	.1715
5	1.0288	.8573	.8573	1.0288	.9431	.362	.2572
6	1.1145	.7716	.9431	1.0288	1.0288	.362	.2572
7	1.2003	.7716	1.0288	1.0288	1.286	.2715	.2572
8	1.2003	.8573	1.2003	1.2003	1.286	.2715	.2572
9	.8573	.9431	1.1145	1.2003	1.1145	.2715	.1715
10	.1715	.1715	.2572	.1715	.1715		.8573
11	.181	.1715	.1715	.1715	.181		1.0288
12	.181	.1715	.1715	.1715	.181	.5144	1.2003
13	.181	.1715	.1715	.1715	.181	.6859	1.2003
14	.181	.1715	.1715	.1715	.181	.8573	1.2003
15	.181	.1715	.1715	.1715	.181	1.0288	1.2003
16	.181	.1715	.1715	.1715	.181	1.3717	1.2003
17	.181	.1715	.1715	.1715	.181	1.286	1.2003
18	.181	.1715	.1715	.1715	.181	.1715	.1715
19	.2715	.2572	.2572	.1715	.181	.2572	.1715
20	.2715	.3429	.2572	.1715	.2715	.2572	.1715
21	.2715	.2572	.1715	.1715	.2715	.1715	.1715
22	.181	.2572	.1715	.1715	.2715	.1715	.1715
23	.181	.1715	.1715	.1715	.181	.1715	.1715
24	.8573	.543	.6001	.6001	.6859	.181	.1715
Max	1.2003	.9431	1.2003	1.2003	1.286	1.3717	1.2003
Min	.1715	.1715	.1715	.1715	.1715	.1715	.1715
Avg	.5202	.4334	.4644	.5001	.5094	.4267	.5073

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154080 / 33/11 KV SHIVANKHED

Feeder No / Name : 202 / 11KV Shivankhed SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.6001	.6001	.6859	.7716	.2715	.3429
2	.8573	.6859	.6001	.6859	.8573	.2715	.3429
3	.8573	.6859	.6859	.8573	.8573	.362	.3429
4	.8573	.6859	.6859	.8573	.9431	.543	.3429
5	.8573	.7716	.7716	.8573	.9431	.6335	.3429
6	.9431	.8573	.8573	1.0288	1.0288	.6335	.5144
7	1.2003	.8573	1.0288	1.286	1.3717	.543	.6859
8	.6859	.9431	1.286	1.3717	1.286	.543	.6859
9	.8573	.8573	.3429	1.286	1.2003	.543	.5144
10	.3429	.3429	.4287	.3429	.3429		.9431
11		.2572	.2572		.2715	1.0288	1.1145
12		.2572	.2572		.2715	1.1145	1.0288
13		.1715	.2572	.3429	.181		1.0288
14			.2572	.3429	.181	1.0288	1.0288
15			.2572	.3429	.181	.8573	.9431
16	.181		.2572	.3429	.181	1.0288	1.0288
17	.181		.2572	.3429	.2715	1.0288	1.2003
18	.2715		.2572	.3429		.2572	.3429
19	.6335	.5144	.5144	.4287		.5144	.4287
20	.543	.6859	.5144	.5144	.543	.5144	.5144
21	.543	.5144	.4287	.5144	.6335	.4287	.4287
22	.4525	.4287	.3429	.4287	.6335	.3429	.4287
23	.4525	.3429	.3429	.4287	.4525	.3429	.4287
24	.8573	.543	.5144	.5144	.6859	.362	.3429
Max	1.2003	.9431	1.286	1.3717	1.3717	1.1145	1.2003
Min	.181	.1715	.2572	.3429	.181	.2572	.3429
Avg	.6543	.5791	.5001	.6430	.6404	.5997	.6394

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154080 / 33/11 KV SHIVANKHED

Feeder No / Name : 203 / 11KV Dhaveli SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.181	.1715	.1715	.1715	.8573	1.0288
2	.3429	.181	.1715	.1715	.1715	1.0288	1.2003
3	.3429	.181	.1715	.1715	.1715	1.1145	1.286
4	.3429	.181	.1715	.1715	.1715	1.1145	1.3717
5	.3429	.181	.1715	.1715	.2572	1.1145	1.5432
6	.3429	.181	.1715	.1715	.2572	1.3717	1.7147
7	.3429	.181	.2572	.2572	.2572	1.6289	1.9719
8	.1715	.181	.2572	.2572	.2572	1.8004	2.1434
9	.1715	.181	.2572	.1715	.1715	1.9719	2.0576
10	.8573		1.1145	1.2003	.6859		.1715
11	1.5432		1.8861	1.7147	1.6289	.0857	.1715
12	1.6289		1.7147	1.8861	1.7147	.0857	.1715
13	1.7147		1.8004	2.0576	1.7147	.0857	.1715
14	.9431	1.0288	1.7147	2.0576	1.8861	.0857	.1715
15	1.8861	1.8004	1.8004	2.0576	1.8861	.0857	.1715
16	1.4575	1.9719	1.8004	2.1434	1.7147	.0857	.1715
17	1.6289	.6001	1.8861	2.1434	1.8004	.0857	.1715
18	.181	1.6289	.1715	.1715	.181	.1715	.1715
19		1.286	.1715	.1715	.181	.1715	.1715
20	.181	1.286	.1715	.1715	.181	.1715	.1715
21	.181	.2572	.1715	.1715	.181	.1715	.1715
22	.181	.1715	.1715	.1715	.181	.1715	.1715
23	.181	.1715	.1715	.1715	.181	.1715	.1715
24	.2572	.181	.1715	.1715	.1715	.905	.8573
Max	1.8861	1.9719	1.8861	2.1434	1.8861	1.9719	2.1434
Min	.1715	.1715	.1715	.1715	.1715	.0857	.1715
Avg	.6767	.6006	.6966	.7573	.6740	.6320	.7323

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154090 / 33 KV SUBSTATION SUGAON

Feeder No / Name : 201 / 11KV Sugaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5868		.6706		.8509	.5487	
2	.6161		.7926		.9095	.5487	
3		.7042	.8535	.9389	.9682	.6097	
4			.9389		1.0269	.6097	
5			.9755		1.1003	.6097	
6		.7628	1.0364	1.1736	1.1736	.6706	
7			1.0364		1.2029	.6706	
8		.8802	.8802	1.1736	1.2616	.6097	
9		.8802				.6097	
10		.1829		.2641	.3521	.7621	.7628
11		.2439		.2347		.945	.8802
12		.2439	.2347	.2347	.2347	1.0669	.9976
13		.3048		.176		1.0974	.9976
14		.3048		.176		1.1584	.8802
15		.3658		.176	.2934	1.1888	.8802
16		.2134	.2934		.2347	1.2498	.8802
17		.2134	.2934	.2934	.2347	1.3108	.9389
18		.2743	.2347	.3814	.2347	.2439	.2934
19				.4108		.3658	.3521
20		.4268	.4694	.5281		.4268	.5868
21		.4877		.5575	.5281	.4877	
22		.4877		.4988		.5487	
23	.3521	.5487	.4108		.4694	.5487	.4108
24	.5281	.6097	.5868	.4988	.5281	.6097	
Max	.6161	.8802	1.0364	1.1736	1.2616	1.3108	.9976
Min	.3521	.1829	.2347	.176	.2347	.2439	.2934
Avg	.5208	.4520	.6472	.4823	.6826	.7291	.7384

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154090 / 33 KV SUBSTATION SUGAON

Feeder No / Name : 202 / 11KV Devangra SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0587		.061		.088	.0152	
2	.088	.044	.0914		.088	.0152	
3			.0914	.088	.1174	.0152	
4			.1174		.1174	.0152	
5	.1174	.0587	.1219		.1467	.0152	
6			.1219	.1467	.1467	.0152	
7	.1467		.1219		.176	.0305	
8		.132	.1174	.1467	.176	.0305	
9		.1467		.1467	.176	.0305	
10		.0152				.0914	.9242
11				.0147		.0914	.088
12		.0152	.0147	.0147	.0147	.1219	.1174
13		.0152		.0147		.1219	
14		.0152			.0147	.1219	.1174
15		.0152		.0147		.1524	.1467
16		.0152	.0147		.0147	.1524	.1467
17		.0152		.0147		.1524	.1174
18		.0305	.0147	.0147	.0147	.0152	.0147
19				.0147		.0152	.0147
20	.0147	.0152	.0147	.0147		.0152	
21		.0152		.0147	.0147	.0152	
22		.0152		.0147		.0152	
23	.0147	.0152	.0147		.0147	.0152	.0147
24	.0587	.061	.0587	.0147	.0587	.0152	
Max	.1467	.1467	.1219	.1467	.176	.1524	.9242
Min	.0147	.0152	.0147	.0147	.0147	.0152	.0147
Avg	.0713	.0377	.0698	.0460	.0862	.0540	.1702

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154090 / 33 KV SUBSTATION SUGAON

Feeder No / Name : 203 / 11KV Ashta SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1524		.2347		
2	.2641	.2347	.2134		.2641		
3	.2934		.2743	.2934	.3227		
4			.2743		.3521		
5		.2934	.3658		.3814		
6	.3521		.3963	.4108	.4401		
7	.4401		.3963		.4694		
8		.3521	.3658	.4694	.4401		
9		.3521	.3521		.4401		
10						.2743	.176
11						2.8654	.2934
12						.3658	.4108
13						.4877	.4401
14						.4877	.4401
15							.4401
16						.4877	.4401
17						.4877	.4401
20	.0734						
23	.0734						
24	.1467	.1524	.1467	.176	.1467		
Max	.4401	.3521	.3963	.4694	.4694	2.8654	.4401
Min	.0734	.1524	.1467	.176	.1467	.2743	.176
Avg	.2347	.2769	.2937	.3374	.3491	.7795	.3851



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154097 / 33 KV ASHTA S/S

Feeder No / Name : 201 / 11KV Mahalangra SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	16-MAR-17	17-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3429		.1524	
2		.4763		.1524	
3		.6097		.2286	
4		.6478		.2858	
5		.724		.3429	
6		.8383		.4191	
7		.8954		.4572	
8	.8764	1.1241		.362	
9	.8383	1.086	1.086	.3048	
10	.1524		.2286		.5525
11	.1143		.1524		.724
12	.1143		.1334		.9335
13	.1143		.1524		1.0669
14	.1143				.8192
15	.0762		.1524		.7811
16	.1143		.1524		.9145
17	.1524		.1334		1.0288
18	.1524		.1715		.1524
19	.1905		.2286		.1905
20	.2858		.3239		.2477
21	.362		.381		.3239
22	.3048		.3048		.2858
23	.2477		.2096		.2858
24		.2667		.1905	
Max	.8764	1.1241	1.086	.4572	1.0669
Min	.0762	.2667	.1334	.1524	.1524
Avg	.2632	.7011	.2722	.2896	.5933

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154097 / 33 KV ASHTA S/S

Feeder No / Name : 202 / 11KV Ganjur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	16-MAR-17	17-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6859		.1524	
2				.1524	
3		.8383		.1905	
4		.9145		.1905	
5		1.0288		.1905	
6		1.105		.2286	
7		1.1812		.2286	
8		1.2955		.2286	
9		.9145	1.2003	.2286	
10	.1905		.1905		.8192
11	.1905		.1524		1.105
12	.1905		.1524		1.1812
13	.1715		.1524		1.1812
14	.1524		.1524		1.2193
15	.1524		.1524		1.2384
16	.1524		.1905		1.2193
17	.1524		.1524		1.2003
18	.1524		.1143		.1524
19	.1905		.1905		.1905
20	.2286		.2667		.2286
21	.2286		.3048		.2286
22	.1905		.2286		
23	.1524		.1524		.1905
24		.5906		.1524	
Max	.2286	1.2955	1.2003	.2286	1.2384
Min	.1524	.5906	.1143	.1524	.1524
Avg	.1783	.9505	.2502	.1943	.7811

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154097 / 33 KV ASHTA S/S

Feeder No / Name : 203 / 11KV Ashta SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	16-MAR-17	17-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3048		.6859	
2		.3048		.8002	
3		.3429		.9526	
4		.4191		1.105	
5		.4572		1.3717	
6				1.6956	
7				1.7909	
9				1.448	1.8671
10			1.1241		.3048
11	.9907		1.4861		.2286
12	1.448		1.7147		
13	1.467		1.6385		.2477
14	1.4861		1.5242		.2286
15	1.467		1.5242		
16	1.4861		1.5242		.1905
17	1.5242		1.6004		.1715
18	.1905		.1524		.1905
19	.2286		.381		.381
20	.4191		.4191		.4572
21	.4954		.4572		.4763
22	.4191		.4001		.4382
23	.3429		.3429		.4001
24		.362		.5335	
Max	1.5242	.4572	1.7147	1.7909	1.8671
Min	.1905	.3048	.1524	.5335	.1715
Avg	.9204	.3651	1.0207	1.1537	.4294

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822] BU 4822

Substation No/ Name :- 154010 / 33/11 DEVANI

Feeder No / Name : 201 / 11KV TOGARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7042	.7316		.7712	.7316	
2		.7377	.8048		.7712	.8048	
3		.8048	.8779		.8048	.8779	
10	.3391	.6443		.4115	.6443	.407	.7377
11	.6104	.6104	.583	.7042	.5426	.6443	.7377
12	.5765	.5426		.6443	.5087	.8048	.7042
13	.5765	.5426	.7202	.6443	.6104	.8048	.7042
14	.6104	.5426	.4572	.5426	.5426	.7042	.6443
15	.6104	.5426		.6104		.6443	.6443
16	.5426	.6104		.6443	.373	.6783	.6443
17	.5087	.5426		.6104	.373		.5087
18	.6783	.7316		.9054	.7682		.6706
19	1.073	1.2437		1.1736	1.1706		.9724
20	1.0395	1.3169		1.1736	1.2803		1.0395
21	.9389	1.2437		.9724			1.073
22	.8048	1.0242		.8718			1.0059
23	.7042	.9511		.7712			.8048
24		.6443	.8048	.5144	.7377		.6706
Max	1.073	1.3169	.8779	1.1736	1.2803	.8779	1.073
Min	.3391	.5426	.4572	.4115	.373	.407	.5087
Avg	.6867	.7767	.7114	.7463	.7070	.7102	.7708

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822] BU 4822

Substation No/ Name :- 154010 / 33/11 DEVANI

Feeder No / Name : 202 / 11KV LASONA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9724	1.153		1.2742	.8048	
2		1.0059	1.2209		1.3748	.8779	
3		1.0059	1.2887		1.4754	1.0242	
4		1.0227	1.3565		1.5257		
5		1.2071			1.6766		
6		1.3916			1.8778		
7		1.5089			2.4863		
8		1.9281			2.7526		2.9492
9		2.0553		2.8807	2.7854		3.2442
10						2.2043	
12						.3429	
13						.4409	
14						.4239	
15						.4239	
16	.5087	.3666		.2883	.4755	.4409	.4409
17	.6274	.439		.3391	.5121		.4748
18	.7042	.5487		.407	.4755		.5087
19	1.1401	1.3169		.5596	.9145		.9724
20	1.1401	1.2437		1.1065	1.3169		1.1065
21	1.0395	1.1706		1.1065			1.0517
22	.8551	.9511		.9556			.9724
23	.7377	.8779		.8048			2.2708
24		.9389	1.0852	.5144	1.1736		
Max	1.1401	2.0553	1.3565	2.8807	2.7854	2.2043	3.2442
Min	.5087	.3666	1.0852	.2883	.4755	.3429	.4409
Avg	.8441	1.1084	1.2209	.8963	1.4731	.7760	1.3992

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822] BU 4822

Substation No/ Name :- 154010 / 33/11 DEVANI

Feeder No / Name : 203 / 11KV WALANDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7042	.7316		.7042	.3391	
2		.7712	.8779		.8048	.407	
3		.8383	.9511		.9054	.4748	
4						.5426	
5						.8139	
6						.4748	
8						.7122	1.0395
9						.8139	1.0059
10	.3052	.4748		.583	.6104		
11	.6104	.6104	.5487	.6783	.7122		
12	.5765	.6443		.7042	.78		
13	.5765	.7122	.6173	.7377	.7461		
14	.5426	.6783	.583	.6706	.6783		
15	.5087	.6783		.6104	.5426		
16	.407	.6783		.6104	.7461	.2035	
17	.4409	.6783		.6783	.7461		.373
18	.7377	.4755		.3391	.439		.3391
19	.8718	.8779		.6443	.8048		.6706
20	.8383	.9877		.8718	.8779		.7377
21	.8383	.9511		.8718			.8048
22	.6783	.8413		.7042			.6443
23	.6104	.8048		.6443			.5426
24		.6443	.7316	.3429	.6104		
Max	.8718	.9877	.9511	.8718	.9054	.8139	1.0395
Min	.3052	.4748	.5487	.3391	.439	.2035	.3391
Avg	.6102	.7251	.7202	.6461	.7139	.5313	.6842

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822] BU 4822

Substation No/ Name :- 154010 / 33/11 DEVANI

Feeder No / Name : 205 / 11KV BORUL SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.407	.6104		.7042	.5121	
2		.4409	.8139		.7377	.5853	
3		.4748	.8817		.7712	.6584	
4		.4748	1.0174		.7712		
5		.5765			.9389		
6		.6104	1.0852		1.073		
7		1.073	1.2209		1.4754		
8		1.1736	1.4243		1.6095		
9		1.3077	1.4243	1.5089	1.6095		
10	.5765					1.1191	.373
11	.9389					.6443	1.5424
12	.8718						1.5424
13						1.073	1.4083
14						1.1401	1.3748
15						1.3413	1.4083
16	.2374	.2561		.3052	.2926	1.3077	1.4083
17	.2713	.2743		.3052	.3292		1.3413
18	.407	.2926		.2713	.3292		.2374
19	.6443	.6584		.373	.5121		.4409
20	.6783	.7682		.5765	.8048		.5765
21	.5426	.7316		.5426			.6783
22	.4409	.6584		.4409			.5087
23	.6104	.5121		.407			.4748
24		.407	.5426	.3429	.6783		
Max	.9389	1.3077	1.4243	1.5089	1.6095	1.3413	1.5424
Min	.2374	.2561	.5426	.2713	.2926	.5121	.2374
Avg	.5654	.6165	1.0023	.5074	.8425	.9313	.9511

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822] BU 4822

Substation No/ Name :- 154010 / 33/11 DEVANI

Feeder No / Name : 206 / AMBEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4409	.5121		.5087	.6104	
2		.5087	.5853		.5426	.6783	
3		.5426	.6584		.5765	.7461	
4						.8139	
5						1.2209	
6						1.3904	
8						1.5939	
9						1.5939	
10	.3391	.5426		.5144	.8383		.7042
11	.5426	.8139	.5144	.8886	1.1869		
12	.6783	.5426		1.073	1.3904		
13	.7042	.8478	.5487	1.073	1.3565		
14	.788	.8478	.6173	1.1736	1.3565		
15	.9054	.8139		1.2071	1.0174		
16	.8383	.8817		1.1904	1.2887	.2374	.3222
17	.6783	.8478		1.2239	1.3565		.3052
18	.4409	.3658		.2713	.3292		.3052
19	.6613	.6584		.4917	.4755		.4578
20	.407	.7316		.6613	.7316		.5087
21	.4917	.6584		.6104			.5596
22	.4239	.5853		.5426			.4578
23	.39	.5121		.5087			.39
24		.39	.4755	.3429	.4409		.3052
Max	.9054	.8817	.6584	1.2239	1.3904	1.5939	.7042
Min	.3391	.3658	.4755	.2713	.3292	.2374	.3052
Avg	.5921	.6407	.5588	.7849	.8931	.9872	.4316



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822] BU 4822

Substation No/ Name :- 154098 / 33 KV SUB STATION TOGRI

Feeder No / Name : 203 / 11 KV WAGDRI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7167	.5658	.462	.6036	.5847	.8299	.8962
2	.7733	.6036	.4251	.6036	.7167	.9431	1.0029
3	.9054	.7167	.499	.6224	.7842	1.0562	1.1919
4						1.2696	1.3032
5						1.3817	1.4922
6						1.4937	1.5083
7						1.5684	1.587
8						1.9044	1.5813
9						1.8107	1.8442
10	.8962	.7545	1.1963	1.1984	.6706		
11	1.1949	.9054	1.3094	1.2955	1.1568		
12	1.3443	.9724	1.3757	1.3443	1.4251		
13	1.307	1.073	1.2266	1.0159	1.4083		
14	1.1949	1.0395	.8253	1.2631	1.3748		
15	1.2323	1.073	1.1822	1.2955	1.0395		
16	1.1694	1.1401	1.2003	1.3279	1.3077	.2987	.2641
17	1.0082	1.1401	1.3748	1.2643	1.3443	.2801	.3395
18	.679	.415	.3018	.3547	.4527	.2987	.3772
19		.7545	.6413	.7167	.8299	.462	.679
20	.5658	.7682	.8676	.7356	.9808	.7762	.9431
21	.5281	.7947	.7922	.7545	.8676	.7316	.7545
22	.6413	.7316	.7167	.7356	.7545	.6838	.679
23	.5281	.5121	.6413	.679	.6413	.5729	.5281
24	.5658	.4904	.5121	.6413	.5847	.6036	.5175
Max	1.3443	1.1401	1.3757	1.3443	1.4251	1.9044	1.8442
Min	.5281	.415	.3018	.3547	.4527	.2801	.2641
Avg	.8971	.8028	.8639	.9140	.9402	.9425	.9716

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822] BU 4822

Substation No/ Name :- 154101 / 33/11 KV JAWALGA

Feeder No / Name : 201 / JAWALGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6668	.5716	.5716		.6097	.8002	.602
2	.724	.6859	.6859		.6859	.8619	.7621
3	.7621	.7621	.7621		.7621	1.1279	.9259
4	.8573	.9526	.8764		.8764	1.3279	1.1069
5	.9526	.9907	.8764		.9907	1.4575	1.2018
6						1.7375	1.2803
7						1.5851	2.0119
8						1.5203	2.13
9							1.989
10	.7682	.7122	.5935	.8383	.9145		
11	.9717	1.2803	1.0059	1.1961	1.2003		
12	1.0936	1.2193	.9717	1.2803	1.4022		
13	1.1702	1.2003	1.166	1.2967	1.0669		
14	1.2018	1.3672	1.166		1.1584		
15	1.1702	1.4327	1.1797	1.3123	1.0974		
16	.6249	1.0669	1.0059	1.0212	1.1888	.3048	.3429
17	.8002	1.4022	1.2955	1.4251	1.278	.3048	.3429
18	.5335	.3048	.381	.4382	.3048	.3048	.3429
19	.8764	.5716	.7621	.724	.7621	.6478	
20	1.0288	.6478	.8573	1.0098	.9145	.8764	.8573
21	.9145	.8002		.8764	.7621	.6859	.7621
22	.7621	.7621		.8002	.6668	.6097	
23	.5716	.6668			.5716	.5335	
24	.6668	.5335	.5716	.6668	.5716	.3963	.4755
Max	1.2018	1.4327	1.2955	1.4251	1.4022	1.7375	2.13
Min	.5335	.3048	.381	.4382	.3048	.3048	.3429
Avg	.8559	.8965	.8664	.9912	.8892	.8872	1.0089

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822]

BU 4822

Substation No/ Name :- 154101 / 33/11 KV JAWALGA

Feeder No / Name : 202 / 11 KV KAUTHALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0119		.0076		.0088	.0038	.0076
2	.0134	.0903	.0091		.0103	.0057	.0095
3	.0153	.1067	.0057		.0117	.0076	.0095
4	.0164	.1372	.0137		.0136	.0095	.0114
5	.0197	.1355	.0151		.0164	.0114	.0114
6	.0211	.1372	.0163	.0119	.0178		
7	.0254	.1372	.016	.0203	.0211		
8	.0183	.0211	.0187	.0227	.0234		
9		.0197	.0168	.0178	.0206		
10							.0119
11							.0229
12							.0243
13						.0187	.0187
14						.0187	.0194
15						.0108	
16	.0381	.0038	.0038	.0038	.0038	.016	.0211
17	.0057		.0038	.0038	.0057	.0187	.0227
18	.0076		.0038	.0057	.0076	.0038	.0038
19	.0114	.0057	.0114	.0114	.0095	.0076	
20	.0133	.0114	.0133	.0133	.0114	.0114	.0114
21	.0095	.0095		.0133	.0076	.0095	.0095
22	.0762	.0076		.0095	.0076	.0076	
23	.0762	.0057			.0057	.0076	
24	.0054	.0602	.0046	.0084	.0072	.0057	.0076
Max	.0762	.1372	.0187	.0227	.0234	.0187	.0243
Min	.0054	.0038	.0038	.0038	.0038	.0038	.0038
Avg	.0226	.0593	.0106	.0118	.0117	.0102	.0139

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822] BU 4822

Substation No/ Name :- 154101 / 33/11 KV JAWALGA

Feeder No / Name : 203 / 11 KV MATEGADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0084	.044	.0061		.0086	.0038	.0038
2	.0102	.0602	.0061		.0086		.0057
3	.0119	.0602	.0089		.0101	.0057	.0076
4	.0119	.0602	.0089		.0119	.0076	.0076
5	.0131	.0753	.0113		.013	.0076	.0095
6	.0162	.0753	.0114	.0117	.0146		
7	.0213	.0903	.0129	.017	.0201		
8	.017	.128	.0183	.0197	.019		
9		.1357	.016	.0162	.0194		
10							.0102
11							.0194
12							.022
13							.022
14						.0213	.0211
15						.0146	
16	.0381	.0019	.0019	.0019	.0019	.0174	.0227
17	.0038	.0038	.0019	.0019	.0038	.019	.0243
18	.0057	.0038	.0019	.0019	.0038	.0038	.0019
19	.0057	.0057	.0057	.0076	.0076	.0057	
20	.0057	.0076	.0076	.0076	.0076	.0076	.0057
21	.0057	.0057		.0057	.0057	.0057	.0057
22	.0381	.0038		.0057	.0038	.0038	
23	.0381	.0019			.0038	.0038	
24	.0055	.0452	.0032	.0051	.007	.0038	.0038
Max	.0381	.1357	.0183	.0197	.0201	.0213	.0243
Min	.0038	.0019	.0019	.0019	.0019	.0038	.0019
Avg	.0151	.0449	.0081	.0085	.0095	.0087	.0121

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822] BU 4822

Substation No/ Name :- 154101 / 33/11 KV JAWALGA

Feeder No / Name : 204 / Morge Express Feeder  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8							.018
9					.0269		.0541
10		.0631					.0722
11	.0631		.0544				.0632
12		.0438	.0542				.0632
13		.0438			.0701		
14	.0632						
15		.0351	.0537		.0351	.0451	
16			.0358	.0716	.0263		.0632
17	.0811			.0627	.0526		.0632
18		.0438		.0716	.0351		
Max	.0811	.0631	.0544	.0716	.0701	.0451	.0722
Min	.0631	.0351	.0358	.0627	.0263	.0451	.018
Avg	.0691	.0459	.0495	.0686	.0410	.0451	.0567

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154012 / 33 kv s/s hali

Feeder No / Name : 201 / mortalwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2572	.3429	.1715		
2			.2572	.4287	.1715		
3			.3429	.4287	.3429		.5144
4			1.0288	.6859	.6859		
5				.8573	.8573		.5144
9			1.0288	1.0288	1.0288		
10		.2572	.3429	.8573			.3429
11		.2572	.3429	.4287			.3429
12		.2572		.4287	.4287		.2572
13		.1715		.3429			.1715
14		.2572	.3429	.3429			.1715
15		.2572		.3429	.3429		.1715
16		.2572		.3429			.1715
17		.2572			.4287		.1715
18	.3429	.5144		.5144	.3429		.3429
19		.8573		.5144			.6859
20		.8573		.8573			.9431
21		.6859		.8573			.8573
22		.5144		.6859			.6859
23		.2572					.5144
24		.3429	.2572	.2572	.1715	.4287	.1715
Max	.3429	.8573	1.0288	1.0288	1.0288	.4287	.9431
Min	.3429	.1715	.2572	.2572	.1715	.4287	.1715
Avg	.3429	.4001	.4668	.5550	.4521	.4287	.4135

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154012 / 33 kv s/s hali

Feeder No / Name : 202 / khandsari SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5144	.4287	.6859	
2			.6859	.8573	.6859	
3			.6859	.8573	.6859	.0762
4			.8573	.8573	.8573	
5			.8573	.8573	1.0288	.0762
9			1.7147	1.5432	1.7147	
10		1.6289	1.7147	1.7147		
11		1.5432	1.8004	1.8861		1.8004
12		1.5432		1.5432	1.5432	1.9719
13		.0857		.0857		1.9719
14		.0857	.0857	.0857		1.8004
15		.0857		.0857	.0857	1.8004
16		.0857		.0857		1.8861
17		.0857		.0857	.0857	1.6289
18	.6097	.0857		.0857	.0857	.0857
19		.0857		.0857		.0857
20		.0857		.0857		.0857
21		.0857		.0857		.0857
22		.0857		.0857		.0857
23		.0857				.0857
24		.381	.3429	.4287	.5144	.0762
Max	.6097	1.6289	1.8004	1.8861	1.7147	1.9719
Min	.6097	.0857	.0857	.0857	.0857	.0762
Avg	.6097	.4026	.9259	.5915	.7248	.8502

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154012 / 33 kv s/s hali

Feeder No / Name : 203 / wadhona

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.5432	1.3717	1.5432	
2			1.5432	1.5432	1.5432	
3			1.7147	1.7147	1.5432	.4572
4			2.2291	1.8861	1.7147	
5				2.2291	2.0576	.6097
6			2.2291	1.7147	2.0576	
7			2.2291	1.8861	2.0576	
8			2.2291	1.8861	2.2291	
9			2.572	1.7147	2.572	
10		.4287	.4287	.8573		.9431
11		.5144	.6859	.8573		.9431
12		.6859		.8573	1.0288	1.5432
13		.6859		.9431		.2572
14		.6859	.4287	.9431		
15		.6859		.6859	.9431	2.4863
16		.6859		.9431		2.572
17		.8573			.8573	2.6578
18	1.3717	.2572		.6859	.2572	2.572
19		.3429		.6859		2.0576
20		.3429		.4287		2.0576
21		.3429		.3429		1.9719
22		.3429		.3429		.3429
23		.3429				.2572
24		1.0669	1.0288	1.2003	1.2003	.3048
Max	1.3717	1.0669	2.572	2.2291	2.572	2.6578
Min	1.3717	.2572	.4287	.3429	.2572	.2572
Avg	1.3717	.5512	1.5718	1.1691	1.5432	1.3771



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154012 / 33 kv s/s hali

Feeder No / Name : 205 / mortalwadi-ww

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	16-MAR-17	17-MAR-17
HR	Load (MW)	Load (MW)
8		.2229
9		.2229
10	.2229	.2058
11	.2229	.2058
12	.2229	
13	.2229	
14	.2229	
15	.2229	
16	.2229	
17	.2229	
Max	.2229	.2229
Min	.2229	.2058
Avg	.2229	.2144

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154020 / shirur taj.

Feeder No / Name : 201 / telgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0123	.0069	.0159	.0123	.0123	.0617	.078
2	.0123	.0069	.0177	.014	.0123	.0652	.078
3	.014	.0103	.0177	.0159	.0158	.0703	.0815
4	.014	.0137	.0195	.0158	.0156	.072	.0833
5	.0175	.0154	.023	.021	.0173	.0772	.078
6	.021	.0206	.0283	.0248	.0243	.0772	.0886
7	.0403		.0408	.0403	.0377	.0789	.0638
8	.0368	.0309	.039	.0403	.0326	.0617	.0656
9	.0403	.0354	.039	.0343	.0377	.0638	.0656
10	.024	.0319		.0319	.0326	.0071	.0053
11	.0326	.0744	.0298	.0301	.0566	.0053	
12			.028	.0301	.0549		.0035
13	.0532		.0596	.0543	.0583	.0053	
14	.0549		.0649	.0597	.0617	.0053	.0071
15		.0053	.0666	.0597	.06		.0088
16	.0051	.0372	.0578	.0567	.0583		.007
17		.039	.0631	.0532	.0549	.0142	.007
18		.0478	.0561	.0532	.0497	.0159	.0104
19	.0223	.0585	.0158	.0181	.0154	.023	.0156
20	.012	.0638	.0175	.0181	.0189	.0195	.0189
21	.0103	.023	.0158	.0163	.0154	.0177	.0154
22	.0086	.0195	.014	.0145	.0137	.0142	.012
23	.0069	.0177	.014	.0127	.012	.0142	.012
24	.0123	.0086	.0159	.0123	.012	.0583	.0691
Max	.0549	.0744	.0666	.0597	.0617	.0789	.0886
Min	.0051	.0053	.014	.0123	.012	.0053	.0035
Avg	.0225	.0283	.0330	.0308	.0325	.0394	.0398

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154020 / shirur taj.

Feeder No / Name : 202 / shirur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0195	.0137	.0195	.0195	.0193	.0189	.0213
2	.0213	.0154	.0195	.0195	.0193	.0189	.0213
3	.023	.0154	.0213	.0213	.021	.0206	.0213
4	.023	.0171	.023	.0213	.0208	.0223	.023
5	.0266	.0189	.0266	.0248	.0191	.024	.023
6	.0319	.0223	.0319	.0283	.0243	.0274	.0283
7	.039		.0372	.0354	.0291	.0326	.0319
8	.0372	.0309	.0354	.0319	.0309	.0274	
9	.0337	.0301	.0337	.0326	.0326	.0266	
10	.0206			.0195	.024	.0177	
11	.0206		.023	.0195	.0223	.0283	.0337
12	.0189	.0266	.0213	.0177		.0301	
13	.0189	.0248	.023	.0163		.0319	.0354
14	.0171	.023	.0195	.0181			.0354
15	.0189	.023	.0195	.0181	.024		.0337
16	.0171	.023	.0195	.0195	.024	.0301	.0354
17		.023	.0201	.023	.024	.0301	.0354
18	.0223	.0213	.0213	.023	.024	.023	.0225
19	.0291	.0319	.0301		.0291	.0283	
20	.0257	.0372	.0319	.038	.0326	.0283	.0343
21	.0206	.0319	.0283	.0308	.0309	.0283	.0343
22	.0206	.0283	.0274	.0271	.0274	.0266	.0295
23	.0189	.0248	.023	.0235	.024	.023	.024
24	.039	.0137	.0195	.0177	.0189	.0189	.0213
Max	.039	.0372	.0372	.038	.0326	.0326	.0354
Min	.0171	.0137	.0195	.0163	.0189	.0177	.0213
Avg	.0245	.0236	.0250	.0238	.0248	.0256	.0287

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154020 / shirur taj.

Feeder No / Name : 203 / belur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0301	.0206	.0301	.0283	.0298	.0086	.0089
2	.0337	.0206	.0319	.0319	.0316	.0086	.0089
3	.0372	.0223	.0372	.0337	.0333	.0103	.0106
4	.0372	.024	.0372	.0354	.0347	.0103	.0124
5	.0443	.0274	.039	.0408	.0399	.012	.0124
6	.0496	.0326	.0443	.0461	.0381	.0137	
7	.0496		.0514	.0496	.0377		
8	.0514	.0446	.0514	.0496	.0497		
9	.0478	.0354	.0461	.0429	.048		
10	.0086	.0089		.0106	.012	.0177	.0089
11	.0051	.0071	.0071	.0053	.0086	.0408	.0473
12	.0034	.0035		.0035	.0051	.0478	.0496
13	.0034	.0053	.0053	.0036	.0051	.0461	.0476
14	.0034	.0035	.0053		.0051		.0478
15		.0053	.0053		.0051		.0408
16	.0069		.0053	.0053	.0034	.0496	.0425
17			.0053	.0071	.0017	.0478	.0425
18	.0103	.0089	.0071	.0071	.0034	.0071	.0071
19	.0137	.0159		.0127	.012	.0124	.014
20	.0137	.0159	.0142	.0145	.0137	.0142	.0154
21	.0103	.0124	.0106	.0127	.012	.0124	.012
22	.0086	.0106	.0089	.0109	.0103	.0106	.0104
23	.0069	.0089	.0089	.009	.0086	.0089	.0086
24	.0283	.0189	.0283	.0266	.0257	.0086	.0089
Max	.0514	.0446	.0514	.0496	.0497	.0496	.0496
Min	.0034	.0035	.0053	.0035	.0017	.0071	.0071
Avg	.0229	.0168	.0229	.0221	.0198	.0204	.0228

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154037 / kolnoor

Feeder No / Name : 201 / kolnoor

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	1.2193	1.2003	1.0288	.9602	.9431	.5144	.5144
6	2.1338	2.0233	2.1434	2.0576	2.0233	.7716	.8573
7			2.572				
8	2.5911		2.7092				
9	2.2862	2.915	2.8464		2.915	.8573	.8573
10					.4572	1.3717	
12	.6001	.5144			.3048		3.2579
13			.6001	.5144		2.2291	
15	.5144	.6001	.6001		.3048		3.0864
16				.6859	.3658	2.4348	
17							2.7435
18		.6173	.6859	1.0288	.4801	.5144	
20	.5144						
21		.823	.7716	.8573	.5144	.7716	.7011
23	.7202	.6859		.6859	.4287	.5144	.6097
24	1.0669	.4287	.6001	.6001	.4287	.4287	.4287
Max	2.5911	2.915	2.8464	2.0576	2.915	2.4348	3.2579
Min	.5144	.4287	.6001	.5144	.3048	.4287	.4287
Avg	1.2940	1.0898	1.4558	.9238	.8333	1.0408	1.4507

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154037 / kolnoor

Feeder No / Name : 202 / sonwala

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.4572	.5144	.6173	.6173	.5144	1.1145	.9945
6						1.5432	1.6289
9						1.8004	1.8861
10	1.0669	.5144	1.2003	1.2003	1.0669		
12	1.406	1.3717	1.3717		1.3717		
13				1.1317			
15	1.0974	1.3717	1.406		.9145		
16				1.3375	1.3108	.4287	
17							.3658
18	.9602	.5144	.5144	.6859	.4115	.6859	.3048
21		.6173	.823	.9431	.6859	.6859	.5487
23	.5144	.5144	.4287	.6859	.4287	.5144	.4572
24	.4877	.5144	.5144	.5144	.5144	.8573	.5144
Max	1.406	1.3717	1.406	1.3375	1.3717	1.8004	1.8861
Min	.4572	.5144	.4287	.5144	.4115	.4287	.3048
Avg	.8557	.7416	.8595	.8895	.8021	.9538	.8376

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154044 / wadhona bk.

Feeder No / Name : 201 / wadhona

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.6554				.6401	
4	.4382				.7202	
6					.6706	
7		.362				
8	.4001			.7545	.7316	
9						.2543
10	.7011	.6859		.7545		.5087
11						.4239
12		.7888		.823		.5087
13	.4458					.5087
14		.6859				.4239
15			.4239	.6859		.4748
16		.6859				.5087
17						.4748
18		.6859			.381	
24	.6859				.6097	
Max	.7011	.7888	.4239	.823	.7316	.5087
Min	.4001	.362	.4239	.6859	.381	.2543
Avg	.5544	.6491	.4239	.7545	.6255	.4541

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154044 / wadhona bk.

Feeder No / Name : 202 / ekurka

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.4191				.6859	
4	.4001				.8573	
6					.7888	
7		.6173				
8	.381			.6097	.5144	
9						.5935
10	.7621	.6173		.7011		.6783
11						.6783
12		.6516		.7716		.5935
13	.7202					.2543
14		.823				.2543
15			.5087	.7545		.2543
16		.8573				.2035
17						.2035
18					.0701	
20					.381	
22					.041	
24	.4344				.7202	
Max	.7621	.8573	.5087	.7716	.8573	.6783
Min	.381	.6173	.5087	.6097	.041	.2035
Avg	.5195	.7133	.5087	.7092	.5073	.4126



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154044 / wadhona bk.

Feeder No / Name : 203 / gudsur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.4191				.6554	
4	.4572				.7373	
6					.6859	
7		.4344				
8	.823			.7202	.5944	
9						.6783
10	.442	.6859		.7716		.6783
11						.5935
12		.4572		.7716		.5935
13	.8573					.2035
14		.6859				.2543
15			.4239			.2543
16		.823				.2035
17						.2035
18		.7888			.061	
22					.0671	
24	.4115				.6859	
Max	.8573	.823	.4239	.7716	.7373	.6783
Min	.4115	.4344	.4239	.7202	.061	.2035
Avg	.5684	.6459	.4239	.7545	.4981	.4070

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154044 / wadhona bk.

Feeder No / Name : 204 / wadhona w/w exp.feeder  
Feeder KV- 11 / INCOMINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	15-MAR-17	17-MAR-17
HR	Load (MW)	Load (MW)
2	.1905	
4	.2743	
8	.3506	.0412
10	.3353	.2972
12		.4801
13	.0274	
24	.0412	
Max	.3506	.4801
Min	.0274	.0412
Avg	.2032	.2728

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154044 / wadhona bk.

Feeder No / Name : 205 / 11 KV SUKNI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.703				.6859	
4	.4572				.6859	
6					.6401	
7		.4572			.4572	
8	.381			.0457		
9						.2543
10		.6516				.2543
11						.2543
12		.6859		.6859		.3391
13	.7202					.4239
14		.6859				.4239
15	.6859		.1696	.6173		.4239
16		.6173				.4239
17						.4239
18		.6516			.6097	
20					.6554	
22					.6554	
24	.381				.0427	
Max	.7202	.6859	.1696	.6859	.6859	.4239
Min	.381	.4572	.1696	.0457	.0427	.2543
Avg	.5547	.6249	.1696	.4496	.5540	.3579

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154079 / kumtha

Feeder No / Name : 201 / kumtha

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0075	.0075	.0075	.0075	.0053	.0384	.0352
2	.0075	.0075	.0093	.0075	.0051	.038	.0377
3	.0094	.0093	.0113	.0075	.0049	.0425	.0398
4	.0094	.0113	.0112	.0094	.0072	.0429	.0453
5	.0094	.0112	.0132	.0113	.0089	.0426	.0509
6	.0149	.0112	.0151	.0113		.0492	.0541
7	.0166	.0151	.0144	.0168	.014	.0587	.0627
8	.0163	.0132	.0151	.0132	.0146	.0512	.0599
9	.0127	.0131	.0131	1.0456	.0125	.052	
10	.0137	.0391	.038	.0372	.0467	.0075	
11	.0208	.0453		.0518	.0543	.0056	.0055
12		.0496		.0502	.0573	.0037	.0056
13		.0557	.0518	.0541	.0615	.0038	.0038
14	.0524	.0522	.0518	.0534	.0537	.0037	.0055
15	.05	.053	.0503	.0534	.0508	.0057	.0037
16	.0472	.0512	.0467	.0534	.0502	.0037	.0038
17	.0262	.0056	.0457	.7095	.0524	.0057	.0036
18		.0057	.0056	.7095	.0054	.0056	.0068
19	.0274	.0094	.0094	1.1458	.0066	.0094	.0092
20	.0272	.0093		1.0751		.0113	.0112
21	.0057	.0075	.0094	.9522		.0093	.0097
22	.0057	.0075	.0075	.8676		.0075	.0165
23	.0057	.0075	.0057	.7392		.0075	.0147
24	.0057	.0057	.0075	.0057	.6908		.0336
Max	.0524	.0557	.0518	1.1458	.6908	.0587	.0627
Min	.0057	.0056	.0056	.0057	.0049	.0037	.0036
Avg	.0186	.0210	.0209	.3203	.0633	.0220	.0236

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154079 / kumtha

Feeder No / Name : 202 / chimachi wadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305	.0281	.0335	.0305	.0356	.0065	.0113
2	.032	.032	.0344	.0335	.0352	.0067	.0112
3	.0335	.0368	.0369	.0351	.0352	.0082	.0113
4	.0355	.0393	.0426	.0366	.0402	.0095	.0132
5	.0386		.0528	.0381	.0439	.0088	.0149
6	.0406	.0448	.05	.0412		.0165	.0151
7	.0497	.0459	.0567	.0512	.0599	.0243	.0187
8	.0505	.048	.058	.0549	.0638	.0168	.017
9	.049	.0508	.057	.0573		.0149	
10	.0112	.0113	.0112	1.1016	.0134	.0268	
11	.0112	.0094		.7922	.0146	.0503	.0302
12	.1584	.0057		.6348	.0049	.0518	.0377
13	.1886	.0037	.0055	.547	.0049	.0597	.0344
14	.0037	.0037	.0045	.5041	.0055	.0528	.034
15	.0056	.0057		.4668	.0053	.0475	.0369
16	.0037	.0057		.5041	.0049	.0496	.0453
17	.0057	.0057		.6979	.0034	.0547	.0344
18		.0056	.0055	.6908	.0051	.0057	.0348
19	.0057	.0131	.0112	1.2449	.0101	.0093	.0132
20	.0075	.0131		1.2136		.0151	.0207
21	.0075	.0132	.0113	1.2826		.0132	.0147
22	.0068	.1132		1.1317		.0112	.0137
23	.0075	.0094	.0094	.9522		.0094	.0107
24	.0293	.0234	.0171	.0297	.0075		.0075
Max	.1886	.1132	.058	1.2826	.0638	.0597	.0453
Min	.0037	.0037	.0045	.0297	.0034	.0057	.0075
Avg	.0353	.0247	.0293	.5072	.0219	.0248	.0219

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154082 / Hadoliti

Feeder No / Name : 201 / hadoliti

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.4239	.5258	.5601	.5601	.5601	.6068
2	.5601	.4239	.5201	.5601	.5601	.5601	.6068
3		.4239	.5144	.5601	.5601	.5601	.6068
4	.5601	.4239	.5144	.5601	.5601	.5601	.6859
5	.5601	.5087	.6001	.6535	.6535	.5601	.7716
6	.6783	.5087	.5935	.6783	.7468	.763	.8478
7	.763	.5935	.6783	.8402	.8402	1.1022	.9326
8	.763		.6859	.7468	.6783	1.1022	.9326
9	.5087			.5087	.5601	1.0174	.9326
10	1.0174			.763	.8478	.4287	.5144
11	1.0402	.5144	.8478	.8669	1.0174	.3391	.5087
12	1.3003	.6001	1.0174	.9536		.3391	.4973
13	1.3003	.6001	1.0174	.8669	1.1022	.3391	.4144
14		.5087	1.0174	.8478	1.0174	.3391	.4144
15	1.3003	.5935	1.0288	.8478	1.1022	.3391	.4144
16	1.0402	.6859	1.0174	.8478	1.1022	.3391	.4144
17		.6859	.9326	.8478	1.1022	.3391	.4144
18			.3734	.4668	.3734	.5201	.3429
19		.6201	.6535	.6535	.5935	.6135	.7011
20		.7973	.6783	.7468	.6783	.7888	.7011
21	.6783	.7087	.6783	.7468	.7468	.7011	.7011
22	.6783	.6201	.5935	.6535	.6535	.6135	.5144
23	.5935	.5316		.5601	.5601	.5258	.5144
24	.5601	.6859	.5258	.5601	.5601	.5601	.6068
Max	1.3003	.7973	1.0288	.9536	1.1022	1.1022	.9326
Min	.5087	.4239	.3734	.4668	.3734	.3391	.3429
Avg	.8035	.5729	.7150	.7040	.7468	.5796	.6082

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154082 / Hadolti

Feeder No / Name : 202 / jagalpur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3391	.3506	.3734	.3734	.6535	.5201
2	.3734	.3391	.3467	.3734	.3734	.6535	.5201
3	.3734	.3391	.3467	.3734	.3734	.6535	.5201
4	.3734	.3391	.3429	.3734	.3734	.6535	.6001
5	.4668	.4239	.3429	.3734	.3734	.6535	.6859
6	.4239	.4239	.4239	.4668	.4668	.763	.8478
7	.4239	.4239	.4239	.4668	.4668	1.1022	1.0174
8	.4239	.4239	.4287	.7468	.4239	1.1022	1.0174
9	.4239	.4239	.3467	.3391	.3734	.8478	1.0174
10	1.0174	.6783		.7802	.6783	.3429	.3429
11	1.1022	.6859	.9326	.8669	.9326	.2543	.3391
12	1.3003	.763	.9326	.8669		.2543	.3315
13	1.3003		.8478	.9536	1.0174	.2543	.2486
14	1.3003	.763	.8573	.8478	1.0174	.2543	.2486
15	1.3003	1.0174	.8478	.8478	.9326	.2572	.2486
16	1.2136		.9326	.8478	.9496	.2543	
17		1.0288	.9326	.8478	.8478	.2543	.2486
18	.2543		.3734	.3734	.3734	.2601	.3467
19	.4239	.3544	.3734	.4668	.4668	.3506	.4382
20	.4239	.443	.4239	.4668	.4239	.4382	.4382
21	.4239	.3544	.0429	.4668	.4668	.4382	.4382
22	.3391	.3544	.3391	.3734	.3734	.3506	.3429
23	.3391	.3544	.3734	.3734	.3734	.3506	.3429
24	.3734	1.0288	.3506	.3734	.3734	.4668	.4334
Max	1.3003	1.0288	.9326	.9536	1.0174	1.1022	1.0174
Min	.2543	.3391	.0429	.3391	.3734	.2543	.2486
Avg	.6421	.5382	.5180	.5683	.5576	.4943	.5015

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154082 / Hadolti

Feeder No / Name : 203 / walsangi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6535	.4239	.5201	.5601	.5087	.3734	.3467
2	.7468	.4239	.5201	.5601	.5087	.3734	.3467
3	.7468	.5087	.5144	.5601	.5087	.3734	.3467
4	.7468	.5087	.6001	.5601	.5087	.3734	.3429
5	.8402	.6783	.6859	.5601	.5935	.3734	.3429
6	1.0174	.763	.8478	.6535	.6783	.4239	.3391
7	1.2717	.9326	1.1022	.9431	.8478	.4239	.4239
8	1.2717	1.3003	1.2003	1.1203	.9326	.4239	.4239
9	1.2717	1.2136	.6859	1.0174		.4239	.3391
10	.2543	.2543			.2543	.7716	.8573
11	.2543		.2801			1.0174	1.0174
12	.2543		.2543	.2543		1.1022	.9945
13	.2543		.2801	.2543		1.1022	.9945
14	.2543	.3391	.2772	.2801	.2543	1.1022	1.1603
15	.2543	.2572	.2772	.2801	.2543	.6859	1.1603
16	.2543			.2801	.2543	.9326	1.1603
17		.2572		.2801	.2543	1.0174	.9945
18	.2543	.2629	.2801	.2801	.2801	.3467	.3467
19	.3391	.3544	.3391	.3734	.4239	.3506	.4382
20	.4239	.443	.4239	.4668	.4239	.4382	.4382
21	.4239	.3544	.3391	.4668	.4668	.3506	.4382
22	.3391	.3544	.3391	.3734	.3734	.3506	.3429
23	.3391	.3544	.3391	.3734	.3734	.3506	.3429
24	.5601	.2572	.4334		.5087	.3734	.3467
Max	1.2717	1.3003	1.2003	1.1203	.9326	1.1022	1.1603
Min	.2543	.2543	.2543	.2543	.2543	.3467	.3391
Avg	.5664	.5121	.5019	.4999	.4604	.5773	.5952



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154088 / Jalkot

Feeder No / Name : 201 / jalkot

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7545	.6706	.9335	.7545	.7545	.8316
2		.7545	.7545	.9145	.7545	.7545	.7468
3		.7545	.8402	.905	.7545	.7545	.7468
4	.7545	.7545	.8764	.8954	.7545		.905
5		.7545	.8764	.8764	.7545	.7545	.7468
6	.8488	.7545	.8764	.9431	.8488	.7545	.8316
8			.8764				
9	.7545		.6706	.8573	.7545	.7545	.8764
10		.7776	.6706	.7545			.7545
11	.7545	.8316	.6706	.8488		.7468	.7545
12	.7545	.6706	.7716	.8488	.7545	.7468	.7545
13	.7545	.6706	.7716		.7545	.8316	.7545
14	.7545	.6706	.7716	.8488	.7545	.7468	.7545
15		.7545	.7716	.8488	.7545	.8316	.7545
16	.7545	.6706	.6859		.7545	.8316	.7545
17		.7459	.6859			.7468	
18		.7459	.8145	.7545	.7545	.7468	
19	.7545	.6706	.905	.7545		.8316	.8488
20		.6706	.9955	.7545	.7545	.8316	.8488
21		.0671	.9955	.7545	.7545	.7468	.7545
22		.6706	1.0059	.7545		.7888	.7545
23		.6706	.924	.7545		.8316	.7545
24	.7545	.7545	.6706	.7545	.7545	.7545	.7468
Max	.8488	.8316	1.0059	.9431	.8488	.8316	.905
Min	.7545	.0671	.6706	.7545	.7545	.7468	.7468
Avg	.7639	.6938	.8066	.8293	.7604	.7770	.7837

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154088 / Jalkot

Feeder No / Name : 202 / kunki

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.1658	.2486	.2829	.1677	.503	.5735
2		.1658	.2486	.2801	.1677	.5868	.7316
3	.2801	.1658	.1677	.2801	.1677		.7316
4						.7545	.7888
5						.8383	.7888
6						.8383	.905
7						.8383	1.0288
8						.8383	1.0288
9			.1677				.985
10	.362	.3315	.4144				
11	.543	.4049	.4858	.5801	.5801		
12	.4525	.5468	1.0059	.8288	.6706		
13	.4525	.6554	1.1869				
14	.4715	.5535	1.1736	.8288			
15		.4973	1.1736		.6706		
16		.5668	1.0174	.8383		.1677	.1867
17		.6859	1.0174			.2486	.1867
18	.1867	.2486	.181	.1677	.1677	.2486	.1867
19	.1848	.1677	.2715	.1677		.1677	.2801
20		.1677	.2715	.2515	.2515	.1677	.2801
21		.0168	.2715	.2515	.2515	.2486	.2801
22		.1677	.2801	.1677		.1677	.2801
23		.1677	.2829	.1677		.2486	.2801
24	.2801	.1658	.1677	.2801	.1677	.4191	.4858
Max	.543	.6859	1.1869	.8383	.6706	.8383	1.0288
Min	.1848	.0168	.1677	.1677	.1677	.1677	.1867
Avg	.3493	.3245	.5281	.3838	.3263	.4551	.5560

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154088 / Jalkot

Feeder No / Name : 203 / ravankola SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3413	.8288	1.6632	1.0517	.9945	.2515	.2515
2		1.0059	1.7147	1.0288	1.1603	.2515	.2515
3		1.3413	1.949	1.0288	1.3413	.2515	.1658
4	1.6766	1.6766	2.2624	1.1869	1.6575		
5		1.6766	1.9204	1.6766	1.8442		
6			1.7375	2.3472	2.3472		
7		1.6766	2.1033	2.5149	2.3472		
8	2.0119	1.6766	2.3529	2.5149	2.3472		
9	2.0119		2.5873	2.4863	2.3472		
10							1.6575
11						2.4006	
12						2.6292	2.1548
13						2.5072	2.2377
14						2.8959	2.2377
15			.1753				2.2377
16	.1677	.2486	.1753				.4973
17		.2486	.1753		.2515	2.4025	
18	.1677	.3239	.1791	.2486		2.1719	
19	.2515	.1677	.2658	.2486		2.4272	1.326
20		.1677	.2686	.2486	.2515	2.5873	1.326
21		.2486	.2686		.2515	.2515	.1867
22		.2486	.2772	.2486		.2515	.2801
23		.2486	.2801	.2486		.2515	.2801
24	.6706	.663	1.4022	.9431	.663	.2515	.2515
Max	2.0119	1.6766	2.5873	2.5149	2.3472	2.8959	2.2377
Min	.1677	.1677	.1753	.2486	.2515	.2515	.1658
Avg	1.0374	.7780	1.1452	1.2015	1.3695	1.4522	1.0228

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154042 / 33/11 KV Udgir

Feeder No / Name : 201 / 11 KV TOWN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0395	.9835	1.1361	1.153	1.153	1.153	1.153
2	1.0059	.9665	1.0682	1.153	1.1361	1.1191	1.1022
3	1.0059	1.0059	1.0343	1.1191	1.1191	1.1022	1.1361
4	1.1401	1.153	1.1022	1.1191	1.1022	1.1022	1.1869
5	1.2407	1.1869	1.153	1.2209	1.1022	1.1869	1.2548
6	1.3413	1.2209	1.2717	1.2209	1.2378	1.2378	1.3226
7	1.4754	1.2717	1.6108	1.2548	1.3565	1.5261	1.5091
8	1.4752	1.4074	1.7804	1.5261	1.4413	1.5939	1.3735
9		1.4582	1.6933	1.3904	1.4243	1.4413	1.3565
10		1.4243	1.8107	1.2039	1.3226	1.4413	1.2887
11		1.3904	1.543	1.153	1.2887	1.3226	
12		1.2887	1.4243	1.1191	1.2887	1.2548	1.2378
13		1.2548	1.3226		1.2548	1.2209	1.1869
14		1.2039	1.2039	1.3735	1.2548	1.2039	1.153
15			1.0898	1.153	1.1869		1.153
16	1.1869		1.1022	1.2039	1.1233		1.1191
17	1.2887	1.4074		1.2239	1.0898		
18	1.4752	1.4413		1.2717	1.2239		
19		1.6278		1.7635	1.6278		
20		1.6956		1.6787	1.7126		
21		1.5769		1.5769	1.6617		
22		1.4243		1.4582	1.543	1.4922	
23		1.3056		1.3056	1.3565	1.3226	
24	1.0395	1.0343	1.1869	1.1869	1.1869	1.17	1.2209
Max	1.4754	1.6956	1.8107	1.7635	1.7126	1.5939	1.5091
Min	1.0059	.9665	1.0343	1.1191	1.0898	1.1022	1.1022
Avg	1.2262	1.3059	1.3255	1.2969	1.2998	1.2877	1.2346

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154042 / 33/11 KV Udgir

Feeder No / Name : 202 / 11 KV NAGARPALIKA(Nalgir)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0671	.0838	.0838	.0678	.0838	.0838	.0838
2	.0671	.0838	.0848	.0678	.0671	.0671	.0838
3	.0671	.0838	.0838	.0678	.0671	.0671	.0671
4	.1006	.0838	.0838	.0678	.0671	.0838	.0671
5	.1006	.0838	.0838	.0848	.0671	.0838	.0838
6	.0838	.1006	.0838	.0848	.0671	.0838	.1509
7	.0671	.0838	.1006	.0848	.0838	.1006	.1341
8	.1017	.1006	.1006	.1017	.0838	.1174	.1174
9		.1357	.1174	.1017	.0838	.1006	.0848
10		.1357	.1006	.1017	.0848	.0848	.1187
11		.1357	.1526	.1526	.1357	.1357	
12		.1696	.1357	.1526	.1357	.1357	.1526
13		.1696	.1357	.1509	.1357	.1526	.1526
14		.1696	.1357	.1509	.1187	.1526	.1696
15			.1509	.1017	.1187		.1696
16	.1696	.1696	.1357	.1526	.1174		.1696
17	.1696	.1865		.1509	.0848		
18	.1865	.1526		.1509	.1174		
19		.1696		.1696	.1696		
20		.1677		.1865	.1696		
21		.1526		.1509	.1526		
22		.1174		.1006	.1174	.1006	
23		.1006		.0838	.1006	.1006	
24	.0838	.1006	.0838	.0848	.0838	.0838	.1006
Max	.1865	.1865	.1526	.1865	.1696	.1526	.1696
Min	.0671	.0838	.0838	.0678	.0671	.0671	.0671
Avg	.1054	.1277	.1090	.1154	.1047	.1020	.1191

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154042 / 33/11 KV Udgir

Feeder No / Name : 203 / 11 KV TELEPHONE Express      NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 11 / OUTGOING      (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0671	.0671	.0838	.0678	.0838	.0838	.0838
2	.0503	.0671	.0838	.0678	.0838	.0838	.0838
3	.0503	.0671	.0838	.0678	.0838	.0838	.0838
4	.0503	.0503	.0838	.0678	.0838	.0838	.0838
5	.0671	.0671	.0838	.0848	.0838	.0838	.0838
6	.0671	.0838	.0838	.0848	.0838	.0838	.0838
7	.0503	.0838	.1006	.0848	.0838	.0838	.0838
8	.0509	.0838	.0838	.0848	.0838	.0838	.0838
9		.1017	.1006	.0678	.0838	.1006	.0848
10		.1357	.0838	.0678	.0678	.0678	.0848
11		.1526	.0848	.1017	.1357	.1187	
12		.1526	.1357	.1187	.1357	.1187	.1526
13		.1526	.1526	.1357	.1357	.1526	.1526
14		.1696	.1526	.1341	.1357	.1526	.1696
15			.1509	.1526	.1357	.1526	.1696
16	.1696	.1696	.1696	.1526	.1174		.1696
17	.1696	.0848		.1509	.0838		
18	.0678	.0848		.1509	.0838		
19		.0838		.1006	.0848		
20		.0838		.0838	.0848		
21		.0838		.0838	.0848		
22		.0838		.0838	.0838	.0838	
23		.0838		.0838	.0838	.0838	
24	.0503	.0671	.0838	.0848	.0838	.0838	.0838
Max	.1696	.1696	.1696	.1526	.1357	.1526	.1696
Min	.0503	.0503	.0838	.0678	.0678	.0678	.0838
Avg	.0759	.0983	.1060	.0985	.0955	.0992	.1086

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154042 / 33/11 KV Udgir

Feeder No / Name : 204 / 11KV AMBEDKAR CHOWK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.6443	.7122	.8139	.7122	.7122	.7122
2	.6036	.6443	.7461	.7461	.6783	.6783	.6783
3	.6036	.6706	.6783	.7461	.6613	.763	.8139
4	.6539	.8139	.1526	.8817	.6783	.8139	.8478
5	.8048	.8478	.7122	.9156	.6783	.8478	.8817
6	.8718	.8648	.9835	1.0513	.8139	.9326	.9496
7	1.0898	.8817	1.1361	1.0852	.9835	1.1022	1.0852
8	1.0852	.8817	1.0174	1.2209	1.0852	1.0852	1.1022
9		.8817	1.0227	1.0513	1.0174	1.0852	1.0004
10		.9496	.9389	.9326	.9496	.8648	.9326
11		1.0174	.9665	.9326	1.0174	.9156	
12		1.0174	.9835	1.0004	1.0852	.8817	.9835
13		.8817	.9156	1.0004	1.0852	.8648	.9496
14		.9496	.9156		1.0174	.8648	.9496
15			.8886	.9496	.9496	.8309	.9665
16	.9665	1.0174	.8817	.9496	.9389		.9156
17	1.0174	1.0513		1.0174	.9221		
18	1.1191	1.0513		1.0852	.9724		
19		1.2071		1.3904	1.3226		
20		1.2742		1.3226	1.3226		
21		1.1022		1.153	1.1191		
22		.9326		.9326	.9156	.8817	
23		.8139		.8478	.8139	.8139	
24	.6706	.6706	.6952	.7122	.7461	.7291	.7291
Max	1.1191	1.2742	1.1361	1.3904	1.3226	1.1022	1.1022
Min	.6036	.6443	.1526	.7122	.6613	.6783	.6783
Avg	.8408	.9160	.8439	.9886	.9369	.8704	.9061

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154053 / 33/11 KV LONI

Feeder No / Name : 201 / 11 KV SUGER FACTORY

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	.0543	.1079	.0366	.1079	.054	.0543
2	.0366	.0514	.1079	.037	.054	.054	.0543
3	.037	.0543	.1079	.0366	.054	.054	.0543
4	.0362	.0543	.054	.037	.054	.054	.1086
5	.037	.1086	.054	.0362	.054	.1079	.1086
6	.0732	.1086	.054	.037	.054	.1079	.1086
7	.0739	.0543	.1079	.0724	.1079	.1079	.0543
8	.0366	.1086	.054	.037	.054	.054	.1086
9	.036	.0543	.0543	.036	.054	.037	.0543
10	.036	.0366	.0543	.036	.054	.0739	.0543
11	.054	.0739	.0543	.1079	.054	.0739	.0514
12	.1079	.0366	.1086	.1079	.054	.0366	.0514
13	.054	.0732	.1086	.054	.054	.0732	
14	.0565	.0724	.1086	.054		.0739	
15	.1079	.037	.0543	.054	.054	.0739	
16		.0732	.0543	.054	.054	.0362	
17	.0543	.054	.0366	.1079	.054	.0739	.0366
18	.0543	.1079	.037	.054	.054	.037	.0366
19		.1079	.037	.054	.054	.0724	.037
20	.1086	.1079	.0732	.1079	.054	.0739	.0739
21	.1086	.1079	.0732	.1079	.1079	.0366	.0739
22	.1086	.054	.0686	.1079	.1079	.1086	.0739
23	.1086	.1079	.0739	.1079	.054	.1086	.0732
24	.054	.0543	.1079	.0732	.1079	.054	.0543
Max	.1086	.1086	.1086	.1079	.1079	.1086	.1086
Min	.036	.0366	.0366	.036	.054	.0362	.0366
Avg	.0660	.0731	.0730	.0648	.0657	.0682	.0661



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154053 / 33/11 KV LONI

Feeder No / Name : 202 / 11 KV TALWES

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7682	.3429	.6642	.7316	.759	.7211	.6859
2	.7023	.3429	.6642	.6584	.7211	.6642	.6859
3	.6516	.3429	.6072	.6653	.7211	.6642	.6859
4	.7023	.5144	.6072	.6878	.759	.759	.7716
5	.7316	.6859	.759	.7316	.8539	.8539	.8573
6	.905	.7716	.8539	.8954	.8539	.9488	.9431
7	1.0387	1.0288	1.0437	1.0498	1.0437	1.1385	1.0288
8	1.1458	.9431	1.1385	1.086	1.1385	1.1385	.9431
9	1.1385	.8573	1.0288	1.0247	1.1385	.9774	.9431
10	.9488	.9145	.8659	.9488	1.0437	.8764	.8573
11	.9488	.7316	.8573	.8539	1.0437	.7964	.6859
12	.8539	.8326	.8573	.759	.9488	.7316	.6859
13	.8539	.6516	.7716	.759	.8539	.724	.6859
14	.759	.695	.6859	.759		.7316	.6859
15	.7211	.7316	.7716	.759	.759	.7164	
16		.695	.7716	.6642	.759	.724	
17	.7716	.759	.724	.759	.759	.724	.8326
18	.8573	.759	.7316	.759	.759	.8501	.8048
19	.8573	1.0437	.9511	1.0437	.9488	.9412	1.0242
20	.8573	.9488	.9511	.9488	1.0437	1.0136	.9511
21	.7716	.9488	.9145	.9488	1.0437	.9511	.9145
22	.6859	.9488	.8326	.9488	.9488	.8573	.8413
23	.5144	.9488	.8048	.8539	.8539	.823	.7964
24	.759	.3429	.759	.8048	.797	.759	.7716
Max	1.1458	1.0437	1.1385	1.086	1.1385	1.1385	1.0288
Min	.5144	.3429	.6072	.6584	.7211	.6642	.6859
Avg	.8236	.7409	.8174	.8375	.8935	.8369	.8219

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154053 / 33/11 KV LONI

Feeder No / Name : 205 / 11KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.4338	.6439	.4904	.5681	.6628	.5609
2	.415	.4338	.5681	.415	.5303	.5681	.5258
3	.415	.415	.4734	.4108	.4734	.5681	.5658
4	.4481	.415	.6628	.4527	.5681	.6628	.6602
5	.5281	.5093	.7575	.4904	.7575	.7575	.7545
6	.6348	.7167	.8333	.7468	.9469	1.0416	.9431
7	.9808	1.0374	1.1363	1.1317	1.1363	1.1363	1.1317
8	1.0562	1.0374	1.212	1.0562	1.0416	1.2309	1.094
9	1.1363	1.0374	1.2449	1.1363	1.1741	1.1317	1.0374
10	1.1741	1.1694	1.2071	1.0737	1.2309	1.3203	.7545
11	1.212	1.3957	1.226	1.2499	1.3635	1.3203	.7167
12	1.212	1.2449	1.1317	1.2878	1.4203	1.3203	
13	1.1363	1.0185	1.0374	1.2499	1.212	1.2323	
14	.9848	1.0562	1.0374	1.1363		1.1694	
15	.9469	1.1317	1.0374	1.1741	1.2499	1.0562	
16		1.1317	1.1317	1.212	1.2878	1.1576	
17	1.1317	1.212	1.0562	1.1363	1.0605	1.2826	1.0562
18	1.226	1.2878	1.1694	1.1363	1.2499	1.1576	1.094
19		1.2499	1.1317	1.1741	1.2499	1.2071	1.1317
20	.7545	1.212	1.0562	1.1741	1.2309	1.0562	1.1317
21	.8488	1.0416	.7545	.9469	.9469	.8299	.7922
22	.7545	.7196	.7167	.7196	.7575	.7545	.7545
23	.5658	.6818	.679		.7575	.6602	.679
24	1.1363	.4715	.6818	.6413	.6628	.7196	.6602
Max	1.226	1.3957	1.2449	1.2878	1.4203	1.3203	1.1317
Min	.415	.415	.4734	.4108	.4734	.5681	.5258
Avg	.8705	.9192	.9411	.9410	.9946	1.0002	.8444

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154053 / 33/11 KV LONI

Feeder No / Name : 207 / 11 KV LONI SPARE2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.0876	.1104	.181	.184	.184	.1543
2	.1448	.0876	.1104	.1463	.1472	.184	.1402
3	.1463	.0876	.1104	.1448	.1472	.184	.1402
4	.1829	.1402	.1104	.2149	.184	.2209	.1753
5	.2172	.1753	.1472	.2172	.2209	.2547	.2103
6	.2926	.2103	.184	.2195	.2577	.2945	.2804
7	.394	.298	.184	.362	.3313	.3681	.333
8	.3292	.298	.184	.2926	.3681	.3681	.4557
9	.3681	.3155		.2945	.4049	.3982	.3506
10	.3681	.2896		.3313	.3865	.4344	.3982
11	.3681	.2172		.3313	.3681	.362	.362
12	.3681	.2534		.2911	.3313	.2926	.2896
13	.3313	.181	.2629	.2577	.3681	.2896	
14	.2577	.181	.2629	.2577		.2534	
15	.2577	.1829	.2454	.2577	.3313	.2195	
16		.181	.2279	.2209	.2945	.2149	
17	.2743	.184	.2534	.2577	.3681	.3258	.2896
18	.3086	.184	.2534	.4049	.3313	.3258	.362
19		.184	.3258	.4049	.4049	.3982	.3258
20	.1753	.184	.2926	.3313	.4049	.2896	.3258
21	.1753	.1656	.2534	.2945	.3681	.2195	.2896
22	.1753	.1472	.2172	.2209	.2209	.1928	.2534
23	.1402	.1288	.2195	.184	.184	.1753	.2195
24	.2761	.0351	.1104	.2172	.184	.184	.1753
Max	.394	.3155	.3258	.4049	.4049	.4344	.4557
Min	.1402	.0351	.1104	.1448	.1472	.1753	.1402
Avg	.2590	.1833	.2033	.2640	.2953	.2764	.2765

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154053 / 33/11 KV LONI

Feeder No / Name : 208 / VAISHALI AGRO EXPRESS

SHEDDABLE RURAL

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0366	.3077	.3639	.3326	.3275	.3457	.2715
2	.037	.3258	.3639	.3361	.3275	.3639	.3077
3	.0362	.3258	.3821	.2957	.3457	.3821	.3258
4	.0362	.2172	.3821	.3658	.3457	.3821	.3258
5	.0362	.2534	.3457	.3326	.3457	.3639	.3439
6	.0366	.2172	.3275	.3326	.3457	.3639	.3439
7	.0366	.3258	.3821	.3658	.3457	.3457	.362
8	.0362	.3077	.3475	.3696	.3457	.3457	.3439
9	.0364	.3439	.3439	.3275	.3457	.3326	.362
10	.0364	.3658	.3077	.3639	.3275	.3658	.3077
11	.0364	.3658	.3439	.3639	.3457	.3658	.3258
12	.0364	.3658	.362	.3457	.2911	.362	.362
13	.0546	.3658	.3439	.3457	.3275	.3658	
14	.0546	.3658	.3439	.3093		.3326	
15	.1092	.3658	.3439	.3275	.3275	.3292	
16		.3658	.3439	.3457	.3275	.3277	
17	.2534	.3457	.3258	.3457	.2911	.3696	.3696
18	.2715	.3275	.3326	.3275	.3457	.3696	.3292
19		.3457	.3292	.3457	.3639		.3658
20	.2172	.3457	.3696	.3275	.3639	.3292	.3658
21	.2715	.3457	.3696	.3639	.3639	.3326	.3326
22	.2896	.3093	.3696	.2911	.3457	.3258	.3326
23	.3439	.3275	.3696	.3275	.3275	.3258	.3292
24	.2365	.3258	.3457	.3696	.3457	.3093	.2896
Max	.3439	.3658	.3821	.3696	.3639	.3821	.3696
Min	.0362	.2172	.3077	.2911	.2911	.3093	.2715
Avg	.1154	.3274	.3517	.3399	.3378	.3494	.3348

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154053 / 33/11 KV LONI

Feeder No / Name : 403 / 33 KV O/G Wadhavana

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	15-MAR-17
HR	Load (MW)
22	.0572
23	.0572
Max	.0572
Min	.0572
Avg	.0572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154100 / 33/11 KV MAHADA

Feeder No / Name : 201 / 11KV BODHAN NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.2401	.2401	.2987	.2743	.2915	.2915
2	.3174	.2229	.2229	.2987	.2743	.2915	.2915
3	.2987	.2229	.2229	.2614	.2572	.2915	.2743
4	.3174	.2229	.2401	.2987	.2743	.3086	.3429
5	.3361	.2572	.2743	.2614	.2743	.3429	.3772
6	.3734	.3429	.4287	.2987	.3086	.3772	.4115
7	.4481	.3772	.4458	.4108	.3772	.4287	.4115
8	.4668	.3601	.4115	.4108	.3944	.4287	.3601
9	.3361	.3658		.3961	.4108	.4854	.3734
10	.3734	.3772		.3239	.4481	.4481	.3361
11	.4108	.3206		.4049	.4854	.3361	.2987
12	.3734	.2926		.3521	.4481	.3734	.4108
13	.3361	.3018		.3391	.4108	.3361	.2987
14	.2987	.2263		.3429	.4108	.3361	.3326
15	.4108	.3395	.2614	.3772	.5228	.3361	.4066
16	.3361	.3395	.2987	.3961	.3361	.3361	.3361
17	.3601	.3258	.3395	.3772	.4904	.3961	.3206
18	.3601	.3258	.3772	.3961	.4904	.415	.3584
19		.3429	.415	.415	.4715	.4338	.4715
20	.3429	.3772	.4338	.3601	.4715	.4338	.4338
21	.3429	.3601	.4338	.3944	.4904	.4527	.4338
22	.2915	.3429	.3361	.3772			
23	.2572	.3086	.3361	.3429			
24	.3361	.2401	.2572	.2987	.3086	.2915	.2915
Max	.4668	.3772	.4458	.415	.5228	.4854	.4715
Min	.2572	.2229	.2229	.2614	.2572	.2915	.2743
Avg	.3504	.3097	.3320	.3514	.3923	.3714	.3574

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154100 / 33/11 KV MAHADA

Feeder No / Name : 204 / 11 KV MAHADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0739	.0343	.0343	.0554	.0648	.0857	.0514
2	.0554	.0343	.0343	.0739	.0324	.0857	.0514
3	.0924	.0343	.0343	.0739	.0324	.0857	.0514
4	.1109	.0343	.0343	.0554	.0324	.0857	.0514
5	.1109	.0514	.0514	.0739	.0648	.1029	.0686
6	.1294	.0686	.0857	.0924	.081	.1029	.0857
7	.0739	.1029	.1029	.1294	.081	.1029	.12
8	.0924	.0514	.0514	.0554	.0514	.0514	.0514
9	.0739	.0503	.0739	.0503	.0739	.0739	.0924
10	.1109	.0503	.0739	.0486	.0924	.0739	.0554
11	.1294	.0335	.0554	.0486	.0739	.0554	.1109
12	.1109	.0503	.0739	.0648	.1478	.0739	.0924
13	.1109	.0503	.0924	.081	.1478	.0924	.0924
14	.1109	.1006	.1109	.0972	.1109	.1109	.1109
15	.1109	.0838	.0739	.1006	.1294	.0739	.1294
16	.1109	.0671	.0739	.1174	.1294	.1109	.1109
17	.0514	.0514	.1006	.0503	.1341	.0838	.1174
18	.0686	.0514	.0671	.0503	.1174	.0671	.0671
19		1.5261	.0503	.0335	.0503	.0838	.0671
20	.0343	1.5947	.0335	.0486	.0503	.0503	.0335
21	.0343	.0857	.1006	.0324	.0671	.0457	.0663
22	.0857	.1029	.1109	.081			
23	.1029	.1029	.037	.0972			
24	.0671	.0514	.0343	.037	.081	.0343	.0514
Max	.1294	1.5947	.1109	.1294	.1478	.1109	.1294
Min	.0343	.0335	.0335	.0324	.0324	.0343	.0335
Avg	.0892	.1860	.0663	.0687	.0839	.0788	.0786

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154100 / 33/11 KV MAHADA

Feeder No / Name : 205 / 11 KV VETERINARY COLLEGE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3696	.3086	.3258	.4066	.3086	.3772	.3772
2	.3511	.2572	.3086	.3696	.2915	.4287	.3772
3	.3511	.2572	.3086	.3511	.2915	.4458	.3772
4	.3696	.2743	.3258	.3696	.3086	.4287	.4115
5	.4066	.3429	.3429	.2957	.3429	.4287	.4458
6	.4066	.4115	.4287	.3142	.3772	.4458	.4801
7	.499	.4801	.5144	.4805	.4287	.4801	.4801
8	.5544	.5144	.4973	.499	.4973	.4801	.4801
9	.5175	.5175	.462	.5359	.5914	.5544	.5359
10	.5544	.4805	.462	.5658	.5729	.5175	.499
11	.5175	.462	.4805	.5487	.5544	.5359	.5544
12	.499	.5175	.5729	.5144	.5729	.5175	.5544
13	.4805	.5359	.5175	.4801	.5544	.5359	.5914
14	.462	.462	.4251	.463	.4435	.462	.5544
15	.499	.5175	.462	.499	.4435	.4805	.5544
16	.4251	.5121	.4805	.5175	.4805	.5359	.5544
17	.463	.5144	.4251	.5729	.5175	.499	.5729
18	.4801	.5144	.4805	.5359	.5359	.5175	.4066
19		.5144	.6099	.6468	.6283	.5914	.5729
20		.5316	.499	.583	.5914	.5914	.5729
21		.5144	.5121	.5316	.5853	.5914	.5544
22		.4801	.462	.4458			
23	.2743	.4115	.4435	.3429			
24	.4066	.3429	.3429	.3696	.3429	.3944	.3772
Max	.5544	.5359	.6099	.6468	.6283	.5914	.5914
Min	.2743	.2572	.3086	.2957	.2915	.3772	.3772
Avg	.4444	.4448	.4454	.4683	.4664	.4927	.4947



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154100 / 33/11 KV MAHADA

Feeder No / Name : 206 / 11 KV SHIVAJI CHOWK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4755	.3772	.4115	.4435	.4115	.4458	.4801
2	.439	.3601	.3772	.462	.3944	.4287	.4801
3	.4572	.3601	.3772	.4435	.4115	.4458	.4801
4	.4938	.3601	.4115	.4251	.3944	.463	.4801
5	.5121	.3601	.4287	.4435	.4287	.4801	.5144
6	.5487	.4115	.4973	.462	.4801	.5144	.5144
7	.6036	.4973	.5316	.5359	.5316	.5487	.5487
8	.6219	.4801	.5144	.5729	.5144	.5144	.5487
9	.5729	.6036	.6283	.567	.5544	.5544	.5359
10	.6653	.567	.6283	.583	.6099	.5729	.6283
11	.7023	.7682	.7023	.6516	.7023	.5914	.6468
12	.6653	.6767	.5729	.6516	.7023	.6468	.6838
13	.7392	.6767	.7392	.6344	.6283	.6283	.7207
14	.7762	.7316	.7207	.6344	.6468	.6283	.6099
15	.7392	.7133	.7023	.6516	.6468	.6468	.6099
16	.7207	.7316	.7207	.7392	.6283	.6468	.7023
17	.6687	.6344	.695	.6767	.6219	.6584	.7499
18	.6859	.7202	.823	.695	.6767	.7133	.7316
19		.8573	.8962	.8779	.8779	.8413	.8413
20		.9259	.823	.8573	.8779	.8048	.9877
21	.7202	.8402	.695	.7545	.7682	.7316	.8962
22	.5316	.583	.5914	.6173			
23	.4801	.5144	.5544	.5316			
24	.4938	.4287	.4287	.462	.4458	.4801	.4801
Max	.7762	.9259	.8962	.8779	.8779	.8413	.9877
Min	.439	.3601	.3772	.4251	.3944	.4287	.4801
Avg	.6051	.5908	.6030	.5989	.5888	.5903	.6305

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154100 / 33/11 KV MAHADA

Feeder No / Name : 207 / 11KV EXPRESS RUDRANI  
HEALTHCAR Feeder KV- 11 /  
OUTGOING

SHEDDABLE RURAL

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0924	.0686	.0686	.0924	.0686	.0686	.0686
2	.0739	.0686	.0686	.0739	.0686	.0686	.0686
3	.0924	.0686	.0686	.0924	.0686	.0686	.0686
4	.0924	.0686		.0739	.0686	.0686	.0686
5	.1109	.0686	.0686	.0924	.0686	.0686	.0686
6	.0924	.0686	.0686	.0739	.0686	.0686	.0686
7	.0924	.0686	.0686	.0739	.0686	.0686	.0686
8	.1478	.0686	.0686	.0739	.0686	.0857	.0686
9	.0924	.1063	.0924	.0886	.0747	.0739	.0739
10	.1109	.0886	.0924	.0857	.0739	.0739	.0739
11	.1109	.0886	.0924	.0686	.0924	.0739	.0739
12	.1109	.1063	.0924	.0857	.0924	.0924	.1109
13	.0924	.0886	.0924	.0857	.0924	.0924	.0924
14	.1109	.1063	.0924	.0857	.1294	.1109	.0739
15	.1109	.1063	.0924	.0857	.0924	.1294	
16	.0739	.124		.0857	.1109	.1109	
17	.0686	.12		.124	.1595	.124	
18	.0857	.1029		.1772	.1949	.124	.124
19		.0857		.1949	.1772	.1417	.1063
20	.1029	.0686	.0886	.1886	.1595	.1063	.1063
21	.1029	.0857	.0886	.1543	.1595	.1063	.1063
22	.12	.1029	.1109	.1372			
23	.0857	.1029	.0924	.1029			
24	.0886	.0686	.1029	.0924	.0857	.12	.0686
Max	.1478	.124	.1109	.1949	.1949	.1417	.124
Min	.0686	.0686	.0686	.0686	.0686	.0686	.0686
Avg	.0984	.0875	.0848	.1037	.1020	.0930	.0821

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 157003 / 132 KV UDGIR

Feeder No / Name : 401 / 33 KV UDGIR

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	17-MAR-17
HR	Load (MW)
13	.0572
Max	.0572
Min	.0572
Avg	.0572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 157003 / 132 KV UDGIR

Feeder No / Name : 402 / 33 KV NALGIR

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.4161	4.6296	5.0412	5.9808	6.3272	5.4527	5.2984
2	5.4527	4.9383	4.6296	5.6516	6.5329	5.2469	5.4012
3	5.679	5.0412	4.1667	5.6516	6.4301	5.607	5.5041
4	4.1541	4.6296	4.9897	5.3772	5.4012	6.0185	7.2017
5	5.8894	4.6296	5.7613	5.5418	5.9156	6.6873	2.4691
6	6.8884	5.9671	6.6873	5.8162	6.9445	7.5617	7.9733
7	8.5711	7.8189	8.0761	8.3951	8.2305	7.8704	8.0761
8	9.6022	8.1276	8.179	8.3951	7.7161	7.7161	8.4877
9	8.8889	8.6146	6.6392	4.7325	8.011	8.6146	8.4499
10	8.2305	8.6146	6.5844	4.473	7.2428	7.8464	8.5048
11	8.3402	6.07	7.2977	5.407	8.2853	9.4925	9.9863
12	8.2305	5.2984		5.7019	6.3649	10.1509	10.5899
13	8.3402	4.8868	7.1879	5.9968	7.0782	10.4253	9.9314
14	7.6818	5.2984	6.6941	6.046	7.1331	9.9314	9.9863
15	7.4074	5.8642	7.1331		5.4321	10.3155	9.9314
16	7.572	6.7387	7.3525		6.6392	10.535	10.4253
17	5.3498	6.6873	7.1502		8.0247	9.9794	10.3704
18	4.1152	3.2407	3.1893	3.035	3.2407	3.0864	2.7778
19		3.9095	4.1152	4.1152	4.2696	4.321	4.4239
20	4.0124	4.3724	4.4753	4.4753	4.7325	4.6296	4.8868
21	3.7037	4.1667	4.1152	4.1152	4.4753	4.4239	4.4239
22	3.3951	3.6008	3.6763	3.7037			
23	3.0864	3.2922	3.4019	3.3951			
24	4.784	4.9897	5.0926	5.7065	5.8642	5.3498	1.3375
Max	9.6022	8.6146	8.179	8.3951	8.2853	10.535	10.5899
Min	3.0864	3.2407	3.1893	3.035	3.2407	3.0864	1.3375
Avg	6.2953	5.4761	5.7233	5.3196	6.3769	7.3301	7.1108

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154025 / 33 KV NALGIR

Feeder No / Name : 201 / 11 KV ATNOOR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7545	.6478		.6706	.4024	
2		.7712	.6874		.7042	.4359	
3		.8048	.6874		.7712	.503	
4		.6706	.6371		.6706		
5		.8718	.7545		.8048		
6		1.0898	.9389		.9221		
7	1.2574	1.1904	1.1401	1.291	.9724		
8		1.2239	1.1736	1.291	1.0059		
9		1.1568	1.1568		1.0562		
10						1.2407	1.1736
11						1.6263	
12							1.643
13							1.6598
14							1.6263
15							1.576
16	.218	.2012		.2347	.2105		1.4754
17	.2515	.2347		.285	.2515		1.643
18	.3185	.3018		.3018	.2683		.2515
19		.4694		.4694	.3521		.4359
20	.5868	.6036		.6706	.6036		.6874
21	.5365	.5197		.5197	.5533		.6203
22	.4024	.4694		.4191	.503		.4694
23	.3401	.3856			.4024		.4191
24	.5197	.4694			.6203	.3688	
Max	1.2574	1.2239	1.1736	1.291	1.0562	1.6263	1.6598
Min	.218	.2012	.6371	.2347	.2105	.3688	.2515
Avg	.4923	.6771	.8693	.6091	.6302	.7629	1.0524

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154025 / 33 KV NALGIR

Feeder No / Name : 202 / 11 KV AWALKONDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3521	.5365		.3353	.6539	
2		.3353	.5365		.3353	.6706	
3		.3521	.6539		.3353	.6706	
4						.503	
5						.7712	
6						.8718	
7						1.2407	1.3077
8						1.576	
9						1.5592	1.4083
10	1.1401	.8215	.9054	.8383	1.1065		
11		.8718	1.2071		1.358		
12	1.4251				1.4083		
13	1.358	1.5592		.9556	1.3413		
14	1.3413	1.5927		.9556	1.0898		
15	1.2239	1.5927		1.0059	1.073		
16	1.0898	1.073		1.0395	.8583		.2683
17	1.0898	.9054		1.1904	1.291		.2683
18	.3856	.3185		.285	.3185		.3018
19		.5868		.5197	.4359		.5868
20	.8383	.8048		.7545	.7377		.8048
21	.7712	.7545		.7042	.7209		.6874
22	.6706	.6539		.5868	.6203		.6539
23	.4024	.5533			.5533		.5365
24	.3521	.3353			.503	.6316	
Max	1.4251	1.5927	1.2071	1.1904	1.4083	1.576	1.4083
Min	.3521	.3185	.5365	.285	.3185	.503	.2683
Avg	.9299	.7919	.7679	.8032	.8012	.9149	.6824

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154031 / 33 / 11 KV KARADKHEL

Feeder No / Name : 201 / 11 KV KARADKHEL SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.4382	.6859	.5087	.5087	.2629	.2572
2	.6859	.4382	.6859	.5935	.5087	.2362	.2572
3	.6001	.4382	.6859	.5935	.5868		.3429
4	.6001	.7011	.6859	.6783	.6783		
5	.7716	.7888	.8573	.763	.8383		
6	1.0288	.964	.9431	1.0174	1.0059		
7	1.2003	1.1393	1.286	1.3565	1.3565		
8	1.3717		1.3717	1.3565	1.3413		
9	1.3717	1.4022	1.3717	1.3565	1.3413		
10						1.0288	.9431
11						1.3717	1.3565
12							1.3565
13							1.3413
14						1.3717	1.3565
15						1.286	1.3413
16	.2629	.1715	.1696		.1753	1.3717	1.3565
17	.1753	.1715	.2543	.1696	.1753		
18	.3506	.2572	.2543	.1696			
19	.4382	.3429	.2543	.2543	.2629		.2543
20	.4382		.4239	.4239	.4382	.5144	.3391
21	.3506	.3429	.3391	.4239	.4382	.4287	.3391
22	.3506	.3429	.3391	.3391	.3506	.3429	.3353
23	.3506		.2543	.3391	.3506	.3429	.2543
24	.4287	.2629	.3429	.5087	.5087	.2629	.2515
Max	1.3717	1.4022	1.3717	1.3565	1.3565	1.3717	1.3565
Min	.1753	.1715	.1696	.1696	.1753	.2362	.2515
Avg	.632	.5468	.6225	.6384	.6392	.7351	.7302

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154031 / 33 / 11 KV KARADKHEL

Feeder No / Name : 202 / 11 KV HER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3544	.3544	.3544	.3429	.3506	.6201	.7011
2	.443	.443	.443	.3429	.3544	.7087	.7011
3	.5316	.443	.443	.3429	.4382	.7087	.7011
4						.7973	.7802
5						.8859	.7802
6						.8859	.9536
7							1.0517
8						.9745	1.2136
9						1.0631	1.2403
10	.7087	.5144	.6783	.6859	.7011		
11	.5316	.7973	.9326	.7888	.7888		
12	.9745	.9745	.8478	.7011	1.0631		
13	.9745	.9745	.8478	.7087	1.0631		
14	.9745	.8859	.9326	.7011	.9745		
15	8.9655	.9745	.8478	.6001	.8859		
16	.7973	.9745	.9326	.7011	.9745		.2629
17	.8859	1.0631	.9431	.7087	.9745	.3467	
18	.3506	.2658	.2572	.2629	.2581	.3506	
19	.5316	.443	.3429	.3544	.443	.4382	.5258
20	.5316		.5144	.5316	.5316	.5258	.5258
21	.443		.5144	.4382	.5316	.5258	.5258
22	.443	.443	.5144	.443	.443	.4382	.443
23	.443	.443	.3429	.3506	.3544	.3506	.4382
24	.3544	.3544	.3544	.3544	.3544	.5316	.5258
Max	8.9655	1.0631	.9431	.7888	1.0631	1.0631	1.2403
Min	.3506	.2658	.2572	.2629	.2581	.3467	.2629
Avg	1.0688	.6468	.6135	.5200	.6380	.6345	.7106



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154031 / 33 / 11 KV KARADKHEL

Feeder No / Name : 203 / 11 KV DIGRESS SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.8669	.7802
2		.1387				.8669	.7802
3						.8669	.8669
4						1.0402	1.0517
5						1.1269	1.0517
6						1.2136	1.5775
7							1.8404
8						1.7337	2.1033
9							1.647
10	.3467	.5258	1.0631	1.0402	1.0402		
11	.2601	1.2269	1.2403	1.3003	1.4737		
12	.2601	1.4022	1.4175	1.387	1.5061		
13	1.0402	1.4022	1.2403	1.387	1.4737		
14	.8669	1.0517	1.3289	1.387	1.4737		
15	1.4737	1.2269	1.3289	1.3003	1.387		
16	1.2136	1.2269	1.4175	1.387	1.4737		
17	1.2136	.8764	1.4175	1.4737	1.4737		
21					.1387		
24						.6935	.6935
Max	1.4737	1.4022	1.4175	1.4737	1.5061	1.7337	2.1033
Min	.2601	.1387	1.0631	1.0402	.1387	.6935	.6935
Avg	.8344	1.0086	1.3068	1.3328	1.2712	1.0511	1.2392

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154039 / 33 / 11 KV DEVARJAN

Feeder No / Name : 201 / 11 KV DEVARJAN (AG)

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.7373	.9145
2					.7969	.9907
3					.8029	.9907
4					.8288	1.0364
5					.8309	1.0974
6					1.1233	1.2193
7					1.3748	1.3413
8					1.3748	1.4632
9						1.3717
10			.9389	.9431		
11		.9907	.9389			
12	1.286		1.1736			
13	1.3375	1.2193		1.326		
14	1.3889		1.2929	1.3592		
15	1.2929		1.2929	1.2763		
16	1.1568	1.2193	1.3108	1.2742		
17			1.3435	1.2742		
24				.7045		.6859
Max	1.3889	1.2193	1.3435	1.3592	1.3748	1.4632
Min	1.1568	.9907	.9389	.7045	.7373	.6859
Avg	1.2924	1.1431	1.1845	1.1654	.9837	1.1111

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154039 / 33 / 11 KV DEVARJAN

Feeder No / Name : 202 / 11 KV SHEKAPUR (AG)

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0774	.6874	.9431	1.3717	1.046		
2		.7499	1.1145	1.6766	1.1401		
3		.8697	1.3717	1.829	1.2574		
4		.9602	1.3203	2.1033	1.3923		
5		1.0974	1.6289	2.0576	1.5565		
6		1.1736	2.4006	2.1338	1.6876		
7		1.829	2.2291	2.2558	2.3266		
8			2.6578	2.21	2.4006		
9			2.6578	2.2253	2.4905		
10							1.9033
11						2.3472	2.7435
12						1.9814	1.0288
13							1.2289
14							2.6578
15						1.5242	2.7435
16						2.2862	1.8861
17						2.5911	2.7435
24		.6249	.9326	.5335	.9602		
Max	1.0774	1.829	2.6578	2.2558	2.4905	2.5911	2.7435
Min	1.0774	.6249	.9326	.5335	.9602	1.5242	1.0288
Avg	1.0774	.9990	1.7256	1.8397	1.6258	2.1460	2.1169

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154039 / 33 / 11 KV DEVARJAN

Feeder No / Name : 205 / 11 KV DEVARJAN GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1753	.1886	.1867		.1886	.1753	.1219
2		.1886	.168		.1886	.2126	.1219
3		.1886	.1886		.1886	.2629	.1067
4		.2263	.2401		.2054	.2835	.1524
5		.2772	.3772		.2801	.3544	.3048
6		.4435	.4801		.439	.443	.381
7		.5175	.5228		.5121	.5138	.4268
8			.4287		.4207	.4252	.3353
9		.3361	.2743	.0457	.3841		.2896
10		.1715	.1886	.1848	.2801		.2134
11		.168	.1219	.1132	.1772	.1372	.1886
12		.1494	.0914	.132		.1067	.1867
13		.12	.0762	.132	.1063	.1067	.112
14		.1307		.132	.1063	.0914	.1307
15		.1494		.132	.1052	.0914	.1494
16		.168	.0762	.132	.1402	.1219	.1867
17		.1494		.132	.1402	.1372	.168
18	.2743	.1867	.1219	.1698	.1595	.2286	.1867
19		.2263	.2439	.2772	.2126	.2743	.2241
20	.3696	.2801	.2743	.3326		.2439	.2614
21		.2987		.2587		.2134	.2801
22	.2033	.2614				.1372	.2241
23		.1867		.1886			
24		.1848	.1867	.1372	.1772		.1219
Max	.3696	.5175	.5228	.3326	.5121	.5138	.4268
Min	.1753	.12	.0762	.0457	.1052	.0914	.1067
Avg	.2556	.2260	.2360	.1667	.2322	.2280	.2119

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154039 / 33 / 11 KV DEVARJAN

Feeder No / Name : 207 / 11 KV ARASNAL AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.426	.5335
2						.4973	.7164
3						.4915	.7773
4						.4807	.8078
5						.4862	.8535
6						.9389	.9145
7						1.0513	1.0212
8						1.0682	1.0974
9							1.0364
10		.4801		.6036	.6173		
11		.6859	.7011	.7042	.6554		
12	.7202	.9431		.8886	.6554		
13	.7202	.8916			.8951		
14	.7545	.8573		.9054	1.0774		
15	.7042	.823		.9054	1.1469		
16	.7459	.823	.7621	.9116			
17		.9431		.9175	.9831		
24					.4641		.3963
Max	.7545	.9431	.7621	.9175	1.1469	1.0682	1.0974
Min	.7042	.4801	.7011	.6036	.4641	.426	.3963
Avg	.729	.8059	.7316	.8338	.8118	.6800	.8154

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154039 / 33 / 11 KV DEVARJAN

Feeder No / Name : 208 / 11 KV Water Works Feeder NON SHEDDABLE WATER SUPPLY AND  
Feeder KV- 11 / OUTGOING UTILITY

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0508	.0491	.0561	.0457	.0491	.0491	.0457
2		.0491	.0514	.0457	.0491	.0496	.0457
3		.0508	.0514	.0457	.0514	.0508	.0305
4		.0508	.0514	.0457	.0514	.0508	.0305
5		.0508	.0514	.0457	.0508	.0508	.0305
6		.0508	.012	.0457	.0526	.0514	.0305
7		.0508	.0103	.0457	.0514	.0514	.0457
8			.0514	.0286	.0514	.0514	.0457
9		.0508	.0514	.0457	.0508		.0457
10		.0508	.0514	.0526	.0491		.0526
11		.0526	.0457	.0526	.0508	.0457	.0543
12	.0508	.0526	.0457	.0508	.0508	.0457	.0508
13	.0508	.0508	.0457	.0508	.0491	.0457	.0508
14	.0508	.0508		.0508	.0491	.0457	.0453
15	.0035	.0526		.0526		.0457	.0467
16	.0035	.0526		.0526	.0508	.0457	.0373
17		.0561		.0526	.0508	.0457	.0421
18	.0035	.0561	.0457	.0543		.0305	.0508
19		.0549	.0457	.0491		.0457	.0438
20	.0491	.0549		.0491		.0457	.0456
21		.0497		.0491		.0457	.0491
22	.0491	.0561				.0457	.0508
23		.0514		.0491			.0497
24		.0491	.0343	.0457	.0508		.0457
Max	.0508	.0561	.0561	.0543	.0526	.0514	.0543
Min	.0035	.0491	.0103	.0286	.0491	.0305	.0305
Avg	.0347	.0519	.0438	.0481	.0505	.0469	.0444

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154085 / 33 KV LOHARA S/S

Feeder No / Name : 201 / 11 KV LOHARA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.1829		.2439		.583	.4858
2	.2743	.2187		.2743	.1829	.6001	.5624
3	.3048	.2286		.3048	.2134	.6001	.6097
4						.6859	.6706
5						.8573	.7133
6						1.0288	.724
7						1.2003	.8916
8						1.2003	1.0364
9						1.0974	
10	.6859	.1448	.1829	.4877	.5213		
11	.8688		.9145	.8573	.9431		
12	.9717		1.0364	.9755	1.2003		
13	.9602		1.0669	1.1203	1.2003		
14	.9431		1.0059	1.0364	1.1317		
15	.9145		.9755	1.0311	1.166		
16	.8573		.9145	.9755	1.1317	.141	.2134
17	.8688		.9145	.1524	1.166	.1486	.2134
18	.1486		.2439	.1562	.2401	.1524	.2439
19			.381	.2429	.3429	.1829	.2743
20			.381	.2949	.4287	.2439	.2591
21			.3353	.2949	.3772	.2915	.25
22			.2439	.2683	.3429	.2622	.2286
23			.2439	.2458	.3086	.2267	.2134
24	.2439	.1829		.1524	.2267	.4458	.3749
Max	.9717	.2286	1.0669	1.1203	1.2003	1.2003	1.0364
Min	.1486	.1448	.1829	.1524	.1829	.141	.2134
Avg	.6397	.1916	.6314	.5064	.6543	.5527	.4685

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154085 / 33 KV LOHARA S/S

Feeder No / Name : 202 / 11 KV BHAKASKHEDA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4877	.4268	.4287	.4877	.4999	.2058	.1619
2	.5487	.4999	.5144	.5487	.5487	.2058	.1875
3	.6097	.5182	.5144	.6097	.5487	.2401	.1829
4	.7316	.5487	.6001	.7316	.535		
5	.7621	.602	.7716	.7621	.6371		
6	.8535	.6539	.8573	.8535	.6573		
7	1.0669	.8688	1.1145	1.0669	.7145		
8	1.3413	.9145	1.2003	1.3413	1.0002		
9	1.3717	.9846	1.0059	1.3717	1.0002		
10						.4999	.4877
11						.8688	.9907
12						.9431	1.0364
13						.9145	1.0364
14						.8779	1.0669
15						.8859	1.0364
16	.1143			.1524		.8741	1.0364
17	.1448			.1524	.1715	.8916	.9755
18	.1486	.2058		.1562	.2058	.1524	.1829
19		.2743		.2267	.2401	.1524	.2286
20		.3086	.4268	.2294	.2743	.2286	.2429
21		.2743	.2439	.2458	.2743	.2591	.2343
22	.2134	.2401	.3048	.2347	.2401	.2294	.2134
23		.2058	.1829	.1966	.2058	.1943	.2134
24	.4572	.3048	.4287	.4572	.3239	.2058	.1562
Max	1.3717	.9846	1.2003	1.3717	1.0002	.9431	1.0669
Min	.1143	.2058	.1829	.1524	.1715	.1524	.1562
Avg	.6323	.4894	.6139	.5458	.4751	.4905	.5372



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154085 / 33 KV LOHARA S/S

Feeder No / Name : 203 / 11 KV KUMTHA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4268	.4572	.3429	.4268	.4687	.2743	.1943
2	.4877	.4999	.3429	.4877	.5182	.2743	.2187
3	.5487	.5487	.3429	.5487	.5792	.2743	.2439
4	.6706	.5487	.3772	.6706	.5944		
5	.7316	.5719	.6173	.7316	.6371		
6	.7621	.5944	.7716	.7621	.7145		
7	.9907	.695	1.0288	.9907	.7859		
8	1.1431	.7145	1.2003	1.1431	.9288		
9	1.2803	.7819	1.0669	1.2803	.9717		
10						.4687	.4572
11						.8688	.9145
12						.9145	.9755
13						.9431	1.0364
14						.9328	.9755
15						.9145	1.0059
16	.1429	.2058	.1524	.1524	.2058	.8459	.945
17	.1738	.2401	.1829	.1524	.2058	.8619	1.0669
18	.2229	.2743	.2439	.1875	.2743	.1524	.1829
19		.3772	.381	.2591	.3429	.1829	.3048
20		.4287	.381	.2949	.4287	.2743	.2915
21		.3772	.3353	.3277	.3772	.3239	.2812
22	.2743	.3429	.2134	.3018	.3086	.2949	.2439
23		.2743	.2439	.2622	.2743	.2429	.2286
24	.3658	.4268	.3429	.3658	.3887	.2743	.1875
Max	1.2803	.7819	1.2003	1.2803	.9717	.9431	1.0669
Min	.1429	.2058	.1524	.1524	.2058	.1524	.1829
Avg	.5872	.4644	.4760	.5192	.5003	.5177	.5419

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154087 / 33/11 KV S. OMARGA

Feeder No / Name : 202 / 11 KV S.OMARGA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2378	.2218	.2218	.2743		.7964	1.3565
2		.2218	.2957	.2743		1.0867	1.4413
3		.3696	.3696	.3224		1.2971	1.5261
4						1.3717	1.5261
5						1.6118	1.95
6						1.7147	2.3739
7						2.5194	2.4587
8						2.652	2.3739
9						2.4531	2.713
10		.4344	1.1218	.8383	1.267		
11	1.1022	1.4403	1.8861	2.1091	2.2634		
12	2.2043	1.7147	2.1948	2.1091	2.1262		
13	2.2043	.3429	1.9376	2.1247	.823		
14	2.1195	.3086	1.8519	2.1091	.7545		
15	2.0348	.3086	2.0576	.9496	1.8861		
16	1.8652	.3429	1.8004		2.0576	.2035	.1829
17	1.7804	1.7833	2.332	1.5565	2.332	.2035	.1867
18	.2543	.2172	.1829	.1829	.1448	.2035	.1867
19		.3696	.3258	.4481	.2957	.3052	.3734
20	.4239	.5175	.3506	.4435	.5175	.3391	.4481
21	.373	.3696	.3506		.3696	.3391	.4527
22	.2035	.2957	.3658	.3696	.2957	.3052	.3772
23		.3326	.2926	.3696	.2218	.2543	
24	.2378	.2035	.2218	.2926		.724	1.3565
Max	2.2043	1.7833	2.332	2.1247	2.332	2.652	2.713
Min	.2035	.2035	.1829	.1829	.1448	.2035	.1829
Avg	1.157	.5441	1.0089	.9234	1.0968	1.0211	1.2520

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154087 / 33/11 KV S. OMARGA

Feeder No / Name : 203 / 11 KV KARWANDI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3582	.3696	.3258	.5258		.2218	.2458
2		.3982	.362	.5609		.2957	.3277
3		.3856	.3506	.6001		.3696	.3277
4		.4207	.4207	.6516			
5		.5144	.4801	.6859			
6		.7716	.5487	.6859			
7		.9431	.6173	.7716			
8		.9431	.8573	.823	.9945		
9		.9431	.8573	.7888	.9431		
10						.362	.7865
11						.9012	.9012
12						.8192	.9686
13						.8192	
14						.8192	
15						.9221	.6249
16	.1311	.0739	.0732	.0876		.9012	.6401
17	.2294	.1109	.1097	.0876	.0739	.9012	
18	.2294	.2218	.1629	.1867	.1478	.0819	
19		.3326	.2865	.3772	.3326	.2949	.3361
20	.3605	.4066	.3224	.3696	.4066	.3605	
21	.3277	.3696	.3403	.3696	.3696	.3277	
22	.2949	.2957	.3292	.3696	.2957	.3277	
23		.2218	.2743	.3696	.2218	.3277	
24	.3224	.3277	.3326	.362		.2218	.2458
Max	.3605	.9431	.8573	.823	.9945	.9221	.9686
Min	.1311	.0739	.0732	.0876	.0739	.0819	.2458
Avg	.2817	.4472	.3917	.4818	.4206	.5153	.5404

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154103 / 33 KV S/S GUTTI

Feeder No / Name : 203 / 11 KV SULLALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.5716	.4801	.7202	.8192	.381	.381
2	.5525	.5906	.5144	.7202	.8002	.362	.381
3	.6097	.6478	.5316	.703	.8764	.4001	.4001
4	.6668	.6668	.5658	.7373	.8764		
5	.724	.743	.6001	.7716	.8764		
6	.8573	.8192	.6516	.823	.8954		
7	1.0288	.9335	.8059	1.046	1.0098		
8	1.0288		.7545	.9945	.9907		
9	1.0288	.8764	.9945	.8745	.9602		
13						1.1488	
14						1.1317	
15						1.1317	
16	.1334	.1524	.1524		.1524	1.2003	
17	.2286	.2286	.1905	.2477	.2286	1.1145	
18	.3429	.1524	.2096	.3048	.3048	.3239	
19		.381	.5716	.6097	.5144	.5144	
20	.5525	.4382	.5906	.6478	.5335	.5335	
21	.5144	.5144	.5144	.5906	.5525	.4763	
22	.4572	.4763	.4954	.724	.4191	.5335	
23	.4191	.381	.4572	.743	.4572	.4191	
24	.4287	.5144	.4458	.8002	.8002	.381	.362
Max	1.0288	.9335	.9945	1.046	1.0098	1.2003	.4001
Min	.1334	.1524	.1524	.2477	.1524	.3239	.362
Avg	.5945	.5346	.5292	.7093	.6704	.6701	.3810