Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
AJARA[022] **BU 1155**
Substation No/ Name :- 144063 / 33/11 KV AJARA
Feeder No / Name : 201 / 11 KV AJARA **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.3292	.3292	.3439	.2896	.2534	.2957
2	.2896	.2926	.3292	.3292	.2896	.2534	.2957
3	.2926	.2896	.2896	.3292	.2715	.2353	.2957
4	.2926	.2926	.2896	.3292	.2715	.2353	.2926
5	.3292	.3292	.3155	.3475	.2715	.2715	.3292
6	.3841	.3841	.3547	.3982	.3982	.362	.3982
7	.4938	.5304	.3982	.4656	.4835	.5249	.5249
8	.6036	.6036	.5121	.5249	.5552	.5373	.5973
9	.6447	.5895	.5658	.5658	.6173	.583	.5611
10	.7164	.6485	.6516	.5316	.6001	.6173	.6173
11	.7164	.6516	.6001	.5487	.8589	.583	.6516
12	.7265	.6344	.703	.5487	.703	.6219	.6687
13	.6697	.6401	.6584	.4755	.6036	.6219	.6697
14	.5487	.5973	.543	.4572	.6219	.5853	.5792
15	.6135	.5959	.583	.5068	.6767	.6036	.5792
16	.631	.5658	.5316	.4024	.695	.5973	.6335
17	.6219	.6001	.6173	.4572	.6401	.5611	.6697
18	.7421	.7865	.7701	.5853	.7682	.6401	.7602
19	.8962	.8238	.8775	.724	.8596	.8413	.8326
20	.8063	.7865	.7964	.7059	.8048	.8048	.7701
21	.7682	.695	.6626	.6697	.7316	.6984	.6335
22	.6584	.5853	.543	.543	.5792	.543	.5611
23	.4755	.4938	.4024	.3292		.362	.3439
24	.3658	.3856	.4024	.362	.2896	.2896	.2926
Max	**.8962**	**.8238**	**.8775**	**.724**	**.8596**	**.8413**	**.8326**
Min	**.2896**	**.2896**	**.2896**	**.3292**	**.2715**	**.2353**	**.2926**
Avg	**.5673**	**.5471**	**.5303**	**.4784**	**.5600**	**.5094**	**.5356**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
AJARA[022] **BU 1155**
Substation No/ Name :- 144063 / 33/11 KV AJARA
Feeder No / Name : 202 / 11 KV Bhadvan Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9496	.5898	.5426	.1086	.1075	.1448	.0905
2	.8848	.5765	.5256	.1086	.1086	.1448	.0905
3	.8478	.5765	.5256	.1086	.1086	.1267	.0905
4	.8478	.5765	.5256	.1086	.1086	.1267	.0905
5	.8573	.6783	.5426	.1267	.1086	.1267	.0905
6	.8684	.7291	.5765	.1267	.1086	.1267	.1086
7	1.3056	.8987	.763	.1267	.1267	.1629	.1267
8	1.3226	1.0343	.8684	.0686	.1254	.1772	.1433
9	.1448	.1029	.1372	.1578	.1543	.1543	.1886
10	.1448	.12	.1372	1.6461	2.1098	2.4977	.7888
11	.1448	.12	.1372	1.9334	2.3834	2.2131	.8063
12	.1448	.1029	.1372	1.8842	2.332	2.0645	.7042
13	.1267	.0732	.12	1.9989	2.2447	2.2119	1.3375
14	.1052	.0747	.1086	1.8842	2.3594	2.2283	
15	.1052	.0857	.1029	1.8652	2.2939	.3932	2.5549
16	.0701	.0934	.0905	2.0645	2.2119		2.4348
17	.1029	.0857	.0905	2.0153	2.2552	.1696	1.5089
18	.1029	.12	.1267	.1526	.1578		.181
19	.1227	.168	.1267	.1629	.1696	.0848	.1791
20	.1448	.1372	.1267	.1629	.1696	.1187	.197
21	.1187	.1448	.1267	.1448	.1526	.1075	.2149
22	.1187	.1357	.1086	.1448	.1448	.1086	.2328
23	.6062	.5853	.1086	.1267	.1448	.0905	1.406
24	.9496	.6783	.5243	.1267	.1086	.1629	.0905
Max	**1.3226**	**1.0343**	**.8684**	**2.0645**	**2.3834**	**2.4977**	**2.5549**
Min	**.0701**	**.0732**	**.0905**	**.0686**	**.1075**	**.0848**	**.0905**
Avg	**.4640**	**.3536**	**.2991**	**.7231**	**.8456**	**.6246**	**.5938**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
AJARA[022] **BU 1155**
Substation No/ Name :- 144063 / 33/11 KV AJARA
Feeder No / Name : 203 / POLGAON AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0848	.0848	.0876	.5144	.4115	.4115	.3429
2	.0848	.0848	.0848	.5144	.4115	.4115	.3429
3	.0848	.0848	.0848	.5144	.4115	.3944	.3429
4	.0848	.0848	.0848	.5316	.4287	.3944	.3429
5	.0848	.0848	.0848	.5487	.4287	.4115	.3429
6	.0848	.0848	.0848	.6173	.463	.463	
7	.0848	.0848	.0848	.7373	.5487	.5658	
8	.0678	.0655	.0819	.7202	.6687	.6344	.2229
9	.0724	.1029	.0857	.0857	.0876	.0514	.0171
10	1.0974	1.1317	1.1317	.0857	.0351	.0514	.0686
11	1.2003	1.3203	1.2174	.0876	.0328	.0549	.1097
12	1.2517	1.2689	1.2689	.0492	.0366	.0492	.0857
13	1.1831	1.3575	1.3146	.0339	.0328	.0655	.0716
14	1.267	1.2071	1.4842	.0339	.0339	.0678	.0724
15	1.2795	1.3546	1.4918	.0339	.0324	.0655	.0543
16	1.166	1.2003	1.3717	.0328	.0526	.0678	.0543
17	1.1403	1.2986	1.2517	.0328	.0678	.0678	.0724
18	.0732	.0732	.0914	.1029	.0848	.0848	.0724
19	.1029	.0857	.0914	.0724	.0848	.0848	.0895
20	.1086	.0905	.0905	.0724	.0848	.0848	.0362
21	.1017	.0848	.0905	.0724	.0678	.0895	.0362
22	.1017	.0848	.0905	.0724	.0724	.0724	.0362
23	.0819	.0848	.5144	.4287	.4115	.3429	.0362
24	.0848	.0819	.0848	.4973	.4287	.4458	.3429
Max	**1.2795**	**1.3575**	**1.4918**	**.7373**	**.6687**	**.6344**	**.3429**
Min	**.0678**	**.0655**	**.0819**	**.0328**	**.0324**	**.0492**	**.0171**
Avg	**.4572**	**.4786**	**.5146**	**.2705**	**.2258**	**.2264**	**.1451**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
AJARA[022] **BU 1155**
Substation No/ Name :- 144063 / 33/11 KV AJARA
Feeder No / Name : 204 / 11 KV Watangi Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1017	.0857	.0848	.9088	1.046	1.0288	.7545
2	.1017	.0905	.0905	.8916	1.046	1.0288	.7545
3	.1017	.0876	.0848	.8916	1.0288	1.046	.7545
4	.1017	.0848	.0848	.8916	1.046	1.046	.7545
5	.1017	.0848	.0848	.9088	1.0631	1.0631	.7545
6	.1017	.0848	.0848	.9431	1.0802	1.0631	.7545
7	.1187	.0848	.1017	1.0288	1.2003	1.166	.8916
8	.1017	.0848	.0164	1.1488	1.2894	1.2346	.9774
9	.1086	.0857	.12	.1029	.1372		.12
10	1.3717	1.4575	1.5604	.1029	.1227	.0876	.1372
11	1.406	1.4403	1.6289	.1227	.1448	.1029	.1463
12	1.5089	.6173	1.7147	.0339	.1227	.1017	.1402
13	1.6118	1.2971	.4733	.0848	.1187	.0678	.1086
14	1.3394	1.7193	.6516	.0848	.1357	.0819	.0905
15	1.5181	1.7318	1.5432	.0848	.1187	.0848	.1086
16	1.4232	1.8107	1.576	.1187	.1267	.0678	.1086
17	1.286	1.7556	1.6644	.1187	.1017	.1017	.1448
18	.0686	.0876	.112	.1578	.1402	.1357	.1254
19	.1097	.1029	.112	.1267	.1357	.1187	.1595
20	.0876	.1029	.1629	.1402	.1526	.1357	.1772
21	.1017	.1187	.1448	.124	.1526	.1267	.1448
22	.1017	.1227	.1267	.1448	.1629	.1254	.1086
23	.0848	.1052	.9088	.9945	.9945	.7545	.1086
24	.1017	.0848	.1017	.9088	1.0631	1.0631	.7545
Max	**1.6118**	**1.8107**	**1.7147**	**1.1488**	**1.2894**	**1.2346**	**.9774**
Min	**.0686**	**.0848**	**.0164**	**.0339**	**.1017**	**.0678**	**.0905**
Avg	**.5442**	**.5553**	**.5514**	**.4610**	**.5304**	**.5145**	**.3783**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
AJARA[022] **BU 1155**
Substation No/ Name :- 144063 / 33/11 KV AJARA
Feeder No / Name : 205 / 11 KV WATANGI VG **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.2126	.2172	.2195	.2534	.2172	.2012
2	.1715	.2035	.2172	.2012	.2353	.1991	.181
3	.1715	.2195	.2126	.1829	.2172	.181	.1829
4	.1715	.2195	.2103	.1829	.2172	.181	.1829
5	.2172	.2195	.2561	.2378	.2172	.1991	.2378
6	.2543	.2561	.2926	.3258	.3258	.2896	.3258
7	.4207	.4024	.4207	.4344	.4525	.4298	.4163
8	.567	.5121	.5249	.4344	.4887	.5014	.4706
9	.4344	.6001	.3601	.4287	.5144	.4801	.4801
10	.3898		.463	.3601	.333	.3944	.4207
11	.362	.4458	.463	.3475	.5014	.3429	.3258
12	.3439	.5316	.3601	.3475	.4458	.3658	.3801
13	.2896	.5316	.2915	.3658	.439	.3292	.3439
14	.2915	.4458	.2743	.2896	.3475	.3439	.2715
15	.2229	.3944	.3944	.2561	.4024	.3292	.2561
16	.2427	.4207	.3856	.3292	.3475	.3292	.2926
17	.2572	.3944	.4458	.3429	.3658	.3429	.3258
18	.543	.5975	.6173		.4572	.4938	.543
19	.7716	.7202	.8402	.8145	.8145	.8145	.8326
20	.8059	.7373	.8145	.7783	.8413	.8413	.788
21	.6878	.7133	.6697	.6733	.7316	.6697	.5792
22	.4755	.4938	.5068	.4344	.4163	.3982	.3982
23	.2926	.3109	.2896	.2896	.2896	.2715	.2534
24	.2254	.2481	.2561	.2534	.2715	.1238	.2195
Max	**.8059**	**.7373**	**.8402**	**.8145**	**.8413**	**.8413**	**.8326**
Min	**.1715**	**.2035**	**.2103**	**.1829**	**.2172**	**.1238**	**.181**
Avg	**.3659**	**.4274**	**.4077**	**.3709**	**.4136**	**.3779**	**.3712**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
AJARA[022] **BU 1155**
Substation No/ Name :- 144063 / 33/11 KV AJARA
Feeder No / Name : 206 / 11 KV MIDC feeder **SHEDDABLE FEEDER HAVING WEEKLY**
Feeder KV- 11 / OUTGOING **STAGGERING (MIDC, EQUIVALENT)**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0509	.0328	.0339	.0181	.0362	.0362	.0362
2	.0509	.0343	.0328	.0181	.0362	.0362	.0362
3	.0509	.0339	.0339	.0181	.0362	.0362	.0362
4	.0509	.0339	.0339	.0181	.0351	.0362	.0362
5	.0509	.0339	.0339	.0181	.0362	.0362	.0362
6	.0509	.0343	.017	.0183	.0362	.0362	.0362
7	.0509	.0339	.0339	.0181	.0543	.0724	.0362
8	.0848	.0678	.0678	.0724	.0724	.0724	.0362
9	.0724	.0686	.0686	.0686	.0686	.0686	.0514
10	.0724	.0686	.0514	.0171	.0914	.0747	.0514
11	.0905	.0686	.1029	.017	.0857	.1029	.0526
12	.1075	.0343	.1029	.017	.0724	.0848	.0514
13	.1448	.12	.0857	.0339	.0848	.1526	.0905
14	.1097	.1715	.0732	.0328	.12	.1696	.0724
15	.0886	.168	.1052	.0164	.1526	.1526	.0905
16	.128	.0914	.1267	.017	.0848	.1017	.0905
17	.124	.12	.0934	.0339	.1017	.1017	.0905
18	.1052	.0914	.0701	.0164	.0678	.0848	.0724
19	.1086	.1029	.0934	.0181	.0678	.0678	.0905
20	.0857	.0857	.0724	.0181	.0678		.0724
21	.0686	.0848	.0543	.0181	.0509	.0543	.0362
22	.0339	.0509	.0181	.0181	.0362	.0362	.0181
23	.0339	.0328	.0181	.0543	.0362	.0362	.0543
24	.0509	.0339	.0339	.0181	.0362	.0543	.0362
Max	**.1448**	**.1715**	**.1267**	**.0724**	**.1526**	**.1696**	**.0905**
Min	**.0339**	**.0328**	**.017**	**.0164**	**.0351**	**.0362**	**.0181**
Avg	**.0777**	**.0708**	**.0607**	**.0256**	**.0653**	**.0741**	**.0546**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
AJARA[022] **BU 1155**
Substation No/ Name :- 144063 / 33/11 KV AJARA
Feeder No / Name : 207 / 11 KV Bhadvan Vg **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1311	.1753	.1928	.181	.181		.1829
2	.1372	.1402	.1578	.181			.1829
3	.1372	.1402	.1646	.1629	.181		.1646
4	.1543	.1402	.1578	.1629	.181		.1646
5	.2534	.2103	.1928	.1991	.181		.2195
6	.2743	.2561	.2195	.2172	.2896		.2715
7	.3841	.3292	.2896	.2865	.3582		.3439
8	.4207	.3658	.3801	.3439	.3801	.4163	.3982
9	.4163	.3772	.3772	.3258	.4115	.3944	.4458
10	.362	.3429	.3944	.3258	.4525	.4458	.4287
11	.362	.2743	.3258	.2561	.4207	.4287	.3944
12	.362	.2743	.2915	.3155	.3258	.3898	.3772
13	.3258	.2195	.2915	.3475	.3292	.3189	.2534
14	.2629	.2561	.2743	.2896	.3155	.2743	.2686
15	.2572	.2279	.2629	.1991	.298	.2534	.2715
16	.2103	.2229	.3658	.2454	.3077		.2896
17	.2534	.2572	.3086	.3258	.3077	.2896	.3258
18	.439	.3429	.3944	.3801	.3841		.3077
19	.6984	.6401	.6485	.6697	.6401	.7133	.6335
20	.7059	.6535	.6335	.6154	.6584	.724	.6089
21	.6036	.5487	.5249	.5304	.6036	.5552	.4344
22	.439	.4207	.4024	.362	.3801	.3439	.3258
23	.2629	.2743	.2378	.2012	.2534	.2328	.1991
24	.1715	.2195	.2279	.2172	.1991		.1829
Max	**.7059**	**.6535**	**.6485**	**.6697**	**.6584**	**.724**	**.6335**
Min	**.1311**	**.1402**	**.1578**	**.1629**	**.181**	**.2328**	**.1646**
Avg	**.3344**	**.3046**	**.3215**	**.3059**	**.3495**	**.4129**	**.3198**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
AJARA[022] **BU 1155**
Substation No/ Name :- 144063 / 33/11 KV AJARA
Feeder No / Name : 405 / 33 KV Amboli **NON SHEDDABLE EXPRESS HV FEEDERS**
Feeder KV- 33 / OUTGOING **(NON-CONTINOUS PROCESS)(NO STAGGERING)**

DATE	27-DEC-17
HR	Load (MW)
1	.0572
2	.0572
3	.0572
4	.0572
5	.0572
6	.0572
7	.0572
23	.052
24	.543
Max	**.543**
Min	**.052**
Avg	**.1106**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
AJARA[022] **BU 1155**
Substation No/ Name :- 144084 / 33/11 KV Uttur
Feeder No / Name : 201 / 11KV UtturVg. **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4656	.4481	.3326	.3696	.5014	.5228	.4481
2	.4656	.4108	.3361	.3326	.5014	.4854	.3696
3	.4656	.4108	.2987	.3326	.4656	.4481	.3696
4	.5014	.4854	.2987	.3326	.5373	.4481	.4108
5	.6089	.5228	.3734	.4066	.6089	.4854	.4481
6	.6805	.6535	.5975	.4805	.6805	.6348	.5788
7	.7164	.7842	.7762	.6283	.7164	.7468	.7095
8	.7522	.8215	.8402	.7392	.7522	.8589	.7468
9	.8238	.7842	.8962	.7392	.7522	.8029	.8402
10	.8596	.7468	.8215	.6805	.7164	.7468	.7842
11	.7468	.6348	.7762	.6089	.6722	.7468	.7392
12	.7095	.6348	.6653	.5731	.6348	.6283	.6653
13	.6722	.462	.5914	.5373	.6348	.6468	.6653
14	.6348	.5975	.5914	.5373	.5975	.5601	.6283
15	.6722	.6348	.5175	.5731	.5975	.5729	.6283
16	.6722	.6722	.5914	.6089	.6348	.5601	.6653
17	.6908	.6908	.5914	.6447	.6722	.6348	.5914
18	.7842	.8589	.8131	.9313	.7842	.8029	.8686
19	1.2696	1.307	1.3676	1.2894	1.2696	1.3121	1.3121
20	1.307	1.2323	1.2936	1.2178	1.3256	1.2752	1.2012
21	1.0829	1.0829	.9979	1.1462	1.0082	1.0829	.9979
22	.8215	.8029	.8686	.8954	.8589	.8402	.7392
23	.5975	.5415	.5544	.5731	.6348	.5975	.4805
24	.5014	.5041	.3734	.4251	.5373	.5144	.4854
Max	**1.307**	**1.307**	**1.3676**	**1.2894**	**1.3256**	**1.3121**	**1.3121**
Min	**.4656**	**.4108**	**.2987**	**.3326**	**.4656**	**.4481**	**.3696**
Avg	**.7293**	**.6969**	**.6735**	**.6501**	**.7123**	**.7065**	**.6822**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
AJARA[022] BU 1155
Substation No/ Name :- 144084 / 33/11 KV Uttur
Feeder No / Name : 202 / 11KV Bahirewadi Ag. SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0324	.0503	.0486	.208	.2429	.3361	.2372
2	.0324	.0503	.048	.208	.3077	.3361	.2241
3	.0324	.0503	.048	.208	.2968	.2987	.2214
4	.0486	.0503	.0486	.208	.421	.2987	.2372
5	.0486	.0503	.0486	.2241	.5182	.3361	.2753
6	.0648	.0503	.0486	.2561	.5668	.3734	.3953
7	.0648	.0838	.0648	.4801	.583	.8402	.578
8	.0648	.0838	.0633		.9393	1.0082	.8381
9	.0648	.0857	.064	.048	.0648	.0686	.0633
10	.8583	.7842	.8381	.081	.081	.0686	.081
11	1.1949	.9231	1.0402	.081	.0709	.0709	.08
12	1.307	1.1336	1.1203	.0648	.0671	.048	.064
13	1.3443	1.1523	1.2003	.0648	.0838	.0486	.064
14	1.4003	1.2483	1.2483	.0648	.0838	.048	.048
15	1.4563	1.1043	1.2803	.0648	.0671	.048	.048
16	1.4563	1.1984	1.2643	.081	.0671	.0486	.064
17	1.2883	1.1012	1.0722	.081	.0838	.0625	.064
18	.0838	.0648	.08	.0648	.0838	.081	.064
19	.0838	.064	.064	.0648	.0838	.064	.064
20	.0838	.0648	.064	.0648	.0671	.064	.064
21	.0671	.0648	.0709	.0648	.0671	.0648	.064
22	.0671	.0648	.064	.0648	.0671	.048	.048
23	.0503	.064	.208	.2267	.2241	.2372	.048
24	.0324	.0503	.0486	.2241	.2429	.3361	.2401
Max	**1.4563**	**1.2483**	**1.2803**	**.4801**	**.9393**	**1.0082**	**.8381**
Min	**.0324**	**.0503**	**.048**	**.048**	**.0648**	**.048**	**.048**
Avg	**.4678**	**.4016**	**.4228**	**.1391**	**.2242**	**.2181**	**.1740**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
AJARA[022] **BU 1155**
Substation No/ Name :- 144084 / 33/11 KV Uttur
Feeder No / Name : 203 / MAHAGOND AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2353	.2241	.3898	.0532	.0543	.0354	.0354
2	.2353	.1867	.3814	.0532	.0543	.0177	.0354
3	.2534	.1494	.3898	.0532	.0543	.0177	.0354
4	.2534	.1494	.3814	.0532	.0543	.0354	.0351
5	.2353	.2614	.3856	.0532	.0543	.0354	.0354
6	.2172	.3734	.3856	.0532	.0543	.0177	.0354
7	.2353	.4854	.4334	.0709	.0543	.0532	.0526
8	.2534	.0177	.5609	.0354	.0543	.0532	.052
9	.0543	.0177	.0532	.0354	.0543	.0177	.052
10	.0724	.0532	.0526	.5068	.2896	.4854	.5028
11	.0177	.0354	.0532	.4344	.4668	.5487	.6024
12	.0532		.0354	.4344	.6348	.6241	.6379
13	.0177	.0351	.0532	.362	.6908	.6415	.6733
14	.0177	.0354	.0709	.362	.6722	.6024	.815
15	.0177	.0354	.0709	.3439	.7095	.6173	.9568
16	.0177	.0354	.0709	.3258	.6733	.6588	.9922
17	.0177	.0354	.0709	.3258	.7282	.5895	.9568
18	.0373	.0351	.0354	.0543	.0532	.052	.0532
19	.0177	.0532	.0532	.0543	.0532	.0526	.0532
20	.0177	.0532	.0709	.0543	.0532	.0354	.0709
21	.0177	.0532	.0532	.0543	.0177	.0532	.0532
22	.0177	.0354	.0532	.0543	.0177	.0532	.0532
23	.1867	.3856	.0354	.0543	.0177	.052	
24	.2172	.2241	.3856	.0354	.0543	.0354	.0354
Max	**.2534**	**.4854**	**.5609**	**.5068**	**.7282**	**.6588**	**.9922**
Min	**.0177**	**.0177**	**.0354**	**.0354**	**.0177**	**.0177**	**.0351**
Avg	**.1132**	**.1291**	**.1886**	**.1632**	**.2342**	**.2244**	**.2967**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
AJARA[022] **BU 1155**
Substation No/ Name :- 144087 / 33/11 Maligre
Feeder No / Name : 201 / 11 KV Kanoli Vg. **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2402	.208	.2534	.2229	.2241	.208	.2896
2	.2241	.2058	.2896	.2058	.2241	.208	.2896
3	.2241	.208	.2896	.2229	.2427	.208	.2715
4	.2614	.2401	.2896	.2401	.2614	.2427	.2715
5	.3361	.2743	.3258	.2572	.3361	.2774	.2896
6	.4481	.3772	.2896	.3086	.4108	.3856	.3258
7	.5601	.4801	.3982	.3772	.5041	.4801	.3982
8	.5788	.4508	.4344	.4973	.5415	.4458	.543
9	.5601	.4458	.5068	.463	.5028	.4287	.4706
10	.3921	.4801	.5068	.4458	.4973	.4508	.3429
11	.3429	.3601	.3944	.3944	.4115	.4287	.3429
12	.2774	.298			.2401	.3258	.3258
13	.2401	.3086	.2229		.2401	.3258	.3086
14	.2427	.3052	.2229			.2896	.2743
15	.2401	.3258		.2801	.3121	.2715	.2401
16	.2629	.362		.2987	.2743	.362	.2229
17	.4115	.3982		.3361	.3772	.3801	.3601
18	.4801	.543	.3086	.462	.4287	.543	.4115
19	.7202	.7602		.6767		.724	.6859
20	.703	.543		.6535	.6516	.6878	.6516
21	.583	.5068		.6348	.5487	.6516	.5658
22	.4115	.5068		.4715	.4161	.4706	.3944
23	.2572	.3258		.3395	.2743	.3077	.3086
24	.2614	.2401	.2896	.2229	.2427	.2401	.2896
Max	**.7202**	**.7602**	**.5068**	**.6767**	**.6516**	**.724**	**.6859**
Min	**.2241**	**.2058**	**.2229**	**.2058**	**.2241**	**.208**	**.2229**
Avg	**.3858**	**.3814**	**.3348**	**.3815**	**.3710**	**.3893**	**.3698**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
AJARA[022] **BU 1155**
Substation No/ Name :- 144087 / 33/11 Maligre
Feeder No / Name : 202 / 11KV Sarambalwadi Ag. **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4481	.7975	.7964	.0343	.0362	.0347	.0543
2	.4534	.7888	.8326	.0343	.0362	.0347	.0543
3	.4858	.823	.9774	.0343	.0362	.0343	.0543
4	.5182	.823	1.0136	.0343	.0373	.0347	.0543
5	.5506	.823	1.0136	.0343	.0543	.0351	.0543
6	.6447	.8669	1.0136	.0343	.0543	.0343	.0543
7	.6401	.9602	1.0136	.0343	.0724	.0343	.0362
8	.6722		.9774	.0343	.0724	.0343	.0724
9	.0358	.0173	.0543	.0343	.0343	.0171	.0362
10	.0358	.0171	.0362	1.166	1.387	1.166	1.2346
11	.0173	.0171	.0181	1.3032	1.3717		1.3717
12	.0171	.0177		1.3413	1.3717	1.448	1.2193
13	.0171	.0181		1.2803	1.4563	1.448	1.2193
14	.0171	.0181		1.4083		1.3756	1.2193
15	.0171	.0362		1.3603	1.4403	1.3756	1.2193
16	.0173	.0362		1.2955	1.4563	1.448	1.2193
17	.0173	.0362		1.2803	1.3717	1.3032	1.1584
18	.0343	.0362		.0358	.0171	.0543	.0686
19	.0343	.0362		.0716		.0724	.0686
20	.0347	.0362		.0724	.0347	.0724	.0686
21	.0343	.0362		.0724	.0343	.0543	.0686
22	.0693	.0362		.0724	.0343	.0543	.0686
23	.7545	.7964		.0554	.0347	.0543	.6706
24	.4534	.7545	.7964	.0343	.0358	.0343	.0543
Max	**.7545**	**.9602**	**1.0136**	**1.4083**	**1.4563**	**1.448**	**1.3717**
Min	**.0171**	**.0171**	**.0181**	**.0343**	**.0171**	**.0171**	**.0362**
Avg	**.2508**	**.3404**	**.7119**	**.4649**	**.4763**	**.4458**	**.4750**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
AJARA[022] BU 1155
Substation No/ Name :- 144087 / 33/11 Maligre
Feeder No / Name : 203 / 11 kv Kolindre Ag. SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1075	.1029	.0724	.4877	.4641	.583	.5792
2	.1086	.1029	.0543	.5487	.4641	.6173	.543
3	.1086	.104	.0543	.5487	.4801	.583	.543
4	.1086	.1029	.0543	.583	.5121	.5548	.543
5	.1086	.1052	.0543	.5792	.5441	.6173	.6516
6	.1097	.1029	.0543	.5792	.6081	.6859	.6878
7	.128	.0867	.0543	.6097	.6722	.7202	.6878
8	.1307	.1029	.0724	.6706	.7362	.7545	.724
9	.1448	.1029	.0724	.12		.1387	.0724
10	.8002	.583	.9774	.1029	.1214	.1029	.1029
11	.8573	.6173	1.0136	.1029	.12		.1372
12	.9015	.8859		.0543	.1372	.1086	.1372
13	.9709	.9503		.0724	.1402	.1086	.1372
14	1.0517	.9831		.1086		.1086	.1372
15	1.0056	1.086		.1086	.1052	.1267	.1372
16	.9602	1.0498		.0905	.1029	.1086	.12
17	.6516	1.0498		.1086	.1029	.1086	.1029
18	.104	.0724		.1075	.104	.1086	.1029
19	.1052	.0724		.1086		.1086	.1029
20	.0857	.0724		.1075	.104	.1086	.12
21	.0857	.0724		.1267	.1029	.1086	.12
22	.1029	.0724		.1294	.1029	.0905	.1029
23	.1029	.0724		.4531	.583	.5792	.1029
24	.1075	.104	.0724	.4877	.4534	.583	.5792
Max	**1.0517**	**1.086**	**1.0136**	**.6706**	**.7362**	**.7545**	**.724**
Min	**.0857**	**.0724**	**.0543**	**.0543**	**.1029**	**.0905**	**.0724**
Avg	**.3728**	**.3607**	**.2172**	**.2915**	**.3220**	**.3354**	**.3031**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
AJARA[022] **BU 1155**
Substation No/ Name :- 144107 / 33/11 KV Gavase
Feeder No / Name : 201 / 11 KV Devarde Vg. **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.1097	.1307	.1357	.1494	.1494	.1433
2	.1254	.112	.1109	.1372	.132	.1294	.1052
3	.1254	.112	.112	.1052	.132	.1307	.1063
4	.1402	.1097	.112	.1052	.132	.1307	.1052
5	.1402	.1307	.1307	.1063	.1478	.1509	.1052
6	.1829	.1478	.1848	.1791	.1663	.1509	.1463
7	.2561	.2926	.2241	.2172	.2012	.1867	.2195
8	.2686	.3224	.2218	.3121	.2896	.2587	.2957
9	.298	.2804	.3361	.3688	.3258	.3734	.3086
10	.3944	.3429	.3582	.4207	.4435	.3696	.3761
11	.3772	.3544	.3856	.3582	.439	.3429	.4298
12	.3155	.3582	.2561	.3189	.3982	.3898	.3982
13	.2534	.3582	.4207	.3582	.3658	.3429	.2572
14	.1267	.3721	.4557	.298	.362	.2401	.2622
15	.1753	.3982	.4161	.3944	.2926	.2622	.2713
16	.1753	.362	.3814	.3475	.3658	.3429	.2774
17	.208	.1848	.4908	.4252	.4435	.4161	.3224
18	.2987	.4066	.5258	.4119	.4481	.362	.3224
19	.4435	.5175	.5792	.5121	.4854	.4435	.415
20	.4656	.4481	.4805	.4251	.4481	.4066	.4338
21	.3258	.3772	.3696	.3696	.3772	.3361	.3395
22	.2149	.2641	.2241	.2587	.2614	.2587	.2641
23	.1448	.1867	.1753	.1646	.2075	.2195	.2075
24	.1646	.124	.1478	.1341	.1494	.1509	.181
Max	**.4656**	**.5175**	**.5792**	**.5121**	**.4854**	**.4435**	**.4338**
Min	**.1254**	**.1097**	**.1109**	**.1052**	**.132**	**.1294**	**.1052**
Avg	**.2396**	**.2780**	**.3013**	**.286**	**.2985**	**.2727**	**.2622**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
AJARA[022] BU 1155
Substation No/ Name :- 144107 / 33/11 KV Gavase
Feeder No / Name : 202 / 11 KV Velvatti Ag. SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0175	.0189	.0183	.096	.0503	.0838	.0633
2	.0171	.0191	.0362	.0972	.0503	.0663	.064
3	.0171	.0191	.0366	.0983	.0492	.0663	.0648
4	.017	.0189	.0183	.0983	.0492	.0838	.064
5	.0175	.0189	.037	.0972	.0497	.0829	.064
6	.0183	.0377	.0366	.1134	.0663	.0995	.0648
7	.0187	.0377	.0366	.2012	.1174	.1341	.0937
8	.0179	.0373	.0181	.2155	.1492	.1844	.1265
9	.0351	.0187	.0183	.0351	.0189		.0358
10	.285	.3391	.3391	.0381	.0187	.0179	.0373
11	.3277	.3856	.3521	.0189	.0183	.0189	.0377
12	.3978	.4024	.3856	.0189	.0181	.0187	.0377
13	.3932	.4527	.3277	.0187	.0179	.0187	.0189
14	.3361	.4807	.3149	.0189	.0181	.0187	.0168
15	.3077	.4694	.3018	.0181	.0181	.0168	.0189
16	.3605	.4144	.3647	.0183	.0183	.0181	.0187
17	.3206	.3441	.3812	.0189	.0185	.037	.0187
18	.0185	.0181	.0377	.0189	.037	.0377	.0377
19	.0373	.0366	.0377	.0377	.037	.0377	.0377
20	.037	.0366	.0377	.0377	.0373	.0381	.0377
21	.0362	.0185	.0377	.0377	.0373	.0373	.0373
22	.0347	.037	.0373	.0373	.037	.0377	.0373
23	.0373	.0183	.0949	.048	.0857	.0663	.0373
24	.0179	.0377	.0185	.0949	.0492	.0848	.0791
Max	**.3978**	**.4807**	**.3856**	**.2155**	**.1492**	**.1844**	**.1265**
Min	**.017**	**.0181**	**.0181**	**.0181**	**.0179**	**.0168**	**.0168**
Avg	**.1302**	**.1549**	**.1385**	**.0639**	**.0445**	**.0568**	**.0479**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
AJARA[022] BU 1155
Substation No/ Name :- 144107 / 33/11 KV Gavase
Feeder No / Name : 203 / 11 KV Kittawade Ag. SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.503	.4858	.0934	.0716	.0732	.0572
2	.503	.5087	.5079	.0943	.0739	.0732	.0572
3	.503	.4915	.5079	.0934	.0747	.0739	.0566
4	.503	.503	.4973	.0934	.0747	.0732	.0566
5	.5144	.5087	.4807	.0943	.0754	.0739	.0572
6	.583	.5243	.4973	.0953	.0732	.0739	.0566
7	.6687	.6371	.5138	.0905	.0905	.0732	.056
8	.6962	.6964	.639	.0934	.0716	.0732	.0554
9	.0943	.0747	.0895	.1143	.0934	.0924	.0747
10	.0943	.0566	.0716	.8886	.9945	.9835	.9724
11	.0754	.0739	.0895	1.046	1.1191	1.2346	1.0852
12	.1132	.0732	.0709	1.0288	.9221	1.2346	1.166
13	.112	.0716	.0739	1.0974	.9835	1.2517	
14	.0943	.0724	.0934	1.0631	1.0802	1.3003	1.0242
15	.0943	.0724	.0747	1.0288	1.1869	1.2887	1.0898
16	.0953	.0724	.0934	1.1145	1.2887	1.3226	1.1736
17	.0943	.0905	.0934	1.0802	.8718	1.1603	.8288
18	.0747	.0914	.0943	.0934	.0895	.0566	.0747
19	.0943	.0914	.1109	.0943	.1097	.0747	.0754
20	.0943	.0914	.1109	.112	.1109	.0943	.0754
21	.0943	.0924	.1097	.0934	.0924	.0747	.0754
22	.0934	.0732	.0924	.0934	.0747	.0754	.0754
23	.4858	.4641	.0943	.0732	.0739	.056	
24	.5144	.5079	.4915	.0934	.0716	.0739	.0572
Max	**.6962**	**.6964**	**.639**	**1.1145**	**1.2887**	**1.3226**	**1.1736**
Min	**.0747**	**.0566**	**.0709**	**.0732**	**.0716**	**.056**	**.0554**
Avg	**.2835**	**.2684**	**.2493**	**.4110**	**.4070**	**.4568**	**.3773**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] **BU 1147**
Substation No/ Name :- 144059 / 33/11 KOWAD
Feeder No / Name : 201 / 11 KV KOWAD VG **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2172		.2195		
2		.1966	.2172		.2172		
3			.2172		.2172	.1638	
4		.2012	.2172		.2172		
5	.2172		.2172		.2172		
6	.362	.3052	.362	.2743	.2896		.3086
7	.5121	.5487	.543	.4801	.543	.5144	.4801
8	.6154	.5487	.5792	.5487	.543	.5487	.5144
9		.583	.543		.7468	.543	.6722
10		.6516	.4961	.4748	.6722	.6154	.5975
11	.4748	.5144	.4706		.5601	.543	.6219
12			.4344		.5601	.5792	.4481
13		.4115	.3982		.4854	.4207	.4108
14	.407		.362		.4108	.2534	.3734
15	.407	.4115	.4344	.3391	.4481	.4344	
16	.4409	.5068			.5601		.5601
17		.543	.4115	.4706			.5068
18	.6104	.724	.5144	.5792		.5487	.6024
19	.6859	.905		.8688			.815
20		.905		.7964		.8573	.724
21	.6241	.5959		.724			.631
22	.4458	.4252	.5144	.4706		.4458	.4607
23		.362	.4115	.2172		.2743	.2896
24	.2534	.2347	.3258	.3086	.2172	.2683	.2743
Max	**.6859**	**.905**	**.5792**	**.8688**	**.7468**	**.8573**	**.815**
Min	**.2172**	**.1966**	**.2172**	**.2172**	**.2172**	**.1638**	**.2743**
Avg	**.4658**	**.5039**	**.3943**	**.5040**	**.4191**	**.4674**	**.5162**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] **BU 1147**
Substation No/ Name :- 144059 / 33/11 KOWAD
Feeder No / Name : 202 / 11 KV Kagani Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					1.448		
2					1.448		
3					1.448	1.4175	
4					1.4175		
5					1.4175		
6				1.6766	1.5074		1.2407
7				1.7436	1.6289	1.4746	1.3748
8				1.8107	1.8099	1.6126	1.3413
9					.0381		.0381
10		1.7436	2.7149		.0381		.0381
11	2.8045	1.9448	3.2579		.0381		.0381
12			3.2579		.0381		.0381
13		3.0178	3.2579		.0381		.0381
14	2.8746		3.2941		.0381		.0381
15	2.9096	3.0849	3.0769		.0381		.0381
16	2.9447	3.0769			.0381		.0381
17	2.9412	2.7149	2.6155				
23				1.448		1.2407	
24				1.8442	1.448	1.4022	1.2407
Max	**2.9447**	**3.0849**	**3.2941**	**1.8442**	**1.8099**	**1.6126**	**1.3748**
Min	**2.8045**	**1.7436**	**2.6155**	**1.448**	**.0381**	**1.2407**	**.0381**
Avg	**2.8949**	**2.5972**	**3.0679**	**1.7046**	**.8164**	**1.4295**	**.4585**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] BU 1147
Substation No/ Name :- 144059 / 33/11 KOWAD
Feeder No / Name : 203 / 11 KV Kudnoor Vg GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3155		.2804		
2		.1966	.3258		.2804		
3			.3258		.2896	.1677	
4		.1658	.3258		.2804		
5	.2896		.362		.2774		
6	.3506	.2683	.4344	.3429			.4801
7	.7011	.5487	.4961	.4115		.4748	.5487
8	.5792	.5487	.5792	.4115	.5792	.5426	
9		.6173	.5792		.6348	.6516	.6722
10		.6173	.7087	.3688	.7468	.6516	.6348
11	.6783	.6173	.6516		.6722	.6516	.5975
12			.5792		.6348	.6516	.5601
13		.5144	.543		.5228	.5068	
14	.4409		.4344		.4755	.4344	.4854
15	.407	.4115	.5068	.2347	.4854	.4344	.4481
16	.373	.543			.5228		.4854
17		.5316	.5487	.4344			.4344
18	.407	.567	.4115	.4344		.5487	.5792
19	.5144	.5316		.3982			.5609
20		.5068		.4024		.6859	.543
21	.4801	.4344		.362			.5068
22	.3018	.4344	.4115	.362		.4115	.3544
23		.3258		.2896		.4115	.2896
24	.3258	.2347	.3258	.3429	.2896	.2347	.4115
Max	**.7011**	**.6173**	**.7087**	**.4344**	**.7468**	**.6859**	**.6722**
Min	**.2896**	**.1658**	**.3155**	**.2347**	**.2774**	**.1677**	**.2896**
Avg	**.4499**	**.4534**	**.4666**	**.3689**	**.4648**	**.4973**	**.5054**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] **BU 1147**
Substation No/ Name :- 144059 / 33/11 KOWAD
Feeder No / Name : 204 / 11 KV KUDNOOR AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3258				
2		.3688	.3258				
3			.3189				
4		.373	.3544				
5	.3506		.362				
6	.4344	.407	.3982				
7	.5068	.407	.4252				
8	.5792	.4694	.4908				
9					.0381		.0381
10				.6783	.8421		.9282
11					.9282	.5792	.9922
12					.9503	.5792	1.0242
13					1.0364	.724	1.004
14					1.0688	1.0136	.9602
15				1.0288	1.0059	.724	.9282
16					.9503		.8322
17				1.0136			.7964
23		.362					.362
24	.3982	.3391	.362				
Max	**.5792**	**.4694**	**.4908**	**1.0288**	**1.0688**	**1.0136**	**1.0242**
Min	**.3506**	**.3391**	**.3189**	**.6783**	**.0381**	**.5792**	**.0381**
Avg	**.4538**	**.3895**	**.3737**	**.9069**	**.8525**	**.724**	**.7866**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] BU 1147
Substation No/ Name :- 144059 / 33/11 KOWAD
Feeder No / Name : 205 / 11 KV KAGANI VG GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0362				
2			.0362		.0724		
3		.0328	.0362		.0724	.0328	
4			.0362		.0701		
5	.0354		.0362		.0724		
6	.0724	.0655	.0724	.0686	.0724	.1006	.0686
7	.1086	.1006	.1086	.1372	.1448	.1357	.1029
8	.1086	.1372	.1417	.1372	.1448	.1357	.1372
9		.1372	.1448		.1867	.1417	.1494
10		.1029	.1448	.1341	.112	.1417	.112
11	.1341	.1029	.1448		.1494	.1417	.112
12			.1448		.112	.1417	.112
13		.0686	.1063		.0747	.1063	.0747
14	.1006		.0724		.0747	.0732	.0747
15		.0686	.0362	.0671	.0747		.0747
16		.0724			.0747		.0747
17		.0709	.1029	.0724			.0709
18	.1017	.0709	.1372	.0724		.1029	.0724
19	.1341	.1402		.1086			.1448
20		.1772		.1448		.2058	.1448
21	.1696	.1086		.1086			.1086
22	.1357	.0724	.1029	.0724		.1029	.0709
23		.0724	.1029	.0724		.0686	.0724
24	.0362	.0335	.0724	.0686	.0701	.0328	.0686
Max	**.1696**	**.1772**	**.1448**	**.1448**	**.1867**	**.2058**	**.1494**
Min	**.0354**	**.0328**	**.0362**	**.0671**	**.0701**	**.0328**	**.0686**
Avg	**.1034**	**.0908**	**.0908**	**.0973**	**.0986**	**.1109**	**.0972**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] **BU 1147**
Substation No/ Name :- 144059 / 33/11 KOWAD
Feeder No / Name : 206 / 11 KV Hemrus
Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS (NON-CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0724		.0732		
2			.0724		.0724		
3		.0335	.0724		.0724	.0332	
4			.0724		.0701	.0335	
5	.0724	.0332	.0724		.0724		
6	.0366	.0328	.0724	.0343	.0724	.0663	.0686
7	.0362	.0335		.0343	.0724	.0671	
8		.0343		.0343		.0335	.0343
9		.0343			.0762		.0381
10		.0343		.0335	.0747		.0381
11	.0335	.0343			.0747	.0362	.0381
12					.0747		.0381
13		.0343			.0747		.0381
14	.0335				.0381		.0381
15		.0686	.0724	.0335	.0381	.0724	.0381
16		.0724			.0747		.0747
17	.0671	.0709	.0686	.0701			.0724
18	.0678	.0709	.0686	.0709		.0686	.0709
19		.0724		.0709			.0701
20		.0709		.0701		.0686	.0701
21		.0724		.0709			.0709
22		.0724	.0686	.0724		.0686	.0709
23		.0709	.0686	.0701		.0686	.0709
24	.0709	.0335	.0724	.0686	.0724	.0671	.0686
Max	**.0724**	**.0724**	**.0724**	**.0724**	**.0762**	**.0724**	**.0747**
Min	**.0335**	**.0328**	**.0686**	**.0335**	**.0381**	**.0332**	**.0343**
Avg	**.0523**	**.0516**	**.0711**	**.0565**	**.0690**	**.0570**	**.0561**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] **BU 1147**
Substation No/ Name :- 144059 / 33/11 KOWAD
Feeder No / Name : 207 / Nrusinhwadi Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.2454		
2					.2454		
3					.2454	.2035	
4					.2454		
5					.2534		
6				.503	.2896		.2012
7				.5365	.362	.2374	.2347
8				.57	.4344	.373	.2683
9					.0381		.0381
10		1.0395	1.2403		.0191		.0381
11	.9156	1.2742	1.448		.0381		.0381
12			1.4842		.0381		.0381
13		1.2742	1.5203		.0381		.0381
14	.9602		.1086		.0381		.0381
15	.9496	1.3375	1.3756		.0381		.0381
16		1.448			.0381		
17	.9602	1.2403	1.1401				
23			.4024	.2534		.1677	
24				.4024	.2454	.2035	.2012
Max	**.9602**	**1.448**	**1.5203**	**.57**	**.4344**	**.373**	**.2683**
Min	**.9156**	**1.0395**	**.1086**	**.2534**	**.0191**	**.1677**	**.0381**
Avg	**.9464**	**1.2690**	**1.0899**	**.4531**	**.1678**	**.2370**	**.1066**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] **BU 1147**
Substation No/ Name :- 144059 / 33/11 KOWAD
Feeder No / Name : 208 / RAJGOLI AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7545	.5487				
2			.543				
3		.8139	.5316				
4			.5609				
5	.631	.823	.6379				
6	.724		.7087				
7	.7964		.8688				
8	.8688		.9114				
9					.0381		.0381
10				1.0174	.9922	1.086	1.0562
11		.6706			1.1843	1.2308	1.0883
12					1.1984	1.3032	1.0883
13					1.1203	1.3032	1.1203
14					1.1336	1.262	1.166
15				1.153	1.1336	1.3032	1.1523
16					1.1336		1.1523
17				1.1584			1.2308
23		.4344					.6516
24	.6516	.6783	.543				
Max	**.8688**	**.823**	**.9114**	**1.1584**	**1.1984**	**1.3032**	**1.2308**
Min	**.631**	**.4344**	**.5316**	**1.0174**	**.0381**	**1.086**	**.0381**
Avg	**.7344**	**.6958**	**.6504**	**1.1096**	**.9918**	**1.2481**	**.9744**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] **BU 1147**
Substation No/ Name :- 144060 / 33/11 KV HALKARNI
Feeder No / Name : 202 / 11 KV Shinoli Ex. **NON SHEDDABLE EXPRESS HV FEEDERS**
Feeder KV- 11 / OUTGOING **(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1187	.0754	.0754	.1187	.0754	.1187	.0754
2	.0678	.0377	.0377	.0678	.0377	.0678	.0377
3	.0339	.0377	.0377	.0339	.0377	.0339	.0377
4	.0339	.0377	.0377	.0339	.0377	.0339	.0377
5	.0339	.0377	.0377	.0339	.0377	.0339	.0377
6	.0678	.0377	.0377	.0678	.0377	.0678	.0377
7	.1187	.0377	.1132	.1187	.1132	.1187	.0754
8	.1187	.132	.1132	.1187	.1132	.1187	.1132
9	.1187	.132	.1509	.1187	.1509	.1187	.1509
10	.1494	.132	.1357	.1494	.1494	.1494	.112
11	.1509	.132	.1187	.1307	.1463	.128	.1307
12	.1109	.1132	.1187	.1097	.112	.1109	.1097
13	.1132	.112	.1187	.112	.1109	.0724	.1097
14	.0377	.1132	.1187		.0373	.037	.1063
15	.0377	.037	.1187	.1097	.0373	.1097	.0362
16		.0366	.0339	.0373	.1097	.0924	.0377
17	.0377	.0373	.0339	.0366	.037	.0943	.0377
18	.0377	.0377	.0339	.0377	.0377	.0377	.0377
19	.0377	.0377	.0339	.0377	.0377	.0377	.0377
20	.1509	.1132	.1187	.132	.1357	.1132	.132
21	.132	.1509	.1187	.1509	.1187	.1509	.132
22	.1132	.1509	.1357	.132	.1187	.1509	.132
23	.1132	.1509	.1357	.132	.1187	.1509	.1132
24	.1187	.1132	.1132	.1187	.0943	.1187	.1132
Max	**.1509**	**.1509**	**.1509**	**.1509**	**.1509**	**.1509**	**.1509**
Min	**.0339**	**.0366**	**.0339**	**.0339**	**.037**	**.0339**	**.0362**
Avg	**.0893**	**.0847**	**.0887**	**.0930**	**.0851**	**.0944**	**.0826**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] BU 1147
Substation No/ Name :- 144060 / 33/11 KV HALKARNI
Feeder No / Name : 203 / 11 KV Gaulwadi Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.017	.0151	.0152	.8139	.7712	.6783	.5182
2	.017	.0151	.0152	.78	.788	.6783	.5182
3	.017	.0151	.0152	.78	.7956	.7461	.5182
4	.017	.0151	.0152	.8139	.703	.763	.5487
5	.017	.0151	.0152	.8139	.7545	.8478	.5792
6	.017	.0151	.0152	.8478	.7545	.8817	.6097
7	.017	.0152	.0152	.8987	.9717	.9326	.7316
8	.017	.0151	.0152	1.153	1.1568	1.0852	1.0059
9	.017	.0151	.0152	.017	.0151	.017	.0152
10	1.5402	1.7072	1.6461	.0151	.017	.017	.0166
11	1.6248	1.8652	1.8991	.0173	.017	.0168	.0164
12	1.8564	1.8991	1.8991	.0166	.017	.0173	.0151
13	1.6518	2.1026	1.8991	.017	.017	.0166	.0164
14	1.7804	1.9839	1.8313		.0166	.0166	.0151
15	1.7974	1.9839	1.6617		.0151	.0173	.0151
16		1.8991	1.6108		.0168	.0152	.0151
17	1.4737	1.6549	1.3904	.017	.0164	.0152	.0151
18	.0156	.0152	.017	.0151	.0151	.0152	.0151
19	.0151	.0152	.017	.0151	.0151	.0152	.0151
20	.0151	.0152	.017	.0149	.017	.0152	.0151
21	.0151	.0152	.017	.0151	.017	.0152	.0152
22	.0151	.0152	.017	.0151	.017	.0152	.0151
23	.0151	.0152	.78	.7316	.6952	.5335	.0151
24	.017	.0151	.0152	.7969	.7449	.6783	.5335
Max	**1.8564**	**2.1026**	**1.8991**	**1.153**	**1.1568**	**1.0852**	**1.0059**
Min	**.0151**	**.0151**	**.0152**	**.0149**	**.0151**	**.0152**	**.0151**
Avg	**.5211**	**.6391**	**.6189**	**.4098**	**.3485**	**.3354**	**.2414**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] BU 1147
Substation No/ Name :- 144060 / 33/11 KV HALKARNI
Feeder No / Name : 206 / 11 KV Gaulwadi Vg GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1187	.1006	.1052	.1017	.1017	.1017	.1052
2	.1187	.1006	.1052	.1017	.1006	.1017	.1052
3	.1187	.1475	.1052	.1017	.1006	.1017	.1052
4	.1357	.1174	.1052	.1017	.1132		.1227
5	.1357	.1296	.1402	.1187	.1696		.1402
6	.2035	.2105	.1753	.1526	.2012		.1753
7	.3222	.3149	.2454	.2543	.2683		.2629
8	.3222	.3077	.3155	.2883	.3222		.298
9	.3561	.2915	.3155	.3222	.3222		.333
10	.3052	.2883	.3052	.2486	.3315	.2947	.1886
11	.3113	.3052	.3222	.2321	.3467	.2652	.1509
12	.3086	.2743	.2883	.2035	.2883	.2486	.2458
13	.2458	.2427	.2543	.1658	.2486	.2713	.2258
14	.2401	.2427	.2543		.2374	.2204	.2204
15	.2254	.2427	.2204		.2515	.2204	.2543
16		.2713	.2543		.2713	.2629	.2374
17	.2543	.2915	.2883	.2486	.2713	.2629	.2713
18	.3561	.2629	.2713	.2915	.3222	.3155	.3561
19	.3932	.3856	.3391	.4372	.4191	.4031	.421
20	.3725	.333	.3222	.3978	.3222	.333	.39
21	.3401	.2804	.3052	.3688	.2883	.2804	.3561
22	.2458	.2103	.2204	.2347	.2035	.2103	.2713
23	.1457	.1578	.1526	.1174	.1526	.1402	.1509
24	.1187	.1006	.1227	.1187	.1006	.1187	.1227
Max	**.3932**	**.3856**	**.3391**	**.4372**	**.4191**	**.4031**	**.421**
Min	**.1187**	**.1006**	**.1052**	**.1017**	**.1006**	**.1017**	**.1052**
Avg	**.2476**	**.2337**	**.2306**	**.2194**	**.2398**	**.2307**	**.2296**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] BU 1147
Substation No/ Name :- 144060 / 33/11 KV HALKARNI
Feeder No / Name : 208 / 11 KV Shivanage Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4239	.3161	.2896	.017	.0152	.017	.0152
2	.4239	.3281	.2896	.017	.0151	.017	.0152
3	.407	.3401	.2896	.017	.0151	.017	.0152
4	.407	.3353	.3048	.017	.0151	.017	.0152
5	.4239		.3048	.0164	.0151	.017	.0152
6	.5087	.3401	.3048	.017	.0151	.017	.0152
7	.5256	.4062	.3201	.017	.0152	.017	.0152
8	.6104	.4862	.3658	.017	.0151	.017	.0152
9	.017	.0151	.0152	.017	.0151	.017	.0152
10	.0171	.0177	.017	.763	.9665	.9326	1.0343
11	.0164		.017	.8648	1.0056	1.0852	1.094
12	.017	.017	.017	.8648	.9882	1.0682	1.1401
13	.0151	.017	.017	.8962	1.0174	1.0442	1.1361
14	.017	.017	.017		1.0682	.9995	
15	.017	.017	.017		1.0852	1.0174	.945
16		.017	.017		1.0513	1.0159	.953
17	.0151	.017	.017	.6783	.9945	.8688	.8436
18	.0151	.0152	.017	.0151	.0151	.0152	.0151
19		.0152	.017	.0151	.0151	.0152	.0151
20	.0151	.0152	.017	.0151	.017	.0152	.0151
21	.0156	.0152	.017	.0152	.017	.0152	.0152
22	.0151	.0152	.017	.0152	.017	.0152	.0151
23	.3125	.2896	.017	.0151	.017	.0152	.4218
24	.4409	.3437	.2896	.017	.0151	.017	.0152
Max	**.6104**	**.4862**	**.3658**	**.8962**	**1.0852**	**1.0852**	**1.1401**
Min	**.0151**	**.0151**	**.0152**	**.0151**	**.0151**	**.0152**	**.0151**
Avg	**.2126**	**.1544**	**.1255**	**.2061**	**.3511**	**.3455**	**.3389**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] BU 1147
Substation No/ Name :- 144060 / 33/11 KV HALKARNI
Feeder No / Name : 209 / 11 KV BELEBHAT Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4239	.3612	.3963	.0509	.0297	.0509	.0305
2	.4239	.3763	.3963	.0509	.0297	.0509	.0305
3	.407	.381	.3963	.0509	.0297	.0509	.0305
4	.4239	.381	.3963	.0509	.0301	.0509	.0457
5	.5087	.3963	.3963	.0509	.0301	.0509	.0457
6	.5426	.4268	.3963	.0509	.0301	.0509	.0457
7	.6274	.5182	.4725	.0678	.0452	.0678	.061
8	.5765	.5335	.5335	.0509	.0452	.0678	.0457
9	.0678	.0297	.0457	.0509	.0452	.0509	.0457
10	.0648	.0343	.0457	.8745	.9831	1.0277	1.1869
11	.0594	.0328	.0509	1.0513	1.153	1.1096	1.3565
12	.0848	.0343	.0509	1.0562		1.1271	1.3565
13	.0297	.0332	.0339	.9332	1.1831	1.2209	1.2597
14		.0332	.0339	1.1191	1.2548	1.3226	1.2574
15	.0503	.0343	.0339	1.1191	1.2548	1.2378	1.0997
16	.0339	.052	.0339	1.1401	1.2174	1.0974	1.0254
17	.0149	.0663	.0509	1.0174	1.0202	1.0364	.9214
18	.0149	.0457	.0509	.0151	.0446	.061	.0594
19	.0149	.0457	.0509	.0446	.0446	.061	.0446
20	.0594	.061	.0509	.0446	.0678	.061	.0446
21	.0594	.061	.0509	.0149	.0509	.0457	.0446
22	.0594	.0457	.0509	.0149	.0509	.0457	.0446
23	.3715	.3963	.0509	.0446	.0509	.0457	.4161
24	.4578	.3612	.3963	.0509	.0149	.0509	.0305
Max	**.6274**	**.5335**	**.5335**	**1.1401**	**1.2548**	**1.3226**	**1.3565**
Min	**.0149**	**.0297**	**.0339**	**.0149**	**.0149**	**.0457**	**.0305**
Avg	**.2338**	**.1975**	**.1861**	**.3756**	**.3785**	**.4184**	**.4387**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] **BU 1147**
Substation No/ Name :- 144060 / 33/11 KV HALKARNI
Feeder No / Name : 210 / Gad AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1357	.3018	.1981	.017	.0152	.017	.0152
2	.1357	.2818	.2134	.017	.0152	.017	.0152
3	.1357	.2883	.2134	.017	.0152	.017	.0152
4	.1357	.2949	.2134	.017	.0151	.017	.0152
5	.1526	.3185	.2439	.017	.0152	.017	.0152
6	.1526	.2883	.2591	.017	.0152	.017	.0152
7	.1696	.3185	.3201	.017	.0151	.017	.0152
8	.2204	.4191	.3353	.017	.0149	.017	.0152
9	.017	.0151	.0152	.017	.0152	.017	.0152
10	.0175	.0173	.017	.5609	.5784	.5721	.7455
11	.017	.0175	.017	.5784	.1907	.6485	.763
12	.0173	.0173	.017	.4908		.6173	.763
13	.0152	.0173	.017	.1387	.7628	.6661	.7975
14	.0175	.0173	.017		.7712	.6836	.7045
15	.0175	.0173	.017	.5426	.7202	.6935	.6613
16		.0173	.017	.4908	.7537		.6104
17	.0151	.0173	.017	.4854	.6836	.6097	.5087
18	.0152	.0152	.017	.017	.0151	.0152	.0151
19	.0149	.0152	.017	.0151	.0151	.0152	.0152
20	.0152	.0152	.017	.0151	.017	.0152	.0152
21	.0151	.0152	.017	.0151	.017	.0152	.0151
22	.0156	.0152	.017	.0151	.017	.0152	.0151
23	.3052	.1981	.017	.0151	.017	.0152	.3018
24	.1526	.3052	.1981	.017	.0151	.017	.0152
Max	**.3052**	**.4191**	**.3353**	**.5784**	**.7712**	**.6935**	**.7975**
Min	**.0149**	**.0151**	**.0152**	**.0151**	**.0149**	**.0152**	**.0151**
Avg	**.0829**	**.1352**	**.102**	**.1544**	**.2048**	**.2066**	**.2535**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] **BU 1147**
Substation No/ Name :- 144061 / 33/11 KV CHANDGAD
Feeder No / Name : 201 / 11 KV Adkur Vg **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0181	.0185	.0373	.0189	.0185	.0185	.0189
2	.0181	.0183	.0377	.0191	.0185	.0187	.0189
3	.0183	.0183	.0373	.0191	.0187	.0185	.0187
4	.0185	.0185	.0373	.0191	.0187	.0189	.0187
5	.0183	.0183	.037	.0189	.0377	.0181	.0189
6	.0185	.0185	.0537	.0377	.0347	.0358	.0366
7	.0373	.037	.0739	.0754	.0537	.0377	.052
8	.0549	.0701	.0732	.056	.0709	.0701	.0724
9	.0354	.0537		.0549	.0537	.0716	.0537
10	.0187	.037		.037	.0549	.0373	.0377
11	.0191	.0373		.037	.037	.0373	.0185
12	.0179	.0373	.0377	.0373	.0354	.037	.0191
13	.0187	.0187	.0366	.0185	.0351	.0185	.0189
14	.0179	.0373	.0366	.037	.0177	.0189	.0187
15	.0185	.0549	.0366	.0183	.0189	.0187	.0179
16	.0187	.0377	.0366	.0362	.0189	.0187	.0183
17	.0173	.0549	.0366	.0358	.0362	.0362	.0181
18	.0537	.0724	.0732	.0543	.0543	.0716	.0532
19	.1097	.1307	.1097	.0914	.0934	.0934	.0905
20	.0924	.1132	.1097	.0905	.0754	.0943	.0924
21	.0747	.0953	.0914	.056	.0754	.0747	.0554
22	.056	.0754	.0549	.0377	.0381	.037	.0566
23	.0187	.0373	.0366	.0187	.0189	.0187	.0187
24	.0185	.0185	.0189	.0366	.0183	.0187	.0187
Max	**.1097**	**.1307**	**.1097**	**.0914**	**.0934**	**.0943**	**.0924**
Min	**.0173**	**.0183**	**.0189**	**.0183**	**.0177**	**.0181**	**.0179**
Avg	**.0337**	**.0470**	**.0525**	**.0401**	**.0397**	**.0391**	**.0359**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] BU 1147
Substation No/ Name :- 144061 / 33/11 KV CHANDGAD
Feeder No / Name : 202 / 11 KV Kurtanwadi Vg GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.0566	.0554	.0549	.0537	.0566	.0566
2	.0377	.0377	.0554	.0566	.0566	.056	.0566
3	.0377	.0381	.0373	.0566	.0572	.0554	.056
4	.0381	.0373	.0373	.0566	.0572	.0566	.0566
5	.0566	.0566	.0377	.0747	.0943	.0924	.056
6	.0943	.0953		.1132	.132	.132	.1132
7	.132	.1334		.1509	.132	.132	.132
8	.132	.1509		.1509	.1307	.1698	.1509
9	.1294	.132	.0191	.1294	.132	.1463	.1663
10	.0554	.1294	.1494	.1478	.1478	.1448	.1663
11	.0914	.1132	.1646	.0943	.1509	.132	.1509
12	.0934	.1143	.112	.0848	.132	.1334	.1494
13	.0701	.0943	.1494	.0829	.1097	.1143	.1307
14	.0943	.1109	.1097	.0829	.0934	.1132	.0953
15	.0747	.1578	.1097	.0716	.0934	.1307	.1294
16	.0953	.1417	.0914	.0724	.1387	.1109	.128
17	.0739	.1663	.128	.0934	.1307	.1097	.1307
18	.1524	.2347	.1829		.1294	.1543	.1526
19	.2667	.2987	.2378	.2075	.2641	.2743	.1715
20	.2241	.2427	.2378	.2096	.2641	.2427	.2614
21	.2241	.2075	.2378	.1886	.2075	.2073	.1886
22	.168	.1334	.1463	.1494	.1524	.1294	.1509
23	.0953	.0747	.1097	.0754	.0924	.0762	.0747
24	.0554	.056	.0554	.0754	.0566	.0537	.056
Max	**.2667**	**.2987**	**.2378**	**.2096**	**.2641**	**.2743**	**.2614**
Min	**.0377**	**.0373**	**.0191**	**.0549**	**.0537**	**.0537**	**.056**
Avg	**.1062**	**.1256**	**.1173**	**.1078**	**.1254**	**.126**	**.1242**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] **BU 1147**
Substation No/ Name :- 144061 / 33/11 KV CHANDGAD
Feeder No / Name : 203 / 11 KV Here Vg **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.017	.0162	.0297	.0366	.0537	.037	.0324
2	.0171	.0166	.0309	.0366	.0532	.0179	.0332
3	.0187	.0171	.0309	.0366	.0537	.0183	.0324
4	.0185	.0173	.0316	.0366	.0532	.037	.0324
5	.0366	.0358	.0332	.0549	.0693	.0537	.0332
6	.0543	.0526	.052	.0732	.0857	.0709	.0537
7	.0709	.0895	.0848	.0914	.1052	.0732	.0732
8	.0532	.1052	.104	.0914	.0876	.0867	.0895
9	.0747	.0867	.0857	.0914	.1017	.0848	.0905
10	.0655	.0671	.0838	.0739	.0701	.0848	.0829
11	.0671	.0819		.0693	.0747	.0663	.1017
12	.0648	.0509			.0724	.0486	.0857
13	.08	.0514			.0895	.064	.0848
14	.0648	.0857	.0914	.0724	.1052	.081	.0655
15	.081	.064	.0914	.0905	.1063	.0781	.0492
16	.0648	.0829	.0914	.104	.104	.061	.0633
17	.0625	.0762	.1463	.1052	.0716	.0829	.0486
18	.0876	.116	.1829	.1341	.1097	.1187	.0949
19	.1478	.1646	.1829	.2033	.1886	.2033	.1372
20	.1463	.1848	.2012	.1494	.1715	.1829	.1646
21	.132	.1646	.1646	.1132	.1334	.1478	.1307
22	.0924	.104	.1097	.0953	.0943	.0732	.0914
23	.0503	.0474	.0754	.0732	.056	.052	.0554
24	.0166	.0309	.0293	.0366	.0543	.0566	.0324
Max	**.1478**	**.1848**	**.2012**	**.2033**	**.1886**	**.2033**	**.1646**
Min	**.0166**	**.0162**	**.0293**	**.0366**	**.0532**	**.0179**	**.0324**
Avg	**.0660**	**.0754**	**.0921**	**.0850**	**.0902**	**.0784**	**.0733**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] BU 1147
Substation No/ Name :- 144061 / 33/11 KV CHANDGAD
Feeder No / Name : 204 / 11 KV Hambire Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3086	.2804	.0732	.0693	.0686	.0183
2	.3121	.3052	.2804	.0732	.0175	.0173	.0183
3	.3155	.3018	.2658	.0732	.0177	.017	
4	.3189	.3429	.2658	.0732	.0181	.0162	.0183
5	.3582	.3429	.3155	.0732	.0173	.0633	.0183
6	.362	.373	.3506	.0732	.0686	.0686	.0716
7	.3772	.4287	.3814	.0732	.0829	.0633	.0857
8	.2534	.4748	.4458	.0914	.0838	.0791	.0655
9	.0732	.1063	.0168	.0943	.052	.0895	.0693
10	.0732	.0671	.0716	.6878		.5658	.6783
11	.0189	.0857		.679	.763	.2743	.6859
12	.0189	.0686			.8478	.583	.695
13		.0693			.8139	.5426	.6516
14	.0183	.0693	.0732	.4973	.8139	.5765	.7545
15	.0724	.0693	.0732	.5801		.4801	
16	.0716	.0686	.0732	.5967	.6722	.503	.6859
17	.0732	.0173	.0732	.6299	.7202	.4748	.6859
18	.0171	.0173	.0732	.0648	.0983	.0747	.0152
19	.1086	.0716	.0914	.1075	.104	.0732	.0171
20	.1097	.0914	.0914	.1097	.0829	.1052	.0886
21	.1086	.1086	.0914	.0924	.0857	.0905	.0867
22	.0905	.0724	.0914	.0934	.0693	.0895	.0857
23	.3086	.2454	.0914	.0838	.0701	.0732	.0701
24	.3052	.3185	.2804	.0914	.0857	.0701	.0739
Max	**.3772**	**.4748**	**.4458**	**.6878**	**.8478**	**.583**	**.7545**
Min	**.0171**	**.0173**	**.0168**	**.0648**	**.0173**	**.0162**	**.0152**
Avg	**.1771**	**.1844**	**.1799**	**.2278**	**.2570**	**.2108**	**.2564**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] BU 1147
Substation No/ Name :- 144061 / 33/11 KV CHANDGAD
Feeder No / Name : 205 / 11 KV Kuratnwadi Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.0189	.0177	.3353	.1806	.1581	.2812
2	.0191	.0191	.0181	.3563	.1829	.1581	.2561
3	.0189	.0189	.0183	.3239	.1852	.144	.2561
4	.0189	.0187	.0183	.3239	.2622	.1619	.2591
5	.0191	.0185	.0187	.3563	.2591	.1619	.2881
6	.0189	.0187	.0189	.3887	.2915	.192	.3201
7	.0189	.0185	.0185	.421	.298	.1943	.3521
8	.0191	.0187	.0189	.4696	.3795	.2214	.3401
9	.0762	.0191	.0191	.0183	.0754	.0187	.0187
10	.0903		.639	.0183	.0754	.0187	.0189
11	.125		.8192	.0183	.0185	.0189	.0747
12	.1406	.5121	.9156	.0183	.0183	.0754	.0183
13	.125	.5761	1.933	.0183	.0187	.0189	.0183
14	.1204	.7045	.9069	.0183	.0187	.0189	.0187
15	.1235		.9175	.0191	.0189	.0189	.0187
16	.1204	.8785	.9339	.0189	.0187	.0953	
17	.104	.6081	.9339	.0189	.0377	.0762	.0166
18	.0189	.0943	.0183	.0189	.0373	.0191	.0185
19	.0187	.0173	.0183	.0189	.0185	.0189	.0171
20	.0189	.0171	.0183	.0191	.0185	.0183	.0154
21	.0189	.0171	.0183	.0189	.0179	.0185	.017
22	.0189	.0173	.0183	.0191	.0185	.0185	.0171
23	.0189	.0179	.3239	.2054	.1581	.2656	.0173
24	.0189	.0189	.0177	.3395	.1907	.1581	.2778
Max	**.1406**	**.8785**	**1.933**	**.4696**	**.3795**	**.2656**	**.3521**
Min	**.0187**	**.0171**	**.0177**	**.0183**	**.0179**	**.0183**	**.0154**
Avg	**.0561**	**.1737**	**.3583**	**.1576**	**.1166**	**.0945**	**.1277**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] **BU 1147**
Substation No/ Name :- 144061 / 33/11 KV CHANDGAD
Feeder No / Name : 206 / 11 KV Adkur Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3887	.3795	.4372	.0183	.0189	.0189	.0189
2	.3321	.3281	.4321	.0183	.0189	.0189	.0189
3	.3361	.3361	.4161	.0183	.0191	.0191	.0191
4	.3401	.3361	.421	.0183	.0189	.0189	.0191
5	.5087	.4915	.421	.0732	.0189	.0189	.0189
6	.5601	.506	.4492	.0732	.0191	.0187	.0747
7	.6154	.5601	.6081	.0732	.0189	.0189	.0754
8	.7209	.7209	.6802	.0732	.0189	.0187	.0943
9	.0754	.0189		.0732	.0762	.0189	.0943
10	.0762	.0732		.8223	.6478	.6958	.8048
11	.0191	.0189		.8223	.7842	.8097	.9717
12	.0953	.0747	.0732	.7907	.7287	.7935	.7468
13	.0762	.0185	.0732	.6874	.7274	.7042	.583
14	.0189	.0187	.0732	.6405	.7362	.7449	.7042
15	.0189	.0189	.0732	.6874	.7362	.7682	.6958
16	.0189	.0754	.0914	.6874	.7682	.7274	
17	.0754	.0189	.0914	.6874	.6722	.7362	.7125
18	.0191	.0754	.1097	.0693	.0924	.0943	.0754
19	.0762	.0953	.0914	.0754	.0754	.1132	.0754
20	.1143	.0953	.0914	.0762	.0943	.1143	.0762
21	.0953	.0857	.0914	.0189	.0747	.0953	.0754
22	.0754	.0709	.0732	.0191	.0754	.0762	.0189
23	.5218	.4816	.0732	.0191	.0762	.0187	.4668
24	.5601	.4999	.427	.0732	.0191	.0189	.0762
Max	**.7209**	**.7209**	**.6802**	**.8223**	**.7842**	**.8097**	**.9717**
Min	**.0189**	**.0185**	**.0732**	**.0183**	**.0189**	**.0187**	**.0189**
Avg	**.2391**	**.2249**	**.2523**	**.2757**	**.2723**	**.2784**	**.2833**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] BU 1147
Substation No/ Name :- 144061 / 33/11 KV CHANDGAD
Feeder No / Name : 208 / 11 KV Chandgad GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6653	.5914	.5853	.439	.5914	.5914	.5093
2	.6722	.5544	.5914	.439	.3921	.3921	.4668
3	.6722	.3921	.5853	.439	.3921	.3961	.4668
4	.3881	.3881	.5914	.439		.3921	.4715
5	.4435	.6722	.6653	.5544	.4572	.4435	.5093
6	.5487	.7392	.8316	.6584	.679	.679	.6653
7	.6516	1.1088	.9877	.7842	.9431	.7468	.7602
8	1.2197	1.2803	1.0608	.9979	1.0719	.9979	.9709
9	1.0082	.924	1.0566	1.0164	.8962	.961	.9054
10	1.182	1.086	1.3575	1.5893	1.5604	1.7337	1.5203
11	.7282	1.2489	1.4266		1.576	1.8267	.5281
12	1.1568	1.2437	1.0719		1.773	1.7375	1.6118
13	1.1946	1.2894	1.1458		1.7541	1.6289	1.6118
14	1.0059	.7023	1.0974	1.4266	1.5769	1.5746	
15	1.086	1.086		1.5364	1.5565	1.5746	1.4118
16	1.086	1.1222	.1829	1.5203	1.5043	.7207	1.3969
17	1.0608	1.1458		1.4723	1.4685	1.3756	1.3969
18	.8962	1.0242	.9979	.8688	.8962	.823	.7602
19	1.251	1.3256	1.2071	1.0562	1.307	1.1576	1.1203
20	1.1203	1.2323	1.1523	.9335	1.094	1.1317	1.0829
21	1.0269	1.0185	.9328	.7922	.9795	.9054	.9054
22	.811	.7356	.7682	.6241	.811	.7095	.823
23	.7392	.7023	.679	.695	.7468	.5975	.8871
24		.5729	.6036	.4572	.5853	.5544	
Max	**1.251**	**1.3256**	**1.4266**	**1.5893**	**1.773**	**1.8267**	**1.6118**
Min	**.3881**	**.3881**	**.1829**	**.439**	**.3921**	**.3921**	**.4668**
Avg	**.8963**	**.9244**	**.8899**	**.8923**	**1.0701**	**.9855**	**.9446**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] **BU 1147**
Substation No/ Name :- 144062 / 33/11 KV SHINOLI S/STN
Feeder No / Name : 201 / 11 KV VAIJANATH **SHEDDABLE RURAL**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0914	.0857	.0914	.0857	.0857	.0857
2	.0857	.0914	.0857	.0914	.0857	.0857	.0857
3	.0857	.0914	.0857	.0914	.0857	.0857	.0857
4	.0857	.0914	.0857	.0886	.0857	.0857	.0857
5	.0857	.0914	.0857	.0914	.0857	.0857	.0857
6	.0857	.1829	.0857	.1829	.0857	.0857	.0857
7	.0857	.2743	.0857	.2743	.1715	.1715	.1715
8	.6001	.4572	.5144	.7316	.5144	.6001	.6001
9	.6001	.6602	.6859	.7316	.6001	.6859	.7716
10	.6401	.5144	.6401	.5144	.6001	.6859	.7316
11	.7316	.5144	.7316	.5144	.6001	.6001	.7316
12	.7316	.6001	.7316	.5144	.6859	.6001	.6401
13	.7316	.7716	.7316	.6001	.6859	.6859	.7316
14	.7316	.6859	.7316	.5144	.6001	.6001	.823
15	.7316	.6001	.823	.5144	.5144	.5144	.7316
16	.6401	.7716	.9145	.5144	.6001		.5487
17	.6401	.8573	.823	.5144	.6001	.5144	.6401
18	.7316	.6859	.7316	.6001	.6001	.6001	.6401
19	.5487	.4287	.5487	.5144	.4287	.5144	.5487
20	.4572	.1715	.4572	.4287	.3429	.3429	.4572
21	.3658	.0857	.3658	.3429	.1715	.1715	.3658
22	.2743	.0857	.2743	.0857	.0857	.0857	.2743
23	.1829		.1829	.0857	.0857	.0857	.1829
24	.0857	.0914	.0857	.0914	.0857	.0857	.0857
Max	**.7316**	**.8573**	**.9145**	**.7316**	**.6859**	**.6859**	**.823**
Min	**.0857**	**.0857**	**.0857**	**.0857**	**.0857**	**.0857**	**.0857**
Avg	**.4177**	**.3868**	**.4406**	**.3635**	**.3536**	**.3504**	**.4246**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] BU 1147
Substation No/ Name :- 144062 / 33/11 KV SHINOLI S/STN
Feeder No / Name : 202 / 11 KV HITECH SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.8573	.6859	.6001	.5144	.6001	.6001
2	.7716	.6859	.6001	.6001	.4287	.5144	.6859
3	.7716	.6859	.5144	.5144	.4287	.6001	.6001
4	.8573	.6001	.5144	.5144	.4287	.6859	.5144
5	.8573	.6001	.4287	.5144	.4287	.6001	.6001
6	.7716	.6001	.5144	.5144	.5144	.5144	.5144
7	.7716	.6001	.6001	.5144	.5144	.5144	.5144
8	.5144	.5144	.3429	.4287	.4287	.6001	.4287
9	.6859	.5144	.3429	.4287	.4287	.6001	.5144
10		1.0288	1.0288	.4287	.6001	.9431	1.2003
11	1.2003	1.3717	1.2003	.4287	1.0288	1.6289	1.2003
12	1.4575	1.2003	1.3717	.4287	1.2003	1.286	1.2003
13	1.2003	.8573	1.1145	.4287	.6001	.9431	1.1145
14	1.0288	.7716	.9431	.4287	.8573	1.0288	1.0288
15	1.448	1.0288	1.0288	.4287	1.2003	1.5432	1.2003
16	1.5432	.8573	1.2003	.4287	1.0288	1.4575	1.1145
17	1.4575	1.0288	.8573	.5144	1.4575	1.3717	.8573
18	1.3717	.8573	.6001	.6001	1.286	1.6289	.6001
19	.8573	.6859	.8573	.6001	.8573	.9431	.6001
20	1.0288	.6859	.8573	.6001	1.3717	.8573	.6859
21	1.2003	1.286	.8573	.6001	1.0288	.7716	.6859
22	1.2003	.7716	.6859	.5144	.6859	.6859	.6859
23	1.2003		.6001	.5144	.6859	.6001	.6859
24	.7716	1.0288	.7716	.6859	.5144	.6001	.6859
Max	**1.5432**	**1.3717**	**1.3717**	**.6859**	**1.4575**	**1.6289**	**1.2003**
Min	**.5144**	**.5144**	**.3429**	**.4287**	**.4287**	**.5144**	**.4287**
Avg	**1.0321**	**.8312**	**.7716**	**.5108**	**.7716**	**.8966**	**.7716**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] **BU 1147**
Substation No/ Name :- 144062 / 33/11 KV SHINOLI S/STN
Feeder No / Name : 203 / 11 KV Angolkar **SHEDDABLE FEEDER HAVING WEEKLY**
Feeder KV- 11 / OUTGOING **STAGGERING (MIDC, EQUIVALENT)**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2058	.1715	.2058	.2058	.1715	.1715
2	.1715	.2058	.1715	.1715	.1715	.1715	.1715
3	.1715	.1715	.1715	.1715	.1715	.1715	.1715
4	.1715	.1715	.1715	.1715	.1715	.1715	.1715
5	.1715	.1715	.1715	.1715	.2058	.1715	.1715
6	.2058	.2058	.1715	.2058	.2058	.1715	.1715
7	.2058	.2058	.1715	.2058	.2058	.1715	.1715
8	.2572	.2058	.2058	.2572	.2572	.2058	.1715
9	.2572	.3429	.2572	.2058	.2572	.2572	.3429
10	.3429	.3429	.3429	.2058	.4287	.4287	.4287
11	.3429	.4287	.3429	.2058	.4287	.4287	.4287
12	.3429	.4287	.3429	.2058	.3429	.4287	.4287
13	.3429	.3429	.3429	.2058	.3429	.4287	
14	.3429	.4287	.3429	.2058	.3429	.3429	.3429
15	.3429		.3429	.2058	.3429	.3429	.3429
16	.3429	.3429	.3429	.2058	.4287	.4287	.4287
17	.3429	.4287	.3429	.1715	.3429	.3429	.3429
18	.3429	.3429	.2572	.1715		.4287	.3429
19	.2572	.2572	.3429	.1715	.2058	.2572	.2572
20	.2572	.2572	.2572	.2058	.2058	.1715	.2058
21	.2572	.2572	.2058	.2058	.2058	.1715	.1715
22	.2572	.2572	.2058	.2058	.1715	.1715	.1715
23	.2058		.1715	.2058	.1715	.1715	.1715
24	.2058	.2058	.1715	.2058	.2058		.1715
Max	**.3429**	**.4287**	**.3429**	**.2572**	**.4287**	**.4287**	**.4287**
Min	**.1715**	**.1715**	**.1715**	**.1715**	**.1715**	**.1715**	**.1715**
Avg	**.2643**	**.2822**	**.2508**	**.1979**	**.2617**	**.2699**	**.2587**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] **BU 1147**
Substation No/ Name :- 144062 / 33/11 KV SHINOLI S/STN
Feeder No / Name : 204 / 11 KV Aqua **NON SHEDDABLE EXPRESS HV FEEDERS**
Feeder KV- 11 / OUTGOING **(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.724	.6001	.724	.6001	.6859	.6001
2	.7716	.724	.5144	.724	.5144	.6001	.5144
3	.6859	.724	.6859	.724	.5144	.6001	.6001
4	.7716	.724	.6001	.724	.6001	.6001	.5144
5	.6859	.724	.5144	.724	.5144	.6859	.6001
6	.6859	.724	.6001	.724	.6001	.6001	.5144
7	.6859	.724	.6859	.724	.6001	.6859	.6859
8		.724	.6859	.724	.6001	.6859	.6859
9	1.0288	.905	.7716	.724	.8573	.7716	.7716
10	1.086	.7716	.724	.6859	.6859	.6859	.905
11	.9955	.7716	.8145	.6001	.8573	.7716	.905
12	.905	.6859	.905	.6001	.6859	.6859	.905
13	.905	.8573	.905	.6859	.7716	.6859	.905
14	.905	.7716	.905	.4287	.7716	.8573	.905
15	.8145	.6859	.8145	.6001	.7716	.7716	.905
16	.724	.6001	.724	.6001	.7716	.6859	.905
17	.724	.7716	.724	.6001	.8573	.7716	.905
18	.724	.7716	.724	.6001	.7716	.6859	.905
19	.905	.8573	.905	.6001	.8573	.7716	.8145
20	.905	.8573	.905	.6001	.8573	.8573	.724
21	.905	.8573	.905	.6001	.8573	.6859	.724
22	.8145	.8573	.905	.6859	.8573	.8573	.724
23	.724		.905	.6859	.7716	.7716	.8145
24		.724	.6859	.8145	.6001	.6859	.6859
Max	**1.086**	**.905**	**.905**	**.8145**	**.8573**	**.8573**	**.905**
Min	**.6859**	**.6001**	**.5144**	**.4287**	**.5144**	**.6001**	**.5144**
Avg	**.8199**	**.7625**	**.7546**	**.6627**	**.7144**	**.7145**	**.7550**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] **BU 1147**
Substation No/ Name :- 144071 / 33/11 KV ADKUR
Feeder No / Name : 201 / 11 KV AMROLI **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0876	.1075	.0739	.0876	.1433	.1132	.0905
2	.0876	.0905	.0739	.0876	.1086	.1143	.0876
3	.0876	.0905	.0732	.0876	.0895	.112	.0876
4	.0876	.0895	.0914	.1063	.0895	.112	.0876
5	.1448	.0905	.1097	.1402	.0895	.112	.1052
6	.181	.1612	.1294	.1753	.1612	.1307	.1753
7	.2103	.2172	.2195	.2103	.2328	.2241	.2454
8	.2279	.3045	.2195	.1928	.2507	.2427	.2279
9	.2629	.2835	.2195	.2279	.2507	.2241	.2454
10	.2865	.2149	.2218	.1928	.2686	.3109	.2454
11	.2149	.2218	.2629	.2804	.2195	.2629	.2534
12	.1791	.2218	.1928	.197	.1829	.2103	.181
13	.1791	.1848	.1753	.1612	.1448	.1753	.1829
14	.1612	.1848	.2279	.1791	.1448	.1578	.1829
15	.1254	.1478	.2454	.2149	.1448	.1417	.2534
16	.1433	.2241	.2103	.2507	.1629	.1402	.1267
17	.2149	.2987	.1928	.2328	.2172	.1402	.181
18	.3045	.2987	.2804	.3224	.3142	.2279	.3174
19	.4119	.4481	.4382	.4119	.4668	.4031	.4668
20	.4835	.4668	.4382	.4607	.4668	.4207	.4668
21	.4119	.3921	.3681	.3761	.4108	.3506	.4108
22	.2328	.2241	.2103	.2507	.2987	.2804	.2987
23	.1629	.1494	.1402	.1791	.2241	.1928	.1829
24	.1052	.1254	.0914	.0876	.1612	.1307	.1402
Max	**.4835**	**.4668**	**.4382**	**.4607**	**.4668**	**.4207**	**.4668**
Min	**.0876**	**.0895**	**.0732**	**.0876**	**.0895**	**.112**	**.0876**
Avg	**.2081**	**.2183**	**.2044**	**.2130**	**.2185**	**.2054**	**.2185**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] **BU 1147**
Substation No/ Name :- 144071 / 33/11 KV ADKUR
Feeder No / Name : 202 / 11 KV BONJURDI **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.9465	.7701	.9145	.905
2				.9465	.8059	.7964	.8859
3				.9465	.8417	7.7103	.9328
4				.964	.8596	.7682	.9231
5				.964	.8775	.7602	.9114
6				.8764	.8954	.8048	.9774
7			.0366	.8939	.9134	.8413	.9955
8			.0366	.8939	.985	.9955	.8939
9		.0905	.0549		.0895	.0554	
10	1.576	1.6118	1.448			.0549	
11	1.6301	1.448	1.6476				
12	1.5939	1.4685	1.6301				
13	1.6118	1.6118	1.6651				
14	1.6118	1.7194	1.6651		.0366		
15	1.7551	1.7013	1.7737		.0366		
16	1.7193	1.5927	1.6651		.0366		.0366
17	1.5939	1.576	1.5775		.037		.0549
18	.0905	.0549		.1086	.0732		.0739
19	.0895	.0732		.1075	.0739		.0732
20	.0905	.0739		.1075	.0732		.0739
21	.0895	.0732		.1086	.0739		.0739
22	.0895	.0554		.1086	.0549		.0554
23	.0362	.0366	.9774	.6626	.823	.8764	.0366
24			.037	.9465	.7164	.905	.905
Max	**1.7551**	**1.7194**	**1.7737**	**.964**	**.985**	**7.7103**	**.9955**
Min	**.0362**	**.0366**	**.0366**	**.1075**	**.0366**	**.0549**	**.0366**
Avg	**.9698**	**.8791**	**1.0934**	**.6388**	**.4537**	**1.2902**	**.5181**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] **BU 1147**
Substation No/ Name :- 144071 / 33/11 KV ADKUR
Feeder No / Name : 204 / Adkur Village **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0701	.0724	.0543	.0701	.0895	.0724	.0724
2	.0701	.0543	.0543	.0701	.0716	.0549	.0701
3	.0724	.0537	.0549	.0701	.0716	.0549	.0701
4	.0724	.0537	.0543	.0701	.0724	.0549	.0701
5	.1052	.1075	.0732	.1075	.0716	.0732	.1086
6	.1402	.1433	.1086	.1402	.1254	.0914	.1402
7	.1753	.1791	.181	.1753	.1433	.1463	.1753
8	.2279	.2481	.181	.2103	.2149	.2195	.1928
9	.2103	.2328	.2195	.1928	.1791	.2172	.1578
10	.1629	.1612	.1991	.1753	.1791	.2103	.1928
11	.181	.1448	.1753	.1402	.1629	.1753	.1612
12	.197	.1267	.1753	.1433	.181	.1578	.1629
13	.1791	.1448	.1753	.1612	.1433	.1402	.1433
14	.1448	.1448	.1448	.1433	.1433	.1402	.1448
15	.1075	.1448	.1402	.1433	.1254	.1402	.1433
16	.1791	.128	.1402	.1448	.1254	.1052	.1433
17	.197	.1612	.1402	.1433	.1254	.1227	.1612
18	.2149	.2172	.2103	.2149	.1448	.1928	.1991
19	.2865	.2561	.2804	.2686	.2561	.2896	.2534
20	.3224	.2743	.2804	.3012	.2743	.2804	.2715
21	.2172	.2561	.2454	.2507	.2353	.2103	.2353
22	.1629	.1646	.1578	.1791	.181	.1402	.1991
23	.1075	.1267	.1227	.1433	.1086	.0876	.1267
24	.0876	.0905	.0724	.0701	.1254	.0905	.0724
Max	**.3224**	**.2743**	**.2804**	**.3012**	**.2743**	**.2896**	**.2715**
Min	**.0701**	**.0537**	**.0543**	**.0701**	**.0716**	**.0549**	**.0701**
Avg	**.1621**	**.1536**	**.1517**	**.1554**	**.1479**	**.1445**	**.1528**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] **BU 1147**
Substation No/ Name :- 144071 / 33/11 KV ADKUR
Feeder No / Name : 205 / Satavane Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6135	.7164	.5068				
2	.6485	.7602	.4887				
3	.6556	.7701	.4938				
4	.6661	.8059	.4938				
5	.7186	.8417	.5068				
6	.7888	.8596	.5068				
7	.8413	.8775	.6697				
8	.8589	1.1641	.8507				
10				1.2269	1.2715	1.448	1.4022
11				1.5249	1.6289	1.5775	1.5927
12				1.7187	1.6651	1.6476	1.5043
13				1.7187	1.5223	1.6476	1.5223
14				1.7013	1.6289	1.5775	1.5043
15				1.7193	1.576	1.4723	1.5581
16				1.7193	1.5223	1.4373	1.5203
17				1.5769	1.5023	1.4723	1.3969
23	.6697	.3658					.4344
24	.6135	.6984	.5068				
Max	**.8589**	**1.1641**	**.8507**	**1.7193**	**1.6651**	**1.6476**	**1.5927**
Min	**.6135**	**.3658**	**.4887**	**1.2269**	**1.2715**	**1.4373**	**.4344**
Avg	**.7075**	**.7860**	**.5582**	**1.6133**	**1.5397**	**1.5350**	**1.3817**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] **BU 1147**
Substation No/ Name :- 144080 / 33/11 KV Kanoor Sub Station
Feeder No / Name : 202 / Bijur AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2246	.2592	.2765	.0346	.0346	.0518	.0346
2	.2074	.2592	.2765	.0346	.0346	.0518	.0346
3	.2074	.2592	.2743	.0339	.0346	.0518	.0346
4	.2074	.2592	.2765	.0339	.0346	.0518	.0346
5	.2246	.2592	.311	.0346	.0346	.0518	.0346
6	.2419	.2938	.4147	.0518	.0518	.0518	.0346
7		.4147	.3283	.0518	.0518	.0518	.0346
8	.432	.4666	.3629	.0346	.0518	.0518	.0346
9	.0346	.0346	.0346	.0518	.0518	.0346	.0346
10	.0346	.0346	.0346	.5011	.6566	.7776	.7776
11	.0346	.0346	.0173		.6221	.7949	
12	.0346	.0346	.0173		.7949	.7776	.8122
13	.0346	.0346			.8294	.7776	.7776
14	.0346		.0173	.6912	.5357	.8122	.8294
15				.7258	.5875	.7949	.8122
16	.0173	.0173		.7603	.6566	.7776	.8813
17	.0346	.0346		.7258	.6566	.743	.7085
18	.0346	.0518	.0346	.0346	.0346	.0346	.0346
19	.0691	.0518	.0518	.0518	.0518	.0346	.0346
20	.0691	.0518	.0518	.0518	.0518	.0346	.0346
21	.0518	.0518	.0518	.0518	.0518	.0346	.0346
22	.0518	.0518	.0518	.0518	.0518	.0346	.0346
23	.2419	.2419	.0346	.0346	.0518	.0346	.3283
24	.2592	.2592	.2592	.0346	.0346	.0518	.0346
Max	**.432**	**.4666**	**.4147**	**.7603**	**.8294**	**.8122**	**.8813**
Min	**.0173**	**.0173**	**.0173**	**.0339**	**.0346**	**.0346**	**.0346**
Avg	**.1265**	**.1571**	**.1589**	**.1941**	**.2520**	**.2902**	**.2803**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] BU 1147
Substation No/ Name :- 144080 / 33/11 KV Kanoor Sub Station
Feeder No / Name : 203 / Pundra AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.017	.017	.017	.1357	.1696	.1696	.1526
2	.017	.017	.017	.1357	.1696	.1696	.1526
3	.017	.017	.017	.1357	.1696	.1526	.1526
4	.017	.017	.017	.1357	.1696	.1526	.1526
5	.017	.017	.017	.1357	.1865	.1357	.1526
6	.017	.017	.017	.1696	.2035	.1357	.1696
7	.017	.017	.017	.2035	.2374	.1357	.1865
8	.017		.017	.2543	.2543	.1696	.2204
9	.017	.017	.017	.017	.017	.017	.017
10	.2035	.017	.2713	.017	.017	.017	.017
11	.2204	.2713	.3052		.017	.017	
12	.1696	.1696	.2883		.017	.017	.017
13	.1865	.2713	.2543		.017	.017	.017
14	.1696		.2543	.017	.017	.017	.017
15	.2035	.2543		.017	.017	.017	.017
16	.2204	.2543		.017	.017	.017	.017
17	.1696	.2035		.017	.017	.017	.017
18	.017	.017	.017	.017	.017	.017	.017
19	.017	.0339	.0339	.017	.017	.017	.017
20	.017	.0339	.0339	.017	.017	.017	.017
21	.017	.017	.017	.017	.017	.017	.017
22	.017	.017	.017	.017	.017	.017	.017
23	.017	.017	.1357	.1696	.1696	.1526	.017
24	.017	.017	.017	.1357	.1696	.1696	.1526
Max	**.2204**	**.2713**	**.3052**	**.2543**	**.2543**	**.1696**	**.2204**
Min	**.017**	**.017**	**.017**	**.017**	**.017**	**.017**	**.017**
Avg	**.0756**	**.0786**	**.0856**	**.0856**	**.0891**	**.0742**	**.0752**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] **BU 1147**
Substation No/ Name :- 144098 / 33/11 KV Halkarni MIDC
Feeder No / Name : 201 / RAVIKIRAN PAPERMILL EXP Feeder Feeder KV- 11 / OUTGOING **NON SHEDDABLE EXPRESS HV FEEDERS (NON-CONTINOUS PROCESS)(NO STAGGERING)**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7095	.7023	.8775	.5041	.037	.8596	.9979
2	.9522	.9055	.7655	.4854	.9149	.9145	1.0349
3	.8131	.9425	.695	.5228	.7095	.7095	.8775
4	.9055	.7207	.9149	.5788	.9145	.7682	1.0349
5	.7133	.8871	.9431	.5975	.7842	.8589	.9979
6	.9335	.6838	.7922	.7842	.6838	.9431	.8596
7	.6838	.924	.8775	.9335	.9335	.9328	.924
8	.8775	.7207	.6908	.7468	.8779	.7282	.7023
9	.9335	.8501	.9149	.9335	.7207	1.0608	.8871
10	.9795	.6838	.6722	.7133	.9425	.8029	.9425
11	.7133	.9145	.9335	.7282	.8413	1.0642	.7023
12	.8962	.7023	.8962	.9145	.8962	.8029	.9522
13	.7095	.8962	.7282	.6838	.8589	.9522	.6908
14	.8402	.6767	.8962	.695	.6535	1.0456	.9335
15	.7282	.9149	.8962	.8686	.8962	.7842	.8589
16	.9335	.6908	.6908	.6908	.6348	1.0642	.8779
17	.9335	.8962	.9055	.8962	.7095	1.2382	.9709
18	.7655	.8215	.8779	.8413	.6535	.8402	.7468
19	.8775	.8962	.9709	.6653	.8775	1.1888	.9709
20	.7095	.6908	.9335	.8962	.8775	1.0903	.7545
21	.9149	.8962	.7133	.9149	.6908	.8871	.8501
22	.7282	.8775	.7655	.7133	.8402	1.0269	1.0456
23	.9694		.9149	.0187	.9242	1.0534	.9335
24	.7762	.8413	.6979	.6584	.0373	.6584	.8048
Max	**.9795**	**.9425**	**.9709**	**.9335**	**.9425**	**1.2382**	**1.0456**
Min	**.6838**	**.6767**	**.6722**	**.0187**	**.037**	**.6584**	**.6908**
Avg	**.8332**	**.8146**	**.8318**	**.7077**	**.7462**	**.9281**	**.8896**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] BU 1147
Substation No/ Name :- 144098 / 33/11 KV Halkarni MIDC
Feeder No / Name : 202 / 11 KV Turkewadi Vg GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1109	.1109	.1307	.1372	.112	.128	.124
2	.112	.1109	.1307	.12	.112	.1307	.1075
3	.1109	.1109	.112	.12	.0914	.1307	.1086
4	.1109	.1109	.1307	.12	.0924	.1307	.1086
5	.1478	.1417	.168	.1543	.1109	.168	.1417
6	.2195	.2218	.2427	.2058		.2241	.2149
7	.439	.4075	.3921	.2401	.2987	.4572	.3544
8	.4481	.4252	.3921	.2572	.6283	.4572	.394
9	.7023	.567	.4108	.3772	.6348	.5068	.5731
10	.7095	.4607		.4115	.6653	.6219	.7442
11	.7842	.567	.5041		.6722	.6201	.691
12	.691	.6584	.4115	.4481	.6908	.5138	.5487
13	.6201	.6535	.3429	.3696	.6219	.4481	.4115
14	.5316	.6036	.2743	.5175	.5415	.5316	.5487
15	.3012	.5975	.3086	.4481	.6219	.5493	.5144
16	.4075		.2743	.4854	.5228	.5316	.4801
17	.443	.5975	.2743	.5175	.5415	.4887	.4458
18	.443	.3921	.2743	.5228	.3547	.3189	.3429
19	.443	.4668	.4973	.4435	.5121	.4525	.4115
20	.4784	.4677	.3772	.4481	.4668	.4298	
21	.443	.3921	.3429	.4854		.394	.3772
22	.3544	.2987		.2926	.2987	.2865	.2401
23	.2481	.1646		.2218	.168	.1991	.1715
24	.1478	.124	.1494	.1543	.1478	.1509	.124
Max	**.7842**	**.6584**	**.5041**	**.5228**	**.6908**	**.6219**	**.7442**
Min	**.1109**	**.1109**	**.112**	**.12**	**.0914**	**.128**	**.1075**
Avg	**.3936**	**.3761**	**.2924**	**.326**	**.4048**	**.3696**	**.3556**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] **BU 1147**
Substation No/ Name :- 144098 / 33/11 KV Halkarni MIDC
Feeder No / Name : 203 / Megha Express **NON SHEDDABLE EXPRESS HV FEEDERS**
Feeder KV- 11 / OUTGOING **(NON-CONTINOUS PROCESS)(NO STAGGERING)**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.037	.0838	.1109	.0914		.0181	.0335
2	.0373	.0838	.1307	.0934		.0187	.0503
3	.0185	.0671	.0914	.0732		.0187	.0671
4	.0366	.1006	.056	.0554		.0183	.0503
5	.0373	.1006	.1494	.0732		.0187	.0335
6	.0183	.1341	.1307	.0183		.0187	.0503
7	.0185	.1006	.1463		.0185	.0187	.0503
8	.0185	.1509	.1307		.0747	.0187	.0503
9	.0183	.1174			.0183	.0187	.0671
10	.1109	.1174			.0934	.1307	.1174
11	.1294	.2054	.1867		.1109	.1341	.1509
12	.0838	.2241	.2054		.056	.1341	.1494
13	.0671	.128	.112		.0373	.1174	.056
14	.0838	.2263	.1494		.0934	.1341	.1307
15	.1006	.2054	.1494		.0914	.1174	.112
16	.0838	.112	.2012	.0187	.0914	.1006	.1307
17	.0838	.168	.1829		.056	.0983	.112
18	.0335	.1097	.0914		.0187	.1006	.056
19	.0168	.112	.1307		.0187	.0492	.0934
20	.0168	.1307	.112		.0189	.0655	.056
21	.0168	.1494	.1307		.0187	.0671	.0187
22	.0168	.0934	.112		.0187	.0671	.0187
23	.0168	.0934	.112		.0187	.0655	.0183
24	.0187	.0671	.056	.1307		.0183	.0335
Max	**.1294**	**.2263**	**.2054**	**.1307**	**.1109**	**.1341**	**.1509**
Min	**.0168**	**.0671**	**.056**	**.0183**	**.0183**	**.0181**	**.0183**
Avg	**.0467**	**.1284**	**.1308**	**.0693**	**.0502**	**.0653**	**.0711**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] BU 1147
Substation No/ Name :- 144099 / 33 /11 KV Parle Substation
Feeder No / Name : 201 / Parle Vg GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1791	.1753	.1829	.181	.1463	.1791	.1494
2	.181	.1791	.1494	.1829	.1267	.1612	.1254
3	.1463	.1753	.1463	.1448	.1075	.1578	.1254
4	.1448	.1433	.1494	.1829	.1463	.1326	.1463
5	.1791	.1791	.2218	.2195	.2218	.1402	.1867
6	.2481	.2172	.2987	.2561	.2561	.1402	.2896
7	.4024	.2896	.362	.3326	.2987	.3224	.3292
8	.4252	.2715	.3582	.4656	.4527	.3582	.3467
9	.3856	.362	.3582	.4161	.394	.2686	.3856
10	.3391	.3601	.4748		.3506	.3506	.2835
11	.3391	.3086	.5087	.2012	.3506	.1772	.3467
12	.4359	.2915	.3391	.3772	.3224	.0693	.3086
13	.2984	.2591	.3353	.285	.2534	.2774	.3086
14	.2058	.2103	.2984	.2713	.2353	.2507	.2103
15	.2984	.2058	.2743	.2804	.2353	.2126	.3155
16	.3429	.2374	.2984	.1463	.2172	.2126	.3086
17	.3155	.3052	.3841	.2103	.3258	.2481	.3429
18	.3155	.5373	.4115	.5731	.543	.3189	.3772
19	.6379	.695	.6653	.7316	.6516	.7316	.6584
20	.631	.7392	.6584	.6584		.7167	.6283
21	.5784	.6653	.5601	.5601	.4525	.5175	.5228
22	.3155	.4108	.3772	.3361	.4344	.3696	.3734
23		.3292	.2896	.1848	.2534	.2865	.2195
24	.181	.2507	.2641	.1829	.1478	.1791	.1848
Max	**.6379**	**.7392**	**.6653**	**.7316**	**.6516**	**.7316**	**.6584**
Min	**.1448**	**.1433**	**.1463**	**.1448**	**.1075**	**.0693**	**.1254**
Avg	**.3272**	**.3249**	**.3486**	**.3209**	**.3010**	**.2824**	**.3114**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] BU 1147
Substation No/ Name :- 144099 / 33 /11 KV Parle Substation
Feeder No / Name : 202 / Here Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2155	.1658	.1326	.0166	.0166	.0332	.0168
2	.1989	.1341	.1326	.0166	.0166	.0335	.0168
3	.1823	.1326	.1326	.0166	.0166	.0332	.0168
4	.1823	.1341	.1658	.0166	.0168	.0332	.0168
5	.1823	.1326	.2321	.0166	.0168	.0335	.0168
6	.1943	.2012	.2321	.0166	.0332	.0335	.0168
7	.2652	.2515	.2652	.0332	.0373	.0332	.0168
8	.2818	.3018	.2652	.0166	.0166	.0332	.0168
9	.0332	.0166	.0332	.3315	.0166	.0332	.0168
10	.0166	.0166	.0332		.3688	.4641	.503
11	.0166	.0166	.0166	.547	.4382	.6036	.5197
12	.0166	.0166	.0166	.4144	.4752	.6706	.6036
13	.0166	.0166	.0166	.4475	.5243	.6706	.4694
14	.0166	.0166	.0166	.431	.5571	.6706	.4862
15	.0166	.0166	.0166	.4144	.5243	.6706	.4862
16	.0166	.0166	.0166	.3978	.5243	.6371	.503
17	.0168	.0166	.0166	.3978	.5898	.6371	.503
18	.0168	.0166	.0166	.0166	.0328	.0168	.0168
19	.0335	.0332	.0166	.0166	.0328	.0168	.0335
20	.0351	.0332	.0166	.0166	.0328	.0168	.0335
21	.0351	.0332	.0166	.0166	.0328	.0168	.0335
22		.0332	.0166	.0332	.0328	.0168	.0168
23	.1677	.1658	.0332	.0332	.0328	.0168	.218
24	.1989	.1677	.1658	.0166	.0332	.0332	.0168
Max	**.2818**	**.3018**	**.2652**	**.547**	**.5898**	**.6706**	**.6036**
Min	**.0166**	**.0166**	**.0166**	**.0166**	**.0166**	**.0168**	**.0168**
Avg	**.1024**	**.0869**	**.0843**	**.1600**	**.1841**	**.2274**	**.1914**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] BU 1147
Substation No/ Name :- 144099 / 33 /11 KV Parle Substation
Feeder No / Name : 203 / Patane ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0185	.0164	.0191	.2915	.1966	.1875	.1638
2	.0183	.0164	.0191	.2949	.1989	.192	.16
3	.0181	.0164	.0187	.3277	.2012	.1638	.1677
4	.0183	.0166	.0189	.3441	.1658	.1989	.2012
5	.0179	.0164	.0191	.3563	.1966	.1989	.16
6	.0181	.0164	.0191	.3812	.2347	.2486	.2294
7	.0179	.0164	.0191	.3391	.2543	.3113	.2713
8	.0187	.0166	.0191		.3018	.3441	.2683
9	.0354	.0166	.4694	.0732	.0189	.0164	.0351
10	.3018	.4527		.0181	.0189	.0332	.0183
11	.3605	.5087	.6104	.0185	.0189	.0362	.0185
12	.4409	.5365	.6104	.0189	.0187	.017	.0187
13	.4359	.4694	.6036	.0189	.0187	.0187	.0191
14	.4359	.5304		.0189	.0164	.0189	.0181
15	.4527	.57	.639	.0189	.0185	.017	.0191
16	.4424	.5365	.5868		.0185	.0189	.0191
17	.4144	.4915	.4359	.0189	.0183	.0187	.0191
18	.0328	.0183	.0716	.0187	.0366	.0189	.0191
19	.0328	.0187	.0732	.0185	.0366	.0187	.0351
20	.032	.0189	.0716	.0526	.0366	.0187	.0351
21	.0328	.0187	.0709	.0554	.0358	.0187	.0701
22		.0189	.0754	.0189	.0351	.0187	.0678
23	.0164	.0189	.181	.2641	.1677	.2347	.0179
24	.0187	.0166	.0189	.2949	.2294	.2012	.2035
Max	**.4527**	**.57**	**.639**	**.3812**	**.3018**	**.3441**	**.2713**
Min	**.0164**	**.0164**	**.0187**	**.0181**	**.0164**	**.0164**	**.0179**
Avg	**.1579**	**.1822**	**.2123**	**.1483**	**.1039**	**.1071**	**.0940**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] BU 1147
Substation No/ Name :- 144117 / 33/11 KV Mangaon
Feeder No / Name : 201 / 11 KV Mangao VG GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0895	.0747	.0709	.0724	.0914	.0716	.0732
2	.0905	.0747	.0701	.0554	.0732	.0537	.0739
3	.0905	.0747	.0537	.0732	.0732	.0867	.0554
4	.0716	.0747	.0537	.0905	.0716	.0876	.0554
5	.0732	.0934	.0914	.1097	.0716	.0724	.056
6	.1097	.1294	.0914	.1294	.1097	.0924	.0934
7	.1463	.1463	.128	.128	.1294	.1463	.1478
8	.181	.197	.1448	.1463	.1629	.1417	.1663
9	.1753	.1907	.1578	.1578	.1753	.124	.1578
10	.1387	.1715	.1526	.1753	.1387	.1341	.1543
11	.1402	.1509	.1372	.1417	.1326	.1017	.1341
12	.1357	.1387	.1387	.1075	.1341	.1187	.1457
13	.1187	.1147	.1187	.1075	.1457	.128	.1475
14	.0179	.0876	.104	.1063	.1187	.0857	.104
15	.1326	.1029	.12	.0886	.1134	.096	.0829
16	.1457	.116	.104	.0187	.1006	.0671	.0671
17	.1457	.1147	.0876	.1433	.0995	.1052	.0819
18	.197	.124	.1417	.1509	.1357	.1829	.1063
19	.2715	.2561	.2195	.2534	.2378	.2561	.2195
20		.2353	.2218	.2715	.2172	.2402	.2481
21	.2378	.2328	.1867	.2195	.2172	.2012	.2012
22	.1646	.1646	.1294	.181	.1478	.1848	.1629
23	.1097	.1086	.0747	.0905	.0914	.1086	.0886
24	.0895	.0924	.0716	.0747	.0905	.0709	.0905
Max	**.2715**	**.2561**	**.2218**	**.2715**	**.2378**	**.2561**	**.2481**
Min	**.0179**	**.0747**	**.0537**	**.0187**	**.0716**	**.0537**	**.0554**
Avg	**.1336**	**.1361**	**.1196**	**.1289**	**.1283**	**.1232**	**.1214**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] BU 1147
Substation No/ Name :- 144117 / 33/11 KV Mangaon
Feeder No / Name : 202 / 11 KV Vargao AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0187	.0187	.1147	.1898	.144	.112
2	.0187	.0187	.0187	.2241	.1739	.1311	.112
3	.0187	.0187	.0189	.253	.1718	.1187	.112
4	.0189	.0187	.0187	.285	.1718	.1174	.128
5	.0189	.0373	.0185	.3315	.2214	.1357	.1581
6	.0189	.0373	.0187	.2881	.253	.1492	.1898
7	.0185	.0373	.0187	.3005	.3321	.2267	.2812
8	.0189	.0185	.0187	.5281	.5376	.3906	.4374
9	.0189	.0377	.0377	.0189	.0189		
10	.5506	.4801	.5441	.0181	.0189		.0141
11	.6802	.6081	.5898	.0177	.0175	.0189	.0149
12	.7287	.6802	.5992	.0179	.0177	.0189	.0177
13	.6562	.6964	.5344	.0183	.0189	.0181	.0171
14	.7042	.6081	.583	.0181	.0183	.0189	.0135
15	.7042	.6081	.6226	.0183	.0189	.0189	.0145
16	.6722	.6882	.5281	.0183	.0183	.0189	.0151
17	.5281	.3437	.4428	.0183	.0189	.016	.0166
18	.0373	.0187	.0183	.0191	.0185	.0181	.0181
19	.0373	.0373	.0373	.0377	.0373	.0183	.0185
20		.0377	.0187	.0377	.037	.0187	.0183
21	.0377	.0187	.0189	.0377	.0373	.0187	.0187
22	.0373	.0187	.0189	.0377	.0185	.0187	.0185
23	.0187	.0187	.128	.1524	.1619	.112	.108
24	.0189	.0187	.0187	.1296	.1898	.144	.112
Max	**.7287**	**.6964**	**.6226**	**.5281**	**.5376**	**.3906**	**.4374**
Min	**.0185**	**.0185**	**.0183**	**.0177**	**.0175**	**.016**	**.0135**
Avg	**.2426**	**.2135**	**.2038**	**.1225**	**.1133**	**.0859**	**.0855**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] **BU 1147**
Substation No/ Name :- 144117 / 33/11 KV Mangaon
Feeder No / Name : 203 / 11 KV Lakkikate AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3521	.3605	.2785	.0377	.0566	.0566	.0566
2	.3521	.3605	.2785	.0572		.0377	.0566
3	.3321	.3605	.2652	.0373	.0377	.0566	.0566
4	.3401	.3277	.2622	.0754	.0377	.0566	.056
5	.3768	.3239	.2753	.0572	.0377	.0377	.056
6	.4049	.3887	.2984	.0754	.0754	.0566	.056
7	.5079	.4696	.3887	.0754	.0754	.0566	.0566
8	.6464	.5243	.4696	.0754	.0566	.0566	.0566
9	.0373	.0566	.0754	.0762	.0754	.0566	.0943
10	.0373	.0566	.0754	.779	.9282	.8583	.8817
11	.0377	.0377	.0377	.9503	.9069	.8259	.9614
12	.0377	.0189	.0377	.9393	.8802	.9831	.9448
13	.0377	.0377	.0566		.8539	1.0486	.9667
14	.0185	.0377		.8583	.8697	.9339	1.0322
15	.0189	.0566	.0189	.9717	.8381	.9779	.9503
16	.0566	.0566	.0377	.2984	.8065	.9339	.9503
17	.0566	.0377	.0566	.852	.7748	.9175	.9175
18	.0566	.0566	.0566	.0566	.0566	.0754	.0762
19	.0566	.0566	.0566	.0472	.0566	.0566	.0566
20		.0566	.0754	.0566	.0754	.0566	.0377
21	.0754	.0566	.0754	.0762	.0566	.0566	.0377
22	.0754	.0754	.0754	.0566	.0566	.0566	.0572
23	.3563	.2753	.0566	.0754	.0566	.0566	.0377
24	.4049	.3605	.2785	.0566	.0566	.0566	.0566
Max	**.6464**	**.5243**	**.4696**	**.9717**	**.9282**	**1.0486**	**1.0322**
Min	**.0185**	**.0189**	**.0189**	**.0373**	**.0377**	**.0377**	**.0377**
Avg	**.2033**	**.1854**	**.1560**	**.2888**	**.3359**	**.3486**	**.3546**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
CHANDGAD[023] BU 1147
Substation No/ Name :- 144120 / 33/11 KV Tudiye
Feeder No / Name : 201 / 11 KV Tudiye VG SHEDDABLE RURAL
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.394	.3658	.4251	.3292	.2829	.2534
2	.2896	.362	.3224	.3206	.3258	.2801	.2378
3	.2896	.3142	.3258	.2641	.2926	.2614	.2378
4	.3366	.3189	.333	.2801	.2957	.3395	.2402
5	.3721	.394	.3582	.3142	.2926	.3395	.2614
6	.4525	.4706	.4344	.4344	.362	.3734	.3326
7	.7087	.7186	.6733	.591	.5249	.6283	.6447
8	1.2174	1.1361	1.0562	1.0117	.9602	1.0166	.9774
9	1.3735	1.4083	1.278	1.1934	1.2887	1.1831	1.065
10	1.3757	1.5415	1.3603	1.2763	1.2574		1.0978
11	1.4089	1.4746	1.6057	1.278	.9536	1.1401	1.1904
12	1.5083	1.5546	1.5402	1.2452	.6964	1.3757	1.3094
13	1.5074	1.6194	1.4883	1.1603	.9069	1.4582	1.2289
14	1.4746	1.668	1.5565	1.2308		1.4091	.6173
15	1.5074	1.6356	1.4746	.9069	1.1498	.9448	1.0227
16	1.6221	1.6872	1.5581	1.1797	1.0814	1.1305	1.2597
17	1.6575	1.6964	1.6766	1.2616	1.2955	1.3272	1.4091
18	1.3245	1.4575	1.3763	.8383	1.1142	1.2146	1.2431
19	1.0099	1.0029	1.0056	.7461	.8682	.8954	.9391
20	.9214	.8507	.815	.6379	.7783		.7701
21	.8059	.695	.7164	.6036	.5853	.6584	.6767
22	.5973	.5611	.5792	.4481	.4668	.4805	.499
23	.4572	.4344	.4656	.3734	.3395	.3475	.3801
24	.3292	.4298	.3841	.4435	.3696	.3206	.2772
Max	**1.6575**	**1.6964**	**1.6766**	**1.278**	**1.2955**	**1.4582**	**1.4091**
Min	**.2896**	**.3142**	**.3224**	**.2641**	**.2926**	**.2614**	**.2378**
Avg	**.9532**	**.9927**	**.9479**	**.7693**	**.7189**	**.7912**	**.7571**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
GADHINGLAJ[025] BU 1121
Substation No/ Name :- 144056 / 33/11 KV GADHINGLAJ
Feeder No / Name : 201 / 11 KV GADHINGLAJ GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5853	.5853	.5853	.5853	.695	.6036	.5853
2	.5487	.5853	.5853	.5853	.6584	.6036	.5853
3	.5487	.5487	.5487	.5487	.6584	.5853	.5853
4	.5487	.5487	.5487	.7316	.6219	.5853	.5853
5	.5853	.6036	.6584	1.0608	.695	.6584	.695
6	.7682	.8413	.8413	1.0974	.7316	.7682	1.0608
7	1.134	1.0608	.9511	1.0974	.9877	1.0059	1.0974
8	1.2803	1.262	1.0974	1.2071	1.2071	1.134	1.2803
9	1.3032	1.1706	1.2437	1.134	1.2071	1.3169	1.0608
10	1.1706	1.1317	1.134	1.0791	1.134	1.134	.8596
11	1.2308	1.1317	1.0974	1.0608	1.134	1.0974	.823
12	1.2071	1.0974	1.0608	1.0059	.9877	1.0974	.8048
13	1.0974	1.0242	.9511	.8413	.9145	1.0974	.8779
14	1.0498	.2561	.9145	.9145	.9145	1.0608	.9145
15	.9116	1.094	.8779	.8048	1.0974	1.0242	.9511
16	1.0242	.9511	.9145	.823	1.0242	1.134	1.0242
17	1.0608		.9877	.9511	1.0608	1.1523	.9511
18	1.4449		1.1706	1.0608	1.39	1.39	1.4632
19	1.6827		1.5729	1.4266	1.5729	1.7193	1.7558
20	1.5729		1.4266	1.39	1.4815	1.6461	1.5729
21	1.39		1.2803	1.2803	1.2071	1.4266	1.3535
22	1.0277		1.0974	1.0242	1.0059	1.0974	1.134
23			.7316	.695	.8413	.695	.7316
24	.5853	.6219	.6219	.5853	.695	.6219	.6219
Max	**1.6827**	**1.262**	**1.5729**	**1.4266**	**1.5729**	**1.7193**	**1.7558**
Min	**.5487**	**.2561**	**.5487**	**.5487**	**.6219**	**.5853**	**.5853**
Avg	**1.0330**	**.8538**	**.9541**	**.9579**	**.9968**	**1.0273**	**.9739**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
GADHINGLAJ[025] BU 1121
Substation No/ Name :- 144056 / 33/11 KV GADHINGLAJ
Feeder No / Name : 204 / 11 KV Uttur Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6401	.1886	.1867	.1829	.7202	.7125	.7499
2	.6401	.1886	.1886	.1829	.7042	.7125	.7499
3	.6081	.2075	.1886	.1829	.6642	.6802	.7499
4	.6081	.2263	.1886	.1829	.6722	.7773	.7811
5	.6401	.2263	.2075	.1829	.7682	.8097	1.0623
6	.7682	.2641	.2263	.2195	1.012	.8745	1.4373
7	1.0242	.3772	.2641	.2926	1.6644	1.2955	1.6248
8	1.3032	.3772	.3772	.2926	2.0485	1.7166	.2195
9	.2172	.2926	.3395	.3018	.2561	.2263	.2263
10	1.3123	1.8747	1.9524	.3018	.2561	.2641	.2263
11	2.1125	2.2184	1.9204	.2829	.2926	.2641	.2075
12	2.4966	1.9372	2.4669	.2641	.2195	.2452	.2263
13	2.5606	2.4996	2.6246	.1886	.2195	.1509	.2263
14	2.7511	2.6246	2.5606	.1509	.1463	.2263	.2263
15		2.6566	2.6566	.1509	.1463	.2263	.2263
16	2.2348	2.4371	2.5606	.1886	.2195	.2641	.2075
17	1.8947		2.1948	.2263	.3018	.2561	.3018
18	.3395		.3658	.3018	.3395	.2926	.3395
19	.3772		.3658	.3772	.415	.3658	.3772
20	.3772		.3658	.3772	.3584	.3658	.3772
21	.0377		.3658	.3206	.3018	.3658	.3584
22	.3018		.2926	.2641	.2829	.2561	.2263
23			.1829	.7186	.6478	.7499	.8223
24	.6401	.2829	.2452	.1829	.7202	.6802	.7499
Max	**2.7511**	**2.6566**	**2.6566**	**.7186**	**2.0485**	**1.7166**	**1.6248**
Min	**.0377**	**.1886**	**.1829**	**.1509**	**.1463**	**.1509**	**.2075**
Avg	**1.0857**	**1.1106**	**.9703**	**.2632**	**.5574**	**.5324**	**.5292**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
GADHINGLAJ[025] BU 1121
Substation No/ Name :- 144056 / 33/11 KV GADHINGLAJ
Feeder No / Name : 205 / 11 KV Nool Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.144	.0377	.0377	.0183	.4111	.4049	
2	.144	.0189	.0189	.0183	.3953	.4049	.3437
3	.144	.0189	.0189	.0183	.4001	.3887	.3437
4	.144	.0189	.0189	.0183	.3953	.421	.3437
5	.144	.0189	.0189	.0183	.4481	.4534	.3437
6	.176	.0189	.0189	.0183	.4744	.4696	.4687
7	.192	.0189	.0189	.0183	.5693		.4999
8	.2561	.0377	.0189	.0183	.6722	.583	.5853
9	.1646	.0366	.0377	.0189	.0366	.0189	.0189
10	.9602	.9061	.6722	.0189	.0183	.0189	.0189
11	.6554	.9374	.9488	.0189	.0183	.0189	.0189
12	.9602	.9717	1.0242	.0189	.0366	.0189	.0189
13	.8962	1.0623	1.0242	.0189	.0366	.0377	.0189
14	1.0883	1.1248	1.1694		.0366	.0189	.0189
15	1.1203	1.0623	1.0242	.0189	.0366	.0189	
16	1.1336	1.0311		.0189	.0366	.0189	.0189
17	.9998		.8749	.0189	.0189	.0183	.0377
18	.0377		.0366	.0189	.0189	.0366	.0377
19			.0366	.0377	.0189	.0366	.0377
20	.0377		.0366	.0377	.0189	.0366	.0377
21	.0377		.0366	.0377	.0189	.0366	.0377
22	.0377		.0183	.0377	.0189	.0183	.0377
23			.0183	.4481	.3563	.3125	.3281
24	.144	.0377	.0377	.0183	.4481	.421	.3125
Max	**1.1336**	**1.1248**	**1.1694**	**.4481**	**.6722**	**.583**	**.5853**
Min	**.0377**	**.0189**	**.0183**	**.0183**	**.0183**	**.0183**	**.0189**
Avg	**.4372**	**.4329**	**.3116**	**.0406**	**.2058**	**.1831**	**.1785**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
GADHINGLAJ[025] BU 1121
Substation No/ Name :- 144056 / 33/11 KV GADHINGLAJ
Feeder No / Name : 207 / 11 KV WATERWORKS NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2012	.1886	.2195	.2926	.2561	.3018
2	.2075	.2012	.1886	.1829	.2263	.2195	.1886
3	.1886	.1829	.1886	.1829	.1867		.1829
4	.1886	.1829	.1886	.1829	.1886	.2012	.1886
5	.1886	.1829	.2075	.1829	.1886	.2012	.1829
6	.2263	.2012	.2263	.1829	.2075	.1829	.1829
7	.2263	.2195	.2452	.2195	.2263	.2012	.2195
8	.2378	.2743	.4527	.2195	.2452	.2012	.2926
9	.5121	.4024	.4527	.2926	.4024	.3772	.3292
10	.439	.415	.4527	.3658	.4024	.3772	.3475
11	.3658	.3395	.415	.3292	.3658	.3584	.3292
12	.2641	.2926	.3206	.3292	.2926	.2829	.3475
13	.3018	.2641	.2829	.2481	.2926	.2641	.2926
14	.2743	.2641	.2829	.2561	.2926	.2829	.2195
15	.2378	.2263	.2829	.2743	.2926	.2829	.2012
16	.2561	.2263	.2263	.2378	.2195	.2829	.2075
17	.1829		.2263	.2263	.2452	.2561	.2452
18	.2195		.2195	.1886	.2012	.1829	.2075
19	.2195		.2195	.2075	.1829	.1829	.2075
20	.1772		.2195	.1886	.1463	.1829	.1886
21	.1646		.2195	.2075	.2195	.1829	.1886
22	.2561		.2926	.3395	.2926	.3018	.2829
23			.3658	.3584	.2195	.415	.3772
24	.3018	.2195	.1886	.2926	.3395	.2561	.415
Max	**.5121**	**.415**	**.4527**	**.3658**	**.4024**	**.415**	**.415**
Min	**.1646**	**.1829**	**.1886**	**.1829**	**.1463**	**.1829**	**.1829**
Avg	**.2549**	**.2527**	**.2731**	**.2465**	**.2570**	**.2579**	**.2553**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
GADHINGLAJ[025] BU 1121
Substation No/ Name :- 144056 / 33/11 KV GADHINGLAJ
Feeder No / Name : 210 / 11 KV Uttur VG GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2172	.2012	.2172	.1829	.2172	.2195	.2195
2	.2172	.2012	.1991	.1829	.181	.2012	.2195
3	.2172	.2012	.1991	.1829	.181	.1829	.2195
4	.2172	.2012	.181	.1829	.181	.2195	.2195
5	.2172	.2195	.2534	.2195	.2172	.2561	.3292
6	.2896	.2561	.2896	.2926	.2715	.3292	.3658
7	.3801	.3292	.362	.3658	.362	.3292	.439
8	.439	.3658	.362	.3841	.362	.4207	.3292
9	.439	.4024	.4344	.3658	.4755	.4525	.3841
10	.3982	.3292	.4024	.3475	.4024	.4525	.4572
11	.439	.4024	.5068	.3475	.439	.4344	.4024
12	.3982	.2926	.4706	.3475	.3658	.3801	.3841
13	.3258	.2926	.2715	.2926	.3658	.3439	.2926
14	.3658	.2926	.2896	.2561	.3658	.2896	.2926
15	.4024	.2926	.2896	.2926	.3658	.2896	.3292
16	.439	.2926	.2896	.2561	.3841	.362	.2896
17	.439		.4024	.2896	.3658	.3658	.362
18			.439	.3982	.4755	.4755	.5068
19	.567		.6219	.543	.6219	.5487	.6335
20	.5304		.6584	.543	.567	.5121	.5792
21	.4755		.4755	.4525	.4024	.439	.5068
22	.4207		.3841	.362	.3841	.2926	.3801
23			.1829	.2172	.2743	.2195	.4163
24	.2172	.2195	.2353	.1829	.2172	.2195	.2195
Max	**.567**	**.4024**	**.6584**	**.543**	**.6219**	**.5487**	**.6335**
Min	**.2172**	**.2012**	**.181**	**.1829**	**.181**	**.1829**	**.2195**
Avg	**.3660**	**.2819**	**.3507**	**.3120**	**.3519**	**.3432**	**.3657**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
GADHINGLAJ[025] BU 1121
Substation No/ Name :- 144056 / 33/11 KV GADHINGLAJ
Feeder No / Name : 211 / 11KV Belbag GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.439	.4572	.439	.439	.5121	.4854	.5121
2	.4024	.439	.439	.439	.5121	.4854	.5121
3	.4024	.439	.439	.439	.5121	.4854	.5121
4	.4024	.439	.5487	.439	.4755	.5041	.5121
5	.439	.5121	.5853	.5487	.4755	.5041	.5853
6	.5487	.567	.6584	.6584	.567	.5228	.7682
7	.7316	.6401	.6584	.695	.7316	.7095	.8048
8	.788	.8413	.7682	.8779	.8413	.9522	.8779
9	.7964	.7499	.8048	.8215	.8779	.8779	.8488
10	.7682	.8413	.8413	.8215	.7682	.9145	.811
11	.7537	.8779	.9511	.7095	.8048	.8779	.8215
12	.8048	.8779	.8413	.6535	.7316	.8413	.8215
13	.7316	.695	.7682	.6348	.7316	.823	.7095
14	.543	.7316	.7682	.6219	.7316	.7316	.6979
15	.6219	.7316	.7316	.5975	.7316	.7316	.6908
16	.7682	.8413	.8048	.5601	.6584	.7682	.2926
17	.7316		.8048	.6401	.8215	.7682	.8048
18	1.0277		.8779	.823	1.0456	1.0242	.9877
19	1.2071		1.1706	1.1157	1.1949	1.2437	1.2071
20	1.0374		1.2437	1.0974	1.0829	1.1706	1.134
21	.9242		.8048	.9145	.8402	.9145	.9511
22	.8299		.7682	.7865	.7842	.7316	.8048
23			.5304	.5853	.5788	.5121	.5487
24	.439	.4755	.439	.439	.5487	.5228	.5121
Max	**1.2071**	**.8779**	**1.2437**	**1.1157**	**1.1949**	**1.2437**	**1.2071**
Min	**.4024**	**.439**	**.439**	**.439**	**.4755**	**.4854**	**.2926**
Avg	**.7017**	**.6563**	**.7369**	**.6816**	**.7317**	**.7543**	**.7387**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
GADHINGLAJ[025] BU 1121
Substation No/ Name :- 144069 / 33/11 KV KAULAGE
Feeder No / Name : 201 / 11 Kv Karambali Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5068	.1478	.1029	.1448	.7133	.6173	.5487
2	.5068	.128	.1029	.1448	.695	.6173	.5304
3	.5068	.128	.1029	.1448	.6401	.6173	.5359
4	.5249	.128	.1029	.1448	.6767	.6173	.5359
5	.543	.1463	.1029	.1629	.7316	.6173	.5487
6	.5792	.1829	.1543	.181	1.0242	.6859	.6584
7	.6878	.2378	.1715	.181	1.134	.9774	.9511
8	.8326	.2378	.1715	.2172	1.3169	1.0802	1.134
9	.1991	.2926	.3086	.2172	.2926		.2561
10	1.166	1.1523	1.3535	.3077	.2926	.2172	
11	1.286	1.5203	1.6461	.1829	.2058	.2172	.2743
12		1.5565	1.6278		.2743	.1991	.2743
13	1.4575	1.5565	1.6095		.0686	.1991	.2195
14		1.5384	1.6278		.1886	.181	.1646
15	1.3375		1.5181	.2195	.2401	.1991	.2195
16	1.4815	1.5203	1.5546	.2561	.2915	.1991	.2561
17	1.4083	1.4661	1.4815		.2915	.2172	.2378
18	.1829	.3077	.2402	.2561	.3086	.3018	.2896
19	.2926	.2743	.2534	.2926	.3258		.1991
20	.2561	.2401		.2743	.2743	.2829	.2172
21	.2743	.2401	.2896	.2378	.2572	.2641	.2172
22	.2195	.1715	.2353	.2195	.2058	.2195	.181
23	.1829	.1372	.1448	.695	.6001	.5487	.5792
24	.5068	.1463	.1029	.1267	.695	.6173	.5487
Max	**1.4815**	**1.5565**	**1.6461**	**.695**	**1.3169**	**1.0802**	**1.134**
Min	**.1829**	**.128**	**.1029**	**.1267**	**.0686**	**.181**	**.1646**
Avg	**.6790**	**.5851**	**.6524**	**.2303**	**.4893**	**.4406**	**.4164**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
GADHINGLAJ[025] BU 1121
Substation No/ Name :- 144069 / 33/11 KV KAULAGE
Feeder No / Name : 202 / 11 KV Kaulage Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.431				.5967	.5639	.5765
2	.431					.5639	.57
3	.431				.5801	.5639	.5765
4	.431				.5636	.5639	.57
5	.4475				.5967	.5639	.5636
6	.4807				.6299	.6097	.5967
7	.4807				.6464	.6706	.6299
8	.5138				.7127	.6706	.6539
10	.4877	.663	.7625				
11	.7468	.779	.8951				
12	.823	.8619	.9116				
13	.8573	.8951	.9282				
14	.8688	.8951	.8951				
15	.7468		.8785				
16	.8288	.8785	.8288				
17	.7956	.8288	.779				
23				.5304	.583	.5765	.547
24	.431				.5967	.5639	.5765
Max	**.8688**	**.8951**	**.9282**	**.5304**	**.7127**	**.6706**	**.6539**
Min	**.431**	**.663**	**.7625**	**.5304**	**.5636**	**.5639**	**.547**
Avg	**.6019**	**.8288**	**.8599**	**.5304**	**.6118**	**.5911**	**.5861**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
GADHINGLAJ[025] **BU 1121**
Substation No/ Name :- 144069 / 33/11 KV KAULAGE
Feeder No / Name : 203 / 11 KV Ainapur Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6226	.7926	.7611			.1341
2		.6226	.7926	.7611			
3		.6226		.7611			
4		.6226	.7926	.7773			
5		.6554	.823	.7773			
6		.7045	.8383	.8097			
7		.8848	.945	1.004			
8		.9995	1.1431	1.0688			
10				1.5384	1.704	1.8138	1.7695
11				1.7204	1.7985	1.8138	1.917
12					1.9357	1.8947	1.9006
13				1.6876	1.9814	1.9271	1.9334
14				1.704	2.2977	1.8461	
15				1.5893	1.8595	1.9271	1.9498
16				1.9006	1.8747	1.7652	1.9989
17				1.7859	1.7985	1.7814	1.8351
23	.5898	.7926	.7287				
24		.6554	.7926	.7611			
Max	**.5898**	**.9995**	**1.1431**	**1.9006**	**2.2977**	**1.9271**	**1.9989**
Min	**.5898**	**.6226**	**.7287**	**.7611**	**1.704**	**1.7652**	**.1341**
Avg	**.5898**	**.7183**	**.8498**	**1.2130**	**1.9063**	**1.8462**	**1.6798**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
GADHINGLAJ[025] BU 1121
Substation No/ Name :- 144069 / 33/11 KV KAULAGE
Feeder No / Name : 204 / 11 KV Hiralge(karmbali) Vg GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2033	.2402	.2058	.2402	.2033	.2058	.2427
2	.2033	.2402	.2058	.2218	.2402	.2058	.2402
3	.2033	.2402	.2058	.2218	.2402	.2058	.2402
4	.2218	.2402	.0343	.2587	.2218	.2058	.2587
5	.2957	.3326	.2401	.2772	.3326	.2743	.3361
6	.3921	.4066	.3258	.3142	.4066	.3258	.4066
7	.499	.4805	.4115	.4251	.462	.3944	.4805
8	.4435	.4805	.4458	.4805	.4805	.4287	.4805
9	.462	.4805	.4458	.4805	.499		.443
10	.4115	.4251	.439	.3881	.4805	.4435	.4607
11	.4458	.4251	.462	.3696	.4115	.4066	.3696
12		.3881	.4805	.3326	.3601	.4435	.4435
13	.2915	.4251	.3696	.2772	.3429	.3326	.3696
14	.2572	.3696	.3696	.2402	.2743	.3142	.3142
15	.3429		.3696	.2957	.3429	.3511	.3142
16	.462	.3511	.3511	.2587	.2915	.3696	.3511
17	.3696	.3511	.4066	.3511	.3429	.3881	.4251
18	.5359	.5175	.4805	.4251	.4287		.462
19	.7207	.6859	.7023	.6283	.703		.7207
20	.6653	.583		.6099	.6516	.6584	.6283
21	.5914	.5144	.7207	.5359	.5144	.5487	.5544
22	.462	.3601	.462	.4066	.4115	.3921	.4251
23	.3326	.2572	.3142	.2587	.2572	.3921	.2772
24	.2218	.2587	.2058	.2587	.2218	.2401	.2378
Max	**.7207**	**.6859**	**.7207**	**.6283**	**.703**	**.6584**	**.7207**
Min	**.2033**	**.2402**	**.0343**	**.2218**	**.2033**	**.2058**	**.2378**
Avg	**.3928**	**.3936**	**.3763**	**.3565**	**.3800**	**.3584**	**.3951**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
GADHINGLAJ[025] BU 1121
Substation No/ Name :- 144069 / 33/11 KV KAULAGE
Feeder No / Name : 205 / KCL **NON SHEDDABLE EXPRESS HV FEEDERS**
Feeder KV- 11 / OUTGOING **(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0189	.0191	.0191	.0189	.0191	
2	.0191	.0189	.0191	.0191	.0189	.0191	
3	.0191	.0189	.0191	.0191	.0189	.0191	
4	.0191	.0189	.0191	.0191	.0189	.0191	
5	.0191	.0189	.0191	.0191	.0189	.0191	
6	.0191	.0189	.0191	.0191	.0189	.0191	
7	.0191	.0189	.0191	.0191	.0189	.0191	
8	.0191	.0189	.0191	.0191	.0189	.0191	
9	.0191	.0189	.0191	.0191	.0189	.0191	
10	.0191	.0189	.0189	.0191	.0189	.0191	
11	.0191	.0191	.0189	.0189	.0191	.0191	.0189
12	.0191	.0191	.0189	.0189	.0191	.0191	.0189
13	.0191	.0191	.0189	.0189	.0191	.0191	.0189
14	.0191	.0191	.0189	.0189	.0191	.0191	.0189
15	.0191		.0189	.0189	.0191	.0191	.0189
16	.0189	.0191	.0189	.0189	.0191	.0191	.0189
17	.0189	.0191	.0189	.0189	.0191	.0191	.0189
18	.0189	.0191	.0191	.0189	.0191		.0191
19	.0189	.0191	.0191	.0189	.0191		.0191
20	.0189	.0191		.0189	.0191		.0191
21	.0189	.0191	.0191		.0191		
22	.0189	.0191	.0191	.0189	.0191		.0191
23	.0189	.0191	.0191	.0189	.0191		.0191
24	.0191	.0189	.0191	.0191	.0189	.0191	
Max	**.0191**	**.0191**	**.0191**	**.0191**	**.0191**	**.0191**	**.0191**
Min	**.0189**	**.0189**	**.0189**	**.0189**	**.0189**	**.0191**	**.0189**
Avg	**.0190**	**.0190**	**.0190**	**.0190**	**.0190**	**.0191**	**.0190**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
GADHINGLAJ[025] BU 1121
Substation No/ Name :- 144075 / 33/11 KV MIDC Sub-Station
Feeder No / Name : 201 / 11 KV MIDC SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1494	.2054	.168	.1494	.1307	.2054
2	.0934	.0747	.2054	.1494	.1307	.0934	.168
3	.0934	.0747	.168	.0934	.0934	.0747	.0747
4	.0747	.0747	.0747	.056	.0934	.0747	.0747
5	.0747	.0747	.056	.056	.0747	.0747	.0747
6	.0747	.0747	.0747	.056	.0747	.0747	.0747
7	.0747	.0934	.0747	.056	.0934	.3174	.0747
8	.3361	.0934	.0934	.0747	.4294	.3361	.0934
9	.3734	.0934	.0934	.0747	.3174	.4668	
10	.3734	.5415	.4854	.0934	.4854	.2054	
11	.1867	.5228	.5415	.168	.5041	.5228	
12	.1867	.5601	.5041	.1494	.5228	.5601	.2054
13	.2427	.5601	.5041	.1307	.5228	.5415	.2054
14	.5041	.5228	.2614		.2801	.5041	.5415
15	.2614	.0934	.1867	.1307	.5041	.4854	.4854
16	.112	.1494	.1307	.112	.4481	.2614	.4854
17	.112	.0934	.0934	.0934	.2614	.0934	.1494
18	.112	.112	.0934	.0747	.112	.0747	.112
19	.1307	.0747	.1494	.0934	.0934	.112	.0747
20	.1494	.2241	.2427	.1494	.1867	.1307	.168
21	.2054	.2054	.1867	.2054	.2054	.168	.2054
22	.2054	.1867	.1867	.2241	.2054	.168	.2054
23	.2054	.2054	.2054	.1867	.2054	.2054	.1867
24	.168	.2054	.2241	.168	.1867	.168	.2054
Max	**.5041**	**.5601**	**.5415**	**.2241**	**.5228**	**.5601**	**.5415**
Min	**.0747**	**.0747**	**.056**	**.056**	**.0747**	**.0747**	**.0747**
Avg	**.1875**	**.2108**	**.2101**	**.1202**	**.2575**	**.2435**	**.1938**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
GADHINGLAJ[025] BU 1121
Substation No/ Name :- 144075 / 33/11 KV MIDC Sub-Station
Feeder No / Name : 202 / Shendri AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0362	.2374	.2743	.2572	.0351	.0181	.0181
2	.0181	.2374	.2572	.2572	.0173	.0181	.0181
3	.0181	.2374	.2572	.2572	.0173	.0181	.0181
4	.0181	.2374	.2572	.2572	.0173	.0181	.0181
5	.0362	.2883	.2915	.2572	.0173	.0362	.0362
6	.0724	.373	.3086	.3258	.0347	.0724	.0543
7	.1086	.6443	.5658	.3772	.0526	.0905	.0905
8	.1086	.78	.703	.6001	.0701	.0724	.1086
9	.1086	.1086	.1086	.1086	.0905	.0724	
10	.0543	.0905	.1267	.8309	.8097	.763	.8478
11	.1267	.0905	.1086	.9414	1.0364	1.004	.9496
12	.0905	.0543	.1086	.9907	1.166	1.1012	1.1191
13	.0905	.0724	.1086	1.1069	1.0978	1.0978	1.1869
14	.1086	.0905	.0905		1.085	1.0526	1.1022
15	.0543	.0905	.0362	1.0202	1.1174	1.1191	1.0343
16	.0905	.0905	.0905	.4696	1.085	1.1191	1.0174
17	.0526	.0701	.0701	.8059	1.1361	1.0852	.9835
18	.0876	.0701	.0701	.0709	.1086	.0905	.0905
19	.1052	.0876	.0876	.0876	.1267	.1086	.1086
20	.0876	.0701	.0701	.0876	.1086	.0905	.0905
21	.0701	.0701	.0876	.0701	.0905	.0905	.0724
22	.0543	.0876	.0701	.0526	.0724	.0543	.0543
23	.2374	.1886	.2401	.0351	.0362	.0543	.0362
24	.0543	.2374	.2572	.2572	.0351	.0181	.0181
Max	**.2374**	**.78**	**.703**	**1.1069**	**1.166**	**1.1191**	**1.1869**
Min	**.0181**	**.0543**	**.0362**	**.0351**	**.0173**	**.0181**	**.0181**
Avg	**.0787**	**.1919**	**.1936**	**.4141**	**.3943**	**.3860**	**.3945**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
GADHINGLAJ[025] BU 1121
Substation No/ Name :- 144089 / 33/11KV Bhadgaon s/stn
Feeder No / Name : 201 / Nool Gaothan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1829	.1848	.181	.1991	.181	.181
2	.1867	.1848	.1905	.181	.181	.181	.181
3	.1867	.1867	.1848	.181	.181	.181	.1867
4	.2241		.1867	.2172	.2172	.2172	.2172
5	.2241	.2218		.2534	.2534	.2534	.2353
6	.3224	.3361		.2896	.2896	.362	.2896
7	.4382	.4066	.4108	.3982	.362	.4525	.362
8	.4075	.3582	.3658	.362	.362	.4706	.3734
9	.3721	.3982	.362	.3506	.3898	.3734	.3721
10	.3721	.3982	.3506	.4031	.3721	.3506	
11	.3898	.3982	.4031	.3506	.3366	.3155	.3721
12	.3189	.3921	.4557	.3467	.4075	.3506	.3721
13	.3544	.4525	.3856	.2804	.3366	.3258	.3898
14	.3721	.4344	.3582	.3155	.3544	.3506	.2303
15	.3189	.3439	.2454	.3155	.3721	.3467	.2481
16	.3012	.3439	.3292	.2454	.3366	.3391	.2481
17	.2303	.3982	.3544	.2804	.3012	.4344	.3721
18	.4163	.4887	.4784	.4344	.3366	.4525	.4607
19	.6335	.724	.6733	.6401	.6201	.543	.6556
20	.5792	.6516	.6556	.6335	.5847	.5973	.6379
21	.5228	.4527	.4887	.5487	.4784	.5249	.5228
22	.3361	.3395	.362	.362	.362	.3174	.3258
23	.2195	.2218	.2353	.2353	.2427	.1991	.181
24	.1829	.1848	.1848	.1991	.2172	.181	.181
Max	**.6335**	**.724**	**.6733**	**.6401**	**.6201**	**.5973**	**.6556**
Min	**.1829**	**.1829**	**.1848**	**.181**	**.181**	**.181**	**.181**
Avg	**.3374**	**.3696**	**.3566**	**.3335**	**.3372**	**.3459**	**.3302**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
GADHINGLAJ[025] BU 1121
Substation No/ Name :- 144089 / 33/11KV Bhadgaon s/stn
Feeder No / Name : 202 / Bhadgaon Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.5281	.5921	.5344	.0543	.0724	.056
2	.0373	.5218	.5992	.5506	.0543	.0747	.056
3	.0377	.5281	.5921	.5506	.0543	.0724	.056
4	.0377	.5344	.5992	.5668	.0543	.0724	.056
5	.0373	.5601	.6401	.6154	.0543	.0724	.0543
6	.0366	.6722	.7682	.6478	.0543	.0724	.0724
7	.0526	1.004	.9393	.7773	.0934		.0905
8	.0486	1.1363	1.1469		.0905	.1052	.0934
9	.0486	.0747	.0549	.0526	.0972	.112	.081
10	.0486	.1372	.0526	1.17	1.3117	1.3565	
11	.0648	.1629	.1387	1.3592	1.4737	1.4089	1.4413
12	.0486		.1463	.663	1.5893	1.5238	1.5223
13			.1448	1.2717	1.5074	1.5893	1.5384
14		.168	.1227	1.326	1.5708	1.5074	1.5384
15		.1086	.1227	1.3565	1.5384	1.4918	1.5061
16		.1017	.1134	1.3717	1.5061	1.5261	1.4899
17	.0486	.1494	.0972	.964	1.4737	1.3927	1.2631
18	.0747	.1629	.0972	.1307	.1134	.112	.0648
19	.1267	.181	.1296	.112	.1134	.1267	.1134
20	.1267	.1629	.1296	.112	.0972	.112	.0972
21	.1143	.1715	.1267	.0934	.0972	.1086	.1086
22	.0943	.1132	.1086	.0724	.0905	.0724	.0724
23	.1107	.5668	.5792	.0543	.0747	.0543	.0543
24	.0373	.5281	.5992	.5344	.0543	.0724	.0543
Max	**.1267**	**1.1363**	**1.1469**	**1.3717**	**1.5893**	**1.5893**	**1.5384**
Min	**.0366**	**.0747**	**.0526**	**.0526**	**.0543**	**.0543**	**.0543**
Avg	**.0635**	**.3761**	**.3600**	**.6473**	**.5508**	**.5699**	**.4991**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
GADHINGLAJ[025] BU 1121
Substation No/ Name :- 144089 / 33/11KV Bhadgaon s/stn
Feeder No / Name : 203 / Chennikuppi Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.0754	.0943	.0848	.4534	.4534	.4534
2	.4298	.0754	.0953	.0848	.4534	.4534	.4534
3	.4607	.0754	.0953	.0857	.4534	.4858	.4534
4	.4607	.0754	.0953	.0905	.4534	.5506	.4858
5	.4908	.1132	.0943	.1029	.4858	.5668	.5344
6	.5144	.132	.1334	.12	.5344	.6316	.583
7	.5935	.1524	.1524	.1267	.7773	.8583	.7449
8	.6554	.1524	.1524	.1357	1.0526	1.1174	1.004
9	.1311	.1086	.1848	.1187	.1311	.1494	.0983
10	1.065	.9878	1.0277	.1341	.1311	.112	
11	1.1142	1.1012	1.2431	.116	.1475	.0905	.1311
12	1.2452	1.1012	1.3413	.1017	.1147	.0701	.1311
13	1.2944	1.247	1.326	.1052	.0983	.112	.1311
14	1.278	1.291	1.326	.0876	.0983	.104	.1311
15	1.278	1.2631	1.2597	.0876	.0983	.0995	.1311
16	1.2452	1.2631	1.2125	.0876	.0983	.1029	.1147
17	.5571	1.0688	1.0486	.0876	.0983	.1494	.1147
18	.0914	.1629	.1311	.1307	.1475	.1629	.1311
19	.1829	.181	.1638	.181	.1802	.181	.1802
20	.1629	.181	.1475	.2054	.1638	.1629	.1638
21	.1524	.1905	.1448	.1867	.1638	.1448	.1867
22	.1143	.1143	.1086	.1086	.1307	.1086	.1267
23	.0943	.0953	.0914	.4049	.421	.421	.4372
24	.2926	.0754	.0953	.0848	.4534	.4534	.4534
Max	**1.2944**	**1.291**	**1.3413**	**.4049**	**1.0526**	**1.1174**	**1.004**
Min	**.0914**	**.0754**	**.0914**	**.0848**	**.0983**	**.0701**	**.0983**
Avg	**.5944**	**.4702**	**.4902**	**.1275**	**.3058**	**.3226**	**.3206**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
GADHINGLAJ[025] BU 1121
Substation No/ Name :- 144089 / 33/11KV Bhadgaon s/stn
Feeder No / Name : 204 / Guddai AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1718	.25	.2591		.0362	.0362
2		.1739	.25	.2591		.0362	.0362
3		.1718	.2469	.2591		.0362	.0373
4		.176	.253	.2591		.0362	.0543
5		.1718	.2561	.2591		.0362	.0543
6		.1898	.2932	.3077		.0362	.0543
7		.2622	.3887	.3077		.0543	.056
8		.2812	.3201	.3239		.0543	.056
9						.0747	.0655
10				.4973	.6554	.6783	.7209
11				.6706	.8356	.7716	.8356
12				.4973	.9012	.7888	.8684
13				.7011	.8684	.9036	.8848
14				.6783	.9012	.8356	.8356
15				.6783	.852	.8573	.8029
16				.7716	.7537	.7969	.7701
17				.6783	.7209	.7287	.7209
18				.0934	.0492	.0543	.0492
19				.0905	.0492	.0543	.0492
20				.0914	.0492	.0747	.0492
21				.0934	.0492	.0543	.0543
22				.0724	.0543	.0543	.0543
23	.1718	.0152	.3077		.0362	.0373	.0486
24		.1718	.253	.2591		.0362	.0362
Max	**.1718**	**.2812**	**.3887**	**.7716**	**.9012**	**.9036**	**.8848**
Min	**.1718**	**.0152**	**.2469**	**.0724**	**.0362**	**.0362**	**.0362**
Avg	**.1718**	**.1786**	**.2819**	**.3685**	**.4840**	**.2969**	**.3013**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
GADHINGLAJ[025] BU 1121
Substation No/ Name :- 144089 / 33/11KV Bhadgaon s/stn
Feeder No / Name : 205 / 11 KV JARALI AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2804				.7449	.7449	.6706
2	.3506				.7449	.7449	.6478
3	.4207				.7449	.7449	.6478
4	.4458				.8097	.7773	.7125
5	.5144				.8421	.8421	.7449
6	.5144				.9892	.8907	.7935
7	.663				1.1822	1.1498	1.0526
8	.7865				1.3441	1.3279	1.1012
10	1.4746	1.7177	1.6575				
11	1.7368	1.8785	1.989				
12	1.8023	2.0814	1.989				
13	1.8187	1.8785	1.9559				
14	1.2125	1.8785	1.9334				
15	1.6385	1.7328	1.9559				
16	1.7532	1.8785	1.8023				
17		1.7652					
23				.7773	.6802	.664	.6154
24	.2534				.7773	.7449	.6478
Max	**1.8187**	**2.0814**	**1.989**	**.7773**	**1.3441**	**1.3279**	**1.1012**
Min	**.2534**	**1.7177**	**1.6575**	**.7773**	**.6802**	**.664**	**.6154**
Avg	**.9791**	**1.8514**	**1.8976**	**.7773**	**.8860**	**.8631**	**.7634**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
GADHINGLAJ[025] BU 1121
Substation No/ Name :- 144089 / 33/11KV Bhadgaon s/stn
Feeder No / Name : 206 / 11 KV SAMARTHNAGAR VG GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1097	.1109	.1086	.112	.1086	.112
2	.1307	.1109	.112	.1086	.112	.1086	.112
3	.1307	.1097	.112	.1086	.112	.1086	.1307
4	.1307	.1109	.112	.1086	.112	.1267	.1307
5	.1494	.1294	.112	.112	.1307	.1448	.1494
6	.1829	.1867	.1509	.1494	.1494	.168	.1867
7	.2374	.2402	.2195	.2172	.2427	.2172	.2241
8	.2303	.2172		.2172	.2427	.2534	.2427
9	.1949	.1629	.2427	.1886	.2126	.2241	.2126
10	.2481	.2534	.2427	.1696	.2126	.2195	.2126
11	.2481	.2353	.2103	.1696	.2481	.2328	.2126
12	.2126	.2427	.2149	.1526	.2303	.1578	.2126
13	.2126	.2172	.2172	.1753	.1772	.1791	.2126
14	.2195	.181	.2103	.1578	.2126	.1734	.2126
15	.1949	.181	.181	.1612	.2126	.1715	.1949
16	.1063	.181	.1646	.1772	.2126	.1865	.1949
17	.1949	.2896	.2012	.2172	.2126	.1867	.2481
18	.2012	.2427	.2378	.2172	.2126	.2241	.2481
19	.3174	.2987	.3366	.2926	.3475	.3258	.3189
20	.3077	.3258	.3189	.2614	.3109	.3077	.3012
21	.2829	.2957	.2896	.2427	.2926	.2896	.2801
22	.2054	.1886	.2172	.1629	.181	.181	.1629
23	.1294	.1524	.1267	.1086	.1267	.1267	.112
24	.168	.1097	.1307	.1267	.112	.1086	.1086
Max	**.3174**	**.3258**	**.3366**	**.2926**	**.3475**	**.3258**	**.3189**
Min	**.1063**	**.1097**	**.1109**	**.1086**	**.112**	**.1086**	**.1086**
Avg	**.1994**	**.1989**	**.1944**	**.1713**	**.197**	**.1888**	**.1972**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
GADHINGLAJ[025] BU 1121
Substation No/ Name :- 144096 / 33/11KV Hebbal (K Nool)
Feeder No / Name : 201 / 11 KV Nilaji Gaothan Feeder Feeder KV- 11 / OUTGOING **GAOTHAN FEEDER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3048	.3048	.3048	.3429	.3658	.3048
2	.3048	.3018	.3048	.3048	.3048	.3658	.3048
3	.3048	.3048	.3048	.3048	.3048	.3658	.3048
4	.3048	.3048	.3048	.3018	.3048	.3658	.3429
5	.4191	.415	.3429	.3429	.4954	.5487	.381
6	.6478	.6478	.5658	.5716	.6478	.6401	.6097
7	.8383	.7922	.7621	.679	.7545	.7865	.7621
8	.7545	.7095	.7545	.7167	.7468	.7468	.8299
9	.7095	.6348	.7095	.6154	.7095	.7468	.7316
10	.6722	.5914	.7095	.5792	.6219	.7023	.5853
11	.5975	.6584	.6653	.5914	.6859	.7468	.5121
12	.4904	.5792	.5121	.5121	.5373	.5487	.439
13	.4481	.5014	.4755	.5121	.4607	.4706	.4024
14	.415	.3696	.4066	.4755	.4755	.4298	.4024
15	.4191	.4066	.4066	.362	.4435	.3582	.4207
16	.4108	.4066	.3734	.439	.5175	.3856	.394
17	.5853	.5175	.4298	.5121	.6401	.5175	.4252
18	.8779	.7282	.6219	.6584	.8596	.6584	.5487
19	.9694	.8775	.9431	.9709	.9511	1.0082	.9335
20	.9431	.9808	1.0185	1.094	.9877	1.0082	.9335
21	.7922	.7922	.7922	.8383	.6219	.7922	.7842
22	.6097	.6413	.6097	.6097	.6219	.6097	.5658
23	.3772	.415	.3429	.381	.3658	.381	.3429
24	.3429	.3429	.3048	.3048	.3429	.3658	.3048
Max	**.9694**	**.9808**	**1.0185**	**1.094**	**.9877**	**1.0082**	**.9335**
Min	**.3048**	**.3018**	**.3048**	**.3018**	**.3048**	**.3582**	**.3048**
Avg	**.5641**	**.5510**	**.5402**	**.5409**	**.5727**	**.5798**	**.5236**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
GADHINGLAJ[025] BU 1121
Substation No/ Name :- 144096 / 33/11KV Hebbal (K Nool)
Feeder No / Name : 202 / HITANI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2785	.181	.168	.1829	.9945	.9145	.7537
2	.2818	.1829	.168	.181	.9945	.9145	.7537
3	.2818	.181	.168	.1829	1.0059	.9145	.7701
4	.2818	.181	.168	.181	1.0059	1.0059	.7956
5	.3353	.2195	.168	.1791	1.2071	1.262	.8122
6	.4588	.2772	.2241	.2452	1.4243	1.4632	.8886
7	.6613	.3475	.3326	.3584	1.6461	1.7558	1.1736
8	.823	.3547	.3696	.3734	1.7147	1.6766	1.3077
9	.3547		.3696	.3658	.3547	.3696	.2195
10	.5967	2.2977	2.4006	.4251	.3584	.4251	.2743
11	.6081	2.572	2.7435	.439	.3658	.3881	.2743
12	.6958	2.6406	2.8121	.4066	.3086	.3761	.2926
13	.7459	2.3739	2.7778		.3326	.333	.2926
14	1.8991	2.34	2.6406		.3292	.3012	.2926
15	2.2634	2.7778	2.572	.2587	.2865	.3077	.3258
16	2.2466	2.6791	2.572	.2957	.3292	.3366	.3224
17	2.3777	2.7435	2.4078	.3881	.3292	.3292	.2865
18	.2926	.1867	.3898	.3326	.3292	.3582	.2896
19	.3292	.2427	.3921	.3142		.3174	.2957
20	.3174	.2987	.3361	.2801	.2926	.2829	.2614
21	.2402	.2801	.3018	.2427	.2743	.2427	.2427
22	.2195	.2033	.2241	.1886	.2561	.168	.1478
23	.181	.1829	.1867	.9014	.8596	.7045	.8951
24		.181	.1663	.1867	.9614	.9145	.7209
Max	**2.3777**	**2.7778**	**2.8121**	**.9014**	**1.7147**	**1.7558**	**1.3077**
Min	**.181**	**.181**	**.1663**	**.1791**	**.2561**	**.168**	**.1478**
Avg	**.7291**	**1.0402**	**1.0441**	**.3141**	**.6939**	**.6692**	**.5287**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
GADHINGLAJ[025] BU 1121
Substation No/ Name :- 144096 / 33/11KV Hebbal (K Nool)
Feeder No / Name : 203 / HASURCHAMPU AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.4816	.4588	.426	.0953	.0732	.0762
2	.0762	.5312	.4641	.431	.0953	.0732	.0762
3	.0762	.5441	.4641	.426	.0953	.0732	.0953
4	.0953	.5376	.4694	.426	.0953	.0732	.0953
5	.1143	.6009	.4961	.4915	.1334	.1463	.1143
6	.1524	.6964	.5601	.5898	.1715	.1829	.1715
7	.1905	.8907	.8139	.7956	.1715	.2012	.1905
8	.2286	.9922	.9945	.9945	.2096	.1715	.2096
9	.1715	.1715	.1334	.1478	.2096	.1509	.2012
10	.1698	.1524	.1334	1.0082	1.2955	1.278	1.5546
11	.1132	.1524	.1334	1.2483	1.5249	1.4586	1.7375
12	.1143	.1334	.1143	1.2163	1.6907	1.4419	1.7375
13	.1143	.0953	.1143	1.3123	1.6385	1.587	1.7558
14	.1143	.0762	.1143	1.3443	1.6221	1.5546	1.7558
15	.0953	.0953	.1143	1.3757	1.6385	1.5384	1.5384
16	.0953	.0953	.1143	1.3443	1.587	1.4723	1.4251
17	.1097	.1143	.0953	1.2967	1.7375		1.2793
18	.1463	.1334	.1524	.1629	.1097	.1334	.1509
19	.1829	.1715	.2263	.2012	.128	.2096	.1715
20	.1886	.1905	.1715	.1715	.128	.1905	.1509
21	.1698	.1143	.1715	.1334	.1097	.1715	.1509
22	.1143	.1143	.1334	.1334	.1097	.1334	.1132
23	.2743	.3953	.3563	.0953	.0732	.0953	.0754
24	.0762	.4588	.4481	.4096	.0953	.0732	.0762
Max	**.2743**	**.9922**	**.9945**	**1.3757**	**1.7375**	**1.587**	**1.7558**
Min	**.0762**	**.0762**	**.0953**	**.0953**	**.0732**	**.0732**	**.0754**
Avg	**.1358**	**.3308**	**.3103**	**.6742**	**.6152**	**.5428**	**.6210**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
GADHINGLAJ[025] BU 1121
Substation No/ Name :- 144096 / 33/11KV Hebbal (K Nool)
Feeder No / Name : 204 / 11KV Hirnyakeshi Industrial Ex Feeder KV- 11 / OUTGOING SHEDDABLE FEEDER MIDC EQUIVALENT HAVING WEEKLY STAGGERING

DATE	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0762	.0754	.0762	.0732	
2	.0747	.0953	.0747	.0762	.0732	
3	.0754	.0762	.0747	.0762	.0732	
4	.0747	.0762	.0754	.0762	.0732	
5	.0754	.0762	.0754	.0953	.0732	
6	.0953	.0943	.0943	.1143	.0914	
7		.1132	.0943	.0762	.0914	
8	.0754	.1132	.1109	.0762	.0739	
9		.0943	.1109	.0762	.0953	
10		.112	.0924	.0762	.1143	
11	.1143	.1334		.1334	.0934	
12	.1524	.1334		.1334	.0924	
13	.1524	.132		.1143	.1524	
14	.1334	.1132		.1143	.0747	
15		.0934		.1143		
16	.1143	.1132		.1143		
17	.112	.0953	.0924	.1097		
18	.0943	.1132	.0924	.0914	.0701	
19	.0953	.1698	.1109	.0914		
20	.0953	.0934	.112	.0732		.0747
21	.0762	.0754	.0943	.0732		
22	.0754	.0754	.0762	.0732		
23	.0754	.0953		.0732		
24		.0953	.0943		.0732	
Max	**.1524**	**.1698**	**.112**	**.1334**	**.1524**	**.0747**
Min	**.0747**	**.0754**	**.0747**	**.0732**	**.0701**	**.0747**
Avg	**.0967**	**.1025**	**.0912**	**.0925**	**.0868**	**.0747**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
NESARI[024] **BU 1139**
Substation No/ Name :- 144057 / 33/11 KV HALKARNI
Feeder No / Name : 201 / 11 KV Halkarni Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1518	.1524	.1143	.3977	.7432	.6249	.3201
2	.1331	.1334	.1127	.4352	.7201	.6139	.4015
3	.1334	.1143	.0953	.3991	.685	.6818	.4362
4	.1524	.1334	.1136	.6363	.6975	.7727	.3239
5	.1715	.1524	.133	.6325	.7248	.786	.3269
6	.2092	.1905	.1715	.7663	.9315	.8591	.2585
7	.2477	.1524	.2279	.9995	1.2082	1.1838	.2591
8	.2081	.1524	.227		1.3016	1.4899	.2789
9	.2452	.2282	.1703	.1898	.2252	.2457	.1692
10	1.2139	1.3169	1.3467	.3021	.2824	.3018	.5127
11	1.4916	1.6113		.3761	.2821	.2643	.2268
12	1.4354	1.6499	.8973	.2633	.3392	.3027	.2275
13	1.3959	1.5708	1.7205	.2651	.3024	.3024	.2273
14	1.4678	1.608	1.6712	.2657	.2841	.2838	.2089
15	1.5309	1.6213	1.4058	.2638	.2651	.2657	.1901
16	1.4701	1.5258		.2804	.2649	.3042	.2056
17	1.3217	1.4266	1.4107	.3203	.3018	.3033	.1672
18	.2467	.1892	.2651	.3003	.2838	.2835	.2383
19	.2852	.2457	.3033	.3018	.3416	.3033	.2993
20	.2659	.2462	.2846	.2657	.3039	.3024	.2993
21	.2282	.2273	.2464	.2457	.2657	.2462	.2619
22	.171	.1894	.2279	.1704	.2277	.2275	.2266
23	.1334	.1331	.507	.6348	.5958	.4068	.1715
24	.1704	.1334	.1331	.4801	.7058	.6363	.4352
Max	**1.5309**	**1.6499**	**1.7205**	**.9995**	**1.3016**	**1.4899**	**.5127**
Min	**.1331**	**.1143**	**.0953**	**.1704**	**.2252**	**.2275**	**.1672**
Avg	**.6034**	**.6293**	**.5357**	**.3997**	**.5118**	**.4997**	**.2780**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
NESARI[024] **BU 1139**
Substation No/ Name :- 144057 / 33/11 KV HALKARNI
Feeder No / Name : 202 / 11 KV Hiduggi Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9168	.9049	.8985	.1503	.1694	.1689	.1134
2	.9191	.9088	.9031	.1319	.1488	.1319	.112
3	.9521	.9355	.8471	.132	.1504	.151	.1315
4	.9544	.9296	.8189	.1501	.1319	.1512	.1322
5	.9969	.973	.8429	.1506	.1497	.1698	.1706
6	1.0212	.9957	.9482	.1867	.1882	.1888	.1886
7	1.2904	1.2793	1.2372		.2279	.2282	.2454
8	1.46	1.5404	1.43		.1896	.2649	.225
9	.2029	.1823	.2188	.1494	.1433	.2732	.2005
10	.2259	.1882	.1888	1.1917	1.262	1.7284	1.6099
11	.2071	.1892	.1692	1.6241		1.9873	1.7764
12	.2257		.1886	1.9756	1.9126	2.0155	1.9158
13	.1871	.1842	.1691	2.0429	2.0509	2.0083	1.692
14	.1687	.1863	.1495	2.0081	2.0325	1.9176	1.6863
15	.1879	.206	.1698	2.0615	1.7772	1.9315	1.7945
16	.1494	.2422	.1485	2.0591	2.0405	1.9113	1.8454
17	.1873	.1764	.1888	1.9387	1.971	1.7912	1.6859
18	.322	.2465	.2635	.1959	.2403	.2165	.2126
19	.2972	.3669	.2996	.2593	.2875	.2809	.2326
20	.2957	.2923	.2969	.2942	.3116	.2795	.2534
21	.2978	.2942	.2963	.2341	.2741	.2766	.238
22	.3109	.2515	.251	.1939	.216	.1658	.2144
23	.8301	.7785	.2179	.1839	.1854	.1319	.8247
24	.9602	.863	.8322	.168	.167	.1871	.1307
Max	**1.46**	**1.5404**	**1.43**	**2.0615**	**2.0509**	**2.0155**	**1.9158**
Min	**.1494**	**.1764**	**.1485**	**.1319**	**.1319**	**.1319**	**.112**
Avg	**.5653**	**.5702**	**.4989**	**.7946**	**.7056**	**.7732**	**.7347**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
NESARI[024] **BU 1139**
Substation No/ Name :- 144057 / 33/11 KV HALKARNI
Feeder No / Name : 203 / 11 KV nagnoor Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3659	.4449	.3042	.3277
2				.3676	.4486	.3193	.3266
3				.4049	.4206	.3714	.4049
4				.4414	.3914	.4598	.3681
5				.4218	.4352	.4904	.3266
6				.4715	.4718	.5545	.5781
7				.6284	.7045	.6653	.6485
8					.7846	.5525	.6972
10	.7159	.7276	.792				
11	.9547	.9242	.9558				
12	1.0206	1.0099	1.0394				
13	1.0737	.9785	1.0559				
14	.9878	1.0099	.9757				
15	1.0511	1.0218	.9218				
16	.9934	.996	.8765				
17	.9176	.9231	.8405				
23			.3584	.3554	.2566	.4864	
24				.391	.3963	.2692	.4068
Max	**1.0737**	**1.0218**	**1.0559**	**.6284**	**.7846**	**.6653**	**.6972**
Min	**.7159**	**.7276**	**.3584**	**.3554**	**.2566**	**.2692**	**.3266**
Avg	**.9644**	**.9489**	**.8684**	**.4275**	**.4755**	**.4473**	**.4538**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
NESARI[024] **BU 1139**
Substation No/ Name :- 144057 / 33/11 KV HALKARNI
Feeder No / Name : 204 / 11 KV HALKARNI VG **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1143	.0951	.1141	.0945	.1143	.1315
2	.1143	.1143	.0947	.132	.1143	.0953	.1315
3	.1334	.1331	.1135	.1507	.0947	.0953	.1497
4	.1334	.1524	.0953	.1517	.1139	.1143	.1494
5	.1524	.1524	.1331	.1715	.1331	.1524	.1691
6	.1715	.1905	.1715	.2286	.1715	.1905	.2241
7	.2667	.3027	.2087	.2649	.2459	.2657	.2635
8	.3203	.2627	.2838		.2635	.2824	.3009
9	.2772	.2427	.2595	.2243	.2798	.2415	.2587
10	.2213	.2398	.2718	.2412	.259	.237	.239
11	.185	.2402	.2156	.1477	.2308	.2131	.2555
12	.1854	.1831	.2029	.1226	.2481	.2074	.2336
13	.168	.1941	.2128	.1127	.1953	.2074	
14	.1491	.185	.1643	.1125	.1451	.1789	.1639
15	.1288	.1638	.1453	.1119	.1816	.1781	.165
16	.1323	.1772	.1934	.1092	.2122	.1913	.1607
17	.2289	.2071	.214	.1075	.2433	.2462	.1764
18	.3323	***	.2422	.2728	.2931	.2808	.3018
19	.402	.3669	.4185	.3361	.2929	.3696	.3746
20	.3333	.334	.3168	.3344	.3168	.3708	.3354
21	.2638	.2818	.2427	.2993	.2812	.225	.2617
22	.1888	.1708	.1894	.1892	.1708	.1867	.1898
23	.1141	.1143	.1143	.1143	.1143	.1692	.1334
24	.1334	.1142	.1143	.1334	.1141	.1143	.1497
Max	**.402**	**13.3004**	**.4185**	**.3361**	**.3168**	**.3708**	**.3746**
Min	**.1141**	**.1142**	**.0947**	**.1075**	**.0945**	**.0953**	**.1315**
Avg	**.2021**	**.7474**	**.1964**	**.1819**	**.2004**	**.2053**	**.2139**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
NESARI[024] **BU 1139**
Substation No/ Name :- 144057 / 33/11 KV HALKARNI
Feeder No / Name : 205 / 11 KV Hidduggi Vg **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.189	.7671	.6478		.64	.7131	.9335
2	.1894	.7453	.606		.559	.6951	.6528
3	.2282	.7037	.6452		.5993	.7175	.5544
4	.2273	.5944	.6097		.5641	.7356	.6535
5	.2829	.559	.567		.5249	.756	.5596
6	.3723	.4481	.3921		.3576	.7954	.537
7	.5343	.4663	.4864		.4644	.9072	.5
8	.4985	.4129	.4644		.4087	.4964	.4463
9	.4075	.4003	.4141		.411	.3765	.4234
10	.3809	.3282	.3696		.3948	.3658	.4321
11	.3292	.4028	.3296	.4785	.3306	.4028	.4049
12	.3685	.4577	.3302	.4846	.2966	.3333	.3833
13	.3578	.3849	.3161	.3921	.2798	.296	.3624
14	.2987	.4371	.2981	.3374		.2948	.2818
15	1.2023	.3364	.2662	.2617	.299	.2622	.2795
16	.1858	.3628	.2075	.2654	.4163	.2427	.2619
17	.3061	.3705	.2635	.3612	.3333	.2721	.3054
18	.4712	.5132	.3925	.3573	.4763	.4251	.3965
19	.5963	.6264	.595	.5098	.5384	.5944	.5786
20	.5969	.7537	.5636	.5624	.9383	1.0332	.8659
21	.6735	.9639	.4668	1.0498	1.0332	1.053	1.0851
22	.8488	.8307	.2617	.8624	.8589	.9335	.8453
23		.7378	.6048	.7182	.7138	.4677	.6243
24	.2263	.7506	.6845	.5658	.6783	.6735	.6595
Max	**1.2023**	**.9639**	**.6845**	**1.0498**	**1.0332**	**1.053**	**1.0851**
Min	**.1858**	**.3282**	**.2075**	**.2617**	**.2798**	**.2427**	**.2619**
Avg	**.4249**	**.5564**	**.4493**	**.5148**	**.5268**	**.5768**	**.5428**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
NESARI[024] **BU 1139**
Substation No/ Name :- 144057 / 33/11 KV HALKARNI
Feeder No / Name : 206 / 11 KV Nagnoor Vg **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0756		.0759	.0953	.0945	.0953	.132
2	.0758	.0762	.0762	.0953	.0759	.0762	.1334
3	.0762	.0762	.0758	.1141	.0762	.0762	.1524
4	.0953	.1334	.0945	.1139	.076	.1143	.1524
5	.1143	.1524	.1143	.1334	.0953	.1334	.1715
6	.152	.1899	.1327	.1524	.1331	.1524	.1706
7	.2279	.2092	.1905	.1899	.1898	.2286	.1899
8	.2261	.1877	.1701		.1879	.2068	.1706
9	.1696	.1884	.1668	.1674	.1509	.1865	.1495
10	.148	.1491	.1469	.1985	.1501	.1141	.1497
11	.1307	.1316	.1296	.1472	.1322	.1133	.1632
12	.1117	.1109	.1127	.1307	.1135	.111	.1276
13	.1311	.0931	.0761	.1132	.1107	.1096	.1094
14	.0758	.0754	.0762	.0754	.0929	.0919	.1078
15	.0762	.0761	.076	.0762	.0757	.0761	.1067
16	.0953	.13	.0933	.1097	.0908	.1096	.1393
17		.1413	.1459	.1427	.1547	.141	.176
18	.1837	.1799	.2542	.1987	.2406	.1941	.1934
19	.2975	.2966	.333	.3135	.3182	.2978	.2862
20	.2978	.3009	.2948	.2587	.2981	.2978	.2786
21	.2257	.2079	.2427	.1888	.245	.2263	.2261
22	.114	.1143	.144	.0953	.1137	.1892	.15
23	.0953	.0762	.0758	.0762	.0953	.1704	.0949
24	.0754	.0953	.0951	.0948	.0951	.0953	.1509
Max	**.2978**	**.3009**	**.333**	**.3135**	**.3182**	**.2978**	**.2862**
Min	**.0754**	**.0754**	**.0758**	**.0754**	**.0757**	**.0761**	**.0949**
Avg	**.1422**	**.1475**	**.1414**	**.1427**	**.1419**	**.1503**	**.1618**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
NESARI[024] **BU 1139**
Substation No/ Name :- 144058 / 33/11 KV NESARI
Feeder No / Name : 201 / 11 KV Kowad Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.567	.4954	.0381	.0347	.0347	.0381
2	.6478	.567	.4954	.0381	.0347	.0347	.0381
3	.6478	.567	.4954	.0381	.0347	.0347	.0381
4	.6478	.567	.4954	.0381	.0347	.0347	.0381
5	.5716	.567	.4954	.0381	.0347	.0347	.0381
6	.6478	.567	.4954	.0381	.0347	.0347	.0381
7	.6859	.4961	.5335	.0381	.0347	.0347	.0381
8	.8002	.6024	.5716	.0381	.0347	.0347	.0343
9	.0343	.0347	.4191	.0343	.0347	.0381	.0343
10	.0343	.0347	.0381	.6859	.9214	1.0669	.8573
11	.0343	.0347	.0381	.7888	.9568	1.0288	.8573
12	.0343	.0347	.0381	.583	.9922	1.1431	.8916
13	.0343	.0347	.0381	.583	1.0277		.9259
14	.0343	.0347	.0381	.7545	1.0277	1.2574	.8573
15	.0343	.0347	.0381	.7888	.9214	1.1812	.8573
16	.0343	.0347	.0381	.823	.8859	1.105	.823
17	.0343	.0347	.0381	.8573	.8859	1.0288	.823
18		.0347	.0381	.0343	.0351	.0381	.0343
19		.0347	.0381	.0343	.0347	.0381	.0343
20		.0347	.0381	.0381	.0347	.0381	.0343
21	.0381	.0381	.0381	.0381	.0347	.0381	.0381
22	.0381	.0381	.0381	.0381	.0347	.0381	.0381
23	.5716	.4954	.0381	.0381	.0347	.0381	.5716
24	.6859	.6097	.4954	.0381	.0381	.0347	.0381
Max	**.8002**	**.6097**	**.5716**	**.8573**	**1.0277**	**1.2574**	**.9259**
Min	**.0343**	**.0347**	**.0381**	**.0343**	**.0347**	**.0347**	**.0343**
Avg	**.3322**	**.2541**	**.2302**	**.2693**	**.3408**	**.3648**	**.3340**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
NESARI[024] **BU 1139**
Substation No/ Name :- 144058 / 33/11 KV NESARI
Feeder No / Name : 202 / 11 KV Talewadi Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9907	.7087	.7621	.0381	.1433	.0347	.0381
2	.9907	.7087	.7621	.0381	.1433	.0347	.0381
3	.9145	.7087	.7621	.0381	.1433	.0347	.0381
4	.9145	.7087	.7621	.0381	.0347	.0347	.0381
5	.9907	.7087	.7621	.0381	.0347	.0347	.0381
6	.9907	.7087	.7621	.0381	.0347	.0347	.0381
7	1.0669	.7796	.9907	.0381	.0347	.0347	.0381
8	1.2193	.9214		.0381	.0347	.0347	.0343
9	.0343	.0347	.0381	.0343	.0347	.0381	.0343
10	.0343	.0347	.0381	1.3032	1.3413	1.6004	1.5775
11	.0343	.0347	.0381	.9945	1.5592	1.9052	1.749
12	.0343	.0347	.0381	.823	1.7909	1.9052	1.8861
13	.0343	.0347	.0381	1.4746	1.7718		
14	.0343	.0347	.0381	1.4746	1.7718	1.9814	1.5432
15	.0343	.0347	.0381	1.4746	1.8427	2.0576	1.5775
16	.0343	.0347	.0381	1.4746	1.8427	1.9052	1.5432
17	.0343	.0347	.0381	1.5089	1.701	1.9052	1.6461
18		.0347	.0381	.0343	.0347	.0381	.0343
19		.0347	.0381	.0343	.0351	.0381	.0343
20		.0347	.0381	.0381	.0347	.0381	.0343
21	.0381	.0381	.0381	.0381	.0347	.0381	.0381
22	.0381	.0381		.0381	.0347	.0381	.0381
23	.7621	.7621	.0381	.0381	.0347	.0381	.9907
24	.9907	.7621	.7621	.0381	.0381	.0347	.0381
Max	**1.2193**	**.9214**	**.9907**	**1.5089**	**1.8427**	**2.0576**	**1.8861**
Min	**.0343**	**.0347**	**.0381**	**.0343**	**.0347**	**.0347**	**.0343**
Avg	**.4865**	**.3321**	**.3118**	**.4636**	**.6044**	**.6017**	**.5681**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
NESARI[024] **BU 1139**
Substation No/ Name :- 144058 / 33/11 KV NESARI
Feeder No / Name : 203 / 11 KV Batakanangle Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0347		1.6766	1.576	1.4327	1.5242
2	.0381	.0347		1.6766	1.576	1.4327	1.5242
3	.0381	.0347		1.6766	1.576	1.4327	1.5242
4	.0381	.0347		1.6766	1.576	1.4327	1.5242
5		.0347		1.6766	1.576	1.4327	1.5242
6		.0347		1.7528	1.576	1.5043	1.6385
7		.0347		1.829	1.9845	1.8031	1.9052
8		.0347		2.0195	.0347	2.0774	2.0233
9	.0343	.0347	.0381	.0343		.0381	.0343
10	2.1605	2.4097		.0343	.0347	.0381	.0343
11	2.3663	2.5789	2.6673	.0343	.0347	.0381	.0343
12	2.2634	2.7995	2.8197	.0343	.0347	.0381	.0343
13	2.332	2.5514	2.9721	.0343	.0347		.0343
14	2.0233	2.6863	2.9721	.0343	.0347	.0381	.0343
15	2.6406	2.8704	2.8197	.0343	.0347	.0381	.0343
16	2.572	2.8704	2.553	.0343	.0347	.0381	.0343
17	2.332	2.6932	2.553	.0343	.0347		.0343
18		.0347	.0381	.0343	.0347	.0381	.0343
19		.0347	.0381	.0343	.0347	.0381	.0343
20		.0347	.0381	.0381	.0347	.0381	.0343
21	.0381	.0381	.0381	.0381	.0347	.0381	.0381
22	.0381	.0381	.0381	.0381	.0347	.0381	.0381
23	.0381	.0381	1.6766	1.6385	1.448	1.4861	.0381
24	.0381	.0381	.0381	1.6766	1.6766	1.4327	1.5242
Max	**2.6406**	**2.8704**	**2.9721**	**2.0195**	**1.9845**	**2.0774**	**2.0233**
Min	**.0343**	**.0347**	**.0381**	**.0343**	**.0347**	**.0381**	**.0343**
Avg	**1.1194**	**.9179**	**1.4200**	**.7413**	**.6544**	**.7238**	**.6349**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
NESARI[024] **BU 1139**
Substation No/ Name :- 144058 / 33/11 KV NESARI
Feeder No / Name : 204 / 11 KV Talewadi Vg **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1417		.1143	.1433	.1063	.1143
2	.1143	.1417		.1143	.1433	.1063	.1143
3	.1143	.1417		.1143	.1433	.1063	.1143
4	.1143	.1417		.1143	.1433	.1063	.1143
5	.1143	.1417		.1143	.1433	.1063	.1143
6	.1524	.1417		.1524	.1433	.1772	.1524
7	.2667	.2126		.2286	.2507	.2481	.2286
8	.2667	.2835		.2286	.2507	.2481	.2401
9	.2401	.2835	.3048	.2058	.2507	.3048	.2401
10	.2058	.2835		.2401	.2126	.2286	.2401
11	.2058	.2835	.2286	.2058	.2126	.1905	.2743
12	.2058	.2481	.2286	.1715	.2126	.1905	.2401
13	.2058	.2126	.1905	.2058	.1772		
14	.1715	.2126	.1524	.2058	.1772	.1524	.2401
15	.1715	.2126	.2286	.2058	.1772		.2401
16	.1715	.0354	.1905	.2058	.1772	.2286	.2401
17	.2743	.2126	.2286	.2058	.2126	.2667	.2058
18		.0347	.2667	.2743	.2481	.3048	.2743
19		.4252	.4191	.4115	.4252	.381	.4115
20		.4607	.381	.4572	.4656	.4572	.4458
21	.381	.4572	.381	.4191	.3898	.381	.4191
22	.2667	.2667	.2667	.2667	.2835	.2667	.3048
23	.1524	.1524	.1524	.1524	.1772	.1524	.1905
24	.1143	.1524	.1524	.1143	.1524	.1063	.1143
Max	**.381**	**.4607**	**.4191**	**.4572**	**.4656**	**.4572**	**.4458**
Min	**.1143**	**.0347**	**.1524**	**.1143**	**.1433**	**.1063**	**.1143**
Avg	**.1916**	**.22**	**.2515**	**.2137**	**.2214**	**.2189**	**.2293**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
NESARI[024] **BU 1139**
Substation No/ Name :- 144058 / 33/11 KV NESARI
Feeder No / Name : 205 / 11 KV Kowad Vg **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.2774		.381	.3189		.3429
2	.3429	.2835		.381	.3189	.2835	.3429
3	.3429	.2835		.381	.3189	.2835	.3429
4	.3429	.2835		.381	.3224	.2835	.3429
5	.3429	.2835		.4191	.3224	.2835	.3429
6	.4954	.2835			.3224	.3544	.4191
7	.6097	.567		.6097	.5731	.567	.6859
8	.6478	.6089		.6478	.6089	.6379	.6516
9	.583	.5731	.7621	.583	.6089	.6859	.6173
10	.583	.5316		.583	.5316	.6859	.6173
11	.5144	.6024	.724	.5144	.6024	.5335	.583
12	.4801	.567	.6478	.4458	.567	.5716	.5487
13	.4458	.5316	.6478	.3772	.5316		.5144
14	.4115	.4961	.5716	.3086	.4961	.4572	.4458
15	.4801	.5014	.5716	.3429	.4607		.4458
16		.4961	.6097	.3429	.4961	.4954	.4458
17		.6024	.6097	.3772	.4961	.5716	.4801
18		.7087	.724	.5144	.6379	.6859	.6516
19		.9922	1.0288	.8573	.9568	1.0669	.823
20		1.0277	1.0288	.9526	.9922	.9145	.9602
21		.9145	.9145	.8764	.8505	.8764	.8764
22	.6859	.6859	.6478	.6097	.6379	.6859	.6859
23	.3429	.381	.4191	.381	.362	.4191	.381
24	.4191	.3048	.381	.381	.3429		.3429
Max	**.6859**	**1.0277**	**1.0288**	**.9526**	**.9922**	**1.0669**	**.9602**
Min	**.3429**	**.2774**	**.381**	**.3086**	**.3189**	**.2835**	**.3429**
Avg	**.4674**	**.5328**	**.6859**	**.5064**	**.5282**	**.5672**	**.5371**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
NESARI[024] **BU 1139**
Substation No/ Name :- 144068 / 33/11 KV MAHAGAON
Feeder No / Name : 201 / 11 KV MAHAGAON VG **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4887	.3801	.4938	.4294	.4525	.2829	.3395
2	.4706	.362	.4755	.4294	.4344	.2829	.3395
3	.4525	.362	.4572	.4294	.4163	.2829	.3395
4	.4525	.362	.4572	.4481	.4344	.2829	.3395
5	.4706	.4163	.4755	.4854	.4887	.2829	.3395
6	.5068	.4706	.499	.4854	.5068	.4527	.4527
7	.5792	.5792	.6036	.5415	.5973	.547	.6413
8	.5792	.5487	.5853	.6348	.5792	.5847	.6602
9	.5658	.5914	.5487	.6161	.6161	.5788	.6348
10	.6036	.6036	.6584		.6161	.6908	.6535
11	.547	1.7558	.5487		.5975	.6722	.6908
12	.5281	.5121	.4207		.5281	.4668	.5601
13	.5281	.4755	.4024		.4481	.4108	.5041
14	.4904	.462	.4024	.5041	.4854	.3734	.4854
15	.3961	.4572	.4108	.5228	.4854	.3921	.4294
16	.5281	.439	.3547	.4854	.5228	.4854	.4525
17	.4755	.4207	.5415	.5304	.5121	.4908	.4525
18	.5544	.6584	.6722	.5853	.5853	.5609	.6219
19	.7682	.7682	.8215	.8413	.8413	.7865	.6878
20	.8048	.8048	.8215	.8048	.8131	.7682	.724
21	.7023	.6219	.7468	.7392	.7023	.695	.5973
22	.5249	.5853	.5415	.6335	.5658	.6413	.543
23	.4344	.567	.5041	.543	.3395	.3961	.4338
24	.5068	.4108	.5487	.4854	.4706	.3018	.3772
Max	**.8048**	**1.7558**	**.8215**	**.8413**	**.8413**	**.7865**	**.724**
Min	**.3961**	**.362**	**.3547**	**.4294**	**.3395**	**.2829**	**.3395**
Avg	**.5399**	**.5673**	**.5413**	**.5587**	**.5433**	**.4879**	**.5125**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
NESARI[024] **BU 1139**
Substation No/ Name :- 144068 / 33/11 KV MAHAGAON
Feeder No / Name : 203 / 11 KV Mahagaon Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3982	.362	.3681	.9242		.905	.8688
2	.3801	.362	.3681	.9808	1.086	.905	.8688
3	.3801	.362	.3681	.9896	1.1403	.905	.8688
4	.3801	.362	.3681	1.1694	1.1946	.905	.8688
5	.3982	.3801	.3856	1.2826	1.2308	.905	.8688
6	.3982	.3982	.3856	1.3957	1.2489	1.086	1.1222
7	.4163	.4163	.4031	1.6057	1.4937	1.3937	1.3394
8	.4163	.4024	.4207	1.7541	1.647	1.6289	1.5384
9	.3982	2.1735	.3856	.4338	.415	.415	.4338
10	1.8099	2.1735	1.893	.4338	.415	.415	.4338
11	2.1176	2.3838	2.4539		.415	.415	.415
12	2.19	2.4539	2.7343		.415	.415	.415
13	2.4796	2.5941	2.8045		.415	.415	.415
14	2.5701	2.6642	2.8045	.415	.415	.415	.415
15	2.5882	2.4188	2.8753	.415	.415	.415	.415
16	2.5158	2.3487	2.9424	.415	.415	.415	.3982
17	2.3838	2.4188	2.7915	.3856	.3856	.3856	.4163
18	.3856	.3856	.415	.3856	.3856	.3856	.4344
19	.3856	.3856	.415	.3856	.3856	.3856	.4344
20	.3856	.3898	.415	.3856	.3856	.3856	.4525
21	.3856	.3856	.415	.3856	.3856	.3856	.4163
22	.3982	.3856	.415	.3982	.3982	.3982	.3982
23	.3801	.3681	.8676	.7059	.8688	.8688	.3982
24	.3982	.362	.3681	.8865	.8326	.905	.8688
Max	**2.5882**	**2.6642**	**2.9424**	**1.7541**	**1.647**	**1.6289**	**1.5384**
Min	**.3801**	**.362**	**.3681**	**.3856**	**.3856**	**.3856**	**.3982**
Avg	**1.0392**	**1.1390**	**1.1693**	**.7683**	**.7126**	**.6689**	**.6460**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
NESARI[024] **BU 1139**
Substation No/ Name :- 144068 / 33/11 KV MAHAGAON
Feeder No / Name : 205 / 11 KV Nadighat Ag Feeder **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0335	.144	.1052	.1638	.1475
2	.0343	.0343	.0335	.144	.1448	.1638	.1475
3	.0343	.0343	.0335	.144	.1629	.1638	.1475
4	.0343	.0343	.0335	.144	.1612	.1638	.1475
5	.0343	.0343	.0343	.144	.181	.1638	.1475
6	.0343	.0343	.0343	.144	.181	.1802	.1638
7	.0362	.0343	.0335	.16	.181	.1802	.1802
8	.0343	.0335	.0335	.208	.2172	.1966	.1966
9	.0328	.0335	.0335	.032	.032	.032	.032
10	.2294	.285	.3258	.032	.032	.032	.032
11	.2294	.3856	.3658		.032	.032	.032
12	.2622	.4031	.3353			.032	.032
13	.3277	.4382	.3772		.032	.032	.032
14	.3277	.4287	.3944	.032	.032	.032	.032
15	.3277	.4359	.4001	.032	.032	.032	.0362
16	.3277	.4458	.3521	.032	.032	.032	.0343
17	.3506	.4191	.3681	.0335	.0335	.0335	.0343
18	.0335	.0343	.032	.0335	.0335	.0351	.0343
19	.0335	.0335	.032	.0335	.0335	.0343	.0343
20	.0335	.0335	.032	.0335	.0335	.0335	.0343
21	.0343	.0335	.032	.0335	.0335	.0343	.0362
22	.0343	.0335	.032	.1086	.0328	.0328	.0343
23	.0343	.0335	.112	.1052	.1966	.0819	.0328
24	.0343	.0362	.0335	.128	.1086		
Max	**.3506**	**.4458**	**.4001**	**.208**	**.2172**	**.1966**	**.1966**
Min	**.0328**	**.0335**	**.032**	**.032**	**.032**	**.032**	**.032**
Avg	**.1221**	**.1578**	**.1470**	**.0905**	**.0897**	**.0834**	**.0774**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
NESARI[024] **BU 1139**
Substation No/ Name :- 144112 / 33/11 Kv Nangnur
Feeder No / Name : 201 / 11 KV Aralgundi AG **FEEDER SEPERATION/PURE AG**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0497	.0686	.0526	1.4251	1.2308	1.0486	.9945
2	.0335	.0693	.0526	1.4251	1.2616	1.0814	1.0059
3	.0328	.0693	.0526	1.4752	1.2597	1.1105	.9995
4		.0678	.0701	1.4586	1.2289	1.1105	1.0343
5	.0492	.0701	.0716	1.5261	1.247	1.1271	1.0898
6	.0686	.0701	.0716	1.6956	1.2955	1.1603	1.1401
7	.0732	.0724	.0732	1.7126	1.4091	1.2597	1.1768
8	.0724	.0716	.0716	1.5581	1.4918		1.1768
9	.0724	.0686	.0532	.0693	.0686	.0701	.0671
10	1.4586	1.5238	1.6766	.0474	.0457	.0474	.0434
11	1.6907	1.8107	1.8442	.0486	.0486	.0514	.0429
12	1.7072	1.8442	1.7604	.0486	.0305	.0297	.044
13	1.7404	1.7368	1.7939	.0474	.0305	.0267	.0267
14	1.757	1.7238	1.8107	.0309	.0316	.0259	.0274
15	1.7404	1.7772	1.7604	.0301	.0301	.0274	.0282
16	1.757	1.757	1.8233	.0312		.0286	.0417
17	1.6575	1.7238	1.7736	.0497	.0305		.0423
18	.0497	.044	.0526	.0497	.0655	.0297	.0446
19	.0848	.0648	.0732	.0716	.0716	.0732	.0526
20	.0886	.0857	.0724	.0905	.0701	.0543	.0671
21	.0876	.0857	.0678	.0701	.0686	.0514	.0693
22	.0671	.0678	.0671	.0678	.0671	.0509	.0671
23	.0678	.0514	1.3426	1.1012	1.0364	.9667	.0503
24	.0497	.0686	.0514	1.3923	1.2452	1.0526	.9995
Max	**1.757**	**1.8442**	**1.8442**	**1.7126**	**1.4918**	**1.2597**	**1.1768**
Min	**.0328**	**.044**	**.0514**	**.0301**	**.0301**	**.0259**	**.0267**
Avg	**.6285**	**.6247**	**.6891**	**.6468**	**.5811**	**.4766**	**.4305**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
GADHINGLAJ DIVISION[112]
NESARI[024] **BU 1139**
Substation No/ Name :- 144112 / 33/11 Kv Nangnur
Feeder No / Name : 203 / Khandal Ag. **FEEDER SEPERATION/PURE AG**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0286	.0335	.0316	.381	.4268	.3795	.3353
2	.0282	.0339	.0316	.3858	.4268	.3953	.3462
3	.0143	.0335	.0332	.3858	.4321	.421	.3395
4	.0145	.0339	.0332	.4062	.4214	.4534	.3749
5	.0149	.0343	.0332	.4428	.4012	.4696	.3953
6	.0312	.0343	.0343	.6081	.4515	.5182	.4481
7	.0354	.0351	.0354	.6882	.5937	.583	.5761
8	.0332	.0343	.0351	.6562	.6405	.6097	.506
9	.0282	.0324	.0351	.0332	.0351	.029	.0271
10	1.0242	.8381	.9122	.0324	.0362	.012	.0332
11	1.1174	.9555	1.004	.0328	.0366	.0151	.0358
12	1.1043	1.0364	1.0688	.0149	.0343	.0133	.0351
13	1.0722	1.0155	1.0202	.0145	.0366	.0137	.0351
14	.9962	.9962	1.0242	.0139	.0366	.0139	.0354
15	.9602	.9804	1.0562	.0135	.037	.0137	.0362
16	.9488	.8905	.9962	.0152	.0362	.0133	.0351
17	.8592	.8592	.9217	.016	.0354		.0537
18	.0309	.0293	.0343	.0328	.0354	.0137	.0543
19	.0492	.0457	.0354	.0343	.0351	.0351	.0554
20	.0509	.0486	.0358	.0526	.0328	.0347	.0543
21	.0514	.0492	.0305	.0316	.0305	.0343	.0543
22	.0503	.0309	.0297	.0312	.0297	.0278	.0347
23	.0509	.0305	.381	.3864	.3658	.3462	.0351
24	.029	.0339	.0305	.381	.4064	.3795	.3462
Max	**1.1174**	**1.0364**	**1.0688**	**.6882**	**.6405**	**.6097**	**.5761**
Min	**.0143**	**.0293**	**.0297**	**.0135**	**.0297**	**.012**	**.0271**
Avg	**.3593**	**.3394**	**.3701**	**.2121**	**.2106**	**.2098**	**.1784**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144052 / 33/11 KV YADRAV
Feeder No / Name : 201 / YADRAV GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.5475	2.95	3.6591	3.6222	3.131	3.5101	3.6969
2	3.4355	2.9874	3.5837	3.5475	3.0556	3.4728	3.6214
3	3.4728	2.838	3.5837	3.5848	3.0178	3.4355	3.546
4	3.4355	2.9127	3.5082	3.5475	3.0178	3.3981	3.4705
5	3.3608	2.8753	3.4705	3.4728	3.0933	3.5101	3.4705
6	3.3608	2.9127	3.546	3.4355	3.2065	3.5475	3.5082
7	3.3981	3.062	3.6969	3.3981	3.3951	3.3981	3.6969
8	3.3608	3.2861	3.5837	2.6783	3.3951	3.3981	3.6969
9	.168	4.1823	4.225	2.8292	4.1076	4.1076	4.225
10	3.7342	4.3317	4.225	2.7161	3.9209	4.1823	4.1823
11	3.7715	4.481	4.4513	2.6029	4.3317	4.3317	4.2196
12	3.8089	3.9209	4.1495	2.2634	4.0329	4.0329	3.7342
13	3.062	3.5475	3.4705	2.0748	3.2526	3.3608	3.1367
14	3.2861	4.1076	3.9986	2.1125	4.2196	4.1076	3.6595
15	3.5848	4.1823	4.4513	2.2634	4.257	4.1823	4.1823
16	3.4355	4.2943	4.225	2.452	4.2943	4.3317	4.0329
17	3.2114	4.2943	4.2627	2.4143	4.3759	4.1495	4.1076
18	3.2114	4.2196	4.1495	2.4897	3.9609	4.1118	4.1076
19	2.9874	4.1076	4.0741	2.6406	3.9956	4.0364	4.0329
20	3.2114	3.7342	3.8855	2.8292	3.6222	3.7723	3.9956
21	3.062	3.8836		3.4705	3.6595	3.8855	3.9209
22	3.062	3.8089		3.3951	3.6222	3.8477	3.8089
23	3.2114	3.7342		3.3951	3.5475	3.81	3.7715
24	3.6222	2.9127	3.6969	3.7342	3.2065	3.5848	3.7723
Max	**3.8089**	**4.481**	**4.4513**	**3.7342**	**4.3759**	**4.3317**	**4.225**
Min	**.168**	**2.838**	**3.4705**	**2.0748**	**3.0178**	**3.3608**	**3.1367**
Avg	**3.2418**	**3.6486**	**3.8998**	**2.9571**	**3.6550**	**3.8127**	**3.8165**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144052 / 33/11 KV YADRAV
Feeder No / Name : 203 / ARUNDATHI SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2696	1.419	1.3957	1.4563	.9431	1.3817	1.3957
2	1.2323	1.3817	1.358	1.419	.9054	1.3443	1.3203
3	1.1949	1.307	1.3203	1.3817	.8676	1.307	1.2449
4	1.1576	1.1949	1.2071	1.3443	.8299	1.307	1.1694
5	1.1203	1.1203	1.1317	1.307	.8299	1.3443	1.1317
6	1.1576	1.1203	1.1317	1.2323	.8676	1.3443	1.094
7	1.307	1.307	1.2449	1.1203	.8676	1.2696	1.2071
8	1.307	1.307	1.2449	.7545	.9808	1.307	1.2449
9	1.4937	1.3817	1.4335	.7922	1.2696	1.3817	1.4712
10	1.4937	1.5684	1.5844	.7545	1.3443	1.6804	1.4563
11	1.5684	1.5684	1.7353	.7922	1.419	1.6057	1.4563
12	1.643	1.4937	1.6221	.7545	1.3817	1.419	1.4563
13	1.3817	1.3443	1.358	.679	1.2323	1.3817	
14	1.531	1.531	1.5844	.7167	1.419	1.419	1.3443
15	1.531	1.4937	1.6221	.679	1.4937	1.4937	1.4937
16	1.4937	1.531	1.5844	.7167	1.531	1.6057	1.4937
17	1.7177	1.5684	1.5844	.679	1.5684	1.6221	1.3817
18	1.531	1.5684	1.5844		1.4937	1.5844	1.3817
19	1.4937	1.531	1.6221		1.531	1.5844	1.3443
20	1.4937	1.4937	1.4712	.8676	1.3817	1.4335	1.307
21	1.4563	1.419		.9431	1.419	1.3957	1.307
22	1.4937	1.4937		1.0185	1.4937	1.4335	1.3443
23	1.6057	1.4563		.9808	1.4563	1.4712	1.307
24	1.307	1.4563	1.4335	1.4937	1.0185	1.419	1.4712
Max	**1.7177**	**1.5684**	**1.7353**	**1.4937**	**1.5684**	**1.6804**	**1.4937**
Min	**1.1203**	**1.1203**	**1.1317**	**.679**	**.8299**	**1.2696**	**1.094**
Avg	**1.4159**	**1.4190**	**1.4407**	**.9947**	**1.2310**	**1.4390**	**1.3402**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144052 / 33/11 KV YADRAV
Feeder No / Name : 204 / SPM **SHEDDABLE FEEDER HAVING WEEKLY**
Feeder KV- 11 / OUTGOING **STAGGERING (MIDC, EQUIVALENT)**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.419	1.531	1.2449	1.2696	.9054	1.3817	1.3957
2	1.3817	1.4937	1.2071	1.2323	.9054	1.3443	1.3957
3	1.3443	1.4937	1.1694	1.1949	.9431	1.307	1.358
4	1.307		1.1317	1.2323	.9431	1.3443	1.358
5	1.307	1.4937	1.1694	1.307	.9431	1.307	1.3957
6	1.307	1.6057	1.2071	1.3817	.9431	1.3443	1.4712
7	1.3817	1.643	1.1694	1.1949	.9431	1.307	1.4712
8	1.3443	1.4937	1.1694	.7922	1.0185	1.3443	1.4712
9	1.531	1.643	1.4335	.9054	1.2696	1.3817	1.4712
10	1.531	1.6804	1.358	.8299	1.3817	1.6057	1.4937
11	1.531	1.6804	1.5466	.8299	1.3817	1.5684	1.531
12	1.587	1.5684	1.4712	.8299	1.307	1.4563	1.4937
13	1.4937	1.419	1.4335	.7922	1.1949	1.307	1.531
14	1.6057	1.4937	1.358	.8676	1.307	1.5684	1.5684
15	1.7924	1.5684	1.6598	.9054	1.3817	1.643	1.531
16	1.643	1.6057	1.6598	.8676	1.3443	1.5684	1.4937
17	1.7177	1.643	1.5089	.9431	1.307	1.5466	1.4937
18	1.643	1.6804	1.358		1.2696	1.5089	1.531
19	1.6804	1.6804	1.3957		1.307	1.5089	1.4937
20	1.6804	1.5089	1.2826	.9431	1.3443	1.4712	1.3817
21	1.643	1.2696		.9054	1.4563	1.4712	1.3443
22	1.7177	1.3817		.9431	1.4563	1.4712	1.3817
23	1.643	1.3443		.9054	1.4563	1.4712	1.419
24	1.4563	1.531	1.3203	1.307	.9054	1.419	1.3957
Max	**1.7924**	**1.6804**	**1.6598**	**1.3817**	**1.4563**	**1.643**	**1.5684**
Min	**1.307**	**1.2696**	**1.1317**	**.7922**	**.9054**	**1.307**	**1.3443**
Avg	**1.5287**	**1.5414**	**1.3454**	**1.0173**	**1.1923**	**1.4436**	**1.4530**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144052 / 33/11 KV YADRAV
Feeder No / Name : 205 / PADMAJA FEEDER SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4937	1.8671	1.773	1.7177	1.1694	1.4937	1.7353
2	1.4937	1.9044	1.7353	1.7551	1.2071	1.531	1.6975
3	1.531	1.8671	1.6975	1.7924	1.2449		1.6598
4	1.531	1.8298	1.6598	1.8298	1.2826	1.531	1.6221
5	1.4937	1.8298	1.6975	1.7924	1.3203	1.4937	1.6598
6	1.4937	1.7551	1.7353	1.8671	1.358	1.4937	1.6975
7	1.531	1.9044	1.7353	1.3443	1.4712	1.531	1.5844
8	1.4937	1.4937	1.5466	.7922	1.3203	1.4937	1.5466
9	1.8671	1.6804	1.8861	.679	1.643	1.643	1.5844
10	1.8671	1.9616	2.037	.7545	1.7924	1.7924	1.9791
11	1.9791	1.9993	2.0748	.7545	1.9418	1.9418	1.531
12	2.0538	1.8861	1.8861	.7167	1.9418	1.8671	1.6804
13	1.7177	1.5844	1.773	.6413	1.7551	1.643	1.4563
14	1.9418	1.9239	1.8861	.6413	1.6804	1.8671	1.6804
15	1.9791	1.8861	2.0748	.7167	2.0165	1.9044	1.587
16	2.0165	1.9239	1.9616	.679	2.0538	1.8298	1.9418
17	1.9044	1.8861	1.6975	.679	1.9418	1.8861	1.8671
18	2.0911	1.9239	1.8484	.679	1.5684	1.6975	1.8671
19	1.9791	1.8861	1.773	.7167	1.8671	1.8484	1.8671
20	1.4563	1.8107	1.7353	.7545	1.6057	1.6975	1.8298
21	1.4563	1.7353		1.1317	1.5684	1.4335	1.8671
22	1.8671	1.773		1.1317	1.643	1.4712	1.5432
23	1.8298	1.7353		1.1317	1.5684	1.5089	1.6057
24	1.531	1.9044	1.7353	1.6804	1.1317	1.531	1.773
Max	**2.0911**	**1.9993**	**2.0748**	**1.8671**	**2.0538**	**1.9418**	**1.9791**
Min	**1.4563**	**1.4937**	**1.5466**	**.6413**	**1.1317**	**1.4335**	**1.4563**
Avg	**1.7333**	**1.8313**	**1.8071**	**1.0991**	**1.5872**	**1.6578**	**1.7026**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144052 / 33/11 KV YADRAV
Feeder No / Name : 206 / 11 kV YADRAV AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.4191	.3201	.3688			
2	.4108	.4024	.3201	.4481			
3	.4108	.3688	.3201	.3688			
4	.4481	.4024	.3521	.4359			
5	.4854	.3688	.3841	.4481			
6	.4481	.4527	.5121	.4481			
7	.5601	.6036	.5921	.5365			
8					.6882	.7377	.7842
9					.9175	.9175	.9602
10					1.0486	1.2323	1.0395
11					1.0814	1.1142	1.0395
12					1.0814	1.1469	.9724
13					1.0814	1.1142	.9556
14					1.0159	1.0814	.9221
15					.9012	1.0486	
16					.0328		
17					.0373		
18							.0747
22	.4191	.3041					.3353
23	.4191	.3521					.3353
24	.3361	.4527	.3361	.3353			
Max	**.5601**	**.6036**	**.5921**	**.5365**	**1.0814**	**1.2323**	**1.0395**
Min	**.3361**	**.3041**	**.3201**	**.3353**	**.0328**	**.7377**	**.0747**
Avg	**.4311**	**.4127**	**.3921**	**.4237**	**.7886**	**1.0491**	**.7419**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144052 / 33/11 KV YADRAV
Feeder No / Name : 207 / TARDAL AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4854	.57	.5898	.6706			
2	.5228	.6036	.5898	.6706			
3	.5975	.57	.6226	.7377			
4	.6036	.5868	.6554				
5	.6706	.6036	.7209	.7712			
6	.8048	.7042	.8356	.8048			
7	.9054	1.0395	.9831	1.073			
8					1.3599	1.643	1.3435
9					1.7695	1.9006	1.7204
10						2.0972	1.9281
11					1.9006	2.1628	1.9784
12					1.9334	2.0317	1.861
13					2.1376	1.9662	1.9281
14					1.9662	1.9334	1.5089
15					1.8351	1.9006	1.6263
16					.0381	.0286	
21							.2054
22	.6203	.5735					.6036
23	.6371	.6226					.57
24	.4481	.6036	.5898	.7042			
Max	**.9054**	**1.0395**	**.9831**	**1.073**	**2.1376**	**2.1628**	**1.9784**
Min	**.4481**	**.57**	**.5898**	**.6706**	**.0381**	**.0286**	**.2054**
Avg	**.6296**	**.6477**	**.6984**	**.7760**	**1.6176**	**1.7405**	**1.3885**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144052 / 33/11 KV YADRAV
Feeder No / Name : 402 / SUNIL INDUSTRIES
Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS (NON-CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3921	.3921	.3395	.3921	.2263	.3361	.3395
2	.4481	.3921	.3961	.4481	.2263	.2801	.3395
3	.3921	.3921	.3961	.3921	.2263	.2801	.3395
4	.3921	.3921	.3961	.3921	.2263	.3361	.3395
5	.4481	.4481	.3961	.3921	.2263	.3361	.3395
6	.3921	.3921	.3395	.3921	.2829	.3921	.3395
7	.3921	.3921	.3395	.3921	.2829	.3921	.3395
8	.3921	.2801	.3395	.3961	.2829	.3921	.2829
9	.4481	.3361	.3395	.3961	.3429	.3429	.2829
10	.4481	.3429	.3395	.2263	.3429	.3429	.3361
11	.3921	.3429	.3961	.2263	.2858	.3429	.2801
12	.3921	.3429	.3395		.3429	.3429	.2801
13	.3361	.3429	.3395		.3429	.2858	.3361
14	.3921	.3429	.3395		.3429	.2858	.3361
15	.3921	.3429	.3395		.3429	.2858	.2801
16	.3361	.4001	.3395		.3429	.2858	.2801
17	.3921	.4001	.3961		.3361	.3395	.2801
18	.3361	.4001	.3395		.3921	.3395	.2801
19	.3921	.3429	.3395		.3921	.3395	.2801
20	.3921	.3429	.3395		.3361	.3395	.2801
21		.3429			.3361	.3395	.3361
22	.3921	.3429			.3921	.3395	.2801
23	.3921	.3429			.3361	.3395	.2801
24	.4481	.3921	.3395	.4481		.3921	.3395
Max	**.4481**	**.4481**	**.3961**	**.4481**	**.3921**	**.3921**	**.3395**
Min	**.3361**	**.2801**	**.3395**	**.2263**	**.2263**	**.2801**	**.2801**
Avg	**.3970**	**.3659**	**.3557**	**.3745**	**.3125**	**.3345**	**.3095**

 Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144052 / 33/11 KV YADRAV
Feeder No / Name : 703 / 33 KV Main VCB **SHEDDABLE FEEDER HAVING WEEKLY**
Feeder KV- 33 / OUTGOING **STAGGERING (MIDC, EQUIVALENT)**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8006	3.3608	3.1687	3.1927	1.358	2.0165	2.037
2	2.8006	3.4728	3.2819	3.2487	1.4712	2.0165	1.9239
3	2.7446	3.3608	3.2819	3.2487	1.4712	1.9605	1.9239
4	2.9127	3.3608	3.2819	3.2487	1.4712	1.9044	1.9239
5	3.0807		3.7346	3.3048	1.4712	1.9605	1.9239
6	3.1367	3.4728	3.7346	3.0247	1.5844	1.7924	1.9239
7	3.4728	4.145	3.9609	3.1367	1.5844	1.9044	1.9239
8	1.9044	2.0165	2.037	.679	3.8477	4.257	4.0741
9	2.1285	2.2405	2.4897	.679	2.5766	5.1532	5.2058
10	2.1285	2.4897	2.3765	1.1317	3.3608	5.7065	5.6013
11	2.5766	2.5766	2.3765	1.1317	5.7133	5.8642	5.1532
12	2.6886	2.4646	2.2634	.9054	5.7133	5.8253	5.1532
13	2.2405	2.1285	2.1502	.8488	5.7065	5.4893	5.0412
14	2.5766	2.4646	2.1502	.9054	5.4893	5.6013	4.7051
15	2.5766	2.4646	2.3765	.9054	5.4893	5.6013	4.7051
16	2.4646	2.5766	2.2634	.9054	2.5766	2.2405	2.4646
17	2.5766	2.4646	2.037	.9054	2.4646	2.1502	2.1285
18	2.6886	2.5766	2.1502	.9054	2.0165	2.037	2.2405
19	2.6886	2.5766	2.037	.9054	2.1285	2.1502	2.1285
20	2.1285	2.4646	2.1502	.9054	1.7924	2.037	2.2405
21		2.4646		1.2449	1.7924	1.9239	2.0165
22	3.4168	3.1367		1.2449	1.9044	1.9239	3.0247
23	3.4728	3.1927		1.2449	2.0165	1.9239	2.9127
24	2.9127	3.4728	3.1687	3.1367	1.2449	2.1285	2.037
Max	**3.4728**	**4.145**	**3.9609**	**3.3048**	**5.7133**	**5.8642**	**5.6013**
Min	**1.9044**	**2.0165**	**2.037**	**.679**	**1.2449**	**1.7924**	**1.9239**
Avg	**2.7008**	**2.8237**	**2.6891**	**1.7079**	**2.7602**	**3.1487**	**3.1005**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144053 / 33/11 KV TILAWANI
Feeder No / Name : 201 / LAXMI **SHEDDABLE FEEDER HAVING WEEKLY**
Feeder KV- 11 / OUTGOING **STAGGERING (MIDC, EQUIVALENT)**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.0576	1.8861	2.2405		2.0576	2.2405
2		2.0233	1.8004	2.4272		2.3148	2.2405
3		2.0233	1.7147	2.5019		2.2291	2.0538
4		2.0576	1.7147	2.5393		1.9719	2.0538
5		2.0576	1.8004	2.6513		1.8861	2.0538
6		2.0576	1.9719	2.7633		2.0576	2.2405
7		1.9719	2.0576	2.9874		2.2291	2.4272
8	1.643		2.0576	1.6804		2.3148	1.8671
9	2.2291	2.838		1.2689	1.5432	2.6139	1.8861
10	2.7435	3.1741			2.1605	2.8006	2.915
11	2.7435	3.1741	2.838		2.4691	2.8753	2.8807
12	2.8292	2.4272	2.9874		2.8292	2.8006	2.915
13		2.9874	2.8006	1.2003	2.4006	2.7633	2.572
14	2.8292	2.9874	2.8006	1.1145	2.8292	2.6139	2.8292
15	2.915	2.9874	2.9127	1.1145	2.915		2.7435
16	2.3148	2.9874	2.4272	1.2003	3.0864	2.8006	2.7435
17		2.9874	2.8006		2.8292	2.8006	2.838
18	2.0576	2.1434	2.9874	1.2323	2.7435	2.8753	2.6139
19	1.8861	2.0576	2.4272	1.2696	2.7435	2.8006	2.5393
20	1.8861	2.0576	2.2405	1.2696	2.2291	2.838	2.4272
21	1.8861	1.9719	2.4272	1.307	2.0576	2.2405	
22	2.2291	1.8861	2.4272	1.307	2.2291	2.4272	
23	2.2291	1.9719	2.2405	1.3443	2.3148	2.4272	2.3152
24		2.1434	1.9719	2.2405		2.1434	2.3899
Max	**2.915**	**3.1741**	**2.9874**	**2.9874**	**3.0864**	**2.8753**	**2.915**
Min	**1.643**	**1.8861**	**1.7147**	**1.1145**	**1.5432**	**1.8861**	**1.8671**
Avg	**2.3158**	**2.3927**	**2.3315**	**1.7830**	**2.492**	**2.4731**	**2.4448**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144053 / 33/11 KV TILAWANI
Feeder No / Name : 202 / MANIK **SHEDDABLE FEEDER HAVING WEEKLY**
Feeder KV- 11 / OUTGOING **STAGGERING (MIDC, EQUIVALENT)**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.749	1.7833	2.2032		2.0233	2.2405
2		1.7147	1.7147	2.0538		2.0576	2.2405
3		1.6461	1.6461	2.0538		1.9547	2.2405
4			1.6804	1.8671		1.8861	2.0538
5			1.749	1.8671		1.8004	2.0538
6		1.8004	1.8176	1.8298		1.7147	2.0538
7		1.8176	1.8519	1.7924		1.6804	2.0538
8		2.2291	2.1262	1.531		1.8861	2.0911
9	1.8861	2.838		1.1317	2.0576	2.2405	2.0576
10	2.4691	2.726		1.0288	2.1605	2.4646	2.5034
11		2.95	2.4646	.9602	2.4691	2.6886	2.4863
12		2.8006	2.6886	.9431	2.4006	2.7633	2.5377
13		2.2032	2.5019	.9259	2.0576	2.6886	2.2291
14	2.5377	2.6513	2.5393	.9431	2.1605	2.6139	2.0919
15	2.7092	2.8006	2.4646	.9259	2.2634	2.5393	2.2291
16	2.2634	2.6886		.9602	2.4006	2.4646	2.5377
17	2.2634	2.9874	2.5393		2.2291	2.4272	2.5393
18	2.332	2.4348	2.6886	1.1576	2.1262	2.3899	2.3899
19	2.1948	2.2977	2.2779	1.2323	2.0062	2.3525	2.3152
20	2.0576	2.332	2.1285	1.2696	1.9033	2.2779	2.2405
21	1.7833	2.1262	2.0538	1.307	1.8861	2.0911	
22	1.8519	2.0233	2.2032		1.9547	2.4272	2.0538
23	1.8176	2.0919	2.1658	1.307	2.0576	2.2779	
24		1.7833	2.0233	2.2032		2.1262	2.2405
Max	**2.7092**	**2.9874**	**2.6886**	**2.2032**	**2.4691**	**2.7633**	**2.5393**
Min	**1.7833**	**1.6461**	**1.6461**	**.9259**	**1.8861**	**1.6804**	**2.0538**
Avg	**2.1805**	**2.3042**	**2.1480**	**1.4315**	**2.1422**	**2.2432**	**2.2491**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144053 / 33/11 KV TILAWANI
Feeder No / Name : 204 / 11 KV AUTOLINE SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.7147	1.5775	2.0538		1.8861	2.0538
2		1.6804	1.7147	2.0538		1.9204	2.0538
3		1.6461	1.8861	1.8671		1.8519	1.8671
4		1.6804	2.0576	1.8671		1.7147	1.7924
5		1.7147	1.9547	1.7924		1.6461	1.7177
6		1.749	1.7833	1.643		1.5775	1.6057
7		1.9204	1.6804	1.2696		1.6632	1.4563
8	2.3899	1.1831	1.4746	1.2323		1.7833	.9335
9	2.2291	2.0538		.9259	1.046	2.2405	1.5089
10	2.1776	2.838		.9602	1.6461	2.4646	1.5604
11	2.4691	2.3899	2.4646	.9259	2.4006	2.6139	1.8861
12	2.6749	2.838	2.8006	.9602	2.332	2.7633	2.0748
13	1.2346	2.0538	2.6139	.9259	1.4232	2.5393	2.1605
14	1.8861	2.6139	2.4646	.9259	1.5432	2.5019	2.3491
15	2.3663	2.6513	2.3899	.9431	1.7833	2.5393	2.2291
16	1.4403	2.1285	2.3152	.9602	1.5775	2.6139	1.3546
17	1.5432	2.6139	2.0538	1.0082	1.5432	2.5393	1.8671
18	1.6289	2.0233	2.0911	1.0456	2.0233	2.4646	2.0165
19	1.5432	2.1262	1.8298	1.0456	2.3491	2.3899	2.0165
20	1.8861	1.9547	2.3152	1.0456	1.9547	2.2405	2.2405
21	1.8861	1.7147	2.2032	1.0456	1.6804	1.8671	
22	2.0576	1.3889	2.4646	1.0456	1.9547	2.3899	2.0538
23	1.9547	1.5261	1.9044	1.0082	2.1262	1.9044	2.0538
24		1.8176	1.6118	2.0538		1.9547	2.0538
Max	**2.6749**	**2.838**	**2.8006**	**2.0538**	**2.4006**	**2.7633**	**2.3491**
Min	**1.2346**	**1.1831**	**1.4746**	**.9259**	**1.046**	**1.5775**	**.9335**
Avg	**1.9605**	**2.0009**	**2.0751**	**1.2752**	**1.8256**	**2.1696**	**1.8655**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144053 / 33/11 KV TILAWANI
Feeder No / Name : 206 / 11 KV MARUTI FEEDER SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.2291	2.0062	2.5766		2.3148	2.3899
2		2.2291	2.0576	2.5393		2.2634	2.4646
3		2.332	1.9204	2.4646		2.1262	2.4646
4		2.332	1.8347	2.5393		2.0233	2.4272
5		2.2977	2.0919	2.2405		1.8519	2.3899
6		2.332	2.2291	2.2405		1.9204	2.5393
7		2.3663	2.332	2.5393		2.0576	2.6513
8	2.4646	2.0919	2.332	2.3525		2.2977	1.9044
9	2.4006	2.3899		1.406	1.9204	2.6139	1.8861
10	2.5377	2.8753		1.3889	2.2291	2.6749	2.572
11	2.2977	2.838	2.838	1.3717	2.4863	2.9127	2.572
12	2.0748	2.5766	2.9874	1.406	2.5034	2.9874	2.4006
13	2.2291	2.6513	2.8753		2.332	2.8006	2.2291
14	2.332	2.5766	2.8006		2.3663	2.7633	1.8176
15	2.5206	2.838	2.6886		2.4006	2.6886	2.332
16	2.4177	2.726	2.6139		2.4691	2.8006	2.5377
17	2.4348	2.1658	2.6513		2.4006	2.838	2.6139
18	2.4691	2.6578	2.7633		2.3663	2.8006	2.6139
19	2.2291	2.7435	2.5019		2.332	2.726	2.4646
20	2.4006	2.572	2.4646	1.1203	2.1948	2.5766	2.4272
21	2.4691	2.6235	2.3899	1.5684	2.1262	2.5393	
22	2.4691	2.6749	2.2405	1.643	2.1948	2.6139	2.2405
23	2.3663	2.2977	2.5766	1.6804	2.2977	2.5393	2.3899
24		2.2977	2.0919	2.5766		2.4006	2.3899
Max	**2.5377**	**2.8753**	**2.9874**	**2.5766**	**2.5034**	**2.9874**	**2.6513**
Min	**2.0748**	**2.0919**	**1.8347**	**1.1203**	**1.9204**	**1.8519**	**1.8176**
Avg	**2.3821**	**2.4881**	**2.4222**	**1.9796**	**2.3080**	**2.5055**	**2.3791**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144053 / 33/11 KV TILAWANI
Feeder No / Name : 401 / 33 KV LIE Industrial No 1 SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 33 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.5206	2.5206	2.9127		2.6749	2.9127
2		2.572	2.4691	2.9127		2.572	2.9127
3		2.572	2.572	3.0247		2.5206	2.9127
4		2.6235	2.6235	2.9127		2.6235	2.9127
5		2.6749	2.6749	2.9127		2.6749	3.0247
6		2.6749	2.7778	3.0247		2.7778	3.1367
7		2.8292	2.7778	3.1367		2.8807	3.0247
8		2.6749	2.7263	2.8006		2.3663	
9	2.572	3.1367		2.4691	2.7263	2.8006	2.8807
10	2.6235	3.0247		2.4691	2.7263	3.0247	2.8807
11	2.7263	3.1367	3.0247	2.3663	2.6235	2.9127	2.8807
12	2.8292	3.2487	3.0807	2.4691	2.6749	2.9687	2.8807
13	2.572	3.1367	3.0247	2.5206	2.6749	3.0247	2.7778
14	2.7263	3.0247	2.8006	2.3663	2.6749	3.0247	2.6749
15	2.9321	3.2487	2.6886	2.4691	2.6235	2.9127	2.572
16	2.6235	2.9127	2.6886	2.572	2.6749		2.572
17	2.7263	2.9127	2.9127	2.9687	2.7778	2.8006	2.9127
18	2.8292	2.6749	3.0247	2.9127	2.7263	2.8006	2.8006
19	2.7263	2.7778	2.9127	2.8006	2.6749	2.9127	2.6886
20	2.6235	2.6749	3.0247	2.8006	2.6235	2.9127	2.5766
21	2.6749	2.6235	2.8006	2.6886	2.6749	2.8006	
22	2.6235	2.6235	2.8006	2.6886	2.6235	2.8006	2.5766
23	2.572	2.6235	3.0247	2.5206	2.6749	3.0247	2.5766
24		2.5206	2.572	2.8006		2.6235	2.9127
Max	**2.9321**	**3.2487**	**3.0807**	**3.1367**	**2.7778**	**3.0247**	**3.1367**
Min	**2.572**	**2.5206**	**2.4691**	**2.3663**	**2.6235**	**2.3663**	**2.572**
Avg	**2.6920**	**2.8101**	**2.7965**	**2.7300**	**2.6783**	**2.8015**	**2.8182**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144053 / 33/11 KV TILAWANI
Feeder No / Name : 402 / 33 KV LIE Industrial No 2 SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 33 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.6975	1.749	1.7924		1.4403	1.5684
2		1.749	1.9547	1.7924		1.3375	1.4563
3		1.749	1.8519	1.6804		1.3375	1.5684
4		1.8004	1.5432	1.6804		1.2346	1.4563
5		1.8519	1.5432	1.5684		1.2346	1.5684
6		1.749	1.6461	1.5684		1.6461	1.4563
7		1.8519	1.8519	1.5684		1.749	1.5684
8	1.3443	1.5432	1.3375			1.3375	1.1203
9	1.749	1.6804		1.0288	1.3375	1.6804	1.6461
10	2.0576	2.0165		1.1317	1.9547		1.749
11	2.0576	2.0165	1.9044	1.2346	1.9547	1.9044	1.8004
12	2.0576	1.7924	2.0165	1.1317	1.9547	1.7924	1.8004
13	1.9547	1.6804	2.2405	1.1317	1.749	2.0165	1.749
14	2.0576	1.7924	2.1285	1.1317	1.8519	1.9044	2.0062
15	2.1605	1.7924	1.9044	1.1317	1.9547	1.9044	2.0062
16	2.0576	2.2405	2.0165	1.1317	2.0062	1.9044	2.0062
17	2.0062	1.5684	1.7924	1.2323	1.8004	1.7924	
18	1.9033	1.8519	1.6804	1.2323	1.6461	1.6804	2.1285
19	1.8004	1.9547	1.6804	1.2323	1.5432	1.5684	2.0165
20	1.8519	1.749	1.5684		1.5432	1.3443	
21	1.6461	1.8519		1.2323	1.4403	1.7924	
22	1.6975	1.8519	1.9044	1.2323	1.5432	1.9044	1.6804
23	1.6975	1.9547	1.9044	1.2323	1.6461	1.9044	1.7924
24		1.6461	1.8519	1.7924		1.5432	1.4563
Max	**2.1605**	**2.2405**	**2.2405**	**1.7924**	**2.0062**	**2.0165**	**2.1285**
Min	**1.3443**	**1.5432**	**1.3375**	**1.0288**	**1.3375**	**1.2346**	**1.1203**
Avg	**1.8812**	**1.8097**	**1.8129**	**1.3587**	**1.7284**	**1.6502**	**1.6953**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144054 / 33/11KV Mangaon
Feeder No / Name : 201 / SAJANI FEEDER GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.4481	.3921	.4108	.3547	.4108	.4108
2	.4108	.4108	.3734	.4108	.3547	.4108	.3734
3	.4108	.4108	.3734	.3734	.3547	.4108	.3734
4	.4481	.4108	.3734	.3734	.3734	.4108	.4108
5	.4481	.4668	.3734	.4294	.4108	.4294	.4854
6	.4854	.5228		.4668	.4481	.5041	.5228
7	.4854	.5228	.5228	.4668	.4854	.4854	.5228
8	.5228	.5601	.5975	.4854	.5041	.5415	.5601
9	.5041	.5788	.5975	.3734	.5228	.5975	.6722
10	.5228	.5601	.5415		.5975	.5975	.6348
11	.5601	.6348	.5601		.6348	.6161	.5975
12	.4481	.5601	.5228		.6722	.5975	.4854
13	.4481	.5228	.4481		.4668	.4294	.4854
14	.4481	.5228	.4294		.5041	.4481	.5601
15	.5041	.5601	.4481		.5601	.4668	.5601
16	.4668	.5975	.4668	.2241	.5975	.4854	.5228
17	.5041	.5975	.4854	.2241	.5228	.5228	.5975
18	.5601	.5601	.5975	.2614	.5601	.5975	.5975
19	.6535	.7282	.7095	.4108	.7545	.6535	.6722
20	.6161	.6348	.6348	.4668	.6722	.6908	.6348
21	.5788	.5601	.6348	.5415	.5975	.6348	.5975
22	.5228		.5601	.5228	.4668	.5601	.5228
23	.4854		.4854	.4108	.4294	.4854	.4294
24	.4481	.4481	.4668	.4481	.3734	.4294	.4481
Max	**.6535**	**.7282**	**.7095**	**.5415**	**.7545**	**.6908**	**.6722**
Min	**.4108**	**.4108**	**.3734**	**.2241**	**.3547**	**.4108**	**.3734**
Avg	**.4956**	**.5372**	**.5041**	**.4056**	**.5091**	**.5173**	**.5282**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144054 / 33/11KV Mangaon
Feeder No / Name : 203 / PANCHAGANGA GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4854	.5228	.3734	.3734	.4854	.5228	.4854
2	.4854	.5228	.3734	.3734	.4481	.4854	.4481
3	.5228	.5228	.3734	.3734	.4481	.4854	.4108
4	.5228	.5975	.3734	.5228	.5228	.5041	.5975
5	.5228	.7655	.4108	.5975	.5975	.5415	.6722
6	.5788	.8589	.5415	.6722	.7468	.7095	.7842
7	.6535	1.0829	.6722	.7095	.9896	.8589	.9709
8	.6908	1.0642	.7282	.7468	1.1203	.7655	1.1203
9	.8402	1.0829	.7922	.7468	1.1203	.8589	.9896
10	.8589	1.2323	.8865		.8402	.8029	1.1203
11	.7545	1.1949	.7762		1.1576	.8402	1.0829
12	.9054	1.0082	.7842		1.1203	.8215	.9709
13	.8676	1.1203	.7095		1.1203	.6908	.9335
14	.8488	1.1203	.7842		1.0082	.7095	.8215
15	.8299	.9431	.8215		.8962	.6908	.9335
16	.8299	.9522	.8775	.4108	.8589	.7282	1.0642
17	.8299	.9709	.7842	.5228	.9335	.7842	.9335
18	.8865	.8676	.8962	.5228	.8589	.8215	1.0082
19	.9709	1.0562	.9335	.5601	1.0456	.8402	1.0082
20	.9335	.9431	.8402	.6348	1.0082	.8589	.9335
21	.7468	.8676	.7468	.6348	.8962	.7468	.8402
22	.5975		.5601	.5601	.6348	.6348	.6722
23	.5601		.4481	.5228	.5975	.5601	.4668
24	.5228	.5228	.4715	.4108	.4854	.5228	.5228
Max	**.9709**	**1.2323**	**.9335**	**.7468**	**1.1576**	**.8589**	**1.1203**
Min	**.4854**	**.5228**	**.3734**	**.3734**	**.4481**	**.4854**	**.4108**
Avg	**.7186**	**.9009**	**.6649**	**.5498**	**.8309**	**.6994**	**.8246**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144054 / 33/11KV Mangaon
Feeder No / Name : 204 / RUI AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0671	.0497	.0671	.3353	.3688	.4024	.3353
2	.0671	.0497	.0503	.3018	.3688	.3479	.3353
3		.0497	.0503	.2683	.3688	.3647	.3353
4	.0503	.0497	.0486	.2683		.3479	.3353
5	.0671	.0663	.0503	.2683	.3856	.3688	.3353
6	.0671	.0663	.0503	.3018	.3856	.3856	.3688
7	.0671	.0791	.0671	.3353	.4694	.431	.3812
8	.0671	.0633	.0838	.4191	.4862	.4527	.4024
9	.3521	.4586	.4527	.1174	.0671	.0838	.1006
10	.6203	.7545	.7545		.1006	.0838	.1174
11	.7209	.7712	.7712		.0838	.0838	.1006
12	.7377	.6036	.7545		.0838	.0838	.0949
13	.7042	.7209	.6874		.0838	.0335	.0838
14	.6874	.7042	.6371		.0838	.0335	.0838
15	.6706	.7377	.6203		.1006	.0335	.0838
16	.6036	.7042	.5868	.0838	.1006	.0335	.0829
17	.0671	.0671	.0838	.0838	.0838	.0168	.0838
18	.1006	.0762	.0838	.1006	.1006	.0838	.1006
19	.116	.1174	.1006	.1006	.1006	.1006	.1006
20	.0995	.0838	.1006	.1006	.1006	.1006	
21	.0829	.0838	.1006	.0838	.1029	.0838	.1006
22	.0671		.1006	.0838	.0838	.0671	.0838
23	.0663		.3353	.3353	.2984	.3353	.0838
24	.0671	.0671	.0671	.3353	.3688	.4024	.3353
Max	**.7377**	**.7712**	**.7712**	**.4191**	**.4862**	**.4527**	**.4024**
Min	**.0503**	**.0497**	**.0486**	**.0838**	**.0671**	**.0168**	**.0829**
Avg	**.2703**	**.2920**	**.2794**	**.2180**	**.2077**	**.1984**	**.1941**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144054 / 33/11KV Mangaon
Feeder No / Name : 205 / MANGAON GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.112	.1307	.1307	.1307	.112	.1494
2	.1494	.112	.1307	.1307	.1307	.112	.1494
3	.1494	.112	.1307	.1307	.1494	.112	.1494
4	.168	.112	.1307	.1307	.1494	.112	.1494
5	.1867	.1307	.1494	.1494	.1494	.112	.168
6	.1867	.2241	.168	.1494	.168	.2427	.1867
7	.2241	.2054	.2054	.2241	.2241	.2614	.2054
8	.2614	.2241	.2427	.2614	.1867	.2427	.2241
9	.2614	.2427	.2427	.2614	.2241	.2241	.2801
10	.2427	.2241	.2427		.2054	.2241	.2054
11	.168	.2054	.2241		.1307	.2054	.2054
12	.168	.2054	.2241		.1494	.2054	.1867
13	.168	.2241	.1867		.112	.2054	.168
14	.168	.2054	.168		.1307	.1867	.1494
15	.168	.1867	.168		.1307	.1867	.1494
16	.1867	.2054	.168	.1867	.1494	.1867	.168
17	.2241	.2241	.2054	.2054	.1867	.2054	.2054
18	.2614	.2987	.2614	.2054	.2614	.2241	.2427
19	.3361	.3174	.3734	.3361	.3174	.2614	.3547
20	.3361	.3361	.3361	.3361	.3547	.3361	.3174
21	.2987	.3174	.2987	.3174	.3361	.2987	.2801
22	.2241		.1867	.2801	.2427	.2614	.2241
23	.1494		.1307	.1494	.1494	.7842	.1867
24	.168	.112	.1494	.1307	.1307	.112	.1494
Max	**.3361**	**.3361**	**.3734**	**.3361**	**.3547**	**.7842**	**.3547**
Min	**.1494**	**.112**	**.1307**	**.1307**	**.112**	**.112**	**.1494**
Avg	**.2085**	**.2062**	**.2023**	**.2064**	**.1875**	**.2256**	**.2023**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144054 / 33/11KV Mangaon
Feeder No / Name : 206 / 11 KV MANGAON AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343	1.2003	.9259	.7888	.7202
2	.0343	.0343	.0343	1.2003	.9259	.7716	.7202
3	.0343	.0343	.0343	1.166	.9602	.7716	.7202
4	.0343	.0339	.0343	1.166	.9602	.7716	.7202
5	.0343	.0339	.0343	1.1488	.9774	.7716	.7202
6	.0343	.0343	.0343	1.1488	.9774	.8059	.7373
7	.0343	.0343	.0343	1.1317	1.0117	.8059	.7373
8	.0343	.0343	.0343	1.1317	.9774	.823	.7373
9	1.1145	1.5261	1.6632	.0343	.0343	.0343	.0343
10	1.4403	1.5947	1.749		.0343	.0343	.0343
11	1.543	1.8004	1.7295		.0343	.0343	.0343
12	1.5947	1.8347	1.7147		.0343	.0343	.0343
13	1.5775	1.8176	1.6804		.0343	.0343	.0343
14	1.5775	1.8004	1.6461		.0343	.0343	.0343
15	1.5775	1.8519	1.6118		.0343	.0343	.0343
16	1.406	1.8004	1.6118		.0343	.0343	.0339
17	.0343	.0343	.0343		.0343	.0343	.0339
18	.0343	.0343	.0343	.0343	.0339	.0343	.0343
19	.0343	.0343	.0343	.0343	.0343	.0343	.0343
20	.0339	.0343	.0343	.0343	.0343	.0343	.0343
21	.0339	.0343	.0343	.0343	.0343	.0343	.0343
22	.0343		.0343	.0343	.0343	.0343	.0343
23	.0343		1.2346	.9259	.7888	.7202	.0343
24	.0343	.0343	.0343	1.2346	.9259	.8059	.7202
Max	**1.5947**	**1.8519**	**1.749**	**1.2346**	**1.0117**	**.823**	**.7373**
Min	**.0339**	**.0339**	**.0343**	**.0343**	**.0339**	**.0343**	**.0339**
Avg	**.5158**	**.6593**	**.6315**	**.7287**	**.4129**	**.3465**	**.2936**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144054 / 33/11KV Mangaon
Feeder No / Name : 207 / 11 KV Laxmi AG. (Sajani) SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0648	.0633	.081	.8002	.9231	.7907	.8002
2	.0648	.0633		.8002	.9393	.7907	.8002
3	.0648	.0633		.8002	.9393	.7907	.8322
4	.081	.0633	.0648	.8482	.9282	.8002	.8642
5	.081	.0633		.8962	.9602	.7907	.8962
6	.081	.0949		.9602	.9602	.9172	.9282
7	.0972	.1107	.0972	1.2483	1.3117	1.186	1.0883
8	.0972	.1107	.1134	1.3443	1.3763	1.3283	1.2163
9	1.1336	1.1385	1.1822	.08	.081	.1265	.112
10	1.5524	1.7604	1.7328		.0972	.0972	.1107
11	1.7976	1.7604	1.8564		.112	.0972	.0949
12	1.7652	1.7604	1.8785		.112	.0972	.0949
13	1.749	1.7924	1.9204		.112	.1134	.0791
14	1.7166	1.7604	1.7924		.112	.1134	.0633
15	1.6842	1.7764	1.7764		.112	.1134	.0949
16	1.6518	1.6804	1.749		.112	.1134	.0949
17	.0486	.096	.064		.112	.1134	.1107
18	.081	.081	.08		.1107	.112	.1296
19	.1107	.1134	.096		.0791	.112	.1296
20	.0949	.1134	.112	.0972	.0791	.128	.1134
21	.0949	.0972	.128	.0972	.0791	.112	.0972
22	.0791		.112	.081	.0791	.096	.081
23	.0791		.8322	.9393	.7907	.9335	.0648
24	.0648	.0633	.081	.8322	.9231	.7907	.8002
Max	**1.7976**	**1.7924**	**1.9204**	**1.3443**	**1.3763**	**1.3283**	**1.2163**
Min	**.0486**	**.0633**	**.064**	**.08**	**.0791**	**.096**	**.0633**
Avg	**.5973**	**.6648**	**.7875**	**.7018**	**.4767**	**.4443**	**.4040**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144054 / 33/11KV Mangaon
Feeder No / Name : 208 / 11 KV Gomtesh Vg GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1494	.1715	.1494	.1307	.1867	.1494
2	.1494	.1494	.1715	.1494	.1307	.1494	.1494
3	.1494	.1494	.1715	.1494	.1307	.1494	.1494
4	.168	.1494	.1715	.1494	.1494	.1494	.1494
5	.168	.1494	.1715	.1494	.1494	.1494	.1494
6	.168	.1494		.1494	.168	.1494	.168
7	.1867	.1494	.1715	.1494	.168	.168	.1867
8	.2241	.2241	.2096	.168	.168	.1867	.2614
9	.3174	.3174	.2286	.168	.1867	.3174	.3361
10	.3734	.3547	.362		.4294	.4294	.4854
11	.4001	.4108	.3734		.4108	.5415	.4854
12	.381	.4527	.2241		.4481	.5041	.5228
13	.381	.3772	.2801		.4294	.3734	.5228
14	.381	.3772	.2614		.4854	.3734	.5041
15	.4001	.5281	.2614		.5601	.4668	.5601
16	.4382	.5281	.3734	.1494	.3734		.6348
17	.4001	.5281	.3361	.1494	.5601	.5228	.5788
18	.2667	.3429	.2614	.1494	.4108	.3734	.4108
19	.3174	.4191	.2241	.1494	.2987	.2515	.3547
20	.2987	.2667	.2054	.1494	.2614	.2427	.2987
21	.2614	.2096	.1867	.1494	.1867	.2054	.2427
22	.1867		.168	.1494	.1867	.168	.2054
23	.168		.1494	.1494	.1494	.1494	.168
24	.168	.1494	.1715	.1494	.1494	.1867	.1494
Max	**.4382**	**.5281**	**.3734**	**.168**	**.5601**	**.5415**	**.6348**
Min	**.1494**	**.1494**	**.1494**	**.1494**	**.1307**	**.1494**	**.1494**
Avg	**.2709**	**.2969**	**.2307**	**.1515**	**.2801**	**.2780**	**.3260**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144054 / 33/11KV Mangaon
Feeder No / Name : 401 / 33 KV Mangaon Industrial SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 33 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.5268	4.7531	4.6965	4.1724	4.1872	4.7531	4.5725
2	4.3004	4.3004	4.7531	4.1152	4.1872	4.7531	4.6296
3	4.2438	4.1872	4.7531	4.1724	4.0741	4.6965	4.5725
4	4.0741	4.2438	4.6399	4.2295	4.0741	4.7051	4.5725
5	4.0741	3.7346	4.8663	4.2867	3.9609	4.6965	4.6868
6	3.9609	3.7912	4.8097	4.2867	3.9609	4.8097	4.5725
7	4.3004	3.7912	4.1872	4.4582	4.1307	4.0741	4.2867
8	4.8097	4.7531	4.0741	4.0581	4.8097	4.357	4.2295
9	4.8663	4.7531	4.0741	3.9609	4.0741	4.1872	4.1724
10	5.036	4.9154	4.7531		4.8097	4.1872	5.0926
11	5.1492	4.9154	5.0926		4.2867	4.1872	4.8097
12	4.8663	5.144	5.0926		5.144	4.0175	5.036
13	4.7531	4.9154	4.5268		4.9154	4.4136	4.9794
14	4.8097	4.9154	5.0926		4.9154	4.7531	4.6399
15	4.9228	5.0297	4.8663		4.9726	4.8663	4.8097
16	5.3755	4.8583	4.5268	1.4003	5.4298	4.7531	4.8663
17	4.1872	4.8583	4.9154	2.999	5.4298	4.9228	4.8663
18	4.8097	4.8663	4.5725	3.1687	5.1492	4.2295	4.5268
19	4.7531	4.7531	4.2867	3.3951	5.3189	4.9154	4.7531
20	4.6965	4.7531	4.6868	3.7346	4.8663	4.9726	4.7531
21	4.7531	4.4136	4.8583	4.0175	5.036	4.9726	4.6965
22	4.7531		4.9154	3.9609	4.8663	4.8583	4.7531
23	4.8097		4.2867	3.9043		4.8011	4.1872
24	4.8097	4.8663	4.4702	4.2295	4.2438	4.8097	4.6868
Max	**5.3755**	**5.144**	**5.0926**	**4.4582**	**5.4298**	**4.9726**	**5.0926**
Min	**3.9609**	**3.7346**	**4.0741**	**1.4003**	**3.9609**	**4.0175**	**4.1724**
Avg	**4.6517**	**4.6142**	**4.6582**	**3.8083**	**4.6453**	**4.6122**	**4.6563**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD
Feeder No / Name : 201 / PUJARI MALA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0457	.0762	.9297	.8916	.8078	.061	.0762
2	.0457	.0762	.9145	.8916	.7926	.061	.0762
3	.0472	.0762	.9297	.8916	.7926	.061	.0762
4	.0495	.0762	.945	.8916	.8078	.061	.0762
5	.0495	.0762	.945	.8916	.8078	.061	.0762
6	.0503	.0762	.945	.8916	.7926	.061	.0762
7	.0457	.0762	.9755	.8916	.8383		.0762
8	1.4419	1.3717	.061	.9088	.061		1.4937
9	1.7072	1.448	.061		.061		1.6461
10	1.757	1.4784	.061	.0602	.0457		1.7375
11	1.704	1.6918	.061	.0587	.061		1.6918
12	1.869	1.8519	.0457	.0594	.0686	1.8519	1.9547
13	1.8004	1.749	.0332	.0617	.0514	1.8347	
14	1.7318	1.749	.0427	.0594	.0686	1.8004	1.8176
15	1.7318	1.6632	.0457	.0686	.0686		1.8176
16	.0686	.0686	.0472	.0686	.0686	.0686	.0762
17	.0857	.0686	.0495	.0686	.0686	.0686	.0762
18	.0857	.0686	.0457	.0514	.0686	.0686	
19	.0857	.0686	.0495	.0686	.0686	.061	
20	.0762	.061	.061	.061	.061	.061	.0648
21	.0762	.061	.061	.061	.061	.061	.0934
22	.0762	.8993	.8573	.8535	.0686	.0762	.0648
23	.0762	.9145	.8916	.8535	.061	.0762	.0667
24	.0495	.0762	.9297	.8916	.8078	.061	.0762
Max	**1.869**	**1.8519**	**.9755**	**.9088**	**.8383**	**1.8519**	**1.9547**
Min	**.0457**	**.061**	**.0332**	**.0514**	**.0457**	**.061**	**.0648**
Avg	**.6149**	**.6593**	**.4162**	**.4563**	**.3108**	**.3586**	**.6291**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD
Feeder No / Name : 202 / 11Kv Ganpati Mandir AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4359	.4458					.6173
2	.4409	.4458					.6173
3	.4458	.4458					.6173
4	.4409	.4458					.6173
5	.4458	.4458					.6173
6	.4409	.4458					.6173
7	.4748	.4458					.6001
8			.9259		.9602		
9			.9602		.9945		
10					1.166		
11			.9431	.8215	1.2174		
12			.9054	.9774	1.2003	.1029	
13			.8718	1.0117	1.1317	1.0802	
14			.7712	1.046	1.166	1.1317	
15			.8886	.9602	1.1488	1.1488	
16				1.046			
17				1.0288			
22	.4458					.6173	.4359
23	.4458					.6173	.4359
24	.4748	.4458					.6173
Max	**.4748**	**.4458**	**.9602**	**1.046**	**1.2174**	**1.1488**	**.6173**
Min	**.4359**	**.4458**	**.7712**	**.8215**	**.9602**	**.1029**	**.4359**
Avg	**.4491**	**.4458**	**.8952**	**.9845**	**1.1231**	**.7830**	**.5793**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD
Feeder No / Name : 203 / SHIRADWAD FEEDER GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5182	.1829	.4877	.5487	.4877	.3963	.4877
2	.5243	.1981	.4877	.5487	.503	.3963	.503
3	.4801	.2134	.5182	.5487	.4877	.3963	.503
4	.4915	.2134	.4877	.5487	.4877	.3963	.5182
5	.4801	.2591	.4877	.5487	.503	.3963	.503
6	.4973	.3201	.4572	.5487	.4877	.4877	.5182
7	.4801	.3048	.503	.5487	.503		.4725
8	.5571	.3658	.503	.6859	.503		.5182
9	.6154	.5792	.6097	.7545	.6859		.6401
10	.5761	.5792	.6401	.7545	.6554		.6706
11	.5761	.6097	.6401	.7373	.6859		.7545
12	.4973	.6859	.6478	.7202	.7202	.7373	.5792
13	.3258	.5144	.4481	.4801	.463	.583	.4801
14	.4458	.583	.4902	.5144	.5144	.5487	.5487
15	.463	.6687	.664	.6687	.6859	.6859	.6173
16	.4287	.6859	.6478	.703	.7202	.6859	.6097
17	.3429		.6718	.7202	.703	.703	.6859
18	.2915	.6173	.7042	.7202	.7545	.7202	
19	.3086	.6516	.7209	.7202	.7545	.6859	
20	.2286	.5335	.6859	.5639			.5506
21	.2134	.5944	.6173	.5944	.5487	.6401	.6226
22	.2134	.5335	.6173	.6097	.5792	.5487	.583
23	.1829	.4877	.5487	.5182	.4877	.5182	.5571
24	.5376	.1524	.503	.5487	.503	.3963	.5182
Max	**.6154**	**.6859**	**.7209**	**.7545**	**.7545**	**.7373**	**.7545**
Min	**.1829**	**.1524**	**.4481**	**.4801**	**.463**	**.3963**	**.4725**
Avg	**.4282**	**.458**	**.5745**	**.6190**	**.5837**	**.5512**	**.5655**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD
Feeder No / Name : 204 / ABDUL LAT AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9831	1.1488	.12	.12	.12	.0914	1.1488
2		1.1488	.1029	.12	.1029	.0914	1.1317
3	.9282	1.1488	.12	.12	.12	.0914	1.1488
4	.9172	1.0212	.12	.12	.12	.0914	1.166
5	.9717	1.1831	.1543	.1372	.1543	.1219	1.2003
6	1.0202	1.2517	.1543	.1543	.1715	.1372	1.286
7	1.4746	1.6289	.1715	.1886	.2229		1.6975
8	.1029	.1715	1.8861		2.0576		.1715
9	.1143	.1543	2.2634	.2229	2.4691		.1715
10	.1029	.1715	2.6235	2.6235	2.6578		.1543
11	.0945	.12	2.7092	2.6063	2.6235		.1543
12	.12	.12	2.7035	2.6406	2.3491	2.692	.1219
13	.1029	.1543	2.6355	2.1091	2.3663		.1067
14	.1029	.1372	2.5526	2.3663	2.3491	2.4177	.1067
15	.0857	.1543	2.5029	2.4691	2.3663	2.3148	.0914
16	.1029	.1543	.0867	2.2291	.1029	.1029	.0914
17	.1715	.0857		.1372	.1372	.1372	
18	.1543	.1886	.132	.1715	.1715	.1715	
19	.1886	.2058	.1547	.2058	.1886	.2058	
20	.1886	.2058	.2229	.2058	.1829	.1886	.1734
21	.1886	.1886	.1829	.2058	.1677	.1886	.1467
22	1.1488	.1543	.1543	.1543	.1372	1.2003	1.0364
23	1.1488	.12	.12	.1372	.0914	1.1488	1.0159
24	.9488	1.1488	.1029	.12	.12	.0914	1.1488
Max	**1.4746**	**1.6289**	**2.7092**	**2.6406**	**2.6578**	**2.692**	**1.6975**
Min	**.0857**	**.0857**	**.0867**	**.12**	**.0914**	**.0914**	**.0914**
Avg	**.494**	**.5069**	**.9555**	**.8506**	**.8979**	**.6380**	**.6414**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD
Feeder No / Name : 205 / 11 KV LATWAD GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0297	.0686	.0686	.0686	.0171	.0305	.0343
2	.0297	.0857	.0857	.0686	.0171	.0305	.0343
3	.0305	.0686	.0686	.0686	.0171	.0305	.0343
4	.0305	.0857	.0857	.0514	.0171	.0305	.0343
5	.0293	.0857	.0857	.0514	.0343	.0457	.0686
6	.0297	.0857	.0857	.0343	.0343	.0762	.0686
7	.0297	.0686	.0857	.0343	.0343		.1029
8	.0297	.0686	.0857	.0343	.0343		.0857
9	.0286	.0686	.0343	.0343	.0343		.1029
10	.0305	.0857	.0343	.0343	.0343		.0857
11	.0305	.0857	.0343	.0857	.0343		.0686
12	.0343	.0857	.0305	.0686		.0343	.0762
13	.0343	.0857	.032	.0686	.0343	.0343	.0305
14	.0343	.0857	.0305	.0343	.0343	.0857	.0152
15	.0343	.0857	.0305	.0343	.0514	.0857	.0152
16	.0343	.0343	.0762	.0343	.1029	.0343	.0305
17	.0343	.0514	.0892	.0343	.0857	.0686	.0305
18	.0343	.1029	.0937		.1029	.1029	
19	.0514	.0857	.0914	.0343	.0857	.0857	
20	.0343	.0343	.1029	.0343	.0305	.0857	.0297
21	.0343	.0857	.1029	.0343	.061	.0857	.0305
22	.0343	.0857	.0686	.0343	.0762	.0857	.0297
23	.0343	.0857	.0857	.0343	.061	.0514	.0305
24	.0267	.0686	.0686	.0857	.0171	.061	.0514
Max	**.0514**	**.1029**	**.1029**	**.0857**	**.1029**	**.1029**	**.1029**
Min	**.0267**	**.0343**	**.0305**	**.0343**	**.0171**	**.0305**	**.0152**
Avg	**.0327**	**.0764**	**.0690**	**.0477**	**.0457**	**.0603**	**.0496**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD
Feeder No / Name : 206 / 11 Kv Society Feeder GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.1886	.2743	.3086	.3086	.2286	.2915
2	.2374	.1715	.2915	.3086	.3086	.2286	.2572
3	.2229	.1886	.2572	.3086	.2915	.2286	.2572
4	.2229	.1886	.2572	.3086	.2915	.2286	.2743
5	.2229	.1715	.2743	.3086	.2743	.2591	.2572
6	.2204	.1715	.2572	.3086	.2743	.2591	.2743
7	.3189	.1886	.2229	.3086	.2915		.2915
8	.2715	.2058	.2915	.2915	.3086		.3086
9	.2743	.3258	.3772	.2572	.3429		.3772
10	.2915	.3601	.4115		.3601		.4115
11	.2915	.0857	.3429		.3429		.4287
12	.2572	.3772	.3429	.2401	.3429	.2915	
13	.2743	.2743	.2481	.2401	.2915	.3086	.3201
14	.2572	.3258	.3086	.2743	.3944	.3086	.3506
15	.2743	.3429	.3681	.2743	.3944		.381
16	.2915	.3601		.2572	.3258	.2915	.3201
17	.2572	.3601	.3681	.2743	.3601		
18	.2572		.3544	1.4098	.3772		
19	.2229	.3258	.3506	.2572	.3601	.3601	
20	.1886	.3258	.2915	.3086	.3201	.3429	.2401
21	.1543	.2743	.2915	.3086	.3048	.3429	.3429
22	.1715	.2743	.2743	.3429	.2591	.3258	.333
23	.1886	.2915	.3086	.3429	.2743	.3258	.3366
24	.2572	.1886	.2743	.3086	.3429	.3086	.3258
Max	**.3189**	**.3772**	**.4115**	**1.4098**	**.3944**	**.3601**	**.4287**
Min	**.1543**	**.0857**	**.2229**	**.2401**	**.2591**	**.2286**	**.2401**
Avg	**.2444**	**.2594**	**.3060**	**.3431**	**.3226**	**.2899**	**.3190**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD
Feeder No / Name : 402 / I-CO SPIN FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.4582	4.2867	4.1152		4.0009		4.3439
2	4.2295	4.3439	4.1152		4.0009		4.3439
3	4.0009	4.3439	4.0581		3.9438		4.2295
4	4.0009	4.2867	4.0009		4.0009		4.1152
5	4.1152	4.1724	3.8866		4.0009		4.2295
6	4.1152	4.0581	3.7723		3.8866		4.1724
7	4.1724	4.1152	4.0009		4.1724		4.0581
8	4.5153	4.4582	3.8866		4.3439		4.1152
9	4.1152	4.0581	4.1152		4.1724		4.5153
10	4.1724	4.3439	4.2295		4.0581		4.2867
11	4.2867	4.401	4.0581		4.401		4.1724
12	3.9095	4.1152	4.401	3.7037	4.3439	4.1724	4.3439
13	4.2181	4.6296	4.2295	4.2867	4.2295	4.2867	4.1152
14	4.0638	4.5153	4.2867	3.9438	4.2867	4.4582	4.5153
15	4.2867	3.7551	4.5725	4.2867	4.7439	4.5725	4.1724
16	4.6296	4.2181	4.4582	4.2867	4.5153	4.5153	4.2295
17	4.4582	3.9095	4.1152	4.2867	4.4582	4.4582	4.4582
18	4.5725	3.9095	3.8866	4.2295	4.5153	4.8011	
19	4.2295	4.4582	4.401	4.2867	4.2867	4.401	
20	4.3439	3.9438	4.401	4.1152	4.5153	4.4582	4.401
21	4.2867	4.2295		4.3439	4.2867	4.2295	
22	4.401	4.2867	4.2867	4.4582	4.3439	4.4582	4.4582
23	4.1152	4.3439	4.5153	4.0581	4.5153	4.4582	4.6868
24	4.6296	4.401	4.1724		4.3439		4.401
Max	**4.6296**	**4.6296**	**4.5725**	**4.4582**	**4.7439**	**4.8011**	**4.6868**
Min	**3.9095**	**3.7551**	**3.7723**	**3.7037**	**3.8866**	**4.1724**	**4.0581**
Avg	**4.2636**	**4.2326**	**4.1724**	**4.1905**	**4.2653**	**4.4391**	**4.3030**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144072 / 33/11 KV CHANDUR
Feeder No / Name : 201 / 11 KV SAHARANAGAR GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5898	.2753	.4858	.506	.5243	.5182	.4858
2	.5571	.2591	.4049	.4687	.5243	.4877	.4915
3	.5243	.2591	.4049	.4801	.5243	.4877	.4915
4	.5243	.2429	.4049	.4744	.5243	.4877	.4915
5	.4915	.2429	.4049	.4801	.5243	.4877	.4915
6	.4915	.2591	.4049	.4801	.5243	.4725	.4915
7	.4915	.2915	.4858	.5121	.4915	.4725	.4915
8	.4915	.3239	.5182	.5281	.4915	.5335	.5735
9	.5898	.6154	.6478	.6097	.6882	.6706	.6554
10	.5571	.6478	.6478	.6562	.6882	.6706	.6554
11	.6009	.6478	.6401	.6554	.6401	.6478	.6249
12	.5693	.6478	.5864	.6554	.5792	.6478	.5792
13	.2372	.4049	.5556	.5571	.442	.4049	.5658
14	.3479	.4858	.4687	.5243	.5335	.5668	
15	.3953	.6478	.6097	.6226	.6554	.7287	.6097
16	.3563	.6478	.6401	.6882	.6859	.7287	.6401
17	.3239	.6478	.6401	.6554	.6859	.7287	.6249
18	.2591	.7287	.602	.6554	.7164	.7287	.6097
19	.2591	.7287	.5792	.6554	.6859	.6478	.5792
20	.2591	.6478	.5556	.6226	.6401		.5792
21	.2753	.6478	.571	.6226	.6097	.1943	.5792
22	.3395	.6478	.571	.5898	.5944	.5668	.5639
23	.3584	.583	.5468	.5243	.5639	.583	.5624
24	.6226	.2915	.5668	.5155	.5243	.5335	.5735
Max	**.6226**	**.7287**	**.6478**	**.6882**	**.7164**	**.7287**	**.6554**
Min	**.2372**	**.2429**	**.4049**	**.4687**	**.442**	**.1943**	**.4858**
Avg	**.4380**	**.4926**	**.5393**	**.5725**	**.5859**	**.5651**	**.5657**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144072 / 33/11 KV CHANDUR
Feeder No / Name : 202 / 11 KV BIRDEV GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2407	.578	1.1336	1.1717	1.1736	1.1888	1.2574
2	1.2071	.5468	1.1336	1.1717	1.1736	1.1431	1.2574
3	1.2071	.5468	1.1336	1.1717	1.1736	1.1431	1.2574
4	1.1736	.5624	1.1336	1.186	1.2071	1.0974	1.2574
5	1.1736	.5937	1.1336	1.2003	1.2407	1.0669	1.2574
6	1.1736	.6882	1.1336	1.2003	1.291	1.1431	1.2574
7	1.3077	.9061	1.2146	1.186	1.3413	1.2651	1.4251
8	1.3916	.9686	1.4575	1.2003	1.4754	1.3413	1.5089
9	1.4754	1.4373	1.6194	1.3889	1.643	1.448	1.5927
10	1.5089	1.4529	1.6194	1.4842	1.6766	1.5242	1.6766
11	1.2955	1.5384	1.448	1.5927	1.6105	1.5384	1.5242
12	1.2346		1.2955	1.1736	1.5051	1.4575	1.1883
13	.6554	1.3765	1.1574		1.0235	1.1336	1.1069
14	1.1279	1.3765	1.448	1.4586	1.2803	1.3765	1.3279
15	1.1888	1.5384	1.448	1.4419	1.3546	1.4575	1.3717
16	1.1431	1.5384	1.3889	1.4419	1.3696	1.5384	1.448
17	.6097	1.6194	1.3717	1.4754	1.3847	1.6194	1.448
18	.5487	1.6194	1.5051	1.4922	1.3998	1.7004	
19	.5792	1.5384	1.448	1.4754	1.3998	1.5384	
20	.6401	1.5384	1.3717	1.4754	1.3847	1.5384	1.3717
21	.7468	1.4575	1.2955	1.5089	1.3847	1.4575	1.3717
22	.7316	1.4575	1.3426	1.3077	1.3546	1.4575	
23	.6859	1.2955	1.2498	1.2239	1.2492	1.3765	1.3279
24	1.2742	.5639	1.2146	1.1717	1.1736	1.2193	1.3413
Max	**1.5089**	**1.6194**	**1.6194**	**1.5927**	**1.6766**	**1.7004**	**1.6766**
Min	**.5487**	**.5468**	**1.1336**	**1.1717**	**1.0235**	**1.0669**	**1.1069**
Avg	**1.0550**	**1.1626**	**1.3207**	**1.3305**	**1.3446**	**1.3654**	**1.3607**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144072 / 33/11 KV CHANDUR
Feeder No / Name : 203 / 11 KV Industrial Feeder KV- 11 / OUTGOING
SHEDDABLE FEEDER HAVING WEEKLY STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9172	2.5911	2.6578	2.5692	2.0645	2.5911	2.5911
2	2.8502	2.5587	2.6578	2.4863	2.0645	2.4615	2.5911
3	2.8166	2.5101	2.7435	2.4863	2.0645	2.4615	2.5911
4	2.8166	2.4291	2.6578	2.4863		2.332	2.5911
5	2.7161	2.3482	2.572	2.4891	2.0972	2.332	2.5911
6	2.7161	2.3967	2.6578	2.4863	2.0972	2.4291	2.5101
7	2.7328	2.4615	2.7435	2.5149	1.9006	2.5101	2.5911
8	2.8166	2.5263	2.7435	2.3148	2.1464	2.5911	2.5911
9	3.1352	3.1093	3.1722	1.1393	2.9165	2.8502	2.915
10	3.1017	2.9797	3.2579	1.1393	2.9001	3.0445	2.915
11	3.0727	3.0864	3.1131	1.1736	3.0769	3.0864	2.9492
12	3.0087	3.0864	2.9492	1.0059	2.3482	2.8292	2.6379
13	2.2405	2.572	2.7035		2.3482	2.572	2.652
14	2.8807	3.0864	2.7854	.6371	2.8502	3.1722	2.8178
15	2.9959	3.0864	2.915	.6706	2.9959	3.2579	2.9835
16	2.9959	3.0864	3.0664	.6706	2.9959	3.3436	3.0664
17	2.9635	3.0864	3.0664	.6706	2.9797	3.3436	3.0312
18	2.915	3.1722	3.0664	.6706	2.9797	3.4294	3.0664
19	2.8826	2.9959	2.9492	.7712	2.9797	3.2579	2.9835
20	2.834	3.0864	2.9007	.9389	2.9797	3.0864	2.9835
21	2.7854	2.915	2.9007	2.2131	2.915	3.1722	2.9835
22	2.753	2.8292	2.8178	2.2466	2.8502	3.0864	2.8006
23	2.7206	2.915	2.7349	2.1628	2.7206	3.0007	2.934
24	3.0178	2.5911	2.7435	2.652	2.0645	2.672	2.915
Max	**3.1352**	**3.1722**	**3.2579**	**2.652**	**3.0769**	**3.4294**	**3.0664**
Min	**2.2405**	**2.3482**	**2.572**	**.6371**	**1.9006**	**2.332**	**2.5101**
Avg	**2.8619**	**2.8127**	**2.8573**	**1.6781**	**2.5798**	**2.8714**	**2.8034**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144072 / 33/11 KV CHANDUR
Feeder No / Name : 205 / Chandur Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.583	.4049	.4458	.4887		
2		.5506	.4049	.4287	.4887		
3		.5182	.4049	.4287	.4706		
4		.4858	.4049	.4287	.4706		
5		.4858	.4858	.4287	.4344		
6		.5182	.4858	.4458	.4344		
7		.5182	.4858	.4801	.4887		
8	1.0679					1.086	.9717
9	1.1403					1.1584	1.2003
10	1.2308					1.3575	1.286
11	1.1142					1.2146	1.2431
12	1.0814					1.2146	1.1934
13	1.0486					1.2146	
14	1.0395					1.2146	1.21
15	.9724					1.2146	1.2483
22	.724	.4049	.4424	.4733			
23	.7964	.4049	.4424	.4733			
24		.7059	.4049	.463	.4887		
Max	**1.2308**	**.7059**	**.4858**	**.4801**	**.4887**	**1.3575**	**1.286**
Min	**.724**	**.4049**	**.4049**	**.4287**	**.4344**	**1.086**	**.9717**
Avg	**1.0216**	**.5176**	**.4367**	**.4496**	**.4706**	**1.2094**	**1.1933**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144072 / 33/11 KV CHANDUR
Feeder No / Name : 206 / 11 Kv Abhar Phata Industrial Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.131	3.131	3.1121	3.0178	3.0933	3.1687	3.2065
2	3.0933	3.1121	3.1121	3.1121	3.0556	3.1121	3.2065
3	3.0933	3.1121	3.2065	3.1121	3.0556	3.0933	3.1121
4	3.131	3.1121	3.0178	3.0178	3.0556	3.0933	3.2065
5	3.1687	3.1121	3.1121	3.0178	3.0556	3.0933	
6	3.131	3.131	3.1121	3.2065	3.0933	3.0556	3.1121
7	3.131	3.1687	3.2065	3.0178	3.2065	3.0556	3.1121
8	3.0933	3.131	3.2065	2.8292	3.131	3.131	3.2065
9	3.2065	3.131	3.2065	2.5463	3.2065	3.263	3.3008
10	3.131	3.1687	3.2065	2.3577	3.0933	3.2065	3.2065
11	3.0556	3.1121	3.1121	2.452	3.2442	3.0178	3.2065
12	3.0556	3.0178	3.0178	2.3577	3.1687	3.1121	3.0556
13	3.0178	3.1121	3.0178	2.1691	3.0178	3.2065	3.0178
14	3.0933	3.2065	3.2065	1.9993	3.2065	3.3008	3.2065
15	3.1687	3.3008	3.1121	2.037	3.3196	3.3951	3.2065
16	3.1121	3.2065	3.2065	2.037	3.2819	3.3008	3.1121
17	3.0556	3.2065	3.2065	1.9993	3.2442	3.3951	3.1121
18	2.9424	3.3008	3.2065	2.037	3.1687	3.2065	3.2065
19	2.9801	3.3008	3.1121	2.1691	3.2065	3.3008	3.2065
20	3.0556	3.2065	3.0178	2.8292	3.2442	3.2065	3.3008
21	3.1121	3.3008	3.1121	3.0933	3.2442	3.2065	3.3951
22	3.1121	3.1121	3.2065	3.0933	3.2442	3.3008	3.3008
23	3.0556	3.1121	3.1121	3.0933	3.2065	3.3008	3.2065
24	3.1687	3.1687	3.0178	3.0178	3.0178	3.1687	3.3008
Max	**3.2065**	**3.3008**	**3.2065**	**3.2065**	**3.3196**	**3.3951**	**3.3951**
Min	**2.9424**	**3.0178**	**3.0178**	**1.9993**	**3.0178**	**3.0178**	**3.0178**
Avg	**3.0956**	**3.1656**	**3.1318**	**2.6508**	**3.1609**	**3.1955**	**3.1958**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144072 / 33/11 KV CHANDUR
Feeder No / Name : 207 / 11 KV Sonar Mali AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.7625	.7712	.6036	.6706
2				.7373	.7712	.6036	.5868
3				.7373	.7712	.5868	.5868
4				.7459	.7712	.5868	.5868
5				.7459	.7377	.5868	.5868
6				.7956	.6371	.6203	.6478
7				.8288	.7042	.6539	.6478
8	.9556	1.1736	1.2146				
9	1.1233		1.2955				
10	1.2407	1.3413	1.2955				
11	1.2407	1.3765	1.2498				
12	1.3077	1.3765	1.2498				
13	1.3077	1.3765	1.2811				
14	1.3077	1.3765	1.278				
15	1.3077	1.3765	1.2289				
22			.8288	.7377	.5365	.6478	
23			.7907		.6371	.6478	
24				.779	.7712	.6371	.6478
Max	**1.3077**	**1.3765**	**1.2955**	**.8288**	**.7712**	**.6539**	**.6706**
Min	**.9556**	**1.1736**	**.7907**	**.7373**	**.5365**	**.5868**	**.5868**
Avg	**1.2239**	**1.3425**	**1.1713**	**.7633**	**.7109**	**.6175**	**.6202**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144072 / 33/11 KV CHANDUR
Feeder No / Name : 208 / 11 KV MAULI FEEDER SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.278	1.1797	1.2308	1.186	.9503	1.2631	1.2289
2	1.278	1.1469	1.2146	1.1203	.9503	1.2631	1.2146
3	1.2452	1.1142	1.2146	1.1203	.9503	1.2308	1.2146
4	1.2125	1.065	1.2146	1.1203	.9175	1.2308	1.2289
5	1.2125	1.065	1.2146	1.1203	.9175	1.2308	1.2289
6	1.2125	1.1469	1.2146	1.1683	.9339	1.247	1.2955
7	1.2125	1.2289	1.2955	1.0802	.9831	1.247	1.3108
8	1.278	1.3108	1.2955	.9602	1.1142	1.3279	1.3108
9	1.4091	1.4746	1.4575	.9717	1.4419	1.4251	1.5565
10	1.3763	1.4255	1.5384	.9717	1.5074	1.4251	1.5384
11	1.4419	1.5384	1.4842		1.4737	1.4575	1.4842
12	1.3763	1.4575	1.3441			1.3765	1.3441
13	1.0486	1.0526	1.186	.4694	1.4251	1.2146	1.1203
14	1.2289	1.2955	1.2811	.4359	1.166	1.3765	1.2651
15	1.2944	1.4575	1.406	.4694	1.4251	1.5384	1.3279
16	1.278	1.4575	1.406	.4694	1.4575	1.5384	1.406
17	1.278	1.4575	1.406	.503	1.4575	1.5384	1.4842
18	1.2616	1.4575	1.4842	.5365	1.4737	1.5384	1.4529
19	1.278	1.4575	1.4842	.57	1.4575	1.4575	1.406
20	1.278	1.3765	1.406	.6036	1.3927	1.4575	1.4232
21	1.3108	1.4575	1.3441	1.0059	1.3279	1.4575	1.4232
22	1.3108	1.4575	1.3441	1.0395	1.3279	1.4575	1.2967
23	1.278	1.3765	1.3441	1.0395	1.3279	1.3765	1.4232
24	1.3108	1.2289	1.2955	1.2651	.9831	1.2955	1.2955
Max	**1.4419**	**1.5384**	**1.5384**	**1.2651**	**1.5074**	**1.5384**	**1.5565**
Min	**1.0486**	**1.0526**	**1.186**	**.4359**	**.9175**	**1.2146**	**1.1203**
Avg	**1.2787**	**1.3202**	**1.3378**	**.8739**	**1.2331**	**1.3738**	**1.3450**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144072 / 33/11 KV CHANDUR
Feeder No / Name : 209 / 11 KV Jaihind Feeder SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7167	.6036	.7545	.7167	.6413	.6413	.7545
2	.679	.6036	.7545	.7167	.6413	.6413	.7545
3	.679	.6036	.7545	.6979	.6036	.6413	.7545
4	.679	.6036	.7545	.6979	.6036	.6413	.7167
5	.679	.6036	.7545	.6979	.6036	.679	.7167
6	.679	.5658	.7545	.679	.6036	.679	.7545
7	.6413	.5281	.7545	.6602	.679	.6413	.7167
8	.6036	.6036	.6602	.6243	.679	.6413	.7545
9	.6036	.679	.7545	.7545	.7167	.679	.7545
10	.6036	.7545	.7545	.7545	.7922	.7545	.7545
11	.6413	.7545	.7733	.7545	.7922	.7545	.7356
12	.6413	.7545	.7545	.7167	.7167	.6602	.679
13	.6036	.6602	.6979		.6413	.4715	.6602
14	.6413	.7545	.7545	.4527	.7167	.4715	.7922
15	.679	.7545	.7545	.5658	.7922	.4715	.7733
16	.679	.7545	.7733	.6036	.7922	.4715	.7733
17	.6413	.7545	.7545	.6036	.7922	.4715	.7545
18	.6036	.7545	.7922	.5658	.7545	.4715	.7545
19	.6036	.7545	.7733	.5658	.7545	.7545	
20	.6036	.7545	.7545	.5658	.7545	.7545	.7545
21	.6036	.7545	.7545	.679	.7167	.7545	.7545
22	.6413	.7545	.7167	.679	.7167	.7545	.7545
23	.6413	.7545	.7356	.679	.679	.7545	.7356
24	.7167	.6036	.7545	.7356	.6413	.679	.7545
Max	**.7167**	**.7545**	**.7922**	**.7545**	**.7922**	**.7545**	**.7922**
Min	**.6036**	**.5281**	**.6602**	**.4527**	**.6036**	**.4715**	**.6602**
Avg	**.6460**	**.6861**	**.7498**	**.6594**	**.7010**	**.6389**	**.7438**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144108 / 33/11 KV PARVATI INDUSTRIAL ES
Feeder No / Name : 201 / 11KV TELEPHONE EXCHANGE Feeder KV- 11 / OUTGOING SHEDDABLE FEEDER HAVING WEEKLY STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.112	.1334		.1143	.112	.1143
2	.1143	.112	.1334		.1143	.112	.1143
3	.1143	.112	.1143		.0953	.112	.0953
4	.1334	.112	.1143		.0953	.112	.0953
5	.1334	.112	.1143		.1143	.112	.1143
6	.1524	.1307	.1143		.1334	.112	.1143
7	.1334	.1307	.1143		.1143	.112	.1334
8	.1143	.1307	.1334			.112	.1524
9	.168	.1494	.1334		.1334	.1494	
10	.168	.1524	.1334		.1334	.1524	.1524
11	.1494	.1524	.1334		.1524	.1524	.1334
12	.1494	.1524	.1334		.1334	.1524	.1334
13	.1307	.1524	.1334		.1143	.1143	.1334
14	.1307	.1524	.1334		.1143	.1334	.1334
15	.128	.1524	.1334		.112	.1334	.1334
16	.1307	.1524	.1334		.1307	.1524	.1524
17	.1307	.1524		.1334	.1307	.1524	.1334
18	.1494	.1524		.1334	.7655	.1334	.1524
19	.1494	.1524		.1143	.1307	.1524	.1524
20	.112	.1524		.1334	.112	.1334	
21	.112	.1524		.1143		.1524	
22	.112	.1334		.1143	.112	.1334	
23	.112	.1334		.1334	.112	.1143	
24	.1334	.112			.1334	.112	.1143
Max	**.168**	**.1524**	**.1334**	**.1334**	**.7655**	**.1524**	**.1524**
Min	**.112**	**.112**	**.1143**	**.1143**	**.0953**	**.112**	**.0953**
Avg	**.1323**	**.1379**	**.1274**	**.1252**	**.1501**	**.1300**	**.1294**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144108 / 33/11 KV PARVATI INDUSTRIAL ES
Feeder No / Name : 202 / 11 KV KHOTWADI GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8962	.8048	1.419		.5975	.8779	.7842
2	.8589	.7682	1.307		.5601	.8413	.7468
3	.8215	.7316	1.1203		.5228	.8048	.7842
4	.7842	.7316	.9335		.5601	.8048	.8215
5	.8589	.7682	.8589		.6348	.8413	.8589
6	.8962	.8413	.7842		.7095	.8413	.8962
7	.9709	.8779	.9145		.7468	.8779	.9709
8	.9335	.9511	.9709		.7842	.9145	.9335
9	.9877	1.0608	1.0456		.9335	1.0974	1.0288
10	1.0608	1.1203	1.1203		.9709	1.0829	1.1431
11	1.134	1.0829	1.1949		1.0082	1.0082	1.1812
12	.9511	1.0456	1.2323		1.0829	1.0456	1.1431
13	.8413	.9335	1.1576		.8589	.7842	1.0669
14	.9145	1.1203	1.1576		.8962	.8962	1.0288
15	.9877	1.0829	1.1203		1.0242	1.1203	1.105
16	1.0242		.9335		.9877	1.0829	1.0288
17	.9511	1.1203	1.1203	.4854	1.0059	1.0669	1.1431
18	.9877	1.1576		.6348	1.0608	1.105	.9145
19	1.0242			.5975	1.0608	1.1203	.9145
20	.9511	1.0456		.6348	.9145	1.0456	
21	.9145	1.0082		.7842	.9877	1.0082	
22	.8779	.9335		.7468	.9511	.9335	
23	.8779	1.1203		.7095	.9145	.8962	
24	.9335				.6722	.9511	.8215
Max	**1.134**	**1.1576**	**1.419**	**.7842**	**1.0829**	**1.1203**	**1.1812**
Min	**.7842**	**.7316**	**.7842**	**.4854**	**.5228**	**.7842**	**.7468**
Avg	**.9350**	**.9670**	**1.0818**	**.6561**	**.8519**	**.9603**	**.9658**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144108 / 33/11 KV PARVATI INDUSTRIAL ES
Feeder No / Name : 203 / 11 KV SARITA POLYMER Feeder KV- 11 / OUTGOING SHEDDABLE FEEDER HAVING WEEKLY STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.3532	3.3234	3.2388		2.9721	3.0727	3.1245
2	3.315	3.2114	3.1626		2.934	3.1741	3.1626
3	3.2769	3.0361	3.0483		3.0102	3.0994	3.2007
4	3.2388	3.1367	2.9721		3.0864	3.062	3.315
5	3.2769	3.1741	2.8578		3.1626	3.0994	3.3532
6	3.3532	3.2487	2.934		3.2007	3.1367	3.4294
7	3.3722	3.2114	3.0483		3.2579	3.1741	3.4484
8	3.1436	3.2674	3.2579		3.3532	3.1927	3.3341
9	3.3421	3.3608	3.3532		3.1436	3.2861	3.2198
10	3.3048	3.4294	3.4294		3.2388	3.3341	3.2579
11	3.3981	3.4675	3.5437		3.3341	3.3913	3.4294
12	3.3234	3.5437	3.4294		3.3913	3.3722	3.3341
13	3.2861	3.4294	3.3532		3.2579	3.2579	3.2388
14	3.3981	3.3532	3.2388		3.3532	3.3913	3.3532
15	3.3234	3.4675	3.2769		3.2861	3.4675	3.4294
16	3.3608	3.3532	3.0483		3.2674	3.4294	3.3913
17	3.3981	3.4294		1.7718	3.2114	3.5056	3.5246
18	3.3234	3.4484		1.5813	3.1741	3.4675	3.4865
19	3.2487	3.4294		1.7147	3.2114	3.4294	3.4675
20				1.8099	3.1741	3.2388	
21	3.2739			3.2388	3.1741	3.2769	
22	3.4728			3.1436	3.2114	3.3341	
23	3.4016	3.2861		3.0483	3.1741	3.2007	
24	3.3913	3.2861			3.0102	3.062	3.0864
Max	**3.4728**	**3.5437**	**3.5437**	**3.2388**	**3.3913**	**3.5056**	**3.5246**
Min	**3.1436**	**3.0361**	**2.8578**	**1.5813**	**2.934**	**3.062**	**3.0864**
Avg	**3.3294**	**3.3283**	**3.1995**	**2.3298**	**3.1913**	**3.2690**	**3.3293**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144108 / 33/11 KV PARVATI INDUSTRIAL ES
Feeder No / Name : 204 / RENUKANAGAR GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0633	1.4998	1.8671		2.0995	2.0485	2.0633
2	2.0271	1.4083	1.7924		2.0633	2.0119	2.0271
3	1.9909	1.3169	1.8298		2.0271	1.9753	1.9909
4	1.9547	1.4266	1.7924		1.9909	1.9387	1.9547
5	1.9185	1.4815	1.6804		1.9547	1.9387	1.9909
6	1.9909	1.5912	1.7177		1.9909	1.9753	2.0633
7	2.0271	1.6095	1.8298		2.0271	2.0119	2.0995
8	1.9185	1.6827	2.1098		2.1719	2.0485	2.1357
9	1.9022	2.1216	2.2405		2.2443	2.268	2.2862
10	1.9753	2.1948	2.4272		2.3529	2.3167	2.4387
11	2.0911	2.3045	2.7446		2.3891	2.3891	2.5149
12	1.9791	2.3777	2.7633		2.3167	2.2805	2.4768
13	1.6827	2.3525	2.8006		1.8823	1.8823	2.2481
14	1.8107	2.0576	2.726		1.8461	2.1719	2.3624
15	1.8656	2.2405	2.8193		2.3045	2.2443	2.4387
16	1.9022	2.2291	2.6139		2.3411	2.4387	2.3815
17	1.829	2.4143		1.9547	2.3777	2.3167	2.4387
18	1.8473	2.4691		1.9185	2.4143	2.3529	2.4006
19	1.7558	2.3777		1.8823	2.3411	2.3891	2.2862
20	1.6827	2.3525		1.9547	2.2314	2.3167	
21	1.6095	2.2405		2.2443	2.3045	2.2624	
22	1.5729	2.1658		2.1357	2.2862	2.2443	
23	1.5912	2.0538		2.1719	2.1948	2.1719	
24	2.0995	1.5546			2.1357	2.1582	2.0814
Max	**2.0995**	**2.4691**	**2.8193**	**2.2443**	**2.4143**	**2.4387**	**2.5149**
Min	**1.5729**	**1.3169**	**1.6804**	**1.8823**	**1.8461**	**1.8823**	**1.9547**
Avg	**1.8787**	**1.9801**	**2.2347**	**2.0374**	**2.1787**	**2.1730**	**2.2340**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144108 / 33/11 KV PARVATI INDUSTRIAL ES
Feeder No / Name : 205 / 11 KV Sanmati Vg Feeder GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7558	1.5364	1.6804		1.3169	1.829	1.7558
2	1.7193	1.5546	1.7177		1.3535	1.7558	1.7193
3	1.6827	1.5912	1.6057		1.39	1.6827	1.6827
4	1.7558	1.6827	1.5684		1.4266	1.6095	1.6461
5	1.7924	1.6461	1.643		1.4998	1.5912	1.7558
6	1.7558	1.6827	1.6804		1.5364	1.6644	1.7924
7	1.829	1.7924	1.7177		1.5912	1.7924	1.8473
8	1.6827	1.7558	1.9231		1.7193	1.9022	1.7924
9	1.9753	2.1582	2.1658			2.2497	2.21
10	1.9387	2.2405	2.2779			2.2862	2.2481
11	1.9753	2.1658	2.3525		2.2314	2.2314	2.3243
12	1.7558	2.2779	2.3777		2.2497	2.0851	2.3815
13	1.3717	2.3045	2.4143		1.8107	1.6095	2.3624
14	1.8656	2.1948	2.4874		1.9387	1.8656	2.2862
15	1.8473	2.2314	2.5606		2.0485	2.2314	2.4006
16	1.8839	2.1216	2.4874		2.1582	2.1216	2.2862
17	1.9204	2.0538		.7682	2.1948	2.3411	2.2481
18	1.9753	1.957		.7865	2.1582	2.0119	2.3624
19	1.8656	1.9753		.9145	1.9753	1.9387	2.2862
20	1.7558	2.0538		1.0425	1.9753	1.9022	
21	1.6827	2.0165		1.5546	1.8656	1.9387	
22	1.6095	1.9791		1.4266	1.9204	1.957	
23	1.6827	1.8671		1.3169	1.9387	1.8656	
24	1.7924	1.6461			1.2803	1.8656	1.7924
Max	**1.9753**	**2.3045**	**2.5606**	**1.5546**	**2.2497**	**2.3411**	**2.4006**
Min	**1.3717**	**1.5364**	**1.5684**	**.7682**	**1.2803**	**1.5912**	**1.6461**
Avg	**1.7863**	**1.9369**	**2.0413**	**1.1157**	**1.7991**	**1.9304**	**2.0590**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144108 / 33/11 KV PARVATI INDUSTRIAL ES
Feeder No / Name : 206 / 11 KV SARADA FEEDER SHEDDABLE FEEDER HAVING WEEKLY Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7816	2.7073	2.5911		2.5911	2.8006	2.8197
2	2.7435	2.5766	2.4768		2.5149	2.6886	2.7816
3	2.7054	2.4832	2.4006		2.4768	2.6513	2.7435
4	2.6673	2.5766	2.3243		2.553	2.5766	2.7816
5	2.7435	2.6513	2.4768		2.5911	2.5579	2.8197
6	2.7816	2.7446	2.5911		2.6673	2.6886	2.8578
7	2.8197	2.7073	2.6673		2.6863	2.6886	2.915
8	2.572	2.7633	2.8197		2.7625	2.7446	2.6673
9	2.8567	2.894	2.8578		2.8769	2.8567	2.9721
10	2.9313	3.0483	2.9721		3.0102	2.8197	2.9721
11	3.0247	3.0864	2.934		3.0674	2.8387	3.1245
12	2.8753	3.1245	2.9721		3.1055	2.934	3.0483
13	2.782	3.0483	2.8959		2.915	2.8387	3.0102
14	2.8753	2.9721	2.7816		2.9531	2.9531	2.9721
15	2.894	2.8769	2.8578		2.9313	2.9721	2.9531
16	2.8753	2.7816			2.95	2.934	2.9531
17	2.9313	2.8769		1.9052	2.9127	2.9912	2.8578
18	2.838			1.8671	2.8753	2.9531	1.0288
19	2.8753	2.8578		1.9052	2.8193	2.8769	2.9721
20	2.6513	3.3532		2.0195	2.7633	2.8197	
21	2.7073			2.7435	2.838	2.8959	
22	2.7633	3.4675		2.572	2.894	2.9531	
23		2.7816		2.6673	2.7618	3.0102	
24	2.8197	2.6886			2.6292	2.7633	2.8578
Max	**3.0247**	**3.4675**	**2.9721**	**2.7435**	**3.1055**	**3.0102**	**3.1245**
Min	**2.572**	**2.4832**	**2.3243**	**1.8671**	**2.4768**	**2.5579**	**1.0288**
Avg	**2.8050**	**2.8667**	**2.7079**	**2.2400**	**2.7978**	**2.8253**	**2.8054**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144114 / 33/33 KV LAXMI SWITCHING STATI
Feeder No / Name : 402 / 33 KV KABNOOR Feeder KV- 33 / INCOMING SHEDDABLE FEEDER HAVING WEEKLY STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3086	.3086	.3086	.3086	.3086	.3086
2	.3086	.3086	.3086	.3086	.3086	.3086	.3086
3	.3086	.3086	.3086	.3086	.3086	.3086	.3086
4	.3086	.3086	.3086	.3086	.3086	.3086	.3086
5	.3086	.3086	.3086	.3086	.3086	.3086	.3086
6	.3086	.3086	.3086	.3086	.3086	.3086	.3086
7	.3086	.3086	.3086	.3086	.3086	.3086	.3086
8	.3086	.3086	.3086	.3086	.3086	.3086	.3086
9	.3086	.3086	.3086	.3086	.3086	.3086	.3086
10	.3086	.3086	.3086	.3086	.3086	.3086	.3086
11	.3086	.3086	.3086	.3086	.3086	.3086	.3086
12	.463	.3086	.3086	.3086	.3086	.3086	.3086
13	.3086	.3086	.3086	.3086	.3086	.3086	.3086
14	.3086	.3086	.3086	.3086	.3086	.3086	.3086
15	.3086	.3086	.3086	.3086	.3086	.3086	.3086
16	.3086	.3086	.3086	.3086	.3086	.3086	.3086
17	.3086	.3086	.3086	.3086	.3086	.3086	.3086
18	.3086	.3086	.3086	.3086	.3086	.3086	.3086
19	.3086	.3086	.3086	.3086	.3086	.3086	.3086
20	.3086	.3086	.3086	.3086	.3086	.3086	.3086
21	.3086	.3086	.3086	.3086	.3086	.3086	.3086
22	.3086	.3086	.3086	.3086	.3086	.3086	.3086
23	.3086	.3086	.3086	.3086	.3086	.3086	.3086
24	.3086	.3086	.3086	.3086		.3086	.3086
Max	**.463**	**.3086**	**.3086**	**.3086**	**.3086**	**.3086**	**.3086**
Min	**.3086**	**.3086**	**.3086**	**.3086**	**.3086**	**.3086**	**.3086**
Avg	**.3150**	**.3086**	**.3086**	**.3086**	**.3086**	**.3086**	**.3086**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144114 / 33/33 KV LAXMI SWITCHING STATI
Feeder No / Name : 405 / 33 KV SAJANI-MANGAON SHEDDABLE URBAN
Feeder KV- 33 / INCOMING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.1728	6.07	5.6584	8.2305	6.893	7.8189	7.9218
2	6.07	5.9671	5.6584	8.179	6.7901	7.7161	7.8704
3	6.07	5.9671	5.5556	8.0761	6.893	7.7161	7.9733
4	5.9156	6.07	5.5556	8.4877	6.9959	7.8189	8.1276
5	5.9156	6.1728	5.7613	8.5905	7.2017	7.9218	7.9218
6	5.9156	6.1728	5.9156	8.5391	7.3045	7.9218	8.0247
7	6.3786	6.1214	5.7099	8.5905	8.3333	8.2305	7.9733
8	6.5844	6.2757	6.2757	8.2305	9.0535	8.8477	8.7963
9	8.8477	10.0823	9.2593	5.144	6.2757	6.7387	5.9671
10	10.2366	11.0597	10.9054		6.9445	6.7901	7.0473
11	10.8025	11.3683	11.5226		6.4815	6.5329	6.7901
12	10.4424	11.1626	11.3683		7.5103	6.6358	6.6358
13	10.2881	11.5741	10.4938		7.0473	6.4815	6.1728
14	9.7222	11.214	10.9568		6.7901	6.6358	6.3272
15	10.6996	11.677	10.3395	.5144	7.2017	6.1728	7.1502
16	9.9794	11.214	11.0082	2.2634	7.0988	6.893	7.2017
17	6.8416	6.6358	6.893	3.8066	7.0988	7.0988	6.7387
18		6.6358	5.9671	3.9609	7.5617	6.2757	6.4301
19	7.0473	6.3272	7.0473	4.2181	6.7901	7.1502	6.6873
20	6.2757	6.5844	5.8642	4.8354	6.6358	6.6873	6.1728
21	5.7613	6.5329	6.2757	5.4527	6.9959	5.9156	6.2757
22	6.3786	6.3786	6.2243	5.144	7.2017	6.4815	6.5329
23	6.1728	6.1728	8.3333	6.7387	7.9218	7.9218	6.1728
24	6.1728	6.07	5.8128	8.3848		7.9218	7.8704
Max	**10.8025**	**11.677**	**11.5226**	**8.5905**	**9.0535**	**8.8477**	**8.7963**
Min	**5.7613**	**5.9671**	**5.5556**	**.5144**	**6.2757**	**5.9156**	**5.9671**
Avg	**7.5953**	**7.8961**	**7.6818**	**6.1783**	**7.1748**	**7.1802**	**7.1159**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144116 / 33/11 KV ABDUL LAT
Feeder No / Name : 202 / 11 KV ABDUL LAT GOVTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0594	.0754	.0924	.0739	.0732	.0732
2	.0686	.0579	.0754	.0934	.0724	.0732	.0732
3	.0686	.0549	.0754	.0633	.0701	.0739	.0754
4	.0671	.0533	.0754	.0556	.0686	.0754	.0633
5	.0655	.0495	.0754	.0648	.0671	.0686	.0594
6	.0655	.0472	.1132	.0657	.0693	.0655	.0625
7	.08	.0671	.1132	.1132	.1029	.0943	.0924
8	.0762	.0541	.1132	.1109	.1132	.0943	.0934
9	.0781	.1254	.1509	.1448	.1829	.1132	.1829
10	.132	.1433	.2218	.1715	.2149	.1886	.2126
11	.1494	.1791	.2481	.181	.2263	.1886	.2126
12	.1509	.1433	.2054	.1509	.2263	.2054	.1791
13	.1509	.1433	.2054	.1132	.1509	.1886	.1075
14	.0983		.1698	.1132	.1509	.2054	.1463
15	.1086	.1886	.1848	.112	.1509	.1698	.1463
16	.0633	.2149	.1663	.1086	.1509	.1509	.1097
17	.0678		.132	.1132	.1509	.2054	.1463
18	.061	.1132	.1109	.0754	.1132	.112	.1097
19	.0533	.1132	.1052	.0594	.0905	.0876	.0732
20	.0619	.0943	.1107	.0533	.0549	.0762	.5898
21	.0638	.0943	.0892	.0633	.0739	.0905	.0732
22	.0533	.0754	.0924	.0693	.0724	.0905	.0732
23	.0541	.0754	.0867	.0686	.0732	.0876	.0732
24	.0754	.0572	.0754	.0876	.0754	.0716	.0686
Max	**.1509**	**.2149**	**.2481**	**.181**	**.2263**	**.2054**	**.5898**
Min	**.0533**	**.0472**	**.0754**	**.0533**	**.0549**	**.0655**	**.0594**
Avg	**.0829**	**.1002**	**.1280**	**.0977**	**.1165**	**.1188**	**.1290**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144116 / 33/11 KV ABDUL LAT
Feeder No / Name : 204 / 11 KV GANGOBA MANDIR GAOTHAN FEEDER
GOVTHAN Feeder KV- 11 /
OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4481	.3429	.4694	.503	.4534	.4744	.4902
2	.4161	.3185	.4359	.4973	.426	.4641	.4744
3	.4161	.333	.4359	.4973	.4024	.4641	.4696
4	.3841	.3258	.4024	.5087		.4424	.4534
5	.4481	.3601	.5365	.5138	.4534	.4807	.4973
6	.5243	.4694	.57	.547	.4999	.5533	.5365
7	.5571	.5609	.6036	.6316	.57	.583	.5765
8	.5898	.5426	.6036	.6478	.6299	.6173	.6036
9	.5898	.6226	.7377	.6722	.6802	.3395	.6718
10	.583	.6554	.6642	.6562	.6081	.6722	.6481
11	.5506	.7209	.6874	.6097	.7042	.6249	
12	.4915	.6226	.6173	.5401	.6722	.578	.5937
13	.4024	.4915	.5281	.4744	.5441	.4744	.5312
14	.3898		.5851	.5117	.5761	.5624	.5761
15	.4694	.5898	.6249		.6081	.6325	.6081
16	.4915	.6226	.6405	.535	.6722	.6171	.6081
17	.431		.6642	.5487	.6722	.5693	.6554
18	.5087	.7712	.6958	.5556	.7042	.7042	.6554
19	.5731	.7042	.7293	.5967	.7373	.7712	.7209
20	.4755	.6706	.6371	.583	.6464	.6783	.5898
21	.4908	.6706	.7045	.6554	.6796	.6718	.5898
22	.4508	.57	.6081	.583	.583	.6167	.5898
23	.407	.5365	.5121	.4938	.506	.5182	.4915
24	.4915	.3467	.503	.5138	.4973	.4784	.506
Max	**.5898**	**.7712**	**.7377**	**.6722**	**.7373**	**.7712**	**.7209**
Min	**.3841**	**.3185**	**.4024**	**.4744**	**.4024**	**.3395**	**.4534**
Avg	**.4825**	**.5386**	**.5915**	**.5598**	**.5881**	**.5662**	**.5712**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARANJI(RURAL)[027] BU 9121
Substation No/ Name :- 144116 / 33/11 KV ABDUL LAT
Feeder No / Name : 205 / 11 KV INDIRA NAGAR GOVTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4588	.2772	.4588	.4902	.4588	.4481	.4588
2	.426	.2772	.426	.4862	.431	.4372	.4534
3	.426	.2427	.426	.4372	.4024	.4111	.4733
4	.3932	.2263	.4588	.4372	.4115	.3953	.4656
5	.4588	.2772	.4915	.4807	.4534	.4372	.4748
6	.4588	.3292	.5243	.4858	.4973	.4915	.5316
7	.4694	.3696	.5571	.4687	.5243	.5243	.5487
8	.4694	.3814	.5571	.5376	.5761	.5441	.5868
9	.503	.6009	.5898	.578	.6249	.6154	.6036
10	.5087	.6081	.5535	.5639	.6173	.5944	.6562
11	.4801	.6401	.5569	.5792	.6249	.5944	.6642
12	.4428	.5761	.4999	.4801	.5624	.5304	.5761
13	.2561	.4801	.4374	.4321	.4999	.427	.4915
14	.4111		.5487	.5093	.5441	.5201	.5243
15	.4374	.6882	.5719	.5624	.5937	.5937	.5898
16	.4111	.6882	.5719	.535	.5937	.6241	.6554
17	.4062		.6019	.5268	.6554	.6562	.6554
18	.373	.6882	.5944	.5182	.6882	.639	.6882
19	.3018	.5898	.583	.4999	.6316	.6796	.6226
20	.2987	.5898	.5218	.4641	.5801	.5967	.6371
21	.3898	.5898	.5376	.5624	.6036	.6478	
22	.3506	.5243	.5312	.5247	.5556	.5304	.6036
23	.3045	.4915	.5376	.4877	.4784	.5144	.57
24	.4915	.2865	.4915	.5218	.4915	.463	.503
Max	**.5087**	**.6882**	**.6019**	**.5792**	**.6882**	**.6796**	**.6882**
Min	**.2561**	**.2263**	**.426**	**.4321**	**.4024**	**.3953**	**.4534**
Avg	**.4136**	**.4737**	**.5262**	**.5071**	**.5458**	**.5381**	**.5667**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI A S/DN.[710] BU 4710
Substation No/ Name :- 144047 / 33/11 KV AMRAI
Feeder No / Name : 201 / 11KV TAKWADE SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6226	.2294	.5344	.5864	.6226	.6299	.5506
2	.583	.2294	.5668	.5312	.6226	.6299	.5668
3	.5506	.213	.5668	.5155	.5898	.5801	.5668
4	.5182	.2294	.5344	.4999	.6226	.5801	.5668
5	.5243	.2458	.502	.4999	.5898	.547	.5506
6	.5571	.2458	.5182	.5312	.5898	.547	.583
7	.5506	.2949	.5218	.5792	.639	.5967	.583
8	.5243	.3768	.5624	.6173	.639	.6133	.583
9	.5735	.6554	.703	.7116	.7701	.7459	.7287
10	.578	.7209	.7186	.7253	.7537	.7459	.7449
11	.578	.7537	.7186	.703	.8029	.779	.7611
12	.5468	.7045	.7253	.7968	.8356	.779	.7773
13	.4049	.5624	.5407	.5801	.6154	.5441	.7209
14	.3887	.6249	.5898	.6299	.6478	.5468	.5735
15	.4696	.6718	.6882	.779	.7935	.7362	.7701
16		.7011	.7373	.7956	.7611	.8002	.8356
17	.2105	.6097	.6882	.779	.7773	.7362	.7537
18	.2429	.6874	.7865	.7459	.7773	.7522	.7701
19	.2915	.7099	.7045	.8122	.6964	.7522	.7701
20	.2753	.6562	.7373	.7045	.7287	.7202	.7537
21	.2622	.6964	.679	.7045	.7459	.7125	.7186
22	.2622	.6802	.6636	.7045	.7127	.6478	.6882
23	.2458	.6802	.6481	.7045	.6962	.664	.7042
24	.6554	.2458	.6316	.6405	.6554	.663	.5992
Max	**.6554**	**.7537**	**.7865**	**.8122**	**.8356**	**.8002**	**.8356**
Min	**.2105**	**.213**	**.502**	**.4999**	**.5898**	**.5441**	**.5506**
Avg	**.4529**	**.5177**	**.6361**	**.6616**	**.6952**	**.6687**	**.6759**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI A S/DN.[710] BU 4710
Substation No/ Name :- 144047 / 33/11 KV AMRAI
Feeder No / Name : 202 / 11 KV PATIL MALA SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1385	.431	.9282	1.0936	1.2597	1.1768	.9602
2	1.1069	.3978	1.0883	1.0623	1.2597	1.1768	1.1043
3	1.0753	.3978	1.0883	.9998	1.1934	1.1271	1.1043
4	1.012	.431	.9602	.9374	1.1934	1.1271	1.0562
5	.9804	.4641	.8962	.9686	1.1934	1.0774	.9602
6	.9875	.4641	.9602	.9998	1.1603	1.0442	.9922
7	1.012	.5304	1.0911	1.0936	1.1934	1.1768	1.0402
8	.9922	.7293	1.1069	1.1873	1.2597	1.1934	1.1683
9	.8002	1.3923	1.3916	1.3435	1.4586	1.4752	1.3283
10	.6718	1.4255	1.3748	1.3904	1.3923	1.4091	1.3763
11	.7186	1.1271	1.4217	1.4373	1.4586	1.4586	1.3443
12	.7186	1.326	1.3904	1.3283	1.3592	1.442	1.2483
13	.4481	.8436	.8951	.9945	.9602	.8905	1.3676
14	.5441	1.0437	1.094	1.2597	1.1203	.953	1.0608
15	.5121	1.2932	1.326	1.3923	1.2963	1.2498	1.3592
16	.6401	1.3435	1.4255	1.3592	1.4083	1.2651	1.4255
17	.5761	1.2811	1.2597	1.4255	1.2963	1.2651	1.2929
18	.5281	1.3283	1.5249	1.4918	1.4563	1.3916	1.4586
19	.5921	1.4232	1.4918	1.5415	1.4723	1.4548	1.4586
20	.5441	1.2967	1.3923	1.4255	1.3763	1.3123	1.3592
21	.5761	1.3123	1.3748	1.4255	1.3592	1.4083	1.2967
22	.5304	1.2483	1.2498	1.326	1.3592	1.2803	1.2651
23	.4641	1.2163	1.2029	1.326	1.3426	1.2643	1.2334
24	1.2334	.4641	1.1043	1.1561	1.2929	1.2431	1.1363
Max	**1.2334**	**1.4255**	**1.5249**	**1.5415**	**1.4723**	**1.4752**	**1.4586**
Min	**.4481**	**.3978**	**.8951**	**.9374**	**.9602**	**.8905**	**.9602**
Avg	**.7668**	**.9671**	**1.2100**	**1.2486**	**1.2967**	**1.2443**	**1.2249**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI A S/DN.[710] BU 4710
Substation No/ Name :- 144047 / 33/11 KV AMRAI
Feeder No / Name : 203 / 11 KV PARIJAAT FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6104	.2984	.5571	.583	.5967	.6299	.5898
2	.583	.2984	.5898	.5533	.5636	.6299	.6062
3	.5765	.2652	.5898	.5596	.5636	.6299	.6062
4	.5658	.2984	.5571	.5426	.5967	.6299	.6062
5	.5658	.3315	.5243	.5487	.6133	.6299	.5898
6	.583	.3315	.639	.5658	.6133	.6539	.7045
7	.6516	.4144	.6554	.6001	.6962	.6464	.6554
8	.6516	.4475	.6554	.5535	.6796	.6962	.7045
9	.6516	.8122	.8097	.6478	.8288	.7956	.8356
10	.5668	.7956	.7811	.6802	.8288	.8288	.9175
11	.5668	.8619	.7499	.7287	.8785	.8619	.8684
12	.5182	.8288	.6642	.7773	.8288	.8288	.7537
13	.3605	.5668	.6133	.663	.6226	.6325	.6882
14	.3113	.6478	.6133	.663	.7373	.7773	.7293
15	.3441	.7773	.7625	.7956	.8192	.8192	.8288
16	.4096	.7499	.7293	.7459	.8192	.8192	.8288
17	.3932	.7907	.7956	.779	.852	.852	.8785
18	.3768	.8097	.7956	.7459	.8356	.8192	.8453
19	.3932	.8421	.8288	.8122	.8192	.8192	.8453
20	.3441	.7287	.8122	.7956	.7537	.7956	.8288
21	.4144	.8029	.7287	.7956	.7956	.7701	
22	.3812	.7045	.6802	.7956	.7459	.6882	.7116
23	.3315	.6554	.6154	.6133	.6962	.7045	.6554
24	.6299	.3315	.6226	.6001	.5967	.663	.6226
Max	**.6516**	**.8619**	**.8288**	**.8122**	**.8785**	**.8619**	**.9175**
Min	**.3113**	**.2652**	**.5243**	**.5426**	**.5636**	**.6299**	**.5898**
Avg	**.4909**	**.5996**	**.6821**	**.6727**	**.7242**	**.7342**	**.7348**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI A S/DN.[710] BU 4710
Substation No/ Name :- 144047 / 33/11 KV AMRAI
Feeder No / Name : 204 / 11 KV DRAINAJE FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8596	.431	.6882	.7202	.7956	.7377	.6962
2	.7712	.3978	.6962	.6859	.7293	.7377	.7291
3	.7362	.3978	.6962	.6859	.7293	.7377	.7291
4	.7265	.431	.663	.6443	.6962	.7377	.7291
5	.7602	.4641	.6371	.6443	.6962	.7377	.7122
6	.7796	.4641	.7042	.7202	.7956	.7377	.7373
7	.8059	.5636	.7712	.823	.8288	.8551	.8149
8	.8063	.7625	.8886	.9175	.8951	.9221	.9156
9	.7362	1.094	1.1065	1.0814	1.1603	1.0898	1.085
10	.6962	1.0608	1.094	1.1271	1.094	1.1401	1.1336
11	.6299	1.0608	1.0608		1.1603	1.1401	1.1174
12	.57	.8951	.9831	.9945	1.0277	1.0562	.9393
13	.4119	.6554	.6962	.7042	.7865	.763	.9282
14	.4075	.8718	.8619	.7712	.8848	.9054	.9614
15	.5083	.9945	1.0277	.9724	1.0486	1.0774	1.1271
16	.4557	1.0322	1.094	1.0059	1.004	1.1065	.9614
17	.4733	.9069	1.094	1.0395	1.1174	1.1271	1.1271
18	.5552	1.094	1.1271	1.1736	1.1012	1.1065	1.1934
19	.6535	1.094	1.0608	1.1736	1.1603	1.1437	1.0277
20	.6584	1.0395	.9614	.9945	1.0608	1.0059	.9945
21	.5304	1.065	1.0486	1.0277	1.1065	1.0774	1.0277
22	.5304	.9945	.8848	.9614	1.0059	.9614	.9054
23		.8745	.8453	.8619	.9221	.8745	.8718
24	.8764	.4641	.7865	.7545	.8288	.7459	.7209
Max	**.8764**	**1.094**	**1.1271**	**1.1736**	**1.1603**	**1.1437**	**1.1934**
Min	**.4075**	**.3978**	**.6371**	**.6443**	**.6962**	**.7377**	**.6962**
Avg	**.6495**	**.7962**	**.8949**	**.8906**	**.9431**	**.9385**	**.9244**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI A S/DN.[710] BU 4710
Substation No/ Name :- 144047 / 33/11 KV AMRAI
Feeder No / Name : 205 / BALIRAJA SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3277	.3277	.2785	.2949		
2		.2949	.3113	.2622	.2294		
3		.2949	.3113	.2652	.2294		
4		.3277	.3113	.2987	.2622		
5		.3605	.3113	.2987	.2949		
6		.3277	.3277	.3315	.2622		
7		.3277	.3361	.3481	.2949		
8					.3932	.5304	.6062
9				.1311	.4915	.5636	.639
10					.5571	.6133	.6882
11					.5898	.6133	.639
12					.639	.6133	.6882
13					.639	.578	.6554
14					.6062	.5601	.6062
15					.5898	.5898	.6062
22	.4424	.3441	.2753	.2949			
23	.3932	.3441	.2949	.2785			
24		.3605	.3277		.2785		
Max	**.4424**	**.3605**	**.3361**	**.3481**	**.639**	**.6133**	**.6882**
Min	**.3932**	**.2949**	**.2753**	**.1311**	**.2294**	**.5304**	**.6062**
Avg	**.4178**	**.3310**	**.3135**	**.2787**	**.4158**	**.5827**	**.6411**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI A S/DN.[710] BU 4710
Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S
Feeder No / Name : 201 / TAMBE MAL SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2308	.4214	1.0974	1.3717	1.1584	1.3717	1.1584
2	1.2308	.4214	1.0974	1.3032	1.1004	1.3717	1.1584
3	1.1984	.3913	1.0974	1.3032	1.1888	1.3032	1.0974
4	1.3443	.3612	1.0974	1.2346	1.1888	1.3032	1.1279
5	1.166	.3612	1.0974	1.2689	1.1584	1.3032	1.1279
6	1.166	.3763	1.1584	1.2689	1.1584	1.3717	1.2193
7	1.166	.4515	1.2193	1.406	1.2193	1.3717	1.2498
8	1.166	.7526	1.2193	1.5604	1.2193	1.5089	1.2498
9		1.3395	1.5242	1.6632	1.5242	1.6461	1.5242
10		1.3546	1.5242	1.7147	1.5242	1.6461	1.5242
11		1.4449	1.5394	1.7147	1.5242	1.6461	1.4784
12		1.3546	1.1888	1.2003	1.0364	1.3032	1.1279
13		1.2041	.9297	1.2003	1.0974	1.2689	.8688
14		1.2643	1.2651	1.4403	1.2193	1.5775	1.2955
15		1.3245	1.3717	1.5775	1.2193	1.6118	1.3565
16		1.3245	1.387	1.6118	1.2193	1.6118	1.387
17		1.3245	1.2955	1.6461	1.3413	1.6118	1.3413
18		1.3847	1.5242	1.7147	1.4022	1.6118	1.4784
19		1.3847	1.4784	1.7147	1.4632	1.6118	1.4327
20		1.3847	1.3413	1.7147	1.4022	1.4403	1.3717
21		1.3847	1.387	1.7147	1.4022	1.4403	1.3717
22		1.2643	1.3717	1.3717	1.4022	1.4403	1.3717
23		1.2041	1.3108	1.3717	1.4022	1.3717	1.3413
24	1.2955	.4515	1.1584	1.4746	1.2193	1.5089	1.2193
Max	**1.3443**	**1.4449**	**1.5394**	**1.7147**	**1.5242**	**1.6461**	**1.5242**
Min	**1.166**	**.3612**	**.9297**	**1.2003**	**1.0364**	**1.2689**	**.8688**
Avg	**1.2182**	**.9971**	**1.2784**	**1.4818**	**1.2830**	**1.4689**	**1.2866**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI A S/DN.[710] BU 4710
Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S
Feeder No / Name : 202 / UTTAM SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3443	1.0056	1.3169	1.2346	1.2971	1.3717	1.283
2	1.307	.9709	1.3169	1.2346	1.2971	1.3717	1.2483
3	1.307	.9709	1.2437	1.1488	.5609	1.3032	1.2136
4	1.307	.8669	1.2437	1.1317	1.2136	1.3032	1.2136
5	1.3443	.9015	1.2437	1.1317	1.2269	1.3032	1.1789
6	1.3443	.9015	1.3169	1.1317	1.2269	1.3717	1.1789
7	1.3443	1.0056	1.3169	1.3032	1.262	1.3717	1.2136
8	1.3817	1.0923	1.39	1.3375	1.2971	1.4403	1.387
9	1.2071	1.4723	1.6095	1.4403	1.5775	1.5089	1.5604
10	1.1706	1.5257	1.6095	1.5432	1.6126	1.5089	1.5604
11	1.134	1.387	1.5546	1.5432	1.6126	1.5432	1.335
12	1.1157	1.3176	1.3717	1.0974	1.1919		1.2309
13	.9328	1.0402	1.2254	1.0974	1.262	1.166	1.2309
14	.9511	1.1789	1.39	1.166	1.3321	1.406	1.1443
15	.9694	1.3176	1.4449	1.3032	1.262	1.4403	1.283
16	1.0242	1.3176	1.5181	1.3717	1.262	1.406	1.0402
17		1.5257	1.4266	1.406	1.5424	1.4403	1.3535
18		1.595	1.4632	1.4403	1.6827	1.4403	1.39
19		1.595	1.6278	1.406	1.6827	1.4403	1.6461
20		1.5257	1.5912	1.4403	1.6126	1.4403	1.491
21		1.5257	1.4266	1.406	1.5424	1.4403	1.4217
22		1.387	1.4632	1.3717	1.5424	1.3717	1.3176
23		1.3176	1.3413	1.3032	1.4723	1.3032	1.3169
24	1.3817	1.0402	1.39	1.3717	1.3321	1.3717	1.3176
Max	**1.3817**	**1.595**	**1.6278**	**1.5432**	**1.6827**	**1.5432**	**1.6461**
Min	**.9328**	**.8669**	**1.2254**	**1.0974**	**.5609**	**1.166**	**1.0402**
Avg	**1.2098**	**1.241**	**1.4101**	**1.3067**	**1.3710**	**1.3941**	**1.3149**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI A S/DN.[710] BU 4710
Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S
Feeder No / Name : 203 / 11 KV CHANDUR ROAD FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7538	.7316	2.3472	2.572	2.6216	2.6063	2.572
2	2.7161	.7316	2.3472	2.5377	2.556	2.6063	2.5034
3	2.6783	.7316	2.2801	2.4006	2.556	2.6063	2.4006
4	2.5652	.7011	2.2801	2.332	2.5232	2.6063	2.2291
5	2.5652	.7011	2.2801	2.3663	2.4577	2.6063	2.2634
6	2.4897	.7316	2.2801	2.3663	2.3922	2.6063	2.332
7	2.4897	.823	2.2801	2.5377	2.3594	2.6063	2.4006
8	2.5274	1.1126	2.3472	2.6406	2.3922	2.6063	2.5034
9	2.5652	2.4539	2.8166	2.8807	2.8182	2.8807	2.7435
10	1.8861	2.4539	2.8166	2.8807	2.7854	2.8807	2.7435
11	1.8296	2.5606	2.8837	2.8807	2.7854	2.8807	2.8807
12	1.6787	2.4387	2.3137	1.7833	2.0972	2.0576	2.5034
13	.8676	1.829	1.6766	1.7833	2.2939	2.0576	1.7833
14	1.4335	2.4387	2.5819	2.7435	2.4905	2.5034	2.6749
15	1.6598	2.4387	2.7161	2.7435	2.4905	2.7435	2.7778
16	1.5089	2.4387	2.7831	2.7435	2.4905	2.7435	2.8121
17		2.4387	2.7496	2.7435	2.6216	2.7435	2.8464
18		2.4387	2.8837	2.7435	2.6216	2.7435	2.8464
19		2.4387	2.7831	2.7435	2.6216	2.7435	2.8121
20		2.4387	2.7161	2.7435	2.6216	2.6063	2.7092
21		2.4387	2.7999	2.6063	2.6216	2.6063	2.7092
22		2.3167	2.5819	2.6749	2.6216	2.7435	2.692
23		2.2558	2.6322	2.7435	2.4905	2.7435	2.6406
24	2.8292	.7316	2.4813	2.7092	2.6216	2.6063	2.7435
Max	**2.8292**	**2.5606**	**2.8837**	**2.8807**	**2.8182**	**2.8807**	**2.8807**
Min	**.8676**	**.7011**	**1.6766**	**1.7833**	**2.0972**	**2.0576**	**1.7833**
Avg	**2.1791**	**1.7839**	**2.5274**	**2.5792**	**2.5397**	**2.6306**	**2.5885**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI A S/DN.[710] BU 4710
Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S
Feeder No / Name : 204 / WATER WORKS SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3777	.8962	2.2131	2.4006	2.3205	2.4006	2.2672
2	2.3777	.8962	2.2131	2.3663	2.3205	2.4006	2.2348
3	2.3045	.8642	2.2131	2.3148	2.2874	2.4006	2.2024
4	2.3045	.8322	2.2131	2.2291	2.2542	2.4006	2.2024
5	2.3045	.8642	2.2131	2.2634	2.2542	2.4006	2.17
6	2.3045	.8642	2.2131	2.2805	2.2542	2.4006	2.1376
7	2.3045	.9122	2.2131	2.3491	2.3537	2.4006	2.2348
8	2.3045	1.1683	2.2801	2.452	2.3868	2.4691	2.3644
9	2.4272	2.3685	2.5484	2.6406	2.42	2.6063	2.5263
10	1.6804	2.4006	2.5484	2.6578	2.4531	2.6063	2.5263
11	1.5684	2.5606	2.649		2.4531	2.6063	2.4939
12	1.1949	2.2405	1.8275	1.8861	1.7901	1.7147	2.0243
13	1.0082	2.3685	1.7269	1.8861	2.3205	1.7147	1.5546
14	1.2696	2.3685	2.4813		2.4531	2.4348	2.2834
15	1.3443	2.4326	2.5819	2.5034	2.5857	2.4691	2.3482
16		2.4326	2.6155	2.572	2.5857	2.4348	2.332
17		2.4326	2.6322	2.6063	2.5857	2.4691	2.3158
18		2.4326	2.6322	2.6063	2.5857	2.4691	2.3644
19		2.4326	2.5819	2.6063	2.4531	2.4691	2.3805
20		2.3685	2.5316	2.6406	2.3868	2.4348	2.3967
21		2.3685	2.5316	2.572	2.3868	2.4348	2.3482
22		2.3045	2.3975	2.5034	2.3868	2.4691	2.2186
23		2.2405	2.4813	2.4348	2.3045	2.4348	2.2834
24	2.524	.8962	2.3472	2.5034	2.3537	2.4006	2.2996
Max	**2.524**	**2.5606**	**2.649**	**2.6578**	**2.5857**	**2.6063**	**2.5263**
Min	**1.0082**	**.8322**	**1.7269**	**1.8861**	**1.7901**	**1.7147**	**1.5546**
Avg	**1.9750**	**1.8311**	**2.3703**	**2.4216**	**2.3723**	**2.3934**	**2.2712**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI A S/DN.[710] BU 4710
Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S
Feeder No / Name : 205 / DKTE SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9808	.8413	.9412	.8573	.8688	.9602	.9145
2	.9808	.8413	.9412	.7888	.8688	.8916	.9145
3	.9808	.8048	.9412	.7545	.8326	.8916	.8779
4	.9431	.7682	.9412	.7202	.8326	.8916	.8413
5	.9808	.7682	.9412	.7202	.7964	.8916	.8413
6	.9431	.7865	.9412	.7373	.7964	.9602	.9511
7	.9808	.9328	.9412	.8573	.905	1.0288	.9877
8	.9808	.9877	.9412	.9602	1.086	1.0288	1.0242
9	1.0082	1.1706	1.2308	1.1488	1.1222	1.2346	1.2437
10	.9709	1.1706	1.2308	1.2346	1.1222	1.2346	1.2437
11		1.1706	1.1946	1.2346	1.1584	1.2346	.8425
12		1.0974	1.1946	1.0288	1.086	1.0631	1.3169
13		.9511	.9412		.9412	1.0631	1.0608
14		1.0242	.8688	1.0288	.8688	1.0631	1.0059
15		1.0974	.9593	.8573	.8688	1.0631	1.1157
16		1.0974	1.0974	.8916	.8688	1.0631	.8596
17		1.2437	1.1041	.9602	1.1584	1.0631	1.2437
18		1.39	1.1157	.9602	1.2308	1.0631	1.1706
19		1.39	1.3394	.9259	1.3756	1.0631	1.4266
20		1.2437	1.1946	.9602	1.2308	1.0631	1.3169
21		1.1706	1.1946	.9602	1.2308	1.0631	1.1888
22		1.0974	1.0498	1.0288	1.2308	1.0288	1.134
23		1.0242	.9412	.7888	1.1584	.8916	1.0059
24	1.0185	.8779	.9412	.8573	.8326	1.0288	.9511
Max	**1.0185**	**1.39**	**1.3394**	**1.2346**	**1.3756**	**1.2346**	**1.4266**
Min	**.9431**	**.7682**	**.8688**	**.7202**	**.7964**	**.8916**	**.8413**
Avg	**.9790**	**1.0395**	**1.0470**	**.9244**	**1.0196**	**1.0345**	**1.0616**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI A S/DN.[710] BU 4710
Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S
Feeder No / Name : 206 / GAON BHAG SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.884	.4778	.7926	.8573	.7956	1.0288	.8535
2	.8535	.4778	.7926	.823	.7956	.9602	.823
3	.8535	.4489	.7926	.823	.7682	.9602	.823
4	.823	.4344	.7926	.7545	.7682	.8916	.823
5	.823	.4633	.7926	.7545	.7407	.8916	.7926
6	.823	.4633	.8535	.7888	.7407	.9602	.7621
7	.7621	.6371	.8535	.9431	.823	.9602	.8535
8	.7621	.6805	.8535	1.1145	.823	1.0288	.884
9		1.0425	.9755	1.3375	.9328	1.3032	1.0974
10		1.0715	.9755	1.3717	.9328	1.3032	1.0974
11		1.0425	1.0669	1.3717	.9328	1.3032	1.0517
12		.9846	.9297	1.166	.9877	1.2689	1.0974
13		.695	.7621	1.166	.823	1.2346	.8078
14		.695	.7468	.9602	.6584	.9602	.7926
15		.9267	.8993	1.0288	.8779	.9602	.8535
16		.9267	.9602	1.0288	.8779		1.0212
17		.9846	.945	1.0631	.9877	1.0288	.9755
18		1.0837	.9907	1.0631	.9877	1.0288	1.0364
19		1.0425	1.1584	1.0631	.9328	1.0288	1.1584
20		1.0425	1.1279	1.0631	.9328	1.0974	1.1279
21		1.0425	1.1126	1.0631	.9328	1.0974	1.0669
22		.8688	.884	1.0974	.9328	1.0631	.9755
23			.884	1.0288	.8779	1.0288	.9145
24	.9145	.4778	.8535	.9945	.823	1.0288	.9145
Max	**.9145**	**1.0837**	**1.1584**	**1.3717**	**.9877**	**1.3032**	**1.1584**
Min	**.7621**	**.4344**	**.7468**	**.7545**	**.6584**	**.8916**	**.7621**
Avg	**.8332**	**.7830**	**.9082**	**1.0302**	**.8619**	**1.0616**	**.9418**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI A S/DN.[710] BU 4710
Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S
Feeder No / Name : 207 / 11 KV Ramnagar SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.1741	2.4451	3.1855	3.0864	2.6612	3.155	3.0769
2	3.1367	2.3743	3.1855	3.0178	2.6612	3.155	3.0769
3	3.062	2.4097	3.1855	2.8464	2.6242	3.155	2.9321
4	3.0247	2.3034	3.1855	2.8464	2.6242	3.155	3.0045
5	2.9874	2.3034	3.1855	2.8121	2.6242	3.155	3.0045
6	3.0247	2.3565	3.1855	2.8121	2.5873	3.155	3.0769
7	2.9874	2.4274	3.1855	2.915	2.7351	3.155	3.1855
8	2.8704	2.5337	3.3303	2.8807	2.7721	3.155	3.1855
9		3.3665	3.7647	2.6578	3.5113	3.4294	3.6199
10		3.4728	3.7647	2.7092	3.5852	3.4294	3.6199
11		3.6854	3.7647	2.7092	3.5852	3.4294	3.6561
12		3.5437	2.9683	1.3717	2.5133	2.7435	3.0226
13		3.2602	2.7149	1.3717	2.7351	2.7435	2.6063
14		3.5437	3.276	1.8176	3.5482	3.4294	3.3303
15		3.5437	3.638	1.989	3.6961	3.4637	3.6742
16		3.5437	3.6199	2.0576	3.6961	3.4294	3.6199
17		3.5437	3.6742	2.0576	3.5482	3.4294	3.5475
18		3.5437	3.6561	1.7147	3.5482	3.4294	3.457
19		3.5437	3.6018	1.6461	3.5482	3.4294	3.6031
20		3.2602	3.457	1.7147	3.4004	3.4294	3.4751
21		3.2602	3.3846	2.5034	3.4004	3.4294	3.4751
22		3.4019	3.3122	2.5034	3.4004	2.915	3.3836
23		3.2602	3.3303	2.5034	3.4004	3.1207	3.3653
24	3.2114	2.4806	3.3303	3.1893	2.6981	3.155	3.2941
Max	**3.2114**	**3.6854**	**3.7647**	**3.1893**	**3.6961**	**3.4637**	**3.6742**
Min	**2.8704**	**2.3034**	**2.7149**	**1.3717**	**2.5133**	**2.7435**	**2.6063**
Avg	**3.0532**	**3.0586**	**3.3703**	**2.4056**	**3.1293**	**3.2365**	**3.3039**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI A S/DN.[710] BU 4710
Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S
Feeder No / Name : 208 / 11 KV KRISHI GANGA SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2012	.2012	.1372	.128		
2	.218	.2012	.1372	.1341		
3	.208	.2012	.1372	.1677		
4	.2347	.2012	.1372	.1677		
5	.2347	.2012	.1372	.1677		
6	.2347	.2012	.1372	.1677		
7	.2347	.2012	.1372	.1677		
8				.1677	.4115	.3353
9				.2683	.4115	.3688
10				.3353	.4115	.4024
11				.3353	.4115	.4024
12				.4024	.4458	.3856
13				.4024	.4458	.3048
14				.4024	.4458	.3353
15				.4024	.4458	.3353
22	.192	.1341	.1372			
23	.192	.1341	.1372			
24	.192	.2012	.1372	.1341		
Max	**.2347**	**.2012**	**.1372**	**.4024**	**.4458**	**.4024**
Min	**.192**	**.1341**	**.1372**	**.128**	**.4115**	**.3048**
Avg	**.2142**	**.1878**	**.1372**	**.2469**	**.4287**	**.3587**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI A S/DN.[710] BU 4710
Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S
Feeder No / Name : 209 / JACKWELL NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0373	.1886	.1715	.0747	.1715	.0754
2	.0754	.0373	.1886	.1715	.0747	.1715	.0754
3	.0754	.0373	.1886	.1715	.0747	.1715	.0754
4	.0754	.0362	.1886	.1715	.0747	.1715	.0754
5	.0754	.1494	.1886	.1715	.0747	.1715	.1886
6	.0754	.1867	.1886	.1715	.1867	.1715	.1886
7	.1886	.1867	.1886	.1715	.1867	.1715	.1886
8	.1886	.1867	.1886	.1715	.1867	.1715	.1886
9	.1886	.181	.1886	.1715	.1867	.1715	.1886
10	.1886	.1867	.1886	.1715	.1867	.1715	.1886
11	.1886	.1867	.2075	.1715	.1867	.1715	.1886
12	.1886	.1867	.1886	.1715	.1867	.1715	.1886
13	.1886	.1867	.1886	.1715	.1848	.1715	.1886
14	.1886	.1867	.1886	.1715	.1867	.1715	.1886
15	.1886	.1867	.1886	.1715	.1867	.1715	.1886
16	.1886	.1867	.181	.1715	.1867	.1715	.1886
17		.1867	.1886	.1715	.1867	.1715	.1886
18		.1867	.1886	.1715	.1867	.1715	.1886
19		.1867	.1886	.1715	.1867	.1715	.1886
20		.1867	.1886	.1715	.1867	.1715	.1886
21		.1867	.1886	.0686	.1867	.1715	.0377
22		.1867	.1886	.0686	.1867	.1715	.0377
23		.1867	.1886	.0686	.1867	.1715	.0377
24	.1886	.1867	.1886	.1715	.0747	.1715	.1886
Max	**.1886**	**.1867**	**.2075**	**.1715**	**.1867**	**.1715**	**.1886**
Min	**.0754**	**.0362**	**.181**	**.0686**	**.0747**	**.1715**	**.0377**
Avg	**.1486**	**.1600**	**.1891**	**.1586**	**.1586**	**.1715**	**.1509**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI A S/DN.[710] BU 4710
Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S
Feeder No / Name : 211 / naikmala SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4006	1.3748	2.3472	2.4006	2.079	2.4006	2.3472
2	2.3663	1.3748	2.3137	2.3663	2.0454	2.4006	2.2801
3	2.332	1.3748	2.3137	2.332	2.0454	2.4006	2.2801
4	2.332	1.3413	2.1795	2.1948	2.1125	2.4006	2.2466
5	2.332	1.3413	2.2131	2.2291	2.1125	2.4348	2.2466
6	2.332	1.3413	2.2801	2.2634	2.1125	2.5206	2.2131
7	2.4348	1.4586	2.2801	2.4177	1.8778	2.4863	2.4143
8	2.4348	2.3137	2.3472	2.4691	1.8778	2.4863	
9		2.649	2.6993	2.452	2.6825	2.7435	2.5819
10		2.6825	2.6993	2.3663	2.6825	2.7435	2.5819
11		2.7664	2.7999	2.4691	2.6825	2.7435	2.7664
12		2.3472	2.3807	1.6461	1.576	1.6975	2.6658
13		2.3472	1.9784	1.6461	1.6766	1.6975	1.8107
14		2.7496	2.3137	2.2291	2.3472	2.4006	2.5149
15		2.6825	2.649	2.1605	2.5484	2.4691	2.7831
16		2.6155	2.7161	2.1262	2.6322	2.5034	2.6658
17		2.6825	2.7664	2.1605	2.5484	2.5034	2.7664
18		2.6825	2.8502	2.1605	2.5484	2.5034	2.7999
19		2.6825	2.8166	2.1262	2.5484	2.4691	2.6322
20		2.5484	2.7664	2.1262	2.5819	2.4691	2.6825
21		2.5819	2.7328	2.1605	2.5819	2.4691	2.7161
22		2.5149	2.6993	2.1262	2.5484	2.5034	2.332
23		2.3472	2.5819	2.1262	2.4813	2.5034	2.5819
24	2.4348	1.3748	2.3472	2.6235	2.079	2.5034	2.4478
Max	**2.4348**	**2.7664**	**2.8502**	**2.6235**	**2.6825**	**2.7435**	**2.7999**
Min	**2.332**	**1.3413**	**1.9784**	**1.6461**	**1.576**	**1.6975**	**1.8107**
Avg	**2.3777**	**2.1740**	**2.5030**	**2.2241**	**2.2920**	**2.4356**	**2.4938**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI A S/DN.[710] BU 4710
Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S
Feeder No / Name : 212 / MAHADEV NAGAR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.1174	.3353	.3601	.3353	.3429	.3018
2	.2915	.1174	.3353	.3601	.3018	.3429	.3018
3	.2915	1.4586	.3353	.3429	.3018	.3429	.3018
4	.2743	.1174	.3353	.2915	.3018	.3258	.3018
5	.2743	.1174	.3353	.3086	.3018	.3086	.3018
6	.2743	.1174	.3353	.3258	.3018	.3429	.3018
7	.2915	.1509	.3688	.3258	.3521	.3601	.3521
8	.3086	.3018	.3688	.4115	.3688	.4115	.3688
9		.4024	.3856		.4024	.4115	.4359
10		.4191	.3856	.4287	.4024	.463	.4359
11		.3688	.4024	.4287	.4024	.463	.4024
12		.3521	.3521	.3429	.3185	.4115	.3688
13		.3353	.3185	.3429	.3353	.3772	.2347
14		.3185	.3521	.4115	.3688	.4115	.3185
15		.3521	.3856	.3772	.3856	.4115	.3856
16		.3521	.4024	.3601	.3688	.4115	.4024
17		.3688	.4024	.4115	.3856	.4115	.4024
18		.3688	.4024	.4115	.3856	.3429	.4024
19		.3688		.4115	.3856	.3429	.3688
20		.3856	.3856	.4115	.3521	.3429	.3688
21		.3856	.3688	.4115	.3521	.3429	.3688
22		.3521	.3856	.4115	.3521	.3429	.3521
23		.3353	.3856	.3772	.3521	.3429	.3521
24	.3429	.1174	.3353	.3772	.3688	.3429	.3353
Max	**.3429**	**1.4586**	**.4024**	**.4287**	**.4024**	**.463**	**.4359**
Min	**.2743**	**.1174**	**.3185**	**.2915**	**.3018**	**.3086**	**.2347**
Avg	**.2953**	**.3367**	**.3652**	**.3757**	**.3535**	**.3729**	**.3528**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI A S/DN.[710] BU 4710
Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S
Feeder No / Name : 704 / 33 KV Main VCB TILAWANI SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 33 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	15.3121	8.6763	14.7691	13.3745	14.1976	15.4321	15.6379
2	15.2035	8.6237	14.6605	13.1173	13.6717	15.4321	15.3635
3	14.9863	8.4134	13.5746	12.8601	13.6717	13.8889	15.3635
4	14.6605	8.3082	13.5746	12.6029	13.7769	13.3745	14.8148
5	14.6605	8.5185	13.9003	13.1687	13.6717	13.8889	15.1441
6	14.6605	8.6763	14.1175	13.6317	13.7769	14.4033	14.8148
7	14.6605	9.4125	15.3664	14.6605	14.776	15.4321	15.9122
8	14.7148	10.727	15.7465	15.072	15.3544	15.9465	16.4609
9	14.389	16.9319	18.2985	16.2037	17.1948	17.5926	18.8203
10	13.5746	17.4577	18.027	13.2202	19.5611	17.6955	18.6557
11	12.0542	17.4577	18.5157	12.8601	19.5611	18.0041	18.3814
12	10.3167	17.3526	14.2261	11.1111	12.7778	13.6831	14.8777
13	9.1221	14.7234	13.2488	11.1111	14.1976	14.5062	13.2488
14	11.0768	15.5121	16.1266	10.8025	15.7751	16.9753	16.3438
15	11.6741	16.3009	17.1582	13.6831	16.4586	16.9753	17.4297
16	10.0452	16.3535	17.3211	13.9403	16.4586	16.8725	17.1582
17		16.8267	17.1039	14.4033	16.8267	16.7181	17.0496
18		17.0896	17.9727	14.5062	17.3526	16.7181	17.3211
19		17.0896	18.027	14.4033	17.6155	16.7696	17.8641
20		17.0896	17.484	14.4033	16.5638	16.5124	17.1039
21		16.6164	17.2125	14.9177	16.5638	16.5638	17.1582
22		15.407	16.7238	14.3004	15.7751	15.6379	16.2352
23		15.2492	16.3981	13.9918	15.7751	15.1749	15.9094
24	15.5293	8.7289	15.6379	13.5803	14.1976	15.4321	16.1866
Max	**15.5293**	**17.4577**	**18.5157**	**16.2037**	**19.5611**	**18.0041**	**18.8203**
Min	**9.1221**	**8.3082**	**13.2488**	**10.8025**	**12.7778**	**13.3745**	**13.2488**
Avg	**13.3318**	**13.6476**	**16.0496**	**13.5803**	**15.6480**	**15.8179**	**16.3856**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI B S/DN.[711] BU 4711
Substation No/ Name :- 144049 / 33/11 KV B S/S
Feeder No / Name : 202 / IND EST FEEDER SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	1.4998	1.7833	1.6827	1.134	1.7833	1.7528
2	1.7337	1.4632	1.7147	1.6126	1.0974	1.6956	1.6827
3	1.6461	1.4415	1.5089	1.5592	1.1088	1.6278	1.6827
4	1.5089	1.4415	1.4243	1.5384	1.1088	1.6461	1.5947
5	1.4403	1.4784	1.5089	1.5384	1.0985	1.4403	1.5947
6	1.5089	1.4632	1.4419	1.5384	1.134	1.4922	1.6476
7	1.6461	1.5364	1.4419	1.5384	1.3169	1.6461	1.7528
8		1.6632	1.7833	1.1765	1.3676	1.6461	1.7528
9	2.1948	2.2634	2.1948	1.086	2.1948	2.332	2.3472
10	2.1948	2.5095	2.332	1.0349		2.4691	2.4143
11	2.4272	2.4143	2.431	1.1827	2.332	2.6063	2.431
12	2.1498	1.4815	2.3148		2.332	2.2291	2.2291
13	1.8427	1.7833	1.8861	.4877	1.7833	1.9418	1.9719
14	1.9845	1.9204	2.1434	.5898	2.1948	2.0576	2.2634
15	2.2977	2.1948	2.2634	.6859	2.332	2.2291	2.3472
16	2.3838	2.332	2.2634	.7316	2.332	2.2801	2.3975
17	2.0805	2.1948	2.1548	.7023	2.332	2.2131	2.431
18	1.949	2.332	2.2131	.5959	2.332	2.2801	2.431
19	1.701	1.9204		.5895	2.1948	2.13	2.2634
20			1.8404	.7682	1.7833	1.7436	1.9418
21	1.701	1.9204	1.8004	1.0498	1.8823	1.7833	1.9418
22	1.6655	1.8861	1.8347	1.3169	1.7833	1.8861	1.9631
23	1.5947	1.7833	1.8755	1.2803	1.9204	1.8176	1.9281
24	1.7833	1.5203	1.7833	1.7528	1.1706	1.7833	1.7833
Max	**2.4272**	**2.5095**	**2.431**	**1.7528**	**2.332**	**2.6063**	**2.431**
Min	**1.4403**	**1.4415**	**1.4243**	**.4877**	**1.0974**	**1.4403**	**1.5947**
Avg	**1.8704**	**1.8454**	**1.9104**	**1.1321**	**1.7507**	**1.9483**	**2.0227**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI B S/DN.[711] BU 4711
Substation No/ Name :- 144049 / 33/11 KV B S/S
Feeder No / Name : 204 / YASHWANT FEEDER SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1719	2.0119	2.3152	2.1253	.7316	1.1203	1.0974
2	2.1948	2.0698	1.8519	2.1253	.7316	1.0562	1.0719
3	2.1437	1.9589	2.1948	1.9909	.7023	.9511	1.0829
4	2.1658	1.922	1.9753	1.9004	.7023	.9511	1.0456
5	2.2634	2.0328	1.9753	1.9004		1.0349	1.0456
6	2.2634	1.9753	2.2916	1.9004	.724	1.0456	1.1203
7	2.3899	1.9022	2.3411	1.9004	.7316	1.0456	1.1203
8		2.268	2.3411	1.448	1.922	1.1706	1.1203
9	2.4143	2.4874	2.3411	1.086	2.0271	1.2437	1.1706
10	2.5606	2.5339	2.7801	1.0164		1.3443	1.3169
11	2.9264	2.8829	2.6242		1.3756	1.3535	1.2574
12	2.8166	2.838	2.6244		1.419	1.2803	1.1765
13	2.4874	2.4897	2.2624		1.358	1.2071	1.086
14	2.6337	2.6139	2.4949	.362	1.2742	1.3443	1.1765
15	2.4977	2.7351	2.8054	.362	1.3756	1.3169	1.3032
16	2.5339	2.7161	2.7149	.4298	1.2887	1.39	1.2308
17	2.8349	2.4646	2.8349	.4298	1.419	1.2803	1.267
18	2.5606	2.838	2.6797	.4161	1.2346	1.39	1.267
19	2.4874	2.7915	2.5873	.4298	.9831	1.3535	1.2308
20		2.7633	2.3101	.5792	.5281	1.2803	1.086
21	2.1948		2.3529	.6379	1.1706	1.2437	1.1584
22	2.268	2.1691	2.4977	.7316	1.2437	1.2071	1.1458
23	2.3655	2.2405	2.4025	.0739	1.0562	1.0974	1.1458
24	2.1262	2.0698	2.3388	2.3101	.7392	1.1827	1.0974
Max	**2.9264**	**2.8829**	**2.8349**	**2.3101**	**2.0271**	**1.39**	**1.3169**
Min	**2.1262**	**1.9022**	**1.8519**	**.0739**	**.5281**	**.9511**	**1.0456**
Avg	**2.4228**	**2.3815**	**2.4141**	**1.1503**	**1.1245**	**1.2038**	**1.1592**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI B S/DN.[711] BU 4711
Substation No/ Name :- 144049 / 33/11 KV B S/S
Feeder No / Name : 205 / IGM FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3413	.3887	1.2163	1.186	1.1797	1.2163	1.2955
2	1.1728		1.1523	1.1385	1.1797	1.1203	1.2308
3	1.1797	.3932	1.1523	1.1203	1.1469	1.1142	1.166
4	1.1797	.3932	1.0364	1.1203	1.1469	1.0494	1.1336
5	1.0364	.421	1.2308	1.1683	1.166	1.1111	1.1336
6	.9998	.4534		1.2483	1.166	1.1797	1.166
7	1.1248	.5506	1.4632	1.2803	1.1984	1.2803	1.2803
8		.8097	1.4083	1.4232	1.2955	1.4083	1.3603
9	1.358	1.6644	1.7284	1.6667	1.8138	1.7284	1.6964
10	1.2803	1.1437	1.7284	1.6766		1.8351	1.6461
11	1.166	1.6049	1.7284	1.749	1.6644	1.6461	1.6004
12	.9831	1.5364	1.4232	1.6194	1.6049	1.5242	1.3441
13	.5243	1.0242	1.2334	1.1012	1.0242	1.1561	1.2651
14	.9069	1.4083	1.3441	1.4575	1.5364	1.4022	1.4548
15	1.004	1.4815	1.4815	1.5546	1.5364	1.5242	1.5432
16	1.0814	1.6644	1.5242	1.6194	1.6644	1.5851	1.5432
17	.9069	1.6049	1.5851	1.6842	1.5364	1.5242	1.5242
18	.7449	1.6644	1.7071	1.6842	1.6644	1.5851	1.6461
19	.6478	1.6248	1.7394	1.7695	1.6644	1.6156	1.6667
20		1.6644	1.4232	1.5546	1.5364	1.4632	1.4998
21	.5182		1.4232	1.5402	1.4251	1.4327	1.4842
22	.4858	1.4083	1.4232	1.4746	1.4083	1.3717	1.4548
23	.4588	1.358	1.3279	1.3763	1.3413	1.2803	1.3441
24	1.2803	.3887	1.2803	1.186	1.2125	1.2803	1.3603
Max	**1.358**	**1.6644**	**1.7394**	**1.7695**	**1.8138**	**1.8351**	**1.6964**
Min	**.4588**	**.3887**	**1.0364**	**1.1012**	**1.0242**	**1.0494**	**1.1336**
Avg	**.9719**	**1.1205**	**1.4244**	**1.4333**	**1.3962**	**1.3931**	**1.4100**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI B S/DN.[711] BU 4711
Substation No/ Name :- 144049 / 33/11 KV B S/S
Feeder No / Name : 206 / 11 K.V BHAJI MARKET SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8779	.7087	.8413	.8507	.8779	.9877	.9774
2	.8215	.7316	.78	.7964	.8413		.9774
3	.7842	.695	.7209	.7964	.823	.8871	.9412
4	.9335	.695	.8413	.8145	.7373	.8779	.9412
5	.9877	.7964	1.0608	.8869	.7449	.9511	.9412
6	1.0608	.8145	1.0608	.9391	.7611	.9877	1.0136
7	.9511	.7865	1.0791	1.0498	.8869	1.0974	
8		1.0425	1.1888	1.0808	1.134	1.0242	1.086
9	.7682	1.1222	1.3443	1.1222	1.1403	1.2071	1.1946
10	.7865	1.1584		1.1163		1.2437	1.3394
11	.7421	1.2127	1.258	1.086	1.2254	1.182	1.2226
12	.6516	1.2437	1.0985	1.0317	1.1888	1.182	1.2308
13	.5487		.905	.8688	.8962	.9774	1.1403
14	.6036	1.1706	1.0498	1.0974	1.134	1.1104	1.134
15	.5973	1.1888	1.0454	1.0608	1.1157	1.182	1.0985
16	.6036	1.134	1.134	1.0498	1.1706	1.1104	1.0985
17	.6516	1.0974	1.0985	1.0679	1.2437	1.0745	1.1517
18	.6697	1.2071	1.0985	1.134	1.2071	1.3032	1.1871
19	.6584	1.2803	1.1517	1.1946	1.2437	1.2894	1.1871
20		1.2803	1.086	1.0791	1.1706	1.1104	1.086
21	.7682	1.1157	1.1222	1.0317	1.0425	1.1104	1.134
22	.7421	1.0791	1.0099	1.0059	1.0425	1.0745	1.086
23	.7499	1.0059	.9745	.9511	.8684	1.0029	.9593
24	.9145	.7316	.8596	.8869	.9145	1.0059	1.0136
Max	**1.0608**	**1.2803**	**1.3443**	**1.1946**	**1.2437**	**1.3032**	**1.3394**
Min	**.5487**	**.695**	**.7209**	**.7964**	**.7373**	**.8779**	**.9412**
Avg	**.7669**	**1.0130**	**1.0352**	**1**	**1.0178**	**1.0861**	**1.0931**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI B S/DN.[711] BU 4711
Substation No/ Name :- 144049 / 33/11 KV B S/S
Feeder No / Name : 207 / 11 KV BALAJI SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9892	.3601	.8684	.8097	1.0059	.8642	.9717
2	.9602	.3467	.8192	.7611	.9724	.8848	.9393
3	.9362	.3467	.8288	.7287	.9175	.8192	.9503
4	.8573	.3467	.8619	.7287	.9069	.8718	.9175
5	.8718	.4115	.8619	.7935	.9069	.8951	.9175
6	.9054	.4917	.9116	.8421	.9393	.9389	.9503
7	.9667	.5256	.9448	.8745	1.0111	.9105	.9717
8		.7042	1.0486	.9122	1.0059	.9892	.9717
9	.7545	1.1142	1.0395	1.1043	1.1736	1.1633	1.1203
10	.7522	1.1437	1.1797	1.1043		1.065	1.1248
11	.779	1.1822	1.1683	1.2239	1.0322	1.1523	1.1843
12	.663	1.1401	.9282	1.004	.9892	1.0242	.9231
13	.4862	.823	.8421	.8048	.6722	.8421	.8907
14	.5365	1.073	.9717	.9831	.8642	1.0562	.9762
15	.5365	1.1797	1.1203	1.1437	.9831	1.1336	1.1523
16	.5533	1.1043	1.0562	1.1271	.9892	1.1203	1.1363
17	.503	1.2003	1.1203	1.1603	.9995	1.1523	1.1363
18	.4024	1.1633	1.1498	1.1437	.9602	1.1203	1.1203
19	.3601	1.2209	.9922	1.1401	.9667	1.0562	1.0562
20		1.1797	1.004	1.0562	.9175	.9922	.9878
21	.3772	1.065	.9878	1.0395	1.0402	.9922	1.0364
22	.3772	1.1523	1.0202	1.046	1.065	.9922	1.0202
23	.3772	1.0562	1.004	1.0682	1.0322	.9922	1.0364
24	.9892	.3601	.8987	.8259	1.0343	.9175	1.004
Max	**.9892**	**1.2209**	**1.1797**	**1.2239**	**1.1736**	**1.1633**	**1.1843**
Min	**.3601**	**.3467**	**.8192**	**.7287**	**.6722**	**.8192**	**.8907**
Avg	**.6788**	**.8621**	**.9845**	**.9761**	**.9733**	**.9977**	**1.0207**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI B S/DN.[711] BU 4711
Substation No/ Name :- 144049 / 33/11 KV B S/S
Feeder No / Name : 208 / 11 KV JIVESHWAR SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4243	1.1744	1.3077	1.0974	1.0974	1.5775	1.6095
2	1.3108	1.1568	1.2266	1.2346	1.0498	1.4746	1.6118
3	1.3108	1.1218	1.1869	1.0288	1.0136	1.4419	1.6118
4	1.1797	1.0517	1.1012	.9945	.985	1.3763	1.5432
5	1.1469	.9362	1.0814	1.0631	1.0029	1.326	1.5775
6	1.2266	.8328	1.1271	1.0288	1.0387	1.4083	1.5775
7	1.1797	.9816	1.2437	1.0288	1.0517	1.2803	.1372
8		1.0517	1.278	.7545	1.0867	.9835	1.3717
9	1.7772	.1696	1.3927	.9114	1.5939	1.1469	1.8442
10	1.5089	1.7101	1.704	.8413		1.1469	1.8778
11	1.6956	1.8778	1.7772	.8764	1.5074	1.9113	1.7436
12	1.6297	1.7695	1.6461	.7442	1.7147	1.7436	1.7147
13	1.5074	1.5424	1.3717	.4607	1.3435	1.6118	1.6118
14	1.6301	1.5729	1.5089	.6024	1.576	1.4746	1.7101
15	1.5424	1.704	1.576	.6733	1.7368	1.7772	1.8107
16	1.5775	1.7974	1.6095	.7442	1.8107	1.8778	1.7436
17	1.6124	1.2452	1.6095		1.7436	1.8442	1.6095
18	1.3717	1.5089	1.3748	.8413	1.5939	1.5775	1.6095
19	.8764	1.8107	1.0608		1.4746	1.5424	1.576
20		1.6385	1.2003	.905	1.3763	1.4403	1.4746
21		1.2346	1.166	1.0498	1.3108	1.4746	1.6118
22	1.1694	1.3904	1.2346	1.1517	1.5912	1.7147	1.6461
23	1.1871	1.2597	1.4083	1.0985	1.643	1.7101	1.7147
24	1.4746	1.1517	1.3748	1.166	1.0631	1.6095	1.6766
Max	**1.7772**	**1.8778**	**1.7772**	**1.2346**	**1.8107**	**1.9113**	**1.8778**
Min	**.8764**	**.1696**	**1.0608**	**.4607**	**.985**	**.9835**	**.1372**
Avg	**1.3971**	**1.3204**	**1.3570**	**.9226**	**1.3654**	**1.5197**	**1.5840**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI B S/DN.[711] BU 4711
Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S
Feeder No / Name : 201 / 11 KV JANTA TEX. SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.5113	3.5482	3.5837	3.3951	3.2341	3.4894	3.3951
2	3.5113	3.5482	3.6025	3.3951	3.2341	3.3484	3.3951
3	3.5482	3.5113	3.5837	3.3951	3.1417	3.3484	3.3951
4	3.4189	3.3265	3.4894	3.3951	3.1417	3.3303	3.3951
5	3.4189	3.3265	3.4894	3.3951	3.1417	3.4541	3.3951
6	3.5113	3.4374	3.6025	3.5837	3.2341	3.4541	3.4894
7	3.6961	3.4004	3.5837	3.5837	3.2341	3.4541	3.5837
8	3.6961	3.4189	3.4894	3.3951	3.2341	3.4541	3.5837
9	3.7515	3.4558	3.5837	3.0178	3.1417	3.3484	3.5837
10	3.733	3.5113	3.6403	3.0178	3.4328	3.4541	3.5837
11	3.7342	3.5837	3.3951	3.0178	3.4894	3.4894	3.5837
12	3.7342	3.5837	3.4894	3.0178	3.4894	3.3951	3.678
13	3.7342	3.4894	3.5837	3.1121	3.4894	3.1674	3.5837
14	3.7342	3.4894	3.4894	3.1121	3.4894	3.3951	3.5837
15	3.7342	3.5113	3.5837	3.1121	3.4894	3.5837	3.5837
16	3.7342	3.5482	3.5837	3.3008	3.5082	3.4389	3.5837
17	3.7723	3.6214	3.5837	3.2065	3.4894	3.5475	3.5837
18	3.7723	3.5837	3.4894	3.3951	3.4894	3.4389	3.5837
19	3.5837	3.5837	3.3951	3.3008	3.3951	3.4541	3.5837
20	3.3951	3.6214	2.834	3.3008	3.4894	3.4894	3.5837
21	3.4894	3.5837	3.4894	3.3008	3.4894		3.5837
22	3.546	3.5837	3.4894	3.3008	3.546	3.4894	3.5837
23		3.5837	3.3484	3.3008		3.4894	3.5837
24	3.5648	3.6403	3.5837	3.3951	3.3265	3.4705	3.3951
Max	**3.7723**	**3.6403**	**3.6403**	**3.5837**	**3.546**	**3.5837**	**3.678**
Min	**3.3951**	**3.3265**	**2.834**	**3.0178**	**3.1417**	**3.1674**	**3.3951**
Avg	**3.6228**	**3.5205**	**3.4994**	**3.2811**	**3.3631**	**3.4341**	**3.5366**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI B S/DN.[711] BU 4711
Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S
Feeder No / Name : 202 / 11 KV DECCAN PROCESS SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0493	3.1047		3.2065	3.1417	3.131	3.2065
2	3.0493	3.0862	3.1367	3.2065	3.1417	3.1499	3.2065
3	2.9938	3.0493	3.0807	3.2065	3.1417	3.1121	3.2065
4	2.9569	2.9569	2.9874	3.2065	3.2341	3.131	3.2065
5	2.9569	2.9569	2.9874	3.2065	3.1417	3.1499	3.2065
6	3.0678	3.0493	3.062	3.2065	3.0493	3.1121	3.2065
7	3.1417	3.1232	3.1367	3.2065	2.9569	3.131	3.2007
8	3.1786	3.1786	3.1741	2.8292	2.9569	3.1687	3.3951
9	3.271	3.2895		2.0748	3.0493	3.2065	
10	3.2526	3.308	3.2253	1.8861	3.3951	3.3008	3.3951
11	3.2341	3.3196	3.3008	1.8861	3.4705	3.3951	3.3951
12	3.2341	3.0178	3.3008	1.6975	3.3196	3.3951	3.4894
13	3.2341	3.131	3.3008	1.6975	3.3196	3.0178	3.5837
14	3.2341	3.1687	3.3008	1.8861	3.3008	3.2065	3.5837
15	3.2341	3.2442	3.3008	1.6975	3.3196	3.3951	3.4894
16	3.2341	3.3008	3.3008	1.8861	3.3196	3.3951	3.3951
17	3.1741	3.2114	3.3008	2.2634	3.3008	3.3951	3.3951
18	3.0807	3.2114	3.2065	2.2634	3.2065	3.3951	3.5837
19	3.1741	3.1927	3.2065	2.6406	2.9424	3.3008	3.5113
20	3.1741	3.1741	3.1121	3.0178	3.1687	3.2065	3.5113
21	3.1741	3.0994	3.2065	3.0178	3.2065	3.3008	3.5113
22	3.0994	3.1741	3.3008	3.0178	3.2065	3.3008	3.5113
23		3.1741	3.3008	3.2065		3.3008	3.6037
24	3.0994	3.1181	3.1927	3.2065	3.1417	3.1687	3.2065
Max	**3.271**	**3.3196**	**3.3008**	**3.2065**	**3.4705**	**3.3951**	**3.6037**
Min	**2.9569**	**2.9569**	**2.9874**	**1.6975**	**2.9424**	**3.0178**	**3.2007**
Avg	**3.1434**	**3.1517**	**3.2010**	**2.6092**	**3.1927**	**3.2403**	**3.3913**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI B S/DN.[711] BU 4711
Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S
Feeder No / Name : 203 / 11 KV ICH METALLOY SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0538	1.8671	1.9418	1.9805	1.8671	1.8296	2.0748
2	2.0538	1.8671	1.9418	1.9805	1.8671	1.8107	2.0748
3	2.0165	1.8298	1.9418		1.7737	1.8296	1.9805
4	1.9605	1.7737	1.8671	1.8861	1.6804	1.8107	1.9805
5	1.9605	1.7737	1.8671	1.8861	1.7737	1.8296	1.8861
6	1.9791	1.8298	1.9418	1.8861	1.7737	1.8107	1.8861
7	1.9791	1.8298	1.9418	1.8861	1.7737	1.8484	1.8861
8	2.0538	1.9605	1.9418	1.6975	1.8671	2.037	1.8861
9	2.0725	2.0911	2.0748	1.226	1.8671	2.0748	1.9805
10	2.0725	2.1098	2.1313	1.3203	2.037	2.0748	1.8861
11	2.0538	2.1691	2.0748	1.3203	2.037	2.0748	1.9805
12	1.9605	2.1313	2.0748	1.3203	1.9805	1.9805	2.0748
13	2.0538	2.1691	2.0936	1.3203	1.9805	1.8861	2.0748
14	1.9605	2.1879	2.0748	1.3203	1.8861	2.0748	2.1691
15	2.0538	2.1691	2.1691	1.3203	2.0748	2.1691	2.2257
16	2.0538	2.1879	2.0748	1.5089	2.0748	2.1691	2.1691
17	1.8671	2.1472	2.0748	1.5089	2.037	2.1691	2.0748
18	1.6804			1.6975	2.037	2.1691	2.1691
19	1.8671	2.0165	1.9805	1.6975	1.8861	2.0748	2.1472
20	1.8484	2.0165	1.9805	1.6975	1.8484	2.0748	2.1472
21	1.8858	1.9605	1.9805	1.6975	1.8484	2.0748	2.0538
22	1.8858	1.9605		1.6975	1.8296	2.0748	2.0538
23		1.9605		1.8861		2.0748	2.0538
24	2.0538	1.8671	1.9418	1.9805	1.8671	1.8484	2.0748
Max	**2.0725**	**2.1879**	**2.1691**	**1.9805**	**2.0748**	**2.1691**	**2.2257**
Min	**1.6804**	**1.7737**	**1.8671**	**1.226**	**1.6804**	**1.8107**	**1.8861**
Avg	**1.9751**	**1.9946**	**2.0053**	**1.6401**	**1.8986**	**1.9946**	**2.0413**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI B S/DN.[711] BU 4711
Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S
Feeder No / Name : 204 / 11 SHAHAPUR IND SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1472	2.0748	2.0748	2.1691	1.8671	1.9805	2.1691
2	2.1472	2.0748	2.0748	2.1691	1.8671	1.9805	2.1691
3	2.0911	2.0748	2.037	2.0748	1.7737	1.9616	2.0748
4	2.0538	1.9805	1.9805	2.0748	1.6804	1.9805	2.0748
5	2.0538	1.9805	1.9805	2.0748	1.587	1.9805	2.0748
6	2.0911	2.0165	2.037	2.0748	1.4937	1.9805	2.0748
7	2.1472	2.0748	2.0748	2.0748	1.587	1.9993	2.0748
8	2.2405	2.1691	2.0748	1.8861	1.587	1.9993	2.0748
9	2.3339	2.2634	2.2634	1.5089	1.587	1.9805	2.1691
10	2.2779	2.3011	2.3011	1.5089	2.1691	1.9805	2.1691
11	2.2405	2.3011	2.2634	1.5089	2.1879	2.0748	2.1691
12	2.2592	2.2634	2.2634	1.5278	2.1125	2.0748	2.1691
13	2.2405	2.1691	2.2634	1.5278	2.1125	1.9805	2.1691
14	2.2405	2.1125	2.2634	1.5089	2.0748	2.0748	2.1691
15	2.2405	2.2634	2.2634	1.5089	2.1691	2.1691	2.1125
16	2.2405	2.2634	2.2634	1.5089	2.1879	2.1691	2.2634
17	2.2634	2.2634	2.2634	1.5089	2.1879	2.1691	2.2634
18	2.2634		2.2634	1.6975	2.1879	2.1691	2.2634
19	2.2257	2.0748	2.1691	1.6975	2.2068	2.0748	2.2405
20	2.0748	2.0748	2.0748	1.6032	2.1691	2.0748	2.2405
21	2.1691	2.0748	2.0748	1.6975	2.1125	2.1691	2.0538
22	2.2068	2.0748	2.1691	1.6975	2.037	2.1691	2.2405
23		2.0748	2.1691	2.037		2.1691	1.8671
24	2.1313	2.0748	2.0748	2.1691	1.8671	2.037	2.1691
Max	**2.3339**	**2.3011**	**2.3011**	**2.1691**	**2.2068**	**2.1691**	**2.2634**
Min	**2.0538**	**1.9805**	**1.9805**	**1.5089**	**1.4937**	**1.9616**	**1.8671**
Avg	**2.1904**	**2.1346**	**2.1557**	**1.7840**	**1.9484**	**2.0583**	**2.1465**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI B S/DN.[711] BU 4711
Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S
Feeder No / Name : 205 / 11 KV RADHA KANHAIYA SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2012	.5359	1.2136	1.3203	1.2936	1.2071	1.3203
2	1.2012	.5359	1.1576	1.3203	1.386	1.1584	1.3203
3	1.1458	.5359	1.0642	1.3203	1.2936	1.1883	1.3203
4	1.1088	.5544	1.0269	1.1317	.8316	1.1706	1.3203
5	1.1088	.5914	1.0082	1.1317	1.2936	1.2071	1.1317
6	1.1458	.5914	1.0082	1.226	1.386	1.1222	1.226
7	1.0903	.6099	1.1203	1.226	1.1088	1.1403	1.226
8	1.0534	1.2567	1.1763	1.3203	1.2012	1.1765	1.3203
9	1.0164	1.386	1.5466	1.4146	1.2012	1.4632	1.5089
10	.9795	1.423	1.5089	1.5089	1.5089	1.5384	1.5089
11	.924	1.4712	1.6032	1.5089	1.6221		1.3203
12	.924	1.4118	1.5089	1.5089	1.448	1.448	1.5089
13	.924	1.3394	1.6032	1.5089	1.4118	1.086	1.1317
14	.924	1.358	1.5089	1.4146	1.3937	1.267	1.1317
15	.924	1.4118	1.5089	1.3203	1.448	1.448	1.3203
16	.7392	1.5089	1.5089	1.3203	1.5203	1.4022	1.5089
17	.7468	1.4003	1.5089	1.3203	1.5023	1.448	1.5089
18	.5601	1.307	1.448	1.3203	1.5466	1.448	1.3203
19	.6348	1.1949	1.448	1.3203	1.4661	1.267	1.2936
20	.6348	1.4003	1.3203	1.3203	1.4118	1.267	1.4784
21	.6348	1.4003	1.3203	1.3203	1.3937	1.267	1.6632
22	.6348	1.3443	1.267	1.3203	1.2308	1.267	1.2936
23		1.2883	1.267	1.4146		1.267	1.4784
24	1.2883	.5415	1.307	1.3203	1.386	1.226	1.3203
Max	**1.2883**	**1.5089**	**1.6032**	**1.5089**	**1.6221**	**1.5384**	**1.6632**
Min	**.5601**	**.5359**	**1.0082**	**1.1317**	**.8316**	**1.086**	**1.1317**
Avg	**.9367**	**1.0999**	**1.3316**	**1.3399**	**1.3602**	**1.2818**	**1.3534**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI B S/DN.[711] BU 4711
Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S
Feeder No / Name : 207 / 11 K.V AMIT SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2405	2.0748	2.0748	2.1691	1.4937	1.8484	2.2634
2	2.2405	2.0748	2.0748	2.1691	1.4937	1.8296	
3	2.2032	2.037	2.0748	2.0748	1.6804	1.8296	2.2634
4	2.1472	1.9805	1.9805	2.0748	1.4937	1.8484	2.1691
5	2.1472	1.9805	1.9805	2.0748	1.4937	1.8484	2.0748
6	2.2405	2.037	2.0748	2.1691	1.6804	1.8296	2.0748
7	2.2779	2.037	2.0748	2.1691	1.6804	1.8484	2.0748
8	2.3339	2.0748	2.0748	2.0748	1.6804	1.8296	2.1691
9	2.3712	2.1125	2.2634	1.8861	1.4937	2.0748	2.2634
10	2.3152	2.1313	2.2634	1.8861	1.9805	2.1691	2.2634
11	2.3339	2.1313	2.2634	1.8861	1.9616	2.2634	2.2634
12	2.3899	2.1125	2.2634		1.9427	2.2634	2.2634
13	2.3525	2.0748	2.2634	1.8861	1.9616	2.1691	2.2634
14	2.2779	2.037	2.2634	1.8861	1.8861	2.1691	2.2634
15	2.2405	2.037	2.2634	1.6975	1.9616	2.2634	
16	2.2405	1.9805	2.2634	1.6975	1.9805	2.2634	
17	2.0748	1.9805	2.2634	1.6975	1.9805	2.2634	2.2634
18	1.8861		2.2634	1.6975	1.9805	2.2634	2.2634
19	1.9805	1.9805	2.1691	1.5089	1.8296	2.2634	2.2405
20	2.0182	2.1691	2.1691	1.5089	1.8484	2.1033	2.2405
21	2.1125	2.1502	2.1691	1.6975	1.8484	2.2634	2.2405
22	2.1691	2.1502	2.1691	1.6975	1.8673	2.2634	2.2405
23		2.1313	2.1691	1.5089		2.2634	2.2405
24	2.2634	2.0936	2.0748	2.1691	1.4937	1.8484	2.2634
Max	**2.3899**	**2.1691**	**2.2634**	**2.1691**	**1.9805**	**2.2634**	**2.2634**
Min	**1.8861**	**1.9805**	**1.9805**	**1.5089**	**1.4937**	**1.8296**	**2.0748**
Avg	**2.2112**	**2.0682**	**2.1652**	**1.8820**	**1.7701**	**2.0783**	**2.2220**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI B S/DN.[711] BU 4711
Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S
Feeder No / Name : 208 / 11 K.V. TULJABHAVANI SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.5113	3.3265	3.5837	3.5837	3.2674	3.5837	3.5837
2	3.5113	3.3265	3.5837	3.5837	3.2674	3.5837	3.5837
3	3.5113	3.3265	3.3951	3.3951	3.1741	3.4389	3.5837
4	3.4189	3.3265	3.3008	3.3951	3.1741	3.5837	3.5837
5	3.4541	3.3265	3.3008	3.3951	3.3608	3.5837	3.5837
6	3.5475	3.5113	3.3951	3.3951	3.4541	3.5837	3.7723
7	3.5475	3.6961	3.2579	3.3951	3.3608	3.4389	3.7723
8	3.7342	3.6961	3.5837	3.2065	3.3608	3.4389	
9	3.7342	3.6961	3.7723	2.6406	3.3608	3.4389	3.7723
10	3.7342	3.8809		2.6406	3.9609	3.7342	3.7723
11	3.7723	3.9609	3.7723	2.2634	3.9609	3.7723	3.9609
12	3.9609	3.7723		2.0748	3.5837	3.7723	3.7723
13	3.9609	3.9609	3.7723	2.0748	3.5837	3.5837	3.5837
14	3.9609	3.9609		2.0748	3.5837	3.4389	3.7723
15	3.7723	3.9209	3.9609	2.0748	3.9609	3.7723	3.9609
16	3.7723	3.9209	3.7723	2.2634	3.9609	3.7723	3.9609
17	3.7723	3.9609	3.9609	2.452	3.7723	3.7723	3.7723
18	3.7723	3.7723	3.9609	2.6406	3.7723	3.7723	3.9609
19	3.7723	3.7723	3.7723	3.0178	3.5837	3.5837	3.5837
20	3.5837	3.7723	3.5837	3.0178	3.5837	3.4389	3.7723
21	3.5837	3.5837	3.5837	3.2065	3.5837	3.5837	3.9609
22	3.5837	3.5837	3.5837	3.3951	3.5837	3.4389	3.7723
23		3.5837	3.5837	3.2065		3.4389	3.5837
24	3.7723	3.3951	3.5837	3.5837	3.2674	3.5837	3.5837
Max	**3.9609**	**3.9609**	**3.9609**	**3.5837**	**3.9609**	**3.7723**	**3.9609**
Min	**3.4189**	**3.3265**	**3.2579**	**2.0748**	**3.1741**	**3.4389**	**3.5837**
Avg	**3.6845**	**3.6681**	**3.6221**	**2.9157**	**3.5444**	**3.5889**	**3.7395**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI B S/DN.[711] BU 4711
Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S
Feeder No / Name : 209 / 11 K.V YOGASHRAM SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.307	.3734	1.307	1.2269	1.4937	1.267	1.2803
2	1.307	.3734	1.307	1.1336	1.4937	1.267	
3	1.1203	.3734	1.1203	1.3203	1.4937	1.267	1.0745
4	.9335	.3734	.9335	1.1317	1.6804	1.267	1.0745
5	.9335	.3734	.9335	1.1317	1.307	1.267	1.0745
6	1.1203	.5601	1.1317	1.1317	1.307	1.267	1.0745
7	1.1203	.5601	1.1203	1.3203	1.307	1.2269	1.2536
8	1.1203	1.307	1.1203	1.5089	1.4003	1.267	1.4327
9	1.1203	1.6804	1.448	1.6975	1.4937	1.448	1.6118
10	1.1203	1.6804	1.6975	1.4175	1.6975	1.6289	1.6289
11	1.086	1.6975	1.5089	1.267	1.6975	1.6289	1.4327
12	.8954	1.5089	1.5089	1.0745	1.5089	1.6289	1.1317
13	1.0745	1.5089	1.3203	1.2536	1.3203	.8764	.7164
14	.985	1.5089	1.3203	1.4327	1.3203	1.267	1.0974
15	1.0745	1.6804	1.4022	1.5947	1.6975	1.448	1.2536
16	.905	1.6804	1.5089	1.6118	1.6975	1.5089	1.5089
17	.9335	1.6804	1.5089	1.6118	1.6975	1.4022	1.4327
18	.7468	1.6804	1.448	1.5947	1.6975	1.448	1.4327
19	.5601	1.6804	1.448	1.4022	1.5089	1.448	1.4327
20	.5601	1.6804	1.448	1.6118	1.5089	1.448	1.4175
21	.5601	1.4937	1.4022	1.4175	1.5089	1.448	1.2536
22	.5601	1.4937	1.267	1.7718	1.3203	1.267	1.2536
23		1.307	1.3203	1.4022		1.267	1.4327
24	1.307	.3734	1.307	1.3203	1.4937	1.2269	1.2536
Max	**1.307**	**1.6975**	**1.6975**	**1.7718**	**1.6975**	**1.6289**	**1.6289**
Min	**.5601**	**.3734**	**.9335**	**1.0745**	**1.307**	**.8764**	**.7164**
Avg	**.9761**	**1.1929**	**1.3266**	**1.3911**	**1.5066**	**1.3536**	**1.2850**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI B S/DN.[711] BU 4711
Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S
Feeder No / Name : 210 / 11 KV New Supereme Feeder SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5133	3.1971	2.572	2.6406	1.848	2.9801	2.6406
2	2.8829	3.0678	2.7625	2.6406	2.2177	2.8669	
3	2.9754	2.8645	2.8006	2.452	2.4025	2.9047	2.452
4	3.0493	2.3285	2.553	2.452	2.5873	2.9801	2.6406
5	3.0862	2.3285	2.553	2.452	2.5873	2.999	2.8292
6	3.1602	2.5688	2.6101	2.452	2.7721	3.0361	3.0178
7	3.2341	2.6242	2.7435	2.452	2.7721	2.5339	3.2065
8	3.271	2.846	2.7625	1.8861	2.7721	2.3137	3.2065
9	3.2895	2.9199	2.6783	1.5089	2.9569	2.6406	3.2065
10	2.6242	2.6057	2.6029	1.5089	3.2065	2.6244	
11	3.1417	2.6783	2.6406	1.4335	3.1876	2.8292	3.0178
12	3.2341	2.0182	2.6783	1.3203	3.2442	2.8292	2.8292
13	3.1417	2.6406	2.6406	1.5089	2.6029	2.6406	2.6406
14	2.9569	2.6972	2.6406	1.7918	2.5086	2.6406	2.8292
15	2.7721	2.6406	2.7349	1.226	2.5463	2.6406	3.0178
16	2.5873	2.5652	2.6406	1.3203	2.584	2.6406	3.2065
17	2.8578	2.9721	2.6406	1.4146	2.6217	2.6139	3.2065
18	3.1817	3.2198	2.6406	1.4146	2.6595	2.7149	1.9805
19	3.2198	3.296	2.6406	1.5089	2.6406	2.8045	3.0178
20	3.1817	2.915	2.6406	1.6975	2.6217	3.1674	3.0178
21	3.1436	2.6101	2.6406	1.9805	2.6406	3.2065	3.1121
22	3.1436	3.1817	2.6406	2.0748	2.6217	2.8292	3.0178
23		3.296	2.6406	2.0748		2.6406	3.1121
24	2.6482	3.2579	2.572	2.6406	1.848	2.9424	2.6406
Max	**3.2895**	**3.296**	**2.8006**	**2.6406**	**3.2442**	**3.2065**	**3.2065**
Min	**2.5133**	**2.0182**	**2.553**	**1.226**	**1.848**	**2.3137**	**1.9805**
Avg	**3.0129**	**2.8058**	**2.6529**	**1.9105**	**2.6283**	**2.7925**	**2.9021**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI B S/DN.[711] BU 4711
Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S
Feeder No / Name : 211 / 11 KV Mhashoba Mandir Feeder Feeder KV- 11 / OUTGOING **SHEDDABLE URBAN**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5546	1.0059	1.4251	1.5089	1.9204	1.4575	1.4575
2	1.5546	1.0059	1.4251	1.5089	1.9204	1.3765	1.6032
3	1.5546	.9511	1.4083	1.5089	1.829	1.3927	1.6032
4	1.4632	.9145	1.3413	1.4251	2.0119	1.4083	1.5089
5	1.4632	.9511	1.3413	1.3765	1.848	1.4251	1.2955
6	1.5546	1.0974	1.4083	1.5089	1.829	1.3603	1.3927
7	1.5729	1.1706		1.5089	1.6461	1.4419	1.6032
8	1.4632	1.6632	1.5089	1.6766	1.6461	1.4575	1.4403
9	1.3535	1.9022	1.7814		1.829	1.6194	1.6385
10	1.3535	1.9387	1.8404	1.6004	1.9909		1.4575
11	1.2803	1.8461	1.6004	1.5203	2.0559	1.8861	1.2955
12	1.1888	1.773	1.7604	1.4746	1.8099	1.6194	1.4575
13	.9145	1.7194	1.8623	1.4575	1.8099	1.1336	1.0936
14	1.0059	1.7375	1.6004	1.5384	1.7737	1.5089	1.1203
15	1.0974	1.8461	1.6194	1.6194	1.9004	1.7004	1.6004
16	.9145	1.9616	1.6385	1.6385	1.9547	1.6404	1.6804
17	.6706	1.7604	1.7814	1.6004	1.9366	1.9004	1.6804
18	.6706	1.7101	2.0748	1.6004	1.9547	1.7004	1.6804
19	.7377	1.6933	1.9004	1.7368	1.9185	1.6766	1.6385
20	.7545	1.6766	1.6194	1.7204	1.9004	1.6766	1.5813
21	.8718	1.5592	1.6194	1.7004	1.8823	1.8861	1.5384
22		1.5592	1.5384	1.6712	1.7375	1.5927	1.5023
23		1.5089	1.5384	1.6194		1.5927	1.5203
24	1.4586	.9054	1.4251	1.5089	1.9204	1.773	1.4403
Max	**1.5729**	**1.9616**	**2.0748**	**1.7368**	**2.0559**	**1.9004**	**1.6804**
Min	**.6706**	**.9054**	**1.3413**	**1.3765**	**1.6461**	**1.1336**	**1.0936**
Avg	**1.2024**	**1.4941**	**1.6113**	**1.5665**	**1.8707**	**1.5751**	**1.4929**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI B S/DN.[711] BU 4711
Substation No/ Name :- 144051 / 33/11 KV KABNOOR
Feeder No / Name : 201 / 11 KV KABNOOR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4327	.8676	1.3717	1.3717	1.4575	1.5775	1.3717
2	1.4327	.8299	1.3717	1.3717	1.4575	1.4899	1.3717
3	1.4327	.8299	1.3717	1.3717	1.4575	1.5061	1.3717
4	1.448	.8299	1.3717	1.3717	1.4575	1.5061	1.3717
5	1.448		1.3717	1.3717	1.4575	1.5061	1.3717
6	1.448	.9431	1.3717	1.3717	1.4575	1.5061	1.3717
7	1.6461	1.358	1.6289	1.6118	1.5432	1.7909	1.5432
8	1.4784	1.6804	1.7147	1.6461	1.7147	1.8604	1.5775
9	1.6461	1.9281	1.9719	1.8861	1.8004	1.9071	1.8861
10	1.5546	1.989	1.9719	1.8991	2.0062	1.8652	1.8991
11	1.4575	1.989	2.0233	1.8004	2.0062	2.0687	2.0119
12	1.0288	1.9204	1.8004	1.6651	1.8861	1.8991	1.8004
13	.6859	1.5432	1.5565	1.6118	1.406	1.4685	1.3717
14	.8573	1.6461	1.8004	1.7337	1.5775	1.8778	1.7147
15	1.0288	1.8861	1.9547	1.8861	1.8861	1.9113	1.8861
16	1.0288	1.8107	2.0008	1.8652	1.9204	1.9448	1.8861
17	.9431	1.8442	2.0348	1.95	1.9204	1.9784	1.9719
18	.9431	2.0119	2.0919	1.9719	1.9281	2.1948	2.0576
19	1.1317	2.0576	2.0919	1.9719	1.9281	2.1948	2.0576
20	1.094	2.0576	1.989	1.7147	1.9281	2.0576	2.0576
21	1.2449	1.7147	1.749	1.7147	1.9071	1.9547	1.9204
22	1.1317	1.6289	1.6461	1.7147	1.7337	1.7833	1.749
23	.9054	1.6289	1.6118	1.7147	1.5604	1.6118	1.5432
24	1.4327	.8676	1.6289	1.5432	1.7147	1.5604	1.5432
Max	**1.6461**	**2.0576**	**2.0919**	**1.9719**	**2.0062**	**2.1948**	**2.0576**
Min	**.6859**	**.8299**	**1.3717**	**1.3717**	**1.406**	**1.4685**	**1.3717**
Avg	**1.2450**	**1.5593**	**1.7290**	**1.6721**	**1.7130**	**1.7926**	**1.6961**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI B S/DN.[711] BU 4711
Substation No/ Name :- 144051 / 33/11 KV KABNOOR
Feeder No / Name : 202 / CHANDUR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.5437	2.4272	3.2579	3.2388	3.6008	3.5608	3.3532
2	3.3665	2.4272	3.2579	3.2388	3.6008	3.6008	3.4294
3	3.2779	2.4272	3.2579	3.2388	3.6008	3.4675	3.4294
4	3.2779	2.4272	3.2579	3.2388	3.6008	3.4675	3.3532
5	3.2779		3.2579	3.2388	3.3436	3.4675	3.2388
6	3.2779	2.5766	3.2579	3.2388	3.3436	3.4675	3.4294
7	3.3665	2.6513	3.2579	3.2388	3.4294	3.6808	3.4294
8	2.8645	2.9264	3.4294	3.4008	3.4294	3.7685	3.5208
9	2.5206	3.9678	4.2867	4.1914	4.1152	4.2753	4.0238
10	2.5206	4.4239	4.3591	4.2391	4.3591	4.2267	4.1914
11	2.4006	4.4582	4.4597	4.3239	4.3591	4.2764	4.2753
12	1.7147	4.1914	3.4328	3.9438	4.0238	3.6286	3.6808
13	1.2003	2.7092	2.8645	2.9864	2.5149	2.8597	2.6578
14	1.5432	3.8561	3.3532	3.9438	3.7555	3.5471	3.5208
15	1.8004	3.9232	4.225	4.2391	4.1244	4.0775	4.1076
16	3.1379	4.0238	4.1914	4.1076	4.1244	4.2433	4.1076
17	1.7147	4.0238	4.1244	4.1076	4.1244	4.177	4.1076
18	1.7147	3.9903	4.0238	4.201	4.2052	4.0238	3.8561
19	1.4969	3.7723	4.0238	4.201	3.9847	4.0238	3.7555
20	1.4937	3.4294	3.6885	3.6008	3.7304	3.6885	3.6885
21	2.3285	3.4294	3.6549	3.6008	3.7304	3.8561	3.6885
22	2.4025	3.4294	3.6694	3.6866	3.6885	3.5879	3.5208
23	2.4394	3.4294	3.6694	3.6866	3.6885	3.5879	3.5208
24	3.6008	2.4394	3.4294	3.4008	3.6866	3.5208	3.6008
Max	**3.6008**	**4.4582**	**4.4597**	**4.3239**	**4.3591**	**4.2764**	**4.2753**
Min	**1.2003**	**2.4272**	**2.8645**	**2.9864**	**2.5149**	**2.8597**	**2.6578**
Avg	**2.5118**	**3.3635**	**3.6538**	**3.6889**	**3.7568**	**3.7534**	**3.6453**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI B S/DN.[711] BU 4711
Substation No/ Name :- 144051 / 33/11 KV KABNOOR
Feeder No / Name : 205 / DATTA NAGAR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2651	.6805	1.3717	1.2308	1.3717	1.2955	1.2955
2	1.2003	.6805	1.3717	1.2308	1.3717	1.2346	1.2955
3	1.2146	.6805	1.3717	1.2308	1.3717	1.2498	1.3717
4	1.2003	.6805	1.3717	1.2308	1.3717	1.2498	1.2955
5	1.2146		1.3717	1.2308	1.3717	1.2498	1.2955
6	1.186	.7522	1.3717	1.2308	1.3717	1.2498	1.2955
7	1.3108	.8954	1.4575	1.3603	1.5432	1.3603	1.3927
8	1.0898	1.0974	1.5432	1.4575	1.7147	1.5384	1.4575
9	1.1022	1.5813	1.8861	1.8138	1.9719	1.6975	1.7814
10	1.1145		1.6766	1.6996	1.8461	1.6766	1.7071
11		1.8138	1.6766	1.7309	1.8461	1.6766	1.6004
12	.8573	1.6194	1.4198	1.5242	1.7814	1.4022	1.2955
13	.5144	1.0688	1.1142	1.1469	1.1012	1.0159	1.1336
14	.5144	1.4575	1.4022	1.448	1.5546	1.4022	1.4575
15	.6859	1.6842	1.5546	1.6024	1.7814	1.5242	1.6194
16		1.6461	1.5851	1.5804	1.749	1.6766	1.6194
17	.7716	1.6461	1.5851	1.5804	1.749	1.5546	1.7004
18	.7716	1.6766	1.7166	1.6004	1.7284	1.8461	1.6518
19	.7023	1.8861	1.7166	1.8861	1.6975	1.8461	1.6518
20	.6733	1.7147	1.6194	1.8861	1.6004	1.7814	1.6194
21	.815	1.7147	1.6518	1.7147	1.6004	1.6518	1.6518
22	.7442	1.7147	1.4575	1.7147	1.5051	1.4899	1.4899
23	.7087	1.7147	1.5432	1.7147	1.3546	1.4575	1.4575
24	1.2193	.6733	1.7147	1.4575	1.7147	1.2793	1.4251
Max	**1.3108**	**1.8861**	**1.8861**	**1.8861**	**1.9719**	**1.8461**	**1.7814**
Min	**.5144**	**.6733**	**1.1142**	**1.1469**	**1.1012**	**1.0159**	**1.1336**
Avg	**.9489**	**1.3218**	**1.5230**	**1.5126**	**1.5862**	**1.4753**	**1.4817**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI B S/DN.[711] BU 4711
Substation No/ Name :- 144051 / 33/11 KV KABNOOR
Feeder No / Name : 207 / Chandur Kabnur Ag Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3201	.0171	.0162	.0171	.0171	.3887
2	.3048	.3201	.0171	.0162	.0171	.0171	.3887
3	.3048	.3201	.0171	.0162	.0171	.0171	.3887
4	.3048	.3201	.0171	.0162	.0171	.0171	.3887
5	.3048		.0171	.0162	.0171	.0171	.3887
6	.3353	.3201	.0171	.0162	.0171	.0171	.3887
7	.4115	.3749	.0171	.0162	.0171	.0171	.4858
8	.0171	.0152	.3429	.5182	.6001	.4877	.0162
9	.0171	.0152	.5144	.583	.6859	.6097	.0162
10	.0171	.0162	.6478	.6859	.7125	.6325	.0171
11	.0171	.0171	.6478	.7621	.7125	.6483	.0171
12	.0171	.0162	.583	.6859	.7125	.6958	.0171
13	.0171	.0162	.6154	.6859	.6478	.7116	
14	.0171	.0162	.6154	.6859	.6478	.6958	.0162
15	.0171	.0162	.6154	.6859	.5182	.6325	.0162
16	.0171	.0152	.0152	.0171	.0162	.0152	.0162
17	.0171	.0152	.0152	.0171	.0162		.0162
18	.0171		.0162	.0171	.0171	.0162	.0162
19	.0152	.0171	.0162	.0171	.0171	.0162	.0162
20	.0152	.0171	.0162	.0171	.0171	.0162	.0162
21	.0152	.0171	.0162	.0171	.0171	.0162	.0162
22	.2881	.0171	.0162	.0171	.0171	.3887	.2591
23	.3201	.0171	.0162	.0171	.0171	.3887	.2591
24	.3048	.3201	.0171	.0162	.0171	.0171	.3887
Max	**.4115**	**.3749**	**.6478**	**.7621**	**.7125**	**.7116**	**.4858**
Min	**.0152**	**.0152**	**.0152**	**.0162**	**.0162**	**.0152**	**.0162**
Avg	**.1424**	**.1155**	**.2019**	**.2316**	**.2295**	**.2656**	**.1712**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI B S/DN.[711] BU 4711
Substation No/ Name :- 144051 / 33/11 KV KABNOOR
Feeder No / Name : 208 / 11 KV Dhuleshwar Nagar SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.503	.3361	.6001	.5144	.6859	.5735	.5487
2	.503	.3361	.6001	.5144	.6859	.4915	.5487
3	.503	.3361	.6001	.5144	.6859	.4973	.5487
4	.503	.3361	.6001	.5144	.6859	.5087	.5487
5	.5087		.6001	.5144	.6859	.5087	.5487
6	.503	.3734	.6001	.5144	.6001	.5087	.5487
7	.6001	.4108	.6001	.5487	.6859	.6001	.6173
8	.6001	.4961	.6859	.6173	.6859	.6783	.6173
9	.6001	.7125	.7716	.7545	.8573	.663	.823
10	.6001		.7287	.7042	.7545	.6554	.759
11	.6001	.7545	.7449	.759	.7545	.6226	.7116
12	.3429	.7545	.7125	.6722	.7545	.6241	.7202
13	.2572	.5144	.5668	.5735	.5487	.583	.6001
14	.3429	.6173	.7042	.6478	.6859	.5967	.6859
15	.4287	.6859	.7042	.7287	.6859	.5967	.7716
16	.4287	.6874	.6874	.7287	.7545		.7716
17	.4287	.6874	.6874	.7202	.7545		.7716
18	.4287	.7186	.7545	.7287	.7209	.823	.823
19	.3206	.7716	.7545	.7716	.7701	.823	.823
20	.3109	.6859	.6859	.6859	.6882	.823	.823
21	.4024	.6859	.6859	.6859	.6962	.7202	.7202
22	.3658	.6859	.6859	.6859	.6478	.6516	.6859
23	.3292	.6859	.6173	.6859	.5668	.6516	.6173
24	.4801	.3292	.6859	.6173	.6859	.5668	.6173
Max	**.6001**	**.7716**	**.7716**	**.7716**	**.8573**	**.823**	**.823**
Min	**.2572**	**.3292**	**.5668**	**.5144**	**.5487**	**.4915**	**.5487**
Avg	**.4538**	**.5728**	**.6693**	**.6418**	**.6970**	**.6258**	**.6771**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI B S/DN.[711] BU 4711
Substation No/ Name :- 144111 / 33/11 KV Hanumannagar
Feeder No / Name : 201 / 11 KV HANUMANNAGAR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.543	.6602	1.6289	1.6278	1.4632	1.5091	1.7147
2	1.4922	.6602	1.5432	1.56	1.4632	1.5091	1.6289
3	1.4752	.6413	1.5432	1.543	1.4632	1.5091	1.5432
4	1.4922	.6413	1.5432	1.543	1.4327	1.56	1.5432
5	1.5261	.6413	1.5432	1.5769	1.4327	1.5769	1.5432
6	1.56	.7356	1.5432	1.5939	1.448	1.56	1.6118
7	1.5091	.8299	1.5775	1.6278	1.4632	1.6617	1.5546
8	1.5261	1.1506	1.6766	1.95	1.5394	1.8143	1.7528
9	1.3056	2.1262	1.9966	.2204	1.9867	2.2043	1.9814
10	1.2887	2.1776	2.0119	2.2891	2.0168	2.2721	2.0424
11	1.2548	1.9052	2.2043	2.0319	2.2891	2.0119	2.0018
12	1.0004	1.7528	2.0348	1.9115	2.0348	1.6766	1.8814
13	.6274	1.387	1.6108	1.4449	1.5939	1.5089	1.4632
14	.763	1.6766	2.0178	1.8061	2.0008	1.829	1.7071
15	.8309	1.9204	2.1874	1.9416	2.2043	1.9814	1.9509
16	.8817	1.9204	2.1704	1.9867	2.2382	1.9814	1.9966
17	.8676	1.9204	2.1874	1.9566	2.2043	1.9814	2.0576
18	.6413	1.829	2.1704	1.9566	2.0687	1.9814	2.0271
19	.4904	1.768	2.0687	1.9566	2.1195	1.9509	1.9052
20	.6602	1.768	1.9839	1.8362	2.0178	2.1434	1.7985
21	.7545	1.6766	1.933	1.7459	1.9839	2.0576	1.768
22	.7545	1.6004	1.8991	1.6857	1.933	1.8861	1.7528
23	.7167	1.7147	1.8143	1.6766	1.8143	1.8004	1.6918
24	1.5769	.679	1.6804	1.6956	1.4784	1.56	1.749
Max	**1.5769**	**2.1776**	**2.2043**	**2.2891**	**2.2891**	**2.2721**	**2.0576**
Min	**.4904**	**.6413**	**1.5432**	**.2204**	**1.4327**	**1.5089**	**1.4632**
Avg	**1.1058**	**1.4076**	**1.8571**	**1.7152**	**1.8204**	**1.8136**	**1.7778**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI B S/DN.[711] BU 4711
Substation No/ Name :- 144111 / 33/11 KV Hanumannagar
Feeder No / Name : 203 / 11 KV SWAMI APPARTMENT SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6104	.2641	.6859	.6783	.6316	.6613	.6859
2	.5765		.6859	.6104	.6316	.6274	.6001
3	.5765	.2452	.6859	.6104	.6316	.6274	.6001
4	.5935	.2452	.6859	.6104	.6154	.6443	.6001
5	.6274	.2641	.6859	.6274	.5992	.6274	.6173
6	.6613	.3206	.6859	.6613	.6316	.6783	.6516
7	.6783	.3961	.6859	.6952	.6802	.7291	.6097
8	.7291	.6224	.7926	.9156	.7611	.8478	.7926
9	.763	1.094	.9145	1.0513	.9602	1.0513	.9297
10	.7461	1.0751	.945	1.0343	.9762	1.0174	.8688
11	.6783	.8383	1.0174	.9922	1.0682	.9145	.9922
12	.5765	.7316	1.0004	.9282	.9496	.7621	.9602
13	.4409	.5182	.5087	.5761	.6104	.6554	.6802
14	.4748	.6401	.8987	.7682	.8478	.8383	
15	.5426	.8383	.9835	.8642	.8987	.8383	.9231
16	.5765	.823	.9665	.9602	1.0004	.884	.9393
17	.5658	.823	1.0004	.9069	.9835	.884	.9122
18	.4527	.884	1.0343	.9922	1.0343	.9145	.9922
19		.8993	1.0174	.9922	1.0682	.945	.9762
20	.4715	.8993	.9665	.9602	1.0343	1.0288	.8802
21	.4338	.8383	.9496	.8802	1.0004	1.0288	.8745
22	.4338	.7621	.8817	.8482	.8987	.8573	.8583
23	.3206	.7716	.78	.7842	.8478	.8573	.7449
24	.6443	.2829	.6859	.7122	.664	.7291	.7373
Max	**.763**	**1.094**	**1.0343**	**1.0513**	**1.0682**	**1.0513**	**.9922**
Min	**.3206**	**.2452**	**.5087**	**.5761**	**.5992**	**.6274**	**.6001**
Avg	**.5728**	**.6555**	**.8394**	**.8192**	**.8344**	**.8187**	**.8012**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI B S/DN.[711] BU 4711
Substation No/ Name :- 144118 / 33/11 KV Korochi Sub Station
Feeder No / Name : 201 / 11 KV Dhangarmal GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9054	.6089	.8718	.9054	.8817	.8718	.8718
2	.8951	.6089	.8478	.9259	.8573	.8573	.8383
3	.8951	.6089	.823	.8916	.823	.9259	.823
4	.8383	.6089	.8413	.8916	.7975	.9054	.7975
5	.852	.6447	.8669	.9156	.8413	.9496	.8063
6	.8848	.6805	.9362	.9259	.9362	.9496	.8669
7	1.0059	.788	.9816	.9282	.9465	.9614	.9709
8	1.0059	.8596	1.0402	.9945	.9816	.9945	1.0056
9	1.0059	1.0745	1.094	1.0562	1.0486	1.0608	1.0174
10	1.0513	1.0364	1.0814	1.1706	.9831	.9602	1.1317
11	.9389	1.004	1.1142	1.0395	1.0486	.9259	1.166
12	.8478	.9717	1.094	.9724	1.0608	.8573	1.1317
13	.6447	.8619	.9156	.7975	1.0059	.823	.8718
14	.7442	.8848	1.0059	.8951	.9389	.8642	.9835
15	.9431	1.004	1.0608	.9614	1.0059	.9922	1.0974
16	.8048	1.0364	1.0364	.9503	.9945		1.0974
17	.7461	.9393	1.0242	.9945	1.0277	1.0159	1.0631
18	.7087	1.0486	1.0608	1.0277	1.0395	1.0159	1.073
19	.7087	1.0631	1.073	1.0056	.9282	1.0974	1.0852
20	.6733	1.0513	.9259	1.0288	.9389	1.0513	1.0059
21	.7087	1.0277	.9054	1.0174	1.073	1.0174	1.0852
22	.7087	.9724	.8951	.9724	.9614	.9724	.9945
23	.6805	.9389	.9054	.8951	.9724	.9389	1.0395
24	.8383	.6447	.8718	.9054	.9054	.8817	.8951
Max	**1.0513**	**1.0745**	**1.1142**	**1.1706**	**1.073**	**1.0974**	**1.166**
Min	**.6447**	**.6089**	**.823**	**.7975**	**.7975**	**.823**	**.7975**
Avg	**.8348**	**.8737**	**.9697**	**.9612**	**.9582**	**.9517**	**.9883**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI B S/DN.[711] BU 4711
Substation No/ Name :- 144118 / 33/11 KV Korochi Sub Station
Feeder No / Name : 203 / 11 KV Ghorpade SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	1.0185	.9808	.9054	.9808	.9431	.9431
2	.9431	1.0185	.9431	.9054	.9431	.9431	.9054
3	.9431	1.0185	.9054	.8676	.9054	.9054	.9054
4	.9431	.9808	.9054	.9054	.9431	.9054	.8676
5	.9054	.9808	.9431	.9431	.9808	.8676	.8676
6	1.0185	.9808	.9808	.9431	.9431	.9054	.8299
7	.9808	.9808	.9808	1.0185	.9808	.9431	.9054
8	.9808	.9431	.9808	1.0185	.9431	.9431	.9054
9	.9808	1.0185	1.0562	.9431	.9054	1.0562	.9054
10	.9808	.9054	.9808	.9808	.9431	1.094	.9054
11	.9808	.9431	1.0185	1.0562	.9808	1.0082	.9808
12	.9431	.9431	1.0185	.9808	.9808	.9808	.9808
13	.9054	.9808	.9808	.9431	.7922	.9431	.9431
14	.9808	1.0185	.9896	.9808	.8676	.8573	.9808
15	.9431	1.0185	.9877	.9808	1.0185	.9465	1.0185
16	.9054	.9431	.9431	.6516	.9671		.9808
17	1.0185	.9808	.9808	.9431	1.094	1.0185	.9808
18	.9808	.9808	1.0185	.9054	1.0562	.9431	.9808
19	.9054	1.0185	1.0185	.9431	.9431	.9808	1.0185
20	1.0562	.9808	1.0185	.9808	.9431	.9808	1.0185
21	.9808	.9431	.9431	1.0185	.9808	.9808	.9808
22	.9431	.9431	.9431	1.0185	.9431	.9808	1.0185
23	.9808	.9431	.9431	1.0185	.9431	.9431	.9054
24	.8299	1.0185	.9808	.9431	.9808	.9054	.9431
Max	**1.0562**	**1.0185**	**1.0562**	**1.0562**	**1.094**	**1.094**	**1.0185**
Min	**.8299**	**.9054**	**.9054**	**.6516**	**.7922**	**.8573**	**.8299**
Avg	**.9572**	**.9792**	**.9767**	**.9498**	**.9567**	**.9555**	**.9447**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
ICHALKARANJI DIVISION[502]
ICHALKARNJI B S/DN.[711] BU 4711
Substation No/ Name :- 144118 / 33/11 KV Korochi Sub Station
Feeder No / Name : 204 / 11 KV Chavan SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4712	1.2826	1.4335	1.4335	1.4335	1.4712	1.5089
2	1.5089	1.2826	1.3957	1.4335	1.358	1.4335	1.4335
3	1.5089	1.2449	1.307	1.4712	1.2826	1.4712	1.4335
4	1.5089	1.2449	1.307	1.4712	1.2826	1.6221	1.358
5	1.4712	1.2826	1.3957	1.4712	1.358	1.5844	1.358
6	1.5089	1.2826	1.4335	1.5089	1.4335	1.3957	1.4335
7	1.419	1.2826	1.5844	1.5089	1.5089	1.531	1.5089
8	1.4563	1.358	1.5844	1.5089	1.5844	1.5684	1.5844
9	1.4712	1.2826	1.5844	1.1203	1.5844	1.6221	1.6598
10	1.4335	1.643	1.643	1.1317	1.6263	1.4419	1.6598
11	1.5089	1.643	1.7177	1.1317	1.643	1.4403	1.7353
12	1.4335	1.4335	1.5089	.9808	1.6598	1.406	1.6975
13	1.358	1.2826	1.358	.7377	1.6221	1.5089	1.358
14	1.4335	1.5684	1.5089	.7964	1.6221	1.5466	1.5844
15	1.4335	1.5844	1.5684	.8962	1.6221	1.5089	1.5844
16	1.4335	1.7177	1.643	.8131	1.5844	1.6598	1.5844
17	1.358	1.643	1.6598	.8131	1.5844	1.6598	1.5844
18	1.358	1.5844	1.5844	.7964	1.6221	1.643	1.5844
19	1.358	1.6598	1.5844	.7964	1.5844	1.5844	1.5844
20	1.358	1.5844	1.5089	1.2071	1.5844	1.5844	1.5089
21	1.2826	1.5089	1.5089	1.5089	1.5844	1.5844	1.5844
22	1.2826	1.5089	1.5089	1.5089	1.5089	1.5844	1.5089
23	1.2826	1.5089	1.3957	1.4335	1.5089	1.5844	1.5089
24	1.5089	1.2826	1.4335	1.3957	1.4335	1.5089	1.5089
Max	**1.5089**	**1.7177**	**1.7177**	**1.5089**	**1.6598**	**1.6598**	**1.7353**
Min	**1.2826**	**1.2449**	**1.307**	**.7377**	**1.2826**	**1.3957**	**1.358**
Avg	**1.4228**	**1.4457**	**1.5066**	**1.2031**	**1.5257**	**1.5394**	**1.5356**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
HATKANANGALE[029] BU 1163
Substation No/ Name :- 144039 / 33/11 KV CHOKAK S/STN
Feeder No / Name : 201 / 11 kv Chokak Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0655	.0655	.0655	.5967	.6554	.823	.5636
2	.0655	.0655	.0655	.5967	.6554	.8573	.5967
3	.0655	.0655	.0655	.5967	.6554	.8573	.5967
4	.0655	.0655	.0655	.5967	.7209	.8916	.5967
5	.0655	.0655	.0655	.663	.7537	.9945	.663
6	.0655	.0819	.0655	.7956	.8029	1.166	.6962
7		.0819	.0819	1.0442	1.065	1.1797	1.0277
8	.0655		.0655	1.094	1.1633	1.2742	1.094
9	.7164	.852	1.0486	.0829	.0819	.0655	.0829
10	1.6575	1.7833	1.8023	.0663	.0829		.0655
11	1.6244	2.0576	***	.0655	.0663		.0819
12	1.8233	2.0233	1.989				
13	1.8233	1.989	1.9204				
14	1.8564	1.9204	1.989				
15	1.7901	1.9204	1.8861				
16	1.757	1.7147	1.749				
17	.0655					.0819	
18	.0983	.0655	.0829	.0655	.0655	.0829	.1802
19	.0983	.0819	.0829	.0819	.0655	.0829	.0819
20	.0983	.0819	.0829	.0819	.0655	.0829	.0819
21	.0819	.0819	.0829	.0655	.0655	.0829	.0819
22	.0819	.0819	.0829	.0655	.0678	.0829	.0819
23	.0819	.0655	.5304	.639	.7545	.5304	.0655
24	.0655	.0655	.0655	.5967	.7209	.823	.5636
Max	**1.8564**	**2.0576**	**19.8903**	**1.094**	**1.1633**	**1.2742**	**1.094**
Min	**.0655**	**.0655**	**.0655**	**.0655**	**.0655**	**.0655**	**.0655**
Avg	**.6165**	**.6944**	**1.4707**	**.4330**	**.4727**	**.5858**	**.4001**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
HATKANANGALE[029] BU 1163
Substation No/ Name :- 144039 / 33/11 KV CHOKAK S/STN
Feeder No / Name : 202 / 11KV Mudshingi Vg GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.307	1.226	1.1694	1.094	.8299	.8589	.8676
2	1.2696	1.1317	1.1317	1.094	.8299	.8215	.8676
3	1.2323	1.1317	1.1317	1.094	.8299	.7545	.8676
4	1.1576	1.226	1.1694	1.094	.9054	.8589	.8676
5	1.307	1.358	1.2826	.679	1.1317	1.0829	.9431
6		1.6598	1.5089	1.2071	1.3769	1.307	1.2449
7		1.8296	1.5466	1.3957		1.4415	1.358
8	1.6057		1.7918	1.5089	1.4712	1.6057	1.5089
9	1.7177	1.5466	1.6975	1.1694	1.4523	1.419	1.358
10	1.5089	1.5684	1.6221	.9808	1.5466	1.3392	1.2826
11	1.4712	1.4563	1.6057	.8962	1.5466		1.1694
12	1.3203	1.3817	1.4937	.8215	1.4335	1.1506	1.0185
13	1.3957	1.3443	1.419	.7468	1.3203	1.1506	.9808
14	1.2826	1.3443	1.2696	.7468	1.2071	1.0374	.9431
15	1.3203	1.3443	1.2936	.7468	1.358	.9054	
16	1.9993	1.5684	1.3443	.9709	1.358	1.094	1.1694
17	1.4712		1.419	1.0456		1.1694	
18	1.7541	1.7353	1.6975	1.2449	2.0538	1.5089	1.5844
19	2.1879	2.1691	2.0748	1.5278	2.1658	1.9239	1.9427
20	2.2257	2.037	1.9239	1.5278	1.9418	1.773	1.7918
21	2.1691	2.037	1.8484	1.4712	1.6804	1.6975	1.7918
22	2.037	1.7353	1.773	1.226	1.4937	1.3957	1.5089
23	1.4335	1.358	1.3203	.9054	.9335	1.0562	1.1317
24	1.419	1.226	1.226	1.1694	.8299	.8962	.9054
Max	**2.2257**	**2.1691**	**2.0748**	**1.5278**	**2.1658**	**1.9239**	**1.9427**
Min	**1.1576**	**1.1317**	**1.1317**	**.679**	**.8299**	**.7545**	**.8676**
Avg	**1.5724**	**1.5189**	**1.4900**	**1.0985**	**1.3498**	**1.2282**	**1.2320**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
HATKANANGALE[029] BU 1163
Substation No/ Name :- 144039 / 33/11 KV CHOKAK S/STN
Feeder No / Name : 203 / 11 KV HERLE VG GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.2987	.2987	.2987	.2987	.2987	.2987
2	.2987	.2987	.2987	.2987	.2987	.2987	.2987
3	.2987	.3018	.2987	.2987	.2987	.2987	.2987
4	.2987	.3361	.2987	.2987	.3174	.3361	.2987
5	.4108	.3734	.3734	.3361	.3734	.4108	.3734
6	.4854	.5415	.4854	.4108	.5228	.5228	.5228
7	.5228	.6161	.5601	.5228		.5975	.4801
8	.5316		.5601	.6348	.6348	.6722	.4801
9	.5788	.5788	.5601	.5601	.5788	.6161	.5601
10	.5228	.5228	.5601	.5601	.4854	.5415	.4854
11	.4854	.5601	.5228	.4481	.4115		.4854
12	.4481	.5228		.4854	.4481	.4294	.4481
13	.4481	.5228	.4854	.4668	.4108	.4668	.4481
14	.3734	.4481	.4108		.4108	.4668	.4481
15	.4115	.4481	.4108		.4481	.4668	.4481
16	.4481	.4854	.4481	.4481	.4108	.4294	.4481
17			.5601	.6348	.5228	.4668	
18	.5415	.6348	.5601	.6535	.5975	.6348	.6161
19	.8029	.7468	.8215	.8029	.7468	.7842	.7842
20	.7095	.7095	.7468	.7655	.7468	.7095	.7095
21	.6161	.6348	.6722	.6348	.6348	.6722	.6908
22	.5228	.5228	.5228	.5415	.5228	.5228	.4854
23	.2987	.3734	.3734	.3734	.3361	.3361	.2987
24	.3734	.2987	.2987	.2987	.2987	.2987	.2987
Max	**.8029**	**.7468**	**.8215**	**.8029**	**.7468**	**.7842**	**.7842**
Min	**.2987**	**.2987**	**.2987**	**.2987**	**.2987**	**.2987**	**.2987**
Avg	**.4680**	**.4898**	**.4838**	**.4897**	**.4676**	**.4903**	**.4655**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
HATKANANGALE[029] BU 1163
Substation No/ Name :- 144039 / 33/11 KV CHOKAK S/STN
Feeder No / Name : 204 / 11Kv Halondi Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2346	1.0059	1.4413	.1543	.1509	.1357	.1715
2	.8573	1.0059	1.4413	.1543	.1509	.1311	.1715
3	.8573	1.0059	1.4413	.1543	.1509	.1311	.1715
4	.8573	1.0898	1.4413	.1543	.1509	.1311	.1715
5	.8573	1.1736	1.5261	.1543	.1509	.1219	.1715
6	.8916		1.6278	.1543	.1509		.1715
7	1.166	1.7939	1.8652	.1543		.1311	.1715
8	1.2346		1.933	.1543	.1844	.1475	.1715
9	.1372	.1677	.1696	1.4746	1.8442	3.3265	2.0919
10	.1372	.1311	.1526	2.5377	3.0864	2.8166	2.9334
11	.1372	.1311	.1311	3.155	3.2922		3.103
12	.1543		.1311	3.0864	3.2922	3.1184	2.9334
13	.1543			1.9204	3.155	3.0514	2.9334
14	.1543	.1311	.1311		3.1893	3.0849	2.8487
15			.1311		3.155	2.9675	2.7808
16			.1311		3.1207	2.934	2.6113
17			.1475		.1372	.1677	
18	.1677	.1677	.1715	1.2407	.1802	.1886	.1844
19	.1844	.1865	.1715	.1677	.1802	.2058	.1844
20	.1677	.1865	.1715	.1677	.1475	.2058	.1844
21	.1677	.1696	.1715	.1677	.1475	.2058	.1677
22	.1677	.1696	.1715	.1509	.1311	.1886	.1677
23	1.1233	1.4243	.1543	.1509	.1311	.1886	1.1736
24	1.2346	1.1401	1.3904	.1543	.1509	.1311	.1886
Max	**1.2346**	**1.7939**	**1.933**	**3.155**	**3.2922**	**3.3265**	**3.103**
Min	**.1372**	**.1311**	**.1311**	**.1509**	**.1311**	**.1219**	**.1677**
Avg	**.5735**	**.6518**	**.7063**	**.7804**	**1.1492**	**1.0778**	**1.1243**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
HATKANANGALE[029] BU 1163
Substation No/ Name :- 144039 / 33/11 KV CHOKAK S/STN
Feeder No / Name : 205 / 11Kv Rukadi Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0328	.0343	.0358	1.3032	1.2136	1.0631	.9259
2	.0328	.0343	.0358	1.3032	1.1145	1.0631	.9259
3	.0328	.0343	.0358	1.3032	1.2323	1.0631	.9259
4	.0339	.0343	.0358	1.3032	1.1317	1.1576	.9259
5	.0328	.0343	.0358	1.3032	1.1488	1.0631	.9259
6	.0328	.0514	.0358	.5144	1.166	1.0974	1.0288
7		.0343	.0358	1.4403	1.286	1.2346	1.1317
8	.0328		.0358	1.4746	1.3203	1.3717	1.1317
9	1.3717	1.989	2.1491	.0343	.0343	.0328	.0343
10	2.2634	2.4006	2.3487	.0343	.0343	.0343	.0358
11	2.4348	2.5377	2.4006	.0328	.0343		.0537
12	2.572	2.6063	2.4691	.0328		.0343	.0358
13	2.5034	2.7092	2.5377	.0328	.0343	.0343	.0358
14	2.2977	2.6155	2.2291		.0343	.0343	.0358
15	2.332	2.5377	2.2977	.0328	.0343	.0373	.0537
16	2.3663	2.332	2.0576	.0328	.0343	.0343	.0716
17	.0514		.0492	.0328		.0343	
18	.0514	.0537	.0686	.0686	.0328	.0343	.0514
19	.0514	.0537	.0857	.0686	.0492	.0514	.0686
20	.0686	.0358	.0857	.0686	.0328	.0514	.0686
21	.0514	.0358	.0857	.0686	.0328	.0514	.0514
22	.0514	.0358	.0857	.0514	.0373	.0514	.0343
23	.0343	.0358	1.3032	1.1317	1.0288	.8916	.0343
24	.0328	.0343	.0358	1.3032	1.0974	1.0631	.9259
Max	**2.572**	**2.7092**	**2.5377**	**1.4746**	**1.3203**	**1.3717**	**1.1317**
Min	**.0328**	**.0343**	**.0358**	**.0328**	**.0328**	**.0328**	**.0343**
Avg	**.8159**	**.9214**	**.8573**	**.5640**	**.5529**	**.5037**	**.4136**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
HATKANANGALE[029] BU 1163
Substation No/ Name :- 144040 / 33/11 KV HATKANGALE
Feeder No / Name : 201 / 11 KV Nimshirgaon AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305	.0328	.0305	.2187	.2134	.2622	.2134
2	.0305	.0328	.0305	.2187	.2134	.2294	.2134
3	.0305	.0328	.0305	.2187	.2134	.2294	.2134
4	.0305	.0328	.0305	.2187	.2134	.2622	.2286
5	.0457	.0328	.0305	.25	.2439	.2949	.2439
6	.0457	.0328	.0457	.3125	.3201	.426	.2743
7	.0457	.0655	.0457	.4374	.4268	.5243	.4062
8	.061	.0655	.061	.4999	.5944	.6062	.4999
9	.4268	.4752	.4877	.0324	.0305	.0492	.0312
10	.5898	.6874	.6882	.0492	.0312	.0625	.0457
11	.7045		.7209	.0655	.0625	.0625	.0457
12	.7537	.6874	.9012	.0655	.0312	.0625	.0457
13	.8029	.6874	.8192	.0655	.0625	.0312	.0457
14	.7701	.6562	.8029	.0492	.0625	.0312	.0457
15	.6882	.7773	.852	.0492	.0625	.0312	.0457
16	.7373	.7811	.8848	.0492	.0625	.0312	.0457
17	.0492	.0312	.0469	.0492	.0492	.0324	.0457
18	.0492	.0457	.0625	.0312	.0492	.0457	.0457
19	.0492	.0457	.0625	.0625	.0492	.061	.0457
20	.0492	.0457	.0625	.0625	.0492	.061	.0457
21	.0492	.0457	.0625	.0457	.0492	.061	.0457
22	.0492	.0457	.0312	.0457	.0328	.0457	.0457
23	.0328	.0305	.25	.2286	.2294	.2134	.0305
24	.0305	.0328	.0305	.25	.2134	.2622	.2134
Max	**.8029**	**.7811**	**.9012**	**.4999**	**.5944**	**.6062**	**.4999**
Min	**.0305**	**.0305**	**.0305**	**.0312**	**.0305**	**.0312**	**.0305**
Avg	**.2563**	**.2349**	**.2946**	**.1490**	**.1486**	**.1658**	**.1318**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
HATKANANGALE[029] BU 1163
Substation No/ Name :- 144040 / 33/11 KV HATKANGALE
Feeder No / Name : 202 / 11 KV Alate AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1562		.1562	.4534	.4999	.6226	.5312
2	.1562	.1638	.1562	.4687	.4687	.5898	.4999
3	.1562	.1966	.1562	.4999	.4687	.5898	.5312
4	.1562	.1966	.1562	.5312	.4687	.639	.5624
5	.1562	.2294	.1718	.4999	.5312	.6882	.6093
6	.2031	.2294	.1875	.5624	.8436	.852	.7343
7	.2187	.2458	.2031	1.2803	1.3592	1.4746	1.3279
8	.25	.2294	.2031	1.4998	1.5779	1.7859	1.5623
9	1.2498	1.278	1.2186	.1875	.1875	.1966	.1562
10	2.0153	1.9372	1.9498	.2294	.1875	.1943	.1406
11	2.1628	2.2184	2.1628	.213	.1875	.2187	.1406
12	2.4577	2.2497	2.1464	.1802	.1875	.1875	.1406
13	2.3102	2.0622	2.13	.1802	.2187	.1562	.125
14	2.2119	2.1247	2.13	.1638	.1875	.125	.125
15	2.2119	2.0934	2.0809	.1638	.1875	.1562	.1406
16	2.1956	2.1559	2.0645	.1802	.2187	.1562	.125
17	.1638		.1562	.1966	.1802	.1875	.1562
18	.2294	.2343	.2267	.2591	.2622	.2187	.1875
19	.3038	.2656	.3125	.2812	.2949	.2656	.2656
20	.2949	.2656	.3125	.2812	.2949	.2812	
21	.2785	.25	.2812	.2656	.2622	.25	.2343
22	.2458	.2031	.2267	.2187	.213	.2031	.1875
23	.1966	.2263	.4374	.4843	.5898	.4999	.1562
24	.1875	.1966	.1562	.4687	.5155	.6226	.5312
Max	**2.4577**	**2.2497**	**2.1628**	**1.4998**	**1.5779**	**1.7859**	**1.5623**
Min	**.1562**	**.1638**	**.1562**	**.1638**	**.1802**	**.125**	**.125**
Avg	**.8403**	**.8751**	**.8076**	**.4062**	**.4330**	**.4651**	**.3987**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
HATKANANGALE[029] BU 1163
Substation No/ Name :- 144040 / 33/11 KV HATKANGALE
Feeder No / Name : 203 / 11 Kv Atigre Vg GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.2801	.2829	.2561	.2641	.2801	.2641
2	.2829	.2614	.2641	.2561	.2641	.2614	.2452
3	.2641	.2614	.2641	.2481	.2641	.2614	.2452
4	.2641	.2614	.2829	.2561	.2641	.2801	.2452
5	.2614		.2829	.2926	.2829	.3174	.2452
6	.3734		.3395	.3292	.3206	.3361	.3206
7	.5041	.4294	.4338	.3292	.3961	.4108	.4024
8	.3921	.3921	.415	.3292	.4715	.4481	.439
9	.4294	.3921	.415	.3292	.415	.4481	.3898
10	.3921	.3658	.4108	.2614	.3658	.3658	.3961
11	.3734	.3292	.3734	.2241	.3292	.3658	.3395
12	.3361	.3292	.3361	.2054	.3292	.3292	.3206
13	.2987	.2926	.3361	.1867	.2926	.3292	.2829
14	.2987	.2561	.3174	.1867	.2926	.2926	.2829
15	.3361	.3292	.3547	.168	.2804	.2926	.3018
16	.2987	.3292	.3361	.1867	.2926	.2926	.3018
17	.3734	.3292	.3475	.2054	.3547	.3292	.3206
18		.4715	.439	.2926	.4108	.4527	.3961
19	5.5826	.5658	.5487	.4024	.5228	.547	.5281
20	.5415	.5281	.5121	.4755	.5041	.5093	.4904
21	.5228	.4904	.4755	.4715	.4854	.4904	.4904
22	.4108	.4338	.4024	.415	.4294	.3961	.3961
23	.3361	.3206	.3292	.2829	.2801	.3206	.3206
24	.2829	.2801	.2829	.2926	.2641	.2801	.2829
Max	**5.5826**	**.5658**	**.5487**	**.4755**	**.5228**	**.547**	**.5281**
Min	**.2614**	**.2561**	**.2641**	**.168**	**.2641**	**.2614**	**.2452**
Avg	**.5843**	**.3604**	**.3659**	**.2868**	**.3490**	**.3599**	**.3436**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
HATKANANGALE[029] BU 1163
Substation No/ Name :- 144040 / 33/11 KV HATKANGALE
Feeder No / Name : 206 / Jathar Industrial SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6194	1.6385	1.7147	1.6385	1.5242	1.6385	1.7147
2	1.6194	1.6385	1.6766	1.6766	1.4861	1.6004	1.6766
3	1.6194	1.6766	1.6385	1.6385	1.4861	1.6004	1.6385
4	1.6194	1.6385	1.6385	1.6004	1.5242	1.6385	1.6766
5	1.7147	1.6766	1.6766	1.6385	1.5242	1.6766	1.6766
6	1.7147	1.6766	1.7147	1.6004	1.5623	1.6766	1.7147
7	1.7147	1.7147	1.6766	1.7147	1.5623	1.6385	1.7528
8	1.7147	1.6385	1.6766	1.3336	1.5623	1.6385	1.406
9	1.7147	1.7147	1.7147	1.3717	1.6385	1.7147	1.7147
10	1.6385	1.6766	1.6385	1.3336	1.5242	1.6766	1.7147
11	1.6766	1.7147	1.3108	1.3717	1.6004	1.6004	1.7147
12	1.6385	1.7147	1.6385	1.2955	1.6004	1.6385	1.6194
13	1.6385	1.6004	1.6385	1.3336	1.5623	1.6766	1.5242
14	1.6004	1.6766	1.6385	1.3336	1.6385	1.6385	1.5242
15	1.6766	1.6766	1.6385	1.2955	1.6004	1.7147	1.6194
16	1.6766	1.7147	1.7147	1.3336	1.6766	1.6004	
17	1.6385	1.6766	1.6385	1.3336	1.6385	1.6766	1.1431
18	1.6385	1.6766	1.7147	1.3336	1.6004	1.6766	1.1812
19	1.6385	1.6766	1.7147	1.3336	1.6766	1.6766	1.6766
20		1.6766	1.6385	1.4098	1.6004	1.6766	1.7147
21	1.7147	1.6766	1.6004	1.5623	1.6004	1.6766	1.6766
22	1.6385	1.6766	1.7147	1.6004	1.6385	1.7147	1.7528
23	1.6766	1.6766	1.7147	1.6194	1.6004	1.6766	1.6766
24	1.5242	1.6766	1.6766	1.6385	1.5623	1.6385	1.7147
Max	**1.7147**	**1.7147**	**1.7147**	**1.7147**	**1.6766**	**1.7147**	**1.7528**
Min	**1.5242**	**1.6004**	**1.3108**	**1.2955**	**1.4861**	**1.6004**	**1.1431**
Avg	**1.6551**	**1.6750**	**1.6566**	**1.4726**	**1.5829**	**1.6576**	**1.6184**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
HATKANANGALE[029] BU 1163
Substation No/ Name :- 144040 / 33/11 KV HATKANGALE
Feeder No / Name : 207 / 11KV ALATE VG GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5281	.5228	.5093	.439	.3772	.4668	.4527
2	.5281	.5041	.4904	.4024	.415	.4668	.4527
3	.5281	.5041	.4904	.4024	.415	.4481	.4527
4	.5281	.5228	.5281	.439	.4338	.4481	.4904
5	.5658	.5788	.5281	.439	.4527	.4668	.4904
6	.6602	.5975	.5658	.4755	.5281	.5601	.5658
7	.7545	.7095	.6413	.5121	.5658	.5975	.4024
8	.7167	.6722	.6413	.5487	.5658	.6348	.5487
9	.7167	.8589	.7545	.6219	.7167	.6722	.6379
10	.7655	.8413	.8589	.4854	.7316	.695	.7545
11	.8215	.9145	.8215	.4108	.7316	.8048	.7545
12	.8589	.7316	.7842	.4108	.7682	.7316	.7167
13	.6722	.6219	.7468	.3734	.7316	.5487	.7167
14	.7842	.5853	.7468	.3361	.5853	.6219	.7167
15		.8048	.6722	.3921	.5487	.7316	.6602
16	.7095	.8048	.7842	.4108	.6584	.7682	.7545
17	.6348	.7316	.6219	.4481	.6722	.8048	.5658
18	.7468	.7167	.8048	.2561	.6348	.7922	.7167
19	.7842	.7922	.7316	.6584	.7468	.7545	.7167
20	.7468	.7167	.695	.7682	.7138	.7545	.679
21	.6722	.7545	.6584	.6036	.6348	.7167	.679
22	.5975	.7545	.5121	.5281	.5975	.6036	.6036
23	.5601	.6413	.4024	.415	.4854	.5281	.5658
24	.5658	.5228	.5281	.4024	.3772	.4854	.415
Max	**.8589**	**.9145**	**.8589**	**.7682**	**.7682**	**.8048**	**.7545**
Min	**.5281**	**.5041**	**.4024**	**.2561**	**.3772**	**.4481**	**.4024**
Avg	**.6716**	**.6836**	**.6466**	**.4658**	**.587**	**.6293**	**.6045**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
HATKANANGALE[029] BU 1163
Substation No/ Name :- 144040 / 33/11 KV HATKANGALE
Feeder No / Name : 208 / Laxminagar Vg GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0724	.056	.0362	.0366	.0362	.0373	.0362
2	.0724	.056	.0362	.0366	.0362		.0362
3	.0724	.056	.0362	.0377	.0362	.0373	.0362
4	.0905	.056	.0362	.0362	.0362	.056	.0362
5	.1086	.056	.0362	.0366	.0362	.056	.0362
6	.1086	.056	.0543	.0732	.0543	.056	.0543
7	.1086	.0747	.0543	.0732	.0724	.0934	.0914
8	.1086	.0747	.0724	.0732	.0905	.0934	.0709
9	.1086	.0934	.0905	.0732	.0724	.0934	.1097
10		.0732	.0934	.0747	.0732	.0732	.1086
11	.0747	.0366	.112	.0747	.0732	.0732	.1086
12	.0747	.0732	.0934	.0747	.0732	.0732	.1086
13	.0747	.0732	.0747	.0747	.0732	.0732	.1086
14	.0747	.0732	.0747	.0747	.0732	.0732	.1086
15	.0747	.0366	.0747	.0747	.0732	.0732	.0724
16	.0934	.0366	.0747	.0747	.0732	.0366	.1086
17	.0934	.0732	.0732	.0747		.0732	.1086
18	.112	.0905	.0366	.0366		.0905	.0724
19	.112	.0724	.1097	.0732		.1086	.0543
20		.0905	.0732	.0732		.0905	
21	.0934	.0905	.0732	.0724	.0934	.0905	.1086
22	.0747	.0724	.1097	.0724	.0753	.0724	.0724
23	.0747	.0724	.0732	.0724	.056	.0543	.0543
24	.0724	.056	.0543	.0366	.0543	.056	.0543
Max	**.112**	**.0934**	**.112**	**.0747**	**.0934**	**.1086**	**.1097**
Min	**.0724**	**.0366**	**.0362**	**.0362**	**.0362**	**.0366**	**.0362**
Avg	**.0886**	**.0666**	**.0689**	**.0630**	**.0631**	**.0711**	**.0764**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
HATKANANGALE[029] BU 1163
Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)
Feeder No / Name : 201 / 11 KV Hingangaon Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.763	.6962	.6371	.0332	.0328	.0335	.0332
2	.763	.6962	.6371	.0332	.0328	.0335	.0332
3	.78	.6882	.6706	.0332	.0328	.0838	.0332
4	.78	.6882	.6706	.0332	.0328	.0335	.0332
5	.78	.6882	.6706	.0332	.0328	.0335	.0332
6	.8139	.6882	.6706	.0332	.0328	.0335	.0332
7	.8478	.8288	.7042	.0332	.0328	.0335	.0332
8	.9156	.8951	.8718	.0332	.0328	.0335	.0332
9	.0335	.0332	.0335	.9054	1.2266	1.3435	1.3108
10	.0335	.0332	.0335	1.6095	1.2266	1.6712	1.704
11	.0335	.0332		1.7101	1.7901	1.7695	1.6907
12	.0335	.0332		1.7436	1.8896	1.7368	1.6712
13	.0335	.0332	.0335	1.7436	1.8896		1.704
14	.0335	.0332	.0335	1.8107	1.8896	1.6907	1.6712
15	.0335	.0332	.0335	1.6766	1.7238	1.6907	1.6385
16	.0335	.0332	.0335	1.6095	1.5581	1.6575	1.6278
17	.0328	.0335	.0332	.0328	.0335	.0328	.0381
18	.0328	.0335	.0332	.0328	.0335	.0328	.0381
19	.0328	.0335	.0332	.0328	.0335	.0328	.0381
20	.0332	.0335	.0332	.0328	.0335	.0332	.0381
21	.0332	.0335		.0328	.0335	.0332	.0381
22	.0332	.0335	.0332	.0328	.0335	.0332	.0381
23	.663	.6036	.0332	.0332	.0335	.0332	.6371
24	.763	.6962	.6371	.0332	.0328	.0335	.0332
Max	**.9156**	**.8951**	**.8718**	**1.8107**	**1.8896**	**1.7695**	**1.704**
Min	**.0328**	**.0332**	**.0332**	**.0328**	**.0328**	**.0328**	**.0332**
Avg	**.3473**	**.3181**	**.3129**	**.5557**	**.5718**	**.5280**	**.5909**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
HATKANANGALE[029] BU 1163
Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)
Feeder No / Name : 202 / 11 KV Warana Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0663	.0678	.0671	.78	.8139	.6706	.6783
2	.0663	.0678	.0671	.78	.8139	.6706	.6783
3	.0663	.0678	.0671	.78	.78	.6706	.6783
4	.0663	.0678	.0671	.78	.78	.6706	.6783
5	.0829	.0678	.0671	.78	.763	.8048	.6783
6	.0829	.0848	.0671	.8478	.763	.8501	.6952
7	.0829	.0848	.0838	.9156	.8478	.9055	.7291
8	.0663	.0678	.0671	.9326	.8648	.8383	1.1022
9	1.0562	1.1022	1.4419	.0838	.0509	.0678	.0678
10	1.358	1.4582	1.4922	.0503	.0509	.0509	
11	1.4586	1.4582	1.5257	.0503	.0509	.0509	.0509
12	1.4251	1.4582	1.5592	.0503	.0509	.0509	.0509
13	1.3916	1.6956	1.576	.0671	.0678		.0678
14	1.4754	1.6448	1.4754	.0503	.0678	.0509	.0509
15	1.4754	1.6278	1.3748	.0503	.0678	.0509	.0509
16	1.4754	1.5091	1.3413	.0503	.0678	.0509	.0332
17	.0678	.0503	.0509	.0509	.0503	.0509	.0332
18	.0678	.0671	.0509	.0848	.0503	.0509	.0497
19	.0848	.0838	.0848	.0678	.0671	.0663	.0663
20	.1017	.0838	.0848	.0678	.0671	.0848	.0663
21	.1017	.0838		.0678	.0503	.0848	.0497
22	.0848	.0671	.0678	.0678	.0503	.0509	.0497
23	.0678	.0671	.8987	.8478	.7042	.6783	.0497
24	.0663	.0678	.0671	.8987	.8478	.6706	.6952
Max	**1.4754**	**1.6956**	**1.576**	**.9326**	**.8648**	**.9055**	**1.1022**
Min	**.0663**	**.0503**	**.0509**	**.0503**	**.0503**	**.0509**	**.0332**
Avg	**.5141**	**.5459**	**.5933**	**.3834**	**.3662**	**.3562**	**.3196**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
HATKANANGALE[029] BU 1163
Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)
Feeder No / Name : 203 / 11KV Kumbhoj Gaothan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3326	.3326	.2587	.3258	.3734	.2587	.2534
2	.3326	.3326	.2587	.3258	.3361	.2587	.2534
3	.3326	.3326	.2957	.3258	.3361	.3326	.3258
4	.3326	.3326	.2957	.3258	.3361	.3326	.3258
5	.3696	.4066	.2957	.3258	.4108	.3326	.3258
6	.5175	.5544	.3326	.5068	.5228	.3696	.4706
7	.5914	.5975	.5544	.5792	.6348	.5914	.6154
8	.5914	.5914	.5544	.6516	.5975	.5914	.5792
9	.4805	.5068	.4435	.5544	.5068	.5014	.5014
10	.4435	.4344	.5175	.4805	.5068	.4298	.4656
11	.4805	.4344	.5175	.4435	.5068	.394	.4298
12	.4435	.4344	.5175	.4805	.4706	.394	.4298
13	.4435	.362	.4435	.4435	.4344		.4607
14	.4435	.4344	.4435	.4435	.4344		.4298
15	.4435	.4344	.4435	.4435	.4344	.394	.3898
16	.4435	.4706	.4435	.4435	.4344	.4298	.4066
17	.4961	.5544	.4706	.4252	.5175	.4706	.4066
18	.6241	.5914	.5792	.567	.5914	.5121	.5544
19	.6805	.7762	.724	.6584	.7392	.6722	.7392
20	.695	.5914	.6878	.7023	.7023	.7095	
21	.6653	.5544		.6348	.6283	.6154	.5914
22	.5914	.4435	.6878	.5228	.5914	.543	.5175
23	.4435	.3696	.3982	.4108	.3326	.362	.3696
24	.3696	.3696	.2957	.3982	.3734	.3326	.2534
Max	**.695**	**.7762**	**.724**	**.7023**	**.7392**	**.7095**	**.7392**
Min	**.3326**	**.3326**	**.2587**	**.3258**	**.3326**	**.2587**	**.2534**
Avg	**.4828**	**.4684**	**.4547**	**.4758**	**.4897**	**.4467**	**.4389**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
HATKANANGALE[029] BU 1163
Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)
Feeder No / Name : 204 / 11 KV Bahubali Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0332	.0332	.0335	.3812	.4144	.4191	.4144
2	.0332	.0332	.0335	.3812	.4144	.4191	.4144
3	.0332	.0332	.0335	.3812	.4144	.4858	.4973
4	.0332	.0332	.0335	.3812	.4144	.503	.4973
5	.0497	.0332	.0335	.3812	.431	.503	.4973
6	.0497	.0497	.0335	.3978	.4475	.57	.4973
7	.0497	.0663	.0503	.547	.5636	.6539	.5636
8	.0497	.0497	.0503	.5636	.663	.6874	.6464
9	.4862	.5636	.5868	.0503	.0497	.0332	.0497
10	.8886	.9448	.9892	.0503	.0497	.0497	.0497
11	.9892	.9448	1.0227	.0503	.0332	.0332	.0509
12	1.0395	.9448	1.073	.0503	.0332	.0332	.0497
13	1.0227	1.0442	1.0059	.0335	.0332		.0328
14	1.073	1.0111	.9724	.0335	.0332	.0332	.0332
15	1.073	1.0111	.9724	.0335	.0332	.0332	.0328
16	1.073	.9945	.9221	.0335	.0332	.0332	.0332
17	.0332	.0503	.0332	.0332	.0335	.0332	.0332
18	.0332	.0503	.0332	.0332	.0335	.0332	.0497
19	.0332	.0503	.0497		.0335	.0332	.0663
20	.0497	.0503	.0497	.0497	.0503	.0497	.0663
21	.0497	.0503		.0497	.0503	.0497	.0663
22	.0497	.0503	.0497	.0497	.0503	.0497	.0497
23	.0332	.0503	.3812	.431	.4024		.0332
24	.0332	.0332	.0503	.3812	.431	.4191	.4144
Max	**1.073**	**1.0442**	**1.073**	**.5636**	**.663**	**.6874**	**.6464**
Min	**.0332**	**.0332**	**.0332**	**.0332**	**.0332**	**.0332**	**.0328**
Avg	**.3455**	**.3407**	**.3693**	**.2077**	**.2144**	**.2345**	**.2141**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
HATKANANGALE[029] BU 1163
Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)
Feeder No / Name : 205 / 11 KV Narande Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.1844	.6344	.7888	.8215	.8402
2	.1886	.1886	.1844	.6344	.7716	.8215	.8402
3	.1886	.1886	.1844	.6344	.7716	.8718	.8916
4	.1886	.1886	.1844	.6344	.7716	.8718	.8916
5	.1886	.1886	.1844	.6344	.8059	.8718	.8916
6	.1886	.1886	.1844	.6516	.8402	.9389	.9602
7	.1886	.1886	.1844	.8573	1.0117	.9892	1.1488
8	.1886	.1886	.1844	1.046	1.0802	1.0395	1.2003
9	1.073	1.0117	1.1904	.1509	.1543	.1543	.1886
10	1.5257	1.5432	1.5424	.1509	.1543	.1372	.1886
11	1.5257	1.5432	1.576	.1509	.1543	.1372	.1715
12	1.5257	1.5432	1.6766	.1509	.1543	.1372	.1715
13	1.5424	1.749	1.6095	.1509	.1543		.1715
14	1.5089	1.7318	1.5424	.1509	.1543	.1715	.1715
15	1.5089	1.6804	1.5424	.1509	.1543	.1715	.1715
16	1.3748	1.6118	1.4419	.1509	.1543	.1715	.1886
17	.1715	.1677	.1886	.1543	.1509	.1715	.1886
18	.1886	.1844	.1886	.1715	.1677	.1886	.1886
19	.1886	.1844	.1886	.1715	.1677	.1886	.2058
20	.1886	.1844	.1886	.1715	.1677	.1886	.2058
21	.1886	.1844		.1715	.1677	.1886	.2058
22	.1886	.2347	.1886	.1715	.1677	.1886	.2058
23	.1886	.1844	.9088	.823	.788	.9431	.2058
24	.1715	.1886	.1844	.9088	.823	.8215	.9431
Max	**1.5424**	**1.749**	**1.6766**	**1.046**	**1.0802**	**1.0395**	**1.2003**
Min	**.1715**	**.1677**	**.1844**	**.1509**	**.1509**	**.1372**	**.1715**
Avg	**.6070**	**.6432**	**.6797**	**.4032**	**.4449**	**.4863**	**.4765**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
HATKANANGALE[029] BU 1163
Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)
Feeder No / Name : 206 / 11 KV Kumbhoj AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6783	.583	.503	.0332	.0328	.0335	.0332
2	.6783	.583	.503	.0332	.0328	.0335	.0332
3	.6443	.583	.5365	.0332	.0328	.0335	.0332
4	.6443	.583	.5365	.0332	.0328	.0335	.0332
5	.6443	.583	.5365	.0332	.0328	.0335	.0332
6	.6783	.6226	.5365	.0332	.0328	.0335	.0332
7	.6783	.6478	.5365	.0332	.0328	.0335	.0332
8	.7122	.6802	.57	.0332	.0328	.0335	.0332
9	.0335	.0332	.0335	.6706	.8951	.9503	.8848
10	.0335	.0332	.0335	1.0059	.8951	1.2125	1.1797
11	.0335	.0332	.0335	1.1401	1.2597	1.2452	1.2266
12	.0335	.0332	.0335	1.2071	1.2266	1.2308	1.2125
13	.0335	.0332	.0335	1.2071	1.2266		1.1469
14	.0335	.0332	.0335	1.1736	1.2266	1.1603	1.1142
15	.0335	.0332	.0335	1.1736	1.2597	1.1603	1.0814
16	.0335	.0332	.0335	1.1736	.8619	1.2266	1.0513
17	.0328	.0335	.0332	.0324	.0335	.0328	.0381
18	.0328	.0335	.0332	.0324	.0335	.0328	.0381
19	.0328	.0335	.0332	.0328	.0335	.0328	.0381
20	.0332	.0335	.0332	.0328	.0335	.0332	.0381
21	.0332	.0335		.0328	.0335	.0332	.0381
22	.0332	.0335	.0332	.0328	.0335	.0332	.0381
23	.583	.5365	.0332	.0332	.0335	.0332	.5365
24	.6783	.6081	.503	.0332	.0328	.0335	.0332
Max	**.7122**	**.6802**	**.57**	**1.2071**	**1.2597**	**1.2452**	**1.2266**
Min	**.0328**	**.0332**	**.0332**	**.0324**	**.0328**	**.0328**	**.0332**
Avg	**.2952**	**.2699**	**.2273**	**.3867**	**.3909**	**.3791**	**.4151**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
HATKANANGALE[029] BU 1163
Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)
Feeder No / Name : 207 / 11KV Bahubali-Nej Vg GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0739	.0924	.0739	.0924	.0924	.0739	.0739
2	.0739	.0924	.0739	.0924	.0924	.0739	.0739
3	.0739	.0924	.1109	.0924	.0924	.0739	.0739
4	.0739	.0924	.1109	.0924	.0924	.0739	.0739
5	.1109	.1109	.1109	.0924	.1109	.0739	.0739
6	.1294	.1294	.1109	.1109	.1294	.0739	.1109
7	.1478	.1478	.1478	.1478	.1478	.1478	.1109
8	.1663	.1663	.1848	.1294	.1478	.1478	.1109
9	.1478	.1848	.1478	.1478	.1848	.1848	.1663
10	.1478	.1478	.1663	.1478	.1848	.1478	.1663
11	.1663	.1478	.1294	.1294	.1478	.1478	.1109
12	.1478	.1478	.1294	.1478	.2218	.1478	.1663
13	.1109	.1848	.1663	.1478	.1663		.1294
14	.1109	.1294	.1478	.1478	.1663	.1294	.1294
15	.1109	.1478	.1294	.1109	.1848	.1294	.1478
16	.1848	.1663	.1478	.1478	.1294	.1478	.1294
17	.2033	.1848	.1848	.1663	.1663	.1663	.1294
18	.1478	.1848	.1848	.1663	.1478	.1848	.1109
19	.1478	.2402	.2402	.1478	.2033	.1848	.2218
20	.1478	.2218	.2218	.1478	.1848	.1848	.2054
21	.1478	.1848		.1294	.1478	.1478	.1848
22	.1294	.1478	.1294	.1109	.1109	.1294	.1109
23	.1109	.1109	.1109	.1109	.1109	.1109	.0924
24	.0924	.0924	.1109	.1109	.0924	.1109	.0924
Max	**.2033**	**.2402**	**.2402**	**.1663**	**.2218**	**.1848**	**.2218**
Min	**.0739**	**.0924**	**.0739**	**.0924**	**.0924**	**.0739**	**.0739**
Avg	**.1294**	**.1478**	**.1422**	**.1278**	**.1440**	**.1302**	**.1248**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
HATKANANGALE[029] BU 1163
Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)
Feeder No / Name : 208 / Parshwanath LIS PURELY LIS FEEDERS
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.3086	.4854	.4207	.4161	.4207	.3887
4	.3086	.5201	.5609	.4508	.5609	.5182
5	.3429	.5721	.5609	.4508	.5609	.5182
6	.3429	.5721	.631	.4854	.7011	.5992
7	.4801	.6241	.5959	.5895	.7011	.5506
8	.7373	.7802	.8063	.6415	.7011	.5668
9	.7888	.664	.7712	.5992	.6415	.5895
10	.8063	.7449	.8063	.5992	.6588	.6068
11	.8063	.7449	.8063	.6154	.6762	.6068
12	.8063	.7449	.8063	.6478	.6588	.6588
13	.8063	.6802	.7537	.664		.6588
14	.8063	.7125	.8063	.664	.7108	.6588
15	.8063	.7611	.8063	.664	.7108	.6415
16	.8063	.6802	.8063	.6154	.7282	.6485
17	.7802	.7537	.7287	.631	.6588	.5609
18	.7802	.7537	.7287	.631	.6588	
Max	**.8063**	**.7802**	**.8063**	**.664**	**.7282**	**.6588**
Min	**.3086**	**.4854**	**.4207**	**.4161**	**.4207**	**.3887**
Avg	**.6571**	**.6746**	**.7122**	**.5853**	**.6499**	**.5848**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
HATKANANGALE[029] BU 1163
Substation No/ Name :- 144113 / 33/11Kv Awade Park
Feeder No / Name : 201 / Tamadalage VG GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1509	.132	.12	.132	.1509	.1372
2	.1509	.132	.132	.1029	.132	.1509	.12
3	.1509	.132	.1509	.1029	.132	.132	.12
4	.1509	.1698	.1886	.1029	.132	.132	.12
5	.1886	.1886	.1698	.1372	.1886	.3018	.1715
6	.2353	.2452	.2452	.2058	.2452	.2263	.1886
7	.3109	.3206	.2829	.2743	.2987	.2829	.2572
8	.2534	.2641	.2641	.2401	.2452	.2641	.2401
9	.2641	.2401	.3018	.2401	.3018	.2641	.2229
10	.2829	.2743	.3018	.3018	.2058	.2987	.3018
11	.3018	.2743	.3018	.2452	.3086	.2987	.2829
12	.2829	.2572	.2641	.2641	.3429	.3142	.3018
13	.2452	.2058	.2452	.2075	.2058	.2587	.2452
14	.2075	.2058	.2263	.2075	.2058	.2263	.2641
15	.2075	.2058	.1903	.2075	.2058	.2801	.2641
16	.2829	.2401	.2452	.1886	.2058	.2614	.2641
17	.2263	.2263	.2263	.2263	.2058	.2641	.2263
18	.2641	.2452	.2229	.3206	.2452	.2401	.3018
19	.415	.4527	.3772	.3961	.415	.3772	.4527
20	.415	.4527	.3429	.415	.415	.4115	.415
21	.3961	.415	.3086	.3961	.3961	.3429	.3018
22	.3206	.3395	.2401	.3018	.2829	.2743	.2452
23	.1886	.1886	.1715	.2303	.2263	.1715	.1886
24	.1698	.1509	.1509	.1372	.1463	.1698	.1372
Max	**.415**	**.4527**	**.3772**	**.415**	**.415**	**.4115**	**.4527**
Min	**.1509**	**.132**	**.132**	**.1029**	**.132**	**.132**	**.12**
Avg	**.2526**	**.2491**	**.2368**	**.2322**	**.2425**	**.2539**	**.2404**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
HATKANANGALE[029] BU 1163
Substation No/ Name :- 144113 / 33/11Kv Awade Park
Feeder No / Name : 202 / Nimshirgaon Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0156	.016	.016	.1372	.1406	.192	.1524
2	.0156	.016	.016	.1372	.1406	.208	.1524
3	.0156	.016	.016	.1372	.1406	.16	.1524
4	.0156	.016	.016	.1372	.1406	.16	.1524
5	.0156	.016	.016	.1677	.1562	.192	.1829
6	.0156	.016	.016	.2134	.2031	.3201	.3048
7	.0156	.016	.032	.2896	.3437	.4161	.3353
8	.0156	.016	.032	.3201	.4374	.4531	.3963
9		.2743	.3041	.0152	.0156	.016	.0305
10		.4572	.4843	.032	.0305	.0312	.0312
11	.3361	.5335	.4999	.016	.0305	.0312	.0312
12	.5761	.5182	.5624	.032	.0305	.0312	.0312
13	.5921	.503	.578	.016	.0305	.0156	.0312
14	.5441	.5182	.5937	.016	.0305	.0156	.0312
15	.5921	.503	.5624	.016	.0305	.0156	.0312
16	.6081	.5182	.5468	.016	.0305	.0156	.0312
17	.5601	.032	.0312	.032	.0152	.0312	.0312
18	.032	.032	.0152	.0312	.032	.0305	.0312
19	.032	.032	.0305	.0312	.032	.0305	.0312
20	.032	.032	.0305	.0312	.032	.0305	.0312
21	.032	.032	.0305	.0312	.032	.0152	.0312
22	.016	.032	.0152	.0312	.016	.0152	.0156
23	.016	.016	.1372	.1562	.16	.1524	.0156
24	.0156	.016	.016	.1372	.1406	.16	.1524
Max	**.6081**	**.5335**	**.5937**	**.3201**	**.4374**	**.4531**	**.3963**
Min	**.0156**	**.016**	**.0152**	**.0152**	**.0152**	**.0152**	**.0156**
Avg	**.1868**	**.1741**	**.1916**	**.0908**	**.0997**	**.1141**	**.1007**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
HATKANANGALE[029] BU 1163
Substation No/ Name :- 144113 / 33/11Kv Awade Park
Feeder No / Name : 203 / 11 KV Hatkanangale Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0156	.0156	.0312	.0914	.1094	.1406	.0914
2	.0156	.0156	.0156	.0914	.0937	.1406	.0914
3	.0156	.0156	.0156	.0914	.0937	.125	.0914
4	.0156	.0156	.0156	.0914		.1406	.0914
5	.0156	.0156	.0156	.1219	.0937	.1562	.0914
6	.0156	.0156	.0156	.1524	.125	.1875	.1524
7	.0156	.0156	.0156	.1829	.2031	.1875	.1677
8	.0156	.0156	.0156	.2134	.2187		.1677
9	.1372	.1524	.1406	.0152	.0156	.0156	.0152
10	.2031	.2591	.2187	.0156	.0152	.0156	
11	.25	.2896	.2812	.0156	.0152	.0156	.0156
12	.2968	.2743	.2968	.0156	.0152	.0156	.0156
13	.2812	.3048	.2968	.0156	.0152	.0156	.0156
14	.2968	.3201	.2968	.0156	.0152	.0156	.0156
15	.2812	.3048	.2968	.0156	.0152	.0156	.0156
16	.2968	.2896	.2343	.0156	.0152	.0156	.0156
17	.0156	.0156	.0156	.0156	.0152	.0156	.0156
18	.0156	.0312	.0152	.0156	.0156	.0152	.0156
19	.0156	.0312	.0152	.0156	.0312	.0152	.0156
20	.0156	.0312	.0152	.0156	.0312	.0152	.0156
21	.0156	.0312		.0156	.0312	.0152	.0156
22	.0156	.0312	.0152	.0156	.0312	.0152	.0156
23	.0156	.0312	.0914	.1094	.1094	.0914	.0156
24	.0156	.0156	.0312	.0914	.1094	.125	.0914
Max	**.2968**	**.3201**	**.2968**	**.2134**	**.2187**	**.1875**	**.1677**
Min	**.0156**	**.0156**	**.0152**	**.0152**	**.0152**	**.0152**	**.0152**
Avg	**.0955**	**.1057**	**.1044**	**.0606**	**.0623**	**.0657**	**.0545**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
HATKANANGALE[029] **BU 1163**
Substation No/ Name :- 144113 / 33/11Kv Awade Park
Feeder No / Name : 204 / 11 KV Ganeshnagar **SEPARATED GAOTHAN FEEDERS**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0566	.0514	.0377	.0566	.0514
2	.0566	.0566	.0566	.0514	.0377	.0566	.0514
3	.0566	.0377	.0377	.0514	.0377	.0566	.0514
4	.0566	.0566	.0566	.0514	.0377	.0377	.0514
5	.0566	.0566	.0377	.0514	.0377	.0377	.0514
6	.0549	.0377	.0377	.0514	.0362	.0754	.0514
7	.0732	.0566	.0566	.0514	.0543	.0754	.0514
8	.0724	.0754	.0943	.0514	.0724		.0514
9	.0754	.1029	.1132	.0686	.0905	.1132	.0857
10	.1132	.12	.128	.0754	.1029	.1267	.1307
11	.1132	.1372	.1463	.1132	.1372	.1307	.1494
12	.1509	.1372	.1463	.1132	.1543	.1294	.132
13	.132	.1372	.128	.0943	.12	.1109	.1132
14	.132	.1372	.1294	.0943	.1372	.1417	.112
15	.132	.1543	.1463	.0943	.1543	.1478	.112
16	.1509	.1715	.1417	.0754	.1372	.1478	.112
17	.1698	.1509	.1132	.0566	.1543	.132	.1132
18	.132	.1509	.12	.0754	.1132	.1372	.1132
19	.132	.1132	.12		.1132	.12	.1132
20	.1132	.1132	.1029	.0754	.1132	.12	.0943
21	.1132	.0943	.0857	.0754	.0943	.1029	.0754
22	.0754	.0943	.0686	.0566	.0754	.0857	.0943
23	.0754	.0943	.0686	.0543	.0754	.0857	.0754
24	.0566	.0566	.0566	.0686	.0549	.0754	.0686
Max	**.1698**	**.1715**	**.1463**	**.1132**	**.1543**	**.1478**	**.1494**
Min	**.0549**	**.0377**	**.0377**	**.0514**	**.0362**	**.0377**	**.0514**
Avg	**.0979**	**.1**	**.0937**	**.0697**	**.0908**	**.1001**	**.0877**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
JAYSINGPUR[030] **BU 1171**
Substation No/ Name :- 144036 / 33/11KV SHIROL
Feeder No / Name : 201 / 11KV Udagaon **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0762	.0762	1.2193	.9526	1.1431	.7049
2	.0189	.0762	.0762	1.2003	.9526	1.1431	.7049
3	.0189	.0762	.0762	1.2003	.9526	1.1431	.6859
4	.0189	.0762	.0762	1.1812	.9907	1.1431	.6859
5	.0189	.0762	.0762	1.1812	.9907	1.1812	.7621
6	.0189	.0762	.0762	1.3146	1.0479	1.2193	.8573
7	.0189	.0762	.0762	1.448		1.448	1.0669
8	.0189	.0762		1.1241	1.3527	1.3717	1.1431
9	1.6004	1.7718	1.3413	.0762	.0762	.0762	.0762
10	2.21	2.3815	2.0348	.0762	.0762	.0762	.0762
11	2.5149	2.4768	2.2634	.0762	.0762	.0762	.0762
12	2.4387	2.4958	2.1874		.0762	.0762	.0762
13	2.21	2.4768	2.079	.0762	.0762	.0762	.0762
14	2.2862	2.4768	2.0287	.0762	.0762	.0762	.0762
15	2.1719	2.4577	2.0008	.0762	.0762	.0762	.0762
16	1.9052	2.3243	1.9669	.0762	.0762	.0762	.0762
17	.0762	.0762	.0762	.0762	.0762	.0762	.0166
18	.0762	.0762	.0762	.0762	.0762	.0762	.0177
19	.0762	.0762	.0762	.0762	.0762	.0762	.0183
20	.0762		.0762	.0762	.0762	.0762	.0185
21	.0762	.0762	.0762	.0762	.0762	.0762	.0183
22	.0762	.0762	.0762	.0762	.0762	.0762	.0183
23	.0762	.0762	1.2574	.9526	1.1431	.743	.0168
24	.0187	.0762	.0762	1.2384	.9717	1.1431	.724
Max	**2.5149**	**2.4958**	**2.2634**	**1.448**	**1.3527**	**1.448**	**1.1431**
Min	**.0187**	**.0762**	**.0762**	**.0762**	**.0762**	**.0762**	**.0166**
Avg	**.7517**	**.8698**	**.7925**	**.5674**	**.4531**	**.5311**	**.3362**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
JAYSINGPUR[030] **BU 1171**
Substation No/ Name :- 144036 / 33/11KV SHIROL
Feeder No / Name : 202 / 11KV Estate **SHEDDABLE FEEDER HAVING WEEKLY**
Feeder KV- 11 / OUTGOING **STAGGERING (MIDC, EQUIVALENT)**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8267	1.7528	1.9052	1.9052	1.5242	1.448	1.9052
2	1.7193	1.6194	1.9052	1.8671	1.3336	1.448	1.8671
3	1.6126	1.5623	1.7909	1.8671	1.3336	1.448	1.8671
4	1.4746	1.5623	1.7909	1.848	1.3717	1.448	1.848
5	1.4723	1.5242	1.6766	1.848	1.4098	1.448	1.848
6	1.4373	1.5242	1.6004	1.3717	1.4289	1.5242	1.3336
7	1.5424	1.6004	1.9052	1.4098	1.3336	1.6004	1.4861
8	1.6476	1.6004		1.3717	1.448	1.6766	1.6385
9	2.2862	1.9814	2.3577	1.2193	1.848	2.191	2.4006
10	2.3624	2.2862	2.452	1.2955	2.0386	2.2862	2.572
11	2.3624	2.6863	2.3011	1.2955	2.2862	2.7816	2.5149
12	2.0576	2.553	2.5339		2.2862	2.572	2.5911
13	1.9814	2.1719	2.2032	1.2193	2.0767	2.3434	2.2862
14	2.2862	2.572	2.5019	1.3717	2.0957	2.3815	2.4196
15	2.1719	2.6292	2.4143	1.2193	2.191	2.572	2.6863
16	2.0576	2.7625	2.5149	1.1431	2.4577	2.4387	2.6673
17	2.3624	2.5911	2.3434	1.3336	2.2862	2.5339	2.7625
18	1.9052	2.2862	2.2481	1.1431	1.7147	2.3053	2.1313
19	2.2291	2.4768	2.2481	1.4861	2.2862	2.3243	2.3954
20	2.191	2.572	2.191	1.448	2.0576	2.3815	2.0911
21	2.2862	2.6673	1.829	1.5242	1.6766	2.2862	2.037
22		2.3624	2.3624	1.5432	1.9052	2.0957	2.0911
23	1.8099	1.9814	2.4387	1.6766	1.6004	2.21	2.2032
24	1.9959	2.0957	1.9052	2.0005	1.5813	1.5242	2.0005
Max	**2.3624**	**2.7625**	**2.5339**	**2.0005**	**2.4577**	**2.7816**	**2.7625**
Min	**1.4373**	**1.5242**	**1.6004**	**1.1431**	**1.3336**	**1.448**	**1.3336**
Avg	**1.9599**	**2.1426**	**2.1487**	**1.4960**	**1.8155**	**2.0529**	**2.1518**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
JAYSINGPUR[030] **BU 1171**
Substation No/ Name :- 144036 / 33/11KV SHIROL
Feeder No / Name : 204 / 11KV Mayur **SHEDDABLE FEEDER HAVING WEEKLY**
Feeder KV- 11 / OUTGOING **STAGGERING (MIDC, EQUIVALENT)**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6476	1.7528	1.7528	1.7147	1.4861	1.6004	1.8671
2	1.7193	1.6766	1.5242	1.7147	1.448	1.6004	1.8671
3	1.5424	1.6766	1.5242	1.6956	1.448	1.6004	1.848
4	1.4582	1.6194	1.5242	1.6956	1.4861	1.5242	1.848
5	1.5402	1.5623	1.5242	1.6575	1.5242	1.5242	1.8671
6	1.3435	1.5242	1.5242	1.6194	1.6766	1.3717	1.6956
7	1.6461	***	1.829	1.448	1.6766	1.7528	1.9243
8	1.4746	1.829		1.5242	1.5242	1.5242	1.6575
9	2.6673	2.5911	2.553	1.5242	2.0957	2.1148	2.4387
10	2.7435	2.6673	2.5652	1.7528	2.0005	2.2862	2.3815
11	3.0483	3.2007	3.1245	1.6766	2.5339	3.1055	3.1436
12	2.8959	3.2769	2.5339	1.6004	2.6292	2.7625	2.7625
13	2.6673	2.3053	2.5911	1.3717	2.21	2.1529	2.1338
14	2.8197	2.6101	2.7435	1.5242	2.4768	2.3053	2.7244
15	2.7435	2.6673	2.7625	1.6766	2.5149	2.4196	2.6863
16	2.5911	2.5339	2.934	1.6766	2.6863	2.5149	2.3053
17	2.7435	3.0483	2.7244	1.3717	2.5149	2.2672	2.8197
18	2.2862	2.3624	2.3624	1.3717	2.1338	2.3815	2.6673
19	2.572	2.7816	2.2291	1.448	2.0957	2.4387	2.0725
20	2.3243	2.0005	2.0576	1.5242	1.829	1.9814	1.6991
21	1.5813	2.0957	1.9243	1.5242	1.6766	1.9052	1.8665
22	1.6766	1.829	1.829	1.4861	1.829	1.6956	1.7924
23	2.0957	2.0576	1.7909	1.7147	1.6766	1.9433	1.7924
24	1.6057	2.0005	1.9814	1.7718	1.6194	1.6766	1.8861
Max	**3.0483**	**19.5664**	**3.1245**	**1.7718**	**2.6863**	**3.1055**	**3.1436**
Min	**1.3435**	**1.5242**	**1.5242**	**1.3717**	**1.448**	**1.3717**	**1.6575**
Avg	**2.1431**	**2.9681**	**2.1700**	**1.5869**	**1.9497**	**2.0187**	**2.1561**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
JAYSINGPUR[030] BU 1171
Substation No/ Name :- 144036 / 33/11KV SHIROL
Feeder No / Name : 205 / 11 KV Buvaphan AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0895	.0762	.0762	.7621	.8192	.8383	.743
2	.0905	.0762	.0762	.743	.8192	.8383	.743
3	.0905	.0762	.0762	.743	.8192	.8383	.724
4	.0905	.0762	.0762		.8192	.8383	.724
5	.0914	.0762	.0762	.8002	.8573	.8383	.7621
6	.1267	.0762	.0762	.9145	.9145	.9145	.8192
7	.128	.0762	.0762	1.2193	1.2574	1.2193	1.0288
8	.1267	.0762		1.4098	1.4289	1.3717	1.2384
9	1.2955	1.4861	1.2517	.0762	.0762	.0762	.0762
10	1.9052	1.848	1.8229	.0762	.0762	.0762	.0762
11	1.9814	2.0957	1.9806	.0762	.0762	.0762	.0762
12	2.0957	2.21	1.858	.0762	.0762	.0762	.0762
13	1.9814	2.0767	1.7974	.0762	.0762	.0762	.0762
14	1.9814	2.0005	1.7804	.0762	.0762	.0762	.0762
15	1.9814	2.0195	1.6956		.0762	.0762	.0762
16	1.9052	1.9814	1.7002	.0762	.0762	.0762	.0762
17	.0762	.0762	.0762	.0762	.0762	.0762	
18	.0762	.0762	.0953		.0762	.0762	.0701
19	.0762	.0762	.0953	.0762	.0762	.0762	.0876
20	.0762	.0762	.1143	.0762	.0762	.0762	.0876
21	.0762	.0762	.0953	.0762	.0762	.0762	.0895
22	.0762	.0762	.0762	.0762	.0762	.0762	
23	.0762	.0762	.8383	.8764	.8383	.7811	.0876
24	.0895	.0762	.0762	.7621	.8573	.8383	.7811
Max	**2.0957**	**2.21**	**1.9806**	**1.4098**	**1.4289**	**1.3717**	**1.2384**
Min	**.0762**	**.0762**	**.0762**	**.0762**	**.0762**	**.0762**	**.0701**
Avg	**.6910**	**.7057**	**.6908**	**.4355**	**.4374**	**.4326**	**.3907**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
JAYSINGPUR[030] BU 1171
Substation No/ Name :- 144036 / 33/11KV SHIROL
Feeder No / Name : 206 / Jogeswari gaonthan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.3048	.3048	.3239	.3048	.2286	.3048
2	.3429	.3048	.3048	.3048	.2667	.2286	.3048
3	.3048	.3048	.3048	.3048	.2667	.2286	.2858
4	.3048	.3429	.3048	.3048	.3048	.2286	.2858
5	.3239	.381	.3048	.381	.381	.3429	.4763
6	.4763	.4954	.4572	.4191	.5335	.4572	.5716
7	.6036	.6478	.5716	.5335	.6097	.6097	.8192
8	.7095	.724		.6097	.7621	.6859	.5906
9	.6859	.6668	.7282	.6097	.6859	.7049	.7049
10	.6097	.6097	.6908	.6097	.6859	.6287	.6478
11	.6097	.6478	.7282	.6097	.7049	.6478	.6478
12	.6097	.5525	.6468	.5335	.6668	.5525	.5716
13	.381	.5144	.4854	.3048	.4572	.4191	.5335
14	.381	.4763	.3921	.381	.4954	.4191	.4191
15	.4572	.4572	.4481	.381	.5906	.4572	.4572
16	.5335	.4191	.4481	.381	.4001	.4763	
17	.381	.381	.5525	.3239	.4572		.4108
18	.4572	.4572	.5716	.6097	.6859	.5906	.5415
19	.9335	.9717	.9145	.9145	1.0669	.9145	.9149
20	.9145	.9145	.8764	.8573	.9145	.8954	.9522
21	.8002	.8764	.743	.8383	.8383	.7621	.8402
22	.7049	.7621	.6668	.724	.6859	.6668	.6979
23	.4572	.4572	.5716	.4954	.3048	.4763	.4715
24	.4001	.3429	.381	.381	.3429	.2286	.3429
Max	**.9335**	**.9717**	**.9145**	**.9145**	**1.0669**	**.9145**	**.9522**
Min	**.3048**	**.3048**	**.3048**	**.3048**	**.2667**	**.2286**	**.2858**
Avg	**.5318**	**.5422**	**.5390**	**.5057**	**.5589**	**.5152**	**.5562**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
JAYSINGPUR[030] BU 1171
Substation No/ Name :- 144036 / 33/11KV SHIROL
Feeder No / Name : 208 / 11 KV Krushna LIS **PURELY LIS FEEDERS**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.0572	.0572	.0572	.0572	.0572	.0953
4	.0572	.0572	.0572	.0572	.0572	.0953
5	.0572	.0572	.0572	.0572	.0572	.0953
6	.0572	.0572	.0572	.0572	.0572	.0953
7	.0572	.0572	.0572	.0572	.0572	.0953
8	.0572	.0572		.0572	.0572	.1143
9	.1334	.1334	.132	.1334	1.4289	.0953
10	.1334	.1334	.1509	.1334	.1524	.1524
11	.1334	.1334	.2075	.1524	.1905	.1715
12	.1334	.1524	.1886	.1524	.1905	.1524
13	.1334	.1524	.1698	.1524	.1905	.1524
14	.1334	.1524	.1509	.1524	.1905	.1334
15	.1334	.1524	.1509	.1524	.1905	.1334
16	.1334	.1524	.132	.1524	.1524	.1334
17	.1334	.1524	.1334	.1524	.1524	.132
18	.1143	.0953	.0572	.1143	.0572	.0943
Max	**.1334**	**.1524**	**.2075**	**.1524**	**1.4289**	**.1715**
Min	**.0572**	**.0572**	**.0572**	**.0572**	**.0572**	**.0943**
Avg	**.1036**	**.1096**	**.1173**	**.1119**	**.2024**	**.1213**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
JAYSINGPUR[030] BU 1171
Substation No/ Name :- 144036 / 33/11KV SHIROL
Feeder No / Name : 209 / KULKARNI POWER TOOLS SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974	1.2384	1.4289	1.1812	1.0479	1.3336	1.3336
2	1.0117	1.2003	1.4289	1.1812	1.0479	1.3336	1.3146
3	.9389	1.2003	1.3336	1.1622	1.0479	1.2574	1.3146
4	.8987	1.1812	1.3336	1.1622	1.0479	1.2574	1.2955
5	.8684	1.1812	1.2193	1.1431	1.0479	1.1812	1.2955
6	.8993	1.2003	1.1431	1.0288	1.0479	1.1812	1.2955
7	.9995	1.0479	1.0479	.9907	1.0098	1.2384	1.0098
8	.8436	1.0098		.9526	1.0098	1.1431	1.105
9	1.4289	1.3336	1.4563	.9145	1.5813	1.5623	1.6766
10	1.6766	1.7337	1.7164	.8573	1.6194	1.5813	1.8861
11	1.5242	1.5813	1.8296	.8573	1.7528	1.8861	1.8099
12	1.6385	2.0005	1.8484		1.8099	2.0005	1.7147
13	1.5242	1.3336	1.8671	.7621	1.4861	1.2765	1.2955
14	1.7528	1.7147	1.9814	.7621	1.5242	1.4861	1.8671
15	1.7909	1.7528	1.6975	.7621	1.6194	1.7337	1.5623
16	1.8099	1.9052	1.8298	.7621	1.9433	1.5623	1.7528
17	1.5242	1.4098	1.467	1.0098	1.4289	1.7528	1.7353
18	1.6766	1.6194	1.2765	.9717	1.7147	1.7147	1.8107
19	1.4289	1.5813	1.2955	.9717	1.3527	1.6194	1.4335
20	1.448	1.4289	1.1622	.9907	1.2955	1.1431	1.2437
21	1.1812	1.2955	1.2003	1.0288	1.4098	1.2574	1.2254
22	1.2574	1.4289	1.3717	1.0098	1.1812	1.5242	1.39
23	1.3336	1.467	1.2765	1.0098	1.2955	1.3527	1.39
24	1.2536	1.2765	1.4289	1.2384	***	1.3336	1.3336
Max	**1.8099**	**2.0005**	**1.9814**	**1.2384**	**10.8215**	**2.0005**	**1.8861**
Min	**.8436**	**1.0098**	**1.0479**	**.7621**	**1.0098**	**1.1431**	**1.0098**
Avg	**1.3253**	**1.4218**	**1.4626**	**.9874**	**1.7560**	**1.4464**	**1.4621**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
JAYSINGPUR[030] **BU 1171**
Substation No/ Name :- 144042 / 33/11 KV Kothali
Feeder No / Name : 201 / 11KV LIS **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762			1.4083			
2	.0762			1.3916			
3	.0762			1.4232			
4	.0953			1.4232			
5	.0953			1.4575			
6	.1143			1.5604			
7	.1143			1.7661			
8	.1143			1.6461			
9	2.6292	2.572	2.3975	.0762	.0953	.0762	
10	3.6389	3.5246	3.0521	.0953	.0953	.0762	
11	3.677	3.7151	3.2579	.0953	.0953	.0762	
12	3.6961	3.677	2.4863	.0191	.0953	.0762	
13	3.7532	3.4103	2.8807	.0191	.0953	.0762	
14	3.6008	3.5056	3.3341	.0191	.0953	.0762	
15	3.6389	3.4294	2.572	.0762	.0762	.0762	
16	3.5818	3.2769	2.5549	.1143	.0953	.0953	
17		.0762	.0953		.0953	.0953	.0762
18		.0762	.1143		.1143	.1334	.0762
19		.1334	.1334		.1524	.1524	.1524
20		.1334	.1334		.1334	.1524	.1334
21		.1334	.1334		.1334	.1334	.1334
22		.1143	.1143		.1143	.1143	.1143
23			1.5432		1.105		.1143
24	.0762			1.4083		1.1431	
Max	**3.7532**	**3.7151**	**3.3341**	**1.7661**	**1.105**	**1.1431**	**.1524**
Min	**.0762**	**.0762**	**.0953**	**.0191**	**.0762**	**.0762**	**.0762**
Avg	**1.7091**	**1.9841**	**1.6535**	**.8235**	**.1728**	**.1702**	**.1143**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
JAYSINGPUR[030] BU 1171
Substation No/ Name :- 144042 / 33/11 KV Kothali
Feeder No / Name : 202 / 11KV Kothali Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724			.0381			
2	.743			.0381			
3	.7621			.0381			
4	.7811			.0572			
5	.8002			.0572			
6	.8383			.0572			
7	.9145			.0762			
8	.9335			.0572			
9	.0381	.0572	.0572	1.2765	1.6221	1.7147	
10	.0572	.0572	.0572	1.7147	1.8275	2.0576	
11	.0572	.0572	.0762	2.0195	1.9113	2.0195	
12	.0572	.0572	.0762	2.1529	1.9113	1.9433	
13	.0572	.0572	.0572	2.1338	1.861	2.0005	
14	.0572	.0381	.0381	2.0576	1.8442	1.9052	
15	.0381	.0381	.0381	2.0005	1.7436	1.7909	
16	.0381	.0572	.0572	1.9433	1.576	1.7528	
17		.0572	.0572		.0572	.0381	.0381
18		.0572	.0572		.0572	.0572	.0381
19		.0953	.0762		.0762	.0762	.0762
20		.0762	.0762		.0762	.0762	.0762
21		.0762	.0762		.0572	.0762	.0572
22		.0572	.0572		.0572	.0572	.0572
23			.0572		.0381	.0572	.8383
24	.7621			.0381		.0381	
Max	**.9335**	**.0953**	**.0762**	**2.1529**	**1.9113**	**2.0576**	**.8383**
Min	**.0381**	**.0381**	**.0381**	**.0381**	**.0381**	**.0381**	**.0381**
Avg	**.4505**	**.0599**	**.0610**	**.9268**	**.9811**	**.9788**	**.1688**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
JAYSINGPUR[030] **BU 1171**
Substation No/ Name :- 144042 / 33/11 KV Kothali
Feeder No / Name : 203 / 11KV Umalwad Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191			.7545			
2	.0191			.7377			
3	.0191			.7042			
4	.0191			.7042			
5				.7209			
6	.0191			.8059			
7	.0191			.9259			
8	.0191			1.0117			
9	1.0288	1.2193	.8848	.0191	.0191	.0191	
10	1.1622	1.4861	1.4083	.0191	.0191	.0191	
11	1.2193	1.5623	1.3916	.0191	.0191	.0191	
12	1.5051	1.5432	1.358		.0191	.0191	
13	1.5242	1.5242	1.4083		.0191	.0191	
14	1.5242		1.3916		.0191	.0191	
15	1.4861	1.4861	1.358		.0191	.0191	
16	1.4861	1.448	1.3245		.0191	.0191	
17		.0191	.0191		.0191	.0191	.0191
18		.0191	.0191		.0191	.0191	.0191
19		.0191	.0191		.0191	.0191	.0191
20		.0191	.0191		.0191	.0191	.0191
21		.0191	.0191		.0191	.0191	.0191
22		.0191	.0191			.0191	.0191
23			.8002		.724	.4858	.0191
24	.0191			.7545		.724	
Max	**1.5242**	**1.5623**	**1.4083**	**1.0117**	**.724**	**.724**	**.0191**
Min	**.0191**	**.0191**	**.0191**	**.0191**	**.0191**	**.0191**	**.0191**
Avg	**.6931**	**.7988**	**.7627**	**.5981**	**.0695**	**.0923**	**.0191**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
JAYSINGPUR[030] **BU 1171**
Substation No/ Name :- 144042 / 33/11 KV Kothali
Feeder No / Name : 204 / 11KV Danoli Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5242			.1143			
2	1.4861			.0953			
3	1.4861			.0953			
4	1.5623			.1143			
5	1.6004			.1334			
6	1.6194			.1905			
7	2.0195			.2477			
8	2.3815			.2096			
9	.1715	.1524	.1715	2.2291	2.146	2.4006	
10	.1524	.1334	.1905	3.296	3.0007	3.2388	
11	.1524	.1143	.1334	3.3341	3.3303	3.3532	
12	.0762	.1143	.0191	3.4675	3.1727	3.3341	
13	.0762	.1143	.1334	3.4294	3.2427	3.2579	
14	.1143	.0953	.0953	3.3913	3.155	3.1436	
15	.0953	.0953	.0762	3.1626	3.0323	3.0674	
16	.0953	.1143	.0953	2.9912	3.0849	2.9912	
17		.0953	.1143		.0953	.0953	.0572
18		.0953	.1334		.1334	.1524	.1143
19		.2096	.2477		.2096	.2096	.2096
20		.2096	.2096		.1905	.1905	.2096
21		.1905	.1905		.1715	.1905	.1905
22		.1334	.1524		.1334	.1524	.1524
23			.1334		.1143	.1334	1.6004
24	1.5242			.1143		.0953	.0953
Max	**2.3815**	**.2096**	**.2477**	**3.4675**	**3.3303**	**3.3532**	**1.6004**
Min	**.0762**	**.0953**	**.0191**	**.0953**	**.0953**	**.0953**	**.0572**
Avg	**.9493**	**.1334**	**.1397**	**1.5656**	**1.6808**	**1.6254**	**.3287**

 Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
JAYSINGPUR[030] **BU 1171**
Substation No/ Name :- 144042 / 33/11 KV Kothali
Feeder No / Name : 205 / 11KV Waranamai **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193			.0381			
2	1.1812			.0381			
3	1.2193			.0381			
4	1.2574			.0572			
5	1.2574			.0381			
6	1.3146			.0572			
7	1.3527			.0572			
8	1.5623			.0572			
9	.0572	.0381	.0572	1.7147	1.6933	2.0957	
10	.0381	.0381	.0572	2.1719	2.0957	2.4196	
11	.0381	.0381	.0381	1.9052	1.9616	2.4387	
12	.0572	.0572	.0381	2.3053	2.0454	2.0195	
13	.0572	.0572	.0381	2.3053	1.9448	2.4196	
14	.0572	.0572	.0572	2.191	1.9448	2.5149	
15	.0572	.0381	.0572	2.1529	1.9547	2.3624	
16	.0572	.0572	.0572	2.1719	1.9113	2.2291	
17		.0381	.0572		.0191	.0381	.0381
18		.0381	.0572		.0381	.0572	.0381
19		.0572	.0572		.0381	.0572	.0381
20		.0572	.0572		.0572	.0572	.0572
21		.0572	.0572		.0572	.0572	.0572
22		.0572	.0572		.0572	.0572	.0381
23			.0381		.0381	.0381	1.1431
24	1.2193			.0381		.0381	
Max	**1.5623**	**.0572**	**.0572**	**2.3053**	**2.0957**	**2.5149**	**1.1431**
Min	**.0381**	**.0381**	**.0381**	**.0381**	**.0191**	**.0381**	**.0381**
Avg	**.7061**	**.0490**	**.0521**	**1.0199**	**1.0571**	**1.1812**	**.2014**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
JAYSINGPUR[030] **BU 1171**
Substation No/ Name :- 144042 / 33/11 KV Kothali
Feeder No / Name : 206 / 11KV Danoli Gaothan **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667			.3429			
2	.2667			.3239			
3	.3429			.3239			
4	.381			.3429			
5	.4191			.4191			
6	.4763			.4572			
7	.4954			.4001			
8	.381			.381			
9	.381	.5335	.4954	.3239	.4954	.4382	
10	.4572	.4763	.4763	.4191	.4572	.4191	
11	.4763	.4954	.4763	.4001	.5335	.4001	
12	.4763	.4382	.4382	.3048	.4763	.4382	
13	.4763	.4191	.4191	.2667	.381	.4001	
14	.4763	.4572	.4001	.3429	.381	.381	
15	.4382	.4763	.381	.3429	.3429	.381	
16	.4763	.4191	.4382	.362	.4382	.3429	
17		.4954	.5144		.4191	.4191	.4572
18		.4954	.5716		.4954	.5144	.5335
19		.6859	.6668		.6478	.6097	.6859
20		.6287	.6287		.6097	.5906	.6668
21		.5716	.5716		.5525	.5335	.6097
22		.4572	.4572		.4001	.4191	.4954
23			.4001		.3239	.381	.381
24	.3048			.3429		.2858	
Max	**.4954**	**.6859**	**.6668**	**.4572**	**.6478**	**.6097**	**.6859**
Min	**.2667**	**.4191**	**.381**	**.2667**	**.3239**	**.2858**	**.381**
Avg	**.4113**	**.5035**	**.489**	**.3586**	**.4636**	**.4346**	**.5471**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
JAYSINGPUR[030] **BU 1171**
Substation No/ Name :- 144042 / 33/11 KV Kothali
Feeder No / Name : 207 / 11KV Umalwad Gaothan **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429			.3239			
2	.3429			.3048			
3	.381			.3048			
4	.4191			.3048			
5	.5335			.381			
6	.5716			.5335			
7	.5716			.6097			
8	.5335			.5525			
9	.4572	.4763	.5144	.4954	.4954	.4954	
10	.4382	.4382	.4763	.4382	.4572	.4572	
11	.4191	.4191	.4572	.4191	.4763	.4191	
12	.4001	.4191	.4763	.381	.4382	.4382	
13	.3239	.4001	.4191	.362	.4001	.381	
14	.3239	.362	.381	.362	.4001	.4191	
15	.3429	.3239	.3239	.381	.4001	.381	
16	.381	.381	.381	.362	.4001	.381	
17		.4191	.4763		.4572	.3429	.4001
18		.4954	.5525		.5335	.4572	.5525
19		.724	.7621		.7621	.6859	.7621
20		.6859	.724		.724	.7049	.6859
21		.5716	.6287		.6478	.6478	.6478
22		.4572	.4763		.5144	.5144	.5716
23			.381		.4191	.4382	.4572
24	.3048			.3239		.362	
Max	**.5716**	**.724**	**.7621**	**.6097**	**.7621**	**.7049**	**.7621**
Min	**.3048**	**.3239**	**.3239**	**.3048**	**.4001**	**.3429**	**.4001**
Avg	**.4169**	**.4695**	**.4953**	**.4023**	**.5017**	**.4703**	**.5825**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
JAYSINGPUR[030] **BU 1171**
Substation No/ Name :- 144042 / 33/11 KV Kothali
Feeder No / Name : 402 / 33 KV Khandsari
Feeder KV- 33 / OUTGOING

DATE	24-DEC-17
HR	Load (MW)
17	1.5432
Max	1.5432
Min	1.5432
Avg	1.5432

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
JAYSINGPUR[030] **BU 1171**
Substation No/ Name :- 144074 / 33/11 KV jaysingpur
Feeder No / Name : 201 / 11KV RAILWAY **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3881	.3734	.4024	.4024	.3881	.3734	.333
2	.3881	.3734	.3841	.3841	.3696	.3734	.3366
3	.3696	.3734	.3841	.3841	.3696	.3734	.3366
4	.3696	.3921	.4207	.4024	.3881	.3921	.3544
5	.3881	.4481	.439	.439	.3696	.4108	.3898
6	.499	.5601	.4755		.5729	.4668	.4607
7	.7392	.6535	.5487	.567	.6653	.5788	.6268
8	.7947	.7282	.6838	.7682	.7207	.6908	.7783
9	.7316	.6584	.6468	.7499	.7655	.7947	.8215
10	.7316	.7762	.7207	.7499	.7842	.7577	.7842
11	.7316	.7842	.7947	.7316	.8215	.7947	.8029
12	.7316	.7655	.7023	.695	.7842	.7762	.8029
13	.7316	.7059	.7023	.695	.7468	.7392	.7468
14	.695	.7059	.6653	.6584	.7095	.6653	.7095
15	.6584	.6908	.5914	.6219	.7095	.6653	.5914
16	.695	.6838	.6653	.6099	.6908	.6283	.6468
17	.8029	.695	.6584	.6468	.7655	.7133	.7207
18	.9335	.8596	.7762	.8131	.9149	.8962	.9979
19	1.0456	.9694	.9522	.961	1.0082	1.0608	1.0164
20	.9709	.8779	.9149	.9425	.9709	.9145	.9055
21	.8962	.7682	.8215	.7947	.8402	.823	.7947
22	.6535	.6401	.6908	.6838	.7468	.6516	.6468
23	.5041	.5304	.5121	.5175	.5601	.4784	.462
24	.4066	.4108	.4024	.4024	.4251	.3921	.3761
Max	**1.0456**	**.9694**	**.9522**	**.961**	**1.0082**	**1.0608**	**1.0164**
Min	**.3696**	**.3734**	**.3841**	**.3841**	**.3696**	**.3734**	**.333**
Avg	**.6607**	**.6427**	**.6232**	**.6357**	**.6703**	**.6421**	**.6434**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
JAYSINGPUR[030] BU 1171
Substation No/ Name :- 144074 / 33/11 KV jaysingpur
Feeder No / Name : 202 / 11KV PINGARA SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.3361	.3109	.3475	.2987	.3361	.2835
2	.2801	.3361	.2926	.3292	.2801	.3361	.2835
3	.2614	.3361	.2926	.3292	.2614	.3361	.2835
4	.2987	.3547	.3109	.3475	.2801	.3734	.3012
5	.3174	.3921	.3475	.4024	.2865	.4108	.3366
6	.4668	.4668	.4207	.4755	.4481	.5041	.4252
7	.5975	.6722	.4938	.5853	.6348	.6535	.567
8	.7468	.7468	.6535	.7682	.7282	.7468	.7059
9	.695	.7133	.6908	.6584	.7095	.6908	.5975
10	.695	.7207	.6348	.6219	.6908	.7282	.5975
11	.6767	.6161	.5788	.5487	.6722	.6161	.5601
12	.6036	.5228	.5601	.439	.6161	.5415	.5228
13	.5487	.4706	.4294	.4572	.5788	.5228	.4854
14	.4572	.4525	.3734	.4024	.4481	.4294	.4854
15	.4938	.4066	.4294	.3841	.5228	.4108	.5228
16	.5121	.499	.3921	.3734	.5975	.4294	.5228
17	.5601	.4938	.4854	.4108	.5975	.4572	.4668
18	.6161	.5853	.5788	.6161	.5975	.6036	.6535
19	.7095	.7133	.7655	.7095	.8029		.7655
20	.7095	.6767	.7282	.6908	.7468	.7316	.7468
21	.6535	.6584	.7095	.6348	.6838	.6767	.6722
22	.5601	.5853	.6348	.5601	.5975	.5975	.5788
23	.4294	.4207	.4572	.4108	.5041	.3898	.3921
24	.2987	.3361	.3109	.3475	.2987	.3361	.3224
Max	**.7468**	**.7468**	**.7655**	**.7682**	**.8029**	**.7468**	**.7655**
Min	**.2614**	**.3361**	**.2926**	**.3292**	**.2614**	**.3361**	**.2835**
Avg	**.5203**	**.5213**	**.4951**	**.4938**	**.5368**	**.5156**	**.5033**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
JAYSINGPUR[030] **BU 1171**
Substation No/ Name :- 144074 / 33/11 KV jaysingpur
Feeder No / Name : 203 / 11KV SHAHUNAGAR **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2772	.2801	.2378	.2378	.2402	.2614	.2303
2	.2772	.2801	.2195	.2195	.2402	.2614	.2303
3	.2587	.2801	.2195	.2195	.2218	.2614	.2303
4	.2957	.2801	.2378	.2378	.2218	.2801	.2481
5	.2772	.3174	.2743	.2743	.2772	.3734	.3012
6	.3881	.3921	.3475	.3841	.4066	.4108	.3544
7	.5359	.5788	.4572	.4572	.4805	.5041	.4784
8	.5914	.5601	.4805	.5487	.5914	.5788	.5611
9	.5121	.4938	.5359	.5304	.5415	.5175	.4854
10	.4572	.5544	.462	.3658	.4481	.462	.4294
11	.3841	.4108	.4435	.4207	.3734	.3511	.3921
12	.4024	.3734	.4066	.3658	.3547	.3696	.3734
13	.3109	.362	.3696	.3658	.3547	.3696	.3361
14	.3292	.3185	.3142	.3475	.3174	.3326	.2987
15	.3475	.3174	.3511	.2743	.3174	.3326	.3326
16	.3292	.3326	.3511	.2957	.3361	.3511	.3174
17	.4108	.439	.4481	.3511	.4108	.3841	.3881
18	.6161	.5304	.5415	.462	.5975	.567	.6099
19	.7095	.6767	.7282	.6283	.7282	.7316	.7207
20	.7095	.6401	.6908	.6283	.7282	.6401	.7023
21	.6535	.6219	.6348	.5729	.6535	.6036	.6283
22	.5041	.5121	.5415	.5175	.5601	.5415	.5544
23	.3734	.4024	.3658	.3511	.4108	.3189	.3511
24	.2957	.2801	.2378	.2378	.2587	.2614	.2507
Max	**.7095**	**.6767**	**.7282**	**.6283**	**.7282**	**.7316**	**.7207**
Min	**.2587**	**.2801**	**.2195**	**.2195**	**.2218**	**.2614**	**.2303**
Avg	**.4269**	**.4264**	**.4124**	**.3872**	**.4196**	**.4194**	**.4085**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
KURUNDWAD[031] **BU 1180**
Substation No/ Name :- 144043 / 33/11 KV SHIRDHON
Feeder No / Name : 201 / 11KV Takawade Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7682	.6706	.6401	.0305	.032	.0297
2	.7682	.6706	.6401	.0305	.032	.0297
3	.7682	.6706	.6401	.0305	.032	.0286
4	.7682	.6706	.6401	.0305	.032	.0286
5	.7682	.6706	.6401	.0305	.032	.0297
6	.7682	.7377	.6401	.0305	.032	.0297
7	.8642	.9054	.7468	.0305	.032	.0297
8	1.0242	.9389	.9717	.0305	.032	.0297
9	.0305	.0671	.0343	.8002	1.2193	1.2793
10	.0297	.032	.0305		1.5242	1.5684
11	.0297	.032	.0305	1.3435	1.6964	1.6964
12	.0297	.032	.0305	1.4685	1.4403	1.7284
13	.0297	.032	.0305	1.4998	1.6164	1.7284
14	.0297	.032	.0305	1.5466	1.6575	1.6004
15	.0297	.032	.0305		1.6575	1.5684
16	.0396	.0366	.0305		1.5043	1.5043
17	.0335	.0297	.0305	.032	.0257	.032
18	.0335	.032	.0305	.032	.0297	.032
19	.0335	.0427	.0305	.032	.032	.0328
20	.0335	.0427	.0305	.032	.0427	.032
21	.0335	.0495	.0305	.032	.0297	.032
22	.0335	.0396	.0305	.032	.0297	.032
23	.6706	.6401	.0305	.032	.0343	.7621
24	.7682	.6706	.6401	.0305	.032	.0314
Max	**1.0242**	**.9389**	**.9717**	**1.5466**	**1.6964**	**1.7284**
Min	**.0297**	**.0297**	**.0305**	**.0305**	**.0257**	**.0286**
Avg	**.3494**	**.3241**	**.2775**	**.3408**	**.5345**	**.5790**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
KURUNDWAD[031] BU 1180
Substation No/ Name :- 144043 / 33/11 KV SHIRDHON
Feeder No / Name : 202 / Shirdhon, Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305	.0335	.0171		.5571	.4268	.4588
2	.0305	.0335	.016	.5487	.5571	.4268	.5121
3	.0305	.0335	.0171	.5182	.5571	.4268	.4755
4	.0305	.0335	.0171	.5182	.5407	.4268	.4755
5	.0305	.0335	.0171	.5487	.5407	.4268	.439
6			.0171	.5487	.5407	.4268	.3932
7	.0305	.0335	.0171	.7011	.5407	.4877	
8	.0305	.0335	.0171	.7316	.5571	.4877	.4096
9	.6962	1.0059	1.0212	.0305	.0305	.0171	.0328
10	.9755	1.2289	1.2803	.0286	.0305	.0305	.0335
11	1.0517	1.3272	1.4083	.0244	.0305	.0305	.0335
12	1.0822	1.3435	1.4083	.0381	.0305	.0305	.0335
13	1.0364	1.3108	1.2803	.0305	.0305	.0305	.0335
14	1.0669	1.3108	1.3443	.0305	.0305	.0305	.0305
15	1.0936	1.3108	1.2803		.0305	.032	.0305
16	1.0364	1.2944	1.2803		.0305	.0305	.0305
17	.0335	.0171	.0305	.0328	.0171	.0328	.0305
18	.0335	.0429	.0305	.0328	.0114	.0328	.0305
19	.0335	.0429	.0305	.0328	.0152	.0328	.0305
20	.0335	.0257	.0305	.0328	.0133	.0328	.0305
21	.0335	.0305	.0305	.0328	.02	.0328	.0305
22	.0335	.0229	.0305	.0328	.02	.0328	.0305
23	.0335	.02	.5487	.5243	.4268	.4588	.0305
24	.0305	.0335	.0171	.5487	.5571	.4268	.4588
Max	**1.0936**	**1.3435**	**1.4083**	**.7316**	**.5571**	**.4877**	**.5121**
Min	**.0305**	**.0171**	**.016**	**.0244**	**.0114**	**.0171**	**.0305**
Avg	**.3703**	**.4610**	**.4662**	**.2651**	**.2382**	**.2021**	**.1780**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
KURUNDWAD[031] **BU 1180**
Substation No/ Name :- 144043 / 33/11 KV SHIRDHON
Feeder No / Name : 204 / 11KV Shiradhon Takawade **GAOTHAN FEEDER**
Vlg Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.2683	.3982	.4024	.4706	.3982	.5121
2	.362	.2683	.3982	.3982	.439	.3841	.5121
3	.362	.2683	.3982	.4344	.439	.3696	.4755
4	.5068	.2683	.3982	.439	.5121	.3658	.4607
5	.5068	.3353	.4163	.5121	.5121	.4525	.5316
6	.543	.4694	.543	.5121	.5316	.543	.5731
7	.6154	.4694	.5973	.6154	.567	.5792	.6089
8	.6154	.503	.5792	.6219	.5853	.5792	.6024
9	.5792	.6036	.5973	.6516	.5792	.5973	.6401
10	.5973	.5493	.5792	.6154	.6154	.6219	.57
11	.6335		.543	.5792	.6154	.5853	.503
12	.5792		.543	.543	.543	.543	.4694
13	.4706		.3982	.4344	.3982	.4344	.4359
14	.4344		.4344	.4706	.4706	.4344	.4706
15	.5249	.6219	.4706	.4163	.4706	.4706	.6516
16	.4344	.5304	.4706	.4163	.5068	.543	.5853
17	.4024	.5249	.543	.4572	.5792	.5853	.695
18	.4694	.6878	.6516	.7316	.724	.5493	.7602
19	.6706	.7964	.8326	.8048	.9412	.8962	.9511
20	.6706	.8326	.8048	.8505	.8507	.8962	.8688
21	.6036	.7964	.6878	.7316	.8326	.7796	.8326
22	.503	.5973	.6219	.6268	.6516	.6485	.6878
23	.3353	.5068	.4755	.4938	.5249	.5853	.5068
24	.439	.2683	.4344	.4024	.5121	.4706	.4755
Max	**.6706**	**.8326**	**.8326**	**.8505**	**.9412**	**.8962**	**.9511**
Min	**.3353**	**.2683**	**.3982**	**.3982**	**.3982**	**.3658**	**.4359**
Avg	**.5092**	**.5083**	**.5340**	**.5484**	**.5780**	**.5547**	**.5992**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
KURUNDWAD[031] BU 1180
Substation No/ Name :- 144043 / 33/11 KV SHIRDHON
Feeder No / Name : 205 / JAMBHALI-TAKWADE LIS PURELY LIS FEEDERS
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.3258	.4024	.4031	.3189	.4207	.3544
4	.3292	.4024	.4119	.3189	.4252	.3898
5	.3258	.4024	.4252	.3189	.4252	.3898
6	.3258	.4024	.2629	.3189	.4207	.439
7	.3258	.4024	.4298	.3292	.4207	.4252
8	.3258	.4024	.4119	.3258	.4031	.439
9	.4024	.4024	.4298	.3086	.4207	.4252
10	.3856	.4207	.4207	.4344	.4344	.4024
11	.3155	.439	.4344	.4298	.4163	.4024
12	.4031	.439	.4344	.4344	.4344	.4024
13	.4031	.3932	.4163	.4344	.439	.4024
14	.4031	.439	.4163	.4344	.4344	.4344
15	.4031	.439	.4344	.4344	.4344	.439
16	.4031	.439	.4344	.4344	.4344	.439
17	.4024	.4207	.4344	.4207	.4252	.4344
18	.0671	.0076	.0362	.2058	.2126	.2172
Max	**.4031**	**.439**	**.4344**	**.4344**	**.439**	**.439**
Min	**.0671**	**.0076**	**.0362**	**.2058**	**.2126**	**.2172**
Avg	**.3467**	**.3909**	**.3898**	**.3689**	**.4126**	**.4023**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
KURUNDWAD[031] BU 1180
Substation No/ Name :- 144043 / 33/11 KV SHIRDHON
Feeder No / Name : 206 / JAYHIND-JAWAHAR LIS PURELY LIS FEEDERS
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.1829	.2012	.2267		.2267	.2709
4	.1829	.2012	.2267		.2267	.2709
5	.1829	.2012	.2267		.2267	.2559
6	.1829	.2012	.2267		.2267	.2709
7	.1677	.2347	.2267		.2267	.3361
8	.1829	.2347	.2267		.2267	.2709
9	.2591	.2683	.2753	.1372	.2591	.3161
10	.2915	.2926	.2439	.2134	.2439	.1677
11	.3077	.2258	.2439	.1829	.3048	.2683
12	.2915	.2743	.2439	.2439	.3048	.2683
13	.2915	.2926	.2439	.2439	.3048	.3688
14	.2915	.3174	.2439	.2439	.3521	.3353
15	.2915	.3475	.2439	.2439	.3201	.3353
16	.2915	.2378	.2439	.2439	.3048	.3353
17	.2683	.2753	.2439	.2753	.301	.3048
18	.1677	.2591	.061	.2753	.3121	.3048
Max	**.3077**	**.3475**	**.2753**	**.2753**	**.3521**	**.3688**
Min	**.1677**	**.2012**	**.061**	**.1372**	**.2267**	**.1677**
Avg	**.2396**	**.2541**	**.2280**	**.2304**	**.2730**	**.2925**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
KURUNDWAD[031] BU 1180
Substation No/ Name :- 144044 / 33/11KV KURUNDWAD
Feeder No / Name : 201 / 11 Kv Shridatt Feeder AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.052	.0312	.7802		.3887	.5201
2		.0526	.0312	.7712		.3681	.5258
3		.0532	.0312	.7796		.3841	.5316
4		.0537	.0312	.8238		.3887	.5373
5		.0543	.0328	.8507		.421	.5792
6		.0549	.0312	.7865		.4534	.5853
7		.0739	.0324	.8316		.4858	.6099
8		.056	.0474	.8402		.5121	.6722
9		2.0182	1.6194	.0377		.0469	.0377
10		1.9757	1.9433	.0343		.0343	.0343
11	2.0111	2.0729	2.1152	.032		.052	.032
12	2.0683	2.1376	2.0508	.032		.0526	.032
13	2.1439	2.1052	2.0908	.032		.0532	.032
14	2.167	1.9433	1.9879	.032		.0537	.032
15	2.0995	1.9433	1.8642	.032		.0543	.032
16	2.0485	1.9433	1.7924	.032	.0312	.0549	.032
17	.0554	.0486	.037	.032	.0312	.0554	.032
18	.0747	.0469	.056	.032	.0469	.056	.032
19	.0566	.0469	.0566	.032	.0312	.0377	.032
20	.0514	.0486	.0514	.032	.0469	.0514	.032
21	.052	.0469	.0347	.032	.0469	.052	.032
22	.0526	.0469	.0351	.032	.0312	.0526	.032
23	.0532	.0469	.8328	.5761	.421	.5493	.032
24		.0514	.0312	.7888		.3841	.5487
Max	**2.167**	**2.1376**	**2.1152**	**.8507**	**.421**	**.5493**	**.6722**
Min	**.0514**	**.0469**	**.0312**	**.032**	**.0312**	**.0343**	**.032**
Avg	**.9949**	**.7072**	**.7028**	**.3452**	**.0858**	**.2101**	**.2333**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
KURUNDWAD[031] BU 1180
Substation No/ Name :- 144044 / 33/11KV KURUNDWAD
Feeder No / Name : 202 / 11 kv Bastwad feeder AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0347	.0335	1.2136		.788	.7802
2		.0351	.0335	1.2269		.788	.7537
3		.0354	.0335	1.2757		.8139	.7619
4		.0358	.0335	1.3432		.8048	.8059
5		.0362	.0328	1.3756		.8383	.8507
6		.0366	.0335	1.4045		.9054	.8779
7		.037	.0335	1.4415		.9724	.961
8		.0373	.0335	1.4563		1.0059	1.0829
9		2.7161	2.0222	.0377		.0335	.0377
10		2.364	2.1963	.0343		.0343	.0343
11	2.3232	2.4813	2.3752	.0328		.0347	.0328
12		2.649	2.4539	.0324		.0351	.0328
13	2.1794	2.5819	2.3565	.0324		.0354	.0328
14	2.3461	2.4813	2.3461	.0324		.0358	.0328
15	2.4977	2.5149	2.3891	.0324		.0362	.0328
16	2.4508	2.2634	2.268	.0328	.0335	.0366	.0328
17		.0335	.037	.0328	.0335		.0328
18	.0373	.0335	.0373	.0328	.0335	.0373	.0328
19	.0377	.0335	.0377	.0328	.0328	.0377	.0328
20	.0343	.0335	.0343	.0328	.0335	.0343	.0328
21	.0347	.0335	.0347	.0328	.0328	.0351	.0328
22	.0351	.0335	.0351	.0328	.0335	.0351	.0328
23	.0354	.0335	1.2757	.9175	.8383	.8328	.0328
24		.0343	.0343	1.2174		.8139	.8059
Max	**2.4977**	**2.7161**	**2.4539**	**1.4563**	**.8383**	**1.0059**	**1.0829**
Min	**.0343**	**.0335**	**.0328**	**.0324**	**.0328**	**.0335**	**.0328**
Avg	**1.0920**	**.8587**	**.8417**	**.5557**	**.1339**	**.3924**	**.3408**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
KURUNDWAD[031] **BU 1180**
Substation No/ Name :- 144044 / 33/11KV KURUNDWAD
Feeder No / Name : 203 / HERWAD VILLEGE **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4334	.4904	.4334		.5281	.4854
2		.4382	.4904	.4382		.4904	.4908
3		.443	.5281	.443		.4904	.4961
4		.4477	.5658	.5373		.5281	.5194
5		.543	.6036	.5792		.6036	.5611
6		.695	.6979	.695		.7167	.695
7		.7392	.7167	.7023		.7545	.7207
8		.7655	.7545	.7468		.7356	.7655
9		.6979	.6224	.6602		.7167	.6602
10			.7167	.5144		.583	.6173
11	.5201	.6413	.6241	.5041		.5201	.6348
12	.5434	.6602	.6135	.4854		.5609	.6161
13	.4961		.567	.5041		.5138	.6161
14	.4477	.6602	.5731	.5041		.4119	.5601
15	.5249	.6602	.6154	.5601		.543	.5415
16	.567	.6335	.6767	.5601	.6602	.6219	.5788
17	.5914	.6584	.6838	.6348	.7167	.6468	.6348
18	.7095	.7545	.7468	.6722	.7545	.7468	.6908
19	.8676	.9054	.8676	.8215	.8299	.8865	.8589
20	.6859	.7545	.7373	.7842	.7922	.6859	.7842
21	.6241	.6413	.6935	.7468	.679	.6241	.6562
22	.5959	.6413	.631	.6535	.6413	.5784	.6722
23	.5316	.6036	.5847	.6161	.6036	.5493	.5415
24		.4801	.5281	.5144		.5658	.5144
Max	**.8676**	**.9054**	**.8676**	**.8215**	**.8299**	**.8865**	**.8589**
Min	**.4477**	**.4334**	**.4904**	**.4334**	**.6036**	**.4119**	**.4854**
Avg	**.5927**	**.6317**	**.6387**	**.5963**	**.7097**	**.6084**	**.6213**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
KURUNDWAD[031] BU 1180
Substation No/ Name :- 144044 / 33/11KV KURUNDWAD
Feeder No / Name : 204 / 11 kv water works feeder NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0867	.0857	.0867		.0857	.0867
2		.0876	.0857	.0876		.0857	.0876
3		.0886	.0848	.0709		.0857	.0886
4		.1075	.0848	.0716		.0857	.0895
5		.1086	.0857	.0724		.0857	.1086
6		.1097	.0857	.0732		.0857	.1097
7		.1109	.0857	.1109		.1029	.1109
8		.112	.0857	.112		.1029	.112
9		.1132	.1029	.1132		.1029	.0943
10		.1029	.1029	.1029		.0857	.1029
11	.0867	.1029	.0867	.0848		.0867	.0848
12	.0876	.1017	.0876	.0848		.0701	.0848
13	.0886	.1017	.0886	.0848		.1075	.0848
14	.0895	.0857	.0895	.0848		.1075	.0848
15	.0905	.0857	.0905	.0848		.0905	.0848
16	.0914	.0857	.1097	.0848	.1029	.0914	.0848
17	.0739	.0857	.0924	.0848	.0857	.0924	.0848
18	.0934	.0857	.0934	.0678	.0857	.0934	.0848
19	.0943	.0857	.0943	.0848	.0857	.0943	.0678
20	.1029	.0857	.0857	.0848	.0857	.1029	.0678
21	.0867	.0857	.0867	.0848	.0857	.104	.0848
22	.1052	.0857	.0876	.0857	.0857	.0876	.0678
23	.1063	.0857	.0886	.0848	.0857	.0886	.0678
24		.1029	.0857	.0857		.0857	.0686
Max	**.1063**	**.1132**	**.1097**	**.1132**	**.1029**	**.1075**	**.112**
Min	**.0739**	**.0857**	**.0848**	**.0678**	**.0857**	**.0701**	**.0678**
Avg	**.0921**	**.0956**	**.0899**	**.0864**	**.0879**	**.0921**	**.0872**

 Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
KURUNDWAD[031] **BU 1180**
Substation No/ Name :- 144044 / 33/11KV KURUNDWAD
Feeder No / Name : 205 / 11 Kv Herwad Fdr **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0358	.0328	1.3003		1.094	1.0749
2		.0351	.0328	1.3146		1.0814	1.0867
3		.0354	.0328	1.3466		1.094	.567
4		.0358	.0328	1.3969		1.1271	1.1283
5		.0362	.0328	1.3575		1.1603	1.1765
6		.0366	.0328	1.4632		1.1934	1.2254
7		.0554	.0492	1.5708		1.3413	1.3121
8		.056	.0492	1.7551		1.5089	1.5684
9		1.6598	1.5927	.0754		.0655	.0754
10		1.6787	1.8442	.0343		.0514	.0514
11	1.7164	1.8564	1.9938	.032			.048
12	1.7353	1.8679	2.0332	.032		.0351	.048
13	1.8959	1.6766	2.0199	.032		.0354	.032
14	1.9879	1.8442	2.0237	.032		.0358	.032
15	1.7556	1.989	2.0271	.032		.0543	.048
16	1.7558	1.7604	2.0485	.032	.0328	.0549	.032
17	.037	.0328	.0554	.048	.0328	.037	.048
18	.0373	.0328	.0747	.032	.0492	.0373	.048
19	.0377	.0503	.0754	.032	.0503	.0566	.048
20	.0343	.0492	.0686	.048	.0671	.0514	.048
21	.0347	.0492	.052	.048	.0328	.052	.048
22	.0351	.0492	.0526	.048	.0503	.0351	.032
23	.0354	.0492	1.3466	1.1203	1.1603	1.1163	.032
24		.0343	.0328	1.3032		1.1271	1.0974
Max	**1.9879**	**1.989**	**2.0485**	**1.7551**	**1.1603**	**1.5089**	**1.5684**
Min	**.0343**	**.0328**	**.0328**	**.032**	**.0328**	**.0351**	**.032**
Avg	**.8537**	**.6253**	**.7349**	**.6036**	**.1845**	**.5411**	**.4545**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
KURUNDWAD[031] BU 1180
Substation No/ Name :- 144044 / 33/11KV KURUNDWAD
Feeder No / Name : 206 / 11KV Kurundwad Urban SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6935	.6962	.6935		.7956	.6935
2		.6135	.663	.6135		.7625	.6135
3		.6201	.663	.6201		.7625	.6201
4		.6268	.6464	.6805		.7956	.6268
5		.724	.7625	.724		.8619	.724
6		1.0059	.8951	1.0059		.9945	.9511
7		1.0719	.9945	1.0534		1.1271	1.1088
8		1.2883	1.1271	1.3256		1.1603	1.2696
9		1.4523	1.326	1.4523		1.326	1.3392
10		1.2763	1.3592	1.2517		1.3717	1.2689
11	1.335	1.1934	1.2656	.8002		1.2656	1.1385
12	1.3321	1.2597	1.2445	.7274		1.3146	1.1203
13	1.0808	1.0486	1.0099	.6642		1.0631	.8749
14	.9313	.9282	.985	.5693		.985	.8436
15	1.2127	1.0608	1.2489	.7042		1.267	.9488
16	1.3169	1.1603	1.3535	.7682	1.1934	1.3169	1.012
17	1.3491	1.1934	1.386	.8002	1.326	1.3491	.8124
18	1.4937	1.2597	1.5497	1.3763	1.4918	1.587	.9922
19	1.7353	1.5249	1.8484	1.4723	1.5581	1.7353	1.1203
20	1.406	1.4255	1.4746	1.4083	1.4918	1.4232	1.0562
21	1.283	1.2266	1.387	1.2803	1.278	1.4217	.9602
22	1.1919	1.1934	1.2445	1.1203	1.2597	1.2269	.8802
23	.9745	.9614	1.0099	.9282	.9945	1.0631	.6401
24		.8402	.8288	.9088		.852	.9088
Max	**1.7353**	**1.5249**	**1.8484**	**1.4723**	**1.5581**	**1.7353**	**1.3392**
Min	**.9313**	**.6135**	**.6464**	**.5693**	**.9945**	**.7625**	**.6135**
Avg	**1.2802**	**1.0687**	**1.1237**	**.9562**	**1.3242**	**1.1595**	**.9385**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
KURUNDWAD[031] **BU 1180**
Substation No/ Name :- 144044 / 33/11KV KURUNDWAD
Feeder No / Name : 207 / BASTWAD VILLEGE **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.156	.1646	.1387		.1646	.1214
2		.1578	.1646	.1402		.1646	.1227
3		.1595	.1829	.1417		.1646	.124
4		.1791	.2561	.1433		.1848	.1791
5		.181	.2561	.181		.2378	.2149
6		.3292	.3109	.2561		.3109	.2926
7		.3142	.3658	.2957		.3658	.3326
8		.2987	.3292	.3361		.3475	.3174
9		.2641	.2561	.3018		.2629	.2829
10		.2378	.2561	.2572		.2572	.2401
11	.208	.2195	.2427	.2507		.2254	.2279
12	.2454	.2743	.2454	.1772		.2126	.2103
13	.2126	.2378	.2303	.1949		.1772	.2303
14	.197	.2743	.2149	.197			.2149
15	.181	.2378	.1991	.2172		.1267	.197
16	.1829	.2378	.2012	.1417	.2926	.1829	.1991
17	.2218	.2378	.2218	.1612	.3109	.2033	.1772
18	.2614	.2926	.2614	.2686	.3292	.2427	.2896
19	.415	.4024	.3772	.394	.4066	.3961	.4207
20	.3086	.3658	.2774	.3544	.3841	.3258	.3841
21	.2774	.3109	.2774	.3224	.3292	.2947	.3696
22	.2454	.3109	.2629	.2507	.2926		.2801
23	.1772	.2195	.2126	.197	.2195	.1417	.1867
24		.1543	.1829	.1543		.1829	.12
Max	**.415**	**.4024**	**.3772**	**.394**	**.4066**	**.3961**	**.4207**
Min	**.1772**	**.1543**	**.1646**	**.1387**	**.2195**	**.1267**	**.12**
Avg	**.2411**	**.2522**	**.2479**	**.2280**	**.3206**	**.2351**	**.2390**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
KURUNDWAD[031] BU 1180
Substation No/ Name :- 144044 / 33/11KV KURUNDWAD
Feeder No / Name : 208 / KURUNDWAD AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0347	.0316	.0693		.08	.052
2		.0351	.0316	.0526		.08	.0526
3		.0354	.0316	.0532		.08	.0532
4		.0358	.0316	.0537		.081	.0537
5		.0362	.0316	.0724		.08	.0724
6		.0366	.0316	.0732		.081	.0914
7		.037	.0316	.1097		.112	.1294
8		.0373	.0316	.1307		.125	.168
9		.1698	.1296	.0377		.0309	.0377
10		.1781	.1562	.0343		.0343	.0343
11	.1907	.192	.1734	.032		.0347	.032
12	.2103	.2105	.1753	.032		.0351	.032
13	.1772	.2105	.1772	.032		.0354	.032
14	.1433	.1943	.1791	.032		.0358	.032
15	.1267	.1943	.181	.032		.0362	.032
16	.1463	.1781	.1829	.032	.0305	.0366	.032
17	.037	.0316	.037	.032	.0312		.032
18	.0373	.0312	.0373	.032	.0312	.0373	.032
19	.0377	.0312	.0377	.032	.0312	.0377	.032
20	.0343	.0312	.0343	.032	.0312	.0343	.032
21	.0347	.0312	.0347	.032	.0312	.0347	.032
22	.0351	.0312	.0351	.032	.0309	.0351	.032
23	.0354	.0316	.0709	.08	.08	.0532	.032
24		.0343	.0312	.0686		.081	.0686
Max	**.2103**	**.2105**	**.1829**	**.1307**	**.08**	**.125**	**.168**
Min	**.0343**	**.0312**	**.0312**	**.032**	**.0305**	**.0309**	**.032**
Avg	**.0958**	**.0862**	**.0802**	**.0508**	**.0372**	**.0570**	**.0512**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
KURUNDWAD[031] BU 1180
Substation No/ Name :- 144044 / 33/11KV KURUNDWAD
Feeder No / Name : 209 / 11KV Nrisinghwadi Vg GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1387	.1646	.156		.1646	.156
2		.1402	.1646	.1578		.1646	.1578
3		.1417	.1463	.1595		.1629	.1772
4		.1612	.1829	.1612		.2012	.1791
5		.1991	.2378	.2172		.2561	.2172
6		.2743	.3109	.3109		.3292	.2561
7		.3511	.3658	.3696		.3696	.3696
8		.3734	.3658	.3921		.3658	.4108
9		.3395	.3292	.3395		.3292	.3395
10		.3109	.3475	.3086		.3429	.2915
11	.2427	.2926	.3121	.3224		.2774	.2865
12	.2629	.2561	.3155	.2865		.2629	.2507
13	.2481	.2561	.2835	.2149		.2303	.2686
14	.2507	.2033	.2686	.197			.2328
15	.2353	.2743	.2534	.2328		.2896	.2507
16	.2743	.3292	.2926	.2507	.3292	.2926	.2686
17	.2957	.2743	.3696	.2865	.3292	.3142	.3224
18	.3547	.3292	.3361	.2865	.3658	.3361	.3582
19	.3772	.439	.4527	.4119	.4024	.3961	.394
20	.3086	.4024	.3772	.394	.3841	.3429	.394
21	.2774	.3658	.3467	.3582	.2926	.2774	.3582
22	.2804	.3109	.298	.2865	.2926	.2454	.2865
23	.1949	.2195	.2303	.2149	.2195	.1949	.2149
24		.1543	.1829	.1886		.1829	.1543
Max	**.3772**	**.439**	**.4527**	**.4119**	**.4024**	**.3961**	**.4108**
Min	**.1949**	**.1387**	**.1463**	**.156**	**.2195**	**.1629**	**.1543**
Avg	**.2771**	**.2724**	**.2889**	**.2710**	**.3269**	**.2752**	**.2748**

 Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
KURUNDWAD[031] **BU 1180**
Substation No/ Name :- 144045 / 33/11KV TAKALI
Feeder No / Name : 201 / 11KV Takali Gaothan **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0572	.0572	.0762	.0572	.0572
2	.0572	.0762	.0572	.0572	.0762	.0572	.0572
3	.0572	.0762	.0572	.0572	.0762	.0572	.0572
4	.0572	.0762	.0572	.0572	.0762	.0572	.0762
5	.0953	.0953	.0572	.0953	.0953	.0762	.0953
6	.1143	.1143	.0953	.1334	.1143	.1143	.1143
7	.1334	.1334	.1524	.1524	.1334	.1524	.1334
8	.1524	.1524	.1524	.1524	.1524	.1524	.1524
9	.1334	.1334	.1143	.1143	.1143	.1334	.1334
10	.1143	.1143	.1143	.1143	.0953	.1143	.1143
11	.0953	.0953	.0953	.1143	.0953	.1143	.1143
12	.1143	.0953	.0953	.0762	.0953	.0953	.1143
13	.0953	.0953	.0953	.0953	.1143	.1143	.1143
14	.0953	.0953	.0762	.0762	.0953	.0953	.1143
15	.0953	.0953	.0953	.0953	.0953	.0953	.1143
16	.0953	.0953	.0953	.1143	.0953	.0762	.1143
17	.1143	.0762	.1143	.0953	.1143	.0953	.1143
18	.1524	.1143	.1334	.1334	.1143	.0953	.1334
19	.1715	.1524	.1715	.1905	.1334	.1905	.2096
20	.1715	.1524	.1715	.1715	.1524	.1715	.1905
21	.1524	.1334	.1334	.1524	.1334	.1524	.1524
22	.1143	.0953	.0953	.1143	.1143	.0953	.0953
23	.0762	.0572	.0762	.0762	.0572	.0762	.0762
24	.0762	.0762	.0572	.0762	.0762	.0572	.0572
Max	**.1715**	**.1524**	**.1715**	**.1905**	**.1524**	**.1905**	**.2096**
Min	**.0572**	**.0572**	**.0572**	**.0572**	**.0572**	**.0572**	**.0572**
Avg	**.1088**	**.1032**	**.1008**	**.1072**	**.1040**	**.1040**	**.1127**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
KURUNDWAD[031] BU 1180
Substation No/ Name :- 144045 / 33/11KV TAKALI
Feeder No / Name : 202 / 11KV Takaliwadi Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8764	.7282	.9335	.0381	.0297	.0381	.0381
2	.8764	.6836	.9335	.0381	.0297	.0381	.0381
3	.8764	.6836	.9335	.0381	.0297	.0381	.0381
4	.9145	.6836	.9526	.0381	.0297	.0381	.0381
5	.9526	.743	.9717	.0381	.0297	.0381	.0381
6	.9907	.8322	.9907	.0381	.0297	.0381	.0381
7	1.105	.9214	1.1241	.0381	.0297	.0381	.0381
8	1.1622	.9511	1.2193	.0381	.0297	.0381	.0381
9	.0381	.0297	.0381	1.1812		1.2765	1.448
10	.0297	.0381	.0381	1.1145	1.4289	1.3717	1.6766
11	.0297	.0381	.0381	1.0848	1.467	1.4289	1.7147
12	.0297	.0381	.0381	1.2483	1.6766	1.6194	1.7147
13	.0297	.0381	.0381	.9362	1.5813	1.6385	1.5813
14	.0297	.0381	.0381	1.1888	1.5623	1.5051	1.5813
15	.0446	.0381	.0381	1.1591	1.448	1.3908	1.5432
16	.0446	.0381	.0381	1.1294	1.2574	1.467	1.4861
17	.0297	.0381	.0381	.0297	.0381	.0381	.0381
18	.0297	.0381	.0381	.0297	.0381	.0381	.0381
19	.0297	.0381	.0381	.0297	.0381	.0381	.0381
20	.0297	.0381	.0381	.0297	.0381	.0572	.0381
21	.0446	.0381	.0381	.0297	.0381	.0572	.0381
22	.0297	.0381	.0381	.0297	.0381	.0381	.0381
23	.7282	.9526	.0381	.0297	.0381	.0381	1.0669
24	.9335	.7282	.9526	.0381	.0297	.0381	.0381
Max	**1.1622**	**.9526**	**1.2193**	**1.2483**	**1.6766**	**1.6385**	**1.7147**
Min	**.0297**	**.0297**	**.0381**	**.0297**	**.0297**	**.0381**	**.0381**
Avg	**.4119**	**.3514**	**.3993**	**.3997**	**.4763**	**.5144**	**.5993**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
KURUNDWAD[031] **BU 1180**
Substation No/ Name :- 144045 / 33/11KV TAKALI
Feeder No / Name : 203 / 11KV Danwad AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0332	.0381	.5335	.4475	.4763	.381
2	.0381	.0332	.0381	.5335	.431	.4763	.362
3	.0381	.0332	.0381	.5144	.431	.4763	.362
4	.0381	.0332	.0381	.5144	.431	.4954	.3429
5	.0381	.0332	.0381	.5716	.4475	.4954	.3429
6	.0381	.0332	.0381	.6287	.4973	.5144	.4191
7	.0381	.0332	.0381	.743	.5636	.6097	.4763
8	.0381	.0332	.0381	.8192	.663	.743	.4954
9	.8764	.9779	1.0098	.0572	.0332	.0381	.0381
10	.9945	1.2574	1.2384	.0497	.0381	.0381	.0381
11	1.1603	1.3146	1.3146	.0332	.0381	.0381	.0381
12	1.1603	1.2384	1.2765	.0497	.0381	.0381	.0381
13	1.1271	1.2955	1.2384	.0497	.0381	.0381	.0381
14	1.1271	1.2955	1.2384	.0497	.0381	.0381	.0381
15	1.094	1.1622	1.1622	.0497	.0381	.0381	.0381
16	1.094	1.1812	1.1431	.0332	.0381	.0381	.0381
17	.0332	.0381	.0381	.0332	.0381	.0381	.0381
18	.0332	.0381	.0381	.0332	.0381	.0381	.0381
19	.0332	.0381	.0572	.0332	.0381	.0381	.0381
20	.0332	.0381	.0572	.0332	.0381	.0381	.0381
21	.0332	.0381	.0572	.0332	.0381	.0381	.0381
22	.0332	.0381	.0381	.0332	.0381	.0381	.0381
23	.0332	.0381	.5716	.4475	.4763	.381	.0381
24	.0381	.0332	.0381	.5335	.4475	.4763	.381
Max	**1.1603**	**1.3146**	**1.3146**	**.8192**	**.663**	**.743**	**.4954**
Min	**.0332**	**.0332**	**.0381**	**.0332**	**.0332**	**.0381**	**.0381**
Avg	**.3837**	**.4287**	**.4509**	**.2671**	**.2235**	**.2366**	**.1723**

 Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
KURUNDWAD[031] **BU 1180**
Substation No/ Name :- 144045 / 33/11KV TAKALI
Feeder No / Name : 204 / 11KV Rajapur AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7049	.5716	.5335	.0381	.0332	.0381	.0381
2	.7049	.4807	.5144	.0381	.0332	.0381	.0381
3	.6859	.4807	.4954	.0381		.0381	.0381
4	.6859	.4641	.4954	.0381	.0332	.0381	.0381
5	.743	.4973	.4954	.0381	.0332	.0381	.0381
6	.7811	.5801	.5335	.0381	.0332	.0381	.0381
7	.8383	.663	.5906	.0572	.0332	.0381	.0762
8	.8764	.7956	.8002	.0572	.0332	.0381	.0381
9	.0381	.0332	.0381	1.1241	1.3592	1.7147	1.7528
10	.0332	.0381	.0572	1.2929	1.848	1.9624	1.9052
11	.0332	.0381	.0381	1.442	2.0576	2.0576	1.9052
12	.0332	.0381	.0381	1.5249	2.0195	2.0386	1.8671
13	.0332	.0381	.0381	1.5083	2.0767	1.9814	1.8099
14	.0332	.0381	.0381	1.4918	1.9624	2.0195	1.6766
15		.0381	.0381	1.442	1.8861	1.9624	1.6385
16	.0332	.0381	.0381	1.4089	1.848	1.8671	1.6194
17	.0332	.0381	.0381	.0332	.0381	.0381	.0572
18	.0332	.0381	.0572	.0332	.0381	.0572	.0381
19	.0332	.0381	.0572	.0332	.0381	.0572	.0381
20	.0332	.0381	.0572	.0332	.0381	.0381	.0381
21		.0381	.0381	.0332	.0381	.0381	.0381
22	.0332	.0381	.0381	.0332	.0381	.0381	.0381
23	.4973	.5144	.0381	.0335	.0381	.0381	.7621
24	.724	.4973	.5335	.0381	.0332	.0381	.0381
Max	**.8764**	**.7956**	**.8002**	**1.5249**	**2.0767**	**2.0576**	**1.9052**
Min	**.0332**	**.0332**	**.0381**	**.0332**	**.0332**	**.0381**	**.0381**
Avg	**.3475**	**.2531**	**.2350**	**.4937**	**.6778**	**.6771**	**.6486**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
KURUNDWAD[031] BU 1180
Substation No/ Name :- 144045 / 33/11KV TAKALI
Feeder No / Name : 205 / Rajapur Vlg GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1334	.1334	.1334	.1143	.1143	.0953
2	.0953	.1334	.1143	.1143	.0953	.0953	.0953
3	.0953	.1143	.1143	.1143	.0953	.0953	.0953
4	.0953		.1143	.1143	.0953	.1143	.0953
5	.1715	.1524	.1524	.1524	.1143	.1524	.1715
6	.2286	.1905	.2286	.2286	.1905	.2477	.2858
7	.2667	.2667	.2858	.2858	.2477	.2858	.2858
8	.2667	.2286	.2667	.2667	.2858	.2858	.2286
9	.2096	.1905	.2477	.2096	.2286	.2096	.1905
10	.1905	.1715	.1905	.1524	.1905	.1524	.1715
11	.1334	.1524	.1524	.1524	.1905	.2096	.1524
12	.0953	.1143	.1905	.1334		.1905	.1524
13	.1143	.1334	.1905	.1334	.1715	.1905	.1334
14	.1143	.1334	.1715	.1334	.1715	.1905	.1334
15	.1334		.1715	.1334	.1334	.1715	.1334
16	.1524		.1715	.1524	.1524	.1524	.1524
17	.2096		.1524	.1524	.1905	.1715	.1524
18	.2667	.2477	.2096	.1905	.1905	.2096	.1905
19	.362	.3239	.3239	.362	.2858	.3239	.3239
20	.3429	.3048	.2858	.3048	.3239	.3048	.2858
21	.2667	.2858	.2667	.2477	.2667	.2858	.2286
22	.2096	.2286	.2096	.1905	.2096	.1905	.1905
23	.1715	.1524	.1524	.1143	.1143	.1143	.1334
24	.1143	.1334	.1334	.1334	.1143	.1143	.1143
Max	**.362**	**.3239**	**.3239**	**.362**	**.3239**	**.3239**	**.3239**
Min	**.0953**	**.1143**	**.1143**	**.1143**	**.0953**	**.0953**	**.0953**
Avg	**.1842**	**.1896**	**.1929**	**.1794**	**.1814**	**.1905**	**.1747**

 Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
KURUNDWAD[031] **BU 1180**
Substation No/ Name :- 144045 / 33/11KV TAKALI
Feeder No / Name : 206 / Takaliwadi Vlg **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0381	.0381	.0381	.0381	.0381
2	.0381	.0381	.0381	.0381	.0381	.0381	.0381
3	.0381	.0381	.0381	.0381	.0381	.0381	.0381
4	.0381	.0381	.0381	.0381	.0381	.0381	.0572
5	.0572	.0572	.0381	.0381	.0572	.0381	.0572
6	.0572	.0572	.0381		.0762	.0572	.0572
7	.0762	.0762	.0572	.0572	.0762	.0572	.0572
8	.0572	.0762	.0762	.0953	.0762	.0762	.0762
9	.0572	.0762	.0762	.0762	.0762	.0762	.0572
10	.0572	.0572	.0762	.0572	.0762	.0572	.0762
11	.0762	.0762	.0762	.0762	.0762	.0572	.0762
12	.0572	.0762	.0953	.0762	.0762	.0762	.0953
13	.0572	.0572	.0953	.0572	.0953	.0762	.0762
14	.0572	.0572	.0572	.0572	.0762	.0572	.0381
15	.0381	.0381	.0572	.0572	.0381	.0572	.0381
16	.0381	.0381	.0762	.0572	.0381	.0381	.0572
17	.0572	.0762	.0762	.0572	.0762	.0572	.0762
18	.0762	.0762	.0953	.0762	.1143	.0953	.0953
19	.1334	.1143	.0953	.1334	.1143	.1334	.1334
20	.1143	.1143	.1143	.1143	.1143	.1143	.1143
21	.0953	.0953	.0953	.0953	.0953	.0953	.0953
22	.0572	.0953	.0762	.0572	.0762	.0572	.0762
23	.0381	.0381	.0381	.0381	.0572	.0381	.0381
24	.0381	.0381	.0381	.0381	.0381	.0381	
Max	**.1334**	**.1143**	**.1143**	**.1334**	**.1143**	**.1334**	**.1334**
Min	**.0381**	**.0381**	**.0381**	**.0381**	**.0381**	**.0381**	**.0381**
Avg	**.0604**	**.0643**	**.0667**	**.0638**	**.0699**	**.0627**	**.0679**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
KURUNDWAD[031] BU 1180
Substation No/ Name :- 144045 / 33/11KV TAKALI
Feeder No / Name : 207 / 11 KV TAKALI (AG) FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.0098	.5365	.6859	.5716
2				1.0098	.503	.6859	.5716
3				.9907	.503	.6668	.5906
4				.9907	.503	.6668	.5906
5				1.0479	.5365	.6859	.6097
6				1.0669	.6036	.724	.6478
7				1.0669	.6371	.8192	.7049
8				1.105	.6706	.8764	.7621
9	.9717	1.3413	1.3146				
10	1.2574	1.8099	1.7147				
11	1.3413	1.8861	1.6766				
12	1.4251	1.8671	1.7147				
13	1.4083	1.8861	1.7528				
14	1.4083	1.8671	1.8099				
15	1.3748	1.9052	1.7718				
16	1.3748	1.7528	1.6385				
23			1.086	.5533	.7049	.6097	
24				1.0479	.5533	.7049	.5716
Max	**1.4251**	**1.9052**	**1.8099**	**1.105**	**.7049**	**.8764**	**.7621**
Min	**.9717**	**1.3413**	**1.086**	**.5533**	**.503**	**.6097**	**.5716**
Avg	**1.3202**	**1.7895**	**1.6088**	**.9889**	**.5752**	**.7126**	**.6245**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
KURUNDWAD[031] BU 1180
Substation No/ Name :- 144045 / 33/11KV TAKALI
Feeder No / Name : 208 / 11 KV SANGAM AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0332	.0381	.6859	.4475	.4001	.4001
2	.0381	.0332	.0381	.6859	.431	.381	.4001
3	.0381	.0332	.0381	.6668	.431	.381	.381
4	.0381	.0332	.0381	.6668	.431	.4001	.381
5	.0381	.0332	.0381	.7049	.4475	.4191	.4191
6	.0381	.0332	.0381	.724	.4973	.4572	.4572
7	.0381	.0332	.0381	.724	.5304	.4954	.5335
8	.0381	.0332	.0381	.6859	.6287	.5335	.5525
9	.7049	.8619	1.1241	.0381	.0332	.0381	.0381
10	.8122	1.1431	1.2384	.0332	.0381	.0381	.0381
11	.9614	1.2574	1.3527	.0332	.0381	.0381	.0381
12	.9945	1.3336	1.2765	.0332	.0381	.0381	.0381
13	.9945	1.3336	1.2765	.0332	.0381	.0381	.0381
14	.9945	1.3336	1.2384	.0332	.0381	.0381	.0381
15	.9282	1.3717	1.2574	.0332	.0381	.0381	.0381
16	.9282	1.2955	1.2193	.0332	.0381	.0381	.0381
17	.0332	.0381	.0381	.0332	.0381	.0381	.0381
18	.0332	.0381	.0381	.0332	.0381	.0381	.0381
19	.0332	.0381	.0381	.0332	.0381	.0381	.0381
20	.0332	.0381	.0381	.0332	.0381	.0381	.0381
21	.0332	.0381	.0381	.0332	.0381	.0381	.0381
22	.0332	.0381	.0381	.0332	.0381	.0381	.0381
23	.0332	.0381	.724	.4641	.4001	.4191	.0381
24	.0381	.0332	.0381	.6859	.4641	.4001	.4191
Max	**.9945**	**1.3717**	**1.3527**	**.724**	**.6287**	**.5335**	**.5525**
Min	**.0332**	**.0332**	**.0381**	**.0332**	**.0332**	**.0381**	**.0381**
Avg	**.3289**	**.4373**	**.4700**	**.2985**	**.2182**	**.2008**	**.1881**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
KURUNDWAD[031] **BU 1180**
Substation No/ Name :- 144045 / 33/11KV TAKALI
Feeder No / Name : 209 / 11 KV Danwad Gaothan **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0572	.0572	.0572	.0572	.0572
2	.0572	.0572	.0572	.0572	.0572	.0572	.0381
3	.0572	.0572	.0572	.0572	.0572	.0572	.0381
4	.0762	.0572	.0381	.0762	.0572	.0572	.0572
5	.0953	.0572	.0572	.0953	.0762	.0762	.0762
6	.1143	.0762	.0953	.1334	.1143	.1143	.1143
7	.1143	.1143	.0953	.1524	.1334	.1143	.1334
8	.0953	.0953	.1143	.1143	.1143	.1143	.0953
9	.0953	.1143	.0953	.1143	.0332	.0953	.1143
10	.1143	.1143	.0762	.0762	.1143	.0762	.1334
11	.0953	.0953	.0762	.0953	.1143	.0762	.0953
12	.1143	.0953	.0762	.0762	.1143	.0953	.0953
13	.0953	.0953	.0572	.0953	.0953	.1143	.1143
14	.0953	.0762	.0572	.0572	.0762	.0572	.0762
15	.0762	.0381	.0762	.0572	.0762	.0381	.0953
16	.0762	.0762	.0762	.0762	.0762	.0381	.0762
17	.0572	.0762	.0762	.0953	.0572	.0572	.0762
18	.0762	.0953	.0953	.1143	.0953	.0953	.1143
19	.1334	.1715	.1334	.1715	.1334	.1334	.1524
20	.1334	.1524	.1334	.1524	.1524	.1334	.1334
21	.1143	.1334	.1143	.1334	.1334	.1334	.1143
22	.0953	.0953	.0953	.0762	.0953	.0953	.0953
23	.0572	.0572	.0572	.0572	.0572	.0572	.0762
24	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Max	**.1334**	**.1715**	**.1334**	**.1715**	**.1524**	**.1334**	**.1524**
Min	**.0572**	**.0381**	**.0381**	**.0572**	**.0332**	**.0381**	**.0381**
Avg	**.0897**	**.0881**	**.0802**	**.0937**	**.0895**	**.0834**	**.0929**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
KURUNDWAD[031] BU 1180
Substation No/ Name :- 144086 / 33/11kv Ghosarawad
Feeder No / Name : 201 / 11 KV Santubai AG Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305	.0332	.0324	1.4022	1.4373	1.4586	1.3441
2	.0305	.0332	.0324	1.4373	1.4373	1.4586	1.3279
3	.0305	.0332	.0324	1.4529	1.4373	1.4586	1.3279
4	.0305	.0332	.0324	1.4685	1.4685	1.4918	1.3279
5	.0457	.0332	.0486	1.4685	1.4842	1.4918	1.3441
6	.0457	.0332	.0486	1.4998	1.4998	1.5415	1.3441
7	.0457	.0497	.0486	1.5154	1.531	1.5746	1.4737
8	.0457	.0332	.0648		1.6872	1.7072	1.5546
9	1.5935	1.8399	1.9433			.0663	.0486
10	1.7497	2.2045	2.1052		.0457	.0497	.0486
11	1.9372	2.1862	2.1091	.0305	.0497	.0497	.0324
12	2.1216	2.2085	2.0934	.0305	.0332	.0486	.0305
13	2.1548	2.251	2.0622	.0305	.0332	.0324	.0312
14	2.1216	2.1376	2.1247	.0305	.0332	.0324	.0305
15	2.0885	2.2024	2.0934	.0305	.0497	.0324	.0305
16	2.0719	2.1052	2.0622	.0305	.0663	.0486	.0305
17	.0332	.0486	.0469	.0305	.0497	.0648	.0305
18	.0332	.0486	.0457	.0457	.0663	.0648	.0305
19	.0497	.0648	.061	.061	.0829	.081	.0469
20	.0663	.0648	.0625	.0457	.0829	.0648	.0457
21	.0663	.0486	.0457	.0457	.0663	.0486	.0457
22	.0497	.0486	.0457	.0305	.0497	.0486	.0305
23	.0332	.0324	1.4022	1.4998	1.442	1.3603	.0305
24	.0305	.0332	.0324	1.4373	1.4373	1.4586	1.3441
Max	**2.1548**	**2.251**	**2.1247**	**1.5154**	**1.6872**	**1.7072**	**1.5546**
Min	**.0305**	**.0324**	**.0324**	**.0305**	**.0332**	**.0324**	**.0305**
Avg	**.6877**	**.7420**	**.7782**	**.6488**	**.6770**	**.6556**	**.5388**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
KURUNDWAD[031] BU 1180
Substation No/ Name :- 144086 / 33/11kv Ghosarawad
Feeder No / Name : 202 / 11 kv Ghosarawad AG Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6874	.663	.6241	.0312	.0152	.0332	.032
2	.6874	.663	.6081	.0305	.0152	.0332	.032
3	.6874	.663	.6081	.0312	.0152	.0332	.032
4	.6874	.663	.6241	.0305	.0152	.0332	.032
5	.6874	.6796	.6241	.0305	.0152	.0332	.032
6	.7186	.6796	.6401	.0305	.0152	.0332	.032
7	.7186	.6796	.6722	.0305	.0305	.0332	.032
8	.7499	.7625	.6722	.0305	.0305	.0332	.032
9	.0305	.0332	.032		.9998	1.0774	.9122
10	.0305	.0332	.032		1.0936	1.21	1.0562
11	.0305		.0312	1.1584	1.21	1.2929	1.1203
12	.0166	.032	.0312	1.1405	1.2597	1.2003	1.166
13	.0332		.0312	1.0623	1.1934	1.1203	1.0467
14	.0332	.032	.0312	1.0623	1.1437	1.1523	.9842
15	.0332	.032	.0312	1.0623	1.1437	1.0242	.9842
16	.0332	.032	.0312	1.0623	1.1437	1.0242	.9998
17	.0166	.032	.0312	.0305	.0166	.032	.0305
18	.0332	.032	.0305	.0305	.0332	.032	
19	.0332	.032	.0305	.0305	.0332	.032	.0305
20	.0332	.032	.0305	.0305	.0332	.032	.0305
21	.0332	.032	.0305	.0305	.0332	.032	.0305
22	.0332	.032	.0305	.0305	.0332	.032	.0305
23	.663	.6241	.0305	.0305	.0332	.032	.6554
24	.6874	.663	.6241	.0305	.0152	.0332	.032
Max	**.7499**	**.7625**	**.6722**	**1.1584**	**1.2597**	**1.2929**	**1.166**
Min	**.0166**	**.032**	**.0305**	**.0305**	**.0152**	**.032**	**.0305**
Avg	**.3083**	**.3239**	**.2568**	**.3199**	**.3988**	**.4010**	**.4072**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
KURUNDWAD[031] **BU 1180**
Substation No/ Name :- 144086 / 33/11kv Ghosarawad
Feeder No / Name : 203 / 11 KV Ghosarawad VG GAOTHAN FEEDER
Feeder Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	.0943	.0739	.0914	.0732	.0754	.0739
2	.0732	.0943	.0739	.0914	.0732	.0754	.0739
3	.0732	.0943	.0924	.0914	.0732	.0943	.0924
4	.0732	.132	.1109	.0914	.0732	.1307	.1294
5	.1097	.168	.1478	.1097	.1097	.168	.1663
6	.1463	.2054	.2033	.128	.1463	.2241	.2218
7	.2926	.2402	.3142	.1991	.3109	.2772	.2402
8	.2743	.2957	.3142	.1991	.2743	.2772	.2218
9	.2195	.2772	.2587	.1629	.2195	.2402	.2587
10	.2926	.2587	.2402	.1991	.2195	.2218	.2402
11	.1829	.2587	.2534	.2172	.2402	.2033	.2402
12	.1848	.2772	.2172	.1829	.2402	.2033	.2172
13	.1848	.2587	.1829	.1646	.1848	.1848	.2378
14	.1478	.2402	.1448	.1097	.1663	.1663	.128
15	.1109	.1848	.1463	.1097	.1294	.1478	.1267
16	.1109	.1848	.1829	.1097	.1294	.1109	.128
17		.1478	.128	.1463	.1663	.1294	.1463
18	.1478	.2033	.1448	.1829	.1848		.1629
19	.2033	.2218	.1991	.2195	.2218	.2218	.2012
20	.2402	.2218	.181	.2012	.2033	.2033	.2172
21	.1848	.1848	.181	.1829	.1663	.1663	.1629
22	.1307	.1294	.1448	.1463	.1307	.1294	.1267
23	.0943	.0924	.0914	.1097	.0943	.0924	.0724
24	.0914	.0943	.0739	.0914	.0732	.0754	.0739
Max	**.2926**	**.2957**	**.3142**	**.2195**	**.3109**	**.2772**	**.2587**
Min	**.0732**	**.0924**	**.0739**	**.0914**	**.0732**	**.0754**	**.0724**
Avg	**.1584**	**.1900**	**.1709**	**.1474**	**.1627**	**.1660**	**.165**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
KURUNDWAD[031] BU 1180
Substation No/ Name :- 144086 / 33/11kv Ghosarawad
Feeder No / Name : 204 / 11 kv Balumama AG Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0152	.0324	.0312	1.0364	.9686	.933	.8124
2	.0152	.0316	.0312		.9686	.933	.7968
3	.0152	.0316	.0312	1.0364	.9686	.9488	.7968
4	.0152	.0324	.0312	1.0364	.9686	.9488	.7968
5	.0305	.0324	.0312	1.0212	.9686	.9646	.8124
6	.0305	.0324	.0312	1.0364	.9686	.9646	.8124
7	.0305	.0324	.0312	1.0212	.9998	.9804	.8749
8	.0305	.048	.0312	1.0669	1.0311	.9962	.9217
9	.8592	1.3125	1.2498	.0312	.0305	.0316	.0312
10	1.1248	1.442	1.3748	.0305	.0305	.032	.0312
11	1.2186	1.4217	1.3748	.0305	.0316	.0158	.0312
12	1.2809	1.4685	1.3748	.0305	.0316	.0156	.0312
13	1.3283	1.4529	1.3748	.0305	.0316	.0156	.0312
14	1.3441	1.3904	1.3592	.0305	.0316	.0156	.0312
15	1.3757	1.3592	1.326	.0305	.0316	.0156	.0305
16	1.2809	1.3592	1.3748	.0305	.0316	.0156	.0305
17	.0158	.0312	.0305	.0305	.0316	.0156	.0305
18	.0316	.0312	.0312		.0316	.0312	.0305
19	.048	.0312	.0305	.0305	.0316	.0312	.0305
20	.0316	.0312	.0305	.0305	.0316	.0312	.0305
21	.0316	.0312	.0305	.0305	.032	.0312	.0305
22	.0324	.0312	.0305		.032	.0312	.0305
23	.032	.0312	1.0212	.9686	.9172	.8124	.0305
24	.0305	.0324	.0312	1.0364	.9686		.8124
Max	**1.3757**	**1.4685**	**1.3748**	**1.0669**	**1.0311**	**.9962**	**.9217**
Min	**.0152**	**.0312**	**.0305**	**.0305**	**.0305**	**.0156**	**.0305**
Avg	**.4270**	**.4888**	**.5123**	**.4584**	**.4237**	**.3831**	**.3291**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
KURUNDWAD[031] BU 1180
Substation No/ Name :- 144086 / 33/11kv Ghosarawad
Feeder No / Name : 205 / 11 KV Dattawad AG Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.703	.5304	.5079	.0312	.0305	.0166	.0328
2	.7186	.5304	.4915	.0312	.0305	.0166	.0328
3	.7186	.5304	.4915	.0305	.0305	.0166	.0328
4	.7186	.5304	.5079	.0305	.0305	.0166	.0328
5	.7186	.5636	.5079	.0305	.0305	.0332	.0328
6	.7186	.5636	.5079	.0312	.0305	.0332	.0328
7	.7343	.5967	.5243	.0305	.0305	.0335	.0328
8	.7773	.5967	.5898	.0305	.0305	.0166	.0328
9	.0305	.0332	.0328	.7811	1.0936	1.1603	1.0978
10	.0152	.0332	.0328	1.1279	1.3748	1.4918	1.3763
11	.0305	.0164	.0312	1.1888	1.4918	1.5581	1.491
12	.0166	.0164	.0312	1.406	1.5083	1.5893	
13	.0332	.0164	.0312	1.406	1.4918	1.5238	1.4529
14	.0166	.0164	.0305	1.3435	1.4752	1.4582	1.3904
15	.0166	.0164	.0312	1.3435	1.442	1.4255	1.406
16	.0166	.0164	.0305	1.3435	1.3757	1.3272	1.2811
17	.0166	.0328	.0305	.0305	.0166	.0328	.0312
18	.0166	.0328	.0305	.0305	.0332	.0328	.0305
19	.0332	.0328	.0305	.0305	.0332	.0328	.0305
20	.0332	.0328	.0305	.0305	.0332	.0328	.0305
21	.0332	.0328	.0305	.0305	.0332	.0328	.0305
22	.0332	.0328	.0305	.0305	.0166	.0328	.0305
23	.547	.5079	.0312	.0305	.0166	.0328	.7926
24	.6874	.5304	.5079	.0312	.0305	.0166	.0328
Max	**.7773**	**.5967**	**.5898**	**1.406**	**1.5083**	**1.5893**	**1.491**
Min	**.0152**	**.0164**	**.0305**	**.0305**	**.0166**	**.0166**	**.0305**
Avg	**.3077**	**.2434**	**.2126**	**.4346**	**.4879**	**.4985**	**.4681**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
KURUNDWAD[031] BU 1180
Substation No/ Name :- 144086 / 33/11kv Ghosarawad
Feeder No / Name : 206 / 11 KV Dattawad VG GAOTHAN FEEDER
Feeder Feeder KV- 11 /
OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.1509	.1097	.1097	.1097	.1132	.128
2	.1463	.1509	.1097	.1097	.1097	.1132	.128
3	.1463	.1509	.1097	.1097	.1097	.1132	.1463
4	.1463	.1886	.128	.1097	.1097	.1698	.1646
5	.1829	.2241	.1463	.1829	.1463	.2054	.1829
6	.2195	.2427	.1829	.2561	.1829	.2614	.2195
7	.2561	.2801	.2926	.2926	.2561	.2957	.2926
8	.2561	.2772	.2743	.3292	.2926	.2772	.2926
9	.2195	.2587	.2926	.2926	.2561	.2587	.2561
10	.2926	.2957	.2561	.2534	.2378	.2218	.2561
11	.2561	.2743	.2715	.2561	.2218	.2402	.2561
12	.2033	.2561	.2715	.1463	.2218	.2195	.2534
13	.1848	.2561	.2896	.1463	.2218	.2195	.2195
14	.1848	.2195	.2172	.1463	.2218	.2012	.2195
15		.2195	.2172	.1463	.2033	.1829	.2172
16	.2957	.1829	.2195	.1463	.2033	.1829	.2534
17	.2218	.2561	.2195	.2195	.2587	.2195	.2534
18	.2587	.2926	.2534	.2561	.3142	.3109	.2926
19	.4251	.3292	.362	.3658	.4251	.4024	.3841
20	.3881	.3292	.3658	.3292	.3921	.3658	.3982
21	.3326	.2561	.3258	.2926	.3361	.2926	.3109
22	.2241	.1829	.2534	.2561	.2054	.2195	.2172
23	.1509	.1463	.1463	.1463	.132	.1829	.1448
24	.1463	.1509	.1097	.1097	.1097	.1132	.1463
Max	**.4251**	**.3292**	**.3658**	**.3658**	**.4251**	**.4024**	**.3982**
Min	**.1463**	**.1463**	**.1097**	**.1097**	**.1097**	**.1132**	**.128**
Avg	**.2297**	**.2321**	**.2260**	**.2087**	**.2199**	**.2243**	**.2347**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
KURUNDWAD[031] BU 1180
Substation No/ Name :- 144086 / 33/11kv Ghosarawad
Feeder No / Name : 207 / 11 KV Hanuman AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6249	.6554	.6706	.0156	.0152	.0152	.0152
2	.6249	.6554	.6706	.0152	.0152	.0152	.0152
3	.6249	.6554	.6706	.0152	.0152	.0152	.0152
4	.6562	.6706	.6859	.0152	.0152	.0152	.0152
5	.6562	.6706	.6859	.0152	.0152	.0152	.0152
6	.6874	.6622	.7011	.0152	.0152	.0152	.0152
7	.6874	.6706	.7468	.0152	.0152	.0152	.0152
8	.7186	.6773	.7468	.0152	.0152	.0152	.0152
9	.0152	.0151	.0152	.884	.9374	.9755	.9297
10	.0152	.0151	.0152	.823	1.078	.9783	.9907
11	.0152	.0152	.0152	.9297	1.0536	1.0084	1.0059
12	.0151	.0152	.0156	.9842	1.0837	1.0364	.9297
13	.0151	.0152		.9686	.6923	1.0517	.9907
14	.0152	.0152	.0152	.9686	.7164	.9907	.9907
15	.0151	.0152	.0156	.9686	.7526	.9907	.9998
16	.0151	.0152	.0152	.9686	.7676	1.0059	.9297
17	.0151	.0152	.0152	.0152	.0152	.0152	.0152
18	.0151	.0152	.0152	.0152	.0151	.0152	.0152
19	.0151	.0152	.0152	.0152	.0152	.0152	.0152
20	.0152	.0152	.0152	.0152	.0151	.0152	.0152
21	.0152	.0152	.0152	.0152	.0152	.0152	.0152
22	.0152	.0152	.0152	.0152	.0152	.0152	.0152
23	.6472	.6859	.0152	.0152	.0152	.0152	.7011
24	.6874	.6472	.6859	.0152	.0152	.0152	.0152
Max	**.7186**	**.6859**	**.7468**	**.9842**	**1.0837**	**1.0517**	**1.0059**
Min	**.0151**	**.0151**	**.0152**	**.0152**	**.0151**	**.0152**	**.0152**
Avg	**.2845**	**.2860**	**.2816**	**.3225**	**.3052**	**.3450**	**.3623**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
SHIROL[917] BU 9148
Substation No/ Name :- 144037 / 33/11 KV SHIRATI
Feeder No / Name : 201 / 11KV Shirati Gaothan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0747	.0514		.0934	.0526	.0747
2	.0686	.0747	.0514	.0747	.0747	.0526	.0747
3	.0686	.0747	.0514	.0747	.0747	.0526	.0747
4	.0747	.0747	.0514	.0747	.0934	.0526	.0747
5	.0934	.0934	.0857	.0934	.0747	.0876	.0934
6	.168	.168	.1715	.1494	.1867	.1753	.1494
7	.2614	.2427	.2401	.2614	.2054	.2103	.2614
8	.2427	.2241	.2229	.2241	.2614	.1886	.2614
9		.2058	.2054	.1867	.1886	.2241	.2241
10		.1543	.1867	.1494	.1715	.1867	.168
11		.1372	.1867	.1307	.1372	.168	.1494
12		.12	.1494	.112	.1372	.1307	.1494
13		.12	.1494	.0934	.1372	.112	.1494
14		.1029	.112	.0934	.0857	.112	.1307
15		.1029	.0934	.112	.1029	.1307	.112
16		.1029	.0747	.112	.0857	.112	.0747
17	.0857	.0857	.112		.0686	.112	.0747
18	.1372	.12	.1494		.1543	.1494	.1307
19	.2241	.2058	.2427	.2241	.2058	.1867	.1867
20	.2241	.1886	.2054	.2241	.1715	.2241	.2054
21	.168	.1543	.168	.2241	.1543	.2054	.2427
22	.1494	.12	.1307	.1307	.12	.1307	.1307
23	.0747	.0857	.0934	.112	.0876	.0934	.0857
24	.0686	.0747	.0514	.0747	.0934	.0526	.0747
Max	**.2614**	**.2427**	**.2427**	**.2614**	**.2614**	**.2241**	**.2614**
Min	**.0686**	**.0747**	**.0514**	**.0747**	**.0686**	**.0526**	**.0747**
Avg	**.1365**	**.1295**	**.1349**	**.1396**	**.1319**	**.1334**	**.1397**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
SHIROL[917] **BU 9148**
Substation No/ Name :- 144037 / 33/11 KV SHIRATI
Feeder No / Name : 202 / KUTWAD AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0171	.9149	.583	.5784	.5788
2		.0343	.0171	.9149	.583	.5784	.5788
3		.0343	.0171	.9149	.5975	.5784	1.1389
4	.0343	.0343	.0171	.9149	.5487	.5784	.5975
5	.0343	.0343	.0171	.9335	.6001	.5784	.5975
6	.0343	.0343	.0343	.9335	.6908	.5609	.6224
7	.0343	.0343	.0343	.9522	.7468	.631	.6348
8	.0343	.0343	.0343	1.0082	.8589	.7202	.7282
9		1.2003	1.643	.0373	.0343	.0187	.0343
10		1.5947	1.9044	.0171	.0343	.0373	.0343
11			2.0165	.0344	.0171	.0373	.0857
12		1.5432	1.9791	.0343	.0171	.0373	.0343
13		1.5947	1.9978	.0343	.0171	.0373	.0343
14		1.7833	1.8484		.0171	.0373	.0514
15		1.7833	1.7924	.0343	.0171	.0373	.0373
16		1.7147	1.7551	.0343	.0171	.0373	.0343
17	.0343	.0343	.0373		.0171	.0373	.0343
18	.0514	.0343	.0373		.0343	.0373	.0343
19	.0514	.0343	.0373	.0343	.0343	.0373	.0343
20	.0514	.0343	.0373	.0343	.0343	.0373	.0343
21	.056	.0343	.0373	.0343	.0343	.0373	.0343
22	.0514	.0343	.0373	.0343	.0343	.0373	.0343
23	.0514	.0171	.9522	.5487	.5784	.5975	.0343
24	.0373	.0514	.0171	.9335	.6535	.5784	
Max	**.056**	**1.7833**	**2.0165**	**1.0082**	**.8589**	**.7202**	**1.1389**
Min	**.0343**	**.0171**	**.0171**	**.0171**	**.0171**	**.0187**	**.0343**
Avg	**.0422**	**.5114**	**.6799**	**.4444**	**.2834**	**.2702**	**.2636**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
SHIROL[917] **BU 9148**
Substation No/ Name :- 144037 / 33/11 KV SHIRATI
Feeder No / Name : 203 / SHIROL AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0514	.0343	1.1389	.8916	.8589	.8589
2	.0514	.0514	.0343	1.1389	.8745	.8589	.8962
3	.0514	.0343	.0343	1.1203	.8745	.8589	.8589
4	.0514	.0514	.0343	1.1389	.8573	.8589	.8589
5	.0514	.0343	.0343	1.1576	.8916	.8589	.8775
6	.0343	.0343	.0343	1.1949	1.0269	.9465	.9149
7	.0343	.0343	.0343	1.2323	1.0117	1.0692	.9709
8	.0343	.0343	.0343	1.3817	1.2136	1.0974	1.0456
9		1.6289	1.6804	.0343	.0343	.0373	.0343
10		1.8861	2.0725	.0343	.0343	.0373	.0343
11		2.0062	2.2405	.0343	.0343	.0373	.0343
12		2.0576	2.1285	.0343	.0343	.0373	.0343
13		1.9719	2.0911	.0344	.0343	.0373	.0857
14		1.9547	2.1285	.0343	.0343	.0373	.0343
15		1.9204	2.0725	.0343	.0343	.0373	.0343
16		1.9547	1.9231	.0343	.0343	.0373	.0343
17	.0343		.0373		.0343	.0373	.0343
18	.0343		.0373		.0343	.0373	.0343
19	.0343		.0373	.056	.0343	.0373	.0343
20	.0514	.0343	.0373	.0514	.0343	.0373	.0343
21	.0343	.0343	.0373	.0514	.0343	.0373	.0343
22	.0514	.0343	.0373	.0343	.0343	.0373	.0343
23	.0514	.0343	1.1203	.8745	.8589	.8775	.0343
24	.0514	.0514	.0343	1.1389	.9088		.8589
Max	**.0514**	**2.0576**	**2.2405**	**1.3817**	**1.2136**	**1.0974**	**1.0456**
Min	**.0343**	**.0343**	**.0343**	**.0343**	**.0343**	**.0373**	**.0343**
Avg	**.0439**	**.7569**	**.7496**	**.5448**	**.4121**	**.3829**	**.3628**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
SHIROL[917] BU 9148
Substation No/ Name :- 144037 / 33/11 KV SHIRATI
Feeder No / Name : 204 / GHALWAD AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6687	.5144	.4973	.056	.0514	.0351	.0373
2	.6687	.5144	.4973	.056	.056	.0351	.0373
3	.6687	.5144	.4973	.056	.0514	.0351	.0187
4	.6687	.5144	.4973	.056	.0514	.0351	.0373
5	.6516	.4973	.4973	.056	.0514	.0351	.0373
6	.7095	.5316	.5487	.056	.0514	.0351	.0373
7	.7468	.5658	.6001	.056	.0343	.0351	.0373
8	.7468	.583	.6001	.056	.0343	.0343	.0373
9		.0514	.056	.9431	1.749	1.419	1.3203
10		.0514	.056	1.7551	1.8861	2.0538	1.8298
11		.0514	.056	1.8671	1.8861		1.8176
12		.0514	.056	2.1658	1.989	2.2218	2.0351
13		.0514	.056	2.0538	1.9204	2.2218	1.8861
14		.0514	.056	2.0911	1.8861	2.1472	1.8519
15		.0514	.056	1.8861	1.9204	2.0911	1.8298
16		.0514	.056	1.9033	1.8519	2.0165	1.7924
17	.0514	.5144	.0373		.0343	.0373	.0343
18	.0514	.0514	.0373		.0343	.0373	.0343
19	.0514	.0514	.056	.056	.0343	.0373	.0343
20	.0514	.0514	.056	.0514	.0343	.0373	.0343
21	.0514	.0514	.056	.0514	.0343	.0373	.0343
22	.0514	.0514	.056	.0514	.0343	.0373	.0343
23	.5041	.4973	.056	.0514	.0351	.0373	.7373
24	.6859	.4973	.4973	.056	.0514	.0351	.0373
Max	**.7468**	**.583**	**.6001**	**2.1658**	**1.989**	**2.2218**	**2.0351**
Min	**.0514**	**.0514**	**.0373**	**.0514**	**.0343**	**.0343**	**.0187**
Avg	**.4392**	**.2672**	**.2306**	**.7014**	**.6568**	**.6412**	**.6510**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
SHIROL[917] BU 9148
Substation No/ Name :- 144037 / 33/11 KV SHIRATI
Feeder No / Name : 205 / 11KV Shirti Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.3772	.2401	.0373	.0343	.0175	.0373
2	.6001	.3772	.2401	.0373	.0343	.0175	.0373
3	.583	.3772	.2401	.0373	.0343	.0175	.0373
4	.583	.3601	.2401	.0373	.0343	.0175	.0373
5	.5487	.3601	.2401	.0373	.0343	.0175	.0373
6	.5487	.3772	.2401	.0373	.0343	.0175	.0373
7	.583	.4287	.3258	.0373	.0343	.0175	.0373
8	.5658	.4973	.3429	.0373	.0343	.0171	.0373
9		.0343	.0187	.9335	1.4918	1.6804	1.7177
10		.0343	.0187	1.5684	1.6975	1.9418	1.7177
11			.0187		1.8519	1.9044	1.8484
12		.0171	.0187	1.6289	1.8861	1.9605	1.7177
13			.0187	1.5947	1.8519	1.9231	1.4575
14		.0343	.0187	1.6289	1.6461	1.9231	1.4232
15		.0343	.0187	1.7177	1.6461	1.9418	1.3717
16		.0343	.0187	1.643	1.6461	1.7924	1.3546
17	.0343	.0343	.0187		.0171	.0373	.0343
18	.0343	.0343	.0187		.0171	.0373	.0343
19	.0373	.0343	.0187	.0343	.0171	.0373	
20	.0343	.0343	.0187	.0343	.0171	.0373	
21	.0343	.0343	.0373	.0343	.0171	.2241	.0343
22	.0343	.0343	.0373	.0343	.0171	.0373	.0343
23	.3772	.2743	.0373	.0343	.0175	.0373	.5487
24	.6173	.3921	.2743	.0373	.0343	.0175	.0373
Max	**.6173**	**.4973**	**.3429**	**1.7177**	**1.8861**	**1.9605**	**1.8484**
Min	**.0343**	**.0171**	**.0187**	**.0343**	**.0171**	**.0171**	**.0343**
Avg	**.3635**	**.1916**	**.1133**	**.5344**	**.5894**	**.6530**	**.6196**

 Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
SHIROL[917] **BU 9148**
Substation No/ Name :- 144037 / 33/11 KV SHIRATI
Feeder No / Name : 206 / Kutwad Gaothan **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.0686	.0514	.056	.056	.0526	.056
2	.056	.0514	.0514	.056	.056	.0526	.056
3	.056	.056	.0514	.056	.056	.0526	.056
4	.056	.0514	.0514	.056	.056	.0526	.0747
5	.0934	.0686	.0686	.0747	.0934	.0701	.0934
6	.1494	.1307	.1372	.112	.1494	.1402	.1307
7	.1867	.1867	.1543	.1494	.168	.1578	.1867
8	.168	.1867	.1715	.112	.1867	.1543	.168
9		.12	.112	.0934	.1372	.1494	.1494
10		.12	.112	.0934	.12	.0934	.1307
11		.12	.2054		.1029	.112	.112
12		.1029	.112	.056	.0857	.112	.112
13		.0857	.112	.056	.0857	.0747	.112
14		.0686	.0934	.056	.0857	.0747	.112
15		.0686	.0934	.0747	.1029	.0934	.0747
16		.0686		.0686	.0857	.0934	.056
17	.0514	.0686	.112		.1029	.0934	.0747
18	.1029	.0857	.1307		.1372	.112	.112
19	.1543	.1715	.2054	.1372	.1715	.1494	.168
20	.1715	.1543	.1867	.168	.1543	.1867	.1867
21	.1543	.1372	.1494	.1494	.1543	.168	.2054
22	.1029	.1029	.112	.0934	.1029	.112	.112
23	.0747	.0514	.056	.056	.0876	.0747	.0857
24	.056	.0686	.0514	.056	.056	.0526	.056
Max	**.1867**	**.1867**	**.2054**	**.168**	**.1867**	**.1867**	**.2054**
Min	**.0514**	**.0514**	**.0514**	**.056**	**.056**	**.0526**	**.056**
Avg	**.1056**	**.0998**	**.1122**	**.0872**	**.1081**	**.1035**	**.1117**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
SHIROL[917] BU 9148
Substation No/ Name :- 144037 / 33/11 KV SHIRATI
Feeder No / Name : 207 / Ghalwad Gaothan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.0857	.1715	.1867	.12	.1227	.0934
2	.0934	.0857	.1715	.1867	.1029	.1227	.0934
3	.0934	.0934	.1715		.1307	.1227	.0934
4	.0934	.112	.1715	.1867	.168	.1227	.112
5	.2801	.168	.2401	.2054	.2427	.1928	.1307
6	.2801	.2987	.3258	.2614	.2801	.298	.1867
7	.3361	.3174	.3429	.3361	.2987	.298	.3174
8	.2987	.2801	.3429	.3174	.2572		.3174
9		.2572	.3547	.2915	.2572	.3547	.2427
10		.2915	.3361	.2743	.2401	.3361	.2801
11		.3086	.2614	.2058	.1715	.2801	.3361
12			.2241	.1867	.1715	.2614	.2614
13		.1543	.2054	.168	.1715	.2614	.2229
14		.1543	.168	.1372	.1715	.2241	.2058
15		.1886	.1494	.1372	.1372	.2054	.2054
16		.1886	.1494	.1372	.1372	.2241	.2241
17	.1886	.1543	.2054		.1543	.2427	.2614
18	.1886	.1715	.2241		.2229	.2427	.2614
19	.2743	.2743	.2987	.2572	.2572	.2987	.3361
20	.2572	.2572	.2801	.2801	.2572	.2801	.2614
21	.1886	.2401	.2617	.2427	.2229	.2427	.2427
22	.1886	.2058	.2241	.168	.1886	.2054	.2054
23	.0934	.1886	.2054	.1372	.1578	.112	.112
24	.0934	.0857	.1715	.1867	.12	.1227	.112
Max	**.3361**	**.3174**	**.3547**	**.3361**	**.2987**	**.3547**	**.3361**
Min	**.0934**	**.0857**	**.1494**	**.1372**	**.1029**	**.112**	**.0934**
Avg	**.1901**	**.1983**	**.2357**	**.2138**	**.1933**	**.2250**	**.2131**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
SHIROL[917] BU 9148
Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND
Feeder No / Name : 201 / 11KV K'Guland SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.016	.0152	.016	.7373	.5868	.6535	.5426
2	.016	.0152	.016	.7373	.5868	.6535	.5426
3	.0158	.0152	.0158	.7459	.5868	.6535	.5365
4	.0158	.0152	.0158	.7459	.6036	.6722	.5365
5	.0158	.0152	.0158	.7373	.6036	.6722	.5868
6	.016	.0152	.0156	.7373	.6036	.6722	.6783
7	.016	.0152	.0156	.8192	.8718	.8029	.6859
8	.016	.0152	.0156	.8192	.8886	.9335	.7122
9	.8383	1.2407	1.065	.0143	.0187	.0187	.0143
10	1.2407	1.3413	1.326	.0152	.0187	.0152	.0152
11	1.3748	1.3748	1.326	.0152	.0187	.0151	.0152
12	1.3245	1.3748	1.2431	.0152	.0187	.0149	.0152
13	1.2742	1.3413	1.2431	.0152	.0187	.0149	.0152
14	1.2742	1.3748	1.286	.0152	.0187	.0149	.0152
15	1.3077	1.3413	1.2071	.0152	.0187	.0149	.0152
16	1.3077	1.1736	1.2071	.0152	.0187	.0149	.0152
17	.0152	.016	.0156	.0152	.0187	.0149	.0152
18	.0152	.016	.0152	.0152	.0187	.0091	.0152
19	.0152	.016	.0152	.0152	.0187	.0149	.0152
20	.0152	.0156	.0152	.0152	.0187	.0149	.0152
21	.0152	.0156	.0152	.0152	.0187	.0149	.0152
22	.0152	.0156	.0152	.0152	.0187	.0143	.0152
23	.0152	.0156	.7373	.0152	.6535	.5365	.0152
24	.016	.0152	.016	.7373	.5868	.6535	.5365
Max	**1.3748**	**1.3748**	**1.326**	**.8192**	**.8886**	**.9335**	**.7122**
Min	**.0152**	**.0152**	**.0152**	**.0143**	**.0187**	**.0091**	**.0143**
Avg	**.4247**	**.4504**	**.4531**	**.2935**	**.2847**	**.2963**	**.2327**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
SHIROL[917] BU 9148
Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND
Feeder No / Name : 202 / 11KV Ganeshwadi SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7459	.7682	.7865	.0152	.016	.0187	.0141
2	.7459	.7682	.7865	.0151	.016	.0187	.0141
3	.7373	.7682	.7956	.0151	.016	.0187	.0143
4	.7373	.7682	.7956	.0151	.016	.0187	.0143
5	.7459	.8002	.7956	.0151	.016	.0187	.0143
6	.9945	.8802	.7865	.0151	.016	.0187	.0143
7	1.1736	1.0883	1.0608	.0143	.016	.0187	.0141
8	1.1869	1.1843	1.1603	.0143	.016	.0187	.0143
9	.016	.016	.016	1.1336	1.6244	1.6804	1.4575
10	.016	.0152	.016	1.6804	2.0725	2.0119	1.7604
11	.0152		.016	1.7124	2.1285	1.989	1.7924
12	.016		.0156	1.7764	2.0538	1.9784	1.7604
13	.016		.0156	1.6804	2.0538	1.9281	1.7284
14	.016	.0152	.016	1.6324	2.0911	1.9719	1.7284
15	.016	.0152	.016	1.6324	2.0538	1.8652	1.6964
16	.016	.0152	.0156	1.6164	1.9605	1.8652	1.6804
17	.016	.0152	.0152	.016	.0187	.0149	.016
18	.016	.0152	.0152	.016	.0187	.0149	.016
19	.016	.0133	.0151	.016	.0187	.0149	.016
20	.016	.0149	.0151	.016	.0187	.0143	.016
21	.016	.0149	.0151	.016	.0187	.0143	.016
22	.016	.0149	.0152	.016	.0187	.0137	.016
23	.7202	.8048	.0152	.016	.0187	.0143	.8002
24	.7373	.7682	.7865	.0152	.016	.0187	.0141
Max	**1.1869**	**1.1843**	**1.1603**	**1.7764**	**2.1285**	**2.0119**	**1.7924**
Min	**.0152**	**.0133**	**.0151**	**.0143**	**.016**	**.0137**	**.0141**
Avg	**.3645**	**.4173**	**.3328**	**.5463**	**.6797**	**.6483**	**.6095**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
SHIROL[917] BU 9148
Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND
Feeder No / Name : 203 / 11KV Alas Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5087	.4359	.4359	.0151	.0133	.1867	.0564
2	.5087	.4359	.4409	.0151	.0133	.1867	.0141
3	.5087	.4359	.4409	.0151	.0133	.1867	.0141
4	.5087	.4359	.4409	.0151	.0133	.1867	.0141
5	.5144	.4191	.4409	.0151	.0133	.1867	.0139
6	.5144	.4191	.4409	.0151	.0133	.2054	.0139
7	.5144	.4862	.4409	.0107	.0133	.4294	.0141
8	.5487	.503	.4748	.0124	.0133	.5228	.0143
9	.016		.016	.5967	.8962	.4481	.8916
10	.0143	.0156	.016	.8383	.8962	1.0852	
11	.0143	.0156	.016	.8383	1.1763	1.0974	1.1317
12	.0143	.0156	.016	.8383	1.1949	1.0631	.9724
13	.0143	.0152	.0158	.8383	1.1763	1.0631	.9724
14	.0143	.0152	.0158	.8551		1.0288	.9556
15	.0143	.0152	.0158	.8551	1.0269	1.0288	.9221
16	.0143	.0152	.0156	.8383	1.0456	1.0288	.8886
17	.0143	.0152	.0152	.0133	.0187	.0149	.0133
18	.0143	.0152	.0152	.0133	.0187	.0149	.0133
19	.0143	.0152	.0151	.0133	.0187	.0143	.0133
20	.0143	.0152	.0152	.0133	.0187	.0143	.0133
21	.0143	.0152	.0152	.0133	.0187	.0143	.0133
22	.0143	.0152	.0152	.0133	.0187	.0143	.0133
23	.4191	.3605	.0152	.0133	.0187	.0143	.4024
24	.5087	.4191	.3688	.0152	.0133	.0187	.0141
Max	**.5487**	**.503**	**.4748**	**.8551**	**1.1949**	**1.0974**	**1.1317**
Min	**.0143**	**.0152**	**.0151**	**.0107**	**.0133**	**.0143**	**.0133**
Avg	**.2190**	**.1978**	**.1733**	**.2800**	**.3332**	**.4189**	**.3211**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
SHIROL[917] **BU 9148**
Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND
Feeder No / Name : 204 / 11KV Alas Village **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1696	.1543	.1526	.2229	.1715		.1677
2	.1696	.1543	.1357	.2229	.1715		.1341
3	.1715	.1543	.1357	.2229	.1715		.1372
4	.1696	.1543	.2035	.2229	.1715		.2058
5	.1696	.2629	.2035	.2629	.2279		.2401
6	.4287	.333	.2743	.2743	.3506		.2743
7	.4557	.4557	.2058	.3391	.4382		.3856
8	.4207	.3681	.3429	.3772	.4382		.3856
9	.4031	.3681	.3772	.3155	.4481		.3856
10	.3856	.2743	.4207	.298	.4481	.3506	.3681
11	.3506	.2743	.4031	.3155	.3361	.3429	.3506
12	.3155	.2713	.3772	.2279	.3547	.3429	.3155
13	.3506	.2713	.3429	.2279	.3734	.3429	.333
14	.298	.2743	.3429	.2103	.4108	.2713	.3506
15	.2804	.2743	.2915	.2454	.3921	.3506	.3506
16	.2804	.2035	.2543	.2804	.3734	.3429	.3155
17	.3506	.2713	.3429	.298	.3361	.2915	.2401
18	.3856	.2713	.3856	.3856	.3547	.3772	.3856
19	.5609	.2743	.5083	.5083	.3734	.5609	.5609
20	.5959	.2058	.4733	.5083	.4668	.4908	.5083
21	.4382	.2103	.4382	.4382	.4481	.4382	.4382
22	.3506	.1715	.3506	.3506	.2987	.0143	.3658
23	.2279	.1753	.2401	.2229	.2427	.2229	.2454
24	.2035	.1715	.1696	.2229	.1886		.2204
Max	**.5959**	**.4557**	**.5083**	**.5083**	**.4668**	**.5609**	**.5609**
Min	**.1696**	**.1543**	**.1357**	**.2103**	**.1715**	**.0143**	**.1341**
Avg	**.3305**	**.2500**	**.3072**	**.3000**	**.3328**	**.3386**	**.3194**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
SHIROL[917] **BU 9148**
Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND
Feeder No / Name : 205 / 11KV Ganeshwadi Gaothan **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1696	.1753	.1844	.1677	.1753	.2054	.1677
2	.1696	.1753	.1844	.1677	.1715	.1867	.1696
3	.1715	.1753	.1844	.1696	.1715	.1867	.1753
4	.1715	.1753	.1966	.2035	.1715	.2427	.1753
5	.2572	.2804	.2622	.2713	.2279	.3361	.2658
6	.4344	.4024	.2622	.3086	.3292	.3921	.362
7	.4024	.439	.3772	.3761	.4024	.4294	.4163
8	.3658	.3292	.3086	.3258	.3658	.3547	.3982
9	.2896	.2629	.2743	.2715	.2987	.2801	.3077
10	.2629	.1844	.2915	.2279	.2987	.3077	.2926
11	.2629	.2012	.2915	.2279	.2801	.2686	.2279
12	.2279	.192	.2743	.1928	.2427	.2715	.2629
13	.2279	.218	.2572	.1928	.2614	.2534	.2804
14	.2454	.2347	.2572	.2103	.2241	.2402	.2629
15	.2279	.1677	.2454	.2103	.2427	.2534	.2629
16	.2454	.2347	.2401	.1928	.2614	.2896	.2454
17	.2926	.2374	.2743	.2454	.2987	.2865	.298
18	.3658	.2374	.3841	.3292	.3361	.362	.3658
19	.4938	.3429	.4938	.4207	.3734	.4755	.5121
20	.5304	.362	.4572	.4572	.4108	.4572	.4755
21	.4024	.3258	.3658	.4024	.4294	.3841	.4207
22	.3109	.2534	.2715	.2926	.3734	.2926	.3292
23	.1928	.181	.1715	.2103	.2241	.1928	.2103
24	.1865	.1928	.1677	.1696	.1928	.2054	.1844
Max	**.5304**	**.439**	**.4938**	**.4572**	**.4294**	**.4755**	**.5121**
Min	**.1696**	**.1677**	**.1677**	**.1677**	**.1715**	**.1867**	**.1677**
Avg	**.2878**	**.2492**	**.2782**	**.2602**	**.2818**	**.2981**	**.2945**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
SHIROL[917] **BU 9148**
Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND
Feeder No / Name : 206 / 11KV Krishna Feeder **PURELY LIS FEEDERS**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.0248	.0476	.0171	.0381	.0934	.1886
4	.0171	.0476	.0171	.0381	.1494	.2263
5	.0171	.0476	.0274	.0381	.2241	.2263
6	.1036	.1219	.0274	.0476	.3547	.2263
7	.1036	.2641	.0427	.0476	.3174	.2263
8	.1219	.2641	.048	.1991	.2987	.2641
9	.1219	.2641	.0747	.2054	.2987	.2829
10	.2534	.2353	.0171	.2801	.3772	
11	.2534	.2328	.0171	.4294	.3772	.3961
12	.2534	.2328	.061	.3921	.3772	.3961
13	.2534	.2149	.0137	.3361	.3772	.3961
14	.2534	.2195	.0137	.4108	.3772	.3961
15	.2534	.2241	.0137	.4108	.3772	.3961
16	.2534	.2241	.0213	.3734	.415	.3961
17	.2534	.2195	.0137	.3921	.3961	.3961
18	.2534	.2195	.0137	.4294	.415	.3772
Max	**.2534**	**.2641**	**.0747**	**.4294**	**.415**	**.3961**
Min	**.0171**	**.0476**	**.0137**	**.0381**	**.0934**	**.1886**
Avg	**.1744**	**.1925**	**.0275**	**.2543**	**.3266**	**.3194**

 Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
SHIROL[917] **BU 9148**
Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND
Feeder No / Name : 207 / 11KV Vijay-Ganesh **PURELY LIS FEEDERS**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.181	.0537	.0895	.0229	.0934	.1433
4	.2743	.0537	.0895	.0229	.0934	.181
5	.2743	.0537	.0895	.0229	.168	.181
6	.2715	.0537	.394	.0229	.2427	.1646
7	.2743		.3801	.4163	.168	.4066
8	.3475	.394	.3982	.4163	.168	.3658
9	.3475	.394	.4163	.3921	.2427	.3658
10	.2686	.3982	.3841	.4108	.3258	.3801
11	.4119	.3982	.4024	.4108	.3658	.4163
12	.4119	.3982	.3841	.4108	.4024	.3982
13	.4119	.4024	.3841	.4108	.4024	.3982
14	.4119	.3982	.3841	.4108	.2561	.3982
15	.4119	.3982	.3801	.4108	.2561	.3982
16	.4119	.3982	.3801	.4108	.4066	.3982
17	.4119	.3258	.3982	.4108	.362	.3982
18	.2865	.362	.4024	.4108	.2534	.3801
Max	**.4119**	**.4024**	**.4163**	**.4163**	**.4066**	**.4163**
Min	**.181**	**.0537**	**.0895**	**.0229**	**.0934**	**.1433**
Avg	**.3381**	**.2988**	**.3348**	**.3133**	**.2629**	**.3359**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
SHIROL[917] **BU 9148**
Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND
Feeder No / Name : 208 / 11 KV Bubnal Express **PURELY LIS FEEDERS**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.0905	.0533	.0171	.0476	.0934	.0895
4	.0905	.0533	.0171	.0476	.0934	.0905
5	.0905	.0533	.0171	.0476	.0934	.0905
6	.1267	.0533	.0171	.0476	.112	.0905
7	.1267	.0533	.12	.0914	.1307	.181
8	.128	.1886	.1791	.1509	.168	.1829
9	.1829	.1886	.181	.1867	.2427	.1829
10	.2452	.1991	.2172	.2241	.2353	.2957
11	.2452	.2353	.2172	.2241	.2402	.3142
12	.2452	.2353	.2353	.2427	.2402	.2957
13	.2452	.2353	.2353	.2241	.2378	.2957
14	.2402	.2172	.2378	.2241	.2402	.2957
15	.2402	.2172	.2378	.2427	.2378	.2957
16	.2402	.2195	.2195	.2614	.2427	.2957
17	.2402	.2195	.1829	.2241	.2402	.2957
18	.2402	.2172	.1829	.2241	.2218	.2353
Max	**.2452**	**.2353**	**.2378**	**.2614**	**.2427**	**.3142**
Min	**.0905**	**.0533**	**.0171**	**.0476**	**.0934**	**.0895**
Avg	**.1886**	**.1650**	**.1572**	**.1694**	**.1919**	**.2205**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
SHIROL[917] BU 9148
Substation No/ Name :- 144090 / 33 / 11 KV Nandani Substation
Feeder No / Name : 201 / 11 KV Nandani Ag Feeder KV- 11 / OUTGOING SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6722	.631	.5975	.0187	.017	.0175	.0187
2	.6722	.631	.6348	.0187	.017	.0175	.0187
3	.6722	.631	.6348	.0187	.017	.0175	.0187
4	.6722	.6661	.6348	.0187	.0171	.0175	.0187
5	.7095	.7011	.6722	.0187	.0171	.0175	.0187
6	.7095	.7362	.6722	.0187	.0171	.0175	.0187
7	.7468	.7712	.8589	.0185	.0168	.0175	.0187
8	.8501	.9114	.9709		.017	.0175	.0187
9	.0181	.0171	.0187	1.1088	.9709	.9709	1.0082
10	.0181	.017	.0187	1.1827	1.1203	1.1949	1.1949
11	.0181	.0168	.0187	1.2323	1.1576	1.0829	1.2696
12	.0181	.0168	.0187	1.1949	1.1949	1.1203	1.2323
13	.0181	.0166	.0187	1.1576	1.1576	1.0456	1.2696
14	.0181	.0166	.0187	1.1694	1.1203	1.0456	1.1949
15	.0181	.0166	.0187	1.0562	1.1203	1.0082	1.1576
16	.0181	.0166	.0187	.9431	1.0829	1.1088	1.1576
17	.0181	.0168	.0187	.0171	.0175	.0187	.0175
18	.0181	.0171	.0187	.0171	.0175	.0191	.0175
19	.0181	.0173	.0187	.017	.0175	.0187	.0175
20	.0181	.0173	.0187	.017	.0175	.0191	.0175
21	.0362	.0173	.0187	.017	.0175	.0187	.0175
22	.0181	.0171	.0187	.017	.0175	.0187	.0175
23	.631	.5975	.0187	.017	.0175	.0187	.6516
24	.6722	.631	.5975	.0187	.017	.0175	.0187
Max	**.8501**	**.9114**	**.9709**	**1.2323**	**1.1949**	**1.1949**	**1.2696**
Min	**.0181**	**.0166**	**.0187**	**.017**	**.0168**	**.0175**	**.0175**
Avg	**.3033**	**.2977**	**.2731**	**.4049**	**.3834**	**.3694**	**.4337**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
SHIROL[917] **BU 9148**
Substation No/ Name :- 144090 / 33 / 11 KV Nandani Substation
Feeder No / Name : 202 / 11 KV Nandani Vg Feeder KV- 11 / OUTGOING **GAOTHAN FEEDER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168	.1753	.1867	.1867	.1696	.1753	.1867
2	.168	.1753	.1867	.1867	.1696	.1753	.1867
3	.1867	.181	.1867	.1867	.1696	.1753	.1869
4	.168	.181	.2241	.2054	.2058	.1753	.2241
5	.2241	.1753	.3361	.2614	.2743	.2103	.3174
6	.3361	.2454	.3734	.3361	.3086	.2454	.3547
7	.4108	.4031	.4108	.4066	.3688	.4031	.4108
8	.3734	.3681	.3734	.3258	.3391	.4207	.4108
9	.3439	.3429	.4108	.3326	.3547	.3361	.3734
10	.3439	.3353	.4294	.3326	.3734	.3174	.3734
11	.3077	.3018	.3561	.3547	.2801	.3174	.2987
12	.3258	.2683	.3391	.3361	.3547	.3547	.3361
13	.3077	.2321	.2957	.3174	.3361	.3361	.3547
14	.2715	.2155	.2801	.2263	.2427	.3174	.2987
15	.3077	.2321	.2614	.2641	.3361	.2801	.2427
16	.362	.2652	.3174	.3018	.3361	.2865	.2054
17	.3439	.0171	.3921	.3258	.3506	.3734	.333
18	.362	.2915	.3547	.3772	.3856	.4108	.3681
19	.4706	.4508	.4854	.407	.4557	.4294	.4557
20	.4706	.3814	.5228	.373	.4207	.4668	.5083
21	.3982	.3641	.4066	.3052	.3681	.3734	.4207
22	.3077	.2401	.3077	.2713	.333	.3174	.298
23	.2454	.2054	.2241	.2374	.298	.2614	.2534
24	.168	.2103	.1848	.1867	.2035	.2103	.2241
Max	**.4706**	**.4508**	**.5228**	**.407**	**.4557**	**.4668**	**.5083**
Min	**.168**	**.0171**	**.1848**	**.1867**	**.1696**	**.1753**	**.1867**
Avg	**.3072**	**.2608**	**.3269**	**.2935**	**.3098**	**.3071**	**.3176**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
SHIROL[917] **BU 9148**
Substation No/ Name :- 144090 / 33 / 11 KV Nandani Substation
Feeder No / Name : 203 / Ganesh Bakery Feeder KV- 11 / OUTGOING
NON SHEDDABLE EXPRESS HV FEEDERS (CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.1052	.112	.1109	.1017	.0876	.0934
2	.112	.1052	.112	.112	.0848	.0876	.0934
3	.112	.1052	.112	.0934	.0848	.0876	.0934
4	.112	.1052	.112	.0934	.0857	.1267	.112
5	.1307	.1402	.1307	.1109	.0857	.1227	
6	.168	.1753	.1307	.112	.0857	.1578	.0373
7	.2054	.2103	.1867	.2218	.2012	.1928	.2241
8	.2218	.0175	.2427		.2204	.2279	.2427
9	.2534	.2058	.2241		.2241	.2241	.2427
10	.2715	.2035	.2427	.2218	.2427	.2241	.2614
11	.2896	.2012	.2801	.2054	.2427	.2427	.3361
12	.2896	.2012	.2801	.2801	.2427	.2614	.3174
13	.2172	.2155	.2427	.2614	.2427	.2241	.2801
14	.2172	.2155	.2427	.2263	.2241	.2241	.2614
15	.2172	.2321	.2427	.2452	.2241	.2402	.2614
16	.2534	.2321	.2427	.2452	.2241	.2241	.2241
17	.2172	.2347	.2614	.2401	.2454	.2427	.2804
18	.1991	.2401	.2614	.2572	.2279	.2241	.2279
19	.2353	.2427	.2241	.2374	.2279	.2054	.2279
20	.2172	.208	.2054	.2035	.2103	.1867	.2103
21	.181	.1907	.1867	.1696	.1753	.168	.2103
22	.1629	.1543	.0373	.1357	.1402	.168	.1753
23	.1227	.168	.0373	.1187	.1052	.1494	.1448
24	.112	.1052	.1478	.112	.1017	.0876	.112
Max	**.2896**	**.2427**	**.2801**	**.2801**	**.2454**	**.2614**	**.3361**
Min	**.112**	**.0175**	**.0373**	**.0934**	**.0848**	**.0876**	**.0373**
Avg	**.1929**	**.1756**	**.1874**	**.1825**	**.1771**	**.1828**	**.2030**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
SHIROL[917] **BU 9148**
Substation No/ Name :- 144090 / 33 / 11 KV Nandani Substation
Feeder No / Name : 204 / 11 KV Agar Village Feeder KV- 11 / OUTGOING **GAOTHAN FEEDER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.1227	.1494	.1478	.1526	.1753	.1867
2	.112	.1227	.1494	.1478	.1357	.1402	.168
3	.1307	.1227	.1494	.1663	.1357	.1402	.168
4	.1494	.1227	.168	.168	.1372	.1402	.1494
5	.1494	.1578	.1867	.1867	.1543	.1753	.1867
6	.2054	.1928	.2054	.1867	.1715	.2103	.2241
7	.2587	.2629	.2801	.2587	.2012	.2804	.3174
8	.2801	.298	.2987		.2374	.2804	.3174
9	.2534	.2229	.2987	.2033	.3174	.3547	.3361
10	.2534	.3391	.3174	.2218	.2801	.2801	.2801
11	.2454	.2683	.3174	.2427	.2614	.2801	.2987
12	.2353	.3018	.2987	.2427	.2614	.2801	.2987
13	.2534	.2652	.2054	.1867	.2801	.2801	.2801
14	.2715	.2321	.2241	.2075	.2614	.2427	.2987
15	.2715	.2652	.2054	.1886	.2987	.2033	.2427
16	.2534	.2984	.2241	.1886	.2987	.2987	.2427
17	.2534	.2683	.2241	.2058	.2279	.2427	.2279
18	.362	.2743	.2987	.2743	.2629	.3174	.2629
19	.362	.2947	.3734	.2713	.2715	.3734	.333
20	.3077	.2774	.3734	.2374	.2629	.3174	.298
21	.2715	.2601	.2801	.2204	.2279	.2801	.2629
22	.2353	.2058	.2054	.2035	.2103	.2054	.2279
23	.1753	.2054	.1494	.1696	.2103	.1867	.181
24	.112	.1227	.1867	.1612	.1526	.1753	.1867
Max	**.362**	**.3391**	**.3734**	**.2743**	**.3174**	**.3734**	**.3361**
Min	**.112**	**.1227**	**.1494**	**.1478**	**.1357**	**.1402**	**.1494**
Avg	**.2298**	**.2293**	**.2404**	**.2038**	**.2255**	**.2442**	**.2490**

 Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
SHIROL[917] **BU 9148**
Substation No/ Name :- 144090 / 33 / 11 KV Nandani Substation
Feeder No / Name : 205 / 11KV Dharangutti Ag Feeder KV- 11 / OUTGOING **SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.531	1.3321	1.3817	.0373	.0339	.0351	.0373
2	1.531	1.3672	1.3676	.0373	.0339	.0351	.0373
3	1.531	1.3672	1.3817	.0373	.0339	.0351	.0373
4	1.5684	1.4022	1.419	.0373	.0343	.0351	.0374
5	1.5684	1.4022	1.419	.0373	.0343	.0351	
6	1.5684	1.4373	1.4563	.0373	.0343	.0351	
7	1.587	1.5074	1.5893	.037		.0351	
8	1.7364	1.7353	1.8671	.0362	.0339	.0351	
9	.0362	.0343	.056	2.0698	2.1472	2.3529	2.2965
10	.0362	.0339	.0543	2.2177	2.4459	2.7446	2.8006
11	.0373	.0335	.0554	2.2779	2.5766	2.8006	2.8567
12	.0362	.0335	.0373	2.2592	2.5953	2.838	2.8193
13	.0362	.0332	.0373	2.1658	2.4832	2.4646	2.4459
14	.0362	.0332	.0373	2.2068	2.4646	2.4272	2.4272
15	.0362	.0332	.0373	2.2257	2.3712	2.3899	2.3899
16	.0362	.0332	.0373	2.1879	2.3712	2.3152	2.3152
17	.0362	.0335	.0373	.0343	.0351	.0373	.0351
18	.0362	.0343	.0373	.0343	.0351	.0374	.0351
19	.0362	.0347	.0339	.0339	.0351	.056	.0351
20	.0362	.0347	.0373	.0339	.0351	.056	.0351
21	.0362	.0347	.0373	.0339	.0351	.0373	.0351
22	.0362		.0335	.0339	.0351	.0373	.0351
23	1.3321	1.3443	.0373	.0339	.0351	.0373	1.4118
24	1.531	1.3321	1.3306	.0373	.0339	.0351	.0373
Max	**1.7364**	**1.7353**	**1.8671**	**2.2779**	**2.5953**	**2.838**	**2.8567**
Min	**.0362**	**.0332**	**.0335**	**.0339**	**.0339**	**.0351**	**.0351**
Avg	**.6664**	**.6377**	**.5758**	**.7576**	**.8684**	**.8728**	**1.1080**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
VADGAON[032] BU 1198
Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN
Feeder No / Name : 201 / MINCHE AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4915	.5182	.5182	.2401	.2401	.1943	.1966
2	.4915	.5182	.5182	.2401	.2401	.1943	.1966
3	.5144	.5182	.5182	.2401	.2401	.1943	.1966
4	.4915	.5182	.5182	.2401	.2401	.1943	.1966
5	.5898	.6478	.6478	.2743	.2401	.1943	.2294
6	.7537	.9069	.8421	.3086	.2743	.2267	.2622
7	1.0159	1.0364	1.166	.3086		.2591	.2949
8	1.3108	1.4575	1.3603	.2743	.3086	.2267	.2949
9	.2401	.1943	.1943	.9175	.8848	.852	
10	.2743	.1966	.2743	1.4575	1.5074	1.4419	
11	.2591	.2622	.2743	1.6194	1.704	1.6385	
12	.2591	.2294	.2743	1.6194	1.7695	1.6385	
13	.2591	.2294	.2401	1.6194	1.7695		
14	.2591	.2294	.2401	1.6194	1.704	1.3763	
15	.2591	.2294	.2401	1.5546	1.5729		
16	.1943	.2294	.2401	1.5546	1.5729	1.5074	
17	.2591	.2294	.2401	.1619	.1966	.1966	
18	.3239	.2591	.2743	.2987	.2267	.2949	.2743
19	.3239	.3239	.3086	.3086	.2915	.3277	
20	.3239	.2915	.3086	.3086	.2915	.3277	.3086
21	.2591	.2591	.3086	.3086	.2591	.3277	.2743
22	.2267	.1943	.2743	.2743	.1943	.2622	.2401
23	.5182	.5182	.2401	.2743	.1943	.2294	.4915
24	.4915	.5182	.5182	.2401	.2401	.1943	.1966
Max	**1.3108**	**1.4575**	**1.3603**	**1.6194**	**1.7695**	**1.6385**	**.4915**
Min	**.1943**	**.1943**	**.1943**	**.1619**	**.1943**	**.1943**	**.1966**
Avg	**.4329**	**.4381**	**.4391**	**.6776**	**.7027**	**.5591**	**.2609**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
VADGAON[032] BU 1198
Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN
Feeder No / Name : 202 / NARANDE Ag FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0648	.0648	.6882	.5571	.5182	.5441
2	.0686	.0648	.0648	.6882	.5571	.5182	.5441
3	.0686	.0648	.0648	.6882	.5571	.5182	.5441
4	.0686	.0648	.0648	.6882	.5571	.5182	.5441
5	.1029	.0648	.0648	.6882	.6226	.583	.6081
6	.112	.0648	.0648	.7537	.7865	.7125	.6401
7	.1029	.0648	.0648	.852	.8848	.9069	.7682
8	.1029	.0648	.0648	.9175	1.0159	1.0364	.8962
9	.7537	.8002	1.0364	.0655	.1029	.0648	
10	1.3763	1.2803	1.5729	.0648	.064	.0648	
11	1.587	1.4723	1.7695	.0648	.064	.0648	
12	1.6194	1.5043	1.704	.0648	.0648	.0648	
13	1.6194	1.5043	1.6385	.0648	.0648		
14	1.587	1.5364	1.6057	.0648	.064	.064	
15	1.5546	1.5043	1.5729	.0648	.064	.0648	
16	1.4251	1.2163	1.4746	.0648	.064	.0648	
17	.0648	.064	.0686	.0648	.064	.0648	
18	.0648	.0648	.0686	.0686	.0648	.0972	.1029
19	.0972	.0972	.0686	.1029	.0972	.0972	.1029
20	.0972	.0972	.1029	.1029	.0972	.096	.1029
21	.0972	.0972	.1029	.1029	.0648	.096	.1029
22	.0648	.0972	.1029	.1029	.0648	.064	.0686
23	.0648		.6882	.5571	.5182	.5182	.0686
24	.0686	.0648	.0648	.6882	.5571	.5182	.5441
Max	**1.6194**	**1.5364**	**1.7695**	**.9175**	**1.0159**	**1.0364**	**.8962**
Min	**.0648**	**.064**	**.0648**	**.0648**	**.064**	**.064**	**.0686**
Avg	**.5349**	**.5182**	**.5900**	**.3447**	**.3175**	**.3181**	**.4121**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
VADGAON[032] BU 1198
Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN
Feeder No / Name : 203 / KHOCHI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0648	.0648	.9175	.7537	.7773	.7773
2	.0686	.0648	.0648	.9175	.7537	.7773	.7773
3	.0686	.0648	.0648	.9175	.7537	.7773	.7773
4	.0686	.0648	.0648	.9175	.7537	.0648	.7773
5	.0686	.0648	.0648	.9175	.7537	.8421	.7773
6	.0686	.0648	.0648	1.0486	.8848	.9393	.8097
7	.0686	.0648	.0648	1.1469	.9831	.9717	.9717
8	.0678	.0648	.0648	1.2452	1.0486	1.1012	.1943
9	1.1469	1.3603	1.6518	.0655	.0686	.0648	
10	1.6385	1.9433	2.0317	.0648	.0648	.0648	
11	1.9433	2.17	2.13	.0648	.0648	.0648	
12	.1943	2.1376	2.13	.0648	.0648	.0648	
13	1.9757	2.1052	2.13	.0648	.0648		
14	1.9433	2.1376	2.0317	.0648	.0648	.0648	
15	1.8461	2.1376	1.9662	.0648	.0648	.0648	
16	1.749	.3239	1.8351	.0648	.0648	.0648	
17	.0648	.0648	.0686	.0648	.0648	.0648	
18	.0648	.0648	.0686	.0686	.0648	.0648	.0686
19	.0648	.0663	.0686	.0686	.0648	.0648	.0686
20	.0648	.0648	.0686	.0686	.0648	.0648	.0686
21	.0648	.0648	.0686	.0343	.0648	.0648	.0686
22	.0648	.0648	.0686	.0655	.0648	.0648	.0686
23	.0648	.0663	.9175	.7537	.7773	.7773	.0686
24	.0686	.0648	.0648	.9175	.7537	.7773	.7773
Max	**1.9757**	**2.17**	**2.13**	**1.2452**	**1.0486**	**1.1012**	**.9717**
Min	**.0648**	**.0648**	**.0648**	**.0343**	**.0648**	**.0648**	**.0686**
Avg	**.5628**	**.6398**	**.7425**	**.4412**	**.3803**	**.376**	**.4701**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
VADGAON[032] BU 1198
Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN
Feeder No / Name : 204 / BENDAVADE AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9831	.9069	.9282	.0686	.0686	.0663	.0655
2	.9831	.9069		.0686	.0686	.0663	.0655
3	.9831	.9069	.9069	.0686	.0686	.0663	.0655
4	.9831	.9069	.9282	.0686	.0686	.0663	.0655
5	.9831	.9069	.9282	.0686	.0686	.0663	.0655
6	1.1797	.9717	1.0608	.0686	.0686	.0663	.0655
7	1.3108	.9717	1.1934	.0686	.0686	.0663	.0655
8	1.3763	1.1984	1.2597	.0686	.0686	.0663	.0671
9	.0686	.0648	.0663	1.2452	1.3763	1.3565	
10	.0686	.0655	.0686	1.8564	1.8679	1.8991	
11	.0663	.0655	.0686	1.8233	2.0317	2.0348	
12	.0663	.0655	.0686	1.7238	1.9989	1.4754	
13	.0663	.0732	.0686	1.8233	1.9989		
14	.0663	.0732	.0686	1.989	1.9662	1.643	
15	.0663	.0655	.0686	1.8564	1.8679	1.8107	
16	.0663	.0655	.0686	1.989	1.8679	1.8107	
17	.0663	.0655	.0686	.0663	.0655	.0671	
18	.0648	.0663	.0686	.0686	.0663	.0671	.0686
19	.0648	.0663	.0686	.0686	.0663	.0655	.0686
20	.0648	.0663	.0686	.0686	.0663	.0655	.0686
21	.0648	.0663	.0686	.0686	.0663	.0655	.0686
22	.0648	.0663	.0686	.0686	.0663	.0655	.0686
23	.9069	.9282	.0686	.0686	.0648	.0655	.852
24	.9831	.9069	.9282	.0686	.0686	.0663	.0655
Max	**1.3763**	**1.1984**	**1.2597**	**1.989**	**2.0317**	**2.0348**	**.852**
Min	**.0648**	**.0648**	**.0663**	**.0663**	**.0648**	**.0655**	**.0655**
Avg	**.4832**	**.4353**	**.3983**	**.6417**	**.6690**	**.5691**	**.1191**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
VADGAON[032] BU 1198
Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN
Feeder No / Name : 205 / BENDAVADE GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0724	.0724	.112	.0747	.0724	.1097
2	.0747	.0724	.0724	.112	.0747	.0724	.1097
3	.0747	.0724	.0724	.112	.0747	.0724	.1097
4	.0747	.0724	.0724	.112	.0747	.0724	.1097
5	.112	.0724	.1086	.112	.0747	.1086	.1097
6	.112	.1448	.1086	.1494	.1494	.1448	.1829
7	.1494	.181	.1448	.1867	.1494	.181	.1829
8	.1867	.181	.1448	.1867	.1867	.1448	.1463
9	.1867	.181	.181	.1867	.1494	.1433	
10	.1494	.1829	.1867	.1448	.1494	.1433	
11	.181	.1097	.1494	.1448	.1463	.1075	
12	.181	.1463	.1494	.1086	.1463	.1448	
13	.1448	.1097	.1494	.1086	.1494		
14	.1448	.1097	.1494	.1086	.1097	.1086	
15	.1448	.1097	.1494	.1086	.1097		
16	.1448	.1097	.1494	.1086	.1097	.1097	
17	.181	.1463	.1867	.1448	.1097	.1463	
18	.2534	.1448	.2614	.1867	.1448	.1829	.1867
19	.2534	.181	.2614	.2241	.2534	.2195	.2614
20	.2534	.181	.2614	.2241	.181	.2195	.2241
21	.181	.1867	.2614	.1867	.1867	.1829	.1867
22	.1448	.1086	.1867	.112	.1448	.1463	.1494
23	.1086	.0724	.1494	.0747	.0724	.1097	.112
24	.0747	.1086	.0724	.112	.0747	.0724	.1097
Max	**.2534**	**.1867**	**.2614**	**.2241**	**.2534**	**.2195**	**.2614**
Min	**.0747**	**.0724**	**.0724**	**.0747**	**.0724**	**.0724**	**.1097**
Avg	**.1494**	**.1274**	**.1542**	**.1403**	**.1290**	**.1321**	**.1527**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
VADGAON[032] BU 1198
Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN
Feeder No / Name : 206 / Khochi Gaothan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.181	.1886	.1494	.1494	.1494	.1509
2	.1494	.181	.1867	.1494	.1494	.1494	.1509
3	.1494	.181	.1867	.1494	.1494	.1509	.1509
4	.1494	.181	.1867	.1494	.1494	.1509	.1509
5	.1867	.2172	.2241	.1867	.1867	.1886	.1509
6	.2241	.2172	.2614	.2241	.2241	.2263	.2263
7	.2614	.2534	.2987	.2614	.2614	.2641	.2987
8	.2614	.2896	.2614	.2614	.2614	.2263	.2987
9	.2614	.2896	.2241	.2241	.2614	.2263	
10	.2241	.2241	.2241	.2241	.2241	.1886	
11	.2241	.1867	.2241	.1867	.2241	.1886	
12	.1943	.1867	.1867	.1494	.1867	.1509	
13	.1619	.1867	.1494	.1494	.1829		
14	.1619	.1494	.1494	.1494	.1867	.1509	
15	.1494	.1867	.1494	.1494	.1494	.1509	
16	.1494	.1867	.1494	.1494	.1867	.2263	
17	.2241	.2614	.2614	.1867	.2241	.2263	
18	.2896	.2987	.3361	.2241	.2614	.3395	.3086
19	.362	.4108	.4108	.3734	.3361	.4527	.4481
20	.362	.3734	.3734	.3361	.3734	.4108	.3734
21	.2534	.2987	.3361	.2987	.2987	.3734	.3361
22	.2172	.2241	.2241	.2241	.2241	.2614	.2241
23	.181	.1886	.2241	.1867	.1886	.2241	.1867
24	.1494	.181	.1886	.1494	.1494	.1867	.1867
Max	**.362**	**.4108**	**.4108**	**.3734**	**.3734**	**.4527**	**.4481**
Min	**.1494**	**.1494**	**.1494**	**.1494**	**.1494**	**.1494**	**.1509**
Avg	**.2124**	**.2306**	**.2336**	**.2038**	**.2162**	**.2288**	**.2428**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
VADGAON[032] BU 1198
Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN
Feeder No / Name : 207 / Narand Vg GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0648	.0747	.0747	.0747	.0747	.0747
2	.0747	.0724	.0747	.0747	.0747	.0747	.0747
3	.0747	.0724	.0747	.0747	.0747	.0754	.0747
4	.0747	.0724	.0747	.0747	.0747	.0747	.0747
5	.0747	.0716	.0747	.0747	.112	.0754	.0747
6	.112	.1086	.112	.112	.112	.1132	.112
7	.1494	.1448	.112	.1494	.1494	.1494	.1494
8	.1494	.1448	.112	.1494	.1494	.1132	.112
9	.112	.1448	.1494	.112	.112	.112	
10	.112	.1867	.1867	.112	.112	.112	
11	.112		.1494	.112	.1494	.1494	
12	.112		.1494	.0747	.1494	.112	
13	.112	.112	.112	.0747	.1494		
14	.112	.112	.112	.0747	.112	.112	
15		.112	.112	.0747	.112	.1494	
16	.112	.112	.1494	.0747	.112	.112	
17	.1494	.1494	.1494	.112	.1494	.1494	
18	.1448	.1494	.1867	.112	.1494	.1494	.1867
19	.181	.1867	.1867	.1867	.1867	.1867	.2241
20	.181	.1867	.1867	.1867	.1867	.1867	.2241
21	.181	.1494	.1494	.1494	.1494	.1494	.1494
22	.1086		.112	.112	.0747	.112	.112
23	.0724	.0747	.0747	.0747	.0747	.0747	.0747
24	.0747	.0724	.0747	.0747	.0747	.0754	.0747
Max	**.181**	**.1867**	**.1867**	**.1867**	**.1867**	**.1867**	**.2241**
Min	**.0724**	**.0648**	**.0747**	**.0747**	**.0747**	**.0747**	**.0747**
Avg	**.1157**	**.1190**	**.1229**	**.1043**	**.1198**	**.1171**	**.1195**

 Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
VADGAON[032] **BU 1198**
Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN
Feeder No / Name : 208 / Minche Vg **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.2172	.1867	.1867	.1867	.1867	.1829
2	.1867	.2172	.1867	.1867	.1867	.1867	.1829
3	.1867	.2172	.1867	.1867	.1867	.1867	.1829
4	.1867	.2172	.1886	.1867	.1867	.1867	.1829
5	.2241	.3258	.2241	.2241	.2241	.2614	.2195
6	.3361	.362	.2987	.2987	.2987	.3395	.2926
7	.4108	.362	.4527	.3361	.3361		.3658
8	.3734	.362	.3772	.3361	.3361	.3361	.3658
9	.3734	.362	.2987	.2987	.3361	.2926	
10		.3292	.2987	.2614	.2926	.2926	
11	.2987	.2926	.2987	.2614	.2926	.2926	
12	.2987	.2926	.2987	.2241	.2926	.2926	
13	.2987	.2926	.2614	.2241	.2926		
14	.2987	.2195	.2614	.2241	.2926	.2195	
15	.2987	.2195	.2614	.2241	.2926	.2195	
16	.2987	.2561	.2614	.1494	.2561	.2561	
17	.2987	.2926	.2987	.2241	.2926	.3292	
18	.362	.3734	.3734	.2987	.3361	.3658	.3734
19	.4344	.5228	.4854	.4481	.4108	.5121	.4854
20	.4344	.4854	.4481	.4108	.4481	.439	.4481
21	.362	.3239	.4108	.3734	.3734	.3658	.3734
22	.2534	.2641	.2614	.2614	.2987	.2926	.2614
23	.2172		.1867	.1867	.2241	.2195	
24	.1867	.2172	.1867	.1867	.1867	.2241	.1829
Max	**.4344**	**.5228**	**.4854**	**.4481**	**.4481**	**.5121**	**.4854**
Min	**.1867**	**.2172**	**.1867**	**.1494**	**.1867**	**.1867**	**.1829**
Avg	**.2959**	**.3054**	**.2914**	**.2583**	**.2858**	**.2862**	**.2929**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
VADGAON[032] BU 1198
Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN
Feeder No / Name : 209 / 11KV Buwache Wathar AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0324	.0305	1.0814	.8848	.7773	.8718
2	.0343	.0324	.0312	1.0814	.8848	.7773	.8718
3	.0343	.0324	.0312	1.0814	.8848	.7773	.8718
4	.0343	.0324	.0324	1.0814	.8848	.7773	.8718
5	.0343	.0324	.0312	1.0814	.9259	.7773	.8718
6	.0343	.0324	.0312	1.1469	.9831	.8421	.9054
7	.0343	.0324	.0324	1.1797	1.0486	.9069	.9724
8	.0343	.0324	.0312	1.2125	1.1142	1.0364	1.0395
9	1.2452	1.3413	1.3927	.0343	.0343	.0251	
10	1.5729	1.7772	1.6385	.0305	.034	.0251	
11	1.6956	1.8107	1.7695	.0267	.0343	.0251	
12	1.7295	1.7772	1.7368	.0267	.034	.029	
13	1.6385	1.7436	1.6712	.0286	.0335		
14	1.6385	1.7436	1.6712	.0274	.0335	.0312	
15	1.6956	1.7101	1.6712		.0335	.0312	
16	1.6617	1.6766	1.6057	.0324	.0335	.0312	
17	.0324	.0351	.0343	.0305	.0335	.0328	
18	.0324	.0324	.0343	.0343	.0324	.0312	.0343
19	.0324	.0305	.0343	.0343	.0305	.0293	.0343
20	.0324	.0305	.0343	.0343	.0305	.0312	.0343
21	.3563	.0305	.0343	.0343	.0305		.0343
22	.0324	.0324	.0343	.0343	.0305	.0316	.0343
23	.0324	.0305	1.0814	.8848	.7773	.8817	.0343
24	.0343	.0324	.0305	1.0814	.8848	.7773	.8718
Max	**1.7295**	**1.8107**	**1.7695**	**1.2125**	**1.1142**	**1.0364**	**1.0395**
Min	**.0324**	**.0305**	**.0305**	**.0267**	**.0305**	**.0251**	**.0343**
Avg	**.5724**	**.5872**	**.6136**	**.4922**	**.4055**	**.3948**	**.5569**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
VADGAON[032] BU 1198
Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN
Feeder No / Name : 210 / Khandoba AG (Bhendwade) SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5571	.5182	.5182	.0343	.0343	.0312	.0312
2	.5571	.5182	.5182	.0343	.0343	.0312	.0312
3	.5571	.5182	.5182	.0343	.0343	.0312	.0312
4	.5571	.5182	.5182	.0343	.0343	.0305	.0312
5	.5898	.5182	.5182	.0343	.0343	.0305	.0312
6	.6226	.583	.6478	.0343	.0343	.0305	.0312
7	.6554	.583	.7125	.0343	.0343	.0324	.0312
8	.6882	.6802	.7449	.0343	.0343	.0312	.0312
9	.0343	.0324	.0324	.6554	.6226	.6401	
10	.0373	.0316	.0343	.9393	.9717	.9602	
11	.0324	.032	.0343	.9393	1.004	.9602	
12	.0324	.032	.0343	.8745	1.004	.7362	
13	.0324	.0324	.0343	.9069	1.004		
14	.0324	.0328	.0343	.9393	1.004	.8642	
15	.0324	.032	.0343	.9717	.9717	.8642	
16	.0324	.032	.0343		.9069	.8642	
17	.0316	.032	.0343	.0324	.0324	.032	
18	.0324	.0316	.0343	.0343	.0316	.032	.0343
19	.0324	.0312	.0343	.0343	.0312	.032	.0343
20	.0324	.0312	.0343	.0343	.0312	.032	.0343
21	.0324	.0312	.0343	.0343	.0312	.0324	.0343
22	.0324	.0312	.0343	.0343	.0312	.0328	.0343
23	.5182	.506	.0343	.0343	.0312	.032	.5571
24	.5571	.5182	.5182	.0343	.0343	.0312	.032
Max	**.6882**	**.6802**	**.7449**	**.9717**	**1.004**	**.9602**	**.5571**
Min	**.0316**	**.0312**	**.0324**	**.0324**	**.0312**	**.0305**	**.0312**
Avg	**.2633**	**.2461**	**.2386**	**.2945**	**.3341**	**.2780**	**.0673**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
VADGAON[032] BU 1198
Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN
Feeder No / Name : 401 / 33 kv Sharad Co-gen
Feeder KV- 33 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.6008	3.8409	4.0741	3.6008		3.8089	3.7311
2	3.6008	3.8409	3.77	3.6008		3.5848	3.5117
3	3.6008	3.8409	3.9209	3.6008	3.3951	3.9609	3.6214
4	3.6008	3.8409	4.0741	3.6008	3.2922	3.6214	3.7311
5	3.5608	4.0604	4.0329	3.6008	3.3951	3.4591	4.0604
6	3.6008	4.0604	3.6214		3.2922	3.3951	3.2922
7	3.6008	3.8409	3.3951		3.3951	3.2556	3.8409
8	3.6008	3.8409	3.6214		3.6008	3.6969	3.7311
9	3.6008	3.8409	3.7346		3.3951	3.8409	
10	3.9095	4.0604	3.7037		3.8409	3.9506	
11	3.7643	3.6214	3.8066		3.2922	3.7311	
12	3.5608	3.7311	3.8066		3.7311	3.5117	
13	4.0329	3.5117	4.1152		3.5117		
14	3.9209	4.145	3.6008		3.7311	3.8409	
15	3.7643	3.5117	3.6008		3.8409	3.7311	
16	3.9209	3.7311	3.3951		3.7311	3.2922	
17	3.9209	3.7311	3.6008		3.6214	3.7311	
18	3.8409	3.2487	3.6008		3.3951	3.8409	3.8066
19	3.8409	3.2487	3.0864		2.9172	3.7311	3.3951
20	3.8409	3.4728	3.6008		2.8487	3.6214	3.3951
21	3.8409	4.0329	3.6008		3.2487	3.5117	3.3951
22	3.8409	3.3608	3.6008		3.0247	3.7311	3.6008
23	3.8409	3.9209	3.6008		3.5848	3.5117	3.6008
24	3.6008	3.8409	3.9209	3.6008		3.4728	3.8409
Max	**4.0329**	**4.145**	**4.1152**	**3.6008**	**3.8409**	**3.9609**	**4.0604**
Min	**3.5608**	**3.2487**	**3.0864**	**3.6008**	**2.8487**	**3.2556**	**3.2922**
Avg	**3.7420**	**3.7573**	**3.7036**	**3.6008**	**3.4326**	**3.6449**	**3.6370**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
VADGAON[032] BU 1198
Substation No/ Name :- 144081 / 33/11KV Latwade Sub station
Feeder No / Name : 201 / 11KV Bhokari (Bhadole) AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0324		.7907	.6478	.5668	.6154
2	.0191	.0324		.7748	.6226	.5506	.583
3		.0324		.759	.6226	.5506	.583
4		.0324		.7499	.6226	.5506	.6154
5	.0191	.0324		.7655	.6554	.6154	.6154
6	.0191	.0324		.8002	.6882	.664	.6478
7	.0191	.0324		.9282	.7865	.7125	.7125
8	.0191	.0324		.9646		.7611	.6802
9	1.0059	1.2146	1.2186		.0328	.0324	.0324
10	1.4022	1.4575	1.4373	.0305	.0324	.0324	.0324
11	1.4842	1.4419	1.6194		.0324	.0305	.0305
12	1.4842	1.491	1.6194		.0324	.0305	.0305
13	1.4373	1.4413	1.4998		.0324		.0305
14	1.4373	1.3765	1.5223		.0324	.0305	.0305
15	1.4899	1.3117	1.4083		.0324	.0305	.0305
16	1.3748	1.1822	1.3123		.0324	.0305	.0305
17	.0305	.0324	.0305	.0191	.0324	.0305	.0305
18			.0305		.0324	.0305	.0191
19	.0324		.0305	.0324	.0324	.0324	.0229
20	.0324		.0305	.0324	.0324	.0324	.0191
21	.0324		.0305	.0324	.0324	.0324	.0191
22	.0324		.0305	.0324	.0324	.0324	.0191
23	.0324		.7655	.6097	.5668	.6478	.0191
24	.0191	.0324		.7907	.6478	.5735	.6154
Max	**1.4899**	**1.491**	**1.6194**	**.9646**	**.7865**	**.7611**	**.7125**
Min	**.0191**	**.0324**	**.0305**	**.0191**	**.0324**	**.0305**	**.0191**
Avg	**.5449**	**.6245**	**.8391**	**.5070**	**.2745**	**.2870**	**.2527**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
VADGAON[032] BU 1198
Substation No/ Name :- 144081 / 33/11KV Latwade Sub station
Feeder No / Name : 202 / 11KV Latwade AG Fdr SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0202	1.0364	.7537	.061	.0648	.0648	.0648
2	1.004	1.0364	.7537	.061	.0648	.0648	.0648
3	1.004	1.0202	.7701	.061	.0648	.0648	.0648
4	1.0202	1.0202	.7701	.061	.0648	.0648	.0648
5	1.0202	1.0364	.7865	.061	.081	.081	.0648
6	1.0364	1.0364	.8192	.061	.081	.081	.0648
7	1.166	1.1822	.8684	.061	.081	.081	.081
8	1.1984	1.166	.9012	.061	.0648	.081	.0648
9	.0381	.0648	.0655		1.6518	1.6032	1.7695
10	.0381	.0648		1.7166	1.9109	1.8299	2.0405
11		.0486	.061	1.7204	2.0645	1.8884	1.9685
12		.0486	.061	1.7859	2.0645	1.9595	1.9919
13		.0486	.061	1.8187	2.0317		1.8947
14		.0486	.061	1.7532	1.9826	1.8564	1.8404
15		.0486	.061	1.704	1.9826	1.8884	1.8244
16		.0486	.061	1.8351	1.9826	1.8564	
17		.0486	.061	.0286	.0648	.0457	.0457
18		.0486	.061		.0648	.0457	.0381
19	.081		.061	.0648	.081	.081	.0381
20	.081		.061	.081	.081	.081	.0191
21	.081		.061	.081	.081	.0324	.0476
22	.081		.061	.081	.081	.081	.0476
23	1.0526	.7209	.061	.081	.081	.081	.8745
24	1.0364	1.0526	.7537	.061	.0648	.081	.081
Max	**1.1984**	**1.1822**	**.9012**	**1.8351**	**2.0645**	**1.9595**	**2.0405**
Min	**.0381**	**.0486**	**.061**	**.0286**	**.0648**	**.0324**	**.0191**
Avg	**.6849**	**.5413**	**.3494**	**.6046**	**.7016**	**.6084**	**.6546**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
VADGAON[032] BU 1198
Substation No/ Name :- 144081 / 33/11KV Latwade Sub station
Feeder No / Name : 203 / 11KV Latwade Village GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2172	.2172	.1646	.1753	.181	.2172	.181
2	.2172	.1991	.1646	.1753	.181	.1991	.1448
3	.1991	.1991	.1829	.1578	.2172	.2591	.1448
4	.2534	.2534	.2012	.1595	.2715		.2172
5		.3292	.2743	.3189	.362	.362	.3258
6	.6154	.6036	.3292	.3721	.5611	.6154	.5973
7	.6878	.695	.6036	.4961	.6335	.6697	.5792
8	.5792	.695	.695	.5194	.6697	.724	.5792
9	.5611	.5304	.6401		.5249	.5792	.5792
10		.4938	.5487	.4075	.4525	.5249	.5249
11	.5304	.4207	.4835	.4938	.4887	.4908	.5083
12	.4572	.4207	.4207	.3475	.4163	.4784	.3294
13	.4207	.362	.3898	.3658	.439		.3506
14	.3841	.362	.3898	.3658	.4024	.3544	.3506
15	.3658	.3801	.4075	.3658	.4207	.3544	.3506
16	.3658	.362	.4075	.2926	.4572	.3582	.3681
17	.4938	.4344	.4031	.3258	.5121	.3681	.3681
18	.5121	.6036	.4607		.567	.5609	.5611
19	.8048	.7499	.6556	.6697	.8413	.7602	.6878
20	.7316	.6401	.4961	.6154	.7316	.6878	.6335
21	.6401	.567	.4607	.543	.6335	.5792	.5249
22	.4527	.439	.3544		.5068	.362	.4525
23	.2926	.2743	.2303	.2353	.2896	.2353	.2715
24	.2353	.2561	.2195	.1928	.1991	.2172	.181
Max	**.8048**	**.7499**	**.695**	**.6697**	**.8413**	**.7602**	**.6878**
Min	**.1991**	**.1991**	**.1646**	**.1578**	**.181**	**.1991**	**.1448**
Avg	**.4553**	**.4370**	**.3993**	**.3617**	**.4567**	**.4526**	**.4088**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
VADGAON[032] BU 1198
Substation No/ Name :- 144081 / 33/11KV Latwade Sub station
Feeder No / Name : 204 / Laxmi AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0297		.3963	.3864	.3864	.3567
2	.0191	.0297		.3906	.3864	.3715	.3567
3	.0191			.3749	.3567	.3715	.3567
4	.0191	.0297		.3704	.3567	.3864	.3864
5	.0191	.0297		.3858	.3567	.3864	.4012
6	.0191	.0297		.3858	.3567	.4161	.4161
7	.0191	.0297		.4843	.4458	.5053	.4161
8	.0229	.0297		.5312	.4755	.5944	.4458
9	.6859	.6836	.6706		.0297	.0297	.0297
10	.7727	.8322	1.0059	.0305	.0297	.0297	.0297
11	.884	.8916	1.0212		.0297	.0305	.0305
12	.9145	.9511	1.0212		.0297	.0305	.0305
13	.9145	.9511	.945		.0297		.0305
14	.884	.9511	.9374		.0297	.0305	.0305
15	.884	.9214	.8592		.0297	.0305	.0305
16	.8535	.8916	.7811		.0297	.0305	
17		.0297	.0305	.0191	.0297	.0305	
18		.0297	.0305		.0297	.0305	.0305
19	.0297		.0305	.0297	.0297		.0191
20	.0297		.0305	.0297	.0297		.0191
21			.0305	.0297	.0297		.0191
22	.0297		.0305	.0297	.0297	.0297	.0191
23	.0297		.4062	.3864	.3864	.3864	.0191
24	.0191	.0297		.3963	.3864	.3864	.3864
Max	**.9145**	**.9511**	**1.0212**	**.5312**	**.4755**	**.5944**	**.4458**
Min	**.0191**	**.0297**	**.0305**	**.0191**	**.0297**	**.0297**	**.0191**
Avg	**.3375**	**.4095**	**.5221**	**.2669**	**.1796**	**.2247**	**.1755**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
JAYASINGPUR DIVISION[503]
VADGAON[032] BU 1198
Substation No/ Name :- 144081 / 33/11KV Latwade Sub station
Feeder No / Name : 205 / Tasgaon LIS PURELY LIS FEEDERS
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.3601	.2267	.3601	.3401	.3401	
7	.3601	.3401	.3601	.3401	.3401	.3401
8	.3601		.3601	.3401	.3401	.3401
9	.3601	.0162	.3601	.3401	.3401	.3401
10	.3601	.3401	.3601	.1619	.3401	.3521
11	.3601	.3401	.3521	.1619	.3521	.3521
12	.3601	.3401	.3521	.1619	.3561	.3521
13	.3601	.3401	.3521	.3401		.3521
14	.3601	.3401	.3561	.3401	.3561	.3521
15	.3601	.3521	.3561	.3401	.3521	.3521
16	.3601	.3401	.3561	.3401		
17	.3601	.3401	.3561	.3401	.3521	.3561
18	.3601	.3401	.3521	.3401	.3521	.3601
Max	**.3601**	**.3521**	**.3601**	**.3401**	**.3561**	**.3601**
Min	**.3601**	**.0162**	**.3521**	**.1619**	**.3401**	**.3401**
Avg	**.3601**	**.3047**	**.3564**	**.2990**	**.3474**	**.3499**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
GAGANBAWADA S/DN.[807] BU 4807
Substation No/ Name :- 144006 / 33/11 KV GAGANBAWDA S/STN
Feeder No / Name : 201 / 11 KV Katali GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.2587	.2987	.2829	.0732	.0716	.1109
2	.2829	.2241	.2614	.2641	.0732	.0709	.0924
3	.2641	.1867	.2587	.2614	.0732	.0526	.0739
4	.2427	.1867	.2987	.2614	.0724	.0686	.0739
5	.2957	.168	.3475	.2957	.0724	.0848	.0914
6	.3658	.3361		.3142	.1052	.1006	.1595
7	.439	.5359	.4108		.1928	.1696	.2835
8	.2801	.3361	.5729	.2957	.2454	.2883	.3366
9	.3174	.3258	.6401	.2561	.3258	.3921	.2658
10	.3326	.3881	.5544	.3258	.2743		.2658
11	.3224	.3429	.3224	.905	1.1641		.3366
12	.3149	.3391	.333	1.2437	1.5384	1.3352	.0514
13	.2155		.3429	1.262	1.5402	1.3375	.0354
14	.1865	.3521	.3258	1.2803	1.56	1.6221	.0532
15	.2652	.3647	.3601	1.0425	1.4746	1.4746	.3155
16	.2743	.3315	.3258	1.3575	1.2174	1.0608	.333
17	.2543	.407	.3086	1.3213	1.283		.3544
18	.2915	.4409	.1907	1.0517	1.0867	.9036	.443
19	.3511	.333	.5487	.3109	.3045	.6908	.3921
20	.3734	.3292	.3511	.2743		.3734	.3142
21	.4108	.3361	.3511	.2195	.2987	.2772	.5041
22	.4108	.3961	.3475	.1109	.1509	.2054	.5601
23	.4108	.3361	.3292	.0924	.112	.1867	.5975
24	.2263	.2987	.3206	.3206	.0739	.0934	.112
Max	**.439**	**.5359**	**.6401**	**1.3575**	**1.56**	**1.6221**	**.5975**
Min	**.1865**	**.168**	**.1907**	**.0924**	**.0724**	**.0526**	**.0354**
Avg	**.3079**	**.3284**	**.3652**	**.5804**	**.5788**	**.5171**	**.2565**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
KADAMWADI[039] BU 6173
Substation No/ Name :- 144001 / 33/11KV SHIYE
Feeder No / Name : 201 / 11 KV Shiye Ag Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0819	.0819	.0819	.0671	.0819	.0819	.0655
2	.0819	.0819	.0819	.0671	.0819	.0819	.0655
3	.0655	.0819	.0819	.0655	.0819	.0819	.0655
4	.0655	.0819	.0819	.0655	.0819	.0819	.0655
5	.0655	.0819	.0819	.0655	.0819	.0819	.0655
6	.0819	.0819	.0819	.0655	.0819	.0819	.0819
7	.0819	.0819	.0819	.0819	.0819	.0819	.0819
8	.0819	.0819	.0819	.0819	.0819	.0819	.0838
9	.0819	.0819	.0819	.0819	.0655	.0819	.0819
10	.0819	.0671	.0819	.0819	.0655	.0819	.0819
11	1.8023	1.9113	1.8842	1.8351	1.8778	1.7204	1.5074
12	1.8679	1.8442	2.0153		2.0119	1.5238	1.6385
13	1.9662	1.7436	2.0809		1.6095	1.6221	1.5402
14	1.9662	2.0454	2.1136	1.8023	1.8107	1.5238	1.4746
15	1.9662	2.0119	2.1464	1.8023	1.8442	1.5074	1.5402
16	1.9662	2.0119	2.1956	1.8023	1.8778	1.6057	1.6385
17	1.9662	2.0119	2.1792	1.8351	1.9113		1.5729
18	1.8023	1.7204	2.0454	1.6385	1.6385	1.4419	1.5729
19	.0819	.0819	.0838	.0819	.0819	1.4754	.0655
20	.0819	.0819	.0838	.0819	.0819	.0838	.0655
21	.0819	.0819	.0838	.0819	.0819	.0819	.0655
22	.0819	.0819	.0671	.0819	.0819	.0819	.0655
23	.0819	.0819	.0655	.0819	.0819	.0655	.0655
24	.0819	.0819	.0819	.0671	.0819	.0819	.0655
Max	**1.9662**	**2.0454**	**2.1956**	**1.8351**	**2.0119**	**1.7204**	**1.6385**
Min	**.0655**	**.0671**	**.0655**	**.0655**	**.0655**	**.0655**	**.0655**
Avg	**.6902**	**.6915**	**.7477**	**.5416**	**.6608**	**.5928**	**.5674**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
KADAMWADI[039] BU 6173
Substation No/ Name :- 144001 / 33/11KV SHIYE
Feeder No / Name : 202 / 11KV Water Supply -Shiye GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7619	.7537	.6249	.7468	.631	.5937	.8676
2	.7619	.7537	.6249	.7468	.6135	.5937	.8589
3	.7442	.7537	.6249	.7468	.6135	.5937	.8676
4	.7442	.7537	.6249	.7392	.6135	.6249	.9431
5	.7796	.7888	.6562	.7468	.6661	.6874	.9709
6	.8682	.8238	.703	.7762	.7362	.703	1.0269
7	.9568	.8764	.8592	.8215	.8063	.8905	1.1389
8	1.2934	1.0517	1.3904	.8299	1.1568	1.0936	1.4937
9	2.1085	1.4937	1.4842	.6562	1.5424	1.6872	1.6476
10	1.6404	1.6057	1.7896	.6249	2.0683	2.1085	1.7528
11	1.6091	1.9418	2.0022	.3906	2.1472	1.7541	1.7878
12	1.531	1.8111	2.5514	.3906	1.9978	2.2148	1.6827
13	1.5623	1.6244		.3906	1.4563	1.4352	1.3146
14	1.6404	1.3306	1.5592	.3906	1.6804	1.2403	1.1393
15	1.7185	1.6804	1.949	.3906	1.7364	1.5947	1.5775
16	1.5623	1.643	1.825		1.6632	1.6301	1.7002
17	1.406	1.307	1.701	.5937	1.5684	1.6124	1.7002
18	1.1717	.953	1.419	.6485	1.1873	1.2883	1.4352
19	1.0166	.8436	1.0456	.7011	.8749	1.1203	1.0277
20	.929	.7811	1.0349	.7011	.7499	1.0082	.815
21	.8238	.703	.8215	.6836	.703	.9808	.8328
22	.8402	.703	.7842	.7011	.6718	.9619	.7973
23	.7712	.6562	.7842	.6661	.6405	.9335	.7442
24	.7619	.7712	.6562	.7468	.631	.6249	.8962
Max	**2.1085**	**1.9418**	**2.5514**	**.8299**	**2.1472**	**2.2148**	**1.7878**
Min	**.7442**	**.6562**	**.6249**	**.3906**	**.6135**	**.5937**	**.7442**
Avg	**1.1668**	**1.1002**	**1.1963**	**.6448**	**1.1315**	**1.1657**	**1.2091**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
KADAMWADI[039] BU 6173
Substation No/ Name :- 144001 / 33/11KV SHIYE
Feeder No / Name : 203 / 11KV TOP II AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3052	.2883	.3018	1.6518	.5596	.5624	.3353
2	.3052	.2883	.3018	1.7101	.5935	.5937	.3353
3	.2883	.2883	.3018	1.6933	.5935	.5937	.3353
4	.2883	.2883	.3018	1.6766	.6443	.6562	.3353
5	.3052	.2883	.3018	1.643	.78	.7499	.3185
6	.3052	.2883	.3018	1.5424	1.0513	.8436	.3185
7	.3052	.2883	.3018	1.3077	1.2717	1.0898	.3185
8	.3052	.2883	.3018	1.3245	1.3226	.6706	.3353
9	1.7126	1.5927	1.6766	.3018	.3052	.285	1.2209
10	2.6825	2.8166	2.5943	.3018	.3052	.2883	1.6956
11	2.5149	2.6155	2.3908	.285	.3018	.2883	1.95
12	2.5149	2.7161	2.2382	.285	.3018	.2883	2.4078
13	2.5149	2.7999	2.7639	.3018	.285	.2883	2.6282
14	2.5819	2.9005	3.0013	.3018	.285	.2883	2.6791
15	2.5987	2.6155	2.5434	.3018	.285	.3052	2.5434
16	2.3472	2.7999	2.5095	.3052	.285	.3052	2.5095
17	.2515	2.7161	.2883	.3018	.285	.3052	.3391
18	.2683	.285	.3018	.2883	.285	.3734	.3391
19	.2713	.3018	.3018	.2883	.285	.3353	.3391
20	.2883	.3018	.3018	.2883	.285	.3353	.3391
21	.2883	.3018	.3018	.2883	.285	.3353	.3391
22	.2883	.3018	1.6766	.2883	.285	.3353	.3391
23	.2883	.3018	1.6766	.5935	.5868	.3353	.3391
24	.3052	.2883	.3018	1.6933	.5596	.5624	.3353
Max	**2.6825**	**2.9005**	**3.0013**	**1.7101**	**1.3226**	**1.0898**	**2.6791**
Min	**.2515**	**.285**	**.2883**	**.285**	**.285**	**.285**	**.3185**
Avg	**1.0052**	**1.1651**	**1.1368**	**.7902**	**.5011**	**.4589**	**.9573**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
KADAMWADI[039] BU 6173
Substation No/ Name :- 144001 / 33/11KV SHIYE
Feeder No / Name : 204 / HANUMAN GAOTHAN FEEDER GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.132	.1307	.1509	.1307	.1307	.1494
2	.1307	.132	.1307	.1494	.132	.1307	.1509
3	.1307	.132	.1307	.1494	.132	.1307	.1494
4	.1307	.132	.1494	.1494	.132	.1307	.1494
5	.1867	.1867	.1867	.1867	.168	.1494	.1867
6	.2241	.2241	.2241	.2241	.2241	.2241	.2241
7	.2614	.2801	.2801	.2427	.2801	.2801	.2587
8	.2801	.2614	.2614	.2241	.2614	.2801	.2614
9	.2614	.2427	.2427	.2241	.2427	.2987	.2427
10	.1867	.2241	.2614	.1867	.1867	.2801	.2241
11	.2614	.1867	.1867	.1867	.1494	.2427	.168
12	.2241	.1867	.2241	.168	.1867	.1867	.1867
13	.168	.1867	.1494	.1494	.1867	.1494	.1494
14	.1494	.1494	.1494	.1494	.1494	.1307	.1307
15	.1494	.1478	.1307	.1307	.1494	.1494	.1307
16	.168	.1867	.168	.1307	.168	.1494	.1867
17	.2427	.2218	.2054	.1307	.168	.1494	.168
18	.1867	.2241	.2241	.2241	.2427	.2241	.2241
19	.3361	.3361	.3361	.3361	.3174	.3174	.3361
20	.2987	.3361	.2801	.3174	.3174	.3326	.2987
21	.2801	.2614	.2614	.2987	.2801	.2957	.2614
22	.2241	.2241	.2241	.2241	.2241	.2241	.2054
23	.1307	.168	.1867	.1494	.1494	.1509	.1494
24	.1307	.1307	.1307	.1494	.1307	.1307	.1494
Max	**.3361**	**.3361**	**.3361**	**.3361**	**.3174**	**.3326**	**.3361**
Min	**.1307**	**.1307**	**.1307**	**.1307**	**.1307**	**.1307**	**.1307**
Avg	**.2031**	**.2039**	**.2023**	**.1930**	**.1962**	**.2029**	**.1976**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
KADAMWADI[039] BU 6173
Substation No/ Name :- 144003 / 33/11 KV KERLE
Feeder No / Name : 202 / 11 KV NIGAWE GAVTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0762		.0924	.1143	.1143	.0953
2	.0953	.0762		.0934	.1143	.1143	.0953
3	.0953	.0762		.0924	.1143	.1143	.0953
4	.0953	.0762		.1109	.1334	.1143	.0953
5	.1143	.1143		.1294	.2033	.1334	.1334
6	.2286	.2641		.2033	.2614	.2641	.2286
7	.2829	.2987		.2587	.2772	.2987	.2477
8	.2987	.2587		.3174	.2772	.2957	.2667
9	.3109	.2241	.2195	.2587	.2402	.2987	.2896
10	.2561	.2614	.2263	.2561	.2241	.2263	.2926
11	.2401	.2263	.2263	.2195	.2641	.2241	.2347
12	.1734	.1698		.1772	.2286	.2263	.2204
13		.1886	.2263	.1463	.2096	.1698	.1791
14	.1543	.1509	.2241	.181	.1886	.1509	.1448
15	.1267	.1524	.2241	.1478	.1867	.1509	.2058
16	.1886	.2075	.1867	.1991	.2241	.1509	.1696
17	.1772	.2229	.2641	.197	.2172	.2801	.1829
18	.2686	.2401	.2452	.2328	.2303	.2987	.2294
19	.3772	.3734	.3734	.3395	.3734	.3696	.2926
20	.3395	.3174	.3361	.3206	.3395	.3361	.3292
21	.2829	.2801	.2587	.2641	.2667	.2427	
22	.1905	.1867	.1886	.1886	.2096	.1698	
23	.1143	.1132	.1509	.1143	.1143	.1334	
24	.0953	.0762		.0934	.1143	.1143	.1143
Max	**.3772**	**.3734**	**.3734**	**.3395**	**.3734**	**.3696**	**.3292**
Min	**.0953**	**.0762**	**.1509**	**.0924**	**.1143**	**.1143**	**.0953**
Avg	**.2001**	**.1930**	**.2393**	**.1931**	**.2136**	**.2080**	**.1973**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
KADAMWADI[039] BU 6173
Substation No/ Name :- 144003 / 33/11 KV KERLE
Feeder No / Name : 204 / 11KV AMBEWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0503	.0572		.04	.0429	.0762	.0389
2	.0495	.0572		.04	.0429	.0762	.0394
3	.0495	.0572		.04	.0429	.0762	.0394
4	.0488	.0572		.0406	.0429	.0762	.0389
5		.0572		.0377	.0429	.0762	.0389
6	.048	.0572		.0389	.0446	.0762	.0526
7	.0366	.0572		.0526	.044	.0762	.04
8	.036	.0572		.0389	.0423	.0572	.0267
9	.0343	.0389	.0686	.0572	.0417	.0514	.0381
10	.0343	.0412	.0686	.0572	.0705	.0686	.0572
11	.7042	.7042	.8573	.8619	.9717	1.0159	.7042
12	.8322	.8097	.8848		.9922	1.0395	.8002
13	.8223	.8688	.8848		.9717	1.0159	.8097
14	.759	.4999	.8951	1.0486	.8002	1.0159	.8539
15	.7042	.4801	.8951	.9717	.8097	.9831	.8642
16	.7125	.6722	.852	.9393	.7362	.9175	.8223
17	.6401	.6249	.8097	.8322	.7274	.7449	.852
18	.583	.5312	.6554	.7042	.6962	.6802	.6706
19	.0572	.061	.0648	.0497	.0762	.0412	.0686
20	.0572	.0587	.0533	.0452	.0762	.0556	.0686
21	.0762	.0587	.0549	.0452	.0762	.0526	
22	.0762	.0587	.0511	.0457	.0762	.0518	
23	.0572	.0533	.0518	.0457	.0762	.0394	
24	.0518	.0572		.0526	.0429	.0762	.04
Max	**.8322**	**.8688**	**.8951**	**1.0486**	**.9922**	**1.0395**	**.8642**
Min	**.0343**	**.0389**	**.0511**	**.0377**	**.0417**	**.0394**	**.0267**
Avg	**.2835**	**.2532**	**.4765**	**.2766**	**.3161**	**.3517**	**.3316**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
KADAMWADI[039] BU 6173
Substation No/ Name :- 144003 / 33/11 KV KERLE
Feeder No / Name : 205 / 11 KV Kerli Ag. SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0907	.1334	.0686	.0827	.088	.1334	.1036
2	.092	.1143	.1029	.084	.088	.1143	.1021
3	.0907	.1143	.0686	.084	.088	.1143	.1021
4	.092	.1143	.0686	.0854	.088	.1143	.1021
5	.092	.1334	.0709	.08	.1006	.1334	.1021
6	.0894	.1524	.0894	.1036	.1006	.1524	.0991
7	.1113	.1524	.0991	.1067	.1036	.1524	.0594
8	.0854	.1334	.0991	.0907	.0854	.1524	
9	.0629	.088	.12	.1334	.0884	.12	.1524
10	.0734	.0854	.12	.1334	.1886	.12	.1524
11	2.0809	2.2348	2.4646	1.9227	2.1628	2.3102	2.0081
12	2.0405	2.1822	2.5774		2.2939	2.4863	2.0481
13	2.0399	2.2558	2.4646		2.5101		2.1052
14	1.9044	2.2377	2.5149	2.3137	2.2939	1.4083	2.0405
15	1.9364	2.1872	2.364	2.4078	2.3594	2.2939	2.0481
16	1.9364	2.1296	2.3102	2.42	2.3644	2.3472	2.0405
17	1.917	2.077	2.1765	2.2611	2.1376	2.2283	1.9662
18	1.3765	1.5653	1.6248	1.7695	1.6385	1.6057	1.5089
19	.1524	.1067	.1097	.2241	.1715	.0556	.12
20	.1524	.1097	.1082	.1128	.1715	.0556	.1372
21	.1524	.1097	.1097	.1143	.1715	.0587	
22	.1524	.1097	.1433	.1	.1524	.0412	
23	.1334	.0934	.0991	.088	.1524	.096	
24	.0907	.1334	.0827	.0867	.088	.1334	.1082
Max	**2.0809**	**2.2558**	**2.5774**	**2.42**	**2.5101**	**2.4863**	**2.1052**
Min	**.0629**	**.0854**	**.0686**	**.08**	**.0854**	**.0412**	**.0594**
Avg	**.7061**	**.7814**	**.8357**	**.6729**	**.8203**	**.7142**	**.8553**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
KADAMWADI[039] BU 6173
Substation No/ Name :- 144003 / 33/11 KV KERLE
Feeder No / Name : 206 / 11 KV VILLAGE GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.3018	.3018	.3734	.3018	.415	.4066
2	.4108	.3018	.3018	.3734	.3018	.4191	.4024
3	.4108	.3395	.3018	.3696	.3772	.4191	.4066
4	.4481	.3395	.3018	.4066	.4108	.4191	.439
5	.4805	.4435	.439	.4435	.4435	.4481	.5853
6	.8131	.8131	.8048	.7316	.8131	.7762	.8131
7	.9979	1.0349	.961	.924	1.0349	1.0349	.9511
8	.9511	.9511	.9511	.9511	.9511	.9877	1.0498
9	.9511	.8688	.9511	.9511	.8871	.961	.9511
10	.8779	.8764	.9511	.8505	.9313	.8962	.8859
11	.9114	.9412	.788	.924	.8764	.8962	.823
12	.7628	.7011	.9054	.6241	.815	.8962	.8573
13	.6241	.7011	.7545	.6241	.7087	.7468	.7888
14	.6173	.6935	.679	.5731	.7011	.679	.6783
15	.6104	.6859	.7468	.5373	.6935	.679	.7122
16	.6173	.6935	.7545	.6024	.6661	.6722	.3688
17	.7011	.6783	.6935	.6379	.6859	.6859	.6554
18	.7796	.788	.788	.788	.7602	.7964	.8048
19	.961	.8962	.8962	.8962	.9709	.924	.9054
20	.8676	.8299	.8215	.8299	.8676	.8962	.8299
21	.7922	.7545	.7545	.7468	.7922	.7545	
22	.7167	.7167	.679	.5601	.7167	.6036	
23	.4854	.4904	.3734	.362	.4904	.5281	
24	.4435	.2987	.2987	.3734	.3018	.415	.4435
Max	**.9979**	**1.0349**	**.961**	**.9511**	**1.0349**	**1.0349**	**1.0498**
Min	**.4108**	**.2987**	**.2987**	**.362**	**.3018**	**.415**	**.3688**
Avg	**.6934**	**.6725**	**.6749**	**.6439**	**.6875**	**.7062**	**.7028**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
KADAMWADI[039] BU 6173
Substation No/ Name :- 144003 / 33/11 KV KERLE
Feeder No / Name : 207 / 11 KV Nigave Ag. SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1524		.112	.1132	.1143	.112
2	.1143	.1715		.1132	.1132	.1143	.112
3	.1143	.1715		.1132	.1132	.1143	.112
4	.1143	.1905		.1132	.1132	.1143	.112
5	.1524	.1905		.128	.132	.1334	.112
6	.1698	.1905		.1494	.1509	.1715	.1509
7	.1698	.1905		.168	.1509	.1715	.1698
8	.1715	.1905		.1524	.1509	.1715	.1715
9	.1524	.1524	.1715	.1524	.132	.1372	.1334
10	.1143	.1509	.1715	.1524	.1334	.1372	.1524
11	1.2193	1.2308	1.4403	1.3927	1.4586	1.3435	1.3927
12	1.2308	1.2955	1.3748	1.2967	.9831	1.3748	1.4403
13	1.0753	1.2483	1.3748	.0509	1.4091	1.3108	1.4723
14	1.2018	1.2955	1.3435	.052	1.2955	1.3413	1.4251
15	1.2651	1.2955	1.3435	1.2308	1.3279	1.3108	1.4403
16	1.2651	1.4251	1.3108	1.4746	1.3279	1.3108	1.4083
17	1.2955	1.2651	1.4251	1.3927	1.3765	1.4251	1.4419
18	1.1203	1.2651	1.1385	1.1336	1.166	1.1728	1.1603
19	.2286	.1886	.2096	.1886	.1715	.1509	.1372
20	.1905	.1509	.2096	.1509	.1905	.1698	.1543
21	.1905		.1886	.1886	.1524	.1698	
22	.1715	.1509	.1509	.132	.1334	.1698	
23	.1524	.1509	.1307	.1132	.1143	.1509	
24	.0943	.1524		.1132	.1132	.1143	.1109
Max	**1.2955**	**1.4251**	**1.4403**	**1.4746**	**1.4586**	**1.4251**	**1.4723**
Min	**.0943**	**.1509**	**.1307**	**.0509**	**.1132**	**.1143**	**.1109**
Avg	**.5037**	**.5594**	**.7989**	**.4277**	**.5218**	**.5373**	**.6153**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
KADAMWADI[039] BU 6173
Substation No/ Name :- 144003 / 33/11 KV KERLE
Feeder No / Name : 208 / 11 KV Panhala Feeder GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.2641		.2987	.3018	.3048	.2987
2	.3772	.2667		.2987	.3018	.3048	.2987
3	.3772	.2667		.2987	.3395	.3048	.2987
4	.3734	.2667		.3361	.415	.3048	.3361
5	.4108	.3772		.4108	.3772	.3395	.3734
6	.5601	.5281		.5658	.5601	.5281	.5228
7	.6348	.5975		.5975	.5601	.6722	.5975
8	.5544	.6653		.6283	.4515	.6283	.5544
9	.5853	.6154	.5601	.5853	.6283	.5544	.5853
10	.543	.543	.5601	.5121	.4854	.6348	.4755
11	.5014	.5068	.4854	.5175	.4755	.6036	.5373
12	.5373	.5731	.5281	.439	.5792	.5658	.5068
13		.5258	.4854	.4298	.4805	.5228	.4557
14	.394	.4656	.4527	.439	.4805	.4854	.3982
15	.5014	.5316	.4108	.3658	.4805	.4854	.3856
16	.4854	.6154	.415	.543	.5121	.4854	.4207
17	.567	.4908	.4961	.5068	.5792	.4207	.4755
18	.5853	.5853	.5487	.6219	.5601	.5121	.5544
19	.8131	.7842	.7842	.7468	.7468	.7023	.7095
20	.7468	.6722	.7468	.679	.7167	.7468	.7095
21	.679	.6036	.7167	.57	.679	.6413	
22	.5658	.5281	.5281	.3772	.5658	.5281	
23	.3018	.415	.3018	.3772	.3395	.4108	
24	.415	.2641		.3018	.3018	.3395	.3326
Max	**.8131**	**.7842**	**.7842**	**.7468**	**.7468**	**.7468**	**.7095**
Min	**.3018**	**.2641**	**.3018**	**.2987**	**.3018**	**.3048**	**.2987**
Avg	**.5168**	**.4980**	**.5347**	**.4770**	**.4966**	**.5011**	**.4679**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
KALE[036] BU 6149
Substation No/ Name :- 144007 / 33/11 KV PADAL
Feeder No / Name : 201 / 11 kv Yavaluj Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.213	.2658	.2267	.0111	.017	.016	.0165
2	.2267	.2896	.2241	.0131	.017	.016	.0131
3	.2294	.2896	.2267		.0168	.016	.0165
4	.2622	.2926	.2429		.017	.016	
5	.3201	.3109	.2561		.017	.016	.0144
6	.3725	.4024	.3041		.017	.016	.0163
7	.4858	.6219	.4641		.0171	.016	.0162
8	.6062	.6767	.6722	.0125	.0171	.016	.0124
9	.639	.7316	.7362	.0165	.0171	.016	.0165
10	.6584	.5506	.0179	.0131	.0162		.0165
11	.0171	.0162	.0172	.9694	.9231	.7916	.9189
12	.0173	.0162	.0165	1.3352	1.2631	1.096	1.2048
13	.0171	.0162		1.4632	1.3117	1.0825	1.3676
14	.0171	.0162	.0124	1.5893	1.2955		1.4685
15	.0171	.0162		1.5154	1.247	1.244	1.4632
16	.0171	.0162		1.4784	1.166	1.2525	1.4632
17	.0173	.0162		1.3535	1.1336	1.2496	1.1706
18	.0173	.0162	.0124	1.1458	.8907		.8413
19	.0175	.0162		.0171	.0162		.0168
20	.0173	.0162	.0165	.0171	.0162	.0165	.0171
21	.0171	.0162	.0131	.0171	.016		.0171
22	.0171	.0162	.0169	.0171	.016	.0162	.0171
23	.0171	.0162	.0162	.0171	.016		.017
24	.0164	.0171	.0162	.0131	.017	.016	.0124
Max	**.6584**	**.7316**	**.7362**	**1.5893**	**1.3117**	**1.2525**	**1.4685**
Min	**.0164**	**.0162**	**.0124**	**.0111**	**.016**	**.016**	**.0124**
Avg	**.1772**	**.1941**	**.1847**	**.5797**	**.3957**	**.3838**	**.4406**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
KALE[036] BU 6149
Substation No/ Name :- 144007 / 33/11 KV PADAL
Feeder No / Name : 202 / 11 KV YEVALUJ VG GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0526	.0549	.1086	.0526	.0532	.0526	.0521
2	.0532	.0549	.1086	.0538	.0532	.0526	.0521
3	.0526	.0543	.1086	.0703	.0549	.0526	.0717
4	.0701	.0554	.1086	.0879	.0549	.0701	.0662
5	.1052	.0724	.1448	.1231	.0724	.1052	.1055
6	.1907	.1086	.181	.2154	.1086	.1734	.1421
7	.1753	.1848	.2149	.2154	.1848	.1907	.1615
8	.1928	.1848	.2149	.1974	.1848	.1907	.0175
9	.1753	.1663	.1734	.1579	.1829	.1734	.1648
10	.1663	.156	.1579	.1436	.1907		.1755
11	.1629	.1387	.1421	.1478	.156	.1564	.1646
12	.1646	.156	.1436	.128	.1387	.1755	.1595
13	.1629	.1387	.149	.128	.1387	.1736	.1595
14	.1097	.1214	.1454	.128	.1387		.1578
15	.1086	.1387	.1615	.128	.1387	.0869	.1646
16	.128	.1387	.1615	.1294	.1387	.1404	.1663
17	.128	.156	.1934	.128	.156	.1562	.1829
18	.1829	.1734	.2188	.1463	.1734		.2012
19	.2218	.1928		.168	.2103		.2378
20	.2402	.1928	.198	.1848	.1928	.193	
21	.2012	.1753	.1758	.1663	.1753		.1646
22	.1646	.1052	.1216	.1097	.1227	.1053	.1075
23	.1097	.0876	.0696	.0732	.0876		.0905
24	.0526	.0549	.0526	.0544	.0532	.0526	.0538
Max	**.2402**	**.1928**	**.2188**	**.2154**	**.2103**	**.193**	**.2378**
Min	**.0526**	**.0543**	**.0526**	**.0526**	**.0532**	**.0526**	**.0175**
Avg	**.1405**	**.1276**	**.1502**	**.1307**	**.1317**	**.1278**	**.1313**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
KALE[036] BU 6149
Substation No/ Name :- 144007 / 33/11 KV PADAL
Feeder No / Name : 203 / 11Kv Satarde sheti SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0164	.0171	.0164	.2649	.3696	.3239	.0144
2	.0164	.0171	.0164	.296	.3658	.3239	.0144
3	.0162		.0164	.298	.3881	.3401	.0162
4	.0162	.0173	.0164	.399		.3401	.0144
5	.0162	.0171	.0164	.4545		.3437	.0162
6	.0162	.0173	.0164	.7251		.3887	.0143
7	.0164	.0171	.0164			.9069	.0141
8	.0164	.0171	.0164	.2637		.9878	.0165
9	.0164	.0171	.0164	.9362		.9374	.0131
10	.0177	.0162	.013	1.0425			.0165
11	2.2497	1.6712	1.8293			.0164	1.5729
12	2.3045	2.0317	2.0881	.0171	.0162	.0131	1.8461
13	2.5688	2.2119	2.1703	.0171	.6882	.0162	2.0851
14	2.0165	2.2611	1.9444		.6882		2.1948
15	2.1948	2.2283	1.553		.6718	.0165	2.2314
16	2.3045	2.0645	1.7967		.0162	.0159	2.2731
17	2.3411	1.8023	1.1945		.0162	.0164	2.2177
18	2.2731	1.2452	1.0345	.0171	.0164		1.885
19	.0171	.0162		.0171	.0164		.0171
20	.0171	.0162	.0124	.0171	.0164	.013	.0171
21	.0175	.0162	.0131	.0171	.0164		.0171
22	.0173	.0162	.0159	.0171	.0164	.0162	.017
23	.0171	.0164	.0164	.0171	.0164		.0173
24	.0164	.0171	.0162	.0165	.0171	.0164	.0162
Max	**2.5688**	**2.2611**	**2.1703**	**1.0425**	**.6882**	**.9878**	**2.2731**
Min	**.0162**	**.0162**	**.0124**	**.0165**	**.0162**	**.013**	**.0131**
Avg	**.7717**	**.6856**	**.6020**	**.2685**	**.2085**	**.2796**	**.6899**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
KALE[036] BU 6149
Substation No/ Name :- 144007 / 33/11 KV PADAL
Feeder No / Name : 204 / Majgaon Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0171	.0173		.7522	.583	.5384
2	.017	.0171	.0173		.7682	.6516	.5982
3	.017	.0173	.0173		.8413	.6516	.9026
4	.0171	.0175	.0173		.8413	.7202	.9459
5	.017	.0173	.0173		.9877	.8987	1.0713
6	.017	.0171	.0173		1.1827	1.0174	1.3144
7	.017	.0171	.0173		1.6644	1.3904	1.2264
8	.017	.0171	.0173		1.922	1.6787	1.4339
9		.0171	.0179		1.9387		1.2337
10		.0173	.0131	.8278	1.5261		1.2462
11	1.8656	2.1534	1.9296	.0171	.0173	.0131	.0171
12	1.957	2.6063	2.351	.0171	.0173	.0165	.0171
13	2.652	2.6578	2.5497	.0171	.0173	.0131	.017
14	.8779	2.6063	2.6698	.0171	.0173		.017
15	2.5873	2.5892	2.3899	.0173	.0173		.0171
16	2.4874	2.572	2.3179	.0171	.0173		.0168
17	2.2546	2.2634	1.9941	.0171	.0173		.0168
18	1.7558	1.869	1.7044	.017	.0173		.017
19	.0173	.0173		.0175	.0173		.0171
20	.0171	.0173	.0124	.0171	.0173	.0131	.0175
21	.0171	.0173	.0133	.0171	.0173		.0171
22	.0171	.0173	.0125	.0173	.0173	.0131	.0171
23	.0171	.0173	.0131	.0171	.0173		.0171
24	.017	.0171	.0173	.0125	.0171	.0173	.0165
Max	**2.652**	**2.6578**	**2.6698**	**.8278**	**1.9387**	**1.6787**	**1.4339**
Min	**.017**	**.0171**	**.0124**	**.0125**	**.0171**	**.0131**	**.0165**
Avg	**.7580**	**.8164**	**.7889**	**.0709**	**.5278**	**.5484**	**.4479**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
KALE[036] **BU 6149**
Substation No/ Name :- 144007 / 33/11 KV PADAL
Feeder No / Name : 205 / Majgaon Vg **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1052	.1086		.0854	.1097	.1086	.0812
2	.0876	.1063		.0748	.0914	.1086	.072
3	.0876	.1097		.0828	.0924	.1086	.0812
4	.124	.1097		.1195	.0914	.1086	.1291
5	.1595	.1463		.1855	.1109	.1086	.13
6	.2804	.1848		.2152	.1463	.181	.212
7	.2481	.2218		.2483	.1646	.2172	.2534
8	.2629	.2172		.2649	.2772	.2865	
9	.2481	.2378	.197	.2227	.2926	.2865	.2104
10	.2378	.2507	.1838	.2227	.2865		.2227
11	.2378	.2507	.212	.2378	.2328	.2227	.2303
12	.2218	.2149	.2048	.2378	.2149	.2048	.2328
13	.2378	.2149	.2069	.2378	.2149	.2048	.2328
14	.2195	.2149	.1987	.2587	.2149		.2103
15	.2402	.2149	.239	.2561	.2149	.2032	.2378
16	.2561	.2149	.2446	.2561	.2507	.2318	.2378
17	.2561	.2507	.2759	.2743	.2865	.2802	.2772
18	.2926	.2865	.3243	.2743	.2865		.3326
19	.3326	.3801		.3326	.362		.3696
20	.3734	.3258	.3073	.3547	.3258	.3414	.3292
21	.3109	.2715	.2398	.0171	.2896		.2957
22	.2772	.1448	.2048	.2218	.181	.137	.1829
23	.1848	.1267	.1195	.1848	.1448		.128
24	.1063	.1267	.1086	.1024	.128	.1267	.0856
Max	**.3734**	**.3801**	**.3243**	**.3547**	**.362**	**.3414**	**.3696**
Min	**.0876**	**.1063**	**.1086**	**.0171**	**.0914**	**.1086**	**.072**
Avg	**.2245**	**.2055**	**.2178**	**.2070**	**.2088**	**.1926**	**.2076**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
KALE[036] BU 6149
Substation No/ Name :- 144007 / 33/11 KV PADAL
Feeder No / Name : 206 / 11 KV Satarde Gaothan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1075	.1109	.1086	.0919	.1097	.1086	.1077
2	.1063	.1075	.1086	.09	.1097	.1086	.0828
3	.1063	.1086	.1086	.0929	.1109	.1086	.0929
4	.1417	.1086	.1086	.1159	.1463	.1086	.1256
5	.2126	.1848	.1629	.2043	.1829	.181	.1615
6	.3761	.3326	.2715	.2574	.2801	.3403	.2363
7	.3366	.3696	.3224	.3197	.3547	.3582	.2802
8	.394	.3326	.3582	.4658	.3881	.3582	.3769
9	.3544	.3142	.3582	.3601	.4066	.3582	.3628
10	.3841	.362	.3901	.3421			.3781
11	.3734	.3224	.3769			.3973	.3841
12	.3361	.2507	.3715	.2957	.3761	.2914	.3658
13	.3292	.3403	.3486	.2772	.394	.2348	.3292
14	.3326	.2865	.3344	.2587	.3761		.3292
15	.2926	.2865	.3566	.2587	.3761	.2872	.2957
16	.3142	.2865	.3715	.2743	.3224	.2692	.2587
17	.3696	.2896	.4057	.2926	.3582	.2529	.2957
18	.4108	.362	.4307	.3174	.2686		.4294
19	.4668	.4163		.3547	.4119		
20	.4251	.3982	.3905	.3734	.3982	.4128	
21	.3881	.2534	.2417		.3258		.3475
22	.2743	.1629	.2442	.2195	.2353	.1795	.2195
23	.2218	.1267	.1085	.1478	.1448		.1448
24	.1227	.1267	.1086	.0929	.1097	.1086	.1077
Max	**.4668**	**.4163**	**.4307**	**.4658**	**.4119**	**.4128**	**.4294**
Min	**.1063**	**.1075**	**.1085**	**.09**	**.1097**	**.1086**	**.0828**
Avg	**.2990**	**.2600**	**.2777**	**.2501**	**.2812**	**.248**	**.2596**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
KALE[036] BU 6149
Substation No/ Name :- 144008 / 33/11KV S//S BAJAR BHOGOAN
Feeder No / Name : 201 / 11KV BORGOAN VG GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0183	.0177	.0171	.0183	.0173	.0177	.0168
2		.0177	.0171	.0183	.0173	.0177	.0168
3	.0181	.0177	.0171	.0183	.0173	.0177	.0168
4	.0183	.0354	.0171	.0181	.0173	.0354	.0168
5	.0183	.0354	.0171	.0366	.0347	.0354	.0168
6	.0366	.0532	.0343	.0549	.0526	.0532	.0343
7	.0532	.0532	.0514	.0543	.052	.0532	.0514
8	.0543	.0709	.0514	.0543	.0526	.0532	.0514
9	.0543	.0532	.0514	.0532	.0526	.0514	.0514
10	.0532	.0514	.0549		.0532	.0514	
11	.0532	.0514	.0549	.0526	.0532	.0514	.0526
12	.0532	.0514	.0549	.0526	.0532	.0514	.0526
13	.0532	.0514	.0549	.0526	.0532	.0514	.0526
14	.0532	.0514	.0543	.0526	.0514	.0514	.052
15	.0532	.0514	.0532	.0526	.0532	.0514	.0543
16	.0532	.0514	.0543	.0526	.0532	.0514	.0526
17	.0532	.0514	.0543	.0526	.0532	.0514	.0526
18		.0514	.0362	.0526	.0532	.0514	.0526
19	.0709	.0701	.0532	.0701	.0532	.0709	.0701
20	.0532	.0709	.0532	.052	.0532	.0716	.052
21	.0354	.0701	.0526	.0526	.0532	.0701	.0526
22	.0354	.0514	.0354		.0354	.0526	
23	.0354	.0339	.0183	.0351	.0354	.0328	
24	.0183	.0354	.0171	.0183		.0354	.0168
Max	**.0709**	**.0709**	**.0549**	**.0701**	**.0532**	**.0716**	**.0701**
Min	**.0181**	**.0177**	**.0171**	**.0181**	**.0173**	**.0177**	**.0168**
Avg	**.0430**	**.0479**	**.0407**	**.0443**	**.0444**	**.0471**	**.0422**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
KALE[036] BU 6149
Substation No/ Name :- 144008 / 33/11KV S//S BAJAR BHOGOAN
Feeder No / Name : 203 / 11KV PADASALI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0366	.9259	.9313	.8688	.0354	.0343	.0335
2	.0366	.9259	.9313	.8505	.0354	.0343	.0335
3	.0366	.9259	.9313	.8688	.0351	.0343	.0335
4	.0366	.9602	.9313	.8869	.0351	.0343	.0335
5	.0366	.9774	.9671		.0351	.0343	.0335
6	.0362	.9945	1.086		.0351	.0343	.0335
7	.0362	1.4918	1.3073		.0351	.0343	.0335
8	.0362	1.6975	1.6289		.0351	.0343	.0335
9	.0362	1.6289	1.7918	.6401	.0351	.0335	.0335
10	.0343	1.6289	1.6126		.0343	.0335	
11	.0343	.0324	.0351	1.893	2.2805	1.9004	1.7528
12	.0343	.0324	.0354	2.4539	2.5377	2.1176	2.0157
13	.0343	.0324	.0354	2.4539	2.6235	2.5339	2.3663
14	.0343	.0335	.0362	2.4539	2.7263	2.4977	2.2786
15	.0343	.0335	.0351	2.7168	2.6749	2.4977	2.1033
16	.0343	.0335	.0351	2.2786	2.4006	2.3529	2.0157
17	.0343	.0335	.0354	2.2611	2.1605	2.2624	1.9281
18	.0343	.0335	.0362	1.9281	2.0748	2.009	1.7528
19	.0343	.0335	.0532	.0351	.0343	.0335	.0351
20	.0343	.0335	.0532	.0347	.0343	.0335	.0351
21	.0343	.0335	.0366	.0351	.0343	.0335	.0351
22	.0343	.0324	.0362		.0343	.0335	
23	.0343	.0324	.0362	.0351	.0343	.0335	
24	.0347	.0343	.0335	.0366	.0351	.0343	.0335
Max	**.0366**	**1.6975**	**1.7918**	**2.7168**	**2.7263**	**2.5339**	**2.3663**
Min	**.0343**	**.0324**	**.0335**	**.0347**	**.0343**	**.0335**	**.0335**
Avg	**.0351**	**.5259**	**.5272**	**1.2628**	**.8348**	**.7798**	**.7930**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
KALE[036] BU 6149
Substation No/ Name :- 144008 / 33/11KV S//S BAJAR BHOGOAN
Feeder No / Name : 204 / 11 Kv Boragaon Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.3898	.3403			
2	.4458	.3898	.3439			
3	.463	.3898	.3439			
4	.463	.3898	.362			
5	.463	.4252	.362			
6	.4801	.4961	.3544			
7	.6173	.6201	.3898			
8	.703	.6626	.5068			
9	.823	.7522	.6335			
10	.8059	.6935				
11			.9114	.7373	.8059	.7011
12			1.0517	.8573	.8954	.9816
13			1.1043	1.0802	.9671	.9991
14			1.0867	1.0974	.9671	.9709
15			.7011	1.0631	.7522	
16			.7011	1.0631	.7087	.9991
17			.1227	.9602	.6733	1.0341
18			.7186	.7716	.6201	.8413
19		.0549				
Max	**.823**	**.7522**	**1.1043**	**1.0974**	**.9671**	**1.0341**
Min	**.4458**	**.0549**	**.1227**	**.7373**	**.6201**	**.7011**
Avg	**.5710**	**.4785**	**.5902**	**.9538**	**.7987**	**.9325**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
KALE[036] BU 6149
Substation No/ Name :- 144008 / 33/11KV S//S BAJAR BHOGOAN
Feeder No / Name : 205 / 11 KV PADASALI GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4706	.0526	.0686	.0543	.4382	.4733	.4382
2	.4557	.0526	.0686	.0543	.4382	.4733	.4382
3	.4706	.0526	.0686	.0549	.4733	.4733	.4382
4	.4887	.0526	.0686	.0526	.4908	.4908	.4382
5	.5068	.0701	.0857	.0724	.5258	.5258	.4908
6	.5611	.1052	.1029	.1097	.6135	.6135	.5847
7	.7059	.1402	.1402	.1448	.6485	.6836	.7343
8	.7455	.1227	.1595	.1448	.7537	.8413	.7701
9	.7975	.1227	.1595	.1227	.7888	.9492	.8596
10	.7712	.1227	.1595		.8063		
11	.7712	.8417	.7964	.1052	.1227		.1227
12	.8764	.9492	.8764	.0876	.1227		.1052
13	.9465	1.0029	.9568	.0876	.0876	.0686	.1052
14	.8589	1.0029	.9955	.0876	.1052	.1227	.1052
15	.9465	1.0387	1.0136	.1052	.1052	.1227	.1052
16	.8589	1.0029	.9922	.1052	.1227	.1227	.1578
17	.8589	.9492	.9816	.1402	.1227	.1227	.1753
18	.7712	.8596	.9877	.1753	.1753	.1595	.1928
19	.2103	.2507	.2126	.2103	.2103	.2507	.2103
20	.1753	.2126	.1772	.1753	.2103	.2149	.1753
21	.1402	.1772	.1448	.1578	.1753	.1772	.1578
22	.1052	.1052	.1086	.1052	.0876	.1029	
23	.0701	.0686	.0886	.0876	.0701	.0686	
24	.0693	.0532	.0686	.0724	.0526	.0526	.0686
Max	**.9465**	**1.0387**	**1.0136**	**.2103**	**.8063**	**.9492**	**.8596**
Min	**.0693**	**.0526**	**.0686**	**.0526**	**.0526**	**.0526**	**.0686**
Avg	**.5680**	**.3920**	**.3951**	**.1093**	**.3228**	**.3386**	**.3273**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
KALE[036] BU 6149
Substation No/ Name :- 144008 / 33/11KV S//S BAJAR BHOGOAN
Feeder No / Name : 206 / 11 KV KARANJFEN GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0886	.0895	.0857	.0914	.0876	.0895	.0857
2	.0905	.0895	.0857	.0895	.0876	.0895	.0857
3	.0886	.0895	.0857	.0914	.0876	.0895	.0857
4	.1254	.0895	.0857	.1075	.0876	.0895	.0857
5	.1448	.1254	.1029	.1448	.1402	.1075	.1029
6	.2195	.1791	.1402	.2149	.2103	.1791	.1402
7	.2427	.2507	.2103	.2481	.2629	.2149	.2172
8	.2715	.2686	.2507	.2658	.2629	.2686	.2507
9	.2715	.2686	.2686	.2658	.2629	.2686	.2686
10	.2686	.2507	.2715		.2686	.2686	
11	.2507	.2686	.2686	.2629	.2507	.2686	.2629
12	.2507	.2686	.2715	.2454	.2507	.2686	.2629
13	.2507	.2686	.2507	.2454	.2507	.2686	.2454
14	.2507	.2686	.2534	.2454	.2507	.2507	.2427
15	.2507	.2686	.2561	.2454	.2507	.2507	.2454
16	.2507	.2686	.2715	.2629	.2507	.2686	.2629
17	.2686	.2686	.2835	.2804	.2686	.2686	.2629
18	.3045	.2865	.2926	.333	.3045	.2896	.333
19	.4298	.4163	.4024	.3856	.4298	.4344	
20	.3403	.3801	.3898	.3155	.3761	.3982	.3155
21	.2686	.3224	.3189	.2454	.3224	.3077	.298
22	.197	.2126	.2172	.1753	.2507	.1772	
23	.1254	.1417	.1646	.1227	.1075	.1402	
24	.1063	.1075	.1029	.0886	.0876	.0895	.1029
Max	**.4298**	**.4163**	**.4024**	**.3856**	**.4298**	**.4344**	**.333**
Min	**.0886**	**.0895**	**.0857**	**.0886**	**.0876**	**.0895**	**.0857**
Avg	**.2232**	**.2270**	**.2221**	**.2162**	**.2254**	**.2228**	**.2078**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
KALE[036] BU 6149
Substation No/ Name :- 144115 / 33/11KV VETAVADE S/STN
Feeder No / Name : 201 / 11 KV MHASURLI AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	23-DEC-17
HR	Load (MW)
18	1.9071
Max	1.9071
Min	1.9071
Avg	1.9071

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
KALE[036] BU 6149
Substation No/ Name :- 144115 / 33/11KV VETAVADE S/STN
Feeder No / Name : 202 / 11 KV MHASURLI VG GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	23-DEC-17
HR	Load (MW)
18	.2774
Max	.2774
Min	.2774
Avg	.2774

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
KODOLI[037] BU 6157
Substation No/ Name :- 144002 / 33/11 KV KODOLI
Feeder No / Name : 201 / 11 KV KAKHE AG. SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0514	.061	.6706	.823	.7621	.0514
2	.0686	.0514	.061	.5487	.823	.7621	.0514
3	.0686	.0514	.061	.6859	.823	.7621	.0514
4	.0686	.0514	.061	.6097	.823	.7621	.0514
5	.0686	.0514	.061	.6706	.823	.7621	.0514
6		.0686	.0914	.7316	1.0364	.7926	.0686
7	.1029	.0857	.0914	.823	1.2346	1.0517	.0857
8	.0857	.0857	.061	1.0059	1.448	1.2651	.0857
9	.1067	.0914	.0857	1.0212	1.7071	1.2346	.0686
10	.0762	.0914	.0857	1.0059	1.3717	.5792	.061
11	1.7833	1.7071	1.9966	.0686	.0686	.0857	1.5851
12	2.1643	2.0424	2.2862	.0686	.0686	.0686	1.9204
13	2.3015	2.1338	2.3472		.0686	.0857	2.1338
14	1.6156	2.1643	2.4844	.0514	.0686	.0686	2.0729
15	2.0881	2.1338	2.332	.0686	.0686	.0686	2.1338
16	2.0729	2.1491	2.2558	.0686	.0686	.0686	2.0119
17	2.0729	1.9662	2.2405	.0857	.061	.0686	1.9814
18	1.7528	1.8595	1.8442	.0762	.0914	.0857	1.7985
19	.12	.0914	.1029	.061	.0914	.0857	.0857
20	.1029	.0914	.0857	.061	.0914	.0857	.0686
21	.1029	.0762	.0857	.061	.0914	.0857	.0686
22	.0857	.0762		.0457	.061	.0686	.0514
23	.0686	.061	.0686	.0457	.061	.0514	.0514
24	.0686	.0686	.061	.0686	.0457	.0457	.0514
Max	**2.3015**	**2.1643**	**2.4844**	**1.0212**	**1.7071**	**1.2651**	**2.1338**
Min	**.0686**	**.0514**	**.061**	**.0457**	**.0457**	**.0457**	**.0514**
Avg	**.7441**	**.7209**	**.8222**	**.3741**	**.4966**	**.4065**	**.6934**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
KODOLI[037] BU 6157
Substation No/ Name :- 144002 / 33/11 KV KODOLI
Feeder No / Name : 202 / 11KV KODOLI URBAN VILLAGE SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3086	.3429	.3601	.3772	.4115	.3429
2	.3429	.3086	.3258	.3429	.3601	.4115	.3429
3	.3429	.3086	.3258	.3429	.3601	.4115	.3429
4	.3601	.3429	.3258	.3772	.3601	.4115	.3772
5	.4458	.4458	.3772	.4458	.3601	.4115	.4458
6	.6687	.6001	.6001	.5487	.6173	.6001	.583
7	.8745	.7545	.7202	.7716	.7716	.7716	.9602
8	.9602	.823	.8916	.9431	.9431	.8916	1.1317
9	.8916	.8573	.9259	.9602	.8745	.8916	.9088
10	.8402	.823	.9088	.8916	.8402	.8573	
11	.7888	.8059	.8573	.7888	.7716	.7888	1.0631
12	.6859	.7545	.8059	.6859	.7202	.7545	.7202
13	.6859	.6516		.6687	.6859	.7202	.6516
14	.6344	.6516	.6516	.6173	.6173	.6344	.583
15	.6173	.6173	.6516	.6001	.5658	.6344	.583
16	.6173	.6516	.703	.6001	.6859	.6001	.6173
17	.6859	.7888	.823	.6859	.7202	.703	.7202
18	.9602	.9945		.8573	1.046	.9602	.8916
19	1.2003	1.2517	1.2689	1.0631	1.2003	1.2689	1.1488
20	1.1317	1.166	1.2346	1.166	1.1488	1.0974	1.0974
21	.9945	1.0288	.9945	.9431	.9945	.9602	1.0288
22	.7888	.7545	.823	.7888	.8573	.7545	.7373
23	.5144	.5487	.583	.6173	.6859	.5144	.5144
24	.3944	.3429	.3772	.4287	.4287	.4287	.3601
Max	**1.2003**	**1.2517**	**1.2689**	**1.166**	**1.2003**	**1.2689**	**1.1488**
Min	**.3429**	**.3086**	**.3258**	**.3429**	**.3601**	**.4115**	**.3429**
Avg	**.7002**	**.6909**	**.7054**	**.6873**	**.7080**	**.7037**	**.7023**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
KODOLI[037] BU 6157
Substation No/ Name :- 144002 / 33/11 KV KODOLI
Feeder No / Name : 203 / 11 KV FACTORY VILLAGE FEEDER Feeder KV- 11 / OUTGOING GAOTHAN FEEDER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	.5144	.6344	.5487	.6516	.5144	.4801
2	1.0288	.4801	.6344	.5144	.6516	.5144	.4801
3	1.0288	.4801	.6344	.5144	.6516	.5144	.4801
4	1.0974	.4801	.6344	.5487	.6516	.6001	
5	1.4575	.6516	.6859	.7202	.6516	.6001	.6859
6	1.6289	1.0288	.9431	.8916	1.0288	.9945	.9774
7	2.1948	1.2346	1.1145	1.0288	1.2174	1.3546	1.0974
8	2.0233	1.2346	1.3203	1.1831	1.1488	1.406	.9259
9	1.9204	1.0059	1.2174	1.1317	1.2174	1.2517	1.0974
10	1.8519	1.0288	1.2003	1.1317	1.2003	1.1488	.9602
11	.9431	1.0802	1.1488	1.0117	1.0631	1.0631	.823
12	.8402	.8573	.8573	.7888	1.0288	.823	.7316
13	.8745	.823	.823	.6687	.823	.7202	.6859
14	.8745	.9259	.8916	.7716	.8573	.8573	.8916
15	.9088	.8916	.8573	.8573	.6859	.9088	.823
16	.9259	.8059	.823	.9259	.7716	.8916	.9602
17	.9602	.9431	.9602	.8059	.8059	.6859	.7926
18	1.1317	1.0974	.9774	.8059	1.0974	.823	1.046
19	1.166	1.286	1.1488	1.1145	1.2174	1.3032	1.406
20	1.0631	1.2346	1.1317	1.0288	1.1317	1.2346	1.2346
21	1.0288	1.0974	.9945	.9602	1.1488	1.1317	1.0974
22	.8573	.7888	.8573	.9259	1.0288	.823	.9431
23	.6173	.6344	.6859	.7373	.9145	.6173	.5487
24	1.046	.5487	.6344	.5658	.6516	.5487	.5144
Max	**2.1948**	**1.286**	**1.3203**	**1.1831**	**1.2174**	**1.406**	**1.406**
Min	**.6173**	**.4801**	**.6344**	**.5144**	**.6516**	**.5144**	**.4801**
Avg	**1.1874**	**.8814**	**.9088**	**.8409**	**.9290**	**.8888**	**.8558**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
KODOLI[037] BU 6157
Substation No/ Name :- 144002 / 33/11 KV KODOLI
Feeder No / Name : 204 / 11 KV POKHALE Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1372	.1219	.4877	.5639	.6401	.1715
2	.1886	.1372	.1219	.4572	.5639	.6401	.1715
3	.1715	.1372	.1219	.4572	.5639	.6401	.1715
4	.1715	.1372	.1219	.4877	.5639	.6401	.1715
5	.1715	.1715	.1524	.5182	.5639	.7316	.2058
6	.2401	.2058	.2286	.6249	1.0364	.884	.2743
7	.3086	.2915	.2896	.8535	1.3108	1.3108	.3258
8	.2743	.3086	.2896	.6859	1.7071	1.5699	.3258
9	.2134	.2591	.3086	.884	1.7071	1.6461	.3429
10	.1829	.1829	.3086	.884	1.5546	1.4937	.2743
11	1.768	1.5242	1.6004	.2229	.2401	.1029	1.7071
12	2.3472	2.0424	2.271	.2229	.2743	.1029	2.1338
13	2.4234	2.1338	2.4844	.2743	.2572	.1029	2.2558
14	2.5758	2.3015	2.4996	.2058	.2572	.0857	2.2862
15	2.4691	2.2253	2.4996	.2058	.2743	.0686	2.4387
16	2.3472	2.1795	2.3624	.2915	.2743	.2915	2.3167
17	2.2253	2.1186	2.2405	.2915	.2591	.3429	2.2253
18	1.829	1.7985	1.8138	.3048	.2743	.3429	1.89
19	.2572	.2591	.2743	.3048	.2286	.2572	.2915
20	.2572	.2439	.2743	.2743	.2286	.2743	.2743
21	.2572	.2134	.2572	.2286	.2134	.2401	.2743
22	.2058	.1524	.2058	.1829	.1829	.2058	.2058
23	.1715	.1524	.1715	.1524	.1524	.1715	.1543
24	.1886	.1543	.1372	.1715	.1524	.1524	.1715
Max	**2.5758**	**2.3015**	**2.4996**	**.884**	**1.7071**	**1.6461**	**2.4387**
Min	**.1715**	**.1372**	**.1219**	**.1524**	**.1524**	**.0686**	**.1543**
Avg	**.8931**	**.8111**	**.8815**	**.4031**	**.5585**	**.5391**	**.8775**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
KODOLI[037] BU 6157
Substation No/ Name :- 144002 / 33/11 KV KODOLI
Feeder No / Name : 205 / 11 KV AMRUT AG. SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.0857	.1067	.6097	.5944	.5792	.0857
2	.1029	.0857	.1372	.6097	.5944	.5792	.0857
3	.1029	.0857	.1067	.6097	.5944	.5792	.0857
4	.1029	.0857	.1067	.6097	.5944	.5792	.0857
5	.1029	.1029	.1067	.6097	.6401	.5792	.1029
6	.12	.12	.1067	.6401	.8993	.6859	.12
7	.1543	.1543	.1219	.7621	.8993	.8535	.1372
8	.1715	.1715	.1677	.8535	1.1126	.9755	
9	.1372	.1677	.1543	.9145	1.0974	.9907	
10	.1219	.1524	.1886	.9145	1.0822	.9907	
11	1.6004	1.4632	1.5851	.0857	.1029	.1372	1.2193
12	1.7985	1.768	1.8595		.1029	.1372	
13	1.768	1.9204	1.8595		.12	.12	1.6461
14	1.7528	1.8595	1.9509	.1029	.1029	.1029	1.6461
15	1.768	1.829	1.8138	.12	.1029	.1029	1.6766
16	1.7223	1.8442	1.768	.12	.1029	.1029	1.768
17	1.7375	1.8595	1.5699	.1372	.0914	.1543	1.7071
18	1.5546	1.6613	1.4175	.1219	.1524	.1372	1.6975
19	.1372	.1524	.1029	.1372	1.0364	.1372	.1372
20	.1372	.1372	.1029	.1372	.1067	.1372	.1372
21	.12	.1219	.0857	.1219	.0067	.1372	.12
22	.12	.1067	.0857	.1067	.1067	.12	.12
23	.12	.0914	.0686	.0914	.0914	.1029	.1029
24	.1029	.1029	.0914	.0857	.0914	.0762	.1029
Max	**1.7985**	**1.9204**	**1.9509**	**.9145**	**1.1126**	**.9907**	**1.768**
Min	**.1029**	**.0857**	**.0686**	**.0857**	**.0067**	**.0762**	**.0857**
Avg	**.6525**	**.6721**	**.6527**	**.3864**	**.4344**	**.3791**	**.6392**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
KODOLI[037] BU 6157
Substation No/ Name :- 144002 / 33/11 KV KODOLI
Feeder No / Name : 206 / 11 KV KAKHE VILLAGE FEEDER GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3086	.4458	.4458	.4115	.2743	.4287
2	.2915	.2743	.4458	.4115	.4115	.2743	.3944
3	.2915	.2743	.3772	.4115	.4115	.2743	.3944
4	.3086	.3086	.3772	.3944	.4115	.3429	.3944
5	.3086	.3772	.3772	.3944	.4458	.4115	.3944
6	.3944	.5658	.3772	.3944	.5144	.5144	.3944
7	.4458	.583	.4458	.463	.6001	.6001	.3944
8	.4458	.6173	.463	.5144	.463	.463	.3772
9	.4973	.4458	.4801	.6173	.4458	.3429	.4115
10	.5658	.3963	.463	.5658	.4115	.4287	.6516
11	.5658	.3944	.4973	.4287	.5144	.463	.4973
12	.6173	.4287	.4458	.4115	.4458	.5658	.463
13	.6344	.4973	.6344	.4458	.4115	.4801	.4287
14	.583	.5658		.5316	.3944	.4973	.4801
15	.5316	.5316	.6173	.5144	.4287	.5144	.3944
16	.3772	.4458	.5487	.5658		.583	.3772
17	.4458	.4115	.463	.6173	.442	.5658	.3963
18	.4801	.5658	.4973	.4801	.583	.6173	.5658
19	.4973	.7202	.5316	.5487	.6001	.7545	.6173
20	.4115	.6001	.583	.4801	.6401	.703	
21	.3772	.5658	.4801	.3601	.6516	.4801	.6173
22	.4801	.5487	.5144	.2915	.5144	.4287	.5316
23	.4287	.8059	.4458	.3258	.3772	.463	.4801
24	.3772	.3086	.4458	.4458	.4115	.2915	.4458
Max	**.6344**	**.8059**	**.6344**	**.6173**	**.6516**	**.7545**	**.6516**
Min	**.2915**	**.2743**	**.3772**	**.2915**	**.3772**	**.2743**	**.3772**
Avg	**.4458**	**.4809**	**.4764**	**.4608**	**.4757**	**.4722**	**.4578**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
KODOLI[037] BU 6157
Substation No/ Name :- 144002 / 33/11 KV KODOLI
Feeder No / Name : 207 / 11 KV Jakhoba LIS
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.0686	.1372	.1372		.1372	.1372
4	.0686	.0686	.1372		.1372	.1372
5	.0686	.1372	.1372		.1372	.1372
6	.0686	.1372	.1372		.1372	.1372
7	.0686	.1372	.1372		.1372	.1372
8	.0686	.1372	.1372		.1372	
9	.0686		.1372		.1372	.0686
10	.0686	.1219	.1372		.1372	
11	.0686	.1219	.12		.1372	.1219
12	.0686	.1219	.12		.1372	.1219
13	.061	.1219	.1372		.1372	.1219
14	.061	.1219	.1372	.1372		.1067
15	.061	.1219	.1372	.1372		.1067
16	.061	.1372	.1372	.1372	.1372	.1067
17	.0686	.1219	.1372	.1372	.12	.1067
18	.1372	.1372	.12		.1372	.12
Max	**.1372**	**.1372**	**.1372**	**.1372**	**.1372**	**.1372**
Min	**.061**	**.0686**	**.12**	**.1372**	**.12**	**.0686**
Avg	**.0710**	**.1255**	**.1340**	**.1372**	**.1360**	**.1191**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
KODOLI[037] **BU 6157**
Substation No/ Name :- 144002 / 33/11 KV KODOLI
Feeder No / Name : 401 / 33 KV Biltube Express Feeder Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS (CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3148	2.572	2.4691	2.6235	2.4691	2.0576	1.8004
2	2.4691	2.6749	2.6235	2.572	2.4691	1.9547	1.9547
3	2.2634	2.572	2.3663	2.4691	2.3663	1.8519	2.0576
4	2.3663	2.4691	2.1605	2.4691	2.4691	1.9033	2.1605
5	2.572	2.572	2.0576	2.6749	2.3663	1.8519	2.2634
6	2.3663	2.4691	1.8004	2.8807	2.4691	1.9033	2.4691
7	2.0062	2.1605	2.1091	2.572	2.2634	2.3148	2.5206
8	2.0062	3.1379	2.572	2.5206	2.3148	2.4691	2.572
9	2.572	2.7778	2.8292	2.6749	2.0576	3.1379	2.1605
10	2.7778	2.6749	2.7778	2.5206	2.4691	2.0576	2.3777
11	2.7263	2.4234	2.4177	2.7263	2.4691	1.3375	2.7263
12	2.3148	1.9662	2.3663	2.7778	2.4691	1.3889	2.6749
13	2.652	1.9662	2.572	2.8807	1.4918	1.3375	3.0864
14	2.0119	2.2862	3.1379	3.0864	1.9547	1.1831	2.5206
15	2.5149	2.6063	2.7778	2.4691	2.2634	1.3375	2.6749
16	2.5606	2.6749	2.0062	2.1605	2.1605	2.3663	2.3777
17	3.1893	2.6235	2.7263	2.8292	1.2346	2.6749	2.7263
18	2.6235	2.9321	2.2119	2.3663	2.8807	2.2119	3.0864
19	2.3663	2.9321	2.8292	2.3663			2.8807
20	2.3148	2.3663	2.3148	2.2634	2.4177	2.4691	2.572
21	2.4691	2.4691	2.4691	2.1605	2.7778	2.3148	2.6749
22	2.4691	2.6235	2.6749	2.3148	2.572	2.572	2.5206
23	2.8807	2.2119	2.572	2.4177	2.3663	2.4177	3.1893
24	2.1091	2.6749	2.4177	2.572	2.4177	1.8519	1.8519
Max	**3.1893**	**3.1379**	**3.1379**	**3.0864**	**2.8807**	**3.1379**	**3.1893**
Min	**2.0062**	**1.9662**	**1.8004**	**2.1605**	**1.2346**	**1.1831**	**1.8004**
Avg	**2.4549**	**2.5349**	**2.4691**	**2.5570**	**2.3126**	**2.0420**	**2.4958**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
KODOLI[037] BU 6157
Substation No/ Name :- 144014 / 33/11 KV SATAVE
Feeder No / Name : 201 / Single Phasing Stave- Sawarde Feeder KV- 11 / OUTGOING **SINGLE PHASING**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4915	.5087	.3605	.407	.0526	.0339	.0343
2	.5243	.4915	.3768	.4409	.0509	.0339	.0343
3	.5243	.426	.3932	.4409	.0514	.0335	.0343
4	.5571	.426	.3932	.4409	.0514	.0335	.0343
5	.6706	.426	.4973	.503	.0514	.0503	.0514
6	.7459	.5365	.5967	.6036	.0514	.0678	.052
7	.8356	.7209	.6796	.7459	.0514	.0838	.0686
8	.8907	.8383	.852	.8356	.0686	.0838	.0686
9	1.0479	.9175	.8583	1.0159	.0686	.0663	.0686
10	.9526	.9012	.8322	1.0486	.0678	.0678	.0503
11	.0509	.0566	.0838	1.0486	1.2765	1.2193	.0503
12	.0572	.0566	.0762	1.1736	1.4146	1.4146	.0503
13	.0526	.0566	.0572	1.2003	1.4712	1.4712	.0572
14	.0572	.0381	.0572	1.4712	1.4146	1.5089	.0572
15	.0572	.0572	.0572	1.4712	1.4712	1.5844	.0572
16	.0572	.0381	.0572	1.3957	1.4335	1.4712	.0572
17	.0503	.0572	.0572	1.3717	1.2449	1.4146	.0572
18	.0497	.0572	.0953	1.2384	1.1431	1.4289	.0686
19	.132	.132	.132	.1132	.132	.132	.132
20	.132	.132	.132	.132	.132	.132	.132
21	.1132	.1132	.1132	.132	.132	.132	.1132
22	.0754	.0754	.0754	.0754	.0953	.0943	.0754
23	.0566	.0381	.0572	.0572	.0572	.0572	.0572
24	.0566	.0566	.0381	.0381	.0572	.0381	.0381
Max	**1.0479**	**.9175**	**.8583**	**1.4712**	**1.4712**	**1.5844**	**.132**
Min	**.0497**	**.0381**	**.0381**	**.0381**	**.0509**	**.0335**	**.0343**
Avg	**.3433**	**.2982**	**.2887**	**.7250**	**.5017**	**.5272**	**.0625**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
KODOLI[037] BU 6157
Substation No/ Name :- 144014 / 33/11 KV SATAVE
Feeder No / Name : 202 / Single Phasing Stave- Mohare Feeder KV- 11 / OUTGOING **FEEDER SEPERATION/PURE AG**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.9816	1.1191	.6516
2				1.1869	1.1191	.823
3				1.2003	1.1065	.8573
4				1.286	1.1065	.8916
5				1.286	1.1401	.8916
6				1.3717	1.2209	.9362
7				1.3717	1.3748	1.0288
8				1.6118	1.4586	1.1317
9				1.5604	1.5083	1.5089
10				1.4752	1.4582	1.576
11	1.4083	1.6598	1.5927			1.3916
12	1.9052	2.3011	2.1338			1.8945
13	1.9281	2.2634	2.2481			2.0195
14	2.191	2.2862	2.3243			2.0957
15	2.2862	2.2481	2.3243			2.21
16		2.2481	2.2862			2.21
17		2.1719	2.2481			2.0576
18	1.6244	2.0005	2.0576			1.7833
Max	**2.2862**	**2.3011**	**2.3243**	**1.6118**	**1.5083**	**2.21**
Min	**1.4083**	**1.6598**	**1.5927**	**.9816**	**1.1065**	**.6516**
Avg	**1.8905**	**2.1474**	**2.1519**	**1.3332**	**1.2612**	**1.4422**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
KODOLI[037] BU 6157
Substation No/ Name :- 144014 / 33/11 KV SATAVE
Feeder No / Name : 203 / Single Phasing Stave- Satave Feeder KV- 11 / OUTGOING **SINGLE PHASING**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4096	.4917	.2458	.373	.0526	.0339	.0343
2	.426	.4752	.2622	.407	.0509	.0339	.0343
3	.426	.4424	.2622	.407	.0514	.0335	.0343
4	.4588	.4096	.2622	.407	.0514	.0335	.0343
5	.5365	.4096	.3315	.4694	.0514	.0503	.0514
6	.5967	.4694	.3812	.503	.0514	.0678	.0693
7	.6554	.6371	.5304	.663	.0686	.1006	.0857
8	.7287	.6706	.6554	.7373	.0857	.1006	.0857
9	.8573	.6882	.664	.852	.0857	.0663	.0857
10	.7621	.6226	.5601	.9503	.0678	.0678	.0671
11	.0509	.0754	.0838	.852	.9526	1.0288	.0671
12	.0572	.0754	.0762	.9389	1.1506	1.1317	.0503
13	.0526	.0754	.0762	1.0288	1.226	1.2826	.0572
14	.0572	.0572	.0572	1.094	1.1883	1.3203	.0572
15	.0572	.0572	.0572	1.2826	1.1506	1.358	.0572
16	.0572	.0572	.0572	1.2071	1.2449	1.3203	.0572
17	.0503	.0762	.0572	1.2193	1.1883	1.2071	.0762
18	.0497	.0762	.0953	1.105	1.1622	1.1431	.0857
19	.132	.132	.1509	.132	.1509	.132	.1509
20	.132	.132	.1509	.132	.1509	.1509	.1509
21	.132	.132	.132	.132	.132	.1509	.132
22	.0943	.0943	.0943	.0754	.0953	.0943	.0943
23	.0566	.0572	.0762	.0572	.0572	.0572	.0762
24	.0566	.0566	.0572	.0572	.0572	.0572	.0572
Max	**.8573**	**.6882**	**.664**	**1.2826**	**1.2449**	**1.358**	**.1509**
Min	**.0497**	**.0566**	**.0572**	**.0572**	**.0509**	**.0335**	**.0343**
Avg	**.2872**	**.2696**	**.2240**	**.6284**	**.4385**	**.4593**	**.0730**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
KODOLI[037] BU 6157
Substation No/ Name :- 144014 / 33/11 KV SATAVE
Feeder No / Name : 204 / Bhairavnath LIS Satave
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.0819	.0655	.0492	.0686	.0838	
4	.0819	.0655	.0492	.0857	.0838	
5	.0838	.0819	.0497	.0857	.0838	
6	.0829	.0838	.0497	.0857	.0848	
7	.0819	.0838	.0497	.0857	.0838	
8	.081	.0838	.0492	.0857	.0838	.0343
9	.0953	.0819	.0486	.0857	.0829	.0343
10	.0953	.0819	.048	.0848	.0848	.0503
11	.0339	.0943	.0503	.0953	.0953	.0503
12	.0381	.0943	.0572	.0943	.0943	.0503
13	.0876	.0943	.0572	.0943	.0943	.0572
14	.0953	.0953	.0572		.0943	.0572
15	.0953	.0953	.0953	.0566	.0943	.0572
16	.0953	.0953	.0953	.0566	.0943	.0572
17	.0838	.0953	.0953	.0943	.0943	.0572
18	.0332	.0953	.0953	.0953	.0953	.0514
Max	**.0953**	**.0953**	**.0953**	**.0953**	**.0953**	**.0572**
Min	**.0332**	**.0655**	**.048**	**.0566**	**.0829**	**.0343**
Avg	**.0779**	**.0867**	**.0623**	**.0836**	**.0892**	**.0506**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
MALKAPUR[041] BU 6190
Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI
Feeder No / Name : 201 / Shahuwadi-Maan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.037	.0377	.0351	.0377	.0366	.0566	.0362
2	.037	.0377	.0351	.0377	.0366	.0566	.0362
3	.037	.0377	.0351	.0377	.0366	.0566	.0377
4	.0373	.0377	.0351	.0377	.0358	.056	.0358
5	.0739	.0747	.0537	.0754	.0543	.0747	.0537
6	.132	.112	.0905	.112	.0914	.112	.0905
7	.1267	.1478	.1254	.1307	.1294	.1478	.1097
8	.1448	.128	.1612	.1463	.1698	.1791	.1294
9	.1075	.128	.1612	.128	.1402	.1663	.1402
10	.0995	.1097	.1075	.128	.12	.1402	.1387
11	.1075	.0895	.1227	.1029	.1475	.1227	.1326
12	.0886	.1052	.12	.0876	.1174	.12	.12
13	.0895	.1052	.0907	.1052	.1029	.1174	.1063
14	.1052	.0709		.1052	.12	.1147	.1075
15	.1029	.0701		.0895	.1029	.1147	.1097
16	.0671	.1029	.0772	.0701	.0937	.1372	.112
17	.0876	.096	.1006	.1063	.1075	.1753	.1463
18	.1433	.1372	.1448	.1612	.1433	.2195	.2241
19	.2172	.2402	.2378	.2149	.2033	.2402	.2378
20	.1991	.2241	.2195	.2054	.2218	.2241	.1829
21	.1829	.2054	.2054	.1698	.1848	.1829	.1433
22	.1307	.1267	.1307	.112	.1307	.128	.1097
23	.0747	.0905	.0747	.0739	.0747	.0724	.0739
24	.037	.0566	.0537	.0566	.0554	.056	.0543
Max	**.2172**	**.2402**	**.2378**	**.2149**	**.2218**	**.2402**	**.2378**
Min	**.037**	**.0377**	**.0351**	**.0377**	**.0358**	**.056**	**.0358**
Avg	**.1028**	**.1071**	**.1099**	**.1055**	**.1107**	**.1280**	**.1112**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
MALKAPUR[041] BU 6190
Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI
Feeder No / Name : 202 / Shahuwadi- Amba SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0754	.0754	.0754	.0754	.0924	.0754
2	.0747	.0754	.0754	.0754	.0754	.0934	.0754
3	.0747	.0754	.0754	.0754	.0754	.0747	.0754
4	.0739	.0754	.0754	.0754	.0754	.0747	.0754
5	.0924	.1132	.0943	.0943	.0943	.112	.0943
6	.128	.1509	.132	.1307	.1132	.1307	.132
7	.1463	.1698	.1509	.1509	.1509	.1663	.1509
8	.181	.2241	.1886	.1867	.2075	.2195	.1886
9	.1829	.2987	.2241	.2241	.2427	.2149	.2241
10	.197	.3174	.3258	.2614	.2743	.2172	.2587
11	.197	.2865	.2896	.2378	.2481	.2378	.2534
12	.2149	.3403	.2865	.1629	.2865	.2378	.2172
13	.2103	.3361	.2865	.2353	.2743	.2195	.2172
14	.2507	.2835	.2865	.2012	.2534	.2195	.2195
15	.2507	.2865	.2715	.1991	.2658	.2195	.2561
16	.2353	.2926	.2328	.2012	.2686	.2241	.2614
17	.1991	.2658	.2743	.2218	.2507	.2427	.2587
18	.2378	.2743	.2743	.2241	.2561	.2241	.2801
19	.2772	.2772	.2743	.2614	.2195	.2614	.2801
20	.2402	.2587	.2587	.2427	.2241	.2241	.2561
21	.2241	.2218	.2241	.2054	.1848	.1886	.2149
22	.1867	.168	.1698	.1698	.1494	.132	.1448
23	.1307	.132	.132	.132	.1307	.0943	.1109
24	.0747	.0943	.0943	.0943	.0943	.0943	.0754
Max	**.2772**	**.3403**	**.3258**	**.2614**	**.2865**	**.2614**	**.2801**
Min	**.0739**	**.0754**	**.0754**	**.0754**	**.0754**	**.0747**	**.0754**
Avg	**.1731**	**.2122**	**.1989**	**.1724**	**.1871**	**.1756**	**.1832**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
MALKAPUR[041] BU 6190
Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI
Feeder No / Name : 203 / Shahuwadi-sawe GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1509	.1509	.1509	.1509	.2075	.1509
2	.1463	.1509	.1509	.1509	.1509	.1867	.1509
3	.1433	.1509	.1509	.1509	.1509	.1867	.1509
4	.1463	.1509	.1509	.1509	.1886	.1867	.1509
5	.181	.1886	.1886	.1886	.2263	.2241	.2263
6	.2561	.2829	.2829	.2829	.2829	.3018	.2829
7	.2957	.3772	.3018	.3772	.3395	.3734	.3395
8	.3547	.415	.3395	.3961	.3961	.4024	.3961
9	.3547	.415	.3921	.3961	.4108	.4294	.3734
10	.3511	.4527	.3696	.4108	.4066	.4024	.3547
11	.3841	.3881	.3696	.3734	.3696	.3361	.3142
12	.3174	.3395	.3547	.3018	.3142	.2987	.3174
13	.2987	.2614	.3174	.2641	.2241	.2263	.3174
14	.2263	.2075	.2987	.2075		.2263	.2987
15	.2075	.2241	.2402	.1698	.2075	.1698	.2801
16	.2427	.2263	.2075	.2452		.2263	.2801
17	.2987	.3174	.3395	.3395	.1867	.3395	.3142
18	.4481	.4854	.4904	.4527	.2987	.4904	.4435
19	.5601	.5658	.5658	.5281	.439	.5658	.5304
20	.5228	.5281	.5281	.5281	.5175	.5658	.5228
21	.4481	.4715	.4715	.4715	.4024	.4527	.415
22	.3772	.3584	.3018	.3395	.3361	.3772	.3326
23	.2263	.2641	.2263	.2641	.2926	.2452	.2614
24	.1848	.1886	.1886	.1886	.1886	.2054	.1886
Max	**.5601**	**.5658**	**.5658**	**.5281**	**.5175**	**.5658**	**.5304**
Min	**.1433**	**.1509**	**.1509**	**.1509**	**.1509**	**.1698**	**.1509**
Avg	**.2967**	**.3151**	**.3074**	**.3054**	**.2946**	**.3178**	**.3080**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
MALKAPUR[041] BU 6190
Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI
Feeder No / Name : 204 / Shahuwadi-Kotoli Ag FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0469	.0324	.0305			
2	.0469	.032	.0305			
3	.0469	.048	.0305			
4	.0474	.0486	.0305			
5	.064	.0655	.0305			
6	.08	.0819	.0305			
7	.0972	.1311	.0328			
8	.1311	.1638	.0648			
9	.1638	.1658	.1296			
10	.2012	.1457	.1943			
11			.2622	.2458	.2241	.3315
12			.3077	.2818	.2591	.3353
13			.3239	.3018	.2683	.3353
14			.3041	.3018	.2683	.3315
15			.3239	.3113	.2486	.3353
16			.285	.2785	.2458	.3185
17			.2683	.2622	.2683	.2984
18			.2347	.2321	.2401	.2347
Max	**.2012**	**.1658**	**.3239**	**.3113**	**.2683**	**.3353**
Min	**.0469**	**.032**	**.0305**	**.2321**	**.2241**	**.2347**
Avg	**.0925**	**.0915**	**.1619**	**.2769**	**.2528**	**.3151**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
MALKAPUR[041] BU 6190
Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI
Feeder No / Name : 205 / Shahuwadi - Malkapur GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.1509	.1886	.1509	.1886	
2	.1886	.1886	.1509	.1509	.1509	.1698	.1509
3	.168	.1829	.1509	.1509	.1509	.1698	.1509
4	.168	.1886	.1509	.1509	.1509	.168	.1509
5	.2241	.2452	.1886	.1886	.1886	.2241	.1886
6	.3174	.3018	.2452	.2452	.2641	.3142	.2829
7	.3772	.3584	.3018	.3395	.3395	.3696	.3772
8	.4527	.3734	.3734	.3921	.415	.4066	.4338
9	.3734	.4108	.4481	.4108	.4108	.439	.4108
10	.3511	.4108	.3734	.4108	.3921	.4024	.4108
11	.4251	.3658	.3881	.4066	.3881	.3658	.3547
12	.3511	.3142	.3475	.3326	.3841	.362	.3547
13	.3475	.3174	.3475	.2801	.3658	.3258	.3547
14	.3511	.3142	.3547	.2987	.3658	.3109	.3734
15	.3292	.3326	.3511	.2772	.3292	.3292	.4108
16	.3475	.3658	.3326	.2926	.3439	.3696	.4108
17	.3475	.3801	.4108	.3696	.4024	.4108	
18	.5121	.5175	.5228	.4854	.4854	.4854	.5487
19	.6219	.6535	.6535	.5975	.5601	.6036	.5975
20	.6401	.5658	.5975	.5847	.5975	.5658	.5544
21	.5544	.5281	.5228	.547	.5041	.4904	.4755
22	.4481	.415	.3772	.415	.3734	.415	.362
23	.2641	.3018	.2641	.2829	.2772	.2641	.2218
24	.1886	.2263	.1886	.2263	.1886	.1886	.1886
Max	**.6401**	**.6535**	**.6535**	**.5975**	**.5975**	**.6036**	**.5975**
Min	**.168**	**.1829**	**.1509**	**.1509**	**.1509**	**.168**	**.1509**
Avg	**.3557**	**.3520**	**.3414**	**.3344**	**.3408**	**.3475**	**.3529**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
MALKAPUR[041] BU 6190
Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI
Feeder No / Name : 206 / Shahuwadi-Parale Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1852	.0114	.0171	.0111	.2294	.3018	.1677
2	.2035	.0114	.0171	.0114	.2294	.3018	.1677
3	.2012	.0114		.0114	.2294	.2743	.1658
4	.2012	.0114	.0171	.0114	.2587	.2622	.1989
5	.2035	.0107	.0171	.0114	.2683	.2652	.2347
6	.2241	.0101	.0171	.0107	.3018	.2713	.285
7	.2713	.0099	.0168	.0103	.4024	.373	.3688
8	.3018	.0099	.0164	.0103	.547	.4359	.3978
9	.4239	.0095	.0171	.0105	.5304	.4694	.4359
10	.4527	.0095	.0183	.0105	.4973	.503	.4694
11	.5197	.5735	.5243	.0171	.0166	.0152	.0097
12	.6036	.6133	.6706		.0147	.0137	.0137
13	.6036	.6371	.7042	.012	.0149	.0137	.0297
14	.6299	.6706	.7377	.0128	.0166	.0141	.0137
15	.6539	.6371	.7712	.0141	.0114	.0141	.0137
16	.6299	.6371	.7127	.0149	.0118	.0152	.0141
17	.5407	.5801	.6173	.0152	.0118	.0152	.0133
18	.5365	.57	.4801	.0152	.0114	.016	.0141
19	.0114	.0185	.0114	.0156	.0118	.0168	.0137
20	.0114	.016	.0111	.016	.0111	.0162	.0168
21	.0107	.0183	.0103	.0168	.0114	.0164	.0149
22	.0111	.0183	.0099	.0171	.013	.0164	.017
23	.0111	.0183	.0107	.0171	.0124	.0166	.0168
24	.017	.0114	.0175	.0099	.0171	.013	.0156
Max	**.6539**	**.6706**	**.7712**	**.0171**	**.547**	**.503**	**.4694**
Min	**.0107**	**.0095**	**.0099**	**.0099**	**.0111**	**.013**	**.0097**
Avg	**.3108**	**.2135**	**.2367**	**.0132**	**.1533**	**.1529**	**.1295**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
MALKAPUR[041] BU 6190
Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI
Feeder No / Name : 207 / Shahuwadi-Bajagewadi Ag FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1966	.1966	.048			
2	.1966	.1989	.048			
3	.1638	.1989	.048			
4	.1638	.2012	.048			
5	.1638	.2347	.064			
6	.2012	.2347	.0819			
7	.2058	.3018	.1006			
8	.2572	.3353	.1715			
9	.3086	.3353	.2743			
10	.3258	.3353	.3086			
11			.3353	.3521	.285	.3481
12			.4144	.3978	.431	.3932
13			.4475	.3481	.421	.426
14			.431	.2818	.421	.4973
15			.431	.4191	.2267	.5304
16			.3647	.1966	.2949	.5197
17			.3353	.2294	.3201	.4973
18			.3353	.1966	.3521	.4588
Max	**.3258**	**.3353**	**.4475**	**.4191**	**.431**	**.5304**
Min	**.1638**	**.1966**	**.048**	**.1966**	**.2267**	**.3481**
Avg	**.2183**	**.2573**	**.2382**	**.3027**	**.3440**	**.4589**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
MALKAPUR[041] BU 6190
Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI
Feeder No / Name : 208 / Shahuwadi-Perid Ag FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0671	.1029	.0983
2				.0671	.1029	.0983
3				.0671	.1017	.0972
4				.1006	.1029	.1296
5				.1326	.104	.128
6				.2012	.0914	.16
7				.2294	.1966	.16
8				.2591	.2683	.1875
9				.2591	.2622	.2241
10				.2401	.2984	.2591
11	.426	.4915	.4424			.3201
12	.5304	.5801	.5304			.3521
13	.5304	.6036	.5304			.3887
14	.503	.6036	.5365			
15	.4973	.5967	.5636			.5898
16	.5138	.57	.421			.5967
17	.4915	.5407	.3932			.5967
18	.3277	.5304	.3353			.5636
Max	**.5304**	**.6036**	**.5636**	**.2591**	**.2984**	**.5967**
Min	**.3277**	**.4915**	**.3353**	**.0671**	**.0914**	**.0972**
Avg	**.4775**	**.5646**	**.4691**	**.1623**	**.1631**	**.2912**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
MALKAPUR[041] BU 6190
Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI
Feeder No / Name : 209 / Shahuwadi-Ameni vg GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0189	.0191	.0189	.0189	.0189
2	.0191	.0191	.0189	.0191	.0189	.0187	.0189
3	.0191	.0191	.0189	.0191	.0189	.0191	.0189
4	.0191	.0191	.0189	.0191	.0189	.0191	.0189
5	.0191	.0191	.0189	.0191	.0189	.0191	.0189
6	.0191	.0377	.0189	.0377	.0189	.0191	.0189
7	.0191	.0377	.0377	.0377	.0377	.0191	.0377
8	.0381	.0377	.0377	.0377	.0377	.0191	.0377
9	.0381	.0373	.0377	.0377	.0377	.0191	.0377
10	.0381	.0373	.0189	.0373	.0377	.0189	.0377
11	.0381	.0381	.0381	.0381	.0381	.0377	.0377
12	.0381	.0381	.0381	.0381	.0381	.0377	.0377
13	.0381	.0381	.0381	.0381	.0381	.0377	.0377
14	.0381	.0381	.0381	.0381	.0381	.0377	.0191
15	.0381	.0381	.0381	.0381	.0381	.0377	.0191
16	.0381	.0381	.0381	.0381	.0381	.0377	.0189
17	.0381	.0381	.0377	.0377	.0381	.0377	.0189
18	.0377	.0377	.0377	.0377	.0183	.0377	.0189
19	.0377	.0377	.0377	.0377	.0377	.0377	.0191
20	.0377	.0377	.0377	.0377	.0381	.0377	.0191
21	.0377	.0377	.0377	.0189	.0191	.0377	.0191
22	.0191	.0189	.0191	.0189	.0191	.0189	.0191
23	.0191	.0189	.0191	.0189	.0191	.0189	.0191
24	.0191	.0191	.0189	.0191	.0189	.0191	.0189
Max	**.0381**	**.0381**	**.0381**	**.0381**	**.0381**	**.0377**	**.0377**
Min	**.0191**	**.0189**	**.0189**	**.0189**	**.0183**	**.0187**	**.0189**
Avg	**.0301**	**.0316**	**.0300**	**.0308**	**.0292**	**.0276**	**.0244**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
MALKAPUR[041] BU 6190
Substation No/ Name :- 144012 / 33 /11 KV SARUD
Feeder No / Name : 201 / Sarud-Bambawade Village GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.4481		.3734	.4481	.4481	
2	.3174	.4481		.3734	.4481	.4108	
3	.3174	.4481		.3734	.4481	.4108	
4	.3174	.4668		.3734	.4481	.4481	
5	.3734	.4668		.3734	.6535	.5601	
6	.5975	.5601		.6535	.8215	.6722	
7	.8962	.8962		.8215	.8962	.8215	
8	.8962	.9709		.8962	.7842	.9896	
9		.8215	.8402		.8215	.8402	.9335
10	.8962	.9335	.8589	.8215	.8962	1.1949	.8962
11	.8402	.8589	.8589	.8962	.8589	.9709	.7095
12	.8402	.9335	.8402	.8962	.7655	.8962	.7095
13	.8402	.9522	.8589	.8215	.7316	.8215	.7095
14		.8029	.8402	.7468	.7468	.8215	.6722
15	.8402	.7655	.8402	.6722	.7468	.8402	.6722
16	.8402	.8215	.8402	.7468	.8589	.8589	.7468
17	.8962	1.0269	.8589	.8215	.8962	.9709	.7468
18	1.0456	.9896	.9709	.8215	.9896	1.1203	1.0269
19	1.307	1.3443	1.419	1.251	1.3443		1.4003
20	1.4003	1.1949	1.2883	1.2136	1.2696		1.3443
21	1.1949	1.0456	.9335	1.1203	1.1949		1.1763
22	.7468		.8775	.7468	.7468		.9335
23	.5228		.5601	.5228	.5601		.5975
24	.3361	.4481		.3734	.4481	.4481	
Max	**1.4003**	**1.3443**	**1.419**	**1.251**	**1.3443**	**1.1949**	**1.4003**
Min	**.3174**	**.4481**	**.5601**	**.3734**	**.4481**	**.4108**	**.5975**
Avg	**.7545**	**.802**	**.9124**	**.7265**	**.7843**	**.7655**	**.885**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
MALKAPUR[041] BU 6190
Substation No/ Name :- 144012 / 33 /11 KV SARUD
Feeder No / Name : 202 / Sarud-Bhedasgaon GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1867		.1867	.1867	.1867	
2	.1867	.1867		.1867	.1867	.1867	
3	.1867	.1867		.1867	.1867	.1867	
4	.1867	.1867		.1867	.1867	.2241	
5	.2987	.2801		.2427	.2801	.2987	
6	.4481	.3734		.3734	.4668	.4481	
7	.5228	.4481		.4108	.5228	.5228	
8	.5228	.5228		.4668	.4854	.5228	
9		.5228	.2987		.4854	.5228	.5601
10	.4108		.4108	.4854	.4481	.3734	.4668
11	.3734	.4668	.4108	.4108	.4481	.4108	.4108
12	.3734	.4108	.4108	.3734	.4481	.3734	.3734
13	.3361	.4108	.4108	.3361	.4108	.3547	.3547
14		.4294	.4108	.3734	.4108	.3174	.3174
15	.2987	.3921	.4481	.3734	.3734	.3174	.3174
16	.3361	.4294	.4668	.3361	.4108	.3361	.3734
17	.4108	.4668	.4668	.4108	.3734	.3734	.3734
18	.4668	.4108	.4668	.3734	.4854		.4854
19	.4668	.5975	.5975	.5228	.6348		.6348
20	.4854	.4854	.5601	.4854	.5975		.5601
21	.4481	.4854	.4668	.4481	.4854		.5041
22	.3734		.3734	.2801	.3361		.3547
23	.2054		.2801	.2241	.2241		.2054
24	.1867	.1867		.1867	.1867	.1867	
Max	**.5228**	**.5975**	**.5975**	**.5228**	**.6348**	**.5228**	**.6348**
Min	**.1867**	**.1867**	**.2801**	**.1867**	**.1867**	**.1867**	**.2054**
Avg	**.3505**	**.3841**	**.4319**	**.3418**	**.3859**	**.3413**	**.4195**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
MALKAPUR[041] BU 6190
Substation No/ Name :- 144012 / 33 /11 KV SARUD
Feeder No / Name : 203 / Sarud-Sarud Village GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0747		.0747	.0747	.0747	
2	.0747	.0747		.0747	.0747	.0747	
3	.0747	.0747		.0747	.0747	.0747	
4	.0747	.0747		.0747	.0747	.0934	
5	.0934	.112		.0747	.112	.1494	
6	.1494	.1494		.1494	.1494	.2054	
7	.2241	.2241		.2241	.2241	.2614	
8	.2241	.2054		.2427	.2241	.2614	
9		.168	.2241		.2241	.2801	.2801
10	.2241	.2054	.2241	.2614	.2241	.2241	.2614
11	.1867	.2054	.1867	.2241	.2241	.2241	.2427
12	.1494	.2054	.1867	.2241	.1867	.168	.168
13	.1494		.1867	.2241	.1494	.1494	.1494
14		.1494	.1867	.1867	.1494	.1494	.168
15	.1867	.1867	.1867	.1867	.2241	.1867	.1867
16	.2241	.2054	.1867	.1867	.2801	.2241	.2241
17	.2241	.2241	.2054	.2241	.2801	.2801	.2241
18	.1867	.2614	.2427	.2241	.2987		.2614
19	.2241	.4108	.3174	.2801	.3361		.4108
20	.2241	.2987	.3361	.2801	.3361		.3361
21	.168	.2987	.2614	.2427	.2614		.3174
22	.0934		.1867	.1867	.1867		.2241
23	.0934		.1494	.0747	.1307		.112
24	.0934	.0747		.0934	.0747	.0934	
Max	**.2241**	**.4108**	**.3361**	**.2801**	**.3361**	**.2801**	**.4108**
Min	**.0747**	**.0747**	**.1494**	**.0747**	**.0747**	**.0747**	**.112**
Avg	**.1553**	**.1849**	**.2178**	**.1778**	**.1906**	**.1764**	**.2378**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
MALKAPUR[041] BU 6190
Substation No/ Name :- 144012 / 33 /11 KV SARUD
Feeder No / Name : 204 / Sarud-Gogawe Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.4481		.0187	.0187	.0191	
2	.5601	.4481		.0187	.0187	.0191	
3	.5601	.4668		.0187	.0187	.0191	
4	.5601	.4668		.0187	.0187	.0191	
5	.5601	.4668		.0187	.0187	.0191	
6	.6722	.6535		.0187	.0187	.0191	
7	.8215	.7468		.0187	.0187	.0191	
8	.9709	.8215		.0187	.0187	.0191	
9		.8962	1.1203			.0191	.0187
10	.9709	.9335	.9709	.0191	.0191	.0187	.0187
11	.0191	.0187	.0191	1.2696	1.4937	1.4937	1.4937
12	.0191	.0187	.0191	1.2696	1.5123	1.5684	1.5684
13	.0191	.0187	.0191	1.5684	1.4937	1.5497	1.4937
14		.0187	.0191	1.5364	1.531	1.5497	1.4003
15	.0191	.0187	.0191	1.643	1.5684	1.5497	1.3443
16	.0191	.0187	.0191	1.4937	1.7177	1.5684	1.3443
17	.0191	.0187	.0191	1.3443	1.4937	1.4937	1.3817
18	.0187	.0191	.0191		1.419		1.2323
19	.0187	.0191	.0191	.0187	.0191		.0187
20	.0187	.0191	.0191	.0187	.0191		.0187
21	.0187	.0191	.0187	.0187	.0191		.0187
22	.0187		.0187	.0187	.0191		.0187
23	.0187		.0187	.0187	.0191		.0187
24	.0187	.0187		.0187	.0187	.0191	
Max	**.9709**	**.9335**	**1.1203**	**1.643**	**1.7177**	**1.5684**	**1.5684**
Min	**.0187**	**.0187**	**.0187**	**.0187**	**.0187**	**.0187**	**.0187**
Avg	**.2946**	**.2988**	**.1559**	**.4730**	**.5440**	**.6102**	**.7593**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
MALKAPUR[041] BU 6190
Substation No/ Name :- 144012 / 33 /11 KV SARUD
Feeder No / Name : 205 / Sarud-Shirgaon Village GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.056		.056	.056	.0566	
2	.056	.056		.056	.056	.056	
3	.056	.056		.056	.056	.0566	
4	.056	.0747		.056	.0747	.0754	
5	.0747	.0934		.0747	.112	.0934	
6	.112	.112		.0934	.1307	.112	
7	.1494	.1494		.112	.1494	.1494	
8	.168	.168		.168	.168	.1867	
9		.168	.1905		.1494	.1867	.168
10	.1494	.168	.1905	.1494	.1307	.1867	.168
11	.112	.168	.1524	.168	.1307	.1494	.168
12	.1307	.168	.1524	.168	.112	.1494	.168
13	.112	.168	.1524	.1307	.112	.112	.1494
14		.1494	.1524	.168	.112	.0934	.1494
15	.112	.1494	.1524	.1307	.1307	.112	.1307
16	.1307	.1307	.1524	.112	.1307	.1494	.1494
17	.1307	.1494	.1905	.1494	.168	.1494	.1307
18	.1867	.1867	.2096	.168	.1867		.168
19	.2241	.2614	.2987	.2801	.2801		.2427
20	.2614	.2614	.2427	.2427	.2614		.2427
21	.2054	.2241	.1867	.2241	.2054		.2614
22	.1867		.1494	.1867	.1867		.168
23	.1494		.0934	.0934	.112		.0747
24	.056	.056		.056	.056	.056	
Max	**.2614**	**.2614**	**.2987**	**.2801**	**.2801**	**.1867**	**.2614**
Min	**.056**	**.056**	**.0934**	**.056**	**.056**	**.056**	**.0747**
Avg	**.1307**	**.1443**	**.1778**	**.1348**	**.1361**	**.1184**	**.1693**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
MALKAPUR[041] **BU 6190**
Substation No/ Name :- 144012 / 33 /11 KV SARUD
Feeder No / Name : 206 / Sarud-Salashi Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6535		.112	.0934	.0934	
2		.7468		.112	.0934	.0934	
3		.7468		.112	.0934	.0934	
4		.7095		.112	.0934	.112	
5		.8402		.112	.112	.1494	
6		1.1203		.1494	.1494	.1867	
7		1.4377		.168	.168	.1867	
8		1.643		.1867	.1867	.2054	
9		1.7551	1.7924		.2054	.2054	.1867
10	1.1203	1.3256	1.4632	.1867	.1867	.2241	.2801
11	.1867	.1494	.1905	1.9753	2.2405	1.9791	2.2405
12		.168	.168	2.4691	2.5206	2.3525	2.3899
13		.168	.1715	2.4326	2.7069	2.4272	2.5953
14		.168	.1905	2.5789	2.8006	2.7633	2.3339
15	.112	.1494	.1867	2.5789	2.5206	2.6139	2.3152
16	.2054	.1867	.1905	2.4691	2.5766	2.5579	2.2405
17	.1867	.1867	.1905	2.4086	2.2965	2.2592	2.1472
18	.2241	.2241	.1905	2.0165	1.7558		1.7737
19	.2427	.2054	.2241	.1494	.168		.1867
20	.2614	.2054	.1867	.1494	.1494		.2427
21	.1867	.1867	.1494	.1494	.1494		.2614
22	.1867		.1307	.1494	.1307		.2241
23	.168		.112	.112	.1132		.2054
24		.112		.112	.0934	.112	
Max	**1.1203**	**1.7551**	**1.7924**	**2.5789**	**2.8006**	**2.7633**	**2.5953**
Min	**.112**	**.112**	**.112**	**.112**	**.0934**	**.0934**	**.1867**
Avg	**.2801**	**.5949**	**.3691**	**.9131**	**.9002**	**1.0342**	**1.3082**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
MALKAPUR[041] BU 6190
Substation No/ Name :- 144012 / 33 /11 KV SARUD
Feeder No / Name : 207 / Sarud-Thergaon Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0187		.2987	.2987	.2987	
2		.0187		.2987	.2987	.2987	
3		.0187		.2987	.3361	.2987	
4		.0187		.2987	.3361	.3361	
5				.2987	.3734	.3361	
6		.0187		.5601	.5228	.3547	
7		.0187		.5975	.6348	.4481	
8		.0187		.7468	.6348	.6535	
9		.0187	.0191		.6348	.5975	.7468
10	.0191	.0187	.0191	.5788	.695	.4854	.5041
11	.8402	1.0269	1.0059	.0191	.0191	.0187	.0187
12	1.1203	1.1763	1.134	.0191	.0191	.0187	.0187
13	1.2323	1.3256	1.1888	.0191	.0191	.0187	.0187
14		1.3256	1.1888	.0191	.0191	.0187	.0187
15	1.1949	1.1763	1.1888	.0191	.0191	.0187	.0187
16	1.1763	1.307	1.1706	.0191	.0187	.0187	.0187
17	1.1203	1.1763	1.0974	.0187	.0187	.0187	.0187
18	.9149	1.0456	.823	.0187	.0191		.0187
19	.0187	.0191	.0191	.0187	.0191		.0187
20	.0187	.0191	.0191	.0187	.0191		.0187
21	.0187	.0191	.0187	.0187	.0191		.0187
22	.0187		.0187	.0187	.0191		.0187
23	.0187		.0187	.0187	.0191		.0187
24		.0187		.0187	.0187	.0191	
Max	**1.2323**	**1.3256**	**1.1888**	**.7468**	**.695**	**.6535**	**.7468**
Min	**.0187**	**.0187**	**.0187**	**.0187**	**.0187**	**.0187**	**.0187**
Avg	**.5932**	**.4669**	**.5953**	**.1844**	**.2096**	**.2365**	**.0996**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
MALKAPUR[041] BU 6190
Substation No/ Name :- 144012 / 33 /11 KV SARUD
Feeder No / Name : 208 / 11 KV Haritkranti Bhadale **PURELY LIS FEEDERS**
LIS Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		.2054				
8		.2987			.2801	
9		.2987	.2743		.2801	
10	.2987	.2614	.2743	.3361	.2987	.2054
11		.2987	.2743	.2926	.2987	.2987
12	.2801	.2987	.2743	.2987	.2987	.2987
13	.2801	.2801	.2743	.2987	.2987	.2987
14		.2801	.2801	.2987	.2987	.2801
15	.2801	.2801	.2743	.2987	.2987	.2801
16	.2801	.2801	.2743	.2987	.2987	.2801
17	.2987	.2801	.2743	.2987	.2801	.2801
18	.2801	.2801	.2743	.2801		.2801
Max	**.2987**	**.2987**	**.2801**	**.3361**	**.2987**	**.2987**
Min	**.2801**	**.2054**	**.2743**	**.2801**	**.2801**	**.2054**
Avg	**.2854**	**.2785**	**.2749**	**.3001**	**.2931**	**.278**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
MALKAPUR[041] BU 6190
Substation No/ Name :- 144012 / 33 /11 KV SARUD
Feeder No / Name : 209 / Sarud-Nerle Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0373		.4108	.3734	.3734	
2		.0373		.3734	.4108	.4108	
3		.0373		.4108	.3734	.4108	
4		.0373		.4108	.4668	.2987	
5		.0373		.4108	.4668	.3361	
6		.0373		.7468	.5601	.3547	
7		.0373		.9335	.7468	.5228	
8		.0373		.9335	.8029	.6722	
9		.0373	.0381		.7842	.7842	.7468
10	.0373	.0373	.0381	.8589	.695	.5788	.5975
11	1.1576	1.3256	1.2803	.0381	.0191	.0373	.0373
12	1.3443	1.5123	1.4632	.0381	.0191	.0187	.0373
13	1.363	1.5684	1.5546	.0381	.0187	.0187	.0373
14		1.5684	1.5546	.0381	.0187	.0187	.0373
15	1.2696	1.5684	1.5546	.0381	.0191	.0187	.0373
16	1.251	1.4937	1.5384	.0381	.0191	.0187	.0373
17	1.1389	1.307	1.4661	.0373	.0187	.0187	.0373
18	.9709	1.1016	1.448	.0373	.0191		.0373
19	.0373	.0381	.0572	.0373	.0191		.0373
20	.0373	.0381	.0572	.0373	.0191		.0373
21	.0373	.0381	.0373	.0373	.0191		.0373
22	.0373		.0373	.0373	.0191		.0373
23	.0373		.0187	.0373	.0191		
24		.0373		.0187	.0373	.0191	
Max	**1.363**	**1.5684**	**1.5546**	**.9335**	**.8029**	**.7842**	**.7468**
Min	**.0373**	**.0373**	**.0187**	**.0187**	**.0187**	**.0187**	**.0373**
Avg	**.6707**	**.5441**	**.8096**	**.2608**	**.2485**	**.2728**	**.1280**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
MALKAPUR[041] BU 6190
Substation No/ Name :- 144088 / 33/11 KV Warul
Feeder No / Name : 201 / 11 Kv Warul-Amba GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17
HR	Load (MW)
1	.3021
2	.3018
3	.3018
4	.3048
5	.381
6	.4191
7	.4904
8	.5228
9	.5601
24	.3018
Max	**.5601**
Min	**.3018**
Avg	**.3886**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
MALKAPUR[041] BU 6190
Substation No/ Name :- 144088 / 33/11 KV Warul
Feeder No / Name : 202 / 11 Kv Warul -Yelur SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17
HR	Load (MW)
1	.4534
2	.4481
3	.4481
4	.4481
5	.4801
6	.4687
7	.4999
8	.6642
9	.6722
Max	**.6722**
Min	**.4481**
Avg	**.5092**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
MALKAPUR[041] BU 6190
Substation No/ Name :- 144088 / 33/11 KV Warul
Feeder No / Name : 401 / 33 Kv Kadavi Generation
Feeder KV- 33 / OUTGOING

DATE	22-DEC-17
HR	Load (MW)
1	1.0099
24	.9568
Max	1.0099
Min	.9568
Avg	.9834

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
MALKAPUR[041] BU 6190
Substation No/ Name :- 144109 / 33/11 KV Thawade
Feeder No / Name : 201 / Turukwadi Ag FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1658	.3018	.3353			
2	.1658	.3018	.3353			
3	.1658	.3018	.3353			
4	.1677	.3018	.3353			
5	.2012	.3018	.3353			
6	.2683	.3391	.3353			
7	.3018	.39	.4191			
8	.3401	.4862	.4973			
9	.4752	.4527	.6783			
10	.4588	.3353	.8886			
11			1.0852			
12				1.1568	.9054	.78
13			.8288	.7956	1.0852	1.1022
14			1.0774	.8886	1.153	1.153
15			1.0059	1.2378	1.1361	1.2039
16			.9614	1.1469	1.2378	1.2378
17			.9614	.9995	1.0852	1.1736
18			.779	.8002	.8478	.9503
Max	**.4752**	**.4862**	**1.0852**	**1.2378**	**1.2378**	**1.2378**
Min	**.1658**	**.3018**	**.3353**	**.7956**	**.8478**	**.78**
Avg	**.2711**	**.3512**	**.6585**	**1.0036**	**1.0644**	**1.0858**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
MALKAPUR[041] BU 6190
Substation No/ Name :- 144109 / 33/11 KV Thawade
Feeder No / Name : 202 / 11 KV Thawade - Udagiri Vg GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1227	.1214	.1578	.1928	.1907	.1629	.1402
2	.1227	.1214	.1578	.1928	.1907	.1629	.1402
3	.1227	.1214	.1578	.1928	.1907	.1646	.1402
4	.1227	.1214	.1578	.1928	.1907	.1629	.1402
5	.1227	.1402	.1578	.1949	.1907	.1612	.1387
6	.1463	.1791	.1753	.197	.197	.1612	.1612
7	.2033	.2378	.2378	.2378	.2378	.2328	.2507
8	.2507	.2149	.2896	.2865	.2865	.2835	.2715
9	.2303	.2774	.2686	.2865	.3189	.333	.2835
10	.2481	.2743	.2629	.2804	.3189	.2454	.2835
11	.2427	.2572	.298	.2835	.2947	.3258	.298
12	.2427	.2601	.3121	.2629	.2804	.2947	.2804
13		.2427	.298	.2804	.2947	.2947	.2629
14	.2374	.2279	.2804	.2572	.2774	.2743	.2454
15	.2374	.2427	.2774	.2401	.2774	.2601	.2454
16	.2515	.2572	.285	.3294	.208	.2774	.2279
17	.2683	.2915	.3018	.3391	.2883	.2601	.2947
18	.3185	.3429	.3258	.3429	.3391	.3814	.373
19	.3801	.3841	.4298	.4706	.4298	.4163	.4252
20	.362	.3547	.4024	.439	.4119	.3982	.4298
21	.2865	.3547	.3475	.3475	.362	.3511	.394
22	.1772	.2218	.2743	.2743	.2686	.2686	.2865
23	.1402	.181	.2103	.2103	.2103	.1949	.1791
24	.1227	.1214	.1578	.1907	.1907	.1791	.1402
Max	**.3801**	**.3841**	**.4298**	**.4706**	**.4298**	**.4163**	**.4298**
Min	**.1227**	**.1214**	**.1578**	**.1907**	**.1907**	**.1612**	**.1387**
Avg	**.2156**	**.2312**	**.2593**	**.2718**	**.2686**	**.2603**	**.2514**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
MALKAPUR[041] BU 6190
Substation No/ Name :- 144109 / 33/11 KV Thawade
Feeder No / Name : 203 / 11 KV Kandavan Village GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1254	.1254	.0914	.128	.128	.128	.1267
2	.1254	.1254	.0914	.128	.128	.1267	.1267
3	.1254	.1254	.0914	.128	.128	.128	.1267
4	.1254	.1254	.0914	.128	.128	.128	.1267
5	.1254	.1433	.1463	.1463	.1463	.1646	.1612
6	.2012	.2149	.2561	.2012	.2012	.2534	.2534
7	.3658	.4207	.3142	.3881	.3881	.3658	.3511
8	.3801	.3189	.3475	.3982	.3841	.3982	.3801
9	.3224	.3086	.3224	.394	.2686	.3721	.3856
10	.2743	.2401	.298	.3506	.2658	.3294	.333
11	.2374	.2713	.2401	.3467	.2543	.2401	.3258
12	.2374	.2683	.1928	.2804	.2601	.2279	.2454
13	.1989		.2279	.2743	.2035	.1753	.2601
14	.2294	.2721	.2126	.197	.1578	.1928	.2401
15	.2267	.2785	.2254	.2229	.1595	.2254	.2204
16	.2241	.2984	.3222	.2515	.2155	.2229	.2347
17	.2683	.3391	.3222	.2984	.2683	.2572	.3086
18	.3467	.3856	.3467	.3506	.3086	.3721	.3856
19	.4344	.462	.5304	.5228	.5304	.5487	.4755
20	.462	.462	.4805	.5041	.4854	.499	.499
21	.3696	.4108	.4108	.3921	.3921	.3734	.462
22	.2743	.2801	.2801	.2801	.2427	.2801	.2772
23	.1629	.1848	.1991	.1991	.1663	.1663	.1663
24	.1254	.1254	.0914	.128	.128	.1448	.1267
Max	**.462**	**.462**	**.5304**	**.5228**	**.5304**	**.5487**	**.499**
Min	**.1254**	**.1254**	**.0914**	**.128**	**.128**	**.1267**	**.1267**
Avg	**.2487**	**.2690**	**.2555**	**.2766**	**.2474**	**.2633**	**.2749**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PANHALA[035] BU 6131
Substation No/ Name :- 144004 / PANHALA SUB-STATION
Feeder No / Name : 201 / Sh-R- Panhala Hill Station SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0857	.0953	.0857	.0953	.0953	.0857
2	.0953	.0857	.0953	.0857	.0953	.0953	.0857
3	.0953	.0857	.0953	.0857	.0953	.0953	.0857
4	.0953	.0857	.0953	.1029	.0953	.0953	.0857
5	.1143	.1029	.0953	.12	.1143	.0953	.1029
6	.1524	.12	.1524	.1372	.1524	.1524	.12
7	.1905	.1715	.1905	.1886	.1905	.1715	.1715
8	.1905	.2058	.2477	.2058	.2286	.2286	.2058
9	.1524	.2096	.2477	.2058	.1905	.2096	.1886
10	.1543	.1715	.1715	.2286	.1905	.1715	.1905
11	.1543	.1524	.1543	.1905	.1715	.1543	.1905
12	.1372	.1524	.1372	.1524	.1715	.1372	.1905
13	.1543	.1524	.12	.1143	.1905	.1715	.1524
14	.1372	.1524	.1372	.1334	.1524	.1372	.1524
15	.1543	.1524	.12	.1524	.1715	.1543	.1524
16	.1372	.1143	.1715	.1524	.2096	.1372	.1524
17	.1372	.1715	.1715	.1715	.1905	.1372	.1524
18	.1543	.1905	.1886	.1715	.2096	.1715	.1524
19	.2058	.2858	.2401	.2667	.2667	.2229	.2477
20	.2058	.2858	.2401	.2667	.2477	.2058	.2286
21	.1886	.2667	.2058	.2286	.2477	.2058	.2286
22	.1715	.2477	.2058	.2286	.1905	.1886	.2096
23	.1543	.1524	.1715	.1524	.1524	.1543	.1524
24	.1143		.1143	.12	.1143	.1524	.1029
Max	**.2058**	**.2858**	**.2477**	**.2667**	**.2667**	**.2286**	**.2477**
Min	**.0953**	**.0857**	**.0953**	**.0857**	**.0953**	**.0953**	**.0857**
Avg	**.1476**	**.1653**	**.1610**	**.1645**	**.1723**	**.1558**	**.1578**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PANHALA[035] BU 6131
Substation No/ Name :- 144004 / PANHALA SUB-STATION
Feeder No / Name : 202 / SH-R- 11 KV WAGHAWE GAOTHAN FEEDER
GAVTHAN Feeder KV- 11 /
OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0857	.0572	.0857	.0762	.0762	.0686
2	.0762	.0857	.0572	.0857	.0762	.0762	.0686
3	.0762	.0857	.0572	.0857	.0762	.0762	.0686
4	.0762	.1372	.0572	.1372	.0762	.0762	.0857
5	.1905	.1886	.0572	.1886	.0953	.0762	.1029
6	.2477	.2572	.1715	.2572	.2286	.2858	.1372
7	.3048	.2572	.2477	.2915	.2667	.3239	.1543
8	.3239	.2743	.2667	.2572	.2858	.3239	.1886
9	.2667	.2477	.2477	.2229	.2477	.3048	.1886
10	.2058	.2858	.1886	.2096	.2667	.2401	.2667
11	.2401	.2858	.2058	.2096	.2667	.2229	.2286
12	.2572	.2477	.1886	.1905	.2667	.2058	.2286
13	.2058	.2858	.1715	.2096	.2667	.2058	.1905
14	.2401	.2858	.1886	.1715	.2667	.2058	.2096
15	.2401	.0191	.1715	.1524	.2477	.2229	.2096
16	.2058	.1905	.1886	.1524	.2286	.2058	.2286
17	.2229	.1905	.1715	.1524	.2096	.2058	.2477
18	.2572	.2667	.2572	.1905	.2477	.2401	.2477
19	.3258	.3048	.3086	.2667	.3429	.2572	.381
20	.3086	.2858	.2743	.2858	.362	.2229	.362
21	.2572	.2667	.2743	.2286	.3429	.2229	.3239
22	.1715	.1524	.2401	.1715	.2096	.1372	.2286
23	.12	.1143	.1372	.1143	.1524	.0857	.1524
24	.0762	.1029	.0572	.12	.0762	.1143	.0686
Max	**.3258**	**.3048**	**.3086**	**.2915**	**.362**	**.3239**	**.381**
Min	**.0762**	**.0191**	**.0572**	**.0857**	**.0762**	**.0762**	**.0686**
Avg	**.2072**	**.2043**	**.1768**	**.1849**	**.2159**	**.1923**	**.1932**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PANHALA[035] BU 6131
Substation No/ Name :- 144004 / PANHALA SUB-STATION
Feeder No / Name : 203 / 11 KV NAVALI VG GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.1715	.2096	.1886	.2096	.2096	.1886
2	.2286	.1715	.2096	.1886	.2096	.2096	.1886
3	.2286	.1715	.2096	.1886	.2096	.2096	.1886
4	.2286	.2229	.2096	.2572	.2096	.2096	.2401
5	.3429	.3086	.2096	.3258	.2286	.3429	.3086
6	.4572	.463	.3429	.4115	.4191	.4191	.3601
7	.5716	.5658	.5525	.5487	.6097	.6097	.5144
8	.6097	.5144	.5906	.5487	.6478	.6097	.4801
9	.5525	.5716	.5716	.5144	.6859	.5525	.5144
10	.4973	.5716	.4954	.5335	.5906	.4801	.5716
11	.3429	.4763	.5144	.381	.5525	.4287	.4572
12	.4973	.5525	.4115	.2096	.4763	.4458	.4572
13	.463	.4382	.3429	.3048	.381	.3772	.5716
14	.4287	.381	.4458	.3048	.4001	.3772	.5335
15	.3429	.4382	.3772	.3048	.4763	.463	.5335
16	.4287	.5525	.4801	.381	.5335	.5144	.5716
17	.4801	.6097	.5144	.4954	.4954	.583	.5716
18	.6516	.6478	.5658	.5716	.6478	.6516	.6478
19	.8059	1.0288	.8573	.8764	.9145	.823	.8764
20	.7716	.8573	.7888	.8383	.8573	.7545	.8383
21	.6516	.724	.6173	.6478	.7621	.6173	.7621
22	.4287	.5525	.5144	.5335	.5335	.4115	.5335
23	.2572	.381	.2572	.3048	.3429	.2401	.3429
24	.2286	.1886	.2096	.2058	.2096	.2096	.1886
Max	**.8059**	**1.0288**	**.8573**	**.8764**	**.9145**	**.823**	**.8764**
Min	**.2286**	**.1715**	**.2096**	**.1886**	**.2096**	**.2096**	**.1886**
Avg	**.4469**	**.4817**	**.4374**	**.4194**	**.4835**	**.4479**	**.4767**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PANHALA[035] BU 6131
Substation No/ Name :- 144004 / PANHALA SUB-STATION
Feeder No / Name : 204 / 11 KV MITHARWADI GAVTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0686	.0953	.0857	.0953	.0953	.0686
2	.0572	.0686	.0953	.0476	.0953	.0953	.0686
3	.0572	.0686	.0953	.0857	.0953	.0953	.0686
4	.0572	.0476	.0953	.1029	.0953	.0953	.0857
5	.1143	.1029	.0953	.12	.1143	.0953	.1029
6	.1524	.1372	.1524	.1372	.1715	.1524	.1372
7	.1905	.1715	.1905	.1715	.2096	.2096	.1886
8	.2286	.1886	.2096	.1886	.1905	.2096	.1886
9	.2286	.1524	.2667	.1886	.1715	.2286	.1715
10	.2058	.1715	.1715	.1334	.1905	.1715	.1905
11	.1543	.2096	.1715	.1715	.1905	.1715	.1905
12	.1372	.1715	.1715	.1143	.1905	.12	.1905
13	.1372	.2096	.1715	.1143	.1524	.12	.1524
14	.1715	.2286	.2058	.1334	.1524		.1715
15	.1715	.1905	.2229	.1524	.1524	.1372	.1715
16	.1886	.1905	.2229	.1715	.1715	.1372	.1715
17	.1886		.2229	.1905	.2096		.1715
18	.1886	.2286	.2058	.1715	.2477	.2572	.2667
19	.2058	.3239	.3258	.2858	.3048	.2572	.3239
20	.2572	.3048	.3086	.2667	.3048	.2572	.3239
21	.2229	.2477	.2401	.2286	.2667	.2058	.2286
22	.1543	.1524	.1886	.1905	.1905	.1543	.1905
23	.1029	.1334	.12	.1334	.1334	.1029	.1524
24	.0953	.0857	.1143	.1029	.0953	.1143	.0857
Max	**.2572**	**.3239**	**.3258**	**.2858**	**.3048**	**.2572**	**.3239**
Min	**.0572**	**.0476**	**.0953**	**.0476**	**.0953**	**.0953**	**.0686**
Avg	**.1552**	**.1676**	**.1816**	**.1537**	**.1747**	**.1583**	**.1692**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PANHALA[035] BU 6131
Substation No/ Name :- 144004 / PANHALA SUB-STATION
Feeder No / Name : 205 / 11 KV INJOLE VG GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.12	.1143	.1029	.1143	.1143	.0857
2	.1334	.12	.1143	.1029	.1143	.1143	.0857
3	.1334	.12	.1143	.1029	.1143	.1143	.0857
4	.1334	.1543	.1143	.12	.1143	.1143	.1029
5	.1905	.1715	.1143	.1372	.1334	.1143	.1372
6	.2286	.1886	.1715	.1715	.2096	.2096	.1715
7	.3048	.2401	.2477	.2401	.3048	.3048	.2229
8	.3429	.2572	.3048	.2572	.3239	.3239	.2743
9	.2858	.2477	.2667	.2229	.2667	.3048	.2401
10	.2572	.2667	.2572	.2858	.2858	.2572	.2286
11	.2229	.2286	.2229	.2667	.2858	.2401	.2286
12	.2058		.2058	.2286	.2477	.2229	.2286
13	.1886		.2401	.1715	.2286	.2229	.1905
14	.1886	.2667	.2058	.1715	.2096	.2058	.1524
15	.1715	.2286	.1886	.1715	.2096	.2058	.1524
16	.2229	.2667	.2058	.1905	.2477	.2058	.1905
17	.1886	.2477	.2229	.2096	.2286	.2058	.2286
18	.2401	.2667	.2743	.2477	.2477	.2401	.2477
19	.3086	.381	.3429	.381	.3429	.3258	.3239
20	.3086	.362	.3429	.3429	.362	.2915	.2858
21	.2572	.3239	.2743	.2667	.3239	.2743	.2858
22	.1715	.2096	.2229	.2096	.2286	.1886	.2286
23	.1372	.1715	.1372	.1524	.1905	.1372	.1524
24	.1524	.1372	.1334	.12	.1143	.1524	.1029
Max	**.3429**	**.381**	**.3429**	**.381**	**.362**	**.3258**	**.3239**
Min	**.1334**	**.12**	**.1143**	**.1029**	**.1143**	**.1143**	**.0857**
Avg	**.2128**	**.2262**	**.2100**	**.2031**	**.2270**	**.2121**	**.1931**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PANHALA[035] BU 6131
Substation No/ Name :- 144004 / PANHALA SUB-STATION
Feeder No / Name : 206 / 11kv Broadcast Express feeder Feeder KV- 11 / OUTGOING
NON SHEDDABLE EXPRESS HV FEEDERS (NON-CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0343	.0381	.0343	.0381	.0381	.0343
2	.0381	.0343	.0381	.0343	.0381	.0381	.0343
3	.0381	.0343	.0381	.0343	.0381	.0381	.0343
4	.0381	.0343	.0381	.0343	.0381	.0381	.0343
5	.0381	.0343	.0381	.0343	.0381	.0381	.0343
6	.0381	.0343	.0381	.0343	.0381	.0381	.0343
7	.0381	.0343	.0381	.0343	.0381	.0381	.0343
8	.0381	.0343	.0381	.0343	.0381	.0381	.0343
9	.0381	.0381	.0381	.0343	.0381	.0381	.0343
10	.0343	.0381		.0381	.0381	.0343	.0381
11	.0343	.0381		.0381	.0381	.0343	.0381
12	.0343	.0381		.0381	.0572	.0343	.0381
13	.0343	.0381		.0381	.0381	.0343	.0381
14	.0343		.0343	.0381	.0381	.0343	.0381
15	.0343		.0343	.0381	.0381	.0343	.0381
16	.0343		.0343	.0381	.0381	.0343	.0381
17	.0343	.2286	.0343	.0381	.0381	.0343	.0381
18	.0343		.0343	.0381	.0381	.0343	.0381
19	.0343	.0381	.0343	.0381	.0381	.0343	.0381
20	.0343	.0381	.0343	.0381	.0572	.0343	.0381
21	.0343	.0381	.0343	.0381	.0572	.0343	.0381
22	.0343	.0381	.0343	.0381	.0381	.0343	.0381
23	.0343	.0381	.0343	.0381	.0381	.0343	.0381
24	.0381	.0343	.0381	.0343	.0381	.0572	.0343
Max	**.0381**	**.2286**	**.0381**	**.0381**	**.0572**	**.0572**	**.0381**
Min	**.0343**	**.0343**	**.0343**	**.0343**	**.0381**	**.0343**	**.0343**
Avg	**.0359**	**.0459**	**.0362**	**.0365**	**.0405**	**.0367**	**.0365**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PANHALA[035] BU 6131
Substation No/ Name :- 144004 / PANHALA SUB-STATION
Feeder No / Name : 207 / 11Kv Mitharwadi Ag. SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.12	.1524	.1372	.4191	.3658	.3086
2	.1334	.12	.1524	.1372	.4191	.3658	.3086
3	.1334	.12	.1524	.1372	.4191	.3658	.3086
4	.1334	.1372	.1524	.1372	.4191	.3658	.3429
5	.1334	.1543	.1524	.1372	.4572	.3658	.3772
6	.1524	.1715	.1905	.1543	.7621	.5487	.4115
7	.1905	.1886	.2286	.2058	.9907	.6706	.4115
8	.1905	.2229	.2667	.2401	1.0669	.9755	.823
9	.2286		.2667	.2401	.9755	.9145	.6859
10	.1715	.3048	.2401	.1524	.9145	.823	
11	1.166	.9145	1.2003		.2286	.1715	1.1431
12	1.5432	1.2193	1.5089		.2286	.2058	1.3717
13	1.8861	1.5242	1.6975		.2096	.2058	1.3717
14	1.7147	1.5851	1.7147		.1905		1.448
15	1.7147	1.4022	1.7147		.2286	.1543	1.448
16	1.8861	1.4632	1.6804	.2286	.2286	.1543	1.4289
17	1.5089	1.2193	1.5089	.381	.2667		1.4098
18	1.0631	1.0059	1.166	.3048	.2667	.2401	1.1431
19	.2229	.2667	.2058	.3048	.2667	.2401	.2286
20	.2058	.2286	.2058	.2667	.2667	.2401	.2286
21	.1715	.2286	.2058	.2286	.2286	.2058	.2286
22	.1543	.1905	.1886	.2286	.1905	.1715	.1905
23	.1372	.1715	.1372	.1905	.1715	.1372	.1524
24	.1524	.12	.1524	.1372	.1715	.1524	.1372
Max	**1.8861**	**1.5851**	**1.7147**	**.381**	**1.0669**	**.9755**	**1.448**
Min	**.1334**	**.12**	**.1372**	**.1372**	**.1715**	**.1372**	**.1372**
Avg	**.6303**	**.5686**	**.6351**	**.2079**	**.4161**	**.3655**	**.6917**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PANHALA[035] BU 6131
Substation No/ Name :- 144004 / PANHALA SUB-STATION
Feeder No / Name : 208 / Waghave Ag. SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.0171	.0191	.0171	.4572	.2286	.2572
2	.2096	.0171	.0191	.0171	.4572	.2286	.3086
3	.2096	.0171	.0191	.0171	.4572	.2286	.3429
4	.2096	.0171	.0191	.0171	.4572	.2286	.4287
5	.5335	.0171	.0191	.0171	.4572	.3048	.5144
6	.743	.0171	.0191	.0171	.9145	.5639	.6173
7	.9907	.0171	.0191	.0171	1.2574	.823	.8059
8	1.0669	.0171	.0191	.0171	1.4861	1.0517	1.0288
9	1.2574	.0191	.0191	.0171	1.0974	1.0212	1.0288
10	1.1317	.0191	.0171	.0191	.9145	.9431	1.0288
11	1.3546	1.2193	1.4918	.0191	.0191		.0191
12	1.3717	1.4632	1.7661	.0191	.0191		.0191
13	1.3546	1.4632	1.8176	.0191	.0191		.0191
14	1.5432	1.3717	1.6975	.0191	.0191	.0171	.0191
15	1.4403	1.4175	1.6632	.0191	.0191	.0171	.0191
16	1.4403	1.4022	1.5432	.0191	.0191	.0171	.0191
17	1.2517	1.3108	1.4403	.0191	.0191	.0171	.0191
18	.9431	1.0974	1.1488	.0191	.0191	.0171	.0191
19	.0171	.0191	.0171	.0191	.0191	.0171	.0191
20	.0171	.0191	.0171	.0191	.0191	.0171	.0191
21	.0171	.0191	.0171	.0191	.0191	.0171	.0191
22	.0171	.0191	.0171	.0191	.0191	.0171	.0191
23	.0171	.0191	.0171	.0191	.0191	.0171	.0191
24	.0191	.0171	.0191	.0171	.0191	.0191	.0171
Max	**1.5432**	**1.4632**	**1.8176**	**.0191**	**1.4861**	**1.0517**	**1.0288**
Min	**.0171**	**.0171**	**.0171**	**.0171**	**.0191**	**.0171**	**.0171**
Avg	**.7236**	**.4597**	**.5359**	**.0183**	**.3426**	**.2768**	**.2761**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PANHALA[035] BU 6131
Substation No/ Name :- 144004 / PANHALA SUB-STATION
Feeder No / Name : 209 / 11KV INJOLE AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.3086	.1524	.2915	.0191	.0191	.0171
2	.0191	.3086	.1524	.3086	.0191	.0191	.0171
3	.0191	.3086	.1524	.3086	.0191	.0191	.0171
4	.0191	.3086	.1524	.3086	.0191	.0191	.0171
5	.0191	.3086	.1524	.3086	.0191	.0191	.0171
6	.0191	.3086	.2439	.3086	.0191	.0191	.0171
7	.0191	.3429	.2896	.3429	.0191	.0191	.0171
8	.0191	.3429	.381	.3772	.0191	.0191	.0171
9	.0191	.3048	.3658	.3601	.2477	.0191	.0171
10	.0171	.2896	.3429	.4572	.0191	.0171	.0191
11	.0171	.0191	.0171	.4191	.3963	.4287	
12	.0171		.0171	.4572	.4572	.5316	.4572
13	.0171		.0171	.5335	.4572	.5487	.6097
14	.0171	.0191	.0171	.4954	.4725	.5487	.6859
15	.0171	.0191	.0171	.4954	.4725	.5658	.6859
16	.0171	.0191	.0171	.5335	.4572	.583	.6478
17	.0171	.0191	.0171	.5716	.4572	.5487	.6478
18	.0171	.0191	.0171	.4954	.4115	.4973	.6097
19	.0171	.0191	.0171	.0191	.0191	.0171	.0191
20	.0171	.0191	.0171	.0191	.0191	.0171	.0191
21	.0171	.0191	.0171	.0191	.0191	.0171	.0191
22	.0171	.0191	.0171	.0191	.0191	.0171	.0191
23	.0171	.0191	.0171	.0191	.0191	.0171	.0191
24	.0191	.0171	.0191	.0171	.0191	.0191	.0171
Max	**.0191**	**.3429**	**.381**	**.5716**	**.4725**	**.583**	**.6859**
Min	**.0171**	**.0171**	**.0171**	**.0171**	**.0191**	**.0171**	**.0171**
Avg	**.0179**	**.1527**	**.1094**	**.3119**	**.1715**	**.1894**	**.2013**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PANHALA[035] BU 6131
Substation No/ Name :- 144013 / 33/11 KV DIGAWADE
Feeder No / Name : 201 / 11 KV DIGAVADE VG GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0514	.0566	.0724	.0566	.0514	.056
2	.0514	.0514	.0566	.0716	.0566	.0514	.056
3	.0514	.0514	.0566	.0709	.056	.0514	.056
4	.0514	.0686	.0754	.0724	.056	.0686	.0747
5	.12	.12	.1307	.0701	.1646	.0857	.112
6	.1715	.1715	.2195	.0716	.2195	.1029	.2218
7	.2058	.2058	.2507	.0701	.1991	.1372	.2481
8	.1886	.1886	.2126		.2149		.1928
9	.1715	.1715	.2303	.1886	.1595	.1886	.181
10	.1696	.1578	.1387	.2058	.1402	.1578	.1417
11	.1578	.1753	.1734	.1543	.124	.1448	
12	.1543	.1753	.1734	.1372	.1267	.124	.1417
13	.1372	.1753	.1949	.1543	.1612	.181	.1448
14	.12	.1457	.1267	.1543	.1578	.1417	.1991
15	.1417	.1227	.1417	.1715	.1448	.1595	.1463
16	.1715	.1753	.1578	.1372	.128	.1543	.1772
17	.1372	.1402	.1578	.1543	.12	.1715	.1417
18	.1543	.1791	.1886	.1715	.1372	.1753	.1715
19	.1886	.2054	.1949	.197	.1886	.1829	.1715
20	.1715	.1867	.1595	.1867	.1543	.168	.1372
21	.12	.1494	.124	.168	.1372	.168	.1029
22	.1029	.112	.1267	.0934	.1029	.0934	.1029
23	.0857	.0754	.1063	.0566	.0686	.0566	
24	.0514	.0514	.0566	.0724	.0566	.0514	.0566
Max	**.2058**	**.2058**	**.2507**	**.2058**	**.2195**	**.1886**	**.2481**
Min	**.0514**	**.0514**	**.0566**	**.0566**	**.056**	**.0514**	**.056**
Avg	**.1303**	**.1378**	**.1463**	**.1262**	**.1305**	**.1247**	**.1379**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PANHALA[035] BU 6131
Substation No/ Name :- 144013 / 33/11 KV DIGAWADE
Feeder No / Name : 202 / 11 KV ALAWE-KOTOLI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.0305	.0305	.0354	.0152	.5335	.6249
2	.9602	.0305	.0305	.0354	.0152	.5182	.6562
3	1.0288	.0305	.0305	.0354		.5335	.6562
4	1.0288	.0305	.0305	.0362	.0152	.5487	.6718
5	1.2346	.0305	.0305	.0358	.0305	.6249	.7432
6	1.2689	.0305	.0305	.0362	.0305	.7468	.8322
7	1.2689	.0305	.0305	.0362	.0305	1.0212	1.0395
8	2.0233	.0305	.0305	.0351	.0305		1.4586
9	2.0748	.061	.0305	.0305	.0305	1.326	1.4529
10	2.1209	.0709	.0358	.0305	.0362	1.3032	1.0498
11	1.9719	2.2148	2.3348	1.2803	.0362	.0351	.0362
12	2.4863	2.4356	2.8054	1.7071	.0351	.0362	.0354
13	2.5377	2.6755	2.9683	1.9052	.0362	.0354	.0354
14	2.6223	2.5766	2.8172	1.8138	.0362	.0362	.0366
15	2.6147	2.5869	2.8235	1.7528	.0362	.0354	.0354
16	2.5766	2.5337	2.4806		.0362	.0305	
17	1.9966	2.2969	2.371	1.7101	.0457	.0305	.0354
18	1.5699	2.0454	1.5074	1.2651	.0457	.0305	.0343
19	.0305	.0305	.0362	.0305	.0457	.0305	.0343
20	.0305	.0305	.0362	.0305	.0457	.0305	.0343
21	.0305	.0305	.0354	.0305	.0305	.0305	.0343
22	.0305	.0305	.0362	.0305	.0305	.0305	.0343
23	.0305	.0305	.0358	.0305	.0305	.0305	.0343
24	.0343	.0305	.0305	.0362	.0305	.0305	.0305
Max	**2.6223**	**2.6755**	**2.9683**	**1.9052**	**.0457**	**1.326**	**1.4586**
Min	**.0305**	**.0305**	**.0305**	**.0305**	**.0152**	**.0305**	**.0305**
Avg	**1.3469**	**.8302**	**.8595**	**.5204**	**.0328**	**.3308**	**.4190**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PANHALA[035] BU 6131
Substation No/ Name :- 144013 / 33/11 KV DIGAWADE
Feeder No / Name : 203 / 11 KV GHOTWADE VG GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0514	.0566	.0543	.0566	.0514	.0566
2	.0686	.0514	.0566	.0532	.0566	.0514	.0566
3	.0686	.0514	.0566	.0543	.0566	.0514	.0566
4	.0686	.0857	.0754	.0709	.0754	.0514	.0754
5	.1715	.1372	.112	.1267	.132	.0857	.1132
6	.2401	.2058	.1663	.1595	.1509	.1886	.1494
7	.2572	.2572	.2534	.1928	.2534	.2572	.2378
8	.2229	.1886	.2507	.181	.2507		.2303
9	.2572	.1715	.2686	.1886	.2658	.2229	.181
10	.2303	.197	.2534	.1543	.2149	.2534	.3761
11	.1772	.197	.1991	.1543	.1791	.181	.1629
12	.1612	.1949	.1578	.1715	.2149	.1417	.1629
13	.1772	.1417	.1463	.12	.1595	.1267	.1448
14	.124	.1949	.1629	.1029	.1629	.1448	.1448
15	.124	.1417	.1448	.1543	.1448	.1417	.1753
16	.1578	.1254	.181	.1543	.124	.12	
17	.1886	.1715	.2172	.1543	.1543	.1715	.1448
18	.3258	.2328	.2172	.1886	.2401		.2229
19	.3772	.3696	.3582	.3582	.3258	.3734	.2572
20	.3258	.3174	.3155	.2641	.2915	.3018	.3429
21	.2229	.2452	.2172	.2075	.2058	.2452	.3429
22	.12	.132	.1448	.1132	.1372	.1132	.1715
23	.0857	.0754	.0724	.0566	.0686	.0566	.1372
24	.0686	.0514	.0566	.0537	.0566	.0514	.0566
Max	**.3772**	**.3696**	**.3582**	**.3582**	**.3258**	**.3734**	**.3761**
Min	**.0686**	**.0514**	**.0566**	**.0532**	**.0566**	**.0514**	**.0566**
Avg	**.1787**	**.1662**	**.1725**	**.1454**	**.1658**	**.1537**	**.1739**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PANHALA[035] BU 6131
Substation No/ Name :- 144013 / 33/11 KV DIGAWADE
Feeder No / Name : 204 / 11 kv Digavade Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6401	.0305	.0305	.032	.0152	.1981	.1372
2	.2401	.0305	.0305	.0332	.0152	.1981	.1219
3	.2743	.0305	.0305	.0335	.0152	.2134	.1219
4	.2743	.0305	.0305	.0312	.0152	.2134	.1219
5	.3086	.0305	.0305	.0324	.0152	.2439	.1372
6	.2591	.0305	.0305	.032	.0305	.2896	.1677
7	.3222	.0305	.0305	.0316	.0305	.381	.2949
8	.4268	.0305	.0305	.0324	.0305		.5281
9	.5335	.0305	.0305	.0305	.0305	.4877	.6697
10	.779	.032	.0312	.0305	.032	1.1363	.4001
11	.9724	.8592	1.1065	.9755	.0312	.0324	.0312
12	.9762	1.2742	1.5089	1.1279	.0309	.032	.0312
13	1.2574	1.3603	1.4575	1.1888	.0332	.0312	.0316
14	1.2323	1.3123	1.3599	1.3413	.0309	.0309	.032
15	1.2163	1.3245	1.2431	1.0364	.0312	.208	.0312
16	1.073	1.291	1.1873	.9755	.0309	.0305	.032
17	.8688	1.0437	1.073	.9014	.0305		.032
18	.6859	.8322	.9054	.7116	.0305	.0305	.0305
19	.0305	.0305	.0335	.0305	.0305	.0305	.0305
20	.0305	.0305	.0335	.0305	.0305	.0305	
21	.0305	.0305	.0343	.0305	.0305	.0305	.0343
22	.0305	.0305	.0324	.0305	.0305	.0305	.0305
23	.0305	.0305	.032	.0305	.0305	.0305	.0305
24	.0305	.0305	.0305	.0335	.0152	.0305	.0305
Max	**1.2574**	**1.3603**	**1.5089**	**1.3413**	**.0332**	**1.1363**	**.6697**
Min	**.0305**	**.0305**	**.0305**	**.0305**	**.0152**	**.0305**	**.0305**
Avg	**.5218**	**.4078**	**.4310**	**.3652**	**.0270**	**.1791**	**.1352**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PANHALA[035] BU 6131
Substation No/ Name :- 144013 / 33/11 KV DIGAWADE
Feeder No / Name : 205 / 11 KV ALAVE-KOTOLI VG GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1029	.0754	.0709	.0943	.0857	.0754
2	.12	.1029	.0754	.0709	.0754	.0857	.0754
3	.12	.1029	.0754	.0716	.0754	.0857	.0754
4	.1372	.1543	.0934	.0886	.1132	.1372	.1132
5	.2572	.2572	.168	.181	.2987	.2058	.2054
6	.3429	.4287	.4251	.2658	.4251	.2743	.3696
7	.3772	.4115	.5014	.4344	.4163	.4801	.4525
8	.5144	.4287	.3761	.3761	.4656		.4298
9	.4287	.3944	.4075	.4115	.443	.4287	.4525
10	.3856	.3944	.3506	.4115	.3898	.333	.443
11	.3681	.4252	.4075	.3601	.3506	.3898	.4031
12	.3366	.3761	.3506	.3258	.3801	.333	.3982
13	.2804	.3801	.3681	.2572	.3681	.4163	.3544
14	.3189	.2915	.3721	.3086	.3189	.3258	.3077
15	.3366	.3086	.3429	.2743	.3506	.362	.3086
16	.3086	.3224	.3155	.3258	.3258	.3429	.2401
17	.3258	.3601	.3801	.3258	.3429	.3086	.3429
18	.4115	.394	.3582	.3258	.3601	.4031	.4287
19	.4973	.5041	.4525	.4938	.4801	.5601	.463
20	.4287	.5041	.439	.4854	.4287	.4854	.3772
21	.3601	.3921	.3544	.3734	.3601	.415	.3429
22	.2572	.2641	.2715	.2452	.2572	.2829	.2572
23	.1543	.132	.1417	.1132	.12	.1132	.1715
24	.12	.1029	.1132	.1097	.0943	.0857	.0943
Max	**.5144**	**.5041**	**.5014**	**.4938**	**.4801**	**.5601**	**.463**
Min	**.12**	**.1029**	**.0754**	**.0709**	**.0754**	**.0857**	**.0754**
Avg	**.3045**	**.3140**	**.3007**	**.2794**	**.3056**	**.3017**	**.2993**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PANHALA[035] BU 6131
Substation No/ Name :- 144013 / 33/11 KV DIGAWADE
Feeder No / Name : 206 / 11 KV GHOTWADE AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	1.0924	.724	.8417		
2	.6001	1.0745	.7087	.8775		
3	.6173	1.0745	.7421	.8775		
4	.6344	1.2536	.8688	.8596		
5	.6516	1.3611	.9745	.9134		
6	.6859	1.4864	1.7737	.9492		
7	1.0631	1.9521	1.8073	1.3394		
8		2.1132	1.8823	1.5927		
9	1.406	2.2207	1.9376	1.9004		
10	1.576	2.1439	1.749	2.0774		
11				1.9313	2.8778	2.19
12				2.1491		2.6642
13				2.3491	3.3131	2.8704
14				2.6406	2.9767	3.1312
15				2.6578	2.5158	2.692
16				2.5206	2.4451	2.4863
17				1.989	2.2857	2.1434
18				1.7147	2.0553	1.8861
Max	**1.576**	**2.2207**	**1.9376**	**2.6578**	**3.3131**	**3.1312**
Min	**.6001**	**1.0745**	**.7087**	**.8417**	**2.0553**	**1.8861**
Avg	**.8705**	**1.5772**	**1.3168**	**1.6767**	**2.6385**	**2.5080**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PARITE[038] BU 6165
Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI
Feeder No / Name : 201 / 11 kv M.Shiroli sheti fdr SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4382	.4954	.0381	.0381	.0381	.0381
2	.381	.4763	.4954	.0381	.0381	.0381	.0381
3	.381	.4763	.4954	.0381	.0381	.0381	.0381
4	.381	.5144	.5335	.0381	.0381	.0381	.0381
5	.5335	.5525	.6668	.0381	.0381	.0381	.0381
6	.6668	.6859	.7621	.0381	.0381	.0381	.0381
7	.8002	.8954	.9145	.0381	.0381	.0381	.0381
8	1.1431	.9907	1.105	.0381	.0381	.0381	.0381
9	1.2003	1.1622	1.0669	.0381	.0381	.0381	.0381
10	1.0479	.9526	.9526	.0381	.0381	.0381	.0381
11	.0381	.0381	.0381	1.5051	1.5242	1.5623	1.8671
12	.0381	.0381	.0381	1.9243	1.9243	1.7337	1.9433
13	.0381			2.0386	2.0957	1.829	2.0195
14	.0381		.0381	1.9624	1.9052	1.9052	1.9052
15	.0381		.0381	1.7528	1.9052	1.6385	1.8671
16	.0381	.0381	.0381	1.5242	1.7528	1.7528	1.7147
17	.0381	.0381	.0381		1.6004	1.5623	1.5813
18	.0381	.0381	.0381	1.1622	1.5242	1.3336	1.2193
19	.0381	.0381	.0381	.0381	.0381	.0381	.0381
20	.0381	.0381	.0381	.0381	.0381	.0381	.0381
21	.0381	.0381	.0381	.0381	.0381	.0381	.0381
22	.0381	.0381	.0381	.0381	.0381	.0381	.0381
23	.0381	.0381	.0381	.0381	.0381	.0381	.0381
24	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Max	**1.2003**	**1.1622**	**1.105**	**2.0386**	**2.0957**	**1.9052**	**2.0195**
Min	**.0381**	**.0381**	**.0381**	**.0381**	**.0381**	**.0381**	**.0381**
Avg	**.3136**	**.3602**	**.3471**	**.5426**	**.6184**	**.5803**	**.6136**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PARITE[038] BU 6165
Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI
Feeder No / Name : 202 / 11 kv Chande Sheti Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0381	.7621	1.1622	.9717	.8764
2	.0381	.0381	.0381	.7621	1.1431	.9717	.8764
3	.0381	.0381	.0381	.7621	1.1431	.9717	.8764
4	.0381	.0381	.0381	.7621	1.1431	.9717	.9145
5	.0381	.0381	.0381	.8002	1.1812	1.3336	1.105
6	.0381	.0381	.0381	1.2955	1.2384	1.3336	1.3336
7	.0381	.0381	.0381	1.5432	1.8861	1.5242	1.4861
8	.0381	.0381	.0381	1.7147	2.0386	1.7147	1.7718
9	.0381	.0381	.0381	1.9814	1.9052	1.5242	1.8099
10	.0381	.0381	.0381	1.7909	1.6956	1.5242	1.6766
11	2.1148	2.4006		.0381	.0381	.0381	.0381
12	2.7054	2.6101	2.3434	.0381	.0381	.0381	.0381
13	2.8578		2.7435	.0381	.0381	.0381	
14	2.8959	2.4768		.0381			
15	2.8769	2.4768	2.7816	.0381			
16	2.8578	2.4768	2.5911	.0381	1.7147		
17	2.5911	2.2862	2.3624	.0381	.0381	.0381	
18	2.2862	1.7337	2.3053	.0381	.0381	.0381	
19	.0381	.0381	.0381	.0381	.0381		
20	.0381	.0381	.0381	.0381	.0381	.0381	.0381
21	.0381	.0381	.0381	.0381	.0381	.0381	.0381
22	.0381	.0381	.0381	.0381	.0381	.0381	.0381
23	.0381	.0381	.0381	.0381	.0381	.0381	.0381
24	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Max	**2.8959**	**2.6101**	**2.7816**	**1.9814**	**2.0386**	**1.7147**	**1.8099**
Min	**.0381**	**.0381**	**.0381**	**.0381**	**.0381**	**.0381**	**.0381**
Avg	**.9081**	**.7422**	**.7153**	**.5295**	**.7577**	**.6611**	**.7643**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PARITE[038] BU 6165
Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI
Feeder No / Name : 203 / 11 Kv Kanchanwadi Sheti Feeder Feeder KV- 11 / OUTGOING SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6668	.362	.4954	.0381	.0381	.0381	.0381
2	.5716	.4191	.4954	.0381	.0381	.0381	.0381
3	.5716	.4191	.4954	.0381	.0381	.0381	.0381
4	.5716	.4763	.4954	.0381	.0381	.0381	.0381
5	.6097	.5335	.7621	.0381	.0381	.0381	.0381
6	.7621	.6097	.9526	.0381	.0381	.0381	.0381
7	.9145	.8573	1.086	.0381	.0381	.0381	.0381
8	1.105	1.1812	1.2384	.0381	.0381	.0381	.0381
9	1.2384	1.1622	1.0669	.0381	.0381	.0381	.0381
10	.9526	.6668	1.0479	.0381	.0381	.0381	.0381
11	.0381	.0381	.0381	1.1622		1.2955	1.7718
12	.0381	.0381	.0381	1.6766		1.6575	1.8099
13			.0381	1.8861	1.3336	1.9433	2.0005
14		.0381	.0381	1.8099	1.7147	1.848	1.9052
15	.0381	.0381	.0381	1.7528	1.7147	1.7909	1.8671
16	.0381		.0381	1.3527		1.6575	1.7528
17	.0381		.0381	1.3908	1.3336	1.5051	1.7528
18	.0381		.0381	.8954	1.3336	1.0288	1.448
19	.0381	.0191	.0381	.0381	.0381	.0381	.0381
20	.0381	.0381	.0381	.0381	.0381	.0381	.0381
21	.0381	.0381	.0381	.0381	.0381	.0381	.0381
22	.0381	.0381	.0381	.0381	.0381	.0381	.0381
23	.0381	.0381	.0381	.0381	.0381	.0381	.0381
24	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Max	**1.2384**	**1.1812**	**1.2384**	**1.8861**	**1.7147**	**1.9433**	**2.0005**
Min	**.0381**	**.0191**	**.0381**	**.0381**	**.0381**	**.0381**	**.0381**
Avg	**.3828**	**.3525**	**.3612**	**.5223**	**.3828**	**.5557**	**.6216**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PARITE[038] BU 6165
Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI
Feeder No / Name : 204 / 11 KV Arale AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3429	.2477	.1715	.2286
2				.2286	.1905	.1715	.2286
3				.2286	.1905	.0381	.2286
4				.2286	.1905	.1715	.2667
5				.2286	.1905	.2667	.3048
6				.3048	.2286	.381	.3429
7				.4001	.5144	.381	.381
8				.5144	.6859	.6287	.5906
9				.4763	.6478	.6478	.5525
10				.4763	.4954	.5144	.5716
11	.6668	.7621	.6478				
12	.8573	.8764	.8954				
13	.9145	.9335	.9335				
14	.9145	.8764	.8954				
15	.9145	.7621	.8192				
16	.8002	.7049	.8573				
17	.6668	.5335	.8002				
18	.4763	.381	.5906				
Max	**.9145**	**.9335**	**.9335**	**.5144**	**.6859**	**.6478**	**.5906**
Min	**.4763**	**.381**	**.5906**	**.2286**	**.1905**	**.0381**	**.2286**
Avg	**.7764**	**.7287**	**.8049**	**.3429**	**.3582**	**.3372**	**.3696**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PARITE[038] BU 6165
Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI
Feeder No / Name : 205 / 11 kv M. Shiroli Gaothan fdr Feeder KV- 11 / OUTGOING **GAOTHAN FEEDER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1524	.1715	.1715	.1524	.1524
2	.1715	.1715	.1524	.1715	.1715	.1524	.1524
3	.1715	.2286	.1524	.1715	.1715	.1524	.1524
4	.1715	.2667	.1524	.1715	.1905	.1524	.1524
5	.1905	.381	.1905	.2477	.2667	.1905	.1905
6	.3048	.4572	.3048	.362	.4001	.2667	.3048
7	.4191	.4382	.4382	.4572	.4382	.381	.4382
8	.381	.4001	.4191	.4191	.4001	.4572	.3429
9	.3048	.3429	.4382	.3429	.3239	.4572	.3239
10	.362	.3048		.2286	.2286	.3048	.2667
11	.3239	.3048	.2667	.2096	.2286	.2667	.2667
12	.3239	.1905	.2286	.1715	.2477	.1905	.2286
13	.2858	.2286	.2286	.2286	.2477	.1715	.2286
14	.1715	.2667	.1905	.1715	.2477	.1715	.2286
15	.2667	.2858	.1905	.1524	.2477	.2096	.2286
16	.2667	.2286	.1905	.1715	.1905	.2667	.2286
17	.2858	.3429	.2477		.3048	.2286	.2667
18	.3239	.4001	.3048	.2667	.3048	.3239	.3239
19	.4763	.4763	.4572	.4572	.4572	.4954	.4191
20	.4382	.4572	.4572	.4382	.4572	.4382	.4572
21	.3239	.3429	.4191	.4191	.4572	.362	.4572
22	.2667	.2096	.3048	.3048	.3048	.2858	.3429
23	.2096	.2096	.1905	.1715	.1905	.2286	.2667
24	.1715	.1715	.1524	.1715	.1715	.1524	.1715
Max	**.4763**	**.4763**	**.4572**	**.4572**	**.4572**	**.4954**	**.4572**
Min	**.1715**	**.1715**	**.1524**	**.1524**	**.1715**	**.1524**	**.1524**
Avg	**.2826**	**.3032**	**.2708**	**.2642**	**.2842**	**.2691**	**.2746**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PARITE[038] BU 6165
Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI
Feeder No / Name : 206 / 11 Kv Chande Gavthan Feeder Feeder KV- 11 / OUTGOING **GAOTHAN FEEDER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0762	.0762	.0953	.0953	.0762	.0762
2	.0953		.0762	.0953	.0953	.0762	.0762
3	.0953	.0762	.0762	.0953	.0953	.0762	.0762
4	.0953	.0953	.0953	.0953	.1143	.0762	
5	.0953	.1143	.1143	.1334	.1524	.1524	.1143
6	.1715	.1524	.1524	.1905	.2286	.1905	.1905
7	.2286	.1905	.1905	.2096	.1905	.1905	.2286
8	.2096	.1334	.1905	.1905	.1905		.1905
9	.1905	.1524	.1524	.1715	.1524	.2286	.1524
10	.1524	.1524	.1524	.1334	.1524	.1524	.1334
11	.1334	.1524	.1334	.1143	.1524	.1524	.1143
12	.1143	.1143	.1143	.1143	.1524	.1524	.1143
13	.1143	.1143	.1143	.0953	.1524	.1143	.2286
14	.1143	.1143	.0953	.1143	.1524		.2286
15	.1143	.1143	.0953	.1143	.1524		.1143
16	.1143	.1524	.0953	.1143	.1524	.1524	.1143
17	.1334	.1524	.1334	.1334	.1905	.1524	.1524
18	.1524	.1905	.1715	.1715	.1905	.1905	.1524
19	.2667	.2667	.2667	.2286	.2286		.2286
20	.1905	.2667	.2667	.1905	.2286	.2286	.2286
21	.1524	.1905	.2477	.1905	.2286	.1905	.2477
22	.1143	.1524	.1905	.1524	.1524	.1524	.1905
23	.0762		.1143	.0953	.0762	.1143	.1524
24	.0953	.0762		.0953	.0953	.0762	.0762
Max	**.2667**	**.2667**	**.2667**	**.2286**	**.2286**	**.2286**	**.2477**
Min	**.0762**	**.0762**	**.0762**	**.0953**	**.0762**	**.0762**	**.0762**
Avg	**.1381**	**.1455**	**.1441**	**.1389**	**.1572**	**.1448**	**.1557**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PARITE[038] BU 6165
Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI
Feeder No / Name : 207 / 11 Kv Kanchanwadi Gavthan GAOTHAN FEEDER
Feed Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1524	.1715	.1905	.1905	.1143	.1715
2	.1905	.1524	.1715	.1905	.1905	.1143	.1715
3	.1905	.1524	.1715	.1905	.1905	.1143	.1715
4	.1905	.2667	.1905	.1905	.3239	.2286	.1905
5	.2286	.4191	.2667	.2286	.4191	.2667	.2286
6	.3048	.4954	.381	.3429	.5525	.4572	.3429
7	.4191	.5716	.4954	.4572	.5335	.5335	.5335
8	.381	.5335	.4763	.4191	.5335	.5335	.4572
9	.381	.4954	.4572	.3429	.4954	.4191	.4191
10	.3429	.4191	.3429	.3429	.3429	.381	.3048
11	.3429	.381	.3048	.3239	.3429	.3429	.2667
12	.3048	.3429		.3048	.3429	.3048	.2286
13	.3048	.362	.2286	.3048	.3429	.3048	.2286
14	.3048	.3429	.2286	.3048	.3429	.3048	.2286
15	.3048	.3429	.2286	.3429	.3429	.3429	.2286
16	.3429	.381	.2286	.3048	.3429	.3429	.4191
17	.381	.4191	.2667	.3429	.4191	.381	.3048
18	.4572	.4954	.3429	.4191	.4191	.4191	.3048
19	.5906	.5716	.4572	.5335	.5335	.5525	.4191
20	.5716	.5716	.4572	.4763	.5335	.4763	.4572
21	.4191	.4382	.4191	.362	.5335	.4382	.4572
22	.2858	.3048	.3048	.2477	.3048	.3048	.381
23	.2286	.2286	.2286	.1905	.1905	.2286	.3048
24	.1905	.1524	.1715	.1905	.1905	.1143	.1905
Max	**.5906**	**.5716**	**.4954**	**.5335**	**.5525**	**.5525**	**.5335**
Min	**.1905**	**.1524**	**.1715**	**.1905**	**.1905**	**.1143**	**.1715**
Avg	**.3270**	**.3747**	**.3040**	**.3143**	**.3731**	**.3342**	**.3088**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PARITE[038] BU 6165
Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI
Feeder No / Name : 208 / 11 kv ARALE GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0572	.0572	.0572	.0381	.0572
2	.0381	.0572	.0572	.0572	.0572	.0381	.0572
3	.0381	.0572	.0572	.0572	.0572	.0381	.0572
4	.0381	.0762	.0572	.0572	.0762	.0381	.0572
5	.0572	.0953	.0762	.0572	.0953	.0572	.0762
6	.0953	.1143	.1143	.0762	.1334	.0953	.0953
7	.1143	.1334	.1143	.1143	.1143	.0953	.1524
8	.1143	.1334	.1143	.1143	.1143	.1334	.1334
9	.0953	.0953	.1143	.0953	.0762	.4572	.0953
10	.0762	.0953		.0953	.0762	.0762	.0953
11	.0762	.0762	.0953	.0572	.0762	.0762	.0762
12	.0572	.0762	.0953	.0762	.0762	.0953	.0572
13	.0572	.0762	.0953	.0572	.0762	.0572	.0572
14	.0762	.0572	.0762	.0572	.0572	.0572	.0572
15	.0572	.0572	.0762	.0572	.0572	.0572	.0572
16	.0762	.0762	.0762	.0762	.0572	.0572	.0572
17	.0762	.0762	.0762	.0762	.0953	.0762	.0762
18	.1143	.1334	.0953	.1334	.0953	.1143	.0953
19	.1715	.1524	.1334	.1524	.1524	.1524	.1334
20	.1524	.1524	.1334	.1715	.1524	.1334	.1334
21	.1143	.1334	.1143	.1334	.1524	.1334	.1334
22	.0953	.0953	.0953	.0953	.0953	.0953	.0953
23	.0572	.0762	.0762	.0762	.0381	.0762	.0762
24	.0572	.0572	.0572	.0572	.0572	.0381	.0572
Max	**.1715**	**.1524**	**.1334**	**.1715**	**.1524**	**.4572**	**.1524**
Min	**.0381**	**.0572**	**.0572**	**.0572**	**.0381**	**.0381**	**.0572**
Avg	**.0818**	**.0921**	**.0895**	**.0858**	**.0873**	**.0953**	**.0850**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PARITE[038] BU 6165
Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE
Feeder No / Name : 201 / 11 Kv Bachani Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5249	.583	.6036	.0549	.0514	.0549	.0343
2	.543	.583	.6224	.0549	.0514	.0566	.0343
3	.543	.583	.6219	.0549	.0514	.0549	.0343
4	.5487	.6516	.6401	.0566	.0686	.056	.0514
5	.583	.6516	.6401	.0549	.0686	.0549	.0514
6	.6173	.6859	.6219	.0549	.0857	.0566	.0514
7	.7373	.7202		.0549	.1029	.0377	.0514
8	.9231	.7202		.0569	.0857	.0549	.0514
9	.9242	1.0288	.8122	.0497	.0857	.0492	.0492
10	.8779	.9339	.779	.0492	.0914	.0497	.0655
11		.0164	.0492		1.6095	1.3763	1.3763
12		.0164	.0492		1.9387	1.6244	1.6385
13		.0166	.0492	1.4419	1.9136	1.6632	1.8004
14		.0166	.0492	1.5249	2.0182	1.6461	1.7318
15		.0497	.0328	1.4091	1.829	1.6461	1.5775
16	.0366	.0332	.0328	1.6078	1.7353	1.6461	1.5775
17	.0343	.0366	.0332	1.5947	1.4632	1.2346	1.5432
18	.0514	.0566	.0377	1.406	1.3169	1.0631	1.3032
19	.0514	.0377	.0566	.0857	.0366	.0514	.0572
20	.0514	.0377	.0549	.0857	.0373	.0514	.0381
21	.0514	.0366		.0686	.0366	.0514	.0381
22	.0514	.0377	.0566	.0686	.0377	.0514	.0381
23		.0366	.0549	.0514	.0377	.0514	.0381
24	.0572	.0514	.0377	.0549	.0514	.0566	.0514
Max	**.9242**	**1.0288**	**.8122**	**1.6078**	**2.0182**	**1.6632**	**1.8004**
Min	**.0343**	**.0164**	**.0328**	**.0492**	**.0366**	**.0377**	**.0343**
Avg	**.4004**	**.3175**	**.2826**	**.4519**	**.6169**	**.5308**	**.5535**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PARITE[038] BU 6165
Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE
Feeder No / Name : 202 / 11 Kv Nandgaon Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0343	.0754	.9877	1.0288	1.0562	.823
2	.0381	.0343	.0754	.9259	1.0288	1.094	.823
3	.0381	.0514	.0754	.9431	1.0288	1.0974	.823
4	.0381	.0686	.0732	1.0117	1.0288	1.134	.8916
5	.0381	.0686	.0754	1.0974	1.0288	1.2071	1.0288
6	.0381	.0686	.1097	1.2346	1.0631	1.2437	1.0631
7	.0381	.0857	.1097	1.3717	1.3717	1.4632	1.3032
8	.0381	.1029	.1132	1.7147	1.5089	1.8107	1.3717
9	.0366	.0857	.0983	1.6632	1.749	1.5729	1.4091
10	.0366	.0829	.0972	1.5261	1.8861	1.4419	1.278
11	1.829	2.1136	2.1795	.0857	.1463	.0328	.0819
12	2.2634	2.4863	2.4034	.0857	.1307	.0492	.0983
13	2.3577	2.556	2.3758	.0857	.1097		.1029
14	2.3954	2.4813	2.3266	.0983	.092		.0857
15	2.2862	2.4366	2.1792	.0857	.0914	.0514	.0686
16	2.4143	2.3537	2.1792	.0857	.0943	.0514	.0953
17	2.1776	2.5652	2.0851	.0857	.0886	.0686	.0953
18	1.8347	2.268		.1029	.0914	.1029	.0953
19	.0686	.0732	.0914	.0857	.0754	.1029	.0572
20	.0686	.0754	.0914	.0857	.0754	.1029	.0762
21	.0686	.0754	.0754	.0686	.0754	.1029	.0762
22	.0686	.0732	.0732	.0686	.0732	.0857	.0572
23	.0343	.0754	.0732	.0686	.0732	.0686	.0572
24	.0381	.0343	.0754	.0732	.0686	.0732	.0686
Max	**2.4143**	**2.5652**	**2.4034**	**1.7147**	**1.8861**	**1.8107**	**1.4091**
Min	**.0343**	**.0343**	**.0732**	**.0686**	**.0686**	**.0328**	**.0572**
Avg	**.7618**	**.8479**	**.7440**	**.5684**	**.5837**	**.6370**	**.4971**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PARITE[038] BU 6165
Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE
Feeder No / Name : 203 / 11 kv Ispurli Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1029	.2263	.9808	.7716	.9145	.7888
2	.1715	.1029	.132	.9511	.7716	.9511	.7888
3	.1905	.1029	.1267	.9694	.7716	.9877	.7545
4	.1905	.12	.128	1.0456		1.0242	.7545
5	.1905	.12	.128	1.0631	1.0288	1.0608	.7545
6	.1905	.1372	.1509	1.1888	1.0974	1.226	.7545
7	.2286	.1372	.2075	1.5089	1.3375	1.5089	1.3717
8	.2286	.1372	.2075	1.8671	1.7147	1.8861	1.5775
9	.1829	.1372	.1619	1.6518	1.8861	1.7652	1.6518
10	.1698	.1619		1.5223	1.8861	1.5424	1.5546
11	1.9753	1.8785	1.8785	.1619	.1509	.1296	.1619
12	2.3777	2.2024	2.2834	.1619	.1886	.1475	.1457
13	2.4669	2.0081		.1619	.1463	.1029	.1372
14	2.4897	2.4453	2.2996	.1619	.128	.1029	.12
15	2.0851	2.4291	2.7816	.1781	.1509	.0514	.1372
16	2.4897	2.332	2.2996	.1619	.1646	.1372	.1905
17	2.2291	2.5123	2.1376	.1715	.1829	.1886	.1905
18	2.0062	2.1948	1.9136	.1715	.1829	.1715	.1905
19	.1715	.1829	.2195	.1715	.2075	.1886	.2286
20	.1543		.0183	.1886	.1886	.1715	.1905
21	.1372	.1886	.2195	.1715	.1829	.1543	.1905
22	.1372	.1698	.2054	.1715	.1829	.1372	.1715
23	.1372	.1463	.1886	.1715	.1698	.1372	.1715
24	.1715	.1372	.1509	.1886	.1715	.1509	.1372
Max	**2.4897**	**2.5123**	**2.7816**	**1.8671**	**1.8861**	**1.8861**	**1.6518**
Min	**.1372**	**.1029**	**.0183**	**.1619**	**.128**	**.0514**	**.12**
Avg	**.8726**	**.8733**	**.8211**	**.6309**	**.5941**	**.6183**	**.5464**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PARITE[038] BU 6165
Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE
Feeder No / Name : 204 / 11 Kv Bachani Vg GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.1886	.2195	.2378	.2229	.2378	.2058
2	.2477	.1886	.1949	.2195	.2229	.2195	.2058
3	.2858	.2743	.2195	.2012	.2743	.0189	.2743
4	.362	.3772	.3584		.4115	.3395	.3772
5	.4887	.4801	.4554	.4024	.5144	.4554	.4801
6	.583	.5487	.6036	.5658	.6173	.6219	.583
7	.6687	.583	.7545	.6697	.6001		.6001
8	.6516	.6173	.6401	.6602	.5658	.6413	.6001
9	.5487	.4801	.5716	.4954	.5144	.4954	.5716
10	.4904	.4572	.4954	.4954	.4527	.4572	.4954
11		.4954	.4572	.381	.4207	.4191	.4191
12		.3429	.4191		.415	.381	.381
13		.3429	.4191	.381	.3772	.3258	.3429
14		.4191	.362	.3429	.3109	.3429	.3086
15		.381	.3429	.3429	.3584	.3944	.2743
16	.5487	.4191	.4572	.3048	.3658	.4115	.3048
17	.5316	.4191	.4954	.3429	.4755	.3772	.381
18	.583	.5487	.5281	.4801	.5853	.4458	.5068
19	.6859	.7922	.7545	.6516	.7167	.6859	.6697
20	.6859	.7356	.6401	.6173	.679	.6516	.6335
21	.5487	.6224	.5487	.5487	.5493	.5487	.5973
22	.463	.4403	.4755	.4287	.4527	.3429	.362
23	.3429	.3772	.3292	.3086	.3772	.2572	.3239
24	.2286	.2229	.2452	.2614	.2401	.2743	.2229
Max	**.6859**	**.7922**	**.7545**	**.6697**	**.7167**	**.6859**	**.6697**
Min	**.2286**	**.1886**	**.1949**	**.2012**	**.2229**	**.0189**	**.2058**
Avg	**.4828**	**.4481**	**.4578**	**.4245**	**.4467**	**.4063**	**.4217**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PARITE[038] BU 6165
Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE
Feeder No / Name : 205 / 11 kv ispurli Vg GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2058	.2263	.2075	.1886	.2195	.2058
2	.2667	.2058	.2012	.2012	.1715	.2012	.2058
3	.362	.2743	.2263	.2263	.2401	.2641	.2743
4	.4382	.4115	.362	.4572	.3429	.3772	.3772
5	.5335	.5487	.4527	.4938	.5144	.4938	.5487
6	.6335	.6173	.679	.5853	.6516	.811	.6859
7	.6859	.6173	.7682	.6219		.7733	.6859
8	.6335	.6173		.695	.6516	.7545	.6859
9	.0378	.5487	.6478	.6287	.5487	.6097	.6668
10	.6036	.6097	.6287	.5335	.5121	.5144	.5716
11	.5281	.5144	.5144	.4191	.4755	.4763	.5716
12		.5144	.5335	.4191	.4904	.5335	.5144
13		.4382	.4572	.3429	.3658	.3772	.3944
14	.3961	.362	.3429	.2667	.3292	.3601	.3086
15	.3658	.4001		.3429	.3658	.3429	.2915
16	.5281	.4954	.4001	.4191	.415	.4115	.4572
17	.5144	.5658	.4954	.3772	.4969	.5144	.4763
18	.5487	.6413	.6219	.583	.5853	.6001	.5658
19	.8402	.8962	.8676	.7888	.8779	.7545	.7964
20	.7545	.7714	.7682	.7545	.8048	.7545	.7059
21	.6173	.6257	.5658	.7202	.6767	.6173	.6697
22	.6173	.4938	.4715	.4458	.5658	.3772	.381
23	.2743	.3961	.3109	.2401	.4527	.2401	.3258
24	.2286	.2229	.2195	.2263	.2058	.2378	.2058
Max	**.8402**	**.8962**	**.8676**	**.7888**	**.8779**	**.811**	**.7964**
Min	**.0378**	**.2058**	**.2012**	**.2012**	**.1715**	**.2012**	**.2058**
Avg	**.4835**	**.4998**	**.4891**	**.4582**	**.4752**	**.4840**	**.4822**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PARITE[038] BU 6165
Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE
Feeder No / Name : 206 / 11 KV Renuka & Hanuman Express Feeder KV- 11 / OUTGOING **PURELY LIS FEEDERS**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.2477	.2229	.2561	.2572	.1646	.3601
4	.2667	.2229	.2561	.2572	.1698	.3601
5	.2667	.2229	.3109	.2572	.1646	.3601
6	.2667	.2229	.2743	.2572	.3841	.3601
7	.2667	.4458	.2561	.3601	.3961	.3601
8	.4887	.4458	.4904	.463	.4938	.3601
9	.5093	.4458	.4954	.463	.5144	.5144
10	.5093	.4954	.4954	.4938	.5144	.5144
11	.4938	.0191	.4954	.4938	.5144	.5144
12	.4938	.4954	.4954	.5093	.5144	.5144
13	.4938	.4954	.4954	.4938	.463	.463
14	.4938	.4954	.4954	.4938	.463	.463
15	.5093	.4954	.4954	.5093	.463	.4458
16	.5093	.4954	.4954	.4938	.4458	.4706
17	.463	.4904	.4954	.4938	.463	.4706
18	.463	.4904	.4755	.5041	.463	.4706
Max	**.5093**	**.4954**	**.4954**	**.5093**	**.5144**	**.5144**
Min	**.2477**	**.0191**	**.2561**	**.2572**	**.1646**	**.3601**
Avg	**.4214**	**.3876**	**.4236**	**.4250**	**.4120**	**.4376**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PARITE[038] BU 6165
Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE
Feeder No / Name : 207 / 11 KV Kawane Ag Feeder FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1372	.1463	.0183	.0171	.0171	.0171
2	.1905	.1372	.1463	.0183	.0171	.0189	.0171
3	.2286	.1372	.1463	.0187	.0171	.0189	.0171
4	.2286	.1372	.1646	.0189	.0171	.0189	.0171
5	.2477	.1715	.1829	.0183	.0171	.0183	.0171
6	.2477	.1715	.2195	.0189	.0171	.0189	.0171
7	.3086	.3429	.2743	.0183	.0171	.0189	.0171
8	.5792	.4115	.3658	.0189	.0171	.0183	.0171
9	.5658	.5144	.3441	.0164	.0171	.0166	.0166
10	.5093	.4424	.2785	.0166	.0189	.0164	.0166
11		.0164	.0164	.8785	.8596	.6962	.7373
12		.0166	.0166	1.0322	1.134	.9503	.9779
13		.0164	.0164	1.1437	1.0808	.9945	1.0631
14		.0166	.0162	1.0322	1.1389	.9945	1.0631
15		.0166	.0164	1.0111	1.1317	.9602	.9602
16	.0183	.0166	.0166	.9831	1.0751	.8916	.8573
17	.0171	.0183	.0166	.8573	.8048	.8059	.8573
18	.0171	.0189	.0183	.7888	.7167	.6859	.6697
19	.0171	.0189	.0183	.0171	.0177	.0171	.0191
20	.0171	.0183	.0189	.0171	.0181	.0171	.0191
21	.0171	.0189	.0189	.0171	.0183	.0171	.0191
22	.0171	.0189	.0189	.0114	.0183	.0171	.0191
23	.0171	.0189	.0183	.0171	.0189	.0171	.0191
24	.0191	.0171		.0183	.0171	.0183	.0171
Max	**.5792**	**.5144**	**.3658**	**1.1437**	**1.1389**	**.9945**	**1.0631**
Min	**.0171**	**.0164**	**.0162**	**.0114**	**.0171**	**.0164**	**.0166**
Avg	**.1818**	**.1188**	**.1085**	**.3336**	**.3426**	**.3027**	**.3112**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PARITE[038] BU 6165
Substation No/ Name :- 144078 / 33/11 KV RASHIWADE
Feeder No / Name : 201 / 11 KV BHOGAWATI GAVTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.2054	.2012		.1867	.2054	.2075
2	.2054	.2054	.2012	.1886	.1867	.2033	.2075
3	.2054	.2054	.2012	.1886	.1867	.2012	.2075
4	.2054	.2054	.2012	.1886	.1867	.2012	.2075
5	.2801	.2427	.2926	.2241	.2241	.2561	.2241
6	.5601	.4572		.4481	.4481	.4525	
7	.5041	.5041	.4252	.4755	.4854	.5121	.5041
8	.4755	.5121	.439	.4938	.4481	.4572	.5228
9	.4755	.499	.4755	.439	.5041	.4706	.5175
10	.4572	.4755	.5121	.4525	.5144	.439	.4344
11	.4805	.4755	.4908	.3982	.4115	.4572	.4207
12	.5304	.439	.4557	.3982	.4207	.4435	.4755
13	.3582	.3982	.4755	.3258	.3681	.3841	.3258
14	.3544	.4163	.4163	.2896	.3155	.3841	.2686
15	.3544	.439	.439	.3292	.2804	.3881	.3582
16	.3841	.443	.4572	.3982	.3681	.4938	.4706
17	.4755	.4755	.5121	.3292	.4525	.4572	.4706
18	.4607	.567	.4066	.3658	.4525	.5014	.439
19	.5914	.6024	.5228	.5359	.5853	.6535	.5121
20	.5359	.5853	.5041	.5175	.5487	.5041	.5121
21	.4805	.5487	.5281	.4854	.5228	.4904	.4481
22	.4066	.3475	.415	.3547	.3734	.3395	.3361
23	.2241		.2641	.2427	.2378	.2452	.2241
24	.2054	.2075	.2195	.2263	.2054	.2195	.2075
Max	**.5914**	**.6024**	**.5281**	**.5359**	**.5853**	**.6535**	**.5228**
Min	**.2054**	**.2054**	**.2012**	**.1886**	**.1867**	**.2012**	**.2075**
Avg	**.3923**	**.4112**	**.3937**	**.3607**	**.3714**	**.3900**	**.3696**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PARITE[038] BU 6165
Substation No/ Name :- 144078 / 33/11 KV RASHIWADE
Feeder No / Name : 202 / 11 KV RASHIWADE SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8288	.5596		.0293	.029	.0335	.0213
2	.8288	.5765		.0297	.029	.0339	.0213
3	.8288	.6104		.0274	.0267	.0339	.021
4	.8619	.6859		.0282	.029	.0503	.0213
5	.8619	.779		.0282	.029	.0509	.0213
6	1.0442	1.073		.0271	.0267	.0335	.0213
7	1.2929	1.4074		.021	.0354	.0335	.0213
8	1.5089	1.6804		.0271	.0343	.0335	.0137
9	1.4586	1.6448	.0343	.021	.0343	.0332	.0141
10	1.3565	1.2346		.0503	.0314	.0343	.0332
11	.0232	.0343	.0194	1.6766	1.6617	1.9839	1.989
12	.0232	.0343	.0194	2.0885	1.9784	2.3491	2.1216
13	.0232	.0366	.0194	2.2542	2.3137	2.4587	2.1795
14	.0232	.0343	.0198	2.2211	2.0957	2.4247	2.0388
15	.0232	.0343	.0194	2.1548	2.0287	2.34	2.13
16	.0232	.0343	.0198	2.0885	1.9784	2.2891	2.0222
17	.0232	.0343	.0198	1.9227	1.8778	2.2043	1.9725
18	.0232	.0366	.021	1.8482	1.543	1.9951	1.668
19	.0232	.0343	.021	.0366	.0509	.0297	.0509
20	.0354	.0343	.0286	.0372	.0509	.0297	.0509
21	.0267	.0343	.029	.0372	.0514	.032	.0503
22	.0274	.0366	.0293	.0248	.0509	.032	.0509
23	.0492		.0293	.0372	.0339	.021	.0503
24	.0514	.0328		.0293	.04	.0339	.0213
Max	**1.5089**	**1.6804**	**.0343**	**2.2542**	**2.3137**	**2.4587**	**2.1795**
Min	**.0232**	**.0328**	**.0194**	**.021**	**.0267**	**.021**	**.0137**
Avg	**.4696**	**.4653**	**.0235**	**.6978**	**.6692**	**.7747**	**.6919**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PARITE[038] BU 6165
Substation No/ Name :- 144078 / 33/11 KV RASHIWADE
Feeder No / Name : 203 / 11 KV KOULAV AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0566	.0354	.6706	.5426	.6706	.6371
2	.0343	.0566		.6952	.57	.6539	.6274
3	.0343	.0566	.0354	.6783	.5765	.6783	.6274
4	.0343	.0566		.4359	.6104	.6706	.6274
5	.0343	.0566	.0532	.7042	.6274	.6874	.6613
6	.0343	.0566	.0709	.8048	.6952	.7377	.7377
7	.0343	.0566	.0343	.9556	.8648	.9496	1.0227
8	.0514	.056	.0354	1.1401	1.0682	1.0111	1.2209
9	.0171	.0373	.0366	1.2574	1.153	1.0774	1.0852
10	.0377	.0343	.0377	1.073	.9012	.9156	1.0059
11	1.3395	1.8176	1.4419	.0171	.0191	.0189	.0168
12	1.8143	2.1605	1.7072	.0168	.0191	.0189	.017
13	1.9669	2.0919	1.7101	.0335	.0381	.0373	.017
14	2.0517	2.1262	1.8275	.0168	.0381	.0189	.0332
15	2.0856	2.1262	1.8778	.0503	.0381	.0189	.017
16	2.1365	2.0576	2.0687	.0335	.0566	.0189	.0339
17	2.0008	1.9204	1.8991	.0339	.0381	.0189	.0339
18	1.6956	1.5947	1.7126	.0373	.0503	.0377	.0678
19	.0566	.0709	.0754	.056	.0503	.0747	.0497
20	.0566	.0549	.0434	.056	.0509	.0566	.0509
21	.0732	.0549	.0286	.0566	.0509	.0566	.0566
22	.0747	.0532	.0566	.0373	.0509	.0566	.0509
23	.056		.0566	.0566	.0503	.0566	.0503
24	.0514	.056	.0343	.0566	.056	.0503	.0566
Max	**2.1365**	**2.1605**	**2.0687**	**1.2574**	**1.153**	**1.0774**	**1.2209**
Min	**.0171**	**.0343**	**.0286**	**.0168**	**.0191**	**.0189**	**.0168**
Avg	**.6586**	**.7265**	**.6763**	**.3739**	**.3423**	**.358**	**.3669**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PARITE[038] BU 6165
Substation No/ Name :- 144078 / 33/11 KV RASHIWADE
Feeder No / Name : 204 / 11 KV NAGESHWAR GAVTHAN GAOTHAN FEEDER
VG FD Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	.0724	.0754	.0754	.0754	.0754
2	.0754	.0754	.0732	.0754	.0754	.0754	.0754
3	.0754	.0754	.0732	.0754	.0754	.0747	.0754
4	.0754	.0754		.0754	.0754	.0747	.0754
5	.1698	.1132	.1097	.0934	.1132	.132	.0943
6	.1886	.1886	.1463	.1646	.1867	.2054	.168
7	.1886	.2241	.2195	.2054	.2054	.2218	.1886
8	.1867	.2033	.2195	.1829	.2054	.2012	.2195
9	.2172	.1848	.2195	.1867	.2241	.1829	.1848
10	.1478	.1829	.1753	.1433	.1791	.1307	.1463
11	.1646	.1595	.1509		.1578	.1478	.1357
12	.1646	.1463	.1543	.0867	.1753	.1848	.1187
13	.1417	.1595	.1715	.1075	.1372	.168	.1254
14	.1463	.1463	.1372	.1227	.1372	.1478	.1267
15	.1595	.1463	.1357	.1254	.1372	.1646	.1433
16	.1463	.124	.1696	.1052	.1509	.1646	.1629
17	.1772	.128	.1543	.0895	.1989	.1848	.1646
18	.2012	.2172	.1928	.132	.2126	.197	.181
19	.2957	.2835	.2957	.2614	.3077	.2987	.2896
20	.2772	.2561	.2801	.2641	.2743	.2987	.2772
21	.2402	.2126	.2614	.2241	.2241	.2452	.2263
22	.2054	.1646	.1886	.1698	.168	.1698	.1494
23	.1132		.1132	.0943	.0886	.0943	.0934
24	.0754	.0754	.0732	.0754	.0747	.0709	.0754
Max	**.2957**	**.2835**	**.2957**	**.2641**	**.3077**	**.2987**	**.2896**
Min	**.0754**	**.0754**	**.0724**	**.0754**	**.0747**	**.0709**	**.0754**
Avg	**.1629**	**.1573**	**.1647**	**.1363**	**.1608**	**.1630**	**.1489**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PARITE[038] BU 6165
Substation No/ Name :- 144078 / 33/11 KV RASHIWADE
Feeder No / Name : 205 / SHAHU LIS **PURELY LIS FEEDERS**
Feeder KV- 11 / OUTGOING

DATE	24-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3		.0189	.0171	.0189
4		.0189	.0171	.0189
5		.0189	.0171	.0189
6		.0754	.017	.0189
7		.0754	.0168	.0189
8		.0747	.0166	.0189
9		.0754	.0166	.0189
10		.1509	.0914	.0175
11		.1494	.128	.0171
12		.1494	.1478	.017
13	.0189	.1494	.1478	.0171
14	.0189	.1494	.1478	.0171
15	.0754	.1494	.1478	.017
16	.0189	.1494	.1478	.0171
17	.0189	.1494	.1478	.0171
18	.0189	.0168	.0189	.0171
Max	**.0754**	**.1509**	**.1478**	**.0189**
Min	**.0189**	**.0168**	**.0166**	**.017**
Avg	**.0283**	**.0982**	**.0777**	**.0179**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PHULEWADI[040] BU 6181
Substation No/ Name :- 144005 / 33/11 KV KOGE
Feeder No / Name : 201 / 11 Kv Wakare Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0168	.0168	.0168	.4359	.5365	.4527	.4694
2	.0168	.0168	.0166	.4359	.5365	.503	.4694
3	.0168	.0168	.0168	.4359	.5365	.503	.4694
4	.0168	.0168	.0166	.4359	.6036	.5365	.4694
5	.0168	.0168	.0166	.4694	.6036	.5365	.503
6	.0168	.0166	.0166	.503	.6371	.5868	.5365
7	.0168	.0168	.0168	.57	.6706	.6371	.57
8	.0168	.0168	.0168	.6371	.7042	.7042	.6371
9	.0168	.0168	.0168	.6706	.7377	.7625	.663
10	.0168	.0166	.0168	.5365	.6371	.5761	.5365
11	.7377	.8288	.8383	.0168	.0168	.0166	.0168
12	.8718	.8619	.9221	.0168	.0168	.0166	.0168
13	.8718	.9282	.9221	.0168	.0168	.0166	.0168
14	.8718	.8619	.9389	.0168	.0168	.0166	.0166
15	.8718	.8288	.9389	.0168	.0168	.0168	.0168
16	.8718	.8288	.9389	.0168	.0168		.0168
17	.8718	.8048	.8383	.0168	.0168		.0168
18	.8048	.7293	.6706	.0168	.0168	.0166	.0168
19	.0168	.0166	.0168	.0168	.0168	.0166	.0168
20	.0168	.0168	.0168	.0168	.0168	.0166	.0168
21	.0166	.0166	.0156	.0168	.017	.0166	.0168
22	.0164	.0166	.0168	.0168	.0168	.0166	.0168
23	.0168	.0166	.017	.0166	.0168	.0166	.0168
24	.0168	.0168	.0168	.0168	.5365	.0168	.0168
Max	**.8718**	**.9282**	**.9389**	**.6706**	**.7377**	**.7625**	**.663**
Min	**.0164**	**.0166**	**.0156**	**.0166**	**.0168**	**.0166**	**.0166**
Avg	**.2934**	**.2892**	**.3031**	**.2236**	**.2899**	**.2726**	**.2316**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PHULEWADI[040] BU 6181
Substation No/ Name :- 144005 / 33/11 KV KOGE
Feeder No / Name : 202 / 11 Kv Mahe Vg GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1254	.1063	.1357	.1063	.1448	.1433	.1433
2	.1254	.1063	.1326	.1075		.1448	.1433
3	.1433	.1063	.1448	.1448	.1433	.1448	.1433
4	.1791	.124	.2149	.1791	.1433	.2172	.1433
5	.2865	.2303	.2896	.2507	.2172	.2561	.2865
6	.4656	.3898	.3982	.3582	.2896	.4024	.4656
7	.4477	.4607	.3982	.3898	.4706	.4298	.4656
8	.4298	.3898	.3982	.3898	.4344	.394	.4298
9	.4298	.394	.4344	.3544	.3898	.3582	.3658
10	.3544	.4298	.394	.3544	.3898	.4298	.4207
11	.4252	.362	.4298	.2835	.3898	.394	.3898
12	.4252	.3582	.394	.2835	.3189	.3582	.4252
13	.3898	.3582	.3582	.2481	.3189	.2507	
14	.3189	.3582	.3582	.1772	.3898	.394	
15	.2835	.3582	.3224	.1772	.2481	.394	.4607
16	.2481	.3582	.2865	.2126			.3898
17	.2835	.3582	.3224	.2481	.4119		.3544
18	.3544	.3582	.5014	.2835	.5194	.362	.3544
19	.4961	.5014	.5194	.4607	.4572	.5068	.567
20	.4656	.4641	.5014	.4607	.4656	.5068	.5316
21	.4167	.4344	.394	.5014	.5014	.5068	.3898
22	.2865	.2507	.2686	.2507	.3582	.2896	.2835
23	.1772	.2149	.1791	.1658	.2865	.1463	.1417
24	.1254	.1063	.1433	.1075	.1448	.1433	.1433
Max	**.4961**	**.5014**	**.5194**	**.5014**	**.5194**	**.5068**	**.567**
Min	**.1254**	**.1063**	**.1326**	**.1063**	**.1433**	**.1433**	**.1417**
Avg	**.3201**	**.3158**	**.3300**	**.2706**	**.3379**	**.3260**	**.3381**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PHULEWADI[040] BU 6181
Substation No/ Name :- 144005 / 33/11 KV KOGE
Feeder No / Name : 203 / 11 Kv Bahireshwar Vg GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0732	.0732	.0724	.0543	.0724
2		.0732	.0732	.0724	.0543	.0724
3		.0732	.0732	.0724	.0543	.0724
4		.1109	.0732	.0724	.0724	.1086
5		.1463	.1097	.1086	.1267	.1448
6		.2195	.1829	.1448	.2172	.2172
7		.2195	.1629	.2534	.2172	.2172
8		.2195	.1829	.2172	.2353	.2172
9	.2195	.2195	.1463	.181	.181	.181
10		.1509	.2218		.2172	.181
11		.2195	.1097	.1448	.2172	.2172
12		.2172	.1463	.181	.2172	.2172
13		.2195	.1097	.181	.181	.181
14		.2195	.1097	.1629	.181	.181
15		.1829	.1097	.1629	.181	.181
16		.1646	.1097	.1448		.1448
17		.1829	.1097	.1448		.1448
18		.2012	.1463	.181	.2172	.1448
19		.2378	.1829	.2172	.2896	.2172
20		.2195	.1829	.2172	.2534	.181
21		.1829	.1829	.2172	.2172	.1448
22		.1463	.1097	.1448	.2172	.112
23		.1075	.0732	.1086	.1448	.0724
24		.0724	.0732	.0724	.0724	.0724
Max	**.2195**	**.2378**	**.2218**	**.2534**	**.2896**	**.2172**
Min	**.2195**	**.0724**	**.0732**	**.0724**	**.0543**	**.0724**
Avg	**.2195**	**.1700**	**.1273**	**.1511**	**.1736**	**.1540**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PHULEWADI[040] BU 6181
Substation No/ Name :- 144005 / 33/11 KV KOGE
Feeder No / Name : 204 / 11 Kv Sangrul Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2949	.2429	.1989	.0164	.0166	.0166	.0164
2	.2949	.2622	.1989	.0164	.0166	.0164	.0164
3	.2949	.3018	.1989	.0164	.0166	.0164	.0164
4	.3277	.2949	.1989	.0164	.0166	.0164	.0164
5	.3277	.2984	.1989	.0164	.0166	.0164	.0164
6	.3932	.2949	.2321	.0164	.0166	.0164	.0164
7	.4424	.4024	.2321	.0164	.0166	.0164	.0164
8	.5898	.5898	.3978	.0166	.0166	.0164	.0164
9	.5735	.5967	.3978	.0166	.0166	.0166	.0166
10	.3932	.5967	.2652	.0166	.0166	.0166	.0168
11	.0164	.0168	.0166	.3315	.9945	.9945	.8848
12	.0164	.0166	.0166	.5636	1.094		1.0059
13	.0164	.0166	.0166	.5967	1.1271	.9945	1.0059
14	.0164	.0166	.0166	.5967	1.0277	.9945	1.0059
15	.0164	.0166	.0164	.5967	1.0277	.9945	.9945
16	.0164	.0166	.0164		.9945		.8951
17	.0164	.0166	.0164	.3978	.8848		.8453
18	.0164	.0166	.0164	.3978	.7209	.6962	.6962
19	.0164	.0166	.0166	.0166	.0164	.0166	.0166
20	.0162	.0166	.0164	.0166	.0164	.0166	.0166
21	.0164	.0166	.0164	.0166	.0164	.0166	
22	.0164	.0166	.0164	.0166	.0164	.0166	.0166
23	.0164	.0166	.0164	.0166	.0164	.0166	.0166
24	.0164	.0164	.0166	.0164	.0166	.0164	.0164
Max	**.5898**	**.5967**	**.3978**	**.5967**	**1.1271**	**.9945**	**1.0059**
Min	**.0162**	**.0164**	**.0164**	**.0164**	**.0164**	**.0164**	**.0164**
Avg	**.1734**	**.1714**	**.1146**	**.1628**	**.3390**	**.2352**	**.3296**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PHULEWADI[040] BU 6181
Substation No/ Name :- 144005 / 33/11 KV KOGE
Feeder No / Name : 205 / 11 Kv Mahe Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0137	.0168	.6081	.9614	.6687	.5121
2		.0135	.0168	.6802	.9724	.6706	.5121
3		.0133	.0168	.6802	.9724	.7042	.5121
4		.0135	.0168	.7209	.9724		.5761
5		.0133	.0168	.7449	1.0395	.8421	.5761
6		.0133	.0166	.8002	1.0395	.9922	.6401
7		.0133	.0168	.9503	1.073	1.0883	.8322
8		.0135	.0168	1.0688	1.1401	1.2452	.9602
9		1.2146	.0168	1.1385	1.0437	1.3413	1.0364
10		1.4586	.0162	.9175	.9717	1.073	.9442
11		1.6766	1.2955	.0168	.0147	.0166	.0147
12		1.6766	1.643	.0145	.016	.0168	.0171
13		1.6766	1.6575	.0143	.0171	.0166	
14	1.5581	1.6766	1.5746	.0152	.0149	.0166	
15	1.8564	1.5424	1.8107	.0168	.0133	.0166	.0139
16	1.8233	1.5424	1.757	.0171			
17	1.6956	1.2742	1.4449	.0181	.0143		.0171
18	1.9669	1.073	1.2342	.0181	.0143	.0168	.0181
19	.0152	.0166	.0151	.0177	.0143	.0181	.0175
20	.0154	.0168	.0152	.0175	.0143	.0181	.0171
21	.0154	.0168	.0154	.0168	.0143	.0166	.0168
22	.0152	.0166	.0152	.0168	.016	.0168	.0171
23	.0156	.0166	.0152	.0179	.0162	.0168	.0175
24		.0143	.0168	.0152	.0168	.0162	.0152
Max	**1.9669**	**1.6766**	**1.8107**	**1.1385**	**1.1401**	**1.3413**	**1.0364**
Min	**.0152**	**.0133**	**.0151**	**.0143**	**.0133**	**.0162**	**.0139**
Avg	**.8977**	**.6257**	**.5282**	**.3559**	**.4514**	**.4204**	**.3468**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PHULEWADI[040] BU 6181
Substation No/ Name :- 144005 / 33/11 KV KOGE
Feeder No / Name : 206 / 11 Kv bahireshwar Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0091	.0168	.5845	.4496	.503	.2286
2		.0093	.0166	.607	.4496	.5258	.2286
3		.0088	.0166	.607	.4496	.5716	.2286
4		.0091	.0166	.6295	.4496	.5944	.2286
5		.0093	.0166	.663	.4946	.6401	.2743
6		.0088	.0166	.6969	.4946	.7306	.3201
7		.0088	.0166	.7846	.5396	.6295	.3658
8		.009	.0166	.8398	.6744	.6969	.4572
9		1.0402	.0166	.9297	.6973	.8093	.4458
10		1.1431	.0095	.823	.5944	.6744	.4201
11		1.2803	1.259	.0095	.0095	.0166	.0082
12		1.2803	1.326	.0095	.0091	.0166	.0111
13		1.3717	1.4163	.0091	.0095	.0168	.0162
14	1.2376	1.3489	1.3489	.0095	.0095	.0166	.0124
15	1.4613	1.214	1.3717	.0107	.0095	.0166	.0072
16	1.3714	1.214	1.3489	.0095			.0095
17	1.3032	1.169	1.2784	.0095	.0095		.0095
18	.9955	1.0791	1.1854	.0095	.0095	.0166	.0095
19	.0103	.0168	.0095	.0095	.0095	.0166	.0095
20	.0105	.0166	.0095	.0091	.0095	.0166	.0095
21	.0107	.0166	.0095	.0166	.0095	.0166	.0095
22	.0107	.0166	.0095	.0166	.0152	.0166	.0095
23	.0107	.0166	.0095	.0168	.0095	.0166	.0095
24		.0086	.0168	.0095	.0112	.0095	.0114
Max	**1.4613**	**1.3717**	**1.4163**	**.9297**	**.6973**	**.8093**	**.4572**
Min	**.0103**	**.0086**	**.0095**	**.0091**	**.0091**	**.0095**	**.0072**
Avg	**.6422**	**.5127**	**.4483**	**.3050**	**.2358**	**.2985**	**.1392**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PHULEWADI[040] BU 6181
Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn
Feeder No / Name : 203 / 11 kv khupire Vg GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.2134	.1886	.2229	.2286	.1543	.1372
2	.1372	.2134	.1715	.2058	.2286	.1543	.1372
3	.1372	.2286	.1715	.2058	.2286	.1543	.12
4	.1372	.3048	.2058	.2058	.3048	.1543	.1715
5	.2572	.381	.3086		.3048	.2401	.2401
6	.4801	.4572	.3429		.3048	.3429	.3429
7	.4801	.4877	.3944		.3963	.4458	.4287
8	.6173	.4877	.3944	.3086	.4572	.463	.4458
9	.5144	.4725	.3772		.4115	.4287	.463
10	.4115	.3963	.3944		.3944	.3429	.4115
11	.3048	.4115			.4287	.3086	.4287
12	.3048	.4115	.5316		.463	.3258	.3944
13	.381	.4115	.4801		.4458	.3258	.3944
14	.381	.4458	.4973		.4458	.4287	.4115
15	.381	.381	.5144		.4801	.4458	.3601
16	.3963	.4458	.4801		.4973		.3601
17	.3963	.4115	.463		.4801	.4973	.3601
18	.4572	.5487	.5487	.5487	.4973	.4801	.3772
19	.503	.583	.6173	.5792	.6173	.583	.4801
20	.4572	.5487	.5487	.5335	.5658	.5144	.4458
21	.4572	.5144	.4973	.4572	.5487	.4973	.4115
22	.3353	.3772	.4115	.381	.3601	.3601	.2915
23	.2286	.2743	.3086	.3048	.2229	.2401	.1886
24	.2401	.2134	.2229	.2401	.2439	.1543	.1886
Max	**.6173**	**.583**	**.6173**	**.5792**	**.6173**	**.583**	**.4801**
Min	**.1372**	**.2134**	**.1715**	**.2058**	**.2229**	**.1543**	**.12**
Avg	**.3556**	**.4009**	**.3944**	**.3495**	**.3982**	**.3496**	**.3329**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PHULEWADI[040] BU 6181
Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn
Feeder No / Name : 204 / 11 Kv Fulewadi Vg GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601	.4572	.4115	.3772	.5144		.4115
2	.3601	.5144	.4458	.3772	.4572		.4115
3	.3601	.5335	.4458	.3772	.6001	.463	.4115
4	.3601	.6859	.4801	.3772	.6097		.4287
5	.4801	.6859	.5487	.3772	.6859		.4801
6	.6859	.8573	.7202	.6173	.7621	.7545	.6516
7	.9602		.7926	.823	.8916	1.0288	.8916
8	1.0288	1.1145	.9259	.9259	1.0288	1.0974	1.0288
9	.8916	.9602	.9602	.9088	1.0288	.9259	1.0288
10	.823	.8573	.7926	.7888	.8916	.7716	.823
11	.6859	.823	.7716	.6097	.7011	.7373	.6859
12	.6859	.8573	.823	.6859	.7202	.7202	
13	.8573	.7888	.6859	.5792	.7373	.6687	
14	.7716	.7202	.6173	.5487	.7545	.6516	.6859
15	.6859	.5487	.6173	.5487	.7202	.6173	.6859
16	.6516	.6859	.6516	.6001	.6859	.6173	.583
17	.7716	.7316	.6859	.5487	.6859	.6859	.7545
18	.9602	.8535	.823	.6859	.823	.9088	.823
19	1.2689	.9145	1.166	1.2003	1.2346	1.2003	1.0974
20	1.2003	.9945	1.0974	.9907	1.166	1.166	1.0631
21	1.1145	.8916	1.0631	1.0288	1.0631	1.0802	.9945
22	.9145	.7011	.8573	.8535	.8916	.9259	.823
23	.8383	.6173	.5487	.8573	.6344	.6344	.5487
24	.3658	.5144	.4458	.4115	.5144	.4801	.4973
Max	**1.2689**	**1.1145**	**1.166**	**1.2003**	**1.2346**	**1.2003**	**1.0974**
Min	**.3601**	**.4572**	**.4115**	**.3772**	**.4572**	**.463**	**.4115**
Avg	**.7534**	**.7525**	**.7241**	**.6708**	**.7834**	**.8068**	**.7186**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PHULEWADI[040] BU 6181
Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn
Feeder No / Name : 207 / 11 KV FULEWADI AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1524	.1524	.1219	
2				.1524	.1524	.1219	
3				.1524	.1524	.1219	
4				.1372	.2286	.1219	
5				.1372	.2286	.1372	
6				.1524	.2286	.1524	
7				.2286	.2286	.1981	
8				.2439	.3048	.2591	
9				.3048	.3048	.2743	
10				.2896	.2743	.2286	
11	.6097	.6706	.7011				.5639
12	.6859	.7164	.7773				.6554
13	.6859	.7316	.7621				.6859
14	.6401	.7316	.7621				.7011
15	.3048	.7164	.7468				.6554
16	.6859	.7011	.7316				.6401
17	.6097	.6706	.5944				.6554
18	.5335	.5335	.5182				.5335
Max	**.6859**	**.7316**	**.7773**	**.3048**	**.3048**	**.2743**	**.7011**
Min	**.3048**	**.5335**	**.5182**	**.1372**	**.1524**	**.1219**	**.5335**
Avg	**.5944**	**.6840**	**.6992**	**.1951**	**.2256**	**.1737**	**.6363**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PHULEWADI[040] BU 6181
Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn
Feeder No / Name : 208 / 11KV Padali Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7316	.6097	.9145	.0762	.0914	.0762	1.0059
2	.7316	.6097	.9145	.0762	.0914	.0762	1.0059
3	.7316	.6097	.945	.0762	.0914	.0762	.9755
4	.7468	.6859	.945	.0762	.1219	.0762	.9755
5	.7621	.7621	.9755	.0914	.1219	.0914	1.0059
6	.823	.9145	.9755	.1219	.1219	.1067	1.1126
7	1.1831		.9755	.1219	.1524	.1067	1.2193
8	1.1584	1.0974	1.0669	.1524	.1524	.0914	1.3717
9	1.1431	1.1431	1.0974	.1372	.1524	.1219	1.3565
10	1.0669	1.0974	1.0364	.1677	.1219	.1067	1.2193
11	.1219	.1067	.1372	1.2193	1.5242	1.5546	.0914
12	.1067	.0914	.1067	1.448	1.5851	1.6766	.1067
13	.1219	.1067	.1524	1.448	1.5546	1.6766	.1219
14	.1219	.1067	.1219	1.5242	1.5242	1.7528	.1219
15		.1067	.1067	1.5242	1.4937	1.6918	.1067
16	.1219	.1219	.1067	1.7071	1.4022	1.7528	.1372
17	.1524	.1219	.1829	1.5242		1.5546	.1219
18	.1524	.1219	.1219	1.3717	1.3717	1.4937	.1219
19	.1829	.1524	.1524	.1829	.1524	.1829	.1981
20	.1829	.1829	.1524	.1829	.1677	.1677	.1372
21	.1829	.1524	.1524	.1524	.1524	.1524	.1219
22	.1524	.1067	.1219	.1219	.0914	.1067	.0914
23	.1219	.1067	.0914	.1067	.0762	.0914	.0762
24	.061	.0914	.0914	.0762	.0914	.0762	.0914
Max	**1.1831**	**1.1431**	**1.0974**	**1.7071**	**1.5851**	**1.7528**	**1.3717**
Min	**.061**	**.0914**	**.0914**	**.0762**	**.0762**	**.0762**	**.0762**
Avg	**.4722**	**.4003**	**.4852**	**.5703**	**.5394**	**.6192**	**.5372**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PHULEWADI[040] BU 6181
Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn
Feeder No / Name : 209 / 11KV Khupire Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7621	.8535	.6097	.4572	.6097	.884
2	.884	.7621	.884	.6097	.4572	.6097	.884
3	.884	.9145	1.0288	.6249	.6097	.6097	.884
4	.8993	.9145	1.0288	.6249	.6097	.6097	.8688
5	.945	.9145	1.0974	.6859	.7621	.6859	.8688
6	1.0974	.9907	1.1279	.7926	.7621	.7621	.9755
7	1.2193	.9907	1.2193	1.0669	.9145	.945	1.2498
8	1.6461	1.5432	1.2803	1.2193	1.3717		1.5242
9	1.7071	1.2193	1.4632	1.4632	1.3717	1.2193	1.6461
10	1.5242	1.0669	1.3413	1.2193		1.1279	1.1736
11	1.6004	1.829		1.0974	2.1338	1.768	1.2193
12	1.5242	1.9814	1.9814	1.829	2.4387	2.8502	
13	1.9719	2.2634	2.2405	1.829	2.7435	2.9721	1.829
14	1.7528	2.0424	2.2862	1.9052	3.0483	2.9721	1.829
15	1.829	2.0729	2.1643	1.7071	2.9874	3.0026	1.9814
16		1.9204	2.1948	1.7071	2.4387	2.713	1.9509
17	1.7071	1.89	1.829	1.5242	2.5606	2.6216	1.6766
18		1.5851	1.5851	1.3717	2.0881	2.2405	1.5242
19	.0305	.0305	.0305	.0343	.0305	.0152	.0305
20		.0305	.0305		.0305	.0152	.0305
21	.0305	.0305	.0305	.0305	.0305	.0152	.0305
22	.0305	.0305	.0305	.0305	.0305	.0152	.0305
23		.0305	.0305	.0305	.0305	.0152	.0305
24	.0305	.0305	.0305	.0305	.0305	.0305	.0152
Max	**1.9719**	**2.2634**	**2.2862**	**1.9052**	**3.0483**	**3.0026**	**1.9814**
Min	**.0305**	**.0305**	**.0305**	**.0305**	**.0305**	**.0152**	**.0152**
Avg	**1.1218**	**1.0769**	**1.1213**	**.9584**	**1.2147**	**1.2359**	**1.0060**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PHULEWADI[040] BU 6181
Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn
Feeder No / Name : 210 / 11 Kv kuditre Vg GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2401	.2743	.2229	.2286	.2915	.2743
2	.2058	.2401	.2401	.2229	.2286	.2915	.2743
3	.2058	.2401	.2743	.2229	.2286	.2915	.2743
4	.2058	.2572	.3086	.2401	.3048	.2915	.3086
5	.3429	.3429	.4458	.3086	.3048	.4287	.3258
6	.6173	.6859	.583	.5487	.4572	.6344	.5658
7	.6859	.7716	.6516	.6173	.6097	.6516	.6173
8	.6859	.5487	.6859	.6173	.6516	.6859	.6173
9	.6859	.6173	.6859	.5658	.6173	.6859	.5144
10	.6173	.6859	.6516	.5316	.5487	.6859	.6344
11	.6097	.6859		.4572	.6173	.6344	.4458
12	.6173	.7202	.5487	.5144	.6859	.5487	
13	.5487	.6859	.463	.381	.5487	.4801	.4801
14	.5487	.6516	.4801	.381	.4458	.4458	.4458
15		.5487	.5487	.381	.463	.463	.4287
16		.5487	.5658	.3353	.4801	.5658	.5658
17	.5487	.6173	.583	.4287	.583	.5658	.583
18	.6173	.7545	.6859	.5144	.5487	.5487	.5658
19		.7888	.7545	.6173	.6859	.7545	.6859
20	.6859	.7545	.6859	.6173	.6687	.7202	.6344
21	.5487	.6173	.6173	.5487	.583	.6516	.6173
22	.5144	.4801	.4801	.5144	.4801	.5316	.4458
23	.2572	.3772	.2743	.3429	.3601	.3429	.3429
24	.2401	.2401	.3086	.2229	.2401	.3086	.2743
Max	**.6859**	**.7888**	**.7545**	**.6173**	**.6859**	**.7545**	**.6859**
Min	**.2058**	**.2401**	**.2401**	**.2229**	**.2286**	**.2915**	**.2743**
Avg	**.4855**	**.5459**	**.5129**	**.4314**	**.4821**	**.5208**	**.4749**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PHULEWADI[040] BU 6181
Substation No/ Name :- 144110 / 33/11KV BOLOLI S.ST
Feeder No / Name : 201 / 11 KV SANGRUL VG GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1509	.1509	.1698	.168	.1509	.1509
2	.1509	.1509	.1509	.1509	.1509	.1509	.132
3	.1509	.1509	.1509	.1509	.1509	.1509	.132
4	.1509	.1698	.1698	.1509	.1509	.1886	.1509
5	.2427	.1886	.3018	.0924	.2054	.1886	.2829
6	.4904	.5281	.5281	.168		.4904	.5041
7	.6161	.6224	.6036	.2263	.6036	.5281	.6161
8	.5975	.5544	.5975	.2218	.5601	.5041	.5601
9	.5041	.462	.4805	.2033	.5121	.4668	.4805
10	.4706	.4435	.4024		.5068	.4163	.4572
11	.4163	.3658	.4572	.3841	.4163	.3801	.362
12	.394	.4207	.362	.3696	.3258	.3439	.3801
13	.3582	.4163	.4024	.3658	.362	.3582	.362
14	.3439	.4163	.3801	.3658	.362	.3224	.3658
15	.3721	.4344	.394	.3658	.3258	.3582	.3258
16	.4334	.4477	.4298	.3982	.3801	.3898	.3077
17	.4733	.4607	.4382	.3801	.4163	.443	.4572
18	.6201	.6268	.5973	.5552	.5304	.6089	.591
19	.7947	.7762	.8316	.8029	.8402	.8589	.8589
20	.8215	.6908	.7655	.7655	.6413	.7655	.7655
21	.6161	.6224	.6348	.6602	.6413	.6535	.6602
22	.4294	.3584	.4527	.3961	.4338	.3961	.4338
23	.2075	.2075	.2829	.2427	.3018	.2452	.2641
24	.1886	.168	.1509	.1698	.2054	.1698	.1509
Max	**.8215**	**.7762**	**.8316**	**.8029**	**.8402**	**.8589**	**.8589**
Min	**.1509**	**.1509**	**.1509**	**.0924**	**.1509**	**.1509**	**.132**
Avg	**.4164**	**.4097**	**.4215**	**.3372**	**.3996**	**.3970**	**.4063**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PHULEWADI[040] BU 6181
Substation No/ Name :- 144110 / 33/11KV BOLOLI S.ST
Feeder No / Name : 202 / 11 KV KHATANGLE AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.2469	.2683				
2	.2881	.2469	.2713				
3	.2881	.2439	.2683				
4	.3239	.2709	.285				
5	.3239	.3549	.3812				
6	.3563	.5079	.4588				
7	.7125	.779	.6882				
8	.8745	.9602	.8259				
9	.9724	1.0364	.8583				
10	.759	.9393	.78				
11				1.0322	1.291	1.3245	1.3565
12				1.3923	1.2955	1.6095	1.6263
13				1.5249	1.6095	1.5927	1.5581
14				1.5746	1.6766	1.6095	1.5238
15				1.5249	1.643	1.576	1.4922
16				1.1961	1.5402	1.5083	1.3413
17				1.2631	1.3441	1.3916	1.1797
18				1.012	1.1065	1.094	.9061
Max	**.9724**	**1.0364**	**.8583**	**1.5746**	**1.6766**	**1.6095**	**1.6263**
Min	**.2881**	**.2439**	**.2683**	**1.012**	**1.1065**	**1.094**	**.9061**
Avg	**.5190**	**.5586**	**.5085**	**1.3150**	**1.4383**	**1.4633**	**1.373**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL I DIVISION[504]
PHULEWADI[040] BU 6181
Substation No/ Name :- 144110 / 33/11KV BOLOLI S.ST
Feeder No / Name : 203 / 11 KV UPWADE AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0867	.0617	.032	.0347
2				.1214	.0753	.048	.052
3				.1214	.0772	.048	.052
4				.1357	.0829	.048	.052
5				.1326	.1174	.048	.0686
6				.1492		.081	.1029
7				.2401	.2321	.1943	.156
8				.3315	.2753	.2753	.2683
9				.3391	.2458	.3113	.2543
10				.1966	.213	.2515	.2543
11	.7042	.5533	.3856				
12	.8215	.763	.6036				
13	.8785	.7712	.6613				
14	.8619	.7209	.6104				
15	.788	.6539	.6859				
16	.788	.5967	.6036				
17	.6036	.5079	.4752				
18	.5079	.3647	.3812				
Max	**.8785**	**.7712**	**.6859**	**.3391**	**.2753**	**.3113**	**.2683**
Min	**.5079**	**.3647**	**.3812**	**.0867**	**.0617**	**.032**	**.0347**
Avg	**.7442**	**.6165**	**.5509**	**.1854**	**.1534**	**.1337**	**.1295**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
GARGOTI[044] BU 7137
Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION
Feeder No / Name : 202 / 11 KV SHENAGAON AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.743	.6668	.6859	.0191	.1143	.0953	.0953
2	.743	.6668	.6859	.0191	.1143	.0953	.0953
3	.743	.6668	.6859	.0191	.1143	.0953	.0953
4	.7811	.6859	.7621	.0191	.1143	.0953	.0953
5	.8192	.724	.8002	.0191	.1143	.0953	.0953
6	.9335	.7621	.8192	.0191	.1143	.0953	.0953
7	1.2193	1.0669	1.0669	.0191	.1143	.0953	.0953
8	1.5242	1.2955		.0191	.1143	.0953	.0953
9	1.4098	1.0669	1.086	.0191	.1143	.0953	.0762
10	.0191	.0191	.0191	.0191	.1143	.0953	.0762
11	.0191	.0191	.0191	1.9052	1.9052	1.9433	2.3434
12		.0191	.0191	2.2291	2.0005	2.0386	2.2862
13	.0191	.0191	.0191	2.2862	2.0957	2.0576	2.3624
14	.0191	.0191	.0191	2.1719	2.2672	2.0005	2.2862
15	.0191	.0191	.0191	1.9624	1.9243	1.9433	2.2862
16	.0191	.0191	.0191	1.848	1.7909	1.8671	2.0767
17	.0191	.0191	.0191	1.7147	1.6766	1.6575	1.9624
18	.0191	.0191	.0191	1.467	1.3336	1.2384	1.448
19	.0191	.0191	.0191	.0953	.0191	.0191	.0191
20	.0191	.0191	.0191	.0953	.0191	.0953	.0191
21	.0191	.0191	.0191	.0953	.0191	.0953	.0191
22	.0191	.0191	.0191	.0953	.0953	.0953	.0191
23	.0191	.0191	.0191	.0953	.0953	.0953	.0191
24	.743	.6668	.6859	.0191	.1143	.0953	.0953
Max	**1.5242**	**1.2955**	**1.086**	**2.2862**	**2.2672**	**2.0576**	**2.3624**
Min	**.0191**	**.0191**	**.0191**	**.0191**	**.0191**	**.0191**	**.0191**
Avg	**.4308**	**.3557**	**.3281**	**.6780**	**.6875**	**.6748**	**.7565**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
GARGOTI[044] BU 7137
Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION
Feeder No / Name : 203 / 11 KV PIMPALGAON VG. GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.3429	.3429	.4763	.3429	.381	.3429
2	.3239	.4191	.3429	.4191	.3429	.4001	.3429
3	.3239	.4001	.3429	.381	.3429	.381	.3429
4	.3429	.4001	.3429	.4001	.381	.4001	.362
5	.381	.4382	.3429	.4001	.4572	.381	.362
6	.5525	.4954	.4572	.4763	.5335	.4763	.4763
7	.6668	.5716	.5335	.5716	.6097	.6097	.6478
8	.6478	.5906	.6478	.5906	.6478	.6478	.7621
9	.724	.5335	.7049	.6287	.6859	.7049	.724
10	.6668	.6097	.6668	.6478	.6097	.6287	.6287
11	.7049	.5906	.6859	.5716	.6097	.6287	.5716
12	.6478	.6097	.6478	.4954		.5716	.5525
13	.5906	.5335	.5716	.4954	.5525	.6287	.5906
14	.5906	.4954	.5906	.4763	.5716	.5335	.5144
15	.5525	.4763	.5716	.4572	.5716	.5335	.4954
16	.5906	.4954	.5716	.4763	.5335	.4954	.5716
17	.6287	.5335	.5906	.5144	.5716		.5906
18	.743	.6478	.6097	.6097	.7049	.6859	.724
19	1.0098	.9717	.8002	.9907	.7621	1.105	1.086
20	.9526	.9526	.8573	.9145	.8573	1.0288	.9907
21	.6859	.8192	.8573	.7621	.7811	.8764	.8383
22	.6859	.6859	.7621	.6478	.6097	.7621	.724
23	.4572	.4382	.6668	.4001	.4572	.4572	.4572
24	.362	.3429	.3429	.5716	.3429	.3429	.3429
Max	**1.0098**	**.9717**	**.8573**	**.9907**	**.8573**	**1.105**	**1.086**
Min	**.3239**	**.3429**	**.3429**	**.381**	**.3429**	**.3429**	**.3429**
Avg	**.5898**	**.5581**	**.5771**	**.5573**	**.5600**	**.5939**	**.5851**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
GARGOTI[044] BU 7137
Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION
Feeder No / Name : 204 / 11 KV MADILAGE VG GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1334	.1334	.1905	.1524	.1524	.1715
2	.1334	.1524	.1334	.1715	.1524	.1334	.1715
3	.1524	.1524	.1334	.1143	.1715	.1524	.1715
4	.1715	.1524	.1524	.1143	.2286	.1715	.1905
5	.2286	.2096	.1905	.1524	.3429	.1905	.2096
6	.381	.362	.3429	.3239	.381	.3239	.3239
7	.4001	.4001	.362	.381	.381	.3429	.381
8	.381	.4191	.4191	.2477	.4001	.4001	.4191
9	.4191	.362	.4001	.3429	.3429	.3429	.4191
10	.3429	.362	.381	.2858	.381	.3048	.4001
11	.3048	.3239	.362	.3239	.3429	.3048	.4001
12	.3048	.362	.3239	.3239	.2858	.3239	.381
13	.2858	.3239	.2858	.2477	.2858	.2858	.4001
14	.3239	.2477	.2667	.0572		.381	.3429
15	.2667	.2858	.3048	.2477	.3239	.362	.381
16	.3048	.3048	.3048	.2667		.3429	.381
17	.4001	.3429	.381	.2667	.362	.362	.381
18	.4191	.4191	.4001	.3048	.362	.4382	.4382
19	.6097	.5906	.5716	.5335	.4191	.6097	.5906
20	.5716	.5144	.5144	.5144	.4954	.5144	.5525
21	.4954	.4763	.4382	.4382	.4572	.4763	.4763
22	.3239	.2858	.3239	.3048	.2858	.362	.362
23	.1715	.1715	.2096	.2096	.1715	.2096	.2096
24	.1524	.1334	.1334	.1524	.1715	.1524	.1905
Max	**.6097**	**.5906**	**.5716**	**.5335**	**.4954**	**.6097**	**.5906**
Min	**.1334**	**.1334**	**.1334**	**.0572**	**.1524**	**.1334**	**.1715**
Avg	**.3199**	**.3120**	**.3112**	**.2715**	**.3135**	**.3183**	**.3477**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
GARGOTI[044] BU 7137
Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION
Feeder No / Name : 205 / 11 KV GARGOTI PWW EXPRESS NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0572	.0191	.0572	.0572	.0572
2	.0572	.0572	.0572	.0572	.0572	.0572	.0572
3	.0572	.0572	.0572	.0191	.0572	.0572	.0572
4	.0572	.0572	.0572	.0191	.0572	.0572	.0572
5	.0572	.0572	.0572	.0191	.0572	.0572	.0572
6	.0572	.0572	.0572	.0191	.0572	.0572	.0572
7	.0572	.0572	.0572	.0191	.0572	.0572	.0572
8	.0572	.0572	.0572	.0191	.0572	.0572	.0572
9	.0572	.0572	.0572	.0191	.0572	.0572	.0572
10	.0572	.0572	.0572	.0191	.0572	.0572	.0572
11	.0572	.0572	.0572	.0191	.0572	.0572	.0572
12	.0572	.0572	.0572	.0191	.0191	.0572	.0572
13	.0572	.0572	.0572	.0191	.0572	.0572	.0572
14	.0572	.0572	.0572	.0191	.0572	.0572	.0572
15	.0572	.0572	.0572	.0191	.0572	.0572	.0572
16	.0572	.0191	.0191	.0191	.0572	.0191	.0191
17	.0572	.0191	.0191	.0191	.0191	.0572	.0572
18	.0572	.0572	.0572	.0572	.0191	.0191	.0191
19	.0572	.0572	.0572	.0572	.0191	.0572	.0572
20	.0572	.0572	.0572	.0572	.0191	.0572	.0572
21	.0572	.0572	.0572	.0572	.0572	.0572	.0572
22	.0572	.0572		.0572	.0572	.0572	.0572
23	.0572	.0572	.0572	.0572	.0572	.0572	.0572
24	.0572	.0572	.0572	.0191	.0572	.0572	.0572
Max	**.0572**	**.0572**	**.0572**	**.0572**	**.0572**	**.0572**	**.0572**
Min	**.0572**	**.0191**	**.0191**	**.0191**	**.0191**	**.0191**	**.0191**
Avg	**.0572**	**.0540**	**.0539**	**.0302**	**.0493**	**.0540**	**.0540**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
GARGOTI[044] BU 7137
Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION
Feeder No / Name : 206 / 11 KV PIMPALGAON AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0762	.0762	.0381	.0381	.0381	.0381
2	.0953	.1143	.0762	.0381	.0381	.0381	.0381
3	.0953	.1143	.0762	.0381	.0572	.0381	.0381
4	.0953	.1143	.0762	.0381	.0572	.0381	.0381
5	.0953	.1143	.0762	.0381	.0572	.0381	.0381
6	.0953	.1334	.0762	.0381	.0572	.0381	.0381
7	.1334	.1524	.1334	.0381	.0572	.0381	.0572
8	.1524	.1715	.1524	.0381	.0381	.0381	.0381
9	.1715	.1143	.1715	.0381	.0381	.0381	.0381
10		.0191	.0381	.0381	.0381	.0381	.0381
11	.0381	.0191	.0381	.1524	.2477	.1905	.2667
12	.0381	.0191	.0381	.1715	.2858	.1905	.2667
13	.0381	.0191	.0381	.3239	.2667	.2667	.2667
14	.0381	.0191	.0381	.3429	.2477	.3048	.2858
15	.0381	.0191	.0381	.381	.2286	.2858	.362
16	.0381	.0572	.0381	.3429	.2477	.2858	.3048
17	.0381	.0381	.0381	.3239	.2477	.2096	.2477
18	.0381	.0381	.0381	.2667	.2096	.2096	.2286
19	.0572	.0381	.0381	.0572	.0191	.0381	.0381
20	.0572	.0762	.0381	.0572	.0381	.0381	.0381
21	.0572	.0381	.0381	.0381	.0381	.0381	.0381
22	.0572	.0381	.0381	.0381	.0381	.0381	.0381
23	.0572	.0381	.0381	.0381	.0381	.0381	.0381
24	.1143	.0762	.0762	.0381	.0381	.0381	.0381
Max	**.1715**	**.1715**	**.1715**	**.381**	**.2858**	**.3048**	**.362**
Min	**.0381**	**.0191**	**.0381**	**.0381**	**.0191**	**.0381**	**.0381**
Avg	**.0754**	**.0691**	**.0635**	**.1230**	**.1112**	**.1064**	**.1191**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
GARGOTI[044] BU 7137
Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION
Feeder No / Name : 207 / 11 KV GANGAPUR AG. SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1905	.1905	.5525	.381	.2477	.381
2	.1524	.1905	.1905	.4954	.381		.381
3	.1524	.1905	.1905	.4572	.4001	.3239	.381
4	.1524	.1905	.1905	.4572	.4382	.3429	.4763
5	.1524	.1905	.1905	.4382	.6859	.5716	.5716
6	.1524	.1905	.1905	.6859	.9145	.6668	.7811
7	.1715	.1905	.1905	.8764	1.1431	1.0669	1.086
8	.1715	.1905	.1715	1.2765	1.4289		1.4861
9	.1715	.1905	.1715	1.2003	1.3146	1.3908	1.3146
10	.1715	.1715	.1715	.1524	.1524	.1524	.1524
11	2.0195	2.21	2.2481	.1524	.1524	.1334	.1524
12	2.191	2.3434	2.3053	.1524	.1524	.1334	.1524
13	1.8861	2.4577	2.3434	.1524	.0572	.1334	.1524
14	2.3624	2.3434	2.3053	.1524	.1143	.1334	.1524
15	2.3053	2.4387	2.3053	.0381	.0953	.1143	.1334
16	1.829	2.3243	2.2672	.1524	.1334	.1334	.1334
17	2.1719	2.1148	1.9814	.1524	.1334	.1334	.1334
18	1.6766	1.7528		.1524	.1334	.1334	.1334
19	.1905	.1905	.1715	.1524	.1334	.1524	.1524
20	.1905	.1905	.1524	.1524	.1334	.1524	.1524
21	.1905	.1905	.1524	.1524	.1334	.1524	.1524
22	.1905	.1905	.1524	.1524	.1524	.1524	.1524
23	.1905	.1905	.1524	.1334	.1524	.1334	.1334
24	.1524	.1905	.1905	.4191	.4001	.2667	.362
Max	**2.3624**	**2.4577**	**2.3434**	**1.2765**	**1.4289**	**1.3908**	**1.4861**
Min	**.1524**	**.1715**	**.1524**	**.0381**	**.0572**	**.1143**	**.1334**
Avg	**.7978**	**.8756**	**.8076**	**.3691**	**.3882**	**.3100**	**.3858**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
GARGOTI[044] BU 7137
Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION
Feeder No / Name : 208 / 11 KV DARWAD AG. SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0572	.0762	.0191	
2	.0191	.0191	.0191	.0381	.0762	.0191	
3	.0191	.0191	.0191	.0381	.0762	.0191	.0191
4	.0191	.0191	.0191	.0381	.0953	.0762	.0191
5	.0191	.0191	.0191	.0381	.1143	.0762	.0191
6	.0191	.0191	.0191	.0572	.1143	.0953	.0191
7	.0191	.0191	.0191	.0953	.2286	.1715	.0191
8	.0191	.0191	.0191	.2477	.3048	.2667	.0191
9	.0191	.0191	.0191	.2286	.2667	.2858	.0191
10	.0191	.0191	.0191	.0191	.0191	.0191	.0191
11	.3239	.4954	.4763	.0191	.0191	.0191	.4572
12	.4001	.5716	.5525		.0191	.0191	
13	.4001	.6097	.5906	.0191	.0191	.0191	.5335
14	.4382	.5716	.5906	.0191	.0191	.0191	.6097
15	.4191	.5525	.5525	.0191	.0191	.0191	.5906
16	.4572	.5525	.5335	.0191		.0191	.5335
17	.4001	.5144	.4572	.0191		.0191	.4763
18	.3429		.3429	.0191	.0191	.0191	.4572
19	.0191	.0191	.0191	.0191	.0191	.0191	.0191
20	.0191	.0191	.0191	.0191	.0191	.0191	.0191
21	.0191	.0191	.0191	.0191	.0191	.0191	.0191
22	.0191	.0191	.0191	.0191	.0191	.0191	.0191
23	.0191	.0191	.0191	.0191	.0191	.0191	.0191
24	.0191	.0191	.0191	.0381	.0572	.0381	.0191
Max	**.4572**	**.6097**	**.5906**	**.2477**	**.3048**	**.2858**	**.6097**
Min	**.0191**	**.0191**	**.0191**	**.0191**	**.0191**	**.0191**	**.0191**
Avg	**.1453**	**.1814**	**.1834**	**.0489**	**.0745**	**.0556**	**.1869**

 Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
GARGOTI[044] BU 7137
Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION
Feeder No / Name : 209 / 11KV MADUR VG GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1334	.1524	.1715	.1334	.1715	.1524
2	.1334	.1334	.1524	.1905	.1524	.1905	.1524
3	.1524	.1334	.1524	.2286	.1524	.1905	.1524
4	.1524	.1905	.1905	.2286	.1905	.1905	.1715
5	.1715	.2477	.2286	.2477	.2286	.1905	.2096
6	.3429	.362	.3239	.3239	.3048		.3048
7	.4382	.4572	.4191	.381	.381	.3239	.4382
8	.4572	.4572	.4191	.4191	.381	.3429	.4382
9	.4191	.381	.4191	.4001	.362	.3239	.4191
10	.362	.4191	.4382	.362	.3429	.3239	.4191
11	.381	.3429	.4191	.3429	.3239	.3048	.362
12	.3239	.381	.362	.2667	.2858	.3239	.381
13	.3048	.3239	.3429	.2286	.2858		.3429
14	.3048	.2858	.362	.1715	.2858	.2667	.2667
15	.2667	.2858	.3239		.2667	.2477	.2667
16	.3429	.2667	.3429	.2096	.2667	.3429	.3048
17	.4001	.3429	.381	.1905	.3429	.2858	.3048
18	.4382	.4001	.4191	.2667	.4001	.381	.4001
19	.5906	.6097	.5716	.4954	.4763	.5906	.6097
20	.5716	.5716	.6478	.4763	.5144	.5716	.5716
21	.5144	.4954	.6668	.4001	.4382	.5525	.5335
22	.3429	.3239	.4001	.2667	.2286	.4191	.362
23	.1905	.1905	.2858	.1524	.1905	.2096	.1905
24	.1143	.1334	.1524	.2286	.1334	.1715	.1905
Max	**.5906**	**.6097**	**.6668**	**.4954**	**.5144**	**.5906**	**.6097**
Min	**.1143**	**.1334**	**.1524**	**.1524**	**.1334**	**.1715**	**.1524**
Avg	**.3271**	**.3279**	**.3572**	**.2891**	**.2945**	**.3144**	**.3310**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
GARGOTI[044] BU 7137
Substation No/ Name :- 144022 / 33/11KV PIMPALGAON S/S
Feeder No / Name : 201 / 11 KV MANGNOOR AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0075	.5228	.547	.5544	.4668
2		.0075	.4854	.547	.5544	.4294
3		.0075	.4854	.547	.6535	.4294
4		.0075	.5601	.547	.6468	.4668
5		.0075	.5975	.5658	.7023	.5041
6		.0075	.6908	.8299	.7316	.5975
7		.6653	.8962	1.0562	.9877	.7842
8		.8596	1.1203	1.3392	1.0974	.9149
9		1.0242	1.0829	1.2826	1.0608	1.0082
10		1.0974	.0019		.0075	
11		1.1949		.0075		.0019
12		1.1576		.0075		.0019
13		1.419		.0075		.0019
14	.6468	1.4377		.0075		.0019
15	1.2071	1.419		.0075		.0019
16	1.3121	1.3817		.0075		.0019
17	1.2752	1.2696		.0075		.0019
18	1.0164	1.0829		.0075		.0019
19		.0019		.0075		.0019
20	.0075	.0019		.0075		.0019
21	.0075	.0019		.0075		.0019
22	.0075	.0019		.0075		.0019
23	.0075	.0019		.0075		.0019
24		.0075	.5228	.547	.5175	.4668
Max	**1.3121**	**1.4377**	**1.1203**	**1.3392**	**1.0974**	**1.0082**
Min	**.0075**	**.0019**	**.0019**	**.0075**	**.0075**	**.0019**
Avg	**.6097**	**.5863**	**.6333**	**.3437**	**.6831**	**.2649**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
GARGOTI[044] BU 7137
Substation No/ Name :- 144022 / 33/11KV PIMPALGAON S/S
Feeder No / Name : 202 / 11 KV ARALGUNDI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.415	.4066	.0019		.0075	
2	.3361	.415	.3734	.0019		.0075	
3	.3734	.3772	.3734			.0075	
4	.3429	.3772	.4066	.0019		.0075	
5	.4108	.4527	.4435	.0019		.0075	
6	.4481	.4715	.4805	.0019		.0075	
7	.4481	.6036	.6653	.0019		.0075	
8	.5228	.679	.7682	.0019		.0075	
9	.5228	.7545	.695	.0019		.0075	
10	.0019		.0075	.0019		.0075	
11		.0075	.0019	.7167	.5359	.4108	.2987
12			.0019	.7922	.5544	.5601	.3734
13		.0075	.0019	.7468	.3361	.5601	.6161
14		.0075	.0019	.9242	.3734	.6722	.5601
15		.0075		.9242	.4805	.6348	.5975
16		.0075		.9619	.6722	.6161	
17		.0075	.0019	.8962	.6653	.5975	.5228
18		.0075	.0019	.415	.5544	.5228	.4854
19			.0019		.0075		.0019
20		.0075	.0019		.0075		.0019
21		.0075	.0019		.0075		.0019
22		.0075	.0019		.0075		.0019
23		.0075	.0019		.0075		.0019
24	.2987	.415	.4435	.0019		.0075	
Max	**.5228**	**.7545**	**.7682**	**.9619**	**.6722**	**.6722**	**.6161**
Min	**.0019**	**.0075**	**.0019**	**.0019**	**.0075**	**.0075**	**.0019**
Avg	**.3674**	**.2402**	**.2311**	**.3553**	**.3238**	**.2451**	**.2886**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
GARGOTI[044] BU 7137
Substation No/ Name :- 144022 / 33/11KV PIMPALGAON S/S
Feeder No / Name : 203 / 11 KV ARALGUNDI VG. GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0566	.0377	.0377	.0754	.0377	.0377
2	.0373	.0566	.0373	.0377	.0754	.0377	.0377
3	.0377	.0566	.0373	.0377	.0566	.0373	.0377
4	.0377	.0566	.0377	.0377	.0566	.0377	.0377
5	.0566	.0754	.0373	.0566	.0566	.0373	.0566
6	.0754	.0943	.0747	.0943	.0754	.0934	.0754
7	.1132	.1132	.1132	.0943	.1132	.112	.1132
8	.1132	.132	.112	.1307	.132	.112	.132
9	.1132	.1132	.112	.1132	.1132	.112	.1132
10	.0943	.1132	.112	.1132	.1132	.112	.1132
11	.1132	.0934	.0943	.1132	.0934	.0943	.0943
12	.0943	.0934	.0934	.1132	.1307	.0754	.1132
13	.1132	.0934	.0754	.1132	.0934	.0754	.0943
14	.0943	.0754	.0566	.0943	.0943	.0754	.0754
15	.1132	.0943	.0754	.0754	.0747	.0754	.0943
16	.0943	.0377	.0943	.0754	.0747	.0754	.0754
17	.0943	.0934	.0943	.0566	.0934	.0943	.0943
18	.1509	.0934	.0943	.1132	.1307	.1132	.132
19	.2075		.2075	.2075	.2054	.2263	.2075
20	.2075	.2263	.1886	.2075	.1867	.2075	.2075
21	.2075	.1886	.1509	.1886	.1509	.1307	.1698
22	.1132	.132	.112	.1132	.1132	.1132	.1307
23	.1132	.0377	.0754	.0754	.0747	.0754	.0754
24	.0566	.0566	.0377	.0566	.0754	.0377	.0377
Max	**.2075**	**.2263**	**.2075**	**.2075**	**.2054**	**.2263**	**.2075**
Min	**.0373**	**.0377**	**.0373**	**.0377**	**.0566**	**.0373**	**.0377**
Avg	**.1037**	**.0949**	**.0901**	**.0982**	**.1025**	**.0916**	**.0982**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
GARGOTI[044] BU 7137
Substation No/ Name :- 144022 / 33/11KV PIMPALGAON S/S
Feeder No / Name : 205 / 11 KV BARVE VG GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.132	.0934	.0754	.0754	.0934	.0754
2	.0943	.1132	.0747	.0754	.0754	.0747	.0754
3	.0943	.1132	.0754	.0754	.0754	.0754	.0754
4	.0943	.1132	.0747	.0943	.0943	.0747	.0754
5	.1132	.132	.112	.132	.0943	.112	.1132
6	.1509	.1698	.1848	.1698	.1886	.1867	.1509
7	.1886	.1886	.2772	.1886	.2263	.2427	.2075
8	.2075	.2075	.2033	.2075	.2263	.2033	.1886
9	.2263	.2641	.2614	.2452	.2263	.2427	.2641
10	.2452	.2829	.2772	.2452	.3018	.2587	.2075
11	.2829	.1848	.2452	.2829	.1867	.1886	.2075
12	.2075	.1494	.1886	.2075	.2241	.132	.2452
13	.2263	.168	.2452	.2075		.132	.1698
14	.1886	.112	.1509	.2263	.1307	.132	.1132
15	.2452	.1867	.1509	.2075	.1494	.0754	.1509
16	.1886	.1307	.132	.2075	.2241	.0943	.2075
17	.2263	.2033	.1132	.1886	.112	.1132	.1886
18	.2452	.2054	.2075	.1886	.1494	.1698	.1886
19	.3584		.3584	.3395	.3361	.3018	.3206
20	.3395	.3361	.3584	.3395	.3326	.3395	.3018
21	.3584	.2987	.2641	.3018	.2801	.3174	.2452
22	.2075	.2054	.2075	.2075	.2054	.2263	.2263
23	.1132	.112	.1494	.132	.1307	.1509	.132
24	.1132	.1509	.112	.0943	.0754	.0934	.0943
Max	**.3584**	**.3361**	**.3584**	**.3395**	**.3361**	**.3395**	**.3206**
Min	**.0943**	**.112**	**.0747**	**.0754**	**.0754**	**.0747**	**.0754**
Avg	**.2004**	**.1809**	**.1882**	**.1933**	**.1792**	**.1680**	**.1760**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
GARGOTI[044] BU 7137
Substation No/ Name :- 144023 / 33/11 KV KADGAON SUBSTATION
Feeder No / Name : 202 / 11 KV MHASARANG AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.056	.0549	1.5684	1.1157	1.1222	1.2689
2	.0549	.0543	.0549	1.5912	1.1157	1.1584	1.3032
3	.0549	.0549	.0549	1.6461	1.1888	1.2071	1.406
4	.0549	.0543	.0549	1.7551	1.2127	1.2308	1.5261
5	.0549	.0549	.0549	1.7737	1.3717	1.3756	1.6804
6	.0732	.0549	.0549	1.8298	1.4632	1.5023	1.7661
7	.0709	.0549	.0747	1.9044	1.4632	1.6832	1.8004
8		.056	.0732	1.9204		2.0271	1.8519
9	.0549	.056	.0747	1.7193		1.8461	1.7318
10	.0549	.0549	.0732	.0549		.0549	.0343
11	2.3777	2.396	2.726	.0549		.0343	.0366
12	2.5339	2.7446	2.5606	.0549		.0514	.0366
13	2.552	2.6337	2.8006	.0549		.0514	.0366
14	2.4977	3.0361	2.7069	.0366	.0366	.0514	
15	2.2624	2.9502	2.7984	.0373	.0366	.0514	
16	2.1399	2.9447	2.6886	.0366		.0686	
17	1.9936	2.6326	2.392	.0549	.0543	.0686	
18	1.828	2.1216	2.0485	.0373	.0366	.0514	.0543
19	.0543	.056	.0732		.0543	.0686	.0732
20	.0543	.056	.0747	.0549	.0724	.0514	.0724
21	.0543	.056	.056	.0549	.0543	.0686	.0732
22	.0543	.0549	.0549	.0549	.0543	.0686	.0549
23	.0543	.056	.0549	.0549	.0549	.0514	.0549
24	.0566	.0549	.0549	1.4998	1.1157	1.1222	1.2003
Max	**2.552**	**3.0361**	**2.8006**	**1.9204**	**1.4632**	**2.0271**	**1.8519**
Min	**.0543**	**.0543**	**.0549**	**.0366**	**.0366**	**.0343**	**.0343**
Avg	**.8279**	**.9310**	**.9048**	**.7761**	**.6177**	**.6278**	**.8031**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
GARGOTI[044] BU 7137
Substation No/ Name :- 144023 / 33/11 KV KADGAON SUBSTATION
Feeder No / Name : 204 / 11 KV DONAWADE AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5238	1.6289	1.5364	.0914	.0914	.0905	.0857
2	1.5729	1.6804	1.5364	.0934	.0914	.0905	.0857
3	1.6095	1.5729	1.5546	.0914	.0905	.0905	.0857
4	1.6461	1.6057	1.5546	.0914	.0934	.0905	.0857
5	1.6827	1.6461	1.6461	.0732	.0934	.0905	.0857
6	1.6301	1.7375	1.7177	.0914	.1086	.0905	.1029
7	1.7193	1.8656	1.7741	.0914	.1097	.1097	.1029
8	2.0668	2.0485	1.957	.0914	.112	.1086	.12
9	2.2131	2.3045	2.0485	.128	.1307	.1448	.1372
10	.1097	.1494	.1097	.1097	.112	.1433	.1029
11	.128	.1494	.1494	2.3777	2.5606	2.7692	3.1093
12	.1478	.1463	.128	2.5606	2.5431	2.8292	3.095
13	.1829	.1867	.1463	2.652		2.915	3.3653
14	.1829	.1829	.1494	2.5606	2.3282	.9602	3.4385
15	.181	.1829	.1463	2.6139	2.3998	1.7147	3.2373
16	.1629	.1829	.1646	2.4691	2.5789	2.6578	2.5692
17	.1448	.1463	.1463	2.4508	2.5339	2.692	2.524
18	.1086	.128	.128	2.4086	2.4072	2.4863	2.652
19	.1075	.128	.128	.128	.0914	.1372	.128
20	.1086	.1267	.1097	.112	.1086	.12	.1097
21	.1086	.1097	.1097	.112	.1086	.1372	.0914
22	.1097	.0914	.1097	.1097	.1086	.12	.0549
23	.1086	.0914	.1097	.1086	.0914	.12	.0549
24	1.5546	1.7558	1.4632	.1097	.1097	.0914	.1029
Max	**2.2131**	**2.3045**	**2.0485**	**2.652**	**2.5789**	**2.915**	**3.4385**
Min	**.1075**	**.0914**	**.1097**	**.0732**	**.0905**	**.0905**	**.0549**
Avg	**.7963**	**.8270**	**.7760**	**.9053**	**.8262**	**.8667**	**1.0636**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
GARGOTI[044] BU 7137
Substation No/ Name :- 144023 / 33/11 KV KADGAON SUBSTATION
Feeder No / Name : 205 / 11 KV SHELOLI VG GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2926	.3292	.2926	.3109	.2743	.2534	.2058
2	.3189		.2926	.3109	.2743	.2172	.2058
3	.3292	.2926	.2926	.2926	.2561	.2172	.2058
4	.3658	.2926	.3292	.2801	.2534	.2195	.2229
5	.4024	.3361	.3292	.2926	.2172	.2195	.2401
6	.4024	.3734	.3658	.3292	.2534	.2195	.2401
7	.439	.3658	.3658	.3439	.3801	.2587	.2804
8	.4024	.4108	.439	.3801	.3658	.2614	.3429
9	.439	.4108	.439	.5792	.3982	.3258	.3856
10	.439	.4108	.3734		.4344	.2865	.4115
11	.439	.439	.3658		.3921	.2033	.4024
12	.4525	.4108	.2012		.3258	.2743	.4024
13	.4525	.2987	.3292	.2801		.3086	.1463
14	.4163	.2987	.2012	.2743		.4115	.3658
15	.4024	.3361	.3841	.2987	.362	.3258	.2926
16	.4024	.3734	.3292	.3258	.362	.3086	.2896
17	.3982	.4481	.3658	.3439	.4344	.3772	.3658
18	.5068	.5228	.4207	.4525	.5014	.4115	.4024
19	.6219	.5975	.5853	.5792	.5014	.583	.5121
20	.5853	.6348	.567	.5121	.4706	.4908	.4755
21	.5121	.5601	.439	.4854	.3982	.4115	.439
22	.439	.4481	.3841	.3258	.3439	.3772	.3658
23	.4024	.362	.3475	.2195	.2896	.3086	.362
24	.2987	.3734	.2987	.3292	.3109	.2534	.2629
Max	**.6219**	**.6348**	**.5853**	**.5792**	**.5014**	**.583**	**.5121**
Min	**.2926**	**.2926**	**.2012**	**.2195**	**.2172**	**.2033**	**.1463**
Avg	**.4233**	**.4055**	**.3641**	**.3593**	**.3545**	**.3135**	**.3261**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
GARGOTI[044] BU 7137
Substation No/ Name :- 144023 / 33/11 KV KADGAON SUBSTATION
Feeder No / Name : 206 / 11 KV KARADWADI VG GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	.0732	.0732	.0747			.0686
2	.0732	.0747	.0747	.0747			.0686
3	.0732	.0724	.0732	.0747	.0724		.0686
4	.0914	.0724	.0914	.0747	.0732	.0724	.0857
5	.1097	.1086	.112	.0914	.0724	.1097	.1029
6	.1097	.1097	.1463	.1097	.1086	.1097	.1372
7	.1463	.1097	.1463	.1463	.1448	.1463	.1715
8	.1463	.1086	.1494	.168	.1448	.181	.1928
9	.1463	.1097	.1463	.1448	.1463		.1928
10	.1097	.1097	.1494	.1448	.112	.181	.1928
11	.0914	.1097	.128		.128	.1097	.128
12	.1086	.1097	.1463		.1086	.0857	.128
13	.1267	.112	.0914	.1097		.1029	.0914
14	.1086	.1097	.1097	.1086	.0905	.0686	.1463
15	.0905	.128	.1307	.1267	.0905	.12	.0914
16	.0914	.1307	.0914	.1267	.1086	.12	.1463
17	.1086	.1307	.1463	.1448	.181	.12	.1753
18	.181	.1463	.2012	.2172	.2172	.1543	.2195
19	.2896	.2987	.3292	.2896	.2507	.2743	.2987
20	.2896	.2926	.2926	.2896	.2896	.2743	.2926
21	.2561	.2561	.2614	.2534	.2172	.2229	.2195
22	.2195	.1463	.2241	.1463	.1448	.1715	.1829
23	.1463	.112	.1646	.0747	.1086	.12	.1097
24	.0732	.0732	.0724	.0934			.0857
Max	**.2896**	**.2987**	**.3292**	**.2896**	**.2896**	**.2743**	**.2987**
Min	**.0732**	**.0724**	**.0724**	**.0747**	**.0724**	**.0686**	**.0686**
Avg	**.1358**	**.1294**	**.1480**	**.1402**	**.1405**	**.1444**	**.1499**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
GARGOTI[044] BU 7137
Substation No/ Name :- 144082 / 33/11 KV DARWAD SUBSTATION
Feeder No / Name : 201 / 11 KV MINCHE GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1711	.1331	.1334	.1715	.1143	.1905
2	.1143	.171	.1139	.1143	.1524	.0953	.1715
3	.0953	.1521	.114	.1143	.1524	.0953	.2667
4	.1524	.2662	.1141	.1524	.1715	.1715	.3048
5	.3048	.3605	.1711	.2477	.1715	.2858	.3429
6	.4382	.3993	.2852	.3429	.2858	.381	.3429
7	.4382	.4179		.4382	.4001	.4382	.4001
8	.4763	.4369		.4763	.4572	.4572	.4382
9	.4572	.3993		.4572	.4763	.4382	.4744
10	.4191	.4373		.4954	.4763	.381	.4373
11	.362	.3423		.4001	.362	.3239	.4175
12	.2667	.2614		.4001	.381	.362	.3232
13	.2477	.2464	.3239	.2477	.2667	.2667	
14	.3048	.2654	.3429	.2667	.2477	.2286	
15	.2667	.2662	.4001	.2858	.3239	.2667	
16	.3429	.3232	.4191	.3239	.362	.3048	.3223
17	.4191	.3226	.2286	.4191	.3429	.3429	.3795
18	.4572	.455	.2477	.4572	.4572	.4954	.4753
19	.7811	.7378	.8192	.8192	.8002	.6668	.7415
20	.5716	.6635	.7621	.7049	.7049	.5716	.6256
21	.4572	.5687	.6097	.5335	.6287	.4954	.5704
22	.3048	.3226	.3429	.3239	.4954	.3429	.2852
23	.1905		.1905	.1905	.1715	.2096	.171
24	.1524	.1711	.1521	.1524	.1715	.1524	.1905
Max	**.7811**	**.7378**	**.8192**	**.8192**	**.8002**	**.6668**	**.7415**
Min	**.0953**	**.1521**	**.1139**	**.1143**	**.1524**	**.0953**	**.171**
Avg	**.3397**	**.3547**	**.3206**	**.3540**	**.3596**	**.3286**	**.3748**

 Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
GARGOTI[044] **BU 7137**
Substation No/ Name :- 144082 / 33/11 KV DARWAD SUBSTATION
Feeder No / Name : 202 / 11 KV HEDEWADE AG. **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1521	.171	.3048	.6668	.381	.5121
2	.1143	.1521	.1711	.2477	.6668	.4001	.5121
3	.1143	.1518	.0171	.3429	.6668	.3429	.695
4	.1143	.152	.1711	.381	.6668	.4954	.7316
5	.1143	.152	.0171	.5335	.7049	.7621	.8413
6	.1334	.171	.1711		.8002	.9907	.8779
7	.1334	.1711	.0171	.7811	1.1622	1.2003	1.2437
8	.1143	.1711	.1708	1.2193	1.2955	1.7147	1.2803
9	.1143	.1899		1.2193	1.448	1.6194	1.0773
10	.1463	.1901		.1524	.1334	.128	.1517
11	1.8473	2.4718		.0572	.1334	.128	.1517
12	1.8656	2.3197		.0572	.1334	.128	.152
13	1.9204	2.1852	2.1529	.0572	.1334	.128	
14	1.9022	1.7924	2.3624	.0762	.1334	.1097	
15	1.7193	1.7683	2.1148	.0572	.1334	.1097	
16	1.7741	1.7027	1.7337	.0572	.1334	.1097	.1521
17	1.5364	1.3838	1.3908	.0762	.0762	.1097	.1521
18	1.2986	1.1151	1.0098	.1334	.1524	.1097	.1518
19	.1595	.171	.1334	.1334	.1334	.1097	.133
20	.1646	.1708	.1334	.1334	.1334	.1097	.1331
21	.1646	.1711	.1334	.1334	.1334	.1097	.133
22	.1595	.1708	.1334	.1334	.1334	.128	.1331
23	.1646		.1334	.1334	.1334	.128	.1518
24	.1143	.1521	.1711	.4001	.6668	.4001	.5304
Max	**1.9204**	**2.4718**	**2.3624**	**1.2193**	**1.448**	**1.7147**	**1.2803**
Min	**.1143**	**.1518**	**.0171**	**.0572**	**.0762**	**.1097**	**.133**
Avg	**.6668**	**.7490**	**.6254**	**.2966**	**.4406**	**.4147**	**.4713**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
GARGOTI[044] BU 7137
Substation No/ Name :- 144082 / 33/11 KV DARWAD SUBSTATION
Feeder No / Name : 203 / 11 KV NILPAN AG. SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.0761	.095	.0762	.0953	.0953	.0914
2	.0953	.1711	.0951	.0762	.0953	.0953	.0914
3	.0572	.3803	.0949	.0762	.0953	.0953	.0914
4	.0762	.3795	.0948	.0762	.0953	.0953	.0914
5	.1334	.3803	.112	.0762	.0953	.0953	.0914
6	.1715	.3989	.1521	.0762	.0953	.0953	.0914
7	.2667	.3985	.2654	.0762	.0953	.0953	.0914
8	.5335	.571	.4749	.0953	.0953	.0953	.0914
9	.5906	.5894		.0762	.0953	.0953	.095
10	.0914	.0951		.0953	.1143	.0914	.0949
11		.112		.6478	.8383	.6401	.8342
12				1.0288	.9335	.6767	.9896
13	.0914	.0758	.0762	1.1431	1.0288	.6767	
14	.0914	.076	.0762	1.086	.9907	.6767	
15	.0732	.0761	.0762	.9526	.8002	.6219	
16	.0732	.0948	.0762	.8573	.724	.6036	1.0829
17	.0732	.0951	.0762	.8573	.6859	.4938	1.0067
18	.0732	.0951	.0762	.5906	.4763	.3475	.7567
19	.0732	.0951	.0762	.0953	.0953	.0914	.0761
20	.0732	.0761	.0762	.0953	.0953	.0914	.076
21	.0732	.076	.0762		.0953	.0914	.0951
22	.0732	.076	.0762	.0953	.0953	.0914	.0951
23	.0732		.0762	.0953	.0953	.0914	
24	.1905	.0761	.0951	.0762	.0953	.0953	.0914
Max	**.5906**	**.5894**	**.4749**	**1.1431**	**1.0288**	**.6767**	**1.0829**
Min	**.0572**	**.0758**	**.0762**	**.0762**	**.0953**	**.0914**	**.076**
Avg	**.1446**	**.2029**	**.1159**	**.3661**	**.3342**	**.2599**	**.3012**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
GARGOTI[044] BU 7137
Substation No/ Name :- 144082 / 33/11 KV DARWAD SUBSTATION
Feeder No / Name : 402 / 33 KV Shriram LIS PURELY LIS FEEDERS
Feeder KV- 33 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572				.0572	.0572
2	.0572				.0572	.0572
3	.0572				.0572	.0572
4	.0572				.0572	.0572
5	.0572	.1139			.0572	.0572
6	.0572	.112			.0572	.0572
7	.0572	.114			.0572	.0572
8	.0572	.1141			.0572	.0572
9	.0572	.1141			.0572	.0572
10	.1143	.1141	.0572		.0572	.0572
11	.1143	.112	.0572		.0572	.0572
12	.1143	.114	.0572		.0572	.0572
13	.1143	.114	.0572		.0572	.0572
14	.1143		.0572		.0572	.0572
23	.0572			.0572	.0572	
24	.0572				.0572	.0572
Max	**.1143**	**.1141**	**.0572**	**.0572**	**.0572**	**.0572**
Min	**.0572**	**.112**	**.0572**	**.0572**	**.0572**	**.0572**
Avg	**.0750**	**.1136**	**.0572**	**.0572**	**.0572**	**.0572**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
GARGOTI[044] BU 7137
Substation No/ Name :- 144094 / 33/11 KV TAMBALE SUBSTATION
Feeder No / Name : 201 / 11 KV DASEWADI AG. SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1063		.7545	.7362	.6668	.6068
2	.1063		.7802	.7362	.6668	.6068
3			.7802	.7973	.743	.6135
4	.1075		.7802	.7973	.8573	.631
5	.1075		.7888	.8505	.8573	.631
6	.1075		.7888	.8764	.9717	.631
7	.1086		.9745	.9465	1.0479	.7265
8	.1075		1.2226	1.0517	1.2003	.7619
9	.1075		1.3496	1.1269	1.2384	.9114
10	.1063		.1227	.1029	.1143	.1052
11	1.448		.1214	.1143	.1052	.0191
12	1.5565		.1214	.1143	.1052	.0191
13	1.5912		.1227		.0526	.0953
14	1.6095			.1334	.0857	.0953
15	1.4842	1.5708	.1357	.1143	.0867	.0953
16	1.4998	1.6078	.1187	.1143	.0876	.0953
17		1.4998	.1187	.1334	.0867	.0953
18		1.3535	.1006	.1334	.104	.1143
19		.1294	.1132	.1143	.112	.1143
20		.1294	.112	.1334	.132	.1143
21		.1307	.1109	.1334	.1307	.1143
22		.0716	.1052	.1334	.1267	.1143
23		.0724	.0848	.1334	.12	.1143
24	.1063		.7545	.6935	.6097	.5895
Max	**1.6095**	**1.6078**	**1.3496**	**1.1269**	**1.2384**	**.9114**
Min	**.1063**	**.0716**	**.0848**	**.1029**	**.0526**	**.0191**
Avg	**.6413**	**.7295**	**.4549**	**.4444**	**.4295**	**.3340**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
GARGOTI[044] BU 7137
Substation No/ Name :- 144094 / 33/11 KV TAMBALE SUBSTATION
Feeder No / Name : 202 / 11 KV PATGAON VG. GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0886		.0857	.0876	.0762	.0867
2	.0709		.0693	.0876	.0762	.0693
3	.0709		.0693	.0709	.0762	.0701
4	.0895		.0867	.1063	.0953	.0876
5	.1086		.104	.1063	.1143	
6	.1267		.1214	.1402	.1524	.1227
7	.1991		.1772	.1928	.1905	.1772
8	.197		.1949	.2103	.1905	.1949
9	.2303		.2454	.2254	.2858	.2279
10	.2481		.2804	.2572	.3048	.2804
11	.2353		.2454	.2667	.2481	.2477
12	.2172		.2254	.2286	.1928	.1905
13	.1829		.1928		.1595	.1715
14	.1646		.1886	.2286	.208	.1524
15	.1448	.2218	.2035	.2286	.1753	.1715
16	.1829	.2402	.1526	.2477	.1753	.1905
17		.2402	.2035	.2667	.2279	.2477
18		.2743	.2683	.3239	.2804	.2858
19		.3881	.3961	.4382	.4066	.3048
20		.3881	.3734	.4001	.3961	.362
21		.3511	.3326	.3429	.3174	.3048
22		.2507	.2454	.2477	.1372	.2477
23		.1991	.1696	.1524		.1524
24	.1214		.12	.1214	.1143	.1214
Max	**.2481**	**.3881**	**.3961**	**.4382**	**.4066**	**.362**
Min	**.0709**	**.1991**	**.0693**	**.0709**	**.0762**	**.0693**
Avg	**.1576**	**.2837**	**.1980**	**.2164**	**.2000**	**.1942**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
GARGOTI[044] BU 7137
Substation No/ Name :- 144094 / 33/11 KV TAMBALE SUBSTATION
Feeder No / Name : 203 / 11 KV SHIVDAV AG. SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.443		.0686	.0701	.0953	.104
2	.4784		.0686	.0701	.0953	.104
3	.4835		.0693	.0701	.0953	.1052
4	.5373		.0693	.0709	.0953	.1052
5	.5731		.0693	.0709	.0953	.1052
6	.5792		.0701	.0701	.1143	.1052
7	.6335		.0709	.0701	.1143	.1063
8	.7701		.0709	.0701	.1143	.1052
9	.8059		.0876	.0693	.1143	.1052
10	.0709		.0876	.0857	.1143	.1052
11	.0543		.7362	1.0479	1.0517	1.0669
12	.0362		.7802	1.086	1.134	.9717
13	.0366		.7362		1.0867	1.0288
14	.0366		.823	1.0479	1.0229	1.0479
15	.0362	.0554	.8139	1.0288	1.0341	1.105
16	.0366	.0554	.8309	1.0288	1.0576	1.1241
17		.0739	.7461	1.0288	1.0341	1.1431
18		.0732	.6874	.9907	.964	1.0288
19		.0739	.0754	.9145	.112	.0572
20		.0739	.0857	.0953	.132	.1143
21		.0747	.1109	.0953	.1132	.1143
22		.0716	.1052	.0953	.1086	.1143
23		.0716	.0876	.0953	.1029	.1143
24	.443		.0686	.0867	.0953	.104
Max	**.8059**	**.0747**	**.8309**	**1.086**	**1.134**	**1.1431**
Min	**.0362**	**.0554**	**.0686**	**.0693**	**.0953**	**.0572**
Avg	**.3561**	**.0693**	**.3091**	**.4069**	**.4207**	**.4244**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
HUPARI[042] BU 7111
Substation No/ Name :- 144064 / 33/11 KV HUPARI
Feeder No / Name : 201 / SILVER ZONE GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0171	.0171	2.1534	.6859	.7712	.815
2	.0343	.0171	.0171	1.7465		.7545	.815
3	.0343	.0171	.0171	1.7804	.6859	.7545	.7973
4	.0343	.0171	.0171	1.8652	.6859	.7545	.7973
5	.0171	.0171	.0171	1.8821	.6859	.7545	.7973
6	.0171	.0171	.0171	1.8991	.6859	.7545	.815
7	.0171	.0171	.0171	1.6956	.6859	.7712	.8859
8	.0343	.0171	.0171	1.6956	.8573	.788	.8682
9	.0343		.8139	1.749	1.0608	.9568	.8328
10	.0343		.9665	1.7833	1.1233	.9671	1.2003
11	.0171		1.0682	1.869	1.0562	.9745	1.2003
12	.0171	.0162	1.0004	1.3717	1.2071	.9214	1.2689
13	.0171		.9156	1.3717	1.0277	.9391	1.2003
14	.0171		.8817	1.2003	1.094	.9745	1.2003
15	.0171		1.0343	.0171	1.1603	.9036	1.2517
16	.0171		1.0004	.0171	.9282	.8328	1.2517
17	.0171		.8987	.0171	.8718	.9036	1.3546
18	.0171		.8817	.0171	1.2574	.8505	.9259
19	.0171			.6859	.9145	1.0099	.8573
20	.0171		2.2043	.6859	.8551	.9214	.8573
21	.0171		2.1704	.6859	.9221	.8505	.823
22	.0171		2.0348	.823	.7459	.7973	.7888
23	.0171		2.0687	.8402	.7625	.7973	
24	.4694	.0171	.0343	2.1195	.6859	.7712	.815
Max	**.4694**	**.0171**	**2.2043**	**2.1534**	**1.2574**	**1.0099**	**1.3546**
Min	**.0171**	**.0162**	**.0171**	**.0171**	**.6859**	**.7545**	**.7888**
Avg	**.0402**	**.0170**	**.7874**	**1.2488**	**.8976**	**.8531**	**.9747**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
HUPARI[042] BU 7111
Substation No/ Name :- 144064 / 33/11 KV HUPARI
Feeder No / Name : 202 / HUPARI VILLAGE GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5959	.6859	.7087	.5434	.6859	.5784	.5249
2	.6135	.6859	.6733	.5258	.6859	.5258	.5068
3	.631	.6859	.6201	.5784	.6859	.5258	.5068
4	.6135	.6859	.567	.5959	.6859	.631	.5611
5	.6485	.8573	.5609	.6135	.6859	.6485	.6089
6	.6485	.8573	.6135	.6135	.8573	.6485	.6805
7	.7362	.8573	.7186	.7888	.6859	.7888	.8682
8	.8764	.8745	.9214	.9114	.8402	.9114	.9214
9	.9088		.964	.9774	.929	.9391	.9391
10	1.0631		1.0166	1.0288	.8764	.9745	1.0288
11	1.0631		1.1218	1.046	1.1043	1.0808	1.0288
12	1.1145	.8248	1.1568	1.0288	1.0867	1.134	1.1488
13	1.1145		1.1043	1.0288	1.1218	.9036	1.0631
14	1.1145		.8589	.9945	.8764	.8505	1.0631
15	1.1145		.9465	.9945	.9465	.9568	.9774
16	1.0288		1.0517	.9602	.9991	1.0277	1.0288
17	1.1145		1.1043	1.0288	1.0867	1.0099	1.0288
18	1.286		1.3321	1.1145	1.2971	1.3289	1.2689
19	1.3717			1.0288	1.2269	1.4883	1.0288
20	1.0288		1.5249	1.0288	1.0867	1.3998	1.0288
21	1.0288		1.4022	.6859	1.1218	1.2048	1.0288
22	.9945		1.2445	.6859		.9922	.8916
23	.6344		.5258	.6516	.5609	.691	
24	.567	.6859	.7362	.5784	.6859	.5784	.543
Max	**1.3717**	**.8745**	**1.5249**	**1.1145**	**1.2971**	**1.4883**	**1.2689**
Min	**.567**	**.6859**	**.5258**	**.5258**	**.5609**	**.5258**	**.5068**
Avg	**.9130**	**.7701**	**.9337**	**.8347**	**.9052**	**.9091**	**.8815**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
HUPARI[042] BU 7111
Substation No/ Name :- 144064 / 33/11 KV HUPARI
Feeder No / Name : 203 / YALGUD AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4588	.5144	.431	.0343	.0343	.0343	.0343
2	.4588	.6859	.4641	.0343	.0343	.0343	.0343
3	.4915	.6859	.4641	.0343	.0343	.0343	.0343
4	.4915	.6859	.4475	.0343	.0343	.0343	.0343
5	.4915	.6859	.4475	.0343	.0343	.0343	.0343
6	.4915	.6859	.4641	.0343	.0343	.0343	.0343
7	.6299	.7716	.5304	.0343	.0343	.0343	.0343
8	.7127	.7716	.663	.0343	.0343	.0343	.0343
9	.7716		.7459	.0343	.0343	.0343	.0343
10	.0171		.0343	.0343	.0343	.0343	.0343
11	.0171		.0343	.9774	1.073	.9831	1.0288
12	.0171	.0162	.0171	1.0288	1.073	.9995	1.0631
13	.0171		.0171	1.0288	1.1401	1.0159	1.0288
14	.0171			.9774	1.0227	1.0159	1.0288
15	.0171			.9774	1.0562	.9339	
16	.0171			.8916	1.0059	.9175	1.0288
17	.0171			.8573	1.0004	.9012	.8916
18	.0171			.7888	.9665	.852	.8059
19	.0171			.0343	.0343	.0328	.0343
20	.0171		.0343	.0343	.0343	.0328	.0343
21	.0171		.0343	.0343	.0343	.0492	.0343
22	.0171		.0343	.0343	.0343	1.3435	.0343
23	.0171		.0343	.0343	.0343	.0343	
24	.4588	.5144	.4973	.0343	.0343	.0343	.0343
Max	**.7716**	**.7716**	**.7459**	**1.0288**	**1.1401**	**1.3435**	**1.0631**
Min	**.0171**	**.0162**	**.0171**	**.0343**	**.0343**	**.0328**	**.0343**
Avg	**.2373**	**.6018**	**.2997**	**.3365**	**.3703**	**.3954**	**.3359**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
HUPARI[042] BU 7111
Substation No/ Name :- 144064 / 33/11 KV HUPARI
Feeder No / Name : 204 / RENDAL SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1869	1.3717	1.4022	1.3717	1.5432		1.4175
2	1.1869	1.3717	1.2269	1.3717	1.5432	1.5432	1.2536
3	1.1869	1.3717	1.0517	1.2003	1.5432	1.5432	1.0974
4	1.1869	1.3717	1.0517	1.2003	1.5432	1.3717	1.0974
5	1.1869	1.3717	1.4022	1.2003	1.5432	1.3717	1.0974
6	1.1869	1.5432	1.4022	1.2003	1.5432	1.3717	1.2803
7	1.3565	1.5432	1.5775	1.6956	1.5432	2.0348	1.6118
8	1.5261	2.0576	2.0576	2.0348	1.2003	2.2043	1.5947
9	2.4006		2.5149	2.7435	1.9662	2.6216	1.7147
10	2.915		3.0178	2.915	2.6216	2.7854	1.3717
11	2.915		3.0178	3.0864	2.8826	2.9492	1.3717
12	2.915	2.9218	3.0178	3.0864	2.713	2.9492	1.0288
13	2.7435		1.7147	3.0864	1.5089	1.949	1.0288
14	2.7435		1.5089	3.0864	2.1795	1.8099	1.0288
15			2.6825	3.0864	2.8826	2.7854	1.0288
16	2.915		2.8502	3.0864	2.8826	2.7854	1.0288
17	2.915		2.8502	2.915	2.8826	2.7854	
18	2.7435		2.8178	2.915	3.2217	2.7854	1.0288
19	2.7435		2.5434	2.7435	2.5434	2.4291	1.0288
20	2.7435		2.0348	2.7435	1.5261	2.1262	1.0288
21	2.0576		1.2003	2.4006	1.8652	1.949	1.2003
22	1.7147		1.2003	1.7147	1.3413	1.949	1.2003
23	1.3717		1.3717	1.5432	1.5089	1.7718	
24	1.1869	1.3717	1.5775	1.3717	1.5432	1.5432	1.5947
Max	**2.915**	**2.9218**	**3.0178**	**3.0864**	**3.2217**	**2.9492**	**1.7147**
Min	**1.1869**	**1.3717**	**1.0517**	**1.2003**	**1.2003**	**1.3717**	**1.0288**
Avg	**2.0447**	**1.6296**	**1.9622**	**2.2416**	**2.0030**	**2.1485**	**1.2334**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
HUPARI[042] BU 7111
Substation No/ Name :- 144064 / 33/11 KV HUPARI
Feeder No / Name : 207 / HUPARI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0171	.0343	.8383	.8573	.8987	.9259
2	.0171	.0343	.0343	.8718	.8573	.9326	.9602
3	.0171	.0343	.0343	.9054	1.0288	.9496	.9602
4	.0343	.0343	.0343	.9221	1.0288	.8478	.9602
5	.0343	.0343	.0343	.9221	1.0288	1.0004	.9774
6	.0343	.0343	.0343	.9556	1.0288	1.0004	1.0117
7	.0343	.0343	.0343	1.0059	1.2346	1.1361	1.0802
8	.0343	.0343	.0343	1.0562	1.2517	1.153	1.0802
9	.0343		.0343	1.166	1.2209		1.1488
10	.0343		.0343	.0171	.0343	.0343	.0343
11	1.1831		1.4083	.0171	.0343	.0343	.0343
12	1.4918	1.7044	1.4251	.0171	.0343	.0343	.0343
13	1.5089		1.6598	.0171	.0343	.0343	.0343
14	1.4918		1.8404	.0171	.0343	.0343	.0343
15	1.4403		1.858	.0171	.0171	.0343	.0343
16	1.4918		1.7878		.0171	.0343	.0343
17	1.2689				.0343	.0343	.0343
18	1.3889			.0171	.0343	.0343	.0343
19	.0343			.0171	.0343	.0343	.0343
20	.0343		.0343	.0171	.0343	.0343	.0343
21	.0343		.0343	.0343	.0343	.0343	.0343
22	.0343		.0343	.0343	.0343	.0343	.0343
23	.0171		.0343	.0343	.0343	.0343	
24	.0343	.0343	.0343	.8048	.8573	.8817	.9259
Max	**1.5089**	**1.7044**	**1.858**	**1.166**	**1.2517**	**1.153**	**1.1488**
Min	**.0171**	**.0171**	**.0343**	**.0171**	**.0171**	**.0343**	**.0343**
Avg	**.4901**	**.1996**	**.4997**	**.4411**	**.4517**	**.4035**	**.4555**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
HUPARI[042] BU 7111
Substation No/ Name :- 144064 / 33/11 KV HUPARI
Feeder No / Name : 208 / BIRDEV AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0171	.0171	.3647	.5144	.3113	.3932
2	.0171	.0171	.0171	.3812	.5144	.3277	.3932
3	.0171	.0171	.0171	.3812	.5144	.3277	.3932
4	.0171	.0171	.0171	.3812	.5144	.3441	.4096
5	.0171	.0171	.0171	.3978	.583	.3481	.426
6	.0171	.0171	.0171	.3978	.583	.3481	.426
7	.0171	.0171	.0171	.4973	.583	.4641	.5243
8	.0171	.0171	.0171	.5636	.583	.4807	.5735
9	.0171		.0171	.6173	.5765	.5365	.5898
10	.0171		.0171	.0171	.0171	.0343	.0171
11	1.0288		.8785	.0171	.0171		.0171
12	1.0288	.9577	.9116	.0171	.0171	.0343	.0171
13	1.0288		.8619	.0171	.0171	.0343	.0171
14	1.0288		.8288		.0171	.0171	.0343
15	1.0288		.779		.0171	.0171	.0171
16	.9945		.7459	.0171	.0166		.0171
17	.9602		.6796	.0171	.0171		.0171
18	.8573		.6796	.0171	.0171		.0171
19	.0171		.0343	.0171	.0171	.0343	.0171
20	.0171		.0343	.0171	.0171	.0343	.0171
21	.0171		.0343	.0171	.0171	.0343	.0171
22	.0171		.0343	.0171	.0343	.0171	.0171
23	.0171		.0343	.0171	.0343	.0171	
24	.0171	.0171	.0171	.3647	.5144	.2949	.3768
Max	**1.0288**	**.9577**	**.9116**	**.6173**	**.583**	**.5365**	**.5898**
Min	**.0171**	**.0171**	**.0171**	**.0171**	**.0166**	**.0171**	**.0171**
Avg	**.3429**	**.1112**	**.2802**	**.2069**	**.2397**	**.2029**	**.2063**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
HUPARI[042] BU 7111
Substation No/ Name :- 144065 / 33/11 KV S/ST PATTANKODOLI
Feeder No / Name : 201 / PATTANKODOLI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8059	.8402	.9335	.0514		.0514	.056
2	.8059	.8402	.8402	.0514		.0514	.056
3	.7716	.823	.8402	.0514		.0514	.056
4	.7716	.823	.8029	.0514		.0514	.056
5	.823	.8573	.8402	.0514		.0514	.056
6	.9088	.9088	.8402	.0514		.0514	.056
7	1.1317	1.1488	1.0269	.0514		.0514	.056
8	1.2174	1.3032	1.0829	.0514		.0514	.056
9	1.3032	1.3889	1.3443	.0514		.0514	.056
10			.056	.0514	.0514	.0514	.056
11	.0343	.0343		2.2291	2.3491	2.726	2.332
12			.0343	2.2291	2.3491	2.8753	2.332
13	.0343			2.2291	2.3148	2.5579	2.332
14		.0343	.0343	2.2291	2.3148	2.6699	2.332
15				2.0919	2.452	2.7633	2.2977
16		.0343	.0343	2.0919	2.452	2.3712	2.2977
17	.0343	.0343	.0343	2.0919	2.452	2.2779	2.1262
18	.0343		.0514	.0514	2.1605	1.9978	1.6461
19	.0686	.0747	.0514	.0514	.0514	.056	.0514
20	.0514	.056	.0514	.0514	.0514	.056	.0514
21	.0514	.056	.0514	.0514	.0514	.056	.0514
22	.0686	.056	.0514	.0514	.0514	.056	.0514
23	.0514	.056	.0514			.056	.0514
24	.8402	.8402	.9896	.0514	.0514	.0514	.056
Max	**1.3032**	**1.3889**	**1.3443**	**2.2291**	**2.452**	**2.8753**	**2.332**
Min	**.0343**	**.0343**	**.0343**	**.0514**	**.0514**	**.0514**	**.0514**
Avg	**.5162**	**.5373**	**.4782**	**.6963**	**1.3681**	**.8785**	**.7737**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
HUPARI[042] BU 7111
Substation No/ Name :- 144065 / 33/11 KV S/ST PATTANKODOLI
Feeder No / Name : 202 / 11 kV INGALI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0171	.0187	.6001	.5316	.4973	.4854
2	.0171	.0171	.0187	.583	.5316	.4973	.4668
3	.0171	.0171	.0187	.583	.5316	.4973	.4668
4	.0171	.0171	.0187	.583	.5658	.4973	.5601
5	.0171	.0343	.0187	.6516	.6001	.5144	.5601
6	.0171	.0343	.0373	.7545	.6516	.5658	.5788
7	.0171	.0343	.0373	.9259	.7545	.6859	.6348
8	.0171	.0343	.0373	.8916	.8745	.8402	.7842
9	.0171	.0343	.0373	.8916	.823	.8402	.7842
10			.0373	.0343	.0343	.0343	.0373
11	1.2003	1.4403	1.5089			.0373	
12	.8573	1.5432	1.5089	.0171	.0171	.0373	.0171
13	1.0288	1.5432	1.5089		.0171	.0373	
14	1.286	1.6118	1.3717			.0373	
15	1.286	1.4746	1.3717			.0373	
16	1.286	1.4746	1.3717	.0171		.0373	
17	1.286	1.5089	1.3717	.0171	.0171	.0373	.0171
18	1.2174		1.2517	.0343	.0171	.0373	.0171
19	.0514	.0373	.0343	.0343	.0686	.0373	.0343
20	.0343	.0373	.0343	.0343	.0686	.0373	.0343
21	.0343	.0373	.0343	.0343	.0686	.0373	.0343
22	.0343	.0373	.0343	.0343	.0514	.0373	.0343
23	.0343	.0373	.0343			.0373	.0343
24	.0171	.0343	.0187	.6001	.5658	.4973	.5228
Max	**1.286**	**1.6118**	**1.5089**	**.9259**	**.8745**	**.8402**	**.7842**
Min	**.0171**	**.0171**	**.0187**	**.0171**	**.0171**	**.0343**	**.0171**
Avg	**.4264**	**.5026**	**.4890**	**.3853**	**.3574**	**.2688**	**.3213**

 Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
HUPARI[042] **BU 7111**
Substation No/ Name :- 144065 / 33/11 KV S/ST PATTANKODOLI
Feeder No / Name : 203 / 11 kV SANGWADE AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.166	.8573	.9709	.0686	.0686	.1029	.0934
2	1.1831	.8573	.9335	.0686	.0686	.1029	.0934
3	1.1488	.823	.9335	.0686	.0686	.1029	.0934
4	1.1488	.823	.9335	.0686	.0686	.1029	.0934
5	1.1831	.8916	.9335	.0686	.0686	.1029	.0934
6	1.2346	.9945	.9522	.0686	.0686	.12	.0934
7	1.4918	1.3203	1.2323	.0857	.12	.12	.1494
8	1.4918	1.5261	1.4003	.1029	.1029	.1029	.1494
9	1.4746	1.6461	1.531	.0857	.12	.1029	.1494
10			.0934	.1029	.1543	.1029	.1307
11	.0686	.0686	.0686	2.332	2.1776	2.3712	2.0576
12	.0686	.0686	.0686	2.332	2.1776	2.5393	2.0576
13	.0686	.0686	.0686	2.332	2.1776	2.0911	2.0576
14	.0686	.0686	.0686	2.332	2.2291	2.2032	2.0576
15	.0686	.0686	.0686	2.2291	2.2634	2.2405	2.2634
16	.0686	.0686	.0686	2.2291	2.2805	2.1472	2.2634
17	.0686	.0686	.0686	2.2291	2.2805	2.1098	2.1262
18	.0686		.0686	2.0748	1.9376	2.0165	1.8176
19	.1029	.1307	.0857	.0343	.0514	.1494	.1372
20	.1029	.112	.0857		.12	.1494	.12
21	.1029	.112	.0857		.12	.1307	.12
22	.0857	.0934	.0686		.12	.112	.12
23	.0857	.0934	.0686			.112	.12
24	1.1317	.8573	1.0269	.0686	.1029	.1029	.0934
Max	**1.4918**	**1.6461**	**1.531**	**2.332**	**2.2805**	**2.5393**	**2.2634**
Min	**.0686**	**.0686**	**.0686**	**.0343**	**.0514**	**.1029**	**.0934**
Avg	**.5949**	**.5281**	**.4952**	**.9491**	**.8238**	**.8141**	**.7730**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
HUPARI[042] BU 7111
Substation No/ Name :- 144065 / 33/11 KV S/ST PATTANKODOLI
Feeder No / Name : 204 / 11 KV INGALI VILLAGE GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0514	.0747	.0514	.0514	.0514	.0747
2	.0514	.0514	.0747	.0514	.0514	.0514	.0747
3	.0514	.0514	.0747	.0514	.0514	.0514	.0747
4	.0514	.0514	.0747	.0514	.0514	.0514	.0747
5	.0857	.0686	.112	.0857	.0857	.0857	.112
6	.1715	.1543	.1494	.1372	.1372	.12	.168
7	.1543	.1715	.1867	.1543	.1543	.1543	.168
8	.1372	.1372	.1494	.1543	.1543	.1543	.1867
9	.1372	.1372	.168	.12	.1372	.1543	.168
10			.1307	.12	.1372	.12	.1494
11	.0857	.0857	.12	.0857	.1029	.1307	.1029
12	.0857	.0857	.1029	.0857	.1029	.0934	.1029
13	.0857	.0857	.1029	.0857	.1029	.112	.1029
14	.0857	.0857	.1029	.0857	.1029	.0934	.1029
15	.0857	.0857	.1029	.0857	.1372	.112	.0857
16	.0857	.0857	.1029	.0857	.1029		.0857
17	.0857	.0857	.1029	.0857	.1029	.0934	.0857
18	.0857		.1029	.0857	.1029	.112	.0857
19	.1715	.2054	.1886	.1543	.1715	.1867	.1715
20	.1543	.168	.1715	.1372	.1543	.168	.1372
21	.12	.1494	.1372	.12	.12	.1494	.12
22	.1029	.1307	.0857	.0857	.1029	.112	.0857
23	.0686	.0747	.0686			.112	.0686
24	.0514	.0514	.0747	.0514	.0514	.0514	.0934
Max	**.1715**	**.2054**	**.1886**	**.1543**	**.1715**	**.1867**	**.1867**
Min	**.0514**	**.0514**	**.0686**	**.0514**	**.0514**	**.0514**	**.0686**
Avg	**.0976**	**.1025**	**.1151**	**.0961**	**.1074**	**.1096**	**.1117**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
HUPARI[042] BU 7111
Substation No/ Name :- 144065 / 33/11 KV S/ST PATTANKODOLI
Feeder No / Name : 205 / 11 KV SANGAWADE VG GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2058	.2801	.1886	.2058	.2058	.2241
2	.2058	.1886	.2801	.1886	.2058	.2058	.2241
3	.2058	.1886	.2801	.1886	.2058	.2058	.2241
4	.2058	.1886	.2801	.1886	.2058	.2058	.2801
5	.2572	.2743	.3734	.2229	.2401	.2743	.3734
6	.3944	.4287	.4668	.3086	.3086	.3944	.4668
7	.6344	.6344	.6348	.4801	.6516	.6859	.6908
8	.7202	.6001	.7095	.5316	.6687	.8059	.7655
9	1.0117	.6687	1.531	.5487	.9088	1.0117	.7095
10			1.1016	.4458	1.0631	1.3203	1.1763
11	1.0974	1.3717	1.0974	.3429	1.1317	1.3256	1.1317
12	1.0974	1.2003	1.0974	.3429	1.1317	1.1763	1.1317
13	1.0974	1.2003	1.0974	.3429	1.1317	.5415	1.1317
14	1.0974	1.2003	1.0974	.3429	1.166	.5975	1.1317
15	1.2003	1.2003	1.0974	.3429	1.0974	1.0456	1.1317
16	1.2003	1.2003	1.0974	.3429	1.0802	1.1389	1.1317
17	1.2003	1.2003	1.0974	.3429	1.0631	.9335	1.1317
18	1.0631		1.166	.3772	1.0974	1.1576	1.0288
19	.7202	.8962	.583	.4801	.6001	.6722	.7888
20	.583	.6535	.5144	.4801	.4973	.7095	.5658
21	.5144	.6535	.4801	.4287	.4458	.6535	.5144
22	.4458	.5601	.3429	.3429	.3601	.5041	.4115
23	.3086	.3734	.3086			.3734	.2915
24	.2058	.2058	.2801	.1886	.2058	.2058	.2801
Max	**1.2003**	**1.3717**	**1.531**	**.5487**	**1.166**	**1.3256**	**1.1763**
Min	**.2058**	**.1886**	**.2801**	**.1886**	**.2058**	**.2058**	**.2241**
Avg	**.6814**	**.6952**	**.7206**	**.3474**	**.6814**	**.6813**	**.7057**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
HUPARI[042] BU 7111
Substation No/ Name :- 144065 / 33/11 KV S/ST PATTANKODOLI
Feeder No / Name : 206 / 11 KV PATTANKODOLI VLG GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915		.3734	.2915	.2915	.2743	.3174
2	.2572		.3361	.2915	.2915	.2743	.3174
3	.2572	.2572	.3361	.2915	.2915	.2743	.3174
4	.2572	.2572	.3361	.2915	.3086	.2743	.3174
5	.3086	.3258	.3361	.3429	.3772	.3601	.3734
6	.5316	.5658	.5041	.4801	.4973	.5144	.4854
7	.7545	.6687	.7095	.7202	.6859	.6859	.6908
8	.703	.5658	.8029	.7716	.6859	.7202	.7655
9	.6687	.5144	.7468	.7545	.6344	.7202	.7468
10			.6722	.6687	.5487	.5658	.6722
11	.6173	.5144	.6173	.5487	.5487	.5975	.5487
12	.6173	.5144	.6173	.5487	.5487	.5975	.5487
13	.6173		.6173	.5487	.5487	.5415	.5487
14	.5487	.5144	.5487	.5487	.5487	.4294	.5144
15	.5487	.5144	.5487	.5144	.5144	.4294	.5144
16	.5487	.5144	.5487	.5144	.5144	.4668	.5144
17	.5487	.5487	.5487	.583	.5487	.6161	.583
18	.5487		.7888	.6516	.6859	.8029	.6516
19	.9088	1.0082	.583	.8745	.9088	1.0456	1.0117
20	.8573	.9149	.8402	.8573	.8916	.9522	.9259
21	.7202	.8775	.7888	.7545	.7888	.8775	.703
22	.6001	.8402	.6173	.5658	.6173	.5975	.4973
23	.3601	.5601	.3601			.3734	.3429
24	.2915	.2743	.3734	.3086	.2915	.2915	.3174
Max	**.9088**	**1.0082**	**.8402**	**.8745**	**.9088**	**1.0456**	**1.0117**
Min	**.2572**	**.2572**	**.3361**	**.2915**	**.2915**	**.2743**	**.3174**
Avg	**.5375**	**.5658**	**.5647**	**.5532**	**.5465**	**.5534**	**.5511**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
HUPARI[042] **BU 7111**
Substation No/ Name :- 144076 / 33/11 KV RANGOLI
Feeder No / Name : 201 / 11 KV BRAMHANATH AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1633	1.0395	.9614	.0343	.0503	.0332	.0663
2	1.1336	1.1317	.9614	.0503	.0514	.0497	.0648
3	1.1336	1.1568	.9614	.0492	.0492	.0497	.064
4	1.1633	1.1469	1.0059	.048	.0469	.0497	.0655
5	1.1498	1.1904	.9945	.0663	.048	.0497	.0678
6	1.3203	1.2689	1.0277	.0655	.0486	.0497	.0838
7	1.3203	1.3321	1.1768	.0663	.0492	.0497	.0819
8	1.6032	1.3466	1.3077	.0648	.0492	.0497	.0663
9	1.7164	1.6409	1.4083	.064	.0503	.0497	.0492
10	.0434	.032	.0332	.0492		.0486	.0474
11	.0373	.0332	.0754	1.9993	1.8233	2.0748	1.8861
12	.0377	.0332	.0754	2.1125	1.873	2.1125	1.9993
13	.0373	.0332	.0754	2.1125	1.8233	2.0748	1.9993
14	.0362	.0332	.0566	2.0351	1.7404	2.037	1.9993
15	.0362	.0332	.0566	2.0748	1.7404	1.9993	1.7918
16	.0343	.0332	.0566	2.0748	1.6078	1.9616	1.9239
17	.0526	.0324	.0566	2.037	1.6907	1.9239	1.9993
18	.0537	.0497	.0566	1.9239	1.576	1.8861	1.7918
19	.0503	.0497	.0492	.0655	.0497	.0497	.0543
20	.0492	.0497	.0324	.0671	.0503	.0486	.0543
21	.0469	.0503	.0332	.0625	.0503	.0503	.0549
22	.0492	.0332	.0339	.064	.0497	.0514	.0492
23		.0335	.0343		.0503	.052	.0492
24	1.1336	1.0288	.9945	.0351	.0497	.0335	.0514
Max	**1.7164**	**1.6409**	**1.4083**	**2.1125**	**1.873**	**2.1125**	**1.9993**
Min	**.0343**	**.032**	**.0324**	**.0343**	**.0469**	**.0332**	**.0474**
Avg	**.5827**	**.5338**	**.4802**	**.7488**	**.6356**	**.7015**	**.6817**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
HUPARI[042] **BU 7111**
Substation No/ Name :- 144076 / 33/11 KV RANGOLI
Feeder No / Name : 202 / 11 KV PANCHGANGA AG **FEEDER SEPERATION/PURE AG**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.8916	1.1736	1.0526	.8619
2				.9054		1.0774	.8745
3						1.0608	.8962
4						1.0608	.9503
5						1.0608	1.0174
6						1.1105	1.0562
7						1.1568	1.0978
8						1.1984	1.1105
9						1.2431	1.1142
11	1.5497	1.6409	1.7353				
12	1.6975	1.6078	1.6975				
13	1.6787	1.5746	1.7353				
14	1.1765	1.5746	1.773				
15	1.1765	1.5581	1.8107				
16	1.1145	1.6409	1.7918				
17	1.2269	1.4083	1.7541				
18	1.5581	1.4089	1.7164				
19					1.0898		
23					1.1065		
24				.8413	1.1437	1.094	.823
Max	**1.6975**	**1.6409**	**1.8107**	**.9054**	**1.1736**	**1.2431**	**1.1142**
Min	**1.1145**	**1.4083**	**1.6975**	**.8413**	**1.0898**	**1.0526**	**.823**
Avg	**1.3973**	**1.5518**	**1.7518**	**.8794**	**1.1284**	**1.1115**	**.9802**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
HUPARI[042] BU 7111
Substation No/ Name :- 144076 / 33/11 KV RANGOLI
Feeder No / Name : 203 / 11 KV RANGOLI VILLAGE GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1311	.1174	.1326	.2058	.1174	.1492	.1989
2	.1134	.12	.1341	.2012	.12	.1326	.1943
3	.1134	.1402	.1457	.2294	.1147	.1326	.208
4	.1147	.1147	.1658	.2401	.125	.1341	.2294
5	.1296	.1677	.2012	.2155	.16	.1492	.2713
6	.1698	.2572	.2321	.2294	.2267	.2321	.285
7	.3206	.3155	.3149	.2155	.2949	.2818	.3113
8	.3395	.3366	.2984	.2267	.3113	.2818	.3315
9	.3961	.3395	.2818	.2401	.3353	.2984	.3277
10	.2606	.3041	.3149	.2458		.2652	.3961
11	.3547	.3315	.3772	.2829	.3185	.2641	.3018
12		.2652	.3584	.2641	.3185	.2829	.3206
13	.2452	.2321	.3395	.2263	.2347	.3018	.2263
14	.2715	.2321		.2427	.285	.3206	.2641
15	.2896	.2984	.3584	.2641	.285	.3584	.2829
16	.2743	.3149	.3772	.3395	.3149	.3395	.3018
17	.3856	.3185	.3584	.3018	.3185	.3772	.3018
18	.394	.3149	.3961	.2641	.3185	.415	.3395
19	.4024	.3315	.3605	.2622	.3812	.3812	.3801
20	.3605	.3315	.3725	.2515	.3315	.3077	.3801
21	.3125	.3315	.3315	.2187	.3315	.285	.2743
22	.2949	.2683	.2883	.192	.3353	.2572	.2294
23		.1989	.2572		.2347	.2254	.2294
24	.1619	.12	.1492	.2279	.1492	.1823	.1886
Max	**.4024**	**.3395**	**.3961**	**.3395**	**.3812**	**.415**	**.3961**
Min	**.1134**	**.1147**	**.1326**	**.192**	**.1147**	**.1326**	**.1886**
Avg	**.2653**	**.2543**	**.2846**	**.2429**	**.2592**	**.2648**	**.2823**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
HUPARI[042] BU 7111
Substation No/ Name :- 144085 / 33/11KV YELGUD SUBSTATION
Feeder No / Name : 201 / 11 KV YELGUD VG GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1629	.1509	.1663	.1629	.1494	.1663	.1509
2	.1448	.132	.1646	.1448		.1463	.132
3	.1448	.1307	.1463	.1267	.1294	.1463	.1307
4	.1448	.1307	.1463	.1267	.1294	.1629	.1307
5	.1629	.1494	.1629	.1612	.1463	.181	.1829
6	.2303	.1867	.1991	.2126	.1629	.197	.2328
7	.2658	.2801	.2507	.2658	.2454	.2303	.2629
8	.2835	.2835	.2835	.2229	.3018	.3155	.2883
9	.2658	.2804		.2743	.2818	.2601	.2515
10	.3109	.3582	.3048	.3584		.2829	.2641
11	.3018	.3258	.3185	.2743	.2883	.2713	.2515
12	.3018	.2915	.285	.2374	.3018	.3052	.2984
13	.2486	.285	.218	.3018	.2683	.2543	.285
14	.2012	.2515	.2347	.2543	.2515	.2543	.2543
15	.2012	.2683	.2713	.1886	.2347	.2683	.2204
16	.2515	.2683	.2543	.2229	.2543	.2683	.2713
17		.2347	.2652	.2572	.2883	.218	.2883
18	.2374	.2401	.2683	.208	.2401	.2713	.2858
19		.3206	.3239	.2858	.3429	.3239	.3239
20	.3239	.3048	.2987	.2858	.3048	.3429	.3048
21	.2858	.2858	.2801	.3048	.2858	.3429	.3048
22	.2477	.2286	.2241	.2075	.2477	.2286	.2286
23		.2096	.2054	.1886	.2096	.2096	.2075
24	.181	.1698	.1867	.1867	.1867	.1905	.1905
Max	**.3239**	**.3582**	**.3239**	**.3584**	**.3429**	**.3429**	**.3239**
Min	**.1448**	**.1307**	**.1463**	**.1267**	**.1294**	**.1463**	**.1307**
Avg	**.2333**	**.2403**	**.2373**	**.2275**	**.2387**	**.2433**	**.2392**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
HUPARI[042] BU 7111
Substation No/ Name :- 144085 / 33/11KV YELGUD SUBSTATION
Feeder No / Name : 202 / LAXMI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0181	.2829	.2402		.0187	.0185	.0189
2	.0181	.2641	.2561	.0181	.0187	.0183	.0189
3	.0181	.2614	.2561	.0181	.0185	.0183	.0187
4	.0181	.2801	.2481	.0181	.0185	.0183	.0187
5	.0181	.2801	.2658	.0358	.0183	.0181	.0183
6	.0177	.2987	.3012	.0354	.0181	.0181	.0179
7	.0177	.4294	.3189	.0177	.0175	.0177	.0175
8	.2481	.3721	.4031	.0171	.0168	.0175	.017
9	.3189	.4031	.2715	.0171	.0166	.0173	.0168
10		.0179	.0191	.0189		.0187	.0189
11	.0168	.0171	.0168	.5658	.5533	.5596	.57
12	.0168	.0171	.0168	.6613	.5868	.6274	.6299
13	.0166	.0168	.0168	.7209	.6203	.6443	.6371
14	.0168	.0168	.0168	.7461	.6539	.6443	.6443
15	.0168	.0168	.017	.7202	.6539	.57	.6104
16	.0168	.0168	.017	.6859	.6613	.5868	.5765
17		.0168	.0166	.6344	.5596	.5365	.5256
18	.017	.0171	.0168	.5721	.4801	.4748	.5144
19		.0377	.0381	.0381	.0191	.0191	.0191
20	.0381	.0191	.0187	.0381	.0191	.0191	.0191
21	.0381	.0191	.0187	.0381	.0191	.0191	.0191
22	.0191	.0191	.0187	.0189	.0191	.0191	.0191
23		.0191	.0187	.0189	.0191	.0191	.0189
24	.0181	.2829	.2402	.0181	.0187	.0187	.0191
Max	**.3189**	**.4294**	**.4031**	**.7461**	**.6613**	**.6443**	**.6443**
Min	**.0166**	**.0168**	**.0166**	**.0171**	**.0166**	**.0173**	**.0168**
Avg	**.0462**	**.1426**	**.1278**	**.2467**	**.2194**	**.2058**	**.2085**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
HUPARI[042] BU 7111
Substation No/ Name :- 144085 / 33/11KV YELGUD SUBSTATION
Feeder No / Name : 203 / bajrang ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5792	.0377	.0185	.6878	.7095	.7392	
2	.543	.0377	.0185	.724	.7095	.7316	.6036
3	.543	.0377	.0183	.724	.6838	.7316	.5975
4	.543	.0373		.7602	.6838	.7602	.5975
5	.5792	.0373	.0362	.788	.0183	.7602	.6219
6	.5847	.0373	.0362	.815	.7421	.8145	.6805
7	.6201	.0373	.0362		.8939	.8505	.8413
8	.0354	.0354		.9088	.9724	.8939	.8817
9	.0354	.0351	.0183	.9774	.9614	.9015	.9221
10	.0366	.0358	.0381	.0377		.0187	.0189
11	1.2407	1.3717	1.3077	.0343	.0168	.017	.0168
12	1.3245	1.4575	1.3748	.0339	.0168	.0339	.0166
13	1.326	1.4083	1.3748	.0335	.0168	.017	.0168
14		1.4083	1.3413	.017	.0168	.017	.017
15	1.3413	1.4251	1.4243	.0171	.0168	.0335	.017
16	1.291	1.1736	1.3226	.0171	.017	.0335	.017
17		1.2742	1.1271	.0171	.017	.0335	.017
18	1.1361	1.2003	1.0395		.0343		.0191
19		.0377	.0381	.0381	.0381	.0381	.0381
20	.0381	.0381	.0373	.0381	.0381	.0381	.0381
21	.0381	.0381	.0373	.0381	.0381	.0381	.0381
22	.0381	.0381	.0187	.0377	.0381	.0381	.0191
23		.0381	.0187	.0377	.0381	.0381	.0189
24	.5792	.0377	.0373	.7095	.6722	.7095	.6287
Max	**1.3413**	**1.4575**	**1.4243**	**.9774**	**.9724**	**.9015**	**.9221**
Min	**.0354**	**.0351**	**.0183**	**.017**	**.0168**	**.017**	**.0166**
Avg	**.6226**	**.4715**	**.4873**	**.3406**	**.3213**	**.3603**	**.2906**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
HUPARI[042] BU 7111
Substation No/ Name :- 144095 / 33/11KV GADMUDSHINGI
Feeder No / Name : 201 / GADMUDSHINGI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5407	.4973	.3944	.0953	.0762	.0686	.0762
2	.5243	.5487	.3429	.0953	.0762	.0686	.0762
3	.5243	.6516	.3429	.1143	.0762	.0686	.0762
4	.6062	.7716	.3772	.1143	.0762	.0686	.0762
5	.6962	.8402	.5144	.1143	.0953	.0857	.0953
6	.9724	.8916	.7716	.1334	.0953	.1029	.1524
7	.9892	.9945	.823	.1715	.1524	.1372	.1715
8	1.2407	1.2346	1.1145	.1905	.1524	.1372	.1524
9	1.3032	1.1568	1.1065	.1543	.132	.132	.1509
10	.1029	.1334	.0953	.1372	.132	.132	.1132
11	.0857	.1143	.1334	1.8519	1.8652	1.933	1.8482
12	.0857	.1143	.0953	2.0233	2.1628	2.0348	1.9161
13	.0857	.0953	.0953	2.1091	2.0622	2.0517	1.8652
14	.0857	.1143	.0953	2.1434	2.0454	1.8652	1.8821
15	.1029	.1143	.0953	2.1434	1.8821	1.9839	1.7974
16	.1029	.1143	.0953	1.9204	1.8143	1.95	1.7126
17	.132	.1029	.1334	2.0454	1.8176	1.9281	1.576
18	.132	.12	.1524	1.6933	1.6289	1.7101	1.2574
19	.1509	.1372	.1524	.1715	.1372	.1524	.1524
20	.1509	.12	.1524	.1524	.1372	.1334	.1334
21	.132	.12	.1524	.1334	.12	.1334	.1334
22	.1132	.1029	.1334	.1143	.1029	.1143	.0953
23	.1132	.0857	.1143	.0953	.0857	.0953	.0953
24	.5407	.4973	.4115	.1143	.0762	.0686	.0953
Max	**1.3032**	**1.2346**	**1.1145**	**2.1434**	**2.1628**	**2.0517**	**1.9161**
Min	**.0857**	**.0857**	**.0953**	**.0953**	**.0762**	**.0686**	**.0762**
Avg	**.3964**	**.4030**	**.3290**	**.7513**	**.7084**	**.7148**	**.6542**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
HUPARI[042] BU 7111
Substation No/ Name :- 144095 / 33/11KV GADMUDSHINGI
Feeder No / Name : 202 / KALAMWADI VG GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.1132	.0857	.0747	.1109	.0857	.0934
2	.0934	.0943	.0686	.0747	.1109	.0857	.0934
3	.0934	.0943	.0686	.0934	.1109	.0857	.0934
4	.0934	.1132	.0686	.0934	.1109	.0857	.112
5	.0934	.132	.1029	.112	.1109	.0857	.112
6	.0934	.1509	.12	.1307	.1109	.1029	.1307
7	.112	.1698	.12	.1307	.1698	.12	.1494
8	.1494	.1698	.12	.1494	.1698	.1372	.168
9	.1886	.2054	.132	.1372	.1886	.1509	.1698
10	.1886	.2054	.1886	.12	.1698	.2075	.1698
11	.2572	.2241	.1698	.1543	.1886	.2263	.1509
12	.2401	.2054	.2075	.1029	.2075	.1886	.2075
13	.1715	.2614	.1698	.1372	.1886	.1509	
14	.1715	.2241	.2263	.1372	.1698	.1698	.132
15	.1543	.2054	.2452	.12	.1886	.1886	.1509
16	.2058	.1867	.1509	.12	.2075	.1886	.1698
17	.2075	.2058	.2054	.1524	.1886	.1867	.1715
18	.2263	.1715	.1494	.1524	.1543	.1494	.1905
19	.1698	.1715	.1494	.2096	.1543	.1494	.2096
20	.2075	.1372	.1494	.1905	.1543	.1494	.1698
21	.132	.1372	.1494	.1509	.1372	.1307	.132
22	.132	.1372	.1307	.132	.12	.1307	.1109
23	.132	.12	.112	.1109	.12	.112	.1109
24	.112	.132	.1029	.0934	.1294	.1029	.112
Max	**.2572**	**.2614**	**.2452**	**.2096**	**.2075**	**.2263**	**.2096**
Min	**.0934**	**.0943**	**.0686**	**.0747**	**.1109**	**.0857**	**.0934**
Avg	**.1549**	**.1653**	**.1414**	**.1283**	**.1530**	**.1405**	**.1439**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
HUPARI[042] BU 7111
Substation No/ Name :- 144095 / 33/11KV GADMUDSHINGI
Feeder No / Name : 203 / GADMUDSHINGI VG GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2957	.3018	.3429	.3361	.1753	.2743	.3174
2	.2772	.3018	.2915	.3361	.1753	.2572	.2987
3	.2772	.2829	.3086	.3734	.1753	.2572	.2987
4	.3326	.3018	.3086	.3921	.1949	.2572	.2987
5	.3511	.415	.4115	.4294	.2353	.2915	.3361
6	.462	.4904	.4801	.4854	.3734	.3429	.3734
7	.4854	.6036	.5487	.5601	.4481	.4458	.4294
8	.5041	.5093	.4458	.5228	.4854	.463	.5041
9	.4458	.4481	.4854	.4973	.4527	.4715	.4904
10	.3944	.4294	.4294	.3944	.4338	.415	.4715
11	.3601	.4294	.4481	.3086	.3961	.4338	.6413
12	.3601	.4108	.5847	.2915	.3395	.415	.3961
13	.2915	.4294	.3547	.2572	.3018	.3961	.4338
14	.4287	.4294	.4854	.2915	.5093	.3961	.415
15	.4287	.4481	.4108	.2743	.4715	.4338	.415
16	.3258	.3921	.3547	.2058	.3018	.3772	.3584
17	.4338	.3772	.3921	.2218	.3429	.3547	.3734
18	.6413	.6344	.6535	.3361	.4287	.4668	.4854
19	.679	.6516	.7842	.4949	.6859	.8215	.7922
20	.7167	.6516	.7095	.4904	.6516	.7468	.7621
21	.679	.6344	.5601	.4527	.4801	.5601	.5228
22	.547	.5487	.6348	.3772	.5658	.5975	.5847
23	.415	.4458	.5041	.2378	.4801	.5041	.4854
24	.2987	.3018	.3772	.3174	.2012	.2915	.3174
Max	**.7167**	**.6516**	**.7842**	**.5601**	**.6859**	**.8215**	**.7922**
Min	**.2772**	**.2829**	**.2915**	**.2058**	**.1753**	**.2572**	**.2987**
Avg	**.4346**	**.4529**	**.4711**	**.3702**	**.3877**	**.4279**	**.4501**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
HUPARI[042] BU 7111
Substation No/ Name :- 144095 / 33/11KV GADMUDSHINGI
Feeder No / Name : 204 / sarnobatwadi ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0514	.2835		.1715	.2126
2	.0572	.0572	.0514	.3012	.1791	.1715	.2126
3	.0572	.0572	.0514	.3012	.1791	.1715	.2126
4	.0572	.0572	.0514	.3189	.1791	.1715	.2481
5	.0572	.0762	.0514	.3544	.2103	.2058	.2481
6	.0762	.0762	.0686	.3898	.3429	.3086	.2835
7	.1143	.0762	.0857	.4252	.3856	.3944	.3898
8	.1334		.0857	.5138	.4191	.4458	.443
9	.0857	.0953	.1143	.4801	.3772	.4733	.463
10	.1029	.0762	.0762	.1029	.0754	.0943	.1143
11	.5658	.4784	.57	.1029	.0762	.1143	.0762
12	.6173	.6024	.6203	.0857	.0762	.1143	.0953
13	.583	.6024	.5868	.0857	.0762	.0953	.0953
14	.5487	.5847		.0857	.0762		.0953
15	.5316	.6024	.5868	.0686	.0762	.0762	.0953
16	.4801	.6201	.5868	.1029	.0953	.0953	.1143
17	.4681	.583	.6201	.0762	.0857	.0953	.0953
18	.2629	.3258	.4252	.0762	.0686	.0762	.0762
19	.0762	.0514	.0953	.0762	.0857	.0762	.0762
20	.0762	.0686	.0953	.0953	.0686	.0762	.0953
21	.0572	.0514	.0953	.0762	.0686	.0762	.0953
22	.0572	.0686	.0953	.0762	.0514	.0762	.0762
23	.0572	.0514	.0762	.0572	.0514	.0762	.0762
24	.0572	.0572	.0514	.2835	.197	.1715	.2126
Max	**.6173**	**.6201**	**.6203**	**.5138**	**.4191**	**.4733**	**.463**
Min	**.0572**	**.0514**	**.0514**	**.0572**	**.0514**	**.0762**	**.0762**
Avg	**.2182**	**.2338**	**.2258**	**.2008**	**.1522**	**.1664**	**.1751**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] **BU 7129**
Substation No/ Name :- 144015 / 33/11KV SIDHNERLI
Feeder No / Name : 201 / EKONDI Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029			1.2483	.1075	.1063	
2	.1075			1.2955	.1063	.104	
3	.1052			1.2955	.1075	.104	
4	.1052			1.3763	.1075	.104	
5	.1052			1.4091	.1075	.104	
6	.1052			1.5565	.1075	.104	
7	.124			1.6575	.1227	.104	
8	.128			2.1956	.1578	.1387	
9	.124		1.9662			.1063	
10	.124	.064	.1294			.1063	.096
11	.124	.0633	.128			2.8166	2.7161
12	.1254	.064				2.8837	2.9447
13	.1254	.064	.124				3.4551
14	.124	.08	.1063				
15	.1417	.08	.1075				
16	.1417	.096	.1075				
17		.1595		2.7846	2.4326		2.6871
18		.1402	.096	2.3868	2.1376		2.4905
19		.1402	.096	.1433	.124		.12
20		.124	.1134	.1433	.124		.128
21		.1254	.112	.1433	.1387		.128
22		.1254	.096	.1448	.1227		.128
23			.08	.1254	.1052		.128
24	.1063			1.2146	.1075	.1063	
Max	**.1417**	**.1595**	**1.9662**	**2.7846**	**2.4326**	**2.8837**	**3.4551**
Min	**.1029**	**.0633**	**.08**	**.1254**	**.1052**	**.104**	**.096**
Avg	**.1188**	**.102**	**.2509**	**1.1950**	**.3885**	**.5299**	**1.3656**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] BU 7129
Substation No/ Name :- 144015 / 33/11KV SIDHNERLI
Feeder No / Name : 202 / Siddhanerli- Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0366			.4481	.0373	.0373	
2	.0343			.4481	.037	.0373	
3	.0351			.4801	.037	.0373	
4	.0351			.4858	.037	.0373	
5	.0351			.5506	.0366	.0373	
6	.0351			.5668	.0366	.0373	
7	.0354			.583	.0373	.0373	
8	.0381			.7125		.0373	
9	.0373		.6706			.0373	
10	.0373	.032	.0332			.0373	.0312
11							1.326
18							.9945
19		.0373	.032	.0373	.0373		.0366
20		.0373	.032	.0366	.0373		.0343
21		.0373	.0312	.037	.0373		.0351
22			.0312	.037	.0373		.0366
23			.0316	.037	.0373		.0354
24	.0335			.4161	.0373	.0373	
Max	**.0381**	**.0373**	**.6706**	**.7125**	**.0373**	**.0373**	**1.326**
Min	**.0335**	**.032**	**.0312**	**.0366**	**.0366**	**.0373**	**.0312**
Avg	**.0357**	**.0360**	**.1231**	**.3483**	**.0371**	**.0373**	**.3162**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] BU 7129
Substation No/ Name :- 144015 / 33/11KV SIDHNERLI
Feeder No / Name : 203 / 11KV Shendur Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173			.0625	.9282	.8848	
2	.6036			.064	.9503	.9012	
3	.6036			.064	.9503	.9012	
4	.5967			.064	.9503	.8907	
5	.6371				.9831	.9503	
6	.663				1.0159	.9831	
7	.8383				1.4255	1.2803	
8	1.0883			.0625	1.6712	1.5061	
9	1.4251		.0762			1.5927	
10	.0914	.096	.0762			.0739	.0937
11	1.9204	1.9281	1.4255			.0739	.0791
12	2.0005	2.2786	.9393			.0655	.0316
13	2.0805	2.3743	2.0081				.0781
14	2.0005	2.3663	2.2672				
15	1.9685	2.191	2.1956				
16	1.9109	2.0157	1.9334				
17		1.5729		.0732	.0724		.0914
18			1.0402	.0732	.1097		.0924
19		.0366	.064	.0739	.0732		.0924
20		.0724	.0633	.0747	.0732		.0914
21		.0732	.064	.0739	.0732		.1097
22		.0895	.064	.0914	.0732		.0924
23			.064	.0732	.0732		.0924
24	.6371			.0625	.8288	.8745	
Max	**2.0805**	**2.3743**	**2.2672**	**.0914**	**1.6712**	**1.5927**	**.1097**
Min	**.0914**	**.0366**	**.0633**	**.0625**	**.0724**	**.0655**	**.0316**
Avg	**1.1578**	**1.2579**	**.8772**	**.0702**	**.6407**	**.8445**	**.0859**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] BU 7129
Substation No/ Name :- 144015 / 33/11KV SIDHNERLI
Feeder No / Name : 204 / Sidhnerli Ekondi Gaothan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286			.2402	.2477	.2195	
2	.2096			.2218	.2286	.2195	
3	.2096			.2195	.2286	.2195	
4	.2096			.2587	.2477	.2195	
5	.2667			.3658	.3048	.2561	
6	.4904			.5544	.4715	.3326	
7	.6036			.5175	.6413	.6348	
8	.6036			.5175	.5601	.5975	
9	.5853		.6722			.679	
10	.3475	.5487	.6161			.5975	.5175
11	.5121	.5175	.5658			.5601	.499
12	.4755	.462	.5975			.499	.4805
13	.439	.4572	.381				.4805
14	.439	.1097	.4252				
15	.4207		.4668				
16	.567	.1097	.4904				
17		.5729		.3696	.4066		.4066
18		.6468	.5175	.4481	.5601		.5601
19		.8299	.8215	.811	.8299		.8215
20		.8215	.7842	.7468	.7545		.7545
21		.7023	.6722	.6097	.6908		.7167
22		.5175	.5175	.5093	.6348		.5093
23			.3734	.3395	.3881		.3429
24	.2477			.2743	.2477	.2561	
Max	**.6036**	**.8299**	**.8215**	**.811**	**.8299**	**.679**	**.8215**
Min	**.2096**	**.1097**	**.3734**	**.2195**	**.2286**	**.2195**	**.3429**
Avg	**.4033**	**.5246**	**.5644**	**.4377**	**.4652**	**.4070**	**.5536**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] BU 7129
Substation No/ Name :- 144015 / 33/11KV SIDHNERLI
Feeder No / Name : 205 / 11 kv Shendur Gavthan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848			.1829	.168	.2149	
2	.1663			.1463	.1478	.1254	
3	.1663			.1463	.1494	.1612	
4	.1663			.1646	.168	.1791	
5	.2218			.2195	.2241	.2149	
6	.3326			.2957	.3174	.2561	
7	.3326			.3109	.3734	.4435	
8	.3326			.3142	.3326	.3921	
9	.2865		.362			.3881	
10	.3366	.3734	.3544			.3582	.3696
11	.2865	.3292	.2507			.3189	.3109
12	.3045	.3142	.3189			.2743	.3142
13	.3109	.3109	.2401				.3142
14	.2865	.2926	.2835				
15	.2743		.2686				
16	.2926	.2743	.2865				
17		.3761		.3224	.2865		.2658
18		.4298	.3142	.3109	.4207		.4207
19		.5853	.5228	.5175	.5601		.5014
20		.5415	.5041	.4805	.5228		.5175
21		.4854	.4435	.4066	.5228		.4435
22		.3696	.3696	.3361	.3734		.3511
23			.2402	.1663	.2614		.2218
24	.2172			.1829	.168	.2686	
Max	**.3366**	**.5853**	**.5228**	**.5175**	**.5601**	**.4435**	**.5175**
Min	**.1663**	**.2743**	**.2401**	**.1463**	**.1478**	**.1254**	**.2218**
Avg	**.2646**	**.3902**	**.3399**	**.2815**	**.3123**	**.2766**	**.3664**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] BU 7129
Substation No/ Name :- 144015 / 33/11KV SIDHNERLI
Feeder No / Name : 207 / 11KV Vitthal Shivaji LIS **PURELY LIS FEEDERS**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.3353			.0171	.5087	
4	.3353			.0171	.0373	
5	.3315			.0171	.0373	
6	.3353			.0171	.0373	
7	.3353			.3086	.0373	
8	.3353			.3353	.0373	
9	.3481				.0335	
10	.3481	.0857			.0332	.1753
11	.3315	.1387			.0332	.1402
12	.3353	.3506			.0328	.1402
13	.3481	.3506	.0164			.1417
14	.3521	.3086	.3277			
15	.3481		.3605			
16	.3481		.3605			
17		.3521		.5426		.1326
18		.3481	.3506	.5365		.1326
Max	**.3521**	**.3521**	**.3605**	**.5426**	**.5087**	**.1753**
Min	**.3315**	**.0857**	**.0164**	**.0171**	**.0328**	**.1326**
Avg	**.3405**	**.2763**	**.2831**	**.2239**	**.0828**	**.1438**

 Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] **BU 7129**
Substation No/ Name :- 144015 / 33/11KV SIDHNERLI
Feeder No / Name : 402 / 33 KV Shahu LIS -SDH- SHEDDABLE HV(AGRICULTURE)
Feeder KV- 33 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	1.1203			2.2405	1.6461	
4				3.1367	.5487	
5	2.4897			3.4728	4.9383	
6	3.0556			3.6969	4.9383	
7	4.7051			5.6013	5.487	
8	4.7051			5.4893	5.487	
9	4.6091				5.3772	
10	4.4993				5.3772	4.3896
11	.4481				5.3772	3.2236
12		.2881	5.4893		5.3772	4.3896
13		1.5947	5.2652			4.7051
14		1.4918	5.3772			
15	3.1824		4.9291			
16	4.6091	4.3896	4.0329			
17				5.2675		4.7051
18		.439	.5258	.5601		.6722
Max	**4.7051**	**4.3896**	**5.4893**	**5.6013**	**5.487**	**4.7051**
Min	**.4481**	**.2881**	**.5258**	**.5601**	**.5487**	**.6722**
Avg	**3.3424**	**1.6406**	**4.2699**	**3.6831**	**4.4554**	**3.6809**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] BU 7129
Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION
Feeder No / Name : 201 / Kagal Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6766			.0762	.0762	.0953	.0572
2	1.6766			.0762	.0953	.0953	.0572
3	1.6766			.0762	.0953	.0953	.0572
4	1.6766			.0762	.0953	.0953	.0572
5	1.6766			.0762	.0953	.0953	.0572
6	1.7147			.0953	.0953	.0953	.0762
7	2.0195			.1143	.0953	.0953	.0953
8	2.3434			.0953	.0953	.1143	.1143
9	2.191	2.3624	2.21	.0762	.0953	.0762	.0953
10	.0572	.0572	.0762	.0762	.0953	.0762	.0572
11	.0762	.0572	.0572	2.4006	3.0102	2.9912	2.6292
12	.0762	.0762	.0572	2.8578	3.0483	3.2579	2.8197
13	.0572	.0572	.0572	2.8769	2.4196	3.1817	2.8769
14	.0572	.0572	.0572	2.7244	2.5149	3.0864	
15	.0572	.0572	.0572	2.915	2.553	2.8578	2.5339
16	.0572	.0572	.0572	2.915	2.915	2.8006	2.5911
17	.0572	.0572	.0572	2.8197	2.8006	2.8197	2.4958
18	.0762	.0762	.0762	2.7054	2.6482	2.5339	2.2481
19	.1143	.0953	.1143	.0762	.1143	.0762	.0953
20	.1143	.0953	.1143	.0572	.1334	.0762	.0953
21	.1143	.0953	.1143	.0572	.1143	.0762	.0953
22	.1143	.0762	.0953	.0572	.0953	.0762	.0762
23	.0762	.0762	.0762	.0572	.0953	.0572	.0762
24	1.6575			.0762	.0762	.0953	.0572
Max	**2.3434**	**2.3624**	**2.21**	**2.915**	**3.0483**	**3.2579**	**2.8769**
Min	**.0572**	**.0572**	**.0572**	**.0572**	**.0762**	**.0572**	**.0572**
Avg	**.8089**	**.2236**	**.2185**	**.9764**	**.9780**	**1.0383**	**.8441**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] BU 7129
Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION
Feeder No / Name : 202 / Kagal-Sugar Factory Vg GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524			.1334	.1524	.1334	.1143
2	.1524			.1143	.1524	.1334	.1143
3	.1524			.1143	.1524	.1334	.1143
4	.1524			.1143	.1524	.1334	.1143
5	.1905			.1905	.1905	.1905	.2096
6	.3429			.2858	.3239	.3429	.3429
7	.5716			.4001	.4572	.4382	.4763
8	.3429			.4572	.5906	.5716	.5144
9	.5906	.724	.5716	.4191	.4954	.6478	.6097
10	.6287	.7621	.6287	.2858	.6097	.6287	.5906
11	.5716	.5144	.5525	.2096		.5906	.6287
12	.5525	.6097	.6287	.1905	.5525	.5525	.5335
13	.6287	.4954	.5335	.2286	.5335	.6097	.6287
14	.4954	.381	.6097	.2477	.5144	.4572	.4191
15	.5335	.5144	.6097	.2477	.4191	.5144	.5144
16	.5716	.5144	.6097	.2096	.5144	.4382	.4954
17	.4382	.5335	.4572	.2286	.5335	.4001	.6097
18	.4572	.5144	.5144	.2667	.5716	.5716	.6668
19	.5525	.5906	.5906	.4954	.5906	.5335	.5906
20	.5335	.5335	.5525	.4382	.4954	.4954	.5525
21	.4382	.4191	.4382	.4001	.381	.4382	.4191
22	.2858	.2667	.3048	.2858	.3239	.3048	.2858
23	.1715	.1524	.1715	.2096	.1715	.1715	.2286
24	.1524			.1334	.1334	.1334	.1143
Max	**.6287**	**.7621**	**.6287**	**.4954**	**.6097**	**.6478**	**.6668**
Min	**.1524**	**.1524**	**.1715**	**.1143**	**.1334**	**.1334**	**.1143**
Avg	**.4025**	**.5017**	**.5182**	**.2628**	**.3918**	**.3985**	**.4120**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] BU 7129
Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION
Feeder No / Name : 203 / Non Sh MIDC Kagal-Anant Roto Feeder KV- 11 / OUTGOING SHEDDABLE FEEDER HAVING WEEKLY STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3336			1.5623	.7049	1.3146	1.1812
2	1.1431			1.5242	.724	1.2765	1.2193
3	1.1431			1.3908	.724	1.3336	1.2765
4	1.2384			1.448	.724	1.4289	1.3336
5	1.3336			1.7337	.7049	1.4861	1.3717
6	1.5242			1.7718	.743	1.5242	1.4861
7	1.7528			1.6956	.7811	1.6575	1.6575
8	1.5623			1.5051	.9907	1.5813	1.8671
9	2.0195	1.6956	1.5432	.6287	.9717	1.7147	1.7337
10		1.7337	1.8671	.5525	1.3908	1.7909	2.1529
11	1.9243	1.8861	1.848	.5525	1.7909	1.8861	2.1529
12	2.1719	2.0005	1.5623	.5716	1.9433	1.7909	2.0957
13	2.0195	1.7337	1.9052	.5906	1.5051	1.848	2.0957
14	1.8861	1.9624	1.7909	.5906	1.5623	1.9243	2.0957
15	1.9243	2.1719	2.0767	.5525	1.7528	1.7909	2.2481
16	1.9624	2.0576	2.0576	.6097	1.6385	1.9052	2.0005
17	1.9243	2.0195	1.8861	.6859	1.6766	1.7147	2.1719
18	1.9052	2.1338	1.9052	.6859	1.7909	1.848	1.8861
19	1.8861		1.8671	.6859	1.6766	1.7147	2.0576
20	1.6575	1.9243	1.848	.6668	1.4289	1.6385	2.1338
21	1.5242	1.4289	1.4098	.6478	1.2003	1.467	1.6004
22	1.3527	1.2003	1.6004	.7049	1.1622	1.5623	1.4861
23	1.2003	1.1431	1.4289	.7049	1.2955	1.2384	1.448
24	1.4098			1.6194	.6859	1.3336	1.086
Max	**2.1719**	**2.1719**	**2.0767**	**1.7718**	**1.9433**	**1.9243**	**2.2481**
Min	**1.1431**	**1.1431**	**1.4098**	**.5525**	**.6859**	**1.2384**	**1.086**
Avg	**1.6434**	**1.7922**	**1.7731**	**.9867**	**1.2320**	**1.6155**	**1.7433**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] BU 7129
Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION
Feeder No / Name : 204 / Laxmi Ind SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429			.7621	.2667	.2477	.2858
2	.381			.724	.2667	.2477	.2667
3	.3429			.724	.2667	.2477	.3048
4	.2667			.6859	.2477	.2667	.3048
5	.3048			.9717	.2477	.2667	.2667
6	.2667			.8192	.2667	.2667	.2858
7	.2858			.6478	.2858	.2858	.3048
8	.381			.6668	.2858	.2858	.3239
9	.4191	.362	.9526	.4572	.3048	3.6008	.2667
10	.3239	.4001	1.0669	.5525	.5144	.3048	.2667
11	.3429	.3429	.9145	.5525	.4191	.2667	.4191
12	.3429	.4001	1.1241	.6478	.3429	.3048	.381
13	.4382	.4763	1.0479	.5716	.4001	.381	.4572
14	.4001	.4763	.7811	.5906	.4191	.362	.3239
15	.2477	.5335	.9335	.5525	.4382	.4001	.4191
16	.2667	.5525	.6859	.5525	.3048	.4954	.3429
17	.3429	.4572	.5716	.5716	.3239	.4382	.362
18	.4382	.4954	.9907	.2667	.3239	.4191	.3429
19	.4001	.4191	1.105	.2667	.362	.4001	.381
20	.2858	.2858	1.2574	.2858	.4191	.4001	.381
21	.2858	.4763	.7621	.2858	.2667	.3048	.2667
22	.3429	.3429	.743	.2667	.2667	.3048	.3239
23	.2477	.381	.8573	.2858	.2286	.3429	.3239
24	.4954			.8002	.2858	.2477	.2858
Max	**.4954**	**.5525**	**1.2574**	**.9717**	**.5144**	**3.6008**	**.4572**
Min	**.2477**	**.2858**	**.5716**	**.2667**	**.2286**	**.2477**	**.2667**
Avg	**.3413**	**.4268**	**.9196**	**.5628**	**.3231**	**.4620**	**.3286**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] BU 7129
Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION
Feeder No / Name : 205 / K.Sangaon SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286			.2858	.3048	.2286	.2096
2	.2096			.2667	.3048	.2096	.2096
3	.2096			.2667	.3048	.2096	.2096
4	.2096			.2667	.3048	.2286	.2286
5	.3429			.362	.381	.381	.3048
6	.4954			.4763	.4763	.4572	.5144
7	.6097			.5906		.5716	.5906
8	.6668			.6478	.6478	.6287	.6859
9	.5906	.5906	.6287	.6287	.5716	.5906	.5906
10	.5906		.5525	.5906	.5525	.5144	.5716
11	.5144	.4382	.4954	.5525	.5906	.5144	.4382
12	.5335	.4954	.4572	.4572	.5335	.4763	.4191
13	.4954	.4763	.4954	.4763	.5144	.4191	.4572
14	.4572	.6097	.5144	.4191	.4954	.4572	.4572
15	.4763	.4382	.4763	.4001	.4572	.4001	.4572
16	.4191	.381	.4572	.4001	.4572	.381	.4191
17	.4763	.5144	.4763	.4382	.5144	.4382	.4382
18	.4763	.5144	.4763	.4763	.4954	.5144	.5144
19	.5906	.4572	.6478	.6668	.6287	.6668	.6478
20	.6668	.6478	.6478	.6097	.6097	.5906	.6859
21	.6097	.5906	.5906	.6097	.5716	.5716	.5525
22	.5144	.5144	.5525	.5144	.5525	.4954	.4572
23	.3429	.362	.3429	.4191	.362	.3429	.3429
24	.3048			.2858	.3048	.2286	.2286
Max	**.6668**	**.6478**	**.6478**	**.6668**	**.6478**	**.6668**	**.6859**
Min	**.2096**	**.362**	**.3429**	**.2667**	**.3048**	**.2096**	**.2096**
Avg	**.4596**	**.5022**	**.5208**	**.4628**	**.4755**	**.4382**	**.4430**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] BU 7129
Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION
Feeder No / Name : 206 / Laxmi-Ag Feeder- SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478			.0381	.0381	.0381	.0381
2	.6478			.0381	.0381	.0381	.0381
3	.6478			.0381	.0381	.0381	.0381
4	.6478			.0381	.0381	.0381	.0381
5	.6859			.0381	.0381	.0381	.0381
6	.7621			.0381	.0381	.0381	.0381
7	.9526			.0381	.0381	.0381	.0381
8	1.105			.0381	.0381	.0381	.0381
9	1.2003	1.2003	1.105	.0381	.0381	.0381	.0381
10	.0381	.0381	.0381	.0381	.0381	.0381	.0381
11	.0381	.0381	.0381	1.448	1.448	1.5623	1.3717
12	.0381	.0381	.0381	1.448	1.7909	1.7718	1.4861
13	.0381	.0381	.0381	1.5623	1.7718	1.7147	1.4861
14	.0381	.0381	.0381	1.4098	1.448	1.6194	1.4098
15	.0381	.0381	.0381	1.4098	1.6766		1.448
16	.0381	.0381	.0381	1.4098	1.6004	1.6385	1.5242
17	.0381	.0381	.0381	1.3717	1.4098	1.4861	1.448
18	.0381	.0381	.0381	1.2193	1.2574	1.3527	1.3717
19	.0381	.0381	.0381	.0381	.0572	.0381	.0381
20	.0381	.0381	.0381	.0381	.0572	.0381	.0381
21	.0381	.0381	.0381	.0381	.0381	.0381	.0381
22	.0381	.0381	.0381	.0381	.0381	.0381	.0381
23	.0381	.0381	.0381	.0381	.0381	.0381	.0381
24	.6859			.0381	.0381	.0381	.0381
Max	**1.2003**	**1.2003**	**1.105**	**1.5623**	**1.7909**	**1.7718**	**1.5242**
Min	**.0381**	**.0381**	**.0381**	**.0381**	**.0381**	**.0381**	**.0381**
Avg	**.3549**	**.1156**	**.1092**	**.4953**	**.5438**	**.5111**	**.5065**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] BU 7129
Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION
Feeder No / Name : 207 / S.Kharkhan Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572			1.1812	1.2574	1.2193	1.0288
2	.0572			1.1812	1.2765	1.105	1.0669
3	.0572			1.1812	1.2955	1.105	1.0669
4	.0572			1.2003	1.2955	1.105	1.0288
5	.0572			1.2765	1.2955	1.2765	1.105
6	.0572			1.3908	1.3717	1.2955	1.2384
7	.0572			1.6956	1.5432	1.5432	1.4098
8				1.9433	1.8861	1.7528	1.6385
9		.0572	.0572	2.0005	1.9052	1.7909	1.6004
10		.0572	.0572	.0381	.0572	.0572	.0762
11	2.4006	2.8197	2.5149	.0381	.0572	.0572	.0381
12	2.6863	2.8959	2.934	.0381	.0381	.0572	.0572
13	2.8959	3.0483	2.8578	.0381	.0381	.0381	.0572
14	2.8959	3.0102	2.7816	.0381		.0572	.0572
15	2.8387	2.8006	2.5911	.0381		.0381	.0572
16		2.8006	2.5911	.0381	.0381	.0381	.0572
17	2.4768	2.6863	2.572	.0381	.0381	.0572	.0381
18	2.3053	2.4387	2.1719	.0381	.0572	.0572	.0381
19	.0762	.0572	.0762	.0381	.0762	.0762	.0762
20	.0762	.0762	.0762	.0572	.0762	.0762	.0762
21	.0762	.0572	.0762	.0572	.0762	.0762	.0762
22	.0572	.0572	.0762	.0572	.0572	.0762	.0572
23	.0572	.0572	.0762	.0572	.0572	.0762	.0572
24	.0572			1.2193	1.2384	1.2193	.9907
Max	**2.8959**	**3.0483**	**2.934**	**2.0005**	**1.9052**	**1.7909**	**1.6385**
Min	**.0572**	**.0572**	**.0572**	**.0381**	**.0381**	**.0381**	**.0381**
Avg	**.9650**	**1.5280**	**1.4340**	**.6200**	**.6833**	**.5938**	**.5414**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] BU 7129
Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION
Feeder No / Name : 208 / Kagal Vg GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4382			.4001	.4382	.4382	.4001
2	.4191			.4001	.4191	.4001	.4001
3	.4191			.4001	.4191	.4001	.4001
4	.4191			.4001	.4001	.4001	.4191
5				.4572	.4191	.4954	.4954
6	.6668			.6097	.6287	.6478	.6287
7	.8573			.7621	.8002	.8002	.7811
8	.8954			.8764	.9145	.9335	.8764
9	.8383	.8192	.8383	.8764	.8573	.8192	.8002
10	.7621	.7049	.8192	.7811	.7621	.7811	.7049
11	.6859	.6668	.7049	.7049	.6668	.6859	.724
12	.6859	.6097	.6859	.5906	.6859	.6478	.6287
13	.6668	.6287	.5906	.6097	.6478	.6478	.5906
14	.5906	.6097	.6097	.5716	.6097	.6287	.6097
15	.5906	.5525	.5716	.5335	.6097	.5716	.5716
16	.6287	.5716	.5525	.5144	.6478	.5906	.6287
17	.7049	.6287	.6478	.5906	.724	.6668	.6668
18	.9335	.7621	.8002	.7811	.8573	.8383	.8954
19	1.2193	1.086	1.105	1.1622	1.1812	1.1812	1.1812
20	1.1431	1.0288	1.0669	1.086	1.105	1.105	1.1431
21	.9907	.9335	.9335	.9717	1.0098	1.105	.9526
22	.8573	.7811	.8192	.8002	.8573	.8192	.7811
23		.5716	.5906	.6287	.6097	.5906	.6097
24	.4763			.4763	.4572	.4763	.4572
Max	**1.2193**	**1.086**	**1.105**	**1.1622**	**1.1812**	**1.1812**	**1.1812**
Min	**.4191**	**.5525**	**.5525**	**.4001**	**.4001**	**.4001**	**.4001**
Avg	**.7222**	**.7303**	**.7557**	**.6660**	**.6970**	**.6946**	**.6811**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] BU 7129
Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION
Feeder No / Name : 402 / 33KV Shahu LIS - KGL- SHEDDABLE HV(AGRICULTURE)
Feeder KV- 33 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	1.1431			.6859	.1715	.9145
4	1.4289			.6859	.6859	1.3717
5	1.4289			.6859	.6859	1.3717
6	1.4289			.743	.6859	1.3717
7	1.4289			.743	.6859	1.3717
8	1.4289			.743	.9145	1.3717
9	1.2003	1.3717	1.3717	.743	1.3717	1.1431
10	1.3717	1.3717	1.4289	.743	1.3146	1.086
11	1.3717	1.4289	1.4289	.743	1.3717	1.1431
12	1.3717	1.3717	1.4289	.743	1.4289	1.1431
13	1.3717	1.4289	1.3717	.743	1.4861	1.1431
14	1.3717	1.3717		.743	1.3717	.5144
15	1.3717	1.3717	1.3717	.743	1.3717	.5144
16	1.3146	1.3717	1.3717	.743	1.3717	.5144
17	1.3717	1.3717	1.3717	.743	1.3717	.5144
18	.743	.9145	.5716	.1715	1.1431	.3429
Max	**1.4289**	**1.4289**	**1.4289**	**.743**	**1.4861**	**1.3717**
Min	**.743**	**.9145**	**.5716**	**.1715**	**.1715**	**.3429**
Avg	**1.3217**	**1.3374**	**1.3019**	**.6966**	**1.0895**	**.9895**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] BU 7129
Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON
Feeder No / Name : 201 / 11KV MIDC SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6385	1.6575	1.6766	1.9433	1.7147	1.7147	1.9243
2	1.6194	1.6004	1.6766	1.8671	1.6956	1.6575	1.8861
3	1.6385	1.6385	1.6766	2.0005	1.6956	1.6194	1.8099
4	1.6194	1.6766	1.6385	1.6385	1.6956	1.6575	1.6194
5	1.6004	1.6385	1.6385	1.7528	1.6956	1.6766	1.6004
6	1.6004	1.6194	1.6766	1.6766	1.6956	1.6575	1.5623
7	1.6004	1.6004	1.6004	1.6194	1.6766	1.6575	1.5432
8	1.6004	1.6004	1.7909	1.6004	1.6766	1.6004	1.5432
9	1.8861	2.1338	1.6766	1.6385	1.829	1.6766	2.0767
10		2.2481	2.191	1.6385	1.8099	2.2481	1.9433
11	1.8671	2.0386	1.9433	1.6194	1.6385	2.0386	2.2481
12	2.1529	2.0957	2.0957	1.5813	1.8671	2.0767	1.9433
13	1.6956	2.0576	1.6004	1.6766	1.9624	1.7718	2.0005
14	2.0005	2.0195	2.191	1.6575	1.9814	2.0576	2.0957
15	1.7528	1.9624	1.9433	1.6575	1.9814	2.2481	2.0957
16	1.9052	1.829	1.9243	.5906	2.191	2.1719	2.0195
17	1.848	1.848	2.1719	1.6766	2.1719	1.9433	2.2862
18	1.7909	1.848	2.0005	1.6385	1.829	1.6385	2.1719
19	2.0576	1.7909	1.6956	1.6194	2.1338	1.8861	1.848
20	1.6385	1.7337	1.8099	1.6194	1.9433	1.7528	1.9052
21	1.7147	1.5813	1.6004	1.6575	1.9052	1.9243	1.7718
22	1.5623	1.5242	1.6194	1.6766	1.6385	1.5242	1.6004
23	1.6385	1.6194	1.5623	1.6766	1.7528	2.0195	2.0195
24	1.6385	1.6956	1.7337	1.829	1.7147	1.9814	1.7909
Max	**2.1529**	**2.2481**	**2.191**	**2.0005**	**2.191**	**2.2481**	**2.2862**
Min	**1.5623**	**1.5242**	**1.5623**	**.5906**	**1.6385**	**1.5242**	**1.5432**
Avg	**1.7420**	**1.7941**	**1.7973**	**1.6480**	**1.8290**	**1.8417**	**1.8877**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] BU 7129
Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON
Feeder No / Name : 202 / 11KV West Block SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4768	2.4768	2.4768	2.4768	2.0005	2.2862	1.9052
2	2.2862	2.2862	2.0957	2.3815	2.0005	2.0957	2.0957
3	2.4768	2.2862	2.0957	2.2862	2.0005	2.2862	2.0005
4	2.2862	1.9052	2.0957	2.0957	2.0005	2.0957	2.0005
5	2.2862	2.0957	2.0957	1.9052	2.0005	1.9052	1.9052
6	2.2862	2.2862	2.2862	2.0957	2.0005	1.9052	1.9052
7	2.191	2.2862	2.2862	1.9052	2.0005	1.9052	1.9052
8	2.0957	2.0957	2.1338	1.9052	2.0005	2.2862	2.2862
9	2.8578	3.0483	2.9721	1.9052	2.6673	2.2862	2.6673
10	3.3341	3.9057	3.8104	2.0005	3.2388	3.4294	3.8104
11	3.9057	4.2867	4.382	1.9052	3.9057	3.4294	3.8104
12	3.3341	3.8104	4.0009	1.9052	3.5246	3.4294	3.6199
13	2.6673	3.6199	3.3341	2.0957	2.9531	3.0483	
14	4.0009	3.8104	3.6199	2.0957	3.0483	3.4294	3.8104
15	3.6199	4.1914	3.8104	1.9052	4.1914	3.8104	3.8104
16	3.8104	3.8485	3.8104	2.0005	3.8104	3.2388	3.4294
17	4.1914	3.658	2.9531	1.9052	3.4294	2.4768	2.9531
18	3.0483	2.6292	2.8578	1.9052	2.8578	2.6673	2.4768
19	2.6673	2.2862	2.572	1.9052	2.6673	2.572	2.4768
20	2.2862	2.2862	2.2862	1.9052	2.2862	2.2862	2.0957
21	2.0957	2.2862	2.0957	1.9052	2.0957	2.2862	2.191
22	2.4768	2.3815	2.191	1.9052	2.2862	2.2862	2.0005
23	2.6673	2.4768	2.8578	2.0005	2.0957	2.191	2.0957
24	2.4768	2.8578	2.6673	2.4768	2.0005	1.9052	1.9052
Max	**4.1914**	**4.2867**	**4.382**	**2.4768**	**4.1914**	**3.8104**	**3.8104**
Min	**2.0957**	**1.9052**	**2.0957**	**1.9052**	**2.0005**	**1.9052**	**1.9052**
Avg	**2.8260**	**2.8792**	**2.8245**	**2.0322**	**2.6276**	**2.5641**	**2.5720**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] BU 7129
Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON
Feeder No / Name : 203 / KANERI GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.9526	.5144	.4572	.4572	.4382	.5335
2	.5144	.9145	.5144	.4191	.4572	.4763	.4191
3	.4382	.9145	.5144	.4191	.5144	.5335	.4191
4	.5716	.8764	.5716	.4382	.5335	.6097	.4763
5	.7621	.8383	.6287	.5144	.5335	.7621	.5525
6	.8002	.8383	.6859	.6668	.7049	1.0288	.7049
7	1.3146	1.1431	1.105	.8764	.8383	.9717	.8954
8	.9145	.9717	1.0669	.9145	1.1622	.9717	.8954
9	1.6004	1.5051	1.3336	.8002	1.1812	1.2955	1.1622
10	1.2384	1.0098	1.2384	.5525	1.1241	1.5051	1.1622
11	1.2765	1.105	1.3527	.381	1.2003	1.7718	.9526
12	1.0288	1.1431	1.2955	.3429	1.2193	1.1812	.9145
13	.9145	1.0669	1.1812	.3429	.9907	.7811	1.0479
14	1.0669	1.3717	1.6194	.3429	1.1622	.9526	1.105
15	1.2574	1.1241	1.3146	.381	1.1431	1.448	.8002
16	1.2193	.8954	1.2193	.4572	1.105	1.4289	.8954
17	1.105	1.5051	1.4861	.5144	.8383	1.467	1.1431
18	1.848	1.5432	1.2193	.5335	.8954	1.105	1.0288
19	2.0767	1.2193	1.5432	.8383	1.0669	1.0669	1.1622
20	1.3908	1.2765	1.2955	.7811	.9717	1.1241	1.105
21	1.1241	.9335	.9526	.7049	.8954	.9145	.8954
22	1.2193	1.2384	.9145	.743	.8002	.8573	.7049
23	1.1241	1.0669	.5716	.5144	.5525	.6097	.5525
24	.5716	.9717	.5144	.4572	.4763	.4572	.5716
Max	**2.0767**	**1.5432**	**1.6194**	**.9145**	**1.2193**	**1.7718**	**1.1622**
Min	**.4382**	**.8383**	**.5144**	**.3429**	**.4572**	**.4382**	**.4191**
Avg	**1.0812**	**1.1010**	**1.0272**	**.5580**	**.8677**	**.9899**	**.8375**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] BU 7129
Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON
Feeder No / Name : 204 / 11 KV PANCHAGANGA SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9052	1.7147	1.9052	1.9052	1.0479	1.7147	2.2862
2	1.9052	1.5242	1.9052	1.9052	.9526	1.5242	1.9052
3	1.9052	1.9052	1.9052	1.8099	.9526	1.7147	2.0957
4	1.9052	1.9052	1.9052	1.7147	.9526	1.5242	2.2862
5	1.8099	2.0957	1.9052	1.7147	.9526	1.5242	1.9052
6	1.7147	2.0957	2.2862	1.8099	1.1431	1.7147	1.9052
7	1.6194	2.2862	2.4768	1.7147	1.1431	2.6673	2.0005
8	1.6194	1.5242	1.8099	1.1431	1.1431	2.4768	1.3336
9	1.9052	2.0957	2.2862	1.3336	2.2862	1.8099	2.6673
10	1.5242	2.4768	2.191	1.3336	2.4768	2.191	2.6673
11	2.191	2.8578	2.3815	1.3336	1.7147	2.191	2.6673
12	1.5242	1.8099	1.8099	1.3336	1.9052	2.0005	1.7147
13	2.4768	2.0957	2.191	1.3336	2.2862	1.8099	2.2862
14	2.6673	2.0957	2.2862	1.5242	2.4768	2.0005	2.6673
15	2.6673	2.2862	2.2862	1.3336	2.6673	1.9052	2.6673
16	2.6673	2.4768	2.0005	1.2384	1.9052	1.9052	1.5242
17	2.4768	1.9052	1.7147	1.2384	2.8578	1.7147	2.0005
18	2.2862	2.6673	2.0957	1.2384	2.6673	1.7147	2.3815
19	2.2862	1.9052	1.9052	1.2384	2.6673	1.9052	2.4768
20	1.9052	2.4768	1.9052	1.2384	1.9052	2.4768	2.4768
21	1.7147	2.6673	1.9052	1.2384	1.7147	2.6673	2.4768
22	2.4768	3.0483	1.7147	1.1431	2.0957	2.8578	2.8578
23		2.572	2.4768	1.0479	2.2862	2.572	2.6673
24	1.4289	1.7147	1.9052	1.5242	1.0479	1.5242	2.2862
Max	**2.6673**	**3.0483**	**2.4768**	**1.9052**	**2.8578**	**2.8578**	**2.8578**
Min	**1.4289**	**1.5242**	**1.7147**	**1.0479**	**.9526**	**1.5242**	**1.3336**
Avg	**2.0253**	**2.1751**	**2.0481**	**1.4329**	**1.8020**	**2.0044**	**2.2585**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] **BU 7129**
Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON
Feeder No / Name : 205 / 11KV MainRoad **SHEDDABLE FEEDER HAVING WEEKLY**
Feeder KV- 11 / OUTGOING **STAGGERING (MIDC, EQUIVALENT)**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7049	.7621	.6668	.7811	.743	.8192	.9145
2	.6859	.724	.6859	.8002	.743	.7621	.8192
3	.6668	.724	.724	.8002	.743	.8002	.8573
4	.6859	.7049	.7621	.7621	.743	.7621	.7811
5	.6668	.7049	.8002	.724	.743	.743	.7811
6	.6668	.7049	.7811	.6859	.743	.7811	.8383
7	.6859	.724	.8192	.724	.743	.724	.8383
8	1.3336	.9717	.9717	.6859	.7811	.8954	1.1812
9	1.1431	1.3717	1.2765	.724	1.3336	.9145	1.086
10	1.3146	1.0479	1.1622	.724	1.4861	1.2765	1.3146
11	1.2765	1.3717	1.6385	.724	1.3527	1.2765	1.1431
12	1.448	1.6194	1.6385	.743	1.6385	1.2955	1.6766
13	1.5623	1.4289	1.2003	.7621	1.5623	1.1812	1.5623
14	1.848	1.4289	1.5432	.7621	1.1812	1.4098	1.3717
15	1.0669	1.5623	1.2765	.7621	1.6956	1.2193	1.6956
16	1.6575	1.4861	.9717	.8002	1.7528	1.3146	1.3527
17	1.2955	1.2003	.9335	.743	1.2574	1.2193	1.6956
18	1.105	1.086	.8573	.7621	.8954	1.105	1.0669
19	.8764	.9526	.8383	.743	.8954	.7811	1.0669
20	.7811	.8002	.7621	.724	.8002	.724	.7049
21	.8192	.7811	.8002	.743	.6859	.8192	.7049
22	.724	.8192	.8002	.743	.8192	.8383	.8002
23	.7621	.8383	.7811	.743	.743	.743	.7621
24	.724	.8002	.6668	.7621	.743	.8383	.8383
Max	**1.848**	**1.6194**	**1.6385**	**.8002**	**1.7528**	**1.4098**	**1.6956**
Min	**.6668**	**.7049**	**.6668**	**.6859**	**.6859**	**.724**	**.7049**
Avg	**1.0209**	**1.0256**	**.9732**	**.7470**	**1.0344**	**.9685**	**1.0772**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] BU 7129
Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON
Feeder No / Name : 206 / 11KV Industrial SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1338	2.0957	1.8671	2.0957	1.448	2.0195	1.9814
2	2.1719	2.0195	1.9052	1.9814	1.4098	1.9052	2.0576
3	2.1719	2.0576	1.9052	2.1338	1.4098	1.9433	1.8671
4	2.1338	2.1338	2.0195	1.9433	1.448	1.9814	1.9433
5	2.1719	2.1338	1.9052	1.8671	1.448	2.0576	1.829
6	2.21	2.1719	2.0195	2.0195	1.4861	1.9052	1.7528
7	1.9814	2.3624	2.4387	1.829	1.5623	2.0576	2.0195
8	1.829	1.829	1.8671	1.5623	1.5242	2.0576	1.9814
9	2.3243	2.4387	1.829	1.4098	1.7909	2.5149	2.3243
10	2.4006		2.6673	1.448	2.553	2.5149	2.7435
11	2.8197	3.0483	2.4768		2.7435	2.7054	2.8578
12	2.6673	2.7435	2.4768		2.5149	2.7054	2.5911
13	2.0957	2.4768	2.4006		2.2862	2.3624	2.553
14	2.6673	2.6673	2.5149		2.553	2.4768	2.8578
15	2.7816	2.7816	2.6673		2.4768	2.5911	2.8578
16	2.3243	2.3624	2.4006		2.1338	2.7054	2.7054
17	2.4768	2.2481	2.4768		2.4006	2.6673	2.5911
18	2.0195	2.3243	1.7909	1.4098	2.0195	2.3243	2.0576
19	1.5242	2.0195	1.6766	1.448	1.7909	1.7147	1.9052
20	1.448	1.7147	1.4098	1.4098	1.5623	1.448	1.5242
21	1.6385	1.7147	1.6385	1.4098	1.3336	1.6004	
22	1.3336	1.5242	1.6766	1.448	1.4861	1.5242	1.5623
23	1.9433	2.1338	1.9814	1.448	2.0957	1.9433	1.9433
24	2.21	2.1338	1.829	2.0576	1.448	1.9052	2.0195
Max	**2.8197**	**3.0483**	**2.6673**	**2.1338**	**2.7435**	**2.7054**	**2.8578**
Min	**1.3336**	**1.5242**	**1.4098**	**1.4098**	**1.3336**	**1.448**	**1.5242**
Avg	**2.1449**	**2.2233**	**2.0767**	**1.7012**	**1.8719**	**2.1513**	**2.1968**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] BU 7129
Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON
Feeder No / Name : 207 / 11 KV UJALAIWADI VG GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.2667	.3239	.2477	.2667	.2667	.2667
2	.2286	.2667	.3239	.2286	.2667	.2667	.2286
3	.2286	.2858	.3239	.2286	.2858	.2667	.2286
4	.3048	.3429	.3239	.2286	.2858	.2667	.2286
5	.3429	.4191	.3239	.2667	.2858	.2667	.3048
6	.4001	.4763	.4191	.381	.4001	.4382	.4001
7	.5906	.5906	.5525	.5144	.5525	.5906	.5716
8	.5906	.5716	.5525	.5525	.5716	.6668	.6478
9	.5335	.5335	.5335	.5335	.4763	.5335	.5525
10	.5525	.4382	.5144	.4572	.4572	.5525	.5716
11	.4763	.4954	.4954	.4382	.4954	.4954	.5525
12	.4382	.4763	.4954	.3429	.4572	.4954	.4954
13	.4572	.4572	.4572	.381	.4001	.4763	.4572
14	.4001	.381	.4191	.3429	.4001	.4191	.4954
15	.381	.381	.4763	.3429	.4191	.4191	.5525
16	.4191	.4001	.4572	.381	.4382	.5335	.4954
17	.4382	.5906	.5144	.4001	.5144	.5335	.5335
18	.5525	.5335	.5525	.4191	.5716	.5716	.7049
19	.6287	.6668	.6097	.5716	.7049	.8002	.8573
20	.6097	.6097	.6097	.5716	.6097	.6859	.7049
21	.5525	.6287	.5906	.5144	.5525	.6097	.6478
22	.4572	.4954	.5335	.4191	.5335	.4954	.5335
23	.362	.4001	.381	.2858	.4001	.3429	.381
24	.2667	.2667	.3429	.2858	.2667	.2858	.2858
Max	**.6287**	**.6668**	**.6097**	**.5716**	**.7049**	**.8002**	**.8573**
Min	**.2286**	**.2667**	**.3239**	**.2286**	**.2667**	**.2667**	**.2286**
Avg	**.4358**	**.4572**	**.4636**	**.3890**	**.4422**	**.4700**	**.4874**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] BU 7129
Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON
Feeder No / Name : 208 / KANERI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	.8764	.9907	.0572	.0572	.0572	.0572
2	.9526	.9145	.9907	.0381	.0572	.0572	.0572
3	.9526	.9145	.9907	.0381	.0572	.0572	.0572
4	.9907	.9526	1.0669	.0381	.0572	.0572	.0572
5	1.0288	1.0669	1.105	.0381	.0572	.0572	.0572
6	1.0288	1.1812	1.1812	.0381	.0762	.0762	.0953
7	1.2384	1.5813	1.3717	.0953	.0762	.0762	.0762
8	1.5051	1.7528	1.7718	.0762	.0953	.0953	.0572
9	1.5432	1.829	1.9624	.0953	.0953	.0953	.0762
10	.0762	.0572	.0762	.0953	.0762	.1143	
11	.1143	.0762	.0762	2.2862	2.2672	2.0767	2.0767
12	.0953	.0953	.0953	2.2672	2.3243	2.191	2.3624
13	.0762	.0953		2.3434	2.2672	1.9814	2.4387
14	.0953	.0953	.0953	2.4006	2.0957	2.0957	2.4006
15	.0762	.0953	.0572	2.2862	2.21	1.6385	2.3815
16	.0953	.0953	.0762	2.2862	2.191	1.8671	2.3815
17	.0953	.1143	.0953	2.191	2.2291	1.9243	2.2481
18	.0953	.0953	.0762	1.9433	1.9624	1.7909	1.9624
19	.0953	.0953	.0762	.0572	.0953	.0953	.0953
20	.0762	.1143	.0762	.0572	.0953	.0953	.0953
21	.0953	.0953	.0762	.0572	.0953	.0572	.0762
22	.0762	.0762	.0572	.0572	.0572	.0572	.0762
23	.0762	.0762	.0572	.0572	.0572	.0572	.0762
24	.9717	.8764	.9907	.0572	.0572	.0572	.0572
Max	**1.5432**	**1.829**	**1.9624**	**2.4006**	**2.3243**	**2.191**	**2.4387**
Min	**.0762**	**.0572**	**.0572**	**.0381**	**.0572**	**.0572**	**.0572**
Avg	**.5168**	**.5509**	**.5832**	**.7899**	**.7796**	**.6970**	**.8400**

 Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] **BU 7129**
Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON
Feeder No / Name : 209 / UJALAIWADI SHETI PUMP SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0381	.0381	.7621	.7621	.743	.6859
2	.0572	.0381	.0381	.7621	.7621	.8192	.6859
3	.0572	.0381	.0381	.8002	.8002	.8192	.724
4	.0572	.0381	.0381	.8002	.8383	.8192	.724
5	.0572	.0381	.0381	.8192	.8764	.8192	.743
6	.0572	.0381	.0381	.8192	1.0098	.9145	.724
7	.0762	.0381	.0762	1.105	1.4098	1.2574	1.1812
8	.0953	.0762	.0762	1.2955	1.6004	1.6766	1.467
9	.0762	.0762	.0762	1.3146	1.5623	1.5623	1.3908
10	.0953	.0572	.0762	.0762	.0953	.0953	.0953
11	1.6194	1.9624	1.829	.0572	.0762	.0762	.0762
12	1.9624	2.0576	1.9243	.0762	.0572	.0762	.0762
13	2.0195	2.0957	1.9814	.0572	.0572	.0762	.0953
14	2.1338	1.9052	1.9052	.0762	.0572	.0762	.0953
15	1.9243	1.8671	1.829	.0762	.0572	.0762	.0762
16	1.848	1.9052	1.8671	.0762	.0762	.0953	.0762
17	1.4098	1.9624	1.8861	.0762	.0762	.0762	.0762
18	1.448	1.6575	1.6194	.1143	.0572	.0953	.0953
19	.0762	.0572	.0762	.1143	.0953	.0762	.0762
20	.0572	.0572	.0762	.0953	.0762	.0953	.0762
21	.0572	.0572	.0762	.0762	.0762	.0762	.0762
22	.0572	.0572	.0381	.0762	.0762	.0762	.0572
23	.0572	.0381	.0381	.0762	.0572	.0762	.0572
24	.0572	.0381	.0381		.743	.7049	.724
Max	**2.1338**	**2.0957**	**1.9814**	**1.3146**	**1.6004**	**1.6766**	**1.467**
Min	**.0572**	**.0381**	**.0381**	**.0572**	**.0572**	**.0762**	**.0572**
Avg	**.6422**	**.6748**	**.6549**	**.4175**	**.4731**	**.4699**	**.4231**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] BU 7129
Substation No/ Name :- 144067 / 33/11 KV K'SANGAON
Feeder No / Name : 202 / M Sangaon Vg GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3881	.4024	.4108	.4527	.4481	.4066	.4338
2	.3881	.3521	.3734	.3961	.3921	.362	.3772
3	.4481	.3521	.3734	.3961	.3921	.4066	.4001
4	.4435	.4527	.3734	.4572	.4481	.4435	.4572
5	.6099	.5533	.3734	.5906	.5544	.4805	.5906
6	.7602	.6706	.7762	.8676	.7602	.823	.5847
7	.8505	.9389	.9511	1.0185	.8939	.905	.9619
8	.8059	.8718	.9511	.8488	.8059	.905	1.0456
9	.8059	.6706	.8779	.924	.7602	.695	.8871
10	.6584	.503	.5788	.7133	.7133	.695	.6838
11	.5533	.6283	.6219	.5914	.6653	.5975	.4805
12	.5868	.6468	.6584	.5544	.462	.462	.5544
13	.5365	.462	.5973	.5544	.5914	.4755	.4481
14	.5365	.5544	.4668	.499	.6154	.6154	.4481
15	.57	.5914	.6516	.499	.462	.5853	.499
16	.6036	.5544	.6838	.5544	.5914	.6697	.4435
17	.6371	.7316	.7087	.6099	.7316	.6697	.6653
18	.7042	.7316	.7522	.6099	.7682	.6838	.7602
19	1.0059	.9955	1.1273	.9036	1.0136	1.0829	.9465
20	1.0059	.823	.8865	.9036	.8688	1.0829	.8505
21	.8886	.8779	.9054	.8505	.905	.9997	.8059
22	.6036	.6468	.811	.6584	.7133	.6668	.7602
23	.4024	.5175	.6161	.5544	.5544	.5601	.499
24	.4435	.4527	.4668	.5093	.462	.462	.5228
Max	**1.0059**	**.9955**	**1.1273**	**1.0185**	**1.0136**	**1.0829**	**1.0456**
Min	**.3881**	**.3521**	**.3734**	**.3961**	**.3921**	**.362**	**.3772**
Avg	**.6349**	**.6242**	**.6664**	**.6465**	**.6489**	**.6556**	**.6294**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] **BU 7129**
Substation No/ Name :- 144067 / 33/11 KV K'SANGAON
Feeder No / Name : 203 / Sulkud AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9465	.8097	.9774	.0514	.0566	.0381	.0514
2	.9465	.8097	.9774	.0514	.0566	.0381	.0343
3	.9991	.8097	.9774	.0514	.0566	.0381	.0343
4	1.0288	.8421	.9945	.0514	.0566	.0381	.0343
5	1.1317	.9069	1.0117	.0514	.0566	.0381	.0343
6	1.2209	.9878	1.0974	.0514	.0754	.0572	.0543
7	1.4586	1.1336	1.2689	.0514	.0754	.0572	.0543
8	1.5912	1.3927	1.4413	.0709	.0754	.0572	.0732
9	1.5415	1.3765	1.4922	.0686	.0754	.0572	.0514
10	.0566	.081	.0762	.0754	.0566	.0953	.0514
11	.0486	.0762	.0762	1.8778	2.3739	2.2969	2.2297
12	.0486	.0762	.0514	2.1136	2.4756	2.4981	2.4194
13	.0486	.0762	.0514	2.1862	2.4587	2.3807	2.3245
14	.0486	.0762	.0514	2.2119	2.2721	2.3472	2.2085
15	.0486	.0762	.0686	2.2119	2.3569	2.3975	2.1862
16	.0486	.0762	.0514	2.1136	2.2043	2.2377	2.0645
17	.0486	.0953	.0514		2.0178	2.0885	2.0153
18	.0486	.0953	.0686	1.643	1.8821	1.9559	1.757
19	.0648	.0762	.0886	.1132	.0762	.0739	.0754
20	.081	.0762	.0686	.0943	.0762	.0686	.0754
21	.0648	.0762	.0686	.0754	.0762	.0686	.0754
22	.0648	.0762	.0686	.0754	.0572	.0514	.0754
23	.0486	.0572	.0686	.0754	.0762	.0514	.0566
24	.9991	.8259	.9774	.0514	.0566	.0381	.0514
Max	**1.5912**	**1.3927**	**1.4922**	**2.2119**	**2.4756**	**2.4981**	**2.4194**
Min	**.0486**	**.0572**	**.0514**	**.0514**	**.0566**	**.0381**	**.0343**
Avg	**.5264**	**.4577**	**.5052**	**.6703**	**.7959**	**.7945**	**.7537**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] BU 7129
Substation No/ Name :- 144067 / 33/11 KV K'SANGAON
Feeder No / Name : 204 / 11 KV LINGNOOR (VG) GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0335	.0381	.0377	.0566	.0381	.0554
2	.0566	.0335	.0381	.0377	.0566	.0381	.037
3	.0566	.0335	.0381	.0373	.0566	.0381	.037
4	.0566	.0503	.0381	.037	.0566	.0381	.0366
5	.0566	.0671	.0572	.0754	.0943	.0572	.056
6	.1132	.1006	.112	.0754	.0943	.1307	.1143
7	.1132	.0914	.112	.1143	.1494	.1307	.1334
8	.1097	.1006	.1307	.1143	.0943	.112	.112
9	.1132	.0671	.112	.0762	.0943	.0934	.0934
10	.0754	.0503	.0762		.0754	.0747	.0739
11	.0503	.056	.0747		.0747	.0739	.0566
12	.0671	.0747	.0732	.0566	.056	.0739	.0566
13	.0503	.056	.0739	.0566	.056	.0739	.0566
14	.0503	.056	.0747	.0566	.056	.056	.0566
15	.0503	.056	.0747	.0566	.0566	.0566	.0566
16	.0503	.056	.0554	.0566	.0566	.0554	.0566
17	.0503	.0747	.0732	.0566	.056	.0554	.0566
18	.0838	.112		.0754	.0934	.0934	.0943
19	.1509	.168	.1886	.168	.1867	.1524	.1494
20	.1509	.168	.1524	.1867	.1663	.1524	.168
21	.1341	.1494	.1524	.1494	.1478	.1334	.1494
22	.0838	.0934	.0953	.1494	.112	.1143	.0943
23	.0503	.056	.0566	.0943	.0566	.056	.0566
24	.0566	.0335	.0381	.0377	.0566	.0381	.056
Max	**.1509**	**.168**	**.1886**	**.1867**	**.1867**	**.1524**	**.168**
Min	**.0503**	**.0335**	**.0381**	**.037**	**.056**	**.0381**	**.0366**
Avg	**.0786**	**.0766**	**.0842**	**.0821**	**.0858**	**.0807**	**.0797**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] BU 7129
Substation No/ Name :- 144073 / 33/11 KV 5 STAR MIDC
Feeder No / Name : 201 / 11KV Arya SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1285	1.9993	2.1658	1.9616	.8802	1.7353	1.3443
2	2.1285	1.9993	1.829	1.9616	.9145	1.8484	1.643
3	1.9936	1.9993	1.7193	1.9616	.9922	1.8861	1.6804
4	2.0119	1.9616	1.7375	1.9239	.9922	1.9239	1.6804
5	1.3176	1.9239	1.701	1.8107	1.0802	1.9616	1.7177
6	1.6832	1.8484	1.5775	1.531	1.2803	2.0182	1.6804
7	1.5581	1.848	1.6124	.8322	1.1218	1.3957	1.643
8	1.595	2.1502	1.7703	.4715		1.7541	1.2696
9	1.4815	1.5089		.4161	1.166	2.2032	1.9791
10	2.2634	1.6057		.3789	1.9231	2.2405	1.8111
11	2.2257	1.6804		.4029	1.9978	2.2032	1.2178
12	2.5463	2.1879		.4096	1.6991	2.0936	1.9231
13	2.1879	1.9231	1.7924	.3506	1.7364	2.0748	1.5524
14	2.2634	1.7364	2.1845	.4765	2.6326	2.1313	1.7926
15	1.8673	2.5206	2.0182	.5489	2.4832	1.9616	1.8484
16	1.8484	1.307	2.0559	.5325	2.2405	1.9044	1.5154
17	2.2634	2.5149	1.773	.5959	2.5463	1.4937	1.8484
18	1.1694	2.5274	1.8861	.3761	1.9805	1.7177	1.9044
19	2.4143	2.1472	1.8107	.4388	1.9239	1.9605	2.0538
20	2.2257	2.1807	1.6804	.4119	1.9993	1.7177	1.9044
21	1.8861	1.885	.4588	.5239	1.6975	2.0911	2.3577
22	2.2634	2.0538	1.358	.8002	1.475	1.7364	2.4272
23	2.452	2.3712	2.2634	.7407	1.6057	2.2405	2.452
24	2.1845	1.9805	2.1068	1.9239	.8431	1.4563	1.0456
Max	**2.5463**	**2.5274**	**2.2634**	**1.9616**	**2.6326**	**2.2405**	**2.452**
Min	**1.1694**	**1.307**	**.4588**	**.3506**	**.8431**	**1.3957**	**1.0456**
Avg	**1.9983**	**1.9942**	**1.7751**	**.9076**	**1.6179**	**1.9062**	**1.7622**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] BU 7129
Substation No/ Name :- 144073 / 33/11 KV 5 STAR MIDC
Feeder No / Name : 202 / 11 KV Managal Metal SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.3475	.2987	.4572	.2096	.4557	.8589
2	.447	.2858	.3361	.4001	.2191	.3765	.8775
3	.4567	.2667	.2763	.381	.2429	.3567	.8589
4	.4039	.3048	.2763	.362	.2235	.3467	.8589
5	.2953	.3692	.2279	.3048	.2382	.3567	.8775
6	.2235	.3567	.2138	.2561	.3109	.3567	.8589
7	.6182	.7804	.7205	.2743	.4241	.7293	1.1203
8	.9736	1.2955	1.0987	.2987		1.4563	1.1949
9	.9859	2.037		.2724	1.5604	1.307	1.6651
10	2.1879	1.7558		.241	2.0883	1.8446	2.2177
11	2.1879	1.8111		.2431	2.1472	1.9909	2.0851
12	1.8484	1.8671		.2389	2.1399	1.9004	1.8107
13	1.4003	1.9404	2.1216	.204	1.7918	1.7718	1.9022
14	1.7918	2.2405	1.8296	.181	2.2405	1.829	1.9022
15	2.2257	1.587	2.0119	.1772	2.1807	2.3152	2.0119
16	1.7353	1.587	1.701	.1457	2.2218	2.1807	2.1807
17	2.0748	1.9004	1.5466	.2096	1.8673	1.9044	1.8473
18	1.905	1.7737	1.5844	.1882	1.8484		1.7909
19	1.7353	1.7551	1.2616	.1943	1.0105	1.5684	1.3272
20	.6188	.6407	.9808	.1684	.9191	.8962	.6382
21	.4572	.5967	.9214	.1715	.6379	.8402	1.028
22	.3475	.5658	.7735	.2138	.4938	1.0082	.771
23	.3048	.4755	.7293	.2332	.4801	.9709	.6916
24	.4763	.2804	.4096	.3909	.2138	.4755	.9709
Max	**2.2257**	**2.2405**	**2.1216**	**.4572**	**2.2405**	**2.3152**	**2.2177**
Min	**.2235**	**.2667**	**.2138**	**.1457**	**.2096**	**.3467**	**.6382**
Avg	**1.0907**	**1.1175**	**.9660**	**.2586**	**1.1178**	**1.1843**	**1.3478**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] BU 7129
Substation No/ Name :- 144073 / 33/11 KV 5 STAR MIDC
Feeder No / Name : 203 / 11 KV KORGAONKAR SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3336	1.3203	.724	.8215	.9955	1.2826	1.1576
2	1.3957	1.3203	.724	.8215	.9955	1.3203	1.2323
3	1.358	1.3203	.743	.8299	.9877	1.3203	1.1949
4	1.3717	1.3203	.679	.7922	1.0425	1.3203	1.2323
5	1.2449	1.2449	.6478	.7545	1.0425	1.3203	1.2696
6	1.2765	1.1694	.6478	.6348	.9522	1.2826	1.0562
7	1.226	1.2136	.5847	.6516	1.0719	1.1506	1.1949
8	1.1128	1.2449	.6668	.6001		1.226	1.2696
9	1.3256	1.358		.5258	1.1317	1.2696	1.3443
10	1.5089	1.307		.8962	1.2883	1.3957	1.4937
11	1.358	1.423			1.2883	1.4377	
12	1.3957	1.1203		.8299	1.307	1.3769	1.307
13	1.3203	1.2323	.7316	.7655	1.0534	1.4937	1.5497
14	1.2826	1.2136	.8029	.8299	1.0829	1.226	1.1576
15	1.3203	1.2696	.7762	.8215	1.134	1.1389	1.419
16	1.226	1.2323	.6722	.8299	1.2136	1.3256	1.3443
17	1.1317	1.3014	.6173	.7865	1.3392	1.4937	1.4563
18	1.0374	1.2449	.6224	.8048	1.2826	1.1203	1.307
19	1.1506	1.3203	.6348	.8573	1.3203	1.2696	1.5844
20	1.3203	1.2003		.8402	1.1317	1.2136	1.4937
21	1.2637	1.4523	.679		1.226	1.1949	1.3817
22	1.2826	1.3957	.8488	1.0082	1.3769	1.1576	1.226
23	1.2449	1.3336	.7964	.9979	1.226	1.419	1.2012
24	1.4289	1.2826	1.3336	.8402	.9877	1.1694	1.307
Max	**1.5089**	**1.4523**	**1.3336**	**1.0082**	**1.3769**	**1.4937**	**1.5844**
Min	**1.0374**	**1.1203**	**.5847**	**.5258**	**.9522**	**1.1203**	**1.0562**
Avg	**1.2882**	**1.2851**	**.7333**	**.7973**	**1.1512**	**1.2886**	**1.3122**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] **BU 7129**
Substation No/ Name :- 144073 / 33/11 KV 5 STAR MIDC
Feeder No / Name : 204 / 11 KV Silver Zone **SHEDDABLE FEEDER HAVING WEEKLY**
Feeder KV- 11 / OUTGOING **STAGGERING (MIDC, EQUIVALENT)**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0062	2.6406	2.2611		1.6991	1.7918	1.8298
2	2.0576	2.6406	2.2961		1.6975	1.7918	1.7924
3	2.0157	2.6029	2.1776		1.6975	1.7918	1.7924
4	2.0285	2.6029	2.0919		1.6991	1.7918	1.7551
5	1.861	2.5652	1.9616		1.7541	1.7541	1.7551
6	1.933	2.4897	2.0008		1.6409	1.6975	1.643
7	1.9448	2.452	2.0517		1.5154	1.7737	1.7737
8	2.3388	2.5652	1.9006			1.6804	1.7737
9	2.6595	2.7538			1.8111	1.8671	2.0748
10	3.4894	2.9047			1.9418	1.6263	2.2068
11	3.8104	3.3573			1.9993	1.9418	2.1098
12	3.2065	3.0178		1.1336	2.037	2.1879	2.1125
13	3.1687	2.8567	1.7737	1.363	1.7364	2.0725	2.1502
14	3.3196	3.0434	1.7737	1.4937	1.9805	2.2822	2.1125
15	2.9235	3.4894	1.9605	1.4969	2.1125	2.2257	2.1691
16	3.2442	3.2487	1.7924	1.4266	2.1691	2.1098	2.1313
17	3.3008	3.263	1.8107	1.4377	2.0748	2.2405	2.0351
18	2.8292	2.9127	1.6975	1.3717	2.037	2.0911	2.0182
19	2.8669	3.1367	1.6804	1.46	1.9805	2.2405	2.1098
20	2.8292	2.7618		1.5466	1.9616	1.9791	1.9605
21	2.8292	2.5972		1.8111	1.9239	1.8671	1.8861
22	2.4897	2.6139		1.6057	1.8673	1.9044	1.7187
23	2.8292	2.4615		1.773	1.8484		1.8296
24	2.0978	2.6783	2.2565		1.6787	1.8107	1.7924
Max	**3.8104**	**3.4894**	**2.2961**	**1.8111**	**2.1691**	**2.2822**	**2.2068**
Min	**1.861**	**2.452**	**1.6804**	**1.1336**	**1.5154**	**1.6263**	**1.643**
Avg	**2.6700**	**2.819**	**1.9679**	**1.4933**	**1.8636**	**1.9356**	**1.9389**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] BU 7129
Substation No/ Name :- 144073 / 33/11 KV 5 STAR MIDC
Feeder No / Name : 205 / 11 kV VILSON ROOFING SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.225	4.225	3.5101	4.225	2.0332	4.1533	4.6304
2	4.2196	4.4201	4.2486	4.5344	2.0332	4.2676	4.7424
3	4.145	4.4963	3.8649	4.382	2.0683	4.3439	4.6677
4	4.1495	4.5725	3.9209	4.6106	2.0908	4.3058	4.7051
5	4.2816	4.4582	3.9609	4.7249	2.073	4.2486	4.7051
6	4.8474	4.3381	5.0297	4.5725	2.167	4.1914	4.6677
7	4.6022	3.8866	5.1821	3.3385	2.1849	4.2676	4.3317
8	3.345	3.7723	4.3877	2.5206		4.0962	2.9874
9	4.2105	4.9535		3.1687	3.9986	3.8836	4.3759
10	5.0488	4.0175		2.4209	3.3951	4.1495	4.2816
11	4.763	4.7154		2.6699	4.0364	3.9209	3.9609
12	5.1821	3.9609		2.4272	4.904	4.772	4.2438
13	4.5725	3.3608	3.5848	2.1285	3.3234	3.9609	4.7531
14	6.0014	4.0175	3.9609	2.1098	4.7154	5.6965	4.5268
15	4.1872	4.4063	4.1076	2.2779	4.0364	5.0926	4.7531
16	4.7154	3.7902	4.2943	2.8006	4.3759	4.1118	4.537
17	4.3004	4.0175	4.1533	2.5766	4.4963	3.6969	4.3193
18	5.2393	3.9232	4.225	2.2965	3.942	4.9291	4.537
19	3.0102	4.0175	3.3008	2.1472	4.6677	4.481	4.5184
20	3.81	3.1786	3.9609	2.0351	4.3439	4.1823	4.4063
21	3.4294	3.6214	3.3385	2.1068	3.9628	4.3317	4.7531
22	3.6591	3.9043	3.8855	1.957	3.8855	4.1823	3.9609
23	3.546	4.5268	4.3381	2.2546	3.9057	4.481	3.8289
24	4.225	2.8669	4.1307	3.3951	2.1582	3.7723	4.4437
Max	**6.0014**	**4.9535**	**5.1821**	**4.7249**	**4.904**	**5.6965**	**4.7531**
Min	**3.0102**	**2.8669**	**3.3008**	**1.957**	**2.0332**	**3.6969**	**2.9874**
Avg	**4.3215**	**4.0603**	**4.0693**	**2.9867**	**3.4260**	**4.3133**	**4.4016**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] BU 7129
Substation No/ Name :- 144073 / 33/11 KV 5 STAR MIDC
Feeder No / Name : 206 / 11KV Mahalaxmi SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7194	.2027	.8583	1.9239	.1524	1.9805	1.5684
2	1.6461	.2027	1.2226	1.9239	.1677	1.9805	1.1203
3	1.7193	.1882	1.6817	1.9239	.1486	1.9805	1.2696
4	1.7372	.1448	1.6301	1.8861	.164	1.9805	1.643
5	1.7187	1.3435	1.7002	1.8484	.2968	1.9805	1.8671
6	1.7187	1.9616	1.6827	1.8107	.3203	1.9616	2.2032
7	1.7741	2.0182	1.7002	2.037	.1412	1.3169	1.6804
8	.8684	2.2257	.587	.3185		.3841	1.307
9	2.9047	2.3011		.2134	1.6301	2.838	1.8671
10	2.6406	2.5393		.2058	2.0538	3.8485	3.4705
11	1.8484	2.6783		.2462	2.1502	2.8292	3.131
12	3.9628	2.4768		.2134	3.4168	3.3234	2.452
13	1.448	2.1125	2.8292	.141	1.9605	3.6969	2.2634
14	3.2065	2.894	1.8671	.136	3.4915	3.8477	3.006
15	3.2442	2.4832	3.3951	.1467	2.4272	3.3981	3.3008
16	1.773	1.419	1.6991	.1467	1.7002	2.1845	1.7741
17	2.6406		2.1502	.1762	1.5655	2.3712	1.8296
18	3.4894	2.0559	1.6975	.192	2.7538	2.3152	1.363
19	2.9047	2.3815	2.7726	.2534	2.2634	2.0911	2.0538
20	3.2065	1.9774	2.4143	.2	1.3375	1.4937	2.0911
21	.3258	.8619	1.9239	.2256	2.1691	1.531	
22	1.358	.8383	.9214	.1762	1.278	1.9418	1.448
23	2.0748	.5376	1.7353	.2044	2.1502	1.9418	1.6095
24	1.7013	.2027	.4858	.2027	.1412	1.9993	.7468
Max	**3.9628**	**2.894**	**3.3951**	**2.037**	**3.4915**	**3.8485**	**3.4705**
Min	**.3258**	**.1448**	**.4858**	**.136**	**.1412**	**.3841**	**.7468**
Avg	**2.1513**	**1.5673**	**1.7477**	**.6980**	**1.4730**	**2.3007**	**1.9594**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] BU 7129
Substation No/ Name :- 144079 / 33/11 KV MIDC G SHIRGAON
Feeder No / Name : 201 / 11 KV Vardhaman Feeder SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4387	2.5339	2.1148	2.0195	1.448	1.8861	2.0576
2	2.2862	2.4768	2.3624	1.9814	1.4289	1.9052	1.9052
3	2.4387	2.3815	1.829	1.9052	1.3336	1.8671	2.0195
4	2.3624	2.2481	1.848	1.8671	1.4098	1.9052	2.0957
5	2.3624	2.2862	1.7337	1.829	1.467	1.9814	1.9814
6	2.4196	2.2862	1.7528	1.829	1.448	1.9624	2.0576
7	2.4196	2.0767	1.7528	1.448	1.467	2.0195	2.553
8	1.829	1.5623	2.1719	1.5623	1.6004	1.7718	1.5623
9	2.6673	2.3815	2.3624	1.2574	1.848	1.9814	2.3243
10	2.9721	2.7816	2.6101	1.2384	2.2481	2.7625	2.7625
11	2.9531	3.0483	2.8959	1.2384	2.0957	2.934	3.0102
12	3.1817	2.8578	2.2291	1.2765	2.2862	2.7816	2.6292
13	2.1148	2.6673	2.191	1.2955	2.1719	2.6673	2.191
14	2.1529	2.8578	2.8578	1.3336	2.21	2.5339	2.6292
15	2.3434	2.4768	2.8959	1.2955	2.0957	2.3053	2.6673
16	2.8578	2.3243	2.2481	1.3336	2.1719	2.572	2.7054
17	2.3434	2.0957	1.7147	1.3146	1.9052	2.3815	2.0195
18	2.2481	2.1529	2.1338	1.3336	1.7147	2.3624	1.6766
19	1.7528	2.4387	1.9052	1.3336	1.9624	2.0957	2.5149
20	1.829	1.8099	1.8671	1.3717	1.6956	2.0195	2.2291
21	1.9814	1.9624	2.0195	1.3717	1.8671	2.0576	2.0195
22	2.0386	2.3815	2.2862	1.3146	1.9814	2.4387	2.4387
23	2.4006	2.4577	2.0576	1.3336	1.6575	2.2862	2.4387
24	2.7054	2.4387	2.3243	1.9052	1.4289	1.9052	2.0957
Max	**3.1817**	**3.0483**	**2.8959**	**2.0195**	**2.2862**	**2.934**	**3.0102**
Min	**1.7528**	**1.5623**	**1.7147**	**1.2384**	**1.3336**	**1.7718**	**1.5623**
Avg	**2.3791**	**2.3744**	**2.1735**	**1.4995**	**1.7893**	**2.2243**	**2.2743**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] BU 7129
Substation No/ Name :- 144079 / 33/11 KV MIDC G SHIRGAON
Feeder No / Name : 202 / 11 KV Mather & Platt SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4098	1.5242	1.3527	1.3717	1.3336	1.3527	1.3717
2	1.4289	1.4861	1.5432	1.3336	1.3336	1.3527	1.3336
3	1.467	1.4289	1.5051	1.3336	1.3717	1.1431	1.3336
4	1.448	1.3336	1.3527	1.3717	1.3908	1.2384	1.3717
5	1.448	1.3717	1.2384	1.3717	1.3908	1.3146	1.3717
6	1.467	1.3908	1.1812		1.3336	1.2955	1.4098
7	1.3336	1.3717	1.4289	1.3717	1.3336	1.3908	1.4098
8	1.448	1.6385	1.4289	1.3717	1.2955	1.6385	1.6766
9	1.7337	1.9052	1.4861	1.3717	1.467	1.829	1.8671
10	1.848	2.2862	1.6385	1.3527	1.6385	2.191	2.1529
11	1.8861	2.2862	1.848	1.3336	1.9052	2.5149	2.3243
12	1.9433	1.8671	1.8861	1.3717	2.0195	2.1338	1.9052
13	1.7528	2.0195	1.5813	1.3717	2.0957	2.0195	1.6766
14	1.9814	2.1719	1.7337	1.3717	1.9814	2.1338	2.2481
15	1.848	1.9052	1.5623	1.3336	2.21	1.9433	2.0005
16	2.0195	1.7909	1.6575	1.3717	2.0195	1.9433	1.8099
17	1.6194	1.5623	1.5242	1.3527	1.5242	1.5813	1.4861
18	1.4861	1.5623	1.3717	1.3717	1.5242	1.4861	1.4861
19	1.3908	1.3717	1.3336	1.3908	1.2955	1.4861	1.5242
20	1.2955	1.2574	1.2574	1.3527	1.2193	1.4098	1.3146
21	1.3908	1.2955	1.3336	1.3908	1.2574	1.2574	1.4098
22	1.3717	1.3336	1.4098	1.3908	1.2955	1.4861	1.4289
23	1.5242	1.4861	1.4861	1.3717	1.5432	1.448	1.448
24	1.4289	1.5242	1.5051	1.4098	1.3717	1.5242	1.4098
Max	**2.0195**	**2.2862**	**1.8861**	**1.4098**	**2.21**	**2.5149**	**2.3243**
Min	**1.2955**	**1.2574**	**1.1812**	**1.3336**	**1.2193**	**1.1431**	**1.3146**
Avg	**1.5821**	**1.6321**	**1.4853**	**1.3667**	**1.5480**	**1.6297**	**1.6154**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] BU 7129
Substation No/ Name :- 144079 / 33/11 KV MIDC G SHIRGAON
Feeder No / Name : 204 / Tamgoan VG GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.6668	.8002	.7621	.6097	.5716	.7621
2	.5716	.6287	.8573	.724	.5906	.743	.724
3	.5716	.6097	.8002	.724	.5716	.6097	.6859
4	.6097	.6668	.9335	.7621	.6287	.5716	.6859
5	.6859	.7621	.9145	.8002	.9526	.7621	.7621
6	.8573	.8954	.9717	.8383	1.105		.9907
7		1.1431	1.0288	1.0669	1.2193	1.2384	1.2574
8	1.4289	1.3336	1.3527	1.3336	1.448	1.467	1.448
9	1.3908	1.4098	1.3146	1.4098	1.3336	1.3336	1.2193
10	1.2574	1.4098	1.448	1.1812	1.2955	1.448	1.2193
11	1.1812	1.2193	1.2193	.9526	1.105	1.2955	1.2574
12	1.1431	1.1431	1.105	.9145	1.0669	1.2574	1.105
13	.9907	.8764	.9907	.8002	.9907	1.0288	.9907
14	.9145	.9526	.8954	.7621	1.0288	1.086	.9145
15	.8383	1.0288	1.0669	.7621	.9526	1.105	1.0098
16	.9335	1.0669	.9335	.724	1.0669	1.105	1.0479
17	1.0479	1.105	1.1812	.724	1.1431	1.1812	1.105
18	1.1812	1.3146	1.2574	.7621	1.2193	1.2574	1.3146
19	1.467	1.467	1.4098	1.2574	1.6194	1.5623	1.6194
20	1.4098	1.4098	1.3717	1.2384	1.5623	1.3336	1.3527
21	1.2384	1.2574	1.3336	1.2003	1.2955	1.2193	1.2384
22	1.0479	1.0479	1.105	1.0288	1.1241	.9907	1.105
23	.7811	.8192	.8383	.8192	.7621	.9145	.8764
24	.6097	.6287	.8573	.8002	.6668	.6287	.8002
Max	**1.467**	**1.467**	**1.448**	**1.4098**	**1.6194**	**1.5623**	**1.6194**
Min	**.5716**	**.6097**	**.8002**	**.724**	**.5716**	**.5716**	**.6859**
Avg	**.9882**	**1.0359**	**1.0828**	**.9312**	**1.0566**	**1.0744**	**1.0622**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] BU 7129
Substation No/ Name :- 144079 / 33/11 KV MIDC G SHIRGAON
Feeder No / Name : 205 / 11 KV Patel Petro feeder SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.105	1.3336	1.1431	.7621	.743	1.3146	1.2574
2	1.2574	1.2955	1.3336	.7621	.7621	1.2384	1.1812
3	1.2955	1.2955	1.3146	.8002	.7811	1.2193	1.2955
4	1.2193	1.2384	1.1622	.7621	.724	1.3336	1.2193
5	1.2193	1.2384	1.1431	.724	.7049	1.3527	1.1431
6	1.3908	1.2574	.9335	.6859	.8002	1.4098	.8383
7	1.3717	1.3908	.8954	.724	.8192	1.3527	1.2955
8	1.6385	1.6766	.8954	.724	.8764	1.9243	1.4098
9	2.4006	1.2003	1.7909	.6859	1.3336	1.9052	1.7909
10	1.6766	1.9433	1.6956	.6859	1.4861	1.829	1.6194
11	2.1148	2.4768	1.9624	.6287	1.5623	1.5242	2.3243
12	2.5149	2.3243	1.9052	.9145	1.5242	2.4768	1.9052
13	2.21	1.6004	1.7337	.6859	1.7147	2.1719	1.3336
14	2.4387	1.9814	1.6575	.6859	1.5242	2.572	2.0005
15	2.0576	2.0957	1.7909	.6859	2.0957	2.4958	2.3815
16	1.9433	2.2862	1.4098	.6859	2.0957	1.3717	2.3815
17	1.848	2.21	1.8099	.7049	1.7147	1.3146	2.0195
18	1.8671	2.1148	1.0288	.724	2.0957	2.21	2.191
19	1.3336	1.5242	.9907	.724	1.6004	2.1719	1.829
20	.9907	.743	.9526	.7049	.7621	1.7147	.9526
21	1.448	1.2765	.9526	.724	1.3527	1.3717	1.3717
22	1.4098	1.2574	.9145	.743	1.3717	1.2574	1.4098
23	1.3336	1.2955	.8383	.743	1.3336	1.2955	1.4289
24	.8002	1.3336	1.1812	.8002	.743	1.3717	1.3336
Max	**2.5149**	**2.4768**	**1.9624**	**.9145**	**2.0957**	**2.572**	**2.3815**
Min	**.8002**	**.743**	**.8383**	**.6287**	**.7049**	**1.2193**	**.8383**
Avg	**1.6202**	**1.5996**	**1.3098**	**.7280**	**1.2717**	**1.6750**	**1.5797**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] BU 7129
Substation No/ Name :- 144079 / 33/11 KV MIDC G SHIRGAON
Feeder No / Name : 206 / 11KV Devi gas SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2574	1.2384	2.1148	1.2574	.743		1.2193
2	1.105	1.2193	1.1622	1.2193	.743	1.2574	1.2574
3	1.105	1.1431	.9526	1.1812	.724	.9717	1.2193
4	1.1431	1.1431	1.1812	1.105	.724	1.1812	1.1812
5	1.105	1.105	1.1241	1.105	.743	1.3146	1.1431
6	1.086	1.2003	1.0479	1.1431	.743	1.2955	1.1812
7	1.0669	1.105	1.086	1.105	.724	1.448	1.1812
8	1.2193	.9145	1.2955	.8383	.724	1.4289	1.105
9	1.467	1.2384	1.6575	.8002	.9526	1.6956	1.7909
10	1.6766	1.6766	1.6575	.8192	1.4098	2.1719	2.0005
11	1.8099	1.7528	1.7147	.8383	1.448	2.1719	1.8099
12	1.448	1.5623	1.5623	.7049	1.4861	1.8671	2.0005
13	1.6194	1.5242	1.5242	.743	1.4098	1.8671	1.6766
14	1.7718	1.829	1.6004	.724	1.448	2.1338	1.7147
15	1.7909	1.7909	1.7528	.6668	1.6766	1.7147	1.9624
16	1.6766	1.829	1.6194	.7621	1.6385	2.1338	1.7147
17	1.6575	1.7909	1.848	.6859	1.3336	1.9433	1.7147
18	1.3336	1.6385	1.448	.7049	1.3527	2.0195	1.9052
19	1.105	1.8099	1.4098	.724	1.105	1.3717	1.4861
20	1.2765	1.448	1.4861	.724	1.2193	1.3336	1.3908
21	1.5623	1.3908	1.6004	.743	1.3527	1.2955	1.3717
22	1.2765	1.3908	1.7528	.724	1.3527	1.105	1.448
23	1.5623	1.2765	1.5242	.724	1.1431	1.1431	1.5623
24	1.3336	1.2574	1.2765	1.2955	.743	1.086	1.1812
Max	**1.8099**	**1.829**	**2.1148**	**1.2955**	**1.6766**	**2.1719**	**2.0005**
Min	**1.0669**	**.9145**	**.9526**	**.6668**	**.724**	**.9717**	**1.105**
Avg	**1.3940**	**1.4281**	**1.4750**	**.8891**	**1.1225**	**1.5631**	**1.5091**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] BU 7129
Substation No/ Name :- 144083 / 33/11 KV kenawade
Feeder No / Name : 201 / Mhakve AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.3429	.3429	.0514	.0335	.0381	.0343
2	.3018	.3429	.3429	.0514	.0335	.0381	.0343
3	.3018	.3429	.3429	.0514	.0335	.0381	.0343
4	.3018	.3429	.3429	.0514	.0335	.0381	.0514
5	.3521	.4191	.4108	.0514	.0335	.0381	.0857
6	.3856	.4954	.4458	.0514	.0335	.0381	.0514
7	.6036	.8002	.5658	.0514	.0335	.0381	.0343
8	.9389	1.0479	.7716	.0503	.0335	.0572	.0686
9	.9389	1.105	.7716	.0838	.0335	.0572	.0686
10			.0343	.0671	.0335	.0762	.0343
11	.0381	.0762	.0343	1.3748	1.3908	1.3032	1.1831
12	.0381	.0686	.0686	1.6095	1.6004	1.5432	1.3032
13	.0381	.0514	.0514	1.5927	1.6956	1.6804	1.406
14	.0381	.0857	.0514	1.6095	1.6194	1.5775	1.4403
15	.0381	.0857	.0514	1.5257		1.4232	1.3717
16	.0381	.0686	.0514	1.4586	1.6004	1.3375	1.2346
17	.0762	.0686	.0514	1.3077	1.3717	1.1831	1.0631
18	.0762	.0686	.0514	.9724	1.1622	.8916	.9088
19	.0762	.0686	.0686	.0503	.0381	.0514	.0857
20	.0762	.0686	.0686	.0503	.0572	.0686	.1029
21		.0686	.0514	.0505	.0381	.0514	.1029
22	.0762	.0686	.0514	.0503	.0381	.0686	.0686
23	.0572	.0514	.0514	.0503	.0381	.0857	.0686
24	.3018	.3429	.3429	.0514	.0335	.0381	.0343
Max	**.9389**	**1.105**	**.7716**	**1.6095**	**1.6956**	**1.6804**	**1.4403**
Min	**.0381**	**.0514**	**.0343**	**.0503**	**.0335**	**.0381**	**.0343**
Avg	**.2452**	**.2818**	**.2257**	**.5131**	**.4791**	**.4900**	**.4530**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] BU 7129
Substation No/ Name :- 144083 / 33/11 KV kenawade
Feeder No / Name : 202 / Mhakve Gavthan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.1524	.1494	.1307	.1478	.1524	.1494
2	.1478	.1524	.1494	.1307	.1478	.1524	.1494
3	.1478	.1524	.1494	.1307	.1478	.1524	.1494
4	.1478	.1524	.1494	.1307	.1478	.1524	.1494
5	.1848	.1905	.1867	.1494	.2033	.1905	.1494
6	.2957	.3048	.2427	.2427		.2667	.2241
7	.3142	.3429	.3547	.3361	.3326	.3429	.3361
8	.2957	.3429	.2987	.2957	.2957	.3429	.3547
9	.2772	.3048	.3734	.3142	.2772	.3048	.2987
10			.2614	.2587	.2587	.2858	.2614
11	.2667	.2667	.2427	.2772	.2667	.2241	.2614
12	.2667	.3174	.2614	.2033	.2667	.2427	.1867
13	.2858	.2801	.2614	.2402	.2667	.2054	.2241
14	.2858	.2427	.2427	.2012	.2667	.1524	.1867
15	.2667	.2241	.2054	.1848		.1867	.2054
16	.2858	.2241	.2241	.2033	.2858	.1867	.2241
17	.3048	.2614	.2614	.2033	.3048	.2614	.2241
18	.3429	.3361	.3174	.2347	.3429	.3361	.2801
19	.5525	.4668	.5041	.5175	.5716	.4481	.5041
20	.5716	.0485	.5228	.5359	.5335	.4108	.5041
21		.4108	.4668	.4435	.4191	.3734	.4294
22	.4382	.2614	.4108	.3881	.3429	.2987	.3361
23	.2667	.2054	.2427	.2033	.2286	.2054	.2054
24	.1663	.1905	.1715	.168	.1478	.1905	.1867
Max	**.5716**	**.4668**	**.5228**	**.5359**	**.5716**	**.4481**	**.5041**
Min	**.1478**	**.0485**	**.1494**	**.1307**	**.1478**	**.1524**	**.1494**
Avg	**.2845**	**.2535**	**.2771**	**.2552**	**.2819**	**.2527**	**.2575**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
KAGAL[043] BU 7129
Substation No/ Name :- 144083 / 33/11 KV kenawade
Feeder No / Name : 203 / Kenavade Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0503	.0572	.0514	.1029	.1174		.1372
2	.0503	.0572	.0514	.1029	.1174	.1524	.1372
3	.0457	.0572	.0514	.1029	.1174	.1524	.1372
4	.061		.0514	.1029	.1174	.1524	.1372
5	.0671	.0762	.0514	.12	.2012	.2286	.1372
6	.0671	.0953	.0686	.1543	.2683	.3429	.2401
7	.0838	.1143	.1029	.3258	.4527	.4954	.4287
8	.1006	.1143	.0857	.4527	.7209	.743	.6344
9	.0838	.1143	.0857	.5636	.7377	.7621	.583
10			.0857	.0663	.0838	.1143	.0686
11	.8954	.8573	.6516		.0953	.0686	.0514
12	1.2193	.9774	.8916	.0663	.0953	.0857	.0514
13	1.2955	1.0631	.9602		.0762	.0857	
14	1.3336	1.0288	.7716	.0497	.0762	.0857	.0686
15	1.1622	.8916	.7545	.0663		.1867	.0686
16	1.105	.8573	.703	.0671			.0686
17	1.0288	.7888	.5316	.0671	.0953	.0686	.0857
18	.7811	.5316	.3772	.0671	.1143	.0857	.0857
19	.0953	.0686		.0671	.0953	.1029	.0857
20	.0953	.0686	.0686	.0671	.0953	.0686	.0686
21		.0686	.0686	.0671	.0762	.0514	.0686
22	.0762	.0514	.0686	.0671	.0762	.0514	.0514
23	.0762	.0514	.0686	.0671	.0762	.0514	.0514
24	.0503	.0572	.0514		.1174	.1905	.1372
Max	**1.3336**	**1.0631**	**.9602**	**.5636**	**.7377**	**.7621**	**.6344**
Min	**.0457**	**.0514**	**.0514**	**.0497**	**.0762**	**.0514**	**.0514**
Avg	**.4465**	**.3658**	**.2892**	**.1340**	**.1829**	**.1967**	**.1558**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
MURGUD[045] BU 7153
Substation No/ Name :- 144018 / 33/11 Kv KAPASHI
Feeder No / Name : 201 / 11KV KAPASHI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.381	.3239				
2	.381	.362	.3239				
3	.381	.3429	.3239				
4	.381	.3429	.3239				
5	.381	.362	.381				
6	.381	.4954	.4382			.0572	.0572
7	.5906	.8383	.7049			.0381	.0572
8	.8764	1.0669	.9717				
9		.9088	.8764				
10	.0381						
11	.0572			.9774	.9945	1.105	1.0288
12	.0572			1.4403	1.3527	1.2003	1.0974
13	.0572			1.5089	1.2517	1.4289	1.2517
14				1.4746	1.2346	1.448	1.286
15				1.3546	1.2003	1.3908	1.2003
16				1.3032	1.286	1.2384	
17				1.2384	1.1431	1.0117	
18				1.0098	.8954	.7716	.8764
19	.0762	.0762	.1143	.0762	.0572	.0572	.0953
20	.0953	.0762	.1143	.0953	.0572		.0762
21	.0762	.0762	.0953	.0762	.0572	.0572	.0762
24	.3239	.381	.3239				
Max	**.8764**	**1.0669**	**.9717**	**1.5089**	**1.3527**	**1.448**	**1.286**
Min	**.0381**	**.0762**	**.0953**	**.0762**	**.0572**	**.0381**	**.0572**
Avg	**.2798**	**.4392**	**.4089**	**.9595**	**.8664**	**.8170**	**.6457**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
MURGUD[045] **BU 7153**
Substation No/ Name :- 144018 / 33/11 Kv KAPASHI
Feeder No / Name : 202 / 11 KV Hasoor Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572			.583	.6859	.743	.8916
2	.0572			.583	.6859	.743	.9259
3	.0572			.583	.6859	.7621	.9259
4	.0572			.583	.6859	.8573	.8916
5	.0572			.583	.6859	.9526	.8916
6	.0572			.6173	.7716	.9526	.8916
7	.0572			.6516	.8573	1.0479	1.0288
8	.0572			.823	.8916	1.2574	1.0974
9	.0762			.823	.823	1.0479	1.0974
10	.0572						
11	.7621	.6859	.7811				
12	.8764	.8573	.9526				
13	.9526	.8916	.9717				
14	.9526	.9175	1.0479				
15	.8002	1.0288	1.105				
16	.8573	.823	1.1431				
17	.7811	.9907	1.105				
18	.6668	.6478	.7545				
19	.1143	.1334	.1715	.1524	.1524	.1905	.2096
20	.0953	.1334	.1715	.1524	.1524	.1715	.2286
21	.0953	.1334	.1905	.1524	.1524	.1524	.2096
24	.0572			.583	.6173	.724	.6859
Max	**.9526**	**1.0288**	**1.1431**	**.823**	**.8916**	**1.2574**	**1.0974**
Min	**.0572**	**.1334**	**.1715**	**.1524**	**.1524**	**.1524**	**.2096**
Avg	**.3456**	**.6584**	**.7631**	**.5285**	**.6037**	**.7386**	**.7673**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
MURGUD[045] BU 7153
Substation No/ Name :- 144018 / 33/11 Kv KAPASHI
Feeder No / Name : 203 / 11 KV MUGALI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.381	.5716				
2	.4191	.381	.5716				
3	.4191	.362	.5716				
4	.4191	.362	.5716				
5	.4191	.4191	.5906				
6	.4191	.5335	.6097			.2667	.1524
7	.6859	.7621	.8002			.3239	.1715
8	.724	.8383	.8764				
9	.7049	.823	.9145				
10	.0762						
11	.0762			.9602	1.0288	.9526	
12	.0953			1.0288	1.2346	1.0479	
13	.1143			1.166	1.3032	1.1431	1.989
14				1.2689	1.2346	1.2384	2.7092
15				1.2346	1.166	1.2193	3.1245
16				1.166	1.1317	1.1431	
17				1.1431	1.1431	.9945	
18				.9526	.9907	.8916	2.8578
19	.1524	.2667	.3048		.1143	.381	.5335
20	.1524	.2667	.2858	.3048	.3048	.362	.4954
21	.1143	.2667	.3048		.381	.3429	.4382
24	.4191	.381	.5716				
Max	**.724**	**.8383**	**.9145**	**1.2689**	**1.3032**	**1.2384**	**3.1245**
Min	**.0762**	**.2667**	**.2858**	**.3048**	**.1143**	**.2667**	**.1524**
Avg	**.3429**	**.4649**	**.5804**	**1.025**	**.9121**	**.7928**	**1.3857**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
MURGUD[045] BU 7153
Substation No/ Name :- 144018 / 33/11 Kv KAPASHI
Feeder No / Name : 204 / 11 KV LINGNOOR AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381			.7545	.8573	.7811	.6859
2	.0381			.7545	.8573	.7811	.6859
3	.0381			.7545	.8573	.7811	.6859
4	.0381			.7545	.8573	.8002	.6859
5	.0381			.7716	.8573	.8002	.6859
6	.0381			.7888	.8573	.9145	.6859
7	.0381			.9602	.9431	1.1431	.9602
8	.0381			1.1317	1.3375	1.4289	1.0974
9	.0381			1.0631	1.2689	1.2955	1.0974
10	.0381						
11	1.6575	.9259	1.4861				
12	1.7528	1.3717	1.5623				
13	1.8099	1.4403	1.7528				
14	1.7528	1.3763	1.7528				
15	1.7337	1.3717	1.7147				
16	1.5242	1.3717	1.6385				
17	1.5242	1.448	1.5623				
18	1.1431	1.2193	1.166				
19	.0381	.2286	.1905	.1524	.0762	.1524	.1715
20	.0572	.2667	.2286	.2286	.1524	.0953	.1524
21	.0381	.1905	.2286	.2667	.1524	.0572	.1524
24	.0381			.7202	.823	.7811	.7202
Max	**1.8099**	**1.448**	**1.7528**	**1.1317**	**1.3375**	**1.4289**	**1.0974**
Min	**.0381**	**.1905**	**.1905**	**.1524**	**.0762**	**.0572**	**.1524**
Avg	**.6114**	**1.0192**	**1.2076**	**.7001**	**.7613**	**.7547**	**.6513**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
MURGUD[045] BU 7153
Substation No/ Name :- 144018 / 33/11 Kv KAPASHI
Feeder No / Name : 205 / 11 KV Arjunwada Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.6478	1.3336				
2	.6097	.6287	1.3527				
3	.6097	.5906	1.3527				
4	.6097	.5906	1.3717				
5	.6097	.6478	1.5242				
6	.6097	.6859	1.7528			.4001	.4191
7	.8192	.8954	1.9433			.4572	.4572
8	1.105	.8383	2.1338				
9	.9907	.9259	2.191				
10	.0572						
11	.0762				1.9547	2.3815	2.5034
12	.0953				2.3663	2.8959	
13	.1334			1.6118	.7545	2.8578	2.6749
14				2.2634	.8573	3.0483	2.7435
15				2.2634	.7888	3.0483	2.934
16				2.4006	.7888	3.0864	
17				2.6673	.7621	2.6578	2.5911
18				1.9624	.5716	2.2977	2.0576
19	.1524	.4763	.6668	.5335	.0953	.5335	.4001
20	.1143	.4763	.6668	.5716	.4191	.5906	.381
21	.1143	.4572	.6478	.5906	.4572	.6097	.381
24	.6097	.6478	1.3336				
Max	**1.105**	**.9259**	**2.191**	**2.6673**	**2.3663**	**3.0864**	**2.934**
Min	**.0572**	**.4572**	**.6478**	**.5335**	**.0953**	**.4001**	**.381**
Avg	**.4662**	**.6545**	**1.4054**	**1.6516**	**.8923**	**1.9127**	**1.5948**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
MURGUD[045] BU 7153
Substation No/ Name :- 144018 / 33/11 Kv KAPASHI
Feeder No / Name : 206 / 11 KV Vadgaon Vg GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2858	.3239	.2477	.2667	.1905	.1905
2	.1715	.2667	.3048	.2477	.2286	.1905	.1715
3	.1715	.2667	.3048	.2477	.2286	.1905	.1715
4	.1715	.2667	.3048	.2477	.2286	.1905	.1715
5	.2667	.3048	.3239	.2477	.3048	.1905	.1715
6	.3429	.4191	.3429	.2477	.362	.3429	.2858
7	.4001	.4191	.362	.381	.4001	.3429	.4001
8	.4191	.4191	.4382	.4001	.4382	.4001	.4001
9	.362	.3801	.4382	.381	.4191	.3429	.4382
10	.381	.3801	.4382	.362	.4572	.381	.4001
11	.2858	.3077	.3429	.3429	.3429	.3429	.381
12		.3429	.2858	.3048	.3239	.2667	.3429
13	.3048	.2858	.3048	.3048	.3048	.2667	.2858
14	.2667	.2667	.2667	.2477	.2096	.2667	.3048
15	.3048	.2858	.2286	.2667	.1905	.2667	.2858
16	.2858	.3048	.2858	.2667	.3048	.2858	.2667
17	.3048	.3048	.3239	.2858	.3239	.3429	.3239
18	.4954	.4572	.4763	.362	.4382	.4954	.4191
19	.8192	.7049	.8573	.743	.7621	.8192	.7811
20	.7049	.743	.7811	.7049	.6668	.7811	.743
21	.6478	.6287	.6287	.6668	.5716	.6859	.6097
22	.4001	.4382	.4572	.4382	.4001	.381	
23	.2286	.3239	.3048	.3048	.3048	.2858	.3429
24	.1905	.2858	.3239	.2858	.2667	.2286	.2286
Max	**.8192**	**.743**	**.8573**	**.743**	**.7621**	**.8192**	**.7811**
Min	**.1715**	**.2667**	**.2286**	**.2477**	**.1905**	**.1905**	**.1715**
Avg	**.3529**	**.3787**	**.3937**	**.3556**	**.3644**	**.3532**	**.3529**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
MURGUD[045] BU 7153
Substation No/ Name :- 144018 / 33/11 Kv KAPASHI
Feeder No / Name : 207 / 11 KV BALEGHOL GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1334	.1143	.1143	.1143	.1334	.1143
2	.0953	.1143	.1143	.1143	.0953	.1334	.0953
3	.0953	.1143	.1143	.1143	.0953	.1143	.0953
4	.0953	.1143	.1143	.1143	.0953	.1334	.0953
5	.1715	.1334	.1524	.1524	.1524	.1905	.1715
6	.2096	.2286	.2286	.2096	.2096	.2477	.2477
7	.3048	.3048	.2858	.2667	.2858	.2667	.2858
8	.3429	.3239	.3239	.2667	.3239	.2858	.3429
9	.2858	.2896	.2858	.2858	.2858	.3048	.3239
10	.2858	.2353	.2858	.2286	.2477	.2667	.2858
11	.1905	.2353	.2477	.2096	.2286	.2667	.2477
12	.1715	.2477	.1905	.2096	.2096	.2096	.2286
13	.1905	.2286	.2286	.2286	.2096	.2286	.2477
14	.1905	.2096	.1905	.1905	.1905	.2096	.1905
15	.1715	.1905	.1715	.1905	.2096	.2096	.1715
16	.1905	.2096	.1905	.2477	.2096	.2286	.2286
17	.2286	.2477	.2667	.2286	.2286	.2286	.2286
18	.3429	.3429	.3048	.2858	.3239	.3429	.3239
19	.4954	.5144	.4763	.4572	.4382	.4954	.4954
20	.4763	.4191	.4382	.4382	.4191	.4954	.4001
21	.4001	.381	.4382	.381	.3429	.4001	.3429
22	.3048	.2096	.3048	.2286	.2858	.3048	.2858
23	.1524	.1524		.1334	.1715	.1905	.1715
24	.1143	.1334	.1143	.1334	.1143	.1334	.1334
Max	**.4954**	**.5144**	**.4763**	**.4572**	**.4382**	**.4954**	**.4954**
Min	**.0953**	**.1143**	**.1143**	**.1143**	**.0953**	**.1143**	**.0953**
Avg	**.2342**	**.2381**	**.2427**	**.2262**	**.2286**	**.2509**	**.2398**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
MURGUD[045] BU 7153
Substation No/ Name :- 144018 / 33/11 Kv KAPASHI
Feeder No / Name : 208 / 11 KV JAINAL GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2096	.2477	.2477	.2858	.3239	.3239
2	.2286	.1905	.2477	.2477	.2286	.3048	.3048
3	.2286	.1905	.2477	.2477	.2286	.3048	.3048
4	.2286	.1905	.2477	.2477	.2286	.3429	.3048
5	.4191	.3048	.3048	.3048	.362	.4191	.3048
6	.5335	.5335	.5144	.4572	.4763	.5716	.4954
7	.6287	.6287	.6097	.6287	.6478	.6859	.6859
8	.5525	.6097	.5906	.5906	.6668	.5906	.6668
9	.5144	.5068	.5144	.5906	.5716	.5716	.5716
10	.4382	.5068	.5144	.4954	.4954	.5144	.4382
11	.5144	.4525	.4954	.4572	.5335	.5335	.381
12	.4572	.4001	.4191	.4001	.4382	.4954	.381
13		.4572	.3429	.381	.4572	.4001	.3086
14	.4191	.362	.3429	.3048	.362	.4191	.3239
15	.3429	.3239	.362	.3048	.362	.362	.362
16	.4191	.4382	.4382	.362	.4001	.4763	.2096
17	.5335	.4001	.4763	.4001	.4954	.4382	.4763
18	.6668	.5906	.6287	.4763	.6287	.6287	.6097
19	.8002	.9907	1.0669	.8573	.9717	1.0098	.9526
20	.8764	.9335	1.0288	.8764	.8764	.9907	.8954
21	.6859	.743	.8573	.8002	.6859	.8954	.743
22	.4572	.5335	.5716	.4763	.4954	.4763	.4954
23	.2667	.3048	.3429	.3429	.381	.381	.2667
24	.2667	.2096	.2667	.2477	.2858	.3239	.3429
Max	**.8764**	**.9907**	**1.0669**	**.8764**	**.9717**	**1.0098**	**.9526**
Min	**.2286**	**.1905**	**.2477**	**.2477**	**.2286**	**.3048**	**.2096**
Avg	**.4672**	**.4588**	**.4866**	**.4477**	**.4819**	**.5192**	**.4645**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
MURGUD[045] **BU 7153**
Substation No/ Name :- 144018 / 33/11 Kv KAPASHI
Feeder No / Name : 209 / 11 KV Madyal Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953			.823	.9431	.9145	.6516
2	.0953			.823	.9431	.9145	
3	.0953			.823	.9431	.9145	
4	.0953			.823	.9431	.9526	
5	.0953			.823	.9431	1.0669	
6	.0953			.8573	1.0288	1.105	
7				1.046	1.1145	1.0479	
8				1.0631	1.286	1.086	
9				.9088		.9526	
10							.6516
11	.2096	.9412	1.0669				.8573
12	.2477	.9945	1.2003				.9259
13	.8764	1.0288	1.0479				.0953
14	1.105	.9831	1.105				.1143
15	1.1622	1.0288	1.1622				.1143
16	1.086	.8573	1.1431				
17	1.1431	.9526	1.0098				
18	1.0288	.8764	.8916				
19	.1905	.1905	.1715	.1905	.1334	.0381	.1905
20	.1905	.1715	.1905	.1905	.1334	.0381	.1905
21	.1905	.1715	.1905	.1905	.1143	.0953	.1905
22						.0953	.1905
23						.0953	.1905
24	.0953			.823	.9088	.8954	.583
Max	**1.1622**	**1.0288**	**1.2003**	**1.0631**	**1.286**	**1.105**	**.9259**
Min	**.0953**	**.1715**	**.1715**	**.1905**	**.1143**	**.0381**	**.0953**
Avg	**.4499**	**.7451**	**.8345**	**.7219**	**.7862**	**.6808**	**.3804**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
MURGUD[045] BU 7153
Substation No/ Name :- 144019 / 33/11 KV SONAGE S/S
Feeder No / Name : 201 / 11 Kv Sonage Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0162		.5373		.6068	.6036
2		.0162		.5373	.6283	.5721	.6036
3		.0162		.5373		.5721	.6036
4		.0162		.5373		.5721	.6706
5		.0162		.7164		.6859	.7042
6		.0162		1.1641	1.1576	1.2656	.9054
7		.0162		1.2971	1.363	1.2656	1.2239
8	.0179	.0162		1.4198	1.475	1.5777	
9		.0162	.0164	1.4899	1.587	1.6124	
10			.0175		.0162	.0175	.7975
11	2.1622	2.0454	2.0858		.0162	.0175	.0162
12	2.4646	2.2466	2.4364		.0162	.0175	.0162
13	2.6699	2.3304	2.5065		.0162	.0175	.0162
14	2.8193	2.431	2.5065	.0164	.0162	.0175	
15	2.5953	2.4813	2.3838		.0162	.0175	
16		2.6155	1.9806		.0162	.0175	
17	2.3899	1.9784	1.8229		.0162	.0175	
18	1.9521	2.2405	1.7002		.0162		.0175
19	.0162		.0179		.0162		.0179
20	.0162		.0179		.0162		.0179
21	.0162		.0179		.0162		.0179
22	.0162		.0179		.0162		.0179
23	.0162			.0164	.0162		.0179
24	.0179	.0162	.0164	.5552	.6468	.6068	.57
Max	**2.8193**	**2.6155**	**2.5065**	**1.4899**	**1.587**	**1.6124**	**1.2239**
Min	**.0162**	**.0162**	**.0164**	**.0164**	**.0162**	**.0175**	**.0162**
Avg	**1.2264**	**1.0295**	**1.1696**	**.7354**	**.3542**	**.5265**	**.3799**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
MURGUD[045] BU 7153
Substation No/ Name :- 144019 / 33/11 KV SONAGE S/S
Feeder No / Name : 202 / 11 KV HAMIDWADA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9313	.5487				
2	.8954	.5548	.7468			
3	.8954	.5548				
4	.8954	.5895				
5	.8596	.6935				
6	.8596	.9015	1.0456			
7	1.1744	.9882	1.3443			
8	1.56	1.2656	1.6244			
9	1.3443	1.1963	1.643			
11				3.034	3.6283	3.7969
12				1.6817	3.7037	3.7795
13				1.7511	4.0314	3.9876
14				1.7164	4.119	
15				3.275	4.0314	
16				3.4637	4.0665	
17				3.7969	3.7723	
18				3.275		
24	.9412	.5548	.7947			
Max	**1.56**	**1.2656**	**1.643**	**3.7969**	**4.119**	**3.9876**
Min	**.8596**	**.5487**	**.7468**	**1.6817**	**3.6283**	**3.7795**
Avg	**1.0357**	**.7848**	**1.1998**	**2.7492**	**3.9075**	**3.8547**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
MURGUD[045] BU 7153
Substation No/ Name :- 144019 / 33/11 KV SONAGE S/S
Feeder No / Name : 203 / 11 KV ARJUNNAGAR VG GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.112		.112		.1307	.128
2	.112	.112	.1109	.112	.1109	.112	.128
3	.112			.112		.112	.1097
4	.1494	.1307		.1494		.112	.1097
5	.1867	.1848		.1867		.1494	
6	.2402	.2561	.2402	.2587	.2587	.2561	.2561
7	.3292	.2926	.2772	.3292	.3547	.3292	.2561
8	.3292	.2561	.2801	.2896	.3361	.2715	.2561
9	.2218	.2012	.2614	.2534	.2987	.2195	
10	.168	.1829	.2172	.1867	.2561	.1991	.2195
11	.1663	.1829	.1991		.1991	.181	.181
12	.1867	.1829	.2172		.197	.1991	.181
13	.0924	.1829	.1991		.2172	.181	
14	.1663	.1509	.181		.1629	.1629	
15	.2033	.1646	.181		.1629	.181	
16	.2054	.1677	.1991		.2195	.1629	
17	.2054	.2926	.181		.2743	.2534	
18	.2561	.3326	.3292		.3109		
19	.4024	.4668	.439	.4854	.4938		.4755
20	.439	.4668	.439	.4251	.4024		.4755
21	.3658		.3696		.3658		.4207
22	.2561	.2987	.2218	.3174	.2561		.2957
23	.1829				.1867		.1848
24	.112	.1097	.1294	.112	.1494	.1478	.1463
Max	**.439**	**.4668**	**.439**	**.4854**	**.4938**	**.3292**	**.4755**
Min	**.0924**	**.1097**	**.1109**	**.112**	**.1109**	**.112**	**.1097**
Avg	**.2167**	**.2251**	**.2459**	**.2378**	**.2607**	**.1867**	**.2390**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
MURGUD[045] BU 7153
Substation No/ Name :- 144019 / 33/11 KV SONAGE S/S
Feeder No / Name : 204 / 11 KV SURUPALI GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1307		.1494		.112	.1463
2	.1494	.1307	.1294	.1494	.1109	.112	.1463
3	.1494	.1307		.1494		.112	.128
4	.1867	.1478		.2241		.1307	.128
5	.2801	.2427		.2801		.1848	.1829
6	.4108	.3658	.3921	.3511	.4435	.3841	.3658
7	.5788	.5121	.5228	.4207	.5601	.567	.6036
8	.5041	.4938	.5359	.5068	.5228	.5304	.5487
9	.4854	.4854	.5041	.3982	.4854	.4938	
10	.4435	.439	.4706	.3547	.3841	.4163	.4024
11	.4294	.4938	.4163	.3547	.3658		.3982
12	.3881	.4024	.3439	.3881	.2715	.2896	.3258
13	.3547	.4024	.362	.3511	.2896	.3258	.3224
14	.3326	.3841	.3801	.3547	.2715	.2896	
15		.4024	.3258	.3174	.2561	.3801	
16	.4294	.3841	.362	.2987	.2743	.4163	
17	.4481	.3658	.3982	.3734	.2926	.5068	
18	.5121	.4435	.4207	.4481	.4755		.4344
19	.695	.7282	.6401	.6908	.6584		.6219
20	.6584	.6348	.6219	.6161	.6401		.5853
21	.5487		.5359		.567		.5304
22	.1829	.3511	.3326	.2801	.3841		.3511
23	.1829				.2033		.2033
24		.128	.1478	.1494	.1109	.1478	.1646
Max	**.695**	**.7282**	**.6401**	**.6908**	**.6584**	**.567**	**.6219**
Min	**.1494**	**.128**	**.1294**	**.1494**	**.1109**	**.112**	**.128**
Avg	**.3864**	**.3727**	**.4127**	**.3458**	**.3784**	**.3176**	**.3468**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
MURGUD[045] BU 7153
Substation No/ Name :- 144019 / 33/11 KV SONAGE S/S
Feeder No / Name : 205 / 11 KV Banage Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2534	.2427		.0724		.0648	
2	.2534	.2427	.2801	.0724		.0648	
3	.2534	.2427		.0724		.0648	
4	.2172	.2427		.0724		.0648	
5	.2172	.2572		.0895		.0648	
6	.2149	.3086	.4108	.0716	.0829	.0648	
7	.3582	.3641	.4668	.0716		.0648	
8	.5014	.5548	.5975	.0895	.0829	.0648	
9	.5914	.6241	.5975	.0895	.0819	.0648	
10			.0895	.0829	.081	.1075	.0648
11	.0819		.0895	1.2012	.9709	.9465	.9015
12			.3403	1.3306	1.1096	1.0517	.9362
13			.1075	1.3443	1.1096	1.0974	.9602
14	.0819		.1254	1.2567	1.0576	1.0402	
15			.1075	1.2136	.9709	.9709	
16			.0886	1.1203	.8669	.9671	
17	.0829			.8962	.7888	.8764	
18	.0648		.0895	.7468	.6935		.7011
19	.0648	.0829	.0895	.0655	.0648		.0895
20	.0648		.0716		.0648		.0895
21			.0895		.0648		.0895
22		.0663	.0716	.0663	.0648		.0716
23	.0648				.0648		.0716
24	.2534	.208	.3174	.0724	.0655	.0648	
Max	**.5914**	**.6241**	**.5975**	**1.3443**	**1.1096**	**1.0974**	**.9602**
Min	**.0648**	**.0663**	**.0716**	**.0655**	**.0648**	**.0648**	**.0648**
Avg	**.2129**	**.2864**	**.2239**	**.4809**	**.4603**	**.4281**	**.3976**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
MURGUD[045] BU 7153
Substation No/ Name :- 144019 / 33/11 KV SONAGE S/S
Feeder No / Name : 206 / CHIKHALI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0362	.0324		.724		.5895	.6036
2	.0362	.0324	.0332	.724	.6535	.5895	.6036
3	.0362	.0324		.724		.5895	.6036
4	.056	.0324		.7602		.5895	.6036
5	.056	.0324		.7964		.6241	.6371
6	.0747	.0324	.061	.8238	.7095	.6859	.6874
7	.0739	.0324	.0663	.985	.9149	.7545	.8718
8	.0366	.0324		1.1283	1.0456	.9945	.9389
9	.0492	.0324	.0663	1.1043	1.1576	1.0749	
10			.0537	.0497	.0486	.0358	.0324
11	1.4937	1.1904	1.4685		.0486	.0358	.0324
12	1.6804	1.5424	1.6476		.0324	.0537	.0324
13	1.7364	1.8107	1.6297		1.8299	.0716	
14	1.7924	1.8275	1.5223		.0324	.0716	
15	1.7924	1.7436	1.5043		.0324	.0716	
16		1.6766	1.5402		.0324	.0543	
17	1.8111	1.291	1.5043		.0324	.0716	
18	1.5257	1.4003	1.3112		.0324		.0716
19	.0324	.0492	.0537	.0492	.0324		.0543
20	.0324		.0543		.0648		.0543
21	.0324		.0543		.0324		.0543
22	.0324	.0497	.0543	.0332	.0324		.0362
23	.0324				.0324		.0362
24		.0324	.0332	.7602	.6722	.6068	.6036
Max	**1.8111**	**1.8275**	**1.6476**	**1.1283**	**1.8299**	**1.0749**	**.9389**
Min	**.0324**	**.0324**	**.0332**	**.0332**	**.0324**	**.0358**	**.0324**
Avg	**.5928**	**.6453**	**.7032**	**.6663**	**.3735**	**.4203**	**.3643**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
MURGUD[045] BU 7153
Substation No/ Name :- 144020 / 33/11 KV MUDHAL THITA
Feeder No / Name : 201 / 11 KV MURGUD Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.3814	.2915	.0876		.0686	.0701
2	.4115	.3814	.2915	.0876		.0686	.0701
3	.4115	.3814	.2915	.0876	.0514	.0686	.0701
4	.4115	.4401	.3086	.0876		.0686	.0701
5	.4458	.4401	.3601	.0905		.0686	.0701
6	.5144	.4988	.4115	.1052	.0514	.0686	.0701
7	.7716	.4801	.6516	.1052		.0686	.0526
8	.9602	.6687	.8402	.1052	.0514	.0857	.0701
9	.8573	.8059	.7888	.1029	.0701	.0857	
10	.0514	.0514	.1372	.0514	.0701	.0686	
11	.0686	.0526	.12	1.1488	1.3203	1.5089	1.1736
12	.0686	.0526	.12	1.5089	1.5775	1.6118	1.2631
13	.0686	.0526	.0343	1.6632		1.6804	1.2929
14	.0514	.0526	.0343	1.7364		1.6461	1.3203
15	.0686	.0526		1.5604	1.406	1.6118	1.5089
16	.0686	.0526	.12	1.5089	1.5089	1.6118	1.4746
17		.0701	.1227	1.4918	1.4575	1.4746	1.286
18	.0446	.0701	.1227	1.2689	1.1831	1.1488	.9774
19	.0587	.0701	.1227	.0514	.0686	.0701	
20	.0587	.0526	.1227		.0686	.0876	
21	.04	.0526	.0876		.0686	.0876	
22	.044	.0526	.0876		.0686	.0876	
23	.044	.0526		.0514	.0686	.0876	.0686
24	.4115	.3521	.2572	.0876	.0514	.0514	.0876
Max	**.9602**	**.8059**	**.8402**	**1.7364**	**1.5775**	**1.6804**	**1.5089**
Min	**.04**	**.0514**	**.0343**	**.0514**	**.0514**	**.0514**	**.0526**
Avg	**.2758**	**.2341**	**.2602**	**.6185**	**.5378**	**.5619**	**.6109**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
MURGUD[045] BU 7153
Substation No/ Name :- 144020 / 33/11 KV MUDHAL THITA
Feeder No / Name : 208 / 11 KV Murgud VG GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2957	.2743	.2896	.2534	.2587	.2401	.2715
2	.2957	.2743	.2715	.2534	.2587	.2401	.2534
3	.2957	.2401	.2715	.2353	.2587	.2058	.2534
4	.3326	.2401	.2715		.2587	.2572	.2534
5	.3696	.2743	.3439	.2715	.2957	.3086	.2896
6	.4805	.4458	.4557	.4344	.4435	.4287	.4908
7	.5914	.5487	.5258	.4706	.5914	.5487	.5784
8	.5914	.5487	.5609	.5249	.6219	.5658	.5784
9	.5144	.5258	.5973	.5144	.543	.6219	.5487
10	.5144	.5609	.543	.4801	.5609	.5853	.5487
11	.4973	.5083	.5792	.4801	.4908	.5121	.5487
12	.463	.5609	.5373	.4115	.4733	.5068	.4801
13	.4287	.4733	.4656	.463		.4656	.4748
14	.3944	.4557	.4298	.4115	.4557	.4344	.3429
15	.4458		.4557	.3944	.4908	.4207	.394
16	.4801		.4557	.4458	.5258	.4557	.3506
17		.5083	.6089	.5014	.583	.543	.5609
18	.6516	.6836	.6626	.543	.6859	.6878	.6878
19	.823	.8413	.8688	.8688	.823	.9231	.9511
20	.823	.7602	.7468	.7682	.7202	.724	.7682
21	.6344	.7059	.6516	.6653	.6344	.724	.695
22	.4801	.4706	.5249	.5544	.5144	.5258	.5175
23	.3429	.3258		.3658	.3429	.3258	.3292
24	.2957	.3086	.2896	.2534	.2587	.2572	.2715
Max	**.823**	**.8413**	**.8688**	**.8688**	**.823**	**.9231**	**.9511**
Min	**.2957**	**.2401**	**.2715**	**.2353**	**.2587**	**.2058**	**.2534**
Avg	**.4801**	**.4789**	**.4960**	**.4593**	**.4822**	**.4795**	**.4766**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
MURGUD[045] BU 7153
Substation No/ Name :- 144020 / 33/11 KV MUDHAL THITA
Feeder No / Name : 403 / 33 KV Sonali LIS **PURELY LIS FEEDERS**
Feeder KV- 33 / OUTGOING

DATE	23-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3				.1646
4				.3292
5				.3841
6	.12	.1029		.439
7	.12	.1029		.4938
8	.12	.1029		.4938
9		.1097	.1543	
10		.1646	.1543	
11		.1646	.1543	.4012
12			.1543	.3961
13		.2743	.1543	.3567
14		.2743	.1543	.3521
15			.1029	.4115
16		.2743	.1029	.4115
17			.0549	.3086
Max	**.12**	**.2743**	**.1543**	**.4938**
Min	**.12**	**.1029**	**.0549**	**.1646**
Avg	**.12**	**.1745**	**.1318**	**.3802**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
MURGUD[045] BU 7153
Substation No/ Name :- 144097 / 33/11KV KURANI
Feeder No / Name : 201 / Bhadgaon AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0572	.0509	.5316	.4409	.3898	.3429
2	.0762	.0572	.0509	.5493	.4239	.4075	.3258
3	.0762	.0572		.5493	.4239	.4075	.3429
4	.0953	.0572		.567	.4409	.443	.3772
5	.0953	.0572	.0509	.6201	.5087	.5083	.463
6	.0953	.0572	.0509	.7011	.6274	.6415	.6001
7	.0724	.0572	.0678	.9945	1.1869	1.1831	1.073
8	.0724	.0572	.0509	1.3375	1.5091	1.5592	1.2574
9	.0724	.0762	.0678	1.4232	1.5939	1.5927	1.2431
10	.0572	.0572	.0678	.056	.0509	.0686	.0762
11	1.7661	2.0233	2.0119	.0514	.0686	.0857	.0686
12	2.332		2.3266	.0514		.1029	.0686
13	2.4006	2.3148	2.4086	.1029	.0686	.1029	
14	2.6235	2.6578	2.3594	.0857	.1029	.1029	.0514
15	2.5377	2.6749	2.2447	.1029	.12	.1029	.0686
16	2.3663	2.5034	2.1216	.0857	.0857	.1029	.0686
17	2.0919	2.1434	1.9448	.1029	.0857	.1029	.0686
18	1.643	1.6787	1.5089	.1187	.0549		.0905
19	.0762	.0678	.0905	.1017	.056	.0953	.1086
20		.0509	.0914	.1017	.0554	.0953	.0914
21	.0762	.0509	.0914	.0678	.0554	.0953	.0914
22	.0572	.0509	.0914	.0678	.0554	.0762	.0739
23	.0572	.0509	.0739	.0509	.056	.0762	.0554
24	.0953	.0572	.0509	.6089	.4409	.4119	.3258
Max	**2.6235**	**2.6749**	**2.4086**	**1.4232**	**1.5939**	**1.5927**	**1.2574**
Min	**.0572**	**.0509**	**.0509**	**.0509**	**.0509**	**.0686**	**.0514**
Avg	**.8231**	**.7355**	**.8125**	**.3763**	**.3701**	**.3806**	**.3188**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
MURGUD[045] **BU 7153**
Substation No/ Name :- 144097 / 33/11KV KURANI
Feeder No / Name : 202 / Sonali AG **FEEDER SEPERATION/PURE AG**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2486	.2214	.3052	.0739	.0678	.0739	.0953
2	.2347	.208	.2374	.0739	.0678	.0739	.0953
3	.2347	.2105	.2035	.0739	.0678	.0739	.0762
4	.2515	.1943	.2035	.0739	.0678	.0739	.0762
5	.2515	.208	.2204	.0739	.0678	.0739	.0953
6	.2515	.2105	.2883	.0732	.0678	.0739	.0953
7	.3688	.421	.5087	.0732	.0678	.0732	.0953
8	.5243	.6718	.6104	.0732	.0678	.0739	.0857
9	.6718	.7125	.5765	.0739	.0678	.0739	.0857
10	.0762	.0762	.0509	.0747	.0678	.0686	.0953
11	.0686	.0686	.0724	1.0288	.7545	.6859	.6859
12	.0686	.0686	.0724	1.0631	.7202	.7716	.7373
13	.0686	.0857	.0732	1.1145	.6516	.7545	
14	.0686	.0857	.0732	.9945	.6173	.703	.7373
15	.0857	.0857	.0732	.9088	.5487	.6687	.823
16	.0686	.0686	.0732	.823	.5316	.583	1.0117
17	.0686	.0686	.0739	.7888	.5316	.5144	.9945
18	.0686	.0678	.0739	.5765	.3898	.3353	.8059
19	.0762	.0678	.0732	.0678	.0739	.0953	.0739
20		.0509		.0678	.0739	.0953	.0739
21	.0762	.0678	.0739	.0678	.0739	.0953	.0739
22	.0762	.0678	.0732	.0678	.0739	.0953	.0739
23	.0762	.0678	.0739	.0678	.0739	.0953	.0747
24	.2486	.2214	.3391	.0739	.0678	.0739	.0953
Max	**.6718**	**.7125**	**.6104**	**1.1145**	**.7545**	**.7716**	**1.0117**
Min	**.0686**	**.0509**	**.0509**	**.0678**	**.0678**	**.0686**	**.0739**
Avg	**.1840**	**.1782**	**.1923**	**.3520**	**.2442**	**.2625**	**.3112**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
MURGUD[045] BU 7153
Substation No/ Name :- 144097 / 33/11KV KURANI
Feeder No / Name : 203 / Sawarde VG GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.2427	.1696	.2241	.2204	.2427	.2054
2	.1867	.2241	.1526	.2241	.2035	.2427	.1867
3	.2054	.2054	.1696	.2054	.2204	.2241	.168
4	.2241	.2241	.1865	.2241	.2204	.2614	.2241
5	.2987	.2987	.2883	.3174	.3222	.3547	.2801
6	.5601	.5359	.4578	.5175	.5256	.5359	.5544
7	.6468	.6653	.5935	.5914	.6613	.6838	.6838
8	.6838	.6767	.6443	.6283	.5935	.6653	.6878
9	.6099	.6154	.6104	.5729	.5765	.6653	.6335
10	.6535	.5975	.5087	.4854	.5256		.5914
11	.4887	.4163	.5068	.4525	.4344		.4706
12	.4706	.4344	.5359	.3801	.3982		.3982
13	.3801	.4163	.4207	.3439	.3801	.4163	
14	.4163	.362	.4207	.3258	.362	.3982	.2896
15	.4344	.3982	.4755	.3439	.362	.362	.3258
16	.362	.3982	.4572	.3982	.3258	.3982	.3258
17	.4344	.3982	.5175	.3982	.4344	.3801	.3982
18	.5792	.5596	.6838	.4578	.7023	.5788	.5729
19	1.0269	.8648	1.0269	.78	1.0082	.9511	1.0164
20		.7011	.9522	.78	.9709	.9055	.961
21	.7947	.6783	.8589	.6952	.8215	.7655	.8589
22	.5415	.3561	.5601	.39	.6161	.462	.5601
23	.2987	.2204	.2987	.2543	.3206	.2801	.2987
24	.2054	.2614	.1696	.2241	.2204	.2801	.2241
Max	**1.0269**	**.8648**	**1.0269**	**.78**	**1.0082**	**.9511**	**1.0164**
Min	**.1867**	**.2054**	**.1526**	**.2054**	**.2035**	**.2241**	**.168**
Avg	**.4647**	**.4480**	**.4861**	**.4256**	**.4761**	**.4788**	**.4746**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
RADHANAGARI[046] BU 7145
Substation No/ Name :- 144024 / 33/11KV WALWA S/S
Feeder No / Name : 201 / 11KV WALWA VILLAGE GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614			.2801	.2561	.2686	.2801
2			.2801		.2534	.2658	.2801
3	.2772	.2715	.2987	.2987	.2561	.2896	.2614
4	.3361		.3361	.4108	.3292	.3475	.3734
5	.6535		.5175		.5853	.591	.6722
6	1.0456	1.0608	.9709	1.0456	1.2071	1.0136	1.0456
7	1.1763	1.134	1.0082	1.0829	1.2437	1.1568	
8		1.0242		1.0642	1.0608	1.0745	1.0082
9	.9335	.9328	1.0534	.9979	.9511	.8596	.9335
10	.7421	.8238	.8215			.8402	.7316
11	.6584	.631	.7095	.7865		.7207	.7023
12	.5853	.6661	.7468		.695	.6722	.7316
13		.6447		.6584	.5609	.5788	.567
14	.7316	.6733	.5975	.6584	.4908	.5601	.5853
15	.695	.6268	.7468	.6584	.443		.4755
16	.695	.6089	.7468	.6219	.5014	.7468	.4755
17	.695	.6379		.695	.567		.695
18	.8048	.6805	.8402	.695	.788	.8402	.823
19	1.1157	.8145	.8402	.9877	.8417	1.0456	1.0242
20	.9511	.8764	.9522		.9036	.8589	.8779
21	.7133	.6836	.8215		.6836	.7468	.7499
22	.567	.5658			.5493	.3361	.439
23	.3292	.3429			.333	.2772	.2378
24	.2614	.2743	.2774	.2801	.2561	.3189	
Max	**1.1763**	**1.134**	**1.0534**	**1.0829**	**1.2437**	**1.1568**	**1.0456**
Min	**.2614**	**.2715**	**.2774**	**.2801**	**.2534**	**.2658**	**.2378**
Avg	**.6775**	**.6987**	**.6981**	**.7014**	**.6253**	**.6550**	**.6350**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
RADHANAGARI[046] BU 7145
Substation No/ Name :- 144024 / 33/11KV WALWA S/S
Feeder No / Name : 205 / 11 Kv Gahininath Ag LIS **PURELY LIS FEEDERS**
Expres Feeder KV- 11 / OUTGOING

DATE	26-DEC-17	27-DEC-17
HR	Load (MW)	Load (MW)
3	.0724	
5	.1158	.0716
6	.1158	.0724
7		.0886
8	.0724	.0895
9	.0724	.0914
12	.0905	
13	.1578	
14	.1578	
15	.1052	
16	.1052	
17	.1086	
18	.0895	
Max	**.1578**	**.0914**
Min	**.0724**	**.0716**
Avg	**.1053**	**.0827**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
RADHANAGARI[046] BU 7145
Substation No/ Name :- 144025 / 33/11 KV DHAMOD
Feeder No / Name : 201 / 11 KV DHAMOD AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0175		.0191	.5373		.4031	
2	.0177		.0191	.5373		.3898	
3	.0177	.0191	.0191	.5373		.4784	.5548
4	.0177		.0191	.5373	.4908	.4908	
5	.0177		.0191	.5731		.5434	
6	.0175		.0191			.631	.6935
7	.0177	.0191	.0191	.6984	.7537	.7186	.7282
8	.0175		.0191	.7701	.7888		.7455
9	.0175	.0191	.0191	.788	.7712		.6241
10	.0175	.0191	.0191	.0175	.0177		.0191
11	1.0402	1.1104	1.1641	.0173	.0177	.0191	.0175
12		1.182	1.2536	.0175			.0175
13	1.1269	1.1999	1.2357			.0191	.0175
14	1.0576	1.1999	1.1641	.0175			.0175
15		1.1641	1.182	.0177			.0175
16	1.0923	1.1104	1.182	.0177		.0191	.0175
17		1.0387	1.0745	.0177	.0175		.0177
18	.8322	.8775	.9313	.0177	.0175	.0191	.0177
19		.0191	.0191	.0179	.0177		.0177
20	.0191	.0191	.0191	.0179	.0177	.0191	.0181
21		.0191	.0191	.0179	.0177		.0177
22	.0191	.0191	.0191	.0179	.0177	.0191	.0177
23		.0191	.0191	.0179	.0177		.0179
24	.0175	.0191	.0191	.591	.4252	.4031	.4334
Max	**1.1269**	**1.1999**	**1.2536**	**.788**	**.7888**	**.7186**	**.7455**
Min	**.0175**	**.0191**	**.0191**	**.0173**	**.0175**	**.0191**	**.0175**
Avg	**.2989**	**.5041**	**.3955**	**.2636**	**.2420**	**.2981**	**.2014**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
RADHANAGARI[046] BU 7145
Substation No/ Name :- 144025 / 33/11 KV DHAMOD
Feeder No / Name : 202 / 11 KV KELOSHI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5201		.5373	.0191		.0175	
2	.5375		.5373	.0191		.0175	
3	.5434	.6588	.5373	.0191		.0177	.0191
4	.5895		.5373	.0191	.0177	.0175	
5	.6661		.5731	.0191		.0177	
6	.7108		.6089	.0191		.0177	
7	.8669	.8669	.6626	.0191	.0177	.0175	.0191
8	.964		.8238	.0191	.0177		.0191
9	1.1616	1.0923	.8059	.0191	.0177		.0191
10	.0173	.0191	.0191		.0177	.0191	.0191
11	.0191	.0191	.0191	1.3003	1.543	1.6817	1.3321
12		.0191	.0191	1.5604			1.5777
13	.0191	.0191	.0191		1.7528	1.9591	1.6124
14	.0191	.0191	.0191	1.5257	1.8204		1.5604
15		.0191	.0191	1.5604	1.7684		
16	.0191	.0191	.0191	1.6126	1.543	1.595	1.6644
17		.0191	.0191	1.5249	1.387		1.5083
18	.0191	.0191	.0191	1.3672	1.2094	1.0923	1.3146
19		.0191	.0191	.0179	.0177		.0177
20	.0191	.0191	.0191	.0179	.0175	.0191	.0177
21		.0191	.0191	.0179	.0177		.0177
22	.0191	.0191	.0191	.0179	.0175	.0191	.0177
23		.0191	.0191	.0179	.0177		.0177
24	.5201	.5548	.5731	.0191	.0177	.0177	.0191
Max	**1.1616**	**1.0923**	**.8238**	**1.6126**	**1.8204**	**1.9591**	**1.6644**
Min	**.0173**	**.0191**	**.0191**	**.0179**	**.0175**	**.0175**	**.0177**
Avg	**.4017**	**.1911**	**.2693**	**.4878**	**.6232**	**.4351**	**.5985**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
RADHANAGARI[046] BU 7145
Substation No/ Name :- 144025 / 33/11 KV DHAMOD
Feeder No / Name : 203 / 11KV DHAMOD-KELOSHI VILLAGE Feeder KV- 11 / OUTGOING **GAOTHAN FEEDER**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0709		.0716	.0716		.0886	
2	.0709		.0716	.0716		.0876	
3	.0701	.0693	.0716	.0716		.0886	.0867
4	.0886		.1075	.1075	.104	.1063	
5	.1417		.1791	.1791		.1595	
6	.1928		.2328	.2328		.2103	
7	.298	.3121	.3045	.3403	.3294	.298	.2774
8	.3155		.3224	.3224	.3467		.2774
9	.298	.2601	.3224	.3224	.2947		.2947
10	.2629	.2328	.2865	.2427	.2454	.208	.2601
11	.208	.1791	.2507	.2401	.1772	.1734	
12		.1791	.2149	.1715	.1578		.1734
13	.1214	.1791	.2149		.1402	.1734	.1214
14	.1214	.1791	.2149	.1907	.1227		.1715
15		.1791	.1612	.1734	.0876		.12
16	.1734	.197	.197	.1753	.1578	.1214	.1715
17		.2507	.2149	.156	.1753		.1886
18	.3121	.2865	.2865	.2947	.2629		.2743
19		.4119	.4119	.3988	.3856		.3814
20	.3641	.3403	.3761	.3506	.3189	.3681	.0173
21		.2686	.2865	.2835	.298		.2629
22	.1734	.197	.1791	.1928	.1595	.1734	.1417
23		.1254	.1433	.1227	.0886		.0867
24	.0709	.0693	.0895	.0895	.1227		.0867
Max	**.3641**	**.4119**	**.4119**	**.3988**	**.3856**	**.3681**	**.3814**
Min	**.0701**	**.0693**	**.0716**	**.0716**	**.0876**	**.0876**	**.0173**
Avg	**.1863**	**.2176**	**.2171**	**.2088**	**.2092**	**.1736**	**.1885**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
RADHANAGARI[046] BU 7145
Substation No/ Name :- 144025 / 33/11 KV DHAMOD
Feeder No / Name : 204 / 11 KV BURAMBALI AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.6447		.4733	
2				.6447		.4733	
3				.6447		.5258	.5548
4				.6805	.6135	.5434	
5				.7522		.5784	
6				.8417		.6135	
7				.9134	.7888	.7362	.7282
8				.9671	.7537		.7628
9				1.0029	.7186		.7455
11	.9362	1.2894	1.3432				
12		1.379	1.3969				
13	1.1789	1.4506	1.2894				
14	1.2483	1.4506	1.3611				
15		1.4148	1.3969				
16	1.4737	1.3969	1.3969				
17		1.2715	1.2536				
18	1.1705	1.2536	1.1641				
24				.6805	.4784	.4557	.4681
Max	**1.4737**	**1.4506**	**1.3969**	**1.0029**	**.7888**	**.7362**	**.7628**
Min	**.9362**	**1.2536**	**1.1641**	**.6447**	**.4784**	**.4557**	**.4681**
Avg	**1.2015**	**1.3633**	**1.3253**	**.7772**	**.6706**	**.5500**	**.6519**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
RADHANAGARI[046] BU 7145
Substation No/ Name :- 144026 / 33/11 KV TARALE SUB STSTION
Feeder No / Name : 201 / 11KV TARALE AG (TARLE) FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8192	.8383	.7865				
2	.8288	.9835	.7956				
3	.8951	.9945	.7956				
4	.9054	.9945	.8288				
5	1.0059	1.073	.8951				
6	1.073	1.1191	1.0059				
7	1.4754	1.3226	1.073				
8	1.6244	1.5089	1.4754				
9	1.643	1.4922	1.5089				
11				1.0608	1.9784	2.1125	2.0553
12				2.0119	2.2466	2.2283	
13				2.3472	2.4863	2.2283	2.1795
14				2.364	2.42	2.4143	2.3205
15				2.3472	2.2801	2.3472	2.2211
16				2.146	2.1879	2.1795	2.0972
17				1.8107	2.0553	1.9227	1.704
18				1.6598	1.7238	1.7238	1.4918
24	.8192	.7956	.6882				
Max	**1.643**	**1.5089**	**1.5089**	**2.364**	**2.4863**	**2.4143**	**2.3205**
Min	**.8192**	**.7956**	**.6882**	**1.0608**	**1.7238**	**1.7238**	**1.4918**
Avg	**1.1089**	**1.1122**	**.9853**	**1.9685**	**2.1723**	**2.1446**	**2.0099**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
RADHANAGARI[046] BU 7145
Substation No/ Name :- 144026 / 33/11 KV TARALE SUB STSTION
Feeder No / Name : 202 / 11 KV TARALE GAOTHAN FEEDER VILLAGE(TARLE) Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1417	.1448	.1402		.1612	.1629	.1402
2	.1417	.1478	.1402	.1417	.1433	.1646	.1402
3	.1417	.1478	.1402	.1433	.1433	.1463	.1402
4	.181	.1646	.1791	.1612	.1629	.1791	.1402
5	.2772	.2534	.2896	.2534	.2353	.2587	.2303
6	.415	.3658	.4066	.4024	.362	.4294	.3881
7	.4481	.5041	.5041	.499	.4887	.4938	.4854
8	.4854	.439	.4481	.4435	.4938	.4805	.4481
9	.4108	.3511	.3696	.4066	.4024	.3361	.3326
10	.2957	.2715	.3142	.3511	.2926	.2801	.2957
11	.2378	.2534	.3109	.3109	.2378	.2587	.2481
12	.2254	.2534	.3109	.3077	.2743	.2561	.2601
13	.2427	.2896	.3109	.2896	.2149	.2743	.2601
14	.2658	.2896	.2378	.2926	.1829	.2279	.2035
15	.2804	.2658	.2378	.2715	.2427	.2279	.1696
16	.2427	.3045	.2534	.2715	.2454	.2481	.2401
17	.2686	.3658	.3077	.2715	.2926	.2715	.2601
18	.3841	.4066	.3841	.3258	.4207	.3696	.3224
19	.5544	.5304	.5175	.4887	.5121	.499	.5359
20	.5121	.4755	.499	.4344	.4755	.4668	.4938
21	.3658	.4066	.4344	.4024	.4294	.3734	.4251
22	.2715	.2926	.3439	.2926	.3142	.2561	.3045
23	.2195	.1753	.197	.1991	.2195	.1928	.2328
24	.1595	.1646	.1578	.1595	.1791	.1791	.1578
Max	**.5544**	**.5304**	**.5175**	**.499**	**.5121**	**.499**	**.5359**
Min	**.1417**	**.1448**	**.1402**	**.1417**	**.1433**	**.1463**	**.1402**
Avg	**.2987**	**.3027**	**.3098**	**.3096**	**.2969**	**.2930**	**.2856**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
RADHANAGARI[046] BU 7145
Substation No/ Name :- 144027 / 33/11 KV Aawali
Feeder No / Name : 201 / 11 KV SHIRGAON AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.176	.1844	.1017				
2	.176	.1844	.1017				
3	.1781	.1844	.0848				
4	.192	.1844	.0838				
5	.2105	.1844	.1174				
6	.2267	.2347	.2012				
7	.2401	.2683	.2012				
8	.2591	.3185	.2012				
9	.2561	.3018	.2012				
11				.4748	.4268	.4917	.3725
12					.4049	.5087	.421
13					.4744	.503	.4372
14				.3978	.4744	.4807	.3361
15					.4531	.4191	.3841
16				.4694	.4218	.4475	.3841
17				.4706	.3858	.431	.3605
18				.4144	.3048	.3688	.2915
24	.1739	.1844	.1017				
Max	**.2591**	**.3185**	**.2012**	**.4748**	**.4744**	**.5087**	**.4372**
Min	**.1739**	**.1844**	**.0838**	**.3978**	**.3048**	**.3688**	**.2915**
Avg	**.2089**	**.2230**	**.1396**	**.4454**	**.4183**	**.4563**	**.3734**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
RADHANAGARI[046] BU 7145
Substation No/ Name :- 144027 / 33/11 KV Aawali
Feeder No / Name : 202 / 11 KV PARITE AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.253	.213	.213				
2	.2622	.213	.213				
3	.2622	.213	.213				
4	.2622	.2294	.0655				
5	.3113		.0655				
6	.3563		.0819				
7	.4372		.0983				
8	.4915		.0983				
9	.5079		.1475				
10		.4481					
11		.3361		.9326	.7011	.779	.7537
12		.3201			.8124	.9339	.852
13		.4001			.8905	.8848	.8619
14		.3841		1.0608	.7926	.8259	.8259
15					.8124	.7373	.8619
16				.9282	.7499	.8356	.7865
17				.8453	.7011	.7209	.6882
18				.8122	.6562	.5571	.5735
24	.25	.2294	.2056				
Max	**.5079**	**.4481**	**.213**	**1.0608**	**.8905**	**.9339**	**.8619**
Min	**.25**	**.213**	**.0655**	**.8122**	**.6562**	**.5571**	**.5735**
Avg	**.3394**	**.2986**	**.1402**	**.9158**	**.7645**	**.7843**	**.7755**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
RADHANAGARI[046] BU 7145
Substation No/ Name :- 144027 / 33/11 KV Aawali
Feeder No / Name : 203 / 11 KV AWALI-RADHANAGARI AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.253	.218	.4752				
2	.2591	.218	.4752				
3	.2591	.2347	.4588				
4	.1966	.2515	.153				
5	.213	.3856	.3963				
6	.3113	.4359	.4527				
7	.4588	.5365	.6203				
8	.4807	.788	.7377				
9	.4475	.788	.6706				
11				1.1022	.9217	1.0395	
12					.9488	1.1065	1.1105
13					.9488	1.0402	1.1768
14				1.0774	.945	1.0202	.9555
15					.8383	.9555	1.1437
16				1.0277	.8539	.9995	1.0486
17				1.0111	.7716	.8745	1.0159
18				.6299	.6405	.2785	.6882
24	.208	.218	.427				
Max	**.4807**	**.788**	**.7377**	**1.1022**	**.9488**	**1.1065**	**1.1768**
Min	**.1966**	**.218**	**.153**	**.6299**	**.6405**	**.2785**	**.6882**
Avg	**.3087**	**.4074**	**.4867**	**.9697**	**.8586**	**.9143**	**1.0199**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
RADHANAGARI[046] BU 7145
Substation No/ Name :- 144027 / 33/11 KV Aawali
Feeder No / Name : 205 / 11 KV Awali Vg GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1254	.1867	.1848	.2033	.1886	.181	.2054
2	.124	.168	.1848	.2012	.1886	.181	.1867
3	.1417	.168	.1848	.1991	.1698	.1646	.1867
4	.1791	.2241	.2241	.1829	.2263	.1991	.2614
5	.3403	.3361	.3174	.2926	.3961	.3921	.3734
6	.5014	.5228	.7468	.5729	.7545	.5914	.7468
7	.6697	.7468	.7842	.6908	.7733	.7392	.8029
8	.6099	.6535	.7023	.6653		.6722	.7095
9	.4805	.4481	.5544	.5729	.5544	.5228	.6161
10	.4207	.3734	.4854	.4755	.4207	.4066	.439
11	.3982	.3582	.4525	.3658	.3155	.3881	.3045
12	.3658	.3582	.394		.4344	.3881	.2507
13	.3326	.3403	.4334		.4572	.3658	.2715
14	.3109	.2881	.443	.4207	.4344	.362	.3366
15	.3658	.3761			.4207	.362	.3189
16	.4435	.439	.5014	.5175	.5014	.3841	.4784
17	.4481	.5121	.6836	.4024	.6135	.543	.5194
18	.5914	.6268	.7059	.5487	.6447	.695	.5973
19	.9709	.9055	.9328	.9149	.8688	.8501	.8048
20	.8131	.8316	.8131		.8048	.7842	.7392
21		.7095	.7282	.6602	.6584	.6535	.6468
22		.4294	.462	.3584	.3881	.3734	.4066
23		.2427	.2658		.2957	.2957	.2534
24	.1448	.2241	.2054	.2149	.1886	.2172	.2241
Max	**.9709**	**.9055**	**.9328**	**.9149**	**.8688**	**.8501**	**.8048**
Min	**.124**	**.168**	**.1848**	**.1829**	**.1698**	**.1646**	**.1867**
Avg	**.4180**	**.4362**	**.4952**	**.4453**	**.4652**	**.4463**	**.4450**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
RADHANAGARI[046] BU 7145
Substation No/ Name :- 144027 / 33/11 KV Aawali
Feeder No / Name : 206 / 11KV Kanthewadi Ag. FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0995	.0541				
2	.1006	.0995	.0549				
3	.0937	.0995	.0549				
4	.0949	.0995	.0695				
5	.096	.0995	.0834				
6	.0972	.1326	.1311				
7	.1296	.2321	.2321				
8	.1357	.3315	.2155				
9	.1357	.2652	.2652				
11				.5256	.4877	.5487	.4578
12					.5624	.5967	.5935
13					.6081	.5243	.6464
14				.5967	.5624	.5967	.639
15					.5182	.6226	.6539
16				.6299	.4999	.5898	.6203
17				.6283	.4012	.547	.57
18				.4973	.3125	.4973	.3856
24	.1492	.0995	.0671				
Max	**.1492**	**.3315**	**.2652**	**.6299**	**.6081**	**.6226**	**.6539**
Min	**.0914**	**.0995**	**.0541**	**.4973**	**.3125**	**.4973**	**.3856**
Avg	**.1124**	**.1558**	**.1228**	**.5756**	**.4941**	**.5654**	**.5708**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
RADHANAGARI[046] BU 7145
Substation No/ Name :- 144027 / 33/11 KV Aawali
Feeder No / Name : 207 / 11 KV Shirgaon VG GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.128	.1629	.168	.1663	.1698	.168	.1867
2	.1254	.1494	.168	.1494	.1698	.1448	.168
3	.1463	.1494	.168	.1494	.1698	.1478	.168
4	.2012	.2054	.1663	.2033	.1698	.1663	.2241
5	.3109	.2987	.2801	.2587	.3395	.3292	.2801
6	.5304	.5601	.5601	.5415	.6036	.5175	.5601
7	.6036	.6161	.6161	.6023	.6224	.6161	.5975
8	.5601	.5601	.5228	.5975		.5068	.5601
9	.4481	.462	.4854	.499	.4251	.3881	.4481
10	.3511	.3511	.3921	.3658	.3841	.3077	.3658
11	.2561	.2865	.2378	.2561	.3155	.2957	.3077
12	.2172	.2686	.3258		.3077	.2957	.2896
13	.2218	.2686	.3155		.2534	.2195	.2926
14	.2033	.2507	.2507	.1829	.2353	.2172	.2507
15	.2561	.2328	.2353		.2534	.2353	.2686
16	.3475		.2534	.2402	.2865	.2743	.3045
17	.4108	.3841	.3544	.3326	.3224	.3982	
18	.4481	.4119	.4572	.3658	.4525	.4207	.4525
19	.5729	.6099	.6283	.5415	.5975	.6099	.6653
20	.5729	.5544	.5415		.543	.5788	.5975
21	.4706	.4854	.5041	.415	.4525	.5041	.5228
22	.3109	.3174	.3734	.2452	.362	.3547	.3547
23	.2402	.1867	.2149		.2218	.2801	.2149
24	.1463	.1991	.168	.1829	.1886	.1848	.2054
Max	**.6036**	**.6161**	**.6283**	**.6023**	**.6224**	**.6161**	**.6653**
Min	**.1254**	**.1494**	**.1663**	**.1494**	**.1698**	**.1448**	**.168**
Avg	**.3367**	**.3466**	**.3495**	**.3313**	**.3411**	**.3401**	**.3602**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
RADHANAGARI[046] BU 7145
Substation No/ Name :- 144066 / 33/11 KV SOLANKUR S/S
Feeder No / Name : 201 / 11 KV SOLANKUR AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4938	.4298	.3258				
2	.5304	.4298	.3429				
3	.5359		.3601				
4	.5487	.4298	.3601				
5	.5729	.4477	.4115				
6	.6401	.6379	.463				
7	1.0059	.8048	.7888				
8	1.2071	1.0425	.9774				
9	1.3535	.8048	.9088				
11				1.4449	1.4575	1.2346	1.6095
12				1.5912	1.6975	1.6975	1.8839
13				1.8839	1.6804	1.7147	2.0119
14				1.9387	1.6289	1.7318	2.0485
15				1.9204	1.5089	1.6975	1.9728
16				1.9753	1.4746	1.5261	1.8656
17				1.7375	1.3032	1.1831	1.6644
18				1.2986	1.0117	.8916	1.1888
24	.4938	.3856	.3258				
Max	**1.3535**	**1.0425**	**.9774**	**1.9753**	**1.6975**	**1.7318**	**2.0485**
Min	**.4938**	**.3856**	**.3258**	**1.2986**	**1.0117**	**.8916**	**1.1888**
Avg	**.7382**	**.6014**	**.5264**	**1.7238**	**1.4703**	**1.4596**	**1.7807**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
RADHANAGARI[046] BU 7145
Substation No/ Name :- 144066 / 33/11 KV SOLANKUR S/S
Feeder No / Name : 202 / 11KV KALAMMAWADI AG(SOLANKUR) Feeder KV- 11 / OUTGOING **FEEDER SEPERATION/PURE AG**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2058	.2241	.0686	.1075
2				.2058	.2172	.0686	.1075
3				.2058	.2172	.0686	.1075
4				.2058	.2172	.0686	.1075
5				.2058	.2172	.0686	.1433
6				.2058	.2149	.1029	.1629
7				.3772	.2715	.2058	.2353
8				.4115	.3841	.3086	.362
9				.4115	.3439	.3086	.2686
11	.362	.5487	.5144				
12	.5014	.567	.5487				
13	.5014	.5853	.6001				
14	.5373	.6401	.6001				
15	.5731	.6219	.5487				
16	.4801	.5487	.583				
17	.463	.5121	.5144				
18	.4115	.4755	.4115				
24				.2058	.2172	.0686	.1029
Max	**.5731**	**.6401**	**.6001**	**.4115**	**.3841**	**.3086**	**.362**
Min	**.362**	**.4755**	**.4115**	**.2058**	**.2149**	**.0686**	**.1029**
Avg	**.4787**	**.5624**	**.5401**	**.2641**	**.2525**	**.1338**	**.1705**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
RADHANAGARI[046] BU 7145
Substation No/ Name :- 144066 / 33/11 KV SOLANKUR S/S
Feeder No / Name : 203 / 11KV SOLANKUR VILLEGE FEEDER Feeder KV- 11 / OUTGOING GAOTHAN FEEDER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2587	.2058	.2058	.2353	.2058	
2	.2561	.2614	.2058	.2058	.2195	.2058	.2054
3	.2587	.2614	.2401	.2058	.2241	.2058	
4	.2743		.2401	.2743	.2172	.2058	.2427
5	.4024	.4435	.4115	.3772	.3582	.3772	.4294
6	.6401	.7468	.6516	.6173	.6516	.6859	.7095
7	.9145	.8589	.7888	.7888	.8869	.823	.8962
8	.8413	.8779	.7545	.823	.823	.7888	.8871
9	.6219	.6219	.6516	.7545	.724	.6516	.7095
10	.6348	.6219	.6516	.695	.583	.6283	.6401
11	.6348	.6584	.6001	.6584	.5144	.6722	.567
12	.5041	.5853	.4801	.5487	.4458		.5487
13	.4854	.4755	.4458	.439	.4458	.5729	.4887
14	.4805	.5121	.4115	.4163	.5487	.5175	.4887
15	.4481	.4938	.4287	.4938	.4801	.5415	.4755
16	.5228	.5973	.5144	.5487	.4801	.5975	.5973
17	.6535	.6767	.6001	.5487	.6173	.6283	.6036
18	.8589	.8048	.7545	.7362	.7545	.8131	.7682
19	1.1827	1.0288	1.0288	1.0903	1.0288	1.1203	1.0974
20	1.0829	.9259	.9602	1.0349	.9259	1.0456	.9877
21	.8871	.7545	.7888	.8501	.7888	.8962	.8871
22		.5487	.5144	.4938	.5144		.5544
23		.2743	.3086	.3658	.2743	.2218	.3109
24	.2743	.2587	.2058	.2401	.2402	.2058	.2241
Max	**1.1827**	**1.0288**	**1.0288**	**1.0903**	**1.0288**	**1.1203**	**1.0974**
Min	**.2561**	**.2587**	**.2058**	**.2058**	**.2172**	**.2058**	**.2054**
Avg	**.5970**	**.5890**	**.5351**	**.5588**	**.5409**	**.5732**	**.6054**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
RADHANAGARI[046] BU 7145
Substation No/ Name :- 144066 / 33/11 KV SOLANKUR S/S
Feeder No / Name : 204 / 11KV AAINI VILLAGE GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.1307	.1029	.1372	.1494	.1029	
2	.1097		.1029	.1372	.1267	.1029	.1307
3	.1097	.112	.1029	.1372	.1227	.1029	
4	.128	.1307	.1029	.1372	.1463	.1029	.112
5	.1463	.168	.1029	.1715	.1629	.1372	.1307
6	.2033	.1867	.1715	.2058	.2172	.2058	.1494
7	.2561	.2427	.2058	.2743	.2926	.2401	.2427
8	.2402	.2195	.2058	.2743	.362	.3086	.2241
9	.2561	.2195	.2058	.2743	.2587	.2743	.2614
10	.1867	.2378	.1543		.2401	.3326	.2172
11	.168	.1646	.1886	.2012	.2058	.2427	.2378
12	.1307	.1463	.1886	.1097	.1715		.2378
13	.1478	.1629	.1715	.0724	.1715	.2241	.1646
14	.1494	.1646	.1715	.128	.1029	.1867	.1109
15	.2033	.1463	.1715	.0724	.1715	.2427	.2353
16	.1372	.1463	.1886	.1097	.2058	.1494	.2715
17	.1867	.2195	.2058	.128	.2058	.2218	.2896
18	.2241	.2172	.2743	.2743	.2743	.2987	.3292
19	.3086	.3086	.3086	.4251	.3429	.4066	.3326
20	.2915	.3086	.3258	.3658	.3086	.3174	.2896
21	.2801	.2401	.2743	.3292	.2743	.2587	.2772
22		.1715	.2058	.2218	.1715	.2427	.2012
23		.1372	.1372	.1646	.1715	.1867	.128
24	.1097	.1478	.1029	.1372	.1448	.1372	.1307
Max	**.3086**	**.3086**	**.3258**	**.4251**	**.362**	**.4066**	**.3326**
Min	**.1097**	**.112**	**.1029**	**.0724**	**.1029**	**.1029**	**.1109**
Avg	**.1856**	**.1882**	**.1822**	**.1951**	**.2084**	**.2185**	**.2138**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
RADHANAGARI[046] BU 7145
Substation No/ Name :- 144091 / 33/11 KV RADHANAGARI
Feeder No / Name : 201 / 11 KV KALAMMAVADI VG GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.1848	.1478	.1478	.1294	.1478	.1663
2	.1478	.1663	.1478	.1478	.1294	.1478	.1663
3	.1478	.1663	.1478	.1478	.1294	.1478	.1663
4	.1478	.1663	.1478	.1478	.1478	.1478	.1663
5	.1663	.2033	.1663		.1663	.1848	.1848
6	.2772	.3142	.3142	.2218	.2587	.2587	.2772
7	.4066	.3881	.3696	.2772	.3696	.3696	.3881
8	.3881	.3881	.3696	.3696	.3881	.3696	.3881
9	.3326	.3142	.3511	.2587	.3696	.3696	.3326
10	.3696	.2772	.3326	.2587	.3142	.3511	.3511
11	.2957	.2957	.3326	.2402	.3511	.3326	.2957
12	.3142	.2957	.3511	.2218	.2772	.2772	.3142
13	.3142	.2772	.3696	.2033	.2957	.2587	.2957
14	.3142	.2402	.2772	.1848	.2772	.3142	.2772
15	.2772	.2587	.2957	.2033	.3142	.3142	.2772
16	.3142	.2587	.3142	.1848	.3142	.2957	.2772
17	.3142	.3142	.3511	.2402	.3696	.3326	.3326
18	.4066	.3511	.4066	.3326	.4435	.3696	.3511
19	.5359	.5175	.5359	.499	.5729	.5544	.5359
20	.4805	.4435	.4805	.462	.5359	.499	.499
21	.4066	.3696	.4435	.4066	.4435	.4251	.4435
22	.3511	.2772	.3142	.2772	.3511	.3511	.2957
23	.2218	.1848	.1848	.1848	.2218	.2587	.2218
24	.1478	.1848	.1663	.1663	.1478	.1663	.1663
Max	**.5359**	**.5175**	**.5359**	**.499**	**.5729**	**.5544**	**.5359**
Min	**.1478**	**.1663**	**.1478**	**.1478**	**.1294**	**.1478**	**.1663**
Avg	**.3011**	**.2849**	**.3049**	**.2515**	**.3049**	**.3018**	**.2988**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
RADHANAGARI[046] BU 7145
Substation No/ Name :- 144091 / 33/11 KV RADHANAGARI
Feeder No / Name : 202 / 11 KV Kudutri Village GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0554	.0373	.0373	.0373	.0373	.056	.0373
2	.0554	.0373	.0373	.0373	.0373	.0373	.0373
3	.0554	.0373	.0373	.0373	.0373	.0373	.0373
4	.0554	.0373	.0373		.056	.0373	.0373
5	.0739	.056	.056	.056	.0747	.056	.056
6	.1294	.1494	.1494	.1307	.1307	.1307	.1494
7	.1848	.2054	.2054	.168	.1867	.1494	.1867
8	.1663	.168	.168	.1307	.168	.1494	.168
9	.168	.1663	.1867	.168	.1848	.1494	.1867
10	.1494	.1663	.2054	.168	.1663	.1307	.168
11	.2241	.1663	.1494	.1307	.1848	.1307	.1307
12	.1307	.1109	.1494	.0934	.1109	.112	.1494
13	.3174	.0924	.112	.0747	.1109	.0373	.0747
14	.0934	.0924	.112	.0747	.0924	.0934	.0747
15	.112	.1109	.0934	.0747	.1109	.112	.1109
16	.0934	.1478	.112	.0747	.112	.1494	.0924
17	.112	.1307	.1307	.0934	.1494	.1867	.1663
18	.168	.1867	.1494	.1307	.1494	.2054	.2218
19	.2241	.2614	.2614	.2427	.2427	.2987	.2772
20	.2054	.2614	.2241	.2054	.2241	.2801	.2402
21	.168	.1867	.1867	.1867	.2054	.2241	.3326
22	.0934	.112	.112	.112	.1307	.112	.0924
23	.0373	.0747	.0373	.056	.0934	.056	.0554
24	.0554	.0373	.056	.0373	.0373	.056	.056
Max	**.3174**	**.2614**	**.2614**	**.2427**	**.2427**	**.2987**	**.3326**
Min	**.0373**	**.0373**	**.0373**	**.0373**	**.0373**	**.0373**	**.0373**
Avg	**.1303**	**.1263**	**.1252**	**.1096**	**.1264**	**.1245**	**.1308**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
RADHANAGARI[046] BU 7145
Substation No/ Name :- 144091 / 33/11 KV RADHANAGARI
Feeder No / Name : 203 / Fejiwade Ag FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2155			.1341	.2543	.2818
2	.2155			.2012	.2543	.2984
3	.2155				.2543	.2984
4	.2155					.2984
5	.2321					.2984
6	.2401					.2984
7	.2572				.2713	.4641
8	.2957			.503	.3561	.4641
9	.4239			.5596	.39	.4475
10				.5426		
11	.6274	.6443	.6443	.5256		
12	.6952	.7291	.7122	.5256		
13	.6613	.7122	.7122	.4917		
14	.6274	.7291	.6613			
15	.6613	.7291	.5935			
16	.7122	.7461	.6274			
17	.4115	.7122	.5256			
18	.5316	.5765	.5935			
24	.2155			.2347	.1372	.2652
Max	**.7122**	**.7461**	**.7122**	**.5596**	**.39**	**.4641**
Min	**.2155**	**.5765**	**.5256**	**.1341**	**.1372**	**.2652**
Avg	**.4141**	**.6973**	**.6338**	**.4131**	**.2739**	**.3415**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR RURAL II DIV.[505]
RADHANAGARI[046] BU 7145
Substation No/ Name :- 144091 / 33/11 KV RADHANAGARI
Feeder No / Name : 204 / 11 KV Piral Ag. SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2321	.1326	.2035			
2	.2321	.1326	.2204			
3	.2486	.1326	.2204			
4	.2486	.1326	.2374			
5	.2818	.1658	.2543			
6	.4641	.2155	.2683			
7	.5801	.4973	.3647			
8	.7293	.7293	.6299			
9	.6962	.663	.7956			
11			1.2266	1.4089	1.442	1.3923
12			1.3757	1.6078	1.6741	1.5912
13			1.442	.4641	1.9418	.9945
14			1.3923	1.3592	1.7238	1.5912
15			1.3426	1.757	1.7072	1.6244
16			1.21	1.757	1.6244	
17			1.1768	1.5746	1.4582	1.2929
18			.9614	1.2597	1.1869	1.0111
24	.2321	.1658	.2012			
Max	**.7293**	**.7293**	**1.442**	**1.757**	**1.9418**	**1.6244**
Min	**.2321**	**.1326**	**.2012**	**.4641**	**1.1869**	**.9945**
Avg	**.3945**	**.2967**	**.7513**	**1.3985**	**1.5948**	**1.3568**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U. CENTRAL[017] BU 4017
Substation No/ Name :- 144033 / SHENDA PARK S/STN
Feeder No / Name : 201 / 11KV I.T.Park SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.0187	.0177	.0181	.0187	.0187	.0181
2	.0187	.0187	.0177	.0181	.0187	.0187	.0181
3	.0187	.0187	.0177	.0181	.0187	.0187	.0181
4	.0187	.0187	.0177	.0181	.0187	.0187	.0181
5	.0187	.0187	.0177	.0181	.0187	.0187	.0181
6	.0187	.0187	.0177	.0181	.0187	.0187	.0181
7	.0187	.0187	.0177	.0181	.0187	.0187	.0181
8	.0187	.0185	.0177	.0181	.0187	.0187	.0181
9	.0187	.0185	.0177	.0181	.0187	.0185	.0181
10	.0354	.0181	.0187	.0177	.0181	.0187	.0187
11	.0354	.0181	.0187	.0177	.0181	.0373	.037
12	.0354	.0181	.0187	.0177	.0181	.0373	.037
13	.0354	.0181	.0187	.0177	.0181	.0373	.0373
14	.0366	.0181	.0187	.0177	.0362	.0373	.0373
15	.0354	.0181	.0187	.0177	.0362	.0373	.0373
16	.0354	.0181	.0187	.0177	.0362	.0373	.0373
17	.0373	.0177	.0181	.0187	.0354	.0362	.056
18	.0373	.0177	.0181	.0187	.0354	.0362	.0373
19	.0373	.0177	.0181	.0187	.0354	.0181	.0373
20	.0373	.0177	.0181	.0187	.0354	.0181	.0187
21	.0373	.0177	.0181	.0187	.0354	.0181	.0187
22	.0187	.0177	.0181	.0187	.0185	.1267	.0187
23	.0187	.0177	.0181	.0185	.0187	.0181	.0187
24	.0187	.0187	.0177	.0181	.0187	.0187	.0181
Max	**.0373**	**.0187**	**.0187**	**.0187**	**.0362**	**.1267**	**.056**
Min	**.0187**	**.0177**	**.0177**	**.0177**	**.0181**	**.0181**	**.0181**
Avg	**.0275**	**.0182**	**.0181**	**.0182**	**.0243**	**.0292**	**.0262**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U. CENTRAL[017] BU 4017
Substation No/ Name :- 144033 / SHENDA PARK S/STN
Feeder No / Name : 202 / HOCKY STADIUM SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0747	.0716	.0924	.0747	.0934	.0739
2	.0747	.0747	.0716	.0739	.0747	.0934	.0739
3	.0747	.0747	.0716	.0739	.0747	.0934	.0739
4	.0747	.0747	.0716	.0739	.0747	.0934	.0739
5	.0747	.0747	.0716	.0739	.0934	.0934	.0739
6	.0938	.0747	.0716	.0924	.112	.0934	.0924
7	.0934	.0934	.0716	.0924	.0934	.0747	.0924
8	.0187	.112	.0716	.0924	.1307	.1307	.1294
9	.1494	.1307	.1254	.1478	.1307	.1307	.1478
10	.1075	.1478	.112	.1254	.1294	.1307	.1307
11	.1075	.1109	.112	.0895	.1109	.1307	.112
12	.1075	.1109	.0934	.0895	.1109	.0934	.112
13	.1075	.0924	.0747	.1075	.0924	.112	.112
14	.0895	.0924	.0747	.1075	.0924	.0934	.0934
15	.0895	.0739	.0747	.1075	.0924	.0747	.0934
16	.0895	.0924	.0747	.0895	.0924	.0934	.112
17	.112	.0895	.0739	.0934	.0716	.0924	.112
18	.0934	.1254	.0739	.112	.0895	.1109	.112
19	.1494	.1254	.1478	.1867	.1254	.1663	.168
20	.1494	.1075	.1478	.1867	.1433	.1663	.168
21	.1494	.1791	.1294	.1494	.1612	.1663	.168
22	.1307	.1433	.1294	.1494		.1294	.168
23	.112	.0895	.1109	.112	.112	.0185	.112
24	.0934	.0934	.0716	.0924	.0943	.0934	.0924
Max	**.1494**	**.1791**	**.1478**	**.1867**	**.1612**	**.1663**	**.168**
Min	**.0187**	**.0739**	**.0716**	**.0739**	**.0716**	**.0185**	**.0739**
Avg	**.1007**	**.1024**	**.0916**	**.1088**	**.1034**	**.1070**	**.1124**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U. CENTRAL[017] BU 4017
Substation No/ Name :- 144033 / SHENDA PARK S/STN
Feeder No / Name : 204 / RENUKA FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5975	.6161	.6668	.6348	.6348	.6348	.6348
2	.5975	.5975	.6478	.5975	.5975	.5975	.5788
3	.5975	.5975	.6478	.5975	.5975	.5975	.5788
4	.5975	.6161	.6478	.5975	.5975	.5975	.5788
5	.6348	.6348	.6287	.5975	.6348	.6348	.5975
6	.7095	.6908	.6668	.6722	.7095	.6908	.7023
7	.8215	.7468	.7621	.7655	.7392	.7282	.7655
8	.9709	.9335	.8764	.8775	.9055	.9335	.9335
9	.9896	.9335	.9907	.9522	.9522	1.0082	1.0082
10	.9335	1.0082	1.0082	.9335	1.1203	1.0082	1.0082
11	.9335	.9522	.9522	.9145	.9335	1.0456	.9335
12	.8954	.8589	.8962	.8192	.9522	.9149	.8962
13	.8002	.8775	.8029	.7811	.7842	.8029	.8029
14	.7621	.7842	.7282	.6859	.7655	.7282	.7468
15	.8002	.7655	.7282	.6668	.7468	.7095	.7282
16	.8002	.7468	.6722	.6668	.6535	.7655	.7842
17	.7655	.7811	.7095	.6722	.5144	.7842	.8215
18	.8775	.9145	.8589	.8029	.9526	.9335	.9335
19	1.0642	1.1431	1.0829	1.0269	1.1431	1.1389	1.1203
20	1.1016	1.105	1.0456	1.0456	1.105	1.1389	1.0829
21	1.1203	1.105	1.0269	1.0269	1.0098	1.0829	1.0269
22	1.0269	.9335	.9896	.9709	1.0082	.9896	.9522
23	.8029	.8002	.8402	.8402	.8962	.8402	.8029
24	.6722	.6722	.6668	.6348	.6722	.6722	.6653
Max	**1.1203**	**1.1431**	**1.0829**	**1.0456**	**1.1431**	**1.1389**	**1.1203**
Min	**.5975**	**.5975**	**.6287**	**.5975**	**.5144**	**.5975**	**.5788**
Avg	**.8280**	**.8256**	**.8143**	**.7825**	**.8178**	**.8324**	**.8202**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U. CENTRAL[017] BU 4017
Substation No/ Name :- 144033 / SHENDA PARK S/STN
Feeder No / Name : 205 / SUBHASH NAGAR FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4481	.4108	.4763	.4108	.4481	.4294	.4294
2	.4108	.4108	.4572	.4108	.4108	.3921	.3734
3	.4108	.4108	.4572	.4108	.4108	.3921	.3734
4	.4108	.4481	.4382	.4108	.4108	.4108	.3734
5	.4481	.4854	.4382	.4108	.4481	.4481	.3921
6	.5041	.5788	.5335	.4294	.3921	.5601	.5228
7	.6908	.8029	.6478	.6535	.5041	.6161	.6722
8	.8962	.8775	.7621	.8402	.8131	.8589	.7842
9	.9522	.9335	.9526	.8775	.924	.9522	.9896
10	.8573	.8775	.8775	.8383	.8775	.8402	.8589
11	.7621	.7282	.8029	.7621	.7468	.8029	.7282
12	.6287	.6653	.7468	.7049	.6908	.6908	.7095
13	.6287	.6535	.6908	.6287	.6161	.6161	.5975
14	.5716	.6348	.6161	.5716	.5601	.5415	.5601
15	.5525	.5975	.5788	.5144	.5788	.5601	.5415
16	.5716	.5415	.5975	.5144	.5415	.5228	.5415
17	.4481	.4763	.4668	.4481	.5144	.4854	.4668
18	.7842	.8002	.8215	.7282	.8192	.7842	.8029
19	1.1203	1.3146	1.0642	1.0269	1.0669	1.0642	1.0829
20	1.0829		1.1016	1.0456	1.086	1.1016	1.0829
21	1.0829	.9335	.9149	.2801	1.0669	.9335	.9149
22	.8775	.7811	.8589	.8029	.8589	.8215	.8029
23	.6161	.6097	.6722	.6348	.6908	.6535	.6161
24	.4854	.5041	.4763	.4668	.4854	.4854	.4668
Max	**1.1203**	**1.3146**	**1.1016**	**1.0456**	**1.086**	**1.1016**	**1.0829**
Min	**.4108**	**.4108**	**.4382**	**.2801**	**.3921**	**.3921**	**.3734**
Avg	**.6767**	**.6729**	**.6854**	**.6176**	**.6651**	**.6651**	**.6535**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U. CENTRAL[017] BU 4017
Substation No/ Name :- 144104 / RAMANAND NAGAR
Feeder No / Name : 201 / SAMBHAJI NAGAR CZ SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.5658	.5658	.5658	.5281	.5658	.5281
2	.5093	.5281	.547	.5281	.4755	.5281	.4715
3	.5093	.5093	.5093	.5093	.4904	.5093	.4715
4	.6036	.547	.5281	.5281	.5093	.4904	.5658
5	.6979	.5658	.6224	.547	.5658	.5658	.6602
6	.7545	.6602	.6602	.6224	.679	.6602	.7545
7	.8299	.8488	.6979	.6979	.811	.7922	.7733
8	.9054	.7922	.7922	.811	.8488	.8488	.8488
9	.9619	.9431	.9431	.8488	.9619	.9054	.9431
10	.9997	.9054	.9431	.811	.8676	.8676	.9431
11	.8676	.8488	.9054	.7167	.7922	.811	.8488
12	.7167	.7922	.7733	.679	.7922	.7545	.7545
13	.679	.679	.7167	.6224	.6979	.6979	.6602
14	.6602	.6602	.6979	.6036	.6602	.6413	.6413
15	.679	.679	.6413	.547	.6602	.679	.6602
16	.6224	.6979	.679	.547	.6979	.679	.6413
17	.6979	.7545	.7167	.6036	.6979	.7545	.6602
18	.9431	.8676	.8488	.7545	1.0374	.9431	.9997
19	1.2637	1.1883	1.226	1.1128	1.1694	1.226	1.226
20	1.1883	1.1694	1.1506	1.094	1.1128	1.1128	1.1506
21	1.1317	1.0751	1.0751	1.0374	1.0562	1.0562	1.0562
22	1.0374	.9808	.9808	.9619	.9619	.9054	.9242
23	.7545	.7545	.811	.7922	.7733	.7545	
24	.6036	.5847	.6036	.6036	.6413	.6413	.5658
Max	**1.2637**	**1.1883**	**1.226**	**1.1128**	**1.1694**	**1.226**	**1.226**
Min	**.5093**	**.5093**	**.5093**	**.5093**	**.4755**	**.4904**	**.4715**
Avg	**.7993**	**.7749**	**.7765**	**.7144**	**.7703**	**.7663**	**.7717**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U. CENTRAL[017] BU 4017
Substation No/ Name :- 144104 / RAMANAND NAGAR
Feeder No / Name : 202 / JAIL KOLHAPUR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.2012	.1991	.2195	.1829	.1829	.1867
2	.168	.1829	.181	.2012	.1829	.1829	.168
3	.168	.1646	.1629	.1829	.1646	.1646	.168
4	.2054	.1646	.1629	.1829	.2012	.1646	.2241
5	.2614	.1829	.1991	.2012	.2378	.2012	.2801
6	.2801	.2743	.2534	.2378	.2743	.2378	.3174
7	.3174	.3326	.2715	.2561	.2743	.2926	.3361
8	.3361	.3361	.3292	.3292	.3109	.3475	.2987
9	.4481	.3696	.3292	.3292	.4207	.5121	.3734
10	.4251	.3734	.2957	.2926	.4024	.4207	.462
11	.3475	.3921	.2561	.2561	.3841	.4024	.4024
12	.2561	.2801	.2172	.2172	.2561	.2561	.2561
13	.2926	.2427	.2012	.2195	.3475	.3292	.2743
14	.2534	.2801	.2012	.2195	.3475	.2926	.3109
15	.1991	.2241	.1829	.1829	.2926	.2012	.2195
16	.3439	.3361	.1663	.1646	.3475	.2743	.2743
17	.3109	.3361	.2033	.2012	.3077	.3292	.2926
18	.3658	.4024	.2195	.2561	.3658	.4108	.3292
19	.4755	.5304	.4024	.4024	.4938	.5601	.567
20	.439	.4755	.4207	.4207	.567	.4854	.5121
21	.4207	.4207	.4024	.4024	.4207	.4108	.4207
22	.3881	.3658	.3658	.3658	.3475	.3547	.3658
23	.2743	.2896	.2926	.2743	.2926	.2801	.2926
24	.2054	.2195	.2195	.2378	.2195	.2195	.2241
Max	**.4755**	**.5304**	**.4207**	**.4207**	**.567**	**.5601**	**.567**
Min	**.168**	**.1646**	**.1629**	**.1646**	**.1646**	**.1646**	**.168**
Avg	**.3070**	**.3074**	**.2556**	**.2605**	**.3184**	**.3131**	**.3148**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U. CENTRAL[017] BU 4017
Substation No/ Name :- 144104 / RAMANAND NAGAR
Feeder No / Name : 204 / KALAMBA **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5544	.5544	.5544	.5914	.5853	.5853	.5544
2	.499	.5175	.5359	.5544	.5487	.567	.499
3	.499	.499	.5121	.5175	.5121	.5304	.499
4	.6468	.5359	.4938	.5544	.4938	.5121	.5914
5	.7762	.5914	.567	.5914	.6219	.6584	.7947
6	.924	.8871	.6767	.7023	.8048	.8413	.9979
7	1.1088	1.2197	.9511	1.0534	1.1523	1.134	1.1273
8	1.3676	1.2936	1.2752	1.2936	1.2254	1.3169	1.2752
9	1.2071	1.2012	1.2752	1.2567	1.134	1.2254	1.1458
10	.9979	1.0534	1.1088	1.0719	.9795	1.0349	.924
11	.8501	1.0349	.9425	.9055	.8871	.8871	.8501
12	.8131	.924	.924	.7947	.8316	.8686	.7762
13	.7947	.9055	.8686	.7762	.7762	.7947	.7392
14	.7947	.8131	.7577	.7392	.7762	.7207	.7392
15	.7392	.8131	.7392	.6838	.7392	.7207	.7023
16	.7316	.8131	.7023	.7207	.7392	.7023	.6838
17	.8316	.8501	.8501	.7577	.7762	.7947	.7577
18	1.0059	1.1088	1.0349	.8779	1.1888	1.1157	1.0242
19	1.4815	1.4784	1.423	1.3169	1.4632	1.4815	1.39
20	1.46	1.423	1.386	1.3717	1.39	1.3535	1.3717
21	1.2567	1.3306	1.3306	1.262	1.3169	1.3169	1.2803
22	1.2012	1.1458	1.1458	1.134	1.134	1.0974	1.0608
23	.8316	.7392	.8501	.8962	.8413	.7762	.695
24	.5914	.6099	.6099	.6283	.6584	.6767	.5914
Max	**1.4815**	**1.4784**	**1.423**	**1.3717**	**1.4632**	**1.4815**	**1.39**
Min	**.499**	**.499**	**.4938**	**.5175**	**.4938**	**.5121**	**.499**
Avg	**.9152**	**.9309**	**.8965**	**.8772**	**.8990**	**.9047**	**.8779**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U. CENTRAL[017] BU 4017
Substation No/ Name :- 144104 / RAMANAND NAGAR
Feeder No / Name : 205 / JARAG NAGAR **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5121	.543	.5792	.5792	.5487	.5853	.4938
2	.4572	.5121	.543	.543	.5121	.5487	.4572
3	.4572	.4938	.5249	.5068	.4938	.5121	.4572
4	.5487	.5121	.5068	.5068	.4938	.4938	.5121
5	.6401	.5487	.5249	.5249	.5487	.567	.5853
6	.7316	.6219	.543	.543	.6584	.6584	.6401
7	.7682	.7682	.6154	.6154	.7499	.7316	.6767
8	.9511	.8145	.7783	.8413	.8962	.8962	.8779
9	.8962	.8779	.8507	.8048	.9145	.8779	.8779
10	.7783	.7316	.7783	.8145	.8145	.7602	.724
11	.6335	.7865	.724	.7602	.7133	.6878	.6697
12	.7059	.7316	.724	.6335	.6697	.6878	.6335
13	.6154	.6767	.6697	.6154	.6154	.6697	.5973
14	.5792	.6401	.5792	.5973	.6036	.5792	.5611
15	.5249	.567	.5611	.543	.5611	.543	.4887
16	.5611	.5487	.543	.543	.5068	.5249	.5068
17	.567	.6401	.6036	.5792	.5611	.5611	.5792
18	.7602	.8145	.7602	.7316	1.0059	.8779	.8779
19	1.1765	1.1946	1.1584	1.134	1.262	1.2437	1.2254
20	1.2308	1.2127	1.2127	1.1888	1.262	1.2437	1.2254
21	1.2071	1.1946	1.1403	1.134	1.1888	1.1706	1.1888
22	1.0425	1.0136	1.1041	1.0791	1.0425	.9511	.9694
23	.7783	.7602	.7783	.8413	.7682	.7682	.695
24	.5487	.5973	.5973	.5973	.6219	.6401	.5487
Max	**1.2308**	**1.2127**	**1.2127**	**1.1888**	**1.262**	**1.2437**	**1.2254**
Min	**.4572**	**.4938**	**.5068**	**.5068**	**.4938**	**.4938**	**.4572**
Avg	**.7363**	**.7418**	**.7250**	**.7191**	**.7505**	**.7408**	**.7112**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(E) S/DN.[016] BU 4016
Substation No/ Name :- 144029 / SHAHU MILL
Feeder No / Name : 208 / RAJARAMPURI SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3772	.3772	.4338	.415	.415	.3584
2	.3772	.3584	.3584	.415	.3961	.3961	.3584
3	.3584	.3206	.3206	.3961	.3961	.3961	.3584
4	.3584	.3206	.3206	.3961	.3961	.3961	.3584
5	.3584	.3395	.3961	.415	.3961	.4338	.3961
6	.4338	.3961	.4527	.4338	.4338	.4904	.4338
7	.5658	.5847	.5658	.5281	.6036	.5658	.5658
8	.7167	.679	.6036	.679	.679	.679	.6602
9	.7356	.7356	.6224	.7356	.7545	.7733	.7545
10	.7545	.7545	.6979	.7167	.7811	.7545	.7733
11	.9808	.9242	.8299	.8865	1.0098	.9242	.8488
12	.9997	1.0185	.9808	.5093	.9907	.9431	.9619
13	1.0751	.8676	.8488	.4904	.9526	.9619	.8299
14	.9431	.8488	.7545	.4527	.8954	.9054	.9242
15	.8676	.7922	.7545	.415	.8192	.7733	.8299
16	.8865	.7922	.7167	.8865	.8764	.811	.7922
17	.9431	.9431	.7733	.9242	.9054	.8676	.9619
18	1.1203	1.1128	.9808	1.0562	1.1883	1.1694	1.0562
19	1.363	1.3203	1.226	1.3014	1.4146	1.3203	1.363
20	1.2696	1.2449	1.1694	1.226	1.2637	1.2637	1.2323
21	.9896	1.0374	1.0751	1.0751	1.0185	1.0751	1.1016
22	.7468	.7545	.7922	.7356	.7545	.7545	.7095
23	.5041	.5658	.5658	.5847	.6224	.5658	.5415
24	.415	.415	.415	.4338	.4338	.4338	.4338
Max	**1.363**	**1.3203**	**1.226**	**1.3014**	**1.4146**	**1.3203**	**1.363**
Min	**.3584**	**.3206**	**.3206**	**.3961**	**.3961**	**.3961**	**.3584**
Avg	**.7558**	**.7293**	**.6916**	**.6719**	**.7665**	**.7529**	**.7335**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(E) S/DN.[016] BU 4016
Substation No/ Name :- 144029 / SHAHU MILL
Feeder No / Name : 209 / 11 KV VARDHAMAN SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2075	.2075	.2263	.2075	.2075	.2263
2	.1886	.1886	.1886	.1886	.1886	.1886	.2263
3	.1886	.1886	.1886	.1886	.1886	.1886	.2075
4	.1886	.2075	.1886	.1886	.2075	.1886	.2075
5	.1886	.2263	.2263	.2263	.2263	.2075	.2263
6	.2452	.2641	.2829	.2829	.2641	.2452	.2829
7	.3395	.3018	.3395	.3018	.3206	.3018	.3206
8	.3961	.3772	.3395	.3206	.3772	.3772	.415
9	.3961	.415	.3584	.3584	.415	.3772	.415
10	.415	.415	.3395	.3772	.381	.3772	.3772
11	.3772	.4338	.3772	.3772	.4572	.415	.3772
12	.3772	.415	.3772		.4191	.415	.4527
13	.3772	.415	.3206		.381	.3772	.4527
14	.3772	.415	.3206	.6036	.381	.3395	.4527
15	.3772	.3395	.3584	.3772	.3048	.3395	.4527
16	.3772	.3772	.2829	.3584	.3429		.3395
17	.3961	.3772	.3206	.3584	.3772	.3772	.3772
18	.4481	.3772	.3961	.3961	.4527	.415	.4527
19	.5415	.5281	.5281	.547	.5281	.547	.5228
20	.5228	.5281	.4904	.5281	.5281	.547	.5228
21	.4294	.3772	.4527	.4527	.4527	.4527	.4668
22	.3547	.3772	.3961	.3584	.3772	.3395	.3734
23	.2614	.3018		.3018	.3018	.2641	.2801
24	.2263	.2263	.2452	.2263	.2263	.2263	.2263
Max	**.5415**	**.5281**	**.5281**	**.6036**	**.5281**	**.547**	**.5228**
Min	**.1886**	**.1886**	**.1886**	**.1886**	**.1886**	**.1886**	**.2075**
Avg	**.3408**	**.3450**	**.3272**	**.3429**	**.3461**	**.3354**	**.3606**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(E) S/DN.[016] BU 4016
Substation No/ Name :- 144029 / SHAHU MILL
Feeder No / Name : 210 / 11 KV SHAHUPURI FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.4527	.4715	.5658	.4715	.4715	.4527
2	.4527	.4338	.4338	.5281	.4527	.4527	.4527
3	.4527	.415	.415	.4715	.4338	.4338	.415
4	.4527	.415	.415	.4715	.4338	.4338	.415
5	.4527	.415	.415	.4715	.4338	.4338	.4527
6	.5281	.4715	.4715	.547	.4715	.4904	.5281
7	.5658	.5658	.5847	.5281	.5281	.547	.5281
8	.6602	.5847	.5281	.6036	.6602	.6602	.6413
9	.7545	.7167	.6224	.5658	.6602	.6979	.6979
10	.9431	.8865	.679	.6602	.9335	.8299	.9054
11	1.1883	.9431	.7733	.8676	1.105	1.0751	.9997
12	1.1694	.9808	.7922	.8488	1.1622	1.0185	1.1506
13	1.094	1.0185	.8676	.9054	1.2003	1.094	1.094
14	1.1317	1.0751	.811	.9808	1.086	1.0562	1.0185
15	1.1506	.9431	.7545	.8676	1.1812	1.0751	1.0751
16	1.1694	1.0374		.8676	1.2765		1.0751
17	1.2449	1.0562	1.1694	.8676	1.1883	1.3392	.9997
18	1.2323	1.094	.9997	.9431	1.226	1.2071	1.1506
19	1.2136	1.1317	1.1128	1.0185	1.3014	1.1694	1.1949
20	1.1389	1.0751	.9431	.9808	1.1506	1.0751	1.0642
21	.7842	.8676	.8676	.8865	1.0185	.9054	.9335
22	.7468	.7167	.8676	.811	.7545	.7167	.7282
23	.6161	.6413	.5658	.6602	.6413	.6979	.6535
24	.5281	.4904	.547	.5658	.5093	.5281	.5658
Max	**1.2449**	**1.1317**	**1.1694**	**1.0185**	**1.3014**	**1.3392**	**1.1949**
Min	**.4527**	**.415**	**.415**	**.4715**	**.4338**	**.4338**	**.415**
Avg	**.8401**	**.7678**	**.7003**	**.7285**	**.8450**	**.8004**	**.7997**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(E) S/DN.[016] BU 4016
Substation No/ Name :- 144029 / SHAHU MILL
Feeder No / Name : 211 / Takala **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4338	.4527	.4715	.4715	.4338	.4715	.4338
2	.4338	.4338	.4527	.4715	.4338	.4338	.4338
3	.415	.415	.4338	.4338	.415	.415	.415
4	.415	.415	.4338	.4338	.415	.415	.415
5	.4338	.415	.4338	.4527	.415	.4527	.4527
6	.5658	.5847	.5658	.5281	.5281	.547	.5847
7	.8299	.7167	.7356	.6413	.6602	.7167	.6979
8	.9054	.8299	.8676	.7922	.811	.9997	.8488
9	.8299	.9431	.8676	.8299	.8488	1.0374	.8488
10	.9242	.9242	.8488	.9619	.8764	.8299	.8865
11	.811	.7733	.7922	.7545	.7811	.8488	.8299
12	.7167	.811	.7545	.7545	.7811	.7167	.7167
13	.7356	.6979	.6979	.6413	.7621	.7356	.6979
14	.6413	.6224	.6036	.6224	.6859	.5093	.6224
15	.5847	.5847		.6036	.6287	.5093	.5847
16	.6036	.5658	.5658	.4904	.6097	.547	.6413
17	.6413	.6602	.6224	.547	.6602	.6413	.6413
18	.8215	.7545	.6979	.6413	.7922	.9054	.6979
19	.9896	.9808	.8865	.8488	.9997	.9431	.9709
20	.8589	.9997	.9242	.8299	.9619	.9431	.9335
21	.8589	.9242	.811	.8488	.9054	.8676	.8215
22	.7655	.8676	.7922	.7545	.8488	.7922	.7655
23	.5788	.6979	.6036	.6036	.6979	.6036	.6161
24	.4715	.4715	.547	.5093	.4527	.5281	.4904
Max	**.9896**	**.9997**	**.9242**	**.9619**	**.9997**	**1.0374**	**.9709**
Min	**.415**	**.415**	**.4338**	**.4338**	**.415**	**.415**	**.415**
Avg	**.6777**	**.6892**	**.6700**	**.6444**	**.6835**	**.6837**	**.6686**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(E) S/DN.[016] BU 4016
Substation No/ Name :- 144029 / SHAHU MILL
Feeder No / Name : 212 / 11 KV SHAHUMILL KOP.MAULI SHEDDABLE URBAN FEED Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3206	.3395	.3395	.3772	.3584	.3584	.3206
2	.3206	.3206	.3206	.3584	.3395	.3395	.3206
3	.3206	.3018	.3018	.3206	.3395	.3395	.3206
4	.3206	.3018	.3018	.3206	.3395	.3395	.3206
5	.3395	.3395	.3395	.3395	.3395	.3395	.3584
6	.4338	.415	.415	.3772	.415	.415	.415
7	.5281	.4715	.4904	.4527	.5093	.4904	.4904
8	.6413	.547	.5658	.5847	.5658	.6036	.6036
9	.6602	.547	.5847	.6224	.5658	.6224	.6224
10	.7545	.5281	.5658	.6036	.5525	.5281	.5847
11	.547	.547	.4904	.5658	.5335	.5093	.547
12	.5658	.547	.5658	.4715	.5335	.4715	.547
13	.5093	.5847	.5281	.5093	.5335	.4527	.5281
14	.4715	.4904	.4715	.4527	.4572	.4338	.4715
15	.4338	.4527	.4338	.4338	.4572	.4338	.415
16	.4527	.4527	.4527	.415	.4001	.415	.4338
17	.4715	.5093	.5093	.4715	.5281	.4527	.4715
18	.6535	.6413	.6224	.5658	.6413	.6036	.6224
19	.9149	.8865	.8676	.7922	.9242	.9242	.9149
20	.8775	.8488	.8488	.8299	.8488	.8676	.8775
21	.8029	.7733	.7922	.7733	.7733	.7922	.8215
22	.6535	.6602	.679	.679	.679	.6602	.6535
23	.4668	.4904	.4715	.4904	.5093	.4904	.4854
24	.3584	.3584	.3584	.3961	.3584	.3584	.3772
Max	**.9149**	**.8865**	**.8676**	**.8299**	**.9242**	**.9242**	**.9149**
Min	**.3206**	**.3018**	**.3018**	**.3206**	**.3395**	**.3395**	**.3206**
Avg	**.5341**	**.5148**	**.5132**	**.5085**	**.5209**	**.5101**	**.5218**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(E) S/DN.[016] BU 4016
Substation No/ Name :- 144029 / SHAHU MILL
Feeder No / Name : 213 / Panjarpol **SHEDDABLE FEEDER HAVING WEEKLY**
Feeder KV- 11 / OUTGOING **STAGGERING (MIDC, EQUIVALENT)**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	.0566	.0754	.0566	.0566	.0754
2	.0566	.0754	.0566	.0754	.0566	.0566	.0754
3	.0566	.0754	.0566	.0566	.0566	.0566	.0566
4	.0566	.0754	.0566	.0566	.0566	.0566	.0566
5	.0566	.0754	.0754	.0566	.0566	.0566	.0566
6	.0754	.0754	.0754	.0566	.0566	.0566	.0754
7	.0754	.0754	.0754	.0566	.0566	.0566	.0754
8	.0754	.0754	.0754	.0754	.0566	.0754	.0754
9	.1132	.132	.0943	.0754	.0754	.0754	.1132
10	.1698	.1886	.1509	.0754	.1334	.132	.1698
11	.1698	.1886	.2263	.0943	.2667	.1886	.2263
12	.2452	.2263	.1509	.0754	.1905	.1698	.2263
13	.1886	.1698	.1698	.0754	.1715	.1698	.1886
14	.1132	.1509	.1132	.0566	.1143	.0943	.132
15	.2075	.1886	.0943	.0754	.2096	.132	.2075
16	.2829	.2263	.1886	.0566	.2286	.2075	.2075
17	.1886	.1886	.2075	.0754	.2075	.1886	.2075
18	.1494	.1509	.1698	.0754	.2075	.2263	.1698
19	.168	.1698	.1698	.0754	.1886	.132	.9149
20	.1307	.132	.1132	.0754	.1509	.1509	.1307
21	.0747	.0754		.0566	.1132	.0943	.0934
22	.0747	.0943	.0754	.0754	.0943	.0943	.0747
23	.0747	.0754	.0754	.0566	.0754	.0754	.0747
24	.0754	.0754	.0754	.0754	.0566	.0754	.0754
Max	**.2829**	**.2263**	**.2263**	**.0943**	**.2667**	**.2263**	**.9149**
Min	**.0566**	**.0754**	**.0566**	**.0566**	**.0566**	**.0566**	**.0566**
Avg	**.1231**	**.1265**	**.1132**	**.0691**	**.1224**	**.1116**	**.1566**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(E) S/DN.[016] BU 4016
Substation No/ Name :- 144029 / SHAHU MILL
Feeder No / Name : 411 / 33 KV Incomer No. I MIDC FEEDE Feeder KV- 33 / INCOMING
NON SHEDDABLE EXPRESS HV FEEDERS (NON-CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.32	2.4331	2.4331	2.6595	2.4897	2.4897	2.32
2	2.2634	2.2634	2.2634	2.5463	2.3765	2.32	2.32
3	2.2634	2.1502	2.1502	2.3765	2.2634	2.2634	2.2068
4	2.2634	2.1502	2.1502	2.3765	2.2634	2.2634	2.2068
5	2.2634	2.2634	2.32	2.4897	2.32	2.4897	2.4331
6	2.8292	2.7726	2.8858	2.7726	2.7161	2.8858	2.8858
7	3.6214	3.3951	3.4517	3.1687	3.2819	3.3385	3.4517
8	4.2438	3.8477		3.8477	3.9609	4.2438	4.1307
9	4.357	4.3004	4.0175	4.0175	4.1872	4.4702	4.3004
10	4.5833		4.1307	4.2438	4.5153	4.3004	4.5833
11		4.6965	4.4136	4.4136	5.0869	4.8663	4.8097
12	4.9794	4.9228	4.4702	3.5082	5.0297	4.6965	4.9794
13	4.8097	4.5833	4.2438	3.5082	4.9154	4.6399	4.6399
14	3.7912	4.4136	3.7346	3.9609	4.4582	4.1307	4.4136
15	4.5268	4.0175	3.0556	3.5082	4.401	3.9609	4.357
16	4.5833	4.1307	2.9424	3.7912	4.4582	3.0556	4.2438
17	4.6965	4.5268	4.357	4.0175	4.7531	4.6965	4.5268
18	5.5453	5.036	4.7531	4.5833	5.5453	5.6019	5.1492
19	6.4975		6.1111	5.8848	6.7335	6.4506	6.6095
20	6.0494	6.0545	5.7716	5.6584	6.2243	6.1111	6.1054
21	5.0412	5.1492	5.1492	5.1492	5.4887	5.2624	5.3772
22	4.537	4.4136	4.5833	4.357	4.4702	4.3004	4.201
23	3.2487	3.5648	3.3951	3.4517	3.6214	3.4517	3.3608
24	2.6029	2.6029	2.7726	2.7726	2.6029	2.7161	2.7161
Max	**6.4975**	**6.0545**	**6.1111**	**5.8848**	**6.7335**	**6.4506**	**6.6095**
Min	**2.2634**	**2.1502**	**2.1502**	**2.3765**	**2.2634**	**2.2634**	**2.2068**
Avg	**3.9964**	**3.8040**	**3.7198**	**3.7110**	**4.0901**	**3.9586**	**4.0137**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(E) S/DN.[016] BU 4016
Substation No/ Name :- 144100 / Y. P. POWAR NAGAR
Feeder No / Name : 201 / 11 KV Udymnagar KOP.INDUSTRIAL Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6478	.6097	.6097	.5716	.6097	.6478
2	.6859	.6478	.6097	.6097	.5716	.6097	.6478
3	.6478	.6478	.6097	.6097	.5716	.6097	.6097
4	.6478	.6859	.6097	.6097	.6097	.6097	.6097
5	.6859	.6859	.6097	.6097	.6478	.6097	.6478
6	.6859	.724	.6097	.6097	.6478	.6097	.6478
7	.6859	.6859	.6097	.6478	.6097	.6097	.6478
8	.6478	.6478	.6097	.6097	.6097	.5716	.6097
9	.5335	.5716	.5716	.5716	.6097	.6097	.6097
10	.8383	.6859	.8383	.4572	.724	.8383	.6859
11	.9907	.9145	.8383	.5716	.7621	.8764	.8383
12	.8764	.8002	.8383	.5335	.7621	.8002	.7621
13	.6478	.6478	.6478	.6097	.6859	.724	.6859
14	.6859	.6859	.6478	.6097	.6859	.6097	.6859
15	.8002	.8002	.6859	.6097	.8383	.8764	.7621
16	.8002	.7621	.6859	.5335	.8383	.9526	.7621
17	.724	.724	.6478	.6097	.6859	.8002	.6859
18	.6478	.6859	.5335	.6097	.6097	.6859	.6097
19	.5335	.5716	.5716	.6097	.4954	.5335	.4954
20	.5335	.6097	.5716	.6097	.5335	.6097	.5335
21	.6478	.5716	.5716	.6097	.5335	.6097	.6097
22	.6859	.6859	.6097	.6097	.6097	.6478	.5716
23	.6478	.5716	.6478	.6478	.5716	.5716	.5335
24	.6859	.6859	.6097	.6097	.6097	.6478	.6478
Max	**.9907**	**.9145**	**.8383**	**.6478**	**.8383**	**.9526**	**.8383**
Min	**.5335**	**.5716**	**.5335**	**.4572**	**.4954**	**.5335**	**.4954**
Avg	**.6938**	**.6811**	**.6415**	**.5970**	**.6415**	**.6764**	**.6478**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(E) S/DN.[016] BU 4016
Substation No/ Name :- 144100 / Y. P. POWAR NAGAR
Feeder No / Name : 202 / 11 KV SAMARAT NAGAR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.2926	.3326	.3429	.2957	.3429	.381
2	.3048	.2926	.2926	.3048	.2957	.3048	.3429
3	.3048	.2926	.2926	.3048	.2957	.3048	.3429
4	.3048	.3292	.2926	.3048	.3326	.3048	.3429
5	.3429	.3658	.2926	.3429	.3696	.3429	.381
6	.4572	.439	.4024	.381	.4066	.4954	.4191
7	.4954	.5175	.5121	.4954	.4854	.6097	.6097
8	.6097	.5975	.5853	.5716	.5975	.6859	.6859
9	.6859	.7095	.6348	.6859	.6348	.6859	.7621
10	.6478	.6859	.5975	.6097	.5716	.6348	.6859
11	.6097	.5335	.5228	.5335	.5716	.5601	.6478
12	.4954	.5335	.4854	.4954	.4572	.4854	.5335
13	.4572	.5335	.4854	.4572	.4191	.4854	.4954
14	.4191	.4191	.4481	.4191	.381	.4481	.4572
15	.4191	.381	.4108	.3048	.381	.4481	.4572
16	.4191	.381	.3734	.2286	.4572	.4108	.4481
17	.4108	.4191	.4191	.3361	.4572	.4191	.5228
18	.5228	.5335	.5335	.4854	.6097	.6097	.6348
19	.7468	.6859	.6859	.6348	.724	.8002	.7468
20	.6722	.6859	.6859	.5975	.6859	.8002	.7468
21	.6348	.6478	.6859	.6348	.7621	.7621	.7095
22	.5975	.6097	.6097	.5601	.6859	.6859	.6348
23	.4435	.4572	.4572	.4481	.4954	.4954	.4854
24	.3429	.3292	.3326	.381	.3326	.381	.4191
Max	**.7468**	**.7095**	**.6859**	**.6859**	**.7621**	**.8002**	**.7621**
Min	**.3048**	**.2926**	**.2926**	**.2286**	**.2957**	**.3048**	**.3429**
Avg	**.4854**	**.4863**	**.4738**	**.4525**	**.4877**	**.5210**	**.5372**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(E) S/DN.[016] BU 4016
Substation No/ Name :- 144100 / Y. P. POWAR NAGAR
Feeder No / Name : 203 / 11 KV HUTATMA PARK SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	.8002	.8764	.8383	.8383	.8383	.9145
2	.8383	.8002	.8764	.8383	.8002	.8383	.9145
3	.8383	.8002	.8764	.8764	.8002	.8002	.9145
4	.8383	.8383	.8764	.8764	.8383	.8002	.8764
5	.8383	.8383	.8764	.8764	.8383	.8383	.8764
6	.8383	.8764	.8383	.9145	.8764	.8383	.9145
7	.8002	.8002	.8002	.9526	.8764	.8383	.8764
8	.8002	.8002	.8383	.9145	.8383	.8002	.8383
9	.8383	.8764	.8764	.9145	.8764	.8383	.8764
10	.9145	.9907	.9526	.9145	.9907	1.0288	.9145
11	1.105	1.1431	1.105	.9145	1.2193	1.1812	1.105
12	1.0288	1.0288	1.0669	.8764	1.1431	1.0669	1.0669
13	.9526	.9907	1.0288	.8764	1.0288	1.0288	.9907
14	.9526	1.0288	.9907	.8764	.9907	.9907	1.0288
15	1.105	1.105	1.0288	.8764	1.1431	1.105	1.105
16	.9526	1.1812	1.0669	.8764	1.105	1.105	1.1812
17	.9907	1.0669	1.0288	.8764	1.0669	1.0669	1.0288
18	.9145	1.0288	1.0288	.8764	.9907	.9907	.9907
19	.9526	.9526	.9907	.8764	.9526	.9145	.9907
20	.8383	.9145	.8764	.9145	.8764	.8764	.8764
21	.8002	.8764	.9145	.8764	.8764	.8383	.8764
22	.8002	.8764	.8383	.8764	.8764	.8764	.8764
23	.8383	.8383	.8383	.8764	.8383	.8764	.8383
24	.8383	.8383	.8764	.8383	.8764	.8764	.8764
Max	**1.105**	**1.1812**	**1.105**	**.9526**	**1.2193**	**1.1812**	**1.1812**
Min	**.8002**	**.8002**	**.8002**	**.8383**	**.8002**	**.8002**	**.8383**
Avg	**.8939**	**.9288**	**.9320**	**.8843**	**.9399**	**.9272**	**.9478**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(E) S/DN.[016] BU 4016
Substation No/ Name :- 144100 / Y. P. POWAR NAGAR
Feeder No / Name : 205 / RADHA KRISHNA SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.7762	.7392	.8002	.7392	.724	.8002
2	.724	.7023	.6653	.6478	.7023	.724	.7621
3	.6859	.7023	.6653	.6097	.6653	.6859	.724
4	.6859	.7023	.6283	.6097	.6653	.6859	.724
5	.724	.7023	.6283	.6478	.7023	.6859	.724
6	.7621	.7023	.7023	.6859	.7023	.724	.724
7	.8383	.8215	.8589	.8002	.7468	.8002	.8383
8	.9526	.8962	.8962		.8589	.8002	.9145
9	1.0669	1.0829	1.0082	1.0669	1.0829	1.0288	1.105
10	1.1812	1.1812	1.0829	1.0669	1.2955	1.2323	1.2955
11	1.3717	1.448	1.1949	1.3336	1.4861	1.531	1.4861
12	1.7147	1.6004	1.3817	1.2955	1.6766	1.6057	1.6766
13	1.7528	1.6004	1.3443	1.2955	1.6766	1.4937	1.6004
14	1.6385	1.4861	1.1949	1.3717	1.6766	1.5684	1.6004
15	1.6385	1.5242	1.2323	1.2955	1.6766	1.531	1.6385
16	1.6385	1.448	1.2696	1.3717	1.6766	1.6804	1.6057
17	1.6804	1.5623	1.3717	1.3443	1.6766	1.7147	1.7177
18	1.8298	1.7147	1.4861	1.531	1.9052	1.9052	1.7924
19	2.0165	1.9433	1.7528	1.7177	2.0576	1.9433	
20	1.643	1.7528	1.7147	1.6057	1.6385		1.6804
21	1.3443	1.4098	1.5242	1.4563	1.448	1.448	1.419
22	1.1949	1.2955	1.2574	1.2323	1.2574	1.2193	1.1949
23	.961	1.0288	1.0288	.9709	.9907	.9907	1.0082
24	.9145	.8501	.8501	.9145	.7762	.8764	.8764
Max	**2.0165**	**1.9433**	**1.7528**	**1.7177**	**2.0576**	**1.9433**	**1.7924**
Min	**.6859**	**.7023**	**.6283**	**.6097**	**.6653**	**.6859**	**.724**
Avg	**1.2368**	**1.2056**	**1.1033**	**1.1161**	**1.2408**	**1.2000**	**1.2134**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(E) S/DN.[016] BU 4016
Substation No/ Name :- 144100 / Y. P. POWAR NAGAR
Feeder No / Name : 411 / 33 KV Incomer no I
Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS (NON-CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8578	2.8578	2.8578	2.915	2.7435	2.8006	3.0864
2	2.8578	2.7435	2.7435	2.6863	2.7435	2.7435	2.9721
3	2.7435	2.7435	2.7435	2.6863	2.6292	2.6863	2.8578
4	2.7435	2.8578	2.6863	2.6863	2.7435	2.6863	2.8578
5	2.8578	2.9721	2.7435	2.8006	2.915	2.7435	2.9721
6	3.0864	3.1436	2.915	2.915	2.9721	2.915	3.0293
7	3.2007	3.2579	3.2007	3.2579	3.1436	3.2579	3.3722
8	3.4865	3.4294	3.4294	3.7151	3.3722	3.3722	3.4865
9	3.6008	3.7723	3.5437	3.7151	3.7151	3.658	3.8295
10	4.0009	4.0009	4.0009	3.5437	4.0581	4.1724	4.0009
11	4.5725	4.4582	4.0581	3.7723	4.5153	4.5725	4.5725
12	4.5153	4.3439	4.2295	3.6008	4.401	4.401	4.4582
13	4.2295	4.2295	3.8866	3.658	4.1724	4.1724	4.1724
14	4.1152	4.0009	3.658	3.658	4.0581	4.0581	4.1724
15	4.3439	4.1724	3.658	3.4865	4.3439	4.257	4.2867
16	4.1724	4.1152	3.7723	3.3722	4.401	4.5153	4.401
17	4.2295	4.1152	3.8295	3.5437	4.2295	4.401	4.401
18	4.3439	4.401	4.0581	4.0009	4.5725	4.6868	4.5153
19	4.9154	4.7439	4.6296	4.4582	4.8011	4.7439	4.9154
20	4.3439	4.5153	4.4582	4.3439	4.2867	4.4582	4.4582
21	4.0009	4.0009	4.2867	4.1152	4.1724	4.1724	4.2295
22	3.7723	4.0009	3.8295	3.8295	4.0009	3.9438	3.8295
23	3.315	3.315	3.4294	3.315	3.315	3.2579	3.3722
24	3.0864	3.0864	3.0293	3.1436	3.1436	3.1436	3.2007
Max	**4.9154**	**4.7439**	**4.6296**	**4.4582**	**4.8011**	**4.7439**	**4.9154**
Min	**2.7435**	**2.7435**	**2.6863**	**2.6863**	**2.6292**	**2.6863**	**2.8578**
Avg	**3.7247**	**3.7199**	**3.5699**	**3.4675**	**3.7271**	**3.7425**	**3.8104**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(E) S/DN.[016] BU 4016
Substation No/ Name :- 144106 / 33/11 KV SHIVAJI VIDYAPEETH
Feeder No / Name : 201 / 11 KV AMBAI DEFENCE SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2075	.2075	.1734	.1886	.1734	.1886
2	.1715	.1886	.1886	.1715	.1886		.1698
3	.1715	.1886	.1886	.1715	.1886	.1715	.1698
4	.1907	.1886	.1886	.1928	.1886	.1907	.1698
5	.208	.2075	.1886	.1928	.2054	.1907	.1886
6	.2303	.2241	.1886	.1949	.2241	.1949	.2263
7	.2353	.2427	.2263	.2172	.2427	.2353	.3018
8	.2353	.2427	.2829	.2378	.2801	.2534	.3584
9	.2715	.2614	.2829	.2561	.2614	.2534	.3395
10	.2715	.2801	.3018	.2743	.2614	.2353	.2829
11	.2614	.2641	.2715	.056	.2172	.2641	.2614
12	.2241	.2452	.2353	.056	.197	.2263	.2241
13	.1867	.2075	.2172	.2427	.1772	.1886	.1867
14	.168	.2075	.197	.2054	.1772	.1698	.168
15	.168	.1886	.1991	.168	.1772	.1509	.168
16	.168	.1698	.181	.168	.1578	.1698	.168
17	.2054	.1698	.197	.2241	.156	.1698	.168
18	.2241	.2452	.2126	.2801	.1907	.1886	.2427
19	.3361	.3772	.3189	.3361	.3121	.3395	.3547
20	.3361	.3584	.3189	.3174	.3189	.3772	.3361
21	.3174	.3584	.3155	.2987	.298	.3206	.3174
22	.2987	.3018	.2804	.2987	.2601	.2829	.2801
23	.2427	.2641	.2279	.2614	.2229	.2452	.2614
24	.2229	.2263	.2263	.1928	.2075	.1907	.2263
Max	**.3361**	**.3772**	**.3189**	**.3361**	**.3189**	**.3772**	**.3584**
Min	**.168**	**.1698**	**.181**	**.056**	**.156**	**.1509**	**.168**
Avg	**.2313**	**.2423**	**.2351**	**.2162**	**.2208**	**.2253**	**.2399**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(E) S/DN.[016] BU 4016
Substation No/ Name :- 144106 / 33/11 KV SHIVAJI VIDYAPEETH
Feeder No / Name : 202 / 11 KV VIDYAPEETH NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1692	.2075	.1886	.1551	.2263	.1669	.2075
2	.1509	.2075	.1886	.1372	.2263	.1509	.1886
3	.1572	.2075	.1886	.1372	.2263	.1509	.1886
4	.1715	.2263	.2263	.1669	.2263	.176	.2075
5	.2054	.2263	.2263	.1882	.2427	.1932	.2263
6	.2561	.2427	.2452	.2321	.2614	.2267	.2829
7	.2883	.2987	.2641	.2454	.2614	.2543	.3018
8	.2947	.2987	.2641	.2715	.2987	.2835	.3206
9	.3077	.2987	.2829	.2481	.2987	.2835	.3206
10	.3109	.3174	.2829	.2328	.2801	.2658	.3206
11	.3361	.3206	.2481	.2614	.2629	.3395	.3361
12	.3547	.3206	.2126	.2427	.2658	.3395	.3174
13	.3547	.2829	.2279	.2241	.2481	.3395	.3174
14	.3361	.2641	.2279	.2241	.2534	.3086	.3174
15	.3361	.2641	.2279	.2427	.2427	.3395	.3361
16	.3361	.2641	.2303	.2241	.2279	.3206	.3547
17	.3174	.2641	.218	.2241	.2204	.3206	.3174
18	.2801	.2641	.2058	.2427	.218	.2641	.2614
19	.2801	.2829	.2056	.2427	.2374	.3018	.2614
20	.2614	.2829	.2006	.2427	.2241	.3018	.2614
21	.2614	.2641	.1907	.2427	.2241	.2829	.2614
22	.2427	.2641	.1932	.2427	.2241	.2452	.2614
23	.2427	.2263	.1882	.2427	.1932	.2263	.2427
24	.1738	.2263	.2075	.1738	.2452	.1833	.2075
Max	**.3547**	**.3206**	**.2829**	**.2715**	**.2987**	**.3395**	**.3547**
Min	**.1509**	**.2075**	**.1882**	**.1372**	**.1932**	**.1509**	**.1886**
Avg	**.2677**	**.2634**	**.2226**	**.2203**	**.2431**	**.2610**	**.2758**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(E) S/DN.[016] BU 4016
Substation No/ Name :- 144106 / 33/11 KV SHIVAJI VIDYAPEETH
Feeder No / Name : 203 / Siber SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.3961	.415	.3224	.3584	.3439	.3584
2	.3439	.3772	.3772	.3224	.3547	.3258	.3206
3	.3439	.3772	.3772	.3258	.3584	.3258	.3206
4	.4024	.3772	.3772	.3982	.3772	.3658	.3206
5	.462	.4338	.3772	.4572	.4108	.439	.3395
6	.5415	.5415	.4715	.4938	.5228	.5175	.5281
7	.5788	.5601	.5093	.4938	.5601	.5601	.5281
8	.5975	.5788	.5093	.499	.5788	.5975	.6036
9	.5788	.5601	.547	.5359	.5975	.6161	.6413
10	.5041	.5041	.547	.5041	.5601	.5601	.5658
11	.4668	.5093	.4805	.4854	.5041	.5658	.5228
12	.4668	.4715	.4251	.3734	.4572	.4904	.4854
13	.4108	.415	.3658	.3361	.4207	.4527	.4294
14	.3921	.415	.3109	.3174	.439	.4338	.4294
15	.3921	.3772	.3109	.3547	.439	.415	.4108
16	.4481	.3395	.3109	.2987	.4207	.415	.3921
17	.4668	.3395	.3658	.3734	.3841	.3772	.3921
18	.4668	.3772	.4207	.4294	.439	.4904	.5601
19	.6535	.6036	.5853	.5975	.6468	.6413	.6908
20	.6348	.6602	.5853	.5788	.5973	.679	.6722
21	.5975	.6036	.5792	.5975	.5792	.6224	.6535
22	.5228	.547	.4887	.5415	.4887	.5658	.5415
23	.4294	.4715	.4344	.4294	.4163	.4527	.4668
24	.3801	.415	.415	.3439	.3584	.3439	.415
Max	**.6535**	**.6602**	**.5853**	**.5975**	**.6468**	**.679**	**.6908**
Min	**.3439**	**.3395**	**.3109**	**.2987**	**.3547**	**.3258**	**.3206**
Avg	**.4768**	**.4688**	**.4411**	**.4337**	**.4696**	**.4832**	**.4829**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(E) S/DN.[016] BU 4016
Substation No/ Name :- 144106 / 33/11 KV SHIVAJI VIDYAPEETH
Feeder No / Name : 411 / 33 KV Incomer no I Feeder KV- 33 / INCOMING
NON SHEDDABLE EXPRESS HV FEEDERS (NON-CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8316	.7922	.7922	.7207	.7922	.7762	.7356
2	.7762	.7922	.7356	.7207	.7922	.7133	.679
3	.7207	.7922	.7356	.7207	.7922	.7133	.679
4	.8316	.7922	.7356	.8316	.7922	.7762	.679
5	.9522	.8488	.7922	.8871	.8488	.8871	.7356
6	1.0642	1.0185	.9054	.9522	1.0082	.9979	1.0185
7	1.1203	1.1203	1.0185	1.0082	1.0642	1.0642	1.1317
8	1.1763	1.1203	1.0751	1.0082	1.1763	1.1763	1.3014
9	1.1763	1.1203	1.1317	1.0642	1.1763	1.1763	1.3014
10	1.1203	1.1203	1.1317	1.0082	1.1203	1.0642	1.1883
11	1.0642	1.0751	1.0082	.7842	1.0082	1.1883	1.1203
12	1.0642	1.0185	.8962	.6722	.9522	1.0751	1.0082
13	.9522	.9054	.8402	.7842	.8962	.9619	.9522
14	.8962	.9054	.7842	.7282	.8962	.9054	.8962
15	.8962	.8488	.7842	.7842	.8962	.9054	.8962
16	.9522	.7922	.7282	.6722	.8316	.9054	.8962
17	1.0082	.7922	.8316	.8402	.7842	.8488	.8962
18	.9522	.9054	.8962	.9522	.8962	.9619	1.0642
19	1.2883	1.2449	1.1763	1.1763	1.2323	1.3014	1.2883
20	1.2323	1.3014	1.1643	1.1203	1.2323	1.358	1.2883
21	1.1763	1.2449	1.1643	1.1203	1.1643	1.2449	1.2323
22	1.0642	1.1317	1.0534	1.0642	1.0534	1.0751	1.0642
23	.8962	.9619	.9425	.9619	.8871	.9054	.8488
24	.8316	.8488	.8488	.7762	.7922	.7762	.8488
Max	**1.2883**	**1.3014**	**1.1763**	**1.1763**	**1.2323**	**1.358**	**1.3014**
Min	**.7207**	**.7922**	**.7282**	**.6722**	**.7842**	**.7133**	**.679**
Avg	**1.0018**	**.9789**	**.9238**	**.8899**	**.9619**	**.9899**	**.9896**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(N) S/DN.[019] BU 4019
Substation No/ Name :- 144034 / 33/11 Kv Sugar Mill
Feeder No / Name : 201 / 11KV KASABA BAWADA SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.6335	.6335	.6516	.6516	.6516	.6335
2	.6154	.5973	.5792	.5792	.6154	.5973	.5973
3	.5792	.5792	.5792	.5792	.5792	.5973	.5973
4	.5792	.5792	.5792	.5792		.5973	.5973
5	.724	.6154	.6154	.6878	.6878	.6335	.6516
6	.8688	.905	.7783	.8145	.8688	.8507	
7	1.1765	1.1584	.9412	1.0317	1.086	1.1584	1.2127
8	1.3394	1.2851	1.2489	1.2127	1.3394	1.3756	1.4299
9	1.267	1.1765	1.267	1.2489	1.1765	1.267	1.3213
10	1.0576	1.0679	1.1946	1.1218	1.0317	1.1584	1.1946
11	.9955	1.0498	1.0317	1.0317	1.0136	1.086	1.1041
12	.905	.9955	.9412	.9231	.9231	.9774	.9955
13	.9231	.9593	.905	.7964	.9412	.8507	.9593
14	.8688	.8507	.8326	.7783	.8326	.7783	.8688
15	.7602	.8507	.7602	.7602	.7783	.7964	.7964
16	.7783	.7783	.7602	.7602	.8688	.8145	.7059
17	.9412	.9412	.9231	.8145	1.0136	.9774	.9593
18	1.1765	1.1963	1.267	1.086	1.1765	1.2851	1.1584
19	1.5927	1.5746	1.5927	1.4299	1.6108	1.647	1.5927
20	1.5203	1.5384	1.5203	1.4299	1.5384	1.5565	1.5384
21	1.4299	1.3937	1.3937	1.3756	1.4118	1.4299	1.4118
22	1.3032	1.2308	1.2489	1.2308	1.3213	1.267	1.267
23	.9593	.9412	.9774	.9231	.9774	.9412	.8869
24	.7059	.7059	.724	.724	.6878	.724	.7059
Max	**1.5927**	**1.5746**	**1.5927**	**1.4299**	**1.6108**	**1.647**	**1.5927**
Min	**.5792**	**.5792**	**.5792**	**.5792**	**.5792**	**.5973**	**.5973**
Avg	**.9883**	**.9835**	**.9706**	**.9404**	**1.0057**	**1.0008**	**1.0081**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(N) S/DN.[019] BU 4019
Substation No/ Name :- 144034 / 33/11 Kv Sugar Mill
Feeder No / Name : 202 / 11 KV KOLHAPUR SUGAR MILL SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.3395	.3584	.3018	.3206	.3395	.3018
2	.2641	.3206	.3584	.3018	.3361	.3395	.3018
3	.2801	.3206	.3584	.3018	.3395	.3206	.3018
4	.2614	.3206	.6036	.3206	.3395	.3018	.3206
5	.2801	.3395	.3395	.3206	.3395	.3961	.3206
6	.2801	.3206	.3395	.3206	.3395	.3961	.3206
7	.3206	.3961	.415	.3206	.3361	.415	.3018
8	.2641	.3961	.415	.3395	.3018	.4338	.3772
9	.3206	.3772	.415	.3206	.3584	.415	.415
10	.3772	.4481	.3584	.3584	.3961	.3961	.3961
11	.2452	.415	.3921	.3772	.3395	.4715	.3921
12	.3961	.3772	.3921	.3961	.4108	.4715	.4805
13	.2829	.415	.415	.415	.415	.4338	.3772
14	.2452	.4338	.4108	.1478	.3961	.415	.415
15	.2452	.4294	.3547	.3961	.4338	.415	.4338
16	.4338	.3734	.3921	.3961	.3961	.415	.415
17	.3772	.3772	.2096	.3961	.3961	.3961	.3206
18	.3772	.3772	.2263	.3395	.3734	.3584	.3206
19	.3961	.3584	.2075	.3961	.3921	.3961	.3206
20	.3961	.3395	.2075	.3395	.3772	.3584	.3018
21	.3961	.3772	.1886	.3018	.3547	.3395	.3018
22	.3206	.3206	.1698	.2829	.3395	.3395	.3395
23	.3584	.3584	.3584	.3018	.3174	.3206	.3142
24	.2452	.3395	.3584	.3206	.3018	.3584	.3206
Max	**.4338**	**.4481**	**.6036**	**.415**	**.4338**	**.4715**	**.4805**
Min	**.2452**	**.3206**	**.1698**	**.1478**	**.3018**	**.3018**	**.3018**
Avg	**.3178**	**.3696**	**.3435**	**.3339**	**.3604**	**.3851**	**.3504**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(N) S/DN.[019] BU 4019
Substation No/ Name :- 144034 / 33/11 Kv Sugar Mill
Feeder No / Name : 203 / 11KV ULAPEMALA SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0914	.0914	.0732	.0914	.0914	.0914
2	.0732	.0914	.0914	.0732	.0914	.0914	.0914
3	.0732	.0732	.0914	.0732	.0914	.0732	.0914
4	.0914	.0732	.0914	.0732	.0732	.0732	.0914
5	.0914	.0914	.0914	.0732	.0732	.0914	.0914
6	.0914	.1097	.0914	.0914	.0914	.0914	.0914
7	.0914	.0914	.0914	.0732	.0914	.0914	.1097
8	.0914	.0914	.0914	.0732	.0914	.0914	.128
9	.0914	.0914	.0914	.0914	.0914	.1097	.1463
10	.0914	.0914	.0914	.0914	.0914	.0914	.128
11	.0943	.1097	.0914	.0732	.0914	.1097	.128
12	.1097	.0732	.0732	.0732	.1097	.1097	.1097
13	.0914	.0732	.0914	.0943	.0914	.128	.1097
14	.0914	.0732	.0914	.0732	.0914	.1097	.0914
15	.0914	.0914	.0914	.0732	.0914	.128	.1097
16	.0914	.0914	.0914	.0732	.0914	.1097	.1097
17	.0914	.0914	.0914	.0914	.0914	.128	.1097
18	.0914	.0914	.1097	.0914	.1097	.1097	.1097
19	.128	.128	.1097	.1097	.128	.128	.1463
20	.1097	.1097	.128	.128	.128	.1463	.128
21	.1097	.1097	.128	.1097	.128	.1463	.128
22	.1097	.1097	.1097	.1097	.1097	.128	.128
23	.0914	.0914	.0914	.0914	.1097	.1097	.0914
24	.0914	.0914	.0914	.0914	.0914	.0914	.1097
Max	**.128**	**.128**	**.128**	**.128**	**.128**	**.1463**	**.1463**
Min	**.0732**	**.0732**	**.0732**	**.0732**	**.0732**	**.0732**	**.0914**
Avg	**.0946**	**.0929**	**.0960**	**.0862**	**.0975**	**.1074**	**.1112**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(N) S/DN.[019] BU 4019
Substation No/ Name :- 144034 / 33/11 Kv Sugar Mill
Feeder No / Name : 204 / 11 KV WADANAGE GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.2587	.2587	.2587	.2587	.2587	.2587
2	.2218	.2402	.2402	.2402	.2587	.2402	.2402
3	.2218	.2402	.2402	.2402	.2587	.2402	.2402
4	.2402	.2402	.2402	.2402	.2587	.2587	.2402
5	.3696	.3142	.2772	.3142	.3696	.2957	.2957
6	.5359	.5175	.4805		.5544	.5175	.5359
7	.6838	.6838	.5914	.6653	.6838	.6653	.7207
8	.6653	.6838	.6838	.6653	.7023	.7023	.6838
9	.6653	.5729	.6653	.6838	.6838	.6283	.6283
10	.5359	.5175	.6283	.6099	.6283	.5729	.5359
11	.5175	.5914	.499	.5359	.5729	.5359	.5729
12	.499	.5359	.5729		.5914	.4805	.462
13	.462	.462	.4805	.4066	.5175	.462	.462
14	.4435	.4435	.4435	.1478	.462	.462	.4251
15	.4066	.4251	.4066	.4066	.4805	.3696	.4066
16	.4435	.4805	.462	.0185	.5175	.462	.4066
17	.5175	.499	.5359	.4251	.499	.499	.499
18	.5359	.5359	.5914	.5544	.6653	.6099	.5359
19	.7762	.8316	.7947	.7762	.8131	.8316	.7947
20	.7762	.7947	.7577	.7762	.7947	.7947	.7577
21	.7207	.7577	.7392	.7207	.7392	.7207	.7023
22	.6099	.5729	.6099	.5544	.5914	.5914	.5729
23	.4066	.3881	.4066	.3881	.3881	.3881	.3696
24	.2587	.2957	.3142	.2957	.2772	.2772	.2772
Max	**.7762**	**.8316**	**.7947**	**.7762**	**.8131**	**.8316**	**.7947**
Min	**.2218**	**.2402**	**.2402**	**.0185**	**.2587**	**.2402**	**.2402**
Avg	**.4890**	**.4951**	**.4967**	**.4511**	**.5236**	**.4944**	**.4843**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(N) S/DN.[019] BU 4019
Substation No/ Name :- 144034 / 33/11 Kv Sugar Mill
Feeder No / Name : 205 / 11 KV Sarwal AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.052	.0693	.052
2					.052	.052	.052
3					.052	.052	.052
4					.0347	.052	.052
5					.0347	.052	.052
6					.0347	.052	.052
7					.052	.0693	.104
8	.2427	.3121	.2774				.1907
9	.3467	.3988	.3814				.2774
10	.3988	.4334	.3641				.3121
11	.3641	.4334	.4161				.3641
12	.3988	.3641	.3988				.3988
13	.4161	.3814	.4161				.4508
14	.3814	.3467	.3121				.3988
15	.3641	.2774	.2947				.3988
22				.104	.0867	.052	
23				.104	.0867	.052	
24					.0693	.0693	.052
Max	**.4161**	**.4334**	**.4161**	**.104**	**.0867**	**.0693**	**.4508**
Min	**.2427**	**.2774**	**.2774**	**.104**	**.0347**	**.052**	**.052**
Avg	**.3641**	**.3684**	**.3576**	**.104**	**.0555**	**.0572**	**.2037**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(N) S/DN.[019] BU 4019
Substation No/ Name :- 144035 / 33/11KV NAGALA S/S
Feeder No / Name : 202 / 11KV FILTER HOUSE FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5228	.4904	.5041	.5041	.5228	.5228	.4854
2			.4854	.6722	.5228	.4854	.4481
3				.4481	.5228	.4755	.4481
4					.5041	.5175	.4854
5					.5228	.5228	.5041
6	.6161	.6161	.5847		.5228	.5975	.5975
7	.8029		.6722	.679	.8029	.9335	.8402
8	1.0082	.9808	.9149	.8775	.9795	.9979	1.0829
9	1.0642	1.0751	1.0269	1.0642	1.1088	1.0829	1.0642
10	1.0269	1.0456	1.0642	1.1317		1.0642	1.0269
11		1.0082	1.0829	.9709	1.1203	1.0642	.9795
12	1.0269	.9709	.9896	.9335	1.0082	.9709	.9328
13	.9522	.8589	.9335	.8775	.8962	.8775	.8501
14		.8029	.8775	.7655	.7655	.7842	.8501
15			.6908	.7655		.7655	
16	.7468	.7282	.7095	.7842	.7282	.7282	.6653
17	.7392	.7059	.7468	.7468		.7655	.6908
18	.8501	.8779	.8402	.7762	.924	.8029	.8029
19	.924	1.0082	.9709	.9522	.9795	1.0374	
20	.9979	.9709		.9709	.9522		.9149
21	.9335	.9522	.9149	.9335	.924	.9335	.9242
22	.8775	.8962	.8775	.8215	.8589	.8402	.8589
23	.7356		.7282	.6722		.6908	
24	.5601	.5601	.5975	.5601	.5601	.5544	.5601
Max	**1.0642**	**1.0751**	**1.0829**	**1.1317**	**1.1203**	**1.0829**	**1.0829**
Min	**.5228**	**.4904**	**.4854**	**.4481**	**.5041**	**.4755**	**.4481**
Avg	**.8462**	**.8558**	**.8106**	**.8051**	**.7863**	**.7833**	**.7625**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(N) S/DN.[019] BU 4019
Substation No/ Name :- 144035 / 33/11KV NAGALA S/S
Feeder No / Name : 203 / 11KV AKASHWANI FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.4854	.4668	.4854	.5601	.4854	.5228
2			.4668	.6535	.5228	.4668	.5228
3				.4435	.5228	.4854	.4854
4					.5228	.4854	.4854
5					.5228	.4904	.5041
6	.6161	.5658	.5601		.5788	.5601	.5975
7	.811	.7655	.7282	.6722	.8029	.8962	.8589
8	.9522	.9149	.8402	.8215	.8775	.9709	.9522
9	.9896	.9709	.8589	.8501	.961	.9896	1.0349
10	1.0269	.9709	.8962	.9709		1.0082	1.0456
11	.9335	.9149	.8589	.7095	.9709	.9522	1.0374
12	.9149	.8215	.7468	.8589	.8775	.9149	.9149
13	.8589	.7842	.6535	.7655	.8402	.8402	.8775
14		.7095	.6535	.6722	.7468	.7842	.811
15			.6348	.6161		.7282	
16	.7655	.6908	.6161	.6535	.7842	.7468	.7468
17	.7762	.6722	.6535	.6535		.7095	.7655
18	.8501	.7842	.6908	.7468	.8589	.7842	.7655
19	.9335	.9795	.9522	.9522	.9979	.9896	
20	.9795	.9335		.8962	.8871		.9896
21	.9425	.8871	.8589	.8686		.8962	.9242
22	.8775	.8402	.8215	.8402		.7842	.8676
23	.7282		.7282	.6908		.6535	
24	.5601	.5601	.5975	.5601	.5788	.5601	.5228
Max	**1.0269**	**.9795**	**.9522**	**.9709**	**.9979**	**1.0082**	**1.0456**
Min	**.4904**	**.4854**	**.4668**	**.4435**	**.5228**	**.4668**	**.4854**
Avg	**.8337**	**.7917**	**.7142**	**.7324**	**.7452**	**.7471**	**.7730**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(N) S/DN.[019] BU 4019
Substation No/ Name :- 144035 / 33/11KV NAGALA S/S
Feeder No / Name : 205 / 11KV LAXMIPURI SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.5847	.5788	.6161	.6535	.6161	.6348
2			.5415	.5601	.5601	.5853	.5975
3				.5228	.5601	.5788	.5975
4					.5975	.5788	.5975
5					.5975	.5788	.6161
6	.6161	.6535	.6413		.6535	.6535	.6722
7	.7468	.8402	.6979	.7545	.8029	.8775	.7655
8	.9335	.8589	.811	.811	.8775		.8962
9	.8962	.8962	.8962	.8775	.9979	.9709	.9709
10	1.1016	1.0269	.9149	1.0082	1.1389	1.1389	1.1389
11	1.1203	1.1389	1.0456	1.1576		1.307	1.2382
12	1.2136	1.251	.9896	1.1016	1.2136	1.2136	1.2197
13	1.1389	1.1203	.9335	1.0642	1.2136	1.1763	1.1157
14		.9896	.8589	.9896	1.0642	1.0642	1.0534
15			.8589	.8775		1.0456	
16	1.0456	.9522	.8589	.8775	1.1016	1.0829	1.0082
17	1.2136	.9877	.9335	.9425		1.1763	1.0269
18		1.1706	.9522	1.0349	1.6057	1.2071	1.2323
19	1.2936	1.4045	1.2323	1.386	1.5893	1.4937	
20	1.262	1.2696		1.2752	1.251		1.358
21	1.0829	1.1763	1.0829	1.1088		1.1389	1.094
22	1.0082	.9896	.9896	.8215		.9335	1.0082
23	.8589		.8589	.8131		.7842	
24	.6348	.6722	.679	.6722	.6908	.6908	.6722
Max	**1.2936**	**1.4045**	**1.2323**	**1.386**	**1.6057**	**1.4937**	**1.358**
Min	**.5601**	**.5847**	**.5415**	**.5228**	**.5601**	**.5788**	**.5975**
Avg	**.9839**	**.9991**	**.8678**	**.9177**	**.9538**	**.9497**	**.9292**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(N) S/DN.[019] BU 4019
Substation No/ Name :- 144035 / 33/11KV NAGALA S/S
Feeder No / Name : 206 / 11KV USHA TALKIES FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6722	.6535	.7095		.4854	.4481	.4294
2			.6535		.4668	.4338	.4108
3				.0934	.4668	.4108	.4108
4					.4668	.4481	.4481
5					.4854	.4481	.4854
6	.7095	.7468	.7545		.4668	.4668	.4854
7	.7842	.7842	.7167	.0943	.5601	.5175	.5415
8	.8962	.9054	.9242	.1307	.6348	.5544	.5975
9	.9808	.9335	.9054	.1494	.6908	.6535	.6348
10	1.1203	1.0082	.9149	.2054		.7468	.7356
11	1.1576	1.1203	1.0082	.8402	.7468	.7655	.7733
12	1.2323	1.1576	.9896	.8589	.7655	.7468	.7356
13	1.1949	1.1016	.9522	.8029	.7655	.7655	.7167
14		1.0082	.9335	.7842	.7655	.7095	.7167
15			.9149	.7468		.7468	
16	1.1576	.9896	.8402	.7282	.7282	.7468	.7356
17	1.1203	1.0374	.8402	.6653		.7167	.6722
18	1.1273	1.0829	.9149	.7095	.8029	.7468	.7655
19	1.1088	1.2136	1.0829	.7842	.8871	.8589	
20	1.0903	1.1016		.7356	.7468		.7468
21	1.0185	.9896	.9896	.6838		.6722	.6535
22	1.0082	.9522	.9808	.6368		.6722	.6161
23	.8589		.8775	.5975		.5975	
24	.7655	.7468	.7655	.7282	.5041	.4854	.5228
Max	**1.2323**	**1.2136**	**1.0829**	**.8589**	**.8871**	**.8589**	**.7733**
Min	**.6722**	**.6535**	**.6535**	**.0934**	**.4668**	**.4108**	**.4108**
Avg	**1.0002**	**.9741**	**.8834**	**.5776**	**.6353**	**.6243**	**.6111**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(N) S/DN.[019] BU 4019
Substation No/ Name :- 144035 / 33/11KV NAGALA S/S
Feeder No / Name : 208 / 11KV BLOOD BANK FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4294	.4481	.4294	.4481	.4481	.4481	.4294
2			.4108	.4481	.4294	.4294	.4294
3				.4435	.4294	.4294	.4481
4					.4294	.4294	.4481
5					.4294	.4294	.4518
6	.4338	.4668	.4904		.4668	.4854	.4668
7	.5041	.4715	.4904	.5228	.5228		.5041
8	.5601	.5658	.5601	.5601	.5788	.5975	.5975
9	.6348	.5788	.5601	.6161	.6535	.5975	.6722
10	.6697	.6535	.5975	.6161		.6908	.7468
11	.6908	.6722	.5975	.6535	.7095	.7095	.7282
12	.7095	.6535	.6161	.5975	.7282	.7282	.7023
13	.7282	.6535	.503	.6535	.7468	.7282	.6838
14		.6348	.5415		.7282	.6908	.6908
15			.5415	.6348		.7095	
16	.7282	.6348	.5228	.6161	.7655	.7282	.7133
17	.7392	.6468	.5601	.6161		.7468	.7167
18	.7762	.7468	.6161	.6838	.8215	.7655	.7468
19	.7842	.7842	.7655	.7468	.8871	.8962	
20	.8029	.7842		.7762	.8029		.8299
21	.7095	.7095	.6908	.7023		.7282	.7095
22	.6224	.6161	.6161			.6161	.6161
23	.5601		.5415	.5415		.5601	
24	.4668	.4904	.4854	.4668	.5041	.4481	.4854
Max	**.8029**	**.7842**	**.7655**	**.7762**	**.8871**	**.8962**	**.8299**
Min	**.4294**	**.4481**	**.4108**	**.4435**	**.4294**	**.4294**	**.4294**
Avg	**.6417**	**.6229**	**.5568**	**.5970**	**.6156**	**.6178**	**.6103**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(N) S/DN.[019] BU 4019
Substation No/ Name :- 144035 / 33/11KV NAGALA S/S
Feeder No / Name : 411 / 33 KV Nagala Park Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS (NON-CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.5082	3.5288	3.5288	2.8858	3.4568	3.3608	3.3048
2				3.0556	3.3048	3.1927	3.1927
3				2.6886	3.3048	3.1367	3.1927
4					3.3048	3.2487	3.1927
5					3.3608	3.2487	2.9321
6	3.9769	3.9209	3.9043		3.6408	3.5482	3.7146
7	4.6965	4.6491	4.1872	3.7912	4.3896	4.4445	4.3896
8	5.4893	5.2652	6.2809	4.257	4.9383	5.1532	5.2126
9	5.7693	5.5453	5.5453	4.7531	5.5967	5.4893	5.4321
10	6.4415	6.0494	5.7133	5.2092	6.1614	6.2174	5.3778
11	6.6655	6.3295	6.0494	5.9374		6.5535	6.4312
12	7.0016	6.3855	5.8253	5.9934	6.4415	6.4975	6.2649
13	6.8336	6.1054	5.4332	5.8253	6.3855	6.2734	5.9877
14		5.5453	5.3772	5.4321	5.8253	5.7693	5.7105
15			5.0972	5.0972		5.6013	
16	6.1614	5.3212	5.0412	5.1532	5.7693	5.7133	5.3778
17	6.31	5.3224	5.3212	5.1029	4.8171	5.8848	5.5453
18	6.9685	6.2649	5.8253	5.7105	7.0782	6.5638	6.3295
19	7.1331	7.2628	7.2257	7.0965	7.6269	7.6178	
20		6.8193		6.749	6.6392		7.1296
21	6.2552	6.1454	6.3295	5.9322		6.0494	5.9934
22	5.8282	5.6573	5.7133	5.2115		5.0972	5.3189
23	4.8731		4.9291	4.3799		4.369	
24	3.9769	4.0175	4.0175	3.9209	3.7146	3.6037	3.6408
Max	**7.1331**	**7.2628**	**7.2257**	**7.0965**	**7.6269**	**7.6178**	**7.1296**
Min	**3.5082**	**3.5288**	**3.5288**	**2.6886**	**3.3048**	**3.1367**	**2.9321**
Avg	**5.7582**	**5.5631**	**5.3339**	**4.9611**	**5.0398**	**5.0711**	**4.9367**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(N) S/DN.[019] BU 4019
Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S
Feeder No / Name : 201 / 11KV S.T. STAND FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5906	.6478	.6979	.9145	.9808	
2		.5847	.6097	.6535	.8383	.9709	.816
3		.5975	.5716	.6535	.8002	.9431	.7978
4		.6036	.5716	.5975	.8002	.9431	.778
5		.5788	.6097	.6602	.8192	.9522	.797
6		.6908	.6287	.811	.9145	.9522	.9488
7		.7655	.724	.9522	1.1241	.9522	1.1006
8		.8501	.8764	1.0719	1.2574	1.1506	1.3473
9	.9522	.9431	.9717	1.1389	1.426	1.226	1.4976
10	1.0082	1.0374	.9709	1.251	1.4028	1.3256	1.475
11	.9979	1.0642	1.0269	1.3817	1.531	1.5123	1.531
12	1.0269	1.1016		1.3817	1.5708	1.4377	1.531
13	1.0082	.9896	.9335	1.2197	1.531	1.4003	1.4377
14	1.0642	1.0642	.9522	1.2883	1.4045	1.4003	1.3817
15	1.0456	1.0456	.9335	1.3256	1.4377	1.3817	1.4146
16	1.0269	.9896	.9522	1.251	1.5466	1.3443	1.419
17	1.0185	1.0973	.9619	1.3203	1.4563	1.4422	1.3817
18	1.1576	1.3028	1.1883	1.5482	1.5655	1.6888	1.5684
19	1.3203	1.3825	1.3527	1.7594	1.8484	1.8009	1.7353
20	1.2826	1.3256	1.2826	1.7233	1.6975	1.515	1.6787
21	1.2071	1.2891	1.2826	1.7078	1.5655	1.5702	1.6032
22	1.094	1.1765	1.1694	1.575	1.3817	1.4801	1.4523
23	.8865	.9678	.9709	1.2524	1.1694	1.2145	1.1763
24	.6722	.6287	.743	.7356		1.0098	1.0437
Max	**1.3203**	**1.3825**	**1.3527**	**1.7594**	**1.8484**	**1.8009**	**1.7353**
Min	**.6722**	**.5788**	**.5716**	**.5975**	**.8002**	**.9431**	**.778**
Avg	**1.0481**	**.9445**	**.9101**	**1.1649**	**1.3045**	**1.2748**	**1.3006**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(N) S/DN.[019] BU 4019
Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S
Feeder No / Name : 202 / 11 KV LINE BAZAR FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.2587	.2795	.2561	.2427	.2561	.239
2	.2614	.2402	.2422	.2402	.2427	.2587	.2393
3	.2614	.2402	.2422	.2402	.2427	.2378	.239
4	.2427	.3077	.242	.2587	.2427	.2402	.2195
5	.2801	.3292	.2422	.2957	.2614	.3326	.2398
6	.3547	.3881	.2818	.2926	.3174	.3511	.332
7	.4668	.4251	.3381	.3142	.3734	.3881	.4481
8	.4668	.439	.4508	.3696	.5041	.462	.5041
9	.5041	.462	.4286	.3801	.4845	.4805	.5426
10	.4066	.3841	.3921	.4251	.4658	.4207	.4572
11	.3511	.3511	.3734	.3696	.4207	.4251	.4024
12	.3511	.3361		.3142	.4066	.3881	.3696
13	.3696	.3174	.2801	.2957	.3841	.3881	.3881
14	.3174	.2957	.3174	.2587	.3475	.4207	.3511
15	.3326	.2772	.2614	.2743	.3475	.3475	.3326
16	.2801	.2218	.2614	.2587	.3174	.3326	.3109
17	.2926	.2942		.2494	.2926	.3555	.2926
18	.3881	.4049	.3109	.3574	.3841	.4412	.3881
19	.5487	.5337	.5175	.4646	.5121	.5337	.5359
20	.5175	.5143	.4805	.4861	.5487	.5464	.5175
21	.4755	.478	.462	.4795	.4938	.5132	.4805
22	.4572	.4606	.4572	.4242	.4481	.4553	.4435
23	.3326	.3515	.3658	.332	.3658	.3643	.3475
24	.2801	.2561	.2763	.2743	.2582	.2743	.2761
Max	**.5487**	**.5337**	**.5175**	**.4861**	**.5487**	**.5464**	**.5426**
Min	**.2427**	**.2218**	**.242**	**.2402**	**.2427**	**.2378**	**.2195**
Avg	**.3665**	**.3570**	**.3411**	**.3296**	**.3710**	**.3839**	**.3707**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(N) S/DN.[019] BU 4019
Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S
Feeder No / Name : 203 / 11 KV EXCISE FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0456	1.0374	1.0437	.9997	1.0098	1.0562	.9469
2	1.0059	1.0479	.9488	.9522	.9907	1.0374	.9108
3	1.0269	1.0185	.9526	.9431	.9907	.9907	.8901
4	1.0082	1.0374	.9526	.9526	.9526	.9709	.8919
5	1.0269	1.1016	1.0288	1.0288	.9907	1.1128	.9108
6	1.251	1.2003	1.086	1.0829	1.1622	1.2003	1.1575
7	1.3443	1.2765	1.2384	1.1883	1.2955	1.2955	1.2524
8	1.6057	1.5623	1.4861	1.419	1.5242	1.5089	1.4771
9	1.6617	1.6057	1.6575	1.5278	1.7268	1.6617	1.515
10	1.6409	1.6221	1.6617	1.587	1.7268	1.5655	1.4523
11	1.587	1.587	1.5684	1.6244	1.6057	1.6221	1.3769
12	1.5655	1.5844		1.6057	1.643	1.6409	1.3817
13	1.475	1.5123	1.1763	1.4377	1.5089	1.5497	1.3256
14	1.3256	1.423	1.5497	1.363	1.4901	1.4937	1.1949
15	1.4377	1.3256	1.307	1.2883	1.363	1.4003	1.2637
16	1.3443	1.3256	1.2136	1.251	1.3203	1.3443	1.251
17	1.3203	1.3957		1.2535	1.3769	1.4553	1.2826
18	1.4712	1.6048	1.1506	1.5154	1.4523	1.6855	1.5844
19	1.7918	1.8881	1.6804	1.8861	1.7918	1.9316	1.8861
20	1.8111	1.7353	1.6975	1.7559	1.8484	1.9108	1.8298
21	1.7353	1.7181	1.6057	1.7181	1.7164	1.7955	1.7353
22	1.5655	1.5876	1.587	1.5876	1.6032	1.512	1.5466
23	1.3203	1.3446	1.3817	1.4742	1.3392	1.2878	1.3014
24	1.0642	1.0669	1.1397	1.0479	1.105	1.0751	1.0416
Max	**1.8111**	**1.8881**	**1.6975**	**1.8861**	**1.8484**	**1.9316**	**1.8861**
Min	**1.0059**	**1.0185**	**.9488**	**.9431**	**.9526**	**.9709**	**.8901**
Avg	**1.3930**	**1.4004**	**1.3234**	**1.3538**	**1.3973**	**1.4210**	**1.3086**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(N) S/DN.[019] BU 4019
Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S
Feeder No / Name : 204 / 11KV SHAHU COLLEGE FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4938	.5093	.4954	.5228	.5144	.5658	.5313
2	.5041	.4854	.4572	.499	.5144	.5281	.4545
3	.4854	.4854	.4382	.4854	.4954	.4904	.4356
4	.4668	.4904	.4382	.4904	.4954	.4854	.4166
5	.5228	.6161	.4763	.6161	.5335	.5359	.4356
6	.7468	.7167	.5144	.6602	.5906	.6099	.5693
7	.8402	.811	.6859	.6908	.7049	.7095	.797
8	1.0269	.8962	.8954	.9054	.8764	.8871	.8901
9	1.0082	.9619	.9279	1.0185	.8522	.8865	.9658
10	.8775	.9522	.9335	.9149	.9279	.9054	.8775
11	.8316	.8215	.8029	.7947	.8131	.8402	.7468
12	.7842	.8029		.7655	.7392	.7762	.7468
13	.7095	.7282	.7282	.7023	.6908	.6535	
14	.5975	.6767	.6535	.6468	.6468	.6283	.6161
15	.5601	.5975	.6161	.7133	.567	.6348	.547
16	.5975	.5914	.5601	.5544	.695	.567	.5415
17	.6224	.6602		.5956	.6283	.6249	.5228
18	.7922	.8488	.6161	.7647	.7842	.8333	.811
19	.9997	.9997	.9242	.9233	.9808	.9668	.9709
20	.9431	.945	.9242	.8989	.9619	.9469	.9619
21	.9054	.9063	.8962	.9044	.8962		.9431
22	.8775	.8324	.8488	.8479	.8488	.8694	.8589
23	.6979	.6628	.7545	.7196	.679	.6642	.7167
24	.5228	.5281	.5503	.547	.5525	.5847	.5871
Max	**1.0269**	**.9997**	**.9335**	**1.0185**	**.9808**	**.9668**	**.9709**
Min	**.4668**	**.4854**	**.4382**	**.4854**	**.4954**	**.4854**	**.4166**
Avg	**.7256**	**.7303**	**.6881**	**.7159**	**.7079**	**.7041**	**.6932**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(N) S/DN.[019] BU 4019
Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S
Feeder No / Name : 205 / RAW WATER WORKS SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.2743	.3881	.2957	.3881	.2926	.3961
2	.3734	.2772	.3881	.2743	.3913	.2957	.3969
3	.3361	.2534	.3881	.2561	.3901	.2614	.3977
4	.3734	.2561	.3881	.2587	.3901	.2614	.3969
5	.3547	.3142	.3881	.2772	.4045	.2772	.3973
6	.3734	.2957	.4066	.2896	.4074	.2926	.3969
7	.3734	.3292	.3881	.3142	.4259	.2957	.3969
8	.3921	.2926	.3881	.3142	.4082	.3258	.4162
9	.4481	.3292	.4066	.3142	.463	.3511	.4338
10	.4481	.3475	.3921	.4251	.4644	.3881	.3475
11	.5304	.4207	.3921	.2772	.5304	.5121	.3841
12	.4294	.4066		.4024	.4938	.4938	.3921
13	.4251	.4066	.4108	.3841	.4938	.499	.3841
14	.4805		.3921	.2957	.3801	.3696	.462
15	.4805	.4066	.3921	.362	.4805	.4938	.3734
16	.5175	.3982	.4108	.3841	.4755	.462	.462
17	.4066	.4049		.3901	.415	.483	.4481
18	.3658	.4045	.2926	.3893	.3475	.4454	.3475
19	.3511	.4229	.3109	.4458	.3475	.4658	.3658
20	.3326	.4049	.3326	.4277	.3475	.4406	.3475
21	.2614	.4053	.3142	.2387	.2561	.3294	.3292
22	.1267	.1507	.168	.1486	.1294	.1194	.3109
23	.3142	.3861	.3109	.4074	.3109	.3841	.3109
24	.3734	.2926	.3857	.3109	.3881	.3109	.3841
Max	**.5304**	**.4229**	**.4108**	**.4458**	**.5304**	**.5121**	**.462**
Min	**.1267**	**.1507**	**.168**	**.1486**	**.1294**	**.1194**	**.3109**
Avg	**.3851**	**.3426**	**.3652**	**.3285**	**.3970**	**.3688**	**.3866**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(N) S/DN.[019] BU 4019
Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S
Feeder No / Name : 206 / APPLE HOSPITAL. **NON SHEDDABLE EXPRESS HV FEEDERS**
Feeder KV- 11 / OUTGOING **(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0532	.0568		.0549	.0739	.0739
2	.0747	.0532	.0568	.0554	.0554	.0739	.0554
3	.056	.0537	.0566	.0549	.0554	.0739	.0554
4	.0549	.0543	.0566	.0554	.0554	.0549	.0554
5	.056	.0549	.0566	.0739	.0739	.0554	.0554
6	.0747	.0732	.0754	.0554	.0745	.0739	.0554
7	.0934	.0732	.0754	.0732		.0732	.0739
8	.0934	.0732	.0943	.0914	.0745	.0934	.1109
9	.112	.0732	.0754	.0739	.1299	.0739	.0739
10	.1294	.0739	.0747	.0924	.1109	.0914	.0914
11	.1448	.0914	.0747	.0739	.0914	.1463	.128
12	.1109	.0924		.0914		.0732	.0732
13	.1109	.1109	.0934	.1097	.1097	.0914	
14	.0924	.0905	.0747	.0914	.0924	.1086	.128
15	.1109	.1097	.0747	.128	.0914	.0914	.0924
16	.1109	.0924	.056	.128	.0914	.0924	.0924
17	.1097	.1136		.1089	.0934	.0749	.0739
18	.0739	.0945	.0543	.0911	.0924	.0739	.0739
19	.0732	.0945	.0739	.0919	.0739	.0739	.0739
20	.0732	.0945	.0732	.0932	.0924	.0745	.0732
21	.0905	.0758	.0549	.0929	.0739	.0739	.0554
22	.0549	.0758	.0549	.0941	.0732	.0745	.0739
23	.0724	.0759	.0549	.0747	.0554	.0739	.0739
24	.0747	.0532	.0727	.0549	.0739	.0739	.0739
Max	**.1448**	**.1136**	**.0943**	**.128**	**.1299**	**.1463**	**.128**
Min	**.0549**	**.0532**	**.0543**	**.0549**	**.0549**	**.0549**	**.0554**
Avg	**.0884**	**.0792**	**.0678**	**.0848**	**.0813**	**.0806**	**.0777**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(N) S/DN.[019] BU 4019
Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S
Feeder No / Name : 207 / 11 KV STP Express Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS (NON-CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.1086			.2427		.2772	
8		.2241			.255	.2402	
9		.2402	.0554				
11		.1463					.2926
12		.1478		.2561			.2926
13	.0924		.2054		.0549		
14			.2075				.2957
15			.1307	.1463	.2561		.2427
16		.1829		.0732	.2561		.2561
17	.0924	.1668		.0746		.2368	.2402
18		.1675				.239	
19		.1491	.2195	.2593			
20		.0742	.2241		.2587		.2402
21		.1675		.2609			.2402
22		.1839					.2402
23		.0559					
Max	**.1086**	**.2402**	**.2241**	**.2609**	**.2587**	**.2772**	**.2957**
Min	**.0924**	**.0559**	**.0554**	**.0732**	**.0549**	**.2368**	**.2402**
Avg	**.0978**	**.1589**	**.1738**	**.1876**	**.2162**	**.2483**	**.2601**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(W) S/DN.[018] BU 4018
Substation No/ Name :- 144032 / 33/11KV PUIKHADI SUBSTATION
Feeder No / Name : 202 / 11KV RANKALA SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7316	.7316	.7059	.7468	.7545	.8131	.7842
2	.7316	.7392	.7059	.7282	.7167	.7762	.7842
3	.7316	.7392		.7282	.7167	.7762	.7468
4	.7682	.7316	.7316	.7468	.7167	.7762	.7468
5	.8779	.8131	.7602	.7842	.8871	.8501	.7842
6	.9145	.961	.8596	.8676	.8871	.9145	.8686
7	1.1157	1.1203	.9593	1.0269	1.1128	.9774	1.0456
8	1.2986	1.1949	1.1949	1.2323	1.2637	1.267	1.307
9	1.1888	1.1203	1.1949	1.2136	1.2637	1.267	1.2323
10	1.1458	1.1389	1.1643	1.1706	1.2012	1.1765	1.1827
11	1.0974	1.0082	1.1088	.9877	1.0164	.9231	.9511
12	.9313	.9709	.9955	.8869	.9231	.9412	.9412
13	.9313	.9335	.9412	.8316	.9412		.788
14	.8507	.8686	.8413	.7602	.9145	.8145	.7316
15	.9145	.8501	.8779		.8779	.8145	.8131
16	.8059	.7947	.8688	.8145	.788	.7602	.724
17	.8238	.8316	.8954	.8688	.8417	.7783	.788
18	1.0631	1.1462	1.0631	.9955	1.0808	1.0387	1.0974
19	1.5203	1.5043	1.5565	1.4969	1.5729	1.5927	1.5912
20	1.5203	1.4327	1.5203	1.4842	1.5546	1.5565	1.5546
21	1.3756	1.4327	1.4632	1.448	1.4998	1.4661	1.4901
22	1.3032	1.2178	1.2986	1.3213	1.3535	1.3575	1.2986
23	1.0136	.9313	1.0974	.8326	1.0059	1.086	.8779
24	.7865	.7964	.788	.8048	.7783	.8413	.7783
Max	**1.5203**	**1.5043**	**1.5565**	**1.4969**	**1.5729**	**1.5927**	**1.5912**
Min	**.7316**	**.7316**	**.7059**	**.7282**	**.7167**	**.7602**	**.724**
Avg	**1.0184**	**1.0004**	**1.0258**	**.9904**	**1.0279**	**1.0246**	**.9961**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(W) S/DN.[018] BU 4018
Substation No/ Name :- 144032 / 33/11KV PUIKHADI SUBSTATION
Feeder No / Name : 203 / 11KV MAHALAXMI SANEGURUJI SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5373	.5853	.5729	.5373	.5373	.5792	.591
2	.5014	.5853	.5729	.5014	.5014	.5792	.5373
3	.5014	.5853	.5914	.5014	.5014	.5792	.5373
4	.5014	.6154	.6161	.5373	.5373	.5792	.5731
5	.5731	.6626	.6908	.5373	.6089	.6335	.591
6	.6626	.7701	.7207	.6089	.7059	.6984	.6805
7	.8238	.9149	.7655	.6805	.8417	.7701	.8059
8	.8954	.9149	.905	.8238	.8954	.9492	.9313
9	.9671	.9313	.9774	.9313	.8954	.9313	
10	.8238	.8596	.8238	.8954	.7701	.8775	.8596
11	.7164	.7701	.8059	.7522	.7522	.7522	.724
12	.6447	.7701	.7545	.6447	.6447	.6984	.6626
13	.6447	.6805	.6626	.6089	.6268	.6268	.6516
14	.6089	.6268	.6089	.591	.6089	.591	.5792
15	.6089	.6089	.6089		.6089	.5552	.543
16	.5373	.5373	.6089	.5373	.5552	.5194	.5373
17	.6089	.6268	.6268	.6805	.6268	.6089	.5611
18	.8413	.7712	.7964	.7164	.7522	.7522	.9313
19	1.2357	1.2308	1.1999	1.1283	1.2357	1.1999	1.2178
20	1.2127	1.2254	1.182	1.182	1.1999	1.1999	1.2178
21	1.1765	1.1462	1.1104	1.1283	1.1104	1.1641	1.1641
22	1.086	1.0679	1.0566	1.1462	1.0745	1.0745	1.0566
23	.8596	.8048	.788	.6805	.7522	.8954	.6805
24	.5731	.6268	.6268	.5731	.6413	.6268	.591
Max	**1.2357**	**1.2308**	**1.1999**	**1.182**	**1.2357**	**1.1999**	**1.2178**
Min	**.5014**	**.5373**	**.5729**	**.5014**	**.5014**	**.5194**	**.5373**
Avg	**.7559**	**.7883**	**.7780**	**.7358**	**.7494**	**.7684**	**.7489**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(W) S/DN.[018] BU 4018
Substation No/ Name :- 144032 / 33/11KV PUIKHADI SUBSTATION
Feeder No / Name : 205 / PUIKHADI WATER WORKS NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.5093	.4904	.4904	.4904	.4904	.4527
2	.415	.4904	.5093	.4904	.4904	.4904	.4904
3	.415	.4715	.4715	.4904	.4904	.4904	.4904
4	.4527	.4904	.5093	.5281	.5281	.4904	.4904
5	.4527	.5093	.5281	.5658	.5658	.5093	.5281
6	.4527	.547	.5093	.5658	.5658	.547	.5281
7	.4527	.547	.547	.5658	.547	.5658	.5281
8	.6036	.5847	.547	.4527	.547	.547	.5281
9	.5658	.547	.547	.4904	.5658	.5658	.4904
10	.5281	.547	.5658	.547	.4527	.5093	.5093
11	.4527	.5281	.5281	.4715	.5281	.6036	.547
12	.4527	.5281	.4527	.4338	.4904	.5281	.5281
13	.415	.4338		.4527	.4904	.415	.5281
14	.4904	.547	.4527	.5093	.4904	.4527	.4904
15	.4904	.5281	.4527		.4527	.5658	.5281
16	.5281	.4904	.4527	.5093	.4527		.5093
17	.3772	.5281	.4527	.4904	.4904	.547	.547
18	.415	.5281	.5281	.5281	.5281	.5281	.5658
19	.3961	.5093	.5658	.4904	.4904	.4527	.5281
20	.547	.5281	.4904	.4904	.4904	.4527	.4904
21	.2263	.5281	.4904	.5281	.4904	.4904	.5281
22	.5281	.5281	.5281	.5093	.4715	.4904	.5093
23	.4904	.4715	.5281	.5093	.4904	.4904	.5093
24	.415	.5281	.5093	.5281	.5281		.4527
Max	**.6036**	**.5847**	**.5658**	**.5658**	**.5658**	**.6036**	**.5658**
Min	**.2263**	**.4338**	**.4527**	**.4338**	**.4527**	**.415**	**.4527**
Avg	**.4574**	**.5187**	**.5068**	**.5060**	**.5053**	**.5101**	**.5124**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(W) S/DN.[018] BU 4018
Substation No/ Name :- 144032 / 33/11KV PUIKHADI SUBSTATION
Feeder No / Name : 206 / K N Patil SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.1886	.2054	.2286	.2195	.2241	.2263
2	.1848	.1886	.2075	.2096	.2012	.1867	.1886
3	.1848	.1886	.1886	.1905	.2012	.1867	.1886
4	.2218	.2286	.2218	.2286	.2195	.1867	.2263
5	.2587	.2858	.2801	.2286	.2561	.2801	.2641
6	.3326	.415	.3961	.2667	.3292	.3511	.3395
7	.5359	.5281	.4715	.4191	.5487	.4066	.5041
8	.5914	.5281	.6036	.6036	.567	.6099	.6413
9	.5729	.5228	.5415	.5658	.567	.6283	.5658
10	.4251	.4435	.5228	.462	.4668	.4435	.4481
11	.3801	.3696	.4108	.4066	.3841	.3881	.3511
12	.3439	.3696	.3921	.3511	.362	.3511	.3475
13	.3258	.3696	.3658	.3142	.3582	.3142	.3658
14	.2957	.3475	.3174	.2772	.362	.2957	.3109
15	.2957	.3658	.3174		.362	.3142	.2587
16	.2957	.2926	.3142	.2957	.3077	.2587	.2743
17	.3258	.3475	.3292	.3326	.3224	.3142	.3224
18	.4835	.4525	.4344	.462	.4119	.4477	.4251
19	.6283	.6283	.6468	.5544	.6335	.6335	.5914
20	.5914	.5788	.5975	.5729	.6099	.6099	.5914
21	.5601	.5544	.5601	.5544	.5729	.5975	.462
22	.5228	.4854	.4668	.4706	.4805	.5041	.4715
23	.3547	.3361	.3734	.3258	.3696	.3734	.2772
24	.2402	.2641	.2614	.2641	.2715	.2587	.2641
Max	**.6283**	**.6283**	**.6468**	**.6036**	**.6335**	**.6335**	**.6413**
Min	**.1848**	**.1886**	**.1886**	**.1905**	**.2012**	**.1867**	**.1886**
Avg	**.3807**	**.3866**	**.3928**	**.3732**	**.3910**	**.3819**	**.3711**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(W) S/DN.[018] BU 4018
Substation No/ Name :- 144101 / DUDHALI S/S
Feeder No / Name : 201 / 11 KV MASKUTI SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4024	.4024	.4435	.3982	.439	.3841	.3801
2	.4024	.3881	.4435	.3801	.4207	.3696	.362
3	.4024	.3696	.4066	.362	.4024	.3511	.3258
4	.4207	.3696	.4066	.362	.4024	.3511	.3258
5	.4572	.3881	.4435	.362	.4024	.3696	.3258
6	.5121	.462	.4435	.3982	.4755	.4251	.4163
7	.567	.5093	.4527	.4706	.5304	.4904	.4887
8	.6036	.5658	.5975		.6036	.5975	.5792
9	.6767	.6161	.6348	.6154	.6584	.6722	.6154
10	.6036	.6838	.6653	.5792	.6584	.5914	.5973
11	.5068	.5068	.5729	.5014	.543	.4938	.5014
12	.5249	.5068	.5359	.5121	.5249	.4938	.4835
13	.4706	.4887	.5304	.439	.5068	.4938	.4887
14	.4344	.4344	.4755	.4435	.4525	.439	.4024
15	.4066	.3801	.3841	.4207	.3801		.3224
16	.4024	.3982	.3841	.4024	.4163	.3841	.3982
17	.4755	.4887	.439	.4207	.4887	.4938	.4207
18	.6556	.7545	.6878	.567	.6697	.5973	.6219
19	.8682	.9214	.8869	.8413	.905	.8688	.9145
20	.8596	.8596	.8326	.8413	.8688	.8688	.8688
21	.7964	.788	.7964	.7865	.7964	.8145	.8145
22	.7421	.724	.724	.7316	.7421	.7059	.7316
23	.567	.5792	.5611	.5853	.567	.5973	.567
24	.4207	.439	.439	.4525	.439	.4207	.4163
Max	**.8682**	**.9214**	**.8869**	**.8413**	**.905**	**.8688**	**.9145**
Min	**.4024**	**.3696**	**.3841**	**.362**	**.3801**	**.3511**	**.3224**
Avg	**.5491**	**.5427**	**.5495**	**.5162**	**.5539**	**.5336**	**.5153**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(W) S/DN.[018] BU 4018
Substation No/ Name :- 144101 / DUDHALI S/S
Feeder No / Name : 202 / 11KV GANGAVES SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.132	.1509	.1294	.1478	.1509	.1478
2	.1294	.132	.1509	.1294	.1294	.132	.1478
3	.1294	.132	.132	.1294	.1294	.132	.1478
4	.1294	.132	.132	.1294	.1294	.132	.1478
5	.1478	.1509	.1509	.1294	.1294	.132	.1294
6	.1663	.1524	.1509	.1294	.1478	.1509	.1294
7	.1663	.1905	.1886	.1478	.1663	.1524	.1478
8	.1848	.1905	.2263	.1848	.2033	.1715	.2033
9	.2218	.2075	.2263	.2218	.2218	.2263	.2402
10	.2561	.2263	.2641	.2587	.2402	.2587	.2587
11	.2957	.2587	.2641	.3018	.3142	.2957	.2957
12	.3142	.2587	.2452	.3018	.3326	.2772	.2772
13	.3142	.2402	.2402	.2801	.2926	.2957	.2926
14	.2772	.2218	.2218	.2614	.2743	.2587	.2587
15	.2957	.2218	.2218	.2218	.2743	.2772	.2378
16	.3292	.2587	.2033	.2801	.2772	.3142	.3142
17	.3292	.2587	.2402	.2957	.3326	.3142	.3326
18	.3761	.3292	.3511	.3696	.4066	.4066	.3881
19	.4706	.3982	.4251	.462	.4805	.462	.4805
20	.4119	.4024	.3696	.4435	.4251	.4251	.4435
21	.3292	.3658	.3142	.3326	.3142	.3326	.3326
22	.2587	.2587	.2402	.2402	.2402	.2218	.2402
23	.2054	.2241	.1848	.1848	.2054	.1848	.1848
24	.1478	.1494	.1886	.1478	.1478	.1509	.1478
Max	**.4706**	**.4024**	**.4251**	**.462**	**.4805**	**.462**	**.4805**
Min	**.1294**	**.132**	**.132**	**.1294**	**.1294**	**.132**	**.1294**
Avg	**.2514**	**.2289**	**.2285**	**.2380**	**.2484**	**.2440**	**.2469**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(W) S/DN.[018] BU 4018
Substation No/ Name :- 144101 / DUDHALI S/S
Feeder No / Name : 203 / 11KV MAHADWAR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7499	.8589	.7783	.8596	.7682	.7316
2	.7499	.7316	.8589	.7421	.823	.7499	.6767
3	.7499	.7207	.7842	.724	.823	.7577	.6584
4	.7499	.7207	.7842	.724	.823	.7392	.6401
5	.8048	.7392	.8589	.724	.823	.7577	.6401
6	.8962	.9055	.924	.8326	.8962	.8871	.8326
7	1.0242	.9709	1.0562	.8326	1.0242	.9619	1.0317
8	1.1523	1.1389	1.1949	1.1222	1.134	1.1949	1.1584
9	1.262	1.2382	1.3443	1.1765	1.2254	1.2197	1.1946
10	1.262	1.2071	1.2936	1.1946	1.2254	1.2437	1.2489
11	1.267	1.1946	1.2382	1.2308	1.2489	1.2254	1.2357
12	1.2308	1.1584	1.2382		1.2489	1.2803	1.2178
13	1.1946	1.1222	1.0608	1.134	1.1946	1.1888	1.1946
14	1.1041	1.0317	1.0425	1.0903	1.1222	1.1157	1.134
15	1.0387	.905	.9877	.9877	1.0136	1.0242	1.0498
16	1.086	.905	1.0242	.9774	1.0136	1.0425	1.0242
17	1.2308	1.0317	1.0974	1.0608	1.1584	1.1523	1.1706
18	1.5592	1.5592	1.448	1.4632	1.4842	1.5384	1.4815
19	2.0237	1.9136	1.9728	1.8839	2.0271	1.9728	1.9936
20	2.0452	1.8625	1.8642	1.8656	1.9547	1.9366	
21	1.6655	1.6118	1.647	1.701	1.6108	1.6289	1.6278
22	1.3575	1.3032	1.3756	1.3535	1.3756	1.3213	1.3169
23	1.0387	1.1584	1.0679	1.0608	1.0387	1.0498	1.0242
24	.7682	.7964	.8326	.8688	.8596	.8145	.7964
Max	**2.0452**	**1.9136**	**1.9728**	**1.8839**	**2.0271**	**1.9728**	**1.9936**
Min	**.7499**	**.7207**	**.7842**	**.724**	**.823**	**.7392**	**.6401**
Avg	**1.1853**	**1.1115**	**1.1606**	**1.1099**	**1.1670**	**1.1488**	**1.0904**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(W) S/DN.[018] BU 4018
Substation No/ Name :- 144101 / DUDHALI S/S
Feeder No / Name : 204 / MIRABAG **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.6219	.6584	.6626	.6697	.6468	.6447
2	.6516	.6036	.6584	.591	.6516	.6283	.6089
3	.6516	.5914	.6219	.5973	.6516	.6099	.6089
4	.6878	.5914	.6219	.5973	.6516	.6099	.6089
5	.7602	.6099	.695	.6089	.7059	.6283	.6089
6	.8688	.8131	.7164	.7343	.7682	.7947	.7164
7	.8869	.8029	.8215	.7522	.8596	.8029	.8238
8	.905	.9335	.9335	.9671	.9231	1.0269	.8775
9	.9955	.9795	1.0082	.985	.9774	.9795	.9671
10	.9511	.961	.9979	.985	.9955	.9979	.9671
11	.905	.9134	.961	.9671	.9671	.9231	.8596
12	.8326	.9313	.9795	.9313	.8775	.8688	.8688
13	.8059	.8954	.8869	.8507	.8417	.9412	.8326
14	.7522	.4298	.7964	.8048	.8059	.7602	.8048
15	.7442	.7164	.7421	.7421	.6984	.7602	.7059
16	.7712	.788	.8145	.7499	.7701	.724	.724
17	.8413	.8775	.8326	.7964	.788	.7964	.8145
18	.9816	1.134	.985	.9412	.9313	1.0566	.9412
19	1.382	1.382	1.3611	1.3032	1.3611	1.3432	1.3937
20	1.382	1.4118	1.3073	1.3575	1.3253	1.3253	1.3575
21	1.2536	1.3032	1.2357	1.267	1.2536	1.2536	1.2308
22	1.1041	1.1222	1.1104	1.1222	1.1104	1.1104	1.1222
23	.8507	.8954	.8775	.8507	.8417	.8954	.8507
24	.6697	.695	.6878	.7164	.6878	.695	.6626
Max	**1.382**	**1.4118**	**1.3611**	**1.3575**	**1.3611**	**1.3432**	**1.3937**
Min	**.6516**	**.4298**	**.6219**	**.591**	**.6516**	**.6099**	**.6089**
Avg	**.8869**	**.8752**	**.8880**	**.8701**	**.8798**	**.8824**	**.8584**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(W) S/DN.[018] BU 4018
Substation No/ Name :- 144101 / DUDHALI S/S
Feeder No / Name : 206 / 11 KV SAKOLI SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.2561	.2587	.2353	.2561	.2402	.2353
2	.2561	.2402	.2587	.2172	.2561	.2218	.2172
3	.2561	.2218	.2218	.2172	.2561	.2218	.1991
4	.2743	.2241	.2218	.2172	.2743	.2218	.1991
5	.3475	.2427	.2957	.2172	.2743	.2402	.1991
6	.3841	.3547	.3361	.2715	.3292	.2957	.2896
7	.4207	.3881	.4481	.362	.3841	.3921	.4163
8	.4755	.5175	.5121	.5068	.4755	.5601	.4525
9	.5487	.5544	.5121	.5068	.5304	.5359	.5068
10	.4755	.5121	.5175	.4706	.4755	.4755	.4706
11	.4344	.5068	.439	.4755	.4525	.439	.4119
12	.3982	.4344	.3658		.4163	.4024	.3982
13	.4163	.3982	.3841	.3982	.3801	.3841	.4024
14	.3801	.362	.3292	.3475	.3439	.3658	.362
15	.3506	.3258	.3109	.3077	.3258	.3292	.3258
16	.3898	.3258	.3109	.3403	.3439	.3109	.3292
17	.3856	.3801	.3658	.3841	.3439	.3658	.3841
18	.4908	.4961	.4525	.4572	.4525	.4887	.4572
19	.5847	.567	.5792	.567	.5973	.5973	.5853
20	.5552	.5316	.5068	.567	.5249	.543	.567
21	.5194	.5014	.5068	.5121	.5068	.5068	.5304
22	.4477	.4344	.4525	.4755	.4525	.4706	.4755
23	.3658	.3982	.362	.3841	.3841	.3801	.3841
24	.2561	.2743	.2896	.2715	.2743	.2743	.2715
Max	**.5847**	**.567**	**.5792**	**.567**	**.5973**	**.5973**	**.5853**
Min	**.2561**	**.2218**	**.2218**	**.2172**	**.2561**	**.2218**	**.1991**
Avg	**.4029**	**.3937**	**.3849**	**.3787**	**.3879**	**.3860**	**.3779**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(W) S/DN.[018] BU 4018
Substation No/ Name :- 144101 / DUDHALI S/S
Feeder No / Name : 207 / SHUKRAWAR GATE SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4525	.439	.4755	.4298	.4525	.4207	.394
2	.4525	.4251	.4755	.394	.4344	.4066	.3761
3	.4525	.4066	.439	.3761	.4344	.3881	.3582
4	.4706	.4066	.439	.3761	.4344	.3881	.3582
5	.5249	.4251	.439	.3801	.4344	.3881	.3582
6	.5792	.499	.439	.4477	.4525	.462	.4119
7	.6154	.5601	.5544	.5014	.543	.5601	.5552
8	.6516	.6348	.6653	.6268	.695	.7023	.6805
9	.7602	.7392	.7023	.7343	.724	.7392	.7522
10	.6697	.6838	.7762	.7164	.724	.6838	.6805
11	.6516	.6447	.6653	.5853	.6447	.6335	.6516
12	.6516	.6468	.5914	.5853	.591	.5973	.6154
13	.591	.6089	.5973	.5792	.5552	.5973	.6335
14	.5552	.5373	.5487	.5487	.5373	.5792	.5304
15	.5014	.5194	.5121	.5121	.4835	.5068	.5068
16	.567	.5194	.4572	.5304	.4835	.5068	.5068
17	.5959	.5731	.5249	.5611	.5552	.5249	.5611
18	.7373	.7712	.7343	.6878	.7164	.7343	.7602
19	.9816	.9816	.9955	.9593	1.0208	1.0029	1.0498
20	.9568	.9313	.9134	.905	.9313	.9313	.9593
21	.9412	.8954	.8775	.8688	.8596	.8775	.8688
22	.8048	.7964	.7701	.7964	.8059	.788	.7964
23	.6268	.6447	.6268	.6154	.6089	.6268	.6154
24	.4706	.4706	.4656	.4835	.4525	.4572	.4477
Max	**.9816**	**.9816**	**.9955**	**.9593**	**1.0208**	**1.0029**	**1.0498**
Min	**.4525**	**.4066**	**.439**	**.3761**	**.4344**	**.3881**	**.3582**
Avg	**.6359**	**.6150**	**.6119**	**.5917**	**.6073**	**.6043**	**.6012**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.(W) S/DN.[018] BU 4018
Substation No/ Name :- 144101 / DUDHALI S/S
Feeder No / Name : 208 / 11 KV LAXTIRTH SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.2926	.3224	.2835	.3292	.2896	.2835
2	.3109	.2743	.3224	.2686	.3109	.2743	.2658
3	.3109	.2587	.2865	.2507	.3109	.2743	.2658
4	.3109	.2587	.2865	.2534	.3109	.2772	.2658
5	.3292	.2772	.3582	.2507	.3292	.2957	.2658
6	.3841	.3881	.3582	.3366	.3475	.3696	.3544
7	.439	.3921	.4108	.3721	.4024	.415	.4075
8	.4938	.4668	.4755	.443	.5121	.4668	.443
9	.439	.5175	.5175	.4961	.5121	.5175	.4607
10	.439	.4755	.4755	.4784	.4938	.4572	.4252
11	.4344	.4298	.4572	.4961	.443	.439	.4031
12	.3898	.4784	.4207		.4607	.439	.4207
13	.4075	.4607	.4207	.3641	.4075	.4572	.4115
14	.3544	.3898	.3841	.3366	.3721	.4024	
15	.3467	.3898	.3475	.3582	.3544	.3658	.3601
16	.3086	.4075	.3475	.3439	.3544	.4024	.3258
17	.3429	.394	.3658	.4024	.3544	.4207	.3841
18	.4287	.5426	.4298	.5304	.4607	.4835	.439
19	.6485	.6935	.6024	.6401	.6379	.6626	.6767
20	.6379	.6661	.6201	.6401	.6201	.6268	.6584
21	.6089	.6516	.591	.6401	.6024	.6024	.6036
22	.5611	.5373	.5316	.567	.567	.5373	.5487
23	.4163	.5014	.4075	.439	.4119	.4075	.4024
24	.3292	.3258	.3155	.3189	.3292	.3077	.3045
Max	**.6485**	**.6935**	**.6201**	**.6401**	**.6379**	**.6626**	**.6767**
Min	**.3086**	**.2587**	**.2865**	**.2507**	**.3109**	**.2743**	**.2658**
Avg	**.4167**	**.4362**	**.4190**	**.4135**	**.4264**	**.4246**	**.4077**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.MARKET Y.[021] BU 4021
Substation No/ Name :- 144030 / 33/11KV GPI S/STN
Feeder No / Name : 201 / 11KV TRYAMBOLI SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.3326			.3658	.3658	.3734
2	.3696	.3326			.3658	.3734	.3734
3	.3696	.3361			.3658	.3734	.3696
4	.3696	.3361			.3658	.3696	.3696
5	.3658	.3326			.3696	.4435	.4435
6	.5121	.3734		.5121	.5175	.5175	.5175
7	.679	.6722		.5975	.6036	.5975	.6722
8	.7468	.6722	.6722	.6722	.679	.6104	.7545
9	.7468	.5975	.7468		.6722	.5975	.7468
10	.6653	.5914	.7468	.5975	.5914	.5975	.5975
11	.5175	.5175	.5228	.5228	.5175	.5175	.5175
12	.4435	.5175	.4805	.4435	.4435	.5121	.4755
13	.439	.5175	.5175	.4435	.4481	.439	.439
14	.3658	.4435	.4435	.3696	.3696	.3582	.3658
15	.3696	.3696	.3696	.3696	.3658	.5121	.3658
16	.3696	.3658	.4066	.3658	.3658	.3658	.3658
17	.439	.5228	.4344	.3658	.4344	.439	.4344
18	.5731	.5121	.5792	.4298	.6154	.5731	.543
19	.788	.8596	.8596	.7964	.788	.7964	.724
20	.7964	.788	.8688	.7964	.724	.8688	.7964
21	.724	.7964	.7964	.7964	.7316	.7964	.724
22	.724	.724	.7316	.7316	.6584	.7316	.6584
23	.5068	.5121	.5068	.5121	.5068	.5121	.5068
24	.362	.362	.3658	.4344	.3658	.362	.4344
Max	**.7964**	**.8596**	**.8688**	**.7964**	**.788**	**.8688**	**.7964**
Min	**.362**	**.3326**	**.3658**	**.3658**	**.3658**	**.3582**	**.3658**
Avg	**.5254**	**.5160**	**.5911**	**.5421**	**.5096**	**.5263**	**.5237**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.MARKET Y.[021] BU 4021
Substation No/ Name :- 144092 / 33/11 KV Bapat Camp
Feeder No / Name : 201 / 11KV Auxilliary Feeder KV- 11 / OUTGOING
NON SHEDDABLE EXPRESS HV FEEDERS (CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11		.0183		.0177
12		.0181	.0191	.0177
13		.0181	.0191	.0177
14		.0181		.0177
15		.0181	.0191	.0177
16	.0177	.0181	.0191	.0177
17	.0177		.0181	.0177
Max	**.0177**	**.0183**	**.0191**	**.0177**
Min	**.0177**	**.0181**	**.0181**	**.0177**
Avg	**.0177**	**.0181**	**.0189**	**.0177**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.MARKET Y.[021] BU 4021
Substation No/ Name :- 144092 / 33/11 KV Bapat Camp
Feeder No / Name : 202 / Shiroli SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.743	.743		.7922	.724		.7545
2	.724	.724		.7922	.724		.7545
3	.724	.724			.7049		.7545
4	.7621	.7621		.7922	.743		.7356
5		.8192		.811	.7621		.7545
6	.9145	.9145		.8299	.8764		.9054
7	1.1241	1.086		.9997	1.0479		1.0374
8	1.2193	1.2384	1.3336	1.094	1.2955		1.1694
9	1.3336		1.448		1.4335	1.5051	1.5051
10			1.5813		1.5655	1.6385	1.5813
11			1.6004		1.6975	1.7337	1.7147
12			1.4861		1.5655	1.2955	1.6385
13			1.467		1.4712	1.3336	1.3908
14			1.4289		1.4146	1.3717	1.4098
15			1.4098		1.5466	1.4098	1.5051
16	1.5432	1.3717	1.467		1.6032	1.3908	1.5242
17	1.3527		1.4712	.9907		1.5089	1.5813
18	1.5813		1.4523	1.0669		1.5466	1.7337
19	1.4861		1.5466	1.2193		1.5466	1.6575
20	1.3717		1.2637	1.1622		1.3203	1.4098
21	1.2955		1.1694	1.105		1.226	1.2574
22	1.1431		1.0751	.9907		1.0562	1.105
23	.9145		.9431	.7811		.9808	.9335
24	.7811	.8002	.8383	.8299	.7621	.6859	.7733
Max	**1.5813**	**1.3717**	**1.6004**	**1.2193**	**1.6975**	**1.7337**	**1.7337**
Min	**.724**	**.724**	**.8383**	**.7811**	**.7049**	**.6859**	**.7356**
Avg	**1.1185**	**.9183**	**1.3519**	**.9505**	**1.1728**	**1.3469**	**1.2328**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.MARKET Y.[021] BU 4021
Substation No/ Name :- 144092 / 33/11 KV Bapat Camp
Feeder No / Name : 204 / Tarabai Park **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9328	.9328		.9145	.9717		.8596
2	.9526	.9145		.823	.9145		.8048
3	.9335	.8962		.8048	.8764		.8048
4	.9808	.9511		.823	.9145		.823
5	1.0288	.9877		.8596	.9619		.8048
6	1.1883	1.1157		1.0059	1.1016		1.1157
7	1.423	1.3717		1.2071	1.2803		1.2803
8	1.5546	1.4815	1.4815	1.5181	1.5181		1.4998
9			1.4815		1.6827	1.6827	1.6461
10			1.4998		1.6827	1.5546	1.4998
11			1.4083		1.4815	1.4266	1.39
12			1.3717		1.4083	1.3717	1.4083
13			1.3535		1.2254	1.2437	1.3169
14			1.2803		1.2071	1.1706	1.2254
15			1.2254		1.3717	1.0974	1.1706
16	1.2071	1.2803	1.1706		1.2437	1.134	1.134
17	1.1706		1.1888	.4805		1.2254	1.134
18	1.4449		1.4266	1.5364		1.4632	1.4815
19	1.957		1.957	1.9022		1.8839	1.9204
20	1.8656		1.8839	1.848		1.8839	1.9022
21	1.7558		1.7741	1.7558		1.7375	1.7558
22	1.5364		1.6827	1.6598		1.6095	1.5912
23	1.3169		1.2986	1.3443		1.2986	1.3169
24	.9997	.9877	.9877	1.0242	1.0374	.9431	.9328
Max	**1.957**	**1.4815**	**1.957**	**1.9022**	**1.6827**	**1.8839**	**1.9204**
Min	**.9328**	**.8962**	**.9877**	**.4805**	**.8764**	**.9431**	**.8048**
Avg	**1.3087**	**1.0919**	**1.4395**	**1.2192**	**1.2282**	**1.4204**	**1.2841**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.MARKET Y.[021] BU 4021
Substation No/ Name :- 144092 / 33/11 KV Bapat Camp
Feeder No / Name : 206 / Vikramnagar SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4338		.4715	.4763		.4294
2	.4382	.4338		.4527	.4572		.4108
3	.4382	.4338		.4294	.4382		.3921
4	.4763	.4527		.4527	.4763		.4108
5	.4954	.5093		.4715	.4954		.4294
6	.5525	.5847		.5281	.5525		.4854
7	.6859	.7356		.5847	.5906		.6161
8	.7811	.6979	.7167	.7095	.7621		.7282
9			.7356		.6908	.7811	.7356
10			.7545		.6908	.724	.679
11			.7167		.6722	.743	.679
12			.6036		.6348	.6097	.6602
13			.6224		.5601	.5716	.5847
14			.6036		.5228	.5906	.6413
15			.5847		.5601	.5716	.547
16	.5847	.6036	.5658		.5847	.5906	.5281
17	.5847		.6348	.6097		.5788	.5658
18	.7167		.6908	.6478		.7468	.7167
19	.9808		.9522	.8954		.9896	.9619
20	.9431		.8962			.9335	.9619
21	.9054		.8589			.8962	.9242
22	.8048		.8215	.8002		.8029	.811
23	.6602		.6908	.6668		.6348	.6413
24	.4763	.4527	.5093	.5658	.5335	.4458	.4854
Max	**.9808**	**.7356**	**.9522**	**.8954**	**.7621**	**.9896**	**.9619**
Min	**.4382**	**.4338**	**.5093**	**.4294**	**.4382**	**.4458**	**.3921**
Avg	**.6460**	**.5338**	**.7034**	**.5918**	**.5705**	**.7007**	**.6261**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.MARKET Y.[021] BU 4021
Substation No/ Name :- 144092 / 33/11 KV Bapat Camp
Feeder No / Name : 207 / Industrial Bapat Camp MYZ SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.5335		.5281	.4191		.5847
2	.5335	.5335		.4338	.381		.415
3	.5144	.4954		.415	.381		.415
4	.4954	.4763		.415	.4001		.415
5	.5144	.4763		.4338	.4382		.4338
6	.5335	.4954		.4527	.4763		.4715
7	.5525	.5525		.4904	.5144		.4904
8	.5144	.5525	.5144	.4904	.4954		.4904
9			.6097		.7922	.6859	.6287
10			.8573		.811	.743	.7049
11			.8573		.8865	.8573	.8192
12			.8192		.8488	.7621	.7621
13			.743		.7356	.7049	.7049
14			.7621		.6602	.724	.6859
15			.7811		.8676	.743	.8002
16	.7811	.8192	.8192		.8488	.724	.7621
17	.743		.7545	.4572		.7733	.7621
18	.6859		.6224	.4763		.7545	.7621
19	.743		.7922	.5716		.8488	.743
20	.6478		.5658	.5716		.679	.7049
21	.6478		.6413	.5335		.7167	.6668
22	.6478		.6224	.4954		.6602	.6097
23	.5906		.5847	.4763		.6224	.4954
24	.5525	.5525	.5525	.547	.4382	.3725	.5658
Max	**.7811**	**.8192**	**.8573**	**.5716**	**.8865**	**.8573**	**.8192**
Min	**.4954**	**.4763**	**.5144**	**.415**	**.381**	**.3725**	**.415**
Avg	**.6018**	**.5487**	**.6999**	**.4868**	**.6114**	**.7107**	**.6206**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.MARKET Y.[021] BU 4021
Substation No/ Name :- 144093 / 33/11 D Block
Feeder No / Name : 201 / Kay Industry SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2667	.2715	.2667	.2614	.2667	.2858
2	.2858	.2858	.2801	.2667	.2614	.2858	.2858
3	.2858	.2858	.2614	.2858	.2801	.2858	.2667
4	.2858	.2858	.2614	.2858	.2801	.2858	.2667
5	.2858	.2858	.2801	.2858	.2801	.2858	.2667
6		.2858	.2614	.2858	.2801	.2858	.0381
7	.2858	.2858	.2614	.2858	.2801	.2858	.0381
8	.2858	.2858	.2801	.3239	.2801	.2858	
9	.2858	.2858	.2987	.2858	.2801	.3048	.2858
10	.2667	.3048	.2858	.2858	.2801	.2801	.2858
11	.3048	.3048	.2858	.0381	.2614	.2987	.3048
12	.2858	.3048	.2858	.0381	.2614	.0373	.3048
13	.3048	.2667	.2667	.0381	.2801	.0373	.3048
14	.2667	.2667	.2858	.0381	.2614	.2801	.2858
15	.2667	.2667	.2667	.0381	.2801	.2801	.2858
16	.2667	.2667	.2667	.0381	.2614	.2801	
17	.2667	.2667	.3048	.0381		.2614	
18	.0381	.0373	.0381	.0373	.2858	.0381	.2667
19	.0381	.0373	.0381	.0373	.2858	.0381	.0381
20	.0381	.0373	.0381	.0373	.0381	.0381	.0381
21	.0381	.0373	.0381	.0373	.0381	.0381	.0381
22	.0381	.0373	.0381	.0373	.0381	.1905	.2477
23	.0381	.0373	.0381	.2614	.0381	.2667	.2667
24	.2667	.0381	.2614	.0381	.2561	.0381	.2667
Max	**.3048**	**.3048**	**.3048**	**.3239**	**.2858**	**.3048**	**.3048**
Min	**.0381**	**.0373**	**.0381**	**.0373**	**.0381**	**.0373**	**.0381**
Avg	**.2170**	**.2110**	**.2164**	**.1504**	**.2326**	**.2073**	**.2223**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.MARKET Y.[021] BU 4021
Substation No/ Name :- 144093 / 33/11 D Block
Feeder No / Name : 202 / Sakal Press DBlock Shiroli SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.086	1.2765	1.0269	1.0479	.8029	1.2003	1.1622
2	1.0669	1.2003	1.0829	1.086	.8962	1.1622	1.2193
3	1.0288	1.1622	1.0642	1.0669	.7842	.9907	1.2003
4	.9145	1.0288	1.0456	.9145	.7468	.7049	.9145
5	.8764	.9145	.9709	.8383	.7655	.8573	.7811
6	.8764	.9145	.8962	.8192	.7842	.8764	.8002
7	.8954	.8573	.8402	.8383	.8215	.8383	.8383
8	.9335	.8573	.7842	.8573	.7842	.9335	
9	.8002	1.0288	.7655	.7621	.8029	.7811	.8764
10	.9335	1.2193	.8383	.7621	.9896	.7842	.8764
11	.9907	1.2574	.9907	.8002	1.0082	.8029	.8764
12	.9526	1.2003	1.0669	.7049	1.0456	.8402	.8573
13	.8573	1.0479	.9335	.6859	1.0456	.8402	.8764
14	1.0669	1.1431	1.0479	.7049		.9335	
15	.8573	1.1431	1.1431	.724	1.0456	.9709	
16	.8954	1.2955	.7811	.6859	1.1576	.9896	1.0288
17	.9907	1.0669	.8573	.743	1.251	.9896	
18	.9907	1.0082	.8764	.7842	1.0288	.9145	.8383
19	1.0479	.9709	.9335	.8029	.8954	.8192	.8383
20	1.0288	.8402	.8573	.7468	.8002	.7621	.743
21	.7811	.6908	.8192	.6722	.8192	.743	.724
22	.7049	.7842	.8002	.5975	.8192	.7049	.7811
23	.9717	.8962	.8573	.6348	.8764	.8764	.8764
24	.9145	1.0669	.9335	.8764	.6722	.9526	.9145
Max	**1.086**	**1.2955**	**1.1431**	**1.086**	**1.251**	**1.2003**	**1.2193**
Min	**.7049**	**.6908**	**.7655**	**.5975**	**.6722**	**.7049**	**.724**
Avg	**.9359**	**1.0363**	**.9255**	**.7982**	**.8975**	**.8862**	**.9012**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.MARKET Y.[021] BU 4021
Substation No/ Name :- 144093 / 33/11 D Block
Feeder No / Name : 203 / Menon Metallics **SHEDDABLE FEEDER HAVING WEEKLY**
Feeder KV- 11 / OUTGOING **STAGGERING (MIDC, EQUIVALENT)**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7049	.6478	.5806	.6478	.3734	.6478	.6478
2	.724	.6668	.5975	.6287	.3547	.6287	.6478
3	.6859	.6287	.5601	.6287	.3547	.6478	.6287
4	.6668	.4954	.5601	.6287	.3361	.6287	.6287
5	.6859	.6478	.5228	.6478	.3361	.6478	.6478
6	.6478	.6668	.5041	.6287	.3174	.6287	.6287
7	.6478	.5144	.4481	.6478	.3734	.6668	.6478
8	.6287	.5144	.4481	.362	.5228	.5716	
9	.724	.724	.4294	.362	.5415	.6859	.5335
10	.743	.7621	.7621	.362	.5415	.7095	.5335
11	.743	.724	.5525	.381	.5415	.5228	.5335
12	.743	.6859	.5335	.381	.5601	.6722	.4954
13	.6097	.5716	.5335	.381	.5415	.7468	.5335
14	.5335	.743	.4763	.381	.5228	.7655	
15	.5144	.7621	.5144	.381	.4668	.7468	
16	.6859	.743	.5144	.381	.5975	.7095	
17	.6478	.6859	.7049	.381	.6348	.6535	
18	.6478	.6908	.6859	.3734	.6287	.6097	.6097
19	.6287	.7095	.6859	.3734	.6097	.6287	.6478
20	.6859	.6535	.6478	.3734	.6097	.6478	
21	.5144	.6161	.5525	.3734	.6097	.6287	.6287
22	.5335	.5975	.4954	.3734	.6287	.6478	.6478
23	.4954	.5975	.5335	.3734	.6287	.6287	.6478
24	.6668	.5144	.6161	.5525	.3742	.6097	.6287
Max	**.743**	**.7621**	**.7621**	**.6478**	**.6348**	**.7655**	**.6478**
Min	**.4954**	**.4954**	**.4294**	**.362**	**.3174**	**.5228**	**.4954**
Avg	**.6462**	**.6485**	**.5608**	**.4585**	**.5003**	**.6534**	**.6065**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.MARKET Y.[021] BU 4021
Substation No/ Name :- 144093 / 33/11 D Block
Feeder No / Name : 204 / Budhale **SHEDDABLE FEEDER HAVING WEEKLY**
Feeder KV- 11 / OUTGOING **STAGGERING (MIDC, EQUIVALENT)**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0098	1.2384	1.2136	1.1241	.9522	.8573	.8764
2	.9717	1.2765	1.1949	1.1812	.9335	.8383	.8573
3	.9717	1.1812	1.0829	1.1431	.9149	.8002	.8192
4	.9145	1.0288	1.0642	1.0098	.9149	.8383	1.0288
5	.8954	1.0288	1.1203	.8192	.8962	.7811	1.1431
6	.8764	1.0288	1.1576	.8002	.8775	.8192	1.0669
7	.9335	1.105	1.0829	.8002	.8402	.8192	.8573
8	1.0669	.8954	1.2696	.7811	1.4003	.8573	
9	1.1812	1.7337	1.4377	.7621	1.6804	1.3146	1.2765
10	2.0195	1.7718	1.9433	.7811	1.8858	1.307	1.4289
11	2.3243	1.8671	1.7909	.8383	2.2032	1.4003	1.6194
12	1.1431	1.8861	1.829	.8383	1.9044	1.4563	1.7147
13	1.2955	1.448	1.5242	.8192	1.8298	1.0829	1.4289
14	1.8861	1.5051	1.7147	.7621	1.8111	1.8298	
15	2.0576	2.0576	1.9433	.743	1.8484	2.2779	
16	1.829	1.7337	1.829	.743	1.9231	1.8671	
17	1.9814	1.8671	1.467	.7621	2.0351	1.7924	
18	1.4289	1.531	1.2955	.7655	1.5813	1.3908	1.4098
19	1.7528	1.2696	1.0098	.7842	1.1431	1.2955	1.2193
20	1.4098	1.251	.8192	.8402	.9526	1.1241	1.2193
21	1.1812	1.2323	.9145	.8962	.8383	.9717	1.2384
22	1.2193	1.2696	1.0669	.9896	1.2574	.8192	
23	1.2765	1.251	1.0479	.9709	.8383	.8192	1.0288
24	.9145	1.2193	1.251	1.0479	.9522	.8002	.8002
Max	**2.3243**	**2.0576**	**1.9433**	**1.1812**	**2.2032**	**2.2779**	**1.7147**
Min	**.8764**	**.8954**	**.8192**	**.743**	**.8383**	**.7811**	**.8002**
Avg	**1.3559**	**1.4032**	**1.3362**	**.8751**	**1.3506**	**1.1733**	**1.1685**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.MARKET Y.[021] BU 4021
Substation No/ Name :- 144093 / 33/11 D Block
Feeder No / Name : 205 / Chintamani **SHEDDABLE FEEDER HAVING WEEKLY**
Feeder KV- 11 / OUTGOING **STAGGERING (MIDC, EQUIVALENT)**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5906	.6287	.6161	.6478	.5601	.5906	.5906
2	.6097	.5906	.6161	.6478	.5415	.5716	.5906
3	.5716	.6097	.6348	.6287	.5415	.5525	.5716
4	.5335		.57	.5906	.5228	.5525	.5716
5	.5335	.6859	.6535	.5525	.5228	.7049	
6	.6097	.7049	.5935	.5335	.5415	.6859	.6287
7	.6859	.7049	.6722	.5335	.5601	.724	.7049
8	.5525	.6859	.7468	.5525	.7468	.6859	
9	.8192	.8383	.7655	.5525	.8029	.743	.8192
10	.9145	1.105	.9907	.5716	.9709	1.1203	1.3336
11	.9907	1.2003	1.3527	.5716	1.0082	1.2136	1.5242
12	1.4289	1.2384	1.0098	.5716	.9896	1.2323	1.6385
13	.8192	.9335	.9717	.5525	.7655	.9149	
14	1.2193	.8954	1.2955	.5716	1.0269	1.1203	
15	1.2574	1.1431	1.2193	.5716	1.0456	1.307	
16	1.4861	1.2003	1.4289	.5716	1.1576	1.2696	
17	1.467	1.2003	.9526	.5906	1.1763	1.251	
18	1.6194	1.2136	.9526	.5788	1.3146	.7811	.8954
19	1.5623	1.251	.9907	.5975	1.2574	.5716	.8192
20	.7811	.6535	.6097	.5788	1.0098	.5716	.743
21	.724	.5601	.7049	.5788	.8002	.5906	.724
22	.7049	.5975	.7621	.5788	.5906	.5716	.5335
23	.743	.5788	.7049	.5788	.5906	.5716	.5335
24	.5335	.6668	.5975	.6668	.5601	.6097	.5716
Max	**1.6194**	**1.251**	**1.4289**	**.6668**	**1.3146**	**1.307**	**1.6385**
Min	**.5335**	**.5601**	**.57**	**.5335**	**.5228**	**.5525**	**.5335**
Avg	**.9066**	**.8646**	**.8505**	**.5821**	**.8168**	**.8128**	**.8114**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.MARKET Y.[021] BU 4021
Substation No/ Name :- 144093 / 33/11 D Block
Feeder No / Name : 206 / Gainmax **SHEDDABLE FEEDER HAVING WEEKLY**
Feeder KV- 11 / OUTGOING **STAGGERING (MIDC, EQUIVALENT)**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	1.3717	1.0642	1.4861	.6348	.9907	1.5432
2	1.5623	1.4861	1.0642	1.467	.6161	1.0288	1.5242
3	1.5051	1.2574	1.0456	1.4289	.5975	1.0098	1.4861
4	1.2384	.9717	1.0269	1.448	.5788	.9145	1.448
5	1.0098	1.0288	1.0082	1.467	.6535	1.2765	1.448
6	.9907	1.467	.9709	1.2955	.8962	1.105	
7	1.0288	.9145	.9335	.9907	1.0082	1.467	
8	.743	1.0669	1.1203	.6668	1.4377	1.5242	
9	1.3527	1.2193	1.1949	.5144	1.7551	1.7718	1.0669
10	1.3717	1.0288	1.1812	.5716	1.7364	1.3817	1.0098
11	1.7147	1.7718	1.2574	.6287	1.7551	1.1949	1.0098
12	1.5623	1.7528	1.1812	.5716	1.7364	1.3535	1.0098
13	1.2003	1.5242	1.1431	.5716	1.6057	1.1949	
14	1.2765	1.3336	1.2765	.5906	1.6057	1.2136	
15	1.2765	1.6766	.7811	.5906	1.6244	1.307	
16	1.3908	.7811	1.2574	.5906	1.6057	1.3717	
17	1.5813	1.4289	1.2003	.6097	1.6057	1.382	
18	1.6004	1.2136	1.4098	.6348	1.3146	1.1431	.7049
19	1.0288	1.0456	1.5623	.6535	1.2003	1.0288	.6287
20	1.5623	1.0269	1.5242	.6348	1.448	1.0288	.5906
21	1.5051	1.0269	1.5242	.6535	1.3336	1.4098	.5525
22	1.2384	1.0642	1.3908	.6535	.9335	1.5623	.5335
23	.6287	1.0642	1.4289	.6161	1.0669	1.5432	.5525
24	1.467	1.2384	1.0829	1.4098	.6348	.9907	1.5242
Max	**1.7147**	**1.7718**	**1.5623**	**1.4861**	**1.7551**	**1.7718**	**1.5432**
Min	**.6287**	**.7811**	**.7811**	**.5144**	**.5788**	**.9145**	**.5335**
Avg	**1.3075**	**1.2400**	**1.1929**	**.8644**	**1.2244**	**1.2581**	**1.0395**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.MARKET Y.[021] BU 4021
Substation No/ Name :- 144093 / 33/11 D Block
Feeder No / Name : 411 / 33 KV I/C DBLOCK
Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS (NON-CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.2012	5.4298	4.7611	5.2012	3.5848	4.5725	5.0869
2	5.2012	5.487	4.8171	5.2584	3.5848	4.5153	5.144
3	5.0297	5.144	4.5931	5.2012	3.4728	4.2867	4.9726
4	4.5725	4.4582	4.5931	4.8583	3.3608	3.9438	4.8583
5	4.2867	4.5725	4.537	4.6296	3.4168	4.5725	4.8583
6	4.2867	5.0869	4.425	4.3439	3.6969	4.401	4.4582
7	4.4582	4.401	4.201	4.1152	3.8649	4.8011	4.2867
8	4.2295	4.2867	4.6491	3.5437	5.1532	4.8583	
9	5.144	5.8299	4.8731	3.2579	5.8253	5.6013	4.8583
10	6.23	6.1728	6.0014	3.315	5.8642	5.5453	5.487
11	7.0873	7.1445	6.23	3.2579	6.7776	5.4332	5.8299
12	6.1157	7.0873	5.8871	3.0864	6.4975	5.6013	6.0014
13	5.0869	5.7728	5.3727	3.0293	5.9934	4.8171	6.0585
14	6.23	5.8871	6.1157	3.0293	6.2734	6.1054	5.7156
15	6.23	6.0014	5.8871	3.0293	6.2734	6.8896	5.5441
16	6.5729	6.0014	6.0585	3.0293	6.6655	6.4975	
17	6.9159	6.5158	5.487	3.1436	6.9456	6.2552	
18	6.3443	5.6573	5.2584	3.1367	6.1728	4.8583	4.7439
19	6.0585	5.2652	5.2012	3.2487	5.3727	4.6868	4.1724
20	5.487	4.425	4.5153	3.1927	4.8583	4.1724	3.9438
21	4.7439	4.145	4.5725	3.1927	4.4582	4.401	3.8866
22	4.4582	4.313	4.5725	3.1927	4.2867	4.5153	3.9438
23	4.1724	4.425	4.6296	3.4168	4.0581	4.6868	3.8866
24	4.7439		4.7051	4.5725	3.4168	4.0009	4.6868
Max	**7.0873**	**7.1445**	**6.23**	**5.2584**	**6.9456**	**6.8896**	**6.0585**
Min	**4.1724**	**4.145**	**4.201**	**3.0293**	**3.3608**	**3.9438**	**3.8866**
Avg	**5.3703**	**5.3700**	**5.0810**	**3.7201**	**4.9948**	**5.0008**	**4.8773**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.MARKET Y.[021] BU 4021
Substation No/ Name :- 144093 / 33/11 D Block
Feeder No / Name : 414 / 33KV I/C-2 DBLOCK
Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS (NON-CONTINOUS PROCESS)(NO STAGGERING)

DATE	23-DEC-17
HR	Load (MW)
23	4.425
Max	4.425
Min	4.425
Avg	4.425

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.MARKET Y.[021] BU 4021
Substation No/ Name :- 144103 / 33/11 Kv Gandhinagar
Feeder No / Name : 204 / INDIRA SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.2987	.3174	.2987	.3734	.2987	.2801
2	.3174	.2801	.2987	.2614	.3361	.2801	.2614
3	.2801	.2614	.2801	.2241	.3361	.2801	.2427
4	.2801	.2614	.2614	.2241	.2801	.2641	.2241
5	.2801	.2801	.2614	.2427	.2801	.2614	.2241
6	.2987	.2987	.2614	.2427	.2987	.2801	.2427
7	.3361	.3174	.2614	.2987	.3174	.2987	.2987
8	.4481	.4108	.3734	.3547	.3734	.3921	.3734
9	.4854	.4294	.5041	.4294	.4481	.4668	.4294
10		.5228	.4854	.4854	.5228	.5228	.4854
11	.6161	.6722	.5228	.5788	.6348	.6348	.6348
12	.6348	.7282	.5788	.6722		.7095	.6722
13	.6722	.7468	.5601	.6535		.6722	.7095
14	.6348	.7282	.5228	.5975		.6535	.6348
15	.6348	.7282	.4668	.5975		.6161	.6161
16	.5975	.6722	.4854	.5601	.6036	.5975	
17	.5601	.6602		.5228	.6413	.5975	.5975
18	.6348	.6722	.4668	.6161	.7468		.6348
19		.8029	.5415	.7095	.7842	.7655	.7095
20		.7468	.4854	.7095	.7655	.7282	.7095
21	.5601	.6535	.4108	.5975	.6161	.5788	.5601
22	.4481	.5228	.4108	.4668	.4854	.4668	.4294
23	.3734	.3921	.3734	.4108	.4108	.4108	.3734
24	.3361	.3174	.3361	.3361	.3734	.3361	.3174
Max	**.6722**	**.8029**	**.5788**	**.7095**	**.7842**	**.7655**	**.7095**
Min	**.2801**	**.2614**	**.2614**	**.2241**	**.2801**	**.2614**	**.2241**
Avg	**.4650**	**.5169**	**.4116**	**.4621**	**.4814**	**.4831**	**.4635**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.MARKET Y.[021] BU 4021
Substation No/ Name :- 144103 / 33/11 Kv Gandhinagar
Feeder No / Name : 205 / GANESH TAIKIES SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5914	.5175	.5544	.5175	.5914	.5544	.5914
2	.5544	.5175	.5175	.4805	.5729	.5544	.5544
3	.5544	.4805	.5175	.462	.5544	.5175	.5175
4	.5175	.4805	.4805	.462	.5175	.5544	.4805
5	.5175	.5175	.4805	.499	.5175	.5544	.4805
6	.5544	.5914	.5175	.5544	.5359	.6468	.5359
7	.6653	.7023	.5914	.6468	.6468	.7023	.6468
8	.7762	.7947	.7023	.6838	.7577	.7023	.7762
9	.924	.8316	.7762	.8871	.8871	.8316	.8316
10	.9425	1.0903	.8316	.9979		.9979	.8871
11		1.1088	.924	1.1273		1.1458	1.1088
12		1.2012	.9979	1.1088		1.1643	1.2012
13	1.2567	1.2567	.9979	1.1088		1.2197	1.0719
14	1.2382	1.1643	.924	1.1088		1.1458	.961
15	1.0349	1.0349	.8501	.9795		1.0719	1.0534
16	1.0534	1.0164	.8316	.961	1.0164	1.0349	
17	1.0164	1.0903	.7947	.924	.924	1.0164	.961
18	1.2012	1.1827	.924	1.1088	1.1827	1.1827	1.1643
19		1.3491	.9979	1.2936	1.3676	1.3491	1.2936
20		1.3306	.924	1.2936	1.3306	1.3121	
21	1.1088	1.1643	.8501	1.1088	1.1088	1.2567	.961
22	.8501	.8871	.7762	.924	.8871	.8686	.8131
23	.7392	.7577	.7023	.7762	.7023	.7392	.7023
24	.6283	.5914	.6099	.5544	.6468	.5914	.6099
Max	**1.2567**	**1.3491**	**.9979**	**1.2936**	**1.3676**	**1.3491**	**1.2936**
Min	**.5175**	**.4805**	**.4805**	**.462**	**.5175**	**.5175**	**.4805**
Avg	**.8362**	**.9025**	**.7531**	**.8570**	**.8193**	**.9048**	**.8274**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.MARKET Y.[021] BU 4021
Substation No/ Name :- 144103 / 33/11 Kv Gandhinagar
Feeder No / Name : 206 / 11 KV Industrial GANDHINAGAR Feeder KV- 11 / OUTGOING **SHEDDABLE FEEDER HAVING WEEKLY STAGGERING (MIDC, EQUIVALENT)**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.2096	.2096	.1905	.0381	.2286	.2096
2	.1905	.1905	.1905	.1905	.0191	.2096	.1905
3	.1715	.1715	.1905	.1715	.0191	.2096	.1905
4	.1524	.1715	.1715	.1715	.0191	.2286	.1715
5	.1524	.1905	.1715	.2096	.0191	.2286	.1715
6	.1715	.2096	.2096	.1905	.0191	.2477	.2477
7	.1715	.1905	.2667	.2096	.0191	.2477	.2286
8	.1524	.1905	.2096	.1715	.0381	.2096	.1905
9	.2858	.2667	.2477	.0572	.2667	.3048	.2477
10	.2477	.2858	.3048	.0572		.4191	.4191
11	.3048	.381	.381	.1143		.4763	.4191
12	.3429	.362	.3239	1.848		.5335	.4954
13	.3239	.4572	.3048	.1143		.4954	.4191
14	.2858	.2667	.2667	.1143		.362	.362
15	.381	.3429	.2667	.1143		.4191	
16	.3239	.3048	.2286	.1143	.4572	.4572	
17	.381	.2858	.2667	.0953	.381	.4763	.4191
18		.381	.2477	.0762	.381		.3429
19		.3429	.3048	.0762	.4191	.362	.2858
20		.3239	.2858	.0762	.3429	.3429	.3048
21	.2096	.2286	.2096	.0572	.2667	.2286	.2286
22	.2096	.2286	.2286	.0381	.1524	.1905	.2096
23	.1905	.2096	.1905	.0381	.2286	.1905	.1905
24	.1715	.1905	.2096	.2096	.0381	.2286	.2096
Max	**.381**	**.4572**	**.381**	**1.848**	**.4572**	**.5335**	**.4954**
Min	**.1524**	**.1715**	**.1715**	**.0381**	**.0191**	**.1905**	**.1715**
Avg	**.2377**	**.2659**	**.2453**	**.1961**	**.1736**	**.3173**	**.2797**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.MARKET Y.[021] BU 4021
Substation No/ Name :- 144103 / 33/11 Kv Gandhinagar
Feeder No / Name : 401 / 33KV Gandhinagar I/C
Feeder KV- 33 / OUTGOING
NON SHEDDABLE EXPRESS HV FEEDERS (NON-CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4563	1.2883	1.4563	1.2449	1.2883	1.2883	1.3443
2	1.4003	1.2449	1.3443	1.1203	1.1763	1.2323	1.2449
3	1.3443	1.1203	1.3014	1.0642	1.1203	1.2323	1.1883
4	1.2752	1.1763	1.2449	1.0642	1.0642	1.2883	1.1317
5	1.2752	1.2883	1.2323	1.2323	1.0642	1.2883	1.1317
6	1.4969	1.5123	1.4563	1.3443	1.0185	1.5123	1.4146
7	1.8296	1.7924	1.6804	1.6078	1.4563	1.6632	1.6975
8	2.0513	2.0725	2.0165	1.6804	1.6804	1.8484	1.8673
9	2.4086	2.2405	2.2068	1.9605	2.1502	2.1068	2.0936
10	2.4086	2.5766	2.2965	2.0165	2.1845	2.384	2.2731
11	1.4003	2.6326	2.3525	2.6886	3.4168	2.8567	3.3608
12	1.4563	2.8006	2.3525	2.9081	3.6969	3.4751	3.4928
13	2.6612	2.9127	2.2965	2.6063	3.5288	3.4208	3.3608
14	2.4949	2.6326	2.1845	2.7149	3.2487	3.1602	
15	2.4646	2.5766	1.9605	2.552	3.3048	3.1047	
16	2.384	2.4646	1.9404	2.4977	3.1927	3.1493	
17	2.4086	2.5206	2.0165	2.4177	3.0807	3.2922	2.9384
18		2.9127	2.2177	2.5252	3.3819	3.2156	3.2156
19		3.1367	2.4949	2.7166	3.271	3.1047	2.9384
20		3.0807	2.3285	2.6612	3.0807	2.9938	2.7446
21	2.4646	2.6326	2.0725	2.2731	2.5503	2.5206	2.3525
22	2.0165	2.1845	1.9044	1.885	2.0165	2.0165	1.9605
23	1.6244	1.6804	1.6244	1.5364	1.6804	1.6804	1.6244
24	1.4003	1.3443	1.4563	1.3443	1.3443	1.3443	1.4003
Max	**2.6612**	**3.1367**	**2.4949**	**2.9081**	**3.6969**	**3.4751**	**3.4928**
Min	**1.2752**	**1.1203**	**1.2323**	**1.0642**	**1.0185**	**1.2323**	**1.1317**
Avg	**1.8915**	**2.1594**	**1.8932**	**1.9859**	**2.2916**	**2.2991**	**2.1322**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.MARKET Y.[021] BU 4021
Substation No/ Name :- 144105 / 33 KV MIDC
Feeder No / Name : 201 / 11KV SARALASHKAR SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573		.8573	.8573		.8573	.9526
2	.8573		.8573	.8573		.9526	.8573
3	.8573		.9526	.9526		.9526	.8573
4	.8573		.9526	.9526		.8573	.9526
5	.9526		.9526	.8573		.9526	.9526
6	.9526		.9526	.7621	.8573	.9526	.8573
7	.9526		.9526	.7621	.8573	1.0479	.8573
8	1.3336	1.3336	1.3336	.7621	.9526	1.0479	1.3336
9	1.3336	1.2384	1.3336	.6668	1.5242	1.3336	1.3336
10	1.5242	1.8099	1.7147	.6668	1.1431	1.5242	1.4289
11	1.9052	1.9052	2.0005	.7621	1.5242	1.8099	1.8099
12	1.9052	1.8099	1.7147		1.7147	1.7147	1.7147
13	1.7147	1.4289	1.6194	.7621	1.3336	1.6194	1.6194
14	1.5242	1.5242	1.7147	.7621	1.4289	1.8099	1.7147
15	1.9052	2.0005	1.7147	.7621		1.9052	1.9052
16	1.7147	1.9052	1.7147		1.5242	1.5242	
17	1.3336	1.4289	1.6194		1.2384	1.6194	
18		1.6194	1.3336		1.3336	1.4289	1.5242
19		1.1431	1.1431		1.3336	.9526	1.3336
20		.8573	1.2384		1.2384	.9526	1.0479
21		1.3336	1.3336		1.1431	.7621	.9526
22		.9526	1.3336		1.1431	1.0479	.9526
23		.9526	1.2384		.8573	1.1431	.8573
24	.8573		.8573	.9526		.8573	.9526
Max	**1.9052**	**2.0005**	**2.0005**	**.9526**	**1.7147**	**1.9052**	**1.9052**
Min	**.8573**	**.8573**	**.8573**	**.6668**	**.8573**	**.7621**	**.8573**
Avg	**1.2966**	**1.4527**	**1.3098**	**.8065**	**1.2440**	**1.2344**	**1.2167**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.MARKET Y.[021] BU 4021
Substation No/ Name :- 144105 / 33 KV MIDC
Feeder No / Name : 202 / 11 KV MAULI FEEDER MIDC SHEDDABLE FEEDER HAVING WEEKLY
Shirol Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431		1.0479	1.0479		1.2384	1.1431
2	1.1431		1.0479	1.1431		1.2384	1.0479
3	1.1431		1.0479	1.1431		1.1431	1.0479
4	1.1431		1.1431	1.1431		1.2384	1.1431
5	1.0479		1.1431	1.0479		1.1431	1.1431
6	1.0479		1.1431	1.0479	1.0479	1.1431	1.0479
7	1.0479		1.1431	1.0479	1.1431	1.2384	1.0479
8	1.0479	1.1431	1.1431	.9526	1.1431	1.2384	1.2384
9	1.4289	1.3336	1.3336	.9526	1.3336	1.5242	1.4289
10	1.5242	1.5242	1.5242	1.1431	1.4289	1.6194	1.6194
11	1.5242	1.5242	1.6194		1.5242	1.6194	1.5242
12	1.5242	1.5242	1.5242		1.4289	1.3336	1.5242
13	1.3336	1.2384	1.3336	1.0479	1.3336	1.3336	1.4289
14	1.5242	1.4289	1.4289	1.0479	1.6194	1.5242	1.5242
15	1.6194	1.6194	1.5242	1.0479	1.5242	1.5242	
16	1.4289	1.5242	1.4289		1.5242	1.1431	
17	1.4289	1.4289	1.3336		1.4289	1.4289	
18		1.4289	1.3336		1.4289	1.4289	1.3336
19		1.2384	1.2384		1.2384	1.3336	1.4289
20		1.2384	1.2384		1.2384	1.3336	1.2384
21		1.1431	1.1431		1.1431	1.3336	1.1431
22		1.0479	1.1431		1.1431	1.2384	1.3336
23		1.0479	1.0479		1.2384	1.2384	1.3336
24	1.1431		1.1431	1.0479		1.1431	1.1431
Max	**1.6194**	**1.6194**	**1.6194**	**1.1431**	**1.6194**	**1.6194**	**1.6194**
Min	**1.0479**	**1.0479**	**1.0479**	**.9526**	**1.0479**	**1.1431**	**1.0479**
Avg	**1.2913**	**1.3396**	**1.2582**	**1.0615**	**1.3284**	**1.3217**	**1.2792**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.MARKET Y.[021] BU 4021
Substation No/ Name :- 144105 / 33 KV MIDC
Feeder No / Name : 203 / G' BLOCK SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2384		1.3336	1.3336		1.2384	1.2384
2	1.3336		1.3336	1.3336		1.3336	1.3336
3	1.3336		1.5242	1.2384		1.2384	1.3336
4	1.2384		1.5242	1.2384		1.3336	1.2384
5	1.3336		1.4289	1.3336		1.3336	1.3336
6	1.5242		1.5242	1.3336	1.3336	1.3336	1.3336
7	1.6194		1.5242	1.3336	1.5242	1.4289	1.3336
8	1.6194	1.8099	1.4289	1.3336	1.5242	1.6194	1.8099
9	2.0005	1.9052	1.9052	1.2384	1.9052	1.5242	2.0957
10	2.0957	2.2862	2.0957	1.2384	2.0957	1.9052	2.191
11	2.2862	2.572	2.2862	1.2384	2.3815	2.191	2.4768
12	2.4768	2.3815	2.0957	1.2384	1.9052	1.9052	2.0957
13	1.8099	1.8099	1.7147	1.2384	1.9052	1.9052	1.9052
14	1.8099	1.9052	1.9052	1.1431	2.2862	2.0957	
15	2.0957	2.2862	1.9052	1.2384	2.191	2.0957	
16	2.0005	2.4768	1.7147		2.0957	2.191	
17	2.0005	2.0005	1.9052		1.8099	2.0957	
18		1.7147	1.7147		1.7147	1.7147	1.7147
19		1.6194	1.6194		1.7147	1.9052	1.4289
20		1.7147	1.3336		1.6194	1.7147	1.7147
21		1.5242	1.5242		1.4289	1.9052	1.3336
22		1.3336	1.2384		1.2384	1.3336	1.2384
23		1.3336	1.1431		1.2384	1.1431	1.1431
24	1.2384		1.2384	1.1431		1.2384	1.2384
Max	**2.4768**	**2.572**	**2.2862**	**1.3336**	**2.3815**	**2.191**	**2.4768**
Min	**1.2384**	**1.3336**	**1.1431**	**1.1431**	**1.2384**	**1.1431**	**1.1431**
Avg	**1.7253**	**1.9171**	**1.6234**	**1.2622**	**1.7729**	**1.6551**	**1.5765**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.MARKET Y.[021] BU 4021
Substation No/ Name :- 144105 / 33 KV MIDC
Feeder No / Name : 204 / 11 KV Maharashtra Feeder SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716		.5716	.5716		.5716	.6668
2	.5716		.5716	.5716		.5716	.5716
3	.6668		.5716	.5716		.6668	.5716
4	.5716		.0572	.5716		.6668	.6668
5	.5716		.6668	.5716		.6668	.6668
6	.6668		.6668	.5716	.0953	.6668	.6668
7	.6668		.6668	.5716	.0953	.6668	.6668
8	.5716		.5716	.1905	.1905	.5716	.6668
9	.6668	.5716	.6668	.0953	.4763	.6668	.7621
10	.5716	.4763	.6668	.0762	.381	.6668	.5716
11	.6668	.7621	.6668	.0762	.5716	.7621	.7621
12	.6668	.6668	.6668	.0762	.5716	.7621	.6668
13	.381	.6668	.6668	.0762	.5716	.7621	.5716
14		.6668	.6668	.0762	.6668	.7621	
15	.5716	.6668	.6668	.0762	.6668	.6668	
16	.7621	.7621	.6668		.7621	.7621	
17	.6668	.6668	.6668		.6668	.6668	
18		.6668	.6668		.6668	.5716	.6668
19		.5716	.5716		.6668	.6668	.5716
20		.5716	.6668		.6668	.5716	.5716
21		.7621	.6668		.5716	.5716	.5716
22		.5716	.6668		.6668	.7621	.7621
23		.5716	.5716		.6668	.5716	.5716
24	.5716		.5716	.5716		.6668	.5716
Max	**.7621**	**.7621**	**.6668**	**.5716**	**.7621**	**.7621**	**.7621**
Min	**.381**	**.4763**	**.0572**	**.0762**	**.0953**	**.5716**	**.5716**
Avg	**.6108**	**.6414**	**.6136**	**.3322**	**.5345**	**.6629**	**.6383**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.MARKET Y.[021] BU 4021
Substation No/ Name :- 144105 / 33 KV MIDC
Feeder No / Name : 206 / DEVAJI **SHEDDABLE FEEDER HAVING WEEKLY**
Feeder KV- 11 / OUTGOING **STAGGERING (MIDC, EQUIVALENT)**

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3336		1.5242	1.1431		.9526	.9526
2	1.3336		1.5242	1.2384		.8573	.8573
3	1.3336		1.4289	1.2384		.9526	.9526
4	1.5242		1.4289	1.0479		.9526	.9526
5	1.5242		1.5242	1.0479		.8573	.8573
6	1.6194		1.7147	.9526	.8573	.9526	.8573
7	1.7147		1.7147	.9526	.9526	1.1431	.9526
8	1.2384	.9526	1.4289	.7621	1.1431	1.7147	.9526
9	2.2862	1.7147	1.7147	.7621	1.9052	1.7147	1.9052
10	1.8099	2.6673	2.8578	.6668	1.8099	2.0957	2.0957
11	2.0957	2.0957	2.6673	.5716	2.6673	2.572	1.4289
12	2.191	2.0957	2.2862		2.0957	2.2862	1.6194
13	1.9052	1.9052	2.191	.5716	2.572	2.0957	1.9052
14	2.0957	1.7147	2.2862	.5716	2.6673	1.8099	2.572
15	1.7147	1.7147	2.2862	.5716	2.0005	2.0957	2.572
16	2.0957	2.8578	2.191		2.0957	2.0957	
17	1.3336	2.8578	2.2862		1.9052	1.5242	
18		1.9052	1.6194		2.0005	1.3336	2.0005
19		1.5242	1.1431		1.9052	1.7147	1.9052
20		1.3336	.9526		1.1431	1.7147	1.8099
21		1.1431	1.1431		1.1431	1.7147	1.8099
22		1.4289	1.7147		1.0479	1.1431	1.7147
23		1.3336	1.3336		1.1431	1.2384	1.7147
24	1.3336		1.3336	1.3336		1.1431	1.1431
Max	**2.2862**	**2.8578**	**2.8578**	**1.3336**	**2.6673**	**2.572**	**2.572**
Min	**1.2384**	**.9526**	**.9526**	**.5716**	**.8573**	**.8573**	**.8573**
Avg	**1.6935**	**1.8278**	**1.7623**	**.8955**	**1.7253**	**1.5281**	**1.5242**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.MARKET Y.[021] BU 4021
Substation No/ Name :- 144105 / 33 KV MIDC
Feeder No / Name : 401 / 33KV MIDC SHIROLI INCOMER NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / INCOMING (NON-CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.144		5.3155	4.9726		4.9726	4.9726
2	5.2584		5.5441	5.144		4.9726	4.6868
3	5.3155		5.5441	5.144		4.9726	4.7439
4	5.3155		5.6013	4.9726		5.0297	4.9726
5	5.4298		5.7156	4.8583		4.9726	4.9726
6	5.8299		6.0014	4.6868	4.1724	5.0297	4.7439
7	6.0014		6.0014	4.6868	4.5725	5.5441	4.8583
8	5.8871		5.8871	4.0009	4.9726	6.1728	6.0014
9	7.7161	6.7444	6.973	3.7151	7.1445	6.7444	7.5446
10	7.5446	8.7449	8.8592	3.8295	6.8587	7.8304	7.8875
11	8.4591	8.8592	9.2593	3.8295	8.6877	8.9735	8.0018
12	8.7449	8.4591	8.2876	1.3146	7.7161	8.0018	7.6017
13	7.1445	7.0302	7.5446	3.7151	7.7161	7.7161	7.4303
14	6.973	7.2588	8.0018	3.6008	8.6877	8.0018	
15	7.8875	8.4591	8.1162	3.7151	6.4015	8.2876	
16	8.0018	9.5451	7.7161		8.0018	7.7161	
17	6.7444	8.4019	7.8304		7.0302	7.316	
18		7.316	6.6873		7.1445	6.4586	7.2017
19		6.1157	5.7156		6.8587	6.5729	6.6873
20		5.7156	5.4298		5.8871	6.2872	6.4015
21		5.8871	5.8299		5.4298	6.2872	5.8299
22		5.3155	6.1157		5.2584	5.5441	6.0014
23		5.2584	5.3155		5.144	5.3155	5.6013
24	5.144		5.144	4.8583		5.0297	5.0297
Max	**8.7449**	**9.5451**	**9.2593**	**5.144**	**8.6877**	**8.9735**	**8.0018**
Min	**5.144**	**5.2584**	**5.144**	**1.3146**	**4.1724**	**4.9726**	**4.6868**
Avg	**6.5856**	**7.2741**	**6.6015**	**4.1903**	**6.5380**	**6.4062**	**6.0585**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.MARKET Y.[021] BU 4021
Substation No/ Name :- 146001 / 132/33 KV BAPAT CAMP
Feeder No / Name : 401 / 33KV Gandhinagar Feeder KV- 33 / INCOMING
NON SHEDDABLE EXPRESS HV FEEDERS (NON-CONTINOUS PROCESS)(NO STAGGERING)

DATE	25-DEC-17
HR	Load (MW)
24	1.4003
Max	1.4003
Min	1.4003
Avg	1.4003

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.MARKET Y.[021] BU 4021
Substation No/ Name :- 146001 / 132/33 KV BAPAT CAMP
Feeder No / Name : 405 / Shahumill NON SHEDDABLE EHV INDUSTRIAL FEEDERS
Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING

DATE	25-DEC-17
HR	Load (MW)
24	4.401
Max	4.401
Min	4.401
Avg	4.401

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

KOLHAPUR ZONE[050]
KOLHAPUR CIRCLE[500]
KOLHAPUR URBAN DIVISION[111]
KOLHAPUR U.MARKET Y.[021] BU 4021
Substation No/ Name :- 146001 / 132/33 KV BAPAT CAMP
Feeder No / Name : 407 / 33KV Bapat Camp Minor Feeder KV- 33 / INCOMING
NON SHEDDABLE EXPRESS HV FEEDERS (NON-CONTINOUS PROCESS)(NO STAGGERING)

DATE	25-DEC-17
HR	Load (MW)
24	2.7446
Max	2.7446
Min	2.7446
Avg	2.7446