

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214405 / 33 KV OTUR

Feeder No / Name : 201 / Udapur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.096	.0819	.0572	.0566
2	.1174	.0972	.0819	.0572	.0566
3	.1187	.0972	.1006	.0762	.0566
4	.1214	.0983	.1006	.0762	.0566
5	.1387	.116	.1006	.0953	.0754
6	.1387	.116	.1174	.0953	.0943
7	.1387	.1526	.1174	.0953	.0943
8	.2204	.1886	.1475	.1524	.1132
9	.2294	.2058	.1475		.132
10	.1715	.132	.1886	.1698	.2286
11	.1905	.1698	.1698	.2321	.1265
12	.2096	.1886	.1698	.2652	.1296
13	.2096	.1886	.1698	.2818	.1457
14	.1905	.1698	.1886	.2429	.1581
15	.1715	.1698	.132	.2429	.1265
16	.2477	.1698	.1698	.2429	.144
17	.2286	.1698	.1698	.2429	.1389
18	.1715	.1698	.1886		.1638
19	.1334	.1132	.132	.1509	.1334
20	.1143	.1143	.1334	.1509	.1334
21	.0953	.1143	.1143	.132	.1143
22	.0762	.0762	.0953	.1132	.0953
23	.0762	.0762	.0762	.0754	.0953
24	.0566	.112	.0972	.0572	.0566
Max	.2477	.2058	.1886	.2818	.2286
Min	.0566	.0762	.0762	.0572	.0566
Avg	.1510	.1376	.1329	.1502	.1136

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214405 / 33 KV OTUR

Feeder No / Name : 202 / Dumbarwadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3584	.4096	.4119	.3395	.3395
2	.7733	.4096	.4477	.3772	.3395
3	.7922	.4372	.5144	.4338	.3206
4	.8299	.4835	.4954	.4715	.3206
5	.9054	.4835	.6615	.5281	.3772
6	.9808	.5321	.7167	.5847	.4715
7	1.1506	.8579	.7602	.6224	.6413
8	1.6409	.9069	.964	.7167	.6602
9	1.7918	.9896	1.0374	.7167	.7545
10	.443	.5544	.5914	.7733	.7265
11	.6447	.7392	.8299	1.8107	.9335
12		.8131	.8299	2.2068	1.0688
13	.5373	.7762	.811	2.2634	1.1511
14	.7421	.7947	.7392	2.2068	1.1591
15	.9231	.7947	.7733	2.3388	1.1368
16	.9522	.9795	.8676	2.3011	1.1336
17	.8059	.924	.7733	2.2257	1.0642
18	.7682	.6838	.6413	1.8861	.9054
19	.7095	.6224	.6036	.5658	.5658
20	.6161	.547	.547	.4904	.4748
21	.5544	.4715	.4904	.4715	.5093
22	.499	.3921	.4715	.415	.4108
23	.4066	.3361	.3584	.3772	.3326
24	.3584	.4201	.3761	.3018	.3395
Max	1.7918	.9896	1.0374	2.3388	1.1591
Min	.3584	.3361	.3584	.3018	.3206
Avg	.7906	.6399	.6547	1.0594	.6724

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214405 / 33 KV OTUR

Feeder No / Name : 203 / Tikekarwadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2787	.4458	.5796	.3374	.2934
2	.4694	.4458	.6093	.362	.2934
3	.5135	.4607	.639	.4054	.3081
4	.5428	.4904	.6602	.4344	.3521
5	.5721	.5201	.6895	.4633	.3814
6	.6161	.5647	.7188	.5068	.4254
7	.6895	.7628	.7482	.5357	.5281
8	.9095	.8655	.9389	.4923	.6308
9	1.0425	.9412	1.1003	.6895	.8069
10	.6661	.5937	.6015	.7922	.8025
11	.7529	.7095	.7095	1.2616	1.4563
12	.7335	.6516	.7145	1.423	1.467
13	.7188	.6661	.6716	1.2323	1.511
14	.7188	.6516	.643	1.2763	1.448
15	.6748	.7385	.6805	1.3056	1.419
16	.7335	.6661	.6805	1.3937	1.4769
17	.6748	.6805	.5937	1.3496	1.3466
18	.5647	.6661	.5937	1.1443	1.2452
19	.5201	.5068	.5068	.4988	.4778
20	.431	.4633	.4694	.4694	.4778
21	.3715	.4458	.4254	.4401	.4344
22	.3269	.3864	.3814	.3961	.3909
23	.2972	.3269	.3374	.3521	.362
24	.2934	.4755	.5647	.3081	.3081
Max	1.0425	.9412	1.1003	1.423	1.511
Min	.2787	.3269	.3374	.3081	.2934
Avg	.5880	.5886	.6357	.7446	.7768

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214405 / 33 KV OTUR

Feeder No / Name : 204 / otur city

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3801	.3077	.362	.3982	.3292
2	.362	.3109	.3982	.4706	.3292
3	.3696	.3109	.4755	.1602	.3475
4	.3881	.3658	.5487	.6099	.4024
5	.4251	.4435	.6283	.6653	.4755
6	.5175	.5729	.7023	.7392	.5853
7	.7392	.7577	.7392	.8131	.7762
8	.8871	.9055	.7762	.7947	.8316
9	.7964	.7316	.7762		.7762
10	.5967	.6697	.7442	.6154	.6068
11	.5548	.5434	.6556	.57	.5316
12	.5144	.5138	.6201	.5375	.4961
13	.4973	.4784		.5258	.4656
14	.4557	.3898	.631	.5083	.4508
15	.4508	.4207		.4207	.4557
16	.4252	.4075		.4382	.4733
17	.5434	.4557	.8589	.4908	.4557
18	.6344	.567	.8328	.6447	.6154
19	.724	.724	.7619	.7701	1.0679
20	.6697	.6335	.7421	.6447	.6697
21	.5973	.2067	.6516	.5731	.5731
22	.543	.4706	.543	.4706	.5014
23	.4163	.3982	.4344	.3801	.3761
24		.3439	.3439	.3439	.362
Max	.8871	.9055	.8589	.8131	1.0679
Min	.362	.2067	.3439	.1602	.3292
Avg	.5430	.4971	.6298	.5472	.5398

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214405 / 33 KV OTUR

Feeder No / Name : 205 / 11 kV Rohakadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1848	.2561	.2214	
2	.1698	.168	.2926	.2688	.208
3	.1698		.3292	.3429	.2321
4	.1886	.2054	.3921	.4207	.2321
5	.2263	.2452	.4294	.4733	.2652
6	.3395	.3018	.4668	.5258	.3113
7	.4904	.5658	.5228	.5609	.5426
8	.6602	.679	.8676	.8413	.7291
9	.7922	.8865	.8865	.7968	.8002
10	.8775	.9431	1.0374	.5415	.5544
11	.7562	.9339	.8421	.6413	.7356
12	.8535	1.0111	1.0202	.7545	.6602
13	.9181	.9231	.9831	.7545	1.0374
14	1.0031	.7274	.9831	.7733	.9997
15	1.0802	1.0722	.9779	.7545	.9619
16	1.1227	1.004	.9231	.811	.9431
17	.9511	.9339	.8962	.7167	.8865
18	.6447	.8097	.664	.5658	.6224
19	.4854	.4904	.4527	.3772	.3961
20	.4066	.415	.3772	.3206	.3547
21	.3696	.3475	.3086	.2641	.3174
22	.3292	.2926	.2622	.2263	.2561
23	.2534	.2378	.2267	.1886	.2218
24	.1886	.2033	.2195	.1898	.208
Max	1.1227	1.0722	1.0374	.8413	1.0374
Min	.1698	.168	.2195	.1886	.208
Avg	.5611	.5905	.6090	.5138	.5424

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214405 / 33 KV OTUR

Feeder No / Name : 207 / 11 KV SARANI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.381	.5144	.5365	.5868
2	.4338	.381	.5906	.6344	.6001
3	.4527	.362	.6859	.703	.6516
4	.4715	.4001	.7621	.7888	.6687
5	.547	.5144	.8573	.8764	.7545
6	.679	.6668	.9335	.9991	.8573
7	1.0185	1.1431	1.0288	1.0867	1.0166
8	1.226	1.2765	1.3527	1.286	1.335
9	1.4523	1.5051	1.5278	1.1961	1.4255
10	1.448	1.6078	1.5844	.9997	1.0669
11	1.5565	1.6078	1.4752	1.2071	1.1812
12	1.6712	1.7404	1.7736	1.4146	1.1812
13	1.8067	1.8564	1.8067	1.4146	1.2193
14	1.8067	1.7404	1.5746	1.2637	1.2193
15	1.8233	1.7814	1.5415	1.226	1.2193
16	1.7604	1.9062	1.5893	1.3957	1.3146
17	1.6221	1.7368	1.4091	1.2449	1.2384
18	1.3125	1.3765	1.247	1.0562	1.0669
19	.8954	1.0751	.7545	.9431	.9335
20	.7811	.9335	.743	.8488	.8383
21	.6287	.7811	.6859	.7922	.7049
22	.4572	.6287	.6287	.7167	.5716
23	.4954	.4763	.5716	.5847	.4572
24	.415	.4191	.4382	.4694	.5407
Max	1.8233	1.9062	1.8067	1.4146	1.4255
Min	.415	.362	.4382	.4694	.4572
Avg	1.049	1.0957	1.0865	.9869	.9437

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214405 / 33 KV OTUR

Feeder No / Name : 208 / Otur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3437	.2715	.3641	.6636	.6173
2	.3437	.2715	.4607	.7343	
3	.3841	.3109	.5138	.7968	.664
4	.4024	.3881	.6036	.8802	.7287
5	.4755	.4435	.6767	.9442	.8097
6	.5853	.5729	.7316	1.0082	.8745
7	.7682	.9055	.8048	1.0722	1.0277
8	1.0317	1.0164	1.0534	1.3123	1.3923
9	1.2178	1.134	1.3352	1.5043	1.5746
10	1.1443	1.2127	1.4299	.8259	.7108
11	1.749	1.8623	1.8623	1.0242	1.0242
12	1.8461	2.0891	2.1214	1.1706	1.0974
13	1.9044	2.0891	2.119	1.1222	1.134
14	1.9364	2.0243	2.0005	1.1041	1.1157
15	1.9595	2.0325	1.8947	1.1584	1.1222
16	1.9919	2.0005	1.7004	1.1222	1.1222
17	1.5851	1.8138	1.6164	1.0136	1.1584
18	.9412	1.4706	1.4413	.8326	.9694
19	.5731	.7682	.6626	.7011	.7602
20	.5083	.5967	.6154	.631	.567
21	.4382	.4973	.543	.5609	.4681
22	.3601	.4144	.4706	.5258	.3601
23		.3429	.3982	.4908	
24	.3437	.2774	.3258	.6019	.6173
Max	1.9919	2.0891	2.1214	1.5043	1.5746
Min	.3437	.2715	.3258	.4908	.3601
Avg	.9928	1.0336	1.0727	.9084	.9053

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214405 / 33 KV OTUR

Feeder No / Name : 209 / CHILHEWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.381	.4001	.3763	.3125
2	.3772	.362	.5144	.2134	.3125
3	.3772	.3584	.5658	.2439	.3481
4		.3961	.5716	.2667	.3961
5	.4527	.4904	.6287	.2972	.4854
6	.6036	.5975	.679	.3201	.1216
7	.8488	.7468	.7621	.3506	.4178
8	1.1506	1.0317	1.3957	.4633	.5247
9	1.6409	1.3014	1.6409	.4534	1.1961
10	1.8111	1.6409	1.8296	1.4937	1.2197
11	1.1568		1.46	1.6991	
12		.5761	1.0229	1.7924	1.587
13	.7796		1.2597	1.7737	1.5339
14	1.829	1.387	1.5261	1.6244	1.5339
15	1.2437	1.7147	1.4413	1.7364	1.6244
16	1.7337	1.3127	1.2136	1.6617	1.7926
17	.7537	.4298	.4578	1.6991	1.7556
18	.0648	.3906	.4934	1.531	1.7177
19	.9054	.9808	.9431	.9242	1.1128
20	.7545	.9054	.7621	.7167	.811
21	.6224	.679	.6478	.5658	.679
22	.547	.5281	.5144	.4338	.547
23	.4763	.3439	.4001	.3961	.5093
24	.3772	.4191	.362	.3311	.1181
Max	1.829	1.7147	1.8296	1.7924	1.7926
Min	.0648	.3439	.362	.2134	.1181
Avg	.8583	.7715	.8955	.8902	.8981



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214405 / 33 KV OTUR

Feeder No / Name : 210 / 11KV RAVANI INDUSTRIES NON SHEDDABLE EXPRESS HV FEEDERS  
 LTD. Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.0187	.0187	.0185	.0377
2	.184	.0189	.0187	.0187	.0189
3	.1646	.0189	.0152	.0189	.0189
4	.1943	.0189		.0183	.0189
5	.2073	.0183	.0164	.0183	.0189
6	.1907	.0181	.0164	.0183	
7	.0185	.0181	.0164	.0183	.0183
8	.0189	.0179	.0173	.0189	.0189
9	.0187	.0189	.0343	.0762	.0469
10	.0351	.0189	.0189	.0354	.0286
11	.0187	.0554	.0189	.0434	.0189
12	.0187	.0366	.0189	.0627	.0189
13	.0189	.0739	.0189	.0697	.0189
14	.0189	.0189	.0189	.0391	.0187
15	.0189	.0895	.0189	.021	.0187
16	.0189	.1063	.0189	.0469	.0185
17	.0185	.0739	.0189	.0469	.0187
18	.0189	.1109	.0189	.0573	.0189
19	.0185	.0943	.0189	.0587	.0185
20	.0183	.0943	.0183	.0566	.0185
21	.0183	.0943	.0185	.0747	.0183
22	.0181	.0943	.0185	.056	.0181
23	.0183	.0189	.0185	.056	.0185
24	.1715	.0187	.0187		.0549
Max	.2073	.1109	.0343	.0762	.0549
Min	.0181	.0179	.0152	.0183	.0181
Avg	.0674	.0486	.0189	.0413	.0227

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214406 / 33 KV ALE

Feeder No / Name : 201 / Mokshadham SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2587	.2543	.2241	.2801	.3326
2	.208	.2915	.2458	.2801	.2987
3	.2721	.3121	.3437	.2614	.2987
4	.3521	.3467	.4801	.2801	.3361
5	.4588	.4161	.5441	.3734	.4108
6	.4999	.5028	.663	.547	.5228
7	.5639	.7545	.7537	.7468	.7095
8	.8962	1.0277	.9686	.823	.8215
9	1.094	1.1768	1.1603	.9328	.8871
10	.5201	.6401	.7421	.5895	
11	.7087	.6653	.6697	1.012	1.0202
12	.7164	.7207	.6697	1.1702	1.1984
13	.7421	.7762	.6878	1.186	1.166
14		.8131	.6878	1.2018	1.2289
15	.8059	.823	.6878	1.2018	1.2597
16	.8954	.8589	.7059	1.1873	1.2334
17	.8954	.924	.8688	1.1873	1.2346
18	.815	.7499	.823	1.0883	1.1843
19	.6401	.5975	.567	.5121	.6099
20	.5487	.5175	.5487	.4755	.5544
21	.5121	.4668	.4572	.439	.462
22	.3841	.3921	.3841	.3982	.4251
23	.3292	.3734	.3292	.3326	.3696
24	.2743	.2012	.2957		.3326
Max	1.094	1.1768	1.1603	1.2018	1.2597
Min	.208	.2012	.2241	.2614	.2987
Avg	.5822	.6084	.6045	.7177	.7346

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214406 / 33 KV ALE

Feeder No / Name : 203 / Rajuri

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5493	.7116	.8002	.5975	.5544
2	.9149	.779	.8356	.5975	.5228
3	.9774	.9221	1.0774	.5788	.5228
4	1.1271	1.0898	1.3413	.5788	.5658
5	1.2431	1.3077	1.5893	.7842	.7733
6	1.6575	1.6263	1.8023	1.1203	1.1128
7	2.2211	2.0119	2.1548	1.4937	1.3957
8	2.7686	2.7328	2.8509	1.4937	1.4335
9	3.1161	3.2487	3.1295	1.2803	1.2752
10	.7209	.7499	.8859	1.1694	
11	.985	1.0082	1.0719	2.7526	2.9984
12	1.0387	1.0534	1.0719	3.2226	3.2442
13	1.0808	1.0242	1.0719	3.2065	3.3261
14		1.0829	1.0317	3.2226	3.2388
15	1.1641	1.1203	.985	3.1903	3.1786
16	1.2536	1.1763	1.0745	3.1741	3.0445
17	1.3466	1.2851	1.1163	3.0283	
18	1.3176	1.3306	1.2851	2.5911	2.0325
19	1.3491	1.2696	1.2567	1.1706	1.1765
20	1.1827	1.1694	1.2382	1.0974	1.0974
21	1.0608	1.0751	1.0164	1.0242	.905
22	.9511	.9431	.8871	.8326	.7421
23	.7343	.7655	.7392	.6584	.567
24	.5847	.7225	.6099		.5853
Max	3.1161	3.2487	3.1295	3.2226	3.3261
Min	.5493	.7116	.6099	.5788	.5228
Avg	1.2759	1.2586	1.2885	1.6898	1.5588

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214406 / 33 KV ALE

Feeder No / Name : 204 / Ale

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2427	.2263	.2402	.1791	.1791
2	.2218	.2263	.2427	.1791	.1829
3	.2241	.3018	.2427	.1612	.1829
4	.2987	.3395	.2987	.181	.2195
5	.3734	.3772	.3547	.181	.2195
6	.4854	.4338	.4108	.2033	.2561
7	.6348	.4715	.5228	.3292	.3292
8	.5853	.5093	.5853	.3988	.4119
9	.4854	.5415	.5041	.3944	.3641
10	.3439	.4251	.3881	.3258	
11	.3401	.3353	.3258	.4066	.3547
12	.3277	.4191	.3258	.3511	.3547
13	.3277	.3856	.3086	.3511	.3511
14		.3856	.2458	.3511	.3511
15	.3239	.3688	.1943	.3696	.3511
16	.3521	.3521	.2591	.3658	.362
17	.3041	.3647	.3277	.3439	
18	.3277	.3944	.2883	.4251	.543
19	.499	.5975	.462	.499	.5121
20	.462	.5041	.4805	.4572	.4854
21	.462	.462	.4435	.4755	.4066
22	.3881	.3841	.3921	.3841	.3696
23	.2987	.3174	.2772	.3174	.2772
24	.2587	.2427	.1772		.1791
Max	.6348	.5975	.5853	.499	.543
Min	.2218	.2263	.1772	.1612	.1791
Avg	.3725	.3902	.3458	.3318	.3292

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214406 / 33 KV ALE

Feeder No / Name : 205 / Wadgaon Kandali

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2402	.3563	.3768	.2801	.2033
2	.3429	.3932	.4191	.2801	.1867
3	.426	.4641	.4475	.2801	.1867
4	.4915	.503	.4801	.2987	.2241
5	.5571	.503	.4999	.3361	.2801
6	.6203	.5365	.5571	.3547	.3734
7	.6962	.663	.6464	.4294	.4481
8	.7712	.8122	.8322	.462	.5359
9	.8619	.8288	.8848	.5121	.5544
10	.2947	.3292	1.2489	.4477	
11	.362	.4251	.4572	.6562	
12	.4024	.4294	.4207	.8322	
13	.4024	.4938	.4024	.8002	.9069
14		.5121	.4024	.8002	.9393
15	.4163	.5304	.439	.8002	.9442
16	.4572	.567	.4344	.7202	1.0202
17	.4706	.6219	.4344	.6081	.9488
18	.4557	.6036	.5014	.5441	.8162
19	.439	.5359	.4207	.4207	.462
20	.3841	.462	.4207	.3658	.3696
21	.3658	.4024	.3292	.3292	.3326
22	.3475	.3696	.2743	.2926	.2772
23	.2743	.3292	.2378	.2561	.2195
24	.2427	.3086	.2033		.2033
Max	.8619	.8288	1.2489	.8322	1.0202
Min	.2402	.3086	.2033	.2561	.1867
Avg	.4488	.4992	.4904	.4829	.4968

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214406 / 33 KV ALE

Feeder No / Name : 206 / Alephata

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5138	.543	.5784	.543	.5487
2	.5304	.5487	.5493	.543	.5487
3	.5316	.6036	.5375	.5249	.5304
4	.5959	.6401	.6001	.543	.5304
5	.6859	.6767	.7011	.5853	.5729
6	.8149	.7499	.7796	.6653	.6283
7	.9568	.9412	.8063	.8871	.9425
8	1.0974	1.1222	1.1096	.9492	1.1706
9	1.1871	1.0985	1.0288	1.0166	1.0099
10	1.1768	1.0974	1.1831	1.1469	
11	1.1869	1.258	1.2934	1.166	
12	1.1869	1.1789	1.2403	1.1361	
13	1.153	1.0802	1.1694	1.1022	1.2136
14		1.1145	1.0852	1.0682	1.1869
15	1.0682	1.1789	1.0513	1.0174	1.1401
16	1.1145	1.2757	1.0974	1.0174	1.1065
17	1.1869	1.2346	1.1831	1.0513	1.1105
18	1.2517	1.283	1.1393	1.2048	1.2445
19	1.267	1.3112	1.1765	1.1946	1.2048
20	1.1462	1.2048	1.1584	1.0745	1.1641
21	.985	1.0288	.9593	.9774	.985
22	.8238	.8669	.8507	.8059	.7796
23	.6733	.6836	.7059	.6447	.6556
24	.5487	.567	.5611		.5611
Max	1.267	1.3112	1.2934	1.2048	1.2445
Min	.5138	.543	.5375	.5249	.5304
Avg	.9427	.9703	.9394	.9072	.8969

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214406 / 33 KV ALE

Feeder No / Name : 207 / KALAMJAI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4854	.5228	.4481	.5935	.4973
2	.462	.5281	.4481	.5935	.503
3	.4668	.5658	.5601	.5935	.5365
4	.5975	.6602	.6283	.6859	.6371
5	.8402	.7922	.7762	.8573	.7042
6	.9709	.9619	1.0059	1.0454	1.0395
7	1.2696	1.1576	1.2696	1.6301	1.5257
8	1.2936	1.4003	1.5708	1.9547	2.0285
9	1.3352	1.475	1.7193	2.1033	2.1704
10	1.379	1.46	1.6078	.8954	
11	1.8187	1.9616	2.2131	1.1458	1.0719
12	2.2119	2.2211	2.0622	1.1273	1.1088
13	2.2283	2.2775	2.0178	1.134	1.0534
14		2.2405	2.0008	1.1523	1.1088
15	2.2119	1.6385	1.8515	1.1706	1.1088
16	2.1628	2.1879	2.0056	1.262	1.1827
17	1.6964	1.9044	2.1051	1.3352	1.2437
18	1.5432	1.8233	1.8399	1.2254	1.1888
19	.8131	.8779	.7392	.9877	1.0164
20	.7947	.8501	.7207	.9145	.8686
21	.7316	.7316	.6468	.8413	.7947
22	.6584	.5853	.6099	.695	.695
23	.567	.5175	.5729	.6099	.5729
24	.4938	.5359	.4862		.4807
Max	2.2283	2.2775	2.2131	2.1033	2.1704
Min	.462	.5175	.4481	.5935	.4807
Avg	1.1753	1.2449	1.2461	1.0675	1.0060

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214406 / 33 KV ALE

Feeder No / Name : 208 / 11 KV RAMDAS SWAMI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1294	.12	.1326	.1294
2	.1475	.1227	.1311	.1109
3	.1966	.1402	.1326	.1109
4	.2343	.1753	.1658	.1294
5	.2561	.2103	.2347	.1494
6	.3113	.2454	.2818	.1886
7	.3768	.373	.3647	.3018
8	.5304	.5087	.5407	.2743
9	.5533	.5365	.5281	.2534
10	.1865	.2033	.2481	.2035
11	.2378	.2054	.2353	.4161
12	.2353	.2054	.2353	.5344
13	.2507	.1867	.2353	.5281
14		.2241	.2328	.5668
15	.2149	.2427	.2481	.5506
16	.2149	.2587	.2427	.4801
17	.1949	.3142	.2572	.4641
18	.1907	.2801	.2507	.426
19	.2195	.2587	.2534	.2195
20	.2033	.2241	.2353	
21	.1829	.2054	.2172	
22	.1629	.1848	.181	
23	.1448	.168	.1448	
24	.1254	.1341	.128	
Max	.5533	.5365	.5407	.5668
Min	.1254	.12	.128	.1109
Avg	.2391	.2387	.2441	.3178



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214429 / 33 KV BELHE

Feeder No / Name : 202 / Gunjalwadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.439	.3174	.4715	1.6057	1.576
2	.439		.415	1.6057	1.576
3	.6401	.2987	.5658	1.643	1.576
4	.7316	.3547	.7167	1.8442	1.8442
5	.823	.5415	.8488	1.9662	2.7831
6	.9145	.7282	.9431	2.3137	3.1017
7	1.0059	.8589	.9808	3.2606	3.3699
8	.8413	.7095	.9054	4.0962	4.1747
9	.6401	.5975	.8488	4.1289	4.225
10	.4755	.6535	.6413	.5847	.5853
11	3.9323	4.9794	3.9903	.5281	.4854
12	3.8504	5.168	4.4932	.3772	.4668
13		5.3567	4.3926	.5658	.5601
14	4.7024	5.0737	3.9064	.6413	.5601
15	4.26	4.904	4.1244	.5658	.5228
16		5.583	4.225	.7167	.5788
17	3.5883	5.3001	4.3591	.7167	.6722
18	3.5227	4.3947	3.8226	.7545	.7468
19	.7842	.7167	.7356	.8413	.8215
20	.7282	.8299	.6979	.695	
21	.6348	.583	.6602	.5853	
22	.5788	.5316	.5847	.4938	
23	.5041	.5144	.5281	.4207	
24	.4572	.3174	.4715	1.8484	1.576
Max	4.7024	5.583	4.4932	4.1289	4.225
Min	.439	.2987	.415	.3772	.4668
Avg	1.5679	2.1440	1.8470	1.3666	1.5901

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214429 / 33 KV BELHE

Feeder No / Name : 203 / Ane

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.9831	1.1317	.6036	.5853
2	1.0227	.9831	1.1317	.6036	.5853
3	1.3413	1.0814	1.5844	.6036	.5853
4	1.5424	1.1469	1.8861	.6602	.695
5	1.6598	1.3108	2.1691	.7202	.823
6	1.8107	1.5238	2.4143	.9619	.9145
7	2.0454	2.13	2.452	1.1694	1.1706
8	2.5819	2.0481	3.3008	1.094	1.0425
9	2.6993	2.13	3.3951	.9808	.9511
10	.5853	.5415	.7922	.547	.7316
11		.547	.6584	2.5463	
12	.4854	.5658	.5121	3.3008	1.9989
13	.4854	.4715	.439	3.1722	2.2939
14	.4854	.4527	.439	3.7723	2.8182
15		.6602	.4024	3.5837	2.6707
16	.5121	.5281	.4572	3.5271	2.7526
17		.5658	.5487	3.0007	2.7199
18	.7468	.6602	.6767	2.7435	2.2939
19	1.0082	.8488	.6224	.9511	.9709
20	.9335	1.0185	.8676	.8413	
21	.8215	.8865	.7922	.7682	
22	.7095	.7922	.7167	.695	
23	.6535	.6001	.6413	.6219	
24	.5487	.9995	.8676	.6036	.5853
Max	2.6993	2.13	3.3951	3.7723	2.8182
Min	.4854	.4527	.4024	.547	.5853
Avg	1.1061	.9782	1.2041	1.5863	1.4310

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214429 / 33 KV BELHE

Feeder No / Name : 204 / MALGANGA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.5571	.8488	.3206	.2743
2	.8048	.6554	.9054	.3206	.2743
3	.9724	.7373	1.4146	.3206	.2743
4	1.1736	.8192	1.8107	.3772	.3292
5	1.4251	.9175	1.8861	.4338	.4572
6	1.6766	.9962	2.0748	.463	.5487
7	1.9448	1.5238	2.3577	.679	.6767
8	2.3472	1.6057	2.8292	.6979	.6219
9	2.1795	1.4419	2.8669	.6224	.5121
10	.3292	.2987	.5281	.3429	.4207
11	.2801	.3601	.3292	2.7349	2.3899
12	.1677	.3601		3.3008	2.3266
13		.2743	.2743	2.915	2.894
14	.2801	.2641	.2561	3.3608	2.9874
15		.2641	.2743	3.0556	2.4086
16	.2801	.3395	.2926	3.0007	2.6513
17	.3174	.3961	.3292	2.7349	2.5953
18	.3547	.4715	.4572	2.452	1.8023
19	.5415	.6036	.9808	.5487	.5281
20	.5228	.7167	.5658	.5121	
21	.4854	.6224	.5093	.439	
22	.3734	.6602	.4338	.3841	
23	.2801	.3772	.3772	.3109	
24	.2743	.5898	.6859	.3206	.2743
Max	2.3472	1.6057	2.8669	3.3608	2.9874
Min	.1677	.2641	.2561	.3109	.2743
Avg	.7857	.6605	1.0125	1.2770	1.2624

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214429 / 33 KV BELHE

Feeder No / Name : 205 / PATILMALA CANOL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2801	.2829	.7922	.9054
2	.2743	.2614	.2829	.7922	.9054
3	.2743	.2614	.2829	.7922	.9877
4	.3109		.2829	.9242	1.0227
5	.3475	.2801	.3772	1.0374	1.1904
6	.3841	.2987	.3772	1.226	1.6598
7	.4207	.3734	.4715	1.6409	1.7939
8	.4572	.4108	.3772	2.037	2.2298
9	.3658	.2987	.3772	2.2257	2.1628
10	.3292	.2614	.3772	.2075	.0366
11	2.2119	2.332	2.4143	.3772	.2987
12	2.2939	2.5463	2.6993	.2829	.2801
13	2.2939	2.5463	2.4646	.2829	.4294
14	2.6513	2.3148	2.5987	.2829	.2427
15		2.5463	2.6155	.2829	.2241
16	2.2939	2.4863	2.4813	.3772	.2427
17	2.1628	2.7349	2.4143	.3772	.2614
18	2.0481	2.452	2.1125	.3772	.2801
19	.3292	.4527	.3772	.4938	.2987
20	.3734	.5093	.3772	.4755	
21	.3361	.415	.3772	.4755	
22	.2987	.3772	.3018	.3475	
23	.2614	.2829	.2641	.3292	
24	.2743	.2801	.2829	.7042	.9054
Max	2.6513	2.7349	2.6993	2.2257	2.2298
Min	.2614	.2614	.2641	.2075	.0366
Avg	.9247	1.0870	1.0529	.7142	.8179

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214429 / 33 KV BELHE

Feeder No / Name : 206 / BELHE GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8488	.6413	.7545	.6979	.7545
2	.8488	.6413	.7545	.6979	.7545
3	.7922		1.0185	.7356	.8488
4	1.0185	.7095	1.226	.9054	1.0185
5	1.1317	.9335	1.358	1.0751	1.1317
6	1.2449	1.2071	1.4146	1.2071	1.2449
7	1.4003	1.4632	1.5089	1.5466	1.4146
8	1.4784	1.531	1.5844	1.5466	1.5089
9	1.3717	1.2696	1.4146	1.5089	1.4146
10	1.0974	1.1576	1.2071	1.226	1.1317
11	1.0185	1.2071	1.0974	1.0185	.5853
12	.8962	.9808		1.1694	.6722
13	.8962	.7545	1.0242	1.1317	.7468
14		.7545	.9145	.9054	.7095
15	.8589	.7545	.9511	.9808	.6722
16	.8215	.7922	1.0242	1.0185	.7095
17		.8488	1.0974	1.1317	.6722
18	1.2323	1.2071	1.3306	1.226	.9431
19	1.3443	1.5089	1.2826	1.5089	1.2136
20	1.2696	1.5844	1.2826	1.5844	
21	1.1949	1.358	1.0562	1.3203	
22	1.0082	1.1317	.9808	1.1694	
23	.8215	.8488	.7922	.9431	
24	.8488	.679	.7545	.6979	.7545
Max	1.4784	1.5844	1.5844	1.5844	1.5089
Min	.7922	.6413	.7545	.6979	.5853
Avg	1.0656	1.0419	1.1230	1.1230	.9451

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214429 / 33 KV BELHE

Feeder No / Name : 207 / GUNJALWADI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545		.6602	.6036	.7167
2	.7545	.4481	.6602	.6036	.7167
3	.7167		.8488	.6036	.7922
4	.9619	.5601	.9774	.8488	.9619
5	1.2071	.7468	1.3203	1.0374	1.2071
6	1.3203	1.1706	1.3957	1.2826	1.3203
7	1.4003	1.3817	1.4523	1.3032	1.4146
8	1.4415	1.419	1.5089	1.358	1.4712
9	1.3169	.8192	1.4146	1.0562	1.358
10	1.0608	.8676	1.0288	.8865	1.0562
11	.7468	.8299	1.0242	.8488	.9145
12	.8589	.7545	.9877	1.0185	.823
13		.7545	.9145	.9054	.7468
14	.6348	.6224	.823	.7922	.6226
15	.6722	.5658	.8779	.9054	.5487
16		.6602	.9694	.9242	.7316
17	.7682	.7167	1.0425	1.0751	.8589
18	.9709	1.1317	1.2567	1.1694	
19	1.1576	1.5089	1.2071	1.4712	
20	.9709	1.4146	1.1883	1.5089	
21	.8589	1.2071	.9808	1.2071	
22	.7468	.9619	.9054	.9431	
23	.6161	.7922	.7545	.8488	
24	.7545	.4527	.6602	.6036	.7167
Max	1.4415	1.5089	1.5089	1.5089	1.4712
Min	.6161	.4481	.6602	.6036	.5487
Avg	.9405	.8994	1.0358	.9919	.9432

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214429 / 33 KV BELHE

Feeder No / Name : 208 / ANE GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6602	.4481	.5658	.5658	.6413
2	.6602	.4481	.5658	.5658	.6413
3	.7167	.4854	.9054	.7167	.7167
4	1.0185	.5228	1.1317	.9242	1.0185
5	1.1317	.7468	1.0974	1.0995	1.1317
6	1.226	1.3443	1.3203	1.5278	1.226
7	1.3817	1.4632	1.4146	1.7353	1.3957
8	1.423	1.4815	1.3717	1.358	1.4523
9	1.3352	.8779	1.3203	1.1128	1.3957
10	1.0242	.3734	1.0185	.7545	1.0562
11	.5975	.9054	.9145	.8488	.5121
12	.5228	.7733	.8779	.9619	.4481
13		.547	.8048	.8299	.4024
14	.4854	.4715	.7682	.7545	.4481
15	.5121	.415	.8413	.8488	.4854
16	.4755	.6413	.9145	.8865	.5228
17	.6348	.7167	.9877	1.0185	.5853
18	.7682	1.0185	1.2012	1.1317	.7545
19	1.1706	1.3014	1.358	1.358	1.1203
20	1.0082	1.4146	1.1506	1.4335	
21	.8962	1.1317	.9808	1.1317	
22	.7842	.8865	.9054	1.0185	
23	.5601	.6036	.7167	.8488	
24	.6602	.4854	.5658	.5658	.6413
Max	1.423	1.4815	1.4146	1.7353	1.4523
Min	.4755	.3734	.5658	.5658	.4024
Avg	.8545	.8126	.9875	.9999	.8298

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214460 / 33 KV KOLWADI

Feeder No / Name : 201 / Madh

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7202	.9431	.6443	.7162	.7202
2	.6859	1.1317	.6859	.6859	.7202
3	.6935	1.3375	.7202	.8276	.7802
4	.7455	1.4746	.7888	1.1207	.8495
5	1.0566	1.6476	1.1104	1.2109	1.0402
6	1.3969	1.7551	1.3253	1.3523	1.543
7	1.7909	1.8267	1.8267	1.6735	1.8204
8	1.9982	1.7177	2.0157	1.5415	1.6057
9	2.2365	1.6651	2.1735	1.4057	1.5565
10	.5365	1.9244	.7956	1.1642	.9686
11	.7209	.9602	.9221		2.4006
12	.9061	.9686	1.1155	2.2552	2.4006
13	.8905	.9488	1.1469	2.3739	2.3663
14	.8749	.8697	1.2146	2.5265	2.332
15	.8592	.9374	1.2557	2.4587	2.2805
16	.9105	.9998	1.2727	2.4926	2.2462
17	.9555	1.0402	1.3077	2.323	2.2119
18	.8745	1.1797	1.4502	1.9719	2.0631
19	.7773	1.2003	1.6241	1.5261	1.4413
20	.7377	1.1488	1.3702	1.3889	1.2887
21	.6706	.8817	1.1736	1.3032	1.1869
22	.6371	.7461	1.0791	1.2003	1.1191
23	.57	.5765	.8817	.9945	.8745
24	.7373	.6706	.6443	.7647	.7373
Max	2.2365	1.9244	2.1735	2.5265	2.4006
Min	.5365	.5765	.6443	.6859	.7202
Avg	.9576	1.1897	1.1894	1.5338	1.5231



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214460 / 33 KV KOLWADI

Feeder No / Name : 202 / Ballalwadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8316	1.0164	.7545	.644	.7468
2	.8316	1.1088	.7545	.7296	.7164
3	.7545	1.2012	.5658	.8192	.8059
4	.9431	1.4003	.5658	.9326	.8059
5	1.0374	1.587	.7545	1.0391	.8859
6	1.226	1.6975	.7468	1.1331	.9745
7	1.3203	1.8861	1.307	1.316	1.0631
8	1.9605	2.1472	2.2405	1.6918	1.5089
9	2.4025	2.2405	2.2177	1.8317	1.8778
10	2.2177	2.4272	2.0328	1.5181	1.8442
11	2.2786	2.4006	2.0553	1.9204	1.8671
12	2.3472	2.3739	2.2043	2.0119	2.0538
13	2.6825	2.2891	2.1314	2.1033	1.9605
14	2.5987	2.3472	2.2043	2.1033	1.9605
15	2.5987	2.3472	2.0119	2.0538	2.1472
16	2.2634	2.3472	***	2.0538	2.2405
17	2.0957	2.2043	1.9456	1.9605	2.1472
18	2.0119	1.6766	1.7128	1.6804	2.0538
19	1.9719	1.4937	1.3875	1.4937	1.587
20	1.5775	1.3203	1.307	1.307	1.4003
21	1.3432	.9431	1.195	1.2136	1.2136
22	1.2012	.7545	.9986	.9335	1.1203
23	1.1088	.7545	.905	.8402	.9335
24	.8316	1.0164	.7545	.7202	.7468
Max	2.6825	2.4272	20.2332	2.1033	2.2405
Min	.7545	.7545	.5658	.644	.7164
Avg	1.6848	1.7075	2.2078	1.4188	1.4442

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214460 / 33 KV KOLWADI

Feeder No / Name : 203 / Pimplegaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.462	.5544	.3772	.1932	.3734
2	.462	.5544	.3772	.1621	.3582
3	.4715	.6468	.3772	.1638	.3582
4	.4715	.7468	.3772	.2543	.3582
5	.4715	.7468	.4668	.2598	.3544
6	.4715	.8488	.5601	.3487	.3544
7	.4715	.8488	.7468	.3509	.3544
8	.8962	.8402	.9335	.3384	.4191
9	1.0164	.8402	1.1088	.4995	.503
10	.5544	1.0269	.5544	.6642	.503
11	.6135	.6859	.5138	.7316	.8402
12	.6706	.6783	.5087	.9145	.8402
13	.6706	.6783	.5115	1.0059	.7468
14	.6706	.5868	.4239	1.0059	.7468
15	.6706	.5868	.4191	1.1203	1.0269
16	.7545	.503	.4215	1.1203	1.1203
17	.6706	.503	.423	1.1203	1.0269
18	.6706	.503	.4282	1.0269	.9335
19	.6859	.5601	.6475	.9335	.8402
20	.6135	.5658	.5601	.8402	.7468
21	.6268	.4715	.4596	.5601	.5601
22	.5544	.3772	.4539	.5601	.5601
23	.5544	.3772	.362	.4668	
24	.462	.5544	.3772	.2401	.3429
Max	1.0164	1.0269	1.1088	1.1203	1.1203
Min	.462	.3772	.362	.1621	.3429
Avg	.6099	.6369	.5162	.6201	.6203

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214460 / 33 KV KOLWADI

Feeder No / Name : 204 / Aalme SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.462	1.5154	.415	.6762	.4481
2	.4435	1.3676	.415	.7134	.4298
3	.5093	1.2197	.4527	.852	.4477
4	.6224	1.1203	.5658	1.153	.5194
5	.7922	1.1203	.5975	1.2989	.6379
6	.9242	1.0751	.7468	1.3946	1.1871
7	.9997	1.0751	***	1.5617	1.4706
8	.9522	1.0082	.9709	1.6918	1.5927
9	1.1458	.9709	.7577	1.7484	1.5089
10	1.0164	1.1203	.8316	.5503	1.291
11	1.6476	1.9204	1.7128	.6401	.8589
12	2.146	2.0178	1.8143	.8779	1.0456
13	2.1293	2.0348	1.8757	1.0751	1.1203
14	2.1125	2.0454	2.0348	1.0242	1.0829
15	2.0957	2.0454	1.9784	1.0082	1.0269
16	2.0454	2.0454	2.0065	1.0082	.9709
17	1.9113	2.0008	1.9456	.9896	.9522
18	1.7436	1.4419	1.7128	.9709	.9522
19	1.7147	.8962	.9065	1.0456	1.0269
20	1.7353	.9242	.9709	.9149	.9335
21	1.773	.7545	.8273	.8215	.8029
22	1.8111	.6036	.5992	.6722	.5788
23	1.8111	.4904	.543	.5788	
24	.4805	1.7372	.4338	.6722	.5228
Max	2.146	2.0454	10.1197	1.7484	1.5927
Min	.4435	.4904	.415	.5503	.4298
Avg	1.3760	1.3563	1.4681	.9975	.9308

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214460 / 33 KV KOLWADI

Feeder No / Name : 205 / Stone Crusher

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0341	.0514
2				.0514	
3				.069	
4				.0517	
5				.0346	
7		.0358			
10	.0335	.0347	.0332		
11		.0343	.0335		
12		.0312	.0328		
13	.0469	.0633	.0164		
14	.0312	.0791	.0509	.017	
15	.0156	.0469	.0322	.017	
16			.0318	.017	
17				.017	
18				.0343	.0173
19				.0343	.017
20				.0373	.017
21				.0343	.0509
22				.0343	.0509
23				.0514	
24					.0514
Max	.0469	.0791	.0509	.069	.0514
Min	.0156	.0312	.0164	.017	.017
Avg	.0318	.0465	.0330	.0356	.0366

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214519 / 33 KV PIMPRI PENDHAR

Feeder No / Name : 201 / KHAMUNDI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.4287	.3429	.2401	.1981
2	.2572	.5316	.463	.2743	.1981
3	.3086	.6687	.5144	.3086	.2134
4	.3601	.7716	.7373	.4115	.2134
5	.4115	.9088	.823	.4801	.2743
6	.463	.9774	.9431	.5487	.3658
7	.7888	1.046	1.1488	.6687	.5182
8		1.2689	1.2346	.6516	.5639
9	1.3032	1.4918	1.286	.6516	.5182
10	1.166	.6859	.5316	.6344	.3944
11	.9602	.6687	.6687	1.1831	1.1126
12		.6859	.823	1.4746	1.2498
13	.7545	.6859	.7888	1.5261	1.2498
14	.7545	.7888	.7545	1.5432	1.2803
15	.7373	.823	.8573	1.5432	1.2955
16	.7202	.8402	.9088	1.2651	1.2193
17	.703	.8059	.8916	1.2498	1.1126
18	.6344	.6687	.6859	.9907	.9602
19	.5658	.6001	.6001	.4572	.4572
20	.5144	.5316	.5316	.3963	.4268
21	.4458	.4973	.4973	.3658	.381
22	.4115	.4115	.4287	.3201	.3048
23	.3772	.3429	.3772	.2286	.2743
24	.2743	.3086	.2743	.2401	.2134
Max	1.3032	1.4918	1.286	1.5432	1.2955
Min	.2572	.3086	.2743	.2286	.1981
Avg	.5994	.7266	.7130	.7356	.6248

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214519 / 33 KV PIMPRI PENDHAR

Feeder No / Name : 202 / JAMBHULPAT SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1886	.2743	.1372	.1372
2	.1372	.2401	.3601	.1715	.1372
3	.1715	.3086	.3944	.2058	.1543
4	.2058	.3601	.4287	.2401	.1715
5	.2572	.4458	.5487	.3086	.2058
6	.2915	.4801	.6516	.3429	.2743
7	.4801	.5144	.6687	.3944	.4115
8		.6344	.6859	.4115	.4458
9	.6516	.7545	.6516	.4115	.463
10	.6173	.3086	.2401	.3772	.3944
11	.583	.3258	.2915	.5144	.5144
12	.5487	.3258	.3429	.6687	.5658
13	.5144	.3429	.3429	.6859	.5658
14	.5144	.3429	.3601	.6859	.5487
15	.5316	.4287	.3772	.6687	.5487
16	.5144	.4973	.3944	.7545	.583
17	.5144	.4801	.3772	.6687	.5335
18	.4287	.3601	.3429	.5316	.5658
19	.3601	.3772	.3258	.2743	.2743
20	.2572	.3429	.3086	.2572	.2743
21	.2058	.2915	.2915	.2401	.2915
22	.1886	.2058	.2572	.2058	.2572
23	.1543	.1715	.2058	.1886	.1715
24	.1372	.1372	.1715	.1715	.1543
Max	.6516	.7545	.6859	.7545	.583
Min	.1372	.1372	.1715	.1372	.1372
Avg	.3653	.3694	.3872	.3965	.3602

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214519 / 33 KV PIMPRI PENDHAR

Feeder No / Name : 203 / NAVLEWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3944	.3086	.2743	.2591
2	.2915	.463	.3429	.3429	.2743
3	.3429	.5487	.3429	.3772	.2896
4	.4115	.6173	.3601	.4115	.3201
5	.5144	.7202	.3772	.6001	.3963
6	.6001	.7716	.4287	.8916	.4877
7	.7716	.823	.5316	.8916	.8078
8		.7545	.6173	1.0288	.9755
9	.7888	.6687	.6516	1.0974	1.0212
10	.9259	.8573	.6001	.3772	.3658
11	1.0974	1.0802	.6001	.5487	.381
12	1.2003	1.0288	.9602	.6001	.442
13	1.3032	.9259	1.166	.5658	.4877
14	1.3032	.9602	1.166	.6001	.5792
15	1.286	1.2003		.6344	.5792
16	1.286	1.3717	1.2003	.5639	.5639
17	1.286	1.1488	1.0974	.583	.5944
18	1.0974	1.1488	1.0117	.583	.5792
19	.7716	.6687	.5487	.583	.4572
20	.7716	.5487	.5487	.4572	.381
21	.5658	.5144	.4801	.4115	.4268
22	.463	.3944	.4115	.3658	.3506
23	.3601	.3601	.3601	.3048	.2896
24	.3429	.3086	.3086	.3086	.2743
Max	1.3032	1.3717	1.2003	1.0974	1.0212
Min	.2915	.3086	.3086	.2743	.2591
Avg	.7865	.7616	.6270	.5584	.4826

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214531 / 33/11 KV NETWAD SUBSTATION

Feeder No / Name : 203 / Netwad SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.5144	.2812	.2824	.3658
2	.3315	.5144	.3749	.2934	.3963
3	.4096	.5144	.4744	.3475	.4572
4	.2172	.6001	.5601	.3715	.5468
5	.5898	.6859	.7042	.4687	.6249
6	.7377	.8288	.8097	.6706	.7116
7	.9389	.9945	1.1469	.7209	.759
8	1.1065	1.1768	1.3426	.759	.9036
9	1.3117	1.5083	1.4083	.9783	.8916
10	1.0802	1.0997	.5681	1.3927	1.0669
11	1.0059	1.1443	.9728	1.7072	1.3765
12	.9808	.724	.9869	1.9113	1.6766
13	1.0105	.8977	.9305	1.8896	1.7772
14	1.0269	.9556	.9869	1.8564	1.7772
15	1.0709		1.0153	1.8233	1.6385
16	1.0715	.9122	1.0425	1.8067	
17	1.086	1.0002	.9976	1.6221	1.3927
18	.8688		.8109	1.3077	
19	.8916	.743	.6622	.8002	
20	.743	.6706	.6718	.5601	
21	.6859	.6009	.4687	.4938	
22		.4374	.381	.4321	
23	.5668		.301	.3521	
24	.23	.4858	.2623	.2709	.3353
Max	1.3117	1.5083	1.4083	1.9113	1.7772
Min	.2172	.4374	.2623	.2709	.3353
Avg	.7914	.8100	.7567	.9633	.9822



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214404 / 33 KV GHODEGAON

Feeder No / Name : 201 / NARODI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1174	.4024	.4024	.0671	.1341
2	.6036	.6036	.6036	.1006	.1341
3	.6036	.8048	.8048	.1006	.1677
4	.8048	.9389	.9389	.1174	.2012
5	.8718	1.2407	1.2407	.1509	.2347
6	.9389	1.5089	1.5089	.1677	.285
7	1.1401	1.6095	1.6095	.1677	.3185
8	1.1736	1.8442	1.643	.1677	.3353
9	1.1904	1.8275	1.3413	.1844	
10	.1509	.1677	.6371	.1677	
11	.2683	.3353	.2515	1.7604	
12	.2347	.2347		1.7939	
13	.2683		.2347	1.8275	
14	.3185		.2515	1.4251	
15	.3353		.2515	1.3413	
16	.3521	.2012	.2683	1.3916	
17	.3688	.2012	.2515	1.4083	
18	.3521		.2515	1.5424	
19	.2683		.2012	.2683	
20	.2347	.2683	.2012	.2515	
21	.218	.2347	.1677	.218	
22	.1844	.2012	.1174	.2012	
23	.1509	.1677	.1006	.1677	
24	.1174	.3688	.3353	.0671	.1341
Max	1.1904	1.8442	1.643	1.8275	.3353
Min	.1174	.1677	.1006	.0671	.1341
Avg	.4695	.6927	.5919	.6273	.2161

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214404 / 33 KV GHODEGAON

Feeder No / Name : 202 / GHODEGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3012	.2481	.2835	.3898	.3012
2	.2835	.2481	.2835	.4961	.3012
3	.2835	.2835	.2835	.6201	.3721
4	.3544	.3544	.3544	.691	.443
5	.4252	.567	.567	.7619	.5138
6	.567	.6733	.6733	.8328	.6379
7	.9214	.8505	.7973	.8859	.8682
8	.8505	.8682	.9568	.9036	1.0277
9	.7619	.8505	.8859	.8859	
10	.7087	1.0099	1.0808	1.0808	
11	.7087	1.0985	1.0277	.8859	
12	.6733	.8859	.8505	.6733	
13	.6733	.7087	.6556	.567	
14	.6733	.815	.6379	.6733	
15	.7087	.9214	.7796	.7973	
16	.7087	.8859		.7796	
17	.6733	.9036		.7796	
18	.6733	.7087	.7087	1.0099	
19	.6201	.6556	.7442	.6733	
20	.6201	.567	.691	.6024	
21	.5316	.5138	.6024	.4961	
22	.4252	.443	.4607	.3898	
23	.3366	.3721	.3721	.3544	
24	.3012	.2835	.2835	.3189	.3012
Max	.9214	1.0985	1.0808	1.0808	1.0277
Min	.2835	.2481	.2835	.3189	.3012
Avg	.5744	.6548	.6355	.6895	.5296

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214404 / 33 KV GHODEGAON

Feeder No / Name : 203 / SHINOLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5041	.4854	.4854	.8775	.8589
2	.4668	.4481	.4481	.9709	.8589
3	.4668	.4481	.4481	1.0829	.0934
4	.5415	.5228	.4481	1.2136	1.1949
5	.6348	.6722	.6722	1.307	1.4003
6	.7095	.7842	.7842	1.4563	1.6617
7	.8775	.8962	.9149	1.7177	1.9044
8	.8589	.7842	.8775	2.1098	1.8671
9	.7282	.6722	.7468	1.9231	
10	.6722	.5228	.5415	.4481	
11	2.2032	1.9978	1.475	.4481	
12	2.3152	2.4272	1.8858	.4481	
13	2.1285	2.5393	2.3152	.4481	
14	1.9791		1.0642	.5228	
15	2.2032		1.9978	.4668	
16	2.2592	2.1845	2.2032	.4108	
17	1.8858	2.1285	2.0351	.3921	
18	1.6244	1.8671	1.6804	.6348	
19	.9149	1.0642	1.0082	.8962	
20	1.0642	1.0082	.9335	1.0082	
21	.9522	.9522	.8962	.7095	
22	.7468	.7095	.6722	.6722	
23	.6908	.6161	.5415	.6161	
24	.5041	.5228	.5415	.7468	.7842
Max	2.3152	2.5393	2.3152	2.1098	1.9044
Min	.4668	.4481	.4481	.3921	.0934
Avg	1.1638	1.1024	1.0674	.8970	1.1804

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214404 / 33 KV GHODEGAON

Feeder No / Name : 204 / Kotamdara SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.096		.2881	.192
2	.096	.096	.096	.3521	.192
3	.096	.128	.128	.4481	.2881
4	.16	.16	.16	.5601	.3841
5	.192	.2241	.2241	.6081	.5121
6	.2241	.2561	.2561	.6722	.6081
7	.2721	.3041	.3361	.7202	.8642
8	.2881	.2561	.2881	.9442	1.0883
9	.3201	.16	.2721	.9922	
10	.2881	.176	.2881	.208	
11	1.2163	1.0402	1.0883	.208	
12	1.2483	1.1203	1.1043	.2241	
13	1.1843	1.2163	1.1203	.2401	
14	1.1523	1.1203	1.0082	.2241	
15	1.1203	1.1043	.9922	.2241	
16	1.1203	.9282	1.0082	.208	
17	.9602	.8642	.8322	.192	
18	.7682	.6882	.6562	.208	
19	.2241	.2881	.3201	.2401	
20	.2721	.2721	.3041	.2721	
21	.176	.2401	.2561	.192	
22	.16	.192	.176	.128	
23	.144	.16	.144	.112	
24	.112	.112		.2241	.192
Max	1.2483	1.2163	1.1203	.9922	1.0883
Min	.096	.096	.096	.112	.192
Avg	.4961	.4668	.5027	.3621	.4801

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214404 / 33 KV GHODEGAON

Feeder No / Name : 206 / AAMONDI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3561	.3391	.3391	.5935	.4409
2	.3561	.3222	.3222	.6783	.5087
3	.3561	.373	.373	.763	.5765
4	.3561	.4409	.4409	.8309	.6443
5	.4239	.5765	.5765	.9326	.78
6	.5426	.6783	.6783	1.0004	1.0174
7	.7122	.6783	.6783	1.0343	1.3565
8	.7461	.5765	.6613	1.4752	1.5261
9	.5256	.5087	.5087	1.4922	
10	.39	.3222	.4409	.407	
11	1.7635	1.3904	1.6617	.373	
12	1.933	1.8652	1.7465	.39	
13	1.8821	2.0517	1.8313	.407	
14	1.8313	1.9839	1.7974	.4239	
15	1.7974	1.8821	1.7295	.39	
16	1.7635	1.7804	1.6956	.4409	
17	1.5091	1.6278	1.4752	.4578	
18	1.2717	1.2887	1.2378	.5596	
19	.5765	.7122	.7122	.6274	
20	.6783	.6783	.6952	.6783	
21	.6443	.6274	.6274	.5765	
22	.5087	.5087	.4578	.4409	
23	.4409	.39	.373	.39	
24	.3561	.3391	.3561	.4917	.4409
Max	1.933	2.0517	1.8313	1.4922	1.5261
Min	.3561	.3222	.3222	.373	.4409
Avg	.9051	.9142	.8923	.6606	.8101

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214445 / 33/11KV TALEGHAR

Feeder No / Name : 201 / TALEGHAR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3475	.3603	.3366	.3361	.3696
2	.3292	.3859	.3437	.3174	.3511
3	.3292	.4408	.3725	.3361	.3511
4	.3292	.4774	.4097	.3734	.3511
5	.5914	.4957	.4724	.4854	.499
6	.8686	.5378	.6062	.5975	.7095
7	.9425	.6302	.8066	.7095	.8962
8	.823	.7189	.791	.6413	.823
9	.7522	.6172	.7258	.5281	.7421
10	.5548	.5305	.6908	.4904	.6556
11	.5538	.4925	.6535	.3696	.6131
12	.4195	.4817	.6516		.4471
13	.4471	.4855	.5415	.4477	.5391
14	.4536	.5267	.4481	.4656	.5086
15	.5086	.557	.4854	.5138	
16	.4847	.5864	.5041	.4656	
17	.5249	.6255	.5228	.4887	
18	.7095	.6727	.3734	.6584	
19	.7503	.7411	.6722	.8048	
20	.6353	.717	.7468	.7842	
21	.5211	.6432	.5228		
22	.4678	.5097	.4854	.5544	
23	.4	.4537	.4481	.4435	
24	.362	.3493	.3955	.3921	.3696
Max	.9425	.7411	.8066	.8048	.8962
Min	.3292	.3493	.3366	.3174	.3511
Avg	.5461	.5432	.5419	.5093	.5484

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214445 / 33/11KV TALEGHAR

Feeder No / Name : 202 / 11kV Bhimashankar

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0678	.0719	.0686	.0747	.0886
2	.0678	.0736	.0705	.0747	.0709
3	.0509	.0771	.0823	.0859	.0709
4	.0509	.0833	.0911	.0934	.0709
5	.0924	.0851	.1003	.1027	.0943
6	.1109	.0923	.127	.1232	.112
7	.1307	.1288	.1641	.1494	.1509
8	.1294	.132	.1396	.1377	.1886
9	.12	.1307	.1481	.1358	.1417
10	.12	.1215	.1363	.132	.1214
11	.1213	.1144	.112	.1097	.1182
12	.0851	.1046	.0971	.0739	.1097
13	.0832	.0894	.104	.0716	.0894
14	.0988	.0841	.104	.0716	.0874
15	.086	.0949	.0763	.0732	
16	.0878	.105	.0824	.0747	
17	.1104	.12	.0895	.0895	
18	.1922	.1647	.1433	.1307	
19	.2107	.2177	.1791	.2033	
20	.1793	.1996	.2054	.2033	
21	.146	.1774	.1494	.181	
22	.1257	.1236	.112	.1448	
23	.0686	.0929	.1027	.1063	
24	.064	.0686	.0832	.084	.0886
Max	.2107	.2177	.2054	.2033	.1886
Min	.0509	.0686	.0686	.0716	.0709
Avg	.1083	.1147	.1153	.1136	.1069

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214445 / 33/11KV TALEGHAR

Feeder No / Name : 203 / AHUPE

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0886	.0811	.0811	.1132
2	.0943		.0868	.0868	.0943
3	.0754	.0981	.0924	.0896	.0943
4	.0754	.1113	.1019	.1019	.0943
5	.1132	.1339	.1113	.1245	.132
6	.1509	.1547	.1245	.1509	.1509
7	.2452	.1792	.2131	.1886	.2452
8	.1886	.1999	.1962	.1886	.2075
9	.1698	.1792	.1528	.1509	.1886
10	.132	.1264	.1075	.132	.132
11	.1151	.1	.0754	.0943	.0773
12	.0736	.0792	.0943	.0943	.0641
13	.0792	.0773	.0905	.0943	.0596
14	.0679	.066	.0868	.0943	.0585
15	.0641	.0717	.0849	.0943	
16	.0924	.0736	.0943	.0943	
17	.1075	.1056	.1037	.1509	
18	.2075	.1848	.1886	.1698	
19	.2414	.2527	.2452	.2452	
20	.2094	.2414	.2452	.2452	
21	.2018	.2301	.2075	.2263	
22	.1716	.1754	.1547	.1698	
23	.1339	.1433	.1132	.1132	
24	.1132	.1094	.1094	.1056	.1132
Max	.2452	.2527	.2452	.2452	.2452
Min	.0641	.066	.0754	.0811	.0585
Avg	.1341	.1383	.1317	.1369	.1217



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214457 / 33/11KV KALAMB S/S

Feeder No / Name : 201 / KALAMB SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0724	.0686	.2058	.2743
2	.0514	.0543	.0686	.2572	.2743
3	.0686	.0543	.0686	.3086	.3086
4	.0686	.0724	.0686	.3086	.3086
5	.0686	.0724	.0686	.3086	.3429
6	.0857	.0905	.0686	.3429	.3772
7	.12	.1063	.0686	.3429	.3772
8	.1595	.1595	.0857	.3429	.4287
9	.1417	.1387	.1372	.3772	.5144
10	.124	.1372	.12	.4115	.1372
11	.3772	.3429	.4801	.1372	.12
12	.4287	.3772	.5658	.1372	.12
13	.4287	.4287	.6001	.1372	.1029
14	.4458	.4458	.583	.1372	.1029
15	.4458	.4458	.6001	.1372	.12
16	.4287	.4801	.5487	.1372	.1372
17	.5144	.4458	.5144	.1372	.12
18	.4287	.4287	.4458	.1543	.12
19	.1372	.2058	.1372	.1543	.12
20	.1214	.1543	.1543	.1715	.1029
21	.104	.1372	.12	.1372	.12
22	.0867	.12		.1372	
23	.0709	.1029		.1029	
24	.0514	.0724	.0686	.0686	.2572
Max	.5144	.4801	.6001	.4115	.5144
Min	.0514	.0543	.0686	.0686	.1029
Avg	.2087	.2144	.2564	.2122	.2221

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214457 / 33/11KV KALAMB S/S

Feeder No / Name : 202 / EKLAHARE SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.181	.1372	.5144	.5487
2	.1543	.181	.1372	.6001	.6001
3	.1543	.1991	.1543	.6001	.6001
4	.1372	.2172	.1543	.6859	.6516
5	.1543	.2534	.1543	.7716	.7202
6	.1886	.2835	.2572	.7716	.7202
7	.3086	.3012	.3086	.823	.7716
8	.3544		.3429	.823	.7716
9	.4252	.3467	.3086	.8573	.823
10	.3721	.2401	.2743	.8916	.2401
11	.9431	.4973	.823	.2058	.2229
12	.9774	.6001	.8573	.2058	.2229
13	1.0288	.7716	1.0288	.2058	.2401
14	1.0288	.9945	1.0288	.2058	.2401
15	1.046	1.0288	.9602	.2058	.2401
16	1.046		.9088	.2572	.2229
17	1.0288	1.0288	.8745	.2572	.2401
18	.9259	1.0288	.8573	.4115	.3429
19	.2743		.2058	.1715	.3086
20	.2947	.1543	.2229		.3086
21	.3121	.1372	.2743	.2743	.2743
22	.2774	.1372		.2229	
23	.2126	.1372		.1715	
24	.1715	.181	.1372	.2572	.5144
Max	1.046	1.0288	1.0288	.8916	.823
Min	.1372	.1372	.1372	.1715	.2229
Avg	.4995	.4238	.4731	.4518	.4466

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214457 / 33/11KV KALAMB S/S

Feeder No / Name : 203 / MAHALUNGE PADWAL SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.3258	.6859	.1543	.12
2	.2058	.362	.7716	.1543	.12
3	.2572	.362	.8573	.1543	.1029
4	.3429	.3982	.8573	.1715	.1029
5	.3429	.4163	.9431	.1715	.12
6	.4115	.4784		.2058	.12
7	.5487	.6556	1.0288	.2058	.1372
8	.9214	1.0631		.2058	.1715
9	.9214	1.1096	.8573	.2058	
10	.2126	1.0288	.2743	.2058	.2229
11	.1715	.2915	.2915	.6859	1.0288
12	.1715	.2915	.2915	.9431	1.166
13	.2058	.2915	.3429	.9431	1.2174
14	.2401	.2743	.3429	1.0288	1.2003
15	.2743	.2743	.2915	1.1488	1.166
16	.2743	.2743	.3086	.9431	1.1145
17	.2743	.2915	.3086	.6859	.9945
18	.2229	.2915	.2743	.6859	.823
19	.2743	.2401	.2572		.2401
20	.2254	.2401	.2743	.2743	.2572
21	.1734	.2058	.2058	.2572	.2058
22	.156	.1372		.1886	
23	.1063			.1543	
24	.1372	.2658	.1372	.2058	.1372
Max	.9214	1.1096	1.0288	1.1488	1.2174
Min	.1063	.1372	.1372	.1543	.1029
Avg	.2997	.4161	.4801	.4339	.5128

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214457 / 33/11KV KALAMB S/S

Feeder No / Name : 204 / Ganeshwadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.2534	.2572	.8573	.4287
2	.1372	.2715	.2572	.9431	.4287
3	.1372	.2715	.2572	.9431	.4801
4	.1543	.2715	.2572	.9945	.5487
5	.1543	.2896	.3086	.9945	.6001
6	.2058	.3012	.3429	1.0117	.6001
7	.2743	.4252	.3772	1.0117	.7373
8	.2303	.4607	.3772	1.0117	.8573
9	.3721	.4973	.4458	1.0117	1.1317
10	.3721	.4287	.3601	.9945	.2572
11	.9602	.7716	1.0288	.3086	.2743
12	1.2003	1.0288	1.1145	.3086	
13	1.166	1.0288	1.1488	.3258	.3086
14	1.1831	1.166	1.1488	.3258	.3086
15	1.2003		1.1317	.3258	.3429
16	1.1317	1.1831	1.1145	.3429	.3772
17	1.0631	.9431	1.046	.3772	.3772
18	.9431	.8573	.8059	.4458	.3601
19	.3772	.3258	.2915	.3944	.3772
20	.3641	.3258	.2743	.3944	.3429
21	.3467	.3086	.3429	.3429	.3429
22	.2947	.2743		.2743	
23	.2658	.2572		.2229	
24	.1543	.2534	.2572	.2058	.3772
Max	1.2003	1.1831	1.1488	1.0117	1.1317
Min	.1372	.2534	.2572	.2058	.2572
Avg	.5351	.5302	.5884	.5987	.4695

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214457 / 33/11KV KALAMB S/S

Feeder No / Name : 206 / 11kV Lauki SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.8145	1.5432	.5144	.3086
2	.8745	.8688	1.5432	.6001	.3429
3	.9945	.9412	1.6289	.6001	.4287
4	.9945	1.0498	1.6289	.6859	.4287
5	1.1488	1.1222	1.6289	.7716	.5487
6	1.286	1.2757	1.8004	.7716	.6859
7	1.6289	1.7718	1.9204	.823	.7202
8	2.392	2.2502	2.1262	.823	.823
9	2.1262	2.4177	2.1262	.8573	1.0288
10	.6024	2.0062	.2058	.9602	.2401
11	1.3717	.8573	.823	1.5432	1.8004
12	1.5775	.9431	.9602	1.6289	2.0576
13	1.5775	1.0288	1.0631	1.8347	2.1262
14	1.5947	1.1145	1.1145	1.9719	2.1091
15	1.6118	1.166	1.0631	2.1776	2.0233
16	1.6461	1.166	1.0288	2.0576	1.9376
17	1.7147	.6859	.8916	1.9719	1.8004
18	1.4918	.6344	.823	1.6632	1.6118
19	1.0974	.2401	.2401	.1543	.2058
20	1.0923	.2229	.2572	.2229	.2229
21	.9709	.2229	.2058	.1886	.1715
22	.7628	.2058		.1715	
23	.5847	.1372		.1372	
24	.7202	.7421	.1372	.1029	.2058
Max	2.392	2.4177	2.1262	2.1776	2.1262
Min	.5847	.1372	.1372	.1029	.1715
Avg	1.2728	.9952	1.1254	.9681	.9922

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214457 / 33/11KV KALAMB S/S

Feeder No / Name : 207 / Amar Flooring

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0905	.12	.1543	.1029
2	.0857	.0724	.12	.1543	.0686
3	.0686	.0543	.12	.1543	.0857
4	.0686	.0543	.12	.1543	.0686
5	.0857	.0543	.12	.1543	.0686
6	.1029	.0532	.12	.1715	.1029
7	.1543	.0709	.1372	.1715	.1029
8	.1063	.0354	.1372	.1886	.12
9	.1063	.0171	.12	.1715	.1543
10	.1063	.0343	.12	.1715	.1029
11	.12	.0686	.12	.12	.12
12	.12	.0857	.12	.12	.12
13	.12	.1029	.1029	.1029	.1029
14	.1029	.12	.1029	.0857	.1029
15	.1029	.12	.12	.0857	.0857
16	.1029	.1029	.12	.0857	.0686
17	.1029		.1029	.1029	.0857
18	.1029		.12	.0857	.1029
19	.1029		.12	.1029	
20	.1387		.1715	.1029	
21	.0693		.1886	.1543	
22	.104			.1372	
23	.1097			.1372	
24	.1029	.1063	.1372	.1543	.12
Max	.1543	.12	.1886	.1886	.1543
Min	.0686	.0171	.1029	.0857	.0686
Avg	.1030	.0731	.1255	.1343	.0993

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214474 / 33 KV WADGAON

Feeder No / Name : 201 / Kolwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2572	.583	.2743	.2572
2	.2401	.2743	.6344	.3086	.2572
3	.6687	.2572	.7202	.3086	.2572
4	.7202	.6516	.7202	.3772	.2915
5	.7545	.7202	.8745	.4801	.3258
6	.9259	.9259	1.0631	.5144	.4115
7	1.0802	1.0288	1.0631	.5487	.4973
8	1.1488	1.3717	1.2003	.6001	.6344
9	.9945	1.2346	1.3032	.5144	.5144
10	.2572	1.0802	1.2003	.3429	.3944
11	.2572	.3258	.3429	1.3032	1.3546
12	.3086	.3086	.3429	1.5604	1.4918
13	.2915	.3086	.3429	1.4918	1.4575
14	.3258	.2743	.3772	1.4746	1.5604
15	.3258	.2743	.3944	1.4403	1.4746
16	.3429	.3258	.3772	1.406	1.3889
17	.3086	.3429	.3429	1.3717	1.1317
18	.4287	.4801	.4287	1.1317	.9945
19	.6001	.6344	.5487	.5487	.6001
20	.5487	.5658	.6173	.5144	.5658
21	.4801	.5144	.4801	.4115	.4973
22	.3944	.4115	.4287	.3429	.3086
23	.3086	.2915	.3258	.2915	.2743
24	.2743	.2572	.2572	.2572	.2743
Max	1.1488	1.3717	1.3032	1.5604	1.5604
Min	.2401	.2572	.2572	.2572	.2572
Avg	.5094	.5465	.6237	.7423	.7173

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214474 / 33 KV WADGAON

Feeder No / Name : 202 / Sultanpur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1134	.1475	.1638	.7373	.639
2	.1134	.1475	.1475	.8356	.639
3	.1134	.1475	.1475	.8192	.6882
4	.1134	.1966	.1475	.852	.7701
5	.1457	.2949	.1966	1.0159	.9503
6	.2267	.3441	.2294	1.1469	1.0322
7	.2591	.3605	.2949	1.1797	1.1797
8	.2753	.3441	.3277	1.2289	1.2616
9	.3239	.2915	.3605	1.2289	1.2452
10	.3077	.2294	.2622	1.2125	.1802
11	1.3765	1.3272	1.4255	.213	.1638
12	1.5546	1.6057	1.5074	.2294	.1802
13	1.6194	1.6876	1.5729	.2458	.1638
14	1.5708	1.704	1.491	.2622	.1966
15	1.587	1.704	1.4419	.2622	.2458
16	1.5384	1.6712	1.3927	.2949	.2622
17	1.4737	1.5402	1.3599	.2622	.2785
18	1.2793	1.4419	1.2289	.2294	.2622
19	.3401	.3768	.3605	.2949	.3605
20	.3239	.3441	.3441	.2622	.3277
21	.2915	.2785	.2622	.2458	.3113
22	.2267	.2294	.2622	.213	.1802
23	.1619	.1638	.2458	.1311	.1638
24	.1457	.1638	.1638	.6882	.1147
Max	1.6194	1.704	1.5729	1.2289	1.2616
Min	.1134	.1475	.1475	.1311	.1147
Avg	.6451	.6976	.6390	.5871	.4915



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214474 / 33 KV WADGAON

Feeder No / Name : 203 / 11kV Chass

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2374	.4917	.2543	.2543
2	.2572	.2374	.5765	.2543	.2374
3	.6344	.2543	.5765	.3052	.2374
4	.6687	.6952	.5765	.3052	.2374
5	.7716	.7461	.6443	.3391	.2713
6	.9774	.8817	.8648	.407	.407
7	1.0974	1.0174	1.0682	.5087	.4578
8	1.166	1.2887	1.2887	.5935	.5426
9	1.2003	1.2689	1.3226	.4578	.407
10	.2572	1.2517	1.1361	.2543	.2713
11	.1715	.2572	.2713	1.4413	1.4243
12	.1886	.0171	.2543	1.6278	1.6108
13	.2401	.0171	.2204	1.6448	1.6448
14	.2572	.0171	.2204	1.6278	1.6956
15	.2401	.2743	.2374	1.5939	1.6956
16	.2401	.3086	.2374	1.543	1.4413
17	.2743	.3429	.2713	1.4922	1.3735
18	.4287	.463	.39	1.3395	1.2039
19	.7202	.6859	.5087	.6443	.6443
20	.5658	.6344	.5426	.5765	.6104
21	.583	.583	.6274	.4578	.5935
22	.4458	.4409	.39	.373	.3052
23	.3086	.3391	.2543	.3052	.3222
24	.2743	.2543	.3052	.2374	.2713
Max	1.2003	1.2887	1.3226	1.6448	1.6956
Min	.1715	.0171	.2204	.2374	.2374
Avg	.5094	.5214	.5532	.7743	.7567

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214486 / 33/11 KV Peth subststion.

Feeder No / Name : 203 / 11 KV Pargaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.6859	.6706	.1543	.12
2	.7202	.703	.6706	.1543	.12
3	.8059	.9088	.8718	.1715	.0686
4	.8916	.9431	.9221	.1886	.0857
5	.9602	1.046	1.0059	.2229	.1029
6	1.046	1.166	1.073	.2572	.12
7	1.3032	1.3889	1.3916		
8	1.3717	1.5947	1.576	.2401	.1886
9	1.406	1.5947	1.5424	.2572	.1886
10	.1715	.1715	.2229	.2743	.2058
11	.1715	.1886	.2743	1.3413	1.1279
12	.1886	.1886	.2058	1.5592	
13	.2401	.3086	.1886	1.5927	1.5604
14	.2572	.2401	.1715	1.6263	1.4022
15	.2572	.3086	.1715	1.7436	1.4632
16	.2915	.2915	.2229	1.4083	1.4632
17	.2401	.2743	.2058	1.1233	1.4746
18	.2401	.3258	.2058	1.0395	1.3717
19	.2058	.3086	.2401	.1715	.2915
20	.1886	.2572	.2058	.1715	.2572
21	.2058	.2401	.1886	.1543	.2401
22	.1372	.2229	.1886	.1372	.2229
23	.1372	.2229	.1715	.12	
24	.1543	.6516	.6539	.1715	.12
Max	1.406	1.5947	1.576	1.7436	1.5604
Min	.1372	.1715	.1715	.12	.0686
Avg	.4887	.593	.5517	.6209	.5807

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214486 / 33/11 KV Peth subststion.

Feeder No / Name : 204 / Peth GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	1.1317	.3921	.3429	.3547
2	.2915	.3429	.3734	.3429	.3734
3	.3258	.3429	.3734	.3772	.3734
4	.4458	.3772	.4481	.463	.4668
5	.5487	.4973	.5601	.5658	.5788
6	.703	.7373	.8215	.8059	.8215
7	.823	.7373	.7842		
8	.7202	.6687	.7095	.7716	.7655
9	.5487	.4801	.5601	.6535	.5601
10	.4287	.4115	.5316	.5788	.5487
11	.4458	.4287	.5316	.5041	.463
12	.3772	.4458	.5316	.4294	.3772
13	.3429	.3772	.4458	.3921	.3601
14	.3258	.3772	.4458	.3734	.2915
15	.4338	.3258	.4115	.3734	.2743
16	.3772	.3772	.4287	.3547	.3772
17	.4458	.3944	.4115	.3921	.4801
18	.4973	.6161	.5658	.5975	.6516
19	.7716	.7947	.7545	.6535	.823
20	.703	.7468	.6687	.7282	.7545
21	.6516	.6173	.6173	.6535	.6344
22	.4801	.6161	.5144	.5601	.4287
23	.3944	.4294	.4115	.4481	
24	.3086	.3601	.3734	.3601	.3547
Max	.823	1.1317	.8215	.8059	.823
Min	.2915	.3258	.3734	.3429	.2743
Avg	.4868	.5264	.5278	.5096	.5051

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214402 / 33/11KV JUNNAR

Feeder No / Name : 201 / SHIVNERI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7265	.5792	.7499	.5418	.8859
2	.7343	.6455	.6535	.4877	.8859
3	.7783	.724	.7133	.4793	.9214
4	.8145	.7529	.9055		.9745
5	.8859	.8333	.8962	.7613	.9991
6	1.1104	.8962	.9795	.7895	1.1269
7	1.1517	.8573	1.2489	.9145	1.5074
8	1.1963	1.0242	1.0229	1.6004	1.9498
9	.8859		1.1157	2.0645	1.7368
10	.7895		.8459	1.8067	
11	1.6861		1.861	1.1568	.5765
12	2.0485	2.4099	1.9456	1.1694	.6478
13	1.8892	2.6755	1.9597	1.1946	.7682
14	1.8328	2.7566	1.9147	1.182	.8383
15	2.3205	2.7913	1.861	1.182	.8192
16	1.9147	2.6755	1.8328	1.182	.9054
17	1.9814	2.6968	1.8046	1.2071	.9835
18	1.7071	2.2131	.7895	1.8233	.9054
19	.7895	1.2012	.8459	1.0056	.7316
20	.7895	1.1157	.8109	.9114	.6706
21	.6401	1.0791	.7331	.7973	.6173
22	.6287	.9149	.6287	.6984	.4572
23	.5967	.823	.6401	.6697	.4268
24	.7537	.6401	.8316	.5075	.6838
Max	2.3205	2.7913	1.9597	2.0645	1.9498
Min	.5967	.5792	.6287	.4793	.4268
Avg	1.1938	1.4431	1.1496	1.0493	.9139

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214402 / 33/11KV JUNNAR

Feeder No / Name : 202 / MANIKDOH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.3841	.9231	.3429	.3292
2	.3326	.423	1.0903	.4287	.362
3	.8059	.6203	1.0791	.4512	.362
4	.7973	.7716	1.1273	.4512	.4251
5	.8954	.8962	1.2382	.4599	.4715
6	1.1641	.9602	1.262	.4938	.5373
7	1.2226	1.6004	1.4299	.4858	.815
8	1.5424	1.8046	3.3779	.5075	.7265
9	1.4146	.6584	3.4848	.6447	.6443
10	1.2289	.2378	.6203	.5609	
11	.8421	.5973	.2858	1.6712	1.6278
12	.3201	.6697	.3384	1.9433	2.0348
13	.2858	.591	.2858	2.2298	2.0348
14	.2256	.6201	.282	2.0972	1.8652
15	.2256	.6485	.3384	2.0081	1.8442
16	.5121	.6556	.3246	1.9784	1.6842
17	.4801	.6697	.3384	1.8519	1.8652
18	.5121	.7421	.4512	1.6617	1.6644
19	.5716	.7343	.5761	.6838	.7099
20	.5487	.7499	.4512	.5853	.6097
21	.423	.6767	.4512	.4887	.5247
22	.4633	.5788	.3429	.462	.3704
23	.282	.462	.2743	.3734	.3048
24	.3772		1.2012		.3361
Max	1.5424	1.8046	3.4848	2.2298	2.0348
Min	.2256	.2378	.2743	.3429	.3048
Avg	.6600	.7284	.8989	.9940	.9630

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214402 / 33/11KV JUNNAR

Feeder No / Name : 203 / 11 kV OZAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7011	.602	.7577	.5075	.9391
2	.6767	.6371	.7059	.4793	.9745
3	.8764	.6767	.7865	.4633	.985
4	.9694	.7331	.823	.4793	.9991
5	.9745	.7716	1.0534	.4793	1.0745
6	1.0745	.7895	1.1523	.8459	1.1517
7	1.2209	1.6217	1.647	.9023	1.2548
8	1.5708	1.5962	1.9376	.8459	1.2717
9	1.6004		2.1439	1.0631	1.1523
10	1.6004	.9134	1.5367	1.1694	
11	.7716	1.1273	.8573	1.9161	1.6278
12	.7895	1.0517	.9023	1.9616	2.0119
13	.7613	1.1393	.8573	2.0287	1.8442
14	.8109	1.2127	.9023	2.0517	1.8679
15	.8619	1.0808	.7331	2.0287	2.0119
16	.9069	1.1043	.8459	2.0856	2.0119
17	.8128	1.1888	.9023	2.0856	1.8442
18	.8535	1.3491	.9145	1.6221	1.7436
19	.8688	1.2012	.8657	1.1694	.679
20	.743	1.0791	.7895	1.0517	.6173
21	.724	1.0164	.8109	1.0208	.6097
22	.6874	.9149	.7331	.9568	.6173
23	.5639	.823	.6859	.8954	.5487
24	.7011	.5075	.823	.5075	.8775
Max	1.6004	1.6217	2.1439	2.0856	2.0119
Min	.5639	.5075	.6859	.4633	.5487
Avg	.9217	1.0060	1.0070	1.1924	1.2485

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214402 / 33/11KV JUNNAR

Feeder No / Name : 204 / JUNNAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8025	.8686	.8177	1.0387
2		.8429	.7947	.8768	1.0498
3		.8002	.823	.9602	1.0566
4		.823	.9425	1.0288	1.0454
5		.7628	1.0791	1.0562	1.0566
6		.8109	1.1871	1.0551	1.3998
7		1.4662	1.6278	1.0997	1.8143
8		1.5575	1.869	1.829	1.8442
9	1.7814		1.9728	1.9334	1.7368
10	1.8884	1.8858	1.4861	1.6108	
11	1.579	1.7187	1.5367	1.4586	1.4251
12	1.6613	1.7703	1.4662	1.4419	1.3565
13	1.5927	1.543	1.4003	1.4922	1.3413
14	1.6004	1.4918	1.5278	1.4251	1.2742
15	1.2498	1.4737	1.1145	1.4419	1.2407
16	1.2483	1.4352	1.1145	1.4251	1.2407
17	1.6644	1.5384	1.1279	1.4922	1.2452
18	1.7284	1.828	1.7924	1.8023	1.6095
19	1.6004	2.1399	1.6636	1.7604	1.6049
20	1.8328	2.1253	1.5575	1.6956	1.4815
21	1.6004	1.9521	1.419	1.5927	1.3717
22	.8642	1.7372	1.2574	1.4575	1.2803
23	.8288	1.46	1.2483	1.1869	1.1584
24		.7895	1.2012	.7895	1.0029
Max	1.8884	2.1399	1.9728	1.9334	1.8442
Min	.8288	.7628	.7947	.7895	1.0029
Avg	1.5147	1.4241	1.3366	1.3637	1.3337

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214402 / 33/11KV JUNNAR

Feeder No / Name : 205 / Pimpalgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6268	.423	.5359	.7095	1.0631
2	.5316	.4512	.5041	.6763	1.1517
3	.6335	.4988	.6099	.7034	1.1871
4	.7701	.5144	.6468	1.5718	1.1797
5	.823	.5213	.7133	1.4098	1.2289
6	1.0059	.6287	.7783	1.8187	1.3108
7	1.1283	.8859	1.1157	1.7314	1.5249
8	1.3056	.9267	1.2656	1.829	2.0885
9				2.2382	2.0972
10	.9267	1.1273	1.1138	1.917	
11	2.0805	2.64	2.0538	1.0166	.9156
12	2.0719	2.9622	1.9073	.9831	.9831
13	1.9738	3.0687	1.9738	1.1163	.9835
14	1.8892	3.1716	1.8667	1.1043	.9389
15	2.2405	2.9994	1.9456	1.1283	.9156
16	2.6558	2.8527	1.8892	1.182	.8383
17	2.2405	2.9502	1.9456	1.182	.9054
18	1.829	2.2131	1.8534	1.1999	.8478
19	.8002	1.1888	.8962	1.1641	.7316
20	.7145	1.1273	.7331	1.0745	.6706
21	.8288	1.0317	.8573	.8954	.6097
22	.5498	.7577	.8002	.7619	.5487
23	.5716	.6767	.6859	.7164	.5247
24	.6838	.5487	.6036	.6908	.6767
Max	2.6558	3.1716	2.0538	2.2382	2.0972
Min	.5316	.423	.5041	.6763	.5247
Avg	1.2557	1.4855	1.1867	1.2009	1.0401



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214402 / 33/11KV JUNNAR

Feeder No / Name : 206 / 11kV Amrapur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.282	.7577	.4161	.3109
2	.5304	.2256	.7947	.3948	.3109
3	.7164	.3048	.8589	.4001	.3109
4	.8059	.3384	.8686	.4089	.3734
5	.8238	.4089	.9055	.4144	.3734
6	.8764	.423	1.0534	.3948	.3658
7		.6344	1.1765	.4089	.462
8	1.1961	.6954	1.1963	.4089	.7207
9	1.1288		1.262	.7087	
10	1.3546	.8682	.5639	1.0099	
11	.7362	1.1041	.423	1.595	
12	.724	1.0454	.423	1.6832	1.5261
13	.5792	1.0229	.4572	1.773	
14	.6344	1.0117	.4512	1.7013	
15	.6478	1.1041	.4512	1.7013	
16	.7287	1.1403	.4287	1.6476	
17	.543	1.2012	.4144	1.56	
18	.5213	.3142	.4572	1.2039	1.5089
19	.4572	.9231	.4287	.5729	
20	.4793	.8962	.4144	.4938	
21	.4344	.7947	.4344	.4572	.3658
22	.443	.7133	.4877	.4207	.3048
23	.423	.6535	.3384	.3658	.2743
24	.6036	.4458	.7655	.3666	.3174
Max	1.3546	1.2012	1.262	1.773	1.5261
Min	.423	.2256	.3384	.3658	.2743
Avg	.6929	.7196	.6589	.8545	.5375

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214402 / 33/11KV JUNNAR

Feeder No / Name : 207 / 11 kV HIRDI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2353	.1372	.2743	.1715	.2033
2	.2033	.1692	.3109	.141	.2012
3	.2926	.2256	.3142	.1572	.2033
4	.2987	.282	.3475	.141	.2328
5	.3395	.3384	.3439	.1551	.2378
6	.362	.3102	.3801	.1692	.2772
7	.4607	.282	.4477	.141	.3511
8	.4938	.3102	.6201	.1715	.3511
9	.3858		.6468	.2241	.2883
10	.8002	.2353	.3102	.1646	
11	.1303	.2012	.2115	.3841	.5765
12	.144	.1949	.2164	.543	.6443
13	.2143	.2328	.2286	.6733	.6036
14	.2435	.1578	.2256	.6878	.5571
15	.2286	.124	.2029	.691	.57
16		.1267	.2195	.7577	.6036
17	.2256	.3077	.1894	.7265	.57
18	.2679	.2743	.2143	.7011	.5365
19	.1738	.499	.2195	.5041	.3658
20	.1692	.4668	.1692	.4668	.3353
21	.1429	.3511	.1448	.3734	.3048
22	.1448	.2829	.1692		.2439
23	.1353	.2427	.1286	.3658	.2134
24	.2402	.1269	.2427	.1646	.2012
Max	.8002	.499	.6468	.7577	.6443
Min	.1303	.124	.1286	.141	.2012
Avg	.2753	.2556	.2824	.3772	.3770

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214412 / 33/11KV APTALE

Feeder No / Name : 201 / Amboli

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1512	.3563	.6501	.1523	.227
2	.3612	.4612	.6965	.1521	.1888
3	.3978	.5373	.7255	.1711	.1882
4	.5436	.6842	.8999	.1903	.225
5	.6914	.7972	1.0476	.2284	.2622
6	.9471	.9116	1.2458	.2474	.4166
7	1.3004	1.2603	1.6845	.3609	.606
8	1.4643	1.4404	1.7375	.4924	.3021
9	1.4123		1.6717	.5681	.2646
10	.2432	.1896	.2763	.4909	
11	.2445	.2081	.2452	1.5415	1.7756
12	.2054	.2079	.2257	1.7884	1.6654
13	.2199	.2087	.1886	2.0031	1.6154
14	.1873	.1901	.188	1.8292	1.4795
15	.1865	.2273	.2056	1.7654	1.4595
16	.2445	.2279	.2432	1.8498	1.4244
17	.2821	.3024	.2635	1.8948	1.442
18	.3772	.3405	.3398	1.6494	1.314
19	.5303	.3402	.5113	.7175	.3402
20	.5118	.3799	.4924	.7196	.3961
21	.4166	.4373	.417	.5698	.4347
22	.303	.3402	.3216	.4166	
23	.189	.2646	.2447	.303	
24	.1512	.2806		.152	.2643
Max	1.4643	1.4404	1.7375	2.0031	1.7756
Min	.1512	.1896	.188	.152	.1882
Avg	.4817	.4606	.6314	.8439	.7758

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214412 / 33/11KV APTALE

Feeder No / Name : 203 / Somatwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5233	.4435	.4677	.6973	.924
2	.4649	.4854	.5051	.7721	.9367
3		.5806	.5618	.8859	.8831
4	.577	.7522	.7289	.9293	.9502
5	.8865	.8685	.9561	1.0208	1.0652
6	1.0237	1.0047	1.1998	1.0634	1.2804
7	1.1162	1.2309	1.3873	1.6319	1.6136
8	1.0907	1.0962	1.2883	1.8531	2.0133
9	1.0862		1.0718	2.1148	2.0756
10	.8131	1.0697	.711	.5459	
11	1.8547	2.0645	2.005	.7289	1.0477
12	2.1505	2.332	2.1589	.7679	.9749
13	2.2619	2.516	2.1714	.8471	.9364
14	2.2708	2.492	2.013	.8536	.6555
15	1.4058	2.4034	2.1399	.8359	.8989
16	2.1579	2.3066	1.9566	.8393	.9749
17	1.9702	2.1597	1.9604	.785	1.0551
18	1.823	1.7776	1.7516	.96	1.2709
19	1.0342	.7858	.8874	.9629	1.2198
20	.9788	1.0466	.9242	.9251	1.1811
21	.8641	1.16	.9223	.8135	1.16
22	.6929	.9008	.7289	.7007	
23	.5764	.7109	.6322	.6042	
24	.5596	.5239		.6661	.7572
Max	2.2708	2.516	2.1714	2.1148	2.0756
Min	.4649	.4435	.4677	.5459	.6555
Avg	1.2253	1.3353	1.2665	.9502	1.1369

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214416 / 33 KV HIVARE

Feeder No / Name : 201 / SHIROLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2591	.2926	.3258
2			.2915	.3258	.3258
3			.3239	.3658	.362
4	1.3394		.3887		.3982
5			.4534	.3841	.3982
6		1.2742	.5182	.362	.4344
7	1.5604	1.3592	.6154	.4525	.4344
8	1.8564	1.9951	.7773	.543	.4887
9	2.0454	2.0885	.8097		.543
10		.543		.5792	
11	1.1273	1.0317	.4835	1.1174	
12		1.0498	.5731	1.1336	
13		1.0498	.5973	1.1336	
14	1.0608		.6089	1.1498	
15		1.1222	.5973	1.1336	
16	1.1827	1.1584	.5731	1.0688	
17		1.086	.543	1.0364	
18	1.1273	1.0679	.4784	1.004	
19		.4163	.4382	.362	
20		.362	.3681	.4525	
21		.3439	.3506	.3982	
22		.3258	.3189	.362	
23		.2896	.298	.3258	
24	.5138		.2267	.2835	.2896
Max	2.0454	2.0885	.8097	1.1498	.543
Min	.5138	.2896	.2267	.2835	.2896
Avg	1.3126	.9743	.4736	.6485	.4000

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214416 / 33 KV HIVARE

Feeder No / Name : 202 / HIVRE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6516	.9328	.5506
2			.6878	.9717	.6154
3			.724	.9469	.6802
4	.6554		.7964		.7449
5			.8688	1.1145	.8097
6		.7865	.905	1.2492	1.1012
7	1.0349	1.0059	1.0317	1.2929	1.3279
8	1.0608	1.0791	1.1222	1.475	1.4899
9		.9328	1.1946	1.0562	1.3927
10		.905	1.0688	1.086	
11	1.6716	2.1376	2.1559	1.2308	
12		2.5101	2.1142	1.267	
13		.9393	2.0881	1.3032	
14	2.2725		2.1296	1.3394	
15		2.5263	2.1033	1.3756	
16	2.4777	2.6882	2.1142	1.3937	
17		2.332	1.8673	1.267	
18	2.1605	2.0729	1.7238	1.1403	
19		.9774	.9175	.905	
20		.905	.8029	.8145	
21		.8145	.7499	.6878	
22		.724	.7274	.543	
23		.6878	.6802	.5068	
24	.4464		.6154	.8623	.543
Max	2.4777	2.6882	2.1559	1.475	1.4899
Min	.4464	.6878	.6154	.5068	.543
Avg	1.4725	1.4132	1.2434	1.0766	.9256

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214416 / 33 KV HIVARE

Feeder No / Name : 203 / BHORWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.9568				
6		.9945			
7		1.1437	.6478		.6878
8	1.7013	1.5424			
9	1.7878	1.7238	.9717		.7602
11	.695				
14	.7316				
16	.7682				
18	.7133				
20				.543	
21		.543			
23		.4706		.4344	
24	.4961		.3563		.3982
<b>Max</b>	<b>1.7878</b>	<b>1.7238</b>	<b>.9717</b>	<b>.543</b>	<b>.7602</b>
<b>Min</b>	<b>.4961</b>	<b>.4706</b>	<b>.3563</b>	<b>.4344</b>	<b>.3982</b>
<b>Avg</b>	<b>.9813</b>	<b>1.0697</b>	<b>.6586</b>	<b>.4887</b>	<b>.6154</b>

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214416 / 33 KV HIVARE

Feeder No / Name : 204 / GANPATI DEVSTHAN (Ozar) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4706	.8855	.4858
2			.5068	1.1012	.583
3			.543	1.0322	.6478
4	.4961		.5792	1.1498	.7773
5			.6154	1.247	.9393
6		.4938	.6516	1.278	.9717
7	.6722	.6099	.6878	1.3765	1.0688
8	.6283	.6535	.6878	1.5223	1.2955
9	.5975	.7207			1.3927
10		.6878	.6838	.543	
11	1.2597	1.5546	1.5546	.6878	
12		1.6518		.724	
13		1.6518		.7964	
14	1.6244		1.656	.8326	
15		1.6194	1.5623	.7964	
16	1.6741	1.4575	1.5181	.7964	
17		1.587	1.6204	.7602	
18	1.6095	1.6194	1.4998	.7602	
19		.6878	.7421	.724	
20		.6516	.5487	.724	
21		.6154	.4755	.6878	
22		.543	.4163	.543	
23		.5068	.3841	.5068	
24	.3395		.4344	.8223	.4534
Max	1.6741	1.6518	1.656	1.5223	1.3927
Min	.3395	.4938	.3841	.5068	.4534
Avg	.9890	1.0183	.8494	.8825	.8615



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214416 / 33 KV HIVARE

Feeder No / Name : 205 / 11 kV KURAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3239	.2402	.2534
2			.421	.2427	.2896
3			.6154	.2241	.3258
4			.6478	.2054	.362
5			.7449	.3206	.3982
6			.7773	.3018	.4344
7			.8097	.3547	.4706
8			1.1012	.4668	.4344
9			1.1336		.4706
10			.3696	.5068	
11	1.2597		.4854	1.2308	
12			.5175	1.2631	
13			.5544	1.2955	
14			.5788	1.3603	
15			.5788	1.3603	
16			.5914	1.2955	
17			.5788	1.2631	
18			.5544	1.2308	
19		.3982	.5041	.362	
20		.362	.4108	.3982	
21		.362	.3696	.362	
22		.362	.3361	.3258	
23		.3258	.2987	.2534	
24			.2591	.2054	.181
Max	1.2597	.3982	1.1336	1.3603	.4706
Min	1.2597	.3258	.2591	.2054	.181
Avg	1.2597	.362	.5651	.6552	.362

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214454 / 33/11KV YENERE

Feeder No / Name : 201 / Yenere

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2402	.2534	.2743	.2829	.3326
2	.2378	.2534	.2926	.2614	.3174
3	.2896	.3258	.3077	.2987	.3361
4	.3439	.362	.362	.3772	.415
5	.4298	.4477	.4344	.4715	.4904
6	.5373	.5552	.6268	.547	.5847
7	.7442	.8328	.7265	.679	.6413
8	.7888	.823	.8495	.6413	.6224
9	.7956	.7291	.823	.5975	.5359
10	.3982	.3326	.5729	.5544	.5487
11	.5975	.6535	.6535	.8215	.7625
12	.6535	.7095	.8029	1.0111	.9282
13	.6653	.7282	.7655	1.0277	1.0608
14	.6653	.7095	.7762	.9503	1.1105
15	.7655	.7655	.7023	.9779	1.0442
16	.8029	.6908	.7947	.9779	.9503
17	.6348	.7282	.7207	.9779	.852
18	.6161	.6908	.5544	.6588	.6241
19	.6413	.6413	.6535	.5601	.6224
20	.6036	.6036	.5601	.5415	.6036
21	.4904	.5281	.5228	.4854	.4854
22	.3734	.4338	.4066	.3696	.3361
23	.2987	.3395	.3142	.3696	.2772
24	.2614	.2353	.2743	.2772	.3326
Max	.8029	.8328	.8495	1.0277	1.1105
Min	.2378	.2353	.2743	.2614	.2772
Avg	.5365	.5572	.5738	.6132	.6173

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214454 / 33/11KV YENERE

Feeder No / Name : 202 / Tambe

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.462	.4066	.439	.6516	.5487
2	.4805	.3881	.4251	.6274	.6443
3	.4668	.5041	.4668	.703	.7202
4	.5601	.6535	.5415	.8149	.8322
5	.6722	.7356	.6602	.9362	.9536
6	.9149	.811	.8865	1.1043	1.0745
7	1.1506	1.0185	1.0562	1.5074	1.5777
8	1.0903	1.0269	1.0829	1.6975	1.8143
9	.9795	.9709	.9896	1.6876	1.8399
10	.8413	.9313	.8775	.5992	.583
11	1.861	1.9281	1.7532	.7392	.724
12	2.0388	2.0957	1.9498	.7964	.7602
13	2.0388	2.2634	1.9498	.7343	.823
14	2.0388	2.2377	1.9334	.7964	.7865
15	2.0553	2.2131	1.8461	.7783	.8779
16	2.0957	2.146	1.8842	.7783	.8779
17	1.8187	1.989	1.7695	.788	.9145
18	1.6575	1.7736	1.5415	.924	1.0642
19	.9425	.8501	.8686	.9795	1.1203
20	.9335		.9055	.9795	1.0534
21	.8029	.8029	.8686	.924	.9795
22	.6401	.6219	.6219	.6401	.7316
23	.5304	.5304	.5487	.5611	.5973
24	.4572	.4251	.4755	.6783	.57
Max	2.0957	2.2634	1.9498	1.6975	1.8399
Min	.4572	.3881	.4251	.5611	.5487
Avg	1.1471	1.1880	1.0976	.8928	.9362

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214454 / 33/11KV YENERE

Feeder No / Name : 203 / BORGHAR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.104	.1075	.124	.1478	.1097
2	.104	.1075	.1063	.112	.1097
3	.1227	.128	.1075	.1132	.1307
4	.128	.128	.1075	.1307	.1307
5	.1478	.1494	.128	.1478	.1478
6	.1848	.1886	.1867	.168	.1886
7	.2614	.2801	.2241	.2614	.2241
8	.2353	.2743	.2427	.2195	.2614
9	.2481	.2507	.1848	.2149	.2149
10	.208	.1989	.2204	.1783	.2254
11	.1734	.1433	.2401	.1417	.156
12	2.1091	.1075	.2401	.1658	.1696
13	.0135	.1417	.1907	.1658	.1715
14	.104	.1402	.1886	.1677	.1753
15	.124	.1417	.1509	.1989	.1509
16	.1052	.1612	.1696	.1677	.1311
17	.1907	.1791	.208	.2012	.1677
18	.2172	.197	.2507		.181
19	.2587	.3077	.3045	.2926	.2241
20	.2402	.2772	.2402	.2587	.2218
21	.2218	.2402	.2033	.2378	.2033
22	.181	.1991	.1629	.2378	.1595
23	.156	.1387	.124	.1402	.1214
24	.1387	.124	.1402	.1267	.1086
Max	2.1091	.3077	.3045	.2926	.2614
Min	.0135	.1075	.1063	.112	.1086
Avg	.2491	.1797	.1852	.1824	.1702

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214407 / 33/11KV NIRGUDSAR

Feeder No / Name : 201 / 11KV PARGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2818	.2652	.2984	.8478	.763
2	.2652	.2652	.3315	.9156	.7969
3	.2984	.2984	.3647	1.0513	.8309
4	.3647	.3315	.3812	1.0682	.8648
5	.431	.3978	.3978	1.17	.8987
6	.6299	.663	.5636	1.2407	1.0174
7	.7956	.7625	.7127	1.3056	1.2209
8	.7122	.5596	.7122	1.4413	1.3056
9	.5596	.5765	.5765	1.4752	1.3226
10	.5596	.5087	.5426	.4748	.4239
11	1.5769	1.6617	1.5261	.407	.4239
12	1.7295	1.7465	1.6278	.407	.4409
13	1.6278	1.7804	1.6278	.407	.5426
14	1.7126	1.8313	1.5939	.4239	.5087
15	1.6956		1.4922	.4409	.5087
16	1.6448	1.6956	1.4243	.4409	.5087
17	1.6244	1.5746	1.3904	.5087	.5765
18	1.4918	1.4586	1.3565	.5596	.6104
19	.5636	.5304	.4748	.1494	.5256
20	.4973	.4641	.5087	.5765	.5087
21	.431	.4144	.4409		.4578
22	.3315	.3647	.373	.2241	.373
23	.2984	.3149	.3222	.373	.3222
24	.3149	.2652	.2818	.8139	.7461
Max	1.7295	1.8313	1.6278	1.4752	1.3226
Min	.2652	.2652	.2818	.1494	.3222
Avg	.8516	.8144	.8051	.7271	.6874

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214407 / 33/11KV NIRGUDSAR

Feeder No / Name : 202 / 11KV NIRGUDSAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.8002	.8592	.2054	.1494
2	.7907	.8097	.8539	.2054	.1698
3	.8162	.852	.8802	.2452	.1886
4	.852	.8421	.9069	.2641	.2263
5	.8785	.8951	.9503	.2641	.2641
6	.9221	.9835	.9892	.3206	.3206
7	1.0898	1.1469	1.1568	.3584	.3961
8	1.2597	1.4089	1.4586	.4338	.3584
9	1.4255	1.4922	1.5424	.3772	.3018
10	.2033	.2587	.2378	.3734	.3395
11	.2427	.2743	.2686	1.6575	1.6244
12	.2561	.2772	.2353	1.7814	1.6804
13	.2896	.2926	.2378	1.6804	1.6644
14	.3045	.3109	.2402	1.7284	1.6518
15	.2835	.3045	.2743	1.7284	1.7166
16	.3224	.3045	.2743	1.6324	1.8404
17	.3258	.3012	.2896	1.6004	1.7604
18	.3109	.3174	.3224	1.6129	1.6484
19	.3206	.3772	.3361	.3547	.3206
20	.3018	.3206	.3206	.2641	.2641
21	.2452	.2641	.3018	.2263	.2641
22	.2075	.2263	.2614	.1867	.2075
23	.1886	.1848	.1829	.1848	.1848
24	.2054	.8002	.8642	.0377	.1494
Max	1.4255	1.4922	1.5424	1.7814	1.8404
Min	.1886	.1848	.1829	.0377	.1494
Avg	.5096	.5852	.5935	.7385	.7372

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214407 / 33/11KV NIRGUDSAR

Feeder No / Name : 203 / 11KV JAWALE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2622	.2785	.2622	1.0688	.9393
2	.2458	.2785	.2622	1.1012	.9231
3	.2622	.2949	.2622	1.1336	.9393
4	.2949	.3277	.2785	1.166	.9555
5	.3277	.3605	.2949	1.2146	.9717
6	.3932	.4588	.4096	1.2955	.9878
7	.4588	.4915	.4424	1.3765	1.004
8	.4534	.4372	.4534	1.4899	1.2955
9	.502	.502	.502	1.6194	1.4251
10	.5182	.4858	.421	.3887	.3239
11	1.8138	1.7814	1.749	.3887	.3887
12	1.9433	2.0081	1.8947	.3887	.421
13	1.8947	2.0729	1.8785	.3887	.4534
14	1.9595	2.1214	1.9919	.4049	.421
15	2.0081	2.1376	1.9109	.421	.421
16	1.9757	1.9919	1.8785	.421	.3887
17	1.8023	1.917	1.6518	.3887	.3887
18	1.6385	1.9006	1.587	.4696	
19	.4915	.4096	.3239	.421	.3887
20	.4588	.3605	.3239	.3725	.3563
21	.3932	.3441	.2915	.3239	.3401
22	.3277	.2785	.2753	.3077	.2915
23	.2949	.2458	.2429	.2591	.2591
24	.2622	.2785	.2458	1.0526	.9231
Max	2.0081	2.1376	1.9919	1.6194	1.4251
Min	.2458	.2458	.2429	.2591	.2591
Avg	.8743	.9068	.8264	.7443	.6612

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214407 / 33/11KV NIRGUDSAR

Feeder No / Name : 204 / 11KV MENGADEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.3688	.4001	.3734	.3174
2	.3239	.3688	.4372	.4108	.3361
3	.3647	.4359	.4696	.4527	.3772
4	.4409	.5144	.5079	.5281	.415
5	.5487	.583	.5304	.6036	.4527
6	.7011	.8063	.7545	.7167	.679
7	1.1096	1.073	1.166	.9054	.9054
8	1.4083	1.4419	1.4419	1.0562	.9242
9	1.4255	1.5249	1.5074	.9808	1.0185
10	.5415	.5544	.5658	.7468	.8299
11	.7468	.6348	.4435	1.2955	1.3108
12	.7468	.6722	.6653	1.2498	1.406
13	.6838	.6653	.5914	1.2651	1.4403
14	.695	.7023	.6099	1.3123	1.4723
15	.7682	.6653	.5853	1.3123	1.3283
16	.7023	.7392	.6154	1.2803	1.2803
17	.7095	.7577	.6335	1.2498	1.1584
18	.7468	.8215	.6584	1.0364	1.0623
19	.7545	.7545	.6535	.679	.4904
20	.6413	.679	.6036	.6036	.3961
21	.5658	.6036	.5228	.5281	.3772
22	.4527	.4715	.4481	.3961	.3206
23	.3772	.3734	.3734	.3395	.2614
24	.2957	.3563	.3841	.3361	.3018
Max	1.4255	1.5249	1.5074	1.3123	1.4723
Min	.2957	.3563	.3734	.3361	.2614
Avg	.6687	.6903	.6487	.8191	.7859



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214407 / 33/11KV NIRGUDSAR

Feeder No / Name : 205 / 11KV JARKARWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2658	.2801	.3511	.6722	.3932
2	.2534	.2801	.3696	.6722	.4144
3	.2896	.3361	.4108	.7209	.431
4	.3326	.3772	.4481	.7712	.4801
5	.4481	.4527	.4904	.7956	.5375
6	.6413	.7545	.7545	.8573	.8063
7	.8962	.9431	.8962	.8916	1.1317
8	.8871	.7468	.9522	1.2407	1.3077
9	.7947	.7577	.9149	1.2125	.6882
10	.4706	.6401	.724	.4298	.431
11	.9804	1.1523	1.1203	.5792	.6401
12	1.2963	1.5223	.9842	.695	.7442
13	1.2651	1.4899	1.2651	.6335	.7164
14	1.2334	1.5402	1.1544	.6335	.7602
15	1.3283	1.5203	1.078	.6516	.7682
16	1.3123	1.4243	1.0155	.7164	.3658
17	1.1843	1.2955	.9488	.7522	.7087
18	.8745	1.1069	.8322	.6733	.5487
19	.5975	.7392	.5853	.7392	.6535
20	.5228		.5601	.6348	.5093
21	.3772	.5601	.4854	.5601	.4904
22	.3018	.4481	.3734	.4481	.3361
23	.3018	.3734	.3174	.3696	.3174
24	.2629	.2801	.3361	.6478	.3605
Max	1.3283	1.5402	1.2651	1.2407	1.3077
Min	.2534	.2801	.3174	.3696	.3174
Avg	.7133	.827	.7237	.7083	.6059

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214407 / 33/11KV NIRGUDSAR

Feeder No / Name : 206 / 11KV BHARADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2347	.503	.4862	.1677	.1844
2	.5365	.503	.4694	.1844	.2012
3	.57	.5365	.503	.218	.218
4	.6036	.57	.5365	.3018	.2515
5	.6371	.6371	.6036	.3185	.285
6	.7209	.7712	.7042	.3521	.4527
7	.9556	.9724	.9389	.4359	.503
8	1.1568	1.1401	1.1568	.503	.503
9	1.2742	1.1736	1.2071	.4024	.4694
10	.3353	.3185	.3353	.3353	.4024
11	.3018	.3018	.3688	1.3413	1.3413
12	.4024	.3185	.3353	1.5424	1.3748
13	.3353	.3353	.3521	1.576	1.4754
14	.3688	.3688	.3185	1.5424	1.4754
15	.4024	.3185		1.5089	1.4083
16	.4359	.3521	.3353	1.5089	1.4083
17	.4024	.3521	.3688	1.3413	1.358
18	.4024	.4191	.3856	1.1065	1.2407
19	.4527	.4359	.4024	.4359	.4024
20	.4024	.3688	.3353	.4024	.3688
21	.3353	.2683	.3018	.3353	.3185
22	.2515	.2515	.2347	.285	.2347
23	.2012	.2012	.1844	.2347	.2012
24	.2347	.503	.4527	.1677	.2012
Max	1.2742	1.1736	1.2071	1.576	1.4754
Min	.2012	.2012	.1844	.1677	.1844
Avg	.4981	.4967	.4920	.6895	.6783

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214407 / 33/11KV NIRGUDSAR

Feeder No / Name : 207 / 11KV SUYOG INDUSTRIAL  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2587	.2075	.2587	.0343	.2801
2	.2033	.2263	.2241	.0267	.2641
3	.1867	.2241	.2054	.0191	.2241
4	.1509	.1867	.1886	.0286	.1646
5	.1086	.0914	.1494	.0171	.1267
6	.1698	.012	.1698	.0114	.0619
7	.1075	.1715	.1097	.0143	.0137
8	.1267	.1132	.0213	.0084	.0118
9	.0191	.0263	.0191	.0509	.0236
10	.0905	.1715	.021	.0905	.1886
11	.168	.2241	.0343	.0377	.1886
12	.1509	.1698	.0372	.2241	.1698
13	.0648	.0257	.0377	.2241	.2263
14	.0143	.0229	.04	.2614	.0747
15	.0914	.2614	.0648	.2561	.2614
16	.2378	.2641	.0857	.2241	.2587
17	.1509	.2587	.0857	.2241	.1698
18	.112	.1698	.0343	.1867	.1698
19	.1509	.0905	.0514	.0895	.1075
20	.0492	.0457	.0463	.0895	.0143
21	.1526	.0914	.0686	.1509	.0171
22	.2561	.2075	.056	.2241	.2452
23	.2402	.1848	.0895	.2587	.2054
24	.2743	.2075	.2402	.0914	.2587
Max	.2743	.2641	.2587	.2614	.2801
Min	.0143	.012	.0191	.0084	.0118
Avg	.1473	.1523	.0975	.1185	.1553

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214413 / 33/11KV MANCHAR

Feeder No / Name : 201 / 11 KV PIMPALGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.12	.8916	.9795
2	.1715	.1715	.12	.9945	1.0288
3	.1715	.1715	.1543	1.0288	1.0288
4	.1905	.1905	.1886	1.0288	1.2689
5	.2286	.2477	.2229	1.1145	1.406
6	.2572	.2477	.2572	1.1831	1.5432
7	.3429	.3772	.3429		1.6461
8	.3258	.3142	.3258	2.1434	2.1091
9	.2229	.2401	.2401	1.9204	1.9357
10	.2401	.2058	.2229	.1886	.1543
11	1.9814	2.3777	1.9814	.1543	.12
12	2.4691	2.4387	2.1338	.1372	.12
13	2.0576	2.4691	2.1643	.12	.12
14	2.5149	2.3777	2.1491	.1715	.12
15	2.2862	2.5149	2.0119	.1372	.0514
16	2.2405	2.5301	2.0119	.2058	.0514
17	2.0424	2.2862	1.9433	.2096	.1905
18	1.829	2.0576	1.6518	.2858	.2286
19	.3429	.2858	.2572	.3239	.3048
20	.3239	.2572	.2667	.2667	.2572
21	.3048	.2572	.2229	.2477	.2096
22	.1372	.2229	.1715	.2096	.2096
23	.1848	.1543	.2033	.1663	.1543
24	.1715	.1663	.12	.8916	.9088
Max	2.5149	2.5301	2.1643	2.1434	2.1091
Min	.1372	.1543	.12	.12	.0514
Avg	.8837	.9472	.8118	.6096	.6728

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214413 / 33/11KV MANCHAR

Feeder No / Name : 202 / 11kv AVSARI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.3086	.2591	.1029	.1132
2	.2401	.3086	.2915	.1132	.1132
3	.3086	.3429	.3239	.1132	.1132
4	.3086	.3772	.3887	.1886	.1029
5	.3429	.4287	.4858	.1886	.1886
6	.4458	.4801	.6802	.2641	.2452
7	.823	.9774	1.1984		.3206
8	1.2346	1.3032	1.4251	.2743	.4527
9	1.0669	1.3413	1.3717	.2058	.1715
10	.1715	.1715	.1372	.2058	.1715
11	.1543	.1372	.1372	1.3717	1.2193
12	.1029	.1029	.12	1.5851	1.5242
13	.1029	.1029	.1029	1.4632	
14	.1029	.1029	.1029	1.3108	1.4632
15	.12	.12	.1029	1.2651	1.4632
16	.1372	.12	.1029	1.3717	1.3108
17	.1372	.1715	.1029	1.2193	1.3717
18	.1715	.2286	.1372	.9602	1.0288
19	.2667	.2667	.2058	.2286	.2477
20	.2286	.1886	.2058	.2286	.2058
21	.2286	.2096	.1886	.2286	.2096
22	.1524	.1543	.1543	.1905	.1715
23	.132	.12	.1509	.132	.12
24	.1334	.2572	.2267	.1132	.1132
Max	1.2346	1.3413	1.4251	1.5851	1.5242
Min	.1029	.1029	.1029	.1029	.1029
Avg	.3019	.3467	.3584	.5794	.5409

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062] BU 5819

Substation No/ Name :- 214413 / 33/11KV MANCHAR

Feeder No / Name : 203 / 11 KV MANCHAR

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.9709	.8916	.8962	.8573
2	.7716	.9709	.8916	.8962	1.0082
3	.7716	1.307	1.0288	1.0082	1.1203
4	.823	1.4563	1.1145	1.1576	1.251
5	.8573	1.5684	1.2003	1.3443	1.4937
6	1.3032	1.5947	1.3032	1.475	1.7924
7	2.2634	1.9719	1.8347		2.0351
8	2.332	2.1434	2.1262	2.0351	2.4646
9	2.0233	1.749	2.0576	2.0576	1.8861
10	1.6804	1.7147	1.8519	1.6804	1.6461
11		1.5775	1.749	1.5432	1.4746
12	1.286	1.4746	1.5775	1.3717	1.5089
13	1.3375	1.4403	1.4403	1.4746	1.3717
14	2.4863	1.4403	1.3717	1.3717	1.3717
15	1.4232	1.4746	1.3717	1.3375	1.3032
16	1.6118	1.4232	1.4746	1.3717	1.3717
17	1.5432	1.5432	1.4746	1.5775	1.4575
18	1.8861	1.7147	1.6632	1.7147	1.5775
19	2.0576	1.8861	1.7147	1.8176	1.5775
20	1.7147	1.7833	1.5947	1.6118	1.6461
21	1.5089	1.5432	1.4746	1.5432	1.406
22	1.3032	1.3032	1.3203	1.2346	1.2689
23	1.2323	1.0631	1.0562	1.1763	.9945
24	.7716	1.0082	.8916	.1867	.9335
Max	2.4863	2.1434	2.1262	2.0576	2.4646
Min	.7716	.9709	.8916	.1867	.8573
Avg	1.4678	1.5051	1.4365	1.3862	1.4508

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214413 / 33/11KV MANCHAR

Feeder No / Name : 206 / 11kv Tawarewadi

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17	14-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.2587	.2743	.3086	.3326	
2	.3429	.2587	.2401	.3326	.3086	
3	.3429	.3696	.2401	.4435	.3944	
4	.4115	.3696	.3772	.499	.5601	
5	.4458	.4801	.463	.5658	.7095	
6	.6173	.6173	.5658	.5914	.7468	
7	.7888	.7392	.6687		.7762	
8	.6516	.7023	.7545	.7392	.7392	
9	.6173	.5487	.7202	.6001	.6516	.6173
10	.5487	.4801	.6001	.5144	.4801	
11	.5144	.4801	.6173	.6001	.5144	
12	.4801	.3429	.4801	.4458	.4801	
13	.4458	.4287	.4801	.4287		
14	.4115	.3772	.3772	.3429	.4458	
15	.3772	.4801	.4287	.3429	.4458	
16	.4287	.4801	.3772	.4115	.4287	
17	.4287	.5144	.4287	.4115	.4287	
18	.4801	.583	.463	.5487	.5144	
19	.6173	.6516	.583	.6173	.2915	
20	.583	.5487	.4973	.5658	.5487	
21	.4801	.5144	.463	.5144	.4973	
22	.4458	.4458	.4287	.4287	.4287	
23	.3326	.3258	.4108	.3086	.3258	
24	.3086	.2957	.3086	.3696	.3326	
Max	.7888	.7392	.7545	.7392	.7762	.6173
Min	.3086	.2587	.2401	.3086	.2915	.6173
Avg	.4768	.4705	.4687	.4753	.4949	.6173

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214413 / 33/11KV MANCHAR

Feeder No / Name : 207 / 11 kv chandoli gfss

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2263	.2401	.2641	.2641
2	.1715	.2263	.2058	.2641	.2641
3	.1715	.3395	.2058	.3772	.3734
4	.2058	.3429	.2743	.4338	.4527
5	.3086	.4904	.3429	.4715	.5093
6	.4458	.5658	.4801	.5281	.5658
7	.5144	.4801	.5487		.6036
8	.583	.4805	.583	.6036	.4527
9	.4287	.5144	.5144	.4801	.4801
10	.4287	.4801	.5144	.4287	.5144
11	.3772	.3772	.4287	.3429	.3772
12	.2058	.2572	.3429	.2743	.2743
13	.2572	.2058	.2743	.2743	.2743
14	.2058	.2058	.2572	.1715	.2743
15	.2058	.2058	.2572	.2058	.2058
16	.2572	.2743	.2743	.2058	.2743
17	.2743	.2572	.2915	.2058	.2401
18	.3429	.3086	.3429	.3429	.2915
19	.4801	.5144	.4973	.4458	.463
20	.4458	.4458	.4287	.4115	.4458
21	.3772	.3429	.3944	.3429	.3429
22	.3086	.3086	.3258	.3086	.3429
23	.3018	.2915	.2641	.3018	.2572
24	.2401	.2641	.2572	.2641	.2641
Max	.583	.5658	.583	.6036	.6036
Min	.1715	.2058	.2058	.1715	.2058
Avg	.3227	.3502	.3561	.3456	.3670



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214413 / 33/11KV MANCHAR

Feeder No / Name : 208 / 11 kv Mordewadi gfss  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5144	.5144	.5658	.5658
2	.4801	.5658	.4287	.5658	.5144
3	.4801	.6348	.4287	.6348	.6516
4	.5144	.583	.5487	.7545	.8215
5	.5487	.7545	.6516	.7545	.9808
6	.7545	.8676	.7888	.8299	1.0562
7	1.1317	1.0631	1.0117		1.1694
8	1.2517	1.1694	1.1145	1.358	1.307
9	1.2003	1.0974	1.2003	1.1317	1.166
10	1.286	1.166	1.1317	1.2346	1.0288
11	1.2346	1.2346	1.0631	1.0631	1.2003
12	1.2003	1.0288	.8916	1.0288	1.0974
13	1.0288	1.166	.823	1.0288	.8573
14	.9431	1.0288	.7716	.7716	1.0288
15	.9945	.8916	.7202	1.0288	.9259
16	1.0631	1.0288	.8573	1.0631	1.0288
17	1.1317	1.0288	.9088	1.1145	
18	.9259	1.0288	.9088	.9945	.9602
19	.7716	.9259	.9259	.8916	.9259
20	.7545	.823	.823	.8402	.823
21	.7545	.823	.7888	.6859	.823
22	.6859	.6859	.703	.6173	.7545
23	.679	.6344	.679	.6348	.6173
24	.3429	.6036	.5316	.5601	.5658
Max	1.286	1.2346	1.2003	1.358	1.307
Min	.3429	.5144	.4287	.5601	.5144
Avg	.8613	.8895	.8006	.8762	.9074

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062] BU 5819

Substation No/ Name :- 214413 / 33/11KV MANCHAR

Feeder No / Name : 211 / 11 KV Gov Polytechnic  
Express Feeder KV- 11 /  
OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	10-DEC-17
HR	Load (MW)
13	.0572
Max	.0572
Min	.0572
Avg	.0572

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214413 / 33/11KV MANCHAR

Feeder No / Name : 213 / 11 KV Tapneshwar

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0191	.0343	.0686	.0716
2	.0572	.0171	.0343	.0686	.1029
3	.0572	.0171	.0343	.1372	.1029
4	.0572	.0343	.0514	.1372	.1715
5	.0572	.0343	.0514	.1715	.2401
6	.0686	.0686	.0686	.2401	.2401
7	.1029	.0686	.0686		.3086
8	.0686	.0554	.0857	.5144	.5658
9	.0686	.0686	.0686	.4572	.4572
10	.0686	.0514	.0686	.0343	.0343
11		.4877	.5792	.0343	.0343
12	.6097	.4572	.6097	.0171	.0171
13	.5792	.5182	.5487	.0171	.0171
14	.6249	.503	.5335	.0171	.0171
15	.6097	.4877	.4572	.0171	.0171
16	.5487	.4725	.3506	.0171	.0171
17	.463	.4268	.3887	.0381	.0381
18	.4115	.3772	.1943	.0381	.0381
19	.0762	.0572	.0514	.0762	.0514
20	.0762	.0514	.0514	.0762	.0514
21	.0686	.0514	.0514	.0572	.0514
22	.0762	.0514	.0343	.0572	.0572
23	.0377	.0343	.0377	.0377	.0343
24	.0572	.0189	.0343	.0377	.0686
Max	.6249	.5182	.6097	.5144	.5658
Min	.0377	.0171	.0343	.0171	.0171
Avg	.2131	.1846	.1870	.1029	.1169

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214413 / 33/11KV MANCHAR

Feeder No / Name : 402 / 33 Kv Parag Express  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9321	3.0864	2.572	2.4177	2.5206
2	2.8807	3.3265	2.4691	2.7721	2.6612
3	2.9321	3.1047	2.3148	2.572	2.4691
4	2.7778	3.1047	2.572	2.6612	2.572
5	2.6749	2.9384	2.572	2.6612	2.572
6	2.4691	2.8275	2.6749	2.6057	2.6057
7	2.7263	2.9938	2.6235		2.6057
8	2.9321	2.9384	2.8292	3.1047	2.8829
9	2.7263	3.1379	2.8807	2.4691	2.7263
10	3.0864	2.9321	2.3663	3.035	2.9321
11	3.1379	3.3951	2.9321	3.1893	3.1893
12	3.3951	3.1893	2.6235	3.1379	3.035
13	3.3951	3.1379	2.3148	3.0864	2.9835
14	3.2407	2.8292	2.4177	2.6235	3.035
15	3.2922	2.9835	2.8292	1.6461	3.035
16	3.4979	3.3436	2.9321	2.4691	2.9835
17	3.4465	3.4465	2.9321	2.6749	3.1379
18	3.035	3.1379	2.7778	3.0556	3.2922
19	2.8807	2.6749	2.7263	2.572	2.9835
20	2.8807	2.7263	2.4691	2.6235	2.9835
21	3.0864	2.7778	2.572	2.9321	2.8292
22	2.9835	2.9321	2.7778	2.7778	2.7263
23	3.1379	2.8292	2.7721	2.6749	2.6749
24	2.9321	3.3819	2.572	2.7166	2.7166
Max	3.4979	3.4465	2.9321	3.1893	3.2922
Min	2.4691	2.6749	2.3148	1.6461	2.4691
Avg	3.0200	3.0490	2.6468	2.7165	2.8397

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214413 / 33/11KV MANCHAR

Feeder No / Name : 403 / 33 Kv Morade Food Express NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6461	1.6632	1.5432	1.386	1.6632
2	1.6975	1.6804	1.5432	1.4969	1.5432
3	1.749	1.9959	1.6461	1.4969	1.5524
4	1.8519	4.269	1.8004	1.6632	1.4403
5	1.8519	2.2177	1.9033	1.6632	1.3889
6	1.5947	2.3285	2.0062	1.6632	1.3889
7	1.4918	1.885	1.5947		1.3889
8	1.5947	6.9302	1.9547	1.4415	1.7187
9	1.749	2.2634	2.0576	1.8004	1.6461
10	1.6461	2.1091	1.6975	1.6975	1.749
11	1.6975	2.4177	1.9547	1.6975	1.749
12	1.6461	2.3663	1.8519	1.749	1.6975
13	1.5432	2.2634	1.9033	1.5947	2.0062
14	1.9547	2.0576	1.8004	1.5432	2.1091
15	1.6975	2.0062	1.9033	1.5432	2.0576
16	1.6461	2.3148	1.9033	1.749	2.0062
17	2.0576	2.2634	1.9547	1.8004	2.2119
18	2.0062	2.0062	1.9033	1.5432	1.9033
19	1.9033	1.8004	1.8519	1.8519	1.749
20	2.0062	1.8519	1.9033	1.5947	1.749
21	1.8004	1.9033	1.6975	1.6975	1.6461
22	1.9033	2.1605	1.749	1.749	1.749
23	2.0513	1.9033	1.9404	1.7741	1.8004
24	1.3889	1.5524	1.5432	1.386	1.5524
Max	2.0576	6.9302	2.0576	1.8519	2.2119
Min	1.3889	1.5524	1.5432	1.386	1.3889
Avg	1.7573	2.3421	1.8170	1.6340	1.7278

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214440 / 33/11KV KATHAPUR

Feeder No / Name : 201 / 11KV KATHAPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.056	.0754	.578	.5093
2	.0566	.056	.0754	.578	.5093
3	.0566	.0747	.0943	.5937	.5093
4	.0747	.0747	.0943	.6097	.5312
5	.0747	.0943	.0934	.6401	.5624
6	.0934	.1132	.112	.6874	.6009
7	.128	.1509	.112	.703	.6167
8	.0914	.112	.128	.7522	.6722
9	.0732	.0943	.0914	.7499	.7449
10	.0732	.0747	.0924	.061	.0754
11	.8684	.8642	.8002	.0537	.0754
12	.8697	.9122	.8539	.056	.0566
13	.8381	.9172	.8381	.0362	.0566
14	.8223	.8855	.8539		.0566
15	.8223	.8697	.8539	.0358	.0566
16	.8223	.8583	.8482	.0554	.0566
17	.8223	.8421	.828	.0503	
18	.7842	.852	.7926	.0934	
19	.0943	.0943	.0905	.0934	
20	.0934	.0943	.0732	.0943	
21	.0747	.0943	.0732	.0747	
22	.0739	.0943	.0739	.0747	
23	.0739	.0754	.0739	.0747	
24	.0566	.056	.0754	.578	.5093
Max	.8697	.9172	.8539	.7522	.7449
Min	.0566	.056	.0732	.0358	.0566
Avg	.3290	.3504	.3374	.3184	.3647

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214440 / 33/11KV KATHAPUR

Feeder No / Name : 202 / 11KV DEOGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.9686	1.004	.1867	.1867
2	.9602	.9686	.9717	.168	.1867
3	1.0279	1.0311	1.1336	.1848	.2054
4	1.0753	1.1203	1.2163	.2218	.2427
5	1.1385	1.2163	1.2967	.2957	.2801
6	1.2651	1.2955	1.5684	.3734	.3734
7	1.3443	1.5729	1.5813	.4481	.5228
8	1.7124	1.6964	1.6129	.4251	.4481
9	1.8027	1.7814	1.7078	.3326	.3511
10	.2561	.2402	.2427	.2012	
11	.112	.1448	.1663	1.6716	1.9498
12		.1867		1.8947	2.1538
13				2.0241	2.1862
14	.1086			1.906	2.2186
15	.1097	.168		1.9662	2.1792
16	.1463	.168	.2012	1.9498	2.13
17	.1791	.2218	.1829	1.8976	
18	.2926	.2587	.2587	1.656	
19	.4108	.2561	.3696	.362	
20	.3174	.2743	.3696	.3547	
21	.3174	.2957	.2957	.3174	
22	.2772	.2614	.2218	.2801	
23	.2402	.2241	.1867	.2033	
24	.2263	.9842	1.004	.1867	.1867
Max	1.8027	1.7814	1.7078	2.0241	2.2186
Min	.1086	.1448	.1663	.168	.1867
Avg	.6157	.6971	.7796	.8128	.9876

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214440 / 33/11KV KATHAPUR

Feeder No / Name : 203 / 11KV LAKHANGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2427	.2218	.2218	1.2967	1.2018
2	.2427	.2218	.2218	1.3123	1.2018
3	.2427	.2402	.2402	1.3748	1.2334
4	.2801	.2801	.2772	1.4373	1.2803
5	.3696	.3361	.3292	1.4937	1.3443
6	.4572	.4108	.4024	1.6248	1.4575
7	.5304	.5093	.4163	1.7444	1.5893
8	.4755	.4294	.4525	1.9685	1.9227
9	.3658	.2054	.3258	1.9444	1.9989
10	.3292	.2054	.2241	.1844	.1867
11	2.0165	2.1464	2.3205	.1463	.1848
12	2.3758	2.4453	2.5126	.1663	.2241
13	2.4291	2.6092	2.5606	.1433	.2241
14	2.3758	2.625	2.5396	.1433	.2054
15	2.2939	2.6566	2.1664	.1494	.1867
16	2.2611	2.5617	2.1348	.1629	.2054
17	2.2996	2.4291	2.0715	.1772	
18	2.1214	2.2348	1.8903	.2772	
19	.3174	.1829	.2926	.3326	
20	.3174	.2561	.2926	.3361	
21	.2801	.2561	.2772	.2987	
22	.2402	.2195	.2587	.2801	
23	.2195	.2218	.2402	.2402	
24	.2427	.2241	.2218	1.3283	1.2018
Max	2.4291	2.6566	2.5606	1.9685	1.9989
Min	.2195	.1829	.2218	.1433	.1848
Avg	.9719	1.0054	.9538	.7735	.9323



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214440 / 33/11KV KATHAPUR

Feeder No / Name : 204 / 11KV KATHAPUR GFFS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1235	.1524	.144	.128
2	.1115	.1235	.1524	.1372	.128
3		.1372	.1718	.1486	.144
4	.2134	.1677	.1875	.1875	.1943
5	.2058	.2315	.2	.2187	.2429
6	.2305	.3125	.2641	.2812	.3239
7	.3307	.4428	.2984	.4321	.4372
8	.2743	.3338	.2858	.2561	.3144
9	.1981	.0876	.2599	.2241	.2606
10	.1886	.0434	.2138	.144	
11	.1486	.0389	.1486	.0941	.0446
12		.1014		.0297	.0724
13	.0901	.0991		.0206	.06
14	.0412	.109	.064	.021	.072
15	.0366	.1189	.0743	.0274	.0754
16	.04	.1362	.0743	.0322	.1153
17	.0347	.176	.0854	.0251	
18	.144	.2073	.1372	.1238	
19	.2705	.189	.1463	.2469	
20	.2435	.2526	.2073	.2172	
21	.192	.2195	.2027	.192	
22	.1692	.2054		.1882	
23	.1448	.1524	.1524	.1337	
24	.12	.1235	.1581	.144	.128
Max	.3307	.4428	.2984	.4321	.4372
Min	.0347	.0389	.064	.0206	.0446
Avg	.1610	.1722	.1732	.1529	.1713

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214440 / 33/11KV KATHAPUR

Feeder No / Name : 205 / 11KV PONDEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.7968	.8583	.0762	.0953
2	1.0279	.7968	.8583	.0762	.0953
3	1.0753	.8436	.8907	.0953	.1143
4	1.1069	.9172	1.0753	.1132	.1524
5	1.1385	.9488	1.2176	.1509	.1905
6	1.2651	1.0437	1.4548	.1905	.2286
7	1.3108	1.2483	1.6446	.2477	.3239
8	1.4327	1.5023	1.6446	.2096	.2286
9	1.448	1.439	1.7394	.2096	.1905
10	.0572	.1143	.0754	.1524	.1715
11	.0754	.0953	.0754	1.9841	2.0325
12	.0953		.1509	2.0715	2.2138
13	.0953	.0754	.1132	2.1506	2.2455
14	.0953	.0754	.0953	1.9841	2.2929
15	.0953	.0754	.0762	2.0778	2.1822
16	.1143	.112	.0762	2.1032	2.2024
17	.1334	.112	.0762	1.9841	
18	.1524	.1463	.1143	1.7528	
19	.1905	.112	.1143	.2096	
20	.1715	.0747	.1905	.1905	
21	.1524		.1143	.1334	
22	.1143	.0943	.0953	.1334	
23	.0953	.0754	.0953	.1143	
24	.0572	.828	.8907	.0762	.0953
Max	1.448	1.5023	1.7394	2.1506	2.2929
Min	.0572	.0747	.0754	.0762	.0953
Avg	.4816	.5240	.5724	.7703	.8856

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062] BU 5819

Substation No/ Name :- 214458 / 33/11KV RANJANI

Feeder No / Name : 201 / 11 KV RAJANI

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	08-DEC-17	09-DEC-17	10-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
2	.4115		
7	.9259		
8			1.4403
9	1.5775		
10		.3772	
11		.3086	
14		.3429	
19		.4801	
24			.4801
Max	1.5775	.4801	1.4403
Min	.4115	.3086	.4801
Avg	.9716	.3772	.9602

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062] BU 5819

Substation No/ Name :- 214458 / 33/11KV RANJANI

Feeder No / Name : 202 / 11KV WALTI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
2	1.166		
8	2.0233		2.2634
9	2.4348		
10		.4115	
11		.4115	
19		.5487	
24			1.2003
Max	2.4348	.5487	2.2634
Min	1.166	.4115	1.2003
Avg	1.8747	.4572	1.7319

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062] BU 5819

Substation No/ Name :- 214458 / 33/11KV RANJANI

Feeder No / Name : 203 / 11KV-GANJEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
2	.3944		
8	1.0117		1.3032
9	1.2689		
10		.2058	
11		.2229	
14		.2915	
19		.2743	
24			.4458
Max	1.2689	.2915	1.3032
Min	.3944	.2058	.4458
Avg	.8917	.2486	.8745

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062] BU 5819

Substation No/ Name :- 214458 / 33/11KV RANJANI

Feeder No / Name : 204 / 11 KV THORANDALE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
2	.3086		
8	1.0288		.8916
9	.823		
10		.583	
11		1.8176	
14		2.0576	
19		.6516	
24			.2743
Max	1.0288	2.0576	.8916
Min	.3086	.583	.2743
Avg	.7201	1.2775	.5830

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062] BU 5819

Substation No/ Name :- 214458 / 33/11KV RANJANI

Feeder No / Name : 205 / WESTORN HILLS

Feeder KV- 11 / OUTGOING

SHEDDABLE HV(AGRICULTURE)

DATE	08-DEC-17	09-DEC-17
HR	Load (MW)	Load (MW)
2	.0017	
9	.0017	
10		.0017
14		.0017
19		.0017
Max	.0017	.0017
Min	.0017	.0017
Avg	.0017	.0017

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062] BU 5819

Substation No/ Name :- 214458 / 33/11KV RANJANI

Feeder No / Name : 206 / 11KV NAGAPUR

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	08-DEC-17	09-DEC-17	10-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
2	.2229		
8	.4801		
9	.3944		.3601
10		.2743	
11		1.3889	
14		1.5432	
19		.2743	
24			.1886
Max	.4801	1.5432	.3601
Min	.2229	.2743	.1886
Avg	.3658	.8702	.2744



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214475 / 33/11kV PIMPALGAON

Feeder No / Name : 201 / 11kV Shriram

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17	14-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0543	.0953	.1448	
2	.0381	.0381	.0543	.1143	.181	
3	.0381	.0381	.0543	.1143	.1448	
4	.0572	.0381	.0543	.1524	.181	
5	.0572	.0572	.0543	.1524	.2172	
6	.0572	.0572	.0543	.1905	.2534	
7	.0572	.0762	.0724	.2667	.2896	
8	.0762	.0724	.0724	.2858	.4163	
9	.0572	.0543	.0543	.2477	.5249	
10	.0572	.0362	.0362	.0381	.0381	
11	.6668	.4805	.5335	.0381	.0381	
12	.8192	.5544	.5906	.0381	.0381	
13	.8192	.6653	.6287	.0381	.0381	
14	.8002	.6838	.5906	.0381		
15	.7811	.6838	.5144	.0381	.0381	
16	.6859	.5729	.4572	.0362	.0381	
17	.6478	.5175	.4191	.0362	.0381	
18	.5716	.3696	.3048	.0543	.0572	
19	.0572	.0543	.0572	.0543	.0572	.0572
20	.0572	.0543	.0762	.0543	.0572	.0572
21	.0762	.0543	.0572	.0543		.0572
22	.0572	.0543	.0572	.0543		.0572
23	.0381	.0543	.0572	.0543		.0572
24	.0572	.0381	.0543	.0953	.1267	
Max	.8192	.6838	.6287	.2858	.5249	.0572
Min	.0381	.0362	.0362	.0362	.0381	.0572
Avg	.2779	.2226	.2066	.0976	.1459	.0572

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214475 / 33/11kV PIMPALGAON

Feeder No / Name : 202 / 11kV Kaniphnath

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0905		.7964
2	.0953	.0762	.0905		.7964
3	.0953	.0953	.0905		.8688
4	.1334	.1143	.0905		.9412
5	.1524	.1334	.1448		.9412
6	.1905	.1715	.2172		1.267
7	.1905		.2172		1.3306
8	.2286		.1991		1.6832
9	.1715		.181		1.6832
10	.1334	.1267	.1267		.1334
11	2.0957	1.9774			.0953
12	2.191	2.0513		.0953	.0953
13	2.2672	2.1622			.0953
14	2.1338	1.9589			.0762
15	2.1338	1.9774	1.8861		.0762
16	2.0195	1.9404		.0905	.0953
17	1.9433	1.7741		.1086	.1143
18	1.9052	1.6078		.1267	.1143
19	.1715	.1448		.1629	.1524
20		.1448		.1629	.1524
21		.1448		.181	
22		.1086		.1267	
23		.0905		.0905	
24	.0953	.0953	.0905		.7602
Max	2.2672	2.1622	1.8861	.181	1.6832
Min	.0953	.0762	.0905	.0905	.0762
Avg	.9221	.8091	.2854	.1272	.5842

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214475 / 33/11kV PIMPALGAON

Feeder No / Name : 203 / 11kV Khadaki

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17	14-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.8002	1.1041	.1524	.181	
2	1.0479	.8002	1.1283	.1715	.181	
3	1.1431	.9526	1.1584	.1905	.181	
4	1.3146	1.0288	1.267	.2286	.2172	
5	1.5242	1.3336	1.3575	.2858	.2534	
6	1.7147	1.4289	1.4661	.381	.4344	
7	1.829	1.8099	1.8296	.4954	.4525	
8	2.0386	1.9728	2.0883	.362	.3439	
9	2.21	1.9366	2.0144	.2667	.2172	
10	.2096	.181	.1629	.2096	.1524	
11	.1334	.1448	.1524	2.0767	2.2862	
12	.1524	.1267	.1334	2.191	2.3434	
13	.1524	.1267	.1334	2.1719	2.3053	
14	.1334	.1448	.1524	2.2862	2.2862	
15	.1334	.1629	.1715	2.3624		
16	.1524	.1629	.1715	2.2916	2.3624	
17	.1524	.181	.2286	2.2546		2.21
18	.2286	.2353	.2477	2.0698	2.0386	2.1148
19	.362	.3077	.3429	.3258	.1905	.2667
20	.3429	.3077	.3048	.3258	.2096	.3429
21	.3048	.2896	.2286	.2896		.3048
22	.2096	.2353	.1905	.2353		.2286
23	.1905	.1991	.1524	.1991		.1905
24	.1715	.8002	1.0679		.181	
Max	2.21	1.9728	2.0883	2.3624	2.3624	2.21
Min	.1334	.1267	.1334	.1524	.1524	.1905
Avg	.6676	.6529	.7189	.9488	.8851	.8083

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214518 / 33/11KV PIMPARKHED

Feeder No / Name : 201 / 11KV MUKTAI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0819		.0819	.1943	.2984
2	.0819		.0819	.2105	.2818
3	.0819		.0819	.2347	.2652
4	.081	.081	.0819	.2534	.2984
5	.0819	.08	.0983	.2987	.3149
6	.0819	.0983	.1311	.1879	.3018
7	.0819	.0972	.1311	.0126	.2984
8	.0819	.081	.0819	.2494	.3315
9		.08	.0819	.2538	.3725
10	.081	.08	.0838	.0829	.0671
11	.2753	.3932	.3185	.081	.0671
12	.3361	.3277	.3353	.0663	
13	.3725	.3277	.3353	.0655	.0671
14	.3768	.3113	.3521	.0663	.0747
15	.3887	.2949	.3077	.0663	.0754
16	.3887	.2622	.1989	.0829	.0671
17	.3563	.2458	.2515	.0838	.0671
18	.3401	.2294	.2515		.0671
19	.0926	.0819	.0671	.0829	.0671
20	.096	.0819	.0587	.0829	.0671
21	.0983	.0819	.0671	.0819	.0671
22	.08	.0819	.0671	.0995	.0754
23	.08	.0819	.2012	.0995	.0671
24	.0848	.081	.0819	.2012	.2984
Max	.3887	.3932	.3521	.2987	.3725
Min	.08	.08	.0587	.0126	.0671
Avg	.1783	.1657	.1596	.1364	.1721

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214518 / 33/11KV PIMPARKHED

Feeder No / Name : 202 / 11KV KATHAPUR ROAD

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.4527	.3647
2				.5788	.3978
3				.3647	.4024
4		.128		.3978	.4359
5		.1296		.431	.4641
6		.1311		.4531	.6796
7		.1311		.8215	.6796
8		.0972		.6455	.6962
9		.0972		.6344	.9282
10	.081	.081	.1006	.0983	.0838
11	.7373		.7316	.0995	.0934
12	.8097		.8259	.0829	
13	.8097		.8907	.0995	.0553
14	.8192		1.0185	.0829	.0838
15	.7701		.9997	.0829	.0553
16	.7935		.5857	.0829	.081
17	.7701		.7545	.0829	.1341
18	.7373		.6371	.1326	.1509
19	.1134		.0943	.1326	
20	.1619		.1006	.1174	.1174
21	.16		.1006	.1326	.1174
22	.16		.1132	.0972	.128
23	.1619		.4527		.1174
24		.1619		.4527	.3315
Max	.8192	.1619	1.0185	.8215	.9282
Min	.081	.081	.0943	.0829	.0553
Avg	.5061	.1196	.5290	.2851	.2999

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214518 / 33/11KV PIMPARKHED

Feeder No / Name : 204 / 11kv PIMPARKHED GFFS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0819		.0819	.1494	.1326
2	.0819		.0819	.1296	.1326
3	.0972		.0983	.1494	.1492
4	.1311	.128	.1219	.1296	.1341
5	.1638	.1457	.1638	.168	.1326
6	.1966	.1457	.1619	.1048	.0995
7	.1638	.1475	.1966	.1551	.0995
8	.1311	.1296	.1311	.0781	.0829
9		.1296	.1311	.1698	.1326
10	.08	.112	.0884	.0983	.0663
11	.096	.1147	.1341	.0838	.1509
12	.0972	.1147	.1219	.0671	
13	.1107	.0819	.1219	.0829	.1341
14	.1134	.0819	.1341	.0838	
15	.112	.0819	.1341	.081	.1509
16	.096	.0819		.0829	.1509
17	.1147	.0983	.1509	.0829	.1467
18	.1311	.1311	.1509	.0829	.1844
19	.128	.1311	.1844	.1174	
20	.1296	.1696	.2012	.0829	.1677
21	.1296	.1966	.1467	.096	.1677
22	.1296	.1638	.1886	.0819	.1677
23	.128	.1311	.1509	.0995	.1698
24	.0819	.128	.0819	.1296	
Max	.1966	.1966	.2012	.1698	.1844
Min	.08	.0819	.0819	.0671	.0663
Avg	.1185	.1259	.1373	.1078	.1376

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214518 / 33/11KV PIMPARKHED

Feeder No / Name : 205 / 11kv PIMPARKHED

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1638		.7209	.1509	
2	.5571		.7701	.1269	
3	.5735		.8029	.132	.2486
4	.6882	.8907	1.0159	.132	
5	.8478	.9831	1.3535	.1833	.2486
6	1.0814	1.065	1.1961	.2494	.1492
7	1.1469	1.2289	1.2616	.547	.2984
8		1.3123	1.3108	.4694	.2012
9		1.2793	1.3108	.4024	.2347
10	.192	.1619	.1844	.1457	.2075
11	.096	.2035	.1341	1.2631	1.643
12	.081	.1658	.1341	1.2929	
13	.081	.1311	.1296	1.3245	1.1904
14	.08		.1341	1.326	1.2239
15	.0972	.1296	.1509	1.326	1.2574
16	.096	.1463	.1341	1.3592	1.2239
17	.0972	.1475	.1341	1.326	1.073
18	.1619	.2294	.1509	1.326	1.1763
19	.2429	.3475	.1475	.1326	.1509
20	.3201	.3932	.1509	.1341	.1509
21	.3681	.3439	.1457		.1509
22	.2881	.2622	.1698		.1509
23	.2429	.1707	.1698	.2012	.1509
24	.1966	.5601	.0922	.1509	.2321
Max	1.1469	1.3123	1.3535	1.3592	1.643
Min	.08	.1296	.0922	.1269	.1492
Avg	.3500	.5076	.4960	.6228	.5681

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214518 / 33/11KV PIMPARKHED

Feeder No / Name : 206 / 11KV TUKAI DEVI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0328		.4752	.0335	
2	.5243		.4915	.0335	.3315
3	.5898		.5898	.0293	.0328
4	.6554		.6554	.0293	.0332
5	.7373	.9831	.7209	.0335	.0332
6	.7209	.9831	.7865	.0293	.0328
7	.8684	.9717	.8192	.0179	.0324
8	.8848	.9995	.9036	.0221	.0324
9	.8848	.9878	.852	.0282	.0332
10	.0324	.032	.0293	.0324	.0335
11	.0324	.0366	.0335	1.0526	.7125
12	.0324	.0328	.0335	1.0277	
13	.032	.0366	.0324	.9945	1.2407
14	.0324	.0328	.0335	1.0059	.8177
15	.032	.0328	.0221	.9945	1.2407
16	.0328	.0328		.9779	1.1498
17	.032	.0328	.0377	.9448	1.1736
18	.032	.0328	.0335	.9448	1.1065
19	.0324	.0328	.0282	.0332	.0335
20	.032	.0328	.0221	.0324	.0335
21	.0324	.0328	.0293	.0335	.0335
22	.0324	.0328	.0377	.0324	.0335
23	.0324	.0324	.0335	.0332	.0335
24	.0328	.6478	.3441	.0335	.0332
Max	.8848	.9995	.9036	1.0526	1.2407
Min	.032	.032	.0221	.0179	.0324
Avg	.2660	.3019	.3063	.3512	.3744



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214518 / 33/11KV PIMPARKHED

Feeder No / Name : 207 / 11KV CHANDOH

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2458		.2622	.6179	.8048
2	.2949		.2949	1.0709	.8122
3	.2949		.3734	1.358	1.0174
4	.4588	.3201	.4755	1.2548	1.0898
5	.3441	.3277	.5735	.8507	1.1401
6	.3932	.4111	.4915	1.1161	1.3094
7	.5079	.4534	.5079	1.1382	1.6598
8		.4096	.5243	1.2155	1.6244
9		.3441	.3441	1.2929	1.6598
10	.2429	.2401	.2286	.0983	.2452
11	1.8299	2.1956	1.9113	.0995	.2263
12	2.0325	2.1628	1.2929	.1341	
13	2.17	2.13	2.1262	.1492	.1677
14	2.17	2.1136	2.0622	.1492	.1698
15	2.0405	1.906	2.3011	.1658	.1698
16	2.0567	1.8842	2.0119	.1619	.1509
17	1.9334	1.8023	2.0936	.0995	.1886
18	1.9109	1.7532	1.6933	.1658	.2012
19	.3239	.1966	.2267	.1823	.2012
20	.4372	.3932	.218	.2012	.1844
21	.4481	.5898	.1216	.2321	.1844
22	.3361	.5304	.1829	.2429	.1216
23	.2881	.3441	1.0059	.2652	.9619
24	.4572	.2561	.2458	1.1317	.779
Max	2.17	2.1956	2.3011	1.358	1.6598
Min	.2429	.1966	.1216	.0983	.1216
Avg	.9644	.9888	.8987	.5581	.6552

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214521 / 33/11KV SHINGAVE

Feeder No / Name : 201 / 11KV PARGAON ROAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	10-DEC-17	11-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0762		.1677
2	.0762		.2012
3	.0762		.2622
4	.0762		.2683
5	.0953		.2949
6	.1143		.4481
7	.1334		.4115
8	.1524		.4268
9	.1524		.4268
10	.1334		.0732
11	.6859	.4877	
12		.5182	
13		.503	
14		.5571	
15		.5407	
16		.5312	
17		.4572	
18		.4268	
19		.1463	
20		.1097	
21		.1097	
22		.1097	
23		.0732	
24	.0762		.1677
Max	.6859	.5571	.4481
Min	.0762	.0732	.0732
Avg	.1540	.3516	.2862

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062] BU 5819

Substation No/ Name :- 214521 / 33/11KV SHINGAVE

Feeder No / Name : 202 / 11KV SANGAM

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	10-DEC-17	11-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0191		.1638
2	.0191		.1638
3	.0191		.1966
4	.0191		.2294
5	.0191		.2294
6	.0191		.2622
7	.0191		.2622
8	.0191		.2622
9	.0191		.2622
10	.0191		.0187
11	.3429	.2743	.2683
12		.2743	
13		.2743	
14		.2683	
15		.2683	
16		.2683	
17		.2743	
18		.2743	
19		.0187	
20		.0187	
21		.0187	
22		.0187	
23		.0187	
24	.0191		.1715
Max	.3429	.2743	.2683
Min	.0191	.0187	.0187
Avg	.0461	.1746	.2075

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214521 / 33/11KV SHINGAVE

Feeder No / Name : 203 / 11KV SHINGAVE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	10-DEC-17	11-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2286		.2195
2	.7621		.2195
3	.7811		.2561
4	.8002		.2926
5	.8383		.3292
6	.8764		.4024
7	.9335		.4755
8	.9907		.5014
9	1.0479		.5121
10	.1715		.4024
11	.2286	.2926	
12		.2012	
13		.1829	
14		.197	
15		.2149	
16		.2328	
17		.2561	
18		.3658	
19		.3292	
20		.3292	
21		.2926	
22		.2926	
23		.2195	
24	.2667		.2195
Max	1.0479	.3658	.5121
Min	.1715	.1829	.2195
Avg	.6605	.2620	.3482

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214521 / 33/11KV SHINGAVE

Feeder No / Name : 204 / 11KV WADI MALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	10-DEC-17	11-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0762		.1097
2	.2858		.1097
3	.3048		.1097
4	.3239		.1097
5	.3429		.1097
6	.362		.1463
7	.381		.1463
8	.4191		.1463
9	.4382		.1097
10	.0572		.1097
11	.0572	.0732	
12		.0732	
13		.0732	
14		.1029	
15		.1097	
16		.1097	
17		.1097	
18		.1097	
19		.1097	
20		.1097	
21		.1097	
22		.1097	
23		.1075	
24	.0953		.1097
Max	.4382	.1097	.1463
Min	.0572	.0732	.1097
Avg	.2620	.1006	.1197

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214521 / 33/11KV SHINGAVE

Feeder No / Name : 205 / 11KV BHAGDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	10-DEC-17	11-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1334		.2743
2	.1143		.2743
3	.1143		.2915
4	.1143		.3086
5	.1143		.2949
6	.1334		.3113
7	.1524		.2949
8	.1524		.2949
9	.1524		.2743
10	.1143		.1097
11	.4382	.3277	
12		.3277	
13		.3441	
14		.3018	
15		.3185	
16		.3018	
17		.2401	
18		.2058	
19		.1463	
20		.1463	
21		.1463	
22		.1097	
23		.1097	
24	.1524		.2743
Max	.4382	.3441	.3113
Min	.1143	.1097	.1097
Avg	.1572	.2328	.273

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062] BU 5819

Substation No/ Name :- 214521 / 33/11KV SHINGAVE

Feeder No / Name : 206 / 11KV DATTA MANDIR  
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	08-DEC-17	10-DEC-17	11-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.743		.7468
2	.724		.823
3	.724		.823
4	.743		.884
5	.7621		.9145
6	.8002		1.0059
7	.8383		1.0059
8	.8573		1.0669
9	.8764		1.1797
10	.8192		.8048
11	1.3336	.9145	
12		1.0364	
13		1.0814	
14		.9755	
15		.9755	
16		.9602	
17		.945	
18		.945	
19		.7316	
20		.8048	
21		.8413	
22		.8048	
23		.8048	
24	.7621		.7682
Max	1.3336	1.0814	1.1797
Min	.724	.7316	.7468
Avg	.8319	.9093	.9112

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214529 / 33/11KV LONI

Feeder No / Name : 201 / KHADAKWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17	13-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2378	.2241	.2614	.5014	.3658
2	.2743	.2378	.2614		.5014	.4024
3	.2743	.2561	.2241	.3734	.5373	.4207
4	.2743	.2561	.2801	.3734	.5552	.4938
5	.2743	.2561	.3547	.6161	.5552	.4938
6	.3086	.3292	.3734	.7095	.5552	.6219
7	.3258	.4755	.4108	.7468	.5552	.695
8	.2915	.4755	.4668	.7842	.4656	.7316
9	.3086	.5487	.4481	.6722	.4656	.7316
10	1.0059	.4755	.3734	.2614	.4656	.6584
11	1.0059		.6722	.2614	.3045	
12	.9877	1.0608	.7468	.2614	.3045	
13	.9877	1.0974	.8215	.2427	.3224	
14	.9511	1.0608	.8962	.2427	.3224	
15	.9145	1.0059	.8589	.2241	.3045	
16	.7865	.9511	.7842	.2427	.3045	
17	.2926	.9145	.7095	.1867	.2865	
18	.2926	.8048	.6535	.168	.2865	
19	.2743	.3898	.6535	.1307	.2865	
20	.2743	.3841	.4108		.2686	
21	.2743	.4024	.4481	.2534	.2686	
22	.2743	.3292	.4108		.2328	
23	.2561	.2926	.3361	.2241	.2378	
24	.2427	.2378	.2241	.2614	.2328	.3658
Max	1.0059	1.0974	.8962	.7842	.5552	.7316
Min	.2058	.2378	.2241	.1307	.2328	.3658
Avg	.4733	.5426	.5018	.3570	.3800	.5437



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062] BU 5819

Substation No/ Name :- 214529 / 33/11KV LONI

Feeder No / Name : 202 / LONI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17	13-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2172	.362	.4694	.2683	.2353	.2427
2	.4706	.3982	.503	.2347	.2534	.2427
3	.5068	.4344	.503	.2347	.2507	.2427
4	.543	.4706	.4862	.3018	.2507	.2774
5	.6516	.4706	.5868	.4359	.2507	.2774
6	.6878	.543	.6539	.503	.2865	.3121
7	.7602	.6516	.6706	.5365	.2865	.3121
8	1.0498	.6516	.6371	.4694	.6805	.3467
9	.905	.6516	.7042	.4359	.6805	.3814
10	.8145	.6516	.3185	.3688	.6805	.3814
11	.2896	.4854	.3353	.4527	.6984	
12	.2896		.3353	.503	.7164	
13	.2896	.3467	.3353	.5868	.7164	
14	.2896	.3814	.3688	.7377	.7522	
15	.362	.3467	.4024	.6874	.8596	
16	.4344	.3467	.4024	.8048	.8596	
17	.3258	.3814			.7628	
18	.3258	.4161	.4359	.788	.5731	
19	.3258	.4161	.4024	.4527	.3224	
20	.3258	.3988	.4359	.6036	.3224	
21	.3258	.3814	.3688	.2601	.3582	
22	.2896	.2774	.3353	.503	.3582	
23	.2896	.1734	.3018	.2601	.3121	.3467
24	.3121	.2896	.4862	.3018	.2353	.2427
Max	1.0498	.6516	.7042	.8048	.8596	.3814
Min	.2172	.1734	.3018	.2347	.2353	.2427
Avg	.4617	.4316	.4556	.4666	.4876	.3005

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062] BU 5819

Substation No/ Name :- 214529 / 33/11KV LONI

Feeder No / Name : 203 / DHAMNI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17	13-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2507	.3224	.2454	.3155	.4656	.4298
2	.3224	.3224	.2279	.3155	.5014	.4298
3	.3224	.3582	.2454	.3506	.5014	.4477
4	.3582	.3582	.3155	.3856	.8417	.5014
5	.3582	.394	.5258	.631	.8954	.5373
6	.4656	.3761	.6661	.7712	.8954	.6447
7	.5373	.3582	.7537	.9114	.8954	.7164
8	.5731	.3544	.6661	.7712	.6805	.7522
9	.6089	.4656	.5609	.7011	.6447	.7522
10	.6089	.4656	.4382	.2804	.4656	.7522
11	1.0029	.7164	.7362	.2454	.4656	
12	1.0029	.8059	.8413		.4298	
13	1.0387	.8417	.964	.2103	.394	
14	1.0387	.8059	.9114	.2103	.3582	
15	1.0745	.7522	.8413	.2103	.3582	
16	1.1283	.7164	.7011	.3856	.3403	
17	1.1283	.7164	.631	.2103	.3582	
18	.4656	.7522	.5959	.2454	.5373	
19	.4656	.4477	.631		.4656	
20	.4656	.394	.7011	.2629	.4298	
21	.4477	.4298	.631	.2804	.394	
22	.4477	.3224	.5784	.2804	.3582	
23	.4119	.2507	.3506	.2804	.2865	
24	.2865	.3224	.2103	.3506	.2865	.2686
Max	1.1283	.8417	.964	.9114	.8954	.7522
Min	.2507	.2507	.2103	.2103	.2865	.2686
Avg	.6171	.5021	.5821	.3912	.5104	.5666

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062] BU 5819

Substation No/ Name :- 214529 / 33/11KV LONI

Feeder No / Name : 204 / SAHARA MILK

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	13-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0747	.0554	.0554	.056
2	.0747	.056	.0554	.0554	.056
3	.0747	.0747	.0554	.0554	.056
4	.0747	.0747	.0554	.0554	.0747
5	.0747	.0747	.0924	.0554	.056
6	.0934	.0747	.1294	.0554	.0747
7	.0657	.0747	.1294	.0554	.0747
8	.092	.0934	.1294	.0739	.112
9	.0934	.0934	.1478	.0739	.112
10	.0934	.0934	.1478	.1663	.112
11	.112	.112	.1294	.1227	
12	.1307	.112	.1478	.0739	
13	.1307	.112	.1663	.1109	
14	.112	.112	.0895	.0924	
15	.112	.112	.0739	.0924	
16	.112	.0934	.0924		
17	.0934	.0934	.0924	.0924	
18	.0934	.0934	.0924	.0739	
19	.0934	.0747	.1109		
20	.0934	.0747	.1109	.1109	
21	.056	.0747	.0924	.1294	
22	.056	.056	.0739	1.7002	
23	.056	.056	.0739	.1294	
24	.0747	.056	.056	.0554	.056
Max	.1307	.112	.1663	1.7002	.112
Min	.056	.056	.0554	.0554	.056
Avg	.0890	.0840	.1	.1584	.0764

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062] BU 5819

Substation No/ Name :- 214538 / 33/11KV AWASARI

Feeder No / Name : 201 / TAVREWADI

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168	.1886	.1886	.1903	.2641
2	.168	.1886	.2075	.1903	.3018
3	.2263	.1886	.2075	.2284	.3395
4	.3018	.2641	.3018	.2665	.3772
5	.3772	.3206	.3584	.3045	.415
6	.5281	.5093	.4715	.5139	.4338
7	.6602	.679	.5847		.679
8	.6413	.6036		.7196	.679
9	.4715	.4481		.4909	.5093
10	.3961	.3366		.3813	.3772
11	.3077	.3224		.3292	.3109
12	.2561	.2149		.2658	.2481
13	.2715	.2507		.2534	.2353
14	.2353	.2012		.2481	.2172
15	.2378	.2218		.2481	.0895
16	.3258	.2328		.2686	.2195
17	.2629	.3258		.3224	.3189
18	.4207	.3696		.072	.3696
19	.5093	.415		.5228	.5415
20	.4668	.415		.4481	.4715
21	.415	.2829		.3961	.3961
22	.3206	.2452		.3018	.3206
23	.2075	.2054		.2241	.2263
24	.1867	.2075	.2075	.2094	.2075
Max	.6602	.679	.5847	.7196	.679
Min	.168	.1886	.1886	.072	.0895
Avg	.3484	.3182	.3159	.3215	.3562

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214538 / 33/11KV AWASARI

Feeder No / Name : 202 / GAWADEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0267	.0149	.0417	.0572
2	.0366	.0297	.2458	.0418	.0572
3	.0183	.0347	.0281	.042	.0667
4	.025	.0343	.0305	.0413	.0667
5	.2675	.0343	.0372	.0416	.0857
6	.0206	.0463	.0492	.0708	.0869
7	.0191	.0372	.0789		.0892
8	.0972	.0867		.0869	.0695
9	.1216	.084		.0498	.0526
10	.0914	.0583		.0404	.0526
11	.0553	.0305		.0429	.1021
12	.0581	.0351		.0427	.176
13	.0326	.0303		.0448	.1635
14	.0236	.0221		.1433	.1395
15	.0229	.0221		.1536	.1257
16	.0303	.032		.2134	.1341
17	.0297	.0326		.1509	.1511
18	.0332	.0543		.16	.1257
19	.0564	.0754		.0518	.0734
20	.0556	.0777		.0556	.0724
21	.0434			.0587	.0743
22	.0267	.0629		.0714	.0579
23	.0251	.0553		.0553	.0434
24	.0396	.0206	.045	.0414	.0572
Max	.2675	.0867	.2458	.2134	.176
Min	.0183	.0206	.0149	.0404	.0434
Avg	.0527	.0445	.0662	.0757	.0909

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

MANCHAR[062] BU 5819

Substation No/ Name :- 214538 / 33/11KV AWASARI

Feeder No / Name : 203 / BHAIKAVNATH

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0657	.0686	.061	.0158	.048
2	.0667	.0564	.0617	.0178	.1097
3	.0857	.0572	.0791	.0219	.0594
4	.1217	.0892	.0724	.0113	.0934
5	.1448	.1204	.1174	.0076	.0869
6	.1692	.1783	.1204	.0126	.0442
7	.2229	.2229	.2258		.0669
8	.208	.2006		.0254	.0167
9	.1467	.1486		.148	.0197
10	.0857	.0869		.1113	.0597
11	.0934	.0567		.0714	.0579
12	.0972	1.0277		.0488	.0442
13	.1235	.012		.0686	.048
14	.1334	.0198		.0495	.0488
15	.1257	.0206		.0743	.045
16	.1349	.0912		.0591	.0457
17	.144	.0112		.06	.06
18	.0686	.085		.06	.0823
19	.1337	.1027		.141	.1355
20	.1486	.104		.1143	.132
21	.1054	.0857		.1158	.1189
22	.088	.0857		.1	.0857
23	.0714	.0695		.0695	.0695
24	.0857	.0676	.0705	.0158	.0556
Max	.2229	1.0277	.2258	.148	.1355
Min	.0657	.0112	.061	.0076	.0167
Avg	.1196	.1279	.1010	.0617	.0681

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214411 / 33/11KV S/S SHIROLI

Feeder No / Name : 201 / BORI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	1.3117	1.2492	.4338	.3961
2	1.5741	1.3117	1.2492	.4338	.3961
3	1.5741	1.358	1.2803	.4715	.3961
4	1.6204	1.4586	1.3279	.5281	.4715
5	1.7444	1.4918	1.3927	.6722	.5415
6	1.8896	1.6741	1.5415	.7577	.6348
7	1.7072	2.0222	1.9393	.7655	.7655
8	2.1822	2.2211	2.0719	.7468	.7095
9	2.2138	2.2348	2.0809	1.773	.679
10	.7865	.6224	.6478	.6602	.6413
11		.6224	.5975	2.2834	1.8461
12	.6097	.6036	.6224	2.5724	2.4615
13	.6413	.6224	.6224	2.4291	2.5526
14	.6668	.6224	.6097	2.4486	
15	.6602	.6224	.6224	2.4006	
16	.6224	.6224	.679	2.3045	2.4615
17	.6859	.6413	.6859	2.3205	2.4646
18	.6224	.7621	.7049	2.2611	2.3365
19	.7922	.7733	.7733	.6413	.7167
20	.7167	.7922	.7356	.6413	.6979
21	.6602	.7167	.6979	.5906	.5658
22	.5847	.6287	.5658	.4954	.5658
23	.4715	.6097	.4763	.4527	
24	.4904	1.2955	1.2334	.4338	.3961
Max	2.2138	2.2348	2.0809	2.5724	2.5526
Min	.4715	.6036	.4763	.4338	.3961
Avg	1.0438	1.0684	1.0170	1.2299	1.0808

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214411 / 33/11KV S/S SHIROLI

Feeder No / Name : 202 / SALWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.2972	.2286	.6099	1.0974
2	.3601	.2972	.2343	.6099	.5487
3	.3715	.3071	.2401	.6468	.5853
4	.4275	.3841	.2926	.7095	.6401
5	.4938	.6401	.3563	.7842	.7095
6	.6401	.5719	.5005	.8865	.811
7	.7811	.7209	.6478	1.2696	1.1203
8	.7621	.7628	.7373	1.2696	1.4003
9	.7619	.703	.7202	1.4842	1.3957
10	.7442	.6762	.6274	.4527	.4338
11	1.2803	1.5565	1.5203		.2894
12	1.5023	1.6289	1.5939	.6935	.6371
13	1.4582	1.8267	1.576	.7202	.6859
14	1.576	1.7909	1.5223	.7537	.2572
15	1.5238	1.7551	1.5939	.7373	.5535
16	1.6289	1.7193	1.4299	.7373	.6935
17	1.5402	1.7013	1.4327	.7042	.6613
18	1.5023	1.5565	1.3575	.6401	.6935
19	.4633	.4401	.4988	.6316	.5601
20	.4923	.3887	.4534	.6062	.5201
21	.4633	.3395	.421	.5601	.4146
22	.3366	.2776	.3536	.4999	.2683
23	.3372	.2572	.313	.4572	
24	.4725	.3029	.2343	.6099	.5487
Max	1.6289	1.8267	1.5939	1.4842	1.4003
Min	.3366	.2572	.2286	.4527	.2572
Avg	.8490	.8709	.7869	.7424	.6750



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214411 / 33/11KV S/S SHIROLI

Feeder No / Name : 203 / AURANGPUR PARGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2033	.6097	.5468	.2587	.2241
2	.7186	.6706	.5468	.2587	.2241
3	.7186	.6859	.5693	.2987	.2241
4	.7655	.7956	.6154	.3361	.2801
5	.8583	.8288	.7045	.3734	.3584
6	.9614	.9282	.9389	.4481	.4338
7	1.3923	1.3094	1.2407	.4481	.5975
8	1.4723	1.5249	1.5089	.6161	.5093
9	1.5043	1.5083	1.4752	.4715	.4207
10	.2126	.3292	.3077	.3561	.5375
11	.3681	.4207	.3841	1.5074	1.5729
12	.394	.439	.3582	1.6876	1.8067
13	.3506	.4344	.3795	1.7328	1.6907
14	.333	.4344	.3224	1.6164	1.5524
15	.3189	.4525	.3366	1.6324	1.6518
16	.4163	.3982	.3582	1.6518	1.9136
17	.3544	.3982	.394	1.6324	1.5546
18	.4207	.4066	.439	1.5912	1.5074
19	.3734	.462	.499	.3921	.4527
20	.3881	.4251	.499	.3734	.4108
21	.3326	.3142	.3696	.3361	.3547
22	.2772	.2587	.3292	.2957	.2347
23	.2218	.2587	.2561	.2402	
24	.2033	.5944	.5468	.2587	.2241
Max	1.5043	1.5249	1.5089	1.7328	1.9136
Min	.2033	.2587	.2561	.2402	.2241
Avg	.5650	.6203	.5802	.7839	.8146

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214411 / 33/11KV S/S SHIROLI

Feeder No / Name : 205 / 11 KV Nimgaon Sava

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2896	.2591	.2881	1.1523	1.085
2	.286	.2591	.2881	1.1523	1.085
3	.3048	.2984	.2881	1.2003	1.085
4	.381	.4973	.3239	1.3435	1.1469
5	.5601	.6464	.4424	1.5402	1.3245
6	.8619	.8453	.8215	1.6933	1.6617
7	.9175	.9282	.9393	2.1051	2.1879
8	.6687	.7773	.7432	2.3102	2.536
9	.4923	.4877	.5556	1.773	2.4371
10	.204	.3814	.4572	.3477	.3121
11	2.4528	2.4326	2.5606	.3616	.2976
12	2.8464	2.5143	2.5777	.3772	.3525
13	2.7965	2.8664	2.7357	.3715	.2976
14	2.7831	2.8826	2.6558	.3544	
15	2.7831	2.8502	2.6246	.3658	
16	2.8306	2.834	2.609	.3902	.3839
17	2.5777	2.7526	2.5152	.3835	.4068
18	2.4086	2.5301	2.234	.4214	.5144
19	.578	.5668	.5992	.6642	.6081
20	.5624	.6081	.5851	.6009	.663
21	.4687	.5693	.5376	.5468	.5506
22	.4062	.4218	.3437	.4012	.4049
23	.3125	.3479	.3241	.3048	
24	.3041	.2984	.2881	1.1523	1.085
Max	2.8464	2.8826	2.7357	2.3102	2.536
Min	.204	.2591	.2881	.3048	.2976
Avg	1.2115	1.2440	1.1807	.8881	.9726

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214411 / 33/11KV S/S SHIROLI

Feeder No / Name : 206 / 11kV Jadhavwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3315	.8259	.8907	.2915	.3439
2	.8848	.8745	.8907	.2915	.3439
3	.8848	.9069	.9012	.333	.362
4	.9503	1.0749	.9556	.5068	.4572
5	1.1919	1.2483	1.1145	.6653	.5601
6	1.4548	1.4217	1.491	.8865	.8676
7	1.8347	1.7833	1.8004	.8775	.8962
8	1.989	2.1293	2.1026	.7842	.7468
9	1.7368	2.3137	2.2131	.5973	.5258
10	.4064	.5304	.4062	.4858	.4239
11	.4641	.5493	.4557	1.9006	2.1216
12	.5201	.5434	.4287	2.1464	2.2542
13	.5087	.5552	.463	2.1956	2.1714
14	.3978	.5373	.4024	2.0729	2.1879
15	.4807	.4961	.4024	2.1052	2.0972
16	.5087	.5316	.3978	2.1792	2.1879
17	1.1192	.567	.431	1.9845	
18	.6556	.695	.5434	1.9448	1.8896
19	.8871	.8501	.8316	.8131	.7842
20	.9425	.8316	.7947	.7947	.8029
21	.5544	.7499	.6838	.7164	.5975
22	.4887	.5194	.5068	.5068	.3982
23	.3898	.4961	.202	.3681	
24	.3315	.8162	.8745	.2915	.3439
Max	1.989	2.3137	2.2131	2.1956	2.2542
Min	.3315	.4961	.202	.2915	.3439
Avg	.8297	.9103	.8410	1.0725	1.0620

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214411 / 33/11KV S/S SHIROLI

Feeder No / Name : 207 / SHIROLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1844	.208	.197	.7011	.7407
2	.1734	.208	.197	.7011	.7407
3	.1734	.2614	.1991	.7186	.7499
4	.2254	.3361	.2378	.7499	.7811
5	.2926	.3734	.2772	.8002	.8322
6	.4108	.4108	.3921	.8421	.8962
7	.5359	.4108	.4668	1.1043	1.1702
8	.499	.4938	.4938	1.5043	1.3443
9	.4706	.4755	.5121	1.5813	1.4685
10	.3641	.394	.4382	.2372	.2486
11	1.5123	1.6129	1.6964	.3511	.3224
12	1.7394	1.7869	1.6964	.3544	.3721
13	1.5154	2.0965	2.009	.3641	.394
14	1.7185	2.0005	1.8084	.3772	.394
15	1.8027	1.8884	1.7078	.3944	.5083
16	1.7711	1.8884	1.692	.4207	.5601
17	3.3208	1.8724	1.8818	.4334	.5258
18	1.5023	1.6804	1.4217	.4344	.5014
19	.3258	.3206	.362	.3761	
20	.3109	.3258	.3224	.3403	.394
21	.3658	.2865	.3224	.3155	.3224
22	.3721	.2303	.2629	.2601	.2835
23	.1928	.2149	.2254	.2427	
24	.218	.208	.197	.7011	.7407
Max	3.3208	2.0965	2.009	1.5813	1.4685
Min	.1734	.208	.197	.2372	.2486
Avg	.8332	.8327	.7924	.5961	.6496

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214411 / 33/11KV S/S SHIROLI

Feeder No / Name : 208 / SULTANPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0895	.0554	1.5708	.3048	.25
2	.0895	.0554	.0924	.3048	.25
3	.0905	.0739	.0924	.3353	.25
4	.1086	.0554	.112	.3749	.2881
5	.1267	.1294	.1509	.4321	.3401
6	.1829	.1509	.1886	.4915	.4372
7	.2427	.1867	.2241	.6081	.7116
8	.2402	.2195	.2218	.6882	.8002
9	.2195	.2378	.2218	.7773	.7621
10	.2561	.2012	.1991	.116	.1254
11	.8179	.9488	.9014	.1448	.1646
12	.8124	1.1069	1.0279	.197	.1829
13	.8642	1.1043	1.0437	.1949	.2033
14	1.0155	1.1203	.9998	.2454	.2865
15	1.0311	1.0722	1.012	.2629	.2743
16	.9998	1.0883	.9448	.3012	.2957
17	.9145	1.0911	.8642	.2686	.2507
18	.8749	.9122	.7926	.2195	.2218
19	.1433	.1509	.1307	.1478	.4344
20	.1494	.1494	.1307	.1307	.1509
21	.1307	.1294	.1307	.128	.132
22	.112	.1109	.0914	.1075	.132
23	.0554	.1109	.0724	.0886	
24	.1075	.0554	.0924	.3048	.2469
Max	1.0311	1.1203	1.5708	.7773	.8002
Min	.0554	.0554	.0724	.0886	.1254
Avg	.4031	.4382	.4712	.2989	.3126

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214417 / 33/11 KV S/S GMRT KHODAD

Feeder No / Name : 201 / SOUTH -RANJANI-

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	.056	.0747	.0754
2	.0754	.0754	.0754	.0747	.0754
3	.0754	.0754	.0747	.0747	.0754
4	.0754	.0754	.0754	.0747	.0754
5	.0754	.0754	.0747	.0747	.0754
6	.0747	.0754	.0754	.0747	.0754
7	.0754	.0754	.0747	.0747	.0754
8	.0747	.0754	.0754	.0747	.0754
9	.0747	.0754	.0747	.0747	.0754
10	.0747	.0754	.0747	.0747	.0747
11	.0754	.0754	.0747	.0747	.0754
12	.0747	.0754	.0747	.0747	.0754
13	.0747	.0754	.0747	.0747	.0754
14	.0747	.0754	.0747	.0747	.0754
15	.0747	.0754	.0747	.0747	.0747
16	.0747		.0747	.0747	.0747
17	.0754	.0754	.0747	.0754	.0754
18	.0747	.0747	.0747	.0754	.0754
19	.0754	.0754	.0747	.0754	.0754
20	.0754	.0566	.0747	.0754	.0747
21	.0754	.0747	.0747	.0754	.0754
22	.0747	.0754	.0747	.0754	.0754
23	.0754	.056	.0747	.0754	.0754
24	.0747	.0754	.0747	.0747	.0754
Max	.0754	.0754	.0754	.0754	.0754
Min	.0747	.056	.056	.0747	.0747
Avg	.0751	.0737	.0740	.0749	.0753

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214417 / 33/11 KV S/S GMRT KHODAD

Feeder No / Name : 202 / WEST -NARAYANGAON-

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0537	.0554	.056	.056	.056
2	.056	.0554	.056	.056	.056
3	.0566	.0554	.056	.056	.056
4	.0543	.0554	.056	.056	.056
5	.056	.0554	.0572	.056	.056
6	.0554	.0554	.0566	.056	.056
7	.0537	.0554	.056	.056	.056
8	.0554	.0554	.0566	.056	.056
9	.0554	.0554	.056	.056	.056
10	.0554	.056	.056	.056	.0554
11	.0554	.056	.056	.056	.0543
12	.0554	.056	.056	.056	.0566
13	.0554	.056	.056	.056	.0554
14	.0554	.056	.056	.056	.056
15	.0554	.056	.056	.056	.0566
16	.0554		.056	.056	.0537
17	.0554	.056	.056	.056	.0554
18	.0554	.0566	.056	.056	.0566
19	.0554	.056	.056	.056	.0554
20	.0554	.056	.056	.056	
21	.0554	.0566	.056	.056	.056
22	.0554	.056	.056	.056	.0566
23	.0554	.0566	.056	.056	.0537
24	.0554	.0554	.056	.056	.056
Max	.0566	.0566	.0572	.056	.0566
Min	.0537	.0554	.056	.056	.0537
Avg	.0553	.0558	.0561	.056	.0557

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214417 / 33/11 KV S/S GMRT KHODAD

Feeder No / Name : 203 / EAST -BORI-

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.056	.0566	.0566
2	.0554	.0566	.0566	.0566	.0566
3	.0537	.0566	.056	.0566	.0566
4	.0566	.0566	.0566	.0566	.0566
5	.0566	.056	.056	.0566	.0566
6	.0554	.0566	.0566	.0566	.0566
7	.056	.0566	.056	.0566	.0566
8	.0566	.0566	.056	.0566	.0566
9	.0566	.0566	.0566	.0566	.0566
10	.056	.0566	.0566	.0566	.0566
11	.0566	.0566	.0566	.0566	.056
12	.0566	.0566	.0566	.0566	.056
13	.0566	.0566	.0566	.0566	.0543
14	.0566	.0566	.0566	.0566	.0566
15	.056	.0566	.0566	.0566	.0554
16	.0566		.0566	.0566	.056
17	.0566	.0566	.0566	.0566	.0566
18	.0566	.056	.0566	.0566	.0554
19	.0566	.0566	.0566	.0566	.0566
20	.0566	.056	.0566	.0566	.0566
21	.0566	.0566	.0566	.0566	.056
22	.0566	.056	.0566	.0566	.0566
23	.0566	.0566	.0566	.0566	.0554
24	.056	.0566	.056	.0566	.0566
Max	.0566	.0566	.0566	.0566	.0566
Min	.0537	.056	.056	.0566	.0543
Avg	.0563	.0565	.0565	.0566	.0563



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214417 / 33/11 KV S/S GMRT KHODAD

Feeder No / Name : 205 / GMRT LOCAL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.1848	.1886	.1867
2	.1886	.1886	.1867	.1886	.1867
3	.1886	.1886	.1886	.1886	.1867
4	.1886	.1886	.1867	.1886	.1867
5	.1886	.1867	.1886	.1886	.1867
6	.1886	.1886	.1867	.1886	.1867
7	.1886	.1886	.1886	.1886	.1867
8	.1886	.1886	.1867	.1886	.1867
9	.1886	.1886	.1886	.1886	.1867
10	.1886	.1886	.1886	.1886	.1886
11	.1886	.1886	.1886	.1886	.1886
12	.1886	.1886	.1886	.1886	.1886
13	.1886	.1886	.1886	.1886	.1886
14	.1886	.1886	.1886	.1886	.1886
15	.1886	.1886	.1886	.1886	.1886
16	.1886		.1886	.1867	.1886
17		.1886	.1886	.1886	.1886
18	.1886	.1867	.1886	.1886	.1886
19	.1886	.1886	.1886	.1886	.1886
20	.1886	.1867	.1886	.1886	.1886
21	.1886	.1886	.1886	.1886	.1886
22	.1886	.1867	.1886	.1886	.1886
23	.1886	.1886	.1886	.1886	
24	.1886	.1886	.1867	.1886	.1886
Max	.1886	.1886	.1886	.1886	.1886
Min	.1886	.1867	.1848	.1867	.1867
Avg	.1886	.1883	.1880	.1885	.1879

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214434 / 33 KV KANDALI

Feeder No / Name : 201 / MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1524	.1715	.1715	.1715
2	.1334	.1334		.1524	.1524
3	.1334	.1334	.1524	.1524	.1524
4	.1524	.1524	.1524	.1524	.1715
5	.1715	.1905	.1524	.1524	.2286
6	.1905	.1715	.2096	.2477	.2858
7	.2096	.2858	.2096	.2286	.2477
8	.2286	.2858	.2667	.3239	.2858
9	.2667	.3048	.3048	.3239	.4001
10	.5335	.381	.4572	.5716	.5716
11	.5716	.6287	.6668	.6097	.6859
12	.5716	.5144	.5906	.6097	.7811
13	.381	.4763	.6097	.4001	.5335
14	.5716	.5144	.6287	.5144	.5144
15	.5716	.5525	.6097	.6097	.5906
16	.6287	.4954	.5335	.5144	.5906
17	.724	.4001	.5335	.381	.4763
18	.5335	.2858	.3429	.4382	.3429
19	.381	.362	.3429	.2858	.3239
20	.2477	.2286	.2286	.2667	.2286
21	.2286	.2286	.1905	.2477	.2286
22	.1905	.2096	.1524	.2286	.1905
23	.1524	.1524	.1524	.2096	.2286
24	.1334	.1524	.1715	.1905	.1905
Max	.724	.6287	.6668	.6097	.7811
Min	.1143	.1334	.1524	.1524	.1524
Avg	.3342	.3080	.3404	.3326	.3572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214434 / 33 KV KANDALI

Feeder No / Name : 202 / Nagadwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1581	.5937	.5335	.1629	.1402
2	.4904	.4687	.5937	.1629	.1341
3	.5792	.6325	.5937	.1829	.1457
4	.6722	.6642	.6401	.1829	.1943
5	.7611	.7202	.7202	.2218	.2454
6	.852	.9555	.9995	.3174	.3174
7	1.2803	1.4746	1.4899	.4294	.4294
8	1.6604	1.7695	1.7652	.4251	.3881
9	1.7924	1.8623	2.0405	.2926	.2926
10	.1852	.197	.2481	.2915	.2658
11	.1886	.181	.2195	1.692	1.5655
12	.1886	.1629	.2195		1.8623
13	.1658	.1612	.1886	2.0005	1.8821
14	.1509	.1612	.1949	2.0005	1.7711
15	.1509	.1772	.1928	1.9204	2.1616
16	.1696	.1949	.2103	1.8976	1.8185
17	.1189	.1791	.208	1.6446	2.0165
18	.218	.2743	.2774	1.2809	1.3272
19	.2715	.2743	.3292	.2534	.2715
20	.2328	.2534	.3395	.2353	.2303
21	.2328	.2328	.2715	.1991	.2328
22	.197	.2126	.2328	.1595	.1949
23	.1578	.1753	.2149	.1595	.1886
24	.1357	.5719	.5335	.181	.1612
Max	1.7924	1.8623	2.0405	2.0005	2.1616
Min	.1189	.1612	.1886	.1595	.1341
Avg	.4588	.5229	.5524	.7084	.7599

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214434 / 33 KV KANDALI

Feeder No / Name : 203 / kandali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1509	.132	.132	.1509
2	.1132	.1509	.1132	.132	.1698
3	.1132	.1698	.1132	.1132	.1698
4	.1132	.1886	.1509	.1132	.1698
5	.1509	.2263	.1886	.132	.1886
6	.1698	.2641	.2263	.2263	.2263
7	.1886	.2263	.2641	.2641	.2641
8	.2263	.1886	.2263	.2263	.2263
9	.1132	.2075	.1886	.1886	.1886
10	.132	.1509	.1509	.1698	.2075
11	.1132	.1509	.1509	.132	.2263
12	.0943	.132	.132	.132	.1886
13	.0189	.1132	.132	.132	.132
14	.0943	.0943	.132	.1132	.1132
15	.1132	.0943	.132	.1132	.1132
16	.1132	.1132	.132	.1132	.0943
17	.132	.132	.1698	.132	.0943
18	.1698	.1886	.1886	.1509	.1132
19	.2263	.3018	.3018	.2075	.1509
20	.2641	.2641	.2641	.2263	.1698
21	.2263	.2263	.2452	.2075	.1886
22	.2075	.1886	.1886	.1886	.1886
23	.1886	.1509	.1509	.1509	.1509
24	.1509	.1698	.132	.132	.132
Max	.2641	.3018	.3018	.2641	.2641
Min	.0189	.0943	.1132	.1132	.0943
Avg	.1478	.1768	.1753	.1595	.1674

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214434 / 33 KV KANDALI

Feeder No / Name : 204 / Vaishakhed

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0324	.0351	.0343	.3479	.2812
2	.0332	.0358	.0351	.3479	.285
3	.0373	.0362	.0351	.3681	.3045
4	.0343	.0362	.0366	.3681	.2926
5	.0351	.037	.0366	.3681	.2915
6	.0366	.0366	.0549	.3725	.2881
7	.0362	.037	.0358	.3932	.2896
8	.0347	.0362	.0343	.4586	.3593
9	.0324	.0362	.0343	.4744	.3858
10	.0263	.0343	.0566	.029	.5487
11	.4428	.6226	.6584	.0362	.0309
12	.5761	.6718	.6478	.0354	.0358
13	.5693	.6962	.0335	.0362	.0362
14	.5441	.6554	.0343	.0362	.0358
15	.4321	.6478	.5801	.0347	.0362
16	.5506	.6554	.5121	.0343	.0358
17	.4744	.639	.5376	.0332	.0351
18	.4115	.6009	.4365	.0335	.0309
19	.0358	.0537	.0332	.0324	.0354
20	.0351	.0339	.0339	.0351	.0351
21	.0343	.0335	.0335	.0373	.0339
22	.0343	.0335	.0332	.0366	.0332
23	.0332	.0328	.0332	.0339	.0328
24	.0309	.0343	.0343	.3637	.2743
Max	.5761	.6962	.6584	.4744	.5487
Min	.0263	.0328	.0332	.029	.0309
Avg	.1893	.2405	.1681	.1811	.1687

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214456 / 33 KV SAWARGAON

Feeder No / Name : 201 / Wadgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1132	.1629	.6661	.583
2	.1677	.1097	.1629	.6661	.583
3	.1677	.1132	.181	.6661	.5895
4		.1425	.2353	.6836	
5	.2347	.2378	.2896	.7186	.5895
6	.4191	.3005	.362	.8063	.8328
7	.463	.3768	.4344	1.0166	.9465
8	.3601	.3898	.3801	1.3003	1.0749
9	.3429	.4207	.3982	1.3904	1.2378
10	.3361	.2896	.3734	.2743	.2957
11	1.2039	1.3108	1.6118	.3921	.3734
12	1.3565	1.4746	1.6118	.415	.3961
13		1.4746	1.5947	.415	.3961
14	1.4083	1.6221	1.5775	.4338	.3961
15	1.3748	1.6712	1.5604	.415	.415
16	1.4754	1.6221	1.5947	.4527	.4527
17	1.4074	1.491	1.5261	.4338	.4904
18	1.3077	1.3599	1.3889	.5093	.4527
19	.333	.362	.2743	.4163	.4119
20	.2896	.3258	.2915	.3155	.394
21	.2134	.2534	.2984	.2915	.3366
22	.2006	.2534	.2155	.2743	.2572
23	.1353	.2172	.176	.208	.2012
24	.1509	.1115	.181	.6415	.5895
Max	1.4754	1.6712	1.6118	1.3904	1.2378
Min	.1353	.1097	.1629	.208	.2012
Avg	.6136	.6685	.7034	.5751	.5346

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214456 / 33 KV SAWARGAON

Feeder No / Name : 202 / Malganga

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0876	.2401	.2458	.132	.112
2	.2279	.2058	.2622	.132	.112
3	.2629	.2401	.2949	.132	.112
4	.298	.2743	.3277	.1509	.1494
5	.298	.2743	.3605	.1886	.168
6	.333	.3403	.3932	.2263	.2241
7	.4382	.5028	.4096	.2829	.2452
8	.5731	.6068	.5735	.2641	.2263
9	.6516	.6874	.639	.1886	.2075
10	.1132	.181	.1698	.1677	.1823
11	.1307	.1991	.2075	.6401	.7537
12	.0191	.2353	.2075	.8381	.8162
13	.2075	.2172	.2263	.8223	.8002
14	.2075	.2172	.2075	.8162	.8002
15	.2263	.2353	.1698	.8962	.7682
16	.0229	.2353		.9393	.7362
17	.1886	.2172	.2263	.68	.7202
18	.0248	.2172	.2263	.7537	.6796
19	.1698	.181	.2218	.2075	.1698
20	.1509		.2033	.2075	.2075
21	.1494	.1629	.1698		.1886
22	.1494	.1448	.1886		.1698
23	.112	.1267	.1494		.1294
24	.0905	.1029	.2294	.1307	
Max	.6516	.6874	.639	.9393	.8162
Min	.0191	.1029	.1494	.1307	.112
Avg	.2139	.2628	.2743	.4189	.3773

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214456 / 33 KV SAWARGAON

Feeder No / Name : 203 / Sawargaon-Khilarwadi  
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.128	.2303	.2458	.1214	.081
2	.2172	.2454	.2949	.1214	.0819
3	.2534	.2774	.3441	.1214	.0848
4	.3077	.2774	.426	.1387	.112
5	.3439	.3467	.5079	.156	.112
6	.4525	.4161	.6062	.2263	.112
7	.6697	.5596	.7045	.2427	.2075
8	.9328	.779	.8029	.2427	.2263
9	.9877	.8848	.8356	.1886	.1494
10	.0857	.1267	.132	.2075	.1698
11	.132	.181	.2452	.852	.7045
12	.1698	.2172	.2829	.8802	.9762
13	.0191	.2172	.2641	.8322	1.0242
14	.1886	.2172	.2452	.8002	1.0402
15	.0229	.2353	.2263	.8642	1.0242
16	.2263	.2534	.2263	.8322	.9922
17	.0229	.2172		.759	.9282
18	.0248	.2172	.1698	.7045	.7701
19	.2263	.2353	.2452	.1715	.1886
20	.0248	.2172	.2452	.1886	.2075
21	.2075	.1991	.2263	.1886	.1886
22	.2075	.1629	.1886	.1494	.1509
23	.1886	.1448	.1433	.12	.1254
24	.4287	.181	.213	.1372	.0995
Max	.9877	.8848	.8356	.8802	1.0402
Min	.0191	.1267	.132	.12	.081
Avg	.2695	.2933	.3401	.3853	.4065



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214459 / 33/11KV S/S UMBRAJ

Feeder No / Name : 201 / UMBRAJ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.1581	.1718	.1448	.1509
2	.2458	.1581	.1718	.1448	.1494
3	.2458	.1581	.1718	.1448	.1494
4	.2458	.1581	.1718	.1463	.1448
5	.2486	.1581	.1718	.1848	.1629
6	.2881	.4917	.4917	.2587	.2715
7	.3479	.4917	.4917	.3206	.3077
8	.4752	.5533	.6539	.3547	.3174
9	.5967	.7293	.7293	.3361	.2772
10	.156	.181	.1991	.3109	.2534
11	.1829	.3361	.3142	.6882	.7287
12	.2926	.3734	.3174	.8288	.7682
13	.2957	.3921	.2587	.7842	.7522
14	.3142	.3511	.2587	.8097	.7202
15	.4108	.3734	.2534	.7537	.7449
16	.3696	.3772	.2896	.663	.8097
17	.4435	.3772	.3109	.7522	.7655
18	.3326	.3772	.3045	.6316	.7116
19	.3292	.3511	.3326		.2534
20	.2957	.2926	.3109	.2715	.2534
21	.2957	.3142	.2561	.2801	.2172
22	.197	.3142	.1829	.1867	.1646
23	.1417	.1595	.1612	.1509	.1629
24	.1307	.1581	.1718	.1448	.1448
Max	.5967	.7293	.7293	.8288	.8097
Min	.1307	.1581	.1612	.1448	.1448
Avg	.2922	.3244	.2978	.4040	.3909

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214459 / 33/11KV S/S UMBRAJ

Feeder No / Name : 202 / MAHALAXMI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2587	.5418	.6321	.3224	.2987
2	.5765	.5418	.6321	.3224	.2926
3	.5281	.5418	.6321	.3224	.2896
4	.547	.5418	.6321	.3258	.2987
5	.5344	.5418	.6321	.3658	.3361
6	.7682	.9892	.9892	.4938	.6161
7	.8124	.9892	.9892	.7655	.6767
8	.9555	1.1934	1.1934	.7655	.5973
9	1.1797	1.3599	1.3426	.6161	.6219
10	.4191	.3898	.3898	.4854	.5316
11	.5258	.4887	.543	1.1984	1.491
12	.5493	.543	.6268	1.56	1.5043
13	.0191	.5068	.6335	1.4419	1.6194
14	.6201	.5194	.6878	1.4922	1.6032
15	.6626	.5611	.6024	1.4723	1.5524
16	.7522	.6154	.4961	1.3927	1.4883
17	.8059	.6516	.567	1.3923	1.439
18	.5959	.6516	.6201	1.2793	1.2963
19	.7602	.6767	.6767		.5853
20	.6697	.6401	.6584	.5601	.6219
21	.6697	.543	.543	.5975	.567
22	.5194	.543	.394	.3881	.4207
23	.4207	.3856	.3155	.2801	
24	.2614	.5418	.6321	.3224	.2987
Max	1.1797	1.3599	1.3426	1.56	1.6194
Min	.0191	.3856	.3155	.2801	.2896
Avg	.6005	.6458	.6692	.7897	.8281

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214459 / 33/11KV S/S UMBRAJ

Feeder No / Name : 203 / BELA PRADESHIK

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1311	.0995	.0983	.112	.1134
2	.125	.0995	.0983	.112	.112
3	.1094	.0995	.0983	.112	.1107
4	.1147	.0995	.0983	.112	.1147
5	.112	.0995	.0983	.1147	.1107
6	.1094	.104	.104	.1174	.1067
7	.116	.104	.104	.1214	.1094
8	.4752	.12	.218	.2347	.1638
9	.112	.2374	.3601	.3277	.2241
10	.1174	.3441	.3361	.3481	.3125
11	.2214	.3391	.3391	.3277	.3561
12	.2056	.3391	.3353	.3315	.3315
13	.3401	.3391	.3353	.3401	.285
14	.3277	.3315	.3521	.3315	.2229
15	.3315	.2035	.3315	.213	.2035
16	.2012	.2058	.3315	.0025	.3582
17	.0015	.0034	.0053	.0051	.0025
18	.0048	.0051	.004	.0048	.0029
19	.004	.0067	.0057		.004
20	.0044	.0059	.0057		.0051
21	.0044	.0084	.0055		.0053
22	.008	.0084	.0051		.0042
23	.1265	.112	.1265	.0937	.0514
24	.1311	.0663	.0983	.112	.112
Max	.4752	.3441	.3601	.3481	.3582
Min	.0015	.0034	.004	.0025	.0025
Avg	.1431	.1409	.1623	.1737	.1426

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214459 / 33/11KV S/S UMBRAJ

Feeder No / Name : 204 / Sondewadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.1478	.1663	.2372	.1966
2	.1494	.1478	.1663	.2372	.1989
3	.1509	.1478	.1663	.2372	.1943
4	.1494	.1478	.1663	.2372	.1966
5	.1509	.1478	.1663	.2753	.2321
6	.2801	.3206	.3206	.3481	.0152
7	.3142	.3206	.3206	.4917	.431
8	.2743	.3018	.3772	.5365	.4696
9	.2241	.1848	.2957	.5243	.5121
10	.2126	.1791	.2353	.1494	.1478
11	.4374	.5218	.6081	.1494	.1991
12	.578	.6241	.6241	.2075	.1991
13	.578	.6401	.6325	.1886	.1991
14	.6325	.6401	.6325	.1867	.2172
15	.6958	.7116	.6249	.168	.1991
16	.6405	.7116	.6249	.2012	.1991
17	.5556	.7202	.6093	.2172	.1991
18	.4938	.7125	.5556	.2561	.2561
19	.3292	.3511	.3511	.3174	.3547
20	.2957	.3292	.3511	.3174	.3174
21	.2957	.2987	.3109	.3174	.2801
22	.2033	.2987	.2561	.2452	.2054
23	.1478	.1646	.2172	.2241	.1478
24	.1494	.1478	.1663	.2372	.1943
Max	.6958	.7202	.6325	.5365	.5121
Min	.1463	.1478	.1663	.1494	.0152
Avg	.3369	.3716	.3727	.2711	.2401

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214459 / 33/11KV S/S UMBRAJ

Feeder No / Name : 205 / UMBRESHWAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.9149	.8775	.2926	.25
2	.9709	.9149	.8775	.2926	.2743
3	.9896	.9149	.8775	.2926	.2703
4	1.0082	.9149	.8775	.2926	.2766
5	.9877	.9149	.8775	.3144	.2703
6	1.1203	1.1949	1.1949	.3467	.2801
7	1.2308	1.1949	1.1949	.3982	.3031
8	1.363	1.4045	1.3676	.423	.3601
9	1.5181	1.6095	1.6095	.4334	.3647
10	.2212	.1358	.1063	.4207	.415
11	.3536	.3189	.421	1.4377	1.5546
12	.4087	.4024	.421	1.5684	1.5912
13	.415	.4212	.4212	1.5729	1.6108
14	.4024	.4212	.4212	1.587	1.647
15	.3835	.3963	.4405	1.6617	1.7551
16	.4334	.3963	.4668	1.5023	1.7372
17	.447	.4087	.4801	1.448	1.5581
18	.4468	.4087	.487	1.4266	1.5023
19	.3951	.4146	.4016	.1715	.2829
20	.4081	.3719	.4087	.3801	.2829
21	.4081	.3426	.3835	.3334	.2578
22	.3521	.3426	.3536	.3174	.2317
23	.3292	.3039	.317	.2622	.2067
24	.2507	.9149	.8775	.2926	.25
Max	1.5181	1.6095	1.6095	1.6617	1.7551
Min	.2212	.1358	.1063	.1715	.2067
Avg	.6294	.6658	.6734	.7279	.7305

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214467 / 33 KV PARGAON MANGRUL

Feeder No / Name : 201 / Pimpri Kawal

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2507	.7209	.9722	.3077	.2587
2	.9755	.8192	1.0279	.2926	.2957
3	1.0212	1.1142	1.0437	.2957	.2987
4	1.1717	1.1142	1.1174	.3696	.3361
5	1.2492	1.4091	1.1498	.4108	.3734
6	1.3441	1.5729	1.2125	.4668	.4481
7	1.4255	1.7718	1.5074	.5601	.5281
8	1.9498	2.1312	1.7328	.6283	.5658
9	1.8842	1.8351	1.7814	.5304	.5544
10	.3506	.3366	.3401		.5121
11	.3277	.3982	.4252	1.8884	2.5953
12	.3441		.3856	1.9204	2.4629
13	.3113	.1254	.3467	1.9204	2.2611
14	.2949	.1254	.3506	1.9204	2.3348
15	.3113	.124	.3155	1.9433	2.2857
16	.3441	.1227	.2658	1.9109	2.0972
17	.3856	.298	.3544	1.7814	2.1948
18	.3277	.4119	.443	1.6004	2.0153
19	.3932	.4477	.5249	.3658	
20	.4915	.5194	.5068	.4024	
21	.5898	.4344	.4525	.4024	
22	.4915	.4298	.3982	.3658	
23	.426	.3544	.362	.3292	
24	.2507	.639	.9259	.3077	.2561
Max	1.9498	2.1312	1.7814	1.9433	2.5953
Min	.2507	.1227	.2658	.2926	.2561
Avg	.7047	.7502	.7476	.9096	1.1934

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214467 / 33 KV PARGAON MANGRUL

Feeder No / Name : 202 / MANGRUL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1387	.1311	.1227	.4374	.4062
2	.1578	.1433	.124	.4428	.4062
3	.1753	.1638	.1448	.4586	.4374
4	.2126	.1966	.1463	.4858	.4801
5	.2303	.2294	.1867	.5506	.5441
6	.2715	.2294	.2075	.6062	.5761
7	.3584	.3113	.2075	.7045	.6706
8	.2427	.2507	.2427	.8097	.7209
9	.2353	.1802	.2587	.852	.7865
10	.2103	.1638	.4031	.1772	.208
11		.8951	.8482	.1829	
12		.9831	.8802	.1829	.1966
13		1.004	.933	.1829	.1772
14		1.0202	.9488	.1829	.1696
15		1.085	.9488	.1848	.1949
16		1.085	.9646	.1848	.1966
17		1.0202	.9488	.1848	.2378
18		.9282	.9172	.1848	.2254
19		.2294	.1829	.1848	
20		.2012	.1646	.1848	
21		.1646	.1417	.1663	
22		.1433	.1227	.168	
23		.1227	.124	.1494	
24	.1357	.1311	.1227	.3963	.3658
Max	.3584	1.085	.9646	.852	.7865
Min	.1357	.1227	.1227	.1494	.1696
Avg	.2153	.4589	.4288	.3436	.3889

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214467 / 33 KV PARGAON MANGRUL

Feeder No / Name : 203 / Pargaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1433	.1638	.1463	.4586	.4687
2	.1448	.1966	.1463	.4902	.4687
3	.1646	.2294	.1646	.4858	.5121
4	.2012	.2949	.1698	.4915	.5121
5	.2378	.3113	.1698	.5243	.5898
6	.2378	.3277	.1886	.5801	.5898
7	.2614	.3932	.2427	.663	.663
8	.2743	.3277	.3326	.7682	.7865
9	.2172	.2949	.2534	.8002	.7773
10	.2454	.1966	.2915	.2229	.1341
11	1.1305	1.0364	.8436	.2103	.2949
12	1.1305	1.0402	.8749	.2103	.1638
13	1.1142	1.0242	.8951	.2149	.1966
14	1.0322	.9804	.8642	.2149	.2294
15	1.0322	.9646	.8535	.2149	.2622
16	.9831	.9282	.8488	.2149	.1966
17	.9831	.9172	.8488	.2149	.192
18	.9995	.8697	.8179	.2126	.2458
19	.1966	.1991	.1991	.2218	
20	.181	.2033	.181	.2218	
21	.1638	.1867	.1629	.1848	
22	.1595	.1646	.1448	.1463	
23	.1646	.1463	.1448	.1463	
24	.1433	.1475	.1463	.4374	.4374
Max	1.1305	1.0402	.8951	.8002	.7865
Min	.1433	.1463	.1448	.1463	.1341
Avg	.4809	.4810	.4138	.3563	.4064



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214467 / 33 KV PARGAON MANGRUL

Feeder No / Name : 205 / 11 KV RAMWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1134	.1475	.1214	.3913	.2743
2	.1311	.1638	.1214	.4167	.3048
3	.1311	.1802	.1254	.4475	.3048
4	.1989	.1966	.1417	.4586	.3658
5	.2321	.2294	.1448	.4902	.3749
6	.2743	.3475	.1494	.5121	.4687
7	.2743	.3277	.2054	.5441	.5407
8	.2427	.2949	.2241	.6093	.6249
9	.2195	.2534	.1663	.6642	.6249
10	.1791	.1638		.0995	.104
11		.5376	.5944	.1753	.1475
12		.6718	.6249	.1753	.1791
13		.703	.6706	.2454	.1791
14		.6636	.6401	.2658	.1772
15		.703	.602	.2865	.1949
16		.7186	.5796	.2865	.2126
17		.6481	.5944	.2865	.2172
18		.5944	.6241	.2865	.2254
19		.1448	.2172	.2481	
20		.1629	.2172	.2481	
21		.1448	.1791	.2126	
22		.1174	.1492	.1791	
23		.1174	.1492	.1791	
24	.112	.1311	.1214	.3567	.2675
Max	.2743	.7186	.6706	.6642	.6249
Min	.112	.1174	.1214	.0995	.104
Avg	.1917	.3485	.3201	.3360	.3046

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214467 / 33 KV PARGAON MANGRUL

Feeder No / Name : 206 / 11 KV ZAPWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.1448	.1494	.4475	.3353
2	.168	.1147	.1646	.4744	.3353
3	.168	.1311	.1646	.4744	.3658
4	.1848	.1638	.2218	.5182	.3749
5	.1848	.1966	.2743	.5668	.4374
6	.2561	.2294		.639	.6226
7	.2926	.3475	.2926	.7377	.8478
8	.3142	.2622	.2587	.9069	.8322
9	.2957	.2785	.2561	.9282	.8322
10	.3018	.2835	.2075	.1886	.1526
11		1.0883	1.0753	.1886	.1543
12		1.2308	1.1069	.1886	.1543
13		1.2955	1.1385	.1886	.1372
14		1.2803	1.0936	.1886	.156
15		1.247	1.0623	.1791	.1753
16		1.2003	1.0031	.1791	.2534
17		1.1523	.9602	.1791	.3395
18		1.0595	.9145	.1562	.3395
19		.1629	.2591	.1791	
20		.2075	.2629	.1791	
21		.2075	.2353	.1612	
22		.1698	.2054	.1433	
23		.1509	.1867	.1448	
24	.1294	.1311	.1494	.4167	.301
Max	.3142	1.2955	1.1385	.9282	.8478
Min	.1294	.1147	.1494	.1433	.1372
Avg	.2221	.5307	.5062	.3564	.3761

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214480 / Kandali Village

Feeder No / Name : 201 / Vadgaon (Kandali)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.3109	.3174		.8029
2	.2378	.2896	.3174	.9555	.7865
3	.2957	.3258	.3174	.9555	.7865
4	.3511	.3582	.3395	.9878	.8192
5	.3881	.4119	.3772	1.0562	.8619
6	.5175	.4477	.4338	1.0898	.9012
7	.5175	.5228	.5093	1.1401	1.0111
8	.6099	.5228	.5596	1.1904	1.1437
9	.6283	.6099	.6952	1.2955	1.2289
10	.7701	.6653	.7059	.6024	.4908
11	1.4251	1.5415	1.6078	.7164	1.7741
12	1.6712	1.6575	1.6876	.6984	
13	1.6549	1.8442	1.704	.6984	.6468
14	1.6549	1.8233	1.7404	.6697	.6401
15	1.7072	1.7901	1.7404	.6878	.6401
16	1.7204	1.7901	1.757	.7059	.6584
17	1.5061	1.6907	1.6004	.6697	.5068
18	1.3765	1.5565	1.4403	.6401	.5068
19	.4191	.5729	.4887	.5853	.4298
20	.4755	.499	.4435	.499	.4961
21	.4207	.462	.3696	.4435	.4835
22	.3841	.4066	.3142	.3658	.4477
23	.3658	.3696	.2587	.3326	.3814
24	.2743	.3292	.3326	.8697	.7935
Max	1.7204	1.8442	1.757	1.2955	1.7741
Min	.2378	.2896	.2587	.3326	.3814
Avg	.8178	.8666	.8357	.7763	.7495

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214480 / Kandali Village

Feeder No / Name : 202 / Abhangwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2347	.8886	.8048	.2515	.2683
2	.7712	.9054	.8048	.2515	.2683
3	.8383	.9054	.8383	.2515	.285
4	.9054	.8886	.8551	.2683	.3018
5	.9724	.9389	.8886	.285	.3353
6	1.0059	1.073	.9221	.3185	.3521
7	1.073	1.2071	1.0395	.3521	.4191
8	1.1568		1.1191	.3856	.4862
9	1.2574	1.358	1.2887	.4024	.4359
10	.3688	.4748	.3688	.4024	.503
11	.4527	.4917	.3688	1.4083	.6036
12	.503	.5256	.4694	1.4251	1.7101
13	.503	.4748	.4862	1.6263	1.6933
14	.4862	.4917	.4694	1.6095	1.7269
15	.4862	.5256	.4862	1.6263	1.7604
16	.4862	.4409	.503	1.643	1.7436
17	.4862	.4239	.4862	1.643	1.643
18	.4694	.4239	.4527	1.5424	1.5927
19	.503	.4239	.4359	.4024	
20	.5365	.3561	.3856	.3688	.4024
21	.4694	.3391	.3521	.3521	.3688
22	.4024	.3018	.3018	.3018	.3521
23	.3856	.2683	.285	.285	.3018
24	.2347	.8886	.8383	.2683	.2683
Max	1.2574	1.358	1.2887	1.643	1.7604
Min	.2347	.2683	.285	.2515	.2683
Avg	.6245	.6529	.6354	.7363	.7749

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214480 / Kandali Village

Feeder No / Name : 203 / GFSS Vadgaon Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0181	.0362	.0181	.0181	.0181
Max	.0181	.0362	.0181	.0181	.0181
Min	.0181	.0362	.0181	.0181	.0181
Avg	.0181	.0362	.0181	.0181	.0181

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214481 / 33/11 KV Yedgaon

Feeder No / Name : 201 / Shri Ganesh

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1006	.4191	.3353	.1509	.1341
2	.3688	.4191	.3353	.1509	.1341
3	.3856	.4191	.3688	.1509	.1341
4	.4191	.4359	.4024	.1677	.1341
5	.4191	.4527	.4191	.1677	.1509
6	.4359	.4694	.4359	.1844	.1677
7	.4527	.503	.4359	.2012	.1677
8	.5365	.5197	.4694	.2012	.1677
9	.5365	.5365		.2012	.1677
10	.1174	.1677	.1341	.2012	.1509
11	.1509	.1677	.1509	.6036	.5868
12	.1509	.1677	.1677	.6539	.6036
13	.1509	.1509	.1677	.6539	.6203
14	.1677	.1509	.1677	.6706	.6203
15	.1677	.1509	.1677	.6706	.6036
16	.1677	.1341	.1677	.6706	.5868
17		.1677	.1509	.6706	.57
18	.1844	.1844	.1509	.6706	.57
19	.2012	.1844	.1677	.1844	.1509
20	.2012	.1677	.2012	.1677	
21	.1844	.1844	.1677	.1509	
22	.1844	.1509	.1677	.1509	
23	.1677	.1341	.1509	.1341	
24	.1174	.4191	.3185	.1509	.1341
Max	.5365	.5365	.4694	.6706	.6203
Min	.1006	.1341	.1341	.1341	.1341
Avg	.2595	.2857	.2522	.3325	.3278

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214481 / 33/11 KV Yedgaon

Feeder No / Name : 202 / Jay Malhar

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2155	.1989	.2267	.9116	.7956
2	.2155	.1989	.2267	.9614	.7956
3	.2486	.1989	.2591	1.1462	.7956
4	.2652	.1989	.2915	1.2536	.8951
5	.2984	.2155	.3077	1.3073	.9779
6	.3315	.2321	.3239	1.3432	1.0774
7	.3647	.2486	.3239	1.3611	1.2266
8	.3481	.3149	.3887	1.3226	1.326
9	.3481	.3812		1.3904	1.3757
10	.39	.3239	.3481	.2984	.2652
11	1.4586	1.5223	1.7736	.2984	.2915
12	1.5249	1.5384	1.757	.3149	.2591
13	1.5581	1.5384	1.7404	.3149	.2429
14	1.5912	1.5546	1.6907	.2984	.2267
15	1.5912	1.5546	1.6575	.2984	.2591
16	1.5581	1.5708	1.5083	.2984	.2915
17	1.5415	1.5223	1.2431	.285	.3077
18	1.5083	1.4737	1.094	.2818	.3077
19	.2652	.2915	.1989	.2652	.2267
20	.2652	.2915	.1989	.2486	
21	.2486	.2753	.2155	.2321	
22	.2321	.2591	.2155	.2321	
23	.2321	.2591	.2155	.218	
24	.2321	.1989	.2267	.8785	.7956
Max	1.5912	1.5708	1.7736	1.3904	1.3757
Min	.2155	.1989	.1989	.218	.2267
Avg	.7014	.6818	.7144	.6567	.6370

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214481 / 33/11 KV Yedgaon

Feeder No / Name : 203 / Yedeshwar

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1526	.1526	.1715	.2713	.2204
2	.1526	.1526	.1715	.3052	.2204
3	.2543	.1526	.1886	.3391	.2204
4	.2543	.1865	.2229	.3391	.2543
5	.3222	.2374	.2572	.373	.3052
6	.3561	.3052	.2743	.4239	.373
7	.373		.3086	.4748	.4409
8	.3222	.373	.3429	.5194	.5087
9	.3052	.407		.6274	.5256
10	.2713	.3601	.3561	.3052	.1696
11	.4917	.6859	.6443	.2713	.2058
12	.5426	.6516	.6443	.2204	.2229
13	.6104	.6687	.6443	.2204	.2572
14	.6613	.6516	.6443	.2204	.2743
15	.6783	.6344	.6443	.2374	.2743
16	.6783	.6516	.5935	.2374	.2572
17	.6443	.5658	.5426	.2374	.2572
18	.6274	.5316	.5256	.2374	.2572
19	.2374	.1886	.2374	.2374	.2401
20	.2374	.1886	.2543	.2204	
21	.2204	.1886	.2374	.2035	
22	.2035	.1715	.1696	.1696	
23	.1696	.1543	.1696	.1526	
24	.1696	.1526	.1543	.2713	.2204
Max	.6783	.6859	.6443	.6274	.5256
Min	.1526	.1526	.1543	.1526	.1696
Avg	.3723	.3658	.3652	.2965	.2853



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214481 / 33/11 KV Yedgaon

Feeder No / Name : 204 / KANIFNATH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2686	.2686	.2686	.4656	.394
2	.2507	.2686	.2915	.5014	.394
3	.3224	.2686	.3403	.5731	.394
4	.394	.3045	.3761	.6805	.4477
5	.4477	.3582	.4119	.788	.5552
6	.5014	.4298	.4119	.8954	.6805
7	.5373	.5014	.4298	.9671	.8596
8	.4835	.5014	.5014	1.0029	1.0208
9	.4298	.4298		1.2178	1.0745
10	.4835	.3224	.394	.2865	.2865
11	1.0387	1.1462	1.0924	.3224	.3224
12	1.1462	1.1999	1.1641	.3761	.3582
13	1.2715	1.2178	1.2178	.3761	.394
14	1.2894	1.2178	1.2536	.3561	.4298
15	1.2894	1.2357	1.2715	.3582	.4119
16	1.2894	1.2357	1.1999	.3582	.394
17	1.2715	1.1462	1.1104	.394	.3761
18	1.2536	1.1104	1.0029	.394	.3761
19	.4298	.4298	.4477	.3403	.4298
20	.4298	.394	.4298	.3582	
21	.394	.3761	.394	.3224	
22	.3582	.3403	.3052	.2686	
23	.3224	.3224	.2686	.2149	
24	.2686	.2686	.2686	.4477	.394
Max	1.2894	1.2357	1.2715	1.2178	1.0745
Min	.2507	.2686	.2686	.2149	.2865
Avg	.6738	.6373	.6457	.5111	.4997

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214481 / 33/11 KV Yedgaon

Feeder No / Name : 205 / BHOLENATH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0179	.0179	.0179	.1254	.1075
2	.0179	.0179	.0179	.1254	.1075
3	.0179	.0179	.0179	.1433	.1075
4	.0179	.0179	.0179	.1478	.1075
5	.0179	.0179	.0179	.1433	.1254
6	.0179	.0179	.0179	.1612	.1433
7	.0179	.0179	.0179	.1612	.1433
8	.0179	.0179	.0179	.1612	.1433
9	.0179	.0179		.2149	.1791
10	.0179	.0179	.0179	.0358	.0179
11	.197	.2686	.1791	.0358	.0179
12	.2149	.2865	.1791	.0358	.0179
13	.2507		.197	.0358	.0179
14	.2507	.2865	.197	.0358	.0179
15	.2686	.3045	.197	.0358	.0179
16	.2686	.3045	.197	.0179	.0179
17	.2686	.2865	.1791	.0179	.0179
18	.2507	.2865	.1791	.0179	.0179
19	.0358	.0179	.0179	.0179	.0179
20	.0358	.0179	.0179	.0179	
21	.0358	.0179	.0179	.0179	
22	.0179	.0179	.0179	.0179	
23	.0179	.0179	.1254	.0179	
24	.0179	.0179	.0179	.1254	.1075
Max	.2686	.3045	.197	.2149	.1791
Min	.0179	.0179	.0179	.0179	.0179
Avg	.0962	.1004	.0818	.0778	.0725

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214481 / 33/11 KV Yedgaon

Feeder No / Name : 206 / SHRI DATTA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2883	.6952	.763	.407	.3222
2	.6783	.6952	.763	.407	.3052
3	.7122	.6952	.7969	.4239	.3052
4	.78	.7461	.8478	.4748	.3052
5	.8478	.78	.8987	.4748	.3391
6	.9326	.8817	.9496	.4748	.407
7		1.0004	1.0174	.5087	.4748
8	1.0343	1.1191	1.2548	.5256	.5596
9	1.2887	1.2548		.5596	.5935
10	.3561	.373	.4239	.5256	.5426
11	.4917	.5426	.5765	1.2548	1.3226
12	.5087	.5087	.5765	1.3904	1.4243
13	.5087	.5256	.5426	1.3904	1.4582
14	.5087	.5426	.5426	1.3565	1.5261
15	.5087	.5426	.5426	1.3056	1.4752
16	.5256	.5256	.5426	1.2717	1.4243
17	.5256	.5426	.5256	1.1869	1.3565
18	.5256	.5596	.5256	1.1022	1.3056
19	.6443	.5426	.5256	.4917	.4748
20	.6104	.5087	.5256	.4748	
21	.5426	.4917	.5087	.4409	
22	.4748	.4578	.4409	.407	
23	.407	.4409	.373	.3561	
24	.2883	.6952	.7291	.373	.3222
Max	1.2887	1.2548	1.2548	1.3904	1.5261
Min	.2883	.373	.373	.3561	.3052
Avg	.6082	.6528	.6605	.7327	.8122

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214515 / 33/11 KV Khodad

Feeder No / Name : 201 / 11 KV Amarwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0655	.3239	.3521	.0819	.0655
2	.3563	.2949	.3521	.081	.0655
3	.4049	.2785	.4001	.0655	.0655
4	.4534	.3605	.4801	.0819	.0655
5	.5182	.426	.6401	.1147	.0983
6	.6316	.5243	.6401	.1638	.0983
7	.6316	.639	.7202	.1966	.1966
8	.8583	.9069	.7682	.1619	.1966
9	1.0526	1.1305	.9282	.213	.1475
10	.1311	.1638	.1475	.1475	.1638
11	.1802	.213	.1638	.9393	1.0526
12	.1802	.1966	.1966	.9555	1.1203
13	.1475	.1802	.2267	1.1012	1.1203
14	.1802	.1802	.1943	1.085	1.1523
15	.2753	.1966	.1802	1.1174	1.1203
16	.2458	.1966	.213	1.0688	1.0562
17	.2429	.1802	.2543	1.0526	1.0242
18	.2267	.1966	.1638	.9717	
19	.1781	.1966	.1475	.0983	
20	.1296	.1802	.1457	.1147	
21	.1296	.1638	.1475	.1147	
22	.0972	.1638	.1296	.0819	
23	.0972	.1311	.0819	.0819	
24	.0819	.3239	.4001	.0819	.0655
Max	1.0526	1.1305	.9282	1.1174	1.1523
Min	.0655	.1311	.0819	.0655	.0655
Avg	.3123	.3228	.3364	.4239	.4930

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214515 / 33/11 KV Khodad

Feeder No / Name : 202 / 11 KV JAGDAMBA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0983	.2949	.2881	.1311	.1311
2	.3077	.2458	.2881	.1296	.1147
3	.3239	.2458	.3201	.1296	.1638
4	.3563	.3932	.4001	.1781	.2622
5	.4049	.4588	.4801	.213	.2294
6	.4858	.4588	.5601	.2915	.2622
7	.5506	.5079	.6401	.3239	.3277
8	.7611	.664	.6722	.3441	.2622
9	.7611	.7865	.7042	.3077	.2785
10	.1802		.1475	.2458	.2949
11	.2622	.1802		.7611	.7773
12	.2622	.1638		.8583	.8192
13	.2622	.1802	.1943	.8097	.8192
14	.2294	.1638	.1638	.8097	.8962
15	.2294	.1638	.1943	.8097	.8642
16	.2105	.1966	.2458	.7773	.8642
17	.2105	.1966	.2458	.8259	.8002
18	.2294	.2294	.2429	.8097	
19	.2429	.2622	.2753	.2458	
20	.2429	.2622	.2429	.2294	
21	.2267	.2458	.2622	.1966	
22	.2105	.2294	.2294	.1638	
23	.1619	.1966	.1475	.1475	
24	.1638	.3113	.3201	.1475	.1311
Max	.7611	.7865	.7042	.8583	.8962
Min	.0983	.1638	.1475	.1296	.1147
Avg	.3073	.3060	.3302	.4119	.4610

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214515 / 33/11 KV Khodad

Feeder No / Name : 203 / 11 kv GADACHIWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1147	.5243	.4801	.1296	.1475
2	.5668	.4915	.5601	.1147	.1311
3	.6478	.4915	.5601	.1134	.1638
4	.7287	.6226	.7202	.1619	.1638
5	.7449	.6882	.8002	.2105	.1966
6	.8097	.8848	.9602	.2429	.2622
7	.8745	.9503	1.1203	.2753	.3113
8	1.2793	1.4091	1.1523	.2949	.2785
9	1.4251	1.6221	1.4403	.3077	.2622
10	.213	.213	.1802	.2753	.213
11	.1966	.2294		1.3927	1.3927
12	.3077	.2458		1.7328	1.4403
13	.2949	.2294		1.7328	1.5043
14	.2785	.2458		1.7166	1.5364
15	.2915	.2458		1.6518	1.5364
16	.3113	.2949	.2622	1.749	1.5684
17	.3239	.2949	.2915	1.587	1.5043
18	.2915	.2622	.2949	1.5384	
19	.2267	.2949	.2785	.2458	
20	.2429	.2622	.2458	.213	
21	.1943	.2458	.2294	.213	
22	.1638	.2294	.1966	.1802	
23	.1311	.1966	.1311	.1638	
24	.1475	.5571	.4801	.1311	.1475
Max	1.4251	1.6221	1.4403	1.749	1.5684
Min	.1147	.1966	.1311	.1134	.1311
Avg	.4503	.4888	.5465	.6823	.7089

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214515 / 33/11 KV Khodad

Feeder No / Name : 204 / 11 KV SWAMINAGAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1638	.4096	.4801	.2267	.1966
2	.5182	.3605	.5601	.1966	.1638
3	.5668	.3605	.6401	.1638	.1802
4	.5668	.4588	.6401	.2915	.1966
5	.6478	.6554	.9602	.3441	.2622
6	.8097	.9503	1.2003	.4049	.3605
7	.9231	1.0159	1.2803	.4424	.4424
8	1.2955	1.065	1.3603	.4696	.4752
9	1.3117	1.4255	1.4403	.3563	.4096
10		.2785	.2294	.3239	.2458
11	.2294	.2785	.3077	1.166	1.1174
12	.2294	.2622	.2753	1.4089	1.1843
13	.2622	.2458	.2753	1.4899	1.1523
14	.2622	.2294	.2915	1.4899	1.2803
15	.2753	.2622	.3239	1.5061	1.3763
16	.2915	.3277		1.4899	1.4403
17	.3441		.3277	1.4089	1.3763
18	.3239	.3277	.4424	1.3765	
19	.3725	.3277	.4096	.3441	
20	.3887	.3277	.3768	.3277	
21	.3768	.3277		.2949	
22	.3239	.2622	.3605	.2949	
23	.2591	.2458	.2458	.2458	
24	.1638	.426	.4801	.2429	.2294
Max	1.3117	1.4255	1.4403	1.5061	1.4403
Min	.1638	.2294	.2294	.1638	.1638
Avg	.4742	.4709	.5867	.6794	.6716

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214516 / 33/11 KV Pimpalwandi

Feeder No / Name : 201 / 11 KV NEHARWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2984	.3353	.3812	1.2266	1.0608
2	.2984	.3353	.4475	1.2266	1.0608
3	.3315	.3521	.5138	1.2597	1.094
4	.3812	.4527	.6299		1.1437
5	.4807	.5868	.7293	1.326	1.1934
6	.6299	.7042	.8288	1.442	1.2431
7	.779	.6874	.9116	1.6078	1.4752
8	.779	.7042	.7459	1.873	1.8564
9	.7293	.7209	.6962	2.0553	2.0388
10	.5967	.5304	.5138	.4807	.431
11	1.9448	2.0056	2.1548	.663	.5636
12	2.1136	2.1382	2.4366	.5967	.6464
13	2.2119	2.1879	2.3703	.5801	.7459
14	2.3304	2.1548	2.3537	.547	.6796
15	2.3472	2.304	2.3537	.6299	.779
16	2.3472	2.304	2.3371	.6133	.6299
17	2.3472	2.42	2.2874	.663	.6133
18	2.1293	2.304	2.1714	.663	.6299
19	.7127	.7127	.7127	.7293	.6796
20	.663	.7459	.7127	.779	.6962
21	.6464	.663	.6796	.6796	.663
22	.4641	.6133	.5138	.5801	.5138
23	.4144	.431	.4144	.431	.3481
24	.3315	.3353	.3149	1.1934	1.0608
Max	2.3472	2.42	2.4366	2.0553	2.0388
Min	.2984	.3353	.3149	.431	.3481
Avg	1.0962	1.1137	1.1755	.9498	.9103



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214516 / 33/11 KV Pimpalwandi

Feeder No / Name : 202 / 11 KV KALEKARWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6104	1.0562	1.0059	.6443	.5426
2	1.0343	1.0898	1.0562	.6613	.5935
3	1.1361	1.1401	1.1568	.6783	.6443
4	1.2209	1.2407	1.2574	.7122	.78
5	1.3565	1.3413	1.3916	.78	.9326
6	1.5939	1.4251	1.6095	1.17	1.1191
7	1.7974	1.5592	1.7269	1.2378	1.3565
8	2.1365	2.1125	2.0287	1.1869	1.1361
9	2.3739	2.2131	2.2131	.9665	.9326
10	.6274	.6874	.8886	.6613	.6274
11	.8048	.8718	.8215	2.0687	2.1125
12	.9556	.9724	.8383	2.2213	2.6155
13	.9556	.8886	.8551	2.34	2.6825
14	.9389	.9389	.8886	2.2891	2.5652
15	.8886	.9724	.8139	2.3061	2.5316
16	.9221	.9054	.8817	2.323	2.4478
17	.9054	.9556	.9156	2.0687	2.3472
18	1.1401	1.0227	1.0174	2.0687	2.2043
19		1.2239	1.0004	1.0513	1.0343
20	1.0111	1.1736	1.0513	1.0174	1.0174
21	.9556	1.0562	1.0343	1.0682	.9835
22	.8551	.9389	.8817	.8309	.78
23	.7377	.7545	.7461	.6783	.7209
24	.6443	1.0562	1.0395	.6443	.5426
Max	2.3739	2.2131	2.2131	2.34	2.6825
Min	.6104	.6874	.7461	.6443	.5426
Avg	1.1131	1.1499	1.1300	1.3198	1.3854

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214516 / 33/11 KV Pimpalwandi

Feeder No / Name : 203 / 11 KV CHALAKWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1658	.3978	.285	.1989	.1989
2	.2818	.4144	.285	.1823	.1989
3	.3481	.4973	.3353	.1989	.2321
4	.4144	.5138	.4191	.2321	.2818
5	.4475	.547	.4527	.2984	.3149
6	.4973	.5636	.5365	.4475	.3812
7	.5801	.6796	.503	.4807	.6299
8	.7625	.7625	.5868	.4641	.6299
9	.779	.8619	.5197	.5138	.431
10	.5304	.3149	.3856	.4641	.3978
11	.5243	.5304	.5304	.6299	.6962
12	.6882	.4807	.5304	.779	.7956
13	.6718	.4144	.5138	.7293	.8122
14	.6718	.4973	.5138	.7459	.8785
15	.6226	.5138	.4807	.7127	.9116
16	.5898	.431	.5801	.8288	.9116
17	.6062	.4475	.4475	.663	.8453
18	.5868	.3856	.5304	.6133	.779
19	.4973	.4694	.4144	.3978	.431
20	.4973	.503	.431	.4144	.5138
21	.4475	.4359	.3149	.3647	.4973
22	.3481	.3185	.3149	.3315	.3978
23	.2984	.2347	.2652	.2652	.3315
24	.1989	.3978	.2515	.1823	.2155
Max	.779	.8619	.5868	.8288	.9116
Min	.1658	.2347	.2515	.1823	.1989
Avg	.5023	.4839	.4345	.4641	.5297

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214539 / HIWARE TARFE NARAYANGAON

Feeder No / Name : 201 / KHAN DOBA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343		.0162	.4144	.3605
2	.0343		.0162	.4475	.3563
3	.0343		.0324	.4973	.3563
4	.0343		.0324	.4973	.3563
5	.0514		.0486	.4973	.3563
6	.0686		.0486	.5304	.421
7	.1543	.0655	.0486	.5636	.5506
8	.1886		.0648	.6796	.6562
9	.1372	.0655		.6796	.502
10	.0514		.0497	.0492	.0648
11	.6882	.7449	.8785	.1311	.0648
12	.6882	.9555	.9614	.1311	.0648
13	.8192	.9555	.9945	.0492	.0648
14	.6882	.9393	.9945	.1326	.0648
15		.9231	.9945	.1326	.0648
16	.8848	.8907	.9448	.1357	.0648
17	.852	.8421	.9282	.0686	.081
18	.7865	.8259	.8288	.1372	.0648
19	.0549	.0162	.0509	.0686	.0648
20		.0162	.0509	.0686	.0486
21		.0162	.0509	.0686	.0486
22		.0162	.0509	.0514	
23	.0366	.0162	.0509	.0514	
24	.0514	.0328	.0162	.3315	.3481
Max	.8848	.9555	.9945	.6796	.6562
Min	.0343	.0162	.0162	.0492	.0486
Avg	.3169	.4576	.3545	.2673	.2284

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214539 / HIWARE TARFE NARAYANGAON

Feeder No / Name : 202 / KALAMJAI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171		.2753	.017	.0171
2	.2652		.2753	.017	.0171
3	.2818		.3239	.017	.0171
4	.2785		.3239	.017	.0171
5	.2753		.4534	.017	.0171
6	.426		.4858	.017	.0171
7	.5735	.4752	.5668	.017	.1886
8	.6964		.6316	.1526	.2058
9	.7274	.7537		.2374	.1886
10	.1147	.1457	.017	.1989	.1619
11	.1638	.1619	.2035	.7432	.664
12	.1966	.1781	.2204	.7811	.8097
13	.2458	.1943	.2374	.823	.8097
14	.2622	.1781	.2374	.7773	.8583
15		.1943	.2543	.8078	.8097
16	.3113	.1943	.2374	.8223	.7287
17	.2949	.1943	.2035	.7432	.7449
18	.2294	.1619	.1865	.7373	.664
19	.2012	.0162	.1865	.0171	.1457
20		.0162	.1696	.0171	.1457
21		.0162	.1696	.0171	.0162
22		.0162	.1696	.0171	
23	.0183	.0162	.017	.0171	
24	.0171	.2458	.2753	.017	.017
Max	.7274	.7537	.6316	.823	.8583
Min	.0171	.0162	.017	.017	.0162
Avg	.2798	.1858	.2661	.2936	.3301

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&amp;M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214539 / HIWARE TARFE NARAYANGAON

Feeder No / Name : 203 / SHIVAHARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171		.0162	.4144	.4641
2	.0171		.0162	.4144	.4588
3	.0171		.0162	.4641	.4588
4	.0171		.0162	.4973	.4428
5	.0171		.0162	.5801	.4428
6	.0171		.0162	.5801	.4902
7	.0171	.0164	.0162	.6464	.6249
8	.0171		.0162	.8619	.7655
9	.0171	.0164		.9116	
10	.0171		.017	.0164	
11	.8848	1.1498	1.1105	.0168	
12	1.1469	1.1822	1.1934	.0166	
13	1.2616	1.2308	1.2431	.0166	
14	1.2289	1.085	1.2597	.0166	.0162
15		1.085	1.2763	.0168	.0162
16	1.1961	1.1012	1.1934	.0171	.0162
17	1.1633	1.1336	1.1603	.0171	.0162
18	1.0486	1.0202	.8478	.0171	.0162
19	.0183	.0162	.017	.0171	.0162
20		.0162	.017	.0171	.0162
21		.0162	.017	.0171	.0162
22		.0162	.017	.0171	
23	.0183	.0162	.017	.0171	
24	.0171	.0164	.0162	.3315	.4641
Max	1.2616	1.2308	1.2763	.9116	.7655
Min	.0171	.0162	.0162	.0164	.0162
Avg	.4077	.5699	.4144	.2474	.2789

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

HADAPSAR[053]

BU 0817

Substation No/ Name :- 213435 / 22/22 PURVRANG SUBSTATION

Feeder No / Name : 301 / SAI SATYAM

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7538	3.0933	3.0178	2.9424	3.0178
2	***	3.0178	2.8292	2.8292	2.9424
3	2.6406	2.8292	2.7161	2.7538	2.8292
4	2.6406	3.0178	2.9047	2.9424	2.8292
5	2.9424	3.3951	3.0933	3.3951	3.131
6	3.8855	3.8477	3.3951	3.8855	3.9609
7	4.7154	4.7908	4.1495	4.5268	4.7154
8	5.2812	5.168	4.6022	5.0926	4.904
9	5.168	5.3567	5.168	5.2058	4.904
10	5.6584	5.7339	5.3944	5.4698	5.3567
11	5.4698	5.4698	5.2812	5.2058	4.9794
12	5.2812	5.2812	4.8285	5.0926	4.904
13	4.5268	4.6022	4.2627	4.5268	4.3381
14	3.9609	4.225		4.1495	4.0364
15	4.7154	4.4136	4.3381	4.5268	4.3381
16	4.7154	4.1495	3.6969	4.5268	4.5268
17	4.6399	4.3381	4.0741	4.6399	4.4136
18	5.0926	4.904	4.3381	4.7154	4.5268
19	5.168	4.7908	4.7154	5.0926	4.9794
20	4.9794	4.7154	4.7154	4.8544	4.7424
21	4.7154	4.5268	4.4513	4.481	4.481
22	4.1495	4.1495	4.0741	4.0329	4.0703
23	3.6591	3.6969	3.5082	3.4728	3.5475
24	2.8292	3.2065	3.4705	3.131	3.131
Max	25.9157	5.7339	5.3944	5.4698	5.3567
Min	2.6406	2.8292	2.7161	2.7538	2.8292
Avg	5.2293	4.2800	4.0446	4.2288	4.1502

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

HADAPSAR[053]

BU 0817

Substation No/ Name :- 213435 / 22/22 PURVRANG SUBSTATION

Feeder No / Name : 302 / MANJARI

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.1417	3.3265	3.4004	2.7721	3.3265
2	2.9569	3.2526	3.3265	2.6981	3.2526
3	2.9569	3.2526	3.1417	2.5873	3.1417
4	1.2197	3.4004	3.3265	2.7721	3.1417
5	3.4374	3.6961	3.5852	3.3265	3.4374
6	4.3614	4.2505	4.1396	3.807	4.4353
7	5.1745	4.9897	4.694	4.2505	5.1745
8	5.5441	5.4332	5.0636		5.3593
9	5.5441	5.3593	5.6181	4.731	5.2854
10	5.9137	5.5441	6.0985	4.8049	5.5441
11	5.7289	5.8398	5.7289	2.726	5.7289
12	5.4702	5.7289	5.7289	5.3399	5.2484
13	4.8049	5.5441	5.0636	5.0412	4.9897
14	2.2177	5.0636		4.7798	4.5092
15	2.2177	5.0636	5.7289	5.1006	3.8477
16	3.0678		4.1766	4.731	4.8049
17	5.2854	5.1745	4.3614	4.8049	4.8049
18	5.3593	5.3593	4.1766	5.2854	4.9897
19	5.5441	5.1745	4.5462	5.3593	5.2484
20	5.1745	4.9897	4.2505	4.9897	5.0636
21	4.8788	4.8049	4.0657	4.9158	4.4772
22	4.5462	4.4353	3.6961	4.3614	4.3244
23	3.8809	3.8809	3.3265	3.807	4.3244
24	3.2526	3.5852	3.4004	2.9569	3.4374
Max	5.9137	5.8398	6.0985	5.3593	5.7289
Min	1.2197	3.2526	3.1417	2.5873	3.1417
Avg	4.2366	4.6587	4.3758	4.1717	4.4957

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

HADAPSAR[053]

BU 0817

Substation No/ Name :- 213435 / 22/22 PURVRANG SUBSTATION

Feeder No / Name : 303 / phulmala

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1509	.1509	.1509	.1509
2	.1509	.1509	.1509	.1509	.1509
3	.1509	.1509	.1509	.1509	.1509
4	.1132	.1509	.1509	.1509	.1509
5	.1509	.1509	.1509	.1509	.1509
6	.1509	.1509	.1509	.1509	.1509
7	.1886	.1509	.1509	.1886	.1509
8	.1886	.1886	.1509	.1509	.1509
9	.2263	.1509	.1132	.1886	.1509
10	.1509	.1886	.1509	.1886	.1886
11	.1509	.1886	.1509	.1886	.1509
12	.1509	.1509	.1886	.1886	.1509
13	.1509	.1509	.1509	.1509	.1509
14	.1132	.1132		.1509	.1509
15		.1132	.1509	.1886	.1509
16	.1509	.1132	.1509	.1509	.1132
17	.1132	.1132	.1509	.1509	.1132
18	.1509		.1509	.1886	.1132
19	.1509	.1509	.1509	.1886	.1509
20	.1509	.1509	.1509	.1509	.1886
21	.1509	.1509	.1509	.1509	.1509
22	.1886	.1509	.1886	.1886	.1509
23	.1886	.1509	.1509	.1509	.1509
24	.1509	.1509	.1509	.1509	.1509
Max	.2263	.1886	.1886	.1886	.1886
Min	.1132	.1132	.1132	.1509	.1132
Avg	.1558	.1493	.1525	.1650	.1493



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

HADAPSAR[053]

BU 0817

Substation No/ Name :- 219018 / 400KV LONIKAND

Feeder No / Name : 302 / Pabal

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.2579	2.8045	2.8746	2.524	2.516
2	3.2956	2.8045	3.0121	2.516	2.4806
3	3.155	2.6642	2.8841	2.4806	2.4539
4	3.2251	2.3487	3.0182	2.5514	2.4451
5	3.3653	2.8704	3.2956	2.8349	2.6642
6	4.1107		3.8009	3.5437	3.5437
7	4.7131	3.8626	4.5222	3.9689	3.7563
8	5.0069	4.8011	5.487	4.5268	4.4461
9	5.4184	5.3498	6.0723	4.904	4.7131
10	6.2414	5.3498	6.4381	5.2469	4.9611
11	6.1043	5.6584	6.4746	5.144	5.2294
12	5.3498	4.8011	6.2186	5.3498	5.2446
13		5.7613	5.9259	4.9726	.2743
14	5.0755	5.6927	4.5359	4.4925	5.1578
15	5.727	5.4184	5.1578	4.6982	5.4927
16	5.8528	.9511	4.8011	4.5268	5.5236
17	5.9991	5.0114	4.7325	4.321	5.1212
18	5.1212	5.2092	4.3896	4.0466	4.9017
19	4.5725	4.792	3.8752	3.8066	4.3801
20	4.3896	4.4627	3.4294	3.5322	4.225
21	3.8775	4.0238	3.155	3.2579	3.7311
22	3.2251	3.4374	2.8395	2.8746	3.3653
23	2.9729	3.083	7.2291	7.0165	
24	3.4728	2.774	2.9729	2.5941	2.5789
Max	6.2414	5.7613	7.2291	7.0165	5.5236
Min	2.9729	.9511	2.8395	2.4806	.2743
Avg	4.5013	4.0840	4.4643	3.9888	3.8785

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

HADAPSAR[053]

BU 0817

Substation No/ Name :- 219018 / 400KV LONIKAND

Feeder No / Name : 304 / Talegaon -D-

FEEDER SEPERATION/PURE AG

Feeder KV- 22 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.8377	5.1029	5.1882	5.2446	4.9257
2	4.9966	5.1029	5.2584	5.2446	4.9429
3	5.1383	5.032	5.3986	5.2801	4.9078
4	5.0675	5.1738	5.5388	5.4298	4.9257
5	5.5159	5.3864	5.7407	5.8116	5.2092
6	5.6699	5.9534	6.0532	6.7215	6.0242
7	6.3077	6.4849	7.0588	7.0203	6.6267
8	6.3443	6.7215	8.0476	7.2017	7.2645
9	6.893	7.3731	8.267	7.5446	
10	6.9959	7.3731	8.0841	8.2648	8.1306
11	6.8244		7.9744	7.7161	7.5835
12	.5487	.583	.7682	.583	
13		.6516	.7316	.583	
14	.583	.6516	.695	.5487	.5487
15	.6173	.6173	.7316	.5144	.5487
16	.5853	.695	.583		.6219
17	.8048		.6859	.6173	.8048
18	1.2803	1.3169	.9945	.9945	
19	1.7558	1.8656	1.5089	1.4746	1.7177
20	1.6095	1.7558	1.4746	1.406	1.6461
21	1.7558	1.6461	1.4746	1.406	1.5203
22	1.5947	1.6827	1.4723	1.3717	1.5364
23	1.382	1.3672	1.3032	1.2971	
24	4.8377	5.1578	5.2233	5.3864	4.9429
Max	6.9959	7.3731	8.267	8.2648	8.1306
Min	.5487	.583	.583	.5144	.5487
Avg	3.5629	3.5316	3.7607	3.8114	3.9173

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

HADAPSAR[053]

BU 0817

Substation No/ Name :- 219018 / 400KV LONIKAND

Feeder No / Name : 305 / Kalyani

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.4489	9.9451	9.8689	10.0976	8.3829
2	5.5632	7.5446	9.9832	9.907	8.5734
3	5.7537	7.4684	9.7546	10.1738	8.421
4		7.3922	9.2593	9.7165	9.145
5		7.697	9.1069	8.6877	9.7165
6		10.8977	9.2974	10.4405	9.526
7	3.2388	7.2398	7.0492	7.1636	7.6208
8	9.8308	10.8215	9.145	9.2593	10.25
9	11.0121	11.3169	10.8977	8.6115	10.5548
10	11.4693	11.2026	9.907	11.0883	12.1171
11	11.2407	11.8884	10.5167	11.0502	10.5929
12	8.3829	8.802	4.763	8.1924	8.1543
13		12.4219	8.6115	9.6022	10.5929
14	11.5836	11.7741	9.907	8.078	10.8596
15	12.841		10.3262	8.6115	10.2881
16	12.7267	11.9647	9.3355	8.6877	11.3931
17	12.1933	12.2314	11.4312	10.0976	10.974
18	11.2026	11.2026	10.5548	11.0502	12.3457
19	11.2026	11.0502	12.6886	11.1264	
20	8.4972	8.421	9.1069	8.7258	8.078
21	10.8596	10.3262	11.0502	10.5167	10.1738
22	9.6784	10.1357		9.907	9.3736
23	9.4879	10.0595	12.079	9.7546	
24	5.4108	8.9163	8.1924	10.8215	7.8875
Max	12.841	12.4219	12.6886	11.1264	12.3457
Min	3.2388	7.2398	4.763	7.1636	7.6208
Avg	9.3812	10.0313	9.6884	9.6403	9.7737

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

HADAPSAR[053]

BU 0817

Substation No/ Name :- 219018 / 400KV LONIKAND

Feeder No / Name : 307 / MARKAL-II

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.893	2.3487	2.4539	2.2977	2.8746
2	1.9631	2.5591	2.3487	2.3137	2.8045
3	1.9136	2.489	2.4188	2.332	2.8045
4	1.8781	2.4188	2.4539	2.2786	2.7694
5	2.332	2.7343	2.516	2.4539	2.9412
6	3.65	3.4705	2.5514	2.6993	3.1893
7	5.3368	5.644	4.9257	4.7996	4.7485
8	5.5213	7.1331	5.1943	5.9671	6.4849
9	5.5556	6.1728	5.5022	6.5844	6.275
10	6.5501	6.9616	6.2186	6.7215	8.1859
11	6.0357	7.0645	7.6086	7.2017	9.241
12	4.4239	6.7558	6.3283	6.9616	7.2291
13		6.9273	6.0357	6.07	6.941
14	3.0864	6.3786	4.7554	6.2757	6.9102
15	3.4979	7.0302	5.0114	6.3786	6.3786
16	3.8043	8.1939	5.0412	5.3498	
17	3.9872	8.3036	5.0755	6.653	7.6178
18	3.914	5.487	4.3896	5.8985	5.9259
19	2.7801	2.7538	2.572	2.9492	2.7801
20	2.9264	2.3777	2.2977	2.6749	2.5606
21	2.5972	2.2314	2.1262	2.7435	2.1948
22	2.3743	2.1033	2.0683	2.3487	2.1216
23	2.8349	2.4097	2.3487	2.8121	
24	1.8427	2.6863	2.4356	2.3663	2.8704
Max	6.5501	8.3036	7.6086	7.2017	9.241
Min	1.8427	2.1033	2.0683	2.2786	2.1216
Avg	3.5086	4.6931	3.9449	4.3805	4.8113

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

HADAPSAR[053]

BU 0817

Substation No/ Name :- 219018 / 400KV LONIKAND

Feeder No / Name : 308 / B.U.Bhandari

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0148	2.8395	3.9335	3.5757	4.9078
2	2.9447	3.0148	3.786	3.4294	4.6975
3	2.8349	2.9447	4.1366	3.546	4.7131
4	2.5941	2.8704	3.9335	3.4004	4.6273
5	3.1184	3.12	3.9262	3.7159	4.784
6	3.2956	3.6808	4.1461	3.6694	4.8548
7	3.8912	3.1471	3.6107	3.7037	4.3942
8	4.0466	3.9781	3.9872	4.0809	4.1495
9	5.0755	3.3265	4.3896	4.9383	4.2417
10	5.487	6.9616	4.6456	4.7668	4.9966
11	5.144	4.4925	4.7554	5.4184	5.6699
12	4.8011	5.2126	3.1184	5.6242	4.6422
13		5.0412	3.5117	4.8011	5.2934
14	5.0412	4.561	4.7554	5.5556	5.3864
15	5.5899	5.4893	4.1701		6.1306
16	5.1943	5.1578	3.9095	4.9383	5.6013
17	5.0114	5.3772	3.9781	5.5213	5.7796
18	5.3189	5.5967	4.0466	5.0412	5.1212
19	5.6699	5.5601	4.4239	5.6927	5.7796
20	5.4138	4.9749	3.7723	4.9383	4.9383
21	5.048	4.7554	3.5665	5.144	5.487
22	5.3285	5.3727	4.217	5.4927	5.2675
23	4.9429	4.1461	3.8272	4.8697	
24	2.9835	4.217	4.8194	3.6808	4.7668
Max	5.6699	6.9616	4.8194	5.6927	6.1306
Min	2.5941	2.8395	3.1184	3.4004	4.1495
Avg	4.4257	4.4099	4.0569	4.5889	5.0535

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

HADAPSAR[053]

BU 0817

Substation No/ Name :- 219018 / 400KV LONIKAND

Feeder No / Name : 310 / 22kv colony

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	.1715	.1715		.1715	.1905
24		.1905	.1905	.1905	.1905
Max	.1715	.1905	.1905	.1905	.1905
Min	.1715	.1715	.1905	.1715	.1905
Avg	.1715	.181	.1905	.181	.1905

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

HADAPSAR[053]

BU 0817

Substation No/ Name :- 219018 / 400KV LONIKAND

Feeder No / Name : 313 / 22 kvstone crusher

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.3086	.2804	.2743	.2743
2	.2454	.3155	.3048	.2835	.2743
3	.2454	.3506	.3086	.3048	.2743
4	.2454	.3856	.3086	.2743	.3048
5	.2401	.3856	.3429	.2743	.3086
6	.2743	.3898	.3544	.3772	.3772
7	.3772	.4961	.3772	.4115	.4207
8	.4481	.5975	.4024	.4481	.5959
9	.5228	.5975	.439	.6348	.5609
10	.6348	.5975	.5853	.5975	.5487
11	.6348	.5975	.439	.7468	.4801
12	.7095	.5975	.5487	.6348	.5487
13		.5975	.4755	.6348	.4801
14	.6348	.5601	.3658		.5487
15	.6348	.5975	.4024		.5959
16	.6219	.6219	.4481		.6219
17	.695	.695	.4854	.7468	.6584
18	.5121	.5853	.5601	.5975	.439
19	.5853	.6219	.4481	.5975	.4108
20	.439	.5487	.3734	.6348	.4755
21	.4024	.4755	.4108	.4481	.4755
22	.4207	.4458	.4115	.3772	.439
23	.3772	.3506	.2743	.3155	
24	.2401	.3544	.3506	.2743	.2743
Max	.7095	.695	.5853	.7468	.6584
Min	.2401	.3086	.2743	.2743	.2743
Avg	.4514	.5031	.4041	.4709	.4516

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

HADAPSAR[053]

BU 0817

Substation No/ Name :- 219018 / 400KV LONIKAND

Feeder No / Name : 314 / 22 kv wika

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.2769	3.6961	3.2007	3.315	3.1245
2	3.1245	3.3913	3.2769	3.1626	3.0102
3	3.0102	3.1626	3.2007	3.1245	2.934
4	2.8197	3.5437	3.1245	3.0102	2.9721
5	3.3913	3.2769	3.0483	2.9721	3.2388
6	3.8104	7.3541	3.3532	3.7723	.4191
7	4.5725	3.9628	3.8485	4.0771	4.3439
8	5.0297	4.6106	4.3439	4.8392	4.5725
9	5.2584	4.8011	4.6868	5.2965	5.6013
10	5.487	5.0678	5.0297	4.9535	5.4108
11	4.9154	5.4489	5.0678	4.9916	5.487
12	4.9535	5.1059	4.9535	4.8392	5.144
13		4.7249	4.7249	5.0678	4.9535
14	4.4582	4.7249	4.3058	2.553	4.8011
15	4.7249	4.3439	4.382	5.1059	5.0297
16	4.9535	4.8392	4.3058	5.0297	5.0678
17	5.1059	4.8392	3.7723	4.8773	3.8104
18	4.2676	4.5725	3.5056	4.5725	4.382
19	4.382	4.3439	3.4294	4.6868	4.4201
20	4.0009	4.2676	3.3913	4.382	
21	3.9628	4.0009	3.2769	4.039	4.039
22	3.9628	3.8104	2.9721	3.8485	4.1914
23	3.8485	3.2388	3.4294	3.9628	
24	3.658	3.8104	3.4294	3.7342	3.6199
Max	5.487	7.3541	5.0678	5.2965	5.6013
Min	2.8197	3.1626	2.9721	2.553	.4191
Avg	4.2163	4.3724	3.8358	4.1756	4.1170



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

HADAPSAR[053]

BU 0817

Substation No/ Name :- 219018 / 400KV LONIKAND

Feeder No / Name : 315 / 22 KV CAROLLA REALITY

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6461	1.8229	1.7878	1.6827	1.7147
2	1.5424	1.701	1.893	1.6118	1.5775
3	1.5775	1.6126	1.9631	1.6126	1.6126
4	1.6827	1.7177	1.8229	1.5775	1.5432
5	1.9281	1.8229	1.701	1.6655	1.7177
6	2.2085	2.1033	1.949	2.1262	2.1605
7	2.6578	2.2085	1.9204	2.2436	2.5941
8	2.6749	2.572	2.4143	2.5034	2.7343
9	2.8807	2.6406	2.8166		2.8464
10	3.0178	2.7778		2.915	2.9447
11	2.7435	2.9492	2.963	2.8807	2.7778
12	2.6406	2.7435	2.6578		2.7221
13		2.5377	2.5606	2.4348	2.5072
14	2.2977	2.3663	2.3045	2.1948	2.4348
15	2.4691	2.4691	2.2805	2.5034	2.3663
16	2.7801	2.7069	2.1605	2.4691	2.4977
17	2.4977	2.8753	2.2977	2.4006	2.4874
18	3.0361	3.2065	2.4006	2.5377	2.5606
19	3.1459	3.219	2.6063	2.7778	3.1093
20	3.0361	3.1093	2.4006	2.7778	2.8532
21	2.9264	2.8292	2.2977	2.5377	2.8597
22	2.6223	2.5869	2.1605	2.524	2.6703
23	2.3743	2.1384	1.949	2.1948	
24	1.989	1.9982	1.989	1.7147	2.0553
Max	3.1459	3.219	2.963	2.915	3.1093
Min	1.5424	1.6126	1.701	1.5775	1.5432
Avg	2.4511	2.4465	2.2303	2.2676	2.4064

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

HADAPSAR[053]

BU 0817

Substation No/ Name :- 219018 / 400KV LONIKAND

Feeder No / Name : 317 / Lonikand Sub-Substation-II NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 22 / OUTGOING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0038	.0038	.0038	.0038	.0038
2	.0038	.0038	.0038	.0038	.0038
3	.0038	.0038	.0038	.0038	.0038
4	.0038	.0038	.0038	.0038	.0038
5	.0038	.0038	.0076	.0038	.0038
6	.0038	.0038	.0038	.0038	.0038
7	.0038	.0038	.0038	.0038	.0038
8	.0038	.0038	.0038	.0038	.0038
9	.0038	.0038		.0038	.0038
10	.0038	.0038	.0038	.0038	.0038
11	.0038	.0038	.0038	.0038	.0038
12	.0038	.0038	.0038	.0038	.0038
13		.0038	.0038	.0038	.0038
14	.0038	.0038	.0038	.0038	.0038
15	.0038	.0038	.0038	.0038	.0038
16	.0038	.0038	.0038	.0038	.0038
17	.0038	.0038	.0038	.0038	.0038
18	.0038	.0038	.0038	.0038	.0038
19	.0038	.0038	.0038	.0038	.0038
20	.0038	.0038	.0038	.0038	.0038
21	.0038	.0038	.0038	.0038	.0038
22	.0038	.0038	.0038	.0038	.0038
23	.0038	.0038	.0038	.0038	
24	.0038	.0038	.0038	.0038	.0076
Max	.0038	.0038	.0076	.0038	.0076
Min	.0038	.0038	.0038	.0038	.0038
Avg	.0038	.0038	.0040	.0038	.0040

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

HADAPSAR[053]

BU 0817

Substation No/ Name :- 219018 / 400KV LONIKAND

Feeder No / Name : 318 / 22 KV Sanghar Feeder  
Feeder KV- 22 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0919	2.1384	2.2786	1.2269	1.9982
2	2.1605	2.4188	2.3137	1.2971	2.332
3	2.0683	2.3388	2.1971	1.3321	2.3663
4	1.8229	1.9982	2.2085	1.3672	2.2291
5	1.9631	2.0908	2.3034	1.4373	2.0576
6	2.1262	1.9982	1.491	1.6126	1.9631
7	1.7878	1.9845	.9945	1.4723	2.0908
8	2.0919	2.3663	1.0242	2.0919	2.0683
9	2.1262	2.2977		2.1605	2.2977
10	2.9492	2.7778	1.134	2.4006	2.4348
11	2.4006	2.332	1.134	2.572	2.3838
12	2.1262	2.2291	1.134	2.332	2.4539
13		2.7435	1.0974	2.7092	3.0498
14	2.332	1.8861	1.0974	2.1948	2.6749
15	2.7435	2.1605	1.086	2.7778	2.5941
16	2.268	2.4508	1.2689	2.5034	2.5606
17	2.7435	2.4508	1.3032	2.7092	2.6337
18	2.7435	2.4143	1.3032	2.7435	2.7801
19	2.8166	2.3411	1.5089	2.6406	2.3777
20	2.3777	2.7435	1.5089	2.332	2.4143
21	2.268	2.3777	1.4746	2.1605	2.5606
22	2.1735	1.8625	1.3375	1.3321	2.4143
23	2.2786	2.268	1.5238	2.0908	
24	2.1033	1.7147	2.0683	1.2003	2.0332
Max	2.9492	2.7778	2.3137	2.7778	3.0498
Min	1.7878	1.7147	.9945	1.2003	1.9631
Avg	2.2853	2.2660	1.5127	2.0290	2.3813

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

HADAPSAR[053]

BU 0817

Substation No/ Name :- 219018 / 400KV LONIKAND

Feeder No / Name : 319 / 22 Kv Fulgaon Industrial  
Feeder KV- 22 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0553	1.8781	1.9631	2.0332	1.9547
2	1.9281	1.9281	1.8519	2.0332	2.0233
3	1.893	1.8229	1.8229	1.9982	1.9547
4	2.0233	1.7878	1.9204	1.989	1.989
5	1.949	1.9982	2.0332	2.0683	2.3838
6	2.0199	2.0199	2.1033	3.2236	3.2956
7	4.5713	5.9816	5.7065	4.8548	5.2092
8	5.6242	5.8642	5.3041	5.1097	6.2049
9	1.9204			6.1728	6.8039
10			6.6941	5.727	7.8083
11			6.9502	6.4129	7.9157
12	1.2003	6.4815	7.316	6.1043	8.6111
13		5.7956	7.0599	6.7558	5.4573
14	1.5775	3.2579	5.5601	5.4184	8.059
15	2.1948	7.476	7.6086	5.6584	7.7618
16	2.7435	8.6694	6.4129	5.8985	7.7549
17	2.8166	6.6575	6.2757	5.144	6.2917
18	2.6703	4.0969	4.1838	3.0521	4.3896
19	2.4806	2.3411	2.0233	1.989	2.1948
20	2.3045	2.0119		1.9547	2.0633
21	2.0485	2.0485	1.9547	1.8861	2.1216
22	2.4356	2.0576	2.0233	1.8861	2.0851
23	1.8427	1.949	2.0553	1.8861	
24	2.0576	1.8519	1.9281	2.0233	1.9845
Max	5.6242	8.6694	7.6086	6.7558	8.6111
Min	1.2003	1.7878	1.8229	1.8861	1.9547
Avg	2.3980	3.7131	4.1251	3.8033	4.6225

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

HADAPSAR[053]

BU 0817

Substation No/ Name :- 219018 / 400KV LONIKAND

Feeder No / Name : 320 / PURVRANG

Feeder KV- 22 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.0997	6.8039	6.6956	6.3801	6.31
2	6.1698	6.5912	6.7657	9.9223	6.2049
3	6.0646	6.5204	6.7684	6.1386	6.1347
4	6.0532	6.5188	6.8359	6.089	6.2399
5	6.5547	6.9128	7.0873	6.6263	6.6606
6	8.6679	8.8889	8.2213	9.0718	10.096
7	10.8295	10.6078	10.5716	10.0164	11.1652
8	10.6653		11.7055	5.5213	11.384
9	10.9397			10.2538	11.5013
10	12.0713		12.4371	10.8025	12.3975
11	11.3855		11.7055	8.2305	11.9384
12	10.9054	11.7627	11.5226	11.1797	11.0143
13			10.4618	10.3224	10.3064
14	6.5844	9.7051		9.1564	10.1197
15	7.3388	9.9109	10.6082	10.1509	9.2547
16	8.1939	10.7179	8.3676	9.7737	10.4984
17	11.3169	10.3155	8.9506	9.8766	9.9497
18	11.3398	11.0906	8.9163	10.1509	10.1326
19	11.5958	11.3763	9.5336	10.5281	10.974
20	10.7911	10.7911	9.1564	10.1166	10.4253
21	10.096	9.9131	8.6077	9.3964	9.7302
22	9.1815	9.0261	8.5963	9.0497	8.8889
23	8.0232	8.1306	7.665	7.548	
24	6.4849	7.0873	7.2645	6.6621	6.8359
Max	12.0713	11.7627	12.4371	11.1797	12.3975
Min	6.0532	6.5188	6.6956	5.5213	6.1347
Avg	9.0153	9.0879	9.0202	8.8735	9.4853

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

MULSHI[057]

BU 0850

Substation No/ Name :- 213331 / 22 KV BHARE SWITCHING

Feeder No / Name : 302 / 22 KV LAWALE

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1901	2.0769	1.9258	1.89	2.037
2	2.0391	2.0391	1.8881	1.5104	2.037
3	2.1146	2.0013	2.0013	1.512	2.0748
4	2.2657	2.1901	2.1146	1.89	2.1879
5	3.1342	2.53	2.2657	2.268	2.6406
6	3.2097	2.7566	2.4167	2.6459	2.9424
7	3.5495	2.9454	2.7943	3.0239	3.2819
8	3.5873	3.1719	3.0964	3.4019	3.3607
9	3.8516	3.3607	3.2097		3.7761
10	3.8894	3.3985		2.4545	3.9649
11	3.9272	3.5873		3.9272	
12	3.7006	3.9649		3.9649	3.8894
13	3.9272	3.6251		3.7383	***
14	3.8516	3.5118		3.6251	3.7761
15	3.6251	3.4363		3.8894	3.7761
16	1.7748	3.6251		3.7761	3.7761
17	3.323	2.0013		3.6251	3.3985
18	3.2475	2.0013		3.5495	3.2475
19	3.474	3.0964		3.323	3.3985
20	3.2475	3.0209			3.0209
21	2.8321	2.7943		1.6992	2.8698
22	2.681	2.3789		1.586	2.4545
23	2.3412	2.2657	2.268	1.8881	2.1901
24	2.3789	2.0013	2.0391	1.8881	2.0769
Max	3.9272	3.9649	3.2097	3.9649	37.1191
Min	1.7748	2.0013	1.8881	1.5104	2.037
Avg	3.0901	2.8242	2.3654	2.7762	4.4912

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

MULSHI[057]

BU 0850

Substation No/ Name :- 213331 / 22 KV BHARE SWITCHING

Feeder No / Name : 303 / VULCAN

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2862	2.1338	1.6648	.451	1.8671
2	2.21	1.9814	1.6073	.6241	1.6975
3	2.0957	1.829	1.4937	.6462	1.5684
4	2.1338	1.7528	1.4335	.6607	1.5893
5	2.0957	1.7147	1.5059	.8259	1.7177
6	2.21	1.7909	1.5388	1.1563	1.8107
7	1.6385	1.5623	.5921	1.1683	1.6385
8	2.3624	2.4768	.5053	2.1647	2.5149
9	2.6292	2.553	.4701	2.6513	2.5149
10	2.9721	2.0576		2.0538	2.6566
11	2.934	2.0094		2.6406	
12	2.7816	2.3958		2.6292	2.4768
13	2.8959	2.4768		2.5911	2.4387
14	3.1626	2.4387		2.934	2.8872
15	2.21	2.6619		2.5911	2.9662
16	2.5149	2.7435		2.934	2.1338
17	2.7054	2.2862		3.0483	2.1274
18	2.3243	2.1338		2.6292	2.2012
19	2.7435	2.4387		2.7816	2.5098
20	2.4768	2.21		2.0576	2.3554
21	2.4768	2.1338		2.5911	1.9394
22	2.5911	1.9258		2.4387	1.6699
23	2.1338	1.9297	.2995	2.21	2.1338
24	1.9755	1.829	1.3915	.4498	1.6766
Max	3.1626	2.7435	1.6648	3.0483	2.9662
Min	1.6385	1.5623	.2995	.4498	1.5684
Avg	2.4400	2.1444	1.1366	1.9554	2.1344

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

MULSHI[057]

BU 0850

Substation No/ Name :- 213338 / 22kV Khanapur Switching

Feeder No / Name : 301 / KUDAJE

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6742	.7491	.6804	.6804	.756
2	.5993	.6742	.6419	.7189	.6797
3	.6368	.5993	.6054	.6824	.6048
4	.7491	.5244	.5687	.7954	.8316
5	.9739	.824	.7552	.945	.944
6	1.1237		.8307	1.0594	1.1328
7	1.3859		.945	1.2084	1.2084
8	1.3859		1.0573	1.4364	1.3972
9	1.1611	1.2461	1.0973	1.8881	1.2084
10	1.1237	1.0973	1.1363	1.6992	1.0951
11	1.1611	1.1741	1.1706	1.5482	1.0573
12	1.1986	1.2096	1.134	1.1706	1.0195
13	.9364	1.2108	1.0584	1.0573	1.0206
14	.9739	1.134		1.2852	
15	.9739	1.8125		1.2084	
16	1.0488	1.5135		1.2096	1.0195
17	1.1986	1.586	1.0206	.793	1.1328
18	1.311	1.6632	1.2486	1.3216	1.1706
19	1.3859	1.8559	1.2108	1.3986	1.2474
20	1.2735	1.9278	1.2084	1.2461	1.0951
21	1.1986	1.134	1.0962	1.1328	1.0195
22	.8989	.9828	.945	1.0195	1.0216
23	.824	.7175	.7175	.8685	.8685
24	.6742	.7866	.7182	.7175	.8307
Max	1.3859	1.9278	1.2486	1.8881	1.3972
Min	.5993	.5244	.5687	.6804	.6048
Avg	1.0363	1.1630	.9451	1.1288	1.0164



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

MULSHI[057]

BU 0850

Substation No/ Name :- 213338 / 22kV Khanapur Switching

Feeder No / Name : 302 / Donje

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7015	.7385	.8307	.7182	.9063
2	.6646	.6646	.7567	.7583	.7938
3	.7385	.6277	.7567	.7567	.7552
4	.8861	.6646	.7189	.8316	.9063
5	1.1077	.7754	.8307	1.0951	1.0584
6	1.3292	1.3292	.9099	1.2096	1.2839
7	1.6246	1.5138	1.0206	1.3243	1.4349
8	1.5498	1.4769	1.0573	1.4742	1.586
9	1.2923	1.4742	1.134	1.5104	1.4364
10	1.2554	1.5135	1.2852	1.3972	1.2826
11	1.1815	1.5482	1.4364	1.2839	1.2461
12	1.134	1.6254	1.3621	1.3216	1.2461
13	1.1815	1.3243	1.2461	1.2461	1.2084
14	1.0708	1.3972		1.1328	1.0951
15	1.0708	1.5104	1.2096	1.2852	
16	1.0708	1.5876	1.5104	1.3972	1.2461
17	1.2554	1.5513		1.3216	1.2461
18	1.3661	1.515	1.3621	1.3594	1.2839
19	1.4031	1.5529	1.3972	1.4364	1.4757
20	1.2554	1.4349	1.4014	1.3972	1.2839
21	1.1815	1.323	1.1718	1.2461	1.2084
22	1.1077	1.2839	1.2108	1.1706	1.1328
23	.9231	1.0973	.944	1.0206	.944
24	.7453	.8123	.9818	.8307	.9818
Max	1.6246	1.6254	1.5104	1.5104	1.586
Min	.6646	.6277	.7189	.7182	.7552
Avg	1.1290	1.2643	1.1152	1.1885	1.1757

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

MULSHI[057]

BU 0850

Substation No/ Name :- 213338 / 22kV Khanapur Switching

Feeder No / Name : 303 / Osade

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8944	1.0434	1.1718	.9063	1.1328
2	.8198	.9689	1.1706	.9063	1.0195
3	.9689	.8944	1.134	.9081	.944
4	1.118	.8944	1.0573	1.0951	1.0951
5	1.3416	1.1925	1.1351	1.1351	1.2084
6	1.4161	1.4161	1.1753	1.3243	1.4364
7	1.5652	1.7515	1.2852	1.4771	1.5876
8	1.6237	1.6024	1.323	1.8522	1.8503
9	1.1925	1.8881	1.323		1.6992
10	1.4161	1.6992	1.3986		1.7388
11	1.5652	1.627	1.4014		1.8144
12	1.7142	1.8162	1.3608	1.8125	1.8503
13	1.6024	1.3972	1.2852	1.586	1.586
14	1.5279	1.737		1.701	1.5482
15	1.6024	1.8144	.6797	1.5135	
16	1.4906	1.5135	.6419	1.6992	1.4727
17	1.5652		1.2474	1.6992	1.6237
18	1.677		1.3972	1.7748	1.627
19	1.7888		1.5513	1.8144	1.8125
20	1.7888		1.5498	1.6992	1.737
21	1.6397	1.7766	1.3608	1.5876	1.586
22	1.4906	1.4	1.2461	1.4349	1.3594
23	1.2298	1.3608	1.0573	1.2839	1.1706
24	.9316	1.118	1.1718	.8685	1.2084
Max	1.7888	1.8881	1.5513	1.8522	1.8503
Min	.8198	.8944	.6419	.8685	.944
Avg	1.4154	1.4456	1.2228	1.4323	1.4830

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

NASARAPUR[058]

BU 0868

Substation No/ Name :- 214453 / 33 KV KHED SHIVAPUR

Feeder No / Name : 301 / Katraj -Nasarapur-

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6975	2.8292	2.8292	2.8292	2.8292
2	1.6975	2.6406	2.6406	2.8292	2.6406
3	1.5089	2.452	2.452	2.6406	2.452
4	1.6975	2.452	2.452	2.6406	2.2634
5	1.8861	2.452	2.2634	2.8292	2.6406
6	2.0748	3.0178	2.8292	2.8292	3.0178
7	2.452	3.3951	3.3951	3.3951	
8	2.8292	3.5837	4.5268	3.5837	3.7723
9	3.9609	4.7154	4.3381	4.904	4.5268
10	5.0926			6.0357	5.6584
11	5.4698	5.6584	5.0926	6.4129	6.2243
12	5.4698	5.4698	5.2812	6.0357	6.2243
13	4.5268	4.5268	4.5268	4.904	4.5268
14	5.2812	5.4698	4.904	5.8471	5.4698
15	5.4698	5.6584	5.0926	5.6584	5.4698
16	5.0926	5.6584	5.4698	5.6584	5.2812
17	5.4698	5.6584	5.2812	5.6584	5.6584
18	4.7154	4.904	4.5268	5.2812	4.904
19	4.7154	4.7154	4.1495	4.5268	4.7154
20	3.9609	4.1495	3.7723	3.9609	3.9609
21	3.7723	3.7723	3.5837	3.7723	3.3951
22	3.5837	3.5837	3.2065	3.5837	3.3951
23	3.2065	3.7723	3.2065	3.2065	
24	1.6975	3.0178	3.7723	2.8292	3.0178
Max	5.4698	5.6584	5.4698	6.4129	6.2243
Min	1.5089	2.452	2.2634	2.6406	2.2634
Avg	3.6387	4.0675	3.8953	4.2438	4.1838

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

NASARAPUR[058]

BU 0868

Substation No/ Name :- 214453 / 33 KV KHED SHIVAPUR

Feeder No / Name : 302 / Kalyan

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1203	1.1088	1.1317	.924	1.2936
2	.9335	1.1088	1.1317	.9335	.924
3	.9431	1.1088	.9431	1.1203	.924
4	1.1317	.924	.9431	.9335	1.2936
5	1.307	1.1088	1.1317	1.1317	1.2936
6	1.4784	1.4784	1.3203	1.307	1.4784
7	1.5089	1.848	1.3203	1.5089	1.848
8	2.0748	2.0328	1.5089	2.2405	2.0328
9	2.5873	2.0748	1.6975	2.5873	2.5873
10	2.8006	2.452	1.8861	2.5873	2.7721
11	2.7721	2.6406	1.848	2.4025	2.9569
12	2.8006	2.452	1.8861	2.2177	2.8006
13	2.2177	2.0748	1.8861	2.2177	2.7721
14	2.2177	2.452	1.8671	2.5873	2.9569
15	2.5873	2.2634	2.0748	2.4025	2.9874
16	2.4025	2.2634	1.8861	2.2177	2.9569
17	2.4025	2.2634	1.8861	2.2177	2.7721
18	2.2177	2.0748	1.6632	2.0328	2.6406
19	2.2177	1.8861	1.5089	2.0328	2.4025
20	2.2177	1.8861	1.4937	1.848	2.0328
21	1.848	1.5089	1.1203	1.848	1.848
22	1.6632	1.6975	.9431	1.4784	1.6632
23	1.4784	1.1317	.9431	1.2936	
24	.9431	1.2936	1.1317	.9335	1.2936
Max	2.8006	2.6406	2.0748	2.5873	2.9874
Min	.9335	.924	.9431	.924	.924
Avg	1.9113	1.7972	1.4647	1.7918	2.1100

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

NASARAPUR[058]

BU 0868

Substation No/ Name :- 214453 / 33 KV KHED SHIVAPUR

Feeder No / Name : 303 / Shivare

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3696	.3658	.3772	.3772	.3734
2	.3696	.3658	.3772	.3734	.3734
3	.3696	.3658	.3772	.3734	.3734
4	.3696	.3658	.3772	.5601	.5601
5	.3696	.5487	.3772	.5601	.5601
6	.3696	.5487	.5658	.5544	.5601
7	.5601	.7316	.9431	.5658	.7468
8	.7545	.7316	.7545	.7545	.7468
9	.7316	.9431	.9431	.924	.9145
10	1.0974	.9431	1.1317	.924	1.0974
11	.9145	1.1317	.9431	.924	1.0974
12	1.0974	1.1317	1.1317	1.1088	1.267
13	1.0974	1.1317	1.1088	1.1088	.9145
14	1.0974	1.1317	1.3203	1.2936	1.0974
15	1.0974	1.3203	1.1317	1.1088	1.0974
16	.9145	1.3203	1.1317	1.1088	1.0974
17	1.0974	1.1317	1.1317	1.1088	1.0974
18	.9145	1.1317	.924	.3696	.9145
19	.9145	.9431	.7545	.7392	.9145
20	.7316	.7545	.7392	.7392	.7316
21	.7316	.5658	.5658	.7392	.7316
22	.7316	.5658	.5601	.3696	.5487
23	.5487	.5658	.3772	.5544	
24	.3772	.3658	.3772	.3772	.3734
Max	1.0974	1.3203	1.3203	1.2936	1.267
Min	.3696	.3658	.3772	.3696	.3734
Avg	.7345	.7959	.7676	.7340	.7908

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

NASARAPUR[058]

BU 0868

Substation No/ Name :- 214453 / 33 KV KHED SHIVAPUR

Feeder No / Name : 304 / Kataraj Exp.

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	.7545	.5658	.7545	1.1431
2	.7545	.7545	.5658	.7545	1.1431
3	.7545	.5658	.7545	.7545	.9526
4	.5658	.5658	.7545	.7545	.7621
5	.7545	.5658	.7545	.9431	.9526
6	.9431	.5658	.7545	.9431	.9526
7	1.1317	.5658	.7545	.7545	.9526
8	1.8861	1.3203	.7545	1.3203	1.9052
9	2.8292	1.5089	.7545	1.8861	1.8861
10	2.2634	1.6975	.5658	2.6406	2.0748
11	1.6975	.7545	.5658	2.2634	1.1317
12	2.0748	.7545	.5658	1.8861	2.0748
13	1.8861	1.5089	.5658	2.6406	1.8861
14	1.1317	.9431	.5658	2.0748	1.3203
15	1.1317	2.0748	.5658	2.6406	1.8861
16	1.1317	1.1317	.5658	1.3203	1.8861
17	1.1317	.9431	.5658	.9431	1.1317
18	.9431	.9431	.5658	.7545	.9431
19	.9431	.9431	.7545	.9431	.9431
20	.7545	.7545	.5658	.7545	.7545
21	.9431	.9431	.7545	.9431	.7545
22	.9431	.7545	.7545	1.1317	.9431
23	.7545	.5658	.7545	1.1317	
24	.9431	.7545	.5658	.7545	1.1317
Max	2.8292	2.0748	.7545	2.6406	2.0748
Min	.5658	.5658	.5658	.7545	.7545
Avg	1.2182	.9431	.6523	1.3203	1.2831

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

NASARAPUR[058]

BU 0868

Substation No/ Name :- 214453 / 33 KV KHED SHIVAPUR

Feeder No / Name : 305 / RASIA EXP

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.1886	.1886	.1886
2	.1886	.1886	.1886	.1886	.1886
3	.1886	.1886	.1886	.1886	.1886
4	.1886	.1886	.1886	.1886	.1886
5	.1886	.1886	.1886	.1886	.1886
6	.1886	.1886	.1509	.1886	.1886
7	.1886	.1886	.1886	.1886	.1886
8	.1886	.1886	.1886	.1886	.1886
9	.3772	.3772	.3772	.3772	.3772
10	.3772	.3772	.3772	.3772	.3772
11	.3772	.3772	.3772	.3772	.1886
12	.3772	.3772	.3772	.3772	.3772
13	.1886	.1886	.1886	.1886	.1886
14	.3772	.3772	.1886	.3772	.3772
15	.1886	.1886	.1886	.3772	.1886
16	.3772	.1886	.1886	.3772	.1886
17	.1886	.1886	.1886	.1886	.1886
18	.1886	.1886	.1886	.1886	.1886
19	.1886	.1886	.1886	.1886	.1886
20		.1886	.1886	.1886	.1886
21	.1886	.1886	.1886	.1886	.1886
22	.1886	.1886	.1886	.1886	.1886
23	.1886	.1886	.1886	.1886	
24	.1886	.1886	.1886	.1886	.1886
Max	.3772	.3772	.3772	.3772	.3772
Min	.1886	.1886	.1509	.1886	.1886
Avg	.2378	.2279	.2185	.2436	.2214

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

NASARAPUR[058]

BU 0868

Substation No/ Name :- 214453 / 33 KV KHED SHIVAPUR

Feeder No / Name : 306 / STAR EXP.

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.3772	.3772	.3772	.381
2	.1886	.3772	.3772	.3772	.381
3	.1886	.3772	.3772	.3772	.381
4	.1886	.3772	.3772	.1886	.381
5	.1886	.3772	.3772	.1886	.381
6	.1886	.3772	.3772	.1886	.381
7	.3772	.3772	.3772	.3772	.381
8	.3772	.3772	.3772	.3772	.381
9	.3772	.3772	.3772	.3772	.3772
10	.5658	.3772	.1886	.5658	.5658
11	.3772	.5658	.3772	.5658	.5658
12	.3772	.3772	.1886	.3772	.5658
13	.5658	.5658	.3772	.5658	.5658
14	.5658	.5658	.3772	.5658	.5658
15	.5658	.5658	.3772	.5658	.5658
16	.3772	.3772	.3772	.5658	.3772
17	.3772	.3772	.3772	.5658	.3772
18	.3772	.3772	.3772	.3772	.3772
19	.3772	.3772	.3772	.3772	.3772
20	.3772	.3772	.1886	.3772	.3772
21	.3772	.3772	.3772	.3772	.3772
22	.3772	.3772		.3772	.3772
23	.3772	.3772	.3772	.5658	
24	.1886	.3772	.3772	.3772	.3772
Max	.5658	.5658	.3772	.5658	.5658
Min	.1886	.3772	.1886	.1886	.3772
Avg	.3536	.4086	.3526	.4165	.4277



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

NASARAPUR[058]

BU 0868

Substation No/ Name :- 214469 / 33 KV PABE

Feeder No / Name : 201 / Ghisar

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.2772	.2587	.2587	.2858
2	.2427	.2378	.2402	.2402	.2858
3	.2452	.2378	.2402	.2402	.2858
4	.2452	.2378	.2402	.2402	.2858
5	.2801	.3109	.2772	.2957	.381
6	.3511	.3475	.2772	.4435	.4572
7	.5914	.5914	.5914	.5729	.6097
8	.6099	.6468	.6653	.6099	.7545
9	.6283	.6219	.6653	.5914	.6979
10	.6838	.695	.7133	.6099	.7545
11	.695	.1478	.7316	.6099	.6602
12	.4207	.5914	.5853	.5175	.6413
13	.4207	.6219	.6036	.4805	.679
14	.4382	.5487	.567	.4435	.6602
15	.5487	.6219	.6401	.6099	.679
16	.5121		.6036	.6413	.7545
17	.567		.6219	.6224	.6602
18	.6468	.8048	.695	.7545	.811
19	.8131	.9328	.9145	.8865	.9431
20	.7947	.5601	.8596	.8676	.8865
21	.6838	.7316	.695	.7922	.7922
22	.5487	.5121	.5121	.5335	.5335
23	.3475	.3206	.3361	.362	.3048
24	.2801	.3142	.2587	.2772	.3048
Max	.8131	.9328	.9145	.8865	.9431
Min	.2427	.1478	.2402	.2402	.2858
Avg	.4940	.496	.5330	.5209	.5878

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

NASARAPUR[058]

BU 0868

Substation No/ Name :- 214469 / 33 KV PABE

Feeder No / Name : 203 / 11 KV Margasani (AG)

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.2058		.4108	
2	.3018	.2035	.2587	.4108	
3	.3018	.2035	.2587	.3921	
4	.2829	.2374	.2587	.3734	
5	.2801	.2543	.2957	.3734	
6	.3018	.2543	.3326	.1848	
7				.2427	
8				.2427	.6979
9				.2801	.7545
10				.6348	.811
11				.6348	.8299
12				.7095	.8676
13				.6908	.7545
14				.6722	.6979
15				.7282	.7356
23	.2012	.112	.3142		
24	.2987	.2058	.2801	.4108	
Max	.3018	.2543	.3326	.7282	.8676
Min	.2012	.112	.2587	.1848	.6979
Avg	.2838	.2096	.2855	.4620	.7686

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

URALIKANCHAN[059]

BU 0876

Substation No/ Name :- 214494 / 33 KV/22 KV Koregaon Mul

Feeder No / Name : 301 / Urulikanchan

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9959	2.0165	2.0538	2.0748	2.1658
2	1.9959	1.8671	1.9791	1.9993	2.1285
3		1.7924	1.9418	1.9993	2.1658
4		2.3899	2.0165	2.1125	2.2405
5	2.6242	2.6139	2.1658	2.2634	2.3899
6	2.9199	2.8006	2.4272	2.8669	2.838
7	3.5482	3.5475	3.1741	3.81	3.4728
8	3.6222	3.5848	3.5101	3.6214	3.4728
9	3.1367	3.2114	3.4328	3.2442	3.062
10	3.0247	3.0308	3.1687	2.9938	2.9127
11	3.062	2.9199	3.0933	2.7721	2.838
12	2.8753	2.846	2.8753	2.6981	2.7633
13	2.8006	2.5873	2.726	2.5873	2.4646
14	2.6513	2.5873	2.4272	2.4394	2.2779
15	2.6139	2.5873	2.3525	2.4394	2.3525
16	2.5766	2.6242	2.3899	2.5503	2.5019
17	2.726	2.6612	2.809	2.6242	2.4646
18	3.3981	2.7351	3.0678	2.6981	3.3573
19	3.8089	3.1417	3.3634	3.1047	3.6222
20	3.4728	2.8829	3.1417	2.9199	4.9291
21		2.726	2.9569	2.846	3.0994
22	2.95	2.3525	2.7161	2.7351	
23	2.5393	2.2405	2.452	2.3525	
24	2.0698	2.2405	2.1658	2.3011	2.2779
Max	3.8089	3.5848	3.5101	3.81	4.9291
Min	1.9959	1.7924	1.9418	1.9993	2.1285
Avg	2.8768	2.6661	2.6836	2.6689	2.8090

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

URALIKANCHAN[059]

BU 0876

Substation No/ Name :- 214494 / 33 KV/22 KV Koregaon Mul

Feeder No / Name : 302 / Shindewadi

FEEDER SEPERATION/PURE AG

Feeder KV- 22 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7915	2.5339	2.6139		
2	2.7915	2.5701	2.6139		
3	2.7161	2.5339	2.6139		
4	2.7161	2.6063	2.6886		
5	2.6406	2.6787	2.6886		
6	2.6406	2.7511	2.7633		
8				2.6673	4.1076
9	.0377			3.5056	4.5557
10	.0377			4.0741	4.7058
11	.0377			4.225	4.7058
12				4.3759	4.6334
13				4.2627	4.4163
14				4.1495	4.3896
15				4.1495	4.2715
23	2.5339	2.6139			
24	2.7161	2.5339	2.6139		
Max	2.7915	2.7511	2.7633	4.3759	4.7058
Min	.0377	2.5339	2.6139	2.6673	4.1076
Avg	1.9690	2.6027	2.6566	3.9262	4.4732

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

URALIKANCHAN[059]

BU 0876

Substation No/ Name :- 214494 / 33 KV/22 KV Koregaon Mul

Feeder No / Name : 303 / Peth

FEEDER SEPERATION/PURE AG

Feeder KV- 22 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1989	.3018
2				.1989	.3353
3				.1989	.3018
4				.2321	.3018
5				.2652	.2347
6				.3315	.2347
8			.3353		
9			.3978		
10			.5967		
11	1.0349	.8288	.8951		
12	1.1827	.8951	1.0349		
13	1.1827	.9614	1.0349		
14	1.2567	.9945	.8501		
15	.8871	.9282	.8501		
16	.8131	.8619			
17	.8048	.7625			
18	.6653	.663			
21			.2652	.2984	
22			.2652	.2984	
23			.2321	.3018	
24				.2587	.3018
Max	1.2567	.9945	1.0349	.3315	.3353
Min	.6653	.663	.2321	.1989	.2347
Avg	.9784	.8619	.6143	.2583	.2874

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

URALIKANCHAN[059]

BU 0876

Substation No/ Name :- 214494 / 33 KV/22 KV Koregaon Mul

Feeder No / Name : 304 / ASHTAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0719	1.2071	1.0349	1.0349	1.0349
2	1.0349	1.1706	1.0349	1.0719	1.0349
3	.961	1.2071	1.0719	1.1088	1.1088
4	1.0349	1.3169	1.1827	1.2936	1.1827
5	1.1827	1.39	1.4415	1.5524	1.4415
6	1.7002	1.9387	1.9589	1.9589	2.0698
7	2.1068	2.1216	2.1068	2.1437	2.1807
8	1.848	1.5729	1.885	1.922	1.885
9	1.8656	1.5364	1.7002	1.4784	1.5154
10	1.3535	1.4415	1.3676	1.4045	1.3535
11	1.2803	1.2567	1.0349	1.2197	1.2437
12	.9145	1.1827	1.0974	1.1088	1.0974
13	1.0242	1.1827	.9877	.961	.9511
14	1.0608	.9979	.9511	.9979	.9877
15	1.0608	1.0349	.9511	.9979	.9511
16	1.0608	1.0349	.7316	1.0349	1.0242
17	.9511	1.0719	1.1088	.9979	1.0974
18	1.39		1.3676	1.2936	1.2803
19	1.7193	.6653	1.6632	1.5893	1.5729
20	1.4998	.5544	1.5154	1.4415	1.4632
21	1.4266	.4066	1.3676	1.2936	1.3535
22	1.2803		1.2936	1.2936	
23	1.1706	1.0719	1.2197	1.1827	
24	1.1088	1.1706	1.0349	1.1088	1.1088
Max	2.1068	2.1216	2.1068	2.1437	2.1807
Min	.9145	.4066	.7316	.961	.9511
Avg	1.2961	1.2061	1.2962	1.3121	1.3154

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

URALIKANCHAN[059]

BU 0876

Substation No/ Name :- 214494 / 33 KV/22 KV Koregaon Mul

Feeder No / Name : 305 / ULTRATECH

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.7545	.2241	.4572	.2241
2		.679	.2241	.2286	.1494
3	.0377	.0377	.1494	.0381	.0373
4	.0377	.0377	.037	.0381	.0373
5	.0377	.0377	.0373	.0381	.0373
6	.0377	.0377	.0373	.0381	.0373
7	.0377		.0373	.0381	.0373
8	.0373	.0377	.0373	.0381	.0373
9	.0377	.0377	.0381	.0381	.0373
10	.0377	.0377	.0381	.0377	.0377
11	.0377	.0377	.0381	.0377	.0377
12	.0377	.2641	.2641	.679	
13	.2263	.3018	.6584	.679	.3018
14	.2263	.3018	.6036	.679	.3018
15	.2263	.3018	.6036	.2263	.3658
16	.2263	.2263	.7316	.2263	.2195
17	.3018	.2263	.2263	.3018	.3018
18	.3018	.2263	.2263	.3018	.3018
19	.3018	.2263	.3018	.2263	.3018
20	.3772	.2641	.2263	.2957	.3395
21	.3018	.2987	.2263	.3018	.3018
22	.3772	.2987	.2286	.2263	
23	.7545	.2987	.3048	.2241	
24	.6036	.7545	.2241	.381	.2241
Max	.7545	.7545	.7316	.679	.3658
Min	.0373	.0377	.037	.0377	.0373
Avg	.2165	.2489	.2385	.2407	.1747

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

LONAVALA[060]

BU 0884

Substation No/ Name :- 213343 / 22/22 KV NANGARGAON SWT SS

Feeder No / Name : 301 / 22 KV VALVAN

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3018	.3395		.2058
2		.3018	.3018		.2058
3		.2641	.3395		.2058
4		.3018	.3395		.2058
5		.3395	.3395		.2058
6		.415	.4527		.3086
7		.4904	.5281		.5144
8		.5281	.6036		.5144
9			.679		
10			.5658		
11			.4527		
12			.4527		
13			.4527		
14			.3772		
15			.3018		
16			.3395	.3018	
17	.3395	.3772	.3086	.3018	.3395
18	.4527	.4527	.3086	.3772	.3772
19	.5281	.5658	.4115	.4904	.4904
20	.5281		.5144	.4527	.4904
21	.4904	.5281	.4115	.4527	.4904
22	.4904	.4904	.4115	.4115	.415
23	.3772	.415	.4115	.3086	.3086
24		.3018	.3772		.3086
Max	.5281	.5658	.679	.4904	.5144
Min	.3395	.2641	.3018	.3018	.2058
Avg	.4581	.4049	.4175	.3871	.3492



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

LONAVALA[060]

BU 0884

Substation No/ Name :- 213343 / 22/22 KV NANGARGAON SWT SS

Feeder No / Name : 302 / 22 KV WATER WORKS

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 22 / OUTGOING

UTILITY

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2641	.2641		.3086
2		.2641	.2263		.3086
3		.2641	.2263		.3086
4		.1886	.2641		.2058
5		.2641	.2641		.2058
6		.3395	.3395		.2058
7		.3395	.3395		.2058
8		.3395	.3772		.3086
9			.3772		
10			.2263		
11			.3395		
12			.415		
13			.2263		
14			.3395		
15			.3772		
16			.2641	.3772	
17	.3018	.3018	.3086	.3395	.3018
18	.3018	.3018	.3086	.2641	.3018
19	.3772	.3018	.3086	.3018	.2641
20	.3018	.3395	.3086	.2641	.3018
21	.3018	.3395	.2058	.3018	.2641
22	.3395	.3395	.7202	.2058	.3018
23	.3018	.3018	.2058	.3086	.3086
24		.2641	.3018		.3086
Max	.3772	.3395	.7202	.3772	.3086
Min	.3018	.1886	.2058	.2058	.2058
Avg	.3180	.2971	.3139	.2954	.2756

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

LONAVALA[060]

BU 0884

Substation No/ Name :- 213343 / 22/22 KV NANGARGAON SWT SS

Feeder No / Name : 303 / 22 KV BARA BUNGLOW

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.679	.7167		.6173
2		.6413	.679		.6173
3		.6413	.679		.5144
4		.6036	.679		.5144
5		.679	.679		.5144
6		.7545	.8676		.7202
7		.8676	.9054		.823
8		.7545	.8676		.823
9			.9054		
10			.9054		
11			.9054		
12			.9054		
13			.8299		
14			.7545		
15			.7545		
16			.8299	.8299	
17	.679	.7922	.7202	.7167	.7167
18	.7922	.9054	.7202	.7545	.7545
19	.9431	1.0562	.9259	.9054	.9431
20	.9431	1.0185	.823	.3018	.8676
21	.8676	.9054	.823	.3018	.7922
22	.8299	.9054	.7202		.7545
23	.7167	.7922	.7202		.6173
24		.679	.7545		
Max	.9431	1.0562	.9259	.9054	.9431
Min	.679	.6036	.679	.3018	.5144
Avg	.8245	.7922	.7946	.6350	.7060

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

LONAVALA[060]

BU 0884

Substation No/ Name :- 213343 / 22/22 KV NANGARGAON SWT SS

Feeder No / Name : 304 / 22 KV LONAVALA BAZAR

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2071	1.094		.9259
2		1.1694	1.094		.9259
3		1.094	1.094		.823
4		1.0185	1.094		.9259
5		1.1317	1.1317		.9259
6		1.3203	1.3203		1.2346
7		1.5089	1.5466		1.5432
8		1.8107	1.9993		1.6461
9			2.2257		
10			2.2257		
11			2.0748		
12			1.8861		
13			1.7353		
14			1.6975		
15			1.6598		
16			1.6598	1.5466	
17	1.773	1.6598	1.5432	1.6221	1.6598
18	2.0748	2.037	1.8519	1.8861	1.8107
19	2.2257	2.4143	1.3717	2.1125	2.0748
20	2.1502	2.2257	2.0576	1.9616	2.037
21	1.9616	2.1125	1.9547	1.8484	1.8107
22	1.8107	1.8107	1.6461	1.4403	1.6221
23	1.5466	1.5089	1.4403	1.1317	1.1317
24		1.3203	1.2449		1.0288
Max	2.2257	2.4143	2.2257	2.1125	2.0748
Min	1.5466	1.0185	1.094	1.1317	.823
Avg	1.9347	1.5844	1.6104	1.6937	1.3829

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

LONAVALA[060]

BU 0884

Substation No/ Name :- 213343 / 22/22 KV NANGARGAON SWT SS

Feeder No / Name : 305 / 22 KV NANGARGAON

SHEDDABLE FEEDER HAVING WEEKLY

INDUSTRIAL Feeder KV- 22 /

STAGGERING (MIDC, EQUIVALENT)

OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9054	.9431		.9259
2		.9808	.9431		.7202
3		.9054	.9054		.7202
4		.7922	.7545		.7202
5		.679	.679		.7202
6		.8299	.7167		.7202
7		.7922	.7167		.823
8		.9431	.8299		.823
9			1.1694		
10			1.2826		
11			1.358		
12			1.2826		
13			1.0562		
14			1.0562		
15			1.2071		
16			1.2449	1.6221	
17	1.3957	1.4712	1.1317	1.4335	1.4712
18	1.2071	1.358	.9259	1.2071	1.2449
19	1.1694	1.2826	.9259	1.1694	1.1694
20	1.1317	1.2449	.823	.9431	1.0185
21	1.2071	1.1317	.823	.9431	.9431
22	1.0185	1.094	.7202	.823	.9431
23	.9808	1.0185	.6173	.823	.7202
24		.7922	1.0562		.7202
Max	1.3957	1.4712	1.358	1.6221	1.4712
Min	.9808	.679	.6173	.823	.7202
Avg	1.1586	1.0138	.9654	1.1205	.9002

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

LONAVALA[060]

BU 0884

Substation No/ Name :- 213343 / 22/22 KV NANGARGAON SWT SS

Feeder No / Name : 306 / 22 KV AUNDHE

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1509	.1509		.1029
2		.1509	.1509		.1029
3		.1509	.1509		.1029
4		.1509	.1509		.1029
5		.2641	.1886		.2058
6		.3772	.3395		.3086
7		.415	.415		.4115
8		.4527	.4527		.4115
9			.3772		
10			.2641		
11			.2641		
12			.2263		
13			.1886		
14			.2263		
15			.2263		
16			.2263	.1886	
17	.2263	.2263	.2058	.2263	.1886
18	.3018	.2641	.2058	.3018	.3018
19	.3772	.3772	.3086	.3395	.3395
20	.3395	.3772	.3086	.3018	.3018
21	.3018	.3018	.3086	.3018	.3018
22	.2641	.2641	.3086	.3086	.2263
23	.1886	.1886	.2058	.2058	.2058
24		.1509	.1509		.2058
Max	.3772	.4527	.4527	.3395	.4115
Min	.1886	.1509	.1509	.1886	.1029
Avg	.2856	.2664	.2501	.2718	.2388

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

LONAVALA[060]

BU 0884

Substation No/ Name :- 213343 / 22/22 KV NANGARGAON SWT SS

Feeder No / Name : 307 / 22 KV KURWANDE (R)

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7167	.7922		.6173
2		.7167	.7167		.6173
3		.679	.7167		.6173
4		.679	.7545		.6173
5		.9054	.7922		.7202
6		1.1317	1.1317		1.1317
7		1.4712	1.3957		1.6461
8			1.7353		1.5432
9			1.8484		
10			1.5466		
11			1.358		
12			1.2071		
13			1.0185		
14			.9431		
15			.8676		
16			.9054	.8676	
17	.9808	.9808	1.0288	.9054	.9054
18	1.1317	1.2071	1.0288	1.094	1.1317
19	1.358	1.4335	1.3375	1.3957	1.358
20	1.3957	1.3957	1.3375	1.3203	1.3203
21	1.358	1.358	1.2346	1.2826	1.2449
22	1.2449	1.358	1.0288	1.0288	1.1694
23	1.0185	1.0562	.9259	.823	.823
24		.7922	.9054		.7202
Max	1.3957	1.4712	1.8484	1.3957	1.6461
Min	.9808	.679	.7167	.823	.6173
Avg	1.2125	1.0587	1.1065	1.0897	1.0115

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214401 / 33 KV RAJGURUNAGAR

Feeder No / Name : 201 / Dawadi

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4572		.439	.4024
2	.4668	.4572		.439	.4024
3		.4572		.4572	.439
4	.8402	.5304	.6468	.567	.4755
5		.7682		.7316	.7133
6		1.3352		1.2437	1.2437
7		1.701		1.7741	1.6461
8	1.9774	1.9204	2.4209		1.7924
9	1.9547	2.1132		2.2177	
10	2.4253	2.1132			1.8296
11	2.3228	2.0774			
12	2.0157	2.2028	2.4209		
13	1.9105	2.2923			
14	1.9521	2.3529			
15	2.0058	2.3211			
16	2.2325				
17	1.957				
18	1.7375				
19	1.3352				
20	1.134				
21	.9328				
22	.7865	.6468			
23	.5853				
24	1.0349	.4938	.5175	.439	.4938
Max	2.4253	2.3529	2.4209	2.2177	1.8296
Min	.4668	.4572	.5175	.439	.4024
Avg	1.5583	1.4259	1.5015	.9231	.9438

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214401 / 33 KV RAJGURUNAGAR

Feeder No / Name : 202 / Rajgurunagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9774		.7964	1.0136
2	1.0349	.8962		.7783	.905
3		.8507		.8326	.905
4	1.4003	.9955		.9593	.9774
5		1.2127		1.2308	1.1222
6		1.5565		1.6832	1.5746
7		2.009		2.0995	2.0814
8	2.4025	2.1176	2.4025		
9	2.2028	2.0995		2.1068	
10	2.2443	2.1538			2.1807
11	2.2805	2.0058			
12	1.97	2.0271	2.0698		
13	1.9163	2.3529			
14	1.9185	1.8461			
15	1.8099	1.9366			
16	1.8823				
17	2.0633				
18	2.2624				
19	2.1719				
20	2.1719				
21	1.9909				
22	1.647	1.5339			
23	1.2851				
24		1.086	1.0829	1.0136	1.0498
Max	2.4025	2.3529	2.4025	2.1068	2.1807
Min	1.0349	.8507	1.0829	.7783	.905
Avg	1.9253	1.6269	1.8517	1.2778	1.3122



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214401 / 33 KV RAJGURUNAGAR

Feeder No / Name : 203 / Wada

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1097			
2	.0747	.1097			
3		.1097			
4	.0739	.1097			
5		.1463			
6		.1646			
8			.2033		.1097
9				.2218	
10					.2772
23	.0183				
24	.0747	.1097			
Max	.0747	.1646	.2033	.2218	.2772
Min	.0183	.1097	.2033	.2218	.1097
Avg	.0604	.1228	.2033	.2218	.1935

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214401 / 33 KV RAJGURUNAGAR

Feeder No / Name : 204 / Wada GFSS SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1646			
2	.1478	.1646			
3		.1829			
4	.1848	.2561			
5		.2926			
6		.3292			
8			.2218	.3658	.3658
9				.3326	
10					.3696
23	.1646				
24	.1478	.1463			
Max	.1848	.3292	.2218	.3658	.3696
Min	.1478	.1463	.2218	.3326	.3658
Avg	.1613	.2195	.2218	.3492	.3677

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214401 / 33 KV RAJGURUNAGAR

Feeder No / Name : 206 / 11Kv Amul express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2614		.2614	.2614
2	.2587	.2241		.2614	.2801
3		.2241		.2614	.2614
4	.2218	.1867	.1478	.2801	.2614
5		.168		.2614	.2241
6		.168		.2241	.1867
7		.1494		.1867	.168
8	.1848	.1867	.2033	.1867	.1867
9	.3018	.2075		.1848	
10	.3395	.2452			.3142
11	.2641	.3206			
12	.2263	.2452	.2402		
13	.2263	.2829			
14	.2452	.3395			
15	.2263	.2263			
16	.2452				
17	.2241				
18	.2054				
19	.1867				
20	.1524				
21	.1867				
22	.2801	.2054			
23	.2614				
24	.2772	.2614	.2402	.2801	.2801
Max	.3395	.3395	.2402	.2801	.3142
Min	.1524	.1494	.1478	.1848	.168
Avg	.2376	.2296	.2079	.2388	.2424

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214401 / 33 KV RAJGURUNAGAR

Feeder No / Name : 207 / KEDARESHWAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5853		.6767	.695
2	.7023	.5487		.6584	.7316
3		.5487		.6584	.7316
4	1.0164	.6767	.8402	.7865	.823
5		.8962		.9145	1.0059
6		1.2803		1.2254	1.262
7		1.6095		1.6461	1.5912
8	1.8656	1.829	1.7741	1.4266	1.7375
9	1.6461	1.6644		1.386	
10	1.4998	1.6095			1.5181
11	1.4998	1.4815			
12	1.4449	1.3717	1.419		
13	1.2795	1.39			
14	1.3253	1.4118			
15	1.2757	1.3014			
16	1.2127				
17	1.4815				
18	1.6095				
19	1.5364				
20	1.4815				
21	1.5364				
22	1.2803	1.2567			
23	1.0425				
24	.7023	.6584	.7468	.7316	.7316
Max	1.8656	1.829	1.7741	1.6461	1.7375
Min	.7023	.5487	.7468	.6584	.695
Avg	1.3389	1.1835	1.1950	1.0110	1.0828

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214401 / 33 KV RAJGURUNAGAR

Feeder No / Name : 301 / TINEWADI FEEDER

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7316		.7316	.8048
2	.7392	.7316		.7316	.8048
3		.7682		.7316	.8048
4	1.4045	.9877	.924	.9145	.7682
5		1.2071		1.0608	.9877
6		1.4632		1.4998	1.6095
7		2.4508		2.0485	2.1948
8	2.5503	2.7069	3.1047	2.8166	2.7435
9	2.7641	2.6337		3.0308	
10	2.6932	2.8597			2.8829
11	2.4539				
12	2.4539		6.4975		
13	2.5591	2.1719			
14	1.7177	2.2805			
15	2.0553	2.4508			
17	2.3411				
18	2.3411				
19	1.8656				
20	1.4632				
21	1.3169				
22	1.134	1.1088			
23	.8048				
24	.7392	.7682	.7762	.7682	.7682
Max	2.7641	2.8597	6.4975	3.0308	2.8829
Min	.7392	.7316	.7762	.7316	.7682
Avg	1.8554	1.6880	2.8256	1.4334	1.4369

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214401 / 33 KV RAJGURUNAGAR

Feeder No / Name : 302 / 22 KV Allcost & Allied NON SHEDDABLE EXPRESS HV FEEDERS  
 Express Feeder KV- 22 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1431			.9145
2	1.1827	1.1431			.9145
3		1.1812			.9526
4	1.1088	1.1431	.8871		.9145
5		1.1431			.3429
6		1.1812			.8383
7		1.1812			.8383
8	1.0719	1.2193	.7762		.9145
9	1.2574	1.448		.6653	
10	1.2071	1.358			1.1458
11	1.3336	1.1694			
12	1.2574	1.2574	.7095		
13	1.1317	1.2574			
14	1.0669	1.2193			
15	1.0288	1.094			
17	1.0288				
18	1.0288				
19	.9907				
20	.9907				
21	1.0288				
22	.9907	.9979			
23	.9145				
24	1.1458	1.105	1.0349	.7621	.9907
Max	1.3336	1.448	1.0349	.7621	1.1458
Min	.9145	.9979	.7095	.6653	.3429
Avg	1.0981	1.1907	.8519	.7137	.8767

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214438 / 33/11 KV DAWADI SUBSTATION

Feeder No / Name : 201 / 11KV NIMGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5296	.5713	.567	.5481	.4938
2	.4957	.5582	.567	.5676	.5192
3	.5453	.5724	.6048	.5664	.5125
4	.5898	.599	.756	.7167	.6873
5	.8477	.774	1.0395	.9798	.8753
6	1.2007	1.1506	1.4523	1.4465	1.1463
7	1.6565	1.636	1.4886	1.6221	1.8089
8	1.029	1.1424	1.8375	1.7964	1.2035
9		.7446	1.8892	1.6972	.8249
10	.5969	.6055	2.0018	1.7065	.595
11	.629	.6296	1.7401	1.5533	.5956
12	.5127		1.4979	1.3977	.5729
13	.5326		1.5964	1.2285	.4938
14	.5481		1.5389	1.1581	.5084
15		.6653	1.4465	.9822	.5183
16		.8131		.5254	.4923
17		.829	.7786	.5774	1.094
18	1.386	1.0652	.8411	1.0456	1.4204
19	1.5093	1.3096	1.3163	1.3873	1.406
20	1.3859	1.2612	1.2084	1.3915	1.4335
21	1.2198	1.0751	1.0206	.7063	1.1482
22	.9561	.7938	.7757	.5807	.9459
23	.5746	.6054	.6804	.4812	.7378
24	.4896	.5944	.5859	.567	.5194
Max	1.6565	1.636	2.0018	1.7964	1.8089
Min	.4896	.5582	.567	.4812	.4923
Avg	.8617	.8569	1.1839	1.0512	.8564

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214438 / 33/11 KV DAWADI SUBSTATION

Feeder No / Name : 202 / 11KV CHINCHOSHI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1548	.1723	.9348	.8138	.191
2	.1691	.1632	.9547	.816	.2001
3	.2054	.1664	.9511	.8209	.2201
4	.2298	.3006	1.0319	.8546	.2721
5	.322	.2553	1.2039	.9336	.3274
6	.3932	.3898	1.2829	1.1808	.3921
7	.431	.3873	.3822	.3955	.3625
8	1.0877	1.5001	.322	.2899	1.5333
9	1.4661	1.2145	.2324	.2346	1.423
10	1.5261	1.3347	.1624	.108	1.5059
11	1.4117	1.3547	.1411	.1143	1.3771
12	1.4311	1.4103	.1104	.1183	1.5022
13	1.3496	1.2879	.0995		1.4375
14	1.2872	1.3071	.1087		1.3656
15		.7802	.1184	.1095	1.2746
16		.1486		.1216	.0923
17		.1348	.1696	.1664	.1345
18	.2486	.1947	.2107	.2892	.2152
19	.3111	.291	.3099	.3153	.308
20	.3118	.3026	.3024	.2883	.3192
21	.2934	.9362		.2718	.9321
22	.2403	.8986	.9657	.2298	.9419
23	.2022	.9258	.3826	.1912	.9865
24	.1902	.2022	.9348	.7907	.1919
Max	1.5261	1.5001	1.2829	1.1808	1.5333
Min	.1548	.1348	.0995	.108	.0923
Avg	.6315	.6691	.5142	.4297	.7294



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214438 / 33/11 KV DAWADI SUBSTATION

Feeder No / Name : 203 / 11KV WAFGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0107	.3909	.0594	.0833	.08
2	.0143	.3658	.0617	.0796	.0724
3	.088	.3094	.0663	.0745	.0229
4	.0953	.2526	.0914	.0789	.0347
5	.1257	.3094	.0945	.0975	.0514
6	.1448	.3858		.0842	.0892
7	.0777	.1907	.2629	.1858	.088
8	.3549	.2953	.4275	.3544	1.5984
9	.4816	.4715	.4365	.3467	.3189
10	.695	.3772	.583	.3441	.3666
11	.3018	.2778	.6001	.381	.4321
12	.3163	.4062	.3812	.4424	.5194
13		.4382			.3772
14		.4525	.5493		.3086
15	.2408	.5014	.4917	.3778	.4954
16	.6468	.4755	.6201	.4627	.5053
17	.2987	.4961	.4382	.5201	.4001
18	.3403	.2195	.3334	.2841	.3681
19	.1446	.0983	.1383	.1124	.2543
20	.1859	.0587	.1006	.0572	.0332
21	.1943	.0305	.0869	.0427	.009
22	.2923	.0189	.2134	.0823	.0076
23	.3174	.0276	.0914	.0701	.036
24	.1429	.3668	.0594	.0833	.0796
Max	.695	.5014	.6201	.5201	1.5984
Min	.0107	.0189	.0594	.0427	.0076
Avg	.2505	.3007	.2812	.2111	.2729

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214438 / 33/11 KV DAWADI SUBSTATION

Feeder No / Name : 401 / KANESAR INFRA

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9054	.8488	1.5876	1.4146	.8488
2	.8402	.8488	1.701	1.4146	.8488
3	.8488	.8488	1.701	1.4146	.8962
4	1.1317	.9054	1.8144	1.5278	1.2449
5	1.5844	1.1883	1.9845	1.6409	1.4146
6	1.7541	1.6975	2.0979	2.037	1.6975
7	.9619	1.0185	.9639	.9054	.9619
8	3.0247	3.1687	2.1546	2.4331	2.7166
9	3.5082	.1134	2.268	2.1502	3.2885
10	3.678	.1134	2.0936	2.0165	.1701
11	3.4517	.1134	1.9805	1.9605	3.005
12	3.2819	3.7988	2.0936	1.7364	3.2318
13	3.3951	2.4947	1.8673	1.7541	3.005
14	3.5082	3.6287	1.7541	1.1203	2.7782
15	2.7726	3.3452	1.6975	1.5844	2.4947
16	.6224	2.7215	.5658	.5601	.1134
17	.7922	.4536	.6224	.6224	.567
18	.9054	.8505	.7356	.7922	.7371
19	.9054	.9639	.9054	.8488	.9072
20	.7922	.8505	.8488	.7922	.8505
21	.7356	1.134	1.2449	1.1317	1.8144
22	.6224	1.4175	1.6409	1.0185	1.8144
23	.9054	1.4742	1.5844	.9054	1.9278
24	.8488	.9054	1.5876	1.4146	.9054
Max	3.678	3.7988	2.268	2.4331	3.2885
Min	.6224	.1134	.5658	.5601	.1134
Avg	1.7407	1.4543	1.5623	1.3832	1.5933

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214447 / 33/11 KV WADA SUBSTATION

Feeder No / Name : 201 / 11KV WADA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3326	.3475	.3439	.3658	.3292
2	.3326	.3658	.3439	.3658	.3292
3	.3511	.3658	.3258	.3658	.3292
4	.3696	.3475	.3475	.3841	.3475
5	.4435	.439	.439	.4755	.4024
6	.6653	.695	.5853	.6219	.6584
7	.8215	.8686	.9526	.823	.8402
8	.8316	.8775	.8686	.7655	.8589
9	.7682	.7362	.7207	.9808	.9391
10	.8676	.8669	.5281	.9997	.8859
11	.9335	.8573	.4527	.8962	.7796
12	.9717	.8059	.3547	.9242	.8682
13	.9717	.8402	.3547	.7655	.8328
14	.9526	.7716	.3511	.8488	.7619
15	.9054	.6036	.3077	.7655	.7265
16		.4294	.3841	.3361	.2303
17	.5316	.4668	.3721	.3734	.3547
18	.6556	.5601	.5493	.5847	.5788
19	.815	.9619	.8596	.8682	.9242
20	.8328	.8505	.8328	.7973	.8764
21	.7265	.4607	.7442	.7442	.5792
22	.5493	.4252	.567	.5493	.5121
23	.4024	.362	.4294	.4024	.4572
24	.3547	.3658	.3439	.3921	.3511
Max	.9717	.9619	.9526	.9997	.9391
Min	.3326	.3475	.3077	.3361	.2303
Avg	.6690	.6113	.5149	.6415	.6147

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214447 / 33/11 KV WADA SUBSTATION

Feeder No / Name : 202 / 11KV BHORGIRI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6838	.6036	.8326	.5853	.5853
2	.6838	.6219	.8145	.6036	.5853
3	.7023	.6219	.7964	.6036	.5853
4	.7392	.6584	.7964	.5853	.695
5	.7947	.7865	.8962		.695
6	.924	1.0059	.8345	.8779	.9328
7	1.6991	1.7002	1.8099	1.6827	1.7924
8	1.4969	1.5497	1.46	1.5684	1.531
9	1.2254	1.1218	1.6817	1.3769	1.2851
10	.8865	.9536	1.8484	1.094	1.0679
11	.6859	.8916	1.7918	.9896	.9955
12	.6859	.8916	1.7924	.811	.7602
13	.381	.7888	1.7551	.6722	.823
14	.2667	.7202	1.7926	.7167	.7133
15	.8865	.8215	1.1946	.7282	.8048
16	.6962	.8589	.823	.8029	.8326
17	.9774	.9522	.9412	.9335	.9149
18	1.4118	1.363	1.3575	1.3937	1.2696
19	2.0271	2.1313	1.9366	2.009	2.0748
20	1.9387	1.9366	1.9004	1.9547	1.9814
21	1.7194	1.7741	.905	.8688	1.6651
22	1.3213	1.3394	.7602	.7783	1.2437
23	.6401	.9593	.7095	.695	.9328
24	.6722	.6584	.8688	.6348	.6099
Max	2.0271	2.1313	1.9366	2.009	2.0748
Min	.2667	.6036	.7095	.5853	.5853
Avg	1.0061	1.0713	1.2625	.9985	1.0574

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214447 / 33/11 KV WADA SUBSTATION

Feeder No / Name : 203 / Kadadhe SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3696	.9511	.6878	.3658	.3841
2	.3511	.9694	.7059	.3841	.3658
3	.3881	1.0059	.7059	.3841	.3658
4	.4251	1.0059	.7421	.4207	.4024
5	.5359	1.1157	.8413	.5304	.5121
6	.8131	1.3535	1.0425	.823	.8962
7	.8686	.9795	.9717	1.0059	1.0269
8	1.5154	.7282	.7392	1.5123	1.5684
9	1.0791	.4733	.5175	1.6975	1.4217
10	1.4712	.4161	.4338	1.6221	1.5777
11	1.5432	.3772	.3584	1.4563	1.262
12	1.5813	.3086	.3174	1.6409	1.439
13	1.5051	.3086	.3547	1.1763	1.439
14	1.7528	.3258	.3511	1.5089	1.3672
15	1.4712	.3353	.3439	1.363	1.262
16	.2818	.4108	.3841	.3734	.3012
17	.4031	.4294	.3982	.4294	.4294
18	.5493	.6908	.5601	.6379	.5788
19	.9242	.9431	.8676	.8686	.9242
20	.788	.9149	.8488	.8488	.8192
21	.7087	.7442	.7343	.7265	.8688
22	.567	.7973	.5316	.5847	.8596
23	.8596	.7964	.4294	.439	.8413
24	.3734	.9328	.7602	.3734	.4251
Max	1.7528	1.3535	1.0425	1.6975	1.5777
Min	.2818	.3086	.3174	.3658	.3012
Avg	.8802	.7214	.6095	.8822	.8891

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214447 / 33/11 KV WADA SUBSTATION

Feeder No / Name : 204 / 11 KV Sahyadri/Amar Prerna

Exp Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.037	.0549	.0362	.0366	.0366
2	.037	.0366	.0362	.0366	.0366
3	.037	.0366	.0362	.0366	.0366
4	.037	.0366	.0362	.0366	.0366
5	.0554	.0366	.0366	.0366	.0366
6	.0739	.0732	.0732	.0549	.0366
7	.0934	.0739	.0762	.0732	.0747
8	.0739	.0747	.0554	.0747	.0747
9	.0549	.0526	.0739	.0566	.036
10	.0566	.052	.0189	.0566	.0354
11	.0572	.0514	.0566	.056	.0274
12	.0381	.0514	.056	.0566	.0389
13	.0381	.0514	.056	.056	.0474
14	.0381	.0514	.0554	.0566	.0434
15	.0566	.0503	.0543	.056	.0549
16	.0332	.0747	.0366	.056	.0503
17	.0701	.0747	.0236	.0747	.0747
18	.0671	.0747	.0309	.0747	.0747
19	.0724	.0754	.0678	.0709	.0754
20	.0701	.0602	.0701	.0895	.0572
21	.0383	.0625	.0394	.0457	.0724
22	.0354	.0412	.0274	.0452	.0549
23	.0549	.0724	.0373	.0549	.0549
24	.0373	.0549	.0543	.0373	.0554
Max	.0934	.0754	.0762	.0895	.0754
Min	.0332	.0366	.0189	.0366	.0274
Avg	.0526	.0573	.0477	.0554	.0509

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214507 / 33/11 KV KANERSAR INFRA

Feeder No / Name : 201 / KANERSAR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4075	.4031	.2614	.2587	.4207
2	.3856	.3856	.2614	.2587	.4207
3	.4115	.4382	.3142	.2957	.463
4	.463	.4973	.4207	.3292	.5487
5	.5487	.6344	.5487	.4024	.6687
6	.823	.7373	.6767	.6878	.7545
7	.8029	.7655	.7783	.7164	.7655
8	.7282	.6535	1.2003	1.2174	.6535
9	.5975	.5228	1.2174	1.3032	.5415
10	.5041	.3734	1.2346	1.2003	.4481
11	.3921	.3801	1.2174	1.1317	.3734
12	.3734	.3403	1.3203	1.0288	.3077
13	.3174	.4525	1.1831	.9945	.362
14	.3361	.3982	.9945	.9259	.3475
15	.3547	.3658	.9259	.8402	.3292
16	.3547	.3801	.3841		
17	.3734	.3658	.3475	.3921	.3109
18	.4854	.5304	.5121	.4668	.4572
19	.7095	.6036	.6219	.6161	.6401
20	.5601	.5487	.6036	.5788	.5853
21	.5228	.4805	.4938	.3988	.4755
22	.4108	.3881	.4251	.4161	.4066
23	.4075	.3547	.2957	.3856	.3142
24	.394	.4252	.2614	.2587	.4031
Max	.823	.7655	1.3203	1.3032	.7655
Min	.3174	.3403	.2614	.2587	.3077
Avg	.4860	.4760	.6875	.6567	.4782

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214507 / 33/11 KV KANERSAR INFRA

Feeder No / Name : 202 / VARUDE SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.4294	1.3375	1.2003	.4108
2	.4294	.4294	1.286	1.2003	.3921
3	.4668	.4481	1.286	1.2003	.4294
4	.5601	.5415	1.3717	1.2517	.4854
5	.7095	.6908	1.4746	1.2517	.6161
6	.7468	.8029	1.6118	1.5261	.7842
7	.8775	.8589	.8145	.788	.8589
8	2.5034	2.8292	.8238	.724	2.4006
9	2.8464		.724	.5792	2.7949
10	2.915		.6268	.4887	
11	2.8635		.5792	.4854	2.6235
12	2.9835	3.1539	.5853	.4668	2.6749
13	2.8978		.5611	.5041	2.6063
14	3.0521	3.0864	.5121	.4854	2.4006
15	2.572	2.7435	.5121	.4481	2.2462
16	.5788	2.572	.5304	.5041	.4207
17	.6722	2.332	.5121	.5601	.4024
18	.7842	.6767	.6584	.6908	.5853
19	.8029	.7865	.8048	.8029	.7682
20	.7468	.7499	.7316	.6908	.7316
21	.6908	.9088	1.0288	.6348	1.2689
22	.5788	1.2174	1.3717	.5415	1.6461
23	.4481	1.2003	1.3375	.4481	1.5604
24	.3921	.4294	1.2003	1.3375	.3921
Max	3.0521	3.1539	1.6118	1.5261	2.7949
Min	.3921	.4294	.5121	.4481	.3921
Avg	1.3554	1.3444	.9284	.7838	1.2826



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214507 / 33/11 KV KANERSAR INFRA

Feeder No / Name : 203 / PUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0373	.0693	.0693	.0373
2	.0373	.0373	.0686	.0867	.056
3	.0373	.0373	.0686	.0857	.056
4	.056	.056	.0857	.1029	.0747
5	.0747	.0934	.1029	.12	.0934
6	.0934	.112	.1372	.1715	.112
7	.112	.112	.1075	.1097	.112
8	.1991	.181	.0905	.1086	.1267
9	.181	.1448	.0724	.0914	.1448
10	.1629	.181	.0724	.0732	.1928
11	.1928	.1715	.0549	.0747	.2172
12	.1753	.1543	.037	.0747	.1715
13	.1402	.12	.0549	.056	.1715
14	.1578	.1372	.037	.056	.1372
15	.1402	.1372	.037	.056	.1543
16	.056	.0549	.0554	.056	.0554
17	.056	.0554	.0185	.056	.0739
18	.0747	.0739	.0554	.0747	.0924
19	.0934	.0924	.1109	.112	.0924
20	.0747	.0739	.0924	.112	.0924
21	.0747	.0701	.1052	.0934	.12
22	.056	.0701	.0867	.056	.12
23	.0373	.0693	.0867	.056	.0857
24	.0373	.0373	.0693	.0867	.056
Max	.1991	.181	.1372	.1715	.2172
Min	.0373	.0373	.0185	.056	.0373
Avg	.0982	.0962	.0740	.0850	.1102

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214508 / 33/11 KV KANERSAR SEZ

Feeder No / Name : 201 / 9 PLANETS

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.5658	.4338	.5228	.4715
2	.3174	.547	.4338	.5415	.4715
3	.3174	.547	.415	.5601	.4715
4	.3361	.5281	.415	.5041	.4715
5	.2987	.5093	.415	.4854	.4527
6	.2801	.4904	.3961	.4294	.415
7	.2054	.4527	.3206	.4108	.415
8	.3734	.3961	.547	.4668	.4338
9	.3961	.5281	.6161	.4338	.4108
10	.4527	.6036	.6348	.5093	.5601
11	.4338	.547	.5228	.547	.4294
12	.4904	.5281	.5041	.4904	.4481
13	.6036	.6602	.5415	.5093	.5601
14	.6413	.6224	.4854	.4904	.5415
15	.6413	.7356	.5041	.6413	.4294
16	.679	.7167	.5415	.5847	.3921
17	.7167	.6535	.5788	.5281	.3734
18	.7545	.547	.5228	.5281	.4294
19	.7167	.5281	.4294	.547	.3547
20	.7167	.5093	.5601	.5281	.5041
21	.679	.4338	.5415	.4715	.5975
22	.679	.415	.5228	.4715	.5601
23	.6413	.415	.5601	.4715	.5601
24	.3361	.6036	.4338	.5601	.4715
Max	.7545	.7356	.6348	.6413	.5975
Min	.2054	.3961	.3206	.4108	.3547
Avg	.5018	.5451	.4948	.5097	.4677

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214508 / 33/11 KV KANERSAR SEZ

Feeder No / Name : 202 / NUMEN

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.4854	.3961	.1905	.3772
2	.2858	.4481	.4001	.1715	.4001
3	.2667	.4108	.381	.2096	.4001
4	.2286	.4108	.381	.1905	.3772
5	.2096	.4344	.3048	.1715	.3429
6	.2096	.4481	.2829	.1905	.381
7	.3048	.3547	.1132	.2858	.3772
8	.2477	.4338	.2452	.3048	.3395
9	.5228	.4527	.2858	.4294	.4763
10	.7095	.6413	.3048	.4527	.4763
11	.5975	.381	.2477	.4338	.6668
12	.5601	.5525	.3048	.5658	.5716
13	.5228	.4763	.1715	.4715	.5906
14	.5601	.415	.2286	.3772	.5716
15	.5975	.5281	.2858	.5093	.6097
16	.6348	.5658	.1905	.547	.5716
17	.6348	.5093	.2096	.4338	.5716
18	.7468	.5658	.2096	.6413	.5906
19	.5975	.6224	.1524	.4715	.6668
20	.5788	.3584	.1905	.415	.4572
21	.5601	.5281	.2096	.5281	.4954
22	.5601	.5281	.2286	.5281	.5144
23	.5415	.415	.2477	.3395	.5335
24	.3429	.5228	.4382	.2286	.3772
Max	.7468	.6413	.4382	.6413	.6668
Min	.2096	.3547	.1132	.1715	.3395
Avg	.4719	.4787	.2671	.3786	.4890

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214509 / 33/11 KV NIMGAON SEZ

Feeder No / Name : 201 / RAJ PROCESS

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1698	.2263	.112	.1698
2	.1698	.1698	.2263	.112	.1698
3	.1698	.1698	.1698	.112	.1698
4	.1698	.1698	.1698	.0934	.1509
5	.132	.1509	.1698	.0934	.1509
6	.132	.1509	.1132	.112	.1509
7	.132	.1132	.1132	.0934	.132
8	.132	.132	.1132	.1307	.1509
9	.2263		.1132	.2614	.3018
10	.2263	.1698	.3395	.2427	.2452
11	.2641	.3206	.1867	.2641	.2452
12	.2452	.3206	.1867	.2829	.2427
13	.1698	.3206	.1494	.2452	.2452
14	.5093	.3206	.1494	.2641	.2427
15	.3395	.3206	.0934	.2829	.2801
16	.4715	.3206	.2614	.2829	.2987
17	.3584	.3206	.2054	.2641	.2614
18	.3584	.3206	.2054	.2641	.2614
19	.3018	.3206	.2241	.2452	.2614
20	.2829	.2641	.1867	.2263	.2614
21	.2829	.2641	.1494	.2075	.2614
22	.2829	.2641	.1307	.1886	.2263
23	.2075	.2263	.1307	.1886	
24	.1698	.1698	.2263	.112	.1698
Max	.5093	.3206	.3395	.2829	.3018
Min	.132	.1132	.0934	.0934	.132
Avg	.2460	.2378	.1767	.1951	.2196

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214509 / 33/11 KV NIMGAON SEZ

Feeder No / Name : 401 / NIMGAON SEZ - KANERSAR SEZ NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / OUTGOING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	.8488	.7922	.6161	1.0751
2	1.1317	.7922	.7922	.6722	1.0751
3	1.1317	.7356	.7922	.6722	1.0751
4	1.1317	.7356	.7356	.7282	1.0751
5	1.0185	.7356	.7356	.8402	1.0185
6	1.0185	.7356	.7356	.8402	1.0185
7	1.0185	.7356	.7356	.8962	1.1317
8	1.0185	.7356	.679	1.0185	1.1317
9	1.1883		.7356	1.1883	1.3014
10	1.1883	.8488	.9619	1.1883	1.1883
11	1.1883	.679	.7842	1.3014	
12	1.1317	.679	.7842	1.2449	1.1883
13	.679	.9054	.6722	1.1317	1.1763
14	1.3014	.9054	.7282	1.2449	1.1883
15	1.0751	.9054	.6722	1.1883	1.2449
16	1.2449	.9054	.8488	1.1883	1.3014
17	1.1317	.9054	.7842	1.1317	1.2449
18	1.0751	.9054	.6722	1.1883	1.2449
19	1.0185	.8488	.7842	1.1883	1.1883
20	.9619	.8488	.7282	1.1317	1.1883
21	.9619	.8488	.7842	1.1883	1.1883
22	.9054	.8488	.6722	1.1883	1.1883
23	.9054	.7922	.6722	1.1883	
24	1.1317	.8488	.7922	.6161	1.1317
Max	1.3014	.9054	.9619	1.3014	1.3014
Min	.679	.679	.6722	.6161	1.0185
Avg	1.0704	.8143	.7531	1.0325	1.1620

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214509 / 33/11 KV NIMGAON SEZ

Feeder No / Name : 402 / Mars India Ltd

Feeder KV- 33 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0185	.5093	.5658	.5041	1.0185
2	1.0185	.5093	.5658	.5041	1.0185
3	1.0185	.5093	.5658	.5041	.9619
4	1.0185	.5093	.5658	.5601	.9619
5	.8488	.5093	.5658	.5601	.9054
6	.8488	.5658	.5093	.6722	.9054
7	.8488	.5658	.5093	.7842	.9054
8	.8488	.5658	.5093	.8488	.9619
9	.9054		.5658	.8488	.9054
10	.9054	.6224	.5658	.9054	.9619
11	.9619	.6224	.5601	.9054	.7922
12	.9054	.6224	.5601	.9054	.7356
13	.4527	.6224	.5601	.9054	.7356
14	.7922	.6224	.6161	.9619	.8488
15	.7356	.6224	.5601	.9054	.9054
16	.7922	.5658	.5601	.9054	.9054
17	.679	.5658	.5601	.8488	.9054
18	.679	.5658	.5041	.9054	.9054
19	.679	.5658	.5601	.9054	.9054
20	.6224	.5093	.5601	.9054	.9054
21	.6224	.5093	.5601	1.0185	.9054
22	.6224	.5093	.5041	1.0185	.9054
23	.5658	.5658	.5041	1.0185	
24	1.0185	.5658	.5658	.5041	1.0185
Max	1.0185	.6224	.6161	1.0185	1.0185
Min	.4527	.5093	.5041	.5041	.7356
Avg	.8087	.5609	.5510	.8044	.9078

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

TALEGAON[061]

BU 0892

Substation No/ Name :- 213314 / 22 KV AMBI

Feeder No / Name : 303 / General Motors

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17	13-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.1152	4.7325	3.8409	1.9204	5.0069	5.3498
2	4.1838	4.3896	3.7723	1.7833	4.8011	
3	4.321	4.4582	3.9095	1.6461	4.6639	
4	4.4582	4.5268	3.9781	1.7833	4.6639	
5	4.6639	4.5268	3.7037	1.9204	4.5268	
6	4.1152	3.4294	2.332		3.7723	
7	4.8697	4.1838	2.6749	4.3896	5.2812	
8	6.1043	5.487	4.1152	5.8299	6.4472	4.8011
9	7.4074	6.1728	7.7504	7.5446	5.8299	
10	6.8587	7.2017	4.1152	6.31	6.8587	
11	7.8875	7.6818	4.2524	7.476	7.2017	
12	7.3731	6.1728	4.1152	8.9163	7.2017	
13	6.7215	7.6818	3.9781	8.2305	7.8875	
14	6.7215	7.8189	4.1152	7.0645	6.1728	
15	7.2017	7.2702	3.4294	7.3388	6.8587	
16	7.6818	7.6475	3.4294	7.2702		
17	8.0247	7.8875		8.2305		
18	6.7215	7.2702	3.155	6.5844		
19	5.8299	6.8587	3.0178	6.1043		
20	5.8985	5.8299	2.7435	5.4184		
21	7.2017	6.3786	2.8807	5.487		
22	6.2414	4.8011	2.7435	5.6927		
23	5.6242	3.9781	2.4691	6.4472		
24	3.7037	4.8011	4.0466	2.0576	5.4184	5.0069
Max	8.0247	7.8875	7.7504	8.9163	7.8875	5.3498
Min	3.7037	3.4294	2.332	1.6461	3.7723	4.8011
Avg	5.9971	5.8828	3.6769	5.4542	5.7870	5.0526

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

TALEGAON[061]

BU 0892

Substation No/ Name :- 213314 / 22 KV AMBI

Feeder No / Name : 304 / 22 KV MANAS EXPRESS FEEDER NON SHEDDABLE EXPRESS HV FEEDERS  
 (01 Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17	13-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.583	.3429	.2058	.5487	
2	.5487	.6516	.3429	.2058	.5144	
3	.583	.583	.3086	.1715	.4801	
4	.5144	.4801	.3086	.1715	.4801	
5	.4801	.4458	.2743	.1715	.5144	
6	.3429	.3772	.2743	.1715	.4115	
7	.5144	.3429	.2058	.1715	.3772	
8	.6173	.3772	.2058	.4801	.4458	.5487
9	.6516	.4458	.2058	.6859	.6173	
10	.7202	.3429	.1372	.823	.7888	
11	.7888	.5144	.1372	.7545	.823	
12	.583	.4801	.1029	.6859	.6859	
13	.6173	.3429	.1029	.6859	.6516	
14	.6516	.3772	.1029	.6859	.7888	
15	.7545	.4458	.1029	.7202		
16	.7202	.4458	.1029	.823		
17	.6859	.4115	.0686	.7888		
18	.6173	.3429	.0686	.7888		
19	.4458	.3772	.0686	.4801		
20	.583	.3429	.0686	.5144		
21	.5487	.4115	.0686	.583		
22	.583	.4458	.2401	.6173		
23	.5487	.3429	.3772	.583		
24	.583	.5487	.3772	.2401	.6173	.5487
Max	.7888	.6516	.3772	.823	.823	.5487
Min	.3429	.3429	.0686	.1715	.3772	.5487
Avg	.5930	.4358	.1915	.5087	.5830	.5487



### Feederwise Load Information for **All Feeders**

Feeder No / Name : 306 / 22 KV Nigade Feeder ( Old Shri Feeder KV- 22 / OUTGOING	SHEDDABLE FEEDER HAVING WEEKLY STAGGERING (MIDC, EQUIVALENT)
--	--

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17	13-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.4458	.3772	.2743	.3772	
2	.3086	.4458	.4115	.2743	.3429	
3	.3429	.4458	.4458	.2743	.3429	
4	.3772	.4801	.4458	.3086	.3772	
5	.4115	.5487	.4801	.4115	.4115	
6	.4115	.583	.5487	.4801	.583	
7	.5144	.6516	.6516	.5487	.6859	
8	.583	.6859	.7888	.5487	.5487	
9	.8573	.823	.7888	.6859	.6173	
10	.7545	.7545	.7545	.6859	.6859	
11	.7888	.7545		.6859	.6859	
12	.823	.7202	.7545	.7545	.5487	
13	.7888	.7545	.6859	.6516	.6173	
14	.6859	.7545	.6173	.6173	.583	
15	.823	.823	.5487	.6173		
16	.823	.823	.6173	.6859		
17	.7202	.7888	.5487	.6516		
18	.7202	.7888	.5487	.7202		
19	.6859	.7202	.5487	.6173		
20		.6516	.4801	.5487		
21	.6173	.583	.4115	.5144		
22	.5487	.5144	.4115	.4458		
23	.4801	.4115	.3429	.3772		
24	.2743	.4801	.4115	.2743	.3772	.5487
Max	.8573	.823	.7888	.7545	.6859	.5487
Min	.2743	.4115	.3429	.2743	.3429	.5487
Avg	.5949	.6430	.5487	.5273	.5190	.5487

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

WADGAON MAVAL S/DN.[769] BU 4769

Substation No/ Name :- 213344 / 22/22 KV FINOLEX S/STN

Feeder No / Name : 301 / 22 KV Finolex Pipes

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.21	2.3624	2.21	2.21	2.3624
2	2.0576	2.4006	2.1719	2.1338	2.553
3	1.9814	2.3624	2.2481	2.1719	2.21
4	1.9814	2.2862	2.0576	2.0576	2.3243
5	1.9052	2.2481	2.0957	2.0576	2.553
6	1.9814	1.7528	1.9052	1.9814	1.7909
7	1.9814	1.6766	1.7147	1.7909	1.7147
8	2.1338	2.1338	1.8671	2.2481	2.0576
9	2.21	2.4387	2.0576	2.3243	2.5149
10	2.21	2.2862	2.21	2.2862	2.2481
11	2.3624	2.2862	2.3624	2.7054	2.3243
12	2.1719	2.0576	2.1338	2.3624	2.21
13	2.1719	2.1338	1.9052	2.2481	2.2862
14	2.21	2.1719	2.0576	2.4387	2.3624
15	1.9433	2.21	2.21	1.829	1.6766
16	2.2862	2.3243	2.3624	2.2862	2.3624
17	2.3243	2.1719	2.2862	2.4387	2.2862
18	2.21	2.0576	2.2481	2.2481	2.2862
19	2.3624	2.1719	2.4006	2.553	2.21
20	2.4006	2.21	2.2862	2.3243	2.1719
21	2.4006	2.2481	2.21	2.3243	2.21
22	2.3624	2.2481	2.0576	2.4387	2.0576
23	1.7528	2.21	1.7528	1.7909	1.9052
24	2.2481	2.3624	2.2481	2.2862	2.3624
Max	2.4006	2.4387	2.4006	2.7054	2.553
Min	1.7528	1.6766	1.7147	1.7909	1.6766
Avg	2.1608	2.2005	2.1275	2.2307	2.2100

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

WADGAON MAVAL S/DN.[769] BU 4769

Substation No/ Name :- 213344 / 22/22 KV FINOLEX S/STN

Feeder No / Name : 302 / 22 KV Finolex Passion NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193	1.3336	1.1431	1.3336	1.3336
2	1.2574	1.3717	1.2193	1.2955	1.3717
3	1.2574	1.3717	1.1812	1.2955	1.3336
4	1.2955	1.3717	1.2193	1.3336	1.3336
5	1.2955	1.3717	1.2574	1.3336	1.3336
6	1.2955	1.2574	1.2193	1.3336	1.3717
7	1.3336	1.2955	1.1431	1.3336	1.3336
8	1.2574	1.1431	1.2193	1.3336	1.2955
9	1.105	1.3336	1.2574	1.4098	1.3336
10	1.1431	1.3336	1.2955	1.3336	1.3336
11	1.3336	1.3717	1.2574	1.2955	1.3717
12	1.2574	1.2955	1.2574	1.1812	1.3717
13	1.1812	1.3336	1.2574	1.2955	1.4098
14	1.1431	1.2955	1.2574	1.2955	1.4098
15	1.2955	1.2574	1.1812	1.2574	1.105
16	1.3717	1.1812	1.1812	1.3717	1.2193
17	1.3717	1.2193	1.2193	1.3717	1.2955
18	1.2955	1.2955	1.1812	1.3336	1.3336
19	1.3717	1.2574	1.2574	1.4098	1.3717
20	1.4098	1.3336	1.2574	1.3336	1.3717
21	1.3717	1.2955	1.2955	1.4098	1.3336
22	1.3717	1.2955	1.2955	1.4098	1.3717
23	1.3717	1.3336	1.3336	1.3336	1.3336
24	1.2193	1.2955	1.105	1.3336	1.3336
Max	1.4098	1.3717	1.3336	1.4098	1.4098
Min	1.105	1.1431	1.105	1.1812	1.105
Avg	1.2844	1.3019	1.2288	1.3320	1.3336

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

WADGAON MAVAL S/DN.[769] BU 4769

Substation No/ Name :- 213344 / 22/22 KV FINOLEX S/STN

Feeder No / Name : 303 / 22 Kv Finolex Cable

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 22 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.21	2.3243	2.2862	2.2862	2.3243
2	2.0576	2.4387	2.21	2.3624	2.3243
3	2.0576	2.3243	2.1719	2.2862	2.1719
4	1.9814	2.2481	2.21	2.21	2.2862
5	1.9052	2.0957	2.0195	2.1338	2.0576
6	1.9814	2.0195	1.9052	2.1338	2.0576
7	2.0195	1.8671	1.7909	2.0576	2.0576
8	1.829	1.6004	1.5242	1.829	1.6004
9	1.5242	1.6766	1.3336	1.5242	1.3336
10	1.4098	1.0669	.9145	1.448	1.2955
11	1.1812	1.105	.8002	1.0669	.8002
12	.9526	1.2955	.6859	.8764	.6859
13	.724	1.3336	.4191	.5335	.5335
14	.9145	1.1431	.6859	1.8671	.6859
15	.9145	1.2193	.8002	.8383	.9145
16	1.6385	1.3717	1.3717	1.7147	1.7528
17	2.2481	1.829	1.6004	2.0957	2.1338
18	2.5911	2.0576	1.829	2.5149	2.2862
19	2.7054	2.21	1.9814	2.553	2.553
20	2.5911	2.2862	2.0576	2.5911	2.553
21	2.3624	2.2862	2.2862	2.3624	2.4387
22	2.2481	2.2481	2.21	2.553	2.1338
23	1.9433	2.1719	2.1338	2.0195	1.9052
24	2.3243	2.5149	2.2481	2.21	2.4387
Max	2.7054	2.5149	2.2862	2.5911	2.553
Min	.724	1.0669	.4191	.5335	.5335
Avg	1.8465	1.8639	1.6448	1.9195	1.8052

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

WADGAON MAVAL S/DN.[769] BU 4769

Substation No/ Name :- 213387 / Belaz Switching S/s.

Feeder No / Name : 302 / RAJAPURI

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.1905	.2241	.2263	.2263
2	.2241	.1905	.2241	.2263	.2263
3	.2263	.2286	.3361	.2263	.2263
4	.2263	.2667	.2241	.3395	.2641
5	.2641	.3429	.2614	.2641	.3018
6	.2641	.4191	.2614	.3395	.3772
7	.3018	.4191	.2614	.4527	.4527
8	.3772	.4954	.2614	.4904	.415
9	.3772	.4954	.2614	.4904	.4527
10	.3361	.4954	.4108	.5281	.415
11	.3734	.5335	.4481	.5281	.4527
12	.3361	.4572	.4481	.4904	.415
13	.3772	.381	.4527	.4527	.4527
14		.4572	.415	.415	.4904
15		.4954	.5281	.4527	.4527
16		.4954	.5228	.3395	.3395
17	.4191	.4904	.4904	.3772	
18	.4191	.4481	.4527	.415	
19	.381	.4481	.3772	.415	
20	.3429	.415	.3772	.3772	
21	.3429	.4481	.3395	.3395	
22	.2667	.2987	.3018	.3018	
23	.2667	.2641	.2641	.2641	
24	.2263	.2286	.3734	.3018	.2641
Max	.4191	.5335	.5281	.5281	.4904
Min	.2241	.1905	.2241	.2263	.2263
Avg	.3131	.3919	.3549	.3772	.3661

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

WADGAON MAVAL S/DN.[769] BU 4769

Substation No/ Name :- 218051 / 220 KV URSE

Feeder No / Name : 302 / TATA MOTORS

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	2.4006	7.8494	7.9637	7.5446	5.6394
Max	2.4006	7.8494	7.9637	7.5446	5.6394
Min	2.4006	7.8494	7.9637	7.5446	5.6394
Avg	2.4006	7.8494	7.9637	7.5446	5.6394

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

WADGAON MAVAL S/DN.[769] BU 4769

Substation No/ Name :- 218051 / 220 KV URSE

Feeder No / Name : 303 / URSE

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			6.8968		
24	3.9247	7.0492		6.973	7.2017
Max	3.9247	7.0492	6.8968	6.973	7.2017
Min	3.9247	7.0492	6.8968	6.973	7.2017
Avg	3.9247	7.0492	6.8968	6.973	7.2017

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

WADGAON MAVAL S/DN.[769] BU 4769

Substation No/ Name :- 218051 / 220 KV URSE

Feeder No / Name : 304 / Pawananagar

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	1.1812	1.2193	1.3336	1.2193	1.2193
Max	1.1812	1.2193	1.3336	1.2193	1.2193
Min	1.1812	1.2193	1.3336	1.2193	1.2193
Avg	1.1812	1.2193	1.3336	1.2193	1.2193



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

WADGAON MAVAL S/DN.[769] BU 4769

Substation No/ Name :- 218051 / 220 KV URSE

Feeder No / Name : 306 / Lamontana

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.1524	.1524	.1524	.1524	.1524
Max	.1524	.1524	.1524	.1524	.1524
Min	.1524	.1524	.1524	.1524	.1524
Avg	.1524	.1524	.1524	.1524	.1524

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

WADGAON MAVAL S/DN.[769] BU 4769

Substation No/ Name :- 218051 / 220 KV URSE

Feeder No / Name : 801 / 220 KV EHV Mahindra  
Hinoday Fe Feeder KV- 220 /  
OUTGOINGNON SHEDDABLE EHV INDUSTRIAL FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	8.7639	13.7174	11.0502	1.1431	13.7174
Max	8.7639	13.7174	11.0502	1.1431	13.7174
Min	8.7639	13.7174	11.0502	1.1431	13.7174
Avg	8.7639	13.7174	11.0502	1.1431	13.7174