

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113015 / LOKPRIYA

Feeder No / Name : 201 / RACHANA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2715	.3658	.2715	.2715	.2926	.3258	.2715
2	.2715	.3258	.2715	.2715	.2743	.3258	.2715
3	.2715	.3258	.2715	.2715	.2561	.2743	.2715
4	.362	.2715	.2715	.2715	.2561	.2715	.2715
5	.362	.2715	.2715	.2715	.2926	.2715	.2715
6	.362	.2715	.2715	.2715	.2926	.362	.3077
7	.4525	.362	.3439	.3077	.3658	.362	.362
8	.4525	.3982	.362	.3825	.4207	.4525	.4344
9	.4525	.4163	.3982	.3982	.362	.4525	.4163
10	.362	.4525	.362	.3801	.362	.362	.362
11	.3077		.3439	.3475	.362	.3439	
12	.3258	.3258	.3439	.3109	.3077	.2896	.2534
13	.3077		.3258	.2926	.2896	.2896	.2353
14	.2715	.2896	.2715	.2743	.2715	.2534	.2561
15	.2172	.2353	.2534	.2378	.2353	.2534	.2353
16	.2172	.2353	.2534	.2743	.2353	.2353	.2353
17	.2715	.2534	.2715	.2743	.2353	.2715	.2715
18	.3077	.3258	.3258	.2926	.362	.3096	.2896
19	.3982	.4344	.4344	.3841	.4525	.4163	.3982
20	.4525	.4344	.4344	.4207	.4525	.4525	.4344
21	.4525	.4344	.4344	.3841	.4525	.4344	.4344
22	.3982	.362	.4163	.3658	.4525	.3982	.3982
23	.362	.3439	.3439	.3475	.362	.3801	.362
24	.3258	.362	.3077	.3077	.3292	.362	.3077
Max	.4525	.4525	.4344	.4207	.4525	.4525	.4344
Min	.2172	.2353	.2534	.2378	.2353	.2353	.2353
Avg	.3431	.3408	.3273	.3172	.3323	.3396	.3196

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113015 / LOKPRIYA

Feeder No / Name : 202 / UDAYSHREE FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.086	1.086	.9774	.8688	1.0425	1.086	.9774
2	1.086	1.0059	.9412	.8688	1.0059	.9955	.9774
3	.9955	.9955	.9412	.8779	.9511	.9955	.9774
4	.9955	.905	.905	.8688	1.0242	.905	.9774
5	.905	.905	.905	.8688	1.0608	.905	.9774
6	.905	.905	.905	.8688	1.0974	.9955	.9774
7	1.086	1.086	.9593	.905	1.134	1.086	1.0679
8	1.1765	1.1765	1.0679	1.0317	1.2071	1.2803	1.262
9	1.267	1.3575	1.2021	1.1706	1.267	1.267	1.3032
10	1.267	1.1765	1.2127	1.2489	1.267	1.267	1.1403
11	1.1765	1.1403	1.2127	1.0974	1.086	1.1584	1.1041
12	1.086	1.1403	1.267	1.134	1.267	1.2127	1.0679
13	1.086	1.1222	1.1403	1.0059	1.086	1.1222	1.1041
14	1.086	1.0679	1.0317	.9328	1.086	.9774	.9593
15	1.086	.9774	1.0136	1.0791	1.086	.9955	.9412
16	.905	.9412	.9231	.9511	.9955	1.0317	.905
17	1.086	1.1041	1.0136	1.0242	.9955	1.0136	.9955
18	1.1765	1.2308	1.1403	1.2254	1.3575	1.2308	1.1222
19	1.5384	1.4299	1.4299	1.4266	1.5384	1.4935	1.4842
20	1.5384	1.4842	1.3394	1.4083	1.448	1.448	1.4661
21	1.448	1.4842	1.3394	1.3717	1.448	1.4842	1.448
22	1.3575	1.3575	1.3014	1.3535	1.3575	1.3756	1.3756
23	1.267	1.2308	1.1403	1.262	1.267	1.2851	1.2127
24	1.1765	1.086	1.0317	.9774	1.1157	1.086	1.0317
Max	1.5384	1.4842	1.4299	1.4266	1.5384	1.4935	1.4842
Min	.905	.905	.905	.8688	.9511	.905	.905
Avg	1.1576	1.1415	1.0976	1.0761	1.1746	1.1541	1.1190

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113015 / LOKPRIYA

Feeder No / Name : 203 / JANTA MARKET FEEDER

Feeder KV- 11 / OUTGOING

DATE	23-DEC-17	27-DEC-17
HR	Load (MW)	Load (MW)
17	.1715	
22		.1715
Max	.1715	.1715
Min	.1715	.1715
Avg	.1715	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113015 / LOKPRIYA

Feeder No / Name : 204 / DAV COLLEGE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	25-DEC-17
HR	Load (MW)	Load (MW)
7	.0953	
14		.0953
Max	.0953	.0953
Min	.0953	.0953
Avg	.0953	.0953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113015 / LOKPRIYA

Feeder No / Name : 205 / 11kV SARVAMANGAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3544	.3544	.362	.362	.3224	.3189	.3258
2	.3544	.3189	.3258	.3258	.2686	.3258	.3258
3	.3544	.3189	.3258	.3258	.2328	.2658	.3077
4	.2658	.2658	.3258	.3261	.2328	.2658	.3077
5	.2658	.2658	.3258	.3395	.2686	.2658	.3077
6	.2658	.2658	.3258	.3258	.3224	.3544	.3077
7	.3898	.3544	.3077	.3439	.3403	.3544	.362
8	.443	.3258	.3439	.362	.4656	.443	.4344
9	.443	.443	.3982	.3982	.443	.443	.4344
10	.443	.443	.4706	.4706	.443	.443	.5249
11	.443	.4344	.4344	.4656	.3544	.3801	.4338
12	.3544	.4706	.4525	.4119	.443	.4525	.3982
13	.3544	.3772	.4344	.2507	.3544	.3258	.3258
14	.8859	.362	.3982	.3403	.3544	.3982	.3278
15	.3189	.362	.3801	.3403	.3189	.3077	.3258
16	.3189	.3439	.362	.2865	.3189	.2896	.4736
17	.3544	.3258	.3258	.3761	.3544	.3077	.3077
18	.443	.3982	.4163	.4298	.443	.4344	.4163
19	.443	.5068	.4706	.4835	.443	.5068	.4887
20	.443	.5068	.4706	.4656	.443	.4887	.4706
21	.5316	.4887		.5014	.4784	.5249	.4887
22	.5316	.4706	.4525	.5014	.4607	.4525	.4887
23	.443	.4344	.4344	.4477	.443	.4189	.4525
24	.3898	.3544	.4007	.3801	.3761	.3544	.3801
Max	.8859	.5068	.4706	.5014	.4784	.5249	.5249
Min	.2658	.2658	.3077	.2507	.2328	.2658	.3077
Avg	.4098	.3830	.3889	.3859	.3719	.3801	.3924

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113015 / LOKPRIYA

Feeder No / Name : 206 / RCF

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9955	1.086	.9412	.9412	.9328	1.0059	.9774
2	.9955	1.0059	.905	.905	.8779	.9145	.9774
3	.905	.9955	.905	.905	.823	.905	.9774
4	.905	.9955	.8688	.905	.8596	.905	.9774
5	1.086	.905	.8688	.905	.8596	.9955	.9774
6	1.1765	.905	.8869	.905	.9694	.9955	.9774
7	1.1765	1.086	.9955	.905	1.1157	1.086	1.1222
8	1.1765	1.086	.9955	1.086	1.1706	1.267	1.2308
9	1.1765	1.1765	1.0679	1.0317	1.1765	1.267	1.1584
10	1.086	1.1765	1.0317	1.1041	1.1765	1.086	1.1222
11	.905	1.1041	1.1222	1.0974	1.086	1.0136	1.086
12	.905	.9593	1.0136	.8779	.905	.9412	.8326
13	.905	.9431	.9412	.8596	.8145	.8326	.8378
14	.8145	.7964	.8507	.8048	.8145	.7964	.8299
15	.8145	.7602	.7964	.7865	.724	.6878	.6878
16	.724	.7602	.7783	.7133	.724	.7059	.7059
17	.724	.7783	.8145	.8048	.724	.7832	.7832
18	.9955	.9593	.9774	.9877	.9955	.7773	.8869
19	1.1765	1.1946	1.2489	1.1706	1.1765	1.1222	1.1222
20	1.267	1.1946	1.2489	1.1888	1.1765	1.1946	1.1765
21	1.267	1.1946	1.2127	1.2071	1.1765	1.2308	1.1946
22	1.267	1.1765	.2858	1.1888	1.1765	1.2127	1.1584
23	1.086	1.1041	1.0136	1.1157	1.1765	1.086	1.0751
24	1.086	1.086	1.0564	1.0242	1.0059	.9955	1.0136
Max	1.267	1.1946	1.2489	1.2071	1.1765	1.267	1.2308
Min	.724	.7602	.2858	.7133	.724	.6878	.6878
Avg	1.0257	1.0179	.9511	.9758	.9849	.9920	.9954

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113015 / LOKPRIYA

Feeder No / Name : 207 / Lokpriya S/Stn

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0943	.0943	.0953	.0953	.0943
2	.0953	.0953	.0943	.0943	.0953	.0953	.0943
3	.0953	.0953	.0943	.0943	.0953	.0953	.0943
4	.0953	.0953	.0943	.0943	.0953	.0953	.0943
5	.0953		.0943	.0943	.0953	.0953	.0943
6	.0953		.0943		.0953	.0953	.0943
7	.0953		.0943	.0943	.0953	.0953	.0943
8	.0953	.0953	.0943	.0943	.0953	.0953	.0943
9	.0953	.0953	.0943	.0943	.0953	.0953	.0943
10	.0953	.0953	.0943	.0943	.0953		
11			.0943	.0953	.0953	.0943	.0943
12	.0953	.0943	.0943	.0953	.0953	.0943	.0943
13	.0953	.0943	.0943	.0953	.0953	.0943	.0943
14	.0953	.0943	.0943	.0953	.0953	.0943	.0943
15	.0953	.0943	.0943	.0953	.0953	.0943	.0943
16	.0953	.0943	.0943	.0953	.0953	.0943	.0943
17	.0953	.0943	.0943	.0953		.0943	.0943
18	.0953	.0943	.0914	.0953	.0953	.0943	.0943
19	.0953	.0943	.0943	.0953	.0953	.0943	.0943
20	.0953	.0943	.0943	.0953	.0953	.0943	.0943
21	.0953	.0943	.0943	.0953		.0943	.0943
22	.0953		.0943	.0953	.0953	.0943	.0905
23	.0953	.0943	.0943	.0953	.0953	.0943	.0943
24	.0953	.0953	.0943	.0943	.0953	.0953	.0943
Max	.0953	.0953	.0943	.0953	.0953	.0953	.0943
Min	.0953	.0943	.0914	.0943	.0953	.0943	.0905
Avg	.0953	.0947	.0942	.0949	.0953	.0947	.0941

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113015 / LOKPRIYA

Feeder No / Name : 208 / Bhandup Station

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	.823	.724	.7602	.7682	.823	.724
2	.823	.823	.724	.724	.695	.7316	.724
3	.7316	.7316	.6878	.724	.7133	.7316	.6878
4	.7316	.7316	.6878	.724	.6584	.7316	.6878
5	.9145	.6401	.6878	.724	.7133	.6401	.6878
6	.9145	.6401	.6878	.724	.7499	.6401	.7059
7	1.0059	.823	.724	.7602	.8779	.823	.8688
8	1.0974	.823	.7964	.8145	.9694	1.0059	.9774
9	.9145	.9145	.905	.8869	1.0059	1.0974	.9955
10	.9145	.9145	.9593	.9955	.9145	.9145	.905
11	.9145	.9593	.9412	.8413	.9145	.9231	.9107
12	.823	.905	.8507	.8413	.823	.8145	.7783
13	.823	.8507	.8326	.7682	.7316	.8145	.7964
14	.7316	.7602	.7602	.7133	.7316	.724	.7602
15	.7316	.7421	.7059	.7499	.7316	.7167	.724
16	.7316	.6878	.7059	.6767	.7316	.6878	.7545
17	.7316	.7421	.7059	.7316	.7316	.7059	.7421
18	.9145	.8869	.8869	.8413	.2012	.9231	.8507
19	1.1888	1.1041	1.086	.9877	1.0974	1.1041	1.086
20	1.1888	1.0679	1.094	1.0425	1.0974	1.0679	1.0679
21	1.0974	1.0679	1.0679	1.0059	1.0974	1.1041	1.0498
22	1.0974	1.0317	1.0136	1.0059	1.0974	1.0136	1.0498
23	1.0059	.8869	.905	.9328	.9145	.9412	.9231
24	.9145	.9145	.7964	.8145	.823	.823	.7964
Max	1.1888	1.1041	1.094	1.0425	1.0974	1.1041	1.086
Min	.7316	.6401	.6878	.6767	.2012	.6401	.6878
Avg	.9069	.8530	.8307	.8246	.8246	.8543	.8439

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113015 / LOKPRIYA

Feeder No / Name : 209 / Bhandupeshwar Kund

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.2241	.9412	.1886	.2075	.2241	.1886
2	.1867	.1867	.1886	.1886	.1886	.2241	.1886
3	.168	.1867	.1886	.1886	.1886	.1867	.1886
4	.168	.1867	.1886	.1886	.2075	.1867	.1886
5	.1494	.2241	.1886	.1886	.2075	.1494	.1886
6	.1494	.2241	.1886	.1886	.2263	.1494	.1886
7	.168	.1867	.1698	.1886	.1886	.1867	.1698
8	.168	.168	.1698	.1886	.1886	.2054	.1698
9	.1494	.1494	.1509	.1509	.1867	.168	.132
10	.1307	.1494	.1509	.132	.2054	.1867	.1509
11	.1307	.1509	.1509	.1509	.1867	.2075	.1509
12	.1494	.1509	.1698	.1509	.168	.2075	.1509
13	.1494	.2075	.1629	.1509	.2054	.1886	.1698
14	.1494	.1698	.1698	.1509	.2241	.1698	.1698
15	.1494	.2075	.1886	.1509	.2054	.1698	.1698
16	.1307		.1509	.1509	.1867	.1509	.1629
17	.1494	.1509	.1886	.1509	.1867	.1509	.1991
18	.168	.1886	.1886	.1698	.2054	.1886	.2263
19	.2427	.2452	.2641	.2452	.2801	.2452	.3018
20	.2801	.2641	.2353	.2641	.2801	.2641	.2896
21	.2801	.2641	.2353	.2641	.2801	.2641	.3018
22	.2427	.2641	.2452	.2829	.2987	.2641	.2829
23	.2241	.2452	.2452	.2452	.2801	.2263	.2641
24	.2241	.2241	.2075	.2075	.2452	.2614	.2075
Max	.2801	.2641	.9412	.2829	.2987	.2641	.3018
Min	.1307	.1494	.1509	.132	.168	.1494	.132
Avg	.1789	.2008	.2220	.1886	.2178	.2011	.2001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113016 / AMFORGE

Feeder No / Name : 201 / Mahavir-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2572		.2401	.2229	.2401	.2667
2	.2667	.2401		.2401	.2058	.2572	
3		.2229		.2401	.2058	.2401	
4		.2058		.2401	.1886	.2572	
5		.2058		.2401	.2058	.2401	
6		.2401	.2667	.2401	.2401	.2401	.2858
7		.3086	.2858	.2229	.3086	.3258	.2667
8	.3048	.2743	.3429	.2229	.2915	.3772	
9	.4572		.3086	.3258			.4001
10	.3258	.3429	.3258	.3086	.3429		.3258
11	.3601		.3429	.3601	.3086	.362	.3086
12	.2572	.4001	.3258	.2743	.3086	.3429	.2743
13	.2401		.3086	.2915			.2572
14	.2401		.2572	.2229	.2229	.2286	.2229
15	.2058	.2477	.2572	.2229	.2401		.2058
16	.2229		.2401	.2229	.2401		.1886
17	.1886	.2286	.2058	.2401	.2401		.1886
18	.2915	.3048	.2058	.2572	.2572	.3429	.2401
19	.2401	.2667	.2401	.2915	.2743		.2572
20	.3086	.2858	.2572	.2572	.2401	.3048	.2743
21	.3086		.2401	.2743	.2915	.3429	.2229
22	.2572	.2667	.2572	.2572	.2743		.2572
23	.2572		.2401	.2743	.2401	.3239	.2572
24	.2667	.2572	.2667	.2229	.2401	.2401	.2477
Max	.4572	.4001	.3429	.3601	.3429	.3772	.4001
Min	.1886	.2058	.2058	.2229	.1886	.2286	.1886
Avg	.2772	.2680	.2723	.2579	.2541	.2916	.2604

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113016 / AMFORGE

Feeder No / Name : 202 / ANGEL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1372		.1372	.1372	.1372	.1524
2	.1524	.1372		.1372	.1372	.1372	
3		.1372		.1372	.1372	.1372	
4		.1372		.1372	.1372	.1372	
5		.1372		.1372	.1372	.1372	
6		.1372	.1524	.1372	.1372	.1372	.1524
7		.1372	.1524	.1372	.1372	.1372	
8	.1524	.1372	.1372	.1372	.1372	.1372	
9	.1524		.1372	.1372			.1524
10	.1372	.1524	.1372	.1372	.1372		
11	.1372		.1372	.1372	.1372	.1524	.1372
12	.1372	.1524	.1372	.1372	.1372	.1524	.1372
13	.1372		.1372	.1372			.1372
14	.1372		.1372	.1372	.1372	.1524	.1372
15	.1372	.1524	.1372	.1372	.1372		.1372
16	.1372		.1372	.1372	.1372		.1372
17	.1372		.1372	.1372	.1372		.1372
18	.1372	.1524	.1372	.1372	.1372	.1524	.1372
19	.1372	.1524	.1372	.1372	.1372		.1372
20	.1372	.1524	.1372	.1372	.1372	.1524	.1372
21	.1543		.1372	.1372	.1372		.1372
22	.1372	.1524	.1372	.1372	.1372	.1524	.1372
23	.1372		.1372	.1372	.1372	.1524	.1372
24	.1524	.1372	.1524	.1372	.1372	.1372	.1524
Max	.1543	.1524	.1524	.1372	.1372	.1524	.1524
Min	.1372	.1372	.1372	.1372	.1372	.1372	.1372
Avg	.1421	.1439	.1396	.1372	.1372	.1439	.1408

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113016 / AMFORGE

Feeder No / Name : 204 / J BHARAT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.166		1.0117	1.0117	1.0288	1.0669
2	1.0288	1.1145		.9602	.9602	.9602	
3		1.0631		.9088	.9259	.9431	
4		1.046		.8916	.9602	.8916	
5		1.0802		.9774	1.0288	.9431	
6		1.1317	1.105	1.0288	1.0974	1.1317	1.105
7		1.2346	1.2003	1.0631	1.2346	1.2174	
8	1.5623	1.286	1.1488	1.2003	1.3889	1.3717	
9	1.5242		1.2346	1.3032			1.4861
10	1.3717	1.5242	1.4232	1.3203	1.406		1.3546
11	1.2174		1.3203	1.3032	1.2689	1.3717	1.2689
12	1.1831	1.2955	1.3546	1.2517	.8573	1.3336	1.1488
13	1.166		1.3203	1.2003			1.0802
14	1.1488		1.2689	1.1488	1.0974	1.2193	1.0974
15	1.1317	1.1431	1.2517	1.1145	1.0974		1.0117
16	1.0974		1.046	1.0974	1.0974		.9945
17	1.1317		1.2174	1.1317	1.1317		1.0288
18	1.4403	1.4861	1.3546	1.3032	1.3032	1.4098	1.1831
19	1.749	1.848	1.6804	1.6461	1.6461		1.5261
20	1.7661	1.9052	1.6632	1.6632	1.7147	1.829	1.5604
21	1.7147		1.5775	1.6632	1.6804		1.5775
22	1.6289	1.6004	1.4575	1.5089	1.5432	1.7909	1.4232
23	1.4232		1.3375	1.3203	1.3889	1.448	1.3203
24	1.2955	1.2174	1.2955	1.166	1.1317	1.1488	1.2193
Max	1.7661	1.9052	1.6804	1.6632	1.7147	1.829	1.5775
Min	1.0288	1.046	1.046	.8916	.8573	.8916	.9945
Avg	1.3539	1.3214	1.3293	1.2160	1.226	1.2524	1.2474

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113016 / AMFORGE

Feeder No / Name : 206 / PANNALAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2574	1.2003		1.1317	1.1317	1.166	1.2574
2	1.2193	1.1488		1.0802	1.0802	1.0974	
3		1.0802		1.0288	1.046	1.0631	
4		1.0802		1.0288	1.0288	1.0288	
5		1.1145		.9945	1.0631	1.0631	
6		1.1488	1.105	.9945	1.0974	1.1317	1.1431
7		1.1145	1.2193	1.0117	1.0802	1.0974	
8	1.6004	1.2517	1.1831	1.1145	1.2517	1.3717	
9	1.8671		1.3032	1.4403			1.7528
10	1.9547	2.2291	1.6118	1.8004	1.989		2.0748
11	2.0405		1.749	1.9719	2.1948	2.21	2.0748
12	2.0748	2.3243	1.869	1.989	2.1605		2.1605
13	1.7318		1.5261	1.749		2.1338	1.6289
14	1.7147		1.5947	1.749	1.8176	1.9433	1.8004
15	1.8861	2.0576	1.5432	1.7661	1.9547		1.9719
16	1.8519		1.4918	1.6975	1.9547		1.8519
17	1.9033		1.3546	1.7833	1.989		1.9547
18	1.9376	2.1338	1.3717	1.8004	2.0233	2.2481	1.8519
19	2.1262	2.21	1.6289	2.0748	2.1948		1.989
20	2.0405	2.2862	1.6289	1.989	2.0576	2.3243	1.8347
21	1.6975		1.6118	1.7318	1.7661		1.6118
22	1.5432	1.6766	1.5604	1.5261	1.6118	.3429	1.4232
23	1.4232		1.3889	1.4403	1.4403	1.5623	1.3717
24	1.4098	1.2346	1.3717	1.2517	1.286	1.2689	1.3717
Max	2.1262	2.3243	1.869	2.0748	2.1948	2.3243	2.1605
Min	1.2193	1.0802	1.105	.9945	1.0288	.3429	1.1431
Avg	1.7516	1.5807	1.4796	1.5061	1.6009	1.4408	1.7292

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113016 / AMFORGE

Feeder No / Name : 207 / NEHA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8954	.8916		.7888	.7888	.7888	.8954
2	.8002	.8573		.7373	.7373	.7373	
3		.823		.703	.7202	.703	
4		.823		.703	.7545	.703	
5		.8402		.7202	.7888	.7202	
6		.8573	.8192	.7716	.8402	.823	.9145
7		.8916	.9335	.7716	.8916	.823	1.0288
8	1.2193	.9774	.9907	.9259	.9774	.9945	
9	1.3146		1.0288	1.1145			1.3336
10	1.2689	1.4861	1.1831	1.166	1.166		1.3032
11	1.3203		1.2003	1.3375	1.3717	1.448	1.2517
12	1.2174	1.4861	1.1488	1.2517	1.2689	1.4861	1.286
13	1.0974		1.1488	1.2003			1.2003
14	1.1488		1.0631	1.1831	1.1488	1.3146	1.046
15	1.1488	1.4098	1.0117	1.166	1.1145		1.166
16	1.1317		.9431	1.1145	1.1145		1.0974
17	1.2003	1.3527	.9945	1.1831	1.2003		1.2346
18	1.3203	1.4098	1.0974	1.2174	1.3032	1.3717	1.166
19	1.4746	1.6004	1.3032	1.4403	1.3375		1.3203
20	1.4403	1.5432	1.1831	1.286	1.3375	1.3717	1.1831
21	1.3375		1.2003	1.2174	1.2689	1.3336	1.0974
22	1.1831	1.2574	1.0288	1.0802	1.1145		1.0288
23	1.0288		1.0117	1.0117	.9945	1.1241	.9431
24	1.0288	.8916	.9907	.8402	.8745	.8573	.9526
Max	1.4746	1.6004	1.3032	1.4403	1.3717	1.4861	1.3336
Min	.8002	.823	.8192	.703	.7202	.703	.8954
Avg	1.1882	1.1411	1.0674	1.0388	1.0506	1.0375	1.1289

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113016 / AMFORGE

Feeder No / Name : 208 / Lodha Imperia

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.5144		.463	.4801	.4801	.5335
2	.4763	.4801		.4458	.4458	.4458	
3		.4458		.1372	.4287	.4287	
4		.463		.4287	.4458	.4458	
5		.4973		.4287	.4801	.4458	
6		.5316	.5144	.4801	.5316	.5144	.5716
7		.6001	.5335	.5316	.5658	.5658	.6859
8	.8002	.703	.583	.6344	.7373	.7202	
9	1.1431		.6173	.8916			.9145
10	1.0117	1.1622	.7716	.8745	.9602		1.0288
11	.9945		.6687	.9431	.9945	1.0288	
12	.9774	1.0288	.703	.8745	.9945		.9602
13	.8402		.7545	.8402		.9335	.7373
14	.9259		.6344	.7545	.7545	.9335	.7545
15	.9088	1.0669	.6344	.7888	.7716		.8059
16	.8745		.6001	.7373	.7888		.8059
17	.8916	1.0288	.583	.7888	.7888		.8059
18	.8573	.9526	.6687	.7888	.8745	.9717	.823
19	.9088	1.0098	.8059	.8402	.8916		.8402
20	.8059	.8383	.6859	.7545	.7888	.8764	.703
21	.7545		.703	.7202	.7716	.8954	.6687
22	.6859	.6859	.6516	.6344	.6687		.6001
23	.6173		.6173	.583	.6173	.6478	.583
24	.6097	.5316	.5716	.5144	.5144	.5487	.5716
Max	1.1431	1.1622	.8059	.9431	.9945	1.0288	1.0288
Min	.4763	.4458	.5144	.1372	.4287	.4287	.5335
Avg	.8220	.7377	.6475	.6616	.6952	.6802	.7441

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113022 / DREAMS

Feeder No / Name : 201 / Dheeraj Dreams-2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.4001			.4001	.381	.4572
2	.4572	.362			.381	.362	.4954
3	.4954	.3429			.362	.3429	.4763
4	.5335	.4191			.4001	.3239	.5716
5	.5906	.4191			.4382	.3429	.5525
6	.6478	.4954			.4954	.4572	
7	.7049	.4382			.5525	.5335	.5716
8	.7621	.5335			.5906	.6287	.4572
9	.7811	.6287	.5335		.7621	.7049	.8573
10	.7621	.6478	.6668	.6097	.743	.8002	.8383
11	.743			.6478	.743		
12	.743	.7049	.5716	.6859	.6478	.6859	.7621
13	.6478	.6478		.5335	.6668	.6668	.5906
14	.6097			.5525	.7049		.5906
15	.6859		.4763	.5335	.6287		.5716
16	.5906			.5144	.5716	.5335	.5335
17	.5716	.5335		.4763	.5716	.5716	.5525
18	.6478	.5525		.5144	.5335	.5716	.6097
19	.6287	.5716		.5335	.6287	.5906	.5716
20	.5906	.5525		.5525	.5906	.5716	.5335
21	.5906	.4763		.5335	.4954	.4954	.5335
22	.5525			.4954	.5525	.5525	.5335
23	.4954			.4763		.4763	
24	.4763	.4191			.4191	.4572	.4572
Max	.7811	.7049	.6668	.6859	.7621	.8002	.8573
Min	.4191	.3429	.4763	.4763	.362	.3239	.4572
Avg	.6136	.5081	.5621	.5471	.5600	.5262	.5770

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113022 / DREAMS

Feeder No / Name : 202 / Dheeraj dreams-4

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905			.1715	.1905	.2858
2	.2096	.1905			.1524	.1905	
3	.2286	.1905			.1524	.1905	
4	.2667	.1715			.2096	.1715	
5	.3048	.1905			.2667	.1905	
6	.3429	.2096			.3239	.2096	
7	.381	.2477			.381	.2477	.2667
8	.4191	.3048			.4191	.362	
9	.4954		.4572		.4763	.4191	.4191
10	.4763	.381		.2286	.4763	.4382	.4191
11	.5144			.2096	.4191		
12	.4954	.4001	.3239	.1905	.4382		.3048
13	.4191	.3048		.1715	.4382	.362	.2477
14	.4191			.1715	.381		.2667
15	.4572		.3048	.1524	.381		.3048
16	.381			.1715	.362	.362	.381
17	.4001	.3429		.1905	.3429	.4001	.381
18	.4382	.362		.2286	.4191	.362	.4001
19	.4382	.362		.2667	.362	.381	.4001
20	.4001	.4001		.2667	.3429	.362	.362
21	.3048	.381			.2667	.362	.3429
22	.3048				.2667	.3429	.2667
23	.2286			.2096	.2477	.3429	
24	.1905	.2096			.1905	.2096	
Max	.5144	.4001	.4572	.2667	.4763	.4382	.4191
Min	.1905	.1715	.3048	.1524	.1524	.1715	.2477
Avg	.3628	.2847	.3620	.2048	.3286	.3048	.3366

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113022 / DREAMS

Feeder No / Name : 203 / Dheeraj Dreams 5

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429			.381	.3429	
2	.381	.3429			.3239	.3239	
3	.4191	.3048			.2667	.3048	
4	.4572	.3048			.3239	.2858	
5	.4763	.3429			.362	.3239	
6	.4954	.4572			.4001	.4572	
7	.5144	.4382			.4382	.4763	.6097
8	.5335				.4763	.5144	
9	.6097		.5525		.6287	.5525	.5525
10	.5716	.4954	.4954	.6668	.6859	.6097	.5716
11	.5144			.6668	.4954		
12		.3048	.4001	.6478	.362	.4191	.5335
13	.4191	.2096		.381		.3429	.3429
14	.362			.3429			.3239
15	.3048		.3429	.3048	.2667		.2858
16	.4001			.362	.3429	.3429	.381
17	.381	.2667		.381	.3048	.3239	.381
18	.3429	.362		.4001	.3429	.2667	.3239
19	.4191	.3048		.4191	.3429	.3048	.3429
20	.4001	.2858		.381	.381	.2858	.4191
21	.5716	.2667		.4382	.4954	.3048	.381
22	.5144			.4191	.5144		.5144
23	.4001				.4191	.4572	
24	.4572	.381			.4191	.4572	
Max	.6097	.4954	.5525	.6668	.6859	.6097	.6097
Min	.3048	.2096	.3429	.3048	.2667	.2667	.2858
Avg	.4473	.3382	.4477	.4470	.4079	.3848	.4259

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113022 / DREAMS

Feeder No / Name : 205 / Jam Theatre

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3908	1.4289			1.3908	1.3336	
2	1.4861	1.3336			1.3146	1.2765	
3	1.5813	1.2955			1.2193	1.2193	
4	1.6766	1.2574			1.3336	1.1812	
5	1.7528	1.3336			1.448	1.3336	
6	1.829	1.5432			1.5813	1.5432	
7	1.9052	1.6004			1.7147	1.6575	1.6956
8	1.9814	1.8099			1.829	1.7718	
9	1.9814		1.829		1.8861	1.9814	
10	1.9624	1.9243	1.9243	1.9052	1.8099	1.9052	2.0005
11	1.9243			1.8861	1.9243		
12	1.8861		1.848	1.8671	1.848	1.9433	1.8099
13	1.6766	1.6385		1.6575	1.6385	1.7147	1.5813
14	1.7718			1.6194	1.7337		1.6956
15	1.7718		1.6385	1.5813	1.6385		1.6004
16	1.7337			1.5813	1.5813	1.6385	1.6004
17	1.8671	1.7337		1.6956	1.6956	1.6956	1.6766
18	2.1338	2.2672		2.0195	2.0386	2.0195	1.8671
19	2.5339	2.5149		2.3243	2.4577	2.3815	2.21
20	2.5339	2.4768		2.3053	2.4006	2.4387	2.2291
21	2.4196	2.3243		2.1719	2.2862	2.2672	2.0957
22	2.2291			2.0386	2.0767	2.2481	1.9814
23	2.0195			1.9052	1.8861	1.8671	
24	1.5813	1.6194			1.4861	1.4861	
Max	2.5339	2.5149	1.9243	2.3243	2.4577	2.4387	2.2291
Min	1.3908	1.2574	1.6385	1.5813	1.2193	1.1812	1.5813
Avg	1.9012	1.7564	1.8100	1.8970	1.7591	1.7573	1.8495

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113022 / DREAMS

Feeder No / Name : 206 / Police Station

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.5716			.5716	.5716	.5525
2	.5335	.5525			.5525	.5335	.5335
3	.4954	.5335			.5335	.5144	.5525
4	.5335	.5144			.5716	.4954	
5	.5335	.4954			.6097	.4954	.4954
6	.5716	.4954			.6287	.4954	.4572
7	.6097	.5144			.6478	.5335	.4382
8	.6478	.5906			.6668	.5906	.4382
9	1.0288		.6097		.9717	.9335	.9145
10	1.2574	.9526	.8002	1.2193	1.2765	1.4098	1.2955
11	1.467			1.3336	1.4098		
12	1.448	1.5242	.8573	1.4289	1.5623	1.5051	1.448
13	1.105	1.1812		1.0288	1.1241	1.0479	1.086
14	1.4098			1.2003	1.4289		1.3717
15	1.5242		.7049	1.3717	1.5623		1.4861
16	1.5623			1.3908	1.3908	1.448	1.4861
17	1.5051	1.4289		1.3146	1.467	1.4289	1.4098
18	1.3717				1.3146	1.4098	1.3146
19	1.2574	1.3336		1.086	1.2765	.9717	1.1622
20	.9717	1.2193		.9907	.9335	.9907	.9526
21	.7049	.6859		.8573	.724	.7811	.7621
22	.6287			.7049	.5906	.5716	.6287
23	.5716			.5716	.6097		
24	.6287	.5906			.5906	.5525	
Max	1.5623	1.5242	.8573	1.4289	1.5623	1.5051	1.4861
Min	.4954	.4954	.6097	.5716	.5335	.4954	.4382
Avg	.9558	.8240	.7430	1.1153	.9590	.8640	.9393

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113023 / Haryali

Feeder No / Name : 200 / Marathon

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2481	.2835	.2401	.2401	.2401	.2835	.3429
2	.2481	.2835	.2401	.2229	.2229	.2835	.3086
3	.2481	.2481	.2058	.2058	.2058	.2481	.3086
4	.2835	.2481	.2058	.2058	.2058	.2481	.2743
5	.2835	.2481	.2058	.2401	.2401	.2481	.3429
6	.2835	.2835	.2401	.2401	.2743	.2481	.3601
7	.3189	.2835	.2743	.2572	.2743	.2481	.4287
8	.4252	.3189	.3429	.2572	.3601	.3898	.5144
9	.3898	.2915	.3086	.3086	.3189	.3429	.6024
10	.2835	.3429	.3429	.2743		.2743	.7442
11	.2835	.2915	.2915	.3086	.2835	.2401	.6379
12	.2481	.2401	.2743	.2743	.2835	.2401	.6379
13	.2481	.2401	.2401	.2401	.2835	.6173	.6379
14	.2481	.2401	.2401	.2058	.2835	.463	.6379
15	.2481	.2058	.2229	.2058	.2481	.4458	.6024
16	.2481	.2058	.2058	.2229	.2481	.4287	.6379
17	.2481	.2401	.2058	.2401	.2481	.4801	.6024
18	.2835	.2572	.2401	.2572	.2481	.4973	.6733
19	.3189	.3086	.3258	.2915	.2835	.5487	.7087
20	.3898	.3429	.3429	.3429	.3658	.5487	.6379
21	.3544	.3429	.3429	.3258	.3544	.4973	.6379
22	.3721	.3258	.3772	.2915	.3544	.463	.5316
23	.2835	.2743	.3429	.2743	.2835	.4115	.4607
24	.2481	.2481	.2572	.2572	.2401	.2835	.3772
Max	.4252	.3429	.3772	.3429	.3658	.6173	.7442
Min	.2481	.2058	.2058	.2058	.2058	.2401	.2743
Avg	.2931	.2748	.2715	.2579	.2761	.3742	.5270

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113023 / Haryali

Feeder No / Name : 201 / 11kV Lodha kanjur feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6095	1.4998	1.4403	1.3717	1.4746	1.6095	1.4575
2	1.5729	1.4632	1.3717	1.3375	1.4403	1.5729	1.3889
3	1.4998	1.4266	1.3375	1.3032	1.3717	1.4998	1.3375
4	1.4632	1.39	1.286	1.2689	1.3375	1.4266	1.3032
5	1.4998	1.4266	1.3203	1.2517	1.3889	1.4266	1.3375
6	1.5181	1.4815	1.3717	1.286	1.4746	1.4632	1.3889
7	1.6827	1.5729	1.3717	1.3032	1.5089	1.5364	1.4403
8	1.829	1.7193	1.5089	1.4918	1.6975	1.7558	1.6632
9	1.829	1.6632	1.6461	1.5775	1.829	1.7318	1.829
10	1.8656	1.6289	1.8176	1.6632	1.7558	1.7318	1.7924
11	1.8656	1.8004	1.749	1.8176	1.7924	1.5775	1.7924
12	1.7924	1.6289	1.6804	1.6461	1.7558	1.6461	1.7558
13	1.7558	1.7318	1.7147	1.5261	1.6827	1.5775	1.7558
14	1.7193	1.6804	1.6289	1.4403	1.6461	1.5089	1.7193
15	1.5729	1.6632	1.5775	1.4403	1.5364	1.406	1.6461
16	1.4998	1.6118	1.5089	1.3203	1.5729	1.3717	1.5729
17	1.6461	1.5775	1.5775	1.406	1.6095	1.4918	1.6461
18	1.8656	1.869	1.8176	1.6289	1.9387	1.8004	1.9387
19	2.3411	1.989	2.1434	1.9547	2.1948	1.9719	2.1582
20	2.2314	2.2291	2.1776	1.9376	2.3045	2.0062	2.1948
21	2.268	2.1434	2.1262	1.8861	2.1948	2.0405	2.1216
22	2.1399	1.9719	1.9719	1.8519	2.0485	1.9376	1.9753
23	1.9387	1.7318	1.6632	1.6975	1.9022	1.6632	1.7924
24	1.6461	1.6827	1.5261	1.5775	1.5604	1.6461	1.5089
Max	2.3411	2.2291	2.1776	1.9547	2.3045	2.0405	2.1948
Min	1.4632	1.39	1.286	1.2517	1.3375	1.3717	1.3032
Avg	1.7772	1.6910	1.6389	1.5411	1.7091	1.6417	1.6882

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113023 / Haryali

Feeder No / Name : 202 / Railway

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7167	.6224	.6173	.6001	.6344	.7545	.6344
2	.7167	.6036	.583	.5487	.6001	.7167	.6001
3	.7167	.5658	.5487	.5144	.5487	.679	.5658
4	.6979	.5281	.5144	.5144	.5316	.6413	.5144
5	.6979	.6036	.5487	.5316	.583	.6602	.5487
6	.6979	.679	.6001	.5658	.6344	.6602	.5487
7	.7922	.7167	.6344	.583	.6516	.7545	.6344
8	.9808	.7167	.6859	.6173	.8059	.9431	.7373
9	1.0562	.9431	.8573	.8916	.9808	1.0117	1.2449
10	1.3957	1.2003	.8916	1.0631	1.6221	1.2689	1.5089
11	1.358	1.2003	.8745	1.0802	1.4335	1.3889	1.5089
12	1.2071	1.2003	.8745	1.1488	1.2449	1.3032	1.3957
13	1.1317	1.0974	.8059	.9088	1.2071	1.2003	1.2449
14	.9496	1.0288	.7373	.8573	1.1317	.9774	1.2071
15	1.2449	1.0288	.7373	.9259	1.1317	1.0288	1.1694
16	1.1694		.6859	.9774	1.1317	1.0631	1.2449
17	1.1317	1.0631	.7716	.9259	1.1317	1.046	1.2826
18	1.1317	1.0631	.8402	.8916	1.0562	1.0288	1.2071
19	1.094	1.046	.9088	.9602	1.1694	1.0631	1.2071
20	1.0562	1.0288	.8573	.8916	1.2071	1.0974	1.1317
21	1.0185	.9088	.7888	.7888	.9431	.8916	.9431
22	.9431	.8402	.7373	.8573	.9431	.8059	.9054
23	.7922	.7545	.703	.7545	.8676	.7545	.7922
24	.7545	.7545	.6687	.6516	.6687	.7922	.6687
Max	1.3957	1.2003	.9088	1.1488	1.6221	1.3889	1.5089
Min	.6979	.5281	.5144	.5144	.5316	.6413	.5144
Avg	.9771	.8780	.7280	.7937	.9525	.9388	.9769

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113023 / Haryali

Feeder No / Name : 204 / Kanjur signal

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0678	.0678	.0686	.0686	.0514	.0686	.0686
2	.0678	.0678	.0686	.0686	.0514	.0686	.0686
3	.0678	.0678	.0686	.0686	.0514	.0686	.0686
4	.0678	.0678	.0686	.0686	.0514	.0686	.0686
5	.0678	.0678	.0686	.0686	.0514	.0686	.0686
6	.0678	.0678	.0686	.0686		.0686	.0686
7			.0686	.0514			.0686
18	.0514		.0686	.0514	.0514		.0509
19	.0686	.0514	.0686	.0514	.0514	.0686	.0678
20	.0686	.0686	.0686	.0514	.0686	.0686	.0678
21	.0686	.0686	.0686	.0514	.0686	.0686	.0686
22	.0686	.0686	.0686	.0514	.0686	.0686	.0678
23	.0686	.0686	.0686	.0514	.0686	.0686	.0678
24	.0686	.0678	.0686	.0686	.0514	.0686	.0686
Max	.0686	.0686	.0686	.0686	.0686	.0686	.0686
Min	.0514	.0514	.0686	.0514	.0514	.0686	.0509
Avg	.0669	.0667	.0686	.06	.0571	.0686	.0671

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113030 / 22/11kV Lodha Receiving

Statio

Feeder No / Name : 200 / Lodha Supremus

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.168	.1543	.1524	.1715	.1543	.1494
2	.1543	.1494	.1543	.1524	.1524	.1372	.168
3	.1372	.1307	.1372	.1524	.1524	.1372	.1494
4	.1372	.112	.1372	.1524	.1715	.1543	.168
5	.1372	.112	.1372	.1524	.1715	.1543	.1494
6	.1543	.1132	.1372	.1715	.1715	.1543	.1494
7	.1543	.1132	.1372	.1524	.1905	.1543	.168
8	.1715	.132	.1372	.1715	.2286	.1715	.1867
9	.3174	.1543	.1715	.1905	.2915	.2987	.3048
10	.4108	.2058	.1715	.2286	.4287	.4294	.4382
11	.4481	.2572	.1905	.2286	.4287	.4668	.4382
12	.4108	.2572	.1905	.2096	.4115	.4108	.4001
13	.4108	.2572	.1905	.2286	.3772	.4481	.4001
14	.4108	.2401	.1905	.2286	.3429	.4108	.4001
15	.3921	.2401	.1905	.2286	.3944	.4108	.4191
16	.4294	.2401	.1905	.2286	.3772	.4108	.4191
17	.3921	.2401	.1905	.2286	.3944	.4108	.4191
18	.3547	.2229	.1905	.2286	.3601	.3921	.362
19	.2614	.2058	.1715	.2096	.2743	.3174	.3239
20	.2427	.1886	.1715	.1905	.2401	.2614	.2477
21	.1867	.1715	.1715	.1905	.2058	.2241	.2286
22	.1509	.1715	.1715	.1715	.1886	.2054	.2096
23	.132	.1543	.1715	.1715	.1543	.1715	.1715
24	.1543	.112	.1543	.1715	.1715	.1543	.168
Max	.4481	.2572	.1905	.2286	.4287	.4668	.4382
Min	.132	.112	.1372	.1524	.1524	.1372	.1494
Avg	.2627	.1812	.1671	.1913	.2688	.2767	.2766

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113030 / 22/11kV Lodha Receiving

Statio

Feeder No / Name : 201 / Lodha Jolly Board

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1867	.1886	.1905	.1905	.1886	.2054
2	.1886	.2054	.1886	.1905	.1905	.1715	.1867
3	.1886	.1867	.1715	.1905	.1905	.1715	.2054
4	.1715	.2054	.1886	.1905	.1905	.1715	.1905
5	.1886	.1905	.1715	.1905	.2096	.1886	.2054
6	.2058	.1886	.1715	.2096	.2096	.1886	.2054
7	.2229	.2075	.1715	.2096	.2858	.2058	.2241
8	.7545	.2452	.1715	.1905	.5525	.4801	.7282
9	.6535	.4973	.1905	.2096	1.0117	.9335	.9145
10	1.1241	.4115	.1905	.2096	.8916	.9709	.6859
11	1.1389	.4458	.2096	.2286	.6516	.7095	1.0288
12	.7468	.4287	.2096	.2477	1.0802	1.1016	1.0098
13	1.0456	.4115	.1905	.2286	.6001	.9896	.6859
14	1.1389	.3772	.2096	.2096	.6344	1.0269	.6859
15	.7621	.4287	.2286	.2286	.6516	.9896	1.0669
16	1.0269	.4287	.2096	.2286	1.0802	.7282	.724
17	1.0269	.3944	.2096	.2096	.9774	1.0829	1.1431
18	.6535	.2058	.2096	.2096	.5487	1.0269	.6097
19	.5415	.2229	.1905	.2096	.463	.5415	.5144
20	.3547	.2058	.2286	.2096	.3944	.3361	.3239
21	.2987	.2058	.2096	.2096	.2743	.2801	.2858
22	.2452	.1886	.2096	.2096	.2229	.2427	.2286
23	.2452	.1715	.1905	.2096	.2229	.2241	.2096
24	.2058	.2241	.1886	.1905	.2096	.2058	.2241
Max	1.1389	.4973	.2286	.2477	1.0802	1.1016	1.1431
Min	.1715	.1715	.1715	.1905	.1905	.1715	.1867
Avg	.5549	.2860	.1958	.2088	.4973	.5482	.5205

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113030 / 22/11kV Lodha Receiving

Statio

Feeder No / Name : 204 / Lodha Aurum Grandies

SHEDDABLE URBAN

feeder Feeder KV- 11 /
OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.168	.1543	.1524	.1524	.1372	.1494
2	.12	.1494	.1372	.1524	.1524	.1372	.168
3	.1029	.1307	.12	.1334	.1524	.1372	.1494
4	.1029	.112	.1029	.1334	.1715	.1543	.168
5	.12	.1143	.12	.1334	.1524	.1543	.1494
6	.2058	.1509	.12	.1905	.1715	.1715	.1494
7	.2915	.1886	.1372	.2286	.2667	.2229	.2858
8	.3429	.2263	.2572	.2667	.3429	.3258	.3734
9	.3361	.2572	.3048	.3429	.3429	.3734	.381
10	.2614	.2915	.2858	.362	.3601	.3547	.3048
11	.3174	.2229	.3239	.3239	.2229	.2987	.3048
12	.2096	.2401	.2667	.2858	.2572	.2801	.3429
13	.1867	.2572	.2858	.2858	.2229	.2614	.2667
14	.168	.1715	.2096	.2286	.1715	.1494	.1715
15	.1143	.2229	.1715	.2096	.1715	.1867	.1524
16	.1494	.1715	.1715	.1715	.2058	.1307	.1524
17	.1307	.1715	.1715	.1715	.12	.1867	.1334
18	.1867	.1715	.2096	.1715	.1543	.2054	.1524
19	.1867	.1886	.2096	.2096	.2058	.2054	.2096
20	.1867	.2401	.2286	.3048	.1715	.2241	.2667
21	.1867	.1715	.2286	.2286	.2058	.2054	.2096
22	.1886	.1543	.1715	.1905	.1886	.168	.2096
23	.1524	.1715	.2096	.1715	.1543	.1867	.1905
24	.1372	.168	.1543	.1524	.1715	.1372	.168
Max	.3429	.2915	.3239	.362	.3601	.3734	.381
Min	.1029	.112	.1029	.1334	.12	.1307	.1334
Avg	.1877	.188	.1980	.2167	.2037	.2081	.2170

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113032 / 22kV Lodha Switching

Feeder No / Name : 302 / 22kV Lodha I-Think

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-DEC-17
HR	Load (MW)
17	1.3336
Max	1.3336
Min	1.3336
Avg	1.3336

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113032 / 22kV Lodha Switching

Feeder No / Name : 303 / 22kV HDFC Bank

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3429	.3086	.381	.3429	.3429	.4191
2	.3772	.381	.3429	.3429	.3429	.3429	.381
3	.3429		.3086	.3429	.3429	.3086	
4	.3429	.381	.3429	.3429	.3048	.3086	.381
5	.3772	.3429	.3086	.3429	.3048	.3429	.4191
6	.3772	.3048	.3086	.3429	.3429	.3772	.381
7	.3772	.3429	.3086	.3429	.381	.3772	.4191
8	1.0288	.4572	.3086	.381	1.2193	.8573	1.1431
9	1.2574	1.0288	.381	.381	1.0631	1.2574	1.1812
10	1.2955	.4458	.3429	.3429	1.2003	1.3717	1.2574
11	1.3336	.5144	.3429	.381	1.2346	1.3717	1.3336
12	1.4098	.4801	.3429	.3048	1.2346	1.3717	1.4098
13	1.2955	.4801	.381	.3429	1.2346	1.4098	1.3717
14	1.3717	.4801	.381	.381	1.2346	1.3717	1.3336
15	1.3717	.4801	.381	.4191	1.2346	1.3717	1.3336
16	1.3717	.4801	.381	.4191	1.2346	1.3717	1.3336
17	1.3336	.7202	.381	.381	1.2346	1.3717	1.3336
18	1.0185	.3772	.381	.4191	.9259	1.3717	1.2574
19	.5658	.4115	.381	.4191	.5144	.6097	.5716
20	.4954	.3772	.3429	.381	.4458	.5335	.5335
21	.4904	.3429	.381	.4191	.4458	.5335	.4954
22	.4191	.3429	.381	.381	.4115	.4572	.4572
23	.4191	.3086	.381	.3429	.3772	.4572	.4191
24	.823	.8002	.3429	.381	.3429	.7888	.8764
Max	1.4098	1.0288	.381	.4191	1.2346	1.4098	1.4098
Min	.3429	.3048	.3086	.3048	.3048	.3086	.381
Avg	.8280	.4619	.3518	.3715	.7479	.8449	.8714

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113032 / 22kV Lodha Switching

Feeder No / Name : 304 / 22 kV Toyo/Steel - I

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-DEC-17	23-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.3086			.3429	.3429	.3048
9	.8002	.3429		.6173	.724	.724
10	.7842	.3429		.7545	.7621	.724
11	.8002	.4801		.7202	.8383	.7621
12	.9526	.5487	.3048	.823	.8764	.9907
13	.8002	.4801	.3048	.7888	.8002	.9145
14	.8383	.4115	.3048	.7202	.8383	.8383
15	.9145	.4115	.3048	.6859	.9907	.8002
16	.7621	.4458		.8573	.7621	.8764
17	.8002			.8573	.8002	.7621
18	.5335			.4458	.4904	
19	.3772			.3429	.4191	.4191
20	.3048			.2743	.3429	.381
21					.3048	
Max	.9526	.5487	.3048	.8573	.9907	.9907
Min	.3048	.3429	.3048	.2743	.3048	.3048
Avg	.6905	.4329	.3048	.6331	.6637	.7081

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

ISHWAR NAGAR S/DN.[732] BU 4732

Substation No/ Name :- 113011 / SBRS

Feeder No / Name : 201 / G E SHIPPING

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	24-DEC-17
HR	Load (MW)
24	.6036
Max	.6036
Min	.6036
Avg	.6036

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

ISHWAR NAGAR S/DN.[732] BU 4732

Substation No/ Name :- 113019 / NITIE SUBSTATION

Feeder No / Name : 202 / NITIE GATE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.595	.5764	.6036	.5847	.6036	.6001	.6413
2	.595	.5764	.6036	.5601	.5658	.5658	.6413
3	.5578	.5764	.6036	.547	.5281	.5316	.6036
4	.5764	.5578	.5658	.5281	.4904	.5658	.5658
5	.595	.5578	.5281	.5093	.5281	.4973	.5658
6	.5578	.5392	.4904	.4904		.583	.5658
7	.5578	.5578	.4904	.4904	.4904	.5487	.6036
8	.688	.5578	.5658	.5228	.6036	.6344	.679
9	.8554	.6694	.5658	.6161	.7167	.7716	.7167
10	.7811	.8589	.6224	.6348	.6859	.9335	.8589
11	.8182	.8215	.5788	.5975	.7373	.7842	
12	.8368	.6348	.6908	.6348	.3944	.7842	.7632
13	.9297	.7095	.6722	.6722	.7716	.7842	.7818
14	.7438	.7095	.6161	.6348	.7545	.8215	.7073
15	.8368	.7095	.6602	.6348	.7888	.8962	.6701
16	.9111	.7095	.6535	.5975	.7202	.7842	.7073
17	.7438	.7095	.6413	.5975	.6687	.7468	.6515
18	.781	.6722	.6413	.6722	.6859	.7842	.7073
19	.874	.7922	.6979	.7922	.7888	.8589	.8562
20	.8554	.7545	.7356	.8299	.7716	.8962	.8562
21	.8554	.7545	.7733	.8299	.7373	.7922	.819
22	.8182	.7167	.6979	.7922	.703	.7545	.819
23	.7438	.7167	.6535	.7167	.6859	.7545	.6515
24	.6694	.6136	.6036		.6413	.6516	.6413
Max	.9297	.8589	.7733	.8299	.7888	.9335	.8589
Min	.5578	.5392	.4904	.4904	.3944	.4973	.5658
Avg	.7407	.6688	.6231	.6298	.6549	.7219	.6988

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

ISHWAR NAGAR S/DN.[732] BU 4732

Substation No/ Name :- 113019 / NITIE SUBSTATION

Feeder No / Name : 203 / TUNGWA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2286	.2263	.2075	.1886	.2058	.2263
2	.2286	.2096	.1886	.2075	.1886	.2058	.2263
3	.2263	.2096	.1886	.1886	.1698	.2058	.2263
4	.2096	.1905	.1886	.1886	.1698	.2058	.1886
5	.2286	.1905	.2263	.2075	.1886	.2229	.1886
6	.2286	.2096	.2263	.2075	.1886	.2229	.1886
7	.2477	.2096	.2263	.1886	.2263	.2229	.2263
8	.2477	.2286	.2263	.2263	.2263	.2401	.2641
9	.2667	.2477	.2641	.2614	.2641	.2572	.3018
10	.3048	.3734	.3206	.3734	.2743	.3734	.3734
11	.3239	.3734	.3174	.3734	.3086	.3734	.4572
12	.362	.3734	.2987	.3361	.3258	.3734	.4563
13	.3239	.3361	.2987	.2987	.3429	.2987	.3993
14	.381	.4108	.2829	.2987	.3601	.3734	.4191
15	.381	.4481	.2641	.3734	.3944	.3734	.3993
16	.381	.4481	.2614	.3734	.3772	.3361	.4183
17	.381	.415	.2829	.3734	.3429	.4108	.4183
18	.362	.3734	.2801	.3361	.3601	.3734	.4183
19	.2096	.415	.2641	.415	.3944	.4481	.5144
20	.2096	.415	.2452	.415	.3429	.4108	.3993
21	.3239	.3395	.2452	.3395	.3086	.3395	.3232
22	.2667	.3018	.2241	.3018	.2401	.2641	.3042
23	.2477	.2641	.1867	.2263	.2058	.2263	.2662
24	.2477	.2286	.2075		.1886	.2058	.2263
Max	.381	.4481	.3206	.415	.3944	.4481	.5144
Min	.2096	.1905	.1867	.1886	.1698	.2058	.1886
Avg	.2841	.31	.2475	.2921	.2741	.2987	.3263

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

ISHWAR NAGAR S/DN.[732] BU 4732

Substation No/ Name :- 113019 / NITIE SUBSTATION

Feeder No / Name : 204 / RESIDENCY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0751	1.1317	1.0562	1.0562	1.1694	.9602	1.1317
2	.9997	.9808	1.0185	.9808	1.1317	.9088	1.094
3	.9808	.9997	.9808	.9431	1.094	.8573	1.094
4	.9808	.9808	.8676	.9335	1.0562	.9088	1.0562
5	1.0374	1.0374	.8676	.9054	1.0185	.8573	1.0562
6	.9997	.9997	.8299		1.0185	.9259	1.094
7	1.0185	1.0751	.8676	.8676	1.0562	.8745	1.0562
8	1.226	1.1694	.8299	.9054	1.0185	1.0288	1.1317
9	1.4335	1.1506	.9808	.9619	1.2449	1.0802	1.0562
10	1.3957	1.2696	1.1506	1.0082	1.1145	1.1949	1.2323
11	1.4523	1.3443	1.0829	1.0829	1.1317	1.1949	1.3014
12	1.4335	1.307	1.2136	1.0829	1.1145	1.3443	1.1706
13	1.4712	1.2696	1.2449	1.0456	1.1317	1.307	1.2272
14	1.358	1.307	1.1506	1.1576	1.1317	1.3443	1.3216
15	1.3769	1.3443	1.1883	1.1949	1.1317	1.307	1.2839
16	1.358	1.3817	1.1576	1.1949	1.1488	1.2696	1.3783
17	1.4712	1.3817	1.1576	1.2323	1.0974	1.2696	1.2084
18	1.3957	1.3817	1.1506	1.3817	1.2174	1.3443	1.2461
19	1.6598	1.5089	1.2136	1.5089	1.3546	1.419	1.3594
20	1.5844	1.5466	1.3014		1.3889	1.3817	1.3405
21	1.5278	1.5089	1.3014	1.5089	1.3546	1.358	1.3028
22	1.4901	1.3203	1.2883	1.4335	1.3032	1.3203	1.265
23	1.3769	1.2449	1.1317	1.3957	1.1488	1.2449	1.2461
24	1.226	1.226	1.094		1.2071	1.0288	1.1694
Max	1.6598	1.5466	1.3014	1.5089	1.3889	1.419	1.3783
Min	.9808	.9808	.8299	.8676	1.0185	.8573	1.0562
Avg	1.3054	1.2445	1.0886	1.1325	1.1577	1.1554	1.2010

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

ISHWAR NAGAR S/DN.[732] BU 4732

Substation No/ Name :- 113024 / M&B

Feeder No / Name : 201 / MMRDA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7095		.7811	.7842	.7095	.6097
2		.7095		.7811	.7842	.6722	.4954
3		.6722		.6859	.7095	.6722	.4954
4		.6908		.6859	.7468	.6722	.5525
5		.6908		.6859	.7468	.7095	.5716
6		.8215		.743	.7842	.7468	.6478
7		.8962		.8002	.8589	.8589	.7811
8	1.0456	.9335		.8764	1.0456	1.0456	.8383
9	1.1016	.9709		1.0288	1.0829	1.0456	
10	1.1576	1.1203	1.105	1.1203	1.1949	1.105	
11	1.1576	1.0829	1.105	1.0829	1.1949	.8764	.7468
12	1.2323	1.0456	1.105	.9896	1.1203	.8764	.7095
13	1.0456	1.0456	.9907	.9335	1.0456	.7621	.7095
14	.9709	1.0082	.9907	.9149	1.0456	.724	
15	1.0642	.9335		.8589	1.0456	.724	.6348
16	1.0082	.9709	.9526	.8215	.9335	.6478	
17	1.1203	.9335	1.0288	.9709	1.0082	.724	.6348
18	1.2323	1.1576	1.1431	1.1576	1.1203	.8764	.7842
19	1.3817	1.2696	1.2574	1.2696	1.307	.9907	
20	1.419	1.2696	1.2955	1.307	1.2696	1.105	
21	1.3817	1.2696	1.3336	1.307	1.3817	1.105	1.0456
22	1.2323	1.1949	1.2003	1.2323	1.1949	.9526	
23	1.0082	.9709	.9717	1.0269	1.0082	.8002	
24		.9335	.8215	.8002	.8589	.8215	.6287
Max	1.419	1.2696	1.3336	1.307	1.3817	1.105	1.0456
Min	.9709	.6722	.8215	.6859	.7095	.6478	.4954
Avg	1.1599	.9709	1.0929	.9526	1.0113	.8427	.6804

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

ISHWAR NAGAR S/DN.[732] BU 4732

Substation No/ Name :- 113024 / M&B

Feeder No / Name : 202 / Neptune

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1867		.2286	.1494	.1494	.1143
2		.1867		.2286	.112	.1494	.1143
3		.1494		.2477	.0747	.1494	.1143
4		.0934		.2286	.0373	.1494	.1143
5		.0934		.2286	.0373	.1494	.1334
6		.112		.2477	.0747	.1494	.1524
7		.112		.1334	.1867	.2241	.1905
8	.3921	.2987		.2477	.3921	.2987	.2667
9	.3921	.3361		.362	.3361	.4481	
10	.3734	.4481	.381	.3361	.3734	.4191	
11	.2987	.2241	.4001	.3734	.4108	.3429	.2987
12	.3734	.2614	.3429	.3174	.3361	.3048	.2614
13	.1867	.2614	.381	.2987	.1494	.3239	.3361
14	.2987	.2987	.2667	.3361	.2614	.1143	
15	.168	.2987	.2286	.2241	.2614	.1334	.2614
16	.2614	.2614	.2096	.2241	.2614	.1524	
17	.1867	.2801	.1905	.2987	.2614	.1524	.2427
18	.2987	.2987	.3429	.1867	.2614	.1524	.2241
19	.1867	.2801	.381	.1867	.2987	.3239	
20	.1867	.2241	.3048	.112	.2241	.362	
21	.3734	.2987	.3429	.2241	.2987	.3048	.2987
22	.3395	.2987	.3239	.1867	.3361	.2858	
23	.2614	.2241	.3239	.2987	.2241	.1715	
24		.2241	.1867	.3048	.1867	.1867	.1334
Max	.3921	.4481	.4001	.3734	.4108	.4481	.3361
Min	.168	.0934	.1867	.112	.0373	.1143	.1143
Avg	.2861	.2396	.3071	.2526	.2311	.2332	.2035

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

ISHWAR NAGAR S/DN.[732] BU 4732

Substation No/ Name :- 113024 / M&B

Feeder No / Name : 209 / Hanuman silk mills

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4108		.1905	.3734	.3734	.362
2		.3734		.1715	.3361	.3361	.3048
3		.3734		.1905	.3361	.3174	.3048
4		.3547		.1905	.2987	.2987	.3239
5		.3734		.1905	.2987	.2987	.3429
6		.3734		.1905	.2987	.3361	.3429
7		.3734		.3048	.3361	.3174	.362
8	.4481	.4108		.381	.4294	.3734	.4191
9	.5228	.4854		.4572	.5228	.4854	
10	.7842	.7468	.5335	.6722	.7468	.8002	
11	.8215	.8215	.5335	.7095	.8962	.8764	.8402
12	.8962	.8589	.5716	.7842	.8962	.9526	.8402
13	.8589	.7842	.5335	.7468	.8589	.8002	.8029
14	.8962	.8589	.6097	.8029	.9335	.9526	
15	.9522	.8589	.5716	.8589	.9335	.8764	.9709
16	.9335	.8962	.5525	.7842	.8589	.9526	
17	.8962	.8962	.4954	.8215	.8962	.9526	.9522
18	.8962	.8589	.4954	.8589	.8589	.8764	.8589
19	.7842	.7468	.4954	.7468	.8215	.7811	
20	.6722	.6348	.381	.5975	.6348	.6097	
21	.5601	.5975	.4572	.5601	.5228	.5716	.5601
22	.5228	.5601	.381	.5228	.4854	.4954	
23	.4854	.4481	.381	.4668	.4481	.4763	
24		.4481	.4481	.362	.4481	.3921	.4572
Max	.9522	.8962	.6097	.8589	.9335	.9526	.9709
Min	.4481	.3547	.381	.1715	.2987	.2987	.3048
Avg	.7457	.6060	.4960	.5234	.6029	.6043	.5653

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

ISHWAR NAGAR S/DN.[732] BU 4732

Substation No/ Name :- 113024 / M&B

Feeder No / Name : 212 / Prestine

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.307		1.0288	1.1949	1.1949	1.2384
2		1.2323		.9907	1.1576	1.1576	1.2384
3		1.1576		.9907	1.1203	1.2136	1.2193
4		1.1763		.9907	1.1949	1.1576	1.1431
5		1.1576		.9907	1.2323	1.1763	1.1622
6		1.2696		1.0288	1.2696	1.2323	1.1812
7		1.2696		1.0669	1.1949	1.2696	1.3717
8	1.5123	1.3817		1.2574	1.419	1.4563	1.4098
9	1.7924	1.4563		1.5242	1.8298	1.8298	
10	2.0538	1.7924	1.5242	1.643	2.2405	2.1719	
11	2.0911	1.8671	1.5623	1.6804	2.0911	2.1338	2.0165
12	2.0538	1.9044	1.5242	1.6804	2.0911	2.1719	2.0538
13	1.9791	1.643	1.4098	1.419	1.9418	1.9052	1.8298
14	1.9044	1.643	1.3717	1.4563	1.7924	2.0957	
15	2.0725	1.5684	1.3717	1.531	2.0165	2.1148	1.9605
16	1.9791	1.643	1.2955	1.531	1.9418	2.0957	
17	2.0538	1.7177	1.2955	1.531	1.9044	2.0957	1.9605
18	1.8671	1.8671	1.4098	1.643	2.0165	2.1719	2.0351
19	1.8671	1.9044	1.5242	1.7924	2.0911	2.1338	
20	1.7551	1.8298	1.5242	1.7551	2.0538	2.1338	
21	1.643	1.6057	1.448	1.6057	1.8298	1.9433	1.6804
22	1.4937	1.531	1.2003	1.4937	1.6057	1.6004	
23	1.2323	1.4563	1.1812	1.3817	1.419	1.4098	
24		1.2696	1.3817		1.2696	1.3443	1.3527
Max	2.0911	1.9044	1.5623	1.7924	2.2405	2.1719	2.0538
Min	1.2323	1.1576	1.1812	.9907	1.1203	1.1576	1.1431
Avg	1.8344	1.5271	1.4016	1.3919	1.6633	1.7171	1.5533

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

ISHWAR NAGAR S/DN.[732] BU 4732

Substation No/ Name :- 113029 / SOLARIES RECIEVING SUB

STATION

Feeder No / Name : 201 / SHIV SAKTI NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954					.4572	
5	.4572	.4338					
6	.5228	.4527					.4904
7	.547	.5093	.4481	.4668	.4854	.4904	.5093
8	.5281	.5093		.4294	.4854	.5281	.5281
9	.5093	.5228	.2241	.4668	.4854	.5281	.5228
10	.4854	.5228	.4481	.5041	.5041		.4854
11	.4668	.5228	.5041	.4854	.5041	.4904	.4668
12	.5041	.4715	.5228	.5041	.5041	.4904	.4668
13	.4668	.4668	.5041		.4668	.4854	.4481
14	.4854			.4668	.4481	.4668	.4481
15	.4294	.4481		.4294	.4668	.4338	.4338
16	.415	.4481	.4668	.4294	.3921	.415	.415
17	.4481	.4668	.4854	.4294	.4338	.4527	.4338
18	.5415		.5415	.5228	.4854	.4904	.4904
19	.6161	.6348	.6535	.6535	.6099	.5975	.5658
20	.6348	.6722	.6348	.6535	.6283	.6161	.5658
21	.6767		.5975	.6348	.6348	.6535	.5847
22	.6584	.5788		.6161	.6161	.6535	.6036
23	.5914		.5041	.5228	.4904		.5335
24	.5093	.5228	.5041	.4854			.5093
Max	.6767	.6722	.6535	.6535	.6348	.6535	.6036
Min	.415	.4338	.2241	.4294	.3921	.415	.415
Avg	.5233	.5115	.5028	.5118	.5083	.5156	.5001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

ISHWAR NAGAR S/DN.[732] BU 4732

Substation No/ Name :- 113029 / SOLARIES RECIEVING SUB

STATION

Feeder No / Name : 202 / SOLARIS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667					.2667	
5	.2477	.2477					
6	.2477	.2477					.2477
7	.2286	.2286	.2241	.2054	.2241	.2477	.2286
8	.3018	.2858		.2241	.2801	.2858	.3048
9	.4715	.3584	.6535	.2614	.4108	.4527	.4904
10	.6348	.5601		.3734	.6722	.6161	.6535
11	.7762	.6161	.3174	.4108	.7947	.8316	.7762
12	.8316	.6413	.2987	.4668	.7316	.8131	.7947
13	.7865	.6535	.3174		.7762	.7577	.7577
14	.7207			.4294	.8029	.7865	.7682
15	.8413	.6535		.5228	.8048	.7762	.8048
16	.8131	.6161	.2801	.4668	.7865	.7762	.823
17	.7577	.5601	.2801	.5041	.8131	.7762	.8131
18	.7095		.3174	.5041	.7207	.7095	.6979
19	.547	.4294	.2614	.3921	.5093	.5788	.5658
20	.4001	.3734	.2801	.3174	.4191	.4191	.4001
21	.3429		.2427	.2427	.3048	.3429	.3429
22	.3239	.8962		.2801	.2667	.2858	.2858
23	.2858		.2427	.2614	.2858		.2858
24	.2667	.2667	.2801	.2427	.2801	.2858	.2858
Max	.8413	.8962	.6535	.5228	.8131	.8316	.823
Min	.2286	.2286	.2241	.2054	.2241	.2477	.2286
Avg	.5144	.4772	.3074	.3591	.5491	.5560	.5435

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

ISHWAR NAGAR S/DN.[732] BU 4732

Substation No/ Name :- 113029 / SOLARIES RECIEVING SUB

STATION

Feeder No / Name : 203 / FAIR DEAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7167					.7167	
5	.6722	.6224					
6	.7282	.7095					.6722
7	.7842	.7468	.6722	.6908	.7095	.7655	.7655
8	.7655	.7282		.6722	.7282	.7655	.7468
9	.7282	.7468	.6908	.2614	.7468	.7842	.7468
10	.8131	.7762		.7842	.7842	.7762	.7282
11	.7577	.7655	.8029	.7655	.7655	.7392	.7207
12	.8131	.811	.7655	.1307	.7207	.7282	.7095
13	.7762	.6722			.7392	.6908	.6722
14	.6838			.7655	.7392	.7207	.7207
15	.6653	.6535		.7468	.6653	.6535	.6535
16	.6161	.6161	.5788	.6722	.6161	.6722	.6161
17	.6838	.5335	.6908	.6908	.6535	.6908	.6161
18	.7207		.7468	.7468	.7207	.7282	.6979
19	.8686	.8589	.9149	.8775	.9055	.8316	.8402
20	.9511	.8962	.8962	.9149	.9145	.8871	.8589
21	.8962		.8775	.8775	.8871	.9055	.8402
22	.9145	.8962		.8775	.8316	.8686	.8402
23	.8962		.7842	.8402	.8589		.8402
24	.7468	.8131	.2614	.7468	.7282	.8029	.7842
Max	.9511	.8962	.9149	.9149	.9145	.9055	.8589
Min	.6161	.5335	.2614	.1307	.6161	.6535	.6161
Avg	.7713	.7404	.7235	.7095	.7619	.7626	.7405

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

ISHWAR NAGAR S/DN.[732] BU 4732

Substation No/ Name :- 113029 / SOLARIES RECIEVING SUB

STATION

Feeder No / Name : 204 / NEW AXIS BANK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334					.1334	
5	.1334	.1334					
6	.1334	.1334					.1334
7	.1334	.1334	.1307	.1307	.112	.1334	.1334
8	.1334	.1334		.1307	.112	.1334	.1334
9	.1334	.1334	.1307	.1307	.112	.2641	.1905
10	.1905	.1334		.1307	.3018	.2641	.2452
11	.2829	.1307	.1307	.1307	.2829	.2829	.2829
12	.2829	.132	.1307	.1307	.2829	.3018	.3018
13	.3018	.1307	.1307		.3018	.2829	.2829
14	.3018			.112	.3018	.3018	.2829
15	.3018	.168		.112	.3018	.2829	.2829
16	.3018	.168	.1307	.1307	.2829	.2829	.2829
17	.2829	.168	.1307	.1307	.2829	.2858	.2829
18	.2452		.1307	.1307	.2477	.2667	.2667
19	.2286	.1307	.1307	.112	.2286	.2477	.2477
20	.1905	.1307	.1307	.112	.1905	.1905	.1905
21	.1524		.1307	.112	.1524	.1524	.1334
22	.1524	.1307		.112	.1334	.1334	.1334
23	.1334		.1307	.112	.1334		.1334
24	.1334	.1334	.1307	.1307	.112	.1334	.1334
Max	.3018	.168	.1307	.1307	.3018	.3018	.3018
Min	.1334	.1307	.1307	.112	.112	.1334	.1334
Avg	.2039	.1390	.1307	.123	.2152	.2263	.2144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113012 / NBRS

Feeder No / Name : 202 / NEELA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4668	.3292	.3734	.4338	.3841	.3292
2	.4207	.4294	.3142	.3206	.3734	.3658	.3292
3	.4024	.3921	.2957	.2987	.3734	.3475	.3109
4	.3841	.3772	.2957	.3206	.3658	.3109	.3142
5	.4024	.3734	.3326	.3395	.3547	.2926	.2957
6	.3841	.3961	.3511	.3361	.3584	.3292	.2957
7	.3841	.4108		.3174	.3734	.3292	.2926
8	.439	.4338		.3584	.3361	.3475	.3439
9	.5601	.5611	.5041	.4715	.567	.5121	.5228
10	.7133	.6447	.5359	.6401	.7682	.7059	.5853
11	.905	.8145	.6283	.8775	.8962	.8596	.7421
12	.9877	.9412	.6767	.8413	.8962	.905	.7865
13	.8413	.7783	.6838	.7468	.7682	.8413	.7682
14	.7865	.9145	.7023	.7095	.7865	.8145	.7865
15	.9694	.9145	.6468	.8962	.8779	.8688	.8596
16	.9231	.9231	.6468	.8962	.8413	.9328	.9231
17	.905	.9412	.6283	.8589	.8962	.9412	.9145
18	.9694	.8779	.5041	.8048	.8413	.8869	.8507
19	.9412	.8779	.5359	.7865	.7865	.8779	.8596
20	.9145	.823	.5975	.8048	.7682	.8048	.7865
21	.7865	.7316	.5041	.7655	.6219	.7316	.7865
22	.6099	.6219	.5041	.6722	.5121	.5121	.5914
23	.056	.4572	.4481	.5041	.4755	.4572	.4854
24	.439	.5041	.3841	.4481	.4572	.4207	.4024
Max	.9877	.9412	.7023	.8962	.8962	.9412	.9231
Min	.056	.3734	.2957	.2987	.3361	.2926	.2926
Avg	.6492	.6503	.5022	.5995	.6137	.6158	.5901

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113012 / NBRS

Feeder No / Name : 203 / SOHEL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6908	.7282	.7545	.6099	.6535	.7095	.6413
2	.6722	.6838	.7356	.5544	.6413	.6722	.6602
3	.6722	.6653	.6979	.5487	.6348	.6348	.6224
4	.6908	.6401	.6602	.5304	.6535	.6348	.6036
5	.6535	.6468	.6224	.5175	.6348	.5975	.5658
6	.7095	.7095	.6413	.6468	.679	.6348	.6413
7	.8775	.7468		.6348	.7095	.8215	.7356
8	.9709	.8299		.8676	.8962	.9896	.9242
9	1.2637	1.1389	.9619	1.0269	1.1317	1.2826	1.2449
10	1.7551	1.7177	1.1317	1.4083	1.6409	1.7353	1.6409
11	1.9044	1.8484	1.1576	1.8111	1.8111	1.905	1.8298
12	2.0538	1.9231	1.1763	1.6827	1.9231	1.8858	1.8484
13	1.5524	1.5497	1.0829	1.3817	1.5655	1.4901	1.5497
14	1.7177	1.6804	1.1506	1.6057	1.8111	1.8484	1.6991
15	1.8298	1.7924	1.1317	1.5912	1.9044	1.8484	1.8298
16	1.8665	1.8111	1.0456	1.7364	1.8671	1.643	1.7372
17	1.885	1.8298	.9054	1.643	1.7924	1.7918	1.7924
18	1.6057	1.6244	.8962	1.4632	1.643	1.6617	1.5684
19	1.5684	1.4523	.9997	1.4377	1.531	1.5278	1.4784
20	1.363	1.358	.9431	1.1949	1.2696	1.3203	1.2323
21	1.0829	1.0562	.9431	1.0082	1.0829	1.1128	1.0562
22	1.0185	1.0374	.9242	.9149	.9709	1.0562	.9522
23	.9054	.9054	.8676	.8299	.8589	.9619	.8676
24	.8589	.8775	.7733	.7468	.8402	.8215	.8488
Max	2.0538	1.9231	1.1763	1.8111	1.9231	1.905	1.8484
Min	.6535	.6401	.6224	.5175	.6348	.5975	.5658
Avg	1.2570	1.2189	.9183	1.0997	1.2144	1.2328	1.1904

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113012 / NBRS

Feeder No / Name : 204 / ASIAN PAINTS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.2656	.3206	.2469	.2987	.3018	.3206
2	.3018	.2656	.3206	.2172	.2263	.3018	.3018
3	.3018	.2408	.3018	.2229	.1886	.3018	.3018
4	.3018	.2286	.3018	.2286	.1829	.3018	.3018
5	.3018	.2225	.3018	.2195	.1886	.3018	.3018
6	.3018	.2317	.3018	.2347	.1677	.3018	.3018
7	.3206	.2591		.2172	.3174	.3018	.3018
8	.3584	.2846		.2559	.3292	.3395	.3395
9	.4161	.4338	.25	.3547	.3961	.4715	.3239
10	.6908	.6224	.285	.6219	.6036	.6036	.5729
11	.7167	.7468	.2947	.7095	.6413	.679	.6348
12	.8299	.7356	.3439	.7316	.7545	.7545	.6602
13	.6602	.547	.3511	.7468	.6036	.6036	.5729
14	.6979	.7356	.3189	.7133	.7545	.7356	.6979
15	.8488	.7545	.4066	.7133	.7922	.6908	.7167
16	.7545	.7167	.3155	.7499	.7167	.7356	.7922
17	.8488	.6602	.285	.7282	.7356	.7545	.6979
18	.679		.2591	.6219	.5847	.6413	.6413
19	.5601	.5847	.2622	.6161	.5658	.5658	.5788
20	.499	.4338	.253	.4854	.4338	.4527	.4805
21	.333	.3772	.2591	.3547	.3395	.3772	.3544
22	.3077	.3395	.2439	.3361	.3206	.3584	.3185
23	.2656	.3206	.2378	.3206	.3018	.3206	.2949
24	.3206	.2623	.3206	.2591	.3018	.3018	.3206
Max	.8488	.7545	.4066	.7499	.7922	.7545	.7922
Min	.2656	.2225	.2378	.2172	.1677	.3018	.2949
Avg	.4966	.4465	.2970	.4544	.4477	.4791	.4637

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113012 / NBRS

Feeder No / Name : 205 / SHIV COLD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.6413	.6219	.4904	.5601	.5121	.567
2	.5853	.6535	.6584	.5041	.5093	.5121	.5121
3	.5853	.6224	.6099	.4854	.5228	.4938	.4805
4	.6219	.5975	.5729	.5093	.5228	.4938	.499
5	.695	.6161	.5415	.5228	.5658	.5121	.5601
6	.6219	.6348	.5544	.5415	.6161	.6401	.5415
7	.6219	.5601		.4854	.5975	.6036	.6584
8	.7865	.6036		.6036	.6401	.7499	.7499
9	1.1203	.8962	.6908	.9328	1.134	1.2071	1.1458
10	1.8473	1.5746	.8501	1.4563	1.7558	1.829	1.7558
11	2.0814	1.8625	.961	1.8298	2.0851	2.0814	2.0271
12	2.1765	1.9366	1.0242	1.9044	2.1948	2.009	2.2081
13	1.7187	1.5546	.924	1.4003	1.5729	1.701	1.7924
14	2.0328	1.9387	.8686	1.5546	2.0485	1.9936	2.0119
15	2.0851	1.9547	.9425	1.6817	2.0119	2.0452	2.1033
16	2.19	1.9753	.8686	1.7193	1.6278	2.0814	2.1765
17	2.1538	1.9936	.8402	1.848	1.7193	2.0814	2.0633
18	1.8823	1.7741	.7842	1.5123	1.4632	1.8107	1.7375
19	1.5364	1.3717	.7095	1.0974	1.2437	1.4083	1.4449
20	1.1273	1.0059	.6224	.8402	.8779	1.0425	.9928
21	.8402	.7733	.5415	.7095	.8048	.8413	.7577
22	.7655	.6838	.5093	.5853	.7316	.6767	.7655
23	.5601	.6219	.5093	.6036	.6219	.6401	.6348
24	.5121	.5658	.7023	.6036	.6722	.6401	.5121
Max	2.19	1.9936	1.0242	1.9044	2.1948	2.0814	2.2081
Min	.5121	.5601	.5093	.4854	.5093	.4938	.4805
Avg	1.2373	1.1422	.7231	1.0176	1.1292	1.1919	1.1958

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113012 / NBRS

Feeder No / Name : 206 / Advani

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189		.0189		.0189	.0189
2	.0189		.0189		.0189	.0189
3	.0189		.0189		.0189	.0189
4	.0189		.0189		.0189	.0189
5	.0189		.0189		.0189	.0189
6	.0189		.0189		.0189	.0189
7	.0189				.0189	.0189
8	.0189				.0189	.0189
9				.0189	.0189	
10		.0189		.0189	.0189	
11		.0189		.0189	.0189	
12		.0189		.0189	.0189	
13		.0189		.0189	.0189	
14		.0189		.0189	.0189	
15		.0189		.0189	.0189	
16		.0189		.0189	.0189	
17		.0189		.0189	.0189	
18		.0189		.0189	.0189	
19		.0189		.0189		
20		.0189		.0189	.0189	
21		.0189		.0189	.0189	
22		.0189		.0189	.0189	
23		.0189		.0189	.0189	
24	.0189		.0189		.0189	.0189
Max	.0189	.0189	.0189	.0189	.0189	.0189
Min	.0189	.0189	.0189	.0189	.0189	.0189
Avg	.0189	.0189	.0189	.0189	.0189	.0189

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113012 / NBRS

Feeder No / Name : 207 / Inamdar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4755	.181	.4572	.4338	.4668	.4572	.2195
2	.4755	.1629		.415	.4527	.439	.1829
3	.4755	.1612		.415	.4481	.439	.2012
4	.439	.1646		.3961	.4294	.4207	.2378
5	.439	.0532		.3961	.4108	.3841	.2218
6	.4755	.1612		.3772	.4294	.4207	
7	.4938	.1629		.4338	.4481	.439	.1829
8	.5304	.1829		.4527	.5041	.5304	.1829
9	.7655	.1629	.5415	.6413	.7682	.7499	.2054
10	.9955	.3077	.6283	.8048	.9328	.9412	.362
11	1.0454	.3109	.7392	.9709	1.0059		.3403
12		.394	.7023	1.0059	1.0608	.3801	.3544
13	.2561	.1991	.6283	.7655	.811	.2926	.3109
14	.3658	.3258	.6838	.8589	.9145	.3292	.9145
15	.3761	1.0425	.5914	.9709	1.0059	.3801	.9955
16	.3761	.9774	.5853	.9149	.9511	.3801	1.0029
17	.3544	.9231	.4805	1.0269	.9877	.3982	1.0029
18	.3045	.9877	.5041	.9145	1.0059	.3475	.9412
19	.2686	.8779	.5601	.8596	1.0242	.3077	.9671
20	.3045	.8507	.5788	.8775	.8779	.3109	.8326
21	.2926	.695	.547	.6348	.6767	.2926	.6697
22	.2033	.6036	.5281	.5975	.6219	.2926	.5601
23	.1867	.5304	.5093	.5415	.5487	.2926	.5658
24	.5121	.1829	.4938	.4527	.5041	.4938	.2926
Max	1.0454	1.0425	.7392	1.0269	1.0608	.9412	1.0029
Min	.1867	.0532	.4572	.3772	.4108	.2926	.1829
Avg	.4527	.4417	.5741	.6732	.7203	.4226	.5107

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113012 / NBRS

Feeder No / Name : 208 / NAHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4335	1.3466	1.5278	1.3112	1.4003	1.4146	1.4335
2	1.3957	1.4148		1.2445	1.4901	1.358	1.4146
3	1.358	1.3289		1.2934	1.4712	1.3203	1.3769
4	1.358	1.2795		1.1789	1.475	1.2826	1.358
5	1.3957	1.3112		1.2136	1.4937	1.2449	1.3957
6	1.3014	1.3466		1.1919	1.4937	1.2637	1.4712
7	1.4523	1.4506		1.2226	1.531	1.4146	1.3957
8	1.6975	1.6827		1.4685	1.7924	1.6598	2.0182
9	1.8665	2.0182	1.6644	2.0165	1.9993	2.0182	2.0538
10	2.6217	2.8292	2.2592	2.7915	2.7726	2.4897	2.8104
11	2.9424	2.999	2.3011	2.8567	4.9228	2.6217	2.5463
12	2.8292	2.8481	2.6029	2.9264	2.999	2.9235	3.0367
13	2.2965	2.2068	2.0911	2.5019	2.3388	2.3954	2.6972
14	2.5086	2.1285	2.2592	2.6886	2.5274	2.4459	2.7538
15	2.6595	2.8481	2.0911	2.8193	2.7726	2.8481	3.0367
16	2.6406	2.7915	2.1691	2.894	3.2065	2.9424	3.2065
17	2.9047	2.6972	1.8298	3.0178	2.9235	2.6972	3.1499
18	2.8481	2.7538	1.9605	2.9264	2.9424	2.8669	3.2253
19	2.8669	2.3388	1.9418	2.5789	3.1121	2.5463	2.9801
20	2.7161	2.6595	2.1313	2.6139	2.7349	2.6783	2.7349
21	2.0911	2.0559	1.8298	2.2592	1.9753	1.9239	2.0725
22	1.7926	1.8861	1.4842	1.8671	2.0748	2.0182	1.8858
23	1.6644	1.7541	1.5927	1.8673	1.6975	1.7541	1.8111
24	1.5466	1.4299	1.4523	1.4148	1.4563	1.5655	1.8296
Max	2.9424	2.999	2.6029	3.0178	4.9228	2.9424	3.2253
Min	1.3014	1.2795	1.4523	1.1789	1.4003	1.2449	1.358
Avg	2.0912	2.0586	1.9523	2.0902	2.2751	2.0706	2.2373

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113012 / NBRS

Feeder No / Name : 209 / TITAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8779	.8488	.8869	.7167	.9335	.8048	.8048
2	.8413	.811	.8596	.679	.8048	.8048	.7865
3	.8048	.7922	.8048	.6348		.7682	.7762
4	.823	.7545	.7842	.6036	.7842	.8048	.7392
5	.6401	.679	.7468	.5788	.724	.7499	.7577
6	.8413	.7922	.7167	.6535	.7655	.823	.8131
7	1.0974	.9054		.7095	.8962	.905	.9328
8	1.0425	.9808		.8299	.9709	1.0425	1.134
9	1.2254	1.3575	1.0082	1.1128	1.1888	1.3073	1.3443
10	1.5339	1.5203	1.3676	1.4815	1.6278	1.6651	1.6461
11	1.6448	1.5203	1.2986	1.6057	1.6461	1.7558	1.7375
12	1.4815	1.7193	1.3169	1.6827	1.4449	1.6832	1.7194
13	1.307	1.3535	1.2012	1.1888	1.0608	1.1403	1.5203
14	1.3121	1.3432	1.2382	1.3817	1.3169	1.2178	1.3575
15	1.4415	1.4864	1.2012	1.6409	1.4815	1.3073	1.5912
16	1.2986	1.5023	1.1643	1.475	1.5181	1.3253	1.4842
17	1.5339	1.4661	.9896	1.4632	1.5364	1.4449	1.5384
18	1.4998	1.5402	.9896	1.39	1.4998	1.4118	1.5912
19	1.6263	1.5043	1.1389	1.6991	1.5729	1.5364	1.5364
20	1.5708	1.5546	.9149	1.4815	1.4449	1.448	1.423
21	1.307	1.2437	.8029	1.2696	1.1888	1.2894	1.2752
22	1.1389	1.0791	.7922	1.134	1.0242	1.1157	1.1203
23	.9709	.9511	.7545	.9896	.8962	.9145	.9335
24	.924	.9522	.8596	.7545	.9145	.8048	.8869
Max	1.6448	1.7193	1.3676	1.6991	1.6461	1.7558	1.7375
Min	.6401	.679	.7167	.5788	.724	.7499	.7392
Avg	1.1994	1.1941	.9926	1.1315	1.1844	1.1696	1.2271

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113012 / NBRS

Feeder No / Name : 212 / Samarth Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189		.0183		.0189	.0183
2	.0189		.0183		.0189	.0183
3	.0189		.0181		.0189	.0181
4	.0189		.0185		.0189	.0183
5	.0189		.0185		.0189	.0183
6	.0189		.0185		.0189	.0183
7	.0189				.0189	.0183
8	.0189				.0189	.0183
9				.0189	.0181	
10		.0183		.0189	.0181	
11		.0181		.0189	.0183	
12		.0183		.0189		
13		.0724		.0189	.0183	
14		.0181		.0189	.0181	
15		.0179		.0189	.0181	
16		.0181		.0189	.0181	
17		.0181			.0181	
18		.0181		.0189	.0181	
19		.0181		.0189	.0183	
20		.0181		.0189	.0183	
21		.0181		.0189	.0181	
22		.0183		.0189	.0183	
23		.0183		.0189	.0183	
24	.0754		.0183		.0189	.0183
Max	.0754	.0724	.0185	.0189	.0189	.0183
Min	.0189	.0179	.0181	.0189	.0181	.0181
Avg	.0252	.0220	.0184	.0189	.0185	.0183

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113012 / NBRS

Feeder No / Name : 213 / FILIX

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2075	.1463	.1509	.1463	.112	.1509	.1509
2	.2075	.1646		.1478	.1132	.1509	.1509
3	.1509	.1646		.1097	.1132	.1509	.1509
4	.132	.1267		.1097	.112	.1132	.1509
5	.132	.1267		.1086	.112	.1132	.1509
6	.132	.1267		.1086	.112	.1132	.1509
7	.1509	.1463		.1086	.1509	.132	.1509
8	.1886	.1829		.1086	.1829	.1886	.1463
9	.3174	.3018	.1478	.1494		.3584	.2801
10	.6224	.3961	.1494	.3361	.547	.679	.5658
11	.679	.6722	.3174	.4668	.7545	.6979	.7167
12	.6413	.5281	.2829	.4207	.679	.6413	.6602
13	.5847	.4668	.2801	.4163	.6224	.6413	.415
14	.6036	.4527	.2987	.4207	.6036	.6413	.5658
15	.6401	.5847	.2427	.4481	1.0374	.6348	.6584
16	.6224	.5281	.2218	.4108	.7733	.6602	.6602
17	.5847	.3584	.2801	.3734	.6602	.5041	.6036
18	.5093	.3206	.2801	.2926	.5847	.4527	.4527
19	.3361	.3206	.2614	.3174	.4338	.3584	.3395
20	.3174	.3018	.2427	.2614	.3584	.3018	.2801
21	.2614	.2829	.2054	.2263	.2829	.3018	.2427
22	.2218	.2641	.1848	.1867	.2641	.3018	.2402
23	.1663	.2075	.1663	.1463	.2263	.3018	.2033
24	.2075	.1463	.2075	.1478	.112	.1886	.3018
Max	.679	.6722	.3174	.4668	1.0374	.6979	.7167
Min	.132	.1267	.1478	.1086	.112	.1132	.1463
Avg	.3590	.3049	.2306	.2487	.3890	.3658	.3495

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113031 / RUNWAL

Feeder No / Name : 202 / Runwal Green-II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.2263	.2075	.2075	.2263	.2263	.1886
2	.1886	.2075	.1698	.2075	.1886	.2075	.2075
3	.1886	.2075	.1886	.2075	.1886	.2075	.2075
4	.1698	.1886	.1886	.1886	.1698	.1886	.1886
5	.1509	.1886	.1698	.1698	.1698	.1886	.1698
6	.132	.1698	.1886	.1698	.1509	.1698	.1886
7	.1698	.1886	.2075	.1698	.1509	.1886	.1509
8	.1886	.1886	.1886	.1886	.2263	.2641	.1698
9	.3018	.3395	.2075	.2641	.2641		.1886
10	.2829	.2452	.2452	.2829	.2829	.2263	.2829
11	.3018	.3206	.2641	.3206	.3018	.3018	.2075
12	.2829	.3395	.2452	.3772	.2641	.2452	.2075
13	.2829	.3395	.2641	.3772	.2829	.2075	.2075
14	.2075	.2452	.3018	.3206	.2452	.1886	.2075
15	.3206	.2829	.3395	.3018	.2263	.2641	.1886
16	.3395	.2452	.3018	.2641	.3018	.2452	.2075
17	.2829	.2641	.2263	.3206	.3584	.2075	.2263
18	.3018	.3206	.3206	.3395	.3584	.2263	.2452
19	.2641	.3206	.3584	.3772	.3018	.2641	.2641
20	.3395	.3018	.3772	.3961	.3018	.3018	.2829
21	.3018	.3018	.3109	.3395	.2829	.2641	.2641
22	.3395	.3772	.3018	.3206	.2452	.2452	.2829
23	.3018	.3584	.3018	.3206	.2263	.2263	.1698
24	.2641	.2263	.3395	.2263	.2641	.2452	.1698
Max	.3395	.3772	.3772	.3961	.3584	.3018	.2829
Min	.132	.1698	.1698	.1698	.1509	.1698	.1509
Avg	.2531	.2664	.2589	.2774	.2491	.2304	.2114

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113036 / HDIL

Feeder No / Name : 201 / Khalasa Compound

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3696	.3734	.3547	.2829	.3696	.3772	.3772
2	.3734	.3511	.3734	.3018	.3547	.3584	.3395
3	.3772	.3547	.3395	.3206	.3361	.3395	.3361
4	.3584	.3395	.3206	.2587	.3142	.3206	.2987
5	.3395	.3174	.2987	.2743	.3109	.3018	.2772
6	.3584	.3142	.3696	.2561	.3292	.3395	.3326
7	.415	.3258	.3326	.2987	.298	.3772	.3734
8	.4527	.3582	.3018	.2614	.4207	.415	.3658
9	.5571	.5601	.3547	.4557	.5959	.5601	.5853
10	.7202	.7023	.4481	.6516	.631	.7468	.8402
11	.78	.8676	.4338	.6241	.7362	.8402	.8402
12	.8059	.8299	.4108	.6762	.7712	.8865	.8589
13	.6485	.7392	.4481	.5847	.6661	.679	.695
14	.7186	.7682	.4108	.631	.7362	.7392	.8048
15	.8149	.7842	.3881	.7108	.7712	.8501	.7499
16	.8059	.8215	.3696	.6588	.7712	.8413	.7842
17	.7802	.8488	.3734	.6344	.7362	.7842	.7682
18	.7537	.7762	.2987	.6485	.7011	.7392	.7316
19	.6687	.6653	.2957	.5895	.631	.7392	.6767
20	.6024	.5975	.2614	.4908	.5373	.5601	.5601
21	.4525	.4108	.2561	.3544	.4024	.5175	.3841
22	.4024	.3734	.2743	.362	.3696	.5175	.3921
23	.3982	.3772	.2534	.3841	.3696	.4527	.3658
24	.3841	.3841	.3772	.2641	.3841	.3696	.3734
Max	.8149	.8676	.4481	.7108	.7712	.8865	.8589
Min	.3395	.3142	.2534	.2561	.298	.3018	.2772
Avg	.5557	.5517	.3477	.4573	.5227	.5689	.5463

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113036 / HDIL

Feeder No / Name : 202 / Killburn

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7922	1.6194	.7167	.4527	1.3336	1.2955	.9808
2	.679	1.5466	.7167	.4715	1.2193	1.1812	1.2071
3	.6859	1.5813	.6413	.4481	1.0751	1.448	.3395
4	.6859	1.4861	.6653	.3734	.9907	1.2193	1.1317
5	.8383	1.4335	.6348	.3921	.9054	1.2955	1.5684
6	1.1694	1.4289	.5975	.4066	.8002	1.1431	1.6804
7	.7167	1.5242	.924	.5544	1.226	1.1431	1.8484
8	1.358	1.2449	1.2323	.5975	1.1694	1.4861	1.6632
9	1.0562	1.5089	.7468	.8589	1.0974	1.1317	1.6118
10	1.1763	2.3152	.8215	1.8111	1.5729	1.643	2.0538
11	1.6244	1.8671	.7762	1.6244	1.5729	1.8671	2.5789
12	1.7741	2.3011	.8501	1.6617	1.9753	2.3011	2.1948
13	1.7164	2.6406	.8215	1.587	1.448	1.6804	1.6095
14	1.922	2.0911	.7468	1.6975	1.5364	1.9418	1.39
15	1.9959	1.307	.7545	1.4563	1.39	2.2177	1.4632
16	2.0328	1.358	.7545	1.9044	2.3655	2.6612	1.4815
17	2.2177	1.6975	.6722	1.7177	1.4784	2.2634	1.4632
18	2.0485	1.2323	.6722	1.4563	1.6095	1.9753	1.4003
19	1.9774	2.0328	.7545	1.2696	1.4784	2.0698	1.8671
20	1.885	1.3306	.7095	1.1763	1.3306	1.7924	1.3817
21	1.8671	.9709	.6653	1.5123	1.6221	1.4003	.8962
22	1.9993	.9335	.5853	1.3203	.8676	1.2012	1.0456
23	1.6032	1.2071	.5121	1.4712	.7545	1.1088	.7282
24	1.2071	1.5655	.7468	.4755	1.4289	.7167	1.2071
Max	2.2177	2.6406	1.2323	1.9044	2.3655	2.6612	2.5789
Min	.679	.9335	.5121	.3734	.7545	.7167	.3395
Avg	1.4595	1.5927	.7383	1.1124	1.3437	1.5910	1.4497

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113020 / Hariomnagar receiving

Feeder No / Name : 201 / AMIT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0886	.1063	.1063	.0886	.0709	.0886	.0886
2	.0886	.0886		.0709	.0709	.0709	.0886
3	.0709	.0886	.0886	.0709	.0709	.0709	.0709
4	.0709	.0709	.0709	.0709	.0709	.0709	.0709
5	.0709	.0709	.0709	.0709	.0709	.0709	.0709
6	.0886	.0886	.0709	.0709	.0709	.0709	.0709
7	.1063	.1063	.1063	.0709	.0709	.0709	.0532
8	.0886	.1063	.1063	.0709	.0709	.0709	.0886
9	.0886	.1063	.0709	.0532	.0709	.0709	.1063
10	.0886	.1063	.0709	.0532	.0709	.124	.0709
11	.0886	.1063	.0709	.1063	.0709	.0709	.0709
12	.0886	.1063	.0532	.0532		.0532	.0532
13	.0886	.1063	.0709	.0532	.0532	.0532	.0532
14	.0532	.0886	.0709	.0532	.0532	.0532	.0532
15	.0532	.0886	.0532	.0532	.0532	.0532	.0532
16	.0532	.0709	.0354	.0532	.0532	.0532	.0354
17	.0532	.0709	.0354	.0354	.0532	.0532	.0354
18	.0532	.0709	.0886	.0709	.0709	.0709	.0886
19	.1063	.124	.0886	.1063	.1063	.1063	.1063
20	.1063	.1417	.1063	.1063	.1063	.1063	.124
21	.1063	.1063	.0886	.0886	.1063	.1417	.1063
22	.1417	.1417	.0886	.0886	.124	.124	.1063
23	.1063	.1063	.1063	.0886	.1063	.1063	.1063
24	.0886	.1063	.1063	.1063	.0886	.0886	.0886
Max	.1417	.1417	.1063	.1063	.124	.1417	.124
Min	.0532	.0709	.0354	.0354	.0532	.0532	.0354
Avg	.0849	.0989	.0794	.0731	.0763	.0798	.0775

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113020 / Hariomnagar receiving

Feeder No / Name : 202 / HARIOM NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2105	.2105	.1943	.2105	.1943	.2267	.2429
2	.2267	.1943	.1619	.2267	.2105	.2105	.2429
3	.1943	.1619	.1619	.2267	.2105	.1943	.2105
4	.1943	.1619	.1457	.2105	.2105	.1943	.2105
5	.2267	.1457	.1296	.2105	.1943	.1943	.1943
6	.2591	.1619	.2105	.2267	.1943	.1943	.2267
7	.2915	.2105	.2105	.2267	.1943	.2267	.2753
8	.3239	.2105	.1943	.2105	.2105	.2591	.3239
9	.2753	.2915	.2267	.2267	.2267	.1619	.2915
10	.2915	.3401	.2429	.2753	.2429	.2591	.2591
11	.2753	.2915	.2591	.2753	.2753	.2753	.2915
12	.2591	.2429	.2753	.2267	.2753	.2591	.3077
13	.2429	.2267	.2267	.2267	.2753	.2753	.2753
14	.2267	.2429	.2591	.2105	.2267	.2429	.2105
15	.2105	.2105	.2429	.1943	.2591	.2591	.2105
16	.2267	.2105	.2267	.1781	.2105	.2591	.1943
17	.2267	.2267	.2429	.1943	.2429	.2267	.2267
18	.2753	.1619	.2753	.1943	.2591	.2753	.2267
19	.2591	.2753	.2753	.2267	.2753	.2591	.2915
20	.2591	.2591	.2591	.2267	.2753	.2591	.2591
21	.2591	.2753	.2429	.2267	.2753	.2753	.2429
22	.2267	.2429	.2429	.2267	.2753	.2753	.2267
23	.2267	.2429	.2267	.2267	.2591	.2591	.2105
24	.2622	.1943	.1943	.2105	.1943	.2591	.2429
Max	.3239	.3401	.2753	.2753	.2753	.2753	.3239
Min	.1943	.1457	.1296	.1781	.1943	.1619	.1943
Avg	.2471	.2247	.2220	.2206	.2362	.2409	.2456

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113020 / Hariomnagar receiving

Feeder No / Name : 203 / KALPTARU

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5281	.4961	.4321	.4641	.4481	.4481	.4481
2	.5281	.4321	.4001	.4161	.4321	.4321	.4481
3	.5121	.4001	.3681	.4161	.4321	.4321	.4161
4	.4801	.3681	.3681	.3841	.4161	.4161	.4161
5	.5441	.3521	.3521	.3841	.4481	.4481	.4481
6	.6722	.4161	.4801	.4161	.5121	.5441	.5121
7	.7682	.6081	.5441	.4801	.5441	.5761	.5761
8	.8322	.6081	.5761	.5441	.6882	.6722	.6562
9	.7842	.7362	.7042	.6401	.7362	.7522	.6562
10	.7202	.7362	.7202	.7202	.6882	.5921	.7042
11	.5761	.6401	.6401	.7042	.6562	.6562	.5921
12	.5601	.5761	.6081	.6401	.5921	.6241	.6081
13	.5121	.6081	.5441	.5441	.5441	.5281	.5441
14	.4161	.5281	.5601	.5121	.5281	.4641	.4481
15	.4801	.4641	.5121	.4481	.4481	.4481	.4001
16	.4641	.4481	.4481	.4481	.4001	.4001	.3521
17	.5121	.4961	.4801	.4481	.4641	.4481	.4161
18	.6081	.5761	.5761	.5441	.5121	.5281	.4481
19	.6241	.6562	.5761	.6081	.5761	.5921	.6081
20	.5761	.5441	.6081	.6081	.6081	.5921	.5761
21	.6401	.6081	.5281	.5761	.5921	.6241	.6081
22	.6081	.5441	.5441	.5441	.5601	.5761	.5761
23	.5601	.4961	.4961	.5121	.5121	.5121	.5601
24	.5441	.4961	.4801	.4481	.4801	.5121	.5121
Max	.8322	.7362	.7202	.7202	.7362	.7522	.7042
Min	.4161	.3521	.3521	.3841	.4001	.4001	.3521
Avg	.5855	.5348	.5228	.5188	.5341	.5341	.5221

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113020 / Hariomnagar receiving

Feeder No / Name : 204 / SAINATH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1753	.1753	.1578	.1578	.1578	.1753	.1928
2	.1753	.1578	.1402	.1402	.1578	.1578	.1578
3	.1578	.1402	.1402	.1402	.1578	.1578	.1578
4	.1578	.1402	.1227	.1402	.1402	.1402	.1402
5	.1753	.1227	.1227	.1402	.1578	.1578	.1402
6	.2279	.1753	.1578	.1402	.1753	.1928	.1753
7	.2804	.2103	.1753	.1402	.1928	.2279	.2454
8	.2279	.1928	.1578	.1753	.2279	.2804	.2804
9	.2454	.2629	.1928	.1753	.2103	.2629	.2629
10	.2454	.2103	.1753	.2103	.1928	.2279	.2454
11	.2454	.2103	.2454	.1928	.2103	.1928	.2454
12	.1753	.2103	.2103	.2279	.1753	.1928	.2103
13	.1928	.1578	.2103	.1928	.1578	.1928	.1753
14	.1578	.1402	.1753	.1753	.1578	.1402	.1402
15	.1928	.1578	.1578	.1402	.1578	.1227	.1402
16	.1402	.1402	.1402	.1227	.1227	.4001	.1227
17	.1402	.1578	.1052	.1402	.1753	.1578	.1402
18	.1753	.1753	.1578	.1402	.1753	.1402	.1227
19	.1928	.2279	.2454	.2454	.2804	.2629	.2103
20	.2279	.2103	.2279	.2103	.2279	.5608	.2103
21	.2103	.2103	.2454	.2279	.2279	.2454	.1928
22	.2454	.2279	.2279	.2279	.2629	.2454	.2454
23	.2279	.1753	.1848	.1928	.1928	.2103	.1753
24	.1928	.1753	.1753	.1753	.1753	.1753	.2103
Max	.2804	.2629	.2454	.2454	.2804	.5608	.2804
Min	.1402	.1227	.1052	.1227	.1227	.1227	.1227
Avg	.1994	.1819	.1772	.1738	.1863	.2175	.1892

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113020 / Hariomnagar receiving

Feeder No / Name : 205 / SANDEEP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4066	.3696	.3696	.3326	.3142	.3326	.3696
2	.2957	.3326	.3326	.2957	.3142	.2926	.3326
3	.2957	.2957	.3142	.2957	.2957	.2926	.2957
4	.2957	.2772	.3142	.2957	.2957	.3292	.2957
5	.3326	.2587	.2772	.2772	.3326	.3658	.3326
6	.3696	.2957	.3511	.2772	.3696	.4024	.3696
7	.4066	.3326	.3326	.2772	.4066	.439	.3881
8	.3696	.3696	.3881	.3326	.3696	.4572	.4251
9	.4251	.4251	.4251	.3881	.4435	.4805	.4435
10	.4435	.4066	.4066	.4251	.4251	.462	.4435
11	.3881	.4066	.4435	.3881	.3881	.4435	.3696
12	.3511	.4066	.4435	.3511	.4066	.4251	.3696
13	.2957	.3326	.3326	.4066	.3696	.3696	.3881
14	.3142	.3326	.2587	.3696	.3142	.3511	.3326
15	.3142	.3326	.2587	.2957	.3142	.3142	.2772
16	.2772	.3142	.2587	.2587	.3142	.2957	.2772
17	.462	.3142		.2587	.3326		.2587
18	.462	.3326	.3326	.3696	.462	.3881	.3326
19	.5175	.4805	.4435	.5175	.5914	.5175	.5175
20	.462	.4805	.462	.4435	.499	.5359	.4066
21	.4435	.4805	.3881	.4066	.4435	.4435	.4251
22	.4251	.462	.4805	.4066	.4435	.439	.4251
23	.4251	.4066	.3881	.4435	.462	.439	.4435
24	.462	.462	.4251	.4251	.3696	.4251	.4435
Max	.5175	.4805	.4805	.5175	.5914	.5359	.5175
Min	.2772	.2587	.2587	.2587	.2957	.2926	.2587
Avg	.3850	.3711	.3664	.3558	.3866	.4018	.3735

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113020 / Hariomnagar receiving

Feeder No / Name : 301 / ETERNITY-I Incomer to NON SHEDDABLE EXPRESS HV FEEDERS
 Eternity Feeder KV- 22 / (CONTINUOUS PROCESS)(NO STAGGERING)
 INCOMING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9874	2.8006	3.2861	3.1367	3.062	2.8292	2.8753
2	2.5393	2.6886	3.1741	2.7633	2.6886	2.7161	2.6513
3	2.5393	2.5393	3.0994	2.3899	2.4646	2.6406	2.5393
4	2.6139	2.4272	3.062	2.3525	2.3899	2.6029	2.5766
5	2.838	2.3411	2.9874	2.4646	2.5393	2.6406	2.6139
6	3.062	2.6886	3.2487	2.7633	2.9874	3.0933	3.0994
7	3.3608	3.5101	2.726	3.2114	3.3981	3.3951	3.5101
8	3.9209	3.7342	3.1741	3.4728	3.8836	3.8855	3.6969
9	4.369	3.8462	3.8462	3.9582	4.4063	4.0741	4.2943
10	4.4063	4.3317	3.7715	4.257	4.5184	4.489	4.7051
11		4.3317	4.3317	4.369	4.4437	4.3759	4.8171
12	4.1076	4.4063		3.8836	4.2196	4.4136	4.8171
13	4.145	4.0703	3.7715	4.1076	3.8836	3.9232	4.481
14	4.4063	3.9582	3.3981	3.9209	3.8089	4.225	4.481
15	3.9209	3.6595	3.5101	3.6595	3.9582	4.1495	4.5557
16	4.0703	3.5848	3.3981	3.3608	3.8462		4.0703
17	4.1823	3.8089	3.2487	3.7715	3.9956	3.8855	4.3317
18	4.9665	4.0703	3.7715	3.9209	4.5184	4.3381	
19	5.1532	4.5184	4.7051	4.7051	4.9665	4.904	5.6386
20	4.8918	4.8171	4.5557	4.481	4.7424	4.8663	5.1532
21	4.5184	4.6304	4.4437	4.481	4.6304	4.7908	4.9291
22	4.257	3.8836	4.2196	4.2943	4.0329	4.2627	4.369
23	3.6595	3.4728	3.8462	3.9209	3.6595	3.7723	4.1076
24	3.5475	3.4728	3.3234	3.3981	3.3608	3.3234	3.3573
Max	5.1532	4.8171	4.7051	4.7051	4.9665	4.904	5.6386
Min	2.5393	2.3411	2.726	2.3525	2.3899	2.6029	2.5393
Avg	3.8462	3.6497	3.6043	3.6268	3.7669	3.8086	3.9857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113020 / Hariomnagar receiving

Feeder No / Name : 302 / ETERNITY-II Incomer to NON SHEDDABLE EXPRESS HV FEEDERS
Eternit Feeder KV- 22 / INCOMING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6413	.679	.6413	.6413	.6413	.6413	.6413
2	.6413	.6036	.5658	.6036	.6036	.6036	.5658
3	.5658	.5281	.5281	.6036	.6036	.6036	.4904
4	.5658	.5281	.5281	.6036	.6036	.5658	.5281
5	.6036	.4527	.4527	.6413	.6036	.5658	.5658
6	.679	.5281	.6413	.6413	.6413	.6413	.6413
7	.7545	.5281	.6413	.6413	.6413	.7167	.7545
8	.8299	.7922	.7167	.679	.7545	.7922	.8676
9	1.0562	.9054	.8676	.7545	.9808	.9808	1.094
10	1.2826	1.2071	.9431	.9808	1.2826	1.358	1.2449
11	1.4335	1.2071	.9054	1.0562	1.4335	1.3957	1.3203
12	1.358	1.2826	1.094	.9808	1.3957	1.3957	1.358
13	1.2826	1.2826	.9431	1.0185	1.4335	1.358	1.4335
14	1.2826	1.1317	.9431	.9808	1.3203	1.3203	1.2826
15	1.2826	1.0562	.9054	.9431	1.2449	1.2071	1.2071
16	1.2826	1.0185	.9431	.9054	1.358	1.2449	1.2071
17	1.2071	1.1317	.9431	.9431	1.2449	1.2449	1.2826
18	1.3203	1.2071	.9808	1.0562	1.2826	1.3203	1.2826
19	1.1694	1.1317	1.1317	1.1317	1.2826	1.3957	1.2071
20	1.1694	1.094	1.0185	1.0562	1.1694	1.1317	1.1317
21	1.0185	.9808	.9808	.9808	1.0562	1.094	.9808
22	.9054	.8299	.8299	.8299	.9054	.8299	.9054
23	.7167	.7545	.7545	.7167	.679	.679	.7545
24	.679	.679	.679	.679	.679	.679	.679
Max	1.4335	1.2826	1.1317	1.1317	1.4335	1.3957	1.4335
Min	.5658	.4527	.4527	.6036	.6036	.5658	.4904
Avg	.9887	.8975	.8158	.8362	.9934	.9902	.9761

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113040 / Pioneer S/stn.

Feeder No / Name : 204 / 11 Kv Chintamani

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4344		.4344		.4706		.1991
2	.4344		.4344		.4706		.3982
3	.4344		.4344		.4706		.3982
4	.4344		.4344		.4706		.3982
5	.4298		.4344		.4706		.3982
6	.543		.4706		.5121		.4706
7	.5731		.5068		.543		.5792
8	.724	.6154	.5068	.5487	.7682	.6335	.5792
9	.7602	.6984		.6335	.724	.6878	
10		.788		.6516		.6805	
11		.788		.7964		.7164	
12	.724	.6805		.7316	.724	.7164	.724
13		.6805		.7316		.7522	
14		.6089		.2743		.6447	
15		.5373		.5121		.5014	
16		.5014		.4755		.5373	
17		.5731		.5853		.5731	
18		.6805		.6584	.6154	.7522	
19		.7522		.7602		.7964	
20		.7164		.7602		.7964	
21		.8238		.7602		.8507	
22		.6878		.6878		.724	
23		.6584		.6516	.6154	.6335	
24	.6805		.6154	.6335	.6154		.5731
Max	.7602	.8238	.6154	.7964	.7682	.8507	.724
Min	.4298	.5014	.4344	.2743	.4706	.5014	.1991
Avg	.5611	.6744	.4746	.6384	.5747	.6873	.4718

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113040 / Pioneer S/stn.

Feeder No / Name : 205 / 11 Kv Ganadhiraj

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.267		1.1946		1.1584		1.2536
2	1.267		1.1946		1.1584		1.267
3	1.267		1.1946		1.1584		1.267
4	1.267		1.1946		1.1584		1.267
5	1.2536		1.1946		1.1584		1.267
6	1.5203		1.2308		1.3032		1.3756
7	1.7013		1.3032		1.448		1.448
8	1.8461	1.6289		1.4118	1.7737	1.8804	1.448
9	1.8461	1.773		1.5546	1.7013	1.8823	
10		1.7551		1.7737		1.7551	
11		1.8625		1.6651		1.6118	
12	1.6651	1.7193		1.5203	1.5927	1.5043	1.5939
13		1.576		1.4632		1.3969	
14		1.2178		1.2803		1.2178	
15		1.2536				1.182	
16		1.2536		1.1706		1.086	
17		1.4327		1.2803		.8326	
18		1.576		1.4998	1.3394	.8326	
19		1.7193		1.6118		1.7375	
20		1.8099		1.6651		1.7375	
21		1.7013		1.6289		1.7558	
22		1.6289		1.6289		1.7375	
23		1.5203			1.3969	1.5927	
24	1.5565		1.448	1.3756	1.5565		1.5043
Max	1.8461	1.8625	1.448	1.7737	1.7737	1.8823	1.5939
Min	1.2536	1.2178	1.1946	1.1706	1.1584	.8326	1.2536
Avg	1.4961	1.5893	1.2444	1.502	1.3772	1.4839	1.3691

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113521 / P.M.G.P. RECEIVING

Feeder No / Name : 201 / ANKITA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7442	.7087	.7265	.7087	.7522	.7087	.7087
2		.7087		.6733	.7164	.6556	
3		.6733		.6556	.6805	.6201	
4		.691		.6556	.6626	.6024	
5		.7619		.691	.691	.6733	
6		.7973		.7087	.788	.7619	
7		.9391		.8328	.8596	.815	
8				.9568	1.0029	1.0454	.9568
9	1.0454	.9922	.9568	.9214	1.0498	1.134	1.0808
10	1.1163	1.1163	1.134	1.0631	1.0566	1.0985	1.0454
11	1.0985	1.0631	1.0808	1.0277	1.0924	1.1163	.9922
12	1.0808	1.134	1.0277	1.0631	1.0924	.9922	.9568
13	1.0099	1.0631	.9922	.9745	1.182	.8682	.9391
14	.8775	.9391	.9391	.8328	.9134	.8505	.815
15	.8869		.815	.7619	.8417	.815	.7619
16	.8682	.8505	.7619	.7602	.8059	.8328	.7087
17	.8859	1.2226	.815	.815	.8596	.8682	.8328
18	1.0099	1.0985	.9391	.9568	1.0387	.8682	.9922
19	1.2403	1.2403	1.1694	1.134	1.2178	1.2048	1.134
20	1.267	1.2226	1.134	1.1517	1.182	1.134	1.2226
21	1.2048	1.1517	1.0808	1.134	1.182	1.1517	1.0985
22	1.1163	1.0985	1.0454	1.0454	1.0924	1.0277	1.0277
23	.9922	.9036	.9568	.9036	.9671	.8682	.9214
24	.8596	.815	.8328	.815	.8682	.8238	.7973
Max	1.267	1.2403	1.1694	1.1517	1.2178	1.2048	1.2226
Min	.7442	.6733	.7265	.6556	.6626	.6024	.7087
Avg	1.0179	.9632	.9651	.8851	.9415	.8974	.9440

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113521 / P.M.G.P. RECEIVING

Feeder No / Name : 204 / SAMPADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1052	.1227	.1227	.1402	.1227	.1227	.1402
2		.1227		.1227	.1227	.1052	
3		.1052		.1052	.1052	.1052	
4		.1052		.1052	.1052	.1052	
5		.1227		.1227	.1227	.1227	
6		.1402		.1402	.1227	.1227	
7		.1402		.1227	.1227	.1402	
8				.1227	.1402	.1402	.1227
9	.1402	.1402	.1052	.1402	.1402	.1402	.1402
10	.1402	.1402	.1402	.1402	.1402	.1402	.1227
11	.1402	.1052	.1402	.1402	.1227	.1052	.1227
12	.1402	.1227	.1227	.1402	.1227	.1227	.1402
13	.1227	.1052	.1227	.1227	.1227		.1227
14	.1227	.1227	.1052	.1214	.1227	.1227	.1227
15	.1052		.1227	.1227	.1227	.1052	.1227
16	.1052	.1227	.1402	.1052	.1052	.1227	.1227
17	.1052	.1052	.1227	.1052	.1052	.1052	.1052
18	.1227	.1227	.1052	.1227	.1227	.1227	.1227
19	.1402	.1052	.1402	.1402	.1227	.1052	.1402
20	.1402	.1227	.1402	.1402	.1402	.1227	.1402
21	.1402	.1402	.1402	.1402	.1402	.1578	.1402
22	.1402	.1402	.1402	.1402	.1402	.1402	.1402
23	.1402	.1578	.1578	.1402	.1227	.1402	.1402
24	.1227	.1227	.1052	.1402	.1402	.1227	.1578
Max	.1402	.1578	.1578	.1402	.1402	.1578	.1578
Min	.1052	.1052	.1052	.1052	.1052	.1052	.1052
Avg	.1278	.1243	.1279	.1285	.1249	.1235	.1315

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113521 / P.M.G.P. RECEIVING

Feeder No / Name : 205 / LALITA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.197	.197	.1791	.1791	.1612	.1433	.1612
2		.1612		.1612	.1433	.1254	
3		.1612		.1254	.1254	.1075	
4		.1433		.1254	.1254	.1075	
5		.1791		.1612	.1433	.1433	
6		.2149		.197	.1791	.197	
7		.2507		.2149	.2149	.2507	
8				.2686	.2507	.2507	.2865
9	.3224	.2686	.2507	.2865	.2865	.2865	.2686
10	.3224	.2865	.3224	.3582	.2865	.3403	.2865
11	.2865	.3403	.2686	.3224	.2686	.3045	.2865
12	.2865	.2328	.2507	.2686	.2686	.2507	.2686
13	.2865	.2507	.2507	.2507	.2865	.2686	.2507
14	.2328	.2686	.2328	.2149	.2507	.2507	.2149
15	.2328		.2149	.2149	.2328	.2149	.2149
16	.2328	.197	.197	.2149	.2328	.2328	.197
17	.2686	.2149	.2149	.197	.2507	.2328	.2328
18	.3045	.2686	.2328	.2149	.2686	.2507	.2507
19	.3045	.3045	.2686	.3045	.2865	.2865	.2686
20	.3045	.3045	.2507	.3045	.3045	.2865	.2686
21	.3045	.2865	.2507	.2865	.2865	.2686	.2865
22	.2865	.2328	.2686	.2686	.2686	.2507	.2507
23	.2507		.2507	.2328	.2328	.2328	.2328
24	.2328	.2328	.2149	.2149	.2149	.2149	.1791
Max	.3224	.3403	.3224	.3582	.3045	.3403	.2865
Min	.197	.1433	.1791	.1254	.1254	.1075	.1612
Avg	.2739	.2379	.2423	.2328	.2321	.2291	.2447

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113521 / P.M.G.P. RECEIVING

Feeder No / Name : 206 / NEELAM NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3294	.2743	.2774	.333	.3294	.3258
2		.2947		.2427	.3121	.2947	
3		.2947		.2254	.2601	.2601	
4		.3294		.2254	.2427	.2601	
5		.3467		.2601	.2427	.2774	
6		.3641		.2774		.3294	
7		.4334		.3121	.4031	.3814	
8				.3467	.4908	.4508	.4801
9	.4973	.4854	.4287	.4161	.5201	.5028	.5144
10	.4801	.4973	.5028	.4508	.4207	.5201	.4161
11	.4287	.4115	.4161	.4508	.4161	.4161	.3641
12	.3506	.3601	.4161	.4681	.3641	.3988	.3814
13	.3772	.3944	.4161	.4334	.3294	.3467	.3467
14	.3155	.3601	.3294	.3121	.2947	.3294	.3121
15	.2915		.2947	.2774	.2774	.2601	.2947
16	.2743	.3086	.2774	.2601	.2427	.2427	.2601
17	.2915	.2915	.2774	.2774	.2947	.3121	.2947
18	.3086	.3601	.2947	.3467	.2774	.3641	.3641
19	.4115	.4115	.3814	.3814	.3814	.4161	.4161
20	.4287	.3944	.3814	.3988	.3988	.3988	.4161
21	.4287	.3772	.3814	.4161	.4161	.4161	
22	.4508	.3601	.3641	.4161	.4508	.4334	.3814
23	.3988	.3258	.3814	.3467	.4161	.3814	.3641
24	.3814	.3467	.2915	.3121	.3467	.3641	.3294
Max	.4973	.4973	.5028	.4681	.5201	.5201	.5144
Min	.2743	.2915	.2743	.2254	.2427	.2427	.2601
Avg	.3799	.3671	.3593	.3388	.3536	.3619	.3683

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113521 / P.M.G.P. RECEIVING

Feeder No / Name : 207 / M H B

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.543	.543	.5068	.5249	.5249	.5249	.5068
2		.5068		.4887	.4706	.4887	
3		.4887		.4706	.4525	.4525	
4		.4887		.4706	.4525	.4163	
5		.5249		.4887	.4706	.4344	
6		.543		.5068	.4887	.4706	
7		.6697		.5249	.5973	.5249	
8				.5611	.7059	.7602	.7602
9	.7059	.724	.6878	.6878	.724	.8145	.6697
10		.7421	.724	.6878	.7421	.6878	.6878
11	.6516	.8326	.6697	.6697	.6878	.6697	.6697
12	.6154	.6878	.6878	.6154	.7059	.5973	.6878
13	.6154	.6516	.5792	.5973	.5792	.5792	.5249
14	.5792	.543	.5611	.4887	.543	.5611	.5249
15	.5194		.543	.4525	.5068	.5068	.4887
16	.5068	.543	.5249	.4525	.4887	.4344	.4706
17	.5068	.543	.5249	.4706	.5068	.4887	
18	.5973	.6878	.5611	.4887	.543	.543	.543
19		.724	.7059	.724	.6335	.6878	.6878
20	.724	.7059	.6878	.6697	.724	.7059	.724
21	.724	.6697	.6878	.6878	.6697	.6697	.6697
22	.724	.6878	.6697	.6878	.6878	.6516	.6697
23	.6154	.6335	.6335	.5973	.5792	.6154	.5792
24	.6154	.5792	.5792	.5249	.5792	.543	.543
Max	.724	.8326	.724	.724	.7421	.8145	.7602
Min	.5068	.4887	.5068	.4525	.4525	.4163	.4706
Avg	.6162	.6236	.6197	.5641	.5860	.5762	.6122

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113521 / P.M.G.P. RECEIVING

Feeder No / Name : 208 / Renuka

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7888	.7888	.7888	.8063	.7973	.7973	.8413
2		.7712		.7537	.7619	.7442	
3		.7362		.7186	.7265	.691	
4		.7186		.7186	.7011	.691	
5				.7712	.7442	.7087	
6		.7888		.7888	.7973	.8328	
7		1.0692		.8589	.9922	.9745	
8				.929	1.0277	1.2048	1.3146
9	1.3496	1.1919	1.1393	1.1919	1.3466	1.3466	1.3496
10	1.4022	1.3321	1.3321	1.1919	1.3643	1.4352	1.5074
11	1.4022	1.4548	1.3321	1.2971	1.3643	.1417	1.4373
12	1.3432	1.3496	1.3496	1.262	1.3466	1.3112	1.262
13	1.2445	1.2269	1.2094	1.2269	1.2757	1.3643	1.262
14	1.0341	1.0867	1.0692	.9991	1.0985	1.1871	1.1218
15	1.0631		.9991	.9816	1.0808	1.0631	1.0867
16	1.0517	1.0517	.9114	.8589	1.0277	1.0985	1.0692
17	1.134	1.0692	.9465	.9313	1.134	1.2403	1.2094
18	1.3643	1.262	1.1218	1.1568	1.2226	1.3643	1.3321
19	1.4548	1.3672	1.3672	1.3146	1.4175	1.5415	1.5074
20	1.4198	1.3496	1.262	1.3146	1.382	1.4706	1.4022
21	1.4198	1.2269	1.3146	1.2445	1.3998	1.3998	1.3496
22	1.1568	1.1218	1.1218	1.1393	1.1694	1.2226	1.1744
23	1.0692	1.0341	.9816	1.0341	1.0454	1.0808	1.1218
24	.9214	.929	.929	.8939	.964	.9568	.9391
Max	1.4548	1.4548	1.3672	1.3146	1.4175	1.5415	1.5074
Min	.7888	.7186	.7888	.7186	.7011	.1417	.8413
Avg	1.2129	1.0917	1.1280	1.0160	1.0911	1.0779	1.2382

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113521 / P.M.G.P. RECEIVING

Feeder No / Name : 209 / Shripad

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3511	.2957	.3326	.2957	.3142	.2957	.3142
2		.2957		.2587	.2957	.2587	
3		.2772		.2402	.2587	.2402	
4		.2772		.2402	.2402	.2614	
5		.3142		.2587	.2772	.3326	
6		.3326		.2957	.3696	.3511	
7		.3696		.2772	.3511	.4066	
8				.2957	.4435	.3326	.4066
9	.3881	.3696	.4066	.4251	.4066	.4066	.4435
10	.3326	.4066	.3881	.4066	.3696	.3511	.3696
11	.3696	.3696		.3881	.3696	.3881	.3511
12	.2957	.3511	.3696	.3142	.3326	.3696	.2957
13	.2957	.3511	.3142	.2957	.2772	.3142	.2957
14	.2957	.2957	.2957	.2957	.2957	.2772	.2772
15	.2957		.2772	.2957	.2772	.2587	.2772
16	.2587	.2772	.2772	.2772	.2402	.2772	.2587
17	.2772	.2957	.2587	.2957	.2587	.3326	.2957
18	.4066	.3326	.3326	.3142	.3142	.3881	.3881
19	.499	.4435	.3881	.4435	.4066	.4435	.4066
20	.462	.4251	.3881	.4435	.4294	.3881	.4251
21	.4435	.3881	.4066	.462	.4251	.4066	.4435
22	.4435	.4066	.3881	.4251	.4435	.4251	.4251
23	.4251	.4251	.4066	.4066		.4066	.3881
24	.3881	.3696	.3696	.3511	.3511	.3511	.3696
Max	.499	.4435	.4066	.462	.4435	.4435	.4435
Min	.2587	.2772	.2587	.2402	.2402	.2402	.2587
Avg	.3663	.3486	.3500	.3334	.3368	.3443	.3573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113521 / P.M.G.P. RECEIVING

Feeder No / Name : 210 / Gurupushyamrut

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6805	.6089	.6447	.5731	.6447	.5731	.6268
2		.5731		.5373	.591	.5194	
3		.6089		.5194	.5373	.4298	
4		.6447		.5731	.5194	.4656	
5		.6984		.6089	.5552	.5194	
6		.7164		.6805	.6089	.6268	
7		.9313		.7783	.8417	.8238	
8				.8417	.9313	1.0029	1.1104
9	1.1104	.9671	.8596	1.0566	1.0029	1.0029	1.0566
10	1.0208	1.0029	.9671	1.0387	.9492	.9313	.9492
11	.8775	.8954	.8059	.9134	.8238	.8954	.8238
12	.7522	.8238	.8059	.8417	.8059	.8238	.7421
13	.7522	.7701	.788	.7522	.7701	.7701	.6805
14	.6626	.7164	.6447	.6447	.6984	.6268	.6268
15	.6268		.5731	.6089	.591	.5373	.591
16	.6089	.6089	.5194	.591	.6089	.591	.5731
17	.6878	.6447	.6089	.6268	.6626	.6626	.6447
18	.8059	.7522	.7164	.788	.7522	.7701	.6984
19	.9492	.8775	.8954	.8775	.9313	.9313	.9313
20	.9313	.985	.8596	.9134	.9134	.9492	.8596
21	.9671	.9313	.8417	.9492	.9313	.8954	.8596
22	.9671	.8954	.8417	.8954	.9134	.9134	.8238
23	.8596	.8059	.7701	.8059	.8238	.8417	.8059
24	.8238	.7164	.7343	.6805	.7343	.7164	.6626
Max	1.1104	1.0029	.9671	1.0566	1.0029	1.0029	1.1104
Min	.6089	.5731	.5194	.5194	.5194	.4298	.5731
Avg	.8285	.7807	.7574	.7540	.7559	.7425	.7815

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113521 / P.M.G.P. RECEIVING

Feeder No / Name : 211 / Navghar HTP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2012	.2012	.1829	.1829	.1646	.1463	.1829
2		.1646		.1646	.1829	.1463	
3		.1463		.1463	.1646	.128	
4		.1463		.1646	.1463	.1463	
5		.1646		.1646	.1646	.1646	
6		.1829		.2012	.1886	.1646	
7		.2378		.2378	.2561	.2012	
8				.2561	.2561	.2561	.2378
9		.3109	.2378	.2743	.3109	.2926	.2743
10	.2561	.3292	.2561	.2561	.2561		.3292
11	.2743	.2926	.2561	.2561	.2378	.2926	.2378
12	.2378	.2926	.2378	.2743	.2561	.2561	.2378
13	.2195	.2378	.2561	.2195	.2012	.2195	.2195
14		.2561	.2195	.1829	.2378	.2378	.2195
15	.2012		.2195	.1646	.2012	.2195	.2012
16	.2012	.1646	.2378	.1829	.1646	.2012	.1829
17	.2012	.1829	.2195	.1829	.1829	.2195	.2195
18	.2743	.2561	.2378	.2561	.2195	.2378	.2743
19	.3109	.3109	.2561	.3109	.2926	.2743	.2743
20	.2926	.2926	.2926	.3109	.2926	.2561	.2561
21	.3109	.2926	.2743	.2926	.2561	.2926	.2561
22	.2743	.2561	.2743	.2743	.2561	.2378	.2743
23	.2561	.2378	.2561	.2743	.2561	.2378	.2378
24	.2195	.2378	.2195	.2195	.2378	.2012	.1829
Max	.3109	.3292	.2926	.3109	.3109	.2926	.3292
Min	.2012	.1463	.1829	.1463	.1463	.128	.1829
Avg	.2487	.2361	.2432	.2271	.2243	.2187	.2388

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 113021 / LOK EVEREST

Feeder No / Name : 201 / ACC

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1088	1.1088		1.0164	.9149	1.0719	.9055
2	1.0534	1.0719		.961	.8589	.9795	.8686
3	1.0164	1.0164		.9055	.8029	.924	.8316
4	.961	.961		.8686	.7468	.8316	.8131
5	.924	.924		.8316	.8029	.7762	.8686
6	1.0164	.8316		.7392	.8589	.8871	.924
7	1.1273	.9425		.8686	.9335	1.0534	.9795
8	1.2382	1.0349		.961	1.2136	1.1643	1.2197
9	1.6448	1.5893		1.4045	1.587	1.7187	1.531
10		2.1437	1.3676	1.8484	2.1622	2.1068	2.1658
11	2.5393	2.2361	1.6632	2.0725	2.5503	2.4764	2.3712
12	2.5019	2.4394	1.5708	2.0725	2.4579	2.4579	
13	2.0725	2.2032	1.4415	1.8484	2.1807	2.0883	
14	2.1098	2.1068	1.2197	1.7924	2.1807	2.0328	
15	2.2032	2.0328	1.1273	1.8858	2.2177	2.2177	
16	2.2965	2.0883	1.2197		2.1068	2.1068	
17	2.2592		1.3121	1.7177	2.2731	2.1807	
18	2.1285	1.9589	1.2197		2.2177	2.1437	1.9978
19	1.9589	1.7741	1.3676	1.6057	1.9959	1.9404	2.0165
20	1.6409	1.5708	1.2936	1.419	1.5893	1.5154	1.587
21	1.5524	1.4784	1.2382	1.3256	1.5339	1.4784	1.4563
22	1.4045	1.3121	1.3121	1.2136	1.3588	1.3121	1.3443
23	1.2567	1.1458	1.0903	1.1389	1.2197	1.1458	
24	1.1458	1.1643	1.1088	1.0719	.9522	1.1088	1.0349
Max	2.5393	2.4394	1.6632	2.0725	2.5503	2.4764	2.3712
Min	.924	.8316	1.0903	.7392	.7468	.7762	.8131
Avg	1.6157	1.5276	1.3035	1.3440	1.5715	1.5716	1.3480

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 113021 / LOK EVEREST

Feeder No / Name : 202 / LOK KAILASH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4066	.3881		.4251	.3696	.3881	.381
2	.3696	.3696		.4066	.3734	.3881	.3429
3	.3511	.3511		.3881	.3511	.3696	.3239
4	.333	.3142		.3696	.3361	.3696	.3239
5	.2957	.2772		.3292	.3734	.3326	.362
6	.3696	.3142		.3142	.4108	.3511	.4001
7	.4066	.4066		.3696	.4481	.3696	.4191
8	.462	.4805		.3881	.5601	.4066	.4763
9	.499	.4805		.4805	.6161	.5544	.499
10		.6287		.6468	.6468	.6653	.7023
11	1.0534	.9526	.7762	.9149	.924	.961	.924
12	1.1643	1.1431	.8871	1.0829	1.1273	1.1827	
13	1.1273	1.2193	.8871	1.0456	1.1088	1.1812	
14	1.1203	1.0479	.8316	.9522	1.0719	1.086	
15	1.1389	1.0669	.8131	.9425	1.0719	1.0288	
16	1.0829	.9979	.8131		1.0719	1.105	
17	1.0534		.8131	1.0456	.9979	1.1812	
18	1.2382	1.2193	.9055		1.2197	1.2384	1.1576
19	1.2936	1.2574	.9979	1.1576	1.1827	1.2574	1.1949
20	1.1273	1.1812	.9425	1.1389	1.1643	1.1458	1.0082
21	1.0164	1.0288	.8871	.9335	1.0164	1.0288	.8402
22	.6838	.6283	.7392	.5914	.5544	.6859	.5601
23	.499	.4191	.4805	.4805	.4251	.4763	.4481
24	.4066	.4066	.3696	.4435	.4108	.4066	.4191
Max	1.2936	1.2574	.9979	1.1576	1.2197	1.2574	1.1949
Min	.2957	.2772	.3696	.3142	.3361	.3326	.3239
Avg	.7608	.7208	.7960	.6749	.7430	.7567	.5990

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 113021 / LOK EVEREST

Feeder No / Name : 204 / CITY OF JOY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9795	.961		.9055	.9335	.924	.7762
2	.924	.924		.8686	.8775	.8686	.743
3	.8686	.8686		.8316	.8316	.7762	.7049
4	.8316	.8316		.7577	.8029	.7392	.6859
5	.7762	.7762		.6838	.7468	.7023	.743
6	1.0164	.7392		.7762	.8029	.8316	.8002
7	1.2012	.8501		.8686	.9709	.924	.8764
8		.961		.924	1.2752	1.0534	1.105
9	1.2752	1.2567		1.1458	1.307	1.1827	1.2567
10		1.3121	1.2382	1.1949	1.3306	1.1827	1.1827
11	1.0349	1.1273	1.2012	1.2883	1.0903	1.1088	1.2136
12	1.0269	1.086	1.1458	.9709	1.0903	1.0534	
13	.924	1.1088	1.0164	.9335	.9425	.9979	
14	.7468	.9335	.924	.8501	.7762	.8131	
15	.7023	.7023	.7577	.8131	.7577	.7762	
16	.6722	.8131	.7947		.7207	.7023	
17	.7356		.7207	.8029	.7392	.7392	
18	.8871	.8383	.9425		.924	.8501	.8775
19	1.0903	1.105	1.1827	1.1016	1.0903	1.1431	1.0534
20	1.0829	1.1088	1.1088	.9979	1.1088	1.0719	1.0903
21	1.1273	1.1812	1.0164	1.1203	1.0534	1.1458	1.0456
22	1.1827	1.0719	1.0903	1.0719	1.1273	1.0349	1.0082
23	1.0719	.9795	.9979	.9795	1.0719	1.0669	.9709
24	.9795	.9979	.8871	.9425	.9795	.9795	.9526
Max	1.2752	1.3121	1.2382	1.2883	1.3306	1.1827	1.2567
Min	.6722	.7023	.7207	.6838	.7207	.7023	.6859
Avg	.9608	.9797	1.0016	.9468	.9730	.9445	.9492

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 113021 / LOK EVEREST

Feeder No / Name : 205 / NEW SHANTI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1494		.1494	.168	.1848	
2	.1494	.1494		.1494	.1494	.1867	
3	.1494	.1494			.1494	.1867	
4	.1494	.1494					
5	.1494	.1494					
6	.1494	.1494					.1524
7	.1494	.168		.1478	.1867	.1494	.1715
8	.1494	.1867		.1494	.1867	.168	.1663
9	.1494	.1494		.1867	.2241	.2054	.1867
10		.2957	.168	.2218	.2614	.2218	.2427
11	.2427	.2587	.1867	.2614	.2987	.2587	.2801
12	.2218	.2218	.1478	.2427	.2241	.2957	
13	.1867	.2402	.1663	.2241	.2054	.2402	
14	.1867	.2402		.2427	.2054	.2402	
15	.2054	.2402		.2054	.1867	.2033	
16	.2427	.2218			.2241	.2402	
17	.2241			.2054	.2054	.2218	
18	.2033	.2218			.2054	.2218	.2241
19	.2054	.2149	.1494	.2402	.1867	.2033	.2241
20	.1848	.2033	.1478	.2241	.2241	.2033	.2241
21	.1494	.1478	.1494	.2054	.1867	.2033	.2054
22	.1506	.1663	.1494	.1867	.1867	.1848	.168
23	.1494	.1848	.1494	.1867	.1867	.1848	.1867
24	.1494	.1494	.1663	.1494	.1867	.1867	.1848
Max	.2427	.2957	.1867	.2614	.2987	.2957	.2801
Min	.1494	.1478	.1478	.1478	.1494	.1494	.1524
Avg	.1760	.1916	.1581	.1988	.2018	.2091	.2013

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 113021 / LOK EVEREST

Feeder No / Name : 206 / GALA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.2096		.1524	.1524	.1524	.1524
2	.2096	.2096		.1524	.1524	.1524	
3	.1905	.2096		.1524	.1524	.1524	
4	.1905	.1715		.1524			
5	.1715	.1524		.1524			
6	.1905	.1715		.1715		.1524	.1524
7	.1905	.1905		.1715	.1715	.1524	.2477
8	.1905	.2096		.1715	.1905	.1715	.2096
9	.5144	.4382		.4954	.5716	.362	.4527
10		.724	.3429	.5906	.5716	.6653	.5847
11	.724	.724	.4001	.7049	.7621	.6859	
12	.7167	.7621	.381	.6668	.6478	.7621	
13	.5716	.5525	.3239	.5144	.5525	.5525	
14	.743	.6859	.3429	.5716	.6097	.6097	
15	.6668	.6478	.3429	.6287	.5716	.6097	
16	.724	.6859	.3429	.679	.5716	.6653	
17	.6283		.1905	.5975	.6478	.7049	
18	.5847	.5335	.1715		.5144	.6097	.547
19	.5281	.4572	.1524	.4763	.4382	.4954	.4954
20	.4715	.4191	.1715	.4763	.4382	.4572	.4572
21	.2452	.3048	.1715	.2286	.3239	.3048	.2858
22	.2096	.2033	.1715	.1905	.1715	.2096	.2286
23	.2096	.2286	.1524	.1715	.1524	.1524	.1715
24	.2096	.2096	.2096	.1524	.1715	.1524	.1524
Max	.743	.7621	.4001	.7049	.7621	.7621	.5847
Min	.1715	.1524	.1524	.1524	.1524	.1524	.1524
Avg	.4039	.3957	.2578	.3661	.4065	.4060	.3183

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 113021 / LOK EVEREST

Feeder No / Name : 207 / SANT DYNESHWAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	.8413		.7865	.7842	.7682	.7023
2	.7842	.8048		.7316	.7392	.7316	.6838
3	.7468	.7682		.695	.6838	.695	.6478
4	.6908	.7316		.6584	.6468	.6401	.6283
5	.6535	.6767		.6219	.6653	.5853	.6859
6	.7468	.6401		.6584	.7095	.7133	.743
7	.8413	.7316		.7316	.7655	.823	.8764
8	.9328	.8413		.7682	.9709	.8779	.924
9	1.0425	.9694		.9328	1.1273	1.0608	1.0903
10		1.1458	1.0974	1.1273	1.2071	1.2567	1.1016
11	1.251	1.1827	1.0663	1.2567	1.2803	1.2936	1.2567
12	1.2012	1.2567	1.0242	1.1763	1.2437	1.2936	
13	1.1203	1.1827	.9877	1.0456	1.1157	1.1458	
14	1.1389	1.1088	.823	.9795	1.0974	1.0719	
15	1.0534	1.0534	.8413	.9709	1.0425	1.0349	
16	1.0269	1.0719	.823		.9694	.9979	
17	1.0903		.8596	.9896	1.0296	.9979	
18	1.3676	1.2197	1.0425		1.2071	1.1458	1.1576
19	1.3676	1.3306	1.134	1.2382	1.2986	1.2936	1.2012
20	1.3121	1.2567	1.1157	1.1827	1.2071	1.1827	1.1643
21	1.1827	1.1458	1.0608	1.0349	1.134	1.1088	1.0269
22	.9877	.9795	.9328	.9425	.9877	.9795	.9425
23	.9328	.8871	.8413	.8501	.8962	.8501	.8501
24	.8779	.8413	.8316	.8413	.8131	.8048	.8316
Max	1.3676	1.3306	1.134	1.2567	1.2986	1.2936	1.2567
Min	.6535	.6401	.823	.6219	.6468	.5853	.6283
Avg	1.0075	.9856	.9654	.9191	.9843	.9730	.9175

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 113021 / LOK EVEREST

Feeder No / Name : 208 / OLD RAM GOPAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478	.6097		.4572	.5847	.6668	.6859
2	.6097	.5716		.4191	.5415	.6097	.6478
3	.5716	.5335		.381	.4854	.5716	.6097
4	.5335	.4572		.3429	.5335	.5335	.5716
5	.4763	.4191		.3239	.5658	.5144	.5716
6	.5716	.4763		.3048	.5906	.5525	.5906
7	.6097	.5906		.381	.6287	.5906	.6097
8	.6859	.6478		.4382	.7621	.6478	.8002
9	.9335	1.0288		.8002	1.1431	1.0288	1.0751
10		1.448	.6859	1.2384	1.448	1.3491	1.4523
11	1.5623	1.5242	.7049	1.3908	1.6194	1.4969	1.5278
12	1.6032	1.6385	.6859	1.5813	1.6004	1.4784	
13	1.2955	1.3908	.6478	1.3336	1.4098	1.5242	
14	1.5813	1.4098	.6287	1.467	1.448	1.3527	
15	1.6194	1.467	.6478	1.3717	1.5242	1.5242	
16	1.643	1.448	.6859		1.5051		
17	1.5089		.6097	1.4861	1.467	1.4861	
18	1.3957	1.4098	.5716		1.4861	1.4098	1.3676
19	1.3203	1.2574	.6287	1.1506	1.3717	1.3336	1.2765
20	1.0185	1.0288	.5716	1.0288	1.0288	1.2574	1.0288
21	.6979	.7621	.4572	.6859	.8002	.8383	.679
22	.7621	.7023	.4954	.6859	.6668	.7049	.6859
23	.6859	.724	.4954	.6478	.724	.6859	.6097
24	.6859	.6478	.6478	.4763	.6287	.7049	.6859
Max	1.643	1.6385	.7049	1.5813	1.6194	1.5242	1.5278
Min	.4763	.4191	.4572	.3048	.4854	.5144	.5716
Avg	1.0008	.9649	.6110	.8360	1.0235	.9940	.8598

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 113021 / LOK EVEREST

Feeder No / Name : 301 / 22 KV RUNWAL ANTHURIAM

Feeder KV- 22 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3					.2689		
6					.2689		
8		.2241		.2614	.3137		.2241
9					.2987		
10	.2987					.2987	.2987
11						.2987	
12	.2987			.2987		.2987	.2987
13		.2273					
14	.2987			.2987			.2987
15	.2987	.2666			.2987	.2987	.3345
16				.2987			
17	.2987	.2697					.2647
18				.3286			.2647
20					.2987		
21				.2987			.2987
23	.2987		.2241	.2689		.2987	.2987
24	.2241	.2241		.2241	.2689	.2241	
Max	.2987	.2697	.2241	.3286	.3137	.2987	.3345
Min	.2241	.2241	.2241	.2241	.2689	.2241	.2241
Avg	.2880	.2424	.2241	.2847	.2881	.2863	.2868

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 113039 / RUNWAL ANTHURIAM

Feeder No / Name : 201 / RAMONA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3					.0336		
6					.0373		
8		.0747		.056	.084		.0747
9					.0709		
10	.0747			.0766		.0747	.0747
11						.0747	
12	.0653			.0784		.0747	.0597
13		.0207					
14	.0747			.0822			
15	.0747	.0602			.0747	.0373	.0418
16				.0747			
17	.0373	.038					.0411
18				.0635			.0287
20					.0747		
21				.0691			.0597
23	.0747		.0747	.0523		.0747	.0635
24	.0747	.056		.0747	.0485	.056	
Max	.0747	.0747	.0747	.0822	.084	.0747	.0747
Min	.0373	.0207	.0747	.0523	.0336	.0373	.0287
Avg	.0680	.0499	.0747	.0697	.0605	.0654	.0555

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 113039 / RUNWAL ANTHURIAM

Feeder No / Name : 202 / GEMINI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3					.1419		
6					.1531		
8		.1867		.1867	.1531		.1867
9					.1755		
10	.2054			.2091		.2241	.2241
11						.2241	
12	.2241					.2241	.2016
13		.1997		.2614			
14	.1867			.2913			
15	.2241	.1605			.2241	.2054	.1692
16				.239			
17	.168	.0901					.1716
18				.2166			.2047
20					.2241		
21				.2315			.2353
23	.2241		.1867	.1867		.2054	
24	.2054	.168		.1867	.1494	.1867	
Max	.2241	.1997	.1867	.2913	.2241	.2241	.2353
Min	.168	.0901	.1867	.1867	.1419	.1867	.1692
Avg	.2054	.161	.1867	.2232	.1745	.2116	.1990

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 113039 / RUNWAL ANTHURIAM

Feeder No / Name : 203 / R SQUARE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3					.0224		
6					.0224		
8		.0373		.0374	.0392		.056
9					.0467		
10	.056			.0672		.0934	.0766
11						.056	
12	.056					.0373	.0803
13		.0589		.0709			
14	.0747			.0728			
15	.0747	.082			.0305	.0934	.1075
16				.0728			
17	.112	.0756					.0746
18				.0709			.0527
20					.0373		
21				.0373			.0392
23	.0373		.0373	.028		.056	.028
24	.0373	.0373		.0373	.0187	.0373	
Max	.112	.082	.0373	.0728	.0467	.0934	.1075
Min	.0373	.0373	.0373	.028	.0187	.0373	.028
Avg	.064	.0582	.0373	.0550	.0310	.0622	.0644

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 283071 / PANCHPAKHADI REC STN

Feeder No / Name : 202 / HUGALI-I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7421	.6335	.6335	.5973	.5973	.6154	.6335
2	.6878	.6154	.5792	.543	.543	.5611	.5792
3	.6516	.5792	.543	.5068	.543	.543	.543
4	.5973	.543	.5068	.4525	.5068	.5068	.5249
5	.5611	.5792	.5611	.4706	.5792	.5973	.5973
6	.6516	.6335	.5973	.5249	.6335	.6335	.6335
7	.7602	.6878	.6335	.5611	.6878	.7059	.6697
8	.6836	.7783	.6697	.6878	.7421	.8145	.8507
9	1.1946	.8507	.8145	.8869	1.0136	1.1041	1.0498
10	1.3032	1.267	.9412	1.086	1.1765	1.086	1.2489
11	1.4842	1.4842	1.1403	1.1403	1.448	1.4842	1.448
12	1.448	1.4118	.9774	1.1222	1.448	1.448	1.4299
13	1.3575	1.267	1.0317	1.0317	1.4118	1.4118	1.4842
14	1.3575	1.3394	.9412	1.086	1.3575	1.2308	1.3575
15	1.267	1.2127	.7964	1.086	1.3213	1.2489	1.267
16	1.267	1.1765	.7964	.9955	1.3213	1.267	1.3213
17	1.3394	1.1584	.7602	.905	1.2489	1.1765	1.2851
18	1.2308	1.1403	.8869	.9593	1.267	1.2127	1.2308
19	1.2489	1.1222	1.0498	1.0679	1.1946	1.2489	1.267
20	1.1222	1.0136	1.0136	1.1041	1.0498	1.1222	1.1946
21	1.0498	.9955	1.0136	1.0136	.9774	1.0498	1.0679
22	.8688	.8145	.9593	.8145	.8688	.9593	.905
23	.7783	.724	.8145	.8145	.7964	.8326	.7783
24	.8145	.6697	.6697	.6335	.7059	.6878	.6878
Max	1.4842	1.4842	1.1403	1.1403	1.448	1.4842	1.4842
Min	.5611	.543	.5068	.4525	.5068	.5068	.5249
Avg	1.0195	.9457	.8055	.8371	.9766	.9812	1.0023

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 283071 / PANCHPAKHADI REC STN

Feeder No / Name : 204 / DENTAL PRODUCT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3467	.2774	.2947	.2328	.2601	.2774	.2774
2	.3121	.2601	.2774	.197	.2774	.2601	.2427
3	.2601	.2427	.2601		.2601	.2427	.2254
4	.2774	.2427	.2427		.2601	.2601	.2601
5	.3121	.2774	.2774		.2947	.3121	.2947
6	.3641	.3121	.3121			.3467	.3294
7	.4508	.3641	.3294	.3467	.3814	.3814	.3814
8	.3224	.4161	.3467	.3294	.4161	.4508	.3988
9	.4508	.4508	.4161	.3641	.4508	.4161	.4161
10	.4508	.4334	.4334	.4161	.4508	.4334	.4334
11	.4161	.4334	.4854	.4681	.4334	.4334	.4334
12	.3814	.3467	.3988	.3814	.3467	.3641	.3467
13	.2947	.3294	.3467	.3467	.2427	.3467	.3467
14	.2774	.2947	.2774	.3467	.3467	.3121	.3294
15	.2774	.2774	.2774	.3294	.2601	.2947	.2774
16	.2947	.3121	.2427	.2774	.2601	.2601	.2947
17	.2774	.2947	.2601	.2947	.2601	.3294	.2947
18	.2947	.2947	.2947	.2947	.2774	.3121	.2774
19	.3988	.3814	.3467	.3814		.3988	.3467
20	.4161	.3814	.3467	.3641	.3988	.3988	.3641
21	.4161	.3641	.3814	.3814	.3814	.3988	.3814
22	.4334	.3988	.3641	.3988	.4334	.4334	.3814
23	.3814	.3467	.3121	.3641	.3294	.3814	.3641
24	.3814	.3121	.3121	.2507	.2774	.2947	.2947
Max	.4508	.4508	.4854	.4681	.4508	.4508	.4334
Min	.2601	.2427	.2427	.197	.2427	.2427	.2254
Avg	.3537	.3352	.3265	.3383	.3318	.3475	.3330

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 283071 / PANCHPAKHADI REC STN

Feeder No / Name : 205 / DEEVECHA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2865	.2328	.2328	.2328	.2149		.2149
2	.2686	.2149	.2149	.197	.2149		.197
3	.2328	.2149	.2149	.1791	.2149		.1791
4	.2328	.2149	.197	.1612	.2149		.2328
5	.197	.2149	.2149	.2149	.2328		.2507
6	.2328	.2328	.2328	.2507	.2686		.2686
7	.3761	.2507	.2507	.3224	.2865	.3045	.2865
8	.9231	.2865	.2686	.3045	.3045	.3403	.3403
9	.3224	.4119	.2865	.3582	.394	.3582	.3403
10	.394	.394	.3045	.394	.4119	.3582	.3582
11	.3582	.394	.3224	.3582	.3582	.3403	.3582
12	.394	.394	.2865	.394	.3224	.3403	.3403
13	.3403	.3582	.3045	.3403	.3045	.3224	.3403
14	.3045	.3224	.2328	.3045	.2686	.3045	.3224
15	.3224	.3045	.2328	.3045	.3045	.3045	.2686
16	.2865	.2686	.2149	.2865	.2686	.2865	.3045
17	.3045	.2865	.2328	.2865	.2865	.3224	.3224
18	.3403	.3224	.2507	.2865	.2507	.3045	.2686
19	.3224	.3045	.3224	.3224	.3045	.3403	.2865
20	.3045	.3045	.2865	.2865	.3045	.3403	.3045
21	.3224	.3224	.2686	.2865	.2865	.3224	.2865
22	.3045		.2686	.3045	.3403	.3403	.2865
23	.2865	.3045	.2686	.2865	.3045	.2865	.2686
24	.3224	.2507	.2507	.2507	.2507		.2328
Max	.9231	.4119	.3224	.394	.4119	.3582	.3582
Min	.197	.2149	.197	.1612	.2149	.2865	.1791
Avg	.3325	.2959	.2567	.2880	.2880	.3245	.2858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 283071 / PANCHPAKHADI REC STN

Feeder No / Name : 206 / S H KELKAR SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3756	1.1765	1.1946	1.1222	1.086	1.1222	1.1765
2	1.3213	.9774	1.1222	1.0136	1.0136	1.0317	1.1222
3	1.2127	.9412	1.0317	.9593	.9955	.9774	1.086
4	1.1403	.905	.9412	.905	.9412	.9231	1.1765
5	1.1765	1.0317	.9955	1.0498	1.0498	1.0679	1.267
6	1.2851	1.1765	1.1222	1.1584	1.2489	1.2308	1.3756
7	1.6651	1.3213	1.267	1.448	1.4118	1.4842	1.4842
8	1.9185	1.6651	1.5023	1.4118	1.7375	1.7918	1.828
9	2.1719	1.8099	1.4842	1.8823	2.0271	2.3529	2.1176
10	2.2805	2.0995	1.9909	2.0995	2.1176	2.3529	2.2624
11	2.2081	2.1719	2.0452	2.1176	2.2624	2.3891	2.1538
12	1.9728	1.9909	1.828	1.9185	7.4027	2.0633	1.9547
13	1.7375	1.7194	1.7375	1.5927	1.9004	1.8642	1.8099
14	1.6651	1.6289	1.5384	1.5927	1.7737	1.7556	1.7918
15	1.6289	1.4661	1.448	1.3575	1.6108	1.7918	1.6289
16	1.6651	1.448	1.3756	1.3575	1.7194	1.7737	1.6289
17	1.7194	1.4661	1.3937	1.448	1.6832	1.5023	1.5384
18	1.8461	1.5565	1.5023	1.647	1.6289	1.7737	1.6108
19	1.9547	1.7375	1.7556	1.828	1.9185	1.9004	1.7375
20	1.7918	1.7194	1.6108	1.7013	1.8099	1.8461	1.8642
21	1.8099	1.6651	1.6651	1.6832	1.6651	1.7737	1.7737
22	1.6289	1.5927	1.5384	1.5927	1.5927	1.576	1.5927
23	1.5023	1.4118	1.448	1.4842	1.5746	1.5023	1.3756
24	1.448	1.3937	1.2489	1.1946	1.3756	1.1946	1.2308
Max	2.2805	2.1719	2.0452	2.1176	7.4027	2.3891	2.2624
Min	1.1403	.905	.9412	.905	.9412	.9231	1.086
Avg	1.6719	1.5030	1.4495	1.4819	1.8145	1.6267	1.6078

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 283071 / PANCHPAKHADI REC STN

Feeder No / Name : 207 / TRIDEV

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8238	.6984	.7701	.6984	.7164	.7343	.7701
2	.788	.6626	.7164	.6626	.6805	.6984	.7343
3	.7343	.6268	.6626	.6089	.6268	.6447	.6626
4	.6626	.6089	.6268	.5373	.5731	.5731	.6268
5	.7164	.7164	.6805	.5014	.6626	.6268	.6805
6	.8059	.7522	.7164	.6089	.7164	.6984	.7164
7	.8596	.8238	.7701	.7164	.788	.8238	.788
8	1.0387	.8954	.8775	.8596	.9134	1.0208	.9671
9	1.182	1.0387	1.0387	1.0924	1.182	1.1999	1.1462
10	1.1999	1.1283	1.1283	1.1283	1.2178	1.1641	1.1641
11	1.0745	1.2178	1.0924	1.1462	1.1641	1.1283	1.1283
12	1.0387	1.0745	1.0029	1.0029	1.1283	1.0387	1.0745
13	.9134	.8954	.8954	.9313	.9492	.9492	.9492
14	.8596	.8954	.8417	.8417	.9671	.8954	.8059
15	.8596	.8596	.8059	.8417	.8417	.8059	.7164
16	.8417	.7522	.8059	.8238	.8059	.7522	.7059
17	.8417	.8238	.7701	.8417	.7701	.8417	.8059
18	1.0029	.9492	.9313	.9492	.985	.9313	.8596
19	1.1641	1.0566		1.0745	1.1104	1.1104	1.0029
20	1.0745	1.0924	1.0566	1.0924	1.0387	1.0387	1.0745
21	1.1104	1.0566	.9671	1.0208	1.0387	1.0029	.985
22	1.0208	.9671	.9313	.985	1.0387	.9492	.9671
23	.9492	.9313	.8775	.9134	.9134	.8775	.8954
24	.8775	.8238	.8238	.7522	.8238	.8059	.8059
Max	1.1999	1.2178	1.1283	1.1462	1.2178	1.1999	1.1641
Min	.6626	.6089	.6268	.5014	.5731	.5731	.6268
Avg	.9350	.8895	.8604	.8596	.9022	.8880	.8764

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 283071 / PANCHPAKHADI REC STN

Feeder No / Name : 208 / TATA FISION

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3582	.3224	.3403	.2865	.3403	.3045	.3582
2	.3224	.3045	.3224	.2686	.2865	.2865	.3224
3	.2686	.2865	.3045	.2328	.2686	.2507	.2865
4	.2865	.2865	.2686	.2149	.2686	.2328	.2686
5	.3045	.3224	.2507	.2507	.3045	.2686	.2507
6	.3582	.3582	.2865	.3045	.3582	.3224	.3045
7	.4119	.4119	.3045	.3582	.4119	.3582	.3761
8	.3761	.4119	.3582	.394	.4119	.4298	.394
9	.4656	.4298	.394	.394	.4298	.4298	.5014
10	.4298	.4656	.4656	.4656	.4477	.4656	.4477
11	.4835	.4835	.4477	.4477	.4477	.4835	.4477
12	.4835	.4835	.4298	.4477	.4835	.4477	.4656
13	.4119	.4298	.394	.4298	.4477	.4477	.4119
14	.4119	.4119	.394	.4477	.4298	.4477	.4298
15	.394	.4119	.3582	.8954	.394	.4119	.3224
16	.3761	.394	.3224	.3761	.394	.3761	.3761
17		.4119	.3582	.394	.4119	.394	.3761
18	.4477	.4477	.4298	.4477	.4298	.4298	.4119
19	.4656	.4656	.4298	.4656	.4656	.4656	.4656
20	.4835	.4656	.4298	.4477	.4656	.4656	.4477
21	.4656	.4477	.4298	.4477	.4298	.4656	.4477
22	.4298	.4298	.4298	.4119	.4298	.4477	.4298
23	.4298	.4298	.3761	.4119	.4298	.4298	.4119
24	.394	.394	.3582	.3045	.3582	.3224	.3761
Max	.4835	.4835	.4656	.8954	.4835	.4835	.5014
Min	.2686	.2865	.2507	.2149	.2686	.2328	.2507
Avg	.4026	.4044	.3701	.3977	.3977	.391	.3888

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 283071 / PANCHPAKHADI REC STN

Feeder No / Name : 209 / YOGI HILL SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1041	1.0136	.9709	.8842	.9709	.9536	.9882
2	1.0317	.8326	.9189	.8495	.8149	.8322	.9536
3	.9412	.7964	.8669	.7975	.7802	.7975	.9015
4	.8688	.7602	.8149	.7282	.7628	.7455	.8495
5	.9593	.8145	.7628	.6935	.8322	.7975	.8842
6	1.0498	.905	.8149	.7455	.8669	.9015	.9189
7	1.3394	1.0317	.8495	.8669	.9536	1.0402	.9882
8	1.3394	1.1222	.9362	1.0056	1.2656	1.3176	1.283
9	1.5203	1.4118	1.1269	1.283	1.4217	1.595	1.5777
10	1.7013	1.6651	1.3696	1.4563	1.595	1.6297	1.8099
11	1.5384	1.6651	1.335	1.5604	1.5604	1.647	1.7194
12	1.3937	1.5203		1.4217	1.439	1.439	1.5927
13	1.3394	1.4118	1.0749	1.3176	1.2656	1.2656	1.4118
14	1.2127	1.1765	1.0402	1.1443	1.1269	1.2483	1.3432
15	1.1222	1.1222	.9015	1.0402	1.1616	1.1789	1.1765
16	1.267	1.1041	.9362	1.0402	1.0923	1.0923	1.1403
17	1.1584	1.1041	1.0056	1.0749	1.1616	1.1269	1.1222
18	1.3575	1.267	1.0749	1.2483	1.2136	1.2483	1.2308
19	1.3756	1.3937	1.1789	1.3176	1.283	1.2656	1.4118
20	1.3394	1.3575	1.1789	1.2483	1.1789	1.283	1.3937
21	1.3394	1.2308	1.1096	1.1443	1.2483	1.2136	1.2308
22	1.3394	1.3937	1.0749	1.2483	1.283	1.3003	1.2127
23	1.1222	1.2127	1.0402	1.1616	1.1096	1.2136	1.2489
24	1.1765	1.086	1.0229	.9362	1.0402	1.0056	1.0402
Max	1.7013	1.6651	1.3696	1.5604	1.595	1.647	1.8099
Min	.8688	.7602	.7628	.6935	.7628	.7455	.8495
Avg	1.2474	1.1833	1.0176	1.0923	1.1428	1.1724	1.2262

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 283071 / PANCHPAKHADI REC STN

Feeder No / Name : 210 / SAPTERSHI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5258	.5609	.4706	.3982	.5068		.4681
2	.4557	.5083	.4525	.3801	.5068		.4334
3	.4207	.4733	.3982	.3439	.4706		.3641
4	.3856	.4207	.362	.2896	.4525		.3641
5	.4207	.4382	.3439	.3258	.4706		.3814
6	.4733	.4382	.3801	.362	.4706		.4161
7	.5959	.4557	.3982	.4344	.4887	.4344	.4508
8	.6836	.5959	.543	.5249	.6335	.5973	.5721
9	.9114	.7537	.6516	.6516	.7421	.6697	.7628
10	.9991	.929	.7421	.8507	1.1041	.8507	.7802
11	1.0867	.8939	.7421	.8326	.7602	.8869	.7975
12	.929	.7362	.7964	.7783	.8145	.7602	.7108
13	.9465	.7011	.7421	.6697	.6335	.7059	.7059
14	.8589	.6836	.6697	.6335	.5792	.5973	.6588
15	.9114	.5434	.6335	.5792	.6154	.5792	.6415
16	.631	.4733	.5068	.4887	.5249	.543	.5028
17	.6485	.4908	.6154	.5792	.5792	.5249	.6068
18	.6661	.5609	.6154	.6154	.5973	.6415	.6762
19	.6661	.7186	.6878	.7602	.7783	.6415	.7108
20	.6485	.631	.6878	.724	.7059	.6762	.7282
21	.7362	.6836	.724	.6878	.7059	.7282	.7802
22	.7362	.7186	.6335	.724	.6154	.6588	.6588
23	.631	.5784	.5973	.6878	.5792	.5721	.6241
24	.5609	.5609	.5068	.4344	.5973		.5028
Max	1.0867	.929	.7964	.8507	1.1041	.8869	.7975
Min	.3856	.4207	.3439	.2896	.4525	.4344	.3641
Avg	.6887	.6062	.5792	.5732	.6222	.6510	.5958

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113013 / 22/11 KV SARVODAYA

Feeder No / Name : 202 / MAASHPURAM SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2308	1.2308		1.2308	1.3203	1.2127	
2	1.1765	1.1584		1.086	1.2449	1.1403	
3	1.1222	1.1222		1.0498	1.1128	1.086	
4	1.0679	1.1041		1.0317	1.2071	1.0317	
5	1.1584	1.1584	1.086	1.0679	1.2449	1.086	
6	1.3756	1.267	1.1584	1.1765		1.2127	
7	1.6289	1.3937	1.3032	1.2851	1.2826	1.3394	
8	1.7918	1.8099	1.5565	1.5565	1.905	1.7556	
9	1.8823	1.7918	1.6289	1.8099	1.9616	2.2081	
10	2.0814	1.8642	1.8473		1.8823	2.1313	2.1538
11	2.3167	2.009	2.0302		2.0119		2.0633
12	1.9185	1.828	1.7558	1.8099	1.8099	1.8296	1.9547
13	1.7013	1.7013	1.701	1.5565	1.6289		1.7918
14	1.5203	1.5203	1.5364	1.448	1.4661	1.6032	1.6289
15	1.5729	1.3394	1.3169	1.2851	1.3756		
16	1.5927	1.3937	1.3717		1.4299	1.4523	
17	1.647	1.5203	1.4083		1.5203	1.6409	
18	1.9185	1.6832	1.6461		1.8642		
19	2.009	1.8823	1.7741		1.8461		
20	1.9004	1.7737	1.7193	1.8673	1.8642		
21	1.828	1.7013	1.6651		1.7737		
22	1.6832	1.6278	1.6108	1.6409	1.5927		
23	1.5565	1.4661	1.4299	1.5089	1.4842		1.5278
24	1.448	1.448	1.3213	1.3213	1.4335	1.3575	1.3575
Max	2.3167	2.009	2.0302	1.8673	2.0119	2.2081	2.1538
Min	1.0679	1.1041	1.086	1.0317	1.1128	1.0317	1.3575
Avg	1.6304	1.5331	1.5434	1.3960	1.5766	1.4725	1.7825

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113013 / 22/11 KV SARVODAYA

Feeder No / Name : 203 / UDYOGKSHETRA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2534	.2715		.2534	.1509	.2715	
2	.2353	.2534		.2353	.1509	.2353	
3	.2353	.2534		.2172	.1509	.2172	
4	.2353	.2715		.2172	.1886	.2172	
5	.2353	.2534	.2534	.2353	.2263	.2172	
6	.2715	.2715	.2534	.2353	.2641	.2534	
7	.2715	.2715	.2534	.2353	.2829	.2534	
8	.3077	.2715	.2896	.2715	.3772	.2534	
9	.4344	.3077	.2896	.3077	.3961	.5611	
10	.6697	.4706	.3109	.4706	.6154	.6413	.5973
11	.7059	.4706	.2926		.6516		.7059
12	.7059	.4887	.2743	.4887	.6516	.6224	.6154
13	.6516	.4706	.2743	.5249	.5973		
14	.5792	.4706	.2561	.4163	.5792	.6036	.6154
15	.6516	.4887	.2561	.4887	.6697		
16	.6878	.4887	.2378	.4527	.6697	.679	
17	.7059	.5068	.2378		.6697	.679	
18	.6516		.2926		.543		
19	.4525	.4163	.3841		.4525		
20	.4163	.4525	.3475	.3772	.3982		
21	.3801	.3801	.3077		.3801		
22	.3801	.3475	.3258	.3395	.3258		
23	.2896	.3077	.3077	.3395	.3439		.3395
24	.2896		.2561	.2896	.1886	.3077	.3077
Max	.7059	.5068	.3841	.5249	.6697	.679	.7059
Min	.2353	.2534	.2378	.2172	.1509	.2172	.3077
Avg	.4457	.3720	.2850	.3366	.4135	.4008	.5302

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113013 / 22/11 KV SARVODAYA

Feeder No / Name : 204 / SAIDHAM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7059	.7602		.7059	.7545	.724	
2	.6697	.724		.6878	.679	.6878	
3	.6154	.6516		.6154	.6413	.6697	
4	.6154	.6154		.6154	.6413	.6516	
5	.6697	.6878	.6653	.6154		.6697	
6	.8145	.7602	.7207	.6878	.7167	.7964	
7	.9231	.8507	.7947	.7602	.8676	.8326	
8	.9231	.8507	.924	.9412	1.0185	.9593	
9	1.086	1.0679		1.0317	1.1883	1.1041	
10	1.0534	1.0317	.8775		1.0534	1.1317	1.0679
11	.961	1.1041	.9511		1.0974		1.0498
12	.924	1.0136	.9511	.9979	1.0349	1.0185	.9955
13	.9055	.9231	.8962	.8501	.9979		.9231
14	.7964	.8326	.8048		.8501	.8865	.7783
15	.8131	.8145	.7499	.7602	.8686		
16	.7207	.543	.7682		.8686	.811	
17	.8869	.9055	.7842		.905	.811	
18	.9593	1.0164	.9149		.9955		
19	1.086	1.0719	1.0269		1.1041		
20	1.0679	1.0534	.9877	1.0185	1.0498		
21	.9774	.9979	.9593		1.0317		
22	.9774	.9425	.8688	.8865	.9955		
23	.8869	.8871	.8507	.7545	.9412		.8865
24	.7964	.7964	.8131	.7602	.7922	.7783	.7783
Max	1.086	1.1041	1.0269	1.0317	1.1883	1.1317	1.0679
Min	.6154	.543	.6653	.6154	.6413	.6516	.7783
Avg	.8681	.8709	.8584	.7930	.9171	.8355	.9256

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113013 / 22/11 KV SARVODAYA

Feeder No / Name : 205 / SARVODAYA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8764	.8413		.4557	.4527	.4382	
2	.8063	.7712		.3856	.3772	.3681	
3	.7712	.7362		.3506	.3772	.3681	
4	.7362	.7186		.3506	.3961	.3506	
5	.7712	.7712	.3544	.3506	.4527	.3506	
6	.929	.8063	.4252	.4207	.5093	.4382	
7	1.0517	.8413	.4607	.4733	.5847	.4557	
8	.9816	.9465	.5138	.4557	.6224	.5959	
9	1.1393	1.0517		.5609	.6036	.5959	
10	1.3289	1.1919	.6219		.7265	.7356	.6485
11	1.2226	1.2445	.6733		.6733		.7537
12	1.1088	1.1393	.7619	.7087	.6201	.679	.631
13	1.0631	1.1043	.5847	.5847	.5493		.631
14	.929	.9816	.6036	.6219	.5316	.8865	.5959
15	.9214	.964	.567	.5138	.4961		
16	1.0277	1.0166	.5853		.4784	.5093	
17	1.0341	1.0631	.5487		.4733	.547	
18	1.0341	1.0631	.567		.5784		
19	1.0867		.6024		.5959		
20	1.1218	.6024	.6201	.5847	.6135		
21	1.1568	.6379	.6135		.631		
22	1.1393	.6024	.5959	.8865	.6485		
23	1.1043	.6413	.5784	.6979	.6135		.6413
24		.9816	.5847	.5434	.5281	.5083	.5083
Max	1.3289	1.2445	.7619	.8865	.7265	.8865	.7537
Min	.7362	.6024	.3544	.3506	.3772	.3506	.5083
Avg	1.0148	.9008	.5717	.5262	.5472	.5218	.6300

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113013 / 22/11 KV SARVODAYA

Feeder No / Name : 206 / SHREERAM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7655	.7842		.6348	.7922	.7733	
2	.7655	.7842		.5788	.7545	.7922	
3	.6722	.7468		.5601	.679	.7545	
4	.6722	.7468		.5415	.679	.7922	
5	.7095	.8215	.695	.5601	.7167	.6979	
6	.8215	.8589	.6584	.5788	.7356	.811	
7	.9896	.9149	.695	.6908	.8299	.8865	
8	1.1016	.8962	.6767	.8402	.9242	.9242	
9	1.2696	1.1389		1.0269	1.2637	1.3769	
10	1.6461	1.5684	.7922		1.7558	1.8673	1.6787
11	1.7741	1.7551	.9242		1.7558		1.6598
12	1.8484	1.7551	.8962	1.3443	.4572	1.5278	1.7541
13	1.5364	1.6244	.8413	1.2803			1.4335
14	1.6461	1.6244		1.4632	1.4266	1.6598	1.3957
15	1.5912	1.5123	.7865	1.3352	1.5729		
16	1.6244	1.531	.7316		1.5565	1.5278	
17	1.5123	1.5364	.7316		1.4901	1.4901	
18	1.5497	1.4266	.7865		1.6221		
19	1.419		.9511		1.3014		
20	1.307	1.1888	1.0425	1.0562	1.1128		
21	1.1576	1.1706	.9709		1.1128		
22	1.1203	.9877	.8962	.9619	1.0185		
23	.9335	.9145	.8029	.9808	.9619		.9431
24	.8775	.8402	.8048	.7095	.8865	.7733	.7922
Max	1.8484	1.7551	1.0425	1.4632	1.7558	1.8673	1.7541
Min	.6722	.7468	.6584	.5415	.4572	.6979	.7922
Avg	1.2213	1.1795	.8158	.8908	1.1046	1.1103	1.3796

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113013 / 22/11 KV SARVODAYA

Feeder No / Name : 207 / RAJA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3206		.1014	.2263	.2829	
2	.3239	.3206		.0934	.2263	.2641	
3	.3048	.3018		.108	.2263	.2641	
4	.3048	.3018		.0937	.2641	.2667	
5	.2987	.2829	.2641	.0903	.2641	.2534	
6	.2926	.3018	.2829	.0934	.3018	.2561	
7	.3206	.2829	.2829	.1021	.3018	.2629	
8	.3206	.3206	.2829	.2054	.3772	.2987	
9	.4854	.4715	.2641	.3734	.4715	.4904	
10	.7545	.7922	.2641		.7545	.811	.8589
11	.8865	.9054	.2641				.9997
12	.8488	.9149	.2452	.7733	.9431	1.094	.9522
13	.7733	.7545	.2452	.6036	.7922		.8488
14	.811	.811	.2452	.6979	.811	.8865	.9335
15	.9997	.9335	.2452	.7167	.9054		
16	.9431	.8299	.2263		.8865	.9242	
17	.8676	.7545	.2263		.8589	.8676	
18	.7922	.7167	.2263		.7655		
19	.6602	.547	.1886		.5847		
20	.5093	.4715	.2263	.415	.4763		
21	.3772	.3961	.2263		.4191		
22	.3584	.3772	.2263	.3018	.4001		
23	.3206		.1204	.3018	.2772		.3018
24	.3429	.3018	.3395	.1097	.3018	.2801	.3395
Max	.9997	.9335	.3395	.7733	.9431	1.094	.9997
Min	.2926	.2829	.1204	.0903	.2263	.2534	.3018
Avg	.5517	.5396	.2446	.3048	.5146	.5002	.7478

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113013 / 22/11 KV SARVODAYA

Feeder No / Name : 208 / KARIA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9231	.8688		.8779	.9431	.8779	
2	.8326	.8326		.8048	.8676	.8413	
3	.8145	.7964		.7865	.7922	.8048	
4	.7783	.7783		.7865	.8488	.7865	
5	.8507	.7964	.8145	.8048	.9054	.823	
6	1.0679	.8688	.8145	.8962	.9431	.8962	
7	1.1765	.9231	.9231	.9511	1.0562	1.0059	
8	1.1946	1.0679	1.086	1.0242	1.1317	1.134	
9	1.2127	1.2308	1.0679	1.1888	1.2449	1.262	
10	1.3213	1.3032	1.2254		1.2851	1.3957	1.3717
11	1.3394	1.3575	1.3352				1.2803
12	1.1584	1.2308	1.1706	1.2851	1.1584	1.4712	1.2437
13	1.0679	1.1584	1.2254	1.0974	1.086		1.134
14	.9955	.9593	1.0059	1.0059	1.0136	.9619	.9511
15	.9593	1.0136	.9877	.9694	1.0136		
16	.9231	.9231	1.0059		.9412	.9431	
17	.9231	.9774	.9511		.9877	.9054	
18	1.0498	1.1222	1.0242		1.0791		
19	1.3213	1.1946	1.2254		1.1706		
20	1.2308	1.1765	1.1888	1.1883	1.262		
21	1.3032	1.2127	1.1222		1.2071		
22	1.1403	1.1222	1.0498	1.1128	1.134		
23	1.086	1.0317	1.0059	1.0751	1.0791		1.0562
24	1.0498	1.0425	.9231	.9145	1.0185	.9877	.9877
Max	1.3394	1.3575	1.3352	1.2851	1.2851	1.4712	1.3717
Min	.7783	.7783	.8145	.7865	.7922	.7865	.9511
Avg	1.0717	1.0412	1.0576	.9864	1.0508	1.0064	1.1464

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113013 / 22/11 KV SARVODAYA

Feeder No / Name : 209 / nahurgaon SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8048	.8145		1.1523	1.3203	1.1157	
2	.7682	.7865		1.0791	1.226	1.0608	
3	.7499	.7682		.9877	1.1317	1.0608	
4	.7316	.7316		.9877	1.2071	1.0608	
5	.7865	.7682	1.0242	1.0974	1.2826	1.0242	
6	.8413		1.0974	1.0974	1.3203	1.134	
7	1.0242	.8596	1.0974	1.1523	1.3203	1.262	
8	1.0974	.9328	1.2803	1.3535	1.4335	1.4083	
9	1.1706	.9328	1.3717	1.3352	1.6032	1.701	
10	1.1157	1.0608	1.6095		1.6827	1.6221	1.6278
11	1.0059	1.0425	1.6278		1.6095		1.5181
12	1.0059	.9877	1.5546	1.6278	1.5181	1.4712	1.3717
13	.823	.8596	1.4998	1.4083	1.2986		1.39
14	.823	.823	1.4083	1.3535	1.2986	1.3203	1.2437
15	.8596	.8048	1.2986	1.2071	1.262		
16	.7499	.823	1.39		1.2071	1.2637	
17	.9145	.8596	1.3169		1.2986	1.2826	
18	.9511	.9877	1.4083		1.4632		
19	1.0791	1.0791	1.5729		1.5729		
20	1.134	1.6095	1.5912	1.6409	1.5912		
21	1.1523	1.6095	1.5912		1.6461		
22	1.0974	1.5181	1.5729	1.5278	1.5546		
23	1.0791	1.4449	1.3535	1.4335	1.4815		1.4901
24	.8962	.9877	1.2803	1.2437	1.3957	1.2803	1.2803
Max	1.1706	1.6095	1.6278	1.6409	1.6827	1.701	1.6278
Min	.7316	.7316	1.0242	.9877	1.1317	1.0242	1.2437
Avg	.9442	1.0040	1.3973	1.2756	1.4052	1.2712	1.4174

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113018 / 22/11 KV BEST

Feeder No / Name : 201 / MARATHON

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.3961		.3961	.3801	.415	.3801
2	.3961	.3772		.3961	.362	.3961	.362
3	.3772	.3772		.3772	.3439	.3772	.362
4	.3772	.3772		.3772	.362	.3772	.3439
5	.3772	.3961		.3772	.362	.3772	.362
6	.415	.415		.3961	.4344	.3772	.3982
7	.6036	.4527		.4527	.4706	.4715	.4706
8	.6036	.5281		.4715	.5792	.4715	.5792
9	.6036	.5658		.547	.6516	.6447	.5731
10	.679	.7167	.591	.6447	.6979	.6089	.724
11	.7167	.6805	.5731	.5731	.6602	.6626	.6516
12	.6413	.5552		.6447	.7167	.6447	.7421
13	.5658	.6447		.5731	.6413		.6154
14	.5658	.5373	.4656	.4835	.6036	.5973	.543
15	.5552	.5373	.3582	.4477	.5658	.5373	.5249
16	.5194	.4477		.4298	.5658	.4706	.4706
17	.5731	.4835		.4835	.5281	.5249	.5068
18	.7167	.5373		.5014	.6036		.543
19	.8488		.5658	.5792	.6224	.5973	.6036
20	.6036			.5249	.5658	.543	.6036
21			.4715	.5792	.5658	.5611	.7167
22			.5093	.5249		.5068	.6036
23		.4338	.4338	.4706		.4887	
24	.4715	.415	.4527	.415	.4706	.4527	.4298
Max	.8488	.7167	.591	.6447	.7167	.6626	.7421
Min	.3772	.3772	.3582	.3772	.3439	.3772	.3439
Avg	.5554	.4937	.4912	.4861	.5342	.5047	.5265

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113018 / 22/11 KV BEST

Feeder No / Name : 202 / RITA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.5281		.5281	.5014	.5281	.5194
2	.4904	.4904		.4527	.4298	.4904	.4835
3	.4904	.4715		.4527	.394	.4527	.4656
4	.4904	.4527		.3772	.394	.4338	.4298
5	.4904	.4715		.3961	.4119	.4338	.4298
6	.5281	.4904		.4527	.4656	.4527	.4656
7	.5658	.4715		.5281	.5014	.4904	.5014
8	.6224	.5658		.5281	.591	.6602	.5373
9	.7356	.679		.5658	.6447	.7164	.6447
10	.7922	.6979	.6099	.6984	.8299	.7701	.8596
11	.9054	.788	.7522	.7343	.9054	.8238	.8596
12	.9054	.8417		.788	.9431	.8954	.8326
13	.8299	.7522		.7343	.7733	.788	.7164
14	.8299	.7522	.5731		.7733	.788	.6447
15	.7522	.6626	.5373	.6268	.7733	.7522	.6697
16	.7701	.6984		.6268	.7733	.788	.6697
17	.788	.6984		.6984	.7733	.7522	.6447
18	.8676	.7164		.7164	.7922	.7164	.6516
19	.9054		.7356	.788	.9054	.8238	.7545
20	.9431			.7701	.8676	.8417	.7733
21			.679	.7164	.7545	.7522	.7167
22			.6413	.6447		.6447	.679
23		.547	.5658	.5731		.591	
24	.6602	.6036	.5658	.5658	.5731	.5658	.591
Max	.9431	.8417	.7522	.788	.9431	.8954	.8596
Min	.4904	.4527	.5373	.3772	.394	.4338	.4298
Avg	.7109	.6190	.6289	.6071	.6714	.6647	.6322

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113018 / 22/11 KV BEST

Feeder No / Name : 203 / BHAWANI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.4904		.5281	.5228	.5658	.6161
2	.5281	.4715		.4527	.5041	.5281	.5975
3	.5281	.4527		.4527	.5228	.4904	.5975
4	.5281	.4527		.4527	.5228	.4904	.5601
5	.547	.4527		.4715	.5041	.5281	.5788
6	.6036	.4527		.5281	.5975	.5658	.5975
7	.679	.6036		.5658	.7095	.6979	.7282
8	.8299	.6979		.6224	.7468	.7545	.8029
9	1.0185	.8299		.679	.9522	1.0534	.9709
10	1.3203	1.0185	.9145	.8962	1.226	1.3014	1.251
11	1.4712	1.382	1.2012	1.1871	1.5089	1.4937	1.3352
12	1.5089	1.419		1.419	1.5466	1.4937	1.3112
13	1.3957	1.3466		1.2883	1.4335	1.5089	1.3014
14	1.226	1.2071	1.0059	1.1389	1.3957	1.307	1.2323
15	1.2012	1.1389	.9242	1.0829	1.3203	1.2757	1.1506
16	1.2826	1.2883		1.0642	1.3957	1.2403	1.1389
17	1.3352	1.2567		1.1389	1.4523	1.4003	1.1949
18	1.5089	1.4901		1.3817	1.5844	1.4937	1.2048
19	1.6598		1.4523	1.4937	1.5844	1.4937	1.358
20	1.5089			1.419	1.358	1.4937	1.2826
21			1.1883	1.2696	1.226	1.363	1.1317
22			.7922	.8029		.8962	.8676
23		.6224	.6036	.6348		.7468	
24	.6036	.5281	.6036	.5658	.5788	.6036	.6722
Max	1.6598	1.4901	1.4523	1.4937	1.5844	1.5089	1.358
Min	.5281	.4527	.6036	.4527	.5041	.4904	.5601
Avg	1.0405	.8801	.9651	.8973	1.0542	1.0328	.9775

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113018 / 22/11 KV BEST

Feeder No / Name : 204 / ASHOK CORPORATION

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1694	1.1317		.9431	1.094		1.1506
2	1.094	1.0185		.9054	.9431	1.0185	.9619
3	1.0562	.9808		.9054	.9054	.9431	.9054
4	1.0185	.9431		.9431	.8676	.8676	.8488
5	.9808	.9431		.9997	.8299	.8676	.811
6	.9808	.9808		1.0562	.9054	.8676	.8865
7	1.094	1.0374		1.2071	.9808	.9808	.9997
8	1.2803	1.1317		1.2637	1.2071	1.2071	1.1317
9	1.5089	1.5089		1.3014	1.5089	1.4003	1.4523
10	1.6975	1.6598	1.0164	1.5089	1.6598	1.643	1.7353
11	1.9805	1.922	1.2136	1.643	1.8107	1.9418	1.9418
12	2.2257	1.8107		1.773	1.9616	1.9616	1.8484
13	1.8107	1.643		1.6598	1.9616	1.643	1.643
14	1.8484	1.7924	.9709	1.7164	1.9616	1.7353	1.7924
15	1.773	1.7924	1.0269	1.5844	1.9616	1.5123	1.7924
16	1.8107	1.7924		1.8296	1.8861	1.7924	
17	1.6598	1.7924		1.5089	1.773	1.8107	1.643
18	1.8107	1.5592		1.5089	1.8107	1.8107	1.4937
19	1.8861		1.2071	1.6975	1.7918	1.8484	1.6221
20	1.6598			1.5089	1.5089	1.6975	1.3957
21			1.0751	1.4523	1.226	1.3203	1.3203
22			.9242	1.226		1.3014	1.2449
23		1.4901	1.0562	1.2826		1.2071	
24	1.2449	1.358	1.3957	.9619	1.2826	1.2071	1.2449
Max	2.2257	1.922	1.3957	1.8296	1.9616	1.9616	1.9418
Min	.9808	.9431	.9242	.9054	.8299	.8676	.811
Avg	1.5043	1.4144	1.0985	1.3495	1.4472	1.4167	1.3575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113018 / 22/11 KV BEST

Feeder No / Name : 205 / SONAR BUNGLOW SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8676	.9431		1.0185	.7973	.9431	.8505
2	.8299	.8676		.9808	.7442	.9054	.7619
3	.8299	.7922		.9431	.7087	.8676	.7442
4	.8299	.7545		.9054	.7265	.8299	.7265
5	.9054	.8676		.9054	.7442	.8676	.7265
6	.9808	1.0185		1.0185	.8505	.9054	.9036
7	1.2254	1.2071		1.094	1.0631	1.226	1.0631
8	1.358	1.358		1.1883	1.1871	1.358	1.3443
9	1.358	1.39		1.2449	1.4175	1.2934	1.3643
10	1.3957	1.5089	1.3443	1.3466	1.5089	1.3998	1.4175
11	1.4146	1.5089	1.3998	1.4146	1.3957	1.3676	1.3998
12	1.3203	1.3998		1.1871	1.226	1.2757	1.3769
13	1.3203	1.2826		.9922	1.2071	1.2382	1.2826
14	1.0562	1.0985	1.0631	1.0277	1.1317	.9568	.9745
15	.9391	1.134	1.0082	.9568	1.094	1.0099	.9335
16	1.0642	1.1694		.8682	1.1317	.8962	1.0808
17	1.0454	1.1576		1.0631	1.4523	.9391	1.0631
18	1.2071	1.1763		1.1871	1.226	1.0454	1.3014
19	1.4712		1.5844	1.2934	1.3957	1.2403	1.358
20	1.358			1.1517	1.3203	1.2048	1.3203
21			1.4146	1.2048	1.4146	1.2403	1.2071
22			1.4901	1.134		1.1871	1.226
23		1.3203	1.3769	1.0631		1.0808	
24	.9431	1.0374	1.0374	1.1128	.9036	1.0185	.9568
Max	1.4712	1.5089	1.5844	1.4146	1.5089	1.3998	1.4175
Min	.8299	.7545	1.0082	.8682	.7087	.8299	.7265
Avg	1.1295	1.1496	1.3021	1.0959	1.1203	1.0957	1.1036

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113018 / 22/11 KV BEST

Feeder No / Name : 207 / AMBEDKAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754		.0754	.0754	.0739	.0754	.0739
2	.0754	.0754		.0754	.0739	.0754	.0739
3	.0754	.0754		.0754	.0739	.0754	.0739
4	.0754	.0754		.0754	.0739	.0754	.0739
5	.0754	.0754		.0754	.0739	.0754	.0739
6	.0754	.0754		.0754	.0739	.0754	.0739
7	.0732	.0754		.0754	.0739	.0566	.0924
8	.0943	.0754		.0754	.0739	.0754	.0924
9	.0754	.0754		.0754	.0739	.0739	.0554
10	.0943		.0739	.0739	.0754	.0739	.0739
11	.0943	.0924	.0739	.0739	.0754	.0739	.0739
12	.0943	.0924		.0739	.0754	.0924	.0739
13	.0754	.0924		.0924	.0754	.0924	.0924
14	.0754	.0924	.0924	.0739		.0739	.0739
15	.0739	.0739	.0924	.0739	.0754	.0739	.0739
16	.0739	.0739		.0739	.0754	.0739	.0739
17	.0739	.0739		.0924	.0754	.0739	.0739
18	.0754	.0739		.0924	.0754	.0924	.0739
19	.0754		.0943	.1109	.0754	.1109	.0943
20	.0943			.1109	.1132	.0924	.0943
21			.0943	.0924	.0754	.0924	.0943
22			.0754	.0924		.0924	.0943
23		.0754	.0754	.0924		.0924	
24	.0754	.0754		.0754	.0924	.0754	.0739
Max	.0943	.0924	.0943	.1109	.1132	.1109	.0943
Min	.0732	.0739	.0739	.0739	.0739	.0566	.0554
Avg	.0796	.0788	.0830	.0822	.0774	.0806	.0791

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113018 / 22/11 KV BEST

Feeder No / Name : 208 / CAMP III

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3395	.3206	.3018	.3326	.3772	.3326
2	.3206	.3206		.3018	.3142	.3395	.3326
3	.3018	.3018		.3018	.3142	.3018	.3142
4	.3018	.3018		.3395	.2957	.3018	.3142
5	.3395	.3018		.3584	.2957	.3018	.3326
6	.3772	.3018		.3772	.3142	.3395	.3142
7	.439	.3395		.3961	.3696	.3772	.4066
8	.547	.415		.3961	.4251	.4904	.462
9	.5658	.4904		.4338	.6468	.499	.499
10	.5658	.5281	.5914	.5175		.5359	.5729
11	.5658	.5544	.5729	.5544	.6036	.5544	.5175
12	.547	.5175		.5359	.5658	.5544	.5359
13	.5281	.5544		.5359	.4715	.5175	.5175
14	.4715	.4435	.4251	.4435	.415	.462	.4066
15	.4251	.4251	.3881	.4066		.4435	
16	.4251	.4066		.4066	.415	.4066	.3696
17	.4435	.4066		.4066	.4527	.4435	.3881
18	.5281	.4805		.462	.4527	.4805	.4435
19	.5658		.4338	.5544	.5281	.499	.4904
20	.5281			.499	.5281	.5544	.4904
21			.4527	.499	.5658	.499	.5093
22			.415	.4805		.4805	.4527
23		.3584	.4338	.4251		.4066	
24	.3772	.3772		.3395	.3511	.3772	.3881
Max	.5658	.5544	.5914	.5544	.6468	.5544	.5729
Min	.3018	.3018	.3206	.3018	.2957	.3018	.3142
Avg	.4525	.4082	.4482	.4280	.4329	.4393	.4268

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113018 / 22/11 KV BEST

Feeder No / Name : 211 / ESIS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1886		.1509	.1494	.1698	.168
2	.1509	.1698		.1509	.1494	.1509	.168
3	.1509	.1509		.1509	.1494	.1509	.1494
4	.1509			.1509	.1494	.1509	.1494
5	.1509			.1509	.1494	.1509	.1494
6	.1509			.1509	.1494	.1509	.1494
7	.1509	.1509		.1509	.1494	.1509	.168
8	.1698	.1509		.1509	.168	.1698	.2241
9	.2263	.1509		.1509	.168	.2263	.2427
10	.2075	.1886	.2195	.2075	.1886	.2218	.2241
11	.1886	.168	.2241	.2263	.2075	.2263	.2263
12	.1886	.1886		.2241	.1886	.2427	.2263
13	.1698	.1772		.2241	.1886	.1509	.1698
14	.2263	.1509	.1509	.1494	.1698	.1867	.1698
15	.1494	.1509	.1509	.1494	.1509	.1509	.1509
16	.1494	.1509		.1494	.1509	.1478	.1509
17	.1509	.1509		.1494	.1509	.1494	.1509
18	.1886	.168		.168	.2263	.1867	.168
19	.2263		.1509	.2054	.1886	.2054	.1886
20	.1886			.1867	.1886	.2241	.2263
21	.2263		.1509	.2054		.2241	.1886
22			.1509	.1867		.2427	.2263
23		.1886	.1509	.168		.2241	
24	.1886	.1886	.1886	.1509	.1494	.1886	.1867
Max	.2263	.1886	.2241	.2263	.2263	.2427	.2427
Min	.1494	.1509	.1509	.1494	.1494	.1478	.1494
Avg	.1782	.1667	.1708	.1712	.1681	.1851	.1836

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113025 / 22/11 KV NIRMAL LIFE S/STN

Feeder No / Name : 200 / Corporate SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3547	.4668	.4668	.4668	.4481	.3734	.4108
2	.2987	.3734	.3734	.4108	.3734	.3174	
3	.2801	.3361	.3174	.3547	.3361	.2801	.2987
4	.2614	.2987	.2427	.2987	.2987	.2614	.2614
5	.2614	.2801	.2427	.2801	.2801	.2427	.2427
6	.2614	.2801	.2614	.2987	.2801	.2427	.2614
7	.2614	.2614	.2614	.3174	.2614	.2614	.2614
8	.4108	.3734	.4108	.4294	.3174	.3361	.4294
9	.5601	.4481	.5788	.6722	.6348	.5041	.4854
10	.8402	.5601	.5415	.7468	.8402	.8589	.9335
11	.9709	.8215	.7655	.7655	.8029	.9149	1.0642
12	.9149	.8402	.7468	.8589	.9896	.9896	.9335
13	.9709	.8029	.7468	.8402	1.0082	.9335	.9335
14	.8775	.8402	.7282	.8402	1.0269	.9149	.8775
15	.9896	.9335	.6722		1.0269	.8962	.9896
16	.9896	1.0456	.6348	.9335	1.0456	.8775	.9709
17	1.0269	1.0456	.8029	1.0082	1.0082	.8402	.9335
18	1.0269	.9335	.8589	.9149	.9335	1.1016	.9522
19	.9522	.8402	.9335	.9709	.8775	.8589	.8962
20	.7842	.8029	.8402	.8215	.7468	.8215	.7655
21	.6908	.7842	.7468	.7842	.6535	.7468	.7468
22	.6908	.6535	.6161	.6348	.5601	.7282	.6161
23	.5601	.5601	.6161	.5415	.4854	.5228	.5415
24	.3921	.5228	.4214	.5041	.5228	.4294	.4668
Max	1.0269	1.0456	.9335	1.0082	1.0456	1.1016	1.0642
Min	.2614	.2614	.2427	.2801	.2614	.2427	.2427
Avg	.6512	.6294	.5761	.6389	.6566	.6356	.6640

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113025 / 22/11 KV NIRMAL LIFE S/STN

Feeder No / Name : 201 / OPEL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1067	.1067	.1067	.1067	.1052	.1052
2	.1067	.1067	.1067	.1067	.1067	.1052	.1052
3	.1067	.1067	.1067	.1067	.1067	.1052	.1052
4	.1067	.1067	.1067	.1067	.1067	.1052	.1052
5	.1067	.1067	.1067	.1067	.1067	.1052	.1052
6	.1334	.1067	.1067	.1067	.1067	.1052	.1052
7	.16	.1067	.1067	.1067	.1067	.1052	.1052
8	.16	.1067	.12	.1067	.1067	.1052	.1052
9	.1867	.12	.1334	.1867	.1467	.1183	.1315
10	.1067	.12	.16	.12	.1334	.184	.1052
11	.1067	.1334	.1867		.1067	.1315	.1052
12	.1067	.12	.16	.1067	.1067	.184	.1052
13	.1067	.1067	.16	.1067	.1067	.1315	.1052
14	.1067	.1067	.1334	.1067	.1067	.1052	.1052
15	.1067	.1067	.1334		.1067	.1052	
16	.1067	.1067	.1334	.1067	.1067	.1052	.1052
17	.1067	.1067	.1334	.1067	.1067	.1052	.1052
18	.1067	.1067	.16	.12	.1067	.1052	.1052
19	.1067	.1067	.1334	.1067	.1067	.1578	.1052
20	.1067	.12	.16	.1067	.1067	.1578	.1052
21	.1067	.12	.1334	.1067	.1067	.1315	.1052
22	.1067	.1067	.16	.1067	.1067	.1578	.1052
23	.1067	.1067	.1334	.12	.1067	.1315	.1052
24	.1334	.1067	.1067	.1067	.1067	.1067	.1052
Max	.1867	.1334	.1867	.1867	.1467	.184	.1315
Min	.1067	.1067	.1067	.1067	.1067	.1052	.1052
Avg	.1178	.1106	.1328	.1122	.1095	.1233	.1063

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113025 / 22/11 KV NIRMAL LIFE S/STN

Feeder No / Name : 202 / Amruta

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6622	.6923	.602	.6622	.6472	.6321	.602
2	.602	.6622	.602	.602	.6321	.602	.5719
3	.587	.6321	.5719	.5418	.587	.587	.5418
4	.5719	.602	.5268	.4816	.5569	.5268	.5117
5	.6171	.5719	.5268	.4816	.5719	.5268	.5268
6	.6773	.6171	.587	.5117	.6321	.602	.587
7	.7375	.6622	.6472	.5268	.6622	.7225	.6773
8	.8278	.7375	.6321	.5719	.7375	.7375	.6171
9	.9783	.8579	.7375	.8128	.7827	.873	.888
10	1.0084	.9031	.888	.8579	1.0385	.9482	.9934
11	1.0084	.9783	.7827	.9031	.9783	.873	.9181
12	.9332	.888	.9031	.8278	.9181	.9783	.9031
13	.9934	.8278	.8579	.8579	.9031	.7827	.9332
14	.8128	.7827	.7225	.7225	.888	.8429	.7977
15	.8128	.7977	.6923		.8579	.9031	.7375
16	.7977	.8278	.6321	.7526	.8579	.8278	.8278
17	.9482	.873	.6472	.7526	.9031	.7375	.8128
18	1.0084	.7827	.8278	.7225	.888	.8128	.8278
19	.9482	.7526	.8128	.7977	.9031	.8278	.8579
20	.873	.7375	.8579	.7375	.873	.8429	.9031
21	.873		.7074	.7375	.8278	.873	.8128
22	.7977	.6773	.6321	.7526	.7827	.7526	.7526
23	.7676	.6321	.6321	.7225	.7526	.7375	.7225
24	.7225	.6773	.6923	.6923	.6622	.6923	.6472
Max	1.0084	.9783	.9031	.9031	1.0385	.9783	.9934
Min	.5719	.5719	.5268	.4816	.5569	.5268	.5117
Avg	.8153	.7467	.6967	.6969	.7852	.7601	.7488

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113025 / 22/11 KV NIRMAL LIFE S/STN

Feeder No / Name : 203 / Runwal SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1128	.1128	.1128	.1128	.1128	.1128	.1128
2	.1128		.1128	.1128	.1128	.1128	.1128
3	.1128	.1128	.1067	.1128	.1128	.1128	.1128
4	.1128	.1128	.1128	.1128	.1128	.1128	.1128
5	.1128	.1128	.1128	.1128	.1128	.1128	.1128
6	.1128	.1128	.1128	.1128	.1128	.1128	.1128
7	.1128	.1128	.1128	.1269	.1128	.1128	.1128
8	.1128	.1128	.1128	.1128	.1128	.1128	.1128
9	.1128	.1128	.1128	.1128	.1113	.1128	.1128
10	.1128	.1269	.141	.1128	.1128	.141	.1128
11	.1128	.141	.1128	.141	.1204	.1128	.1128
12	.1128	.1128	.1128	.1128	.1128	.1692	.1128
13	.1128	.1128	.1692	.1128	.1128	.141	.1128
14	.1128	.1128	.1692	.1128	.1128	.141	.1128
15	.1128	.1128	.141		.1128	.141	.1128
16	.1128	.1128	.141	.1128	.1128	.1692	.1128
17	.1128	.1128	.1692	.1128	.1128	.141	.1128
18	.1128	.1128	.141	.1128	.1128	.1692	.1128
19	.1097	.1128	.141	.1128	.1128	.1128	.1128
20	.1128	.1128	.1128	.1128	.1269	.1128	.1128
21	.1128	.1128	.1128	.1128	.1269	.141	.1128
22	.1128	.1128	.1128	.1128	.1269	.1128	.1128
23	.1128	.1128	.1128	.1128	.1128	.1128	.1128
24	.1128	.1128	.1128	.1128	.1128	.1128	.1128
Max	.1128	.141	.1692	.141	.1269	.1692	.1128
Min	.1097	.1128	.1067	.1128	.1113	.1128	.1128
Avg	.1127	.1146	.1255	.1146	.1148	.1269	.1128

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113025 / 22/11 KV NIRMAL LIFE S/STN

Feeder No / Name : 204 / sonapur htp SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	1.0562	1.094	.679	.4715	.4527	.415
2	.8676	.9997	1.0374	.6224	.4338	.415	.3772
3	.8488	.9431	.9808	.5658	.3772	.415	.3584
4	.8488	.9619	.9431	.5847	.3772	.4527	.3584
5	1.0562	.9431	.9431	.6413	.3961	.4527	.3961
6	1.3203	1.0751	1.0751	.679	.4338	.5093	.4338
7	1.4146	1.2637	1.1317	.7733	.4904	.6224	.4715
8	1.8107	1.3392	1.1317	.811	.6036	.8488	.547
9	1.9805	1.6221	1.2637	.9431	.7545	.7356	.7545
10	2.1125	1.8861	1.1506	1.094	.811	.8865	.7922
11	1.9427	2.0936	1.1128	1.0562	.8865	.7922	.8488
12	1.9993	1.8484	1.1317	1.0562	.8488	.7922	.8865
13	1.7353	1.7918	.9619	.9054	.7922	.7733	.8299
14	1.8296	1.773	.9431	.8865	.7733	.7545	.7545
15	1.9239	1.7353	.9054		.7545	.679	.7733
16	1.7918	1.7164	.8299	.5658	.7545	.6979	.7545
17	1.7164	1.7541	.7733	.4904	.7733	.7545	.7545
18	1.7353	1.6975	.8865	.4715	.7545	.7545	.7545
19	1.7541	1.5278	.9619	.4338	.6602	.6979	.7356
20	1.6975	1.4335	.9242	.4527	.6602	.6602	.6224
21	1.5655	1.3014	.8299	.3961	.679	.5658	.5847
22	1.3957	1.226	.7922	.3395	.6224	.547	.5658
23	1.0185	1.1694	.7545	.4904	.547	.5093	.5093
24	.9997	1.0185	1.1317	.7733	.4527	.4904	.4904
Max	2.1125	2.0936	1.2637	1.094	.8865	.8865	.8865
Min	.8488	.9431	.7545	.3395	.3772	.415	.3584
Avg	1.5129	1.4240	.9871	.6831	.6295	.6358	.6154

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113025 / 22/11 KV NIRMAL LIFE S/STN

Feeder No / Name : 205 / vasant oscar 2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4842	1.5384	1.6289	1.4842	1.6289	1.7194	1.5203
2	1.448	1.4842	1.5384	1.4118	1.5927	1.6289	1.448
3	1.4118	1.448	1.4299	1.3575	1.5746	1.448	1.3756
4	1.3575	1.4118	1.3394	1.3032	1.5384	1.448	1.3032
5	1.4842	1.3575	1.3032	1.3394	1.5927	1.448	1.3575
6	1.647	1.4299	1.3394	1.3937	1.647	1.4299	1.3937
7	1.7194	1.4842	1.4842	1.4661	1.7013	1.7194	1.4299
8	1.7918	1.647	1.6832	1.6832	1.6832	1.8099	1.7194
9	2.0633	1.9366	1.8823	1.9728	1.9185	1.9185	1.9366
10	2.2081	1.9909	2.0633	2.1357	2.2624	2.1719	2.1176
11	2.0452	2.1719	1.9547	2.4072	2.0633	1.9004	3.0226
12	1.9728	2.1538	1.9185	2.2986	1.9547	2.0633	1.9366
13	1.7375	1.9728	1.9004	2.1538	1.9004	1.9004	1.7918
14	1.5203	1.8823	1.8642	1.7556	1.8099	1.7375	1.6651
15	1.5023	1.8099	1.6651		1.7194	1.5927	1.5565
16	1.4842	1.647	1.5023	1.5565	1.5746	1.5927	1.4661
17	1.5565	1.7194	1.5927	1.5203	1.5384	1.647	1.3937
18	1.7737	1.6651	1.8823	1.7194	1.8099	1.8642	1.7194
19	2.0271	1.8099	2.0452	2.1176	2.1176	2.009	1.8823
20	2.0814	1.9366	2.0271	2.2262	2.0271	1.8299	1.9366
21	2.1125	2.0633	1.8823	2.0633	1.9909	1.9547	1.8099
22	1.9004	1.9728	1.8461	2.1691	1.9004	1.828	1.828
23	1.7013	1.8099	1.5927	1.7737	1.7737	1.7918	1.7375
24	1.5565	1.5565	1.7194	1.5565	1.6289	1.7013	1.5927
Max	2.2081	2.1719	2.0633	2.4072	2.2624	2.1719	3.0226
Min	1.3575	1.3575	1.3032	1.3032	1.5384	1.4299	1.3032
Avg	1.7328	1.7458	1.7119	1.7768	1.7895	1.7565	1.7059

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - III[551]

MUMBRA[152] BU 4391

Substation No/ Name :- 283087 / BHARAT GEAR SWITCHING

STATION

Feeder No / Name : 301 / SAGAR

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)
13	7.1674	
24		7.1674
Max	7.1674	7.1674
Min	7.1674	7.1674
Avg	7.1674	7.1674

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - III[551]

MUMBRA[152] BU 4391

Substation No/ Name :- 283087 / BHARAT GEAR SWITCHING

STATION

Feeder No / Name : 303 / SHIL PHATA

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)
13	.7602	
24		.8413
Max	.7602	.8413
Min	.7602	.8413
Avg	.7602	.8413

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - III[551]

MUMBRA[152] BU 4391

Substation No/ Name :- 283087 / BHARAT GEAR SWITCHING

STATION

Feeder No / Name : 304 / KAUSA

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)
13	7.3922	
24		5.6927
Max	7.3922	5.6927
Min	7.3922	5.6927
Avg	7.3922	5.6927

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - III[551]

MUMBRA[152] BU 4391

Substation No/ Name :- 283087 / BHARAT GEAR SWITCHING

STATION

Feeder No / Name : 308 / Devari Pada

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)
13	2.3529	
24		2.1971
Max	2.3529	2.1971
Min	2.3529	2.1971
Avg	2.3529	2.1971

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - III[551]

SHIL SUB DIVISION[643] BU 4643

Substation No/ Name :- 283090 / khidkali s/s

Feeder No / Name : 301 / DIVA

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.7215	7.2017		6.1728	6.6873	6.8587	7.2017
2	6.5158	6.8587	6.2071	5.8299	6.0014	6.5158	6.5158
3	6.3443	6.5158	5.8299	6.1043	5.8299	6.1728	6.6873
4	6.8587	6.1728	6.5844	6.7901	7.2017	7.0302	7.5446
5	7.5446	7.0302	7.0302	8.1962	8.4705	8.4019	8.4019
6	8.7449	8.4019	7.7161	9.2593	8.7449	8.9163	8.9849
7	9.2593	9.0878	7.6475	9.0535	8.882	9.2593	8.882
8	8.5734	8.7449	8.4019	8.642	8.9163	8.7449	8.642
9	7.5446		8.8135		8.3676	7.8875	
10	6.6873		8.1619	7.8189	7.5103	7.3045	
11	6.1728	7.0645	7.4417		7.0302	7.2017	
12	6.2414		6.9273	6.4815	6.3443	6.2071	
13		6.0014	6.3786		5.8299	5.9671	
14			5.6584		5.7613	5.5556	
15	7.8875	5.3841	5.4184	6.4129	5.144		
16	6.4129	5.487	5.6242		5.6584		
17	6.5158		5.9328	6.0014	6.3443	5.7956	5.6584
18	7.5446	6.653	7.1674	6.9959	7.2017	7.1674	6.5158
19	9.2593	9.1221	7.7161	9.465	9.4307	9.1907	9.2936
20	9.6022	9.4993	9.6022	9.4307	9.7737	9.0192	
21	9.6022	10.0823	9.4307	9.2936	9.8423	9.3964	9.0535
22	9.2593		9.225	9.2936	8.9163	9.0878	8.642
23	8.9163	8.2648	8.5734	8.0933	7.7161	7.8532	7.7504
24	7.0302	7.8875	6.9616	7.0302	7.2017	7.3731	7.6132
Max	9.6022	10.0823	9.6022	9.465	9.8423	9.3964	9.2936
Min	6.1728	5.3841	5.4184	5.8299	5.144	5.5556	5.6584
Avg	7.6927	7.5255	7.3239	7.7034	7.4503	7.5867	7.8258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

KALWA S/DN.[128]

BU 4261

Substation No/ Name :- 283086 / SHIVAJI HOSPITAL 22/11 KV

Feeder No / Name : 204 / S. T. WORKSHOP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.134	1.1104	1.0208	1.0387	1.0608	1.0387	1.0608
2	1.0608	1.0387	.9671	.9671	.9877	.9671	
3	1.0242	.985	.9313	.9671	.9145	.9313	.9511
4	.9877	.985	.8954	.9313	.9145	.8954	.9145
5	1.0425		.9671	.9671	.9877	.985	1.0242
6	1.1706	1.1104	1.0387	1.0387	1.0974	1.0745	1.1157
7	1.2986	1.2178	1.0208	1.0745	1.0974	1.1999	1.1523
8	1.4266	1.2894	1.1104	1.182	1.1706	1.3611	1.3717
9	1.4632	1.3432	1.2536	1.3432	1.39	1.4685	1.4998
10	1.4632	1.4864	1.3611	1.4083	1.5546		1.379
11	1.5223	1.3969	1.3611	1.4266		1.4266	1.3969
12	1.3432	1.3253	1.2894	1.3352	1.379	1.3717	1.3611
13	1.2715	1.2536	1.2894	1.2803	1.2536	1.2254	1.1283
14	1.1999	1.1104	1.0745	1.0974	1.1641	1.0974	1.0745
15	1.1462	1.0208	1.0387	.8779	1.0566	1.0425	1.0208
16	1.0745	1.0387	.9671	.8048	1.0208	.9877	.9492
17	1.0745	1.0208	1.0208	.8596	.985	1.0242	1.0745
18	1.6476	1.3432	1.3073	1.5364	1.2894	1.2071	1.3253
19	1.6476	1.6834	1.576	1.6095	1.576	1.5546	1.6297
20	1.6834	1.6834	1.5402	1.5729	1.6118	1.6095	1.576
21	1.6118	1.5043	1.4864	1.4449	1.5223	1.4998	1.4327
22	1.4685	1.3969	1.3969	1.3352	1.379	1.4083	1.3611
23	.1433	1.3611	1.2894	1.2437	1.2536		1.2536
24	1.2071	1.2178	1.1104	1.1283	1.134	1.1104	1.0974
Max	1.6834	1.6834	1.576	1.6095	1.6118	1.6095	1.6297
Min	.1433	.985	.8954	.8048	.9145	.8954	.9145
Avg	1.2547	1.2575	1.1797	1.1863	1.2087	1.2039	1.2239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

KALWA S/DN.[128]

BU 4261

Substation No/ Name :- 283086 / SHIVAJI HOSPITAL 22/11 KV

Feeder No / Name : 205 / SHIVAJI HOSPITAL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1646	.1509	.1698	.1509	.1463	.1509	.1463
2	.1463	.1509	.1509	.1509	.1463	.1509	.1463
3	.1463	.1509	.1509	.1509	.1463	.1509	.1463
4	.1463	.1509	.1509	.1509	.1463	.0754	.1463
5	.1463	.1509	.1509	.1509	.1463	.0943	.1463
6	.1463	.1509	.1509	.1509	.1463	.1132	.1463
7	.1646	.1509	.1509	.1509	.1463	.0377	.1463
8	.1646	.1509	.1509	.1698	.1646	.0754	.1646
9	.2561	.2263	.1509	.1698	.2195	.2075	.2012
10	.2561	.2641	.1509	.2012	.567		.2263
11	.2641	.2829	.1509	.2012		.3109	.2641
12	.2641	.2641	.1698	.1829	.2829	.3292	.2263
13	.2641	.2452	.1509	.1829	.3018	.3109	.2641
14	.2263	.3018	.1509	.2012	.2452	.3292	.2452
15	.2075	.1886	.1509	.1829	.2641	.2743	.1886
16	.1886	.2075	.1509	.1463	.2829	.2378	.2075
17	.1698	.2075	.1509		.1698	.1829	.1698
18	.1698	.1698	.1509	.1829	.1886	.1829	.1698
19	.1886	.1886	.1509	.1646	.1886	.1829	.1698
20	.1509	.1698	.1509	.1646	.1698	.1646	.1509
21	.1698	.1698	.1509	.1646	.1698	.1646	.1509
22	.1509	.1698		.1646	.1509	.1463	.1509
23	.1509	.1509	.1509	.1463	.1698		.1509
24	.1646	.1509	.1698	.1509	.1463	.1509	.1463
Max	.2641	.3018	.1698	.2012	.567	.3292	.2641
Min	.1463	.1509	.1509	.1463	.1463	.0377	.1463
Avg	.1861	.1902	.1534	.1667	.2046	.1829	.1780

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

KALWA S/DN.[128]

BU 4261

Substation No/ Name :- 283086 / SHIVAJI HOSPITAL 22/11 KV

Feeder No / Name : 301 / CHINCHPADA

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8413	.8048	.8048	.7316	.8048	.8048	.7682
2	.8048	.7316	.7682	.695	.7316	.7682	.7316
3	.7682	.7316	.7316	.6584	.695	.7316	.695
4	.7682	.7316	.695	.695	.6584	.695	.7316
5	.8413	.7682	.7682	.695	.8048	.8048	.7682
6	.9511	.8779	.8048	.7682	.9145	.9145	.8048
7	1.0608	.9511	.8048	.8413	.9511	.9511	.9511
8	1.1694	1.134	.9511	.9877	1.1706	1.1706	1.134
9	1.2437	1.0974	1.0974	1.1706	1.2071	1.3169	1.1706
10	1.1706	1.2437	1.0242	1.1706	1.134		1.2071
11		1.0974	1.0242	.9877		1.2437	1.134
12		1.0242	1.0242	.9145	1.0242	1.0974	1.0608
13	.9877	.9145	.9877	.8413	.9877		.9511
14	.8048	.8779	.8779	.8048		.9145	.8413
15	.7682	.7316	.8048	.7545	.8048	.8413	.7682
16	.7316	.7316	.695	.7316	.7316	.7316	.7316
17	.7316	.8048	.695	.9511	.8048	.8048	.7682
18	.8779	1.0242	1.3169	1.2437	.8779	.9145	.9145
19	1.134	1.3169	1.3169	1.2437	1.2803	1.2437	1.2071
20	1.0974	1.3203	1.2437	1.2437	1.3169	1.2803	1.2437
21	1.134	1.1706	1.2071	1.134	1.2803	1.1706	1.2437
22	1.0242	1.0242	1.0242	.9877	1.0974	1.0974	1.0608
23	.9511	.9877	.9511	.9511	.9877		1.0242
24	.8779	.8779	.8413	.8048	.8413	.8779	.8048
Max	1.2437	1.3203	1.3169	1.2437	1.3169	1.3169	1.2437
Min	.7316	.7316	.695	.6584	.6584	.695	.695
Avg	.9427	.9573	.9358	.9170	.9594	.9702	.9465

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

KALWA S/DN.[128]

BU 4261

Substation No/ Name :- 283086 / SHIVAJI HOSPITAL 22/11 KV

Feeder No / Name : 302 / KALWA NAKA

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0485	2.0328	1.9959	1.9589	1.9387	1.9959	2.0119
2	1.9753	1.922	1.922	1.848	1.829	1.922	1.9753
3	1.9753	1.848	1.848	1.7741	1.7558	1.885	1.9022
4	1.9022	1.848	1.7741	1.7741	1.6827	1.8111	1.8656
5	2.1948	2.1437	1.922		1.829	2.1807	1.7924
6	2.5972	2.3655	2.0698	2.0698	2.5606	2.4764	2.2314
7	2.9264	2.809	2.2916	2.3285	2.6337	2.6612	2.6337
8	2.9264	2.7721	2.5133	2.5133	2.9264	2.9938	2.963
9	2.9264		2.6981	2.846	2.8532	2.9569	2.9995
10	2.6337	2.7351	2.7351	2.4874	2.7069		2.6981
11	2.3655	2.4025	2.6981	2.1948		2.4874	2.4764
12	2.3285	2.3285	2.4764	2.1948	2.2177	2.1948	2.2916
13	2.1437	2.2177	2.0698	2.0485	2.1437	2.0119	1.9959
14	1.9589	1.9589	2.0698	1.829	1.9959	1.8781	1.922
15	1.8111	1.7741	1.922	1.6827	1.848	1.829	1.7741
16	1.7002	1.7372	1.8111	1.829	1.6632	1.7193	1.7372
17	1.885	1.848	1.7741	1.9387	1.7372	1.829	1.9589
18	2.1068	2.3285	2.2916	2.4143	2.1068	1.7193	2.1068
19	2.7351	2.7351	2.7801	2.7435	2.5503	2.7801	2.6981
20	2.7351	2.809	2.5873	2.7069	2.8829	2.7801	2.809
21	2.7721	2.7351	2.6242	2.8898	2.8829	2.6703	2.809
22	2.6612	2.6612	2.5133	2.6337	2.6612	2.5606	2.6612
23	2.4764	2.4025	2.3655	2.3411	2.3655		2.4394
24	2.1948	2.1807	2.1068	2.1068	2.0851	2.1807	2.0851
Max	2.9264	2.809	2.7801	2.8898	2.9264	2.9938	2.9995
Min	1.7002	1.7372	1.7741	1.6827	1.6632	1.7193	1.7372
Avg	2.3325	2.2867	2.2442	2.2241	2.2546	2.2511	2.2849

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

POWER HOUSE S/DN.[727] BU 4727

Substation No/ Name :- 283070 / THANE (W)RECVING STATION

Feeder No / Name : 201 / CLOCK TOWER SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9955					.9955	
2		1.0059		.924	.924		.8316
3	.905					.905	
4		.9145		.924	.924		.8316
5	.9335					.905	
6		1.0059		1.0059	1.1088		1.1088
7	1.267		.1848			1.1765	
8		1.2803		1.267	1.267		
10	1.6289		1.386	1.5384	1.5384	1.448	1.5384
12	1.7194	1.6632	1.4632	1.5384	1.6289	1.7194	1.6632
14	1.7556	1.5708	1.386	1.448	1.6289	1.6289	1.6289
15							1.448
16	1.6461			1.386	1.5384	1.5384	
18	1.9404	1.9404	1.6632	1.7556	1.7194	1.7556	1.7375
20	2.0328	1.848	1.7556	1.848	1.8099	1.7556	1.829
22	1.5708	1.4784	1.4784	1.4784		1.386	1.4632
23	1.1088						
24	1.086		1.1088	1.1088	1.1203	1.086	1.0164
Max	2.0328	1.9404	1.7556	1.848	1.8099	1.7556	1.829
Min	.905	.9145	.1848	.924	.924	.905	.8316
Avg	1.4300	1.4119	1.3033	1.3519	1.3825	1.3583	1.3724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

POWER HOUSE S/DN.[727] BU 4727

Substation No/ Name :- 283070 / THANE (W)RECIIVING STATION

Feeder No / Name : 202 / BALAWANT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734			1.0269		1.587	
2		.9335		.7468	.8402		.8402
3	.8402					1.4003	
4		.8402		.7468	.8402		.8402
5	.9335					1.4003	
6		1.0269		.8402	1.0269		1.0269
7	1.2136					1.9605	
8		1.2136		1.1203	1.307		
10	1.9605		1.4937	1.587	1.7737	3.2674	1.7737
12	1.8671	1.9605	1.4937	1.587	3.0807	3.0807	1.9605
14	1.6804	1.587	1.4003	1.4937	2.9874	1.7737	1.6804
15							1.6804
16	1.7737			1.4003	2.8006	1.6804	
18	2.0538	1.848	1.307	1.587	2.9874	1.9605	1.8671
20	1.9605	1.8671	1.4937	1.6804	3.0807	1.8671	1.7737
22	1.4937	1.4937	1.4003	1.4003		1.4003	1.587
23	1.1203						
24	1.1203		1.0269	1.0269	1.0269	1.7737	1.0269
Max	2.0538	1.9605	1.4937	1.6804	3.0807	3.2674	1.9605
Min	.3734	.8402	1.0269	.7468	.8402	1.4003	.8402
Avg	1.4147	1.4189	1.3737	1.2495	1.9774	1.9293	1.4597

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

POWER HOUSE S/DN.[727] BU 4727

Substation No/ Name :- 283070 / THANE (W)RECVING STATION

Feeder No / Name : 203 / RAVI UDAY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829					.1829	
2		.2743		.2743	.2772		.2772
3	.1829					.1829	
4		.1829		.1829	.1848		.1848
5	.1829					.1829	
6		.2743		.2743	.1848		.1848
7	.2743					.1829	
8		.2743		.3658	.3658		
10	.3658		.3658	.3658	.3658	.3658	.4572
12	.4572	.462	.4572	.4572	.4572	.4572	.4572
14		.462	.3658	.4572	.4572	.5487	.4572
15	.462						.4572
16	.4572			.3696	.4572	.4572	
18	.5487	.5601	.3658	.462	.4572	.462	.4572
20	.5487	.5544	.4572	.462	.4572		.4572
22	.3658	.3696		.3696		.3696	.3658
23	.2743						
24	.1829		.2772	.2743	.2772	.1829	.2772
Max	.5487	.5601	.4572	.462	.4572	.5487	.4572
Min	.1829	.1829	.2772	.1829	.1848	.1829	.1848
Avg	.3450	.3793	.3815	.3596	.3583	.325	.3666

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

POWER HOUSE S/DN.[727] BU 4727

Substation No/ Name :- 283070 / THANE (W)RECVING STATION

Feeder No / Name : 204 / NIRAJ

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867					.1867	
2		.1867		.2801	.2801		.2772
3	.1867					.1867	
4		.0934		.1867	.2801		.2772
5	.1867					.1867	
6		.0934		.2801	.2801		.2801
7	.1867					.2801	
8		.1867		.3734	.3734		
10	.1867		.4668	.4668	.6535	.6535	.6535
12	.2801	.2801	.7468	.8402	.9335	.9335	1.0269
14	.2801	.2801	.6535	.6535	.8402	.8402	.9335
15							.7468
16	.2801			.5601	.9335	.9335	
18	.2801	.2543	.7468	.6535	.9335	.9335	.9335
20	.3734	.3734	.8402	.6535	.8402	.8402	1.8298
22	.2801	.2801		.3696		.3734	.3734
23	.1867						
24	.1867		.2801	.2801	.2801	.1867	.2801
Max	.3734	.3734	.8402	.8402	.9335	.9335	1.8298
Min	.1867	.0934	.2801	.1867	.2801	.1867	.2772
Avg	.2370	.2254	.6224	.4665	.6026	.5446	.692

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

POWER HOUSE S/DN.[727] BU 4727

Substation No/ Name :- 283070 / THANE (W)RECVING STATION

Feeder No / Name : 205 / THANE AUDITORIUM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801					.4668	
2		.2801		.2801	.2801		.2801
3	.1867					.3734	
4		.2801		.2801	.1867		.2801
5	.1867					.3734	
6		.2801			.2801		.3734
7	.3734					.3734	
8		.3734		.3734	.3734		
10	.6602		.5601	.5601	.6535	.6602	.7545
12	.8488	.7468	.6535	.8402	.7468	.8402	.8402
14	.7468	.8402	.6535	.7468	.7468	.8488	.8488
15							.8488
16	.8488			.6535	.9335	.8488	
18	.8402	.8402	.9335	.6535	1.0269	.9335	.9335
20		.9335	.9335	.7468	.7468	.8402	.8402
22	.4668	.5601		.5601		.5601	.5601
23	.3734						
24	.3734		.3734	.3734		.4668	.3734
Max	.8488	.9335	.9335	.8402	1.0269	.9335	.9335
Min	.1867	.2801	.3734	.2801	.1867	.3734	.2801
Avg	.5154	.5705	.6846	.5516	.5975	.6321	.6303

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

POWER HOUSE S/DN.[727] BU 4727

Substation No/ Name :- 283070 / THANE (W)RECIIVING STATION

Feeder No / Name : 206 / PURNIMA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4668					.3734	
2		.4668		.2801	.2801		.2801
3	.3734					.2801	
4		.3734		.2801	.1867		.2801
5	.3734					.2801	
6		.4668		.3734	.2801		.3734
7	.4668					.3734	
8		.6535		.4668	.5601		
10	1.307		.8402	.7468	1.0269	.9335	.9335
12	2.0538	2.0538	1.2136	1.1203	1.4937	1.4937	1.4937
14	1.9605		1.307	1.1203	1.4937	1.4937	1.4937
15							1.4937
16	2.0538			1.2136	1.4937	1.4003	
18	2.2405	2.1472	1.307	1.307	1.4003	1.4937	1.4937
20	1.9605	1.8671	1.1203	1.2136	1.2136	1.307	1.307
22	1.1203	.7468		.7468		.7468	.8402
23	.5601						
24	.4668		.3734	.4668	.3734	.3734	.3734
Max	2.2405	2.1472	1.307	1.307	1.4937	1.4937	1.4937
Min	.3734	.3734	.3734	.2801	.1867	.2801	.2801
Avg	1.1849	1.0969	1.0269	.7780	.8911	.8791	.9420

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

POWER HOUSE S/DN.[727] BU 4727

Substation No/ Name :- 283070 / THANE (W)RECVING STATION

Feeder No / Name : 208 / LAKE VIEW

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.462					.462	
2		.462		.3696	.2772		.2772
3	.3696					.3696	
4		.3696		.924	.2772		.2772
5	.3696					.3696	
6		.462		.462	.462		.462
7	.0166					.5544	
8		.6468		.5544	.7392		
10	1.0164		.7392	.6468	1.0164		.924
11						.924	
12	1.2936	1.1088	1.0164	1.0164	1.2936	1.1765	1.2012
14	1.2012	1.0164	.924	.924	1.1088	1.1088	1.1088
15							1.1088
16	1.1088			1.1088	1.1088	1.1088	
18	1.386	1.2936	1.0164	1.0164	1.2012	1.2936	1.2936
20	1.2936	1.2012	1.1088	1.1088	1.2012	1.2012	1.2803
22	.8316	.7392		.7392		.7392	.8316
23	.5544						
24	.5544		.462	.462	.462	.462	.462
Max	1.386	1.2936	1.1088	1.1088	1.2936	1.2936	1.2936
Min	.0166	.3696	.462	.3696	.2772	.3696	.2772
Avg	.8044	.8111	.8778	.7777	.8316	.8141	.8388

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

POWER HOUSE S/DN.[727] BU 4727

Substation No/ Name :- 283070 / THANE (W)RECIIVING STATION

Feeder No / Name : 210 / CHIRANJIVI SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848					.1848	
2		.1848	.1848	.0924	.1848		.2772
3	.1848					.1848	
4		.1848	.1848	.1848	.1848		.1848
5	.1848					.1848	
6		.1848		.1848	.1848		.1848
7	.1848					.1848	
8		.2772		.1848	.1848		
10	.2772		.2772	.1848	.1867	.1848	.1848
12	.2772	.2772	.2772	.2772	.1848	.1848	.2772
14	.2772	.2772		.1848	.1848	.1848	
15			.2772				.2772
16	.1829			.1848	.1848	.2772	
18	.1848	.2772	.1848	.1848	.1848	.1848	.1848
20	.2772	.2772	.1848	.1848	.2772	.2772	.2772
22	.2772	.2772		.1848		.2772	.2772
24	.1848	.2772	.2772	.1848	.1848	.1848	.2772
Max	.2772	.2772	.2772	.2772	.2772	.2772	.2772
Min	.1829	.1848	.1848	.0924	.1848	.1848	.1848
Avg	.2231	.2495	.231	.1848	.1934	.2079	.2402

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

POWER HOUSE S/DN.[727] BU 4727

Substation No/ Name :- 283070 / THANE (W)RECVING STATION

Feeder No / Name : 212 / VPM

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0838					.0857	
2		.0876			.0914		.0914
3	.0848					.0848	
4		.0876		.0876	.0914		.0914
5	.0848					.0848	
6		.0876			.0914		.0914
7	.0857					.0848	
8		.0876		.0848	.0857		
10	.0934		.0876	.0857	.0848	.0848	.0848
12	.2543	.0914	.0876	.0848	.0924	.0848	.2629
14	.0914	.0914	.0876	.0848	.0848	.0848	.0848
16	.1696			.0914	.0857	.0848	
18	.0876	.0914	.0876	.0914	.0838	.0914	.0876
20	.0876	.0914	.0876	.0914	.0857	.0914	.0876
22	.0876	.0914		.0914		.0914	.0876
24	.1509	.0876	.0914	.0876	.0914	.0838	.0914
Max	.2543	.0914	.0914	.0914	.0924	.0914	.2629
Min	.0838	.0876	.0876	.0848	.0838	.0838	.0848
Avg	.1135	.0895	.0882	.0881	.0880	.0864	.1061

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283072 / 22/11kv vrindavan s/s

Feeder No / Name : 201 / RABODI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9709	.9242	.8589	.8676	.9335		
2						.8865	
3	.8589		.7842		.8402		.8299
5	.8029	.8299	.8402	.8676	.8402	.7733	
6							.9054
7	1.0456		.9335		.9795		
8	1.1203				1.0136		
9	1.1506	1.1694	1.0349	1.094		1.094	1.1694
11		1.0642		1.1016			1.0269
12	1.1317		1.0751	.9522	.9619	1.0374	1.0269
13		.9335					.961
14	1.1317			1.0082			1.0349
15		.8962	.9619			.8676	.8871
16				.8131			
17		.8775					.8589
18				.961		.9619	
19		1.1576		1.1088			1.1949
20	1.1694			1.1458			
21		1.2136				1.3014	1.2567
22				1.1763			1.1458
23		1.0719		1.0829			1.0456
24	1.0456	.9808	.9979		.9896	.9619	.9431
Max	1.1694	1.2136	1.0751	1.1763	1.0136	1.3014	1.2567
Min	.8029	.8299	.7842	.8131	.8402	.7733	.8299
Avg	1.0428	1.0108	.9358	1.0149	.9369	.9855	1.0205

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283072 / 22/11kv vrindavan s/s

Feeder No / Name : 202 / H T CABIN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5228	.5281	.4805	.4715	.4854		
2						.4715	
3	.4481		.4481		.462		.4527
5	.4668	.415	.4108	.4904	.4668	.4338	
6							.5658
7	.6908		.4854		.6348		
8	.7842				.7023		
9	.8299	.7167	.6161	.6413		.7545	.7545
11		.6908		.7095			.6283
12	.6413		.6831	.5975	.6413	.6413	.5729
13		.7207					.5914
14	.5658			.5914			.499
15		.5415	.5093			.4904	.462
16				.4805			
17		.5041					.5121
18				.5853		.5658	
19		.7023		.6653			.5975
20	.6979			.7468			
21		.6908				.7356	.6805
22		.6722		.6838			.6838
23		.6283		.6468			.5914
24	.5788	.547	.5975		.5601	.547	.5281
Max	.8299	.7207	.6831	.7468	.7023	.7545	.7545
Min	.4481	.415	.4108	.4715	.462	.4338	.4527
Avg	.6226	.6131	.5289	.6092	.5647	.5800	.58

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283072 / 22/11kv vrindavan s/s

Feeder No / Name : 203 / VRINDAVAN - 4

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.132	.1494	.132	.1307		
2						.132	
3	.1307		.1307		.1307		.1132
5	.1307	.1509	.1307	.1132	.1307	.132	
6							.1509
7	.2054		.1307		.2054		
8	.1867				.2054		
9	.2452	.2263	.2402	.1886		.2075	.1886
11		.2427		.2054			.2801
12	.1509		.2263	.2218	.1698	.1886	.1867
13		.2241					
14	.1509			.1663			.1867
15		.1663	.1509			.1509	.1494
16				.1478			
17		.1663					.168
18				.168		.1509	
19		.1867					.2054
20	.2075			.2033			
21		.1867				.2452	.2054
22		.1848		.1848			.2033
23		.2614		.1867			.1867
24	.1663	.132	.1494		.168	.132	.1509
Max	.2452	.2614	.2402	.2218	.2054	.2452	.2801
Min	.1307	.132	.1307	.1132	.1307	.132	.1132
Avg	.1724	.1884	.1635	.1744	.1630	.1674	.1827

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283072 / 22/11kv vrindavan s/s

Feeder No / Name : 205 / R W SAWANT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6535	.679	.6348	.679	.6283		
2						.9808	
3	.5788		.5975		.5601		.5658
5	.6413	.6036	.6468	.6036	.5975	.547	
6							.7167
7	.9335		.6908		.8029		
8	.9335				.9522		
9	.9242	.9431	.8501	.9431		.9242	1.0185
11		1.0534		.9709			.9522
12	.8865		.9431	.8962	.8865	.9619	.8589
13		.8871					.8871
14	.8299			.7762			.7577
15		.7655	.7545			.7545	
16				.6838			
17		.8215					.8402
18				.8402		.9054	
19		.924		.8962			.8871
20	.9242			.924			
21		.8686				.9808	.8871
22		.8686		.8316			.8215
23		.7947		.7947			.7602
24	.7468	.6602	.7392		.6838	.6979	.6602
Max	.9335	1.0534	.9431	.9709	.9522	.9808	1.0185
Min	.5788	.6036	.5975	.6036	.5601	.547	.5658
Avg	.8052	.8224	.7321	.8200	.7302	.8441	.8164

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283072 / 22/11kv vrindavan s/s

Feeder No / Name : 206 / INDIAN LEAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1576	1.0185	1.0082	1.0185	1.1203		
2						.9808	
3	.9335		.9335		.9979		.9808
5	.9054	.9054	.9522	.9808	1.0456	.8676	
6							1.0562
7	1.2323		1.0269		1.0164		
8	1.3443				1.2715		
9	1.6032	1.6221	1.3491	1.3957		1.6409	1.6221
11		1.9044		1.848			1.9231
12	2.0559		1.5089	1.8671	2.1502	2.1313	2.0911
13		1.8298					1.7364
14	1.8296			1.7177			1.7556
15		1.7924	1.1694			1.773	1.7372
16				1.5497			
17		1.6804					1.7551
18				1.643		1.8861	
19		2.0351		1.885			1.922
20	1.8861			1.8111			
21		1.7737				1.8107	1.7926
22		1.587		1.6804			1.587
23		1.4003		1.4563			1.4003
24	1.2197	1.1883	1.2323		1.1763	1.1883	1.1317
Max	2.0559	2.0351	1.5089	1.885	2.1502	2.1313	2.0911
Min	.9054	.9054	.9335	.9808	.9979	.8676	.9808
Avg	1.4168	1.5615	1.1476	1.5711	1.2540	1.5348	1.6065

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283072 / 22/11kv vrindavan s/s

Feeder No / Name : 207 / T.M.C.PUMPING

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8589	.8299	.8215	.7922	.7762		
2						.7545	
3	.7842		.7468		.7468		.7922
5	.8402	.7167	.7468	.7545	.7655	.7167	
6							.9054
7	1.1203		.7947		1.0164		
8	1.2323				1.2323		
9	1.358	1.2826	1.1203	1.2449		1.3014	1.358
11		1.307		1.4003			
12	1.1883		1.1694	1.307	1.3203	1.2826	1.2696
13		1.1203					1.1203
14	1.0751			1.0269			1.1203
15		1.0829	.9808			1.0562	1.0456
16				1.0082			
17		.9979					1.0534
18				1.0829		1.1694	
19		1.307		1.307			1.307
20	1.226			1.2136			
21		1.1203				1.3203	1.307
22		1.0349		1.1203			1.1576
23		1.0456		.9709			1.0269
24	.9335	.9054	.9335		.8402	.9054	.9242
Max	1.358	1.307	1.1694	1.4003	1.3203	1.3203	1.358
Min	.7842	.7167	.7468	.7545	.7468	.7167	.7922
Avg	1.0617	1.0625	.9142	1.1024	.9568	1.0633	1.1067

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283073 / SAKET RECEIVING STATION

Feeder No / Name : 202 / SAKET-I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3			.1417		.1494		.2126
6	.1667				.1949	.1417	.1772
7		.2303					
9	.2778	.2658	.2835	.1949	.2835	.2835	.2126
12	.1772	.2303		.2835	.1949	.2481	.1772
15		.1595		.1772	.2126		.1772
18	.1949	.1772	.1772	.1595	.1463		.1772
21	.2126	.1772	.1772	.1949	.2303	.1949	.1949
24		.1595	.1595		.1595	.1595	
Max	.2778	.2658	.2835	.2835	.2835	.2835	.2126
Min	.1667	.1595	.1417	.1595	.1463	.1417	.1772
Avg	.2058	.2000	.1878	.202	.1964	.2055	.1898

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283073 / SAKET RECEIVING STATION

Feeder No / Name : 203 / AKASHGANGA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3			1.0608		1.0608	1.0608	1.0242
6	1.2686		1.0974		1.1706	1.1157	1.1157
7		1.262					
9	1.4877	1.4083	1.3717	1.3352	1.4083	1.4083	1.3717
12	1.4449	1.0974		1.2803	1.2071	1.2254	1.2437
15		1.2254		1.2803	1.2071		1.134
18	1.2437	1.2803	1.2803	1.2986	1.2437		1.1706
21	1.6461	1.6827	1.6461	1.6095	1.7193	1.6278	1.6644
24		1.2986	1.3169		1.2437	1.262	
Max	1.6461	1.6827	1.6461	1.6095	1.7193	1.6278	1.6644
Min	1.2437	1.0974	1.0608	1.2803	1.0608	1.0608	1.0242
Avg	1.4182	1.3221	1.2955	1.3608	1.2826	1.2833	1.2463

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283073 / SAKET RECEIVING STATION

Feeder No / Name : 204 / SAKET II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3			.6653		.6348	.6653	.6283
6	.9121		.7392		.9335	.8871	.8501
7		.9709					
9	1.0982	1.1016	1.1273	1.1088	1.1389	1.1273	1.1458
12	.7655	.8501		.8501	.7762	.7577	.7577
15		.6653		.7392	.6283		.6722
18	.8402	.8131	.9425	.8962	.8871		.8402
21	1.1203	1.1088	1.0719	1.0829	1.2012	1.0534	1.0269
24		.8402	.8316			.7762	
Max	1.1203	1.1088	1.1273	1.1088	1.2012	1.1273	1.1458
Min	.7655	.6653	.6653	.7392	.6283	.6653	.6283
Avg	.9473	.9071	.8963	.9354	.8857	.8778	.8459

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283073 / SAKET RECEIVING STATION

Feeder No / Name : 207 / Mira bhayender pumping NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3			.3696		.3696	.2957	.3142
6	.5932		.4066		.2957	.3696	.4251
7		.2957					
9	.2966	.4251	.3326	.3881	.4251	.2957	.2402
12	.3511	.3142		.2957	.2957	.2772	.2957
15		.4066		.3326	.4066		.3696
18	.3142	.2957	.2218	.3326	.2772		.2772
21	.499	.2957	.5544	.499	.2957	.2587	.2772
24		.3142	.3142		.462	.2218	
Max	.5932	.4251	.5544	.499	.462	.3696	.4251
Min	.2966	.2957	.2218	.2957	.2772	.2218	.2402
Avg	.4108	.3353	.3665	.3696	.3535	.2865	.3142

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283089 / 22 KV VIKAS

Feeder No / Name : 201 / VIKAS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	1.0059		.8413	1.0099	1.0099	1.0242
24		.695	.6584	.6584	.6379	.6485
Max	1.0059	.695	.8413	1.0099	1.0099	1.0242
Min	1.0059	.695	.6584	.6584	.6379	.6485
Avg	1.0059	.695	.7499	.8342	.8239	.8364

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283089 / 22 KV VIKAS

Feeder No / Name : 202 / K-VILLA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	1.4449		1.5729	1.5339	1.4998	1.4415
24		1.2803	1.2803	1.3535	1.3253	1.2567
Max	1.4449	1.2803	1.5729	1.5339	1.4998	1.4415
Min	1.4449	1.2803	1.2803	1.3535	1.3253	1.2567
Avg	1.4449	1.2803	1.4266	1.4437	1.4126	1.3491

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283089 / 22 KV VIKAS

Feeder No / Name : 205 / Ganraj

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	.9694		1.0242	.985	.9412	.924
24		.695	.6584	.7316	.6626	.695
Max	.9694	.695	1.0242	.985	.9412	.924
Min	.9694	.695	.6584	.7316	.6626	.695
Avg	.9694	.695	.8413	.8583	.8019	.8095

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283089 / 22 KV VIKAS

Feeder No / Name : 206 / SHETH DEVELOPERS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	.6584		.6584	.679	.6413	.6722
24		.6584	.6219	.6584	.6036	.6413
Max	.6584	.6584	.6584	.679	.6413	.6722
Min	.6584	.6584	.6219	.6584	.6036	.6413
Avg	.6584	.6584	.6402	.6687	.6225	.6568

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283112 / 22/11 KV Rustomjee

Feeder No / Name : 202 / Rustamji Mira Bhainder NON SHEDDABLE WATER SUPPLY AND
Pumping Feeder KV- 11 / OUTGOING UTILITY

DATE	22-DEC-17	23-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.1109			.1478	.1109
10	.1478		.1109		
11		.1478	.1848	.1848	.0739
12	.2218	.1848	.1478	.1478	.1109
13	.1848	.1109	.1478		.1478
14	.2218		.1848	.1478	
15		.0739	.2218	.0739	
16		.037	.1478	.037	.1848
17		.1109	.1109		.1109
Max	.2218	.1848	.2218	.1848	.1848
Min	.1109	.037	.1109	.037	.0739
Avg	.1774	.1109	.1571	.1232	.1232

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283112 / 22/11 KV Rustomjee

Feeder No / Name : 203 / Shyam Sub Station feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.4755	.3658	.4755	.4024	.4755
10	.4024		.439		
11	.4024	.4024	.3658	.3292	.4024
12	.2926	.415	.3292	.3658	.3658
13	.3292	.3772	.3658	.3292	.2926
14	.2561		.2926	.2926	
15		.2926	.2561	.2561	
16		.2561	.2926	.2195	.2561
17		.2561	.2926		.2561
Max	.4755	.415	.4755	.4024	.4755
Min	.2561	.2561	.2561	.2195	.2561
Avg	.3597	.3379	.3455	.3135	.3414

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283112 / 22/11 KV Rustomjee

Feeder No / Name : 204 / Acura 1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.679	.679	.7167	.679	.6413
10	.9054		.7545		
11	.6413	.7545	.7545	.7167	.679
12	.6413	.7545	.7167	.7167	.7545
13	.6036	.6413	.6413	.6413	.5658
14	.4527		.5658	.6036	
15		.6413	.5658	.5281	
16		.6413	.4527	.6036	.4527
17		.5658	.5281		.5658
Max	.9054	.7545	.7545	.7167	.7545
Min	.4527	.5658	.4527	.5281	.4527
Avg	.6539	.6682	.6329	.6413	.6099

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283112 / 22/11 KV Rustomjee

Feeder No / Name : 207 / 11 kV Manish Builders

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	1.0082	.9335	1.0082	.9709	1.0456
10	1.0082		1.0082		
11	1.0456	1.0456	1.0456	1.0082	1.0829
12	1.0456	1.0456	1.0082	.9335	1.0456
13	.9709	.8589	1.0269	.9335	.8589
14	.8962		1.0082	.8962	
15		.7842	.8215	.8215	
16		.7842	.7468	.8215	.8215
17		.8215	.8215		.8962
Max	1.0456	1.0456	1.0456	1.0082	1.0829
Min	.8962	.7842	.7468	.8215	.8215
Avg	.9958	.8962	.9439	.9122	.9585

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283112 / 22/11 KV Rustomjee

Feeder No / Name : 208 / 11 kV Old Civil

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	1.1203	1.307	1.2696	1.307	1.307
10	1.2696		1.3443		
11	1.3443	1.3443	1.1576	1.3817	1.3817
12	1.1949	1.307	.8215	1.307	1.307
13	1.419	1.3443	1.0456	1.0829	1.2696
14	1.1949		1.1203	1.2696	
15		1.307	1.1576	1.1949	
16		1.2696	1.1203	1.0829	1.0829
17		1.2696	1.3817		1.307
Max	1.419	1.3443	1.3817	1.3817	1.3817
Min	1.1203	1.2696	.8215	1.0829	1.0829
Avg	1.2572	1.3070	1.1576	1.2323	1.2759

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283085 / TARANGAN S/STN

Feeder No / Name : 201 / Solanki Dham

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2384	1.2193	1.1431	1.1812	1.1431	1.3336	1.2193
2	1.1431	1.0479	1.0479	1.0669	1.0669	1.2384	1.1431
3	1.0479	.9907	.9907	.9717	1.0098	1.2384	1.0288
4	1.0479	.9526	.9145	.9526	.9526	1.1431	.9526
5	1.0479	.9717	.8764	.9907	.9526	1.1431	.9526
6	1.1431	1.0669	1.0479	1.0669	1.1431	1.2384	1.105
7	1.2384	1.2193	1.1431	1.1431	1.1812	1.3336	1.1812
8	1.4289	1.2574	1.2765	1.2384	1.3717	1.4289	1.3717
9	1.5242	1.3336	1.467	1.3336	1.3336	1.467	1.4861
10	1.5242	1.4289	1.4289	1.4861	1.4861	1.4289	1.5051
11	1.3336	1.3336	1.5242	1.3717		1.4289	1.1431
12	1.4289	1.5242	1.6194	1.448	1.4289	1.5623	1.0479
13	1.3336	1.4289	1.3336	1.2955	1.3336	1.3527	.9335
14	1.2384	1.3336	1.3336	1.3336	1.3336	1.2955	.9717
15	1.3336	1.3336	1.2384	1.2003	1.3336	1.2384	.8954
16	1.2384	1.2384	1.1431	1.1241	1.1431	1.2574	.8954
17	1.2765	1.2765	1.1812	1.105	1.2384	1.2955	.9717
18	1.3717	1.448	1.3527	1.3336	.8573	1.448	1.0669
19	1.7337	1.7909	1.6766	1.6385	1.7147	1.7528	1.2003
20	1.8099		1.829	1.6956	1.7528	1.8099	1.2003
21	1.7718	1.7337	1.7909	1.7528	1.7147	1.7528	1.1812
22	1.7337	1.6385	1.7147	1.6004	1.7147	1.7147	1.1241
23	1.5623	1.5242	1.5242	1.4861	1.5242	1.5623	.9717
24	1.3336	1.3527	1.2765	1.2955	1.3527	1.3336	1.3146
Max	1.8099	1.7909	1.829	1.7528	1.7528	1.8099	1.5051
Min	1.0479	.9526	.8764	.9526	.8573	1.1431	.8954
Avg	1.3702	1.3237	1.3281	1.2963	1.3080	1.4083	1.1193

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283085 / TARANGAN S/STN

Feeder No / Name : 202 / Navnirman

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.0288	.9526	.9907	1.0288	1.0479	1.0669
2	1.0479	.9335	.8764	.9145	.9145	1.0479	.9907
3	1.0479	.8764	.8383	.8573	.8764	.9526	.9145
4	1.0479	.8764	.8002	.8002	.8573	.9526	.8764
5	1.0479	.9335	.8383	.8764	.8383	.8573	.8764
6	1.1431	1.0669	.9907	.9526	1.086	.8573	1.0669
7	1.2384	1.1431	1.0288	.9907	1.1241	1.0479	1.1431
8	1.4289	1.2574	1.1431	1.1241	1.4098	1.2384	1.2574
9	1.4289	1.3336	1.3908	1.4098	1.5623	1.448	1.4098
10	1.4289	1.4289	1.4289	1.4098	1.448	1.4289	1.3908
11	1.4289	1.5242	1.4289	1.4098		1.3527	
12	1.2384	1.3336	1.3336	1.3336	1.1431	1.2574	
13	1.2384	1.2384	1.1431	1.1812	1.0479	1.1622	
14	1.2384	1.1431	1.1431	1.1241	1.0479	1.105	
15	1.0479	1.0479	1.0479	1.0669	1.0479	1.0479	
16	.9526	.9526	.9526	1.0098	1.0479	.9907	
17	1.086	1.1622	1.1431		1.0479	1.1431	
18	1.2574	1.3146	1.2003	1.2193	1.1431	1.2574	
19	1.5813	1.3908	1.6385	1.5813	1.5242	1.5623	
20	1.5813		1.5623	1.5813	1.5242	1.5432	
21	1.6004	1.5242	1.5242	1.5432	1.6194	1.5623	
22	1.467	1.4289	1.4098	1.448	1.5242	1.4861	
23	1.2955	1.3527	1.3336	1.3336	1.3336	1.3717	
24	1.1431	1.1622	1.105	1.1431	1.105	1.1431	1.1622
Max	1.6004	1.5242	1.6385	1.5813	1.6194	1.5623	1.4098
Min	.9526	.8764	.8002	.8002	.8383	.8573	.8764
Avg	1.2566	1.1936	1.1773	1.1870	1.1870	1.2027	1.1050

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283085 / TARANGAN S/STN

Feeder No / Name : 205 / Tarangan

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6194	1.6194	1.5623	1.6004	1.5623	.7621	1.4861
2	1.6194	1.5051	1.448	1.5242	1.448	.6668	1.4098
3	1.5242	1.448	1.2955	1.4289	1.3717	.6668	1.3336
4	1.5242	1.3908	1.1431	1.3908	1.2955	.6668	1.2955
5	1.5242	1.5432	1.105	1.448	1.2574	.6668	1.3336
6	1.7147	1.7337	1.6956	1.5813	1.7147	.7621	1.7528
7	2.2291	1.848	1.7909	1.6766	1.9433	.8954	1.9243
8	2.2862	2.0957	1.9243	1.8861	2.0195	1.0479	2.1529
9	2.4768	2.3815	2.0957	2.0957	2.2862	1.086	2.1719
10	2.3815	2.2862	2.0957	2.1719	2.572	1.1431	2.3815
11	2.3815	2.191	2.0957	2.2481		1.0288	2.4196
12	2.3815	2.0957	2.191	2.0386	.8573	.8573	2.1338
13	2.0005	2.0005	1.9052	1.8671	.8573	.8764	1.9433
14	2.191	1.9052	1.9052	1.9624	.8573	1.9433	1.8099
15	2.0957	1.9052	1.7147	1.7718	.8573	1.9052	1.829
16	2.0005	1.7147	1.6194	1.6766	.7621	1.8671	1.8861
17	2.0957	1.8099	1.7528	1.7718	.7621	1.9433	1.9243
18	2.3053	2.0957	1.848	1.9814	.8573	1.9052	2.0576
19	2.6482	2.4577	2.191	2.3053	1.0479	2.2481	2.2481
20	2.4768	2.3815	2.1529	2.1529	1.0479	2.3053	2.1338
21	2.6101	2.4958	2.4006	2.3243	1.0479	2.4006	2.21
22	2.2291	2.21	2.1719	2.0957	.9526	2.0957	2.0195
23	2.1719	2.0005	1.9814	1.848	.8573	1.8671	1.829
24	1.7147	1.7337	1.6575	1.6575	1.6385	.7621	1.5813
Max	2.6482	2.4958	2.4006	2.3243	2.572	2.4006	2.4196
Min	1.5242	1.3908	1.105	1.3908	.7621	.6668	1.2955
Avg	2.0918	1.9520	1.8226	1.8544	1.2988	1.3487	1.8861

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283085 / TARANGAN S/STN

Feeder No / Name : 206 / Pumping

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.6478	.6668	.6097	.6478	.7621	.6859
2	.5716	.5906	.5525	.5716	.6097	.6668	.6097
3	.5716	.5716	.5144	.5144	.5906	.6668	.5716
4	.5716	.5525	.4763	.5144	.5716	.5716	.5335
5	.5716	.5525	.5335	.5335	.6097	.5716	.5335
6	.6668	.743	.6478	.6287	.7621	.6668	.8002
7	.9526	.7811	.724	.6859	.8573	.8573	.8954
8	.9526	.8383	.9526	.9717	.9145	1.0479	.9335
9	.9526	.9526	.8192	.8383	.9145	1.105	1.0479
10	.9526	1.2384	.9526	.9526	1.086	1.0479	1.0479
11	1.1431	1.1431	.9526	1.0288		1.1431	1.0669
12	.9526	1.1431	.9526	1.1431	1.2384	1.1241	1.086
13	.9526	.9526	.8573	.9526	.9526	.9526	1.0288
14	.9526	.9526	.8573	.8954	.9526	.9526	.9907
15	.9526	.9526	.6668	.8954	.9526	.9526	.9145
16	.9526	.8573	.6668	.8002	.9526	.9145	.8954
17	1.0288	.8573	.724	.8954	.9526	.9526	.9335
18	1.0479	.9907	.8573	.9145	.9526	.9907	1.0288
19	1.1241	1.086	1.0098	1.105	.9526	1.1431	1.105
20	1.105	1.086	1.0098	.9907	1.0479	1.086	1.0479
21	1.0669	1.0098	1.0288	1.0098	1.0479	1.0288	1.0288
22	.9335	.9526	.9526	.9335	1.0479	.9907	.9526
23	.9145	.7621	.7621	.8383	.9526	.8383	.8573
24	.6668	.7049	.7621	.6668	.6859	.7621	.7811
Max	1.1431	1.2384	1.0288	1.1431	1.2384	1.1431	1.105
Min	.5716	.5525	.4763	.5144	.5716	.5716	.5335
Avg	.8820	.8716	.7875	.8288	.8805	.9082	.8907

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283085 / TARANGAN S/STN

Feeder No / Name : 305 / Mahavir-II

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.1905	.1905				.1905	
10	.1905	.1905	.1905	.1905	.1905	.1905	.2286
11	.1905	.1905	.1905	.1905		.2286	.3048
12	.381	.1905	.1905	.3048	.381	.3048	.3048
13	.381	.1905	.1905	.3048	.381	.3048	.3048
14	.381	.1905	.1905	.3048	.381	.3048	.3048
15	.381	.1905	.1905	.3048	.381	.3048	
16	.381	.1905	.1905	.2286	.381	.3048	.3048
17	.381	.1905	.1905	.2286	.381	.3048	.3048
18	.3048	.1905	.1905	.2286	.1905	.3048	.3048
19	.2286	.1905	.1905	.2286	.1905	.2286	.2286
20	.2286	.1905	.1905	.1905	.1905	.1905	.1905
21	.1905	.1905	.1905	.1905	.1905	.1905	.1905
22	.1905	.1905	.1905	.1905	.1905	.1905	.1905
23	.1905	.1905	.1905		.1905	.1905	.1905
24	.1905		.1905	.1905	.1905	.1905	.1905
Max	.381	.1905	.1905	.3048	.381	.3048	.3048
Min	.1905	.1905	.1905	.1905	.1905	.1905	.1905
Avg	.2738	.1905	.1905	.2340	.2721	.2453	.2531

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283085 / TARANGAN S/STN

Feeder No / Name : 306 / Kalpataru-II

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.4191	.4572	.4954	.4572	.3048	.4191
2	.2286	.3048	.381	.381	.3429	.2667	.3429
3	.2286	.2667	.3048	.2667	.2286	.2286	.3048
4	.2286	.2286	.2667	.2286	.2286	.2286	.2667
5	.2286	.2286	.2286	.2286	.2286	.2286	.2667
6	.2286	.2286	.2286	.2286	.2286	.2286	.2667
7	.2667	.2286	.2286	.2286	.2286	.2286	.2667
8	.2667	.2286	.2667	.2667	.2667	.3429	.3048
9	.7621	.7621	.8383	.8002	.7621	.8002	.4572
10	.9526	.9526	.9526	1.0288	1.1812	.9907	1.0288
11	1.7147	1.7147	1.7147	1.5623		1.5623	1.5242
12	1.7147	1.7147	1.7147	1.7909	1.6385	1.7147	1.6766
13	1.7147	1.9052	1.9052	1.7528	1.7147	1.7909	1.7147
14	1.7147	1.9052	1.9052	1.829	1.7147	1.7528	1.6766
15	1.7147	1.9052	1.9052	2.2481	1.7147	1.7147	1.6385
16	1.7147	1.9052	1.9052	2.0576	1.7147	1.6766	1.6385
17	1.6766	1.7909	1.9052	2.0957	1.6385	1.7147	1.6385
18	1.8671	1.9433	2.0576	2.21	1.6766	1.829	1.6385
19	1.9052	2.0195	2.2862	2.2862	1.829	1.9052	1.7909
20	1.9814	1.9814	2.2862	2.2862	1.9052	1.8671	1.7528
21	1.9052	1.9814	2.2481	2.3243	1.9052	1.829	1.7909
22	1.5623	1.7528	1.7909	1.6766	1.5242	1.6766	1.5242
23	1.0669	1.2193	1.2574	1.2574	1.2574	1.2193	1.0669
24	.5335	.4954	.5335	.6097	.5716	.4954	.5335
Max	1.9814	2.0195	2.2862	2.3243	1.9052	1.9052	1.7909
Min	.2286	.2286	.2286	.2286	.2286	.2286	.2667
Avg	1.1066	1.1701	1.2320	1.2558	1.0851	1.1082	1.0637

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283091 / ETERNITY S/STN

Feeder No / Name : 201 / Kankia

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.3429	.3048	.3429	.3048	.2858	.2858
2	.2477	.3048	.2858	.3048	.2667	.2667	.2667
3	.2477	.2858	.2667	.2667		.2477	.2667
4	.2096	.2667	.2667		.2286	.2286	
5	.2477	.2286	.2477	.2286	.2477	.2286	.2858
6	.3048	.2096	.2286	.2667	.2667	.2858	1.3527
7	.362	.2858	.2286	.2858	.3048	.3048	.3048
8		.3429	.3429	.3239	.381	.3429	.362
9	.5144	.4001	.3429	.3239	.4572	.4954	.5144
10	.5906	.5335	.3429	.4572	.5335	.5716	.5525
11	.6478	.6287	.381	.4572	.6097	.6287	.5716
12	.5906	.5525	.381	.4382	.8573	.6097	.5716
13	.5906	.5716	.362	.4191	.6097		.5716
14	.6097	.5335	.362	.4572	.5906		.5335
15	.5906	.5144	.381	.4382	.5716	.5716	.5335
16	.5716	.4954	.381	.4382	.5525	.4954	.5716
17	.5906	.4763	.381	.4572	.5335	.5335	.5335
18	.5716	.4382	.4191	.4572	.5525	.5335	.5716
19	.5525	.4382	.4382	.4572	.5335	.5144	.4001
20	.4763	.4191	.4191	.4382	.4572	.4191	
21	.4191	.381	.4001	.4001	.4001	.4191	.4191
22	.4191	.381	.381	.362	.362	.3429	.4001
23	.381	.362	.381	.362	.3239	.3048	.3048
24	.2477		.3239	.362	.3429		.2858
Max	.6478	.6287	.4382	.4572	.8573	.6287	1.3527
Min	.2096	.2096	.2286	.2286	.2286	.2286	.2667
Avg	.4481	.4084	.3437	.3802	.4473	.4110	.4754

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283091 / ETERNITY S/STN

Feeder No / Name : 202 / Sandipani

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9717	1.086	.9526	.9145	.8573	.9335	.9907
2	.9335	.9526	.9145	.7049	.7811	.8573	.9717
3	.8954	.9335	.8764	.6478	.724	.8192	.9526
4	.8573	.8573	.8383	.6097	.6668	.8002	.9335
5		.8383	.8002	.6097	.6668	.7621	1.448
6	.9145	.9526	.7621	.6668	.6478	.724	.8954
7	.9717	.9335	.724	.7811	.7049	.6668	.8764
8	.9717	.9717		.9145	.7621	1.0288	1.0479
9	1.0098	.9717	.8764	.9335	1.0288	.9717	.9907
10	.9907	1.086	.9717	.9717	1.0098	1.0098	.9717
11	1.0669	1.0669	.9907	.9907	1.0098	.9907	1.2003
12	.9335	.9335	.9145	.9526	.9717	.9335	1.105
13	.8764	.9717	.9335	.9335	.8764		1.0669
14	.8573	.8764	.8192	.8764	.8954		1.0479
15	.9145	.9145	.8002	.8002	.8954	.8764	1.0479
16	.8192	.8764	.8002	.8573	.8954	.8573	1.0098
17	.8383	.8954	.8192	.9335	.8573	.8954	1.0479
18	.9335	.9335	.8954	1.0669	.9907	.9526	1.4098
19	1.3146	1.2955	1.1622	1.2384	1.2955	1.2765	1.7718
20	1.2574	1.2574	1.2384	1.2765	1.2574	1.2574	1.7909
21	1.2765	1.2955	1.1812	1.1812	1.3336	1.2574	1.8099
22	1.2765	1.1812	1.1622	1.1812	1.2384	1.2574	1.7528
23	1.1241	1.1431	1.086	1.0669	1.105	1.1431	
24	.9717		.9907	.9907	.9335		1.0098
Max	1.3146	1.2955	1.2384	1.2765	1.3336	1.2765	1.8099
Min	.8192	.8383	.724	.6097	.6478	.6668	.8764
Avg	.9990	1.0097	.9352	.9208	.9335	.9653	1.1804

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283091 / ETERNITY S/STN

Feeder No / Name : 205 / Jay Tower

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4289	1.6575	1.5051	1.3527	1.3527	1.4289	1.4861
2	1.3717	1.6194	1.4861	1.2955	1.2765	1.3717	1.467
3	1.3146	1.5813	1.4861	1.1812	1.1431	1.3336	1.448
4	1.2574	1.5242	1.4861	1.1622	1.105	1.2384	1.448
5	1.2193	1.4289	1.467	1.1431	1.1241	1.1812	1.4861
6	1.4861	1.3336	1.467	1.105	1.1622	1.1431	1.5051
7	1.6956	1.467	1.467	1.1812	1.3717	1.4098	1.5242
8	1.7909	1.6956	1.5051	1.3527	1.6766	1.7337	1.7909
9	2.0195	1.9624	1.7528	1.829	1.9433	1.9624	2.0386
10	2.0386	1.9624	1.7147	1.8671	2.0767	2.0195	2.1338
11	1.9814	1.9052	1.6766	1.7528	2.0576	2.0005	2.0576
12	1.8861	1.8861	1.6766	1.7337	1.9814	.9526	2.0386
13	1.7718	1.9243	1.5813	1.7147	1.8671		1.8861
14	2.0386	1.848	1.5432	1.5051	1.6956		1.8671
15	1.848	1.6766	1.5242	1.5813	1.7528	1.9433	1.829
16	1.8099	1.6194	1.3336	1.5432	1.6766	1.848	1.829
17	1.829	1.6575	1.3336	1.467	1.7337	1.7718	1.8099
18	1.9433	1.7528	1.5432	1.8099	1.9052	1.8861	1.8861
19	2.1148	1.9624	1.2765	1.8099	2.1529	2.1529	2.0957
20	2.0767	1.9433	1.829	1.9052	2.0386	2.0957	2.0195
21	2.0957	1.9243	1.9433	1.9814	2.0386	2.0957	2.0576
22	1.6004	1.7718	1.5051	1.5623	1.7718	1.9624	1.9052
23	1.7147	1.6385	1.6004	1.6956	1.6385	1.7337	1.6956
24	1.4861		1.5051	1.467	1.4861		1.5051
Max	2.1148	1.9624	1.9433	1.9814	2.1529	2.1529	2.1338
Min	1.2193	1.3336	1.2765	1.105	1.105	.9526	1.448
Avg	1.7425	1.7279	1.5504	1.5416	1.6679	1.6793	1.7837

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283094 / RAHEJA S/STN

Feeder No / Name : 201 / L.I.C. Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.4191		.4191	.4763	.4191	.381
2	.4001	.381		.4001	.381	.4001	.381
3	.381	.381		.381	.381	.381	.381
4	.381	.381		.381	.381	.362	.381
5	.381	.381		.381	.381	.362	.381
6	.4382	.4001		.4001	.381	.4001	.381
7	.4572	.4382		.4191		.4382	.4763
8	.5716	.5144		.4382	.4763	.4572	.4763
9	.4763	.4954	.4191	.381	.4954	.4572	.4191
10	.5335	.5335	.4572	.4382	.5335	.5144	.5335
11	.6097	.6287	.4191	.4954	.5906	.5716	.5716
12	.6097	.5716	.4572	.5335	.6478	.6097	.5335
13	.5716	.5716	.4763	.4382	.5716	.5525	.5144
14	.5335	.5144	.4382	.4382	.5716	.4763	.4763
15	.4954	.4572	.4382	.4191	.5144	.4954	.4954
16	.4763	.4572	.4001	.4001	.5335	.4763	.4763
17	.5144	.4191	.4572	.4001	.5144	.4763	.4763
18	.5335	.5144	.4763	.4382	.5144	.5716	.5716
19	.5906	.5525	.5335	.4954	.5525	.5716	.4954
20	.4954	.5716	.5525	.5144	.5906	.5716	.5335
21	.5716	.5525	.5144	.5335	.5525	.5716	.5335
22	.5144	.5144	.5144	.4763	.5525	.5716	.5144
23	.5144	.4763	.4954	.4763	.4954	.4763	.4954
24	.4763	.4572	.4382	.4572	.4763	.4382	.4763
Max	.6097	.6287	.5525	.5335	.6478	.6097	.5716
Min	.381	.381	.4001	.381	.381	.362	.381
Avg	.4977	.4826	.4680	.4398	.5028	.4842	.4731

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728] BU 4728

Substation No/ Name :- 283094 / RAHEJA S/STN

Feeder No / Name : 202 / Gangotri

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)
1	.8383	
11		1.4289
12		1.2384
13		1.2193
14		1.086
15		1.105
16		.9907
17		1.086
18		1.1812
19		1.5432
20		1.4861
21		1.4289
22		1.4289
23		1.3908
Max	.8383	1.5432
Min	.8383	.9907
Avg	.8383	1.2780

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283094 / RAHEJA S/STN

Feeder No / Name : 203 / Tip-Top Plaza

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2477		.2286	.2858	.2667	.2858
2	.2667	.2286		.2286	.2858	.2667	.2858
3	.2667	.2286		.2286	.2858	.2477	.2858
4	.2667	.2096		.2286	.2858	.2286	.2858
5	.2667	.2096		.2286	.2858	.2477	.2858
6	.2667	.2286		.2286	.2858	.2667	.2858
7	.2858	.2667		.2286	.2858	.2858	.2858
8	.4001	.3048		.3048	.381	.6097	.4763
9	.5716	.381	.4191	.3429	.8002	.5906	.6859
10	.6287	.381	.5335	.3239	.8764	.7049	.7049
11	.6478	.4382	.6287	.3429	.9526	.7621	.743
12	.724	.4572	.6668	.381	.9907	.7811	.8573
13	.724	.4572	.724	.4382	.9526	.8192	.8573
14	.724	.5144	.724	.4191	.8764	.8383	1.0669
15	.7621	.4954	.7049	.4191	.9526	.8002	1.086
16	.6668	.4572	.362	.381	.8954	.6668	1.0288
17	.6859	.4001	.2858	.3239	.724	.5716	.6668
18	.6097	.381	.3239	.2858	.6478	.5716	.8002
19	.5144	.5144	.381	.381	.724	.4763	.6478
20	.4954	.5144	.4001	.4001	.5716	.4763	.5525
21	.4763	.5144	.381	.381	.5716	.381	.5335
22	.381	.4954	.362	.381	.5144	.381	.4763
23	.3429	.4572	.2858	.381	.4954	.381	.4191
24	.3239	.2667	.3239	.2477	.2858	.2858	.2858
Max	.7621	.5144	.724	.4382	.9907	.8383	1.086
Min	.2667	.2096	.2858	.2286	.2858	.2286	.2858
Avg	.4819	.3771	.4692	.3223	.5922	.4961	.5787

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283094 / RAHEJA S/STN

Feeder No / Name : 204 / Anand Timber

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.4763		.4001	.4763	.4954	.4763
2	.4382	.4382		.381	.4763	.4763	.381
3	.4191	.4191		.362	.381	.4001	.381
4	.381	.381		.362	.381	.381	.381
5	.4191	.4191		.362	.381	.4191	.4763
6	.4572	.4382		.381	.4763	.4572	.4763
7	.5144	.4382		.3429	.4763	.4382	.4763
8	.5335	.5144		.4191	.4763	.4954	.4763
9	.6478	.5716	.4191	.5335	.5716	.5335	.5716
10	.724	.6859	.4572	.5716	.6859	.6859	.724
11	.724	.724	.4572	.6097	.724	.724	.724
12	.6859	.7049	.381	.6668	.7621	.6097	.6859
13	.6859	.5716	.2667	.6097	.5716	.5525	.5525
14	.6478	.5716	.2667	.6097	.6097	.6097	.6668
15	.6478	.6478	.2477	.6097	.6859	.5906	.6668
16	.6478	.6097	.3429	.5716	.6097	.5716	.6287
17	.6478	.6097	.381	.5716	.7049	.6668	.6097
18	.6478	.724	.4001	.6097	.7049	.6668	.6478
19	.6859	.7049	.4954	.6859	.743	.6668	.743
20	.6668	.6859	.4954	.6478	.6668	.6668	.6668
21	.6097	.6097	.5144	.6097	.6478	.5716	.6287
22	.5716	.5906	.4954	.5716	.6287	.5716	.6287
23	.5716	.5716	.4763	.5716	.6097	.5716	.5716
24	.4954	.5525	.5525	.4572	.4763	.5335	.5716
Max	.724	.724	.5525	.6859	.7621	.724	.743
Min	.381	.381	.2477	.3429	.381	.381	.381
Avg	.5811	.5692	.4156	.5216	.5803	.5565	.5755

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283094 / RAHEJA S/STN

Feeder No / Name : 205 / A.C.C.-II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8002	.8192		.8573	.7621	.8002	.9526
2	.7811	.8002		.8002	.5716	.7621	.8573
3	.7811	.7621		.8002	.8573	.724	.7621
4	.7621	.743		.724	.8573	.724	.7621
5	.7811	.8002		.743	.8573	.743	.7621
6	.9907	.8764		.8002	.8573	.8192	.7621
7	1.1241	.9907		1.086	.8573	1.0288	1.1431
8	1.3717	1.1431		.9145	1.2384	1.3336	.9526
9	1.1431	1.3336	1.2193	1.1431	1.3336	1.1622	1.2003
10	1.1431	1.1812	1.1431	1.1812	1.2193	1.1812	1.2003
11	1.3717	1.1622	1.2574	1.1431	1.2384	1.4289	1.3336
12	1.2193	1.3336	1.1431	1.105	1.1431	1.1431	1.2193
13		1.1431	1.0288	.9907	.9907	1.0479	1.2193
14	1.0288	1.0669	.9145	.9907	.9526	.9526	1.0288
15	1.0669	.9907	.9145	.9907	.9526	.9717	1.0479
16	1.0288	1.105	1.0479	.9717	.9907	.9526	.9335
17	1.0098	1.0669	.8764	1.105	1.1622	.9526	1.0098
18	1.2955	1.2384	1.105	1.0479	1.3717	1.1431	1.105
19	1.4289	1.6004	1.3717	1.3336	1.4289	1.4289	1.467
20	1.5623	1.3527	1.5432	1.5242	1.448	1.4289	1.5051
21	1.6194	1.5242	1.3146	1.2955	1.3908	1.3336	1.5813
22	1.3717	1.3336	1.105	1.2384	1.1622	1.2384	1.1431
23	1.0669	1.0288	1.0098	1.1431	1.2193	1.0479	.9907
24	.9145	.8954	.9145	.8573	.8573	.8383	.8573
Max	1.6194	1.6004	1.5432	1.5242	1.448	1.4289	1.5813
Min	.7621	.743	.8764	.724	.5716	.724	.7621
Avg	1.1158	1.0955	1.1193	1.0328	1.0717	1.0495	1.0748

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283094 / RAHEJA S/STN

Feeder No / Name : 206 / Raheja

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9717	.9145		.9145	.9526	.9526	.9526
2	.7621	.7621		.8002	.8573	.743	.6668
3	.724	.6478		.7049	.6668	.724	.6668
4	.6859	.6478		.6478	.6668	.6859	.7621
5	.8954	.724		.6859	.7621	.6668	.8573
6	1.105	.7621		.8954	.8573	.9335	.9526
7	1.3717	1.0669		1.0098	1.1431	1.1812	1.0479
8	1.3527	1.1622		1.1241	1.2384	1.3717	1.3336
9	1.448	1.4098	1.4098	1.2574	1.3717	1.3717	1.3717
10	1.5242	1.5051	1.4861	1.3336	1.5623	1.448	1.5242
11	1.4098	1.448	1.4098	1.4098	1.4861	1.4289	1.4289
12	1.2955	1.3336	1.4289	1.3717	1.4098	1.2955	1.4289
13	1.2193	1.2574	1.3717	1.3717	1.2955	1.2955	1.2574
14	1.1431	1.1431	1.2574	1.3146	1.1431	1.2384	1.1812
15	1.105	1.2574	1.1431	1.2574	1.1431	1.1431	1.2384
16	1.086	1.105	.9526	1.1431	1.105	1.1431	1.1622
17	1.0479	1.2193	1.0479	1.1431	1.0669	1.1431	1.1622
18	1.1812	1.2574	1.2384	1.2384	1.1431	1.2384	1.2193
19	1.5242	1.5623	1.5623	1.4289	1.4098	1.3336	1.5432
20	1.4289	1.5242	1.5242	1.3717	1.4098	1.4289	1.5813
21	1.4289	1.4289	1.4289	1.3336	1.3908	1.4289	1.4289
22	1.2574	1.3717	1.2574	1.2384	1.2574	1.2384	1.2765
23	1.2003	1.2193	1.0669	.8573	1.1241	1.1431	1.1812
24	1.086	1.086	1.105	1.0479		1.0669	1.0479
Max	1.5242	1.5623	1.5623	1.4289	1.5623	1.448	1.5813
Min	.6859	.6478	.9526	.6478	.6668	.6668	.6668
Avg	1.1773	1.1590	1.2932	1.1209	1.1506	1.1518	1.1780

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283094 / RAHEJA S/STN

Feeder No / Name : 207 / Nitin Casting

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8192	.8573		.8764	.8573	.8573	.8573
2	.7811	.8192		.8192	.8573	.8192	.7621
3	.7621	.8002		.7811	.7621	.8002	.7621
4	.7621	.7621		.743	.7621	.7811	.7621
5	.7621	.8002		.7811	.7621	.8002	.7621
6	.9717	.9335		.8573	.9526	.8954	1.0479
7	1.1622	1.0669		1.0288	1.1431		1.1431
8	1.4289	1.3527		1.2574	1.3336	1.448	1.3336
9	1.4861	1.7528	1.2955	1.3717	1.5242	1.5623	1.6194
10	1.6766	2.191	1.4098	1.5242	2.3624	1.6766	2.0005
11	1.7147	1.9052	1.5623	1.6385	2.4387	1.8099	2.3243
12	1.7528	2.3815	1.5242	1.7718	2.4006	1.8099	2.3243
13	1.6385	1.829	1.4098	1.5623	1.6385	1.6194	1.6766
14	1.5242	2.1719	1.3336	1.5623	2.0957	1.6194	2.0957
15	1.5623	1.6766	1.2574	1.5623	2.0576	1.5242	2.0957
16	1.5623	1.6194	1.1431	1.4289	1.6385	1.4289	1.5242
17	1.5623	1.5242	1.1431	1.3908	1.5242	1.5242	1.4861
18	1.6956	1.4289	1.2384	1.467	1.6385	1.5242	1.5242
19	1.6766	1.6194	1.467	1.6385	1.7337	1.8099	1.7909
20	1.6194	1.6385	1.448	1.5432	1.6004	1.5242	1.6194
21	1.6194	1.5623	1.5813	1.5623	1.6575	1.6194	1.5813
22	1.5051	1.5432	1.5432	1.6194	1.4861	1.5242	1.5242
23	1.2955	1.2955	1.2574	1.2384	1.2574	1.2384	1.2574
24	1.0098	1.0479	1.0479	1.105	1.0479	1.0098	1.0479
Max	1.7528	2.3815	1.5813	1.7718	2.4387	1.8099	2.3243
Min	.7621	.7621	1.0479	.743	.7621	.7811	.7621
Avg	1.3479	1.4408	1.3539	1.2971	1.4805	1.3577	1.4551

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283094 / RAHEJA S/STN

Feeder No / Name : 208 / SITAVIHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4577	2.4196		.9335	2.3815	2.2862	2.2862
2	2.3815	2.3243		.9335	2.3815	2.3815	2.2862
3	2.3243	2.2291		.9335	2.2862	2.191	2.191
4	2.2481	2.191		.8764	2.2862		2.191
5	2.2862	2.1338		.8383	2.191	2.1529	2.191
6	2.3434	2.1148		1.1431	2.191	2.3053	2.2862
7	2.2291	1.9624		1.7909	2.191	2.21	2.191
8	2.5339	2.3053		2.4387	2.572	2.4196	2.572
9	2.7625	2.3815	1.6004	2.6673	2.7816	2.7625	2.6673
10	2.9721	2.6482	1.0669	2.7054	3.0483	2.8578	3.0483
11	2.934	2.7054	1.105	2.6673	3.0102	3.0102	2.9912
12	2.8578	2.6292	1.1812	2.7435	3.0864	2.8959	3.0483
13	2.8197	2.6292	1.1431	2.7054	.4954	2.8959	
14	2.7435	2.4006	1.1431	2.572	2.8578	2.7625	2.7054
15	2.6673	2.4768	.9145	2.4006	2.7625	2.7625	2.572
16	2.934	2.4958	.8954	2.6292	2.915	2.7625	3.0483
17	2.8578	2.7625	.8954	2.7054	2.9912	2.7625	2.8959
18	2.8578	2.6673	.9717	2.7816	2.8006	2.8578	2.8959
19	2.9531	2.7054	.9717	2.6673	2.934	2.7625	2.915
20	2.7816	2.6101	1.0098	2.6673	2.6673	2.7625	2.6482
21	2.6673	2.5149	.9907	2.553	2.5911	2.572	2.6101
22	2.4768	2.2672	.9717	2.3815	2.4387	2.3815	2.3434
23	2.4006	2.4006	.8764	2.3815	2.3053	2.191	2.3624
24	2.5149	2.4577	2.4006	.9335	2.4768	2.3434	2.3815
Max	2.9721	2.7625	2.4006	2.7816	3.0864	3.0102	3.0483
Min	2.2291	1.9624	.8764	.8383	.4954	2.1529	2.191
Avg	2.6252	2.4347	1.1336	2.0854	2.5268	2.5778	2.5795

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

KISAN NAGAR[540]

BU 4540

Substation No/ Name :- 283100 / KISAN NAGAR

Feeder No / Name : 201 / Sub-Station No.6

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7282	.7468	.6722	.6535	.5975	.6348	.7095
2	.6722	.6722	.5788	.6161	.5975	.5975	.6348
3	.6161	.6348	.5601	.5788	.5788	.5601	.5788
4	.5975	.5601	.5228	.5788	.5788	.5601	.5601
5	.6161	.6348	.5228	.5788	.5601	.5975	.5601
6	.6348	.6348	.5601	.5601	.6161	.6161	.5975
7	.7655	.6348	.5975	.6161	.8215	.6348	.6722
8	.8962	.8215	.7282	.7655	.8589	.8029	.8215
9	.9335	.8589	.8589	.9149	.8962	1.0082	.8775
10	.9522	.9522	.9709	.9709	1.0269	.9709	.9709
11	.9896	.9522	.9896	.9335	.9335	.8215	1.0269
12	.8775	.9522	.9709	.8775	.8962	.9335	.9709
13	.7655	.8962	.8402	.8029	.9335	.9335	.9335
14	.7468	.8402	.8029	.8962	.8775	.8589	.8589
15	.7468	.7655	.7842	.7468	.7842	.8962	.9335
16	.7468	.7842	.7655	.7468	.7655	.8215	.9335
17	.6908	.7655	.7095	.7468	.7842	.8029	.8775
18	.8029	.8589	.8215	.8215	.9335	.8775	.8775
19	1.0642	1.251	.9709	1.0082	1.0082	.9522	.9709
20	1.0082	1.0829	.9709	1.0082	1.0269	.9896	1.0829
21	.9522	.9896	.9709	.9709	.9896	.9522	.9709
22	.9522	.9896	.9896	.9522	.9522	.9709	.9709
23	.8589	.8775	.9709	.8215	.8589	.8775	.8962
24	.7655	.7468	.7468	.6722	.6722	.7095	.7282
Max	1.0642	1.251	.9896	1.0082	1.0269	1.0082	1.0829
Min	.5975	.5601	.5228	.5601	.5601	.5601	.5601
Avg	.8075	.8293	.7865	.7849	.8145	.8075	.8340

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

KISAN NAGAR[540]

BU 4540

Substation No/ Name :- 283100 / KISAN NAGAR

Feeder No / Name : 203 / Nair Hotel

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4045	1.6263	1.4415	1.3121	1.2567	1.3121	1.4045
2	1.3491	1.5154	1.3121	1.2012	1.2197	1.2936	1.2936
3	1.2567	1.4415	1.1643	1.1273	1.1643	1.2197	1.2012
4	1.2012	1.3676	1.1458	1.1273	1.1643	1.1088	1.1458
5	1.2752	1.2936	1.2012	1.1273	1.1827	1.2197	1.1827
6	1.386	1.3306	1.2197	1.1827	1.2752	1.386	1.2197
7	1.423	1.3676	1.2382	1.2012	1.4784	1.4045	1.3676
8	1.5708	1.5154	1.2936	1.4969	1.5524	1.5154	1.4784
9	1.6632	1.7741	1.5154	1.7556	1.7372	1.922	1.7187
10	1.9404	1.9035	1.7741	1.7741	1.9035	1.9589	1.922
11	1.8665	1.8296	1.7187	1.8111	1.922	1.848	2.0144
12	1.7556	1.7741	1.6263	1.7926	2.0328	1.848	1.8111
13	1.6448	1.7002	1.5708	1.6078	1.6817	1.6263	1.7372
14	1.5893	1.6817	1.46	1.6263	1.7187	1.8111	1.7741
15	1.6263	1.6078	1.3491	1.5154	1.6263	1.6263	1.6632
16	1.5893	1.5893	1.4045	1.5154	1.5524	1.5524	1.7002
17	1.5524	1.6448	1.4045	1.5893	1.7187	1.5708	1.6817
18	1.7741	1.7926	1.5524	1.7741	1.922	1.7556	1.7926
19	2.1253	2.1622	1.848	1.9959	2.0328	2.0144	2.0698
20	1.9959	2.0328	1.922	1.922	1.9404	1.9774	2.0698
21	1.922	1.922	1.848	1.885	1.9774	1.9035	1.9589
22	1.8665	1.848	1.8665	1.7926	1.9035	1.9589	2.0698
23	1.7002	1.922	1.6632	1.6263	1.6632	1.6817	1.7002
24	1.4969	1.6448	1.4969	1.4415	1.4045	1.4784	1.4969
Max	2.1253	2.1622	1.922	1.9959	2.0328	2.0144	2.0698
Min	1.2012	1.2936	1.1458	1.1273	1.1643	1.1088	1.1458
Avg	1.6240	1.6786	1.5015	1.5500	1.6263	1.6247	1.6448

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

KISAN NAGAR[540]

BU 4540

Substation No/ Name :- 283100 / KISAN NAGAR

Feeder No / Name : 204 / Administrative Bldg.

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7421	.724	.6154	.6335	.5792	.6154	.724
2	.7059	.6516	.543	.5973	.5792	.5792	.6516
3	.6516	.6154	.5068	.5611	.5611	.543	.5973
4	.6335	.543	.5068	.5611	.543	.543	.5973
5	.6335	.6154	.543	.5068	.5068	.6154	.5973
6	.6516	.6154	.5611	.543	.5611	.6516	.5973
7	.7421	.6878	.5973	.6516	.6516	.6878	.6335
8	.7783	.7964	.6697	.6697	.724	.7783	.724
9	.9593	.8869	.7421	.8145	.9412	.9231	.9412
10	1.0498	.9412	.7964	.8869	.9593	.9774	1.0498
11	1.086	.9231	.8145	.8326	.9955	.9231	.9412
12	.9593	.9231	.7602	.8145	.9774	.9593	.9955
13	.8688	.8145	.7059	.724	.9231	.8688	.905
14	.8688	.8145	.6516	.7059	.8507	.8688	.905
15	.8326	.7783	.5973	.6516	.8688	.8326	.8326
16	.8145	.724	.6154	.6335	.8507	.8145	.8688
17	.8869	.7783	.4887	.6335	.8869	.7964	.8326
18	.905	.8326	.5068	.7421	.8869	.8326	.905
19	.9412	.7783	.7964	.8145	.9231	.905	.9593
20	.9412	.8869	.8507	.8507	.905	.905	.905
21	.9231	.8326	.8145	.8326	.8869	.8869	.9412
22	.905	.8326	.7964	.8507	.8145	.8688	.905
23	.8688		.7421	.7421	.7783	.8507	.8507
24	.7964	.7602	.6878	.6516	.6697	.7059	.7421
Max	1.086	.9412	.8507	.8869	.9955	.9774	1.0498
Min	.6335	.543	.4887	.5068	.5068	.543	.5973
Avg	.8394	.7720	.6629	.7044	.7843	.7889	.8168

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

KISAN NAGAR[540]

BU 4540

Substation No/ Name :- 283100 / KISAN NAGAR

Feeder No / Name : 205 / Kalibai

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1663	.2587	.2402		.1294	.1294	.2218
2	.1478	.1848	.2218	.1294	.1109	.1109	.1663
3	.1109	.1478	.1848	.0924	.1109	.1109	.0739
4	.1109	.1109	.1109	.0924	.0924	.1478	.0739
5	.1294	.1109	.0924	.1294	.1478	.1848	.1294
6	.1294	.1478	.1109	.1109	.1294	.1848	.0924
7	.2218	.1478	.1294	.1294	.1848	.2218	.1294
8	.2957	.2957	.2402	.2957	.2957	.2772	.2772
9	.3142	.2957	.2957	.2957	.2957	.2957	.2957
10	.3326	.2957	.2218	.2957	.2957	.2957	.2957
11	.2218	.2772	.2033	.3142	.2957	.2402	.2772
12	.2218	.2772	.2218	.2957	.2957	.2402	.2772
13	.2218	.2402	.2772	.2402	.1663	.2033	.1478
14	.2587	.2033	.2957	.2402	.2218	.2033	.1848
15	.2218	.2218	.2402	.2402	.1848	.1663	.2218
16	.2218	.2402	.2218	.2218	.2218	.1848	.2033
17	.1848	.1663	.1294	.2218	.1478	.1848	.2218
18	.2218	.2033	.2587	.2218	.1848	.2033	.2402
19	.2957	.2957	.2033	.2957	.2957	.2772	.2957
20	.3511	.3326	.3511	.3326	.3326	.3142	.3511
21	.2957	.3142	.3142	.3142	.2957	.2957	.3142
22	.2957	.2772	.2957	.2957	.2957	.2957	.2957
23	.2587	.2587	.2587	.2587	.2587	.2772	.2587
24	.1848	.2957	.2957	.2033	.2218	.1848	.2772
Max	.3511	.3326	.3511	.3326	.3326	.3142	.3511
Min	.1109	.1109	.0924	.0924	.0924	.1109	.0739
Avg	.2256	.2333	.2256	.2290	.2172	.2179	.2218

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

KISAN NAGAR[540]

BU 4540

Substation No/ Name :- 283100 / KISAN NAGAR

Feeder No / Name : 206 / Old Modella

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.6371	.6371	.6371	.6203	.6133	.6299
2	.5868	.6036	.6036	.6371	.6036	.5636	.6133
3	.5533	.5365	.503	.6036	.5868	.5914	.6133
4	.57	.503	.5197	.5868	.5868	.4973	.5801
5	.6036	.503	.5365	.5868	.57	.4973	.5304
6	.6371	.5365	.5533	.57	.57	.5304	.5636
7	.6371	.57	.5868	.5868	.57	.5636	.5967
8	.7712	.6706	.6203	.6874	.6036	.6796	.7127
9	.8215	.788	.8215	.7209	.7377	.779	.8288
10	.8718	.8718	.8383	.8886	.8718	.9054	.8951
11	.8383	.9221	.8383	.8886	.9221	.8619	.9116
12	.8215	.8886	.8718	.8886	.9282	.8619	
13	.7377	.788	.7377	.788	.7625	.8122	.7956
14	.7042	.7545	.7042	.8048	.7459	.8122	.7956
15	.7042	.788	.7209	.788	.779	.8122	.7956
16	.7209	.8048	.788	.7209	.7459	.8122	.8122
17	.7377	.8215	.7712	.7545	.7956	.8288	.7956
18	.7712	.8551	.8048	.788	.8122	.8453	.8453
19	.8048	.9054	.8886	.9221	.9116	.9116	.9116
20	.8551	.9221	.8383	.8886	.9282	.8785	.8785
21	.788	.8383	.7377	.8215	.8122	.779	.8122
22	.8383	.8048	.7712	.788	.7459	.7293	.7625
23	.7209	.7377	.6874	.7209	.7127	.6796	.7127
24	.6539	.6706	.6706	.6874	.6539	.6133	.6299
Max	.8718	.9221	.8886	.9221	.9282	.9116	.9116
Min	.5533	.503	.503	.57	.57	.4973	.5304
Avg	.7230	.7384	.7105	.7398	.7324	.7275	.7401

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

KOPRI S/DN.[655]

BU 4655

Substation No/ Name :- 283074 / WALMIKI S/S

Feeder No / Name : 203 / Walmiki

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.5415	.5228	.5228	.4668	.4854	.4668
2	.2241	.4481	.8402	.4481	.4481	.4481	.4481
3		.4481	.4668			.4668	.4668
4		.4668	.5041	.4668	.4668	.4294	
5		.5601	.4668	.4668	.4668	.4481	
6	.1867	.6161	.5975		.6161	.6348	.6348
7	.2614	.6161		.5788	.7095	.6722	.7282
8		.6908		.5975	.7468	.7655	.7282
9	.2427	.7282	.6908	.6908	.7282	.7468	.7468
10	.2241	.7655	.7282	.6908	.6908	.7095	.7655
11	.1867	.7095	.6722	.6161	.6348	.6348	.7468
12	.2241	.5975	.6348	.5975	.5601	.5975	.5788
13	.2054	.5788	.5975	.5788	.5601	.5228	.5975
14	.168	.5788	.5228	.5601	.5041	.5041	
15	.1307	.4668	.3921	.5228	.4108	.4854	
16	.1307	.4668	.4481	.4108	.4108	.4294	
17	.1494	.5228	.4854	.4481	.4481	.4481	.5041
18	.5975	.5975	.5601	.5788	.5788		.5601
19	.6722	.7095	.7842	.7095	.7095	.6908	.7468
20	.7842	.7468	.7468	.6908	.7095		.7282
21	.7095	.7095	.6722	.6348	.6722		.6908
22	.6722	.6535	.6348	.6348	.6348	.6348	.6535
23	.6161	.6161	.6348	.5975	.6161	.5975	.5975
24			.5601	.5975	.5601	.5601	.5228
Max	.7842	.7655	.8402	.7095	.7468	.7655	.7655
Min	.1307	.4481	.3921	.4108	.4108	.4294	.4481
Avg	.3479	.6015	.5983	.5746	.5804	.5672	.6270

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

KOPRI S/DN.[655]

BU 4655

Substation No/ Name :- 283074 / WALMIKI S/S

Feeder No / Name : 204 / Devika

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6348	.6348	.6161	.6535	.5975	.5975	.6161
2	.5975	.6161	.5975	.5601	.5788	.5601	.5788
3		.5601	.5601	.5788		.5788	.5415
4		.5601	.5601	.5601	.5788	.5415	
5		.6161	.5975	.5788	.5975	.5788	
6	.7468	.7655	.6722		.6908	.7842	.8589
7	1.0269	1.0082		.7842	.9522	1.0456	1.0642
8		.9896		.9335	1.1203	1.2136	1.1016
9	1.1949	1.1016	1.0082	1.1016	1.1949	1.1016	1.2136
10	1.1203	1.1576	1.0642	.9896	1.1203	.9335	1.0642
11	.8962	1.1203	1.0456	1.0082	1.0082	.9149	.8962
12	.8215	.8962	.8962	.8589	.8402	.8402	.7655
13	.7468	.8029	.8215	.7468	.5601	.8029	
14	.7468	.7842	.7655	.6908	.5975	.7468	
15	.6535	.6535	.6535	.6535	.5975	.6348	
16	.6161	.6348	.6535	.5601	.5975	.5601	
17	.6348	.6348	.6722	.5975	.6348	.5228	.6908
18	.7655	.8215	.8589	.8029	.7842		.8215
19	1.0456	1.1016	1.1016	1.0456	1.1016	1.0829	1.2136
20	1.1763	1.1576	1.1576	1.1576	1.251		1.251
21	1.1203	1.1016	1.0082	1.0269	1.0829		1.1763
22	.9896	.9335	.9149	.9522	1.0082	1.0082	1.0269
23	.7282	.8215	.8402	.8775	.8402	.8589	.8962
24			.6908	.7095	.7095	.6722	.6722
Max	1.1949	1.1576	1.1576	1.1576	1.251	1.2136	1.251
Min	.5975	.5601	.5601	.5601	.5601	.5228	.5415
Avg	.8559	.8467	.8071	.8012	.8280	.7895	.9138

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

KOPRI S/DN.[655]

BU 4655

Substation No/ Name :- 283074 / WALMIKI S/S

Feeder No / Name : 205 / Puranik

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9896	.9896	.9709	.9522	.9335	.9335	.9522
2	.9149	.9335	.8962	.8589	.8589	.8962	.9149
3		.8775	.8589	.8589		.8402	.8589
4		.8775	.8215	.8402		.8589	
5		1.0829	.8962	.8775	.8775	.9149	
6	1.0829	1.1203	.9709		1.0269	1.0642	1.1763
7	1.3817	1.2136		1.0829	1.2323	1.2883	1.4003
8		1.3256		1.2696	1.4377	1.4377	1.531
9	1.531	1.475	1.251	1.363	1.4937	1.4937	1.643
10	1.6057	1.4377	1.419	1.419	1.531	1.475	1.4937
11	1.4003	1.7364	1.475	1.475	1.6057	1.4563	
12	1.3817	1.419	1.4003	1.4563	1.4003	1.4377	1.363
13	1.2323	1.307		1.3443	1.3443	1.3443	1.2883
14	1.307	1.307	1.2136	1.1949	1.2136	1.2136	
15	1.1389	1.1576	1.0829	1.1203	1.1389	1.1016	
16	1.1016	1.0642	.9896	1.0829	1.1576		
17	1.1576	1.1949	1.0642	.9709	1.1949	1.1203	1.1576
18	1.307	1.307	1.2323	1.2696	1.4003		1.307
19	1.5684	1.6617	1.5684	1.5497	1.5497	1.6804	1.5684
20	1.643	1.6057	1.5684	1.4937	1.5497		1.6057
21	1.4937	1.6057	1.4377	1.419	1.4937		1.475
22	1.419	1.307	1.307	1.3256	1.4003	1.3256	1.3817
23	1.251	1.1949	1.2136	1.2136	1.2883	1.1949	1.251
24	1.1203	1.1389	1.1016	1.1016	1.0829	1.0456	1.0829
Max	1.643	1.7364	1.5684	1.5497	1.6057	1.6804	1.643
Min	.9149	.8775	.8215	.8402	.8589	.8402	.8589
Avg	1.3014	1.2642	1.1781	1.1974	1.2824	1.2061	1.3028

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

KOPRI S/DN.[655]

BU 4655

Substation No/ Name :- 283074 / WALMIKI S/S

Feeder No / Name : 206 / Gautam Tower

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9335	.9149	.9335	.9149	.8775	.8962	.9335
2	.8962	.8775	.8402	.8402	.8589	.8402	.9149
3		.8215	.7842	.8215		.8589	.8215
4		.8589	.8402	.8215	.8215	.8029	
5			.8402	.8029	.8215	.8215	
6	.9522	.9709	.8589		.9335	1.0082	.9709
7	1.1203	1.0642			1.0269	1.0829	1.1016
8		1.0829		1.0642	1.1949	1.1949	1.2136
9	1.2323	1.2323	1.0829	1.1016	1.2696	1.251	1.251
10	1.531	1.307	1.1576	1.2323	1.307	1.307	1.2696
11	1.531	1.475	1.2136	1.307	1.3443	1.4003	1.3443
12	1.3256	1.363	1.1389	1.2323	1.4003		1.4003
13	1.3443	1.3443	1.1949	1.1763	1.3443	1.3256	1.3443
14	1.251	1.3443	1.0829	1.1389	1.307	1.2136	
15	1.1949	1.1763	.9896	1.0829	1.1763	1.1389	
16	1.1763	1.1763	.9709	.9709	1.1203	1.0642	
17	1.1949	1.1576	1.0456	.9335	1.1763	1.0829	1.1763
18	1.307	1.2883	1.1949	1.1763	1.2696		1.2883
19	1.531	1.5684	1.5497	1.5123	1.5497	1.6244	1.6057
20	1.5684	1.6057	1.5123	1.4563	1.587		1.6244
21	1.4003	1.4377	1.3817	1.307	1.4377		1.4937
22	1.3256	1.307	1.2696	1.2323	1.3443	1.251	1.2883
23	1.1763	1.1203	1.1389	1.1389	1.1389	1.1389	1.1389
24	1.0829	1.0642	.9896	1.0269	1.0082	1.0082	1.0642
Max	1.5684	1.6057	1.5497	1.5123	1.587	1.6244	1.6244
Min	.8962	.8215	.7842	.8029	.8215	.8029	.8215
Avg	1.2538	1.1982	1.0914	1.1041	1.1876	1.1156	1.2234

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

KOPRI S/DN.[655]

BU 4655

Substation No/ Name :- 283074 / WALMIKI S/S

Feeder No / Name : 207 / BSUP Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.5601	.5788	.5601	.5601	.5601	.5601
2	.5228	.5228	.5041	.5415	.5601	.5228	.5228
3		.5228	.5415	.5041		.4854	.5228
4		.4668	.4854	.4854	.5228	.5228	
5		.5601	.5415	.4854	.5228	.5228	
6	.5601	.5601	.5975		.5975	.5228	.6908
7	.6348	.6908		.6161	.5601	.5975	.7655
8		.7282		.6908	.6722	.6535	.6722
9	.6908	.7282	.6348	.6161	.7095	.7095	.6908
10	.7282	.6161	.6348	.6348	.6535	.6722	.6908
11	.5601	.5975	.7095	.5601	.5788	.6348	.5601
12	.4108	.5601	1.4003	.5228	.5601	.6722	.5041
13	.4481	.5601	.6161	.4668	.6161	.5788	.5228
14	.5601	.5601	.6161	.5041	.5788	.5228	
15	.5601	.5601	.6161	.5228	.5975	.5415	
16	.5041	.5228	.5601	.5415	.5228	.5415	
17	.5041	.5975	.5415	.5228	.4294	.5228	.3921
18	.4481	.5975	.5601	.4294	.4854		.4294
19	.5788	.6161	.5788	.5975	.5975	.6348	.5975
20	.6722	.6908	.6722	.6722	.6722		.6722
21	.6161	.6348	.5415	.6535	.6535		.6348
22	.6161	.6161	.5228	.5601	.6161	.6161	.5975
23	.6722	.6908	.6535	.6535	.6722	.6535	.6908
24	.6535	.6348	.6161	.6161	.6161	.5975	.5975
Max	.7282	.7282	1.4003	.6908	.7095	.7095	.7655
Min	.3734	.4668	.4854	.4294	.4294	.4854	.3921
Avg	.5657	.5998	.6238	.5634	.5894	.5850	.5955

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283079 / VASANT VIHAR

Feeder No / Name : 201 / SHOPPING FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1393	1.1443	1.1393	1.1393	1.182	1.1946	1.1403
2	1.0692	1.0923	1.0517	1.1043	1.0387	1.0679	1.1222
3	1.0166	1.0517	.9816	1.0402	1.0029	1.0317	1.086
4	1.0166	.9882	.9991	.9991	1.1104	.9955	1.0498
5	1.0341	.9882	.9816	.9991	1.1641	.9955	.9955
6	1.1871	1.1218	1.1218	1.1393	1.2178	1.2308	1.2489
7	1.3998	1.3672	1.2971	1.2094	1.4327	1.5746	1.5746
8	1.7364	1.4198	1.387	1.3496	1.6476	1.6651	1.6832
9	1.8073	1.6827	1.647	1.7002	1.8088	1.7375	1.828
10	1.7909		1.7551	1.8461	1.8804	1.8804	1.8755
11	1.7551	1.9879	1.8625	1.7551		1.8625	1.8983
12	1.6834	1.7551	1.9163	1.7193	1.7372	1.8267	1.7551
13	1.6834	1.6118	1.7909	1.7193	1.6834	1.6655	1.6651
14	1.5223	1.576	1.5939	1.576	1.5939	1.5223	1.4148
15	1.3969	1.3969	1.4327	1.4148	1.3969	1.3611	1.4352
16	1.2548	1.4118	1.3394	1.379	1.3073	1.2715	1.2894
17	1.3735	1.4661	1.3937	1.4661	1.3253	1.3253	1.3969
18	1.5083	1.5384	1.5384	1.5565	1.4864	1.5223	1.4506
19	1.7684	1.828	1.828	1.8823	1.7551	1.7372	1.7551
20	1.825	1.8823	1.7375	1.8642	1.8088	1.7909	1.7909
21	1.9136	1.8823	1.7918	1.8461	1.8625	.7964	1.8267
22	1.6478	1.6289	1.5927	1.6651	1.7193	1.6289	1.6476
23	1.3672	1.3496	1.4022	1.5043	1.3937	1.4118	1.4661
24	1.258	1.2136	1.1744	1.1919	1.2894	1.267	1.2489
Max	1.9136	1.9879	1.9163	1.8823	1.8804	1.8804	1.8983
Min	1.0166	.9882	.9816	.9991	1.0029	.7964	.9955
Avg	1.4648	1.4515	1.4482	1.4611	1.4715	1.4318	1.4852

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283079 / VASANT VIHAR

Feeder No / Name : 202 / M R S FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	28-DEC-17
HR	Load (MW)
1	.1448
Max	.1448
Min	.1448
Avg	.1448

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283079 / VASANT VIHAR

Feeder No / Name : 203 / VOLTAS FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8859	.8322	.8413	.8764	.8596	.8775	.8238
2	.815	.8413	.8413	.8413	.8238	.788	.7964
3	.8063	.8322	.8238	.8413	.788	.7522	.788
4	.7973	.8238	.8238	.8238	.8596	.7522	.788
5	.8859	.8413	.8413	.8413	.9313	.8596	.8596
6	1.1871	.9465	.8939	.8764	1.0745	1.0566	1.0566
7	1.3466	1.1393	.9465	.9991	1.379	1.4506	1.3969
8	1.5238	1.2483	1.1789	1.1043	1.5043	1.4864	1.5581
9	1.6301	1.3847	1.2971	1.3672	1.4506	1.5402	1.576
10	1.5023	1.5203	1.448	1.5565	1.5043	1.5203	1.4685
11	1.4661	1.4661	1.5565	1.5927	1.3969	1.3394	1.3289
12	1.2851	1.3756	1.4118	1.3937	1.2357	1.1403	1.2934
13	1.3394	1.2851	1.448	1.3575	1.3432	1.3032	1.3321
14	1.0498	1.1584	1.086	1.1222	.985	1.0498	1.0454
15	.905	.9412	.9955	.9412	.9134	.9593	.9036
16	.8669	.8954	.8954	.905	.8869	.8688	.8326
17	.9465	.9492	1.0029	1.0029	.9412		.8688
18	1.0517	1.1104	1.1104	1.1104	1.0317	1.0317	1.0498
19	1.4198	1.3969	1.4327	1.4685	1.4118	1.2489	1.3394
20	1.2795	1.2357	1.2536	1.3073	1.3575	1.3213	1.3394
21	1.3146	1.2715	1.1641	1.2715	1.2489	1.267	1.267
22	1.1919	1.182	1.1641	1.182	1.1946	1.1765	1.1946
23	1.0867	1.0341	1.0166	1.1584	1.0745	1.1104	1.0566
24	.9568	.9536	.9015	.9114	.9671	.985	.9492
Max	1.6301	1.5203	1.5565	1.5927	1.5043	1.5402	1.576
Min	.7973	.8238	.8238	.8238	.788	.7522	.788
Avg	1.1475	1.1110	1.0990	1.1188	1.1318	1.1254	1.1214

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283079 / VASANT VIHAR

Feeder No / Name : 204 / TOWER FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0454	1.0166	1.0166	.9465	.9465	.9568	.9391
2	.9568	.9465	.9991	.8764	.9114	.9214	.9214
3	.9568	.9465	.9465	.8589	.8589	.8859	.8859
4	.9922	.964	.9465	.8589	.9465	.8682	.8505
5	1.0517	.9709	.964	.8764	1.0341	.8682	.8505
6	1.1517	1.0517	.9816	.9465	1.1744	1.0985	1.134
7	1.2226	1.1393	1.0517	.9991	1.1744	1.134	1.1694
8	1.3643	1.2445	1.1568	1.0985	1.3146	1.2226	1.2757
9	1.5249	1.4022	1.2795	1.3847	1.5074	1.382	1.5061
10	1.56	1.4373	1.4022	1.4548	1.4373	1.4723	1.4148
11	1.4723	1.5074	1.5424	1.6651	1.56	1.3847	1.4352
12	1.4022	1.4022	1.4373	1.4548	1.262	1.3321	1.4175
13	1.262	1.4373	1.3321	1.4022	1.2094	1.3146	1.2403
14	1.2269	1.2094	1.2445	1.3321	1.1568	1.1393	1.2403
15	1.1218	1.1218	1.0867	1.0867	1.0867	1.0867	1.0631
16	1.1919	1.1517	1.1694	1.0692	1.0517	1.0867	1.0867
17	1.0749	1.1871	1.0985	1.0099	1.0341	.9816	.9465
18	1.2094	1.2934	1.258	1.2403	1.1919	1.1218	1.1744
19	1.4373	1.5415	1.5061	1.4529	1.4373	1.4373	1.3847
20	1.4737	1.5238	1.5061	1.4529	1.4899	1.7528	1.4022
21	1.4373	1.5238	1.5238	1.5061	1.4723	1.4198	1.3847
22	1.4352	1.4175	1.382	1.5061	1.3847	1.3672	1.3672
23	1.2094	1.2445	1.3112	1.1568	1.2048	1.2048	1.2403
24	1.1163	1.0341	1.0692	1.0341	1.0692	.9922	1.0985
Max	1.56	1.5415	1.5424	1.6651	1.56	1.7528	1.5061
Min	.9568	.9465	.9465	.8589	.8589	.8682	.8505
Avg	1.2457	1.2381	1.2172	1.1946	1.2048	1.1846	1.1845

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283079 / VASANT VIHAR

Feeder No / Name : 205 / SIDDHACAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1595	.1402	.1387	.1402	.1463	.1463	.1463
2	.1417	.1387	.1402	.1227	.1463	.1463	.1463
3	.1417	.1402	.1227	.1227	.128	.1463	.1463
4	.1227	.1227	.1227	.1227	.128	.1646	.1463
5	.1402	.1227	.1402	.1227	.1646	.1829	.1646
6	.2126	.1578	.1402	.1402	.1829	.1829	.1646
7	.2303	.1928	.1578	.1753	.2195	.2378	.2378
8	.2481	.2454	.1907	.2103	.2378	.2561	.2743
9	.2835	.298	.2279	.2279	.2865	.2743	.3109
10	.2743	.2926	.2743	.2743	.3109	.3109	.2686
11	.2743	.3109	.3292	.3109	.3109	.3109	.2686
12	.2743	.2926	.2743	.2926	.2743	.2561	.2804
13	.2012	.2378	.2926	.2378	.2743	.2743	.2303
14	.2195	.2195	.2561	.1829	.2195	.2195	.2303
15	.1829	.1829	.1829	.1829	.1646	.1829	.1612
16	.1928		.1646	.1646	.1646	.1646	.1646
17	.1928	.1646	.1829	.1646	.1829	.1646	.2195
18	.2103	.2012	.2378	.2012	.2195	.2195	.2195
19	.2629	.2378	.2561	.2195	.2195	.2378	.2378
20	.2279	.2195	.2378	.2195	.2743	.2561	.2561
21	.2629	.2378	.2561	.2378	.2378	.2195	.2561
22	.2279	.2195	.2012	.2012	.2378	.2195	.2378
23	.2103	.1753	.1753		.2012	.2012	.1829
24	.1595	.1578		.1578	.1646	.1646	.1646
Max	.2835	.3109	.3292	.3109	.3109	.3109	.3109
Min	.1227	.1227	.1227	.1227	.128	.1463	.1463
Avg	.2106	.2047	.2044	.1927	.2124	.2141	.2132

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283097 / 22/11 KV SOHAM S/S

Feeder No / Name : 201 / Soham 1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1715	.1715	.1715	.1715	.1715	.1715
2	.1886	.1543	.1372	.1715	.1715	.1715	.1715
3	.1715	.1543	.1372	.1543	.1715	.1543	.1543
4	.1543	.1372	.1543	.1543	.1543	.1543	.1543
5	.1543	.1715	.1543	.1543	.1543	.1715	.1543
6	.1543	.1715	.1543	.1543	.1543	.1715	.1715
7	.1715	.1543	.1543	.1372	.1543	.1715	.1715
8	.2058	.1543	.1886	.1372	.1543	.1715	.1715
9	.1886	.1715	.1715	.1715	.2229	.2229	.1715
10	.2401	.2572	.2572	.2401	.2229	.2743	.2229
11	.2401	.2229		.2229	.2401	.2229	.2572
12	.2743	.2915		.1886	.2915	.2572	.2401
13	.2743	.3258		.2401	.2058	.2401	.2058
14	.2401	.2572		.2229	.1715	.2058	.1886
15	.1886	.2058		.2229	.1715	.2229	.2058
16	.2229	.2058		.1886	.2058	.2229	.2058
17	.2058			.2229	.2058	.1886	.2058
18	.2743	.2572		.2401	.2572	.2572	.2572
19	.2572	.2572		.3429	.2572	.2401	.2572
20	.2743	.2572		.2743	.3429	.2572	.2743
21	.2743	.2743		.2915	.2401	.2572	.2915
22	.2572	.2229	.2229	.2058	.1886	.2401	.2229
23	.2229	.2058		.1886	.1886	.1886	.1886
24	.2058	.1715	.1715	.2058	.1715	.1886	.1715
Max	.2743	.3258	.2572	.3429	.3429	.2743	.2915
Min	.1543	.1372	.1372	.1372	.1543	.1543	.1543
Avg	.2179	.2110	.1729	.2043	.2029	.2093	.2036

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283097 / 22/11 KV SOHAM S/S

Feeder No / Name : 202 / Unnati

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.2915	.3429	.2401	.2572	.2572	.2915
2	.2743	.3086	.3086	.2401	.2743	.2401	.2915
3	.2743	.3086	.2572	.2401	.2743	.2058	.2743
4	.2572	.3429	.2572	.2229	.2743	.1715	.2743
5	.2572	.3429	.2401	.2229	.2401	.2572	.2915
6	.2572	.3258	.2401	.2401	.2915	.3086	.2915
7	.3086	.3086	.2743	.2743	.3086	.3429	.3086
8	.3944	.3086	.3086	.3086	.3086	.3944	.3086
9	.4115	.3601	.2915	.3601	.3086	.3944	.3772
10	.4287	.3601	.3772	.3772	.3601	.3772	.3429
11	.4287	.3601		.4115	.3772	.3258	.3429
12	.3772	.463		.3086	.4287	.3258	.3086
13	.3429	.3772		.3429	.3772	.3258	.2743
14	.2915	.3772		.2915	.3429	.2572	.2915
15	.3086	.3086		.2572	.2743	.2401	.3086
16	.3258	.3429		.2915	.3258	.2401	.3086
17	.2743			.2915	.2915	.2915	.2743
18	.2915	.3258		.2915	.2915	.2572	.2743
19	.2743	.3601		.3086	.3601	.3086	.3086
20	.3258	.3086		.3086	.3429	.2915	.3258
21	.2915	.3601		.2915	.3601	.3086	.3258
22	.3601	.3772	.3086	.3086	.3772	.3086	.3086
23	.3258	.3258		.2915	.3772	.3258	.3601
24	.3086	.2915	.3429	.2572	.2572	.3086	.1715
Max	.4287	.463	.3772	.4115	.4287	.3944	.3772
Min	.2572	.2915	.2401	.2229	.2401	.1715	.1715
Avg	.3201	.3407	.2958	.2908	.3201	.2944	.3015

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283097 / 22/11 KV SOHAM S/S

Feeder No / Name : 203 / Regency

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8059	.7888	.7716	.7888	.8059	.8059	.8402
2	.7888	.7545	.7202	.7716	.7716	.7888	.8402
3	.7716	.7545	.6859	.7373	.7716	.7716	.8573
4	.7716	.7202	.7373	.7373	.8059	.7716	.9088
5	.7716	.6859	.7373	.7373	.8402	.9431	.9431
6	.7888	.823	.7545	.7373	.8573	.9602	.9774
7	.9774	.9431	.8573	.7545	1.1145	.9945	1.0117
8	1.1317	.9774	.823	.8573	1.0802	1.0288	1.0288
9	1.1488	1.1317	.9774	1.0288	1.046	1.1317	1.1317
10	1.2517	1.1488	1.0974	1.1488	1.1488	1.2346	1.2689
11	1.2003	1.2346		1.2174	1.2174	1.1488	1.1488
12	1.0974	1.1317		1.1317	1.0974	1.166	1.1145
13	1.0288	1.0802		.9945	1.0288	1.0117	1.0288
14	.8573	1.046		.8573		.9088	.9259
15	.9088	.9088		.8402	.8916	.9088	.9259
16	1.0288	.9431		.823	.9602	.9088	.9945
17	.9431			.8573	.9431	1.0631	1.046
18	1.046	1.0117		.9431	1.0974	1.166	1.0631
19	1.0802	1.1488		1.1145	1.1488	1.1831	1.0974
20	1.0631	1.0631		1.0802	1.1145	1.0974	1.0974
21	1.0631	1.0117		.9774	1.046	1.0802	1.0974
22	1.0117	.9945	.9602	.9774	.9602	.8745	1.0802
23	.9431	.9259		.9431	.9431	.9259	.9088
24	.823	.8402	.8059	.823	.823	.823	.823
Max	1.2517	1.2346	1.0974	1.2174	1.2174	1.2346	1.2689
Min	.7716	.6859	.6859	.7373	.7716	.7716	.823
Avg	.9709	.9595	.8273	.9116	.9788	.9874	1.0067

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283097 / 22/11 KV SOHAM S/S

Feeder No / Name : 204 / Omkareshwar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2229	.1715	.1886	.2401	.1715	.2229
2	.1886	.2058	.1543	.1715	.2229	.1543	.2058
3	.1886	.1715	.1372	.1715	.2229	.1543	.2058
4	.1886	.1715	.1372	.1715	.2229	.1543	.2058
5	.1886	.1543	.1715	.1715	.2058	.1715	.1886
6	.1886	.1543	.1715	.1715	.2058	.1715	.1886
7	.1886	.2058	.1715	.1715	.1886	.1886	.1715
8	.1886	.2229	.1715	.1886	.1886	.1886	.1715
9	.2229	.2229	.2572	.1886	.2058	.2572	.1886
10	.2229	.2401	.2572	.2058	.2058	.2572	.2058
11	.2229	.2229		.2058	.2058	.2572	.2401
12	.2229	.2058		.2229	.2572	.2572	.2401
13	.2401	.2572		.2229	.1886	.2401	.2401
14	.2401	.2058		.2229	.1715	.2058	.2401
15	.2572	.2058		.2229	.1886	.2058	.2229
16	.2572	.2401		.2229	.1886	.2058	.2229
17	.2401			.2401	.1715	.2058	1.0631
18	.2401	.1715		.2401	.1886	.2058	.2229
19	.2401	.2572		.2572	.2401	.2229	.2058
20	.2572	.2401		.2572	.2058	.2229	.2058
21	.2229	.2229		.2401	.2572	.2401	.2058
22	.2229	.2058	.2401	.2401	.2058	.2401	.1886
23	.2229	.1886		.2401	.1715	.2401	.1886
24	.2058	.2401	.1715	.2058	.2401	.1886	.2229
Max	.2572	.2572	.2572	.2572	.2572	.2572	1.0631
Min	.1886	.1543	.1372	.1715	.1715	.1543	.1715
Avg	.2193	.2103	.1844	.2101	.2079	.2086	.2444

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283097 / 22/11 KV SOHAM S/S

Feeder No / Name : 205 / HAWARE ESTATE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0631	.9945	.9945	.9945	.9774	.9602	.9774
2	.9945	.9602	.8916	.9259	.9431	.9431	.9431
3	.9945	.8916	.8573	.1715	.9088	.8573	.9259
4	.9945	.9431	.823	.8916	.8745	.8916	.8745
5	.9945	1.0288	.8916	.8916	.8573	.9945	.8573
6	.9945	1.286	.9431	.9602	1.1145	1.166	1.0974
7	1.1488	1.3889	1.0974	1.2689	1.2003	1.3375	1.1488
8	1.4575	1.4232	1.2346	1.2689	1.2517	1.3203	1.286
9	1.3375	1.3375	1.1831	1.2346	1.1831	1.3032	1.2346
10	1.2689	1.4575	1.2517	1.1488	1.2346	1.2003	1.166
11	1.286	1.2003		1.0802	1.0288	1.0802	1.0974
12	1.0802	1.0631		.9945	1.0117	.8745	.9945
13	.9431	.9431		.9431	.8573	.8573	.8745
14	.8745	.8573		.7716	.8059	.8059	.2743
15	.823	.823		.6859	.7716	.7888	.2743
16	.8745	.8573		.7545		.7716	.2572
17	.9088			1.046	.9088	.823	.2572
18	1.0974	1.0288		1.1317	1.0631	.9945	.2743
19	1.3032	1.2174		1.2689	1.0974	1.2174	.2743
20	1.2517	1.1831		1.1488	1.1317	1.0974	.2915
21	1.2517	1.1488		1.0802	1.1145	1.0631	.3086
22	1.2517	1.1145	1.0288	1.046	1.0288	1.0631	.3086
23	1.2346	1.0631		1.0974	1.0802	1.0802	.3086
24	1.0974	1.0974	1.0117	.9945	1.0117	.9945	1.0117
Max	1.4575	1.4575	1.2517	1.2689	1.2517	1.3375	1.286
Min	.823	.823	.823	.1715	.7716	.7716	.2572
Avg	1.1053	1.1004	1.0174	.9917	1.0199	1.0202	.7216

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283097 / 22/11 KV SOHAM S/S

Feeder No / Name : 206 / MERIT MAGNUM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1715	.1543	.1715	.1715	.1715	.1886
2	.1715	.1715	.1543	.1543	.1543	.1715	.1886
3	.1715	.1543	.1372	.1543	.1543	.1543	.1715
4	.1715	.1543	.1372	.1372	.1715	.1543	.1715
5	.1543	.1543	.1715	.1372	.1715	.1543	.1543
6	.1543	.2058	.1715	.1372	.1886	.2058	.1715
7	.1886	.2058	.0857	.1372	.2058	.2572	.2058
8	.2743	.2058	.1543	.1715	.2229	.2401	.2229
9	.2229	.2229	.1886	.2401	.2743	.2572	.2401
10	.2229	.2743	.2915	.2229	.1886	.2401	.2572
11	.2572	.2229		.2572	.2572	.2058	.2229
12	.2058	.2229		.2229	.1543	.2229	.2229
13	.1886	.1886		.2229	.1886	.2058	.2058
14	.1543	.1886		.1715	.1715	.1543	.2058
15	.1543	.1543		.1543	.1372	.1543	.1715
16	.1372	.1372		.1372		.1543	.1543
17	.1715			.1715	.1372	.1543	.1372
18	.2058	.2058		.2058	.1543	.2229	.1715
19	.2401	.2058		.2229	.2058	.2229	.1886
20	.2401	.2229		.2058	.2401	.2229	.2229
21	.2229	.2229		.2229	.2915	.2058	.2229
22	.2058	.2058	.1886	.2229	.2229	.2058	.2229
23	.2058	.2058		.2058	.1886	.2229	.2058
24	.1886	.1886	.1715	.1715	.1715	.1886	.1886
Max	.2743	.2743	.2915	.2572	.2915	.2572	.2572
Min	.1372	.1372	.0857	.1372	.1372	.1543	.1372
Avg	.1958	.1953	.1672	.1858	.1923	.1979	.1965

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283097 / 22/11 KV SOHAM S/S

Feeder No / Name : 207 / ORIAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0171	.0171	.0171	.0171	.0171	.0171
2	.0171	.0171	.0171	.0171	.0171	.0171	.0171
3	.0171	.0171	.0171	.0171	.0171	.0171	.0171
4	.0171	.0171	.0171	.0171	.0171	.0171	.0171
5	.0171	.0171	.0171	.0171	.0171	.0171	.0171
6	.0171	.0171	.0171	.0171	.0171	.0171	.0171
7	.0171	.0171	.0171	.0171	.0171	.0171	.0171
8	.0171	.0171	.0171	.0171	.0171	.0171	.0171
9	.0171	.0171	.0171	.0171	.0171	.0171	.0171
10	.0171	.0171	.0171	.0171	.0171	.0171	.0171
11	.0171	.0171		.0171	.0171	.0171	.0343
12	.0171	.0171		.0171	.0171	.0171	.0343
13	.0171	.0171		.0171	.0171	.0171	.0343
14	.0171	.0171		.0171	.0171	.0171	.0171
15	.0171	.0171		.0171	.0171	.0171	.0171
16	.0171	.0171		.0171		.0171	.0171
17	.0171			.0171	.0171	.0171	.0171
18	.0171	.0171		.0171	.0171	.0171	.0171
19	.0171	.0171		.0171	.0171	.0171	.0343
20	.0171	.0171		.0171	.0171	.0171	.0343
21	.0171	.0171		.0171	.0171	.0171	.0343
22	.0171	.0343	.0343	.0171	.0171	.0171	.0343
23	.0171	.0171		.0171	.0171	.0171	.0343
24	.0343	.0171	.0171	.0343		.0171	.0171
Max	.0343	.0343	.0343	.0343	.0171	.0171	.0343
Min	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Avg	.0178	.0178	.0185	.0178	.0171	.0171	.0228

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283103 / 22/11KV LODHA SUBSTATION

Feeder No / Name : 201 / MANGALMURTI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-DEC-17	24-DEC-17	25-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
8		.5144	.4763
9		.5906	.5716
10		.5906	
11	.5335	.5906	
12	.5335	.5716	
13	.5144	.5525	
14	.5335	.4572	
15		.4191	
16	.4763		
17	.5144		
18	.4954	.4954	
19	.6097		
20	.5716	.5716	
21	.5525	.5335	
22	.5335	.4763	
23		.4954	
24		.4382	.4382
Max	.6097	.5906	.5716
Min	.4763	.4191	.4382
Avg	.5335	.5212	.4954

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283103 / 22/11KV LODHA SUBSTATION

Feeder No / Name : 202 / BHAINDERPADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-DEC-17	24-DEC-17	25-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
8		.1334	.1334
9		.1334	.1334
10		.1334	
11	.1524	.1334	
12	.1334	.1334	
13	.1524	.1334	
14	.1143	.1143	
15		.1334	
16	.1524		
17	.1524		
18	.1334	.1334	
19	.2096		
20	.1715	.1905	
21	.1905	.1905	
22	.1715	.1524	
23		.1334	
24		.1143	.1334
Max	.2096	.1905	.1334
Min	.1143	.1143	.1334
Avg	.1576	.1402	.1334

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283103 / 22/11KV LODHA SUBSTATION

Feeder No / Name : 203 / CIEOLA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-DEC-17	24-DEC-17	25-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
8		.1524	.1334
9		.1334	.1715
10		.2477	
11	.2096	.2858	
12	.2286	.2477	
13	.1905	.1905	
14	.1715	.1905	
15		.1334	
16	.1715		
17	.1905		
18	.1524	.1524	
19	.1524		
20	.1905	.1715	
21	.2096	.1524	
22	.1524	.1524	
23		.1524	
24		.1524	.1524
Max	.2286	.2858	.1715
Min	.1524	.1334	.1334
Avg	.1836	.1796	.1524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283103 / 22/11KV LODHA SUBSTATION

Feeder No / Name : 204 / IGNIS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-DEC-17	24-DEC-17	25-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
8		.2477	.2667
9		.362	.3048
10		.4001	
11	.3048	.4001	
12	.4191	.381	
13	.362	.3429	
14	.381	.3048	
15		.2858	
16	.3048		
17	.2858		
18	.3239	.4191	
19	.4191		
20	.4001	.3429	
21	.4001	.381	
22	.3239	.381	
23		.2858	
24		.2858	.2667
Max	.4191	.4191	.3048
Min	.2858	.2477	.2667
Avg	.3568	.3443	.2794

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283103 / 22/11KV LODHA SUBSTATION

Feeder No / Name : 205 / COSMOS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-DEC-17	24-DEC-17	25-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
8		.2667	.2096
9		.2286	.2667
10		.2667	
11	.0572	.2286	
12	.0572	.2286	
13	.0381	.1905	
14	.0381	.1524	
15		.1524	
16	.0381		
17	.0381		
18	.2096	.1905	
19	.2286		
20	.2096	.2286	
21	.2096	.2286	
22	.2096	.2096	
23		.1715	
24		.1524	.1524
Max	.2286	.2667	.2667
Min	.0381	.1524	.1524
Avg	.1213	.2068	.2096

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283103 / 22/11KV LODHA SUBSTATION

Feeder No / Name : 206 / GIRIKUNJ

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-DEC-17	24-DEC-17	25-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
8		.0381	.0572
9		.0572	.0953
10		.0572	
11	.0572	.0572	
12	.0572	.0381	
13	.0381	.0381	
14	.0572	.0762	
15		.0953	
16	.0572		
17	.0572		
18	.0572	.0762	
19	.0572		
20	.0572	.0762	
21	.0572	.0762	
22	.0572	.0762	
23		.0762	
24		.0572	.0762
Max	.0572	.0953	.0953
Min	.0381	.0381	.0572
Avg	.0555	.0640	.0762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283103 / 22/11KV LODHA SUBSTATION

Feeder No / Name : 208 / BHAINDERPADA-II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-DEC-17	24-DEC-17	25-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
8		.0762	.0572
9		.0381	
11	.0762	.0762	
12	.0762	.0762	
13	.0572	.0762	
14	.0572	.0762	
15		.0572	
16	.0572		
17	.0572		
18	.0572	.0762	
19	.0953		
20	.0762	.0953	
21	.0953	.0762	
22	.0762	.0762	
23		.0762	
24		.0762	.0762
Max	.0953	.0953	.0762
Min	.0572	.0381	.0572
Avg	.0710	.0733	.0667

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283104 / 22/11 KV ANILINE SUBSTATION

Feeder No / Name : 201 / SANGHAVI HILLS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0762	.0754	.0754	.0762	.0762
2	.0762	.0762	.0762	.0754	.0754	.0762	.0572
3	.0762	.0762	.0762	.0754	.0754	.0762	.0572
4	.0762	.0572	.0762	.0754	.0754	.0762	.0572
5	.0762	.0572	.0572	.0754	.0754	.0762	.0572
6	.0762	.0572	.0762	.0754	.0754	.0953	.0762
7	.0953	.0572	.0762	.0754	.0754	.1143	.0953
8	.0953	.0953	.0953	.0943	.1143	.1143	.1143
9	.1334	.1143	.0953	.0943	.1143	.1143	.1334
10	.0953	.1143	.112	.132	.1143	.1143	.0943
11	.0762	.1143	.0934	.0943	.1143	.1143	.0943
12	.0953	.1143	.112	.0754	.0953	.1143	.0943
13	.0762	.0953	.112	.0566	.0953	.0953	.0943
14	.0953	.0953	.0934	.0566	.0762	.0762	.0943
15	.0953	.0762	.0754	.0754	.0762	.0762	.0754
16	.0572	.0762	.0754	.0754	.0762	.0762	.0754
17	.0762	.0762	.0754	.0754	.0762	.0953	.0754
18	.0762	.0953	.1132	.0754	.0953	.0953	.0943
19	.1143	.0762	.1132	.0943	.1143	.0953	.1132
20	.0953	.1143	.1132	.0943	.1143	.0953	.0943
21	.0953	.0953	.0943	.0943	.1143	.0953	.0943
22	.0953	.0762	.0754	.0943	.0953	.0762	.0943
23	.0953		.0754	.0754	.0953	.0762	.0754
24	.0762	.0762	.0762	.0754	.0754	.0953	.0762
Max	.1334	.1143	.1132	.132	.1143	.1143	.1334
Min	.0572	.0572	.0572	.0566	.0754	.0762	.0572
Avg	.0873	.0853	.0881	.0817	.0910	.0921	.0860

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283104 / 22/11 KV ANILINE SUBSTATION

Feeder No / Name : 202 / BORIVADE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0572	.0381	.0377	.0377	.0572	.0572
2	.0381	.0572	.0381	.0377		.0572	.0572
3	.0381	.0572	.0381			.0572	.0572
4	.0381	.0381	.0381			.0572	.0572
5	.0381	.0381	.0572			.0572	.0572
6	.0381	.0572	.0381		.0377	.0572	.0572
7	.0381	.0572	.0381		.0566	.0572	.0572
8	.0381	.0381	.0572	.0377	.0572	.0572	.0572
9	.0381	.0381	.0572	.0377	.0572	.0572	.0572
10	.0381	.0381	.0566	.0377		.0572	.0377
11	.0381	.0381	.0566	.0566	.0572	.0572	.0377
12	.0572	.0572	.0566		.0572	.0572	
13		.0381	.0566		.0572	.0572	
14		.0381	.0377		.0572	.0572	.0377
15			.0377		.0572		
16		.0572	.0377	.0377	.0572		
17	.0381	.0762	.0377	.0377			
18	.0381	.0572	.0566	.0566	.0572	.0572	
19	.0572	.0572	.0566	.0566	.0572	.0572	.0566
20	.0572	.0572	.0566	.0566	.0572	.0572	.0566
21	.0572	.0572	.0566	.0566	.0572	.0572	.056
22	.0572	.0572	.0566	.0566	.0572	.0572	.056
23	.0572		.0566	.0566	.0572	.0572	.0377
24	.0381	.0572	.0381	.0377	.0377	.0572	.0572
Max	.0572	.0762	.0572	.0566	.0572	.0572	.0572
Min	.0381	.0381	.0377	.0377	.0377	.0572	.0377
Avg	.0438	.0511	.0481	.0465	.0539	.0572	.0527

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283104 / 22/11 KV ANILINE SUBSTATION

Feeder No / Name : 203 / RUTU ENCLAVE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.4191	.4191	.415	.3961	.4954	.4954
2	.381	.381	.381	.3584	.3395	.4954	.4572
3	.3429	.3429	.381	.3206	.3395	.4763	.4191
4	.362	.362	.381	.3206	.3395	.4763	.4191
5	.381	.4191	.381	.3584	.3772	.4763	.4191
6	.4191	.4572	.4191	.4527	.4527	.5144	.4191
7	.5716	.5716		.5093	.547	.5716	.5716
8	.8002	.6097	.5525	.6413	.724	.6668	.6859
9	.743	.8002	.743	.679	.7049	.7621	.743
10	.6859	.724	.7545	.7733	.7049	.6859	.7095
11	.743	.6859	.7545	.679	.6478	.6287	.7095
12	.5525	.6668	.7922	.6224	.6287	.6478	.6348
13	.5906	.6668	.6979	.5658	.6287	.6668	.5658
14	.4572	.6668	.5281	.5658	.5335	.4763	.5228
15	.4763	.4954	.4481	.4715	.4572	.4191	.4338
16	.4191	.4763	.4481	.3772	.4572	.4191	.3772
17	.4191	.4382	.4527	.3961	.4382	.4382	.5281
18	.5716	.5144	.5093	.5658	.5716	.5144	.5281
19	.6668	.5716	.5658	.6979	.6668	.6287	.6413
20	.743	.5335	.5601	.547	.6668	.6287	.547
21	.6287		.5658	.5281	.6668	.6287	.5068
22	.5906	.5335	.547	.4904	.5906	.5716	.5853
23	.5144		.5093	.4715	.5335	.5144	.5658
24	.5144	.4572	.4572	.4338	.4338	.5144	.4954
Max	.8002	.8002	.7922	.7733	.724	.7621	.743
Min	.3429	.3429	.381	.3206	.3395	.4191	.3772
Avg	.5438	.5361	.5325	.5100	.5353	.5549	.5409

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283104 / 22/11 KV ANILINE SUBSTATION

Feeder No / Name : 204 / RUBY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0572	.0754	.0754	.0762	.0762
2	.0381	.0762	.0572	.0754	.0754	.0572	.0762
3	.0381	.0762	.0572	.0566	.0754	.0572	.0762
4	.0572	.0762	.0572	.0566	.0566	.0572	.0762
5	.0572	.0572	.0762	.0566	.0566	.0572	.0762
6	.0572	.0572	.0762	.0566	.0566	.0572	.0762
7	.0762	.0762	.0953	.0754	.0754	.0762	.0953
8	.0953	.0762	.0953	.0943	.0572	.0953	.0953
9	.0953	.0953		.1132	.0762	.1143	.0953
10	.0762	.1143	.0943	.132	.0762	.0953	.0754
11	.0572	.1143	.1132	.0943	.0953		.0754
12	.0762	.0572	.0754	.0754	.0762	.0762	.0754
13	.0572	.0572	.0566	.0754	.0762	.0762	.0566
14	.0762	.0572	.0754	.0566	.0572	.0572	.0566
15	.0762	.0572	.0566	.0566	.0572	.0572	.0754
16	.0762	.0572	.0566	.0754	.0572	.0572	.0566
17	.0762	.0762	.056	.0754	.0762	.0572	.0566
18	.0762	.0762	.0754	.0754	.0762	.0762	.0754
19	.0762	.0953	.0943	.0754	.0762	.0762	.0754
20	.0953	.0953	.0943	.0943	.0762	.0762	.0739
21	.0953	.0953	.0754	.0943	.0762	.0762	.0732
22	.0953	.0953	.0754	.0754	.0953	.0762	.0914
23	.0953		.0754	.0754	.0953	.0762	.0739
24	.0762	.0953	.0572	.0754	.0754	.0762	.0762
Max	.0953	.1143	.1132	.132	.0953	.1143	.0953
Min	.0381	.0572	.056	.0566	.0566	.0572	.0566
Avg	.0738	.0787	.0741	.0778	.0728	.0721	.0754

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283104 / 22/11 KV ANILINE SUBSTATION

Feeder No / Name : 205 / SAFIRE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0762	.0572	.0566	.0566	.0572	.0572
2	.0572	.0762	.0572	.0566	.0566	.0572	.0572
3	.0572	.0572	.0572	.0566	.0566	.0572	.0572
4	.0572	.0572	.0572	.0566	.0566	.0572	.0572
5	.0572	.0572	.0572	.0566	.0566	.0572	.0572
6	.0572	.0572	.0572	.0566	.0566	.0572	.0572
7	.0572	.0572	.0572	.0566	.0754	.0762	.0762
8	.0953	.0572		.0566	.0762	.0572	.0762
9	.0953	.0572	.0572	.0566	.0762	.0572	.0572
10	.0572	.0762	.0754	.0566	.0762	.0762	.0566
11	.0762	.0572	.0754	.0754	.0762	.0762	.0566
12	.0762	.0572	.0754	.0566	.0953	.0762	.0943
13	.0572		.0566	.0566	.1143	.0572	.0566
14	.0572	.0762	.0566	.0566	.0762	.0762	.0566
15	.0762	.0762	.0566	.0566	.0572	.0953	.0566
16	.0572	.0762	.0377	.0566	.0572	.0762	.0566
17	.0572	.0762	.0566	.0566	.0572	.0572	.0566
18	.0572	.0762	.0754	.0566	.0762	.0762	.0943
19	.0762	.0762	.0754	.0566	.1143	.0953	.0754
20	.0762	.0953	.0754	.0754	.0953	.0762	.0732
21	.0762	.0762	.0566	.0754	.0762	.0762	.0747
22	.0762	.0762	.0754	.0754	.0953	.0762	.0747
23	.0762		.0566	.0566	.0953	.0762	.0732
24	.0572	.0762	.0572	.0566	.0566	.0762	.0762
Max	.0953	.0953	.0754	.0754	.1143	.0953	.0943
Min	.0572	.0572	.0377	.0566	.0566	.0572	.0566
Avg	.0667	.0693	.0617	.0597	.0744	.0699	.0660

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283104 / 22/11 KV ANILINE SUBSTATION

Feeder No / Name : 206 / SOLITARE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0762	.0953	.0566	.0943	.0762	.0762
2	.0572	.0572	.0953	.0566	.0754	.0762	.0762
3	.0572	.0572	.0953	.0566	.0754	.0762	.0762
4	.0572	.0572	.0953	.0566	.0754	.0762	.0762
5	.0572	.0572	.0572	.0566	.0754	.0762	.0762
6	.0572	.0572	.0572	.0566	.0754	.0762	.0762
7	.0762	.0762	.0953	.0566	.0754	.1143	.0762
8	.1143	.0953	.0572	.0754	.0762	.0953	.0762
9	.0762	.0953	.0572	.0943	.0953	.0953	.0754
10	.0762	.0953	.0566	.0943	.0953	.0953	.0943
11	.0953	.0762	.1132	.0754	.1334	.0953	.0943
12	.0953	.1143	.1132	.0754	.1143	.0953	.1132
13	.0953	.1143	.0943	.0754	.0953	.0953	.0943
14	.1143	.1143	.0754	.0754	.0953	.0953	.0943
15	.1143	.0762	.0943	.0754	.0953	.0953	.0943
16	.0953		.0943	.0754	.0762	.0953	.0943
17	.0762		.0943	.0943	.0762	.0953	.0754
18	.0762	.1143	.132	.1132	.0953	.1143	.0943
19	.1334	.1143	.1132	.1509	.1143	.1334	.1509
20	.1143	.1143	.132	.1509	.1143	.1143	.1097
21	.0953	.0953	.132	.1509	.1143	.1143	.128
22	.1143	.1524	.1132	.132	.1143	.1143	.1267
23	.0953		.0754	.1132	.1143	.1143	.0914
24	.0572	.0953	.0953	.0566	.1132	.0953	.0953
Max	.1334	.1524	.132	.1509	.1334	.1334	.1509
Min	.0572	.0572	.0566	.0566	.0754	.0762	.0754
Avg	.0858	.0907	.0931	.0864	.0950	.0969	.0932

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283105 / 22/22 KV PATLIPADA SWITCHING

Feeder No / Name : 301 / Incommmer to ROMA 1

Feeder KV- 22 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6063	2.4691	2.5377	2.4348	2.4348	2.5034	2.6406
2	2.572	2.4006	2.4691	2.3663	2.4006	2.3663	2.4348
3	2.6063	2.332	2.332	2.2291	2.2634	2.2291	2.2634
4	2.4006	2.332	2.2977	2.1948	2.2291	2.2291	2.1605
5	2.332	2.332	2.4006	2.332	2.2291	2.2634	2.2977
6	2.9835	2.4006	2.4691	2.4006	2.4006	2.8121	2.6406
7	3.4294	2.8121	2.6749	2.572	2.7435	3.0864	3.0178
8	3.7723	2.9835	2.8807	2.8464	3.4637	3.3608	3.4979
9	4.0124	3.7037	3.4294	3.2922	3.8066	3.7723	3.8409
10	3.9781	3.9781	3.8409	3.8409	3.9095	3.7723	4.0466
11	3.9781	3.9781	4.0466	3.9095	3.9095	3.8066	3.738
12	3.6694	3.9438	3.9781	3.7037	3.9095	3.7723	3.7037
13	3.3265	3.7037	3.7037	3.4979	3.5322	3.5322	3.4979
14	3.1893	3.2579	3.3608	3.155	3.2579	3.2579	3.2579
15	3.1893	3.2236	3.2236	3.155	3.155	3.3608	3.3265
16	3.3608	3.155	3.1207	3.0864	3.3608	3.3951	3.3608
17	3.5322	3.3265	3.3608	3.1207	3.2922	3.3951	3.3265
18	3.7723	3.6008	3.5322	3.3608	3.4294	3.4979	3.4294
19	4.0124	3.7723	3.8409	3.5322	3.5665	3.7723	3.7037
20	3.7723	3.7037	3.5665	3.4979	3.6008	3.6351	3.6351
21	3.5665	3.5665	3.3265	3.5665	3.4294	3.5665	3.4637
22	3.3951	3.3951	3.3265	3.2236	3.2922	3.3265	3.2922
23	3.155	2.9492	2.9492	2.9835	2.9835	2.915	2.8807
24	2.7435	2.7435	2.7435	2.6749	2.6749	2.7092	2.6749
Max	4.0124	3.9781	4.0466	3.9095	3.9095	3.8066	4.0466
Min	2.332	2.332	2.2977	2.1948	2.2291	2.2291	2.1605
Avg	3.3065	3.1693	3.1422	3.0407	3.1364	3.1807	3.1722

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283105 / 22/22 KV PATLIPADA SWITCHING

Feeder No / Name : 302 / POKHRAN

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5034	.3772	.3772		.4115	.3772	.4458
2	2.2291	.3772	.3429	.3772	.3772	.3772	.4458
3	1.6804	.3772	.3429	.3772	.3772	.3429	.4115
4	1.0288	.3772	.3772	.3772	.3772	.4115	.4115
5	1.0288	.3772	.3772	.3429	.4115	.4115	.4115
6	3.1893	.3772	.3772	.3772	.4115	.4458	.4115
7	3.2922	.3772	.4115	.4115	.4115	.4115	.4458
8	3.3265	.3772	.3772	.3772	.4458	.4115	.4458
9	3.8752	.4458	.4115	.4115	.4458	.4458	.4458
10	3.9781	.5144	.4458	.4801	.4801	.5144	.4801
11	4.561	.4801	.4801	.4801	.4801	.4458	.5144
12	4.3896	.5487	.5144	.4801	.1029	.4458	.4801
13			.4801	.4801	.1029	.4458	.4458
14		.2743	.4801	.4458	.4801	.4801	.4458
15		.2743	.4801	.4458	.4458	.4458	.4458
16		.3429	.4458	.4801	.4115	.4458	.4801
17		.3429	.4458	.4801	.4115	.4458	.5144
18	.3429	.5144	.4801	.4801	.4458	.4458	.4458
19	.5487	.5144	.4801	.5144	.4801	.5144	.5144
20	.4801	.5487	.4801	.4801	.4801	.5144	.4458
21	.4801	.4801	.4458	.4801	.4801	.4801	.4801
22	.4801	.4458	.4458	.4801	.4458	.4458	.4801
23	.4458	.4458	.4115	.4458	.4458	.4458	.4458
24	2.9835	.4115	.4115	.4115	.4458	.4115	.4458
Max	4.561	.5487	.5144	.5144	.4801	.5144	.5144
Min	.3429	.2743	.3429	.3429	.1029	.3429	.4115
Avg	2.1497	.4175	.4301	.4398	.4087	.4401	.4558

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283105 / 22/22 KV PATLIPADA SWITCHING

Feeder No / Name : 304 / AKBAR CAMP SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.6516	1.8861	.583	.9945	1.8176	.583
2	.6173	.6516	1.7833	.5487	.9602	1.6804	.583
3	.6516	.6173	1.749	.5487	1.0288	1.6461	.583
4	.583	.6173	1.7147	.583	1.0631	1.6118	.6173
5	.583	.6516	1.749	.583	1.2346	1.6804	.6516
6	.7545	.7888	2.0233	.6173	1.3717	1.9547	.6859
7	.9259	.7888	2.0576	.6859	1.6118	2.1948	.8573
8	.8916	.823	2.2291	.7545	1.8861	2.0919	.8573
9	.9259	.823	2.2291	1.0288	1.8861	2.2291	.8573
10	1.0974	.8916	2.1948	1.0631	1.8176	2.2977	.9602
11	1.2346	1.0288	2.332		1.9204	1.0974	.9602
12	1.1317	1.166	2.2634	1.1317	2.2977	1.0288	1.0631
13	.9602	1.0288	1.989	1.1317	2.1605	.8916	1.0631
14	.9945	1.0288	.6859	1.1317		.9602	.9945
15	.823	1.0288	.6859	1.166	2.3663	1.0288	1.0288
16	.7545	2.332	.6859	1.2003	2.4348	.9945	.9602
17	.7888	2.2634	.6173	1.2003	2.2291	.8573	.8573
18	.8916	2.4348	.8573	1.2003	2.1948	1.0631	1.0631
19	1.0631	2.4691	.9259	1.3717	2.3663	1.166	1.1317
20	.8573	2.8807	.9259	1.2346	2.2634	.9259	.9602
21	.8573	2.2291	.7888	1.2003	2.0576	.8916	.8573
22	.8573	2.2634	.8573	1.2003	1.9204	.8573	.823
23	.7545	1.9547	.7545	.9602	1.989	.7202	.7202
24	.6859	.6173	2.0233	.583	1.0288	1.9547	.6173
Max	1.2346	2.8807	2.332	1.3717	2.4348	2.2977	1.1317
Min	.583	.6173	.6173	.5487	.9602	.7202	.583
Avg	.8473	1.3346	1.5004	.9438	1.7862	1.4017	.8473

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283105 / 22/22 KV PATLIPADA SWITCHING

Feeder No / Name : 306 / G.B. South SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6118	1.7833	1.4403	2.1948	1.406	2.4691	2.7778
2	1.4746	1.6804	1.3032	2.0919	1.3717	2.332	2.6406
3	1.406	1.5432	1.2346	2.0233	1.2689	2.2291	2.4348
4	1.3032	1.4403	1.2003	1.8519	1.2346	2.1948	2.2291
5	1.406	1.3717	1.2346	1.989	1.2003	2.1605	2.332
6	1.406	1.3717	1.3032	2.0919	1.2346	2.6063	2.4006
7	1.5775	1.4746	1.4403	2.1948	1.5432	2.8121	2.5034
8	1.7833	1.8519	1.5432	2.4691	1.7147	3.1207	2.7435
9	2.1605	2.0233	1.749	2.7435	2.2291	3.2579	3.6008
10	2.8807	2.6406	2.0919	5.0069	2.8121	4.0809	4.1152
11	3.0521	2.915	2.4691		3.3265	4.2867	4.5953
12	2.2291	3.0178	2.572	3.5322	3.4294	4.4582	4.4582
13	2.0919	2.7435	3.2236	3.3951	3.0864	4.1152	4.1152
14		2.9492	3.2922	2.0919	3.1893	4.1495	4.1838
15	2.6063	2.7435	3.4294	2.2634	3.3608	4.3896	4.2524
16	3.0521	2.8464	3.4979	2.4691	4.4925	4.3553	4.2867
17	3.1893	3.0521	3.1893	2.2291	4.4582	4.321	4.4582
18	3.1893	3.0178	3.6694	2.5034	4.561	4.4239	4.7325
19	3.4294	3.155		2.6063	4.6296	4.904	4.8011
20	2.8807	2.5377	3.7723	2.4006	4.321	4.4239	4.2867
21	2.6063	2.7092	3.6351	2.1948	3.7723	3.8409	3.9781
22	2.1605	2.2291		1.9204	3.2579	3.2922	3.4637
23	2.0233	1.6804	2.7092	1.7147	2.9492	2.7778	2.9492
24	1.7833	1.7833	1.5775	2.332	1.5775	2.7092	2.8807
Max	3.4294	3.155	3.7723	5.0069	4.6296	4.904	4.8011
Min	1.3032	1.3717	1.2003	1.7147	1.2003	2.1605	2.2291
Avg	2.2306	2.2734	2.3444	2.4483	2.7678	3.4880	3.5508

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283107 / 22/11KV HAWARE CITY

SUBSTATION

Feeder No / Name : 201 / RATANTEJ

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4382	.5716	.5335	.4382	.4572	.1715	.1334
2	.4382	.5335	.5335	.4382	.4572	.1715	.1143
3	.4191	.5335	.4954	.4382	.4572	.1524	.1143
4	.4001	.5335	.4763	.4382	.4382	.1524	.0953
5	.4001	.5716	.4763	.4382	.4191	.1334	.0953
6	.4382	.5716	.4954	.4382	.4382	.1524	.0953
7	.5144	.5716	.5335	.4572	.4572	.1715	.1143
8	.4572	.4763	.5335	.4572	.4572	.1715	.8764
9	.4954	.5525	.4954	.4572	.4954	.1905	.1143
10	.5716	.5716	.4954	.5144	.5335	.1524	.1334
11	.5906	.5906	.5525	.5144	.5144	.1905	.1524
12	.5716	.6478		.5144	.5525	.1905	.1715
13	.5144	.5906	.362	.5335	.4763	.1715	.1524
14	.5335	.5144	.4572	.4572	.1715	.1334	.1524
15	.5335	.5525	.5335	.5716	.1524	.1524	.1524
16	.5716	.6668	.5525	.4954	.1524	.1524	.1334
17	.5335	.5716	.5525	.5525	.2096	.1143	.1334
18	.6478	.6478	.5906	.5716	.2096	.1715	.1715
19	.6478	.724	.6668	.6478	.2286	.1905	.1715
20	.6478	.7621	.6478	.6287	.2286	.1524	.1524
21	.6478	.7049	.6478	.5906	.2096	.1524	.1334
22	.5716	.6287	.5335	.5525	.1905	.1524	.1334
23	.5716	.6287	.4954	.5144	.1905	.1334	.1334
24	.4763	.5716	.5335	.4382	.4572	.1905	.1334
Max	.6478	.7621	.6668	.6478	.5525	.1905	.8764
Min	.4001	.4763	.362	.4382	.1524	.1143	.0953
Avg	.5263	.5954	.5302	.5041	.3564	.1612	.1651

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283107 / 22/11KV HAWARE CITY

SUBSTATION

Feeder No / Name : 202 / PLATINUM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.362	.362	.3429	.3429	.362	.3048
2	.3048	.3429	.3429	.3429	.3239	.3429	.2858
3	.3048	.3429	.3239	.3048	.3239	.3239	.2858
4	.2858	.3239	.3239	.3048	.3429	.3239	.2667
5	.3239	.3429		.3239	.362	.3048	.3048
6	.4001	.362	.3429	.3048	.381	.3429	.3429
7	.4572	.381	.362	.3239	.4763	.4382	.4001
8	.4954	.4001	.4191	.362	.5716	.4954	.4572
9	.5144	.5144	.5525	.5335	.6097	.5144	.6097
10	.4572	.4572	.5525	.5335	.5525	.5525	.5716
11	.4382	.4382	.4382	.4572	.4763	.4191	.4954
12	.381	.5335	.381	.5716	.4572	.4191	.4382
13	.381	.381	.381	.4191	.4382	.4191	.4001
14	.3239	.3429	.362	.3429	.381	.3239	.3429
15	.3239	.3429	.2667	.3429	.3239	.3048	.3239
16	.4001	.3429	.3429	.4001	.3239	.3239	
17	.381	.3239	.3239	.4382	.381	.381	
18	.4763	.4954	.4572	.4954	.4572	.5144	.4572
19		.4954	.4572	.4954	.4954	.4954	.4954
20	.4191	.4763	.4572	.4191	.4382	.4572	.5144
21	.4763	.4001	.4572	.4572	.4572	.4382	.4191
22	.362	.4001	.4001	.4572	.4001	.4572	.4191
23	.3429	.381	.381	.4191	.4382	.362	.4191
24	.3429	.362	.3048	.3048	.3239	.4001	.3239
Max	.5144	.5335	.5525	.5716	.6097	.5525	.6097
Min	.2858	.3239	.2667	.3048	.3239	.3048	.2667
Avg	.3877	.3977	.3910	.4041	.4199	.4048	.4036

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283107 / 22/11KV HAWARE CITY

SUBSTATION

Feeder No / Name : 203 / 11 KV HAWARE CITY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3429	.2858	.3048	.2858	.3048	.2667
2	.2858	.3429	.2858	.2858	.2858	.2858	.2477
3	.2667	.3429	.2858	.2858	.2858	.2858	.2477
4	.2667	.3429	.2858	.2858	.3048	.2477	.2286
5	.2858	.3429	.2858	.3048	.3239	.2858	.2477
6	.3429	.3429	.2858	.3429	.3239	.3239	.3048
7	.4954	.362	.2858	.3239	.362	.381	.381
8	.5144	.4382	.3048	.3429	.4382	.4572	.4382
9	.4382	.4191	.4572	.4382	.4382	.4763	.4572
10	.2858	.4191	.4763	.4763	.4954	.4382	.4954
11	.2858	.4191	.4191	.4001	.4382	.381	.381
12	.3429	.362	.381	.4001	.3429	.362	.362
13	.362	.362	.381	.362	.3048	.3048	.3429
14	.2667	.3048	.362	.2667	.3048	.2858	.2858
15	.2096	.2477	.3048	.2477	.2477	.2667	.2477
16	.2858	.2858	.2858	.2477	.2477	.2477	.2477
17	.2858	.2477	.2858	.2667	.2477	.2858	.2477
18	.2667	.3048	.362	.3429	.3048	.3048	.3239
19	.3239	.3239	.3429	.3239	.4001	.3429	.362
20	.4001	.3429	.362	.3429	.3429	.3429	.362
21	.4001	.4001	.362	.381	.362	.4191	.381
22	.3429	.3429	.3429	.381	.4001	.4191	.4001
23	.3429	.3429	.3239	.3239	.3429	.3239	.3239
24	.3239	.3429	.2858	.2858	.2858	.3239	.3048
Max	.5144	.4382	.4763	.4763	.4954	.4763	.4954
Min	.2096	.2477	.2858	.2477	.2477	.2477	.2286
Avg	.3302	.3469	.3350	.3318	.3382	.3374	.3286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283107 / 22/11KV HAWARE CITY

SUBSTATION

Feeder No / Name : 204 / UNNATI GREEN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.2286	.2477	.2096	.2096	.2286	.2096
2	.2096	.2286	.2477	.1905	.1905	.2096	.2096
3	.1905	.2286	.2477	.1905	.1905	.2096	.1905
4	.1905	.2477	.2286	.1905	.2096	.1905	.1905
5	.2477	.2286	.2286	.2096	.2096	.2477	.1905
6	.3239	.2477	.2477	.2286	.2286	.3048	.2477
7	.2667	.2477	.2477	.2286	.2477	.3429	
8	.3429	.2858	.2667	.2477	.2477	.3048	.3239
9	.3239	.2667	.2477	.3429	.3429	.3239	.3239
10	.362	.3429	.381	.4191	.381	.362	.3239
11	.362	.3429	.4001	.362	.3429	.4001	.3239
12	.362	.381	.3239	.362	.2858	.3048	.362
13	.3048	.3048	.3239	.3239	.2667	.2477	.3048
14	.2286	.2667	.362	.2477	.2858	.2667	.2667
15	.3048	.2477	.3239	.3048	.2667	.2667	.2667
16	.3239	.2667	.2667	.2858	.2667	.2667	.2667
17	.2286	.2477	.3239	.2667	.2477	.2667	.2858
18	.3429	.2858	.3429	.3239	.2858	.3429	.3048
19	.3239	.3429	.3429	.3239	.3429	.3239	.3429
20		.3048	.2667	.3048	.2858	.2858	.3048
21	.3429	.2667	.2667	.2667	.2858	.2858	.2667
22	.2286	.2477	.2286	.2667	.2477	.2858	.2477
23	.2286	.2096	.2286	.2286	.2477	.2286	.2286
24	.2286	.2477	.2286	.1905	.1905	.2286	.2286
Max	.362	.381	.4001	.4191	.381	.4001	.362
Min	.1905	.2096	.2286	.1905	.1905	.1905	.1905
Avg	.2816	.2715	.2842	.2715	.2628	.2802	.2700

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283037 / 22/11 KV DOSTI VIHAR

Feeder No / Name : 201 / DF-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4095	.5847	.5093	.6036	
2	.3909	.6224	.4904	.5658	
3	.4467	.6036	.4715	.5658	
4	.4281	.6602	.4904	.6224	
5	.5584	.7545	.5093	.6224	
6	.577	.7922	.547	.679	
7	.5956	.7167	.5847	.7545	
8	.819	.6224	.6602	.7545	
9	.819	.8676	.9054	.811	
10	.8004	.6602	.7545	.7545	
11	.7446	.7545	.7545	.6979	
12	.6329	.6224	.679	.6036	
13	.6515	.5658	.6413	.5658	
14	.5398	.5658	.5847	.5658	
15	.5026	.5093	.547	.5281	
16	.5398	.4715	.547	.5093	
17	.6329	.5658	.5281	.5093	
18	.6701	.6224	.6036	.6036	
19	.7632	.7922	.679	.6602	
20	.819	.6979	.7356	.7922	
21	.7446	.7356	.7356	.7922	
22	.8004	.7167	.7167	.7545	
23		.6413	.7167	.6413	
24	.5303	.5492	.5093	.5281	.5093
Max	.819	.8676	.9054	.811	.5093
Min	.3909	.4715	.4715	.5093	.5093
Avg	.6268	.6540	.6209	.6452	.5093

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283037 / 22/11 KV DOSTI VIHAR

Feeder No / Name : 202 / DF-2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2606	.2012	.2012	.2561	
2	.2978	.1463	.1698	.2012	
3	.2792	.2743	.1886	.1829	
4	.3164	.2561	.2195	.1829	
5	.335	.2378	.1829	.1829	
6	.242	.2012	.2378	.2378	
7	.2234	.1829	.2195	.3109	
8	.3723	.2378	.2378	.3658	
9	.3723	.3658	.3658	.439	
10	.3909	.4024	.3292	.439	
11	.3723	.3841	.3292	.4024	
12	.3164	.3475	.3292	.3475	
13	.2792	.3109	.3292	.3292	
14	.2606	.2743	.3292	.2926	
15	.242	.2378	.2743	.2926	
16	.2606	.2195	.2743	.2561	
17	.2792	.2378	.2378	.2561	
18	.2978	.3109	.2743	.2926	
19	.335	.2743	.3395	.2926	
20	.3164	.3109	.3395	.2926	
21	.2978	.2926	.3206	.3109	
22	.3537	.3292	.2926	.3109	
23		.2743	.2926	.3109	
24	.2273	.2462	.2195	.2195	.2195
Max	.3909	.4024	.3658	.439	.2195
Min	.2234	.1463	.1698	.1829	.2195
Avg	.3012	.2732	.2722	.2919	.2195

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283037 / 22/11 KV DOSTI VIHAR

Feeder No / Name : 203 / DF-3

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2234	.3206	.2075	.1886	
2	.2048	.3018	.1886	.1509	
3	.2606	.2641	.1698	.1509	
4	.2234	.2452	.1509	.1509	
5	.242	.2075	.1886	.1509	
6	.2792	.2263	.2263	.1886	
7	.2606	.2075	.1886	.1886	
8	.2792	.2452	.2075	.2452	
9	.2606	.2829	.3206	.3206	
10	.2792	.3018	.3206	.3206	
11	.2048	.2075	.3206	.2829	
12	.1861	.2263	.2263	.2263	
13	.2234	.2075	.1886	.1886	
14	.2048	.1886	.1886	.1886	
15	.1675	.1509	.1509	.1509	
16	.1675	.1509	.1509	.1509	
17	.1861	.1509	.1509	.1509	
18	.2048	.1698	.1886	.1886	
19	.2978	.2263	.1886	.1886	
20	.2792	.2452	.2075	.3018	
21	.2978	.2263	.2263		
22	.2792	.2263	.1886	.3018	
23		.2075	.1886	.2452	
24	.1704	.1894	.1698	.1698	.1698
Max	.2978	.3206	.3206	.3206	.1698
Min	.1675	.1509	.1509	.1509	.1698
Avg	.2340	.2240	.2043	.2083	.1698

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283037 / 22/11 KV DOSTI VIHAR

Feeder No / Name : 205 / DF-5

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4281	.3734	.2427	.3734	
2	.484	.4108	.2241	.3361	
3	.4095	.4668	.2054	.3361	
4	.4281	.5228	.1867	.2987	
5	.4467	.4108	.2241	.2987	
6	.3909	.3921	.2427	.3547	
7	.3723	.3734	.2614	.3734	
8	.5026	.4481	.4854	.3734	
9	.3909	.3734	.4294	.4108	
10	.4095	.4108	.4294	.4108	
11	.3723	.4481	.4294	.3734	
12	.2978	.3547	.3734	.3174	
13	.3164	.3734	.3734	.3174	
14	.2792	.3734	.3361	.3174	
15	.2606	.3547	.2801	.3174	
16	.242	.2801	.2801	.3174	
17	.335	.2427	.2427	.3174	
18	.3537	.4668	.3174	.3174	
19	.5026	.4668	.3734	.3921	
20	.484	.8029	.3734	.4668	
21	.4095	.3921	.3734	.4108	
22	.3909	.3921	.3734	.4108	
23		.3921	.3734	.3921	
24	.3598	.3788	.3361	.3547	.3361
Max	.5026	.8029	.4854	.4668	.3361
Min	.242	.2427	.1867	.2987	.3361
Avg	.3855	.4125	.3236	.3579	.3361

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283037 / 22/11 KV DOSTI VIHAR

Feeder No / Name : 206 / DF-6

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6329	.815	.5138	.5316	
2	.6515	.8328	.4961	.4784	
3	.6143	.7442	.4607	.4784	
4	.7073	.7973	.443	.4607	
5	.577	.6201	.4252	.4961	
6	.6515	.7087	.5138	.5316	
7	.7073	.5493	.5493	.567	
8	.7818	.567	.5847	.6201	
9	.8562	.7265	.6733	.7619	
10	.9307	.7087	.7442	.7796	
11	.7818	.7619	.7796	.7796	
12	.8004	.7087	.7796	.7796	
13	.819	.6733	.7087	.7442	
14	.6701		.6201	.7087	
15	.6515	.5493	.6201	.6556	
16	.6887	.5493	.567	.6024	
17	.6701	.567	.5316	.5493	
18	.7073	.6024	.6201	.6556	
19	.819	.6733	.6733	.6556	
20	.8562	.811	.7087	.7619	
21	.819	.6733	.7265		
22	.7446	.6379	.7087	.7087	
23		.567	.5847	.6024	
24	.6439	.5681	.5316	.5316	.5138
Max	.9307	.8328	.7796	.7796	.5138
Min	.577	.5493	.4252	.4607	.5138
Avg	.7297	.6701	.6069	.6279	.5138

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283037 / 22/11 KV DOSTI VIHAR

Feeder No / Name : 207 / DF-7

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2048	.1867	.1494	.1867	
2	.1861	.168	.1307	.1494	
3	.242	.1494	.168	.1494	
4	.2234	.2241	.1867	.1494	
5	.2606	.2614	.2054	.1494	
6	.2792	.2801	.168	.1867	
7	.1861	.2054	.1867	.1867	
8	.242	.2241	.2241	.2241	
9	.2234	.2054	.2427	.2614	
10	.2606	.1867	.2801	.2614	
11	.3537	.3174	.3174	.2614	
12	.242	.2801	.3174	.2427	
13	.2048	.2054	.2801	.2241	
14	.1861	.2241	.2241	.1867	
15	.1489	.168	.1867	.1494	
16	.1675	.1867	.1867	.1494	
17	.1489	.168	.1867	.168	
18	.1675	.2241	.1867	.1867	
19	.242	.2427	.1867	.1867	
20	.1861	.2427	.1867	.2241	
21	.2606	.2054	.2241	.2054	
22	.2234	.2241	.1867	.2054	
23		.168	.1867	.2054	
24	.1704	.1704	.1494	.1494	.1494
Max	.3537	.3174	.3174	.2614	.1494
Min	.1489	.1494	.1307	.1494	.1494
Avg	.2178	.2133	.2062	.1937	.1494

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283080 / 22/11KV MHADA S/STN

Feeder No / Name : 203 / FEEDER NO. 3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.4066	.4066	.4066	.4251	.4805	.439
2	.2743	.3326	.3326	.3326	.3511	.3881	.3841
3	.2195	.2957	.3326	.3511	.3326	.3142	.3475
4	.2561	.3696	.3511	.4066	.3326	.3142	.2743
5	.4024	.4805	.5175	.462	.5914	.3881	.6401
6	.5487	.6099	.6468	.5359	.7023	.4805	.6219
7	.695	.6653	.6468	.6468	.7207	.6838	.6584
8	.6767	.7207	.7207	.7023	.7392	.6653	.7499
9	.6401	.8131	.7762	.7207	.7392	.7577	.7499
10	.6838	.8316	.8871	.7577	.7947	.8413	.7947
11	.6468	.7392	.8316	.7762	.7577	.7499	.7577
12	.6653	.7207	.7499	.7577	.7762	.6584	.7392
13	.7577	.6838	.7762	.7023		.6219	.6283
14	.5729	.5544	.5175	.5544	.6283	.5853	.6099
15	.3142	.462	.3142	.5359	.3511	.5487	.5175
16	.5175	.4435	.4251	.499	.4251	.4572	.4066
17	.5175	.3881	.5729	.5175	.6283	.4024	.3881
18	.6653	.4805	.6099	.6838	.6099	.6584	.5914
19	.7207	.7207	.7392	.7577	.7762	.7682	.7947
20	.7577	.7392	.7207	.7577	.7577	.7682	.8131
21	.6653	.7577	.7023	.7023	.7577	.7316	.7577
22	.7207	.7392	.6838	.6653	.7392	.6584	.6838
23	.6468	.6653	.6099	.6468	.6283	.6584	
24	.5304	.462	.4805	.5544	.5729	.5175	.4938
Max	.7577	.8316	.8871	.7762	.7947	.8413	.8131
Min	.2195	.2957	.3142	.3326	.3326	.3142	.2743
Avg	.5609	.5867	.5980	.6014	.6147	.5874	.6018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283080 / 22/11KV MHADA S/STN

Feeder No / Name : 204 / FEEDER NO. 4

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6827	1.6644	1.6461	1.6461	1.6461	1.6461	1.6461
2	1.5729	1.4998	1.5364	1.5729	1.5364	1.5912	1.5729
3	1.4998	1.4449	1.4815	1.4815	1.4998	1.5181	1.5181
4	1.5546	1.4998	1.4815	1.4998	1.4815	1.4632	1.4815
5	1.5912		1.4998	1.5729	1.5546	1.5181	1.701
6	1.8839	1.701	1.6278	1.5729	1.7558	1.5912	1.6461
7	1.9387	2.0119	1.701	1.7375	1.8656	1.701	1.9022
8	2.2314	2.1948	2.0302	2.0302	2.3411	2.2497	2.3045
9	2.4326	2.3228	2.268	2.4691	2.4508	2.4143	2.3594
10	2.1948	2.2314	2.3045	2.4143	.7865	2.2862	2.3777
11	2.1216	2.1948	2.5057	2.1765	2.2131	2.1399	2.2314
12	2.0119	2.0668	2.0485	2.0485	2.0302	2.0485	2.0485
13	1.8839	1.9936	1.9387	1.957		1.9022	1.829
14	1.7741	1.8656	1.8473	1.957	1.9387	1.829	1.8473
15	1.701	1.8656	1.701	1.701	1.7193	1.8107	1.829
16	1.6827	1.825	1.6827	1.6278	1.6095	1.829	1.6644
17	1.7193	1.9022	1.7741	1.8107	1.8656	1.8473	1.829
18	2.1399	2.1582	2.1033	2.2131	2.1216	2.1216	2.0851
19	2.4508	2.5789	2.4691	2.5606	2.5423	2.4874	2.5789
20	2.5789	2.5972	2.5606	2.5606	2.5606	2.5606	2.5606
21	2.4691	2.5789	2.4508	2.4874	2.4874	2.5057	2.5423
22	2.4691	2.396	2.3045	2.3777	2.4508	2.4326	2.4326
23	2.2862	2.1582	2.0668	2.1033	2.1216	2.1399	
24	1.8839	1.9204	1.8473	1.829	1.8107	1.829	1.8656
Max	2.5789	2.5972	2.5606	2.5606	2.5606	2.5606	2.5789
Min	1.4998	1.4449	1.4815	1.4815	.7865	1.4632	1.4815
Avg	1.9898	2.0292	1.9532	1.9753	1.9300	1.9776	1.9936

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283080 / 22/11KV MHADA S/STN

Feeder No / Name : 205 / FEEDER NO. 5

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3898	.3658	.4075	.4207	.3898	.4024	.4075
2	.3841	.3475	.3544	.3658	.3544	.3841	.3898
3	.3658	.3109	.337	.3475	.3544	.3658	.3721
4	.3475	.3658	.3366	.3475	.3544	.3658	.3366
5	.3475	.3841	.3544	.3658	.3898	.3841	.3721
6	.443	.439	.3544	.3658	.4075	.4024	.4252
7	.4252	.4755	.3544	.4024	.443	.439	.4784
8	.4755	.5304	.4961	.5138	.4784	.5853	.4961
9	.5304	.5487	.5493	.5316		.6401	.5316
10	.5487	.6024	.4938	.443	.5121	.5304	.567
11	.4755	.5316	.6036	.4961	.4755	.4961	.5121
12	.4024	.443	.462	.443	.4572	.443	.4207
13	.3841	.4252	.4572	.4075		.4252	.4207
14	.3658	.3544	.439	.4252	.4024	.3898	.3841
15	.3658	.3544	.4024	.3189	.3475	.3544	
16	.3475	.3544	.3658	.3189	.3658	.3544	.3475
17	.3475	.3544	.3658	.3544	.3658	.3544	.3475
18	.439	.443	.4207	.4252	.439	.4075	.4024
19	.6401	.5847	.5853	.567	.5853	.567	.567
20	.6767	.567	.5853	.567	.6036	.567	.5853
21	.6219	.5847	.567	.6024	.6219	.567	.5853
22	.5853	.6024	.5304	.5316	.5487	.5493	.567
23	.5121	.5316	.5304	.4961	.5121	.4784	
24	.443	.439	.443	.4572	.4252	.4207	.443
Max	.6767	.6024	.6036	.6024	.6219	.6401	.5853
Min	.3475	.3109	.3366	.3189	.3475	.3544	.3366
Avg	.4527	.4558	.4498	.4381	.4470	.4531	.4527

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283110 / 22/11 kv Akruti Substation

Feeder No / Name : 202 / Old MSEB SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7964	.6697	.7602		.7964	.7421	.7602
2	.7964	.6697	.724		.7964	.7164	.724
3	.724	.6516	.6878		.7783	.724	.724
4	.724	.6697	.6878		.724	.7421	.724
5	.724	.7059	.724		.724	.7421	.7783
6	.7602	.724	.724		.7602	.7343	.8326
7	.8326	.7602	.7059		.8326	.7602	.8326
8	.905	.7964	.8145		.8688	.8688	.8326
9	.9774	1.0136	.8326	.905	.905	1.0136	.9955
10	1.0136	.9955	.9955	1.0317	1.0498	1.1222	1.086
11	1.0498	1.0498		.9593	1.1222	1.0317	1.1584
12	1.0498	1.2851	.9774	.9955	1.1222	1.0498	1.086
13	.8869	.9774	.7964	.8507	1.0136	.9593	.9231
14	.8688	.905		.8326	1.0136	.905	1.0136
15	.8326	.9231		.8326	.8326	.905	1.0317
16	.8869	.9412		.724	.8326	.9774	1.0679
17	.9593	.9774		.905	1.0317	1.0498	1.1946
18	1.1222	1.1765		.9774	1.1946	1.1041	1.2308
19	1.2127	1.2489		1.1584	1.3213	1.267	1.3032
20	1.1403	1.1946		1.0288	1.267	1.1946	
21	1.0317	1.086		1.0498	1.1222	1.086	
22	.9231	.9774		.9231	1.1946	.9774	
23	.8326	.8145		.8688	.8326	.8326	
24	.8326	.7421		.7421	.8326	.8145	.7602
Max	1.2127	1.2851	.9955	1.1584	1.3213	1.267	1.3032
Min	.724	.6516	.6878	.724	.724	.7164	.724
Avg	.9118	.9148	.7858	.9241	.9570	.93	.9530

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283110 / 22/11 kv Akruti Substation

Feeder No / Name : 203 / VIHANG PARK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1372	.1715		.1372	.1543	.1372
2	.1543	.1372	.1715		.12	.1372	.12
3	.1543	.12	.1372		.12	.12	.12
4	.1372	.1372	.1372		.12	.1543	.12
5	.1372	.1543	.1267		.12	.1372	.1372
6	.1372	.1543	.1372		.1372	.1372	.1372
7	.1543	.1715	.1629		.1543	.1715	.1372
8	.1715	.1715	.1629		.1886	.2058	.1372
9	.12	.1715	.181	.1715	.1715	.2058	.1543
10	.12	.1543	.1991	.1715	.1372	.1543	.1715
11	.12	.1543	.1543	.12	.1372	.1543	.1372
12	.1029	.1543	.1543	.12	.1715	.1372	.1372
13	.1372	.1029	.1448	.12	.1029	.12	.1543
14	.12	.1715		.1372	.1448	.12	.1372
15	.12	.1543		.1372	.1372	.12	.1372
16	.1029	.1029		.1372	.1372	.0857	.1029
17	.12	.1029		.0857	.12	.0857	.12
18	.1715	.2058		.12	.1372	.1029	.1372
19	.1886	.1715		.1715	.2229	.1715	.1715
20	.1715	.1886		.1715	.2058	.1715	
21	.1886	.2058		.1886	.2229	.1715	
22	.2058	.2058		.1886	.2172	.1886	
23	.1715	.1715		.1715	.1715	.1715	
24	.1715	.1543		.1543	.1372	.1715	.1372
Max	.2058	.2058	.1991	.1886	.2229	.2058	.1715
Min	.1029	.1029	.1267	.0857	.1029	.0857	.1029
Avg	.1479	.1565	.1570	.1479	.1530	.1479	.1372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283110 / 22/11 kv Akruti Substation

Feeder No / Name : 206 / BHAITHI COLONY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8238	.6984	.7522		.8238	.8238	.7522
2	.8238	.6805	.7343		.788	.8059	.7522
3	.8238	.6447	.7164		.7522	.788	.7522
4	.8059	.6626	.7701		.7522	.8238	.7522
5	.8238	.7522	.8417		.7522	.8417	.788
6	.8954	.8417	.8596		.788	.8417	.8238
7	.9671	.9492	.8596		.8596	.8954	.8954
8	1.0566	.985	.9134		1.0029	.985	.8954
9	.9313	.9671	.9134	.9313	.9671	.8954	.8596
10	.8954	.9134	.8954	.9492	.8954	.9134	.8869
11	.8417	.9492	.9313	.8954	.8775	.8417	.9313
12	.788	1.1283	.9313	.9134	.8775	.8059	.8954
13	.7343	.8417	.8059	.8059	.8596	.7701	.788
14	.6984	.7522		.7701	.7164	.7701	.7701
15	.7164	.7701		.7522	.7164	.7343	.7164
16	.6984	.7343		.703	.7164	.7522	.7343
17	.6805	.8417		.7701	.8238	.8238	.8238
18	.8417	.985		.9313	.9313	.8775	.8954
19	1.0387	1.0566		1.0566	1.0745	1.0745	1.0745
20	1.0745	1.0745		1.0208	1.0387	1.0387	
21	.9671	1.0029		.985	.985	1.0029	
22	1.0029	.9671		.9492	.9671	.9313	
23	.8417	.788		.8954	.8596	.9313	
24	.8596	.7701		.7522	.8596	.8596	.7701
Max	1.0745	1.1283	.9313	1.0566	1.0745	1.0745	1.0745
Min	.6805	.6447	.7164	.703	.7164	.7343	.7164
Avg	.8596	.8649	.8404	.8801	.8619	.8678	.8279

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283110 / 22/11 kv Akruti Substation

Feeder No / Name : 207 / BHIM NAGAR

Feeder KV- 11 / OUTGOING

DATE	23-DEC-17
HR	Load (MW)
15	.1372
Max	.1372
Min	.1372
Avg	.1372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283076 / 22/22 KV WAGLE ETATE

SWITCHING

Feeder No / Name : 301 / Feeder No I

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8292	2.8292	2.6406	2.6406	2.8292	2.8292	2.8292
2	2.8292	2.6406	2.6406	2.6406	2.8292	2.8292	2.8292
3	2.8292	2.6406	2.6406	2.6406	3.0178	2.8292	2.8292
4	2.8292	2.6406	2.6406	2.6406	3.0178	2.8292	2.8292
5	2.8292	2.6406	2.6406	2.6406	3.0178	2.8292	2.8292
6	2.8292	2.452	2.6406	2.6406	2.8292	2.8292	2.8292
7	2.8292	2.452	2.6406	2.6406	2.8292		2.8292
8	3.2065	2.8292	2.8292	2.8292	3.0178	3.2065	3.2065
9	3.5837	3.3951	3.2065	3.3951	3.9609	6.9787	4.3381
10	3.9609	4.1495	3.7723	4.1495	5.0926	4.904	5.2812
11	4.1495	3.9609	3.9609	4.7154	4.904	5.2812	5.4698
12	3.9609	4.5268	3.7723	4.3381	5.0926	5.4698	5.4698
13		3.5837	2.8292	3.7723	4.1495	4.3381	4.5268
14		4.1495	3.7723	3.9609	5.2812	5.2812	4.904
15		4.1495	3.7723	4.1495	5.4698	5.4698	5.2812
16	3.9609	3.9609	3.5837	4.3381	5.2812	5.0926	5.0926
17	3.7723	4.3381	3.5837	4.3381	5.2812	5.2812	5.0926
18	3.5837	4.1495	3.7723	4.3381	5.0926	4.7154	4.904
19	3.2065	4.1495	3.7723	3.9609	4.5268	4.904	4.7154
20	3.0178	3.9609	3.3951	3.5837	3.9609	4.1495	3.9609
21	2.8292	3.2065	3.2065	3.2065	3.5837	3.3951	3.5837
22	2.8292	3.0178	3.2065	3.2065	3.3951	3.3951	3.3951
23	3.0178	3.0178	3.0178	3.2065	3.3951	3.2065	3.2065
24	3.0178	2.6406	2.6406	2.8292	3.0178	3.0178	3.0178
Max	4.1495	4.5268	3.9609	4.7154	5.4698	6.9787	5.4698
Min	2.8292	2.452	2.6406	2.6406	2.8292	2.8292	2.8292
Avg	3.2334	3.3951	3.1907	3.4501	3.9530	4.1331	3.9688

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283076 / 22/22 KV WAGLE ESTATE

SWITCHING

Feeder No / Name : 302 / Feeder No -II

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8861	1.8861	1.6975	1.6975	1.8861	1.6975	1.5089
2	1.8861	1.6975	1.6975	1.6975	1.6975	1.5089	1.5089
3	1.8861	1.6975	1.6975	1.6975	1.6975	1.5089	1.5089
4	1.8861	1.8861	1.5089	1.6975	1.6975	1.5089	1.5089
5	1.8861	1.8861	1.5089	1.5089	1.6975	1.5089	1.5089
6	1.8861	1.6975	1.5089	1.5089	1.5089	1.5089	1.5089
7	1.8861	1.6975	1.5089	1.6975	1.5089	1.6975	1.5089
8	2.2634	1.8861	1.6975	1.8861	2.0748	2.0748	1.8861
9	2.6406	2.452	1.8861	2.0748	3.0178	2.8292	2.8292
10	3.2065	2.8292	1.8861	2.6406	3.3951	3.2065	3.2065
11	3.2065	3.2065	2.2634	2.6406	3.3951	3.5837	3.3951
12	3.2065	3.3951	2.452	15.391	3.2065	3.5837	3.3951
13	3.3951	3.2065	2.452	2.8292	3.3951	3.5837	3.5837
14	3.3951	3.3951	2.452	2.8292	3.5837	3.5837	3.3951
15	3.2065	3.2065		2.6406	3.3951	3.7723	3.5837
16	3.2065	3.0178	2.0748	2.6406	3.5837	3.3951	3.5837
17	3.3951	3.0178	2.0748	2.6406	3.7723	3.3951	3.3951
18	3.0178	2.6406	2.2634	2.6406	3.0178	3.2065	3.0178
19	2.6406	2.6406	1.8861	2.452	2.6406	2.6406	2.452
20	2.2634	2.0748	1.8861	2.0748	2.2634	2.2634	2.2634
21	2.2634	2.0748	1.8861	1.8861	2.0748	2.0748	2.0748
22	2.2634	1.8861	1.6975	1.8861	1.8861	1.8861	2.0748
23	2.2634	2.0748	1.8861	1.8861	1.8861	1.8861	1.8861
24	2.0748	1.8861	1.8861	1.8861	1.8861	1.6975	1.6975
Max	3.3951	3.3951	2.452	15.391	3.7723	3.7723	3.5837
Min	1.8861	1.6975	1.5089	1.5089	1.5089	1.5089	1.5089
Avg	2.5463	2.3891	1.9025	2.6846	2.507	2.4834	2.4284

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283076 / 22/22 KV WAGLE ETATE

SWITCHING

Feeder No / Name : 305 / Feeder No V

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0748	1.5089	1.5089	1.6975	1.8861	1.6975	1.6975
2	1.8861	1.6975	1.5089	1.6975	1.6975	1.6975	1.6975
3	1.8861	1.5089	1.3203	1.6975	1.6975	1.6975	1.6975
4	1.8861	1.5089	1.3203	1.6975	1.6975	1.6975	1.6975
5	1.8861	1.6975	1.3203	1.6975	1.8861	1.6975	1.6975
6	1.8861	1.6975	1.3203	1.6975	1.6975	1.6975	1.6975
7	1.8861	1.6975	1.3203	1.6975	1.8861		1.8861
8	2.0748	2.0748	1.6975	2.0748	2.0748	2.0748	2.0748
9	2.452	2.2634	2.0748	2.2634	2.8292	2.8292	2.6406
10	2.8292	3.0178	2.6406	2.8292	3.3951	2.8292	3.3951
11	2.8292	3.0178	2.2634	3.0178	3.2065	3.2065	3.3951
12	2.8292	3.0178	2.452	3.0178	3.5837	3.0178	3.3951
13	2.6406	2.6406	2.0748	2.452	3.0178	2.8292	2.8292
14	2.6406	2.8292	2.2634	3.2065	3.3951	3.2065	3.0178
15	2.8292	3.2065	2.2634	3.2065	3.5837	3.3951	3.2065
16	2.8292	2.6406	2.2634	2.8292	3.3951	3.0178	3.5837
17		2.8292	2.2634	3.0178	3.3951	3.2065	3.0178
18	2.2634	3.0178	2.2634	2.6406	3.0178	3.0178	2.8292
19	2.452	2.6406	2.452	2.6406	2.6406	2.452	2.6406
20	2.0748	2.6406	2.0748	2.452	2.2634	2.2634	2.452
21	2.0748	2.2634	1.8861	2.0748	2.452	2.2634	2.2634
22	1.8861	1.8861	1.8861	1.8861	2.452	2.0748	2.0748
23	1.8861	1.8861	1.6975	1.8861	1.8861	1.6975	2.037
24	2.2634	1.6975	1.6975	1.6975	1.8861	1.6975	1.8861
Max	2.8292	3.2065	2.6406	3.2065	3.5837	3.3951	3.5837
Min	1.8861	1.5089	1.3203	1.6975	1.6975	1.6975	1.6975
Avg	2.2716	2.2869	1.9097	2.2948	2.5384	2.4028	2.4504

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283076 / 22/22 KV WAGLE ETATE

SWITCHING

Feeder No / Name : 310 / Feeder No IV

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7545	.7545	.7545	.7545	.7545	.7545
2		.7545	.7545	.7545	.9431	.7545	.7545
3		.7545	.7545	.7545	.9431	.7545	.7545
4		.7545	.7545	.7545	.9431	.7545	.7545
5		.7545	.7545	.7545	.9431	.7545	.7545
6		.7545	.7545	.7545	.7545	.7545	.7545
7		.9431	.7545	.7545	.7545		.9431
8		.9431	.9431	.7545	1.1317	1.1317	.9431
9		1.3203	1.1317	.7545	1.5089	1.3203	1.3203
10		1.3203	.9431	.7545	1.3203	1.5089	1.3203
11		1.3203	1.1317	.7545	1.5089	1.3203	1.1317
12		1.3203	1.1317	.7545	1.5089	1.6975	1.5089
13		.9431	.7545	.7545	1.3203	1.3203	1.1317
14		1.3203	1.1317	.7545	1.5089	1.3203	1.5089
15		1.1317	.9431	.7545	1.1317	1.3203	1.3203
16	1.5089	1.1317	1.1317	.7545	1.3203	1.3203	1.1317
17	1.1317	1.1317	1.1317	.7545	1.3203	1.5089	1.5089
18	1.3203	.9431	1.1317	.7545	1.3203	1.3203	1.3203
19	1.1317	1.1317	.9431	.7545	1.1317	1.3203	1.1317
20	1.1317	.9431	1.1317	.7545	1.3203	1.3203	1.3203
21	.9431	1.1317	1.1317	.7545	.9431	.9431	.9431
22	.7545	.7545	.9431	.7545	1.1317	.9431	1.1317
23	.8676	.9431	.9431	.7545	.9431		.9431
24		.7545	.7545	.7545	.7545	.7545	.9431
Max	1.5089	1.3203	1.1317	.7545	1.5089	1.6975	1.5089
Min	.7545	.7545	.7545	.7545	.7545	.7545	.7545
Avg	1.0987	.9981	.9431	.7545	1.1317	1.1317	1.0846

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283076 / 22/22 KV WAGLE ETATE

SWITCHING

Feeder No / Name : 320 / Kisan Nagar-2 Incomer to NON SHEDDABLE EXPRESS HV FEEDERS
 Kisan Feeder KV- 22 / INCOMING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5089	1.8861	1.5089	1.5089	1.6975	1.5089	1.6975
2	1.5089	1.8861	1.3203	1.5089	1.5089	1.5089	1.5089
3	1.5089	1.8861	1.3203	1.5089	1.6975	1.5089	1.5089
4	1.5089	1.8861	1.3203	1.5089	1.6975	1.5089	1.5089
5	1.5089	1.6975	1.3203	1.5089	1.5089	1.5089	1.5089
6	1.6975	1.8861	1.3203	1.5089	1.5089	1.5089	1.5089
7	1.6975	1.6975	1.3203	1.5089	1.5089	1.5089	1.5089
8	1.8861	1.6975	1.6975	1.6975	1.6975	1.8861	1.8861
9	2.0748	2.0748	1.8861	1.8861	2.0748	2.2634	2.0748
10	2.2634	2.2634	1.8861	2.2634	2.2634	2.2634	2.2634
11	2.2634	2.2634	1.8861	2.2634	2.2634	2.2634	2.2634
12	2.2634	2.0748	2.0748	2.0748	2.2634	2.2634	2.2634
13	1.8861	1.8861	1.6598	1.6975	1.8861	1.8861	1.8861
14	1.8861	1.8861	1.6975	1.8861	1.8861	2.0748	1.8861
15	1.8861	1.8861	1.5089	1.6975	1.8861	1.8861	1.8861
16	1.8861	1.6975	1.5089	1.6975	1.8861	1.8957	1.8861
17	1.8861	1.8861	1.5089	1.6975	1.8861	1.8861	1.8861
18	1.8861	1.8861	1.6975	1.8861	1.8861	1.8861	2.0748
19	2.2634	2.0748	2.0748	2.2634	2.2634	2.2634	2.2634
20	2.2634	2.2634	2.0748	2.2634	2.2634	2.2634	2.452
21	2.0748	2.0748	1.8861	1.8861	2.0748	2.0748	2.0748
22	2.0748	1.8861	1.8861	1.8861	1.8861	1.8861	1.8861
23	1.8861	1.6975	1.6975	1.6975	1.6975	1.8861	1.8861
24	1.6975	1.6975	1.5089	1.5089	1.6975	1.5089	1.6975
Max	2.2634	2.2634	2.0748	2.2634	2.2634	2.2634	2.452
Min	1.5089	1.6975	1.3203	1.5089	1.5089	1.5089	1.5089
Avg	1.8861	1.9176	1.6488	1.7840	1.8704	1.8708	1.8861

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283077 / 22 /11KV WAGLE ESTATE S/S

Feeder No / Name : 202 / NEW RAM GOPAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1698	.1509	.1698	.1886	.1509	.1698
2	.1509	.1509	.1509	.1509	.1886	.1509	.1509
3	.1509	.1509	.1509	.1509	.1886	.1509	.1509
4	.1509	.1509	.1509	.1509	.1509		.1509
5	.1509	.1509	.1509	.1509	.1886		.1509
6	.1509	.1509	.1509	.1509	.1886		.1509
7	.1509	.1509	.1509	.1509	.1509		.1509
8	.1698	.1509	.1509	.1509	.1698	.1886	.1698
9	.1886	.2263	.1886	.1886	.1886	.2263	.1886
10	.3961	.2452	.1886	.2452	.3772	.415	.3772
11	.3772	.3395	.2263	.2641	.3772	.415	.3772
12	.3961	.3018	.2829	.2641	.3206	.2452	.4715
13	.3772	.2641	.2829	.2452	.3018	.1698	.3395
14	.3961	.2829	.2829	.3018	.3206	.2075	.3772
15	.415	.3018	.2452	.3018	.4715	.415	.3772
16	.415	.3395	.2452	.3018	.3772	.4527	.3395
17	.415	.3018	.2263	.2452	.3772	.3772	.3772
18	.415	.3018	.2263	.3772	.3772	.3772	.2829
19	.2829	.3395	.2263	.3018	.2829	.3584	.2641
20	.2641	.3206	.2641	.2452	.2452	.2641	.2641
21	.2075	.3018	.2829	.2452	.2263	.2075	.2452
22	.1886	.2263	.2263	.2263	.2075	.1886	.1886
23	.1886	.1886	.1886	.1886	.1886	.2075	.1698
24	.1698	.1886	.1509	.1698	.1509	.1509	.1886
Max	.415	.3395	.2829	.3772	.4715	.4527	.4715
Min	.1509	.1509	.1509	.1509	.1509	.1509	.1509
Avg	.2641	.2373	.2059	.2224	.2585	.2660	.2531

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283077 / 22 /11KV WAGLE ESTATE S/S

Feeder No / Name : 203 / JAI MAHARASHTRA NAGAR
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	.9431	1.0374	.9431	1.1317	1.0374	.9431
2	.9431	1.0374	.9431	.9431	1.0374	1.0374	.9431
3	.9431	.9431	.9431	.9431	1.0374	1.0374	1.0374
4	.9431	1.0374	.9431	.9431	1.1317	1.0374	.9431
5	.9431	.9431	.9431	.9431	1.1317	1.0374	.9431
6	.9431	1.0374	.9431	.9431	1.0374	1.0374	.9431
7	1.0374	.9431	.9431	.9431	1.0374	1.0374	1.0374
8	1.0374	1.1317	1.0374	1.1317	1.1317	1.0374	1.1317
9	1.226	1.226	1.226	1.3203	1.5089	1.5089	1.3203
10	1.6032	1.6032	1.226	1.7918	2.2634	2.1691	1.6975
11	1.6975	1.6975	1.3203	1.6975	2.0748	2.0748	1.7918
12	1.5089	1.6032	1.3203	1.6032	1.8861	2.452	1.7918
13	1.4146	1.6032	1.1317	1.5089	2.0748	1.8861	1.5089
14	1.5089	1.6032	1.226	1.3203	2.1691	1.6975	1.6975
15	1.6032	1.5089	1.1317	1.6032	1.7918	2.1691	1.6975
16	1.7918	1.5089	1.3203	1.7918	2.0748	2.2634	1.6975
17	1.3203	1.5089	1.226	1.5089	2.1691	1.7918	1.9805
18	1.3203	1.4146	1.226	1.4146	1.6032	1.6032	1.5089
19	1.3203	1.5089	1.1317	1.226	1.5089	1.5089	1.5089
20	1.226	1.226	1.226	1.3203	1.226	1.3203	1.226
21	1.1317	1.1317	1.1317	1.3203	1.1317	1.226	1.1317
22	1.0374	1.1317	1.1317	1.226	1.1317	1.3203	1.1317
23	1.5089	1.0468	1.0374	1.1317	1.1317	1.1317	1.1317
24	1.0374	.9431	1.1317	.9431	1.1317	1.1317	1.0374
Max	1.7918	1.6975	1.3203	1.7918	2.2634	2.452	1.9805
Min	.9431	.9431	.9431	.9431	1.0374	1.0374	.9431
Avg	1.2496	1.2618	1.1199	1.2692	1.4814	1.4814	1.3242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283077 / 22 /11KV WAGLE ESTATE S/S

Feeder No / Name : 205 / RAILADEVI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6602	.6602	.6602	.5658	.6602	.6602	.5658
2	.6602	.6602	.5658	.5658	.6602	.6602	.5658
3	.6602	.6602	.5658	.5658	.6602	.6602	.5658
4	.6602	.5658	.5658	.5658	.6602	.6602	.5658
5	.6602	.5658	.5658	.5658		.6602	.5658
6	.6602	.5658	.5658	.5658	.6602	.6602	.5658
7	.6602	.5658	.5658	.5658	.6602	.6602	.5658
8	.6602	.6602	.6602	.6602	.7545	.6602	.6602
9	.8488	.8488	.7545	.8488	.9431	.9431	.9431
10	1.0374	1.1317	.7545	1.0374	1.3203	1.1317	1.3203
11	1.226	1.3203	.9431	1.1317	1.4146	1.4146	1.3203
12	1.226	1.226	.9431	1.1317	1.4146	1.3203	1.4146
13	.9431	1.0374	.8488	1.0374	1.226	1.226	1.3203
14	.9431	1.226	.9431	.9431	1.3203	1.5089	1.3203
15	1.1317		.9431	1.0374	1.5089	1.5089	1.5089
16	1.226	1.3203	.9431	1.226	1.5089	1.5089	1.4146
17	1.1317	1.3203	.8488	1.1317	1.4146	1.4146	1.4146
18	.9431	1.1317	.8488	1.0374	1.1317	1.226	1.1317
19	.8488	1.0374	.8488	.9431	1.0374	1.1317	1.0374
20	.7545	.8488	.7545	.8488	.8488	.8488	.8488
21	.7545	.7545	.7545	.7545	.7545		.7545
22	.6602	.7545	.6602	.6602	.6602	.6602	.7545
23	.6602	.6602	.6602	.6602	.6602	.6602	.6602
24	.6602	.6602	.6602	.6602	.6602	.6602	.6602
Max	1.226	1.3203	.9431	1.226	1.5089	1.5089	1.5089
Min	.6602	.5658	.5658	.5658	.6602	.6602	.5658
Avg	.8449	.8775	.7427	.8213	.98	.9759	.9352

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283083 / 22/11KV Ramnagar Substation

Feeder No / Name : 202 / 11KV Hanuman Nagar

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.7356			
4	.7545			
6	.7356			
7	.6602			
9		.7202		.9619
10		.9945		1.2826
11		1.0288		1.3392
12		1.166		1.3957
13		1.0631		1.0374
14		1.166		1.3014
15		1.0631		1.1883
16		1.0631		1.2826
17		1.2637		1.4146
18		1.2449		1.4146
19		1.226		1.1506
20		.9997		1.094
21		.811		.9242
22		.8299		.811
23		.7922		.7733
24	.7922		.7356	
Max	.7922	1.2637	.7356	1.4146
Min	.6602	.7202	.7356	.7733
Avg	.7356	1.0288	.7356	1.1581

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283083 / 22/11KV Ramnagar Substation

Feeder No / Name : 204 / NSIL-HT

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER MIDC EQUIVALENT

HAVING WEEKLY STAGGERING

DATE	28-DEC-17
HR	Load (MW)
10	.3584
11	.3395
12	.3018
13	.2641
14	.3395
15	.3395
16	.3018
17	.3018
18	.2075
Max	.3584
Min	.2075
Avg	.3060

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283083 / 22/11KV Ramnagar Substation

Feeder No / Name : 205 / I-THINK IT Park-1
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER MIDC EQUIVALENT
HAVING WEEKLY STAGGERING

DATE	23-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)
10	.1372	
11	.1372	
12	.1372	.2263
13		.2263
14		.2263
15		.2263
16		.2452
17		.2263
18		.2263
19		.1509
Max	.1372	.2452
Min	.1372	.1509
Avg	.1372	.2192

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283099 / 22/22KV Ashar IT Park

Switchin

Feeder No / Name : 301 / 22KV Sathenagar Feeder

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4897	1.6975	1.6598	2.0748	1.8861	1.8861	1.8861
2	2.3765	1.6975	1.6221	1.8861	1.6975	1.8861	1.8861
3	2.452	1.6975	1.5844	1.8861	1.6975	1.8861	1.8861
4	2.4143	1.6975	1.5466	1.6975	1.6975	1.8861	1.6975
5	2.3765	1.6975	1.5466	1.6975	1.6975	1.8861	1.6975
6	2.3765	1.6975	1.5466	1.6975	1.6975	1.8861	1.6975
7	2.8669	1.6975	1.5466	1.6975	1.6975	1.8861	1.8861
8	2.7915	1.8861	1.6975	1.8861	2.0748	2.0748	
9	3.4328	2.0748	2.0748	2.2634	2.452	2.6406	
10	3.7723	2.452	2.2634	2.452	2.8292	2.8292	
11	4.1495	2.452	2.2634	2.452	3.0178	3.0178	
12	3.9609	2.8292	2.2634	2.452	3.0178	3.0178	
13	2.6406	2.2634	2.0748	2.2634	2.6406	2.6406	
14	2.6406	2.452	2.2634	2.2634	3.0178	3.0178	
15	2.6406	2.452	2.0748	2.2634	3.0178	3.2065	
16	2.6406	2.452	2.0748	2.2634	3.0178	2.8292	
17	2.452	2.2634	2.2634	2.452	3.0178	3.0178	
18	2.452	2.452	2.452	2.452	3.0178	***	
19	2.452	2.8292	2.452	2.6406	2.8292	3.0178	
20	2.452	2.452	2.452	2.452	2.6406	2.8292	
21	2.2634	1.3622	2.452	2.452	2.2634	2.6406	
22	2.2634	2.1125	2.2634	2.0748	2.2634	2.452	
23	2.0748	1.9239	2.0748	1.8861	2.2634	2.452	
24	2.5652	1.8861	1.6598	2.0748	1.8861	2.0748	2.2634
Max	4.1495	2.8292	2.452	2.6406	3.0178	29.0467	2.2634
Min	2.0748	1.3622	1.5466	1.6975	1.6975	1.8861	1.6975
Avg	2.7082	2.1032	2.0072	2.1534	2.3891	3.5837	1.8625

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283099 / 22/22KV Ashar IT Park

Switchin

Feeder No / Name : 303 / Ashir IT complex feeder

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	.9431	.8676	.9431	.9431	1.1317	1.1317
2	1.094	.9431	.8299	.9431	.9431	.9431	1.1317
3	1.0185	.9431	.7922	.9431	.9431	.9431	1.1317
4	.9808	.9431	.7545	.7545	.9431	.9431	1.1317
5	.9431	.9431	.7545	.7545	.9431	.9431	.9431
6	.9431	.9431	.7922	.7545	.9431	.9516	.9431
7	.9808	.9431	.8299	.9431	.9431	.9431	.9431
8	1.0185	.9431	.9054	.9431	1.1317	1.1317	
9	1.773	1.5089	1.1317	1.1317	1.6975		
10	2.0748	1.8861	1.3203	1.3203	2.2634	2.0748	
11	2.2634	1.8861		1.3203	2.452	2.452	
12		1.8861		1.3203	2.452	2.452	
13	2.2634	1.8861		1.3203	2.452	2.452	
14	2.2634	1.8861		1.3203	2.452	2.2634	
15	2.452	1.8861	.9431	1.5089	2.452	2.452	
16	2.452	1.8861	.7545	1.5089	2.6406	2.6406	
17	2.6406	1.8861	1.3203	1.3203	2.452	2.6406	
18	2.452	1.6975	1.1317	1.1317	2.452	2.452	
19	2.0748	1.6975	1.3203	1.1317	2.0748	2.2634	
20	1.6975	1.3203	1.1317	.9431	1.6975	1.6975	
21	1.5089	1.1317	1.1317		1.5089	1.5089	
22	1.5089	1.0185	1.1317	.9431	1.3203	1.5089	
23	1.3203	.9431	1.1317	.9431	1.3203	1.5089	
24	1.2071	1.1317	.9054	1.1317	.9431	1.1317	1.3203
Max	2.6406	1.8861	1.3203	1.5089	2.6406	2.6406	1.3203
Min	.9431	.9431	.7545	.7545	.9431	.9431	.9431
Avg	1.6549	1.3785	.9940	1.0989	1.6818	1.7143	1.0846

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283099 / 22/22KV Ashar IT Park

Switchin

Feeder No / Name : 309 / 22KV JAI BHAWANI NAGER SHEDDABLE FEEDER HAVING WEEKLY

FEEDER Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.679	.5658	.7167	.7545	.7545	.7545	.9431
2	.6036	.5658	.679	.7545	.5658	.5658	.7545
3	.5658	.5658	.679	.7545	.5658	.5658	.7545
4	.4904	.5658	.6413	.7545	.5658	.5658	.7545
5	.4904	.5658	.6413	.7545	.5658	.5658	.7545
6	.4904	.5658	.6413	.7545	.5658	.5658	.7545
7	.7545	.7545	.679	.7545	.5658	.7545	.7545
8	1.0185	.9431	.8676	1.1317	.9431	.9431	
9	1.2071	1.3203	1.1317	1.1317	1.3203	1.3203	
10	1.3203	1.5089	1.3203	1.5089	1.6975	1.6975	
11	1.3203	1.6975	1.3203	1.6975	1.8861	1.6975	
12	1.3203	1.5089	1.3203	1.6975	1.6975	1.6975	
13	1.3203	1.3203	1.1317	1.3203	1.5089	1.3203	
14	1.1317	1.3203	.9431	1.3203	1.3203	1.5089	
15	.9431	1.1317	.9431	1.3203	1.3203	1.6975	
16	.9431	1.1317	.9431	1.1317	1.3203	1.5089	
17	1.3203	1.1317	.9431	1.3203	1.3203	1.5089	
18	1.1317	1.1317	1.1317	1.5089	1.5089	1.5089	
19	1.1317	.8383	1.1317	1.3203	1.3203	1.5089	
20	.9431	1.3203	1.1317	1.1317	1.3203	1.3203	
21	.9431	1.1317	.9431	1.1317	1.1317	1.1317	
22	.9431	1.0185	.9431	.9431	.9431	1.1317	
23	.7545	.8299	.7545	.9431	.9431	1.1317	
24	.7545	.7545	.7545	.7545	.7545	.7545	.9431
Max	1.3203	1.6975	1.3203	1.6975	1.8861	1.6975	.9431
Min	.4904	.5658	.6413	.7545	.5658	.5658	.7545
Avg	.9384	1.0079	.9305	1.1081	1.1002	1.1553	.8017