

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024003 / 33 KV WANI RAMBHAPUR

Feeder No / Name : 201 / 11 KV BORGAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9945	.9431	1.226	.9431	.8288
2	.9945	.9431	1.226	.9431	.7621
3	.9945	.9431	1.226	.9431	.8288
4	1.0277	.9431	1.226	.9431	.8619
5	1.0608	.9145	1.2637	.9619	.8619
6	1.1603	1.0185	1.2826	1.0562	.8785
7	1.2936	1.0751	1.2826	1.2637	.9795
8	.8453	.9808	.9242	.7922	.961
9	1.1088	1.0185	.9808	.9808	1.0534
10	1.1105	1.3392	1.2637	1.3203	1.3491
11	1.386	1.1273	1.4335	1.4901	1.1317
12	1.3957	1.0349	1.3957	1.1694	1.0562
13	1.3014	1.2012	1.1317	1.0374	1.0751
14	1.1317	.8453	1.2826	1.0374	.9431
15	1.2826	.9945	1.2826	1.0751	1.0751
16	1.1317	1.1088		1.0751	.8299
17	1.4146	1.1458	1.094	1.1317	.7356
18	1.3203	1.3014	1.1317	1.0719	.9619
19	1.1883	1.226	1.1317	1.0534	.9242
20	.9054	.9619	1.1317	.8619	.9242
21	.9054	.9997	.9997	.961	
22	1.0185	1.0374	.9431	.9795	
23	1.0374	1.1694	.9808	.8785	
24	1.0277	.8488	1.2637	.7545	.8619
Max	1.4146	1.3392	1.4335	1.4901	1.3491
Min	.8453	.8453	.9242	.7545	.7356
Avg	1.1266	1.0467	1.1784	1.0302	.9469

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024003 / 33 KV WANI RAMBHAPUR

Feeder No / Name : 202 / 11 KV KHAMBORA ,EXPRESS SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.0762	.0762	.1143	.0953
2	.1326	.0762	.0762	.0762	.0953
3	.1341	.0762	.0762	.0762	.0953
4	.1524	.0762	.0762	.0762	.1143
5	.1524	.0762	.0762	.0762	.1143
6	.1524	.0762	.0762	.0762	.0953
7	.1524	.0762	.0762	.0762	.0953
8	.1524	.0381	.0762	.0381	.0953
9	.1715		.0762	.0762	.0924
10	.1715	.0762	.0762	.0762	.0953
11	.1524	.0829	.0762	.1524	.0762
12	.1524	.0829	.0762	.1524	.1097
13	.1524	.1109	.0762	.1524	.0762
14	.1524	.1143	.0762	.1143	.0762
15	.1524	.1524	.1143	.1143	.0762
16	.7701	.1143	.0762	.1143	.1143
17	.0762	.1143	.0381	.1143	.0762
18	.0762	.1143	.1143	.1524	.1143
19	.1524	.1143	.0762	.1109	.0762
20	.0762	.1143	.1143	.1143	.1143
21	.0762	.1143	.0762	.1143	
22	.1143	.1143	.1143	.1109	
23	.0762	.1143	.1143	.1143	
24	.1524	.0762	.1143	.1143	.0953
Max	.7701	.1524	.1143	.1524	.1143
Min	.0762	.0381	.0381	.0381	.0762
Avg	.1607	.0949	.0841	.1045	.0949

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024003 / 33 KV WANI RAMBHAPUR

Feeder No / Name : 203 / 11 KV PALSO

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4973	.5487	.5373	.394	.5175
2	.5544	.5487	.5373	.394	.499
3	.5544	.5487	.5373	.394	.499
4	.5914	.5487	.5373	.394	.5175
5	.5914	.5487	.5373	.3761	.5544
6	.6653	.6767	.5731	.394	.6099
7	.7392	.6767	.6447	.5731	.7023
8	.7947	.7316	.7701	.5373	.7577
9	.7762	.823	.8059	.7164	.7762
10	.7762	.7316	.823	.7316	.8501
11	.7762	.0924	.8413	.6805	.8596
12	.7701	.0829	.8962	.6805	.8048
13	.8238	.7459	.5853	.8417	.8962
14	.7343	1.0164	.6401	.8596	.7343
15	.7164	.9425	.6401	.8417	.6984
16	.7701	.8686		.6447	.6447
17	.7865	.924	.6447	.7164	.7164
18	.8871	.8596	.7164	.4251	.8775
19	.9511	.9134	.6805	.8686	.8954
20	.8779	.788	.6089	.8131	.788
21	.7762	.6805	.5731	.663	
22	.6584	.591	.4835	.6099	
23	.5853	.5731	.4477	.5544	
24	.5601	.5487	.5373	.4119	.499
Max	.9511	1.0164	.8962	.8686	.8962
Min	.4973	.0829	.4477	.3761	.499
Avg	.7173	.6671	.6347	.6048	.6999

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024003 / 33 KV WANI RAMBHAPUR

Feeder No / Name : 204 / 11 KV KANSHIVANI,AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5544	.1334	.197	.1629	1.2197
2	.4973	.1334	.197	.1629	1.0277
3	.4401	.1334	.197	.1629	1.1458
4	.5138	.1334	.197	.1629	1.0277
5	.4807	.1334	.197	.1629	1.1088
6	.4807	.1334	.197	.1267	1.0349
7	.3315	.1334	.1433	.0905	.9614
8	1.0164	1.094	.9313	.1086	.1492
9	.9945	1.2795	1.3253	.2534	.1478
10	1.3306	1.4146	1.3253	.2641	.1478
11	1.1934	1.1768	1.3321	.197	.2075
12	1.3073	1.1603	1.1393	.1612	.1886
13	1.2357	1.2266	1.1568	.2686	.1886
14	1.2894	1.3306	1.1568	.1791	.1791
15	1.1999	1.2266	1.262	.1433	.0716
16	.5552	.1326		.1433	.0716
17	.4706		.0905	.1612	.0716
18	.5121		.1629	.1326	.1612
19	.4755		.1629	.2033	.1433
20	.1097	.181	.181	.2218	.1612
21	.2012	.181	.181	.1989	
22	.2286	.181	.181	1.2567	
23	.2096	.2896	.1715	1.1271	
24	.4973	.1886	.1991	.181	1.1105
Max	1.3306	1.4146	1.3321	1.2567	1.2197
Min	.1097	.1326	.0905	.0905	.0716
Avg	.6719	.5713	.5341	.2597	.5012

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024003 / 33 KV WANI RAMBHAPUR

Feeder No / Name : 206 / 11 KV Rajeshwar Express. NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0029	.0027	.0029	.0032	.0029
2	.0029	.0027	.0029	.0032	.0029
3	.0029	.0027	.0179	.0032	.0029
4	.0029	.0027	.0179	.0032	.0029
5	.0027	.0027	.0179	.0032	.0029
6	.0029	.0027	.0029	.0032	.0029
7	.0057	.0027	.0029	.0032	.0029
8	.0029	.0032	.0029	.0032	.0029
9	.0029	.0065	.0057	.0032	.0185
10	.0029	.0065	.0057	.009	.0029
11	.0029	.0029	.0149	.0057	.009
12	.0057	.0166	.0179	.0358	.009
13	.0057	.0029	.0179	.0358	.009
14	.0358	.0029	.0179	.0057	.0029
15	.0358	.0029		.0057	.0029
16	.0057	.0029	.0179	.0057	.0029
17	.0065	.0029	.0065	.0057	.0029
18	.0065	.0032	.0065	.0029	.0029
19	.0065	.0032	.0032	.0029	.0029
20	.0032	.0032	.0032	.0023	.0029
21	.0032	.0032	.0032	.0023	
22	.0029	.0032	.0032	.0029	
23	.0027	.0032	.0032	.0029	
24	.0029	.0027	.0032	.0032	.0191
Max	.0358	.0166	.0179	.0358	.0191
Min	.0027	.0027	.0029	.0023	.0029
Avg	.0066	.0038	.0086	.0066	.0053

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024003 / 33 KV WANI RAMBHAPUR

Feeder No / Name : 207 / 11 KV KANSHIVANI GAVTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.1646	.1612	.1433	.1478
2	.1848	.1646	.1612	.1433	.1478
3	.1848	.1646	.1612	.1433	.1326
4	.2033	.1646	.1612	.1433	.1492
5	.2033	.1646	.1791	.1612	.1492
6	.2218	.2012	.197	.1791	.1848
7	.2218	.2195	.2149	.2328	.1848
8	.2402	.2012	.197	.2149	.2402
9	.2033	.2561	.2149	.197	.2587
10	.2155	.2378	.2507	.3292	.2957
11	.2155	.2402	.3877	.197	.2378
12	.197	.2218	.2012	.2686	.2012
13	.2507			.2328	.1886
14	.2686	.2218	.1646	.2328	.1791
15	.2328	.2321	.2561	.2328	.1254
16	.2507	.2155	.2378	.2865	.0895
17	.3109		.2865	.2218	
18	.2561		.3582	.3142	.3224
19	.3292		.3224	.3326	.3045
20	.2743	.2686	.2865	.3142	.2865
21	.2378	.2686	.2507	.2957	
22	.2012	.1791	.1791	.1848	
23	.2012	.1791	.1612	.1848	
24	.2033	.1646	.1612	.1433	.1478
Max	.3292	.2686	.3877	.3326	.3224
Min	.1848	.1646	.1612	.1433	.0895
Avg	.2289	.2065	.2240	.2221	.1987

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024003 / 33 KV WANI RAMBHAPUR

Feeder No / Name : 208 / 11 kv BORGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0995	.2968	.3353	.3048	.1109
2	.0995	.2968	.3353	.3048	.0995
3	.0995	.2968	.3353	.3048	.1109
4	.0995	.2968	.3353	.3048	.0995
5	.0995	.2968	.3658	.2896	.0995
6	.1109	.3125	.3963	.3048	.0995
7	.1109	.4218	.3658	.3048	.0995
8	.1658	.1406	.0914	.2439	.2652
9	.1848	.1562	.1219	.3048	.4108
10	.0995	.1562	.1524	.2343	.4973
11	.1326	.1848	.1219	.5182	.5624
12	.1219	.1989	.1219	.4877	.5624
13	.1524	.1478	.1219	.5182	.5624
14	.1524	.116	.0937	.5487	.4572
15	.1524	.1326	.0914	.5487	.5639
16	.1829	.1326	.1562	.5182	.1219
17	.1677	.1658	.1219	.1219	.1219
18	.1219	.1524	.1372	.0995	.0914
19	.1067	.0914	.1372	.1326	.1219
20	.1219	.1219	.1372	.1326	.0914
21	.1219	.1219	.1372	.1326	
22	.1219	.3048	.3048	.1326	
23	.1067	.3048	.3048	.0995	
24	.0995	.2896	.3353	.3048	.1109
Max	.1848	.4218	.3963	.5487	.5639
Min	.0995	.0914	.0914	.0995	.0914
Avg	.1263	.2140	.2149	.2999	.2505

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024003 / 33 KV WANI RAMBHAPUR

Feeder No / Name : 405 / 33 KV AMIBIKA EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0721	1.0242	1.1031	1.0345	.9758
2	.0646	1.0525	1.1145	1.0402	.9314
3	.0776	1.0468	1.1145	1.0231	.937
4	.0696	1.0808	1.1145	1.1488	.8155
5	.0746	1.0864	1.1145	1.2289	.9203
6	.0796	.8205	.7087	1.1546	.8593
7	.0943	.5093	.703	1.1431	.9314
8	.0887	.9336	.8859	1.1431	.9259
9	.0998	.9336	1.0974	1.1431	1.1033
10	.0943	.9054	1.2003	1.0185	1.1255
11	1.4304	.9314	1.1996	1.2174	1.0298
12	.4915	.9314	1.1883	1.2289	.5093
13	.9202	.8254	1.1317	1.1431	1.2166
14	.5373	.9092	1.1317	1.1317	.7145
15	.9488	.8354	1.2166	1.2003	1.1431
16	1.1317	.8254	1.16	1.1431	1.1431
17	1.1317	.9813	1.177	.9717	1.1317
18	.9336	1.126	1.1774	1.1188	1.1603
19	.928		1.1431	1.131	1.1088
20	.9733	1.0974	1.1431	1.0343	1.086
21	.679	1.1431	1.1431	1.0293	
22	.6507	1.1431	1.1431	1.0243	
23	.9789	1.1317	1.0288	1.0146	
24	.0646	1.0751	1.1088	1.0002	.9702
Max	1.4304	1.1431	1.2166	1.2289	1.2166
Min	.0646	.5093	.703	.9717	.5093
Avg	.5256	.9717	1.0937	1.1028	.9876

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024003 / 33 KV WANI RAMBHAPUR

Feeder No / Name : 409 / J.J.Fine Express NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1735	1.4975	1.5432	1.3717	1.3326
2	1.1437	1.5203	1.5432	1.3717	1.5302
3	1.3306	1.4861	1.5432	1.4003	1.3078
4	1.3472	1.5032	1.5432	1.3832	1.3078
5	1.3417	1.5089	1.5432	1.4289	1.2382
6	1.3306	1.406	1.4518	1.4289	1.2382
7	1.2696	1.5032	1.3946	1.4289	1.2382
8	1.3472	1.4232	1.3717	1.3375	1.3805
9	1.5524	1.3889	1.4575	1.4746	1.4858
10	1.2641	1.366	1.4861	1.1203	1.2282
11	1.4304	1.4248	1.2974	1.4289	1.3546
12	1.4289	1.3029	1.5432	1.4289	1.6004
13	1.5432	1.4526	1.3832	1.4861	1.4289
14	1.2574	1.2253	1.4575	1.2574	1.4118
15	1.4861	1.3417	1.4289	1.3717	1.4003
16	1.3146	1.4637	1.3146	1.5432	1.1888
17	1.4518	1.2531	1.2631	1.3717	1.3546
18	1.3089	1.4861	1.3717	1.1476	1.5375
19	1.5146	1.4861	1.3717	1.1835	1.286
20	1.3832	1.4289	1.3717	1.2829	1.326
21	1.446	1.4289	1.3717	1.4027	
22	1.4518	1.4289	1.3717	1.4304	
23	1.4403	1.4289	1.3717	1.4581	
24	1.2752	1.5489	1.5432	1.3717	1.3525
Max	1.5524	1.5489	1.5432	1.5432	1.6004
Min	1.1437	1.2253	1.2631	1.1203	1.1888
Avg	1.3680	1.4293	1.4308	1.3713	1.3585

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024021 / 33 KV APATAPA

Feeder No / Name : 201 / 11 KV GHUSAR FDR .

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4668	.4435	.4294	.3326	.3734
2	.462	.4435	.4294	.3326	.3734
3	.462	.4435	.4108	.3326	.3734
4	.4668	.4435	.4108	.3292	.3734
5	.4805	.4435	.4108	.3292	.3547
6	.462	.4251	.4294	.3292	.3734
7	.4435	.4251	.4108	.3881	.3921
8	.4251	.4251	.4108	.2957	.4294
9	.4435	.5175	.5121	.3734	.5041
10	.462	.4805	.5487	.6722	.4435
11	.4805	.4805	.6036	.5601	.5359
12	.4805	.5914	.5121	.4854	.4435
13	.2402	.5914	.439	.4854	.3696
14	.4435	.5914	.5487	.5041	.3658
15	.5175	.5544	.6036	.5041	.462
16	.4435	.5175	.6219	.5041	.4805
17	.5175	.5415	.6099	.5788	.5175
18	.7207	.6722	.6283	.6161	.6584
19	.7947	.7282	.6838	.6908	.6099
20	.7207	.6535	.4805	.6161	.5544
21	.6468	.5415	.3696	.5601	.5175
22	.543	.5041	.3326	.4854	.4805
23	.499	.4668	.3326	.4481	
24	.462	.4435	.4481	.3142	.3921
Max	.7947	.7282	.6838	.6908	.6584
Min	.2402	.4251	.3326	.2957	.3547
Avg	.5035	.5154	.4841	.4612	.4512

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024021 / 33 KV APATAPA

Feeder No / Name : 202 / 11 KV MHAISANG FDR .
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7712	.7362	.6584	.5373	.6036
2	.7712	.7186	.6036	.5373	.6036
3	.7712	.7186	.6036	.5373	.6036
4	.7712	.7011	.6036	.5373	.5853
5	.7712	.7011	.6036	.5373	.5853
6	.7362	.631	.6036	.543	.6036
7	.7011	.7011	.6036		.6401
8	.8413	.7186	.695		.8413
9	1.0317	.8869	.8764	.5121	.9694
10	1.0679	.9412	.9114	.6219	1.0136
11	.9412	.9412	.9465	.6584	1.0631
12	.9774	.9412	.8764	.823	.9816
13	.9774	.9412	.8238	1.1157	.9568
14	.9412	.9412	.8413	1.1888	.9465
15	.9774			1.0608	.9816
16	.9774	.9412	.8764	.9511	.9465
17	.9114	1.0242	.9231	.9694	.9465
18	1.1043	1.1157	1.1403	1.1157	1.1403
19	1.1568	1.1888	1.3032	1.2437	1.1744
20	1.0692	1.0791	1.1403	1.0425	1.0867
21	.9465	.9511	.9593	.8962	.9774
22	.8413	.8779	.8326	.7682	.8326
23	.7888	.7682	.7522	.695	
24	.7888	.7362	.695	.6878	.6219
Max	1.1568	1.1888	1.3032	1.2437	1.1744
Min	.7011	.631	.6036	.5121	.5853
Avg	.9014	.8653	.8206	.7991	.8568

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024021 / 33 KV APATAPA

Feeder No / Name : 203 / 11 KV Ghusar W/W Express. NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0158	.0158	.0154	.0158	.0154
2	.0158	.0158	.0154	.0158	.0154
3	.0158	.0158	.0154	.0158	.0154
4	.0158	.0158	.0154	.0158	.0154
5	.0158	.0158	.0154	.0158	.0154
6	.0158	.0158	.0154	.0158	.0154
7	.0158	.0158	.0154	.0158	.0154
8	.0158	.0158	.0154	.0158	.0154
9	.0158	.0158	.0158	.0154	.0154
10	.0158	.0158	.0158	.0154	.0158
11	.0158	.0158	.0158	.0154	.0158
12	.0158	.0158	.0158	.0154	.0158
13	.0158	.0158	.0158	.0154	.0158
14	.0158	.0158	.0158	.0154	.0158
15	.0158	.0158	.0158	.0154	.0158
16	.0158	.0158	.0158	.0154	.0158
17	.0158	.0154	.0158	.0154	.0158
18	.0158	.0154	.0158	.0154	.0158
19	.0158	.0154	.0158	.0154	.0158
20	.0158	.0154	.0158	.0154	.0158
21	.0158	.0154	.0158	.0154	.0158
22	.0158	.0154	.0158	.0154	.0158
23	.0158	.0154	.0158	.0154	
24	.0158	.0158	.0154	.0158	.0154
Max	.0158	.0158	.0158	.0158	.0158
Min	.0158	.0154	.0154	.0154	.0154
Avg	.0158	.0157	.0157	.0156	.0156

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024021 / 33 KV APATAPA

Feeder No / Name : 204 / 11 KV Jaiguru Express.

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1109	.1109	.1097	.0924	.1097
2	.1109	.1109	.1097	.0924	.1097
3	.1109	.1109	.1097	.0934	.1097
4	.0185	.0185	.0183	.0185	.0183
5	.0185	.0187	.0183	.0185	.0183
6	.0187	.0187	.0183	.0185	.0183
7	.0187	.0187	.0183		.0183
8	.0187	.0187	.0183	.0185	.0114
9	.168	.168	.1663	.1463	.1646
10	.168	.168	.1463	.0549	.1663
11	.168	.1867	.1478	.0549	.168
12	.168	.1867	.1646	.0549	.1867
13	.1867	.1867	.1646	.0549	.1867
14	.1867	.1867	.1646	.0549	.1848
15	.1867	.0187	.1463	.0732	.1848
16		.168	.1646	.0732	.2241
17	.1848	.1463	.168	.0732	.2218
18	.1109	.1646	.1307	.0183	.1867
19	.0185	.0183	.0187	.0183	.0554
20	.1109	.1097	.112	.1097	.168
21	.1109	.1097	.0747	.1097	.168
22	.1109	.1097	.112	.1097	.112
23	.1109	.1097	.112	.1097	
24	.1109	.1109	.1097	.112	.1097
Max	.1867	.1867	.168	.1463	.2241
Min	.0185	.0183	.0183	.0183	.0114
Avg	.1099	.1073	.1051	.0687	.1261

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024021 / 33 KV APATAPA

Feeder No / Name : 205 / RAMGAON 11 KV FEEDER
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3326	.362	.3734	.2957	.3361
2	.3326	.362	.3734	.2772	.3361
3	.3326	.362	.3734	.2772	.3361
4	.3326	.362	.9335	.2772	.3174
5	.3326	.362	.9335	.3142	.3174
6	.4066	.3982	.3921	.3696	.3921
7	.5175	.5249	.5228	.5175	.5041
8	.462	.4251	.4481	.4805	.4668
9	.4066	.4435	.4066	.4108	.4854
10	.3696	.4435	.4066	.4668	.4755
11		.3696	.4066	.4294	.3658
12	.3696	.3326	.3696	.3361	.3292
13	.3326	.3326	.3326	.3361	.3292
14	.3326	.3326	.3361	.3174	.2772
15	.3326	.3696	.3361	.2987	.2743
16	.3326	.3696		.3174	.2896
17	.3734	.4108	.3326	.3547	.4066
18	.5228	.5228	.5175	.5041	.5175
19	.5121	.5415	.5175	.5041	.4805
20	.462	.4854	.4435	.4668	.4755
21	.4435	.4294	.4066	.4108	.3982
22	.3982	.3921	.3696	.3921	.3696
23	.362	.3734	.3326	.3734	
24	.3326	.3734	.3734	.3326	.3547
Max	.5228	.5415	.9335	.5175	.5175
Min	.3326	.3326	.3326	.2772	.2743
Avg	.3883	.4034	.4451	.3775	.3841

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024023 / 33 KV Nimbi

Feeder No / Name : 201 / 11 KV HINGNA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.5228	.5716	.4382	.4294
2	.4801	.5041	.5335	.373	.4108
3	.4801	.5041	.5335	.4024	.4108
4	.4801	.5228	.5335	.4115	.4108
5	.4801	.5228	.6478	.4801	.4294
6	.4973	.5601	.6859	.6344	.4854
7	.6344	.7468	.8002	.6935	.5788
8	.6859	.6348	.6859	.6516	.6908
9	.6516	.7655	.7282	.6001	.6908
10	.763	.823	.7842	.6687	.7202
11	.7373	.7716	.8215	.8002	.7545
12	.6836	.7716	.8215	.724	.7545
13	.6001	.7716	.8215	.8002	.7888
14	.7712	.6516	.7655	.7621	.7373
15	.7545	.6859	.7468	.9145	.7545
16	.8029		.7655	.724	.8916
17	.7842	.8383	.7095	.7655	.9907
18	.8962	.8002	.6783	.7842	.9907
19	.7468	.8383	.7716	.6722	.7621
20	.7468	.8002	.7373	.6348	.6859
21	.6722	.7621	.6173	.5228	.6097
22	.6161	.724	.5316	.4854	.4954
23	.5788	.6859	.5087	.4481	
24	.4801	.5228	.5716	.4854	.4294
Max	.8962	.8383	.8215	.9145	.9907
Min	.4801	.5041	.5087	.373	.4108
Avg	.6460	.6840	.6822	.6199	.6479

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024023 / 33 KV Nimbi

Feeder No / Name : 203 / 11 KV RUHATIYA EXP.

FEEDER Feeder KV- 11 /
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0187	.0191		.0187
2	.0191	.0187	.0191	.0191	.0187
3	.0191	.0187	.0191	.0191	.0187
4	.0191	.0187	.0191	.0191	.0187
5	.0191	.0187	.0191	.0191	.0187
6	.0191	.0187	.0191	.0191	.0187
7	.0191	.0187	.0191	.0191	.0187
8	.0191	.0187	.0191	.0191	.0187
9	.0191	.0187	.0187	.0191	.0187
10	.0191	.0191	.0187	.0191	.0191
11	.0191	.0191	.0187	.0191	.0191
12	.0191	.0191	.0187	.0191	.0191
13	.0191	.0191	.0187	.0191	.0191
14	.0191	.0191	.0187	.0191	.0191
15	.0191	.0191	.0187	.0191	.0191
16	.0187		.0187	.0191	.0191
17	.0187		.0187	.0187	.0191
18	.0187		.0191	.0187	.0191
19	.0187	.0191	.0191	.0187	.0191
20	.0187	.0191	.0191	.0187	.0191
21	.0187	.0191	.0191	.0187	.0191
22	.0187	.0191	.0191	.0187	
23	.0187	.0191	.0191	.0187	
24	.0191	.0187	.0191	.0191	.0187
Max	.0191	.0191	.0191	.0191	.0191
Min	.0187	.0187	.0187	.0187	.0187
Avg	.0190	.0189	.0190	.0190	.0189

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024023 / 33 KV Nimbi

Feeder No / Name : 204 / 11 KV HINGANA-AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.2971	1.3817
2				1.2209	1.3817
3				1.262	1.3443
4				1.2346	1.3817
5				1.2689	
6				1.2209	1.3443
7				1.3032	1.3817
8	.8573	.9149	.6478		
9	1.5432	1.6804	1.7177		
10	1.5623	1.6461	1.7177		
11	1.7814	1.6804	1.5684		
12	1.5581	1.5432	.9149		
13	.9393	1.6461	1.5684		
14	1.4243	1.6118	1.7177		
15	1.4255	1.6118	1.6804		
22			1.2003	1.531	
23			1.2209	1.4937	
24					1.419
Max	1.7814	1.6804	1.7177	1.531	1.419
Min	.8573	.9149	.6478	1.2209	1.3443
Avg	1.3864	1.5418	1.3954	1.3147	1.3763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024037 / 33KV PACHMORI S/Si

Feeder No / Name : 201 / 11 kv Sangvi Mohadi

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6133	.6554	.663	.503	.6133
2	.6036	.6226	.6464	.503	.5967
3	.6036	.6556	.6371	.503	.6036
4	.5935	.691	.6371	.503	.5868
5	.5765	.7619	.6203	.503	.5801
6	.6001	.7265	.6371	.57	.6036
7	.6299	.6882	.7701	.6706	.6952
8	.7865	.852	1.0159	.9054	.8192
9	.9231	.7209	1.085	1.0059	.9503
10	.9717	1.073	1.2289	1.1633	1.1012
11	1.0814	1.1401		1.0322	1.1012
12	1.1142	1.2071		1.0814	1.1336
13	1.1336	1.1336		1.1305	1.0688
14	.8642	1.0395	1.3272	.9995	
15	.9602	1.1736	1.3763	1.0814	
16		1.073	1.3435	1.065	
17			1.2742	1.2452	
18	1.0486		1.2071	1.1142	
19	1.1142		.8048	1.0978	
20	1.0814	.5441	.8048	.9831	
21	.9339	.9282	.7377	.8785	
22	.8192	.8453	.7377	.7545	
23	.7045	.7459	.57	.663	
24	.6133	.6718	.6962	.503	.6299
Max	1.1336	1.2071	1.3763	1.2452	1.1336
Min	.5765	.5441	.57	.503	.5801
Avg	.8350	.8547	.8962	.8525	.7917

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024037 / 33KV PACHMORI S/Si

Feeder No / Name : 202 / 11 kv Ugwa

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6335	.5847	.5792	.4694	.4572
2	.6335	.6201	.5611	.4534	.439
3	.6036	.5847	.567	.4694	.439
4	.6036	.6024	.5487	.4694	.439
5	.5792	.567	.543	.503	.4572
6	.6401	.6379	.5853	.503	.4755
7	.6447	.6201	.5973	.5197	.5121
8	.6068	.6836	.5784	.5365	.4961
9	.6344	.6485	.6173	.5533	.5201
10	.5668	.6036	.631	.5784	.3932
11	.547	.57	.631	.5434	.4588
12	.5636	.57	.5258	.5083	.5079
13	.5243	.5197	.5258		.5182
14	.5407	.57	.5493	.5609	
15	.5243	.503	.5493	.5784	.5344
16	.5571	.7042	.5493	.5609	.5182
17	.5959	.5182	.5365	.5609	
18	.8589	.7282	.7125	.7011	
19	.8413	.7796	.6964	.7362	
20	.8063	.7701	.7042	.7265	
21	.7186	.7059	.6478	.6516	
22	.7186	.724	.5197	.5304	
23	.6661	.5853	.503	.4706	
24	.6516	.6201	.5792	.4534	.4572
Max	.8589	.7796	.7125	.7362	.5344
Min	.5243	.503	.503	.4534	.3932
Avg	.6359	.6259	.5849	.5495	.4764

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024037 / 33KV PACHMORI S/Si

Feeder No / Name : 203 / 11 kv Gandhigram

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4557	.4557	.4207	.3688	.3898
2	.443	.4557	.4252	.3688	.3898
3	.443	.4382	.4075	.3688	.3721
4	.4298	.4382	.4119	.3688	.3721
5	.4298	.4207	.4298	.3688	.3721
6	.4706	.4908	.4163	.4024	.4298
7	.4854	.4908	.4557	.4024	.443
8	.503	.6135		.5365	.4287
9	.5967	.5609	.4862	.5365	.5197
10	.5898	.6036	.5847	.5959	.5243
11	.5571	.6036	.6024	.6661	.5506
12	.5571	.6036	.7888	.6661	.5243
13	.5571	.6371	.7537	.6836	.5441
14	.6154	.6371	.7186	.6836	.5182
15	.5898	.6706	.6135	.6836	.4858
16		.6802	.5784	.6661	1.3927
17	.6201	.6722	.6036	.6379	
18	.8589	.763	.6371	.691	
19	.7087	.7373	.5868	.6661	
20	.6201	.6415	.4858	.631	
21	.6024	.5847	.4024	.5784	
22	.5784	.5258	.3688	.4908	
23		.4908		.4075	
24	.4557	.4733	.4607	.3688	.4075
Max	.8589	.763	.7888	.691	1.3927
Min	.4298	.4207	.3688	.3688	.3721
Avg	.5531	.5704	.5290	.5349	.5097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024038 / 33 kV VIZORA

Feeder No / Name : 201 / 11 kv sarawa gavthan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2477	.2477	.1905	.2286
2	.2667	.2286	.2477	.1905	.2286
3	.2667	.2286	.2667	.1905	.2477
4	.2667	.2477	.2667	.1905	.2667
5	.3048	.2667	.2858	.2477	.2667
6	.3429	.3429	.2858	.3048	.2858
7	.4572	.4382	.4763	.381	.381
8	.5144	.4572	.5525	.3429	.4001
9	.4001	.362	.4001	.3048	.362
10	.5525	.4572	.4954	.3048	.2858
11	.6287	.724	.5335	.2858	.5906
12	.5335	.4954	.4763	.3048	.6097
13	.5525	.5144	.5335	.3239	.5144
14	.6097	.6287	.7049	.3239	.5716
15	.4954	.724	.5716	.362	.4954
16	.4191	.6287	.5716	.381	.6859
17	.6097	.4382	.4382	.3429	.362
18	.4763	.362	.5906	.4572	.4763
19	.4191	.362	.4001	.4572	.4191
20	.3429	.3048	.3429	.381	.4572
21	.3239	.3048	.3048	.2858	.381
22	.2858	.2858	.2477	.2667	.362
23	.2667	.2667	.2477	.2477	.2667
24	.2667	.2477	.2477	.2477	.2286
Max	.6287	.724	.7049	.4572	.6859
Min	.2667	.2286	.2477	.1905	.2286
Avg	.4112	.3985	.4057	.3048	.3906

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024038 / 33 kV VIZORA

Feeder No / Name : 202 / 11 kv eranda gavthan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2096	.2286	.2096	.2286
2	.2667	.2096	.2286	.2096	.2286
3	.2667	.2096	.2477	.2096	.2477
4	.2667	.2286	.2477	.2096	.2667
5	.2667	.2667	.2858	.2096	.2858
6	.2667	.3429	.3048	.3048	.3239
7	.3048	.381	.3429	.362	.4001
8	.3429	.362	.362	.3429	.381
9	.2667	.3239	.2858	.3048	.2858
10	.2477	.2667	.362	.2858	.2858
11	.2477	.3048	.3429	.2286	.3239
12	.2858	.3239	.2477	.2096	.1905
13	.2286	.3239	.2858	.2096	.3048
14	.2858	.2477	.2858	.2286	.3239
15	.1524	.2858	.2096	.2096	.3048
16	.3048	.2667	.1905	.2477	.1715
17	.2858	.3239	.2477	.1715	.2286
18	.3429	.3429	.3048	.2667	.3048
19	.3429	.3429	.3429	.3048	.3048
20	.2667	.2858	.2667	.2477	.2667
21	.2858	.2477	.2477	.2477	.2286
22	.2286	.2667	.2477	.2286	.2096
23	.2286	.2477	.2286	.2096	.2096
24	.2667	.2096	.2286	.2096	.2286
Max	.3429	.381	.362	.362	.4001
Min	.1524	.2096	.1905	.1715	.1715
Avg	.2715	.2842	.2739	.2445	.2723

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024038 / 33 kV VIZORA

Feeder No / Name : 203 / 11 kv katkeda ag
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193	1.4289	1.3527	.1334	.1524
2	1.1812	1.3908	1.3527	.1334	.1334
3	1.1812	1.3717	1.3908	.1334	.1334
4	1.2193	1.4098	1.3908	.1334	.1524
5	1.2574	1.4861	1.4289	.1334	.1524
6	1.3336	1.8861	1.448	.1334	.1524
7	1.7528	2.0576	1.9243	.1334	.1143
8	.0953	.0953	.0953	.9526	1.2574
9	.0953	.0953	.0762	2.2291	1.7718
10	.0953	.0762	.0762	2.0576	2.0957
11	.0953	.0762	.0953	2.3434	2.3053
12	.0953	.0572	.0953	2.21	2.3815
13	.0953	.0572	.0953	2.21	2.5149
14	.0762	.0572	.0953	2.3624	2.0576
15	.0762	.0762	.0953	2.3053	2.0576
16	.0953	.0762	.1143	.0953	.0762
17	.0953	.0762	.0953	.0762	.0762
18	.1143	.1143	.1143	.1143	.1524
19	.1143	.1143	.1143	.1334	.1524
20	.1334	.1143	.1143	.1334	.1905
21	.1334	.1143	.1334	.1334	.1715
22	1.3527	1.467	.1334	.1334	.1715
23	1.4861	1.5242	.1334	.1524	.1715
24	1.2193	1.4861	1.448	.1334	.1524
Max	1.7528	2.0576	1.9243	2.3624	2.5149
Min	.0762	.0572	.0762	.0762	.0762
Avg	.6089	.6962	.5589	.7796	.7811

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024051 / 33/11kv kanshivani

Feeder No / Name : 201 / 11kv Rahit Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17	13-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4973	.4801	.5304	.4287	.3944	
2	.4973	.4801	.5175	.4287	.3944	
3	.4801	.4801	.499	.4287	.4115	
4	.4801	.4801	.499	.4287	.4115	
5	.5144	.4801	.5175	.4458	.463	
6	.5487	.4801	.5487	.4801	.5144	
7	.583	.4801	.6099	.583	.5487	
8		.6516	.6556	.5316	.6173	
9	.6344	.6344	.6379	.6173	.6687	
10	.6697	.6001	.7682	.6344	.6516	
11	.6036	.5658	.6706	.6036		
12	.6733	.583	.6874	.7164		
13	.6201	.583	.5868	.6268	.5316	
14	.5784	.5487	.57	.6089	.583	
15	.6485	.583	.5533	.5304	.6001	
16	.5792	.583	.57	.5487	.5658	
17	.583	.6516	.6203	.5487	.5658	
18	.6687	.823	.7373	.6859	.7373	
19	.6687	.8131	.8059	.6859	.7545	
20	.6344	.7577	.703	.6344	.6859	
21	.583	.6283	.6173	.5144	.6001	
22	.5316	.5729	.5144	.4801		
23	.4801	.5544	.4458	.4287		
24	.4973	.4801	.5304	.4458	.3944	.3601
Max	.6733	.823	.8059	.7164	.7545	.3601
Min	.4801	.4801	.4458	.4287	.3944	.3601
Avg	.5763	.5823	.5998	.5444	.5547	.3601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024051 / 33/11kv kanshivani

Feeder No / Name : 202 / 11kv Rahit Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487				.6554
2	.5335				.6554
3	.5335				.6554
4	.5182				.6554
5	.5182				.6554
6	.503				.6554
7	.503				.6706
8		.5335	.6171		
9	.503	.7468	.6773		
10	.5418	.6401	.6472		
11	.5418	.5487	.6097		
12	.5268	.4725	.5639		
13	.5418	.5639	.5792		
14	.5213	.5639	.6097		
15	.6226	.5182	.6554		
22				.6554	
23				.6554	
24	.6401				.6554
Max	.6401	.7468	.6773	.6554	.6706
Min	.503	.4725	.5639	.6554	.6554
Avg	.5398	.5735	.6199	.6554	.6573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024051 / 33/11kv kanshivani

Feeder No / Name : 203 / 11kv Deoli AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.6371
2					.5792
3					.5487
4					.5487
5					.5487
6					.5335
7					.5182
8		.5335	.6859		
9	.7773	.6554	.6661		
10	.7011	.6401	.6622		
11	.7225	.6097	.6706		
12	.6093	.5944	.5792		
13	.6097	.5487	.5792		
14	.587	.5944	.5944		
15	.6171	.6097	.5944		
17	.4572				
18	.4572				
19	.4572				
22				.7316	
23				.7011	
24					.7209
Max	.7773	.6554	.6859	.7316	.7209
Min	.4572	.5335	.5792	.7011	.5182
Avg	.5996	.5982	.629	.7164	.5794

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024007 / 33 KV BALAPUR S/S

Feeder No / Name : 201 / 11 KV BALAPUR

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1395	1.1088	1.0349	.961	.8501
2	2.2458	1.1088	1.0349	.961	.8962
3	2.2458	1.1088	1.0349	.9979	.8871
4	2.2828	1.3306	1.1088	1.0082	.924
5	2.6109	1.4415	1.2567	1.1827	1.2936
6	2.9759	1.5893	1.5684	1.5154	1.5893
7	3.0266	1.8111	1.9044	1.5524	1.922
8	1.9589	1.6632	1.9044	1.7741	1.848
9	1.885	1.5154	1.8671	1.7372	1.7002
10	2.0328	1.4784	1.7551	1.6632	1.5524
11	1.9589	4.7992	1.5154	1.419	1.4784
12	1.9959	4.5725	4.2463	1.307	1.3676
13	1.885	4.2928	4.3682	1.2696	1.2936
14	1.1827	1.2936	1.307	1.1203	1.2567
15	1.2197	1.3306	1.1576	1.1576	1.2197
16	1.2567	1.3676	1.4937	1.1827	1.3676
17	1.5154	1.5524	1.4937	1.4045	1.5154
18	1.7002	2.1068	1.6804	1.8671	1.7741
19	1.7741	1.9959	1.9418	1.7372	1.848
20	1.7002	1.7372	1.643	1.4784	1.7002
21	1.4784	1.5893	1.419	1.3676	1.4415
22	1.4045	1.3306	1.2567	1.2382	1.848
23	1.1458	1.1827	1.0349	.8962	
24		1.0719	1.0719	.924	
Max	3.0266	4.7992	4.3682	1.8671	1.922
Min	1.1458	1.0719	1.0349	.8962	.8501
Avg	1.8966	1.8491	1.6708	1.3218	1.4352

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024007 / 33 KV BALAPUR S/S

Feeder No / Name : 202 / 11 KV PARAS

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8002	.759	.8539	.0633	.0949
2	.7682	.7907	.8539	.0633	.0949
3	.7682	.7907	.8539	.0633	.0949
4	.7682	.8223	.8539	.0633	.0949
5	.7682	.8223	.8855	.0633	.0949
6	.7682	.8223	.9488	.0633	.0949
7	.8962	.9488	1.1385	.0633	.0791
8	.0633	.0791	.0791	.7682	.8855
9	.0633	.0791	.0791	.9602	1.0753
10	.0633	.0791	.0791	1.3443	1.1385
11	.0949	.0633	.0633	1.1385	1.1069
12	.0791	.0633	.0633	1.0753	1.0753
13	.0791	.0633	.0633	1.0753	1.1385
14	.0633	.0633	.0633	1.0753	1.2018
15	.0633	.0791	.0633	1.0753	1.2018
16	.0633	.0633	.0633	.0949	.0633
17	.0791	.0791	.064	.0791	.0949
18	.0791	.0949	.064	.0949	.0949
19	.0949	.0949	.064	.096	.0791
20	.0949	.0949	.064	.0949	.0949
21	.1107	.0949	.064	.1107	.0949
22	.1107	.8223	.064	.112	.0791
23	.1107	.8223	.064	.0949	
24		.759	.8855	.064	
Max	.8962	.9488	1.1385	1.3443	1.2018
Min	.0633	.0633	.0633	.0633	.0633
Avg	.2978	.3855	.3475	.4082	.4579

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024007 / 33 KV BALAPUR S/S

Feeder No / Name : 204 / 11 KV PALASI GAUTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1132	.1132	.112	.0934
2	.1494	.1132	.1132	.112	.0934
3	.1494	.132	.1132	.112	.0934
4	.1494	.132	.1132	.112	.0934
5	.1307	.132	.1132	.112	.1307
6	.112	.132	.1132	.112	.1494
7	.168	.1698	.2075	.1494	.1867
8	.1867	.1698	.1886	.1494	.2241
9	.168	.1698	.1867	.1494	.2054
10	.168	.168	.1494	.1494	.1478
11	.128	.1494	.1494	.112	1.8111
12	.1463	.1494	.1307	.0934	.1478
13	.1097	.1494	.112	.112	.1478
14	.128	.1494	.1109	.112	.1294
15	.1097	.1307	.1109	.1307	.1494
16	.128	.112	.1307	.1307	.0914
17	.1097	.1509	.112	.1307	.1097
18	.1509	.1886	.2241	.2241	.1463
19	.2075	.2263	.2218	.1867	.1829
20	.1698	.1886	.2241	.1867	.1829
21	.1494	.1886	.1867	.1867	.1646
22	.1307	.1509	.1494	.1494	.12
23	.1132	.1132	.112	.112	
24		.1132	.1132	.112	
Max	.2075	.2263	.2241	.2241	1.8111
Min	.1097	.112	.1109	.0934	.0914
Avg	.1440	.1497	.1458	.1354	.2182

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024007 / 33 KV BALAPUR S/S

Feeder No / Name : 206 / 11 KV MANN EXPRESS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0191	.0191
2	.0191		.0191	.0191	.0191
3	.0191	.0191	.0191	.0191	.0191
4	.0191	.0191	.0191	.0191	.0191
5	.0191	.0191	.0191	.0191	.0191
6	.0191	.0191	.0191	.0191	.0191
7	.0191	.0191	.0191	.0191	.0191
8		.0191	.0191	.0191	.0191
9	.0492	.0492	.0492	.0492	.0497
10	.0492	.0497	.0328	.0492	.0497
11	.0497	.0497	.0492	.0497	.0497
12	.0497	.0497	.0191	.0497	.0497
13	.0497	.0497	.0191	.0497	.0497
14	.0497	.0492	.0191	.0497	.0492
15	.0191	.0191	.0191	.0191	.0497
16	.0497	.0497	.0492	.0492	.0492
17	.0497	.0497	.0492	.0492	.0492
18	.0497	.0497	.0492	.0492	.0492
19	.0486	.0497	.0492	.0492	.0492
20	.0486	.0497	.0492	.0492	.0492
21	.0486	.0497	.0492	.0492	.0492
22	.0191	.0191	.0492	.0191	.0474
23	.0191	.0191	.0191	.0191	
24		.0191	.0191	.0191	
Max	.0497	.0497	.0492	.0497	.0497
Min	.0191	.0191	.0191	.0191	.0191
Avg	.0356	.0350	.0310	.0342	.0383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024007 / 33 KV BALAPUR S/S

Feeder No / Name : 207 / 11 KV VYALLA AGRICULTURE
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.2972	.2439
2	.0191	.0191	.0191	.2972	.2439
3	.0191	.0191	.0191	.2972	.2439
4	.0191	.0191	.0191	.2972	.2439
5	.0191	.0191	.0191	.2972	
6	.0191	.0191	.0191	.2972	.2439
7	.0191	.0191	.0191	.3567	.3048
8	.3125	.3163	.3658	.0191	.0191
9	.4428	.4428	.4268	.0191	.0191
10	.4374	.506	.4877	.0191	.0191
11	.4428	.506	.4268	.0191	.0191
12	.4428	.506	.3749	.0191	.0191
13	.3795	.506	.3125	.0191	.0191
14	.506	.506	.3521	.0191	.0191
15	.4428	.506	.3841	.0191	.0191
16	.0191	.0191	.0191	.0191	.0191
17	.0191	.0191	.0191	.0191	.0191
18	.0191	.0191	.0191	.0191	.0191
19	.0191	.0191	.0191	.0191	.0191
20	.0191	.0191	.0191	.0191	.0191
21	.0191	.0191	.0191	.0191	.0191
22	.0191	.0191	.2972	.3048	.2378
23	.0191	.0191	.2972	.3048	
24		.0191	.0191	.2439	
Max	.506	.506	.4877	.3567	.3048
Min	.0191	.0191	.0191	.0191	.0191
Avg	.1606	.1709	.1664	.1359	.0966

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024007 / 33 KV BALAPUR S/S

Feeder No / Name : 208 / 11 KV PALASI AGRICULTURE
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0762	.3048	.5335
2	.0762	.0191	.0762	.3048	.5335
3	.0762	.0762	.0762	.3048	.4374
4	.0953	.0953	.0191	.3048	.4999
5	.0953	.0953		.3658	.5624
6	.0953	.0953	.0953	.3658	.6874
7	.1143	.0762	.1334	.4268	.8124
8	.5556	.6401	.5121	.1143	.1143
9	.9259	.9602	.5121	.1143	.1524
10	.9877	.9602	.8322	.1143	.0762
11	1.012	.8962	.8421	.1334	.0953
12	.8223	.8223	.8002	.1143	.1143
13	.8855	.8855	.7682	.0953	.0953
14	.9488	.8002	.759	.0953	.0762
15	.8223	.7682	.7682	.1307	.0762
16	.0572	.0762	.0572	.0953	.1143
17	.0762	.1143	.0953	.0762	.0953
18	.0953	.1143	.0953	.1143	.0953
19	.0953	.1143	.0953	.1143	.1143
20	.0953	.0953	.0953	.1143	.1143
21	.0953	.0953	.0762	.1334	.0953
22	.0762	.0953	.3048	.3704	.3704
23	.0762	.0762	.3048	.4321	
24		.0762	.0762	.4321	
Max	1.012	.9602	.8421	.4321	.8124
Min	.0572	.0191	.0191	.0762	.0762
Avg	.3590	.3385	.3248	.2155	.2666

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024007 / 33 KV BALAPUR S/S

Feeder No / Name : 209 / 11 KV BALAPUR AGRICULTURE FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1271	1.1603	1.0608	.0497	.0497
2	1.1271	1.1603	1.0608	.0497	.0497
3	1.1271	1.1603	1.0608	.0497	.0497
4	1.094	1.1603	1.0608	.0497	.0497
5	1.094	1.1934	1.0608	.0497	.0497
6	1.094	1.1934	1.1271	.0497	.0497
7	1.2266	1.442	1.3592	.0497	.0332
8	.0332		.0328	.9614	1.2266
9	.0332	.0497	.0328	1.4586	1.4586
10	.0332	.0332	.0328	1.5083	1.5912
11	.0332	.0332	.0492	1.5402	1.5581
12	.0332	.0332	.0492	1.5074	1.5249
13	.0332	.0332	.0492	1.4746	1.4918
14	.0332	.0332	.0497	1.3763	1.4586
15	.0332	.0332	.0497	1.5402	1.5249
16	.0332	.0332	.0492	.0332	.0332
17	.0332	.0332	.0497	.0332	.0332
18	.0497	.0497	.0497	.0497	.0497
19	.0497	.0497	.0497	.0492	.0497
20	.0497	.0497	.0497	.0497	.0497
21	.0497	.0497	.0497	.0497	.0497
22	.0497	1.0277	.0497	.0497	.0497
23	.0497	1.0277	.0497	.0497	
24		1.1603	1.094	.0497	
Max	1.2266	1.442	1.3592	1.5402	1.5912
Min	.0332	.0332	.0328	.0332	.0332
Avg	.3704	.5304	.4011	.5054	.5673

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024007 / 33 KV BALAPUR S/S

Feeder No / Name : 401 / 33KV Balapur/Wadegaon
Feeder KV- 33 / INCOMING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		3.2236	2.2805	5.5556	5.4081
2		3.2236	2.2805	6.1111	4.8388
3		3.2236	2.2805	6.3889	5.1235
4		3.546	2.2805	6.9445	5.7613
5		3.546	2.6063	6.9445	6.9136
6		3.546	2.963	7.668	
7	4.1461	4.2798	3.9095	9.7325	10.2469
8	9.7805	8.1482	9.1427	3.9506	4.2798
9	12.3045	11.166	11.797	3.6214	3.6214
10	12.4383	10.5316	10.3224	3.2922	2.963
11	9.8423		7.4589	2.3765	2.5514
12	9.2798			2.037	2.2325
13	9.2798			2.037	2.1605
14	9.2798	9.1084	8.8477	2.037	1.9136
15	8.7174	9.1084	8.8477	1.9342	
16	1.3889	3.3333	7.1331	1.9342	2.2085
17	2.524	2.524	2.5514	1.9342	2.8395
18	3.155	3.786	3.1893	3.8683	3.4705
19	4.1015	4.1015	4.1461	3.8683	4.465
20	3.8683	3.786	3.5082	3.5837	3.5082
21	3.4705	3.4705	3.1893	3.1893	3.5082
22	3.155	2.9012	4.1667	6.9136	7.4006
23	2.9012	2.5789	5	6.0494	
24		2.5789	2.2805	5.4733	
Max	12.4383	11.166	11.797	9.7325	10.2469
Min	1.3889	2.524	2.2805	1.9342	1.9136
Avg	6.4490	4.8434	5.0083	4.4769	4.2707

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024010 / 33 KV KARANJA RAMJANPUR

Feeder No / Name : 201 / 11 KV NIMBA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	.7545	.8916		.6859
2	.823	.8573	.8573		.6859
3	.823	.8573	.8573		.6859
4	.823	1.0288	.8573		.6859
5	.823	1.0288	.8916		.6859
6	.823	1.0631	.8916		.6859
7	.823	1.0974	.8573		.6859
8	.823	1.0974	1.0288		.8573
9	1.2003	1.7147	1.3717		1.0974
10		1.7833	1.7147		1.2346
11	1.7833	1.6461	1.7833	1.7147	1.7147
12	1.8519	1.8861		1.7147	1.8004
13	1.8519	1.8861		1.7147	1.7147
14	1.8519	1.7147		1.7147	1.7833
15	1.8519	1.6804		1.7147	1.7147
16	1.7147	1.5089		1.7147	1.5432
17	1.7147	1.8861		1.7147	1.3717
18	1.7147	1.7147		1.749	1.4575
19	1.6289	1.6461		1.7833	1.5432
20	1.4403	1.5432		1.5432	1.3375
21	1.286	1.2003		.9602	1.2003
22	1.0288	1.1145		.8916	.9945
23	.9431	.9602		.8916	.8573
24	.823	.7545	.8916		.6859
Max	1.8519	1.8861	1.7833	1.7833	1.8004
Min	.823	.7545	.8573	.8916	.6859
Avg	1.2726	1.3510	1.0745	1.5248	1.1546

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024010 / 33 KV KARANJA RAMJANPUR

Feeder No / Name : 202 / 11 KV KARANJA RAMJANPUR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5144	.6516		.5144
2	.5144	.6001	.6344		.5144
3	.5144	.6001	.6344		.5144
4	.5144	.6001	.6344		.5144
5	.5144	.6859	.6516		.5144
6	.5144	.6859	.6859		.5144
7	.5144	.6859	.6859		.5144
8	.5144	.6859	.6859		.6516
9	.8573	.9431	.8916		.7202
10	1.2003	1.3032	1.1145		.823
11	1.2346	1.2346	1.1145	1.0631	1.0631
12	1.166	1.2003		1.0631	.8916
13	1.166	1.1145		1.0974	.9945
14	1.166	1.2003		1.0974	1.0288
15	1.166	1.1145		1.0631	1.0288
16	1.0974	1.166		1.0288	
17	1.3717	1.0288		1.0288	
18	1.2346	1.0631		1.0288	.9945
19	1.0974	1.1145		1.0288	1.0288
20	1.0288	1.1145		.8573	.8916
21	.9431	.8573		.7888	.7716
22	.7545	.7202		.6173	.6516
23	.6859	.6859		.5144	.5658
24	.5144	.5144	.6516		.5144
Max	1.3717	1.3032	1.1145	1.0974	1.0631
Min	.5144	.5144	.6344	.5144	.5144
Avg	.8666	.8931	.7530	.9444	.7373

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024010 / 33 KV KARANJA RAMJANPUR

Feeder No / Name : 204 / 11 KV ANTARI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.7888	.6001		.6516
2	.6516	.7888	.6001		.6516
3	.6516	.7888	.583		.6516
4	.6516	.8573	.583		.6516
5	.6516	.8573	.6001		.6516
6	.6516	.8573	.6516		.6516
7	.6516	.9259	.6859		.6859
8	.7545	.9259	.6687		.7202
9	.9259	1.0288	.8573		.823
10	1.0288	1.1317	.7373		.8916
11	1.0631	.4973	.6859	.9602	.9431
12		1.0288		.9602	.9774
13		1.2517		.9602	1.0288
14		1.2689		.9602	1.1831
15		1.2517		.9602	1.0802
16		1.2689		.9602	1.1145
17	1.0974	1.0974		.9602	1.0288
18	1.286	.9431		.8916	1.0117
19	1.2003	.9088		.8916	1.0288
20	1.0974	.8573		.8573	.9602
21	.9431	.7716		.8573	.8745
22		.7202		.6859	.7888
23	.8573	.6516		.6516	.6859
24	.6516	.7888	.6001		.6516
Max	1.286	1.2689	.8573	.9602	1.1831
Min	.6516	.4973	.583	.6516	.6516
Avg	.8593	.9274	.6544	.8890	.8495

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024011 / 33 KV GAIGAON

Feeder No / Name : 201 / 11 KV NIMKARDA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8916	.6859	.5761		
2	.9191	.6584	.5761		
3	.9191	.6584	.5487		
4	.8916	.6584	.5487		
5	.8779	.6722	.5761		
6	.8642	.3681	.6036		
7	.8642	.727	.6859		
8					.6447
9				.7133	.6859
10				.7545	.7407
11				.7682	.6859
12				.7545	.6859
13				.7819	.6859
14				.7682	.7133
15				.823	.6859
22		.5761			
23		.5761			
24	.8916	.6859	.5761		
Max	.9191	.727	.6859	.823	.7407
Min	.8642	.3681	.5487	.7133	.6447
Avg	.8899	.6267	.5864	.7662	.6910

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024011 / 33 KV GAIGAON

Feeder No / Name : 202 / 11 KV IOC

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.1698		.1698
2	.1886	.1698	.1698	.1886	.1698
3	.1886	.1698	.1698	.1886	.1698
4	.1886	.1698	.1698	.2075	.1698
5	.1509	.1698	.1698	.2075	.1509
6	.1509	.1509	.132	.1698	.1509
7	.0754	.0754	.1132	.0754	.1132
8	.0754	.0943	.0754		.0754
9	.1132	.132	.0754	.1132	.1509
10	.2452	.3395	.0943	.1886	.2263
11	.3018	.3018	.0943	.2263	.2263
12	.3206	.3206	.0943	.1886	.2641
13	.1509	.132	.0943	.2263	.1132
14	.1698	.1509	.0754	.2641	.1509
15	.1509	.1886	.0943	.2452	.2263
16	.132	.1886	.1132	.2263	.2263
17	.1509	.3206	.1132	.0754	.1509
18	.2452	.2829	.1509	.1698	.2263
19	.1886	.2829	.2075	.1698	.2641
20	.2829	.2075	.1886	.0189	.2641
21	.3018	.2263	.1886	.1698	.1886
22	.3018	.1886	.2075	.1698	.1698
23	.2075	.1698	.1886	.1698	
24	.1886	.1886	.1698	.1886	.1698
Max	.3206	.3395	.2075	.2641	.2641
Min	.0754	.0754	.0754	.0189	.0754
Avg	.1941	.2004	.1383	.1749	.1821

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024011 / 33 KV GAIGAON

Feeder No / Name : 203 / 11 KV GAIGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2075	.1429
2				.1467	.1429
3				.141	.1572
4				.141	.1572
5				.1429	.1715
6				.1334	.1715
7				.1646	.1429
8	.192	.1429	.1738		
9	.1783	.1572	.1572		
10	.16	.1677	.1858		
11	.2378	.1829	.208		
12	.2378	.1524	.2		
13	.2229	.1981	.1858		
14	.2229	.2012	.2641		
15	.1907	.1981	.1858		
22			.1738	.1429	.1429
23			.1551	.1429	
24				.1509	.1429
Max	.2378	.2012	.2641	.2075	.1715
Min	.16	.1429	.1551	.1334	.1429
Avg	.2053	.1751	.1889	.1514	.1524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024011 / 33 KV GAIGAON

Feeder No / Name : 204 / 11 KV HATRUN FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.643	.6944
2				.6895	.6944
3				.6573	.7099
4				.6602	.7099
5				.6573	.6944
6				.6573	.6944
7				.6344	.6481
8	.9414	.8697	.7716		
9	.9374	.8796	.8025		
10	.9962	.9568	.9374		
11	1.0279	.9488	.9014		
12	1.012	.9488	1.0562		
13	.9962	.9646	.8333		
14	.9962	.9297	.823		
15	1.0242	.9145	.8796		
22			.7042	.6944	.7099
23			.7164	.7186	
24				.643	.6944
Max	1.0279	.9646	1.0562	.7186	.7099
Min	.9374	.8697	.7042	.6344	.6481
Avg	.9914	.9266	.8426	.6655	.6944

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024011 / 33 KV GAIGAON

Feeder No / Name : 205 / 11 KV NIMKARDA G

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0164	1.0164	.8871		.924
2	.9979	1.0534	.8871	.9425	.924
3	.9979	1.0534	.8501	.9425	.9055
4	1.0164	1.0719	.8501	.8871	.924
5	1.0719	1.0719	.924	.8501	.961
6	1.1273	1.1088	1.1088	1.0719	.9795
7	1.3121	1.2197	1.2567	1.2382	1.0164
8	1.0719	1.0534	1.0349		1.0164
9	1.0534	.8316	1.1088	1.0719	1.0164
10	.9979	.9055	.9795	.924	1.0719
11	1.0164	.8316	.924	.7762	1.0164
12	.9979	.7947	.8501	.6653	.924
13	.9795	.6653	.7577	.1478	.8871
14	.8501	.6468	.7762	.7392	.8316
15	.8316	.6653	.8131	.7392	.8316
16	.7947	.7023	.8686	.2587	.8316
17	.9055	.6653	.9425	1.0164	.9979
18	1.2752	1.386	1.2936	1.2936	1.2936
19	1.4415	1.3676	1.386	.2772	1.4045
20	1.3306	1.2382	1.2752	1.2012	1.2197
21	1.2197	1.1643	1.1643	1.0719	1.1088
22	1.1458	1.1088	1.0719	.961	1.0164
23	1.0164	1.0164	.9979	.8501	
24	1.0164	1.0164	.924	.924	.924
Max	1.4415	1.386	1.386	1.2936	1.4045
Min	.7947	.6468	.7577	.1478	.8316
Avg	1.0619	.9856	.9972	.8568	1.0011

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024025 / 33 KV WADEGAON S/SN

Feeder No / Name : 201 / 11 KV WADEGAON Ag
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3086	.3366
2				.3086	.3366
3				.3258	.3155
4				.3258	.362
5				.3601	.3801
6				.3944	.4525
7				.4801	.4668
8	.381	.4525	.3963		
9	.5487	.5639	.5335		
10	.6762	.6097	.5639		
11	.6135	.6554	.5658		
12	.6135	.5639	.5487		
13	.6348	.5639	.5658		
14	.6584	.583	.5316		
15	.6335	.6687	.583		
22			.3086	.3601	.3201
23			.3086	.3601	.3772
24				.3086	.3429
Max	.6762	.6687	.583	.4801	.4668
Min	.381	.4525	.3086	.3086	.3155
Avg	.5950	.5826	.4906	.3532	.3690

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024025 / 33 KV WADEGAON S/SN

Feeder No / Name : 202 / 11 KV TAMSHI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1791	.1829	.4287	.4334
2	.1829	.1595	.1524	.4115	.4525
3	.1677	.1595	.1524	.4115	.4835
4	.2743	.1646	.2134	.4287	.5068
5	.2896	.1463	.2743	.4287	.5258
6	.3201	.2195	.2591	.5144	.8402
7	.3048	.3292	.2591	.8573	1.086
8	.6249	.7421	.6706	.3086	.2743
9	.8383	.8535	.8688	.2572	.2378
10	1.0082	.7621	.7621	.2401	.1829
11	.6335	.7011	.5144	.1543	.1829
12	.8029	.7316	.7202	.12	.1219
13	.7655	.6554	.7202	.1029	.12
14	.7108	.7202	.6859	.12	
15	.8842	.8402	.7202	.12	.12
16	.1646	.1372	.1372	.1372	.1219
17	.1646	.1372	.1715	.1372	
18	.3086	.2743	.2743	.3086	.2896
19	.3658	.3048	.3429	.3772	.2896
20	.3012	.2591	.3429	.3258	.2286
21	.2534	.2896	.2915	.3109	.2286
22	.2896	.2286	.463	.6344	.6554
23	.2561	.2401	.4115	.5316	.5487
24		.2353	.1981	.4115	.463
Max	1.0082	.8535	.8688	.8573	1.086
Min	.1646	.1372	.1372	.1029	.12
Avg	.4389	.3946	.4079	.3366	.3815

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024025 / 33 KV WADEGAON S/SN

Feeder No / Name : 203 / 11KV BELURA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.3721	.3353	.6687	.8402
2	.3353	.3841	.2896	.6687	.7682
3	.4268	.3801	.3353	.6859	.7468
4	.442	.4207	.3963	.6859	.6697
5	.4877	.5041	.5944	.7373	.8764
6	.5182	.631	.6097	.8745	1.262
7	.503	.7682	.6097	1.1488	1.4937
8	.9602	.8682	.7621	.5487	.6516
9	1.2803	1.2193	1.2193	.5487	.5487
10	1.4706	.6097	1.1126	.3944	.3506
11	1.3443	1.1584	1.1145	.3258	.2134
12	1.2696	1.0212	1.0631	.2743	.2439
13	1.2696	.9907	1.0631	.2743	.2401
14	1.1568	1.1831	.9945	.2572	.2572
15	1.1163	1.2346	1.0802	.2915	.2572
16	.3544	.3048	.3429	.3086	.2743
17	.4294	.3201	.3429	.3429	
18	.6344	.6001	.5658	.583	.5792
19	.7133	.5639	.7545	.6344	.5487
20	.6697	.5335	.703	.6344	.5182
21	.5853	.5335	.5487	.6401	.4877
22	.5316	.4268	.6859	.8573	.7773
23	.4854	.4287	.6687	.8059	.8573
24	.4115	.4508	.4115	.6687	.7545
Max	1.4706	1.2346	1.2193	1.1488	1.4937
Min	.3353	.3048	.2896	.2572	.2134
Avg	.7401	.6628	.6918	.5775	.6181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024025 / 33 KV WADEGAON S/SN

Feeder No / Name : 204 / 11 KV WADEGAON Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.3544	.3048	.2915	.3258
2	.3201	.3292	.2896	.2915	.3109
3	.2896	.3292	.2743	.3086	.3077
4	.4877	.3224	.3658	.2915	.3734
5	.5792	.5316	.3963	.3086	.4938
6	.5944	.6584	.5639	.4115	.6722
7	.6401	.7619	.5944	.7202	.8029
8	.6249	.691	.6401	.6516	.7202
9	.5792	.4877	.6401	.6001	.7133
10	.7282	.5182	.5792	.4801	.4725
11	.5792	.5792	.583	.4458	.442
12	.5316	.7316	.5144	.3944	.3658
13	.5304	.381	.4458	.4287	
14	.439	.3944	.463	.3601	.4115
15	.4344	.3772	.4458	.3772	.4287
16	.4252	.381	.4458	.3944	.3506
17	.5138	.4268	.4801	.4115	
18	.7716	.7373	.703	.6516	.6554
19	.7499	.6249	.6859	.6173	.5944
20	.6584	.5335	.6516	.5487	.5335
21	.6024	.4725	.4801	.5304	.5182
22	.5304	.3963	.4115	.4287	.3658
23	.439	.3944	.3429	.3429	.3772
24	.3506	.3721	.3601	.3086	.3086
Max	.7716	.7619	.703	.7202	.8029
Min	.2896	.3224	.2743	.2915	.3077
Avg	.5306	.4911	.4859	.4415	.4793

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024057 / 33 KV KANHERI GAWALI

Feeder No / Name : 201 / 11 KV VYALA G

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4525	.4344	.5041	.4525	.3982
2	.3982	.3982	.499	.3982	.3801
3	.3801	.3982	.499	.3982	.3801
4	.3801	.3982	.4835	.3982	.3821
5	.3801	.4525	.4835	.362	.4525
6	.4887	.6335	.5249	.543	.5792
7	.6697	.6697	.6268	.5973	.6697
8	.5792	.5068	.6697	.5792	
9	.6154	.4887	.5373	.5973	.5973
10	.543	.4525	.5068	.543	.5544
11	.4706	.4481		.4887	.4854
12	.4525	.4108		.4525	.4294
13	.4163	.3696		.3982	.4066
14	.3982	.3734		.362	.3734
15	.3982	.4066		.362	.4294
16	.3982	.3921		.3982	.4435
17	.4163	.4294		.4344	.5415
18	.6878	.7468		.724	.7842
19	.724	.8316		.8145	.8589
20	.7059	.7468		.724	.7577
21	.6878	.5544		.5973	.6535
22	.6335	.5041		.5249	
23	.5611			.4525	
24	.4525	.4706	.5041	.4525	.3982
Max	.724	.8316	.6697	.8145	.8589
Min	.3801	.3696	.4835	.362	.3734
Avg	.5121	.5007	.5308	.5023	.5217

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024057 / 33 KV KANHERI GAWALI

Feeder No / Name : 203 / 11 KV DEGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0373	.0362	.9412	.905
2	.0373	.0373	.0362	.9412	.9412
3	.0373	.0373	.0358	.9412	.9412
4	.0373	.0373	.0358	.9412	.9593
5	.0373	.0373	.0351	.9955	.9774
6	.0373	.0373	.0351	1.086	.9955
7	.0373	.0373	.9536	1.1041	1.1946
8	1.0498	1.0498		.0543	.0373
9	1.2851	1.2127	1.1393	.0362	.0373
10	1.3032	1.3032	1.2178	.0362	.0373
11	1.3032	1.3256		.0362	.0373
12	1.3213	1.307		.0373	.056
13	1.3213	1.3817		.0373	.037
14	1.3394			.0374	.037
15	1.3756	1.2382		.0373	.0373
16	.1268	.1494		.1867	.1663
17	.1867	.2241		.2241	.2054
18	.2614	.1867		.2241	.2241
19	.2241	.2054		.2614	.2614
20	.2054	.2241		.2801	.2587
21	.2054	.0373		.2801	.2614
22	.2054	.037		.8402	
23	.2054			.8153	
24	.0373	.0373	.037	.9412	.905
Max	1.3756	1.3817	1.2178	1.1041	1.1946
Min	.0373	.037	.0351	.0362	.037
Avg	.5091	.4628	.3562	.4715	.4324

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024004 / 33 KV MAHAN S/S

Feeder No / Name : 201 / 11 KV WAGHA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.6859	.4115	.2058	.2058
2	.5144	.6859	.4115	.2058	.2058
3	.5144	.6859	.4458	.2058	.2058
4	.583	.6859	.4458	.2058	.2401
5	.6173	.7888	.5487	.2401	.2401
6	.6173	.823	.6859	.2743	.2743
7	.2058	.8916	.6173	.2743	.2743
8	.2058	.2058		.4801	.6859
9	.2058	.2058	.1715	.6859	.7545
10		.2058	.1372	.7545	.7545
11	.1372	.2058	.1372	.9602	.823
12	.1372	.1372	.1372	.823	.6859
13	.1372	.1372	.1372	.823	.6859
14	.1372	.1372	.1372	.7545	.7545
15	.1372	.2058	.1372	.7545	.6859
16	.1372	.1715	.1372	.1372	.1715
17	.2058	.3429	.2401	.2058	.1715
18	.2743	.3429	.3086	.2743	.3429
19	.4115	.3429	.3429	.3429	.3429
20	.3429	.3429	.3429	.3429	.3429
21	.3429	.3429	.3429	.3429	
22	.2743	.4115	.2743	.2743	
23	.2743	.4115	.2401	.2743	
24	.5487	.6173	.4115	.2058	.2058
Max	.6173	.8916	.6859	.9602	.823
Min	.1372	.1372	.1372	.1372	.1715
Avg	.3265	.4172	.3131	.4187	.4311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024004 / 33 KV MAHAN S/S

Feeder No / Name : 202 / 11 KV KOTHALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8745	.8573	.8573	.583	.5487
2	.8573	.8573	.8916	.583	.5144
3	.8573	.8573	.8916	.583	.5144
4	.9945	.8573	.8573	.583	.4801
5	1.1488	.8573	.9602	.6516	.6173
6	1.2517	1.1317	1.0631	.7545	.7716
7	1.3546	1.3717	1.3546	.8916	.7888
8	.6344	.6516	.7373	.9431	.7545
9	.6001	.5316	.5487	1.1488	.7888
10	.4458	.4115	.4973	1.1488	.583
11	.3944	.3772	.4115	.9945	.9259
12	.3429	.3258	.3601	.8916	.7888
13	.3601	.3429	.3258		.8916
14	.3601	.3429	.3429	.9431	.9602
15	.3429	.3601	.3601	1.0288	.9259
16	.3944	.3429	.3429	.3772	.3601
17	.4973	.5316	.4115		.4801
18	.7888	.9259	.8745		.9088
19	.9602	.9945	.9774	.4287	.9945
20	.9088	.9431	.8573	.7716	.8916
21	.8745	.7888	.7716	.7373	
22	.7888	.8745	.7202	.6516	
23	.7545	.8402	.6516	.6001	
24	.8745	.7888	.8573	.583	.5487
Max	1.3546	1.3717	1.3546	1.1488	.9945
Min	.3429	.3258	.3258	.3772	.3601
Avg	.7359	.7152	.7052	.7561	.7161

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024004 / 33 KV MAHAN S/S

Feeder No / Name : 203 / 11 KV MAHAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8402	.7716	.7545	1.2003	1.0802
2	.8059	.7716	.7373	1.2003	1.0288
3	.8059	.7716	.7373	1.2003	1.0288
4	.8573	.7716		1.2003	1.0117
5	.9259	.823	.8573	1.4403	
6	1.2003	1.1488	1.2346	1.5432	1.3032
7	1.6804	1.7147	1.7147	1.9033	
8	1.8861	1.1488	1.7661	1.5604	1.5089
9	2.3834	1.9204	2.1605	1.4403	1.3546
10	2.4177	2.2977	2.2977	1.1317	1.2346
11	2.452	2.2119	2.2805	.9088	.9945
12	2.1091	2.0233	2.0919	.8573	.9088
13	2.0576	1.9204	1.869		.7888
14	2.0233	1.8861	1.8004	.8059	.6344
15	1.9376	1.8861	1.8347	.7373	.6687
16	.9088	.9088	.9088	.8573	.8745
17	1.1317	1.2346	1.1488	.8745	1.0117
18	1.4918	1.4918	1.406	1.5775	1.4232
19	1.4746	1.5261	1.3717	1.5432	1.3889
20	1.2689	1.2346	1.2174	1.2003	1.2003
21	1.1831	1.0631	.9945	1.046	
22	.9774	.9088	1.2346	.9945	
23	.8745	.8573	1.2003	1.0974	
24	.8402	.7716	.7545	1.166	1.1145
Max	2.452	2.2977	2.2977	1.9033	1.5089
Min	.8059	.7716	.7373	.7373	.6344
Avg	1.4389	1.3360	1.4075	1.1951	1.0821

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024004 / 33 KV MAHAN S/S

Feeder No / Name : 204 / 11 KV Donod

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2401	.2401	1.0288	.9259
2	.2401	.2401	.2058	1.0288	.9259
3	.2058	.2401	.2058	1.0288	.8916
4	.2058	.2401	.2058	1.0288	1.4746
5	.2401	.2401	.2401	1.0288	.9602
6	.2743	.2743	.2743	1.0288	.9945
7	.2743	.3086	.3086	1.0288	1.0288
8	1.0974	.9259	.9259	.2401	.2058
9	1.3375	1.3717	1.3717	.2229	.1715
10	1.4746	1.3032	1.4746	.1372	.1372
11	1.4403	1.3032	1.3717	.1372	.1372
12	1.0631	1.2003	1.1317	.1372	.1029
13	1.2346	1.2003	1.2003	.1372	.1372
14	1.2003	1.166	1.2003	.1372	.1372
15	1.2003	1.166	1.166	.1029	.1543
16	.1372	.1372	.1372	.1372	.1372
17	.1715	.2058	.1543	.1372	.1715
18	.2743	.3086	.2743	.3086	.2743
19	.3429	.3772	.3429	.3429	.3429
20	.3429	.3429	.3086	.2058	.3086
21	.3429	.3086	.3086	.2401	
22	.2743	.2743	1.0631	1.0288	
23	.2743	.2401	1.0288	1.0288	
24	.2401	.2401	.2401	1.0288	.9431
Max	1.4746	1.3717	1.4746	1.0288	1.4746
Min	.1372	.1372	.1372	.1029	.1029
Avg	.5887	.5773	.6409	.5380	.5030

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024004 / 33 KV MAHAN S/S

Feeder No / Name : 401 / 33 KV Mahan Water Work NON SHEDDABLE WATER SUPPLY AND
 Feeder KV- 33 / OUTGOING UTILITY

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	1.0802	.9259	1.0288	1.0288
2	1.0288	1.0802	.9259	1.0288	1.0288
3	1.0288	1.0802	.9259	1.0288	1.0288
4	1.0288	1.0802	.9259	1.0288	1.0288
5	1.0288	1.0802	.9259	1.0288	1.0288
6	1.0288	1.0802	1.5432	1.1317	1.0288
7	1.5432	1.2346	1.5432	1.749	1.0288
8	1.5432	1.2346	1.5432	1.5947	1.3375
9	1.5432	1.2346	1.4403	1.6975	1.3375
10	1.5432	1.2346	1.3375	1.6461	1.5432
11	1.5432	1.2346	1.3375		1.6461
12	1.5432	1.2346	1.3375	1.6461	1.0802
13	1.5432	1.2346	1.749	1.6461	1.0802
14	1.2346	1.2346	1.8519	1.6461	1.0802
15	1.2346	1.2346	1.6461	1.6461	1.0802
16	1.2346	1.2346	1.4918	1.6461	.9774
17	1.2346	1.2346	1.5432	1.5432	.9259
18	1.2346	1.2346	1.4403	1.5432	1.1317
19	1.2346	1.0288	1.0802	1.3375	1.0288
20	1.2346	1.0288	1.0802	1.3375	1.0288
21	1.2346	1.0288	1.0802	1.3375	
22	1.2346	1.0288	1.0802	1.3375	
23	1.2346	.9259	1.0288	1.3375	
24	1.0288	1.2346	.9259	1.0288	1.0288
Max	1.5432	1.2346	1.8519	1.749	1.6461
Min	1.0288	.9259	.9259	1.0288	.9259
Avg	1.2646	1.1488	1.2796	1.3911	1.1194

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024005 / 33 KV PINJAR

Feeder No / Name : 201 / 11 KV PATUR-NANDAPUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.7373	.8962	.823	.9979
2	.7545	.7545	.8215	.823	.924
3	.7888	.7716	.8215	.8573	.7392
4	.7888	.7545	.8589	.8573	.7392
5	.823	.7545	.8589	.9259	.7577
6	.9088	.8402	.9709	.9945	.8501
7	1.0288	1.0117	1.1949	1.0974	1.2012
8	.8916	.961	1.1203	.7545	.8916
9	1.3717	1.4784	1.4937	1.2346	1.2003
10		1.7002	1.5684	1.3032	1.3889
11	1.2567	1.7924	1.3375	1.2174	1.5927
12	1.5524	1.1203	1.2346	1.2346	1.2308
13	.8871	1.3443	.7545	1.2003	.724
14	1.2936	1.6095	1.2346	1.286	1.2308
15	1.4045	1.3169	1.3717	1.1831	1.4118
16	1.7002	1.1203	1.4403	.9425	.9313
17	1.6263	1.7924	1.5775	1.4969	1.3032
18	1.7741	1.5364	1.6461	1.6632	1.5927
19	1.5893	1.4937	1.4403	1.6632	1.448
20	1.5524	1.419	1.3717	1.5708	1.3306
21	1.46	1.2696	1.2346	1.386	.788
22	1.3306	.9709	1.0288	1.2012	1.0136
23	1.1643	.9335	.9259	1.1273	.9313
24	.7545	.703	.8962	.823	1.0903
Max	1.7741	1.7924	1.6461	1.6632	1.5927
Min	.7545	.703	.7545	.7545	.724
Avg	1.1938	1.1744	1.1708	1.1528	1.0962

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024005 / 33 KV PINJAR

Feeder No / Name : 202 / 11 KV PINJAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5359	.5228	.3772	.3944
2	.5144	.5175	.5601	.3772	.3944
3	.5487	.5175	.5601	.4115	.3944
4	.5487	.499	.5975	.4115	.3772
5	.6173	.5175	.5975	.4458	.3944
6	.6859	.5914	.5975	.4801	.4801
7	.7888	.7577		.5487	.6001
8	.5144	.6173	.7316	.7202	.7207
9	.6173	.6687	.7682	.7202	.7023
10	.6173	.6173	.7095	.6173	.7207
11	.6173	.5975	.6001	.6283	.6447
12	.5487	.5914	.4801	.5544	.5731
13	.6001	.5544	.4115	.5359	.5014
14	.4973	.5121	.4115	.462	.4656
15	.5144	.4755	.4801	.462	.5014
16	.4435	.4854	.4458	.5544	.5731
17	.6283	.6348	.583	.6099	.6805
18	.8501	.8779	.7202	.8871	.788
19	.8316	.8048	.7202	.8871	.8238
20	.7947	.7842	.6687	.7392	.7164
21	.7207	.6722	.5487	.6653	.6089
22	.6653	.5487	.3772	.4287	.4298
23	.6099		.3772	.4115	.3582
24	.5144	.5544	.5228	.3086	.4115
Max	.8501	.8779	.7682	.8871	.8238
Min	.4435	.4755	.3772	.3086	.3582
Avg	.6168	.6058	.5649	.5518	.5523

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024005 / 33 KV PINJAR

Feeder No / Name : 204 / 11 KV MAHAGAON

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974	1.0631	.9259	.9602	.9602
2	1.0974	1.0974	.9602	.9602	.9602
3	1.166	1.0802	1.0117	.9945	.9259
4	1.166	1.0802	1.0802	.9945	.8916
5	1.2346	1.1145	1.1317	1.0631	.8916
6	1.406	1.3203	1.2003	1.1831	1.0117
7	1.6118	1.6461	1.5261	1.3717	1.3889
8	1.2689	1.1317	1.3546	1.2517	1.3546
9	1.869	1.4575	1.869	1.6461	1.5775
10	1.7661	1.7147	1.4746	1.8861	1.8004
11	1.8004	1.7737	1.869	1.5775	
12	1.7318	1.6617	1.9547	1.6118	
13	1.6461	1.6461	1.7661	1.406	
14	1.5775	2.1285	1.7147	1.4232	
15	1.0631	1.7833	1.7147	.8402	
16	1.1827	1.7558	.9431	.9795	
17	1.5524	1.423	1.3203	1.4969	
18	1.6448	1.5432	1.5089	1.6448	
19	1.5893	1.3889	1.4403	1.5154	
20	1.46	1.3203	1.3032	1.0164	
21	1.386	1.1831	.8916	1.1273	
22	.9795	1.0631	1.0288	1.0802	
23	.961	1.0288	.9945	1.0288	
24	1.0974	1.0631	.9259	.9602	.9774
Max	1.869	2.1285	1.9547	1.8861	1.8004
Min	.961	1.0288	.8916	.8402	.8916
Avg	1.3898	1.3945	1.3296	1.2508	1.1582

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024005 / 33 KV PINJAR

Feeder No / Name : 205 / 11 KV BAHIRKHED

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17	14-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	.9602	.9602	.823	.8501	
2	.9431	.9945	.9945	.823	.8501	
3	.9945	.9945	1.0288	.8573	.8316	
4	.9945	.9774	1.0631	.8573	.8131	
5	1.0631	1.0117	1.166	.8916	.8316	
6	1.2346	1.1488	1.166	.9602	.8871	
7	1.3889	1.3546	1.286	1.0631	1.1458	
8	.9945	.961	.9774	1.1145	1.1145	
9	1.0117	1.0534	1.1145	1.4575	1.4746	
10	.7202	1.2012	1.1488	1.6461	1.6289	
11	1.1827	.5304	1.1145	1.6289		1.0631
12	1.0534	1.0642	1.1145	1.4918		1.1145
13	.9795	1.2136	.6001	1.406		.9431
14	1.0164	1.1389	1.1317	1.3203		.9774
15	1.0349	1.0631	1.046	1.3375		.9774
16	1.1643	1.0631	1.0802	.6099		1.046
17	1.1458	1.0117	1.0802	1.1458		1.0802
18	1.386	1.2003	1.3546	1.3676		1.2346
19	1.4045	1.0117	1.286	1.4045		1.1488
20	1.3121	.9945	1.0974	1.2567		1.2003
21	1.2012	.9945	1.0288	1.1827		.9774
22	1.1273	.9259	.8745	.961		.9088
23	1.0349	.8916	.8573	.8686		.8402
24	.9431	.9602	.8573	.823	.8686	
Max	1.4045	1.3546	1.3546	1.6461	1.6289	1.2346
Min	.7202	.5304	.6001	.6099	.8131	.8402
Avg	1.0948	1.0300	1.0595	1.1374	1.0269	1.0394

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024005 / 33 KV PINJAR

Feeder No / Name : 206 / 11 KV GHOTA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8745	.8686	1.0456	.9259	1.0631
2	.8745	.8501	.9259	.9259	1.046
3	.8745	.8501	.8573	.9602	
4	.9088	.8316	.823	.9602	1.0288
5	.9088	.8501	.8059	.9945	1.046
6	.9431	.9425	.7888	1.1145	1.0802
7	.9945	1.0719	.9774	1.3546	1.286
8	1.1145	1.1317	1.0974	.823	.9979
9	1.5261	1.5261	1.6804	.9945	1.1827
10	1.7661	1.9204	2.0062	.9088	.8316
11	1.8519	1.8004	1.8861	.8316	
12	1.749	1.9204	1.8519	.961	
13	1.5775	1.9033	1.6118	1.0349	
14	1.6461	1.8484	1.749	1.0164	
15	1.6461	1.7924		1.1458	
16	.7577	.6687		1.2197	
17	1.0349	.8573	1.0802		
18	1.386	1.0117	1.286	1.46	
19	1.386	1.2346	1.2346	1.5154	
20	1.3306	1.2003	1.1317	1.3306	
21	1.3306	1.2346	1.0288	1.1458	
22	1.2382	1.0288	.9602	1.0802	
23	1.0534	1.0288	.9431	1.0631	
24	.8745	.924	.9945	.9259	1.046
Max	1.8519	1.9204	2.0062	1.5154	1.286
Min	.7577	.6687	.7888	.823	.8316
Avg	1.2353	1.2207	1.2166	1.0736	1.0608

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024006 / 33 KV BARSHI TAKLI S/S

Feeder No / Name : 201 / 11 KV KANHERI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17	14-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1296			.5182	.5441
2	.1134			.4858	.5441
3	.1134			.4534	.5121
4	.1134			.4534	.4801
5	.1296			.4049	.5121
6	.1296			.4049	.5121
7	.1296			.4696	.5121
8				1.4899	1.4403
9				1.4899	1.5684
10	.7287			1.8785	1.6484
11	.8421			1.9919	1.7284
12		.8097	1.9271		
13		.8097	1.8623		
14		.7773	1.8785		
15		.7611			
16			.0162		
17		.0189	.0324		
18		.0189	.0324		
19		.0189	.0324		
20		.0189			
21		.0189	.5344		
22		.5079	.5344		
23		.502	.5668		
24	.1296		.5373	.5668	.5441
Max	.8421	.8097	1.9271	1.9919	1.7284
Min	.1134	.0189	.0162	.4049	.4801
Avg	.2559	.3875	.7231	.8839	.8789

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024006 / 33 KV BARSHI TAKLI S/S

Feeder No / Name : 202 / 11 KV DHABA BT

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	09-DEC-17	11-DEC-17	12-DEC-17	14-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263			.1619
2	.2263			.1619
3	.2263			.1619
4	.2263			.1619
5	.1943			.1619
6	.1619			.1619
7	.1619			.1619
8			.1457	
9			.1781	
10			.2267	
11			.2429	
12		.2267		
13		.2429		
14		.2429		
15		.2267		
23	.1619			
24	.2263			.1619
Max	.2263	.2429	.2429	.1619
Min	.1619	.2267	.1457	.1619
Avg	.2013	.2348	.1984	.1619

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024006 / 33 KV BARSHI TAKLI S/S

Feeder No / Name : 203 / 11 KV REDWA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17	14-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7125			.0162	.016
2	.7125			.0162	.016
3	.7125			.0162	.016
4	.7125			.0162	.016
5	.7611			.0162	.016
6	.8421			.0162	.016
7	.8907			.0162	.016
8	.0162			.6802	.6401
9	.0162			.6802	.7682
10	.0162			.8421	.8962
11	.0162			1.1174	.8482
12		.0189	.8745		
13		.0189	.9717		
14		.0189	1.0688		
15		.0189	.9717		
16		.0189	.0162		
17		.0189	.0162		
18		.0189	.0162		
19		.0189	.0162		
20		.0189	.0162		
21		.0189	.0162		
22		.0189	.0162		
23		.0189			
24	.6964		.0189	.0162	.016
Max	.8907	.0189	1.0688	1.1174	.8962
Min	.0162	.0189	.0162	.0162	.016
Avg	.5088	.0189	.3349	.2875	.2734

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024006 / 33 KV BARSHI TAKLI S/S

Feeder No / Name : 204 / 11 kv Industrial

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17	14-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0185			1.0374	.9431
2	1.0185			1.0374	.9808
3	.9431			1.0374	.9808
4	.9431			1.094	.8488
5	1.1128			1.094	1.0374
6	1.2637			1.1317	1.0751
7	.9808			1.1883	1.0751
8	1.1317			.7356	.9431
9	1.2449			.7356	1.3769
10	1.2826			1.0374	1.4335
11	1.3392			1.2637	1.4712
12		1.1088	1.2449		
13		.9335	.9431		
14		.8326	.7922		
15		.8501	.8488		
16		.8413	.9242		
17		.8326	.9808		
18		.8962	1.0374		
19		.8688	1.0374		
20		.9335	1.0374		
21		.9335	1.0374		
22		.9511	1.0185		
23		.9709	1.0374		
24	.7733		.961	1.0374	.8488
Max	1.3392	1.1088	1.2449	1.2637	1.4712
Min	.7733	.8326	.7922	.7356	.8488
Avg	1.0877	.9127	.9923	1.0358	1.0846

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024006 / 33 KV BARSHI TAKLI S/S

Feeder No / Name : 205 / 11 kv Dagadparwa Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17	14-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886			.112	.2075
2	.1886			.112	.1886
3	.1886			.112	.1886
4	.1886			.1494	.1886
5	.2263			.1867	.1886
6	.2829			.2801	.2263
7	.3018			.3174	.2829
8	.2641			.2241	.2263
9	.2263			.2241	.2829
10	.1509	.1991		.1867	.1886
11		.1448		.168	.1698
12		.1109	.112		
13		.1086	.0934		
14		.0905	.0934		
15		.0905	.1307		
16		.1086	.1494		
17		.1448	.2241		
18		.2172	.2614		
19		.2534	.2801		
20		.2534	.2241		
21		.2172	.2241		
22		.2172	.2054		
23		.181	.168		
24	.2075		.181	.1307	.2075
Max	.3018	.2534	.2801	.3174	.2829
Min	.1509	.0905	.0934	.112	.1698
Avg	.2195	.1669	.1805	.1836	.2122

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024006 / 33 KV BARSHI TAKLI S/S

Feeder No / Name : 206 / 11 kv Barshitakali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17	14-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	1.094			1.0829	1.1317
2		1.0751			1.0269	1.0374
3		1.0374			.9709	1.0374
4		1.0374			1.2696	1.094
5					1.4937	1.4146
6		1.8484			1.8298	1.7918
7		2.0182			2.0911	2.0182
8		1.8484			1.7924	1.8484
9		1.7353			1.7924	1.7541
10		1.5089			1.6804	1.8107
11		1.5089			1.643	1.5655
12		1.358	1.2955	1.363		
13			1.1469	1.2696		
14			.9717	.9709		
15			.8745			
16			.9717	1.3443		
17			1.1336	1.8298		
18			1.4575	1.9044		
19			1.6194	1.9044		
20			1.6194	1.4937		
21			1.2955	1.2696		
22			1.1469	1.2136		
23			.9831	1.1576		
24		1.1128		.8421	1.1203	1.1694
Max	.9431	2.0182	1.6194	1.9044	2.0911	2.0182
Min	.9431	1.0374	.8745	.8421	.9709	1.0374
Avg	.9431	1.4319	1.2096	1.3803	1.4828	1.4728

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024028 / 33 KV DHABA

Feeder No / Name : 201 / 11 KV DHABA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.0857	.0686	.0857	.0857
2	.1029	.0686	.0686	.0857	.0857
3	.1029	.0686	.0686	.0857	.0857
4	.1029	.0686	.12	.12	.0857
5	.12	.1029	.12	.12	.1029
6	.1372	.1372	.1543	.12	.12
7	.1543	.1543	.1372	.1372	.1543
8	.1372	.0857	.1372	.1372	.1372
9	.0514	.0857	.1029	.1029	.1029
10	.0514	.0686	.0686	.0686	.0686
11	.0686	.0732	.0686	.0514	.0686
12	.0686	.0732	.0857	.0514	.0686
13	.0686	.0732	.0857	.0514	.0686
14	.0686	.0732	.0857	.0514	
15	.0686	.0732	.0686	.0686	
16	.0857	.0514	.0857	.0514	.0686
17	.0686	.1029	.1029	.0857	.0857
18	.1372	.1372	.1715	.1372	.1372
19	.1543	.1543	.1372	.1372	.1543
20	.1372	.1372	.1372	.12	.1029
21	.1372	.1372	.1372	.12	.1029
22	.12	.1372	.1029	.1029	.0857
23	.1029	.12	.0857	.1029	.0857
24	.1029	.0857	.1029	.0857	.0857
Max	.1543	.1543	.1715	.1372	.1543
Min	.0514	.0514	.0686	.0514	.0686
Avg	.1022	.0981	.1043	.0950	.0974

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024028 / 33 KV DHABA

Feeder No / Name : 202 / 11 KV PUNOTI GAOTHAN NEW

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1543	.1543	.1372	.1543
2	.1543	.1372	.12	.1372	.1543
3	.1543	.1372	.12	.1372	.1543
4	.1543	.1372	.1372	.1372	.1715
5	.1715	.1543	.1715	.1715	.1886
6	.2058	.1715	.2058	.1715	.2058
7	.2401	.2058	.2058	.2058	.2229
8	.2058	.2058	.2229	.2058	.1715
9	.1886	.1715	.1886	.2058	.1715
10	.1372	.1715	.1715	.1543	.1715
11	.1372	.1494	.1543	.12	.1543
12	.1372	.1494	.1372	.1029	.1372
13	.1029	.112		.0857	.1029
14	.0857	.112	.12	.1029	
15	.0857	.112	.1372	.0857	
16	.12	.1372	.12	.0686	.1029
17	.12	.1715	.1543	.1372	.12
18	.2401	.2058	.2401	.2058	.2229
19	.2572	.2572	.2401	.2743	.2401
20	.2743	.2401	.2401	.2401	.2401
21	.2229	.2229	.2058	.2229	.2058
22	.1886	.1886	.1715	.1715	.1715
23	.1715	.1715	.1543	.1543	.1543
24	.1543	.1543	.1543	.1372	.1543
Max	.2743	.2572	.2401	.2743	.2401
Min	.0857	.112	.12	.0686	.1029
Avg	.1693	.1679	.1707	.1572	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024028 / 33 KV DHABA

Feeder No / Name : 203 / 11KV NIMBI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0305	.0486
2				.0305	.0486
3				.0305	.0486
4				.0305	.0486
5				.0457	.0486
6				.0457	.0648
7				.0457	.1029
8	.0648	.0457	.0457		
9	.1134	.061	.0457		
10	.1134	.0914	.061		
11	.0762	.0914	.0648		
12	.0762	.0762	.081		
13	.0762	.0762	.0648		
14	.0457	.0762	.0486		
15	.0457	.061	.0486		
22			.0305	.0486	.0457
23			.0305	.0486	.0457
24				.0305	
Max	.1134	.0914	.081	.0486	.1029
Min	.0457	.0457	.0305	.0305	.0457
Avg	.0765	.0724	.0521	.0387	.0558

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024028 / 33 KV DHABA

Feeder No / Name : 204 / 11 KV DHABA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3944	.381	.3963		
2	.3725	.3658	.3963		
3	.421	.3658	.4268		
4	.4049	.3963	.5487		
5	.421	.4268	.6097		
6	.4534	.4572	.7316		
7	.583	.8535	.7164		
8				.4725	
9				.7316	
10				.7773	
11				.6249	.4115
12				.6554	
13				.7011	
14				.6097	
15				.6706	
17					.6097
22		.3506			
23		.3658			
24	.3563	.3963	.3963		
Max	.583	.8535	.7316	.7773	.6097
Min	.3563	.3506	.3963	.4725	.4115
Avg	.4258	.4359	.5278	.6554	.5106

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024019 / 33 KV DURGAWADA SUB-STATION

Feeder No / Name : 201 / 11 KV KOLSARA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0285	.8676	1.0785	.9945	1.0185
2	1.0285	.8676	1.0413	.9602	.9808
3	.9764	.8299	1.0413	.9602	.9808
4	.9764	.7922	1.0041	.9602	.9431
5	.9297	.7922	.9855	.8573	.9054
6	.9297	.7356	.9483	.8573	.8402
7	.9111	.8676	.8962	.6859	.9431
8	1.0317		1.2322	.7716	1.0185
9	1.1355	1.4712	1.3395	1.1145	1.3203
10	1.5477	1.5796	1.406	1.3717	1.6598
11	1.8858	1.6525	1.406	1.587	1.5775
12	1.6991	1.6118	1.406	1.5844	1.5947
13	1.6804	1.6118	1.4403	1.6032	1.5432
14	1.6244	1.5967	1.4746	1.5844	1.5432
15	1.6057	1.5638	1.4403	1.5278	1.5089
16	.9522	1.4686	1.4232	1.5466	1.3717
17	1.2323	1.4866	1.4403	1.5278	1.3546
18	1.7364	1.6023	1.3375	1.5844	1.3717
19	1.9427	1.7366	1.3032	1.6221	1.3717
20	1.6409	1.5867	1.2346	1.4712	1.3546
21	1.6032	1.3702	1.1831	1.3203	1.2003
22	1.0185	1.2076	1.0288	1.2071	1.0631
23	.9431	1.1238	1.0288	1.1317	
24	1.0442	.9054	1.1238	1.0288	1.0185
Max	1.9427	1.7366	1.4746	1.6221	1.6598
Min	.9111	.7356	.8962	.6859	.8402
Avg	1.2960	1.2751	1.2185	1.2442	1.2384

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024019 / 33 KV DURGAWADA SUB-STATION

Feeder No / Name : 202 / 11 KV BHATORI FEEDER
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1816	1.2449	1.2829	1.2003	1.094
2	1.1478	1.2449	1.2489	1.1488	1.0562
3	1.1647	1.2449	1.2837	1.1145	1.0562
4	1.1606	1.226	1.2309	1.1145	1.0562
5	1.1606	1.226	1.2296	1.0802	1.0374
6	1.1607	1.2071	1.2217	1.0288	1.0185
7	1.1375	1.1883	1.0894	.9259	.9808
8	1.2072	1.3957	1.2322	1.0288	1.0374
9	1.3498	1.5466	1.3963	1.3546	1.2826
10	1.5473	1.4455	1.5432	1.406	1.6598
11	1.7924	1.4615	1.6118	1.7737	1.5089
12	1.7551	1.5967	1.6289	1.7541	1.4918
13	1.6991	1.644	1.6461	1.7164	1.5432
14	1.6991	1.6118	1.6804	1.8107	1.5947
15	1.6057	1.5976	1.7147	1.8484	1.6289
16	1.6057	1.4937	1.5775	1.7918	1.5775
17	1.643	1.568	1.749	1.6975	1.5432
18	1.9044	1.615	1.8519	1.9993	1.5775
19	2.0936	1.6757	1.6804	2.0559	1.6118
20	1.8861	1.5967	1.3717	1.8861	1.6975
21	1.7164	1.5344	1.3546	1.6787	1.5432
22	1.5278	1.401	1.3375	1.3203	1.3717
23	1.358	1.3719	1.2003	1.1694	
24	1.2309	1.2826	1.3185	1.2003	1.1317
Max	2.0936	1.6757	1.8519	2.0559	1.6975
Min	1.1375	1.1883	1.0894	.9259	.9808
Avg	1.4890	1.4342	1.4368	1.4627	1.3522

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024019 / 33 KV DURGAWADA SUB-STATION

Feeder No / Name : 203 / 11 KV JAMBHA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17
HR	Load (MW)
19	1.8484
Max	1.8484
Min	1.8484
Avg	1.8484

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024019 / 33 KV DURGAWADA SUB-STATION

Feeder No / Name : 204 / 11 KV POHI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	12-DEC-17
HR	Load (MW)
6	.1509
Max	.1509
Min	.1509
Avg	.1509

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024020 / 33KV S/S MANA

Feeder No / Name : 201 / 11 KV MANA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4954	.5144	.4115	.4763
2	.5144	.4954	.4973	.4115	.4382
3	.5144	.4954	.4973	.4115	.4382
4	.5144	.4954	.4801	.4115	.4572
5	.6001	.4763	.4801		.4763
6	.6001	.7621	.5316	.6516	.5716
7	.6687	.7621	.6516	.6687	.724
8	.8402	.8002	.7545	.7373	.8002
9	1.0288	.9431	.9259	.823	1.105
10		.9945	.9945	1.0802	1.1431
11				.9088	1.0669
12				.9774	.9335
13	1.1812			.8916	1.0098
14	1.1812	1.0631	1.0802	.8916	.8954
15	1.105	.9602	.9088	.9088	.8192
16	1.105	.9602	1.0117	1.0117	.9717
17	1.105	1.1145	1.0631		1.0479
18	1.1241	1.1317	1.0974	1.0974	1.3336
19	1.086	1.0631	1.0288	1.0117	1.1812
20	.9145		.8745	.8745	
21	.8192		.7202	.6687	
22	.743	.6344	.583	.5316	
23	.6478	.5487	.4973	.5144	
24	.6001	.5525	.5144	.4287	.4763
Max	1.1812	1.1317	1.0974	1.0974	1.3336
Min	.5144	.4763	.4801	.4115	.4382
Avg	.8447	.7762	.7479	.7420	.8183

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024020 / 33KV S/S MANA

Feeder No / Name : 202 / 11 KV KURUM AG FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0953	.0857	1.0288	1.5432
2	.0686	.0953	.0857	1.0288	1.4289
3	.0686	.0953	.0857	1.0631	1.4289
4	.0686	.0953	.0857	1.0288	1.448
5	.0686	.0953	.0857	1.2346	1.5242
6	.0686	.0953	.0857	1.3203	1.7909
7	.0686	.0953	.0686	1.406	1.6194
8	1.5432	1.6575	1.6289	.0686	.0762
9	2.2805	1.9376	2.0919	.0686	.0572
10	2.553	1.8347	2.8807	.0686	.0762
11	2.4768	1.7833	3.0178	.0514	.0572
12	2.0386	1.8347	2.9664	.0514	
13	1.829	1.7661	2.5377	.0514	
14	1.829	1.6804	1.4918	.0514	
15	1.8099	1.7661	2.5377	.0514	
16	.0762	.0686	.0686	.0514	
17	.0762	.0514	.0514	.0514	
18	.0762	.0686	.0686	.0686	
19	.0953	.0686	.0686	.0686	
20	.0953		.0686	.0762	
21	.0953		.0686	.0762	
22	.0953	.0857	1.1145	1.6194	
23	.0953	.0857	1.2174	1.6385	
24	.0686	.0953	.0857	1.2346	1.6385
Max	2.553	1.9376	3.0178	1.6385	1.7909
Min	.0686	.0514	.0514	.0514	.0572
Avg	.7339	.7023	.9395	.5608	1.0574

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024020 / 33KV S/S MANA

Feeder No / Name : 203 / 11 KV JAMATHI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.4572	.3601	.0343	.0572
2	.3086	.4572	.3601	.0343	.0572
3	.3086	.4572	.3429	.0343	.0762
4	.3086	.4572	.4287	.0343	.0762
5	.3429	.4763	.463	.0343	
6	.4287	.7621	.5144	.0343	.0572
7	.4287	.7621	.5487	.0343	.0572
8	.0171	.0381	.0343	.463	
9	.0343	.0343	.0343	.7888	
10	.0381	.0343	.0343	.7888	
11	.0381	.0343	.0343	.6687	
12		.0343	.0343	.6859	
13		.0343	.0343	.583	.0762
14		.0343	.0343	.6516	.0762
15	.0381	.0343	.0343	.5487	1.1241
16	.0381	.0343	.0343	.0343	.0762
17	.0191	.0343	.0343	.0514	.0381
18	.0381	.0514	.0514	.0686	.0381
19	.0381	.0514	.0514		.0381
20	.0572		.0514	.0572	
21	.0381			.0572	
22	.0572	.3258	.0343	.0572	
23	.0572	.3944	.0343	.0572	
24	.3258	.4572	.3601	.0343	.0572
Max	.4287	.7621	.5487	.7888	1.1241
Min	.0171	.0343	.0343	.0343	.0381
Avg	.1557	.2480	.1715	.2537	.1361

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024020 / 33KV S/S MANA

Feeder No / Name : 204 / 11 KV NAWASAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.7621	.6344	.463	.6478
2	.6173	.7621	.583	.4801	.6097
3	.6173	.7621	.583	.4801	.6097
4	.6173	.7621	.6001	.4801	.6287
5	.6516	.724	.6344	.5144	.6097
6	.6859	.9145	.6859	.5487	.8002
7	.7716	.9145	.8402	.703	.9335
8	.8402	.9145	1.0631	.823	.9335
9	1.0802	1.0117	.9774	.9088	1.1241
10	1.2003	.9259	.9945	1.0288	1.3908
11	1.3146	1.0288	1.166	.9774	1.2003
12	1.105	1.1145	1.166	1.0288	1.0479
13			.9602	.9088	1.0288
14				.8573	.9907
15			1.046	.7716	.9717
16	.9526	.9088	.9259	.7888	.8954
17	1.105	1.166	.9945	.8573	.8954
18	1.2765	1.1831	1.0974	.9259	.9717
19	1.3146	1.1317	1.0631	1.1241	1.2003
20	1.1241		.823	.9526	1.2193
21	1.0669		.7373	.8954	
22	.9335	.823	.6687	.8002	
23	.9145	.703	.5487	.6668	
24	.6859	.8192	.6516	.463	.6668
Max	1.3146	1.1831	1.166	1.1241	1.3908
Min	.6173	.703	.5487	.463	.6097
Avg	.9282	.9122	.8454	.7687	.9227

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024020 / 33KV S/S MANA

Feeder No / Name : 205 / 11 KV RAJURA GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1334	.1372	.1029	.1715
2	.12	.1334	.12	.1029	.1524
3	.12	.1334	.12	.1029	.1524
4	.12	.1334	.12	.1029	.1524
5	.12	.1334	.12	.12	.1715
6	.1372	.1715	.1372	.12	.1715
7	.12	.1715	.1372	.12	.1524
8	.12	.1524	.1372	.12	.1334
9	.1524	.12	.1029	.1029	.1143
10	.1334	.0686	.12	.0857	.0953
11	.0953	.0686	.0857	.0857	.1143
12	.0953	.0686	.0857	.0686	.0191
13	.0762	.0686	.0857	.0686	.0953
14	.0762	.0857	.0686	.0686	.0953
15	.0953	.0686	.0686		.1143
16	.0762	.0686	.0686		.1143
17	.0953	.1029	.0857		.0953
18	.0953	.2058	.1543	.2572	.2667
19	.2667	.2401	.2401	.2743	.3429
20	.2477	.2401	.2058	.2858	
21	.2096		.1715	.2477	
22	.1715	.1543	.1372	.2096	
23	.1524	.1372	.1029	.1715	
24	.1372	.1334	.1372	.1029	.1715
Max	.2667	.2401	.2401	.2858	.3429
Min	.0762	.0686	.0686	.0686	.0191
Avg	.1314	.1302	.1229	.1391	.1448

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024026 / 33 KV MORAMBA

Feeder No / Name : 201 / 11 KV DAHATONDA AG FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.4748	.4409
2				.4748	.4694
3				.4748	.6036
4				.4748	.6104
5				.4748	
6				.5087	.6706
7				.407	.7712
8	.6962	.5426	.4694		
9	.9945	.8817	.9945		
10	.9945	.9835	.663		
11	.8288	.7956	.8619		
12	.78	.663	.78		
13	.7461	.663	.6783		
14	.6783	.663	.5765		
15	.6783	.5967	.5765		
16		.5967			
17		.5967			
22			.2713	.3391	.4191
23			.2713	.3688	.4475
24				.2713	.4024
Max	.9945	.9835	.9945	.5087	.7712
Min	.6783	.5426	.2713	.2713	.4024
Avg	.7996	.6983	.6143	.4269	.5372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024026 / 33 KV MORAMBA

Feeder No / Name : 202 / 11 KV SHIVAN FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1989	.2035	.2486	.2374	.1677
2	.1989	.2035	.2486	.2374	.1677
3	.1989	.2035	.2321	.2374	.1696
4	.1989	.2035	.2321	.2374	.1696
5	.1989	.2035	.2155	.2374	.1677
6	.1989	.2035	.2155	.2374	.1696
7	.1989	.2035	.2321	.2374	.2012
8	.2984	.3052	.2652	.2713	.2347
9	.3315	.3052	.3978	.373	.2652
10	.3315	.3391	.3315	.3391	.2652
11	.3647	.3647	.3647	.373	.3315
12	.373	.3647	.373	.3018	.3315
13	.3391	.3315	.2713	.3052	.3647
14	.3052	.2984	.3391	.3315	.3149
15	.3052	.3315	.3391	.3391	.2984
16	.3391	.3647	.4409	.3391	.3315
17	.3052	.3315	.407	.3018	.3315
18	.3052	.3315	.407	.2713	.2652
19	.2713	.2321	.3052	.2347	.1989
20	.2374	.1989	.2713	.2035	.2155
21	.2035		.2374	.2241	.2486
22	.2374	.2984	.2374	.2012	.2012
23	.2035	.2984	.2374	.1658	.2012
24	.1989	.2035	.2486	.2374	.1658
Max	.373	.3647	.4409	.373	.3647
Min	.1989	.1989	.2155	.1658	.1658
Avg	.2643	.2749	.2958	.2698	.2408

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024026 / 33 KV MORAMBA

Feeder No / Name : 203 / 11 KV UMRI FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5868	.5426	.4694	.4748	.5087
2	.5636	.5426	.4694	.4748	.4694
3	.5636	.5426	.4694	.4748	.4748
4	.5636	.5426	.4973	.4748	.4694
5	.5304	.5426	.4973	.4748	.4748
6	.5304	.5426	.5365	.4748	.4694
7	.6036	.5426	.6706	.4748	.6104
8	.8619	.7461	.7712	.8139	.8048
9	.9724	.9156	1.326	1.2209	1.0059
10	1.1401	1.153	1.1603	1.2209	.9945
11	.8619	1.073	1.1401	1.0852	.9282
12	.8817	.9945	1.0852	1.0174	.8048
13	.8817	.9389	1.0174	.9282	.8619
14	.8139	.6036	1.0174	.8718	.9945
15	.8139	.8718	1.0174	.8817	1.073
16	.8139	.5868	1.0174	.8817	1.1271
17	.8817	.9945	.8817	.8718	.7377
18	.7461	.8619	.6783	.7461	.7293
19	.6104	.6706	.6104	.6706	.663
20	.6783	.663	.5426	.6783	.6299
21	.4748		.5426	.6104	.5304
22	.407	.6036	.5426		.4191
23	.5087	.4641	.5087	.5087	.3521
24	.5801	.5426	.4694	.4748	.503
Max	1.1401	1.153	1.326	1.2209	1.1271
Min	.407	.4641	.4694	.4748	.3521
Avg	.7029	.7166	.7474	.7307	.6932

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024026 / 33 KV MORAMBA

Feeder No / Name : 204 / 11 KV KHANDALA W/W EXPRESS NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1357	.1509	.0678	.1341
2	.1509	.1357	.1509	.0678	.1341
3	.1509	.1357	.1509	.0678	.1341
4	.1509	.1357	.132	.0678	.1341
5	.1509	.1357	.132	.0678	.0678
6	.1509	.1357	.0566	.0678	.0509
7	.1509	.0678	.1698	.1017	.1509
8	.1698	.0509	.0566	.1357	.1341
9	.1698	.0509	.0566	.1357	.1509
10	.0566	.0678	.0566	.1357	.1698
11	.0566	.0566	.1509	.1357	.1698
12	.1357	.0566	.1526	.1526	.1698
13	.1357	.0566	.1357	.1174	.1509
14	.1357	.0189	.1357	.0503	
15	.1357	.0566	.1526	.0503	.0566
16	.0509	.0566	.0339	.0509	.1509
17	.0678	.0566	.0509	.1494	.0377
18	.0509	.0566	.0678	.1357	.0566
19	.0509	.0566	.0509	.0503	1.6409
20	.0509	.0377	.0509	.0509	.0566
21	.0339		.0339	.0503	.0566
22	.1357	.0566	.1357	.1341	.1174
23	.1357	.132	.1357	.1357	.1357
24	.1509	.1357	.1509	.0678	.1341
Max	.1698	.1357	.1698	.1526	1.6409
Min	.0339	.0189	.0339	.0503	.0377
Avg	.1158	.0820	.1063	.0936	.1824

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024026 / 33 KV MORAMBA

Feeder No / Name : 205 / 11 KV MURAMBA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1677	.1696	.1341	.1017	.1017
2	.1492	.1696	.1326	.1017	.1006
3	.1326	.1696	.1326	.1017	.1017
4	.1326	.1696	.1341	.1017	.1017
5	.1326	.1696	.1326	.1017	.1017
6	.1326	.1696	.1326	.1696	.1357
7	.1658	.2035	.1658	.1696	.1696
8	.2012	.1696	.1658	.1696	.1357
9	.1326	.1357	.1326	.1696	.1989
10	.1658	.1696	.1326	.1696	.1658
11	.1326	.1326	.1989	.1357	.0829
12	.1357	.1341	.1696	.1017	.0995
13	.1357	.1326	.1357	.1006	.0995
14	.1357	.0995	.1357	.1017	.1326
15	.1357	.0995	.1357	.0995	.0995
16	.1357	.1326	.1017	.1017	.1658
17	.1357	.1326	.1187	.1341	.1326
18	.1696	.1989	.2035	.2035	.1658
19	.2035	.2012	.2035	.2012	.1989
20	.1696	.1658	.1696	.1696	.1989
21	.1696		.1526	.1696	.1658
22	.1696	.1326	.1357	.1341	.1492
23	.1696	.1326	.1357	.1017	.1341
24	.1677	.1696	.1326	.1017	.1006
Max	.2035	.2035	.2035	.2035	.1989
Min	.1326	.0995	.1017	.0995	.0829
Avg	.1533	.1548	.1469	.1339	.1350

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024026 / 33 KV MORAMBA

Feeder No / Name : 206 / 11 KV BIDGAON GF

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0838	.0848	.0829	.0678	.0678
2	.1006	.1017	.0829	.0678	.0678
3	.1006	.1017	.0829	.0678	.0678
4	.0995	.1017	.0829	.0678	.0678
5	.1174	.1017	.0829	.0678	.0678
6	.1174	.1017	.0838	.0848	.0671
7	.116	.1187	.0829	.0848	.1006
8	.0663	.1187	.0829	.1017	.1017
9	.116	.0339	.116	.1187	.1006
10	.0995	.0509	.0829	.1017	.0995
11	.0497	.0332	.0663	.0678	.0829
12	.0509	.0503	.0509	.0497	.0497
13	.0509	.0497	.0509		.0497
14	.0339	.0497	.0848	.0332	.0497
15	.0509	.0663	.1017	.0671	.0497
16	.0509	.0663	.0848	.0678	.0332
17	.1187	.116	.1017		.0995
18	.1017	.1492	.1357	.1357	.0995
19	.1187	.1677	.1357	.1341	.1492
20	.1017	.116	.1017	.1006	
21	.1017		.0848		.0995
22	.0848	.0995	.0848	.0838	.0743
23	.0848	.0829	.0848	.0671	.0663
24	.0838	.0848	.0829	.0678	.0671
Max	.1187	.1677	.1357	.1357	.1492
Min	.0339	.0332	.0509	.0332	.0332
Avg	.0875	.0890	.0881	.0812	.0773

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024026 / 33 KV MORAMBA

Feeder No / Name : 207 / 11 KV DHANORA P GF

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2683	.373	.2515	.2204	.2374
2	.2683	.373	.2515	.2204	.2347
3	.2683	.373	.2652	.2204	.2321
4	.2683	.373	.2984	.2204	.2374
5	.2683	.373	.3018	.2204	.2713
6	.2683	.373	.3315	.2713	.3052
7	.2515	.373	.3521	.3222	.3315
8	.218	.2883	.3149	.3391	.3353
9	.218	.2713	.1658	.3052	.3315
10	.2155	.2374	.2321	.2713	.2683
11	.1658	.2486	.2515	.2035	.2012
12	.1696	.1844	.1865	.1677	.1989
13		.218	.1696	.1677	.1677
14	.2035	.2155	.1865	.1677	.1823
15	.2035	.2012	.1696	.1867	.1677
16	.1865	.2012	.1865	.1696	.1658
17	.2374	.2321	.2035	.2204	.1989
18	.5087	.4475	.39	.4409	.4475
19	.5596	.4475	.4578		.431
20	.4409	.3647	.373	.3353	.3978
21	.39		.3052	.4191	.3315
22	.39	.2818	.2713	.2683	.2984
23	.373	.2486	.2204	.2683	.2515
24	.2683	.373	.2515	.2204	.2374
Max	.5596	.4475	.4578	.4409	.4475
Min	.1658	.1844	.1658	.1677	.1658
Avg	.2874	.3075	.2662	.2542	.2693

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024036 / 33 KV SIRSO

Feeder No / Name : 201 / 11 KV SIRSO AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.4843	.5937
2				.4843	.5937
3				.4843	.5937
4				.4843	.5937
5				.4843	.5937
6				.4843	.5937
7				.5535	.5693
8	.5376	.4967	.5851		
9	.7274	.7811	.8223		
10	.8436	.8025	.8539		
11	.7499	.8592	.9014		
12	.7716	.828	.8223		
13	.7811		.8539		
14	.8122	.8592	.787		
15	.8179	.8697	.7407		
22			.4784	.5376	.4687
23			.4843	.6009	.5535
24				.4999	.6019
Max	.8436	.8697	.9014	.6009	.6019
Min	.5376	.4967	.4784	.4843	.4687
Avg	.7552	.7852	.7329	.5098	.5756

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024036 / 33 KV SIRSO

Feeder No / Name : 202 / 11 KV HIRPUR GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1698	.168	.168	.1494
2	.1463	.1698	.168	.168	.1494
3	.1829	.1698	.168	.168	.1494
4	.1829	.1698	.168	.168	.1494
5	.1829	.1886	.168	.168	.1494
6	.1829	.1886	.168	.168	.1867
7	.2075	.2218	.2054	.2054	.2241
8	.168	.168	.2054	.1886	.2054
9	.2241	.2054	.2987	.2054	.2241
10	.1848	.1867	.1848	.1867	.168
11	.1612	.168	.168	.1494	.1646
12	.1267	.1509	.168	.1307	.1294
13	.1463	.1307	.1494	.112	.1294
14	.1254	.1307	.1294	.112	.1294
15	.1372	.112	.1294	.112	.1294
16	.1075	.112	.1063	.0934	.1109
17	.1612	.1494	.1478	.0943	.1478
18	.2534	.2241	.2427	.2241	.2218
19	.2957	.2801	.2801	.2801	.2772
20	.2402	.2427	.2241	.2427	.2402
21	.2241	.2241	.2054	.2054	.2218
22	.2033	.2054	.1886	.1867	.1848
23	.1848	.1867	.1698	.1494	.1698
24	.1829	.168	.168	.1629	.1494
Max	.2957	.2801	.2987	.2801	.2772
Min	.1075	.112	.1063	.0934	.1109
Avg	.1831	.1801	.1825	.1687	.1734

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024036 / 33 KV SIRSO

Feeder No / Name : 203 / 11 KV PUNDLIK NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.1494	.4481	.4294	.4668
2	.5601	.1494	.4481	.4294	.4668
3	.5601	.1494	.4481	.4294	.4668
4	.5601	.1494	.4481	.4294	.4481
5	.5601	.2987	.4481	.5228	.4481
6	.5601	.3361	.5415	.5788	.7468
7	.5041	.3547	.8029	.8029	.6722
8	.4854	.3921	.8589	.8029	.8029
9	.5041	.4668	.9522	.8589	.7842
10	.4294	.7655	.8775	.8402	.8316
11	.4668	.9619	.9149	.8215	.8589
12	.3734	.9149	.8215	.7842	.8402
13	.3734	.8215	.7964	.7282	.7842
14	.3361	.8029	.8962	.8029	.7842
15	.1867	.8775	.8402	.7282	.7655
16	.2241	.8589	.8962	.7282	.8215
17	.2054	.9055	.8962	.8589	.8402
18	.2427	.9425	.9335	.9149	.7282
19	.2614	.6468	.7842	.7842	.7468
20	.2801	.6161	.7095	.7468	.6722
21	.2427	.5228	.6161	.6535	.6161
22	.1867	.5041	.5041	.5041	.4668
23	.168	.4854	.4668	.4668	.4294
24	.5601	.1494	.4481	.4294	.4854
Max	.5601	.9619	.9522	.9149	.8589
Min	.168	.1494	.4481	.4294	.4294
Avg	.3913	.5509	.6999	.6698	.6656

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024044 / 33/11 KV Sonori S/S

Feeder No / Name : 201 / 11 KV KHADAKA FEEDER
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4706	.3224	.4525	.4163	
2	.4706	.298	.4525	.4344	.3982
3	.4706	.2804	.4344	.4344	.3982
4	.4706	.2804	.4344	.4344	.3982
5	.5068	.2947	.4344	.4344	.3982
6	.5249	.3467	.4525	.4344	.3982
7		.3641	.5373	.4938	.5373
8	.5784	.4409	.5609		.6836
9	.7011	.5258	.6344	.5658	
10	.7973	.5784	.6443	.6001	
11	.691	.7712	.663	.5721	
12	.6201	.8238	.663		.8573
13	.6733	.6516	.6783		.8149
14	.6268	.7011	.4578		.7362
15	.5731	.6836	.5765		.6836
16	.6135	.6661	.6783		.7011
17		.6344	.5765		.7442
18		.6661	.6068		.6733
19	.1829	.7087	.6241	.7975	.7442
20	.3801	.6001	.5194	.6836	.6024
21	.3801	.6516	.5249	.631	.5138
22	.4119	.4887	.4572	.5316	.4508
23	.394	.4887	.4572	.4706	.3814
24	.5138	.3045	.4525	.4344	.4344
Max	.7973	.8238	.6783	.7975	.8573
Min	.1829	.2804	.4344	.4163	.3814
Avg	.5263	.5238	.5405	.5231	.5775

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024044 / 33/11 KV Sonori S/S

Feeder No / Name : 202 / 11KV SONORI AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1957	1.0402	1.1203	.5944	.679
2	.1957	1.0385	1.1043	.5944	.679
3	.1957	1.0669	1.0883	.5944	.679
4	.1981	1.0364	1.0722	.5944	.679
5	.2134	1.0517	1.0883	.6622	.7407
6	.2315	1.0686	1.0883	.7676	.9414
7	.2469	1.3108	1.1523	.9297	1.0802
8	.8124	.703	.7842	1.0311	.8951
9	1.1561	1.1043	1.0467	1.3603	1.2029
10	1.2191	1.2963	.9998	1.5684	1.3435
11	1.2654	.9442	1.0467	1.4899	1.406
12	1.1405	1.2003	1.0467		1.3435
13	.9998	1.085	1.0155		1.186
14	1.012	1.0364	.9686		1.2323
15	1.0279	1.0242			1.2483
22		1.1043	.5647	.7773	.8718
23		1.1043	.5647	.7407	.8215
24	.1957	.9957	1.1203	.5944	.7253
Max	1.2654	1.3108	1.1523	1.5684	1.406
Min	.1957	.703	.5647	.5944	.679
Avg	.6441	1.0673	.9925	.8785	.9864

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 025007 / 33 KV MURTIZAPUR

Feeder No / Name : 201 / 11KV NAGOLI AG FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.9945	1.1145	1.0631	.0183
2	.0171	.9945	1.1145	1.0631	.0183
3	.0171	.9945	1.0974	1.0631	.0183
4	.0171	.9945	1.0631	1.0631	.0183
5	.0171	.9259	1.0288	1.0288	.0183
6	.0171	.8573	1.0288	.9945	.0183
7	.0171	.9259	1.0288	.9602	.0183
8	.0171	.0171	.0171	.7545	.8954
9	.0171	.0171	.0343	1.0288	1.166
10	.0171	.0171	.0343	1.2003	1.3032
11	.0171	.0171	.0343	1.3032	1.3375
12	.0171	.0171	.0343	1.3032	1.3032
13		.0171	.0343	1.2346	1.2689
14	.0171	.0171	.0343	1.2346	1.2346
15	.0171	.0171	.0343	1.166	1.2346
16	.0171	.0171		.0171	.0171
17	.0171	.0171	.0343	.0187	.0181
18	.0171	.0171	.0343	.0181	.0181
19	.0171	.0171	.0343	.0181	.0181
20	.0171	.0171	.0343	.0181	.0181
21	.0171		.0343	.0181	.0181
22	.0171	1.0288	1.0974	.0171	.0171
23	.0171	.9945	1.1317	.0171	.0171
24	.0171	1.0288	1.166	1.0974	.0171
Max	.0171	1.0288	1.166	1.3032	1.3375
Min	.0171	.0171	.0171	.0171	.0171
Avg	.0171	.4331	.4913	.7375	.4179

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 025007 / 33 KV MURTIZAPUR

Feeder No / Name : 202 / 11 KV TOWN - 2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.2743	.3086	.2743	.362
2	.3086	.2743	.3086	.2743	.362
3	.3086	.2743	.3086	.2743	.362
4	.3086	.2743	.3086	.2743	.362
5	.3429	.2743	.3086	.2743	.362
6	.3772	.3772	.3429	.3429	.362
7		.4458	.3772	.3429	.3982
8	.4115	.4115	.3772	.3772	.4344
9	.4115	.4458	.3772	.4115	.4801
10	.5487	.5144	.4458	.4458	.3772
11	.583	.4801	.4458	.3772	.4115
12	.5144	.4115	.4458	.3086	.4115
13	.4458	.4115	.3772	.3086	.3086
14	.4115	.0171	.3772	.3086	.3429
15	.3772	.4115	.3772	.3429	.4115
16	.3772	.4115		.3772	.4115
17	.3429	.4115	.4115	.3982	.3258
18	.4458	.5487	.5487	.4344	.5068
19	.4115	.5144	.4458	.4706	.5068
20	.4458	.4458	.4115	.4344	.3982
21	.4115		.4115	.3982	.362
22	.4115	.3772	.3429	.3086	.3086
23	.3772	.3429	.3086	.3086	.3086
24	.3429	.3429	.3086	.3086	.2743
Max	.583	.5487	.5487	.4706	.5068
Min	.3086	.0171	.3086	.2743	.2743
Avg	.4026	.3779	.3772	.3490	.3813

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 025007 / 33 KV MURTIZAPUR

Feeder No / Name : 203 / 11 KV TOWN-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9259	.8573	.8916	.7545	.9602
2	.8916	.8573	.8573	.7545	.9602
3	.8916	.8573	.8573	.7545	1.0288
4	.8916	.8573	.8573	.7545	1.0288
5	.9431	.8916	.8916	.823	1.166
6	1.1145	1.0288	.9945	.8916	1.2003
7	1.2346	1.3032	1.0974	1.2003	1.2346
8	1.2003	1.2003	1.2003	1.2003	1.2003
9	1.3032	1.2003	1.2346	1.2346	1.3032
10	1.2689	1.2003	1.406	1.2346	1.2346
11	1.2689	1.2003	1.2003	1.1317	1.166
12	1.2346	1.1317	1.2346	1.0974	1.1317
13	1.1317	1.1317	.9602	1.0288	1.0631
14	1.1317	1.1317	1.0288	.9602	.9945
15	1.0631	.9602	.8916	.9259	.9602
16	1.0974	1.0288		1.0631	.9602
17	1.0974	1.0974	1.0974	1.1096	1.086
18	1.4403	1.5775	1.3717	1.3032	1.3032
19	1.406	1.4746	1.406	1.448	1.448
20	1.4746	1.4746	1.2346	1.3394	1.3394
21	1.3717		1.1317	1.267	1.267
22	1.3032	1.2003	1.0288	1.0631	1.0288
23	1.0631	1.0288	.9259	.9259	.9259
24	.9259	.8916	.8916	.823	.823
Max	1.4746	1.5775	1.406	1.448	1.448
Min	.8916	.8573	.8573	.7545	.823
Avg	1.1531	1.1123	1.0735	1.0454	1.1173

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 025007 / 33 KV MURTIZAPUR

Feeder No / Name : 204 / 11KV Goyanaka fdr

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3429	.3086	.3086	.4115
2	.3429	.3429	.3086	.3086	.4115
3	.3429	.3429	.3086	.3086	.4115
4	.3429	.3429	.3429	.3086	.4115
5	.3772	.3429	.3772	.3086	.4115
6	.4115	.3429	.4115	.3772	.4287
7	.4115	.4458	.4801	.4801	.4458
8	.4115	.4801	.4115	.4458	.4115
9	.5144	.4801	.4458	.4801	.4115
10	.5144	.7202	.6859	.5487	.6173
11	.5144	.6516	.6173	.5144	.5487
12	.5144	.583	.5487	.4458	.5487
13	.4115	.4458	.5144	.4458	.6859
14	.5487	.5144	.5144	.4801	.4801
15	.5144	.5144	.4801	.4458	.4801
16	.4115	.4458		.5144	.5144
17	.3772	.5487	.5144	.4706	.4706
18	.4801	.5487	.5487	.5068	.4344
19	.5144	.583	.4801	.543	.5792
20	.5144	.5144	.3772	.5068	.543
21	.4801		.4115	.4344	.4706
22	.4801	.4115	.3429	.3772	.3772
23	.4115	.4458	.3772	.4115	.3772
24	.3772	.3429	.3086	.3772	.3772
Max	.5487	.7202	.6859	.5487	.6859
Min	.3429	.3429	.3086	.3086	.3772
Avg	.4415	.4667	.4398	.4312	.4692

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 025007 / 33 KV MURTIZAPUR

Feeder No / Name : 205 / 11 KV MIDC IND

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.1715	.3086	.3429	.3429
2	.3086	.1715	.3086	.3772	.3429
3	.2743	.1715	.2743	.3772	.3429
4	.2743	.1715	.3086	.3429	.3086
5	.3086	.1715	.3429	.3429	.3086
6	.2743	.2058	.3429	.3429	.3086
7	.2743	.2058	.3429	.3772	.3086
8	.2401	.1715	.2743	.3429	.3086
9	.3086	.2058	.3429	.3772	.3772
10	.3429	.4801	.5487	.4115	.4115
11	.3772	.5487	.5144	.2058	.4801
12	.3086		.5144		.4801
13	.3086	.5487	.4801		.4458
14	.3086	.4458	.3429		.3429
15	.3086	.6173	.4458		.4115
16	.2743	.5144			.4801
17	.1715	.5144	.3429		.4344
18	.1372	.4115	.3772		.3982
19	.1029	.4115	.3086	.362	.362
20	.1372	.4115	.3086	.362	.3982
21	.1029		.3429	.3982	.3258
22	.1372	.3086	.3429	.3086	.3086
23	.1715	.3086	.3429	.3086	.3429
24	.3086	.1715	.3086	.3429	.3429
Max	.3772	.6173	.5487	.4115	.4801
Min	.1029	.1715	.2743	.2058	.3086
Avg	.2529	.3336	.3638	.3484	.3714

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 025007 / 33 KV MURTIZAPUR

Feeder No / Name : 206 / 11 KV Water /W EXPRESS NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343	.0343	.0366
2	.0857	.0343	.0343	.0343	.0366
3	.0857	.0343	.0857	.0343	.0362
4	.0857	.0343	.0857	.0343	.0366
5	.0857	.0343	.0857	.0343	.0362
6	.0857	.0343	.0857	.0343	.0366
7	.0857	.0343	.0857	.0343	.0362
8	.0857	.0343	.0343	.0343	.0362
9	.0857	.0343	.0343	.0514	.0343
10	.0857	.0343	.0343	.0343	.0343
11	.0857	.0343	.0343	.0343	.0343
12	.0343	.0343	.0343	.0343	.0343
13	.0343	.0343	.0343	.0343	.0343
14	.0343	.0343	.0343	.0343	.0343
15	.0343	.0343	.0514	.0343	.0343
16	.0686	.0343		.0343	.0343
17	.0343	.0343	.0343	.0362	.0362
18	.0343	.0343	.0343	.0362	.0362
19	.0343	.0343	.0343	.0362	.0362
20	.0343	.0343	.0343	.0362	.0362
21	.0343		.0343	.0362	.0362
22	.0343	.0343	.0343	.0343	.0343
23	.0343	.0343	.0343	.0343	.0343
24	.0343	.0514	.0343	.0514	.0343
Max	.0857	.0514	.0857	.0514	.0366
Min	.0343	.0343	.0343	.0343	.0343
Avg	.0571	.0350	.0462	.0361	.0354

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 025007 / 33 KV MURTIZAPUR

Feeder No / Name : 207 / 11 KV ANBHORA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.6173	.6859	.4458	.6859
2	.7202	.6173	.6859	.2743	.6859
3	.6859	.6173	.6516	.4458	.6859
4	.6859	.6173	.6859	.4458	.6859
5	.7545	.6173	.7202	.4801	.703
6	.823	.6859	.7545	.5487	.703
7	.9431	.7202	.8059	.6516	.7202
8	.7545	.7545	.7888	.6516	.7888
9	.823	.7888	.9259	.7202	.3429
10	.8916	.7202	.823	.6889	.4115
11	.9259	.9259	.823	.6859	.6859
12	.7888	.7888	.7545	.583	.7545
13	.7202	.6516	.6516	.6173	.7202
14	.6173	.7545	.6516	.6173	.6516
15	.5487	.823	.6173	.6173	.6516
16	.7202	.823		.6173	.583
17	.7545	.7545	.7545	.8063	.6516
18	1.0288	.9945	.823	.8326	.724
19	.8573	.9602	.8573	.8326	.905
20	.823	.9259	.823	.8326	.7964
21	.7545		.6859	.724	.7602
22	.7202	.7888	.6173	.6859	.6516
23	.7545	.7202	.583	.7202	.6687
24	.7545	.7202	.7202	.5487	.6859
Max	1.0288	.9945	.9259	.8326	.905
Min	.5487	.6173	.583	.2743	.3429
Avg	.7752	.7560	.7343	.6281	.6793

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 025007 / 33 KV MURTIZAPUR

Feeder No / Name : 208 / 11KV J.K. GINING

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.2058	.3086	.2743	
2	.3429	.2058	.2743	.2743	
3	.3086	.2058	.2743	.2743	
4	.3086	.2058	.2743	.2743	
5	.3086	.2058	.3086	.2743	
6	.3429	.2058	.3086	.3086	
7	.3429	.2743	.3086	.3429	
8	.2401	.2401	.3086	.2743	
9	.3429		.2743	.2401	.2743
10	.3429	.3429	.2401	.3772	.2401
11	.3086	.3429	.3429	.3772	.4115
12	.3086	.3429	.2743	.3772	.3429
13	.2743	.2058	.2401	.2743	.3429
14	.2401	.2401	.2401	.3086	.2401
15	.2401	.2401	.3086	.3429	.2058
16	.2058	.2401		.3429	.2743
17	.2058	.2058	.2401	.4344	.2896
18	.2401	.3429	.3429	.3982	.3258
19	.2743	.3772	.3086	.3982	.362
20	.2743	.3086	.2743	.2896	.2896
21	.2401		.3086	.3258	.3258
22	.2401	.2401	.3086	.3429	.4115
23	.2058	.3772	.3086	.3086	.3772
24	.3429	.2058	.3086	.3086	.2743
Max	.3429	.3772	.3429	.4344	.4115
Min	.2058	.2058	.2401	.2401	.2058
Avg	.2843	.2619	.2907	.3227	.3117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 025007 / 33 KV MURTIZAPUR

Feeder No / Name : 401 / 33 KV Murtizapur Main I/C NON SHEDDABLE EHV INDUSTRIAL FEEDERS

Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.6873	7.0988	7.7161	7.9218	7.7161
2	6.7901	6.893	7.7161	7.8189	7.9218
3	6.6358	6.7901	7.8189	7.8189	7.9218
4	6.6873	6.893	7.5617		8.0761
5	7.7161	7.0988	7.8189	8.1276	8.7449
6	7.7161	7.356	8.1276	8.3848	9.2078
7	7.7675	8.4362	9.0535	10.0823	9.7222
8	9.8766	9.2078	10.2366	7.0473	7.5617
9	12.7058	10.9568	12.1399	10.1852	9.0535
10	11.8313	12.5515	13.1687	11.1111	9.9794
11	10.9568	11.0597	11.3683	10.4938	9.9794
12	10.0823	10.391	10.6482	9.6194	9.2593
13	9.5679	8.3333	9.5679	9.2078	8.7449
14	9.2078	9.2078	9.1564	8.7449	8.6934
15	8.7449	9.6194	10.3395	8.5391	9.7222
16	7.2017	8.0761		7.2531	7.7161
17	7.5103	8.8477	8.0247	7.2217	7.6017
18	8.6934	9.6708	8.9506	7.8189	9.2307
19	9.0535	9.3622	8.8477	9.3393	9.4479
20	8.2819	5.9671	7.8189	8.6877	8.6877
21	7.5103		7.2531	7.6017	8.1447
22	7.3045	8.3333	9.3622	8.6934	6.9445
23	6.5329	7.8704	8.5391	8.1276	6.6873
24	6.7387	7.3045	7.4589	8.1276	7.7675
Max	12.7058	12.5515	13.1687	11.1111	9.9794
Min	6.5329	5.9671	7.2531	7.0473	6.6873
Avg	8.4084	8.5794	9.0736	8.6076	8.5222

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 025007 / 33 KV MURTIZAPUR

Feeder No / Name : 403 / 33 KV O/G -I (To Mana S/S) NON SHEDDABLE EHV INDUSTRIAL FEEDERS

Feeder KV- 33 / INCOMING (CONTINUOUS PROCESS)(NO STAGGERING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.9033	1.9547	2.4691	3.0864
2	2.0576	1.9033	1.9033	2.3663	3.0864
3	1.9547	1.9033	2.0062	2.3663	3.0864
4	1.9547	1.9033	2.0576	2.3663	3.0864
5	2.0576	1.9033	2.1605	2.4691	3.2922
6	2.1091	2.0062	2.3148	2.6235	3.2922
7	2.1605	2.5206	2.572	3.2407	3.4465
8	3.5494	3.3436	3.858	.8745	.9774
9	5.144	4.6811	4.6811	2.9835	2.3148
10	4.1667	5.0412	5.1955	3.2407	2.6235
11	3.858	3.5494	3.6523	3.1379	2.4691
12	3.3951	3.5494	3.5494	3.035	2.0576
13	3.1379	2.1605	3.1893	2.7778	2.1091
14	3.0864	3.2407	3.1379	2.7778	1.9547
15	2.9835	3.3436	2.4691	2.572	3.0864
16	2.1605	2.4691		1.9547	1.9547
17	2.3663	2.4691	2.3663	1.1403	2.2262
18	2.6749	2.9835	2.6749	1.3575	2.2805
19	2.8807	2.9835	2.7263	2.7149	2.8778
20	2.4691	2.1091	2.2634	2.4977	2.6063
21	2.1605		1.9547	2.1719	2.2805
22	2.0576	2.2634	2.9835	3.0864	1.8004
23	1.749	2.1091	2.6749	3.0864	1.5947
24	1.9547	2.0062	1.9033	2.572	2.9321
Max	5.144	5.0412	5.1955	3.2407	3.4465
Min	1.749	1.9033	1.9033	.8745	.9774
Avg	2.6995	2.7107	2.7934	2.4951	2.5218

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 025007 / 33 KV MURTIZAPUR

Feeder No / Name : 404 / 33 KV O/G -II (To Kherda NON SHEDDABLE EHV INDUSTRIAL FEEDERS
S/S) Feeder KV- 33 / INCOMING (CONTINOUS PROCESS)(NO STAGGERING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3375	1.0802	1.286	1.4918	1.749
2	1.4198	1.0802	1.3375	1.4918	1.8004
3	1.3889	1.0802	1.3375	1.4918	1.8004
4	1.4403	1.0802	1.4403	1.4918	1.8004
5	1.4403	1.0802	1.4918	1.4918	1.9547
6	1.4918	1.1317	1.5947	1.4918	2.0062
7	1.4918	1.2346	1.5947	1.9547	2.3663
8	2.4691	2.1605	2.3148	1.749	1.6975
9	3.3436	2.572	3.3951	2.3663	1.9547
10	3.1893	3.2407	3.5494	2.2634	1.9547
11	2.7778	2.8292	3.2407	2.0576	2.0062
12	2.6235	2.572	2.9321	1.9547	1.749
13	2.5206	2.4691	2.7778	1.8004	1.5947
14	2.4691	2.4177	2.572	1.5947	1.6975
15	2.3663	2.4177	2.7263	1.5947	1.749
16	1.5947	1.4918		1.9033	2.0062
17	1.6461	1.9033	1.749	1.9342	1.6289
18	1.6975	1.9033	1.8004	1.9004	1.7375
19	1.5432	1.5947	1.5432	1.7375	1.5746
20	1.4403	1.4918	1.3375	1.6289	1.4118
21	1.286		1.4918	1.5203	1.3032
22	1.286	1.3889	1.6461	1.5947	1.2346
23	1.286	1.286	1.5947	1.749	1.6461
24	1.286	1.286	1.286	1.4403	1.5947
Max	3.3436	3.2407	3.5494	2.3663	2.3663
Min	1.286	1.0802	1.286	1.4403	1.2346
Avg	1.8681	1.7736	2.0017	1.7373	1.7508

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024008 / 33 KV PATUR S/S

Feeder No / Name : 201 / 11 KV PATUR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0719	1.0456	.8779		.9412
2	1.0456	1.0456	.8413		.8954
3	1.0349	1.0456	.8501		.8954
4	1.0498	1.0456	.8779		.905
5	1.1827	1.2071	.9511	.8688	.9214
6	1.419	1.3957	1.2323	1.3306	1.267
7	1.7924	1.8107		1.7177	1.7002
8	1.5424	1.5684	1.6461	1.7558	1.6827
9	1.6263	1.4784	1.7741	1.643	1.5893
10	1.7013	1.4327	1.7193	1.7372	1.7375
11	1.7193	1.2757	1.5364	1.5524	1.4842
12	1.6301	1.1218	1.2894	1.2757	1.2269
13	1.5203	1.0402	1.134	1.0985	1.1919
14	1.1919	.9945	1.0402	.9816	1.0974
15	1.0517	.9816	1.0166	1.0631	.9602
16	1.1443	1.0288	1.0852	1.1271	1.1012
17	1.3466	1.2346	1.2887	1.2346	1.4685
18	1.8099	1.6301	1.6301	1.6655	1.829
19	1.6651	1.5927	1.5927	1.5565	1.5927
20	1.4998	1.3756	1.4632	1.3611	1.4784
21	1.3032	1.2178	1.3756	1.2757	1.3676
22	1.2308	1.086	1.1706	1.1584	
23	1.134	.8688	.9671		
24	1.1203	1.0456	.8688	.8596	.9313
Max	1.8099	1.8107	1.7741	1.7558	1.829
Min	1.0349	.8688	.8413	.8596	.8954
Avg	1.3681	1.2321	1.2273	1.3296	1.2847

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024008 / 33 KV PATUR S/S

Feeder No / Name : 202 / 11 KV KARLA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6104	.4973	.4915	.415	.4527
2	.6299	.5967	.4858		.4527
3	.6371	.5967	.5121		.4527
4	.6783	.663	.5182		.415
5	.6706	.7293	.583	.4527	
6	.6802	.7956	.6081	.4904	
7		.9831	.8124	.5658	
8	.415	.415	.415	.4268	.4428
9	.3018	.3395	.3772	.7716	.7362
10	.2641	.3018	.2641	.8749	.8962
11	.2263	.2263	.2263	.8855	.7716
12	.1886	.2263	.3018	.9061	.884
13	.2263	.2263	.2641	.9061	.7011
14	.2263	.2263	.2641	.8333	.8855
15	.2263	.2641	.2641	.6401	.7621
16	.2641	.2641	.3018	.3018	.2587
17	.3018	.3395	.3361	.3395	.3018
18	.5281	.5281	.5658	.5658	.5658
19	.6036	.6413	.679	.679	.6413
20	.6413	.6413	.6413	.6413	.6413
21	.6036	.6413	.6036	.679	.6036
22	.6036	.4858	.5281	.5658	
23	.6036	.4481	.4904		
24	.6036	.4641	.4801	.4527	.4904
Max	.6802	.9831	.8124	.9061	.8962
Min	.1886	.2263	.2263	.3018	.2587
Avg	.4667	.4809	.4589	.6197	.5977

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024008 / 33 KV PATUR S/S

Feeder No / Name : 203 / 11 KV SHIRLA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6009	.7449	.6173	.415	.4527
2	.6325	.7773	.6958		.415
3	.6478	.8097	.6958		.415
4	.6962	.9069	.7186	.3772	.415
5	.7956	1.0688	.7186	.3772	.4527
6	.9069	1.1984	1.0437	.5281	.5658
7		1.5546		.6413	.7167
8	.6413	.6036		.759	.7811
9	.5281	.5281	.6036	1.3108	1.1843
10	.415	.4527	.4904	.8421	1.1248
11		.3772	.3395	1.2955	1.0059
12	.3772	.3018	.3018	1.2498	1.0364
13	.3018	.3395	.3395	1.2498	1.0402
14	.3395	.3018	.3018	1.1728	1.0802
15	.3772	.3772	.3395	1.1873	1.0494
16	.3395	.3772	.3395	.3018	.3018
17		.4527		.3772	.3772
18	.679	.6036	.679	.6413	.6413
19	.7545	.7545	.7545	.679	.679
20	.7545	.7167	.7167	.679	.6413
21	.679	.679	.6036	.6413	.6413
22	.6036	.5761	.4904	.5281	
23	.5658	.6249	.4527	.4527	
24	.5937	.7125	.5792	.415	.4527
Max	.9069	1.5546	1.0437	1.3108	1.1843
Min	.3018	.3018	.3018	.3018	.3018
Avg	.5824	.6600	.5629	.7328	.7032

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024008 / 33 KV PATUR S/S

Feeder No / Name : 204 / 11 KV KHANAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	1.094	1.0562	.6554	.7712
2	1.1317	1.094	1.0185		.7888
3	1.1317	1.094	.9808		.7712
4	1.1694	1.094	.9808	.7293	.7956
5	1.2071	1.1694	1.0562	.7682	.8322
6	1.2071	1.2826	1.1317		1.1869
7	1.5089	1.5089	1.5089	1.5424	1.6575
8	1.3592	1.1142		1.358	
9		1.5912		1.0185	.1132
10	1.989	1.0242	1.7901	.8676	.9808
11	1.3927	1.3108	1.6575	.7545	.6036
12	1.704	1.3763	1.6575	.6413	.6036
13	1.8138	1.3603	1.5402	.5281	.4527
14	1.6446	1.2803	1.4251	.679	.4527
15	1.7368	1.4251	1.5043	.6413	.415
16	.6722	.7095	.679	.6722	.5228
17	.8962	.8871	.8589	.7842	1.0082
18	1.3203	1.3443	1.2696	1.1694	1.307
19	1.5089	1.4335	1.5089	1.4335	1.4712
20	1.4335	1.4335	1.358	1.358	1.3957
21	1.4335	1.3203	1.3203	1.2826	1.3203
22	1.2826	1.1694	.7293	.8322	
23	1.1694	1.094	.6401	.8573	
24	1.1694	1.094	1.0562	.6554	.8322
Max	1.989	1.5912	1.7901	1.5424	1.6575
Min	.6722	.7095	.6401	.5281	.1132
Avg	1.3484	1.2210	1.2149	.9156	.8706

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024008 / 33 KV PATUR S/S

Feeder No / Name : 205 / ww patur

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0377			
2		.0377			.0377
3	.0377	.0377	.0377		.0377
4	.0377	.0377	.0377	.0377	.0377
5	.0377	.0377	.0377	.0377	.0377
6	.0377	.0377	.0377	.0377	.0377
7	.0377	.0377	.0377	.0377	.0377
8	.0377	.0377	.0377	.0377	.0377
9	.0377	.0377	.0377	.0377	.0377
10	.0377	.0377	.0377	.0377	.0377
11		.0377	.0377	.0377	.0377
12		.0377	.0377	.0377	.0377
13		.0377	.0377	.0377	.0377
14		.0377	.0377	.0377	.0377
15	.0377	.0377	.0377	.0377	.0377
16	.0377	.0377	.0377	.0377	.0377
17	.0377	.0377	.0377	.0377	.0377
18	.0377	.0377	.0377	.0377	.0377
19	.0377	.0377	.0377	.0377	.0377
20	.0377	.0377	.0377	.0377	.0377
21	.0377	.0377	.0377	.0377	.0377
22	.0377	.0377	.0377	.0377	
23	.0377		.0377		
24		.0377	.0377	.0377	
Max	.0377	.0377	.0377	.0377	.0377
Min	.0377	.0377	.0377	.0377	.0377
Avg	.0377	.0377	.0377	.0377	.0377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024009 / Sasti

Feeder No / Name : 201 / 11 KV SASTI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1372	.1029	.2401	.2743
2	.12	.1372	.1029	.2743	.2743
3	.12	.12	.1029	.2743	.2743
4	.12	.12	.12	.3086	.3086
5	.1372	.12	.1372	.3429	.3429
6	.1543	.1715	.1543	.3944	.4801
7	.2229	.2229	.2058	.5658	.6516
8	.4239	.5487	.4115	.2058	.2058
9	.5087	.5658	.5487	.1886	.1886
10	.5079	.6001	.5487	.1543	.1715
11	.5316	.5658	.5087	.1029	.1029
12	.5487	.583	.5426	.0857	.0857
13	.5487	.5658	.5426	.0686	.0857
14	.5487	.5658	.5426	.0686	.0686
15	.5316	.583	.5426	.0686	.0857
16	.1029	.0857	.0848	.0857	.0686
17	.12	.0857	.1029	.0857	.1029
18	.1543	.1543	.1372	.1372	.1372
19	.2058	.1543	.1715	.1543	.1543
20	.2058	.1372	.1715	.1372	.1372
21	.1372	.12	.12	.1372	.12
22	.1372	.12	.2572	.3429	
23	.12	.12	.2572	.3086	
24	.12	.12	.1029	.2401	.2743
Max	.5487	.6001	.5487	.5658	.6516
Min	.1029	.0857	.0848	.0686	.0686
Avg	.2686	.2793	.2716	.2072	.2089

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024009 / Sasti

Feeder No / Name : 202 / 11 KV SUKALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3391	.3258	.3258	.12	.1029
2	.3391	.3258	.3258	.12	.1029
3	.3391	.3258	.3258	.12	.1029
4	.407	.3258	.3429	.12	.1029
5	.4409	.3258	.3429	.12	.12
6	.4578	.3429	.3601	.12	.12
7	.4748		.3772	.1543	.1543
8	.12				.3086
9	.1029	.1543	.1372	.4287	.3772
10	.1029	.0857	.12	.4801	.4115
11	.0343	.0686	.0857	.4115	.4458
12		.12	.0514	.3944	.2058
13	.0343	.0857	.0343		.3772
14	.0343	.0686	.0343	.2572	.3772
15	.0343	.0686	.0343	.2572	.4115
16	.0686	.0857	.0343	.0343	.0343
17	.1029	.0686	.0514	.0514	.0686
18	.1029	.12	.1029	.12	.1029
19	.1029	.1372	.1372	.12	.1372
20	.12	.1372	.12	.12	.12
21	.12	.12	.12	.12	.12
22	.1029	.3086	.12	.1029	
23	.1029	.3086	.12	.1029	
24	.3391	.3258	.3258	.12	
Max	.4748	.3429	.3772	.4801	.4458
Min	.0343	.0686	.0343	.0343	.0343
Avg	.1923	.1925	.1752	.1816	.2049

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024009 / Sasti

Feeder No / Name : 203 / 11 KV KHETRI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2058	.2058	.6859	.6859
2	.2401	.2229	.2058	.7716	.6859
3	.2401	.2229	.2058	.823	.6859
4	.2743	.2229	.2743	.9431	.8573
5	.3086	.2572	.3429	1.0288	.9945
6	.3601	.3429	.4115	1.0974	1.2689
7	.463	.5316	.5658	1.6118	1.6804
8	1.4922	1.2689	1.166	.4458	.4458
9	1.6289	1.5947	1.6804	.4115	.4458
10	1.4255	1.2003	1.5089	.3429	.3772
11	1.3375	1.2346	1.2003	.2915	.3429
12	1.3032	1.3203	1.0974	.2572	.2401
13	1.1831	1.2003	1.0288	.2401	.2572
14	1.286	1.0802	.8848	.2401	.2572
15		1.166	1.1191	.2401	.2229
16	.2058	.2229	.2401	.2743	.2401
17	.2401	.2743	.2743	.2743	.3086
18	.3601	.4287	.3086	.4287	.3429
19	.3772	.3944	.3772	.3429	.3772
20	.3429	.3772	.3086	.3086	.3429
21	.3086	.3429	.2572	.2915	.2915
22	.2743	.2743	.6859	1.0974	
23	.2058	.2401	.6859	.8573	
24	.2401	.2058	.2058	.6516	.6859
Max	1.6289	1.5947	1.6804	1.6118	1.6804
Min	.2058	.2058	.2058	.2401	.2229
Avg	.6234	.6180	.6351	.5816	.5471

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024009 / Sasti

Feeder No / Name : 204 / 11 KV WADEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1869	1.1145	1.0974	.1715	.1715
2	1.1869	1.1145	1.0974	.2058	.1715
3	1.2346	1.0974	1.0974	.2058	.1715
4	1.3226	1.0974	1.2003	.2058	.2058
5	1.4403	1.0802	1.2689	.2572	.2401
6	1.543	1.2003	1.4403	.2743	.3086
7	1.6617	1.6289	1.6118	.3429	.3601
8	.2915	.2915	.3258	1.5432	1.6118
9	.2572	.2229	.2743	1.6975	1.7147
10	.1715	.1543	.2229	.4801	1.6461
11	.12	.1372	.1543	1.3717	1.3717
12	.12	.1029	.1886	1.286	1.3717
13	.12	.1029	.1543	1.2346	
14	.12	.12	.12	1.3375	1.3375
15		.12	.12		1.3717
16	.1372	.1372	.1543		.12
17	.1715	.1543	.1543	1.3032	.1543
18	.2401	.2058	.2058	.2229	.2401
19	.2572	.2915	.2572	.2743	.2743
20	.2743	.2743	.2229	.2572	.2572
21	.2401	.2401	.2229	.2401	.2401
22	.1543	1.2003	.2058		
23	.1886	1.166	.1715	.1715	
24	1.1869	1.1145	1.0974	.1543	.1715
Max	1.6617	1.6289	1.6118	1.6975	1.7147
Min	.12	.1029	.12	.1543	.12
Avg	.5925	.5987	.5444	.6304	.6434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024022 / 33 KV ALEGAON

Feeder No / Name : 201 / 11 KV CHONDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1736		.9054	.4904	.5975
2	1.1736	1.1271	.9054	.4904	.5975
3	1.2071		.8718	.4904	.5601
4	1.2071	1.1336	.8718	.5281	.5601
5	1.2071	1.1797	.9054	.6036	.5975
6	1.2239	1.278	.9221	.6602	.7023
7	1.5089	1.4899	1.1401	.8488	.5973
8	.6722	.6535	.6908	.7287	1.2452
9	.5601	.5415	.6722	.9878	1.6741
10	.4668	.3921	.4854	1.4091	1.6741
11	.3174	.3361	.2987	1.7859	1.6244
12	.2829	.2987	.2987	1.5546	1.5971
13	.2427	.2987	.2987	1.4737	1.1574
14	.2743	.3174	.2987	1.6842	1.2811
15	.2987	.3174	.2987	1.6057	1.1717
16	.3174	.3921	.3174	.3258	.3641
17	.3921	.4481	.4108	.3898	.5487
18		.6979	.6908	.7059	.8029
19	.8589	.8488	.7468	.8589	.8402
20	.8215	.8299	.7842	.8029	.7468
21	.7842	.7922	.7468	.7282	.7468
22	.7095	.703	.6224	.6722	.6908
23	.6535	.8718	.5658	.6535	
24	1.1145	1.1105	.8718	.547	.6348
Max	1.5089	1.4899	1.1401	1.7859	1.6741
Min	.2427	.2987	.2987	.3258	.3641
Avg	.7595	.7299	.6509	.8761	.9136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024022 / 33 KV ALEGAON

Feeder No / Name : 202 / 11 KV ALEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.4481	.4854	.2846	.298
2	.5658	.4294	.4854	.2846	.298
3	.5658	.4108	.4854	.2949	.3189
4	.6413	.4108	.5228	.3429	.3189
5	.7167	.6535	.5228	.3856	.3429
6	.8215		.6722	.3856	.4239
7	1.0829	1.1016	.9808	.5373	.5533
8	.583		.5487	1.0562	1.0185
9	.6516	.663	.7202	.9054	1.094
10	.6706	.6062	.7545	.8299	.8299
11	.4024	.6062	.6516	.6413	.6979
12		.6226	.6371	.5611	.5281
13	.6316	.6226	.5487	.4294	.4481
14	.6718	.6226	.4755	.3921	.4527
15	.6796	.5898	.4694	.3921	.4527
16	.5415	.7316	.5121	.5121	.5601
17	.7282	.7133	.7095	.6335	.7468
18	1.0082	.9335	.9335	.8507	.9709
19	.8215	.8215	.9709	.8775	1.0456
20	.7468	.7545	.7468	.7468	.8962
21	.6348	.6413	.5601	.5975	.5544
22	.5601	.5847	.253	.3366	.3201
23	.4854	.5228	.253	.3224	
24	.5601		.4854	.253	.3258
Max	1.0829	1.1016	.9808	1.0562	1.094
Min	.4024	.4108	.253	.253	.298
Avg	.6668	.6424	.5994	.5355	.5868

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024022 / 33 KV ALEGAON

Feeder No / Name : 203 / 11 KV AMBASHI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1145	1.2071	.9945	.7545	.8402
2	1.0898	1.2431	1.0288	.7545	.7842
3	1.1736	1.2289	1.0059	.7545	.7842
4	1.2407	1.2616	1.0059	.9808	.8215
5	1.2407	1.3279	1.073	1.226	1.0456
6	1.5089	1.5729	1.358	1.3203	1.251
7	1.8107	1.8947	1.8778	1.6598	1.7194
8	1.5123		1.5181	1.2346	1.2378
9	1.3957	1.1576	1.3256	1.7772	1.7901
10	1.1317	.8962	.9896	2.0454	1.6575
11	.8488	.8215	.8402	1.9784	1.6409
12	.7468	.7842	.7468	1.3717	1.1431
13	.8215	.7468	.6722	1.6518	1.3904
14	.6838	.6348	.6535	1.6032	1.3757
15	.7282	.6535	.7733	1.5238	1.2651
16	.7095	.8589	.6838	.6104	.6348
17	.8402	.8215	.8316	.8145	.9335
18	1.3256	1.2637	1.2197	1.1222	1.3769
19	1.363	1.4146	1.2936	1.363	1.5089
20	1.307	1.3203	1.1203	1.1949	1.3203
21	1.1576	1.1883	1.0751	1.0829	1.1506
22	1.1016	.9602	.9242	1.0082	1.0562
23	1.0269	.9259	.8676	.9709	
24	1.0802	1.0898	.9431	.811	.9335
Max	1.8107	1.8947	1.8778	2.0454	1.7901
Min	.6838	.6348	.6535	.6104	.6348
Avg	1.1233	1.0989	1.0343	1.2339	1.2027

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024053 / CHANNI

Feeder No / Name : 201 / 11 KV CHANNI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1067	.1067	.1715	.1067
2	.1372	.1067	.1067	.1543	.1067
3	.1372	.1067	.0914	.1543	.1067
4	.1372	.1067	.0914	.1715	.1067
5	.1372	.0914	.1372	.1715	.1677
6	.2058	.1372	.2134	.2401	.1677
7	.2743	.2439	.2591	.3086	.1829
8	.2572	.2134	.2401	.1715	.1829
9	.2572	.2286	.2229	.2058	.2134
10	.2058	.1981	.2058	.1715	.1829
11	.1715	.2286	.2229	.1677	.1524
12	.1524	.2229	.2401	.1981	.1677
13	.1219		.2572	.1829	.1372
14	.1524	.1715	.1524	.1677	.1524
15	.1524		.1219	.1524	.1524
16	.1524	.1715		.1067	.12
17	.1219	.1715	.1715		.1715
18	.1829	.2572	.2229	.1981	.2229
19	.1981	.2572	.2572	.2286	.2401
20	.2134	.2401	.2401	.1981	.2401
21	.2134	.2401	.2229	.1829	.2229
22	.1981	.1372	.1886	.1677	.2058
23	.1677	.1067	.1715	.1372	.1715
24	.1372	.1067	.0914	.1715	.1524
Max	.2743	.2572	.2591	.3086	.2401
Min	.1219	.0914	.0914	.1067	.1067
Avg	.1759	.1750	.1841	.1817	.1681

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024053 / CHANNI

Feeder No / Name : 202 / 11 KV UMRA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3048	.3258	.9774	.9755
2	.3429	.3048	.3086	.9602	.9755
3	.3429	.3048	.3258	.9602	.9755
4	.3429	.3048	.3258	.9945	1.0364
5	.3772	.3353	.3772	1.0802	1.1279
6	.4973	.3963	.463	1.0974	1.1888
7	.6516	.3963	.6516	1.2346	1.1888
8	1.2346	1.0364	1.0669	.5316	.442
9	1.3717	1.1584	1.0974	.5316	.4572
10	1.3203	1.2346	1.2193	.4115	.3506
11	1.3546	1.2346	1.2193	.2896	.3201
12	1.2193	1.1126	1.3889	.2439	.3258
13	1.2193	1.1888	1.3889	.2896	.2915
14	1.0669	1.2498	1.2193	.3201	.3258
15	1.1431	1.1888	1.1736	.2591	.3086
16	.3048	.2229		.2896	.3086
17	.3048	.2743	.3429	.3658	.3944
18		.4287	.4973	.442	.4973
19	.3963	.4973	.4973	.4572	.463
20	.4268	.4458	.4458	.381	.4458
21	.3963	.4115	.4115	.3506	.4115
22	.3353	.3772	.9774	.884	.8078
23	.3201	.3429	.9431	.8535	
24	.3429	.3201	.3258	.9774	.884
Max	1.3717	1.2498	1.3889	1.2346	1.1888
Min	.3048	.2229	.3086	.2439	.2915
Avg	.6806	.6280	.7388	.6326	.6305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024053 / CHANNI

Feeder No / Name : 203 / 11 KV MALSUR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.3048	.6401	.5487	.4877
2	.7716	.6706	.6249	.5316	.4877
3	.7716	.6706	.6249	.5316	.4877
4	.7716	.6706	.6097	.5487	.5792
5	.7888	.6859	.6859	.583	.6401
6	.8916	.7926	.8078	.703	.7316
7	1.2003	.8993	1.0364	.8573	.7621
8	.7202	.5182	.703	1.2174	.7468
9	.6516	.5487	.6687	1.2174	.9297
10	.5144	.4572	.5316	1.0631	.381
11	.4287	.3963	.463	.884	.381
12	.3353	.3944	.4115	.823	.3963
13	.3048	.4115	.4115	.8078	.8078
14	.3201	.3944	.3658	.6554	.945
15	.3353	.4115	.2743	.8383	.945
16	.4268	.4801		.3048	.3258
17	.5182	.6001	.5487	.4725	.5316
18	.5792	.7202	.8573	.6706	.7716
19	.6859	.8573	.9088	.7621	.8745
20	.7011	.7888	.7888	.7468	.8573
21	.7011	.7716	.7545	.6859	.7716
22	.6554	.6097	.6516	.5944	.7202
23	.6097	.5944	.6173	.5487	
24	.7716	.6401	.5487	.5487	.5335
Max	1.2003	.8993	1.0364	1.2174	.945
Min	.3048	.3048	.2743	.3048	.3258
Avg	.6344	.5954	.6319	.7144	.6563

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024001 / 33 KV Dabki Sub Station

Feeder No / Name : 201 / 11 KV Rajeshwar Feeder SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.462	.4435	.4435	.4066	.3881
2	.4435	.4251	.4435	.4251	.3881
3	.4435	.4251	.4435	.4066	.3881
4	.4435	.4435	.4435	.4066	.4066
5	.4435	.4435	.4805	.4066	.4251
6	.5914	.5729	.5359	.5914	.6838
7	.8501	.8131	.7762	.8871	.7577
8	.8316	.8686	.8131	.961	.8316
9	.7762	.7947	.8686	.8871	.7392
10	.6099	.7392	.7577	.7207	.6838
11	.5914	.5544	.6838	.6468	.5359
12	.462	.5359	.5175	.462	.499
13	.4251	.462	.4435	.4251	.3881
14	.3881	.4066	.3881	.3881	.3696
15	.4066	.3881	.3696	.3696	.3881
16	.4066	.4251	.3881	.3326	
17	.4435	.4251	.4251	.3881	
18	.6283	.5729	.5359	.5729	
19	.6468	.6908	.6099	.6283	.6099
20	.6283	.6468	.6099	.5544	
21	.5544	.6099	.5729	.5729	
22	.5544	.5729	.499	.5359	
23	.499	.5359	.4435	.462	
24	.4805	.4435	.462	.4251	.4066
Max	.8501	.8686	.8686	.961	.8316
Min	.3881	.3881	.3696	.3326	.3696
Avg	.5421	.5516	.5398	.5359	.5229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024001 / 33 KV Dabki Sub Station

Feeder No / Name : 202 / 11KV MORNA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	12-DEC-17
HR	Load (MW)
24	.5121
Max	.5121
Min	.5121
Avg	.5121

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024001 / 33 KV Dabki Sub Station

Feeder No / Name : 204 / 11 KV Renuka Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.7922	.7545	.679	.679
2	.6979	.7733	.7356	.6979	.679
3	.7167	.7545	.7356	.6979	.679
4	.6979	.7545	.7545	.7167	.679
5	.7167	.7733	.7922	.6979	.6979
6	.9054	.9431	.8299	.9242	.9619
7	1.3769	1.3392	1.1883	1.358	1.3769
8	1.4003	1.4712	1.4003	1.3443	1.3817
9	1.3256	1.363	1.419	1.307	1.251
10	1.1088	1.0534	1.1949	1.1088	1.0642
11	.9694	.9145	1.1088	.8779	.924
12	.724	.7964	.9328	.6516	.7499
13	.724	.7421	.7783	.6379	.6154
14	.6767	.6878	.6697	.591	.5973
15	.6767	.6767	.6335	.6036	.5792
16	.6767	.7059	.6626	.5973	
17	.8048	.8326	.788	.695	
18	1.1523	1.1157	1.0317	1.0534	
19	1.1888	1.1888	1.0791	1.0425	1.1403
20	1.1458	1.1088	1.0059	1.0349	
21	1.1088	1.0534	.924	.9979	
22	1.0269	.9896	.8775	.8962	
23	.9054	.8865	.7733	.7733	
24	.7733	.811	.7922	.6979	.6979
Max	1.4003	1.4712	1.419	1.358	1.3817
Min	.6767	.6767	.6335	.591	.5792
Avg	.9273	.9386	.9109	.8618	.8679

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024001 / 33 KV Dabki Sub Station

Feeder No / Name : 205 / 11 KV Shivsena Vasahat SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.547	.5281	.5281	.4854	.4294
2	.5658	.5281	.5093	.4481	.4294
3	.6224	.5658	.5093	.5228	.4294
4	.6413	.5847	.5281	.5228	.4668
5	.679	.6602	.6224	.5601	.5415
6	.9619	.9335	.9054	.9522	1.0082
7	1.3014	1.2883	1.226	1.363	1.307
8	1.3203	1.307	1.4335	1.4563	1.3256
9	1.2449	1.2323	1.2637	1.2696	1.2254
10	1.1016	.9997	1.0562	1.1317	1.0829
11	.9149	.9054	.9808	.9522	.8962
12	.8775	.7842	.9054	.8962	.6348
13	.7468	.7095	.6908	.7282	.6908
14	.6348	.6348	.5788	.6722	.5975
15	.6535	.5788	.5788	.4854	.5041
16	.5975	.6161	.5788	.5415	
17	.6722	.6908	.6535	.6348	
18	.9335	.8865	.8215	.8402	
19	1.0269	.9431	.9335	.9522	.8962
20	.9054	.8299	.8589	.8589	
21	.7842	.7733	.7468	.7468	
22	.6908	.679	.6161	.6535	
23	.5847	.5847	.5228	.5415	
24	.5281	.5281	.5281	.4481	.4668
Max	1.3203	1.307	1.4335	1.4563	1.3256
Min	.5281	.5281	.5093	.4481	.4294
Avg	.8140	.7822	.7740	.7777	.7607

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024001 / 33 KV Dabki Sub Station

Feeder No / Name : 241 / 11KV DABKI I/C NO.1

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5154	1.6263	1.6787	1.2136	1.1273
2	1.4045	1.5524	1.6221	1.2136	1.1088
3	1.4415	1.5339	1.6032	1.251	1.1088
4	1.6263	1.5154	1.5844	1.2696	1.1643
5	1.7187	1.5154	1.5154	1.307	1.2567
6	2.4209	2.1807	1.8296	1.9231	2.0144
7	2.9754	2.5873	2.3655	2.6699	2.4579
8	3.2341	2.6242	2.6427	2.8006	2.5873
9	2.5503	2.6981	2.6981	2.6326	2.6057
10	2.4394	2.5688	2.5318	2.4209	2.4579
11	2.1807	2.2546	2.3101	2.1992	2.1068
12	2.1622	2.1068	2.1658	1.3491	1.848
13	1.9035	1.885	1.7556	1.6632	1.6078
14	1.6263	1.848	1.6632	1.6448	1.6448
15	1.6632	1.7556	1.6448	1.4045	1.5524
16	1.5893	1.885	1.6263	1.423	
17	1.848	1.922	1.7187	1.6263	
18	2.3101	2.1253	2.0725	2.0698	
19	2.4025	2.4646	2.1437	2.1437	2.1253
20	2.1253	2.0698	2.0513	1.9404	
21	1.848	1.9404	1.7187	1.7926	
22	2.0883	1.7187	1.4969	1.6263	
23	1.4969	1.848	1.3491	1.2936	
24	1.46	1.6078	1.423	1.1949	1.2567
Max	3.2341	2.6981	2.6981	2.8006	2.6057
Min	1.4045	1.5154	1.3491	1.1949	1.1088
Avg	2.0013	1.9931	1.8838	1.7531	1.7665

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024001 / 33 KV Dabki Sub Station

Feeder No / Name : 242 / 11 KV DABKI I/C NO.2

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.358	1.4146	1.3203	1.1694	1.1883
2	1.3203	1.3769	1.2826	1.1883	1.1883
3	1.3203	1.3392	1.2567	1.1883	1.1883
4	1.3203	1.3392	1.3014	1.1883	1.2071
5	1.3392	1.3769	1.3392	1.1883	1.1883
6	1.6032	1.5844	1.4335	1.5844	1.6032
7	2.3388	2.2445	2.0936	2.2445	2.1502
8	2.3525	2.3388	2.3152	2.1502	2.2634
9	2.2779	2.2218	2.2731	2.2634	2.1845
10	1.922	1.8665	2.1879	1.9418	1.8858
11	1.7741	1.7002	1.9418	1.6632	1.7187
12	1.4118	1.5384	1.6827	1.3253	1.4449
13	1.448	1.448	1.5023		1.2803
14	1.2851	1.2752	1.3306	1.1283	1.1523
15	1.2986	1.3032	1.2254	1.1403	1.086
16	1.3352	1.3394	1.3032	1.2127	
17	1.4327	1.4661	1.4998	1.3535	
18	2.0328	2.0513	1.8665	1.9404	
19	2.0668	2.1253	1.9204	1.9404	1.9936
20	1.9959	1.7926	1.7926	1.8111	
21	1.9035	1.8298	1.6632	1.7551	
22	1.7737	1.6617	1.5655	1.5684	
23	1.5844	1.5089	1.3392	1.3256	
24	1.3957	1.4523	1.3769	1.226	1.226
Max	2.3525	2.3388	2.3152	2.2634	2.2634
Min	1.2851	1.2752	1.2254	1.1283	1.086
Avg	1.6621	1.6498	1.6172	1.5434	1.5264

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024001 / 33 KV Dabki Sub Station

Feeder No / Name : 401 / 33KV I/C APATAPA TO DABKI SHEDDABLE RURAL
SOUR Feeder KV- 33 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8858	2.999	2.999	2.3765	2.32
2	2.7161	2.9424	2.9424	2.3765	2.32
3	2.7726	2.8292	2.8858	2.4331	2.32
4	2.9424	2.7726	2.8858	2.4331	2.3765
5	3.2253	2.8292	2.8858	2.6029	2.4897
6	3.7912	3.5648	3.5082	3.3951	3.7346
7	4.8663	5.3189	4.4136	4.8097	4.6399
8	5.6013	4.8663	4.8663	4.9794	4.9228
9	4.9291	5.036	4.9851	5.0926	4.8663
10	4.425	4.537	4.7051	4.425	4.4702
11	3.9918	3.9918	4.257	3.9209	3.8649
12	3.6037	3.6763	3.8809	2.7446	3.2487
13	3.4374	3.3819	3.271	2.9687	2.9938
14	2.9384	3.1047	3.0493	2.6886	2.8275
15	2.9938	3.0493	2.9938	2.5766	2.8275
16	3.0493	3.2156	2.9081	2.6886	2.9938
17	3.271	3.3471	3.0727	3.0247	
18	4.269	4.1581	4.0055	3.8809	
19	4.4907	4.6016	4.257	4.0472	4.2135
20	4.201	3.9769	3.9209	3.8649	
21	3.7912	3.7529	3.4168	3.5288	
22	3.5288	3.4517	3.1687	3.2253	
23	3.5082	3.2253	2.7726	2.7726	
24	2.8858	3.0556	2.8292	2.3765	2.4331
Max	5.6013	5.3189	4.9851	5.0926	4.9228
Min	2.7161	2.7726	2.7726	2.3765	2.32
Avg	3.6715	3.6535	3.5367	3.3014	3.3257

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024001 / 33 KV Dabki Sub Station

Feeder No / Name : 403 / 33 KV I/C KHADKI TO DABKI

Feeder KV- 33 / OUTGOING

DATE	10-DEC-17
HR	Load (MW)
13	3.271
Max	3.271
Min	3.271
Avg	3.271

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024029 / 33 KV Mohata Sub Station

Feeder No / Name : 201 / 11KV RPTS Feeder SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7762	.7842	.8215	.6908	.7023
2	.7762	.7468	.8029	.6722	.6653
3	.7392	.7468	.7842	.6722	.6653
4	.7762	.7468	.7468	.6722	.6653
5	.8131	.7842	.8402	.6722	.7762
6	1.1088	1.0456	1.0829	.9335	.924
7	1.4045	1.3817	1.3443	1.307	1.3306
8	1.5154	1.531	1.531	1.4937	1.5339
9	1.587	1.4937	1.4937	1.4937	1.4784
10	1.419	1.2323	1.4045	1.307	1.3443
11	1.643	1.1389	1.3676	1.1763	1.2323
12	1.643	1.1389	1.2012	1.0269	1.1827
13	1.6057	1.0456	.9979	1.0456	1.1576
14	1.0642	.8589	.9979	.9335	.9709
15	.8402	.8215	.8316	.8215	.8962
16	.8775	.9709	.924	.9795	.9335
17	1.1576	1.2323	1.0082	.9979	1.1576
18	1.4563	1.4937	1.4003	1.3491	1.4003
19	1.475	1.3817	1.2883	1.2936	1.419
20	1.1949	1.1763	1.1203	1.0534	1.2136
21	1.1016	1.1016	.9896	.9795	1.0829
22	.9709	.9896	.8962	.924	.8962
23	.8962	.8962	.8215	.8501	.8589
24	.8131	.8215	.8402	.7282	.7392
Max	1.643	1.531	1.531	1.4937	1.5339
Min	.7392	.7468	.7468	.6722	.6653
Avg	1.1523	1.0650	1.0640	1.0031	1.0511

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024029 / 33 KV Mohata Sub Station

Feeder No / Name : 204 / 11 KV Cotton Market

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4805	.4854	.5041	.4294	.4435
2	.4435	.4481	.4854	.4108	.4066
3	.4435	.4481	.4668	.4108	.4066
4	.4435	.4481	.4668	.4108	.4066
5	.4805	.4854	.4854	.4108	.4435
6	.5914	.5601	.6161	.4854	.5175
7	.7392	.7468	.7468	.6722	.7392
8	.7392	.7842	.9335	.7468	.7392
9	.9335	.8215	1.0082	.8215	.7762
10	.8215	.7842	1.0349	.8215	.7842
11	.9335	.7842		.6722	.7947
12	1.0456	.8215	1.0349	.7282	.7023
13	1.1949		.8131	.6722	.7392
14	.7842	.5975	.6653	.5975	.5975
15	.5975	.6161	.5914	.5415	.5975
16	.5975	.5975	.6653	.5359	.5601
17	.7468	.7095	.6161	.5914	.6908
18	.8215	.8215	.7762	.7392	.8215
19	.8589	.8962	.8589	.7392	.8029
20	.7468	.7468	.7282	.6653	.7095
21	.7095	.6722	.6348	.6283	.6535
22	.6348	.6348	.5788	.5914	.5975
23	.5975	.6161	.5228	.5175	.5228
24	.5175	.5228	.5228	.4854	.4435
Max	1.1949	.8962	1.0349	.8215	.8215
Min	.4435	.4481	.4668	.4108	.4066
Avg	.7043	.6543	.6851	.5969	.6207

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024029 / 33 KV Mohata Sub Station

Feeder No / Name : 205 / 11 KV Tajnapeth Feeder SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5544	.5601	.5975	.5228	.5544
2	.5544	.5228	.5975	.5041	.5175
3	.5175	.5228	.5601	.5041	.499
4	.5175	.5228	.5601	.5041	.4805
5	.5914	.5601	.5975	.5041	.4805
6	.6653	.6722	.6348	.6161	.6283
7	.7392	.7842	.7655	.7842	.8316
8	.8871	.7468		.7095	.8131
9	.9896	.8215	.9335	.8215	.8501
10	1.0456	.8215	.924	.8962	.924
11	1.0642	.8501	1.0349	.7842	.8316
12	1.1203	.8131	.924	.7655	.924
13	1.1203	.8589	.8131	.8215	.8316
14	.8215	.7468	.7023	.6722	.7023
15	.6348	.6722	.6283	.6348	.6908
16	.7095	.7095	.6653	.7023	.6653
17	.7842	.7392	.7095	.7392	.7468
18	.9335	.8962	.7947	.8316	.8962
19	.9335	.8962	.8131	.7392	.8402
20	.8589	.8215	.7468	.7392	.7842
21	.7842	.7282	.6908	.7392	.7468
22	.7468	.6722	.6722	.6283	.6908
23	.7095	.6535	.6348	.5914	.6348
24	.5914	.5975	.6099	.5601	.5914
Max	1.1203	.8962	1.0349	.8962	.924
Min	.5175	.5228	.5601	.5041	.4805
Avg	.7864	.7162	.7222	.6798	.7148

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024029 / 33 KV Mohata Sub Station

Feeder No / Name : 241 / 11KV MOHATA I/C NO.1

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3306	1.3443	1.363	1.1949	1.2012
2	1.2936	1.2696	1.3256	1.1576	1.1458
3	1.2567	1.2696	1.2883	1.1576	1.1458
4	1.2936	1.2696	1.2696	1.1576	1.1458
5	1.3306	1.3443	1.3817	1.1203	1.2567
6	1.7741	1.7177	1.7177	1.531	1.4784
7	2.2546	2.1658	2.0538	2.0911	2.1437
8	2.2916	2.3525	2.2779	2.3152	2.3285
9	2.4459	2.2405	2.2405	2.3152	2.2916
10	2.2592	2.0538	2.2177	2.1845	2.0911
11	2.4086	1.8298	2.1437	1.9231	1.9231
12	2.3899	1.8298	1.9404	1.7364	1.7926
13	2.2779	1.7364	1.6263	1.7177	1.7002
14	1.6804	1.4563	1.4784	1.531	1.4563
15	1.3817	1.363	1.386	1.419	1.3817
16	1.4377	1.5497	1.4784	1.5708	1.4003
17	1.7737	1.8858	1.587	1.5893	1.7177
18	2.2779	2.2965	2.1807	2.1807	2.1845
19	2.3339	2.2218	2.0911	2.1285	2.2032
20	1.9605	1.9044	1.8111	1.8111	1.9418
21	1.8298	1.8484	1.6617	1.6817	1.7551
22	1.6617	1.6617	1.531	1.5893	1.531
23	1.531	1.4937	1.3817	1.4045	1.4563
24	1.4045	1.419	1.4003	1.251	1.2567
Max	2.4459	2.3525	2.2779	2.3152	2.3285
Min	1.2567	1.2696	1.2696	1.1203	1.1458
Avg	1.8283	1.7302	1.7014	1.6566	1.6637

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024029 / 33 KV Mohata Sub Station

Feeder No / Name : 242 / 11 KV MOHATA I/C NO. 2

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0349	1.0456	1.1016	.9522	.9979
2	.9979	.9709	1.0829	.9149	.924
3	.961	.9709	1.0269	.9149	.9055
4	.961	.9709	1.0269	.9149	.8871
5	1.0719	1.0456	1.0829	.9149	.924
6	1.2567	1.2323	1.251	1.1016	1.1458
7	1.4784	1.531	1.5123	1.4563	1.5708
8	1.6263	1.531	1.7737	1.4563	1.5524
9	1.9231	1.643	1.9418	1.643	1.6263
10	1.8671	1.6057	1.9589	1.7177	1.7177
11	1.9978	1.643	1.0349	1.4563	1.6263
12	2.1658	1.643	1.9589	1.4937	1.6263
13	2.3152	1.6057	1.6263	1.4937	1.5708
14	1.6057	1.3443	1.3676	1.2696	1.307
15	1.2323	1.2883		1.1763	1.2883
16	1.307	1.307	1.3306	1.2382	1.2323
17	1.531	1.4563	1.3256	1.3306	1.4377
18	1.7551	1.7177	1.5708	1.5708	1.7177
19	1.7924	1.7924	1.8671	1.4784	1.643
20	1.6057	1.5684	1.475	1.4045	1.4937
21	1.4937	1.4003	1.3256	1.3676	1.4003
22	1.2689	1.307	1.251	1.2197	1.2883
23	1.307	1.2696	1.1576	1.1088	1.1576
24	1.1088	1.1203	1.1389	1.0456	1.0349
Max	2.3152	1.7924	1.9589	1.7177	1.7177
Min	.961	.9709	1.0269	.9149	.8871
Avg	1.4860	1.3754	1.3995	1.2767	1.3365

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024029 / 33 KV Mohata Sub Station

Feeder No / Name : 401 / 33KV APATAPA TO MOHATA S/S

I/C Feeder KV- 33 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.8809	3.8649	3.9363	3.5288	3.6591
2	3.6591	3.6408	3.77	3.4168	3.3819
3	3.5482	3.6408	3.6037	3.4168	3.3819
4	3.6037	3.6408	3.6408	3.4168	3.3819
5	3.8809	3.8089	3.77		3.4928
6	4.768	4.6491	4.425	4.201	4.2135
7	5.9877	5.9374	5.4332	5.7693	5.9322
8	6.3758	6.2734	6.154	6.1614	6.2094
9	6.9856	6.3295	6.4312	6.3855	6.4312
10	6.5975	6.1614	6.5421	6.154	6.1614
11	6.9302	5.8253	5.3778	5.5453	5.8253
12	6.7638	5.7133	6.0985	5.2115	5.4887
13	6.7776	5.4332	5.3224	5.1006	5.2115
14	5.3778	4.8171	4.6016	4.4907	4.5931
15	4.6491	4.537	4.3244	4.369	4.481
16	4.6571	4.8171	4.4907	4.6571	4.537
17	5.4893	5.2092	4.7611	4.8788	5.1006
18	6.8336	6.4866	6.1054	6.2094	6.4312
19	6.8896	6.5421	6.2734	5.9877	7.6509
20	5.9934	5.655	5.4893	5.5441	5.8768
21	5.6573	5.4887	5.0972	5.2115	5.3778
22	5.2092	5.0452	4.8171	4.9343	4.8788
23	4.7051	4.5931	4.257	4.2135	4.425
24	4.0472	4.145	4.1027	3.9043	3.8255
Max	6.9856	6.5421	6.5421	6.3855	7.6509
Min	3.5482	3.6408	3.6037	3.4168	3.3819
Avg	5.3862	5.0940	4.9510	4.9004	4.9979

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024029 / 33 KV Mohata Sub Station

Feeder No / Name : 402 / 33KV MOHATA TO VIDYUT B
S/S O/ Feeder KV- 33 / INCOMING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4969	1.4563	1.3717	1.4003	1.4415
2	1.386	1.4003	1.3717	1.3443	1.3306
3	1.3306	1.4003	1.3169	1.3443	1.3306
4	1.3306	1.4003	1.3443	1.3443	1.3306
5	1.4969	1.4003	1.3169	1.3443	1.3306
6	1.7187	1.6804	1.4815	1.5684	1.6078
7	2.2731	2.2405	1.8656	2.2405	2.2177
8	2.4394	2.4086	2.1399	2.4086	2.3285
9	2.4691	2.4646	2.2497	2.4086	2.4949
10	2.4691	2.5206	2.384	2.2497	2.3525
11	2.524	2.3525	2.2177	2.1399	2.2405
12	2.2497	2.2405	2.2177	1.9753	2.0513
13	2.1399	2.0725	2.0513	1.9204	1.9404
14	2.0851	2.0165	1.7741	1.701	1.8296
15	1.9753	1.9044	1.7187	1.7558	1.7924
16	1.9204	1.9605	1.6632	1.8296	1.9044
17	2.1845	1.8484	1.8484	1.9404	1.9753
18	2.8006	2.4691	2.2731	2.4394	2.524
19	2.7446	2.524	2.2965	2.384	2.5789
20	2.5206	2.1948	2.1845	2.3285	2.4691
21	2.3525	2.2497	2.1285	2.1622	2.2497
22	2.1845	2.0851	2.0165	2.1068	2.0851
23	1.8484	1.8107	1.7364	1.7187	1.7558
24	1.5524	1.6244	1.5912	1.5684	1.5524
Max	2.8006	2.524	2.384	2.4394	2.5789
Min	1.3306	1.4003	1.3169	1.3443	1.3306
Avg	2.0622	1.9886	1.8567	1.9010	1.9464

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024045 / 33/11 KV Collector Office

Feeder No / Name : 201 / 11KV Washim NAKA SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724		.7621	.6097	.6478
2	.724		.7621	.6097	.6478
3	.724		.7621	.6097	.6478
4	.724		.8192	.6097	.6478
5	.724		.8573	.6097	.6478
6	.9526		.9335	.8383	.9335
7	1.3146		1.1431	1.105	1.3146
8	1.2955		1.3717	1.1622	1.3527
9	1.3908	1.2193	1.3336	1.2384	1.3336
10	1.3336	1.2384	1.3908	1.3908	1.2765
11	1.3717	1.1241	1.2574	1.2574	1.1622
12	1.2765	1.0669	1.1812	1.0669	1.086
13	1.2955	1.0098	1.0288	.9907	1.0098
14	.9526	.8002	.8764		.8192
15	.8764	.8002	.8002		.8002
16	.8383	.9145	.8383		.7811
17	.9907	.9907	.9526	.9526	.9526
18	1.2955	1.3336	1.2574	1.2003	1.3146
19	1.3717	1.3146	1.2574	1.2574	1.3146
20	1.1622		1.086		1.1431
21	.9145	.8954	.8764		
22	.8954	.9335	.8002		.8383
23	.8002	.8383			.7811
24	.743		.8002	.6478	.6859
Max	1.3908	1.3336	1.3908	1.3908	1.3527
Min	.724	.8002	.7621	.6097	.6478
Avg	1.0288	1.0343	1.0064	.9504	.9625

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024045 / 33/11 KV Collector Office

Feeder No / Name : 202 / 11 KV Kholeshwar SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905		.1524	.1715	.1524
2	.1905		.1524	.1715	.1524
3	.1905		.1524	.1715	.1524
4	.1905			.1715	.1524
5	.1905		.1715	.1715	.1524
6	.2096		.1715	.1905	.1905
7	.2858		.2286	.2667	.2286
8	.2858		.2477	.362	.2667
9	.3429	.2858	.3048	.3429	.362
10	.3048	.2858	.362	.3239	.362
11	.2667	.2477	.3048	.3048	.3239
12	.2477	.2286	.2286	.2286	.2477
13	.2477	.2477	.1905	.2096	.2286
14	.1905	.2286	.2096	.1715	.1905
15	.1905	.1905	.1905	.1905	.1715
16	.1905	.2096	.1905	.1905	.2096
17	.1715	.2286	.1905	.2477	.2286
18	.2477	.2667	.2477	.2858	.2477
19	.2477	.2667	.2477	.2286	.2477
20	.2477	.2477	.2477		.2286
21	.2477	.2286			.2286
22	.2286	.2096	.1905		.2096
23	.2096	.1905			.1905
24	.1905		.1905	.1715	.1524
Max	.3429	.2858	.362	.362	.362
Min	.1715	.1905	.1524	.1715	.1524
Avg	.2294	.2375	.2177	.2286	.2199

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024045 / 33/11 KV Collector Office

Feeder No / Name : 203 / 11 KV Rajputpura SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143		.0953	.0953	.0953
2	.1143		.0953	.0953	.0953
3	.1143			.0953	.0953
4	.1143		.0953	.0953	.0953
5	.1143		.0953	.0953	.0953
6	.1143		.0953	.0953	.0953
7	.1334		.0953	.1143	.1143
8	.1715		.1143	.1524	.1143
9	.1143	.1334	.1143	.1715	.1334
10	.1905	.1715	.1905	.1905	.1905
11	.1715	.1715	.1524	.2477	.1715
12	.1905	.1524	.1524	.1905	.1524
13	.1905	.1524	.1334	.1905	.1524
14	.1715	.1334	.1334	.1524	.1524
15	.1905	.1334	.1143	.1524	.1524
16	.1524	.1143	.1143	.1334	.1334
17	.1715	.1334	.1143	.1524	.1524
18	.1905	.1524	.1715	.1715	.1905
19	.2096	.1905	.1524	.1905	.1905
20	.1715	.1905	.1524		.1715
21	.1524	.1524			
22	.1334	.1334	.1143		.1334
23	.1143	.1334			.1143
24	.1143		.1143	.0953	.0953
Max	.2096	.1905	.1905	.2477	.1905
Min	.1143	.1143	.0953	.0953	.0953
Avg	.1508	.1499	.1243	.1439	.1342

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024045 / 33/11 KV Collector Office

Feeder No / Name : 204 / 11 KV NEW CLOTH MARKET SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191		.3429	.4191	.4191
2	.4191		.3429	.4191	.4191
3	.4191		.3429	.4191	.4191
4	.4191		.3429	.4191	.4191
5	.4191		.3429	.4191	.4191
6	.362		.3429	.362	.3429
7	.4382		.3429	.4001	.4191
8	.4191		.4001	.4191	.4001
9	.4954	.4382	.4572	.4954	.4763
10	.5716	.4954	.5144	.5906	.6478
11	.9145	.8002	.724	.8573	.8573
12	1.0479	.8573	.8002	.8764	.9145
13	1.1241	.8573	.8383	.9145	.9335
14	1.0098	.8002	.8192	.9526	1.1622
15	.9526	.8383	.7621	.8954	.9145
16	.8954	.8192	.7621	.8954	.8764
17	.9526	.8573	.8002	.9526	.9717
18	1.1431	1.105	1.0288	1.086	1.105
19	1.105	1.105	1.0098	1.086	1.086
20	.9335	1.0288	.9335		1.0098
21	.6478	.7049			.7049
22	.4954	.5525	.5335		.5335
23	.4572	.4382			.4382
24	.4191		.4191	.4382	.4572
Max	1.1431	1.105	1.0288	1.086	1.1622
Min	.362	.4382	.3429	.362	.3429
Avg	.6867	.7799	.6001	.6659	.6811

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024045 / 33/11 KV Collector Office

Feeder No / Name : 205 / 11 KV Dana Bazar SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381		.3239	.3429	.362
2	.381		.3239	.3429	.362
3	.381		.3239	.3429	.362
4	.381		.3239	.3429	.362
5	.381		.3429	.3429	.362
6	.362		.3429	.3429	.3429
7	.381		.3429	.3429	.362
8	.4382			.4001	.4001
9	.6097	.4382	.4763	.4191	.5525
10	.6097	.5716	.5144	.6097	.6478
11	.8383	.6668	.6097	.6859	.6668
12	.8764	.6668	.6478	.6859	.6859
13	.8764	.6478	.6668	.6668	.7049
14	.8002	.6668	.5716	.6478	.6668
15	.6478	.6287	.5335	.5716	.5906
16	.6097	.5906	.5335	.724	.5716
17	.6668	.6478	.5906	.7621	.6859
18	.8192	.8192	.6859		.8192
19	.8192	.8002	.7049	.8383	.8192
20	.7621	.743	.6478		.7811
21	.6097	.6097			.6287
22	.4572	.4382	.4001		.4191
23	.4001	.381			.4001
24	.381		.3429		.362
Max	.8764	.8192	.7049	.8383	.8192
Min	.362	.381	.3239	.3429	.3429
Avg	.5779	.6211	.4881	.5229	.5382

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024045 / 33/11 KV Collector Office

Feeder No / Name : 206 / 11 KV COLLECTOR OFFICE SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191		.0191	.0191	.0191
2	.0191		.0191		.0191
3	.0191		.0191		.0191
4	.0191				.0191
5	.0191		.0191	.0191	.0191
6	.0191		.0191		.0191
7	.0191		.0191		.0191
8	.0191		.0191		.0191
9	.0191	.0191	.0191	.0191	.0191
10	.0191	.0191	.0191	.0191	.0381
11	.0572	.0191	.0191	.0572	.0381
12	.0572	.0191	.0191	.0572	.0381
13	.0572	.0191	.0191	.0762	.0381
14	.0572	.0191	.0191	.0572	.0381
15	.0572	.0191	.0191	.0381	.0381
16	.0572	.0191	.0191	.0572	.0381
17	.0572	.0191	.0191	.0572	.0381
18	.0381	.0191	.0191	.0381	.0381
19	.0191	.0191	.0191	.0191	.0381
20	.0191	.0191	.0191		.0381
21	.0191	.0191	.0191		.0191
22	.0191	.0191	.0191		.0191
23	.0191	.0191			.0191
24	.0191		.0191	.0191	.0191
Max	.0572	.0191	.0191	.0762	.0381
Min	.0191	.0191	.0191	.0191	.0191
Avg	.0310	.0191	.0191	.0395	.0278

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024045 / 33/11 KV Collector Office

Feeder No / Name : 241 / 11 KV COLLECTOR OFFICE I/C

NO. Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	.9717	1.0098	.8764	.8954
2	1.0288	.9717	1.0098	.8764	.8954
3	1.0288	.9717	1.0098	.8764	.8954
4	1.0288	.9717	1.0669	.8764	.8954
5	1.0288	.9717	1.086	.8764	.8954
6	1.2765	1.2384	1.2003	1.1241	1.2193
7	1.7337	1.4861	1.5051	1.4861	1.6575
8	1.7528	1.7528		1.6766	1.7337
9	1.848	1.6385	1.7528	1.9433	1.829
10	1.829	1.6956	1.9433	1.9052	1.829
11	1.8099	1.5432	1.7147	1.8099	1.6575
12	1.7147	1.448	1.5623	1.4861	1.4861
13	1.7337	1.4098	1.3527	1.3908	1.3908
14	1.3146	1.1622	1.2193	1.2003	1.1622
15	1.2574	1.1241	1.105	1.105	1.1241
16	1.1812	1.2384	1.1431	1.1622	1.1241
17	1.3336	1.3527	1.2574	1.3527	1.3336
18	1.7337	1.7528	1.6766	1.6575	1.7528
19	1.829		1.6575	1.6766	1.7528
20	1.5813	1.5813	1.4861		1.5432
21	1.3146	1.2765	1.2384		1.2955
22	1.2574	1.2765	1.105		1.1812
23	1.1241	1.1622			1.086
24	1.0479	1.0098	1.105	.9145	.9335
Max	1.848	1.7528	1.9433	1.9433	1.829
Min	1.0288	.9717	1.0098	.8764	.8954
Avg	1.4090	1.3047	1.3276	1.3136	1.3154

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024045 / 33/11 KV Collector Office

Feeder No / Name : 242 / 11KV COLLECTOR OFFICE I/C
NO.2 Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8192	.8002	.6859	.7811	.8002
2	.8192	.8002	.6859	.7811	.8002
3	.8192	.8002	.6859	.7811	.8002
4	.8192	.8002	.6859	.7811	.8002
5	.8192	.8002	.6859	.7811	.8002
6	.743	.724	.6859	.724	.7049
7	.8383	.8002	.7049	.7621	.8002
8	.8764	.8192		.8383	.8192
9	.9717	.8954	.9526	.9335	1.0479
10	1.2003	1.086	1.0479	1.2193	1.3336
11	1.8099	1.4861	1.3527	1.6004	1.5623
12	1.9814	1.5432	1.4861	1.6194	1.6385
13	2.0576	1.5242	1.5432	1.6575	1.6766
14	1.8671	1.4861	1.4098	1.6575	1.8671
15	1.7909	1.4861	1.3146	1.5051	1.5432
16	1.5623	1.4289	1.3146	1.5623	1.4861
17	1.6766	1.5242	1.4098	1.7337	1.6956
18	2.0005	1.9433	1.7337	1.8861	1.9624
19	1.9433	1.9243	1.7337	1.9433	1.9433
20	1.7147	1.7909	1.6004		1.829
21	1.2765	1.3336	1.2955		1.3527
22	.9717	1.0098	.9526		.9717
23	.8764	.8383			.8573
24	.8192	.8002	.7811	.8002	.8383
Max	2.0576	1.9433	1.7337	1.9433	1.9624
Min	.743	.724	.6859	.724	.7049
Avg	1.2947	1.1852	1.1249	1.2174	1.2471

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024045 / 33/11 KV Collector Office

Feeder No / Name : 401 / 33KV APATAPA TO COLLECTOR

I/C Feeder KV- 33 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8861	1.829	1.6575	
2	1.8861	1.829	1.6575	
3	1.8861	1.829	1.6575	
4	1.8861	1.829	1.7147	
5	1.8861	1.829	1.7147	
6	2.1148	2.0576	1.7147	
7	2.6863	2.3434	2.0005	
8	2.7435	2.6863	2.4006	
9	2.915	2.5149	2.5149	
10	3.0293	2.8006		
11	3.6008	3.0293		
12	3.7151	3.2007		
13	3.7723	2.915		
14	3.2007	2.6292		
15	3.0293	2.5149		
16	2.7435	2.6292		
17	3.0293	2.8578		
18	3.7151	3.7151		
19	3.7723	3.5437		
20	3.315	3.315		
21		2.6292		
22	2.572	2.1719		
23	2.0576	1.9433		
24	1.9433	1.8861	1.7718	.0572
Max	3.7723	3.7151	2.5149	.0572
Min	1.8861	1.829	1.6575	.0572
Avg	2.7559	2.5220	1.8804	.0572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024045 / 33/11 KV Collector Office

Feeder No / Name : 402 / 33 KV TUKARAM TO COLLECTOR
S/S Feeder KV- 33 / OUTGOING

DATE	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1		1.7147	1.7718
2		1.7147	1.7718
3		1.7147	1.7718
4		1.7147	1.7718
5		1.7147	1.7718
6		1.8861	2.0005
7		2.3434	2.5149
8		2.8006	2.6292
9		2.9721	2.6292
10	2.9721	2.915	2.915
11	3.0864	3.1436	3.0293
12	3.0293	2.9721	2.1148
13	2.915	2.915	2.8578
14	2.6292	2.8578	2.6863
15	2.4006	2.5149	2.572
16	2.5149	2.6292	2.572
17	2.7435	3.0864	2.8006
18	3.4865	3.5437	3.5437
19	3.4865	3.5437	3.5437
20	3.2007		3.2007
21	2.6863	2.5149	2.572
22	2.0005	2.0576	2.2291
23		1.9433	2.0005
24		1.7718	1.829
Max	3.4865	3.5437	3.5437
Min	2.0005	1.7147	1.7718
Avg	2.8578	2.4776	2.4625

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024048 / 33/11 KV Shivaji Nagar Sub-
staFeeder No / Name : 201 / 11KV Bhim Nagar Feeder
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3944	.3841	.4108	.3547	.3292
2	.3772	.3841	.4108	.3361	.3292
3	.3772	.3841	.4108	.3361	.3292
4	.4108	.3841	.4108	.3361	.3292
5	.4481	.4207	.4854	.3734	.3658
6	.5415	.5853	.5228	.4854	.5487
7	.679	.7133	.6348	.6348	.7133
8	.7655	.695	1.363	.7095	.8048
9	.8029	.695	.7842	.7468	.8048
10	.6859	.6722	.7316	.695	.6516
11	.6859	.5975	.6036	.5487	.5487
12	.6173	.5415	.567	.4572	.5487
13	.583	.4854	.5121	.4755	.4801
14	.4115	.4481	.4024	.3841	.3772
15	.3429	.4481	.4024	.3658	.4108
16	.3772	.3734	.439	.4024	.4481
17	.4458	.4481	.4755	.439	.5228
18	.6584	.6516	.6535	.567	.6584
19	.6219	.6001	.5788	.6036	.6036
20	.6036	.5316	.5228	.5121	.5487
21	.5121	.5228	.4854	.4572	.4938
22	.4938	.5228	.4668	.439	.4668
23	.4572	.4481	.4108	.4108	
24	.4115	.4207	.4108	.3734	.3658
Max	.8029	.7133	1.363	.7468	.8048
Min	.3429	.3734	.4024	.3361	.3292
Avg	.5294	.5149	.5457	.4768	.5078

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024048 / 33/11 KV Shivaji Nagar Sub-
staFeeder No / Name : 202 / 11KV Tilak Road Feeder
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2561	.2614	.2641	.2561
2	.2401	.2561	.3174	.2452	.2561
3	.2401	.2561	.2614	.2452	.2561
4	.2641	.2561	.2614	.2452	.2561
5	.2641	.2561	.2614	.2641	.2561
6	.2829	.2926	.2614	.2829	.2561
7	.2829	.2743	.2987	.3018	.3109
8	.3018	.3109	.2987	.2829	.2926
9	.3395	.3292	.2987	.3395	.3475
10	.3429	.3734	.3475	.3841	.3944
11	.4287	.5601	.3658	.5853	.5487
12	.7545	.703	.4207	.7682	.6516
13	.7545	.6859	.4024	.7316	.7202
14	.6173	.7202	.4207	.6219	.6516
15	.6173	.7202	.4024	.6584	.7095
16	.7545	.6859	.3841	.695	.7468
17	.7545	.7716	.4024	.4207	.7842
18	.9511	.823	.4904	.8596	.8048
19	.9328	.823	.4715	.8779	.7499
20	.7316	.6001	.4527	.7316	.6767
21	.5487	.4854	.3772	.439	.4572
22	.3292	.3361	.3018	.3109	.2987
23	.2743	.2801	.2829	.2987	
24	.2401	.2561	.3174	.2641	.2561
Max	.9511	.823	.4904	.8779	.8048
Min	.2401	.2561	.2614	.2452	.2561
Avg	.4787	.4713	.3484	.4632	.4756

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024048 / 33/11 KV Shivaji Nagar Sub-
staFeeder No / Name : 204 / 11KV Bhandpura Feeder
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.463	.4572	.5041	.4294	.439
2	.4458	.4572	.5041	.4294	.439
3	.4458	.4572	.5041	.4294	.439
4	.4904	.4572	.5228	.4294	.439
5	.5281	.5304	.5975	.4854	.4755
6	.7545	.6401	.6535	.6348	.5853
7	.9054	.8779	.8589	.8589	.8779
8	.9808	.9328	.9709	.8962	.9328
9	.9431	.8779	.9335	.8589	.8779
10	.7888	.8589	.8779	.8048	.7545
11	.823	.7842	.8048	.6767	.6859
12	.7202	.6173	.7133	.6584	.6173
13	.6859	.583	.6219	.6584	.583
14	.583	.5144	.5304		.4801
15	.0857	.5144	.5121	.5121	.4854
16	.6173	.5487	.567	.5121	.4854
17	.6516	.5144	.6584	.6036	.6348
18	.8413	.7888	.8402	.8215	.8048
19	.8413	.7373	.7842	.7499	.7682
20	.7316	.6344	.7095	.6584	.6584
21	.6584	.6722	.6161	.6219	.6036
22	.6219	.6348	.5601	.5487	
23	.5487	.5975	.5228	.4755	
24	.4801	.5121	.5041	.4481	.4572
Max	.9808	.9328	.9709	.8962	.9328
Min	.0857	.4572	.5041	.4294	.439
Avg	.6515	.6333	.6613	.6175	.6147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024048 / 33/11 KV Shivaji Nagar Sub-
staFeeder No / Name : 205 / 11 KV Ganesh Nagar Feeder SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.5121	.5601	.4805	.4572
2	.463	.5121	.5601	.462	.4572
3	.4801	.5121	.5601	.462	.4572
4	.5175	.5121	.5975	.462	.4572
5	.5359	.5487	.6348	.4805	.4938
6	.7207	.823	.6722	.6099	.6584
7	.8871	.8779	.8215	.8686	.8413
8	1.0164	1.0059	1.0642	.9795	1.0425
9	1.0349	1.0059	1.1016	1.0164	1.0974
10	.8059	.8775	1.0242	.8962	.8573
11	.823	.7655	.8596	.7682	.6173
12	.6344	.6722	.7316	.6219	.6001
13	.6859	.6908	.6401	.6036	.5487
14	.5487	.5788	.5853	.5853	.4801
15	.5144	.5601	.5304	.5121	.5041
16	.5144	.5601	.4938	.5487	.5788
17	.583	.5658	.6036	.6036	.6348
18	.8413	.7888	.8316	.8029	.8048
19	.8779	.8059	.7947	.8048	.8413
20	.823	.7373	.7762	.7865	.8048
21	.7682	.7468	.7392	.7499	.7499
22	.7316	.6908	.6653	.6584	.6722
23	.6219	.6348	.5544	.567	
24	.5144	.567	.5601	.5175	.5121
Max	1.0349	1.0059	1.1016	1.0164	1.0974
Min	.463	.5121	.4938	.462	.4572
Avg	.6843	.6897	.7068	.6603	.6595

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024048 / 33/11 KV Shivaji Nagar Sub-
staFeeder No / Name : 206 / 11 KV Shivji Nagar Feeder SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2012	.2054	.2033	.2012
2	.1886	.2012	.2054	.1848	.2012
3	.1886	.2012	.2054	.1848	.2012
4	.2033	.2012	.2054	.1848	.2012
5	.2218	.2012	.2054	.2033	.2012
6	.2587	.2926	.2241	.2587	.2743
7	.2957	.3292	.2987	.3881	.3841
8	.3142	.2743	.2987	.4066	.4024
9	.3326	.3109	.3547	.3326	.3841
10	.2743	.2987	.3109	.3292	.3429
11	.3086	.2801	.2743	.3109	.2915
12	.2229	.2614	.2195	.2926	.2743
13	.1886	.2054	.2195	.2743	.2743
14	.1886	.1867	.2012	.2378	.2229
15	.1543	.1867	.1829	.2195	.2427
16	.1886	.2241	.1829	.2195	.2427
17	.2229	.2058	.2378	.2378	.2801
18	.3109	.2915	.2957	.3174	.3292
19	.2926	.2743	.3142	.3109	.3292
20	.2926	.2743	.2957	.2926	.3292
21	.2926	.2614	.2587	.3109	.2926
22	.2561	.2427	.2402	.2561	.2801
23	.2195	.2427	.2402	.2427	
24	.2058	.2012	.2054	.2033	.2012
Max	.3326	.3292	.3547	.4066	.4024
Min	.1543	.1867	.1829	.1848	.2012
Avg	.2428	.2438	.2451	.2668	.2776

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024048 / 33/11 KV Shivaji Nagar Sub-
sta

Feeder No / Name : 241 / 11 KV Shivji Nagar I/C No.

1 Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6344	.6401	.6722	.6224	.5853
2	.6173	.6401	.6722	.5847	.5853
3	.6173	.6401	.6722	.5847	.5853
4	.679	.6401	.6722	.5847	.5853
5	.7167	.6767	.7468	.6413	.6219
6	.8299	.8779	.7842	.7733	.8048
7	.9619	.9877	.9335	.9431	1.0242
8	1.0751	1.0059	1.1016	.9997	1.0974
9	1.1506	1.0242	1.0829	1.094	1.1523
10	1.0288	1.0456	1.0791	1.0791	1.046
11	1.1145	1.1576	.9694	1.134	1.0974
12	1.3717	1.2003	.9877	1.2254	1.2003
13	1.3375	1.1317	.9145	1.2071	1.2003
14	1.0288	1.1317	.823	1.0059	1.0288
15	.9602	1.1317	.8048	1.0242	1.1203
16	1.1317	1.0288	.823	1.0974	1.1949
17	1.2003	1.1831	.8779	.8596	1.307
18	1.6095	1.4746	1.1506	1.4563	1.4632
19	1.5546	1.4232	1.0562	1.4815	1.3535
20	1.3352	1.1317	.9808	1.2437	1.2254
21	1.0608	1.0082	.8676		.9511
22	.823	.8589	.7733	.7499	.7655
23	.7316	.7282	.6979	.695	
24	.6516	.6767	.6722	.6413	.6219
Max	1.6095	1.4746	1.1506	1.4815	1.4632
Min	.6173	.6401	.6722	.5847	.5853
Avg	1.0093	.9769	.8673	.9447	.9834

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024048 / 33/11 KV Shivaji Nagar Sub-
staFeeder No / Name : 242 / 11 KV Shivji Nagar I/C No.
2 Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1488	1.1706	1.2696	1.1203	1.0974
2	1.0974	1.1706	1.2696	1.0829	1.0974
3	1.1145	1.1706	1.2696	1.0829	1.0974
4	1.2136	1.1706	1.3256	1.0829	1.0974
5	1.2883	1.2803	1.4377	1.1763	1.1706
6	1.7364	1.7558	1.5497	1.5123	1.5181
7	2.0911	2.0851		2.1285	2.1033
8	2.3152	2.2131	2.3339	2.2965	2.3777
9	2.3152	2.1948	2.3899	2.2218	2.3594
10	1.869	2.0351	2.2131	2.0302	1.9547
11	1.9547	1.8298	1.9387	1.7558	1.5947
12	1.5775	1.4746	1.6644	1.5729	1.4918
13	1.5604	1.406	1.4815	1.5364	1.406
14	1.3203	1.2174	1.3169	.823	1.1831
15		1.2003	1.2254	1.2437	1.2323
16	1.3203	1.2689	1.2437	1.2803	1.307
17	1.4575	1.286	1.4998	1.4449	1.5497
18	1.9936	1.869	1.9791	1.9418	1.9387
19	2.0119	1.8176	1.9044	1.8656	1.9387
20	1.8473	1.6461	1.7924	1.7375	1.7924
21	1.7193	1.6804	1.6244	1.6827	1.6461
22	1.6095	1.5684	1.475	1.4632	1.531
23	1.39	1.475	1.3256	1.2803	
24	1.2003	1.2803	1.2696	1.1763	1.1706
Max	2.3152	2.2131	2.3899	2.2965	2.3777
Min	1.0974	1.1706	1.2254	.823	1.0974
Avg	1.6153	1.5528	1.6000	1.5225	1.5502

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024055 / P.K.V. Washim Road, Sub

Statio

Feeder No / Name : 201 / 11 KV Gajraj Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168	.168	.168	.1494	.1494
2	.168	.168	.1494	.1494	.1494
3	.168	.168	.168	.1494	.1494
4	.168	.1867	.1494	.1494	.1867
5	.168	.1867	.168	.1494	.1867
6	.1867	.2241	.168	.1867	.2241
7	.1867	.2427	.1867	.2263	.2241
8	.2427	.2241	.2614	.2261	.2054
9	.2241	.2241	.2241	.2241	.2427
10	.2987	.2801	.2614	.2263	.2241
11	.2641	.2427	.2801	.2241	.2427
12	.3174	.2614	.2614	.2075	.2801
13	.3018	.2829	.2427	.1867	.3174
14	.2427	.2452	.2241	.1886	.2614
15	.2641	.2641	.2241	.1494	.2987
16	.2829	.2987	.2614	.1698	.2614
17	.3018	.2987	.2641	.168	.2614
18	.3361	.3361	.2829	.2241	.2801
19	.2801	.2614	.2452	.2241	.2987
20	.2427	.2241	.2054	.2054	.2801
21	.1867	.1867	.1886	.168	.2054
22	.168	.2054	.1698	.168	.168
23	.168	.168		.1494	.1509
24	.168	.168	.168	.1509	.1494
Max	.3361	.3361	.2829	.2263	.3174
Min	.168	.168	.1494	.1494	.1494
Avg	.2293	.2298	.2140	.1842	.2249

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024055 / P.K.V. Washim Road, Sub

Statio

Feeder No / Name : 202 / 11 KV Kamala Nagar Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4481	.4854	.5041	.4527	.3734
2	.4481	.4854	.4854	.415	.3734
3	.4481	.4854	.4854	.4108	.4108
4	.4481	.5601	.5041	.415	.4481
5	.4854	.6348	.5041	.5281	.4854
6	.6161	.7468	.5601	.5788	.6722
7	.8402	.7842	.7095	.7733	.7095
8	.8402	.8402	.8402	.8299	.6908
9	.8589	.8029	.7842	.7655	.7468
10	.9335	.8215	.7842	.7655	.8029
11	.9242	.7842	.7842	.6161	.6908
12	.811	.5788	.7468	.5658	.5975
13	.7468	.7167	.6348	.4904	.5788
14	.5975	.6413	.5788	.5281	.5041
15	.5847	.6036	.5415	.4338	.4854
16	.5847	.5601	.5601	.4527	.5041
17	.6602	.6348	.547	.5601	.5788
18	.7842	.7282	.7167	.6348	.7655
19	.8962	.8215	.8299	.7095	.8029
20	.8589	.7655	.7167	.7095	.7468
21	.6348	.5975	.6036	.5788	.5975
22	.5975	.5788	.5847	.4854	.5975
23	.5601	.3734	.5281	.4668	.5415
24	.4668	.4854	.5041	.4527	.3734
Max	.9335	.8402	.8402	.8299	.8029
Min	.4481	.3734	.4854	.4108	.3734
Avg	.6698	.6465	.6266	.5675	.5866

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024055 / P.K.V. Washim Road, Sub

Statio

Feeder No / Name : 203 / 11 KV Akoli

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.2614	.2054	.168	.1867
2	.2054	.2614	.1867	.1698	.1867
3	.2054	.2614	.168	.1698	.1867
4	.2054	.3174	.168	.1698	.2241
5	.2241	.3361	.1867	.1886	.2241
6	.2614	.3734	.2241	.2641	.3174
7	.4108	.3734	.3174	.3734	.3361
8	.4668	.3921	.3921	.415	.4108
9	.4294	.4108	.4108	.4108	.4294
10	.4294	.3921	.4481	.3961	.4294
11	.3961	.3547	.4481	.3734	.3921
12	.3361	.3174	.3734	.3361	
13	.3174	.2641		.2987	.2987
14	.2641	.2641	.2801	.2801	.2614
15	.2641	.2452	.2801		.2801
16	.2452	.2241	.2614	.2452	.2614
17	.2829	.2427	.2987	.2241	.2614
18	.3361	.3361	.3584	.3361	.3584
19	.3734	.3174	.3584	.3361	.3734
20	.3734	.3361	.3361	.3361	.3361
21	.3174	.2801	.3206	.2801	.2614
22	.2801	.2987	.2829	.2054	.2614
23	.2614	.2241		.1867	.2054
24	.2054	.2614	.2054	.1886	.1867
Max	.4668	.4108	.4481	.415	.4294
Min	.2054	.2241	.168	.168	.1867
Avg	.3040	.3061	.2960	.2762	.2900

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024055 / P.K.V. Washim Road, Sub

Statio

Feeder No / Name : 241 / 11 KV PKV I/C No. 1

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6161	.6535	.6535	.5975	.5228
2	.6161	.6535	.6348	.5658	.5228
3	.6161	.6535	.6535	.5658	.5601
4	.6161	.7468	.6535	.5658	.6348
5	.6535	.8215	.6722	.6036	.6722
6	.8029	.9709	.7282	.7655	.8589
7	1.0269	1.0269	.8962	.9997	.9335
8	1.0829	1.0642	1.1016	1.0562	1.1016
9	1.0829	1.0269	1.0082	.9896	.9896
10	1.2323	1.1016	1.0456	.9997	1.0269
11	1.1883	1.0269	1.0642	.8402	.9335
12	1.1203	.8402	1.0082	.7733	.8775
13	1.0456	.9997	.8775	.679	.8962
14	.8402	.8865	.8029	.7167	.7655
15	.8488	.8676	.7655		.7842
16	.8676	.8589	.8215	.6224	.7655
17	.9619	.9335	.811	.7282	.8402
18	1.1203	1.0642	.9997	.8589	1.0562
19	1.1763	1.0829	1.0751	.9335	1.1016
20	1.1016	.9896	.9242	.9149	1.0269
21	.8215	.7842	.7922	.7468	.8029
22	.7655	.7842	.7545	.6535	.7733
23	.7282	.6908		.6161	.6908
24	.6348	.6468	.6722	.6036	.5228
Max	1.2323	1.1016	1.1016	1.0562	1.1016
Min	.6161	.6468	.6348	.5658	.5228
Avg	.8986	.8823	.8442	.7564	.8192

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024055 / P.K.V. Washim Road, Sub
StatioFeeder No / Name : 242 / 11 KV PKV I/C No. 2
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.2614	.2054	.1698	.1867
2	.2054	.2614	.1867	.1698	.1867
3	.2054	.2614	.168	.1698	.1867
4	.2054	.3174	.168	.1698	.2241
5	.2241	.3361	.1867	.1886	.2241
6	.2614	.3734	.2241	.2614	.3174
7	.4108	.3734	.3174	.3772	.3361
8	.4668	.3921	.3921		.4108
9	.4294	.4108	.4108	.4108	.4294
10	.4294	.3921	.4481	.3961	.4294
11	.3961	.3547	.4481	.3734	.3921
12	.3361	.3174	.3734	.3395	.3174
13	.3174	.2641	.3174	.3018	.2987
14	.2641	.2641	.2801	.2829	.2614
15	.2641	.2452	.2801	.2452	.2801
16	.2452	.2241	.2614	.2452	.2614
17	.2829	.2427	.3018	.2241	.2614
18	.3361	.3361	.3584	.3361	.3584
19	.3734	.3174	.3584	.3361	.3734
20	.3734	.3361	.3547	.3361	.3361
21	.3174	.2801	.3206	.2801	.2614
22	.2801	.2987	.2829	.2054	.2641
23	.2614	.2241		.1867	.2054
24	.2054	.2614	.2054	.1886	.1867
Max	.4668	.4108	.4481	.4108	.4294
Min	.2054	.2241	.168	.1698	.1867
Avg	.3040	.3061	.2978	.2693	.2912

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024055 / P.K.V. Washim Road, Sub

Statio

Feeder No / Name : 402 / 33 KV Incommmer No.2

Khadaki to Feeder KV- 33 /

INCOMING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8402	.9522	.8402	.7842	.6722
2	.8402	.9522	.8402	.7282	.6722
3	.8402	.9522	.8402	.7282	.7282
4	.8402	1.0642	.8402	.7282	.8402
5	.8962	1.1763	.8402	.7922	.8962
6	1.0642	1.3443	.9522	1.0082	1.2323
7	1.4003	1.4003	1.2323	1.358	1.2883
8	1.5123	1.4563	1.5123	1.4712	1.5123
9	1.5123	1.4003	1.4003	1.4146	1.4563
10	1.6804	1.5123	1.5123	1.4003	1.4563
11	1.5844	1.3443	1.5123	1.2323	1.3443
12	1.4563	1.1763	1.4003	1.1317	1.1763
13	1.4003	1.3014	1.2323	.9619	1.1763
14	1.1317	1.1317	1.1203	1.0185	1.0082
15	1.1317	1.1317	1.0642	.8488	1.0642
16	1.1317	1.1203	1.1203	.8488	1.0082
17	1.2449	1.1763	1.0751	.9522	1.1203
18	1.4563	1.4003	1.358	1.1763	1.4003
19	1.5684	1.4003	1.4146	1.2883	1.4563
20	1.5123	1.3443	1.2323	1.2323	1.3443
21	1.1763	1.0642	1.1317	1.0082	1.0642
22	1.0642	1.0642	1.0185	.8962	1.0185
23	1.0082	.8962		.7842	.8962
24	.8402	.9522	.8962	.7922	.6722
Max	1.6804	1.5123	1.5123	1.4712	1.5123
Min	.8402	.8962	.8402	.7282	.6722
Avg	1.2139	1.1964	1.1472	1.0244	1.1043

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 201 / 11 KV KHADKI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0692	1.0498	1.086	1.0059	.9145
2	1.1157	1.0136	1.0498	1.0425	.8688
3	1.0317	1.0136	1.0498	1.0425	.8688
4	1.0277	1.0498	1.0498	1.0608	.8688
5	1.0608	1.1222	1.086	1.1888	.9774
6	1.4083	1.4118	1.1946	1.39	1.2308
7	1.5912	1.7375	1.6289	1.9753	1.6651
8	1.7741	1.7013	1.7924	1.7558	1.6651
9	1.6289	1.7924	1.8099	1.7375	1.5927
10	1.5546	1.4998	1.6118	1.5565	1.4449
11	1.3169	1.3756	1.448	1.267	1.2536
12	1.1706	1.1393	1.2308	1.1584	1.1462
13	1.0608	1.134	1.1222	.9774	1.0425
14	.9593	1.0425	.9774	.9593	.9511
15	.8779	.9328	.9774	.8596	.8962
16	.9877	1.0317	.9412	.8954	.9145
17	1.1584	1.086	.9991	1.0136	1.0745
18	1.576	1.5565	1.4899	1.4842	1.4685
19	1.6289	1.6289	1.5581	1.5927	1.6289
20	1.5927	1.5927	1.6108	1.5565	1.5043
21	1.4842	1.4842	1.3937	1.4118	1.379
22	1.3394	1.3394	1.2437	1.267	1.2803
23	1.1946	1.1946	1.0974	1.0498	1.134
24	1.0974	1.086	1.086	.9511	.905
Max	1.7741	1.7924	1.8099	1.9753	1.6651
Min	.8779	.9328	.9412	.8596	.8688
Avg	1.2795	1.2923	1.2723	1.2583	1.1948

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 202 / 11 KV MALKAPUR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1075	.1132	.132	.112	.1132
2	.1029	.1132	.132	.1097	.1132
3	.1075	.1132	.132	.1097	.1132
4	.1052	.1132	.1132	.112	.1132
5	.1267	.1132	.1132	.1227	.1132
6	.1433	.132	.132	.124	.132
7	.1646	.2263	.132	.1991	.1698
8	.197	.1867	.2427	.181	.2241
9	.1629	.1991	.2075	.1629	.1991
10	.1494	.1448	.1829	.1478	.1629
11	.1478	.1433	.1646	.1294	.1267
12	.1494	.1227	.1629	.1097	.1254
13	.1097	.1227	.1254	.1097	.0895
14	.1097	.0876	.1109	.1097	.0895
15	.112	.1075	.0914	.0924	.0914
16	.1052	.128	.1063	.0895	.0716
17	.104	.1097	.1052	.0905	.1227
18	.1646	.1698	.1448	.1463	.1463
19	.1494	.2075	.1478	.1494	.1867
20	.168	.1494	.1448	.1494	.168
21	.1494	.1698	.1227	.1509	.168
22	.1494	.132	.1132	.132	.1494
23	.1307	.132	.0905	.112	.128
24	.1097	.1132	.132	.1097	.0943
Max	.197	.2263	.2427	.1991	.2241
Min	.1029	.0876	.0905	.0895	.0716
Avg	.1344	.1396	.1368	.1276	.1338

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 241 / 11 KV INCOMER NO-I

Feeder KV- 11 / INCOMING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1641	1.0903	1.1643	1.7375	1.5089
2	1.1641	1.0534	1.1273	1.7918	1.4403
3		1.0534	1.1273	1.7918	1.406
4	1.1104	1.0903	1.1088	1.8484	1.4217
5		1.1643	1.1576	1.825	1.5424
6	1.4842	1.475	1.2696	2.0633	1.8625
7		1.848	1.7002	2.6425	2.4508
8	2.364	2.2786	2.4806	1.829	1.7187
9	2.8117	2.8746	2.9096	1.828	1.7013
10	2.692	2.7343	2.7778	1.6118	1.5203
11	2.5484	2.7519	2.6063	1.3253	1.4327
12	2.4356	2.5415	2.3537	1.2795	1.2656
13	2.1376	2.5065	2.13	1.0852	1.2197
14	2.3211	2.2436	2.0081	1.0682	1.1462
15	2.2325	2.2786	2.0405	1.0174	1.0208
16	1.0974	1.2094	1.0159	1.0174	.9556
17	1.2689	1.2483	1.2357	.9156	1.2071
18	1.6478	1.701	1.7013	1.5769	1.6478
19	1.647	1.7556	1.6655	1.7193	1.7909
20	1.6651	1.7194	1.7193	1.6834	1.6655
21	1.5181	1.5927	1.4403	1.5384	1.5565
22	1.3717	1.4118	1.7551	1.8176	2.0119
23	1.2254	1.2936	1.7556	1.6278	1.7833
24	1.1218	1.1273	1.1827	1.6301	1.4922
Max	2.8117	2.8746	2.9096	2.6425	2.4508
Min	1.0974	1.0534	1.0159	.9156	.9556
Avg	1.7633	1.7518	1.7264	1.5946	1.5320

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 242 / 11 KV INCOMER NO-II

Feeder KV- 11 / INCOMING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8328	.8383	.8676	.7712
2	.7973	.815	.8215	.8589	.7377
3		.7712	.788	.8589	.7127
4	.7712	.7545	.7712	.8326	.6964
5		.7716	.7116	.9054	.7373
6	.8596	.815	.7432	.8688	.8048
7		1.0136	.8149	.9774	.8573
8	.9991	.9795	1.1694	.9431	1.0719
9	.929	1.0576	1.226	1.0751	1.0387
10	1.226	1.1568	1.3256	1.1506	1.0566
11	1.3392	1.0802	1.2136	1.1883	1.0745
12	1.0387	.964	1.0029	1.0269	1.0208
13	1.0029	.8764	1.226	1.0903	.9671
14	1.1458	.964	1.226	1.1283	1.0208
15	1.1694			.9536	.9492
16	1.1203	1.0679	1.1317	.9492	1.0829
17	1.0425	1.1128	.9313	.8764	1.1389
18	.9116	1.0829	.823	.8886	.9745
19	.8859	1.0164	.9134	.852	.9313
20	.8682	.8764	.8764	.744	.8817
21	.8775	.8764	.7888	.7773	.8149
22	.8596	.8309	.8865	.8059	.8842
23	.8238	.8383	.8402	.7209	.8501
24	.7975	.8328	.8383	.8596	.7712
Max	1.3392	1.1568	1.3256	1.1883	1.1389
Min	.7712	.7545	.7116	.7209	.6964
Avg	.9733	.9299	.9525	.9250	.9103

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 401 / 33KV I/C Khadki feeder

Feeder KV- 33 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6046	2.7435	3.0556	3.2425	2.8858
2	2.6046	2.6292	2.999	3.4568	2.7161
3	2.392	2.572	2.9424	3.4568	2.6595
4	2.3891	2.6292	2.9424	3.4751	2.7161
5	2.4177	2.8578	2.9424	3.638	2.9424
6	2.7938	3.5082	3.1687	3.9095	3.678
7	3.9095	4.1872	3.8866	5.1029	4.7531
8	4.6296	4.7611	5.2624	4.2444	4.0175
9	5.0497	4.9411	5.7728	4.1267	3.9758
10	5.6573	5.1006	5.3772	4.1307	3.922
11	5.6013	5.2669	5.1578	3.7912	3.6145
12	4.9291	4.6273	4.4993	3.4168	3.4751
13	4.8171	4.6273	4.3519	3.2819	3.2773
14	4.7051	4.1015	4.1907	3.2819	3.0624
15	4.5931	4.3118		2.999	2.8475
16	2.9687	3.3311	2.963	2.5766	3.1047
17	3.1367	3.6408	3.1024	2.7446	3.6037
18	3.9043	4.201	3.7334	3.678	4.2438
19	3.9609	4.3004	4.0741	3.678	4.357
20	3.8477	4.1307	3.6808	3.4517	4.1307
21	3.5648	3.678	3.3311	3.3385	
22	3.3385	3.6008	4.1307	3.5848	4.0889
23	2.9721	3.2819	3.7529	3.2487	3.7529
24	2.7401	2.8578	3.0556	3.3608	2.9687
Max	5.6573	5.2669	5.7728	5.1029	4.7531
Min	2.3891	2.572	2.9424	2.5766	2.6595
Avg	3.7303	3.8286	3.8423	3.5507	3.5128

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 402 / 33 KV DABAKI-NIMBI O/G

FEEDER Feeder KV- 33 / INCOMING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6379	.7922	.9054	.7682	.7922
2	.631	.7922	.9054	.823	.7356
3	.5373	.7922	.9054	.8145	.7356
4	.4733	.8488	.9054	.8688	.7922
5	.4733	.9054	.9054	.9231	.8488
6	.4733	1.086	.9619	.9774	1.0185
7	1.3432	1.4861	1.2003	1.4118	1.358
8	1.4661	1.4861	1.4289	1.4661	1.358
9	1.3289	1.1963	1.3717	1.2489	1.3432
10	1.5278	1.2094	1.5844	1.2449	1.3432
11	1.4146	1.3169	1.5278	1.1883	1.182
12	1.2883	1.1163	1.3014	1.0185	1.1283
13	1.3014	1.262	1.1883	.9619	1.1043
14	1.0751	.8939	1.0751	.9054	.9134
15	1.0751	.9465		.7922	.8939
16	.9619	.9991	1.0751	.7922	1.0082
17	1.1317	1.1883	1.262	.9619	1.1203
18	1.4146	1.3014	1.262	1.2449	1.4146
19	1.4146	1.4146	1.358	1.2449	1.4712
20	1.3717	1.358	1.1043	1.2574	1.358
21	1.086	1.086	1.0317	1.086	1.1431
22	1.086	1.1431	1.4003	.9717	1.086
23	.9717	1.0288	1.086	.9145	.9717
24	.7362	.9054	.9054	.7842	.7922
Max	1.5278	1.4861	1.5844	1.4661	1.4712
Min	.4733	.7922	.9054	.7682	.7356
Avg	1.0509	1.1065	1.1588	1.0279	1.0797

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 421 / 33 KV INCOMER TO P.T. NO-I

Feeder KV- 33 / INCOMING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.086	1.1523	1.7375	1.4918
2	1.1568	1.0317	1.1523	1.8673	1.4403
3		1.0317	1.1523	1.7918	1.358
4	1.1043	1.086	1.0974	1.7918	1.3426
5		1.1643	1.1643	1.8461	1.5249
6	1.4198	1.4415	1.2752	2.0633	1.8404
7		1.8107	1.701	2.6606	2.392
8	2.3137	2.2365	2.4446	5.6019	1.6832
9	2.8172	2.8921	2.8292	1.8461	1.6655
10	2.8172	2.7046	2.7161	1.5775	1.5203
11	2.6235	2.6749	2.5652	1.3146	1.4506
12	2.3926	2.4966	2.3102	1.2574	1.2894
13	2.2634	2.524	2.0645	1.094	1.1568
14	2.3388	2.2611	1.945	1.0562	1.1163
15	2.2565	2.2611			1.0208
16	1.0322	1.2094	1.0202	.9831	.9339
17	1.2574	1.2346	1.2094	.8848	1.1797
18	1.6124	1.6461	1.6301	1.5775	1.6124
19	1.5947	1.7541	1.6301	1.6827	1.8073
20	1.6478	1.701	1.6644	1.6301	1.6478
21	1.5043	1.6118		1.4883	1.5415
22	1.3432	1.4118	1.7918	1.7604	1.9879
23	1.182	1.3169	1.7918	1.5912	1.8604
24	1.1043	1.086	1.2071	1.8673	1.4918
Max	2.8172	2.8921	2.8292	5.6019	2.392
Min	1.0322	1.0317	1.0202	.8848	.9339
Avg	1.7891	1.7364	1.7052	1.7814	1.5148

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 422 / 33 KV INCOMER TO P.T. NO-
II Feeder KV- 33 / INCOMING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8871	.8453	.8145	.7716
2	.7888	.823	.8453	.8145	.7716
3		.7973	.7956	.7888	.7042
4	.7888	.7888	.7956	.8145	.6962
5		.7802	.7459	.8688	.7545
6	.8413	.8145	.7956	.8688	.823
7	.8413	1.0317	.8322	.9877	.8745
8	.9882	1.0082	1.1763		.9991
9	1.0185	1.0517	1.2449	.9991	1.0208
10	1.2449	1.1443	1.2883	1.1883	
11	1.2894	1.1043	1.2323	1.1883	1.0402
12	1.0974	.9465	1.0425	1.0751	1.0208
13	1.0425	.8939	1.2449	1.1203	
14	1.1643	.9774	1.2449	1.1523	1.0208
15	1.1523	1.1043		1.0208	1.0208
16	1.1317	1.086	1.1317	.9979	1.1317
17	1.0425	1.0745	.9465	.8842	1.1883
18	.9156	1.1203	.8413	.9259	1.0208
19	.9036	1.0642	.9231	.8453	.9671
20	.8596	.9036	.9877	.7305	.9362
21	.8688	.8842	.7888	.8505	.8596
22	.8688	.8162	.9054	.8505	.9425
23	.8596	.7865	.8402	.7716	.823
24	.7888	.8871	.8453	.8962	.7716
Max	1.2894	1.1443	1.2883	1.1883	1.1883
Min	.7888	.7802	.7459	.7305	.6962
Avg	.9760	.9490	.9713	.9328	.9163

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 204 / TRANSPORT NAGAR

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11					.0191
12					.0191
13	.0191	.0191			.0191
14		.0191			.0381
15	.0191	.0191			.0572
16		.0191			.0381
17	.0381	.0191	.0381		.0381
18	.0381	.0381	.0191	.0189	.0381
19	.0381	.0381	.0191	.0189	.0381
20	.0381	.0191	.0191		.0191
21	.0191	.0191			.0191
Max	.0381	.0381	.0381	.0189	.0572
Min	.0191	.0191	.0191	.0189	.0191
Avg	.0300	.0233	.0239	.0189	.0312

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 205 / 11KV NARAYAN

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.362	.3429	.3048	.3048
2	.362	.362	.3429	.3048	.3048
3	.362	.3395	.3429	.3048	.3048
4	.3429	.3429	.3429	.3048	.2858
5	.362	.3429	.3429	.3048	.3048
6	.362	.3429	.3429	.3239	.3048
7	.362	.3429	.3429	.3048	.3048
8	.381	.381	.3429	.3048	.3239
9	.5525	.5906	.4763	.3048	.381
10	.8573	.7049	.743	.3239	.724
11	.9526	.724	.8383	.3048	.8383
12	.8954	.7811	.8573	.3048	.9145
13	.6478	.6478	.6668		.4954
14	.743	.6859	.724		.724
15	.9526	.8573	.6859		.381
16	.9907	.9907	.8192		.4001
17	.9907	.9145	.724		.8383
18	.8954	.8192	.6668	.3048	.8573
19	.7811	.6287	.5716	.3048	.8002
20	.5716	.4001	.362	.3048	.5716
21	.381	.381	.3239	.2858	.4001
22	.381	.362	.3239	.3048	.362
23	.362	.3429	.3239	.3048	.362
24	.362	.362	.362	.3048	.3048
Max	.9907	.9907	.8573	.3239	.9145
Min	.3429	.3395	.3239	.2858	.2858
Avg	.5922	.5420	.5088	.3058	.4914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 206 / 11 KV B.K. FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5525	.5525	.5144	.5335	.3429
2		.5335	.4954	.5144	.3429
3	.4954	.5144	.4572	.4954	.3429
4	.4954	.4954	.4572	.4954	.3429
5	.4954	.4763	.4572	.4954	.3429
6	.4954	.4763	.4572	.4954	.3429
7	.743	.6478	.5144	.4763	.4001
8	.7811	.7049	.6859	.3429	.5525
9	1.1241	.9907	.9335	.3239	.8764
10	1.5623	1.4098	1.2955	.3239	1.2574
11	1.7718	1.7337	1.448	.3239	1.3527
12	1.2193	1.6385	1.3908	.2858	1.3908
13	1.6004	1.3717	1.2765	.2858	1.3527
14	1.7147	1.4098	1.2384	.3048	1.2574
15	1.7718	1.6004	1.3336	.3429	1.2955
16	1.7718	1.5623	1.3336	.3429	1.2384
17	1.7147	1.5432	1.3336	.3048	1.2384
18	1.5432	1.5623	1.2574	.2858	1.2384
19	1.2955	1.3146	1.0288	.3239	1.1431
20	1.105	1.0098	.9335	.3429	1.0479
21	.6859	.5716	.6097	.3239	.6097
22	.6097	.5716	.6668	.362	.6478
23	.5906	.5144	.5906	.362	.5906
24	.5906	.5716	.5525	.5906	.3429
Max	1.7718	1.7337	1.448	.5906	1.3908
Min	.4954	.4763	.4572	.2858	.3429
Avg	1.0752	.9907	.8859	.3866	.8288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 207 / 11KV DADAJI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4191	.4001	.4954	.2858
2	.4382	.4001	.4191	.4572	
3	.4382	.4001	.4191	.4572	.2858
4	.4191	.381	.4191	.4572	.2858
5	.4382	.381	.4191	.4572	.2858
6	.4382	.4001	.4191	.4572	.2858
7	.4572	.4001	.4382	.4572	.2667
8	.4572	.4191	.4572	.3239	.2858
9	.8192	.8002	.7621	.3048	.362
10	1.0288	1.0669	.9526	.3048	.9526
11	1.3717	1.2193	1.1431	.3048	1.0479
12	1.3336	1.2003	1.2003	.3239	1.1812
13	1.2765	.9335	.9526		.9526
14	1.2955	1.1622	1.0479		1.0479
15	1.3336	1.2765	1.0479		1.2384
16	1.3146	1.2193	1.0479		1.3717
17	1.4098	1.2384	1.0288		1.3908
18	1.105	1.0479	.9526	.2858	1.2384
19	1.0669	.9145	.8764	.2858	1.0479
20	.724	.5525	.6859	.2858	.9145
21	.6287	.4382	.5525	.2858	.4763
22	.4191	.4001	.5335	.2858	.4191
23	.4191	.4191	.5335	.2858	.4954
24	.4763	.4191	.4191	.5335	.2858
Max	1.4098	1.2765	1.2003	.5335	1.3908
Min	.4191	.381	.4001	.2858	.2667
Avg	.8152	.7295	.7137	.3710	.7132

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 208 / 11KV YEVATA ROAD

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.2263	.1905	.1524	.0943
2	.1509	.1886	.1905	.1524	.0943
3	.1509	.1698	.1905	.1524	.0943
4	.1698	.1698	.1905	.1524	.0943
5	.1698	.1698	.1905	.1524	.0754
6	.1886	.1698	.2096	.1524	.1132
7	.1698	.1886	.1905	.1715	.132
8	.2452	.2075	.2477	.1334	.132
9	.3395	.3395	.4001	.1334	.2263
10	.4572	.5716	.6036	.1334	.362
11	.5335	.6478	.5658	.0762	.4191
12	.5144	.6097	.6036	.0762	.4954
13	.6287	.6287	.5093		.5335
14	.5144	.5525	.4527		.4763
15	.6287	.6478	.6036		.5525
16	.5906	.6668	.5281		.5716
17	.4954	.6478	.5335		.6097
18	.5525	.5716	.5716	.0943	.7049
19	.4382	.6097	.5144	.1509	.5716
20	.4001	.4954	.4191	.1509	.4572
21	.2667	.2858	.2858	.1509	.3048
22	.2641	.2096	.2286	.0943	.1905
23	.2263	.1905	.2286	.0953	.2477
24	.1698	.2641	.1905	.1905	
Max	.6287	.6668	.6036	.1905	.7049
Min	.1509	.1698	.1905	.0762	.0754
Avg	.3515	.3929	.3683	.1350	.3284

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 241 / 11 KV INCOMER NO-I

Feeder KV- 11 / INCOMING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.362	.3429	.3048	.3048
2	.362	.362	.3429	.3048	.3048
3	.362	.3429	.3429	.3048	.3048
4	.3429	.3429	.3429	.3048	.2858
5	.362	.3429	.3429	.3048	.3048
6	.362	.3429	.3429	.3048	.3048
7	.362	.3429	.3429	.3048	.3048
8	.381	.381	.3429	.3048	.3239
9	.5525	.5906	.4763	.3048	.381
10	.8573	.7049	.743	.3239	.724
11	.9526	.724	.8383	.3048	.8383
12	.8954	.7811	.8573	.3048	.9335
13	.6668	.6668	.6668		.5144
14	.743		.724		.7621
15	.9717	.8764	.6859		.4382
16	.9907	1.0098	.8192		.4382
17	1.0288	.9335	.7621		.8764
18	.9335	.8573	.6859		.8954
19	.8192	.0953	.5906	.3239	.8383
20	.6097	.4191	.381	.3048	.5906
21	.4001	.4001	.3239	.2858	.4191
22	.381	.362	.3239	.3048	.362
23	.362	.3429	.3239	.3048	.362
24	.362	.362	.362	.3239	.3048
Max	1.0288	1.0098	.8573	.3239	.9335
Min	.3429	.0953	.3239	.2858	.2858
Avg	.6009	.5194	.5128	.3069	.5049

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 242 / 11 KV INCOMER NO-II

Feeder KV- 11 / INCOMING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1812	1.2003	1.105	1.1812	.724
2	1.1241	1.1241	1.105	1.1241	.724
3	1.086	1.086	1.0669	1.105	.724
4	1.086	1.0479	1.0669	1.105	.724
5	1.105	1.0288	1.0669	1.105	.7049
6	1.1241	1.0479	1.086	1.105	.743
7	1.3717	1.2384	1.1431	1.105	.8002
8	1.4861	1.3336	1.105	.8002	.9717
9	2.2862	2.3243	2.0957	.7621	1.467
10	3.0483	3.0483	2.8578	.7621	2.572
11	3.677	3.6008	3.1626	.7049	2.8197
12	3.0674	3.4484	3.2007	.6859	3.0674
13	3.5056	2.934	2.7435	.2858	2.8387
14	3.5246	3.1245	2.7435	.3048	2.7816
15	3.7342	3.5246	2.9912	.3429	3.0864
16	3.677	3.4484	2.915	.3429	3.1817
17	3.6199	3.4294	2.8959	.3048	3.2388
18	3.1817	3.1817	2.7816	.6668	3.1817
19	2.8578	2.8387	2.4196	.7621	2.7625
20	2.2291	2.0576	2.0386	.7811	2.4196
21	1.5813	1.2955	1.448	.7621	1.3908
22	1.2955	1.1812	1.4289	.743	1.3527
23	1.2384	1.1241	.4572	.743	1.3336
24	1.2384	1.2574	1.1622	1.3146	.724
Max	3.7342	3.6008	3.2007	1.3146	3.2388
Min	1.086	1.0288	.4572	.2858	.7049
Avg	2.2219	2.1219	1.9203	.7875	1.8473

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 401 / 33 KV INCOMER NO-I

Feeder KV- 33 / INCOMING

SHEDDABLE FEEDER MIDC EQUIVALENT

HAVING WEEKLY STAGGERING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5278	1.5278	1.4289	1.4861	1.0288
2	1.4712	1.4712	1.4289	1.4289	1.0288
3	1.4146	1.4146	1.4289	1.4289	1.0288
4	1.4146	1.358	1.4289	1.4289	1.0288
5	1.4712	1.358	1.4289	1.4289	1.0288
6	1.4712	1.358	1.4289	1.4289	1.0288
7	1.6975	1.5278	1.4861	1.4289	1.086
8	1.8861	1.7147	1.7147	1.086	1.3146
9		2.8858	2.572	1.086	1.8107
10	3.8866	3.7723	3.5648	1.086	3.315
11	4.6296	4.2295	3.9609	1.0288	3.658
12	3.9438	4.2295	4.0175	.9717	4.0009
13	4.1724	3.6008	3.4259	.2829	3.3722
14	4.2867	3.8295	3.4517	.2829	3.5437
15	4.6868	4.401	3.6214	.3395	3.5437
16	4.6868	4.4582	3.678	.3395	3.6008
17	4.6296	4.3439	3.658	.2829	4.1152
18	4.0009	4.0581	3.4865	.7922	4.0581
19	3.658	3.4865	2.915	1.0751	3.6008
20	2.8578	2.4577	2.4006	1.0751	3.0293
21	2.0005	1.7147	1.7718	1.0288	1.829
22	1.6409	1.5432	1.7718	1.0288	1.7147
23	1.5844	1.4861	1.6575	1.0288	1.7147
24	1.5844	1.5844	1.5432	1.6575	1.0185
Max	4.6868	4.4582	4.0175	1.6575	4.1152
Min	1.4146	1.358	1.4289	.2829	1.0185
Avg	2.8088	2.6588	2.4696	1.0222	2.3541

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 402 / 33 KV INCOMER NO-II

Feeder KV- 33 / INCOMING

DATE	09-DEC-17
HR	Load (MW)
12	3.4294
Max	3.4294
Min	3.4294
Avg	3.4294

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 421 / 33 KV INCOMER TO P.T. NO-I

Feeder KV- 33 / INCOMING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3395	.3429	.2858	.2829
2	.3395	.3395	.3429	.2858	.2829
3	.3395	.3395	.3429	.2858	.2829
4	.3395	.3395	.3429		.2829
5	.3395	.3395	.3429	.2858	.2829
6	.3395	.3395	.3429	.2858	.2829
7	.3395	.3395	.3429	.2858	.2829
8	.3961	.3961	.3429	.2858	.3395
9	.5658	.5658	.4572	.2858	.3961
10	.8573	.6859	.7356	.3429	.743
11	.9717	.743	.8488	.2858	.8573
12	.9145	.8002	.8565	.2858	.9145
13	.6859	.6859	.6852		.5144
14	.743	.6859	.7356		.743
15	.9717	.8573	.679		.4572
16	.9717	1.0288	.7922		.4572
17	1.0288	.9145	.743		.8573
18	.9145	.8573	.6859	.3395	.9145
19	.8002	.6859	.5716	.3395	.8573
20	.6287	.4001	.4001	.2829	.5716
21	.4001	.4001	.3429	.2829	.4001
22	.3961	.3429	.3429	.2829	.3429
23	.3429	.3429	.3429	.2829	.3429
24	.3395	.3395	.3429	.3429	.2858
Max	1.0288	1.0288	.8565	.3429	.9145
Min	.3395	.3395	.3429	.2829	.2829
Avg	.5960	.5462	.5127	.2975	.4990

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 422 / 33 KV INCOMER TO P.T. NO-
II Feeder KV- 33 / INCOMING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1883	1.1883	1.086	1.2003	.7356
2	1.1317	1.1317	1.086	1.1431	.7356
3	1.0751	1.0751	1.086	1.086	.7356
4	1.0751	1.0185	1.086	1.086	.7356
5	1.0751	1.0185	1.086	1.086	.679
6	1.1317	1.0185	1.086	1.086	.7356
7	1.358	1.2449	1.1431	1.086	.7922
8	1.4712	1.3014	1.3717		.9619
9	2.2634	2.32	2.1148	.743	1.4712
10	3.0293	3.0293	2.8292	.743	
11	3.658	3.6008	3.1121	.6859	2.8006
12	3.0864	10.3452	3.1975	.6859	3.0864
13	3.4865	2.915	2.7161	.2829	2.8578
14	3.5437		2.7161	.2829	2.8006
15	3.7151	3.5437	2.9424	.3395	3.0864
16	3.658	3.4294	2.8858	.3395	3.2007
17	3.6008	3.4294	2.915	.2829	3.2579
18	3.2579	3.2007	2.8006	.679	3.2007
19	2.8578	2.8578	2.5149	.7356	2.7435
20	2.2291	2.1719	2.0576	.7922	2.4006
21	1.6004	1.3146	1.4289	.7356	1.3717
22	1.3014	1.2003	1.4289	.7356	1.3717
23	1.2449	1.1431	1.3717	.7356	1.3146
24	1.2449	1.2449	1.1431	1.3146	.7356
Max	3.7151	10.3452	3.1975	1.3146	3.2579
Min	1.0751	1.0185	1.086	.2829	.679
Avg	2.2202	2.3801	1.9669	.7777	1.8179

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 201 / 11KV TUKARAM SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4755	.4755	.4938	.439	.4572
2	.4572	.4572	.4755	.4207	.4572
3	.4572	.4755	.439	.4207	.439
4	.4572	.4755	.439	.4024	.439
5	.4755	.5121	.439	.4755	.439
6	.5487	.6219	.5487	.567	.5853
7	.9877	.7865	.7316	.8596	.8779
8	.8962	.823	.8413	.8779	.8596
9	.8962	.8779	.8779	.8962	.8048
10	.7682	.823	.8962	.823	.823
11	.7499	.7682	.8596		.7316
12	.6401	.695	.6767	.6219	
13	.6036	.6401	.6401	.5304	
14	.5487	.5487	.567	.5304	
15	.5121	.5121	.5853	.5304	
16	.5487	.567	.5121	.4938	.7499
17	.6036	.6219	.5853	.5121	.6767
18	.8413	.8596	.823	.8048	.9328
19	.8962	.8962	.8962	.8779	.9145
20	.8779	.823	.7865	.8596	.8596
21	.8048	.8413	.7682	.8048	.7865
22	.7316	.7316	.7682	.7133	.695
23	.6036	.5853	.5487	.567	.6036
24	.4938		.4961	.4755	.4572
Max	.9877	.8962	.8962	.8962	.9328
Min	.4572	.4572	.439	.4024	.439
Avg	.6615	.6704	.6540	.6306	.6795

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 202 / 11KV KOTHARI WATIKA SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3142	.3326	.3326	.2957	.3142
2	.3142	.3326	.3142	.2957	.2957
3	.3142	.3142	.2957	.2772	.2772
4	.2957	.3142	.2957	.2587	.2772
5	.3142	.3326	.3142	.2957	.2957
6	.4435	.4251	.3772	.3881	.3881
7	.6283	.5359	.499	.5914	.6099
8	.6468	.5914	.6099	.5914	.5544
9	.5544	.6283	.5544	.5359	.5544
10	.7762	.499	.5914	.5359	.462
11	.499	.4435	.499	.4251	.4066
12	.3696	.3696	.4251	.3696	.3326
13	.3142	.3511	.3696	.3326	.2957
14	.2957	.3142	.3142		.2957
15	.2772	.2957	.3142	.2957	.2772
16	.2957	.3326	.3326	.2987	.2587
17	.3696	.3881	.3326	.3142	.3142
18	.5359	.5359	.4805	.4805	.462
19	.5544	.5544	.5359	.499	.499
20	.5175	.4805	.4805	.499	.499
21	.499	.4805	.4805	.4435	.462
22	.462	.4805	.4251	.4066	.4251
23	.4066	.3881	.3696	.3511	.3696
24	.3326	.3511	.3511	.3142	.3142
Max	.7762	.6283	.6099	.5914	.6099
Min	.2772	.2957	.2957	.2587	.2587
Avg	.4304	.4197	.4123	.3955	.3850

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 203 / 11KV MIDC II

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0669	1.2193	1.4098	1.2003	.8954
2	1.0349	1.3146	1.4098	1.2003	.9145
3	1.0164	1.2003	1.3717	1.2384	.9145
4	1.2382	1.2765	1.3717	1.2955	.8764
5	1.3146	1.3336	1.3527	1.3908	.8764
6	1.3146	1.2765	1.3908	1.4098	.8954
7	1.3146	1.2003	1.3908	1.3717	1.1622
8	1.2765	1.2955	1.3908	1.1812	1.1431
9	1.7147	1.9052	1.7718	1.0669	1.3146
10	2.21	2.21	2.0195	1.0288	1.8099
11	2.3624	2.3624	2.3624	1.0669	1.9433
12	2.2291	2.2672	2.4387	1.0098	2.0957
13	2.0957	1.8099	2.21	.9907	1.9433
14	2.0576	1.8861	2.0386	1.0479	2.0957
15	2.2481	2.4577	2.2862	1.0479	2.1338
16	2.2862	2.4958	2.1719	.8573	2.191
17	2.2672	2.3434	2.2481	.8383	1.9243
18	2.1338	1.9624	1.8861	.8764	1.8861
19	1.8671	1.7337	1.5051	.8764	1.7528
20	1.3717	1.3527	1.2765	.8383	1.4098
21	1.1241	1.1622	1.105	.8192	1.1241
22	1.0669	1.105	1.2574	.8764	1.1812
23	1.0669	1.105	1.2003	.8954	1.1431
24	1.105	1.2574	1.3336	1.1812	.9335
Max	2.3624	2.4958	2.4387	1.4098	2.191
Min	1.0164	1.105	1.105	.8192	.8764
Avg	1.6160	1.6472	1.6750	1.0669	1.4400

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 204 / 11KV CHAITANYA SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4668	.5415	.5041	.4854	.4854
2	.4668	.5415	.4854	.4668	.4668
3	.4668	.4294	.4481	.4294	.4668
4	.4108	.4294	.4294	.3734	.4481
5	.4108	.4294	.4294	.4108	.4294
6	.5601	.5601	.5228	.5228	.5041
7	.8029	.8029	.6908	.8215	.7655
8	.7842	.8402	.7842	.8215	.8402
9	.8215	.7842	.8775	.8215	.7655
10	.7842	.7095	.8775	.8589	.7282
11	.7095	.6722	.7655	.6722	.6348
12	.6535	.5788	.6535	.6161	.5601
13		.5788	.5601	.5415	.4854
14	.5228	.5415	.5415	.4854	.4481
15	.5041	.5041	.5041	.4481	.4294
16	.4854	.5415	.4854	.4668	.4481
17	.5788	.5415	.5041	.5041	.5228
18	.7842	.7655	.7468	.7468	
19		.8029	.7468	.7842	.7842
20	.8215	.8215	.7842	.8402	.8029
21	.7655	.7842	.8215	.7468	.7842
22	.6908	.6908	.7282	.6908	.7095
23	.6535	.6161	.6722	.6161	.5975
24	.5975	.5601	.5415	.5415	.4854
Max	.8215	.8402	.8775	.8589	.8402
Min	.4108	.4294	.4294	.3734	.4294
Avg	.6246	.6278	.6294	.6130	.5910

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 206 / 11 KV FEEDER NO-6

Feeder KV- 11 / OUTGOING

DATE	09-DEC-17
HR	Load (MW)
18	.9145
Max	.9145
Min	.9145
Avg	.9145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 241 / 11 KV INCOMER NO-I

Feeder KV- 11 / INCOMING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.462	.5415	.4938	.4854	.4854
2	.4668	.5415	.4755	.4668	.4668
3	.4668	.4294	.439	.4294	.4668
4	.4108	.4294	.4207	.3734	.4481
5	.4108	.4294	.4207	.4108	.4294
6	.5601	.5601	.5121	.5228	.5041
7	.8029	.8029	.6767	.8215	.7655
8	.7842	.8402	.7682	.8215	.8402
9	.8215	.7842	.8775	.8215	.7655
10	.7842	.7095	.8775	.8589	.7282
11	.7095	.6722	.7655	.6722	.6348
12	.6535	.5788	.6535	.6036	.5601
13	.5601	.5788	.5601	.5415	.4854
14	.5228	.5415	.5415	.4854	.4481
15	.5041	.5041	.5041	.4481	.4294
16	.4854	.5415	.4854	.4668	.4481
17	.5788	.5415	.5041	.5041	.5228
18	.7842	.7655	.7468	.7468	.8029
19	.7682	.7865	.7468	.7842	.7842
20	.8048	.8215	.7842	.8402	.8029
21	.7655		.8215	.7468	.7842
22	.6908	.6767	.7282	.6908	.6161
23	.6535	.6161	.679	.6161	.5975
24	.4668	.5601	.5415	.5415	.4854
Max	.8215	.8402	.8775	.8589	.8402
Min	.4108	.4294	.4207	.3734	.4294
Avg	.6216	.6197	.6260	.6125	.5959

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 242 / 11 KV INCOMER NO-II

Feeder KV- 11 / INCOMING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8673	2.037	2.2445	1.9427	1.6956
2	1.8484	2.1125	2.2068	1.9239	1.6956
3	1.8296	1.9993	2.1125	1.9427	1.6575
4	2.037	2.0748	2.1125	1.9616	1.6194
5	2.1125	2.1879	2.1125	2.1691	1.6385
6	2.32	2.3388	2.32	2.3765	1.9052
7		2.5463	2.6406	2.6783	2.7054
8	2.8481	2.7349	2.8669	2.6783	2.6101
9	3.1876	3.4328	3.2253	2.5274	2.7244
10	3.5082	3.546	3.5271	2.4143	3.1121
11	3.6214	3.5837	3.7346	2.1502	3.0933
12	3.2769	3.3385	3.546	2.0182	2.4143
13	3.0178	2.8104	3.2253	1.8673	2.2257
14	2.9047	2.7538	2.9235	1.8861	2.3765
15	3.0367	3.263	3.2198	1.8673	2.3954
16	3.131	3.3951	3.0483	1.6598	3.2065
17	3.2442	3.3573	3.1687	1.6956	2.9235
18	3.5271	3.3762	3.2065	2.21	3.3341
19	3.3385	3.2065	2.9613	2.3053	3.2198
20	2.7915	2.6783	2.5652	2.2481	2.8197
21	2.452	2.5086	2.3577	2.1148	2.4196
22	2.2822	2.3388	2.4709	2.0386	2.3434
23	2.0936	2.0936	2.1313	1.848	2.1529
24	1.9427	2.1313	2.1622	1.9805	1.7337
Max	3.6214	3.5837	3.7346	2.6783	3.3341
Min	1.8296	1.9993	2.1125	1.6598	1.6194
Avg	2.7052	2.7436	2.7538	2.1044	2.4176

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 402 / 33 KV INCOMER (TUKARAM
SST) Feeder KV- 33 / INCOMING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6975	1.9239	2.1502	1.8673	1.4146
2	1.6975	1.9805	1.6975	1.7541	1.4146
3	1.6975	1.8107	1.6975	1.6975	1.4146
4	1.6409	1.8107	1.8107	1.5844	1.358
5	1.8673	1.9239	1.9805	1.9805	1.358
6	2.1502	2.1502	2.1502	2.2634	1.6409
7	3.0556	2.7161		2.999	2.5463
8	2.7726	2.8858	2.999	2.7161	2.7161
9	3.3951	3.5082	3.5082	2.4897	2.7161
10	3.678	3.678	3.678	2.32	3.2819
11	3.5082	3.7346	3.9043	2.037	3.0556
12	3.3385	3.5082	3.4517	1.6975	2.3765
13	2.8858	2.6595	3.1121	1.4712	2.0936
14	2.7726	2.6029	2.8858	1.4146	2.0936
15	2.8858	3.1121	2.999	1.358	2.2068
16	2.999	3.1687	2.7161	1.1883	3.0556
17	3.1121	3.2253	2.999	1.2449	2.7726
18	3.6214	3.5082	3.2819	1.9239	3.3951
19	3.6214	3.5082	3.0556	2.0936	3.3951
20	2.999	2.9424	2.7161	2.037	2.9424
21	2.4897	2.5463	2.4331	1.9239	2.4897
22	2.32	2.3765	2.32	1.8107	2.32
23	2.037	2.2068	2.1502	1.6975	2.1502
24	1.9239	1.8673	1.9805	1.9805	1.5278
Max	3.678	3.7346	3.9043	2.999	3.3951
Min	1.6409	1.8107	1.6975	1.1883	1.358
Avg	2.6736	2.7231	2.6816	1.8979	2.3223

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 421 / 33 KV INCOMER TO P.T. NO-I

Feeder KV- 33 / INCOMING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4572	.5144	.5144	.5144
2	.4572	.4572	.4572	.4572	.5144
3	.4572	.4001	.4572	.4572	.4572
4	.4001	.4001	.4572	.3429	.4572
5	.4001	.4001	.4572	.4001	.4572
6	.5716	.5716	.5144	.5716	.5716
7	.8573	.8002	.6859	.2858	.743
8	.743	.8002	.8002	.8002	.8573
9	.8002	.8573	.8002	.8002	.743
10	.8002	.743	.8573	.8573	.8002
11	.6859	.6859	.8002	.6859	.6859
12	.6287	.6287	.6859	.5144	.5716
13	.5716	.5716	.5716	.5144	
14	.5144	.5144	.5144	.4572	.4572
15	.5144	.5144	.5144	.4572	.4572
16	.5144	.5144	.5144	.4572	.4572
17	.5716	.5144	.5144	.5144	.5144
18	.743	.8002	.743	.6859	.743
19		.8573	.8002	.743	.8002
20	.8573	.8002	.743	.743	.743
21	.743	.8002	.743	.743	.8002
22	.6859	.6859	.6859	.6859	.6287
23	.6287	.6287	.5716	.6287	.6287
24	.5144	.5716	.5144	.5144	.5144
Max	.8573	.8573	.8573	.8573	.8573
Min	.4001	.4001	.4572	.2858	.4572
Avg	.6138	.6240	.6216	.5763	.6138

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 422 / 33 KV INCOMER TO P.T. NO-

II Feeder KV- 33 / INCOMING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2574	1.4289	1.6575	1.4289	.9717
2	1.2003	1.4861	1.6575	1.3146	.9717
3	1.2574	1.3717	1.6004	1.3146	.9717
4	1.3717	1.3717	1.5432	1.3717	.9145
5	1.4861	1.4861	1.6004	1.5432	.9145
6	1.6575	1.6004	1.6575	1.7147	1.086
7	2.2291	1.9433	2.0576	2.1719	1.7718
8	2.1148	2.0576	2.2291	1.9433	1.8861
9	2.572	2.6863	2.572	1.6575	1.9433
10	2.8006	2.9721	2.8578	1.4861	2.4577
11	2.8006	3.0293	3.0864	1.3146	2.4006
12	2.6863	2.8578	2.8006	1.086	1.829
13	2.3434	2.1148	2.6863	.9717	
14	2.2862	2.1148	2.2862	.9717	1.6004
15	2.4006	2.6292	2.4006	.9717	1.8861
16	2.5149	2.6863	2.2291	.743	2.572
17	2.572	2.6863	2.5149	.743	2.2291
18	2.8578	2.7435	2.572	1.2003	2.6863
19	2.7435	2.6863	2.3434	1.3717	2.572
20	2.1719	2.1719	1.9433	1.3146	2.1719
21	1.7147	1.829	1.6575	1.2003	1.7147
22	1.6575	1.7147		1.1431	1.6575
23	1.4289	1.5432	1.4861	1.1431	1.5432
24	1.3717	1.3717	1.6004	1.4289	1.086
Max	2.8578	3.0293	3.0864	2.1719	2.6863
Min	1.2003	1.3717	1.4861	.743	.9145
Avg	2.0624	2.1076	2.1322	1.3146	1.7321

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024002 / 33 KV UMRI

Feeder No / Name : 201 / 11 KV PKV FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1829	.1629	.1629	.1629
2	.1829	.1829	.1629	.1448	.1448
3	.1829	.1829	.1448	.1448	.1448
4	.2195	.2012	.1448	.1448	.1448
5	.2195	.2012	.181	.1448	.1629
6	.2195	.2012	.2172	.181	.181
7	.2743	.2012	.2534	.1991	.9745
8	.2743	.2743		.2534	.2534
9	.2896	.3475	.2926	.2926	.2926
10		.2926	.2926	.2926	.3109
11	.3258	.2743	.2743	.3292	.3475
12	.3258	.2561	.2378	.3109	.2926
13		.2195	.2195	.2926	.2378
14	.2896	.2195	.1829	.2195	.2378
15	.2896	.2012	.1829	.2561	.2743
16	.2926	.1991	.1829	.2926	.2561
17	.2926	.1991	.2195	.2926	.2926
18	.2926	.2715	.2195	.2926	.2743
19	.2926	.2896	.2743	.2743	.2743
20	.3109	.2896	.2743	.2378	.2195
21	.2378	.2534	.2195	.2378	.2195
22		.2218	.1753	.2172	.1991
23		.2033	.3319	.1867	.1629
24	.1829	.1829	.181	.1629	.1629
Max	.3258	.3475	.3319	.3292	.9745
Min	.1829	.1829	.1448	.1448	.1448
Avg	.2589	.2312	.2186	.2318	.2593

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024002 / 33 KV UMRI

Feeder No / Name : 202 / 11 KV PANCHSHIL FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3475	.3292	.3077	.2534	.2715
2	.3475	.3292	.3077	.2353	.2534
3	.3658	.3658	.3077	.2353	.2534
4	.3658	.439	.2896	.2172	.2715
5	.3841	.4755	.3258	.2534	.2896
6	.3841	.5121	.439	.4024	.4024
7	.4572	.5487	.5175	.5359	.5544
8	.5853	.5304	.5729	.5359	.5729
9	.5729	.5121	.5487	.5304	.567
10	.4207	.4938	.5304	.4024	.439
11	.3841	.4207	.439	.3475	.4024
12	.3658	.3841	.4207	.3292	.3475
13	.3077	.3109	.3475	.3109	.3475
14	.2896	.3292	.3109	.2561	.2743
15	.2896	.3292	.2926	.2561	.2743
16	.2926	.3439	.2926	.3292	.2743
17	.3658	.3258	.3658	.4024	.3475
18	.4938	.5175	.4938	.5121	.4755
19	.5121	.5359	.4755	.4938	.5121
20	.4938	.4755	.439	.4572	.4755
21	.4572	.439	.439	.4572	.4572
22		.4435	.4024	.3841	.4024
23		.4066	.2715	.3174	.3439
24	.3475	.3292	.3258	.2534	.2715
Max	.5853	.5487	.5729	.5359	.5729
Min	.2896	.3109	.2715	.2172	.2534
Avg	.4014	.4220	.3943	.3628	.3784

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024002 / 33 KV UMRI

Feeder No / Name : 203 / 11 KV SUDHIR COLONY FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9511	.9877	1.0082	.7468	.8589
2	.9511	.9877	.9709	.7468	.8589
3	.9877	.9877	.9709	.6722	.8215
4	1.0242	1.0974	.9335	.6348	.8215
5	1.0974	1.2803	.9335	.8215	1.0456
6	1.1523	1.4632	1.1949	1.1949	1.3817
7	1.4632	1.5729	1.307	1.587	1.4937
8	1.701	1.6278	1.5123	1.587	1.6057
9	1.7364	1.6095	1.5154	1.4969	1.5154
10	1.5684	1.4266	1.46	1.423	1.46
11	1.419	1.3535	1.3491	1.1888	1.1706
12	1.2136	1.1888	1.262	1.0791	
13	1.0829	1.0608	1.0425	.8962	1.0791
14	.8962	1.0059	.8962	.8779	.8779
15	.9149	.9694	.8779	.8596	.8779
16	.8962	.9896	1.0059	1.0059	.8779
17	.9877	1.0082		1.1888	.9877
18	1.4266	1.4003	1.39	1.3717	1.39
19	1.4632	1.5123	1.4998	1.3535	1.4266
20	1.4083	1.4003	1.3535	1.2803	1.3352
21	1.3169	1.2883	1.2986	1.262	1.2986
22	1.1888	1.2437	1.1576	1.1389	1.1763
23	1.0791	1.0608	.9709	.9896	1.0829
24	.9511	.9877	1.0082	.7468	.8962
Max	1.7364	1.6278	1.5154	1.587	1.6057
Min	.8962	.9694	.8779	.6348	.8215
Avg	1.2032	1.2296	1.1704	1.0896	1.1452

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024002 / 33 KV UMRI

Feeder No / Name : 204 / 11kv Vishwakarma Feeder
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5121	.4755	.4755	.3258	.4755
2	.5121	.4755	.4755	.3258	.439
3	.5487	.4755	.439	.2896	.439
4	.5487	.5487	.439	.2896	.439
5	.5487	.6401	.5175	.3658	.5175
6	.5487	.7316	.6653	.6653	.6653
7	.6584	.8048	.7468	.7842	.7842
8	.7865	.7499	.8215	.8215	.8402
9	.8589	.8131	.8316	.7947	.8131
10	.6908	.6653	.8131	.6468	.7023
11	.5544	.5544	.6283	.5544	.5544
12	.499	.462	.5729	.4251	.4805
13	.4207	.499	.462	.3696	.462
14	.4207	.4251	.462	.3696	.3696
15	.4024	.4251	.4066	.3696	.3696
16	.4251	.4572	.3841	.5487	.3658
17	.4805	.5175	.4938	.5487	.439
18	.7207	.7468	.6584	.695	.6401
19	.7947	.7842	.7133	.7133	.7316
20	.7577	.7468	.7133	.695	.6767
21	.7023	.6722	.6219	.6584	.6584
22		.5487	.7282	.5914	.5729
23		.5544	.439	.5041	.4938
24	.5121	.4755	.4755	.3258	.4755
Max	.8589	.8131	.8316	.8215	.8402
Min	.4024	.4251	.3841	.2896	.3658
Avg	.5865	.5937	.5827	.5282	.5585

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024002 / 33 KV UMRI

Feeder No / Name : 206 / 11kv feeder no. 2

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17
HR	Load (MW)
8	.1463
Max	.1463
Min	.1463
Avg	.1463

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024002 / 33 KV UMRI

Feeder No / Name : 210 / 11 kv Incomer No.1

Feeder KV- 11 / INCOMING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0425	.9877	.9709	.7655	.9335
2	1.0425	.9877	.9335	.7282	.8589
3	1.0974	1.0242	.9149	.6908	.8589
4	1.134	1.1888	.8962	.6653	.8589
5	1.1523	1.3169	1.0456	.7842	.9896
6	1.1523	1.4449	1.3443	1.2696	1.2696
7	1.39	1.5546	1.531	1.531	1.587
8	1.6461	1.5546	1.8484	1.6244	1.6804
9	1.6804	1.7187	1.7002	1.6448	1.6448
10	1.4377	1.4449	1.6448	1.3491	1.46
11	1.2883	1.2437	1.3491	1.2254	1.2986
12	1.2136	1.0974	1.2254	1.0608	1.1157
13	1.0642		1.0242	.9694	1.0425
14	1.0269	.9694	.9511	.8413	.8779
15	1.0082	.9511	.8779	.8779	.9145
16	1.0059	1.0082	.8596	1.1706	.8962
17	1.134	1.0642	1.0791	1.2437	1.0791
18	1.4998	1.5497	1.3717	1.4998	1.39
19	1.5912	1.6244	1.4632	1.4815	1.5181
20	1.5546	1.531	1.4266	1.39	1.3717
21	1.39	1.3817	1.2803	1.3535	1.3352
22		1.1763	1.3256	1.2136	1.1949
23		1.1643	.9149	1.0082	1.0269
24	1.0425	.9877	1.0082	.7655	.9335
Max	1.6804	1.7187	1.8484	1.6448	1.6804
Min	1.0059	.9511	.8596	.6653	.8589
Avg	1.2543	1.2597	1.2078	1.1314	1.1724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024002 / 33 KV UMRI

Feeder No / Name : 211 / Incomer No.2

Feeder KV- 11 / INCOMING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9511	.9877	1.0082	.7468	.8589
2	.9511	.9877	.9709	.7468	.8589
3	.9877	.9877	.9709	.6722	.8215
4	1.0242	1.0974	.9335	.6348	.8215
5	1.0974	1.2803	.9335	.8215	1.0456
6	1.1523	1.4632	1.1949	1.1949	1.3817
7	1.4632	1.5729	1.307	1.587	1.4937
8	1.701	1.6278	1.5123	1.587	1.6057
9	1.7551	1.6095	1.5154	1.4969	1.5154
10	1.5684	1.4266	1.46	1.423	1.46
11	1.419	1.3535	1.3491	1.1888	1.1706
12	1.2136	1.1888	1.262	1.0791	
13	1.0829	1.0608	1.0425	.8962	1.0791
14	.8962	1.0059	.8962	.8779	.8779
15	.9149	.9694	.8779	.8596	.8779
16	.8962	.9896	1.0059	1.0059	.8779
17	.9877	1.0082	1.1888	1.1888	.9877
18	1.4266	1.4003	1.39	1.3717	1.39
19	1.4632	1.5123	1.4998	1.3535	1.4266
20	1.4083	1.4003	1.3535	1.2803	1.3352
21	1.3169	1.2883	1.2986	1.262	1.2986
22		1.2567	1.1576	1.1389	1.1763
23		1.0719	.9709	.9896	1.0829
24	.9511	.9877	1.0082	.8215	.8962
Max	1.7551	1.6278	1.5154	1.587	1.6057
Min	.8962	.9694	.8779	.6348	.8215
Avg	1.2104	1.2306	1.1712	1.0927	1.1452

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024002 / 33 KV UMRI

Feeder No / Name : 401 / 33 kv I/C Appatapa to
Umari Feeder KV- 33 /
OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9753	1.9753	1.9959	1.7187	1.885
2	1.9753	1.9753	1.9959	1.6632	1.885
3	2.0851	1.9753	1.885	1.6632	1.7741
4	2.1399	2.2497	1.885	1.5684	1.7741
5	2.2497	2.5789	2.1285	1.8296	2.1285
6	2.3045	2.9081	2.4646	2.5766	2.5766
7	2.8532	3.1276	3.0247	2.652	3.2487
8	3.3471	3.1824	3.3608	3.3608	3.5288
9	3.5848	3.3311	3.095	3.095	3.1493
10	3.3048	2.8172	3.0624	2.7401	2.8475
11	2.9127	2.5514	2.6578	2.392	2.4451
12	2.6326	2.2325	2.4451	2.073	1.1163
13	2.3525	2.073	2.0199	1.8604	2.073
14	2.0513	1.9667	1.8604	1.701	1.701
15	1.9959	1.9136	1.701	1.701	1.7541
16	1.9136	2.1285	1.8656	2.1399	1.7558
17	2.073	2.2405	2.2497	2.4143	2.0302
18	2.8704	2.8567	2.7435	2.8532	2.7435
19	2.9767	2.9687	2.963	2.7984	2.9081
20	2.9235	2.8006	2.7435	2.6337	2.6886
21	2.6578	2.8567	2.5789	2.5789	2.6337
22		2.5766	2.5206	2.5766	2.5206
23		2.32	1.9959	2.2085	2.1285
24	1.9753	1.9753	2.0513	1.7187	1.9959
Max	3.5848	3.3311	3.3608	3.3608	3.5288
Min	1.9136	1.9136	1.701	1.5684	1.1163
Avg	2.5070	2.4826	2.3873	2.2716	2.3038

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024030 / VIDYUT BHAVAN S/S

Feeder No / Name : 201 / WOMEN HOSPITAL EXPRESS NON SHEDDABLE WATER SUPPLY AND
 Feeder KV- 11 / OUTGOING UTILITY

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572		.0572	.0381
2	.0381	.0572		.0572	.0572
3	.0572	.0572		.0572	.0381
4	.0381	.0572		.0572	.0572
5	.0572	.0572		.0572	.0572
6	.0572	.0572		.0572	.0381
7	.0572	.0572		.0572	.0572
8	.0572	.0572			.0572
9	.1143	.0762	.0762	.0572	.0572
10	.0572	.0762			.0762
11		.1143	.0572		.0953
12		.1143	.0572		.0953
13		.0572	.0572		.0953
14		.0572	.0572		.0762
15		.0572	.0572		.0953
16		.0572	.0572		.0762
17		.0572	.0572		.0762
18				.0572	.0762
19				.0572	
20	.0572			.0572	
21	.0572			.0572	
22	.0572			.0572	
23	.0572			.0572	
24	.0572	.0572		.0572	.0572
Max	.1143	.1143	.0762	.0572	.0953
Min	.0381	.0572	.0572	.0572	.0381
Avg	.0585	.0657	.0596	.0572	.0672

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024030 / VIDYUT BHAVAN S/S

Feeder No / Name : 202 / RAMDASPETH SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6468	.7095		.6722	.6283
2	.6099	.6722		.6535	.5914
3	.5914	.6722		.6535	
4	.5544	.6722		.6535	.5228
5	.6653	.7095		.6722	.5975
6	.8131	.8402		.9335	.7947
7	1.0164	1.0456		1.0269	.9979
8	1.0719	1.1203			.9979
9	1.1827	1.0456	.9694	1.0642	1.1088
10	1.1273	1.0456			1.0269
11		.9979	.8501		.9055
12		.9795	.8131		.8131
13		.9795	.8686		.462
14		.961	.7577		.6653
15		.8131	.7577		.7095
16		.7947	.6838		.6908
17		.7947	.6838		.7762
18				1.1203	.7762
19				1.0456	
20	1.0719			.9979	
21	1.0269			.924	
22	.9335			.9055	
23	.7842			.7577	
24	.6838	.7095		.6722	.6468
Max	1.1827	1.1203	.9694	1.1203	1.1088
Min	.5544	.6722	.6838	.6535	.462
Avg	.8520	.8646	.7980	.8502	.7618

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024030 / VIDYUT BHAVAN S/S

Feeder No / Name : 204 / D. P.

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6584	.7392		.7762	.6584
2	.6219	.7023		.7762	.6219
3	.5853	.7023		.7023	.5914
4	.5487	.7392		.7023	.5544
5	.7316	.7468		.7392	.7468
6	.9511	.8316		.9979	.8413
7	1.1706	1.0719		1.1458	1.0791
8	1.1706	1.1273			1.2071
9	1.3169	1.1827	1.2197	1.1643	1.1888
10	1.2071	1.1827			1.1088
11		1.134	1.2197		1.0164
12		1.0059	1.0791		.9425
13		.8962	.9694		.9425
14		.8779	.8596		.8686
15		.8779	.8596		
16		.8779	.7865		.8686
17		.8779	.7865		.9328
18				1.1827	.9328
19				1.2567	
20	1.3169				
21	1.1827			1.0608	
22	1.0164			.9511	
23	.8871			.823	
24	.695	.7392		.7762	.7133
Max	1.3169	1.1827	1.2197	1.2567	1.2071
Min	.5487	.7023	.7865	.7023	.5544
Avg	.9374	.9063	.9725	.9325	.8786

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024030 / VIDYUT BHAVAN S/S

Feeder No / Name : 206 / 11 KV VIDYUT BHAWAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0339		.017	.0339
2	.0339	.0339		.017	.0339
3	.0343	.0339		.017	.0339
4	.0343	.0339		.017	.0339
5	.0343	.0339		.017	.0339
6	.0324	.0339		.0171	.0339
7	.0328	.0339		.0171	.0324
8	.0324	.0339			.0324
9	.0324	.0339	.0187	.0339	.0324
10	.0486	.017			.0343
11		.0162	.0162		.0526
12		.0162	.0162		.0526
13		.0162	.0162		.0876
14		.0162	.0162		.0701
15		.0162	.0162		.0686
16		.0162	.0162		.0876
17		.0162	.0162		.0648
18				.056	
19				.0514	
20	.0332				
21	.0339			.0328	
22	.0339			.0339	
23	.0339			.0339	
24	.0335	.0339		.017	.0332
Max	.0486	.0339	.0187	.056	.0876
Min	.0324	.0162	.0162	.017	.0324
Avg	.0345	.0261	.0165	.0270	.0473

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024030 / VIDYUT BHAVAN S/S

Feeder No / Name : 207 / 11KV ICON HOSPITAL
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953		.0572	.0572
2	.0762	.0953		.0572	.0572
3	.0762	.0953		.0572	.0572
4	.0762	.0953		.0572	.0572
5	.0762	.0953		.0572	.0572
6	.0762	.0953		.0572	.0572
7	.0762	.0953		.0572	.0572
8	.0953	.0953			.0572
9	.1334	.1143	.0953	.1143	.0762
10	.1524	.0953			.1334
11		.1143	.0953		.1334
12		.1334	.1143		.1524
13		.1715	.1143		.1715
14		.1524	.1334		.1715
15		.1524	.1334		.1524
16		.1715	.1143		.1715
17		.1524	.1143		.1524
18				.1143	
19				.1143	
20	.1143				
21	.1143			.1143	
22	.0953			.0953	
23	.0953			.0953	
24	.1143	.0953		.0572	.0762
Max	.1524	.1715	.1334	.1143	.1715
Min	.0762	.0953	.0953	.0572	.0572
Avg	.0978	.1175	.1143	.0790	.1027

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024030 / VIDYUT BHAVAN S/S

Feeder No / Name : 210 / 11 kvIncommer 1

Feeder KV- 11 / INCOMING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7023	.7811		.7282	.6653
2	.6468	.7282		.7095	.6468
3	.6468	.7282		.7095	.5914
4	.5914	.7282		.7095	.5788
5	.7207	.7655		.7282	.6535
6	.8686	.8962		.9896	
7	.8686	1.1016		1.0829	
8	1.1273	1.1763			1.0534
9	1.2012	1.1203	1.0456	1.1203	1.1458
10	1.1827	1.1203			1.1016
11		1.1088	.9055		1.0082
12		1.0903	.8686		.9149
13		1.0349	.924		.5601
14		1.0164	.8131		.7468
15		.8686	.8131		.8029
16		.8501	.7392		.7655
17	.9522	.8501	.7392		.8501
18	1.1763			1.1763	.8501
19	1.2323			1.1016	
20	1.1389			1.0534	
21	1.0829			.9795	
22	.9896			.961	
23	.8402			.8131	
24	.7392	.7655		.7282	.7023
Max	1.2323	1.1763	1.0456	1.1763	1.1458
Min	.5914	.7282	.7392	.7095	.5601
Avg	.9282	.9295	.8560	.9061	.8022

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024030 / VIDYUT BHAVAN S/S

Feeder No / Name : 211 / Incommmer No.2

Feeder KV- 11 / INCOMING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7865	.8686		.8501	.7499
2	.7316	.8316		.8501	.7133
3	.695	.8316			.6838
4	.6584	.8686		.7762	.6468
5	.8413	.8775		.8131	.8316
6	1.0608	.961		1.0719	
7	1.2803	1.2012		1.2197	1.1706
8	1.2986	1.2012			1.2986
9	1.4449	1.3306	1.3306	1.3306	1.3352
10	1.4083	1.2936			1.2752
11		1.262	1.3169		1.2012
12		1.1523	1.2071		1.1458
13		1.0791	1.0974		1.2012
14		1.0425	1.0059		1.1088
15		1.0425	1.0059		1.0719
16		1.0608	.924		1.1273
17		1.0425	.9145		1.1523
18				1.3491	1.1523
19				1.423	
20	1.4632			1.3169	
21	1.3306			1.2071	
22	1.1458			1.0791	
23	1.0164			.9511	
24	.8413	.8686		.8501	.823
Max	1.4632	1.3306	1.3306	1.423	1.3352
Min	.6584	.8316	.9145	.7762	.6468
Avg	1.0669	1.0453	1.1003	1.0777	1.0383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024030 / VIDYUT BHAVAN S/S

Feeder No / Name : 401 / 33KV VIDYUT BHAVAN I/C

Feeder KV- 33 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4969	1.6804		1.6244	1.4415
2	1.386	1.5684		1.5684	1.386
3	1.3306	1.5684		1.5123	1.2883
4	1.2752	1.6244		1.5123	1.2323
5	1.5524	1.6804		1.5684	1.5123
6	1.9404	1.9044		2.0725	1.7741
7	2.384	2.3525		2.3525	2.2177
8	2.4394	2.4646			2.384
9	2.6612	2.4646	2.3285	2.4646	2.4394
10	2.6057				2.4086
11		2.384	2.2177		2.2405
12		2.2731	2.1068		2.0725
13		2.1068	2.0513		1.7924
14		2.0513	1.8296		1.9044
15		1.9404	1.8296		1.9044
16		1.9404	1.6632		1.885
17		1.885	1.6632		2.0513
18				2.5206	
19				2.5206	
20	2.6057			2.384	
21	2.4646			2.2177	
22	2.1845			2.0513	
23	1.9044			1.7741	
24	1.6078	1.6804		1.6244	1.5524
Max	2.6612	2.4646	2.3285	2.5206	2.4394
Min	1.2752	1.5684	1.6632	1.5123	1.2323
Avg	1.9893	1.9747	1.9612	1.9845	1.8604

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024030 / VIDYUT BHAVAN S/S

Feeder No / Name : 410 / T/F no.1

Feeder KV- 33 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7207				.6653
2	.6653				.6653
3	.6653				
4	.6099				
5	.7207				
6	.8871				.8316
7	1.0534				1.0534
8	1.1088				1.0534
9	1.2197	1.1203	1.0534	1.1203	1.0534
10	1.1643	1.1203			
11		1.1088	.8871		
12		1.1088	.8871		
13		1.0534	.9425		
14		.9979	.8316		
15		.8871	.8316		
16		.8316	.7207		
17		.8316	.7207		.8316
18				1.1763	
19				1.1203	
20	1.1088			1.0534	
21	1.1088			.9979	
22	1.0082			.9425	
23	.8316			.8316	
24	.7207				.7207
Max	1.2197	1.1203	1.0534	1.1763	1.0534
Min	.6099	.8316	.7207	.8316	.6653
Avg	.9062	1.0066	.8593	1.0346	.8593

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024030 / VIDYUT BHAVAN S/S

Feeder No / Name : 411 / T./F NO. 2

Feeder KV- 33 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7682				.7762
2					.7133
3	.7133				
4	.6584				
5	.823				
6	1.0534				.9328
7	1.262				1.1523
8	1.3169				1.3169
9	1.4266	1.3306	1.2323	1.3306	1.262
10	1.4266	1.3306			
11		1.262	1.3169		
12		1.1523	1.2071		
13		1.0974	1.1088		
14		1.0425	.9877		
15		1.0425	.9877		
16		1.0425	.9328		
17		1.0425	.9328		1.1523
18				1.386	
19				1.4415	
20	1.4969			1.3169	
21	1.3306			1.2071	
22	1.1643			1.0974	
23	1.0534			.9328	
24	.823				.8316
Max	1.4969	1.3306	1.3169	1.4415	1.3169
Min	.6584	1.0425	.9328	.9328	.7133
Avg	1.0940	1.1492	1.0883	1.2446	1.0172

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 201 / DAMANI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1509	.132	.132	.132
2	.132	.1509	.132	.132	.132
3	.132	.1509	.132	.1307	.132
4	.132	.1509	.132	.132	.132
5	.132	.1509	.132	.132	.132
6	.1509	.1698	.1509	.1509	.1509
7	.1886	.1886	.1886	.2075	.1886
8	.1698	.1886	.1886	.1886	.1886
9	.1886	.1698	.1886	.1886	.1886
10	.1698	.1698	.1886	.1698	.1698
11	.1509	.1509	.2075	.1509	.1698
12	.1509	.1698	.1886	.1698	.2075
13		.1509	.1509	.1132	.1509
14	.1132	.1509	.132	.132	.1509
15	.1132	.132	.132	.1132	.132
16	.132	.1132	.132	.1132	.1132
17	.1509	.132	.132	.0943	.132
18	.1886	.1886	.1886	.1509	.1886
19	.2075	.1886	.2075	.1886	.2263
20	.1886	.1886	.1886	.1886	.2075
21	.1886	.1886	.132	.1886	.1886
22	.1886	.1886	.1509	.1698	.1698
23	.1509	.1698	.1509	.1509	.1509
24	.132	.1509	.132	.132	.132
Max	.2075	.1886	.2075	.2075	.2263
Min	.1132	.1132	.132	.0943	.1132
Avg	.1558	.1627	.1580	.1508	.1611

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 202 / GOYANAKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7842	.7655	.7468	.6722	.7095
2	.7655	.7468	.7468	.6722	.7095
3	.7468	.7468	.7282	.6722	.6908
4	.7468	.7468	.7095	.6908	.7095
5	.8029	.7655	.8029	.6908	.7095
6	1.0269	.9896	1.0456	.8962	.8962
7	1.363	1.251	1.1203	1.251	1.251
8	1.419	1.2883	1.363	1.307	1.3256
9	1.363	1.251	1.363	1.1576	1.1763
10	1.251	1.0456	1.251	1.1016	1.1016
11	1.2883	1.0456	1.1016	1.0456	1.0082
12	1.4377	1.0829	1.1016	.9335	1.0829
13	1.4003	.9709	1.0456	.8589	1.0269
14	1.0082	.8402	.9522	.8402	.9149
15	.8962	.9149	.8962	.8215	.8589
16	.8962	.9709	.9896	.8775	.9335
17	1.0642	1.0829	1.0829	.9896	1.0456
18	1.3817	1.3443	1.3443	1.2696	1.4003
19	1.307	1.363	1.251	1.2136	1.3817
20	1.1016	1.1763	1.0829	1.0456	1.1203
21	1.0456	1.0269	.9709	1.0082	1.0642
22	.9896	.9896	.9335	.9522	.9522
23	.9149	.8962	.8029	.8589	.8775
24	.8402	.8215	.8029	.7095	.7655
Max	1.4377	1.363	1.363	1.307	1.4003
Min	.7468	.7468	.7095	.6722	.6908
Avg	1.0767	1.0051	1.0098	.939	.9880

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 204 / PANKAJ

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.3395	.3547	.2829	.3018
2	.3174	.3395	.3361	.2829	.3018
3	.2987	.3395	.3174	.2829	.3018
4	.3174	.3395	.2987	.2829	.3018
5	.3547	.3395	.3547	.3018	.3206
6	.4303	.4338	.3734	.3772	.415
7	.5415	.4904	.4668	.5093	.4715
8	.5601	.4904	.5415	.4715	.5093
9	.6348	.547	.5601	.5281	.5847
10	.5975	.4904	.6224	.5228	.5658
11	.6161	.4715	.5093	.4668	.4715
12	.6036	.4338	.4715	.3734	.4715
13	.6036	.3584	.4715	.4108	.3961
14	.4338	.3584	.3961	.3174	.3395
15	.3395	.3018	.3206	.2987	.2829
16	.3206	.3395	.3206	.3174	.3206
17	.3584	.3734	.415	.3364	.3395
18	.4715	.5788	.4715	.4904	.4854
19	.5281	.5041	.5281	.4527	.5228
20	.4715	.4668	.462	.4338	.4668
21	.4715	.4481	.4527	.415	.4854
22	.4715	.4481	.4527	.4338	.4108
23	.415	.3921	.415	.3395	.3547
24	.3734	.3772	.3547	.3018	.3395
Max	.6348	.5788	.6224	.5281	.5847
Min	.2987	.3018	.2987	.2829	.2829
Avg	.4528	.4167	.4278	.3846	.4067

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 205 / NEW TAPADIYA NAGAR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2587	.2957	.2772	.2218	.2587
2	.2587	.2772	.2772	.2218	.2587
3	.2402	.2772	.2587	.2218	.2402
4	.2587	.2772	.2402	.2218	.2587
5	.2587	.2587	.2587	.2218	.2587
6	.3174	.3326	.3326	.2957	.3142
7	.3881	.4066	.4251	.4251	.3881
8	.4251	.4435	.5175	.4251	.4805
9	.4251	.4251	.4066	.3511	.4805
10	.3696	.3696	.4435	.3511	.4435
11	.3696	.3142	.4251	.3174	.3326
12	.2957	.2587	.3696	.2587	.2587
13	.2772	.2957	.4066		.2218
14	.2587	.2772	.3326	.2218	.2033
15	.2587	.2587	.2772	.2218	.2218
16	.2957	.2402	.2772	.2218	.2402
17	.2772	.2801	.2957	.2402	.2772
18	.4066	.4251	.3696	.4066	.4066
19	.4805	.4435	.4066	.4066	.4251
20	.4066	.4251	.3696	.4066	.3696
21	.3696	.4251	.3511	.3696	.3696
22	.4066	.3881	.3326	.3511	.3696
23	.3326	.3326	.2957	.3142	.2957
24	.2957	.2772	.2772	.2402	.2587
Max	.4805	.4435	.5175	.4251	.4805
Min	.2402	.2402	.2402	.2218	.2033
Avg	.3305	.3335	.3427	.3015	.3180

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 206 / Ashok nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9149	.8962	.9335	.8029	.8215
2	.8962	.8962	.8962	.7842	.8029
3	.8775	.8962	.8589	.7842	.7842
4	.8775	.8962	.8589	.7842	.8029
5	.9335	.9149	.9335	.7655	.8029
6	1.1576	1.1389	1.1016	1.0269	1.0082
7	1.5059	1.3817	1.3443	1.3443	1.419
8	1.4937	1.363	1.531	1.4377	1.4563
9	1.5123	1.3256	1.5684	1.1763	1.3443
10	1.4377	1.2136	1.4563	1.1576	1.2696
11	1.3256	1.0456	1.2696	1.0642	1.1763
12	1.3256	1.0082	1.2136	.9709	1.0642
13	1.4563	.9896	1.0642	.9709	1.0642
14	1.0456	.8402	.9709	.8589	1.0082
15	.8589	.8962	.8962	.7655	.8402
16	.8962	.8478	.9335	.8402	.9335
17	1.0082	1.0082	1.0269	.9149	1.1016
18	1.4003	1.3443	1.3443	1.307	1.3443
19	1.4377	1.419	1.3817	1.3443	1.4003
20	1.307	1.2696	1.2136	1.2136	1.2883
21	1.251	1.2323	1.1576	1.1389	1.1763
22	1.1389	1.1576	1.0456	1.0269	1.0829
23	1.0642	1.0082	.9335	.9335	.9896
24	.9896	.9335	.9522	.8402	.8589
Max	1.5123	1.419	1.5684	1.4377	1.4563
Min	.8589	.8402	.8589	.7655	.7842
Avg	1.1713	1.0801	1.1203	1.0106	1.0767

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 210 / 11KV Incommer no.I NTN

Feeder KV- 11 / INCOMING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1763	1.2136	1.1576	1.0269	1.1016
2	1.134	1.1763	1.1576	1.0269	1.1016
3		1.1763	1.1203	1.0269	1.0642
4	1.1389	1.1763	1.0829	1.0456	1.1016
5	1.1706	1.1763	1.1949	1.0456	1.1016
6	1.4937	1.4937	1.531	1.3443	1.363
7	1.9418	1.8484	1.7364	1.8858	1.8298
8	2.0165	1.9231	2.0725	1.9231	1.9978
9	1.9791		1.9605	1.6991	1.8484
10	1.7924	1.587	1.8858	1.6244	1.7177
11	1.8111	1.5123	1.7364	1.5123	1.5123
12	1.8858	1.5123	1.6617	1.3352	1.5497
13	1.8111	1.419	1.6057	1.2136	1.4003
14	1.3817	1.2696	1.419	1.1949	1.2696
15	1.2696	1.307	1.307	1.1576	1.2136
16	1.3256	1.3256	1.4003	1.2136	1.2883
17	1.4937	1.4937	1.5123	1.3256	1.4563
18	1.9791	1.9605	1.9044	1.8298	1.9978
19	1.9978	1.9978	1.8671	1.8111	2.0351
20	1.6991	1.7924	1.643	1.643	1.6991
21	1.6057	1.643	1.4563	1.5684	1.6244
22	1.587	1.5684	1.419	1.475	1.4937
23	1.419	1.3717	1.251	1.3256	1.3256
24	1.2696	1.251	1.2136	1.0829	1.1576
Max	2.0165	1.9978	2.0725	1.9231	2.0351
Min	1.134	1.1763	1.0829	1.0269	1.0642
Avg	1.5817	1.4868	1.5123	1.3891	1.4688

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 211 / 11KV Incommer no.2 NTN

Feeder KV- 11 / INCOMING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9418	1.7924	1.957	1.6448	1.6644
2	1.8858	1.7924	1.8656	1.6448	1.6278
3	1.8298	1.7924	1.7741	1.6448	1.5912
4	1.8671	1.7924	1.7558	1.6632	1.6278
5	1.9605	1.829	1.9204	1.7187	1.6278
6	2.2314	2.1948	2.1658	2.0328	2.0119
7	2.8193	2.5972	2.5019	2.6242	2.5606
8	2.8715	2.6337	2.95	2.6427	2.652
9	3.2674	2.8166	2.9447	2.6242	2.8349
10	3.091	2.6337	3.1276	2.7073	2.9264
11	3.1181	2.4143	2.8898	2.5579	2.5873
12	2.9081	2.5057	2.6703	2.2965	1.5154
13	2.8532	2.396	2.5423	2.2131	2.1807
14	2.5057	2.2131	2.3777	2.0725	2.2916
15	2.2314	2.1033	2.2314	1.9418	2.0328
16	2.1765	2.1948	2.3594	1.9791	2.2177
17	2.3594	2.3045	2.4691	2.1098	2.4949
18	2.963	3.2301	2.9384	2.7252	3.0434
19	3.0178	3.0807	2.9199	2.7801	2.9874
20	2.7069	2.7435	2.6513	2.524	2.7633
21	2.524	2.5972	2.4579	2.268	2.6139
22	2.3228	2.4394	2.2731	2.1582	2.2592
23	2.1033	2.1285	2.1068	1.829	2.0725
24	2.0725	1.8839	1.957	1.7002	1.7375
Max	3.2674	3.2301	3.1276	2.7801	3.0434
Min	1.8298	1.7924	1.7558	1.6448	1.5154
Avg	2.4845	2.3379	2.4086	2.1710	2.2468

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 401 / 33 kv I/C Appatapa to New
Tapd Feeder KV- 33 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0727	2.963	3.0727	2.6612	2.7435
2	2.963	2.963	3.0807	2.6612	2.6886
3	2.9081	2.963	2.8532	2.6612	2.6337
4	2.9081	2.963	2.7984	2.7166	2.6886
5	3.0727	2.963	3.0727	2.7721	2.7435
6	3.6763	3.6763	3.6214	3.3819	3.3471
7	4.6639	4.3896	4.1152	4.4907	4.3347
8	4.8285	4.6399	4.8834	4.5462	4.6091
9	5.1578	4.6091	4.8285	4.269	4.6639
10	4.8285	4.1701	4.9931	4.225	4.6091
11	4.8285	3.8958	4.6091	3.9506	4.1027
12	4.7737	4.0055	4.2798	3.5665	3.0493
13	4.6091	3.786	4.1152	3.4019	3.5482
14	3.8409	3.4568	3.7311	3.1824	3.5482
15	3.4568	3.3471	3.5117	3.0178	3.2156
16	3.4568	3.5117	3.7311	3.1276	3.4928
17	3.8409	3.8649	3.9506	3.4168	3.9363
18	4.8834	5.2092	4.8234	4.4993	4.9383
19	4.9931	4.9931	4.768	4.5542	4.9383
20	4.3896	4.4993	4.2135	4.1152	4.3347
21	4.1152	4.257	3.8809	3.786	4.201
22	3.8958	3.9506	3.6591	3.5665	3.6763
23	3.5117	3.4568	3.3265	3.1276	3.4517
24	3.2922	3.1276	3.1276	2.7721	2.8532
Max	5.1578	5.2092	4.9931	4.5542	4.9383
Min	2.9081	2.963	2.7984	2.6612	2.6337
Avg	3.9986	3.8192	3.8770	3.5196	3.6812

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 410 / Transformer no.1

Feeder KV- 33 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1763	1.2323	1.1763	1.0082	1.1203
2	1.1763	1.1763	1.1763	1.0082	1.1203
3	1.1203	1.1763	1.1203	1.0082	1.0642
4	1.1203	1.1763	1.0642	1.0642	1.1203
5	1.1763	1.1763	1.1763	1.0642	1.1203
6	1.5123	1.5123	1.5123	1.3443	1.3443
7	1.9605	1.8484	1.7364	1.9044	1.8484
8	2.0165	1.9044	2.0725	1.9044	2.0165
9	1.9605	1.8484	1.9605	1.6632	1.8484
10	1.7924	1.5684	1.9044	1.6244	1.7364
11	1.7924	1.5123	1.7364	1.5123	1.5123
12	1.9044	1.5123	1.6804	1.3443	1.5684
13	1.7924	1.4003	1.6244	1.2323	1.4003
14	1.4003	1.2883	1.4003	1.1763	1.2883
15	1.2883	1.2883	1.2883	1.1763	1.2323
16	1.3443	1.3443	1.4003	1.2323	1.2883
17	1.5123	1.5123	1.5123	1.3443	
18	1.9605	1.9605	1.9044	1.8484	2.0165
19	2.0165	2.0165	1.8484	1.7924	2.0165
20	1.6804	1.7924	1.6244	1.6244	1.6804
21	1.6244	1.6244	1.4563	1.5684	1.6244
22	1.5684	1.5684	1.4003	1.4563	1.5123
23		1.4003	1.2323	1.3443	1.3443
24	1.2883	1.2323	1.2071	1.0642	1.1763
Max	2.0165	2.0165	2.0725	1.9044	2.0165
Min	1.1203	1.1763	1.0642	1.0082	1.0642
Avg	1.5732	1.5030	1.5090	1.3879	1.4783

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 411 / Transformer no.2

Feeder KV- 33 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9605	1.8296	2.0165	1.6632	1.6461
2	1.8107	1.8107	1.8656	1.6632	1.6461
3	1.8107	1.8107	1.7558	1.6632	1.5912
4	1.8107	1.8296	1.7558	1.6632	1.6461
5	1.9605	1.8296	1.9204	1.7187	1.6461
6	2.2965	2.2177	2.0851	2.0513	2.0302
7	2.7435	2.6057	2.4143	2.6057	2.524
8	2.8532	2.6612	2.8532	2.6612	2.6337
9	3.1824	2.8275	2.9687	2.6057	2.8532
10	3.0727	2.6612	3.1276	2.6886	2.9081
11	3.0727	2.4394	2.9081	2.4691	2.6057
12	2.9081	2.524	2.6337	2.2497	1.4969
13	2.8532	2.4143	2.524	2.1948	2.1622
14	2.4691	2.1948	2.3594	2.0725	2.2731
15	2.2497	2.0851	2.2497	1.9605	2.0513
16	2.1948	2.1948	2.3594	1.9605	2.2177
17		2.3045	2.4691	2.1285	2.4949
18	2.963	3.2487	2.9384	2.7435	2.963
19	3.0493	3.0807	2.9384	2.7984	2.9687
20	2.7166	2.7435	2.6057	2.524	2.7446
21	2.5503	2.5789	2.4394	2.2497	2.5766
22	2.3285	2.4143	2.2731	2.1399	
23	2.1068	2.0851	2.1068	1.8107	2.0302
24	2.0302	1.885	1.9753	1.7187	1.701
Max	3.1824	3.2487	3.1276	2.7984	2.9687
Min	1.8107	1.8107	1.7558	1.6632	1.4969
Avg	2.4780	2.3449	2.3976	2.1669	2.2352

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024047 / 33/11 kv SUBSTATION ITI

AKOLA

Feeder No / Name : 201 / 11 KV ITI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5544	.5175	.5359	.5359	.5544
2	.5175	.4805	.5175	.5359	.499
3	.499	.4805	.4805	.4805	.499
4	.499	.4805	.4805	.4805	.499
5	.5359	.5175	.5175	.5175	.5175
6	.5914	.5914	.5544	.5729	.5729
7	.7392	.7762	.6099	.7023	.7023
8	.8131	.7392	.7207	.7762	.7577
9	.9055	.8131	.7577	.7947	.7947
10	.8501	.8316	.7577	.8686	.8316
11	.8686	.8686	.8686	.961	.9055
12	.9795	.9055	.8316	.961	.961
13	.9795	.9055	.7577	.924	.8686
14	.9055	.8686	.7947	.9055	.924
15	.8871	.8871	.6838	.8501	.8871
16	.8871	.8871	.7392	.8501	.924
17	.8871	.924	.7392	.9425	.9795
18	1.0903	1.2012	.9055	1.0903	1.2567
19	1.1273	1.2567	.961	1.1643	1.2197
20	1.1088	1.1273	.8871	1.1458	1.0903
21	.961	.9795	.8131	.9979	.9795
22	.7947	.8131	.6838	.8316	.8316
23	.6838	.6653	.6283	.7392	.7023
24	.6099	.5729	.5729	.5729	.6283
Max	1.1273	1.2567	.961	1.1643	1.2567
Min	.499	.4805	.4805	.4805	.499
Avg	.8031	.7954	.7000	.8001	.8078

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024047 / 33/11 kv SUBSTATION ITI

AKOLA

Feeder No / Name : 202 / 11 KV MHADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0739	.0554	.0739	.0739	.0554
2	.0739	.0554	.0554	.0554	.0554
3	.0739	.0554	.0554	.0554	.0554
4	.0739	.0554	.0554	.0554	.0554
5	.0739	.0739	.0739	.0739	.0739
6	.1109	.0934	.0739	.0739	.0739
7	.1307	.1307	.0924	.1478	.112
8	.1494	.1494	.1294	.1294	.112
9	.1109	.1307	.0934	.1307	.112
10	.1109	.1478	.1109	.1294	.1109
11	.1109	.1109	.1294	.0924	.0924
12	.0739	.0924	.1109	.0924	.1109
13	.0924	.1109	.0924	.0924	.1109
14	.0924	.1109	.0739	.0747	.0739
15	.1294	.1109	.0739	.0739	.0739
16	.0739	.0924	.0739	.056	.0739
17	.0924	.0924		.0924	.0934
18	.1109	.1478	.1109	.1109	.2054
19	.1109	.1294	.1294	.1109	.1867
20	.1294	.1294	.1109	.1109	.1494
21	.1109	.1109	.1109	.0924	.1307
22	.0924	.0747	.0924	.0924	.1294
23	.0924	.0747	.0924	.0739	.0924
24	.0739	.0739	.0747	.0739	.0554
Max	.1494	.1494	.1294	.1478	.2054
Min	.0739	.0554	.0554	.0554	.0554
Avg	.0987	.1004	.0909	.0902	.0998

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024047 / 33/11 kv SUBSTATION ITI

AKOLA

Feeder No / Name : 203 / 11 KV SHITALA MATA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2012	.2195	.2012	.2012	.2012
2	.1829	.2012	.1829	.1829	.2012
3	.1829	.2012	.1829	.1829	.2012
4	.1829	.2012	.1829	.1829	.2012
5	.2012	.2195	.2195	.2012	.2012
6	.2561	.2561	.2378	.2378	.2561
7	.3475	.3475	.2926	.3109	.3292
8	.3658	.3109	.3109	.3475	.3109
9	.3841	.3109	.3292	.3475	.3881
10	.3475	.3292	.3109	.3475	.3292
11	.3475	.3292	.3109	.3109	.3292
12	.3475	.3658	.2743	.3109	.3109
13	.3292	.3109	.2926	.2926	.2926
14	.3109	.2743	.2218	.3142	.3109
15	.2926	.2743	.2195	.2743	.2926
16	.3109	.2926	.2378	.2743	.3109
17	.3475	.3109	.2378	.3292	.3326
18	.4207	.4024	.2743	.4755	.3841
19	.4755	.4207	.3475	.439	.3658
20	.4207	.3658	.3109	.4024	.3475
21	.3292	.3292	.3109	.3475	.3109
22	.3109	.2743	.2926	.2587	.2743
23	.2561	.2378	.2561	.2378	.2195
24	.2195	.2195	.2195	.2195	.2195
Max	.4755	.4207	.3475	.4755	.3881
Min	.1829	.2012	.1829	.1829	.2012
Avg	.3071	.2919	.2607	.2929	.2884

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024047 / 33/11 kv SUBSTATION ITI

AKOLA

Feeder No / Name : 207 / 11 KV INCOMMER

Feeder KV- 11 / INCOMING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8316	.7947	.8131	.8131	.8131
2	.7762	.7392	.7577	.7392	.7577
3	.7577	.7392	.7133	.7207	.7577
4	.7577	.7392	.7207	.7207	.7577
5	.8131	.8131	.8131	.7947	.7947
6	.961	.9425	.8686	.8871	.9055
7	1.2197	1.2567	.9979	1.1643	1.1458
8	1.3306	1.2012	1.1643	1.2567	1.1827
9	1.4045	1.2567	1.1827	1.2752	1.2936
10	1.3121	1.3121	1.1827	1.3491	1.2752
11	1.3306	1.3121	1.3121	1.3676	1.3306
12	1.4045	1.3676	1.2197	1.3676	1.386
13	1.4045	1.3306	1.1458	1.3121	1.2752
14	1.3121	1.2567	1.0903	1.2936	1.3121
15	1.3121	1.2752	.9795	1.2012	1.2567
16	1.2752	1.2752	1.0534	1.1827	1.3121
17	1.3306	1.3306	1.0719	1.3676	1.4045
18	1.6263	1.7556	1.2936	1.6817	1.848
19	1.7187	1.8111	1.4415	1.7187	1.7741
20	1.6632	1.6263	1.3121	1.6632	1.5893
21	1.4045	1.423	1.2382	1.4415	1.423
22	1.2012	1.1643	1.0719	1.1827	1.2382
23	1.0349	.9795	.9795	1.0534	1.0164
24	.9055	.8686	.8686	.8686	.9055
Max	1.7187	1.8111	1.4415	1.7187	1.848
Min	.7577	.7392	.7133	.7207	.7577
Avg	1.2120	1.1905	1.0538	1.1843	1.1981

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024012 / KUTASA

Feeder No / Name : 201 / 11 KV KUTASA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1109	.0934	.0924	.0739	.0747
2	.1109	.0934	.0924	.0739	.0739
3	.1109	.0747	.0924	.0739	.0739
4	.1109	.0934	.0924	.0739	.056
5	.1109	.0934	.0924	.0739	.0739
6	.1109	.1109	.0924	.0924	.112
7	.1109	.1109	.1109	.0934	.0934
8	.0739	.0924	.0924	.0934	.0924
9	.0739	.0924	.1109	.0747	.0739
10	.0747	.0739	.0924	.0934	.0924
11	.0747	.0739	.0739	.0747	.0739
12	.0747	.0739	.0739	.056	.0554
13	.0747	.0739	.0554	.056	.0554
14	.056	.0554	.0554	.056	.0554
15	.056	.0739	.0739	.0554	.0554
16	.056	.0739	.0739	.0554	.0739
17	.0747	.0739	.0739	.0554	.0739
18	.112	.1294	.1294	.1307	.1294
19	.1663	.1848	.1478	.168	.1478
20	.1478	.1663	.1478	.1663	.1663
21	.1478	.1478	.1478	.168	.1478
22	.1294	.1294	.0924	.1109	
23	.1307	.1109	.0739	.0934	
24	.1109	.1109	.0924	.0739	.0934
Max	.1663	.1848	.1478	.168	.1663
Min	.056	.0554	.0554	.0554	.0554
Avg	.1004	.1003	.0947	.0890	.0884

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024012 / KUTASA

Feeder No / Name : 202 / 11KV Dahihanda

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3921	.3734	.3734	.3174	.2587
2	.3658	.3734	.3734	.2987	.2241
3	.3696	.3511	.3734	.2987	.2427
4	.3734	.3511	.3921	.2772	.2987
5	.3734	.4108	.3921	.2926	.2987
6	.4066	.4481	.4108	.4108	.3696
7	.462	.4108	.4108	.4108	.3881
8	.3658	.4294	.3547	.3511	.3326
9	.4024	.3734	.3734	.3696	.4108
10	.3921	.3734	.3547	.3734	.4294
11	.3734	.3734	.3045	.3734	.3361
12	.3734	.3547	.3258	.3361	.3734
13	.3174	.3361	.2926	.2801	.3174
14	.2957	.3174	.3109	.2957	.3174
15	.3174	.3174	.2743	.2957	.3174
16	.3174	.2987	.3045	.2957	.3174
17	.3361	.2801	.3045	.2987	.2987
18	.4481	.4481	.439	.462	.4668
19	.5228	.5415	.5121	.5601	.5415
20	.5359	.5601	.5304	.4668	.4854
21	.4805	.5041	.4668	.462	.4481
22	.4435	.4481	.4481	.3921	
23	.4481	.4108	.3547	.3547	
24	.4108	.4108	.3734	.3174	.3361
Max	.5359	.5601	.5304	.5601	.5415
Min	.2957	.2801	.2743	.2772	.2241
Avg	.3968	.3957	.3771	.3580	.3550

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024013 / 33 KV CHOHATA

Feeder No / Name : 201 / 11 KV TAKLI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.2033	.2241	.1848	.1848
2	.2075	.4066	.2033	.1867	.1663
3	.2054	.4108	.2054	.1867	.168
4	.2054	.4108	.2033	.1867	.168
5	.2241	.4066	.2075	.1867	.1848
6	.2452	.4436	.2452	.2241	.1829
7	.2263	.4804	.2452	.2378	.2172
8	.1886	.4344	.2075	.2012	.1991
9	.2054	.3506	.2402	.208	.2254
10	.1867	.4206	.2172	.2279	.1753
11	.2033	.3856	.197	.1753	.181
12	.181	.319	.1949	.1578	.1991
13	.1629	.319		.1402	.1991
14	.1949	.3156	.2058	.156	.1791
15	.1791	.312	.1753	.1772	.181
16	.1715	.343	.1753	.1772	.1448
17	.1658	.343	.1865	.197	.197
18	.3012	.3077	.2865	.2534	.362
19	.3681	.3475	.3544	.2835	.3801
20	.3544	.3142	.3155	.2896	.3258
21	.3045	.2987	.2835	.2195	.3142
22	.5122	.2801	.2353	.2195	.2614
23	.4756	.2614	.2195	.1848	.2378
24	.2241	.439	.2241	.2033	.1276
Max	.5122	.4804	.3544	.2896	.3801
Min	.1629	.2033	.1753	.1402	.1276
Avg	.2458	.3564	.2284	.2027	.2151

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024013 / 33 KV CHOHATA

Feeder No / Name : 202 / 11 KV RAIL

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4066	.415	.4108	.3772	.3772
2	.4108	.415	.4066	.3547	.3584
3	.4066	.415		.3584	.3584
4	.4108	.4527	.4108	.3584	.3584
5	.4435	.4904	.4481	.415	.3772
6	.5788	.5847	.547	.5281	.5281
7	.5601	.547	.5847	.6224	.6224
8	.4668	.5228	.5041	.4527	.5228
9	.5304	.4887	.5304	.5175	.3361
10	.5249	.5304	.4887	.5487	.5359
11	.4344	.4938	.5014	.4572	.4572
12	.3761	.439	.3982	.4024	.4207
13	.3761	.3982		.4119	.3658
14	.3403	.3761	.3898	.4075	.3801
15	.3506	.3761	.3506	.3761	.3506
16	.3506	.3544	.3601	.3801	.3544
17	.443	.4298	.3898	.4207	.4075
18	.7133	.6219	.567	.6401	.6401
19	.6908	.6401	.5914	.7023	.6535
20	.6535	.6283	.5601	.6219	.5788
21	.6224	.5601	.547	.5544	.5415
22	.5658	.5041	.4715	.4854	.4668
23	.5093	.4904	.415	.4294	.4294
24	.4481	.4338	.4527	.3772	.4108
Max	.7133	.6401	.5914	.7023	.6535
Min	.3403	.3544	.3506	.3547	.3361
Avg	.4839	.4837	.4694	.4667	.4513

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024013 / 33 KV CHOHATA

Feeder No / Name : 203 / 11 KV CHOHATA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1509	.1509	.1132	.132
2	.1509	.1509	.1494	.1143	.1132
3	.1494	.132	.1509	.1143	.1132
4	.1509	.132	.1494	.1132	.1132
5	.1494	.132	.1509	.1334	.1307
6	.2452	.1886	.2075	.1524	.1867
7	.2263	.2263	.2263	.2378	.2378
8	.2241	.2241	.2427	.2075	.2195
9	.2641	.2195	.2241	.2218	.2054
10	.2241	.2353	.2427	.2012	.197
11	.2149	.2149	.181	.1663	.3902
12	.2241	.1772	.1715	.128	.1646
13	.2195	.1772		.1478	.181
14	.1791	.1734	.1417	.1448	.1433
15	.2402	.1734	.1612	.1267	.1629
16	.2353	.1907	.1696	.1267	.168
17	.2254	.2279	.1781	.1646	.181
18	.3109	.3109	.2686	.2402	.2427
19	.3361	.2957	.2641	.2561	.2829
20	.2801	.2452	.2378	.2241	.2427
21	.2452	.2263	.1867	.1867	.2263
22	.2054	.1886	.1509	.1698	.1698
23	.1867	.1698	.1509	.1509	.1509
24	.1698	.1698	.1509	.132	.132
Max	.3361	.3109	.2686	.2561	.3902
Min	.1494	.132	.1417	.1132	.1132
Avg	.217	.1972	.1873	.1656	.1870

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024013 / 33 KV CHOHATA

Feeder No / Name : 204 / 11 KV KELIVELI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.2096	.1848	.1905	.1905
2	.2033	.2096	.1867	.1905	.1905
3	.2054	.2096	.1886	.1905	.1905
4	.2033	.2096	.1867	.1905	.1905
5	.2054	.2075	.1886	.1905	.1905
6	.2452	.2263	.2641	.2477	.2477
7	.2641	.2452	.2263	.2667	.2667
8	.2427	.2263	.2452	.2096	.2286
9	.2241	.1886	.2263	.2075	.2075
10	.168	.1715	.2033	.2241	.1886
11	.1867	.1698	.2054	.2033	.1698
12	.1494	.1698	.2075	.2218	.1494
13	.1494	.1867		.2033	.1663
14	.1848	.2054	.1886		.1698
15	.2012	.1867	.168	.1848	.132
16	.2012	.168	.1867	.1848	.132
17	.2195	.4298	.1663	.2054	.1663
18	.3395	.3045	.2801	.2641	.2772
19	.4108	.3439	.3206	.2641	.3174
20	.3734	.2829	.2829	.3206	.2829
21	.3206	.2641	.2858	.2829	.2829
22	.3048	.2614	.2477	.2477	.2263
23	.2667	.2263	.2286	.2286	.2263
24	.2263	.2286	.2054	.2096	.1905
Max	.4108	.4298	.3206	.3206	.3174
Min	.1494	.168	.1663	.1848	.132
Avg	.2376	.2305	.2206	.2230	.2075

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024014 / 33 KV UMARA

Feeder No / Name : 201 / 11 KV UMARA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2926	.2058	.2263	1.9022	1.5775
2	.2743	.2058	.2263	1.829	1.6126
3	.2743	.2058	.2263	1.829	1.6476
4	.2743	.2058	.2263	1.6461	1.6476
5	.2743	.2058	.1886	1.5546	1.7528
6	.2378	.1715	.1886	1.5546	1.5432
7	.1463	.1715	.1886	1.5729	1.5432
8	.1463	.1715	.1886	1.7193	1.5074
9	.1463	.1372	.1463	1.6827	1.5432
10	1.9022	1.989	2.0668	.1463	.1372
11	2.1033	1.6644	1.9387	.1448	.1494
12	2.1033	1.6792	1.9387	.1448	.1494
13	1.9982	1.6857	1.8656	.1448	.1509
14	1.9982	1.6347	1.8656	.1448	.1509
15		1.6347	1.8656	.1448	.1509
16	1.8861	1.6255	1.6827	.1448	.1509
17	1.8427	1.6198		.1629	.1698
18	.3206	.2987	.3109	.3395	.3395
19	.3086	.3395	.3109	.3395	
20	.3395	.3395	.3292	.3395	
21	.3395	.3395	.3292	.3395	
22	.3018	.3018	.2378	.3395	
23	.3018	.2829	.2195	.2641	
24	.2926	.2829	.2641	1.9204	1.6126
Max	2.1033	1.989	2.0668	1.9204	1.7528
Min	.1463	.1372	.1463	.1448	.1372
Avg	.7872	.7249	.7405	.8479	.9230

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024014 / 33 KV UMARA

Feeder No / Name : 202 / 11 KV KASOD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.1886	.6979	.6516
2	.1886	.1886	.1886	.6979	.6516
3	.2075	.1886	.1886	.6979	.6661
4	.2075	.1886	.1886	.6979	.6173
5	.2075	.1886	.1886	.6979	.6173
6	.2075	.1698	.1698	.7545	.7545
7	.1886	.1698	.1698	.7922	.823
8	.1886	.1698	.1509	.8865	.8573
9	.1509	.1509	.1509	.9997	.9259
10	.8299	.823	.8488	.1509	.1698
11	1.0288	.8429	1.1317	.132	.168
12	1.0631	.8429	1.1317	.132	.1494
13	1.0631	.8471	1.0751	.132	.1307
14	1.0631	.8322	1.0751	.132	.132
15	1.0631	.8173	1.094	.132	.132
16	1.0631	.873	1.094	.1509	.1509
17	1.0631	.8322	1.0562	.1886	.1886
18	.2075	.2075	.2263	.2452	.2829
19	.2641	.2829	.2641	.2452	
20	.2641	.3018	.2452	.2263	
21	.2641	.2263	.2263	.1886	
22	.2641	.2263	.1886	.1886	
23	.2263	.2263	.0151	.1509	
24	.1886	.1886	.1886	.679	.6516
Max	1.0631	.873	1.1317	.9997	.9259
Min	.1509	.1509	.0151	.132	.1307
Avg	.4855	.4156	.4769	.4165	.4590

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024014 / 33 KV UMARA

Feeder No / Name : 203 / 11 KV BORDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1658	1.4403	1.2193	.1658	.1698
2	1.5415	1.2003	1.2193	.1823	.1698
3	1.6244	1.2003	1.2346	.1823	.1698
4	1.6409	1.2003	1.2037	.1823	.1698
5	1.6409	1.1469	1.2346	.1823	.1509
6	1.9062	1.1736	1.3108	.1658	.1886
7	2.2045	1.2071	1.4352	.2155	.2263
8	2.2045	1.2071	1.6644	.1989	.2263
9	2.2708	1.0486	1.989	.1989	.2075
10	.116	.1132	.1326	1.6078	1.4754
11	.1132	.112		2.2291	1.7833
12	.1132	.112	.0995	2.2466	2.1548
13	.1132	.112	.0995	2.3137	2.3034
14	.0943	.1132	.0995	2.3137	2.3331
15	.0943	.1132	.0995	2.3472	2.3777
16	.0943	.1132	.0995	.3201	2.3167
17	.0943	.132	.0995	1.6385	2.1338
18	.2075	.2263	.1823	.2452	.2452
19	.2263	.2641	.2155	.2452	
20	.2263	.2641	.2321	.2263	
21	.2263	.2263	.2378	.1886	
22	.2263	.2263	.1823	.1886	
23	.2263	.2263	.1492	.1886	
24	.1658	.1886	1.1717	.1326	.1698
Max	2.2708	1.4403	1.989	2.3472	2.3777
Min	.0943	.112	.0995	.1326	.1509
Avg	.7307	.5570	.6788	.7544	.9985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024014 / 33 KV UMARA

Feeder No / Name : 204 / 11 KV ADGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	1.6804	1.6461	.2012	.2172
2	1.7924	1.6804	1.6461	.1829	.2172
3	1.7741	1.6804	1.6309	.1829	.2172
4	1.7375	1.643	1.5653	.1829	.2172
5	1.701	1.643	1.6049	.1829	.181
6	1.7375	1.643	1.5432	.1829	.181
7	1.6827	1.6804	1.5123	.1829	.1448
8	1.5364	1.6804	1.5901	.1463	.1402
9	1.7375	1.7436	1.7558	.1463	.1753
10	.1463	.1372	.1463	1.6095	1.5089
11	.1448	.1463	.1463	1.6289	1.2483
12	.1509	.1478	.1463	1.7528	1.2631
13	.1886	.1494	.1463	1.7528	1.2944
14	.1886	.1494	.1463	1.7528	1.3077
15	.1886	.1509	.1463	1.8229	1.3375
16	.181	.1509	.1463	1.6827	1.4148
17	.181	.1509	.1463	1.7318	1.4937
18	.3018	.3018	.3109	.2641	.2641
19	.3018	.3584	.3109	.2641	
20	.3018	.3772	.2743	.2641	
21	.3018	.3206	.2561	.2641	
22	.2641	.3018	.2195	.2641	
23	.2641	.2641	.2012	.2263	
24	.2561	.2452	1.6358	.2012	.2172
Max	1.7924	1.7436	1.7558	1.8229	1.5089
Min	.1448	.1372	.1463	.1463	.1402
Avg	.7215	.7678	.7864	.7114	.6864

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024015 / 33 KV PANAJ

Feeder No / Name : 201 / 11 KV PANAJ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3395	.2452	.6687	1.0159
2	.3018	.3206	.2614	.6687	1.0631
3	.3018	.3206	.2452	.6539	1.0802
4	.3018	.3584	.2561	.6539	1.0974
5	.3395	.3584	.2427	.6602	1.0688
6	.3772	.3206	.2195	.6661	1.0526
7	.415	.2614	.2452	.7529	1.0562
8	.3584	.2286	.2641	.8951	1.0623
9	.3018		.2279	.9105	1.0526
10	1.0202	.9061	1.0166	.2427	.2195
11	1.1385	.9374	1.0467	.1875	.3206
12	1.1843	1.0155	1.0623	.2641	.3018
13	1.1385	.953	.9511	.2614	.2656
14	1.0753	.9722	.8802	.1494	.2134
15	1.1544	.9842	.8916	.1867	.2829
16	1.1405	.9934	.8619	.2402	.3018
17	1.1092	.9783	1.0229	.2587	.3206
18	.2241	.2926	.2427	.415	.3601
19	.2801	.2835	.2254	.4338	.3961
20	.3395	.298	.2254	.3961	
21	.3584	.298		.415	
22	.3772	.3018	.1219	.3772	
23	.3584	.2801	.1524	.3395	
24	.3921	.3018	.2858	.6516	1.0682
Max	1.1843	1.0155	1.0623	.9105	1.0974
Min	.2241	.2286	.1219	.1494	.2134
Avg	.5970	.5350	.4867	.4729	.6800

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024015 / 33 KV PANAJ

Feeder No / Name : 202 / 11 KV AKOLI J

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5571	.5079	.5571	.426	.4588
2	.5735	.5571	.5898	.426	.4915
3	.5898	.639	.6226	.4424	.5079
4	.5898	.7209	.6882	.4588	.4915
5	.6554	.852	.8029	.5898	.852
6	.7373	.9175	.9503	.6554	.9831
7	.9503	.9503	.9175	.9831	1.0159
8	1.1469	.9995	.9995	.852	.9339
9	1.2616	1.0814	1.065	.7865	.7045
10	.6718	.5898	.7045	.8684	.8029
11	.5571	.4424	.6554	1.1469	1.0814
12	.4424	.3768	4.686	1.1305	1.065
13	.3932	.3277	.3605	1.0159	
14	.3277	.3277	.3113	1.0486	1.0486
15	.3113	.3441		1.0322	1.0159
16	.3441	.3768	.3441	1.0814	1.0322
17	.4096	.3768	.3605	.9831	.9831
18	.6718	.426	.6226	.5898	.6226
19	.7045	.4915	.6882	.7701	.7537
20	.7373	.4752	.6882	.7209	
21	.7537	.639	.639	.6718	
22	.5898	.5243	.5898	.639	
23	.5735	.4915	.4424	.4915	
24	.5571	.4915	.4752	.426	.4096
Max	1.2616	1.0814	4.686	1.1469	1.0814
Min	.3113	.3277	.3113	.426	.4096
Avg	.6294	.5803	.8157	.7598	.8028

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024015 / 33 KV PANAJ

Feeder No / Name : 203 / 11 KV RUIKHED

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1219	.1372	.1372	1.6156	1.6309
2	.1219	.1524	.1524	1.5242	1.6156
3	.1219	.1524	.1372	1.5242	1.7204
4	.1219	.1829	.1219	1.4937	1.6004
5	.1219	.1981	.1372	1.4937	1.6004
6	.1677	.1981	.1524	1.4327	1.6156
7	.1981	.1981	.1677	1.4937	1.6309
8	.1524	.1829	.1829	1.6766	1.6156
9	.1372		.1677	1.7375	1.9357
10	1.7375	1.7071	1.7368	.1524	.1372
11	2.0119	1.829	1.89	.1372	.1219
12	1.9204	2.0576	1.89	.1219	.1219
13	1.9052	2.3624	1.829	.1219	.1219
14		1.9052	1.768	.1219	.1219
15	1.768	1.9204	1.829	.1219	.1372
16	1.8442	1.9357	1.8595	.1219	.1219
17	1.7985	1.9814	1.8747	.1219	.1372
18	.1829	.1524	.1829	.1677	.1372
19	.1981	.1524	.1829	.1829	.2134
20	.1677	.1372	.1829	.1524	
21	.1677	.1372	.1524	.1524	
22	.1372	.1219		.1524	
23	.1372	.1372	.1219	.1524	
24	.1219	.1219	.1219	1.6156	1.6461
Max	2.0119	2.3624	1.89	1.7375	1.9357
Min	.1219	.1219	.1219	.1219	.1219
Avg	.6680	.7853	.7382	.7329	.8992

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024015 / 33 KV PANAJ

Feeder No / Name : 204 / 11 KV RAJURA Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0781	1.065	.9686	.0602	.0328
2	.9602	1.1142	.9061	.0602	.0328
3	.9755	1.1797	.9374	.0602	.0328
4	.9755	1.2289	.9998	.0602	.0655
5	1.0669	1.3108	1.0467	.0602	.0655
6	1.1279	1.3435	1.0155	.0602	.0819
7	1.3565	1.3927	.9686	.0903	.0983
8	1.4937	1.5238	1.0623	.0903	.0983
9	1.4784	1.5893	1.6091	.0753	.1147
10	.061	.0492	.0625	1.2193	1.3272
11	.0492	.0469	.0781	1.8747	.2896
12	.0328	.0469	.0781	2.0317	1.89
13	.0328	.0312	.0312	1.9766	1.9052
14	.0328	.0469	.0312	1.8842	1.7375
15	.0328	.0312	.0312	1.9334	1.6766
16	.0328	.0312	.0469	1.906	1.6309
17	.0328	.0469	.0469	1.8404	1.6461
18	.0819	.0937	.1094	.0655	.0762
19	.0819	.0781	.1094	.1147	.0914
20	.0819	.0625	.0937	.0819	
21	.0819	.0781	.0937	.0655	
22	.0819	.0625	.0903	.0492	
23	.0655	.0469	.0753	.0492	
24	.0781	1.0486	.9374	.0625	.0492
Max	1.4937	1.5893	1.6091	2.0317	1.9052
Min	.0328	.0312	.0312	.0492	.0328
Avg	.4322	.5645	.4762	.6572	.6471

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024031 / 33KV LAKHAMAPUR

Feeder No / Name : 201 / 11 KV BORDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.2987	.3174	1.0936	1.0623
2	.3734	.2987	.3174	1.0936	1.0364
3	.3734	.2987	.3361	1.0936	1.0235
4	.3734	.3018	.3361	1.0936	1.0364
5	.3734	.3734	.3292	1.0936	1.0364
6	.3734	.4481	.3658	1.0936	1.0494
7	.4481	.5601	.4706	1.2498	1.0669
8	.4481	.5601		1.2498	1.1431
9	.4481	.5175	.5487	1.2651	1.2498
10	1.406	1.3717	1.4419	.4024	.2241
11	1.4998	1.4022	1.4632	.2241	.2241
12	1.4998	1.4529	1.3435	.2218	
13	1.4449	1.5384	1.3748	.2241	
14	1.3717	1.5364	1.3748	.2241	.2614
15	1.387	1.4998	1.3748	.2195	.2614
16	1.3717	1.4373	1.2498	.1867	.2987
17	1.3889	1.5432	1.2498	.2054	.2987
18	.381	.4108	.3734	.3582	.3734
19	.415	.4481	.5228	.4108	
20	.4108	.4668	.5975	.415	
21	.4527	.4527	.5975	.4108	
22	.3772	.3772	.5228	.4108	
23	.3734	.3361	.4668	.3734	
24	.3734	.3292	.3174	1.0936	.9998
Max	1.4998	1.5432	1.4632	1.2651	1.2498
Min	.3734	.2987	.3174	.1867	.2241
Avg	.7391	.7608	.7518	.6545	.7439

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024031 / 33KV LAKHAMAPUR

Feeder No / Name : 202 / 11 KV RAMAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934		.0762	1.3717	1.4746
2	.0934	.0953	.0762	1.3717	1.3717
3	.0934	.0943	.0762	1.3717	1.3546
4	.0934	.0762	.0762	1.3717	1.3717
5	.0934	.0762	.0762	1.3717	1.3717
6	.0572	.0762	.0747	1.3717	1.3717
7	.0572	.0953		1.5242	1.3847
8	.0572	.0566	.0572	1.5242	1.531
9	.0572	.0572	.056	1.6385	1.7071
10	1.5242	1.829	1.8233	.0549	.0572
11	1.9814	2.2253	2.1338	.0381	.0381
12	1.9814	2.3122	2.1643	.0381	.0381
13	2.2222	2.3205	1.9814	.0381	.0572
14	2.1948	2.1872	1.9814	.0381	.0572
15	2.1948	2.1872	1.9814	.0373	.0572
16	2.1338	2.1872	1.9814	.0373	.0572
17	2.0729		1.9814	.0373	.0572
18	.0381		.0747	.0373	.0747
19	.0762	2.2466	.112	.0762	
20	.0762	.0953	.112	.0762	
21	.1143	.1143	.112	.1143	
22	.132	.0953	.112	.1143	
23	.0953	.0762	.112	.1143	
24	.112	.0953	.0762	1.3717	1.3108
Max	2.2222	2.3205	2.1643	1.6385	1.7071
Min	.0381	.0566	.056	.0373	.0381
Avg	.7352	.8857	.7525	.6309	.7760

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024031 / 33KV LAKHAMAPUR

Feeder No / Name : 203 / 11 KV POPATKHED

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5959	.5853	.5228	.5258	.4755
2	.5959	.5853	.5175	.5258	.4755
3	.5959	.5853	.5544	.5258	.4755
4	.5959	.5853	.5487	.5258	.4755
5	.5959	.5914	.5853	.5258	.5228
6	.5959	.6219	.6154	.5258	.6584
7	.5959	.6584	.6878	.5258	.695
8	.7011	.6584	.6516	.7011	.7011
9	.7011	.6584	.6371	.7087	.7011
10	.7011	.6584	.6859	.7087	.6097
11	.6859	.5487	.6097	.7095	.5609
12	.6859	.5624	.7011	.695	.5609
13	.5853	.5761	.5258	.6219	.5609
14	.5853	.5624	.5258	.5426	.5609
15	.5853	.5624	.5258	.6219	.5609
16	.6089	.5792	.5258	.6219	.5609
17	.6584	.7202	.5258	.5418	.5609
18	.8048	.7842	.7011	.7316	.7011
19	.8048	.7468	.6859	.695	
20	.7682	.7023	.7011	.6584	
21	.7316	.7468	.7011	.6154	
22	.6584	.7468	.5258	.5487	
23	.6584	.7095	.5258	.5228	
24	.5959	.5243		.5258	.4755
Max	.8048	.7842	.7011	.7316	.7011
Min	.5853	.5243	.5175	.5228	.4755
Avg	.6538	.6358	.5994	.6021	.5733

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024031 / 33KV LAKHAMAPUR

Feeder No / Name : 204 / 11 KV MOHADA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.7185	1.7528		
2	1.6766	1.7185	1.7147		
3	1.6766	1.6766	1.7147		
4	1.6766	1.6766	1.9631		
5	1.6766	1.8747	1.9204		
6	1.6766	1.9685	1.9113		
7	1.829	2.0165	1.9006		
8	2.0424	2.1795	1.829		
9	2.1338	2.3472	2.1052		
10				1.6446	1.768
11				2.6558	2.8045
12				2.915	2.8045
13				2.915	2.7435
14				2.8464	2.7435
15				2.4387	2.7435
16				2.4228	2.4387
17				2.5396	2.4387
24		1.6358	1.7147		
Max	2.1338	2.3472	2.1052	2.915	2.8045
Min	1.6766	1.6358	1.7147	1.6446	1.768
Avg	1.7985	1.8812	1.8527	2.5472	2.5606

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024031 / 33KV LAKHAMAPUR

Feeder No / Name : 205 / water supply express
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2812	.1867	.2241	.1677	.2241
2	.2812	.1848	.2241	.1677	.2195
3	.2812	.1867	.2241	.1677	.2195
4	.2812	.1867	.2195	.1677	.2195
5	.2812	.1867	.2218	.1677	.2241
6	.2812	.1867	.2195	.1677	.2195
7	.2812	.1848	.2195	.1677	.2561
8	.25	.1867	.2058	.1677	.2187
9	.25	.1867	.2012	.1829	.2187
10	.25	.2054	.1943	.1772	.25
11	.1562	.1677	.1829	.2195	.2454
12	.1562	.1718	.1875	.2195	.2187
13	.1848	.192	.1875	.2195	.2187
14	.1829	.1875	.1875	.2378	.2187
15	.2012	.1875	.1875	.2427	.2187
16	.2012	.1875	.1562	.2427	.2187
17	.2012	.2103	.1562	.2241	.2187
18	.2987	.2241	.1562	.2378	.1875
19	.2926	.2218	.1677	.2427	
20	.2801	.2054	.1677	.2378	
21	.2801	.2241	.1677	.2378	
22	.2241	.2241	.1677	.2427	
23	.1867	.2241	.1677		
24	.2812	.1867	.2241	.1677	.2241
Max	.2987	.2241	.2241	.2427	.2561
Min	.1562	.1677	.1562	.1677	.1875
Avg	.2436	.1957	.1924	.2032	.2231

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024033 / 33 kv RUIKHED

Feeder No / Name : 201 / 11 KV RUIKHED

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2263	.2241	.6154	.5761
2	.192	.2263	.2241	.6802	
3	.192	.2263	.2241	.6722	.5761
4	.192	.2263	.2241	.6722	
5	.192	.2263	.2614	.6802	.7362
6	.2881	.2641	.4108	.7042	.7362
7	.2881	.3395	.4108	.7682	.7362
8	.2881	.3395	.2987	.8322	.7362
9		.2641	.2987	.8962	.7362
10	.8322	.759	.7682	.1886	.16
11		1.0242	1.0883	.1886	.1867
12	1.0883	1.0883	1.0562	.16	.1867
13	1.1523	1.1203	1.0242	.128	.1867
14	1.0883	1.0242	1.0242	.096	.1494
15	1.1523	1.0242	1.0242	.096	.112
16	1.2483	1.0883	.9922	.096	.112
17	1.0242	1.0562	.9922	.112	.1494
18	.9922	.2241	.3018	.112	.2614
19	.2641	.2987	.3018	.192	
20	.3018	.2987	.3018	.192	
21	.3018	.2987	.2641	.192	
22	.2641	.2614	.2641		
23	.2263	.2241	.2263	.192	
24	.2241	.2263	.2241	.6154	.5761
Max	1.2483	1.1203	1.0883	.8962	.7362
Min	.192	.2241	.2241	.096	.112
Avg	.5462	.5148	.5179	.3949	.4067

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024033 / 33 kv RUIKHED

Feeder No / Name : 203 / 11 KV VASTAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3521	.8322	.7682	.3353	.2881
2	.8002	1.0242	.7682	.3353	.2881
3	.8002	1.0242	.7362	.3353	.2881
4	.8002	1.012	.7682	.3353	.2881
5	.8002	1.0753	.8002	.3353	.2881
6	1.5364	1.1385	.8962	.3353	.2881
7	1.5364	1.2186		.3353	.2881
8	1.5364	1.4373	1.3123	.3018	.2881
9	1.5364	1.3916	1.1843	.2683	.2881
10	.192	.2012	.2454	.6642	.8642
11	.2012	.2454	.2347	1.2811	
12	.2012	.1753	.2012	1.3123	1.5364
13	.2012	.1753	.2012	1.3763	1.6004
14	.2012	.2103	.2012	1.5684	1.6004
15	.1677	.2103	.2012	1.4723	1.6004
16	.1677	.2454	.2012	1.4723	1.6644
17	.2012	.3155	.2347	1.2483	1.5364
18	.3688	.4207	.4024	.2881	.3506
19	.4024	.4207	.4024	.3841	
20	.4024	.4207	.4024	.3841	
21	.4024	.4207	.4024	.3841	
22	.3688	.3856	.3688	.3841	
23	.3688	.3506	.3353	.3841	
24	.3521	.8223	.7287	.3353	.2881
Max	1.5364	1.4373	1.3123	1.5684	1.6644
Min	.1677	.1753	.2012	.2683	.2881
Avg	.5791	.6322	.5216	.6607	.7575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024033 / 33 kv RUIKHED

Feeder No / Name : 204 / 11 KV Khirkund new

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.208	.1867	.2054	.5243	.4001
2	.176	.1848	.1867	.5761	.4481
3	.176	.1848	.1867	.583	.4481
4	.176	.1848	.1867	.5761	.4481
5	.176	.1848	.2241	.5898	.7042
6	.208	.1848	.2614	.5761	.7042
7	.208	.2033	.2614	.6401	.7042
8	.208	.1848	.2427	.7762	.7042
9	.208	.1663	.2241	.6718	.7042
10		.5376	.5601	.1294	.144
11		.7522	.7202	.1109	.144
12	.9061	.8002	.8162	.096	.1494
13	.953	.9465	.8482	.096	.1494
14	.9686	.8642	.8223	.096	.1494
15	.9686	.8002	.8223	.2561	.1494
16	.9172	.8322	.8421	.2561	
17	.8223	.8322	.8322	.192	.1867
18	.6958	.1867	.2218	.192	.2427
19	.2218		.2587	.2241	
20	.2218	.2614	.2587	.2241	
21	.2587	.2614	.2402	.2241	
22	.2402	.2241	.2218	.2241	
23	.2033	.2241	.2218	.2241	
24	.208	.1848	.2054	.5079	.4481
Max	.9686	.9465	.8482	.7762	.7042
Min	.176	.1663	.1867	.096	.144
Avg	.4241	.4075	.4113	.3569	.3905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024034 / 33 kv SAWARA

Feeder No / Name : 201 / 201 -11 kv sawara gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9574	.7922		.6401	.6811
2	.8669	.7796	.7183	.6535	.6687
3	.8802	.8032	.6935	.6668	.7613
4	.8669	.8421	.7514	.7335	.8109
5	.8802	.9069	.9145	.7335	.9065
6	1.1431	.9587	.9717	.8002	.9511
7	1.2193	1.3496	1.247	.9717	1.2437
8	1.1584	1.3146	1.1843	1.1431	1.2986
9	1.1888	1.262	1.2289	1.1888	1.419
10	1.1888	1.379	1.4842	1.2346	1.363
11	.8882	1.3073	1.1736	.8792	1.1694
12	.8291	1.1498	.8716	.8049	.7868
13	.8269	.9069	.6173	.7922	.7468
14	.7914	1.0288	.7468	.7202	.7468
15	.7914	.9859	.7602	.6969	.7335
16	.815	1.028	.7468	.743	.727
17	.6973	.9164	.7868	.644	.8859
18	1.134	1.5023	1.1288	.9808	1.2193
19	1.1393	1.5927	1.3413	1.1105	1.2955
20	1.0898	1.4842	1.1736	1.0212	1.1736
21	.9998	1.4118	.9859	.8345	1.0364
22	.8779	.9859	.7868	.7796	.8402
23	.8048	.9145	.7068	.7167	.7602
24	.9717	.7802	.9002	.6535	.0704
Max	1.2193	1.5927	1.4842	1.2346	1.419
Min	.6973	.7796	.6173	.6401	.0704
Avg	.9586	1.0993	.9531	.8393	.9290

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024034 / 33 kv SAWARA

Feeder No / Name : 202 / 11 kv sawara ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.5546	1.5927
2				1.7147	1.4575
3				1.5123	1.3756
4				1.448	1.4045
5				1.4327	1.4146
6				1.4575	1.3717
7				1.4022	1.4335
8				1.6004	1.4861
9				1.6156	1.6289
10	1.7833	1.7604	1.6575		
11	1.7981	1.9071	1.7246		
12	1.7433	1.829	1.7665		
13	1.6354	1.72	1.8212		
14	1.6636	1.6777	1.5994		
15	1.5638	1.6289	1.5299		
16	1.5577	1.7231	1.5861		
17	1.5299	1.7535	1.5855		
24				1.4464	1.6651
Max	1.7981	1.9071	1.8212	1.7147	1.6651
Min	1.5299	1.6289	1.5299	1.4022	1.3717
Avg	1.6594	1.7500	1.6588	1.5184	1.4830

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024039 / 33 KV JITAPUR S/S AKOT

Feeder No / Name : 201 / Pimpri(kh)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1913	1.5242	1.6495	.1416	.1509
2	1.3683	1.5546	1.6495	.1405	.1509
3	1.4669	1.5546	1.5901	.1453	.1509
4	1.5508	1.6255	1.5704	.1615	.1698
5	1.6687	1.6255	1.5009	.1852	.1698
6	1.6912	1.6049	1.4266	.1758	.1886
7	1.6724	1.6347	1.5455	.1757	.1886
8	1.7614	1.6347	1.6347	.1758	.1886
9	1.768	1.6347	1.7017	.1886	.1867
10	.1509	.1494	.1407	1.7375	1.9913
11	.1509	.1867	.1057	1.829	1.813
12	.1132	.1494	.0736	1.9204	1.9319
13	.1132	.1494	.1045	1.9662	1.9319
14	.132	.1494	.1046	1.9814	1.9616
15	.1132	.1494	.1041	2.0119	1.9913
16	.0762	.1494	.1095	2.0424	1.9319
17		.1307	.106	1.89	1.8427
18	.2263	.2241	.1757	.1886	.2241
19	.2263	.2427	.2475	.2263	.2241
20	.2263	.2614	.2465	.2263	.2427
21	.2263	.2614	.1821	.2263	.208
22	.2263	.2427	.1757	.1886	
23	.2452	.2427	.1757	.1698	
24	.2193	.2263	1.6347	.1393	.1509
Max	1.768	1.6347	1.7017	2.0424	1.9913
Min	.0762	.1307	.0736	.1393	.1509
Avg	.6776	.7212	.7481	.7598	.8177

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024039 / 33 KV JITAPUR S/S AKOT

Feeder No / Name : 202 / Shahapur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0878	.1132	.0934	1.1001	1.1003
2	.0908	.1132	.0934	1.176	1.1003
3	.0919	.1132	.0934	1.1603	1.1003
4	.0883	.1132	.0934	1.1321	1.1003
5	.0922	.0943	.0934	1.1139	1.1149
6	.0935	.1132	.0934	1.0682	1.1149
7	.091	.1132	.0934	1.1139	1.1149
8	.0707	.0943	.0747	1.2376	1.1149
9	.0566	.056	.0546	1.2029	1.1294
10	1.2631	1.2483	1.3443	.0566	.0373
11	1.3375	1.3969	1.3683	.0377	.0373
12	1.4266	1.4563	1.37	.0377	.0373
13	1.4523	1.4266	1.3752	.0377	.0373
14	1.8673	1.4118	1.4352	.0377	.0373
15	1.4523	1.3672	1.3769	.0377	.0373
16	1.467	1.3375	1.4425	.0566	.056
17	1.3203	1.3226	1.3889	.0754	.0747
18	.1132	.0934	.1057	.1132	.112
19	.1132	.112	.1101	.1132	.1307
20	.132	.1307	.1054	.132	.1307
21	.132	.1307	.123	.132	.1307
22	.132	.112	.1053	.1132	
23	.1132	.112	.1077	.1132	
24	.0877	.1132	.0934	1.1555	1.1145
Max	1.8673	1.4563	1.4425	1.2376	1.1294
Min	.0566	.056	.0546	.0377	.0373
Avg	.5489	.5290	.5265	.5231	.5438

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024039 / 33 KV JITAPUR S/S AKOT

Feeder No / Name : 203 / Shivpur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3839	.3961
2				.3649	.3961
3				.3973	.3961
4				.4177	.3961
5				.3722	.3961
6				.351	.3961
7				.3563	.3961
8				.3868	.3961
9				.4458	.4012
10	.4012	.3269	.43		
11	.4458	.4755	.4396		
12	.4904	.4904	.5023		
13	.4988	.4607	.5169		
14	.4988	.431	.489		
15	.4904	.4607	.5195		
16	.4904	.4755	.5099		
17	.4572	.4607	.4567		
24				.412	.4064
Max	.4988	.4904	.5195	.4458	.4064
Min	.4012	.3269	.43	.351	.3961
Avg	.4716	.4477	.4830	.3888	.3976

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024046 / AKOT M.I.D.C

Feeder No / Name : 201 / M.I.D.C Lohari road
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4481	.4066	.4024	.3961	.2658
2	.4527	.4108	.4108	.3921	.2454
3	.4527	.3881	.4108	.3658	.2427
4	.4481	.3801	.415	.3801	.2641
5	.4435	.3801	.415	.3582	.2427
6	.4435	.3801	.415	.3506	.3018
7	.4525	.3544	.3189	.3258	.3258
8	.4525	.4207	.4251	.3582	.3224
9	.5415	.5847	.5228	.3801	.3761
10	.5847	.6036	.6036	.4338	.6036
11	.6036	.6224	.6224	.362	.5847
12	.5658	.6097	.5658	.3881	.6036
13	.6413	.6097	.4108	.3801	.6036
14	.6602	.6413	.415	.3841	.6036
15	.6478	.679	.415	.4066	.5658
16	.6097	.6097	.3961	.4382	.5788
17	.6097	.547	.415	.4572	.6036
18	.5847	.5906	.3961	.4572	.6036
19	.6036	.5144	.4191	.3658	.5041
20	.5847	.5525	.3361	.2896	.5281
21	.4481	.4294	.3961	.2561	
22	.3921	.4338	.4191	.2801	
23	.3881	.4338	.3696	.2801	
24	.4294	.3841	.3982	.3961	.2743
Max	.6602	.679	.6224	.4572	.6036
Min	.3881	.3544	.3189	.2561	.2427
Avg	.5204	.4986	.4297	.3701	.4402

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024046 / AKOT M.I.D.C

Feeder No / Name : 202 / Hiwarkhed Road industry
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4937	1.4003	1.4937	1.4937	.4401
2	1.4377	1.3306	1.4937	1.4563	.4268
3	1.419	1.3676	1.5123	1.4045	.4146
4	1.419	1.3817	1.4937	1.3306	.4016
5	1.4377	1.419	1.475	1.1888	.3822
6	1.4563	1.419	1.475	1.1706	.3978
7	1.4937	1.3676	1.6032	1.1157	.423
8	1.3121	1.2382	1.1999	.7373	.3909
9	1.643	1.7353	1.8484	.4778	.8383
10	1.8673	2.0767	2.0748	.1707	1.6032
11	1.9427	2.0005	2.3053	.0613	1.6975
12	1.7353	1.9814	2.2481	.0526	1.6975
13	1.773	1.9239	1.9052	.0419	1.7353
14	1.7918	2.0767	1.9433	.0461	2.0748
15	1.8673	2.0957	1.9814	.0713	2.2257
16	1.8673	2.0576	1.9433	.0503	2.1502
17	1.9805	2.2291	1.9433	.1097	2.037
18	1.6975	1.7909	1.8484	.1555	1.3769
19	1.7364	1.6804	1.7177	.1402	1.6804
20	1.773	1.905	1.419	.2578	1.7551
21	1.5089	1.5844	1.7164	.378	
22	1.4523	1.4937	1.358	.5502	
23	1.4377	1.5089	1.6221	.5721	
24	1.531	1.419	1.5123	1.531	.487
Max	1.9805	2.2291	2.3053	1.531	2.2257
Min	1.3121	1.2382	1.1999	.0419	.3822
Avg	1.6281	1.6868	1.7139	.6068	1.1731

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024046 / AKOT M.I.D.C

Feeder No / Name : 203 / 11KV Water supply
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1943	.1966	.208	.176	.1656
2	.1966	.192	.2031	.176	.1635
3	.1966	.1966	.2031	.176	.1635
4	.1966	.1966	.2031	.176	.1635
5	.1989	.1989	.2006	.176	.1635
6	.2035	.2058	.2006	.1783	.1698
7	.192	.2279	.1981	.1783	.1829
8	.2155	.2347	.1966	.1989	.2012
9	.3734	.4854	.3292	.3292	.3696
10	.4715	.462	.4108	.3881	.4066
11	.5281	.4481	.4668	.3921	.2896
12	.4668	.3696	.3696	.4108	.3258
13	.4481	.3258	.2321	.4108	.3258
14	.3696	.3292	.2629	.4066	.3258
15	.3109	.3045	.2507	.4066	.3439
16	.4251	.3292	.2686	.4066	.3658
17	.4904	.3326	.2601	.362	.415
18	.4904	.5093	.2865	.3142	.4715
19	.5281	.5093	.2715	.3326	.4294
20	.3045	.2204	.2401	.1829	.2321
21	.2401	.2056	.1898	.176	
22	.218	.2006	.1614	.176	
23	.1943	.2056	.2241	.1635	
24	.1943	.1966	.213	.176	.1635
Max	.5281	.5093	.4668	.4108	.4715
Min	.192	.192	.1614	.1635	.1635
Avg	.3187	.2951	.2521	.2696	.2780

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024046 / AKOT M.I.D.C

Feeder No / Name : 204 / 11KV Wadali-S

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2033	.2033	.1848	.1663	.1663
2	.2033	.2033	.1848	.1663	.1663
3	.2033	.2033	.1848	.1663	.1663
4	.2033	.2033	.1848	.1663	.1663
5	.2218	.2218	.2033	.1663	.1848
6	.2772	.2587	.2402	.2218	.2402
7	.2772	.2772	.2772	.2772	.2587
8	.2218	.2772	.2587	.2587	.2772
9	.2218	.2957	.2402	.2772	.2402
10	.2033	.2587	.2218	.2218	.3142
11	.2033	.2402	.2033	.2218	.2218
12	.1663	.1848	.1848	.1663	.1848
13	.1478	.1478	.1663	.1478	.1663
14	.1109	.1478	.1663	.1109	.1478
15	.1109	.1294	.1478	.1109	.1478
16	.1109	.1294	.1294	.1109	.1478
17	.1478	.1478	.1294	.1478	.1848
18	.2587	.2402	.2587	.2402	.2772
19	.2957	.2957	.2587	.2772	.2957
20	.2402	.2587	.2033	.2103	.2402
21	.2402	.2402	.2218	.2033	
22	.2218	.2033	.1848	.2033	
23	.2033	.2033	.1663	.1848	
24	.2033	.2033	.1848	.1663	.1663
Max	.2957	.2957	.2772	.2772	.3142
Min	.1109	.1294	.1294	.1109	.1478
Avg	.2041	.2156	.1994	.1913	.2077

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024046 / AKOT M.I.D.C

Feeder No / Name : 205 / 11KV Mundgoan AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1004		.7827	.7628
2		1.1004		.7621	.724
3		1.1003		.7727	.724
4		1.086		.7526	.7335
5		1.1004		.743	.7335
6		1.086		.7827	.7042
7		1.1584		.8078	.7727
8		1.4266		1.0311	1.0059
9				.9808	1.1728
10	1.2811	1.3117	1.2967		
11	1.4083	1.5623	1.3123		
12	1.4582		1.2498		
13	1.3603	1.2803	1.1138		
14	1.0936	1.2342	1.1584		
15	1.1294	1.1888	1.0997		
16		1.2186	1.1279		
17	1.5158	1.1584	1.0997		
19	1.4148				
20	1.3466				
21	1.3321				
22	1.291				
23	1.2003				
24		1.1294		.7926	.7727
Max	1.5158	1.5623	1.3123	1.0311	1.1728
Min	1.0936	1.086	1.0997	.743	.7042
Avg	1.3193	1.2026	1.1823	.8208	.8106

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024016 / 33 KV TELHARA S/STN

Feeder No / Name : 201 / 11 KV GADEGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4066	.8669	.9313	.3437	.3749
2	.6859	.823	1.0387	.3437	.3749
3	.7545	.823	1.0985	.3086	.3906
4	.823	.8619	1.1317	.3395	.3704
5	.8916	.8383	1.1191	.3658	.4012
6	.8745	.8288	1.0608	.3658	.3906
7	.8097	.8848	1.1012	.3353	.4001
8	.9496	.9069	1.0311	.3125	.3086
9	1.0174	.8539	1.0974	.3048	.2743
10	.4024	.2214	.2187	1.0364	1.0753
11	.3239	.2214	.2187	1.166	1.2018
12	.2949	.1898	.1875	1.1469	1.2431
13	.2984		.1875	1.1336	1.2266
14	.2591		.1875	1.1012	1.1336
15	.2241		.2134	1.1984	1.1336
16	.2591	.2915	.2134	1.1702	1.1523
17		.3277	.2134	1.1385	1.2018
18	.3582	.3772	.3224	.4656	.4805
19	.4755	.4557	.4706	.4755	.4572
20	.439	.5544	.543	.439	.4755
21	.3982	.5121	.543	.4024	.4572
22	.3696	.4755	.4525	.3982	.462
23	.3658	.4066	.3887	.3982	.462
24		.924	.8413	.3749	.3395
Max	1.0174	.924	1.1317	1.1984	1.2431
Min	.2241	.1898	.1875	.3048	.2743
Avg	.5310	.6021	.6171	.6277	.6578

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024016 / 33 KV TELHARA S/STN

Feeder No / Name : 202 / 11 KV BELKHED

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.4062	.4687
2	1.0974			.3906	.4374
3	1.0631			.4321	.4687
4	1.0288			.463	.4938
5	.9945			.4268	.463
6	.9069			.4572	.4999
7	.9393			.4877	.5121
8	.9496			.4687	.463
9	.9835		.9259	.4877	.5182
10	.6036	.4744	.4999	1.2955	1.1385
11	.6154	.506	.4999	1.3279	1.5181
12	.5898	.6009	.6249	1.5729	1.6907
13	.5636	.6097	.5937	1.3927	1.7238
14	.6478	.6081	.5624	1.4899	1.6518
15	.6081	.5182	.5487	1.4575	1.6194
16	.583	.583	.5182	1.5813	1.4083
17	.5304	.6554	.4877	1.5181	1.5813
24				.3906	.463
Max	1.0974	.6554	.9259	1.5813	1.7238
Min	.5304	.4744	.4877	.3906	.4374
Avg	.7941	.5695	.5846	.8915	.9511

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024016 / 33 KV TELHARA S/STN

Feeder No / Name : 203 / 11 KV TELHARA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1827	1.1096	1.0745	.7811	.9686
2		1.0974	1.1462	.7811	.9374
3		1.0974	1.0985	.8025	.9061
4		.9945	1.0631	.8488	.8642
5		1.0059	1.0174	.8535	.9259
6		.9282	.8951	.8535	1.0311
7		.9503	.8745	.9145	1.1843
8		.9717	.8124	.9374	1.1111
9		.8855		.884	1.1431
10	1.1736	1.1385	1.2498		
11	1.3927	1.5813	1.1873		
12	1.6057	1.6762	1.2186		
13	1.6575	1.6461	1.1248		
14	1.6842	1.5927	1.0936		
15	1.5364	1.6156	1.0669		
16		1.6842	1.0974		
17	1.5581	1.8023	1.2193		
18	1.4327	1.6461	1.1462	1.1462	1.4784
19	1.6827	1.5424	1.3032	1.6095	1.7558
20	1.7558	1.5893		1.4998	1.7375
21	1.5203	1.5729	1.3394	1.39	1.4632
22	1.4784	1.5364	.9955		1.2936
23	1.3169	1.4784	1.0059	1.1584	1.1827
24	1.2567	1.2197	1.3169	.8124	.9259
Max	1.7558	1.8023	1.3394	1.6095	1.7558
Min	1.1736	.8855	.8124	.7811	.8642
Avg	1.4823	1.3484	1.1067	1.0182	1.1818

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024016 / 33 KV TELHARA S/STN

Feeder No / Name : 204 / 11 KV MALEGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7023	2.6006	2.7221	.5937	.4374
2	2.7435	2.5377	2.6863	.6249	.4687
3	2.8807	2.5034	2.5869	.5556	.4687
4	2.915	2.4531	2.5377	.5864	.4938
5	3.155	2.4478	2.5434	.6097	.5556
6	3.0445	2.3868	2.7183	.6097	.5937
7	2.5911	2.2939	2.7206	.5487	.5761
8	3.2556	2.3644	2.5934	.5312	.4938
9	3.2217	2.2138	2.7435	.4572	.4572
10	.6036	.4111	.4062	2.753	2.9096
11	.5182	.3795	.4374	3.0769	2.9096
12	.4915	.3795	.4374	3.0803	3.083
13	.4641	.3353	.3437	3.1093	3.1161
14	.421	.3475	.3125	3.0769	3.0769
15	.3841	.3353	.3658	3.0121	3.1093
16	.3887	.3887	.3048	2.878	2.8807
17	.431	.4588	.3048	2.9096	2.6882
18	.5014	.5487	.5014	.5731	.6653
19	.6584	.6661	.6516	.6219	.695
20	.7316	.6661	.7602	.6219	.6584
21	.6878	.7392	.7602	.5487	.6584
22	.5914	.695	.724	.5068	.5544
23	.5853	.6653	.6878	.5068	.5544
24	.7023	2.7721	2.5606	.5937	.4012
Max	3.2556	2.7721	2.7435	3.1093	3.1161
Min	.3841	.3353	.3048	.4572	.4012
Avg	1.3612	1.3162	1.3921	1.3744	1.3544

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024016 / 33 KV TELHARA S/STN

Feeder No / Name : 205 / TUDGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3696	.2427	.2865	1.3279	1.3279
2	.3086	.2058	.3224	1.3592	1.3279
3	.3086	.2058	.2835	1.3272	1.2811
4	.2743	.1989	.2401	1.3117	1.2809
5	.2743	.1677	.2035	1.0669	1.2346
6	.2267	.1658	.1989	1.2193	1.3123
7	.2267	.1638	.1943	1.2803	1.3603
8	.2035	.1619	.1562	1.2811	1.3272
9	.1696	.1581	.1715	1.2955	1.3717
10	1.576	1.6446	1.656	.2267	.2214
11	1.5546	1.5813	1.6872	.1943	.1898
12	1.6057	1.7394	1.656	.1638	.2984
13	1.8233	1.6461	1.6872	.1619	.1658
14	2.0081	1.5927	1.6872	.2267	.2591
15	1.8564	1.6004	1.6766	.1943	.2267
16	1.8138	1.8138	1.6156	.1581	.192
17	1.7901	1.9662	1.5242	.1581	.1898
18	.2865	.3086	.2865	.2865	.2218
19	.3658	.3856	.4344	.2926	.3658
20	.4024	.4066	.4706	.3292	.3292
21	.362	.3658	.4706	.2926	.3292
22	.3326	.3292	.2715	.3258	.3142
23	.2926	.2957	.2534	.2896	.2772
24	.3696	.2587	.2926	.8436	1.2963
Max	2.0081	1.9662	1.6872	1.3592	1.3717
Min	.1696	.1581	.1562	.1581	.1658
Avg	.7834	.7336	.7386	.6505	.6959

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024017 / HIWARKHED S/S

Feeder No / Name : 201 / 11 KV HKD feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.6348	.6348	.5228	.5601
2	.5487	.6722	.6348		.5601
3	.5975	.6722	.6722	.5228	.5975
4	.5975	.7468	.6722	.5601	.5975
5	.7095	.8402	.7282	.7468	.6535
6	1.0829	1.0082	1.0456	.9149	.8029
7	1.0456	1.1576	1.1203	.9335	1.0456
8	.8573	.9709	1.0082	.9522	.9709
9	.8421	8.6633	.9335	.8402	.8962
10	1.0082	.724	.7888	.7888	.8215
11	.8589	.724	.7545	.724	.7842
12	.8402	.583	.6859		.6722
13	.6908	.583	.5144	.5487	.5601
14	.6161	.583	.4858	.6173	.5415
15	.6535	.5506	.5487	.6104	.5975
16	.6535	.6348	.5487	.6173	.5975
17	.7468	.7095	.7095	.7095	.583
18	1.0269	1.0082	.9335	.7655	1.0288
19	.9896	.9709	.9709	.8589	.8916
20	.9149	.9522	.8215	.8589	.7888
21	.8589	.8589	.7468	.7468	.7545
22	.8215	.7468	.6908	.6908	.7095
23	.7468	.7095	.5975	.6161	.6722
24	.5487	.6348	.6348	.5415	.5601
Max	1.0829	8.6633	1.1203	.9522	1.0456
Min	.5487	.5506	.4858	.5228	.5415
Avg	.7835	1.0975	.7451	.7131	.7186

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024017 / HIWARKHED S/S

Feeder No / Name : 202 / GORDHA FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.4748	.5935
2				.4748	.5765
3				.4748	.5765
4				.4409	.5765
5				.4409	.5765
6				.4409	.5765
7				.4239	.6104
8				.5935	.5765
9				.6104	.6443
10	.7291	.7125	.6478		
11	.8139	.8421	.7449		
12	.8648	.8421	.7773		
13	.9326	.7773	.7773		
14	.7969	.7773	.7449		
15	.8453	.7773	.7449		
16	.8478	.8478	.8097		
17	.8139	.8817	.8478		
24				.4917	.5935
Max	.9326	.8817	.8478	.6104	.6443
Min	.7291	.7125	.6478	.4239	.5765
Avg	.8305	.8073	.7618	.4867	.5901

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024017 / HIWARKHED S/S

Feeder No / Name : 203 / SAUNDALA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0362	1.0631	.0362	.0332
2	1.0526	1.0802	1.0442	.0362	.0332
3	1.0486	1.0288	1.0442	.0362	.0332
4	1.0486	1.0288	1.0774	.0362	.0332
5	1.0486	.9945	1.0774	.0362	.0332
6	1.0486	.9945	1.094	.0362	.0332
7	1.1469	1.1022	1.1191	.0362	.0362
8	1.2955		1.0774	.0362	.0362
9	1.3765	1.278	1.1469	.081	.0362
10	.0332	.0362	.0339	1.166	1.065
11	.0332	.0324	.0324	1.3603	1.4091
12	.0332	.0324	.0324	1.3927	1.4746
13	.0332	.0324	.0339	1.3279	1.4419
14	.0332	.0324	.0339	1.3279	1.278
15	.0332	.0324	.0343	1.3279	1.4255
16	.0332	.0332	.0324	1.3279	1.4419
17	.0332	.0332	.0362	.2984	1.3927
18	.0332	.0332	.0362	.0332	.0324
19	.0332	.0332	.0362	.0332	.0324
20	.0332	.0332	.0362	.0332	.0324
21	.0332	.0332	.0362	.0362	.0343
22	.0332	.0362		.0362	.0362
23	.0332	.0362	.0362	.0362	.0362
24	.0343	.0362	1.1145	.0362	.0362
Max	1.3765	1.278	1.1469	1.3927	1.4746
Min	.0332	.0324	.0324	.0332	.0324
Avg	.4000	.3500	.4917	.4227	.4782

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024017 / HIWARKHED S/S

Feeder No / Name : 204 / Wari express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0328	.0332	.032
2	.0362	.0343	.032	.0332	.032
3	.0343	.0343	.032	.0332	.032
4	.0343	.0343	.032	.0332	.032
5	.0343	.0343	.032	.0332	.032
6	.0343	.0343	.032	.0332	.032
7	.0343	.0328	.032	.0332	.0343
8	.0362	.0328	.032	.0332	.0343
9	.0324	.0328	.0328	.032	.0343
10	.032	.0362	.0362	.0362	.0332
11	.032	.0343	.0362	.0362	.0332
12	.032	.0343	.0324	.0324	.0332
13	.032	.0343	.0324	.0324	.0332
14	.032	.0362	.0339	.0343	.0332
15	.032	.0343	.0343	.0324	.0332
16	.032	.032	.0324	.0324	.0332
17	.032	.032	.0328	.032	.0324
18	.032	.032	.0343	.032	.0324
19	.032	.032	.0343	.032	.0343
20	.032	.032	.0343	.032	.0343
21	.032	.032	.0343	.0343	.0362
22	.032	.0343	.0332	.0343	.0343
23	.032	.0343	.0332	.0343	.0343
24	.0362	.0343	.0343	.0332	.0343
Max	.0362	.0362	.0362	.0362	.0362
Min	.032	.032	.032	.032	.032
Avg	.0331	.0337	.0333	.0333	.0333

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024017 / HIWARKHED S/S

Feeder No / Name : 205 / DIWANZARI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.116	2.0885	.1097	.0995
2	1.9757	1.989	2.0885	.128	.0995
3	1.989	1.989	2.0885	.128	.0995
4	1.8233	1.989	2.1051		.0995
5	1.8233	1.989	2.1051	.128	.0995
6	1.8233	1.989	2.0719	.128	.0995
7	1.8233	1.989	1.9559	.128	.1326
8	1.9433	2.0719	2.1548	.128	.0995
9	1.9757	2.1879	2.1879	.0983	.0995
10	.0995	.1448	.1086	2.3482	2.364
11	.0497	.0972	.0972	2.4615	2.6322
12	.0995	.0972	.1029	2.7206	2.7664
13	.0995	.1029	.0972	2.5101	2.7161
14	.0663	.081	.0972	2.4615	2.5484
15	.0663	.081	.0972	2.7206	2.1795
16	.0829	.0829	.0972	2.7206	2.5987
17	.0995	.0663	.0829	2.652	2.4615
18	.116	.0995	.116	.1326	.1457
19	.1326	.116	.1326	.116	.1296
20	.1326	.1326	.1326	.0995	.1372
21	.1326	.1326	.1326	.0995	.1357
22	.1326	.1326	.1463	.0995	.1326
23	.1326	.1326	.1097	.116	.1326
24	.1372	.116	2.1548	.1097	.0995
Max	1.989	2.1879	2.1879	2.7206	2.7664
Min	.0497	.0663	.0829	.0983	.0995
Avg	.7039	.7469	.9396	.9715	.9212

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024017 / HIWARKHED S/S

Feeder No / Name : 206 / KHANDALA FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				2.1052	2.1052
2				2.1052	2.0243
3				2.1052	2.0243
4				2.1052	1.9433
5				2.1862	1.9433
6				2.1052	1.9433
7				2.1052	1.9109
8				2.1052	2.0243
9				2.1862	2.4291
10	2.2348	2.5587	2.4291		
11	2.2672	2.4291	2.5911		
12	2.4291	2.5911	2.5911		
13	2.5263	2.4291	2.5587		
14	2.2672	2.4291	2.4291		
15	2.3967	2.4291	2.4291		
16	2.4939	2.4291	2.4291		
17	2.5911	2.4291	2.3482		
24				2.3482	2.1862
Max	2.5911	2.5911	2.5911	2.3482	2.4291
Min	2.2348	2.4291	2.3482	2.1052	1.9109
Avg	2.4008	2.4656	2.4757	2.1457	2.0534

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024018 / 33 KV ADGAON S/S

Feeder No / Name : 201 / 11 KV KHARKHED SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029			.8916	.823
2	.1029	.0678	.1017	.8916	.823
3	.0686			.9259	.823
4	.0686	.0678	.1017	.9259	.8478
5	.0686			.8916	.8478
6	.0686	.0678	.1017	.9259	.8916
7	.0686	.0678		.8916	.8478
8	.0686	.0678		1.0288	.8478
9	.0686	.0678	.1017	1.0631	.9945
10	1.0631	.8916	.8573		.1029
11	1.0631	.8916	1.0852	.0678	.1029
12	1.0852	1.0288	1.1065	.0678	.1029
13	1.1317	1.0631	1.1401	.0848	.1029
14	1.1191	1.0974	1.153	.0678	.1029
15	1.0852	1.1317	1.1191	.0678	.1029
16	.9602		1.153		
17	1.1401		1.0513		
18	.1017	.1017	.1029	.0678	.0678
19	.1017	.1696	.1029	.0678	.0678
20	.1017	.1696	.1029	.104	.0678
21	.1017	.1357	.1029	.1029	.0678
22	.0678	.1357	.1029	.0686	.0678
23			.1029	.0686	.0678
24	.1029	.0678	.1017	.8916	.8573
Max	1.1401	1.1317	1.153	1.0631	.9945
Min	.0678	.0678	.1017	.0678	.0678
Avg	.4309	.4051	.5153	.4840	.4376

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024018 / 33 KV ADGAON S/S

Feeder No / Name : 202 / 11 KV UMARA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144			.4801	.4801
2	1.0288	.8573	.8573		.4801
3	1.0631			.4458	.4801
4	1.0974	1.0288	.9431	.4458	.5144
5	1.0974			.4458	.5144
6	1.0974	1.0631	1.0288	.3201	.5487
7	1.0631	1.0631		.3429	.5548
8	1.0974	1.0974	1.0631	.5144	.5895
9	1.0974	1.0631	1.0288	.5144	.5144
10	.5144	.5144	.5487		1.0288
11	.5144	.4801	.5487	.9431	1.0288
12	.5144	.4801	.5087	1.0631	1.0631
13		.5144	.4748	1.0288	1.0631
14	.5087	.4801	.4748	1.0288	1.0974
15	.5144	.4801	.503	1.0974	1.0974
16	.503	.5144	.4748		
17	.5087	.4801	.503		
18	.5487	.5087	.5144	.5087	.5087
19	.5487	.5426	.4801	.5426	.5087
20	.5426	.5426	.5144	.5487	.5426
21	.5426	.5426	.5144	.5201	.5087
22	.5426	.5426	.5144	.5144	.4748
23			.4801	.5144	.4748
24	.5144	.5087	.5087	.4801	.5144
Max	1.0974	1.0974	1.0631	1.0974	1.0974
Min	.503	.4801	.4748	.3201	.4748
Avg	.7261	.6652	.6242	.6150	.6631

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024018 / 33 KV ADGAON S/S

Feeder No / Name : 204 / 11 KV CHITTALWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1831			2.4006	2.1948
2	.4115	.407	.407	1.2003	1.166
3	.4115			1.0288	1.1317
4	.3429	.373	.373	1.0288	1.1191
5	.3429			.9945	1.0974
6	.2743	.3391	.373	.9945	1.1317
7	.3086	.3391		.9259	1.0631
8	.3086	.3052	.3052	1.0631	1.0174
9	.3086	.3052	.3052	1.0288	.9602
10	1.6004	1.3717	1.0288		1.2346
11	2.6791	2.7778	2.713	1.3717	1.2346
12	2.6825	2.6749	2.649	2.0576	1.2346
13	1.4083	3.1207	2.6825	1.8861	1.286
14	1.3748	3.1207	2.7808	2.0919	1.2346
15	2.3739	3.155	2.7161	2.2977	1.1831
16	2.6452	3.1207	2.8166		
17	2.7831	3.0864	2.6452		
18	1.2003	.8573	1.0288	1.0288	.8573
19	1.2346	1.0288	1.0288	1.0631	1.0288
20	1.2003	1.0631	.9945	1.0513	1.0631
21	1.2003	1.0288	.9259	1.0288	1.0288
22	1.2003	1.0288	.9259	1.0288	.9945
23			.8916	.9602	.9602
24	1.1831	1.166	1.0288	1.5775	1.6804
Max	2.7831	3.155	2.8166	2.4006	2.1948
Min	.2743	.3052	.3052	.9259	.8573
Avg	1.2460	1.5335	1.4310	1.3385	1.1774

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024018 / 33 KV ADGAON S/S

Feeder No / Name : 205 / 11 KV Water Supply Express NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6				.0514	
7	.0343	.0335		.0343	
8	.0514	.0335	.0335	.0514	
9	.0343	.0503	.0335	.0514	
10	.0514	.0514	.0503		.0514
11	.0339	.0514	.0509	.0335	.0514
12	.0343	.0514	.0339	.0503	.0514
13	.0343	.0514	.0509	.0335	
14	.0343	.0514	.0514	.0335	.0514
15	.0514	.0514	.0343	.0503	.0343
16	.0339	.0514	.0343		
17	.0171	.0171	.0343		
18	.0168	.0168		.0168	.0168
19		.0168		.0168	
Max	.0514	.0514	.0514	.0514	.0514
Min	.0168	.0168	.0335	.0168	.0168
Avg	.0356	.0406	.0407	.0385	.0428

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024027 / 33 KV MANATRI

Feeder No / Name : 201 / 11 KV PANCHGAVHAN SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.583	.6516	
2		.5658	.6859	
3		.5487	.7202	
4		.5658	.7545	
5		.583	.823	
6		.6687	.823	
7		.8573	.9088	
8		.6516	.6859	
9		.583	.7202	
10	.5335	.4458	.503	
11	.503	.5144	.5182	
12	.442	.5144	.503	
13	.4115	.5316	.4572	
14	.3963	.5316	.4572	
15	.381	1.5775	.442	
16	.4268	.5487	.4725	
17	.4572	.5487	.4287	
18	.6687	.8059	.703	
19	.823	.7716	.7545	
20	.7545	.823	.7545	
21	.7373	.823	.6859	
22	.6859	.7888	.6173	
23	.6687	.6516	.5144	
24		.6173	.5658	.4287
Max	.823	1.5775	.9088	.4287
Min	.381	.4458	.4287	.4287
Avg	.5635	.6709	.6313	.4287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024027 / 33 KV MANATRI

Feeder No / Name : 202 / 11 KV ADSUL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6344	.6859	
2		.6173	.6859	
3		.6001	.6859	
4		.6173	.6859	
5		.6001	.6859	
6		.6516	.6859	
7		.6859	.6687	
8		.5144	.5658	
9			.5144	
10	.7468			
11	.7164	.6859	.7926	
12	.6859	.7202	.8078	
13	.6401	.7202	.7773	
14	.6249	.823	.7926	
15	.6097	.8573	.823	
16	.6401	.8573	.7621	
17	.6097	.8573	.8059	
18	.7202	.6516	.6859	
19	.8402	.8573	.6859	
20	.823	.8916	.7202	
21	.823	.8573	.6516	
22	.7716	.823	.6173	
23	.7202	.7202	.5487	
24		.6687	.6687	.6001
Max	.8402	.8916	.823	.6001
Min	.6097	.5144	.5144	.6001
Avg	.7123	.7233	.6958	.6001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024027 / 33 KV MANATRI

Feeder No / Name : 205 / 11 kV BHAMBERI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.1033	2.5034	
2		2.1186	2.5034	
3		2.1186	2.4691	
4		2.1795	2.4691	
5		2.1643	2.5034	
6		2.0881	2.5034	
7		2.1491	1.8861	
8		2.2558	1.9033	
9		2.1033	1.989	
10	1.6309	1.8004	1.4175	
11	1.6613	1.8519	1.6309	
12	1.7223	1.8176	1.5851	
13	1.6918	1.7833	1.6918	
14	1.6613	1.8004	1.4022	
15	1.5851	1.7833	1.4937	
16	1.6156	1.8004	1.5089	
17	1.6613	1.6975	1.7661	
18	.6687	.6173	.5316	
19	.6859	.6859	.823	
20	.6859	.7202	.823	
21	.6687	.7545	.6859	
22	.6344	.7888	.6173	
23	.6001	.6859	.4801	
24		2.0119	2.4691	1.6804
Max	1.7223	2.2558	2.5034	1.6804
Min	.6001	.6173	.4801	1.6804
Avg	1.2267	1.6617	1.6524	1.6804

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024032 / 33 KV Danapur

Feeder No / Name : 201 / 11 KV Danapur SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.4458	.4763	.6097	.5693
2	.4287	.4115	.4763	.6401	.5937
3	.4287	.4115	.4763	.6706	.5937
4	.4287	.0343	.4763	.703	.6562
5	.4287	.3601	.4763	.6944	.6718
6	.4458	.3772	.4763	.7432	.6874
7	.4458	.3429	.4763	.7186	.6874
8	.3772	.3429	.4001	.7343	.7335
9	.3429	.3086	.3429	.7011	.7842
10	.7621	.8383	.7811	.2743	.3239
11	.8223	.945	.9686	.2229	.2667
12	.9069	.945	1.0722	.2401	.3048
13	.9945	.9297	1.0212	.2667	.2858
14	.8688	.953	1.0364	.3239	.2743
15	.9488	.953	1.0669	.2667	.2743
16	.9686	.9693	1.0936	.3048	.2743
17	.8993	.8749	1.0212	.3239	.2915
18	.5316	.5335	.4458	.4954	.4458
19	.5316	.5525	.5144	.5335	.5144
20	.5487	.5906	.4801	.4954	.4973
21	.5144	.5716	.4801	.4763	.4973
22	.4801	.5335	.4115	.4572	
23	.4458	.4763	.3772	.4191	
24	.4954	.4458		.5944	.5441
Max	.9945	.9693	1.0936	.7432	.7842
Min	.3429	.0343	.3429	.2229	.2667
Avg	.6059	.5895	.6455	.4962	.4896

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024032 / 33 KV Danapur

Feeder No / Name : 202 / 11 KV Warkhed SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1543	.5937	.1372	.1524
2	.4572	.5182	.5937	.1372	.1524
3	.4877	.5624	.5937	.1029	.1524
4	.5182	.6249	.6093	.1372	.1524
5	.5335	.6401	.6249	.1029	.1524
6	.5639	.7316	.6562	.1029	.1524
7	.5944	.7716	.6874	.1029	.1524
8	.7316	.823	.5053	.1132	.1334
9	.6401	.7773	.8855	.0686	.1143
10	.0857	.0686	.0953	.7316	.9326
11	.0686	.0686	.0953	.9755	1.2163
12	.0514	.0686	.0953	1.0822	1.2803
13	.0686	.0343	.0857	1.2003	1.2176
14	.0686	.0762	.0857	1.1043	.9755
15	.0857	.0953	.0686	1.0501	1.0311
16	.0857	.0953	.0686	1.0402	1.0059
17	.1029			1.0883	1.012
18		.1905	.1372	.1524	.1715
19	.2058	.1905	.2058	.1715	.2229
20	.2058	.1905	.2058	.1715	.2058
21	.1715	.2286	.1715	.1905	.1886
22	.1715	.1905	.1715	.1905	
23	.1543	.1905	.1372	.1715	
24	.1715	.1543	.5738	.1372	.1524
Max	.7316	.823	.8855	1.2003	1.2803
Min	.0514	.0343	.0686	.0686	.1143
Avg	.2781	.3237	.3455	.4359	.4967

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024032 / 33 KV Danapur

Feeder No / Name : 203 / 11 KV Hingani SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1029	.1334	1.1888	1.1248
2	.1334	.1029	.1334	1.2186	1.1873
3	.12	.1029	.1334	1.2498	1.1873
4	.12	.0857	.1334	1.2186	1.2334
5	.12	.0686	.1334	1.3123	1.2483
6	.1029	.0686	.1334	1.3108	1.3123
7	.0857	.0686	.1143	1.3245	1.4243
8	.0686	.0686	.0572	1.3413	1.4667
9	.0686	.0514	.0762	1.3717	1.6129
10	1.5699	1.8976	1.7806	.0686	.0762
11	1.8435	2.0424	2.0607	.0514	.0572
12	1.8747	2.2131	1.971	.0343	.0762
13	1.7375	1.9528	2.0153	.0572	.0762
14	1.5546	1.8747	1.9052	.0762	.0686
15	1.8185	1.8278	1.9608	.0762	.0514
16	1.8501	1.8122	1.89	.0572	.0514
17	1.8404	1.8637	1.8122	.0762	.0514
18	.1543	.1524	.1029	.1524	.1029
19	.1543	.1715	.1372	.1905	.1543
20	.1543	.1905	.1372	.1715	.1372
21	.1543	.1905	.1029	.1524	.1372
22	.1372	.1524	.1029	.1334	
23	.12	.1334	.1029	.1334	
24	.1524	.12	.1334	1.1584	1.1203
Max	1.8747	2.2131	2.0607	1.3717	1.6129
Min	.0686	.0514	.0572	.0343	.0514
Avg	.6695	.7215	.7193	.5886	.6344

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024032 / 33 KV Danapur

Feeder No / Name : 204 / balhadi feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.2058	1.7394	.5624	.7042
2	1.6004	1.5935	1.7711	.5418	.6958
3	1.6766	1.6766	1.7711	.5792	.6958
4	1.7528	1.7711	1.7711	.5792	.68
5	1.7985	1.7985	1.8027	.6173	.68
6	1.829	1.9685	1.8185	.6401	.68
7	1.9357	2.0119	1.9044	.6706	.68
8	2.21	2.1948	2.1741	.6836	.7691
9	2.2184	2.3434	2.2914	.7011	.8065
10	.8124	.9061	.7755	2.2253	2.562
11	.9145	.9602	.8272	2.7938	3.4841
12	.9907	.9297	.8855	3.3699	3.3508
13	.9998	.9374	.8535	2.9007	3.0931
14	.9945	.9488	.8124	2.5888	3.152
15	.9061	.9646	.7621	3.034	3.1131
16	.8993	.8995	.7655	.4199	3.0308
17	.8993	.8894	.7926		
18	.9774	.1905	.2058	.2477	.2058
19	.2058	.2286	.2229	.3429	.2401
20	.2401	.2667	.2229	.3048	.2401
21	.884	.2667	.2058	.2667	.2401
22	.2229	.2286	.1715	.2286	
23	.2229	.2286	.1715	.2286	
24	.2286	.2058	1.7814	.5182	.7202
Max	2.2184	2.3434	2.2914	3.3699	3.4841
Min	.2058	.1905	.1715	.2286	.2058
Avg	1.0679	1.0256	1.1042	1.0889	1.4202

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024035 / Khandala

Feeder No / Name : 201 / Talegaon Bz SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.362	.3584	1.9204	1.8122
2	.381	.3584	.3584	1.89	1.7185
3	.362	.3395	.3395	1.89	1.6766
4	.381	.3429	.3395	1.8595	1.7185
5	.4001	.3395	.3584	1.8595	1.6872
6	.4191	.3206	.3772	1.829	1.6872
7	.4001	.2829	.415	1.7071	1.6872
8	.3239	.2858	.3395	1.7375	1.8122
9	.381	.2829	.3206	1.6918	1.829
10	2.5724	2.1862	1.9841	.2263	.2452
11	2.5263	2.4939	2.4291	.2096	.2641
12	2.3805	2.4905	2.4291	.2075	
13	2.2672	2.4453	2.3594	.1509	.1886
14	2.2348	2.1538	2.3644	.1886	.1886
15	2.2834	2.332	2.2996	.1715	.1905
16	2.4249	2.4291	2.2834		.1886
17	2.2186	2.3644	2.3644	.2075	.2263
18	.3206	.3961	.3772	.3772	.3961
19	.4715	.4527	.415	.4338	.4527
20	.4527	.4527	.415	.415	.4338
21	.4527	.4527	.3961	.3961	.415
22	.4527	.3961	.3772	.3584	.3584
23	.3772	.3772	.3584	.3018	
24	.4001	.3584	.3584	1.9509	1.8747
Max	2.5724	2.4939	2.4291	1.9509	1.8747
Min	.3206	.2829	.3206	.1509	.1886
Avg	1.0527	1.0290	1.0174	.9556	.9569

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024035 / Khandala

Feeder No / Name : 202 / industrial feeder

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1905	.1509	.1698	.132
2	.1715	.1715	.132	.1698	.132
3	.1715	.1715	.1698	.1698	.132
4	.1715	.1905	.1886	.1698	.132
5	.1715	.1905	.132	.1698	.132
6	.1524	.1905	.1698	.1698	.132
7	.1334	.1905	.0943	.1132	.132
8	.1334	.1905	.0754	.1132	.132
9	.1334	.2286	.0754	.132	.132
10	.1334	.1715	.0566	.1334	.132
11	.1334	.2096	.2096	.1334	.1334
12		.1905	.2286	.1334	.2096
13	.1905	.1715	.2096	.1334	.1905
14	.2096	.2096	.1334	.1334	.1905
15	.2096	.1334	.1334	.1334	.1715
16	.1715	.1334	.1334		.1715
17	.2096	.1905	.132	.132	.1886
18	.1886	.1698	.132	.132	.1509
19	.1524	.1886	.1886	.132	.1886
20	.1334	.1886	.2075	.132	
21	.1715	.0943	.1698	.132	.1886
22	.1905	.0754	.1698	.132	.1886
23	.1905	.1509	.1698	.132	
24	.1905	.1905	.0754	.1698	.132
Max	.2096	.2286	.2286	.1698	.2096
Min	.1334	.0754	.0566	.1132	.132
Avg	.1689	.1743	.1474	.1422	.1557

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024035 / Khandala

Feeder No / Name : 203 / Borwa

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001	.3961	2.1403	.3395	.3206
2	2.2365	2.3594	2.0881	.3395	.3206
3	2.1845	2.3266	2.0873	.3206	.3206
4	2.0919	2.2672	2.0622	.3206	.3395
5	2.0233	2.2939	1.8747	.3206	.3395
6	1.9547	2.2611	1.8435	.3395	.3772
7	2.0458	2.2348	1.8122	.3961	.3961
8	2.0631	2.1136	1.9841	.3772	.3772
9	1.989	2.2611	1.9997	.2829	.3206
10		.2263	.2641	2.3158	2.8669
11	.2667	.1886	.2477	2.2672	2.332
12	.2075	.1698	.2452	2.34	2.3158
13	.2263	.1886	.2075	2.251	2.3266
14	.2096	.1886	.2075	2.2611	2.2672
15	.2075	.2263	.1886	2.251	2.17
16	.2286	.2075	.1886		2.2672
17	.2452	.2263	.2075	2.3903	2.1956
18	.3961	.415	.3772	.3772	.3584
19	.4715	.4527	.4338	.4527	.4527
20	.4715	.4527	.4338	.4338	.4338
21	.4763	.4527	.415	.3961	.4338
22	.4527	.415	.3772	.3772	.3961
23	.415	.415	.3584	.3395	
24	.4191	.3961	2.1559	.3395	.3206
Max	2.2365	2.3594	2.1559	2.3903	2.8669
Min	.2075	.1698	.1886	.2829	.3206
Avg	.9427	.9640	1.0083	.9491	1.0543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024043 / 33 KV UKALI BZ S/STN

Feeder No / Name : 201 / 11 KV KODRI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2143	.2073		
2	.2042	.2143	.1915		
3	.2042	.2143	.1915		
4	.1943	.2143	.1915		
5	.1943	.2143	.1858		
6	.2042	.2143	.1981		
7	.2164	.2286	.2073		
8	.2705	.2429	.2105		
9	.2934	.2429	.285		
10				.2202	.2572
11				.2881	.3429
12				.2715	.3246
13				.2858	.3201
14				.3041	.2892
15				.3286	.2881
16				.3286	.2721
17				.3286	.3064
24		.1858	.2073		
Max	.2934	.2429	.285	.3286	.3429
Min	.1943	.1858	.1858	.2202	.2572
Avg	.2227	.2186	.2076	.2944	.3001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024043 / 33 KV UKALI BZ S/STN

Feeder No / Name : 202 / Wadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5144	.4763	1.4998	1.4232
2	.5335	.5144	.4191	1.4217	1.4232
3	.5335	.5144	.4191	1.2803	1.4232
4	.4954	.4954	.4191	1.2191	1.4232
5	.4954	.4954	.381	1.1443	1.4232
6	.4763	.4954	.381	1.1296	1.4232
7	.4763	.4763	.381	1.2809	1.4232
8	.381	.362	.362	1.4842	1.4864
9	.3429	.3239	.3429	1.3466	1.4864
10	1.6129	1.6309	1.6049		
11	1.8185	1.7747	1.7833	.3429	
12	1.7078	1.8519	1.6644	.2477	1.4864
13	1.7236	1.6918	1.6255	.2477	
14	1.6446	1.4712	1.3969	.2667	
15	1.7078	1.6975	1.6255	.2477	
16	1.7394	1.6556	1.599	.2477	
17	1.7553	1.7593	1.599	.2477	
18	.5906	.5525	.6668	.5716	
19	.7049	.7049	.743	.6859	
20	.6859	.6859	.6478	.6668	
21	.6478	.6478	.5525	.6097	
22	.5906	.5716	.4763	.4954	
23	.5525	.5144	.4572	.4191	
24	.5335	.5144	.4954	1.5844	1.4864
Max	1.8185	1.8519	1.7833	1.5844	1.4864
Min	.3429	.3239	.3429	.2477	1.4232
Avg	.9277	.9132	.8550	.8125	1.4462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024043 / 33 KV UKALI BZ S/STN

Feeder No / Name : 203 / Warud SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.9122	.9145	.1905	.1905
2	.9122	.9122	.9031	.1905	.1905
3	.9122	.9122	.873	.1715	.1905
4	.9804	.9122	.884	.1715	.1715
5	1.0311	.9122	.9145	.1715	.1715
6	1.0467	.9282	1.0669	.2477	.1715
7	1.0623	1.0279	1.0974	.1905	.1905
8	1.186	1.1717	1.1589	.1715	.1715
9	1.2963	1.2029	1.1431	.1905	.1715
10	.0572	.1143	.1334	1.0822	1.0402
11	.0572	.0953	.0762	1.2492	1.2643
12	.0762	.0572	.0572	1.2803	
13	.0572	.0572	.0572	1.3123	
14	.0572	.0762	.0572	1.0722	
15		.0762	.0381	1.2963	
16		.0762	.0572	1.2803	
17	.0953	.0572	.0572	1.2803	
18	.3048	.2667	.3048	.2286	
19	.381	.362	.3429	.362	
20	.381	.381	.3048	.3429	
21	.362	.381	.2667	.3429	
22	.3429	.2858	.2286	.2858	
23	.3048	.2286	.2096	.1905	
24	.3048	.9282	.884	.1905	.1905
Max	1.2963	1.2029	1.1589	1.3123	1.2643
Min	.0572	.0572	.0381	.1715	.1715
Avg	.5233	.5140	.5013	.5622	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024049 / 33/11 KV BELKHED S/S

Feeder No / Name : 201 / 11 KV BELKHED

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4715	1.6478	1.9313	.3772	.3772
2	1.9662	1.8821	1.9313	.3772	.3772
3	1.9334	1.7859	1.949		.3772
4	1.8842	1.7695	1.949	.3772	.3772
5	1.8023	1.7204	1.9313	.3772	.3961
6	1.704	1.6712	1.9313	.3961	.4527
7	1.7368	1.6549	1.9136	.4527	.4904
8	1.9334	2.0645	1.949	.3961	.3961
9	1.9826	4.1618	1.9845	.4715	.3961
10	2.268	.9054	.7922	1.9136	2.0553
11	.3961	.7544	.4338	2.4097	2.3211
12	.4904	.3584	.3961	2.1956	2.4274
13	.415	.3772	.3772	2.1464	2.392
14	.3961	.3772	.3584	1.9826	2.1971
15	.3584	.3395	.3395	2.1464	2.5337
16	.3961	.3772	.3206	2.13	2.073
17	.3584	.3772	.3206	2.1956	
18	.5093	.547	.547	.4915	1.8842
19	.6036	.5658	.5847	.5079	.5407
20	.6224	.5847	.6036	.4915	.4973
21	.6224	.6036	.547	.4588	.4807
22	.6224	.7922	.4904	.3932	.4475
23		.4904	.4527	.3605	.4475
24	.4904	1.8861	1.949	.3772	.3277
Max	2.268	4.1618	1.9845	2.4097	2.5337
Min	.3584	.3395	.3206	.3605	.3277
Avg	1.0419	1.1539	1.0826	1.0185	1.0550

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024049 / 33/11 KV BELKHED S/S

Feeder No / Name : 202 / 11 kV Warud (Bihade). SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2075	.1886	1.949	1.9662
2	.2075	.2075	.1886	1.949	1.9662
3	.2075	.1886	.1886	1.9313	1.9498
4	.1886	.1886	.1698	1.9136	1.9498
5	.2075	.1886	.1698	1.7718	1.9334
6	.2452	.1886	.1698	1.5947	1.8023
7	.1886	.1886	.1698	1.6301	1.7204
8	.1698	.132	.1698	1.7718	1.8351
9	.1132	.1132	.1509	1.6478	1.8023
10	2.268	2.3743	2.4806	.1886	.0754
11	2.4097	2.4983	2.5869	.0943	.0943
12	2.64	2.6046	2.6578	.1063	.0754
13	2.5869	2.5337	2.4451	.0886	.0943
14	2.4709	2.2325	2.2325	.0905	.0754
15	2.4274	2.6046	2.1794	.0709	.0943
16	2.4983	2.3388	2.4274	.0709	.0943
17	2.3743	2.2634	1.9313	.0709	.0886
18	.1886	.2075	.1698	.1595	.2126
19	.2829	.2263	.2829	.1772	.2658
20	.2829	.2641	.2452	.2075	.2481
21	.2829	.2641	.2452	.2075	.2481
22	.2452	.2263	.2452	.1886	.2126
23	.2263	.2075	.2263	.1772	.2126
24	.2263	.1886	.1886	1.9845	1.9662
Max	2.64	2.6046	2.6578	1.9845	1.9662
Min	.1132	.1132	.1509	.0709	.0754
Avg	.9652	.9432	.9212	.8351	.8743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024050 / 33/11 kV SAUNDALA

Feeder No / Name : 201 / 11 kV SAUNDALA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2191	.2263	.5658	.429
2	.2075	.221	.2263	.6413	.3749
3	.2075	.2229	.2263	.6413	.4265
4	.2075	.2229	.2263	.6413	.4025
5	.2075	.2153	.2075	.6602	.4161
6	.2263	.2134	.1886	.6602	.4374
7	.1886	.202	.2075	.6602	.4399
8	.132	.1238	.1509	.6413	.4572
9	.132	.1429	.132	.4904	.422
10	.4161	.3873	.6036	.08	.1143
11	.7209	.613	.8488	.08	.1132
12	.6827		.8865	.0991	.132
13	.5908	.6249	.8488	.1181	.132
14	.5543	.5624	.7545	.1143	.132
15	.5458	.6706	.7733	.1162	
16	.5668	.5944	.7922	.0972	
17	.5868		.8299	.1257	.132
18	.2229		.1886		.2452
19	.282	.5117	.2263	.2534	2.6783
20	.282	.2641	.2641	.2591	.2641
21	.2705	.2641	.2452	.2477	
22	.2572	.2452	.2263	.2096	
23	.2343	.2452	.1886	.1924	
24	.2452	.2134	.2263	.5281	.3873
Max	.7209	.6706	.8865	.6602	2.6783
Min	.132	.1238	.132	.08	.1132
Avg	.3414	.3324	.4039	.3532	.4282

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024050 / 33/11 kV SAUNDALA

Feeder No / Name : 202 / 11kV PIMPARKHED

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.5658	.5454
2				.6036	.5314
3				.6413	.5101
4	1.6766			.6413	.535
5				.6602	.5268
6				.6602	.5335
7				.6602	.5525
8				.6602	.5424
9				.5068	.6103
10		.48	.7167		
11	.6718	.5487	.811		
12	.6462	.6249	.8488		
13	.598	.6097	.8488		
14	.5792	.5357	.8676		
15	.669	.6321	.8865		
16	.5668	.6321	.9054		
17	.5915	.5944	.811		
24				.4904	.5271
Max	1.6766	.6321	.9054	.6602	.6103
Min	.5668	.48	.7167	.4904	.5101
Avg	.7499	.5822	.8370	.609	.5415

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024050 / 33/11 kV SAUNDALA

Feeder No / Name : 203 / 11kV KARLA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1372		.0943	.1105
2	1.2342	1.8328	1.0364	.0943	.1086
3	1.2193	1.3946		.0754	.1029
4	1.2029	1.4074	.132	.0754	.101
5	1.2003	1.3169	.132	.0943	.101
6	1.001	1.3205	.132	.0943	.1086
7	1.1138	1.4147	1.0059	.0943	.1372
8	1.1873	1.4161	1.5203	.0943	.0972
9	1.1736	1.4523	1.9427	.0762	.0838
10	.0754	.0648	.0754	1.3289	1.6049
11	.0754	.0762	.0566	1.5956	1.768
12	.0629	.0943	.0566	1.7723	1.761
13	.0895	.0943	.0754	1.6688	1.7833
14	.0724	.0754	.0754	1.5377	1.6004
15	.0857	.0754	.0754	1.7115	1.8122
16	.0857	.0754	.0754	1.699	1.7008
17	.0972	.0754	.0754	1.6376	1.7223
18	.1562	.1509	.0943	.1124	.132
19	.1905	.1698	.1132	.1524	.1886
20	.1715	.1886	.1698	.1924	.1886
21	.16	.1509	.1509	.1715	
22	.1524	.3395	.132	.1524	
23	.1353	.132	.1132	.1296	
24	.1509	.1372	1.0059	.0943	.1219
Max	1.2342	1.8328	1.9427	1.7723	1.8122
Min	.0629	.0648	.0566	.0754	.0838
Avg	.4677	.5664	.3748	.6146	.7302

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024054 / 33/11 kV YEDLAPUR S/S

Feeder No / Name : 201 / 11kV YEDLAPUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1067		1.286	.1219	.0937
2	1.2193	1.3904	1.2003	.1372	.0937
3	1.2498	1.3279	1.2574	.1372	.0937
4	1.2651	1.3123	1.2742	.1372	.0937
5	1.2193	1.2498	1.2431	.1219	.0937
6	1.2803	1.2342	1.1717	.1219	.0937
7	1.2498	1.2029	1.1431	.1219	.125
8	1.2193	1.2498	1.1431	.0914	.0937
9	1.2651	1.2498	1.2003	.0914	.0937
10	.0762	.0625	.0429	1.0364	1.4373
11	.0469	.0625	.0762		1.4289
12	.0625	.0625	.061	1.4784	1.4861
13	.0625	.0572	.061	1.5779	1.4575
14	.0625	.0572	.061	1.4529	1.5432
15	.0781	.0572	.061	1.4685	1.7147
16	.0781	.0572	.061		1.4432
17	.0625	.0572	.0762	1.5466	1.3146
18	.1562	.1143	.1372	.125	.1286
19	.1406	.1143	.1524	.1562	.1429
20	.1562	.1143	.1677	.1562	.1429
21	.1562	.1143	.1372	.1406	.1429
22	.1406	.1	.1219	.125	.1286
23	.125	.0857	.1219	.1094	
24	.1067	.125	1.3003	.1067	.0937
Max	1.2803	1.3904	1.3003	1.5779	1.7147
Min	.0469	.0572	.0429	.0914	.0937
Avg	.4827	.4982	.5649	.4801	.5861

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024054 / 33/11 kV YEDLAPUR S/S

Feeder No / Name : 202 / 11kV Khairkhed SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1677		.1406	1.768	1.5623
2	.1677	.1562	.1406	1.89	1.5623
3	.1677	.1562	.125	1.9204	1.531
4	.1677	.1562			1.531
5	.1677	.1562	.125	1.829	1.4529
6	.1524	.1875	.1562	1.768	1.5154
7	.1524	.1875	.1875	1.7528	1.5935
8	.1372	.1562	.125	1.6766	1.6248
9	.1219	.1094	.0949	1.6766	1.7341
10	1.8595	1.9372	1.7341	.0914	.0937
11	1.9685	2.1247	1.9052		.0781
12	2.0466	2.1403	1.89	.0762	.0791
13	1.9841	2.0309	1.8595	.0781	.0457
14	1.9841	1.9841	1.829	.0625	.0469
15	2.0309	1.9136	1.829	.0781	.0633
16	2.0309	1.8122	1.89		.0633
17	1.9685	1.8185	1.7528	.0625	.0625
18	.1562	.1677	.1981	.1562	.1875
19	.2343	.1783	.1981	.1875	.2031
20	.2343	.1882	.1829	.2187	.2031
21		.2031	.1677	.1875	.1875
22	.2031	.1898	.1677	.1718	.1739
23	.1718	.1562	.1524	.1562	
24	.1524	.1718	.1562	.3963	1.5779
Max	2.0466	2.1403	1.9052	1.9204	1.7341
Min	.1219	.1094	.0949	.0625	.0457
Avg	.8012	.7949	.7395	.7716	.7466