

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344019 / 33 KV KARMARGAON SUB STATION

Feeder No / Name : 201 / 11 KV KAMARGAON AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.567				.4801	
2		.567				.4001	
3		.5609				.4001	
4		.5258				.3841	
5		.5258				.3361	
6		.4973				.3077	
7		.6415	.8124			.4801	
8		.964	1.0467			.9282	
9		1.3203	1.1561			1.3927	
10		1.2689	1.1336			1.1822	
11		1.3441	1.0526			1.2793	
12		1.2955	.8907			1.2793	
13	.7783	1.0936	.9878			1.1012	
14	.6415	.9374	.9393			.9717	
15	1.0692						1.749
16	1.1946			1.4998			1.5223
17				1.1248			1.2308
18							.7773
19				.8124			.7125
20				.7499			.6478
21				.6562			.6154
22				.6249			.583
23	.8145				.7773		
24		.7602				.5921	
Max	1.1946	1.3441	1.1561	1.4998	.7773	1.3927	1.749
Min	.6415	.4973	.8124	.6249	.7773	.3077	.583
Avg	.8996	.8580	1.0024	.9113	.7773	.7677	.9798

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344019 / 33 KV KARMARGAON SUB STATION

Feeder No / Name : 202 / 11 KV KAMARGAON GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5721	.6001	.6135	.6135	.6154	.5611	.8573
2	.5721	.5731	.6135	.5959	.6154	.5611	.8097
3	.5548	.567	.5959	.5959	.5792	.5611	.8573
4	.5548	.5847	.631	.6135	.5792	.5792	.8573
5	.6241	.6024	.7011	.8413	.724	.6154	.8573
6	.8322	.7716	.8413	1.1218	1.0498	.7059	.8573
7	.9709	1.1744	1.1043	1.0166	1.1946	1.0498	1.0802
8	1.1789	1.2094	1.0867	1.0166	1.2489	1.1584	1.0802
9	1.1443	1.1517	1.1919	1.1043	1.1584	1.086	1.046
10	1.1096	1.0166	1.1043	1.1043	1.0136	.9945	1.046
11	.9882	.8745	.9465	.8589	.8413	.8745	.7545
12	.8589	.8322	.7362		.8063	.8745	.6859
13	.7545	.7011	.631	.6661	.5784	.6173	.6859
14	.5895	.631	.5784	.5258	.5548	.6173	
15	.6024	.6516	.6661	.5609	.5721	.6344	
16	.6344	.5434	.7011	.6661	.5548	.6344	
17	.8149	.7888	.7362	.7712	.7202	.7545	.9259
18	1.2003	1.1393	1.1393		1.1744	1.1831	1.1488
19	1.2346	1.1218	1.1568	1.3496	1.2048	1.1831	1.2003
20	1.1641	1.0166	1.0517	1.1919	1.0631	.7888	1.0117
21	.9134	.8063	.7655	.9816	.8589	.7888	.8573
22	.7602	.7011	.7362	.7712	.7011	.6687	.7202
23	.7011	.5959	.6135	.6661	.5959	.5658	.6173
24	.6241	.6661	.6135	.6135	.6516	.5552	.5487
Max	1.2346	1.2094	1.1919	1.3496	1.2489	1.1831	1.2003
Min	.5548	.5434	.5784	.5258	.5548	.5552	.5487
Avg	.8314	.8050	.8148	.8294	.8190	.7755	.8812

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344019 / 33 KV KARMARGAON SUB STATION

Feeder No / Name : 203 / 11 KV KHERDA BHULODA

FEEDER SEPERATION/PURE AG

FEEDER Feeder KV- 11 /
OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5182	.144	.7773	.7186	.543	.2105	.6802
2	.5182	.144	.7773	.7186	.4687	.2105	.6802
3	.5506	.144	.7773	.703	.4687	.2105	.6802
4	.5506	.144	.7773	.703	.4999	.2105	.6802
5	.5506	.144	.7935	.703	.4999	.2105	.6802
6	.583	.192	.7935	.6562	.5312	.2105	.6802
7	.6478	.2241		.7499	.7186	.3239	.8583
8	.9069	.3163		.7499	.8124	.2753	.8583
9	.1943	.4062		.9374	1.0311	.3563	1.0202
10	1.0364	.4268	.2429	.9374	.9998	.4049	1.0202
11	1.0364	.463	.2267		.8124		1.0202
12		.4687	.2812	.4374	.8642		.8097
13		.2187	.2343	.8749	.8322	.1457	.8097
14		.2343	.25	.8124	.5601	.2429	.6478
15		.9374	.9842	.125	.8642	.7773	.3239
16		.9686	.8436	.1875	.9717	.7773	.2915
17	.9282	.8124	.8436	.3749	.9717	.7773	.2915
18	.8907	.8097	.7499	.1562	.7682	.6316	.3239
19	.8642	.7449	.703	.1875	.7449	.6316	.3239
20	.8421	.7125	.703	.1875	.7287	.6316	.3239
21	.8097	.6802	.6562	.2187	.7125	.6316	.3239
22	.7842	.6802	.6249	.25	.6964	.583	.3239
23	.2401	.8583	.7499	.4687	.213	.7935	.5182
24	.5182	.2241	.7773	.6562	.4999	.2105	.7449
Max	1.0364	.9686	.9842	.9374	1.0311	.7935	1.0202
Min	.1943	.144	.2267	.125	.213	.1457	.2915
Avg	.6827	.4624	.6460	.5441	.7006	.4299	.6215

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344019 / 33 KV KARMARGAON SUB STATION

Feeder No / Name : 204 / 11 KV KAMARGAON INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0143	.0141		.0137	.0137	.0143	.0143
2	.0143	.0141		.0137	.0137	.0143	.0143
3	.0143	.0141		.0137	.0137	.0143	.0143
4	.0143	.0141		.0137	.0137	.0143	.0143
5	.0143	.0141		.0137	.0137	.0143	.0143
6	.0143	.0141		.0137	.0137	.0143	.0143
7	.0143	.0141		.0137	.0137	.0143	.0143
8	.0143	.0141		.0137	.0137	.0143	.0143
9	.0143	.0143		.0137	.0137	.0143	.0143
10	.0143	.0141	.0412	.0137	.0137	.0143	.0143
11	.0143	.0143	.0274	.0137	.0137	.0143	.0143
12	.0143	.0143	.0274	.0137	.0139	.0143	.0143
13	.0143	.0137	.0274	.0137	.0143	.0143	.0143
14	.0145	.0137	.0274	.0137	.0141	.0143	.0143
15	.0145		.0274	.0137	.0143	.0143	.0143
16	.0143		.0137	.0137	.0143	.0143	.0143
17	.0137		.0137	.0137	.0141	.0143	.0143
18	.0143		.0137	.0137	.0143	.0143	.0143
19	.0141	.0137	.0137	.0137	.0145	.0143	.0143
20	.0143		.0137	.0137	.0143	.0143	.0143
21	.0141		.0137	.0137	.0143	.0143	.0143
22	.0143		.0137	.0137	.0141	.0143	.0143
23	.0143		.0137	.0137	.0141	.0143	.0143
24	.0143	.0143		.0137	.0137	.0143	.0143
Max	.0145	.0143	.0412	.0137	.0145	.0143	.0143
Min	.0137	.0137	.0137	.0137	.0137	.0143	.0143
Avg	.0143	.0141	.0206	.0137	.0140	.0143	.0143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344019 / 33 KV KARMARGAON SUB STATION

Feeder No / Name : 205 / 11 KV KHERDA GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.104	.12	.1086	.0905	.1086	.0895	.1214
2	.0867	.12	.1086	.0905	.1086	.0895	.1214
3	.0867	.12	.1086	.0724	.1086	.0895	.1214
4	.104	.12	.1086	.0724	.1086	.0895	.1214
5	.104	.12	.1267	.1086	.1086	.1075	.1214
6	.104	.1214	.1448	.1448	.1448	.1227	.1214
7	.1448	.1372	.1629	.1448	.1448	.1578	.1214
8	.1448	.1372	.1267	.1448	.1448	.1387	.1214
9	.1448	.156	.1267	.1448	.1267	.1214	.1734
10	.1448	.12	.1448	.1448	.1267	.1214	.1734
11	.1267	.1029	.1267	.1267	.1086	.104	.1734
12	.1029		.1267	.1086	.0905	.0867	.1214
13	.0857	.0857	.1086	.0905	.0905	.0867	.104
14	.0876	.0857	.1086	.0905	.0876	.104	.0693
15	.0857	.0857	.1086	.1086	.0876	.0867	.0867
16		.0857	.0905	.1086	.0857	.0867	.0867
17	.1052	.12	.1086	.1086	.1254	.104	.104
18	.1907	.1991	.181	.181	.1629	.104	.1734
19	.1696	.181	.181	.181	.1791	.1734	.1734
20	.1543	.181	.181	.181	.1595	.1214	.156
21	.1372	.1448	.1448	.1448	.1402	.1214	.1214
22	.1387	.1267	.1267	.1267	.1214	.1214	.104
23	.1372	.1086	.1086	.1267	.1086		.104
24	.104	.12	.1086	.1086	.1086		.104
Max	.1907	.1991	.181	.181	.1791	.1734	.1734
Min	.0857	.0857	.0905	.0724	.0857	.0867	.0693
Avg	.1215	.1260	.1282	.1229	.1203	.1104	.1250

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344020 / 33 KV UMBARDA BAZAR SUB

STAT

Feeder No / Name : 201 / 11 KV SOMTHANA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3201	.3601	.3125				.2743
2	.3201	.3601	.3125				.2743
3	.3201	.3601	.2968				.1524
4	.3521	.3601	.3125				.2743
5	.3841	.3688	.2812				.3048
6	.4111	.503	.3437				.3353
7	.5851	.6226	.5468				.4321
8	.7655	.7373	.6718				.5864
9	.7655	.7209	.7186				.6173
10				.5312	.5624	.5197	
11				.6958	.6562	.6081	
12				.6958	.6554	.6562	
13				.6642	.6081	.5851	
14				.6241	.5468	.5468	
15				.6081	.5624	.5468	
16				.6081	.5761	.578	
17				.5121	.6249	.578	
24	.3201	.3601	.3125				.2286
Max	.7655	.7373	.7186	.6958	.6562	.6562	.6173
Min	.3201	.3601	.2812	.5121	.5468	.5197	.1524
Avg	.4544	.4753	.4109	.6174	.5990	.5773	.3480

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344020 / 33 KV UMBARDA BAZAR SUB

STAT

Feeder No / Name : 202 / 11 KV UMBARDA AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.9061	.9804	.9496	
2				.9061	.9488	.9389	
3				.9282	.9488	.9389	
4				.9282	.9172	.9389	
5				.9282	.8905	.9389	
6				.9602	.8592	.9503	
7				1.0082	1.0467	.9602	
8				1.2483	1.2967	1.2654	
9				1.3283	1.3748	1.2342	
10	1.4413	1.4586	1.3117				1.142
11		1.4842	1.4217				1.2498
12	1.5565	1.4373	1.4529				1.2963
13	1.4883	1.406	1.3279				1.3123
14	1.4403	1.3435	1.3123				1.2811
15	1.5074	1.3123	1.3927				1.2811
16	1.5402	1.3279	1.3283				1.3443
17	1.3435	1.2967	1.3123				1.2803
24				.8749	.9804	.9496	
Max	1.5565	1.4842	1.4529	1.3283	1.3748	1.2654	1.3443
Min	1.3435	1.2967	1.3117	.8749	.8592	.9389	1.142
Avg	1.4739	1.3833	1.3575	1.0017	1.0244	1.0065	1.2734

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344020 / 33 KV UMBARDA BAZAR SUB

STAT

Feeder No / Name : 203 / 11 KV UMBARDA GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3547	.3734	.3547	.3547	.3734	.3361	.3174
2	.3547	.3734	.3547	.3547	.3734	.3361	.3174
3	.3547	.3734	.3547	.3547	.3734	.3361	.3174
4	.3921	.3734	.3547	.3547	.4108	.3361	.3174
5	.4294	.4481	.3547	.3547	.4481	.4854	.4108
6	.4854	.5601	.4668	.4854	.5041	.5975	.4294
7	.6722	.6722	.7095	.6535	.7095	.7095	.6722
8	.7095	.7095	.7095	.6908	.6722	.6722	.6908
9	.6535	.6348	.6908	.5601	.6722	.6535	.5975
10	.5975	.5975	.5228	.5601	.5975	.5601	.5975
11	.5041	.4294	.4294	.5601	.4481	.4294	.4668
12	.3547	.4108	.4294	.3921	.3734	.4108	.3921
13	.3734	.3361	.3734	.3734	.3361	.3547	.3734
14	.2801	.3547	.3361	.3361	.2987	.2801	.2987
15	.2801	.3174	.2987	.3547	.2987	.2987	.2801
16	.2987	.3361	.3361	.3547	.2987	.2987	.2801
17	.3734	.4481	.4294	.4294	.4108	.3734	.2987
18	.6161	.6722	.6535	.6722	.7095	.6722	.7095
19	.7468	.7842	.7842	.7095	.7282	.7655	.8402
20	.7095	.6535	.7095	.6535	.6722	.6722	.6722
21	.5975	.5788	.5788	.5415	.5975	.5415	.5415
22	.5228	.4668	.4481	.4481	.4854	.4294	.4481
23	.3921	.3921	.3734	.3921	.3547	.3734	.3547
24	.3734	.3734	.3547	.3547	.3921	.3361	.3361
Max	.7468	.7842	.7842	.7095	.7282	.7655	.8402
Min	.2801	.3174	.2987	.3361	.2987	.2801	.2801
Avg	.4761	.4862	.4753	.4706	.4808	.4691	.4567

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344021 / 33 KV DHANAJ SUB STATION

Feeder No / Name : 201 / 11 KV DHANAJ AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3219	.3448	.3174
2				.3219	.3463	.3174
3				.3219	.3463	.3174
4				.3571	.3448	.3174
5				.3571	.3448	.3174
6				.4761	.3862	.3333
7				.5952	.6409	.4285
8				.8962	.9035	.4444
9				.9522	.8333	.6507
10	.6759	.6734	.7618			.6666
11	.833	.8243	.7776			.7459
12	.7764	.856	.7935			.6983
13	.6546	.745	.8411			.7142
14	.7143	.7292	.8094			.5555
15	.7143	.7142	.7142			.6666
16	.6521	.7618	.7618			.7459
17	.6677	.5568	.73			.6824
24				.3809	.3448	.3333
Max	.833	.856	.8411	.9522	.9035	.7459
Min	.6521	.5568	.7142	.3219	.3448	.3174
Avg	.7110	.7326	.7737	.4981	.4836	.5140

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344021 / 33 KV DHANAJ SUB STATION

Feeder No / Name : 202 / 11 KV RAHATI AG FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7167	.6516	.7167	.6516		
2	.7167	.5376	.6842	.5864		
3	.6842	.5213	.6516	.4887		
4	.6842	.4887	.6516	.4887		
5	.6516	.4887	.6516	.4887		
6	.6842	.5701	.4887	.5538		
7	1.0751	.9774	.8633	.7819		
8	1.1566	1.3032	1.1566	.7819		
9	1.0751	1.0262	.7819	.6516		
10				.619	1.124	1.0099
11				.7167	1.0425	1.0751
12				.7016	.8145	.6027
13				.6027	.6842	.6027
14				7.3442	.6516	.619
15				.5109	.6516	.619
16				.6386	.6516	.619
17				.6546	.7167	
24	.6842	.7167	.7167	.505		
Max	1.1566	1.3032	1.1566	7.3442	1.124	1.0751
Min	.6516	.4887	.4887	.4887	.6516	.6027
Avg	.8129	.7282	.7363	.9870	.7921	.7353

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344021 / 33 KV DHANAJ SUB STATION

Feeder No / Name : 203 / 11 KV GAS PLANT EXP.

NON SHEDDABLE EXPRESS HV FEEDERS

FEEDER Feeder KV- 11 /

(CONTINUOUS PROCESS)(NO STAGGERING)

OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0761	.057	.0761	.057	.057	.0747	.057
2	.0761	.057	.0761	.057	.0561	.0747	.057
3	.0761	.057	.0761	.057	.0561	.0748	.057
4	.0761	.057	.0761	.057	.0561	.0748	.057
5	.0761	.057	.0761	.057	.0561	.0754	.1141
6	.1141	.1331	.2282	.1141	.1121	.132	.1901
7	.2662	.2092	.2662	.1521	.2259	.2832	.0951
8	.3423	.3423	.3042	.1331	.1869	.2812	.1141
9	.3423	.2662	.2282	.1331	.299	.2783	.0761
10	.3613	.2964	.3042	.1331	.2029	.2606	.0951
11	.2282	.2662	.3232	.112	.2772	.242	
12	.2274	.2852	.3042	.0997	.2743	.2234	
13	.2087	.2662	.2472	.0665	.238	.1507	.0761
14	.2274	.2662	.1141	.0991	.1497	.2073	.0761
15	.1749	.2662	.0761	.099	.1468	.1886	.1141
16	.217	.2662	.057	.1031	.1662	.0943	.0761
17	.217	.2852	.3232	.1448		.3012	
18	.2266	.3423	.3232	.1411	.2231	.3015	.2852
19	.2282	.3423	.3803	.1402	.2452	.3015	.2472
20	.2472	.2662	.3423	.1355	.2064	.3015	.2472
21	.2282	.2662	.3042	.1452	.2056	.2282	.2282
22	.1711	.1711	.0761	.0645	.0674	.1901	.0951
23	.0761	.0761	.0761	.0496	.0674	.0761	.0761
24	.0761	.0761	.0761	.0761	.057	.074	.057
Max	.3613	.3423	.3803	.1521	.299	.3015	.2852
Min	.0761	.057	.057	.0496	.0561	.074	.057
Avg	.1900	.2072	.1973	.1011	.1579	.1871	.1186

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344021 / 33 KV DHANAJ SUB STATION

Feeder No / Name : 204 / 11 KV DHANAJ GAONTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5607	.4108	.4133	.4889	.4338	.4338	.3602
2	.5607	.4108	.4133	.4944	.415	.4338	.3602
3	.5613	.4108	.4133	.4904	.415	.4338	.3602
4	.5613	.4108	.4133	.4904	.415	.4338	.3602
5	.5613	.4108	.4321	.5281	.415	.4338	.3602
6	.6174	.5046	.526	.5847	.5093	.5093	.6445
7	.7484	.7102	.6387	.7371	.6224	.6602	.6824
8	.679	.7102	.6011	.7095	.6722	.6036	.6635
9	.6584	.6715	.6763	.7066	.5658	.5975	.6824
10	.6421	.6161	.5636	.7073	.5658	.4207	.5578
11	.5504	.5228	.5641	.5956	.5175	.4233	.4835
12	.4587	.449	.5228	.4854	.3658	.3681	.4281
13	.3486	.3742	.4673	.439	.3292	.3135	.3685
14	.332	.3742	.4486	.3738	.3109	.332	.2954
15	.332	.3555	.4859	.3738	.3109	.332	.3323
16	.4673	.3742	.4486	.4486	.3292	.332	.3511
17	.5233	.5051	.4673	.3506	.4024	.4242	.444
18	.785	.7138	.7476	.7207	.6722	.7377	.7453
19	.8224	.6951	.8962	.7468	.8215	.7369	.8078
20	.7289	.6387	.8061	.6722	.7468	.6639	.7297
21	.6413	.6387	.6381	.6535	.6224	.6224	.6922
22	.5664	.5636	.5453	.5415	.4715	.5292	.6548
23	.4154	.4133	.4701	.4481	.4338	.3981	.4486
24	.4112	.4108	.4133	.4329	.4294	.4338	.3602
Max	.8224	.7138	.8962	.7468	.8215	.7377	.8078
Min	.332	.3555	.4133	.3506	.3109	.3135	.2954
Avg	.5639	.5123	.5422	.5508	.4914	.4836	.5072

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344021 / 33 KV DHANAJ SUB STATION

Feeder No / Name : 205 / 11 KV RAHATHI GAONTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1869	.168	.1488	.1494	.1509	.1494	.1302
2	.1869	.168	.1488	.1494	.1509	.1494	.1302
3	.1869	.168	.1488	.1494	.1509	.1494	.1302
4	.1867	.168	.1488	.1491	.1509	.1494	.1302
5	.1846	.1662	.1488	.1679	.1509	.1494	.1302
6	.2029	.2213	.1302	.1863	.1869		.1488
7	.1844	.2029	.2045	.1863	.2054	.2033	.2045
8	.2587		.1859	.2603	.2029	.2033	.1859
9	.2211	.2029	.2045	.2048	.2033	.1848	.2045
10	.2766	.2213	.1488	.205	.2029	.2033	.2045
11	.2582	.2213	.1488	.2012	.2033	.2033	.1859
12	.1844	.1844	.1303	.166	.1463	.2218	
13	.2029	.1291	.166	.1844	.128	.1848	.1646
14	.1612	.1107	.166	.1107	.128	.1294	.1463
15	.1291	.1107	.166	.1107	.128	.1294	.1658
16		.1475	.1844	.1107	.128	.1294	.1291
17	.1254	.1662	.1478	.1448	.128	.1665	
18	.2582	.2603	.2035	.197	.2195	.222	.2772
19	.2582	.2417	.2598	.2165	.2772	.222	.2582
20	.2398	.2045	.2603	.2345	.2427	.222	.2766
21	.2029	.1859	.2236	.2029	.2054	.2231	.2213
22	.1844	.1674	.1679	.166	.168	.2045	.2213
23	.166	.1674	.168	.1475	.1494	.1302	.1663
24	.1682	.168	.1488	.1682	.1475	.1494	.1302
Max	.2766	.2603	.2603	.2603	.2772	.2231	.2772
Min	.1254	.1107	.1302	.1107	.128	.1294	.1291
Avg	.2006	.1805	.1733	.1737	.1731	.1774	.1792

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344022 / 33 KV POHA SUB STATION

Feeder No / Name : 201 / 11 KV POHA INDUSTRIAL

SHEDDABLE FEEDER HAVING WEEKLY

FEEDER Feeder KV- 11 /

STAGGERING (MIDC, EQUIVALENT)

OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.2641	.2641	.1132	.3206	.2641	.2801
2	.132	.2641	.2641	.1132	.2641	.2641	.2801
3	.132	.2641	.2452	.132	.2641	.2641	.2801
4	.1509	.2641	.2452	.132	.2641	.2452	.2801
5	.1509	.2641	.2452	.132	.2641	.2452	.2801
6	.1509	.2641	.2241	.1494	.1698	.2641	.2614
7	.1494	.2263	.2054	.2218	.2641	.1509	.2241
8	.1494	.2452	.2614	.2427	.2075	.2427	.1494
9	.2241	.415	.2801	.2427	.3395	.2427	.2427
10	.2263	.415	.2614	.2614	.2829	.2987	.2263
11	.2241	.2801	.2614	.2641	.2987	.3206	.1867
12	.2241	.2427	.2587	.2641	.3361	.2543	.2054
13	.2075	.2241	.2218	.2641	.2987	.1867	.2241
14	.2641	.2054	.1867	.2263	.2801	.2641	.2241
15	.2641	.2054	.168	.2263	.2614	.2829	.168
16	.2829	.2427	.168	.2263	.1867	.3018	.1886
17	.2987	.2614	.168	.2641	.2987	.3395	.1867
18	.2614	.2614	.1867	.1698	.2427	.2641	.2054
19	.2241	.2801	.2263	.1886	.2829	.3206	.2263
20	.2641	.2987	.1307	.2263	.3018	.3206	.2075
21	.2641	.3018	.1307	.2641	.3018	.2829	.2263
22	.2641	.3018	.1478	.2641	.3018	.2829	.2452
23	.2641	.2829	.1307	.2641	.3018	.2829	.2452
24	.132	.2641	.2641	.112	.2641	.2829	.2829
Max	.2987	.415	.2801	.2641	.3395	.3395	.2829
Min	.132	.2054	.1307	.112	.1698	.1509	.1494
Avg	.2099	.2724	.2144	.2069	.2749	.2695	.2303

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344022 / 33 KV POHA SUB STATION

Feeder No / Name : 202 / 11 KV POHA GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2601	.3086	.3189	.2835	.2743	.3189	.3429
2	.2601	.3086	.3189	.2835	.2743	.3155	.3429
3	.2601	.3086	.3189	.2835	.2743	.3155	.3429
4	.2835	.3086	.3189	.2774	.2743	.3155	.3429
5	.2835	.3086	.3189	.3189	.2743	.3155	.3429
6	.3506	.3429	.3544	.3506	.2915	.3544	.3429
7	.5201	.4801	.4557	.4961	.4801	.4908	.3429
8	.4908	.4458	.4908	.4784	.4801	.4908	.4801
9	.4252	.4115	.4908	.4607	.4458	.4557	.4458
10	.3121	.3772	.4252	.4207	.3429	.3814	.3086
11	.2427	.3155	.2601	.3086	.2481	.2743	.2947
12	.208	.2804	.2835	.2058	.2126	.2641	.2126
13	.2614	.2401	.2658	.1715	.2103	.2286	.2126
14	.1715	.2401	.2126	.1715	.2126	.2058	.2126
15	.1372	.2454	.2126	.1886	.2126	.1715	.208
16	.1715	.2804	.2835	.2058	.2126	.2401	.2481
17	.2915	.2804	.3121	.2743	.3189	.2743	.2774
18	.4115	.4908	.5028	.4801	.4908	.4115	.5316
19	.4458	.4961	.4681	.5144	.5316	.4801	.5201
20	.4458	.4607	.4508	.3429	.4607	.4458	.4161
21	.4115	.3898	.3856	.2915	.3898	.3772	.3467
22	.3429	.3544	.3467	.2915	.3189	.3429	.3189
23	.2743	.3189	.3121	.2743	.3189	.3429	.2658
24	.2804	.2743	.3189	.298	.2743	.3189	.3429
Max	.5201	.4961	.5028	.5144	.5316	.4908	.5316
Min	.1372	.2401	.2126	.1715	.2103	.1715	.208
Avg	.3143	.3445	.3511	.3197	.3260	.3388	.3351

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344022 / 33 KV POHA SUB STATION

Feeder No / Name : 203 / 11 KV SOOTGIRNI EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 FEEDER Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2858	.3018	.2477	.3239	.2641	.3048
2	.2286	.2858	.2829	.2477	.3048	.2641	.3048
3	.2286	.2858	.2829	.2477	.3048	.2452	.3048
4	.2477	.2858	.2641	.2477	.3048	.2641	.3048
5	.2477	.2858	.2829	.2667	.3048	.2641	.2858
6	.2477	.2667	.3018	.2667	.2858	.2452	.2667
7	.2477	.2667	.2801	.2667	.2858	.2614	.3048
8	.2286	.2858	.2987	.2667	.3048	.2987	.3239
9	.2667	.2858	.3174	.3048	.3048	.2427	.3239
10	.2667	.2858	.2614	.2477	.2858	.2801	.3239
11	.2477	.2801	.2858	.2667	.3018	.3048	.2858
12	.2667	.2987	.3048	.2858	.2987	.2858	.3048
13	.2667	.2801	.2667	.2858	.2987	.2477	.3048
14	.2858	.2987	.2096	.2858	.2987	.2858	.3048
15	.3048	.2987	.1905	.3048	.2987	.3048	.3048
16	.3048	.2987	.2096	.3239	.2987	.3239	.3048
17	.2858	.2987	.2667	.3048	.2801	.3239	.3048
18	.3239	.3174	.2858	.3429	.3174	.3239	.3048
19	.3048	.3174	.2477	.3429	.3206	.3239	.2858
20	.3048	.3174	.2667	.3429	.3018	.3239	.2667
21	.3048	.2829	.2477	.3239	.3206	.3239	.2667
22	.3048	.2829	.2477	.3239	.3018	.3239	.2667
23	.2858	.2641	.2477	.3239	.3018	.3239	.2667
24	.2477	.2858	.3018	.2477	.3239	.2641	.3239
Max	.3239	.3174	.3174	.3429	.3239	.3239	.3239
Min	.2286	.2641	.1905	.2477	.2801	.2427	.2667
Avg	.2699	.2892	.2689	.2882	.3031	.2881	.2977

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344022 / 33 KV POHA SUB STATION

Feeder No / Name : 204 / 11 KV KINHI GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0724	.0678	.0686	.0732	.0724	.0686	.0905
2	.0732	.0678	.0686	.0732	.0724	.0686	.0724
3	.0732	.0678	.0686	.0732	.0724	.0686	.0724
4	.0724	.0678	.0686	.0732	.0724	.0686	.0724
5	.0732	.0678	.0686	.0732	.0724	.0686	.0724
6	.0724	.0848	.0848	.1097	.0724	.0857	.0724
7	.0914	.1357	.1017	.1267	.0905	.1017	.0724
8	.1097	.1017	.1017	.1267	.0905	.1017	.0905
9	.1097	.1029	.1017	.1267	.0724	.1017	.0724
10	.1086	.0848	.1029	.1097	.0905	.0678	.0724
11	.1097	.0848	.0905	.0905	.0848	.0543	.0543
12	.0905	.0678	.0732	.0724	.0678	.0543	.0549
13	.0724	.0678	.0732	.0724	.0678	.0543	.0549
14		.0678	.0549	.0543	.0509	.0543	.0549
15	.0724	.0678	.0549	.0543	.0678	.0543	.0549
16	.0905	.0848	.0549	.0724	.0678	.0543	.0724
17	.1086	.0848	.0732	.0724	.0678	.0543	.0724
18	.1267	.1187	.1267	.1086	.1187	.1267	.128
19	.1448	.1372	.1463	.1267	.12	.1448	.1463
20	.1267	.1372	.1267	.1086	.1029	.1267	.1097
21	.1086	.12	.1086	.0905	.1029	.1086	.1097
22	.0905	.1029	.1086	.0905	.0857	.0905	.0732
23	.0724	.0857	.0914	.0724	.0857	.0905	.0732
24	.0724	.0724	.0857	.0732	.0724	.0857	.0905
Max	.1448	.1372	.1463	.1267	.12	.1448	.1463
Min	.0724	.0678	.0549	.0543	.0509	.0543	.0543
Avg	.0931	.0895	.0877	.0885	.0809	.0815	.0796

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344022 / 33 KV POHA SUB STATION

Feeder No / Name : 205 / 11 KV WAI AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3637	.3437	.3086	.3906
2			.3593	.3749	.3086	.3906
3			.3125	.3749	.3395	.3906
4			.3437	.3749	.3395	.3906
5			.3637	.3749	.3086	.3906
6			.3906	.3906	.3704	.3953
7			.6019	.5937	.5093	.4428
8			.6562	.828	.6481	.578
9			.679	.7499	.679	.6249
10	.7968	.6478				.703
11	.9877	.9172				.8065
12	.9962	.953				
13	.9393	.9414				.8124
14	.8078	.9105				.8124
15	.7621	.8749				.8223
16	.7164	.8796				.7907
17	.6249	.6327				
24			.3479	.3125	.2778	.3906
Max	.9962	.953	.679	.828	.679	.8223
Min	.6249	.6327	.3125	.3125	.2778	.3906
Avg	.8289	.8446	.4419	.4718	.4089	.5707

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344022 / 33 KV POHA SUB STATION

Feeder No / Name : 206 / 11 KV WAI GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.3772		.3018	.2641	.3018	.3048
2	.2829	.3772		.3018	.2641	.3018	.3048
3	.2829	.3772		.2829	.2641	.3018	.3048
4	.3018	.3772		.2829	.2641	.3018	.3048
5	.3018	.3772		.3018	.3018	.3395	.3429
6	.3395	.3772		.3395	.3772	.415	.381
7	.5658	.4527		.5658	.5658	.6036	.5335
8	.4904	.5281		.5281	.5281	.5716	.5716
9	.4527	.4527		.4527	.3772	.4527	.4527
10	.3734	.415		.4527	.3772	.415	.3429
11	.3018		.3018	.3772		.2286	.3018
12	.2263		.3018	.1715		.2286	.2263
13	.2263		.2829	.1886		.1905	.2263
14	.2263		.2263	.2263			.1886
15	.2263		.2263	.2263		.2263	.1886
16	.2641		.2641	.2263		.2263	.2263
17	.3018		.3018	.2263		.2263	.3018
18	.5228		.5281	.3772		.4527	.5658
19	.5975		.5281	.6036		.4904	.5658
20	.5601		.4527	.5281		.4572	.4527
21	.5281		.415	.3018		.3429	.3772
22	.4527		.3395	.3018		.3429	.3395
23	.3734		.3206	.3018		.3048	.3018
24	.3018	.3772		.3018	.2641	.3018	.3048
Max	.5975	.5281	.5281	.6036	.5658	.6036	.5716
Min	.2263	.3772	.2263	.1715	.2641	.1905	.1886
Avg	.3660	.4081	.3453	.3404	.3498	.3489	.3505

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344022 / 33 KV POHA SUB STATION

Feeder No / Name : 207 / 11 KV KINHI AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8124	.823	.703			
2	.8223	.823	.703			
3		.823	.703			
4		.823	.703			
5		.823	.6562			
6		.823	.679			
7		1.0974	.7499			
8		1.3717	.7499			
9		1.3717	.703			
10	.9374		1.0311	1.0623	1.2517	.9482
11			1.1385	1.4922	1.25	1.3226
12			1.2498	1.6108	1.2191	1.3226
13	1.2003		1.174	1.4413	1.2346	1.3226
14	1.3056		1.1888	1.406	1.1873	1.286
15			1.2041	1.3226	1.0987	1.2517
16			1.1069	1.2378	1.0385	1.2174
17			1.0753	1.1869	.9783	1.2003
24	.7499	.823	.6718			
Max	1.3056	1.3717	1.2498	1.6108	1.2517	1.3226
Min	.7499	.823	.6562	1.0623	.9783	.9482
Avg	.9713	.9602	.8995	1.3450	1.1573	1.2339

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344026 / 33 KV DHANORA SUB STATION

Feeder No / Name : 202 / 11 KV DHANORA AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	1.2378	1.2209	1.4413	.1715	.1696	.1526
2	.2058	1.2209	1.2209		.1715	.1526	.1526
3	.2058	1.2209	1.2209		.1715	.1526	.1526
4	.1715	1.3735	1.3735		.1715	.1526	.1696
5	.2058	1.4922	1.4243		.2058	.1696	.2035
6	.2401	1.56	1.4243		.2401	.2035	.2035
7	.2401	1.6617	1.4752		.2401	.2543	.2204
8		1.8313	1.7635		.2743	.3052	.2883
9	.3772	1.6617	1.8652		.2743	.3052	.3222
10		.2543	.2713		1.4922	1.3904	1.6108
11		.2883	.3052		1.6617	1.5939	1.7295
12	.2204	.2543	.3086	1.7147	1.7295	1.7126	1.7295
13	.2374	.2035	.2572	1.6804	1.6956	1.6278	1.56
14	.2035	.2035	.2572	1.7833	1.6956	1.4752	1.3904
15	.1696	.2035	.2743	1.7147	1.6617	1.4922	1.4582
16	.1865	.2713	.2572	1.6461	1.6108	1.5091	1.4582
17	.3052	.2374	.2743	1.5432	1.4582	1.4243	1.3904
18	.2713	.2713	.2743	.2743	.3052	.2883	.2374
19	.3222	.2713	.2572	.2743	.2883	.2543	.2713
20	.2713	.2204	.2572	.2401	.2543	.2713	.2713
21	.2374	.1865	.2572	.2401	.2713	.2035	.2374
22	.2035	.1696	.2572	.2058	.2035	.2035	.2035
23	.1865	.1357	.2572	.2058	.1865	.1526	.1696
24	.1715	1.2378	1.0513	1.4413	.1715	.1696	.1526
Max	.3772	1.8313	1.8652	1.7833	1.7295	1.7126	1.7295
Min	.1696	.1357	.2572	.2058	.1715	.1526	.1526
Avg	.2288	.7362	.7419	1.0290	.6919	.6514	.6556

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344026 / 33 KV DHANORA SUB STATION

Feeder No / Name : 203 / 11 KV LONI FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0688			.9259	.9145	.9145
2	1.0526			.9259	.9145	1.0174
3	1.0526			.9259	.9145	.9145
4	1.0688			.9259	.9145	.945
5	1.004			.9259	.9602	.9755
6	1.004			.9259	.9907	.9755
7	1.2955			1.142	1.0059	.9907
8				1.5123	1.4632	1.1584
9	1.4251			1.5741	1.3717	1.2803
10		1.1873	1.2498			
11		1.2498	1.2498			
12	1.3599	1.2498	1.3765			
13	1.1385	1.1888	1.4575			
14	1.3283	1.2498	1.2955			
15	1.3283	1.2498	1.2955			
16	1.2967	1.3565	1.3603			
17	1.2651	1.3413	1.1984			
24	.9717			.9259	.884	.884
Max	1.4251	1.3565	1.4575	1.5741	1.4632	1.2803
Min	.9717	1.1873	1.1984	.9259	.884	.884
Avg	1.1773	1.2591	1.3104	1.0710	1.0334	1.0056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344026 / 33 KV DHANORA SUB STATION

Feeder No / Name : 401 / 33 KV DHANAJ FEEDER

SHEDDABLE RURAL

Feeder KV- 33 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.262	1.2757		1.1043	1.0631	1.0631
2		1.262	1.2757		1.1568	1.0631	1.0631
3		1.3672	1.2757		1.1568	1.0631	1.0631
4		1.5775	1.382		1.1568	1.0631	1.0631
5			1.6478		1.2094	1.4883	1.1163
6		1.9982	1.9136		1.1568	1.5947	1.1694
7		2.1365	2.1262		1.7353	1.7541	1.1694
8		2.2085	1.1694		2.1033	2.1794	1.4883
9		2.2262	1.9667		2.1033	2.1262	1.6478
10		1.9004	1.9667		2.0805	2.1262	1.4883
11		1.8604	1.9136		2.0285	2.073	.823
12	1.749	1.8073	1.6095	1.4403	2.0062	1.4883	
13	1.5432	1.5947	1.6095	1.2346	1.5432	1.382	1.4723
14	1.4918	1.382	1.6095	1.1831	1.2346	1.3289	.5784
15	1.3889	1.4883	1.5592	1.1317	1.2346	1.2757	1.1963
16	1.4918	1.6478	1.5089	1.286	1.2346	1.2757	1.2483
17	1.5432	1.4883	1.5089	1.4403	1.3375	1.4883	1.2483
18	1.17	1.2757	1.2071	1.0288	1.0288	1.2226	1.262
19	1.3146	1.3289	1.2071	.4161	1.2346	1.3289	1.262
20	1.2489	1.2757	1.2071	.9882	1.1317	1.2226	1.262
21	.9991	1.1163	.5533	.9362	.9774	.7442	1.0517
22	.7362	.8505	.6036	.7802	.5658	.7442	.5258
23	.631	.6379	.6036	.6762	.6173	.6379	.631
24	1.5592	1.262	1.1694		1.1568	1.0099	1.0631
Max	1.749	2.2262	2.1262	1.4403	2.1033	2.1794	1.6478
Min	.631	.6379	.5533	.4161	.5658	.6379	.5258
Avg	1.2975	1.5198	1.4112	1.0451	1.3456	1.3643	1.1285

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344027 / 33 KV KAKADSHIVANI SUB

STATION

Feeder No / Name : 201 / 11 KV SHAHA AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.0494	1.0494	1.0669	
2			1.5741	1.0802	1.0669	
3			1.7284	1.142	1.0669	
4			1.6667	1.1728	1.1888	
5			1.7593	1.2963	1.2803	
6			1.7593	1.358	1.3717	
7			1.6358	1.5123	1.4632	
8			1.6667	1.6975	1.4632	
9			1.4506	1.6049	1.4937	
10	1.5242	1.4632				.7926
11	1.6766	1.7071				1.7071
12	1.7985	1.6975				1.6766
13	1.6461	1.6358				1.6766
14	1.6156	1.5432				1.6461
15	1.5546	1.4815				1.6461
16	1.4022	1.4815				1.5851
17	1.3717	1.5123				1.4327
24			1.0185	.9877	.9755	
Max	1.7985	1.7071	1.7593	1.6975	1.4937	1.7071
Min	1.3717	1.4632	1.0185	.9877	.9755	.7926
Avg	1.5737	1.5653	1.5309	1.2901	1.2437	1.5204

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344027 / 33 KV KAKADSHIVANI SUB

STATION

Feeder No / Name : 202 / 11 KV KAKADSHIVANI AG

FEEDER SEPERATION/PURE AG

FEEDER Feeder KV- 11 /
OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.3567	.3765				.2606
2	.3668	.4161	.3765				.2606
3	.3814	.4458	.4054				.2494
4	.3765	.3567	.4054				.2494
5	.4401	.4161					.2896
6	.4778	.5053					.3374
7	.5135	.4755	.4054				.3668
8	.5792	.6241	.4344				.362
9	.5281	.5944	.4344				.4401
10			.5213	.4344	.4344	.3765	
11			.5502	.4923	.4344	.4344	
12			.5213	.4923	.4923	.4633	
13			.4923	.4923	.4633	.4633	
14			.5213	.5213		.4841	
15			.4923	.4633		.4694	
16			.4923	.5213	.4923	.4778	
17			.4054	.4344	.4923	.4923	
24	.362	.3269	.3765				.2641
Max	.5792	.6241	.5502	.5213	.4923	.4923	.4401
Min	.362	.3269	.3765	.4344	.4344	.3765	.2494
Avg	.4387	.4518	.4507	.4815	.4682	.4576	.308

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344027 / 33 KV KAKADSHIVANI SUB

STATION

Feeder No / Name : 203 / 11 KV KAJLESHWAR FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.8962	.7468	.8215	.8962	.7842	.7282
2	.7392	.8589	.7468	.7842	.8962	.7842	.7023
3	.7762	.7468	.7468	.8589	1.0082	.8589	.7023
4	.7842	.8215	.8215	.7842	1.0456	.8589	.7282
5	.8316	.9335	.9335	.7468	1.0829	.9335	.7392
6	.924	.9709	1.0829	.8962	1.0829	1.0456	.8402
7	1.0269	1.0829	1.0829	.7842	1.1576	1.1203	.924
8	1.1203	1.1203	1.0082	1.1576	1.1203	1.1203	1.0456
9	1.1827	1.0829	.9709	1.1949	1.1203	1.1576	1.0642
10	1.1203	.8962	1.0082		1.1203	1.0829	.961
11	1.0829	.8962	1.1203	1.0456	.9709	.9877	.8589
12	1.0082	.9335	1.0829	.9709	1.0082	.8402	.8589
13	1.0456	1.0456	.9335	1.0082	.9335	.7392	.8589
14	1.0829	1.0456	.9709	.8962	.8962	.7842	.8215
15	.7468	1.0829	.9709	.9335	.9335	.7947	.8589
16	.9335	1.0829	.9335	.9335	1.0082	.8215	.8962
17	1.0456	1.1203	1.1203	1.0082	1.0456	.9335	.9709
18	1.2696	1.1576	1.0829	1.1576	1.0829	1.1203	1.0456
19	1.1576	1.134	1.0829	1.0829	1.0829	1.0534	1.0456
20	1.0829	1.0082	1.0456	.9335	1.0829	.961	.9335
21	.9709	.9335	.9335	.8962	1.0082	.8402	.8215
22	.8589	.8215	.8589	.8215	.9335	.8316	.7842
23	.8215	.7468	.8215	.7842	.8589	.7468	.7468
24	.7468	.7842	.7468	.7842	.7842	.7842	.7282
Max	1.2696	1.1576	1.1203	1.1949	1.1576	1.1576	1.0642
Min	.7392	.7468	.7468	.7468	.7842	.7392	.7023
Avg	.9627	.9668	.9522	.9254	1.0067	.9160	.8610

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344027 / 33 KV KAKADSHIVANI SUB

STATION

Feeder No / Name : 401 / 33 KV KAMARGAON FEEDER

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0923	1.7142	1.5432	1.567	1.7984	1.4563	1.3889
2	1.0923	2.035	1.5432	1.588	1.9929	1.4563	1.286
3	1.0288	2.0508	1.749	1.9771	1.546	1.5604	1.3003
4		2.2295	2.0062	2.0718	2.1086	1.7164	1.3523
5	1.4243	2.0876	2.0576	1.7984	1.9456	1.7684	1.3889
6	1.5432	2.3768	2.1091	1.9771	1.7247	1.8204	1.5261
7	1.8004	2.4188	2.1091	1.9561	2.0876	2.2365	1.8004
8	2.0805	2.6187	1.9547	2.1139	2.1139	2.4966	2.0805
9	1.3375	2.9762	1.3889	2.2401	2.1559	2.8086	2.1365
10	2.3663	2.7659	2.7778	2.3032	1.9877	2.8607	2.2634
11	2.0348	2.808	2.5206	1.0306	1.7563	2.7046	2.0576
12	1.0185	2.6292	2.1914	1.5354	1.6644	2.4143	1.893
13	1.8724	2.4188	2.0062	1.7142	1.5604	2.1605	1.893
14	.7407	2.2611	.7819	2.0297	1.1963	.9156	1.1043
15	1.8827	1.8404	1.1214	2.6502	1.6644	1.1831	1.9982
16		1.8404	1.6722	2.7449	1.6644	1.5089	2.0087
17	2.0087	1.8724	2.0297	2.4399	1.7684	1.6278	2.5345
18	2.3873	1.9456	2.1139	.4259	1.9244	2.0576	2.9973
19	2.3768	2.0508	2.0192	2.4714	2.0285	1.9244	2.4188
20	2.1349	1.6461	1.914	2.2085	1.9765	1.6461	1.8404
21	1.9035	1.5432	1.5775	2.0508	1.9244	1.4918	1.5775
22	1.8615	1.5432	1.6196	1.0096	1.8204	1.3226	1.3672
23	1.8089	1.4918	1.4934	1.1779	1.5604	1.4403	1.262
24	1.1831	1.6196	1.3375	1.3987	1.1253	1.4043	1.3735
Max	2.3873	2.9762	2.7778	2.7449	2.1559	2.8607	2.9973
Min	.7407	1.4918	.7819	.4259	1.1253	.9156	1.1043
Avg	1.6809	2.1160	1.8182	1.8534	1.7957	1.8326	1.7854

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344029 / 33 KV KARANJA LAD SUB

STATION

Feeder No / Name : 201 / 11 KV MANORA ROAD FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1433	.0934	.112	.1097	.0747	.0934	.0747
2	.1494	.0934	.112	.1097	.0747	.0934	.0747
3	.1448	.0934	.1109	.1086	.0747	.0924	.0754
4	.1612	.0934	.1109	.1494	.0747	.0924	.0754
5	.168	.0934	.112	.1494	.0747	.1109	.0754
6	.1663	.168	.1307	.2241	.112	.1494	.1132
7	.1829	.2241	.1478	.2614	.168	.1886	.2054
8	.2743	.2195	.2402	.2743	.2195	.3511	.2743
9	.2772	.2172	.2587		.2561		.2378
10	.2402	.2012	.2402	.2195	.2012		.2012
11	.2218	.181	.1848	.1478	.2218		.1829
12	.2033	.181	.1478	.1463	.1663		.1829
13	.1646	.1448	.1463	.1478	.1478		.128
14	.1829	.1086	.1097	.1478	.1294		.1097
15	.1478	.1086	.1097	.1307	.1294		.1097
16		.1086	.1097	.1494	.1478		.0914
17	.1463	.2012	.1463	.1463	.1478		
18	.2012	.1848	.2012	.1646	.1848		
19	.168	.1848	.1829	.168	.1848		
20	.168	.1848	.1829	.168	.1848		
21	.1494	.1663	.1829	.168	.1646		
22	.112	.1478	.1463	.1494	.1478		
23	.112	.1109	.1463	.112	.1294		
24	.1463	.0934	.1109	.1086	.0934	.0924	.0747
Max	.2772	.2241	.2587	.2743	.2561	.3511	.2743
Min	.112	.0934	.1097	.1086	.0747	.0924	.0747
Avg	.1753	.1502	.1535	.1592	.1463	.1404	.1345

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344029 / 33 KV KARANJA LAD SUB

STATION

Feeder No / Name : 202 / 11 KV OLD TOWN FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.905	.8962	.8962	.8779	.8215	.8501	.8215
2	.9511	.8962	.8865	.9145	.8215	.8316	.8215
3	.9877	.8962	.8686	.9412	.8215	.823	.8215
4	.9877	.8962	.8589	.9877	.8215	.8316	.8215
5	1.2437	1.0082	.9979	1.0498	.8962	1.0719	.9709
6	1.3535	1.307	1.1949	1.1888	1.251	1.1949	1.1016
7	1.4815	1.419	1.4003	1.3169	1.4377	1.5123	1.4563
8	1.6651	1.5364	1.5684	1.6057	1.5729	1.6461	1.5729
9		1.4842	1.5524	1.5524	1.5912		1.5729
10	1.7002	1.5203	1.4969	1.5708	1.4998		1.5729
11	1.6263	1.4998		1.3121	1.4083		1.3717
12	1.5154	1.1523	1.3676	1.1643	1.2197		1.3352
13	1.4415	1.0974	1.2803	1.0719	1.1088		1.2437
14	1.0974	1.0498	1.2308	1.0082	1.0349		1.0425
15	1.0974	.9694	1.0059	.9896	1.0719		.9511
16		1.0059	1.0608	.9896	1.0829		1.0791
17	1.39	1.4415	1.1222	1.1888	1.2382		
18	1.7193	1.7556	1.3352	1.4998	1.5893		
19	1.643	1.5893	1.6827	1.531	1.5524		
20	1.4937	1.4415	1.5364	1.4003	1.386		
21	1.3443	1.2382	1.3443	1.2883	1.2567		
22	1.1763	1.1458	1.2308	1.1576	1.1706		
23	1.0642	1.0534	1.0059	1.0082	.9896		
24	.9145	.9335	.924	.8779	.8962	.8871	.8962
Max	1.7193	1.7556	1.6827	1.6057	1.5912	1.6461	1.5729
Min	.905	.8962	.8589	.8779	.8215	.823	.8215
Avg	1.3090	1.2181	1.2108	1.1872	1.1892	1.0721	1.1443

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344029 / 33 KV KARANJA LAD SUB

STATION

Feeder No / Name : 203 / 11 KV GAWALIPURA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8779	.8402	.8402	.8596	.8029	.7842	.7655
2	.9593	.8402	.8131	.8328	.8029	.7842	.7655
3	.9896	.8402	.8131	.8869	.8029		.7655
4	1.0791	.8402	.8871	1.0608	.8029	.8029	.7655
5	1.2136	.9709	.9979	1.1765	.8029	.9054	.9335
6	1.3169	1.3443	1.1458	1.2894	1.1949	1.094	1.1389
7	1.6095	1.531	1.4415	1.3937	1.531	1.4901	1.531
8	1.7924	1.6057	1.6448	1.4815	1.6289	1.5844	1.643
9	1.8111	1.6461	1.6632	1.5524	1.5708		1.5684
10	1.829	1.7013	1.5708	1.4632	1.5524		1.643
11	1.7372	1.6278	1.5708	1.3306	1.4045		1.531
12	1.6448	1.1706	1.3491	1.2567	1.3121		1.3256
13	1.5339	1.134	1.2803	1.1827	1.2197		1.1949
14	.961	1.0608	1.1765	1.0903	1.0164		1.0082
15	.8686	.9511	1.0498	1.0269	.961		.9896
16		.9774	1.134	1.0719	1.0349		1.1203
17	1.251	1.2567	1.2489	1.1706	1.2382		
18	1.4998	1.5154	1.4266	1.4937	1.5497		
19	1.4937	1.4784	1.4998	1.4377	1.4969		
20	1.363	1.3443	1.5364	1.3256	1.2567		
21	1.1763	1.226	1.267	1.2136	1.1458		
22	1.0829	1.0791	1.1222	1.0829	1.0608		
23	.9522	.9328	.9774	.9709	.8871		
24	.8688	.8775	.8686	.8413	.8589	.8215	
Max	1.829	1.7013	1.6632	1.5524	1.6289	1.5844	1.643
Min	.8686	.8402	.8131	.8328	.8029	.7842	.7655
Avg	1.3005	1.1997	1.2219	1.1872	1.1640	1.0333	1.1681

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344029 / 33 KV KARANJA LAD SUB

STATION

Feeder No / Name : 204 / 11 KV KARANJA INDUSTRIAL

SHEDDABLE FEEDER HAVING WEEKLY

FEEDER Feeder KV- 11 / OUTGOING

STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5068	.4854	.5544	.4344	.4294	.3734	.4481
2	.5121	.4854	.5544	.439	.4294	.3734	.4481
3	.4755	.4854	.5544	.4706	.4294	.3734	.4481
4	.4755	.4854	.5544		.4108	.3734	.4481
5	.5121	.4854	.5544	.4344	.4294	.3734	.4108
6	.5121	.5975	.4805	.439	.4854	.3772	.3734
7	.4108	.5041	.4066	.3982	.5415	.4338	.4108
8	.4887	.4854	.3881	.4024	.4108	.415	.5041
9	.7023	.5068	.5544	.5729	.4066		.5415
10	.6838	.5792	.5544	.5121	.5729		.6161
11	.5729	.5611	.462	.6468	.6283		.5788
12	.6283	.695	.4435	.6099	.6099		.5788
13	.6653	.6401	.5068	.5853	.6099		.5975
14	.7023	.6219	.5487	.4805	.6283		.6348
15	.5729	.6154	.5853	.6535	.6468		.5601
16		.6219	.6219	.6036	.6283		.5487
17	.7282	.7023	.6401	.6348	.5175		
18	.6348	.6283	.6722	.5788	.5041		
19	.5228	.5853	.5853	.5228	.5228		
20		.5175	.5487	.4854	.5175		
21		.4805	.5121	.4294	.462		
22	.3921	.5175	.4755	.4668	.462		
23	.4108	.5175	.4481	.4294	.4251		
24	.5228	.4481	.5601	.4163	.4294	.3772	.4668
Max	.7282	.7023	.6722	.6535	.6468	.4338	.6348
Min	.3921	.4481	.3881	.3982	.4066	.3734	.3734
Avg	.5539	.5522	.5319	.5064	.5057	.3856	.5067

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344029 / 33 KV KARANJA LAD SUB

STATION

Feeder No / Name : 205 / 11 KV BYPASS TOWN FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.3361	.3326	.3361	.3361	.3142	.3361
2	.4024	.3361	.3326	.3258	.3361	.3142	.3361
3	.4024	.3361	.3326	.3258	.3361	.3174	.3361
4	.439	.3361	.3326	.3982	.3361	.3361	.3361
5	.439	.3361	.3696	.439	.3361	.3696	.3361
6	.4938	.5041	.4435	.4961	.4481	.4481	.4108
7	.6219	.5601	.5359	.6219	.5601	.5228	.5788
8	.6767	.6401	.6099	.6584	.6767	.6722	.695
9	.6283	.5792	.6283	.6219	.7133		.6767
10	.5729	.543	.5914	.6283	.5914		.6036
11	.462	.5068	.5175	.5544	.499		.4755
12	.5175	.4755	.499	.5175	.4805		.4525
13	.4294	.4344	.4755	.4207	.4251		.4207
14	.4207	.3801	.3982	.4294	.4066		.4024
15	.4066	.3801	.3658	.4251	.4251		.3658
16		.3982	.4115	.462	.3658		.3658
17	.4938	.5175	.4706	.4207	.4251		
18	.6036	.6099	.5853	.5853	.6036		
19	.6161	.6413	.5973	.5975	.6099		
20	.5975	.5914	.543	.5601	.5729		
21	.5601	.5175	.5068	.5601	.5175		
22	.4854	.4572	.4805	.4668	.4805		
23	.4108	.4066	.4108	.3921	.3881		
24	.3658	.3734	.3658	.3734	.3547	.3395	.3361
Max	.6767	.6413	.6283	.6584	.7133	.6722	.695
Min	.3658	.3361	.3326	.3258	.3361	.3142	.3361
Avg	.4962	.4665	.4640	.4840	.4677	.4038	.4391

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344029 / 33 KV KARANJA LAD SUB

STATION

Feeder No / Name : 206 / 11 KV BHILKHEDA INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY

FEE Feeder KV- 11 / OUTGOING

STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1267	.1448	.1478	.1463	.1448	.1494	.2534
2	.128	.1448	.1494	.1463	.1448	.1509	.2534
3	.128	.1448	.1494	.1448	.1448	.1509	.2534
4	.1463	.1448	.1478	.1463	.1448	.1494	.181
5	.1463	.1448	.1494	.1463	.1448	.1494	.181
6	.1463	.1448	.1478	.1448	.1448	.1494	.1448
7	.1463	.1402	.1478	.1478	.1448	.1494	.181
8	.1629	.1448	.1478	.1478	.1448	.1494	.2172
9	.2772	.1463	.1478	.1463	.1478		.2353
10	.2957	.181	.1663	.1463	.1294		.2353
11	.3395	.2172	.1663	.1478	.1478		.2172
12	.2772	.2926	.1663	.1478	.1478		.2353
13	.2743	.2715	.1629	.1478	.1494		.2353
14	.3109	.2715	.1448	.1494	.2772		.2353
15	.2926	.2743	.1463	.1494	.2772		.2353
16		.2896	.181	.1294	.2801		.2534
17	.2715	.2957	.2195	.1267	.1494		
18	.2715	.2957	.2172	.2172	.2772		
19	.2715	.1663	.2561	.1448	.2587		
20	.1448	.1663	.1448	.1448	.1478		
21	.1448	.1478	.1646	.1448	.1478		
22	.1448	.1307	.1463	.1433	.1478		
23	.1448	.1307	.1448	.1448	.1478		
24	.128	.1448	.1478	.1463	.1448	.1509	.2534
Max	.3395	.2957	.2561	.2172	.2801	.1509	.2534
Min	.1267	.1307	.1448	.1267	.1294	.1494	.1448
Avg	.2052	.1907	.1629	.1478	.1724	.1499	.2236

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344029 / 33 KV KARANJA LAD SUB

STATION

Feeder No / Name : 401 / 33 KV POHA FEEDER

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7558	1.5935	2.1068	1.4266	1.2186	1.5844	1.2186
2	1.7924	1.5935	2.1068	1.4118	1.2186	1.5844	1.2186
3	1.6461	1.5935	2.1068	1.6461	1.2186	1.5844	1.4998
4	1.6804	1.5935	2.1068	1.6289	1.2186	1.5844	1.5935
5	1.5043	1.5935	2.1948	1.6461	1.2186	1.4998	1.3123
6	1.2197	1.781	2.2177	1.3969	1.5935	1.5546	1.3603
7	1.4118	2.2497	2.3285	1.4118	1.781	2.1285	1.6872
8		2.5263	2.5503	1.4118	2.1559	2.4897	1.8747
9	1.7741	2.7435	2.3285	2.4394	2.2634		1.9685
10	3.3265	2.4691	2.6612	2.6612	2.1948		1.6872
11	2.4394	2.1948	2.5503	2.9424	2.572		1.5935
12	2.2177	2.3045	2.7721	2.8829	2.6612		1.5935
13	3.3265	2.3045	2.7435	2.5503	2.6612		1.6518
14	3.4374	2.1948	2.7435	2.5766	2.4394		1.406
15	3.3265	2.1948	2.7721	2.3525	1.9204		1.5546
16		2.1719	2.2805	2.4394	2.0405		1.6872
17	1.5935	2.1068	2.1719	2.1125	2.5503		
18	1.2963	1.5684	1.5364	1.2186	1.5203		
19	1.3603	1.5684	1.6289	1.3123	1.5524		
20	1.2186	1.4563	1.6289	1.2186	1.5524		
21	1.1248	1.2323	1.5043	1.2186	1.4415		
22	1.0688	1.2323	1.5203	1.0311	1.3443		
23	.9374	1.2197	1.4118	1.0311	1.2197		
24	1.7558	1.6872	1.9959	1.382	1.1248	1.5524	.9374
Max	3.4374	2.7435	2.7721	2.9424	2.6612	2.4897	1.9685
Min	.9374	1.2197	1.4118	1.0311	1.1248	1.4998	.9374
Avg	1.8734	1.8822	2.1654	1.8062	1.7784	1.7292	1.5203

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344029 / 33 KV KARANJA LAD SUB

STATION

Feeder No / Name : 402 / 33 KV KARANJA MANORA

FEEDER Feeder KV- 33 /
OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4266	1.3032	1.0974	1.3169	1.2071	1.0517	1.2071
2	1.4815	1.2094	1.0288	1.3169	1.2071	1.1317	1.2071
3	1.5364	1.3169	1.0288	1.3717	1.1946	1.0059	1.2071
4	1.5912	1.3169	.9859	1.5364	1.2071	1.0517	1.2071
5	1.8107	1.4266	1.2346	1.6461	1.2489	1.5947	1.3717
6	1.9753	1.9204	1.7558	1.9004	1.7375	1.4998	1.5912
7	2.2497	2.1176	1.6918	2.1948	2.1399	1.7147	2.0633
8	2.6337	2.3348	2.1628	2.4691	2.4434	2.0851	2.1559
9	2.0953	2.2805	2.1033	1.9662	2.0147		2.4434
10	2.1033	2.3045	1.9662	2.0119	2.1605		2.3348
11	2.1605	2.1948	2.0576	1.6461	2.1622		2.0633
12	2.0576	1.8484	1.9959	1.6975	1.885		1.9342
13	2.0513	1.6289	1.8461	1.3717	1.4575		1.773
14	1.7187	1.5684	1.7558	1.2003	1.5524		1.5746
15	1.5089	1.4661	1.4815	1.5524	1.2431		1.4506
16		1.4815	1.5912	1.6244	1.4918		1.5203
17	2.009	2.1399	1.7558	1.7375	1.8296		
18	2.4434	2.1033	2.0851	2.2262	1.9662		
19	2.3891	1.9662	2.4691	2.2262	1.9685		
20	2.1719	1.829	2.2497	2.0633	1.7833		
21	2.009	1.9204	1.9753	1.9547	1.7004		
22	1.7375	1.3717	1.8656	1.6832	1.6409		
23	1.4661	1.5524	1.5203	1.4661	1.2346		
24	1.4266	1.3575	1.0974	1.3169	1.3032	1.1248	1.262
Max	2.6337	2.3348	2.4691	2.4691	2.4434	2.0851	2.4434
Min	1.4266	1.2094	.9859	1.2003	1.1946	1.0059	1.2071
Avg	1.9154	1.7483	1.7001	1.7290	1.6575	1.3622	1.6686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344029 / 33 KV KARANJA LAD SUB

STATION

Feeder No / Name : 403 / 33 KV KARANJA FEEDER

SHEDDABLE URBAN

Feeder KV- 33 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.2036	3.2579	3.6591	2.8532	2.7692	2.8275	2.7984
2	3.2036	3.0407	3.678	2.8532	2.7692	2.8275	2.7984
3	3.2487	3.2922	3.5665	3.1276	2.6063	2.8275	3.1276
4	3.3122	3.2922	3.7146	3.2922	2.7435	3.1367	3.2373
5	3.3471	3.4568	3.9769	3.4019	2.7984	3.1927	3.0178
6	3.1493	4.1152	3.9918	3.2922	3.6763	3.4928	3.1824
7	3.5294	4.6639	4.369	3.3471	4.2353	4.1581	3.9638
8	3.8409	4.7851	4.7611	3.4568	4.561	4.5462	4.4525
9	4.5931	5.1532	4.8788	4.7125	4.5462		4.561
10	6.154	4.8868	4.9343	4.8234	4.9343		4.4593
11	5.1006	5.1578	4.768	4.9383	4.9343		4.1015
12	4.8171	4.3982	4.7125	4.9291	4.7125		3.9095
13	5.8213	4.425	4.6639	4.4907	4.6571		3.8009
14	5.4332	4.1701	4.6091	4.269	4.3799		3.6923
15	5.0452	4.0055	4.4525	4.1581	4.3244		3.638
16		4.0181	4.225	4.313	4.357		3.8552
17	4.0181	4.3799	4.2798	4.2896	4.4353		
18	4.0181	3.3265	3.8409	3.7466	3.8809		
19	3.9095	3.77	3.9506	4.181	3.8255		
20	3.3665	3.4374	3.8409	3.3122	3.4928		
21	3.0407	3.0493	3.4568	3.1493	3.2487		
22	2.8778	2.9384	3.2922	2.8778	2.9938		
23	2.6606	2.8567	2.963	2.7149	2.6612		
24	3.2036	3.4568	3.4374	2.7984	2.7435	2.8292	2.6063
Max	6.154	5.1578	4.9343	4.9383	4.9343	4.5462	4.561
Min	2.6606	2.8567	2.963	2.7149	2.6063	2.8275	2.6063
Avg	3.9519	3.8889	4.0843	3.7220	3.7619	3.3154	3.6001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344030 / 33 KV DARWHA ROAD SUB

STATION

Feeder No / Name : 201 / 11 KV DARWHA INDUSTRIAL

SHEDDABLE FEEDER HAVING WEEKLY

FEEDER Feeder KV- 11 / OUTGOING

STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0358	.0373	.0362	.1086	.0181	.0373	.0724
2	.0358	.0373	.0362	.1086	.0181	.0373	.0362
3	.0358	.0373	.0358	.1086	.0181	.0373	.0362
4	.0358	.0335	.0358	.1086	.0181	.0373	.0362
5	.0358	.0373	.0358	.1448	.0181	.0373	.0362
6	.0358	.056	.0358	.0724	.0181	.0373	.0362
7	.0358		.0358	.0724	.0181	.0373	.0362
8	.0358	.1307	.0716	.0362	.0362	.056	.0362
9	.0537	.112	.1075	.0362	.0648	.056	.0362
10		.1791	.1509	.0362	.1448	.0747	.1086
11	.1433	.1791	.1086	.0362	.1448	.1307	.1086
12	.112	.0905	.1448	.0724	.1494	.181	.1086
13	.112	.0724	.1086	.0724	.1867	.1086	.1448
14	.0373	.0362	.1086	.0724	.1494	.1086	.1448
15	.0747	.0716	.1086	.1448	.1867	.1448	.181
16	.112	.0716	.1086	.0724	.112	.1086	.181
17	.0747	.1086	.1086	.1086	.0747	.1448	.181
18	.0373	.1086	.1448	.1086	.112	.181	.181
19	.0747	.1448	.1448	.1086	.112	.1086	.1448
20	.0747	.1075	.1448	.1086	.112	.0724	.1448
21	.0373	.0716	.1448	.1086	.112	.0724	.1086
22	.0373	.0358	.1448	.0724	.0747	.0724	.0724
23	.0373	.0358	.1086	.0543	.0373	.0724	.0724
24	.0358	.0373	.0358	.1086	.0362	.0373	.0724
Max	.1433	.1791	.1509	.1448	.1867	.181	.181
Min	.0358	.0335	.0358	.0362	.0181	.0373	.0362
Avg	.0583	.0796	.0936	.0867	.0822	.0830	.0965

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344030 / 33 KV DARWHA ROAD SUB

STATION

Feeder No / Name : 202 / 11 KV DADGAON AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3887	.3887	.4481	
2				.3887	.3887	.4359	
3				.3887	.3887	.4359	
4				.3887	.3887	.4359	
5				.3887	.421	.4694	
6				.421	.421	.4862	
7				.5182	.5506	.4862	
8				.6478	.6478	.57	
9				.6154	.6802	.6036	
10	.6516	.8573	.7888				.6478
11	.9602	.8916	.7125				.8421
12	.9054	.8916	.7773				.8097
13	.8383	.8573	.7449				.7773
14	.8048	.9335	.6478				.7449
15	.8383	.7545	.6478				.7125
16	.8048	.7545	.6154				.6478
17	.7377	.6859	.583				.6154
24				.3887	.421	.4024	
Max	.9602	.9335	.7888	.6478	.6802	.6036	.8421
Min	.6516	.6859	.583	.3887	.3887	.4024	.6154
Avg	.8176	.8283	.6897	.4535	.4696	.4774	.7247

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344030 / 33 KV DARWHA ROAD SUB

STATION

Feeder No / Name : 203 / 11 KV DARWHAWESH FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1494	.132	.1307	.1494	.1494	.112
2	.132	.1307	.132	.1307	.1494	.1494	.112
3	.132	.1307	.132	.1307	.1494	.1867	.112
4	.132	.1307	.132	.1307	.1494	.1867	.112
5	.1509	.1494	.1509	.1307	.1494	.1867	.1494
6	.1886	.168	.1698	.1494	.1494	.2054	.168
7	.2263	.2241	.1886	.1867	.168	.2241	.2241
8	.2263	.2241	.2075	.2427	.2241	.2241	.2241
9	.2263	.2054	.2263	.2241	.2054	.2241	.2054
10	.2075	.2075	.1886	.2054	.1867	.2241	.1867
11	.1886	.1886	.2054	.168	.1494	.1867	.168
12	.1867	.1509	.168	.1478	.168	.1494	.1494
13	.1307	.1509	.1307	.1267	.1494	.1494	.1307
14	.112	.1097	.1867	.1086	.112	.1494	.112
15	.112	.132	.1307	.1086	.112	.112	.112
16	.1307	.132	.1307	.112	.1307	.2241	.112
17	.1494	.1509	.1494	.1494	.1494	.2054	.1494
18	.2241	.2263	.1867	.2241	.2241	.2054	.2054
19	.2427	.2263	.1867	.2427	.2427	.2241	.2427
20	.2427	.2452	.1867	.2241	.2241	.2054	.2241
21	.1867	.2263	.1867	.1867	.2054	.1867	.2241
22	.168	.1886	.1867	.1867	.2054	.1494	.112
23	.1494	.1509	.1307	.1867	.1494	.112	.112
24	.132	.1494	.132	.1307	.1494	.1494	.112
Max	.2427	.2452	.2263	.2427	.2427	.2241	.2427
Min	.112	.1097	.1307	.1086	.112	.112	.112
Avg	.1712	.1728	.1649	.1652	.1688	.1821	.1571

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344035 / 33 KV MANORA ROAD SUB

STATION

Feeder No / Name : 201 / 11 KV KRUSHNA COLONY

SHEDDABLE URBAN

FEEDER Feeder KV- 11 /
OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.1612	.1753	.128	.1448	.1254	.1463
2	.1646	.181	.1753	.1463	.1448	.1478	.1646
3	.1463	.1753	.1578	.128	.1448	.1433	.1463
4	.1629	.1646	.1578	.128	.1448	.1254	.1463
5	.1646	.1829	.1402	.1463	.181	.1463	.1646
6	.1829	.1991	.156	.1463	.181	.1791	.1829
7	.2353	.2149	.1928	.2012	.2172	.2534	.2195
8	.2715	.2534	.208	.2561	.2896	.3224	.2715
9	.2896	.2686	.2279	.3077	.3439	.4119	.4207
10	.3077	.3045	.3681	.3258	.4344	.0362	.362
11	.2715	.333	.3292	.3258	.3982	.3258	.3506
12	.2353	.333	.3439	.3258	.3475	.3475	.3155
13	.2172	.2454	.2534	.2896	.2896	.3077	.298
14	.2587	.2103	.2534	.2896	.3142	.2743	.298
15	.2149	.2454	.2926	.2715	.2715	.2743	.2774
16	.2507	.298	.2715	.2534	.2686	.3077	.3155
17	.3077	.298	.2896	.2534	.3258	.3439	.3155
18	.3439	.298	.2715	.2896	.3403	.4344	.3856
19	.362	.2804	.2378	.2715	.3258	.3475	.3856
20	.2328	.2804	.2195	.2353	.2507	.3475	.298
21	.2149	.2454	.2195	.1991	.2353	.2353	.208
22	.2172	.1753	.1629	.1991	.197	.1829	.1753
23		.1753	.128	.1991		.1646	.1753
24	.1646	.1629	.1928	.1463	.1448	.1448	.1646
Max	.362	.333	.3681	.3258	.4344	.4344	.4207
Min	.1463	.1612	.128	.128	.1448	.0362	.1463
Avg	.2332	.2369	.2260	.2276	.2581	.2471	.2578

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344035 / 33 KV MANORA ROAD SUB

STATION

Feeder No / Name : 203 / 11 KV GIRDA GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2658	.2865	.2601	.2658	.2658	.2353	.2279
2	.2658	.3045	.2601	.2658	.2303	.2172	.2303
3	.2481	.2926	.2454	.2658	.2303	.1991	.2303
4	.2481	.2896	.2454	.2658	.2303	.2149	.2303
5	.2658	.2896	.2454	.2835	.2658	.2328	.2303
6	.3155	.3258	.2804	.3012	.2835	.2328	.2658
7	.333	.3801	.3155	.3366	.3366	.3045	.3155
8	.3506	.3439	.333	.3506	.333	.2686	.3155
9	.3681	.3761	.3121	.333	.3155	.3582	.3189
10	.333	.3258	.333	.3189	.2835	.2534	.3366
11	.3258	.2804	.3189	.2835	.2481	.2481	.3294
12	.2896	.2774	.3012	.2658	.1991	.2481	.2804
13	.2686	.2629	.2658	.2303	.1791	.2103	.2279
14	.2896	.2804	.2658	.2658	.181	.1595	.2279
15	.2743	.2629	.2303	.2835	.2172	.1595	.208
16	.2865	.2774	.2658	.2835	.2507	.2279	.2279
17	.3224	.2947	.3012	.3012	.2715	.2835	.2279
18	.3982	.298	.3898	.3366	.362	.3681	.3681
19	.362	.2804	.4252	.3898	.3982	.3544	.3681
20	.3801	.2804	.3681	.3366	.3403	.3544	.333
21	.3582	.2427	.333	.3189	.3077	.3012	.298
22	.3258	.2804	.3012	.2835	.2534	.2658	.2427
23		.2804	.2481	.2835		.2303	.2454
24	.2629	.2896	.2629	.2835	.2686	.2218	.2303
Max	.3982	.3801	.4252	.3898	.3982	.3681	.3681
Min	.2481	.2427	.2303	.2303	.1791	.1595	.208
Avg	.3103	.2959	.2962	.2972	.2718	.2562	.2715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344035 / 33 KV MANORA ROAD SUB

STATION

Feeder No / Name : 401 / 33 KV DAPURA FEEDER

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4563	1.5043	1.4198	.5784	.4298	.8596	1.2094
2	1.4723	1.4506	1.4198	.5784	.4298	.9134	1.2094
3	1.5083	1.5043	1.3146	.5258	.4298	.8779	1.1443
4	1.4563	1.5043	1.262	.5784	.4835	.9134	1.1443
5	1.5083	1.4506	1.3146	.5784	.5316	.8688	1.1963
6	1.5775	1.4661	1.4723	.631	.5316	.8059	1.3146
7	1.8724	1.5203	1.6827	.7362	.7442	.8145	1.5604
8	1.9765	1.7375	1.7878	.7888	.7442		1.7164
9	1.9244	1.6289	2.1033	.7888	.7442	.6584	1.7878
10	.6762	.3761	2.1033	1.7353	1.893	1.9204	.7362
11	.543	.5258	.5784	1.7353	1.6827	2.0285	.7282
12	.4344	.5258	.2103	1.7878	1.9004	1.6644	.631
13	.4835	.4733	.3681	1.4883	1.6118	1.4563	.5201
14	.3292	.3155	.3641	1.9456		1.6827	.5258
15	.3224	.3155	.1052	1.5604	.2149	1.6301	.4681
16	.3224	.4681	.3681	1.5604		1.6644	.4207
17	.4835	.5258	.4733	1.5775	1.773	.8413	.4207
18	.6984	.5201	.6762	.7362	.8145	.6836	.631
19	2.2805	.5784	.6836	.7362	1.8461	.8413	.631
20	.5973	.5784	.6762	.691	.8145	.7888	.5258
21	.5487	.5258	.5784	.6447	.7059	.6836	.631
22	2.8235	.631	.5721	.6447	.5373	.5784	.5258
23		.631	.631	.591		.5784	.5201
24	1.5083	1.2489	.5784	.5784	.4298	.543	.4733
Max	2.8235	1.7375	2.1033	1.9456	1.9004	2.0285	1.7878
Min	.3224	.3155	.1052	.5258	.2149	.543	.4207
Avg	1.1654	.9169	.9477	.9915	.9187	1.0564	.8613

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344035 / 33 KV MANORA ROAD SUB

STATION

Feeder No / Name : 402 / 33 KV MANORA KARANJA

SHEDDABLE URBAN

FEEDER Feeder KV- 33 /
INCOMING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2197	1.6289	1.3146	1.2197	1.1523	1.6118	1.1088
2	1.2752	2.009	1.3146	1.2752	1.1523	1.8461	1.1088
3	1.3306	2.1719	1.3146	1.3306	1.0974	1.9547	1.1088
4	1.3306	1.8804	1.262	1.2752	1.086	2.0953	1.1643
5	1.5364	1.8804	1.262	1.3169	1.2489	2.0633	1.1088
6	1.7558	1.9342	1.5775	1.5364	1.5203	2.1719	1.6078
7	2.1948	1.6118	1.6827	2.0302	2.0633	2.2731	2.1622
8	2.4691	2.4977	2.1033	2.4394	2.4434	2.5252	2.4691
9	2.524	2.3891	2.3137	2.4143	2.4434	2.4714	2.4691
10	2.524	2.2565	2.2085	2.3045	2.2805	2.2028	2.3594
11	2.2565	1.893	2.1948	2.0851	2.0633	1.9753	2.2611
12	2.1719	1.893	1.9404	1.9004	1.9004	1.9753	2.1033
13	1.9879	1.9456	1.8107	1.6461	1.7918	1.7558	1.8404
14	1.5043	1.4563	1.5524	1.5203	1.5746	1.6632	1.8204
15	1.5746	1.5249	1.5524	1.4661	1.5947	1.4969	1.6827
16	1.6655	1.6301	1.6078	1.7375	1.5249	1.5524	1.5775
17	1.9547	1.7878	1.7558	1.7918	1.8461	1.885	1.5775
18	2.4434	1.7878	2.2497	2.2805	2.2805	2.3045	2.3137
19	2.2565	1.6124	2.1948	2.1948	2.2262	2.3594	2.2885
20	2.1719	1.6301	1.9753	2.0851	2.1719	2.1948	2.1033
21	1.9004	1.5775	1.8656	1.9753	1.7918	1.9959	1.7878
22	1.6289	1.6827	1.6632	1.7558	1.6289	1.7187	1.5775
23		1.6644	1.4969	1.6461			1.5775
24	1.3306	1.2489	1.5775	1.2752	1.262	1.2357	1.2197
Max	2.524	2.4977	2.3137	2.4394	2.4434	2.5252	2.4691
Min	1.2197	1.2489	1.262	1.2197	1.086	1.2357	1.1088
Avg	1.8699	1.8164	1.7413	1.7709	1.7454	1.9708	1.7666

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MALEGAON S DN.[575] BU 1562

Substation No/ Name :- 344014 / 33 KV MEDSHI

Feeder No / Name : 202 / 11 KV RIDHORA AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2561	.2812	.2656	
2				.2241	.2812	.2656	
3				.2241	.2812	.2656	
4				.2241	.2812	.2656	
5				.2241	.2812	.2812	
6				.2241	.3125	.2968	
7				.2721	.4062	.3437	
8				.3479	.4687	.4687	
9				.3795	.5155	.5468	
10	.5218	.3906	.421				.4534
11	.578	.6478	.5535				.6401
12	.5624	.6478	.6009				.7042
13	.6249	.6478	.6483				.68
14	.578	.6478	.6483				.6483
15	.5468	.6478	.6009				.6009
16	.5155	.6478	.5376				.5218
17	.4687	.6478	.4428				.5121
24				.2561	.2812	.2656	
Max	.6249	.6478	.6483	.3795	.5155	.5468	.7042
Min	.4687	.3906	.421	.2241	.2812	.2656	.4534
Avg	.5495	.6157	.5567	.2632	.3390	.3265	.5951

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MALEGAON S DN.[575] BU 1562

Substation No/ Name :- 344014 / 33 KV MEDSHI

Feeder No / Name : 203 / Medshi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1509	.168	.0943	.168	.1494	.1494
2	.1509	.1509	.168	.1509	.168	.1494	.1494
3	.1509	.1509	.168	.1509	.168	.1494	.1494
4	.1509	1.5089	.168	.1509	.168	.168	.1494
5	.1698	.168	.1867	.1867	.168	.1867	.1494
6	.1886	.2241	.2241	.2427	.2772	.2054	.1867
7	.3174	.3174	.2241	.3174	.3142	.3361	.2987
8	1.0642	.2987	.2241	.3174	.2957	.3361	.2987
9	.2987	.2987	.2241	.2614	.2402	.2801	.3174
10	.2614	.2241	.2614	.2427	.2402	.2614	.2614
11	.2054	.1867	.2241	.2218	.2054	.1867	.2241
12	.2241	.168	.168	.1663	.168	.1867	.1867
13	.2054	.168	.2054	.1663	.1494	.1867	.1494
14	.1867	.168	.1494	.1663		.1307	.1494
15	.1867	.1494	.1494	.1663		.1307	.1494
16	.2241	.1494	.168	.1663		.1307	.168
17	.2054	.1867	.1867	.2402	.2987	.1867	.2241
18	.2427	.2801	.2614	.2772	.3174	.2987	.2987
19	.2987	.3174	.3174	.2957	.3547	.3361	.2987
20	.2801	.2987	.2614	.2957	.2987	.2987	.2829
21	.2054	.2987	.2263	.2241	.2614	.2987	.2263
22	.1867	.2241	.1886	.1867	.2054	.2987	.1886
23	.1494	.1867	.1698	.168	.1494	.1867	.1509
24	.1509	.1494	.168	.1509	.168	.1494	.1494
Max	1.0642	1.5089	.3174	.3174	.3547	.3361	.3174
Min	.1494	.1494	.1494	.0943	.1494	.1307	.1494
Avg	.2440	.2677	.2025	.2086	.2278	.2178	.2065

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MALEGAON S DN.[575] BU 1562

Substation No/ Name :- 344014 / 33 KV MEDSHI

Feeder No / Name : 204 / Ridhora Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4294	.415	.6626	.8048	.7865	.6584	.7164
2	.4294	.415		.8048	.7865	.6584	.7164
3	.4294	.4338		.8048	.7865	.6584	.7164
4	.4481	.4715		.8688	.7865	.6584	.7164
5	.5975	.6036		.9671	.7865	.7316	.7164
6	.8402	.8488		1.1104	1.0745	.9145	1.0745
7	1.1016	1.226		1.4529	1.3969	1.2936	1.3969
8	1.0642	1.0082		1.4327	1.3969	1.4449	1.3969
9	1.0642	.7392		1.5746	1.3611	1.5384	1.3969
10	.8215	.7095	1.0387	1.4685		1.3575	1.3611
11	.724	.5373	1.134	1.0745		1.0745	1.0745
12	.4525	.5373	1.0985	1.0566	1.0208	1.0745	1.0029
13	.394	.6268	1.0631	1.0387	.985	1.0745	.9671
14	.4525	.6268	1.0277	.9492	.9671	1.0745	.9134
15	.4344	.6626	.9214	1.0387	.9492	.6805	.9313
16	.4887	.6626	.985	1.0566	.9671	1.2536	.9671
17	.6401	.7164	1.2536	1.0566	1.0745	1.2536	1.1041
18	.9145	1.0745	1.3611	1.2536	1.2536	1.4327	1.4118
19	1.0164	1.379	1.3969	1.2536	1.3756	1.4864	1.3969
20	.924	1.0745	1.2894	1.2536	1.1946	1.4327	1.086
21	.7023	1.0745	1.182	1.0608	.9955	1.4327	1.086
22	.5544	1.0745	1.0745	.823	.8507	1.0745	.9877
23	.4668	.8954	.8145	.7865	.6697	1.0745	.8413
24	.4294	.415	.6626	.8048	.7865	.6516	.7164
Max	1.1016	1.379	1.3969	1.5746	1.3969	1.5384	1.4118
Min	.394	.415	.6626	.7865	.6697	.6516	.7164
Avg	.6591	.7595	1.0604	1.0748	1.0114	1.0827	1.0290

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MALEGAON S DN.[575] BU 1562

Substation No/ Name :- 344023 / SHIRPUR

Feeder No / Name : 202 / shirpur town

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4854	.4668	.462	.462	.4854	.4066	.4251
2	.4854	.4668	.5544	.462	.4854	.4435	.4251
3	.4854	.4668	.6653	.5281	.4854	.6283	.4251
4	.5975	.5228	.7392	.5658	.5601	.8501	.5041
5	.7842	.6602	1.0349	.6413	.6908	.924	.6413
6	1.1203	1.1128	1.1458	1.0374	.9896	1.1088	.9997
7	1.307	1.358	1.3121	1.3014	1.3443	1.2197	1.3203
8	1.307	1.226	1.3121		1.251	1.2567	1.3203
9	1.1576	1.1883	1.2197	1.3817	1.1949	1.1643	1.3014
10	1.1203	1.0082	1.0903	1.3817	.6653	1.0349	1.1016
11	.961	.8316	.9328	.8779	.8131	.8316	.7947
12	.8131	.6468	.7316	.7133	.7023	.7023	.7392
13	.7392	.6283	.5973	.5853	.6283	.7087	.6584
14	.543	.6161	.6154	.5373	.5544	.5731	.5792
15	.5434	.5788	.6379	.5316	.5544	.5731	.543
16	.6379	.6535	.6556	.6268		.6335	.6697
17	.7522	.7468	.7421	.7682	.7947	.8871	.7783
18	1.0534	1.0269	.9593	.9979	1.0164	1.0456	.961
19	.8962	.9149	.9335	.961	.9795	.8775	.8871
20	.8029	.8029	.7655	.7392	.8316	.8029	
21	.6908	.6908	.5788	.6468	.6838	.6722	.6722
22	.5975	.5975	.5788	.5601	.5544	.5415	.5788
23	.5228	.5228	.4805	.4854	.4805	.4668	.4805
24	.4854	.4854	.4481	.462	.4854	.4435	.4251
Max	1.307	1.358	1.3121	1.3817	1.3443	1.2567	1.3203
Min	.4854	.4668	.4481	.462	.4805	.4066	.4251
Avg	.7870	.7592	.7997	.7502	.7492	.7832	.7492

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MALEGAON S DN.[575] BU 1562

Substation No/ Name :- 344023 / SHIRPUR

Feeder No / Name : 203 / karanji ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.2534	.3161	.2258	.2972	.3353	
2	.3353	.2534	.3311	.2258	.2972	.3658	
3	.3353	.2534	.3612	.2258	.2972	.3658	
4	.3353	.2743	.3913	.2709	.2972	.4268	
5	.3353	.2743	.4515	.301	.2972	.442	
6	.4268	.3475	.5117	.3311	.3567	.4572	
7	.6859	.6923	.7375	.3763	.5201	.5182	
8	1.0669	.9031	.9332		.6687	.8078	
9	1.0669	1.0031	.8579	.5268	.6687	.7468	
10	.5868	.5792	.5639	.6668	.535	.5944	.6097
11	.7827	.6859	.7621	.8916	.5498	.6401	.7926
12	.743	.7375	.7621	.8916	.5647	.6321	.7926
13	.7876	.7811	.7621	.8916	.5944	.5792	.8078
14	.6748	.7316	.7225	.8173	.5944	.5502	.7621
15	.6748	.7316	.7225	.7727	.5944	.5001	.6773
16	.6748	.6859	.7225	.6687	.535	.4858	.7225
17	.5721	.6097	.587	.5201	.4904	.423	.7526
24	.3048	.2366	.2709	.2258	.2972	.3048	
Max	1.0669	1.0031	.9332	.8916	.6687	.8078	.8078
Min	.3048	.2366	.2709	.2258	.2972	.3048	.6097
Avg	.5958	.5574	.5982	.5194	.4698	.5097	.7397

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MALEGAON S DN.[575] BU 1562

Substation No/ Name :- 344023 / SHIRPUR

Feeder No / Name : 205 / karanji gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2402	.2772	.2241	.2378	.2402	.2218	.2402
2	.2402	.2772	.2614	.2561	.2402	.2402	.2402
3	.2402	.2957	.3361	.3292	.2402	.3142	.2402
4	.3696	.3696	.4481	.4024	.3696	.4805	.3734
5	.6468	.5228	.5975	.5304	.4805	.6283	.5601
6	.8501	.8402	.8962	.823	.7392	.8686	.8589
7	1.1458	1.1389	1.0642	.9877	1.0164	1.0719	1.1576
8	1.0164	.8589	1.1576		.9979	1.0719	
9	.924	.9335	.9896	.8779	.924	.961	.9709
10	.7023	.7095	.7655	.6767	.5914	.6838	.6722
11	.4066	.4435	.4481	.4572	.2772	.3326	.3734
12	.3326	.2772	.3734	.2743		.2587	.3361
13	.2772	.2987	.2241	.2561	.2218	.2378	.2427
14	.2033	.2427	.2241	.2195	.2033	.2012	.1867
15	.2772	.2614	.2801	.2195	.2033	.2195	.2054
16	.3881	.3361	.3361	.3658	.3326	.2743	.3361
17	.6099	.4668	.5041	.4572	.4435	.5304	.4854
18	.8215	.7842	.7468	.6401	.7577	.8131	.7468
19	.7468	.5788	.6535		.8131	.8131	.5975
20	.5601	.5415	.5788	.5487	.499	.5914	.6722
21	.4108	.4108	.4854	.3326	.3881	.462	.4108
22	.3142	.4481	.2957	.2772	.2772	.2957	.2987
23	.2587	.3734	.2402	.2587	.2218	.2587	.2561
24	.2402	.2587	.2987	.2378	.2402	.2033	.2402
Max	1.1458	1.1389	1.1576	.9877	1.0164	1.0719	1.1576
Min	.2033	.2427	.2241	.2195	.2033	.2012	.1867
Avg	.5093	.4977	.5179	.4394	.4660	.5014	.4653

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MALEGAON S DN.[575] BU 1562

Substation No/ Name :- 344024 / KINHIRAJA

Feeder No / Name : 201 / YERANDA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.5087	.5144	.631	.4748	.6516	.426
2	.6783	.5487	.5609	.631	.4748	.6516	.4359
3	.5765	.5721	.6201	.6024	.4748	.6516	
4	.5636	.5959	.6697	.6024	.583	.6762	.5487
5	5.1217	.6447	.6697	.5144	.6984	.7087	.6379
10	1.1517	1.1218	1.0166	1.0631	1.1694	1.0631	1.0454
11	1.0174	1.1869	.9189	1.0802	1.0513	1.134	1.0004
12	.9892	1.073	.9556	.9389	.9892	1.2136	.8987
13	.8421	1.073	.7773	.8421	.6962	1.1317	.7202
14	.9116	.8288	.7956	.8002	.7459		.7202
15	.9665	.8288	.7701	.8383	.8619		.7373
20	1.0395	.6516	.8764	.7712	.8842	.7373	.8322
21	.6874	.6443	.7888	.7202	.7969	.703	.6859
22	.5256	.5548	.6935	.6104	.6687	.5197	.547
23	.5138	.463	.6859	.5087	.6516	.4588	.4915
24	.7888	.503	.4801	.631	.4748	.6516	.4424
Max	5.1217	1.1869	1.0166	1.0802	1.1694	1.2136	1.0454
Min	.5138	.463	.4801	.5087	.4748	.4588	.426
Avg	1.0705	.7374	.7371	.7366	.7310	.7823	.6780

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MALEGAON S DN.[575] BU 1562

Substation No/ Name :- 344024 / KINHIRAJA

Feeder No / Name : 202 / kinhiraja SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	.6859	.6962	.7628	.5426	.5426	.6062
2	.9602	.7011	.7042	.7628	.5426	.6173	.6133
3	.9389	.7442	.7545	.7011	.6173	.6173	.6371
4	.9054	.7442	.8063	.7011	.7011	.7011	.6935
5	.9054	.7964	.7362	.7087	.7522	.8505	.8413
10	1.2136	1.2136	1.1096	1.0288	.9431	1.0402	1.0402
11	1.153	1.2003	1.1401	1.0174	.8718	1.2136	.9602
12	1.0852	1.2003	.9389	1.0059	.8048	1.2003	.8817
13		1.2003	.8619	.8951	.7042	1.0852	.8192
14		1.0288	.8478	.8192	.7042		.7865
15	.9835	.8478	.7625	.8383	.6706		.7377
20	1.0059	1.0059	1.0288	.823	.8669	.8916	.7545
21	.9496	.8619	.9259	.7122	.7461	.7545	.6104
22	.7796	.7377	.8478	.6443	.6443	.6796	.57
23	.6962	.6962	.8573	.5426	.6443	.6226	.4915
24	1.0402	.6783	.6962	.7628	.5426	.5426	.6226
Max	1.2136	1.2136	1.1401	1.0288	.9431	1.2136	1.0402
Min	.6962	.6783	.6962	.5426	.5426	.5426	.4915
Avg	.9747	.8964	.8571	.7954	.7062	.8114	.7291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MALEGAON S DN.[575] BU 1562

Substation No/ Name :- 344024 / KINHIRAJA

Feeder No / Name : 203 / kawardari SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.1928	.1753	.1772	.1928	.1991	.1753
2	.2401	.2658	.1753	.1772	.1928	.1991	.1753
3	.2374	.3189	.1753	.1715	.1949	.1991	.1772
4	.2374	.3403	.197	.1715	.2149	.2195	.1772
5	.2374	.3582	.197	.1715	.2172	.2195	.197
6	.2743	.3582	.3544	.208	.2896	.2743	.2957
7	.3155	.3582	.4031	.2865	.3544		.362
8	.3898	.443	.4031	.3258	.4733	.4119	.4477
9	.3772	.4409	.3391	.362	.5028	.3582	.4409
16	.4218	.4915	.3277	.4641	.4024	.4062	.4144
17	.4424	.4144	.2915		.3772	.4096	.431
18	.39	.3772		.3814	.3544	.4024	.3812
19	.3086	.2601	.3467	.3121	.2865	.3403	.3353
22	.1949	.1928	.1734	.2149	.1991	.1949	.1844
23	.1791	.1753	.1715	.1949	.1991	.1907	.1715
24	.2401	.1753	.1753	.1772	.1949	.1991	.1753
Max	.4424	.4915	.4031	.4641	.5028	.4119	.4477
Min	.1791	.1753	.1715	.1715	.1928	.1907	.1715
Avg	.2954	.3227	.2604	.2531	.2904	.2816	.2838

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MALEGAON S DN.[575] BU 1562

Substation No/ Name :- 344032 / 33 KV AMANI

Feeder No / Name : 201 / amani gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5041	.4908	.4938	.4668		.3658	.5544
2	.5041	.4733	.4887	.4668	.5228	.362	.5544
3	.5975	.6154	.4887	.4668	.5228	.3658	.462
4	.7095	1.1088	.5304	.7095	.6036	.3982	.5544
5	1.0082	1.363	.9055	1.0082	.7621	.5359	.8871
6	1.2323	1.4003	1.363	1.2696	1.3146		1.386
7	.4854	1.531	1.386	1.587	1.4003		1.6057
8	.8402	1.3443	1.5497	1.363	1.4377		1.475
9	.7655	1.419	1.363	1.2136	1.363		1.4937
10	.5194	1.1088	1.1203	1.1088	1.1088	.7392	1.1706
11	.3982	.5601	.8775	.7316	.823	.4435	.8238
12		.5544	.7095	.6201	.7392	.2402	.6588
13		.591	.6348	.5895	.5784	.499	.5197
14	.5068	.6274	.6535	.6783	.543	.4805	.5434
15	.6344	.6697	.6161	.6104	.6401	.5175	.5609
16	.7164	.6838	.6535	.7628	.7335	.961	.6556
17	1.0791	.823	.8215	.905	.8596	.7392	.9328
18	1.3491	1.2883	1.2936	1.1706	1.251	1.386	1.2567
19	1.2696	1.2136	1.2136	1.2696	1.2012	1.3306	1.2637
20	1.0059	1.0456	.9335	1.0164	.9145	.9979	1.0185
21	.823	.7947	.9335	.823	.7783	.8131	.7842
22	.6653	.583	.6099	.6401	.6099	.6283	.5729
23	.5249	.5068	.5041	.5487	.4755	.6099	.462
24	.5041	.5249	.4938	.4668	.5228	.439	.5914
Max	1.3491	1.531	1.5497	1.587	1.4377	1.386	1.6057
Min	.3982	.4733	.4887	.4668	.4755	.2402	.462
Avg	.7565	.8884	.8599	.8539	.8568	.6426	.8662

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MALEGAON S DN.[575] BU 1562

Substation No/ Name :- 344032 / 33 KV AMANI

Feeder No / Name : 203 / amani ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.3715	.3858	.2688	.2401	.2896	.3239
2	.3353	.4012	.3525	.2688	.2534	.2675	.3239
3	.3353	.3807	.3429	.2688	.2534	.2881	.2915
4	.3658	.3948	.3475	.2688	.2401	.3277	.3239
5	.3963	.4033	.3144	.2688	.2675	.3086	.3563
6	.4115	.2782	.2743	.2846	.2675	.3155	.2915
7	.3353	.3201	.4668		.5357	.5967	.2915
8	.3353	.3567	.4805		.6773	.6401	.3887
9	.3353	.4001	.4075		.7407	.6944	.4372
10	.3163	.5144	.3479		.703	.7099	.3978
11	.2881	.4435	.3898	.5792	.6773	.7099	.3605
12		.439	.4252	.7253	.6401	.703	.3321
13		.4435	.4607	.6923	.6321	.7343	.3605
14	.381	.4435	.4075	.643	.6081	.703	.3281
15	.8951	.8764	.8796	.953	.724	.578	.7907
16	.9414	.8796	.7907	.945	.7335	.578	.7621
17	.8383	.7145	.7116	.6241	.5921	.578	.6859
18	.6687	.6602	.6958		.459	.4687	.6241
19	.5647	.5716	.5693	.4199	.3572	.3906	.4923
20	.535	.5498	.5376	.3616	.3338	.3125	.4371
21	.5068	.5357	.5376	.3067	.3018	.3281	.439
22	.6348	.5287	.506	.2721	.2858	.3077	.3978
23	.4725	.4652	.3163	.3201	.3185	.3887	.3201
24	.3201	.3567	.3909	.2688	.2534	.2972	.3563
Max	.9414	.8796	.8796	.953	.7407	.7343	.7907
Min	.2881	.2782	.2743	.2688	.2401	.2675	.2915
Avg	.4795	.4887	.4724	.4600	.4623	.4798	.4214

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MALEGAON S DN.[575] BU 1562

Substation No/ Name :- 344052 / Jaulka

Feeder No / Name : 201 / JAULKA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7207		.6193	.905	.8316	.9107	.6375
2	.7207		.6011	.905	.8131	.8743	.6375
3	.7947		.6011	.9231	.9795	.9107	.6739
4	.924		.6921	.9593	1.0534	.9653	.765
5	1.0349		.9471	1.1041	1.1088	1.0928	.8743
14	1.4025	.9289	1.4175		1.7849		
15	1.3114	1.6757	1.382		1.9489		
16	1.0928	1.4753		1.7002			1.7372
17	1.3073	1.4935	1.4175		1.8396		1.7909
18	1.2536	1.4571	1.4529	1.7926	1.8214	1.3842	1.7013
19	1.0029	1.2203	1.2757	1.6632	1.7667	1.3478	1.6655
20	.8238	1.0382	1.2536	1.6263	1.6574	1.2385	1.3213
21	.765	1.02	1.0029	1.3306	1.4207	1.02	1.1403
22	.7103	.8743	1.0745	.9979	1.2385	.8743	.8688
23	.6921	.6193	.9593	.924	1.0018	.6921	.8145
24	.7023		.6375	.905	.8501	.9471	.6375
Max	1.4025	1.6757	1.4529	1.7926	1.9489	1.3842	1.7909
Min	.6921	.6193	.6011	.905	.8131	.6921	.6375
Avg	.9537	1.1803	1.0223	1.2105	1.3411	1.0215	1.0904

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MALEGAON S DN.[575] BU 1562

Substation No/ Name :- 344058 / KARLI

Feeder No / Name : 201 / Karli

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4334	.3467	.3467	.4458	.4115	.3814	.3429
2	.4334	.3467	.3467	.4115	.4115	.4334	.3429
3	.5201	.3467	.3467	.3772	.4458	.4334	.3086
4	.5201	.4161	.5895	.5144	.4801	.5201	.4115
5		.5895	.6588	.6516		.6068	.583
9							.583
10	.7716	.5144	.7202	.5144	.7545	.7716	.7202
11		.7202	.6104	.5144	.4801	.6516	.6001
12	.5144	.7621	.5144	.6173	.4801	.6344	.5144
13	.6859	.6173	.4801	.583	.4458	.6173	.4115
14	.5144	.5144	.4458	.583	.3772	.4458	.4287
19	.7461	.7282	.5765	.7545	.7202	.6859	.6516
20	.583	.6241	.6104	.6516	.6001	.7202	.583
21	.5895	.5895	.583	.6173	.5487	.5144	.5144
22	.4508	.4854	.4458	.5487	.4508	.4115	.4115
23	.3814	.3814	.4115	.5144	.3814	.3429	.3772
24	.4334	.3814	.3467	.3772	.4458	.3814	.3429
Max	.7716	.7621	.7202	.7545	.7545	.7716	.7202
Min	.3814	.3467	.3467	.3772	.3772	.3429	.3086
Avg	.5413	.5228	.5021	.5423	.4956	.5345	.4781

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MALEGAON S DN.[575] BU 1562

Substation No/ Name :- 344058 / KARLI

Feeder No / Name : 202 / Borala

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2601	.3052	.2401	.3391	.3258	.2774	.3121
2	.2601	.2713	.2401	.3391	.3086	.3121	.2774
3	.2774	.2713	.2401	.373	.3429	.3121	.2774
4	.3467	.4409	.2401	.3052	.4115	.4334	.3467
5	.5201	.5765	.4458	.6104	.4801	.5201	.5548
10	.6859	.7545	.6859	.6859	.6173	.6516	.6001
11	.6001	.6859	.6173	.6859	.5144	.5658	.6001
12	.5144	.6859	.3944	.6173	.4458	.4801	.5144
13	.2229	.4458	.3772	.4458	.4115	.4458	.4458
14	.4287	.5144	.3429	.4801		.3772	.4287
19	.6706	.6516	.6371	.6173	.6859	.7282	.6173
20	.5765	.583	.6104	.5144	.5144	.6935	.5201
21	.4801	.4458	.5765	.4287	.4287	.4508	.4161
22	.373	.3429	.5426	.4115	.3467	.3467	.3121
23	.3052	.2743	.4409	.3258	.3467	.3121	.2774
24	.2601	.3052	.2401	.3052	.3258	.2774	.2774
Max	.6859	.7545	.6859	.6859	.6859	.7282	.6173
Min	.2229	.2713	.2401	.3052	.3086	.2774	.2774
Avg	.4239	.4722	.4295	.4678	.4337	.4490	.4236

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344010 / 33 KV MAGALURPIR SUB STATION

Feeder No / Name : 201 / Town-1 feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4409	.4458	.4801	.4409	.4359	.4409	.4458
2	.4359	.4458	.4557	.4024	.4298	.4359	.4458
3	.4359	.4908	.4607	.4298	.439	.4578	.4578
4	.4801	.6379	.4607	.4755	.4755	.4409	.503
5	.8048	.8688	.6283	.5853	.5975	.6661	.9774
6	1.0456	1.2197	.9709	.8215	.8215	.924	1.2936
7	1.6221	1.3306	1.5684	1.3443	1.3443	1.7551	1.4937
8	1.5844	1.4563	1.5684	1.4937	1.5684	1.6057	1.5684
9	1.7924	1.3443	1.6057	1.419	1.4937		1.419
10	1.6057	1.3443	1.531	1.419	1.4937	1.2323	1.419
11	1.4937	1.2936	1.307	1.2567	1.3443	1.1203	1.2696
12	1.4563	1.1458	1.0974	1.0242	1.2197	1.2308	1.1458
13	1.2323	1.2437	.8413	.8779	.8779	1.0029	.8779
14	.9412		.724		.7164	.7522	.7164
15	.567	.7316	.6379	.6089	.6661	.631	.7011
16	.7964	.788	.7682	.7316	.7796	.7087	.6733
17	1.0242	1.0608	.9877	1.086		.9774	1.0242
18	1.3676	1.3676	1.0974	1.1827	1.6448	1.419	1.3676
19	1.1458	1.1458	1.2178	1.1088	1.2567	1.1827	1.1949
20	.9877	.9877	.9511	.8779	.9877		.9511
21		.905	.8048	.7522	.7602	.8688	.788
22		.6733	.6173	.6241	.6173		.5959
23		.5144	.5144	.5487	.5144	.5487	.503
24	.4748	.4458	.4801	.4409	.4755	.4268	.4755
Max	1.7924	1.4563	1.6057	1.4937	1.6448	1.7551	1.5684
Min	.4359	.4458	.4557	.4024	.4298	.4268	.4458
Avg	1.0350	.9516	.9073	.8675	.9113	.8966	.9295

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344010 / 33 KV MAGALURPIR SUB STATION

Feeder No / Name : 202 / Town-2 feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7537	.7802	.7202	.7133	.7682	.7164	.7442
2	.7108	.7282	.6935	.6878	.6935	.7087	.7186
3	.6859	.7282	.6859	.6733	.6859	.6836	
4	.7712	.7973	.703	.788	.7186	.6762	.788
5	.9145	1.0136	.8413	.9511	.8779		1.0608
6	1.0974	1.3306	1.0425	1.1706	1.0534	1.0059	1.3535
7	1.6617	1.5524	1.4969	1.423	1.4969	1.7372	1.5708
8	1.7556	1.5708	1.7556	1.5524	1.6632	1.7002	1.6632
9	1.6644	1.5364	1.6263	1.6278	1.6263		1.5364
10	1.5364	1.4661	1.5655	1.4449	1.4842	1.5023	1.4661
11	1.3611	1.4175	1.3575	1.2489	1.2536	1.2403	1.2715
12	1.262	1.262	1.2308	1.134	1.0749	1.0923	1.0749
13	1.0166	1.166	1.0288	1.0166	.9259	.9945	1.134
14	.9945		.9088	.9536	.8817	.8951	1.0425
15	.9389	1.0608	.9088	.9389	.9156	.8848	1.0242
16	1.0631	1.0631	1.1203	1.0059	1.1203	.9779	1.0059
17	1.1789	1.1831	1.17	1.2269		1.1191	1.1065
18	1.4706	1.4175	1.2209	1.4022	1.5238	1.4373	1.5061
19	1.5023	1.4864	1.3969	1.3756	1.448	1.382	1.086
20	1.2894		1.2536	1.2403	1.3535		1.2536
21		1.1517	1.0867	1.1163	1.1403	1.1517	1.1104
22		.964	.8916	.9189	.9774		.9362
23		.8596	.8029	.9015	.7545	.7888	.7712
24	.7888	.7888	.7545	.7455	.7455	.7682	.7522
Max	1.7556	1.5708	1.7556	1.6278	1.6632	1.7372	1.6632
Min	.6859	.7282	.6859	.6733	.6859	.6762	.7186
Avg	1.1628	1.1511	1.0943	1.0941	1.0949	1.0731	1.1294

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344010 / 33 KV MAGALURPIR SUB STATION

Feeder No / Name : 203 / manora

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4066		.5914				.4435
2	.4251		.4805				.4251
3	.4251		.4435				.4251
4	.4435		.4435				.4805
5	.5175		.4805				.5175
6	.5729		.5544				.5914
7	.8501		.924				.6283
8		1.1088	1.2567				.8871
9		1.3676	1.1088				.8131
10				1.0164	.8501	.8871	
11				.9979	1.0349	1.1088	
12				1.1088	.924	.961	
13				.961	.8686	.8871	
14				.6838	.7392	.7762	
15				.8316	.7023	.7762	
16					.8131	.8316	
17						.5175	
24	.3881		.7392				.4435
Max	.8501	1.3676	1.2567	1.1088	1.0349	1.1088	.8871
Min	.3881	1.1088	.4435	.6838	.7023	.5175	.4251
Avg	.5036	1.2382	.7023	.9333	.8475	.8432	.5655

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344010 / 33 KV MAGALURPIR SUB STATION

Feeder No / Name : 204 / shelu

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2321	.2984	.2652	.7293	.7956	.5967	.2652
2	.2155	.2984	.2652	.7293	.6962	.5801	.2652
3	.1989	.2652	.2486	.663	.7293	.5967	.2486
4	.2155	.2652	.2652	.7293	.8619	.6464	.2486
5	.2652	.2652	.2984	.8619	.8619	.663	.3978
6	.3315	.3647	.3315	.8619	.9945	.663	.4641
7	.5636	.4973	.547	.9945	1.1934	1.0774	.5636
8	.5967	.5636	.547	1.1934	1.3592	1.442	.5304
9	.5636	.4973	.4973	1.2597	1.2763		.4973
10	1.3426	1.1271	1.1603	.4475	.431	.431	.9116
11	1.4586	1.1934	1.2597	.4475	.2321		1.2597
12	1.3923	1.1603	1.1934	.2652	.2818	.3315	1.1934
13	1.2266	1.1271	1.094	.3292	.2321	.2984	1.1271
14	1.1603		.9945	.2984	.2155	.2652	1.1271
15	1.1271	.8951	.9282	.3315	.2321	.2652	.9945
16	1.1271	.9282	.9945	.2984	.2155	.2652	.9945
17	1.094	.9945	.9945	.3048		.3315	.9945
18	.5304	.4973	.5304	.4807	.4641	.4641	.4973
19	.5967	.5304	.4973	.5596	.5304	.5636	.4973
20	.4973		.4973	.373	.4641	.4973	.4641
21		.3978	.3978	.3222	.3812	.431	.3978
22		.2652	.3315	.2713	.3315		.3353
23		.2652	.2652	.2652	.2652	.2984	.2652
24	.2652	.3315	.2652	.7956	.7956	.5967	.2652
Max	1.4586	1.1934	1.2597	1.2597	1.3592	1.442	1.2597
Min	.1989	.2652	.2486	.2652	.2155	.2652	.2486
Avg	.7143	.5922	.6112	.5755	.6018	.5383	.6169

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344010 / 33 KV MAGALURPIR SUB STATION

Feeder No / Name : 205 / INDUSTRIAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7							.0995
8			.1029		.1357	.0754	.1509
9	.3734	.0754	.1886	.2561	.1227	.3361	.3018
10	.3772	.1132	.1509	.3258	.2534	.3018	.3018
11	.3395	.064	.2263	.2035	.2328	.3772	.2987
12	.3395	.0633	.2263	.1966	.1509	.3734	.181
13	.3772	.0465	.2263		.0754	.3772	.2263
14	.3772		.2263	.2149	.2218	.1109	.2641
15	.3772		.2263	.1463	.1991	.1052	.2263
16	.3772		.1829	.1638	.1848	.3018	.2263
17	.3395		.1463	.1638		.1848	.2218
18	.3018		.1509	.1677	.2195	.1478	.1257
19	.1132		.1524	.1677	.2641	.1463	.1524
20	.1132		.1509	.1006	.0198	.0869	.1509
21		.0754		.1341			
22				.1174			
Max	.3772	.1132	.2263	.3258	.2641	.3772	.3018
Min	.1132	.0465	.1029	.1006	.0198	.0754	.0995
Avg	.3172	.0730	.1813	.1814	.1733	.2250	.2091

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344010 / 33 KV MAGALURPIR SUB STATION

Feeder No / Name : 206 / 11kv gavthan feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5281	.543	.6224	.439	.439	.4938	.5068
2	.547	.5068	.5601	.4207	.439	.499	.5068
3	.547	.5068	.5658	.4557	.4557	.5228	.4887
4	.5658	.6584	.6161	.4607	.4508	.5281	.5544
5	.7167		.7468	.6219	.6219	.6722	.7023
6	.8865		.9431	.7023	.695	.8488	1.0082
7	1.1949		1.1128	1.0751	1.0534		1.1576
8	1.1283		1.1389	1.1016	1.0517		
9	1.1643	.4024	1.0288	1.0269			1.1458
10	1.0534	.9979	.8745	.8871	.8326		.9511
11	.6401	.6099	.8048	.7682	.6447	.7392	.8145
12	.7602	.6099	.7316	.6036	.6219	.6516	.7087
13	.5973	.5359	.6584	.567	.631	.6335	.5731
14	.6201		.5853	.5801	.7023	.591	.5373
15	.6556		.5973	.5853	.6201	.5731	.6516
16	.7602	.8413	.724	.6401	.6154	.7087	.6161
17	.8688	.8869	.8145	.7316		.4801	.443
18		.9511	.9511	.9979	.9979	.6984	1.0242
19	.9896	.8764	1.0164	.9425	1.0349	1.0974	1.0534
20	.8775		.8402	.8215	.8589	.9145	.8402
21		.7655	.7842	.7095	.695	.7682	.7095
22		.6161	.6348	.6036	.6413		.6161
23		.547	.5415	.547	.5281	.5544	.5601
24	.5281	.5544	.679	.5281	1.1694	.5121	.5487
Max	1.1949	.9979	1.1389	1.1016	1.1694	1.0974	1.1576
Min	.5281	.4024	.5415	.4207	.439	.4801	.443
Avg	.7815	.6712	.7739	.7007	.7182	.6572	.7269

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344011 / 33/11 KV SHIVANI ROAD SUB

STAT

Feeder No / Name : 201 / GHOTA GAVTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1219	.0762	.1219	.1219	.0914	
2	.1524	.1219	.0762	.1219	.1219	.0914	.1524
3	.1524	.1219	.0762	.1524	.1219	.0914	.1524
4	.1524	.1219	.0762	.1524	.1219	.0914	.1524
5	.1524	.1219	.0762	.1829	.1219	.0914	.1524
6	.1524	.1219	.1524	.1829	.1219	.1219	.1829
7	.1524	.1219	.1829	.1981	.1219	.1829	.1829
8	.1524	.1219	.1829	.1981	.1219	.1829	.2134
9	.1524	.1219	.1524	.1677	.1219	.1829	.2134
10	.1524	.1219	.1524	.1677	.1219	.1524	.1829
11	.1524	.1219	.1524	.1677	.1219	.1219	
12	.1619	.0914	.1067	.0168	.0914	.0762	.0762
13	.1619	.0762	.1067	.1829	.0914	.0762	.0762
14	.1619	.1372	.0914	.3048	.0914	.0762	.0762
15	.1619	.061	.0914	.3048	.0914	.0762	.1219
16	.1619	.1219	.0914	.1524	.0914	.0762	.1219
17	.1296	.1524	.1372	.061	.1219	.1372	.1219
18	.1219	.1524	.1372	.061	.1829	.1829	.1219
19	.1219	.1829	.1372	.061	.1829	.2134	.1219
20	.3048	.1829	.1372	.061	.1524	.2134	.1219
21	.1219	.1219	.1372	.061	.1219	.1829	.1524
22	.1219	.0914	.1219	.1219	.1219	.1829	.1524
23	.1219	.0762	.1219		.0914	.1524	.1524
24	.1524	.1219	.0762	.1219	.1219	.0914	.1524
Max	.3048	.1829	.1829	.3048	.1829	.2134	.2134
Min	.1219	.061	.0762	.0168	.0914	.0762	.0762
Avg	.1534	.1213	.1188	.1445	.1206	.1308	.1434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344011 / 33/11 KV SHIVANI ROAD SUB

STAT

Feeder No / Name : 203 / DHAMANI AG FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.0972	.0972	.1296	
3				.1296	.0972	.1296	
4				.1619	.1296	.1296	
5				.1619	.1296	.1296	
6				.1619	.1296	.1619	
7				.1781	.1296	.1943	
8				.1781	.2591	.2105	
9				.1781	.2591	.2267	
10	.2591	.1296	.1619				.1943
11	.2105	.2105	.1619				.2267
12	.2105	.1943	.1943				.2267
13	.2172	.1943	.1943				.2267
14	.1943	.1619	.1781				.2267
15	.1943	.1296	.1781				
16	.1341	.1296	.1619				
17	.1296	.0972	.1296				
Max	.2591	.2105	.1943	.1781	.2591	.2267	.2267
Min	.1296	.0972	.1296	.0972	.0972	.1296	.1943
Avg	.1937	.1559	.1700	.1559	.1539	.1640	.2202

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344011 / 33/11 KV SHIVANI ROAD SUB

STAT

Feeder No / Name : 204 / PARWA GAVTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.181	.1086	.0905	.0905	.1086	.0905
2	.181	.181	.1086	.0905	.0905	.1086	.0905
3	.181	.181	.1086	.0905	.0905	.1086	.1267
4	.181	.181	.1086	.1448	.0724	.1086	.1267
5	.181	.181	.1086	.1448	.0905	.1448	.1267
6	.1991	.181	.1448	.1629	.0724	.1086	.1448
7	.1991	.181	.1448	.1629	.0724	.1086	.181
8	.1991	.181	.181	.1629	.0991	.1629	.181
9	.181	.181	.2172	.181	.1448	.1629	.181
10	.181	.181	.181	.181	.1448	.1448	.2353
11	.1629	.1086	.1629	.1991	.1448	.181	.2172
12	.1629	.1448	.1629	.181	.1448	.0905	.0905
13	.1086	.1448	.1629	.181	.1448	.0905	.0905
14	.1086	.1267	.1448	.181	.1086	.0905	.0905
15	.1086	.1267	.1448	.1448	.1086	.0905	.0905
16	.1448	.1448	.1448	.1448	.1448	.1267	.1448
17	.1448	.181	.1448	.1448	.1448	.1629	.1448
18	.1448	.181	.0905	.1448	.1991	.1991	.1448
19	.1448	.181	.0905	.1448	.1629	.1448	
20	.1448	.181	.0905	.1448	.1629	.1267	.1448
21	.1448	.1448	.0905	.0905	.1448	.1086	.1448
22	.181	.1448	.0905	.0905	.1448	.1086	.1448
23	.181	.1086	.0905	.0905	.1448		.181
24	.181	.181	.1086	.0905	.0905	.1086	.0905
Max	.1991	.181	.2172	.1991	.1991	.1991	.2353
Min	.1086	.1086	.0905	.0905	.0724	.0905	.0905
Avg	.1637	.1629	.1305	.1410	.1233	.1259	.1393

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344012 / 33/11 KV ASEGAON SUB-STATION

Feeder No / Name : 201 / dhanora

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1787	.192	.208	.2401	.1659	.2332	.1006
2	.1787	.192	.208	.2267	.1684	.2134	.1257
3	.1787		.208	.2397	.1734	.2073	.1257
4	.2073	.2023	.2378	.2572	.2058	.2332	.1787
5		.221	.2896	.282	.2961	.2263	.2263
10		.3841	.4329	.434	.2789	.2557	.3772
11		.2477	.3071	.3772	.2789	.1829	.317
12		.2477	.2743	.3307	.2324	.1654	.2515
13		.2058	.2263	.2023	.2058	.1768	.1829
14		.192	.2305	.189	.1814	.1852	.1768
15	.4733	.2096	.2498	.2195	.2092	.2248	.2023
16	.3978	.2431	.3487	.3018	.2362	.2724	.221
17	.4649	.3094	.2972	.2804	.3201	.3064	.2873
18	.4851						
19	.4085						
20	.3121	.3616	.3155	.3064	.3517	.2683	.2778
21	.2835	.3201	.285	.2601	.2667	.2439	.2347
22	.2401	.2667	.2591	.192	.2591	.1509	.1989
23	.216	.2027	.2629	.1829	.2332	.1257	.1585
24	.2042	.1951	.208	.2332	.176	.2298	.1006
Max	.4851	.3841	.4329	.434	.3517	.3064	.3772
Min	.1787	.192	.208	.1829	.1659	.1257	.1006
Avg	.3021	.2466	.2694	.2642	.2355	.2168	.2080

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344012 / 33/11 KV ASEGAON SUB-STATION

Feeder No / Name : 202 / Wara

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5114	.503	.4923	.3307	.4527	.3071	.3574
2	.503	.5197	.4851	.3536	.4595	.3544	.3628
3	.503	.5281	.4851	.3521	.4723	.4527	.3887
4	.567	.567	.5361	.4146	.5312	.5155	.447
5		.6142	.6219	.5258	.5959	.6478	.5068
10		.6859	.7796	.7183	.562	.7322	.7602
11		.6299	.6299	.6401	.562	.6043	.6935
12		.5304	.6401	.6188	.5716	.5441	.5487
13		.6828	.6497	.5658	.5716	.5239	.5396
14		.6828	.5449	.5548	.4847	.4645	.4954
15		.6602	.5973	.6081	.4778	.4755	.535
16		.7682	.7082	.7194	.6859	.5647	.7682
17	1.1888	.7255	.8459	.8032	.7545	.7087	.7205
18	1.1283						
19	.9214						
20	.8162	.6962	.6935	.6866	.7659	.503	.7021
21	.7324	.6584	.5853	.6036	.6287	.4877	.6192
22	.6722	.5365	.4725	.5243	.4778	.4146	.5121
23	.5811	.503	.3487	.5201	.3658	.3772	.4458
24	.5114	.5258	.4923	.3429	.4954	.3658	.3521
Max	1.1888	.7682	.8459	.8032	.7659	.7322	.7682
Min	.503	.503	.3487	.3307	.3658	.3071	.3521
Avg	.7197	.6121	.5894	.5490	.5509	.5024	.5420

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344012 / 33/11 KV ASEGAON SUB-STATION

Feeder No / Name : 203 / shegi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2538	.2469	.2134	.2134	.2134	.2561	.2134
2	.2538	.25	.2134	.2187	.2134	.2241	.2107
3	.2606	.2591	.2134	.2343	.2107	.2267	.208
4	.2896	.2709	.2134	.25	.2896	.2561	.2027
5		.2896	.2286	.2469		.25	.2172
10		.3048	.2401	.2743	.2256	.3018	.2606
11		.3384	.2201	.2429	.2256	.2267	.2538
12		.3018	.1882	.208	.2503	.2281	.2134
13		.2591	.1692	.0701	.282	.2008	.1814
14		.2515	.1623	.1276	.1867	.1829	.1463
15	.282	.2683	.1623	.1659	.3467	.1915	.1509
16	.3447	.2766	.2469	.217	.4268	.2267	.2134
17	.4001	.2766	.282	.2841	.3109	.2429	.2538
18	.4778						
19	.4214						
20	.3913	.2667	.3353	.3161	.3353	.2801	.3005
21	.3418	.2667	.3125	.2972	.3048	.2824	.2591
22	.301	.2134	.2812	.2494	.3048	.2439	.2258
23	.2743	.1867	.2439	.2378	.25	.2439	.2134
24	.2538	.2439	.2214	.2439	.2258	.25	.2134
Max	.4778	.3384	.3353	.3161	.4268	.3018	.3005
Min	.2538	.1867	.1623	.0701	.1867	.1829	.1463
Avg	.3247	.2651	.2304	.2276	.2707	.2397	.2188

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344013 / 33/11 KV SHELU BAZAR SUB

STATI

Feeder No / Name : 202 / tarala-ag feeder

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1052	.1052	.1063	
2				.1052	.1052	.1063	
3				.1402	.1402	.1417	
4				.1402	.1402	.1772	
5				.1052	.2454	.2481	
6				.1417	.2454	.2835	
7				.2126	.2454	.2835	
8				.3898	.4557	.3189	
9				.3856	.4557	.3544	
10	.1372	.2804	.3506				
11	.4207	.3506	.3506				.4557
12	.3155	.3121	.3155				.3467
13	.2804	.208	.2774				.3155
14	.2454	.208	.2774				.2774
15	.2804	.1734	.3121				.3121
16	.2804	.3155	.2774				.3121
17	.2454	.2481	.2774				.2804
24				.0709	.0693		
Max	.4207	.3506	.3506	.3898	.4557	.3544	.4557
Min	.1372	.1734	.2774	.0709	.0693	.1063	.2774
Avg	.2757	.2620	.3048	.1797	.2208	.2244	.3286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344013 / 33/11 KV SHELU BAZAR SUB

STATI

Feeder No / Name : 204 / 11kv kanzara gavthan

GAOTHAN FEEDER

feeder Feeder KV- 11 /
OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1595	.1928	.1595	.1595	.1578	.1595	.1772
2		.1928	.1595	.1772	.1578	.1595	.1772
3	.1772	.0876	.1417	.1595	.1753	.1772	.1949
4	.1949	.0876	.1417	.3189	.1753	.1772	.1949
11	.3506	.1928	.3856	.3681	.3155	.3155	.3155
12	.3772	.1734	.2629	.4031	.298	.298	.3121
13	.3258	.1734	.2774	.3294	.2454	.2629	.2601
14	.2947	.1734	.2427	.2774	.2103	.2279	.2279
15	.3155	.156	.2601	.2774	.2454	.1753	.2427
16	.2804	.2279	.2774	.1907	.2454	.2481	.2629
17	.3086	.1772	.208	.208	.2103	.2481	.2804
18	.2279	.1772	.2454	.2279	.298	.2658	.3121
19	.2947	.1949	.2279	.2427	.3012	.2743	.2601
20	.2601	.1949	.2279	.2454	.3012	.2126	.2774
21	.2103	.1772	.2103	.1928	.2835	.1949	.2454
22	.2279	.1772	.1928	.1753	.2835	.2126	.1928
23	.2279	.1772	.1753	.1402	.1595	.1772	.1928
24	.1772	.1595		.1753	.1595		.1595
Max	.3772	.2279	.3856	.4031	.3155	.3155	.3155
Min	.1595	.0876	.1417	.1402	.1578	.1595	.1595
Avg	.2594	.1718	.2233	.2372	.2346	.2227	.2381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344013 / 33/11 KV SHELU BAZAR SUB

STATI

Feeder No / Name : 205 / 11kv Tarhala Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 /
OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.567	.631	.6733	.6379	.5609	.567	.567
2	.5316	.631	.7087	.6733	.5258	.6024	.5959
3	.5316	.6661	.6733	.7087	.5258	.6024	.631
4	.4961	.6661	.7087	.7087	.5609	.6024	.631
11	1.2971	1.7878	1.858	1.893	1.7528	1.5424	1.6126
12	1.7833	1.7684	1.9071	1.5775	1.7878	1.4022	1.4563
13	1.5775	1.5604	1.6817	1.4723	1.2971	1.2269	1.3176
14	1.5074	1.387	1.387	1.2971	1.2971	1.1568	1.2136
15	1.3523	1.387	1.387	1.1919	1.1919	.8764	1.1789
16	1.3672	1.4022	1.2136	1.2269	1.1218	1.0867	1.2136
17	1.3672	1.382	1.2483	1.2269	1.1568	1.2048	1.2136
18	1.4373	1.4175	1.262	1.1568	1.2269	1.0631	1.3176
19	1.2269	.1205	1.1919	1.0867	1.134	1.134	1.0749
20	.9362	.9922	1.0867	.9114	1.0277	1.0631	.9816
21	.7712	.8859	.8764	.8764	.8859	1.0277	.8413
22	.7011	.8505	.8413	.7011	.6733	.815	.7011
23	.7011	.7442	.631	.5959	.567	.6379	.631
24	.567	.6733		.6024	.567		
Max	1.7833	1.7878	1.9071	1.893	1.7878	1.5424	1.6126
Min	.4961	.1205	.631	.5959	.5258	.567	.567
Avg	1.0400	1.0530	1.1374	1.0303	.9923	.9771	1.0105

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344013 / 33/11 KV SHELU BAZAR SUB

STATI

Feeder No / Name : 206 / 11kv Hirangi ww Feeder

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0177	.0343	.0177	.0354	.0175	.0177	.0351
2	.0354	.0175	.0177	.0177	.0351	.0177	.0175
3		.0351	.0354	.0354	.0351	.0177	.0351
4	.0354	.0175	.0177	.0177	.0351	.0177	.0351
5	.0177	.0351	.0354	.0354	.0175	.0354	.0175
6	.0354	.0175	.0177	.0177	.0351	.0177	.0175
7	.0177	.0351	.0177	.0354	.0175	.0177	.0351
8	.0354	.0175	.0354	.0177	.0175	.0177	
9	.0354	.0175	.0709		.0351	.0354	.0351
10	.0177	.0351	.0709	.0351	.0351	.0175	.0701
11	.0351	.052	.1753	.0351	.0347	.0175	.1052
12	.0347	.052	.208	.2103	.0351	.0351	.0347
13	.052	.0693	.1734	.1928	.2103	.0175	.0351
14	.1753	.0693	.2427	.1387	.1753	.0175	.0175
15	.0701	.052	.208	.2103	.1052	.0351	.0351
16	.0701	.0701	.1734		.2103	.0175	.0173
17	.0351	.1063	.104		.0876		.0351
18	.0173	.0532	.0701	.0351	.0175		.0173
19	.0351	.0177	.0351	.0351	.0177	.0354	.0175
20	.0173	.0177		.0175	.0177		.0351
21	.0351	.0177	.0351	.0351	.0177	.0354	.0351
22	.0175	.0354		.0175	.0354		.0175
23	.0351	.0177	.0175	.0175	.0177	.0354	.0351
24	.0354	.0354		.0177	.0177		.0175
Max	.1753	.1063	.2427	.2103	.2103	.0354	.1052
Min	.0173	.0175	.0175	.0175	.0175	.0175	.0173
Avg	.0397	.0387	.0847	.0576	.0534	.0241	.0327

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344013 / 33/11 KV SHELU BAZAR SUB

STATI

Feeder No / Name : 207 / Shelu AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6733	.9114	.8859	.7087	.7712	.7796	.5959
2	.7087	.8764	.8505	.8859	.8413	.815	.631
3	.815	.8764	.8505	1.0277	.9816	1.0277	.6661
4	.8505	.8764	.8505	1.0985	1.0517	1.134	.7712
5				.6379	.5609	.567	
6				.5316	.5258	.6024	
7				.4961	.4557	.6733	
8				.6024	.1402	.6024	
9					.7362	.6024	
10		.5959	.7011				
11	2.6642	2.524	2.6353	1.7878	1.7878	1.8229	2.4539
12	2.5591	2.4619	2.4966	1.6297	1.7528	1.7528	2.2192
13	2.3232	2.1152		1.5424	1.6126	1.6476	2.1845
14	2.0683	2.0805	2.0111	1.4373	1.4022	1.4022	1.858
15	1.9631	2.0111	1.9071	1.4373	1.3321	1.3321	1.8229
16	2.1033	2.0332	1.7684		1.4022	1.2269	1.7528
17	2.0683	1.949	1.7337		1.4022		1.8229
18	1.6126	1.4529	1.4022	2.0111	1.5424	1.3466	1.4723
19	1.5424	1.4883	1.3321	1.7337	1.4175	1.382	1.3523
20	1.4022	1.1694	1.1393	1.262	1.2757	1.2403	1.1568
21	1.1218	1.0631	.9816	1.262	.9214	1.134	.964
22	.9362	.9568	.8413	.9114	.7442	.9568	
23	.9114	.9568	.6661	.7362	.6733	.6733	.6661
24	.7087	.8859		.631	.7087		
Max	2.6642	2.524	2.6353	2.0111	1.7878	1.8229	2.4539
Min	.6733	.5959	.6661	.4961	.1402	.567	.5959
Avg	1.5018	1.4360	1.3561	1.1185	1.0452	1.0820	1.3994

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344034 / 33/11 KV DASTAPUR SUB

STATION

Feeder No / Name : 201 / 11 KV DASTAPUR FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.3601	.3086	.333	.3521	.2949	.3814
2	.463	.3353	.3086	.3294	.3521	.3018	.3772
3	.463	.373	.3086	.3814	.3521	.2915	.3641
4	.4681	.3812	.3086	.4031	.3688	.2743	.3944
5		.407	.3561	.4334	.4359	.3052	.4115
10		.4694	.5316	.6104	.4915	.547	.5967
11		.4239	.4862	.5316	.4915	.4694	.5365
12	.4586	.4458	.4588	.4973	.4239	.4578	.5079
13	.4902	.4681	.4527	.5316	.4527	.463	.4588
14	.4801	.4801	.3768	.5144	.4458	.4508	.4096
15	.5376	.4681	.4024	.4801	.4641	.4287	.4096
16	.5121	.463	.426	.5487	.4752	.463	.426
17	.5596	.4973	.5533	.583	.503	.5256	.4588
18	.6516						
19	.5868						
20	.547	.5316	.6001	.583	.5596	.5658	.502
21	1.5089	.4458	.4973	.5144	.4862	.5596	.4696
22	.4748	.3772	.4334	.4115	.4475	.4508	.3887
23	.3944	.3506	.3856	.3601	.3772	.3772	.3563
24	.5201	.3856	.3086	.3294	.3601	.3506	.3772
Max	1.5089	.5316	.6001	.6104	.5596	.5658	.5967
Min	.3944	.3353	.3086	.3294	.3521	.2743	.3563
Avg	.5645	.4257	.4169	.4653	.4355	.4209	.4348

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344034 / 33/11 KV DASTAPUR SUB

STATION

Feeder No / Name : 202 / 11 KV KASOLA FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801			.4334	.3052		.3429
2	.4973			.4031	.3052		.3258
3	.4973			.3988	.3052		.3258
4	.5316			.4908	.3391		.3772
5				.5316	.4239		.4458
10					.4748		.5407
11		.463					.431
12		.3681				.3772	.373
13		.3772		.4239		.3772	.3561
14		.3944		.407		.3988	.3391
15		.4161		.373		.4115	.373
16		.3601		.39			.407
17				.4578		.5316	.39
20			.5316	.5256		.57	.5426
21			.5658	.4409		.4748	.4578
22			.4681	.3561		.3561	.373
23			.4031	.3052		.3086	.3391
24	.4681			.4031	.3052		.3086
Max	.5316	.463	.5658	.5316	.4748	.57	.5426
Min	.4681	.3601	.4031	.3052	.3052	.3086	.3086
Avg	.4949	.3965	.4922	.4227	.3512	.4229	.3916

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344034 / 33/11 KV DASTAPUR SUB

STATION

Feeder No / Name : 203 / 11 KV DAM FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0351	.0343	.0328	
2				.0347	.0343	.0335	
3				.0347	.0343	.0335	
4				.0351	.0343	.0497	
5				.0526	.0343	.0503	
6				.0526	.0514	.0492	
7				.052	.0857	.0671	
8				.052	.1715	.1029	
9				.0686	.1715	.116	
10	.1406	.1715	.1052				.1029
11	.1718	.1734	.1326				.1029
12	.1562	.156	.1526				.1029
13	.1562	.1357	.12				.1372
14	.1562	.12	.1658				.1029
15	.1562	.0867	.1844				.12
16	.144	.0867	.1886				.12
17	.1341	.0686	.1509				.1029
24				.0351	.0343	.0343	
Max	.1718	.1734	.1886	.0686	.1715	.116	.1372
Min	.1341	.0686	.1052	.0347	.0343	.0328	.1029
Avg	.1519	.1248	.1500	.0453	.0686	.0569	.1115

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANORA DN.[552]

BU 1554

Substation No/ Name :- 344015 / 33 KV MANORA

Feeder No / Name : 201 / 11 kv amgavan feeder

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3277	.3277	.394	.3277		.2572
2	.3429	.2984	.3315	.394	.2949	.2984	.2058
3	.3429	.2984	.3315	.394	.2984	3.0333	.2058
4	.3429	.2984		.394	.2984	.2984	.2058
5	.3772	.3315		.394	.4144	.3277	.2058
6	.4287	.4096		.4572	.4915	.4096	.2401
10	.8316	.6325	.9061	.7888	.8002	.6325	.3391
11	.7907	.7116	.9116	.7907	.7343	.7545	.3479
12	.8223		.8288	.8697	.7499	.7545	.3437
13	.703	.6097	.7202	.7907	.6325	.6478	.3353
14	.6401	.7164	.7202	.7253	.5851	.5668	.3163
15		.7343	.6478	.703	.5851	.5668	.2286
16	.6859	.7499	.6478	.703	.6249		.3048
17	.6325	.7116		.6642	.578		.4572
18	.5668	.6325	.5735	.6401	.5601		.5535
19	.5182	.5601	.4915	.5601	.5121		.5601
20	.4858	.4801	.4915	.4858	.4858	.3429	.4858
21	.4096	.4321	.4477	.4372	.4424	.3086	.4372
22	.3768	.4096	.4477	.4049	.4096	.2572	.4096
23	.3605	.4096	.4477	.4096	.3605	.2572	.4096
24	.3429	.3277	.3605	.394	.3768	.3277	.2572
Max	.8316	.7499	.9116	.8697	.8002	3.0333	.5601
Min	.3429	.2984	.3277	.394	.2949	.2572	.2058
Avg	.5172	.5041	.5667	.5616	.5030	.6115	.3384

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANORA DN.[552]

BU 1554

Substation No/ Name :- 344015 / 33 KV MANORA

Feeder No / Name : 202 / 11 KV GAWHA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2629	.1638	.1638	.2035	.1638	.1638	.2058
2	.2103	.1638	.1658	.2035	.1638	.1658	.2058
3	.2103	.1658	.1658	.2035	.1658	.1658	.2058
4	.2103	.1658	.1658	.2035	.1658	.1658	.2058
5	.2103	.1658	.1658	.2035	.1658	.1638	.2058
6	.2686	.1638	.1638	.2035	.1638	.1638	.3045
10	.5144	.6081	.506	.5487	.4801	.4744	.5868
11	.381	.4801	.4144	.4321	.3953	.4001	.3953
12	.3906	.2401	.8288	.3125	.3163	.4001	.3953
13	.3163	.2372	.3125	.2372	.2372	.3086	.381
14	.2372	.1898	.3125	.1875	.1898	.3086	.3163
15	.2343	.1898	.2515	.1898	.1898		.2286
16	.2286	.1898	.2515	.1898	.1898	.3086	.2286
17	.2721	.192		.2372	.1898	.3429	.2343
18	.3239	.2372	.2515	.2846	.2401	.3429	.3163
19	.3239	.2401	.2515	.2401	.2401	.2572	.3201
20	.2915	.2401	.2515	.1943	.2429	.2572	.2915
21	.2458	.1943	.2515	.1943	.2458	.2572	.2915
22	.1966	.1966	.2035	.1943	.1966	.2012	.2429
23	.1966	.1966	.2035	.1966	.1966	.2012	.1966
24	.3086	.1966	.1966	.2035	.1966	.1966	.2058
Max	.5144	.6081	.8288	.5487	.4801	.4744	.5868
Min	.1966	.1638	.1638	.1875	.1638	.1638	.1966
Avg	.2778	.2294	.2739	.2411	.2255	.2623	.2840

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANORA DN.[552]

BU 1554

Substation No/ Name :- 344015 / 33 KV MANORA

Feeder No / Name : 203 / 11 KV KONDOLI FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6468	.5735	.5735	.6224	.5735	.5243	.5533
2	.6468	.4915	.4973	.6224	.4915	.4973	.5533
3	.6468	.4973	.4973	.6224	.4973	.4973	.5533
4	.6468	.4973	.4973	.6224	.4973	.4973	.5533
5	.7095	.5801	.5801	.6224	.5801	.5735	.5533
6	.7095	.7373	.6554	.7468	.6554	.6554	.7468
10	1.2269	.6401	1.0155	1.2403	1.1203	1.0279	1.0867
11	.9602	1.0402	1.0174	1.0279	.9602	.8383	.7811
12	.8802	.8002	.9326	.9488	.7907	.7545	.7907
13	.7811	.7907	.8383	.8697	.7907	.6554	.759
14	.6859	.7907	.8383	.7811	.7907	.6554	.703
15	.703	.759	.8048	.7116	.7116	.6554	.6562
16	.7407	.7682	.8048	.6642	.6642	.6097	.759
17	.8002	.8697		.7907	.7907	.8059	.759
18	.9717	.9602	.7716	.9488	.8802	.8059	.759
19	.8192	.8097	.6859	.8802	.8002	.8059	.8002
20	.7773	.7287	.7202	.7773	.7287	.7164	.7287
21	.7287	.6722	.6859	.7287	.6554	.695	.6478
22	.6554	.6554	.6602	.6478	.6226	.6401	.6226
23	.6554	.6554	.6602	.6554	.5735	.6401	.5735
24	.7023	.6226	.6226	.6602	.6226	.5735	.547
Max	1.2269	1.0402	1.0174	1.2403	1.1203	1.0279	1.0867
Min	.6468	.4915	.4973	.6224	.4915	.4973	.547
Avg	.7664	.7114	.7180	.7710	.7046	.6726	.6898

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANORA DN.[552]

BU 1554

Substation No/ Name :- 344015 / 33 KV MANORA

Feeder No / Name : 204 / 11 kv Manora Town Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3277	.3277	.3658	.3277	.3277	.415
2	.3395	.3277	.3315	.3658	.3277	.2984	.415
3	.3395	.3315	.3315	.3658	.3315	.2984	.415
4	.3395	.3315	.3315	.3658	.3315	.2984	.415
5	.3772	.4973	.4915	.3658	.4973	.4915	.5658
6	.7545	.6554	.6554	.7167	.6554	.6226	.6602
9	.1886						
10	.3395	.7373	.8097	.9335	.7287	.8097	.9709
11	.6882	.7287	.7316	.7287	.6401	.695	.6325
12	.6226	.6226	.695	.6478	.6154	.695	.6478
13	.5535	.5735	.5792	.5668	.5668	.543	.6554
14	.4915	.4858	.5792	.4858	.4858	.543	.5735
15	.4915	.4915	.5316	.4858	.4858	.543	.4915
16	.4915	.4915	.5316	.4858	.4858	.543	.4858
17	.5668	.5668		.5668	.5668	.6535	.5668
18	.6554	.6478	.5487	.6401	.6554	.6535	.6478
19	.6554	.5735	.462	.6478	.6554	.6535	.6802
20	.2915	.4858	.462	.5735	.6226	.5601	.6554
21	.4858	.4372	.3696	.4915	.4915	.4715	.4915
22	.4096	.4096	.3696	.4096	.4096	.415	.4096
23	.4096	.4096	.3696	.4096	.4096	.415	.4096
24	.3772	.3605	.3605	.3696	.3605	.3605	.415
Max	.7545	.7373	.8097	.9335	.7287	.8097	.9709
Min	.1886	.3277	.3277	.3658	.3277	.2984	.4096
Avg	.4640	.4997	.4935	.5233	.5072	.5186	.5533

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANORA DN.[552]

BU 1554

Substation No/ Name :- 344015 / 33 KV MANORA

Feeder No / Name : 205 / 11kv manora industrial

feeder Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0328	.0328	.0943	.0328	.0332	.0377
2	.0943	.0332	.0332	.0943	.0328	.0332	.0377
3	.0943	.0332	.0332	.0943	.0332	.0332	.0377
4	.0943	.0332	.0332	.0943	.0332	.0332	.0377
5	.0943	.0332	.0328	.0943	.0332	.0328	.0377
6	.0943	.0328	.0328	.0943	.0328	.0328	.0377
7	.0943	.0332	.0328	.0943	.0328	.0328	.0943
8	.0943	.0819	.0819	.1886	.0819	.0819	.0943
9		.0829	.0819	.1886	.1147	.0819	.0943
10		.2458	.2915	.3395	.2429	.1638	.1886
11	.2949	.2458	.3206	.2915	.3563	.3395	.1147
12	.1966	.2458	.3206	.2915	.2915	.3395	.1134
13	.1638	.2915	.2263	.2915	.2915	.2829	.1147
14	.1638	.3239	.1886	.2915	.3239	.2829	.1638
15	.1147	.2949	.3206	.2429	.3239	.2829	.2458
16	.0819	.2458	.3206	.2458	.3563	.2829	.1619
17	.0819	.1619		.1638	.1638	.1886	.1619
18	.0819	.081	.1886	.081	.0819	.1886	.1296
19	.0819	.0819	.1886	.081	.0492	.0943	.0819
20	.0324	.0486	.1886	.0328	.0328	.0943	.0328
21	.0328	.0324	.1886	.0328	.0328	.0943	.0328
22	.0328	.0324	.0943	.0328	.0328	.0377	.0328
23	.0328	.0328	.0943	.0328	.0328	.0377	.0328
24	.0943	.0328	.0328	.0943	.0328	.0328	.0377
Max	.2949	.3239	.3206	.3395	.3563	.3395	.2458
Min	.0324	.0324	.0328	.0328	.0328	.0328	.0328
Avg	.1019	.1164	.1461	.1493	.1280	.1307	.0898

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANORA DN.[552]

BU 1554

Substation No/ Name :- 344016 / 33 KV POHARADEVI

Feeder No / Name : 201 / umari

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0633	.0633	.0671	
2				.0648	.0648	.0671	
3				.0633	.0648	.0671	
4				.064	.0633	.1006	
5				.096	.1265	.1006	
6				.1898	.1581	.1341	
7				.2846	.25	.2683	
8				.4321	.4877	.2012	
9				.3704	.4572	.2012	
10	.4374	.3048	.2683				.3353
11	.4999	.5365	.5182				.4999
12	.5937	.503	.6722				.6874
13		.6036	.6642				.6874
14	.6874	.6706	.4999				.6562
15	.6249	.4024	.4938				.6249
16	.4687	.4694	.4374				.3749
17	.4374	.4024	.3658				
24				.0633	.0633	.061	
Max	.6874	.6706	.6722	.4321	.4877	.2683	.6874
Min	.4374	.3048	.2683	.0633	.0633	.061	.3353
Avg	.5356	.4866	.4900	.1692	.1799	.1268	.5523

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANORA DN.[552]

BU 1554

Substation No/ Name :- 344016 / 33 KV POHARADEVI

Feeder No / Name : 203 / 11 kv s/stn wai

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0633	.0633	.2012	.1898	.1943	.1562	.0625
2	.0633	.0633	.2012	.192	.2591	.1875	.0625
3	.1265	.0633	.2347	.2561	.2561	.1875	.0937
4	.1265	.0949	.2683	.2561	.2561	.2187	.0937
5	.1898	.1898	.2683	.2915	.2846	.25	.125
6	.2214	.1898	.2683	.2881	.3201	.25	.125
7	.2846	.253	.3353	.3201	.3841	.4374	.1875
8	.4428	.4428	.6706	.4428	.4999	.4999	.3125
9	.5693	.506	.7545	.4999	.5556	.4999	.3749
10	.506	.4428	.3353	.3749	.25	.3125	
11	.5693	.6036	.5761	.6173	.3125	.3437	
12	.6642	.6706	.6958	.7811	.6249	.4374	
13		.7377	.6958	.9172		.5624	.4999
14	.6642	.8048	.6325	.8749	.5624	.5312	.5937
15	.6325	.7377	.6722	.8025	.4999		.6874
16	.4744	.6706	.5182	.6562	.6249	.4687	.6562
17	.4428	.6371	.4321	.506	.4374	.4374	.5624
24	.0633	.0633	.1677	.1296	.1296	.1562	.0625
Max	.6642	.8048	.7545	.9172	.6249	.5624	.6874
Min	.0633	.0633	.1677	.1296	.1296	.1562	.0625
Avg	.3591	.4019	.4405	.4665	.3795	.3492	.3000

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANORA DN.[552]

BU 1554

Substation No/ Name :- 344016 / 33 KV POHARADEVI

Feeder No / Name : 204 / COE ZP WAI EXP.

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1509	.1509	.1509	.1509	.1886	.1509
2	.1509	.1509	.1886	.1509	.1509	.1886	.1509
3	.1509	.1509	.1886	.1509	.1509	.1509	.1509
4	.1509	.1509	.1886	.1509	.1509	.1886	.1509
5	.1509	.1509	.1509	.1509	.1132	.1886	.1509
6	.1509	.1509	.1509	.1132	.1132	.1886	.1509
7	.1509	.1509	.1509	.1132	.1132	.1886	.1509
8	.1509	.1132	.1509	.1132	.1132	.1509	.1132
9	.1132	.0754	.1509	.1132	.0754	.1509	.1132
10	.1132	.0754		.0754	.0754	.1132	
11	.0377		.0377	.0377	.1132		.0377
12		.0754	.0377				
14					.0747		
18	.0754	.0754					
19	.1509		.0754	.0377	.0754	.0754	
20	.1509	.1132	.1509	.1509	.1132	.1509	
21	.1509	.1132	.1509	.1509	.1132	.1509	.1509
22	.1509	.1509	.1509	.1509	.1509	.1509	.1509
23	.1509	.1509	.1509	.1509	.1509	.1509	.1509
24	.1509	.1509	.1509	.1509	.1509	.1509	.1509
Max	.1509	.1509	.1886	.1509	.1509	.1886	.1509
Min	.0377	.0754	.0377	.0377	.0747	.0754	.0377
Avg	.1362	.1265	.1398	.1243	.1194	.1580	.1374

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANORA DN.[552]

BU 1554

Substation No/ Name :- 344016 / 33 KV POHARADEVI

Feeder No / Name : 205 / WAI GOATHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8402	.8215	.7468	.8962	.8962	.7468	.8589
2	.8215	.8589	.8215	.9709	.9522	.7842	.8589
3	.8402	.9335	.8962	.9896	.9896	.8962	.8962
4	.9709	1.0269	1.0269	1.1949	1.2136	1.1203	.9709
5	1.307	1.1949	1.1949	1.307	1.307	1.2136	1.251
9	1.9978	1.8858	2.0165	1.7177	1.9418	2.0538	2.0351
10	1.643	1.531	1.6991	1.6804	1.6244	1.8111	1.4937
11	1.1949	.9709	1.2136	1.2696	1.1576	1.2136	1.4937
12	.8402	.5228	.8775	.9896	.8589	.2427	.7468
13		.7095	.7468	.8029		.2427	.7468
14	.6348	.6161	.6908	.6908	.7842	.2427	.7842
15	.6161	.7468	.7468	.7095	.7095	.8029	.7842
16	.8962	.8962	.9335	.9709	.2987	.9335	.9709
17	1.1389	1.3443	1.4003	1.4563	1.3256	1.251	1.307
18	1.4563	1.7737	1.9605	1.8858	1.9044	1.475	1.531
19	1.531	1.8111	1.8298	1.8298	1.8671	1.531	1.531
20	1.2883	1.6804	1.4003	1.4377	1.4563	1.5497	1.5497
21	1.307	1.1203	1.1016	1.1389	1.1203	1.4003	1.531
22	1.1203	1.0269	.9896	.9896	.9709	1.1576	1.307
23	.8215		.9149	.9149	.8589	.8589	.8589
24	.8589	.8215	.7842	.8775	.8962	.8215	.8589
Max	1.9978	1.8858	2.0165	1.8858	1.9418	2.0538	2.0351
Min	.6161	.5228	.6908	.6908	.2987	.2427	.7468
Avg	1.1063	1.1147	1.1425	1.1772	1.1567	1.0642	1.1603

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANORA DN.[552]

BU 1554

Substation No/ Name :- 344017 / 33 KV DAPORA

Feeder No / Name : 201 / 11 kv DAPURA AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	.9602	1.0288	.1063			1.0288
2	.9431	.9602	1.0631	.1063			1.2003
3	.9431	.8916	1.1145	.1063			1.2174
4	.9431	.8916	1.1145	.1063			1.286
5	.9431	.8916	1.1145	.1063			1.286
6	1.2003	.8916	1.1145	.1063			1.0802
7	1.2003	1.0288	1.0974	.1063			1.0288
8	1.2003	1.0631	1.2689	.1063			1.1145
9	1.2003	1.1317	1.0631	.1063			1.1145
10				.1097	1.2003	1.2346	
11				.1166	1.2003	1.3717	
12				.1166	.2058	1.3717	
13			.1063	1.3717	1.2346	1.3032	.1115
14			.1063	1.3717		1.2003	.1115
15			.1063	1.3717		1.2689	.1115
16			.1063	1.3717			.1115
17			.1063	1.0631	1.2346	1.1317	
18			.1063				.1115
19			.1063				.1115
20			.1063				.1115
21			.1063				.1115
22			.1063				.1115
23			.1063				.1115
24	.9088	.9602	.823	.1063			
Max	1.2003	1.1317	1.2689	1.3717	1.2346	1.3717	1.286
Min	.9088	.8916	.1063	.1063	.2058	1.1317	.1115
Avg	1.0426	.9671	.5701	.4420	1.0151	1.2689	.6038

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANORA DN.[552]

BU 1554

Substation No/ Name :- 344017 / 33 KV DAPORA

Feeder No / Name : 203 / COE ZP MASNI EXP.

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.1029	.2058	.0206	.2058	.2058	.2058
2	.2058	.1029	.2058	.0206	.2058	.2058	.2058
3	.2058	.1029	.2058	.0206	.2058	.2058	.2058
4	.2058	.1029	.2058	.0206	.2058	.2058	.2058
5	.2058	.1029	.2058	.0206	.2058	.2058	.2058
6	.2058	.1029	.2058	.0206	.2058	.2058	.2058
7	.2058	.1029	.2058	.0206	.2058	.2058	.2401
8	.2058	.0343	.2058	.0206	.2058	.2058	.2058
9	.2058	.0343	.2058	.0206	.2058	.2058	.2058
10	.2058		.2058	.0206	.2058	.2058	.2058
11	.2058		.2058	.0206	.2058	.2401	.2058
12	.2058	.2058	.2058	.0206	.2058		.2058
13		.2058	.0206	.2058			.0171
14		.2058	.0206	.2058		.1372	.0103
15		.2058	.0206	.1029		.2058	.0103
16	.1029	.2058	.0206	.1029		.2058	.0206
17	.1029	.2058	.0206	.1029	.1029	.2058	.0206
18		.2058	.0206	.1029	.2058	.2058	.0206
19		.2058	.0206	.1029	.2058	.2058	
20		.1372	.0206	.1029	.2058	.2058	.0206
21		.1029	.0206	.2058	.2058	.2058	
22	.0857	.1029	.0103	.2058	.2058	.2058	.0103
23	.0857	.1543	.0206	.2058	.2058	.2058	.0171
24	.2058	.0857	.1543	.0206	.2058	.2058	.2058
Max	.2058	.2058	.2058	.2058	.2058	.2401	.2401
Min	.0857	.0343	.0103	.0206	.1029	.1372	.0103
Avg	.1796	.1372	.1183	.0798	.2007	.2042	.1299

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANORA DN.[552]

BU 1554

Substation No/ Name :- 344018 / 33 KV SAKHARDOH S/STN

Feeder No / Name : 201 / 11 kv s/stn sakhardoh
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829		.1768	.1303		
2	.1829	.1467	.2023	.1547		
3	.1951	.1494	.1799	.1257		
4	.1951	.1707	.1768	.1235		
5	.1951	.1738	.2058	.1257		
6	.1951	.1738	.2286	.1303		
7	.3734	.439	.3521	.216		
8	.5335	.5563	.5792	.3018		
9	.6036	.4599	.4664	.2808		
10				.3715	.4572	.3384
11				.4054	.5281	.4633
12				.3338	.439	.4572
13				.3567	.3734	.3201
14				.3201	.3734	.2477
15				.3109	.3155	.2972
16				.285	.3155	.3963
17				.1981	.2926	.2515
24	.1768	.1707	.1799	.1574		
Max	.6036	.5563	.5792	.4054	.5281	.4633
Min	.1768	.1467	.1768	.1235	.2926	.2477
Avg	.2834	.2711	.2748	.2404	.3868	.3465

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANORA DN.[552]

BU 1554

Substation No/ Name :- 344018 / 33 KV SAKHARDOH S/STN

Feeder No / Name : 202 / 11kv shendurjana

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2286	.1829	.1585
2		.0191		.2	.2256	.1235
3				.2286	.1867	.0854
4				.2286	.2195	.0869
5				.2	.16	.1303
6				.1715	.1692	.1326
7				.4287	.3064	.1326
8				.543	.3681	.2256
9				.4572	.3841	.2591
10	.3429	.3429	.3429			.3292
11	.5144	.5144	.4001			.4755
12	.4858	.4287	.4001			.5075
13	.4572	.4572	.4572			.5075
14	.4001	.4572	.4287			
15	.4001	.4001	.3715			.4512
16	.3715	.3715	.3715			.3666
17	.2858	.2858	.2572			.3384
24				.2286	.2561	.1555
Max	.5144	.5144	.4572	.543	.3841	.5075
Min	.2858	.0191	.2572	.1715	.16	.0854
Avg	.4072	.3641	.3787	.2915	.2459	.2627

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANORA DN.[552]

BU 1554

Substation No/ Name :- 344018 / 33 KV SAKHARDOH S/STN

Feeder No / Name : 203 / SAKHARDOH GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4161	.4458	.4115	.3814	.4161	.631	.5175
2	.4207	.4508	.4115	.4115	.4557	.567	.5914
3	.4207	.4748	.3814	.4115	.4115	.5731	.5975
4	.5014	.4458	.373	.4508		.6584	.9709
5	.5731	.4694	.4409	.4641	.4801	.6516	.9335
6	.9054	.823	.7377	.6962	.6935	.679	1.0349
7	.9054	.9724			.8916		1.0562
8		.8817			.9114		.4527
9		.7545			.8322		
10	.8962	.6783	.7628	.8573	.6443	.8962	.1989
11	.6653	.4748	.6783	.6241	.4694	.5487	.1417
12	.5121	.4115	.5201	.5373	.3506	.4161	.1417
13	.4706	.2774	.3429	.4207	.3506	.362	.1753
14	.3658	.2774	.4207	.4252	.2865	.1417	.3155
15	.5068	.3582	.3898	.3898	.4207	.1448	.439
16	.4435	.4435	.5014	.5068	.4207	.1463	.5228
17	.695	.6447	.6805	.788	.5792	.5853	.724
18	.9465	.9214	.9214	.9922	.9114	.8505	1.0136
19		.9114	.9114	.9015	.8322	.9313	1.0745
20	.7362	.7628	.7628	.7545	.6783	.7087	.8505
21	.5487	.6241	.583	.5895	.5487	.6653	.7087
22	.4854	.4908	.5201	.4854	.4854	.5175	.6447
23	.4908	.4557	.4557	.4607	.4207	.4435	.2172
24	.4161	.4557	.4161	.4115	.4207	.6241	.4481
Max	.9465	.9724	.9214	.9922	.9114	.9313	1.0745
Min	.3658	.2774	.3429	.3814	.2865	.1417	.1417
Avg	.5868	.5794	.5535	.5695	.5614	.5591	.5987

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANORA DN.[552]

BU 1554

Substation No/ Name :- 344031 / 33 KV SHENDURJANA

Feeder No / Name : 201 / SHENDURJANA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1715	.1715	.1905	.1334	.1524	.1715
2	.1905	.1524	.1715	.1905	.1143	.1524	.1715
3	.2096	.1524	.1715	.1905	.1334	.1524	.1715
4	.2286	.2096	.1905	.1905	.1715	.1715	.2096
5	.2477	.2477	.2477	.2096	.2286	.1905	.2286
9	.3048	.3429	.1905	.381	.381	.381	.362
10	.2477	.2667	.3048	.3048	.3239	.2667	.2477
11	.1524	.2096	.2096	.1905	.1905	.1715	.1524
12	.1334	.1524	.1524	.1905	.1524	.1524	.1715
13	.1334	.1524	.1143	.1143	.1524	.0953	.0953
14	.1143	.1334	.1143	.1334	.1524	.1334	.0953
15	.1524	.1334	.1334	.1334	.1715	.1715	.1334
16	.2096	.1905	.2286	.2286	.2477	.1715	.1715
17	.2667	.3429	.3239	.3048	.3048	.2667	.2286
18	.4572	.381	.4191	.4001	.381	.381	.381
19	.362	.362	.381	.362	.3429	.362	.362
20	.3048	.3048	.3048	.2667	.2667	.2858	.3048
21	.2477	.2286	.2477	.2477	.2096	.2096	.2286
22	.1905	.1905	.2286	.2096	.1715	.1905	.1905
23	.1905	.1715	.2096	.1715	.1524	.1715	.1715
24	.1905	.1715	.1715	.1905	.1334	.1524	.1715
Max	.4572	.381	.4191	.4001	.381	.381	.381
Min	.1143	.1334	.1143	.1143	.1143	.0953	.0953
Avg	.2250	.2223	.2232	.2286	.2150	.2087	.2105

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANORA DN.[552]

BU 1554

Substation No/ Name :- 344031 / 33 KV SHENDURJANA

Feeder No / Name : 202 / 11 KV PALODI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1143	.0762	
2				.0953	.0762	
3				.0762	.0762	
4				.1143	.0762	
5				.1524	.0953	
6				.1715	.1143	
7				.2096		
8				.1524	.362	
9				.2858	.1905	
10	.2858		.2667			.2286
11	.3048	.3239	.381			.3239
12	.3239	.3048	.4001			.2667
13	.362	.2286	.4382			.4001
14	.1143	.1905	.3429			.4191
15	.2096	.1524	.2667			.3239
16	.2286	.1715				.2477
17	.3429	.1334	.1715			.2667
24				.1143	.0762	
Max	.362	.3239	.4382	.2858	.362	.4191
Min	.1143	.1334	.1715	.0762	.0762	.2286
Avg	.2715	.2150	.3239	.1486	.1270	.3096

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANORA DN.[552]

BU 1554

Substation No/ Name :- 344031 / 33 KV SHENDURJANA

Feeder No / Name : 301 / 11KV INCOMMER SHENDURJANA

Feeder KV- 11 / INCOMING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2667	.2667	.3048	.3429	.3239	.2477
2	.2858	.2667	.2667	.3048	.3239	.3239	.2477
3	.3048	.2477	.2667	.3048	.3239	.3239	.3048
4	.362	.3429	.3048	.3048	.4191	.362	.362
5	.4001	.4191	.4001	.3429	.5335	.4382	.4001
6					.1715	.1143	
7					.2096		
8					.1524	.362	
9	.4572	.4954	.3239	.5716	.8383	.7621	.5525
10	.6668	.4001	.6859	.4382	.4572	.4191	.5906
11	.5335	.5906	.6668	.2667	.2477	.2477	.5335
12	.4763	.4954	.6097	.2286	.1905	.1905	.2096
13	.5335	.4191	.5906	.1524	.1905	.1334	.5335
14	.2667	.362	.4954	.1715	.1905	.1715	.5525
15	.381	.3239	.4572	.1715	.1715	.2286	.4954
16	.4763	.4382	.5525	.3048	.2477	.2477	.4763
17	.724	.5906	.6287	.4382	.4191	.381	.5906
18	.6478	.5335	.5906	.5906	.5335	.5716	.5716
19	.5144	.5335	.5525	.5144	.4954	.5335	.5144
20	.4382	.4382	.4382	.4001	.4001	.4382	.4572
21	.362	.3429	.362	.362	.3239	.3239	.3239
22	.3048	.2858	.3429	.3048	.2667	.2667	.2858
23	.3048	.2667	.3239	.2667	.2477	.2477	.2477
24	.2858	.2667	.2667	.3048	.3429	.3239	.2477
Max	.724	.5906	.6859	.5906	.8383	.7621	.5906
Min	.2667	.2477	.2667	.1524	.1524	.1143	.2096
Avg	.4291	.3965	.4473	.3357	.335	.3363	.4164

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANORA DN.[552]

BU 1554

Substation No/ Name :- 344031 / 33 KV SHENDURJANA

Feeder No / Name : 401 / 33KV INCOMMER SHENDURJANA

Feeder KV- 33 / INCOMING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2858	.2858	.2858	.3429	.3429	.743
2	.2858	.2858	.2858	.2858	.3429	.3429	.743
3	.2858	.2286	.2858	.2858	.3429	.3429	.2858
4	.3429	.3429	.2858	.2858	.4001	.3429	.3429
5	.4001	.4001	1.2003	.3429	.5144	.4572	.4001
6					.1715	.1143	
7					.2286		
8					.1715	.3429	
9	.4572	.5144	.3429	.5716	.8573	.743	.5716
10	.6859	.4001	.6859	.4572	.4572	.4001	.5716
11	.5144	.5716	.6859	.2858	.2286	.2286	.5144
12	.4572	.5144	.6287	.2286	.1715	.1715	.2286
13	.5144	.4001	.5716	.1715	.1715	.1143	.5144
14	.2858	.4001	.5144	.1715	.1715	.1715	.5716
15	.4001	.3429	.4572	.1715	.1715	.2286	.5144
16	.4572	.4572	.5716	.2286	.2286	.2286	.4572
17	.743	.5716	.6287	.4572	.4001	.4001	.5716
18	.6287	.5144	.5716	.5716	.5144	.5716	.5716
19	.5144	.5144	.5716	.5144	.5144	.5144	.5144
20	.4572	.4572	.4572	.4001	.4001	.4572	.4572
21	.3429	.3429	.3429	.3429	.3429	.3429	.3429
22	.2858	.2858	.3429	.2858	.2858	.2858	.2858
23	.2858	.2858	.3429	.2858	.2858	.2286	.2286
24	.2858	.2858	.2858	.2858	.3429	.3429	.2286
Max	.743	.5716	1.2003	.5716	.8573	.743	.743
Min	.2858	.2286	.2858	.1715	.1715	.1143	.2286
Avg	.4246	.4001	.4926	.3293	.3358	.3355	.4600

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANORA DN.[552]

BU 1554

Substation No/ Name :- 344054 / 33 KV GAVHA

Feeder No / Name : 201 / 11KV VITHOLI FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3052	.3222	.2883	.3052	.3052	.3222	.2883
2	.3052	.3052	.2883	.3052	.3052	.3052	.2883
3	.3052	.3052	.2883	.3052	.3052	.3052	.2883
4	.3052	.2883	.2883	.3391	.3052	.2883	.3561
5	.3391	.4239	.3391	.39	.3391	.373	.373
6	.407	.4748	.4409	.4239	.407	.4409	.4409
10	.78	.7122	.6783	.6783	.6783	.78	.7291
11	.7122	.6783	.6952	.5765	.5426	.6783	.6104
12	.6443	.78	.5935	.6104	.5765	.6783	.6104
13	.6783	.6443	.5256	.6104	.4748	.6274	.6104
14	.5765	.6274	.6274	.6104		.5765	.5426
15	.5087	.5935	.5596	.5426	.4748	.4748	.5426
16	.5765	.6104	.5765	.5087	.6104	.4748	.5087
17	.6783	.5765	.6104	.5087	.6443	.5256	.5426
18	.6613	.6783	.6443	.5765	.6443	.6274	.5765
19	.6104	.5765	.5087	.5426	.5426	.5596	.5087
20	.5087	.5087	.4578		.4748	.4917	.4409
21		.4239	.407	.407	.407	.407	.373
22	.373	.373	.373	.3391	.373	.3391	.3391
23		.3391	.3561	.3391	.3391	.3222	.3052
24	.3052	.2883	.2883	.3222	.3391	.3222	.3052
Max	.78	.78	.6952	.6783	.6783	.78	.7291
Min	.3052	.2883	.2883	.3052	.3052	.2883	.2883
Avg	.5042	.5014	.4683	.4621	.4544	.4724	.4562

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANORA DN.[552]

BU 1554

Substation No/ Name :- 344054 / 33 KV GAVHA

Feeder No / Name : 203 / 11KV GAWHA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3086	.2743	.2915	.3429	.3429	.3086
2	.3086	.3086	.2743	.2915	.3429	.3429	.2915
3	.3052	.2915	.2743	.2915	.3429	.3086	.2915
4	.3772	.3429	.2743	.3772	.3429	.3429	.3944
5	.4115	.4458	.3429	.4115	.3429	.4115	.3772
6	.5144	.5487	.4115	.4801	.4458	.4801	.4801
10	.7202	.6516	.7202	.7888	.7888	.583	.7373
11	.703	.6344	.6173	.6859	.6859	.583	.6516
12	.7888	.6516	.6687	.6859	.583	.5487	.5487
13	.7202	.7373	.6344	.5487	.583	.5487	.6173
14	.6516	.6344	.6001	.5487	.6173	.463	.6516
15	.6859	.583	.5487	.583	.5658	.4801	.5487
16	.6516	.6344	.6001	.6173	.5144	.4973	.583
17	.6687	.5658	.6001	.6173	.5487	.5316	.583
18	.6859	.6344	.6344	.583	.6859	.6516	.6173
19	.6344	.6001	.583	.5487	.6516	.5316	.5487
20	.5316	.5144	.463	.4801	.5487	.5144	.4801
21		.3772	.3944	.4115	.4458	.4287	.3429
22	.3772	.3429	.3601	.3772	.4115	.3429	.3086
23	.3429	.2915	.3052	.3429	.3772	.3258	.2743
24	.3429	.2572		.2915	.3429	.3429	.3086
Max	.7888	.7373	.7202	.7888	.7888	.6516	.7373
Min	.3052	.2572	.2743	.2915	.3429	.3086	.2743
Avg	.5365	.4932	.4791	.4883	.5005	.4572	.4736

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344005 / 33 KV MOP

Feeder No / Name : 201 / 11 KV LONI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2896	.2987	.2715	.2926	.2715	.2801	.2743
2	.2896	.2987	.2715	.2926	.2715	.2801	.2743
3	.2926	.2987	.3258	.3086	.2715	.2987	.3292
4	.3696	.2987	.3292	.3734	.3109	.4854	.3658
5	.5415	.5658	.5121	.5228	.5041	.8589	.5544
6	.8962	.8488	.7468	.7392	.8865	1.0242	.7842
7	1.0829	.9709	1.1128	1.0349	1.0642	1.1694	1.2136
8	1.1389	1.1389	1.1694	1.1088	1.0829	1.1317	1.0642
9	1.1576	1.0349	1.2012	1.0059	1.0082	1.086	.9335
10	.8145	.961	.9425	.8596	1.0974	.8686	.7842
11	.691	.8145	.6697	.8238	.8764	.6447	.6219
12	.5935	.724	.5434	.6379	.6706	.5144	
13	.5487	.6697	.5426	.5548	.503		.6173
14	.57	.6335	.4748	.503	.5138		.6516
15	.57	.6089	.5596	.5487	.503	.6133	.6859
16	.6241	.6401	.6379	.6516	.6001		.7362
17	.7973	.8507	.8059	.7619	.7011	.7973	.7964
18	.9335	.9425	.9593	.9511	.9877		.8871
19	.9149	.8775		.7842	.9709		.7842
20	.6348	.6283	.7023	.5914	.7023		.6348
21	.4854	.5121	.5175	.4755	.4805		.5121
22	.4108	.362	.4024	.3721	.3361	.5487	.3475
23	.3361	.2715	.3258	.2865	.3361	.3658	.2743
24	.3077	.2987	.2715	.3109	.2715	.3174	.2743
Max	1.1576	1.1389	1.2012	1.1088	1.0974	1.1694	1.2136
Min	.2896	.2715	.2715	.2865	.2715	.2801	.2743
Avg	.6371	.6479	.6215	.6163	.6342	.6638	.6261

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344005 / 33 KV MOP

Feeder No / Name : 202 / 11 KV BORKHEDI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1063	.1227	.1372	.1402	.1063	.1052	.0857
2	.1063	.1227	.1372	.1402	.1063	.1052	.0857
3	.1063	.1227	.1372		.124	.1227	.12
4	.1772	.1227	.1715	.1715	.1595		.1372
5	.2126	.3582	.2743	.2743	.2481	.2454	.2401
6	.2835	.4656	.4287	.4557	.4075	.4298	.3429
7	.4961	.6089	.6089	.7011	.5138	.5609	.4656
8	.4784	.6805	.6805	.631	.6024	.5609	.5731
9	.5609	.6733	.6379	.5609	.6485	.567	.6447
10	.4287	.6379	.567	.5258	.5784	.4334	.5609
11	.3258	.4733	.4784	.4557	.5144	.3366	.3582
12	.3086	.4207	.4784	.4207	.4458	.3721	.3506
13		.4382	.443	.4207	.4115	.3721	.3506
14	.4287	.4382	.3721	.3582	.3258	.3012	.3544
15	.4458	.4557	.3012	.3506	.3429	.3189	.3155
16	.4458	.3856	.443	.3582	.3155	.3721	.3429
17	.4733	.4119	.5083	.5847	.4908	.5194	.3721
18	.5258	.4298	.6485	.6024	.5609	.591	.4607
19	.567	.4119	.567	.4252	.567	.4477	.4607
20	.3189	.3155	.3544	.2835	.4298	.3506	.3189
21	.2481	.2058	.2507	.2126	.2507	.5487	
22	.1753	.1715	.1772	.1595	.1772	.3429	.1417
23	.1402	.1372	.1402	.1417	.1402	.1715	.1063
24	.124	.1227	.1372	.1402	.124	.1402	.0857
Max	.567	.6805	.6805	.7011	.6485	.591	.6447
Min	.1063	.1227	.1372	.1402	.1063	.1052	.0857
Avg	.3254	.3639	.3783	.3702	.3580	.3615	.3163

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344005 / 33 KV MOP

Feeder No / Name : 203 / 11 KV RISOD FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3772	.547	.4801	.4694	.4801	.4144
2	.3429	.3772	.547	.4854	.4359	.4801	.4144
3	.3772	.3772	.5636	.4854	.4748	.4801	.4191
4	.4607	.3772	.6371	.5201	.5201	.5144	.4801
5	.5853	.6859	.7716	.7282	.7164	.6706	.5609
6	.8779	.9511	.8413	.9259	.905	.8478	.7522
7	.9412	1.2178	.9134	1.0288	.9774	.9511	1.0059
8	.8954	1.1462	1.0029	1.0517	1.0387	.9145	1.0029
9	1.0029	1.0517	.9313	.9465	1.1462	1.0985	.7522
10	.7888	.9816	.9362	.9114	.9882	.7975	.7011
11	.6718	.7545	.8048	.823	.9015	.6554	.5144
12	.8002	.6859	.8288	.7377	.7287	.583	.4428
13	.8322	.6588	.7537	.8048	.6642	.6154	.4374
14	.6478	.7628	.6554		.5624	.5441	.4374
15	.5506	.7802	.8192		.5535	.5506	.4801
16	.8029	.8669	.8383		.7045	.6882	.6036
17	.9431	1.0517	1.0056	1.0631	.7888	.788	.7282
18	.8916	.9991	1.0402	1.0402	.8383	.7186	.8859
19	.8413	.9214	.9114	.8505	.8916	.4477	.7442
20	.7202	.7888	.7011	.6935	.631	.5959	.5959
21	.6516	.703	.631	.583	.5609	.5895	.3814
22	.4908	.6001	.5609	.503	.4908	.503	.3688
23	.4115	.5533	.5144	.4641	.5144	.4191	.3353
24	.3772	.3772	.547	.5144	.4694	.5144	.4144
Max	1.0029	1.2178	1.0402	1.0631	1.1462	1.0985	1.0059
Min	.3429	.3772	.5144	.4641	.4359	.4191	.3353
Avg	.677	.7520	.7626	.7448	.7072	.6437	.5780

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344005 / 33 KV MOP

Feeder No / Name : 204 / 11 KV NEW RISOD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6733	.7164	.6733	.6733	.6089	.6447	.5731
2	.7087	.724	.6733	.6878	.6268	.6219	.5731
3	.7522	.7316	.7087	.724	.6516	.6584	.6089
4	.8326	.7316	.8596	.8688	.8316	.823	.7164
5	1.0791	1.2696	1.086	1.0745	1.2323	1.2323	1.0745
6	1.3535	1.4003	1.448	1.3969	1.6078	1.531	1.4327
7		1.5181	1.7375	1.7909	1.7193	1.6804	1.8088
8	1.6832	1.4998	1.5912	1.6301	1.828	1.6804	1.6832
9	1.5939	1.5729	1.7737	1.5415	1.8088	1.7013	1.5927
10	1.3321	1.5203	1.5927	1.4022	1.6834	1.5746	1.1946
11	1.2795	1.3611	1.4864	1.2971	1.3717	1.3146	
12	1.2003	1.2715	1.3003	1.2269	1.0059	1.1145	.9602
13	1.2517	1.2178	1.2174	1.2003	.7377	.9945	.8916
14	1.1145	1.1517	1.0682		.8886	.8916	.823
15	1.1145	1.1517	1.1317		.8817	.9259	.7545
16	1.2174	1.379	1.2795		.9362	1.0402	.8063
17	1.5238	1.6476	1.4529	1.8073	1.4175	1.382	1.5061
18	1.5043	1.8111	1.4175	1.9004	1.4685	1.5091	1.448
19	1.423	1.4998	1.3032	1.6278	1.4632	1.5729	1.3535
20	1.0974	1.3169	1.1827	1.2489	1.2197	1.2803	1.1584
21	1.0136	1.0136	.9979	.9313	.9979	.9145	.8869
22	.788	.7973	.8131	.691	.7392	.7164	.7087
23	.7164	.6733	.724	.6379	.724	.5731	.6805
24	.7087	.7164	.6733	.6733	.6089	.6805	.5552
Max	1.6832	1.8111	1.7737	1.9004	1.828	1.7013	1.8088
Min	.6733	.6733	.6733	.6379	.6089	.5731	.5552
Avg	1.1288	1.1956	1.1747	1.1920	1.1275	1.1274	1.0344

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344006 / 33 KV RITHAD

Feeder No / Name : 201 / 11 KV AASEGAON AGP FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.1271			
2				1.153			
3				1.0364			
4				1.0105			
5				.9877			
6				1.012		.3906	
7	1.5306	1.3696	1.4575	.9488	1.07	.9145	.8573
8	1.6941	1.5089	1.4575	1.0031	1.2654	1.0936	.8928
9	1.8892	1.5927	1.6133	1.2176	1.2003	.3906	.9596
10	1.9837	1.7457	1.7535	1.2037	1.1544		1.2193
11	2.0062	1.7535	1.6133	1.2498	1.3203		1.174
12	2.0319	1.6368	1.8513	1.3426	1.387	1.1145	1.2803
13	2.021	1.9662	1.9662	1.3108	1.2944	1.2346	1.2346
14	2.0119	1.8099	1.7482	1.2963	1.2342	1.2963	1.1736
15	1.0105		.9332	.945	1.0004	1.2018	.9214
16	.9659	.8833	.945	1.0185	1.0277	.9297	.8916
17	.9145	.7468	.8768	.9332	.9646		.8579
18	.8429	.7775	.8078	.8002	.8383	.8333	
19	.823		.7727	.787	.7526	.7316	.6836
20	.8078	.743	.787	.7002	.7042	.6836	.6859
21	.8025		.7188		.7164		.6554
22	.7827	.7133	.7316	.7562	.6958		.6636
23			1.2003		1.7236		
24				1.2309		1.6644	
Max	2.0319	1.9662	1.9662	1.3426	1.7236	1.6644	1.2803
Min	.7827	.7133	.7188	.7002	.6958	.3906	.6554
Avg	1.3824	1.3267	1.2491	1.0487	1.0794	.9599	.9434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344006 / 33 KV RITHAD

Feeder No / Name : 202 / 11 KV SAWARGAON AGP

FEEDER SEPERATION/PURE AG

FEEDER Feeder KV- 11 /
OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3375	1.174			1.6975		1.6137
2	1.3546	1.1443	.9739		1.6255		1.6766
3	1.3289	1.1288			1.6872		1.6796
4	1.3108	1.1883	1.0669		1.467		1.8061
5	1.1126	1.1431			1.4506		1.9966
6	1.028	1.0709	.8916	.1067	1.3375	.1429	1.9951
7	.4729	.463		.2258	.3429	.2029	.2782
8	.5868	.5335	.4458	.2934	.5556	.4515	.4161
9	.5182	.5647		.4816	.5201		.4572
10	.5868	.5944	.4534	.6097	.503		.4401
11	.5647	.5944	.5575	.6173	.4633		.4816
12	.6401	.6203	.6485	.6706	.6602	.7099	.6687
13	.743	.743	.6954	.6944	.6622	.639	.6097
14	.6173	.5716	.6706	.6706	.6344	.5937	.5268
15			1.9136	2.0062	1.7718	1.9456	1.752
16			1.8576	1.9204	1.7897	1.8061	1.7718
17			1.8964	1.813	1.6503	1.6347	1.7604
18			1.6272	1.7535	1.643	1.467	1.6941
19			1.5927	1.6137	1.5804	1.286	1.6766
20			1.5954	1.5844	1.5089	1.3375	1.5503
21			1.475		1.3937		1.5242
22			1.475	1.5546	1.3094		1.5242
23	1.2346						1.4449
24	1.3375	1.2041	1.0431		1.7071		1.6644
Max	1.3546	1.2041	1.9136	2.0062	1.7897	1.9456	1.9966
Min	.4729	.463	.4458	.1067	.3429	.1429	.2782
Avg	.9234	.8492	1.1600	1.0385	1.2157	1.0181	1.2920

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344006 / 33 KV RITHAD

Feeder No / Name : 203 / 11 KV SIRSALA AGP FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6				.1075			
7	.1981		.2401	.1718	.218	.2054	.2343
8				.208	.2458	.2328	.2343
9	.3185	.2721	.2606	.2515	.2439		.3109
10	.2561	.2743		.2462	.2317		.2591
11	.2915	.3185	.3125	.2526	.2949		.2241
12	.3772	.3906	.3521	.3201	.3353	.3185	.2667
13	.3932	.3086	.2972	.3281	.2972		.3277
14	.2804	.3041	.2115	.2591	.3041	.2622	.3086
15	1.0212						
16	1.0155	.9907					
17	.945	1.0322					
18	.8535	.9217					
19	.8383	.8322					
20	.8848	.8916					
21	.9431						
22	.823	.8124					
23	.823						
Max	1.0212	1.0322	.3521	.3281	.3353	.3185	.3277
Min	.1981	.2721	.2115	.1075	.218	.2054	.2241
Avg	.6414	.6124	.279	.2383	.2714	.2547	.2707

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344006 / 33 KV RITHAD

Feeder No / Name : 205 / SAWARGAON& SIRSALA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4967	.5053		.4458	.4458	.3763	.4167
2	.443	.5335	.503	.4115	.4475	.3763	
3	.5335	.5719		.4877	.4904	.4167	.4254
4	.9145	.7164	.6327	.7225	.7579	.7621	.7977
5	1.174	1.0385		.9536	1.0517	.2378	1.0385
6	1.4198	1.3056	1.3496	1.4043	1.3375	.2286	1.2323
7	1.6378	1.5546		1.5051	1.6198	.1543	1.3696
8	1.6091	1.5278	1.5895	1.3226	1.2037	.1355	1.3937
9	1.4175	1.2346		1.3395	1.0562	1.3413	1.2616
10	1.0364	1.0084	1.2193	1.0669	.8543		.8509
11	.828	.7579	1.0517	.679	.6455		.8069
12	.5719	.5247	.602	.503	.5401	.442	.4666
13	.4877	.3963	.463	.4321	.4515		.4268
14	.4607	.3437	.3763	1.0974	.381	.3161	.4167
15	.503		.3048	.3395	.3269	.431	.4214
16	.6249	.5944	.6687	.4877	.5792	.4725	.5135
17	.9297	.9907	.9783	.8025	.8642	.888	.8025
18	1.2186	1.2944	1.2346	1.2041	1.2631	1.2643	1.2483
19	1.2176	1.2803	1.2631	1.2643	1.0536	1.2334	1.3717
20	.9659	.9214	.9907		1.0648	1.0269	1.0536
21	.7926		.8278		.8173		.8278
22	.6093	.6321	.7225	.5944	.5268		.5944
23	.5268		.5792		.5401		.5335
24	.5117	.5117	.4877	.4515	.4458	.4115	.442
Max	1.6378	1.5546	1.5895	1.5051	1.6198	1.3413	1.3937
Min	.443	.3437	.3048	.3395	.3269	.1355	.4167
Avg	.8721	.8688	.8339	.8340	.7819	.5841	.8136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344006 / 33 KV RITHAD

Feeder No / Name : 206 / 11 kv BORALA EXPRESS

FEEDER Feeder KV- 11 /
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	.9694			.9431	.9465	.8669
2	.9671	1.0136	.2804		.8987	.9362	.8413
3	1.1191	1.182			1.0566	.929	.9511
4	1.829	1.3696	.8688		1.3672	1.0343	1.1393
5	2.1209	2.1434			2.1216	1.9204	2.0908
6	2.4874	2.3975	1.0974		2.3167	2.4272	2.4535
7	.1063	.1109			.1063	2.6006	2.6755
8	.1029	.1086	.1097		.0914	.1052	.0857
9	.1086	.1086			.0857	.0895	.0905
10	.1052	.1063	.1097	.6687	1.9163		.0857
11	.1097	.1086	1.2226	.4854	.0867		.1063
12	.1097	.7796	1.335	1.0288	1.1317	1.3394	1.4899
13	.1086	.7282	1.2003	1.1789	1.0692	1.1393	1.2894
14	.1097	.5792	1.0852		1.0229		1.1222
15	1.4198		.9556	1.0749	1.1744	1.134	1.1317
16	1.6124	1.5023	1.1789	1.4232	1.2346	1.267	1.2346
17	1.9204	1.8781	1.3672	1.7541	1.6617	1.7896	1.5947
18	2.4756	2.3045	2.0271	2.3045	2.2462	2.3045	2.1152
19	2.3752	1.9719	1.9136	1.9982	2.0858	2.1616	2.0919
20	2.0452	1.9753		1.7194	1.7857	1.8656	1.7878
21	1.8473		.4835		1.7194		1.4352
22	1.2309	.8505	.4835	1.1831	1.2517		1.2127
23	1.0791		.8495		1.0277		.9231
24	.9922	1.0059	.3292	.8238	.9922	.9189	.9036
Max	2.4874	2.3975	2.0271	2.3045	2.3167	2.6006	2.6755
Min	.1029	.1063	.1097	.4854	.0857	.0895	.0857
Avg	1.1386	1.1045	.9387	1.3036	1.2247	1.3838	1.2383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344007 / 33 KV RISOD

Feeder No / Name : 201 / 11 KV RITHAD FFEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6554	.6104	.78	.5365	.6539	.7042
2	.639	.583	.7888	.5087	.6443	.6706
3	.6762	.6241	.7628	.5487	.6588	.7122
4	.7619	.6661	.8063	.5895	.7802	.7545
5	.8505	.7087	.9214	.7362	.9568	.7975
6	1.1946	1.0745	1.3575	1.0631	1.3394	1.4022
7	1.4842	1.3394	1.5565	1.3394	1.6289	1.6834
8	1.7878	1.4327	1.7909	1.6118	1.7551	
9	1.8031	1.4373	1.9136	1.949	1.7528	1.7147
10	1.5432	1.3717	1.6827	1.6126	1.9071	1.7833
11	1.5402		1.6118	1.5432	1.5424	1.5402
12	1.704	1.5261	1.3592	1.5775	1.4746	1.4083
13	1.3923	1.6385	1.5581	1.6766	1.5402	.9568
14	1.3435	1.6385	1.5729	1.4918	1.5074	1.3435
15	1.4251	1.6385	1.6575	1.4419	1.4746	1.2346
16	1.6385	1.6385	1.7436		1.4746	
17	1.6385	1.6575	1.8519	1.8313	1.4419	
18	1.7528	1.6766	1.5775	1.7684	1.4723	
19	1.5604	1.5089	1.4723		1.4723	
20	1.3717	1.4083	1.1443	1.2483	1.2269	
21	.8573	1.1869	1.0288	.8817	.8573	
22	.6706	.8192	.6706	.6802	.7042	
23	.6036	.8048	.6371	.6478	.663	
24	.6401	.57	.8048	.57	.6316	.6554
Max	1.8031	1.6766	1.9136	1.949	1.9071	1.7833
Min	.6036	.57	.6371	.5087	.6316	.6554
Avg	1.2306	1.1983	1.2938	1.1752	1.2317	1.1574

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344007 / 33 KV RISOD

Feeder No / Name : 203 / 11 KV WAKAD FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3521	.3277	.3086	.3315	.39	.3277
2	.3521	.3647	.3086	.3688	.39	.3018
3	.3814	.4024	.3086	.4748	.3988	.3429
4	.4075	.373	.3155	.3772	.4334	.3814
5	.5138	.4115	.4207	.4252	.5028	.4207
6	.6447	.4508	.631	.5373	.724	.5258
7	.8059	.7796	.815	.7442	.8326	.7522
8	.8413	.7087	.8238	.7796	.9036	.7796
9	.8669	.7975	.8063	.8413	.8322	.7545
10	.823	.823	.7975	.8573	.7545	.6706
11	.7209	.6036	.7127	.7042	.6371	.5535
12	.6249	.6036	.7293	.6554	.6371	.4877
13	.5898	.6226	.5624	.6299	.583	.5487
14	.5487	.5571	.6167	.6554	.6226	.5155
15	.5693	.6554	.7362	.6554	.5898	.5121
16	.6554	.6554	.7125	.6554	.5761	
17	.7865	.6554	.7209	.7865	.6706	
18	.8573	.7209	.8573	.8383	.7888	
19	.7545	.7712	.7202	.7975	.6859	
20	.6706	.6706	.6036	.6613	.5487	
21	.4915	.503	.4915	.5087	.3353	
22	.4161	.4024	.3932	.39	.2915	
23	.3887	.3391	.3605	.39	.2915	
24	.3437	.3688	.3391	.3563	.39	.2915
Max	.8669	.823	.8573	.8573	.9036	.7796
Min	.3437	.3277	.3086	.3315	.2915	.2915
Avg	.6003	.5653	.5872	.6009	.5754	.5104

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344007 / 33 KV RISOD

Feeder No / Name : 204 / 11 KV RISOD TOWN 1 FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5914		.7842	.7842	.7356	.5601
2	.5914	.8299	.7842	.7842	.7167	.5975
3	.6161	.7842	.7842	.7602	.6979	.6348
4	.6036	.8215	.8029	.7468	.7545	.5975
5	.7356	.8589	.9149	.7842	.8488	.6348
6	1.094	.9335	1.2136	1.0456		1.4937
7	1.6221	1.9616	1.6975	1.6057	1.773	1.8298
8	1.5684	1.9044	1.773	1.9418	1.8107	1.9044
9	1.7364	1.6057	1.6598	1.7177	1.6632	1.7177
10		1.4784	1.3957	1.5123	1.5893	1.4937
11	1.7558	1.0974	1.2449	1.2936		
12	1.4998		1.0242	1.1458	1.4327	1.307
13	1.3169		.8779	1.0059	1.1949	1.1949
14	1.1888	1.4937	.7865	.8962	1.2323	1.0082
15	1.0498	1.2197	.9145	.8869	1.2012	1.8671
16	1.0745	1.1458	1.086	.9774	1.1088	
17	1.1946	1.1088	1.1946	1.1157	1.2936	
18	1.5524	1.5893	1.4784	1.4377	1.4784	
19	1.4937	1.4784	1.419	1.286	1.4415	
20	1.1203	1.386	1.1203	1.1389	1.2323	
21	1.0456	.9145	.9335	.8962	1.1203	
22	.8215	.8962	.7842	.7842	.7762	
23	.7762	.8402	.7842	.7468	.6722	
24	.5914		.8402	.8962	.7356	.5975
Max	1.7558	1.9616	1.773	1.9418	1.8107	1.9044
Min	.5914	.7842	.7842	.7468	.6722	.5601
Avg	1.1148	1.2174	1.0958	1.0913	1.1595	1.1626

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344007 / 33 KV RISOD

Feeder No / Name : 206 / WATWR WOKR EXPRESS FEEDER NON SHEDDABLE WATER SUPPLY AND
 Feeder KV- 11 / OUTGOING UTILITY

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0686	.0686	.0168	.0514	.0686
2	.0514	.104	.0686	.017	.0514	.0693
3	.0514	.0686	.0686	.0171	.0686	.1017
4	.0686	.104	.0686	.0171	.0686	.0686
5	.0857	.0701	.0686	.0171	.0686	.0686
6	.0857	.0693	.0686	.0171	.0686	.104
7	.0343	.0686	.0686	.0168	.0686	.1052
8	.0343	.0686	.0857	.0171	.0686	.1063
9	.0686	.0686	.0857	.0171	.0693	.0532
10	.1029	.0671	.0686	.0171	.0526	.0532
11	.1006	.0678	.0686	.0171	.1387	.0532
12	.0838		.0686	.0171	.0686	.0532
13	.1006		.0514	.0171	.0686	.0532
14	.0168	.0335	.0171	.0171	.0514	.0177
15	.0328	.0168	.0171	.0171	.0514	.0177
16	.0166	.0168	.017	.0171	.0686	
17	.0168	.0168	.0168	.0171	.017	
18	.0168	.0168	.0168	.0171	.017	
19	.0168	.0168	.0187	.0171	.0168	
20	.017	.0168	.0171	.0171	.0168	
21	.0171	.017	.0171	.0171	.0343	
22	.0335	.017	.0168	.0514	.0343	
23	.0686	.0857	.0168	.0686	.0343	
24	.0514	.0686	.0857	.017	.0514	.0343
Max	.1029	.104	.0857	.0686	.1387	.1063
Min	.0166	.0168	.0168	.0168	.0168	.0177
Avg	.0510	.0522	.0486	.0206	.0544	.0643

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344007 / 33 KV RISOD

Feeder No / Name : 207 / GHONSOR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.208	.2012	.1526	.1677	.1802	.1658
2	.1943	.2374	.1526	.2058	.1844	.2012
3	.1966	.208	.1543	.208	.1844	.2401
4	.213	.2454	.1715	.2103	.2279	.208
5	.2458	.2804	.2103	.2481	.2629	.2454
6	.3113	.3189	.3258	.2865	.3224	.3189
7	.3932	.3898	.3856	.362	.3761	.3898
8	.4748	.5144	.4161	.362	.4656	.5487
9	.6443	.6036	.6661	.5596	.5144	.6516
10	.6706	.663	.7209	.5868	.57	.6316
11	.6554	.6554	.6539	.5801	.5243	.583
12	.6478		.6203	.4973	.5407	.5506
13	.6154		.6203	.4915	.5243	.502
14	.6554	.5735	.5868	.5407	.4973	.5182
15	.6554	.7209	.4858	.5735	.4588	.5312
16	.6154	.6718	.5735	.5407	.4359	
17	.583	.6554	.5761	.5921	.4024	
18	.503	.503	.4359	.4321	.4359	
19	.4024	.4191	.3688	.3812	.4694	
20	.3353	.3353	.3018	.3149	.3605	
21	.2622	.2683	.2683	.2721	.2743	
22	.2294	.2012	.2458	.1943	.2561	
23	.2321	.1677	.1966	.1943	.2267	
24	.2056	.2321	.1677	.1311	.1781	.1943
Max	.6706	.7209	.7209	.5921	.57	.6516
Min	.1943	.1677	.1526	.1311	.1781	.1658
Avg	.4229	.4121	.3941	.3722	.3697	.4050

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344008 / 33 KV MANGULZANAK

Feeder No / Name : 202 / 11 kv mangulzanak

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478	.8573	.8573	.8097	.9602	.8322	.7202
2	.6478	.6859	.7888		.6859	.8309	.6859
3	.6478	.6859	.7202	.8162	.6173	.7935	.6344
4	.6405	.6859	.7202	.8583	.6173	.7935	.6344
5	.6802	.7293	.7202	.8745	.6173	.7655	.6344
6	.6964	.8916	.9259	.8802	.6173	.8592	.7888
7	.8097	1.166	1.166	1.004	.6173	1.0631	.7888
8	.9717	1.1843	1.166	1.1174	.9945	1.1683	.8573
9	1.4575	1.5278	1.8347	1.8084	1.2003	1.5939	1.1317
10	1.587	1.8299		2.0805	1.6804	2.0243	1.4403
11	1.6032	2.3758	2.0919	2.3805	1.749	2.2291	1.4737
12	1.7072	2.2119	1.8564	2.2725	1.9547	1.9547	1.5043
13	1.6644	2.4177	1.7966	2.2939	1.749		1.587
14	1.704	2.1776	1.5684	1.8623	1.6804	2.0748	1.5043
15			2.4291	1.7328	2.0481	1.7318	
16	2.2965		2.6073	1.9393	2.6558	2.2291	2.1538
17	2.3158	2.1605	2.5396	1.5432	2.3205	2.1262	.096
18	2.2405	1.9719	2.2348	1.3435	1.945	1.6118	1.9524
19	1.6549	1.6804	1.7459	1.1984	1.7284	1.2346	1.6324
20	1.4918	1.4232	1.5524	1.1203	1.668	1.1317	1.4685
21	1.3117	1.1488	1.4737	1.1191	1.2763	.8573	1.1043
22	1.3717	1.1317	1.3603	.9602	1.0486	.8573	1.085
23	1.4575	1.1317	1.0364	.9602	.9431	.7545	.953
24	.9717	.8573	1.0974	.8421	.9602	.8916	.7545
Max	2.3158	2.4177	2.6073	2.3805	2.6558	2.2291	2.1538
Min	.6405	.6859	.7202	.8097	.6173	.7545	.096
Avg	1.3294	1.4060	1.4908	1.3834	1.3473	1.3221	1.1124

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344009 / 33 KV MASALA PEN

Feeder No / Name : 201 / 11 KV Karkhana

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1307	.1448	.1646	.1543	.132	.1463
2	.1372	.1307	.1463	.1646	.1543	.132	.1463
3	.1372	.1307	.1463	.1646	.1543	.132	.1463
4	.1372	.1494	.1463	.1646	.1543	.1509	.1463
5	.1372	.1494	.1463	.1646	.1543	.132	.1463
6	.1372	.1494	.1463	.1646	.1543	.1463	.1463
7	.1372	.1494	.1463	.1646	.1543	.1463	.128
8	.1372	.128	.1463	.1463	.1372	.128	.128
9	.12	.128	.1463	.1463	.1372	.128	
10	.1372	.128	.1463	.1372	.1463	.128	.124
11	.1463	.124	.1448	.12	.1463		.1463
12	.128	.124	.1463	.12	.132	.1097	.1463
13	.128	.124	.1448	.12	.132	.1097	.1463
14	.128	.124	.1448	.12	.132	.128	.1448
15	.1417	.1417	.1417	.12	.132	.128	.124
16	.128	.124	.1448	.12	.132	.128	.124
17	.128	.1063	.1463	.12	.132	.128	.128
18			.1463	.12	.132	.1097	.128
19	.128	.128	.1448	.12	.132	.1097	.128
20	.128	.128	.1417	.1372	.132		.1463
21	.128	.128	.1463	.1372	.1509		
22	.128	.1267	.1463	.1372	.1509		.1463
23	.1267	.128	.1646	.1543	.132		.1829
24	.12	.128	.128	.1646	.1543	.132	.1463
Max	.1463	.1494	.1646	.1646	.1543	.1509	.1829
Min	.12	.1063	.128	.12	.132	.1097	.124
Avg	.1322	.1308	.1455	.1414	.1426	.1283	.1407

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344009 / 33 KV MASALA PEN

Feeder No / Name : 202 / chinchambapen ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.1469	1.7147	1.4754	
2				1.1336	1.7147	1.4251	
3				1.2967	1.7661	1.5089	
4				1.5623	1.749	1.4754	
5				1.5813	1.8861	1.8442	
6				1.7394	2.0576	2.0119	
7				1.7394	2.3148	2.0957	
8				1.6385	2.572	2.1795	
9				1.8023	2.4006	2.3807	
10	2.2291	2.0957	2.7035				1.9867
11	2.915	1.9479	2.6558				2.6092
12	2.9492	2.1975					2.8121
13	2.9321	2.2253	2.7854				2.6558
14	2.8669	2.3644	2.6882				2.753
15	2.7435	2.6425	2.6216				2.7206
16	2.5149	2.2809	2.4577				2.6558
17	2.4006		2.3758				2.2138
24				1.1142	1.7147	1.4419	
Max	2.9492	2.6425	2.7854	1.8023	2.572	2.3807	2.8121
Min	2.2291	1.9479	2.3758	1.1142	1.7147	1.4251	1.9867
Avg	2.6939	2.2506	2.6126	1.4755	1.9890	1.7839	2.5509

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344009 / 33 KV MASALA PEN

Feeder No / Name : 203 / MASALA PEN GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1494	.1638	.1265	.1543	.1829	.1772
2	.1372	.1463	.1638	.1265	.1543	.1646	.1772
3	.1372	.1494	.1581	.125	.1543	.1646	.1772
4	.1372	.168	.1966	.1875	.1543	.1646	.2481
5	.1372	.3921	.2622	.2294	.1715	.3658	.3155
6	.3429	.5121	.4534	.253	.4115	.5487	.4252
7	.583	.6219	.5312	.4428	.5658	.5853	.6241
8	.6173	.5487	.5376	.583	.6173	.5487	.631
9	.5144	.5121	.4062	.5624	.5144	.4961	
10	.4458	.4755	.3125	.4428	.4755	.2926	.426
11	.3109	.3932	.2846	.3429	.2641	.2481	.1898
12	.3109	.3277	.2214	.2058	.1886	.1772	.1581
13	.1829	.2622	.1562	.1886	.1698	.1772	.1581
14	.1829	.1638	.1581	.1886	.1698	.1595	.1581
15	.1829	.1638	.1581	.1715	.1886	.1595	.1581
16	.2195	.2804	.1562	.1715	.2263	.1772	.1581
17	.2743	.3544	.1875	.2743	.415	.2481	.1875
18		.4252	.426	.463	.4715	.4252	.2591
19	.5121	.3932	.4687	.5144	.5658		.2846
20	.5487	.2622	.3277	.2743	.415	.4252	.426
21	.3292	.2214	.2458	.2058	.2454		.1898
22	.1829	.1638	.1966	.1715	.2126		.1638
23	.168		.1581	.1715	.1753		.1581
24	.1372	.1463	.1638	.1619	.1543	.1772	.1772
Max	.6173	.6219	.5376	.583	.6173	.5853	.631
Min	.1372	.1463	.1562	.125	.1543	.1595	.1581
Avg	.2927	.3145	.2706	.2744	.3015	.2944	.2621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344009 / 33 KV MASALA PEN

Feeder No / Name : 204 / 11 kv Mangulzanak

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.3921	.5243	1.0526	1.286	1.5061	.426
2	.4458	.3658	.4999	1.0526	1.286	1.4754	
3	.4458	.3658	.5182	1.0936	1.3717	1.5089	
4	.4458	.7095	.6154	1.3927		1.7147	
5	.5144	.8859	.7537	1.5623	1.5432	2.0576	
6	.8916	1.1145	.9175	1.5623	1.8004	2.2291	.9755
7	1.2346	1.3032	.9831	2.1872	2.4006	2.3061	.9934
8	1.0974	1.2269	.9831	2.4996	2.6749	2.2382	1.012
9	1.166	1.1191	.9831	2.0557	2.7435	1.8004	
10	2.332	2.332	2.2672	.8421	.9389	.4801	1.7158
11	2.6155	1.9479	2.5606	.6859	.503	.6226	2.8464
12	2.8121	1.9471	2.2929	.6173	.3185	.5898	2.3434
13	2.6825	1.9471	2.1872	.6516	.5533	.5898	2.372
14	2.2634	1.9471	2.2672	.6516	.6539	.5898	2.372
15	2.2801	1.8637	2.2138	.6859	.6706	.5898	2.372
16	2.2634	1.9471	2.1872	.6859	.7042	.7209	2.372
17	2.2634	1.9749	2.2377	.8573	.8048	.7865	1.9925
18	1.0288	1.012	.9488	.9602	.9389	1.0486	.9831
19	.9945		.9175	1.0974	.8718	1.0486	1.0814
20	.6859		.7373	.6859	.8215	.5898	.9175
21	.6344		.5898	.583	.6588		.6325
22	.6401	.5182	.4111	.5144	.6201		.4588
23	.567	.5243	.421	.3772	.333		.3795
24	.4458	.3658	.5487	.9488	1.2003	1.5947	.5535
Max	2.8121	2.332	2.5606	2.4996	2.7435	2.3061	2.8464
Min	.4458	.3658	.4111	.3772	.3185	.4801	.3795
Avg	1.2998	1.2290	1.2319	1.0543	1.1173	1.2423	1.4105

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344033 / 33 kv CHIKHALI SUB STATION

Feeder No / Name : 201 / 11KV Chikhali

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5434	.4557	.4557	.4961	.4508	.4024	.4733
2	.5784	.4557	.4207	.4961	.4161	.373	.4733
3	.631	.4557	.4908	.0532	.4161	.3772	.443
4	.631	.5144	.5895	.5434	.4801	.4115	.5028
5	.6415	.6443	.6588	.5434	.6173	.5258	.5375
6	.7373	.7712	.823	.6762	.6783	.6661	.6516
7	.7291	.8551	.8916	.8745	.763	.8059	.6687
8	.8551	.8718	.9496	1.0343	.788	.8478	.8987
9	.9116	.9614	1.046	1.1022	.9831	.8684	.8648
10	1.1271	.9945	.9326	1.0682	.9503	.9667	.9556
11	1.0227	.9175	.9724	.823	.7748	.8139	.8478
12	1.1736	.9442	.9221	.8745	.8124	.7888	.8987
13	1.1233	.8259	1.0277	.8916	.9488	.9282	.9556
14	1.0898	.9503	1.0442	.9156	.8381	.9054	.9156
15	1.0059	1.0227	1.0059	.9835	.8322		.8478
16		1.1271	.9326	.8478	.7748		.8886
17		1.0277	.9496	1.0227	.8124		.8478
18	1.0227	.9339	1.0004	1.0059	.8539	1.0486	.8478
19	.9496	.8619	.8916	.9496	.7186	.7969	.78
20	.8573	.78	.7802	.8478	.6325	.7202	.7202
21	.6935	.7202	.7455	.7202	.5093	.703	.6516
22	.5959	.6415	.6485	.6001	.4374	.6068	.5895
23	.5434	.5895	.5316	.583	.4161	.5434	.5434
24	.567	.5083	.4908	.5138	.5144	.4588	.5083
Max	1.1736	1.1271	1.046	1.1022	.9831	1.0486	.9556
Min	.5434	.4557	.4207	.0532	.4161	.373	.443
Avg	.8196	.7846	.8001	.7694	.6841	.6933	.7213

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344033 / 33 kv CHIKHALI SUB STATION

Feeder No / Name : 203 / 11 KV Kawatha

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3544	.2835	.3292	.3582	.3155	.3224	.333
2	.3898	.2835	.3109	.3582	.3155	.3012	.3721
3	.3681	.2835	.3258	.3761	.3155	.2865	.3898
4		.3814	.4119	.3582	.4161	.3224	.3898
5	.4382	.5144	.4607	.3544	.4801	.4344	.4075
6	.6001	.6443	.5373	.4031	.6173	.5731	.5609
7	.7545	.7461	.6447	.4508	.7461	.6626	.6762
8	.7956	.6783	.7343	.6687	.7291	.7343	.6762
9	.8122	.7461	.7973	.7545	.6344		.7202
10	.8453	.7122	.7888	.6859	.6344	.7087	.703
11	.7209	.57	.7011	.6859		.691	.5658
12	.5144	.5765	.7282	.6859		.6447	.5487
13	.5487	.6203	.7108	.6859	.6874	.6733	.6173
14	.5487	.6796	.6485	.6516	.7122	.6836	.5487
15	.5658	.7461	.6068	.6687	.6133	.6379	.5144
16	.5316	.7459	.6935	.7373	.6554	.7186	.6001
17	.78	.7209	.7888	.8059	.7293	.7975	.6516
18	.7202	.7461	.7628	.7202	.7042	.7537	.6173
19	.6173	.6836	.6588	.6859	.6952	.6733	.5144
20	.5201	.5258	.4908	.6241	.6173	.5552	.4801
21	.4557	.4656	.4252	.5201	.4681	.5552	.4334
22	.3681	.3761	.3582	.3856	.4161	.394	.4031
23	.3012	.362	.3403	.3506	.3856	.3439	.3506
24	.3544	.2835	.3439	.3403	.3506	.3544	.3582
Max	.8453	.7461	.7973	.8059	.7461	.7975	.7202
Min	.3012	.2835	.3109	.3403	.3155	.2865	.333
Avg	.5611	.5573	.5666	.5548	.5563	.5575	.5180

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344036 / 33 KV KENWAD

Feeder No / Name : 201 / 11 KV KENWAD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.134	1.2437	1.0974	1.0974	1.134	1.0974	.9877
2	1.0974	1.2803	1.0974	1.0974	1.2071	1.134	.9511
3	1.2437	1.3535	1.2437	1.134	1.2071	1.4266	.9511
4	1.4266	1.7924	1.4998	1.4632	1.9022	1.5364	1.1706
5	1.8656	1.9753	1.9022	1.7193	1.9753	1.829	1.5364
6							1.6095
7							1.7558
8							1.4998
9							1.3535
10							1.39
11							1.3535
12	2.3411	2.3411	2.3777	2.3777	2.268	2.0851	1.4998
13	1.7558	2.3045	2.2314	2.3045	1.9022	1.9387	1.4998
14	1.6461	2.0119	1.9022	1.7924	1.5729	1.6827	1.2437
15							1.2437
16							1.0974
17							1.4632
18							1.8656
19	2.5606	2.524	2.524	2.4874	2.524	2.0119	1.2803
20	2.3777	2.1582	2.3045	1.8656	2.1582	1.9022	1.7558
21	2.0119	1.7193	1.7924	1.829	2.0119	1.6095	1.4998
22	1.0974	1.5364	1.4998	1.3535	1.7193	1.2437	1.1706
23	1.2071	1.134	1.2071	1.1706	1.1706	.9877	.9877
24	1.134	1.0974	1.0974	1.0974	1.134	1.0974	.9877
Max	2.5606	2.524	2.524	2.4874	2.524	2.0851	1.8656
Min	1.0974	1.0974	1.0974	1.0974	1.134	.9877	.9511
Avg	1.6356	1.748	1.6984	1.6278	1.7062	1.5416	1.3398

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344036 / 33 KV KENWAD

Feeder No / Name : 202 / 11 KV SAKHRAPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6661	.6661	.6371	.5792	.5792	.5792	.5792
2	.695	.5502	.6081	.5792	.6081	.5502	.5502
3	.724	.4633	.5792	.5502	.5792	.5213	.5502
4	.6661	.3765	.5502	.5502	.5792	.5502	.4633
5	.4633	.5502	.5502	.5213	.4923	.4344	.4344
10	1.1584	1.1294	1.2452	1.1584	1.1004	1.1584	1.0715
11	1.0136	.9267	1.1004	1.0136	.8977	.8977	.8109
23					.6371		.6081
24	.6371	.695		.6081	.5502		.6081
Max	1.1584	1.1294	1.2452	1.1584	1.1004	1.1584	1.0715
Min	.4633	.3765	.5502	.5213	.4923	.4344	.4344
Avg	.7530	.6697	.7529	.6950	.6693	.6702	.6307

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344036 / 33 KV KENWAD

Feeder No / Name : 203 / 11 KV JAIYKHEDA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.8025	.8333	.9877	1.0185	1.4198	.9259	.7099
7	.8333	1.0802	1.1111	1.1111	1.2963	.9568	.9259
8	1.2654	1.2346	1.2654		1.2963	1.2037	1.142
9	1.358	1.142	1.2037	1.2654	1.142	1.1728	1.1728
15	1.821	1.7593	1.7593	1.7901	1.7284	1.5123	1.4815
16	1.7593	1.6358	1.5741	1.8519	1.5741	1.6975	1.358
17	1.5123	1.4815	1.4815	1.5432	1.4815	1.2963	1.2963
18	1.2654	1.2346	1.3272	1.3272	1.2037	1.2346	1.0802
Max	1.821	1.7593	1.7593	1.8519	1.7284	1.6975	1.4815
Min	.8025	.8333	.9877	1.0185	1.142	.9259	.7099
Avg	1.3272	1.3002	1.3388	1.4153	1.3928	1.2500	1.1458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344037 / 33 KV WAKAD SUB STATION

Feeder No / Name : 201 / 11 KV WAKAD,WAKAD S/S

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6443	.5765	.6783	.5765	.5087	.5765	.6104
2	.6104	.5426	.78	.5765	.4748	.5765	.78
3	.6783	.5426	.8139	.5765	.5426	.5765	.8478
4	.8139	.6783	.9835	.6104	.7122	.6104	1.0174
5	.9835	.8139	1.3226	.8139	.8478	.6783	1.0513
6	1.3226	1.0174	1.3226	.8478	.8817	.9496	1.1191
7	1.2887	1.2548	1.2887	.9835	.9835	1.1191	1.0852
8	1.2209	1.2548	1.2548	1.1191	1.0513	1.0174	1.0852
9	1.2209		1.2887	1.3226	1.1191	1.2209	1.0852
10	1.4582	1.1869	1.3226	1.2209	1.1869	1.2209	1.0852
11	1.3565	1.3056	1.2548	1.153	.9835	1.1869	.9156
12	1.3904	.9496	1.3226	1.0852		1.0174	.9156
13	1.4582	1.2209	1.4243	1.2887	1.0852	1.0174	.9156
14	1.56	1.3565	1.3904		1.3904	1.1191	1.0513
15	1.4243	1.3565	1.3226		1.2887	1.1191	1.1191
16	1.56	1.4582	1.2548		1.2887	1.2209	1.1869
17	1.4582	1.5261	1.3904	1.7635	1.2887	1.2887	1.0852
18	1.4243	1.4922	1.4243	1.6278	1.3904	1.2887	1.2548
19	1.153	1.0174	1.2548	1.2209	1.153	1.0174	1.0513
20	.9496	.9835	.9835	.8478	.9835	.9496	.9496
21	.8139	.9496	.8139	.7461	.78	.9496	.78
22	.7122	.7461	.6443	.6104	.6783	.6443	.6443
23	.6104	.7122	.6104	.5087	.6104	.5765	.5765
24	.5426	.5765	.6783	.5765	.5087	.5765	.5426
Max	1.56	1.5261	1.4243	1.7635	1.3904	1.2887	1.2548
Min	.5426	.5426	.6104	.5087	.4748	.5765	.5426
Avg	1.1106	1.0226	1.1177	.9560	.9451	.9383	.9481

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344037 / 33 KV WAKAD SUB STATION

Feeder No / Name : 202 / 11 KV GOHGAON FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4973	.3978	.4973	.3978	.4641	.3978	.5636
2	.4973	.3978	.5636	.407	.431	.3978	.6299
3	.5304	.3647	.5636	.431	.4973	.3978	.7625
4	.5636	.4641	.6299	.4641	.5967	.431	.8288
5	.6962	.5304	.663	.5304	.7293	.5304	.9614
6	.9282	.663	.7956	.7625	.7625	.663	.9282
7	.9282	.7956	.9282	.9282	.7293	.8288	.8951
8	1.0277	.9614	.9945	.8619	.7956	.9282	.9614
9	1.0608	1.0608	1.1603	1.094	.8619	1.094	.9945
10	1.1271	1.1271	1.2929	1.1603	1.0608	1.2597	.9945
11	1.1271		1.2266	1.1271	1.0277	1.1603	.8288
12	1.1603		1.1271	1.094	1.0608	.9945	.8288
13	1.0608		1.1271		1.153	.9945	.8951
14	1.094	1.326	1.1603		1.1603	1.0608	.9282
15	1.1271	1.4255	1.1271		1.094	.9945	.9614
16	1.1934	1.4918	.9945	1.2597	1.0277	1.1603	.9945
17	1.1603	1.3923	1.094	1.3592	1.094	1.1934	.9614
18	1.094	1.2266	1.0277	1.2929	.9614	1.0608	.9945
19	.8619	1.1603	.9282	.9945	.8951	.9945	.7956
20	.7956	.9282	.78	.7625	.7625	.8288	.6962
21	.663	.6962	.663	.663	.663	.8288	.5636
22	.5636	.5636	.5304	.4973	.5426	.5304	.431
23	.4641	.4973	.4641	.431	.431	.4973	.3978
24	.4641	.431	.4973	.431	.3978	.3978	.4973
Max	1.1934	1.4918	1.2929	1.3592	1.1603	1.2597	.9945
Min	.4641	.3647	.4641	.3978	.3978	.3978	.3978
Avg	.8619	.8525	.8682	.8071	.8000	.8177	.8039

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344001 / 33KV S/S WASHIM

Feeder No / Name : 201 / RAILWAY STATION

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4435	.4668		.4572	.4527	.3582	.4294
2	.4435	.4668		.4572	.4527	.4298	.4294
3	.4435	.4668		.462	.4527	.4251	.4294
4	.4435	.4668		.462	.4527	.3881	.4481
5	.5544	.5544		.5175	.4904	.5975	.5041
6	.6838	.5914		.6161	.6535	1.086	.5975
7	.7316	.7316		.7545	.7392	.7095	.7577
8	.8507	.8413		.8488	.8059	.7522	.9145
9	.905	.8059		.905	.7842	.7762	.924
10	.9412	.8059	.8059	.8962	.8215	.7522	.9145
11	.8145	.6805	.7468	.7888	.724	.6447	.7682
12	.788	.724	.724	.7164	.695	.6135	.695
13	.7164	.7164	.5201	.6135	.6535	.5784	.6584
14	.7316	.7023	.6379	.6805	.5544	.5609	.6584
15	.6516	.6154	.6468	.6135	.5373	.583	.6584
16	.6626	.6201	.6001	.591	.5721	.5552	.6401
17	.7087	.6935	.6584	.6024	.6001	.5731	.6335
18	.8145	.7421	.695	.6805	.6859	.6401	.6335
19	.7682	.7602	.7023	.7316	.6485	.7392	.724
20	.7316	.695	.6401	.6447	.6268	.6468	.6268
21	.6401	.6401	.5853	.5792	.5731	.5914	.6535
22	.5544	.6219	.5487	.5487	.4477	.5228	
23	.5544		.4525	.462	.4668	.4668	.4572
24	.462	.4668		.4525	.4668	.4755	.4294
Max	.9412	.8413	.8059	.905	.8215	1.086	.924
Min	.4435	.4668	.4525	.4525	.4477	.3582	.4294
Avg	.6683	.6468	.6403	.6284	.5982	.6028	.6341

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344001 / 33KV S/S WASHIM

Feeder No / Name : 202 / TOWN FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7167	.6036		.5601	.6036	.7655	.5658
2	.7167	.6036		.5601	.6224	.6535	.5658
3	.7167	.6036		.5601	.6036	.6535	.5658
4	.7545	.6036		.5658	.6036	.6535	.6602
5	.7545	.7545		.6602	.7167	.8954	.6979
6	1.094	.9997		.9431	1.0562	1.1576	1.0185
7	1.3203	1.2883		1.1694	1.1949	1.307	1.3256
8	1.5089	1.3817		1.5089	1.475	1.4563	1.587
9	1.4937	1.3443	1.4563	1.4003	1.4937	1.3957	1.4937
10	1.5684	1.307	1.3443	1.4003	1.3817	1.4146	1.4563
11	1.4784	1.2696	1.3817	1.386	1.3443	1.307	1.3306
12	1.386	1.2936	1.2696	1.2136	1.1949	1.2136	1.2437
13	1.2936	1.2012	1.1203	1.1203	1.1949	1.0719	1.0608
14	1.0719	1.1458	1.0082	1.0269	1.0829	1.0349	1.0608
15	1.1203	.9709	.9709	.9335	1.0269	.9145	.8779
16	1.0164	.9709	.961	1.1203	1.0059	.924	.9877
17	1.1458	1.1088	1.1458	1.0719	1.134	1.0719	1.0974
18	1.4784	1.5154	1.6263	1.4563	1.5684	1.6632	1.4632
19	1.5154	1.587	1.643	1.587	1.587	1.6263	1.6461
20	1.3676	1.4937	1.423	1.363	1.4003	1.4563	1.4937
21	1.2012	1.307	1.1949	1.1576	1.3443	1.307	1.307
22	.9709	1.2323	1.1576	.9335	.9896	1.0269	
23	.7468		.7468	.7468	.7468	.6161	.7392
24	.7167	.6602		.6161	.5601	.6468	.6161
Max	1.5684	1.587	1.643	1.587	1.587	1.6632	1.6461
Min	.7167	.6036	.7468	.5601	.5601	.6161	.5658
Avg	1.1314	1.0977	1.2300	1.0442	1.0805	1.0930	1.0809

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344001 / 33KV S/S WASHIM

Feeder No / Name : 203 / NARAYANBABA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.6036		.5658	.5788	.7468	.5658
2	.7545	.6036		.5658	.5847	.7095	.5658
3	.7545	.6036		.5658	.5847	.6908	.5658
4	.7545	.6036		.5281	.5847	.7282	.9431
5	.7545	.7922			.7545	1.0269	.7733
6	1.1317	1.094			1.1317	1.307	.9431
7	1.4937	1.4937		1.4146	1.307		1.4784
8	1.6632	1.643		1.5466	1.643	1.7177	1.7556
9	1.5708	1.4937	1.5684	1.4937	1.6804	1.2826	
10	1.5154	1.3443	1.3817	1.386	1.4937	1.4712	1.4784
11	1.4415	1.1949	1.2936	1.307	1.4784	1.3203	1.2567
12	1.307	1.1088	1.307	1.0829	1.2012	1.1203	1.134
13	1.307	1.1203	1.0719	1.0164	.924	.9335	1.0425
14	.924	.9335	.9335	.7468	.9335	.8962	.9145
15	.9335	.8962	.8962	.8402	.8402	.8962	.8779
16	.924	.8871	.8962	.7762	.8871	.8962	.9145
17	1.0719	1.1088	.961	.961	.961	.961	.9145
18	1.2936	1.2936	1.3443	1.2936	1.307	1.3676	1.2803
19	1.2936	1.307	1.307	1.2936	1.307	1.3443	1.2803
20	1.1088	1.1203	1.1576	1.1458	1.1203	1.1576	1.1576
21	.9979	1.0456	.9709	.961	1.0456	1.0829	1.0719
22	.8589	1.0082		.924	.8962	.8962	
23	.7468		.7468	.7468	.7468	.7468	.7468
24	.7545	.7545		.7545	.5975	.7468	.6535
Max	1.6632	1.643	1.5684	1.5466	1.6804	1.7177	1.7556
Min	.7468	.6036	.7468	.5281	.5788	.6908	.5658
Avg	1.0879	1.0458	1.1312	.9962	1.0245	1.0455	1.0143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344001 / 33KV S/S WASHIM

Feeder No / Name : 204 / IUDP FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2263		.2241	.2241	.2263	
2	.2641	.2263		.2263	.2263	.2241	.2452
3	.2641	.2263		.2263	.2263	.2241	.2452
4	.2641	.2263		.2075	.2263		.2452
5	.2641	.2641		.2452	.2452		.2641
6	.3772	.3772		.3018	.3772	.3547	.3395
7	.4854	.5228		.415	.4294	.4294	.4668
8	.5544	.5041		.4904	.4854	.5415	.5359
9	.4805	.4715	.5415	.4854	.5228	.5658	.4805
10	.4251	.4108	.4904	.4481	.4108	.5487	.4481
11	.3696	.4294	.4108	.3921	.3547		.4066
12	.2987	.3547	.3174	.2987	.2614	.394	.3696
13	.2987	.3326	.2987	.2987	.2987	.3761	.3326
14	.2587	.2987	.2987	.2987	.2614	.3582	.3326
15	.2614	.3326	.2241	.2801	.2427	.3506	.2926
16	.2402	.3174	.2614	.2427	.2614	.3326	.3292
17	.2957	.3292	.3174	.2957	.2987	.3142	.3292
18	.3511	.439	.4854	.3511	.4572	.4251	.439
19	.4251	.4481	.4481	.4066	.4755	.462	.439
20	.4066	.4108	.4435	.4066	.3881	.4294	.4481
21	.3696	.4108	.3881	.4066	.3734	.3921	.4481
22	.3361	.4108	.3696	.3142	.4108	.3547	
23	.2801		.2987	.2614	.2801	.2801	.2987
24	.2829	.2452		.2614	.2614	.2241	.2801
Max	.5544	.5228	.5415	.4904	.5228	.5658	.5359
Min	.2402	.2263	.2241	.2075	.2241	.2241	.2452
Avg	.3382	.3572	.3729	.3244	.3333	.3718	.3644

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344002 / 33 kV PIMPALGAON SUB-STATION

Feeder No / Name : 202 / 11 KV ANSING GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)
1	.8775	.8962
2	.9335	1.0829
3	1.1763	1.2136
4	1.587	1.6804
5	2.0911	1.9231
6	2.3712	2.5393
7	1.2136	
8	1.0402	
9	1.8564	2.5206
10	1.587	1.7551
11	1.2136	1.3256
12	.9335	.9709
13	.8402	.8131
14	.8215	.7762
15	.8775	1.0829
16	1.1203	1.0425
17	1.4937	1.5181
18	1.9978	1.9231
19	2.2592	2.0725
20	1.6804	1.7364
21	1.251	1.3717
22	1.0456	1.1203
23	.8775	.8589
24	.8402	.8775
Max	2.3712	2.5393
Min	.8215	.7762
Avg	1.3327	1.4137

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344002 / 33 kV PIMPALGAON SUB-

STATION

Feeder No / Name : 203 / 11 KV ANSING AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3041	.2932		.0316		
2		.3041	.3563		.032		
3		.2881	.2721		.032		
4	.125	.2881	.3768		.032		
5		.2721	.3281		.032		
6		.2721	.3113		.032		
7		.4641	.2968		.032		
8		.5281	.3593		.032		
9		.5601			.032		
10					.3361	.128	.3567
11					.4321	.5601	.4458
12				.5601		.5761	.4755
13				.6401		.5761	.506
14				.5121		.4801	.3858
15				.4481		.4481	.4531
16				.4481		.4481	.4588
17					.16	.4161	.3637
24		.3041	.0926		.0316		
Max	.125	.5601	.3768	.6401	.4321	.5761	.506
Min	.125	.2721	.0926	.4481	.0316	.128	.3567
Avg	.125	.3585	.2985	.5217	.0960	.4541	.4307

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344002 / 33 kV PIMPALGAON SUB-

STATION

Feeder No / Name : 204 / 11 KV PARDI AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.213		.208	.2623
2				.1802		.2241	
3				.1781		.2241	.2778
4				.1619		.2401	.2778
5				.1581		.2401	.3086
6				.1475		.2401	.3086
7				.4843		.4481	
8				.547		.5921	.4938
9				.6249	.3292	.5601	.439
10	.5921		.2006				
11	.6874		.213				
12	.6562		.2031				
13	.6562	.5243	.6554				
14	.6882	.5937	.5735				
15		.5937	.5468				
16		.6093	.5556				
17	.4961	.6554	.5967				
24				.2785	.3281	.208	.2623
Max	.6882	.6554	.6554	.6249	.3292	.5921	.4938
Min	.4961	.5243	.2006	.1475	.3281	.208	.2623
Avg	.6294	.5953	.4431	.2974	.3287	.3185	.3288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344002 / 33 kV PIMPALGAON SUB-

STATION

Feeder No / Name : 205 / 11 KV INDUSTRIAL FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0381	.0381	.0762	.0381	.0572
2	.0762	.0381	.0381	.0381	.0762	.0381	.0572
3	.0762	.0191	.0381	.0381	.0762	.0381	.0572
4	.0762	.0191	.0381	.0381	.0572	.0381	.0572
5	.0762	.0191	.0377	.0381	.0572	.0381	.0572
6	.0381	.0191	.0381	.0381	.0381	.0381	.0572
7	.0381	.0191	.0381	.0381	.0381	.0381	
8	.0191	.0191	.0381	.0381	.1524	.0381	.0381
9	.1905	.0381	.0381	.1334	.1524	.0572	.1334
10	.2477	.0953	.1715	.132	.1524	.0953	.1334
11	.1905	.0953	.2096	.1334	.1905	.1524	.1334
12	.1905	.1715	.2096	.1334		.1524	.2096
13	.1905	.1715	.2096	.1334	.1905	.1524	.2096
14	.1905	.2096	.2075	.1334	.1905	.1524	.2096
15	.1905	.2096	.2096	.1334		.1524	.2096
16	.1524	.2096	.2096	.1334	.1524	.1524	.2096
17	.0953	.2096	.2096	.1334	.0953	.1524	.2096
18	.0762	.1905	.1905	.1905	.0953	.1905	.2096
19	.0381	.2096	.1905	.1905	.0572	.1905	.2096
20	.0381	.2096	.1905	.0762	.0572	.0762	.1715
21	.0381	.1905	.0572	.0572	.0572	.0572	.1334
22	.0381	.0572	.0572		.0572	.0572	.0566
23	.0381	.0572	.0572		.0381	.0572	.0572
24	.0381	.0381	.0381	.0572	.0381	.0381	.0572
Max	.2477	.2096	.2096	.1905	.1905	.1905	.2096
Min	.0191	.0191	.0377	.0381	.0381	.0381	.0381
Avg	.0992	.1064	.1150	.0943	.0953	.0913	.1276

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344002 / 33 kV PIMPALGAON SUB-

STATION

Feeder No / Name : 206 / 11 KV WARLA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)
1	.2427	.2241
2	.2801	.2987
3	.3547	.3734
4	.4668	.5228
5	.5975	.6722
6	.6908	.7468
9	.5415	.6348
10	.3361	.3921
11	.2427	.3174
12	.168	.2054
13	.1867	.2054
14	.2054	.168
15	.2054	.1867
16	.3174	.2957
17	.5041	.4435
18	.6535	.4668
19		.5228
20	.5975	.4294
21	.4108	.3841
22	.2987	.2801
23	.2427	.2241
24	.2427	.2241
Max	.6908	.7468
Min	.168	.168
Avg	.3708	.3736

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344003 / 33 KV RAJGAON S/S

Feeder No / Name : 201 / 11 KV RAJGAON TONDGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7956	.7164	.8871	.2149	.3696	.2652	
2	.7625	.7164	.9054	.2149	.2957	.2652	
3	.7293	.724	.9431	.2103	.2743	.2321	.181
4	.7625	.7602	.9145	.2103	.2686	.3315	.2172
5	.7956	.7522	.8954	.2058	.2686	.431	.3582
6	.8288	.788	.9114	.2401	.3582	.7293	.362
7	.8288	.788	.9922	.2507	.4344	.663	.5792
8	.8288	.788	.8859	.2149		.7625	.5792
9	.8122	.7712	.7973	.2896	.6516	.6962	.6878
10	.3315	.1715	.4607	.8322	.8669		.8573
11		.3391	.5144	.9602	.9496		1.1065
12	.5636	.3315	.4915	.9282	.9945		1.2929
13	.4858	.4973	.3932	.9831		1.2431	1.1603
14	.463	.4778	.3647	.9717		1.2431	
15	.4572	.4973	.3647	.9393		1.2742	1.1065
16	.3688	.5596	.3647	.9282		1.2742	1.1934
17	.3467	.5658	.3647	.9054		1.3077	1.1869
24	.8288	.7164	.924	.2172	.3696	.1326	.1715
Max	.8288	.788	.9922	.9831	.9945	1.3077	1.2929
Min	.3315	.1715	.3647	.2058	.2686	.1326	.1715
Avg	.6464	.6089	.6875	.5398	.5085	.7234	.7360

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344003 / 33 KV RAJGAON S/S

Feeder No / Name : 202 / RAJGAON TONDGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5121	.4477	.5544	.4477	.5544	.4938	.4668
2	.5487	.5373	.5281	.4835	.5175	.5121	.5601
3	.5487	.543	.5281	.5609	.695	.5121	.543
4	.7682	.5792	.6584	.5959	.9313	.7865	.6335
5	1.0791	.8596	.9671	.8402	1.0029	.8962	.8596
6	1.3169	1.0387	1.2269	.9088	1.1641	1.2437	1.0498
7	1.2437	1.1462	1.1517	1.2178	1.2308	1.2254	1.1403
8	1.262	1.1104	1.1517	1.2894	1.1765	.9694	1.1765
9	.8962	1.0517	1.1517	1.1403	1.086	.9694	1.1222
10	.8962	.7373	.9745	.9189	.7802	.9511	.823
11		.6274	.6859	.6516	.5935	.9145	.6371
12	.547	.4973	.5407	.4475	.5121		
13	.4372	.4973	.4915	.4424	.5487	.4144	.3647
14	.3704		.4641	.4049	.4938	.4144	
15	.4572	.5304	.431	.4049		.4694	.4359
16	.7042	.6783	.5801	.4321	.5121	.5365	.547
17	.8322	.823	.663	.7545		.5533	.8478
18	1.1763	1.2012	.8871	1.0534	1.0974	1.0269	1.0456
19	1.1088	1.0642	.924	1.1088	1.1576	1.0185	1.1576
20	.9795	.8871	.8871	.9145	.823	.8962	1.0164
21	.7682		.7392	.7316	.8048	.7392	.7865
22	.6401	.6401	.6468	.5853	.7316	.5914	.6401
23	.4938	.543	.4805	.5373	.5487	.5544	.5487
24	.5121	.4477	.5544	.4525	.5544	.4938	.4287
Max	1.3169	1.2012	1.2269	1.2894	1.2308	1.2437	1.1765
Min	.3704	.4477	.431	.4049	.4938	.4144	.3647
Avg	.7869	.7495	.7445	.7219	.7962	.7471	.7650

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344004 / 33 KV MIDC WASHIM SUB-

STATION

Feeder No / Name : 201 / 11 KV LALDEO AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2572	.1457	.0829	
2				.2204	.1457	.0829	
3				.1696	.1457	.0995	
4				.1715	.1457	.0995	
5				.2401	.1457	.1006	
6				.218	.1781	.1658	
7				.2267	.2753	.1658	
8				.2321	.3077	.1658	
9				.2155	.3077	.1658	
10	.1943	.1658	.2984				.1619
11	.1943	.3239	.3086				.285
12	.1619	.2429	.3353				.2984
13	.1943	.2429	.3353				.3185
14	.1943	.2429	.2629				.3688
15	.1943	.2286	.2515				.3185
16	.0095	.1619	.2347				.2984
17	.1619	.1619	.2204				.2515
24				.1677	.1619	.0829	
Max	.1943	.3239	.3353	.2572	.3077	.1658	.3688
Min	.0095	.1619	.2204	.1677	.1457	.0829	.1619
Avg	.1631	.2214	.2809	.2119	.1959	.1212	.2876

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344004 / 33 KV MIDC WASHIM SUB-

STATION

Feeder No / Name : 202 / 11 KV WW-EK BHURJI DAM-

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND

UTILITY

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0183	.0118	.0189	.0171	.0189	.0171	.0343
2	.0183	.0118		.0171	.0189	.0171	.0171
3	.0183	.0118	.0189	.0171	.0189	.0175	.0343
4	.0185	.0118	.0189	.0171	.0189	.0175	.0343
5	.0185	.0312	.0189	.0171	.0189	.0175	.0343
6	.0175	.0335	.0189	.2033	.0189	.0175	.0343
7	.1949	.0857	.0189	.2801	.197	.2321	.0343
8	.2229	.2321	.1886	.3174	.2658	.2321	.1753
9	.2454	.2652	.1886	.2772	.2486	.2155	.1715
10	.2427	.2347	.3174	.2241	.2321	.213	.1715
11	.2254	.0943	.3142	.2614	.2572	.1886	.2241
12	.2254	.1886	.2772	.2401	.2401	.1886	.2229
13	.2427	.1867	.285	.3429	.2401	.1886	.2328
14	.2427	.1867	.2987	.1886	.2427	.0943	.2427
15		.0943	.3174	.2103	.2427		.2402
16		.1867	.2801	.2454	.2947	.1886	.2587
17	.2058	.1867	.1848	.2915	.3185	.4715	.2614
18	.2294	.0943	.3174	.2401	.218	.1886	.2587
19	.1966	.1886	.2957	.2629	.2012	.1886	.2427
20	.1638	.1886	.3174	.2321	.2515		.2587
21	.1638	.1886	.2236	.1844	.1844	.1886	.1867
22	.1619	.0189	.0924	.0339	.1509	.0377	.0924
23	.0118	.0189	.0187	.0175	.0171	.0377	.0171
24	.0183	.0118	.0189	.0171	.0189	.0171	.0343
Max	.2454	.2652	.3174	.3429	.3185	.4715	.2614
Min	.0118	.0118	.0187	.0171	.0171	.0171	.0171
Avg	.1410	.1151	.1761	.1732	.1640	.1352	.1464

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344004 / 33 KV MIDC WASHIM SUB-

STATION

Feeder No / Name : 203 / 11 KV KALAMBA AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1677	.3239	.1677	
2				.1658	.3401	.1677	
3				.1677	.3401	.2012	
4				.1658	.3725	.2486	
5				.1658	.3563	.2486	
6				.1715	.3239	.2486	
7				.463	.7449	.4973	
8				.4973	.8421	.8288	
9				.4858	.8097	.8288	
10	.6478	.5801					.1619
11	.6478	.5668	.3391				.4973
12	.4858	.3572	.4144				.5868
13	.4858	.362	.4191				.5801
14	.4858	.362	.1753				.3315
15	.5668	.362	.1696				.5801
16	.5668	.2896	.1715				.503
17	.4858	.2896	.1696				.3315
24				.1677	.3239	.1677	
Max	.6478	.5801	.4191	.4973	.8421	.8288	.5868
Min	.4858	.2896	.1696	.1658	.3239	.1677	.1619
Avg	.5466	.3962	.2655	.2618	.4777	.3605	.4465

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344004 / 33 KV MIDC WASHIM SUB-

STATION

Feeder No / Name : 204 / 11kv TAMSALA AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305	.0082	.0278	.503	.5898	.7773	
2	.0305	.0082	.0278	.5636	.6062	.7773	
3	.0305	.0082	.0278	.5365	.639	.8097	
4	.0305	.0175	.0278	.5801	.7865	.8288	
5	.0305	.0175	.0278	.5636	.9831	.8951	
6	.0305	.016	.0278	.5801	.9831	.9282	
7	.0305	.0171	.0278	.9221	1.3108	1.1736	
8	.0305	.0332	.0278	.9069	1.4419	1.3748	
9	.0305	.0332	.0278	1.0486	1.4918	1.4754	
10	.9831	.9389	1.0898				.8097
11	1.1934	1.1469	1.1904				1.7404
12	1.2929	1.2289	1.1736				1.3748
13	.503	1.2289	1.1603				1.6244
14	.503	1.2289	1.0774				1.7368
15	1.1934		1.094				1.7238
16	1.2597	1.1469	.9779	.0286	.0236	.0278	1.3847
17	1.094	1.1469	1.0059	.0286	.0236	.0278	1.3108
18	.0236	.0274	.0343	.0286	.0354	.0278	.0343
19	.0236	.0278	.0343	.0305	.024	.0278	.0343
20	.0236	.0278	.0343	.0305	.024	.0278	.0343
21	.0248	.0274	.0343	.0305	.0236	.0278	.0343
22	.0248	.0278	.0343	.0305	.0236	.0278	.0343
23	.0164	.0278	.0343	.0305	.0236	.0278	.0343
24	.0305	.0082	.0278	.3856	.5243	.7773	
Max	1.2929	1.2289	1.1904	1.0486	1.4918	1.4754	1.7404
Min	.0164	.0082	.0278	.0286	.0236	.0278	.0343
Avg	.3527	.3652	.3855	.3794	.5310	.5578	.8508

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344004 / 33 KV MIDC WASHIM SUB-

STATION

Feeder No / Name : 205 / TAMSALA GAOTHAN FDR

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.0838	.1886	.1402	.132	.0739	.1867
2	.1132	.0838	.1886	.1595	.132	.0739	.1867
3	.1132	.0838	.1886	.1372	.132	.0924	.1867
4	.132	.1372	.1867	.1387	.132	.0924	.1867
5	.1509	.1372	.1867	.156	.1509	.1478	.1867
6	.2263	.2402	.1867	.1543	.1509	.1294	.1867
7	.2075	.2402	.1867	.1753	.2263	.2772	.1867
8	.2829	.2402	.1867	.1715	.2829	.2587	.2801
9	.3395	.2218	.1867	.2427	.2075	.3511	.2801
10	.2829	.1109	.181		.2263	.3696	.2801
11	.1848	.1886	.2561	.132	.3018	.1867	.2715
12	.1109	.1867	.2454	.1132	.1848	.1867	.2378
13	.1109	.1867	.2204	.132	.1848	.1867	.1448
14	.1109	.1867	.2155	.132	.2218	.1867	.2353
15	.1478	.1867	.2328	.1509	.3696	.1867	.1991
16	.1663	.1867	.1629	.2075	.3326	.1867	.2195
17	.1109	.1867	.128	.2263	.3326	.2801	.2534
18	.2054	.1867	.1753	.1886	.3881	.1867	.1829
19	.1478	.1867	.1734	.2075	.3326	.1867	.181
20	.1478	.1867	.1578	.1698	.1663	.1867	.1791
21	.0924	.1867	.1433	.1509	.1294	.1867	.1463
22	.0924	.1867	.1463	.132	.1294	.1867	.112
23	.0829	.1867	.1372	.132	.1109	.1867	.1109
24	.132	.0829	.1886	.1991	.132	.0532	.1867
Max	.3395	.2402	.2561	.2427	.3881	.3696	.2801
Min	.0829	.0829	.128	.1132	.1109	.0532	.1109
Avg	.1585	.1705	.1854	.1630	.2121	.1850	.2003

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344004 / 33 KV MIDC WASHIM SUB-

STATION

Feeder No / Name : 209 / 11 KV ANANT SAHAKARI SUT

SHEDDABLE RURAL

GIRNI Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.4904	.4715	.462	.5093	.415	.4715
2	.4715	.4904	.4715	.4854	.5281	.3961	.4668
3	.4527	.5093	.4715	.4668	.5093	.4338	.4668
4	.4904	.5093	.4715	.4805	.5093	.4904	.4715
5	.4904	.5281	.4715	.5041	.5281	.4527	.4715
6	.5093	.547	.4715	.4294	.547	.4904	.4715
7	.4715	.547	.4715	.4854	.5093	.5041	.4715
8	.4338	.4108	.4715	.4668	.4715	.5041	.4715
9	.3018	.3174	.5281	.4904	.3395	.415	.3772
10	.5281	.5041	.5228	.5175	.415	.4904	.4715
11	.5093	.4715	.4854	.4527	.4904	.4715	.4066
12	.5281	.4715	.4854	.5093	.415	.5281	.5281
13	.5281	.4668	.5041	.5658	.4715	.1867	.5228
14	.5093	.4715	.5228	.5281	.4904	.4715	.4854
15	.5093	.5093	.5415	.547	.4527	.4715	.4527
16	.5093	.4715	.4668	.547	.5228	.4715	.547
17	.4338	.4715	.4294	.4338	.4668	.4715	.4481
18	.3961	.4715	.3881	.5281	.4668	.4715	.3142
19	.5093	.4715	.462	.5093	.4854	.4715	.4481
20	.5281	.4715	.4805	.4338	.4294	.4715	.4251
21	.5281	.4715	.4481	.4904	.4527	.4715	.5228
22	.5093	.4715	.3881	.5093	.4904	.4715	.5359
23	.5281	.4715	.4668	.5281	.4338	.4715	.4854
24	.4338	.5093	.4715	.4854	.5281	.4715	.4715
Max	.5281	.547	.5415	.5658	.547	.5281	.547
Min	.3018	.3174	.3881	.4294	.3395	.1867	.3142
Avg	.4818	.4802	.4735	.4940	.4776	.4569	.4669

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344025 / KALAMBA SUBSTATION

Feeder No / Name : 201 / KAJALAMBA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.738	.6748				
2	.7371	.6902				
3	.7217	.6902				
4	.7371	.6902				
5	.7985	.7668				
6	.8599	.7975				
7	1.167	1.0736				
8	1.4435	1.348	.965			
9	1.4263		1.2714			
10			1.1948	1.1335	.9497	.9497
11			1.0263	1.1795	1.2254	1.1488
12			1.348	1.2561	1.2714	1.1488
13			1.4705	1.2561	1.3326	1.1335
14			1.3633	1.302		1.1335
15			1.2867		1.2254	1.1642
16			.9038	1.3786	1.2407	1.1948
17			1.2561	1.3326	1.2407	1.2407
24	.7226	.6441				
Max	1.4435	1.348	1.4705	1.3786	1.3326	1.2407
Min	.7217	.6441	.9038	1.1335	.9497	.9497
Avg	.9352	.8195	1.2086	1.2626	1.2123	1.1393

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344025 / KALAMBA SUBSTATION

Feeder No / Name : 202 / 11 KV PARDI TAKMOR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.515				.2263	.6337	.5583
2	.515				.1962	.679	
3	.515				.2112	.6036	.5583
4	.5143				.2112	.5432	.5576
5	.5748				.2263	.9959	.6329
6	.6656				.2263	.6187	.6329
7	.7705				.3471	.7695	.7836
8	.8763				1.0562	.9959	.9946
9	1.1331				.9657	1.011	1.0248
10	.695	.7101	.7846				
11	.7252	.8007	.845				
12	.7554	.8612	.8763				
13	.7754	.8914	.8158				
14	.7705	.8612	.8158				
15	.6043	.8158	.7545				
16	.7101	.7403	.7243				
17	.6345	.7092	.7695				
24	.4891			.2263		.5885	.5583
Max	1.1331	.8914	.8763	.2263	1.0562	1.011	1.0248
Min	.4891	.7092	.7243	.2263	.1962	.5432	.5576
Avg	.6800	.7987	.7982	.2263	.4074	.7439	.7001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344025 / KALAMBA SUBSTATION

Feeder No / Name : 203 / KALAMBA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1986	1.2361	1.1424	1.3484	1.1799	1.1799	1.1237
2	1.1986	1.3484	1.2922	1.3859	1.3297	1.4046	1.1237
3	1.4608	1.3672	1.4982	1.3859	1.6481	1.6106	1.4046
4	1.723	1.7979	1.8541	1.723	1.7604	1.6293	1.4982
10	1.3297	1.4795	1.6106	1.6481	1.2548	1.4233	1.5919
11	1.0675	.9177	1.03	1.0488	.6929		.8428
12	.6929	.7304	.6555	.7117	.6555	.6368	.6742
13	.5618	.6368	.5993	.7304	.4869	.5618	.6368
14	.5618	.6742	.5993	.6368	.6555	.5618	1.3859
15	.5431	.6742	.5993	.6742		.6368	.5993
16	.7491	.7679	.5618	.6929	.7304	.8802	.6742
17	1.1237	1.0862	.9551	.9364	.9551	.8802	.8989
18	2.0226	1.6855	1.9103	1.5732	1.6855	1.6855	1.517
19	2.0788	1.9665	1.9665	1.7979	1.9665	1.9665	1.9103
20	1.7979	1.7979	1.7979		1.6855	1.7979	1.7417
21	1.5732	1.5732	1.6293	1.517		1.5732	1.5732
22	1.4046	1.4046	1.4608	1.3484	1.2922	1.5732	1.3484
23		1.1799	1.3484	1.2361		1.0675	1.1799
24	1.2173	1.7604	1.1237	1.1237		1.1237	1.0675
Max	2.0788	1.9665	1.9665	1.7979	1.9665	1.9665	1.9103
Min	.5431	.6368	.5618	.6368	.4869	.5618	.5993
Avg	1.2392	1.2676	1.2439	1.1955	1.1986	1.2329	1.1996

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344028 / 33 KV CIVIL LINE SUBSTATION

Feeder No / Name : 201 / 11 KV MAHADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3027	.3033	.2849	.2844	.2846	.2662	.3216
2	.3027	.3033	.2849	.2844	.2846	.2657	.303
3	.3027	.3033	.2849	.2844	.2841	.2852	.2841
4	.3027	.3033	.2849	.2646	.2841	.2852	.2844
5	.3027	.3033	.2849	.2846	.2858	.3042	.2657
6	.3595	.3412	.3229	.3803	.3239	.3429	.3229
7	.473	.455	.3799	.381	.4001	.4382	.4369
8	.4919	.4929	.4753	.4554	.4373	.4744	.5319
9	.5108	.4545	.4749	.472	.4179	.4749	.5693
10	.455	.4343	.4725	.4343	.4554	.4527	.4734
11	.4154	.3772	.4321	.4141	.3945	.412	.3953
12		.3738	.4299	.3566	.3727	.4264	.3961
13	.3925	.3361	.3515	.3374	.3381	.3551	.3206
14	.3381	.3193	.3364	.3364	.3526	.3164	.3206
15	.3371	.2981	.2809	.3177	.3357	.3177	.3206
16	.3742	.3357	.2981	.3361	.3555	.3181	.3398
17	.3925	.3181	.334	.3889	.3929	.3566	.3547
18	.4481	.4687	.4078	.4499	.4845	.4879	.4099
19	.4894	.4154	.4634	.4499	.4854	.4904	.4513
20	.4692	.4162	.4264	.4124	.449	.4338	.4518
21	.4137	.4162	.3893	.3937	.4316	.4154	.4329
22	.3761	.3776	.3753	.3753	.378	.3784	.3784
23	.3385	.3213	.321	.3187	.3027	.3216	.3203
24	.3216	.3033	.2849	.2841	.3	.2849	.3024
Max	.5108	.4929	.4753	.472	.4854	.4904	.5693
Min	.3027	.2981	.2809	.2646	.2841	.2657	.2657
Avg	.3874	.3655	.3617	.3624	.3680	.3710	.3745

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344028 / 33 KV CIVIL LINE SUBSTATION

Feeder No / Name : 202 / 11 KV CHIKHALI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.057	.0569	
2				.0598	.0569	
3				.0584	.0569	
4				.0569	.0598	
5				.0569	.0612	
6				.0598	.0712	
7				.0769	.0868	
8				.1708	.1423	
9				.1992	.1708	
10	.1289	.1143	.1341			.0512
11	.1719	.1002	.1427			
12	.1433	.1	.1085			.1423
13	.1145	.0857	.1284			.1423
14	.1145	.1142	.1027			.1283
15	.1002	.0999	.1156			.1139
16	.0858	.1042	.1299			.1281
17	.0858	.1313	.1698			.1281
24				.0584	.0541	
Max	.1719	.1313	.1698	.1992	.1708	.1423
Min	.0858	.0857	.1027	.0569	.0541	.0512
Avg	.1181	.1062	.1290	.0854	.0817	.1192

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344028 / 33 KV CIVIL LINE SUBSTATION

Feeder No / Name : 203 / 11 KV URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4909	.4527	.4343	.4347	.4347	.4338	.415
2	.4909	.4531	.4343	.4351	.4356	.4536	.3776
3	.5098	.4536	.4343	.4343	.4545	.4369	.473
4	.5287	.4924	.472	.4725	.5113	.5129	.5308
5	.5475	.5497	.5287	.5313	.5877	.6066	.4934
6	.7552	.759	.6797	.6608	.759	.756	.6642
7	1.0007	.9678	.8874	.9298	.9412	.9668	.9118
8	.9251	1.0626	1.0007	1.0195	1.0363	1.1374	1.0247
9	.8479	.9629	.96	.9639	.9619	.8143	.9986
10	.8069	.793	.8462	.8632	.8366	.771	.8488
11	.6694	.6568	.7671	.6958	.688	.7109	.7175
12	.551	.5556	.6722	.5618	.5376	.5578	.6452
13	.537	.5326	.5191	.5498	.5392	.5493	.5292
14	.4422	.481	.4444	.4454	.4639	.4954	.4909
15	.4775	.482	.482	.4449	.4553	.4765	.5098
16	.4995	.5	.5381	.5376	.4918	.478	.4909
17	.5741	.4251	.6521	.6303	.6251	.6435	.6212
18	.7624	.4444	.8536	.7786	.8757	.874	.7996
19	.9158	.9008	.8536	.8527	.8624	.8545	.9288
20	.8053	.8053	.7608	.7971	.8078	.6873	.8757
21	.7311	.7117	.6866	.6674	.7702	.6873	.6958
22	.5999	.5847	.5853	.5818	.6231	.5741	.5664
23	.5249	.5093	.5098	.5087	.4909	.4825	.4909
24	.5287	.4904	.4531	.4531	.4536	.472	.4338
Max	1.0007	1.0626	1.0007	1.0195	1.0363	1.1374	1.0247
Min	.4422	.4251	.4343	.4343	.4347	.4338	.3776
Avg	.6468	.6261	.6440	.6354	.6518	.6430	.6472

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344028 / 33 KV CIVIL LINE SUBSTATION

Feeder No / Name : 204 / 11 KV CIVIL HOSPITAL

SHEDDABLE RURAL

EXPRESS Feeder KV- 11 /
OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0229	.0248	.0229	.0229	.0248	.0229	.0248
2	.0229	.0248	.0229	.021	.0248	.0229	.0248
3	.0229	.0248	.0229	.021	.0229	.0229	.0229
4	.021	.0248	.0229	.021	.0229	.0229	.0229
5	.021	.0248	.0229	.021	.0229	.0229	.0229
6	.0229	.0229	.0229	.021	.0229	.0229	.0229
7	.0191	.021	.021	.0191	.0229	.0191	.0229
8	.0229	.021	.0191	.021	.0191	.0191	.0229
9	.0324	.021	.0191	.0191	.021	.0229	.0324
10	.0362	.0362	.021	.0305	.0305	.0362	.0267
11	.0438	.0381	.0248	.0305	.0419	.0514	.0286
12	.0438	.0343	.0286	.0286	.0381	.0457	.0362
13	.0362	.0362	.0286	.0305	.04	.0381	.0305
14	.0305	.0248	.0286	.0286	.0343	.0362	.0305
15	.0305	.0248	.0191	.0267	.0362	.0305	.0381
16	.0305	.0248	.0267	.0248	.0381	.0248	.0305
17	.0324	.021	.0248	.021	.0267	.0343	.0229
18	.0229	.021	.0248	.0248	.0248	.0229	.0229
19	.0248	.0267	.0229	.0248	.0248	.0248	.0248
20	.0248	.0267	.0229	.0248	.0248	.0248	.0248
21	.0248	.0229	.0229	.0248	.0248	.0248	.0248
22	.0248	.0248	.0229	.0248	.0229	.0248	.0229
23	.0267	.0229	.0229	.0229	.0229	.0229	.0248
24	.0229	.0229	.0248	.021	.0248	.0229	.0229
Max	.0438	.0381	.0286	.0305	.0419	.0514	.0381
Min	.0191	.021	.0191	.0191	.0191	.0191	.0229
Avg	.0277	.0258	.0235	.0240	.0275	.0277	.0263

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344028 / 33 KV CIVIL LINE SUBSTATION

Feeder No / Name : 205 / 11KV JAVAHAR NAVODAY

SHEDDABLE RURAL

VIDYALAYA Feeder KV- 11 /
OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0278	.0278					
2	.0278	.0278					
3	.0259	.0278					
4	.0259	.0278					
5	.0259	.0278					
6	.0259	.0241	.0148				
7	.0296	.037	.0148		.0148	.0148	.0148
8	.0315	.0222	.0167	.0185	.0222	.0185	
9	.0259	.0204	.0222	.0185	.0185	.0167	.0167
10	.0259	.0185	.0185	.0167		.0204	.0167
11	.0167	.0148	.0222	.0222			.0204
12	.0185	.0167	.0148				.0167
13	.0167	.0148	.0185		.0167		
14	.0167	.0204	.0185				.0148
15	.0185						.0148
16	.0148						.0148
17	.0148						.0167
18	.0222	.0148			.0222	.0148	
19	.0333	.0148	.0167	.0167	.0222	.0148	
20	.0241		.0222		.0222	.0167	
21	.0222		.0185	.0185	.0222	.0167	
22	.0315			.0185			.0148
23	.0333			.0204			
24	.0315	.0296					
Max	.0333	.037	.0222	.0222	.0222	.0204	.0204
Min	.0148	.0148	.0148	.0167	.0148	.0148	.0148
Avg	.0245	.0228	.0182	.0188	.0201	.0167	.0161

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344028 / 33 KV CIVIL LINE SUBSTATION

Feeder No / Name : 206 / 11 KV COLLECTOR OFFICE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0528	.0472	.0453	.049	.0453	.049	.0566
2	.0528	.0472	.0453	.0472	.0453	.0472	.0585
3	.0528	.0472	.0453	.0472	.0453	.0472	.0604
4	.0547	.0491	.0472	.049	.0453	.049	.0566
5	.0566	.0548	.049	.0509	.049	.0528	.0585
6	.066	.0548	.049	.0509	.0453	.0453	.0566
7	.0604	.0585	.0377	.0472	.0528	.0396	.0453
8	.0622	.0566	.0434	.0358	.0641	.0528	.051
9	.0547	.0415	.0302	.0358	.0509	.049	.0566
10	.0811	.0453	.0321	.0321	.0792	.0773	.0849
11	.1113	.0453	.034	.0415	.1151	.1	.1001
12	.1188	.0528	.0321	.0585	.1132	.1245	.1037
13	.1132	.0585	.0396	.0415	.1037	.1132	.1226
14	.1056	.0453	.0302	.034	.1094	.0981	.0811
15	.1094	.0509	.0302	.0321	.0962	.1	.1095
16	.1075	.0434	.0377	.0358	.1	.1114	.1075
17	.0962	.0415	.0321	.034	.0962	.0887	.0943
18	.0924	.0472	.0358	.0622	.0868	.0983	.0849
19	.0943	.0641	.0547	.066	.0793	.0661	.0698
20	.0641	.0547	.0641	.0604	.068	.0643	.0679
21	.0622	.066	.0585	.0641	.0642	.0586	.0585
22	.0566	.0566	.0622	.0547	.0604	.0567	.0528
23	.0585	.0585	.0547	.0528	.0547	.0661	.0604
24	.0585	.0509	.0509	.0585	.0547	.0509	.0548
Max	.1188	.066	.0641	.066	.1151	.1245	.1226
Min	.0528	.0415	.0302	.0321	.0453	.0396	.0453
Avg	.0768	.0516	.0434	.0476	.0719	.0711	.0730

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344028 / 33 KV CIVIL LINE SUBSTATION

Feeder No / Name : 207 / 11 KV TIRUPATI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1653	.1653	.1653	.1653	.1469	.1469	.1708
2	.1653	.1653	.1653	.1653	.1469	.1469	.1708
3	.1653	.1653	.1653	.1653	.1469	.1469	.1469
4	.1653	.1653	.1653	.1653	.1469	.1469	.1524
5	.1837	.1837	.1653	.1653	.1653	.1469	.1561
6	.2204	.2571	.1837	.1837	.202	.202	.202
7	.2755	.2939	.2204	.2204	.2571	.2755	.2571
8	.2939	.2755	.2571	.2755	.2939	.2939	.3306
9	.3125	.349	.2939	.3122	.2939	.2939	.3122
10	.2942	.2755	.3122	.3122	.2939	.2571	.2939
11	.2574	.2571	.2755	.2755	.2939	.2388	.2393
12	.2388	.2755	.2755	.2388	.2204	.1837	.2206
13	.1837	.202	.202	.1837	.202	.1837	.1839
14	.2022	.1837	.1839	.1653	.1837	.202	.184
15	.2206	.202	.202	.18	.1837	.1837	.1842
16	.1839	.2204	.1837	.202	.1837	.202	.1677
17	.239	.2204	.1837	.2204	.2204	.1653	
18	.2206	.2204	.2204	.2388	.2388	.2204	.2571
19	.2942	.2574	.2755	.2939	.2942	.2755	.2755
20	.2758	.2206	.2755	.2755	.2755	.2755	.2755
21	.2206	.2206	.2388	.2755	.2388	.2388	.2574
22	.2069	.2204	.2388	.202	.2204	.2022	.2204
23	.2022	.1837	.202	.1837	.1837	.2022	.1837
24	.1837	.1837		.1837	.1653	.1653	.1655
Max	.3125	.349	.3122	.3122	.2942	.2939	.3306
Min	.1653	.1653	.1653	.1653	.1469	.1469	.1469
Avg	.2238	.2235	.2196	.2187	.2166	.2082	.2177

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344028 / 33 KV CIVIL LINE SUBSTATION

Feeder No / Name : 208 / 11 KV KATA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.6257	.5803	
2				.6257	.5654	
3				.5952	.5952	
4				.6101	.5803	
5				.6398	.5647	
6				.6398	.6241	
7				.8928	.7876	
8				1.2201	1.0551	
9				1.116	1.07	
10	.9386	.8205	.9237			.9821
11	.8641	.8354	.8801			1.2136
12	.9398	.9249	.7459			.9237
13	.731	.8801	.7459			.9237
14	.8503	.8652	.7449			.7459
15	.91	.731	.7906			.8066
16	.9547	.7906	.7757			.8066
17	.8801	.8801	.8951			.8322
24				.6406	.6101	
Max	.9547	.9249	.9237	1.2201	1.07	1.2136
Min	.731	.731	.7449	.5952	.5647	.7459
Avg	.8836	.8410	.8127	.7606	.7033	.9043

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344041 / 33/11 KV POLE FACTORY S/STN

Feeder No / Name : 202 / 11 KV TAMSHI AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2	.1646	.1509
2				.1974	.2058	.1509
3				.2	.2058	.1509
4				.2143	.2058	.1669
5				.2429	.2469	.1669
6				.2782	.2286	.1646
7				.3286	.3429	.1551
8				.5001	.3704	.2332
9				.4652	.4115	.2606
10	.2921	.3201	.3616			.3292
11	.3018	.3549	.3067			.3246
12	.3292	.3155	.3246			.3755
13	.2435	.3201	.3755			.3704
14	.2667	.3201	.3601			.3292
15	.2681	.3201	.2841			.3246
16	.3111	.3334	.3201			.3201
17	.3111	.2761				.4251
24				.2229	.1646	.1509
Max	.3292	.3549	.3755	.5001	.4115	.4251
Min	.2435	.2761	.2841	.1974	.1646	.1509
Avg	.2905	.3200	.3332	.2850	.2547	.2528

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344041 / 33/11 KV POLE FACTORY S/STN

Feeder No / Name : 203 / 11 KV WANGI AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.2218	.2115	.1372		
2	.2058	.1715	.2115	.1372		
3	.2225	.1858	.2143	.1391		
4	.2429	.1858	.2256	.153		
5	.2429	.2143	.2256	.1808		
6	.3121	.2675	.2972	.2538		
7	.5647	.602	.5639	.3384		
8	1.1385	.8579	.9374	.4401		
9	.873	.6539	.5796	.4144	.3948	
10				.3909		.3715
11				.4633	.4652	.4548
12				.5213	.5914	.4287
13				.5792	.6099	.3292
14				.6468	.6099	.2934
15				.431	.5729	.3517
16				.3418	.4311	.3384
17				.2705	.298	.3807
24	.2957	.1669	.2115	.1509		
Max	1.1385	.8579	.9374	.6468	.6099	.4548
Min	.1867	.1669	.2115	.1372	.298	.2934
Avg	.4285	.3527	.3678	.3328	.4967	.3686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344041 / 33/11 KV POLE FACTORY S/STN

Feeder No / Name : 204 / 11 KV SONKHAS GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5544	.5175	.5729	.5544	.5729	.499	.499
2	.5359	.5175	.5914	.5544	.5544	.499	.499
3	.5914	.5175	.5914	.5544	.5544	.4805	.499
4	.7023	.5729	.6283	.6099	.7207	.5729	.5359
5	.9055	.9425	.961	.9795	.9979	1.0349	.9425
6	1.4415	1.5524	1.4784	1.4969	1.4969	1.4784	1.4969
7	1.7741	1.848	1.7926	1.7741	1.9589	1.922	1.7556
8	1.7187	1.885	1.7187	1.7741	1.8296	1.8665	1.6448
9	1.6263	1.6263	1.6632	1.386	1.8296	1.4969	1.6078
10	1.1273	1.2012	1.2752	1.0903	1.423	1.1458	1.1458
11	.7762	.8316	.8501	.6283	.7207	.6283	.7207
12	.5914	.5914	.5729	.5544	.5729	.5544	.5544
13	.462	.5544	.5175	.5175	.4435	.4435	.4251
14	.5544	.5175	.4251	.4435	.4251	.4435	.4251
15	.4435	.5359	.499	.4251	.499	.4435	.4251
16	.6838	.7392	.4435	.6283	.7023	.4435	.4435
17	.924	1.0349	.8131	.8871	.9795		.8871
18	1.4415	1.4045	1.1827	1.3121	1.3121	1.3306	1.3491
19	1.3306	1.4415	1.3121	1.3121	1.3676	1.4969	1.4415
20	1.0534	1.0349	1.0903	1.0719		1.1458	1.2382
21	.8131	.8501	.8316	1.0719		.8871	.8501
22		.6653	.6099	.7023	.4435	.6468	.8501
23	.5359	.6099	.5359	.5729	.5175	.5729	.5544
24	.3923	.5175	.5729	.5359	.5729	.499	.499
Max	1.7741	1.885	1.7926	1.7741	1.9589	1.922	1.7556
Min	.3923	.5175	.4251	.4251	.4251	.4435	.4251
Avg	.9122	.9379	.8971	.8932	.9316	.8927	.8871

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344041 / 33/11 KV POLE FACTORY S/STN

Feeder No / Name : 206 / LAKHALA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6283	.6468	.6468	.6283	.6468	.6283	.6468
2	.6468	.6468	.6653	.6283	.6468	.5729	.6468
3	.6653	.6653	.6653	.6468	.6468	.5729	.6468
4	.6838	.6653	.6653	.6468	.6653	.6099	.6653
5	.7207	.7392	.7023	.6838	.7392	.6468	.6838
6	.9055	.924	.8131	.8316	.8501	.8501	.8686
7	1.1827	1.2012	1.1273	1.1088	1.1458	1.1643	1.2136
8	1.3121	1.2567	1.2936	1.2012	1.2567	1.2936	1.2936
9	1.2936	1.3121	1.2382	1.1643	1.2752	1.2936	1.3491
10	1.1088	1.1458	1.1643	1.1458	1.1643	1.1458	1.1088
11	1.0719	1.0349	1.1458	1.0164	1.0349	1.1458	1.1088
12	.961	.924	1.0349	.961	.9979	.9979	.9979
13	.924	1.0164	1.0164	.9795	.9795	.9055	.8501
14	.8686	.8131	.8501	.8871	.8686	.8686	.8131
15	.8316	.8686	.8501	.8131	.8501	.8316	.7762
16	.924	.8316	.8131	.8501		.9055	.8501
17	.9979	.961	.9425	.9425		.9425	.924
18	1.2567	1.2012	1.2752	1.1827		1.2012	1.2012
19	1.2752	1.3121		1.1827		1.1643	1.1827
20	1.1273	1.1273	1.1643	1.0719		1.1088	1.1088
21	1.1088	1.1088	1.0534	.8871		.9979	.9979
22	.924	.9979	.8686		.8131	.8501	
23	.7392	.7392	.6838	.6838	.6653	.7207	.6838
24	.6653	.6468	.6468	.6283	.6468	.6653	.6653
Max	1.3121	1.3121	1.2936	1.2012	1.2752	1.2936	1.3491
Min	.6283	.6468	.6468	.6283	.6468	.5729	.6468
Avg	.9510	.9494	.9272	.9031	.8830	.9202	.9254

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344042 / 33/11 KV WAI SUB-STATION

Feeder No / Name : 201 / 11 KV WAI ,WARALA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2347	.2591	.2229			
2	.2155	.2622	.208			
3	.2012	.2591	.2229			
4	.2294	.2401	.2229			
5	.2155	.2429	.2229			
6	.2515		.2229			
7	.3018		.2675			
8	.3277		.2675			
9	.2949		.2526			
10			.2229	.2683	.2134	.1966
11			.2229	.2286	.216	.2622
12			.2378	.2027	.2343	.2458
13			.2458	.176	.2241	.2458
14			.2949	.176	.2591	.213
15			.3048	.208	.2429	.2458
16			.2591	.2675	.2429	.2458
17			.2785	.2559	.2429	.2294
24	.2155	.2591	.2229			
Max	.3277	.2622	.3048	.2683	.2591	.2622
Min	.2012	.2401	.208	.176	.2134	.1966
Avg	.2488	.2538	.2444	.2229	.2345	.2356

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344042 / 33/11 KV WAI SUB-STATION

Feeder No / Name : 202 / 11 KV WAI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5914	.3961	.4525	.6224	.4755	.5487	.543
2	.7023	.4108	.5068	.6979	.4435	.5487	.5914
3	.7316	.462	.5853	.7356	.4435	.6219	.6878
4	.8048	.5487	.8048	.7922	.5914	.6878	.7682
5	.8048	.7392	.7865	.7922	.7023	.7602	.8779
9	.8779	.8962	.8779	1.0164	.924	.724	.695
10	.6219	.6283		.6838	.6767	.6878	.3258
11	.4572	.4668	.499	.5544	.5068	.5487	.5853
12	.3109	.439	.3511	.499	.3982	.4344	.5487
13	.4024	.4024	.3881	.462	.3982	.2926	.4938
14	.5359	.3841	.3881	.4251	.4344	.362	.4207
15	.499	.439	.4435	.3841	.4344	.3439	.439
16	.5175	.5068	.4251	.4904	.4938	.4572	.5487
17	.6036	.6697	.7023	.6219	.6219	.5068	.6219
18	.8596	.823	.7762	.7316	.7964	.7421	.823
19	.823	.8145	.7762	.7682	.7602	.7421	.823
20	.7865	.7865	.6653	.695	.7964	.7964	.7682
21	.7316	.695	.5544	.6283	.724	.6878	.6584
22	.4572	.5249	.5544	.5175	.5853	.6036	.5487
23	.4066	.4706	.499	.4805	.543	.543	.4938
24	.462	.3921	.4344	.4435	.4805	.5487	.543
Max	.8779	.8962	.8779	1.0164	.924	.7964	.8779
Min	.3109	.3841	.3511	.3841	.3982	.2926	.3258
Avg	.6185	.5665	.5735	.6210	.5824	.5804	.6098

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344042 / 33/11 KV WAI SUB-STATION

Feeder No / Name : 203 / 11 KV JAIPUR, DHILLI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.073			1.291	1.2071	.9393
2	1.073			1.3272	1.2071	.9503
3	1.1401			1.3435	1.1934	.9503
4	1.2071			1.2944	1.1934	.9282
5	1.2071			1.0814	1.1797	.9282
6	1.2071			1.1797		.9717
7	1.2071			1.3413		.9175
8	1.2574			.9831		1.0202
9	1.2574			1.1469		1.0364
10	1.3413	1.2407				
11	.7209	1.3603	1.5238			
12	.7373	1.5565	1.4419			
13	.7537	1.4575	1.4083			
14	.8356	1.4899	1.5089			
15	.8192	1.5223	1.5089			
16	1.3108	1.4899	1.3748			
17	1.278		1.3413			
24	1.0898			1.2574	1.1065	.9069
Max	1.3413	1.5565	1.5238	1.3435	1.2071	1.0364
Min	.7209	1.2407	1.3413	.9831	1.1065	.9069
Avg	1.0842	1.4453	1.4440	1.2246	1.1812	.9549

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344043 / 33/11 KV ADOLI SUB-STATION

Feeder No / Name : 201 / 11 KV ADOLI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7628	1.0031	1.2047				.8951
2	.7628	1.0155	1.1674				.8674
3	.7335	1.0311	1.1674				.8631
4	.7922	1.0623	1.1846				.8488
5	.9214	1.1092	1.2176				.8313
6	1.0402	1.1873	1.2319				.8884
7	1.2191	1.3904	1.5497				1.016
8	1.5089	1.781	1.7436				1.3326
9	1.4937	1.6404	1.8953				1.3872
10				1.5779	1.3592	1.4215	
11				1.781	1.5741	1.5896	
12				1.8435	1.5242	1.5202	
13				1.7223	1.3523	1.5254	
14				1.5851	1.382	1.418	
15				1.3717	1.3413	1.4139	
16				1.4937	1.2643	1.3182	
17				1.3565	1.2492	1.1588	
24	.7335	1.0185	1.1874				.8498
Max	1.5089	1.781	1.8953	1.8435	1.5741	1.5896	1.3872
Min	.7335	1.0031	1.1674	1.3565	1.2492	1.1588	.8313
Avg	.9968	1.2239	1.3550	1.5915	1.3808	1.4207	.9780

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344043 / 33/11 KV ADOLI SUB-STATION

Feeder No / Name : 203 / 11 KV KUMBHARKHEDA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4344	.3801	.5068	.4163	.4344	.4163	.4344
2	.4344	.3801	.5792	.3982	.4525	.4525	.4887
3	.4344	.362	.7059	.4525	.4706	.4344	.5611
4	.543	.362	.8688	.5249	.543	.543	.6878
5	.7602	.3982	.9955	.6516	.8688	.8688	.905
6	1.0498	.8507	1.2308	1.1946	1.1584	1.1765	1.3575
7		1.2851	1.5023	1.4299	1.3032		1.5203
8	.905	1.267	1.3756	1.448	1.1222		1.3756
9	.905	1.086	1.3032	1.3032	.9955		1.267
10	.5973	.8326	.9774	1.0498	.724	1.0679	.9231
11	.2896	.543	.6154	.6516	.4706	.5611	.5973
12	.2896	.3982	.4344	.3982	.3439	.3982	.2172
13	.181		.3801	.3439	.2896	.4163	.362
14	.3982		.3982	.3982	.3077	.3439	.3258
15	.3982	.4163	.3982	.4344	.362	.3258	.3439
16	.3982	.5068	.4344	.4344	.3982	.4163	.5068
17	.9593	.6878	.6516	.6878	.6335	.6697	.6697
18	1.1041		.905	1.0498	1.0317	1.1403	1.0498
19	.9774	1.0136	.9955	.905	1.1222	1.1584	1.1765
20	.7783	.8145	.8326	.7783	.9412	.905	.9593
21	.6516	.6878	.6878	.6878	.7059	.724	
22	.5068	.543	.5068	.5249	.5068	.5249	.2353
23	.4163	.4706	.4525	.4706	.4525	.4163	.3982
24	.4344	.3982	.4525	.4344	.4163	.4163	.4163
Max	1.1041	1.2851	1.5023	1.448	1.3032	1.1765	1.5203
Min	.181	.362	.3801	.3439	.2896	.3258	.2172
Avg	.6020	.6516	.7579	.7112	.6689	.6369	.7295

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344044 / 33/11 KV ANSING SUB STATION

Feeder No / Name : 201 / 11 KV EKAMBA GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2353	.2303	.2195		.2218	.2534	
2	.2743	.2328	.2743		.2195	.3292	
3	.3292	.2328	.3142		.2378	.3658	
4	.3696	.2715	.3696		.3361	.4251	
5	.4251	.4525	.4108		.5041	.499	
6	.5415	.4755	.4854				
9					.3547	.4024	
10	.3109	.2534	.2378		.2378	.2587	.2987
11	.2378	.2743	.2378		.1646		.2614
12	.1715	.2103			.1715		.2012
13	.1646	.1907	.2054	.2058	.1402		.1734
14	.1696	.1715		.2058	.1492		.1492
15	.2103	.2481		.2254	.1326		.2012
16	.2126	.2896		.2658	.2303		.2195
17	.2835	.3258	.3547	.3189	.3439		.3326
18	.3841	.4024		.4344	.439		.4024
19	.3801	.4024		.4066	.3841		.3881
20	.3475	.3439		.3511	.3658		.2507
21	.2743	.2896		.3189	.2926		.3109
22	.2629	.2328		.2543	.2534		.2715
23	.2427	.2149		.2481	.2353		.2481
24	.2353	.2303	.1991			.2172	
Max	.5415	.4755	.4854	.4344	.5041	.499	.4024
Min	.1646	.1715	.1991	.2058	.1326	.2172	.1492
Avg	.2887	.2845	.3008	.2941	.2707	.3439	.2649

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344044 / 33/11 KV ANSING SUB STATION

Feeder No / Name : 202 / 11 KV SHRUNGARUSHI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.431	.3612	.4001			
2	.4365	.3612	.3749			
3	.4515	.3658	.3749			
4	.463	.3858	.3858			
5	.4725	.3963	.3963			
6	.4877	.4268	.3864			
7	.5624	.5247	.4515			
8	.679	.5487	.5556			
9	.6401	.5792	.5556			
10					.5312	.4877
12					.6481	
13				.6718	.4725	
14				.6481	.6327	
15				.68	.6481	
16				.6097	.6249	
17				.5792	.5556	
24	.4161	.3572	.4161			
Max	.679	.5792	.5556	.68	.6481	.4877
Min	.4161	.3572	.3749	.5792	.4725	.4877
Avg	.5040	.4307	.4297	.6378	.5876	.4877

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344044 / 33/11 KV ANSING SUB STATION

Feeder No / Name : 203 / 11 KV UMARA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2054	.192	
2				.2027	.1974	
3				.2027	.2	
4				.2054	.2143	
5				.2201	.2115	
6				.2143	.2317	
7		.1524		.2679	.2397	
8				.3121	.2743	
9				.3521	.2896	
10	.442	.381	.3658			.3647
11	.5401	.4572	.4481			.5121
12	.5556	.5401				.5401
13	.571	.5312	.5636			.5093
14	.5335	.5376				.4938
15	.5247	.4999				.5247
16	.4268	.4784				.5247
17	.4268	.381	.3481			.4572
24				.2	.1833	
Max	.571	.5401	.5636	.3521	.2896	.5401
Min	.4268	.1524	.3481	.2	.1833	.3647
Avg	.5026	.4399	.4314	.2383	.2234	.4908