

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054007 / 33/11KV S/S AMBAJOGAI

Feeder No / Name : 201 / 11 KV HOSPITAL FEEDER
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715		.1543
2	.1715	.1543		.1543
3	.1715	.1886		.1886
4	.1715	.2229		.2058
5	.1715	.2743		.2229
6	.2401	.3086		.2572
7	.3429	.3429		.3772
8	.3601	.4115	.3429	.4458
9	.3944	.3944	.3258	.4115
10	.3258	.3772	.4115	.3601
11	.3258	.3086	.3429	.3086
12	.3086	.2743	.3086	.2572
13	.2743	.2743	.2572	.2229
14	.2229		.2058	.2058
15	.1886	.1715		.1886
16	.1715	.1886	.2058	.1886
17	.2572		.2229	
18	.2915	.2401	.3086	.2743
19	.2572		.2743	
20	.2572	.2743	.2572	.2743
21	.2401		.2743	
22	.2229	.2572	.2572	
24	.1886	.1715	.1886	.1715
Max	.3944	.4115	.4115	.4458
Min	.1715	.1543	.1886	.1543
Avg	.2490	.2635	.2789	.2563

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054007 / 33/11KV S/S AMBAJOGAI

Feeder No / Name : 202 / 11 KV YOGESHWARI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.4115		.4115
2	.4115	.4115		.4115
3	.4115	.4115		.4801
4	.4115	.4115		.5487
5	.4801	.5487		.6516
6	.6859	.7545		.7545
7	.8916	.9602		1.0288
8	1.0288	.9602	1.0288	1.0974
9	.8916	.9602	.8916	1.0288
10	.7545	.823	.6859	.823
11	.6859	.6859	.6859	.7545
12	.6173	.6173	.6859	.6173
13	.6173	.5487	.6173	.5487
14	.4801		.4115	.5487
15	.4801	.4115		.5487
16	.5487	.5487	.5487	.4801
17	.6859		.6173	
18	.823	.8916	1.0288	.9602
19	.8916		1.0288	
20	.7545	.8916	.823	.8916
21	.6859		.7545	
22	.5487	.6859	.6859	
24	.4115	.4115	.4801	.4801
Max	1.0288	.9602	1.0288	1.0974
Min	.4115	.4115	.4115	.4115
Avg	.6352	.6498	.7316	.6877

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054007 / 33/11KV S/S AMBAJOGAI

Feeder No / Name : 204 / 11 KV LOKHANDI FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.061		.061
2		.061		
3		.061		.061
4		.061		.061
5		.061		.061
6	.061	.061		.061
7	.061	.061		.061
8	.061	.061		.061
9	.9145	1.4632	1.2193	
10	1.829	2.0729	1.89	.9145
11	1.829		1.89	
12	.4268	1.2193	1.829	2.1948
13	.8535	2.0729	1.768	2.1338
14	.9755	2.1948	2.3777	1.5242
15	1.166	2.3777		2.2558
16	.9145	.3048	2.0729	1.3413
17	.061		.0762	
18	.061		.061	
19	.061		.0914	
20	.061		.061	
21	.061		.1829	
22	.061		.0914	
24		.061		.061
Max	1.829	2.3777	2.3777	2.2558
Min	.061	.061	.061	.061
Avg	.5563	.7659	1.0470	.7752

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054007 / 33/11KV S/S AMBAJOGAI

Feeder No / Name : 205 / 11 KV MOREWADI-SAIGAON-
FEEDER Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6859		.7545
2	.6859	.6859		.7545
3	.6859	.6859		.823
4	.823	.823		1.0288
5	.8916	1.0974		1.166
6	1.3717	1.3717		1.4403
7	1.8861	1.8519		1.9204
8	1.9204	1.9204	1.8519	1.9204
9	1.7147	1.8519	1.8519	1.7147
10	1.6461	1.4403	1.4403	1.5089
11	1.3032	1.2346	1.166	1.3032
12	1.166	1.0974	1.0974	.9602
13	1.0288	.4115	1.0974	.9602
14	.9602	.4115	.8916	.9602
15	.9602	1.166		.8916
16	1.0974	1.166	1.0288	1.0974
17	1.3032		1.3717	
18	1.6461	1.5775	1.7147	1.5775
19	1.5775		1.7147	
20	1.5089	1.5089	1.4403	1.5089
21	1.3717		1.3032	
22	1.0288	1.0288	1.0974	
24	.6859	.7545	.7545	.823
Max	1.9204	1.9204	1.8519	1.9204
Min	.6859	.4115	.7545	.7545
Avg	1.2152	1.1386	1.3215	1.2165

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422] BU 2569

Substation No/ Name :- 054007 / 33/11KV S/S AMBAJOGAI

Feeder No / Name : 206 / 11 KV WAGHALE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.9069		.9602
2	.9602		1.0136
3	.9602		1.0669
4	1.0136		1.1203
5	1.0136		1.2269
6	1.1203		1.3336
7	1.387		1.6004
8	1.547	1.4403	1.4403
24	.8535	.8002	.8535
Max	1.547	1.4403	1.6004
Min	.8535	.8002	.8535
Avg	1.0847	1.1203	1.1795

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054007 / 33/11KV S/S AMBAJOGAI

Feeder No / Name : 207 / 11 KV SHIVAJI CHOWK FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429		.3429
2	.3429	.3429		.3429
3	.3429	.3429		.4115
4	.4115	.4115		.4801
5	.4115	.4801		.583
6	.6859	.6173		.6859
7	.823	.7545		.823
8	.823	.8916	1.0288	.8916
9	.823	.823	.8916	.823
10		.7545	.823	.823
11	.6859	.6859	.6859	.7545
12	.0686	.6859	.6173	.6173
13	.8916	.6173	.6173	.5487
14	.6859	.6173	.6173	.5487
15	.5487	.5487		.5487
16	.5487	.6173	.5487	.5487
17	.7545		.6173	
18	.8916	.8916	.9602	.8916
19	.8916		.9602	
20	.823	.9602	.823	.823
21	.6859		.6859	
22	.4801	.5487	.4801	
24	.3429	.3429	.4115	.4115
Max	.8916	.9602	1.0288	.8916
Min	.0686	.3429	.4115	.3429
Avg	.6048	.6139	.7179	.6263

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054007 / 33/11KV S/S AMBAJOGAI

Feeder No / Name : 208 / 11 KV WATER WORKS FEEDER NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		.0381		
8		.0381		
9		.0381	.0381	
10		.0381	.0381	
11		.0381		
12	.0381	.0381	.0381	
13	.0381	.0381	.0381	
14	.0381		.0381	.0381
15	.0381	.0381		.0381
16	.0381	.0381	.0381	.0381
17	.0381			
18	.0381	.0457		.0381
19	.0381		.0381	
20	.0381	.0057	.0476	.0572
21	.0381		.0381	
22		.0381	.0381	
Max	.0381	.0457	.0476	.0572
Min	.0381	.0057	.0381	.0381
Avg	.0381	.0360	.0391	.0419

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054007 / 33/11KV S/S AMBAJOGAI

Feeder No / Name : 209 / 11KV GFSS JOGAIWADI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.1143		.1524
2	.0953	.0762		.1143
3	.0953	.0762		.0762
4	.0953	.0762		.0762
5	.0953	.1143		.0762
6	.1715	.1524		.0762
7	.2286	.1905		.1905
8	.2096	.1524	.1524	.1905
9	.2286	.1524	.1905	.1524
10	.1524	.1524	.1524	.1524
11	.0762	.1524	.1524	.1524
12	.1524	.1524	.1524	.1524
13	.1524	.1524	.1524	.1524
14	.0953	.1524	.1143	.1524
15	.1524	.0762		.1524
16	.1524	.1524	.1524	.1524
17	.1905		.1524	
18	.1905	.1905	.1715	.1524
19	.1524		.1905	.1524
20	.1524	.1524	.1524	.1524
21	.1524		.1524	
22	.1524	.1524	.1524	
24	.1143	.1143	.1524	.1524
Max	.2286	.1905	.1905	.1905
Min	.0762	.0762	.1143	.0762
Avg	.1458	.1353	.1562	.1391

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054014 / 33 KV BARDAPUR

Feeder No / Name : 201 / 11 KV MORWAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0741	.8066	.5601	1.1271
2		1.2342	.8755	.7698	1.3139
3		1.128	.9385	.9499	1.3347
4		1.3171	1.2102	1.1852	1.3786
5		1.4922	1.4601	1.4152	1.5732
6		1.5109		1.6159	1.813
7		1.5912	1.7907	1.812	1.89
8		2.0954	1.8509		.5281
9		.1848	.2068	.2195	
10		.1658	.1509	.216	.184
11		.1128	.1326	.095	
12		.0762		.095	.0764
13		.1135	.1125	.1128	.0949
14		.0758	.1132		.0917
15		.0943	.0742	.1139	.0746
16		.0906	.0736	.1486	.0925
17		.1436	.146	.1789	.1665
18		.185	.1799	.2515	
19			.1783		.2681
20		.2318	.2521	.2419	.2067
21		.1789	.2167		.189
22	.1848		.0975	.2119	.1734
23	.7378		.0642		.4806
24		1.0727	.6828	.3345	.6328
Max	.7378	2.0954	1.8509	1.812	1.89
Min	.1848	.0758	.0642	.095	.0746
Avg	.4613	.6747	.5279	.5541	.6519

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054014 / 33 KV BARDAPUR

Feeder No / Name : 202 / 11 KV BARDAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5913	.5176	.6426	.4409
2		.5937	.5697	.5712	.6228
3		.7042	.5759	.5517	.6776
4		.873	.655	.6481	.7024
5		.7127	.791	.7343	.7315
6		.7888		.7949	.9379
7		.7659	1.0928	.7984	1.0022
8		1.0776	1.2872		.375
9		.5609	.41	.5106	
10		.4048	.2666	.493	.316
11		.3704	.317	.3131	
12		.3371		.2775	.2139
13			.2469	.1728	.2469
14		.2342	.2519	.2116	.1976
15		.2277	.2257	.2519	
16		.2593	.2229	.2984	.2136
17		.3522	.2716	.373	.4319
18		.4919	.389	.4295	
19		.7153	.4362		.519
20		.4275	.4094	.3958	.4327
21		.3467	.3382		.3987
22	.2674		.3608	.3584	.3721
23	.4207		.5292		.3457
24		.5681	.4431	.5121	.3725
Max	.4207	1.0776	1.2872	.7984	1.0022
Min	.2674	.2277	.2229	.1728	.1976
Avg	.3441	.5430	.4822	.4669	.4775

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054014 / 33 KV BARDAPUR

Feeder No / Name : 203 / 11 KV JAWALGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0934	.0709	.0908	.2054
2		.0804	.072	.1303	.187
3		.0806	.0732	.1303	.1771
4		.1056	.0896	.1593	.1573
5		.1203	.1126	.1856	.1882
6		.2054	.144	.2031	.2195
7		.208	.1756	.2061	.2185
8		.192	.1877		.2035
9		.3921	1.2346	.5887	
10		1.8229	1.9506	1.6398	1.9845
11		1.8697	2.1523	2.5859	2.1653
12		1.262		2.5372	1.6297
13		1.1629	1.8435	2.1965	1.5713
14		1.3547	1.5364	1.918	1.7175
15		.3426	1.8474	2.5793	1.7175
16		.9858	2.1191	2.5319	1.6108
17		.1102	.1738	.0547	
18		.163	.2263	.1433	.1185
19		.1547	.214		.1456
20		.1628	.1723	.4053	.1102
21		.1101	.1438		.199
22	.1311		.1228	.3398	.1169
23	.11		.1048		.1085
24		.0895	.0642	.0937	.2598
Max	.1311	1.8697	2.1523	2.5859	2.1653
Min	.11	.0804	.0642	.0547	.1085
Avg	.1206	.5031	.6448	.9360	.6823

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054031 / 33 KV DHANORA S/S

Feeder No / Name : 201 / 11 KV RADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	2.8675			2.3205
13	2.7018			2.8178
14	1.1401			2.5149
15	2.7018			3.0178
16	2.7183	2.5149		
17	2.6852	2.5149	2.8826	
18	2.3868	2.3472	2.8502	
19	2.0719	2.3472	2.6658	
Max	2.8675	2.5149	2.8826	3.0178
Min	1.1401	2.3472	2.6658	2.3205
Avg	2.4092	2.4311	2.7995	2.6678

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054031 / 33 KV DHANORA S/S

Feeder No / Name : 202 / 11 KV AKOLA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3429	.2667
2			.3048	.2477
3			.2667	.2477
4			1.2955	1.186
5			1.4746	1.4083
6			1.6385	1.6518
7			1.9989	1.9498
8		1.6324	2.13	2.1464
9	1.8404			2.2611
10	1.5813			2.3922
11	1.7341			2.0645
20	.5525	.6097	.6478	
21	.4001	.5716	.4763	
22	.2667	.5716	.381	
23	.2477	.4954	.3239	
24		.2286	.381	.2667
Max	1.8404	1.6324	2.13	2.3922
Min	.2477	.2286	.2667	.2477
Avg	.9461	.6849	.8971	1.3407

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054031 / 33 KV DHANORA S/S

Feeder No / Name : 203 / 11 KV MAMDAPUR PATODA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.679	.679
2			.679	.7922
3			.8676	.9054
12	3.2023			2.6825
13	3.0178			3.1855
14	3.2861			2.8502
15	2.9843			3.1855
16	3.0514	3.152		3.1855
17	2.9508	3.152		
18	2.5484	2.6825	2.8837	
19	2.3703	2.5149	2.6993	
20	1.251	1.2449	1.2696	
21	.9896	1.3203	1.1016	
22	.6908	1.2449	.7655	
23	.6224	.9431	.6602	
24		.5281	.7545	.5658
Max	3.2861	3.152	2.8837	3.1855
Min	.6224	.5281	.6602	.5658
Avg	2.2471	1.8647	1.236	2.0035

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054046 / 33 KV APEGAON

Feeder No / Name : 201 / 11 KV APEGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0746		.0746	
2	.0746		.0746	
3	.0746		.0746	.0761
4	.0746		.0746	
5	.0746		.0746	
6	.0746		.0746	.0761
7	.0746		.0746	
8	.0746		.0746	.0761
9	.9326		.9326	.9516
10	1.4922		2.2382	1.3323
11	2.3196	.9326	2.4247	2.8549
12	2.3196	2.518	2.4247	2.8549
13	2.3196	2.6113	2.4247	3.4259
14	2.5979	2.6113	2.4247	3.4259
15	3.3402	2.6113	2.4247	3.4259
16	3.3402	2.6113	2.4247	3.4259
17	.0742	.0746	.0746	.0761
18	.0742	.0746	.0746	.0761
19	.0742	.0746		.0761
20		.0746		.0761
21	.0742	.0746	.0746	.0761
22		.0746		.0761
23	.0742	.0746	.0746	.0761
24	.0746		.0746	.0761
Max	3.3402	2.6113	2.4247	3.4259
Min	.0742	.0746	.0746	.0761
Avg	.8957	1.1091	.8899	1.1860

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054046 / 33 KV APEGAON

Feeder No / Name : 202 / 11 KV TATBORGAEON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2239		1.5337	.8288
2	1.2239		1.5337	.8288
3	1.3769		1.8404	.8288
4	1.6829		1.9171	.8288
5	1.8359		1.9938	1.1603
6	2.1418		2.1472	1.4918
7	2.2948		2.3005	2.3205
8	2.2948		2.3005	2.9835
9	.0612		.0613	.0663
10	.0612		.0613	.0663
11	.0613	.0613	.0613	.0663
12	.0613		.0613	.0663
13	.0613		.0613	.0663
14	.0613		.0613	.0663
15	.0613		.0613	.0663
16	.0613	.0613	.0613	.0663
17	.0613	.0613	.0613	.0663
18	.0613	.0613	.0613	.0663
19	.0613	.0613		.0663
20		.0613		.0663
21	.0613	.0613	.0663	.0663
22		.0613		.0663
23	.6135	.6135	.663	.663
24	1.0709		.7668	.8288
Max	2.2948	.6135	2.3005	2.9835
Min	.0612	.0613	.0613	.0663
Avg	.7498	.1227	.8417	.5705

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054046 / 33 KV APEGAON

Feeder No / Name : 203 / 11KV GFSS APEGAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1551		.1551	.1257
2	.1551		.1551	.1257
3	.1551		.1551	.1257
4	.1551		.1861	.1257
5	.1551		.2171	.1257
6	.1861		.2171	.1572
7	.2171		.2171	.2201
8	.2171		.1861	.2201
9	.1861		.1551	.2515
10	.1551		.1551	.2201
11	.1236	.1241	.1551	.1257
12		.093	.1551	.1257
13	.0773	.1241	.1551	.1572
14	.0773	.1241	.1241	.1572
15	.0773	.1241	.1241	.1257
16	.0773	.093	.0775	.0786
17	.0927	.1551	.1551	.1572
18		.1551	.1551	.1572
19	.1545	.1861	.2201	.2201
20	.2171	.2171	.2201	.2201
21	.2163	.2171	.2201	.1886
22	.1854	.1861	.1886	.1572
23	.1545	.1551	.1572	.1572
24	.1551		.1551	.1572
Max	.2171	.2171	.2201	.2515
Min	.0773	.093	.0775	.0786
Avg	.1521	.1503	.1692	.1618

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054064 / 33 KV SAIGAON

Feeder No / Name : 201 / 11 KV SAIGAON FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2743	.1981	.2534	.2926
2		.2743	.1981	.2534	.2743
3		.2743	.1829	.2896	.2561
4		.2321	.2469	.3887	.4144
5		.2984	.3953	.421	.4641
6		.3481	.5079	.4858	.4973
7		.3978	.5935	2.8664	.5967
8		.5636	.7712	.7287	.6464
9		.5636	.5868	.583	.6133
10		.7362	.583	.6299	
11		.6001	.5506	.5636	.4287
19			.6154		
20		.4681	.4706	.6219	.5083
21	.3841	.3315	.4344	.4755	.3561
22	.3109	.2812	.362	.4024	.3113
23	.3109	.2134	.2896	.3292	.25
24		.2926	.1981	.2534	.3109
Max	.3841	.7362	.7712	2.8664	.6464
Min	.3109	.2134	.1829	.2534	.25
Avg	.3353	.3844	.4226	.5966	.4147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054064 / 33 KV SAIGAON

Feeder No / Name : 202 / 11 KV SUGAON FEEDER
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.132	.1334	.1086	.1132
2		.1509	.1334	.1267	.132
3		.1698	.1334	.1267	.1698
12			.8421		1.4575
13		1.6518	1.3765		1.6385
14		1.3603	1.6194		.5401
15		.9602	1.5384	.7926	1.6057
16		1.6194	1.5384	1.2803	1.7814
17		1.5203	1.2955		1.6004
18		1.3603	1.3765	1.1126	1.4661
19		1.2193	1.2955	.9755	1.3717
20		.1509	.181	.1509	.1886
21	.1698	.1698	.181	.1698	.1524
22	.1509	.132	.1448	.132	.1334
23	.1509	.1143	.1448	.1132	.1334
24		.132	.1143	.1086	.1132
Max	.1698	1.6518	1.6194	1.2803	1.7814
Min	.1509	.1143	.1143	.1086	.1132
Avg	.1572	.7229	.7530	.4331	.7873

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054064 / 33 KV SAIGAON

Feeder No / Name : 203 / 11 KV POKHARI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4572	.4108	.3982	.4024
2		.4024	.3772	.3982	.3841
3		.3658	.3772	.5068	.3658
4		1.0911	1.2651	1.4575	1.4548
5		1.2651	1.6194	1.6194	1.6604
6		1.6604	1.873	1.8623	1.9766
7		1.8185	2.2634	2.1862	2.2138
8		2.0715	2.6621	2.3482	2.2929
9		2.0557	2.5095	2.3482	2.0557
10		2.3205	2.4291	2.2929	2.0119
11		2.0481	2.2672	2.2138	1.4419
19			.905		
20		1.0269	.8688	1.0974	1.0829
21	.7316	.8589	.724	.8779	.8215
22	.5853	.6535	.6516	.567	.679
23	.5487	.5415	.5792	.4938	.5228
24		.5121	.415	.4706	.4572
Max	.7316	2.3205	2.6621	2.3482	2.2929
Min	.5487	.3658	.3772	.3982	.3658
Avg	.6219	1.1968	1.3057	1.3212	1.2390

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054064 / 33 KV SAIGAON

Feeder No / Name : 204 / Dudhdairy Express
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0739	.1478	.1619	.1478
2		.0934	.1294	.1619	.1294
3		.0554	.1294	.1457	.1294
4		.0739	.1307	.1629	.037
5		.0739	.1307	.1448	.037
6		.0554	.1307	.1448	.037
7		.056	.1307	.1134	.0554
8		.0554	.2054	.1134	.0185
9		.0018	.1867	.0648	.0018
10		.0373	.1619	.0739	.0373
11		.0373	.1296		.0373
12		.0373	.1296		.0373
13		.0373	.081		.0373
14		.0373	.081		.0373
15		.0373	.1134	.037	.0373
16		.056	.1296	.037	.0373
17		.0554	.0972	.037	.0373
18		.0554	.0972	.037	.0373
19		.0554	.081	.037	.0373
20		.0554	.1296	.0554	.1478
21	.0924	.037	.1296	.0934	.1478
22	.1478	.1109	.1457	.1478	.1307
23	.0739	.1478		.1294	.1307
24		.0924	.2033	.1619	
Max	.1478	.1478	.2054	.1629	.1478
Min	.0739	.0018	.081	.037	.0018
Avg	.1047	.0595	.1318	.1030	.0662

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054067 / 33/11 KV PATHAN MANDVA

Feeder No / Name : 201 / 11 KV NAGAZARI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3169	1.4632	1.2346	
2		1.3169	1.3169	1.3306	
3		1.3169	1.3169	1.3306	
4		1.3169	1.3169	1.4784	
5		1.39	1.4632	1.7372	
6		1.922	1.922	2.0911	1.848
7		2.0698	2.0698	2.2177	1.905
8		1.9418	1.9418	1.9418	
9		1.7741	1.7002	1.7558	1.643
10		1.6263	1.5524	1.6095	1.6827
11		1.5893	1.3169	1.3756	1.5364
12			1.1706	1.1946	1.5364
13		1.1706	1.0029	.7421	1.2437
14			.9816	1.4175	.7316
15		1.0242	1.4022	1.5777	1.1706
16			1.4563	1.6991	1.1706
17		2.2436	1.9631	2.1152	1.267
18		1.8823	2.1491		1.8625
19		2.1719	2.1491		1.7375
20		1.8823	2.0058	1.8823	1.6278
21		1.6651	1.6827	1.5402	1.4449
22		1.4327	1.6263		
23	1.3611	1.448			
24				1.4045	1.1222
Max	1.3611	2.2436	2.1491	2.2177	1.905
Min	1.3611	1.0242	.9816	.7421	.7316
Avg	1.3611	1.6251	1.5895	1.5838	1.4706

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054067 / 33/11 KV PATHAN MANDVA

Feeder No / Name : 202 / 11 KV RAVIVAR PETH FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5014	.5068	.5544	
2		.5068	.5121	.5544	
3		.5068	.5121	.5544	
4		.5068	.5121	.5914	
5		.5121	.5121	.6283	
6		.7468	.7468	.7392	.6908
7		.8962	.8215	.8131	.9335
8		.9709	.8131	.9335	
9		.8131	.7392	.8413	.8501
10		.7023	.6584	.7499	.7392
11		.5914	.5731	.6154	.6283
12			.5258	.5731	.6283
13		.439	.4908	.4961	.4024
14			.4207	.4656	.439
15		.439	.3506	.394	.439
16			.3506	.4298	.4755
17		.4908	.5258	.567	.5792
18		.7087	.7164		.6556
19		.7796	.7964		.7712
20		.6379	.7602	.7282	.7282
21		.6173	.6516	.6485	.6241
22		.5426	.6283		
23	.5258	.5373			
24				.5544	.5258
Max	.5258	.9709	.8215	.9335	.9335
Min	.5258	.439	.3506	.394	.4024
Avg	.5258	.6223	.5966	.6216	.6319

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054067 / 33/11 KV PATHAN MANDVA

Feeder No / Name : 203 / 11 KV MUKUNDRAJ FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5975	.5601	.6348	
2		.5601	.5228	.6348	
3		.5601	.5228	.6348	
4		.5228	.5228	.6722	
5		.5228	.5228	.6516	
6		.8299	.8299	.6859	.7545
7		.9808	.9808	.8962	.9808
8		1.1317	.9808	1.1694	
9		1.0082	.9808	1.0456	1.0456
10		1.0082	.961	.9335	.8589
11		.7468	.8871	.7499	.7468
12			.8131	.7316	.7468
13		.7023	.5853	.695	
14			.5853	.5853	.6348
15			.5121	.5121	.6722
16			.5121	.6036	.6348
17		.8048	.7316	.823	.7392
18		1.0242	.961		.8871
19		1.0349	1.0456		1.0349
20		.8871	1.0082	.9145	.9055
21		.8131	.7468	.7316	.7133
22		.6584	.7468		
23	.5914	.6283			
24				.6722	.5853
Max	.5914	1.1317	1.0456	1.1694	1.0456
Min	.5914	.5228	.5121	.5121	.5853
Avg	.5914	.7906	.7509	.7489	.7960

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054067 / 33/11 KV PATHAN MANDVA

Feeder No / Name : 204 / 11KV KALWATI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3048	.3048	.1905	
2		.2286	.3048	.1905	
3		.2286	.2286	.1905	
4		.2286	.2286	.1905	
5		.2286	.2286	.2667	
6		.2667	.3048	.2667	.3772
7		.2667	.3048	.2667	.3772
8		.3018	.3048	.2641	
9		.7712	.7628	.0181	.8764
10		1.0517	.823	.0177	.8916
11		1.0166	.8817	.6687	.9602
12			.7956	.8139	.9259
13		.7545	.7377	.8718	.6859
14			.8048	.9054	.6859
15		.6935	.8718		.7202
16			.8718		
17			.1886	.2241	.2286
18		.2263	.2263		.2286
19		.3018	.2286		.3048
20		.3048	.2286	.3395	.3048
21		.3018	.2286	.3018	.3018
22		.3018	.2286		
23	.3048	.3018			
24				.1905	.2149
Max	.3048	1.0517	.8817	.9054	.9602
Min	.3048	.2263	.1886	.0177	.2149
Avg	.3048	.4253	.4586	.3432	.5389

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054067 / 33/11 KV PATHAN MANDVA

Feeder No / Name : 205 / 11 KV WATER SUPPLY EXPRESS NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.0633	.061	
7		.0648	.061	.064
8	.0312	.064	.1296	
9		.064	.125	.064
10	.0617	.064	.125	.0625
11	.0617	.064	.1265	.0625
12		.0648	.128	.064
13	.061	.064	.128	.0617
14		.0648	.128	.0617
15	.0617	.0648	.128	.0617
16		.0648	.128	.0617
17	.0625	.0617	.1265	.0602
18	.0625	.0617		.0594
19	.061	.0617		.0587
20	.0594	.061	.1204	.0572
21	.0594		.1189	.0572
22	.0594			
23	.0594			
Max	.0625	.0648	.1296	.064
Min	.0312	.061	.061	.0572
Avg	.0584	.0636	.1167	.0612

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054067 / 33/11 KV PATHAN MANDVA

Feeder No / Name : 404 / 33 KV DAWAKHANA

Feeder KV- 33 / INCOMING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.182	.9671	.7522	
2		1.182	1.182	.7522	
3		1.182	1.182	.7522	
4		1.2894	1.3969	.7522	
5		1.4506	1.4506	1.182	
6		1.9342	1.9879	1.8804	2.0416
7		2.5252	2.2028	1.9879	2.6863
8		2.4177	2.2565		
9		1.4506	1.5581	1.5043	1.5043
10		1.1283	1.1283	1.0745	1.2357
11		1.0745	1.0208	2.0416	1.0208
12			.8596	.8596	.7522
13		.7842	.7522	.7522	.7522
14			.7522	.7522	.7522
15		.9134	.6984	.8596	.8059
16			.6984	.8596	.8059
17		1.1283	.9134	1.0745	.9671
18		1.2357	1.0745		1.2357
19		1.2357	1.2357		1.1283
20		1.0745	1.0317	1.1283	1.0745
21		.9134	.9522	.9671	.8596
22		.7522	.8059		
23	.8596	.7522			
24				.7522	.6447
Max	.8596	2.5252	2.2565	2.0416	2.6863
Min	.8596	.7522	.6984	.7522	.6447
Avg	.8596	1.2803	1.1867	1.0887	1.1417

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054106 / DONGAR PIMPALA 33/11 KV

Feeder No / Name : 201 / 11 kv sonawala

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1355	1.358	1.3203	1.2109
2	1.2901	1.5089	1.3203	1.028
3	1.358	1.6975	1.358	1.3788
4	1.4033	1.7918	1.4712	1.5278
5	1.5127	1.8484	1.5844	1.3769
6	1.607	1.8861	1.8107	1.441
7	1.9465	2.0748	2.3388	2.1502
8	2.0521	2.1691	2.1125	2.2747
9	2.6406	2.4935		2.452
10	3.1687	3.0254	3.0178	3.5082
11	3.3573	3.1782	3.3951	3.3951
12	3.6969	3.3291	3.2065	3.4705
13	3.7346	3.131	3.6969	3.1499
14	3.4705	2.4614	3.7723	3.546
15	2.8292	3.0612	3.4328	3.5837
16	3.4328	3.0612	3.7723	3.3951
17	.0377	.0566		.0566
18	.0566	.0754		.0566
19	.0754	.0943	.0905	.0754
20	.0754	.0754		.0566
21	.0754	.0754		.0754
22	.0566	.0566	.0811	.0754
23	.9431	1.1883	.9054	1.1317
24	1.0374	1.226	1.2826	.7714
Max	3.7346	3.3291	3.7723	3.5837
Min	.0377	.0566	.0811	.0566
Avg	1.7081	1.7052	2.1037	1.7162

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054106 / DONGAR PIMPALA 33/11 KV

Feeder No / Name : 203 / 11 KV D.PIMPALA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1942	.128	.1463	.1719
2	.2263	.1663	.1494	.1552
3	.2678	.1867	.1494	.1885
4	.2829	.2641	.1886	.2334
5	.3093	.2987	.2263	.2452
6	.3282	.3696	.3395	.3018
7	.4829	.4108	.4527	.4546
8	.415	.3734	.4527	.415
9	.2641	.211		.2987
10	.2263	.225	.2715	.2195
11	.1848	.1884	.2033	.1629
12	.1867	.1568	.1448	.1595
13	.1848	.1343	.0709	.1402
14	.1848	.0585	.1448	.1448
15	.1132	.1006	.1254	.1448
16	.1448	.1536	.1646	.0943
17	.1006	.1696		.2294
18	.3052	.2865		.3605
19	.3429	.3982	.4306	.3814
20	.3018	.2743	.3269	.285
21	.2105	.2427	.2507	.2294
22	.1543	.1886	.2075	.1718
23	.1494	.1402	.1629	.1417
24	.1866	.1294	.1448	.1805
Max	.4829	.4108	.4527	.4546
Min	.1006	.0585	.0709	.0943
Avg	.2395	.2190	.2264	.2296

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054133 / 33/11KV DAWAKHANA S/S

Feeder No / Name : 201 / 11KV KRANTI NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5516	.5533	.5212	.4108
2	.5516	.5533	.5212	.4108
3	.6251	.5533	.5212	.4108
4	.717	.5902		.4108
5	.8641	.7193	.7073	.6722
6	1.2134	1.0317	.9679	.8402
7	1.3789	1.2541	1.303	.9335
8	1.434	1.4016		1.363
9	1.3237	1.3278	1.4003	1.3256
10	1.0512	1.0248	1.0829	1.1399
11	.8668	.8571	.8215	.9009
12	.8115	.708	.2427	.8089
13	.7377	.7267	.7655	.717
14	.7008	.6708	.7095	.6619
15	.7008	.5956	.6535	.6067
16	.8299	.6143	.6722	.717
17	.9221	.7282	.8775	.8825
18	1.1065	1.0796	1.0269	1.0296
19	1.1238	1.1541	1.1949	1.1215
20	.9764	1.0051	1.0269	.956
21	.8299	.8402	.8402	.8273
22	.6824	.7073	.6535	.6619
23	.627	.6515	.5415	.5332
24	.5516	.5902	.5584	.4668
Max	1.434	1.4016	1.4003	1.363
Min	.5516	.5533	.2427	.4108
Avg	.8824	.8308	.8004	.7837

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054133 / 33/11KV DAWAKHANA S/S

Feeder No / Name : 202 / 11KV DAGADWADI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0659	.0671	.037	.056
2	.0659	.0671	.037	.056
3	.0824	.0671	.037	.056
4	.0989	.0671	.037	.0747
5	.1318	.1678	.037	.1307
6	.1648	.2014	.037	.1867
7	.1648	.1511	.0556	.1867
8	.2142	.1846		.2054
9	.0839	.1825	.0747	.1867
10	.0839	.0365	.1307	.1471
11	.2686	.073	.1867	.2307
12	.2686	.0548	.2987	.1978
13	.3021	.0913	.1494	.0989
14	.3357	.0365	.2614	.1813
15	.3693	.037	.2614	.1483
16	.3357	.037	.1867	.1483
17	.1511	.037	.3174	.1648
18	.1511	.037	.3174	.1648
19	.0839	.0739	.112	.0989
20	.0839	.0934	.0934	.0989
21	.0839	.0934	.0934	.0824
22	.0839	.0747	.0934	.0824
23	.0839	.056	.0747	.0824
24	.0824	.0671	.037	.056
Max	.3693	.2014	.3174	.2307
Min	.0659	.0365	.037	.056
Avg	.1600	.0856	.1290	.1301

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054133 / 33/11KV DAWAKHANA S/S

Feeder No / Name : 203 / 11 KV KURUNWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1371	.9899	.9922	1.1603
2	1.236	1.0229	1.0584	1.1603
3	1.2854	1.0229	1.0584	1.2266
4	1.3349	1.0559	1.0749	1.5249
5	1.5821	1.2209	1.2734	1.5249
6	1.7634	1.4189	1.5214	1.6575
7	1.8293	1.6004	2.1664	1.8233
8	1.5326	1.9304		2.3205
9	.3461	.3008	.3481	.3441
10	.2811	.2673	.2155	.1813
11	.2977	.1838	.2321	
12	.2811	.1337	.1966	.1813
13	.287	.1671	.1802	.1648
14	.2811	.2005	.1638	.1813
15	.2811	.1984		.1648
16	.2811	.2241	.1494	.1813
17	.2811	.2486	.2294	.2307
18	.33	.3149	.2818	.3296
19	.33	.2652	.2949	.3296
20	.231	.2155	.2622	.2637
21	.198	.1658	.1802	.2307
22	.165	.1492	.1492	.1813
23	.759	.7956	1.0774	
24	1.0382	.8909	.9095	1.0774
Max	1.8293	1.9304	2.1664	2.3205
Min	.165	.1337	.1492	.1648
Avg	.7237	.6243	.6371	.7473

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054141 / PATTIWADGAON SUBSTATION

Feeder No / Name : 201 / MURTI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5959	.6135	
2		.6485	.6203	
3		.6836	.7011	
4		.6836	.7537	
5		.7362	.7888	
6		.7888	.8238	
7	.8063	.8063	.8589	
8		.7011	.8413	
9		.1677	.2103	.4207
10	.2103	.1402		.6661
11	.1402	.1052		
12		.0876		1.0166
13	.0701			1.0517
14	.0526		.0701	1.0517
15	.0526	.0351		1.0166
16	.0701	.0351		.8063
17	.1052	.0876	.0701	.0701
18	.1402	.1052		.1402
19	.2103	.1052		.2103
20	.1753	.1753		.1753
21	.1402	.1402		.1227
22	.1052			.0876
23	.4207			.0876
24	.8063	.4908	.5083	.1052
Max	.8063	.8063	.8589	1.0517
Min	.0526	.0351	.0701	.0701
Avg	.2337	.3660	.5717	.4686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054141 / PATTIWADGAON SUBSTATION

Feeder No / Name : 202 / PATTIWADGAON FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7712	.7545	
2		.7712	.7712	
3		.8048	.8048	
4		.8383	.8551	
5		.9724	.8886	
6		1.1568	.9556	
7	1.1233	1.2071	1.0395	
8		1.1065	1.0898	
9		.4024	.4527	.7377
10	.3521	.3688		.4694
11	.2347	.2515		
12	.2012	.1341		1.0898
13	.1677			1.3413
14	.1341		.1174	1.2742
15	.1174	.1341		
16	.1006	.1509		.9556
17	.1844	.1341	.2012	.2012
18	.3018	.3185		.3521
19	.4694	.4527		.4694
20	.3521	.3856		.3688
21	.285			.3185
22	.2012			.2515
23	.503			.2347
24	.7377	.7042	.6874	.1677
Max	1.1233	1.2071	1.0898	1.3413
Min	.1006	.1341	.1174	.1677
Avg	.3416	.5824	.7182	.5880

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054141 / PATTIWADGAON SUBSTATION

Feeder No / Name : 203 / BHABALGAON FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2347	.2515	
2		.2515	.285	
3		.2683	.3185	
4		.285	.3856	
5		.4359	.4191	
6		.7712	.503	
7	.8215	.9054	.6874	
8		.788	.7545	
9		.8718	1.1401	.6874
10	1.5927	1.4586		.4862
11	1.6095	1.6933		.3506
12	1.6598	1.7772		.2012
13	1.576	1.7269		.2012
14	1.4922	1.643	1.6095	.1677
15	1.6766	1.6263		.1341
16	1.8275	1.576		.1844
17	.218	.1677	.218	.2347
18	.4527	.4694		.4024
19	.5365	.6874		.5365
20	.4359	.4862		.4694
21	.3353	.3521		.4191
22	.2683			.3018
23	.2515			.6706
24	.2012	.2347	.2347	1.0395
Max	1.8275	1.7772	1.6095	1.0395
Min	.2012	.1677	.218	.1341
Avg	.9347	.8505	.5672	.4054

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054005 / 33/11 KV DHARUR

Feeder No / Name : 203 / ARANWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
8		1.5851	
9	.0171	.0152	.0177
10		.0152	
11	.0152	.0152	
12	.0171		
15	.0305	.0152	
16	.0152	.0152	
17	.0152		
Max	.0305	1.5851	.0177
Min	.0152	.0152	.0177
Avg	.0184	.2769	.0177

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054005 / 33/11 KV DHARUR

Feeder No / Name : 204 / EXPRESS JINING

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0457		.112
2		.0286		.112
3		.0343		.112
4		.0343		.056
5		.0667		.112
6		.0533		.112
7	.1427	.0857		.112
8			.12	.1494
9		.1029	.12	
10		.12	.1372	
11		.0857	.12	
12		.12		
13		.12		
14		.1029		
15		.1029	.1029	
16		.1372	.12	
17	.0343	.12	.112	
18	.0286		.0934	
19	.0343		.1307	
20	.0343		.1307	.0934
21	.0343		.112	
22	.0286		.112	
23	.0286		.1307	
24	.1307	.0457		.056
Max	.1427	.1372	.1372	.1494
Min	.0286	.0286	.0934	.056
Avg	.0552	.0827	.1186	.1027

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054005 / 33/11 KV DHARUR

Feeder No / Name : 205 / GFSS Avargaon

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1524		.3475
2		.1448		.3475
3		.16		.3658
4		.2572		.4207
5		.3429		.6401
6		.4458		.7682
7	.9145	.6401		.8779
8			.7545	.9328
9		.5487	.6001	
10		.3944	.4115	
11		.3429	.3772	
12		.3086		
13		.2743		
14		.2401		
15		.2229	.3772	
16		.1372	.5487	
17	.2382	.2743	.3944	
18	.3658		.4755	
19	.3544		.6401	
20	.2382		.7133	.8215
21	.2		.6219	
22	.2191		.5121	
23	.16		.3841	
24	.3921	.1524		
Max	.9145	.6401	.7545	.9328
Min	.16	.1372	.3772	.3475
Avg	.3425	.2964	.5239	.6136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054005 / 33/11 KV DHARUR

Feeder No / Name : 206 / GFSS Aranwadi
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0076		.0366
2		.0076		.0366
3		.0076		.0549
4		.0286		.0732
5				.128
6		.0953		.1646
7	.1829	.1067		.1646
8			.2401	.1646
9		.1715	.1715	
10		.0857	.1029	
11		.0514	.0171	
12		.0343		
13		.0343		
14		.0171		
15		.0343	.0171	
16		.0343	.0514	
17	.0286	.0514	.0686	
18	.0343		.128	
19	.061		.112	
20	.0343		.0732	.0934
21	.0114		.0549	
22	.0076			
23	.0076		.0366	
24	.0373	.0076		.0366
Max	.1829	.1715	.2401	.1646
Min	.0076	.0076	.0171	.0366
Avg	.045	.0485	.0895	.0953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054017 / 33 KV. ADAS S/S

Feeder No / Name : 201 / 11 KV. ADAS FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5087	.6783	.5087	.5087
2	.5087	.6783	.5087	.5087
3	.5087	.6783	.5087	.5087
4	.8478	.6783	.6783	.5087
5	1.0174	1.0174	.8478	.8478
6	1.0174	1.0174	1.0174	1.0174
7		1.0174	1.0174	1.0174
8	1.0174	1.0174	1.0174	1.0174
9	1.1869	1.0174	1.0174	1.1869
10	1.3565	1.1869	1.0174	1.6956
11	1.3565	1.1869	1.3565	1.8652
12	1.3565	1.2717		1.6956
13	1.3565	1.3565		1.8652
14	1.3565	1.2717		1.6108
15	1.3565		1.0174	1.7804
16	1.3565	1.1869	1.6108	1.8652
17	.6783	.6783	.5087	.6783
18	.6783	.6783	.8478	1.0174
19	1.0174	1.0174	1.0174	1.0174
20	1.0174	1.0174	1.0174	1.0174
21	1.0174	.8478	.8478	1.0174
22	.8478	.6783	.5087	1.0174
23	.8478	.5087	.5087	.8478
24	.5087	.6783	.5087	.5087
Max	1.3565	1.3565	1.6108	1.8652
Min	.5087	.5087	.5087	.5087
Avg	.9879	.9289	.8519	1.1092

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054017 / 33 KV. ADAS S/S

Feeder No / Name : 202 / 11 KV. KHODAS FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8957	1.8957	1.8976	1.3296
2	2.0852	2.0852	1.8976	1.3296
3	2.18	2.0852	1.8976	1.7095
4	1.9905	2.0852	2.0873	1.8995
5	2.2748	2.0873	2.2771	2.2794
6	2.0852	2.0873	2.6566	2.6593
7	2.2748	2.8464	2.6566	2.6593
8	2.8435	2.8464	2.6566	2.6593
9	.3791	.3795	.3795	.3799
10	.3791	.3795	.3795	.3799
11	.3791	.3795	.3795	.1899
12		.3795		.1899
13		.3795		.1899
14	.3791	.3795		.1899
15	.3791	.3795		.1899
16	.3791	.3795	.3799	.2849
17	.3791	.3795	.3799	.2849
18	.3791	.3795	.5698	.2849
19	.5687	.5693	.7598	.3799
20	.5687	.5693	.7598	.3799
21	.3791	.3795	.5698	.3799
22	.3791	.3795	.3799	.3799
23	.5687	1.1385	1.1397	.7598
24	1.1374	1.1374	1.5181	1.3296
Max	2.8435	2.8464	2.6566	2.6593
Min	.3791	.3795	.3795	.1899
Avg	1.1029	1.0828	1.2811	.9458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054017 / 33 KV. ADAS S/S

Feeder No / Name : 203 / 11 KV ASARDON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2844	.3791	.1896	.1896
2	.2844	.3791	.1896	.1896
3	.3791	.3791	.1896	.1896
4	.3791	.3791	.3791	.1896
5	.5687	.3791	.5687	.3791
6	.5687	.3791	.5687	.5687
7	.5687	.5687	.5687	.5687
8	.5687	.5687	.5687	.5687
9	.7583	.5687	.7583	.7583
10	.9478	.7583	1.1374	1.1374
11	.9478	.9478	1.1374	1.5165
12	.9478	.9478		1.327
13	.9478	.9478		1.4218
14	.9478	.7583		1.1374
15	.9478	1.1374	.9478	1.1374
16	.9478	1.1374	1.1374	1.327
17	.1896	.3791	.3791	.2844
18	.3791	.3791	.3791	.2844
19	.3791	.5687	.5687	.3791
20	.3791	.5687	.5687	.5687
21	.3791	.3791	.4739	.5687
22	.3791	.3791	.3791	.5687
23	.3791	.1896	.1896	.3791
24	.2844	.3791	.1896	.1896
Max	.9478	1.1374	1.1374	1.5165
Min	.1896	.1896	.1896	.1896
Avg	.5726	.5766	.5461	.6595

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054072 / 33/11 KV AMBEWADGAON S/S

Feeder No / Name : 202 / AMBEWAGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9				.4614	.4604
10				.33	.3288
11				.2532	.2026
12					.1688
13					.1973
15				.2026	.1973
16	.2012			.2026	.2523
17		.2495		.3135	
18		.4158	.2483	.363	
19		.3659	.298	.4455	
20		.2664	.3477	.3795	
21		.2331	.298		
22		1.8275	1.8191		
23		1.7922	1.8191		
24			1.7238	1.817	
Max	.2012	1.8275	1.8191	1.817	.4604
Min	.2012	.2331	.2483	.2026	.1688
Avg	.2012	.7358	.9363	.4768	.2582

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054072 / 33/11 KV AMBEWADGAON S/S

Feeder No / Name : 203 / SONIMOHA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9				2.2167	2.7313
10				2.5577	2.7129
11					2.7313
12					2.3899
13					2.3899
16	.3743			.4696	.4263
17				.648	
18		.8497	.7826	.8526	
19		.8157	.8507	.9549	
20		.5608	.5961	.7673	
21		.3739	.4088		
22		.2892	.2896		
23		.2722	.2725		
24			.2722	.2725	
Max	.3743	.8497	.8507	2.5577	2.7313
Min	.3743	.2722	.2722	.2725	.4263
Avg	.3743	.5269	.4961	1.0924	2.2303

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054113 / 33KV ASARDOH S/stn

Feeder No / Name : 201 / Morphali SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0572	
2	.0381	.0572	.0572	.0457
3	.0381	.0572	.0572	
4	.0572	.0762	.0572	
5	.0762	.1143	.0762	
6	.0953	.1143	.1143	.0762
7	.1143	.1334	.1143	
8	.0953	.0953		.0914
9	.0914	.0762	.0914	.3201
10	.0914	.0686		.3963
11	.0914	.0686		.4268
12	.061	.0686		.503
13	.1067	.0686		.503
14	.1219	.12		.5182
15	.1219	.12	.4572	.442
16	.1067	.12		.5335
17	.0572	.0572	.0762	
18	.1143	.0762	.1143	.0572
19	.1524	.1143	.1334	.1143
20	.0953	.0953	.1334	.1143
21	.0953	.0572	.1143	.0953
22	.0762	.0572	.0953	.0762
23	.0572	.0572	.0762	.0572
24	.0572	.0572	.0572	
Max	.1524	.1334	.4572	.5335
Min	.0381	.0572	.0572	.0457
Avg	.0862	.0828	.1107	.2571

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054113 / 33KV ASARDOH S/stn

Feeder No / Name : 202 / Asardoha SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1279	1.0364	1.1279	
2	1.2041	1.1126	1.1888	
3	1.1888	1.1126	1.2651	1.2803
4	1.2955	1.2041	1.3413	
5	1.387	1.2346	1.4175	
6	1.4632	1.2955	1.4784	1.7071
7	1.6766	1.5546	1.5394	
8	1.5699	1.7223		1.5546
9	.381	.4191	.3506	.2477
10	.2667	.2477		.1715
11	.2096	.1715	.1829	.1143
12	.1524	.1524		.1143
13	.1143	.1334		.1524
14	.1334	.0953		.1715
15	.1334	.1143	.1219	.1524
16	.1334	.1334		.1334
17	.1524	.1715	.1715	.2477
18	.4572	.4001	.4763	.362
19		.4382	.5335	.4382
20	.3048	.381	.4954	.4001
21	.2096	.2667	.4763	.3239
22	.1715	.2286	.4191	.2096
23	.8383	.8993	.8383	.884
24	1.1126	.945	.9297	.9145
Max	1.6766	1.7223	1.5394	1.7071
Min	.1143	.0953	.1219	.1143
Avg	.6819	.6446	.7974	.5042

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054113 / 33KV ASARDOH S/stn

Feeder No / Name : 203 / Rui dharur SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1334	.1524	
2	.1524	.1524	.1524	.2439
3	.1715	.1905	.2096	
4	.2286	.2667	.3048	
5	.3429	.381	.362	
6	.4572	.4954	.4001	.3963
7	.5335	.5144	.4382	
8	.4382	.4763		.3658
9	.7011	.5792	.3506	.9755
10	1.1888	1.2651		1.6461
11	1.2193	1.3717	.6859	1.7985
12	1.326	1.326		1.6613
13	1.4784	1.2498		1.6766
14	1.387	1.2803		1.7071
15	1.5242	1.2955	1.6766	1.7071
16	1.5851	1.2651		1.6766
17	.2096	.1715	.2477	
18	.4001	.4191	.3429	.4382
19	.4763	.4382	.4191	.5525
20	.381	.381	.4382	.4001
21	.2667	.2096	.381	.3048
22	.1715	.1715	.3048	.1905
23	.1334	.1334	.3048	.1524
24	.1715	.1334	.1334	.2134
Max	1.5851	1.3717	1.6766	1.7985
Min	.1334	.1334	.1334	.1524
Avg	.6298	.5959	.4058	.8948

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054002 / 33KV KAIJ

Feeder No / Name : 201 / Town-I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		1.267		
8	1.7194			
10		1.3575	1.3575	
12	1.162			1.134
15		.905		
18	1.4632	1.2696		
19				1.5203
20	1.2437			
23	.7682			
24			.5441	
Max	1.7194	1.3575	1.3575	1.5203
Min	.7682	.905	.5441	1.134
Avg	1.2713	1.1998	.9508	1.3272

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054002 / 33KV KAIJ

Feeder No / Name : 202 / Tambva

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
6		2.6063	
8	2.8995		
23	1.3717		
24			1.8067
Max	2.8995	2.6063	1.8067
Min	1.3717	2.6063	1.8067
Avg	2.1356	2.6063	1.8067

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054002 / 33KV KAIJ

Feeder No / Name : 204 / Massajog Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.1475		
8	.1638			
10		2.2119	2.0388	
12	2.2578			1.7204
15		2.0317		
18	.1311	.1654		
19				.1326
20	.1475			
23	.1147			
24			.1158	
Max	2.2578	2.2119	2.0388	1.7204
Min	.1147	.1475	.1158	.1326
Avg	.5630	1.1391	1.0773	.9265

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054002 / 33KV KAIJ

Feeder No / Name : 205 / Town-II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		1.4523		
8	2.4143			
10			1.905	
12	1.8957			1.6409
15		1.3769		
18	2.0559	1.8596		
19				1.8296
20	1.5466			
23	.9808			
24			.8539	
Max	2.4143	1.8596	1.905	1.8296
Min	.9808	1.3769	.8539	1.6409
Avg	1.7787	1.5629	1.3795	1.7353

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054002 / 33KV KAIJ

Feeder No / Name : 206 / Water supply
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.132		
8	.3547			
10		.1509	.5281	
12	.3361			.679
15		.132		
18	.3395	.1448		
19				.2427
20	.1698			
23	.1509			
24			.2195	
Max	.3547	.1509	.5281	.679
Min	.1509	.132	.2195	.2427
Avg	.2702	.1399	.3738	.4609

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054002 / 33KV KAIJ

Feeder No / Name : 207 / GFS sonijawalla

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.3841		
8	.4075			
10		.3982	.3961	
12	.3224			.3772
15		.2534		
18	.3772	.3432		
19				.3982
20	.2641			
23	.2075			
24			.1875	
Max	.4075	.3982	.3961	.3982
Min	.2075	.2534	.1875	.3772
Avg	.3157	.3447	.2918	.3877

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054002 / 33KV KAIJ

Feeder No / Name : 208 / GFS Tambva

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.4938		
8	.6036			
10		.3475	.3292	
12	.1839			.128
15		.2012		
18	.2926			
19				.4207
20	.2378			
23	.1463		.3292	
24			.1283	
Max	.6036	.4938	.3292	.4207
Min	.1463	.2012	.1283	.128
Avg	.2928	.3475	.2622	.2744

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054015 / 33KV BANSAROLA

Feeder No / Name : 201 / Bansarola SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.6401	.9145	.9511	.9694
23		.4374		
24		.5548	.4687	.4843
Max	.6401	.9145	.9511	.9694
Min	.6401	.4374	.4687	.4843
Avg	.6401	.6356	.7099	.7269

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054015 / 33KV BANSAROLA

Feeder No / Name : 202 / Isthal SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9			1.1702	.8322
10		1.1069		.124
23		.1494		
24	1.0669	.1254	.1494	
Max	1.0669	1.1069	1.1702	.8322
Min	1.0669	.1254	.1494	.124
Avg	1.0669	.4606	.6598	.4781

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054015 / 33KV BANSAROLA

Feeder No / Name : 203 / Kaudgaon

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
9	.6287	.5281	.6036
23	.8573		
24	1.065	.9755	1.4746
Max	1.065	.9755	1.4746
Min	.6287	.5281	.6036
Avg	.8503	.7518	1.0391

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054015 / 33KV BANSAROLA

Feeder No / Name : 204 / Jawallban
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
9		.1886	.1905
23	.0572		
24	.0381	.0572	.0381
Max	.0572	.1886	.1905
Min	.0381	.0572	.0381
Avg	.0477	.1229	.1143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054015 / 33KV BANSAROLA

Feeder No / Name : 205 / Awasgaon

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
9		2.6155	2.6658
23	.1905		
24	.2667	.1905	.2286
Max	.2667	2.6155	2.6658
Min	.1905	.1905	.2286
Avg	.2286	1.403	1.4472

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054015 / 33KV BANSAROLA

Feeder No / Name : 206 / Borisavargaon

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
9	.5144	.6097	
10	2.4996		1.8023
23	1.1248		
24	2.4996	1.2498	
Max	2.4996	1.2498	1.8023
Min	.5144	.6097	1.8023
Avg	1.6596	.9298	1.8023

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054038 / NANDURGHAT

Feeder No / Name : 202 / Waghebabulgaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	21-DEC-17
HR	Load (MW)
20	.3506
Max	.3506
Min	.3506
Avg	.3506

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054040 / YUSUFWADGAON

Feeder No / Name : 201 / Yusufwadgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17
HR	Load (MW)	Load (MW)
6		.3525
7	.4954	.4761
9	.5695	.6969
10	.756	
12	.9503	
14	1.0166	
16	.9945	
20	.3647	
21	.2835	
23	.1738	
24		.1463
Max	1.0166	.6969
Min	.1738	.1463
Avg	.6227	.4180

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054040 / YUSUFWADGAON

Feeder No / Name : 202 / Sadola

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17
HR	Load (MW)	Load (MW)
6		.0985
7	.1457	.1402
9	.3475	.4801
10	.467	
12	.5194	
14	.5967	
16	.652	
20	.036	
21	.0267	
23	.0276	
24		.0335
Max	.652	.4801
Min	.0267	.0335
Avg	.3132	.1881

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054043 / 33/11 KV H.PIMPRI SS

Feeder No / Name : 204 / GFSS H.pimpri

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17
HR	Load (MW)	Load (MW)
24	.4572	.4572
Max	.4572	.4572
Min	.4572	.4572
Avg	.4572	.4572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054043 / 33/11 KV H.PIMPRI SS

Feeder No / Name : 205 / 11 KV Borgaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17
HR	Load (MW)	Load (MW)
1		.1867
24	.1886	
Max	.1886	.1867
Min	.1886	.1867
Avg	.1886	.1867

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054077 / DHANEGAON

Feeder No / Name : 201 / Pathra AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	21-DEC-17
HR	Load (MW)
9	1.7528
Max	1.7528
Min	1.7528
Avg	1.7528

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054077 / DHANEGAON

Feeder No / Name : 204 / GFSS Dhanegaon

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3506
2				.3506
3				.3506
4				.4382
5				.4382
6				.5258
7		.5468		.5258
8				.5258
9		.3201		.5258
10			.1791	
11			.3506	.3429
12			.3506	.3429
13			.1753	
14			.1753	
15			.1791	
16			.1791	
17	.16		.3582	
18			.4382	
19			.4525	
20			.3506	.5144
21	.3277		.3506	
22			.3506	
23			.3506	
24				.3506
Max	.3277	.5468	.4525	.5258
Min	.16	.3201	.1753	.3429
Avg	.2439	.4335	.3029	.4294

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054077 / DHANEGAON

Feeder No / Name : 205 / GFSS Pathra

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.5258
2				.5373
3				.5258
4				.5373
5				.5258
6				.6135
7		.6401		.6135
8			.8764	.724
9		.6554	.8059	.7011
10			.7011	
11			.5373	.5144
12			.5373	.4287
13			.5373	
14			.3506	
15			.3506	
16			.3582	
17	.4096		.5258	
18			.7087	
19			.7011	
20			.6135	.6001
21	.3353		.5373	
22			.5373	
23			.5373	
24				.5258
Max	.4096	.6554	.8764	.724
Min	.3353	.6401	.3506	.4287
Avg	.3725	.6478	.5760	.5672

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054079 / MASSAJOG

Feeder No / Name : 203 / SHINDE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	19-DEC-17
HR	Load (MW)
15	1.1336
Max	1.1336
Min	1.1336
Avg	1.1336

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054080 / KUMBEPHAL

Feeder No / Name : 202 / Janegaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.0914		
9			2.0062	
11				2.6368
12	2.5606			
14				2.5301
20	.0914			
Max	2.5606	.0914	2.0062	2.6368
Min	.0914	.0914	2.0062	2.5301
Avg	1.326	.0914	2.0062	2.5835

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054080 / KUMBEPHAL

Feeder No / Name : 203 / Kumbephal
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
8		2.1795	
11			.0457
12	.061		
20	.0457		
Max	.061	2.1795	.0457
Min	.0457	2.1795	.0457
Avg	.0534	2.1795	.0457

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054080 / KUMBEPHAL

Feeder No / Name : 205 / Kumbhefal Gfss

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.5639		
9			.5487	
11				.1372
12	.1981			
20	.4268			
Max	.4268	.5639	.5487	.1372
Min	.1981	.5639	.5487	.1372
Avg	.3125	.5639	.5487	.1372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054132 / 33KV Devgoan

Feeder No / Name : 201 / Devgaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2374		.1966
2		.2713		.1966
3		.2713		.2294
4		.3052		.2622
5		.3391		.3277
6		.5765		.6226
7		.78	.7377	.7537
8		.7122	.4694	.6554
9		.6443	.6706	1.3108
10		1.3226	2.146	2.3266
11			.9831	2.6791
12			2.5888	2.4078
13			2.5232	
14			2.4143	2.8147
15			2.4577	2.5774
16			2.4905	2.5774
17			.2012	.1357
18			.3018	
19			.7042	.7461
20			.4694	.5087
21			.3353	.3052
22	.3052		.3018	.2683
23	.2713		.2012	.4359
24	.2374			.6371
Max	.3052	1.3226	2.5888	2.8147
Min	.2374	.2374	.2012	.1357
Avg	.2713	.5460	1.1762	1.0443

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054132 / 33KV Devgoan

Feeder No / Name : 202 / Limbachiwadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7274		.9717
2		.8855		1.004
3		.9172		1.0688
4		.9804		1.0688
5		.9804		1.1336
6		1.0753		1.1797
7		1.1385	1.2967	1.1984
8		1.2018	1.2651	1.2308
9		.0316	.0316	.0648
10		.0316	.0324	.0648
11			.0324	.0633
12			.0324	.0633
13			.0324	
14			.0324	.0633
15			.0324	.0316
16			.0324	.0316
17			.0648	
18			.0648	.0949
19			.0983	.1265
20				.1265
21			.0972	.0949
22	.0633		.0648	.0949
23	.3479		.5182	.0949
24	.506			.0633
Max	.506	1.2018	1.2967	1.2308
Min	.0633	.0316	.0316	.0316
Avg	.3057	.7970	.2330	.4516

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054132 / 33KV Devgoan

Feeder No / Name : 203 / Dahiphal

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5624		.8288
2		.6562		.8619
3				.8619
4		.6874		.9282
5		.7186		.9945
6		.9061		1.0608
7		.9998	.9717	1.1271
8		1.0623	.9282	1.0608
9		.0937	.16	.0995
10		.0937	.0995	.1658
11			.0995	
12			.0995	
13			.0995	
14			.0663	.0937
15				.0625
16				.0625
17			.0995	.125
18			.1326	.1562
19			.1658	.2031
20			.1989	.125
21			.1658	.125
22	.0937		.1658	.0937
23	.2187		.2652	.0937
24	.3437			.0937
Max	.3437	1.0623	.9717	1.1271
Min	.0937	.0937	.0663	.0625
Avg	.2187	.6422	.2479	.4392

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054132 / 33KV Devgoan

Feeder No / Name : 204 / Express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	17-DEC-17	18-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0168		.0168
2		.0168		.0168
3		.0168		.0168
4		.0168		.0168
5		.0168		
6		.0168		.0168
7		.0168	.0166	.0168
8		.0168	.0166	.0168
9		.0168	.0166	.0168
10		.0168	.0168	.0168
11			.1006	.0164
12			.0168	.0164
13			.0168	
14			.0168	.0164
15			.1006	.0164
16			.1006	.0164
17			.0838	.0164
18			.1006	.0164
19			.0335	.0164
20			.0168	.0164
21			.0168	.0164
22	.0503		.0168	.0164
23	.0503		.0168	.0164
24	.0335			.0164
Max	.0503	.0168	.1006	.0168
Min	.0335	.0168	.0166	.0164
Avg	.0447	.0168	.0414	.0166

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054136 / 33 KV Waghebabulgaon

Feeder No / Name : 201 / Narewadi

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)
9	1.5424	1.4022
10	1.5432	1.6301
13	1.4529	
14	1.6766	
15	1.587	
16	1.5655	
Max	1.6766	1.6301
Min	1.4529	1.4022
Avg	1.5613	1.5162

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054136 / 33 KV Waghebabulgaon

Feeder No / Name : 202 / Bandewadi

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)
1		1.1888
2		1.2048
3		1.1706
4		1.267
5		1.1517
6		1.1104
23	.8145	
24		1.0974
Max	.8145	1.267
Min	.8145	1.0974
Avg	.8145	1.1701

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054136 / 33 KV Waghebabulgaon

Feeder No / Name : 203 / Waghebabulgaon

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	19-DEC-17
HR	Load (MW)
16	1.6667
17	1.8299
18	1.6512
Max	1.8299
Min	1.6512
Avg	1.7159

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054149 / 33/11 KV SALEGAON S/Stn

Feeder No / Name : 201 / salegaon gfss

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)
8	.6037	
11		.2126
12	.1776	
14	.2308	
16		.2126
18		.3582
Max	.6037	.3582
Min	.1776	.2126
Avg	.3374	.2611

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054149 / 33/11 KV SALEGAON S/Stn

Feeder No / Name : 202 / Ganji AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17
HR	Load (MW)
8	.7773
Max	.7773
Min	.7773
Avg	.7773

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054149 / 33/11 KV SALEGAON S/Stn

Feeder No / Name : 203 / Salegaon AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)
11		1.5466
12	1.5489	
14	1.5429	
16		1.2498
Max	1.5489	1.5466
Min	1.5429	1.2498
Avg	1.5459	1.3982

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

MAJALGAON S/DN.[423] BU 2593

Substation No/ Name :- 054001 / 33 KV MAJALGAON s/stn

Feeder No / Name : 201 / 11KV MANJRATH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)
3	.7865	
4		.8962
8	1.9456	1.7871
12	1.2023	
16	1.1083	1.0749
20	1.3114	
24	.8573	.7354
Max	1.9456	1.7871
Min	.7865	.7354
Avg	1.2019	1.1234

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

MAJALGAON S/DN.[423] BU 2593

Substation No/ Name :- 054001 / 33 KV MAJALGAON s/stn

Feeder No / Name : 202 / 11KV GANGAMASALA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4				1.1459
8	1.5074		1.7528	1.8954
9		.1791		
10		.1402		
12	.1126		.2442	
15		.1052		
16	.1127		.2766	.2883
20	.2064		.3813	
24	.9602		1.2536	1.0884
Max	1.5074	.1791	1.7528	1.8954
Min	.1126	.1052	.2442	.2883
Avg	.5799	.1415	.7817	1.1045

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

MAJALGAON S/DN.[423] BU 2593

Substation No/ Name :- 054001 / 33 KV MAJALGAON s/stn

Feeder No / Name : 203 / 11KV KALEGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	18-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
3	.6687		
4			.8623
8	1.4548		1.5746
12	.8641	1.0154	
16	.9164	1.2334	1.2037
20	1.0542		
24	.7011		.5865
Max	1.4548	1.2334	1.5746
Min	.6687	1.0154	.5865
Avg	.9432	1.1244	1.0568

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

MAJALGAON S/DN.[423] BU 2593

Substation No/ Name :- 054001 / 33 KV MAJALGAON s/stn

Feeder No / Name : 205 / 11 KV Express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.0282			
6			.0366	
8	.0286			.0545
12	.0368			
15		.0895		
16	.0375	.0537		.0549
20	.0368			
24	.029		.0366	
Max	.0375	.0895	.0366	.0549
Min	.0282	.0537	.0366	.0545
Avg	.0328	.0716	.0366	.0547

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

MAJALGAON S/DN.[423] BU 2593

Substation No/ Name :- 054001 / 33 KV MAJALGAON s/stn

Feeder No / Name : 208 / 11 KV Manjarth GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.7783			
8	2.1098			1.9448
9		2.1209		
10		1.9418		
11		1.6644		
12	1.315	1.5424		
13		1.3611		
15		.9816		
16	1.4623	1.39		1.2696
20	1.1559			
23		.9816		
24	.7888		.8063	.5498
Max	2.1098	2.1209	.8063	1.9448
Min	.7783	.9816	.8063	.5498
Avg	1.2684	1.4980	.8063	1.2547

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

MAJALGAON S/DN.[423] BU 2593

Substation No/ Name :- 054134 / 33 KV MANUR DEVI S/stn

Feeder No / Name : 201 / MANJRATH AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1			.2675
2			.2972
3			.3269
4			.3121
5			.2972
6			.3418
7			.3567
12	.2901		
14	.3572		
23		.1783	
24			.2229
Max	.3572	.1783	.3567
Min	.2901	.1783	.2229
Avg	.3237	.1783	.3028

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

MAJALGAON S/DN.[423] BU 2593

Substation No/ Name :- 054134 / 33 KV MANUR DEVI S/stn

Feeder No / Name : 202 / NAGADGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	20-DEC-17
HR	Load (MW)
10	.4572
11	.5487
12	.6859
13	.5639
14	.7468
15	.8078
16	.7926
Max	.8078
Min	.4572
Avg	.6576

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

MAJALGAON S/DN.[423] BU 2593

Substation No/ Name :- 054135 / 33KV GANGAMASLA S/stn

Feeder No / Name : 203 / GANGAMASLA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6834	.6295	.6475	.6173
2		.5755	.6834	.7014	.6516
3		.6475	.7194	.7194	.7202
4		.7194	.7194	.8273	.823
5		.8633	.9892	.9352	.9602
6		.9892	1.0791	1.223	1.1145
7		1.169	1.3489	1.2949	1.2517
8		1.1757	1.241	1.259	1.3203
9	1.166	.9976	1.223	1.205	1.2003
10		1.532	.9712	.823	.9532
11			.6475	.7545	.8633
12		.697	.6115	.6859	.8093
13		.9829			.7734
14		.7171	.6475		.7554
15		.753	.6834	.6173	.8273
16		.664	.7554	.7545	.9172
17		.7179	.9352		.9892
18		.8076	1.0072	.823	1.046
19		.8983	1.0611	.8916	1.046
20	.8633	.8085	.8633	.9602	1.0288
21	.7734	.8264	.7194	.7545	1.1145
22	.9172	.6468	.6475	.6516	1.1488
23	.7194	.5569	.5935	.6173	.9431
24		.7554	.5569	.6115	.583
Max	1.166	1.532	1.3489	1.2949	1.3203
Min	.7194	.5569	.5569	.6115	.583
Avg	.8879	.8341	.8406	.8456	.9357

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054042 / 33/11 KV OPH PARLI S/S

Feeder No / Name : 201 / 11kv CHANDAPUR AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.1494		
9			.1013	
10	.5396		.3204	
11			.5227	
12	.8738		.4705	
13	.7721			
14		.1433	.4042	
15	.9751			
16			.6706	.9149
18				.1187
19				.1191
21				.1187
Max	.9751	.1494	.6706	.9149
Min	.5396	.1433	.1013	.1187
Avg	.7902	.1464	.4150	.3179

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054042 / 33/11 KV OPH PARLI S/S

Feeder No / Name : 204 / 11 KV GFSS CHANDAPUR
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.3361		
9			.1795	
10	.1932		.2467	
11			.2281	
12	.2293		.2954	
13	.2286			
14		.3292	.1562	
15	.247			
16	.2646		.1936	.3982
18				.3388
19				.3096
21				.2202
Max	.2646	.3361	.2954	.3982
Min	.1932	.3292	.1562	.2202
Avg	.2325	.3327	.2166	.3167

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054042 / 33/11 KV OPH PARLI S/S

Feeder No / Name : 205 / 11 KV Kalratri Devi Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		2.2405		
10	1.483		1.6967	
11			1.4385	
12	1.2567		1.2012	
13	1.1803			
14		.905	.8089	
15	.8852			
16	1.037		.9221	1.0269
18				1.5652
19				1.5556
21				1.1434
Max	1.483	2.2405	1.6967	1.5652
Min	.8852	.905	.8089	1.0269
Avg	1.1684	1.5728	1.2135	1.3228

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054048 / 33/11 KV NATHRA S/S

Feeder No / Name : 201 / 11 KV PANGRI FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2308	1.086	1.3555	1.0974
2		1.2308	1.086	1.4283	1.1584
3		1.2308	1.086	1.6032	1.2308
4		1.3032	1.2308	1.6324	1.2308
5		1.3321	1.2742	1.749	1.2742
6		1.3611	1.3032	1.851	1.4335
7		1.5927	1.8244	1.9239	1.5493
8		1.5927	1.8244	1.953	1.6941
9		.029	1.8244		
18			.0146		
20		.029			
21	.029			.029	
22		.029	.0291	.029	
23	1.2308	1.086	1.3117	1.1294	
24		1.2308	1.086	1.3555	1.1584
Max	1.2308	1.5927	1.8244	1.953	1.6941
Min	.029	.029	.0146	.029	1.0974
Avg	.6299	1.0214	1.1524	1.3366	1.3141

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054048 / 33/11 KV NATHRA S/S

Feeder No / Name : 202 / 11 KV NATHRA FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3039	.3039	.4054	.3453
2		.3039	.3039	.4561	.3453
3		.3039	.3039	.4814	.3453
4		.3453	.3453	.5068	.3453
5		.4144	.4006	.5068	.3591
6		.4558	.4834	.5575	.5525
7		.5525	.5525	.5828	.663
8		.6078	.7321	.5828	.7321
18				.0414	.0698
19		.0553	.0507	.0553	.0698
20			.0633	.0553	.0559
21		.0716	.0633	.0414	.0559
22	.3039		.0633		.0559
23		.3039	.3167	.2348	.3352
24		.3039	.3039	.3801	.3453
Max	.3039	.6078	.7321	.5828	.7321
Min	.3039	.0553	.0507	.0414	.0559
Avg	.3039	.3352	.3062	.3491	.3117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054048 / 33/11 KV NATHRA S/S

Feeder No / Name : 203 / 11 KV GFSS Nathra Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1112	.1112	.1111	.1483
2		.1483	.1483	.1111	.1483
3		.1854	.1854	.1852	.1854
4		.3337	.3337	.3333	.2966
5		.6488	.6488	.6481	.5932
10		.482	.5185	.482	.5747
11		.3522	.3148	.3708	.3708
12		.1668	.2593	.241	.241
13			.2076	.1854	.2225
14		.1483	.1852	.1668	.1298
15			.1667	.1854	.1668
16		.2225	.2222	.2595	.1668
17		.241	.2593	.3151	
18		.3708	.4815	.482	.5932
19		.3708		.6303	.5191
20		.4078	.3333	.3522	.4078
21	.241	.2781	.3148	.1854	.3522
22	.1854	.1092	.2778	.1854	.2039
23	.1112	.1483	.1481	.1483	.1483
24		.1112	.1112	.1481	.1483
Max	.241	.6488	.6488	.6481	.5932
Min	.1112	.1092	.1112	.1111	.1298
Avg	.1792	.2687	.2751	.2863	.2956

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054048 / 33/11 KV NATHRA S/S

Feeder No / Name : 204 / 11 KV Pangri GFSS Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3692	.3708	.3788	.2966
2		.3692	.3708	.3788	.2966
3		.4615	.5005		.482
4		.9231		.9469	1.0196
5		1.0154	1.1123	1.0416	1.1123
10		.8898	1.0794		.96
11		.6674		.6674	.7015
12		.5191		.5191	
13				.4449	
14		.4449		.4449	
15			.5681	.4449	
16			.4734	.4449	.7385
17			.5492	.5191	.6986
18		.964	.8522	.8157	1.0154
19		.8898		1.0381	1.0091
20		.6674	.7575	.7415	.7385
21	.48	.4634	.7007	.3708	.72
22	.5169	.3708	.606	.3708	.3692
23	.3323	.2966	.4166	.2966	.3323
24		.3323	.3522	.3788	.2966
Max	.5169	1.0154	1.1123	1.0416	1.1123
Min	.3323	.2966	.3522	.2966	.2966
Avg	.4431	.6027	.6221	.5691	.6742

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054048 / 33/11 KV NATHRA S/S

Feeder No / Name : 206 / Pimpalgaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.08	.0762	.0865	.0762
2		.0914	.1219	.0865	
3		.1067	.1219	.173	.1854
4		.2	.2134	.2595	.2781
5		.4001	.3963	.519	.4572
10		.3048	.3806	.3048	.439
11		.1677	.2422	.2134	.2561
12		.1219	.1557	.1372	.1463
13		.1067	.1038	.0914	.1097
14		.0914	.0865	.0762	.0914
15		.0762	.1038	.0762	.0983
16		.0914	.1384	.0914	.1463
17		.0914	.173		.1829
18		.1981	.3114		.3292
19		.3048		.4268	.4207
20		.2134	.3114	.3048	.3475
21	.16	.1524	.2768	.0914	.3292
22	.1334	.1067	.1038	.0914	.1463
23	.08	.0762	.0865	.0762	.1463
24		.08	.0762	.0865	.0762
Max	.16	.4001	.3963	.519	.4572
Min	.08	.0762	.0762	.0762	.0762
Avg	.1245	.1531	.1831	.1773	.2243

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054048 / 33/11 KV NATHRA S/S

Feeder No / Name : 207 / Pimpalgaon AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1457	
2		.1621	.1621	.1457	
3				.1457	.1621
4		.1621	.1621	.1749	
5		.2432	.2594	.2186	.2432
9		1.4916		1.7781	
10		2.0267	1.9891	2.2374	2.432
11		2.3671	2.1792	.1135	2.7725
12		2.5293	2.1285		2.967
13		2.6914	2.1665	2.8373	2.8373
14		2.74	2.1158	2.9184	2.7563
15			2.0905	2.6103	2.6914
16			2.1792	2.8049	2.5941
17					2.5779
18		.2594	.2027		
19		.2432	.2623	.3405	
20			.2623	.2918	
21	.1783		.2332	.2594	
22		.1621	.204		
23	.1621		.1895	.2108	
24		.1621	.1621	.1457	
Max	.1783	2.74	2.1792	2.9184	2.967
Min	.1621	.1621	.1621	.1135	.1621
Avg	.1702	1.1723	.9970	1.0223	2.2034

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054065 / 33/11 KV DAUTPUR S/S

Feeder No / Name : 203 / 11 KV Wadgaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9			1.4937	1.5123
10	1.7901	1.9216	1.8591	2.1559
11		2.0485		2.1925
12	2.4453	2.4486		
13	2.4249	2.4646		
14		2.4806		
15	2.5232	2.4166	2.3158	
16	2.5587	2.4486	2.4905	
Max	2.5587	2.4806	2.4905	2.1925
Min	1.7901	1.9216	1.4937	1.5123
Avg	2.3484	2.3184	2.0398	1.9536

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054065 / 33/11 KV DAUTPUR S/S

Feeder No / Name : 205 / 11 kv GFSS Wadgaon

GAOTHAN FEEDER

Dadahari Feeder KV- 11 /
OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3		.2263		
4	.3584	.3206		
5	.5281	.4904		
6	.6413	.7167		
9			.5658	.5658
10		.4904	.5658	.415
11		.2829		.3961
12	.2641	.2263		
13	.2263	.1886		
14		.1886		
15	.1698	.2641	.1886	
16	.2263	.3018	.3018	
17	.3395		.415	
18	.5093		.5281	
19	.4904		.6036	
20	.415		.4715	
21	.2829		.3018	
22	.2452		.2263	
23			.1886	
24	.1886	.1886		.1886
Max	.6413	.7167	.6036	.5658
Min	.1698	.1886	.1886	.1886
Avg	.3489	.3238	.3961	.3914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054137 / 33/11 KV KALRATRI PARLI S/S

Feeder No / Name : 201 / 11 KV KANYA SHALA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7377	.7392	.6448	.6244
2	.7392	.7762	.6461	.5877
3	.7423	.8368	.6667	.5895
4	.8589	1.1214	.7274	.7453
5	1.2248	1.3525	1.7147	1.3859
6	1.9805	2.081	1.89	1.7388
7	2.4569	2.8292	2.6999	2.4569
8	2.6379	2.6273	2.8452	2.6326
9	2.5548	2.2941	2.595	2.5172
10	2.2405	2.064	2.2077	2.2359
11	1.8499	1.463	1.7924	1.8595
12	1.6598	1.118	1.5341	1.48
13		1.2712	1.2489	1.1975
14	1.1352	1.0652	1.1065	1.0136
15	1.0641	.9673	.9183	.9794
16	1.1316	.8715	1.0242	1.0608
17	1.5582	1.5498	1.4662	1.6512
18	2.0021	1.7963	1.9918	2.1111
19	1.7002	1.9006	1.9589	1.6632
20	1.4754	1.6111	1.5893	1.5216
21	1.291	1.3292	1.3704	1.2606
22	1.0663	.9714	1.0021	.9221
23	.9221	.7377	.7324	.8273
24	.7722	.74	.6401	.6965
Max	2.6379	2.8292	2.8452	2.6326
Min	.7377	.7377	.6401	.5877
Avg	1.4696	1.4214	1.4589	1.4066

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054137 / 33/11 KV KALRATRI PARLI S/S

Feeder No / Name : 202 / 11 KV KASARWADI FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5497	1.5702	1.2513	1.5107
2	1.5851	1.5702	1.2635	1.5478
3	1.5889	1.6421	1.2568	1.5721
4	1.5553	1.7024	1.2628	1.6232
5	1.559	1.7981	1.2833	1.704
6	1.7918	1.9685	1.3086	1.8065
7			1.4718	
8			1.5949	
9	.2254	1.669	.0751	
10		.148	.0735	
11		.1115		
12			.0364	
13			.0362	
14		.2275	.0355	
15		.0501	.0359	.0914
16		.0703	.036	.1118
17	.1854	.0706	.036	.1498
18	.2241	.0716	.1497	.1504
19	.2222	.0713	.1867	.1494
20	.1842	.0703	.1483	.1481
21	.1459	.0726	.1107	.1103
22	.1451	.0662	.1109	.1097
23	1.442	1.4611	1.2899	1.3603
24	1.4979	1.5889	1.2422	1.4163
Max	1.7918	1.9685	1.5949	1.8065
Min	.1451	.0501	.0355	.0914
Avg	.9268	.8000	.6216	.8476

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054161 / 33/11 KV SANGAM(INDAPWADI)

Feeder No / Name : 201 / 11KV Someshwar SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)
7		.2795
8		.3018
23	1.0669	
Max	1.0669	.3018
Min	1.0669	.2795
Avg	1.0669	.2907

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054161 / 33/11 KV SANGAM(INDAPWADI)

Feeder No / Name : 202 / 11KV Ratneshwar SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17
HR	Load (MW)
20	.9907
23	.3048
Max	.9907
Min	.3048
Avg	.6478

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054161 / 33/11 KV SANGAM(INDAPWADI)

Feeder No / Name : 203 / 11KV Kapileshwar SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17
HR	Load (MW)
20	.3048
23	.1524
Max	.3048
Min	.1524
Avg	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054049 / 33 KV S/S DEWADI

Feeder No / Name : 201 / 11 kv Dewadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.5087	.5087	1.1717	1.0002
4	.6516	.6783		1.1888
5			1.3765	
6	1.1317	.9835		1.7101
7			1.8313	
8	.9221	1.0513	1.7604	1.7772
9		1.0774		
10	1.7126		.6859	.5596
11			.4458	.583
12	.2997			
14	.1665			
15			.2572	
16	1.8023			
17			.4334	
18	.6516			
20	.823			
22	.4409			
24	.4115	.4409	1.0402	.8977
Max	1.8023	1.0774	1.8313	1.7772
Min	.1665	.4409	.2572	.5596
Avg	.7935	.7900	1.0003	1.1024

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054049 / 33 KV S/S DEWADI

Feeder No / Name : 203 / 11 Kv Khalwat Limbgaon SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	1.1989	1.3321	.2664	.3164
4	1.2988	1.4653	.4163	.4496
6	1.3654	1.5819	.5828	.6328
8	1.5652		.5162	.5328
10	.3497		1.4154	1.9149
11			1.7484	1.9649
12				2.0648
13				2.2979
14				2.198
15			1.4653	1.9815
16	.1832			2.2979
17			.2831	
18	.3663			
20	.3996			
22	.2997			
24	1.1489	1.1989	.2664	.2664
Max	1.5652	1.5819	1.7484	2.2979
Min	.1832	1.1989	.2664	.2664
Avg	.8176	1.3946	.7734	1.4098

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054090 / 33 KV S/S LAUL

Feeder No / Name : 201 / 11 Kv Laul SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3201	.2972	.2905	.3138
2		.3258	.3368	.2972	.3096
3		.4784	.3841	.2905	.3841
4		.506	.4572	.4915	.4784
5		.4902	.5243	.502	.5407
9		.6154	.5801	.5376	.5898
10		.5498		.4988	.5247
11		.4793	.4001	.5001	.4877
15		.4252		.4534	.423
16		.5075	.5001	.4793	.4254
17		.5335	.4801	.4938	.5275
18		.7682	.5201	.5335	.5213
19		.5658	.4572	.4995	.483
20	.4235	.4961	.503	.4416	.4384
21	.4012	.4721	.4268	.3909	.3982
22	.3692	.4489		.3668	.3498
23	.3414	.378	.3022	.3292	.3144
24		.3201	.3201	.3022	.3086
Max	.4235	.7682	.5801	.5376	.5898
Min	.3414	.3201	.2972	.2905	.3086
Avg	.3838	.4822	.4326	.4277	.4344

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054090 / 33 KV S/S LAUL

Feeder No / Name : 202 / 11 Kv Pathrud SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7316	.9328	.8162	.8169
2		.7659	.9602	.9328	.881
3		.7926	1.0425	1.0562	.9739
4		.9957	1.1279	1.2163	1.0848
5		1.1111	1.2163	1.2323	1.1584
6		1.2346	1.4632	1.5242	1.3245
7		1.358	1.5779	1.6324	1.4373
8		1.5623	1.6604		1.4864
9		.3772	.3961	.5228	.3921
10		.3206		.3475	.2452
11		.2286	.3018	.2378	.1867
12		.2195	.2743	.2155	.1867
13		.2218	.2926	.1595	.1867
14			.2772		
15			.2378		.1698
16		.2218	.2195	.1848	
17		.2835	.2957	.2402	.2865
18		.4298	.439	.3841	.3696
19		.3856	.4435	.4024	.439
20	.3856	.3391	.3201	.333	.4207
21	.2622	.3018	.2818	.2622	.2683
22	.2652	.2881	.2286	.2486	.2818
23	.2622	.2743	.2439	.2374	.2622
24		.2543	.2317	.2561	.208
Max	.3856	1.5623	1.6604	1.6324	1.4864
Min	.2622	.2195	.2195	.1595	.1698
Avg	.2938	.5772	.6289	.5925	.5939

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054090 / 33 KV S/S LAUL

Feeder No / Name : 203 / 11 Kv Pardi Mategaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.8067	.8623	.8318	.9023
10	.7846		.8116	.9318
11	.8345	.9587	.823	.9587
12	.8623	.9469	1.0084	1.0014
13	.9457	.9736	1.0105	.9875
14	.9457	1.0151	.9701	.9587
15	.9305	1.2346	.9596	
16	.9164	.9717	1.0288	.9412
Max	.9457	1.2346	1.0288	1.0014
Min	.7846	.8623	.8116	.9023
Avg	.8783	.9947	.9305	.9545

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054130 / 33 KV Kuppa Sub-station

Feeder No / Name : 201 / 11kv kuppa SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3258	1.3413	.9962	1.0364
2		.3258	1.2574	1.0437	1.0364
3		.362	1.3413	1.0753	1.0688
4		.4344	1.3413	1.1069	1.1012
5		.5068	1.3413	1.1702	1.1336
6		.7964		1.2334	1.2955
7		.9412	1.8023	1.5497	1.4575
8		.9774		.8223	.9774
9		.8688	.6706	.759	.905
10		.5243	.5376	.543	.5247
11		.2949			.3704
12		.2515			.3086
13		.2515			.216
14		.2515			.1852
15				.181	
16		1.4754	.3479	.362	.2469
17		1.6766	.506		.4938
18		1.5089	.6325	.724	.6173
19		1.5089	.5376	.7602	.5864
20		1.5424	.4428	.543	.4321
21		1.5089	.3795	.3982	.3704
22	1.4899	1.5089	.3163	.3258	.3086
23	1.4575	1.5089	.2846	.2896	.2778
24		.3258	1.3413	.9488	.9717
Max	1.4899	1.6766	1.8023	1.5497	1.4575
Min	1.4575	.2515	.2846	.181	.1852
Avg	1.4737	.8555	.8483	.7806	.6922

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054130 / 33 KV Kuppa Sub-station

Feeder No / Name : 202 / 11KV UPALI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.4575	.0671	.0655	.0724
2		1.4899	.0671	.1311	.0724
3		1.4899	.1341	.1638	.0724
4		1.4899	.2012	.1966	.181
5		1.5223	.2012	.2294	.2172
6		1.5546	.2683	.2622	.4344
7		1.6194	.2683	.2294	.4344
8		.2896	1.5424	2.1628	2.332
9		.2172	1.7695	2.2939	2.4615
10		.1341	1.8351	2.2672	2.4326
11		.0671	2.0317	2.3967	2.5606
12		.0671			
13			1.8023		2.5606
14		.0671	2.1628		3.0727
15		.0671	2.2283	2.5263	3.0727
16		.0671		.0724	.064
17		.0671	.1638	.1448	.128
18		.2012	.1966	.2172	.2561
19		.2683	.1638	.2896	.192
20		.2012	.1311	.2172	.128
21		.1341	.1311	.0724	.128
22	.0724	.0671	.0655	.0724	.064
23	.0724	.0671	.0655	.0724	.064
24		1.3603	.0671	.0655	.0724
Max	.0724	1.6194	2.2283	2.5263	3.0727
Min	.0724	.0671	.0655	.0655	.064
Avg	.0724	.6072	.7075	.6738	.9162

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054130 / 33 KV Kuppa Sub-station

Feeder No / Name : 203 / 11KV RAJEWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.543	.4694	.6036	.4706
2		.543	.4694		.4706
3		.5792	.5868	.6874	.5068
4		.6516	.6706	.7712	.543
5		.8688	.8383	.8383	.8688
6		1.1946		.9054	1.1946
7		1.2308		1.0059	1.1946
8		1.3279	1.1065	.9892	1.1222
9		1.7814	.8383	.7377	.9774
10		1.9006	.5365	.543	.5967
11		1.7695		.3258	.3315
12		1.9662	.3018		.2652
13		1.9662	.285		.2984
14		1.9006	.2683		.3315
15		1.8842	.285	.2896	.3647
16		.3018	1.7101		2.3537
17		.6036	1.8778	2.5911	2.9172
18		.8383	.4694	2.5263	.7956
19		1.0395	1.576	2.4615	2.0553
20		.6036	1.8107	2.2672	1.989
21		.503	1.8442	2.1052	1.8896
22	.5792	.503	1.7772	2.0405	1.7901
23	.543	.503	1.6095	1.9433	1.6575
24		.543	.503	.4024	.4706
Max	.5792	1.9662	1.8778	2.5911	2.9172
Min	.543	.3018	.2683	.2896	.2652
Avg	.5611	1.0644	.9445	1.2650	1.0606

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

ASHTI (R) S/DN[415] BU 2551

Substation No/ Name :- 054120 / Ashti

Feeder No / Name : 201 / Ashti Urban

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8002	.7621	.8002	.7621
2	.7811	.8002	.8573	.743
3	.8192	.7811	.8573	.724
4	.8954	.9335		.9335
5	1.1241	.9335		1.2384
6	1.5623	1.5432		1.6194
7	2.1148	2.0576	2.0195	2.1719
8	2.3243	2.1529	2.2291	2.3815
9				2.1148
10	2.1529	1.6766	1.7718	1.8671
11			1.5432	1.5813
12	1.6385	1.8671	1.5813	1.5623
13	1.6385	1.4289	1.448	1.4861
14	1.5051	1.086		1.3336
15	1.3717	1.2003		1.3336
16	1.2384	1.2955	1.3717	
17	1.4861	1.5432	1.6004	1.467
18	1.7337	1.7147	1.6956	1.7909
19	1.9433	1.9243	1.9243	1.8861
20	1.4289	1.5242	1.5813	
21	1.2384	1.2955	1.3146	
22	.9335	.9526	1.0669	
23	.7811	.8573	.9145	
24	.7811	.7049	.7621	.7811
Max	2.3243	2.1529	2.2291	2.3815
Min	.7811	.7049	.7621	.724
Avg	1.3769	1.3198	1.4077	1.4620

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

ASHTI (R) S/DN[415] BU 2551

Substation No/ Name :- 054124 / TAKALI AMIYA

Feeder No / Name : 201 / 11 TAKALI AMIYA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.285	.9221	1.2742	1.0059	1.0395
2		.3353	1.0059	1.1469	1.0898	1.0898
3		.4694	1.0059	1.1469	1.2574	1.2452
4		.7545	1.0059	1.3927	1.4251	1.6385
5		1.0059	1.3413	1.8023	1.6766	1.9662
6		1.073	1.7404	1.8023	1.8442	2.2119
7		1.0395	1.989	1.8187	2.3205	2.343
8			2.1548	2.3102	2.4863	2.6871
9	.4359		2.2377	2.3758	2.2939	2.652
10	.4024		1.989	2.2939	2.2611	2.431
11	2.0119		.4973	.4096		.1696
12	2.2283		.4359	.3353	.2515	.1696
13	2.3758		.4024		.2347	.1696
14	2.2283				.218	.1865
15	2.7854				.2012	.2204
16	2.8334				.218	.2543
17	2.7854	2.4863			.2347	.2713
18	2.8182	2.2377	.7545		.8383	.4239
19	.7373	.503	.8718	.5935	.9724	.763
20	.9175	1.0174	.9054	1.0174	1.0059	1.0174
21	.9503	.8478	.8048	.8478	.9054	.9326
22	.5735	.6783	.6706	.763	.8383	.763
23	.3018	.5935	.7545	.5335	.6706	.6783
24		.2949	.4409	.4694	.4239	.5087
Max	2.8334	2.4863	2.2377	2.3758	2.4863	2.6871
Min	.3018	.285	.4024	.3353	.2012	.1696
Avg	1.6257	.9081	1.0965	1.2407	1.0728	1.0764

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

ASHTI (R) S/DN[415] BU 2551

Substation No/ Name :- 054124 / TAKALI AMIYA

Feeder No / Name : 202 / 11 KV CHOBHA NIMGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2574	.4239	.4359	.4239	.5087
2		1.6712	.4239	.4024	.4239	.4748
3		1.8023	.4239	.503	.4239	.407
4		1.9662	.5087	.57	.4239	.4748
5		1.9334	.5935	.6036	.5087	.5087
6		2.0454	.6783	.6706	.5765	.5935
7		2.3472	.5935	.57	.5596	.5596
8		2.431	.5935	.503	.5596	.3561
9	2.3205		.5087	.503		.1696
10	.1658			.4191		
11	.1658		1.6907	1.8442		1.9281
12	.1658		2.7183	2.6322	2.6216	2.4863
13			2.7681	2.6825	2.7035	2.8178
14			2.6871	2.8502	2.7035	2.7035
15	.1341		2.652	2.652	2.6216	2.7035
16	.1509		2.6543	2.5692	2.6993	2.6216
17	.1509	.2543	2.6216	2.5149	2.6825	2.5987
18	.5868	.4239	2.3758	2.5149		2.5149
19	.5868	.5087	.6036	.5087	.5426	.5087
20	.6706	.6783	.6371		.6443	.6783
21	.7545	.5935	.6783	.6783	.6783	.5935
22	.7545	.5935		.5935	.6104	.5935
23	.503	.5087	.6783	.5087	.5935	.5087
24		.4191	.4239	.4694	.4578	.5596
Max	2.3205	2.431	2.7681	2.8502	2.7035	2.8178
Min	.1341	.2543	.4239	.4024	.4239	.1696
Avg	.5469	1.2146	1.2699	1.2261	1.1729	1.2117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

ASHTI (R) S/DN[415] BU 2551

Substation No/ Name :- 054127 / 33/11 KV DAULAWADGAON SUB

STAT

Feeder No / Name : 201 / 11 KV SALEWADGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	20-DEC-17
HR	Load (MW)
24	.4111
Max	.4111
Min	.4111
Avg	.4111

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

ASHTI (R) S/DN[415] BU 2551

Substation No/ Name :- 054127 / 33/11 KV DAULAWADGAON SUB

STAT

Feeder No / Name : 202 / 11 KV DAULAWADGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	20-DEC-17
HR	Load (MW)
24	.5138
Max	.5138
Min	.5138
Avg	.5138

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

ASHTI (R) S/DN[415] BU 2551

Substation No/ Name :- 054127 / 33/11 KV DAULAWADGAON SUB

STAT

Feeder No / Name : 203 / 11 KV PIMPALGAON GHAT SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	20-DEC-17
HR	Load (MW)
24	1.5746
Max	1.5746
Min	1.5746
Avg	1.5746

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054050 / 33/11 KV. MALIVES S/S, BEED

Feeder No / Name : 201 / 11 KV. TILAK ROAD FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.8954
2				.8775
3				.8596
4				.8775
5	.8871	.9055		.9313
6		1.1827		1.1462
7	1.4784	1.4784	2.0271	1.4327
8	1.6263	1.6448	1.8099	1.6655
9	1.5203	1.6095	1.8296	1.7556
10	1.5203	1.5384		1.7002
11	1.5023	1.448		1.6263
12	1.3756	1.3987		
13	1.267	1.3032	1.7741	
14	1.1584	1.2308		
15	1.086	1.2071		
16		1.1222		
17	1.4685	1.3611		
18	1.9163	1.7909	2.5339	1.9185
19	2.1491	1.9521	2.5701	2.0271
20	1.7909	1.7909	2.3529	1.8823
21	1.5043	1.5402	1.8099	1.5729
22	1.2894	1.4784	1.7375	1.3394
23	.9979		1.0387	
24	.9055	.924	.788	.8954
Max	2.1491	1.9521	2.5701	2.0271
Min	.8871	.9055	.788	.8596
Avg	1.4135	1.4162	1.8429	1.3767

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054050 / 33/11 KV. MALIVES S/S, BEED

Feeder No / Name : 202 / 11 KV. JALNA ROAD FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3582	.3658
2			.3258	.3005
3			.3224	.2846
4				.2915
5	.39	.3688		.3605
6		.4748		.4641
7	.6878	.5898	1.0387	.6443
8	.6036	.6554	.9412	.703
9	.6401	.6447	.8029	.7682
10	.5761	.5792		
11	.5506	.5792		
12	.4858	.5487		
13	.4534	.5068	.6722	
14	.4372	.5121	.5182	
15	.4372	.6335	.3953	
16		.543		
17	.4915	.5898	.5792	.5068
18	.6882	.6371	.6154	.6516
19	.6554	.7042	.7602	.7316
20	.5967	.6036	.6516	.6878
21		.5243	.5373	.5792
22		.4588	.4755	.4525
23	.3856		.3605	
24	.3222	.3391	.3658	.3353
Max	.6882	.7042	1.0387	.7682
Min	.3222	.3391	.3224	.2846
Avg	.5251	.5523	.5718	.5080

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054050 / 33/11 KV. MALIVES S/S, BEED

Feeder No / Name : 203 / 11 KV MONDHA ROAD FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.543	.6468
2			.5014	.6283
3			.5068	.5914
4				.6283
5	.7577			1.1827
6		1.1949		1.1949
7	1.5466	1.5844	2.0633	1.643
8	1.6598	1.5655	1.9547	1.7551
9	1.5181	1.5565	1.8298	1.6787
10	1.3535	1.3169		1.4377
11	1.1523	1.1706		
12	1.0059	1.0136		
13	.9145	.905	1.0749	
14	.8048	.8326		
15	.7602	.7316	.9492	
16		.724		
17	1.0349	.961	.9145	.9511
18	1.4563	1.2567	1.3535	1.3032
19	1.2936	1.4003	1.4998	1.3611
20	1.1949	1.1949	1.2308	1.2308
21	1.1203	1.0349	1.0498	1.0136
22	.924	.8962	.9313	.9145
23	.6626		.7023	
24	.6401	.6268	.5792	.6468
Max	1.6598	1.5844	2.0633	1.7551
Min	.6401	.6268	.5014	.5914
Avg	1.1000	1.1092	1.1053	1.1064

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054050 / 33/11 KV. MALIVES S/S, BEED

Feeder No / Name : 205 / 11 KV Jillha Parishad

SHEDDABLE URBAN

Feeder Feeder KV- 11 /
OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.362	.439
2			.3224	.4755
3			.2896	.5121
4				.4755
5	.499	.4805		
6		.8871		
7	.924	.924	1.267	
8	.924	.8501	1.0498	
9	.7682	.9412	.8131	.8871
10	.6516	.8413		
11	.6154	.6878		
12	.4706	.5487		
13	.4706	.5121	.6283	
14	.4706	.4706	.4805	
15	.4706	.4525	.4805	
16		.5068		
17	.6219	.5121	.543	.6584
18	.7682	.7133	.8048	.7164
19	.8215	.8413	.905	.8596
20	.7682	.7316	.8413	.7964
21		.7316	.724	.7602
22		.6584	.6516	.6401
23	.4805		.4755	
24	.4435	.462	.3982	.439
Max	.924	.9412	1.267	.8871
Min	.4435	.4525	.2896	.439
Avg	.6355	.6712	.6492	.6383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054061 / 33/11 KV. DHANORA ROAD S/S

Feeder No / Name : 201 / 11 KV. DHANORA ROAD FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	20-DEC-17
HR	Load (MW)
9	.6097
13	.3963
Max	.6097
Min	.3963
Avg	.503

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054061 / 33/11 KV. DHANORA ROAD S/S

Feeder No / Name : 203 / 11 KV. PALWAN FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	20-DEC-17
HR	Load (MW)
9	.3292
13	.6767
Max	.6767
Min	.3292
Avg	.5030

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

LATUR ZONE, LATUR[068]

LATUR ZONE, LATUR[068]

LATUR ZONE, LATUR[068]

LATUR ZONE, LATUR[068]

LATUR ZONE, LATUR[068]

LATUR ZONE, LATUR[068]

DATE	20-DEC-17
HR	Load (MW)
9	.0549
13	.0366
Max	.0549
Min	.0366
Avg	.0458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054061 / 33/11 KV. DHANORA ROAD S/S

Feeder No / Name : 205 / 11 KV BALEPEER FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	20-DEC-17
HR	Load (MW)
9	2.3777
Max	2.3777
Min	2.3777
Avg	2.3777

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054061 / 33/11 KV. DHANORA ROAD S/S

Feeder No / Name : 206 / 11KV COLLECTOR OFFICE NON SHEDDABLE EXPRESS HV FEEDERS
EXPRESS Feeder KV- 11 / (CONTINOUS PROCESS)(NO STAGGERING)
OUTGOING

DATE	20-DEC-17
HR	Load (MW)
9	.0221
13	.0332
Max	.0332
Min	.0221
Avg	.0277

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054061 / 33/11 KV. DHANORA ROAD S/S

Feeder No / Name : 207 / 11 KV Natyagruh feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	20-DEC-17
HR	Load (MW)
9	2.1399
13	1.701
Max	2.1399
Min	1.701
Avg	1.9205

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054082 / 33/11 KV. MIDC S/S, BEED

Feeder No / Name : 201 / 11 KV. GORE FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5144	.3086	.3429
2			.4801	.3086	
3			.463	.3429	
4			.4801	.3772	.3772
5			.463	.4115	.4115
6			.5316	.4458	.4458
7			.6001	.4115	.4973
8			.6173	.3772	.4801
9		.4115	.6173		.6001
10		.6516	.7716		.823
11		.6001	.7373		.8059
12		.703	.7202		.7888
13		.7888			.6859
14	.7888	.7888	.6687		.6344
15	.823	.8059	.8059		.703
16	.823	.8059	.7373		.7888
17		.583	.7716	.1372	
18		.8573	.7716	.1886	
19		.7545	.7716	.1886	
20		.7888		.2058	
21		.5316	.5487	.2743	
22		.5316	.463	.3944	
23		.5316			
24			.5658	.4287	.3601
Max	.823	.8573	.8059	.4458	.823
Min	.7888	.4115	.463	.1372	.3429
Avg	.8116	.6756	.6238	.3201	.5830

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054082 / 33/11 KV. MIDC S/S, BEED

Feeder No / Name : 202 / 11 KV. N.K. FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4877	.4572	.4268
2			.4877	.4572	
3			.4877	.4572	
4			.503	.4877	.4572
5			.5792	.4877	.4877
6			.6097	.4877	.4877
7			.5487	.4877	.6097
8			.6249	.4877	.6859
9		.7621	1.0364		.9145
10		.9145	.9755		.9145
11		.8688	.4877		.9907
12		.8535			1.0364
13		.7316			.9145
14	1.9814	.7621	.9145		1.0669
15	1.0669	.8535	1.0974		1.0669
16	1.0974	.8535	1.1279		1.0364
17		.8383	.9145	.2439	
18		.823	.823	.2743	
19		.823	.9755	.3048	
20		.7011	.6706	.2743	
21		.5792	.6706	.4572	
22		.4877	.6249	.5487	
23		.4973			
24			.5335	.4744	.4877
Max	1.9814	.9145	1.1279	.5487	1.0669
Min	1.0669	.4877	.4877	.2439	.4268
Avg	1.3819	.7566	.7229	.4258	.7722

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054082 / 33/11 KV. MIDC S/S, BEED

Feeder No / Name : 203 / 11KV POLYTECHNIC COLLEGE FEEDER SEPERATION/PURE AG
feede Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0514	.0686	.1029
2			.0686	.0686	
3			.0686	.0686	
4			.0514	.0686	.1715
5			.0514	.1715	.2058
6			.12	.2229	.2572
7			.12	.2915	.3086
8			.1543	.3429	.3601
9		.3944	.12		.3601
10		.2743	.12		.3601
11		.2572	.1372		.3429
12		.2915	.1372		.2401
13		.3258			.3258
14	.2401	.3086	.0857		.3429
15	.2743	.2743	.1029		.3258
16	.3258	.2401	.12		.3601
17		.2743	.12	.3086	
18		.3201	.12	.2915	
19		.3258	.1029	.2915	
20		.2743	.0857	.2401	
21		.2229	.1543	.1715	
22			.1029	.1372	
24			.1543	.0686	.1029
Max	.3258	.3944	.1543	.3429	.3601
Min	.2401	.2229	.0514	.0686	.1029
Avg	.2801	.2910	.1068	.1875	.2778

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054082 / 33/11 KV. MIDC S/S, BEED

Feeder No / Name : 204 / 11 KV BAHIRWADI FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3506	.3353	.3353
2			.3353	.3353	
3			.3353	.3658	
4			.4115	.381	.6097
5			.5639	.4877	.7926
6			1.0669	.8535	1.0364
7			1.2193	1.0669	1.2193
8			1.1888	1.2955	1.1584
9		1.0364	.945		.9755
10		.7926	.945		.884
11		.7621	.7011		.7621
12		.4877	.5487		.7202
13		.4877			.5792
14	.4877	.4115	.4268		.503
15	.4572	.381	.4268		.4268
16	.2439	.3658	.4877		.4572
17		.5335	.6097	.6401	
18		.7621	.7316	.7621	
19		.823	.7926	.7926	
20		.7011		.7316	
21		.5487	.6097	.5487	
22		.4287	.4572	.4572	
23		.4973			
24			.3506	.381	.3429
Max	.4877	1.0364	1.2193	1.2955	1.2193
Min	.2439	.3658	.3353	.3353	.3353
Avg	.3963	.6013	.6431	.6290	.7202

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054082 / 33/11 KV. MIDC S/S, BEED

Feeder No / Name : 205 / 11 KV MAULI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.463	.5144	.4458
2			.5144	.5144	
3			.5144	.5144	
4			.4973	.5316	.4801
5			.6344	.5487	.5487
6			.6001	.6001	.6173
7			.6344	.5487	.6859
8			.6859	.5144	.7716
9		.5658	.7888		.9431
10		.6173	.8916		.9088
11		.583	.7202		.823
12		.6344	.7545		.7373
13		.5487			.6859
14	.5144	.5487	.6516		.6516
15		.6001	.6687		.7202
16	.6001	.6001	.6516		.7716
17		.583	.6859	.3772	
18		.4973	.7716	.3601	
19			.7716	.3944	
20		.6173	.703	.463	
21		.5487	.6344	.4801	
22		.4973	.583	.5487	
23		.5144			
24			.4973	.5658	.4801
Max	.6001	.6344	.8916	.6001	.9431
Min	.5144	.4973	.463	.3601	.4458
Avg	.5573	.5683	.6508	.4984	.6847

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054125 / 33/11 KV JALANA ROAD S/STN

Feeder No / Name : 202 / 11 KV SHANTAI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.3012	.2481	.2658
2	.3292	.3012	.2303	.2658
3	.3475	.3189		.2481
4	.3292	.3189		.2481
5	.3292	.3544		.3012
6	.439	.5138		.4961
7	.6584	.6733	.9214	.6556
8		.691	.7619	.7087
9	.691			.695
10	.6201			.6584
11	.5847			.5487
12	.5316			.4755
13	.4784			.4755
14	.4607			.4755
15	.4607	.4656	.5014	.439
16	.4607	.4755		
17	.4755	.4755	.6584	.5121
18	.5853	.5487	.6584	.6584
19	.6584	.5853	.695	.5853
20	.5487	.5487	.5853	.5304
21	.5121		.5121	.4755
22	.4252	.3898	.443	.4252
23	.3898	.3189	.3544	.3544
24	.3292	.3012	.2481	.2658
Max	.691	.691	.9214	.7087
Min	.3292	.3012	.2303	.2481
Avg	.4771	.4460	.5244	.4680

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054125 / 33/11 KV JALANA ROAD S/STN

Feeder No / Name : 203 / 11KV Ambika Nagar feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9694	.815	.6024	.7265
2	.9511	.7796	.6024	.7265
3	.9511	.7796	.567	.7087
4	.9877	.8328		.7619
5	1.0059	.9214		.815
6	1.5181	1.5415		1.2226
7	2.0119	2.0199	2.2148	1.6478
8		2.0022	2.0199	1.7364
9	1.8073			1.4998
10	1.6655			1.3169
11	1.3643			1.0974
12	1.1517			.9511
13	1.0454			.8779
14	.9922			.8413
15	1.0099	.8417	.8954	.823
16	1.0808	.9877		
17	1.2803	1.0974	1.0974	1.1157
18	1.6095	1.3535	1.2803	1.3717
19	1.6827	1.3535	1.4815	1.39
20	1.4266	1.3169	1.3352	1.3535
21	1.3169		1.1706	1.1706
22	1.0808	1.0099	.9568	.9745
23	.9568	.7973	.7973	.8859
24	.8962	.8328	.6201	.7442
Max	2.0119	2.0199	2.2148	1.7364
Min	.8962	.7796	.567	.7087
Avg	1.2505	1.1343	1.1172	1.0765

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054125 / 33/11 KV JALANA ROAD S/STN

Feeder No / Name : 204 / 11 KV Vitthal Mandir

SHEDDABLE URBAN

Feeder Feeder KV- 11 /
OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1267	.1063	.0886	.124
2	.1086	.1063	.0886	.124
3	.1086	.1063	.0886	.124
4	.1086	.1063		.1417
5	.128	.124		.1772
6	.181	.2126		.2303
7	.3077	.3012	.4252	.2835
8		.2835	.3544	.2835
9	.2481			.1829
10	.2126			.128
11	.1772			.1646
12	.1595			.128
13	.1417			.1463
14	.124			.128
15	.1063	.1254	.1254	.128
16	.124	.1463		
17	.1829	.1646	.1991	.1629
18	.2195	.1829	.2353	.2534
19	.2561	.2012	.3077	.2715
20	.2378	.2012	.3077	.2534
21	.2012		.2896	.2172
22	.1772	.1772	.2481	.1772
23	.1417	.1417	.2126	.1417
24	.1086	.124	.1063	.1417
Max	.3077	.3012	.4252	.2835
Min	.1063	.1063	.0886	.124
Avg	.1690	.1654	.2198	.1788

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054125 / 33/11 KV JALANA ROAD S/STN

Feeder No / Name : 205 / 11 kv Jain Patra Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0709	.0709	
2	.0905	.0709	.0709	.1063
3	.0905	.0709	.0709	.1063
4	.0905	.0709		.1063
5	.1086	.0709		.1063
6	.1086	.124		.1417
7	.1629	.2126	.2126	.1949
8		.2658	.2835	.2835
9	.2481			.2926
10	.2303			.2743
11	.2126			.2378
12	.1772			.2012
13	.1417			.2012
14	.1772			.2012
15	.2126	.2507	.1433	.1829
16	.2658	.2378		
17	.2561	.2378	.1991	.2534
18	.2561	.2561	.2534	.2715
19	.2561	.2195	.2534	.2715
20	.2195	.1829	.2172	.1629
21	.1829		.1267	.1267
22	.0709	.1063	.124	.124
23	.0709	.0886	.1063	.1063
24	.0905	.0709	.0886	.1063
Max	.2658	.2658	.2835	.2926
Min	.0709	.0709	.0709	.1063
Avg	.1657	.1534	.1586	.1845

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054151 / 33/11 KV KHAPAR-PANGARI

S/Stn

Feeder No / Name : 201 / 11 KV Gawli Baba Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.3239			
7	.421			
9		.5344	.431	
10		.57		
11		.5344		
12	.4858	.5571		
13		.5243	.1174	
14	.4534	.4915	.1677	
15		.4696	.2155	
16	.5365	.4191		
17	.4862	.5506	.3239	.4694
18		.4372	.3605	
19		.3887	.3887	
20	.2591		.2753	
22				.2012
Max	.5365	.57	.431	.4694
Min	.2591	.3887	.1174	.2012
Avg	.4237	.4979	.285	.3353

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054151 / 33/11 KV KHAPAR-PANGARI

S/Stn

Feeder No / Name : 202 / 11 KV Shivneri Feeder
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
9		.1677	
13		.218	
14		.1844	
15	.0972	.1823	
16	.1341		
17	.1658	.1619	.1677
18	.2155	.1943	
19	.2321	.2155	
20		.1989	
22			.1509
Max	.2321	.218	.1677
Min	.0972	.1619	.1509
Avg	.1689	.1904	.1593

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054003 / 33/11 KV. CHOUSALA

Feeder No / Name : 201 / 11 KV. CHOUSALA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.5573	.4334	.5144	
4	.6192	.6192		
6	.8802	.6811	.8135	.8421
11	.6763	.567		.6668
12	.6763	.6001		
13	.6087	.6142		.744
14	.6859	.5197		.6859
15	.7545			.6859
16		.6097		.6859
17	.6763	.6241		.6173
18	.823			.7545
19	.8049	.743	.7773	.8049
20	.743			.743
21	.5573	.5578		.6192
22	.4954			.5573
24	.4954	.4334		.5182
Max	.8802	.743	.8135	.8421
Min	.4954	.4334	.5144	.5182
Avg	.6702	.5836	.7017	.6865

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054003 / 33/11 KV. CHOUSALA

Feeder No / Name : 202 / 11 KV. SULTANPUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.191		
2	.5106	.4468	.5735	
4	.6382	.5744		
6	.8297	.9717	.7087	.8421
12	.3829			
13		.4068		
14	.3829	.3487		.3829
15	.3829			.3829
16		.2858		
17	.5106	.3254		.4468
18	.7125			.5106
19	1.7147	.7087	.7773	1.7147
20	2.6578			
21	2.6863	1.9662		1.9281
22	2.4539			1.7528
24	2.4539	2.3282		1.2955
Max	2.6863	2.3282	.7773	1.9281
Min	.3829	.2858	.5735	.3829
Avg	1.2551	.9594	.6865	1.0285

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054003 / 33/11 KV. CHOUSALA

Feeder No / Name : 204 / 11 KV. HINGNI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.1829	.1463	.1743	
4	.2439	.2439		
6	.4954	.5573	.4881	.5182
11	.5335	.6001		
12	.6087	.7316		
13		.7442		.8916
14	.8116	.7202		.9602
15				1.0974
16	.8116	.7202		
17	.8116	.756		1.0574
18	.8916			1.0574
19	.4334	.4134	.3887	.4334
20	.3715			.3715
21		.2858		
22	.1829			.2477
24	.1829	.1829		.1943
Max	.8916	.756	.4881	1.0974
Min	.1829	.1463	.1743	.1943
Avg	.5047	.5085	.3504	.6829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054003 / 33/11 KV. CHOUSALA

Feeder No / Name : 205 / 11 KV ANJANWATI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.1886	.1886	.5487	
3		1.7147		
4	1.7528	2.1033		
5		2.1491		
6	2.2386	2.3282		1.6194
7	2.6292	2.5339	1.5604	
8	3.0445	2.9264	1.7071	
9	2.955		1.9509	
10	2.8654			2.8654
17	.1509	.3429		
18	.3191			.3191
19	.4468	.3429	.3887	.4468
20	.3829			.4468
21	.3191	.2953		.3829
22	.2553			.3191
24	.2515	.2515		.1943
Max	3.0445	2.9264	1.9509	2.8654
Min	.1509	.1886	.3887	.1943
Avg	1.2714	1.3797	1.2312	.8242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054032 / 33/11 KV. S.S LIMBAGANESH

Feeder No / Name : 202 / 11 KV. KALEWADI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.4024	.4527	.5335
11				.5335
16	.6478		2.2447	1.4083
17		1.8404		
24		.1886	.1867	.2829
Max	.6478	1.8404	2.2447	1.4083
Min	.6478	.1886	.1867	.2829
Avg	.6478	.8105	.9614	.6896

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054032 / 33/11 KV. S.S LIMBAGANESH

Feeder No / Name : 203 / 11 KV. BORKHED SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.9431	1.2378	1.442
16	.1943	.2587		
17			.2286	
24		.2772	.4207	.4108
Max	.1943	.9431	1.2378	1.442
Min	.1943	.2587	.2286	.4108
Avg	.1943	.493	.6290	.9264

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054032 / 33/11 KV. S.S LIMBAGANESH

Feeder No / Name : 204 / 11 KV LIMBAGANESH SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.3696	.3547	.2801
16	.1696	.1357	.1372	.192
24		.132	.0934	.124
Max	.1696	.3696	.3547	.2801
Min	.1696	.132	.0934	.124
Avg	.1696	.2124	.1951	.1987

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054034 / 33/11 KV. S/S PENDGAON

Feeder No / Name : 201 / 11 KV. SIDDOD FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			.3658	
4	.6493	.6493		
5				.1867
11	.5731	.6859		
12		.9297		1.3717
13			.6353	
14		.9602		1.4022
15	.6493	.9602	.628	
16		.9602		1.4632
17		1.1584		1.326
18		1.1279	1.1096	1.2955
19	.6338	.6859	.4329	.5335
24	.3733	.3529	.3048	
Max	.6493	1.1584	1.1096	1.4632
Min	.3733	.3529	.3048	.1867
Avg	.5758	.8471	.5794	1.0827

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054034 / 33/11 KV. S/S PENDGAON

Feeder No / Name : 204 / 11 KV. MIDC PENDGAON
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
2		.9755	
5			.6237
7		.9755	
8		.8535	1.0713
10	1.2346		1.0517
11	1.2041		
12	1.1279		1.0364
13		.0974	
14	1.1279		.442
15		.1564	
16	1.3108		1.1431
17	1.4175		1.2193
18	1.3565	.2541	1.0364
19	1.0669	.3925	.9907
24		1.0212	
Max	1.4175	1.0212	1.2193
Min	1.0669	.0974	.442
Avg	1.2308	.5908	.9572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054034 / 33/11 KV. S/S PENDGAON

Feeder No / Name : 205 / 11 KV KUMSHI NEW FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.5165	.4591		
5				.4283
7	.9886	.9182		
10	1.1003			
19	.3251		.3246	
24	.1599	.1973		
Max	1.1003	.9182	.3246	.4283
Min	.1599	.1973	.3246	.4283
Avg	.6181	.5249	.3246	.4283

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054034 / 33/11 KV. S/S PENDGAON

Feeder No / Name : 206 / 11 KV KUKKADGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.1004			
4	.373	.4155		
5				.257
7		.6447		
10	.659			
19	.2371		.2824	
24	.1004	.1146		
Max	.659	.6447	.2824	.257
Min	.1004	.1146	.2824	.257
Avg	.2940	.3916	.2824	.257

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054036 / 33/11 KV. PIMPALNER S/S

Feeder No / Name : 202 / 11 KV. GHATSAWALI FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.181		.1715
2	.1715	.362		.1715
3	.1715	.362		.2058
4	.2058	.543		.3086
5	.3086	.724		.5144
6	.5487	.8145		
7	.6859	.9955		
8	.823	.8507	.2035	.8048
9	.6001	.724	.5087	
10	.3801			
11	1.9616			1.2003
12	2.146	2.4863		1.3717
13	2.1795		2.1776	1.7147
14	2.3304			1.5775
15	2.2634		.6859	1.3717
16	2.0622	2.4006	1.166	1.0288
17	2.146		1.3203	1.0288
18	.4525	2.0576	1.2346	1.1145
19	.5068		.6173	.5544
20	.6335	.4287		.4435
21	.543			.3734
22	.5068	.2012		.3361
23	.2715			.2801
24	.1715	.181		.1715
Max	2.3304	2.4863	2.1776	1.7147
Min	.1715	.181	.2035	.1715
Avg	.9267	.8875	.9892	.7372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054036 / 33/11 KV. PIMPALNER S/S

Feeder No / Name : 203 / 11KV GUNDHA NEW FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.0934		
2	.1029	.0934		
3	.1029	.0934		
4	.1372	.1494		
5	.2401	.1494		
6	.2743	.1867		
7	.3086	.2241		
8	.3429	.4481	.373	
9	.2915	.2614	.4115	
10	.1494			.1867
11	.6036			.5144
12	.6203	.2543		.6001
13	.6371		.2058	.6001
14			.3944	.6001
15			.3086	.5487
16	.0857	.2401		.4801
17	.2515		.3772	.5487
18	.2715	.2572	.3429	.6001
19	.2715		.3258	.3326
20	.5041	.2713		.2801
21	.3921			.2054
22	.1867	.0838		.168
23	.1307			.1307
24	.1029	.0934		
Max	.6371	.4481	.4115	.6001
Min	.0857	.0838	.2058	.1307
Avg	.2777	.1933	.3424	.4140

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054053 / 33/11 KV. S/S SHIVNI

Feeder No / Name : 201 / 11 kv Shivni feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1653	.1658	.3039	.2479
2	.1928	.166	.3306	.2617
3	.2204	.2069	.3315	.2893
4	.2204	.2479	.3581	.2893
5	.2342	.3068	.3841	.303
6	.2342	.3448	.4132	.303
7	.1928	.4396	.4282	.4683
8	.2342	.3846	.631	.5923
9	.1931	.4138	.5111	.5923
10	.2069	.442		.5495
Max	.2342	.442	.631	.5923
Min	.1653	.1658	.3039	.2479
Avg	.2094	.3118	.4102	.3897

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054053 / 33/11 KV. S/S SHIVNI

Feeder No / Name : 202 / 11 MOCHI PIMPALGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8318	.8551	.7339	.7639
2		.9336	.9263	.8378	.8318
3		.9846	1.0332	.9002	1.375
4		1.0694	1.1223		1.5108
5		1.2222	1.247		1.6296
6		1.375			2.0201
7		1.3411			2.1219
8		1.358			2.3256
9		1.6567			2.3256
10		1.7814	.2631		2.2831
11			.2202		.4275
12			.2701		.3563
13		.4097	.2466		.3741
14		.4097	.1631		.4097
15		.4632	.3617		.4097
16		.4988	.5137		
17		.5878	.4753		.5166
18		.6562	.7581		.6591
19		.766	.7251		.8016
20		.7813	.7339	.8148	.7482
21		.7125	.6543	.679	.6947
22	.6281	.6591	.5464	.6111	.6769
23	.5772	.6235	.51	.6111	.6435
24		.5262	.57	.51	.6111
Max	.6281	1.7814	1.247	.9002	2.3256
Min	.5772	.4097	.1631	.51	.3563
Avg	.6027	.8931	.6098	.7122	1.0659

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054053 / 33/11 KV. S/S SHIVNI

Feeder No / Name : 203 / 11 KV Indestrial feeder SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0917	.0355	.0727	.055
2		.0917	.0355	.0727	.0367
3		.0734	.0356	.0729	.0367
4		.0734	.0356	.0729	.0183
5		.0734	.0534	.0545	.0183
6		.0734	.0533	.0545	.0183
7		.0734	.0891	.055	.0183
8		.0734	.0713	.054	.055
9		.0534	.1247	.0546	.055
10		.0355	.162		.1247
11		.0713	.1468		.1069
12		.0534	.1272		.0891
13		.0356	.1284		.1247
14		.0709	.126		.1247
15		.1065	.1275		.1247
16		.0713	.126		.1247
17		.1069	.1284		.1603
18		.0713	.1284		.1247
19		.0713	.1275		.0713
20		.0552	.1284		.0534
21		.0355	.1271	.0367	.0533
22	.0734	.0356	.1278	.0183	.0356
23	.0734	.0356	.1275	.0367	.0534
24		.0917	.0713	.1275	.055
Max	.0734	.1069	.162	.1275	.1603
Min	.0734	.0355	.0355	.0183	.0183
Avg	.0734	.0677	.1018	.0602	.0724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054053 / 33/11 KV. S/S SHIVNI

Feeder No / Name : 204 / 11 kv Borfadi feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.564	.3919	.2914	.3093
2		.5822	.4988	.3278	.3275
3		.6004	.57	.4403	.3821
4		.746	.6769	.5816	.655
5		.8733	.7482	.765	.8733
6		.9643	.8372	.9471	1.0371
7		1.1281	1.0154	.9471	1.2008
8		.9643	1.0688	.9078	.7096
9			.766	.6557	.7096
10		.481	.4553		.5166
11		1.5854	2.088		2.4048
12		1.8882	2.2505		2.4405
13		2.3692	2.2815		3.3846
14		2.0308	2.2685		3.2065
15		2.0664	2.1856		3.0283
16		2.1308	2.2949		2.8502
17		2.1911	2.3471		2.8858
18		2.2267	1.5304		2.6186
19		.7125	.8462		
20		.6769	.7339	.6186	.7125
21		.6235	.5828	.564	.6769
22	.0728	.5878	.478	.4003	.6769
23	.5822	.57	.2881	.3275	.7125
24		.564	.285	.2905	.2911
Max	.5822	2.3692	2.3471	.9471	3.3846
Min	.0728	.481	.285	.2905	.2911
Avg	.3275	1.1794	1.1454	.5761	1.4178

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054059 / 33/11 KV. S/S/ MHALASJAWALA

Feeder No / Name : 201 / 11 KV. MHALASJAWALA SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.6783	1.085	.7802
2	.7108	.7716	1.4255	.8383
3	.7122	.8907	1.4586	1.065
4	.8886	.9602	1.5089	1.0526
5	1.0648	.9831	1.5746	1.1336
6	1.3599	1.1142	1.5384	1.1203
7	1.6032	1.1822	1.5546	1.2003
8	2.0965	1.3927	1.5364	1.2003
9	2.0965	1.3435		1.4746
10		1.4089		1.4575
11		.04		.072
12		.0343		.0787
13		.0467	.076	.0438
14	.0495	.0467	.076	.0438
15	.0524	.0457	.0834	.0419
16	.0467	.0995	.0834	.0533
17		.048	.0667	.0533
18	.1029	.0469	.0914	.0892
19	.1313	.0857	.128	.096
20	.1174	.1829	.1174	.0884
21	.1029	.1739	.1048	.0747
22	.0629	.1457	.096	.0652
23	.0514	.1357	.1012	.064
24	.0617	.0495	.112	.093
Max	2.0965	1.4089	1.5746	1.4746
Min	.0467	.0343	.0667	.0419
Avg	.6296	.4961	.6409	.5117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054059 / 33/11 KV. S/S/ MHALASJAWALA

Feeder No / Name : 202 / 11 KV. KALEGAON FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0391	.0335	.0305	.0457
2		.0391	.0343	.0305	
3		.032	.0335	.0305	
4		.032	.0343	.0305	
5		.032	.0419	.032	
6		.032	.0429	.0328	
7		.0328	.0448	.041	
8		.0328	.0457	.0419	
9		.0328			
10		.032			
11		.815	.8954		1.2936
12		.815	1.1283		1.3003
13			1.262	1.6478	
14		.9536	1.1517	1.825	2.0805
15		1.0454	1.0692	1.7541	2.0576
16		1.0719	1.2048	1.8404	2.1152
17		.8059	1.1269	1.7896	2.1735
18		.8688	1.0517	1.7364	2.0332
19		.0343	.0335	.0448	.0391
20		.0335	.041	.0429	.04
21		.0343	.0381	.04	.0343
22		.0343	.0328	.041	.0335
23	.0391	.0343	.0335	.0429	.0335
24		.0391	.0343	.0343	.0448
Max	.0391	1.0719	1.262	1.8404	2.1735
Min	.0391	.032	.0328	.0305	.0335
Avg	.0391	.3010	.4279	.5554	.9518

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054059 / 33/11 KV. S/S/ MHALASJAWALA

Feeder No / Name : 203 / 11KV MHALASJAWALA -G-

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1865	.1715	.1543	.1677
2	.1844	.1715	.1486	.1457
3	.1581	.2012		.144
4	.1562	.2429	.1467	.1677
5	.1372	.2881	.2201	.1932
6	.1932	.3161	.2934	.2364
7	.2961	.3429	.3144	.3652
8	.3858	.3144	.3525	.3429
9	.3199	.3241	.3521	.3311
10		.3988		.3239
11		.2915		.3052
12	.3086	.3189		.3258
13	.2915	.3121	.3353	.3222
14	.1219		.2743	.2915
15	.1107	.2279	.2347	.2883
16	.12	.3222	.2683	.3086
17	.2486	.2572	.2652	.3475
18	.2915	.208	.3841	.3281
19	.3441	.2427	.3563	.3841
20	.3391	.2572	.3018	.3441
21	.3018	.2713	.2601	.285
22	.1949	.2427	.2454	.2012
23	.1753	.1753	.2126	.1865
24	.208	.1715	.1715	.1772
Max	.3858	.3988	.3841	.3841
Min	.1107	.1715	.1467	.144
Avg	.2306	.2639	.2646	.2714

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054059 / 33/11 KV. S/S/ MHALASJAWALA

Feeder No / Name : 204 / 11KV KALEGAON -G- FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168	.1867	.156	.1417
2	.1848	.1753	.1543	.1341
3	.1829	.1715	.1372	.1492
4	.1907	.1781	.1429	.1619
5	.2012	.1981	.1429	.1669
6	.1981	.2172	.1692	.2
7	.2027	.2286	.1974	.2134
8	.2115	.2027	.2225	.2469
9	.1833			
10	.1524			
11	.1402	.144		.1134
12	.156	.1595		.0867
13		.1402	.1578	.1052
14	.1543	.1417	.1433	.104
15	.1387	.1254	.12	.1029
16	.1402	.1402	.1509	.104
17	.1696	.1052		.1214
18	.2241	.104	.1781	.1739
19	.2402	.1402	.2427	.218
20	.2241	.1595	.2328	.2035
21	.1638	.1791	.2263	.2012
22	.1772	.1629	.2075	.1886
23	.1463	.1698	.1886	.1526
24	.168	.1867	.1612	.1698
Max	.2402	.2286	.2427	.2469
Min	.1387	.104	.12	.0867
Avg	.1791	.1644	.1753	.1572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054081 / 33/11 KV. RAJURI (N) S/S

Feeder No / Name : 204 / 11KV Rajuri-Gaonthan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)
16	.1814	
19		.4058
Max	.1814	.4058
Min	.1814	.4058
Avg	.1814	.4058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054103 / 33/11 KV NALWANDI SUB-
STATION

Feeder No / Name : 201 / 11 KV Nalwandi (New) SINGLE PHASING

Feeder Feeder KV- 11 /
OUTGOING

DATE	18-DEC-17
HR	Load (MW)
1	.9831
2	1.1012
3	1.1336
4	1.1984
5	1.2631
6	1.3279
7	1.3603
8	1.5546
11	.5304
12	.3315
13	.2652
14	.2652
24	.3277
Max	1.5546
Min	.2652
Avg	.8956

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054103 / 33/11 KV NALWANDI SUB-STATION

Feeder No / Name : 202 / 11 KV Jarud SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17
HR	Load (MW)
1	.439
2	.4435
3	.4755
4	.5487
5	.7316
6	.8413
7	.8779
8	.8413
9	.6219
11	.8048
12	1.2437
13	1.1706
14	1.1706
24	.4755
Max	1.2437
Min	.439
Avg	.7633

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054112 / 33/11 KV GHATSAVLI SS

Feeder No / Name : 201 / 11 KV GHATSAVLI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8097	1.3927	.3858	.3521
2	1.4575	1.4746	.4321	.6706
3	1.6194	1.5565	.6173	.7042
4	1.7404	1.6057	.8488	.7293
5	1.8233	1.6057	1.2037	.7287
6	1.8564	1.6712	1.3889	.9069
7	1.9662	1.7532	1.6975	1.5497
8	1.9989	1.6385	1.8827	1.8023
9		1.6762	1.713	1.9662
10		1.5339	1.5623	
11		1.4864	1.2146	
12		1.8976		
13		1.5123		
14		1.3889		
15		1.25		
16		1.3426		
17		1.0031		
18		.6944	.6478	
19		.6173	.6802	
20		.6019	.7287	
21		.4475		
22		.3241		
23		.3704	.3688	
24	.3563	.9831	.3241	.3688
Max	1.9989	1.8976	1.8827	1.9662
Min	.3563	.3241	.3241	.3521
Avg	1.5142	1.2428	.9810	.9779

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054123 / 33/11KV PIMPALWADI S/Sn

Feeder No / Name : 201 / 11 KV DOKEWADA TALAV SINGLE PHASING

FEEDER Feeder KV- 11 /
OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.0631	.6783	.7377	.7888
2				1.1022	.6952	.8886	.8309
3				1.2039	.7122	.9503	.8139
4				1.2548	.8139	.9831	1.0004
5				1.4582	.8817	1.065	1.0227
6				1.6598	.9326	1.166	1.2239
7				1.7772	1.0004	1.2631	1.3748
8				1.7939	1.0852	1.1984	1.4083
9		.12		1.7269	1.1022	1.1012	1.5057
10		.0857		1.7436	1.153	1.0202	1.5089
11		1.7814			.0857	.0857	.1029
12		2.251			.0686		
13		2.0081			.0686		
14	1.643			.0514	.0686		.0857
15	1.8275			.0686	.0514		.0686
16				.0686	.0514	.0857	.0686
17				.0526	.0857	.0686	.0857
18				.1715	.1029	.1029	.0857
19				.1543	.1543	.1029	.1372
20				.12	.12	.1886	.1372
21				.1029	.12	.1543	.12
22				.1029	.1029	.1543	.1029
23			.12	.1029	.1029	.12	.1029
24				.12	.1029	.1029	.1029
Max	1.8275	2.251	.12	1.7939	1.153	1.2631	1.5089
Min	1.643	.0857	.12	.0514	.0514	.0686	.0686
Avg	1.7353	1.2492	.12	.7571	.4309	.5770	.5763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054123 / 33/11KV PIMPALWADI S/Sn

Feeder No / Name : 202 / 11 KV BHALWANI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0857	.1372	.1372	.1372
2			.0857	.1372	.1372	.1372
3			.0857	.1372	.12	.1372
4			.0857	.1543	.1543	.1372
5			.0857	.1715	.1715	.1715
6			.1372	.2058	.2058	.1865
7			.1372	.2229	.2572	.2204
8			.12	.2058	.2229	.2204
9	.6104		.12	.1886	.1886	.1886
10			.0857	.1372	.1372	.1715
11	.0857		.5256	.7712	1.2174	
12	.0514		.6104	.8383	1.4922	
13			.6443			1.2944
14			.6274			1.4251
15			.6104			
16			.6613	1.3094	1.5257	1.5546
17			.8215	1.2955	1.4754	1.3441
18			.7712	1.0486	1.4419	1.3927
19			.1715	.2229	.2401	.2229
20			.1715	.2058	.2229	.2058
21			.1715	.1715	.2058	.1886
22			.1543	.1715	.1715	.1715
23		.1029	.1543	.1543	.1372	.1543
24			.0857	.1372	.1372	.1372
Max	.6104	.1029	.8215	1.3094	1.5257	1.5546
Min	.0514	.1029	.0857	.1372	.12	.1372
Avg	.2492	.1029	.3004	.3821	.4762	.4666

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054123 / 33/11KV PIMPALWADI S/Sn

Feeder No / Name : 203 / 11 KV PIMPALWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0181	.0351	.0351	.0181
2				.0351	.0351	.0181
3			.0724	.0351	.0351	.0358
4			.0181	.0526	.0351	.0358
5			.0181	.0701	.0686	.0532
6			.0532	.0857	.0686	.0701
7			.0876	.1029	.1543	.12
8			.104	.12	.1543	.1372
9	.1029		.1214	.1029	.1029	.1214
10			.0526	.0857	.0857	.0857
11			.0526	.0351	.0351	.0526
12	.0181		.0351	.0351	.0347	.0351
13			.0351	.0351		.0351
14			.0351	.0351		.0351
15			.0175	.0351		.0175
16			.0351	.0175	.0175	.0175
17			.0526	.0351	.0351	.0351
18			.0857	.0686	.0526	.0686
19			.0857	.1029	.1214	.12
20			.0351	.0526	.1052	.0857
21			.0351	.0526	.0709	.0351
22			.0351	.0351	.0532	.0351
23		.0171	.0351	.0351	.0354	.0351
24			.0181	.0351	.0351	.0179
Max	.1029	.0171	.1214	.12	.1543	.1372
Min	.0181	.0171	.0175	.0175	.0175	.0175
Avg	.0605	.0171	.0495	.0556	.0653	.0550

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054145 / 33/11 KV KUKKADGAON S/Stn

Feeder No / Name : 201 / 11 kv Kukkadgaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4049	.3277	.3841	.426
2	.4049	.5735	.4801	.4588
3	.4049	.6554	.5407	.5243
4	.4534	.7373	.7842	.5243
5	.502	.852	.8322	.6226
6	.5992	.852	.8802	.7537
7	.8259	.9175	.8802	.8848
8	.9231	.8192	.8962	1.0322
9	1.1012	.8356	.9442	1.0322
10	1.0688	.852		.9503
11		.208		.1619
12	.1475			.1943
13	.1638	.192	.1802	.1781
14	.1638		.1966	.1619
15	.1311	.176	.1475	
16	.2458	.16	.1311	.1619
17	.2713	.208	.0983	.2591
18	.3277	.208		.3563
19	.1311	.3041	.1311	.4049
20	.2622	.2881	.1638	.2915
21	.2458	.2401	.2785	.2591
22	.2785	.2241	.2294	.2429
23	.2949	.3201	.1966	.2267
24	.1457	.3841		.1638
Max	1.1012	.9175	.9442	1.0322
Min	.1311	.16	.0983	.1619
Avg	.4129	.4698	.4408	.4466

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054145 / 33/11 KV KUKKADGAON S/Stn

Feeder No / Name : 202 / 11 kv Wadgaon Gunda SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1739	.1638	.0972	.128
2	.1739	.1802	.0972	.16
3	.1739	.1966	.0972	.16
4	.1898	.1966	.1619	.192
5	.2056	.213	.1943	.2241
6	.2214	.1966	.1457	.2561
7	.1739	.1638	.1457	.2881
8	.1265	.1802	.1619	.2881
9	.1265	.1311	.1457	.2401
10	.0949	.1311		.128
11	.0983	.1619		.3163
12	.0983	.1619		.3953
13	.0819	.1619	.144	.3953
14	.0655		.128	.3005
15	.1311	.0972	.16	.3953
16	.1311	.1134	.144	.3953
17	.1475	.1457	.144	.427
18	.1475	.1781		.3953
19	.1638	.2429	.16	.2214
20	.1311	.2591	.192	.2214
21	.1638	.1943	.2241	.2056
22	.1311	.1781	.192	.1898
23	.1311	.0972	.16	.1739
24	.1739	.0972		.128
Max	.2214	.2591	.2241	.427
Min	.0655	.0972	.0972	.128
Avg	.1440	.1670	.1524	.2594

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054145 / 33/11 KV KUKKADGAON S/Stn

Feeder No / Name : 203 / 11 KV Rakshasbhuvan feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4359	.4588	.4024	.503
2	.4359	.4424	.5197	.503
3	.4359	.4588	.503	.5365
4	.503	.4096	.5868	.5365
5	.6036	.5243	.6371	.7042
6	.7712	.6554	.6706	.8048
7	.9389	.6718	.7042	.8551
8	.8048	.7373	.788	.8215
9	.6203	.5243	.6036	.7042
10	.4527	.4096		.4694
11	.5735	.6036		.788
12	.5735	.7545		.9389
13	.6554	.7712	.8215	.6706
14	.6554		.9389	.6706
15	.6226	.6706	.9389	.9724
16	.5735	.8886	.9556	1.0059
17	.6882	.9221	1.0059	1.0059
18	.7373	.8551		1.0898
19	.4915	.5533	.4694	.4694
20	.4096	.5365	.503	.5197
21	.4096	.4694	.5533	.503
22	.4096	.4191	.503	.4862
23	.4588	.3353	.4694	.4694
24	.4359	.3688		.4694
Max	.9389	.9221	1.0059	1.0898
Min	.4096	.3353	.4024	.4694
Avg	.5707	.5844	.6618	.6874

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054164 / 33/11 KV SHIRAS PARGAON

Feeder No / Name : 201 / 11 Kv Dagdi Shahajanpur SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.2126	.2743	.2378
2	.2614	.1981	.2743	.2378
3	.3018	.2926	.2926	.2229
4	.3734	.3658	.3292	.2229
5	.4854	.3658	.3292	.2972
6	.4668	.4024	.3658	.3688
7	.3361	.439	.3658	.4024
8	.2829	.3658	.4024	.4024
9	.2244	.2896	.3696	.3353
10	.2229	.2012	.1981	
11	.5944	.5735		.3812
12	.6811		.2915	.7287
13	.6811	.8097		.8097
14	.6935	.7773		.7449
15	.679	.7611		.7611
16	.6811	.7773	.7545	.7773
17	.5906	.7373	.823	.7935
18	.5434	.5735	.703	.6964
19	.3361	.4938	.463	.567
20	.2972	.4572	.503	.4572
21	.2724	.4207	.4359	.4207
22	.2362	.3658	.2972	.3658
23	.2229	.3326	.2972	.3109
24	.2641	.2126	.2743	.2378
Max	.6935	.8097	.823	.8097
Min	.2229	.1981	.1981	.2229
Avg	.4162	.4533	.4022	.4687

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054164 / 33/11 KV SHIRAS PARGAON

Feeder No / Name : 202 / 11 Kv Pargaon AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0648	.1238	
2	.0648	.1238	
3	.0648	.1257	
4	.0648	.1486	
5	.0648	.1654	
6	.0972	.2073	.0189
7	.1134	.1654	.0189
8	.1698	.1619	.0189
9	.1417	.1781	.0189
10	.2229	.1781	.0019
Max	.2229	.2073	.0189
Min	.0648	.1238	.0019
Avg	.1069	.1578	.0155

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054164 / 33/11 KV SHIRAS PARGAON

Feeder No / Name : 203 / 11 kv Pargaon G

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1509	.1181	.2033	.1337
2		.1494	.1299	.2033	.12
3		.1867	.1238	.2033	.12
4		.1494	.1257	.2218	.12
5		.0943		.2402	.16
6		.1886	.216	.2587	.208
7		.2263	.2881	.2772	.1486
8		.1698	.3628	.2772	.2378
9		.0991	.3277	.3142	.218
10		.1238	.1865	.2	.1734
11		.3715	.4475	.4458	.3481
12		.4087	.4915	.463	.5668
13		.5906	.4534		.6478
14		.5761	.5138		.5506
15		.6192	.5506		.4858
16		.5906	.5735	.583	.5992
17		.4961	.5304	.6859	.5138
18		.4561	.3647	.5658	.4475
19		.2401	.3174	.2743	.2772
20		.189	.2772	.2378	.2402
21		.1734	.2012	.1932	.2218
22		.1486	.1829	.1932	.2012
23	.1867	.1654	.2012	.1783	.2012
24		.1867	.1509	.2012	.1486
Max	.1867	.6192	.5735	.6859	.6478
Min	.1867	.0943	.1181	.1783	.12
Avg	.1867	.2813	.3102	.3057	.2954

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054021 / 33/11 KV. TALWADA S/S

Feeder No / Name : 201 / 11 KV. CHAVANWADI FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17
HR	Load (MW)	Load (MW)
11	1.8671	
12	1.8858	
13	1.922	
14	1.922	
15	1.9035	
16	1.9231	
17	.0953	
19	.2286	
20	.2477	
21	.1905	
22	.1524	
24		.1524
Max	1.9231	.1524
Min	.0953	.1524
Avg	1.1216	.1524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054021 / 33/11 KV. TALWADA S/S

Feeder No / Name : 205 / 11 KV DEVI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17
HR	Load (MW)	Load (MW)
11	.3239	
12	.3048	
13	.2858	
14	.3048	
15	.3239	
16	.3239	
17	.381	
18	.5335	
19	.6097	
20	.6097	
21	.6097	
22	.6097	
24		.5335
Max	.6097	.5335
Min	.2858	.5335
Avg	.4350	.5335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054035 / 33/11 KV. SIRASMARG S/S

Feeder No / Name : 201 / 11 KV. SIRASMARG FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.112		.1478	.0972
4	.1478	.132	.1478	.0972
6	.2195	.1886	.2561	.1619
8			.1848	.2591
9		.1848		.2896
10	.1509	.1478	.2267	.2561
11		.1494		.2195
12	.1509	.1494	.1296	.1848
13		.112		.1478
14	.1132	.112	.0972	.112
15	.1886	.0943		.0943
16	.1132	.0943	.0972	.0943
17		.112		.0943
18	.1886	.1478	.1619	.1478
19		.1478		.2195
20	.1867	.1848	.2241	.1848
21		.2195		.1848
22	.1509	.1848	.1448	.1478
24	.112	.1132	.1494	.1086
Max	.2195	.2195	.2561	.2896
Min	.112	.0943	.0972	.0943
Avg	.1529	.1456	.1640	.1632

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054035 / 33/11 KV. SIRASMARG S/S

Feeder No / Name : 202 / 11 KV. UKHADPIMPRI FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.2134	.2452	.3018	.2105
4	.2134	.2641	.5487	.2591
6	.6706	.3048	.7225	.4687
8	.6097	.4268	.7225	.6478
9		.3201		.5596
10	.3395	.2591	.421	.5418
11		.1829		.2858
12	.1875	.1562		.3185
13		.1562		.2896
14	.1543		.421	
15				.3102
16	.1806		.4877	.423
17		.3948		.4199
18	.3763	.4214	.5182	.3807
19		.5719		.4586
20	.4108	.4214	.4887	.4111
21		.3311		.3086
22	.2343	.2439	.362	.2107
24	.2134		.1867	.2353
Max	.6706	.5719	.7225	.6478
Min	.1543	.1562	.1867	.2105
Avg	.3170	.3133	.4710	.3744

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054035 / 33/11 KV. SIRASMARG S/S

Feeder No / Name : 203 / 11 KV. SHAJANPIMPRI FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.2263	.2286	.2172	.1989
4	.2614	.2263	.2378	.1989
6	.2641	.2829	.3361	.2155
8	.2641	.2452	.3734	.2105
9		.2241		.2587
10	.2641	.2241	.2267	.2033
11		.4062		.4321
12		.5601	.5344	.5851
13		.5182		.6009
14		.57		
15		.6093	.2267	.3239
16	.5506	.5556	.6154	.664
17		.5312		.6154
18	.4534	.4752	.5138	.4858
19		.2402		.2195
20	.3361	.2926	.2987	.2801
21		.2614		.2801
22	.2452	.2241	.2987	.2241
24	.2263	.2286	.1991	.2172
Max	.5506	.6093	.6154	.664
Min	.2263	.2241	.1991	.1989
Avg	.3092	.3634	.3398	.3452

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054035 / 33/11 KV. SIRASMARG S/S

Feeder No / Name : 204 / 11 KV. TAKALGAVAN FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.1532	.2427	.2896	.1619
4	.1787	.2601	.3269	.3239
6	.2229	.3467	.3948	.4858
8	.3277	.3064	.423	.6478
9		.2896		.6443
10	.2256	.2172	.5506	.5418
11				.2241
12	.0152		.1296	.1307
14	.0114			
16	.1143		.1134	
17		.1509		.1848
18	.2641	.2378	.2378	.2957
19		.2561		.4344
20	.298	.2172	.3511	.3326
21		.2172		.2896
22	.0173	.1829	.2614	.2353
24	.1143	.156	.1478	.181
Max	.3277	.3467	.5506	.6478
Min	.0114	.1509	.1134	.1307
Avg	.1619	.2370	.2933	.3409

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054035 / 33/11 KV. SIRASMARG S/S

Feeder No / Name : 205 / 11 KV TARTEWADI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.3353	.0217	.2374	.1619
4	.407	.2172	.3856	.3239
6	.503	.301	.5087	.4049
8	.503	.3932	.5426	.4531
9		.3658		.3763
10	.2641	.3048	.5506	.3462
11		.0943		.112
12		.0943		.0867
13		.0754		.0943
14		.0754		
15		.0943		
16	.0754	.0943		
17		.1307		
18	.0943	.0934		
19		.0943		.112
20		.1494	.1494	.1132
21		.112		.0924
22	.0732	.112	.1086	.0905
24	.1132	.0747	.1132	.0747
Max	.503	.3932	.5506	.4531
Min	.0732	.0217	.1086	.0747
Avg	.2632	.1525	.3245	.2030

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054035 / 33/11 KV. SIRASMARG S/S

Feeder No / Name : 206 / 11 KV. TANDALWADI FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.1372	.112	.208	.0972
4	.1677	.128	.2629	.125
6	.2012	.1886	.2947	.1943
8	.2012	.2601	.3121	.2915
9		.2656		.3612
10	.2486	.25	.2915	.3462
11		.0591		.064
12		.0819	.0648	.0671
13		.0655		.0678
14		.0587		
15		.0533		
16	.0446	.0724	.0648	
17		.0638		
18	.0594	.048	.0663	
19		.06		.0753
20	.0591	.0724	.112	.0619
21		.0724		.0457
22	.0503	.0663	.0724	.0412
24	.0509	.0051	.0509	.056
Max	.2486	.2656	.3121	.3612
Min	.0446	.0051	.0509	.0412
Avg	.1220	.1044	.1637	.1353

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054085 / 33/11KV DHONDRAI S/S

Feeder No / Name : 201 / 11KV RAJPIMPRI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2804	.2804	.1677	.3391
2	.3224	.2896	.1715	.3391
3	.3506	.2896	.2103	.3018
4	.3772	.2926	.2454	.3086
5	.426	.3506	.3277	.3814
6	.503	.4908	.4024	.4557
7	.583	.5548	.4115	.4508
8	.5609	.4161	.3353	.4115
9	.4115	.3429	.4801	.3814
10	.2427	.2804	.3467	.3391
16	.3506			
17	.8322	.852	.8139	.884
18	.823	.9259	.8718	1.4251
19	.6241	.8413	.9156	
20	.7011	.7202	.9282	
21	.6241	.6401	.852	
22	.5487	.5735	.8383	
23	.4908	.503	.7293	
24	.2743	.4161	.4908	.6962
Max	.8322	.9259	.9282	1.4251
Min	.2427	.2804	.1677	.3018
Avg	.4909	.5033	.5299	.5164

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054085 / 33/11KV DHONDRAI S/S

Feeder No / Name : 202 / 11KV DHONDRAI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4908	.4207	.4694	.78
2	.5373	.4344	.5144	.8478
3	.5434	.5068	.5609	.8048
4	.5487	.5121	.5609	.8916
5	.5898	.8413	.7209	1.0056
6	.6706	1.0517	.8383	1.0867
7	.7202	1.0402	1.0631	1.1096
8	.7712	.9709	.8718	1.166
14	.3429			
15	.4115	.4588	.3391	.3605
16	.4908	.4801	.4207	.4287
17	.5548	.426	.407	.5765
18	.7545	.7888	.503	.905
19	.9015	.9816	.5426	
20	.7712	.823	.5636	
21	.6241	.6722	.6226	
22	.4801	.4915	.4694	
23	.4908	.4694	.431	
24	.4801	.4161	.4557	.431
Max	.9015	1.0517	1.0631	1.166
Min	.3429	.4161	.3391	.3605
Avg	.5881	.6548	.5752	.7995

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054085 / 33/11KV DHONDRAI S/S

Feeder No / Name : 203 / 11KV GANGAWADI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0701	.0701	.0671	
2	.0716	.0724		
3	.0701	.0724	.0351	.0671
4	.0686	.0732	.0351	.0686
8		.3467		
9	.5487	.6173	.6173	.6241
10	.6935	.7011	.5895	.6783
11	.6859	.7442		.7125
12	.7628	.8764	.6443	.7274
13	.7545	.9156	.7202	.7621
14	.8322	.9602	.7975	.7621
15	.823	.7865	.8139	.7125
16	.8413	.8573	.8764	
18	.0686			
19	.0693	.0701	.1357	
20	.0701	.0686	.1326	
21	.0693	.064	.1638	
22	.0686	.0671	.0671	
23	.0701	.0686	.0663	
24	.0686	.0693	.0701	.0663
Max	.8413	.9602	.8764	.7621
Min	.0686	.064	.0351	.0663
Avg	.3530	.3948	.3645	.5181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054085 / 33/11KV DHONDRAI S/S

Feeder No / Name : 204 / 11 KV MAHALAXMI INDESTRIAL SHEDDABLE FEEDER HAVING WEEKLY
 FEE Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2103	.1402	.3688	.1017
2	.1791	.1448	.4115	.1017
3	.1753	.1448	.4557	.1006
4	.1372	.1463	.4557	.1029
5	.1311	.1402	.3932	.104
6	.1341	.1402	.1677	.1052
7	.1715	.1734	.2058	.104
8	.1402	.1387	.1677	.1029
9		.2058	.2743	.3814
10	.104	.3155	.3121	.5087
11	.0686	.1417		.4572
12	.0693	.1753	.2374	.5716
13	.1029	.1357	.4115	.695
14	.1387	.1715	.5201	.2378
15	.1029	.5243	.4748	.4268
16	.2804		.4557	.4915
17	.4161	.0983	.2035	.5668
18	.6859	.5487		.5365
19	.2774	.631	.1017	
20	.2454	.4801	.1326	
21	.1387	.4161	.1311	
22	.1372	.3932	.1006	
23	.1402	.3688	.0995	
24	.2058	.1387	.3506	.0995
Max	.6859	.631	.5201	.695
Min	.0686	.0983	.0995	.0995
Avg	.1910	.2571	.2923	.3050

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054008 / 33/11 KV. PATODA S/S

Feeder No / Name : 201 / 11 KV. PATODA FEEDER
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.6733			
6	1.5083		1.4217	
7	1.9616	2.0576	1.7804	
8	2.2131	2.1672	2.1125	2.4188
9	1.9616	1.9719	1.9281	2.0919
10		1.6991	1.7269	1.7269
11		1.3523	1.7318	1.5947
12		1.387	1.4575	1.4563
13		1.2269		1.3496
14			1.2003	1.1919
15		1.1919	1.166	1.1919
16		1.2269	1.2346	1.2795
17		1.387	1.406	1.3496
18	1.647	1.595	1.5432	1.5257
20	1.387	1.4563	1.5432	1.5083
21		1.2269		1.2269
24			.7087	
Max	2.2131	2.1672	2.1125	2.4188
Min	.6733	1.1919	.7087	1.1919
Avg	1.6217	1.5343	1.4972	1.5317

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054008 / 33/11 KV. PATODA S/S

Feeder No / Name : 203 / 11 KV. MAJARSUMBHA FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	1.1393			
6	2.3205		2.0119	
7	2.9001	2.982	2.42	
8	3.1131	3.1901	2.769	3.1207
9	2.7526	3.1893	2.536	3.1901
17		.7442		
18	1.2003	1.0631		
20	1.3717	1.7661	1.7528	1.5432
21		1.3146		1.5261
24			1.1043	
Max	3.1131	3.1901	2.769	3.1901
Min	1.1393	.7442	1.1043	1.5261
Avg	2.1139	2.0356	2.099	2.3450

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054008 / 33/11 KV. PATODA S/S

Feeder No / Name : 204 / 11 KV. TALE PIMPALGAON SINGLE PHASING

FEEDER Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.181			
6	.4607		.4961	
7	.5316	.4854	.5493	
8	.5138	.4115	.5138	.5487
9				.4161
11	1.5089	2.146	2.0458	2.4413
12	1.9204	2.3371	2.3579	2.769
13	1.8861	2.3205		2.7199
14	2.0332		2.6063	2.8018
15		2.3868	2.4691	2.6871
16		2.2874	2.7435	2.7035
17		2.3868	2.7393	2.3868
18	1.6461	2.0957	2.6353	2.6189
20	.2743	.3045	.3155	.3045
21		.2686		.2507
24			.1463	
Max	2.0332	2.3868	2.7435	2.8018
Min	.181	.2686	.1463	.2507
Avg	1.0956	1.5846	1.6349	1.8874

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054008 / 33/11 KV. PATODA S/S

Feeder No / Name : 206 / MAHASANGVI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.2507			
6	1.9616		2.0119	
7	2.1628	2.3405	2.2298	
8	2.3137	1.5108	2.3868	2.5833
9	2.2466	2.4691	2.1795	2.5377
10		1.8176	2.2131	2.2801
11	.2572	.2865	.0351	
12	.1886	.197		
13	.1886	.197		
14	.1387		.2058	.2149
15			.1715	.1791
16			.1715	.1791
17		.197	.2427	.2149
18	.4115	.3544	.3814	.3761
20	.3601	.4607	.463	.4607
21		.3721		.4252
24			.1991	
Max	2.3137	2.4691	2.3868	2.5833
Min	.1387	.197	.0351	.1791
Avg	.9527	.9275	.9916	.9451

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054008 / 33/11 KV. PATODA S/S

Feeder No / Name : 207 / 11 KV HT Feeder

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.0373			
6	.0373		.0373	
7	.0373	.0347	.0373	
8	.0373	.0686	.0373	.0343
9	.128	.1886	.056	.0343
10		.052	.056	.0373
11	.2229	.1791	.0343	.0373
12	.1715	.2328	.0171	.0373
13	.2058	.1791		.0373
14	.0514		.0343	.0373
15		.056	.0343	.0373
16		.2149	.0171	.0189
17		.2149	.052	.056
18	.0171	.056	.0347	.0187
20	.0343	.056	.0343	.0373
21		.056		.0187
24			.0373	
Max	.2229	.2328	.056	.056
Min	.0171	.0347	.0171	.0187
Avg	.0891	.1222	.0371	.034

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054044 / 33/11 KV. KUSLAMB S/S

Feeder No / Name : 203 / 11 KV. SUPPA FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	21-DEC-17
HR	Load (MW)
18	1.3032
Max	1.3032
Min	1.3032
Avg	1.3032

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054057 / 33/11 KV ROHATWADI

Feeder No / Name : 201 / 11 KV NAIGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4115	.4973	.4287	.4115
2		.4287	.4801	.4115	.4458
3		.6516	.5144	.4458	.5144
4		.6859	.6516	.5144	.823
5		.8916	.9774	.823	1.0288
11		.4877	.3353	.6097	.6097
12		.4877	.4877	.7926	.823
13		.503	.6097	.8535	.7316
14		.4877	.6097	.7926	.6859
15		.4572	.6859	.6706	.6706
16	.4115		.6401	.7926	.7926
17	.4801	.5182	.7316	.7926	.4877
18	.8916	.5182	.7011	.7316	.7011
19	1.046	1.0288	.9602	1.0288	.9602
20	.6516	.8573	.8573		.823
21	.5487	.6516	.6344		.6516
22	.4287	.583	.5487		.5144
23	.4115	.5487	.5144		.4115
24		.4115	.5144	.4801	.3429
Max	1.046	1.0288	.9774	1.0288	1.0288
Min	.4115	.4115	.3353	.4115	.3429
Avg	.6087	.5894	.6290	.6779	.6542

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054057 / 33/11 KV ROHATWADI

Feeder No / Name : 202 / 11 KV ROHATWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5144	.4801	.3658	.7926
2		.5487	.463	.4572	.9145
3		.6401	.945	.6097	1.5242
4		.9907	1.2689	.7316	1.6766
5		1.4632	1.326	.8383	1.829
6		1.768	2.1338	.945	1.829
7		2.1643	2.1643	.9907	1.829
8		2.4387	2.1338	1.0974	1.6461
9		2.3472	.8535	1.1584	2.2862
10		2.0729	.7773	1.0974	2.1338
11		.3429	.3944	.4287	.5144
12		.1715	.3429	.3086	.3086
13		.2915	.2401	.2743	.2743
14		.2915	.2058		.2743
15		.3086	.2401	.2743	.3086
16	2.1948	.3944	.2401	.3772	.3086
17	2.2253	.5487	.4115	.3772	.4115
18	2.1643	.7888	.6859	.7545	.6173
19	1.0059	1.0631	1.0288	1.0974	1.0631
20	.8573	.9259	.9431		.9431
21	.7202	.7202	.7202		.823
22	.5658	.6516	.6859		.6859
23	.5144	.583	.6001		.583
24		.4801	.5144	.4458	.3658
Max	2.2253	2.4387	2.1643	1.1584	2.2862
Min	.5144	.1715	.2058	.2743	.2743
Avg	1.281	.9379	.8250	.6647	.9976

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054057 / 33/11 KV ROHATWADI

Feeder No / Name : 203 / 11 KV DOMRI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2058	.2743	.2401	.1715
2		.2401	.2572	.2058	.2058
3		.4458	.2401	.2401	.2743
4		.6001	.2743	.2915	.3429
5		.6859	.3429	.3429	.5144
12		.3658		1.0364	
13		.6249	.3048	1.1279	.9755
14		.6859	.9145	1.1279	1.2498
15		.7316	1.0364	1.2193	1.2193
16	.2572	.7316	1.0059	1.2193	1.2193
17	.3429	.7468	1.0974	1.2498	1.0974
18	.5144	.6859	.6097		1.1584
19	.4801	.6001	.6516	.7545	.7545
20	.4458	.463	.4801		.583
21	.3429	.3772	.3601		.4801
22	.2401	.3429	.3429		.4115
23	.2229	.3086	.3086		.3086
24		.2058	.2915	.2572	.1715
Max	.5144	.7468	1.0974	1.2498	1.2498
Min	.2229	.2058	.2401	.2058	.1715
Avg	.3558	.5027	.5172	.7164	.6552

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054069 / 33/11 KV. DONGARKINNI S/S

Feeder No / Name : 201 / 11 KV. NALWANDI FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3		.1715	.2286		
7		.2286			
8					.2286
10	.724				
11					1.7909
12			1.2384		
14					1.6804
15		1.0479			
18					.6668
19			.4572		
20				.2667	
23					.1905
Max	.724	1.0479	1.2384	.2667	1.7909
Min	.724	.1715	.2286	.2667	.1905
Avg	.724	.4827	.6414	.2667	.9114

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054069 / 33/11 KV. DONGARKINNI S/S

Feeder No / Name : 202 / 11 KV. DONGARKINHI FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1109	
3		.0572	.1143		
6			.1524		
7		.1143		.1448	
8					.1905
10	.7621	.2286			
11					.1715
12			.8002		
14					1.3717
15		.8573			
16			.6668		
18					1.1812
19			.1509		
20				.3048	
23			.112		.0762
Max	.7621	.8573	.8002	.3048	1.3717
Min	.7621	.0572	.112	.1109	.0762
Avg	.7621	.3144	.3328	.1868	.5982

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054069 / 33/11 KV. DONGARKINNI S/S

Feeder No / Name : 203 / 11 KV. JATNANDUR FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.2003	
3		1.9052	1.9052		
6			2.191		
7		2.572			
8					1.2384
9			2.572		
10		2.7054			
13	2.2862				
23			.3292		
Max	2.2862	2.7054	2.572	1.2003	1.2384
Min	2.2862	1.9052	.3292	1.2003	1.2384
Avg	2.2862	2.3942	1.7494	1.2003	1.2384

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054069 / 33/11 KV. DONGARKINNI S/S

Feeder No / Name : 204 / NALWANDI GAOTHAN (P)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2743	
3	.1905	.2286		
6		.381		
7	.4191		.543	
8				.4763
9		.4763		
10	.5335			
11				.1753
12		.2858		
14				.3155
15	.2858			
16		.381		
18				.381
19		.6001		
20			.5716	
23		.3292		.1905
Max	.5335	.6001	.5716	.4763
Min	.1905	.2286	.2743	.1753
Avg	.3572	.3831	.4630	.3077

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054069 / 33/11 KV. DONGARKINNI S/S

Feeder No / Name : 205 / 11 kv Dongarkini

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1267	
3	.1905	.1905		
6		.2858		
7	.3429		.2743	
8				.3429
9		.381		
10	.2667			
11				.2572
12		.1905		
14				.1715
15	.2667			
16		.1905		
18				.2858
19		.1858		
20			.362	
23		.1463		.1715
Max	.3429	.381	.362	.3429
Min	.1905	.1463	.1267	.1715
Avg	.2667	.2243	.2543	.2458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054096 / 33/11 KV. DASKHED S/S

Feeder No / Name : 201 / 11 KV. DASKHED FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0187	.0187	.208	.1646
2		.0187	.0187	.2401	.1646
3		.1204	.2241	.2401	
4		.1524	.2401	.2401	.2
5		.1829	.2721	.2721	.2286
6		.216	.2721	.3201	.3001
7		.25	.4161	.3521	.4001
8		.3163	.4961	.4641	.443
9		.2439	.4641	.4001	.4725
10		.3048	.4641	.4001	.4115
11		.0179	.0187	.0187	.0179
12		.0179	.0187	.0187	.0179
13		.0179	.0187	.0187	.0179
14		.0179	.0187		.0179
15		.0179	.0187	.0187	.0179
16		.0179	.0187	.0187	.0179
17		.0179	.0187		.0179
18		.0171	.0187	.0187	.0179
19		.0171	.0187	.0189	.0179
20		.0171	.0171	.0189	.0179
21			.0187	.0189	
22	.0187	.0171	.0187	.0189	
23	.0187	.0171			
24		.0187	.0187	.0187	.0189
Max	.0187	.3163	.4961	.4641	.4725
Min	.0187	.0171	.0171	.0187	.0179
Avg	.0187	.0893	.1360	.1592	.1491

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054096 / 33/11 KV. DASKHED S/S

Feeder No / Name : 203 / Pachangri Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11	.3506	.4801		.5639
12	.5639	.5792		.9728
13	.6706	.7316		.9446
14	.5792	.7926		
15	.7011	.7621		1.001
16	.7164	.7316	.7404	1.001
17	.6097	.8002		.9305
18	.4572	.5487	.9002	.9023
Max	.7164	.8002	.9002	1.001
Min	.3506	.4801	.7404	.5639
Avg	.5811	.6783	.8203	.9023

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054096 / 33/11 KV. DASKHED S/S

Feeder No / Name : 204 / Pachangri Gav

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0762	.0934		.0572
2		.0762	.0747		.0572
3		.1143	.0934		.0762
4		.1905	.112		.1143
5		.2667	.1867		.1524
6		.4191	.3734		.2286
7		.4572	.3921		.2477
8		.4382	.3734		.2096
9		.381	.3361		.0934
10		.2286			
11		.0953	.1307		
12		.1143	.1307		.0934
13		.1143	.112		.0747
14			.0934		
15			.112	.0953	.0747
16			.112	.0953	
17		.1334	.112		
18		.2286	.2801	.1524	
19		.2286	.3734	.1905	.2427
20		.1524	.2241	.1905	.2241
21		.1524	.1307	.0953	
22	.1334	.0572	.112	.0762	
23	.0953	.0572		.0762	
24		.0953	.0934		.0572
Max	.1334	.4572	.3921	.1905	.2477
Min	.0953	.0572	.0747	.0762	.0572
Avg	.1144	.1941	.1842	.1215	.1336

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054096 / 33/11 KV. DASKHED S/S

Feeder No / Name : 205 / Vaidyakini Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1			.3353
2			.4268
3	.2187	.381	.4877
4	.25	.4115	.5335
5	.2812	.4572	.6097
6	.3125	.5182	.7316
7	.3281	.4725	.8383
8	.3749	.6401	.945
9	.4062	.7316	1.0623
10	.3281	.7468	1.0155
Max	.4062	.7468	1.0623
Min	.2187	.381	.3353
Avg	.3125	.5449	.6986

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054096 / 33/11 KV. DASKHED S/S

Feeder No / Name : 206 / Vaidyakini Gav

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0724	.0724	.0724	.0543
2		.0724	.0724	.0724	.0543
3		.0724	.0724	.0724	.0543
4		.0724	.0724	.0724	.0724
5		.0905	.0905	.0905	.0905
6		.1086	.1086	.1267	.0905
7		.1448	.1086	.0724	.0358
8		.1267	.1267	.1267	.0358
9		.1254	.0905	.1267	.0305
10		.0537	.0905	.1086	.0305
11		.0716	.1086	.0543	.0457
12		.0895	.0905	.0543	
13		.0895	.0905	.1075	
14		.0358	.0905		.0305
15		.0716	.0724	.0716	.0457
16		.0537	.0724	.1254	.061
17		.0895	.1086		.0762
18		.0716	.1086	.0895	.061
19		.1075	.1086	.1075	.061
20		.1254	.0905	.0905	.0762
21		.0716	.0724	.0724	
22	.0905	.0716	.0724	.0724	
23	.0905	.0716		.0724	
24		.0724	.0724	.0724	.0716
Max	.0905	.1448	.1267	.1267	.0905
Min	.0905	.0358	.0724	.0543	.0305
Avg	.0905	.0847	.0897	.0878	.0567

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054114 / 33/11Kv Lambarwadi S/s

Feeder No / Name : 201 / Lambarwadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)
4		.064
7		.1134
13	1.4403	
14		1.3717
15		1.3717
16	1.5257	1.4575
17		1.3717
18	1.406	1.3717
19		.3258
20		.181
21		.1448
22		.1267
23		.0905
Max	1.5257	1.4575
Min	1.406	.064
Avg	1.4573	.6659

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054114 / 33/11Kv Lambarwadi S/s

Feeder No / Name : 202 / Chincholi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)
4		2.2192
7		2.4097
9		2.524
10	2.2539	2.3405
19		1.2071
20		1.0751
21		.9619
22		.7545
23		.6602
Max	2.2539	2.524
Min	2.2539	.6602
Avg	2.2539	1.5725

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054114 / 33/11Kv Lambarwadi S/s

Feeder No / Name : 203 / Muggoan SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)
4		.2915
7		.426
11		1.1022
12		1.2717
13	1.0923	1.286
14		1.406
15		1.3717
16	1.2517	1.3375
17		1.4232
18	1.2309	1.3375
19		.3258
20		.2353
21		.2534
22		.2353
23		.2353
Max	1.2517	1.4232
Min	1.0923	.2353
Avg	1.1916	.8359

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054159 / 33/11 KV PIMPALWANDI

Feeder No / Name : 201 / PIMPALWANDI GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					1.1488		
2						.5487	.4801
3		.3978	.5117	1.4255		.6516	
4					1.2003		
5			.6299				1.1317
6		.5304		1.3546			
7				1.3847	1.286	1.4575	1.5775
8		.5636	.8619				
9					1.0288	1.2174	1.406
10			.9116	1.3094			
11		.4807					
12	.3462			1.1869		1.1317	
13		.4409	.8278		.823		
14			.9614			.8916	
15		.4064					
16				.7537			
17			1.0277			1.0288	
18	.4424	.5268	1.0277	.6321	.823		
19						1.2003	
21	.6226	.6622	1.1437				
22					.5487	.9259	
23	.426	.4515	1.1934	.9482			
24		.3647		1.1439		.4801	.5144
Max	.6226	.6622	1.1934	1.4255	1.286	1.4575	1.5775
Min	.3462	.3647	.5117	.6321	.5487	.4801	.4801
Avg	.4593	.4825	.9097	1.1266	.9798	.9534	1.0219

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054159 / 33/11 KV PIMPALWANDI

Feeder No / Name : 202 / Jarewadi AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.0452	.6299			
5	.0328				
6		.7956			
8	.0497	.873			
10	.0983	.9633			.0339
11			.547		.5487
13				.4572	
14			1.094		.6249
15					.6401
16			.7074		
17				.0914	.7926
18				.0914	
Max	.0983	.9633	1.094	.4572	.7926
Min	.0328	.6299	.547	.0914	.0339
Avg	.0565	.8155	.7828	.2133	.5280

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054163 / 33/11 KV JAWALAGIRI

Feeder No / Name : 201 / 11KV TAGARA FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17
HR	Load (MW)	Load (MW)
3		.1372
11		.1715
12	.4287	
13	.4458	
14		.5144
15	.4458	.5487
16	.4458	
17	.3429	
19	.2401	
21	.1715	
22	.12	
Max	.4458	.5487
Min	.12	.1372
Avg	.3301	.3430

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054163 / 33/11 KV JAWALAGIRI

Feeder No / Name : 202 / GARMATHA FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17
HR	Load (MW)	Load (MW)
11		.5144
12	.7373	
13	.823	
14		1.5432
15	.8573	1.2689
16	.8916	
17	.8402	
21	.9088	
Max	.9088	1.5432
Min	.7373	.5144
Avg	.8430	1.1088

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054163 / 33/11 KV JAWALAGIRI

Feeder No / Name : 203 / NIRGUDI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
3		.1372	
8	1.0288		
9			1.0288
10			.8402
11		.4801	
17	.5487		
19	.823		
21	.5487		
22	.4287		
Max	1.0288	.4801	1.0288
Min	.4287	.1372	.8402
Avg	.6756	.3087	.9345

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

SHIRUR(KASAR) S/DN.[802] BU 4802

Substation No/ Name :- 054024 / 33/11 KV. BR. YALLAM S/S

Feeder No / Name : 205 / 11Kv sawargaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0533	.044	.0389	.0497
2		.0471	.0471	.0356	.0514
3		.04	.0583	.0427	.0591
4		.0377	.0688	.0343	.0692
5		.0335	.08	.0347	.0457
6		.044	.096	.056	.0747
7		.0524	.1048	.1	.0827
8		.0356	.0777	.1183	.0857
9		.0274	.0267	.0495	.0251
10		.0213	.0267		.0251
11		.1075	.1212		.14
12		.0787	.0667	.0892	.0518
13		.1174	.0638	.0909	.04
14		.1149	.0533	.1036	.0594
15		.1257	.1252		.0434
16	.0526	.0894	.1067	.1014	.0572
17	.0572	.0754	.1217	.0846	.0259
18	.0732	.0572			.032
19	.0713	.072	.0789	.0747	.1402
20	.056	.0686	.064	.0724	.1536
21	.0486	.0874	.068	.0457	.0876
22	.0343	.0857	.08	.0692	.0892
23	.0366	.0617	.064	.0566	.0629
24		.0257	.0419	.0446	.0497
Max	.0732	.1257	.1252	.1183	.1536
Min	.0343	.0213	.0267	.0343	.0251
Avg	.0537	.0650	.0733	.0671	.0667

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

SHIRUR(KASAR) S/DN.[802] BU 4802

Substation No/ Name :- 054051 / 33 KV PIMPLNER

Feeder No / Name : 201 / PIMPALNER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2649	.2963	.2465	.2835
2	.3189	.3323	.2531	.3563
3	.4289	.407	.2914	.4307
4	.5089	.5041	.2978	.5068
5	.5601	.5987	.4531	.5636
6	.6054	.6439	.7567	.606
7	.5297	.5292	.7189	.6054
8	.5664	.5287	.6993	.5676
9	.4725	.472	.6615	.4929
10	.3776	.3776	.5497	.4175
11	.9682	.8431	.8949	.7746
12	1.226	1.0298	1.1907	
13	1.167	1.1523	1.1176	1.3943
14	1.1331	.8676	1.0829	1.5565
15	1.0279			1.4486
16	.9568	1.2293	1.3571	1.5039
17	.875	1.1468	1.4506	1.3619
18	.5535	1.1756	1.166	1.4008
19	.5877	.7686	.7834	.7059
20	.5487	.6701	.6277	.5544
21	.4184	.4577	.475	.3994
22	.3448	.3772	.3768	.3582
23	.2898	.3049	.338	.3104
24	.2612	.2949	.2719	.3059
Max	1.226	1.2293	1.4506	1.5565
Min	.2612	.2949	.2465	.2835
Avg	.6246	.6525	.6983	.7350

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

SHIRUR(KASAR) S/DN.[802] BU 4802

Substation No/ Name :- 054051 / 33 KV PIMPLNER

Feeder No / Name : 202 / 11 KV GOMALWADA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6706	.7042	.7385	.7739
2	.7712	.9054	.7721	.8738
3	.9702	1.1388	.9378	.9746
4	1.2016	1.472	1.055	1.0898
5	1.467	1.604	1.4235	1.4083
6	1.6671	1.7377	1.7249	1.5407
7	2.1387	2.3445	2.364	2.5484
8	2.275	2.146	2.4506	2.9541
9	2.4115	2.2801	2.5177	2.9541
10	2.4115	2.1485	2.031	1.6132
11	.1677	.1677	.235	.3025
12				.2016
13		.1343	.1678	.168
14		.1007	.1343	.168
15	.2347	.1343		.168
16	.2683	.1678	.235	.168
17		.3021	.3025	
18	.5365	.4364	.5377	.5041
19	.9735	.9746	1.0923	1.0754
20	.8066	.7058	.8075	.8411
21	.5881	.5377	.6729	.572
22	.5041	.3869	.5383	.5047
23	.4201	.3533	.4374	.4374
24	.4033	.3697	.3196	.4037
Max	2.4115	2.3445	2.5177	2.9541
Min	.1677	.1007	.1343	.168
Avg	1.0444	.9240	.9771	.9672

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

SHIRUR(KASAR) S/DN.[802] BU 4802

Substation No/ Name :- 054054 / 33 KV KHALAPURI

Feeder No / Name : 201 / Khalapuri Agri

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1981	.1886	.1886	.2134
2	.1981	.1715	.1715	.2439
3	.2286	.2058	.2058	.2743
4	.2743	.2743	.2915	.3048
5	.3353	.3429	.3944	.3658
6	.4572	.4115	.4801	.442
7	.4877	.5144	.6001	.6097
8	.4572	.4801	.5487	.5792
9		.4115	.4115	.4733
10		.2743	.4115	.4031
11		.6401	.9259	1.1393
12		.8688	1.2003	1.4723
13		.9259		1.4198
14	1.0288			1.4022
15	1.1317	1.0117		1.4723
16	1.0974	1.2346	1.3717	1.5249
17	1.2003		1.6461	1.4373
18	1.0974		1.5432	1.56
19	.4801		.3963	.5609
20	.4115		.3658	.4908
21	.3086		.3048	.3506
22	.2743		.2286	.2804
23	.2058		.1981	.2454
24	.1981	.1886	.2058	.1829
Max	1.2003	1.2346	1.6461	1.56
Min	.1981	.1715	.1715	.1829
Avg	.5300	.5090	.5757	.7270

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

SHIRUR(KASAR) S/DN.[802] BU 4802

Substation No/ Name :- 054115 / manoor

Feeder No / Name : 202 / Loni

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2574	.5228	.9431	1.046
2		1.286	.7964	1.0059	1.2574
3		1.4074	1.0136	1.0774	1.5546
4		1.387	.905	1.1469	1.6461
5		1.4118	1.073	1.0402	1.6871
6		1.669	1.1736	1.2955	1.8328
7		1.6213	1.1736	1.4232	1.8814
8		1.4861		1.4198	1.5718
9		1.5089	1.3432	1.2955	1.5804
10		1.4899	1.4289		1.5089
11		.1905	.1524	.4763	.2858
12		.1905	.1524	.2858	.2286
13		.1905	.1905	.1905	.1905
14		.1905	.1905	.0953	.1334
15		.1905	.2286	.1334	.0953
16		.1905	.2286	.0953	.1334
17		.3048	.2286	.1334	.1334
18	1.7814	.4572		.3429	.1905
19	.6478	.6097	.3048	.4382	.2858
20	.5335	.2858	.3429	.6859	.4763
21	.4763	.2858	.381	.5335	.3429
22	.4191		.381	.4191	
23	.2858		.3048	.2096	.2477
24		.1524		.3048	.1905
Max	1.7814	1.669	1.4289	1.4232	1.8814
Min	.2858	.1524	.1524	.0953	.0953
Avg	.6907	.8074	.5960	.6518	.8044

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

SHIRUR(KASAR) S/DN.[802] BU 4802

Substation No/ Name :- 054128 / 33 KV TINTARWANI

Feeder No / Name : 201 / 11 KV TINTARWANI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.4984	
2		.5677	
3		.6193	
4		.671	
5		.7226	
6		.7742	
7	.775	.8086	
8	.8095	.8602	
9	.8267	.6538	
10	.6358	.5333	.7422
11	.5843	.5167	.8631
12	.7046		1.0357
13			.9839
14			.9148
15	.5327		.9494
16	.7046		.9666
17	.7905		
18	.8936		.9321
19	.4984		1.1565
20	.5843		.8803
21	.464		.7422
22	.3953		.4488
23	.3781		.6732
Max	.8936	.8602	1.1565
Min	.3781	.4984	.4488
Avg	.6385	.6569	.8684

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

SHIRUR(KASAR) S/DN.[802] BU 4802

Substation No/ Name :- 054128 / 33 KV TINTARWANI

Feeder No / Name : 202 / Anandwadi AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	18-DEC-17	19-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.2215	
2		.24	
3		.2769	
4		.2954	
5		.3323	
7	.1833	.4615	
8	.2016	.5354	
9	.2199	.5723	
10	.4229	.4985	.5343
11	.2022	.4431	.4066
12	.3125		.4805
13			.4625
14			.4995
15	.2206		.3885
16	.2574		.37
18	.4412		.4995
19	.4233		.592
20	.3497		.481
21	.3681		.3885
22	.2945		.259
23			.2405
Max	.4412	.5723	.592
Min	.1833	.2215	.2405
Avg	.2998	.3877	.4310

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

SHIRUR(KASAR) S/DN.[802] BU 4802

Substation No/ Name :- 054128 / 33 KV TINTARWANI

Feeder No / Name : 203 / Matori Ag

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	18-DEC-17	19-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.055	
2		.11	
3		.0549	
4		.0732	
5		.0914	
6		.128	
7	.1081	.1646	
8	.1262	.1829	
9	.1442	.2012	
10	.0915	.2012	1.0476
11	.0366	.0366	.0526
12	.0183		.0175
13			.0175
14			.0175
15	.0183		.0526
16	.0183		.0351
17	.0183		
18	.055		.0526
19	.055		.0878
20	.0367		.1053
21	.0367		.0703
22	.055		.0527
23			.0527
Max	.1442	.2012	1.0476
Min	.0183	.0366	.0175
Avg	.0584	.1181	.1278