

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134003 / AMBAD

Feeder No / Name : 201 / TOWN I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335			.381		.4763	.6097
2	.7621			.381		.4763	.6097
3	.6668			.4763		.4763	.6097
4	.4572			.4763		.4763	.6097
5	.5335			.4763		.4763	.6097
6	.5335			.4763		.4763	.7621
7	.5335	1.1431		.4763	1.1431	.4763	.7621
8	.9526	.8002	.5716		.4763	.6668	.7621
9		.6668			.4763	.6668	.9526
10		.5335	.5716		.4763	.5335	.9526
11		.5335	.5716		.4763	.6668	.9526
12		.5335	.5716	1.1431	.4763	.381	.9526
13		.5335	.4763		.4763	.6668	
14	.9526	.4001	.4763		.4763	.4001	
15		.4001	.381		.4763	.4572	
16		.4572	.381		.4763	.4572	.6668
17		.6668	.381		.4763	.6097	.5335
18		.8002	.4763		.4763	.7621	.8002
19		.6668	.4763		.4763	.7621	.8002
20		.6668	.381		.4763	.7621	.8002
21		.5335	.1524		.4763	.7621	
22		.381	.1524	.9526		.7621	.6668
23			.1524		.4763	.7621	.6668
24	.6097	.9526	.1524		.4763		.6097
Max	.9526	1.1431	.5716	1.1431	1.1431	.7621	.9526
Min	.4572	.381	.1524	.381	.4763	.381	.5335
Avg	.6535	.6276	.3953	.5821	.5155	.5832	.7345

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134003 / AMBAD

Feeder No / Name : 202 / TOWN2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8002		.4763	.4763		.5716	.7621
2	.9145		.4763	.4763		.5716	.7621
3	.8002		.4763	.4763		.5716	.7621
4	.9335		.5716	.5716		.5716	.7621
5	.9335			.5716		.6668	.7621
6				.5716		.6668	1.0669
7	.8002	1.5242		.5716		.6668	1.0669
8	1.3336	1.0669			.5716	1.0669	1.0669
9		.9335			.5716	1.2003	1.3336
10		.8002			.5716	.8002	1.1431
11		.6668	.5239		.5716	.6668	
12		.6668	.5716	1.1431	.5716	.8002	.9526
13		.6668	.5716		.5716	.5335	
14	1.1431	.5335	.5716		.5716	.5335	
15		.4668			.5716	.6097	
16		.5335			.5716	.6097	.5716
17		.5335	.4763		.5716	.7621	.6668
18		.6668	.5716			.9145	
19		.6668	.5716		.5716	.9145	.6668
20		.8002	.4763		.5716	.9145	.6668
21		.8002	.1905		.5716	.9145	.6001
22		.8002	.4763	1.1431	.5716	.9145	.6259
23			.1905			.9145	
24	.7621	1.2955	.1905		.6859		.7621
Max	1.3336	1.5242	.5716	1.1431	.6859	1.2003	1.3336
Min	.7621	.4668	.1905	.4763	.5716	.5335	.5716
Avg	.9357	.7895	.4614	.6668	.5792	.7546	.8334

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134003 / AMBAD

Feeder No / Name : 205 / SHAHAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.4289		.9526	1.5242
2				1.7147		.9526	1.5242
3				1.7147		1.1431	1.5242
4				1.7147		1.1431	1.5242
5				1.7147		1.1431	2.2862
6				1.7147		1.1431	2.2862
7		1.8671			3.0483	1.1431	2.2862
8	.9526	1.2003		1.7147	1.5242	1.7337	2.2862
9		1.2003	.5716		1.5242	1.8404	3.0483
10			.5716		.381		.7621
11		2.0005	.9526		.381		.7621
12		2.1338	.9526	.9526	.381		.7621
13		2.4006	1.4289		.381		
14	3.4294	2.5339	1.4289		.381		
15		2.4006	1.7147		.381		
16		2.4006			.5716		
17		2.7435	1.7147		.5716		
18		2.5339	.5716		.5716	.7621	
19		.7621	.5716		.5716	1.1431	.9335
20		.6668	.5716		.5716	1.1431	1.0669
21		.6668	.5716		.5716	1.1431	1.0669
22		.6668	.5716	1.7147	.5716	1.0669	1.0669
23					.5716	1.2193	1.3336
24		1.7147	.9526		.9526		1.5242
Max	3.4294	2.7435	1.7147	1.7147	3.0483	1.8404	3.0483
Min	.9526	.6668	.5716	.9526	.381	.7621	.7621
Avg	2.191	1.7433	.9390	1.5983	.7727	1.1782	1.5316

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134003 / AMBAD

Feeder No / Name : 206 / WATER SUPPLY

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334			.0953		.1429	.3048
2	.1524			.0953		.1429	.3048
3	.1334			.0953		.1429	.3048
4	.1334			.0953		.1429	.3048
5	.1143			.0953		.1429	.3048
6	.1429			.0953		.1429	.3048
7	.2286	.381		.0953		.1429	
8	.381	.2286	.1905		.1905	.1524	.3048
9		.1715	.1905		.1905	.1334	.381
10		.1715	.1905		.1905	.1143	.381
11		.2	.1905		.1905	.1143	.381
12		.1143	.1905	.1905	.1905	.2	.381
13		.1334	.1905		.1905	.2	
14	.381	.1143	.1905		.1905	.1334	
15		.2	.1905		.1905	.3048	
16		.1143	.1905		.1905	.4572	.2667
17		.1429	.1905		.1905	.3048	.1334
18		.2	.1905		.1905	.3048	.1143
19		.2	.1905		.1905	.3048	.1334
20		.1334	.1905		.1905	.3048	.2286
21		.1334	.0762		.1905	.3048	.2
22		.1334	.0762		.1905	.3048	.2
23			.0762		.1905	.3048	.1143
24	.1524	.381	.0762		.1905		.3048
Max	.381	.381	.1905	.1905	.1905	.4572	.381
Min	.1143	.1143	.0762	.0953	.1905	.1143	.1143
Avg	.1953	.1855	.1636	.1072	.1905	.2149	.2677

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134003 / AMBAD

Feeder No / Name : 207 / TOWN NO-3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001			.2382		.2858	.3048
2	.4001			.2382		.2858	.381
3	.4001			.2858		.3334	.381
4	.4572			.2858		.3334	.381
5	.381			.2858		.2858	.4572
6	.3334			.2858		.2858	.4572
7	.3334	.5716			.5716	.2858	.4572
8	.5716	.4001	.2858		.2858	.3334	.4572
9		.3334	.2858		.2858	.3334	.5716
10		.3429	.2858		.2858	.4001	.5716
11		.3334	.2858		.2858	.4001	.5716
12		.3334	.2858	.5716	.2858	.4001	.5716
13		.3334	.2858		.2858	.4001	
14	.5716	.3334	.2858		.2858	.3334	
15		.2858	.2858		.2858	.4572	
16		.4001	.2858		.2858		.4001
17		.4001	.2858		.2858	.4572	.3429
18		.3334	.2858		.2858	.4572	.2667
19		.6668	.2858			.4572	.3334
20		.4572	.2858		.2858	.4572	.3334
21		.4668	.2858		.2858	.4572	.3334
22		.4001	.2858	.5716	.2858	.4572	.3334
23			.2858		.2858	.4572	.4001
24	.4668	.5716	.2858		.2858		.381
Max	.5716	.6668	.2858	.5716	.5716	.4572	.5716
Min	.3334	.2858	.2858	.2382	.2858	.2858	.2667
Avg	.4315	.4096	.2858	.3454	.3026	.3797	.4137

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134011 / WADIGODRI

Feeder No / Name : 201 / TAKA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.2667	.2667	.4001	.0381	.4001	
2	.2477	.3048	.3239	.4382	.0381	.4001	
3	.2858	.3048	.3429	.4763	.0381	.4572	
4	.362	.4191	.362	.5525	.0572	.5525	
5	.4572	.743	.3048	.6478	.0572	.724	
6	.5335		.4191	.7621	.0572	.9145	
7	.6097		.6097	.8954	.0572	1.0288	
8	.7049	1.0288	.724	1.0669	.0572	1.2384	
9	.7621	1.0479	.6097	1.1431	.0572	1.3336	
11							.724
12			1.0479				.8002
14							1.1241
15							1.3336
16							1.4098
17							1.2003
18							1.2003
23		.2286					
24	.2096	.4572	.2286	.381	.0381	.3429	
Max	.7621	1.0479	1.0479	1.1431	.0572	1.3336	1.4098
Min	.2096	.2286	.2286	.381	.0381	.3429	.724
Avg	.4420	.5334	.4763	.6763	.0496	.7392	1.1132

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134011 / WADIGODRI

Feeder No / Name : 202 / NALEWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.2667	.2286	.1715	.1905	.1905	.3429
2	.2477	.2667	.2667	.2286	.3429	.1905	.381
3	.2858	.3429	.3048	.2667		.2096	.5335
4	.362	.362	.362	.362	.4572	.2477	.5716
5	.4572	.4572	.4191	.5525	.5525	.3429	.6859
6	.5525	.5335	.5335	.5906	.6478	.4572	.7621
7	.7049	.6668	.5716	.6287	.743	.6097	.7811
8	.7811	.7621	.743	.6287	.8383	.743	.6859
9	.7621	.7621	.5525	.6478	.6097	.5716	.5716
10	.4001	.4191	.4954	.5716	.4572	.381	.4572
11	.3429	.3429	.381	.4572	.3048	.2858	.381
12	.3048	.3048	.2667	.3429	.1905	.1905	.2667
13	.2477	.2286	.2286	.2286	.1715		.1715
14	.2096		.1905	.2286	.1524	.1715	.1524
15	.1905		.1905	.1905	.1524	.1905	.1905
16	.1905		.1905	.1905	.1524	.2096	.2477
17		.2286		.4572	.3048	.381	.3239
18		.6097	.4763	.6097	.5906	.4572	.4572
19		.6478	.4763	.4572	.6859	.4001	.5525
20		.5716	.5335	.4954	.6668	.3429	.6097
21		.362	.4191	.381	.5525	.2667	.5716
22		.2667	.2096	.2477	.4572	.2096	.4382
23		.1905	.1905		.3239	.1905	.3048
24	.2477	.4572	.1905	.1524	.1905	.2286	.1524
Max	.7811	.7621	.743	.6478	.8383	.743	.7811
Min	.1905	.1905	.1905	.1524	.1524	.1715	.1524
Avg	.3844	.4309	.3661	.3951	.4233	.3247	.4414

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134011 / WADIGODRI

Feeder No / Name : 203 / GONDI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.3429	.3429	.3429	.362	.381	.362
2	.381	.362	.362	.381	.3429	.362	.381
3	.381	.4191	.362	.5335	.3239	.362	.381
4	.4572	.4572	.4001	.5716	.3048	.4001	.4382
5	.6097	.5525	.5716		.4572	.4191	.5525
6	.9145				.743	.5525	.7621
7	1.0288				.8383	.724	.9526
8	1.0479		.381	.4191	.9145	.9335	.9907
9	1.0098		.6097	.8002	.6859	1.0098	1.0288
10	.7621		.5716	.6097	.5716	.7811	.724
11	.6097	.5906	.5716	.5335	.4191	.4572	.4954
12	.381	.5906	.5335	.4191	.2667	.3239	.381
13	.3239	.4572	.381	.381	.2667	.3048	.2858
14	.2858		.3429	.3429	.2477	.3048	.3048
15	.2667	.3429	.3048	.3429	.2477	.2858	.3429
16	.2858	.3048	.3048	.3429	.2858	.3429	.362
17	.6478	.381	.4191	.5525	.4572	.3429	.4572
18	.8192	.5906	.6478	.7621	.7621	.4382	.724
19	.6859		.6478	.5525	.8573	.6859	.8383
20	.6478	.4954	.724	.5335	.8764	.724	.8002
21	.5906	.4763	.724	.4572	.7621	.6097	.724
22	.4572	.4191	.362	.362	.6097	.6097	.4763
23	.4572	.3429	.3239		.4572	.5525	.381
24	.4001	.4954	.3239	.3048	.3239	.4001	.3239
Max	1.0479	.5906	.724	.8002	.9145	1.0098	1.0288
Min	.2667	.3048	.3048	.3048	.2477	.2858	.2858
Avg	.5755	.4483	.4642	.4772	.5160	.5128	.5612



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134011 / WADIGODRI

Feeder No / Name : 205 / SHAHAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.743	.8002	1.3527	.9907	1.3146	1.0669	
2	.743	.8002	1.4098	1.0479	1.4861	1.086	
3	.8383	.9145	1.467	1.1241	1.6956	1.086	
4	1.1622	1.0288	1.5432	1.2574	1.8861	1.1241	
5	1.3146	1.3146	1.5813	1.3717	2.2672	1.5432	
6	1.5813	1.5242	1.7718	1.6956	2.4577	1.6956	
7	1.8671	1.5242	1.9624	2.0957	2.553	2.2481	
8	1.9624	1.829	.2667	2.2862	2.4768	2.3815	
9	2.0957	2.2672	.2858	2.3434	2.4006	2.4577	
12							2.1338
13							2.21
14							2.4577
15							2.572
16			.1524				2.6482
17							2.4768
18							2.2291
24	.6478	.4572	1.2955	.9145	.5525	.9717	
Max	2.0957	2.2672	1.9624	2.3434	2.553	2.4577	2.6482
Min	.6478	.4572	.1524	.9145	.5525	.9717	2.1338
Avg	1.2955	1.2460	1.1899	1.5127	1.9090	1.5661	2.3897

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134011 / WADIGODRI

Feeder No / Name : 206 / SHAHAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3429	.381	.3429	.381	.381	.3429
2	.3048		.3429	.381	.4382	.381	.362
3	.3429	.362	.381	.4382	.5144	.4191	.3239
4	.362	.4382	.4572	.5144	.6478	.4382	.362
5	.4572	.4954	.5525	.5716	.743	.4382	.4954
6	.5716		.6287	.6287	.8002	.5335	.743
7	.6668		.7621	.6859	.8383	.6668	.9907
8	.724		.381	.7621	.8764	.6097	.9145
9	.7049	.3429		.8573	.6097	.6478	.724
10	.5335	.4763		.6859	.5335	.4001	.5335
11	.4001	.4001		.4954	.381	.3239	.362
12	.362	.3429		.4191	.3239	.3239	.3429
13	.362		.4191	.3429	.3239	.3048	.3048
14	.3429	.3048	.381	.3429	.3429	.2858	.2858
15	.3429	.362	.3429	.3429	.3429	.3048	.2667
16	.3048	.381	.3048	.3429	.3429	.3048	.3048
17		.5716	.5335	.6478	.4001	.5144	.4191
18		.8002	.6478	.8002	.8192	.5906	.724
19		.8764	.6478	.724	.8954	.6478	.7811
20		.7621	.7621	.6097	.8954	.5716	.8383
21		.6668	.6287	.5144	.7811	.4954	.743
22		.381	.362	.4382	.5716	.4382	.5335
23		.362	.3239		.4954	.362	.4191
24	.3239	.3429	.3239	.2858	.3429	.381	.3429
Max	.724	.8764	.7621	.8573	.8954	.6668	.9907
Min	.3048	.3048	.3048	.2858	.3239	.2858	.2667
Avg	.4359	.4743	.4782	.5293	.5684	.4485	.5192

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134011 / WADIGODRI

Feeder No / Name : 207 / GONDI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.5906
2							.6287
11	.743	.743	.8002	.8573	.9907	.9526	
12	.8764	.7621	.9526	.9907	1.1431	1.105	
13	.8954		.9526	1.105	1.1431	1.1622	
14	.8954	.8764	.9907	1.105	1.1812	1.1431	
15	.8573	.9526	1.0479	1.1431	1.2193	1.105	
16	.8383	.9145	1.0479	1.1431	1.1812	1.1431	
17	.9145	.8954	1.0098	1.1241	1.105	1.0098	
18	.724	.9526	1.0288	.8573	1.0098	.8002	
21	.1524						
24							.5716
Max	.9145	.9526	1.0479	1.1431	1.2193	1.1622	.6287
Min	.1524	.743	.8002	.8573	.9907	.8002	.5716
Avg	.7663	.8709	.9788	1.0407	1.1217	1.0526	.5970

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134011 / WADIGODRI

Feeder No / Name : 208 / DONGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.724
2							.724
3							.8002
4							.8383
5							.8383
6			.1524	.1524			1.0288
7							1.1431
8							.6859
9		.4191					.5716
11	.7621	.4191	.724	1.105	1.0669	1.2384	
12	.8764	.4572	.8573	1.1812	1.2384	1.5432	
13	.9145		.9907	1.2765	1.2384	1.6004	
14	1.0098	1.0669	1.1431	1.2384	1.2955	1.4861	
15	.9907	1.2193	1.2193	1.2384	1.2955	1.4289	
16	.9526	1.1431	1.1812	1.2384	1.2955	1.3146	
17		1.1812	1.4098	.8002	1.1431	1.2574	
18		1.1431	1.5242	.5906	1.0288	1.2003	
24							.6478
Max	1.0098	1.2193	1.5242	1.2765	1.2955	1.6004	1.1431
Min	.7621	.4191	.1524	.1524	1.0288	1.2003	.5716
Avg	.9177	.8811	1.0224	.9801	1.2003	1.3837	.8002

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134011 / WADIGODRI

Feeder No / Name : 210 / p.sirasgaon (Ag)

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							1.448
2							1.5051
3							1.5242
4							1.6194
5							1.6385
6							1.6956
7							1.7147
8							1.6575
9							1.5813
11	2.6292	2.4006		2.2862	2.4387	2.0957	
12	2.915	2.2672		2.8197	2.5149	2.4577	
13	3.0293		2.572	2.8578	2.4768	2.6482	
14	3.1436	2.4768	2.7054	2.8578	2.4768	2.6101	
15	3.1245	2.8578	2.8197	2.8197	2.4196	2.6482	
16	3.0864	3.1055	2.6673	2.7816	2.3815	2.5149	
17	2.8578	2.4768	2.6673	2.553	2.3053	2.2862	
18	2.6482	2.21	2.4768	2.3053	2.0957	2.1148	
20						.1524	
22				2.3053			
23		2.21					
24			2.21				1.467
Max	3.1436	3.1055	2.8197	2.8578	2.5149	2.6482	1.7147
Min	2.6292	2.21	2.21	2.2862	2.0957	.1524	1.448
Avg	2.9293	2.5006	2.5884	2.6207	2.3887	2.1698	1.5851

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134011 / WADIGODRI

Feeder No / Name : 212 / Baraswda (G)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	1.2193	.8002	.4763	.5525	.6478	.1524
2	.9145	1.3146	.9145	.5144	.5335	.6478	.1905
3	.9145	1.4098	.9907	.5716	.6478	.743	.1905
4	.9335	1.4861	1.0479	.6859	.8383	.8573	.2286
5	1.0479	1.5242	1.1431	.7621	1.2193	.8573	.3048
6	1.1431	1.5623	1.1622	.9145	1.3146	1.2955	.3429
7	1.2384	1.5432	1.1812	1.0288	1.4098	1.448	.362
8	1.3146	1.6004	1.2193	1.105	1.4861	1.5242	.3048
9	1.2384	1.6194	1.2384	1.2003	1.448	1.5051	.2667
10	.2477	.2858	.2667	.2667	.2286	.2096	.2286
11	.1715	.1905	.1905	.2286	.1905	.1715	1.1431
12	.1334	.1905	.1524	.1524	.1524	.1524	1.2003
13	.1334		.1524	.1334	.1524	.1334	1.2574
14	.1334	.1905	.1524	.1334	.1524	.1143	1.3908
15	.1334	.1143	.1143	.1334	.1143	.1143	1.4861
16	.1334	.1524	.1143	.1524	.1143	.1524	1.4098
17	.1715	.1524	.1524	.1715	.1905	.1905	1.4098
18	.1524	.3429	.1524	.2477	.3239	.2858	1.2574
19	.1524	.2667	.1715	.1905	.362	.3429	.2477
20	.1905	.1905	.3429	.1715	.3429	.362	.3048
21	.1905	.1524	.2286	.1715	.2858	.3048	.2858
22	.2667	.1143	.1905	.1524	.2286	.2667	.2667
23	.3048	.1143	.1905		.1905	.2286	.2286
24	.743	.4572	.7621	.4382	.362	.5906	.1524
Max	1.3146	1.6194	1.2384	1.2003	1.4861	1.5242	1.4861
Min	.1334	.1143	.1143	.1334	.1143	.1143	.1524
Avg	.5351	.7041	.5430	.4349	.5350	.5477	.6089

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134026 / JAMKHED

Feeder No / Name : 201 / JAMKHED

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.7716	.583	.6859	.6859	.7716	.6859
2	.6859	.8573	.583	.6859	.7716	.8573	.8573
3	.7716	.8573	.8573		.8573	.9431	.9431
4	.8573	.9431	.8573	1.0974	1.0288	.9774	1.0288
5	1.1831	1.0288	1.0288	1.2003	1.2003	1.0802	1.2689
6	1.286	1.2003	1.2003	1.3717	1.2003	1.3546	
11	1.0288	1.3546	1.0802	1.286	.9602	1.2003	
12	1.0288	1.5432	1.0631	1.3717	.9259	1.3717	.823
13	.9945	1.6632	1.046	1.2003	.7716	1.6118	.8916
14	.8573	1.6289	1.0974	1.3717	.7716	1.5432	
15	.7716	1.5432	1.2003	1.3717	.7716	1.5604	.7888
16		1.5432	1.2689	1.3032	.8745	1.5261	.8573
17	1.0288	1.5261	1.3203	1.3717	.9259		.9431
18	1.2003	1.3203	1.406	1.1145	.1372	1.2003	1.3203
19	1.3889	1.0288	1.2003	1.2174	1.4575	1.2003	1.5775
20	1.0288	.9602	1.0288	.9431	1.0974	1.0974	1.3546
21	.9431	.8573	.8573	.7373	1.0288	1.0288	1.1317
22	.8573	.6859	.8059	.7373	.9088	.8573	1.0288
23	.7716	.6344	.7716	.6859	.7716	.6859	.8573
24	.6859	.6001	.7716	.7716		.6859	.6859
Max	1.3889	1.6632	1.406	1.3717	1.4575	1.6118	1.5775
Min	.6859	.6001	.583	.6859	.1372	.6859	.6859
Avg	.9503	1.1274	1.0014	1.0802	.9025	1.1344	1.0026

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134026 / JAMKHED

Feeder No / Name : 202 / ROHILAGAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.286	1.7147	1.0288	.8573	.8573	.7716	.8573
2	1.3717	1.8004	1.3717	.8573	1.0288	.9945	1.0288
3	1.3717	1.8519	1.7147	1.0288	1.2003	1.2346	1.2003
4	1.5089	1.8861	1.8861	1.2003	1.2003		
5	1.8176	1.989	2.0576				
6	2.2291	2.572	2.2291				
7	3.035	3.0864	2.7606				
8	3.2922	3.2579	3.1379				
9	3.035	3.035	2.8292				
10	1.1831						
11	.8573			2.8807	3.2407	2.6235	2.7435
12	.6859			3.4294	3.3951	3.1379	3.2236
13	.6001	.9259			3.3608	3.155	3.275
14	.6001	.8573	.6859	3.5837	3.4979	3.035	.3086
15		.8573	.6859	2.0576	3.4294	3.1893	3.1379
16	.6859	.9431	.7545	3.4808	3.275	3.0693	3.0007
17	.8573	.9431	.8059	3.5151	3.3436	3.2579	2.9492
18	1.3717	1.4575	1.2689	3.2922	3.0693	2.8292	1.6632
19	2.0576	1.5432	1.3717	2.1091	2.2805	2.0576	2.2634
20	1.9033	1.869	1.8861	2.2119	1.869	2.1776	1.8861
21	1.0288	1.0288	1.0288	1.1145	1.1145	1.2003	1.3375
22	1.0288	.8573	.9088	1.1145	.9259	1.2003	.9945
23	.8573	.7545	.8573	.7716	.8059	1.2346	.7716
24	1.0288	1.0288	1.0288	.8573	.6859	.8573	.8573
Max	3.2922	3.2579	3.1379	3.5837	3.4979	3.2579	3.275
Min	.6001	.7545	.6859	.7716	.6859	.7716	.3086
Avg	1.4649	1.6314	1.5149	2.0213	2.1433	2.1191	1.8529



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134026 / JAMKHED

Feeder No / Name : 203 / NANDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.4287	.2401	.6516	.9431	.703	.6859
2	.3429	.4287	.2229	.6859	.9431	.7202	.703
3	.3429	.4287	.2401	.6859	.9431	.7202	.7545
4	.5144	.4287	.3429	.7716	1.0288	.7373	.8573
5	.6344	.5144	.5144	.8573	1.1145	.8573	1.0288
6	.6859	.5144	.5144	1.0288	1.4575	1.0117	1.5089
7	.9774	.6859	.6516	1.2689	1.8004	1.6632	
8	.5144	.8059	.7545	1.8176	2.2977	2.2977	2.0576
9	.5144	.6859	.6859	1.9376	2.0748	2.1262	2.1605
10				.4287	.4287	.3429	.3944
11	1.7318	1.6804	1.9547	.2572	.2058	.2572	.2229
12	1.749	2.0576	2.0576	.1715	.1715		
13	2.1605	2.2977	2.2291	.1715	.12	.2229	
14	2.2291	2.2291	2.2634	.1715	.1543	.1715	.1543
15	2.0748	2.2291	2.2291	.1715		.2229	
16	2.0748	2.1262	2.2291		.2058	.1543	.2229
17	1.8861	2.1262	1.9719	.3429	.2915	.2743	.3086
18	1.6461		1.286		.6173	.5144	.583
19	.7716		.5144	.7545	.5658	.5144	.5144
20	.6859	.463	.4801	.6859	.4287	.4973	.463
21	.6001	.3429	.3429	.5144	.3772	.4801	.3429
22	.4287	.2572	.3258	.5144	.3086	.3429	.2572
23	.4287	.2401	.3086	.8573	.2572	.3429	.2229
24	.4287	.2401	.5144	.5144	.8916	.6859	.6859
Max	2.2291	2.2977	2.2634	1.9376	2.2977	2.2977	2.1605
Min	.3429	.2401	.2229	.1715	.12	.1543	.1543
Avg	1.0370	1.0100	.9945	.6937	.7664	.6896	.7064

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134039 / CHINCHKHED

Feeder No / Name : 201 / CHINCHKHED AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193	1.2193	1.3717				
2	1.2193	1.3717	1.3717				
3	1.2193	1.3717	1.3717				
4	1.3717	1.5242	1.3717				
5	1.3717	1.5242	1.3717				
6	1.6766	1.6766	1.5242				
7	2.2862	1.9052	2.2862				
8	2.5911	2.5911	2.7435				
9	2.5911	1.9814	2.4006				
11				1.9814	2.4006	1.8861	2.0576
12				2.5911	2.4006	2.572	2.7435
13				2.5911	2.8959	2.915	3.0864
14				2.5911	2.6673	2.572	
15				2.5911	2.5339	2.7435	2.572
16				2.5911	2.7435	2.7435	2.7435
17				1.9814	2.5911	2.8292	2.7435
18				2.4006	2.4387		2.2291
24	1.2193	1.2193	1.3717				
Max	2.5911	2.5911	2.7435	2.5911	2.8959	2.915	3.0864
Min	1.2193	1.2193	1.3717	1.9814	2.4006	1.8861	2.0576
Avg	1.6766	1.6385	1.7185	2.4149	2.5840	2.6088	2.5965

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134039 / CHINCHKHED

Feeder No / Name : 202 / SIRNER GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.0857	.1715	.1715	.1715	.1715	.1715
2	.1715	.0857	.1715	.1715	.1715	.1715	.1715
3	.1715	.0857	.1715	.2572	.2572	.1715	.1715
4	.1715	.0857	.1715	.3429	.3429	.2572	.2572
5	.3429	.2572	.3429	.4287	.3429	.4287	.3429
6	.5144	.3429	.5144	.5144	.5144	.6001	.6001
7		.4287		.5144	.5144	.6001	.6001
8		.4287		.3429	.5144	.5144	.6001
9				.3429	.5144	.5144	
10	.5144		.3429	.3429	.3429		.3429
11	.1715	.1715	.2572	.1715	.1715	.2572	.1715
12	.1715	.1715	.1715	.1905	.0857	.1715	.1715
13	.1715			.1715	.0857	.1715	.0857
14	.0857			.1715	.0857	.1715	.0857
15	.0857	.1715	.0857	.1715	.0857	.1715	.0857
16	.1715		.1715	.1715	.0953	.1715	.1715
17	.2572		.1715			.1715	.1715
18	.3429		.2572		.3429	.3429	.3429
19	.4287	.4287	.4287	.5144	.5716	.5144	.5144
20	.3429	.3429	.2572	.3429		.3429	.3429
21	.2572	.2572	.2572	.3429	.2572	.2572	.2572
22	.1715	.1715	.1715	.1715	.1715	.1715	.1715
23	.0857	.1715	.1715	.1715	.1715	.0857	.1715
24	.1715	.0857	.1715	.1715	.1715	.1715	.1715
Max	.5144	.4287	.5144	.5144	.5716	.6001	.6001
Min	.0857	.0857	.0857	.1715	.0857	.0857	.0857
Avg	.2368	.2219	.2347	.2815	.2719	.2870	.2684

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134039 / CHINCHKHED

Feeder No / Name : 203 / SHIRNER AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.9145	1.0669	1.3336	.8573
2				.9145	1.2003	1.3336	.8573
3				1.0288	1.0669	1.3336	
4				.9145	1.1431	1.3336	
5				1.0669	1.1431	1.5242	
6				1.0669	1.2193	1.5242	
7				1.5242	1.9814	2.2862	
8				1.829	2.4387	2.8578	1.4575
9				2.1338	2.4387	2.8578	2.6673
10	1.5242						
11	1.9814	1.6766	2.2291				
12	2.4387	2.5911	2.4387				
13	2.4387	2.7435	3.4294				
14	2.5911	3.2007	3.0483				
15	2.5911	3.2007	3.0483				
16	2.4387	2.8006	2.8959				
17	2.2862	2.8006	2.8959				
18	2.2862	2.6673	2.4387				
24				.7621	.9907	1.3336	.8573
Max	2.5911	3.2007	3.4294	2.1338	2.4387	2.8578	2.6673
Min	1.5242	1.6766	2.2291	.7621	.9907	1.3336	.8573
Avg	2.2863	2.7101	2.8030	1.2155	1.4689	1.7718	1.3393

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134039 / CHINCHKHED

Feeder No / Name : 204 / CHINCHKHED GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.4287	.4287	.5144	.4287	.4287	.4287
2	.5144	.4287	.4287	.5144	.4287	.4287	.4287
3	.5144	.4287	.4287	.6859	.6859	.4287	.4287
4	.5144	.6859	.5144	.8573	.8573	.5144	.4287
5	1.2003	1.0288	.9431	1.0288	1.0288	1.0288	.6859
6	1.3717	1.286	1.0669	1.3717	1.3717	1.6289	1.0288
7		1.286	1.2193				1.5432
8							1.4575
9		1.0669		.6859			
10	1.3717		1.0669	1.3717	1.0288		.9431
11	.7716	.6859	.7716	.7716	.6859	.7716	.6859
12		.5144	.6859	.5144	.5144	.5144	.5144
13	.4287	.5144		.5144	.5144	.5144	.4287
14	.4287			.5144	.5144	.3429	
15	.5144			.5144	.5144	.2572	.4287
16				.5144		.2572	.5144
17						.3429	.6859
18	.6001		.6001		.8573	.8573	
19	1.2193	1.3717	1.3717	1.3717	1.3717	1.2955	1.3717
20	.9145	1.0288	1.0288	1.0288	.8573	.9145	1.0288
21	.7716	.7716	.6859	.6859	.7716	.7716	.6859
22	.5144	.6001	.5144	.5144	.4287	.5144	.5144
23		.4287	.5144	.5144	.4287	.4287	.5144
24	.5144	.4287	.4287	.5144	.4287	.4287	.4287
Max	1.3717	1.3717	1.3717	1.3717	1.3717	1.6289	1.5432
Min	.4287	.4287	.4287	.5144	.4287	.2572	.4287
Avg	.7458	.7638	.7470	.7502	.7220	.6335	.7226

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134048 / TADHADGAON

Feeder No / Name : 201 / TADHADGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3982	.3048	.3429	.362	.3881	.3048	.4287
2	.4163	.3334	.3429	.3475	.4435	.3353	.4287
3	.4163	.3334	.3429	.3475	.499	.3201	.4287
4	.4344	.4001	.3429	.439	.5544	.3334	.4287
5	.4525	.5335	.3429	.4755	.5853	.3334	.5144
6	.4344	.4572	.3429	.362	.5853	.4572	.5144
7	.543	.4572	.3429	.3582	.6401	.3334	.6173
8	.5973	.5335	.4458	.362	.0183	.2286	.5144
9	.4115	.4572	.3429		.2829	.2	.3292
10			.2058	.3658	.3048	.2286	.128
11			.591	.695	.4572	.6097	.6733
12			.567	.7712	.5335	.7011	.631
13			.5609	.7716	.6097	.7773	.8063
14			.5784	.7712	.7621	.6859	.7282
15			.5609	.8785	.8383	.6097	.7011
16	.16	.0762	.6836	.9116	.6859	.7316	.6661
17	.2286	.1219	.7011	.8951	.6001	.7316	.6836
18	.2	.3353	.4854	.8478	.6097	.7888	.6068
19	.3048	.4877	.3506	.5853	.4572	.4287	.394
20	.381	.5144	.3582	.567	.381	.5144	.362
21	.381	.5144	.362	.5487	.4572	.5144	.362
22	.3048	.4287	.3658	.5121	.3048	.5144	.3658
23	.2667	.4287	.3841	.4755	.2667	.4287	.362
24	.3982	.3048	.3429	.3658	.3841	.2667	.4287
Max	.5973	.5335	.7011	.9116	.8383	.7888	.8063
Min	.16	.0762	.2058	.3475	.0183	.2	.128
Avg	.3738	.3901	.4286	.5659	.4854	.4741	.5043

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134048 / TADHADGAON

Feeder No / Name : 202 / PANGERKHEDA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.905	.6001	1.3717	1.5947	1.134	.9145	1.3717
2	.8688	.7621	1.3717	1.6834	1.2437	.9335	1.3717
3	.8688	.8383	1.3717	1.6832	1.2803	1.2003	1.3717
4	1.086	.7621	1.3717	1.7909	1.3032	1.5242	1.3717
5	1.1946	.7621	1.7147	2.1491	1.4685	1.5242	2.0576
6	1.2308	.8383	1.8861	2.3034	2.0058	1.5242	2.4006
7	.543	.4001	2.0405	2.4714	2.4539	1.9814	2.5034
8	.543	.2	2.4348	2.8656	3.1381	2.2862	2.572
9	.5853	.3048	2.572	2.6406	2.8807	2.3624	
10	.4877						
11	1.5242	1.829					
12	1.6004	2.2862					
13	2.0576	2.6216					
14	2.1338	2.6216					
15	2.2862	2.4387					
16	1.9814	2.4387	.4481	.3292	.2	.5658	.4163
17	1.6004	2.4387	.5175	.4024	.2667	.6344	.6516
18	1.6766	2.4387	.4435	.5487	.1334	.8745	.9412
19	.7621	.8688	1.1283	1.3121	.6097	.9088	.9593
20	.9145	.8383	1.1462	1.182	.7621	.9602	.9412
21	.7621	.9431	1.1283	1.0498	.9145	.9431	.905
22	.6097	.9088	.985	.924	.7621	.9431	.905
23	.6859	.8573	.9774	.8413	.6097	.9431	.8505
24	.905	.6097	1.0288	1.4175	1.0974	.7621	.9088
Max	2.2862	2.6216	2.572	2.8656	3.1381	2.3624	2.572
Min	.4877	.2	.4435	.3292	.1334	.5658	.4163
Avg	1.1589	1.2873	1.3299	1.5105	1.2369	1.2103	1.3235

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134048 / TADHADGAON

Feeder No / Name : 203 / RUI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6668	.9431	.905	.6468	.4572	.8573
2	1.3432	.9145	.9431	.905	.6838	.4668	.8573
3	1.3969	1.0669	.9431	.9412	.7023	.4668	.8573
4	1.4327	1.1431	.9431	.985	.7316	.6097	.8573
5	1.5061	1.2193	.9945	1.0029	.823	.6097	.9088
6	1.6827	1.2955	1.0288	.7087	.8962	.7621	.9431
7	2.1384	1.3717	1.0802	.7164	1.0059	.6097	.9431
8	2.4272	1.5242	.8573	.6805	.6161	.4572	.7621
9	2.2365	1.6766	.7716	.6036	.5281	.381	.4163
10			.3601	.4572	.381	.3429	.3439
11			2.3312	1.949	1.6766	2.0576	1.7857
12			2.2977	2.4177	2.1338	2.3148	2.2382
13			2.2977	2.5434	2.1338	2.1948	2.0957
14			2.3148	2.5194	2.1338	2.1338	2.0454
15			2.2382	2.5692	2.2862	1.6004	2.079
16		.3429	2.3137	2.3868	2.1338	1.8747	1.9951
17	.2667	.6859	2.3868	2.2447	1.9814	1.9966	2.0287
18	.3048	.8573	1.8233	2.079	1.6766	1.8138	1.9161
19	.6097	1.0974	.8478	.9328	.5335	.8573	.724
20	.7621	1.0288	.9313	.9511	.6001	.9431	.8059
21	.6097	1.0288	.9313	.9694	.6097	.9431	.8059
22	.4572	.9431	.9492	.9145	.6859	.9431	.7164
23	.4572	.8573	.9214	.823	.6097	.9431	.724
24	1.086	.7621	.8573	.905	.5914	.4572	.8573
Max	2.4272	1.6766	2.3868	2.5692	2.2862	2.3148	2.2382
Min	.2667	.3429	.3601	.4572	.381	.3429	.3439
Avg	1.1698	1.0268	1.3461	1.3379	1.1167	1.0932	1.1902



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134049 / SHAHAGAD

Feeder No / Name : 201 / WATER SUPPLY

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0328	.0351	.0343	.0328	.0351	.0351	.0351
2	.0328	.0351	.0343	.0328	.0351	.0175	.0351
3	.0328	.0351	.0343	.0328	.0347	.0175	.0347
4	.0328	.0351	.0343	.0328	.0351	.0175	.0347
5	.0328	.0351	.0343	.0328	.0351	.0173	.0351
6	.0328	.0351	.0343	.0328	.0351	.0175	.0351
7	.0328	.0351	.0343	.0328	.0351	.0173	.0351
8	.0328	.0351	.0343	.0328	.0351	.0347	.0351
9	.0328	.0328	.0171	.0328	.0328	.0171	.0351
10	.0328	.0328	.0343	.0328	.0328	.0343	.0351
11	.0328	.0328	.0514	.0328	.0328	.0343	.0347
12	.0328	.0328	.0343	.0328	.0819	.0171	.0174
13	.0328	.0328	.0343	.0328	.0164		.0175
14	.0328	.0328	.0343	.0328	.0328		.0175
15	.1966	.0328	.0343	.0328	.0328		.0175
16	.0328	.0328	.0351	.0347	.0328	.0343	
17	.0351	.0343	.0175		.0351	.0177	
18	.0351	.0343	.0175	.0351	.0351	.0177	.0175
19	.0351	.0343	.0351	.0354	.0351	.0175	.0175
20	.0351	.0343	.0351	.0354	.0177	.0175	.0175
21	.0351	.0343	.0343	.0354	.0175	.0354	.0175
22	.0351	.0343	.0351	.0354	.0175	.0351	.0175
23	.0351	.0171	.0164	.0354	.0177	.0351	.0175
24	.0328	.0351	.0171	.0328	.0351	.0175	.0351
Max	.1966	.0351	.0514	.0354	.0819	.0354	.0351
Min	.0328	.0171	.0164	.0328	.0164	.0171	.0174
Avg	.0403	.0334	.0316	.0335	.0328	.0240	.0270

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134049 / SHAHAGAD

Feeder No / Name : 202 / PATHARWALA - AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.9217	.695	.8065	.7529
2				1.004	.7145	.787	.8253
3				.9922	.828	.828	.8471
4				1.012	.7674	.8592	.8688
5				1.0526	.9412	.8802	.945
6				1.0526	1.0385	.9217	.9602
7				1.085	1.0686	.9374	1.0031
8				1.2289	1.1873	.9842	.9633
9				1.278	1.2146	1.0974	1.0883
11	1.4243	1.5074					
12		1.5565	1.406				
13	1.5684		1.5775				
14	1.6876		1.5947				
15	1.5729		1.6118				
16	1.6004	1.5238	1.5238				
17	1.5524	1.4746	1.3321				
18		1.406	1.4243				
24				.9217	.6516	.8322	.724
Max	1.6876	1.5565	1.6118	1.278	1.2146	1.0974	1.0883
Min	1.4243	1.406	1.3321	.9217	.6516	.787	.724
Avg	1.5677	1.4937	1.4957	1.0549	.9107	.8934	.8978

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134049 / SHAHAGAD

Feeder No / Name : 203 / S.PIMPLEGON AG 1

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.695	.7811	.8916				
2	.743	.8124	.8916				
3	.743	.8124	.9259				
4	.7876	.8124	.9602				
5	.8025	.8482	1.0288				
6	.8173	.8322	1.0631				
7	.8173	.828	1.1317				
8	.9717	.9878	1.166				
9	1.0364	1.004	1.2517				
11				1.2346	1.3272	1.6632	
12				1.326	1.6712	1.7147	1.8814
13				1.6804	1.5844	1.8347	1.906
14				1.6964	1.4723		1.8061
15				1.6404	1.3125		1.9528
16				1.668	1.5181		1.9845
17				1.531	1.5154		1.7147
18				1.4548	1.5466		1.6857
24	.6805	.7811	.7716				
Max	1.0364	1.004	1.2517	1.6964	1.6712	1.8347	1.9845
Min	.6805	.7811	.7716	1.2346	1.3125	1.6632	1.6857
Avg	.8094	.8500	1.0082	1.5290	1.4935	1.7375	1.8473

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134049 / SHAHAGAD

Feeder No / Name : 204 / GINING

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0036	.1629	.0171	.004	.124	.0044	.0044
2	.0036	.1612	.0171	.004	.1227	.0044	.0044
3	.0036	.1448	.0171	.004	.1014	.004	.004
4	.0036	.1433	.0171	.004	.1463	.004	.0044
5	.0036	.1629	.0171	.004	.1448	.004	.004
6	.0036	.1629	.0171	.004	.1227	.0044	.004
7	.0036	.1612	.0171	.004	.1417	.0048	.0044
8	.0036	.0088	.1543	.1886	.004	.1829	.004
9	.0678	.2263	.2572	.2452	.0857	.1372	.004
10	.0848	.2075	.2229	.2075	.0686	.1372	.004
11	.0848	.2075	.2229	.0857	.0857	.2229	.0044
12	.0678	.2075	.1886	.0857	.0686	.1372	.0044
13	.0678	.2452	.1886	.0678	.0686	.12	.0044
14	.0678	.2641	.2058	.0848	.0686	.1715	.0044
15	.0678	.2641	.2058	.0678	.0686	.12	.0038
16	.0678	.2829	.2103	.0686	.0686	.1543	.0044
17	.0724	.2229	.2353	.0179	.0716	.1254	.0038
18	.0724	.2229	.2172	.0179	.0537	.0179	.004
19	.0886	.12	.128	.0179	.0179	.0179	
20	.1267	.0343	.1267	.1254	.0177	.0181	.0044
21	.0044	.0171	.0044	.1254	.0179	.0177	.0044
22	.128	.0171	.0044	.124	.0179	.0179	.004
23	.128	.0171	.004	.1254	.0175	.0175	.0044
24	.0036	.1086	.0171	.004	.124	.0044	.004
Max	.128	.2829	.2572	.2452	.1463	.2229	.0044
Min	.0036	.0088	.004	.004	.004	.004	.0038
Avg	.0512	.1572	.1131	.0703	.0762	.0688	.0042

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134049 / SHAHAGAD

Feeder No / Name : 205 / PATHARWALA(GAOTHAN)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1187	.1448	.1543	.12	.1629	.1227	.124
2	.1526	.1629	.1543	.12	.181	.1227	.1448
3	.1753	.1791	.1543	.1543	.181	.124	.1448
4	.2561	.2172	.1715	.2195	.2172	.1433	.2149
5	.3109	.3077	.2401	.3109	.3109	.181	.2715
6	.3961	.3658	.3086	.3961	.3801	.2172	.3475
7	.4904	.362	.3772	.4527	.4938	.3077	.4344
8	.4715	.4207	.4458	.4527	.4938	.462	.4207
9	.415	.4527	.4115	.3772	.4755	.4115	.3439
10	.2804	.3292	.3258	.2743	.3584	.2743	.2172
11	.1753	.2743		.2743	.2561	.2229	.2172
12		.2195	.1543	.2195	.1753	.0514	.1629
13	.0175		.1372	.1753	.0335	.0514	.1267
14	.0175		.1372	.1017	.0335	.0514	.1086
15	.0175		.1372	.1017	.0838	.0514	.1097
16	.0175	.2195	.1629	.1017	.0838	.0514	.128
17	.0343	.2058	.2195	.1402	.0354	.0526	.1829
18		.3086	.2715	.2629		.0526	.3841
19	.2926	.3258	.362	.3366	.3721		.3475
20	.2715	.3429	.2715	.2195	.2686	.3506	.2926
21	.2378	.2058	.1646	.1949	.197	.2126	.1829
22	.1629	.12	.1629	.1772	.1791	.1772	.128
23	.1448	.1543	.1372	.1417	.1433	.124	.1097
24	.1187	.128	.1543	.12	.128	.1463	.1227
Max	.4904	.4527	.4458	.4527	.4938	.462	.4344
Min	.0175	.12	.1372	.1017	.0335	.0514	.1086
Avg	.2080	.2594	.2268	.2269	.2280	.1723	.2195

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134049 / SHAHAGAD

Feeder No / Name : 206 / MAHAKALA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.6321	.7674	.4778	.6516
2				.6321	.7876	.5001	.6773
3				.6321	.8173	.5335	.7074
4				.6554	.8253	.5716	.7621
5				.6706	.8688	.8002	.7827
6				.6554	.9145	.7573	.8592
7				.6554	.9804	.8916	.8796
8				.8065	1.0364	.9122	1.0031
9				.8539	1.0202	1.0288	.8398
11	.953	1.1336	1.1145				
12	1.0311	1.1523	1.2003				
13	1.078	1.2803	1.2346				
14	1.0623	1.2651	1.2689				
15	1.0936	1.3123	1.2346				
16	1.1405	1.166	1.0136				
17	.9412	1.166					
18	.7537	.8916	.7701				
24				.602	.5201	.5068	.5468
Max	1.1405	1.3123	1.2689	.8539	1.0364	1.0288	1.0031
Min	.7537	.8916	.7701	.602	.5201	.4778	.5468
Avg	1.0067	1.1709	1.1195	.6796	.8538	.6980	.7710

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134049 / SHAHAGAD

Feeder No / Name : 207 / SHAHAGAD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3052	.6335	.6516	.583	.6767	.6036	.6767
2	.373	.6697	.6859	.6024	.6697	.6335	.7133
3	.4917	.724	.7202	.6984	.7164	.6697	1.0425
4	.7202	.9511	.7545	.8596	.8059	.8962	1.0974
5	.9259	1.0208	.823	1.0791	.9955	1.0242	1.2127
6	1.1919	1.086	.9602	1.4784	1.262	1.2803	1.267
7	1.2803	1.1765	1.2003	1.7353	1.5729	1.3937	1.3169
8	1.531			1.7353	1.2803	1.701	
9	.9694		1.0288	1.643	1.4784	1.3717	1.0985
10	1.3717		1.0974	1.6409	1.5339	1.1145	1.0974
11	1.0974	1.134	.9602	1.5089	1.39	1.0631	1.4632
12	.8962	1.2254	1.3032	1.3121	1.1706	1.286	1.1946
13	.7682	.8238	1.2003	1.0425	1.0425	1.0288	1.086
14	.5083		1.1145	1.0608		.9602	.9877
15	.4908	.7796	.7545	1.0974	1.0974	.8573	.9511
16	.5784	1.0425	.9877		1.134	.9602	.9145
17	.8507	1.0288	1.1888		1.3073	1.2403	1.2803
18		1.0974	1.4373	1.5223		1.4022	1.5364
19	1.0791	1.2003	1.134	1.3611	1.5223	1.3289	1.4632
20	1.086	1.0288	1.1157	1.1157	1.0745	1.2971	1.086
21	.8962	.8916	.905	1.0517	.8505	.985	.7343
22	.8145	.7545	.7783	.9313	.7619	.9313	.7316
23	.7133	.7202	.6274	.7442	.6201	.7164	.0175
24	.3052	.6767	.6859	.6001	.6516	.6219	.6447
Max	1.531	1.2254	1.4373	1.7353	1.5729	1.701	1.5364
Min	.3052	.6335	.6274	.583	.6201	.6036	.0175
Avg	.8367	.9333	.9615	1.1547	1.0734	1.0570	1.0267

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134049 / SHAHAGAD

Feeder No / Name : 208 / S- PIPALGAO GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5544	.6697	.4458	.5544	.4525	.439	.4887
2	.5729	.7164	.6859	.5544	.4477	.543	.6335
3	.7207	.7682	.6859	.7023	.5373	.5487	.6516
4	.8871	.9412	.8745	.7762	.7522	.6154	.8507
5		1.1871	1.0288	.924	.6516	.8596	1.2254
6	1.386	1.2803	1.2003	1.3491	1.2357	.9694	1.2127
7	1.6632	1.4685	1.2346	1.4969	1.39	1.1222	1.2803
8	1.5339	1.4327	1.0631	1.4784	1.267	1.4083	.1417
9	1.2752	1.1827		1.3491	1.1273	1.0288	.2743
10	.9979	1.0534		.9055	.8871	.6859	.1629
11	.5544	.6099	.8573	.6099	.5914	.5658	
12	.4066	.4805	.6859	.4435	.5175	.3944	.5973
13	.3696	.4251	.4801	.4435	.4251	.2743	.4706
14	.2772		.4115	.3881	.3511		.4344
15	.3142			.3511	.3142		.4572
16	.3326			.4435	.462		.4755
17	.5487			.5258	.5258		.5792
18	.8962		.8688	.7442	.7888		.823
19	.8779		1.1765	.9114	1.0867		.8596
20	.8507	.7888	.905	.6379	.724	1.262	.8962
21	.7133	.583	.6878	.6024	.567	.7442	.823
22	.6335	.4458	.6219	.5316	.4163	.6024	.7865
23	.5487	.4287	.5729	.3721	.5792	.4784	.5487
24	.5729	.567	.4287	.5544		.4755	.4706
Max	1.6632	1.4685	1.2346	1.4969	1.39	1.4083	1.2803
Min	.2772	.4251	.4115	.3511	.3142	.2743	.1417
Avg	.7603	.8349	.7850	.7354	.6999	.7232	.6584



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134049 / SHAHAGAD

Feeder No / Name : 209 / S.PIMPALGAON AG 2

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2462	.2172	.2058				
2	.2526	.2317	.2058				
3	.2675	.2429	.2401				
4	.2824	.2286	.2572				
5	.2972	.2378	.2743				
6	.2972	.2462	.2915				
7	.2972	.2526	.3086				
8	.3121	.2896	.3429				
9	.2972	.2824	.3601				
11				.3658	.3864	.4115	
12				.381	.381	.3944	.6249
13					.4572	.4287	.5937
14					.4115		.6081
15					.3506		.6241
16				.2347	.3418		.6321
17				.2343	.3593		1.0551
18				.2968	.3749		.5213
24	.2317	.2286	.2058				
Max	.3121	.2896	.3601	.381	.4572	.4287	1.0551
Min	.2317	.2172	.2058	.2343	.3418	.3944	.5213
Avg	.2781	.2458	.2692	.3025	.3828	.4115	.6656

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134052 / SUKHAPURI

Feeder No / Name : 201 / SUKHAPURI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.763	2.1148	.362	.3734	.301	.6287	.3696
2	.8288	2.572	.5258	.3734	.3315	.6287	.462
3	.8288	2.6673	.6068	.4525	.4144	.6668	.462
4	.9326	2.7625	.6859	.5201	.5268	.6668	.5487
5	1.0526	2.9531	.6935	.6068	.5944	.8383	.6401
6	1.4089		.763	.763	.602	.8383	.823
7	1.8023	2.8578	.8097	.8383	.8478	.4763	.905
8	2.1072	2.7625	.9717	1.0174	.7459		.9145
9	2.1072	2.4768	1.0174	.8383	.7087		.905
10	.6773	.8383	.7811	.6135		.4191	.5544
11	.6135		1.5604	1.406	1.7404	2.3243	1.8004
12	.5258		1.9204	2.3482	1.9566	2.3815	1.7147
13	.5201	.4763	2.0576	2.3482	2.1072	2.4768	2.1052
14	.5258		2.2291	2.3482	2.0062	2.572	2.1862
15	.3734	.6287		2.2672	2.4539	2.3815	2.0243
16		.7011	2.0719	2.1072		2.4387	1.7861
17		.6783	1.7871	2.0062		1.9281	1.8576
18		.6859	1.4842	2.0719		1.4575	1.4118
19		.763	.6859	.663			.7287
20		.6135	.6068	.5935		.5544	.6706
21		.5935	.5258	.5087		.462	.6201
22		.5201	.5258	.4239		.3696	.4525
23		.3734	.4525	.3544		.3696	.4525
24	.6773		.3734	.3734			.3696
Max	2.1072	2.9531	2.2291	2.3482	2.4539	2.572	2.1862
Min	.3734	.3734	.362	.3544	.301	.3696	.3696
Avg	.9840	1.4757	1.0216	1.0924	1.0955	1.2440	1.0319

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134052 / SUKHAPURI

Feeder No / Name : 202 / BELGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.6668	1.1022	1.0059	.6783	1.6766	.823
2	.3734		1.1336	1.1717	.7888	1.8099	.823
3	.3734	.8383	1.1431	1.1888	.763		.823
4	.4668		1.1888	1.3279	.9326		.905
5	.462	.8383	1.3279	1.2631	1.0774		1.0517
6	.5487		1.4575	1.4118	1.3108	2.2862	1.286
7	.5544	.8383	1.3375	1.3375	1.8023		1.8004
8	.6401		1.5089	1.8576	1.989	2.3815	1.8004
9	.5601	.8383		1.7861	1.989		2.1052
10	.3734	.6783	.3734		.5601	.6287	.5544
11	1.166	1.2146		.2801	.2772		.3696
12	1.488	1.3032		.2772	.1867	.4191	.1848
13	1.3803	1.4403	.181		.1867	.2096	
14	1.7147	1.4403	.1867	.1848	.1867	.0953	.1848
15	1.5556	1.4289		.1848	.1867	.0953	.0924
16		1.286	.1867	.1867	.1867	.0953	.1867
17		1.7861	.1867	.1848		.1848	.1867
18		1.5384	.4382	.6468		.6401	.3734
19		.6859	.6935	.8316		.6401	.6335
20		.6001	.6135	.6468		.7316	.6135
21		.5201	.4525	.5601		.462	.6135
22			.4668	.3734		.462	.5258
23		.3506		.3734		.3696	.5258
24			1.0174	.9012	.7087		.6401
Max	1.7147	1.7861	1.5089	1.8576	1.989	2.3815	2.1052
Min	.3734	.3506	.181	.1848	.1867	.0953	.0924
Avg	.8020	1.0163	.7893	.8174	.8124	.7757	.7436

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134052 / SUKHAPURI

Feeder No / Name : 203 / WADIKALYA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4382		1.0059	.9326	.9326	1.2574	.7316
2	.6001		1.0526	.9717	.9116	1.5242	.7316
3	.6001		1.0936	1.0526	1.0174	2.1148	.7316
4	.6783		1.2146	1.1574	1.065	2.1148	.905
5	.6859		1.0802	1.0402	1.1336	2.0005	1.0517
6	.6201		1.1717	1.1288	1.4089	2.0005	1.2003
7	.543		1.2146	1.2041	1.5565	2.0957	1.5432
8	.2801		1.4575	1.6347	1.7404	2.0957	1.5432
9	.2801	.1867	1.3575	1.4118	1.8233	1.9052	1.6766
10	.1867	.181	.1867	.1867	.1867	.1905	.1848
11	1.1717	1.1717	.1867	.1867	.1867		.0924
12	1.267	1.3375	.0934	.0924	.0934		
13	1.286	1.3717	.0934		.0934		.0924
14	1.3279	1.4661	.0934	.0924	.0924		.0924
15	1.2955	1.2346			.0934	2.1148	.0924
16		1.5089	.0934		.0934	.0953	.0905
17		1.4861	.1867	.0934		.0924	.0905
18		1.0936	.3734	.4572		.462	.4668
19		.5258	.5316	.5601		.5487	.5201
20		.5316	.5316	.4668		.5544	.6135
21			.5316	.4668		.5487	.5258
22		.4382	.4668	.4668		.462	.5258
23			.763	.4668		.462	.6135
24	.3734		.9326	.8478	.8764		.6401
Max	1.3279	1.5089	1.4575	1.6347	1.8233	2.1148	1.6766
Min	.1867	.181	.0934	.0924	.0924	.0924	.0905
Avg	.7271	.9641	.6832	.7104	.7827	1.1916	.6416

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134053 / GONDI

Feeder No / Name : 201 / HASNAPUR AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5681	.6059	.5335	.0572			.0572
2	.6173	.6935	.6154	.0572	.0514	.0514	.0572
3	.6584	.7059	.6796	.0572			.0572
4	.7145	.9555	.7459				
5		.9878	.8122				
6	.7922	.9555	.7859				
7	.8069	.9393	.8368				
8	.8916	.9878	.8135				
9	.9214	1.0202	.8402				
11				.7287	.8097	.6628	.0572
12					1.1336	.7472	.0572
13				.3239	1.1336		.4858
14				.7287	1.1984	.8573	.0762
15					1.1174	1.1498	
16				1.1145		1.2146	.664
17							.8097
18		.0572		1.0631	1.1145		1.1012
19	.0381	.0572	.0572			.0572	.0486
20	.0381	.0572	.0572	.0514	.0343	.0572	.0572
21	.0381	.0572	.0572			.0572	.0572
22	.0381	.0572	.0572			.0572	
23	.4012	.4534	.0572	.0514	.0514	.0572	
24	.4995	.6935	.4858		.0514	.0514	.0572
Max	.9214	1.0202	.8402	1.1145	1.1984	1.2146	1.1012
Min	.0381	.0572	.0572	.0514	.0343	.0514	.0486
Avg	.5017	.5803	.4957	.4233	.6696	.4184	.2602

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134053 / GONDI

Feeder No / Name : 202 / GHUNGARDE HADGAON AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4858	.3725	.3239	.9214			.8097
2	.5182	.4696	.3563	1.0277	.7202	.823	.8259
3	.5668	.5506	.4049	1.1041			.8421
4	.6478	.6478	.5182	1.2048	.823	.8573	.8745
5	.6802	.6964	.6478	1.2403			.8097
6	.7125	.7125	.7316	1.258	1.0288	1.0288	.7287
7	.6001	.7287	.7773	1.2403			.5992
8	.5601	.7287	.6859	1.258	1.0631	1.0631	.6478
9	.5335	.7773	.7164	1.2517	.9231	1.0745	.6802
10	.3334	.4858	.6097	.5668	.4049	.5729	.421
11	.5335	.8097	.7926	.4534	.3239	.5175	.3563
12	.8097		.8383		.2915	.4435	.3077
13	.8745	.8097	1.0056	.3239	.2591		.2591
14		.8907	.9536	.3077	.2429	.3326	.2105
15	.7735	.9069	.8669	.3239	.2429	.2591	
16	.8749	.8745	.8413			.4696	.3077
17	.8573	.8907	1.0099			.4534	.4049
18	.8116	.8421	1.0454	.6859	.6001	.4372	.5182
19	.4668	.7773	.7207			.4534	
20	.5335	.7287	.7392	.6859	.7202	.4858	.4858
21	.5468	.5506	.462			.5668	
22	.5735	.4858	.4251			.5992	
23	.442	.3077	.7392	.7202	.7716	.6802	
24	.4858	.3077	.3239	.7802	.7716	.7716	.7287
Max	.8749	.9069	1.0454	1.258	1.0631	1.0745	.8745
Min	.3334	.3077	.3239	.3077	.2429	.2591	.2105
Avg	.6183	.6675	.6890	.8530	.6125	.6258	.5694

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134053 / GONDI

Feeder No / Name : 203 / GONDI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0191	.0572	.2441		.6001	.5407
2	.0572	.0191	.0572	.2789	.4287		.5801
3	.0572	.0191	.0572	.2905		.6859	.6249
4				.3591	.6001		.6401
5				.3839			.643
6				.3715	.7202		.6716
7				.3839		.7716	.6268
8				.3096	.7202	.7716	.6001
9				.4696	.5668		
11	.3772	.3887	.4858				
12	.502		.4858				
13	.502	.5344	.3788				
14		.6478	.5357				
15	.5506	.6802	.5573				
16	.5344	.6802	.5868				
17	.502	.7125	.5858				
18	.4696	.7287	.439	.0171	.0171		.0572
19	.0191	.0572	.0191			.0572	.0572
20	.0191	.0572	.0191	.0171	.0171	.0572	.0572
21	.0191		.0191			.0572	.0572
22	.0191	.0572	.0191			.0572	
23	.0191	.0572	.2441	.0171	.5144	.4534	
24	.0572	.0191	.0572	.2324	.3086	.4287	.4858
Max	.5506	.7287	.5868	.4696	.7202	.7716	.6716
Min	.0191	.0191	.0191	.0171	.0171	.0572	.0572
Avg	.2351	.3118	.2708	.2596	.4326	.3940	.4340

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134053 / GONDI

Feeder No / Name : 204 / KARNJALA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.663	.9231	.6802				
2	.743		.7287				
3	.6859		.7287				
4	.7554	1.0526	.8907				
5	.7202	1.1174	.9717				
6	1.0364	1.1498	.9878				
7	1.0364	.9555	1.004				
8	.8421	.9878	1.0526				
9	1.1336	1.0364	1.0364				
11				1.1012	1.2955	.9282	.7773
12					1.1546	.9878	.8573
13				1.1822	1.1203		1.2803
14				1.5546	1.2003	1.4746	1.2346
15				1.166	1.2231	1.0631	
16				1.8004		1.086	1.246
17						1.0745	1.0288
18				1.5432	1.5432	1.0745	1.2955
23	.9878	.5992					
24		1.0202	.6478			.1524	
Max	1.1336	1.1498	1.0526	1.8004	1.5432	1.4746	1.2955
Min	.663	.5992	.6478	1.1012	1.1203	.1524	.7773
Avg	.8604	.9824	.8729	1.3913	1.2562	.9801	1.1028



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134055 / SHEVGA

Feeder No / Name : 201 / HARATHKHEDA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.2591	.3239	.4954	.6668	.4862	.5716
2	.4001	.2915	.3239	.5716	1.0479	.5365	.5716
3	.381	.3239	.3239	.6668	.8954	.5506	.5716
4	.743	.4024	.3429	.7621	.9526	.6154	.7621
5	.7811	.4858	.4001	.9145	1.1431	.6478	.8764
6	.7621	.5506	.7621	.9145	1.0288	.7125	1.0288
7	.8192	.6478	.9145	1.1622	1.1431	.9555	1.1812
8	.8192	.5992	.8002	1.2003	.5716	1.2631	
9	.724	.5365	.724	1.2574	1.2193	1.3336	1.0669
10	.4572	.362	.4382	.4763	.4001	.4572	.3429
11	1.1822	1.2765	1.1431	.2858	.1781	.2477	.2858
12	1.3441	1.2193	1.5623	.2286	.1619	.1524	.1524
13	1.3117	1.2384	1.5623	.1524	.1457	.1524	.1334
14	1.3603	1.2193	1.467	.1715	.1296	.1715	.1334
15	1.2146	1.467	1.4098	.1715	.1296		.1334
16	.503	1.467		.1715	.1296	.1715	.1905
17	1.1498	1.2384		.2667	.1943	.2286	.2667
18	1.0688	1.1812		.4382	.4696	.4382	.6097
19	.4696	.7621	.743	.381	.6154	.5335	.4763
20	.4858	.5716	.9526	.4191	.5182	.5525	.2858
21	.3887	.381	.4001	.3048	.3353	.4572	.381
22	.2915	.3429	.3429	.3048	.2915	.3429	.3429
23	.2591	.3048	.3429	.2858	.2429	.2858	.2667
24	.3239	.2591	.3239	.362	.7621	.4372	.5716
Max	1.3603	1.467	1.5623	1.2574	1.2193	1.3336	1.1812
Min	.2591	.2591	.3239	.1524	.1296	.1524	.1334
Avg	.7358	.7245	.7430	.5152	.5572	.5100	.4871

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134055 / SHEVGA

Feeder No / Name : 202 / SHEVGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.3018	.3429	.4382	.6668	.7287	.7621
2	.381	.3239	.3429	.4763	.7049	.6802	.7621
3	.3048	.3688	.3429	.6478	.7621	.7449	.9526
4	.2858	.421	.3429	.743	.8002	.7287	1.0479
5	.3429	.5182	.381	.8002	.9717	.8421	1.1431
6	.4763	.6154	.6097	.0953		.9724	1.3336
7	.8573	.6802	.7621	.9907	1.0479	1.0526	1.6766
8	.7621	.7287	.724	.9335	1.1431	1.3603	
9	.6668	.6036	.6859	1.0479	.9526	1.5432	1.3336
10	.4954	.4763	.5144	.5144	.381	.4001	.4191
11	1.2146	1.5242	1.5623	.2477	.2267	.2858	.2667
12	1.4575	1.9052	1.8671	.2096	.1781	.2096	.2286
13	1.5546	1.9243	1.8671	.1715	.1781	.2096	.2096
14	1.5708	1.9052	1.5813	.1715	.1457	.1905	.1905
15	1.5061	1.8099	1.5813	.1715	.1781		
16	.5506	1.7909		.1905	.1943	.1905	.2096
17	1.3927	1.6766		.3429	.2591	.3048	.2667
18	1.2308	1.3908		.5716	.4858	.6097	.7049
19	.4534		.8002	.381	.6706	.6097	.6668
20	.4696	.5716	.3429	.4001	.5182	.6097	.5716
21	.3563	.4572	.362	.3048	.3077	.4954	.4763
22	.3239	.381	.2667	.3429	.2429	.362	.362
23	.2915	.3429	.2667	.381	.2267	.3239	.3429
24	.3429	.2915	.3429	.381	.5716	.583	.724
Max	1.5708	1.9243	1.8671	1.0479	1.1431	1.5432	1.6766
Min	.2858	.2915	.2667	.0953	.1457	.1905	.1905
Avg	.7354	.9134	.7566	.4565	.5136	.6103	.6660

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134055 / SHEVGA

Feeder No / Name : 203 / DHANGAR PIMPRI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.583	.7621	.2858	.2858	.218	.2667
2	.8002	.6706	.8002	.2858	.2667	.2105	.2667
3	1.1431	.6802	.9145	.2858	.3239	.2429	.2667
4	.9335	.8048	.9526	.3239	.3429	.3401	.2667
5	1.2765	1.0395	1.1812	.362	.0381	.3887	.3048
6	1.5242	1.3279	1.5242	.3429		.4858	.381
7	1.7147	1.5424	1.6575	.381	.4191	.5506	.4572
8	1.7528	1.5089	1.7147	.4763	.4763	.5182	
9	1.8099	1.3279	1.7909	.4572	.381	.4572	.4572
10	.4763	.3048	.4572	.4954	.3429	.4001	.4763
11	.1943	.2096	.3048	1.7147		1.7528	
12	.1619	.1905	.2096	2.0767	.6706	2.1529	1.9814
13	.1619	.1905	.2096	1.3336	1.8623	2.1338	2.0195
14	.1457	.1905	.1905	1.9814	1.7652	2.1338	1.829
15	.1296	.1905	.1905	2.0005	1.749		1.829
16	.1457	.2096		1.9624	1.8299	2.1338	1.6956
17	.2429	.2477		2.0957	1.7652	1.7909	1.848
18		.362		1.7147	1.5061	1.7147	1.5242
19	.3239	.4763	.4763	.4763	.4694	.4191	.4763
20	.3077	.381	.362	.4763	.3521	.4382	.3429
21	.2515	.3048	.381	.3429	.2753	.381	.4001
22	.2105	.3048	.3429	.3048	.2591	.3239	
23	.218	.3048	.2858	.2667	.2105	.3048	.362
24	.7621	.6371	.7049	.3239	.4001	.2429	.2667
Max	1.8099	1.5424	1.7909	2.0957	1.8623	2.1529	2.0195
Min	.1296	.1905	.1905	.2667	.0381	.2105	.2667
Avg	.6758	.5829	.7340	.8653	.7269	.8580	.8437

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134055 / SHEVGA

Feeder No / Name : 204 / DATA AGRO EXPRESS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0335	.0381	.0381	.0572	.0486	.0572
2	.0572	.0335	.0381	.0572	.0572	.0324	.0572
3	.0572	.0486	.0381	.0572	.0572	.0486	.0572
4	.0572	.0486	.0381	.0572	.0572	.0503	.0572
5	.0572	.0335	.0381	.0572	.0572	.0335	.0381
6	.0381	.0486	.0381	.0381	.0572	.0503	.0572
7	.0381	.0486	.0381	.0381	.0762	.0486	.0572
8	.0572	.0486	.0381	.0381	.0381	.0625	
9	.0381	.0486	.0381	.0381	.0381	.0381	.0572
10	.0572	.0572	.0381	.0381	.0381	.0381	.0572
11	.0503	.0572	.0381	.0381	.0324	.0381	.0572
12	.0486	.0381	.0381	.0572	.0335	.0381	.0572
13	.0486	.0381	.0381	.0572	.0324	.0381	.0572
14	.0324	.0381	.0381	.0572	.0324	.0572	.0572
15	.0648	.0572	.0381	.0572	.0324		.0572
16	.0324	.0572		.0572	.0486	.0572	.0572
17	.0486	.0572		.0572	.0486	.0381	.0572
18	.0486	.0381		.0572	.0486	.0572	.0572
19	.0335	.0381	.0381	.0572	.0486	.0572	.0381
20	.0335	.0381	.0381	.0572	.0486	.0572	.0572
21	.0324	.0381	.0381	.0381	.0503	.0572	.0572
22	.0324	.0381	.0381	.0381	.0324	.0572	.0572
23	.0335	.0381	.0381	.0381	.0486	.0572	.0572
24	.0572	.0335	.0381	.0381	.0381	.0486	.0572
Max	.0648	.0572	.0381	.0572	.0762	.0625	.0572
Min	.0324	.0335	.0381	.0381	.0324	.0324	.0381
Avg	.0463	.0439	.0381	.0484	.0462	.0482	.0555

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134072 / KARJAT

Feeder No / Name : 201 / 11 KV KARJAT-BHAYGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.5716	.6097	.9031	1.1431	1.1431	1.1431
2	.6097	.5716	.6097	.8383	1.0479	1.1431	1.1431
3	.6097	.5716	.6668	.9374	1.1431	1.2384	1.2384
4	.6668	.5716	.7621	.884	1.2384	1.4289	1.2955
5	.8573	.6668	.8573	1.1431	1.3336	2.0005	1.4289
6	1.3336	.7621	1.0479	1.6432	1.5242	2.3815	1.9052
7	1.3717		1.2384	1.7861	2.0957	2.572	2.0957
8	1.1431	.6668	1.1431	1.8576	.6668	2.7625	2.0005
9	.7621	.5716	.9907	1.7833	2.2862	2.6673	2.5149
10	.5716	.4763	.7621	.5716	.6097	.5716	.5716
11	1.9052	1.4289	1.813	.5716	.5716	.5716	.4191
12	2.6673	2.191	1.9319	.5716	.4763	.5716	.4191
13	2.4768	2.6673	1.9052	.5716	.4191	.5335	.4763
14	2.2862	2.4768	1.813	.6097	.381	.5716	.4763
15	2.572	2.572	1.8061	.5716	.381	.4763	.4763
16	2.2862	2.572	1.8138	.4763	.4191	.5335	.5716
17	1.9052	2.4768	1.8023	.4763	.4763	.5716	.6668
18	2.191	2.4768	1.8623	.5716	.6668	.5716	.7621
19	.5716	.7621	.4763	.6097	.8573	.7621	.8573
20	.5716	.8573	.724	.5716	.7621	.5335	.8573
21	.5716	.7621	.6668	.5716	.7621	.5716	.8573
22	.5716	.6668	.5716	.5716	.6668	.4763	.724
23	.6668	.6097	.5716	.4191	.5716	.5716	.5716
24	.6097		.6097	.8916	.8192	.9526	.9526
Max	2.6673	2.6673	1.9319	1.8576	2.2862	2.7625	2.5149
Min	.5716	.4763	.4763	.4191	.381	.4763	.4191
Avg	1.2662	1.2704	1.1273	.8501	.8883	1.0907	1.0177

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134072 / KARJAT

Feeder No / Name : 202 / 11 KV KARJAT-A

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3763	.5716	.4763				
2	.3906	.4763	.4763				
3	.4458	.5716	.4763				
4	.5201	.6668	.5716				
5	.602	.7621	.6668				
6	.6687	.8573	.7621				
7	.743	.9526	.8573				
8	.6687	.9526	.8573			2.7625	
9	.5944	.9526	.7621				
11				.9526	.5716	.5716	.5268
12				.7621	.7621	.7621	.5182
13				.9526	.8573	.5716	.4687
14				.7621	.8002		.4877
15				.8573	.7621	.5716	.4877
16				.7621	.7621	.5716	.4687
17				.9526	.724	.6668	.5256
18				.5716	.6668	.5716	.4858
20	.381						
24	.381	.4763	.4763				
Max	.743	.9526	.8573	.9526	.8573	2.7625	.5268
Min	.3763	.4763	.4763	.5716	.5716	.5716	.4687
Avg	.5247	.7240	.6382	.8216	.7383	.8812	.4962

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134072 / KARJAT

Feeder No / Name : 203 / 11 KV DHANGAR PIMPALGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5944	.724	.5716	.3429	.362	.3429	.2858
2	.5719	.7621	.5716	.3429	.2858	.3429	.381
3	.5719	.8573	.6668	.381	.2858	.3429	.362
4	.6241	.8573	.7621	.4191	.2858	.381	.4191
5	.7727	1.3336	.9526	.5335	.381	.4763	.381
6	.8173	.7621	1.0479	.6668	.5716	.5716	.381
7	.8173	1.1431	1.0479	.6859	.5716	.6668	.6478
8	.743	1.4289	1.2384	.6668	.4763	.5716	.5716
9	.8097	.9526	1.105	.5716		.4763	.3429
10	.381	.381	.381	.381	.1905	.381	.2858
11	.381	.2858	.2286	.381	.8002	.8573	.6478
12	.5716	.2858	.1905	.5716	1.0479	.8573	.8592
13	.381	.1905		.9526	1.2384	.9526	.9332
14	.5716	.1905	.1905	1.0098	1.1812	.724	1.0513
15	.4763	.1905	.2286		1.105	.6668	.9717
16	.5716	.2286	.2286	.7621	1.0479	.6668	.9503
17	.5716	.2858	.2858	.7621	1.0479	1.0479	.9393
18	.381	.381	.3429		.9526		1.004
19	.381	.5335	.4763	.5716	.4763	.6668	.4763
20	.4191	.5716	.4763	.4954	.4763	.381	.5716
21	.381	.5335	.5335	.381	.4191	.2286	.5335
22	.381	.4763	.381	.2858	.381	.2858	.5335
23	.381	.381	.381	.2286	.381	.2286	.381
24	.5944	.381	.5716	.3429	.3239	.381	.381
Max	.8173	1.4289	1.2384	1.0098	1.2384	1.0479	1.0513
Min	.381	.1905	.1905	.2286	.1905	.2286	.2858
Avg	.5478	.5882	.5591	.5335	.6213	.5434	.5955

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134074 / Chandanapuri

Feeder No / Name : 201 / CHANDANAPURI GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.5415	.6535	.2614	.2614	.2801	.3734
2	.3361	.6161	.6348	.2614	.2614	.3547	.4481
3	.4108	.6348	.6722	.3361	.3361	.4481	.5041
4	.5228	.6722	.6535	.4481	.4108	.5228	.5601
5	.6722	.7095	.7468	.5975	.6348	.6161	.6348
6	.7468	.7468	.8215	.8029	.7842	.8589	.6908
7	.8775	.8029	.8589	.9709	.8589	.8962	.8402
8	.9335	.8962	.8962	.8962	.8402	.7282	.8775
9	.7282	.7842	.9335	.8962	.7842	.6348	.9335
10	.5975	.7095	.7282	.6535	.6161	.5601	.6535
11	.3734	.2987		.4108	.3921	.4108	.3547
12	.2427		.2241	.2801	.2614	.2801	.2614
13	.1867	.2241	.1867	.2241	.2241	.2241	.2241
14	.2987	.2614	.1867	.1867	.1867	.1867	.1867
15	.3547	.2987	.1867	.2241	.2614	.2427	.2241
16		.3174	.2241	.2801	.3734	.3547	.3734
17		.4294	.4481	.4108	.6348	.6908	.6908
18	.7655	.6908	.7282	.7468	.7842	.7468	.7468
19	.7842	.7282	.7655	.7468	.7282	.8402	.8215
20	.6908	.6348	.6348	.4854	.6722	.7282	.7282
21	.6348	.5228	.4108	.3734	.5601	.6348	.6908
22	.5601	.4854	.2987	.3361	.4108	.4854	.4481
23	.5041	.4481	.2987	.2987	.2987	.3361	.2987
24	.2241	.4481	.4294	.2614	.2614	.2427	.2987
Max	.9335	.8962	.9335	.9709	.8589	.8962	.9335
Min	.1867	.2241	.1867	.1867	.1867	.1867	.1867
Avg	.5330	.5609	.5488	.4746	.4932	.5127	.536



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134074 / Chandanapuri

Feeder No / Name : 202 / BHAMBERI-AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.463
2							.5247
3							.5556
5							.6173
6							.6481
7							.6173
8							.6636
9							.8333
11			.7099	.7407	.6481	.8179	
12	.571		.8179	.9259		.9282	
13	.5401	.7407	.8951	.9259	.6636	.9259	
14	.5864	.8179	.9259	.9414	.7716	1.034	
15	.6173	.8951	.9259	.9568		.9259	
16		.8333	.9259	.9568	.6481	.8951	
17		.8796	.8642	.8951	.6173	.8333	
18	.679	.7562	.7716	.7716	.7099	.7562	
24							.4012
Max	.679	.8951	.9259	.9568	.7716	1.034	.8333
Min	.5401	.7407	.7099	.7407	.6173	.7562	.4012
Avg	.5988	.8205	.8546	.8893	.6764	.8896	.5916

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134074 / Chandanapuri

Feeder No / Name : 203 / CHURMAPURI-AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.5247
2							.5556
3							.6327
4							.571
5							.679
6							.6481
7							.7407
8							.7716
9							.8025
11	.7316	.9414	.9722	.9259		.7562	
12	.8951		1.0957	1.034	.4167	.9105	
13			1.1728	1.0494	.3704	.8333	
14		1.0031	1.2037	1.0648	.4854	.9259	
15		1.0648	1.2037	1.0648	.8333	.9568	
16		1.0802	1.2037	1.0185	.9105	.8796	
17		1.1265	1.3443	1.0185	.8642	.8333	
18	.9105	1.0802	1.0648	.8796	.9414	.9259	
24							.463
Max	.9105	1.1265	1.3443	1.0648	.9414	.9568	.8025
Min	.7316	.9414	.9722	.8796	.3704	.7562	.463
Avg	.8457	1.0494	1.1576	1.0069	.6888	.8777	.6389

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134009 / GHANSAWANGI

Feeder No / Name : 201 / 11KV BOLEGAON FDR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5242	1.5432	1.5242	.4763	.5716	.5716	.5716
2	1.7147	1.5432	1.9052	.4763	.5716	.5716	.5716
3	1.9052	1.5432	1.9052	.381	.5716	.5716	.5716
4	1.9052	1.5432	1.9052	.381	.5716	.5716	.5716
5	2.0957	1.6289	1.9052	.5716	.5716	.7621	.5716
6	2.0957	1.7147	2.2862	.5716	.7621	.9526	.7621
7		2.2291	2.2862	.4763	.7621	.9526	.8573
8	2.8578	2.7435	2.6673	.2858	.9526	.7621	.8573
9	2.6673	2.572	2.4768	.2858	.8573	.7621	.7621
10	.7621	.7621	.7621	.381	.7621	.5716	.4763
11	.5716	.1905	.5716	2.2862	2.0576	2.2862	2.4768
12	.381	.1905	.381	3.0483	2.4006	2.4768	2.6673
13	.381	.1905	.2858	3.0483	2.2291	2.6673	2.2862
14	.381	.381	.1905	3.0483	2.2291	2.6673	1.9052
15	.381	.381	.1905	3.0483	2.3148	2.6673	1.9052
16	.381	.381	.1905	2.6673	2.4006	2.4768	1.9052
17	.5716	.381	.1905	2.6673	2.4006	2.4768	1.7147
18	.9526	.381	.5716	1.7147	2.0576	2.0957	1.7147
19	.9526	.7621	.7621	.9526	.9526	.7621	.5716
20	.7621	.7621	.7621	.7621	.7621	.7621	.9526
21	.7621	.6668	.5716	.6668	.6668	.6668	.9526
22	.5716	.5716	.5716	.5716	.5716	.5716	.7621
23	.5716	.5716	.4763	.5716	.5716	.5716	.7621
24	1.5242	1.3717	1.1431	.381	.5716	.5716	.5716
Max	2.8578	2.7435	2.6673	3.0483	2.4006	2.6673	2.6673
Min	.381	.1905	.1905	.2858	.5716	.5716	.4763
Avg	1.1597	1.0419	1.1034	1.2384	1.2142	1.2821	1.1550

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134009 / GHANSAWANGI

Feeder No / Name : 202 / 11KV MCHINCHOLI FDR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0957	2.2291	2.2862	.7621	.7621	.7621	
2	2.4768	2.2291	2.2862	.7621	.7621	.9526	
3	2.2862	2.2291	2.2862	.7621	.7621	.9526	.9526
4	2.8578	2.2291	2.8578	1.1431	1.0479	.9526	1.2384
5	2.8578	2.3148	3.2388	1.3336	1.1431	1.1431	
6	3.4294	2.4006	3.4294				
7	3.8104	2.915	3.4294				
8	3.8104	3.2579	3.6199				
9	3.8104	3.2579	3.4294				
10	.9526	1.1431	1.2384	1.1431		2.8578	2.6673
11	.7621	.7621	.9526	3.6199	2.4006	3.1436	2.8578
12		.6668	.7621	3.8104	2.572	3.1436	3.0483
13	.5716	.5716	.5716	3.8104	2.7435	3.1436	3.1436
14	.4763	.5716	.381		2.7435	3.0483	3.0483
15	.4763		.381		2.4006	2.4768	2.4768
16	.5716	.7621	.5716		2.572	2.4768	2.4768
17	.8573	.9526	.7621		2.4863	2.6673	2.4768
18	1.2384	1.2384	1.1431	1.1431	1.9719	2.4768	2.3815
19	1.2384	1.2384	1.1431	1.3336	1.9719	2.0957	2.2862
20	1.1431	1.2384	1.1431	1.1431	1.1431	1.2384	1.1431
21	.9526	.9526	1.0479	1.0479	.9526	1.0479	1.2384
22	.7621	.7621	.9526	.8573	.7621	.8573	.9526
23	.7621	.6668	.7621	.7621	.7621	.7621	.7621
24	1.9052	1.7147	2.191	.5716	.7621	.7621	
Max	3.8104	3.2579	3.6199	3.8104	2.7435	3.1436	3.1436
Min	.4763	.5716	.381	.5716	.7621	.7621	.7621
Avg	1.7437	1.5784	1.7028	1.5003	1.6169	1.8481	2.0719

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134009 / GHANSAWANGI

Feeder No / Name : 203 / 11KV GHANSAWANGI FDR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5716	.7621	1.3336	1.0479	1.3717	1.1431
2	.9526	.5716	.9526	1.5242	1.0479	1.3717	1.1431
3	1.1431	.5716	.9526	1.5242	1.0479	1.3717	1.2384
4	1.3336	.9526	1.1431	2.4768	1.0479	1.3717	1.3336
5	1.3336	1.2384	1.2384	2.8578	2.2862	1.5432	3.0483
6	1.3336	1.2384		2.8578	2.4768	1.8861	3.0483
7				2.8578	2.4768	2.4006	3.0483
8				3.0483	2.6673	2.915	3.3341
9				3.0483	2.8578	2.915	3.0483
10	1.3336	1.2384	1.2384	1.3336	1.3336	1.2384	1.1431
11	2.0576	2.3815	3.1436	1.0479	1.2384	1.2384	1.1431
12	2.572	2.4768	2.9531	.9526	1.1431	1.2384	.9526
13	2.572	2.572	2.9531	1.0479	.9526	1.2384	1.0479
14	2.4006	2.4768	2.9531	1.0479	.9526	1.2384	1.1431
15	2.3148	2.4768	2.8578	.9526	.9526	1.2384	1.1431
16	2.4006	2.572	2.8578	.9526	.9526	1.2384	1.1431
17	2.4863	2.2862	2.6673	1.1431	1.1431	1.1431	1.1431
18	2.4006	2.0957	2.6673	1.2384	1.2384	1.1431	1.2384
19	1.2384	1.2384	1.3336	1.3336	1.3336	1.2384	1.2384
20	1.2384	1.2384	1.3336	1.2384	1.2384	1.2384	1.2384
21	.7621	1.1431	1.2384	1.1431	1.1431	1.1431	1.2384
22	.5716	1.1431	1.2384	1.1431	.9526	1.1431	.9526
23	.5716	.9526	.9526	1.0479	.9526	.9526	.9526
24	.9526	.5716	.7621	1.3336	1.0479	1.2003	.9526
Max	2.572	2.572	3.1436	3.0483	2.8578	2.915	3.3341
Min	.5716	.5716	.7621	.9526	.9526	.9526	.9526
Avg	1.5985	1.5242	1.8100	1.6035	1.3972	1.4591	1.544

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134009 / GHANSAWANGI

Feeder No / Name : 204 / 11KV TANUWADI FDR  
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381	.4763	.7621	1.1431	1.0288	.9526
2	.381	.381	.4763	1.3336	1.1431	1.0288	1.1431
3	.381	.381	.4763	1.3336	1.3336	1.0288	1.1431
4	.5716	.5716	.5716	1.3336	1.3336	1.0288	1.3336
5	.5716	.7621	.5716	1.9052	1.3336	1.2003	1.7147
6	.7621	.7621	.5716	1.9052	1.9052	1.3717	1.9052
7	.7621	.9526	.5716	1.9052	2.0957	1.7147	
8	.5716	.7621	.9526	1.9052	2.0957	1.8861	1.9052
9	.5716	.7621	.9526	1.9052	2.2862	1.8861	1.9052
10	.5716	.5716	.8573	.7621	.6668	.5716	.7621
11	1.7147	2.2862	2.2862	.5716	.381	.5716	.5716
12	1.7147	2.2862	2.2862	.381	.381	.5716	.5716
13	2.0576	2.2862	2.4768	.4763		.381	.5716
14	2.2291	2.8578	2.6673	.381		.381	.381
15	2.2291	2.8578	2.7625	.381	.381	.381	.381
16	2.2291	2.7625	2.6673	.381	.381	.4763	.381
17	2.1434	2.3815	2.4768	.4763	.5716	.4763	.5716
18	1.8861	2.3815	2.0957	.7621	.7621	.8573	.5716
19	.7621	.7621	.7621	.8573	.7621	.7621	.5716
20	.7621	.7621	.7621	.7621	.5716	.7621	.5716
21	.5716	.6668	.5716	.7621	.381	.5716	.5716
22	.381	.5716	.5716	.5716	.381	.5716	.381
23	.381	.5716	.4763	.5716	.381	.5716	.381
24	.381	.381	.381	.5716	1.0479		.7621
Max	2.2291	2.8578	2.7625	1.9052	2.2862	1.8861	1.9052
Min	.381	.381	.381	.381	.381	.381	.381
Avg	1.0403	1.2543	1.2384	.9566	.9872	.8731	.8698

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134009 / GHANSAWANGI

Feeder No / Name : 205 / 11 KV BOLEGAON 2

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381	.2858	.7621	.9526	.7716	.9526
2	.381	.381	.381	.9526	1.0479	.8573	.9526
3	.381	.381	.381	.9526	1.0479	.8573	1.0479
4	.5716	.5716	.381	.9526	1.0479	.8573	1.1431
5	.5716	.7621	.5716	1.3336	1.3336	1.0288	1.9052
6	.5716	.9526	.7621	1.3336	1.5242	1.2003	1.9052
7	.9526	.9526	.9526	1.5242	1.5242	1.3717	1.9052
8	1.1431	.9526	1.1431	1.6194	1.5242	1.6289	1.9052
9	.7621	.9526	1.1431	1.4289	1.6194	1.6289	1.9052
10	.5716	.7621	.9526	.4763	.6668	.7621	.5716
11	1.4575	1.4289	1.5242	.2858	.381	.381	.381
12	1.5432	1.5242	1.7147	.1905	.2858	.1905	.381
13	1.5432	1.6194	1.8099	.1905	.2858	.1905	.2858
14	1.5432	1.6194	1.7147	.1905	.2858	.1905	.2858
15	1.5432	1.6194	1.6194	.1905	.2858	.1905	.2858
16	1.5432	1.7147	1.7147	.2858	.2858	.2858	.381
17	1.4575	1.6194	1.5242	.4763	.5716	.381	.5716
18	1.3717	1.6194	1.5242	.8573	.9526	.8573	.5716
19	.9526	.6668	.7621	.8573	.9526	.9526	.7621
20	.4763	.6668	.5716	.5716	.5716	.7621	.9526
21	.4763	.381	.2858	.381	.381	.4763	.7621
22	.381	.2858	.2858	.2858	.2858	.2858	.5716
23	.381	.2858	.2858	.2858	.2858	.2858	.381
24	.381	.381	.2858	.381	.9526	.6859	.7621
Max	1.5432	1.7147	1.8099	1.6194	1.6194	1.6289	1.9052
Min	.381	.2858	.2858	.1905	.2858	.1905	.2858
Avg	.8891	.9367	.9407	.6986	.7938	.7117	.8970

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134013 / RUGAON

Feeder No / Name : 201 / 11KV R.U.GAON-AG FDR SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144		.3982	.8573	.6859	.6859	1.4003
2	.5144		.3547	.8573	.8573	.8573	1.4563
3	.5144		.3921	.8573	.8573	.8573	1.363
4	.5144			.8573	.8573	.8573	1.587
5	.5144		.4481	1.0288	1.2003	1.2003	1.7375
6	.3429		.3801	1.0288	1.3717	1.7147	1.8461
7				1.2003	1.5432	1.8861	
8				1.3717	2.0576	2.0576	
9				1.5432	2.0576	1.9605	1.9547
11	2.572	2.0538	2.572				
12	3.0864	2.838	2.915				
13	3.0864	3.0807	2.915				
14	2.915		2.7435				
15	3.0864	3.2674	2.915				
16	3.2579	3.1927					
17	3.0864	3.3234					
18	3.0864	3.2487					
19						.3881	
20		.3921		.4287	.3429	.3982	.3921
21		.4108		.5144	.5144		
22		.3734		.6001	.5144	.4294	.3921
23				.5144	.5144	.4294	.3734
24	.5144		.3734	.8573	.5144	.5144	1.4937
Max	3.2579	3.3234	2.915	1.5432	2.0576	2.0576	1.9547
Min	.3429	.3734	.3547	.4287	.3429	.3881	.3734
Avg	1.8404	2.2181	1.4916	.8941	.9921	1.0169	1.2724



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134013 / RUGAON

Feeder No / Name : 202 / 11KV PANEWADI-AG FDR  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	22-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.5228				
2	.6001					
3	.6001	.5611				
4	.6859	.5975				
5	.6859					
6	.6859	.6335				
7	.7716	.6335				
8	.7716	.6722				
9	.7716	.6908				
10	.7716					
11			.6859	.6859	.7655	.7655
12				1.0288	.8402	.7842
13				1.0288	.8688	.8029
14				1.0288	1.0082	.9335
15			1.0288	1.0288	.905	.9522
16			1.1145	.8573	.8145	.7842
17			1.0288	.8573	.724	.695
18			1.0288	.6001	.6535	.6335
19			.5144			
20			.3772			
24	.6001	.5415				
Max	.7716	.6908	1.1145	1.0288	1.0082	.9522
Min	.6001	.5228	.3772	.6001	.6535	.6335
Avg	.6859	.6066	.8255	.8895	.8225	.7939

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134013 / RUGAON

Feeder No / Name : 203 / 11KVTALEGOAN-AG FDR  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429		.362	1.0288	.6859		1.7737
2	.3429			1.0288	1.0288		1.7126
3	.3429		.3801	1.0288	1.2003		1.9605
4	.3429		.4108	1.2003	1.3717		
5	.3429			1.3717	1.3717		2.1472
6	.3429		.4294	1.7147	1.7147		2.19
7				1.8861	2.0576		2.3339
8				2.0576	2.6578	2.2291	
9				2.0576	2.4006		2.2779
11	2.7435	2.95	2.572				
12	3.2579	3.0807	2.7435				.8402
13	3.2579	3.2487	2.7435				
14	3.0864	3.3048	2.8292				
15	3.0864	3.1367	2.915				
16	3.0864						
17	2.915	3.2487					
18	2.915	3.1927					
19						.3921	
20		.3921		.6001	.5144		.4108
21		.4294		.5144	.6859	.4294	
22				.5144	.6859	.3734	
23		.3921		.5144	.7716	.3921	
24	.4287		.3921	.6859	.5144		1.8298
Max	3.2579	3.3048	2.915	2.0576	2.6578	2.2291	2.3339
Min	.3429	.3921	.362	.5144	.5144	.3734	.4108
Avg	1.7890	2.3376	1.5778	1.1574	1.2615	.7632	1.7477

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134013 / RUGAON

Feeder No / Name : 204 / 11KV SHINDEWADGAON-AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859		1.8111	.3429	.2572	.2572	.3547
2	.8573			.3429	.2572	.2572	.3921
3	1.0288		1.7194	.3429	.2572	.2572	
4	1.0288			.3429	.3429	.2572	.3734
5	1.2003		1.9044	.3429	.3429	.3429	
6	1.2003			.3429	.3429	.3429	.3361
7	1.7147		1.8642				
8	1.8861		1.8461				
9	1.8861		1.9004				
11				1.8861	2.0576	1.8111	1.475
12				2.4006	2.1434	1.9605	1.531
13				2.4006	2.1434	2.0538	
14				2.4006	2.1434		1.8298
15				2.4006	2.0576		2.2405
16				2.0576	2.0576	1.9605	2.1472
17				2.0576	2.0576	1.9978	
18				1.8861	1.7147	2.0351	1.6827
20		.3921		.2572	.2572	.4108	.4294
21		.4108		.2572	.2572	.4481	.3921
22				.2572	.2572		.4294
23		.3547		.2572	.2572	.3801	.4108
24	.6859		1.8298	.3429	.2572	.2572	.3734
Max	1.8861	.4108	1.9044	2.4006	2.1434	2.0538	2.2405
Min	.6859	.3547	1.7194	.2572	.2572	.2572	.3361
Avg	1.2174	.3859	1.8393	1.1010	1.0243	.9394	.9598

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134013 / RUGAON

Feeder No / Name : 205 / RUGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429		.5228	.3429	.2572	.2572	.4481
2	.3429			.3429	.2572	.2572	.168
3	.4287		.5041	.3429	.2572	.2572	.5041
4	.4287			.4287	.3429	.2572	.5068
5	.5144		.4409	.5144	.4287	.3429	.5601
6	.6001		.5975	.6001	.5144	.6859	.7095
7	.6001		.6535	.7716	.6001	.7716	.7655
8	.6001			.6859	.5144		
9	.6001		.5792	.6859	.4287		.6535
10	.4287		.5144	.6859	.3429		
11	.3429	.2801	.4287	.5144			.4668
12	.3429	.2614	.3429	.3429		.0019	.3391
13	.2572	.3361	.3429	.3429	.2572		.3361
14	.2572		.3429	.3429	.2572	.2241	.3174
15	.3429		.4287	.3429	.2572	.2241	.3439
16	.4287	.2987		.3429	.2572	.3361	
17		.5228		.4287			.6535
18		.5788		.5144			
19		.6535		.3429	.6859	.4294	.6516
20		.5975		.4287	.5144	.4668	.6535
21		.5601		.3429	.5144		.5975
22				.2572	.4287	.5041	.5788
23		.4668		.2572	.3429	.4481	.5415
24	.3429		.5415	.3429	.2572	.2572	.4668
Max	.6001	.6535	.6535	.7716	.6859	.7716	.7655
Min	.2572	.2614	.3429	.2572	.2572	.0019	.168
Avg	.4236	.4556	.48	.4394	.3858	.3576	.5131

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134013 / RUGAON

Feeder No / Name : 206 / SHINDEWADGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857		.0934	.0857	.0857	.0857	.2054
2	.0857		.112	.0857	.0857	.0857	.1629
3	.0857			.0857	.0857	.0857	.1494
4	.0857		.0934	.1029	.0857	.0857	.1307
5	.1715			.1715	.0857	.0857	.168
6	.2229		.0747	.2058	.1715	.1715	.1867
7	.1715		.112	.2572	.1715	.1715	
8	.1715		.1494	.2572		.1715	.2241
9	.1715		.1696	.2058	.1715		.2054
10	.1715		.1715	.1715	.0857		.1463
11	.1372	.1307	.1372	.0857	.0857	.2241	.168
12	.1029	.168	.0857	.0514	.0343	.1867	.181
13	.1029	.0934	.0857	.0514	.0343		
14	.0857	.1006	.0857	.0514	.0343		.0934
15	.12			.0514	.0343	.1494	.0934
16	.1372			.0857	.0343	.1448	
17	.2058			.0857	.0857	.112	.1629
18	.2572	.168		.1715	.1715		.1494
19		.1307		.2572	.1715	.1646	
20		.1494		.1715	.1715	.1867	.2241
21		.1307		.0857	.1715	.1865	
22				.0857	.0857	.1867	
23		.0934		.0857	.0857		.1494
24	.0857		.0848	.0857	.0857	.0857	.2054
Max	.2572	.168	.1715	.2572	.1715	.2241	.2241
Min	.0857	.0934	.0747	.0514	.0343	.0857	.0934
Avg	.1399	.1294	.1119	.1264	.1006	.1428	.1670

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134013 / RUGAON

Feeder No / Name : 208 / PANEWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572			.3429	.2572	.2572	.3174
2	.2572		.3361	.2572	.2572	.2572	.3547
3	.3429		.3734	.2572	.2572	.2572	.3174
4	.3429		.3174	.3086	.3429	.3429	.2987
5	.5144		.3439	.3429	.4287	.4287	.3361
6	.5144		.5415	.4287	.5144	.5144	
7	.5144			.5144	.6001	.6001	.5041
8			.4668	.5144	.5144	.5144	.4668
9			.4706	.5144	.5144		.4854
10			.2572	.5144	.4287		
11			.2572	.4287	.3429	.2801	
12			.1715	.2572		.2614	.168
13		.168	.1715	.1715			.2054
14	.1715	.1867	.1715	.1715	.2572	.2054	.2241
15	.1715		.2058	.1715	.2572	.2614	.3174
16	.1715	.2427		.1715	.2572		.2987
17	.3429	.3361		.3429	.3429	.3734	.3921
18	.4287			.5144	.5144		
19		.3734		.5144	.6001	.4668	.4668
20		.3361		.3429	.6001	.4668	.3547
21				.3429	.5144	.4294	.4481
22		.2987		.2572	.3429	.3921	.3547
23		.2801		.2572	.2572	.3547	.3734
24	.2058		.3174	.3429	.2572	.2572	.3361
Max	.5144	.3734	.5415	.5144	.6001	.6001	.5041
Min	.1715	.168	.1715	.1715	.2572	.2054	.168
Avg	.3258	.2777	.3144	.3451	.3936	.3643	.3510

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134013 / RUGAON

Feeder No / Name : 209 / 11KV EXPRESS FEEDER UTTARA NON SHEDDABLE EXPRESS HV FEEDERS  
 FOO Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171			.0343	.0171	.0171	.0187
2	.0171		.017	.0343	.0171	.0171	
3	.0171		.0373	.0343	.0171	.0171	.0187
4	.0171		.0187	.0343	.0171	.0171	.0181
5	.0171		.0187	.0343	.0171	.0171	
6	.0171		.0187	.0343	.0171	.0171	.0187
7	.0171		.0181	.0343	.0171	.0171	.0187
8	.0171			.0343	.0171	.0171	
9	.0171		.0187	.0343	.0171		.0373
10			.0171	.0171	.0171	.0187	
11	.0343	.0187	.0343	.0171	.0171		
12	.0343		.0343	.0171	.0343		.0373
13		.0339	.0343	.0171	.0343		.0373
14	.0343	.0187	.0343	.0171	.0171		
15	.0343	.0187	.0343	.0171	.0171		
16	.0343			.0343	.0171		.0187
17	.0343	.0187		.0171	.0171		.0373
18	.0343	.0187		.0343	.0171		.0187
19				.0343	.0171		.0362
20		.0187		.0171	.0171		.0362
21		.0187		.0171	.0171		.0373
22				.0171	.0171		.0187
23		.0187		.0171	.0171		.0187
24	.0171		.0187	.0343	.0171	.0171	.0187
Max	.0343	.0339	.0373	.0343	.0343	.0187	.0373
Min	.0171	.0187	.017	.0171	.0171	.0171	.0181
Avg	.0242	.0204	.0253	.0264	.0185	.0173	.0262

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134027 / TIRTHPURI

Feeder No / Name : 202 / 11KV KANDARI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6			2.4006	2.7054	2.6292	2.572	2.8578
7			2.572	2.7816	2.8006	2.572	2.8769
8			2.6578	2.8959	2.9721	2.4863	2.9531
9			2.7435	2.9531	3.0483	2.572	3.0864
15	3.2388	3.0864					
16	3.3341	3.0864					
17	3.2388	3.0864					
18	3.0483	2.8292					
Max	3.3341	3.0864	2.7435	2.9531	3.0483	2.572	3.0864
Min	3.0483	2.8292	2.4006	2.7054	2.6292	2.4863	2.8578
Avg	3.215	3.0221	2.5935	2.834	2.8626	2.5506	2.9436



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134027 / TIRTHPURI

Feeder No / Name : 203 / BHAIGAVHAN-AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2							.1143
6	.9526	2.572					
7	2.2862	2.9531					
8	2.9531	2.9531					
9	2.6673	2.9531					
11			3.5246	3.677	3.0007	3.4294	2.8578
12			3.6008	3.7913		3.4294	2.8578
13			3.5818	3.8866		3.4294	2.9531
14			3.5056	3.8295		3.4294	2.8578
15						3.4294	
Max	2.9531	2.9531	3.6008	3.8866	3.0007	3.4294	2.9531
Min	.9526	2.572	3.5056	3.677	3.0007	3.4294	.1143
Avg	2.2148	2.8578	3.5532	3.7961	3.0007	3.4294	2.3282

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134056 / DEODI HADGAON

Feeder No / Name : 201 / 11KV Deodi Hadgaon SP FDR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.5716	.9145	.5228	.5716	.5716	.4108
2	1.1431	1.3336	1.1763	.5121	.5716	.5716	.3696
3	1.307	1.3336	1.2136	.4854	.5716	.5716	.3658
4	1.1869	1.3336	.9335	.4755	.5716	.5716	.4481
5	1.3565	1.5242	1.1949	.5601	.7621	.7621	.5228
6	1.3565	1.5242	1.1576	.6722	.7621	.7621	.5853
7	1.5261	1.5242	1.1203	.7023	.7621	.7621	.6584
8	1.5261	1.4937	1.1949	.5975	.7621	.7621	
9	1.6461	1.3565		.5975	.7621	1.3336	.6722
10	.1905	.381	.1829	1.3717	.9526	1.3336	.8139
11	.1905	.2858	.1829	1.5261	1.1203	1.2574	1.0059
12	.1905	.1829	.1524	1.7147	1.1317	.8139	1.3817
13	.1905	.1463	.1524	1.6461	1.1431	.9724	
14	.1905	.1829	.1524	1.4632	1.1431	1.3413	
15	.1905	.1829	.1524	1.307	1.1431	1.3077	
16	.1905	.1463	.1905	1.307	1.4632	1.3413	1.4937
17	.381	.1829	.2286	1.3336	1.4937		1.5684
18	.7621	.7316	.724		.7621	.5228	.4024
19	.6668	.7682	.8413	.9526	.7621	.6219	.439
20	.6668	.7316	.8413	.9526	.7621	.5121	.4755
21	.5716	.8779	.8215	.7621	.7621	.3734	.5121
22	.5716	.8596	.7468	.5716	.7621	.4108	.5487
23	.5716	.7316	.5601	.5716	.7621	.4108	.6219
24		.5716	.7682	.5601	.5716	.5716	.415
Max	1.6461	1.5242	1.2136	1.7147	1.4937	1.3413	1.5684
Min	.1905	.1463	.1524	.4755	.5716	.3734	.3658
Avg	.7454	.7899	.6784	.9202	.8680	.8026	.6856

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134056 / DEODI HADGAON

Feeder No / Name : 202 / 11KV Dhakefal SP FDR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1829	.4191	1.1431	.1905	1.2003
2	.1905	.1905	.2195	.4191	.1905	.2858	.4572
3	.1905	.1905	.2195	.4191	.1905		.4572
4	.1905	.1905	.2561	.4572	.1905	.381	.4954
5	.1905	.1905	.2195	.724	.1905	.381	.5716
6	.1905	.1905	.2561	1.0288	.1905	.381	1.0288
7	.2858	.1905	.2743	1.0669	.1905		
8	.2858	.2858	.3658	.8383	.1905	.381	1.0669
9	.1905	.2858	.439	.8002	.1905	.2858	.7621
10	1.6956	1.9052	1.6804	.5716	.1905	.2858	
11	2.2862	2.2862	1.9418	.4572	.1905	.2858	.381
12	2.3777	2.4272	2.0119	.1905	.1905	.3048	.1829
13	2.3777	2.2405	2.1548		.1905	.2667	.1463
14	2.4272	2.0538	2.0119		.1905	.2667	.1463
15	2.3529	2.1285	2.0119		.1905	.2667	.128
16	2.2043	2.2405		.1905	.1905	.2667	.1463
17	2.0119	2.2405	1.6766	.2858	.2858	.2858	.2012
18	.2858	.3658	.6097		2.3777	2.1795	2.3152
19	.2858	.2561	.8383	1.3336	2.6139	1.8652	2.4272
20	.2858	.2743	.6859	1.3336	2.5606	1.6289	2.5766
21	.1905	.3292	.6478	1.3336	2.4272	1.5089	2.6139
22	.1905	.3658	.5335	1.1431	2.4272	1.3413	2.6513
23	.1905	.4024	.4572	1.1431	2.2405	1.3413	2.7633
24	.1905	.1905	.3658	.4572	1.1431	2.0538	1.2003
Max	2.4272	2.4272	2.1548	1.3336	2.6139	2.1795	2.7633
Min	.1905	.1905	.1829	.1905	.1905	.1905	.128
Avg	.8858	.9005	.8722	.7306	.8365	.747	1.0872

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134056 / DEODI HADGAON

Feeder No / Name : 203 / 11KV Avalgaon AG FDR  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	1.5242	1.307	1.1736		1.3336	
2	.9526	.9526	1.3443	1.0174	1.3336	1.3336	.7545
3	1.1431	.9526	1.4563	1.0288	1.5242	1.3336	.8192
4	1.1431	.9526	1.3443	1.0059	1.5261	1.5242	.9717
5		1.1431	1.4937	.9724	1.6804	1.4632	.9717
6	1.3336	1.1431	1.5684	.9945	1.8671	1.6975	1.2955
7	1.3336	1.3336	1.4937	1.1469	1.829	1.6975	1.2955
8	1.3336	1.3336	1.307	1.5927	2.0119	1.7918	1.6095
9	1.1431		1.3817	1.6385	2.0538	1.5089	1.6766
10				.8192	1.307	1.5089	1.1603
11				1.3413	1.3203	1.1469	1.3413
12				1.5242	1.3203	1.3413	1.307
13				1.4413		1.2146	1.3256
14				1.4937		1.2955	1.307
15					1.1431	1.3108	1.3443
16					1.6975	1.3108	1.4563
17				1.1431	1.6804	1.2955	1.307
18	2.2405	2.4272	2.0957				
19	2.2405	2.2592	1.7901				
20	2.2862	1.9791	1.1603				
21	2.0957	1.8671	1.3413				
22	1.9052	1.8298	1.3108				
23	1.7147	1.7177	1.4089				
24	1.6956	1.5242	1.6804	1.3413			
Max	2.2862	2.4272	2.0957	1.6385	2.0538	1.7918	1.6766
Min	.9526	.9526	1.1603	.8192	1.1431	1.1469	.7545
Avg	1.5676	1.5293	1.4677	1.2297	1.5925	1.4181	1.2464

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134066 / SADEGAON

Feeder No / Name : 201 / 11 KV SADEGAON AG FDR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6443				
2			.7865	.8059	.7373	.6516	.6173
3			.7865	.823	.7716	.7202	.6516
4			.852	.8059	.7888	.7202	.6516
5			.852	.8402	.823	.7888	.7202
6			.9503	.8916	.9774	.8916	.7545
7			.9175	.9602	1.046	.9259	.823
8			.9831	1.0631	1.2003	1.0802	.8745
9			1.0814	1.0117	1.2517	1.1488	.9088
11	1.4091	1.278					
12	1.4419						
13	1.4922	1.3735					
14	1.4419	1.278					
15	1.4413	1.278					
16	1.3108	1.2944					
17	1.3395	1.3108					
18	1.2289	1.1961					
Max	1.4922	1.3735	1.0814	1.0631	1.2517	1.1488	.9088
Min	1.2289	1.1961	.6443	.8059	.7373	.6516	.6173
Avg	1.3882	1.2870	.8726	.9002	.9495	.8659	.7502

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134066 / SADEGAON

Feeder No / Name : 202 / 11KV Sadegaon Gaothan

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.2949	.3277		.381	.2058	.2229
2	.3601	.3277	.3277		.4115	.2743	.3086
3	.4115	.407	.426		.5487	.3086	.3772
4	.4458	.4424	.4752		.6173	.4115	.4801
5	.5487	.503			.703	.5487	.5487
6	.6687	.6882			.7716	.6687	.6173
7	.7545	.7209			.8573	.9774	.7545
8	.7202	.7045			.8059	.823	.6173
9	.6344	.6062			.7373	.6344	.6173
10	.5144	.4588			.4115	.4115	.3932
11	.3605	.3605	.5316		.2229		
12			.4973		.2229	.3086	
13		.2622		.3353	.2058	.2915	.2622
14		.2294		.3658	.2058		
15	.2949	.2785		.3658	.2401	.2915	.1966
16	.426	.3441		.3506	.3429	.3086	.3113
17	.4578	.426	.583	.5487	.3944	.4115	.426
18	.5735	.5735	.703	.7202	.6687	.5487	.5079
19	.7373	.7537	.7716	.7716	.6001	.6344	.5765
20	.6554	.763	.5658	.583	.5144	.4801	.6226
21	.6554	.4752	.4801	.583	.3772	.3601	.3605
22	.426	.4588	.381	.5144	.3086	.2229	.2458
23	.3277	.3277	.3201	.463	.2743		.2458
24	.2915	.2785	.2949	.3048	.3963	.2401	.2058
Max	.7545	.763	.7716	.7716	.8573	.9774	.7545
Min	.2915	.2294	.2949	.3048	.2058	.2058	.1966
Avg	.5027	.4646	.4775	.4922	.4675	.4458	.4237

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134066 / SADEGAON

Feeder No / Name : 203 / 11KV Gangachincholi AG

FEEDER SEPERATION/PURE AG

FEEDER Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6226					
2	.6687	.6882					
3	.703	.7209					
4	.7545	.852					
5	.8916	.852					
6	.9602	.9175					
7	1.1145	1.0486					
8	1.1831	1.1633					
9	1.2003	1.1305					
11			1.3546	1.4746	1.5604	1.4575	1.4746
12			1.6461		1.7147	1.5432	1.7204
13			1.7833	1.6289	1.7147	1.6289	1.7368
14			1.6804	1.6975	1.6804	1.6289	
15			1.5261	1.6975	1.6289	1.6461	1.6385
16			1.7147	1.7318	1.5604	1.6632	1.5729
17			1.5604	1.7833	1.4232	1.4746	1.5729
18			1.5775	1.6118	1.3375	1.3717	1.5074
Max	1.2003	1.1633	1.7833	1.7833	1.7147	1.6632	1.7368
Min	.6687	.6226	1.3546	1.4746	1.3375	1.3717	1.4746
Avg	.9345	.8884	1.6054	1.6608	1.5775	1.5518	1.6034

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134066 / SADEGAON

Feeder No / Name : 204 / 11KV EXPRESS FDR Jogladevi NON SHEDDABLE EXPRESS HV FEEDERS  
Bar Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	24-DEC-17
HR	Load (MW)
17	1.2193
Max	1.2193
Min	1.2193
Avg	1.2193



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134068 / 33KV S/S SINDKHED

Feeder No / Name : 201 / Limboni Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4534	.2591				
2	.2915	.5182	.3239				
3	.2915	.6154	.3563				
4	.3239		.421				
5	.3239	.5992	.4858				
6	.3239	.7773	.5182				
7	.3239	.9717	.5506				
8	.9069	1.2955	.6154				
9	.8421	1.2955	.6478				
10							.1296
11				.7773	1.2955	.8421	.9717
12						.9717	1.2146
13					1.3765	.8097	
14				.9717	1.3927		1.2955
15				1.2955	1.2631		1.2955
16				1.2955	1.4251	1.0688	1.2146
17				1.2146	1.2631	1.1336	1.1336
18				.9717	.8907	1.1012	.4858
24		.3563	.1943				
Max	.9069	1.2955	.6478	1.2955	1.4251	1.1336	1.2955
Min	.2915	.3563	.1943	.7773	.8907	.8097	.1296
Avg	.4535	.7647	.4372	1.0877	1.2724	.9879	.9676

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134068 / 33KV S/S SINDKHED

Feeder No / Name : 202 / Sindkhed Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.8097	.1943	.1619	.2591
2				.8907	.2429	.1943	.3239
3					.2429	.2591	.3887
4					.2915	.3239	.4534
5					.3239	.421	.4858
6						.4858	.421
7						.583	.5506
8					.3239	.6802	.6154
9				.3239	.4049	.6802	.6154
11	1.587	1.5546	1.2955				
12	1.7814	1.9109	1.6194				
13		2.0243	1.7814				
14	2.2672		1.8623				
15	2.3644	1.9433	1.8623				
16	2.332		1.7814				
17	2.0405	1.5546	1.7004				
18	1.7166	1.6194	1.5384				
24				.6478	.1619	.1296	.2267
Max	2.3644	2.0243	1.8623	.8907	.4049	.6802	.6154
Min	1.587	1.5546	1.2955	.3239	.1619	.1296	.2267
Avg	2.0127	1.7679	1.6801	.6680	.2733	.3919	.434

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134069 / 33 kv Banegaon

Feeder No / Name : 201 / 11 kv Banegaon Ag  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	22-DEC-17	23-DEC-17
HR	Load (MW)	Load (MW)
11	.4801	
12	.6173	.5792
13	.6516	.6706
14	.7545	.7621
15	.7888	.7926
16	.7716	.7621
17	.8059	.7621
18	.7716	.7773
Max	.8059	.7926
Min	.4801	.5792
Avg	.7052	.7294

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134069 / 33 kv Banegaon

Feeder No / Name : 202 / 11 kv Bhogaon Ag

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	22-DEC-17	23-DEC-17
HR	Load (MW)	Load (MW)
1	.6173	.7545
2	.6516	.823
3	.7716	.8573
4	.7716	.8916
5	.9945	.9431
6	1.1317	.9602
7	1.166	.9945
8	1.166	.9945
9	1.1488	.9145
24	.583	.583
Max	1.166	.9945
Min	.583	.583
Avg	.9002	.8716

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134069 / 33 kv Banegaon

Feeder No / Name : 203 / 11 kv banegaon Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17
HR	Load (MW)	Load (MW)
1	.2058	.1715
2	.2058	.1715
3	.2401	.2401
4	.3772	.2915
5	.4115	.4801
6	.4973	.4973
7	.4801	.4973
8	.4801	.5316
9	.4458	.5487
11	.1715	
12	.1715	.3292
13	.1372	.2743
14	.2401	.2378
15	.2572	.2012
16	.2743	.2195
17	.3086	.2561
18	.3258	.439
19	.3258	.5487
20	.4115	.3658
21	.2401	.2926
22	.1372	.2561
23	.1029	
24	.2058	.1029
Max	.4973	.5487
Min	.1029	.1029
Avg	.2893	.3311

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134075 / 33 kv Bhutegaon

Feeder No / Name : 201 / 11 KV Bhutegaon AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3944	.4382	.4954			
2	.4287	.4191	.5335			
3	.4287	.4572	.5335			
4	.463	.4954	.5716			
5	.463	.5335	.6097			
6	.4801	.5716	.6668			
7	.4801	.7621	.724			
8	.5487	.743	.9145			
9	.6001	.7621	1.0098			
11				.8573	.7621	
12				1.1622	1.1431	.8573
13				1.2003	1.1241	1.0098
14				1.0669	1.105	.9907
15				.8954	.8573	.9907
16				1.1812	.8002	1.0098
17				.7811	1.0479	
18				.8002	.2667	
24	.3086	.381	.4191			
Max	.6001	.7621	1.0098	1.2003	1.1431	1.0098
Min	.3086	.381	.4191	.7811	.2667	.8573
Avg	.4595	.5563	.6478	.9931	.8883	.9717

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134075 / 33 kv Bhutegaon

Feeder No / Name : 202 / 11 kv Dai Anterwali ag  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2477	.381	.3048	.381
2				.2477	.381	.3048	.381
3				.2667	.4191	.3429	.381
4				.3048	.4572	.381	.381
5				.3429	.4954	.4382	.4191
6				.381	.5335	.5144	.4763
7				.4001	.5716	.5906	.5335
8				.4382	.7621	.6859	.724
9				.6859	.7811	.7049	.6478
11	.5906	.5716	.4954				
12	.724	.7811	.8192				
13	.7621	.8002	.9717				
14	.8573	.8192	1.0098				
15	.8954	.8383	.9526				
16	.743	.8573	.8002				
17	.7621	.8002	.7049				
18	.4191	.5716	.724				
24				.1905	.2858	.2858	.3429
Max	.8954	.8573	1.0098	.6859	.7811	.7049	.724
Min	.4191	.5716	.4954	.1905	.2858	.2858	.3429
Avg	.7192	.7549	.8097	.3506	.5068	.4553	.4668

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134075 / 33 kv Bhutegaon

Feeder No / Name : 203 / 11 kv Bhutegaon Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.4954	.4191	.4001	.4191	.381	.4001
2	.4458	.5335	.4382	.4191	.4382	.381	.4001
3	.5144	.5716	.4382	.4763	.5144	.4001	.4191
4	.6516	.6668	.4763	.6287	.6668	.4763	.7621
5	.823	.724	.724	.743	.7621	.6287	.8573
6	.9602	.9526	.7621	.7621	.8573	.7049	1.0098
7	.9259	1.0479	.7811	.8002	.9907	.8764	.9717
8	1.0631	.9907	.8764	.8192	.9526	.8954	
9	.9259	.8764	.8573	.9526	.9526	.8192	.8383
10	.6668	.724	.6668	.6668	.7621		
11	.5335		.5335	.4763	.4954		
12	.4001	.4191	.381	.362	.4191	.4001	
13	.3429	.3048	.3048	.2477	.3429	.3429	
14	.3239	.4001	.3048	.3239	.2858	.3048	
15	.381	.4191	.362	.3429	.3429	.3048	
16	.381	.4572	.362	.381	.4001	.3429	
17	.5335	.5716	.5144	.5335	.5144	.4572	
18	.8573	.8764	.7811	.8192		.7621	
19	.8764	.8573	.743	.9526	.9145	1.0098	
20	.6478	.8002	.6668	.6668	.6859	.7621	
21	.4954	.6668	.5716	.5716	.5144	.5335	
22	.4954	.5716	.4572	.4763	.4191	.4763	
23	.4572	.4191	.4001	.4382	.4001	.4191	
24	.4115	.4763	.4191	.4191	.4191	.381	.4001
Max	1.0631	1.0479	.8764	.9526	.9907	1.0098	1.0098
Min	.3239	.3048	.3048	.2477	.2858	.3048	.4001
Avg	.6052	.6445	.5517	.5700	.5856	.5482	.6732



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134085 / ANTERWALI TEMBHI

Feeder No / Name : 201 / 11KV ANTARWALI -T AG FDR FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.6289	1.6975	1.5844	1.0185
2				1.6289	1.7833	1.6032	1.6975
3				1.7147	1.869	1.6975	1.7541
4				1.8004	1.9547	1.7918	1.7541
5				1.8861	2.1262	2.1691	1.8673
6				1.9719	2.2119	2.32	2.0559
7				2.0748		2.3011	2.0748
8				2.1434	2.452	2.5086	2.5274
9				2.1948	.4287	2.4897	2.4897
11		2.6673	2.7054				
12	2.8959		2.7435				
13	3.1436		2.8121				
14	3.1626	3.5437	2.8464				
15	3.0864	3.677	2.8807				
16	3.1245	3.2769	2.8978				
17	3.0483	3.2388	2.9321				
18		3.1245	2.4348				
24				1.6632			1.0185
Max	3.1626	3.677	2.9321	2.1948	2.452	2.5086	2.5274
Min	2.8959	2.6673	2.4348	1.6289	.4287	1.5844	1.0185
Avg	3.0769	3.2547	2.7816	1.8707	1.8154	2.0517	1.8258

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134085 / ANTERWALI TEMBHI

Feeder No / Name : 202 / 11KV MANGRUL AG FDR  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	25-DEC-17	26-DEC-17
HR	Load (MW)	Load (MW)
11	.6859	1.0288
12	.9774	1.3717
13	1.1317	
15	1.2003	
16	1.286	
17	1.3546	
18	1.2003	
Max	1.3546	1.3717
Min	.6859	1.0288
Avg	1.1195	1.2003

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134085 / ANTERWALI TEMBHI

Feeder No / Name : 204 / 11KV EXPRESS FDR MANGRUL NON SHEDDABLE EXPRESS HV FEEDERS  
 BARRA Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0191	.0191	.0171	.0191	.0189	.0189
2		.0191	.0191	.0171	.0171	.0189	.0189
3		.0191	.0191	.0171	.0171	.0189	.0189
4		.0191	.0191	.0171	.0171	.0189	.0189
5		.0191	.0191	.0171	.0171	.0189	.0189
6		.0191	.0191	.0171	.0191	.0189	.0189
7		.0191	.0191	.0171	.0191	.0189	.0189
8		.0191	.0191	.0171	.0171	.0189	.0189
9		.0191	.0191	.0171		.0189	.0189
10		.0191		.0171		.0189	
11		.0191	.0191	.0171	.0171	.0189	
12	.0191		.0171	.0171	.0171	.0189	
13			.0171	.0171	.0189	.0189	
14	.0191	.0191	.0171	.1372	.0189	.0189	
15	.0191	.0191	.0171	.1372	.0189		
16	.0191	.0191	.0171	.0171	.0189	.0189	
17	.0191	.0191	.0171	.0171	.0189	.0189	
18	.0191	.0191	.0171	.0171	.0189	.0189	
19	.0191	.0191	.0171	.0171	.0189	.0189	
20	.0191	.0191	.0171	.0171	.0189	.0189	
21	.0191	.0191	.0171	.0171	.0189	.0189	
22	.0191	.0191	.0171	.0171	.0189	.0189	
23	.0191	.0191	.0171	.0171	.0189	.0189	
24		.0191	.0191	.0171	.0171	.0189	.0189
Max	.0191	.0191	.0191	.1372	.0191	.0189	.0189
Min	.0191	.0191	.0171	.0171	.0171	.0189	.0189
Avg	.0191	.0191	.0181	.0271	.0183	.0189	.0189

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134085 / ANTERWALI TEMBHI

Feeder No / Name : 205 / 11KV Antarwali-T Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5906	.5144	.4801	.4973	.4527	.4715
2		.6287	.5525	.5144	.6001	.3772	.4715
3		.724	.6097	.6001	.6859	.3961	.4904
4		.9717	.7811		.8573	.415	.6036
5		1.3336	1.0288	.6859	1.0288	.7733	.8488
6		1.4861	1.4098	.8573	1.1145	1.2637	1.358
7		1.5813	1.5623	.9431	1.2003	1.358	1.6975
8		1.5432	1.4861	1.3032	1.3203	1.1506	1.5844
9		1.467	1.4098	1.2003	1.1145	.9242	1.4523
10		1.0288	1.0288		.9945	.7167	
11		.6668	.8764	.583	.5144	.6036	
12	.743		.6859	.583	.463	.5281	
13	.6097		.6001	.5658	.4527	.4904	
14	.5525	.5525	.5144	.5144	.3961	.4527	
15	.5335	.6097		.4973	.4338	.4904	
16	.8002	.6668	.5144	.6001	.7356	.6036	
17	1.0288	.9335	.6859	.6859	.9808	.8299	
18		1.3717	.9774	.8745	1.2071	1.1883	
19	1.448	1.2955	.9088	1.1145	1.1883	1.2826	
20	1.0288	.9907	.8573	.7716	1.2449	1.0751	
21	.7811	.6478	.6001	.6001	.9431	.7733	
22	.6859	.6097	.5144	.5144	.7922	.7167	
23	.5906	.5906	.4287	.4287	.6979	.6413	
24		.5716	.5716	.3429	.3601	.4527	.547
Max	1.448	1.5813	1.5623	1.3032	1.3203	1.358	1.6975
Min	.5335	.5525	.4287	.3429	.3601	.3772	.4715
Avg	.8002	.9483	.8312	.6937	.8260	.7482	.9525

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134085 / ANTERWALI TEMBHI

Feeder No / Name : 206 / 11KV Mangrul Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.1334	.1543	.1715	.0754	.0754
2		.2096	.1334	.1543	.1715	.0754	.0754
3		.2477	.1715	.1715	.2229	.0754	.0566
4		.2667	.2477	.1715	.2401	.1132	.0566
5		.3239	.3239	.1886	.2572	.1698	.0943
6		.4001	.4001	.2058	.3086	.3206	.2452
7		.4763	.362	.2401	.3944	.4527	
8		.362	.4191	.3086		.3772	
9			.4763	.2572		.2075	
10			.3239	.1715		.132	
11	.1715		.2286	.1715	.1372	.0754	
12	.1524			.1372	.1372	.0754	
13				.1372	.0943	.0754	
14	.0953	.1143		.1372	.0754	.0943	
15	.1143	.1334		.1372	.0943	.0754	
16	.1143	.1905	.1543	.12	.0943	.0754	
17	.1143	.2096	.1886	.1715	.1698	.0943	
18	.2667	.3429	.2743	.2572	.2452	.2263	
19	.4763	.4001		.2572	.2829	.3206	
20	.3429	.362	.2058	.1715	.2641	.2641	
21	.2667	.2096	.1715	.1715	.1886	.0943	
22	.2096	.1715	.1543	.1715	.1698	.0754	
23	.1715	.1334	.1543	.4287	.0943	.0754	
24		.1334	.1334	.1372	.0857	.0943	.0566
Max	.4763	.4763	.4763	.4287	.3944	.4527	.2452
Min	.0953	.1143	.1334	.12	.0754	.0754	.0566
Avg	.2080	.2557	.2451	.1929	.1857	.1548	.0943

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134086 / 33 KV RANJANI SUB STATION

Feeder No / Name : 201 / 11 KV RANJANI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3601	.2401	.3601	.4801	.2401	.7545
2		.6344	.2401	.463	.5144	.3086	.7716
3		.8573	.3086	.8573	.9602	.3772	.8402
4		.9602	.3601	1.3375	1.0288	.4458	.9945
5		1.166	.4801	1.6804	1.5432	.6173	
6		1.4918	.6687	1.7147	1.5432	.9945	1.166
7		1.5432	.9602	2.0233	1.6289	1.406	1.2003
8		1.6804	1.166	2.0062	1.7147	1.3032	1.2689
9		1.5604	1.3717	1.9719	1.749	1.1317	1.2346
10			1.6118	1.3717	.9259	.9602	.9945
11	.9088	.6859	1.2346		.7888	.9431	.8059
12		.5487	.9945	.7202	.5144	.8916	.5144
13	1.1145	.4801	.6859	.7373	.4458	.8573	.583
14			.6344	.6516	.4115	.7373	
15	.8059	.5144	.7202	.7373	.3772	.6001	
16	.8745	.5487	.9088	.8745	.5487	.7202	.823
17	1.4918	.7545	.9945	1.166	.7545	.9945	.823
18	1.6461	1.0631	1.3375	1.4918	1.0974	1.2003	1.0631
19	1.5089	.9602	1.2003	.9602	.9259	1.2689	1.2003
20	.8059	.6516	1.046	.8402	.6173	1.166	1.2346
21	.6859	.463	.6344	.6516	.4458	1.0288	.9945
22	.463	.3944	.6001	.5487	.3772	.9431	.823
23		.3429	.5144	.5144	.3086	.823	
24		.3772	.3086	.463	.4287	.2401	.823
Max	1.6461	1.6804	1.6118	2.0233	1.749	1.406	1.2689
Min	.463	.3429	.2401	.3601	.3086	.2401	.5144
Avg	1.0305	.8199	.8009	1.0497	.8388	.8416	.9456

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134086 / 33 KV RANJANI SUB STATION

Feeder No / Name : 202 / 11 KV RANJANI AG FDR SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.0762	.0914	.1886	.0343
3				.0914	.1524	.1886	.3258
4				.1219	.1829	.1886	.3429
5				.1524	.2134	.1886	.3601
6				.1524	.2286	.2229	.3772
7				.1677	.2743	.3772	.3944
8				.2439	.3048	.463	.3944
9				.2439	.3658	.1715	.3944
10			.3048				
11	.1981	.2743	.4268				
12	.2743		.3963				.0019
13	.2286	.6001	.4268				
14	.2743	.5316	.3658				
15	.2286	.5658	.3658				
16		.5316	.3963				
17		.4973	.4268				
18		.4115	.3201				
Max	.2743	.6001	.4268	.2439	.3658	.463	.3944
Min	.1981	.2743	.3048	.0762	.0914	.1715	.0019
Avg	.2408	.4875	.3811	.1562	.2267	.2486	.2917

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134086 / 33 KV RANJANI SUB STATION

Feeder No / Name : 203 / 11 KV KRISHNAPUR AG FEEDER SEPERATION/PURE AG  
 FEEDER Feeder KV- 11 /  
 OUTGOING

DATE	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.5792	.6249			
3	.6097	.7926			
4	.6859	.8535			
5	.7773	.9297			
6	.9297	1.0364			
7	1.0212	1.0669			
8	1.1126	1.2498			
9		1.1888			
11			1.2346	1.4327	1.3889
12			1.3565	1.7223	1.5432
13				1.7223	1.6804
14			1.6461	1.7071	1.6118
15			1.6156	1.4632	1.5775
16			1.5851	1.5089	1.4403
17			1.5546	1.4632	1.2689
18			1.3717	1.2803	1.2346
Max	1.1126	1.2498	1.6461	1.7223	1.6804
Min	.5792	.6249	1.2346	1.2803	1.2346
Avg	.8165	.9678	1.4806	1.5375	1.4682



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134086 / 33 KV RANJANI SUB STATION

Feeder No / Name : 204 / 11 KV CHITRAWADGAON AG. FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.4877	.6859	.7621	.1486
3				.5182	.7011	1.0364	1.3546
4				.5335	.7621	1.2498	
5				.6401	.8078	1.3108	
6				.7468	.884		
7					.9907		
8				1.1736	1.2041		1.166
9				1.2498	1.3413	.503	1.2174
10							1.2174
11	.5182	.9755	1.3565				
12	1.3413	1.4784	1.4784				
13	1.3717	1.3413	1.5089				
14	1.3717	1.4632	1.5242				
15	1.326	1.4937	1.4784				
16	1.2346	1.6461	1.4632				
17	1.2193	1.5242	1.448				
18	1.1888	1.448	1.3717				
Max	1.3717	1.6461	1.5242	1.2498	1.3413	1.3108	1.3546
Min	.5182	.9755	1.3565	.4877	.6859	.503	.1486
Avg	1.1965	1.4213	1.4537	.7642	.9221	.9724	1.0208

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134086 / 33 KV RANJANI SUB STATION

Feeder No / Name : 205 / 11 KV EXPRESS FEEDER  
Ranjani Feeder KV- 11 /  
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0267	.0191	.0324	.0191	.0171	.04
2			.0191	.0343	.0191	.0191	.0017
3			.0191	.021		.0152	.0025
4				.0305			.0027
5				.0267			.0034
6				.0343			.0025
7				.0229		.0191	.0017
9			.0171	.0324	.0171	.0191	
10		.0457	.0457	.0324	.0191		.0017
11	.0381		.0305	.0362			.0025
12	.0191		.021	.0267			.0021
13			.0191	.0267			.0206
14	.0286						.036
15	.0248			.0267			.0514
16	.0267			.0267			.0326
17	.0248			.021			
18	.0267	.0248	.021	.0191	.0152		
19	.0305	.0381	.0229	.04	.0286		.0291
20		.0438	.0343	.0457	.0343		.0223
21	.0343	.0381	.0419	.0495	.0381		.0206
22	.0381	.0191	.04	.0457	.04		.0223
23	.0248	.0191	.0381	.04	.0324		
24		.0229	.0171	.0343	.0267	.0171	.004
Max	.0381	.0457	.0457	.0495	.04	.0191	.0514
Min	.0191	.0191	.0171	.0191	.0152	.0152	.0017
Avg	.0288	.0309	.0271	.0321	.0263	.0178	.0158

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134086 / 33 KV RANJANI SUB STATION

Feeder No / Name : 206 / PARADGAON GFS.

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.12	.0686	.12	.12	.12	.1029
2		.12	.0686	.12	.12	.12	.1029
3		.12	.0857	.12	.12	.12	
4		.12	.0857	.12	.12	.1543	.1543
5		.12	.12	.1715	.1543	.1715	.1715
6		.2572	.1543	.3258	.2572	.2058	.1715
7		.3086	.1886	.2572	.3258	.2401	
8		.2572	.2572	.2572	.2058	.2058	.2401
9		.2058	.2058	.2743	.2058		.2401
10		.12	.12	.12	.1029		.12
11	.0686	.0857	.0857	.12	.0686		
12	.12	.0686	.0857	.12	.0686		
13	.12	.0686	.12	.12	.0686		.0857
14	.12	.12	.12	.1029	.0686		.0686
15	.12	.1029	.12	.1029	.0514		
16	.12	.12	.12	.12	.12		.0857
17	.12	.1029	.12	.12	.12		.12
18	.3258	.12	.1029	.12	.1886		.1543
19	.1543	.1715	.3258	.1543	.1886		.1886
20	.12	.12	.2572	.1029	.12		.2058
21	.12		.12	.1029	.12		.12
22	.12		.12	.12	.12		.12
23	.12		.12	.12	.1029		
24		.12	.0857	.12	.12	.1029	.0857
Max	.3258	.3086	.3258	.3258	.3258	.2401	.2401
Min	.0686	.0686	.0686	.1029	.0514	.1029	.0686
Avg	.1345	.1404	.1357	.1472	.1357	.1600	.1410

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134087 / 33 KV JIRADGAON SUB STATION

Feeder No / Name : 201 / 11KV BORGAON GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001	.1867	.1867	.3239	.1715	.1867	.3429
2	.4191	.1886	.1867	.362	.1715	.2241	.381
3	.4382	.2614	.1867	.362	.2401	.2241	.381
4	.4763	.2229	.2241	.381	.2743	.2801	
5	.4954	.2614	.3364	.381	.3086	.2801	
6	.5335	.2401	.3742	.4382	.3258	.3361	
7	.1715	.2058	.4677	.4001	.3258	.3734	
8	.2096	.2915	.4668	.381	.3086	.3734	
9	.2858	.1715	.4481	.3429	.2987	.3734	
10	.2229		.2241	.2743	.2614	.2241	
11	.1715	.112	.1867		.1867		
12	.0934	.0934	.0934		.1494	.0953	
13	.0857	.112	.0934	.1029	.112	.0953	
14	.0686	.0934	.0747	.12	.0934	.1143	
15		.0934	.0747	.1029	.0934	.1524	
16		.1494	.1143	.1372	.1494	.1524	
17		.1867	.1334	.1715	.1869	.2858	
18		.2801		.2572	.3361	.3239	
19	.2987	.3734	.3429	.2801	.2241	.3429	.2401
20	.2743	.3361	.4001	.2572	.2241	.381	
21	.2401	.2801	.4001	.2427	.2241	.4191	.1715
22	.2401	.1867	.381		.1867	.4001	.1715
23	.1886	.1867	.3429	.1715	.1867	.381	.1715
24		.1715	.1867		.12	.1867	
Max	.5335	.3734	.4677	.4382	.3361	.4191	.381
Min	.0686	.0934	.0747	.1029	.0934	.0953	.1715
Avg	.2797	.2037	.2576	.2745	.2150	.2698	.2656

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134087 / 33 KV JIRADGAON SUB STATION

Feeder No / Name : 202 / 11 KV KANDARI GAOTHAN GAOTHAN FEEDER  
Feeder KV- 11 / OUTGOING

DATE	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2801	.2241	.2614
2	.2801	.1867	.2617
3	.2614	.1867	.1867
4	.2852	.1867	.2801
5	.2987	.2801	.2801
6	.1867	.2241	.2801
7	.0943	.1494	.2614
8	.0747	.0934	.2614
9	.0934	.2241	.2427
10	.3174	.2987	.3547
11	.2241	.112	.1867
12		.112	.1307
13	.1494	.112	.1307
14	.112	.112	.112
15	.0934	.1307	.112
16	.1867	.112	
17	.2243	.1494	.2054
18	.2241	.1886	.1867
19	.2241	.2241	.2614
20	.2241	.2427	.2987
21	.2801	.2801	.2614
22	.2241	.2801	.2614
23	.1867	.2614	.2614
24	.2987	.2241	.1867
Max	.3174	.2987	.3547
Min	.0747	.0934	.112
Avg	.2097	.1915	.2289

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134087 / 33 KV JIRADGAON SUB STATION

Feeder No / Name : 203 / 11 KV BORGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0171	.0187	.0191	.0171	.0187	.2858
2		.0171	.0187	.4191	.6859	.2801	.2858
3		.0171	.0187	.4572	.6859	.3361	.3048
4	.0191	.0171	.0187	.4763	.703	.4668	.381
5	.0191	.0171	.0187	.5525	.6859	.5975	.4001
6	.0191	.0171	.0187	.7621	.703	.7468	.4191
7	.0191	.0171	.0187	.8573	.7202	.7468	.4763
8	.0191	.0171	.0187	.8954	.8402	.8962	.5906
9	.0191	.0171	.0187	.8764	.8962	.8402	.6668
10			.0373	.0171	.0187	.0187	.0171
11	.6001	1.4563	.7095	.0171	.0373	.0191	.0171
12	.8916	1.2696	1.0269	.0171	.0189	.0191	.0171
13	.9335	1.2136	1.0456	.0171	.0187	.0191	
14	.7468	1.1203	1.0829	.0171			.0171
15	.8745	.8962	.9709	.0171			.0187
16	.9522	.8402	.0191	.0171			.0171
17	.8589	.8402		.0171			.0171
18	.6722	.7468	.0191	.0171	.0187	.0191	.0171
19	.0187	.0187	.0191	.0171	.0187	.0191	.0171
20	.0171	.0187	.0191		.0373	.0191	.0171
21		.0187	.0191	.0171	.0373	.0191	.0171
22	.0187	.0187	.0191	.0171	.0373		.0171
23	.0171	.0187	.0191	.0171	.0373		.0171
24		.0171	.0187		.0171	.0373	
Max	.9522	1.4563	1.0829	.8954	.8962	.8962	.6668
Min	.0171	.0171	.0187	.0171	.0171	.0187	.0171
Avg	.3731	.3760	.2258	.2517	.3117	.2844	.1834

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134087 / 33 KV JIRADGAON SUB STATION

Feeder No / Name : 204 / 11 KV KANDARI AG SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.4382	.6001	.3361				
3	.4572	.6173	.3361				
4	.4572	.6859	.4108				
5	.4763	.6516	.5228				
6	.6287	.6173	.6535				
7	.724	.583	.7095				
8	.7811	.6687	.7468				
9	.724	.6344	.8402				
11				.6344	1.4003	1.5242	1.1317
12				.7468		1.8099	1.5775
13				.9602	1.9605	1.848	1.749
14					1.9605	1.8671	1.7318
15				1.3203	2.0165	1.7528	1.5261
16				1.6804	1.9625	1.8099	.9431
17				1.8861	1.8298	1.4289	1.5432
18				1.3717	1.363	1.4289	1.5432
Max	.7811	.6859	.8402	1.8861	2.0165	1.8671	1.749
Min	.4382	.583	.3361	.6344	1.363	1.4289	.9431
Avg	.5858	.6323	.5695	1.2286	1.7847	1.6837	1.4682

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134087 / 33 KV JIRADGAON SUB STATION

Feeder No / Name : 205 / 11 KV PANGRA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			.381		.3361	.7621
3					.5601	.7621
4			.4763		.6535	.9526
5			.4763		.9709	1.4289
6					1.0884	1.6194
7					1.2136	1.7147
8					1.6804	1.7147
9				.7468	1.0829	1.5813
10					.1524	
11	1.5497	1.1576				
12	2.0911	1.9605				
13	2.6513	1.9044				
14	2.1472	1.7737				
15	1.8298	1.1203				
16	1.8298	1.3717				
17	1.9044	1.3908				
18	1.6804					
Max	2.6513	1.9605	.4763	.7468	1.6804	1.7147
Min	1.5497	1.1203	.381	.7468	.1524	.7621
Avg	1.9605	1.5256	.4445	.7468	.8598	1.3170



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134087 / 33 KV JIRADGAON SUB STATION

Feeder No / Name : 206 / 11 KV Maherjawla gaothan GAOTHAN FEEDER  
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.1715	.1494	.3239	.1372	.1494	.3429
2	.3239	.1715	.1494	.4572	.1543	.1867	.3429
3	.3429	.1715	.1867	.4572	.2401	.1867	.5525
4	.381	.2401	.1867	.4954	.2401	.2241	.5716
5	.4191	.3429	.2801	.6287	.3086	.3361	.5716
6	.4954	.4801	.5228	.6097	.4458	.5601	.5906
7	.5335	.4801	.6535	.5716	.583	.6535	.6097
8	.4763	.5788	.5601	.5525	.5316	.5975	.5906
9	.4572	.1543	.5228	.4572	.4481	.5601	.5144
10	.1715		.2801	.3174	.2614	.2427	.3601
11	.1029	.1494	.1867		.1867	.1143	.1372
12	.0747	.168	.112		.1494	.0953	.1372
13	.0686	.112	.112	.12	.0934	.0953	
14	.0747	.1494	.0934	.0857	.0934		.1029
15	.0934	.1494	.1086	.1029	.0747	.1334	
16	.12	.1867	.1334	.1372	.112	.1524	.1543
17	.0686	.2804		.2058	.2241	.1715	.1543
18	.4481	.3734		.4115	.5228	.2286	.4287
19	.3772	.4668		.4481	.3734	.5335	.4481
20	.3772	.3361		.3429	.3361	.5716	.4115
21	.3429	.1867	.4572	.3429	.1867	.5144	.1886
22	.2401	.1494	.4572	.2801	.1867	.4954	.1886
23	.1715	.1494	.4382	.1715	.1494	.4001	.1867
24		.1372	.1715		.12	.1867	
Max	.5335	.5788	.6535	.6287	.583	.6535	.6097
Min	.0686	.112	.0934	.0857	.0747	.0953	.1029
Avg	.2819	.2515	.2881	.3581	.2566	.3213	.3612

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134087 / 33 KV JIRADGAON SUB STATION

Feeder No / Name : 207 / 11 KV MASHEGAON AG FEEDER FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.4191	.5144	.4668				
3	.4763	.6687	.5601				
4	.5716	.6687	.6535				
5	.6668	.6859	.8215				
6	.7621	.6859	.9709				
7	.7621	.7202	1.0829				
8	.8573	.6859	1.1203				
9	.9907	.6859	1.2136				
11				.4115	1.1576	1.1431	1.7551
12				.6859	1.1763	3.0179	2.5073
13				.703	1.531	3.1058	1.4403
14				.6859	1.587	3.112	3.0087
15				.9149	1.531	3.0933	3.2952
16				1.1203	1.4003	2.8292	
17				1.1203	1.2136	1.9616	1.531
18				1.0288	1.2774	1.7729	2.8654
Max	.9907	.7202	1.2136	1.1203	1.587	3.112	3.2952
Min	.4191	.5144	.4668	.4115	1.1576	1.1431	1.4403
Avg	.6883	.6645	.8612	.8338	1.3593	2.5045	2.3433

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134088 / 33kv BOR-RANJANI

Feeder No / Name : 201 / 11 KV PARADGAON AG  
FEEDER Feeder KV- 11 /  
OUTGOING

FEEDER SEPERATION/PURE AG

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3201	.2743	.3462	
2				.3658	.3658	.4666	.3612
3				.3658	.3658	.587	.4064
4				.4268	.3963	.7074	.4666
5				.4268	.4268	.8278	.7074
6				.5639	.5639	.9482	.888
7				.7926	.823	1.0686	1.0084
8					.9145	1.2191	1.2793
9				.823	.8993	1.2643	1.2803
11		.6097					
12		.7316					
13		.7316	.8078				
14		.5639	.9755				
15	.5201	.7926	.9755				
16	.6984	.6097	.9907				
17	.743	.8078	1.0364				
18	.6984	.7316	.9145				
Max	.743	.8078	1.0364	.823	.9145	1.2643	1.2803
Min	.5201	.5639	.8078	.3201	.2743	.3462	.3612
Avg	.6650	.6973	.9501	.5106	.5589	.8261	.7997

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134088 / 33kv BOR-RANJANI

Feeder No / Name : 202 / YEOLA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494		.1494	.1494	.112	.0934	.1307
2	.1494	.1494	.1494	.1494	.1307	.0934	.1307
3	.1494	.1494	.1494	.168	.1494	.112	.1494
4	.168	.1867	.168	.1867	.1867	.1307	.1867
5	.2241	.2241	.168	.3174	.2614	.1307	.2241
6	.2614	.2801	.1867	.3921	.2241	.1494	.2614
7	.2801	.2987	.2054	.3174	.2801	.168	.2241
8	.2241	.3174	.2241	.2241	.3174	.1867	.2241
9	.2614	.2427	.2241	.2801	.2427	.1494	.2987
10	.2987	.2241	.2614	.3547	.2801	.2241	.2427
11		.2241		.1867	.2427	.1867	.2241
12		.2054	.2241	.2241	.1867	.1494	.1494
13	.2241	.168	.2054	.1307	.1867	.112	.168
14	.2241	.168	.1867	.1307	.112	.112	.2241
15	.2241	.2054	.2241	.2241	.1494	.112	.168
16	.2801	.1867	.2987	.2054	.168	.1867	.2614
17	.2987	.1867	.2987	.1867	.2054	.2054	.2987
18	.4108	.3174	.4294	.2987	.2987	.3174	.3361
19	.3921	.3361	.3734	.2614	.2987	.2987	.3734
20	.3361	.2614	.2801	.1867	.2427	.2987	.2614
21	.2241	.2241	.2427	.168	.1867	.2241	.2054
22	.1867	.1867	.2241	.1494	.1494	.1867	.168
23	.1867	.1494	.2054	.1307	.0934	.1494	.1494
24	.1494	.1494	.1494	.1494	.1307	.0934	.1307
Max	.4108	.3361	.4294	.3921	.3174	.3174	.3734
Min	.1494	.1494	.1494	.1307	.0934	.0934	.1307
Avg	.2410	.2192	.2273	.2155	.2015	.1696	.2163

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134088 / 33kv BOR-RANJANI

Feeder No / Name : 203 / 11 KV BOR RANJANI AG FEEDER SEPERATION/PURE AG  
FEEDER Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4755				
2	.3658	.3121	.5053				
3	.2972	.3269	.535				
4	.2972	.3269	.5647				
5	.3269	.4161	.5944				
6	.3567	.4904	.639				
7	.4161	.6687	.6687				
8	.743	.7133	.743				
9	.7876	.8173	.6836				
11				.9511	.8768	.8322	.9214
12				.9808	1.0551	.9659	1.0402
13				1.0997	1.0402	1.1443	.9511
14				1.0402	1.0848	1.1294	1.1145
15				1.0997	.9065	1.1443	1.1443
16				1.0402	1.0254	1.0402	1.1591
17				1.07	.8471	.8025	1.0105
18				.9065	.8916	.7133	1.0254
Max	.7876	.8173	.743	1.0997	1.0848	1.1443	1.1591
Min	.2972	.3121	.4755	.9065	.8471	.7133	.9214
Avg	.4488	.5090	.6010	1.0235	.9659	.9715	1.0458

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134012 / MANTHA

Feeder No / Name : 201 / TALNI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3032	1.3032	1.2003	1.2346	1.3717	1.2346	1.3375
2	1.7147	1.3375	1.2003	1.2689	1.3717	1.2003	1.3717
3	1.7147	1.4746	1.2346	1.3032	1.3717	1.2346	1.6461
4	1.7147	1.5432	1.3717	1.3717	1.3717	1.2346	1.9547
5	2.1434	1.6461	1.6118	1.5089	1.3717	1.4403	1.989
6	2.1605	2.0233	2.0576	2.0233	1.3717	1.4403	2.0748
7	1.406	1.1317	1.406	1.2346	1.5432	1.4403	1.3375
8	1.8861	1.7147	1.8861	1.5089	1.8861	1.8861	1.749
9	2.0233	2.0576	2.4006	1.8176	2.0576	2.0233	1.9204
10	1.9547	1.989	2.2291		1.8861		1.749
11	1.7833	1.9204	2.0919		1.8861	.9602	1.6118
12	1.0974	1.0288	1.0631			.8573	1.5432
13	1.6118	1.7147	1.3717	1.3717	1.9204	1.7833	1.8861
14	1.8861	1.4746	1.6804	2.572	2.0576	1.3375	1.5775
15	1.7833	1.9204	1.4403	2.572	2.1262	2.0233	1.8861
16	1.5432	1.8519	1.6461	2.572	2.0233	2.0233	1.9204
17	1.406	1.749	1.4403	2.0576	1.9547	1.8519	1.5432
18	1.3375	1.5432	1.4746	1.7147	1.749	1.7147	1.406
19	1.8861	1.8176	1.8861	1.7147	1.8004	1.7833	2.1262
20	1.7147	1.6461	1.7147	1.7833	1.8004	1.9547	1.749
21	1.5775	1.5775	1.5432	1.7833	1.7147	1.6461	1.6118
22	1.3717	1.4746	1.3717	1.5432	1.7147	1.4403	1.3717
23		1.406	1.2346	1.4746	1.3717	1.3717	1.3032
24	1.3032	1.3032	.6859	1.2003	1.3717	1.2346	1.3032
Max	2.1605	2.0576	2.4006	2.572	2.1262	2.0233	2.1262
Min	1.0974	1.0288	.6859	1.2003	1.3717	.8573	1.3032
Avg	1.6662	1.6104	1.5518	1.6967	1.6997	1.5268	1.6654

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134012 / MANTHA

Feeder No / Name : 202 / IDOLI (ARDA)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1029	.1029	.1372	.2572	.2401	.2058
2	.1029	.1029	.1029	.1372	.2572	.6859	.2743
3	.1715	.1372	.1372	.1715	.2572	.6859	.3429
4	.1715	.1715	.1715	.1715	.3429	.5144	.4115
5				.1715	.3429	.5144	.5144
6				.3429	.4458	.8573	.6173
7				.6173	.5144	.8573	.6859
8				.8573	.8573	.8916	.9602
9				.7545	1.0288	.9259	.823
11	.5487	.5144	.583				
12	.7202	.7202	.6516				
13	.4801	.7202	.6859				
14	.4458	.7202	.7888				
15	.583	.7545	.7888				
16	.6173	.7545	.823	.1372	.2058	.2058	.1029
17	.5487	.7545	.6859	.12	.2401	.2058	.1372
18	.5144	.6173	.5487	.1029	.2058	.2058	.2058
19	.2058	.2058	.2401	.1029	.2058	.2401	.2058
20	.1715	.2058	.1372	.1029	.1715	.2058	.2401
21	.1715	.1372	.1715	.1029	.1715	.1715	.1715
22	.1372	.1372	.1372	.1029	.1715	.1372	.1372
23		.1372	.1372	.1029	.1715	.1715	.1372
24	.1029	.1372	.1372	.1372	.1715	.2401	.2058
Max	.7202	.7545	.823	.8573	1.0288	.9259	.9602
Min	.1029	.1029	.1029	.1029	.1715	.1372	.1029
Avg	.3409	.3906	.3906	.2429	.3344	.4420	.3544

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134012 / MANTHA

Feeder No / Name : 203 / PATHODA (HEALS)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.7202	.5487	.5144	.6001	.5658	.6173
2	.4115	.583	.583	.5487	.6859	.6516	.7202
3	.5144	.6173	.6173	.583	.6859	.6859	.8573
4	.7545	.6173	.6516	.583	.6859	.6859	.9259
5	.8573	.6516	.8573				
6	.8573	.6516	1.0288				
7	1.5432	1.2003	1.166				
8	1.3717	1.5432					
9	1.1488	1.406					
11					1.2003		1.2003
12				1.4746	1.3717	1.3717	1.406
13				1.6118	1.6289	1.3546	1.3717
14				1.8861	1.6289	1.286	1.3717
15				1.8861	1.3717	1.2003	1.3717
16	.8916	1.2003	1.2346	1.7147	1.3032	1.1317	1.1317
17	.823	1.2346	1.2346	1.5432	1.286	1.0288	1.0288
18	.7202	1.3032	1.0631	.9602	1.1317	1.0631	.8573
19	1.0974	1.0631	1.0288	.8573	1.1317	1.0974	1.0288
20	.9602	1.0288	.8916	.7716	.7545	.9945	.9945
21	.8573	.823	.7545	.7202	2.4691	.7545	.823
22	.7202	.583	.6173	.6001	3.0864	.5487	.583
23		.583	.583	.5487	1.3717	.5487	.5144
24	.4115	.6516	.5487	.5144	.5144	.5658	.5144
Max	1.5432	1.5432	1.2346	1.8861	3.0864	1.3717	1.406
Min	.4115	.583	.5487	.5144	.5144	.5487	.5144
Avg	.8442	.9145	.8381	1.0187	1.2727	.9138	.9621



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134012 / MANTHA

Feeder No / Name : 204 / AMBHODA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3032	1.5089	1.406	1.2689	1.3717	1.3717	.6859
2	1.3032	1.5432	1.4403	1.3717	1.3717	1.3717	.7202
3	1.5432	1.5775	1.5089	1.4403	1.5432	1.3717	.7545
4	1.7147	1.5775	1.5432	1.5432	1.5432	1.3375	.823
5	1.7147	1.6118	1.5432	1.6461	1.5432	1.3375	.8573
6	1.7661	1.6804	1.4746	1.8176	1.5432	1.5089	.8573
7	1.1317	.6859	1.2346	1.3032	1.8861	1.5089	1.406
8	1.0288	1.3717	1.5432	1.9204	2.2291	2.2291	2.1605
9	.9431	1.8861	1.9204		2.572	2.3148	2.4348
10	1.2689	1.8519	1.6461		2.572	2.4006	2.2291
11	1.1317	1.6804	1.5089		2.4006	2.0748	2.1948
12	.9945	1.3717	1.3717	1.5432		1.7318	1.8519
13	1.9204	2.1948	2.0576	1.8861	1.6461	1.5261	1.5432
14	1.8861	2.572	2.4006	1.8176	1.7147	1.4918	1.5089
15	2.2291	2.4348	2.4691	1.8861	1.6804	1.5089	1.5089
16	2.1605	2.4006	2.5034	1.7147	1.5432	1.406	1.5089
17	1.8861	2.0919	2.1605	1.5432	1.3717	1.2689	1.3717
18	1.2689	1.8861	1.7833	1.3717	1.2517	1.2003	1.0974
19	2.0233	1.9204	1.7147	1.5432	1.7147	1.8519	1.0974
20	1.8519	1.8861	1.5089	1.7147	1.7147	1.869	1.0288
21	1.7147	1.7147	1.5775	1.749	1.749	.8573	1.046
22	1.6118	1.5432	1.4746	1.5432	1.3717	.9259	.9259
23		1.4403	1.3717	1.406	1.4746	.8573	.8573
24	1.3032	1.5432	1.3717	1.2346	1.3717	1.3717	.7545
Max	2.2291	2.572	2.5034	1.9204	2.572	2.4006	2.4348
Min	.9431	.6859	1.2346	1.2346	1.2517	.8573	.6859
Avg	1.5522	1.7490	1.6889	1.5840	1.7035	1.5289	1.3010

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134012 / MANTHA

Feeder No / Name : 205 / MANTHA TOWN-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.0514	.1029	.0857	.1029	.1029	.0514
2	.1029	.0514	.0857	.0857	.1029	.1029	.0514
3	.1029	.0514	.1029	.0857	.1029	.1029	.0514
4	.1029	.0514	.0857	.1029	.1029	.1029	.0514
5	.1029	.0686	.1029	.1029	.1029	.1029	.0686
6	.1029	.0686	.1029	.1029	.1029	.1029	.0857
7	.1029	.0857	.1029	.1029	.1029	.1372	.0857
8	.1029	.1029	.1029	.1029	.1029	.1029	.1029
9	.1029	.1029	.1029	.1029	.1029	.1029	.1029
10	.1029	.1029	.1029		.1029	.1029	.1029
11	.0686	.1029			.1029	.0343	.1029
12	.0857	.0857	.1029	.1372	.1029	.0343	.1029
13	.0857	.1029	1.0974	.1029		.0343	.0857
14	.0857	.0857	.1029	.1029	.0686	.0343	.0857
15	.0857	.0857	.0857	.1029	.0686	.0686	.0857
16	.1029	.0857	.1029	.1029	.0686	.1029	.0857
17	.1029	.0857	.1029	.12	.0857	.1029	.0857
18	.1029	.1029	.1029	.12	.1029	.1029	.1029
19	.1029	.1029	.1029	.12	.1029	.1029	.1029
20	.0857	.1029	.1029	.1029	.1029	.0857	.0857
21	.0686	.0857	.1029	.1029	.1029	.0686	.0857
22	.0686	.0857	.1029	.1029	.1029	.0514	.0514
23		.0857	.1029	.1029	.1029	.0514	.0514
24	.1029	.0514	.1029	.1029	.1029	.1029	.0514
Max	.1029	.1029	1.0974	.1372	.1029	.1372	.1029
Min	.0686	.0514	.0857	.0857	.0686	.0343	.0514
Avg	.0947	.0829	.1439	.1044	.0977	.0850	.08

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134012 / MANTHA

Feeder No / Name : 206 / INDUSTRIAL FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.1029	.4801	.2401	.3429	.2743	.1715
2	.5487	.1372	.4458	.2743	.3429	.2743	.2058
3	.5144	.1372	.4458	.2743	.3429	.2743	.2058
4	.5144	.1372	.3429	.2743	.3086	.2743	.2058
5	.583	.1029	.3429	.3086	.3086	.2743	.2401
6	.583	.1372	.3086	.3772	.3086	.3086	.2401
7	.583	.1372	.3772	.4115	.3086	.3086	.2401
8	.3772	.1029	.2058	.2401	.2743	.1029	.1372
9		.2058	.2743	.1372	.2743	.1029	.1372
10	.3086	.3429	.3772		.2401	.1029	.1372
11	.3086	.4115	.2401		.2401	.2058	.1372
12	.2743	.3429	.3086		.2401	.12	.1029
13	.4115	.3772	.3086	.1715	.2401	.1715	.1029
14	.3429	.3429	.3429	.3086	.2058	.1715	.1372
15	.0686	.3429	.3086	.3086	.1715		.1372
16	.0686	.3772	.2743	.2401	.2058	.1715	.1029
17	.0686	.4115	.2743	.1715	.2401	.1715	.1029
18	.1029	.3429	.1715	.1372	.1715	.1715	.1372
19	.1029	.3772	.2401	.1372	.1715	.1372	.1029
20	.1372	.4115	.2401	.2058	.1715	.2058	.1372
21	.1715	.5144	.2743	.2743	.1715	.2743	.1372
22	.1372	.4801	.2401	.3086	.2743	.2743	.3086
23		.4458	.2401	.3772	.3086	.1715	.3429
24	.5487	.1029	.4801	.2401	.3772	.2743	.1372
Max	.583	.5144	.4801	.4115	.3772	.3086	.3429
Min	.0686	.1029	.1715	.1372	.1715	.1029	.1029
Avg	.3320	.2843	.3143	.2580	.2601	.2095	.1686

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134012 / MANTHA

Feeder No / Name : 207 / MANTHA TOWN-II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.7202	.6859	.6516	.6859	.5487	.6173
2	.5487	.7545	.7202	.6859	.6859	.6859	.6859
3	.6516	.8573	.823	.7202	.6859	.6859	.6859
4	.6859	.9259	.8916	.7888	.8573	1.3375	.8916
5	.6859	.9945	1.0288	.8573	1.0288	1.5089	.9602
6	1.0288	1.0631	1.0974	.9259	1.2003	1.5432	1.1317
7	1.6804	1.4403	1.5432	1.4403	1.2003	1.5432	1.4746
8	1.6804	1.5775	1.5432	1.6461	1.3717	1.7147	1.5432
9	1.6804	1.4746	1.5089	1.6804	1.5432	1.406	1.406
10	1.5432		1.406		1.3717		1.3717
11	1.5089	1.3717	1.2346		1.286	1.2689	1.3375
12	1.3717	1.2003	1.2689	1.7833	1.2003	1.166	1.3032
13	1.2003	1.0288	1.2003	1.4403	1.0974	1.0288	1.0631
14	1.3717	1.166	1.166	1.2346	1.0974	1.0288	.8573
15	1.0631	1.166	1.1317		1.0974	.9945	1.0288
16	1.1317		1.2003	1.2003	1.0974	1.0631	1.166
17	1.0974	1.4746	1.3032	1.2003	1.2689	1.2003	1.0974
18	1.0631	1.406	1.406	1.2346	1.3375	1.3717	1.3032
19	1.2346	1.2003	.8573	1.0288	1.3032	1.166	1.166
20	1.0288	1.0631	1.166	.9431	1.0288	.9945	.9945
21	.8916	.823	.8573	.8573	.8573	.7888	.823
22	.7888	.7202	.7545	.7716	.8573	.6859	.6516
23		.7202	.6859	.6859	.6173	.6516	.583
24	.5487	.7545	.6859	.6516	.6859	.5487	.583
Max	1.6804	1.5775	1.5432	1.7833	1.5432	1.7147	1.5432
Min	.5487	.7202	.6859	.6516	.6173	.5487	.583
Avg	1.0885	1.0865	1.0903	1.0680	1.0610	1.0840	1.0302

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134020 / DAHIPHAL KHANDARE

Feeder No / Name : 202 / DAHIFAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003	1.3717	1.3717	1.2003	1.2003	.8573	.7716
2	1.3717	1.3717	1.5432	1.2003	1.2003	.8573	.7716
3	1.3717	1.5432	2.0576		1.2003	.8573	.7716
4	1.5432		2.0576	1.2003	1.2003	.8573	.7716
5	1.5432	1.7147	2.4006				
6	1.7147	2.0576	2.572				
7	1.9719	2.7435	2.7435				
8	2.1262	3.0864	2.915				
9	2.2291	3.2579	3.0864				
11					2.572	2.4006	
12				1.7147	2.915	3.0007	
13				2.0576	3.0864	2.915	
14				1.7147	3.0864	3.0864	
15				2.572		3.0864	
16		1.0288	1.0288	2.572	2.8292	2.572	
17	.7716	1.0288	1.3717	2.7435	3.3265	2.4006	
18	.9431	1.0288	1.3717	2.7435	2.7435	1.8861	
19	.8573	1.0288	1.3717	1.2003	.8573	.823	
20	.6859	1.0288	1.3717	1.2003	1.0288	.8573	
21	.6859	1.1145	1.3717	1.3717	.8573	.8573	
22	.6859	1.1145	1.2003	1.3717	.8573	.823	
23	.6859	1.1145	1.2003	1.2003	.8573	.7716	
24	1.2003	1.0288	1.2003	1.2003	1.2003	.8573	.7716
Max	2.2291	3.2579	3.0864	2.7435	3.3265	3.0864	.7716
Min	.6859	1.0288	1.0288	1.2003	.8573	.7716	.7716
Avg	1.2699	1.5684	1.7909	1.7040	1.8246	1.6537	.7716

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134020 / DAHIPHAL KHANDARE

Feeder No / Name : 203 / KOKARSHA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1715	.5144	.5144	.6859	.8573
2	.1715	.1715	.1715	.5144	.5144	.8573	.8573
3	.1715	.1715	.1715	.8573	.6859	.8573	.8573
4	.1715	.1715	.1715	.8573	.6859	.8573	1.0288
5				1.0288	1.0288	1.0288	1.0288
6				1.0288	1.2003	1.0288	1.0288
7				1.3717	1.3717	1.2003	1.2003
8				1.3717	1.3717	1.2003	1.2003
9					1.3717	1.3717	1.0288
11	1.2003	1.2003	1.0288				
12	1.2003	1.2003	1.2003				
13	1.286	1.5432	1.5432				
14	1.0288	1.5432	1.5432				
15		1.5432	1.3717				
16		1.5432	1.0288	.3429	.1372	.1715	
17	1.1145	1.5432		.3429	.1372	.2229	
18	1.0288	1.2003	1.0288	.3429	.1715	.2572	
19	.1715	.3429	.3429	.3429	.2058	.2058	
20	.1715	.3429	.3429	.3429	.2058	.1715	
21	.1715	.2572	.3429	.3429	.1715	.1715	
22	.1715	.2572	.3429	.3429	.1715	.2058	.1715
23	.1715	.1715	.4287	.3429	.1715	.1715	
24	.1715	.1715	.1715	.4287	.4287	.6859	.7716
Max	1.286	1.5432	1.5432	1.3717	1.3717	1.3717	1.2003
Min	.1715	.1715	.1715	.3429	.1372	.1715	.1715
Avg	.5359	.7526	.6707	.6304	.5859	.6306	.9119

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134020 / DAHIPHAL KHANDARE

Feeder No / Name : 204 / PEWA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.286	1.3717	1.2003	1.2003	1.0288	.6859	.6859
2	1.286	1.5432	1.7147	1.2003	1.0288	.6859	.6859
3	1.3717	1.5432	2.0576	1.2003	1.0288	.6859	.6859
4	1.3717	1.7147	2.0576	1.2003	1.0288	.6859	.6859
5	1.5432	1.7147	2.4006				
6	1.5432	1.8861	2.7435				
7	1.7147	2.0576	3.0864				
8		2.2291	3.2579				
9	1.7147	2.572	3.2579				
10	1.8861						
11					1.5432	1.6118	
12				2.0576	1.7318	1.9719	
13				2.0576	1.9719	1.5432	
14				2.0576	1.9547	1.8519	
15				2.4006	1.8861	1.9547	
16		1.0288	1.0288	2.4006	1.5432	1.6289	
17	1.0117	1.0288	1.3717	2.572	1.5432	1.5432	
18	1.0288	1.0288	1.3717	2.572	1.4575	1.3717	
19	.8573	1.0288	1.3717	1.2003	.7545	.6859	
20	.8573	1.0288	1.3717	1.2003	.7716	.6859	
21	.7716	1.0288	1.3717	1.3717	.6859	.6344	
22	.6859	1.0288	1.2003	1.2003	.6001	.6173	
23	.6001	1.0288	1.2003	1.2003	.6001	.6001	
24	1.3717	1.3717	1.1145	1.2003	1.2003	.5144	.6859
Max	1.8861	2.572	3.2579	2.572	1.9719	1.9719	.6859
Min	.6001	1.0288	1.0288	1.2003	.6001	.5144	.6859
Avg	1.2295	1.4575	1.8433	1.6643	1.2422	1.1088	.6859

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134050 / JAIPUR

Feeder No / Name : 201 / V.WADGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6783	.5596	.8139	1.0174	.8478	.8478	.8139
2	.8309		.7373	1.1022	1.1022	1.153	.8478
3	.8648	.5935	.6783	1.1869	1.3565	1.1869	1.0343
4	.8192	.6613	.6104	1.4413	1.6448	1.6108	1.0343
5				1.7804	1.7974	1.6448	1.1869
6				2.0348	2.0348	1.7295	1.95
7				2.2043	2.1195	2.0348	2.3739
8				2.3739	2.2043	2.1195	2.34
9				2.0348	2.0348	2.2043	2.0348
11	1.7465	1.5261	1.7804				
12	1.7368		1.95				
13	1.8842	1.9662	2.0348				
14	1.6385	2.2043	1.8652				
15	1.6278	2.1704	1.95				
16	1.5893	2.1195	1.95	1.0174	.9835	1.0174	1.1869
17	1.4922	2.0348	2.0008	1.3735	1.4413	1.3904	1.2717
18	1.4413	1.3565	1.7804	1.4074	1.4413	1.5261	1.5261
19	1.1869	1.153	1.5261	1.1022	1.1361	1.4413	1.4413
20	1.0004	1.0174	1.1869	.9326	1.0174	1.2209	1.3565
21	.7461	.9665	1.1022	.78	.8139	1.0174	1.1869
22	.7122	.9156	1.1022	.6783	.763	.8817	1.1022
23	.6952	.9496	1.0174	.5765	.6783	.78	1.0174
24		.5935	.8139	.6443	.6443		.8139
Max	1.8842	2.2043	2.0348	2.3739	2.2043	2.2043	2.3739
Min	.6783	.5596	.6104	.5765	.6443	.78	.8139
Avg	1.2171	1.2992	1.3833	1.3160	1.3367	1.4004	1.3622



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134050 / JAIPUR

Feeder No / Name : 202 / WAZAR S.

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6443	.5596	.5426	.5935	.5426	.5426	.5426
2	.6443	.5765	.5765	.5935	.5256	.5256	.5087
3	.6613	.6443	.6443	.5935	.5256	.5426	.5256
4	.7122	.8309	.6783	.7122	.5426	.5765	.5765
5	1.0004	.7122	.8478				
6	1.1869	1.0174	1.1191				
7	1.5261	1.3226	1.3735				
8	1.7465	1.4746	1.5261				
9	2.0348	1.1022	1.1869				
11				1.1869	1.3395	.9835	1.0174
12				1.2717		1.1022	1.1022
13				1.3056		1.0852	1.153
14				1.1869		1.0343	1.0174
15				1.17	1.4413	1.0174	1.0174
16	.6104	.6443	.8478	1.1022	1.3565	.9496	1.0174
17	.7122	.6783	.9326	1.0004	1.4752	1.0513	1.1022
18	.9326	.78	.9326	.8309	1.5261		1.1022
19	.8478	.8478	.9156	.763	.8478	.8478	.9326
20	.763	.7461	.8987	.7461	.763	.78	.8478
21	.6783	.6783	.8478	.6783	.6783	.7122	.8139
22	.6443	.6104	.8478	.6104	.5935	.6783	.763
23	.5935	.5765	.6783	.5426	.5765	.6104	.5935
24	.6443	.5087	.5426	.5087	.5426		.5765
Max	2.0348	1.4746	1.5261	1.3056	1.5261	1.1022	1.153
Min	.5935	.5087	.5426	.5087	.5256	.5256	.5087
Avg	.9213	.7950	.8855	.8554	.8851	.8150	.8450

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134057 / 33/11 KV IDOLI SSTN

Feeder No / Name : 202 / PATODA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7888	.7888	.7628	.5853	.5853	.7316	.5853
2	.7888	.8145	.7796	.5975	.5853	.6219	.6219
3	.823	.8869	.8328	.6348	.6516	.5853	.5853
4	.8573	.8775	.8859	.6283	.6584	.7316	.6584
5	.9945	.9313	1.0229				
6	1.2003	.9816	1.0923				.6201
7	1.2346	1.0454	1.2403				
8	1.2689	1.2403	1.3289				
9	1.3032	1.2403	1.0631				
11					1.2437	1.0974	.8962
12				1.086	1.134	1.3169	1.0974
13				1.2308	1.0974	1.4632	1.134
14				1.267	1.0974	1.3169	1.2437
15				1.3535	1.0425	1.2127	1.2071
16		.7011	.7095	1.2308	1.0974	1.2071	1.262
17	.8328	.7888	.7023	1.267	1.1706	1.134	1.2437
18	.9214		.6219	1.2308	1.0974	1.0288	1.2437
19	.7802	.7164	.7133	.6584	.8688	.7316	.5487
20	.7011	.6805		.6154	.6859	.5853	.5853
21	.6661	.6268	.6584	.6878	.695	.5487	.6219
22	.6836	.6379	.6219	.6584	.6219	.5853	.5853
23	.6984	.6556	.6219	.6348	.6584	.6219	.695
24	.6516	.7186	.7164	.5853	.6219	.6661	.5853
Max	1.3032	1.2403	1.3289	1.3535	1.2437	1.4632	1.262
Min	.6516	.6268	.6219	.5853	.5853	.5487	.5487
Avg	.8938	.8431	.8455	.8795	.8674	.8992	.8432

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134057 / 33/11 KV IDOLI SSTN

Feeder No / Name : 203 / IDOLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9259	.8589	.8495	1.1203	1.5927	1.9387	.8962
2	.9602	.8682	.8596	1.0608	1.2803	1.9022	1.2986
3	1.0288	.9313	.8417	1.134	1.3169	2.0119	1.307
4	1.0631	.9134	.8505	1.086	1.2437	2.1582	1.3169
5				1.4842	2.0119	2.2314	1.2803
6				1.531	2.7435	2.5423	1.1946
7				2.0119	2.5606	2.5606	1.4632
8				2.1216	2.3045	2.4874	1.5364
9				2.7801	2.3411	2.5057	1.6278
11	2.1262	2.6642	2.2018		.0187		
12	2.6467	.3467	2.7759				
13	2.6006	.4681	2.7984				
14	2.6526	1.7187	2.6886				
15	2.5892	2.2857	2.7069				
16	2.6292	2.6353	2.524	1.0974	1.9022		1.3032
17	2.516	2.6353	2.7149	1.6095	1.9728	1.134	1.3394
18	2.4097	1.949	1.9765	1.9936	1.7558	1.0974	1.3756
19	1.0631	1.1641	1.2696	1.7924	1.701	1.0631	1.5708
20	.9671	1.086	1.134	1.4998	1.3443	1.0974	1.3169
21		1.0679	1.1157	1.39	1.3352	1.0974	1.3535
22	.8238	.9745	1.0242	1.3352	1.2803	1.134	1.2803
23	.7973	.964	.823	1.2437	1.2437	1.0974	1.134
24	.9088	.8063	.8859	.8779	1.0985	1.2071	1.0608
Max	2.6526	2.6642	2.7984	2.7801	2.7435	2.5606	1.6278
Min	.7973	.3467	.823	.8779	.0187	1.0631	.8962
Avg	1.6887	1.3521	1.6689	1.5094	1.6341	1.7215	1.3142

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134057 / 33/11 KV IDOLI SSTN

Feeder No / Name : 204 / express water supply  
INDUSTRIA Feeder KV- 11 /  
OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0181	.0181	.0189	.0187	.0183	.0187
2	.0171	.0181	.0177	.0189	.0183	.0187	.0187
3	.0171	.0181	.0177	.0189	.0183	.0187	.0183
4	.0171	.0177	.0177	.0189	.0183	.0187	.0183
5	.0171	.0181	.0173	.0189	.0183	.0187	.0183
6	.0171	.0177	.0177	.0189	.0183	.0171	.0187
7	.0171	.0181	.0179	.0189	.0183	.0183	.0187
8	.0171	.0179	.0175	.0189	.0187	.0185	.0171
9	.0171	.1433	.0179	.0189	.0183	.0187	.0187
10	.1075	.124	.0179			.0187	.0187
11	.1433	.1227	.0179		.0185	.0187	.0187
12	.1402	.0181	.0181	.0189	.0187	.0187	.0187
13	.1402	.1227	.0189	.0189	.0187	.0187	.0187
14	.1402	.1227	.0189	.0189	.0183	.0183	.0187
15	.1417	.0177	.0189	.0189	.0187	.0187	.0183
16	.1402	.0177	.0189	.0189	.0187	.0187	.0185
17	.1227	.0177	.0189	.0189	.0187	.0187	.0183
18	.0177	.0179	.0189	.0189	.0187	.0187	.0181
19	.0179	.0181	.0189	.0189	.0187	.0183	.0187
20	.0179	.0181	.0189	.0189	.0187	.0183	.0183
21	.0181	.0181	.0189	.0189	.0187	.0187	.0183
22	.0181	.0179	.0189	.0189	.0187	.0183	.0185
23	.0181	.0181	.0189	.0189	.0187	.0171	.0187
24	.0171	.0179	.0179	.0189	.0183	.0183	.0183
Max	.1433	.1433	.0189	.0189	.0187	.0187	.0187
Min	.0171	.0177	.0173	.0189	.0183	.0171	.0171
Avg	.0565	.0407	.0183	.0189	.0185	.0184	.0185

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134070 / Talni

Feeder No / Name : 201 / 11 KV DEVTHANA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.8402		1.4232	1.166	1.2517	1.3375
2	.6344	.8402		1.4746	1.2346	1.286	1.4918
3	.6687	.8916		1.5432	1.3375	1.3546	1.5089
4	.703	.9431		1.5775	1.4403	1.3717	1.6461
5				1.6632	1.6461	1.4918	1.8176
6				1.7147	1.7318	1.9547	1.8861
7				1.7833	1.9719	1.989	1.8861
8				1.8861	2.0748	1.9204	1.7833
9				1.8519	1.9547	1.8861	1.749
11	1.9376	2.0919					
12	2.1776	2.2462					
13		2.2977					
14	1.7833	2.1948					
15	1.4975	2.1776					
16	1.8861	2.1776	2.0062	.7716	.8745	.8573	.8745
17	1.9719	2.1948	2.3148	.9088	.8916	1.0802	.9774
18	1.989	1.9719	2.0748	.9945	.9945	1.2346	1.0288
19	.9945	1.046	1.0974	1.1145	1.166	1.1831	1.166
20	.823	.9088	1.0117	.9945	.9259	1.0631	.9945
21	.9431	.8916	.9259	.9774	.8745	1.0288	.9431
22	.9088		.8745	.8916	.8573	.9602	.823
23	.8402		.8402	.8402	.8059	.8916	.8059
24	.7545	.8402		1.3717	.823	1.046	1.046
Max	2.1776	2.2977	2.3148	1.8861	2.0748	1.989	1.8861
Min	.6344	.8402	.8402	.7716	.8059	.8573	.8059
Avg	1.2470	1.5346	1.3932	1.3213	1.2651	1.3251	1.3203

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134070 / Talni

Feeder No / Name : 203 / 11 KV TALNI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4403	.6859	.7202	.6859	.4801	.4801	.4458
2	1.5432	.7716	.7716	.703	.4801	.463	.4973
3	1.6632	.8745	.8573	.7202	.5658	.463	.5487
4	1.7318	1.0117	1.0288	.7545	.703	.4801	.5316
5	1.8861	1.1145	1.3717				
6	2.0748	1.4575	1.5432				
7	2.2119	1.8519	1.8004				
8	1.9547	2.0576	1.9033				
9	1.9033	1.7661	1.8004				
11					1.286	1.3032	1.0288
12				1.7318	1.3032	1.2689	1.3032
13				1.749	1.286	1.286	1.166
14				1.7147	1.2689	1.2003	1.2174
15				1.5089	1.2517	1.0802	1.1488
16		.9088	.7545	1.286	1.2689	1.1831	1.1488
17	1.166	.9259	.8745	1.4403	1.3375	1.2689	1.2346
18	1.166	1.1145	1.0288	1.2517	1.2689	1.3032	1.3375
19	1.0974	1.0802	1.1145	.9774	.9259	.9088	.9602
20	.8745	.8402	1.046	.7373	.7373	.7888	.7373
21	.7373	.6859	.9945	.583	.6173	.6516	.6687
22	.6173	.6173	.9602	.5316	.5487	.583	.583
23	.5316	.5316	.8745	.4801	.4973	.5144	.4973
24	1.3889	.6516	.6859	.7888	.463	.4458	.4458
Max	2.2119	2.0576	1.9033	1.749	1.3375	1.3032	1.3375
Min	.5316	.5316	.6859	.4801	.463	.4458	.4458
Avg	1.4111	1.0526	1.1184	1.0379	.9050	.8707	.8612

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134071 / pangari gosavi

Feeder No / Name : 201 / pangari 11 kv

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.3429	.5256	.3429	.3086		.3086
2	.4287	.3772	.5138	.3772	.3086		.3086
3	.4287	.6516	.5243	.3429	.3086		.3086
4	.5144	.9945	.5426	.2572	.3086	.5256	.3429
5	.6001	1.1145	.4816				
6	.7716	1.2003					
7	1.4575	1.2346	.8987				
8	1.3717	1.2346	1.1191				
9	1.5089	1.286	1.2003				
11				.9431		1.1869	.8573
12				1.2003		1.2209	.8573
13				1.2003		1.1022	.9431
14				1.2003		.9431	
15				1.1145		.9431	
16		.5944	.5316	1.0288		.8573	
17	.7716	.6783	.5144	1.0288	.5935	.8573	
18	.3429		.3429	.8573	.5935	.7716	
19	.3772		.3772	.4801	.3561	.4801	
20	.4115		.4115	.4287	.5087	.3772	
21	.4287		.3429	.3429	.5935	.3429	
22	.4801	.5256	.3601	.3429		.3429	
23	.2229	.5256		.3429		.3086	
24	.4287	.2572	.5087	.3429	.3429	.5256	.3086
Max	1.5089	1.286	1.2003	1.2003	.5935	1.2209	.9431
Min	.2229	.2572	.3429	.2572	.3086	.3086	.3086
Avg	.6455	.7870	.5747	.6763	.4223	.7190	.5294

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134071 / pangari gosavi

Feeder No / Name : 202 / wai

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.2572	.4409	.6001	.4801		.4801
2	.3429	.3086	.431	.7716	.4801		.4801
3	.3429	.3429	.426	.6001	.4801		.4801
4	.3429	.3086	.4748	.6001	.5144	.6687	.5144
5					.5144		.6001
6				.4287	.6859		
7				.8573	.9431		.9431
8				.9945	1.286		1.286
9				.8916	1.3717		1.0288
10			1.286				
11	.5144	1.1469	1.406				
12	.7888	1.2039	1.3375				
13	.7716	1.2039	1.4232				
14	.8916	1.1869	1.406				
15	1.0288		1.286				
16	.6344	1.1869	1.1831	.3429		.4287	
17	.6859		1.2003	.4287	.6783	.4287	
18	.3086	1.1869	1.2003	.4287		.4287	
19	.2401			.4287	.5256	.4287	
20			.3772	.3772	.5256	.3772	
21	.2572			.3429	.4239	.3772	
22	.3086		.3429	.3429		.3429	
23	.3086			.3429		.3429	
24	.3429	.2572	.4578	.3429	.5144	.4917	.463
Max	1.0288	1.2039	1.4232	.9945	1.3717	.6687	1.286
Min	.2401	.2572	.3429	.3429	.4239	.3429	.463
Avg	.4972	.7809	.9174	.5366	.6731	.4315	.6973



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134071 / pangari gosavi

Feeder No / Name : 203 / 11 kv kathala feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.8916	.5087	.3429	.3429		.2915
2	.5144	.7716	.4973	.3772	.3429		.2915
3	.5144	.6516	.4915	.4287	.3429		.2915
4	.6001	.6001	.5087		.3429	.5256	.3429
5	.6859	.8916	.4752				
6	.8573	1.166	.4755				
7	1.2003	1.0631	.763				
8	1.3443	1.286	1.1361				
9	1.2346	1.286	1.1361				
11				1.1145		1.1869	
12				1.286		1.4255	1.0288
13				1.2003		1.3735	1.1145
14				1.2003		1.286	
15				1.2003		1.2003	
16	.2401	.5935	.7202	1.2003		1.0288	
17	.3086	.6613	.3429	1.1145		1.0288	
18	.2572		.3429	.9431	1.1022	.8573	
19	.3429		.3429	.4287	.5087	.463	
20	.3086		.3772	.3944	.5935	.3772	
21	.3429		.4115	.3429	.5256	.3429	
22	.3772		.3429	.3429		.3429	
23				.3429		.3429	
24	.5144	.2572	.5256		.3429	.5256	.2915
Max	1.3443	1.286	1.1361	1.286	1.1022	1.4255	1.1145
Min	.2401	.2572	.3429	.3429	.3429	.3429	.2915
Avg	.5975	.8433	.5528	.7662	.4938	.8205	.5217

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134004 / 33/11 KV PARTUR

Feeder No / Name : 201 / TOWN-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5144	.5144		.4801	.5144	
2		.5144	.5144		.4801	.6001	
3		.5144	.6001		.4801	.6859	
4		.583	.6859		.5487	.7716	
5		.6687	.8573		.7202	.8573	
6	1.2689	1.1145				1.1317	
7	1.749	1.6461		1.5089		1.6289	
8	2.0233	1.8176	1.869	1.749	1.869	1.6975	1.6118
9	1.9547	1.7147	1.7833	1.5947	1.5604	1.6118	1.5775
10	1.6118	1.4746	1.5775		1.3032	1.4232	1.406
11	1.5432	1.166	1.3717	1.2517	1.0974	1.2003	1.3032
12	1.4232	.9945	1.1317	1.0288	.7716	.9088	1.1145
13		.8916	.7888	.8916		.823	.8573
14	.8573	.7545	.7202	.7545	.7202		.7373
15	1.0479	.7888	.6859	.7716	.6516		.7202
16		.8916	.6859	.823	.7716		.9259
17	1.105	1.1145	1.1317	1.2003	1.0802		1.166
18	1.5432	1.4232	1.3889	1.4403	1.3546		1.406
19	1.4289	1.2346	1.2689	1.3203	1.3032	1.6289	1.286
20	1.1431	1.0288	1.2003	1.0288	1.0117		1.0631
21	.9526	.7888	.8402	.8573	.7888	1.1145	.8573
22	.7373	.6859	.6687	.6859	.6687	.6344	.6687
23	.6001	.583		.583	.5316		.5144
24	.4973	.5487	.5316	.4973	.5144	.463	.4801
Max	2.0233	1.8176	1.869	1.749	1.869	1.6975	1.6118
Min	.4973	.5144	.5144	.4973	.4801	.463	.4801
Avg	1.2639	.9774	.9913	1.0581	.8908	1.0409	1.0409

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134004 / 33/11 KV PARTUR

Feeder No / Name : 202 / TOWN-II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7202	.7545		.7202	.6859	
2		.7202	.8059		.7202	.7716	
3		.7545	.9431		.7202	.8573	
4		.823	.9431		.7716	.8573	
5		.8573			.8916	1.0288	
6	1.2346	1.2346				1.2174	
7	1.9719	1.8347		1.5604	2.0748	1.9376	1.8861
8	2.1776	2.2634	2.0062	2.0405	2.1434	2.1776	
9	1.9547	2.0576	2.0576	2.0233	1.5947	2.0062	1.7833
10	1.8519	1.749			1.5261	1.7661	1.6118
11	1.6804	1.4746	1.9204	1.6804	1.7661	1.5089	
12	1.5261	1.406	1.5432	1.4918	1.4575	1.286	1.4403
13	1.3889	1.2346	1.3032	1.3375		1.2517	1.0631
14	1.3203	1.1317	1.2689	1.3203	1.5432	1.166	.8745
15	1.5242	1.1317	1.166	1.286	1.0974	1.1317	.8916
16	1.7147	1.2003	1.2003	1.2689	1.1145	1.1145	1.2003
17		1.3546	1.3203	1.4746	1.4918	1.5432	1.4403
18	1.9243	1.6632	1.5775	1.749	1.7147	1.7147	1.4232
19		1.7147	1.5432	1.7147	1.7147	1.7147	1.4403
20	1.9433	1.3717	1.3717	1.3717	1.3546		1.5432
21	1.3717	1.1317	1.0974	1.2003	1.1317	1.4575	1.2346
22	1.0117	.9774	.9259	1.0288	.9431	.9259	.9602
23	.823	.8059		.823	.7716		.7716
24	.7373	.7373	.7373	.6859	.7545	.6687	.6516
Max	2.1776	2.2634	2.0576	2.0405	2.1434	2.1776	1.8861
Min	.7373	.7202	.7373	.6859	.7202	.6687	.6516
Avg	1.5386	1.2646	1.2887	1.4151	1.2736	1.3086	1.2635

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134004 / 33/11 KV PARTUR

Feeder No / Name : 203 / SAIBABA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5089			1.3717	.2572	
2		1.5775			2.0576	.5144	
3		1.6804			2.0576	.5144	
4		1.8347			2.0919	.6001	
5		1.9719			2.4177	.7716	
6	2.5034	2.452				.8916	
7	2.4863	2.915		3.035	3.3265	1.1488	
8	2.8978	3.2922	2.5549	1.4746	1.6289	1.166	1.166
9	2.8292	2.4348	2.4863	1.4232	.743	1.2346	1.2003
10	.9774	1.1812	1.6194		.6097	.5716	1.5089
11	2.0576	2.2634	2.7092	2.1262	.3239	.362	
12		2.2634	2.4863	2.6063	1.4403	1.9719	2.8121
13	1.4403	2.1262	2.2291	2.6063		2.7092	2.9492
14	1.5432	1.7833	1.989	2.5034	1.6289	.1715	2.7778
15	1.3717	2.0576	2.0576	2.9664	2.2805	2.7092	2.6749
16	1.2003	2.1262	2.0576	2.7949	2.1434	3.1036	2.6749
17	1.166	2.2291	2.2291		2.6063	3.3779	2.915
18	2.0919	2.4006	2.7435	2.3663	.5144	2.9321	2.5377
19	1.9052	2.2977	1.6575	2.0919	.583	2.0233	2.2291
20	2.5149	1.9719	1.5242	1.9204	.4115		2.0062
21	1.829	1.749	1.8671	1.8176	.2743	1.7147	1.8347
22	1.6804	1.6289	1.7337	1.6289	.0286	1.7909	1.3889
23	1.4746	1.4575		1.4918	.2058		.1505
24	1.6766	1.406	1.3717	1.5242	1.406	.2058	1.6004
Max	2.8978	3.2922	2.7435	3.035	3.3265	3.3779	2.9492
Min	.9774	1.1812	1.3717	1.4232	.0286	.1715	.1505
Avg	1.8692	2.0254	2.0823	2.1486	1.3705	1.3974	2.0267

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134004 / 33/11 KV PARTUR

Feeder No / Name : 204 / KAWAJAWALA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4458			.5144	.6001	
2		.4458			.8573	.6859	
3		.4801			.8573	.7716	
4		.5144			.8916	1.0288	
5		.6001			.9774	1.0288	
6	.8192	.6173				1.1317	
7	.3772	.3772		.6859	1.1831	1.3032	
8	.3772	.3239	.362	1.0974	1.4232	1.6461	.9945
9	.4801	.4954	.4191	1.2689	.4763	1.6461	1.6804
10	.3429	.2667	.5525		.6478		.381
11		1.5432	1.5432	.0476	.3239	.3429	.4001
12	.9774	1.749	1.8176	.0324	.3239	.3239	.4001
13	1.7833	1.749	1.8347	.0248			.381
14	1.749	1.7147	1.749	.2572	.4191	.3048	.3429
15	1.7147	1.749	1.7147	.0343	.2667	.3239	.381
16	1.7318	1.7147	1.749	.0343	.3429	.2915	.4001
17	1.7147	1.8004	1.4575	.362	.0438	.4001	.381
18	1.4918	1.406	1.166	.362	.3944	.2858	.5525
19	1.5242	.0476	.6097	.5906	.5144	.5906	.8192
20	.8573	.0762	.5716	.8002	.7202		.8573
21	.6668	.0705	.6287	.6668	.6173	.5335	.6478
22	.5144	.5487	.5335	.5906	.0591	.5906	.0572
23	.4458	.0495		.5525	.0514		.0495
24	.5144	.4287	.4287	.4763	.5335	.0495	.4954
Max	1.7833	1.8004	1.8347	1.2689	1.4232	1.6461	1.6804
Min	.3429	.0476	.362	.0248	.0438	.0495	.0495
Avg	1.0046	.8006	1.0711	.4638	.5654	.6940	.5424

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134004 / 33/11 KV PARTUR

Feeder No / Name : 205 / ANANDWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2689			.8745	.8573	
2		1.3032			.8573	.0953	
3		1.3032			.8573	.0953	
4		1.5089			.9602	.1048	
5		1.7661			1.286	.1143	
6	2.1091	2.0919				.1467	
7	2.6063	2.5892		1.4861	1.0117	.1619	
8	3.1893	3.1893	3.0007	1.0098	.9088	.1448	1.1812
9	2.915	2.8292	2.9492	.7545	.9145	1.0802	
10	.6516	.9145	.9145		.8192		1.105
11	.6001	.8002	.6097	2.5206	1.2689	1.8176	1.6118
12	.6173	.7049		3.2579	1.6289	2.2977	2.0062
13	.6516	.6097		3.3436		2.6235	1.9547
14	.6001	.5716	.8383		1.6804	2.4177	1.8004
15	.7621	.5716	.8383	3.4294	1.3889	2.1434	.9259
16	.8573	.7621	.9145	3.3265	1.3203	2.1262	1.0288
17		.0914	.9907		1.4746	2.0233	1.749
18	1.0669	.1067		3.0007	.141	1.9719	1.7147
19	1.1431	.1562	1.6575	1.4746	.1162	1.5432	1.2346
20	1.467	.1562	1.5242	1.2003	.1219		1.1317
21	1.2955	.1315	1.3336	1.166	.1105	1.105	1.0631
22	1.0117	.0972	1.2003	1.0631	.0991	1.2574	.1029
23	.8916	.0914		.9774	.0953		.0953
24	1.105	.9259	.0857	1.0479	.9088	.0876	.9907
Max	3.1893	3.1893	3.0007	3.4294	1.6804	2.6235	2.0062
Min	.6001	.0914	.0857	.7545	.0953	.0876	.0953
Avg	1.3078	1.0225	1.2967	1.9372	.8566	1.1531	1.231

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134004 / 33/11 KV PARTUR

Feeder No / Name : 206 / INDUSTRIAL  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.197			.12	.2401	
2		.197			.12	.2401	
3		.197			.12	.2401	
4		.2149			.12	.2401	
5		.2149			.12	.2401	
6	.1143	.2149				.2229	
7	.0686	.1791		.1715	.1254	.2058	
8	.12	.12	.0857	.0762	.0716	.1029	.1905
9	.1886	.12	.0857	.0857	.1143	.12	.12
10	.2401	.1372	.0686		.0953	.1029	.1372
11	.2229	.1715	.0514	.0686	.1334	.0857	.1372
12	.2401	.1715	.0686	.0686	.0953	.0514	.12
13	.1886	.12	.0686	.1029		.0857	.1029
14	.1715	.1715	.0686	.0857	.1143	.1029	.12
15	.1524	.1715	.0686	.0514	.1143	.1029	.1029
16	.1524	.1029	.0686	.0514	.1143	.1029	.12
17	.1334	.1715	.0762	.0686	.1029	.1143	.1029
18	.1715	.12	.0953	.1029	.0857	.1143	.12
19	.1143	.1029	.0953	.1029	.0857	.1143	.1029
20	.1143	.1029	.0762	.1029	.12		.12
21	.2477	.1372	.1524	.12	.2572	.1143	.2058
22	.1791	.1372	.0762	.12	.2401	.2477	.2229
23	.2058	.1372		.12	.2401		.2401
24	.1143	.197	.1372	.1524	.12	.2401	.2286
Max	.2477	.2149	.1524	.1715	.2572	.2477	.2401
Min	.0686	.1029	.0514	.0514	.0716	.0514	.1029
Avg	.1653	.1586	.0840	.0972	.1286	.1560	.1467

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134004 / 33/11 KV PARTUR

Feeder No / Name : 207 / 11 KV AMBA FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2					.8402	.5144	
3					.8402	.6001	
4					.8573	.6859	
5					.8916	.7716	
6						.9088	
7				.8745	.9431	.5658	
8				1.1317		.823	.9088
9				1.1488		.7545	1.0288
11	1.6461	1.5432	1.4918				
12	1.8861	1.6118	1.6118				
13	1.8004	1.869	1.8519				
14	1.9547	1.749	1.8347				
15	1.7147	1.6289	1.6804				
16	1.8004	1.4403	1.6804				
17	1.749	1.5432	1.5604				
18	1.5604	1.4575	1.0974				
19						.0381	
Max	1.9547	1.869	1.8519	1.1488	.9431	.9088	1.0288
Min	1.5604	1.4403	1.0974	.8745	.8402	.0381	.9088
Avg	1.7640	1.6054	1.6011	1.0517	.8745	.6291	.9688



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134004 / 33/11 KV PARTUR

Feeder No / Name : 208 / 11KV water supply express SHEDDABLE RURAL  
feed Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0716			.0514	.0514	
2		.0716			.0514	.0514	
3		.0716			.0514	.0514	
4		.0716			.0514	.0514	
5		.0716			.0514	.0514	
6	.0572	.0716			.0514	.0514	
7	.0686	.1791		.0191	.0716	.0686	.0381
8	.12	.12	.0514	.0191	.1075	.1029	
9	.12	.12	.1029	.1029	.1143	.1029	.0857
10	.12	.12	.1029		.1143	.1029	.1029
11	.12	.1372	.12	.1029	.1334	.1029	.1029
12	.0686	.12	.1372	.1029	.0953	.0514	.1029
13	.1029	.12	.1372	.1029		.0171	.12
14	.1029	.12	.1372	.0343	.0953	.0171	.1029
15	.0953	.12	.1372	.0686	.0171	.0171	.0686
16	.1143		.1372	.0343	.0572	.0171	.1029
17	.0953	.1029	.1334	.0343	.0686	.0953	.12
18	.1524	.0343	.0953	.0343	.0686	.0953	.12
19	.0953	.0514	.0381	.0514	.0686	.0381	.1029
20	.0953	.0514	.0762	.0514	.12		.0686
21	.0953	.0343	.0762	.0514	.0514	.0381	.0686
22	.0895	.0343	.0191	.0514	.0514	.0381	.0514
23	.2149	.0343		.0514	.0514		.0514
24	.0572	.0716		.0191	.0514	.0514	.0381
Max	.2149	.1791	.1372	.1029	.1334	.1029	.12
Min	.0572	.0343	.0191	.0191	.0171	.0171	.0381
Avg	.1045	.0870	.1001	.0548	.0725	.0575	.0852

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134010 / 33/11 Kv ASHTI

Feeder No / Name : 201 / ASHATI TOWN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3944	.4801	.3429	.3772	.3601	.463
2	.3772	.5144	.4801	.3772	.3601	.4287	.5144
3	.4287	.7373	.5487	.4287	.4801	.5144	.5316
4	.5487	.8059	.6516	.583	.5487	.7202	.5658
5	.7202	.8573	.7202	.6687	.6001	.9602	.6859
6	.8573	.8402	.9945	.7373	.8059	1.0631	.703
7	1.1145	.9774	1.0631	.9945	1.1145	1.1488	1.0288
8	1.1317	1.0288	1.0802	1.0802	1.1488	1.2174	1.1488
9	1.0288	.8573	1.0974	1.0974	1.0631	1.0802	1.1831
10	1.0631	.9214	.9431	.9945	.9602	.9259	.815
11	.9259	.7701	.823	.823	.823	.8916	.7202
12	.7545	.724	.7545	.9259	.7202	.823	.6379
13	.6344	.7087	.6859	.703	.6173		.6201
14	.6173	.1715	.6173	.6173	.583	.6516	.5959
15	.5316	.5316	.6516	.6001	.6516	.5316	.5847
16	.823	.6733	.6859	.703	.6859	.6001	.6805
17	.9088	.8859	.7888	.7888	.823	.7545	.7888
18	.8745	1.0059	.8573	.9088	.9602	.8916	.8764
19	.8573	.815	.8916	.7716	.823	.8059	.8596
20	.6859	.7087	.6859	.6687	.7202	.6516	.7442
21	.5316	.5792	.6001	.5144	.5316	.6173	.5853
22	.4287	.4607	.4458	.4115	.4801	.5487	.4252
23	.3944	.4887	.3772	.3772	.3772		.3403
24	.3772	.3772	.463	.3772	.3601	.3601	.3772
Max	1.1317	1.0288	1.0974	1.0974	1.1488	1.2174	1.1831
Min	.3429	.1715	.3772	.3429	.3601	.3601	.3403
Avg	.7066	.7015	.7245	.6873	.6923	.7521	.6865

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134010 / 33/11 Kv ASHTI

Feeder No / Name : 202 / KARALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6859	.823	.7621	.7621	1.0974	.9602
2	.6859	.8145	.8402	.7926	.8383	1.2803	1.0669
3	.7716	1.0317	.8402	.9145	.9755	1.4632	1.1888
4	.9259	1.086	.8916	1.0364	1.0669	1.5242	1.2346
5	1.0631	1.2127	.9945	1.0974	1.2498	1.6766	1.326
6	1.2346	1.267	1.0631	1.2193	1.3717	1.7985	1.3717
7			1.166	1.2498	1.829	1.8595	1.8442
8	1.2003		1.1488	1.8595	2.0576	1.89	1.5242
9	1.166	1.1317		1.7528	1.9052	1.8138	
10	.7716	1.0288	.6859	.823	.7202	.6859	
11	1.5546	1.5083	1.6766	.6001	.583	.5487	
12	1.6004	1.7652	2.0119	.4801	.5487	.5144	
13	1.6309	1.7976	2.0576	.4115	.5144	.4973	
14	1.7223	1.8842	1.9052	.4287	.4973	.4287	
15	1.829	1.9919	1.9719	.4287	.4973	.463	
16	1.829	2.1052	1.829	.4801	.4973	.463	.7712
17	1.7375	2.1548	2.0576	.6859	.7202	.6173	.8505
18	1.6766	2.1365	1.6309	1.0288	1.0631	.8059	1.0566
19	1.046	1.1871	1.1488	1.0631	1.1317	.7373	1.2357
20	.9602	1.0317	.8573	.9259	.8916	.6859	.9745
21	.8402	.8859	.823	.7888	.7716	.6344	.7773
22	.7888	.7442	.7202	.6859	.6859	.6173	.815
23	.703	.7087	.6097	.6097	.6344		.7973
24	.6516	.6687	.7202	.6859	.823	.7468	.5944
Max	1.829	2.1548	2.0576	1.8595	2.0576	1.89	1.8442
Min	.6516	.6687	.6097	.4115	.4973	.4287	.5944
Avg	1.1772	1.3104	1.2380	.8671	.9432	.9935	1.0817

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134010 / 33/11 Kv ASHTI

Feeder No / Name : 203 / WAHEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.7783	1.1919	.9145	1.0669	1.1888	1.2193
2	.7202	.9955	1.2403	.9755	1.1431	1.4022	1.3413
3	.8573	1.1403	1.2403	1.0669	1.1888	1.6766	1.4022
4	.9945	1.2308	1.2226	1.2498	1.2803	1.7985	1.5242
5	1.0974	1.2851	1.2971	1.3717	1.3717	1.8595	1.5546
6	1.2003	1.3575	1.3321	1.4937	1.5242	2.1643	1.5851
7	1.286	1.3575	1.3565	1.6309	2.0881	2.4844	1.8442
8	1.2003	1.3213	1.2346	1.9052	2.5911	2.4996	2.0271
9	1.166	.9774	1.2094	1.6004	2.5149	2.3624	2.3624
10		1.0631	1.0288	.8573	.8745	.9602	1.2094
11	1.8747	2.0645	1.5242	.7888	.7716	.7716	.9214
12	1.829	2.6397	2.21		.703	.6859	.6626
13	1.8747	2.5617	2.3624	.823	.6687	.6344	.6379
14	1.9509	2.2708	2.4691	.6173	.6344	.5658	.6447
15	2.4387	2.5911	2.4996		.703	.6001	.6201
16	2.3929	2.7515	1.9814	.6516	.7545	.6859	.7343
17	2.4539	2.6235	2.21	.8573	.7373	1.1317	.964
18	2.21	2.3739	1.9814	.7373	.7545	1.2174	.9991
19	.8573	1.1871	.9945	1.1145	1.0117	1.2003	1.1919
20	.8745	1.1694	1.0631	.9774	1.1317	.9431	1.1694
21	.8916	1.0985	.8916	.8916	1.046	.8573	1.1104
22	.823	.9593	.7716	.823	.9945	.823	.9391
23	.7888	.8859	.6097	.7621	.9259	.7888	.8238
24	.6516	.8145	1.0631	.8383	.9907	1.0364	.9602
Max	2.4539	2.7515	2.4996	1.9052	2.5911	2.4996	2.3624
Min	.6516	.7783	.6097	.6173	.6344	.5658	.6201
Avg	1.3530	1.5624	1.4577	1.0431	1.1446	1.2641	1.1854

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134010 / 33/11 Kv ASHTI

Feeder No / Name : 204 / WATER SUPPLY FEEDER  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	24-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)
16	2.2291	.0701
Max	2.2291	.0701
Min	2.2291	.0701
Avg	2.2291	.0701

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134010 / 33/11 Kv ASHTI

Feeder No / Name : 205 / RAIGWAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0517	1.1126	1.0364	.4801	.5144	.4801	.5847
2	1.1431	1.2651	1.1888	.5144	.5487	.6173	.6201
3	1.2498	1.4632	1.5546	.6001	.6859	.7202	
4	1.3717	1.5242	1.6461	.8059	.823	1.046	1.086
5	1.4784	1.5546	1.829	1.0288	1.0117	1.1831	1.1871
6	1.6004	1.6004	1.9052	1.2003	1.2003		1.2403
7	1.9052	1.6004	2.0729				
8	2.21	1.5851	2.0119	.7202	1.0288	.9259	1.0517
9	2.0119	1.8595	1.9052	.7716	1.166	1.0974	1.1568
10	.8573	.8413	.5144	.9088	.8916	.6344	.5316
11	.6001	.5973	.4801	1.9814	1.6156	1.5699	1.7604
12	.5316	.5138	.8688	2.5911	2.1643		2.1216
13	.4287		.3429	2.7435	2.271	2.3777	2.2043
14	.3772	.3898	.4877	2.5911	2.332	2.5606	2.1714
15	.3944	.4298	.4801	2.6673	2.2558	2.3167	2.2634
16	.5144		.5144	2.6216	2.1643	2.2862	2.1051
17	.5487	.7087	.583	1.9814	2.0729	2.2558	2.1956
18	.4973	.9568	.7716	1.9814	1.9509	2.0576	2.0622
19	.9774	.8859	.9602	.9602	.9945	.5144	.9391
20	.8402	.8859	.7888	.7888	.8402	.4458	.8682
21	.7373	.6201	.6859	.6687	.7373	.4801	.7164
22	.6687	.6878	.6173	.583	.6687	.5487	.567
23	.583	.6733	.5487	.4801	.5487	.5144	.5014
24	.9145	1.0212	.8688	.5144	.4287	.4801	.4973
Max	2.21	1.8595	2.0729	2.7435	2.332	2.5606	2.2634
Min	.3772	.3898	.3429	.4801	.4287	.4458	.4973
Avg	.9789	1.0353	1.0276	1.3124	1.2572	1.1958	1.2924

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134010 / 33/11 Kv ASHTI

Feeder No / Name : 206 / 11KV BHAGAWANNAGAR FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0857	.0686	.061	.1219	.1219	.1372
2	.0686	.0857	.0686	.0762	.1524	.1524	.1543
3	.0514	.1029	.0857	.0762	.1829	.1829	.1715
4	.0686	.1029	.0686	.1219	.2134	.2134	.1865
5	.0857	.1029	.0857	.1524	.2286	.2743	
6	.0857	.1029	.0857	.1829	.2591	.3201	.3601
7	.0857	.0857	.1029	.2286	.3353	.3353	.3521
8	.0857	.0686	.0857	.442	.4572	.2896	.3391
9	.0686	.0343	.0686	.381	.3963	.2896	.4807
10	.0514	.0857	.0514	.0514	.0343	.0514	.0532
11	.2896	.3222	.381	.0343	.0343	.0343	.0358
12	.4572	.4858	.4268		.0343	.0343	
13	.4877	.4973	.4877	.0171	.0343		
14	.4877	.4807	.4877	.0171	.0171		
15	.381		.4725	.0343	.0171		
16	.3048	.4752	.4877	.0171	.0171		
17	.2743	.4144	.4572	.0343	.0171	.0343	.0177
18	.3201	.4239	.4268	.0343	.0343	.0343	.0532
19	.1029	.0886	.0686	.0857	.0514		.0709
20	.1029	.1063	.0686	.0686	.0514	.0343	.0532
21	.12	.1063	.0514	.0686	.0514	.0343	.0514
22	.1372	.1063	.0514	.0514	.0514	.0343	.0354
23	.12	.0886	.061	.061	.0514	.0343	.0701
24	.0686	.1029	.0686	.0457	.0762	.0762	.0762
Max	.4877	.4973	.4877	.442	.4572	.3353	.4807
Min	.0514	.0343	.0514	.0171	.0171	.0343	.0177
Avg	.1815	.1981	.1987	.1019	.1217	.1359	.1499

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134010 / 33/11 Kv ASHTI

Feeder No / Name : 207 / 11KV Surumgaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3201	.4572	.2058	.1715	.2058	.2658
2	.3201	.381	.4877	.1715	.1886	.2058	.2835
3	.3658	.4115	.5792	.2058	.2058	.2401	.3439
4	.381	.4268	.6097	.2572	.2401	.2743	.3506
5	.4268	.4572	.6097	.3086	.2572	.3086	.3898
6	.4877	.503	.6401	.3429	.2572	.3429	.4477
7	.7468	.6859	.6859	.3086	.3429	.3601	.4252
8	1.0212	.8535	.6401	.2915	.3086	.3601	.4031
9	.9907	.7926	.6097	.2572	.2572	.3772	.7754
10	.2915	.2126	.1372	.2572	.2401	.2401	.2303
11	.4802	.2126	.12	.7621	.6401	.7011	.5792
12	.2229	.1791	.1029	.9755	.7316	.8383	.8619
13	.1715	.1629	.1372	1.1736	.7773	.9145	.8573
14	.1886	.2126	.1029	1.0669	.8078	.8993	.8648
15	.1886	.2126	.12	1.0364	.7773	.7773	.8718
16	.2401	.2149	.1372	.8535	.7621	.7621	.8402
17	.2572	.3012	.1715	.8383	.7011	.7164	.8139
18	.3772	.4525	.2572	.6554	.6706	.6554	.7122
19	.3772	.4075	.1886	.3429	.3601	.5144	.3898
20	.3086	.4075	.3258	.2915	.3258	.5144	.3189
21	.2915	.3012	.2915	.2915	.2915	.4973	.2454
22	.2401	.2303	.2572	.2572	.2572	.3429	.2149
23	.2229		.2058	.2401	.2229	.2058	.2058
24	.2743	.3048	.3658	.1715	.2058	.2058	.2229
Max	1.0212	.8535	.6859	1.1736	.8078	.9145	.8718
Min	.1715	.1629	.1029	.1715	.1715	.2058	.2058
Avg	.3824	.3758	.3433	.4818	.4167	.4775	.4964



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134017 / 33/11 Kv SATONA

Feeder No / Name : 201 / MAPEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5365	.4191	.4359	1.1233	.7545	.6371	.6539
2	.57	.4191	.4694	1.1065	.8383	.6706	.6874
3	.5868	.503	.4862	1.1401	.9221	.7042	.7209
4		.6874	.4527	1.0898	.9724	.7545	.788
5		.9389	.6874	1.0562	1.0898	.8886	.9724
6			.7377	1.0395	1.1401	.9892	1.0562
7		1.0059	.8718	1.073	1.1736	1.1401	1.1568
8		.9054	.9054	1.1568	1.2239	1.2407	1.2574
9		.5868	.5533	1.0227	1.0562	1.1904	1.291
10		.4359	.4694	.3185	.3688	.5197	.503
11	1.291	1.2407	1.1736	.285	.3521	.3018	.2347
12	1.291	1.4419	1.2071		.3018	.2683	.2515
13	1.3413	1.4083	1.2239	.3018	.2515	.285	.2012
14	1.3748	1.4586	1.1904	.3185	.2515	.2515	.1844
15	1.4586	1.358	1.2407	.3353	.285	.2347	.218
16	1.4251	1.3077	1.2574	.4862	.3185	.285	.2347
17	1.3748	1.3077	1.2574	.5868	.3688		.2012
18	1.3077	1.3245	1.1568	.7209	.5533	.7545	.503
19	.7377	.6874	.6036	.6036	.6706	.6874	.57
20	.5533	.6203	.6371	.5365	.5365	.6203	.6371
21	.4527	.5365	.4862	.5197	.4191	.4862	.5087
22	.4024	.4862	.3856	.503	.3688	.3521	.4748
23	.3688	.3688	.3353	.5365	.3353	.3353	.4917
24	.503	.3856	.4024	1.073	.5533	.6371	.6203
Max	1.4586	1.4586	1.2574	1.1568	1.2239	1.2407	1.291
Min	.3688	.3688	.3353	.285	.2515	.2347	.1844
Avg	.9162	.8623	.7761	.7362	.6294	.6189	.6008

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134017 / 33/11 Kv SATONA

Feeder No / Name : 202 / SATONA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4694	.4191	.4527	.8048	.6036	.4694	.4862
2	.5365	.4359	.4527	.8383	.6371	.4694	.57
3	.5533	.4862	.4862	.8215	.6706	.503	.5197
4	.5868	.6539	.6371	.8551	.7042	.57	.6371
5	.6036	.8718	.8718	.9054	.7377	.6203	.7377
6		1.0562	1.0227	.9221	.7545	.0655	.9892
7		1.1065	1.0898	.8886	.9221	.9724	1.0227
8		.9221		.8215	.9724	.8718	1.0562
9		.8718		.8383	.8886	.8551	1.0562
10	.4862	.8383	.7712	.7712	.6036	.7042	.6874
11	.7712	.788	.8048	.57	.5197	.5365	.3353
12	.8383	.7377	.8215	.5197	.4191	.4862	.3688
13	.8048	.7545	.8215	.4862	.3688	.4359	.2012
14	.7712	.7042	.9556	.3521	.4191	.4527	.1844
15	.7712	.7712	.9389	.4862	.4527		.2035
16	.8048	.788	.9389	.503	.6036	.5197	.5365
17	.8215	.8551	.8718	.5365	.7377		.57
18	.9221	.8886	.7209	.5365	.9724	.7545	.5868
19	1.1065	.8048	.5365	.503	.8886	.6874	.5765
20	.8215	.7042	.5197	.5533	.8215	.6203	
21	.6706	.6874		.5533	.6203	.4862	.7122
22	.6036	.4862	.4359	.5868	.5365	.3521	.5935
23	.4191	.4024	.4527	.5868	.4359	.3353	.5365
24	.6036	.4359	.3856	.7042	.6036	.4862	.4862
Max	1.1065	1.1065	1.0898	.9221	.9724	.9724	1.0562
Min	.4191	.4024	.3856	.3521	.3688	.0655	.1844
Avg	.6983	.7279	.7137	.6644	.6622	.5570	.5936

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134017 / 33/11 Kv SATONA

Feeder No / Name : 203 / SHELGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0059	1.073	1.0898	.3521	.3506	.4024	.4191
2	1.0898	1.1065	1.5257	.3688	.4024	.4024	.4527
3	1.1736	1.1736	1.7101	.3353	.4024	.4191	.4862
4	1.3413	1.2407	1.7269	.3856	.4359	.4527	.5365
5	1.4251	1.3748	1.7436	.4862	.4694	.5365	.6203
6	1.5089	1.4922	1.643	.5197	.5365	.57	.6539
7	1.5927	1.7269	1.7269	.5365	.57	.6371	.7042
8	2.0454	1.9448	1.6933	.6371	.4191	.6371	
9	1.8945	1.5927	1.7269			.7042	.57
10	.4694	.4527	.4359	1.1568			.5365
11	.3856		.503	1.6263	1.7436	1.5257	1.5424
12	.4024	.285	.5365	2.0454	1.8442	1.7436	1.8442
13	.3856	.2683	.5868	2.2298	1.9448	1.9113	1.8778
14		.2515	.6203	2.1795	1.9281	1.9448	1.9616
15		.285	.503	2.079	1.9281	1.9616	1.8778
16		.3185	.4694	2.0119	1.8778	2.0287	1.8275
17	.4694	.4359	.3688	2.0454	1.861		1.8313
18	.6706	.4862	.7209	1.7101	1.5592	1.4754	1.7604
19	.6036	.5197	.4862	.4694	.8215	.6706	.6104
20	.503	.4862	.4527	.4862	.6036	.6539	.6371
21	.4694	.4694	.4024	.5197	.5365	.4694	.6706
22	.4191	.4359	.3688	.4694	.4527	.4024	.6706
23	.3353	.3856	.3856	.4862	.4191	.3688	.5365
24	.4359	.9724	.3521	.7042	.503	.4024	.3856
Max	2.0454	1.9448	1.7436	2.2298	1.9448	2.0287	1.9616
Min	.3353	.2515	.3521	.3353	.3506	.3688	.3856
Avg	.8870	.8164	.9074	1.0365	.9823	.9236	1.0006

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134017 / 33/11 Kv SATONA

Feeder No / Name : 205 / DEVLA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1174	.0838	.1174	.57	.6036	.3688	.3856
2	.1677	.0838	.1509	.6203	.6036	.3688	.4024
3	.2515	.1006	.1677	.6036	.6371	.4024	.4359
4	.285	.1509	.1509	.6203	.6539	.4191	.4862
5	.3353	.2012	.1341	.6539	.6706	.4359	.5365
6	.3018	.2515	.2012	.6371	.7042	.4694	.57
7	.3353	.3521	.2347	.6874	.7377	.5533	.6539
8	.3688	.3185	.285	.7377	.6539	.5868	.7042
9	.2683	.2683	.2347	.6371	.6036	.5868	.6371
10	.1677	.2012	.5868	.2012	.1509	.1677	.285
11	.7042	.6706	.6203	.1509	.1006	.1006	.0838
12	.7545	.6874	.6371	.1341	.0838	.0838	.1006
13	.7545	.7042	.6371	.1174	.0671	.0838	.0671
14	.7042	.7042	.6371	.1006	.0671	.0671	
15	.7042	.6874	.503	.0671	.0838	.0671	.0838
16	.6706	.6706	.6371	.1677	.1341	.0838	.1174
17	.6706	.7545	.7042	.1844	.1677	.2515	.1509
18	.6203	.7712	.6371	.218	.2012	.2012	.218
19	.218	.218	.285	.1006	.2515		.218
20	.1677	.1844	.2012	.1006	.2012	.1174	.2347
21	.1174	.1677	.1509	.0838	.1509	.0671	.2515
22	.0838	.1509	.1006	.1341	.1006	.0838	.1677
23	.0671	.1174	.0503	.1509	.0671	.0838	.1174
24	.1341	.0671	.0838	.4862	.1509	.4024	.3856
Max	.7545	.7712	.7042	.7377	.7377	.5868	.7042
Min	.0671	.0671	.0503	.0671	.0671	.0671	.0671
Avg	.3738	.3570	.3395	.3402	.3269	.2631	.3171

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134017 / 33/11 Kv SATONA

Feeder No / Name : 207 / Express Kedarwakdi  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0838	.1219	.0671	.0671	.1676	.1342	.1174
2	.0838	.1341	.0838	.0838	.1676	.1342	.1341
3	.1006	.1509	.1006	.0838	.2012	.1342	.1509
4		.1677	.1174	.1006	.2348	.1676	.1174
5		.1677	.1341	.1341	.2348	.2012	.1006
6		.1509	.1174	.1174	.1281	.2012	.0838
7		.1509	.1006	.1006	.1342	.2348	.1174
8		.1509	.1174	.0838	.1342	.2348	.1341
9		.1341	.0838	.0671	.2012	.2682	.1509
10	.1509	.1509	.1006	.1174	.1342	.2348	.1341
11	.1677	.1341	.0838	.1509	.1342	.1174	.1006
12	.1341	.1174	.1006	.1006	.1676	.1006	.0838
13	.1006	.1006	.1006	.0671	.2682	.0838	
14	.1006	.0671	.1174	.1006	.2348	.1006	
15	.1006	.1006	.1341	.0671	.2012	.0838	.0671
16	.0838	.1341	.1341	.1006	.2012	.1006	.0838
17	.0838	.0838	.1509	.1174	.1676	.0838	.1006
18	.0671	.0671	.1006	.0838	.2012	.0671	.0838
19	.0503	.0838	.1341	.0671	.2348	.0838	.0838
20	.1006	.1006	.1174	.0671	.2012	.1006	.1174
21	.1341	.1174	.1341	.0838	.1676	.1341	.1174
22	.1509	.1174	.1341	.1006	.1676	.1509	.1006
23	.1509	.1006	.1341	.1174	.1676	.1341	.0838
24	.0838	.1341	.0838	.1006	.2682	.1342	.1006
Max	.1677	.1677	.1509	.1509	.2682	.2682	.1509
Min	.0503	.0671	.0671	.0671	.1281	.0671	.0671
Avg	.1071	.1224	.1118	.0950	.1884	.1425	.1075

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134017 / 33/11 Kv SATONA

Feeder No / Name : 208 / 11 KV IRREGATION EXPRESS PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0168	.0168	.0168		.0168	.0168	.0168
2	.0168	.0168	.0168	.0168	.0168	.0168	.0168
3	.0168	.0168	.0168	.0168	.0168	.0168	.0168
4	.0168	.0168	.0168	.0168	.0168	.0168	.0168
5	.0168	.0168	.0168	.0168	.0168	.0168	.0168
6	.0168	.0168	.0168	.0168	.0168	.0168	.0168
7	.0168	.0168			.0168		.0168
8	.0168	.0168			.0168		.0168
9	.0168	.0168			.0168		.0168
10	.0168	.0168	.0168	.0168	.0168	.0168	.0168
11	.1509	.0168	.0168		.0168	.0168	.0168
12	.0168	.0168	.0168		.0168	.0168	.0168
13	.0168	.0168		.0168	.1509	.0168	.0168
14	.0168	.0168	.0168	.0168	.1509	.0168	.0168
15	.0168	.0168	.0168	.0168	.1174	.0168	.0168
16	.0168	.0168	.0168	.0168	.1174	.0168	.0168
17	.0168	.0168	.0168	.0168	.0168	.0168	.0168
18	.0168	.0168	.0168	.0168	.0168	.0168	.0168
19	.0168	.0168	.0168	.0168	.0168	.0168	.0168
20	.0168	.0168	.0168	.0168	.0168	.0168	.0168
21	.0168	.0168	.0168		.0168	.0168	.0168
22	.0168	.0168	.0168	.0168	.0168	.0168	.0168
23	.0168	.0168	.0168	.0168	.0168	.0168	.0168
24	.0168	.0168	.0168	.0168	.0168	.0168	.0168
Max	.1509	.0168	.0168	.0168	.1509	.0168	.0168
Min	.0168	.0168	.0168	.0168	.0168	.0168	.0168
Avg	.0224	.0168	.0168	.0168	.0364	.0168	.0168

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134031 / 33/11 KV SHRISHTI

Feeder No / Name : 201 / SHRISHTI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4268	.3887	.5601	.5182			
2				.5182	.2105	.2743	.2286
3				.503	.2105	.2743	.4572
4				.4877	.2429	.3658	.5792
5				.4877	.2915	.439	.6706
6				.4725	.3887	.5121	.7011
7				.4572	.7449	1.0974	.6859
8				.6401	.8583	1.1523	.9145
9				.7773	.8583	1.0164	.8078
18	.8745	1.1157	.7468				
19	.7611	.8145	.6859				
20	.7125	.7468	.6706				
21	.6478	.7655	.6097				
22	.583	.7095	.5944				
23	.5182	.6535	.5639				
24	.4572	.4534	.6535	.5335			
Max	.8745	1.1157	.7468	.7773	.8583	1.1523	.9145
Min	.4268	.3887	.5601	.4572	.2105	.2743	.2286
Avg	.6226	.7060	.6356	.5395	.4757	.6415	.6306

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134031 / 33/11 KV SHRISHTI

Feeder No / Name : 202 / PATODA Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					1.1174	1.3717	
10	1.5223	1.4074	1.2041				
11	1.8138	1.829	1.5394				
12	1.4899	2.1582	1.7833				
13	2.0081	2.2624	1.8138				
14	1.9109	2.2081	1.7528				
15	1.9433	2.1719	1.7223				
16	1.8623	2.1033	1.7071				
17	1.7004	2.0119	1.7071				
18				1.8138	1.4632	2.0729	2.2624
19				1.6032	1.8473	2.1033	2.0119
20				1.4737	1.5261	2.0119	2.0814
21				1.3765	1.5546	1.9509	1.829
22				1.2793	1.4815	1.8138	1.7375
23				1.1984	1.4632	1.6766	1.6461
24					1.1822	1.4632	1.5089
Max	2.0081	2.2624	1.8138	1.8138	1.8473	2.1033	2.2624
Min	1.4899	1.4074	1.2041	1.1984	1.1174	1.3717	1.5089
Avg	1.7814	2.0190	1.6537	1.4575	1.4544	1.8080	1.8682



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134031 / 33/11 KV SHRISHTI

Feeder No / Name : 203 / DATHANA Gao

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3547	.3361	.2801	.3547	.3174	.2987	.5415
2	.3547	.3547	.2801	.3361	.3361	.2801	.5601
3	.3361	.4108	.4715	.3361	.3361	.3361	.5601
4	.3547	.4481	.5658	.3734	.4108	.6535	.6348
5	.5415	.5415	.6535	.4481	.5601	.7468	.6722
6	.7095	.5601	.7095	.6535	.6348	.7842	.8215
7	.7655	.7095	.8215	.6908	.7282	.7468	.8589
8	.6908	.6722	.7842	.7468	.8029	.6908	.7468
9	.6535	.6348	.6722	.6908	.6908	.6535	.8029
10	.5975	.5228	.6535	.6535	.5788	.4294	.6161
11	.4108	.4481	.5041	.4481	.4108	.3921	.3734
12	.3921	.3921	.3734	.3361	.3734	.2801	.2801
13	.2987	.2987	.3547	.2801	.2801	.2614	.2427
14	.2801	.2801	.3547	.2801	.0943	.2427	.2427
15	.2241	.2801	.3361	.2987	.2427	.2054	.2801
16	.2987	.3361	.3361	.3361	.2427		.2987
17	.3921	.3772	.3734	.4108	.2743	.3921	.3395
18	.6348	.5788	.6161	.6722	.5487	.5975	.4108
19	.6535	.6535	.6161	.4481	.6722	.5601	.6468
20	.4854	.6161	.5788	.4481	.5975	.5415	.7095
21	.4108	.5601	.5601	.4294	.5601	.5415	.6468
22	.3921	.5228	.4108	.3921	.5228	.5415	.3361
23	.3547	.5041	.3734	.3734	.4668	.5228	.2987
24	.3547	.3547	.3361	.3547	.3361	.4108	.5415
Max	.7655	.7095	.8215	.7468	.8029	.7842	.8589
Min	.2241	.2801	.2801	.2801	.0943	.2054	.2427
Avg	.4559	.4747	.5007	.4497	.4591	.4830	.5193

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134031 / 33/11 KV SHRISHTI

Feeder No / Name : 204 / YENORA Gao

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1494	.1509	.2229	.132	.1494	.2229
2	.1715	.1494	.1494	.2229	.1509	.1494	.2229
3	.2058	.1867	.1509	.2401	.1886	.1867	.2229
4	.2401	.2054	.1867	.2572	.2075	.2801	.2401
5	.2743	.2614	.2801	.2743	.3174	.3361	.3086
6	.3429	.4294	.3361	.4287	.3921	.3547	.3086
7	.3601	.4854	.415	.4458	.3734	.4108	.3258
8	.3944	.4668	.3772	.4458	.2427	.4294	.3429
9		.3174	.3395	.4294	.2427	.3361	.3258
10	.2241	.2427	.3086	.2801	.1867	.3086	.2801
11	.1494	.1867	.2229	.168	.1494	.1543	.1867
12	.112	.1886	.1543	.1307	.1494	.1372	.1509
13	.112	.1509	.1372	.1307	.112	.1372	.1132
14	.0934	.1494	.1372	.1307	.0943	.12	.1132
15	.112	.1494	.1543	.112	.112	.12	.0943
16	.168	.1867	.1543	.1494	.1494	.1372	.1509
17	.2801	.1886	.1886	.1494	.1886		.1886
18	.3734	.2829	.3086	.3921	.2801	.3086	.2987
19	.3547	.2987	.3258	.3547	.3547	.2743	.3361
20	.2427	.3361	.3258	.2427	.3361	.2572	.3547
21	.2054	.3361	.2915	.2054	.2987	.2572	.2829
22	.1867	.2801	.2743	.1867	.168	.2401	.1886
23	.168	.2241	.2229	.1494	.168	.2229	.1848
24	.1886	.1494	.1509	.2229	.1509	.1494	.2058
Max	.3944	.4854	.415	.4458	.3921	.4294	.3547
Min	.0934	.1494	.1372	.112	.0943	.12	.0943
Avg	.2238	.2501	.2393	.2488	.2144	.2373	.2354

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134031 / 33/11 KV SHRISHTI

Feeder No / Name : 205 / Ashti Water Supply  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0189	.0191	.0191	.0187	.0191
2	.0191	.0191	.0189	.0191	.0191	.0189	.0191
3	.0191	.0191	.0189	.0191	.0191	.0189	.0191
4	.0191	.0191	.0189	.0191	.0191	.0189	.0191
5	.0191	.0191	.0189	.0191	.0191	.0189	.0191
6	.0191	.0191	.0189	.0191	.0191	.0189	.0191
7	.0191	.0191	.0189	.0191	.0191	.0189	.0191
8	.0191	.0191		.0191	.0191	.0189	
9	.0191	.0191		.0191	.0191	.0189	
10	.0191	.0191	.0191	.0191	.0191	.0191	
11	.0191	.0189	.0191		.0189	.0191	.0189
12	.0191	.0189	.0191		.0189	.0191	.0189
13		.0189			.0189	.0191	.0189
14		.0189			.0189		.0189
15		.0189			.0189		.0189
16		.0189			.0189		.0189
17		.0189			.0189		.0189
18		.0189		.0191	.0187		.0189
19		.0187	.0191	.0191	.0189		.0189
20	.0191	.0189	.0191	.0191	.0189	.0191	.0189
21	.0191	.0189	.0191	.0191		.0191	.0189
22	.0191	.0189	.0191	.0191		.0191	.0189
23	.0191	.0189	.0191		.0189	.0191	.0189
24	.0191	.0191	.0189	.0191	.0191	.0187	.0191
Max	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0191	.0187	.0189	.0191	.0187	.0187	.0189
Avg	.0191	.0190	.019	.0191	.0190	.0190	.0190

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134058 / 33KV/11KV LONI SUBSATION

Feeder No / Name : 201 / LONI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2558	1.4754	1.5623	.0381	.4954	.4954	.4954
2	2.4387	1.5424	1.8747	.0343	.5335	.5335	.5335
3	2.3624	1.8778	2.1091	.0343	.5716	.5716	.6097
4	2.2558	2.079	2.2929	.0362	.5335	.5716	.6478
5	2.2405	2.1795	2.3434	.4001	.5335	.5335	.6097
6	2.3777	2.2634	2.6216	.4191	.6668	.6097	.5335
7	2.4082	2.4143	2.734	.0438	.4572	.6668	.5716
8	2.5911	2.4143	2.915	.0286	.2286	.3048	.2286
9	2.21	1.8778	2.8121	.2858	.2286	.2286	.1905
10	.0286	.0343	.3429	.2286	.1905	.1905	.381
11	.0229	.0229	.2858	2.0424	1.829	1.829	1.9052
12	.0191	.2286		1.9814	1.9814	1.9509	1.9357
13		.1905		1.9509	2.0576	2.0576	1.9814
14			.0191	1.9814	1.9052	2.0881	2.0881
15	.0191		.1905	2.0881	1.829	2.1338	2.1338
16	.0229	.2286	.1905	2.0576	2.0881	2.2405	2.0576
17	.0343	.2667	.2286	1.9814	2.1338	2.2862	1.9814
18	.0457	.3048	.3048	2.1338	2.1795	2.2558	1.9052
19	.0495	.381	.381	.4763	.4763	.5335	.5335
20	.0514	.0572	.0419	.5335	.5335	.6097	.6097
21		.4763	.4572	.5144	.6097	.5716	.5716
22	.0533	.4572	.4763	.4763	.4954	.5335	.5335
23	.0495	1.2498	.4191	.4954	.381	.4954	.4763
24		1.2071	1.4089	.381	.4572	.4191	.4572
Max	2.5911	2.4143	2.915	2.1338	2.1795	2.2862	2.1338
Min	.0191	.0229	.0191	.0286	.1905	.1905	.1905
Avg	1.0768	1.0559	1.1824	.8601	.9748	1.0296	.9988

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134058 / 33KV/11KV LONI SUBSATION

Feeder No / Name : 202 / CHANGATPURI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.0419	.381	.5668	.6097	.6097	.5792
2	.5335	.0419	.381	.6226	.9145	.6401	.6859
3	.6097	.0419	.4191	.6249	.945	.6859	.7621
4	.7049	.0495	.4763	.7373	1.0364	.7621	.9145
5	.7621	.0667	.5716	.7373	1.1431	.823	1.0212
6	.724	.0743	.724	.8192	1.1888	.884	1.0669
7	.7049	.0781	.7621	.6478	1.1584	.9145	.9907
8	.6668	.0781	.7621	.9012		.9907	1.1584
9	.5335	.0686	.5716	1.0688	1.2955	1.0669	1.0669
10	.0324	.0495	.6097	.0514	.4763	.4572	.2858
11	.5365	.8259		.2667	.381	.3048	.2667
12	.6203	.9717		.2477	.3429	.2858	.3048
13	.6203	1.0159		.2286		.3048	.2858
14	.5365	.1943	.8583	.2477		.2667	.1715
15	.5365		.9717	.2858		.1905	.2858
16	.7377		.953	.2667		.3048	.3429
17	.8048	.381	1.0467		1.2346	.381	.381
18	.8048	.4763	.9998		.5716	.6859	.5906
19	.0572	.5716	.0724	.724	.6097	.724	.6668
20	.0667	.6097	.5716	.6668	.724	.6668	.7049
21	.0667	.6668	.5335	.6859	.6859	.724	.724
22	.0572	.5335	.4382	.6097	.5716	.7049	.6668
23	.0495	.4001	.4763	.6478		.6668	.7049
24	.381	.0438	.4382	.5668		.5792	.5944
Max	.8048	1.0159	1.0467	1.0688	1.2955	1.0669	1.1584
Min	.0324	.0419	.0724	.0514	.3429	.1905	.1715
Avg	.4851	.3310	.6199	.5555	.817	.6093	.6343

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134061 / 33/11 KHANDAVI SUBSTATION

Feeder No / Name : 201 / TAKALI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1829	.2134	.1029	.0857	.12	.1029
2	.2286	.2286	.2134	.12	.0857	.1372	.1029
3	.2743	.2439	.2439	.12	.0857	.1372	.12
4	.3353	.2743	.3048	.1715	.12	.2058	.1543
5	.4115	.3048	.3963	.2743	.1715	.2229	.1886
6	.5335	.4115	.5182	.3601	.2572	.2572	.2915
7	.7011	.5944	.7011	.4287	.2572	.3429	.3429
8	.6859	.7926	.7316	.2401	.3258	.3429	.2915
9	.7926	.7316	.823	.3258	.2915	.2401	.2401
10	.1886	.1886	.2401	.2401	.2058	.1543	.1715
11	.1029	.1029	.1372	.503	.5182	.5639	.4268
12	.0857	.0857	.1029	.7621	.6097	.5792	.5792
13	.0686		.0857	.8383	.6859	.6249	.5792
14	.0514		.0857	.7621	.6097	.5639	.5335
15	.0857	.0686	.0686	.7621	.5182	.5182	.5487
16	.0686	.0857	.0857	.6859	.5487	.5944	.4877
17		.1029	.0857	.6706	.6249	.4877	.503
18	.1029	.1886	.1715	.4725	.4268	.442	.4268
19	.2572	.2401	.2058	.2058	.2058	.2229	.2229
20	.1886	.2058	.1715	.1372	.1886	.1886	.1886
21	.1372	.1543	.1372	.12	.12	.1543	.1543
22	.1372	.1372	.12	.1029	.1372	.0857	.1029
23	.1029	.1029	.1029	.0857	.1372	.0857	.1029
24	.1029	.1829	.2286	.1029	.0857	.12	.0857
Max	.7926	.7926	.823	.8383	.6859	.6249	.5792
Min	.0514	.0686	.0686	.0857	.0857	.0857	.0857
Avg	.2498	.2550	.2573	.3581	.3043	.3080	.2895

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134061 / 33/11 KHANDAVI SUBSTATION

Feeder No / Name : 202 / KHANDVI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4973	.5639	.4877	.4801	.5144	.5658	.5144
2	.6859	.6097	.5487	.4801	.5144	.5487	.5487
3	.7621	.6859	.6097	.5144	.5144	.5487	.5658
4	.9297	.7164	.6401	.6859	.8573	.6173	.6173
5	1.1431	.8383	.9145	.9259	1.2003	.7202	.7202
6	1.4175	1.0822		1.2003		1.2689	1.2689
7	1.5394	1.3717		1.3375	1.3717	1.3375	1.3375
8	1.5546	1.5546		1.3032	1.4232	1.2003	1.2346
9	1.5394	1.3717		1.1317	.8916	.9088	1.1831
10	.6859	.6173		.7373	.6173	.5144	.7716
11	.3601	.4458		1.3565	.9755	1.1888	.9755
12	.2743	.3601		1.6918	1.1584		1.1584
13	.3429	.3258		1.7833	1.3717	1.387	1.2346
14	.2572	.3429		1.6766	1.387	1.326	1.1736
15	.2743	.3772		1.6766	1.4022	1.1126	1.1584
16	.3258	.4115	.583	1.5242	1.3413	1.2498	1.1431
17	.5144	.463	.6173	1.4937	1.2651	1.1736	1.1279
18	.7716	.7888	.9088	1.1736	1.1431	1.0059	1.0059
19	1.0117	.8916	.9259	.9259	.823	.9431	.9774
20	.7888	.7888	.7545	.703	.7545	.7888	.7888
21	.6516	.6516	.703	.6001	.5658	.6859	.6173
22	.6001	.583	.6001	.5144	.5658	.5316	.5316
23	.5316	.5144	.5144	.5144	.6173	.4973	.5144
24	.6001	.5335	.4268	.4973	.5144	.5487	.5144
Max	1.5546	1.5546	.9259	1.7833	1.4232	1.387	1.3375
Min	.2572	.3258	.4268	.4801	.5144	.4973	.5144
Avg	.7525	.7037	.6596	1.0387	.9474	.8987	.9035

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134061 / 33/11 KHANDAVI SUBSTATION

Feeder No / Name : 203 / USMANPUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1715	.1543	.945	.9145		.9145
2	.12	.1715	.1543	.9755	.9145		.9907
3	.1029	.1543	.1886	.9755	.9907		1.0669
4	.1029	.1886	.2743	1.0669	1.0669		1.3717
5	.1543	.2572	.3086	1.1279	1.3717		1.448
6	.2572	.3086	.5144	1.1584	1.5242		1.5089
7	.4287	.5144	.6344	1.1888	1.5242		1.5394
8		.463	.3944	1.4022	1.6309		1.768
9			.463	1.3413	1.5546		1.6766
10	.2229		.3601	.3772	.2915		.3258
11		1.326	1.4327	.2401	.1886	.2572	.2229
12	2.0119	1.5242	1.8747	.1543	.1543	.2229	.1715
13	1.9966	1.7528	2.0576		.1715		.1543
14	2.1033	1.7071	2.0119	.0686	.1543	.1715	.12
15	2.0729	1.3108	1.9814	.0686	.1372	.1372	.12
16	2.1033	1.4784	1.8138	.0686	.1715	.1543	.1372
17	1.768	1.829	1.8442	.2915	.2229	.2229	.1886
18	1.5546	1.5851	1.4937	.3772	.3429	.3258	.2915
19		.4801	.3601	.3601	.3772	.4458	.4115
20	.3772	.3772	.3429	.2572	.2743	.3258	.3429
21	.2058	.2572	.2572	.1715	.2229	.2572	.2229
22	.2058	.2229	.1886	.1543	.1543	.1715	.1543
23	.2058	.1715	.1543	.0857	.1715	.1543	.1372
24	.1029	.1715	.1715	.9145	.9145		.9145
Max	2.1033	1.829	2.0576	1.4022	1.6309	.4458	1.768
Min	.1029	.1543	.1543	.0686	.1372	.1372	.12
Avg	.8109	.7465	.8096	.5987	.6434	.2372	.6750



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 201 / TOWN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429		.4287	.3429	.3429	.4287	.3429
2	.3429		.4287	.3429	.3429	.4287	.3429
3	.3429		.4287	.3429	.3429	.4287	.3429
4	.3429		.4287	.3429	.4287	.5144	.4287
5	.5144		.5144	.5144	.5144	.5144	.5144
6	.7716		.6859	.6859	.6859	.6859	.6859
7	.9431		.9431	.7621	.9431	1.0288	.7621
8	1.1145		1.0288	1.0288	1.0288	1.0288	.9145
9	1.0288	.9431	1.0288	.9145	1.0288	1.0288	.9145
10	.8573	.8573	.8383	.8573	.8573	.8573	.8573
11	.8573	.7716	.8573	.8573	.8573	.7716	.6859
12	.7716	.6859		.6859	.6859	.6859	.6859
13	.6859	.6001	.6859	.6001	.6859	.6859	.6859
14	.6001	.6001	.6859	.6001	.1715	.6001	.6001
15	.6001	.6001	.6001	.6001	.6859	.6001	.6859
16	.6859	.6859	.6859	.6001	.6859	.6859	.6859
17	.8573	.7716	.7716	.7716	.7716	.7716	.7716
18	.9431	.8573	.7716	.8573	.9431	.7621	.8573
19	1.0288	.8573	.7716	1.1145	.7716	.7621	.8573
20	1.1145	.6859	.6859	1.0288	.6859	.7716	.7716
21	.8573	.6859	.6001	.8573	.6001	.6001	.6859
22	.7716	.5144	.5144	.5144	.5144	.5144	.4287
23	.6001	.5144	.4287	.3429	.5144	.4287	.4287
24	.5144		.4287	.3429	.3429	.4287	.3429
Max	1.1145	.9431	1.0288	1.1145	1.0288	1.0288	.9145
Min	.3429	.5144	.4287	.3429	.1715	.4287	.3429
Avg	.7287	.7087	.6627	.6628	.6430	.6672	.6367

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 202 / RAMKHEDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859		.8573	.6859	1.0288	1.2003	.9907
2	.6859		1.0288	.7621	1.0288	1.2003	1.0669
3	.6859		1.0288	.7621	1.0288	1.286	1.1431
4	.7621		1.0288	.7621	1.2003	1.3717	1.2193
5	1.0669		1.2003	.9907	1.5432	1.3717	1.2955
6	1.2193		1.3717	.9907	1.7147	1.6289	1.448
7			2.0576	1.1431	2.2291	2.3148	1.6766
8			2.3148	1.2955	2.4006	2.572	1.8004
9		1.0288		.6859	1.2955	1.286	1.3717
10	1.2003	.5144	.5144	.381	.7621	.6859	.6859
11	1.8004	.4287		.2286	.5144	.5144	.5144
12		.3429		.2286	.3429	.5144	.5144
13		.3429		.2286	.2572	.4287	.5144
14		.3429		.2286	.3429		.3429
15		.3429	.2572	.2286	.3429		
16		.5144	.2572	.3048	.4287	.5144	.6859
17		.9431		.4572	.6859	.6859	.7716
18		1.2003		1.2193	1.3717	1.2003	1.3717
19		1.2003	.6001	1.1431	1.3717	1.6289	1.5432
20		1.1145	.6001	1.0669	1.2003	1.3717	1.286
21			.5144	.9145	.8573	1.0288	1.2003
22			.4287	.6859	.6859	.8573	.7716
23		.6859	.7716	1.0288	.8573	.9145	.8573
24	.6859		.8573	.6859	1.0288	1.0288	.9907
Max	1.8004	1.2003	2.3148	1.2955	2.4006	2.572	1.8004
Min	.6859	.3429	.2572	.2286	.2572	.4287	.3429
Avg	.9770	.6925	.9229	.7129	1.0217	1.1639	1.0462

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 203 / AMBADGAON-AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573						
2	.8573						
3	.8573						
4	.8573						
5	1.0288						
6	1.2003						
7	1.8861						
8	1.9719						
9			.5144			.4287	
10		1.7147	1.2193	1.4575	1.6289	.9907	1.2003
11		2.0576	1.6766	1.4575	1.6289	1.2193	1.3717
12		2.0576	1.7528	1.4575	1.6289	1.2193	1.5432
13		2.0576	1.6766	1.3717	1.6289	1.2955	1.3717
14		1.8861	1.6004	1.3717	1.5432	1.3717	1.286
15		1.8004	1.2193	1.3717	1.5432	1.448	1.2003
16		1.8004	1.0669	1.2003	1.5432	1.3717	1.2003
17		1.8004	.9907	1.2003	1.4575	1.448	1.2003
24	.8573						
Max	1.9719	2.0576	1.7528	1.4575	1.6289	1.448	1.5432
Min	.8573	1.7147	.5144	1.2003	1.4575	.4287	1.2003
Avg	1.1526	1.8969	1.3019	1.3610	1.5753	1.1992	1.2967

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 204 / KUSALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335		.8573	.7621	.6859	1.0288	.6859
2	.5335		1.0288	.8383	.6859	1.0288	.7621
3	.5335		1.0288	.8383	.6859	1.0288	.8383
4	.5335		1.0288	.8383	.6859	1.0288	.9145
5	.6097		1.2003	.9145	.8573	1.0288	.9907
6	1.2193		1.2003	1.0669	1.2003	1.1145	1.1431
7	1.2955		1.5432	1.2955	1.7147	1.5432	1.448
8			.6859	1.6004	2.0576	1.8004	1.829
9		1.0288	1.3717	1.2003	.4572		1.286
10	1.2003	.6859	.9431	.7621	.381		1.2003
11	1.4575	.5144	.7716	.4572	.3429		
12	1.5432	.5144		.4572	.3429	.6001	
13	1.8004	.3429		.3048	.1715	.6001	
14	1.7147	.3429	.5144	.3048		.6001	
15	1.4575		.5144	.3048		.5144	.5144
16	1.4575		.6859	.3048		.5144	.7716
17	1.286		.7716	.5335			.7716
18	1.0288	1.1145	1.2003	.7621	1.1145		1.286
19	1.286	1.2003	1.4575	.9907	1.286	1.2003	1.4575
20	1.2003	1.1145	1.286	.9145	1.2003	1.0288	1.286
21	1.1145	.9431	1.0288	.7621	.8573	.9431	
22	1.0288	.7716	.8573	.6859	.7716	.8573	.7716
23	.8573	.6859	.6859	.6859	.8573	.6859	.8573
24	.8573		.8573	.7621	.6859	1.0288	.7716
Max	1.8004	1.2003	1.5432	1.6004	2.0576	1.8004	1.829
Min	.5335	.3429	.5144	.3048	.1715	.5144	.5144
Avg	1.1158	.7716	.9781	.7645	.8521	.9566	1.0308

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 205 / ROSHANGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287			.2572	.2286	.2572	.2572
2	.4287		.3429	.2572	.2286	.2572	.3429
3	.4287		.3429	.2572	.2286	.2572	.3429
4	.4287		.3429	.3429	.3429	.2572	.4287
5	.5144		.3429	.4287	.4572	.3429	.5144
6	.6859		.4287	.6001	.6859	.5144	.6859
7	.9431		.5144	.7716	.7621	.6859	.7716
8	1.0288		.7716	.6859		.7716	.7716
9	.5335		.6859	.5144		.6001	.6001
10	.4287		.6859	.7716	.7716	.6859	.6859
11	.2572	.5144	.7716	.7716	.8573	.7621	.6859
12		1.0288	.9431	.8573	.8573	.7621	.7716
13		1.0288	1.0288	.8573	.8573	.8573	.8573
14		1.0288	1.0288	.8573	.8573	.8573	.8573
15		1.0288		.8573	.8573	.7621	
16		1.0288	.8573	.8573	.8573	.8383	.6859
17		.6859	.6859	.8573	.8573	.7621	.6859
18		.5144	.5144	.4572	.5144	.5144	.6859
19		.6001	.6001	.5335	.6859	.6859	.6859
20		.5144	.5144	.5335	.5144	.5144	.6001
21		.4287	.4287	.381	.4287	.4287	.5144
22		.3429	.3429	.3048	.3429	.3429	.3429
23		.3429	.2572	.2286	.3429	.2572	.3429
24	.4287		.3429	.2572	.2286	.2572	.2572
Max	1.0288	1.0288	1.0288	.8573	.8573	.8573	.8573
Min	.2572	.3429	.2572	.2286	.2286	.2572	.2572
Avg	.5446	.6991	.5806	.5624	.5802	.5513	.5815

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 206 / AMBADGAON (G)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1715	.0857	.0857	.1715	.1715
2			.1715	.0857	.0857	.1715	.0857
3			.1715	.0857	.0857	.1715	.0857
4			.1715	.1715	.1715	.1715	.1715
5			.1715	.2572	.2572	.2572	.2572
6			.1715	.3429	.3429	.4287	.3429
7			.3429	.4287	.4287	.5144	.4287
8			.4287	.4287	.3429	.4287	.5144
9	.2572	.3429		.3429	.2572	.4287	.4287
10	.2572		.1715			.1715	
11	.1715		.0857			.0857	
12			.0857			.0857	
13			.0857			.0857	
14			.0857			.0857	
15			.0857			.0857	
16			.0857			.0857	
17			.0857			.0857	
18		.5144	.2572	.3429	.4287	.2572	.4287
19		.5144	.3429	.3429	.3429	.3429	.3429
20		.2572	.2572	.3429	.2572	.2572	.2572
21		.8573	.1715	.2572	.1715	.1715	.2572
22		.6859	.1715	.1715	.1715	.1715	.1715
23		.1715	.0857	.0857	.1715	.1715	.1715
24			.1715	.0857	.0857	.1715	.1715
Max	.2572	.8573	.4287	.4287	.4287	.5144	.5144
Min	.1715	.1715	.0857	.0857	.0857	.0857	.0857
Avg	.2286	.4777	.1752	.2411	.2304	.2108	.2679

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 207 / WARUDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287		.5144	.9431	.5335	.6859	.5144
2	.4287		.5144	1.0288	.5335	.6859	.6001
3	.4287		.5144	1.2003	.5335	.6859	.6001
4	.4287		.6859	1.3717	.5335	.8573	.6859
5	.5144		.8573	1.5432	.6097	1.0288	1.0288
6	.8573		.8573	1.8004	1.1431	1.286	1.3717
7	.8573		1.286		1.1431	1.1145	1.5432
8	1.3717		1.2003			1.0288	
9	.8383	.8573	***			.7716	1.2003
10	.7716	1.3717	.9907	1.6289	1.286	1.0669	1.2003
11	.6001	1.7147	.9907	1.5432	1.6289	1.2193	1.2003
12	.6001	1.5432	1.1431	1.8861	1.6289	1.2193	1.2003
13	.5144	1.5432	1.2193	1.8861	1.6289	1.2955	
14	.5144	1.3717	1.2955	1.9719	1.6289	1.2955	
15	.2572	1.0288	1.2193	1.9719	1.6289	1.2955	1.3717
16	.5144	1.0288	1.2955	1.9719	1.4575	1.2193	1.5432
17	.9431	.9431	1.2193	1.6289	1.3717	1.1431	1.5432
18	1.0288	1.2003		.9145		.6859	1.3717
19	1.0288	1.2003		1.0669	1.286	.8573	1.286
20		1.0288	1.5432	.9145	1.1145	.9431	1.0288
21	.8573	.8573	1.3717	.7621	.8573	.8573	.9431
22		.6001	1.1145	.6097	.7716	.6859	.8573
23	.6001	.5144	.8573	.5335		.6001	.8573
24	.5144		.5144	.8573	.5335	.6859	.6001
Max	1.3717	1.7147	11.2312	1.9719	1.6289	1.2955	1.5432
Min	.2572	.5144	.5144	.5335	.5335	.6001	.5144
Avg	.6772	1.1202	1.4744	1.3350	1.0926	.9673	1.0737

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 208 / COTTEX GINNING

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	27-DEC-17
HR	Load (MW)
23	.0857
Max	.0857
Min	.0857
Avg	.0857



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 209 / BAGADIYA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857		.0857	.0857	.0857	.0857	.0857
2	.0857		.0857	.0857	.0857	.0857	.0857
3	.0857		.0857	.0857	.0857	.0857	.0857
4	.0857		.0857	.0857	.0857	.0857	.0857
5	.0857		.0857	.0857	.0857	.0857	.0857
6	.0857		.0857	.0857	.0857	.0857	.1715
7	.0857		.0857	.1715	.0857	.0857	.1715
8	.1715		.0857	.1715	.1715		.1715
9	.1715	.2572	.1715	.1715	.2572	.0857	.1715
10	.1715	.2572	.1715	.0857	.3429	.1715	.1715
11	.2572	.1715	.1715	.1715	.1715	.1715	.1715
12	.2572	.1715	.1715	.1715	.1715	.1715	.1715
13	.2572	.1715	.1715	.1715	.0857	.1715	.1715
14	.1715	.1715	.1715	.1715	.0857	.1715	.2572
15	.1715	.1715	.0857	.1715	.1715	.1715	.2572
16	.1715	.1715	.1715	.1715	.1715	.1715	.2572
17	.0857	.1715	.2572	.2572	.0171	.1715	.2572
18	.0857	.0857	.1715	.1715	.1715	.1715	.2572
19	.0857	.1715	.1715	.1715	.1715	.1715	.1715
20	.0857	.1715	.1715	.1715	.1715	.1715	.1715
21	.0857	.1715	.1715	.1715	.1715	.1715	
22	.0857	.1715	.0857	.1715	.1715	.1715	.1715
23	.0857	.1715	.0857	.1715	.1715	.1715	.0857
24	.0857		.1715	.0857	.0857	.0857	.0857
Max	.2572	.2572	.2572	.2572	.3429	.1715	.2572
Min	.0857	.0857	.0857	.0857	.0171	.0857	.0857
Avg	.1286	.1772	.1357	.1465	.1400	.1379	.1640

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013430 / 33KV DABHADI

Feeder No / Name : 201 / DABHADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.8029	.8954	.7316	.6535	.7468	.6036
2	.7716	.8029	.8859	.8145	.7316	.8589	.6036
3	.8745	.8002	.8619	.9955	.724	.8589	.6401
4	1.0288	1.0288	.8951	1.086	.7468	.9709	.6401
5	1.0059	.9717	.9175	1.0745	1.1203	1.1203	.724
6	1.1065	1.186	.9012	1.3253	1.1888	1.2254	1.086
7	1.2574	1.3279	1.3927	1.4723	1.587	1.4632	1.448
8	1.3413	1.406	1.5223	1.0867	1.4003	1.4632	1.3717
9	1.2536	1.1203	1.182	.7716	1.1203	1.2803	1.0974
10	1.2136	.9335	.8316	1.0059	.8288	.9221	1.1568
11	.7468	.7468	.7316	1.3927	.9012	1.1065	1.3108
12	.6535	.7095	.6401	1.5089	1.2146	1.1736	1.3765
13	.5975	.6722	.462	1.2803	.9717	1.1736	1.2574
14	.5601	.5601	.462	1.0059	1.1336	1.1065	1.3765
15	.5041	.7095	.4805	1.0174	1.2146	1.1065	1.3077
16	.462	.7468	.5487	.8589	.9831	1.1022	1.1145
17	.4108	.7468	.7133	.6335	.9175	1.0174	1.1012
18	.6535	1.307	1.1765	1.4723	.9145	.7133	.5601
19	1.0974	1.2803	1.2323	.8779	1.2803	1.0425	1.419
20	1.0242	1.2071	1.086	1.1706	1.4266	1.086	.9709
21	.9335	.9335	.7964	.7468	1.1576	1.0059	.8402
22	.8402	.7842	.6401	.6535	.7095	.8316	.7842
23	.7545	.823	.6036	.6535	.7095	.6653	.6468
24	.5201	.763	.9145	.5544	.5658	.7468	.5544
Max	1.3413	1.406	1.5223	1.5089	1.587	1.4632	1.448
Min	.4108	.5601	.462	.5544	.5658	.6653	.5544
Avg	.8493	.9321	.8656	1.0079	1.0084	1.0328	.9996

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013430 / 33KV DABHADI

Feeder No / Name : 202 / CHIKHALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2957	.2801	.2683	.3189	.5144	.3658	.6068
2	.3881	.3361	.3018	.3721	.5087	.394	.6068
3	.3841	.3658	.4108	.3721	.503	.4973	.7802
4	.4572	.462	.5228	.3681	.4748	.5487	.8322
5	.4938	.6535	.6401	.4382	.5735	.7537	.823
6				.463	.7287	.8192	.9774
7				1.0288	.9831	1.1142	1.1317
8				1.073	1.5089	1.1961	1.2174
9	.4572			.4938	.5601	.4477	.7133
10	1.267	.9389	1.0288	.4572	.4108	.3881	.3734
11	1.1145	1.065	1.1904	.3881	.3361	.2772	.2743
12	1.2963	1.1336	1.1736	.4668	.2241		.1867
13	1.2003	1.1336	1.1065	.2829	.1867	.2033	.2241
14	1.2346	1.3765	1.1022	.1886	.1494	.2033	.2241
15	1.1385	1.2955	1.0059	.1867	.1494	.2033	.1867
16	1.2631	1.1603	1.0288	.1829	.1867	.2218	.1867
17	1.3413	1.0774	.9774	.3547	.1867	.3881	.3206
18	.3772	.5304	.5544	.415	.3734	.4805	.3734
19	.4668	.5853	.7133	.4668	.5975	.7207	.7095
20	.5487	.5601	.5121	.4668	.6722	.7499	.4481
21	.5228	.4108	.3841	.4108	.4481	.6584	.4108
22	.3174	.3547	.2218	.2829	.2801	.543	.3361
23	.2801	.2987	.2149	.4287	.2926	.443	.2743
24	.2772	.2801	.2614	.2835	.6859	.3292	.5144
Max	1.3413	1.3765	1.1904	1.073	1.5089	1.1961	1.2174
Min	.2772	.2801	.2149	.1829	.1494	.2033	.1867
Avg	.7201	.7149	.6810	.4246	.4806	.5194	.5305

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013438 / 33KV NANEGAON

Feeder No / Name : 201 / NANEGAON-AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.462	.4115	.4066	.0739	.0686	.0686	.0857
2	.5068	.4801	.439	.0739	.0686	.1029	.0857
3	.543	.5487	.4805	.0924	.0686	.12	.0857
4	.6335	.6173	.5544	.1109	.0686	.1372	.1029
5	.6878	.6687	.6401	.1294	.0857	.1715	.1029
6	.724	.6687	.6878		.0857	.1715	.1372
7	.0905	.6859	.8326	.1294	.0857	.1886	.1715
8		.8402	.8688	.1478	.0686	.1886	.1886
9				.1478	.0857	.1715	.1715
10					.4801	.6001	.5144
11					.5658	.6687	.6687
12					.6001	.6516	.7545
13						.2401	.7888
14					.6516	.2229	.7888
15	.0343	.0857	.0739	1.0117	.7545	.8573	.8059
16		.12	.0739	1.0631	.8573	.9259	
17		.1372	.0924	1.0288	.8745	.9945	.7888
18		.1715	.1848				
19	.1543	.1886	.1848				
20	.1543	.1715	.1478				
21	.1372	.1543	.1109				
22	.12	.1372	.1109				
23	.2743	.3439	.1109				
24	.3326	.3086	.3841	.0924	.0686	.1029	.1029
Max	.724	.8402	.8688	1.0631	.8745	.9945	.8059
Min	.0343	.0857	.0739	.0739	.0686	.0686	.0857
Avg	.3468	.3744	.3547	.3418	.3258	.3658	.3732

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013438 / 33KV NANEGAON

Feeder No / Name : 202 / NANEGAON (G)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0739	.0686	.0554	.0739	.0686	.0686	.0514
2	.0739	.0857	.0739	.0554	.0686	.1029	.0514
3	.0739	.1029	.0739	.0554	.1029	.1372	.0514
4	.0924	.1372	.0739	.1109	.1372	.1543	.0686
5	.1294	.1543	.0924	.1848	.1543	.1886	.0857
6	.1663	.1886	.1478	.2054	.1715	.2229	.12
7	.1848	.2058	.1848	.2218	.1886	.1715	.1886
8	.1848	.1886	2.0698	.2328	.1715	.1372	.1886
9	.1478	.1543	.1478	.1848	.1372	.1029	.1543
10	.1478	.12	.1109	.1029	.1029	.0857	.12
11	.0686	.0857	.1109	.0686	.0514	.0686	.0857
12	.0514	.0686	.0924	.0514	.0343	.0514	.0514
13	.0514	.0686	.0924	.0343	.0171	.0514	.0343
14	.0343	.0686	.0739			.0343	.0343
15	.0343	.0857	.0739	.0343		.0343	.0343
16		.0857	.0554	.0514	.1029	.0514	
17		.0686	.0739	.0857	.1372	.0686	.0514
18		.1372	.1478	.12	.1372	.1029	.1029
19	.1372	.1715	.1848	.1543	.1715	.1543	.1715
20	.1372	.1543	.1663	.1372	.2058	.12	.1372
21	.0857	.1372	.1294	.1029	.1715	.0857	.1029
22	.0686	.12	.1109	.0686	.1715	.0514	.0686
23	.0343	.0739	.0924	.0514	.1372	.0514	.0514
24	.0924	.0343	.0554	.0924	.0514	.1372	.0514
Max	.1848	.2058	2.0698	.2328	.2058	.2229	.1886
Min	.0343	.0343	.0554	.0343	.0171	.0343	.0343
Avg	.0986	.1152	.1871	.1079	.1224	.1014	.0894

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013438 / 33KV NANEGAON

Feeder No / Name : 203 / SAIGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.5487	.4287	.5658	.5144
2				.5853	.4801	.6859	.5144
3				.6219	.583	.7545	.5487
4				.6401	.6173	.823	.6173
5				.6335	.6516	.8573	.6859
6				.6878	.6859	.8916	.7545
7				.724	.7202	.8059	.823
8				.8326	.9088	.7545	.9945
10	.8145	.7202	.724				
11	.9431	.8573	.8688				
12	1.0974	.9774	.9955				
13	1.0802	.9945	1.2308				
14	1.0802	.9945	1.1765				
15	.9945	.9774	1.0719				
16	.9259	.9774	1.086				
17	.8916	.8916	1.086				
23			.3109	.2743	.4287	.4287	.3772
24					.3429	.5144	.463
Max	1.0974	.9945	1.2308	.8326	.9088	.8916	.9945
Min	.8145	.7202	.3109	.2743	.3429	.4287	.3772
Avg	.9784	.9238	.9500	.6165	.5847	.7082	.6293

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013441 / 33 KV SHELGAON

Feeder No / Name : 201 / SHELGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8192	.0549	.5316	.3582	.3734	.362	.3658
2	.8192	.5487	.5316	.3582	.3734	.362	.3544
3	.9012	.5487	.5316	.3582	.4668	.4572	.3658
4	.8907	.7316	.7087	.7164	.7468	.8145	.724
5	1.0526	1.0059	1.0517	1.0745	1.1203	1.1765	1.267
6	1.3108	1.3717	1.4022	1.2403			
7	1.6385						
8	1.7394						
9	1.3717						
10	.9145	1.6385	1.6766	1.5927	1.267	1.5089	2.0957
11	.5487	.9831	1.6575	1.7814	1.4632	1.4089	1.2955
12	.4572	1.6766	1.6575	1.7004	1.6461	1.4089	1.4842
13	.4572	1.7604	1.5565	1.6385	1.5546	1.5089	1.5023
14	.4572	1.6766	1.5089	1.5813	1.6651	1.5089	1.4232
15	.3658	1.6766	1.5089	1.4575	1.6118	1.4251	1.3441
16	.4572	1.6804	1.6766	1.4575	1.5384	1.2574	1.406
17	.7316	1.4251	1.3565	1.1336	1.5384	1.2574	1.2498
18		1.0974	1.0631	1.1888	1.086	1.0631	1.0974
19	1.2803	1.0631	1.2403	1.0974	1.2489	1.267	1.2803
20	.9145	.8859	.8954	.9145	.9145	1.086	1.2803
21	.823	.7087	.8954	.9145	.8145	.905	1.0059
22	.7316	.5373	.724	.7468	.724	.724	.7468
23	.5487	.5316	.7087	.5601	.4344	.5373	.5487
24	.8383	.5601	.5316	.543	.4668	.362	.3544
Max	1.7394	1.7604	1.6766	1.7814	1.6651	1.5089	2.0957
Min	.3658	.0549	.5316	.3582	.3734	.362	.3544
Avg	.8726	1.0554	1.1150	1.0673	1.0527	1.0201	1.0596

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013441 / 33 KV SHELGAON

Feeder No / Name : 202 / RAJEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6401	.3391	.6859	.9431	.9831	1.0288	.6859
2	.6401	.3391	.6783	.9431	.1065	1.0898	.8573
3	.7316		.6706	1.0288	1.1469	1.1736	.8573
4	.9145		1.0059	1.0059	1.2146	1.2742	1.0288
5	1.0974		1.3413	1.326	1.3927	1.4586	1.1869
6	1.2803		1.8442	1.6766	1.6194	1.6907	1.5927
7	1.3717		2.3472	2.2634	2.0557		2.13
8	1.4632		2.4034	2.3205	2.4291	2.2119	2.3758
9	1.1336		.8859	.8954	1.086	1.0631	1.0631
10	1.7814		.7087	.8059	.9145	.7973	.8859
11	2.1052		.5316	.4572	.543	.5316	.543
12	2.1862		.5258	.4668	.3696	.5373	.6401
13	2.1862		.5316	.5487	.362	.5316	.6401
14	2.1052		.5316	.5601	.3258	.543	.5487
15	2.0557		.5316	.543	.3658	.5316	.5487
16	2.1862		.3544	.6335	.3326	.543	.6401
17		.724	.7087	.724	.543	.5316	.823
18	.5487	1.0631	.8859	.9335	.9955	.905	.9335
19	.7316	1.1517	.985	.8402	1.267	1.0631	1.0974
20	.5487	.8859	.724	.7316	.9145	.905	1.0059
21	.3658	.7087	.724	.7468	.5487	.724	.9145
22	.3658	.5316	.543	.7373	.5487	.543	.5601
23	.3658	.7087	.6859	.8907	.8417	.6935	.6478
24	.6401	.3277	.6859	.8573	.9831	.8764	.6859
Max	2.1862	1.1517	2.4034	2.3205	2.4291	2.2119	2.3758
Min	.3658	.3277	.3544	.4572	.1065	.5316	.543
Avg	1.1933	.6780	.8967	.9533	.9121	.9238	.9539



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013441 / 33 KV SHELGAON

Feeder No / Name : 203 / BAJARANG CRUSHER FEEDER  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0164	.0187	.0189	.0168	.0187	.0189
2		.0164	.0189	.0189	.0162	.0189	.0189
3		.0164	.0189	.0189	.0158	.0187	.0189
4		.0164	.0187	.0189	.0158	.0187	.0189
5		.0164	.0189	.0189	.0164	.0187	.0189
6		.0164	.0189	.0189	.0164	.0187	.0189
7		.0164	.0189	.0187	.0328	.0187	.0189
8		.0162	.0187	.0187	.0328	.0187	.0373
9	.0164	.0158	.0747	.0181	.0185	.0187	.0187
10	.0819	.0791	.0377	.0185	.0183	.0187	.056
11	.0486	.0972	.1109	.0819	.0914	.0747	.0474
12	.0486	1.5893	.168	.1646	.1294	.0739	.0474
13	.0162	.0739	.168	.1097	.0739	.0739	.0316
14	.0949	.0739	.168	.0914	.1646	.0739	.0158
15	.1107	.1494	.0373	.1848	.1109	.0373	.1581
16	.0655	.1109	.0747	.181	.1294	.056	.1619
17	.0366	.0732	.0924	.0181	.0554	.037	.0914
18	.0164	.037	.0185	.017	.0554	.0747	.017
19	.0164	.0187	.0187	.017	.0185	.0187	.0183
20	.0183	.0189	.0189	.0164	.0185	.0187	.017
21	.0164	.0189	.0189	.017	.0185	.0187	.017
22	.0177	.0189	.0189		.0185	.0187	.0162
23	.0183	.0189	.0189	.0164	.0185	.0189	.0183
24	.0164	.0164	.0189	.0189	.0164	.0185	.0189
Max	.1107	1.5893	.168	.1848	.1646	.0747	.1619
Min	.0162	.0158	.0185	.0164	.0158	.0185	.0158
Avg	.0400	.1059	.0506	.0488	.0466	.0334	.0384

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013445 / 33 KV KANDARI

Feeder No / Name : 201 / KANDARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2452	.743	.1524	.7956	.663	.6767	.9145
2	.3206	.8278	.1524	.9945	.8288	.7472	.9145
3	.415	.9297	.1524	1.1603	1.0774	.8916	.9145
4	.4904	1.034	.3048	1.4251	1.1736	1.0974	1.2193
5	.5658	1.1561	.3048	1.5912	1.2955	1.3123	1.6766
6	.7167	1.2342	.3048	1.8233	1.8233	1.6964	1.829
7	.8676	1.5813	.4572	1.989	1.9559	1.9595	1.9052
8	.6413	1.9784	1.3717	2.3868	2.0719	2.1792	2.1338
9	.547	.6224	.5144	.6224	.4641	.4715	.6001
10	1.5684	.3734	.4287	.4715	.3361	.3429	.3429
11	2.1792	.1715	.2075	.2829	.2054	.1715	.1698
12	2.3807	.1715	.1132	.132	.128	.0857	.1509
13	2.2131	.0857	.132	.132	.128	.0857	.1132
14	2.0972	.1715	.132	.132	.1478	.0857	.1509
15	1.9826	.1715	.1509	.132	.1478	.0857	.1509
16	1.8884	.1715	.1886	.1698	.2054	.0857	.1509
17	1.8842	.2572	.2452	.2075	.2614	.1715	.2075
18	.547	.5144	.4904	.5093	.5658		.4715
19	.5041	.6001	.547	.4715	.4854	.4287	.6602
20	.4527	.4287	.4338	.3772	.4108	.5144	.5093
21	.3547	.3429	.3584	.2829	.3361	.2572	.3018
22	.2378	.1715	.2829	.2263	.2987	.2058	.1886
23	.6093		.7459	.3772	.4652		.6371
24	.2263	.6944	.1715	.6859	.6133	.5898	.7621
Max	2.3807	1.9784	1.3717	2.3868	2.0719	2.1792	2.1338
Min	.2263	.0857	.1132	.132	.128	.0857	.1132
Avg	.9973	.6275	.3476	.7241	.6704	.6428	.7115

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013445 / 33 KV KANDARI

Feeder No / Name : 202 / KHADAKWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9945	.4108	.3429	.3206	.3395	.3772	.3429
2	1.0774	.4481	.3429	.4715	.4338	.3772	.3429
3	1.1603	.4854	.3429	.5658	.5658	.4481	.3429
4	1.326	.5228	.5144	.7167	.6602	.5281	.3429
5	1.442	.6036	.5144	.8676	.7545	.6224	.5144
6	1.8233	.7167	.6001	.9431	.9619	.7167	.5144
7	1.989	.811	.6859	1.0374	1.0751	.8676	.6001
8	2.4863	.7545	.5144	.9431	.9997	.9054	.5144
9	.7167	.547	.5144	.7733	.8488	.7922	.5144
10	.5281	2.4531	2.1338	1.989	2.0005	1.829	1.6766
11	.3584	2.5911	2.9835	2.4034	2.6216	2.0576	2.3472
12	.2263	2.8959	2.9835	2.9835	2.7664	2.5149	2.7664
13	.2195	2.2862	3.0001	3.1493	2.1628	2.2862	2.0119
14	.2195	2.4387	2.652	3.1659	2.6155	2.2862	2.4478
15	.2241	2.5911	3.0664	2.9835	2.7349	2.2862	2.5484
16	.3734	2.7435	1.326	2.8178	2.652	2.21	2.6825
17	.4854	2.4387	2.1548	2.652	2.4905	2.2862	2.4813
18	.6602	.5144	.6036	.6602	.6036	.5144	.7167
19	.7167	.5144	.7167	.5658	.5658	.5144	.7356
20	.5847	.4287	.6036	.5281	.5847	.4287	.5658
21	.5093	.3429	.4715	.4338	.5281	.3429	.3018
22	.3734	.3429	.3772	.3772	.4527	.3086	.3018
23	.3547		.3395	.3772	.3772		.3772
24	.9116	.3584	.2572	.3395	.3395	.3547	.2572
Max	2.4863	2.8959	3.0664	3.1659	2.7664	2.5149	2.7664
Min	.2195	.3429	.2572	.3206	.3395	.3086	.2572
Avg	.8234	1.2278	1.1684	1.3361	1.2556	1.1241	1.0936

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013445 / 33 KV KANDARI

Feeder No / Name : 203 / WALHA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4715	.8619	.9145	.9945	1.1603	1.0402	1.0669
2	.5658	.9511	.9145	1.0774	1.326	1.1248	1.2193
3	.7167	1.0536	1.0669	1.1603	1.5083	1.1888	1.2193
4	.8299	1.1736	1.0669	1.326	1.5746	1.3889	1.6766
5	.9431	1.3279	1.2193	1.5746	1.7404	1.5623	1.829
6	1.1317	1.4403	1.829	1.8233	1.9062	1.7604	1.9814
7	1.226	1.7404	1.829	1.989	2.3205	2.0972	1.9814
8	.9997	1.8991	1.9052	2.3205	2.8645	2.2939	2.1338
9	.8488	.9808	1.0288	1.0374	.9116	.9054	.9431
10	1.6385	.6602	.6001	.9431	.9054	.5144	.5144
11	1.9448	.3429	.5658	.6602	.3547	.4287	.4715
12	2.0972	.3429	.4338	.3772	.2452	.2572	.3018
13	1.989	.2572	.3772	.3584	.2641	.2572	.2263
14	1.8351	.2572	.3395	.3206	.2452	.2572	.2263
15	1.8623	.2572	.2829	.2829	.2641		.2641
16	1.8187	.3429	.2452	.5281	.3772	.2572	.3395
17	1.6804	.4287	.3961	.7545	.4715	.3429	.4338
18	.7545		.8488	.7545	.7545	.8573	.7545
19	.7167	.8573	.9997	.6602	.679	.6859	.8865
20	.5847	.6001	.679	.5658	.5847	.5144	.7545
21	.5228	.5144	.4904	.4715	.5281	.4287	.5093
22	.4108	.3429	1.6409	.415	.4854	.3429	.3772
23	.7225	.7621	.9448	.663	.8642		.8383
24	.3395	.9145		.9448	.9945	.9808	1.0669
Max	2.0972	1.8991	1.9052	2.3205	2.8645	2.2939	2.1338
Min	.3395	.2572	.2452	.2829	.2452	.2572	.2263
Avg	1.1104	.7961	.8964	.9168	.9721	.8858	.9173

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013445 / 33 KV KANDARI

Feeder No / Name : 204 / UJJAINPURI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4973	.4108	.3429	.3961	.3584	.3547	.3429
2	.5967	.4481	.3429	.415	.4715	.3734	.3429
3	.7293	.4854	.3429	.4904	.5281	.4108	.3429
4	.8288	.5281	.4287		.6224	.4668	.4287
5	.9116	.5658	.5144	.6602	.7167	.547	.5144
6	.9945	.6036	.6859	.8488	.8488	.6413	.5144
7	1.0774	.8488	.8573	.9054	.9242	.7922	.6859
8	1.21	.8488	.7716	.811	.5658	.8676	.6859
9	.4904	.4668	.6001	.5375	.3772	.7545	.6859
10	.3174	1.0551	.8383	1.0774	1.0402	.8383	.7621
11	.2427	1.3717	1.326	1.1603	1.1288	1.0669	1.073
12	.1886	1.5242	1.5083	1.4089		1.0669	1.3748
13	.1646	1.6004	1.5083	1.5249	1.2193	1.0669	1.3413
14	.1463	1.6004	1.4089	1.4918	1.3123	1.0669	1.3413
15	.1867	1.5242	1.3757	1.4089	1.2186	1.0669	1.1736
16	.2801	1.5242	1.3426	1.2431	1.1294	1.0669	1.2239
17	.3174	1.2955	1.2597	1.21	1.1431	1.0669	1.1233
18	.5281	.5144	.5093	.5281	.5281	.4287	.4904
19	.5658		.6602	.4904	.5093	.4287	.6602
20	.5093	.5144	.4715	.4527	.4668	.5144	.5093
21	.4338	.3429	.4527	.415	.4481	.3429	.4527
22	.3921	.3429	.415	.3772	.3921	.3429	.3772
23	.3326		.3772	.3584	.3547	.3429	.3395
24	.3978	.3734	.3429	.3772	.3395	.3429	
Max	1.21	1.6004	1.5083	1.5249	1.3123	1.0669	1.3748
Min	.1463	.3429	.3429	.3584	.3395	.3429	.3395
Avg	.5141	.8541	.7785	.8082	.7236	.6774	.7298

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134002 / BHOKARADAN 33 KV

Feeder No / Name : 201 / TADEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	2.2291		2.1434	2.4006	2.4006	1.5432
2	1.3717	2.2291		2.1434	2.4006	2.4006	1.5432
3	1.4575	2.2291		2.2291	2.4006	2.4006	1.5432
4	1.5432	2.4863		2.3148	2.572	2.7435	1.7147
5	1.5432	2.7435		3.4294	3.2579	3.4294	2.4006
6		3.0007		3.4294	3.4294	3.9438	2.7435
7		3.2579		3.4294	3.4294	3.9438	3.4294
8		3.4294		2.572	2.0576	3.4294	2.6578
9	.6859	1.3717	1.7147	.8573	.4287	3.4294	.8573
10	.8573	.6859	1.5432	.8573	.5144	.8573	.6001
11	1.5432	.5144	.6859	.8573	.3429	.6859	.5144
12	1.7147	.6001	.6859	.8573	.6859	.7716	.6859
13	1.3717	.0686	.8573	.8573	.6859	.7716	.6859
14	1.3717	.6859	.6859	.8573	.8573	.7716	.6859
15	1.2003	.6001	.9431	1.0288	.8573	.2572	.7716
16	1.2003	.8573	1.3717	1.0288	1.1145	.2572	.8573
17	.6859	.9431	1.3717	1.2003	1.1145	.3429	.9431
18	1.8004	1.8861	1.7147	1.8861	1.8861	1.7147	1.286
19	1.8861	1.8861	1.9719	1.8004	1.7147	1.8004	1.8004
20	1.8861	1.8861	1.8004	1.7147	1.7147	1.7147	1.5432
21	1.8004	1.8861	1.6289	1.6289	1.7147	1.5432	1.5432
22	1.7147	1.8861	1.4575	1.3717		1.4575	1.3717
23	2.0576	2.0576	1.8004	1.7147	2.4006	1.5432	1.5432
24	1.4575	2.0576	2.0576	2.1434	2.2291	2.4006	1.5432
Max	2.0576	3.4294	2.0576	3.4294	3.4294	3.9438	3.4294
Min	.6859	.0686	.6859	.8573	.3429	.2572	.5144
Avg	1.4616	1.7282	1.3932	1.7647	1.7482	1.8754	1.4503

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134002 / BHOKARADAN 33 KV

Feeder No / Name : 202 / BHOKARDAN TOWN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.8573		.8573	.8573	.8573	.8573
2	.8573	.8573		.8573	.8573	.8573	.8573
3	.7716	.8573		.8573	.8573	.8573	.8573
4	1.0288			.8573	.8573	1.2003	.8573
5	1.2003	1.3717		1.0288	1.2003	1.3717	1.2003
6	1.6289	1.7147		1.2003	1.7147	1.6289	1.5432
7	1.9719	2.0576		1.6289	2.0576	1.8861	2.0576
8	2.0576	2.1434		1.9719	2.1434	2.0576	2.1434
9	2.0576	1.8861	1.7147	2.0576	1.9719	2.0576	2.0576
10	1.7147	1.8861	1.7147	1.7147	1.5432	1.5432	1.7147
11	1.7147	1.5432	1.6289	1.4575	1.5432	1.3717	1.6289
12	1.3717	1.2003	1.3717	1.4575	1.3717	1.286	1.3717
13	1.2003	1.3717	1.2003	1.0288	1.2003	1.2003	1.286
14	1.2003	1.2003		1.0288	1.0288	1.2003	1.2003
15	1.1145	1.2003	1.2003	1.0288	1.2003	1.2003	1.5432
16	1.2003	1.286	1.3717	1.0288	1.5432	1.2003	1.6289
17	1.0288	1.3717	1.3717	1.4575	1.5432	1.3717	1.5432
18	1.8004	1.3717	1.7147	1.8004	1.7147	1.7147	1.7147
19	1.6289	1.2003	1.7147	1.7147	1.7147	1.8004	1.7147
20	1.3717	1.2003	1.4575	1.4575	1.7147	1.4575	1.4575
21	1.2003	1.2003	1.286	1.2003	1.5432	1.286	1.286
22	1.0288	1.2003	1.0288	1.0288	1.0288	1.0288	1.0288
23	.8573	1.0288	.9431	.9431	.8573	.8573	.8573
24	.7716	.8573	.8573	.8573	.8573	.8573	.7716
Max	2.0576	2.1434	1.7147	2.0576	2.1434	2.0576	2.1434
Min	.6859	.8573	.8573	.8573	.8573	.8573	.7716
Avg	1.3110	1.3419	1.3717	1.2717	1.3717	1.3396	1.3825

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134002 / BHOKARADAN 33 KV

Feeder No / Name : 203 / Sipora BZ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	1.0288		1.1145	1.2003	.8573	1.1145
2	.9431	1.0288		1.1145	1.2003	.8573	1.1145
3	.8573	1.0288		1.1145	1.2003	.8573	1.1145
4	1.0288	1.1145		1.286	1.2003	.8573	1.2003
5	1.286	1.1145		1.4575	1.286	1.0288	1.286
6	1.5432	1.286			1.3717		1.3717
7	2.4006	1.286			1.4575		1.4575
8	2.4863	1.1145			1.2003		
9	1.3717	.9431	.6287		1.2003		
10	1.4575	1.7147	1.3717		1.7147	1.7147	1.7147
11		.5144	2.4006	2.0576	1.7147	1.8861	1.7147
12		2.4006	.6859	2.2291	2.0576	1.8861	1.7147
13		2.4863	2.0576	2.2291	1.8861	1.8861	1.8861
14		.8573	2.0576	2.2291	1.8861	1.8861	1.8861
15		2.4006	2.4006	2.0576	1.8861	1.6289	1.5432
16		2.572	1.8004	2.0576		1.6289	1.5432
17		2.0576	1.8861	1.8861	1.8861	1.7147	1.7147
18			1.4575	1.5432	1.8861	1.4575	1.4575
19	1.5432	1.7147	1.7147	1.7147	1.5432	1.6289	1.3717
20	1.4575	1.7147	1.3717	1.6289	1.5432	1.286	1.286
21	1.286	1.5432	1.286	1.5432	1.3717	1.3717	1.286
22	1.286	1.5432	1.2003	1.3717	1.3717	1.2003	1.2003
23	1.0288	1.3717	1.1145	1.286	1.2003	1.1145	1.1145
24	1.0288	1.0288	1.2003	1.1145	1.2003	1.0288	1.1145
Max	2.4863	2.572	2.4006	2.2291	2.0576	1.8861	1.8861
Min	.8573	.5144	.6287	1.1145	1.2003	.8573	1.1145
Avg	1.3771	1.4724	1.5396	1.6334	1.4985	1.3889	1.4185



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134002 / BHOKARADAN 33 KV

Feeder No / Name : 204 / Malkapur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.6001		.6859	.6001	.3429	.6859
2	.4287	.6001		.6859	.6001	.3429	.6859
3	.4287	.6001		.6859	.6001	.3429	.7716
4	.4287	.6859		.8573	.6001	.5144	.9431
5	.5144	.8573		1.0288	.9431	.5144	1.0288
6	.6001	1.0288			1.1145		
7	.8573				1.2003		
8	.9431	1.1145			1.0288		
9	.5144	.6859	.5144		.8573		
10	.6001	.6859	.6859	.8573	.5144	.6859	
11	.6859	.8573	.8573	.7716	.6859	.5144	
12	.3429	.8573	.8573	.6859	.5144	.6001	
13		.8573		.6859	.5144	.4287	
14		.8573	.6859	.6859	.4287	.4287	
15			.5144	.6859	.5144	.2572	
16		.6859	.5144	.6859	.6001	.2572	.6859
17		.2572	.5144	.5144	.5144	.5144	.5144
18		.8573	.9431	1.2003	1.0288	1.1145	.9431
19	1.1145	.8573	1.1145	1.3717	1.0288	1.286	1.0288
20	.9431	.8573	.9431	1.1145	.8573	1.1145	.9431
21	.7716	.6859	.9431	.8573	.6859	.9431	.9431
22	.6859	.6859	.7716	.6859	.6859	.7716	.7716
23	.6001	.5144	.6859	.6001	.5144	.7716	.7716
24	.3429	.6001	.5144	.6859	.6001	.3429	.6859
Max	1.1145	1.1145	1.1145	1.3717	1.2003	1.286	1.0288
Min	.3429	.2572	.5144	.5144	.4287	.2572	.5144
Avg	.6192	.7404	.7373	.8016	.7180	.6044	.8145

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134002 / BHOKARADAN 33 KV

Feeder No / Name : 205 / Fattepur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.1715		.4287	.2572	.1715	.4287
2	.6859	.1715		.4287	.2572	.1715	
3	.6859	.1715		.4287	.2572	.1715	.4287
4	.8573	.2572		.4287	.3429	.3429	.4287
5	1.1145	.4287		.5144	.8573	.6859	.6001
6	1.5432	.6001		.6001	1.1145	.8573	.7716
7	1.5432	.6859		.7716	1.2003	.8573	1.0288
8	1.5432	1.0288		.2572		1.2003	1.3717
9	.3429	.8573	.8573	.1715	.8573	1.3717	1.286
10	.8573	.6859	.6859	.3429	.6859	.5144	.4287
11	.8573	.3429	.5144	.3429	.5144	.4287	.4287
12	.9431	.5144	.4287	.3429	.2572	.5144	.5144
13	.9431	.3429	.6859	.5144	.5144	.6001	.5144
14	.9431	.5144	.6859	.5144	.5144	.5144	.4287
15	.6859	.6859	.6859	.3429	.3429	.6001	.3429
16	.7716	.6859	.4572	.3429	.5144	.3429	.2572
17	.8573	.6859	.6859	.6001	.6859	.5144	.5144
18	1.2003	.8573	1.1145	1.1145	1.0288	1.0288	.8573
19	1.3717	.8573	1.2003	1.2003	1.3717	1.286	1.2003
20	1.2003	.8573	1.1145	1.0288	1.2003	1.0288	1.0288
21	.9431	.8573	.8573	.8573	1.0288	.8573	.7716
22	.6859	.8573	.6859	.6859	.6859	.7716	.6859
23	.1715	.6859	.3429	.1715	.1715	.4287	
24	.6859	.1715	.3429	.3429	.1715	.1715	.4287
Max	1.5432	1.0288	1.2003	1.2003	1.3717	1.3717	1.3717
Min	.1715	.1715	.3429	.1715	.1715	.1715	.2572
Avg	.9216	.5823	.7091	.5323	.6449	.643	.6703

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134002 / BHOKARADAN 33 KV

Feeder No / Name : 206 / W/W EXPRESS FEEDER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0171		.0171	.0514	.0171	.0171
2	.0171	.0171		.0171	.0171	.0171	.0171
3	.0171	.0171		.0171	.0171	.0171	.0171
4	.0171	.0171		.0171	.0171	.0171	.0171
5	.0171	.0171		.0171	.0171	.0171	.0171
6	.0171	.0171		.0171	.0171	.0171	.0171
7	.0171	.0171		.0171	.0171	.0171	.0171
8	.0171	.0343		.0343	.0343	.0171	.0171
9	.0171	.0343	.0343	.0343	.0343	.0171	.0171
10	.0343	.0343	.0343	.0343	.0343	.0171	.0171
11	.0343	.0171	.0171	.0343	.0343	***	.0171
12	.0171	.0171	.0171	.0343	.0343	.0171	.0343
13	.0171	.0171	.0171	.0171	.0343	.0171	.0343
14	.0171	.0171	.0171	.0171	.0343	.0171	.0343
15	.0171	.0343	.0171	.0171	.0343	.0171	.0343
16	.0343	.0343	.0171	.0343	.0343	.0171	.0343
17	.0171	.0343	.0171	.0343	.0343	.0171	.0343
18	.0171	.0343	.0171	.0514	.0343	.0343	.0343
19	.0171	.0343	.0514	.0514	.0343	.0343	.0514
20	.0171	.0343	.0343	.0514	.0343	.0343	.0343
21	.0171	.0343	.0343	.0514	.0343	.0343	.0171
22	.0171	.0343	.0171	.0514	.0343	.0343	.0171
23	.0171	.0171	.0171	.0514	.0171	.0171	.0171
24	.0171	.0171	.0171	.0171	.0514	.0171	.0171
Max	.0343	.0343	.0514	.0514	.0514	31.8245	.0514
Min	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Avg	.0193	.0250	.0235	.0307	.0307	1.3460	.0243

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134002 / BHOKARADAN 33 KV

Feeder No / Name : 207 / Perjapur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.1715		.2572	.1715	.2572	.2572
2	.2572	.1715		.2572	.1715	.2572	.2572
3	.2572	.1715		.2572	.1715	.2572	.2572
4	.2572	.2572		.2572	.2572	.3429	.2572
5	.2572	.4287		.2572	.3429	.3429	.2572
6	.4287	.5144		.3429	.4287	.3429	.3429
7	.6001	.6001		.4287	.6001	.3944	.5144
8	.5144	.4287		.5144		.2743	
9	.3429	.3429	.5144	.4287	.2572	.2743	
10	.6001	.3429	.6859	.2572	.3429		.3429
11	.5144	.3429	.6859	.3429	.3429	.2572	.4287
12	.3429	.5144	.5144	.4287	.2572	.2572	.3429
13	.2572	.5144	.5144	.3429	.2572	.3429	.2572
14	.2572	.5144	.5144	.3429	.2572	.3429	.2572
15	.3429	.5144	.3429	.3429	.2572	.2572	.2572
16	.2572	.6001	.5144	.3429	.2572	.2572	.2572
17	.3429	.6859	.3429	.3429	.2572	.2572	.2572
18	.4287	.4287	.3429	.5144		.3429	.3429
19	.5144	.4287	.4287	.4287		.4287	.4287
20	.4287	.4287	.3429	.3429	.2572	.3429	.3429
21	.3429	.4287	.2572	.2572	.2572	.2572	.2572
22	.2572	.3772	.2572	.1715	.2743	.2572	.2572
23	.1715	.3772	.2572	.1715	.2572	.2572	.2572
24	.3429	.1715	.3772	.2572	.1715	.2572	.1715
Max	.6001	.6859	.6859	.5144	.6001	.4287	.5144
Min	.1715	.1715	.2572	.1715	.1715	.2572	.1715
Avg	.3608	.4065	.4308	.3286	.2784	.2982	.3001

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134006 / 33 KV RAJUR

Feeder No / Name : 201 / KHAMKHEDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.381	.4763	.9945	.9602	.9526	.7716
2	.5716	.4763	.4191	1.1145	1.1145	.9526	.7716
3	.5716	.4763	.5716	1.3375	1.2003	.9526	.8573
4	.5716	.5716	.7621	1.406	1.2346	.9526	.8573
5	.5716	.8573	1.0479	1.3717	1.4575	1.1431	.8573
6	.8573	.9526	1.0669	1.2174	1.5775	1.5242	1.1145
7	.8573	1.2384	1.1241	1.2174	1.5432	1.7147	1.2003
8	.8573	.7621	.9907	1.5947	1.406	1.9052	1.4575
9	.6668	.7621	.8573	.6668	.6097	.7621	.5716
10	1.0288	.9602	.8573	.5144	.381	.381	.4763
11	1.0288	1.2003	1.2003	.3048	.381	.2858	.381
12	1.2003	1.3717	1.286	.2858	.2858	.2858	.4191
13	1.3717	1.3203	1.1145	.381	.2858	.2858	.4763
14	1.286	1.2689	1.2003	.3239	.381	.2858	.4763
15	1.1145	1.1488	1.0288	.3429	.381	.381	
16	1.0288	1.0117	1.046	.4191	.5716	.4763	.3048
17	1.0288	.9088	.9774	.5335	.5716	.6668	.381
18	.4763	.5716	.8573	.7621	.7621	.7621	.381
19	.9526	.9526	.9907	.9145	1.0479	1.0479	.8573
20	.8573	.8764	.8573	.8573	.7621	.8573	.4763
21	.8573	.8002	.5716	.7621	.7621	.5716	.6097
22	.7621	.5716	.6668	.6668	.7621	.6668	.381
23	.5716	.6668	.7202	.6859	.9526	.6859	.5144
24	.5716	.4763	.4191	.6859	.7202	.9526	.5144
Max	1.3717	1.3717	1.286	1.5947	1.5775	1.9052	1.4575
Min	.4763	.381	.4191	.2858	.2858	.2858	.3048
Avg	.8431	.8577	.8796	.8067	.8380	.8105	.6569

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134006 / 33 KV RAJUR

Feeder No / Name : 202 / Chandai Th

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	1.0288	.8573	.5716	.8573	.7621	
2	.9526	1.0288	.9431	.6668	.9526	.7621	
3	.9526	1.2003	1.286	.724	.9907	.7621	
4	1.1431	1.286	1.3717	.7621	.7621	.7621	
5	1.9052	1.3717	1.406	1.2384	1.1431	.7621	
6	1.9052	1.4575	1.2003	1.3336	.9526	1.1431	
7	2.0005	1.6289	1.4403	1.3146	.7811		
8	1.9052	1.4575	1.4575	1.1812	.8764	1.1431	
9	.9526	.8573	1.0479	1.1431	.6097		
10	.381	.6097	.8573	1.3717	1.5242	1.2003	
11	.381	.4191		1.5432	1.4289	1.286	
12	.2858	.4763		1.6975	1.5242	1.1145	1.2003
13	.2858	.4191		1.4575	1.7147	1.2003	1.286
14	.2858	.4572		1.2003	1.5242	1.1145	1.1145
15	.381		.381	1.1831	1.5242	1.0288	1.0974
16			.5335	1.3717	1.5242		.8573
17			.6287		1.1431		.6001
18		.5525	1.2574	1.0288	.7621		.6668
19	1.2384	1.2955	1.2003	1.2765	1.1431		1.0479
20	.9526	.8573	1.0479	.724	.7621		1.0479
21	.8573	.7621	.8002	.9145	.7621		.7621
22	.6668		.7621	.7621	.7621		.6668
23	.6859	.5144	.6668	.5716			.5716
24	.9526		.6516	.5716	.724	.7621	
Max	2.0005	1.6289	1.4575	1.6975	1.7147	1.286	1.286
Min	.2858	.4191	.381	.5716	.6097	.7621	.5716
Avg	.9535	.9305	.9898	1.0700	1.0760	.9859	.9099

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134006 / 33 KV RAJUR

Feeder No / Name : 203 / Rajur Town

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2572	.3429	.3086	.4287	.381	.2572
2	.2858	.2572	.4115	.3601	.4801	.381	.2572
3	.2858	.2572	.3772	.4801	.5487	.381	.2572
4	.2858	.2572	.4287	.3772	.6001	.381	.3429
5	.381	.2572	.5144		.6516	.381	.3429
6	.5716	.4287	.583		.6001	.381	.4287
7	.6668	.6001	.6516	.6173	.6173	.6668	.6859
8	.6668	.6001	.6687	.6001	.6344	.6668	.6001
9	.6668	.5144	.6001	.6001	.6001	.6668	.5144
10	.4287	.5144	.6001	.5144	.6668	.5144	.463
11	.4287	.3086	.4287	.4287	.4763	.4287	.3772
12	.3429	.2572	.4287	.4287	.4763	.3429	.3429
13	.3429	.3086	.3772	.3772	.4763	.3429	.3429
14	.2058	.2915	.2743	.2915	.381	.3429	.3429
15	.3429	.3601	.2743	.3258	.381	.2572	.3429
16	.3429	.3601	.3772	.3429	.381	.3429	.4287
17	.4287	.463	.4115	.3429	.4763	.4287	.4287
18	.6001	.4801	.6001	.5144	.5716	.5144	.4287
19	.6001	.6001	.5144	.6001	.6668	.6001	.5487
20	.4287	.4801	.4287	.3772	.6668	.6001	.4801
21	.4287	.4115	.3086	.3429	.5716		.5144
22	.2572	.4287	.2572	.2572	.4763	.2572	.2572
23	.2572	.3772	.3429	.3429	.381	.2572	.3429
24	.2858	.2572	.3429	.3772	.3601	.381	.2572
Max	.6668	.6001	.6687	.6173	.6668	.6668	.6859
Min	.2058	.2572	.2572	.2572	.3601	.2572	.2572
Avg	.4091	.3887	.4394	.4185	.5238	.4303	.3994

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134006 / 33 KV RAJUR

Feeder No / Name : 204 / LONGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.8573	.6097	.9945	1.0288	1.1431	.8573
2	.7621	.7621	.5716	1.286	1.2346	1.1431	.8573
3	.7621	.7621	.6668	1.3203	1.286	1.1431	1.0288
4	.7621	.8573	.7621	1.3717	1.5432	1.1431	1.0288
5	.7621	.9526	1.0479	.5487	1.5089	1.5242	1.3717
6	1.0479	1.0479	1.2384	1.4575	1.6289	1.9052	1.4575
7	1.0479	1.2384	1.2003	1.3375	1.7147	2.0957	1.5432
8	.9526		.9335	1.4746	1.8519	2.0957	1.8004
9	.9526	1.0288	.9526	.9526	1.105	.7621	.8573
10	1.286	.6859	1.4575	.5716	.7621	.5716	.5716
11	1.2003	1.5089	1.6289	.5716	.4763	.4763	.4763
12	1.3717	.823	1.5432	.4763	.381	.381	.381
13	1.7147	1.7318	1.3717	.381	.381	.381	.381
14	1.5432	1.5604	1.4575		.381		.4763
15	1.4575	1.5432	1.3375		.381		.5144
16	1.3717	1.5089	1.406		.381	.381	.4191
17	1.286	1.3717	1.2689		.381	.5716	.381
18	.9526	.8764			.7621	.8573	.9526
19	1.1431	1.1431	1.0479	1.2384	1.1431	1.1431	
20	.8573	1.0288	.8573	.9526	1.1431	.8573	.9526
21	.7621	.8383	.9145	.8002	.9526	.7621	.8573
22	.5716	.5716	.6097	.5716	.9526	.5716	.6097
23	.5716	.6287	.7716	.8573	1.1431	.6859	.6859
24	.7621	.6668	.6668	.8573	1.0631	1.1431	.8573
Max	1.7147	1.7318	1.6289	1.4746	1.8519	2.0957	1.8004
Min	.5716	.5716	.5716	.381	.381	.381	.381
Avg	1.0276	1.0432	1.0575	.9485	.9828	.9881	.8399



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134006 / 33 KV RAJUR

Feeder No / Name : 205 / TAPOWAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	.7716	.7202	.5335	.5716	.5716	.4763
2	1.1431	1.0288	.8573	.6668	.6668	.5716	.5716
3	1.1431	1.0288	.8916	.5716	.7621	.5716	.5716
4	1.1431	1.2003	.823	.7621	.9145	.5716	.5716
5	1.3336	1.2003	.8573	.8573	.9907	.7621	.6668
6	1.5242	1.4575	.6687	1.0479	.9526	.9526	.8573
7	1.8099	1.6289	1.749	1.0288	1.0479	1.0479	1.1431
8	1.9052	1.3717	1.749	.9526	.9145	1.0479	1.0479
9	.5716	.6668	.6668	.8573	.7049	.7621	.9526
10	.381	.381	.4763	1.166	1.2384	1.1145	.8573
11	.2858	.3048	.3429	1.4575	1.2384	1.1145	.9431
12	.2858	.381	.3048	1.6289	1.3336	1.0288	1.0288
13	.381	.3429	.3429	.4287	1.3336	1.2003	1.0288
14	.2858	.2096	.2858	1.0288	1.1431	.8573	1.0288
15	.381	.3239	.3048	1.4232	1.1431	1.1145	1.0288
16	.381	.4572	.3239	1.3717	1.1431	1.0288	.7716
17		.5525	.4191	1.0288	.9526	.7716	.5144
18	.381	.6859	.7621	.8573	.5716	.7621	.5716
19	.6668	.8573	.7621	.9526	.8573	.8573	.7621
20	.5716	.724	.8002	.9145	.7621	.7621	.7621
21	.4763	.6097	.6097	.7621	.7621	.6668	.5716
22	.5716	.5716	.5716	.5716	.7621	.5716	.4763
23	.4287	.6859	.5716	.6668	.5716	.4763	.5716
24	1.1431	.5144	.7202	.724	.7621	.5716	.5716
Max	1.9052	1.6289	1.749	1.6289	1.3336	1.2003	1.1431
Min	.2858	.2096	.2858	.4287	.5716	.4763	.4763
Avg	.7973	.7482	.6909	.9275	.9209	.8232	.7645

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134006 / 33 KV RAJUR

Feeder No / Name : 206 / CHANDAI EKKO

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.6859	.5487	.5716		.7621	.6668
2	.7621	.6859	.6173	.6097		.7621	.7621
3	.7621	.6859	.7716	.6668		.7621	.7621
4	.7621	.7716	.823	.7621		.7621	.7621
5	.7621	.7716	.8916	.9145		.9526	.8573
6	.9526		1.0288	.9907		1.1431	.9526
7	1.2384	.8573	.9431	.9526		1.1431	1.1431
8	1.1431	1.0288	1.3717	1.0669		1.1431	.9526
9	.9526	.9526	1.0479	.7621		1.1431	.9526
10	.4763	.8573	.9526	1.0288		.9431	.6859
11	.4763	.6668	.7621	1.286		1.0288	.9431
12	.5716	.6097	.6287	1.286	.5716	.8573	.9431
13	.5716	.6668	.6097	1.0288		.9431	.9431
14	.5716	.724	.5716	1.0631	.7621	.7716	.823
15	.4763		.5716	.8573	1.3336	.8573	.8573
16				1.166	1.0479	.8573	.8916
17				1.0288	1.0479	.8573	.7716
18		.4954	1.1431	.7621	.7621	.9526	.7621
19	1.0479	1.0669	1.0479	.9526	1.0479	1.1431	.9526
20	.7621	.8764	.7621	.8002	.9526	.7621	.8573
21	.6668	.7621	.6668	.6668	.7621	.5716	.8002
22	.4763	.5716	.6097	.6668	.7621	.5716	.5716
23	.3429	.4801	.4763		.7621	.4763	.6097
24	.7621	.6001	.6516	.4191		.7621	.5716
Max	1.2384	1.0669	1.3717	1.286	1.3336	1.1431	1.1431
Min	.3429	.4801	.4763	.4191	.5716	.4763	.5716
Avg	.7285	.7408	.7953	.8830	.892	.8720	.8248

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134006 / 33 KV RAJUR

Feeder No / Name : 207 / AT&amp;T TOWER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0829	.0953	.0829
2		.0829	.0953	.0829
3		.0829	.0953	.0829
4		.0829	.0953	.0829
5		.0829	.0953	.0829
6		.0829		.0829
7		.0829	.0953	.0829
8		.0829	.0953	.0829
9		.0829	.0953	.0829
10		.0953	.0829	.0829
11		.0953	.0829	.0829
12		.0953	.0829	.0829
13		.0953	.0829	.0829
14		.0953	.0829	.0829
15		.0953	.0829	.1326
16		.0953	.0829	.0829
17	.0829	.0953	.0829	.0829
18	.0829	.0953	.0829	.0829
19	.0829	.0953	.0829	.0829
20	.0829	.0953	.0829	.0829
21	.0829	.0953	.0829	.0829
22	.0829	.0953	.0829	.0829
23		.0953	.0829	.0829
24		.0829	.0953	.0829
Max	.0829	.0953	.0953	.1326
Min	.0829	.0829	.0829	.0829
Avg	.0829	.0901	.0878	.0850

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134008 / ANWA 33 KV S/S

Feeder No / Name : 201 / ANWA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	.4572	.4239	.4287	.4191	.4477	.4191
2	1.0288	.4287	.4239	.4239	.4191	.4287	.4191
3	1.0288	.5087	.5087	.4096	.503	.4191	.4239
4	1.0288	.5087	.503	.4915	.6097	.503	.4191
5	1.2003	.8002	.6859	.6859	.9145	.8192	.503
6	1.3717	.9145	1.1069	1.1736	1.2041	1.0802	.823
7	1.3717	1.3717	1.7147	1.4746	1.5242	1.406	1.3032
8	1.3717	1.5432	1.8861	1.6766	1.5623	1.5813	1.4861
9	1.3717	1.0669	1.7147	1.0288	1.7147	1.7147	1.0288
10	1.2003	1.0669	1.2003		1.3717	1.2003	1.0288
11	1.2003	.7621	1.0288		.8573		.8573
12	.8573	.5144	.8573	1.0288	.6859	.6859	.8573
13	.8573	.3429	.6859	.7716	.6859	.6859	.8573
14	.8573	.3429	.6859	.6859	.6859	.6859	.6859
15	.6859	.3429	.6859	.6859	.6859	.6859	.6859
16	.6859	.5144	.6859	.7716	.6859	.6859	.7621
17	1.0288	1.3203	.9145	.9145	.9145	.9145	.9145
18	1.3717	1.8861	1.3336	1.3336	1.3336	.9145	1.3717
19	1.8861	2.0748	1.467	1.467	1.467	1.5337	1.7528
20	1.5432	1.4937	1.2003	1.2193	1.3717	1.3717	1.448
21	1.2003	1.307	1.0669	.9145	.9145	1.0669	1.0669
22	1.0288	1.307	.9145	.8383	.7621	.7621	.9145
23	.3582	.4334	.4572	.4287	.4572	.4287	.9431
24	1.3717	.3658	.4334	.4572	.4239	.4572	.4334
Max	1.8861	2.0748	1.8861	1.6766	1.7147	1.7147	1.7528
Min	.3582	.3429	.4239	.4096	.4191	.4191	.4191
Avg	1.1223	.9031	.9411	.8777	.9239	.8904	.8919

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134008 / ANWA 33 KV S/S

Feeder No / Name : 202 / JALGAON SAPKAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.4477	.4334	.4572	.4239	.4572	.4334
2	.5144	.4477	.4287	.4572	.4239	.4477	.4287
3	.5144	.5144	.4287	.4572	.5087	.4287	.5144
4	.5144	.6859	.5201	.5487	.6783	.5144	.8478
5	.6859	1.0059	.6859	.8573	.8573	1.0059	.8478
6	1.0288	1.1736	1.1869	1.1869	1.1469	1.1736	1.1736
7	1.2003	1.1469	1.2003	1.3413	1.1469	1.1736	1.1736
8	1.0288	1.1469	1.2003	1.3413	1.1469	1.1869	1.1869
9	1.0288	.5144	1.0288	.8573	.6859	.6859	1.0288
10	1.0288	.7621	.8573	.8573	.8573	.8573	1.0288
11	1.3717	.9145	1.0288	.8573	.8573	.8573	1.0288
12	1.3717	1.0669	1.0288	1.0288	.8573	.8573	1.2003
13	1.3717	.9907	1.0288	1.0288	.8573	.8573	1.2003
14	1.3717	1.1431	1.0288	1.0288	.8573	.8573	1.2003
15	1.3717	.9907	1.0288	1.0288	.8573	.8573	1.0288
16	1.3717	.9145	1.0288	.9431	.8573	.8573	.9145
17	1.2003	1.1469	.5144	.7621	.7621	.7621	.8383
18	1.0288	1.0974	.9145	.9145	.9145	.9145	.8383
19	1.0288	1.0517	.9145	1.0669	1.0669	.9907	.9145
20	.8573	.8859	.7621	.7621	.7621	.7621	.7621
21	.6859	.5144	.5144	.5144	.5144	.6097	.5144
22	.6859	.5144	.3429	.3429	.3429	.3429	.3429
23	.3582	.4287	.4572	.4572	.4572	.4287	.3429
24	.5144	.3582	.4287	.4572	.4287	.4572	.4287
Max	1.3717	1.1736	1.2003	1.3413	1.1469	1.1869	1.2003
Min	.3582	.3582	.3429	.3429	.3429	.3429	.3429
Avg	.9437	.8276	.7913	.8148	.7612	.7643	.8425

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134008 / ANWA 33 KV S/S

Feeder No / Name : 203 / WAKDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	.4477	.4287	.4572	.4191	.3658	.4287
2	1.0288	.4477	.4239	.5487	.4096	.4477	.3429
3	1.0288	.5144	.5087	.9145	.4801	.4477	.4287
4	1.0288	.5144	.6401	.8573	.6173	.5373	.4239
5	1.2003	.9831	.8002	1.0288	.7716	.602	.5087
6	1.2003	.9602	1.0669	1.3717	1.0669	.9145	.9831
7	1.286	1.5242	1.7147	1.3565	1.5432	1.3889	1.2193
8	1.3717	1.5432	1.7147	1.2003	1.406	1.4232	1.3889
9	1.3717	.9907	1.0288	1.0288		1.0288	1.0288
10	.6859	.5144	.6859			.8573	1.0288
11	.6859	.5144	.5144		.6859	.6859	.8573
12	.6859	.5144	.5144	.6859	.6859	.6859	.8573
13	.6859	.1715	.5144	.6859	.6859	.5144	.6859
14	.6859	.1715	.5144	.6859	.6859	.5144	.6859
15	.6859	.1715	.5144	.6859	.6859	.5144	.6859
16	.6859	.3429	.6859	.7716	.6859	.6859	.6097
17	1.0288	1.307		1.0669	1.0669	.9145	.9145
18	1.3717	1.8861		1.5242	1.3336	1.3336	1.3717
19	1.7147	1.8861	.5144	1.448	1.3336	1.3336	1.467
20	1.3717	1.4937		1.1431	1.2193	1.3717	1.1336
21	1.2003	1.307	.9145	1.0669	1.0669	1.0669	1.0669
22	1.0288	1.307	.7621	.9145	.9145	.8383	.9145
23	.3658	.4287	.4572	.3429	.3658	.4287	.9335
24	1.3717	.3658	.4287	.4572	.4191	.3658	.4287
Max	1.7147	1.8861	1.7147	1.5242	1.5432	1.4232	1.467
Min	.3658	.1715	.4239	.3429	.3658	.3658	.3429
Avg	1.0333	.8462	.7308	.9201	.8431	.8028	.8498

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134008 / ANWA 33 KV S/S

Feeder No / Name : 204 / KALYANI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6401	.503	.6068	.6001	.4572	.5144
2	.6859	.6068	.503	.6001	.5868	.5373	.5144
3	.6859	.6001	.503	.6001	.5868	.5144	.5087
4	.6859	.6859	.5601	.6001	.5335	.5144	.5087
5	.8573	.7545	.6401	.7373	.6097	.7202	.5144
6	1.0288	.9012	.7716	.8802	.9602	.8383	.7621
7	1.0288	1.3108	1.2003	1.1431	1.2193	1.2651	1.0155
8	1.2003	1.3717	1.5432	1.2346	1.186	1.3717	1.186
9	1.2003	.6097	1.0288	.6859	.7716	.6001	.5144
10	.5144	.5144	.5144	.6001	.5144	.4287	.5144
11	.5144	.3429	.2572	.5144	.4287	.3429	.5144
12	.5144	.2572	.2572	.3429	.3429	.3429	.5144
13	.3429	.2572	.2572	.3429		.1715	.5144
14	.3429	.2286	.2572	.3429	.3429	.2572	.3048
15	.3429	.3429	.2572	.3429	.2572	.2572	.3429
16	.3429	.3429	.3429	.2572	.3429	.2572	.3429
17	.4287	.5601	.5335	.5144	.4572	.4287	.5144
18	.8573	.9335	.6859	.7621	.7621	.6859	.7621
19	.8573	.9335	.7621	.7621	.6859	.7621	.9145
20	.6859	.6535	.6097	.6097	.6097	.6097	.6859
21	.5144	.5601	.5144	.5144	.5144	.5144	.6001
22	.3429	.5601	.4287	.4287	.4287	.4287	.5144
23	.5487	.5201	.5487	.5373	.5487	.5201	.4715
24	.8573	.6401	.6001	.6268	.6001	.4572	.5144
Max	1.2003	1.3717	1.5432	1.2346	1.2193	1.3717	1.186
Min	.3429	.2286	.2572	.2572	.2572	.1715	.3048
Avg	.6694	.6303	.5866	.6078	.6039	.5535	.5860

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134008 / ANWA 33 KV S/S

Feeder No / Name : 205 / HISODA BK

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5601	.5601	.4477	.5487	.5601	.5601
2	.5144	.6468	.5601	.5373	.6401	.6468	.6401
3	.5144	.7316	.6535	.7164	.7316	.7316	.7316
4	.5144	.8316	.823	.7716	.7716	.7316	.8954
5	.6859	1.0059	.823	.985	.7716	.985	.8954
6	.8573	1.0059	.8059	1.0745	1.1145	.985	.8573
7	1.0288	1.0745	.8573	1.0288	1.0288	.9431	.8669
8	.8573	1.0288	.8573	1.0288	1.0288	.9536	1.0288
9	1.0288	1.0669			1.2003	1.2003	.8573
10	1.5432	1.3336	1.6289	1.1145	1.5432	1.5432	1.5432
11	2.2291	1.8861	1.7147	1.5432	1.7147	1.5432	1.5432
12	2.2291	1.6004	1.8004	1.8004	1.6289	1.5432	1.8861
13	2.0576	1.7337	1.8004	1.8004	1.5432	1.7147	1.8861
14	2.0576	1.6004	1.8004	1.8004	1.5432	1.5432	1.8861
15	2.0576	1.467	1.8004	1.7147	1.5432	1.5432	1.8861
16	2.0576	1.467	1.7147	1.5432	1.5432	1.3717	1.3336
17	1.8861	1.6004	.6097	1.3336	1.0669	1.2193	1.3717
18	1.0288	1.2136	.8383		.8383	.9145	.7621
19	1.0288	.8402	.8383	.9145	.8383	.9145	.9145
20	.8573	.7468	.7621	.6097	.7621	.7621	.7621
21	.6001	.7468	.5335	.6097	.6097	.6097	.6097
22	.5144	.7468	.5144	.5335	.5144	.6001	.6001
23	.5601	.5601	.4668	.5601	.5601	.5487	.9431
24	.6859	.4668	.5601	.4572	.5487	.5601	.5601
Max	2.2291	1.8861	1.8004	1.8004	1.7147	1.7147	1.8861
Min	.5144	.4668	.4668	.4477	.5144	.5487	.5601
Avg	1.1629	1.0817	1.0141	1.0421	1.0264	1.0279	1.0759



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134015 / HASNABAD

Feeder No / Name : 201 / HASNABAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6401	.3391	.2641	.4527	.3391	.3395	.3018
2		.3391	.2641		.3391	.3395	.3395
3		.5087	.2987	.6413	.5087	.3772	
4	.8779	.5087	.3734		.6783	.4527	
5	1.0608	.5935	.4938	1.0185	.763	.5658	
6	1.2437	.5935	.6584	1.0562	.8478	.7545	.8676
7	1.0974	.9326	.9145	1.094	.9326	1.0751	1.0562
8	1.0608	.9665	.8417	1.0374	.9326	1.0374	1.0374
9		.5935	.9431	.7865	.6783	.4854	.5487
10	.6602	.5426	.7167	.8413	.6783	.6089	.5853
11	.4239	.373		.763	.6089	.5853	1.2887
12	.4239	.3052	.4715	.6783	.5121	.5487	.5596
13	.2883	.3052		.6783	.4572	.5121	.5087
14	.3052	.2543	.3584	.6104	.4119		.4748
15	.3391	.2543		.5087	.4024		.5087
16	.3391	.2883	.415	.5426	.439	.4938	.4239
17	.5087	.5658		.4239	.5658	.4527	.5087
18	.6783	.7922	.6979	.6443	.7545		.6274
19	.6783	.8865		.6783	.9242	.9808	.763
20	.6443	.7733		.6104	.7167		.7122
21	.5087	.5658		.373	.5658		.4239
22	.4239	.4338		.3391	.4527		.3048
23	.4239	.3772	.3658	.3052	.415	.5281	.3391
24	.3018	.2883	.3395	.3206	.2883	.3772	.3206
Max	1.2437	.9665	.9431	1.094	.9326	1.0751	1.2887
Min	.2883	.2543	.2641	.3052	.2883	.3395	.3018
Avg	.6156	.5159	.5260	.6547	.5922	.5842	.5953

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134015 / HASNABAD

Feeder No / Name : 202 / LATIFPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.3391	.3772	.4904	.3391	.2829	.4715
2		.3391			.5087	.2829	.5093
3		.3391	.4527	.6413	.5087	.3395	
4	.7922	.5087	.5281		.6783	.3772	
5	.9808	.5087	.7733	1.0185	.8139	.5658	.8676
6	1.1317	.5935	1.1128	1.0562	.8139	.7167	.9431
7	1.0185	.6783	1.1317	1.094	.8478	.9808	1.0185
8	1.0562	.6783	1.0185	1.0185	.8817	.9431	.9431
9		.8478	.7888	.9431	.6783	.679	.8299
10	1.0242	.8478	1.0288	.679	.6443	.5281	.6979
11	.9326	1.0174		.373	.415		.3391
12	.9156	.9835	1.1706	.2883	.3395	.2263	.3391
13	.763	1.0174		.3052	.3018	.2641	.2883
14	.763	1.0174	1.0059	.2713	.2829		.2883
15	.8478	1.0174		.2035	.2641		.4239
16	.7969	1.0174	1.0242	.2374	.2641	.3584	.3391
17	.5087	.5658		1.3056	1.2689	1.0974	1.3565
18	.6783	.7922	.7733	1.3056	1.2689		1.4074
19	.7122	.9619		.9835	1.1317	1.262	1.1022
20	.7122	.811		.8139	.8745		.9156
21	.5087	.6036		.5935	.6447		.6783
22	.4578	.4715		.5087	.5487		.6274
23	.4239	.415	.4024	.5087	.4527	.6219	.5087
24	.3772	.39	.3772	.3772	.4239	.3772	.5121
Max	1.1317	1.0174	1.1706	1.3056	1.2689	1.262	1.4074
Min	.3772	.3391	.3772	.2035	.2641	.2263	.2883
Avg	.7550	.6984	.7977	.6826	.6332	.5825	.7003

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134015 / HASNABAD

Feeder No / Name : 203 / BORGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	24-DEC-17	25-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7316		.5658		.2829
2					.3395
3			.7167		
4	1.0974				
5	1.2437		.9431		.5658
6	1.4266		.9808		.7545
7	1.5364		1.0185		.5093
8	1.6095		1.0374		.3961
9			1.4632		.8413
10	.4715		1.5546		.9694
11				1.0974	
12		.3395			
13				.9511	
14		.3961			
16		.4338		.9511	
17				.4527	
18		.8488			
19				1.0562	
23		.5121		.4527	
24	.3961		.5093		.2829
Max	1.6095	.8488	1.5546	1.0974	.9694
Min	.3961	.3395	.5093	.4527	.2829
Avg	1.0641	.5061	.9766	.8269	.5491

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134015 / HASNABAD

Feeder No / Name : 204 / NIMGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.3391	.3772	1.1706	1.0174	.8573	.7316
2		.3391	.3772		1.1022	.9259	.8779
3		.5087	.3772	1.3717	1.1869	1.0288	
4	.5281	.5087	.4904		1.1869	1.166	
5	.6602	.6783	.6413	1.4815	1.2717	1.2689	1.4266
6	.7545	.6783	.7733	1.4998	1.2717	1.3717	
7	.8299	.6783	.8488	1.5181	1.5261	1.6804	1.9022
8	.7733	.6783	.7545	1.6278	1.5939	1.7833	
9		.5087	.679	.6979		.5281	.5658
10	.4338	.4578	.3206	.415			.415
11	.2035	.2035		.2543	.1886	.2641	.3052
12	.1696	.1865	.1698	.1526	.2263	.1886	.2204
13	.1526	.1865		.1526	.2263	.1132	.2543
14	.1526	.1865	.1509	.1526	.2263		.1865
15	.1696	.2035		.2035	.2263		.2713
16	.1696	.2374	.1698	.2204	.2263	.2263	.2713
17	1.95	1.6804		.373	.3961	.2829	.4239
18	1.8313	1.8519	1.9387	.5087	.6413		.5935
19	1.5261	1.6118		.5087	.7733	.679	.6783
20	1.3565	1.3889		.4239	.6036		.5765
21	1.2717	1.2346		.5426	.3772		.3391
22	1.1022	1.1317		.4239	.3772		.2543
23	1.0174	1.0288	1.0791	.373	.3772	.3395	.2543
24	1.1157	.9496	.9602	1.0425		.3395	.1886
Max	1.95	1.8519	1.9387	1.6278	1.5939	1.7833	1.9022
Min	.1526	.1865	.1509	.1526	.1886	.1132	.1865
Avg	.7834	.7274	.6318	.6870	.7154	.7673	.5368

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134015 / HASNABAD

Feeder No / Name : 205 / KHADKI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3391	.6036	1.5729	1.0174	.8573	.8779
2		.3391	.6036		1.1022	.9602	.9877
3		.3391	.6413	1.6461	1.1869	1.0802	
4	.679	.5087	.7167		1.1869	1.2689	
5	.8676	.6783	.8676	1.7924	1.2717	1.4746	1.4632
6	1.094	.8478	1.094	1.8656	1.3226	1.7833	2.1582
7	1.1694	.9326	1.094	1.9753	1.8652	2.1605	2.7435
8	1.0374	.9496	1.1317	2.1216	1.95	2.2977	2.5606
9		.8478	1.1694	.9808	.763		.5281
10	.6602	.8478	.8676	.7733	.5935	.7167	.679
11	.3391			.373	.3772	.6036	.373
12	.3052		.415	.3052	.2075	.4904	.2374
13	.3052			.3391	.1886	.2641	.373
14	.2883		.2829	.3561			.2883
15		.3052		.3391			.3052
16	.3052	.3391	.3206	.373	.3395	.3395	.3391
17	1.6956	2.6749		.6783	.5093	.4715	.5087
18	2.8826	2.8807	2.5606	.8478	.9054		.6783
19	2.3739	2.5206		.7969	1.0562	1.0562	.8478
20	1.8821	1.8519		.6274	.7733		.7291
21	1.6108	1.6461		.5935	.679		.6443
22	1.4922	1.5604		.5087	.6036		.4748
23	1.3565	1.4403	1.4998	.4239	.5658	.5658	.4239
24	1.6461	1.2548	1.3375	1.4083		.5658	.4904
Max	2.8826	2.8807	2.5606	2.1216	1.95	2.2977	2.7435
Min	.2883	.3052	.2829	.3052	.1886	.2641	.2374
Avg	1.1574	1.1552	.9504	.9408	.8793	.9974	.8505

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134015 / HASNABAD

Feeder No / Name : 206 / RAJALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3391		.5658	.3391	.4904	.3772
2		.3391	.6036		.3391	.4904	.4527
3		.5087	.6413	.6413	.5087	.5658	
4	.6413	.5087	.7167			.6036	
5	.8048	.763	.811	.7545	.6783	.679	.679
6	.9054	.7969	.9054		.9326	.7545	.7167
7		.7122	.7922	.9054	.7122	.8488	.7733
8	.9054	.7461	.7545	.8865	.7461	.7733	.7545
9		1.3565	1.3889	.7545	.5935	.679	.7922
10	1.6461	1.3565	1.6118	.547	.5087	.415	.4904
11	1.5261	1.3565		.373	.3772	.3772	
12	1.5939		1.6095	.2543	.3395	.3395	.373
13	1.3565	1.3565		.2543		.2641	.373
14	1.3565	1.3565	1.7193	.2713	.1886		.2883
15	1.4413	1.5261		.2713	.2641		.2543
16	1.3565	1.6108	1.5364	.3052	.3018	.2829	.2713
17	.373	.5658		1.5261	1.6461	1.5546	1.6956
18	.4578	.7733	.5093	1.6108	1.7833		1.8652
19	.6443	.9054		1.5261	1.6289	1.7741	1.6956
20	.6443	.6979		1.5091	1.5432		1.5261
21	.5935	.6413		1.4922	1.4575		1.4243
22	.5087	.6036		1.5091	1.2003		1.2548
23	.4239	.6036	.547	1.5091	1.166	1.2803	1.1869
24	.5847		.6036	.5281		1.0631	1.2071
Max	1.6461	1.6108	1.7193	1.6108	1.7833	1.7741	1.8652
Min	.373	.3391	.5093	.2543	.1886	.2641	.2543
Avg	.9071	.8829	.9834	.8569	.8217	.7353	.8786

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134018 / DHAWDA

Feeder No / Name : 201 / DHAWDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.583	.2572	.2915	.3086	.3086	.3086	.3772
2	.6173	.2572	.3258	.3772	.3258	.3429	.3944
3	.6859	.2915	.3429	.4115	.3944	.4458	.3772
4	.7373	.3086	.4115	.4458	.4801	.6173	.463
5	.7716	.4458	.5487	.5144	.6687	.6687	.6687
6	.7888	.7716	.583	.583	.703	.7202	1.0117
7	.6859	.8745	.7545	.823	.7373	.7545	
8		.8059	.8573	.8573	.703	.703	.6859
9	.8573	.7716	1.0288	.9431	.9602	1.0117	.5144
10	.9945	.9431	.9259	.7202	.703	1.0288	.6859
11	.7716	.6859	.823	.5487	.7888	.8573	.583
12	.6001	.4115	.6344	.5144	.6687	.703	.6173
13	.6173	.6687	.583	.583	.5144	.5144	.5487
14	.5144	.6001	.5144	.4801	.4973	.4973	.5316
15	.4801	.5487	.463	.703	.5487	.4801	.5144
16	.4458	.7888	.5487	.823	.6173	.4973	.4458
17	.9602	.8916	.8402	.8745	.7888		.6173
18	.9259	1.1145	.8573	.9602	.8573	.9774	1.0802
19	.8573	.8745	.9088	.8402	.9602	.9088	.9431
20	.7202	.7373	.6687	.7373	.9945	.703	.7888
21	.5487	.6001	.5487	.6173	.9088	.6173	.6173
22	.4458	.4115	.4458	.4973	.5144	.4801	.583
23	.2915	.2743	.3429	.2058		.3772	.3601
24	.2572	.2401	.2572	.2401	.2229	.2401	.3601
Max	.9945	1.1145	1.0288	.9602	.9945	1.0288	1.0802
Min	.2572	.2401	.2572	.2058	.2229	.2401	.3601
Avg	.6590	.6073	.6044	.6087	.6464	.6285	.5987

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134018 / DHAWDA

Feeder No / Name : 202 / WALSAWANGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.286	1.2689	1.166	1.0631	1.1831	1.2003	.8573
2	1.5261	1.2346	1.1488	1.0288	1.406	1.1488	.9259
3	1.6804	1.3032	1.1145	.9945	1.6118	1.1831	.9774
4	1.8519	1.3375	1.3546	1.0974	1.749	1.3546	1.0974
5	1.989	1.3889	1.6461	1.4746	2.0233	1.6632	1.3375
6		1.4403	2.1605	1.7833		1.869	1.6632
7							1.8861
8		.8916	1.0288		1.5604	.9945	
9	.9945	.9259	1.1317	2.0576	1.4746	1.2346	1.2517
10	2.3148	1.5261	1.8176	1.4403	1.8176	1.5604	1.1145
11	2.6063	2.2119	2.2291	2.5034	1.9204	1.5089	.7888
12	2.6749	2.4691	2.2805	2.452	2.0233	1.5432	.703
13	2.7092	2.4863	2.1948	2.3834	2.1948	2.3834	.6516
14	2.572	2.4177	1.3032	2.2805		2.4348	
15	2.5377	2.2291	2.0576	2.2977	2.2462		.6173
16	2.452	2.332	1.8861	2.2291	2.5034		.6344
17	1.3717	1.1831	1.6461	2.2634	1.3032		1.2003
18	1.9719	1.6975	1.7147	1.9547	1.6975	2.4006	1.7318
19	2.1434	1.9033	2.2977	2.0748	2.1434	2.4006	2.332
20	1.9033	1.5604	1.7147	1.869	2.0919	2.0233	2.1605
21	1.5775	1.406	1.4403	1.5947	1.7833	1.7147	2.0062
22	1.5604	1.3889	1.286	.583	1.3889	1.5604	1.7147
23	1.3717	1.3203	1.2003	1.2174		.7716	.8745
24	.6859	1.2346	1.2003	1.0974	1.166	1.2003	.823
Max	2.7092	2.4863	2.2977	2.5034	2.5034	2.4348	2.332
Min	.6859	.8916	1.0288	.583	1.166	.7716	.6173
Avg	1.8943	1.6155	1.6096	1.7155	1.7644	1.6075	1.2431



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134018 / DHAWDA

Feeder No / Name : 203 / BHORKHEDA FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.12	.12	.1372	.12	.1372	.1029
2	.1029	.1372	.1029	.1543	.1029	.1543	.12
3	.1715	.12	.12	.1543	.1543	.1543	.1543
4	.2743	.1029	.1543	.1715	.2058	.1715	.1543
5	.2915	.1372	.2915	.2058	.3086	.2229	.2058
6		.1715	.3772	.2743		.3086	.2401
7							.2743
8		.1543	.2058		.1543	.1372	.3944
9	.1543	.12	.1543	.3086	.1715	.12	.1886
10	.2915	.2572	.3258	.2572	.2229	.2058	.1715
11	.3944	.4973	.3772	.3258	.3429	.2915	.1029
12	.5487	.5144	.3772	.3944	.3772	.3601	.0686
13	.6173	.6001	.5487	.4458	.4115	.3772	.0343
14	.5144	.5487	.5487	.4115	.4115	.3601	.0514
15	.3429	.4115	.4287	.3601	.3944	.3772	.0686
16	.4458	.4458	.3601	.3429	.3086	.4458	.0857
17	.2058	.2229	.3086	.2915	.1543	.3944	.12
18	.2572	.3258	.3086	.3086	.2229	.2572	.2743
19	.2743	.2572	.3086	.2743	.2915	.2743	.2915
20	.2401	.1886	.2058	.2229	.3258	.1886	.2229
21	.1715	.1543	.1715	.1715	.2401	.1543	.1543
22	.1543	.1372	.12	.1543	.1543	.1372	.0686
23	.1372	.1372	.12	.12		.1029	.0686
24	.12	.12	.12	.12	.12	.12	.0857
Max	.6173	.6001	.5487	.4458	.4115	.4458	.3944
Min	.1029	.1029	.1029	.12	.1029	.1029	.0343
Avg	.2768	.2557	.2676	.2549	.2474	.2371	.1543

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134018 / DHAWDA

Feeder No / Name : 204 / JAIDEVWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.7716	.823	.7716	.583	.7888	.3601
2	.6859	.7545	.8916	.7888	.583	.8402	.3772
3	.7716	.7888	.9774	.823	1.046	1.046	.3772
4	.823	.9088	1.0802	.8916	1.0974	1.1831	.4287
5	.9259	1.2174	1.166	1.0974	1.166	1.3375	.703
6	1.166	1.3546	1.2517	1.2174	1.2346	1.4918	.8402
7	1.5604	1.3889	1.4575	1.3717	1.3717	1.6461	
8		1.3889	1.5775	1.4575	1.4403	1.6804	.4801
9	.6859	.6516	.703	.703	.6173	.6516	.7545
10		.5487	.4801	.463	.4973	.5316	1.5089
11	.2743	.4115	.4115		.4801	.4458	1.7318
12	.2401	.2915		.2915	.4287	.3086	1.6804
13	.2572	.2743	.2401	.2572	.3601	.2401	1.6118
14	.2572	.2572	.2743	.2401	.2572	.2743	1.5432
15	.2915	.2743	.2401	.3258	.3086	.2915	1.5089
16	.2915	.3772	.2915	.3601	.3429		1.4232
17	.5144	.463	.4115	.4801	.3772		1.2003
18	.703	.7202	.6001	.7545	.6859	.8573	.6516
19	.6859	.7545	.703	.7202	.7373	.7545	.703
20	.583	.6001	.6344	.7373	.7716	.6344	.6687
21	.463	.5144	.5144	.703	.7202	.5144	.6173
22	.4115	.3944	.4287	.6859	.4287	.463	.5487
23	.2743	.2743	.5487	.6173		.3601	.4458
24	.6859	.7545	.8059	.7545	.6687	.7373	.3429
Max	1.5604	1.3889	1.5775	1.4575	1.4403	1.6804	1.7318
Min	.2401	.2572	.2401	.2401	.2572	.2401	.3429
Avg	.5986	.6723	.7179	.7179	.7045	.7763	.8916

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134018 / DHAWDA

Feeder No / Name : 205 / 11kv Wadot T

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	1.0288	.8916	.9259	.7373	.9088	
2	.8573	1.0631	.9259	.9602	1.0974	.9945	.463
3	.9088	1.0631	.9945	1.0288	1.166	1.0631	.463
4	.9602	1.1317	1.1317	1.0974	1.2346	1.1831	.4973
5	1.0974	1.3546	1.3032	1.2003	1.3032	1.3032	.6516
6	1.286	1.4918	1.406	1.3032	1.3717	1.5261	.7202
7	1.6975	1.6632	1.6118	1.3375	1.4403	1.5947	
8		1.5775	1.7147	1.3889	1.3717	1.5089	.583
9	.6687	.6516	.6173	.3772	.6173	.6344	.4458
10	.3258	.6859	.463	.3429	.4458	.2915	1.2003
11	.2229	.3086	.3086	.4115	.2743	.3086	1.5261
12	.2915		.3086	.3258	.3086	.2743	1.5947
13	.3086		.3086	.3258	.3601	.2572	1.6461
14	.3258		.3086	.2572	.3601	.2915	1.5604
15	.3601		.4115	.3258	.2743	.3086	1.3717
16	.2915			.4458	.3086	.3086	1.2346
17	.5487	.2401	.4973	.583		.5658	1.0974
18	.8059	.703	.6001	.7545		.7373	.703
19	.7716	.7716	.8573	.7202	.7202	.8059	.8059
20	.703	.7202	.6687	.703	.7888	.7202	.7373
21	.583	.5316	.6173	.7202	.7373	.6173	.6687
22	.4973	.463	.5316	.6687	.463	.5658	.5658
23	.3429	.7373	.6859	.6859		.5316	.5658
24	.703	.9945	.8573	.8916	.7202	.8745	.463
Max	1.6975	1.6632	1.7147	1.3889	1.4403	1.5947	1.6461
Min	.2229	.2401	.3086	.2572	.2743	.2572	.4458
Avg	.6687	.9043	.7835	.7409	.7667	.7573	.8893

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134029 / PIMPALGAON (R) 33 KV

Feeder No / Name : 201 / Relgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.6908	.7164	.4572	.5788	.4572	.4572
2		.7655	.6097	.5335	.6348	.4115	.5335
3	.7621	.9145	.6401	.6097	.7655	.2286	.6859
4	.9145	1.0059	.7773	.7621	.8596	.1829	.6859
5	1.0669	1.0974	1.0517	.9145	.9511	.2591	.7621
6	1.1584	1.2986	1.1888	1.0212	1.1157		.8383
7	1.829	1.6956	1.1431	1.0059		.7621	.8383
8	1.9509	2.0005	1.0364	.9755	.9145	.9145	.8383
9	2.0576	2.2672	.7926	.8383	.7655	.6859	.6859
10	2.1491	2.4486		.6859	.5975		.503
11	2.4006	2.4539		.8029	.3963		.6348
12		2.4844		.5601	.442		.6161
13	2.2862	2.271	.6554	.6535	.381	.2591	.5788
14	2.1445	2.0881	.4268	.6348	.2896	.2743	.4481
15	.6535			2.4387	2.0424	2.3624	2.0957
16	.6908	.6401		2.9607	2.3167	2.4387	2.5749
17	.7842	.7926	2.4082	2.6073	2.271	2.21	2.6566
18	1.134	.6573	2.4387	2.1765	2.1338	1.9814	2.1925
19	1.1888	1.1126	1.9052	1.9669	1.6309	1.5242	1.8004
20	.8962	.1219	1.6918	1.8204	1.5546	1.3413	1.6975
21	.823	.8688		1.7013	1.448	1.2803	1.5364
22	.7468		1.1736	1.6461	1.3108	1.2193	1.4632
23	.6535	.6401	.6097	.7655	.6401	.6859	
24	.5792	.5601	.6097	.442	.7282	.5639	.503
Max	2.4006	2.4844	2.4387	2.9607	2.3167	2.4387	2.6566
Min	.5335	.1219	.4268	.442	.2896	.1829	.4481
Avg	1.2456	1.3125	1.1042	1.2075	1.0769	1.0021	1.1142

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134029 / PIMPALGAON (R) 33 KV

Feeder No / Name : 202 / Pimpalgaon R SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4268	.5041	.3963	.3658	.4294	.381	.381
2	.4572	.5601	.381	.4572	.5041	.3506	.4572
3	.5335	.6535	.4115	.5335	.6161	.4115	.5335
4	.6097	.7468	.6401	.6859	.8048	.5335	.6097
5	.6859	.7865	.9297	.8383	.9877	.8688	.6859
6	.7621	.8779	1.0669	.945	1.1157	1.1126	.7164
7	.9907	1.1888	1.0212	.8383		.6706	.9145
8	1.1279	.9328	.7164	.6859	1.1888	.6249	1.0669
9	1.1888	1.2803	.5487	.6859	1.1523	.7316	.7621
10	1.2193	1.4922	.5487	.6859	.9145	.7468	.6554
11	1.56	1.326	.7926	.6161	.5487	.5335	.6722
12		1.3108		.4108	.4725	.3658	
13	1.3717	1.6004		.3734	.4268	.3658	
14	1.3395	1.3565	.3353	.3174	.3048	.381	
15	.5041	.3353	1.3717	1.5242	1.4022	.8383	1.647
16	.4668		1.7833	1.7295	1.4632	.9907	1.9204
17	.7095	.6706		1.9784	1.448	1.2193	1.9204
18	.9877	1.0059	1.448		1.4784	1.4632	1.5043
19	1.2254	.7773	1.2193	1.439	1.2803	1.3717	1.4864
20	1.0242	.7926	1.0669	1.4449	1.1431	1.2193	1.3717
21	1.0242	.7468	.9907	1.4083	1.0669	1.1431	1.1157
22	.5601	.503	.9145	1.2437	.9297	1.0669	1.0974
23	.5041	.381	.5335	.6161	.5182	.4572	.6535
24	.4115	.5415	.381	.3353	.4668	.442	.3353
Max	1.56	1.6004	1.7833	1.9784	1.4784	1.4632	1.9204
Min	.4115	.3353	.3353	.3174	.3048	.3506	.3353
Avg	.8561	.8857	.8332	.8765	.8984	.7621	.9765

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134029 / PIMPALGAON (R) 33 KV

Feeder No / Name : 203 / LEHA/SHELUD FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.829	2.0005	.6097	.6097	.6722	.5182	.5335
2	1.89	2.0567	.5944	.7621	.7468	.5335	.7621
3	1.9052	2.0405	.6249	.9145	.8775	.6097	.9145
4	1.9509	2.0891	.8718	1.0669	1.0059	.7773	.9907
5	1.9814	2.1214	1.2041	1.2193	1.2986	1.0974	1.0669
6	2.0881	2.2213	1.4175	1.3717	1.448	1.2651	1.1584
7	1.1431	1.3717	2.21	2.2862		2.1338	2.21
8	1.0974	1.3169	2.4844	2.6673	2.834	2.4844	2.3167
9	.9907	1.0059	2.4844	2.8197	3.1687	2.7587	2.4387
10	.7621	.8962	2.7282	3.0178	2.9287	2.6368	2.5149
11	.5788	.4877		2.9607	2.6978	2.5911	2.2885
12		.3353	2.8959	3.0567	2.8045	2.5606	2.4966
13	.3048	.3506	2.5911	2.9447	2.652	2.5149	2.4486
14	.3921	.3048	.8535	2.8967	2.2862	2.4387	2.2672
15				.2743	.2743	.381	.3734
16	.4668			.4668	.3201	.2896	.3734
17	.7316		.9145	.7468	.6859	.6097	.7282
18	1.2437		1.0669	1.262	.8993	.8078	1.3535
19	1.39		.945	1.3717	1.1736	.7621	1.1523
20	.8779		.884	1.0242	1.0059	.9145	1.0791
21	.7865		.7621	.9145	.823	.8383	.9145
22	.7282		.6554	.7842	.6401	.6859	.7095
23	1.7147		.6097	.7468	.6097	.6097	.6535
24	1.9509	2.0348	.5944	.5792	.6908	.5639	.6097
Max	2.0881	2.2213	2.8959	3.0567	3.1687	2.7587	2.5149
Min	.3048	.3048	.5944	.2743	.2743	.2896	.3734
Avg	1.2184	1.3756	1.3334	1.5319	1.4149	1.3076	1.3481

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134029 / PIMPALGAON (R) 33 KV

Feeder No / Name : 204 / PARADH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.6348	1.0059	1.829	2.0178	1.7833	1.829
2	.6097	.7282	.9907	1.6766	1.9839	1.8138	1.6766
3	.7621	.7842	1.1233	1.7528	2.0348	1.8595	1.6004
4		1.0242	1.0669	1.829	2.0957	1.89	1.6004
5	1.0669	1.2437	1.1279	1.9052	2.1795	1.9204	1.6766
6	1.2955	1.4083	1.1584	1.9814	2.2801	1.9509	1.7985
7	1.2651	1.4998	1.2346	1.1431		1.2651	1.1431
8	1.2193	1.3717	1.2041	1.2193	1.2803	1.1279	1.2193
9	1.0669	1.0425	.9755	1.0669	1.1706	1.0364	1.0974
10	.8535	.9877	.9297		.9877	.884	2.0454
11	.823		.5792	.8962	.7468	.6859	.5788
12			.6097	.6908		.5792	.6535
13	.5182		.5182	.6908		.5182	.6161
14	.4854		.5335	.5601		.4572	.5415
15	2.1862		.6859	.442		.4115	.5601
16	2.4006		.8078	.6348		.381	.5788
17	2.3685			.823	.7164	.6097	.823
18	2.2885			1.2071	1.0517	.945	1.1706
19	2.1214		.8535	1.3169	1.0364	.884	1.2986
20	1.9845		.7621	.9328	.9297	.7773	1.0974
21	1.9839		.6706	.7468	.8688	.6859	.8215
22	1.8821		.5792	.6535	.5182	.5944	.6722
23	.7468		1.7528	1.7147	1.5851	1.6766	1.9281
24	.4877	.6535	1.0212	1.8442	1.95	1.6766	1.8595
Max	2.4006	1.4998	1.7528	1.9814	2.2801	1.9509	2.0454
Min	.4854	.6348	.5182	.442	.5182	.381	.5415
Avg	1.3159	1.0344	.9178	1.1981	1.4130	1.1006	1.2036

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134029 / PIMPALGAON (R) 33 KV

Feeder No / Name : 205 / Awghadrao sawangi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.4108	.3201	.3048	.3734	.3048	.381
2	.4572	.4668	.3048	.3658	.4668	.3353	.4572
3	.6859	.5041	.3353	.4572	.5788	.381	.6097
4	.8383	.7468	.442	.6097	.7682	.6097	.6859
5	.945	1.0059	.8688	.7621	1.0059	.7164	.7621
6	1.0212	1.2437	1.0517	.8688	1.1523	.7926	.8535
7	1.0517	1.3717	.6859	.823		.7468	.884
8	1.0974	1.262	.7926	.7621	.9877	.7926	.9145
9	.9145	.9145	.7468	.7621	1.0242	.823	.9297
10	.6554	.8048	.7773	.7621	.9145	.8078	.9297
11	.6161	.5639	.7621	.9145	.7468	.7621	.8596
12		.4268	.7468	1.0059	.6706	.7316	.8048
13	.4115		.6097	.823	.6249	.7164	.7842
14	.3734	.3353	.6706	.7655	.5944	.6859	.7499
15	.9145		.6097	.3048	.2896	.5335	.3734
16	1.0974		.5335	.4668	.442	.3963	.3547
17	1.0059		.884	.7468	.4877	.6859	.6908
18	.9877		.9297	1.1706	.9755	.8688	1.1523
19	1.0059		.8383	1.134	.9297	.8383	1.1157
20	.8962		.7011	.7842	1.5546	.7621	.8596
21	.6908		.5335	.6535	1.448	.6097	.5601
22	.5415		.381	.4294	1.3108	.381	.4294
23	.4668		.3353	.3734	.3353	.3048	.3734
24	.2743	.3734	.3048	.2896	.3361	.3201	.3048
Max	1.0974	1.3717	1.0517	1.1706	1.5546	.8688	1.1523
Min	.2743	.3353	.3048	.2896	.2896	.3048	.3048
Avg	.7515	.7450	.6319	.6808	.7834	.6211	.7008



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134035 / 33 KV KEDERKHEDA S/S

Feeder No / Name : 201 / KEDARKHEDA ag1

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.4973	.4534		.4475
2				.5138	.4534		.4641
3				.547	.4858		.4973
4				.5967	.5182		.5801
5				.6299	.5506		.6133
6				.663	.6154		.6796
7				.6962	.7287		.7293
8				.7459	.8421		.7956
9			.4999			1.0669	
10		1.1431	.8749				
11	1.3336	1.2193	.4973				
12	1.1431	1.2574	1.094				
13		1.2384	1.0277				
14		1.1241	.9614				
15		1.1241	.9448				
16		1.1622	.9448				
17		1.0669	.779				
23			.431	.5144		.5636	.4973
24				.4807	.4382		.4475
Max	1.3336	1.2574	1.094	.7459	.8421	1.0669	.7956
Min	1.1431	1.0669	.431	.4807	.4382	.5636	.4475
Avg	1.2384	1.1669	.8055	.5885	.5651	.8153	.5752

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134035 / 33 KV KEDERKHEDA S/S

Feeder No / Name : 202 / DEOLGAON TAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4696	.2096	.2286		.2477
2			.5182	.2286	.2477		.2667
3			.5668	.2667	.2858		.3048
4			.5668	.3429	.3429		.362
5			.6154	.4191	.381		.4191
6			.8421	.4763	.381		.4954
7			1.1336	.5716	.4954		.5335
8			1.4251	.4191	.4954		.381
9	1.8099			.4572	.4191	.4382	.362
10				1.21	.9069	1.1241	.8288
11				1.4089	1.105	.9614	.8785
12				1.4586		.9945	.8785
13				1.4752	1.3336	.9448	.9116
14				1.3923	1.105	.8122	.7956
15		.1524	.1905	1.2431		.5716	.7956
16		.2858	.3048	1.0608	1.1431	1.0479	.8288
17		.381	.362	1.0111	1.3336	.7956	.6796
18		.4954	.4191				.6796
19		.4572	.4954				
20		.4001	.381				
21		.3048	.2667				
22		.2286	.2667				
23		.3077	.2667	.2286			.2286
24			.3563	.2096	.2286		.2477
Max	1.8099	.4954	1.4251	1.4752	1.3336	1.1241	.9116
Min	1.8099	.1524	.1905	.2096	.2286	.4382	.2286
Avg	1.8099	.3348	.5248	.7415	.6520	.8545	.5563

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134035 / 33 KV KEDERKHEDA S/S

Feeder No / Name : 203 / KEDARKHEDA AG 2

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2486			.2321
2				.2486	.3048		.2321
3				.2652	.2858		.2486
4					.3239		.2652
5				.2984	.3429		.2652
6				.3315	.381		.2984
7				.3812	.4382		.3315
8				.3978	.4954		.2984
9			.2286				
10		.5716	.5335				
11	.7621	.5144	.4973				
12	.2858	.5716	.547				
13		.5335	.4973				
14		.4954	.5304				
15		.4763	.4475				
16		.4954	.4807				
17		.4382	.3978				
19		.4382					
23				.2286		.1989	.2286
24				.2155	.2858		.2321
Max	.7621	.5716	.547	.3978	.4954	.1989	.3315
Min	.2858	.4382	.2286	.2155	.2858	.1989	.2286
Avg	.5240	.5038	.4622	.2906	.3572	.1989	.2632

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134035 / 33 KV KEDERKHEDA S/S

Feeder No / Name : 204 / DEOLGAON TAD G

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1334	.1334	.1905		.1334
2			.1524	.1334	.2286		.1334
3			.1905	.1524	.2667		.2096
4			.3429	.2667	.2858		.3429
5			.5335	.4001	.362		.4001
6			.6097	.4763	.4572		.5335
7			.6287	.5335	.5144		.5716
8			.6097	.4001	.5144		
9	.5716		.4572	.4954	.4572	.6478	.4954
10		.8002	.3429	.2667		.2667	.2286
11	.381	.1524	.1905	.2096	.3048	.1143	.0953
12	.2667	.1143	.1334	.1334		.0953	.0953
13		.1143	.0953	.1143	.1905	.0762	.0953
14		.1143	.0762	.0953	.0953	.0762	.0572
15		.1334	.0953	.1143		.0762	.0572
16		.1334	.1715	.1715	.1143	.1143	.1524
17		.2667	.2858	.2286	.2667	.2096	.2858
18		.4572	.4763	.4572	.3429	.4382	.4572
19		.5144	.5525	.4954		.5716	.5144
20		.3429	.3048	.3239		.4001	.4001
21		.1905	.1715	.1905		.2096	.3429
22		.1715	.1524	.1524		.1715	.1334
23		.1334	.1524	.1334		.1334	.1334
24			.1334	.1334	.1334		.1334
Max	.5716	.8002	.6287	.5335	.5144	.6478	.5716
Min	.2667	.1143	.0762	.0953	.0953	.0762	.0572
Avg	.4064	.2599	.2913	.2588	.2953	.2401	.2609

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134035 / 33 KV KEDERKHEDA S/S

Feeder No / Name : 205 / KEDARKHEDA G

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4763	.5144	.5716		.4954
2			.5144	.5144	.6097		.4954
3			.5716	.5716	.6859		.5716
4			.724	.8002	.8573		.9145
5			1.2955	.9145	1.0288		1.086
6			1.4861	1.1431	1.2765		1.3717
7			1.5432	1.5051	1.4289		1.5623
8			1.3717	1.3908	1.2765		1.4861
9	.8764		1.1431	1.3717	1.3717	.8573	1.2193
10		.8764	.8192	.8764	.9907	.8573	.9717
11	.8573	.4001	.5335	.6478	.7621	.5144	.5716
12	.5335	.2858	.4191	.4572		.4572	.4763
13		.3048	.3048	.362	.381	.362	.4382
14		.2858	.362	.4001	.3429	.3429	.4191
15		.381	.3239	.362		.3429	.4382
16		.4191	.381	.5144	.4572	.5144	.4763
17			.5716	.743	.5716	.743	.7049
18		1.3336	1.105	1.3908	1.1431	1.2574	1.3336
19		1.3336	1.2193	1.448		1.5432	1.5051
20		.8192	.8954	1.2384		1.1431	1.2003
21		.724	.743	.7621		.8002	.9526
22				.6287		.5906	.6668
23		.6097	.5906	.5335		.5335	.5716
24			.5716	.5144			.4954
Max	.8764	1.3336	1.5432	1.5051	1.4289	1.5432	1.5623
Min	.5335	.2858	.3048	.362	.3429	.3429	.4191
Avg	.7557	.6478	.7811	.8169	.8597	.7240	.851

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134044 / DANAPUR 33 KV S/S

Feeder No / Name : 201 / Surangli AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.9945	1.0288	.9431	.6859
2				1.0288	1.0288	.9431	.7202
3				1.1145	1.1145	.9945	.7716
4				1.3203	1.2003	1.0288	.7888
5				1.4575	1.2003	1.046	.8916
6				1.5432	1.286	.9259	1.046
7				1.6804	1.7147	1.406	1.1145
8				1.7833	1.8004	1.4918	1.166
10	.1029	1.8519	1.9033				
11	.12	2.3834	2.0748				
12	2.2462	2.4691	2.4177				
13	2.4691	2.3834	2.0748				
14	2.6063	2.1091	2.0748				
15	2.5377	2.4691	2.2291				
16	2.3663	2.4006	2.2462				
17	2.2462	2.1605	1.9204				
18		2.1605					
23					.6859	.6344	.7716
24				.9774	.9088	.7716	.6687
Max	2.6063	2.4691	2.4177	1.7833	1.8004	1.4918	1.166
Min	.1029	1.8519	1.9033	.9774	.6859	.6344	.6687
Avg	1.8368	2.2653	2.1176	1.3222	1.1969	1.0185	.8625

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134044 / DANAPUR 33 KV S/S

Feeder No / Name : 202 / KATHORA BAZAR GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.4338	.3584	.3584	.4287	.3772	.3772
2	.4287	.4338	.3772	.3772	.5144	.4715	.3961
3	.5144	.5093	.3772	.3772	.6001	.4715	.4527
4	.6001	.6036	.5281	.5658	.6859	.6602	.5281
5	.9088	.7733	.6602	.7167	.9431	.7545	.6602
6	1.0288	.7922	1.0185	1.0374	1.0288	1.0185	.7733
7	1.0288	.8299	.5847	.7167	.823	.9997	.7922
8	.7716	.7733	.6036	.7167	.6859	.9431	.6602
9	.5144	.6979	.3395	.679	.5144	.7545	.7545
10	.2641	.5281	.547	.5144	.5144	.5658	.4904
11	.3395	.3206	.415	.4287	.3944	.3395	.4527
12	.4527	.2452	.3395	.3429	.3429	.2829	.3772
13	.415	.2075		.3429	.2572	.2452	.3018
14	.2829	.2829	.2641	.3772	.2572	.2641	.2829
15	.2641	.2829	.2641	.4287	.2572	.3018	.3018
16	.5281	.3772	.4715	.5144	.4287	.4715	.3395
17	.6036	.679	.703	.7888	.6859	.7167	.6979
18	1.0374	.9431	.8488	.9431		.9054	.3944
19	.8676	.8865	.8865	.7716	1.0288	1.0185	.7888
20	.7167	.5847	.7167	.6859	.7733	.7545	.6001
21	.5847	.547	.5093	.6173	.4715	.5658	.5144
22	.5281	.4715	.3395	.4287	.3584	.4527	.4287
23	.415	.415			.3395	.3584	
24	.4287	.415	.3584	.2452	.3772	.3395	.3086
Max	1.0374	.9431	1.0185	1.0374	1.0288	1.0185	.7922
Min	.2641	.2075	.2641	.2452	.2572	.2452	.2829
Avg	.5814	.5431	.5232	.5641	.5526	.5847	.5076

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134044 / DANAPUR 33 KV S/S

Feeder No / Name : 203 / Dagadwadi Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.1029	.0857				
2		.1029	.0857				
3	.2401	.12	.1029				
4	.2572	.12	.12				
5	.2572	.1372	.1543				
6	.3429	.2229	.1372				
7	.4287	.2743	.3429				
8	.5144	.3601	.3086				
10				.1715	.1715	.1543	.1715
11				.2401	.2572	.2058	.1715
12				.2743	.3086	.2401	.2263
13				.2572	.3086	.2058	.1715
14				.2572	.2572	.2229	.2401
15				.2743	.2572	.2058	.2572
16				.2572	.2572	.2058	.1886
17				.2743	.2401	.1372	.12
18				.2743			
19					1.0288		
20							.12
21							.1715
22							.1029
23	.0686	.0514					.1029
24	.2058	.0857	.0686				
Max	.5144	.3601	.3429	.2743	1.0288	.2401	.2572
Min	.0686	.0514	.0686	.1715	.1715	.1372	.1029
Avg	.2801	.1577	.1562	.2534	.3429	.1972	.1703



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134044 / DANAPUR 33 KV S/S

Feeder No / Name : 204 / Express Water Supply  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.0343		.0343				
6			.0514		.0343		.0343
7		.0514	.0514	.0514		.0514	.0514
8	.0343	.0514	.0514	.0514		.0514	.0514
9		.0514	.0514	.0514		.0514	.0514
10		.0514	.0514	.0514		.0514	.0514
11		.0686	.0514	.0514		.0514	.0514
12		.0514	.0514	.0514		.0686	.0514
13		.0514	.0514	.0514	.0686	.0514	.0514
14		.0343	.1029	.0514	.0514	.0514	.0514
15		.0343	.0514	.0514	.0514	.0514	.0514
16		.0514	.0514	.0514	.0514	.0514	.0514
17		.0514	.0343	.0514	.0514	.0514	.0514
18		.0514	.0514	.0514		.0514	
19		.0514	.0514	.0514	.0514	.0686	
20		.0686	.0343	.0514	.0514	.0514	.0514
21		.0514	.0514	.0514	.0514	.0514	.0343
22		.0343	.0514	.0514	.0514	.0514	
23		.0343			.0343		
24		.0514			.0514	.0343	
Max	.0343	.0686	.1029	.0514	.0686	.0686	.0514
Min	.0343	.0343	.0343	.0514	.0343	.0343	.0343
Avg	.0343	.0495	.0514	.0514	.0500	.0524	.0490

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134044 / DANAPUR 33 KV S/S

Feeder No / Name : 205 / Danapur GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.3018	.3206	.3206	.4287	.3961	.2829
2	.5144	.3395	.3395	.3395	.4287	.4715	.3018
3	.6859	.4527	.3584	.3584	.5144	.5658	.7167
4	.8573	.6602	.4904	.5658	.6859	.7545	
5	1.0288	1.1694	.7167	.7922	.9431	1.1506	1.094
6	1.0288	1.0374	1.226	1.2637	1.0288	1.3203	
7	1.0288	.9054	1.1694	.9431	.9431	1.1883	
8	.8573	.9054	.8488	.9431	.8573	1.1317	1.1317
9	.7716	.9997	1.0751	.8299	.6859		1.0562
10		.5847	.8488	.5144	.4287	.6602	.7167
11		.415	.5658	.4287	.3429	.415	.3772
12	.4527	.3961	.415	.2572	.3429	.2641	.3206
13	.4338	.2829	.3772	.2572	.3086	.2075	.3018
14	.3584	.3206	.3584	.2915	.2572	.2263	.3395
15	.3772	.3206	.3018	.2572	.3429	.2263	.3772
16	.5658	.3961		.4287	.4458	.2641	.4715
17	.7356	.3961	.5658	.6001	.5144		.7545
18	1.094	1.0185	1.1317	1.0288		1.1883	.6859
19	1.1694	1.0562	1.0751	.9431	1.1145	1.1128	.8573
20	.811	.8488	.8865	.6859	.8299	.811	.7716
21	.6036	.6036	.6224	.5144	.6036	.547	.6001
22	.4715	.5281	.3772	.3772	.3772	.3961	.4287
23	.3206	.3395			.3584	.3206	.3944
24	.3944	.3018	.3395	.3395	.3429	.3772	.3018
Max	1.1694	1.1694	1.226	1.2637	1.1145	1.3203	1.1317
Min	.3206	.2829	.3018	.2572	.2572	.2075	.2829
Avg	.6852	.6075	.6550	.5774	.5707	.6362	.5849

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134044 / DANAPUR 33 KV S/S

Feeder No / Name : 206 / GODRI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.5316	.5316				
2	.4287	.5487	.5144				
3	.5144	.5487	.5487				
4	.5144	.5658	.5487				
5	.6001	.679	.6001				
6	.6859	.823	.5658				
7	.8573	1.1317	1.0288				
8		1.166	1.286				
9	1.2003						
10				1.1145	.7716	1.0117	.7716
11				1.2003	1.1145	1.3375	1.1488
12				1.3717	1.3717	1.4575	1.2003
13				1.286	1.4403	1.3546	1.286
14				1.286	1.3717	1.3717	1.1145
15				1.5432	1.286	1.2003	1.0631
16				1.286	1.2517	1.286	1.1317
17				1.166	.0514	1.0802	1.0288
23	.4115	.3772					
24	.3429	.5316	.4973				
Max	1.2003	1.166	1.286	1.5432	1.4403	1.4575	1.286
Min	.3429	.3772	.4973	1.1145	.0514	1.0117	.7716
Avg	.5898	.6903	.6802	1.2817	1.0824	1.2624	1.0931

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134044 / DANAPUR 33 KV S/S

Feeder No / Name : 207 / KARKHANA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.0857	.0514				
2	.1715	.0857	.0857				
3	.1715	.12	.0686				
4	.1886	.1543	.1029				
5	.2058	.1886	.1372				
6	.2572	.3258	.1715				
7	.3429	.5144	.3601				
8	.4801	.5487	.4287				
10				.2572	.1715	.1715	.1372
11				.4287	.2572	.2915	.2401
12				.6001	.3772	.3429	.2229
13				.5144	.4287	.3772	.2401
14				.6173	.3429	.3429	.2058
15				.6001	.3086	.2572	.1886
16				.5487	.2401	.2401	.1543
17				.5144	.1715	.1372	.0686
23	.0857	.0343					
24	.1372	.0686	.0343				
Max	.4801	.5487	.4287	.6173	.4287	.3772	.2401
Min	.0857	.0343	.0343	.2572	.1715	.1372	.0686
Avg	.2178	.2126	.1600	.5101	.2872	.2701	.1822

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134044 / DANAPUR 33 KV S/S

Feeder No / Name : 208 / KATHORA BAZAR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.3203	1.3717	1.406	1.1831
2				1.286	1.4575	1.4575	1.166
3				1.3375	.5487	1.4575	1.166
4				.8573	1.4575	1.4918	
5				1.5432	1.4918	1.5089	1.5089
6				1.7147	1.5089	1.5432	1.749
7				1.869	1.9204	1.9204	1.9033
8				1.9547	2.0576	2.0576	2.0576
10	2.1434	1.7833	2.0233				
11	2.3148	2.2805	2.1948				
12	2.6063	2.4691	2.572				
13	2.5549	2.4348	2.5206				
14	2.3148	2.5206	2.4863				
15	2.2634	2.3663	2.4691				
16	2.2462		2.0576				
17	2.1776	1.9376	1.9719				
23					1.2003	1.2003	
24				1.2346	1.4403	1.2346	1.1831
Max	2.6063	2.5206	2.572	1.9547	2.0576	2.0576	2.0576
Min	2.1434	1.7833	1.9719	.8573	.5487	1.2003	1.166
Avg	2.3277	2.2560	2.2870	1.4575	1.4455	1.5278	1.4896

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134060 / NALNI

Feeder No / Name : 201 / NALNI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9831	.9831	1.1469	.3768	.3277	.3932	.5735
2	1.065	.9831	1.2289	.3932	.3277	.3932	.6554
3	1.1469	1.065	1.3108	.3932	.3277	.4915	.7373
4	1.2289	1.2289	1.3435	.4915	.4096	.5735	.7865
5	1.3108	1.3108	1.3763	.5735	.4915	.6554	.8192
6	1.6385	1.5565	1.3927	.639	.7373	.8192	.8356
7	1.8023	1.8023	1.6712	.7701	.8192	.9012	.7865
8	1.7532	1.6385	1.704	.7045	.7373	.852	.6062
9	.7209	.7373	.7209	.6226	.6554	.7209	.6226
10	.6554	.6226	.7209	1.7814	1.8351	1.6057	1.5238
11			.5571	1.8842	1.8842		1.704
12	.4096		.4915	1.8623	1.8023		1.7695
13	.4915		.4752	2.0481	1.8842	1.8023	1.8351
14	.4915	.4096	.4588	2.0481	1.8842	1.8515	1.6549
15	.4096	.4588	.4588	2.0481	1.8351	1.8023	1.704
16	.4915	.5571	.4915	2.0243	1.8351	1.8842	1.6876
17	.5735	.7209	.5407	1.6194	1.6057	1.6712	1.4091
18	.6554	.8356	.7209	.6001	.6554	.6554	.6062
19	.6554	.852	.7701	.6859	.7865	.8356	.639
20	.5735	.5571	.5243	.5144	.6882	.7865	.5571
21	.4915	.4752	.4588	.5144	.5243	.5735	.4588
22	.4096	.4096	.3768	.4287	.4588		.3605
23	.3277	.3605	.3277	.3429	.3932	.4096	.3605
24	.2458	.2458	.2294	.3277	.3429	.3768	.426
Max	1.8023	1.8023	1.704	2.0481	1.8842	1.8842	1.8351
Min	.2458	.2458	.2294	.3277	.3277	.3768	.3605
Avg	.8057	.8481	.8124	.9873	.9687	.9550	.9633

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134060 / NALNI

Feeder No / Name : 202 / PIMPALGAON BARAV

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5735	.4915	.4915	.6554	.8192	.8192	1.1469
2	.5735	.4915	.5735	.6718	.9012	.8192	1.2289
3	.5735	.4915	.6226	.6882	.9012	.9831	1.278
4	.6554	.6554	.6554	.7209	1.065	1.065	1.3108
5	.8192	.8192	.6554	.7373	1.1469	1.4746	1.3927
6	.9503	.9012	.6882	.7373	1.3927	1.6385	1.4582
7	.9503	.9012	.7865	.7209	1.8842	1.8023	1.7368
8	.9012	.8192	.6226	.9995	1.8023	1.6712	
9	1.6057	1.5565	1.5565	.8684	.8192	.9012	.5079
10	1.5565	1.5893	1.491	.4858	.6554	.5079	.4588
11		1.4419	1.5402	.4049	.4752	.3605	.3932
12		1.4091	1.3927	.3239	.3605	.2785	.3277
13	1.5565	1.4419	1.2616	.3239	.3605	.2949	.2785
14	1.3927	1.3108	1.1961	.3239	.3605	.3277	.2622
15	1.2289	1.2125	1.1469	.3277	.3441	.3932	.2949
16	1.1469	1.2125	1.0814	.3239	.3605	.3605	.3441
17	.4915	.3932	.4424	.4049	.5735	.5243	.4588
18	.7373	.8029	.7865	.7716	.852	.8356	.6882
19	.9012	.9012	.8192	.7716	.9667	.8356	.7373
20	.7373	.7701	.7537	.6859	.9012	.7045	.7865
21	.6554	.6882	.6882	.6001	.6226	.4915	.639
22	.6554	.6554	.6062	.5144	.5735		.5571
23	.5735	.5735	.4588	.6001	.852	.4915	.7701
24	.5407	.4915	.5407	.4424	.8573	.8192	.8029
Max	1.6057	1.5893	1.5565	.9995	1.8842	1.8023	1.7368
Min	.4915	.3932	.4424	.3239	.3441	.2785	.2622
Avg	.8989	.9176	.8691	.5877	.8270	.8000	.7765

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134060 / NALNI

Feeder No / Name : 203 / KHAPERKHEDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3277	.3277	.4916	.7373	.6554	1.3108	.6554
2	.3277	.3277	.5244	.852	.7373	1.6384	.7373
3	.3605	.3277	.5898	.9339	.7373	1.9662	.7865
4	.4096	.4096	.5898	1.0159	.8192	2.13	.8192
5	.4915	.4915	.6554	1.1142	.9012	2.2938	.9012
6	.5735	.4915	.6554	1.2125	1.065	2.4578	.9339
7	.5407	.5735	.7864	1.2452	1.4746	2.7854	1.1142
8	.4915	.4915	.7864	1.5729	1.3927	2.687	1.4091
9	.4096	.4915	.721	.426	.4096	.983	.3605
10	.3277	.3277	.1966	.4049	.3605	.426	.3605
11	.2458	.3113	.2458	.4049	.3277	.2949	.2785
12		.3277	.2785	.2458	.721	.3277	.3441
13	.2458	.3441	.2785	.4049	.721	.3768	.2949
14	.2458	.3441	.2622	.4049	.721	.3441	.3113
15	.2458	.2949	.2785	.4049	.721	.3605	.3277
16	.1638	.2458	.1475	.4049	.721	.3113	.3113
17	1.5565	1.3108	.0983	.4858	.9176	.3441	.426
18	1.3108	1.491	.2949	.6001	1.1142	.5735	.5407
19	1.3108	1.3435	.5735	.6001	1.2124	.5079	.5407
20	1.3108	1.1797	.4752	.5144	1.0486	.3932	.5243
21	1.1469	1.0486	.4096	.3429	.9176	.3277	.3768
22	1.1469	1.0159	.3277	.3429	.6554	.3932	.3277
23	1.065	.9175	.5079	.5144	1.147	.4096	.2294
24	.852	.9831	.8684	.5407	.6859	1.1961	.6062
Max	1.5565	1.491	.8684	1.5729	1.4746	2.7854	1.4091
Min	.1638	.2458	.0983	.2458	.3277	.2949	.2294
Avg	.6568	.6424	.4601	.6553	.8410	1.0350	.5632



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134064 / 33 kv Pimpalgaon KO

Feeder No / Name : 201 / Pimpalgaon Ko SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1696	.1715	.1753	.3174	.3361	.3292	.3475
2	.2543	.2058	.1928	.2987	.3734	.4024	.3841
3	.3052	.2204	.2229	.3361	.4066	.4572	.4572
4	.3688	.3222	.2572	.3696	.5175	.6036	.5304
5	.4694	.4578	.3086	.5359	.6584	.6584	.5853
6	.503	.57	.4191	.7316	.7865	.7682	.8048
7	.663	.6718	.6371	.7207	.9511	.8779	.8779
8	.7865	.663	.7373	.6767	.7316	.8413	.8048
9	.499	.499	.5487	.5729	.6653	.7133	.6767
10	.2614	.2926	.3292	.2543	.2204	.3688	.3688
11	.1698	.1646	.168	.3222	.2543	.4527	.2883
12	.1886	.1109	.1307	.4475	.3353	.3521	.2713
13	.1509	.1109	.112	.4641	.3481	.3978	.3052
14	.1509	.1294	.1307	.3812	.3647	.4144	.2883
15	.168	.1109	.0934	.3978	.3481	.3315	.3391
16	.1867	.1109	.112	.3391	.3315	.3481	.2713
17	.3174	.2033	.168	.2883	.2486	.3315	.3052
18	.5175	.4024	.4435	.5359	.5121	.4755	.394
19	.7023	.695	.5853	.6767	.695	.695	.6485
20	.5729	.4938	.4805	.5729	.567	.567	.5847
21	.499	.4024	.3696	.4805	.4572	.4572	.5014
22	.4251	.3658	.3511	.4251	.3658	.4024	.4298
23	.1357	.1629	.3511	.3734	.3292	.3292	.3403
24	.1526	.1865	.1629	.2883	.3734	.3109	.3292
Max	.7865	.695	.7373	.7316	.9511	.8779	.8779
Min	.1357	.1109	.0934	.2543	.2204	.3109	.2713
Avg	.3591	.3218	.3120	.4503	.4657	.4952	.4639

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134064 / 33 kv Pimpalgaon KO

Feeder No / Name : 203 / Vazirkheda SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.4108	.3475	.3052	.2543	.4359	.2683
2	.3921	.4435	.439	.3391	.3052	.4527	.3521
3	.4251	.5359	.5487	.3561	.3353	.503	.4191
4	.462	.6036	.6584	.4359	.5365	.5304	.5197
5	.7207	.7133	.823	.4862	.6796	.6299	.6133
6	.9877	.9694	1.0242	.663	.8619	.9175	.9339
7	.9979	1.0679	1.1157	.9831	1.247	1.2289	1.3765
8	.9511	.9955	.695	1.166	1.247	1.2955	1.3117
9	.8962	.8962	.9145	.8413	.8779	.7316	.9511
10	.8288	.7209	.7956	.6099	.6283	.567	.6767
11	.7956	.8192	.7459	.3361	.4066	.3109	.3366
12	.9448	.8684	.7865	.1867	.2561	.2743	.2507
13	.9503	.8848	.9339	.1867	.2561	.2561	.2328
14	.8684	.7865	.9012	.2054	.2033	.1848	.2328
15	.788	.7865	.8192	.2801	.2195	.2561	.2328
16	.7293	.852	.7373	.2801	.2926	.2926	.3224
17	.663	.7373	.7045	.4251	.4572	.4572	.4477
18	.7762	.695	.5914	.7316	.695	.6767	.7186
19	.8962	.9145	.9145	.9328	.9145	1.0608	.9991
20	.7207	.695	.6838	.567	.6401	.823	.7796
21	.5729	.5853	.5359	.5359	.4755	.567	.5611
22	.4481	.4572	.4066	.3696	.3475	.3658	.4119
23	.4251	.3475	.1696	.2543	.3353	.2204	.2534
24	.3696	.3881	.3475	.2035	.2883	.4024	.2347
Max	.9979	1.0679	1.1157	1.166	1.247	1.2955	1.3765
Min	.3696	.3475	.1696	.1867	.2033	.1848	.2328
Avg	.7076	.7156	.6933	.4867	.5317	.5600	.5599

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134065 / MALKHEDA

Feeder No / Name : 201 / AVANA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.094	1.1128	1.2197	.4715	.5228	.8326	.7682
2	1.1694	1.094	1.2567	.4715	.5975	.823	.8596
3	1.1706	1.0751	1.2752	.5658	.6584	.9145	.9412
4	1.2437	1.0751	1.3491	.6602	.8048	1.0974	1.0317
5	1.3717	1.4712	1.386	.7167	.823	1.2308	1.086
6	1.4712		1.423	.7545	1.2071	1.267	1.2127
7			1.46	.9431	1.8298	1.7909	1.6651
8				1.1317	2.2192	2.0058	1.9728
10	1.2894	1.1222	.9054	1.3203	1.094	1.386	1.1317
11	1.0924	1.1946	.8676	.7922	.8676	.9795	.5658
12	1.1946	1.0745	1.094	.6036	.5847	.6838	.5093
13	1.1523	1.1222	.9431	.547	.5658	.5359	.5093
14	.8779	1.0498	.8299	.4904	.4527	.499	.4904
15	.8962	.7602	.7545	.547	.4715	.5359	.5281
16	.8413	.9412	.6036	.6602	.6036	.6099	.7167
17	.8413	.7783	.5281	1.1128	.9054	1.0349	.9242
18	1.3014	1.3121	1.358	1.2826	1.3014	1.386	1.4712
19	1.4335	1.46	1.1317	1.4712	1.4901	1.46	1.3203
20	1.1317	1.46	1.0562	1.2071	1.3203	1.46	1.094
21	1.0562	1.4415	.9808	1.0562	1.3392	1.4415	.9808
22	1.0751	1.386	.811	.9808	1.3203	1.423	.811
23	1.0374	1.3306	.3772	.5281	.695	.4938	.3018
24	1.1317	1.094	1.2936	.3206	.679	.7316	.7133
Max	1.4712	1.4712	1.46	1.4712	2.2192	2.0058	1.9728
Min	.8413	.7602	.3772	.3206	.4527	.4938	.3018
Avg	1.1368	1.1678	1.0411	.8102	.9719	1.0706	.9394

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134065 / MALKHEDA

Feeder No / Name : 202 / MUTHAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9054	1.1888	1.086	.6413	.7167	.7356	.5359
2	.9808	1.1584	1.1584	.6413	.7545	.7167	.5729
3	1.0242	1.1888	1.2489	.5658	.811	.7545	.6099
4	1.0974	1.134	1.3073	.5658	.8299	.7922	.6468
5	1.2071	1.3756	1.379	.5281	.8488	.811	.6838
6	1.3352	1.4327	1.4148	.9054	.8865	.811	.7023
7	1.6278	1.4864	1.4506	.9431	.8488	.8299	.6653
8	1.6278	1.6118	1.6297	.8865	.7733	.8299	.6468
9	.6602	.6413	.5914	.7545	.7167	.679	.5853
10	.5093	.499	.5281	1.7375	.7059	1.5223	1.3957
11	.4338	.3696	.4715	1.8642	1.7013	1.5581	1.5089
12	.3961	.3696	.3772	1.9004	1.7741	1.5223	1.5089
13	.3772	.3326	.3961	1.8823	1.701	1.5581	1.4712
14	.3395	.3142	.3961	1.828	1.6461	1.379	1.3392
15	.3206	.3881	.547	1.7375	1.4632	1.2308	1.4146
16	.3206	.4435	.547	1.6289	1.5043	1.267	1.358
17	.6602	.5359	.6224	1.5546	1.3937	1.1222	1.2449
18	.7733	.6653	.7733	.7545	.679	.6653	.5658
19	.7733	.7207	.6602	.811	.7733	.3881	.5658
20	.6979	.6653	.7545	.8488	.7733	.6099	
21	.7167	.6283	.7733	.811	.7545	.5914	.6224
22	.6979	.5914	.679	.7545	.7356	.5359	.5658
23	.9511	.7964	.6602	.7167	.7356	.5359	.5281
24	.8488	1.0974	1.0498	.6413	.6979	.7167	.5359
Max	1.6278	1.6118	1.6297	1.9004	1.7741	1.5581	1.5089
Min	.3206	.3142	.3772	.5281	.679	.3881	.5281
Avg	.8034	.8181	.8542	1.0793	1.0094	.9235	.8815

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134065 / MALKHEDA

Feeder No / Name : 203 / IBRAHIMPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.4024	.3982	.7167	.8299	.8865	.8131
2	.5281	.439	.4706	.7167	.9054	.8865	.8686
3	.5658	.5121	.543	.8488	1.0185	.9808	.9425
4	.6036	.5121	.5973	1.0374	1.1317	1.2449	1.0719
5	.6401	.7392	.7164	1.226	1.2071		1.2752
6	.6401	1.0059	.9671	1.3203	1.4335		1.423
7	1.39	1.3575	1.1641				
8	1.5912	1.5729	1.4685	1.1317			
9	1.0185	1.1317	1.1283	1.3203	1.1694		1.2254
10	.7545	.7023	.9808	1.0242	1.1403	.9231	.7545
11	.4904	.499	.6036	1.1222	.9955	.9593	.7167
12	.3961	.3696	.415	1.1041	.905	.7059	.6979
13	.415	.2772	.3772	1.0317	.823	.6697	.811
14	.3018	.3511	.3395	1.1041	.8596	.5068	.7356
15	.2926	.2957	.3584	.9231	.6584	.5068	.6602
16	.3584	.3326	.3584	.695	.7783	.4706	.6602
17	.6413	.5359	.5093	.7316	.724	.543	.6413
18	1.1506	1.0534	.9619	1.0374	1.0185	1.1827	.9431
19	1.3957	1.3306	1.1317	1.3203	1.4335	1.423	1.226
20	.9997	1.0719	.9997	1.0374	1.0562	1.1643	1.3203
21	.8488	.8501	.9054	.9431		.961	.9997
22	.7922	.7392	.7733	.9054	.9431	.8316	.811
23	.3961	.362	.7545	.8676	.9054	.8131	.7922
24	.4527	.362	.362	.7356	.7733	.8488	.7762
Max	1.5912	1.5729	1.4685	1.3203	1.4335	1.423	1.423
Min	.2926	.2772	.3395	.695	.6584	.4706	.6413
Avg	.7147	.7002	.7202	.9957	.9862	.8689	.9166

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134001 / 33KV JAFRABAD

Feeder No / Name : 201 / ALAND

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601	.2972	1.9662	1.9319	2.1195	2.1195	2.0008
2	.4001	.3567	1.9662	2.0062	2.1195	2.1382	2.0687
3	.4734	.4161	1.989	2.0805	2.2043	2.1548	2.1195
4	.6173	.6133	2.1195	2.4034	2.2377	2.1548	2.1195
5	.6722	.6241	2.1195	2.4034	2.3739	2.1879	2.2043
6	.7407	.8619	2.1548	2.4697	2.4034	2.2891	2.2891
7	.7956	.8471	2.2045	2.5526	2.4863	2.2708	2.4587
8	.6135	.9282	1.8404	2.1072	2.6791	2.3205	2.4863
9		.6716	.6802	.7468	.6535	.7371	.6668
10		1.9147	.3601	.4934	.4001	.4868	.4668
11	2.0271	1.9862	.2267	.3201	.2534	.2643	.2652
12	2.0138	2.0862	.1734	.1867	.1734	.2225	.2155
13	2.0138	2.1148	.1734	.2155	.1467	.153	.1823
14	1.9738	1.9719		.16	.1334	.1391	
15	1.9471	2.0862			.16	.1947	.1823
16	1.9204	2.0576			.2134	.2858	.2667
17	1.9719	1.8938	.6573			.4287	
18	.4287	.6001	.6859	.7674		.6859	
19	.6859	.5335	.7145	.6344	.7287	.543	.663
20	.6144	.4934	.6226	.5487	.5357	.5144	.6796
21	.5144	.4001	.5801	.5304	.5636	.5596	.4252
22	.5138	.431	.431	.4161	.431	.4475	.4534
23	.4475	1.8842	2.0348	1.989	1.9662	1.989	2.1376
24	.3978	.3121	1.989	2.0719	2.1195	2.0056	1.9669
Max	2.0271	2.1148	2.2045	2.5526	2.6791	2.3205	2.4863
Min	.3601	.2972	.1734	.16	.1334	.1391	.1823
Avg	1.0065	1.0993	1.2233	1.2874	1.2319	1.1372	1.2532

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134001 / 33KV JAFRABAD

Feeder No / Name : 202 / JANEFAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6783	.8402	.3978	.4641	.3481	.4144	.431
2	.763	.8288	.4144	.4973	.4144	.4641	.4641
3	.78	.9116	.4144	.5801	.4641	.4973	.4973
4	.78	.9945	.4973	.663	.5801	.5801	.5801
5	.8139	1.0402	.663	.7459	.7459	.6962	.663
6	1.17	1.21	.7459	.8288	.8288	.9945	.7459
7	1.4922	1.5746	.8619	.8785	.9448		.8951
8	1.2548	1.757	.6299	.8619	.8619		.7956
9	.6299		.5967	.7956	.7459	.8478	
10	.3978	.4973	1.5581	1.0608	1.094	1.0852	.9448
11	.1989	.2984	1.5581		1.1271	1.17	.9945
12		.1492	1.5249	1.1437	1.1271	1.1869	1.0774
13	.1326	.1492	1.326	1.1437	1.094	1.0513	1.0774
14	.1326	.1989	1.1603	1.1437	1.0277	1.153	.9448
15		.1658	1.1603		.9779	1.0343	.8453
16	.2321	.2155	1.1105	1.0774	.9614	.9945	
17	.4973	.4475	1.1271	1.0608	.9614	.9614	1.094
18	.7956	.5801	.4475	.7293	.7293	.8951	.9614
19	.7293	.663	.8453	.9116	.9614	.8288	.9116
20	.663	.779	.7956	.8122	.8288	.7956	.8785
21	.5636	.6299	.663	.6962	.663	.6796	.7459
22	.4973	.5138	.547	.5636	.5304	.547	.5636
23	.6962	.4475	.4641	.4641	.4641	.4807	.4641
24	.6443	.663	.4144	.4144	.3647	.4641	.4641
Max	1.4922	1.757	1.5581	1.1437	1.1271	1.1869	1.094
Min	.1326	.1492	.3978	.4144	.3481	.4144	.431
Avg	.6610	.6763	.8301	.7971	.7853	.8101	.7745

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134001 / 33KV JAFRABAD

Feeder No / Name : 203 / BHARAJ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4409	.5304	.9945	1.0774	1.2431	.9945	.9945
2	.5426	.5801	1.0277	1.1271	1.326	1.0277	1.0277
3	.6443	.663	1.0774	1.1603	1.4089	1.0774	1.0774
4	.7122	.7459	1.1603	1.3426	1.4918	1.1271	1.1603
5	.763	.8288	1.1934	1.4089	1.5746	1.1603	1.442
6	.763	.9614	1.4089	1.5746	1.6575	1.5746	1.6575
7	1.0004	.9945	1.4918	1.8233	1.7901	1.8896	1.8233
8	1.0343	.9282	1.7238	1.8896	2.0388	1.8564	2.0056
9	.8122	.6706	.9448	.9116	1.0442	.9665	.6299
10	1.757	1.7436	.5636	.6464	.6962	.583	.5636
11	1.6907	1.8107	.3812	.431	.4641	.3391	.3647
12	1.7238	1.9951	.2984	.2818	.3315	.4748	.2321
13	1.7736	1.6095	.2155	.3315	.2321	.373	.2486
14	1.7736	1.5927	.0995	.3481	.2486	.4409	.3149
15	1.4586	1.861	.1326	.1006	.2984	.2713	.3315
16	1.5415	1.6598	.1492	.1326	.3647	.4359	.3978
17	1.5746	1.5083	.7042	.1677	.218	.503	.1823
18	1.0059	.663	.7545	.9389	.2515	.8551	.1989
19	.8886	.7625	.8551	.8551	.9389	.6371	.7459
20	.7042	.6796	.663	.6706	.6371	.6036	.7293
21	.6036	.5304	.547	.4973	.547	.5138	.5801
22	.4641	.4475	.4973	.3812	.4144	.4973	.4807
23	.431	.8785	.9116	1.1271		.8785	.8785
24	.407	.4973	.9116	.9945	1.2431	.9282	
Max	1.7736	1.9951	1.7238	1.8896	2.0388	1.8896	2.0056
Min	.407	.4475	.0995	.1006	.218	.2713	.1823
Avg	1.0213	1.0476	.7795	.8425	.8896	.8337	.7855



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134001 / 33KV JAFRABAD

Feeder No / Name : 204 / ASAI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7293	.5967	.3978	.3647	.3978	.4973	.4973
2	.7459	.6299	.431	.3978	.4641	.5304	.547
3	.7956	.663	.5601	.3978	.4973	.5801	.663
4	.7282	.6962	.5801	.431	.5304	.663	.7459
5	.8453	.7956	.6299	.5801	.5801	.7459	.7956
6	.8288	.8619	.663	.6299	.6299	.9614	.8619
7	.8288	.9116	.7293	.6962	.663		
8	.9779	1.0277	.5967	.6299	.663		
9	.431	.3812	.4475	.4144	.4475	.6783	.5138
10		.2321	1.3592	1.2431	1.0277	1.0105	1.1603
11		.6464	1.5083	1.3923	1.1437	1.2431	.9779
12		.0995	1.4255	1.3923	1.1271	1.2929	1.094
13		.1006	1.2431	1.2431	1.0774	1.1603	1.0277
14			1.2929	1.094	1.1437	1.0608	.9614
15	.116		1.1603	.7459	.9945	.9116	.8785
16	.1658		1.094	1.0277	1.0277	1.0277	.9054
17	.3315		1.1603	.9945	.9945	.9945	.8785
18	.7127	.663	.5138	.7459	.7459	.6962	.7459
19	.8453	.9116	.5967	.6796	.7956	.7127	.7459
20	.6706	.6962	.6796	.663	.6464	.6962	.7127
21	.6133	.663	.5304	.6299	.663	.7468	.5801
22	.5138	.5304	.4973	.5138	.5304	.5636	.4807
23	.5138	.4475	.431	.4641	.4973	.5138	.4475
24	.7461	.5801	.4144	.3978	.4144	.5975	.5138
Max	.9779	1.0277	1.5083	1.3923	1.1437	1.2929	1.1603
Min	.116	.0995	.3978	.3647	.3978	.4973	.4475
Avg	.6389	.6067	.7893	.7404	.7376	.8129	.7607

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134001 / 33KV JAFRABAD

Feeder No / Name : 205 / TEMBHURNI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8488	.7049	.3048	.381	.3048	.3429	.362
2	.8488	.6859	.3429	.381	.3429	.3315	.4001
3	.8865	.6299	.381	.4191	.381	.4191	.4572
4	.9242	.724	.4763	.4763	.4763	.5335	.5144
5	.9431	.7621	.6668	.5144	.5716	.743	.5525
6	1.358	.8383	.663	.724	.7049	.9145	.6668
7	1.5655	1.0288	.8192	.6097	.8954		.8573
8	1.5844	1.1622	.6104	.9145			.6859
9	.7621	.6371	.5935	.663	.6796	.5847	.4807
10	.4001	.3688	1.0608	.7956	.8453	.7545	.6962
11	.2096	.2012	1.1768	.9282	1.0277	.8676	
12	.1334	.1341	1.2597	1.094	1.094	.8865	.7625
13	.0953	.1006	1.1603	.9945	.9779	.9054	.7625
14	.1143	.1006	1.0442	.9282	.8785	.8865	.7127
15	.0953	.1341	.9945	.8619	.7625	.7922	.6962
16	.1715	.2012	.8951	.8453	.7459	.7377	.6796
17	.3688	.3978	.9221	.8383	.7545	.7545	.6133
18	.7377	.4973	.5868	.5533	.6371	.6371	.5636
19	.6874	.5801	.788	.7712	.788	.57	.663
20	.6371	.6962	.5716	.6371	.5365	.5868	.6962
21	.4954	.4807	.5335	.5335	.5335	.4807	.6668
22	.4001	.5716	.381	.4001	.5716	.4001	.3315
23	.6859	.3429	.5335	.3429	.5335	.3481	.2818
24	.8488	.6668	.3239	.4763	.2858	.381	.4001
Max	1.5844	1.1622	1.2597	1.094	1.094	.9145	.8573
Min	.0953	.1006	.3048	.3429	.2858	.3315	.2818
Avg	.6584	.5270	.7121	.6701	.6665	.6299	.5871

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134001 / 33KV JAFRABAD

Feeder No / Name : 206 / JAFRABAD

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5975	.6908	.8402	.7095	.7468	.6535	.5788
2	.6535	.6464	1.0269	.7468	.8288	.7842	.6535
3	.7282	.7842	1.0829	.7842	1.1203	1.0269	.7095
4	.8962	.9149	1.3443	.8962	1.4563	1.1576	1.4003
5	1.3443	1.4003	1.4937	1.1203	1.7737	1.4937	1.4003
6	1.6804	1.6991	1.8671	1.587	1.9791	1.9791	1.9418
7	2.0911	1.9044	1.9231	1.9978	2.1285	2.2779	2.2592
8	2.2965	2.0165	1.9387	1.8858	2.2405	2.0911	2.2032
9	2.1399		1.829	1.8656	2.0485	2.0911	2.0668
10	1.8656	1.5364	1.7558	1.7924	1.8473	1.8484	1.8107
11	1.5546	1.5546	1.6461	1.6644	1.7375	1.5497	1.5546
12	1.6827	1.3352	1.5364	1.4083	1.4632	1.419	1.4449
13	1.39	.8977	1.1888	1.2803	1.2986	1.2696	1.1888
14	1.0791	.8288	1.0425	1.0974	1.0608	1.0642	.9511
15	.695	.9574	1.134	.9694	1.0608	.9709	.9694
16	1.2803	1.2437	1.2254	1.2437	1.262	1.2803	1.1888
17	1.587	1.6278	1.4632	1.4632	1.5912	1.5364	2.0668
18	1.4289	1.829	1.7193	1.7558	1.8107	1.8107	1.8839
19	1.7375	1.6461	1.7741	1.6095	1.701	1.4815	1.829
20		1.4266	1.0288	1.2986	1.3352	1.4998	1.4815
21	.8716	1.0974	1.0829	1.1203	1.1949	1.1763	1.2254
22	.9335	.8589	.8775	.8775	.8589	.8962	.8402
23	.7095	.6908	.7095	.6908	.6722	.7282	.6722
24	.6348		.6535	.6722	.5601	.5788	.5975
Max	2.2965	2.0165	1.9387	1.9978	2.2405	2.2779	2.2592
Min	.5975	.6464	.6535	.6722	.5601	.5788	.5788
Avg	1.2990	1.2540	1.3410	1.2724	1.4074	1.3610	1.3716

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134021 / 33KV TEMBHURNI

Feeder No / Name : 201 / TEMBHURNI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.4696	.543	.2818	.5716	.502	.5792
2	.6859	.5506	.6335	.3149	.5716	.4858	.5792
3	.7621	.6478	.724	.3441	.6859	.5992	.6335
4	1.0479	.8097		.6062	.7621	.6802	.6878
5	1.2003	1.0202	1.0498	.7125	.8192	.7125	.7602
6	1.3717	1.1336	1.267	.7449	.9526	.7935	.8326
7	1.5242	1.085	1.448	.9069	1.0098	.9069	.9774
8	1.6194	1.1336	1.3213	.8421	.7621	.9231	1.0498
9	.9717	1.1822	1.086	1.0802	.6668	.7611	1.2851
10	1.085	.8745	.9231	1.1241	.6097	.5992	1.1431
11	.7287	.8688	.6783	.8573	.502	.543	.8002
12	.6964	.5973	.6344	.7621	.4049	.4706	.7621
13		.5792	.4287	.8383	.3401	.3982	.6859
14		.5792	.4287	.6668	.3401		.5716
15		.5792	.4458	.6859	.2915		.5335
16		.5792	.463	.7621	.4049	.7602	.5716
17	.664	.7964	.6443	.8002	.4696	.8688	.8383
18	.7773	.8688	.8718	.8573	.6964	1.1765	1.3336
19	.6964	.9412	.8383	1.0479	.7287	1.2851	1.105
20	.5344	.7421	.6874	.9145	.583	1.1765	.9145
21	.4858	.6335	.5087	.9145	.4858	.724	.7621
22	.4534	.543	.407	.8573	.4372	.6878	.6859
23	.3401	.4525	.3391	.6859	.4049	.6335	.5716
24	.4954	.2429	.362	.3018	.5716	.3725	.543
Max	1.6194	1.1822	1.448	1.1241	1.0098	1.2851	1.3336
Min	.3401	.2429	.3391	.2818	.2915	.3725	.5335
Avg	.8356	.7463	.7275	.7462	.5863	.7300	.8003

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134021 / 33KV TEMBHURNI

Feeder No / Name : 202 / AKOLADEO

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3336	1.1984	1.2308	.3294	.4191	.3725	.4344
2	1.4289	1.2308	1.267	.3429	.4572	.3887	.4525
3	1.5623	1.3279	1.3394	.4115	.4572	.4534	.5068
4	1.7718	1.4575	1.4118	.6173	.5335	.5668	.6154
5	1.9052	1.5384	1.5023	.7888	.5716	.6478	.724
6	1.9052	1.6766	1.5384	.8402	.7621	.7449	.8688
7	2.0957	1.6842	1.5927	.9774	.724	.8907	1.0317
8	2.1719	1.7004	2.3891	.8402	.6668	.8583	.905
9	.4858	.6154	.4382	1.1768	1.9052	1.2146	2.0814
10	.3725	.421	.5658	1.9052	1.9243	1.3603	2.0957
11		.4163	.3429	2.0957	1.8947	1.7194	2.1148
12		.2715	.3258	1.9052	1.7976	1.828	2.1148
13		.2172	.3086	1.9052	1.7652	1.7556	1.9052
14	.2429	.1991	.2401	2.1148	1.8461	1.7556	
15	.2267	.2715	.2572	2.1719	1.587	1.5927	2.191
16	.3563	.3258	.3086	1.9052	1.4737	1.5565	2.0957
17	.4858	.4706		.4763	.421		.5716
18	.7773	.6335	.703	.5716		.7602	.9526
19	.7125	.7964	.7545	.5335	.7935	.8869	.8383
20	.4372	.543	.6135	.5525	.5344	.6335	.5716
21	.3887	.4163	.4557	.5335	.4858	.5068	.5335
22	.3401	.3982	.3856	.4763	.4534	.4525	.4382
23	.2753	.362	.3155	.4763	.3563	.4525	.4191
24	.4382	.2683	.2715	.298	.4572	.3401	.4163
Max	2.1719	1.7004	2.3891	2.1719	1.9243	1.828	2.191
Min	.2267	.1991	.2401	.298	.3563	.3401	.4163
Avg	.9388	.7683	.8069	1.0102	.9690	.9451	1.0817

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134021 / 33KV TEMBHURNI

Feeder No / Name : 203 / PAPAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003	1.0202	1.1765	.3944	.4763	.4049	.5068
2	1.3336	1.1336	1.2851	.4115	.4572	.3725	.4525
3	1.3336	1.1336	1.3032	.4801	.4763	.3887	.5068
4	1.4289	1.1984	1.3394	.583	1.5623	.4534	.543
5	1.6766	1.3765	1.7013	.6859	.5716	.4858	.6335
6	1.9052	1.6518	1.8461	.7373	.6859	.5506	.724
7	2.0957	1.7652	1.9909	.8745	.6668	.5668	.7964
8	2.0957	1.8623	2.0814	.583	.7049	.6154	.724
9	.6478	.5668	.5784	1.1603	1.7147	.4858	1.5384
10	.583	.4858	.6068	1.6575	1.6766	1.5384	1.6766
11	.5506	.6335	.2915	1.829	1.4575	1.7556	1.7147
12	.4049	.5068		1.9052	1.5061	1.8099	1.9052
13	.3563	.4344		2.0957	3.2226	1.9909	2.0576
14	.3239	.3982		2.0957	1.6356	1.7194	1.9052
15		.4344		1.9052	1.7814	1.5927	1.6766
16	.3563	.4706		1.6766	1.7814	1.6108	1.7147
17	.3887	.5068		.7621	.6478	.6878	.6097
18	.4372	.4706	.6687	.7621	.7287	.7602	.8002
19	.4858	.4525	.7716	.7049	.7611	.724	.7621
20	.4534	.4344	.6135	.6668	.6478	.6878	.6859
21	.3887	.3982	.4557	.5716	.6154	.6335	.6097
22	.3239	.3982	.3856	.5335	.5668	.543	.5716
23	.3077	.362	.3681	.4954	.4858	.4344	.5335
24	.381	.2429	.3258	.3506	.4763	.3239	.4344
Max	2.0957	1.8623	2.0814	2.0957	3.2226	1.9909	2.0576
Min	.3077	.2429	.2915	.3506	.4572	.3239	.4344
Avg	.8460	.7641	.9883	.9967	1.0545	.8807	1.0035

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134021 / 33KV TEMBHURNI

Feeder No / Name : 204 / BHATODI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.4858	.6335	.4458	.4954	.421	.4525
2	.6097	.4858	.6878	.463	.5335	.4534	.5068
3	.7621	.5182	.7602	.6001	.5716	.4858	.5792
4	.7545	.5506	.7964	.7202	.6859	.6154	.6878
5	.8383	.6478	.905	.7716	.7621	.6478	.8145
6	.9526	.8097	.9955	.8059	.9526	.7449	.9955
7	1.0479	.9069	1.086	.8745	.9145	.9555	1.2127
8	.9717	.9393	.8688	.8402	.9526	.9393	1.1222
9	1.1717	1.5223	1.5746	.823	.8192	.7935	1.0317
10	.4858	1.8785	1.8351	.6287	.724	.6802	.6287
11	1.749	2.2624	2.0405		.5668	.6335	.4954
12	1.7652	2.4977	1.9919			.3801	.381
13	2.1052	2.4434	1.8785			.3258	.4191
14	.5506	2.2262	1.873			.3258	.3429
15	2.0405	2.1719	1.8515		.3563	.362	.3239
16	2.2024	2.1176	1.7404		.3401	.5068	.3429
17	.421	.6697	.4801	1.8099	1.3765	2.1719	2.191
18	.8421	.8507	.6687	1.6766	1.7814	2.1719	2.1719
19	.9231	.905	.6687	1.7147		1.8099	1.9052
20	1.2308	.7602	.5258	1.6575	1.5223	1.7194	1.6766
21	1.1336	.6335	.4908	1.6766	1.4575	1.5746	1.4289
22	1.085	.6154	.4382	1.5242	1.3279	1.5384	1.3336
23	.905	.5792	.4207	1.4289	1.1336	1.448	1.2193
24	1.6385	.7712	.543	.4161	1.2765	1.0467	1.2489
Max	2.2024	2.4977	2.0405	1.8099	1.7814	2.1719	2.191
Min	.421	.4858	.4207	.4161	.3401	.3258	.3239
Avg	1.1149	1.1770	1.0731	1.0488	.9275	.9480	.9797

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134021 / 33KV TEMBHURNI

Feeder No / Name : 205 / AMBEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.1619	.2172	.1372	.2286	.1781	.2715
2	.2477	.1619	.2353	.12	.2286	.1619	.2715
3	.2858	.1457	.2715	.2058	.2858	.1943	.3077
4	.3429	.2105	.3258	.2743	.3048	.2429	.362
5	.381	.2429	.362	.4801	.381	.3239	.3982
6	.381	.2753	.362	.6173	.4191	.3563	.4525
7	.4191	.3563	.3982	.4458	.4763	.4049	.5068
8	.4763	.4049	.4525	.3429	.4572	.3887	.4525
9	.6478	.6964	.7545	.3086	.4382	.4049	.4525
10	.6154	.7611	.8288	.3429	.381	.3239	.4191
11	.6478	.905	.8029	.3048	.3077	.3258	.381
12	.8583	.9955	.7701	.2858	.2753	.3258	.2858
13	.9069	.9955	.7209	.2667	.2429	.2715	.3048
14	.9878	.9412		.2286	.2105	.3258	.2858
15	1.0688	.905		.2286	.1943	.362	.2667
16	1.1174	.905	.8029	.2477	.2267	.3982	.2858
17	.2429	.2715	.2058	.9145	.7935	.905	1.0479
18	.2915	.3258	.3772	1.1431	.8421	1.086	1.0479
19	.3401	.3982	.4458	1.0479	.9717	1.1765	1.105
20	.3239	.362	.2629	1.0479	.8592	1.086	1.1431
21	.2915	.3258	.298	1.0288	.8745	.9955	1.1431
22	.2591	.2896	.2454	.9526	.8421	.9593	.9907
23	.2267	.2534	.1753	.9526	.6964	.905	.8383
24	.2286	.1943	.2172	.1402	.8192	.6964	.8145
Max	1.1174	.9955	.8288	1.1431	.9717	1.1765	1.1431
Min	.2267	.1457	.1753	.12	.1943	.1619	.2667
Avg	.4924	.4785	.4333	.5027	.4899	.5333	.5764



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134021 / 33KV TEMBHURNI

Feeder No / Name : 206 / DAWARGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.7125	.8688	.7377	1.2384	1.0364	1.1765
2	.9526	.8421	.9231	.7712	1.3336	1.166	1.267
3	.9907	.8097	.9593	.8551	1.3336	1.1336	1.3575
4	1.1431	1.0202	1.1222	.9556	1.4289	1.2146	1.4842
5	1.2003	1.1336	1.1946	1.0277	1.6766	1.4251	1.6108
6	1.3336	1.2308	1.2851	1.0814	1.5813	1.3765	1.8099
7	1.4289	1.1498	1.3213	1.3441	2.0957	2.1052	2.0814
8	1.3336	.9717	1.086	1.587	2.0957	2.2186	2.1719
9	.9717	1.0526	1.0166	1.0526	1.0479	1.1336	1.1765
10	.6478	.7611	.6935	.9145	.9145	.8097	
11	.4372	.8145	.6068	.6668	.4534	.8688	.6097
12	.3725	.6335	.463	.5716	.3563	.8145	.5716
13		.6335	.3086	.4763	.2915	.724	.5335
14			.3086	.4191	.3563		.4191
15			.3258	.4954	.3239		.381
16		.8145	.3944	.6287	.4049	.543	.6097
17	2.1214	2.1176	2.0454	.7621	.664	.7964	.8383
18	2.1862	2.2624	2.079	1.105	1.1336	.9955	1.3336
19	1.7328	2.4434	1.6263	1.3336	1.166	1.086	1.2574
20	1.3765	1.9909	1.3413	1.2003	1.1336	1.1584	1.1431
21	1.2955	1.6289	1.1233	1.0479	1.0688	.9955	1.0669
22	1.2146	1.5023	.9724	.7621	.8097	.7602	.7621
23	1.1336	1.3575	.8215	.6859	.7287	.6878	.6859
24	1.4289	1.0688	1.267	.788	1.5623	.6478	.4706
Max	2.1862	2.4434	2.079	1.587	2.0957	2.2186	2.1719
Min	.3725	.6335	.3086	.4191	.2915	.543	.381
Avg	1.2079	1.2251	1.0064	.8862	1.0500	1.0771	1.0791

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134022 / WARUD 33/11 KV S.S

Feeder No / Name : 201 / WARUD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0179	.0179	.0189	.0179	.0189	.0189	.0179
2	.0179	.0179	.0189	.0179	.0189	.0189	.0179
3	.0179	.0179	.0189	.0179	.0189	.0189	.0175
4	.0179	.0179	.0189	.0179	.0189	.0189	.0175
5	.0179	.0179	.0189	.0179	.0189	.0189	.0179
6	.0179	.0179	.0189	.0179	.0189	.0189	.0358
7	.0358	.0179	.0189	.0716	.0187	.0189	.0351
8	.0716	.0179	.0377	.0537	.0554	.0189	.0179
9	.0537	.0358	.0358	.0716	.0732	.0189	.0179
10	.0716	.12	.0701	.1267	.037	.0179	.132
11	.0716	.12	.1227	.1267	.0189	.0537	.1132
12	.1075	.1174	.1227	.0549	.0189	.0537	.1132
13	.0895	.1132	.1075	.0549	.0189	.0716	.0189
14	.0716	.0754	.0716	.0732	.0189	.0716	.0943
15	.0716	.0754	.0537	.1267	.0189	.0716	.0754
16	.0716	.0754	.1052	.0732	.0189	.0716	.132
17	.0537	.0754	.0701	.0732	.0189	.0716	.0754
18	.0358	.0377	.0716	.1097	.0189	.0716	.0754
19	.0179	.0377	.0175	.0189	.0189	.0358	.0189
20	.0179	.0189	.0183	.0189	.0189	.0179	.0189
21	.0187	.0189	.0183	.0187	.0189	.0179	.0189
22	.0187	.0189	.0179	.0189	.0189	.0179	.0183
23	.0183	.0189	.0179	.0189	.0189	.0179	.0189
24	.0183	.0179	.0189	.0179	.0189	.0189	.0179
Max	.1075	.12	.1227	.1267	.0732	.0716	.132
Min	.0179	.0179	.0175	.0179	.0187	.0179	.0175
Avg	.0426	.0467	.0462	.0515	.0234	.0355	.0474

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134022 / WARUD 33/11 KV S.S

Feeder No / Name : 202 / ADHA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1641	1.1568	1.1736	1.2894	1.4255	1.278	1.4373
2	1.2536	1.2269	1.1736	1.3253	1.4419	1.3108	1.4723
3	1.3253	1.262	1.3413	1.3969	1.4575	1.3599	1.5424
4	1.3611	1.2971	1.3413	1.4327	1.5384	1.4746	1.5775
5	1.4327	1.286	1.4083	1.6834	1.5813	1.5223	1.6126
6			1.4754	2.2436	1.5181	1.866	1.8404
7			1.7328	2.5034	2.0622	1.9997	2.0157
8			1.8244		2.2653	2.0309	2.3487
10	2.0774	1.8519					
11	2.1849	2.4006					
12	2.4177	2.431					.4715
13	2.3282	2.1795					
14	2.2386	2.1491					
15	1.97	1.9357	.3506	.5415			.5487
16	1.8804	1.7814	.4382				.5935
17	1.7177	1.7204	.5784	.9979		.964	.8215
18	1.1283	1.0288	1.0517	1.2437	1.4998	1.3073	1.0978
19	1.3432	1.2003	1.3073	1.3535	1.3717	1.3432	1.278
20	1.4327	1.3717	1.3432	1.4449	1.3535	1.3969	1.1469
21	1.4327	1.3717	1.2894	1.3169	1.3169	1.4327	.9831
22	1.4327	1.2308	1.3253	1.1157	1.2986	1.3432	1.0486
23	1.3969	1.1797	1.2536	1.4089	1.3927	1.4327	1.2498
24	1.182	1.3146	1.1633	1.2894	1.4091	1.2616	1.4685
Max	2.4177	2.431	1.8244	2.5034	2.2653	2.0309	2.3487
Min	1.1283	1.0288	.3506	.5415	1.2986	.964	.4715
Avg	1.6350	1.5688	1.1984	1.4117	1.5288	1.4577	1.2924

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134022 / WARUD 33/11 KV S.S

Feeder No / Name : 203 / WANKHEDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6447	.6268	.8383	.8954	.9335	.9431	.8954
2	.6805	.6805	.9221	.985	1.0269	1.0456	.985
3	.7164	.7164	1.0059	1.0745	1.2567	1.2696	1.1641
4	.7888	.8059	1.2742	1.2894	1.2936	1.4563	1.2536
5	.964	.8764	1.3413	1.4327	1.386	1.4784	1.4327
6	1.0517	1.1568					
7	1.5775	1.5424					
8	2.0332	2.0157					
9			1.3146				
10			1.5775	.9945	1.0631	1.0745	.8383
11			1.5775	.8745	1.0898	1.182	1.0059
12			1.6301	1.1736		1.2536	1.0059
13			1.6118	1.2266		1.2894	1.0059
14			1.5775	1.2929	1.3435	1.0517	.8383
15	.4252	.5144	1.4899	1.1736	1.3108	1.0517	.8383
16	.6268	.6859	1.2269	1.1603	1.3108	1.0517	1.0059
17	.7522	.8573	1.0745	.9054	1.0395	.7011	.8383
18	1.4327	.8573	1.2536	1.4784	1.4784	1.3146	1.1469
19	1.4327	.8573	1.4327	1.2567	1.386	1.4327	1.1469
20	1.3432	.8573	1.2536	1.0719	1.2323	1.2894	1.065
21	1.2178	.6859	1.1641	.8775	1.1203	1.1641	.9831
22	1.0745	.6554	1.1462	.8402	.9335	1.0745	.8192
23	1.3969	.6554	1.0745	.8402	.8865	.985	.7373
24	.6447	.6268	.4915	.985	.8962	.9054	.8954
Max	2.0332	2.0157	1.6301	1.4784	1.4784	1.4784	1.4327
Min	.4252	.5144	.4915	.8402	.8865	.7011	.7373
Avg	1.0446	.8708	1.2513	1.0914	1.1660	1.1507	.9951

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134032 / MAHORA 33/11 KV SUBSTATION

Feeder No / Name : 201 / 11 KV PIMPALGAON KAD SINGLE PHASING

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.6516	.9907	.7619	1.1145	.6859	.8573
2	1.0288	.5335	1.2003	.7802	1.1831	.8573	.8573
3	1.0288	.6001	1.2346	.815	1.2003	1.2003	.8573
4	1.0288	.6344	1.286	.8413	1.3375	1.7147	.8573
5	1.2003	.6344	1.3375	.6485	1.4575	1.7147	.8573
6	1.0288	.6516	1.406		1.6975	1.7147	1.0288
7	.8573	.6687	1.5947		1.7147	1.8861	1.2003
8	.8573	.6097	1.0802		1.8519	1.9719	1.2003
9	1.0288	1.1145	.6516	.8059	.6516	.8573	.6859
10	1.1831	1.1831	.3721	.7888	.5144	.3429	.5487
11	1.406	1.3375	.3506	.8535	.5144	.3429	.583
12	1.0174	1.3889	.2629	.7888		.2572	.583
13	1.5775	1.4575	.2454	.7888	.3429	.2572	.6173
14	1.5775	1.4918	.2103	.8059	.3429	.2572	.6173
15	1.6118	1.5261	.2454	.8059	.3429	.2572	.6344
16	1.4327	1.5432	.3506	.7888	.3429	.3429	.6344
17	1.6289	1.5432	.4733	.7202	.6859	.5144	.5639
18	.7621		.8413		.6859	.6859	.6344
19	.7621	.4973	1.1393		.8573	.6859	
20	.7716	.5144	1.0867		.8573	.8573	
21		.5487			.8573	.8573	
22		.6001			.6859	.8745	
23		.6001			.6859	1.0288	
24	.6859	.6097	.6516	.6485		.6859	1.2003
Max	1.6289	1.5432	1.5947	.8535	1.8519	1.9719	1.2003
Min	.6859	.4973	.2103	.6485	.3429	.2572	.5487
Avg	1.1111	.9104	.8101	.7761	.9057	.8688	.7904

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134032 / MAHORA 33/11 KV SUBSTATION

Feeder No / Name : 202 / 11 KV MAHORA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.9431	1.0288	.7011	.6516	.6859	.6859
2	.6859	1.0288	1.286	.7087	.5792	.6859	.6859
3	.6859	1.286	1.286	.7455	.4458	.6859	.6859
4	.6859	1.286	1.406	.7973	.6687	.6859	.6859
5	.7716	1.3203	1.406	1.0867	.3715	.8573	.6859
6	.8573	1.3375	1.406		.6859	1.0288	.8573
7	1.0288	1.3375	1.3889		.703	1.2003	.8573
8	1.2003	1.3375	1.3889		.4687	1.2003	.8573
9	1.2003	.6001	1.1145	.8745	.7202	1.2003	.9431
10	.6516	.5335	1.387	.9945	.8573	1.2003	.7621
11	.6516	.6344	1.5249	.9945	1.0288	1.2003	.9431
12	.6001	.6687	1.4899	1.0288	1.0288	1.2003	1.0117
13	.6001	.6859	1.4706	1.0288	1.1145	1.2003	1.0631
14	.583	.6859	1.3847	.9945	1.2003	1.0288	1.0631
15	.583	.703	1.3146	.9945	1.2003	1.0288	1.1145
16	.583	.703	1.0923	1.0288	1.0288	.8573	1.166
17	.583	.703	.9465	1.046	.8573	.8573	1.1831
18	.7202	.4001	.9816		.6859	1.0288	.7716
19	.8573	.6516	1.0387		.6859	1.0288	
20	.8573	.6001	.929		.8573	1.2003	
21		.9431			1.0288	.6859	
22		.7202			1.2003	.4287	
23					.8573	.5144	
24	.8573	.6516	.6859	.6733		.6859	.5144
Max	1.2003	1.3375	1.5249	1.0867	1.2003	1.2003	1.1831
Min	.583	.4001	.6859	.6733	.3715	.4287	.5144
Avg	.7585	.8592	1.2360	.9132	.8229	.9324	.8704

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134032 / MAHORA 33/11 KV SUBSTATION

Feeder No / Name : 203 / 11 KV WADALA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.6516	1.1145	.567	.5792	.5144	
2	.5144	.6516	1.2346	.567	.7716	1.2003	
3	.5144	.6859	1.2193	.6024	1.0288	1.2003	
4	.5144	.6859	1.4575	.6135	1.166	1.2003	
5	.6001	.6249	1.5775	.8238	1.3375	1.3717	
6	.5144	.7202	1.6289		1.2955	1.3717	
7	.5144	.7202	1.6804		1.6289	1.7147	
8	.5144	.7202	1.7147		1.8861	1.8004	
9	.6001	.9145	.6859	.4287	.5487	.6859	
10		1.1145	.3856	.7202	.5144	.5144	.3429
11		1.1831	.3506	.463	.4287	.3429	.4801
12		1.3375	.3155	.4973	.3429	.3429	.5144
13		1.3375	.2804	.5144	.3429	.3429	.5144
14		1.3717	.2804	.5487	.3429	.3429	.5487
15		1.3717	.3189	.583	.3429	.3429	.583
16		1.3889	.3506	.6001	.3429	.3429	.6001
17		1.3889	.3506	.6516	.3429	.3429	.6001
18			.6135		.3429	.5144	.6344
19		.4973	.7362		.5144	.5144	
20		.5144	.6836		.5144	.5144	
21					.6859	.5144	
22		.5144			.5144	.4287	
23		.5316			.5144	.5144	
24	.6859	.6001	.5487	.5316		.5144	.5144
Max	.6859	1.3889	1.7147	.8238	1.8861	1.8004	.6344
Min	.5144	.4973	.2804	.4287	.3429	.3429	.3429
Avg	.5487	.8876	.8347	.5808	.7100	.7287	.5333

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134032 / MAHORA 33/11 KV SUBSTATION

Feeder No / Name : 204 / 11KV MHASARUL FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	1.0117	1.1145	.4784	.4801	.5144	
2	.6859	1.0631	.6344	.4908	.4268	.5144	
3	.6859	.9145	.6516	.4961	.5487	.5144	
4	.6859	1.0631	.6859	.4908	.5487	.5144	
5	.7716	.1029	.6859	.5434	.583	.5144	
6	.8573	1.0631	.7202		.6173	.5144	
7	.8573	1.0631	.7202		.4115	.6859	
8	.8573	1.046	.7202		.423	.6859	
9	.5144	.3429	.6859	.6344	.6516	.5144	
10	.3086	.3429	1.1145	.6859	.6859	.6859	.6001
11	.2058	.3258	1.1744		.8573	.8573	.6173
12	.2743	.3258	1.1517		.8573	.8573	.6687
13		.3086	1.1043		.9431	.8573	.7202
14			1.1043	.6859	.9431	.8573	.8059
15		.3258	1.0517	.8383	1.286	.7716	.7716
16		.3086	.9816	.9602	.6859	.6859	.7888
17		.3086		.9945	.6001	.6001	.7716
18					.5144	.6859	.503
19		.3772	.6661		.5144	.8573	
20		.4115	.631		.5144	.6859	
21		.4115			.5144	.6859	
22		.4287			.4287	.5144	
23		.463			.4287	.6859	
24	.6859	.6001	.5144	.4908		.5144	.6859
Max	.8573	1.0631	1.1744	.9945	1.286	.8573	.8059
Min	.2058	.1029	.5144	.4784	.4115	.5144	.503
Avg	.6212	.5731	.8480	.6491	.6289	.6573	.6933



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134032 / MAHORA 33/11 KV SUBSTATION

Feeder No / Name : 205 / 11KV BELORA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	1.3889	.6516	.5959	.6344	.6859	
2	1.0288	1.406	.6516	.6024	.6344	.6859	
3	1.0288	1.4575	.6859	.6135	.6687	.6859	
4	1.0288	1.5432	.703	.631	.6859	.6859	
5	1.1488	1.5775	.7202	.7537	.7316	.6859	
6	1.3717	1.5775	.6859		.4687	.8573	
7	1.3717	1.5947	.7716		.703	.8573	
8	1.5432	1.5947	.7888		.7202	.9431	
9	.6001	.4287	.6097	.7202	.7202	.6859	
10		.4973	1.7878	1.1145	1.0288	.8573	.743
11		.5316	1.858	1.1488	1.5432	1.2003	1.2346
12		.5316	1.7878	1.2003	1.5432	1.2003	1.3889
13		.5487	1.7896	1.2346	1.6289	1.286	1.5089
14		.5487	1.6827	1.2517	1.5432	1.3717	1.5261
15		.5487	1.5061	1.1126	1.3717	1.3717	1.5775
16		.5658	1.4022	1.2517	1.2003	1.2003	1.5775
17		.5658	1.3146	1.2517	1.2003	1.0288	1.5947
18			.6379		.8573	.6859	1.5947
19		.5487	.7973		.6859	.6859	
20		.583	.7186		.8573	.6859	
21		.6001			.8573	.5144	
22		.6001			.6859	.5144	
23		.583			.6859	.5144	
24	1.0288	.6001	.6001	.6024		.6859	.5144
Max	1.5432	1.5947	1.858	1.2517	1.6289	1.3717	1.5947
Min	.6001	.4287	.6001	.5959	.4687	.5144	.5144
Avg	1.1180	.8879	1.0548	.939	.9416	.8573	1.3260

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134032 / MAHORA 33/11 KV SUBSTATION

Feeder No / Name : 206 / 11KV INDUSTRIAL FEEDER SHEDDABLE FEEDER HAVING WEEKLY  
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0171	.0171	.0177	.0171	.0171	
2	.0171	.0171	.0171	.0177	.0171	.0171	
3	.0171	.0171	.0171	.0175	.0171	.0171	
4	.0171	.0171	.0171	.0175	.0171	.0171	
5	.0171	.0171	.0171	.0177	.0152	.0171	
6	.0171	.0171	.0171		.0343	.0171	
7	.0171	.0171	.0171		.0152	.0171	
8	.0171	.0171	.0171		.0343	.0171	
9	.0171	.0171	.0171	.0171	.0343	.0171	
10		.0343	.0171	.0343	.0171	.0171	.0171
11		.0171	.0181	.0343	.0171	.0171	.0152
12		.0171	.0181	.0514	.0171	.0171	.0171
13		.0171	.0181	.0514	.0171	.0171	.0171
14		.0171	.0181	.0514	.0171	.0171	.0171
15		.0171	.0183	.0514	.0171	.0171	.0171
16		.0171	.0358	.0514	.0171	.0171	.0171
17		.0171	.0701	.0514	.0171	.0171	.0171
18			.0526		.0171	.0171	.0171
19		.0171	.0526		.0171	.0171	
20		.0171	.0347		.0171	.0171	
21		.0171			.0171	.0171	
22		.0171			.0171	.0171	
23		.0171			.0171	.0171	
24	.0171	.0171	.0171	.0177		.0171	.0171
Max	.0171	.0343	.0701	.0514	.0343	.0171	.0171
Min	.0171	.0171	.0171	.0171	.0152	.0171	.0152
Avg	.0171	.0178	.0250	.0333	.0192	.0171	.0169

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134042 / HIVRAKABLI

Feeder No / Name : 207 / BRAHMAPURI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.3575	1.1765	1.2094	1.2437
2				1.3575	1.262	1.2094	1.2437
3				1.3575	1.1999	1.1919	1.262
4				1.3756	1.1041	1.1919	1.262
5				1.3756	1.1584	1.2269	1.2803
6				1.4118	1.2094	1.2269	1.2803
7				1.4299	1.3146	1.2269	1.2986
8				1.4661	1.3523	1.3146	1.3352
10	1.5546	1.7741	1.9909				
11	1.7924	1.8642	2.009				
12	1.8473	1.9185	1.9909				
13	1.8473	1.9547	2.009			.1524	
14	1.9022	1.9366	2.0351				
15	1.9204	1.9547	1.8461				
16	1.8656	1.9004	1.7918			.1524	
17	1.8473	1.8099	1.7375				
23			1.3756	1.2757	1.2094	1.2437	1.2012
24				1.3032		1.2094	1.2437
Max	1.9204	1.9547	2.0351	1.4661	1.3523	1.3146	1.3352
Min	1.5546	1.7741	1.3756	1.2757	1.1041	.1524	1.2012
Avg	1.8221	1.8891	1.8651	1.3710	1.2207	1.0463	1.2651

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134042 / HIVRAKABLI

Feeder No / Name : 208 / KALEGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.8764	.7811	.7621	.6478
2				.8764	.8764	.7621	.6668
3				.8764	.6668	.8002	.6668
4				.8764	.7621	.8383	.6859
5				.8954	.8002	.8573	.724
6				.8954	.724	.8764	.7621
7				.9145	.7811		.7621
8				.9145	.9145	.9526	.743
9						.1524	
10	1.0669		1.1431				
11	1.1622	1.0288	1.1812			.1524	
12	1.105	1.1431	1.2765				
13	1.1812	1.1812	1.3146				
14	1.2384	1.2765	1.2765				
15	1.2574	1.2574	1.2384				
16	1.2384	1.2003	1.1622				
17	1.1431	1.086	1.105				
23			.8573	.743	.7621	.6478	.5906
24				.743		.7621	.6478
Max	1.2574	1.2765	1.3146	.9145	.9145	.9526	.7621
Min	1.0669	1.0288	.8573	.743	.6668	.1524	.5906
Avg	1.1741	1.1676	1.1728	.8611	.7854	.6876	.6897

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134047 / 33 KV DONGAON

Feeder No / Name : 201 / POKHRI - AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1219	.1852	.1543	.6097	.6097	.6173	1.2193
2	.1219	.1852	.1543	.6097	.6097	1.2346	1.2193
3	.1219	.1852	.1543	.8383	1.5242	1.3889	.3048
4	.1372	.1852	.1852	.7621	1.2193	1.3889	1.829
5	.1372	.1852	.2315	1.0669	1.3717	1.4198	1.829
6	.1524	.2315	.1852	1.2955	1.5242	1.6204	2.4387
7	.1524	.2315	.1852	1.5242	2.2862	2.1795	2.2862
8	.0762	.2315	.1543	1.9814	2.5911	2.271	2.5911
9	.0762			.0762	.0762	.2591	.1389
10	2.3148	1.142	1.829	.0762	.0772	.1829	.1543
11	2.8549	2.0062	2.7435	.0762	.108	.1219	.1543
12	2.6852	2.3148	2.7435	.0762	.0926		.1543
13	2.8086	2.3148	2.8959	.0762	.1389	.0762	.216
14	2.4074	2.3148	2.9721		.1235	.0762	.216
15	2.5772	2.0833	2.8959		.0926	.0762	.216
16	1.7284	2.0833	2.8959	.0762	.0772	.0762	.2315
17	2.0833	1.8519	2.5911	.0762		.0762	.2315
18	.2006			.0762		.0762	.2778
19		.1852		.0762	.1852	.1524	.2315
20	.2932	.2315	.1372	.0762	.1852	.1372	.2315
21	.2469	.1852		.1219	.216	.1372	.2315
22	.2778	.1543		.1219	.1543	.1372	.2315
23	.2315	.1543		.1219	.1543	.1372	.2315
24	.1219	.2469	.1543	.1372	.1219	.1389	.0914
Max	2.8549	2.3148	2.9721	1.9814	2.5911	2.271	2.5911
Min	.0762	.1543	.1372	.0762	.0762	.0762	.0914
Avg	.9534	.8586	1.2924	.4524	.6154	.6079	.7065

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134047 / 33 KV DONGAON

Feeder No / Name : 203 / NIVDUNGA - AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0936	1.0936	1.0155	.125	.1219	.0781	.0762
2	1.0936	.9374	1.0936	.125	.1219	.0781	.0762
3	1.2498	1.3279	1.2498	.125	.1219	.0781	.0762
4	1.406	1.3592	1.3279	.1406	.1219	.0781	.0914
5	1.5623	1.3592	1.406	.1406	.1219	.0781	.0914
6	1.5623	1.4373	1.8747	.1406	.1372	.0937	.1067
7	1.7966	2.2497	2.1872	.1562	.1219	.0914	.1219
8	1.829	2.1872	1.9528	.1562	.0914	.0914	.0914
9	.125			.1524	.0762	.0914	.0914
10				1.5623	2.0309		1.4842
11				2.1872	2.6246		2.0309
12				2.1872	2.8121		2.0309
13	.125			2.2653	2.5777		2.1948
14				2.1872	2.7965		2.1872
15				2.4996	2.1091		2.3434
16				2.4996	2.3746	1.5242	2.0309
17	.125			1.7185	2.8121	1.9814	1.8747
18	.1562	.2343	.1219	.0937	.0781	.1067	.125
19	.1718	.1875		.0937	.0937	.1067	.125
20	.1718	.1875	.1562	.0937	.0937	.1067	.125
21	.1562	.1875	.1562	.1067	.0937	.0762	.125
22	.1562	.1562		.0914	.0781	.0762	.125
23	.1562	.1562	.1562	.0914	.0781	.0762	.125
24	.1406	.1406	.1562	.1619	.1372	.0781	.0762
Max	1.829	2.2497	2.1872	2.4996	2.8121	1.9814	2.3434
Min	.125	.1406	.1219	.0914	.0762	.0762	.0762
Avg	.7265	.8801	.9888	.7959	.9094	.2717	.7428

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134067 / BORGAON (M) 33 KV S/S

Feeder No / Name : 201 / BORAGAON MATH SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1142	1.1831	.7164	.5792	.5658	.6878	.6859
2	1.1797	1.4232	.8059	.6878	.6516	.7522	.7716
3	1.4746	1.5089	.9313	.7701	.823	.8413	.9431
4	1.5581	1.5947	1.0745	.9134	.9088	.9412	1.1488
5	1.6575	1.7661	1.1641	.985	1.046	1.0566	1.1831
6	1.9845	1.8347	1.2178	1.0745	1.1317	1.2308	1.1831
7	2.1792	1.869				1.166	
8	1.9204	1.9719				1.2254	
9						.9877	
10			1.7204	1.491	1.7532	1.5939	1.6118
11			1.7284	1.6118	1.7404	1.6118	1.5432
12			1.7736	1.7318	1.6712	1.5947	1.5089
13			1.6385	1.7147	1.5074	1.7013	1.4575
14			1.4746	1.7147	1.442	1.5432	1.3717
15	.3086	.3224	1.6221	1.3375	1.2929	1.3889	1.1831
16	.3601	.4298	1.4586		1.2239	1.286	1.1145
17	.5316	.6805	1.2929		1.1603	1.1999	1.1641
18	.823	1.182	1.1706	.7373	1.262	1.0745	.8745
19	1.0802	1.1104	1.166	1.0288	1.1831	1.0974	1.3432
20	.8745	.9313	.9602	.9088	.9945	.8916	.9774
21	.7202	.8059	.7373	.7202	.7202	.7202	.8059
22	.4973	.591	.6001	.5487	.6584	.5487	.6001
23	.8059	.5014	.5853	.5144	.6401	.583	
24	1.0898	1.0117	.5731	.543	.5144	.6173	.6516
Max	2.1792	1.9719	1.7736	1.7318	1.7532	1.7013	1.6118
Min	.3086	.3224	.5731	.5144	.5144	.5487	.6001
Avg	1.1200	1.151	1.1625	1.0322	1.0900	1.0976	1.1062

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134067 / BORGAON (M) 33 KV S/S

Feeder No / Name : 202 / PASODI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3429	.5194	.5487	.7373	.7712	.7202
2	.3174	.3944	.5014	.6516	.9945	.8402	.7716
3	.3361	.4801	.5373	.763	1.1488	.8718	.823
4	.3734	.5144	.5731	.8551	1.2517	.9892	.8916
5	.3921	.5658	.6516	.9088	1.3375	.9297	.9431
6	.4115	.6001	.7202	.9724	1.3889	1.1065	.9945
7	.4458	.6001	.7716	1.3108	1.406	1.358	1.5089
8	.3944	.5144	.8573	1.3916	1.4575	1.3245	1.3375
9	.4115	.4973					
10	1.0227	1.0117					
11	1.0288	1.0924					
12	1.0117	1.0745					
13	.9945	1.2178					
14	.9774	.9671					
15	.8916	1.0387	.1829	.1543	.1543	.1029	.1715
16	.703	.985	.2054	.2401	.2427	.1612	.2572
17	.6173	.8238	.2915	.3601	.3429	.1886	.3429
18	.3601	.5194	.5487	.4115	.583	.5658	.5144
19	.4801	.4835	.5658	.463	.5487	.583	.6344
20	.4287	.4119	.4287	.4115	.4458	.4115	.4458
21	.3772	.394	.3601	.3429	.3601	.3429	.4115
22	.3086	.3045	.3086	.2915	.3429	.2743	.2915
23	.3086	.4298	.4191	.6173	.4287	.463	.4458
24	.3361	.3086	.4835	.5144	.6687	.6613	.6859
Max	1.0288	1.2178	.8573	1.3916	1.4575	1.358	1.5089
Min	.3086	.3045	.1829	.1543	.1543	.1029	.1715
Avg	.5621	.6488	.4959	.6227	.7689	.6636	.6773



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134067 / BORGAON (M) 33 KV S/S

Feeder No / Name : 203 / KHASAGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.4973	.394	.5487	.463	.4191	.4801
2	.6348	.6001	.4115	.6036	.463	.4694	.463
3	.7095	.6516	.4656	.6516	.4973	.5144	.4801
4	.7842	.6687	.4801	.6706	.5658	.5144	.4973
5	.8402	.7202	.4801	.7122	.6001	.5365	.5144
6	.8962	.7716	.4458	.7042	.6516	.5868	.3944
7	.8573	.7888	.4801	1.0117	.6687	.8139	1.1145
8	.6859	.7545	.5144	.8383	.703	.9259	.8402
9	.6173	.6516					
10	.6874	.4287					
11	.7202	.5014					
12	.7545	.5373					
13	.6687	.6089					
14	.5658	.6447					
15	.5487	.591	.3429	.2058	.2058	.2229	.0857
16	.5658	.5731	.3258	.2915	.2915	.2229	.1543
17	.5658	.4835	.2401	.3258	.2229	.2229	.2915
18	.5487	.5373	.6344	.4801	.6001	.2743	.5316
19	.6859	.7343	.5281	.6687	.7545	.7716	.8402
20	.6344	.6805	.3944	.583	.6344	.6516	.6173
21	.5658	.6268	.5658	.4973	.5487	.5144	.591
22	.463	.5014	.463	.4458	.4801	.4458	.463
23	.4458	.3045	.3772	.3944	.5144	.5144	.5487
24	.5228	.463	.3258	.4801	.4458	.4287	.463
Max	.8962	.7888	.6344	1.0117	.7545	.9259	1.1145
Min	.4458	.3045	.2401	.2058	.2058	.2229	.0857
Avg	.6470	.5967	.4372	.5619	.5173	.5028	.5206

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 201 / 11 KV RAM MANDIR FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.3258	.3077		.2896	.3077	.3361
2	.362		.3077		.2896	.3077	.3361
3	.362		.3077	.3258	.2896		.3361
4	.4525	.362	.362		.362		.3734
5	.724	.6335	.5792		.5068		.6161
6	.8869	.8688	.724	.724	.724	.8326	
7	1.0498	1.0498	.9412	.9593	1.0136	1.0498	
8	1.1222	1.1765	1.1403	1.0317	1.1222	1.1765	
9	1.4937	.9335	1.1041		1.1041	1.0829	
10		.7842	.9412	.8962	.9593		
11	.5601	.6535	.7421	.8402	.724	.8589	
12		.5975	.7059	.7095	.5792	.7842	
13		.5601	.5973	.5601	.5068	.6535	
14		.4668	.5068	.4668		.5228	
15	.4108		.4525	.4854	.4887	.5041	
16						.4481	
17	.0747					.5975	
18						.7842	
19	.8962					.8775	
20	.8215					.8029	
21	.6516					.6722	
22	.5249					.5601	
23	.362					.3361	
24	.362	.3258	.3077	.3258	.2896	.3077	.3361
Max	1.4937	1.1765	1.1403	1.0317	1.1222	1.1765	.6161
Min	.0747	.3258	.3077	.3258	.2896	.3077	.3361
Avg	.6377	.6721	.6267	.6659	.6166	.6734	.3890

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 202 / MEDICAL COMPLEX

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.362	.3982		.4163	.4163	.3921
2	.362	.362	.3982		.4163		.3921
3	.362	.362	.3982	.4163	.4163		.3921
4	.4344		.4887		.4887		.4108
5	.6516	.8145	.8145		.5792		.7468
6	1.0317	1.086	.905	.9774	1.0498	1.086	
7	1.3756	1.3213	1.1946	1.3213	1.3756	1.3756	
8	1.5384	1.448	1.2851	1.3756	1.3575	1.3575	
9	1.4003	1.307	1.2489	1.307	1.3756	1.307	
10		1.2136	1.0498		1.0136		
11	1.1203	.9709	1.086		.9774	1.2136	
12		.8402	.9955	1.0269	.8869	.8962	
13	1.3256	.7095	.7964	.7468	.6697		
14		.5975	.5792			.6722	
15	.5975		.6878	.5788	.5792	.6161	
16						.6161	
17	.9335						
19	1.2136						
20	1.0829						
21	.7783					.8962	
22	.6697					.6535	
23	.543					.4668	
24	.3982	.3982	.3982	.4525	.4525	.4163	.3921
Max	1.5384	1.448	1.2851	1.3756	1.3756	1.3756	.7468
Min	.362	.362	.3982	.4163	.4163	.4163	.3921
Avg	.8516	.8423	.7953	.9114	.8036	.8564	.4543

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 203 / SATELLITE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3077	.3258	.3258		.3258	.3258	.2987
2	.3077	.3258	.3258			.3258	.2987
3	.3077	.3258	.3258	.3439			.2743
4	.3982		.362		.362		.2915
5	.6697	.4887	.4887		.4525		.4481
6	.6516	.6516	.5973	.5611	.6154	.6154	
7	.8507	.905	.8326	.724	.8145	.8145	
8	.905	.8688	.905	.9231	.905	.905	
9		.7842	.905		.7964	.8402	
10		.7095	.7783		.724		
11	.5788	.6535	.6516	.072	.5792	.6908	
12		.5788	.5792		.5249	.5415	
13		.5415	.5792	.5249	.4525	.4525	
14		.4854	.4887	.543		.4115	
15	.4294		.4706	.5228	.3982	.3944	
16						.4108	
17	.5975						
19	.7095						
20	.6535						
21	.5792					.6161	
22	.5068					.4668	
23	.3801					.3547	
24	.3077	.3258		.3439	.3258	.3258	.2987
Max	.905	.905	.905	.9231	.905	.905	.4481
Min	.3077	.3258	.3258	.072	.3258	.3258	.2743
Avg	.5377	.5693	.5744	.5065	.5597	.5307	.3183

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 205 / MEDICAL EXPRESS  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0181	.0181			.0181	.0181	
2	.0181	.0181	.0181				.0187
3	.0181			.0181			.0187
4	.0181		.0181				.0171
5	.0181	.0181	.0181		.0181		.0187
6	.0181	.0181	.0181	.0181	.0181	.0181	
7		.0181	.0181			.0181	
8	.0181	.0181	.0181	.0181	.0181	.0181	
9	.0187	.0187	.0181	.0181	.0181	.0187	
10		.0187		.0181	.0181		
11	.0187	.0187	.0181	.0181	.0362	.0373	
12		.0187	.0181	.0181	.0181	.0373	
13	.0187	.0373	.0181	.0181	.0181	.0187	
14		.0373	.0181	.0181		.0171	
15	.0187		.0181	.0187	.0181	.0187	
16						.0171	
17	.0187						
19	.0187						
20	.0187						
21	.0181					.0187	
22	.0181					.0187	
23	.0181					.0187	
24	.0181	.0181	.0181	.0181	.0181	.0181	.0171
Max	.0187	.0373	.0181	.0187	.0362	.0373	.0187
Min	.0181	.0181	.0181	.0181	.0181	.0171	.0171
Avg	.0183	.0212	.0181	.0182	.0197	.0208	.0181

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 206 / COLLECTOR OFFICE (EXP)  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0181						
2							.0187
3			.0181	.0181	.0181	.0181	
4	.0181	.0362					.0187
5							.0187
6	.0181		.0181	.0181	.0181	.0181	
7	.0181						
8	.0181	.0362	.0181	.0181	.0181	.0181	
9	.0187	.0187	.0181	.0187	.0362	.0187	
10					.0362		
11	.056	.0187	.0181	.0187	.0724	.0747	
12	.0747				.0724	.0747	
13	.061	.0187	.0181	.0187	.0724	.0686	
14						.0747	
15	.0747		.0181	.0187	.0724	.0747	
16						.0686	
17	.056						
19	.0037						
20	.0373						
21	.0362						
22						.0187	
23	.0362					.0187	
24	.0181	.0362	.0181	.0366	.0181	.0181	.0187
Max	.0747	.0362	.0181	.0366	.0724	.0747	.0187
Min	.0037	.0187	.0181	.0181	.0181	.0181	.0187
Avg	.0352	.0275	.0181	.0207	.0434	.0434	.0187

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 208 / Railway station Express NON SHEDDABLE EXPRESS HV FEEDERS  
 feeder Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0362		.0543		.0543	.0543	.0373
2	.0362		.0543		.0543	.0543	.0373
3	.0362	.0543	.0543	.0543	.0543		.0373
4	.0362				.0543	.0543	.0373
5	.0543		.0543		.0543		.0373
6	.0543	.0543	.0543	.0543	.0543	.0543	
7	.0543				.0543		
8	.0543	.0543	.0543	.0543	.0543	.0543	
9		.056	.0543	.056	.0543	.056	
10		.056		.056	.0724		
11		.056	.0724		.0543	.056	
12		.056	.0543	.0373	.0543	.056	
13		.056	.0543		.0543	.0514	
14		.056		.0373		.0543	
15			.0362	.0373	.0543	.0343	
16						.0373	
21	.0543					.056	
22						.0514	
23	.0543					.056	
24	.0543	.0543	.0543	.056	.0543	.0543	.056
Max	.0543	.056	.0724	.056	.0724	.056	.056
Min	.0362	.0543	.0362	.0373	.0543	.0343	.0373
Avg	.0477	.0553	.0543	.0492	.0555	.0522	.0404

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 209 / 11 KV SAMRTH NAGAR FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3077	.2896	.2896		.2896	.2896	.2987
2	.3077	.2896	.2896		.2896		.2987
3	.3077	.2896	.2896	.2896	.2896	.2896	.2987
4	.3258		.2896		.3258		.3174
5	.3982	.4344	.3258		.362	.362	.3361
6	.4887	.5068	.3801	.3801	.4525	.4344	
7	.6154	.6335	.5249	.4887	.5611	.6516	
8	.7059	.6697	.7059	.6516	.6516	.6878	
9	.5601	.5601	.6516	.6348	.6516	.6535	
10		.5228	.5973	.5975	.5611		
11	.0523		.5249		.5249	.5144	
12		.4854	.4887	.5601	.4706	.4294	
13	.3601	.4481	.3982	.5601	.5041	.3944	
14		.4108		.4108		.4108	
15	.3921		.3439	.3547	.3982	.4108	
16						.3921	
17	.0467						
19	.6348						
20	.6535						
21	.5249						
22	.4525					.3772	
23	.3258					.3361	
24	.3077	.2896	.2896	.2896	.2896	.2896	.2987
Max	.7059	.6697	.7059	.6516	.6516	.6878	.3361
Min	.0467	.2896	.2896	.2896	.2896	.2896	.2987
Avg	.4088	.4485	.4260	.4743	.4415	.4327	.3081



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 210 / 11 KV TV centre New  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1267		.1267				
2					.1448		.1307
3	.1267			.1267		.1267	.1307
4		.181			.1448		.1494
5	.2172		.181		.181		.2427
6	.3801	.3801	.2896	.3439	.3258	.3439	
7	.4525	.4163	.4163	.3982	.4163	.4344	
8	.4706	.4706	.4525	.4525	.4525	.4525	
9		.3734	.3982	.3734	.4344	.3734	
10		.3361	.3258	.3086	.3439		
11			.2715		.2896	.3174	
12		.168		.1619		.1867	
13		.1307	.181		.1991		
14		.1494		.1307		.168	
15			.1629	.1494	.1629		
16						.1307	
21						.2241	
22	.181					.1867	
23	.1448					.1494	
24	.1267	.1448	.1267	.1448	.1448	.1267	.1307
Max	.4706	.4706	.4525	.4525	.4525	.4525	.2427
Min	.1267	.1307	.1267	.1267	.1448	.1267	.1307
Avg	.2474	.2750	.2666	.2590	.2700	.2477	.1568

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 213 / 11 KV YOGESH NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258	.3258	.3258		.3077	.3258	.3174
2	.3258	.3258	.3258			.3258	.3174
3	.3258			.3258	.3077	.3258	.3174
4	.362	.362	.362			.362	.3547
5	.6335	.6697					.7095
6	1.0498	.905	.7783	.6878	.7964	.905	
7	1.1765	1.1222	1.0317	.9593	1.0498	1.1222	
8	1.2127	1.1946	1.086	1.1765	1.267	1.2308	
9	.9335	1.0269	1.1765	1.086	1.0679	1.0269	
10		.9335	.9412	.905	.7602		
11	.6722	.7468	.8688	.8688	.5792	.7842	
12		.5975	.5973	.8145	.4525	.5975	
13	.4294	.3734	.3258	.5068	.3982	.5041	
14		.4108	.4163	.4163		.3921	
15			.3982	.3547	.3258		
16						.4108	
17	.7095						
19	.8402						
20	.8402						
21	.6516					.7095	
22	.5068					.5601	
23	.362					.3734	
24	.3258	.3258	.3258	.3258	.3077	.3258	.2915
Max	1.2127	1.1946	1.1765	1.1765	1.267	1.2308	.7095
Min	.3258	.3258	.3258	.3258	.3077	.3258	.2915
Avg	.6491	.6657	.6400	.7023	.6350	.6048	.3847

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134030 / Pole Factory Sub-station

Feeder No / Name : 201 / 11KV Industrial, Pole SHEDDABLE FEEDER HAVING WEEKLY  
 factory Feeder KV- 11 / STAGGERING (MIDC, EQUIVALENT)  
 OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.679	.7545	.7733	.811	.6413	.9431	.8488
2	.6413	.7167	.7733	.811	.6413	.9431	.8676
3	.6413	.679	.7733	.811	.6413	.9431	.9431
4	.679	.6413	.7545	.7545	.679	1.0185	1.0185
5	.7167	.679	.7545	.7167	.679	1.1317	1.0374
6	.8676	.7922	.7545	.679	.7167	1.2071	1.0374
7	.9808	.9054	.7733	.679	.7545	1.2071	1.0562
8	.9808	.9431	.7733	.6036	.9054	1.1317	1.1506
9	1.1694	1.1317	.9997	.6036	1.094	1.2826	1.1694
10	.9808	1.2826	1.1317	.5658	1.1694	1.3203	1.3957
11	1.2071	1.2449	1.1317	.6036	1.2071	1.2449	1.5844
12	1.2826	1.3203	1.1317	.5658	1.358	1.3203	1.5089
13	1.2449	1.2071	1.094		1.2071	1.2449	1.358
14	1.094	1.1317	.9808	.4527	1.1694	1.1317	1.2071
15	1.3203	1.2826	1.2449	.4527	1.4335	1.2071	1.3957
16	1.2449	1.358	1.2071	.415	1.358	1.1694	1.3203
17	1.2449	1.2071	1.226	.3772	1.358	1.3203	1.358
18	1.094	1.1317	1.1506	.4338	1.4146	1.3203	1.2449
19	1.0562	1.226	1.1128	.4527	1.358	1.358	1.2449
20	1.0751	1.0374	.9808	.4338	1.2071	1.2071	1.1694
21	.9242	.811	.8299	.4904	1.226	1.0562	.9431
22	.8316	.7922	.811	.6036	1.0374	.9054	.9054
23	.8676	.7733	.8488	.5658	.8676	.9054	.9619
24	.6413	.7922	.7733	.811	.5847	1.0374	.8676
Max	1.3203	1.358	1.2449	.811	1.4335	1.358	1.5844
Min	.6413	.6413	.7545	.3772	.5847	.9054	.8488
Avg	.9777	.9934	.9494	.5954	1.0295	1.1482	1.1498

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134030 / Pole Factory Sub-station

Feeder No / Name : 202 / 11 KV AGRESAN FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3326	.3395	.2587	.3292	.2926	.4805	.2772
2	.2957	.3326	.2587	.3292	.2926	.4755	.2772
3	.3326	.2957	.2772	.3292	.2926	.4755	.2957
4	.3326	.2957	.2772	.3658	.3658	.3772	.3881
5	.3696	.3696	.3696	.439	.4024	.3658	.5175
6	.5175	.4805	.4435	.5121	.439	.5487	.5544
7	.7392	.6283	.5729	.5487	.6219	.5853	.5729
8	.7762	.7023	.7023	.6584	.7316	.7316	.7207
9	.8131	.7762	.7762	.7316	.7762	.7316	.7577
10	.7316	.6219	.695	.7316	.6653	.6219	.6219
11	.6584	.5487	.6219	.5487	.5544	.5853	.5487
12	.4024	.439	.3658	.5121	.4805	.4755	.4755
13	.439	.3292	.3292		.4435	.3292	.439
14	.3658	.3658	.2561	.4024	.4066	.3292	.3696
15	.3292	.3292	.3658	.2926	.3326	.3292	.2218
16	.3658	.3292	.3658	.3658	.3326	.3292	.2957
17	.439	.4251	.4251	.4066	.4251	.3696	.3696
18	.499	.5359	.5914		.5359	.5175	.5175
19	.6283	.5914	.6283	.5544	.5544	.5914	.5544
20	.5544	.6468	.6283	.4805	.5544	.7023	.5175
21	.499	.499	.5359	.4805	.462	.5175	.4805
22	.4435	.4251	.4435	.4066	.4066	.4435	.4435
23	.3696	.3326	.3511	.3326	.3326	.3511	.3326
24	.2957	.2957	.2772	.3142	.2957	.2772	.2587
Max	.8131	.7762	.7762	.7316	.7762	.7316	.7577
Min	.2957	.2957	.2561	.2926	.2926	.2772	.2218
Avg	.4804	.4556	.4507	.4578	.4582	.4809	.4503

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 201 / RLY STN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.5975		.5487	.5228	.5415	.5415
2	.5415	.5729		.5121	.5041		.5228
3	.5228	.5544		.439	.4854		.5041
4	.5228	.5359		.5853	.4668		.5975
5	.7282	.6908		.7316	.5601		.5975
6		.9149		.9145	.8029		.8402
7		1.1576		1.2437	1.1389		1.1949
8		1.423		1.4266	.5228		
9	1.3717	1.2803		1.3443	1.3535		1.6095
10		1.1888		1.2883	1.2071	1.6095	1.3169
11		1.1043		1.2136	.9511	1.2437	1.2437
12		1.0059		.9709	.8779		.9877
13		.9145		.8775	.8779	.8779	.8779
14		.823		.7468	.8048	.823	.7682
15		.823		.7655	.7682	.7682	
16		.9145		.7655	.695		
17	1.0059	1.0269	1.0608		.8413	1.0425	.9335
18	1.1888	1.0269	1.2071		1.0608	1.2012	1.2136
19	1.2936	1.6617	1.0608		1.386	1.3306	1.2136
20	1.2012	1.531	1.0608		1.2012	1.2567	
21	1.1088	1.4937	1.0608		1.1088	1.1827	
22	.9145	.8775	.7682		.924	1.0719	
23		.7468	.695				
24	.5788	.6161	.5975	.6219	.5415	.5601	.5601
Max	1.3717	1.6617	1.2071	1.4266	1.386	1.6095	1.6095
Min	.5228	.5359	.5975	.439	.4668	.5415	.5041
Avg	.8876	.9784	.9389	.8821	.8523	1.0392	.9131

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 202 / BUS STAND

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2772	.2801		.1867	.2801	.3734	.2801
2	.2801	.2801		.1867	.2772		.2801
3	.2801	.2772		.1867	.2801		.2801
4	.2801	.2772		.1867	.2801		.2801
5	.7282	.3734		.3734	.2801		.6908
6		.3696		.3734	.3734		.3734
7		.2614		.3734	.4668		.3734
8		.3734		.3734	.5601		
9	.4572	.4572		.3734	.6535		.6535
10		.5487		.3734	.5601	.8402	.5601
11		.5487		.3734	.4668	.6535	.5601
12		.5487		.4668	.3734		.4668
13		.5487		.6535	.3734	.5601	.3734
14		.4572		.7392	.3734	.4668	.3734
15		.4572		.5601	.3734	.3734	
16		.4572		.3734	.3734	.3734	
17	.7316	.5601	.6535	.6401	.5487	.5487	.3734
18	.9145	.6535	.7468	1.1088	.823	.7392	.5601
19	1.1088	1.0269	.5601	1.0164	1.0164	.924	1.0269
20	.924	.8402	.3734		.7392	.7392	
21	.6468	.6535	.3734		.5544	.5544	
22	.5487	.3734	.3734		.4805	.462	
23		.2801	.3734				
24	.3696	.3734	.2804	.2801	.3734	.3734	.3734
Max	1.1088	1.0269	.7468	1.1088	1.0164	.924	1.0269
Min	.2772	.2614	.2804	.1867	.2772	.3734	.2801
Avg	.5805	.4699	.4668	.4600	.4731	.5701	.4635

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 203 / KADRABAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168	.1663		.2241	.1494	.1494	.1494
2	.1478	.1494		.1867	.1307		.1494
3	.1478	.1478		.1867	.1307		.1294
4	.168	.168		.3174			.1307
5	.1867	.1867		.2987	.1307		.168
6		.2241		.3361	.2614		.2427
7		.2614		.3734	.3921		.3361
8		.3547		.4108	.4481		
9	.439	.3292		.3734	.5228		.6722
10		.3292		.3547	.5975	.7095	.6348
11		.3292		.3326	.5601	.5975	.5975
12		.3292		.3174	.4854		.4481
13		.3109		.2987	.4481	.4854	.4108
14		.2926		.2801	.4108	.4481	.3734
15		.2743		.2614	.2614	.3734	
16		.2926		.2614	.2614	.3361	
17	.3658	.3361	.5601		.2926	.3292	1.1576
18	.439	.3734	.6722		.4024	.4251	.4481
19	.4805	.4294	.5975		.4805	.5729	.4805
20		.3734	.4481		.4066	.4066	
21		.3547	.4108		.3696	.3696	
22		.2614	.4108		.3326	.3696	
23		.1848	.3734				
24	.168	.168	.168	.2614	.1494	.168	.168
Max	.4805	.4294	.6722	.4108	.5975	.7095	1.1576
Min	.1478	.1478	.168	.1867	.1307	.1494	.1294
Avg	.2711	.2761	.4551	.2985	.3466	.4100	.3939

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 204 / 11KV PWW FEEDER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.0934		.0934	.0934	.0934	.0934
2	.0938	.0934		.0934	.0934		.0934
3	.0924	.0938		.0934	.0934		.0934
4	.0924	.0938		.0934	.0934		.0934
5		.0934		.0934	.0938		.0934
6		.0924		.0934	.0934		.0934
7		.0934		.0934	.0934		.0934
8		.0938		.0934	.0934		
9	.0914	.0914		.0934	.0934		.0934
10		.0914		.0934	.0934	.0934	.0934
11		.0914		.0934	.0934	.0934	.0934
12		.0914		.0934	.0934		.0934
13		.0914		.0934	.0934	.0934	.0934
14		.0914		.0934	.0934	.0934	.0934
15		.0914		.0934	.0934	.0934	
16		.0914		.0934	.0934	.0934	
17	.0914	.0934	.0934	.0914	.0886		.0934
18	.0914	.0924	.0934	.0924	.0914	.0924	.0934
19	.0924	.0934	.0934	.0924	.0924	.0924	.0924
20	.0924	.0934	.0934		.0924	.0924	
21	.0924	.0934	.0934		.0924	.0924	
22	.0914	.0934	.0934		.0924	.0924	
23		.0934	.0934				
24	.0934	.0924	.0934	.0934	.0934	.0934	.0934
Max	.0938	.0938	.0934	.0934	.0938	.0934	.0934
Min	.0914	.0914	.0934	.0914	.0886	.0924	.0924
Avg	.0924	.0927	.0934	.0932	.0929	.0930	.0933



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 205 / JINDAL COMPLEX INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0924	.0924		.0934	.0934	.0934	.0934
2	.0934	.0934		.0934	.0934		.0934
3	.0924	.0938		.0934	.0934		.0934
4	.0924	.0934		.0934	.0857		.0938
5		.0934		.0934	.0934		.0934
6		.0934		.0934	.0934		.0938
7		.0934		.0934	.0934		.0934
8		.0934		.0934	.0934		
9		.0914		.0934	.0934	.0934	.0934
10		.0914		.0934	.0934	.0934	.0934
11	.0914	.0914		.0934	.0934	.0934	.0934
12		.0914		.0934	.0934		.0934
13		.0914		.0934	.0934	.0934	.0934
14		.0914		.0934	.0934	.0934	.0934
15		.0914		.0934	.0934	.0934	
16		.0914		.0934	.0934	.0934	
17	.0914	.0924	.0934		.0914	.0914	.0934
18	.0914	.0934	.0934		.0914	.0924	.0934
19	.0924	.0934	.0934		.0924	.0924	.0934
20	.0924	.0934	.0934		.0924	.0924	
21	.0924	.0934	.0934		.0924	.0924	
22	.0914	.0934	.0934		.0924	.0924	
23		.0934	.0934				
24	.0934	.0924	.0934	.0934	.0934	.0934	.0934
Max	.0934	.0938	.0934	.0934	.0934	.0934	.0938
Min	.0914	.0914	.0934	.0934	.0857	.0914	.0934
Avg	.0922	.0926	.0934	.0934	.0927	.0929	.0934

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 206 / Mangal Bazar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5415	.5359		.5601	.5228	.499	.5041
2	.5228	.5228		.4854	.5041		.4854
3	.499	.5041		.4481	.4854		.4668
4	.4854	.4805		.5601	.4668		.5601
5		.7095		.7842	.4668		.7468
6		.9149		1.1203	1.0642		1.0642
7		1.363		1.4563	1.6991		1.531
8		1.7177		1.7924	1.8111		
9		1.5729		1.6804	1.7551	1.531	1.643
10		1.39		1.4937	1.419	1.5684	1.307
11		1.2071		1.3817	1.1203	1.0456	1.2696
12		1.0974		1.1389	1.0082		.9709
13		1.0242		.9335	.8215	.8589	.9335
14		.9145		.7842	.7095	.7842	.7468
15		.7316		.8775	.7095	.7468	
16		.8413		.8029	.6722	.6722	
17	.8779	.9709	1.0829		.7316	.8779	1.1576
18	1.0974	1.1088	1.3443		1.0059	1.2197	1.531
19	1.2936	1.4937	1.1949		1.4415	1.4784	1.5684
20		1.419	1.1576		1.2567	1.1827	
21		1.0642	1.0456		1.1088	.9979	
22		.8402	.8215		1.0349	.924	
23		.7095	.6722				
24	.5601	.5601	.5415	.5601	.4973	.5228	.5228
Max	1.2936	1.7177	1.3443	1.7924	1.8111	1.5684	1.643
Min	.4854	.4805	.5415	.4481	.4668	.499	.4668
Avg	.7347	.9872	.9826	.9918	.9701	.9940	1.0005

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 207 / NARIMAN NAGAR FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.1867		.1867	.1867	.168	.168
2	.1867	.1867		.1494	.168		.168
3	.1848	.168		.1307	.1494		.1494
4	.1848			.168	.1307		.1494
5		.2054		.2054	.168		.2241
6		.2241		.2614	.2801		.3174
7		.3361		.4294	.4108		.4481
8		.4854		.4668	.4854		
9		.439		.4668	.5041		.5041
10		.4024		.4481	.4481	.5041	.4108
11		.3841		.4294	.4294	.4668	.3734
12		.3658		.4854	.3921		.3174
13		.3292		.3601	.1867	.3547	.2801
14		.3109		.3547	.2987	.3174	.3734
15		.3109		.3361	.3174	.2987	
16		.3475		.3174	.2614	.2614	
17	.3658	.3734	.3734		.2926	.3658	.4108
18	.4024	.3881	.4108		.3841	.4066	.4668
19	.4435	.4481	.3734		.462	.4251	.4854
20		.4108	.3547		.4066	.3881	
21		.3361	.3361		.3696	.3696	
22		.2772	.2614		.3326	.3326	
23		.2241					
24	.2218	.2054	.2054	.2054	.2054	.1867	.1867
Max	.4435	.4854	.4108	.4854	.5041	.5041	.5041
Min	.1848	.168	.2054	.1307	.1307	.168	.1494
Avg	.2744	.3194	.3307	.3177	.3161	.3461	.3196

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 208 / TULJABHWANI NAGAR FEEDER SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0554	.056		.0549	.0373	.0373	.0373
2	.056	.056		.0549	.0373		.0373
3	.037	.0554		.0366	.0373		.0373
4	.0373			.0366	.0373		.0373
5		.0747		.0366	.168		.0373
6		.0934		.0549	.0747		.0747
7		.0934		.1097	.1307		.1307
8		.112		.128	.1307		
9		.0914		.112	.1097		.1463
10		.0914		.112	.0914	.128	.0914
11		.0914		.0934	.0914	.0732	.0914
12		.0914		.0747	.0914		.0914
13		.0914		.0747	.0914	.0914	.0732
14		.0914		.0747		.0732	.0914
15		.0914		.0934	.0732	.0914	
16		.0914		.112	.0549	.0732	
17	.0914	.0934	.1097		.0732	.0914	.0934
18	.0914	.0934	.128		.0914	.1109	.0934
19	.0924	.112	.1097		.1109	.1109	.0934
20	.1109	.0924	.0914		.1109	.1109	
21	.1109	.0934	.0914		.0924	.0924	
22	.0914	.0934	.0732		.0924	.0924	
23		.0747	.0549				
24	.056	.0747	.056	.0549	.0373	.056	.0373
Max	.1109	.112	.128	.128	.168	.128	.1463
Min	.037	.0554	.0549	.0366	.0373	.0373	.0373
Avg	.0755	.0869	.0893	.0773	.0848	.0880	.0761

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 209 / 11 KV SAMBHAJI NAGAR8

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5544	.5544		.4854	.4854	.5415	.5601
2	.5415	.5359		.4108	.4668		.5415
3	.5175	.4854		.4108	.4481		.5228
4	.499	.4854		.4481	.5415		.0373
5		.6908		.7095	.7095		.6908
6		.8775		.8775	1.1763		.8402
7		1.1763		1.1576	1.2883		1.4003
8		1.3817		1.3817	1.5497		
9		1.2803		1.307	1.419	1.3443	1.3443
10		1.2071		1.2883	1.307	1.419	1.1949
11		1.0974		1.2696	1.1203	1.2696	1.1576
12		1.0242		1.1016	1.0829		.8215
13		.9145		.8775	.8962	.8215	.7468
14		.8413		.7095	.7468	.7842	.6401
15		.823		.9149	.7468	.8215	
16		.8779		.9149	.6348	.6348	
17	.9511	1.0829	.9709		.7316	.8962	1.0642
18	1.134	1.1203	1.1576		.9511	1.1088	1.4937
19	1.2936	1.3256	1.0456		1.2012	1.2936	1.3817
20		1.251	.9709		1.0349	1.1088	
21		1.1016	.8962		.924	.924	
22		.8775	.6722		.8871	.8871	
23	.6908	.6908	.5975				
24	.5788	.5788	.5041	.5228	.5041	.5601	.5788
Max	1.2936	1.3817	1.1576	1.3817	1.5497	1.419	1.4937
Min	.499	.4854	.5041	.4108	.4481	.5415	.0373
Avg	.7512	.9284	.8519	.8699	.9067	.961	.8833

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134036 / 33/11 KV Rohanwadi

Substaion

Feeder No / Name : 201 / 11 kv Sarswati Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4525	.4525	.4706	.4344	.362	.3982	.3982
2	.4163	.4525	.4706	.4706	.3439	.4163	.362
3	.3982	.4525	.5068	.543	.362	.4706	.3982
4	.4344	.4525	.543	.6878	.3982	.5792	.4525
5	.6335	.5792	.6516	.7602	.5068	.8326	.543
6	.8326	.7602	.8145	.905	.543	.9412	.7421
7	.9412	.9955	.9774	.9774	.724	1.0498	.9231
8	1.1946	1.1403	1.1584	1.086	.9774	1.1584	1.0498
9	1.3213	1.086	1.2489	1.2308	.905	.9955	1.1946
10	1.1765	1.0679	1.1403	1.1041	.9412	1.0136	1.1041
11	1.1041	1.086	1.1041	.8869	.8145	.8869	.9412
12	.9774	.9412	.9412	.8316	.905	.8869	.905
13	.9955	.905	.905	.7421	.7602	.8507	.8145
14	.8869	.8688	.8326	.6878	.7602	.724	.8145
15	.8326	.8507	.7783	.6516	.724	.7964	.7421
16	.7602	.8145	.7964	.7602	.6878	.7783	.7783
17	.8869	.8326	.8326	.8326	.724	.7783	.7964
18	.8688	.7964	.9231	.8507	.905	.8688	.8326
19	.9412	.7783	.8507	.8688	.8326	.905	.9412
20	.8326	.724	.724	.724	.7602	.8145	.9231
21	.724	.6878	.543	.7059	.6697	.6878	.724
22	.6516	.5792	.5068	.5611	.543	.6154	.5792
23	.5068	.4887	.4525	.3982	.4706	.5068	.4706
24	.4887	.4706	.4706	.3982	.362	.4344	.4525
Max	1.3213	1.1403	1.2489	1.2308	.9774	1.1584	1.1946
Min	.3982	.4525	.4525	.3982	.3439	.3982	.362
Avg	.8024	.7610	.7768	.7541	.6659	.7662	.7451

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134036 / 33/11 KV Rohanwadi

Substaion

Feeder No / Name : 202 / 11 KV Bholeshwar Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7207	.7207	.8871	.7023	.6468	.7023	.6468
2	.6838	.7023	.8871	.7762	.6283	.7392	.6468
3	.6283	.7023	.924	.8501	.6468	.8501	.7023
4	.5914	.6468	.961	.961	.7023	.9979	.8316
5	.7762	.7947	1.0719	1.0534	.8316	1.2567	.924
6	1.2012	1.0719	1.2012	1.2567	1.1088	1.4045	1.1088
7	1.6263	1.5154	1.3676	1.4045	1.5154	1.6448	1.5893
8	2.0144	1.7741	1.4969	1.7926	1.7741	1.848	1.8296
9	1.8111	1.6632	1.5708	1.9404	1.6632	1.7741	1.7926
10	1.5339	1.2936	1.4969	1.5708	1.423	1.386	1.4969
11	1.4784	1.1765	1.4045	1.3491	1.3213	1.3491	1.3491
12	1.3676	1.1458	1.2936	1.2012	1.1458	1.1827	1.1827
13	1.1827	.9425	.9055	.9795	1.0719	1.0164	1.0349
14	.9425	.9979	.9795	.8316	.9425	.8316	.961
15	.9055	.7947	.8686	.8316	.9055	.8686	.8871
16	1.0534	.9979	.9425	.924	.9979	.9979	1.0903
17	1.0719	1.2012	1.1458	1.1273	1.1273	1.1088	1.2197
18	1.5154	1.5708	1.5154	1.4415	1.6078	1.4784	1.5154
19	1.6448	1.5203	1.5339	1.4969	1.5893	1.6078	1.6817
20	1.386		1.3306	1.2567	1.386	1.4045	1.5339
21	1.2197		.9425	1.2197	1.1458	1.1458	1.2197
22	1.0349		.924	.9979	.9425	.961	1.0164
23	.9425		.7947	.7947	.7577	.7577	.8316
24	.7762	.8316	.8501	.6653	.6838	.7392	.6468
Max	2.0144	1.7741	1.5708	1.9404	1.7741	1.848	1.8296
Min	.5914	.6468	.7947	.6653	.6283	.7023	.6468
Avg	1.1712	1.1032	1.1373	1.1427	1.1069	1.1689	1.1558

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134045 / 33/11 KV Motibag Substaion

Feeder No / Name : 201 / 11 KV Gokulnagari feeder SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3704	.3715	.3506		.3715	.3715	.3155
2	.3704		.3506		.3715	.3715	.3155
3	.3704		.3506		.3715	.3715	.394
4	.4074	.4458	.3506	.4087	.4458	.4458	.4477
5	.4815	.5201	.4298	.483	.5944	.595	.5014
6	.5926	.6316	.6219	.6316	.6316	.6316	.7392
7	.8889	.8916	.7023	.7059	.8731	.9288	.8501
8	.7037	.8916	.7577	.8359	.8173	.8916	.924
9	.6838	.8501	.7762	.7392	.8165	.8173	.8889
10	.6036	.8316	.6767	.8131	.6866	.7392	.6667
11	.695	.6401	.5611	.7023	.5567	.7392	.5185
12	.6401	.6036	.4887	.4887	.5196	.4477	.5185
13	.543	.4525	.4525	.4344	.3711	.4119	.5185
14	.4887	.4119	.3761	.4298	.334	.3544	.4074
15	.4163		.3366	.3582	.3155	.3761	.4074
16	.394	.4163	.394	.3467	.3155	.3155	.3704
17	.5201	.4815	.4082	.483	.3711	.4887	.4449
18	.7988	.6667	.5381	.6687	.6687	.6219	.7037
19	.8916	.7778	.6309	.6873	.7237	.7392	.7407
20	.7802	.7407	.5753	.6687	.6316	.7392	.7577
21	.6501	.6667	.5196	.5944	.6687	.6036	.7392
22	.5573	.5944	.4825	.4458	.5201	.394	.6036
23		.543				.3506	.3544
24	.3708	.3715	.4207	.3715	.3715	.3715	.3506
Max	.8916	.8916	.7762	.8359	.8731	.9288	.924
Min	.3704	.3715	.3366	.3467	.3155	.3155	.3155
Avg	.5747	.6096	.5022	.5648	.5369	.5466	.5616



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134045 / 33/11 KV Motibag Substaion

Feeder No / Name : 202 / 11 KV Dukhi Nagar SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8907	.8916	.8871	.9288	.9288	.9288	.8686
2	.8907		.8871		.9288	.9288	.924
3	.8907		.8871		.9288	.9288	.924
4	.9278	1.0774	.9979	1.2631	1.0774	1.1517	1.1763
5	1.0021	1.3003	1.2696	1.3746	1.1888	1.3746	1.4937
6	1.4074	1.4489	1.4563	1.6718	1.5604	1.5604	1.7541
7	1.8889	1.9133	1.8861	1.8204	1.9876	1.9504	1.9993
8	2.1852	2.0062	2.0559	1.9319	2.0433	2.1176	.2248
9	.2401	1.9805	.2191	1.7461	2.0969	1.9319	1.967
10	.2134	1.9239	2.037	2.0748	1.967	1.7541	1.7814
11	.2305	1.6221	2.037	1.9616	1.7814	1.8107	1.5959
12	.2191	1.6975	1.773	1.6598	1.5773	1.6032	1.7443
13	1.9993	1.5278	1.5844	1.531	1.4289	1.4563	1.5216
14	1.5089	1.3443	1.4003	1.1643	1.0021	1.2883	1.4103
15	1.2136		1.3443	1.0719	1.0392	1.1458	1.1876
16	1.1949	1.2696	1.307	1.1458	1.132	1.1088	1.2247
17	1.4861	1.5216	1.3917	1.3375	1.4474	1.6057	1.4845
18	1.7647	1.8928	1.6701	1.8204	1.8557	1.7353	1.7814
19	1.8947	1.9299	1.8557	1.8204	1.8	1.8107	2.0041
20	1.7461	1.7072	1.6144	1.8576	1.709	1.6975	1.773
21	1.4861	1.5588	1.4103	1.4861	1.5604	1.5089	1.587
22	1.3375	1.3375	1.2247	1.3003	1.3746	1.2136	1.3769
23		.9979				.9335	1.0269
24	.9278	.9288	.924	.9288	.9288	.9288	.8871
Max	2.1852	2.0062	2.0559	2.0748	2.0969	2.1176	2.0041
Min	.2134	.8916	.2191	.9288	.9288	.9288	.2248
Avg	1.1977	1.5180	1.3965	1.5189	1.4498	1.4364	1.4049

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134045 / 33/11 KV Motibag Substaion

Feeder No / Name : 203 / 11 KV BACHAT BHAVAN FEEDER SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1481	.1486	.1387	.1486	.1486	.1486	.12
2	.1481		.1387		.1486	.1486	.12
3	.1481		.1387		.1486	.1486	.1372
4		.1858	.156	.1672	.1672	.1672	.1372
5	.1852	.2229	.1907	.2043	.2043	.2043	.1734
6	.2222	.2601	.2279	.2415	.2415	.2415	.2454
7	.2963	.3344	.2804	.2786	.2786	.3158	.3189
8	.3333	.3344	.3366	.2972	.2786	.3344	.3189
9	.3224	.3189	.298	.2786	.2972	.2972	.3333
10	.3258	.3012	.2804	.3189	.2601	.2774	.2593
11	.2686	.2454	.2629	.2804	.2043	.2454	.2222
12	.2481	.1907	.1907	.208	.2043	.1907	.2222
13	.2126	.1734	.1734	.208	.1858	.1734	.1852
14	.1907	.1734	.1387	.1734	.1672	.156	.1481
15	.1734		.156	.1387	.1672	.1372	.1481
16	.1734	.156	.1734	.1734	.1672	.1543	.1481
17	.2043	.1852	.1672	.2229	.1858	.1734	.1852
18	.2229	.2222	.2415	.2229		.2254	.2222
19	.2786	.2222	.2415	.2229	.2229	.2835	.2593
20	.2601	.2222	.2229	.2043	.2415	.2835	.2454
21	.2043	.2222	.1858	.2229	.2229	.2454	.2279
22	.1858	.1858	.1486	.1858	.2043	.1907	.1734
23		.156				.1372	.1372
24	.1481	.1486	.1387	.1486	.1486	.1486	.1372
Max	.3333	.3344	.3366	.3189	.2972	.3344	.3333
Min	.1481	.1486	.1387	.1387	.1486	.1372	.12
Avg	.2227	.2195	.2012	.2165	.2043	.2095	.2011

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134019 / RAMNAGAR 33/11 KV S/S

Feeder No / Name : 202 / RAMNAGAR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5487	.4572	.5487	.4572
2			.5487	.4572	.5487	.4572
3			.5487	.4572	.6401	.4572
4			.5487	.4572	.6401	.4572
5			.5487	.6097	.6401	
6			.6401	.6859	.6401	.4572
7			.9145	.7926	1.0059	.7621
8			1.0974	.9145	1.1888	.9145
10	1.2803	1.1317				
11	1.2689	1.1488				
12	1.5432	1.4575				
13	1.5775	1.3717				
14	1.5432	1.4403				
15	1.3717	1.4575				
16	1.4746	1.3203				
17	1.286	1.1145				
18		.1463				
23		.5487	.5335	.5487	.4572	.4572
24			.5658	.5792	.5487	.4572
Max	1.5775	1.4575	1.0974	.9145	1.1888	.9145
Min	1.2689	.1463	.5335	.4572	.4572	.4572
Avg	1.4182	1.1137	.6495	.5959	.6858	.5419

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134019 / RAMNAGAR 33/11 KV S/S

Feeder No / Name : 203 / EX-D'RAJA

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.6401		.5487	.4572	.5487	.5144
2	.4572	.6401		.5487	4.603	.5487	.5335
3	.5335	.6401		.5487	.4572	.6401	.5335
4	.5335	.7316		.6401	.6097	.6401	.4572
5	.5335	.7316		.7316	.7621	.6401	.4572
6	.5335	.823					
7	.6097	.9145					
15				.6859	.9431	.9431	.9145
16				.8573	.9431	.9431	1.0974
17			.9774	.9945	.9602	.9431	1.0974
18	1.0974		1.0059	.7621			1.0974
19	.9145	.5335	.9145				
22	.9145						
24					.6097	.5487	.5335
Max	1.0974	.9145	1.0059	.9945	4.603	.9431	1.0974
Min	.4572	.5335	.9145	.5487	.4572	.5487	.4572
Avg	.6585	.7068	.9659	.7020	1.1495	.7106	.7236

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134019 / RAMNAGAR 33/11 KV S/S

Feeder No / Name : 204 / EX-GINNING

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.823		.6401	.7621	.4572	
2	.6668	.823		.1829	.7621	.4572	
3	.381	.6401		.6401	.5716	.4572	
4	.5335	.4572		.6401	.5716	.3658	
5	.381	.4572		.6401	.4763	.3658	
6	.381	.4572		.6401	.4763	.3658	
7	.381	.4572		.7316	.2858	.4572	
8	.381	.4572		.823		.4572	
9	.4763	.823		.6401			
10		.4572	.5144	.7316	.3772	.4287	.2915
11		.8916	.7202	.6859	.4115	.5144	.3429
12		.8916	.6859	.8059	.4287	.5144	.3429
13		.8916	.7716	.7202	.4458	.4801	.3429
14		.6859	.6859	.8059	.4801	.4458	.3429
15		.9602	.6859	.6859	.4572	1.0631	
16		.8916	.463		.4572	.5487	
17		.5716	.6859	.4287	.4572	.583	.3658
18	.6401	.5716	.6401	.5144	.4572		.4572
19	.6401	.5716	.7316	.2858	.4572		.4572
20	.6401	.4763	.7316	.2858	.3658		.4572
21	.6401	.4763	.7316	.381	.3658		.3658
22	.7316	.4763	.7316	.381	.3658		.4572
23	.823	.4763	.7316	.7621	.4572		.823
24	.7621	.823	.8192	.6401	.7621	.4572	
Max	.823	.9602	.8192	.823	.7621	1.0631	.823
Min	.381	.4572	.463	.1829	.2858	.3658	.2915
Avg	.5763	.6462	.6887	.5953	.4842	.4952	.4205

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134019 / RAMNAGAR 33/11 KV S/S

Feeder No / Name : 205 / BHATEPURI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.3658		.3658	.381	.3658	.4572
2	.4572	.4572		.3658	.381	.3658	
3	.4572	.4572		.3658	.4572	.4572	.4572
4	.6097	.5487		.5487	.7621	.4572	.6097
5	.7621	.7316		.7316	.9145	.7316	
6	.9145	1.0974		1.0974	1.1431	1.0974	.8383
7	.9145	1.2803		1.1888	1.2193	1.3717	1.1431
8	.7621	1.0059		1.1888		1.1888	1.0669
9	.7621	.823		1.1888			1.0669
10		.823	.4344	.8488	.7716	.7716	.7202
11		.5144	.4458		.4287	.3772	.4115
12		.3429	.3429		.3772		.3429
13		.3086	.3429		.2915		.2915
14		.2572	.3429		.3086		.2915
15		.3772	.3086	.3429	.3258		.2743
16		.3772	.2743	.5144	.4801		
17		.5335	.5144	.5658	.5487		
18	.9145	.5335	1.0974	.8383	.8573	.7621	
19	.7316	.5335	1.0059	.6859	.9259	.7621	1.0974
20	.7316	.5335	.6401	.6859	.6687	.4572	.823
21	.6401	.4572	.6401	.5335	.6173	.4572	.6401
22	.5487	.4572	.5487	.4572	.5487		.5487
23	.4572	.4572	.3658	.381	.3658	.4572	.4572
24	.4572	.3658	.4572	.3658	.381	.3658	.4572
Max	.9145	1.2803	1.0974	1.1888	1.2193	1.3717	1.1431
Min	.4572	.2572	.2743	.3429	.2915	.3658	.2743
Avg	.6611	.5683	.5174	.6631	.5980	.6529	.6313

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134019 / RAMNAGAR 33/11 KV S/S

Feeder No / Name : 206 / RAMNAGAR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.4572		.2743	.2286	.3658	.4572
2	.6097	.4572		.3658	.3048	.3658	.4572
3	.6097	.5487		.3658	.3048	.4572	.4572
4	.6097	.6401		.5487	.4572	.5487	.6097
5	.7621	.823		.823	.5335	.823	
6	.9145	1.0974		1.0059	.6097	1.0059	.6859
7	.9145	1.0059		1.0059	.6859	.9145	.8383
8		1.0059		.9145		.9145	
9		1.0059		.7316			
10		.7316	.5658	.823	.6859	.6859	
11		.5658	.4801	.6859	.3944	.3944	
12		.4287	.4801	.4458	.3429	.3944	
13		.3944	.3772	.3772	.4458	.3944	
14		.3429	.3944	.3772	.3772	.3601	.3944
15		.5144	.3772	.3772	.4287		.5487
16		.5144	.4458	.5144	.5144	.3601	
17			.6001	.6001	.6173	.6173	.7316
18	1.0974		1.0059	.7621	.823		1.0059
19	1.0059		1.0059	.6859	.8573	.7621	1.0974
20	.823	.6859	.7316	.5335	.6859	.6097	.823
21	.7316	.6097	.6401	.5335	.6859	.4572	.6401
22	.5487	.4572	.4572	.3048	.4572	.4572	.4572
23	.4572	.3048	.3658	.2286	.2743	.4572	.3658
24	.6097	.4572	.3048	.3658	.2286	.2743	.4572
Max	1.0974	1.0974	1.0059	1.0059	.8573	1.0059	1.0974
Min	.4572	.3048	.3048	.2286	.2286	.2743	.3658
Avg	.7360	.6213	.5488	.5688	.4974	.5533	.6267

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134019 / RAMNAGAR 33/11 KV S/S

Feeder No / Name : 207 / Bajiumrad FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

DATE	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6401	.4572	.7316	.4572
2			.6401	.4572	.7545	.4572
3			.6401	.4572	.7316	
4			.6401	.4572	.7316	.4572
5			.7316	1.0669	.7545	.4572
6			.7316	1.2193	.823	.7621
7			1.2803	1.3717	1.3717	1.2955
8			1.5546	1.6461	2.0119	1.3717
10	1.0974	1.0117				
11	1.3203	1.4575				
12	1.3717	1.6289				
13	1.7147	1.7147				
14	1.5432	1.3717				
15	1.2003	1.3717				
16	1.0288	1.0288				
17	1.2003	1.1145				
23		.6401	.5568	.6401	.4572	.6401
24			.6401	.4572	.7316	.4572
Max	1.7147	1.7147	1.5546	1.6461	2.0119	1.3717
Min	1.0288	.6401	.5568	.4572	.4572	.4572
Avg	1.3096	1.2600	.8055	.8230	.9099	.7062



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134019 / RAMNAGAR 33/11 KV S/S

Feeder No / Name : 209 / SALEGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4572					
2	.4572	.4572					
3	.4572	.5487					
4		.5487					
5	.4572	.6401					
6	.4572	.9145					
7	.9145	1.0974					
8	1.0669	1.2803					
9		.1463					
10				1.0059		.7716	.9259
11				1.2003	.9774	.9088	.9259
12				1.2346	1.0288	.8573	.9259
13				1.2003	1.166	.9774	1.0802
14				1.1145	.7773	.9945	1.0631
15				1.1145	.1115	.9431	1.0608
16				1.0288	.8573	.9431	
17				.9602	.8573	.8573	
20			.1463				
23	.4572	.381					
24	.381	.4572	.4115				
Max	1.0669	1.2803	.4115	1.2346	1.166	.9945	1.0802
Min	.381	.1463	.1463	.9602	.1115	.7716	.9259
Avg	.5673	.6299	.2789	1.1074	.8251	.9066	.9970

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134025 / GOLAPANGRI

Feeder No / Name : 204 / GOLAPANGHRI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524				.1829	.1829	
2	.1524				.1829	.1829	
3	.1524				.1981	.2134	
4	.1829				.1981	.2286	
5	.1981				.2134	.2439	
6	.2439				.2439	.2286	
7	.2896			.2401	.2896	.2439	
8	.3506	.2401			.2591	.1524	
9		.3086	.2743	.1829	.3201	.2591	.3601
10		.2743		.1981	.3048	.3658	.3506
11	.4973	.2896		.3048	.2743	.3658	.4268
12		.3048		.3048	.3506	.4115	.381
13		.3963		.3048	.3353	.4725	.3658
14		.3963		.3048	.3048		.3506
15		.3963	.1981	.3048	.2743	.4115	.381
16		.381		.3048	.3506	.4115	.3963
17				.3353		.381	.4115
18				.381	.2743	.3658	.3658
19			.3086	.4725	.3048	.381	.3048
20				.381	.2286		.2286
21				.3048	.2134		.2591
22				.2439	.1829		.2439
23				.2286	.1981	.2439	.2286
24	.2134				.2134	.1829	
Max	.4973	.3963	.3086	.4725	.3506	.4725	.4268
Min	.1524	.2401	.1981	.1829	.1829	.1524	.2286
Avg	.2433	.3319	.2603	.2998	.2564	.2964	.3370

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134025 / GOLAPANGRI

Feeder No / Name : 205 / mali pimpalgaon

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524				.1372	.1524	
2	.1524				.1372	.1524	
3	.1829				.1677	.1829	
4	.2439				.1981	.2286	
5	.3048				.2439	.4572	
6	.5335				.5335	.5792	
7	.6249			.7545	.6706	.6249	
8	.6554	.7373			.6097	.6554	
9		.7716	.6401	.6859	.6859	.6554	.7716
10		.5182		.6097	.503	.4268	
11	.3086	.2896		.3506	.3048	.2439	.2286
12		.1677		.2743	.1829	.1981	.1829
13		.1524		.2286	.1829		.1524
14		.1524		.1829			.1219
15		.1524	.1486	.1677		.1067	
16		.1677		.2286	.1524		.1219
17				.2743	.3048	.2134	.2439
18				.3048	.4725	.5487	.4877
19			.583	.4572	.5792	.5639	.381
20				.381			.3048
21				.2743	.2286		.2286
22				.1677	.1981		.1524
23				.1219	.1524	.1067	.1524
24	.1524				.1219	.1524	
Max	.6554	.7716	.6401	.7545	.6859	.6554	.7716
Min	.1524	.1524	.1486	.1219	.1219	.1067	.1219
Avg	.3311	.3455	.4572	.3415	.3223	.3472	.2715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134025 / GOLAPANGRI

Feeder No / Name : 206 / kajala GFS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	27-DEC-17
HR	Load (MW)
16	.1372
Max	.1372
Min	.1372
Avg	.1372

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134025 / GOLAPANGRI

Feeder No / Name : 207 / ROHANWDI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	23-DEC-17	24-DEC-17	25-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.8916	.945	.9297		
10	.6249			.7468	.7316
11	.5639			.6706	
12	.4877			.6097	.5639
13				.4725	.5335
14	.4572			.4725	.4115
15	.503			.503	
16	.6097			.5639	
17	.6401				
Max	.8916	.945	.9297	.7468	.7316
Min	.4572	.945	.9297	.4725	.4115
Avg	.5973	.945	.9297	.577	.5601

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134037 / HISWAN

Feeder No / Name : 202 / TANDULWADI AG FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1619			.8097	.9717	.9717
2	.1619			.9717	1.1336	.9717
3	.1619			.9717	1.1336	.9717
4				.9717	1.1336	.9717
5				.9717	1.2955	1.4575
6				.9717	1.2955	1.4575
7				1.1336	1.4575	1.4575
8				1.2955	1.4575	
10	1.9433	1.4575	1.4575			
11	1.7814	1.7004	1.7004			
12	1.6194	1.749	1.7814			
13	1.5708		1.9433			
14	1.587	1.6194	1.7328			
15	1.6194	1.6194	1.7004			
16	1.7814					
18					.1619	
19		.081	.1619		.1619	
20			.1619		.1619	
21			.1619		.1619	
22			.1619			
24	.1619	.081		.9717	.9717	.9717
Max	1.9433	1.749	1.9433	1.2955	1.4575	1.4575
Min	.1619	.081	.1619	.8097	.1619	.9717
Avg	1.1409	1.1868	1.0963	1.0077	.8844	1.1539

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134037 / HISWAN

Feeder No / Name : 203 / PUNEGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8097			.1134		.081	.081
2	.9717			.1134		.081	.081
3	.9717			.1134		.081	.081
4	.9717						
5	1.1336						
6	1.1336						
7	1.8623						
8	2.1052						
10				1.2955	1.6194		1.2955
11					1.9433	1.5223	1.6194
12					1.9433		1.7004
13					1.9433	2.0243	1.8623
14					1.7814	2.1052	1.7004
15						2.1052	
16						2.1052	
18	.1619						
19	.0972	.081	.1134				
20	.1296		.1134				
21	.1134		.1134				
22	.1134		.1134				
23	.6478						
24	.8097	.8907		.1134		.081	.081
Max	2.1052	.8907	.1134	1.2955	1.9433	2.1052	1.8623
Min	.0972	.081	.1134	.1134	1.6194	.081	.081
Avg	.8022	.4859	.1134	.3498	1.8461	1.1318	.9447

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134037 / HISWAN

Feeder No / Name : 204 / HISWAN+TANDULWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9717			.9717		.8097	.8097
2	.9717			.9717		.8097	.8097
3	1.1336			1.1336		.9717	.8097
4	1.1336			1.1336		.9717	.8097
5	1.1336			1.1336		.9717	.8097
6	1.1336			1.1336			
7	1.1336						
8	1.1336						
9	1.1336						
10	1.1336	1.1336	1.2955	1.1336	.9717	1.1336	1.1336
11	1.1336	1.1336	.9717		.9717	.9717	1.1336
12	1.1336	1.1336	.8907		1.1336		.9717
13	1.0526	.9717	.8907		.9717	.9717	.9717
14	1.0526	.9717	.8907		1.1336	.9717	.9717
15	1.0526	.9717	.9717			1.0526	
16	1.1336					1.1336	
19			1.1336				
20			1.1336				
21			.9717				
22			.9717				
24	1.1336	1.1336		.8097		.8097	
Max	1.1336	1.1336	1.2955	1.1336	1.1336	1.1336	1.1336
Min	.9717	.9717	.8907	.8097	.9717	.8097	.8097
Avg	1.1003	1.0642	1.0122	1.0526	1.0365	.9649	.9231



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134037 / HISWAN

Feeder No / Name : 205 / PUNEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4049			.4049		.4049	.3239
2	.4049			.4049		.4049	.3239
3	.4858			.4858		.4049	.3239
4	.4858			.4858		.4858	.3239
5	.4858			.5668		.5668	.4049
6	.4858			.5668		.5668	
7	.4049			.6478			
8	.5668						
9	.4858						
10	.4858	.583	.3239	.4858	.4049	.4858	.3239
11	.4858	.5344	.3725		.4049	.4858	.3239
12	.4858	.4372	.3239		.3239	.3725	.3239
13	.4534		.2753		.3239	.3725	.3239
14	.3887	.3725	.2753		.3239	.3563	.2753
15	.3887	.3725	.3077			.3401	
16	.4049					.3563	
19			.4858				
20			.4858				
21			.4858				
22			.4858				
24	.3239	.4858		.4858		.4049	
Max	.5668	.583	.4858	.6478	.4049	.5668	.4049
Min	.3239	.3725	.2753	.4049	.3239	.3401	.2753
Avg	.4487	.4642	.3822	.5038	.3563	.4292	.3271

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134037 / HISWAN

Feeder No / Name : 206 / GADE SAWARGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.081			.0972		.081
2	.081			.0972		.081
3	.2429			.081		.081
4	.2429					
5	.2429					
6	.3239					
7	.4049					
8	.4858					
10				.3239	.4858	.4049
11					.6478	.4858
12						.5344
13					.4858	.5668
14					.4858	.5668
15					.5668	
16					.5668	
19		.081	.081			
20			.081			
21			.081			
22			.081			
24	.081	.2429		.081		
Max	.4858	.2429	.081	.3239	.6478	.5668
Min	.081	.081	.081	.081	.4858	.081
Avg	.2429	.1620	.081	.1361	.5398	.3502

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134040 / 33KV GONDEGAON

Feeder No / Name : 201 / DHALDI - AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0898	.8573	.9221	.5716	.5716	.4763	.4763
2	1.0898	.8573	.9221	.5716	.5716	.4763	.4763
3	1.0898	1.0288	.9221	.5716	.5716	.5716	.4763
4	1.2574	1.3717	1.0898	.6668	.6668	.8573	.5716
5	1.4918	1.5432	1.4089	.8573	.7621	1.0479	.8573
6	1.6575	1.6289	1.6575	1.0479	.9526	1.1812	.9526
7	1.2384	1.3717	1.3336	1.9062	1.7404	1.749	1.7404
8	1.2384	1.5242	1.3336	2.2939	2.13	2.1091	2.13
9				2.5101	2.2939	2.4006	2.13
10				2.5101	2.2119	2.3148	1.8099
11				2.4577	2.0919	1.8823	1.7833
12				2.3758	2.2291	2.13	1.7833
13				2.2119	2.1434	2.0719	1.6213
14				2.13	2.0062	1.8233	1.5927
18	1.0669	.8573	.9526	.9526	.8192	.7621	.8573
19	.9526	.9526	.9526	.9526	.8573	.9526	.9526
20	.8573	.8573	.8573	.7621	.8002	.8573	.8573
21	.7621	.6668	.7621	.6668	.6668	.6668	.6668
22	.6097	.5716	.6668	.5716	.5335	.5716	.5716
23	.8573	.8383	.5716	.5716	.4763	.5716	.5716
24	1.0059	.1715	.9221	.5716	.5716	.4763	.4763
Max	1.6575	1.6289	1.6575	2.5101	2.2939	2.4006	2.13
Min	.6097	.1715	.5716	.5716	.4763	.4763	.4763
Avg	1.0843	1.0066	1.0183	1.3205	1.2223	1.2357	1.1121

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134040 / 33KV GONDEGAON

Feeder No / Name : 202 / WANJAR UMRAD

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2858	.1905	.3353	.5868	.5144	.5868
2	.1905	.2858	.1905	.3353	.5868	.6859	.5868
3	.1905	.381	.1905	.3353	.5868	.6859	.6706
4	.1905	.381	.1905	.3353	.6706	.8573	.8383
5	.2477	.4191	.2858	.503	.8383	1.0288	1.0059
6	.3429	.4763	.2858	.5868	.9221	1.0288	1.0898
7	.4763	.4763	.381	.381	.4763	.5335	.4763
8	.5716	.381	.4763	.381	.4763	.5335	.5716
15	1.7147	1.1888	1.5746				
16	1.8861	1.5051	1.9062				
17	1.8861	1.5203	1.6575				
18	1.406	1.4089	1.4089	.381	.381	.381	.2858
19	1.0288	.503	1.0059	.381	.381	.4763	.381
20	.8573	.6706	.8383	.2858	.3239	.381	.2858
21	.6516	.5868	.6706	.1905	.2858	.2858	.1905
22	.5487	.503	.503	.1905	.2286	.2858	.1905
23	.2858	.1905	.4191	.503	.5144	.503	.503
24	.1905	.2858	.1905	.3353	.5868	.5144	.5868
Max	1.8861	1.5203	1.9062	.5868	.9221	1.0288	1.0898
Min	.1905	.1905	.1905	.1905	.2286	.2858	.1905
Avg	.7142	.6361	.6870	.3640	.5230	.5797	.5500

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134040 / 33KV GONDEGAON

Feeder No / Name : 203 / WAGHRUL (J)  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1905	.1905	.1905	.1905	.1905
2	.1905	.1905	.1905		.1905	.1905	.1905
3	.1905	.2286	.1905	.1905	.1905	.2572	.1905
4	.1905	.2667	.1905	.1905	.1905	.3239	.1905
5	.2858	.2858	.2858	.1905	.1905	.4191	.2858
6	.3429	.2858	.381	.2858	.3429	.4763	.381
7	1.0059	1.0288	1.0059	.4763	.381	.4572	.381
8	1.8233	1.5432	1.4089	.4763	.4763	.5716	.4763
9	1.0059	1.7147	1.7404				
10	1.7404	1.8004	1.5746				
11	1.8004	1.6347	1.8233				
12	1.9719	1.4118	1.8233				
13	1.8861	1.5804	1.6575				
14	1.3717	1.3937	1.5746				
15				1.0059	1.3717	1.989	1.989
16				2.2119	1.7147	2.2119	1.9559
17				2.13	2.0233	1.9062	1.9062
18	.4001	.2858	.2858	1.4089	1.6289	1.2574	1.6575
19	.381	.381	.2858	1.1736	1.3717	1.0059	1.1736
20	.2858	.381	.2858	1.0898	1.1145	.9221	1.0059
21	.2667	.381	.2858	.9221	1.0288	.8383	.9221
22	.2858	.2858	.2286	.8383	.9431	.7545	.8383
23	.1905	.2858	.1905	.1905	.2858	.1905	.1905
24	.1905	.1905	.1905	.1905	.1905	.1905	.1905
Max	1.9719	1.8004	1.8233	2.2119	2.0233	2.2119	1.989
Min	.1905	.1905	.1905	.1905	.1905	.1905	.1905
Avg	.7617	.7498	.7519	.7742	.7681	.7863	.7842

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134040 / 33KV GONDEGAON

Feeder No / Name : 204 / WAGHUL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1715	.1715	.1715	.1715	.1715
2	.1715	.1715	.1715	.1715	.1715	.1715	.1715
3	.1715	.1715	.1715	.1715	.1715	.2058	.1715
4	.2058	.2572	.2058	.2572	.2058		.1715
5	.3429	.2572	.3429	.3429	.3429	.3429	.3429
6	.5144	.2572	.4287	.5144	.5144	.4287	.5144
7	.5144		.5144	.5144	.5144	.4287	.6001
8	.5144		.5144	.5144	.4287	.3429	.4287
9	.4287		.4287	.4287	.4287	.3429	.4287
10	.2572		.3429	.3429	.3429	.2572	.3761
11	.2572		.2572	.1715			.2812
12	.1715	.2812		.1715			.188
13	.1715	.2821	.1715	.1715			.1879
14	.1715	.2815	.1715				.1879
15		.1871	.1715	.1372			.1715
16			.1715	.1715			.1715
17		.1871	.2572	.2572	.2572		.2572
18	.4287	.3429	.3429	.4287	.4287	.4287	.3429
19	.4287	.4287	.4287	.4287	.4287	.5144	.4287
20	.3429	.3429	.3429	.3429	.3429	.4287	.3429
21	.2572	.2572	.2572	.2572	.2572	.2572	.2572
22	.2572	.1715	.1715	.1715	.1715	.1715	.1715
23	.1715	.1715	.1715	.1715	.1715	.1715	.1715
24	.1715	.1715	.1715	.1715	.1715	.1715	.1715
Max	.5144	.4287	.5144	.5144	.5144	.5144	.6001
Min	.1715	.1715	.1715	.1372	.1715	.1715	.1715
Avg	.2915	.2440	.2773	.2818	.3068	.3022	.2795

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134040 / 33KV GONDEGAON

Feeder No / Name : 205 / WANJAR UMRAD GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857	.0857	.0857	.0857	.0857	.0857
2	.0857	.0857	.0857	.0857	.0857	.0857	.0857
3	.0857	.12	.0857	.0857	.0857	.1029	.0857
4	.1029	.1715	.1029	.0857	.12	.1715	.0857
5	.1715	.2401	.1715	.1372	.1715	.1715	.1715
6	.2229	.2572	.2229	.2058	.2572	.2572	.2572
7	.2572	.2572	.2572	.2572	.2572	.2572	.3429
8	.2572	.2572	.2572	.2572	.2229	.2743	.3429
9	.2572	.2058	.2572	.1715	.1715	.2241	.3429
10	.1715	.1715	.2058	.1715	.1715	.1715	.3761
11	.0857	.0937	.12		.12	.1879	.1879
12	.0686	.0938	.0857	.0857	.0857	.0857	.1877
13	.0514	.0941	.0857	.0857	.0857	.0857	.0938
14	.0514	.0942	.0857	.0857	.0686	.0857	.0936
15	.0514	.0942	.0857	.0857	.0686	.0857	.0857
16	.0686	.0943	.0857	.0857	.1029	.0857	.0857
17	.0857	.0941	.1715	.1372	.1372	.0857	.0857
18	.2058	.2058	.2572	.2058	.2401	.2058	.2572
19	.1715	.2572	.2572	.2572	.1886	.2572	.3429
20	.1715	.2058	.2229	.1715	.1543	.2058	.2572
21	.1543	.1715	.1715	.1372	.12	.1372	.1715
22	.12	.1715	.1372	.1372	.1029	.12	.12
23	.0857	.1029	.0857	.12	.0857	.0857	.0857
24	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Max	.2572	.2572	.2572	.2572	.2572	.2743	.3761
Min	.0514	.0857	.0857	.0857	.0686	.0857	.0857
Avg	.1315	.1546	.1529	.1402	.1365	.1500	.1799

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134043 / DHARKALYAN

Feeder No / Name : 201 / KADVANCHI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4481	.5716	.7621	.5716	.7621	.3361	.4108
2	.4108	.5716	.7621	.6859	.8573		.4481
3	.3734	.5335	.7621		1.1431	.3174	.5041
4	.3921	.5716	.8573	.8573	1.5242	.3734	.3547
5			.8573	1.1431	1.5242		
6			1.0479	1.5242	1.9052		
7			1.7147	2.0957	2.0957		
8						.9149	1.0829
9						1.7364	1.3817
11				.7621		1.8671	2.0748
12						2.0538	1.6975
13						2.3339	1.7918
14						2.4272	1.6289
15						2.5206	1.8111
16	1.7147	1.7147					
17	2.4768	2.572					
18	2.0957	2.2862					
19	1.5242	1.9052			.4294		.6602
20	1.3336	1.1431			.4854		.6602
21	1.2384	1.1431			.5601		.5658
22	1.1431	.8573			.6535		.6036
23	1.0479	.7621			.7468		.4715
24	.5601	.4763	.7621	.4763	.5716	.3174	.2987
Max	2.4768	2.572	1.7147	2.0957	2.0957	2.5206	2.0748
Min	.3734	.4763	.7621	.4763	.4294	.3174	.2987
Avg	1.1353	1.1622	.9407	1.0145	1.0199	1.3817	.9674



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134043 / DHARKALYAN

Feeder No / Name : 202 / NAVHA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1203	.5716	.4763	.381	.4763		.4294
2	1.1949	.5335	.4763	.3429	.4763		.4108
3	1.2696		.5716	.381	.5335		.3361
4	1.307	.6097	.5716	.3429	.5335		.3734
5	1.4003	.5716					
6	1.587	1.5242					
7	1.1576	1.7147					
8			1.0479	1.1431	.9145		
9			2.0005	1.4289	1.5242		
10				1.7147	1.9052		
11				1.7147	2.0538		
12				1.6194	2.1472		
13					2.2405		
14		1.7147			2.3339		
15					2.5206		
16							.8488
17							2.452
18							1.4146
19	.8573	.7621			.3921		
20	.7621	.8573			.4481		.9431
21	.6668	.9526			.415		.5658
22	.6668	.6668			.5041		.5175
23	.5716	.5716			.3361		.462
24	1.0082	.4763	.4763	.4191	.5335	.2801	.3921
Max	1.587	1.7147	2.0005	1.7147	2.5206	.2801	2.452
Min	.5716	.4763	.4763	.3429	.3361	.2801	.3361
Avg	1.0438	.8867	.8029	.9488	1.1271	.2801	.7621

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134043 / DHARKALYAN

Feeder No / Name : 203 / BORKHEDI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8775	.5716	1.5242	.9526	.9526		.7282
2	.7282	.5716	1.5242	1.2384	1.1431		.6348
3	.9149	.7621	1.5242	1.3336	1.1431		.5975
4	1.0829	.8573	1.5242	1.5242	1.5242		.5415
5			1.5242	1.6194	1.9052		
6			1.8099	1.7147	2.0957		
7			2.2862	2.0005	2.5339		
8						2.2405	1.8111
9						2.2405	2.8006
10							2.8006
11						2.8753	2.894
12						3.0807	2.8753
13						3.1367	2.6139
14						3.1741	2.8006
15						3.3608	2.4272
16	2.4768	2.191					
17	2.7625	2.8578					
18	2.4768	2.572					
19	2.6673	2.4768			.5601		.9335
20	2.4768	2.0957			.6602		.8402
21	2.191	1.9052			.7167		.8589
22	1.9052	1.9052			.7545	3.3608	.8029
23	1.8099	1.7147			.7733		.7468
24	.8215	.6668	1.5242	.8573	.9145	.7095	.7468
Max	2.7625	2.8578	2.2862	2.0005	2.5339	3.3608	2.894
Min	.7282	.5716	1.5242	.8573	.5601	.7095	.5415
Avg	1.7839	1.6268	1.6552	1.4051	1.2059	2.6865	1.5808

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134043 / DHARKALYAN

Feeder No / Name : 204 / KOTHARI EXP

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0191	.0191	.0191	.0191		.0189
2	.0189	.0191	.0191	.0191	.0191		.0189
3	.0189	.0191	.0191	.0191	.0191		.0187
4	.0187	.0191	.0191	.0191	.0191		.0189
5	.0187	.0191	.0191	.0191	.0191		.0187
6	.0189	.0191	.0191		.0191		.0187
7	.0187	.0191	.0191	.0191	.0191		.0187
8	.0187	.0191	.0191	.0191	.0191		.0187
9	.0189	.0191	.0191	.0191	.0191		.0187
10	.0187	.0191		.0191	.0191		.0189
11	.0191	.0191		.0191	.0189		.0189
12	.0191	.0191		.0191	.0189		.0189
13	.0191	.0191			.0189		.0189
14	.0191	.0191			.0187		.0181
15	.0191	.0191			.0187		.0189
16	.0191	.0191			.0187		.0189
17	.0191	.0191			.0189		.0189
18	.0191	.0191			.0189		.0189
19	.0191	.0191			.0189		.0189
20	.0191	.0191			.0189		.0189
21	.0191	.0191			.0187		.0189
22	.0191	.0191			.0187		.0189
23	.0191	.0191			.0187		.0189
24	.0189	.0191	.0191	.0191	.0191	.0187	.0189
Max	.0191	.0191	.0191	.0191	.0191	.0187	.0189
Min	.0187	.0191	.0191	.0191	.0187	.0187	.0181
Avg	.0190	.0191	.0191	.0191	.0189	.0187	.0188

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134043 / DHARKALYAN

Feeder No / Name : 205 / GAWALI POKHARI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.094	.0191	.9526	.5716	.7621		1.9044
2	1.0829	.9145	.9526	.5335	.7621	1.2323	1.9978
3	1.0642	.8573	1.0479	.6097	.8573		2.0538
4	1.1317	.9526	1.0479	.5716	.8573		2.3339
5							2.4272
6							2.5206
7							2.3712
8		1.5242					
9	2.0748	2.0957					
10	2.4897	2.191					
11	2.6673	2.0957					
12	2.6673	2.0957					
13	2.2862	2.0005					
14	2.191	2.191					
15	2.2862	2.0957					
16					.7922		
17					2.0748		
18					2.3339		
19	.9526	.7621			2.452		1.0374
20	1.0479	.9526			2.6406		1.0562
21	.9526	.9526			2.3954		.9808
22	.9145	.9526			2.2445		.9054
23	.8573	.9526			1.8298		.8299
24	1.0751	.8573	.9526	.4763	.6668		1.2136
Max	2.6673	2.191	1.0479	.6097	2.6406	1.2323	2.5206
Min	.8573	.0191	.9526	.4763	.6668	1.2323	.8299
Avg	1.5785	1.3590	.9907	.5525	1.5899	1.2323	1.6640

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134043 / DHARKALYAN

Feeder No / Name : 206 / PIRKALYAN SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2858	.2858	.2858	.2286		1.8298
2	.3018	.3048	.2858	.381	.1905		1.8671
3	.3395	.3429	.2858	.3429	.1905		2.0748
4	.3961	.3429	.2858	.381	.2286		2.2405
5							2.3152
6							2.3712
7							1.8484
8	1.2637	1.4289					
9	1.9805	2.0005					
10	2.5274	2.191					
11	2.572	2.0957					
12	2.572	2.0957					
13	2.4768	2.191					
14	2.0957	2.2862					
15	2.191	2.191					
16					2.1502		
17					1.8298		
18					.2641		
19	.381	.381			.2641		.2641
20	.2858	.3429			.2641		.2263
21	.2858	.2858			.3395		.2075
22	.3048	.2858			.3961		.2641
23	.2667	.2858			.4294		.2263
24	.2829	.2286	.2858	.1905	.2477	.3547	1.094
Max	2.572	2.2862	.2858	.381	2.1502	.3547	2.3712
Min	.2641	.2286	.2858	.1905	.1905	.3547	.2075
Avg	1.1549	1.0870	.2858	.3162	.5402	.3547	1.2946

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134046 / BAWANE PANGRI 33/11 KV S/S

Feeder No / Name : 201 / BAWNEPANGRI-AG

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.3658			.5487	2.1948	.5487
2	.1848	.3658			.5487	2.1948	.5544
3	.1848	.3658			.5487	2.371	.5544
4					.7316	2.552	.5544
5					.7316	2.5339	.6401
6					.7316	2.7149	.6401
7					1.9022	2.7149	1.5364
8					2.1216	2.7149	2.1033
9						2.7692	
10	1.6461		1.4632				
11	1.829	1.8099	1.829				
12	2.1948	1.829	2.1948				
13	2.2862	2.0119	2.1948				
14	2.1948	2.1719	1.7375				
15	2.1948	1.8099	1.829				
16	2.1948	1.8099	1.829				
17	2.1948	2.1719	1.4632				
19	.1829			.1848	.2715	.1848	
20	.1829	.5487		.1848	.362	.1848	
21	.1829	.5487		.1848	.4572	.1848	
22	.2743	.543		.1848	.5487	.1848	
23	.2743	.543		.3696	.7133	.462	
24	.1829	.4525			.7059		.462
Max	2.2862	2.1719	2.1948	.3696	2.1216	2.7692	2.1033
Min	.1829	.3658	1.4632	.1848	.2715	.1848	.462
Avg	1.0923	1.1565	1.8176	.2218	.7802	1.7115	.8438

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134046 / BAWANE PANGRI 33/11 KV S/S

Feeder No / Name : 202 / MANDEULGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-DEC-17	23-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7316	.7316		.1848		.1848
2	.7316	.9145		.1848		
3	.7316	.9145		.1848		.1848
4	.7316	1.2803				
5	.9145	1.6461				
6	1.1888	1.4632				
7	1.5912	2.3777				
8	3.0727	2.7435				
10			1.7375	1.8839	2.3777	1.6278
11			2.4691	2.5606	2.7435	
12			2.7435	2.4508	3.0178	2.7435
13			2.7435	2.4253	2.8898	2.8898
14			2.7435	2.7149	2.5972	2.7435
15			3.2556	2.5339	2.4691	2.5606
16			3.2007	2.5339	2.4691	2.1948
17			2.3045		2.1948	2.1033
19	.2743	.543	.1848	.2743	.1848	
20	.2743	.5487	.1848	.362	.1848	
21	.3658		.1848	.4525	.1848	
22	.3658	.543	.1848	.543	.1848	
23	.5487	.543	.1848		.1848	
24	.5487	.4525		.543		.1848
Max	3.0727	2.7435	3.2556	2.7149	3.0178	2.8898
Min	.2743	.4525	.1848	.1848	.1848	.1848
Avg	.8622	1.1309	1.7017	1.3222	1.6679	1.7418

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407]

BU 2721

Substation No/ Name :- 134046 / BAWANE PANGRI 33/11 KV S/S

Feeder No / Name : 203 / MANDEULGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.2743			.4572	.3582	.462
2	.4572	.2743			.4572	.362	.4572
3	.4572	.2743			.4572	.362	.4572
4	.5487	.5487			.4572	.543	.4572
5	.6401	.7316			.5487	.6154	.5487
6	.7316	.823			.5487	.543	.823
7	.9145	.9145			.823	.543	.924
8	.823	.7316			.823	.543	.823
9	.7865	.6401			.6401	.543	.6401
10	.5487	.3841	.3658	.4572	.5487	.5304	.5487
11	.4572	.6602	.3658	.4572	.5068	.3658	.2743
12	.3658	.6401	.2743	.4572	.7316	.3326	.2195
13	.3658	.5068	.2743	.4572	.724	.2772	.2195
14	.2743	.4344	.2743	.3658	.543	.2772	.2743
15	.2743	.362	.2743	.2772	.8413	.2772	.2743
16	.3658	.6401	.3658	.3696	.7865	.2772	.3658
17	.3658	.543	.5487	.5487	.543	.3658	.4572
18	.5487	.8688		.6401	.8145	.6401	
19	.7316	.5973		.823	.2715	.823	
20	.9145	.6036		.7499	.362	.6767	
21	.7316	.543		.5487	.4525	.4755	
22	.5487	.543		.4572	.543	.462	
23	.3658	.543		.4572	.543	.462	
24	.2743	.4887			.5487		.462
Max	.9145	.9145	.5487	.823	.8413	.823	.924
Min	.2743	.2743	.2743	.2772	.2715	.2772	.2195
Avg	.5395	.5654	.3429	.5047	.5822	.4633	.4827



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134062 / MANEGAON

Feeder No / Name : 202 / PAREGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.5716		.1524	.1715	.1524	.1715
2	.4763	.5716		.1524	.1524	.1524	.1715
3	.5144	.5716		.1715	.1524	.1905	.1905
4	.5716	.5716					
5	.6668	.6097					
6	.7811	.724					
7	1.0288	1.0479					
8	1.1431	1.3527					
10				.8954	.8192	.8573	.724
11				1.0669	.9717	.8002	.9335
12				1.105	1.1431	.7621	1.0288
13				1.0479	1.0669	.6287	1.0288
14				.9717	1.0098	.7621	.8954
15	.1143		.1143	.9145	.8383	.9145	.8954
16	.1334		.1143	.9145	.8573	.8573	.8383
17	.1905		.1334	.8764	.8192	.7811	.724
18	.1334		.2477	.1524	.2286	.1905	.2667
19	.0953		.1905	.2667	.2667	.2286	.2477
20	.1905		.1715	.2286	.2286	.2286	.2096
21	.1905		.1905	.2096	.1905	.1905	.1524
22	.1905		.1715	.1905	.1905	.1715	.1524
23	.5144		.1334	.1905	.1524	.1715	.1524
24		.5335		.1334	.1905	.1715	
Max	1.1431	1.3527	.2477	1.105	1.1431	.9145	1.0288
Min	.0953	.5335	.1143	.1334	.1524	.1524	.1524
Avg	.4360	.7282	.1630	.5356	.5250	.4562	.5166

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134062 / MANEGAON

Feeder No / Name : 203 / SAWANGI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0479	1.0479		.2667	.2477	.2667	.2477
2	1.0479	1.0479		.2667	.2667	.2667	.2667
3	1.105	1.0479		.4191	.2858		.381
4	1.1241	1.1431					
5	1.2384	1.1431					
6	1.2955	1.1431					
7	1.4861	1.2384					
8	1.6194	1.5242					
10				1.2955	1.2574	1.5242	1.3527
11				1.5813	1.4861	1.4861	1.5813
12				1.6194	1.6766	1.3336	1.6575
13				1.6194	1.4098	1.2955	1.6004
14				1.5813	1.5623	1.4861	1.5242
15	.2477		.2096	.9526	1.4861	1.5242	1.467
16	.2858		.2667	1.6194	1.3908	1.4861	1.5051
17	.4382		.3048	1.6004	1.5242		1.5051
18	.6097		.5144	.5525	.6478	.4001	.5906
19	.6478		.5144	.4763	.6859	.6097	.6097
20	.381		.381	.4191	.4954	.5716	.4572
21	.3239		.2858	.3429	.2858	.4572	.3239
22	.3048		.2667	.2477	.2858	.3429	.2667
23	.9717		.2286	.2477	.2477	.3048	.2667
24		.9907		.2667	.2477	.2477	
Max	1.6194	1.5242	.5144	1.6194	1.6766	1.5242	1.6575
Min	.2477	.9907	.2096	.2477	.2477	.2477	.2477
Avg	.8338	1.1474	.3302	.8542	.8605	.8502	.9179

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134089 / Bhatepuri

Feeder No / Name : 201 / WADIWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.1829	.1829	.1829	.1829	.1829	.1829
2	.2743	.1829	.1829	.2743	.1829	.1829	.1829
3	.3658	.1829	.1829	.2743	.1829	.0183	.1829
4	.3658	.2743	.1829	.3658	.2743	.2743	.2743
5	.4572	.3658	.2743	.3658	.3658	.3658	.2743
6	.5487	.5487	.4572	.4572	.4572	.3658	.3658
7	.7316	.6401	.5487	.5487	.3658		.4572
8	.6401	.6401	.4572	.5487	.4572		.3658
9	.5487	.5487	.5487	.5487	.2743		.3658
10	.4572	.3658	.3658	.1829	.2743		.2743
11	.2743	.1829	.1829	.1829			.1829
12		.1829			.1829		.1829
13	.1829	.1829	.1829	.1829	.1829	.1829	.1829
14	.1829	.1829	.0914	.1829	.1829	.1829	.0914
15	.0914		.1829	.1829	.1829	.1829	.0914
16	.1829	.1829	.1829	.1829	.1829	.2743	.0914
17	.2743	.2743	.2743	.2743	.2743	.3658	.1829
18	.4572	.3658	.4572	.3658	.3658	.3658	.3658
19	.5487	.4572	.5487	.5487	.4572	.4572	.4572
20	.3658	.3658	.4572	.3658	.3658	.3658	.4572
21	.2743	.3658	.3658	.2743	.2743	.3658	.3658
22	.1829	.2743	.2743	.1829	.1829	.2743	.3658
23	.1829	.1829	.1829	.1829	.1829	.2743	.2743
24	.1829	.1829	.1829	.1829	.1829	.1829	.1829
Max	.7316	.6401	.5487	.5487	.4572	.4572	.4572
Min	.0914	.1829	.0914	.1829	.1829	.0183	.0914
Avg	.3499	.3181	.3022	.3061	.2704	.2703	.2667

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-DEC-17 and 28-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134089 / Bhatepuri

Feeder No / Name : 202 / WADIWAI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-DEC-17	23-DEC-17	24-DEC-17	25-DEC-17	26-DEC-17	27-DEC-17	28-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4734	.5716	.423				
2	.5487	.643	.423				
3	.6173	.7859	.4934				
4		.643	.5639				
5		.7145	.5639				
6		.7145	.5639				
7		1.0717	.9164				
8		1.0717	.9164				
10					.7859		.744
11							.8916
12					1.2146		.9736
13				.9869	1.286	1.1431	1.0431
14				1.2689	1.2146	1.286	1.0431
15				1.2689	1.2146	1.286	.9736
16				1.2689	1.0717	1.2146	.5563
17				.6344	1.0717	1.1431	.7754
23	.4287	.3525					
24	.4058	.5716	.423				
Max	.6173	1.0717	.9164	1.2689	1.286	1.286	1.0431
Min	.4058	.3525	.423	.6344	.7859	1.1431	.5563
Avg	.4948	.714	.5874	1.0856	1.1227	1.2146	.8751