

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

ARVI URBAN S/DN[378] BU 1848

Substation No/ Name :- 294002 / 33 KV ROHANA

Feeder No / Name : 201 / 11 KV ROHONA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2474	.1905	.1903	.1708
2	.2474	.1905	.1691	.1703
3	.2284	.1901	.1248	.1701
4	.2284	.1901	.1704	.1701
5	.1591	.1396	.1385	.1892
6	.1762	.1768	.1738	.2079
7	.2039	.1848	.2698	.2279
8	.1971	.2337	.2643	.1987
9	.2371	.2652	.3262	.2623
10	.1823	.2637	.3243	.3266
11	.2268	.2081	.2447	.3052
12	.2068	.2087	.1708	.257
13	.1896	.2068	.2075	.2518
14	.1894	.1684	.2585	.2254
15	.2427	.1884	.1884	
16	.1898	.1892	.1884	.188
17	.2254	.2257	.1699	.2077
18	.381	.3807	.3609	.3239
19	.4191	.3997	.4382	.4191
20	.4373	.4187	.4382	.4191
21	.381	.3807	.4001	.3997
22	.2858	.3045	.3048	.2855
23	.2096	.2282	.2282	.2094
24	.2474	.1905	.1903	.1899
Max	.4373	.4187	.4382	.4191
Min	.1591	.1396	.1248	.1701
Avg	.2475	.2385	.2475	.2511

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

ARVI URBAN S/DN[378] BU 1848

Substation No/ Name :- 294002 / 33 KV ROHANA

Feeder No / Name : 202 / 11 KV DIGHI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1694	.1314	.1328	.127
2	.1694	.13	.1139	.1275
3	.1497	.1299	.1139	.1279
4	.1509	.111	.1291	.1268
5	.26	.213	.1941	.1271
6	.3095	.2652	.2339	.1465
7	.3221	.3341	.2615	.151
8	.2852	.3545	.2795	.2561
9	.2604	.3527	.43	.3772
10	.2614	.3444	.3703	.427
11	.1137	.0952	.1143	.4652
12	.1326	.095	.0953	.447
13	.1328	.0947	.0939	.4115
14	.1331	.0952	.0939	.3944
15	.1137	.1142	.0947	
16	.1142	.0952	.1141	.0953
17	.1135	.114	.114	.131
18	.2477	.2665	.2477	.2089
19	.3039	.2855	.3048	.3048
20	.3048	.3236	.3239	.3239
21	.2659	.2855	.2858	.2665
22	.1884	.1903	.1894	.1892
23	.1494	.1498	.1503	.1498
24	.1694	.1307	.1298	.1306
Max	.3221	.3545	.43	.4652
Min	.1135	.0947	.0939	.0953
Avg	.2009	.1959	.1921	.2397

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

ARVI URBAN S/DN[378] BU 1848

Substation No/ Name :- 294002 / 33 KV ROHANA

Feeder No / Name : 203 / 11 KV BOTHALI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1815	.2241	.1315	.1699
2	.1815	.1867	.1123	.1163
3	.1582	.1867	.1123	.1099
4	.1555	.1877	.1271	.1116
5	.4299	.2911	.2838	.1265
6	.5806	.6428	.3985	.3142
7	.7666	.5694	.7488	.3374
8	.6646	.7179	.7725	.5889
9	.7222	.6697	.8019	.8188
10	.6199	.4744	.6147	.9558
11	.3224	.1178	.3203	.793
12	.3412	.1217	.2911	.8673
13	.32	.1308	.2243	.793
14	.3087	.0989	.3395	.8354
15	.3412	.0886	.3206	.8194
16	.3409	.0866	.3206	.3219
17	.321	.0974	.3206	
18	.5093	.2466	.4744	.4343
19	.5297	.3323	.5503	.5123
20	.4133	.3341	.5509	.3939
21	.4133	.2886	.4658	.4929
22	.3174	.2204	.3354	.4364
23	.2804	.1498	.2969	.3776
24	.1815	.2241	.1326	.2603
Max	.7666	.7179	.8019	.9558
Min	.1555	.0866	.1123	.1099
Avg	.3917	.2787	.3769	.4777

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

ARVI URBAN S/DN[378] BU 1848

Substation No/ Name :- 294002 / 33 KV ROHANA

Feeder No / Name : 205 / Lower Wardha Express
 feeder Feeder KV- 11 /
 OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0321	.0322	.0304	.029
2	.034	.0321	.0304	.0269
3	.034	.0275	.0304	.0268
4	.034	.0269	.0305	.0268
5	.0324	.0305	.0304	.0268
6	.0322	.0303	.0303	.0324
7		.0051		
8		.0059		
9				.0137
10				.0129
11				.0125
12				.0058
13		.0137		.0055
14				.013
16				.0045
17	.0097			.0156
18	.0303	.0304	.0358	.0189
19	.0305	.0304	.0305	.0324
20	.0324	.0302	.0323	.0305
21	.0324	.0304	.0324	.0324
22	.0324	.0304	.0323	.0305
23	.0323	.0304	.0324	.0324
24	.0321	.0324	.0304	.0305
Max	.034	.0324	.0358	.0324
Min	.0097	.0051	.0303	.0045
Avg	.0308	.0262	.0314	.0219

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

ARVI URBAN S/DN[378] BU 1848

Substation No/ Name :- 294023 / 33 KV ARVI S/Stn

Feeder No / Name : 201 / INDUSTRIAL-1 ARVI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9907	.7811	.9717	.6668
2	.9526	.7621	.9717	.6668
3	.9526	.7621	.9717	.6668
4	.9526	.7621	.9717	.6478
5	.9145	.724	.9717	.6859
6	1.0288	.6478	.9526	.7811
7	.9335	.5906	1.0288	.9907
8	1.0669	.743	1.105	.9526
9	1.4861	1.5813	1.6766	.9907
10	1.7528	1.6194	1.9052	1.1431
11	1.6766	1.6004	1.7909	1.2193
12	1.5623	1.6575	1.7909	1.1241
13	1.5242	1.3527	1.448	.9907
14	1.5051	1.4098	1.448	1.0098
15	1.5623	1.6004	1.5051	.8383
16	1.467	1.5813	1.2765	.6668
17	1.5813	1.6956	1.3336	.381
18	1.8671	1.6956	1.5051	.362
19	1.829	1.7909	1.4098	.381
20	1.5813	1.6194	1.467	.4191
21	1.2955	1.2765	1.2384	.4001
22	1.6004	1.0288	1.1622	.3429
23	.8002	.8383	.6668	.3429
24	.9907	.7811	.8002	.6668
Max	1.8671	1.7909	1.9052	1.2193
Min	.8002	.5906	.6668	.3429
Avg	1.3281	1.2042	1.2654	.7224

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

ARVI URBAN S/DN[378] BU 1848

Substation No/ Name :- 294023 / 33 KV ARVI S/Stn

Feeder No / Name : 202 / 11 KV KHUBGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.1905		.1905
2	.2096	.1905	.1905	.1905
3	.2096	.1905	.1905	.1715
4	.2096	.1905	.1905	.1715
5	.1905	.1715	.1715	.1524
6	.1905	.1905	.1715	.1715
7	.2096	.1905	.1524	.1905
8	.2286	.2286	.2096	.1905
9	.2286	.2667	.3048	.2096
10	.2667	.2667	.2667	.1715
11	.2286	.2286	.2477	.1905
12	.2096	.2286	.2096	.1524
13	.2096	.2286	.2477	.1905
14	.1905	.2477	.1905	.1905
15	.1905	.2477	.1715	.1905
16	.1905	.2286	.1905	.1524
17	.1905	.2477	.1905	.2477
18	.3048	.3429	.3239	.2477
19	.3429	.362	.362	.3048
20	.3239	.3239	.3239	.3429
21	.2667	.2667	.2858	.2286
22	.2286	.2096	.2286	.1524
23	.2096	.1905	.1905	.1524
24	.2096	.1905	.1715	.1715
Max	.3429	.362	.362	.3429
Min	.1905	.1715	.1524	.1524
Avg	.2270	.2342	.2253	.1969

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

ARVI URBAN S/DN[378] BU 1848

Substation No/ Name :- 294023 / 33 KV ARVI S/Stn

Feeder No / Name : 401 / 33 KV PARALAM GLOBAL NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3146	1.3146	1.5432	1.4289
2	1.3146	1.3146		1.3146
3	1.3146	1.2003	1.5432	1.3146
4	1.2574	1.1431	1.4289	1.3717
5	1.2574	1.0288	1.4289	1.2574
6	.8002	1.3146	1.3717	.8573
7	.9145	1.2574	1.3146	.3429
8	.9145	.4572	1.0288	.2286
9	1.7718	1.5432	1.3146	.1143
10	1.4289	1.3717	.6859	.2286
11	1.6575	1.4861	.9145	.2286
12	1.6004	1.4861	1.5432	.1715
13	1.6575	1.4861	1.2574	.1715
14	1.6004	.8002	1.1431	.1143
15	1.7147	1.5432	1.1431	.1143
16	1.6004	1.6004	1.5432	.2286
17	1.5432	1.4289	1.2574	.2286
18	.9717	1.3146	1.2003	.2286
19	1.2003	1.5432	1.2574	.1143
20	1.5432	1.4861	1.3146	.1143
21	1.7147	1.5432	1.4289	.0572
22	1.4289	1.6004	1.3717	.1143
23	1.5432	1.4289	1.3146	.0572
24	1.3717	1.3146	1.6004	1.4289
Max	1.7718	1.6004	1.6004	1.4289
Min	.8002	.4572	.6859	.0572
Avg	1.3932	1.3336	1.3022	.4930

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

ARVI URBAN S/DN[378] BU 1848

Substation No/ Name :- 294023 / 33 KV ARVI S/Stn

Feeder No / Name : 402 / 33 KV Incomer_

Feeder KV- 33 / INCOMING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.572	2.2291	2.6863	2.3434
2	2.5149	2.2291	2.6863	2.2291
3	2.5149	2.1148	2.6292	2.2291
4	2.4577	2.0576	2.6292	2.2291
5	2.4006	1.8861	2.6292	2.1719
6	2.0576	2.2291	2.572	1.8861
7	2.1719	2.1148	2.572	1.6004
8	2.2862	1.4861	2.5149	1.4289
9	3.4865	3.3722	3.315	1.3146
10	3.4294	3.2579	2.8578	1.5432
11	3.5437	3.315	2.915	1.6575
12	3.3722	3.3722	3.5437	1.4289
13	3.3722	3.0864	2.9721	1.3717
14	3.315	2.4577	2.8006	1.3146
15	3.4865	3.3722	2.8006	1.1431
16	3.2579	3.4294	3.0293	1.086
17	3.3722	3.4294	2.8578	.8573
18	3.2579	3.4294	3.1436	.8573
19	3.4294	3.7723	3.1436	.8573
20	3.4865	3.5437	3.1436	.9145
21	3.4865	3.1436	3.0293	.8002
22	2.9721	2.915	2.8006	.743
23	2.6292	2.4577	2.2291	.6859
24	2.6292	2.6292	2.6863	2.3434
Max	3.5437	3.7723	3.5437	2.3434
Min	2.0576	1.4861	2.2291	.6859
Avg	2.9793	2.8054	2.8411	1.4599

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

ARVI URBAN S/DN[378] BU 1848

Substation No/ Name :- 294036 / 33 /11 KV SARANGPURI ARVI

Feeder No / Name : 201 / 11 KV TOWN FEEDER Arvi SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5609	.5716	.4557	.4458
2			.5609	.5716	.4557	.4458
3			.5609	.5335	.4207	.4458
4			.5258	.5335	.4207	.4458
5			.5258	.5716	.4207	.4458
6			.5609	.5716	.4908	.4973
7			.6089	.5716	.5258	.5316
8			.6805	.6668	.5609	.583
9			.8383	.7621	.6805	.6687
10			.8002	.7202	.7164	.8002
11			.724	.6173	.6268	.8002
12			.6478	.5487	.567	.6668
13			.6097	.5658	.5258	.6478
14			.6097	.5487	.5258	.6097
15	.5487		.6097	.5316	.4908	.6097
16			.5716	.5487	.5258	.6097
17			.6097	.5487	.583	.5609
18			.9526	.8745	.8573	.9671
19			1.0479	.9945	.9602	1.0498
20			.9526	.9259	.9602	1.0029
21			.8764	.8238	.7888	.8596
22			.7621	.6805	.6516	.7164
23		.6447	.6097	.5258	.5487	.5258
24			.5609	.6097	.4557	.4801
Max	.5487	.6447	1.0479	.9945	.9602	1.0498
Min	.5487	.6447	.5258	.5258	.4207	.4458
Avg	.5487	.6447	.6820	.6424	.5923	.6423

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

ARVI URBAN S/DN[378] BU 1848

Substation No/ Name :- 294036 / 33 /11 KV SARANGPURI ARVI

Feeder No / Name : 202 / 11 KV TALEGAON FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2526	.2667	.2462	.2591
2		.2526	.2667	.2462	.2439
3		.2526	.2667	.2317	.2439
4		.2378	.2858	.2317	.2439
5		.2378	.2858	.2317	.2743
6		.2408	.3048	.2462	.2591
7		.3353	.381	.2896	.3201
8		.5182	.5716	.3864	.442
9		.9907	.7621	.6097	.6554
10		1.2955	.8078	.8381	1.0479
11		1.2384	.8993	.8697	1.2193
12		1.105	.6554	.9172	1.2193
13		1.2955	.9907	1.1043	1.1812
14		1.2384	.945	1.1043	1.0479
15			1.0364	1.1984	1.1812
16		1.3336	1.0669	1.1043	1.1431
17		1.2193	.884	1.0059	.8642
18		.7621	.5182	.5944	.578
19		.6478	.4572	.503	.5312
20		.5716	.4268	.4572	.3963
21		.4954	.3269	.381	.2972
22		.3429	.2972	.3201	.2824
23	.2675	.3048	.2675	.3048	.2494
24		.2526	.3048	.2526	.2743
Max	.2675	1.3336	1.0669	1.1984	1.2193
Min	.2675	.2378	.2667	.2317	.2439
Avg	.2675	.6705	.5531	.5698	.6023

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

ARVI URBAN S/DN[378] BU 1848

Substation No/ Name :- 294036 / 33 /11 KV SARANGPURI ARVI

Feeder No / Name : 203 / 11 KV INDUSTRIAL FEEDER SHEDDABLE URBAN
ARVI Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8507	.8383	.6697	.7202
2		.8507	.8383	.6878	.7202
3		.8326	.8002	.724	.7202
4		.8326	.8002	.724	.7545
5		.8507	.8383	.7783	.7888
6		.8869	.9145	.8688	.7373
7		1.0242	.9526	.9877	.8402
8		1.1888	1.0288	.9877	1.0288
9		1.1812	1.105	1.1706	1.2346
10		1.2955	.9774	1.1888	1.1431
11		1.105	.9774	.9877	1.1812
12		1.0669	.8916	1.0317	1.0669
13		.9526	.823	1.0317	1.105
14		.9145	.9602	.9412	1.0669
15		.9145	.8745		.9907
16		1.0669	.8745	.9412	.9526
17		1.0479	.9088	.9602	.8145
18		1.2384	1.1145	1.166	.8688
19		1.2384	1.166	1.2003	.9511
20		1.2193	1.0974	1.166	.9145
21		1.1431	1.0425	1.0631	.9694
22		.9526	.924	.9431	.8688
23	.9511	.8383	.9055	.8573	.7964
24		.8688	.8383	.8326	.7545
Max	.9511	1.2955	1.166	1.2003	1.2346
Min	.9511	.8326	.8002	.6697	.7202
Avg	.9511	1.0150	.9372	.9526	.9162

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

ARVI URBAN S/DN[378] BU 1848

Substation No/ Name :- 294036 / 33 /11 KV SARANGPURI ARVI

Feeder No / Name : 204 / 11 KV WATHODA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3185	.3048	.2538	.3048
2		.3185	.3048	.2538	.3048
3		.2896	.3048	.2538	.3048
4		.2896	.2667	.2538	.3048
5		.2896	.2667	.2538	.3353
6		.2896	.3048	.2256	.3353
7		.3567	.1905	.2858	.3658
8		.5647	.1905	.3765	.4572
9		1.1431	.1524	.6241	.7011
10		1.2574	.0914	.9214	1.1431
11		1.4098		1.1561	1.3336
12		1.2193	.945	1.1843	1.4098
13		.7621	.9145	1.2163	1.3336
14		1.3717	1.2498	1.2483	1.3336
15		1.3336	1.2193	1.2308	1.1812
16		1.0669	1.2803	1.2163	.8573
17		1.2955	1.2193	1.0974	.6562
18		.8002	.7011	.6859	.5182
19		.7621	.5792	.5335	.4268
20		.5716	.5182	.5182	.3567
21		.4572	.3765	.4268	.3185
22		.381	.3144	.3963	.2896
23	.3185	.3429	.2858	.3658	.2317
24		.3185	.3048	.2858	.3353
Max	.3185	1.4098	1.2803	1.2483	1.4098
Min	.3185	.2896	.0914	.2256	.2317
Avg	.3185	.7171	.5342	.6360	.6308

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

ARVI URBAN S/DN[378] BU 1848

Substation No/ Name :- 294036 / 33 /11 KV SARANGPURI ARVI

Feeder No / Name : 205 / 11 KV Sawalapur Gaothan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1109	.1143	.1109	.1029
2		.1109	.0953	.1109	.1029
3		.0924	.0953	.1109	.1029
4		.0924	.0953	.1109	.1029
5		.0924	.1143	.1109	.12
6		.1109	.1334	.1109	.12
7		.0739	.1524	.1109	.1029
8		.1663	.1524	.0924	.1029
9		.1715	.0762	.1663	.1029
10		.1524	.0857	.1109	.1143
11		.1905	.0857	.0739	
12		.1143	.1029	.0924	.0762
13		.1524	.0857	.1294	.0953
14		.1715	.0857	.0739	.0953
15		.1524	.0857	.1848	.0762
16			.0857	.1109	.0762
17			.0343	.1543	.0739
18		.1143	.1029	.1543	.0924
19		.1334	.1029	.1543	.0924
20		.1334	.12	.12	.1109
21		.1524	.1109	.1543	.1109
22		.1715	.1109	.0857	.1109
23	.0924	.1334	.1109	.1029	.1109
24		.1109	.1143	.1109	.1029
Max	.0924	.1905	.1524	.1848	.12
Min	.0924	.0739	.0343	.0739	.0739
Avg	.0924	.1320	.1022	.1187	.1

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

ARVI URBAN S/DN[378] BU 1848

Substation No/ Name :- 294038 / 33/11 KV Deurwada

Feeder No / Name : 201 / 11 KV SHIRPUR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3022	.1939	.2352	.2778
2	.3161	.1941	.2182	.246
3	.3129	.1955	.2185	.2454
4	.3201	.1802	.209	.2454
5	.3285	.1823	.2429	.2472
6	.3521	.2385	.2689	.3273
7	.3606	.2905	.3341	.3941
8	.5344	.3859	.5024	.503
9	.8133	.7262	.7423	.7167
10	.9938	.9541	.946	.9362
11	1.0727	1.0217	.9842	1.0084
12	1.0963	1.0142	.822	
13	1.0649	.9473	.9202	1.0023
14	1.0301	.7225	.9472	.983
15	1.0468	.9794	.9521	.9518
16	1.0649	.984	.9718	.873
17	.971	.8813	.9116	.8391
18	.7347	.7531	.8735	.7467
19	.7218	.7305	.7656	.7243
20	.5892	.5921	.6882	.5668
21	.4444	.4534	.52	.4752
22	.2932	.3037	.4006	.3813
23	.2257	.2352	.3163	.2976
24	.3018	.2098	.2355	.2795
Max	1.0963	1.0217	.9842	1.0084
Min	.2257	.1802	.209	.2454
Avg	.6371	.5571	.5928	.5769

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

ARVI URBAN S/DN[378] BU 1848

Substation No/ Name :- 294038 / 33/11 KV Deurwada

Feeder No / Name : 202 / 11 KV DEURWADA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4161	.3349	.3745	.3772
2	.3977	.3349	.3786	.3768
3	.3963	.3353	.3749	.3768
4	.3977	.3193	.3668	.3781
5	.401	.3239	.3733	.3772
6	.3839	.3315	.3626	.3747
7	.4136	.3602	.3754	.422
8	.525	.4727	.4126	.4364
9	.5754	.4973	.447	.4406
10	.7888	.5792	.5357	.6059
11	.7471	.8159	.695	.6417
12	.8064	.7896	.7151	.7975
13	.8219	.6958	.8289	.6959
14	.8025	.6775	.833	.6884
15	.8374	.6959	.8007	.6265
16	.8026	.6644	.8226	.596
17	.5508	.6799	.6581	.5759
18	.559	.59	.6074	.5748
19	.5995	.5905	.6176	.5533
20	.5298	.5073	.5432	.5018
21	.4163	.4139	.425	.3843
22	.296	.3385	.425	.3153
23	.2753	.3041	.4049	.2918
24	.4166	.3377	.3818	.3795
Max	.8374	.8159	.833	.7975
Min	.2753	.3041	.3626	.2918
Avg	.5482	.4996	.5317	.4912

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

ASHTI SUB DN[377]

BU 4377

Substation No/ Name :- 294001 / 33KV ASHTI

Feeder No / Name : 201 / 11 KV ASHTI FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3982	.3142	.3142	.3258
2	.3801	.3142	.2957	.3224
3	.362	.3142	.2957	.3077
4	.362	.2957	.2957	.3077
5	.4024	.3142	.3326	.3258
6	.4207	.3511	.3696	.3721
7	.499	.4251	.4435	.4075
8	.5249	.4706	.4938	.4961
9	.5973	.463	.5249	.5258
10	.5792	.5426	.5249	.5784
11	.6154		.5611	.5596
12	.5316		.5373	.4917
13	.5552	.6001	.567	.4694
14	.4887	.5533	.4887	.431
15	.5068	.5197	.5014	.4191
16	.4887	.5182	.4835	.4475
17	.5201	.4915	.5249	.463
18	.6268	.6335	.6626	.6154
19	.6697	.6516	.6878	.6401
20	.6154	.6154	.6401	.5853
21	.5487	.5487	.5373	.5304
22	.5121	.462	.4344	.4207
23	.3475	.3696	.362	.3475
24	.3982	.3326	.3142	.3224
Max	.6697	.6516	.6878	.6401
Min	.3475	.2957	.2957	.3077
Avg	.4979	.4591	.4664	.4464

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

ASHTI SUB DN[377]

BU 4377

Substation No/ Name :- 294001 / 33KV ASHTI

Feeder No / Name : 202 / 11 kV Antora

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5		.0572	.0572	.0686
6		.0857	.0714	.0857
7		.104	.104	.1
8		.1128	.1303	.104
9	.1326	.1286	.1635	.1174
10	.1492	.1269	.1429	.1174
Max	.1492	.1286	.1635	.1174
Min	.1326	.0572	.0572	.0686
Avg	.1409	.1025	.1116	.0989

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

ASHTI SUB DN[377]

BU 4377

Substation No/ Name :- 294001 / 33KV ASHTI

Feeder No / Name : 203 / 11 kV Sarwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2402	.1886	.1698	.1848
2	.2218	.1698	.1698	.1848
3	.1829	.1698	.1698	.1629
4	.2012	.1698	.1698	.1663
5	.5304	.4858	.421	.4973
6	.5801	.5344	.4858	.5304
7	.7293	.6882	.6964	.583
8	.6081	.6642	.8802	.639
9	.663	.8749	.7127	.8223
10	.7343	.7499	.7625	.7274
11	.1478	.1448	.168	.1267
12	.168		.1294	.1433
13	.1494	.128	.1294	.1294
14	.1294	.1509	.1494	.128
15	.1478	.1494	.1463	.1307
16	.1494	.1307	.1307	.1267
17	.1267	.1307	.1294	.1433
18	.3547	.3584	.3174	.3734
19	.4481	.4527	.4572	.4481
20	.4527	.4715	.4481	.4527
21	.3772	.3772	.3696	.415
22	.3395	.2829	.2957	.2772
23	.2075	.2263	.2402	.1991
24	.2402	.1886	.1886	.1823
Max	.7343	.8749	.8802	.8223
Min	.1267	.128	.1294	.1267
Avg	.3387	.3429	.3307	.3239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

ASHTI SUB DN[377]

BU 4377

Substation No/ Name :- 294001 / 33KV ASHTI

Feeder No / Name : 204 / 11KV KHADKI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.2263	.2452	.2378
2	.2987	.2263	.2263	.2218
3	.2614	.2263	.2263	.2195
4	.2614	.2263	.2263	.2218
5	1.0802	1.0212	.945	1.0513
6	1.142	1.0669	1.0059	1.094
7	1.2346	1.2498	1.1294	1.1437
8	1.2654	1.1589	1.3523	1.166
9	1.2793	1.2929	1.4575	1.4148
10	1.4255	1.1589	1.4706	1.2191
11	.1867	.1886	.2054	.1886
12	.1698		.2054	.1886
13	.168	.1905	.1886	.1698
14	.2054	.1886	.1848	.1886
15	.1867	.2075	.1991	.2075
16	.2012	.2096	.1848	.1886
17	.1886	.2263	.2033	.2075
18	.4904	.4527	.4481	.4763
19	.547	.5658	.5544	.5716
20	.547	.547	.5359	.5525
21	.4527	.4527	.439	.4954
22	.3961	.3206	.3326	.3584
23	.2641	.2641	.3142	.2587
24	.2801	.2452	.2452	.2587
Max	1.4255	1.2929	1.4706	1.4148
Min	.168	.1886	.1848	.1698
Avg	.5339	.5180	.5219	.5125

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

ASHTI SUB DN[377]

BU 4377

Substation No/ Name :- 294006 / 33KV SAHUR

Feeder No / Name : 201 / 11KV SAHUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2096	.2286	.2286
2	.2286	.2096	.2286	.2286
3	.2286	.2096	.2286	.2286
4	.2286	.2096	.2286	.2286
5	.2667	.2096	.2286	.5853
6	.2667	.2096	.2286	.5853
7	.2286	.2286	.2477	.695
8	.2286	.2477	.2096	
9	.2286	.2667	.1905	.9231
10	.2286	.1905	.1905	.8421
11	.9393	1.1041	.9014	.1905
12	.9555		.9282	.1905
13	1.004	1.1104	.9442	.1524
14	1.0202	1.0288	.9717	.1524
15	.8745	1.0395	.9122	.1524
16	.9995	1.0341	.8583	.1905
17	1.0202	.8583	.8907	.1524
18	.8907	.7125	.8122	.4191
19	.5525	.5716	.5335	.4572
20	.5144	.5335	.5335	.4954
21	.4572	.4572	.4572	.4382
22	.3048	.3429	.2286	.3239
23	.2667	.2667	.2286	.2667
24	.2667	.2096	.2286	.2286
Max	1.0202	1.1104	.9717	.9231
Min	.2286	.1905	.1905	.1524
Avg	.5179	.4983	.4850	.3633

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

ASHTI SUB DN[377]

BU 4377

Substation No/ Name :- 294006 / 33KV SAHUR

Feeder No / Name : 203 / 11KV WADALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1143	.0953	.1143	.1143
2		.1143	.0953	.1143	.1143
3		.1143	.0953	.1143	.1143
4		.1143	.0953	.1143	.1143
5		.1334	.0953	.1143	.8962
6		.1334	.0953	.1143	.9511
7		.1143	.1143	.1334	1.0608
8		.1143	.1334	.0953	
9		.1143	.1334	.1334	1.0936
10		.1143	.0953	.1143	1.1561
11	.0762	.9393	1.1946	1.1717	.0953
12		1.2955		1.2492	.0953
13		1.3117	1.2894	1.3916	.0953
14		1.3765	1.2574	1.3125	.0953
15		1.2793	1.278	1.3441	.0953
16		1.2793	1.2689	1.2492	.0953
17		1.1984	1.2631	1.2018	.1143
18		1.004	1.0202	1.0688	.2286
19		.3048	.3239	.2858	.2858
20		.3048	.2858	.2858	.2858
21		.2286	.2286	.2286	.2286
22		.1524	.1715	.2286	.1715
23		.1334	.1334	.1143	.1334
24		.1334	.0953	.1143	.1143
Max	.0762	1.3765	1.2894	1.3916	1.1561
Min	.0762	.1143	.0953	.0953	.0953
Avg	.0762	.5051	.4721	.5170	.3369

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

ASHTI SUB DN[377]

BU 4377

Substation No/ Name :- 294006 / 33KV SAHUR

Feeder No / Name : 204 / 11KV MANIKWADA+DHADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1715	.1905
2	.1905	.1905	.1715	.1905
3	.1905	.1905	.1715	.1905
4	.1905	.1905	.1715	.1905
5	1.1827	1.0526	1.1336	.1905
6	1.1827	1.2146	1.2146	.1905
7	1.6827	1.4575	1.5384	.1905
8	1.9022	1.8461	2.0081	
9	1.7814	2.2291	2.4646	.1905
10	1.7004	2.1948	2.2405	.1905
11	.1905	.1905	.1905	2.1285
12	.1334		.1905	2.2965
13	.1334	.1524	.1524	2.5206
14	.1334	.1524	.1524	2.4272
15	.1334	.1524	.1715	2.4646
16	.1524	.1524	.1524	2.2405
17	.1524	.1524	.1524	1.587
18	.381	.2858	.2667	1.531
19	.4572	.4572	.4572	.4001
20	.4382	.4191	.4572	.4382
21	.3429	.3429	.381	.381
22	.2286	.2477	.1905	.2667
23	.2096	.1905	.1905	.2286
24	.2286	.1905	.1715	.1905
Max	1.9022	2.2291	2.4646	2.5206
Min	.1334	.1524	.1524	.1905
Avg	.5629	.6019	.6068	.9050

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

ASHTI SUB DN[377]

BU 4377

Substation No/ Name :- 294039 / 33 KV ANTORA S/STN

Feeder No / Name : 201 / 11 KV ANTORA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1143	.0953	.0848
2	.1143	.1143	.0953	.0848
3	.1143	.1143	.0953	.0848
4	.1143	.1143	.0762	.0848
5	.1143	.0953	.0953	.0848
6	.1143	.1143	.1143	.0848
7	.1143	.1143	.1143	.1017
8	.3048	.3048	.3239	.3052
9	.407	.3222	.362	.4572
10	.39	.3561	.4572	.4191
11	.39	.39	.381	.4001
12	.373	.407	.4572	.4191
13	.407	.373	.4954	.4001
14	.4239	.373	.4382	.4001
15	.407	.373	.4572	.381
16	.0762		.1187	.0953
17	.0953		.1187	.0953
18	.1715	.2096	.1865	.2096
19	.2286	.2477	.2374	.2477
20	.2286	.2477	.2204	.2477
21	.1905	.2286	.1865	.2286
22	.1334	.1524	.1526	.1524
23	.0953	.1143	.0848	.1143
24	.1334	.0953	.0953	.0848
Max	.4239	.407	.4954	.4572
Min	.0762	.0953	.0762	.0848
Avg	.2190	.2262	.2275	.2195

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

ASHTI SUB DN[377]

BU 4377

Substation No/ Name :- 294039 / 33 KV ANTORA S/STN

Feeder No / Name : 202 / 11 KV L.ARVI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1334	.1357
2	.1715	.1715	.1143	.1357
3	.1715	.1524	.1143	.1187
4	.1715	.1334	.1143	.1187
5	.1524	.1334	.1143	.1187
6	.1905	.1334	.1524	.1187
7	.1905	.1524	.1715	.1187
8	.5335	.5906	.5335	.4578
9	.6613	.7122	.6478	.7621
10	.6783	.6783	.7811	.7811
11	.6783	.763	.6478	.8002
12	.78	.78	.743	.8002
13	.78	.763	.7621	.7811
14	.763	.7291	.7811	.7621
15	.7122	.7291	.8002	.724
16	.1334		.0848	.1143
17	.1143		.1017	.0953
18	.2667	.2858	.2374	.2667
19	.3429	.3429	.2713	.3239
20	.3429	.3429	.2883	.3048
21	.3048	.3048	.2713	.2858
22	.2096	.2096	.2035	.2286
23	.1715	.1715	.1526	.1715
24	.1715	.1715	.1715	.1526
Max	.78	.78	.8002	.8002
Min	.1143	.1334	.0848	.0953
Avg	.3693	.3919	.3497	.3615

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

ASHTI SUB DN[377]

BU 4377

Substation No/ Name :- 294039 / 33 KV ANTORA S/STN

Feeder No / Name : 203 / 11 KV BELORA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1715	.1492
2	.1715	.1715	.1524	.1492
3	.1715	.1715	.1524	.1492
4	.1715	.1524	.1715	.1492
5	.1715	.1524	.1715	.1492
6	.1715	.1715	.1715	.1326
7	.1715	.1715	.1715	.1326
8	.6668	.724	.6287	.4973
9	.6962	.7625	.7621	.743
10	.8619	.8785	.8192	.8383
11		.8288	.7621	.8764
12	.8619	.8453	.8573	.7621
13	.8453	.7956	.8764	.8573
14	.8619	.8139	.8383	.8383
15	.8785	.7459	.8383	.8383
16	.0953		.0829	.0953
17	.0953		.0995	.0953
18	.2858	.3048	.2321	.3048
19	.362	.4191	.2984	.3429
20	.362	.3429	.3149	.3429
21	.3048	.3048	.2818	.3239
22	.2096	.2286	.1989	.2286
23	.1715	.1715	.1492	.1715
24	.1715	.1715	.1524	.1492
Max	.8785	.8785	.8764	.8764
Min	.0953	.1524	.0829	.0953
Avg	.3883	.4318	.3898	.3882

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

ASHTI SUB DN[377]

BU 4377

Substation No/ Name :- 297004 / 132 KV TALEGAON

Feeder No / Name : 402 / 33 KV Karanja

Feeder KV- 33 / INCOMING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.9717	.9717	1.0288	.9717	.9145	.8002	.9717
Max	.9717	.9717	1.0288	.9717	.9145	.8002	.9717
Min	.9717	.9717	1.0288	.9717	.9145	.8002	.9717
Avg	.9717	.9717	1.0288	.9717	.9145	.8002	.9717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

ASHTI SUB DN[377]

BU 4377

Substation No/ Name :- 297004 / 132 KV TALEGAON

Feeder No / Name : 405 / 33 KV Nara

Feeder KV- 33 / INCOMING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.8573	.6859	.743	.6859	.6287	.743	.5716
Max	.8573	.6859	.743	.6859	.6287	.743	.5716
Min	.8573	.6859	.743	.6859	.6287	.743	.5716
Avg	.8573	.6859	.743	.6859	.6287	.743	.5716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

KARANJA SUB DN[379] BU 4379

Substation No/ Name :- 294003 / 33 KV KARANJA

Feeder No / Name : 201 / 11 kV Karanja

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2515	.3045	.3326	.3206
2		.3669	.2858	.3326	.3206
3		.3497	.2858	.2957	.3206
4		.3486	.3048	.2926	.3206
5		.3426	.2667	.3142	.3395
6		.3841	.2858	.3658	.3772
7		.4572	.3239	.3658	.3961
8		.5487	.4572	.5121	.6878
9		.7865	.788	.8596	.7522
10		.7577	.8326	.8048	.7522
11		.7577	.6516	.7682	.6447
12		.7682	.4706	.7207	.5194
13		.695	.543	.6653	.5731
14		.695	.6335	.695	.6626
15		.695	.7059	.7316	.6984
16		.5121	.7421	.7499	.6089
17		.7164	.7316	.7602	.7343
18		.8238	.8048	.8145	.743
19		.7621	.8589	.8145	.7202
20		.7811	.8048	.8145	.7964
21		.6097	.7865	.6697	.4763
22		.4001	.4755	.5068	.381
23	.4403	.3048	.3475	.3584	.3772
24		.3853	.3048	.3326	.3206
Max	.4403	.8238	.8589	.8596	.7964
Min	.4403	.2515	.2667	.2926	.3206
Avg	.4403	.5625	.5415	.5782	.5351

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

KARANJA SUB DN[379]

BU 4379

Substation No/ Name :- 294003 / 33 KV KARANJA

Feeder No / Name : 202 / 11 KV JUNAPANI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0532	.0381	.0509	.0377
2		.0549	.0381	.0509	.0377
3		.055	.0381	.0339	.0377
4		.0549	.0381	.0339	.0377
5		.3048	.2401	.0339	.0377
6		.3048	.3429	.0339	.0377
7		.4359	.4115	.0509	.0377
8		.5668	.5487	.2883	.362
9		.6733	.5487	.407	.4801
10		.5609	.4024	.5609	.4458
11		.0509	.0754	.5258	.4115
12		.0339	.0754	.4557	.4115
13		.0339	.0754	.4557	.4115
14		.0509	.0377	.4557	.4115
15		.0509	.0377	.4207	.4115
16		.0509	.0377	.0343	.0381
17		.0381	.0339	.0754	.0381
18		.1143	.1017	.1132	.0953
19		.1334	.1372	.1132	.1334
20		.1334	.1187	.132	.1334
21		.1143	.1017	.1132	.1143
22		.0762	.0678	.0943	.0762
23	.0734	.0572	.0509	.0754	.0754
24		.0572	.0381	.0509	.0377
Max	.0734	.6733	.5487	.5609	.4801
Min	.0734	.0339	.0339	.0339	.0377
Avg	.0734	.1692	.1515	.1942	.1813

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

KARANJA SUB DN[379] BU 4379

Substation No/ Name :- 294003 / 33 KV KARANJA

Feeder No / Name : 203 / 11 KV DABHA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0381		.0187	.0377
2		.0366		.0187	.0189
3		.019		.0187	.0189
4		.0183		.0187	
5		.0183		.0187	
6		.0377		.0187	
7		.0366	.0191	.0187	
8		.0366	.0381	.0373	.0189
9		.0373	.0381	.0373	.0572
10		.0373	.0189	.0373	.0381
11		.056	.0377	.0373	.0381
12		.0373	.0377	.0373	.0572
13		.0509	.0189	.0373	.0572
14		.0509	.0377	.0373	.0381
15		.056	.0189	.0373	.0381
16		.0373	.0189	.0373	.0381
17		.0381	.8402	.0189	.0381
18		.0381	.0373	.0189	.0381
19		.0381	.0373	.0377	.0381
20		.0381	.0373	.0377	.0381
21		.0381	.0373	.0377	.0381
22		.0381	.0373	.0377	.0381
23	.0366	.0381	.0373	.0377	
24		.0367	.0191	.0187	.0377
Max	.0366	.056	.8402	.0377	.0572
Min	.0366	.0183	.0189	.0187	.0189
Avg	.0366	.0378	.0760	.0297	.0380

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

KARANJA SUB DN[379] BU 4379

Substation No/ Name :- 294003 / 33 KV KARANJA

Feeder No / Name : 205 / 11 KV NARA WW FEEDER
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.0655	.0838
2		.0655	.0838
3		.0983	.0838
4		.0983	.0943
5		.0983	.0838
6		.0995	.0838
7		.0995	.0838
8		.0995	.1006
9		.1492	.12
10		.1492	.1029
11		.1492	.0686
12		.0829	.12
13		.0829	.1254
14			.1372
15			.12
16			.1334
17		.0838	.1334
18		.0838	.0953
19	.0983	.0838	.1143
20	.0995	.0838	.1334
21	.116	.0838	.1143
22	.0983	.0838	.1143
23	.0663	.0838	
24		.0655	.0838
Max	.116	.1492	.1372
Min	.0663	.0655	.0686
Avg	.0957	.0948	.1050

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

KARANJA SUB DN[379]

BU 4379

Substation No/ Name :- 294003 / 33 KV KARANJA

Feeder No / Name : 206 / 11 KV ORIENTAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0943	.0762	.0924	.0943
2		.092	.0762	.0924	.0943
3		.092	.0762	.0739	.0754
4		.0917	.0572	.0739	.0754
5		.0917	.0762	.0739	.0754
6		.0848	.0762	.0739	.0754
7		.0629	.0762	.0739	.0754
8		.1284	.1143	.1109	.1132
9		.2402	.1334	.1478	.1524
10		.2801	.1509	.1307	.2858
11		.2987	.1509	.1867	.1334
12		.2427	.132	.2427	.2667
13		.2801	.132	.2614	.2667
14		.2801	.132	.2614	.3048
15		.3174	.132	.2614	.2667
16		.3174	.1509	.3142	.2477
17		.2667	.1494	.3018	.2667
18		.2667	.168	.2829	.3429
19		.1524	.1494	.2263	.1524
20		.1334	.1494	.1698	.1334
21		.1334	.1494	.1509	.1143
22		.1143	.112	.132	.0953
23	.1097	.0953	.0934	.0943	.0943
24		.0917	.0953	.0934	.0943
Max	.1097	.3174	.168	.3142	.3429
Min	.1097	.0629	.0572	.0739	.0754
Avg	.1097	.1770	.1170	.1635	.1624

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

KARANJA SUB DN[379]

BU 4379

Substation No/ Name :- 294003 / 33 KV KARANJA

Feeder No / Name : 207 / 11 KV CHANDEWANI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.0693	.0943
2		.0693	.0943
3		.0693	.0943
4		.0693	.0943
5		.0693	.0754
6		.0693	.0754
7		.0693	.0754
8		1.1789	1.3032
9		1.3176	1.5604
10		1.4506	1.4403
11		1.6301	1.3032
12		1.6655	1.3717
13		1.6476	1.4403
14			1.5089
15			1.3032
16			.0381
17		1.238	.0381
18		.1698	.1905
19	.208	.2075	.1905
20	.1734	.2452	.2286
21	.1734	.1886	.1715
22	.104	.1509	.1334
23	.0693	.0943	
24		.0693	.0943
Max	.208	1.6655	1.5604
Min	.0693	.0693	.0381
Avg	.1456	.559	.5617

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

KARANJA SUB DN[379] BU 4379

Substation No/ Name :- 294003 / 33 KV KARANJA

Feeder No / Name : 208 / 11 KV Yengaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1468	.1334	.1372	.1509
2		.1463	.1334	.1372	.1509
3		.1468	.1334	.1357	.1509
4		.1468	.1334	.12	.1509
5		1.2843	1.0288	.12	.1509
6		1.2308	1.1317	.1372	.1509
7		1.3927	1.3032	.1372	.1509
8		1.7814	1.7147	1.046	1.595
9		1.8625	1.7833	1.8861	1.8176
10		1.576	1.6194	1.9281	1.8519
11		.12	.1132	1.8404	1.7147
12		.1029	.1132	1.7718	1.5089
13		.1029	.1132	1.7718	1.5432
14		.1029	.1132	1.7718	1.6118
15		.1029	.1132	1.7193	1.5089
16		.1029	.1132	.1214	.1143
17		.1143	.1029	.2263	.1143
18		.3429	.2743	.3018	.3048
19		.381	.3772		.4191
20		.381	.3429	.415	.381
21		.3048	.3086	.3395	.3429
22		.2286	.2058	.2452	.2286
23	.1835	.1524	.1372	.1509	.2075
24		.1651	.1334	.1372	.1509
Max	.1835	1.8625	1.7833	1.9281	1.8519
Min	.1835	.1029	.1029	.12	.1143
Avg	.1835	.5175	.4865	.7216	.6863

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

KARANJA SUB DN[379] BU 4379

Substation No/ Name :- 294003 / 33 KV KARANJA

Feeder No / Name : 403 / 33 KV Nara Incomer at 33

Karan Feeder KV- 33 / INCOMING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0974	.6859	.3292	.0189
2		1.1008	.743	.3292	.0189
3		.796	.743	.3018	.0126
4		1.1174	1.4289	1.0151	.0126
5		1.2659	1.4289	1.0974	.0343
6		1.5592	1.7147	1.4283	.056
7		2.2834	4.0009	1.5146	.0766
8		3.3036	4.5725	1.9719	.1063
9		2.3594	4.6868	2.4577	5.2584
10		1.9753	.2515	1.7833	4.9726
11		2.6886	.3464	1.9753	3.7151
12		2.6886	.3875	2.0302	1.5432
13		2.7709	.3229	1.4575	1.5432
14		2.8807	.3201	1.5912	1.5432
15		2.963	.3172	1.7558	3.5437
16		2.8258	.4915	1.7833	4.1152
17		4.6868	2.1674	.0617	2.9721
18		1.0288	1.5912	.0492	2.2862
19		1.1431	.5487	.0914	2.0005
20		.9145	.5213	.072	1.7147
21		.9145	.4664	.1543	1.1431
22		.8573	.4115	.1115	1.1431
23	1.1008	.743	.3292	.0823	.1195
24		1.1008	.6859	.3292	.088
Max	1.1008	4.6868	4.6868	2.4577	5.2584
Min	1.1008	.743	.2515	.0492	.0126
Avg	1.1008	1.8777	1.2151	.9906	1.5849

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

KARANJA SUB DN[379]

BU 4379

Substation No/ Name :- 294008 / 33KV KANMWARGRAM

Feeder No / Name : 201 / 11 KV K'gram AG Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0943	.0754	.0474	.0633
2		.0754	.0754	.0474	.0625
3		.0754	.0754	.0474	.0625
4		.0754	.0754	.0474	.0633
5		.0754	.0754		.427
6		.0754	.0754	.0474	.427
7		.0566	.0754	.0474	.4428
8		.5668	.5182	.4687	.5121
9		.664	.6093	.5506	.5312
10		.6478	.6718	.5992	.5281
11		.664	.6882	.6167	.0377
12		.6478	.5992	.5851	.0377
13		.4534	.5441	.5535	.0377
14		.5182	.639	.5535	.0377
15		.502	.6081	.5535	.0377
16		.0377	.0191	.0377	.0377
17		.0566	.032	.016	.0377
18		.0566	.048	.0633	.0566
19		.0754	.048	.0781	.0754
20		.0754	.064	.08	.0943
21		.0943	.064	.064	.0943
22		.0754	.0474	.0633	.0754
23	.0943	.0754	.048	.064	.0754
24		.0943	.0754	.048	.0633
Max	.0943	.664	.6882	.6167	.5312
Min	.0943	.0377	.0191	.016	.0377
Avg	.0943	.2430	.2438	.2295	.1633

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

KARANJA SUB DN[379]

BU 4379

Substation No/ Name :- 294008 / 33KV KANMWARGRAM

Feeder No / Name : 202 / 11KV SINDVIHARI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0926	.0791	.0791
2	.0686	.0926	.08	.0791
3	.0686	.0926	.08	.0791
4	.0686	.0772	.096	.08
5	.0686	.0772	.0949	.08
6	.0686	.0772	.112	.08
7	.12	.108	.112	.0791
8	.2058	.1852	.192	.128
9	.3086	.2932	.2469	.2721
10	.1543	.2932	.2778	.2623
11	.2469	.3429	.2778	.2623
12	.2778	.3601	.2778	.3086
13	.2932	.3772	.2469	.3549
14	.3704	.3944	.2623	.3395
15	.3704	.3772	.2623	.3395
16	.3704	.1715	.2315	.3549
17	.3858	.3201		.2778
18	.2778	.16	.1739	.216
19	.2006	.1457	.192	.1852
20	.1543	.1423	.144	.1543
21	.1389	.1265	.144	.1389
22	.1235	.096	.128	.1235
23	.0926	.08	.096	.108
24	.0686	.0926	.08	.08
Max	.3858	.3944	.2778	.3549
Min	.0686	.0772	.0791	.0791
Avg	.1905	.1906	.1690	.1859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

KARANJA SUB DN[379]

BU 4379

Substation No/ Name :- 294008 / 33KV KANMWARGRAM

Feeder No / Name : 203 / 11 KV K'gram Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.056	.0354	.0354
2	.0566	.0373	.0354	.0354
3	.0572	.0373	.0354	.0532
4	.0566	.0373	.0532	.0526
5	.0566	.0373	.0532	.0532
6	.0754	.0373	.0532	.0532
7	.056	.0373	.0526	.0354
8	.0566	.056	.0532	.0354
9	.0566	.0373	.056	.0351
10	.0566	.056	.056	.056
11	.056	.0377	.056	.056
12	.056	.0377	.056	.056
13	.0373	.0566	.056	.0747
14	.056	.0566	.0373	.056
15	.056	.0566	.0373	.0373
16	.056	.0377	.056	.056
17	.056	.0351	.0351	.056
18	.056	.0886	.0709	.0747
19	.0747	.0709	.0886	.0754
20	.0747	.0709	.0709	.0754
21	.0747	.0532	.0532	.0747
22	.056	.0351	.0532	.056
23	.056	.0351	.0351	.0377
24	.0566	.056	.0354	.0354
Max	.0754	.0886	.0886	.0754
Min	.0373	.0351	.0351	.0351
Avg	.0586	.0482	.0510	.0528

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

KARANJA SUB DN[379]

BU 4379

Substation No/ Name :- 294008 / 33KV KANMWARGRAM

Feeder No / Name : 204 / 11 KV NANDORA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1612	.1619	.144	.16
2	.1578	.1619	.144	.16
3	.1629	.1619	.144	.16
4	.1578	.1457	.1581	.1581
5	.052	.1457	.1581	.144
6	.1075	.1619	.1739	.16
7	.1886	.2105	.192	.1898
8	.4508	.4534	.3681	.3681
9	.6062	.583	.4858	
10	.4374	.5992	.5344	.4696
11	.5182	.3201	.4858	.4049
12	.5668	.4481	.4372	.421
13	.6154	.4752	.4372	.4534
14	.6964	.5281	.4858	.4858
15	.6802	.664	.502	.5344
16	.6802	.3521	.4858	.5668
17	.6316	.5218	.4481	.502
18	.3239	.253	.2915	.421
19	.2915	.2372	.2241	.2591
20	.2429	.2056	.208	.1619
21	.2267	.192	.192	.1619
22	.1943	.16	.176	.1457
23	.1781	.144	.16	.1296
24	.1492	.1619	.144	.16
Max	.6964	.664	.5344	.5668
Min	.052	.144	.144	.1296
Avg	.3532	.3103	.2992	.2947

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

KARANJA SUB DN[379] BU 4379

Substation No/ Name :- 294008 / 33KV KANMWARGRAM

Feeder No / Name : 205 / 11 KV B Y AGRO EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 FEEDER Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1086	.112	.0886	.1086
2	.0924	.1494	.0886	.1075
3	.0934	.1307	.0886	.1075
4		.112	.0886	.1086
5	.112	.1109	.0886	.1629
6	.112	.1867	.0886	.1448
7	.1494	.2054	.0886	.1075
8	.2241	.1848	.1791	.197
9	.2218	.1109	.2126	.1612
10	.2149	.3189	.2534	.3561
11	.2218	.4207	.3391	.4024
12	.2033	.4024	.3441	.4096
13	.2012	.1433	.3391	.4239
14	.5256	.181	.3521	.3688
15	.5316	.4733	.3856	.3185
16	.4915	.132	.4191	.3856
17	.4801	.1791	.4119	.3429
18	.3511	.1086	.1254	.3077
19	.168	.1086	.2172	.2402
20	.0943	.1267	.1791	.1848
21	.1132	.1448	.1791	.1478
22	.112	.1267	.1433	.1294
23	.1307	.0895	.1433	.1294
24	.132	.112	.0886	.1075
Max	.5316	.4733	.4191	.4239
Min	.0924	.0895	.0886	.1075
Avg	.2211	.1821	.2055	.2275

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

KARANJA SUB DN[379]

BU 4379

Substation No/ Name :- 294026 / 33 KV NARA SUBSTATION

Feeder No / Name : 201 / 11 KV NARA FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.112	.1132	.1132	.0934
2		.112	.1132	.1132	.0934
3		.112	.1132	.1132	.0934
4		.112	.1132	.1132	.0934
5		.2561	.2915	.1132	.0934
6		.253	.3401	.1132	.112
7		.421	.4049	.132	.1307
8		.5182	.6413	.1132	.1494
9		.4321	.5243	.1509	.132
10		.4161	.4096	.132	.1524
11		.1132	.112	.4858	.4161
12		.0943	.0934	.5992	.4938
13		.0943	.0934	.5668	.4687
14		.0943	.0934	.5182	.4374
15		.0953	.0934	.502	.427
16		.0953	.0934		.4218
17		.1132	.0943	.4915	.3725
18		.2452	.2286	.4915	.3041
19		.2829	.2829	.2801	.2829
20		.3018	.2829	.2987	.3018
21		.2452	.2641	.2614	.2641
22	.2614	.1886	.1886	.1867	.2075
23	.1867	.132	.132	.1494	.1698
24		.1307	.1132	.132	.112
Max	.2614	.5182	.6413	.5992	.4938
Min	.1867	.0943	.0934	.1132	.0934
Avg	.2241	.2071	.2179	.2683	.2426

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

KARANJA SUB DN[379]

BU 4379

Substation No/ Name :- 294026 / 33 KV NARA SUBSTATION

Feeder No / Name : 202 / 11 KV WAGHODA FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0934	.0943	.0754	.0747
2		.0934	.0943	.0754	.0747
3		.0934	.0754	.0754	.0747
4		.0934	.0754	.0754	.0747
5		.0934	.0754	1.0814	1.0279
6		.0934	.0943	1.1305	1.0911
7		.112		1.2266	1.186
8		.112	.0943	1.3435	1.2809
9		.1132	.0747	1.4089	1.3927
10		.0943	.0747	1.3279	1.1363
11		1.7604	1.5089	.0754	.0724
12		1.7436	1.6263	.0754	.0366
13		1.6933	1.6766	.0754	.0739
14		1.6598	1.5565	.0754	.0709
15		1.5927	1.5729	.0754	.0732
16		1.7635	1.4419		.0716
17		1.587	1.4089	.0747	.0754
18		1.5384	1.3426	.168	.1698
19		.2075	.2075	.2241	.2075
20		.2263	.2075	.2054	.2263
21		.1698	.1886	.168	.1886
22	.1867	.132	.132	.1307	.132
23	.1307	.0943	.0943	.112	.0943
24		.0934	.0943	.0943	.112
Max	.1867	1.7635	1.6766	1.4089	1.3927
Min	.1307	.0934	.0747	.0747	.0366
Avg	.1587	.6356	.6005	.4076	.3758

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

KARANJA SUB DN[379]

BU 4379

Substation No/ Name :- 294026 / 33 KV NARA SUBSTATION

Feeder No / Name : 203 / 11 KV SAWARDOH FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0934	.0943	.0943	.0934
2		.0934	.0943	.0943	.0934
3		.0934	.0943	.0943	.0934
4		.0934	.0943	.0943	
5		1.3603	.502	.0943	.0934
6		1.3765	.502	.1132	.112
7		1.5844	.5182	.1132	.112
8		1.7764	.6154	.0943	.0934
9		1.8842	.639	.0943	.0943
10		1.749	.5243	.0943	.0895
11		.0701		1.749	1.5813
12		.0914		1.7976	1.8724
13		.0724	.0747	1.7976	1.9271
14		.0924	.0747	1.8138	1.9757
15		.0914	.0747	1.7764	1.8947
16		.0914	.056		1.8785
17		.0943	.0701	1.7652	1.7814
18		.1698	.1509	1.3757	1.4403
19		.1886	.2075	.2054	.1886
20		.2075	.2075	.2054	.2075
21		.1698	.2075	.168	.2075
22	.1867	.132	.132	.1307	.1509
23	.112	.0943	.1132	.112	.0943
24		.112	.0943	.1132	.0934
Max	.1867	1.8842	.639	1.8138	1.9757
Min	.112	.0701	.056	.0943	.0895
Avg	.1494	.4909	.2337	.6083	.7030

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

KARANJA SUB DN[379]

BU 4379

Substation No/ Name :- 294034 / SAWALI (BK)

Feeder No / Name : 201 / 11 KV SARWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2587	.2263	.3429	.2218
2		.2587	.2263	.3048	.2218
3		.2402	.2263	.3048	.2218
4		.2402	.2263	.3048	.2012
5		1.3765	1.5708	.2667	.1991
6		1.5061	1.6194	.2641	.2402
7		1.749	1.668	.2452	.2402
8		2.1052	1.9271	.2075	.2641
9		2.1956	1.8884	.2075	.2452
10		1.9989	1.8185	.2075	.2452
11		.1886	.1698	1.9433	1.9364
12		.1509	.1698	1.9109	2.1214
13		.168	.1698	2.0891	2.0405
14		.1867	.1698	1.9757	2.0165
15		.168	.1698	1.8138	1.8785
16		.168	.1509	1.9757	1.749
17		.3361	.1698	1.6356	1.7004
18		.3921	.3772	1.3603	1.4091
19		.4904	.4527	.4904	.4904
20		.4904	.4904	.4904	.4954
21		.3961	.415	.415	.4382
22		.2829	.4191	.3206	.3239
23	.3018	.2263	.4191	.2402	.3239
24		.2641	.2263	.381	.2218
Max	.3018	2.1956	1.9271	2.0891	2.1214
Min	.3018	.1509	.1509	.2075	.1991
Avg	.3018	.6599	.6403	.8207	.8103

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

KARANJA SUB DN[379] BU 4379

Substation No/ Name :- 294034 / SAWALI (BK)

Feeder No / Name : 202 / 11 KV RAJANI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2218	.2263	.2667	.2033
2		.2218	.2263	.2667	.2033
3		.2218	.2263	.2667	.2033
4		.2218	.2263	.2667	.1991
5		.2218	.2241	1.278	1.1363
6		.2587	.2614	1.3108	1.2483
7		.2587	.2614	1.3765	1.6484
8		.2587	.2427	1.6644	2.1348
9		.2614	.2427	1.9364	2.2455
10		.2614	.2667	1.5779	2.0622
11		2.0241	1.9364	.1867	.1698
12		2.0715	2.119	.1494	
13		2.0622	2.1032	.1307	.1698
14		2.0873	1.9925	.1086	.1698
15		1.9766	1.945	.1294	.1886
16		1.9766	1.8564	.1294	.1886
17		1.8343	1.7166	.1663	.1698
18		1.4548	1.2793	.3881	.4338
19		.5281	.5093	.5281	.5281
20		.5281	.5658	.5281	.5093
21		.4338	.4572	.4527	.4763
22		.3018	.4572	.3206	.362
23	.2829	.2263	.381	.2402	.362
24		.2641	.2263	.3239	.2218
Max	.2829	2.0873	2.119	1.9364	2.2455
Min	.2829	.2218	.2241	.1086	.1698
Avg	.2829	.8407	.8312	.5830	.6624

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

KARANJA SUB DN[379]

BU 4379

Substation No/ Name :- 294034 / SAWALI (BK)

Feeder No / Name : 204 / 11 KV Aarohi

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0747	.0747	
2		.0747	.0747	.056
3		.0747	.0747	.056
4		.0747	.0747	.056
5		.0747		.056
9	.0747	.0747	.0747	.0934
10	.056	.0747	.056	.0747
11	.0747	.0934	.0747	.0747
12	.0747	.0934	.0747	.0747
13	.0747	.0747	.0747	.0747
14	.0747	.0747	.0747	.0934
15	.0934	.0747	.056	.0747
16	.0747	.0747	.056	.0747
17	.0747	.0747		.0747
18	.0056			.0056
19			.0056	.0037
20		.0019		.0187
21	.0747	.0373		.0747
22	.0747	.0747		.0747
23	.0747	.0747		.0747
24		.0747	.0747	
Max	.0934	.0934	.0747	.0934
Min	.0056	.0019	.0056	.0037
Avg	.0694	.0709	.0658	.0624

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

KARANJA SUB DN[379] BU 4379

Substation No/ Name :- 294034 / SAWALI (BK)

Feeder No / Name : 400 / 33 KV Incomer-Sawali
Feeder KV- 33 / INCOMING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.168	.2263	.2858	.1109
2		.168	.2263	.2858	.168
3		.112	.2263	.2858	.168
4		.112	.2263	.2858	.168
5		1.4255	1.7004	1.3272	1.2289
6		1.5729	1.7976	1.3763	1.2963
7		1.8187	1.8461	1.4255	1.6804
8		2.1628	1.9919	1.749	2.1822
9		2.2834	2.0165	2.0165	2.372
10		2.0891	2.0405	1.6404	2.2297
11		2.1348	2.3525	2.0165	2.0891
12		2.1822	2.3525	1.9685	2.2348
13		2.1559	2.2085	2.1605	2.2348
14		2.1822	2.1125	2.0165	2.2348
15		2.0873	2.0399	1.8724	1.9685
16		2.0873	1.945	2.0165	1.8244
17		1.945	1.7764	1.6324	1.7976
18		1.5655	1.3923	1.4403	1.5238
19		.3395	.3395	.3395	.3395
20		.3395	.3395	.3395	.3395
21		.3395	.3961	.2829	.3961
22		.2829	.3395	.1698	.2829
23	.1698	.2263	.3429	.1663	.2829
24		.1698	.2263	.4001	.1109
Max	.1698	2.2834	2.3525	2.1605	2.372
Min	.1698	.112	.2263	.1663	.1109
Avg	.1698	1.2479	1.2692	1.1458	1.2193

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

KARANJA SUB DN[379]

BU 4379

Substation No/ Name :- 294035 / 33/11 KV HETIKUNDI

Feeder No / Name : 201 / 11 KV KAJALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1227	.132	.132
2	.132	.1214	.1132	.132
3	.1307	.104	.0943	.132
4	.1307	.1214	.1132	.1132
5	.132	.1214	.5312	.8421
6	.1509	.1494	.5851	.8642
7	.168	.1646	.7682	.8855
8	.1886	.1494	.9804	1.2146
9	.168	.168	1.247	1.2146
10	.168	.1494	1.0911	1.1683
11	1.1336	1.1797	.1307	.1294
12	1.3599	1.2944	.112	.132
13	1.3599	1.3426	.1307	.1109
14	1.3117	1.2616	.1109	.1097
15	1.3599	.7116	.0934	.1132
16	1.2631	1.0911	.0934	.1132
17	1.1012	1.0155	.112	.112
18	.8855	.8097	.2641	.2829
19	.362	.3395	.3584	.3395
20	.3395	.3395	.3584	.3395
21	.2829	.2829	.2829	.3018
22	.1848	.1848	.1886	.1848
23	.1433	.1509	.1509	.1448
24	.132	.1214	.132	.1509
Max	1.3599	1.3426	1.247	1.2146
Min	.1307	.104	.0934	.1097
Avg	.5300	.4790	.3406	.3860

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

KARANJA SUB DN[379]

BU 4379

Substation No/ Name :- 294035 / 33/11 KV HETIKUNDI

Feeder No / Name : 202 / 11 KV HETIKUNDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.2263	.2096
2		.2263	.2096
3		.2075	.2096
4		.1886	.2096
5		.1886	.1886
6		.2075	.1886
7		.2075	.2075
8		.2241	.2452
9		.2452	.2286
10		.2075	.1886
11		1.5181	1.6164
12		1.8947	.5639
13		1.7309	
14		1.7078	
15		1.5851	1.9109
16		1.5623	2.0485
17	.1886	1.5023	1.9006
18	.3772	1.012	1.0974
19	.4382	.4715	.8488
20	.4527	.4715	.7074
21	.4191	.415	.415
22	.2829	.2641	.3018
23	.2641	.2263	.2427
24		.2452	.2075
Max	.4527	1.8947	2.0485
Min	.1886	.1886	.1886
Avg	.3461	.6973	.6339

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

KARANJA SUB DN[379] BU 4379

Substation No/ Name :- 294035 / 33/11 KV HETIKUNDI

Feeder No / Name : 203 / 11 KV Bori SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.0686	.0943	.0754
2	.0747	.0686	.0739	.0747
3	.0747	.0671	.0732	.0747
4	.0747	.0663	.0747	.0754
5	.0747	.0686	.6802	.9667
6	.0747		.7935	1.004
7	.0934		.9646	1.0688
8	.0943	.0716	1.1043	1.4091
9	.132	.1132	1.278	1.4706
10	.0943	.0747	1.2308	1.4586
11	1.4089	1.4586	.0747	.0701
12	1.5729	1.6244	.0747	.0943
13	1.5074	1.6244	.0739	.0486
14	1.5074	1.4586	.056	.0514
15	1.4582	1.3283	.056	.0537
16	1.2955	1.2323	.056	.0497
17	1.247	1.1227	.056	.0526
18	1.0814	.9831	.1294	.1307
19	.2096	.1905	.2054	.2096
20	.1886	.2096	.2054	.1698
21	.1509	.1698	.1698	.1698
22	.1097	.128	.1132	.1109
23	.0886	.112	.0754	.0701
24	.0953	.0686	.112	.0754
Max	1.5729	1.6244	1.278	1.4706
Min	.0747	.0663	.056	.0486
Avg	.5334	.5595	.3261	.3764

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

KHARANGANA (R) S/DN.[380] BU 4380

Substation No/ Name :- 294005 / 33 KV KHARANGANA

Feeder No / Name : 201 / 11 kV Anji+Masod

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1372	.1372	.12	.12
2		.1372	.12	.12	.12
3		.12	.12	.12	.1029
4		.1029	.1029	.1029	.1029
5		.1029	.1029	.1029	.2743
6		.1029	.1029	.12	.3086
7		.1543	.12	.1372	.3944
8		.4287	.463	.4287	.5316
9		.6516	.6173	.4801	.6173
10		.6687	.6687	.5487	.5316
11		.6001	.6173	.5316	.0857
12		.6001	.5658	.6001	.0686
13		.5658	.583	.5487	.0686
14		.5316	.5658	.5658	.0686
15		.5316	.6344	.6173	.0686
16			.0686	.0686	.0857
17			.12	.0857	.0857
18		.2058	.1715	.1886	.1886
19		.2229	.2058	.2058	.2229
20		.2229	.2058	.2229	.2229
21		.1886	.1886	.1886	.1886
22		.1372	.1372	.1543	.1372
23	.1715	.1372	.1372	.1372	.1029
24	.1372		.12	.12	
Max	.1715	.6687	.6687	.6173	.6173
Min	.1372	.1029	.0686	.0686	.0686
Avg	.1544	.3119	.2865	.2715	.2043

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

KHARANGANA (R) S/DN.[380] BU 4380

Substation No/ Name :- 294005 / 33 KV KHARANGANA

Feeder No / Name : 202 / 11 KV KHARANAGANA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2743	.3086	.2915	.2229
2		.2401	.2743	.2915	.2229
3		.2058	.2915	.2743	.2058
4		.2058	.2743	.2743	.1886
5		.2229	.2743	.2572	.2401
6		.2572	.2572	.2915	.2743
7		.3258	.2915	.2915	.3429
8		.3944	.3772	.4115	.4973
9		.6173	.6516	.4973	.583
10		.703	.6516	.5658	.5487
11		.6687	.6516	.5487	.2401
12		.6516	.6001	.583	.2058
13		.6687	.5487	.5487	.2401
14		.6001	.5144	.5316	.2229
15		.5658	.6344	.6001	.2229
16			.2401	.2058	.2401
17			.3086	.2401	.2572
18		.5316	.463	.4287	.463
19		.5658	.5487	.4801	.5316
20		.5316	.5316	.5316	.5316
21		.4458	.4287	.4801	.4458
22		.3086	.3086	.4458	.3086
23	.3601	.2915	.3086	.3429	.2572
24	.3086		.2915	.2743	
Max	.3601	.703	.6516	.6001	.583
Min	.3086	.2058	.2401	.2058	.1886
Avg	.3344	.4417	.4179	.4037	.3258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

KHARANGANA (R) S/DN.[380] BU 4380

Substation No/ Name :- 294005 / 33 KV KHARANGANA

Feeder No / Name : 203 / 11 KV PANWADI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1886	.1886	.2058	.1715
2		.1715	.2058	.1886	.1543
3		.1715	.1715	.1715	.1372
4		.1543	.1715	.1543	.1543
5		.1543	.1715	.1543	.4458
6		.1886	.1543	.1372	.4801
7		.1715	.1543	.1372	.5658
8		.6344	.703	.6173	.8573
9		1.046	1.0802	.7202	.9774
10		1.166	1.1145	.9431	.9602
11		1.1317	1.0117	1.0117	.12
12		1.0802	.9602	.9259	.12
13		1.0288	.9259	.8573	.12
14		1.0288	.8916	.8059	.12
15		1.0117	.8059	.9602	.12
16			.12	.1029	.12
17			.1886	.1029	.12
18		.3086	.2743	.2915	.2915
19		.3944	.3772	.3258	.3772
20		.3601	.3601	.3601	.3601
21		.2915	.3086	.3086	.3258
22		.2229	.2229	.2401	.2229
23	.2572	.1886	.2229	.1886	.1715
24	.2058		.1886	.1715	
Max	.2572	1.166	1.1145	1.0117	.9774
Min	.2058	.1543	.12	.1029	.12
Avg	.2315	.5283	.4572	.4201	.3258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

KHARANGANA (R) S/DN.[380] BU 4380

Substation No/ Name :- 294005 / 33 KV KHARANGANA

Feeder No / Name : 204 / SHIVSAI COTSPIN EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 FEEDER Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1524	.1677	.1524	.1829
2		.1524	.1677	.1524	.1524
3		.1524	.1829	.1524	.1524
4		.1829	.2058	.1524	.1524
5		.1829	.1677	.1524	.1524
6		.1829	.1677	.1677	.1829
7		.1829	.1524	.1677	.1829
8		.0914	.061	.1372	.0914
9		.0914		.0457	.061
10		.061	.061	.0305	.061
11		.061	.061	.0152	.061
12		.0762	.061	.0152	.061
13		.061	.061	.0152	.061
14		.061	.061	.0152	.061
15		.061	.061	.0152	.0457
16			.061	.0152	.061
17			.061	.061	.0686
18		.0152	.061	.061	.061
19		.0305	.061	.0914	.061
20		.1067	.1677	.0305	.1829
21		.1524	.1677	.1829	.1829
22		.1677	.0914	.1829	.1677
23	.1524	.1677	.1372	.1829	.1829
24	.1524		.1829	.1829	
Max	.1524	.1829	.2058	.1829	.1829
Min	.1524	.0152	.061	.0152	.0457
Avg	.1524	.1140	.1143	.0991	.1143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

KHARANGANA (R) S/DN.[380] BU 4380

Substation No/ Name :- 294005 / 33 KV KHARANGANA

Feeder No / Name : 205 / 11 KV MALEGAON THEKA SINGLE PHASING
 FEEDER Feeder KV- 11 /
 OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2058	.2229	.2572	.2058
2		.2058	.2229	.2401	.1715
3		.1715	.2229	.2401	.1715
4		.1715	.2058	.2229	
5		.2058	.2058	.2229	.4801
6		.2229	.2058	.2058	.5144
7		.2229	.1886	.1886	.6516
8		.823	.8916	.7888	.8745
9		1.1317	1.0974	.8745	.9431
10		1.1145	1.0117	1.0117	.8402
11		1.2174	1.0974	1.0288	.1543
12		1.1488	1.0288	1.046	.1715
13		1.1145	1.0117	1.0802	.1543
14		.8402	.9774	1.0631	.1543
15		.8916	.9774	.9945	.1543
16			.1543	.1543	.12
17			.2572	.1715	.12
18		.3944	.3601	.3944	.3772
19		.4801	.4458	.4115	.463
20		.463	.463	.4458	.463
21		.3944	.3772	.3772	.3944
22		.2743	.2915	.2915	.2743
23	.3086	.2572	.2915	.2401	.2058
24	.2401		.2401	.2058	
Max	.3086	1.2174	1.0974	1.0802	.9431
Min	.2401	.1715	.1543	.1543	.12
Avg	.2744	.5691	.5187	.5066	.3663

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

KHARANGANA (R) S/DN.[380] BU 4380

Substation No/ Name :- 294005 / 33 KV KHARANGANA

Feeder No / Name : 206 / 11 KV SHREERAM KRUPA

SHEDDABLE RURAL

EXPRESS Feeder KV- 11 /
OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0152	.0152	.0171	.0152
2		.0152	.0152	.0171	.0152
3		.0152	.0152	.0152	.0152
4		.0152	.0152	.0152	.0152
5		.0152	.0152	.0152	.0152
6		.0152	.0152	.0152	.0152
7		.0152	.0152	.0152	.0152
8		.0152	.0152	.0152	.0152
9		.0152	.1677	.0152	.1677
10		.1677	.1829	.1372	.1677
11		.1524	.1524	.1372	.1524
12		.1677	.1524	.1715	.1372
13		.1524	.1677	.1543	.1524
14		.1372	.1524	.1543	.1372
15		.1372	.1372	.1543	.1524
16			.1524	.1543	.1372
17			.1543	.1524	.1524
18		.1524	.1715	.1372	.1372
19		.1372	.1715	.0914	.0305
20		.0152	.0343	.0305	.0152
21		.0152	.0152	.0305	.0152
22		.0152	.0171	.0152	.0152
23	.0152	.0152	.0171	.0152	.0152
24	.0152		.0152	.0152	
Max	.0152	.1677	.1829	.1715	.1677
Min	.0152	.0152	.0152	.0152	.0152
Avg	.0152	.0668	.0826	.0705	.0742

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

KHARANGANA (R) S/DN.[380] BU 4380

Substation No/ Name :- 294005 / 33 KV KHARANGANA

Feeder No / Name : 401 / 33 KV ANJI CROSSOVER

FEEDER Feeder KV- 33 /
INCOMING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6173	.2829	.5658	.5144
2		.5144	.1698	.5658	.5144
3		.5144	.1698	.5658	.463
4		.5144	.1698	.5658	.4115
5		1.9033	2.0936	2.6595	
6		2.1605	2.32	2.5463	.5144
7		2.2634	2.6029	2.2634	.3086
8		2.0062	2.4897	2.8292	1.9033
9		2.2634	2.7778	3.1121	3.0556
10		.679	2.572	2.8292	3.678
11		.3961	.5144	.679	3.678
12		.3395	.2058	.679	3.1687
13		.3395	.2058	.6224	3.0556
14		.3395	.2058	.5658	3.3951
15		.2829	.2058	.6224	3.2253
16			.2058	.679	.4527
17			.5658	.6173	.2829
18			.679	.7202	.679
19		.2829	.7922	.7202	.8488
20		.2829	.8488	.823	.7356
21		.2829	.7922	.7202	.679
22	.7202	.2263	.679	.823	.3961
23	.7202	.2263	.679	.7202	.2829
24	.6173		.2263	.6173	
Max	.7202	2.2634	2.7778	3.1121	3.678
Min	.6173	.2263	.1698	.5658	.2829
Avg	.6859	.8218	.9356	1.1713	1.4656

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

KHARANGANA (R) S/DN.[380] BU 4380

Substation No/ Name :- 294009 / 33 KV PIMPALKHUTA SUB STN

Feeder No / Name : 201 / 11 KV TALEGAON -R- FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.061		.0686	.061	.0686	.0686	.0514
2	.061		.0686	.061	.0686	.0686	.0514
3	.061		.0686	.061	.0686	.0686	.0514
4	.061		.0686	.061	.0514	.0686	.0514
5	.1524		.1372	.061	.0514	.0686	.1372
6	.1829		.1886	.061	.0514	.0514	.1543
7	.1829		.2058	.0457	.0514	.0514	.1543
8	.1829		.2058	.1372	.1543	.1029	.1886
9	.1886			.2401	.1829	.1543	.3258
10	.1886			.2229	.1829	.1543	.1715
11	.0343			.2229	.1829	.1372	.0343
12	.0343			.2058	.1981	.1543	.0343
13	.0514			.2229	.1829	.12	.0343
14	.0514			.2401	.1677	.1372	.0343
15	.0514			.2058	.1829	.2058	.0514
16	.0514				.0343	.0343	.0343
17		.0514	.0305		.0686	.0686	.0343
18		.1029	.0914	.0857	.0857	.1029	.1029
19		.12	.1067	.1029	.12	.12	.12
20		.12	.1219	.12	.12	.1372	.12
21		.12	.1067	.0857	.1029	.12	.1029
22		.1029	.0762	.0686	.0857	.1029	
23		.0686	.0762	.0686	.0686	.0686	.0686
24	.061		.0686	.061	.0686	.0686	.0514
Max	.1886	.12	.2058	.2401	.1981	.2058	.3258
Min	.0343	.0514	.0305	.0457	.0343	.0343	.0343
Avg	.0975	.0980	.1056	.1228	.1084	.1015	.0939

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

KHARANGANA (R) S/DN.[380] BU 4380

Substation No/ Name :- 294009 / 33 KV PIMPALKHUTA SUB STN

Feeder No / Name : 202 / 11 KV WADHONA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1981		.2401	.1981	.2229	.2058	.2058
2	.1829		.2401	.1981	.2229	.2058	.2058
3	.1829		.2401	.1981	.2229	.2058	.1886
4	.1829		.2229	.1981	.2229	.2058	.1715
5	.6097		.7545	.1829	.2229	.2058	.1886
6	.7773		.8916	.2134	.2058	.2058	.2058
7	.8993		1.0802	.1829	.1715	.1886	.1886
8	.8078		1.4918	.6859	.5658	1.0288	.1715
9	.823			1.1317	.7164	1.046	.1715
10	.7716			1.166	.823	1.0631	.1543
11	.1372			1.1488	.884	1.046	.1372
12	.1543			1.166	.9145	1.0802	.9945
13	.1372			1.1317	.9602	1.0631	1.3717
14	.1372			1.1145	.9145	1.1145	1.3375
15	.1372			.9259	.8535	1.0288	1.2174
16	.1372				.1543	.1372	.1372
17		.2058			.2572	.2401	.1372
18		.3258		.3429	.3258	.3258	.3086
19		.4287		.4115	.3944	.3601	.3944
20		.3944		.4287	.3429	.4115	.5658
21		.3772		.3429	.3258	.3772	.5144
22		.3258		.2915	.2743	.3429	.4973
23		.2401	.2134	.2229	.2058	.2058	.4801
24	.1981		.2401	.1981	.2229	.2058	.2058
Max	.8993	.4287	1.4918	1.166	.9602	1.1145	1.3717
Min	.1372	.2058	.2134	.1829	.1543	.1372	.1372
Avg	.3808	.3283	.5615	.5491	.4428	.5208	.4230

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

KHARANGANA (R) S/DN.[380] BU 4380

Substation No/ Name :- 294009 / 33 KV PIMPALKHUTA SUB STN

Feeder No / Name : 203 / 11 KV BRAMHANWADA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0457		.0686	.0457	.0514	.0686	.0686
2	.0457		.0686	.0457	.0514	.0686	.0686
3	.0457		.0686	.0457	.0514	.0686	.0686
4	.0457		.0686	.0457	.0514	.0686	.0686
5	.2743		.3944	.0457	.0514	.0686	.1715
6	.3658		.4801	.061	.0514	.0514	.2743
7	.4268		.5144	.0457	.0686	.0514	.3429
8	.5335		.6001	.2896	.2743	.2572	.5144
9	.4801			.4115	.3506	.4801	.5658
10	.4458			.463	.503	.5487	.5487
11	.0343			.4115	.503	.583	.0343
12	.0343			.463	.503	.583	.0514
13	.0343			.4973		.583	.0514
14	.0343			.5316		.583	.0514
15	.0343			.5316		.5487	.0514
16	.0514				.0343	.0343	.0514
17		.0686			.0686	.0686	.0514
18		.12		.12	.0857	.1029	.1372
19		.1543		.1372	.12	.12	.1543
20		.1543		.1543	.12	.1372	.1543
21		.1372		.12	.12	.12	.1029
22		.1029		.0857	.0857	.1029	.0857
23		.0686	.061	.0686	.0686	.0686	.0686
24	.0457		.0686	.0457	.0514	.0686	.0686
Max	.5335	.1543	.6001	.5316	.503	.583	.5658
Min	.0343	.0686	.061	.0457	.0343	.0343	.0343
Avg	.1752	.1151	.2393	.2121	.1555	.2265	.1586

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

KHARANGANA (R) S/DN.[380] BU 4380

Substation No/ Name :- 294009 / 33 KV PIMPALKHUTA SUB STN

Feeder No / Name : 205 / 11 KV TARODA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305		.0514	.0457	.0343	.0514	.0514
2	.0305		.0514	.0457	.0343	.0514	.0514
3	.0305		.0514	.0305	.0343	.0514	.0514
4	.0305		.0514	.0305	.0343	.0343	.0343
5	.061		.0686	.0305	.0343	.0343	.0343
6	.0762		.1029	.0305	.0343	.0343	.0343
7	.0762		.12	.0305	.0343	.0343	.0343
8	.061		.12	.0457	.0857	.0686	.0343
9	.0686			.1029	.0914	.1029	.0857
10	.0686			.1372	.1067	.1029	.0686
11	.0343			.1372	.0914	.1029	.0686
12	.0514			.12	.0762	.1543	.0857
13	.0343			.12	.0762	.12	.2229
14	.0343			.12	.0762	.1029	.0857
15	.0343			.12	.0914	.0857	.0857
16	.0343					.0686	.0343
17		.0343			.0514	.0857	.0514
18		.0686		.0343	.0686	.0857	.0686
19		.0686		.0343	.0686	.0857	.0857
20		.0857		.0343	.0686	.0857	.0686
21		.0686		.0343	.0686	.0686	.0686
22		.0514		.0343	.0514	.0686	.0514
23		.0514	.0457	.0343	.0514	.0514	.0514
24	.0457		.0514	.0457	.0343	.0514	.0514
Max	.0762	.0857	.12	.1372	.1067	.1543	.2229
Min	.0305	.0343	.0457	.0305	.0343	.0343	.0343
Avg	.0472	.0612	.0714	.0636	.0608	.0743	.065

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

KHARANGANA (R) S/DN.[380] BU 4380

Substation No/ Name :- 294009 / 33 KV PIMPALKHUTA SUB STN

Feeder No / Name : 206 / 11 KV PIMPALKHUTHA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.061		.0686	.0457	.0514	.0686	.0686
2	.061		.0686	.0457	.0514	.0686	.0686
3	.0457		.0686	.0457	.0514	.0686	.0514
4	.0457		.0514	.0457	.0514	.0686	.0514
5	.0762		.0686	.0457	.0514	.0686	.0514
6	.0914		.0857	.0762	.0514	.0686	.0514
7	.0914		.0857	.0457	.0514	.0686	.0686
8	.0762		.0686	.0457	.0857	.0857	.0857
9	.1029			.12	.0914	.0857	.0857
10	.0686			.12	.061	.0857	.0686
11	.0686			.12	.061	.0857	.0686
12	.0514			.1029	.061	.0857	.0514
13	.0514			.1029	.061	.0686	.0514
14	.0514			.0857	.0457	.0686	.0514
15	.0514			.0857	.0457	.0514	.0514
16	.0514				.0514	.0514	.0514
17		.0686			.0686	.0857	.0343
18		.1029		.12	.1029	.1029	.12
19		.12		.1372	.1543	.12	.1372
20		.1372		.1372	.1372	.12	.12
21		.12		.1029	.12	.12	.1029
22		.1029		.0857	.0857	.1029	.0686
23		.0686	.0762	.0686	.0686	.0686	.0514
24	.061		.0686	.061	.0514	.0686	.0686
Max	.1029	.1372	.0857	.1372	.1543	.12	.1372
Min	.0457	.0686	.0514	.0457	.0457	.0514	.0343
Avg	.0651	.1029	.0711	.0839	.0714	.0807	.07

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

KHARANGANA (R) S/DN.[380] BU 4380

Substation No/ Name :- 294009 / 33 KV PIMPALKHUTA SUB STN

Feeder No / Name : 207 / 11 KV HIWARA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2572	.2286	.2229	.2401	.2572
2			.2572	.2286	.2229	.2401	.2572
3			.2572	.2134	.2229	.2401	.2572
4			.2572	.2134	.2229	.2058	.2401
5			.2572	.4725	.4115	.7716	.2401
6			.2572	.6097	.6859	.9431	.2572
7			.2572	.823	.9259	.9774	.2401
8			.8745	.7926	1.2003	1.2003	.8745
9	1.3717			.9431	1.0364	1.3717	1.0974
10	1.3889			.8402	.8993	1.4746	1.3889
11	1.286			.12	.0914	.0343	1.1317
12	1.2346			.1029		.0343	.1029
13	1.1488			.1029	.0762	.12	.1029
14	1.166			.1029	.0762	.12	.12
15	1.166			.12	.0914	.12	.12
16	.1029				.0857	.1029	1.1145
17		.2229			.1543	.2058	1.2174
18		.3429		.3086	.3086	.3258	1.1145
19		.3944		.3429	.3601	.3772	.8916
20		.3772		.3429	.3601	.3944	.3086
21		.3772		.3086	.3601	.3601	.3086
22		.3429		.2743	.2572	.3429	.2572
23		.2915	.2439	.2401	.2743	.2743	.2229
24			.2572	.2439	.2401	.2401	.2572
Max	1.3889	.3944	.8745	.9431	1.2003	1.4746	1.3889
Min	.1029	.2229	.2439	.1029	.0762	.0343	.1029
Avg	1.1081	.3356	.3176	.3625	.3820	.4465	.5158

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

PULGAON URBAN S/DN[376] BU 1881

Substation No/ Name :- 294007 / 33 KV STN,VIJAYGOPAL

Feeder No / Name : 201 / 11 KV Vijaygopal AG Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3		.0503			
4		.2672		.2072	
5		.2904		.2441	
6		.3109		.2631	
7		.3264	.3684	.2983	
8		.2881	.2877	.405	
9		.3246	.3217	.3514	
10		.3255	.349	.291	
11		.0411			
12		.0394			
13		.0374		.0373	
14		.0378			
15		.0405			
16			.039		
18					.0374
19					.0374
20					.0372
23	.0514				
24		.0462			
Max	.0514	.3264	.3684	.405	.0374
Min	.0514	.0374	.039	.0373	.0372
Avg	.0514	.1733	.2732	.2622	.0373

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

PULGAON URBAN S/DN[376] BU 1881

Substation No/ Name :- 294007 / 33 KV STN,VIJAYGOPAL

Feeder No / Name : 202 / 11 kV Rohani Ag Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.0573	.0604	.0382	
9	.0734	.0984	.106	
10	.1115	.0983	.1509	
11	.1237	.1118	.1815	.1056
12	.1371	.1115	.1829	.1059
13	.1268	.1115	.137	.1218
14	.135	.11	.1358	.1218
15	.0884		.1358	.1372
Max	.1371	.1118	.1829	.1372
Min	.0573	.0604	.0382	.1056
Avg	.1067	.1003	.1335	.1185

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

PULGAON URBAN S/DN[376] BU 1881

Substation No/ Name :- 294007 / 33 KV STN,VIJAYGOPAL

Feeder No / Name : 203 / 11 KV INZALA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.6395	.5679	.7761	
9	.9333	.9384	.9168	
10	.9506	.9398	.9842	
11	.9327	.9541		.9495
12	.9123	.9591	.8557	.9316
13	.97	.9889	.9734	.9396
14	.9727	.9678	.9614	.9339
15	.8941	.9374	.9168	.9006
Max	.9727	.9889	.9842	.9495
Min	.6395	.5679	.7761	.9006
Avg	.9007	.9067	.9121	.9310

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

PULGAON URBAN S/DN[376] BU 1881

Substation No/ Name :- 294007 / 33 KV STN,VIJAYGOPAL

Feeder No / Name : 204 / 11KV Vijaygopal Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1052		.0835	
2		.1093		.0874	
3		.1064		.0799	
4		.1057		.078	
5		.1102		.0928	
6		.1174		.1132	
7		.1278	.1135	.1181	
8		.1226	.1031	.1288	
9		.1255	.1088	.1052	
10		.1292	.1127	.1226	
11		.115	.1045	.1029	.1059
12		.0969	.102	.0676	.0686
13		.0892	.0855	.0516	.1052
14		.0808	.0931	.0556	.0728
15		.0836	.112	.0549	.0899
16		.0966	.0573	.0854	.0718
17		.0862	.0657		.0898
18		.1383	.1553		.1503
19		.1677	.1807		.1142
20		.1753	.1638		.1523
21		.1353	.1464		.0952
22		.1231	.1293		
23	.1143	.116	.0894		.0943
24		.1098	.1104	.0856	
Max	.1143	.1753	.1807	.1288	.1523
Min	.1143	.0808	.0573	.0516	.0686
Avg	.1143	.1155	.1130	.0890	.1009

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

PULGAON URBAN S/DN[376] BU 1881

Substation No/ Name :- 294007 / 33 KV STN,VIJAYGOPAL

Feeder No / Name : 205 / 11 KV Inzala Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 /
OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1637		.1292	
2		.1524		.1236	
3		.1368		.1174	
4		.133		.1155	
5		.1331		.1289	
6		.1528		.1439	
7			.1551	.1801	
8		.1866	.1979	.1793	
9		.1888	.1552	.1974	
10		.149	.1498	.1437	
11		.1353	.1186	.11	.1113
12		.1225	.1044	.1097	.1102
13		.0998	.0915	.0931	.1087
14		.1033	.0941	.0921	.1124
15		.093	.0819	.0761	.0948
16		.1031	.0914	.0758	.0947
17		.1227	.0949		.1124
18		.2369	.2649		
19		.3283	.3301		.3164
20		.2703	.2851		.2824
21		.2134	.2474		.2474
22		.1962	.1673		.1701
23	.1656	.1677	.1368		.1331
24		.1559	.16	.1351	
Max	.1656	.3283	.3301	.1974	.3164
Min	.1656	.093	.0819	.0758	.0947
Avg	.1656	.1628	.1626	.1265	.1578

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

PULGAON URBAN S/DN[376] BU 1881

Substation No/ Name :- 294018 / 33 KV VIRUL SUB STN

Feeder No / Name : 201 / 11 KV Virul AG Feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0297	.0274	.0452	
2		.0301	.0274	.0301	.0274
3		.0305	.0274	.0301	.0274
4		.2515	.2012	.2553	.0274
5		.2808	.2766	.2439	.0274
6		.3382	.3144	.3144	.0274
7		.3681	.4024	.3702	.0274
8		.3829	.415	.3772	.2263
9		.3144	.4146	.4401	.3772
10		.3395	.4401	.4401	.4212
11		.0267	.0297	.0286	.5182
12		.0412	.0297	.0274	.4468
13		.0267	.0301		.5106
14		.0274	.0301		.4468
15		.0412			.4595
16		.0274			.0297
17		.0274	.0301	.0274	.0297
18		.0274	.0446	.0274	.0301
19		.0274	.0452	.0274	.0446
20		.0274	.0446	.0274	.0452
21	.0297	.0274	.0452	.0274	.044
22	.0301	.0274	.0446	.0274	.0286
23	.0297	.0274	.0452	.0274	.0452
24		.0301	.0274	.0297	.0274
Max	.0301	.3829	.4401	.4401	.5182
Min	.0297	.0267	.0274	.0274	.0274
Avg	.0298	.1158	.1360	.1412	.1694

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

PULGAON URBAN S/DN[376] BU 1881

Substation No/ Name :- 294018 / 33 KV VIRUL SUB STN

Feeder No / Name : 202 / 11 KV RASULABAD AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3		.0305		
4	.1692		.1783	.2347
5	.2229	.1189	.1806	.2347
6	.2972	.1882	.2606	.2347
7	.301	.2812	.3311	.301
8	.3086	.3311	.3963	
9	.2408	.301	.3864	
10	.2709	.2972	.3572	.3765
11				.3763
12				.3715
Max	.3086	.3311	.3963	.3765
Min	.1692	.0305	.1783	.2347
Avg	.2587	.2212	.2986	.3042

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

PULGAON URBAN S/DN[376] BU 1881

Substation No/ Name :- 294018 / 33 KV VIRUL SUB STN

Feeder No / Name : 203 / 11 KV Virul/ Pachod
 Gaothan Feeder KV- 11 /
 OUTGOING

GAOTHAN FEEDER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.112	.0754	.0754	.0943
2		.112	.0754	.0747	.0754
3		.1109	.0754	.0747	.0754
4		.112	.0754	.0747	.0754
5		.0934	.0754	.0754	.0754
6		.0934	.0943	.0747	.0754
7		.0943	.0943	.0747	.0943
8		.0934	.0943	.0934	.0934
9		.1267	.0934		.0934
10		.1063	.0943	.0914	.0709
11		.0924	.0747	.0934	.0724
12		.0739	.0747	.0924	.0732
13		.0747	.0549	.0934	.0732
14		.0747	.0554	.0747	.0739
15		.0724		.0747	.0914
16		.0543	.0747	.0732	.0924
17		.0724	.0747	.0732	.0739
18		.1867	.1494	.1494	.1663
19		.2241	.1867	.2054	.1886
20		.1867	.1698	.1867	.1886
21	.1509	.168	.1509	.168	.1509
22	.132	.1494	.1132	.1307	.1494
23	.1307	.1494	.0943	.0934	.0934
24		.1109	.0747	.0754	.0934
Max	.1509	.2241	.1867	.2054	.1886
Min	.1307	.0543	.0549	.0732	.0709
Avg	.1379	.1144	.0955	.0997	.1002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

PULGAON URBAN S/DN[376] BU 1881

Substation No/ Name :- 294018 / 33 KV VIRUL SUB STN

Feeder No / Name : 204 / 11 KV Rasulabad Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0924	.0754	.0747	.0747
2		.0747	.0754	.0747	.0754
3		.0747	.0754	.0747	.0754
4		.0747	.0754	.0747	.0754
5		.0747	.0754	.0739	.0566
6		.0747	.0943	.0739	.0934
7		.0934	.0943	.0934	.0934
8		.0934	.0943	.0934	.0747
9		.1109	.0934	.0934	.0747
10		.0924	.0747	.0739	.0747
11		.0747	.0747	.056	.0747
12		.0747	.112	.0934	
13		.0747	.0747	.0934	
14		.0739	.0747	.0934	.0732
15		.0739	.0747	.0747	.0732
16		.0747	.0739	.056	.0739
17		.0934	.0739	.0747	.0934
18		.168	.1494	.112	.112
19		.168	.168	.168	.1867
20		.1494	.1698	.1494	.168
21	.1307	.1307	.132	.1307	.0894
22	.1307	.0934	.1132	.0934	.112
23	.112	.0747	.0943	.0747	.0747
24		.0924	.0754	.0747	.0747
Max	.1307	.168	.1698	.168	.1867
Min	.112	.0739	.0739	.056	.0566
Avg	.1245	.0947	.0954	.0894	.0897

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

PULGAON URBAN S/DN[376] BU 1881

Substation No/ Name :- 294033 / 33/11 KV Pulgaon Sub-Station

Feeder No / Name : 202 / VPF GAOTHAN SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5629	.5629	.5359	.6622
2		.4967	.5668	.5175	.6835
3		.5359	.5526	.5175	.7034
4		.5464	.5526	.5175	.7285
5		.6866	.5526	.5359	.7502
6		.8373	.6622	.6468	.7703
7		.9713	.7871	1.0534	.7665
8		.8708	.7369	.8686	.7828
9		.7871	.8708	.8686	.8206
10		.7665	.924	.8871	.8346
11		.7781	.8316	.8686	.8038
12		.7034	.8316	.8501	.7335
13		.6699	.8131	.8501	.8413
14		.6699	.8131	.7947	.7499
15		.6531	.8131	.6838	.695
16	.745	.6364	.7392	.6531	.695
17	.8609	.6622	.7947	.6866	.823
18	1.1093	.9546	1.1273	.8708	1.2071
19	1.0762	1.0215	1.1458	1.0885	1.2071
20	1.055	.9546	1.1088	1.0048	1.0974
21	.8373	.8154	.9425	.8708	.9328
22	.7536	.7369	.7762	.7119	.7865
23	.6866	.6699	.6283	.6954	.6401
24		.6291	.5464	.5729	.7119
Max	1.1093	1.0215	1.1458	1.0885	1.2071
Min	.6866	.4967	.5464	.5175	.6401
Avg	.8905	.7340	.7783	.7563	.8095

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

PULGAON URBAN S/DN[376] BU 1881

Substation No/ Name :- 294033 / 33/11 KV Pulgaon Sub-Station

Feeder No / Name : 203 / 11 KV NACHANGAON AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1142	.149	.1698	.149
2		.1305	.1334	.1698	.1656
3		.1159	.1332	.1698	.1842
4		.134	.1334	.1698	.8444
5		.134	.1507	.1698	.9043
6		.1172	.1334	.1698	1.0048
7		.1334	.1305	.1509	1.1169
8		.15	1.1169	.9217	1.2336
9		1.467	1.4338	1.2498	1.3565
10		1.5407	1.3904	1.3279	1.2721
11		1.5909	1.4529	1.3904	.3311
12		1.5072	1.3904	1.4373	.2772
13		1.467	1.3279	1.406	.3113
14		1.3699	1.3123	1.4217	.2949
15		1.4284	1.3435	1.3904	.2458
16	.2649	.1987	.1646	.1305	.2785
17	.2152	.1821	.1646		.2458
18	.149	.201	.2012		.1966
19	.1507	.1675	.1886	.1842	.1966
20	.1675	.1656	.2075	.1813	.1966
21	.1507	.1675	.2075	.2	.1638
22	.149	.1675	.2075	.1842	.1966
23	.1507	.1656	.1698	.1821	.1966
24		.1324	.149	.1698	.201
Max	.2649	1.5909	1.4529	1.4373	1.3565
Min	.149	.1142	.1305	.1305	.149
Avg	.1747	.5395	.558	.5885	.4818

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

PULGAON URBAN S/DN[376] BU 1881

Substation No/ Name :- 294033 / 33/11 KV Pulgaon Sub-Station

Feeder No / Name : 204 / C.A.D.

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 11 / OUTGOING

UTILITY

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1324	.1675	.1886	.1656
2		.149	.1648	.1886	.1834
3		.134	.1842	.1886	.1507
4		.1667	.1987	.1886	.1675
5		.201	.212	.2075	.201
6		.2345	.2966	.2641	.2342
7		.3099	.3182	.3584	.3477
8		.2667	.2167	.2829	.3311
9		.2561	.2483	.3018	.2847
10		.2334	.2641	.2641	.2307
11		.2167	.2452	.2452	.1821
12		.1987	.2641	.2263	.1142
13		.1794	.3395	.2263	.2452
14		.2318	.2641	.2075	.1886
15		.3146	.1886	.1886	.1698
16	.1324	.1675	.1698	.1675	.2075
17	.2177	.201	.1886	.1667	.2075
18	.2483	.2446	.2641	.2167	.2829
19	.2483	.2649	.3206	.2667	.3206
20	.2483	.2667	.2829	.2501	.3018
21	.2152	.2345	.2452	.2345	.2641
22	.1987	.201	.2075	.1998	.2263
23	.1821	.1794	.1886	.201	.2075
24		.1656	.1667	.1886	.1656
Max	.2483	.3146	.3395	.3584	.3477
Min	.1324	.1324	.1648	.1667	.1142
Avg	.2114	.2146	.2336	.2258	.2242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

PULGAON URBAN S/DN[376] BU 1881

Substation No/ Name :- 294033 / 33/11 KV Pulgaon Sub-Station

Feeder No / Name : 205 / Pulgaon Town

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3517	.4019	.3881	.519
2		.3808	.4019	.3696	.4971
3		.3517	.3834	.3696	.4336
4		.3852	.3642	.3696	.6005
5		.3973	.3852		.5532
6		.5629	.4285	.4805	.5906
7		.6622	.5694	.7392	.5945
8		.5861	.5359	.6468	.6501
9		.5298	.5191	.6283	.6301
10		.5359	.462	.6099	.6638
11		.5298	.2772	.5914	.5228
12		.3852	.3696	.499	.4805
13		.3182	.5359	.5175	.5041
14		.5191	.499	.4805	.2534
15		.9546	.4251	.4435	.2353
16	.3973	.4522	.4066	.4139	.2534
17	.5668	.4689	.4251	.4305	.2534
18	.6788	.6788	.7392	.6364	.7964
19	.6668	.7034	.7762	.7119	.7602
20	.6622	.6335	.7392	.6699	.6878
21	.6335	.5629	.6468	.5694	.6154
22	.8609	.4967	.5359	.5024	.5068
23	.5191	.4334	.462	.4077	.4163
24		.5024	.3852	.4066	.424
Max	.8609	.9546	.7762	.7392	.7964
Min	.3973	.3182	.2772	.3696	.2353
Avg	.6232	.5159	.4864	.5166	.5184

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

PULGAON URBAN S/DN[376] BU 1881

Substation No/ Name :- 294033 / 33/11 KV Pulgaon Sub-Station

Feeder No / Name : 207 / MEDICAL NON SHEDDABLE WATER SUPPLY AND
 Feeder KV- 11 / OUTGOING UTILITY

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0167	.0331	.037	.0166
2		.0167	.0335	.037	.0335
3		.0335	.0333	.037	.0167
4		.0335	.0333	.037	.0167
5		.0166	.0335	.037	.0335
6		.0167	.0325	.037	.0167
7		.0167	.0335	.0185	.0167
8		.0167	.0335	.0185	.0167
9		.0163	.0335	.0185	.0167
10		.0167	.0185	.0185	.0167
11		.0335	.0185	.037	.0335
12		.0327	.0185	.037	.0333
13		.0333	.0185	.037	.0187
14		.0167	.0185	.0185	.0187
15		.0167	.0185	.0185	.0373
16	.0166	.0166	.037	.0167	.0373
17	.0167	.0167	.037	.0167	.0187
18	.0326	.0167	.037	.0167	.0373
19	.0335	.0335	.037	.0167	.0373
20	.0335	.0335	.037	.0333	.0373
21	.0335	.0335	.037	.0333	.0373
22	.0335	.0335	.037	.0333	.0373
23	.0335	.0331	.037	.0167	.0373
24		.0167	.0331	.037	.0167
Max	.0335	.0335	.037	.037	.0373
Min	.0166	.0163	.0185	.0167	.0166
Avg	.0292	.0236	.0308	.0277	.0266

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

PULGAON URBAN S/DN[376] BU 1881

Substation No/ Name :- 294033 / 33/11 KV Pulgaon Sub-Station

Feeder No / Name : 209 / 11 KV VPF Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1142	.0331	.0566	.0166
2		.0979	.0333	.0566	.033
3		.1159	.0335	.0566	.0167
4		.0993	.0335	.1475	.0167
5		.1159	.1005	.1311	.0335
6		.134	.1	.1311	.0333
7		.1507	.1675	.1311	.0333
8		.1324	.2152	.1966	.2512
9		.1507	.1834	.2294	.2501
10		.149	.1802	.2294	.2501
11		.0333	.0377	.0377	.2667
12		.0335	.0377	.0328	.2446
13		.0489	.0566	.0377	.2401
14		.0335	.0566	.0377	.2241
15		.0331	.0566	.0377	.064
16	.0662	.0331	.0566	.0331	.032
17	.0659	.0335	.0566	.0333	.016
18	.0502	.0335	.0566	.0167	.032
19	.0489	.0335	.0566	.0335	.032
20	.0165	.0502	.0566	.0333	.032
21	.0326	.0502	.0566	.0335	.032
22	.0331	.0502	.0566	.0326	.032
23	.0335	.0335	.0566	.0167	.032
24		.0335	.0331	.0566	.0166
Max	.0662	.1507	.2152	.2294	.2667
Min	.0165	.0331	.0331	.0167	.016
Avg	.0434	.0747	.0755	.0766	.0929

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

PULGAON URBAN S/DN[376] BU 1881

Substation No/ Name :- 294037 / 33/11 KV Gunjkheda

Substation

Feeder No / Name : 201 / LAXMINARAYNPUR/KURZADI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1112	.1132	.1112	.1132
2		.1112	.1132	.1112	.1132
3		.1112	.1132	.1112	.1132
4		.1112	.1132	.1112	.1132
5		.1132	.1132	.1112	.1132
6			.1132	.1112	.1132
7		.1112	.1132	.1132	.1132
8		.1132	.0943	.1132	.0943
9		.0934	.1112	.1112	.1112
10		.1112	.1112	.1112	.1112
11		.1494	.1112	.0934	.1086
12		.1307	.1112		.1448
13		.1112	.1112	.0934	.0934
14		.1112	.1112	.0905	.0934
15		.1112	.1112	.0934	.1307
16		.1112	.1112	.1267	.1227
17		.1132	.1132	.132	.1698
18		.1132	.0943	.132	.1132
19		.1132	.1112	.1132	.1132
20		.1132	.1132	.132	.1132
21		.1132	.1132	.1132	.1132
22		.1132	.1132	.1132	.1132
23	.1132	.1132	.1132	.1132	.1132
24		.1112	.1132	.1132	.1132
Max	.1132	.1494	.1132	.132	.1698
Min	.1132	.0934	.0943	.0905	.0934
Avg	.1132	.1141	.1112	.1123	.1153

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

PULGAON URBAN S/DN[376] BU 1881

Substation No/ Name :- 294037 / 33/11 KV Gunjkheda

Substation

Feeder No / Name : 202 / HIWARA/PULGAON TOWN I

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1372	.1357	.1372	.1543
2		.1372	.1372	.1372	.1543
3		.1372	.1372	.1372	.1543
4		.12	.1372	.1372	.1372
5		.1372	.1357	.1372	.1372
6			.1357	.1372	.1372
7		.1372	.1372	.1372	.1372
8		.12	.1543	.1029	.1372
9		.168	.168	.168	.1448
10		.3174	.2054	.2054	.1867
11		.2987	.2241	.2054	.2241
12		.2054	.2427	.2054	.2353
13		.1991	.2427	.2241	.2353
14		.3174	.1867	.2054	.2427
15		.181	.2987	.168	.2054
16		.2241	.2427	.2241	.168
17		.1372	.1029	.1595	.1715
18		.1658	.1543	.1865	.1543
19		.1509	.1715	.1886	.1543
20		.1715	.1886	.1715	.1543
21		.1865	.1543	.1543	.1543
22		.1372	.1372	.1543	.12
23	.1372	.1715	.1372	.1543	.1715
24		.1372	.1509	.1543	.1543
Max	.1372	.3174	.2987	.2241	.2427
Min	.1372	.12	.1029	.1029	.12
Avg	.1372	.1780	.1716	.1664	.1677

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

ARVI DIVISION[184]

PULGAON URBAN S/DN[376] BU 1881

Substation No/ Name :- 294037 / 33/11 KV Gunjkheda

Substation

Feeder No / Name : 203 / GUNJKHEDA/PULGAON TOWN II

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1267	.2629	.1267	.2303
2		.1267	.2658	.1267	.2126
3		.1267	.2686	.1267	.2126
4		.1267	.2686	.1267	.2103
5		.1267	.2715	.1267	.2149
6			.2865	.1448	.124
7		.1267	.2507	.1267	.1227
8		.1267	.1402	.1267	.124
9		.112	.1307	.112	.1307
10		.1867	.1267	.1307	.1307
11		.1307	.2987	.1307	.1267
12		.1494	.2987	.1307	.1267
13		.1629	.2801	.1307	.1307
14		.1307	.2614	.2801	.112
15		.1307	.2801	.112	.112
16		.112	.2614	.112	.1086
17		.124	.2534	.1029	.1267
18		.1772	.1629	.1772	.181
19		.1753	.1991	.1949	.1991
20		.1753	.181	.1772	.2534
21		.1772	.1629	.298	.3258
22		.3189	.1267	.298	.3077
23	.1448	.2481	.1267	.2454	.2896
24		.1267	.2658	.1267	.2303
Max	.1448	.3189	.2987	.298	.3258
Min	.1448	.112	.1267	.1029	.1086
Avg	.1448	.1532	.2263	.1580	.1810

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

HINGANGHAT (U) S/DN[374] BU 1830

Substation No/ Name :- 294050 / 33/11 KV SUBSTATION

HINGANGHAT

Feeder No / Name : 201 / 11 kv MOHTA FEEDER

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			1.406	1.4575
4			1.4232	1.4575
6			1.4575	1.4746
7			1.4746	1.4918
8	1.5089	1.4746	1.5261	1.4746
9	1.5775	1.6975	1.6461	1.4918
10	1.6118	1.7147	1.5261	1.5604
11	1.5775	1.5604	1.4403	1.5604
12	1.6804	1.4575	1.5261	.1543
13	1.7661	1.286	1.5432	1.1317
14	1.4746	1.286	1.5089	1.5604
15	1.5775	1.4403	1.4746	1.5089
16	1.5604	1.4232	1.5261	1.5604
17	1.5432	.7373	1.5604	1.5432
18	1.5089		1.6118	
19	1.4918	1.5089	1.5947	1.5432
20	1.3889	1.3717	1.3203	1.4232
21	1.4746	1.3032	1.5089	1.406
22	1.3889	1.5089	1.406	1.3546
23	1.3889	1.3717	1.4575	1.3717
24	1.286	1.3889	1.3717	1.4575
Max	1.7661	1.7147	1.6461	1.5604
Min	1.286	.7373	1.3203	.1543
Avg	1.5180	1.4082	1.4910	1.3992

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

HINGANGHAT (U) S/DN[374] BU 1830

Substation No/ Name :- 294050 / 33/11 KV SUBSTATION

HINGANGHAT

Feeder No / Name : 202 / 11 kv VIBHA FEEDER

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			2.5034	2.4691
4			2.5034	2.4863
6			2.4177	2.3491
7			2.4691	2.452
8	2.572	2.4691	2.6063	2.452
9	2.572	2.4348	2.2634	2.2977
10	2.8121	2.6063	2.1948	2.3148
11	3.0007	2.572	2.2634	2.2805
12	2.8292	2.2805	2.3148	2.4691
13	2.7949	2.4691	2.3663	2.2805
14	2.6406		2.2634	2.3491
15	2.8464		2.572	2.4863
16	2.6063		2.2634	2.4863
17	2.6749		2.2634	2.332
18	2.5206		2.5034	2.5034
19	2.4177	2.1262	2.4006	2.4863
20	2.5034	2.5549	2.3663	2.4348
21	2.4348	2.3663	2.2634	2.3834
22	2.5549	2.4177	2.5377	2.3834
23	2.5549	2.4691	2.5377	2.5206
24	2.5892	2.2291	2.5549	2.4177
Max	3.0007	2.6063	2.6063	2.5206
Min	2.4177	2.1262	2.1948	2.2805
Avg	2.6426	2.4163	2.4014	2.4112

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

HINGANGHAT (U) S/DN[374] BU 1830

Substation No/ Name :- 294050 / 33/11 KV SUBSTATION

HINGANGHAT

Feeder No / Name : 203 / 11 KV NANDGAON INDUSTRIAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			1.0974	.9602
4			1.0974	.9602
6			1.1317	1.0974
7			.9431	1.1145
8	.8402	.8059	.9774	1.0631
9	.9259	1.166	1.1317	1.3032
10	.9602	1.3546	.8745	1.1145
11	.9774	1.2517	.8402	1.3546
12	1.046	1.2003	.9088	1.4232
13	1.3032	1.2003	.8916	1.3546
14	1.1488	.9774	.7716	1.3546
15	1.166	.9945		1.4746
16	.9431	1.046	.1372	1.4746
17	.8402	.8745	.1715	1.406
18	.7716		.8059	1.5089
19	.8745	.9431	1.3203	1.5432
20	.7202	.823	.9945	1.3203
21	.6001	.823	1.0117	1.0802
22	.7888	1.1317	.8745	1.0288
23	.9088	1.1145	.8916	.9259
24	.8059	.7373	1.1145	.9088
Max	1.3032	1.3546	1.3203	1.5432
Min	.6001	.7373	.1372	.9088
Avg	.9189	1.0277	.8994	1.2272

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

HINGANGHAT (U) S/DN[374] BU 1830

Substation No/ Name :- 294050 / 33/11 KV SUBSTATION

HINGANGHAT

Feeder No / Name : 204 / 11 KV TELANGKHEDI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			.4115	.3601
4			.463	.3772
6			.4973	.5487
7			.6001	.6173
8	.583	.5487	.6173	.5658
9	.5316	.5144	.5658	.5487
10	.5144	.4801	.5144	.7373
11	.463	.4458	.463	.463
12	.4458	.4458	.4458	.6516
13	.4287	.4287	.463	.463
14	.3772	.3772	.3601	.4287
15	.3944	.6344	.3944	.3772
16	.4115		.3772	.3772
17	.4287	.3944	.3944	.4115
18	.6173		.6344	.6173
19	.6516	.6344	.6173	.6859
20	.6516	.6173	.6001	.6001
21	.5658	.5658	.5487	.6001
22	.5316	.4801	.5144	.4973
23	.4115	.4115	.4115	.6859
24	.6687	.3772	.3601	.3601
Max	.6687	.6344	.6344	.7373
Min	.3772	.3772	.3601	.3601
Avg	.5104	.4904	.4883	.5226

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

HINGANGHAT (U) S/DN[374] BU 1830

Substation No/ Name :- 294050 / 33/11 KV SUBSTATION

HINGANGHAT

Feeder No / Name : 205 / 11KV IND-1 FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			.7545	.7202
4			.8059	.7888
6			.8573	.8573
7			.8573	.8745
8	.6516	.6344	.6344	.6516
9	.7545	.6516	.7202	
10	.7888	.6687	.6516	.6859
11	.7202	.703	.7373	.6687
12	.7202	.6173	.6516	.6859
13	.6687	.6344	.6687	.6173
14	.6687	.6173	.6344	.6173
15	.6516	.6173	.6001	.583
16	.6687	.6173	.6687	.583
17	.6859	.7373	.6859	.6859
18	.9602		1.0631	.9259
19	1.0288	1.046	1.2689	1.0117
20	.9945	1.2174	1.2517	1.2346
21	.8745	1.166	1.0974	1.0117
22	.6516	.9259	.9088	.9259
23	.4973	.8059	.7545	.823
24	.4801	.4458	.6859	.6859
Max	1.0288	1.2174	1.2689	1.2346
Min	.4801	.4458	.6001	.583
Avg	.7333	.7566	.8075	.7819

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

HINGANGHAT (U) S/DN[374] BU 1830

Substation No/ Name :- 294050 / 33/11 KV SUBSTATION

HINGANGHAT

Feeder No / Name : 206 / 11 KV INDUSTRIAL-II

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			.463	.4801
4			.4973	.463
6			.6001	.5658
7			.583	.583
8	.703	.6173	.6001	.583
9	.7202	.703	.6859	.7373
10	.7545	.6687	.6001	.6344
11	.7373	.6344	.6859	.6859
12	.703	.6516	.6687	.6001
13	.6516	.6687	.6516	.6516
14	.6344	.6516	.5658	.6859
15	.6001	.6173	.583	.6344
16	.6516	.6173	.6516	.6344
17	.6859	.6516	.6859	.7373
18	.823		.5316	.7545
19	.8745	.8573	.7888	.8402
20	.8402	.7888	.7716	.7716
21	.7716	.7202	.7202	.7202
22	.6859	.6344	.6344	.6516
23	.5658	.5487	.5316	.5316
24	.5316	.5316	.4973	.3258
Max	.8745	.8573	.7888	.8402
Min	.5316	.5316	.463	.3258
Avg	.7020	.6602	.6189	.6320

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

HINGANGHAT (U) S/DN[374] BU 1830

Substation No/ Name :- 294050 / 33/11 KV SUBSTATION

HINGANGHAT

Feeder No / Name : 207 / 11 KV TOWN FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			.3772	.3601
4			.4115	.4115
6			.4287	.4458
7			.4801	.463
8	.5316	.4973	.4801	.463
9	.5487	.5144	.5658	.5144
10	.5316	.5316	.5487	.4973
11	.5316	.5144	.583	.5487
12	.5658	.5144	.583	.4973
13	.5316	.5316	.6001	.5144
14	.4458	.4458	.4801	.4801
15	.4287	.4287	.4801	.4458
16	.4458	.3944	.463	.4458
17	.463	.4287	.5144	.4801
18	.6859		.7373	.6516
19	.823	.7373	.7373	.8573
20	.703	.6859	.6859	.703
21	.6516	.703	.6001	.6516
22	.5487	.5658	.5316	.5316
23	.4287	.4458	.4458	.4458
24	.4287	.3944	.3772	.3772
Max	.823	.7373	.7373	.8573
Min	.4287	.3944	.3772	.3601
Avg	.5467	.5208	.5291	.5136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

HINGANGHAT (U) S/DN[374] BU 1830

Substation No/ Name :- 294050 / 33/11 KV SUBSTATION

HINGANGHAT

Feeder No / Name : 208 / 11 KV APMC FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			.3086	.3258
4			.3258	.3429
6			.3772	.4287
7			.3601	.3944
8	.4287	.3258	.4458	.4115
9	.4458	.3429	.3944	.463
10	.4458	.3601	.3944	.4973
11	.4458	.4287	.4287	.5144
12	.4287	.4287	.4458	.463
13	.4287	.4801	.4287	.4973
14	.4458	.3944	.4115	.4458
15	.4458	.3944	.4115	.4287
16	.4115	.3944	.4115	.4287
17	.4458		.4115	.4458
18	.5316		.5316	.4973
19	.5316	.5316	.5487	.5316
20	.4801	.4973	.5144	.5144
21	.463	.463	.4801	.4801
22	.4115	.3944	.4115	.4115
23	.3429	.3258	.3772	.3601
24	.3429	.3258	.2915	.3258
Max	.5316	.5316	.5487	.5316
Min	.3429	.3258	.2915	.3258
Avg	.4398	.4058	.4148	.4385

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

HINGANGHAT (U) S/DN[374] BU 1830

Substation No/ Name :- 294050 / 33/11 KV SUBSTATION

HINGANGHAT

Feeder No / Name : 209 / 11 KV RESTHOUSE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			.5316	.583
4			.583	.5487
6			.5487	.5658
7			.6001	.6859
8	.6173	.6516	.6687	.703
9	.6687	.6344	.6173	.6687
10	.7202	.6173	.583	.7373
11	.583	.583	.5487	.5144
12	.5144	.4801	.463	.6001
13	.4973	.4801	.4801	
14	.4458	.3772	.3944	.4973
15	.4458	.4458	.4115	.4973
16	.4287	.3944	.4458	.4973
17	.5316	.5658	.4973	.6173
18	.8059		.8402	.8059
19	.8745	.9259	.8573	.9259
20	.8059	.8402	.823	.8745
21	.7716	.7716	.7545	.823
22	.6687	.6687	.6516	.703
23	.5487	.5144	.5487	.5658
24	.4801	.4801	.463	.4801
Max	.8745	.9259	.8573	.9259
Min	.4287	.3772	.3944	.4801
Avg	.6122	.5894	.5863	.6447

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

HINGANGHAT (U) S/DN[374] BU 1830

Substation No/ Name :- 294050 / 33/11 KV SUBSTATION

HINGANGHAT

Feeder No / Name : 210 / 11 KV BUS STAND FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.583
4				.6001
6			.703	.7202
7			.823	.8059
8	.4287	.6859	.8573	.8573
9	.8402	.823	.7716	.8745
10	.823	.7888	.8402	.8402
11	.7545	.7373	.703	.7545
12	.703	.703	.6516	.7888
13	.7202	.6516	.6516	.703
14	.6687	.6516	.6173	.7202
15	.6516		.4973	.6859
16	.6687		.4801	.6859
17	.7888	.6001	.5487	.8402
18	.9945		.9088	1.0117
19	1.0974	.8573	.9945	1.0974
20	.9945	1.0117	1.0288	.8745
21	.8402	.9259	.9602	.823
22	.823	.823	.823	.7888
23	.703	.823	.7202	.6859
24	.6687	.6344	.6344	.583
Max	1.0974	1.0117	1.0288	1.0974
Min	.4287	.6001	.4801	.583
Avg	.7746	.7655	.7481	.7773

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

HINGANGHAT (U) S/DN[374] BU 1830

Substation No/ Name :- 294050 / 33/11 KV SUBSTATION

HINGANGHAT

Feeder No / Name : 401 / 33 KV NANDORI INCOMER

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			7.0988	4.2181
4			7.6646	4.3724
6			8.4362	4.5782
7			8.5391	4.5782
8		8.7963	12.4486	8.5391
9		11.4712	12.3457	11.8827
10		12.0885	11.4198	12.3971
11		9.4136	9.3622	10.5453
12		9.0535	9.1564	15.4321
13		9.1564	9.3107	15.9465
14		6.2757	9.3107	14.9177
15		6.2757	9.2593	13.9918
16		6.1214	4.5782	
17	9.8251	6.2757	4.5268	6.2243
18	4.2696		5.5556	8.4362
19	4.2181	8.4877	5.7613	9.5679
20	4.2181	8.642	5.607	9.0021
21	3.9095	7.7675	4.8868	8.4362
22	3.7037	7.5103	4.784	7.6132
23	3.5494	6.7901	4.3724	6.7901
24		3.6008	6.5844	4.1667
Max	9.8251	12.0885	12.4486	15.9465
Min	3.5494	3.6008	4.3724	4.1667
Avg	4.8134	7.9829	7.6671	9.0818

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

HINGANGHAT (U) S/DN[374] BU 1830

Substation No/ Name :- 294050 / 33/11 KV SUBSTATION

HINGANGHAT

Feeder No / Name : 402 / 33 KV BHUGAON-HGT INCOMER NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			2.4177	4.6296
4			2.572	4.7325
6			2.6749	5.5041
7			2.7778	5.8642
8	9.928	5.144	2.9321	5.8642
9	10.2366	5.8642	5.9156	6.4301
10	10.4938	6.07	5.7613	6.1214
11	10.2366	5.7613	5.4012	6.5329
12	10.391		5.144	1.6461
13	10.751		5.0412	2.4177
14	9.7222		4.7325	2.7263
15	10.1338		3.858	2.6749
16	9.5679		4.0638	
17	9.8251		4.321	2.7263
18	6.2243		6.07	3.035
19	6.6358	2.9835	6.7387	3.2922
20	5.8642	2.9321	6.07	2.8807
21	5.3498	2.6749	6.0185	2.8292
22	5.144	2.6749	5.3498	2.7778
23	4.9897	2.3663	4.9383	2.572
24	8.4877	4.4753	2.2119	4.6296
Max	10.751	6.07	6.7387	6.5329
Min	4.9897	2.3663	2.2119	1.6461
Avg	8.4695	4.0947	4.5243	3.9943

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

HINGHANGHAT S/DN.[373] BU 4373

Substation No/ Name :- 294011 / 33/11 KV PIPERI S/STN

Feeder No / Name : 201 / 11 KV POHANA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.3944	.5144	.4287
2	.583	.3944	.5144	
3	.5144	.3944	.5144	.4287
4	.4458	.3772	.5144	.4115
5	.8573	1.1145	.4973	.3944
6	1.2346	1.3032	.4801	.4115
7	1.5432	1.3032	.463	.4801
8	1.4746	1.3717	1.2689	1.3375
9	1.4575	1.6461	1.7318	1.5261
10	1.3717	1.6289	1.7833	1.7372
11	.3772	.3601	1.7318	1.7372
12	.3601	.3429	1.7147	1.7187
13	.3772	.3086	1.6804	1.7002
14	.4115	.2743	1.6461	1.6632
15	.3772	.3086	1.5604	1.5339
16	.4115	.3086	.2572	.2987
17	.4115	.3429	.3772	.3174
18	.7716	.823	.5487	.8589
19	.8573	.9088	.9088	.9896
20	.8916	.8745	.8573	1.1016
21	.6859	.6859	.7888	.7468
22	.4973	.4973	.5658	.5415
23	.4801		.4973	.5415
24	.6001	.463	.4973	.3944
Max	1.5432	1.6461	1.7833	1.7372
Min	.3601	.2743	.2572	.2987
Avg	.7337	.7142	.9131	.9261

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

HINGHANGHAT S/DN.[373] BU 4373

Substation No/ Name :- 294011 / 33/11 KV PIPERI S/STN

Feeder No / Name : 202 / 11 KV SHEKAPUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.7716	.6859		
6	1.0974	.7545		
7	1.2346	.8745		
8	1.286		1.0288	.8745
9	1.2346	.5316	1.4403	1.2689
10	1.2003	.6001	1.4403	1.3306
11			1.3203	1.3121
12			1.3889	1.2012
13			1.3717	1.423
14			1.3717	1.3676
15			1.3546	1.3306
19	1.2003			
Max	1.286	.8745	1.4403	1.423
Min	.7716	.5316	1.0288	.8745
Avg	1.1464	.6893	1.3396	1.2636

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

HINGHANGHAT S/DN.[373] BU 4373

Substation No/ Name :- 294011 / 33/11 KV PIPERI S/STN

Feeder No / Name : 203 / 11 KV WADNER INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3258	.2058	.3429
2		.2915	.2058	.3429
3		.3086	.2058	.3429
4		.3258	.2058	.3258
5		.3258		.3086
6		.1715	.2229	.2743
7		.1715		.2401
8		.2858	.1715	.2401
9	.2058	.2572	.2195	.2572
10	.1905	.2058	.3086	.3772
11		.1372	.3086	.3395
12		.1372	.3086	.3772
13		.1029	.1905	.3018
14		.1372	.3258	.3395
15		.1372	.3429	.3395
16		.2401	.3429	.3961
17		.2229	.3086	.415
18	.1905	.2058	.3429	.3961
19	.1905	.2058	.3429	.3961
20	.2858	.2058	.3429	.3772
21	.3239	.2058	.3429	.3395
22	.3258	.2229	.3429	.2829
23	.3258		.3429	.2641
24		.3258	.2058	.3429
Max	.3258	.3258	.3429	.415
Min	.1905	.1029	.1715	.2401
Avg	.2548	.2242	.2789	.3316

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

HINGHANGHAT S/DN.[373] BU 4373

Substation No/ Name :- 294011 / 33/11 KV PIPERI S/STN

Feeder No / Name : 206 / 11 KV Tembha

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.7716	.823		
6	1.0288	.9945		
7	1.286	1.2003		
8	1.2346	1.3717	1.3375	1.2003
9	1.2689	1.5775	1.5775	1.5432
10		1.5432	1.6461	1.5154
11			1.4403	1.4415
12			1.3717	1.5339
13			1.3717	1.6263
14			1.5089	1.6448
15			1.5775	1.386
Max	1.286	1.5775	1.6461	1.6448
Min	.7716	.823	1.3375	1.2003
Avg	1.1180	1.2517	1.4789	1.4864

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

HINGHANGHAT S/DN.[373] BU 4373

Substation No/ Name :- 294017 / 33/11 KV KANGOAN S/STN

Feeder No / Name : 201 / 11 KV KANGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0792	.0754	.0754	.0641
2		.0792	.0717	.0754	.0641
3		.0754	.066	.066	.0641
4		.0754	.0604	.0585	.066
5		.0754	.0585	.0604	.0679
6		.0905	.08	.0622	.0698
7		.0641	.061	.0622	.0717
8	.3906	.3401	.4161	.431	.3768
9		.4372	.4858	.4588	.4807
10		.4858	.4961	.5079	.4752
11		.5079	.4534	.5243	.5243
12		.5668	.4588	.4961	.5079
13		.5921	.5182	.4801	.5506
14		.5121	.5992	.4586	.5182
15		.5121	.5281	.4481	.4534
16		.0415	.0415	.0509	.0377
17		.0453	.0453	.0585	.0453
18		.1334	.1094	.1528	.1603
19		.0156	.1603	.1547	.16
20		.1562	.1584	.1547	.1584
21		.1257	.1358	.1169	.1358
22		.0943	.0924	.1094	.0943
23		.0868	.0886	.0943	.0868
24		.0849	.0754	.0849	.0698
Max	.3906	.5921	.5992	.5243	.5506
Min	.3906	.0156	.0415	.0509	.0377
Avg	.3906	.2199	.2223	.2184	.2210

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

HINGHANGHAT S/DN.[373] BU 4373

Substation No/ Name :- 294017 / 33/11 KV KANGOAN S/STN

Feeder No / Name : 202 / 11 KV KAPSI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0754	.0679	.0698	.0622
2			.0736	.0641	.0698	.0622
3			.0717	.0585	.0622	.0604
4			.0679	.0566	.0585	.0604
5			.066	.0566	.0604	.0604
6			.083	.08	.0585	.0622
7			.0679	.0572	.0566	.066
8	.5407		.5079	.426	.4807	.4973
9	.5407		.5243	.5182	.5571	.5801
10			.5571	.5243	.5506	.5636
11			.5506	.3932	.5441	.5304
12			.639	.5571	.5281	.6133
13			.6226	.5407	.5535	.663
14			.5898	.5407	.5851	.6299
15			.5243	.5182	.5761	.6133
16			.0415	.0396	.0396	.0415
17			.0472	.0415	.049	.0453
18			.1181	.1019	.1339	.1377
19			.1524	.1509	.1358	.1448
20			.141	.1584	.1377	.1471
21			.1181	.1226	.1132	.1169
22			.0792	.0811	.1037	.0792
23		.083	.0754	.0811	.0868	.0754
24			.0754	.0717	.0736	.0641
Max	.5407	.083	.639	.5571	.5851	.663
Min	.5407	.083	.0415	.0396	.0396	.0415
Avg	.5407	.083	.2446	.2212	.2369	.2490

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

HINGHANGHAT S/DN.[373] BU 4373

Substation No/ Name :- 294017 / 33/11 KV KANGOAN S/STN

Feeder No / Name : 203 / 11 KV CHANKI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1037	.0943	.0962	.083
2		.1037	.0905	.0962	.083
3		.1019	.083	.0868	.0811
4		.0981	.0792	.0792	.0792
5		.0943	.0754	.0905	.0811
6		.132	.1029	.0773	.0811
7		.0868	.08	.0754	.083
8	.3725	.2984	.2652	.2984	.2721
9		.421	.3906	.3441	.426
10		.4001	.3239	.3681	.3953
11		.3841		.3704	.3795
12		.3521	.3321	.3048	.3401
13		.3887	.3321	.3395	.3521
14		.3795	.3321	.3593	.3953
15		.3321	.3637	.3005	.3521
16		.0641		.0547	.0641
17		.066	.0736	.0679	.0754
18		.1677	.1433	.1716	.1698
19		.2058	.198	.1792	.1981
20		.1981	.183	.1867	.1886
21		.1562	.1547	.1471	.1584
22		.1132	.1113	.1339	.1056
23		.1037	.1075	.1245	.1019
24		.1094	.0943	.1	.083
Max	.3725	.421	.3906	.3704	.426
Min	.3725	.0641	.0736	.0547	.0641
Avg	.3725	.2025	.1823	.1855	.1929

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

HINGHANGHAT S/DN.[373] BU 4373

Substation No/ Name :- 294017 / 33/11 KV KANGOAN S/STN

Feeder No / Name : 204 / 11 KV ALAMDOH AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5		.4961	.4545	.5409	
6		.6834	.6257	.6129	
7		.6722	.6818	.741	
8	.8578	.6241	.6946	.8962	.6658
9		.6241	.7682	.8962	.8162
10		.5601	.9794	.773	.7842
11					.877
12					1.0562
13					.9602
14					.8802
15					.8002
17			.9794		
Max	.8578	.6834	.9794	.8962	1.0562
Min	.8578	.4961	.4545	.5409	.6658
Avg	.8578	.61	.7405	.7434	.855

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

HINGHANGHAT S/DN.[373] BU 4373

Substation No/ Name :- 294022 / 33/11 KV AJANTI S/STN.

Feeder No / Name : 201 / 11 KV MIDC

SHEDDABLE FEEDER MIDC EQUIVALENT

Feeder KV- 11 / OUTGOING

HAVING WEEKLY STAGGERING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4344	.3439	.4344	.3801
2	.4344	.3439	.4344	.3801
3	.4163	.3439	.4163	.3801
4	.4163	.3439	.3982	.3801
5	.4298	.362	.3982	.3982
6	.4961	.4344	.4344	.4298
7	.5138	.4887	.5258	.4784
8	.7122		.7716	
9	.8505	.8817	.9054	
10	.9214	.8817	.8779	.7865
11	.9922	.8817	.8779	.7865
12	.9175		.7316	.9831
13	.9175	1.073	.7316	.9831
14	.9175	1.073	.7316	.9831
15	.9175	1.073	.8779	.852
16	.852	1.0059	.8779	.7209
17	.9214	.8779	.7316	.7545
18	.9273	.8505	.7545	.6584
19	.7316	.8505	.6348	.5853
20	.7316	.8505	.5853	.5853
21	.7545	.9054	.5853	.439
22	.6379	.7316	.5853	.439
23	.3801	.4344	.3982	.4527
24	.4706	.362	.4344	.3801
Max	.9922	1.073	.9054	.9831
Min	.3801	.3439	.3982	.3801
Avg	.6956	.6997	.6306	.6007

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

HINGHANGHAT S/DN.[373] BU 4373

Substation No/ Name :- 294022 / 33/11 KV AJANTI S/STN.

Feeder No / Name : 202 / 11 KV CHICHGHAT AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.176	.1595	.1753	.2279
2	.176	.1595		.2279
3	.1781	.1595		.2279
4	.1781	.1595	.1753	.2279
5	.7373	.9816	1.0513	.2254
6	.7712	.3898	1.073	.2229
7	1.0174	.4075	1.1401	.2058
8	1.004		1.2239	
9	1.0322	.415	1.4712	1.6827
10	.9667	.3185	1.5844	1.7924
11	.2027	.2027	.2263	1.7375
12	.1882		.2263	1.8673
13	.1882		.2263	1.9616
14	.2317		.3018	1.8484
15	.2317	.1593	.2641	1.9239
16	.2462	.2027	.3018	.2462
17	.2263	.2263	.3018	.3292
18	.2641	.2263	.3018	.2561
19	.1886	.2263	.3018	.3395
20	.1886	.1886	.3018	.2641
21	.1698	.1886	.2641	.2641
22	.1509	.1886	.3018	.2641
23	.1595	.1753	.2279	.2641
24	.176	.1595	.1753	.2303
Max	1.0322	.9816	1.5844	1.9616
Min	.1509	.1593	.1753	.2058
Avg	.3771	.2647	.5281	.7321

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

HINGHANGHAT S/DN.[373] BU 4373

Substation No/ Name :- 294022 / 33/11 KV AJANTI S/STN.

Feeder No / Name : 203 / 11 KV INDUSTRIAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.924	.9145	1.2012	.8779
2	.924	.8779	1.2012	.8779
3	.8871	.8413	1.2012	.8779
4	.8871	.823	1.1641	.8779
5	.8871	.8779	1.2012	.8413
6	.924	1.0242	1.1458	.8413
7	.9425	1.1088	1.1273	.8316
8	.823	1.1088	.7682	
9	.8139	1.1088	.8048	
10	.8987	1.5089	.7316	.6062
11	.8817	1.4335	.7316	1.0719
12	1.065	1.3392	.7682	1.3957
13	1.065	1.5089	.7316	1.1888
14	.9339	1.5089	.7682	1.0974
15	1.1361	1.2197	.7682	1.2437
16	1.3014	1.4523	.7682	1.5089
17	1.3957	1.382	.811	.9108
18	1.3535	1.4712	.7922	.7545
19	1.2437	1.358	.679	.7316
20	1.1706	1.4712	.679	1.0608
21	1.1706	1.4712	.6036	1.0608
22	1.2071	1.4266	1.2826	1.134
23	1.2012	1.2012	.9694	1.134
24	.961	.961	1.2012	.8962
Max	1.3957	1.5089	1.2826	1.5089
Min	.8139	.823	.6036	.6062
Avg	1.0416	1.2250	.9209	.9919

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

HINGHANGHAT S/DN.[373] BU 4373

Substation No/ Name :- 294022 / 33/11 KV AJANTI S/STN.

Feeder No / Name : 205 / 11 KV URBAN INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1526	.2149	.2328	.2507
2	.1526	.2149	.2328	.2507
3	.1526	.2149	.2328	.2507
4	.1526	.2149	.2328	.2507
5	.1543	.2149	.2328	.2507
6	.1543	.2328	.2328	.2481
7	.1543	.2328	.2481	.2481
8	.1029	.2507	.2658	
9	.1448	.2107	.2075	.1738
10	.1593	.2107	.3395	.4344
11	.1738	.2027	.4024	.4633
12	.1738	.1882	.3658	.4633
13	.1738	.1882	.3658	.4054
14	.1738	.1882	.3658	.4344
15	.1882	.1882	.3658	.4199
16	.1738	.0724	.4024	.4199
17	.2452	.1886	.415	.415
18	.2452	.2263	.415	.4187
19	.2641	.2075		.3814
20	.2641	.2263	.3018	.3772
21	.2829	.1886	.2641	.3772
22	.2829	.1905	.3018	.2378
23	.2507	.2507	.2507	.2452
24	.1475	.2328	.2507	.2507
Max	.2829	.2507	.415	.4633
Min	.1029	.0724	.2075	.1738
Avg	.1883	.2063	.3011	.3334

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

HINGHANGHAT S/DN.[373] BU 4373

Substation No/ Name :- 294022 / 33/11 KV AJANTI S/STN.

Feeder No / Name : 401 / 33 KV JAM AJANTI INCOMER NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9753	1.4266	1.7558	1.5524
2	1.9753	1.4266	1.7558	1.5524
3	1.9204	1.3717	1.7558	1.5524
4	1.9204	1.3717	1.7558	1.5524
5	2.6612	2.2177	2.7721	1.5524
6	2.7721	1.9959	2.7721	1.5364
7	2.8829	2.2177	2.8829	1.5912
8	2.9384	1.2197	3.0493	
9	3.4019	2.6886	3.2819	1.7558
10	3.4019	3.0727	2.3045	3.8958
11	2.6337	2.7435	2.3045	4.225
12	2.7984	1.5364	2.037	4.8285
13	2.7984	2.8532	2.037	4.6639
14	2.5789	2.8532	1.9239	4.4993
15	2.7435	2.7984	1.9239	4.5542
16	2.7435	2.8532	1.9239	3.0727
17	2.7435	2.9424	2.1502	3.0727
18	2.8292	2.9424	2.1502	3.1824
19	2.4897	2.8292	2.1502	2.3045
20	2.3765	2.8292	1.8107	2.037
21	2.3765	2.8292	1.8107	2.037
22	2.3765	2.7435	1.8107	1.9239
23	1.6461	1.7558	1.6461	2.1502
24	2.0851	1.5364	1.7558	1.5364
Max	3.4019	3.0727	3.2819	4.8285
Min	1.6461	1.2197	1.6461	1.5364
Avg	2.5446	2.2940	2.1467	2.6360

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

HINGHANGHAT S/DN.[373] BU 4373

Substation No/ Name :- 294030 / 33/11 KV WANI KUTKI S/Stn

Feeder No / Name : 201 / 11 KV TIRUPATI EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0343	.1029	.2572	.0343
2		.0343	.1029	.2572	.0343
3		.0343	.1886	.2401	.0343
4		.0343	.1715	.2229	.0343
5		.0343	.2058	.2229	.0343
6		.0343	.1886	.2058	.0343
7		.0343	.1715	.2058	.0343
8		.0343	.2058	.2229	.0343
9		.0343	.1886	.2058	.0343
10		.0343	.1715	.1886	.0343
11		.0343	.1886	.1715	.0343
12		.0857	.2058	.1715	.0343
13		.0686	.2229	.0514	.0343
14		.0686	.2058	.0514	.0343
15		.0343	.2229	.0514	.0343
16		.0343	.2058	.0343	.0343
17		.0343	.2058	.0343	.0343
18		.1029	.2229	.0343	.0343
19		.0514	.2401	.0343	.0343
20		.1029	.2572	.0343	.0343
21			.2401	.0343	.0343
22		.1029	.2229	.0343	.0343
23	.0343	.0686	.2401	.0343	.0343
24		.0343	.0686	.2401	.0343
Max	.0343	.1029	.2572	.2572	.0343
Min	.0343	.0343	.0686	.0343	.0343
Avg	.0343	.0507	.1936	.1350	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

HINGHANGHAT S/DN.[373] BU 4373

Substation No/ Name :- 294030 / 33/11 KV WANI KUTKI S/Stn

Feeder No / Name : 202 / 11 KV SONEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3086	.2229	.2915	.2915
2		.2915	.2229	.2743	.2743
3		.2915	.2058	.2915	.2743
4		.2743	.2058	.2743	.2743
5		.2915	.2229	.2743	.2915
6		.3258	.2572	.2915	.2915
7		.3258	.2401	.3086	.2915
8		.2915	.2058	.3086	.3086
9		.2915	.7716	.3944	.8745
10		.3601	.7716	.4115	.9088
11		.2743	.9259	.3086	.9431
12		.2572	.9431	.3086	1.1488
13		.2058	.9088	.2915	1.1145
14		.2401	.2229	.3086	1.1488
15		.2229	.2743	.3086	.9431
16		.2743	.3086	.3772	.3258
17		.2572	.463	.3772	.3601
18		.463	.6173	.4973	.5144
19		.5658	.703	.6173	.5658
20		.4458	.5487	.5316	.5316
21			.4458	.463	.3429
22		.3086	.3772	.3944	.3429
23	.3258	.2401	.3258	.3086	.3086
24		.3086	.2401	.2915	.2915
Max	.3258	.5658	.9431	.6173	1.1488
Min	.3258	.2058	.2058	.2743	.2743
Avg	.3258	.3094	.4430	.3544	.5401

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

HINGHANGHAT S/DN.[373] BU 4373

Substation No/ Name :- 294030 / 33/11 KV WANI KUTKI S/Stn

Feeder No / Name : 203 / 11 KV SONEGAON AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2058	.1543	.1886	.2229
2		.2058	.1543	.1886	.2229
3		.2058	.1543	.1715	.2229
4		.2058	.1715	.1715	.2229
5		1.0974		.9945	.2229
6		1.2346		1.1145	.2229
7		1.3375		1.3546	.2058
8		1.2689		1.6461	1.8861
9		1.3717	.2401	1.6118	2.0576
10		1.3032	.9431	1.6461	2.1948
11		.1715	1.2174	.1543	2.0576
12		.1715	1.4746	.2058	2.3663
13		.1886	1.5947	.2058	2.332
14		.2058	1.9719	.1715	1.6461
15		.2058	.2058		2.1948
16		.2058	.2401		.2058
17		.1715	.2229		.1715
18		.1715	.2058	.2058	.1715
19		.1715	.2229	.2058	.2058
20		.1886	.2229	.2401	.2058
21			.2058	.2401	.2058
22		.1886	.2058	.2401	.1886
23	.2058	.1715	.1886	.2401	.2058
24		.2058	.1715	.1886	.2229
Max	.2058	1.3717	1.9719	1.6461	2.3663
Min	.2058	.1715	.1543	.1543	.1715
Avg	.2058	.4719	.5084	.5422	.8359

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

HINGHANGHAT S/DN.[373] BU 4373

Substation No/ Name :- 294030 / 33/11 KV WANI KUTKI S/Stn

Feeder No / Name : 204 / 11 KV SIRUD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1029	.0857	.1029	.0686
2		.1029	.0857	.0857	.0686
3		.1029	.0857	.0857	.0686
4		.1029	.0857		.0686
5		.0857	.0857		.1029
6		.1029	.0857		.1029
7		.0857			.2058
8		.7716			.3429
9		1.0974			.3772
10		1.166			.3772
11		1.2346		.4973	.1372
12		1.2003			.1372
13		1.2003	.3429	.6687	.1543
14		1.1317		.6516	.1543
15		.9602	.8573	.6173	.1372
16		.1029	.7888	.4458	.1372
17		.1543		.3429	.1372
18		.1029	.6001	.1372	.0686
19		.1029	.3944	.0686	.0514
20		.1029	.3772	.0686	.0514
21			.1029	.0686	.0514
22		.1029	.1029	.0686	.0514
23	.1029	.1029	.1029	.0686	.0514
24		.1029	.1029	.1029	.0686
Max	.1029	1.2346	.8573	.6687	.3772
Min	.1029	.0857	.0857	.0686	.0514
Avg	.1029	.4488	.2679	.2551	.1322

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

HINGHANGHAT S/DN.[373] BU 4373

Substation No/ Name :- 294030 / 33/11 KV WANI KUTKI S/Stn

Feeder No / Name : 205 / 11 KV SIRUD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1543	.12	.12	.12
2		.1372	.1029	.1029	.1029
3		.1372	.1029	.0857	.1029
4		.12	.1029	.0686	.0857
5		.1372	.1029	.0857	.1029
6		.1372	.1029	.0857	.1029
7		.12	.12	.1029	.12
8		.12	.1029	.1372	.1029
9		.1886	.1372	.1543	.1715
10		.1886	.1886	.2058	.1543
11		.1543	.1715	.2058	.1029
12		.1886	.1715	.1543	.2229
13		.2058	.1886	.2058	.2058
14		.1029	.1886	.1715	.1886
15		.12	.1886	.1543	.2058
16		.1543	.1543	.1372	.1886
17		.12	.1372	.1715	.1543
18		.1543	.2229	.1886	.1886
19		.2058	.2229	.2058	.2401
20		.2058	.1886	.1715	.1886
21			.1372	.1372	.1715
22		.1372	.1372	.12	.1372
23	.1372	.12	.12	.1029	.12
24		.1543	.12	.12	.12
Max	.1372	.2058	.2229	.2058	.2401
Min	.1372	.1029	.1029	.0686	.0857
Avg	.1372	.1506	.1472	.1415	.1500

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

HINGHANGHAT S/DN.[373] BU 4373

Substation No/ Name :- 294030 / 33/11 KV WANI KUTKI S/Stn

Feeder No / Name : 206 / 11 KV BORGAON INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2689	1.6461	1.6289	1.9547
2		1.2517	1.6461	1.5947	1.9547
3		1.2517	1.6118	1.5775	1.9204
4		1.2689	1.5775	1.6461	1.8861
5		1.2689	1.5432	1.6289	2.0576
6		1.3032	1.4403	1.5775	1.5432
7		1.3032	1.4403	1.5432	2.0576
8		1.3032	1.4403	.9774	1.749
9		1.9204	1.8004	.9259	2.1605
10		1.6461	1.7318		2.0576
11		1.8519	1.7318		2.2977
12		1.7833	1.8004		2.1948
13		1.7147	1.7661		2.2977
14		1.7147	1.8004		2.2291
15		1.8861	1.8004		2.3663
16		1.9547	1.7147		2.0919
17		1.9547	1.749		2.1605
18		2.0919	1.7833	.3944	2.1948
19		2.1262	1.8861	.7888	2.332
20		2.0576	1.7318	.6859	2.2634
21			1.5775	1.7833	1.8176
22		1.7147	1.6289	2.0919	1.8519
23	1.3032	1.7147	1.5775	2.0576	1.8176
24		1.2689	1.6804	1.6118	1.9204
Max	1.3032	2.1262	1.8861	2.0919	2.3663
Min	1.3032	1.2517	1.4403	.3944	1.5432
Avg	1.3032	1.6357	1.6711	1.4071	2.0490

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

HINGHANGHAT S/DN.[373] BU 4373

Substation No/ Name :- 294060 / 33/11 KV SONEGAON(DHOTRA)

Feeder No / Name : 202 / 11 KV EKURLI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0373	.0305	.0747	.0474
2		.0373	.0305	.0747	.0474
3		.0373	.0305	.0747	.0474
4		.0373	.0457	.0747	.0316
5		.3439	.3353	.3439	.0316
6		.4344	.5792	.4887	.0474
7		.6344	.7773	.6687	.0457
8		.5144	.5487	.8573	.5335
9		.5658	.5944	.9259	.823
10		.503	.6687	.6859	.945
11		.0305	.0747	.0633	1.0059
12		.0305	.0747	.0316	1.0212
13		.0305	.0747	.0316	1.0212
14		.0305	.0747	.0316	1.0059
15		.0305	.0747	.0316	.8993
16		.0457	.0747	.0316	.0762
17		.0457	.056	.0316	.061
18		.061	.0747	.0633	.061
19		.061	.056	.0633	.061
20		.0457	.056	.061	.061
21		.0457	.0747	.0474	.061
22		.0457	.0747	.0633	.061
23	.056	.0457	.0747	.0474	.061
24		.0373	.0457	.0747	.0474
Max	.056	.6344	.7773	.9259	1.0212
Min	.056	.0305	.0305	.0316	.0316
Avg	.056	.1555	.1917	.2059	.3377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

HINGHANGHAT S/DN.[373] BU 4373

Substation No/ Name :- 294060 / 33/11 KV SONEGAON(DHOTRA)

Feeder No / Name : 203 / 11 KV DHANORA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.056	.056	.056	.0554
2		.056	.056	.056	.0554
3		.056	.056	.056	.037
4		.0747	.056	.056	.0554
5		.056	.056	.056	.0554
6		.056	.056	.056	.056
7		.0747	.0747	.056	.0739
8		.056	.056	.056	.0739
9		.056	.0934	.0747	.0554
10		.0747	.0934	.0739	.0934
11		.0747	.0934	.0739	.0934
12			.0747	.0739	.0934
13			.056	.0739	.0747
14			.0373	.0739	.0747
15		.056	.056	.0739	.056
16		.0747	.056	.0739	.056
17		.061	.056	.0739	.056
18		.0914	.0934	.1109	.112
19		.112	.112	.1294	.1307
20		.0914	.112	.0924	.112
21		.0934	.0934	.0739	.0934
22			.0747	.0739	.0747
23	.056		.056	.0554	.056
24		.056	.056	.056	.0554
Max	.056	.112	.112	.1294	.1307
Min	.056	.056	.0373	.0554	.037
Avg	.056	.0698	.0700	.0711	.0729

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

HINGHANGHAT S/DN.[373] BU 4373

Substation No/ Name :- 294060 / 33/11 KV SONEGAON(DHOTRA)

Feeder No / Name : 205 / 11 KV ALLIPUR GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3801	.3361	.3258
2		.3801	.2801	.3077
3		.362	.2801	.3077
4		.362	.3361	.2896
5		.3982	.3547	.3439
6		.4344	.3921	.3982
7		.4163	.4481	.3801
8		.3982	.4108	.3982
9		.4344	.4481	.4163
10		.4108	.3801	
11		.3353	.362	
12		.4108	.3801	
13		.3048	.362	
14		.3734	.3801	
15		.3361	.3801	
16		.4108	.4525	
17		.4481	.4344	
18		.5975	.5792	
19		.5975	.6335	
20		.6348	.6154	
21		.5601	.543	
22			.4163	
23	.3982		.3439	
24		.3982	.3921	.3258
Max	.3982	.6348	.6335	.4163
Min	.3982	.3048	.2801	.2896
Avg	.3982	.4265	.4142	.3493

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

HINGHANGHAT S/DN.[373] BU 4373

Substation No/ Name :- 294060 / 33/11 KV SONEGAON(DHOTRA)

Feeder No / Name : 206 / 11KV DHANORA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0747	.061	.056	.0474
2		.0747	.061	.056	.0474
3		.056	.061	.056	.0474
4		.056	.061	.056	.0474
5		.0747	.061	.0373	.3658
6		.0747	.0762	.0373	.4744
7		.0747	.0762	.056	.6249
8		.9088	.8078	.4287	.6859
9		1.1012	1.1126	.6001	.9297
10		.9755	1.1822	.503	.5792
11		.9755	1.1336		.0914
12		1.0059	1.0526	.8993	.0762
13		1.0212	1.0688	1.2193	.0762
14		1.0212	1.0202		.0762
15		.9602	1.046	1.2346	.0762
16		.0762	.0747	1.0822	.0762
17		.0762		.7773	.1067
18		.0914	.1307	.0791	.0457
19		.0762	.056	.0474	.0762
20		.0762	.056	.0949	.0762
21		.0762	.056	.0633	.061
22			.056	.0633	.061
23	.0747		.056	.0633	.061
24		.0747		.056	.0633
Max	.0747	1.1012	1.1822	1.2346	.9297
Min	.0747	.056	.056	.0373	.0457
Avg	.0747	.4092	.4258	.3439	.2030

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294004 / 33/11 KV SAMUDRAPUR S/STN

Feeder No / Name : 201 / 11 kv Samudrapur town
 feeder Feeder KV- 11 /
 OUTGOING

GAOTHAN FEEDER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2715	.1949	.1772	.2126
2		.2534	.1772	.1772	.2126
3		.2353	.1772	.181	.2126
4			.1772	.181	.2126
5			.1949	.181	.2126
6		.2353	.2303	.2172	.2481
7		.2355	.2481	.2481	.2658
8		.2279	.2303	.2658	.2658
9		.2303	.2303	.2658	
10		.2835	.2303	.2534	.2534
11		.2303	.2481	.2534	.2481
12		.2658	.2126	.2353	.2126
13		.2481	.2126	.2303	.2126
14		.2481	.1949	.2481	.2126
15		.2303	.2481	.2303	.2126
16		.2481	.2303	.2126	.2303
17		.2481	.2303	.2658	.2303
18		.3366	.3189	.3366	.3189
19		.3189	.3544	.3189	.3721
20		.3189	.3189	.3189	.3189
21		.2835	.2658	.2658	.2658
22		.2658	.2481	.2126	.2303
23	.2715	.2303	.2126	.1949	.2658
24		.2715	.1949	.2126	.1991
Max	.2715	.3366	.3544	.3366	.3721
Min	.2715	.2279	.1772	.1772	.1991
Avg	.2715	.2599	.2326	.2368	.2446

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294004 / 33/11 KV SAMUDRAPUR S/STN

Feeder No / Name : 202 / 11KV WAIGAON GOND AG SEPARATED AG FEEDERS HAVING SPECIAL
 FEEDER Feeder KV- 11 / DESIGN TRANSFORMER
 OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0819	.0587	.1006	.0838
2		.0819	.0587	.1006	.0838
3		.0819	.0564	.1006	.0838
4		.0819	.0594	.1006	.0838
5		.4588		.3163	.0838
6		.5407		.3163	.0838
7		.6062		.4428	.0838
8		.4755		.5693	.5376
9		.3864		.5693	
10		.4344		.5693	
11		.1189		.0838	
12		.0892	.5281	.0838	
13		.0714	.8509	.0838	
14		.0743	.7922		
15		.0743	.7628	.0838	
16		.0762	.7907	.1509	.5376
17		.088	.6299	.1341	.5376
18		.0892	.0838	.1006	.4428
19		.0892	.0829	.1174	.2683
20		.0892	.1006	.1006	.2214
21		.088	.1006	.1006	.192
22		.088	.1006	.0972	.1898
23	.0819	.0734	.0838	.1006	.0838
24		.0819	.0734	.0838	.1006
Max	.0819	.6062	.8509	.5693	.5376
Min	.0819	.0714	.0564	.0838	.0838
Avg	.0819	.1842	.3067	.1959	.2175

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294004 / 33/11 KV SAMUDRAPUR S/STN

Feeder No / Name : 203 / 11 KV DAHEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1402	.1029	.1063	.1063
2		.1402	.1029	.1063	.1063
3		.1052	.1029	.1063	.1063
4		.1029	.1029	.1063	.1063
5		.1052		.1063	.1063
6		.1029	.1372	.1417	.1063
7		.1227	.1029	.1612	.1063
8		.1372	.1029	.1595	.1063
9		.12	.12	.1595	
10		.1886	.1372	.1772	.1417
11		.1715	.1372	.1772	
12		.1543	.1372	.1417	
13		.1543	.1372	.1595	.1772
14		.1543	.1372	.1772	.1772
15		.1372	.1372	.1949	
16		.1715		.1772	.1772
17		.1372		.1417	.124
18		.1372		.1417	.1417
19		.1372	.1417	.1417	.1417
20		.1372	.1595	.1417	.1417
21		.1372	.1417	.1063	.1417
22		.1372	.1417	.1063	.1417
23	.1402	.12	.1063	.1417	.1417
24		.1402	.1029	.1063	.1417
Max	.1402	.1886	.1595	.1949	.1772
Min	.1402	.1029	.1029	.1063	.1063
Avg	.1402	.1372	.1246	.1411	.1320

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294004 / 33/11 KV SAMUDRAPUR S/STN

Feeder No / Name : 204 / 11kV Jamb AG Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1543	.1134	.0983	.1147
2		.1543	.1134	.0983	.1147
3		.1372	.1134	.0983	.1147
4		.1372	.1134	.0983	.1147
5		.1372	.12	.0983	.1147
6		.12	.1134	.1147	1.442
7		.12	.1134	.0983	.116
8		1.2967		.9998	.9686
9		1.5623		1.0623	
10		1.3592	1.0623	1.1405	1.4529
11		1.656	1.1873	1.1405	1.6129
12		1.7029	1.6871	1.6404	1.6288
13		1.6872	1.7029	1.5935	1.4842
14		1.5779	1.6091	1.4842	1.4998
15		1.2811	1.4685	1.2811	1.1702
16		.0972	1.3279	.0983	.125
17		.0819	.5155	.124	.0781
18		.1619	.1147	.1475	.1311
19		.1781	.1475	.1638	.1802
20		.1781	.1475	.1802	.1311
21		.1619	.1311	.1802	.1147
22		.1638	.1311	.1638	.1147
23	.1715	.1475	.1147	.1311	.1147
24		.1715	.1311	.1147	.0983
Max	.1715	1.7029	1.7029	1.6404	1.6288
Min	.1715	.0819	.1134	.0983	.0781
Avg	.1715	.6011	.5581	.5146	.5668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294004 / 33/11 KV SAMUDRAPUR S/STN

Feeder No / Name : 205 / 11KV WAIGAON HALDYA
 GAONTHAN Feeder KV- 11 /
 OUTGOING

GAOTHAN FEEDER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1829	.1772	.1612	.1791
2		.1829	.1772	.1612	.1791
3		.1372	.1595	.1612	.1791
4		.1372	.1595	.1612	.1772
5		.1677	.1417	.1791	.1791
6		.1829	.1595	.2149	.2149
7		.2134	.2126	.2149	.2303
8		.3189	.3155	.2686	.3224
9		.3856	.3366	.3045	
10		.3801	.3544	.2507	.2865
11		.2454	.3189	.2149	.2686
12		.2126		.2149	.2686
13		.2481	.2481	.2149	.2328
14		.2481	.2126	.2149	.2328
15		.2303	.2126	.197	.2149
16		.2303	.2149	.2149	.2149
17		.2126	.2303	.2686	.2686
18		.3189	.2865	.3045	.2865
19		.3189	.3224	.3366	.3224
20		.2835	.3045	.3224	.2126
21		.2481	.2507	.2772	.2149
22		.2126	.2126	.2149	.1791
23	.1981	.2126	.2149	.2149	.1791
24		.1981	.1949	.197	.1791
Max	.1981	.3856	.3544	.3366	.3224
Min	.1981	.1372	.1417	.1612	.1772
Avg	.1981	.2379	.2355	.2285	.2271

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294004 / 33/11 KV SAMUDRAPUR S/STN

Feeder No / Name : 206 / 11kv Jamb MIDC Feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9145	.6733	.7811	.8383
2		.9145	.6089	.7621	.8383
3		.9145	.6024	.7621	.8383
4		.9145	.5847	.7811	.8383
5		.9335	.7973	.7621	.9145
6		.9526	.8505	.8383	.9145
7		.9526	.7973	.8002	.9145
8		.9134	.9568	.724	1.0288
9		1.0277	.9568	.4763	
10		1.0277	1.0454	.5144	1.1431
11		1.0631	1.1462	.5144	1.2955
12		1.134	.9745	.5525	1.2955
13			.9922	.5335	1.3717
14		1.2403	1.0277		1.3717
15		1.2715	1.1163	.5716	1.3908
16		1.3466	1.1812	.6478	1.1812
17		1.3289	1.1431	.5906	1.467
18		1.2934	1.2384	.6668	1.4861
19		1.2757	1.0288	.6859	1.4861
20		.8859	.8954	.6097	1.1622
21		.8505	.5525	.5906	1.0479
22		.7973	.6478	.5906	.9717
23	.9145	.7796	.6859	.6097	.9526
24		.9145	.7265	.7621	.6097
Max	.9145	1.3466	1.2384	.8383	1.4861
Min	.9145	.7796	.5525	.4763	.6097
Avg	.9145	1.0281	.8846	.6577	1.1025

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294004 / 33/11 KV SAMUDRAPUR S/STN

Feeder No / Name : 207 / WAIGAON GOND GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1307	.0886	.0905	.0905
2		.1307	.0886	.0905	.0905
3		.112	.0886	.0905	.0905
4		.1086	.0886	.0905	.0905
5		.1267	.1029	.1086	.0905
6		.1494	.1417	.1086	.1086
7		.1494	.1417	.1448	.1448
8		.1433	.1595	.181	
9		.1791	.1949	.181	
10		.1595	.1417	.1433	.1448
11		.1254	.1417	.1086	.1086
12		.1063	.0886	.0905	.1086
13		.0886	.0709	.0905	.0905
14		.0886	.0716	.0905	.0905
15		.0857	.0716	.0905	.1086
16		.1063	.0724	.1086	.1086
17		.0886	.0724	.1086	.1086
18		.197	.1086	.1991	.181
19		.2126	.1991	.2172	.2353
20		.1949	.181	.1991	.1991
21		.1595	.1086	.1629	.1448
22		.1254	.1086	.1448	.1267
23	.1494	.1075	.1086	.1267	.1086
24		.1494	.0895	.1086	.0905
Max	.1494	.2126	.1991	.2172	.2353
Min	.1494	.0857	.0709	.0905	.0905
Avg	.1494	.1344	.1138	.1281	.1209

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294004 / 33/11 KV SAMUDRAPUR S/STN

Feeder No / Name : 208 / WAIGAON HALDIYA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1265	.0734	.0829	.1492
2		.1265	.0734	.0829	.1475
3		.1265	.0734	.0829	.1492
4		.1372	.0734	.0829	.1492
5		.1265	.0734		.1492
6		.1107	.088	.0663	.1492
7		.0949	.0587	.0663	.0663
8		.8025		.9922	.7682
9		1.1149		.9602	
10		.9976		1.0082	.9922
11		1.0562		1.0082	1.0242
12		1.0709		1.0082	1.0242
13		1.0562	1.2944	1.0883	.8642
14		1.0562	1.4563	.9602	
15		.9682	1.3496	.8802	
16		.0709	1.3763	.0829	
17		.0716	.9122	.0995	.8322
18		.0594	.5761	.116	.6722
19		.0734	.5121	.1492	.4801
20		.0734	.4001	.0995	.0995
21		.0743	.0829	.0995	.0995
22		.0734	.0838	.0995	.0829
23	.1265	.0743	.0829	.1326	.0829
24		.1265	.0743	.0829	.1341
Max	.1265	1.1149	1.4563	1.0883	1.0242
Min	.1265	.0594	.0587	.0663	.0663
Avg	.1265	.4029	.4587	.4057	.4058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294004 / 33/11 KV SAMUDRAPUR S/STN

Feeder No / Name : 209 / 11 KV JAM GAONTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2801	.1772	.1829	.1829
2		.2614	.1772	.1829	.1829
3		.2241	.1772	.1829	.1829
4		.2241	.1772	.1829	.1829
5		.2427	.1772	.2195	.1829
6		.2427	.2126	.2195	.1791
7		.2241	.2126	.1829	.2195
8		.2507	.2126	.2561	.2561
9		.2835	.2481	.2561	
10		.3189	.2835	.2561	.2195
11		.2835	.2481	.2561	.2195
12		.2481	.2481	.2561	.2561
13		.2126	.2481	.2195	.2561
14		.2126	.2481	.2195	
15		.2126	.2481	.2195	
16		.2126	.2195	.2561	
17		.2126	.2195	.2195	.2926
18		.3189	.3658	.3658	.3292
19		.3544	.4024	.3658	.3658
20		.3544	.3658	.3658	.3292
21		.3224	.2926	.2926	.2926
22		.2835	.2561	.2561	.2561
23	.2987	.2328	.2195	.2195	.2195
24		.2801	.197	.1829	.1829
Max	.2987	.3544	.4024	.3658	.3658
Min	.2987	.2126	.1772	.1829	.1791
Avg	.2987	.2622	.2431	.2424	.2394

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294004 / 33/11 KV SAMUDRAPUR S/STN

Feeder No / Name : 241 / 11 KV INCOMMER NO.1

Feeder KV- 11 / INCOMING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0269	.7202	.7888	.9619
2		1.0288	.6859	.8676	.9619
3		1.0098	.6733	.8676	.9619
4		.9997	.6733	.8676	.9619
5		1.0669	.8505	.8676	1.0185
6		1.105	.9259	.9619	1.0185
7		1.0751	.8916	.9054	1.0185
8		2.1434	.8916	1.9616	2.1879
9		2.5892	.9391	1.7541	
10		2.452	2.1971	1.8861	2.8858
11		2.8464	2.4006	1.8861	3.2065
12		2.1091	2.8807	2.5274	3.2065
13		3.0521	2.8881	2.452	3.0933
14		2.9321		1.7918	3.1687
15		2.6235	2.572	2.1125	2.7726
16		1.3889	2.7161	.7545	1.3203
17		1.3717	1.7541	.7167	1.5466
18		1.4232	1.358	.8299	1.6221
19		1.406	1.1883	.8676	1.6787
20		1.046	1.0185	.811	1.3014
21		.9945	.679	.7922	1.1694
22		.9088	.7922	.7733	1.094
23	1.0456	.8573	.7922	.7545	1.094
24		1.0562	.8059	.679	.7167
Max	1.0456	3.0521	2.8881	2.5274	3.2065
Min	1.0456	.8573	.6733	.679	.7167
Avg	1.0456	1.6047	1.3606	1.2282	1.6942

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294004 / 33/11 KV SAMUDRAPUR S/STN

Feeder No / Name : 404 / 33 kV SAMUDRAPUR INCOMMER NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		3.5504	2.0062	2.0513	2.2731
2		3.3608	1.9547	2.0513	2.2731
3		3.1367	1.9547	2.0513	2.2731
4		2.8006	1.9547	2.0513	2.2731
5		4.369	2.9835	3.77	3.4922
6		4.8731	3.3436	4.269	4.1581
7		5.257	3.6008	4.9343	4.3799
8		11.2654	3.6008	7.3737	8.2613
9		11.3683	4.2696	6.7638	
10		10.2366	5.3498	6.653	7.9281
11		8.834	3.9095	4.6016	5.7659
12		8.9506	10.3395	4.9343	5.8213
13		8.6934		5.0452	5.655
14		8.2819	10.8539	4.5462	4.3799
15		8.3608	10.2366	4.5462	3.9918
16		6.4301	8.6488	2.2731	3.2156
17		6.1214	7.4846	2.2731	4.8234
18		8.5905	3.9918	2.9938	5.1006
19		8.3848	3.9918	3.271	4.9343
20		6.5329	3.6037	3.0493	3.6037
21		4.5268	2.5503	2.6057	3.1602
22		3.6523	2.384	2.384	2.8275
23	3.5288	3.3436		2.2177	2.4949
24		3.5288	2.2634	1.9959	2.0513
Max	3.5288	11.3683	10.8539	7.3737	8.2613
Min	3.5288	2.8006	1.9547	1.9959	2.0513
Avg	3.5288	6.4354	4.6035	3.6961	4.1364

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294012 / 33/11 KV KANDHALI S/STN

Feeder No / Name : 201 / 11 KV KANDHLI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0187	.037	.0171
2	.0343	.0373	.037	.0171
3	.0343	.0373	.037	.0171
4	.0857	.0187	.037	.0171
5	.3944	.4801	.4525	.0171
6	.4115	.4961	.4887	.0171
7	.4801	.5281	.5611	.0171
8	.5144	.5761	.6154	.5144
9	.4801	.5851	.6344	.68
10	.506	.5535	.6001	.7274
11	.0373	.0373	.0343	.7432
12	.0373	.0373	.0343	.7432
13	.0373	.0187	.0171	.7432
14	.0373	.0187	.0171	.6958
15	.0373	.0373	.0343	
16	.0373	.0373	.0171	.0373
17	.0373	.0373	.0171	.0373
18	.0187	.0543	.0171	.0373
19	.0187	.0554	.0343	.0373
20	.0187	.0554	.0343	.0373
21	.0187	.0554	.0343	.0373
22	.0343	.037	.0171	.0373
23	.0373	.037	.0171	.0373
24	.0343	.0187	.037	.0343
Max	.5144	.5851	.6344	.7432
Min	.0187	.0187	.0171	.0171
Avg	.1424	.1612	.1609	.2304

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294012 / 33/11 KV KANDHALI S/STN

Feeder No / Name : 202 / 11 KV TAMBHARI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0343	.037	.0343
2	.0514	.0343	.0362	.0343
3	.0514	.0343	.037	.0343
4	.0514	.0343	.037	.9088
5	.0514	.0343	.037	.9259
6	.0514	.0343	.037	.9602
7	.0343	.0343	.037	1.0631
8	1.5775	1.3765	1.2127	1.3889
9	1.6964	1.7185	1.4918	1.4998
10	1.7185	1.7341	1.5947	1.3904
11	1.6404	1.5339	1.6289	.0339
12	1.5154	1.4217	1.6289	.0343
13		1.5181	1.5089	.0343
14	1.4661	1.4864	1.3032	.0343
15	1.3426	1.439	1.3032	
16	.0343	.0343	.0686	.0343
17	.0171	.0924	.0686	.0343
18	.0343	.0554	.0514	.0343
19	.0343	.0554	.0686	.0343
20	.0343	.0554	.0857	.0514
21	.0343	.037	.0514	.0514
22	.0343	.037	.0686	.0514
23	.0343	.037	.0686	.0514
24	.0514	.0343	.037	.0514
Max	1.7185	1.7341	1.6289	1.4998
Min	.0171	.0343	.0362	.0339
Avg	.5047	.5378	.5208	.3813

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294012 / 33/11 KV KANDHALI S/STN

Feeder No / Name : 206 / JSR and Gurukrupa express SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0173	.0362	.0171
2	.0171	.0171	.0362	.0171
3	.0171	.0171	.0362	.0171
4	.0171	.0171	.0362	.0171
5	.0171	.0171	.0362	.0171
6	.0343		.0362	.0686
7	.0686	.0905	.0362	.0514
8	.0686	.1294	.0362	.0686
9	.1663	.1109	.0343	.1663
10	.2427	.1109	.0171	.128
11	.2427	.1867	.0343	.128
12	.2614	.1294	.0171	.1294
13	.2614	.1294	.0171	.1294
14	.2614	.1478	.0171	.1294
15	.2987	.1494	.0171	
16	.1294	.1294	.0171	.1478
17	.1848	.1448	.0171	.1294
18	.1715	.1448	.0171	.1109
19	.1294	.1086	.0343	.1294
20	.1294	.0905	.0171	.1663
21	.052	.0543	.0171	.1663
22	.0886	.0543	.0171	.1663
23	.0173	.0362	.0171	.1294
24	.0343	.0173	.0362	.0171
Max	.2987	.1867	.0362	.1663
Min	.0171	.0171	.0171	.0171
Avg	.1220	.0891	.0264	.0977

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294012 / 33/11 KV KANDHALI S/STN

Feeder No / Name : 242 / 11 KV INCOMMER NO.2

Feeder KV- 11 / INCOMING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4525	.4298	.3982	.3801
2	.4525	.4298	.3801	.3801
3	.4525	.4119	.3801	.3801
4	.5068	.394	.3801	.3801
5	.7602	.9036	.7964	.3801
6	.8869	1.0277	.905	.5249
7	1.0498	1.134	1.0679	.5249
8	1.267	1.2934	1.267	1.1765
9	1.4175	1.5769	1.5023	1.6478
10	1.6301	1.5415	1.448	1.6832
11	.9922	.9745	.8869	1.701
12	1.0631	.8682	.8688	1.7187
13	1.134	.9745	.7783	1.8296
14	1.1163	.9391	.8507	1.6832
15	1.0985	.9745	.7421	
16	.9745	.9568	.7964	.9745
17	.9391	.9955	.7602	.8328
18	.9036	.9774	.7964	.9391
19	.8682	.9593	.8326	.9745
20	.7796	.8507	.724	.8682
21	.6556	.6697	.6154	.7796
22	.5316	.5249	.4887	.6201
23	.4477	.4163	.4163	.5493
24	.4706	.4119	.3982	.3982
Max	1.6301	1.5769	1.5023	1.8296
Min	.4477	.394	.3801	.3801
Avg	.8688	.8598	.7700	.9272

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294012 / 33/11 KV KANDHALI S/STN

Feeder No / Name : 401 / 33KV SINDI RLY

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4887	.4435	.4115	.3801
2	.4887	.3881	.4115	.3801
3	.4887	.3881	.4115	.3801
4	.7602	.7059	.4115	.3801
5	.7602	.8145	.7716	.4344
6	.8688	.8505	.823	.5973
7	1.1403	1.0631	1.0802	1.1946
8	2.4977	2.2874	2.3663	2.3891
9	2.6543	2.6852	2.8235	2.536
10	2.6543	2.2377	2.7149	2.6852
11	2.4086	2.1382	2.009	2.7349
12	2.1136	1.9662	.3258	2.5857
13	1.989	1.917	1.7375	2.4366
14	1.989	1.9662	1.9033	2.3868
15	1.989	1.8187	2.009	
16	.6099	.6036	.5973	1.8204
17	.6653	.6173	.5973	.499
18	.9774	.823	.8688	.6653
19	.8688	.823	.8688	.8871
20	.823	.7202	.7602	.8316
21	.6584	.6173	.7059	.7207
22	.5544	.463	.4887	.5544
23	.5544	.4115	.4344	.4435
24	.4887	.499	.4115	.4344
Max	2.6543	2.6852	2.8235	2.7349
Min	.4887	.3881	.3258	.3801
Avg	1.2288	1.1353	1.0810	1.2329

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294020 / 33/11KV SAKHARA

Feeder No / Name : 201 / 11kV Girad

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.3174	.3361	.3077	.2075
2	.1867	.3174	.3361	.3077	.2075
3	.1867	.3174	.3361	.3077	.2075
4	.1867	.3174	.3361	.2715	.2075
5	.4572	.3174	.3361	.2715	.2075
6	.4908	.3361	.2987	.181	.2263
7	.5083	.3361	.2987	.1867	.2641
8		.6348	.4108	.4031	.4207
9	.333	.2987	.5898	.7537	.6588
10	.3506	.2614	.5735	.6836	.5975
11	.1646	.5041	.5571	.6068	.4481
12	.2561	.8962	.5571	.631	.7095
13	.2012	.8775	.5407	.7108	.7842
14	.1829	.8589	.6718	.6485	.6535
15	.1646	.6535	.5407	.567	.6348
16	.168	.5601	.1267	.2054	
17	.2614	.4854	.181	.168	.2054
18	.3921	.3547	.2353	.2987	.2987
19	.4481	.4481	.3258	.3921	.3921
20	.4481	.4294	.3258	.3921	.3921
21	.4108	.4108	.3801	.3174	.3734
22	.3734	.3734	.3801	.2614	.3547
23	.3361	.3734	.3258	.2263	.3361
24		.3174	.3734	.3258	.2075
Max	.5083	.8962	.6718	.7537	.7842
Min	.1646	.2614	.1267	.168	.2054
Avg	.3077	.4582	.3906	.3927	.3911

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294020 / 33/11KV SAKHARA

Feeder No / Name : 202 / 11 KV Kora

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.4481	.5601	.5068	.415
2	.4108	.4481	.5601	.3982	.415
3	.4108	.4481	.5601	.3982	.415
4	.4108	.4481	.5601	.362	.415
5	1.3169	.4854	.5601	.362	.4338
6	1.3847	.5415	.4108	.2534	.4527
7	1.8404	.5415	.4294	.2801	.4715
8		2.1658	1.1949	.8939	1.0867
9	1.262	2.0165	1.0486	1.335	1.5089
10	1.2094	2.0351	1.1797	1.4737	1.4377
11	.439	1.4937	1.4091	1.2136	1.2136
12	.3292	1.3443	1.1797	1.1568	1.3443
13	.3475	1.0829	1.1797	1.1963	1.4003
14	.4024	.9709	1.1797	1.0692	1.4003
15	.3475	.7468	.3113	1.0166	1.2696
16	.2987	.2427	.2458	.3734	.2614
17	.3547	.2614	1.0679	.3734	.4108
18	.8029	.5788	1.0679	.6908	.6722
19	.9335	.8215	.6878	.8775	.8215
20	.8775	.7842	.8326	.8589	.7842
21	.7842	.7095	.8326	.7095	.6348
22	.5975	.6535	.8326	.5601	.6535
23	.4668	.6535	.543	.4527	.5601
24		.4481	.5975	.543	.415
Max	1.8404	2.1658	1.4091	1.4737	1.5089
Min	.2987	.2427	.2458	.2534	.2614
Avg	.7108	.8488	.7930	.7231	.7872

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294020 / 33/11KV SAKHARA

Feeder No / Name : 203 / mangrul

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2054	.2241	.2241	.2715	.1698
2		.2054	.2241	.2241	.2534	.1698
3		.2054	.2241	.2241	.2534	.1698
4		.2054	.2241	.2241	.2172	.1698
5		.5853	.2427	.2241	.2172	.1886
6		.6661	.2801	.2054	.2172	.1886
7		.7011	.2801	.1867	.168	.2075
8	.4108		.7282	.4854	.5609	.3856
9		.4733	.168	.7045	.8149	.6588
10		.5083	.1867	.6062	.6661	.5601
11		.1227	.1307	.5898	.5959	.4854
12		.1494	.112	.5243	.6661	.7282
13		.128	.112	.5735	.631	.7468
14		.128	.0934	.7373	.6836	.8029
15		.128	.8029	.7045	.5847	.7095
16		.1307	.8402	.181	.0934	.1307
17		.1494	.7655	.181	.112	.112
18		.3547	.4668	.2896	.2987	
19		.4668	.4481	.2896	.4294	.3361
20		.4481	.3734	.3077	.3921	.4294
21		.3361	.2987	.3077	.3174	.4108
22		.2801	.2614	.3077	.2241	.3361
23		.2241	.2614	.2715	.1886	.2987
24			.2241	.2427	.2715	.1698
Max	.4108	.7011	.8402	.7373	.8149	.8029
Min	.4108	.1227	.0934	.181	.0934	.112
Avg	.4108	.3092	.3322	.3674	.3803	.3724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294020 / 33/11KV SAKHARA

Feeder No / Name : 204 / 11 KV LAL NALA

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	17-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0109	
2			.0109	
3			.0109	
4			.0109	
5			.0109	
6			.0109	
8				.0073
9		.0066	.0128	.0072
10	.0073	.0115	.0127	
11	.0128	.0115	.0127	
12	.0128	.0115	.0127	
13	.0128	.0115	.0127	
14	.0128	.0131	.0127	
15	.0165	.0115	.0128	
16	.0131	.0127	.0129	
17	.0131	.0115	.0128	
18		.0066	.0075	
19		.0082	.0075	
20		.009	.0075	
21		.0109		
22		.0109		
23		.0109		
24			.0109	
Max	.0165	.0131	.0129	.0073
Min	.0073	.0066	.0075	.0072
Avg	.0127	.0105	.0112	.0073

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294020 / 33/11KV SAKHARA

Feeder No / Name : 241 / 11 KV INCOMMER

Feeder KV- 11 / INCOMING

DATE	15-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6161				.5847
2		.6161				.5847
3		.6161				.5847
4		.6161				.5847
5		1.9418				.6224
6	1.6244	2.1845				.6413
7	.3547	2.5415			.4481	.679
8					1.4548	1.4723
9		1.7353			2.1262	2.1605
10		1.7177			2.1091	1.9978
11		.567			1.8031	1.6991
12		.4755			1.6644	2.0725
13		.4755			1.8404	2.1472
14		.5304			1.7528	
15		.4755			1.595	
16		.4294			.4668	
17		.5041			.4854	
18		1.1576			.9896	
19		1.4003			1.307	
20		1.3256	1.1576		1.251	
21		1.1203	1.0082		1.0269	
22		.8775	.9149	.2353	.7842	
23		.6908			.6413	
24			.6722			.5847
Max	1.6244	2.5415	1.1576	.2353	2.1262	2.1605
Min	.3547	.4294	.6722	.2353	.4481	.5847
Avg	.9896	1.0279	.9382	.2353	1.2792	1.1725

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294025 / 33/11 Kv GIRAD

Feeder No / Name : 201 / Girad new

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4435	.5658	.3547	.3921
2		.439	.5658	.3547	.3734
3		.4344	.5658	.3547	.3734
4		.4435	.5281	.3547	.3734
5		.4481	.5658	.7842	.7842
6		.462	.6173	1.0456	.9522
7		.4668	.7202	1.0456	1.0829
8		.4481	.7202	1.2136	1.2136
9		.4527	.9149	1.1317	1.7924
10		.3772	.8402	.9602	1.2136
11		1.0288	.2801	.6602	.4854
12		1.3032		.5658	.4481
13		1.3203		.547	.4108
14		1.2517	.3547	.2641	.4294
15		1.0802	.3361	.3206	.4108
16		.8402	.3547	.415	.3921
17		.7888	.4294	.4108	.4481
18		.6859	.5601	.7095	.6722
19		.6602	.6722	.6722	.7316
20		.6413	.6161	.7282	.6722
21		.7167	.5601	.5975	.5914
22	.5601	.6224	.5228	.5975	.5601
23	.5121	.5658	.4854	.4108	.5175
24		.4854	.5658	.4854	.4108
Max	.5601	1.3203	.9149	1.2136	1.7924
Min	.5121	.3772	.2801	.2641	.3734
Avg	.5361	.6836	.5610	.6243	.6555

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294025 / 33/11 Kv GIRAD

Feeder No / Name : 202 / Mohagaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0739	.0754	.0747	.056
2		.0739	.0566	.056	.056
3		.0747	.0566	.056	.056
4		.0739	.0566	.056	.056
5		.0747	.4801	.5788	.5788
6		.0747	.5316	1.0269	.6535
7		.0732	.583	.8962	.8215
8		.7095	.6687	.8962	.9335
9		.7373	.8215	.823	.8775
10		.7888	.8402	.7716	.7842
11		.0566	.0373	.0377	.0373
12		.0566		.0566	.0373
13		.0377		.0377	.0373
14		.0566	.0373	.0566	.0373
15		.0377	.0373	.0377	.0373
16		.8916	.0373	.0377	.037
17		.9088	.056	.056	.0554
18		.6173	.0747	.1307	.1494
19		.583	.1494	.168	.1663
20		.5658	.1494	.1494	.1463
21		.132	.1307	.1307	.1267
22	.1294	.0943	.112	.112	.0924
23	.1097	.0754	.0934	.0747	.0732
24		.0924	.0754	.0747	.056
Max	.1294	.9088	.8402	1.0269	.9335
Min	.1097	.0377	.0373	.0377	.037
Avg	.1196	.2900	.2346	.2665	.2484

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294025 / 33/11 Kv GIRAD

Feeder No / Name : 203 / Dhondgaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1867	.1886	.168	.1494
2		.1848	.1698	.168	.1494
3		.1867	.1698	.168	.1494
4		.1646	.1698	.168	.1494
5		.1848	.2401	.2987	.3174
6		.2054	.3086	.4294	.3921
7		.2033	.3601	.5228	.4854
8		.4294	.463	.6348	.6722
9		.5144	.5415	.6344	.7468
10		.4115	.4854	.5316	.5788
11		.1509	.1307	.1509	.1307
12		.1509		.1509	.0934
13		.132		.1132	.0934
14		.1132	.0934	.132	.0934
15		.132	.0934	.1132	.112
16			.0934	.1509	.1097
17		.6344	.1307	.1307	.1307
18		.463	.2054	.2801	.3361
19		.3772	.3361	.3361	.3696
20		.3258	.2987	.3361	.3361
21		.2829	.2801	.2427	.2957
22	.2772	.2263	.2241	.1867	.2614
23	.2587	.1886	.2241	.168	.2218
24		.2218	.1886	.1867	.1494
Max	.2772	.6344	.5415	.6348	.7468
Min	.2587	.1132	.0934	.1132	.0934
Avg	.2680	.2639	.2452	.2667	.2718

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294025 / 33/11 Kv GIRAD

Feeder No / Name : 204 / 11kv OG Express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0183	.1663	.1509	.1494
2		.0181	.1478	.1494	.1494
3		.0179	.1478	.1494	.1494
4		.0171	.1478	.1494	.1494
5		.0185	.1646	.1494	.1494
6		.0183	.1478	.1494	.1494
7		.0187	.1294	.1494	.2972
8		.0162	.1848	.1509	.2957
9		.0057	.2587	.1463	.3361
10		.0514	.1494	.3881	.3715
11		.3982	.3361	.2587	.4829
12		.0537		.1848	.3206
13		.2926		.1294	.285
14		.0549	.1867	.463	.3343
15		.1097	.2614	.2229	.4087
16		.128	.1867	.1372	.4066
17		.128	.1663	.1307	.4066
18		.1463	.1478	.2801	.3772
19		.1463	.1478	.168	.3696
20		.1663	.1478	.1494	.2614
21		.1646	.1478	.1494	.1494
22	.0185	.1478	.1478	.1494	.1494
23	.0185	.1646	.1478	.1509	.1494
24		.0185	.1663	.1494	
Max	.0185	.3982	.3361	.463	.4829
Min	.0185	.0057	.1294	.1294	.1494
Avg	.0185	.0967	.1743	.1857	.2738

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294025 / 33/11 Kv GIRAD

Feeder No / Name : 241 / 11 kv INCOMER

Feeder KV- 11 / INCOMING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7207	.9997	.7468	.7468
2		.7207		.6859	.6687
3		.7282	.9431	.7468	.7282
4		.695	.9054	.7468	.7282
5		.7282	1.4403	1.8111	1.8298
6		.7655	1.5947	2.1285	2.1472
7		.7577	1.8176	2.4006	2.5393
8		1.6057	1.9719	.9522	
9		1.6804	2.5766	2.5892	3.0807
10		1.5947	2.3152	2.6235	2.5206
11		1.7541	.7842	1.1128	.8962
12		1.6975		.9619	.7468
13		1.9239		.8299	.6908
14		1.6032	.6722	.9619	.8775
15		1.4712	.7282	.7167	.7655
16		2.5206	.6722	.7545	.7468
17		2.452	.7842	.6687	1.0349
18		1.9204	.9896	1.4003	1.5684
19		1.6975	1.307	1.3443	1.6617
20		1.6289	1.2136	1.307	1.419
21		1.3014	1.1203	1.0288	1.1523
22	.9795	1.094	1.0082	1.0456	1.0642
23	.9149	.9997	.9522	.8029	.961
24		.8048	.9997	.8962	.7655
Max	.9795	2.5206	2.5766	2.6235	3.0807
Min	.9149	.695	.6722	.6687	.6687
Avg	.9472	1.3694	1.2284	1.2193	1.2757

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294025 / 33/11 Kv GIRAD

Feeder No / Name : 401 / 33 KV GIRAD INCOMMER
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7207	1.0185	.7282	.7282
2		.7282	.9619	.7282	.7282
3		.7207	.9619	.7282	.7282
4		.7282	.9054	.7282	.7282
5		.7207	1.5684	1.7924	1.7924
6		.7842	1.7364	2.1285	2.1285
7		.7842	1.9605	2.5766	2.5206
8		1.6078	2.1285	2.6235	2.9687
9		1.6975	2.5766	2.572	3.0807
10		1.5947	2.2965	2.6235	
11		1.7541	.7842	1.1317	.8962
12		1.6975		.9619	.7282
13		1.9239		.8488	.6722
14		1.5844	.6722		.8402
15		1.4712	.7282	.7356	.6687
16		2.5206	.6722	.7356	.7282
17		2.4691	.7842	.7282	1.0642
18		1.9033	.9522	1.4003	1.5684
19		1.6975	1.2883	1.3443	1.6804
20		1.6461	1.1763	1.2883	1.4003
21		1.3014	1.1203	1.1203	1.1763
22	.9979	1.0751	1.0082	1.0082	1.0534
23	.8962	1.0185	.9522	.7842	.9425
24		.8402	1.0185	.823	.7282
Max	.9979	2.5206	2.5766	2.6235	3.0807
Min	.8962	.7207	.6722	.7282	.6687
Avg	.9471	1.3746	1.2396	1.3104	1.2848

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294040 / 33 / 11KV NANDORI S/TN

Feeder No / Name : 202 / 11 KV NARAYANPUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1294	.1039	.1097	.1109
2	.1307	.112	.1097	.1109
3	.1294	.112	.1097	.1109
4	.1294	.112	.1097	.1294
5	.1294	.112	.128	.1109
6	.1663	.1307	.1463	.1478
7	.1478	.1307	.128	.1478
8	.1478	.5041	.6584	.2957
9	.1463	.5359	.8775	.8048
10	.1097	.8962	.8775	.5304
11	.1097	.8501	.7842	.4207
12	.0914	.8316	.8402	.6767
13	.0914	.0924	.6722	.6767
14	.0732	.0934	.6602	.7316
15	.0914	.0924	.5601	.6584
16	.9694	.8686	.0934	.0732
17	.9335	.8048	.0924	.0934
18	.8775	.8962	.2402	.2427
19	.7655	.2926	.3142	.3174
20	.6722	.2743	.2957	.2801
21	.5601	.2195	.2402	.2427
22	.5228	.1463	.1663	.1494
23	.4668	.128	.1294	.112
24	.1294	.112	.1097	.1294
Max	.9694	.8962	.8775	.8048
Min	.0732	.0924	.0924	.0732
Avg	.3217	.3522	.3522	.3043

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294040 / 33 / 11KV NANDORI S/TN

Feeder No / Name : 204 / 11 KV SAMUDRAPUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0185	.0187	.0366	.0185
2	.0185	.0187	.0366	.0185
3	.0185	.0187	.0366	.0185
4	.0185	.0187	.0366	.0185
5	.0185	.0187	.0366	.0185
6	.0185	.0187	.0377	.0185
7	.0185	.0187	.0366	.0185
8	.0185	.1307	.128	.1867
9	.0366	.1663	.2054	.1646
10	.0366	.2054	.2054	.1463
11	.0366	.1663	.168	.128
12	.0366	.1109	.168	.1463
13	.0366	.0739	.2054	.1646
14	.0366	.1294	.1867	.1829
15	.0366	.1294	.168	.1829
16	.2378	.0185	.0187	.0366
17	.2241	.0366		.0187
18	.1867	.0366	.0185	.0373
19	.112	.0366	.037	.0373
20	.1017	.0366	.037	.0373
21	.0934	.0366	.037	.0373
22	.0934	.0366	.0185	.0187
23	.0678	.0366	.0185	.0187
24	.0185	.0187	.0366	.0185
Max	.2378	.2054	.2054	.1867
Min	.0185	.0185	.0185	.0185
Avg	.0642	.0640	.0832	.0705

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294040 / 33 / 11KV NANDORI S/TN

Feeder No / Name : 205 / 11 kv Nakoda Industrial SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0924	.0747	.0732	.0739
2	.0924	.0747	.0732	.0739
3	.0924	.0747	.0732	.0739
4	.0924	.0747	.0732	.0739
5	.0924	.0747	.0732	.0924
6	.0924	.0747	.0732	.0924
7	.1109	.0934	.0732	.0739
8	.2772	.0747	.1829	.2402
9	.3841	.168	.168	.2012
10	.2561	.1867	.0747	.2926
11	.2926	.3696	.0934	.2926
12	.4024	.3696	.1494	.2926
13	.3658	.1478	.1867	.2561
14	.3292	.3174	.1867	.2195
15	.3292	.2241	.1494	.2743
16	.3475	.1663	.0747	.2561
17	.3361	.0914	.2772	.3361
18	.2801	.0914	.2772	.2427
19	.2054	.0732	.1867	.168
20	.0747	.0732	.0924	.0934
21	.0934	.0732	.0924	.0934
22	.0934	.0732	.0739	.0934
23	.0934	.0732	.0739	.0934
24	.0924	.0747	.0732	.0924
Max	.4024	.3696	.2772	.3361
Min	.0747	.0732	.0732	.0739
Avg	.2049	.1329	.1219	.1705

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294040 / 33 / 11KV NANDORI S/TN

Feeder No / Name : 241 / 11 KV INCOMMER NO.1

Feeder KV- 11 / INCOMING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.462	.4668	.3658	.4108
2	.462	.4481	.3658	.4066
3	.4435	.4294	.3658	.3881
4	.4435	.3921	.3658	.4108
5	1.3676	2.0351	1.829	.4108
6	1.885	2.3339	2.0119	.4805
7	2.0513	2.4272	2.1582	.4805
8	2.4025	3.8275	5.2309	3.9918
9	2.2314	4.8544	5.3586	5.6699
10	.695	5.23	5.0225	5.6516
11	.8962	3.0123	2.9874	5.2309
12	.7316	3.2895	3.1367	5.6699
13	.695	1.7364	3.006	5.6882
14	.6219	2.5873	2.7639	5.3589
15	.5853	2.4272	2.8006	4.225
16	1.6827	1.386	.0503	.5853
17	2.4086	1.134	.6653	.7282
18	2.4646	1.2437	1.0534	1.0456
19	2.6326	.9877	1.1458	1.1203
20	2.1472	.8779	.961	.9709
21	1.8111	.7316	.7947	.8029
22	1.6804	.5121	.5914	.5788
23		.439	.462	.5228
24	.499		.3841	.4251
Max	2.6326	5.23	5.3586	5.6882
Min	.4435	.3921	.0503	.3881
Avg	1.3609	1.8613	1.8282	2.1356

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294040 / 33 / 11KV NANDORI S/TN

Feeder No / Name : 242 / 11 KV INCOMMER NO.2

Feeder KV- 11 / INCOMING

DATE	19-DEC-17
HR	Load (MW)
8	.1494
Max	.1494
Min	.1494
Avg	.1494

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294040 / 33 / 11KV NANDORI S/TN

Feeder No / Name : 401 / 33 KV NANDORI INCOMMER
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.5601	.823	.7842
2	.5041	.7682	.7922
3	.4481	.823	.743
4	.4481	1.1523	.7842
5	1.7804	1.8656	.8573
6	2.0725	2.0851	.9522
7	2.2965	2.3045	.9054
8	6.4975	8.011	7.6589
9		9.2981	9.4925
10	8.3162	8.794	8.9986
11	6.9159	6.3855	8.4499
12		6.3855	9.2181
13		6.6095	9.3827
14		6.6655	9.0535
15		6.1614	7.4074
16		1.0642	.7133
17		1.1317	.9054
18		1.6409	1.4003
19	1.5364	1.7541	1.6244
20	1.4815	1.5432	1.4003
21	1.3169	1.2752	1.2323
22	.9877	1.0185	.9522
23	.823	.8488	.7842
24	.5601	.823	.8316
Max	8.3162	9.2981	9.4925
Min	.4481	.7682	.7133
Avg	2.2841	3.3013	3.5552

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294040 / 33 / 11KV NANDORI S/TN

Feeder No / Name : 402 / 33 KV SAKHARA

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3292	.2218
2			.2743	.2218
3			.2743	.2218
4			.2743	.2772
5			.3292	.2772
6			.3841	.3361
7			.3841	.3326
8			2.4143	2.6612
9		2.8006	3.3608	3.1276
10		3.2156	3.1367	2.7435
11		2.8829	2.6886	2.4143
12		2.8006	2.7446	3.0178
13		1.3443	2.9687	3.1276
14		1.8296	2.9127	3.0727
15		1.6244	2.8006	2.6886
16		1.2883	.2241	
17	.4481	1.262	.2772	.112
18		.3292	.5041	.3361
19		.6584	.6099	.4481
20		.6036	.5544	.3921
21		.6036	.4435	.3361
22		.3841	.3326	.2241
23		.3292	.2772	.2241
24			.3292	.2772
Max	.4481	3.2156	3.3608	3.1276
Min	.4481	.3292	.2241	.112
Avg	.4481	1.4638	1.2012	1.1779

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294040 / 33 / 11KV NANDORI S/TN

Feeder No / Name : 403 / 33 KV KHAMBADA
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1			.1109
2		.1097	.1109
3		.1097	.1109
4		.1097	.1109
5		.1097	.112
6		.1097	.1109
7	.4481	.1097	.1109
8			.1109
11	.1109		
12	.1109		
13	.1109		
14	.1109		
16	.112		
17	.1097		
18			.112
19			.112
21			.112
22			.112
23			.112
Max	.4481	.1097	.112
Min	.1097	.1097	.1109
Avg	.1591	.1097	.1114

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294045 / 33 KV MANDGAON

Feeder No / Name : 201 / 11 kv Mandgaon gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1029	.0686	.1029	.0857
2		.1029	.0686	.1029	.0857
3		.1029	.0686	.1029	.0857
4		.0857	.0686	.0857	.0686
5		.1029	.0686	.0857	.0686
6		.1029	.0686	.0857	.0857
7		.1029	.1029	.1029	.0857
8		.0857	.0857	.1029	.1029
9		.0857	.0857	.0857	.1029
10		.1029	.0857	.1029	.1029
11		.0686	.0857	.1029	.1029
12		.0686	.0857	.1029	.1029
13		.0686	.0857	.0514	.1029
14		.0514	.0686	.1029	.1029
15		.0686	.0857	.0857	.1029
16		.1029	.0857	.0857	.1029
17		.1029	.1029	.1029	.1029
18		.1543	.12	.1543	.1543
19		.1543	.1715	.1715	.1715
20		.1543	.1715	.1543	.1715
21		.12	.1543	.12	.1543
22		.0857	.1029	.1029	.12
23	.1029	.0857	.1029	.0857	.1029
24		.0857	.0686	.0857	.0857
Max	.1029	.1543	.1715	.1715	.1715
Min	.1029	.0514	.0686	.0514	.0686
Avg	.1029	.0979	.0943	.1029	.1065

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294045 / 33 KV MANDGAON

Feeder No / Name : 202 / 11 kv Derda

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5144	.5144	.4287	.3772
2		.5144	.5144	.4287	.3772
3		.5144	.4801	.4287	.3772
4		.4973		.4115	.3429
5		.4973	.4801	.4115	.3429
6		.4973	.4287	.4287	.3258
7		.4801	.4287	.4287	.3086
8		.5658	.5144	.4287	.3429
9		.6859	.6687	.5658	.5316
10		.823	.7888	.703	.5316
11		.7202	.7373	.7545	.6173
12		.8916	.823	.7545	.6516
13		.9431	.7716	.7545	.6859
14		.9431	.8402	.6859	.703
15		.8573	.7716	.6859	.6516
16		.8916	.7888	.703	.6344
17		.8573	.7202	.6859	.583
18		.6344	.703	.5487	.5658
19		.6516	.6516	.5658	.5658
20		.6344	.6516	.5144	.5658
21		.6001	.6173	.5144	.5144
22		.5144	.5144	.4287	.4458
23	.5316	.5144	.4801	.3944	.4115
24		.5144	.5144	.4287	.3772
Max	.5316	.9431	.8402	.7545	.703
Min	.5316	.4801	.4287	.3944	.3086
Avg	.5316	.6566	.6262	.5451	.4930

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294045 / 33 KV MANDGAON

Feeder No / Name : 203 / 11 kv KINGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6859	.6516	.6859	.5658
2		.6859	.6516	.6859	.5658
3		.6516	.6516	.6859	.5658
4		.6516	.6173	.6516	.5487
5		.6001	.6173	.6001	.5487
6		.6001	.6173	.5487	.5144
7		.5658	.7545	.5658	.4801
8		.8745	.9774	.7202	.6173
9		1.046	1.046	.9259	.8059
10		1.1145	1.2003	1.0631	.9774
11		1.166	1.2003	1.0288	1.0288
12		1.2517	1.2174	1.0631	1.1145
13		1.2174	1.2003	1.1145	1.0802
14		1.0802	1.2689	1.0802	1.0802
15		1.2174	1.2003	1.0802	1.166
16		1.0802	1.166	.9774	1.0974
17		1.0288	1.1145	.9774	.9774
18		.9088	.9945	.9259	.9259
19		.9431	.9431	.8402	.9431
20		.8745	.8916	.8059	.8573
21		.823	.823	.7202	.7716
22		.7202	.7716	.7202	.703
23	.7202	.7202	.7545	.5658	.6687
24		.703	.6516	.703	.5658
Max	.7202	1.2517	1.2689	1.1145	1.166
Min	.7202	.5658	.6173	.5487	.4801
Avg	.7202	.8838	.9159	.8223	.7987

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294045 / 33 KV MANDGAON

Feeder No / Name : 241 / 11 KV INCOMMER

Feeder KV- 11 / INCOMING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3032	1.2346	1.1831	.9945
2		1.3032	1.2346	1.1831	.9945
3		1.286	1.166	1.1831	.9602
4		1.286	1.166	1.1317	.9602
5		1.1831	1.166	1.0802	.9602
6		1.1831	1.0802	1.0288	.8745
7		1.1317	1.2003	1.046	.8573
8		1.5432	1.5261	1.2003	1.0288
9		1.8004	1.8004	1.6461	1.4746
10		2.0576	2.0919	1.9033	1.6461
11		2.1434	2.0576	1.8861	1.749
12		2.2119	2.1605	1.9204	1.9204
13		2.2291	2.1091	1.9719	1.9204
14		2.1091	2.2634	1.8861	1.9204
15		2.1948	2.1605	1.9033	1.9719
16		2.0748	2.0919	1.8004	1.8861
17		2.0576	2.0233	1.7833	1.6804
18		1.7147	1.869	1.6118	1.6632
19		1.7318	1.8347	1.5775	1.6804
20		1.5947	1.6461	1.4575	1.5604
21		1.5432	1.5089	1.3717	1.3375
22		1.286	1.2174	1.286	1.2003
23	1.3717	1.286	1.2174	1.0117	1.166
24		1.3032	1.2346	1.1831	.9945
Max	1.3717	2.2291	2.2634	1.9719	1.9719
Min	1.3717	1.1317	1.0802	1.0117	.8573
Avg	1.3717	1.6482	1.6275	1.4682	1.3917

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

HINGANGHAT DIVSION[183]

SAMUDRAPUR RURAL SDN[375] BU 1864

Substation No/ Name :- 294045 / 33 KV MANDGAON

Feeder No / Name : 406 / 33 KV MANDGAON INCOMMER NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3889	1.286	1.2346	1.0802
2		1.3889	1.286	1.2346	1.0802
3		1.3375	1.2346	1.2346	1.0288
4		1.3375	1.2346	1.1831	1.0288
5			1.1831	1.1317	1.0288
6		1.2346	1.1831	1.1317	.9774
7		1.1831	1.286	1.1317	.9259
8		1.5947	1.5947	1.286	1.0802
9		1.8519	1.8004	1.6975	1.5432
10		2.1091	2.1605	2.0062	1.6975
11		2.1605	2.1091	1.9547	1.8004
12		2.2119	2.2119	1.9547	1.9547
13		2.3148	2.1605	2.0576	1.9547
14		2.1605	2.3148	1.9547	2.0062
15		2.2119	2.2119	1.9547	2.0576
16		2.1605	2.1605	1.8519	1.9033
17		2.0576	2.0062	1.8004	1.749
18		1.749	1.9033	1.6975	1.6975
19		1.8004	1.8519	1.6975	1.749
20		1.6975	1.749	1.5432	1.6461
21		1.5432	1.6461	1.286	1.4403
22		1.3889	1.286	1.286	1.3375
23	1.4403	1.3889	1.286	1.1317	1.2346
24		1.3889	1.286	1.2346	1.0802
Max	1.4403	2.3148	2.3148	2.0576	2.0576
Min	1.4403	1.1831	1.1831	1.1317	.9259
Avg	1.4403	1.7244	1.6847	1.5282	1.4618

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

DEOLI RURAL S/DN[369] BU 1856

Substation No/ Name :- 294013 / 33KV BHIDI

Feeder No / Name : 201 / 11 KV BHIDI (AG)

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0924	.0899	.1151	.0977
2		.0943	.0949	.1113	.1006
3		.0962	.0977	.1132	.1006
4		.0981	.0933	.1169	.0988
5		.745	.9448	.7809	.0916
6		.9714	.9808	.8695	
7			1.0374	1.028	.0865
8		.9468	1.0343	1.2486	.8501
9		.702	1.1053	1.1424	1.4215
10		.9325	1.2561	1.1424	1.432
11		.1499		.1192	1.4706
12		.195		.1998	1.5895
13		.1998			1.6704
14		.1998	.1978	.0995	1.5552
15		.2318	.1952	.0805	1.551
16		.1932	.1973	.0993	.1924
17		.1683	.2263	.2451	.1377
18		.0841	.1433	.1536	.1019
19		.0874	.132	.1104	.0811
20		.0959	.1245	.1079	.0792
21		.0977	.1301	.1094	.0849
22	.1019	.099	.1245	.1097	.0849
23	.1	.0882	.1207	.1083	.0811
24		.0981	.0951	.1169	.0977
Max	.1019	.9714	1.2561	1.2486	1.6704
Min	.1	.0841	.0899	.0805	.0792
Avg	.1010	.2899	.4010	.3621	.5677

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

DEOLI RURAL S/DN[369] BU 1856

Substation No/ Name :- 294013 / 33KV BHIDI

Feeder No / Name : 202 / 11 KV SHIRPUR (AG)

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0868	.1086	.0792	.1169
2		.0981	.1017	.0792	.1063
3		.1056	.1	.0754	.1116
4		.0905	.0983	.1037	.1104
5		.9318	.9156	.9374	.1189
6		1.0336	.9496	.9751	.1339
7		1.0959	.9934	1.0826	.1171
8		1.0034	1.0343	1.0789	.929
9		.894	1.043	.9603	1.2276
10		.7018	.947	.9701	1.4083
11		.0641	.0729		1.3582
12		.0816	.0662	.0822	1.4092
13				.0547	1.3565
14		.0658		.0571	1.3882
15		.0574		.0642	1.3919
16		.0711		.0796	.0754
17		.075	.0943	.0924	.0811
18		.1043	.083	.1207	.0924
19		.1024	.0914	.1176	.1019
20		.1061	.0981	.1097	.1056
21		.1189	.1056	.1269	.1176
22	.0981	.1171	.1094	.1171	.1151
23	.0868	.1122	.1056	.114	.1083
24		.0792	.1134	.0868	.1134
Max	.0981	1.0959	1.043	1.0826	1.4092
Min	.0868	.0574	.0662	.0547	.0754
Avg	.0925	.3129	.3616	.3289	.5081

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

DEOLI RURAL S/DN[369] BU 1856

Substation No/ Name :- 294013 / 33KV BHIDI

Feeder No / Name : 203 / 11 KV Bhidi Gaothan

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1884	.1555	.15	.1591
2		.1848	.1373	.1445	.1555
3		.1738	.1427	.1294	.1518
4		.1353	.1249	.1294	.139
5		.1368	.128	.1257	.1538
6		.1682	.1372	.1335	.1679
7		.1573	.1536	.1528	.1573
8		.183	.1557	.1939	.1866
9		.179	.1461	.1665	.1902
10		.1821	.199	.1987	.1865
11		.2165	.1364	.1786	.1526
12		.1821	.1998	.1464	.1262
13		.1159	.1818	.1151	.1555
14		.1305		.0824	.1317
15		.0966		.1138	.203
16		.1288		.0993	.1146
17		.2067	.231	.1719	.1793
18		.2195	.2359	.2615	.2513
19		.2268	.2402	.2561	.3036
20		.2323	.268	.2579	.2791
21		.2122	.2181	.1994	.2231
22	.2012	.1624	.1628	.161	.1663
23	.1977	.1606	.1608	.161	.1628
24		.1939	.1538	.1552	.1591
Max	.2012	.2323	.268	.2615	.3036
Min	.1977	.0966	.1249	.0824	.1146
Avg	.1995	.1739	.1747	.1618	.1773

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

DEOLI RURAL S/DN[369] BU 1856

Substation No/ Name :- 294013 / 33KV BHIDI

Feeder No / Name : 204 / 11 KV Shirpur Gaothan

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1288	.1068	.1139	.0969
2		.1251	.1034	.112	.1006
3		.112	.0983	.0934	.1024
4		.0971	.0914	.0747	.1043
5		.1097	.0969	.0822	.1068
6		.1083	.1079	.1214	.1335
7		.1363	.1051	.1195	.1299
8		.1624	.1481	.1438	.1249
9		.1832	.1499	.11	.1116
10		.1305	.1364	.1127	.1262
11		.13	.1194	.1127	.1285
12		.0993	.0993	.0833	.128
13		.0852		.0793	.114
14		.0662	.0966	.1084	.076
15		.0833	.0927	.0805	.1024
16		.0828	.0897	.0771	.1344
17		.1134	.1139	.1866	.1344
18		.139	.1886	.1774	.1886
19		.1555	.2147	.1738	.2203
20		.2048	.2334	.1557	.2091
21		.1646	.1867	.1509	.1606
22	.14	.1136	.1214	.1043	.1195
23	.1344	.1102	.1176	.1006	.1214
24		.1307	.1068	.1176	.0969
Max	.14	.2048	.2334	.1866	.2203
Min	.1344	.0662	.0897	.0747	.076
Avg	.1372	.1238	.1272	.1163	.1280

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

DEOLI RURAL S/DN[369] BU 1856

Substation No/ Name :- 294013 / 33KV BHIDI

Feeder No / Name : 205 / 11 KV Wabgaon Gaothan
Feeder KV- 11 / OUTGOING

SEPARATED GAOTHAN FEEDERS

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1286	.1097	.1063	.1189
2		.1235	.1097	.1029	.1171
3		.1029	.1061	.0977	.1171
4		.1012	.1024	.0943	.1152
5		.1029	.1046	.0995	.1152
6		.1132	.1043	.1132	.1171
7		.1012	.1061	.0977	.1061
8		.0977	.112	.1012	.1079
9		.1166	.0999	.1023	.1176
10		.0814	.0999	.1656	.1152
11		.0805	.0747	.149	.0988
12		.0532	.0662	.1159	.086
13		.0662	.0662	.0828	.086
14		.0662	.2498	.0569	.0805
15		.0662	.0666	.1138	.0878
16		.0833	.0569	.1159	.084
17		.0892	.084	.1591	.0874
18		.1463	.1526	.2433	.1492
19		.1555	.1595	.1829	.1783
20		.156	.1663	.1738	.1866
21		.1481	.144	.15	.1423
22	.1372	.1189	.1166	.1262	.1115
23	.1355	.1152	.1149	.1225	.1115
24		.1303	.1116	.1097	.1115
Max	.1372	.156	.2498	.2433	.1866
Min	.1355	.0532	.0569	.0569	.0805
Avg	.1364	.1060	.1119	.1243	.1145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

DEOLI RURAL S/DN[369] BU 1856

Substation No/ Name :- 294021 / 33/11 KV WAIGAON

Feeder No / Name : 201 / 11 KV Waigaon

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.16	.2058	.2058
2	.2401	.2401		.2058
3	.2401	.2058		.2401
4	.2401	.2058		.2401
5	.2743	.2058		.2401
6	.3086	.1715	.2401	.2401
7	.3086	.2058	.2058	.3086
8	.3086	.2401	.2058	.3086
9	.3772	.1715	.2058	.3429
10	.3429	.1715	.1715	.3086
11	.2743			.2743
12	.2743	.2401	.2743	.2743
13	.2401	.2401	.2401	.2058
14	.2058	.2401	.2058	.2058
15	.2401	.2743	.2401	
16	.2401	.3086	.2401	.2401
17	.2058	.3086	.2401	.2058
18	.4115	.4801	.4458	.4115
19	.3086	.5487	.5487	.4801
20	.4115	.4458		.4801
21	.3086	.3772	.3772	.3772
22	.2743	.2743	.2743	.3429
23	.2401	.2401	.2058	.2743
24	.2743	.2058	.2058	.2058
Max	.4115	.5487	.5487	.4801
Min	.2058	.16	.1715	.2058
Avg	.2829	.2679	.2629	.2878

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

DEOLI RURAL S/DN[369] BU 1856

Substation No/ Name :- 294021 / 33/11 KV WAIGAON

Feeder No / Name : 202 / 11 KV Sarul(AG)

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1029	.12	.1029
2	.1029	.1029	.12	.1029
3	.12	.1372	.12	.12
4	.1372	.1543	.12	.1029
5	.5335	1.1431	.4268	.1029
6	.5335	1.1584	.8802	.12
7	.6268	1.4175	1.1203	.1372
8	.7868	1.387	1.467	1.3889
9	.9602	1.5394	1.467	1.6766
10	1.0059	1.3565	1.448	1.9357
11	.0686	.0686	.1543	1.9814
12	.0514	.12	.2915	2.0271
13	.0686	.0686	.1715	2.0233
14	.0857	.1372	.0857	1.989
15	.0857	.0686	.0857	
16	.0686	.0686	.0857	
17	.0686	.0686	.0686	
18	.1029	.12	.1029	.1029
19	.12	.12	.12	.12
20	.12	.1029	.12	.1372
21	.1029	.12	.12	.12
22	.1029	.12	.12	.12
23	.12	.12	.12	.12
24	.1029	.1029	.12	.1029
Max	1.0059	1.5394	1.467	2.0271
Min	.0514	.0686	.0686	.1029
Avg	.2574	.4127	.3773	.6968

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

DEOLI RURAL S/DN[369] BU 1856

Substation No/ Name :- 294021 / 33/11 KV WAIGAON

Feeder No / Name : 203 / 11 KV Aajgaon Gaothan

SEPARATED GAOTHAN FEEDERS

Feeder Feeder KV- 11 /
OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2058	.1543	.3086
2	.2572	.2401	.1715	.3258
3	.2401	.2058	.1543	.3429
4	.2572	.2401	.2058	.3601
5	.2058	.2401	.2401	.3429
6	.2401	.2743	.2743	.3772
7	.3086	.2915	.3258	.1715
8	.4458	.3258	.2572	.4973
9	.3429	.3601	.4115	.3429
10	.5144	.6344	.6173	.4287
11	.5487	.6001	.5658	.4287
12	.4801	.583	.583	.5144
13	.5316	.3601	.5144	.6001
14	.4287	.3944	.3944	.3772
15	.6001	.5487	.5658	
16	.5316	.5144	.583	.3601
17	.5316	.5658	.5144	.3601
18	.4115	.3601	.4458	.3429
19	.4287	.4287	.4115	.2572
20	.2915	.3944	.3258	.2229
21	.2229	.2401	.2229	.2058
22	.3258	.2401	.3429	.2401
23	.2743	.2401	.3772	.2743
24	.2572	.1886	.1543	.3258
Max	.6001	.6344	.6173	.6001
Min	.2058	.1886	.1543	.1715
Avg	.3715	.3615	.3672	.3482

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

DEOLI RURAL S/DN[369] BU 1856

Substation No/ Name :- 294021 / 33/11 KV WAIGAON

Feeder No / Name : 204 / 11 KV Sanskar Agro

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0576	2.1434	2.1262	2.0919
2	2.0919	2.0748	2.0919	2.0576
3	2.1434	2.0576	2.0919	2.0919
4	2.1776	2.0062	2.0576	2.1262
5	2.1605	2.0919	2.0576	2.1434
6	2.0062	2.0576	2.0233	2.0062
7	1.869	1.989	2.1605	2.1605
8	2.0919	2.0405	2.1776	2.0748
9	2.2291	1.7833	2.1262	2.0748
10	2.2862	2.3243	2.4387	2.1091
11	2.2672	2.3053	2.4577	2.2977
12	2.3434	2.2481	2.3815	2.1948
13	2.3243	2.1148	2.0767	2.1605
14	2.3624	2.3434	2.4387	2.3148
15	2.3053	2.553	2.3434	
16	2.2291	2.0957	2.2862	2.1948
17	2.3624	2.3053	2.3815	2.1605
18	2.0919	2.3624	2.2672	2.1605
19	1.8519	2.2672	2.3243	2.1091
20	2.0919	2.1719	2.21	1.989
21	1.8861	2.1719	2.3053	2.0233
22	1.989	2.3243	2.2672	2.0405
23	2.1434	1.8347	1.8176	2.0576
24	2.0576	2.0919	2.1262	2.1434
Max	2.3624	2.553	2.4577	2.3148
Min	1.8519	1.7833	1.8176	1.989
Avg	2.1425	2.1566	2.2098	2.1210

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

DEOLI RURAL S/DN[369] BU 1856

Substation No/ Name :- 294028 / 33/11 KV Deoli Substation

Feeder No / Name : 203 / 11 KV NAGZIRI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.12	.1543	.12
2				.12	.1543	.12
3				.12	.1372	.12
4				.12	.1372	.12
5				.12	.12	.12
6					.1543	.1372
7				.1372	.1543	.1543
8				.703	.1543	.5658
9	1.0974	1.2174		1.046	.1372	.8916
10	1.0974	1.0974	1.3889	1.2689	.0514	1.046
11	.3258	.3258	1.5261	1.2174		1.2514
12	.3772	.4115	1.406	1.406		.8895
13		.4458	1.4232	1.406	1.5775	1.2026
14		.4458	1.3717	1.3032	1.7147	.788
15		.4287	1.286	1.2689	1.6461	.7798
16		.3601	.3086	.3258	.9602	.8714
17		.3429	.3601	.3086	1.046	1.0064
18			.2572	.2572	.7202	.2401
19			.2743	.2743	.2401	.2572
20			.2572	.2572	.2401	.2572
21			.2058	.2401	.2058	.2229
22			.1543	.1886	.1715	.1715
23			.1372	.1543	.1433	.1543
24				.12	.1543	.12
Max	1.0974	1.2174	1.5261	1.406	1.7147	1.2514
Min	.3258	.3258	.1372	.12	.0514	.12
Avg	.7245	.5639	.7398	.5427	.4625	.4836

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

DEOLI RURAL S/DN[369] BU 1856

Substation No/ Name :- 294028 / 33/11 KV Deoli Substation

Feeder No / Name : 204 / 11 KV WATKHEDA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1067	
2				.0934	
3				.0934	
4				.0934	
5				.12	
6				.1334	
7				.1334	
8			.5182	.4801	.442
9	1.166		.9297	.3201	.8535
10	1.0802	1.0631	.9907	.9602	1.0059
11	.2572	1.7661	1.4918	1.2403	1.1379
12	.463	1.7833	1.7318	1.307	1.1553
13	.4801	1.6461	1.6804	1.307	1.26
14	.4801	1.6975	1.286	1.1336	1.1639
15	.5144	1.6118	1.4746	1.1469	1.1966
16	.4287	.3772	.3772	.9869	.0165
17	.3772	.4115	.3601	.9145	.0152
18			.2	.503	.2134
19			.2134	.1829	.2134
20			.2134		.2
21			.1867		.16
22			.0934		.12
23			.1334		.12
24				.12	
Max	1.166	1.7833	1.7318	1.307	1.26
Min	.2572	.3772	.0934	.0934	.0152
Avg	.5830	1.2946	.7426	.5688	.5796

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

DEOLI RURAL S/DN[369] BU 1856

Substation No/ Name :- 294028 / 33/11 KV Deoli Substation

Feeder No / Name : 205 / 11 KV DAHEGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1524	
2				.1372	
3				.1219	
4				.1067	
5				.0914	
6				.1219	
7				.0914	
8			.5068	.4725	.04
9	1.1831		.8402	.6859	.6802
10	1.0974	1.2689	.9069	.8993	.7335
11	.3429	1.286	1.2517	.9602	1.0762
12	.3601	1.1145	.8059	.945	.9182
13	.3944	1.1145	1.1317	.7926	.5575
14	.3944	1.0802	1.1145	.7926	.6079
15	.3944	1.2003	.9602	.9907	.8532
16	.3601	.2572	.2915	.884	.0166
17	.3258	.3086	.2915	.6535	.0145
18			.2591	.4801	.2896
19			.2743		.3048
20			.2896		.2743
21			.2591		.2439
22			.1829		.2134
23			.1677		.1829
24				.1677	
Max	1.1831	1.286	1.2517	.9907	1.0762
Min	.3258	.2572	.1677	.0914	.0145
Avg	.5392	.9538	.5959	.5025	.4379

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

DEOLI RURAL S/DN[369] BU 1856

Substation No/ Name :- 294032 / 33/11 KV ADEGAON

SUBSTATION

Feeder No / Name : 201 / 11KV GIROLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2058	.2229	.2229
2	.2058	.2058	.2058	.2229
3	.1886	.2058	.1886	.2058
4	.1886	.2058	.2058	.2058
5	.2058	.2572	.1543	.2058
6	.3258	.3258	.1886	.2229
7	.4458	.4115	.3429	.1886
8	.4287	.5487	.4458	.2743
9	.4115	.6173	.583	.4973
10	.2915	.6173	.4973	.5144
11	.1886	.1715	.12	.5658
12	.1715	.1886	.1029	.6516
13	.1543	.1715		.6344
14	.1715	.1886	.0857	.6173
15	.1715	.1715	.1372	.5487
16	.1715	.1543	.1372	.1715
17	.1886	.1886	.1715	.1715
18	.3086	.2915	.2743	.2915
19	.3601	.3429	.3429	.3258
20	.3429	.3429	.3258	.3258
21	.3086	.3086	.3086	.2915
22	.2572	.2572	.2572	.2401
23	.2229	.2229	.2229	.2058
24	.2229	.2058	.2058	.2058
Max	.4458	.6173	.583	.6516
Min	.1543	.1543	.0857	.1715
Avg	.2565	.2836	.249	.3337

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

DEOLI RURAL S/DN[369] BU 1856

Substation No/ Name :- 294032 / 33/11 KV ADEGAON

SUBSTATION

Feeder No / Name : 202 / 11KV GAUL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1543	.1715	.1543
2	.1886	.1543	.1543	.1543
3	.1715	.1543	.1543	.1543
4	.1543	.1543	.1543	.1372
5	.2058	.2058	.1372	.1543
6	.3258	.2915	.2058	.1715
7	.4115	.3944	.3601	.1715
8	.3772	.5144	.5144	.2401
9	.4458	.6173	.5658	.4973
10	.2401	.583	.5316	.583
11	.3086	.2572	.3429	.6344
12	.3601	.3772	.3772	.6859
13	.3601	.4115	.4287	.6859
14	.3086	.4115	.4115	.6687
15	.3429		.3772	.6687
16	.2743	.2743	.3772	.2401
17	.2572	.3086	.3429	.2401
18	.3086	.3601	.2915	.2915
19	.3772	.3772	.3601	.3429
20	.3429	.3429	.3429	.3086
21	.2743	.2915	.2915	.2743
22	.1886	.2058	.2058	.1886
23	.1715	.1715	.1715	.1543
24	.1715	.1543	.1543	.1543
Max	.4458	.6173	.5658	.6859
Min	.1543	.1543	.1372	.1372
Avg	.2808	.3116	.3094	.3315

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

DEOLI RURAL S/DN[369] BU 1856

Substation No/ Name :- 294032 / 33/11 KV ADEGAON

SUBSTATION

Feeder No / Name : 203 / 11KV ADEGOAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1543	.1543
2	.1886	.1543	.1372	.1543
3	.1715	.1543	.12	.1372
4	.1715	.1372	.12	.1372
5	.2058	.2058	.1372	.1543
6	.3601	.3429	.2401	.1715
7	.5144	.4458	.3772	.1543
8	.463	.583	.5658	.3601
9	.4801	.5487	.6859	.5487
10	.2572	.5487	.5658	.6516
11	.3601	.2915	.3429	.703
12	.3601	.3086	.4458	.7373
13		.4287	.3944	.7888
14	.3429	.3601	.3601	.7716
15	.5144	.4287	.2401	.6173
16	.4458	.4458	.4115	.3258
17	.3772	.3944	.3601	.2915
18	.2743	.2915	.2743	.3086
19	.3086	.2743	.3086	.3086
20	.2915	.2743	.2915	.3258
21	.2229	.2229		.2572
22	.1715	.1715	.1886	.1715
23	.1715	.1715	.1543	.1715
24	.1715	.1715	.1715	.1372
Max	.5144	.583	.6859	.7888
Min	.1715	.1372	.12	.1372
Avg	.3042	.3136	.3064	.3558

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

DEOLI RURAL S/DN[369] BU 1856

Substation No/ Name :- 294042 / 33/11 KV Deoli MIDC

Substation

Feeder No / Name : 201 / 11 KV Deoli Town No 2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.642	.5706	.6255	.5652
2		.6127	.5633	.6401	.5505
3		.6237	.5377	.6287	.5469
4		.6511	.5706	.5944	.5578
5		.6603	.5487	.6078	.5871
6		.6639	.6017	.5761	.6054
7		.6968	.7005	.6767	.6731
8		.7481	.6767	.7316	.6987
9		.7261	.6786	.7535	.7554
10		.7627	.7316	.7407	.7206
11		.7225	.6109	.6273	.6072
12		.6164	.5743	.5853	.5853
13		.6054	.5249	.5267	.5231
14		.5469	.4646	.5121	.5414
15		.5286	.5011		.522
16		.62	.5322	.4902	.5158
17		.984	.5944	.5139	.6182
18			.9907	.9236	.8871
19		1.0096	1.0316	.9913	1.0187
20		.9547	.9694	.9474	.9675
21		.8267	.8761	.8413	.8084
22		.6968	.6804	.6877	.6859
23	.7334	.5706	.653	.6237	.5396
24		.7042	.5743	.6573	.5908
Max	.7334	1.0096	1.0316	.9913	1.0187
Min	.7334	.5286	.4646	.4902	.5158
Avg	.7334	.7032	.6566	.6740	.6530

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

DEOLI RURAL S/DN[369] BU 1856

Substation No/ Name :- 294042 / 33/11 KV Deoli MIDC

Substation

Feeder No / Name : 202 / 11 KV MIDC No 1

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6363	.5716	.5716	.4534
2		.6497	.5792	.5811	.4592
3		.644	.5944	.503	.4363
4		.5792	.5849	.5563	.4477
5		.5639	.6059	.5373	.4039
6		.4973	.5144	.522	.3982
7		.4534	.4287	.4401	.3753
8		.5316	.503	.4744	.4572
9		.703	.6611	.5106	.6039
10		.6878	.7487	.583	.724
11		.5906	.5792	.5487	.6039
12		.6783	.703	.5925	.7202
13		.5144	.5963	.5811	.684
14		.6287	.6516	.3201	.6649
15		.5468	.6135		.6687
16		.6382	.6725		.7259
17	.6382	.7068	.6821		.7278
18	.6992	.7526	.8402		.7221
19	.5735	.5982	.583	.3163	.6268
20	.5354	.6554	.6592	.3829	.6763
21	.6497	.6916	.5735	.4572	.7811
22	.7297	.7926	.6382	.4306	.7506
23	.6687	.5354	.6001	.4496	.5677
24		.6268	.5582	.5944	.4592
Max	.7297	.7926	.8402	.5944	.7811
Min	.5354	.4534	.4287	.3163	.3753
Avg	.6421	.6209	.6143	.4976	.5891

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

DEOLI RURAL S/DN[369] BU 1856

Substation No/ Name :- 294042 / 33/11 KV Deoli MIDC

Substation

Feeder No / Name : 203 / 11 KV MIDC No 2

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8859	.7335	.8688	1.0021
2		.905	.7183	.8935	1.0193
3		.9202	.6878	.9145	1.0326
4		.8097	.6954	.9012	.9964
5		.7487	.7125	.9107	.9488
6		.6973	.7545	.9202	.6763
7		.6763	.6535	.7564	1.0269
8		.7087	.7049	.6363	1.0174
9		.8211	1.004	.703	.9964
10		.865	1.0307	.7735	.9945
11		.8612	.8783	.9774	1.0707
12		.562	.985	1.1107	1.3622
13		.7926	.9793	.9526	1.0936
14		.9564	1.0021	.8288	
15		.9164	1.0822		1.2949
16		1.1698	1.1622	1.1584	
17	.9964	1.2308	1.1927	1.0936	
18	1.0974	1.1107	1.0898	1.1088	.8372
19	1.0212	1.044	1.0288	1.0498	.8316
20	.9774	1.0841	1.0536	1.1088	.9314
21	.9888	.5506	.7068	.9621	1.1125
22	1.044	.7011	.9069	1.0136	1.0478
23	.9259	.7164	.8954	.9621	.9185
24		.8402	.7259	.8592	.9221
Max	1.0974	1.2308	1.1927	1.1584	1.3622
Min	.9259	.5506	.6535	.6363	.6763
Avg	1.0073	.8573	.8910	.9332	1.0063

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

DEOLI RURAL S/DN[369] BU 1856

Substation No/ Name :- 297008 / 132 KV Deoli

Feeder No / Name : 405 / 33 KV Mahalaxmi TMT
Express Fe Feeder KV- 33 /
OUTGOINGNON SHEDDABLE EHV INDUSTRIAL FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0091	.0457
2			.0091	.0457
3			.0023	.0457
4			.0023	.0457
5			.016	.0457
6			.0046	.0686
7		.1143	.0091	.0457
8		.0686	.0069	.171
9	.1143		.0086	.1795
10	.0914		.0114	.1758
11	.0514		.0137	.1735
12	.0686		.0069	.1335
13	.1372			.1365
14	.0686			.1348
15	.0514		.0017	.1449
16	.0189			.0069
17	.0223	.0171	.12	.0086
18	.0394	.0189	.12	.0171
19	.0223	.0206	.0206	.0023
20	.0023	.0023		.0137
21		.0046		.0046
22		.0046		.0069
23		.0091	.0229	.0091
24			.0046	
Max	.1372	.1143	.12	.1795
Min	.0023	.0023	.0017	.0023
Avg	.0573	.0289	.0217	.0722

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

DEOLI RURAL S/DN[369] BU 1856

Substation No/ Name :- 297008 / 132 KV Deoli

Feeder No / Name : 408 / 33 KV WARDHA

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.6118	1.6118	1.6118
2		1.6118	1.6118	1.5043
3		1.6118	1.5043	1.5043
4		1.6118	1.5043	1.5043
5		1.7193	1.5043	1.7193
6		1.9342	1.9342	1.9342
7		2.2565	2.364	2.2565
8		2.364	2.364	2.364
9	2.3663		2.4714	2.1527
10	2.2634		2.4714	2.0981
11	2.1605		2.2565	1.9012
12	1.9547		2.0416	1.642
13	1.749		1.8267	2.0416
14	1.6461		1.7193	1.7193
15	1.6461		1.6118	1.7193
16	1.6461		1.6118	1.7193
17	1.749	1.8267	1.7193	1.8267
18	2.6863	2.6863	2.6863	2.7938
19	2.9012	3.0087	3.0087	3.0087
20	2.7938	2.7938	2.7938	2.7938
21	2.5789	2.5789	2.5789	2.5789
22	2.2565	2.2565	2.364	2.364
23	1.9342	1.9342	1.9342	1.9342
24		1.7193	1.7193	1.6118
Max	2.9012	3.0087	3.0087	3.0087
Min	1.6461	1.6118	1.5043	1.5043
Avg	2.1555	2.0954	2.0506	2.0127

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

DEOLI RURAL S/DN[369] BU 1856

Substation No/ Name :- 297008 / 132 KV Deoli

Feeder No / Name : 701 / 132 KV MAHALAXMI TMT NON SHEDDABLE EHV INDUSTRIAL FEEDERS
 FEEDER Feeder KV- 132 / (CONTINUOUS PROCESS)(NO STAGGERING
 OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		35.0824	23.3128	25.2812
2		40.7408	29.4239	40.9671
3			36.5204	41.6736
4		34.856	41.3809	38.985
5		19.3416	41.1523	35.0824
6		24.8697	16.6804	13.6831
7		26.214	30.7819	30.5556
8		28.578	26.214	25.8437
9	24.6914		29.1976	22.4404
10	27.7778		27.1605	28.5058
11	26.3375		34.7508	25.5419
12	26.3375		28.0659	17.4486
13	25.7202		26.9776	22.7014
14	26.1317		32.3663	20.7984
15	26.3375		24.4993	20.9966
16	27.5721		31.5913	25.0938
17	25.7202	32.3663	27.1102	28.3494
18	26.5204	26.8336	31.2346	21.5021
19	31.1432	27.1605	25.4596	31.2346
20	26.9342	28.0659	25.2401	26.2552
21	28.7975	29.4925	26.0288	29.8766
22	30.1784	27.1102	30.5556	31.0471
23	39.8354	38.9301	40.9237	41.2255
24		26.557	34.0558	40.5145
Max	39.8354	40.7408	41.3809	41.6736
Min	24.6914	19.3416	16.6804	13.6831
Avg	28.0023	29.7466	30.0285	28.5668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

SELU RURAL S/DN[370] BU 3808

Substation No/ Name :- 294024 / 33/11 KV SINDI(RLY)

Feeder No / Name : 201 / 11 KV SINDI RURAL

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0377	.0267	.0355	.0302
2		.034	.0248	.0355	.0302
3		.0358	.0248	.0355	.0283
4		.0358	.0248	.0355	.0302
5		.0396	.0283	.0358	.0302
6		.0396		.0472	.034
7		.0472	.0302		.0321
8		.0485	.0358	.0396	.0419
9		.0407	.0343	.0305	.0504
10		.0373	.0373	.0248	.0305
11		.0302	.0229	.0207	.034
12		.0226	.0229	.0189	.5503
13		.0226	.0226	.0151	.0267
14		.0248	.0226	.0151	.0267
15		.0264	.0283	.017	
16		.0283	.029	.0358	.0314
17		.0517	.0299	.028	.0399
18		.0528	.0677	.0553	.0758
19		.0717	.0805	.083	.0869
20		.0698	.0647	.0648	.0773
21		.0528	.0566	.0415	.0547
22		.0377	.0411	.0321	.0396
23	.0415	.0302	.0355	.0283	.0343
24		.0396	.0286	.0355	.0283
Max	.0415	.0717	.0805	.083	.5503
Min	.0415	.0226	.0226	.0151	.0267
Avg	.0415	.0399	.0356	.0353	.0628

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

SELU RURAL S/DN[370] BU 3808

Substation No/ Name :- 294024 / 33/11 KV SINDI(RLY)

Feeder No / Name : 202 / 11 KV SINDI (RLY) AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0237	.0221	.0237	.0237
2		.0237	.0221	.0237	.0237
3		.0253	.0221	.0237	.0221
4		.0237	.0221	.0237	.0221
5		.3194	.3005	.3194	.0221
6		.3542	.3479	.3511	.0221
7		.3542	.4523		.0174
8		.3605	.5029	.5629	.4459
9		.3858	.5282	.6072	.5914
10		.37	.4333	.5503	.6357
11		.019	.0174	.0158	.623
12		.0142	.0142	.0142	.3922
13		.019	.0269	.0206	.6104
14		.0206	.0269	.0206	.661
15		.0221	.0206	.0269	
16		.0221	.0237	.0206	.427
17		.0237	.0285	.0269	.0206
18		.0237	.0237	.0221	.019
19		.0285	.0221	.0221	.0411
20		.0221	.0237	.0221	.0395
21		.0221	.0237	.0221	.0411
22		.0221	.0237	.0206	.0443
23	.0253	.0206	.0237	.0237	.0285
24		.0253	.0221	.0237	.0237
Max	.0253	.3858	.5282	.6072	.661
Min	.0253	.0142	.0142	.0142	.0174
Avg	.0253	.1061	.1239	.1212	.2086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

SELU RURAL S/DN[370] BU 3808

Substation No/ Name :- 294024 / 33/11 KV SINDI(RLY)

Feeder No / Name : 203 / 11 KV SINDI URBAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3259	.3041	.2746	.2973
2		.3224	.2919	.2729	.2955
3		.3045	.2817	.2693	.2937
4		.3027	.2699	.2551	.2955
5		.2963	.3005	.2926	.2986
6		.3955	.3678	.34	.4101
7		.4953	.3996		.4656
8		.5433	.4369	.5284	.4985
9		.5359	.4948	.4713	.4929
10		.4646	.4694	.4417	.5122
11		.4362	.3987	.4489	.3896
12		.414	.3439	.3222	.34
13		.3567	.3896		.3567
14		.377	.362	.3696	.3256
15		.3914	.3384	.2986	
16		.3821	.3863	.3693	.3
17		.3537	.3901	.3693	.3384
18		.6814	.638	.6276	.4961
19		.5874	.6371	.5999	.6232
20		.5484	.5487	.5322	.5828
21		.4742	.4561	.4525	.4829
22		.3636	.3474	.3224	.3833
23	.3456	.333	.287	.2924	.3101
24		.3403	.3113	.2835	.2937
Max	.3456	.6814	.638	.6276	.6232
Min	.3456	.2963	.2699	.2551	.2937
Avg	.3456	.4177	.3938	.3834	.3949

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

SELU RURAL S/DN[370] BU 3808

Substation No/ Name :- 294024 / 33/11 KV SINDI(RLY)

Feeder No / Name : 204 / 11 KV PALASGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0615	.0632	.0648	.0713
2		.0599	.0648	.0648	.0696
3		.0599	.0664	.081	.0713
4		.0599	.068	.081	.0713
5		.0648	.068	.0874	.0713
6		.0615	.0777	.0794	.0729
7		.0551	.0599		.068
8		.651	.6138	.5619	.5538
9		.8324	.7773	.7093	.6931
10		.8826	.8146	.7255	.7239
11		.7919	.8016	.6915	.7579
12		.8567	.7903	.5749	.7579
13		.7741	.7676	.7368	.6526
14		.7854	.7789	.7174	.6915
15		.7498	.7417	.6915	
16		.1231	.1053	.1296	.4437
17		.1668	.0518	.1215	.115
18		.1441	.0858	.102	.0858
19		.1425	.1134	.115	.1085
20		.1344	.1004	.1134	.0988
21		.1004	.1036	.0972	.0955
22		.1004	.081	.0713	.068
23	.0583	.068	.0648	.0713	.0632
24		.0615	.0615	.0648	.0713
Max	.0583	.8826	.8146	.7368	.7579
Min	.0583	.0551	.0518	.0648	.0632
Avg	.0583	.3245	.3051	.2936	.2816

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

SELU RURAL S/DN[370] BU 3808

Substation No/ Name :- 294029 / 33/11 KV SELOO

Feeder No / Name : 201 / 11 KV SELOO

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7973	.8238	.6878	.6154
2	.7602	.8328	.6516	.6154
3	.724	.8507	.6335	.543
4	.724	.6697	.6335	.543
5	.7602	.905	.905	.3077
6	.7783	.9774	1.0136	.6878
7	.9774	1.1222	1.1765	.724
8	1.3466	1.3756	1.5565	.8869
9	1.7194	1.7372	1.3643	1.086
10	1.7918	1.6655	1.4148	.8145
11	1.7194		1.3756	1.7737
12	1.8099	1.6832	1.3032	1.828
13	1.5203	1.134	1.8267	1.9004
14	1.5203	1.4506	1.7551	1.8642
15	1.4661	1.2357	1.7556	1.9004
16	1.6651	1.3466	1.7556	1.8446
17	1.6651	1.267	1.7194	1.9004
18	1.6108	1.2851	1.5927	1.5223
19	1.5203	1.2127	1.2308	1.4299
20	1.2308	1.0498	1.0136	1.1888
21	1.1584	.8688	.9231	1.0317
22	.9774	.8326	.905	.8869
23	.8688	.6697	.6878	.7059
24	.8507	.8507	.6878	.6154
Max	1.8099	1.7372	1.8267	1.9004
Min	.724	.6697	.6335	.3077
Avg	1.2484	1.1238	1.1904	1.1340

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

SELU RURAL S/DN[370] BU 3808

Substation No/ Name :- 294029 / 33/11 KV SELOO

Feeder No / Name : 202 / 11 KV LLOYDS W/W EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.2858	.2858	.2858
2	.6859	.2858	.2858	.2858
3	.6859	.2858	.2858	.2858
4	.6859	.2858	.2858	.2858
5	.6859	.2858	.2858	.2858
6	.7049	.2858	.2858	.2858
7	.7049	.2858	.2858	.2858
8	.724	.2858	.3048	.2858
9	.2858	.2858	.2858	.2858
10	.3048	.2858	.2858	.2858
11	.3048		.2858	.2858
12	.3048	.2858	.3048	.2858
13	.3048	.2858	.2858	.2858
14	.3048	.2858	.2858	.2858
15	.3048	.2858	.3048	.2858
16	.2858	.2858	.2858	.2858
17	.2858	.2858	.3048	.2858
18	.2858	.2858	.2858	.2858
19	.2858	.2858	.2858	.2858
20	.2858	.2858	.2858	.2858
21	.2667	.2858	.2858	.2858
22	.2667	.2858	.2858	.2858
23	.2858	.2858	.2858	.2858
24	.6859	.2858	.2858	.2858
Max	.724	.2858	.3048	.2858
Min	.2667	.2858	.2858	.2858
Avg	.4422	.2858	.2890	.2858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

SELU RURAL S/DN[370] BU 3808

Substation No/ Name :- 294029 / 33/11 KV SELOO

Feeder No / Name : 204 / 11 KV REHKI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3077	.2743	.2401	.2458
2	.3077	.2865	.2401	.2458
3	.3077	.2743	.2401	.2458
4	.3077	.2401	.2401	.2458
5	1.4685	1.3717	1.3889	.2458
6	1.7318	1.4746	1.5089	.2949
7	2.0405	1.9547	1.7318	.3113
8	1.8347	2.1176	2.2291	1.5074
9	1.9342	2.0008	2.1434	2.1948
10	1.773	1.8482	1.9033	2.2862
11	.2686		.2058	1.5546
12	.2149	.1526	.2058	2.1582
13	.2149	.1357		2.2314
14	.2149	.2204		2.1399
15	.2149	.2035	.3258	2.1399
16	.2534	.2149	.2543	.2195
17	.2353	.2058	.2458	.2926
18	.5068	.4973	.5571	.5434
19	.6516	.6344	.6226	.6584
20	.6335	.6001	.5898	.6268
21	.5249	.5144	.4588	.5304
22	.3801	.3772	.3605	.3841
23	.3077		.2785	.2926
24	.3258	.2896	.2572	.2458
Max	2.0405	2.1176	2.2291	2.2862
Min	.2149	.1357	.2058	.2195
Avg	.7067	.7222	.7376	.9101

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

SELU RURAL S/DN[370] BU 3808

Substation No/ Name :- 294029 / 33/11 KV SELOO

Feeder No / Name : 205 / 11 KV WADGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3801	.2715	.2543	.2458
2	.362	.2572	.2543	.2458
3	.362	.2865	.2374	.2458
4	.362	.2401	.2374	.2458
5	.7522	.9774	.8309	.2458
6	1.0566	.9602	.9326	.3113
7	1.2894	1.4118	1.2378	.3113
8	1.2209	1.6832	1.6617	.9503
9	1.4148	1.7295	1.7126	1.4506
10	1.379	1.6108	1.5261	1.1641
11	.2328		.2204	1.5939
12		.2204	.2204	1.8267
13		.2035	.1928	1.8446
14		.2204	.1886	1.4685
15	.2328	.1865	.1865	1.8804
16	.2353	.2204	.2058	.2149
17	.2534	.2204	.1966	.3045
18	.543	.5426	.4752	.5373
19	.7059	.6613	.5407	.6626
20	.6878	.6274	.5571	.6697
21	.5121	.6104	.4752	
22	.362	.3561	.3277	.4298
23	.2896	.2713	.2622	.3582
24	.394	.2896	.2543	.2458
Max	1.4148	1.7295	1.7126	1.8804
Min	.2328	.1865	.1865	.2149
Avg	.6204	.6112	.5495	.7588

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

SELU RURAL S/DN[370] BU 3808

Substation No/ Name :- 294029 / 33/11 KV SELOO

Feeder No / Name : 206 / 11 KV HINGNI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3521	.3018	.2818	.2458
2	.3521	.3018	.2818	.2458
3	.3353	.3018	.2652	.2458
4	.3521	.3018	.2896	.2622
5	.4694	.5365	.5792	.2622
6	.5365	.6706	.5801	.3277
7	.8215	.663	.663	.3277
8	.7042	.779	.7293	.5079
9	.6539	.5243	.2683	.7459
10	.5533	.547	.4973	.7545
11	.2515		.1677	.1341
12	.1844	.218	.1326	.0335
13	.1844	.218	.1543	1.0395
14	.1844	.1658	.1509	1.0059
15	.1677	.1989	.1844	.7545
16	.2321	.1989	.2058	.1844
17	.4144	.1989	.1802	.2347
18	.4144	.4641	.4588	.4694
19	.547	.5967	.5243	.5868
20	.547	.5801	.5243	.5365
21	.4807	.4973	.4424	.4694
22	.3481	.3978	.3441	.3688
23	.3149	.3149	.2785	.3018
24	.3688	.2984	.2984	.2622
Max	.8215	.779	.7293	1.0395
Min	.1677	.1658	.1326	.0335
Avg	.4071	.4033	.3534	.4295

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

SELU RURAL S/DN[370] BU 3808

Substation No/ Name :- 294029 / 33/11 KV SELOO

Feeder No / Name : 402 / 33 KV HINGNI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3086	.3086	
2	.3086	.3086	.3086	.2263
3	.2572	.3086	.3086	.2263
4	.3086	.3086	.3086	.2263
5	.3086	.3155	.3086	.2263
6	.3086		.3086	.2829
7	.4115	.3189	.3601	.3961
8	1.9239		1.8004	2.2634
9	2.0576	2.6235	2.4177	2.8607
10	2.572	2.6749	2.7263	2.7566
11	2.7263		3.035	2.9127
12	2.572	3.2922	2.7263	2.9127
13	2.8292	2.6235	2.6235	2.7046
14	2.8292	2.7263	2.1605	2.6006
15	2.6235	2.6235	2.6749	2.7046
16	.6173	.4115	.6173	.5721
17	.6173	.4115	.7356	.6241
18	.463	.5144	.7922	.6687
19	.4115	.5144	.6224	.6241
20	.4115	.463	.3961	.5721
21	.3601	.3601	.3395	.4161
22	.3086	.3601	.2829	.3641
23	.3086	.3086	.4527	.3121
24	.3086	.3086	.3086	.2263
Max	2.8292	3.2922	3.035	2.9127
Min	.2572	.3086	.2829	.2263
Avg	1.0897	1.0517	1.1218	1.2035

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

SELU RURAL S/DN[370] BU 3808

Substation No/ Name :- 294031 / 33/11 KV SELDOH

Feeder No / Name : 201 / 11 KV MEL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0754	.0474	.0549	.0754
2		.0943	.0474	.0549	.0754
3		.1132	.0474	.0549	.0754
4		.132	.0474	.0549	.0754
5		.132	.0474	.0549	.0754
6		.132	.0791	.0549	.0754
7		.132	.0633	.0549	.0754
8		.2033		.1928	.1663
9		.2772	.2372	.2658	.2587
10		.3109	.253	.2835	.2587
11		.2846	.3641	.3142	.253
12		.3321	.3429	.2957	.2688
13		.3321	.3688	.2926	.0617
14		.2846	.3258	.2587	
15		.2688	.2835	.2772	
16		.0316	.0554	.0566	
17		.0474	.0554	.0566	
18		.0633	.0554	.0754	.0474
19		.0633	.0549	.0754	.0474
20		.0633	.0554	.0754	.0633
21		.0474	.0732	.0754	.0474
22		.0633	.0732	.0754	.0474
23	.0754	.0633	.0554	.0754	.0474
24		.0754	.0474	.0549	.0754
Max	.0754	.3321	.3688	.3142	.2688
Min	.0754	.0316	.0474	.0549	.0474
Avg	.0754	.1510	.1339	.1327	.1085

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

SELU RURAL S/DN[370] BU 3808

Substation No/ Name :- 294031 / 33/11 KV SELDOH

Feeder No / Name : 202 / 11 KV KELZAR GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	18-DEC-17
HR	Load (MW)
17	.1457
Max	.1457
Min	.1457
Avg	.1457

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

SELU RURAL S/DN[370] BU 3808

Substation No/ Name :- 294031 / 33/11 KV SELDOH

Feeder No / Name : 204 / 11 KV SINDI RLY GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3658	.3475	.3012	.3475
2		.3658	.3475	.2835	.3475
3		.3658	.3292	.2686	.3475
4		.3658	.3292	.2686	.3109
5		.4024	.3292	.2835	.3109
6		.439	.4024	.3012	.3326
7		.4207	.4755	.4508	.4572
8			.4572	.4161	.4572
9		.4024	.4755	.4031	.4755
10		.4755	.3841	.4508	.4024
11		.3841	.3506	.4024	.3658
12		.2926	.3772	.2957	.3109
13		.2743	.3772	.5487	.3475
14		.3292	.3467	.3109	.2743
15		.2561	.3467	.2561	.3475
16		.3841	.3224	.3142	.3475
17		.4024	.3506	.3109	.3658
18		.5487	.4748	.4755	.567
19		.567	.4801	.5121	.5304
20		.5121	.4382	.4207	.4938
21		.4572	.394	.4938	.4572
22		.3841	.3506	.4207	.3658
23	.3841	.3841	.2686	.3658	.3658
24		.3841	.3292	.3189	.3475
Max	.3841	.567	.4801	.5487	.567
Min	.3841	.2561	.2686	.2561	.2743
Avg	.3841	.3984	.3785	.3697	.3865

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

SELU RURAL S/DN[370] BU 3808

Substation No/ Name :- 294031 / 33/11 KV SELDOH

Feeder No / Name : 205 / 11 kV MEL SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3292	.2035	.2835	.3142
2		.3326	.2035	.2835	.3109
3		.3326	.2035	.3012	.3109
4		.3292	.2035	.2835	.3142
5		.3658	.2035	.2835	.3292
6		.4207	.2543	.3012	.3658
7		.6401	.373	.463	.567
8		.8962	.6443	.7291	.7865
9		1.2254	.8648	.9221	.9694
10		1.1157	.9156	1.073	.9877
11		1.1233	.9116	1.701	.9012
12		1.1736	.631	1.1706	.9503
13		1.2071	.9945	1.1888	.9012
14		1.1568	1.0442	1.1523	
15		1.0852	1.0159	1.0974	
16		1.0852	1.073	.7682	
17		.9724	.9724	.9328	
18		.6371	.763	.6767	.5596
19		.5868	.6344	.5853	.5426
20		.4024	.5365	.5121	.5087
21		.285	.4458	.439	.4409
22		.218	.3772	.3841	.3561
23	.3658	.218	.3155	.3326	.3052
24		.3475	.2035	.3012	.3109
Max	.3658	1.2254	1.073	1.701	.9877
Min	.3658	.218	.2035	.2835	.3052
Avg	.3658	.6869	.5828	.6736	.5516

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

SELU RURAL S/DN[370] BU 3808

Substation No/ Name :- 294031 / 33/11 KV SELDOH

Feeder No / Name : 208 / 11 KV DAHEGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1307	.0972	.1267	
2		.112	.0972	.1267	
3		.112	.0972	.1267	
4		.112	.0972	.1448	
5		.9145			
6		1.2071			
7		1.3169	.9555		
8		1.3535	1.3279	1.0227	1.5546
9		1.5181	1.587	1.4419	2.1033
10		.1132	1.9109	1.3927	2.1399
11		.1457	1.8564	1.6827	1.9109
12		.1943	1.8023	1.6827	1.8138
13		.1943	.1267	1.6827	1.7814
14		.1619	.1267	1.8656	1.7166
15		.1943	.1448		1.5708
16		.1619	.1267		.0972
17			.1448	.112	.1134
18		.1619	.1448	.112	.1134
19		.1457	.1267	.112	.081
20		.1134	.128	.1494	.081
21		.0972	.128	.1867	.0972
22		.0972	.128	.1867	.1457
23	.1307	.0972	.1267	.1867	.0972
24		.1307	.0972	.128	
Max	.1307	1.5181	1.9109	1.8656	2.1399
Min	.1307	.0972	.0972	.112	.081
Avg	.1307	.3820	.5172	.6563	.9636

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

SELU RURAL S/DN[370] BU 3808

Substation No/ Name :- 294043 / 33/11 KV HINGNI

Feeder No / Name : 201 / 11 KV BORI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.4268	.4572	.4321	.4268
9	.5639	.6249	.6325	.5761
10	.6836	.6636	.6481	.4999
11	.679	.6706	.6327	.5401
12	.7011	.4214	.5575	.5647
13	.6097	.6405	.5575	.5556
14	.6401	.6019	.3462	.5487
15	.5117	.6636	.5487	.5792
Max	.7011	.6706	.6481	.5792
Min	.4268	.4214	.3462	.4268
Avg	.6020	.5930	.5444	.5364

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

SELU RURAL S/DN[370] BU 3808

Substation No/ Name :- 294043 / 33/11 KV HINGNI

Feeder No / Name : 202 / 11 KV SALAI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.4382	.5525	.4954
2	.5144	.4382	.5525	.4954
3	.4954	.4191	.5525	.4763
4	.5144	.4191	.5716	.4763
5	.5525	.4954	.5906	.4954
6	.5716	.5525	.5716	.5144
7	.6287	.5906	.6097	.6287
8	.7676	.7186	.6636	.6472
9	1.1227	1.0467	1.0883	.9877
10	1.0517	.6636	1.0311	1.034
11	1.0425	1.0185	.9783	1.0185
12	.873	1.0467	.9145	.9568
13	.9722	.9877	.884	.8749
14	.9374	.945	.8768	.8179
15	.945	.9259	.8592	.8592
16	.4763	.4001	.4382	.4954
17	.4763	.4382	.4572	.5144
18	.724	.8954	.9526	.9145
19	.9907	1.0479	1.086	1.1622
20	.9717	1.0288	1.0479	
21	.8383	.9145	.9145	.9335
22	.6287	.7049	.6668	.7049
23	.4954	.6478	.5144	.6097
24	.4954	.4382	.5716	.4572
Max	1.1227	1.0479	1.0883	1.1622
Min	.4763	.4001	.4382	.4572
Avg	.7333	.7176	.7478	.7204

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

SELU RURAL S/DN[370] BU 3808

Substation No/ Name :- 294043 / 33/11 KV HINGNI

Feeder No / Name : 203 / 11 KV HINGNI-2 SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.1578	.156	.1715	.1772
9	.1457	.156	.1715	.1772
10	.1457	.1753	.1772	.2126
11	.1619	.2096	.1772	.1715
12	.1638		.1457	.1905
13	.1823	.1715	.1372	.1612
14	.1475	.1905	.125	.1524
15	.1638	.1524	.12	.1524
Max	.1823	.2096	.1772	.2126
Min	.1457	.1524	.12	.1524
Avg	.1586	.1730	.1532	.1744

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

SELU RURAL S/DN[370] BU 3808

Substation No/ Name :- 294043 / 33/11 KV HINGNI

Feeder No / Name : 204 / 11 KV SARVADNY EXPRESS
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINOUS PROCESS)(NO STAGGERING)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1791	.1791	.1791	.0537
2	.1791	.1791	.1791	.0537
3	.1791	.1791	.1791	.0537
4	.1791	.1791	.1791	.0537
5	.1791	.1791	.1791	.0537
6	.1791	.1791	.1791	.0537
7	.1791	.1791	.1612	.1612
8	.1612	.1791	.1791	.5014
9	.1791	.2328	.2149	.4835
10	.1791	.197	.197	.4835
11	.1791	.5014	.4835	.4835
12	.2328	.4656	.4656	.4477
13	.4835	.4298	.4656	.5373
14	.4477	.4477	.1791	.5014
15	.4835	.4656	.5014	.4835
16	.4477	.2328	.5014	.5014
17	.2686	.2507	.5194	.4656
18	.1791	.2149	.4835	.4656
19	.1791	.2149	.3045	.2686
20	.1791	.1254	.0537	.2328
21	.1791	.1791	.0537	.1612
22	.1791	.1791	.0537	.1791
23	.1791	.1791	.0537	.1791
24	.1791	.1791	.1791	.0537
Max	.4835	.5014	.5194	.5373
Min	.1612	.1254	.0537	.0537
Avg	.2321	.2470	.2552	.2880

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

SELU RURAL S/DN[370] BU 3808

Substation No/ Name :- 297010 / 132 kV SELOO

Feeder No / Name : 401 / 33 KV SAINATH TEXTILE
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINOUS PROCESS)(NO STAGGERING)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3961	.016	.0069	.0057
2		.3961	.0183	.0103	.0046
3		.3961	.016	.0097	.0057
4		.3961	.0171	.0114	.0051
5		.4527	.016	.0126	.0063
6		.4527	.0183	.0137	.0069
7		.3395	.0034	.0137	
8		.4527	.0034	.0011	
9		.4572	.0034	.2263	.0034
10		.4572	.0229	.2286	.004
11		.2858	.0354	.1646	.004
12		.4527	.016	.2263	.0029
13		.4527	.016	.2263	.0091
14		.3961	.0183	.2263	.0011
15		.3961	.0194	.2241	.0017
16		.3395	.0017	.3841	.0057
17		.4527	.004	.2241	.0034
18		.4527	.0046	.2149	.0069
19		.4527	.0006	.0069	.024
20		.4527	.0097	.012	.0114
21		.0171	.0109	.0057	.0183
22		.0171	.0114	.0057	.0069
23	.3961	.0149	.0103	.0074	.016
24		.3961	.0183	.0109	.0149
Max	.3961	.4572	.0354	.3841	.024
Min	.3961	.0149	.0006	.0011	.0011
Avg	.3961	.3656	.0130	.1031	.0076

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

SELU RURAL S/DN[370] BU 3808

Substation No/ Name :- 297010 / 132 kV SELOO

Feeder No / Name : 402 / 33 KV INCOMER 1 SELOO
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8402	.543	.5487	.543
2	1.8804	.543	.5487	.543
3	.7973	.543	.5487	.543
4	.8402	.543	.5487	.543
5	2.9127	2.8235	2.7984	.543
6	3.4168	2.8235	3.0178	.5973
7	4.0329	3.6923	3.2922	.5973
8	3.6677	3.9638	4.4445	2.9321
9	3.7529	4.3896	4.1152	4.201
10	3.5288	3.9438	3.9866	
11	.5601		.4938	
12	.4481	.4835	.4298	
13	.5041	.4835	.3801	
14	.5041	.4835	.3292	4.201
15	.5041	.4835	.5373	4.5931
16	.4938	.4938	.5316	.4481
17	.4938	.4938	.543	.543
18	.7682	.7682	.8145	.8145
19	.9328	.9328	.9328	.9522
20	.8779	.8779	.8688	.8962
21	.7682	.823	.7602	.7842
22	.6584	.7133	.6516	.6722
23	.6036	.6036	.6516	.6161
24	.8962	.5487	.5487	.543
Max	4.0329	4.3896	4.4445	4.5931
Min	.4481	.4835	.3292	.4481
Avg	1.4451	1.3912	1.3468	1.3053

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

SELU RURAL S/DN[370] BU 3808

Substation No/ Name :- 297010 / 132 kV SELOO

Feeder No / Name : 403 / 33 KV INCOMER 2 SELOO
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974	1.0099	.9877	.9328
2	1.0745	1.0317	.9877	.9328
3	1.0174	1.0317	.9877	.9328
4	1.0631	1.0317	.9877	.6584
5	1.5415	1.6289	1.6461	.6584
6		1.9004	1.9753	.9877
7	2.073	2.1719	2.2497	1.0974
8	2.392	2.552	2.7435	2.0302
9	2.7446		2.4691	2.5206
10	2.8006		2.364	
11	2.0725		1.5912	
12	2.1285	2.0416	1.5746	
13	1.9044	1.4883	2.1491	
14	1.9044	1.773	2.1399	3.5288
15	1.7924	1.5043	1.9879	3.3608
16	1.9204	1.7558	2.0508	2.2965
17	2.0302	1.5364	2.0302	2.2965
18	1.9204	1.6461	1.9204	1.8267
19	1.8107	1.5364	1.4815	1.6804
20	1.5364	1.3169	1.3169	1.5684
21	1.1523	.8779	.9328	1.5684
22	.9877	.823	.7682	1.3443
23	1.2071	1.0425	.9328	1.0082
24	1.1203	1.2071	.9877	.9328
Max	2.8006	2.552	2.7435	3.5288
Min	.9877	.823	.7682	.6584
Avg	1.7083	1.4718	1.6359	1.6081

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA S/DN. R-II[372] BU 4372

Substation No/ Name :- 294010 / 33 KV ANJI

Feeder No / Name : 201 / 11 KV YELAKELI (AG)

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.5624	.6249	.5487	
6	.6249	.6405	.5944	
7	.703	.6718	.6706	
8	.6249	.7186	.7468	.5487
9	.6093	.7164	.7926	.6874
10	.6249	.7316	.7011	.823
11				.8383
12				.8688
13				.8688
14				.8688
15				.8993
Max	.703	.7316	.7926	.8993
Min	.5624	.6249	.5487	.5487
Avg	.6249	.6840	.6757	.8004

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA S/DN. R-II[372] BU 4372

Substation No/ Name :- 294010 / 33 KV ANJI

Feeder No / Name : 202 / 11 KV MANDAWA (AG)

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.3125	.3593	.3048	
6	.3749	.4062	.3201	
7	.4531	.4531	.3658	
8	.4374	.4999	.4877	.3201
9	.4374	.5335	.5487	
10	.4062	.4725	.503	.5624
11				.6097
12				.5792
13				.503
14				.503
15				.4877
Max	.4531	.5335	.5487	.6097
Min	.3125	.3593	.3048	.3201
Avg	.4036	.4541	.4217	.5093

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA S/DN. R-II[372] BU 4372

Substation No/ Name :- 294010 / 33 KV ANJI

Feeder No / Name : 203 / 11 KV KAMPTEE (AG)

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.3437	.3637	.3353	
6	.4062	.4111	.3658	
7	.5468	.506	.4572	
8	.4687	.506	.5335	.442
9	.427	.5182	.5335	.6405
10	.4428	.503	.4725	.6249
11				.5792
12				.6097
13				.6554
14				.6554
15				.7011
Max	.5468	.5182	.5335	.7011
Min	.3437	.3637	.3353	.442
Avg	.4392	.468	.4496	.6135

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA S/DN. R-II[372] BU 4372

Substation No/ Name :- 294010 / 33 KV ANJI

Feeder No / Name : 204 / 11 KV ZADGAON(AG)

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.1875	.1823	.1886	
6	.2343	.2652	.2229	
7	.3281	.3315	.3258	
8	.2656	.3978	.4115	.2896
9	.2984	.3658	.4973	.4374
10	.2486	.3353	.5658	.4374
11				.4696
12				.4115
13				.381
14				.381
15				.4115
Max	.3281	.3978	.5658	.4696
Min	.1875	.1823	.1886	.2896
Avg	.2604	.3130	.3687	.4024

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA S/DN. R-II[372] BU 4372

Substation No/ Name :- 294010 / 33 KV ANJI

Feeder No / Name : 205 / 11 KV Mandwa(G)

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.0537	.0457	.0457
2	.0549	.0537	.0457	.0457
3	.0549	.0537	.0457	.0457
4	.0549	.0532	.0457	.0514
5	.0549	.0701	.0457	.061
6	.0732	.0876	.061	.061
7	.0914	.0876	.0762	.0762
8	.0848	.0876	.0762	.0762
9	.12	.0762	.0914	.0829
10		.0762	.1219	.0781
11	.12	.061	.0914	.0655
12	.1029	.0457	.0762	.0648
13	.1029	.0914	.0762	.0492
14	.0857	.0762	.0762	.0492
15	.0857	.0762	.0762	.0492
16		.0762	.0762	.0509
17		.0914	.0914	.0509
18		.0762	.0914	.1017
19	.1578	.1219	.1219	.1463
20	.1402	.1067	.1067	.128
21	.1052	.0914	.0914	.128
22	.0701	.0762	.0762	.0549
23	.0701	.061	.061	.0549
24	.0732	.0537	.0457	.0457
Max	.1578	.1219	.1219	.1463
Min	.0549	.0457	.0457	.0457
Avg	.0879	.0752	.0756	.0693

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA S/DN. R-II[372] BU 4372

Substation No/ Name :- 294010 / 33 KV ANJI

Feeder No / Name : 206 / 11 KV Yelakeli (G)

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2926		.2915	.3258
2		.2926			.3086
3		.2926		.2915	.3086
4		.2926		.3086	.3086
5		.3292		.3258	.3429
6		.3841		.3601	.3601
7		.2378		.2743	.2229
8		.2204		.2229	.2229
9		.4338	.2743	.3944	.4641
10		.2829	.2401	.4115	.4843
11		.3395	.3429	.3601	.4096
12		.3584	.2229	.3601	.1981
13		.3584	.2058	.3772	.2785
14		.3206	.1543	.3429	.2949
15		.2829	.1886	.3086	.4096
16			.2058	.3772	.3052
17			.2229	.3772	.2713
18			.4115	.4973	.3721
19			.4115	.583	.3841
20			.3944	.5144	.3841
21			.3601		.3292
22			.3086	.3772	.2561
23	.4024		.2401	.3429	.2561
24		.3292		.3086	.3258
Max	.4024	.4338	.4115	.583	.4843
Min	.4024	.2204	.1543	.2229	.1981
Avg	.4024	.3155	.2789	.3640	.3260

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA S/DN. R-II[372] BU 4372

Substation No/ Name :- 294010 / 33 KV ANJI

Feeder No / Name : 207 / 11 KV Kamptee(G)

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0373	.0373	.0343	.0343
2			.0373	.0343	.0343
3		.0366	.0373	.0343	.0343
4			.0373	.0343	.0343
5			.0373	.0343	.0343
6		.0366	.0373	.0343	.0343
7		.0366	.0373	.0343	.0343
8		.0339	.0373	.0343	.0343
9		.0343	.0171	.0343	.0332
10		.0373	.0171	.0343	.0324
11		.0373	.0171	.0171	.0162
12		.0187	.0171	.0171	.0164
13		.0187	.0171	.0171	.0164
14		.0187	.0171	.0171	.0011
15		.0373	.0171	.0171	.0164
16			.0171	.0171	.0339
17			.0171	.0343	.0316
18			.0514	.0686	.0709
19		.0747	.0857	.0857	.0914
20		.0934	.0686	.0857	.0914
21			.0514	.0857	.0732
22		.056	.0514	.0514	.0366
23	.0549	.0373	.0343	.0343	.0366
24		.0366	.0373	.0343	.0343
Max	.0549	.0934	.0857	.0857	.0914
Min	.0549	.0187	.0171	.0171	.0011
Avg	.0549	.0401	.0347	.0386	.0378

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA S/DN. R-II[372] BU 4372

Substation No/ Name :- 294010 / 33 KV ANJI

Feeder No / Name : 208 / 11 KV Zadgaon(G)

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0532	.0351	.0514	.0514
2	.056	.0351	.0514	.0514
3	.056	.0351	.0514	.0514
4	.056	.0526	.0514	.0514
5	.0549	.0526	.0514	.0514
6	.0739	.0701	.0686	.0514
7	.0554	.0526	.0686	.0686
8	.0848	.0686	.0686	.0686
9	.0686	.0857	.0857	.0829
10	.0686	.0857	.1029	.0819
11	.0514	.0514	.0686	.0648
12	.0351	.0514	.0514	.0492
13	.0351	.0514	.0514	.0492
14	.0187	.0514	.0514	.0492
15	.0343	.0343	.0514	.0492
16		.0343	.0514	.0339
17		.0514	.0514	.0509
18		.0857	.1029	.0693
19	.12	.12	.12	.1463
20	.1029	.1029	.1029	.1097
21	.0876	.0857	.0857	.0914
22	.0701	.0686	.0686	.0549
23	.0526	.0686	.0514	.055
24	.056	.0351	.0514	.0514
Max	.12	.12	.12	.1463
Min	.0187	.0343	.0514	.0339
Avg	.0615	.0611	.0671	.0640

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA S/DN. R-II[372] BU 4372

Substation No/ Name :- 294010 / 33 KV ANJI

Feeder No / Name : 209 / 11 KV LANCO EXPRESS FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0476	.0572	.0857
2	.0754	.0476	.0686	.0572
3	.0754	.0476	.0572	.0857
4	.0754	.0476	.0572	.0572
5	.0754	.0476	.0572	.0572
6	.0754	.0476	.0572	.0572
7	.0754	.0572	.0686	.0572
8	.0754	.0572	.0686	.0686
9	.0572	.0686	.0686	.0754
10	.0572	.0686	.0686	.0754
11	.0572	.0686	.0686	.0754
12	.0572	.0686	.0686	.0754
13	.0572	.0686	.0686	.0754
14	.0572	.0686	.0686	.0754
15		.0686	.0686	.0754
16		.0686	.0572	.0629
17		.0572	.0572	.0629
18		.0572	.0572	.0754
19	.0572	.0572	.0572	.0629
20	.0476	.0572	.0572	.0629
21	.0476	.0572	.0572	.0629
22	.0476	.0572	.0572	.0629
23	.0476	.0572	.0572	.0629
24	.0629	.0476	.0572	.0572
Max	.0754	.0686	.0686	.0857
Min	.0476	.0476	.0572	.0572
Avg	.0628	.0582	.0620	.0678

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA S/DN. R-II[372] BU 4372

Substation No/ Name :- 294014 / 33/11 KV Waifad

Feeder No / Name : 201 / 11 KV TIGAON (AG)
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2286	.1886	.1892	.2286
2		.2286	.1886	.189	.2286
3		.2286	.1886	.1896	.2286
4		.2286	.1886	.1898	.2286
5		.2286	.1886	.1896	.2477
6		.2286	.1886	.1903	.2286
7		.1905	.1715	.1713	.1905
8		1.3908	1.0212	1.1603	1.1622
9		1.2193	1.3608	1.4861	1.5051
10		1.387	1.4043	1.5623	1.448
11		1.4175	1.4373	1.5813	1.2346
12		1.3108	1.4458	1.4289	1.2803
13		1.448	1.3872	1.5813	1.2651
14		1.448	1.3396	1.6194	1.3108
15		1.4175	.0191	1.6004	1.1888
16		.1372	.1512	.1334	.12
17		.1543	.1509	.1524	.12
18		.2572	.1703	.1905	.12
19		.1886	.1901	.2477	.1886
20		.1886	.2079	.2477	.2229
21		.2058	.2085	.2477	.2229
22	.2286	.2058	.2087	.2477	.2229
23	.2477	.1886	.1879	.2477	.2058
24		.2286	.1886	.1896	.2286
Max	.2477	1.448	1.4458	1.6194	1.5051
Min	.2286	.1372	.0191	.1334	.12
Avg	.2382	.5982	.5159	.6347	.5678

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA S/DN. R-II[372] BU 4372

Substation No/ Name :- 294014 / 33/11 KV Waifad

Feeder No / Name : 203 / 11 KV TIGAON Gaothan
Feeder KV- 11 / OUTGOING

SEPARATED GAOTHAN FEEDERS

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2018	.1715	.189	.1651
2		.2024	.1715	.1898	.1667
3		.1811	.1715	.1901	.1686
4		.1955	.1715	.1711	.1668
5		.2083	.1715	.189	.2018
6		.2213	.1886	.1886	.2018
7		.2024	.2058	.2261	.2202
8		.2222	.2058	.2259	.3486
9		.3429	.2398	.2378	.4074
10		.3429	.2407	.2202	.3889
11		.3601	.1846	.2385	.2058
12		.2915	.1477	.184	.2915
13		.2743	.131	.1823	.3258
14		.2572	.1295	.1275	.2743
15		.2743	.15		.2401
16		.3086	.1503	.1101	.2572
17		.2743	.1686	.1825	.3601
18		.4115	.2829	.2936	.3772
19		.5316	.4137	.3937	.463
20		.4458	.415	.3704	.4458
21		.3944	.3398	.3486	.2401
22	.2936	.2743	.2459	.3302	.2401
23	.2908	.1886	.1886	.3119	.1886
24		.2064	.1715	.1903	.2936
Max	.2936	.5316	.415	.3937	.463
Min	.2908	.1811	.1295	.1101	.1651
Avg	.2922	.2839	.2107	.2301	.2766

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA S/DN. R-II[372] BU 4372

Substation No/ Name :- 294019 / 33KV PIPRI S/S

Feeder No / Name : 201 / 11 KV PIPRI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.7682	.4382	.3475
2	.3841	.724	.443	.3258
3	.3801	.7499	.3761	.3292
4	.4066	.724	.3582	.3511
5	.4294	.7133	.3045	.3511
6	.439	.2195	.3582	.3475
7	.4344	.567	.394	.3982
8		.7682	.591	.4938
9	.583	1.2254	.6268	.5784
10	.6962	1.39	.9511	.8238
11	1.0277	1.9936	.9313	.9991
12	1.2403	2.2314	1.0387	1.0454
13	1.1096	2.0302	1.267	.7619
14	1.1163	2.1399	1.0924	.9492
15	1.1393	2.2862	1.0208	1.1403
16	1.3289	.3292	1.4022	1.3937
17	2.4013	1.2209	.695	1.267
18	1.8755	.6154	.8048	.695
19	1.5769	.5544	.6878	.6036
20	1.3253	.5415	.6036	.567
21	1.1104	.5121	.4938	.4755
22	.9694	.5853	.4805	.4755
23	.8048	.4656	.3841	.3658
24	.3801	.7499	.4748	.3511
Max	2.4013	2.2862	1.4022	1.3937
Min	.3658	.2195	.3045	.3258
Avg	.9358	1.0044	.6757	.6432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA S/DN. R-II[372] BU 4372

Substation No/ Name :- 294019 / 33KV PIPRI S/S

Feeder No / Name : 202 / 11 KV NALWADI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3982	.3258	.3292	.3258
2	.4207	.4755	.3109	.3142
3	.4668	.3292	.3109	.3109
4	.4706	.3292	.3142	.3511
5	.4938	.3439	.3326	.3881
6	.5068	.3658	.4251	.3982
7	.5792	.4525	.5914	.5304
8	.5853	.5121	.5853	.5914
9	.567	.543	.5068	.5544
10	.5304	.4572	.5304	.5359
11	.5121	.3982	.4887	.499
12	.4207	.3982	.3982	.4435
13	.3841	.3475	.362	.3696
14	.6401	.3292	.3045	
15	.3292	.3292	.3109	
16	.3224	.3258	.3475	
17	.3366	.3155	.3475	
18	.591	.5853	.5611	.7865
19	.6447	.6653	.7133	.6767
20	.5973	.6099	.6348	.6516
21	.5304	.5544	.5601	.5853
22	.4938	.4805	.4887	.4938
23	.4024	.3801	.4108	.4207
24	.4207	.3658	.3439	.3439
Max	.6447	.6653	.7133	.7865
Min	.3224	.3155	.3045	.3109
Avg	.4852	.4258	.4379	.4786

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA S/DN. R-II[372] BU 4372

Substation No/ Name :- 294019 / 33KV PIPRI S/S

Feeder No / Name : 203 / 11 KV GAJANAN NAGAR
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5121	.439	.4572	.4755
2	.5121	.4344	.4572	.4572
3	.4887	.4207	.4572	.4481
4	.5359	.4207	.4435	.4525
5	.5304	.439	.4435	.4938
6	.5601	.4706	.5175	.5121
7	.6838	.6036	.6099	.6154
8	.6653	.6401	.6219	.6468
9	.695	.6154	.6219	.6838
10	.695	.7023	.6584	.6653
11	.6584	.6653	.6154	.6468
12	.5853	.6161	.5853	.6099
13	.567	.5304	.5487	.5544
14	.5304	.4887	.4706	1.386
15	.4755	.4572	.4938	.7207
16	.4706	.4572	.4572	.7207
17	.5014	.4656	.5068	.7421
18	.7602	.8048	.7783	.7499
19	.8779	.8596	.8871	.8145
20	.7499	.7682	.823	.7865
21	.7133	.7316	.7392	.724
22	.6335	.6401	.6722	.6219
23	.543	.543	.543	.5487
24	.5729	.4938	.4835	.4755
Max	.8779	.8596	.8871	1.386
Min	.4706	.4207	.4435	.4481
Avg	.6049	.5711	.5788	.6480

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA S/DN. R-II[372] BU 4372

Substation No/ Name :- 294019 / 33KV PIPRI S/S

Feeder No / Name : 204 / 11KV MJP WW EXP
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0141	.3269	.0152	.1823
2	.3185	.3185	.3353	.1806
3	.3418	.3185	.3353	.1783
4	.3462	.3227	.3353	.1957
5	.3567	.3185	.3353	.3201
6	.3185	.3269	.3353	.3001
7	.3418	.3243	.3353	.3201
8	.3612	.362	.3658	.1656
9	.3763	.3572	.3475	.3658
10	.3612	.3715	.3475	.3658
11	.1806	.1981	.3506	.3658
12	.1806	.2035	.0149	.0152
13	.1957	.2035	.0152	.0152
14	.1806	.1806	.0152	.0152
15	.1806	.1806	.0152	.0152
16	.3462	.2012	.0152	.0152
17	.3384	.3353	.0151	.0152
18	.3418	.3353	.0149	.0152
19	.3243	.3353	.1865	.1677
20	.3418	.3353	.1677	.2012
21	.0141	.0152	.1677	.1677
22	.0141	.0152	.1677	.1677
23	.0141	.0152	.1677	.1677
24	.0141	.0141	.0152	.1677
Max	.3763	.3715	.3658	.3658
Min	.0141	.0141	.0149	.0152
Avg	.2418	.2465	.1840	.1703

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA S/DN. R-II[372] BU 4372

Substation No/ Name :- 294019 / 33KV PIPRI S/S

Feeder No / Name : 205 / 11 KV Sindhi (M)

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2534	.2012	.2507	.2012
2	.2587	.2012	.2507	.2218
3	.2561	.2195	.2328	.2195
4	.2715	.2012	.2328	.2218
5	.2715	.2195	.2507	.1991
6	.2743	.2561	.2686	.2172
7	.3109	.2926	.3403	.3109
8	.462	.4024	.394	.4706
9	.591	.5729	.5121	.5014
10	.6984	.5359	.567	.5373
11	.5552	.5359	.4572	.6447
12	.5731	.3881	.4938	.6268
13	.5373	.4755	.4572	.5731
14	.5552	.6348	.567	.8954
15	.5552	.5068	.5487	.9134
16	.591	.6154	.5487	.985
17	.6089	.591	.5487	.9877
18	.5973	.6089	.5611	.7682
19	.6219	.6089	.5788	.7133
20	.439	.4119	.4572	.5487
21	.3475	.394	.3511	.4938
22	.2926	.3403	.2743	.4024
23	.2561	.2865	.2378	.3475
24	.2587	.2195	.2507	.2012
Max	.6984	.6348	.5788	.9877
Min	.2534	.2012	.2328	.1991
Avg	.4349	.405	.4013	.5084

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA S/DN. R-II[372] BU 4372

Substation No/ Name :- 294041 / 33/11 KV DATTAPUR

Feeder No / Name : 201 / 11 KV MAHAKAL

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1566	.1241	.1214	.1551
2		.1566	.1241	.1214	.1551
3		.1566	.1241	.1214	.1551
4		.1566	.1241	.1214	.1551
5		.1392	.1241	.1214	.1551
6		.1392	.1241	.104	
7		.1739	.1551	.104	.1551
8		.1913	.1706	.156	.1706
9		.2783	.2609	.1861	.1241
10		.3131	.3131	.2481	.2791
11		.4001	.4001	.3412	.2791
12		.4349	.2435	.3877	.4032
13		.4175	.3827	.3877	.4032
14		.4523	.4001	.3102	.4701
15		.4001	.4175	.2947	.4032
16		.4523	.4349	.3257	.4032
17	.3305	.3105	.4161	.295	.4161
18	.2609	.2329	.1907	.2174	.2947
19	.3131	.2019	.1907	.2174	.2947
20	.2087	.1863	.1907	.2019	.2601
21	.1739	.1708	.156	.1863	.2254
22	.1739	.1397	.156	.1706	.1907
23	.1566	.1242	.1214	.1551	.1907
24		.1566	.1241	.1214	.1551
Max	.3305	.4523	.4349	.3877	.4701
Min	.1566	.1242	.1214	.104	.1241
Avg	.2311	.2476	.2279	.2091	.2563

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA S/DN. R-II[372] BU 4372

Substation No/ Name :- 294041 / 33/11 KV DATTAPUR

Feeder No / Name : 202 / 11 KV ALODI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3889	.3515	.3326	.3519
2		.3889	.37		.3148
3		.3889		.3326	.3148
4		.3519	.407	.3326	.3148
5		.3519	.4255	.3326	.3704
6		.4815	.4255	.4066	.4074
7		.6296		.6283	.5185
8		.6667	.6105	.5914	.6111
9		.5926	.5926	.5741	.5741
10		.5741	.5556	.537	.537
11		.537	.5	.537	.5185
12		.4259	.4259	.4815	.463
13		.4074	.3889	.4444	.4074
14		.3704	.3519	.3519	.463
15		.4074	.3333	.3519	.3519
16		.3889	.3889	.323	.3704
17	.463	.4259		.3889	.4251
18	.6852	.6111	.7947	.6111	.6468
19	.6852	.6481	.8131	.6667	.6468
20	.6296	.6111	.6653	.6296	.6283
21	.5741	.5556	.5914	.5926	.5914
22	.5	.4815	.4805	.5	.499
23	.463	.3948	.4251	.3889	.4066
24		.4074	.3515	.3511	.3519
Max	.6852	.6667	.8131	.6667	.6468
Min	.463	.3519	.3333	.323	.3148
Avg	.5714	.4786	.4880	.4646	.4619

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA S/DN. R-II[372] BU 4372

Substation No/ Name :- 294041 / 33/11 KV DATTAPUR

Feeder No / Name : 203 / 11 KV DATTAPUR

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1974	.1793	.181	.1791
2		.1974	.1614	.181	.1612
3		.1974	.1614	.181	.1612
4		.1974	.1793	.181	.1612
5		.2154	.2151	.181	.2149
6		.2692	.2689	.2534	.2507
7		.341	.3406	.3801	.3224
8		.3948	.3765	.4344	.2149
9		.3973	.3769	.3769	.3948
10		.3793	.3948	.3769	.3948
11		.3432	.323	.341	.3769
12		.3432	.3051	.3589	.323
13		.3251	.3051	.341	.2872
14		.2872	.2513	.323	.2872
15		.2743	.2513	.2872	.2513
16		.307	.2872	.2692	.2872
17	.2872	.251	.3077	.2686	.3077
18	.3948	.3765	.3801	.3761	.4344
19	.3948	.3944	.3801	.394	.3982
20	.3589	.3406	.3982	.3761	.3801
21	.341	.3048	.3439	.3406	.3439
22	.2872	.2689	.2353	.3048	.2896
23	.2513	.2331	.2353	.2331	.2353
24		.2154	.1793	.1991	.1791
Max	.3948	.3973	.3982	.4344	.4344
Min	.2513	.1974	.1614	.181	.1612
Avg	.3307	.2938	.2849	.2975	.2848

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA S/DN. R-II[372] BU 4372

Substation No/ Name :- 294061 / 33/11 KV GIROLI SUB-STATION

Feeder No / Name : 201 / 11 KV GIROLI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0762		.0457	.061
2			.061		.0457	.061
3			.061		.0457	.061
4			.061		.0457	.061
5			.061		.0457	.061
6			.0762		.061	.061
7			.0762		.0753	.0762
8			.1355		.0903	.1524
9			.1957		.1806	.2439
10			.2743		.2591	.2896
11	.3353		.3048		.2896	.3201
12			.381		.3201	
13			.3658		.3506	.4268
14			.381		.4115	.4725
15			.3506		.3963	.4268
16			.3658	.0753	.3353	.4268
17				.3161	.2591	.2743
18				.1505	.1372	.1372
19				.1204	.1219	.1067
20				.0903	.0914	.0914
21				.0753	.0762	.0762
22				.0452	.061	.061
23		.0753		.0457	.061	.061
24			.0753		.0457	.061
Max	.3353	.0753	.381	.3161	.4115	.4725
Min	.3353	.0753	.061	.0452	.0457	.061
Avg	.3353	.0753	.1943	.1149	.1605	.1770

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA S/DN. R-II[372] BU 4372

Substation No/ Name :- 294061 / 33/11 KV GIROLI SUB-STATION

Feeder No / Name : 202 / 11 KV AKOLI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.088		.088	.0892
2		.088		.0734	.0892
3		.088		.0734	.0743
4		.088		.0734	.0743
5		.088		.0734	.0892
6		.088		.0734	.104
7		.1027		.132	.1189
8		.2347		.2347	.2378
9		.2054		.3961	.3269
10		.3353		.4458	.4115
11		.381		.4458	.4268
12		.3048		.431	
13		.503		.431	.4572
14		.4572		.4458	.2439
15		.4572		.4012	.4268
16		.503	.4108	.4458	.4725
17			.4694	.431	.3963
18			.2054	.2526	.3201
19			.176	.208	.2591
20			.176	.1932	.2134
21			.1467	.1486	.1677
22			.1027	.104	.1219
23	.1027		.088	.104	.1067
24		.1027		.088	.104
Max	.1027	.503	.4694	.4458	.4725
Min	.1027	.088	.088	.0734	.0743
Avg	.1027	.2421	.2219	.2414	.2318

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA S/DN. R-I[371] BU 4371

Substation No/ Name :- 294015 / 33 KV SAWANGI (M)

Feeder No / Name : 201 / 11 KV PALLOTI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0686	.0905	.0724
2	.0943	.0686	.0905	.0724
3	.0754	.0686	.0905	.0724
4	.0754	.0686	.0543	.0724
5	.0754	.0686	.0543	.0724
6	.0754	.0686	.0543	.0724
7	.0754	.0686	.0543	.0724
8	.132		.1267	.0724
9	.1886	.1715	.1086	.1267
10	.1086	.1698	.1698	.2229
11	.1267	.1698	.132	.2229
12	.1086	.132	.1698	.2229
13	.132	.132	.1509	.1543
14	.0943	.0943	.0943	.0686
15	.0754	.0943	.1334	.1543
16	.1132	.0914	.1886	.0905
17	.12	.1029	.1029	.1629
18	.1715	.1543	.1886	.181
19	.2058	.2229	.2477	.1991
20	.1543	.1543	.1543	.2353
21	.1543	.1543	.1543	.2172
22	.12	.1267	.1448	.1448
23	.0857	.1086	.1629	.1448
24	.0857	.0686	.1086	.0724
Max	.2058	.2229	.2477	.2353
Min	.0754	.0686	.0543	.0686
Avg	.1143	.1143	.1261	.1333

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA S/DN. R-I[371] BU 4371

Substation No/ Name :- 294015 / 33 KV SAWANGI (M)

Feeder No / Name : 202 / 11 KV SALOD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.4287	.3658	.3841
2	.4338	.4287	.3658	.3841
3	.415	.4287	.3658	.3841
4	.415	.4287	.3258	.4572
5	.4715	.4287	.4024	.4572
6	.5093	.4458	.4024	.4572
7	.6413	.583	.4938	.5487
8		.583	.5487	.6036
9	.6767	.6001	.567	.6401
10	.567	.5281	.5847	.5658
11	.5853	.4715	.4572	.5658
12	.5487	.4715	.5093	.5144
13	.5281	.5093	.4715	.4801
14	.4715	.4715	.415	.463
15	.4715	.415		.4458
16	.4527	.4338	.4527	.439
17	.4801	.3944	.4287	.5304
18	.6687	.6344	.6687	.7316
19	.6687	.6605	.724	.7133
20	.6173	.6344	.6173	.7133
21	.583	.583	.5658	.6219
22	.463	.4938	.5304	.5487
23	.4458	.3841	.4207	.4207
24	.4115	.4287	.3841	.3841
Max	.6767	.6605	.724	.7316
Min	.4115	.3841	.3258	.3841
Avg	.5208	.4946	.4812	.5189

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA S/DN. R-I[371] BU 4371

Substation No/ Name :- 294015 / 33 KV SAWANGI (M)

Feeder No / Name : 203 / 11 KV MEDICAL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINOUS PROCESS)(NO STAGGERING)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4715	.463	.4755	.5121
2	.4715		.4755	.5121
3	.4715	.4458	.4755	.5121
4	.4715	.4458	.4572	.4938
5		.4458	.4572	.4938
6	.5281	.4458	.4572	.4938
7	.6413	.5316	.5853	.695
8	.6036	.6173	.6036	.6219
9	.4527	.5144	.5853	.5487
10	.3841	.4338	.4715	.3601
11	.439	.3961	.3239	.3258
12	.3658	.2829	.4338	.3258
13	.3584	.3584	.4338	.3601
14	.3018	.3584	.415	.3772
15		.439	.4572	.4801
16	.5093	.5658	.5853	.5487
17	.583	.6001	.6001	.7682
18	.6687	.6516	.6687	.7316
19	.6859	.703	.724	.7499
20	.6173	.583	.6001	.6036
21	.5487	.5658	.6173	.6219
22	.5144	.6036	.6036	.6401
23	.5144	.567	.5853	.6219
24	.4801	.463	.5121	.5121
Max	.6859	.703	.724	.7682
Min	.3018	.2829	.3239	.3258
Avg	.5038	.4992	.5252	.5379

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA S/DN. R-I[371] BU 4371

Substation No/ Name :- 294015 / 33 KV SAWANGI (M)

Feeder No / Name : 204 / 11 KV JAMTHA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0381	.0377	.0377
2	.0377	.0381	.0377	.0377
3	.0377	.0381	.0377	.0377
4	.0377	.0343	.0377	.0377
5	.1886	.1734	.1067	.0377
6	.1677	.1722	.1067	.0377
7	.2829	.2932	.2286	.0377
8	.2358	.2591	.3506	.2439
9	.1692	.2332	.4268	.3506
10	.1524	.249	.2926	.3628
11				.4818
12				.4578
13				.3521
14				.3429
15				.3506
17	.0343	.04	.036	
18	.0326	.04	.0476	
19	.0377	.0394	.0381	.0377
20	.0377	.0438	.0419	.0377
21	.0377	.0394	.0419	.0377
22	.0377	.0377	.0377	.0377
23	.0377	.0377	.0377	.0377
24	.0343	.0377	.0377	.0377
Max	.2829	.2932	.4268	.4818
Min	.0326	.0343	.036	.0377
Avg	.0910	.1025	.1101	.1635

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA S/DN. R-I[371] BU 4371

Substation No/ Name :- 294015 / 33 KV SAWANGI (M)

Feeder No / Name : 205 / 11 KV Sawangi(AG)

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.066	.0806	.0943	.0943
2	.066	.0806	.0943	.0943
3	.0641	.0806	.0943	.0943
4	.0641	.0806	.0943	.0943
5	.5677	.535	.4725	.0943
6	.6092	.6203	.503	.0943
7	.6979	.7665	.6859	.0754
8	.5998	.6874	.884	.6706
9	.4588	.695	.9145	.7773
10	.3963	.7733	.7682	.8886
11				.9722
12				1.0305
13				.8246
14				.9252
15				.9145
17	.1423	.1543	.1423	
18	.108	.1217	.1029	
19	.0789	.1097	.0857	.0943
20	.0789	.1029	.0772	.0943
21	.0754	.1029	.0772	.0943
22	.0789	.1132	.0943	.0943
23	.0772	.1132	.0943	.0943
24	.0583	.0806	.1132	.0943
Max	.6979	.7733	.9145	1.0305
Min	.0583	.0806	.0772	.0754
Avg	.2382	.2944	.2996	.3910

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA S/DN. R-I[371] BU 4371

Substation No/ Name :- 294016 / 33KV MADNI

Feeder No / Name : 201 / 11 KV KARANJI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5944	.1524	.5182	.1543
2	.5944	.1524	.5182	.1543
3	.5944	.1524	.5182	.1543
4	.5944	.1524	.5182	
5	.5944	.1524	.5182	.1886
6	.6554	.2134	.5182	.2058
7	.8993	.8535	.7468	.8402
8	1.326	1.2955	1.1431	1.3546
9	1.5242	1.6004	1.4632	1.5394
10	1.4327	1.5394	1.4632	1.5242
11	1.2803	1.4175	1.326	1.3717
12	1.0974	1.1888	1.0517	1.2651
13	.1372	.1219	.1372	.1067
14	.1372	.1219		.1219
15	.1219	.0914	.1219	.1219
16	.1524		.1067	
17	.1372	.1219	.1524	.1524
18	.2896	.3201	.3048	.3353
19	.381	.3963	.4801	.381
20	.3658	.381	.5487	.3658
21	.3201	.3201	.5316	.3353
22	.2286	.1981	.3772	.2134
23	.2286	.1677	.463	.1677
24	.6097	.1524	.5335	.1543
Max	1.5242	1.6004	1.4632	1.5394
Min	.1219	.0914	.1067	.1067
Avg	.5957	.4897	.6113	.5095

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA S/DN. R-I[371] BU 4371

Substation No/ Name :- 294016 / 33KV MADNI

Feeder No / Name : 202 / 11 KV TARODA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.7316	.7926	.8059
2	.7468	.7316	.7926	.8059
3	.7468	.7316	.7926	.7888
4	.7468	.7316	.7773	.7888
5	.7164	.7316	.7621	.7888
6	.7011	.7621	.7926	.8402
7	1.448	1.5242	1.0212	1.6289
8		1.3565	1.3717	1.4232
9	1.6766	1.5546	1.6613	1.4327
10	1.5242	1.5089	1.5394	1.4937
11	1.3413	1.4327	1.4175	1.3413
12	1.1126	1.2803	1.2955	1.1888
13	2.1529	1.5546	1.5699	1.4632
14	1.7375	1.5394		1.4937
15	1.5699	1.5699	1.5546	1.6004
16	1.5089		2.7435	1.4327
17	1.3413	1.3717	1.3717	1.2955
18	1.326	1.2955	1.2803	1.1584
19	.442	.6706	.4973	.4572
20	.5639	.6706	.4801	.381
21	.3353	.5944	.4287	.3658
22	.2439	.4115	.3086	.2743
23	.2667	.3353	1.9547	.2134
24	.7621	.7316	.1372	.8059
Max	2.1529	1.5699	2.7435	1.6289
Min	.2439	.3353	.1372	.2134
Avg	1.0329	1.0358	1.1019	1.0112

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA S/DN. R-I[371] BU 4371

Substation No/ Name :- 294016 / 33KV MADNI

Feeder No / Name : 203 / 11 KV DINDODA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1677	.5335		.5487
2	.1677	.5335	.1372	.5487
3	.1677	.5335	.1372	.5316
4	.1677	.5335	.1372	.5144
5	.1677	.5182	.1372	.5144
6	.1981	.5487	.1677	.5487
7	.2439	.5487	.2134	.5487
8	.1829	.1524	.1524	.2572
9	.2286	.1981	.1981	.2134
10	.1524	.1524	.1524	.1981
11	.1677	.1524	.1524	.1829
12	.1067	.1219	.1372	.1524
13	1.2498	1.1736	1.2498	1.1126
14	1.2803	1.2803		1.2955
15	1.1279	1.1431	1.2803	1.2346
16	1.0669			1.1431
17	1.0212	1.0669	.7621	1.0517
18	.8383	.7926	.8573	.7468
19	.3506	.3658	.4973	.4115
20	.3506	.3506	.4801	.4115
21	.2896	.3048	.4287	.3506
22	.2134	.2134	.2915	.2439
23	.1829	.1677	.2229	.2667
24	.1829	.5335	.1372	.5487
Max	1.2803	1.2803	1.2803	1.2955
Min	.1067	.1219	.1372	.1524
Avg	.4281	.5182	.3776	.5657

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA S/DN. R-I[371] BU 4371

Substation No/ Name :- 294044 / 33/11 KV KHARANGANA-GODE

Feeder No / Name : 201 / 11 KV KHARANGANA GODE AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0481	.0549	.0514	.0481
2		.0481	.0549	.0514	.0481
3		.0481	.0549	.0514	.0481
4		.0481	.0549	.0514	.0481
5		.0481	.0549	.0514	.0481
6		.0481	.0549	.0514	.0481
7		.0481	.0549	.0343	.0481
8		1.4758	1.4632	1.2498	1.155
9		1.7071	1.8461	1.5089	1.4438
10		1.7528	1.7165	1.6202	1.5242
11		1.7071	1.7646	1.6844	1.4784
12		1.6309	1.524	1.6523	1.5546
13		1.6766	1.7967	1.6844	1.5089
14		1.6766	1.7165	1.5881	1.5089
15		1.6156	1.6683	1.524	1.3413
16		1.9022			
22			.0514	.0481	.0549
23	.0481	.0549	.0514	.0481	.0549
24		.0481	.0549	.0514	.0481
Max	.0481	1.9022	1.8461	1.6844	1.5546
Min	.0481	.0481	.0514	.0343	.0481
Avg	.0481	.8658	.7799	.7224	.6672

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA S/DN. R-I[371] BU 4371

Substation No/ Name :- 294044 / 33/11 KV KHARANGANA-GODE

Feeder No / Name : 202 / 11 KV KHARANGANA GODE

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 /
OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2202	.1829	.1886	.2018
2		.2202	.1829	.1886	.2018
3		.2202	.2012	.1886	.2018
4		.2202	.2012	.1886	.2018
5		.2385	.2012	.2058	.2569
6		.2936	.2195	.2229	.2752
7		.2936	.2561	.2401	.2752
8		.2936	.3109	.2572	.2936
9		.2915	.3658	.2743	.2752
10		.2743	.3302	.3119	.2572
11		.2401	.2752	.2202	.2401
12		.2058	.2385	.2202	.2401
13		.2229	.1925	.2018	.2058
14		.2229	.2202	.1835	.2229
15		.2058	.2018	.1835	.2058
16		.2058	.2018	.1835	.2058
17		.2378	.2229	.2018	.2561
18		.4024	.3772	.422	.4572
19		.5304	.4801	.5504	.5121
20		.439	.4115	.4403	.4207
21		.3292		.3669	.3292
22		.2378	.2401	.2936	.2378
23	.2385	.2012	.2058	.2202	.2195
24		.2202	.1829	.1886	.2018
Max	.2385	.5304	.4801	.5504	.5121
Min	.2385	.2012	.1829	.1835	.2018
Avg	.2385	.2695	.2566	.2560	.2665

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA S/DN. R-I[371] BU 4371

Substation No/ Name :- 294044 / 33/11 KV KHARANGANA-GODE

Feeder No / Name : 203 / 11 KV HAMDAPUR AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9		.0189		
10	.0171			
11	.0171			.0171
12	.0171			.0171
13	.0171	.0184	.0276	.0171
14	.0171	.0184	.0276	.0171
15		.0184		.0171
Max	.0171	.0189	.0276	.0171
Min	.0171	.0184	.0276	.0171
Avg	.0171	.0185	.0276	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA URBAN S/DN[368] BU 1813

Substation No/ Name :- 294027 / 33 KV SEWAGRAM

Feeder No / Name : 204 / 11 KV Essential Feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7762	.8316	.7392	.6838
2	.7762	.8316	.7392	.6838
3	.7762	.8316	.7392	.6838
4	.7947	.8316	.7392	.6838
5	.8131	.8316	.7392	.6838
6	.8686	.8316	.7207	.7207
7	.8871	.9055	.7577	.7392
8	.9425	.961	.7947	.8131
9	1.1088	.9431	.8686	.9425
10	1.0631	1.0631	.8916	.9259
11	.9774	1.1831	.8745	1.0631
12	1.166	1.1145	.8916	1.0631
13	1.0117	1.1145	.7888	1.0117
14	1.1145	1.0288	.7545	1.046
15	1.0288	1.046	.8402	.9774
16	.9774	1.0117	.7716	1.1488
17	1.0719	.8745	.8871	.8916
18	1.0164	.9088	.7947	.9945
19	.9055	.8745	.7947	.8916
20	.8686	.7888	.7947	.8059
21		.7716	.7577	.8059
22	.8501	.8316	.7577	.7545
23	.8316	.8131	.7207	.7545
24	.7762	.8316	.7392	.6838
Max	1.166	1.1831	.8916	1.1488
Min	.7762	.7716	.7207	.6838
Avg	.9305	.9190	.7874	.8522

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA URBAN S/DN[368] BU 1813

Substation No/ Name :- 294027 / 33 KV SEWAGRAM

Feeder No / Name : 205 / 11 KV Indira Sut Girini SHEDDABLE FEEDER HAVING WEEKLY
 Feeder Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3121	1.6078	1.5154	1.1088
2	1.3306	1.6078	1.5154	1.1088
3	1.386	1.6078	1.5154	1.1088
4	1.4415	1.6078	1.5154	1.1088
5	1.46	1.5893	1.4969	1.1088
6	1.4969	1.5524	1.46	1.0903
7	1.6263	1.5708	1.386	1.0534
8	1.4415	1.4784	1.2012	1.0164
9	1.7372	1.4901	1.1643	1.2936
10	1.8861	1.5466	1.094	1.5278
11	2.1313	1.6975	1.094	1.5655
12	1.9427	1.1506	1.2071	1.5466
13	1.905	1.7353	1.0562	1.5089
14	1.7918	1.8484	1.1506	1.6975
15	1.7164	1.8296	1.1694	1.7541
16	1.7164	1.8107	1.1694	1.773
17	1.7926		1.1088	1.7541
18	1.4969	1.5089	1.1088	1.6221
19	1.4415	1.5278	1.1088	1.6598
20	1.5339	1.5466	1.1273	1.7164
21	1.5154	1.358	1.1643	1.5655
22	1.4969	1.386	1.1827	1.6221
23	1.6263	1.5181	1.1458	1.6975
24	1.3121	1.6078	1.5154	1.1088
Max	2.1313	1.8484	1.5154	1.773
Min	1.3121	1.1506	1.0562	1.0164
Avg	1.6057	1.5732	1.2572	1.4216

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA URBAN S/DN[368] BU 1813

Substation No/ Name :- 294027 / 33 KV SEWAGRAM

Feeder No / Name : 208 / 11 KV BAPURAO DESHMUKH SAH SHEDDABLE FEEDER HAVING WEEKLY
SUT Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	18-DEC-17
HR	Load (MW)
17	.3292
Max	.3292
Min	.3292
Avg	.3292

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA URBAN S/DN[368] BU 1813

Substation No/ Name :- 294047 / 33 KV VIDYUT BHAVAN

Feeder No / Name : 201 / 11 KV VIDYUT BHAVAN - I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.3077	.2926	.3109
2		.2957	.2926	.2926
3		.2957	.2926	.2957
4		.2957	.2926	.2957
5	.3109	.4066	.2926	.3881
6	.3841	.4525	.3841	.4755
7	.4938	.4435	.4938	.4938
8	.5121	.4805	.4755	.5175
9	.4755	.462	.5121	.5175
10	.4887	.4706	.4887	.5068
11	.4344	.4344	1.647	.4525
12	.4163	.4344	.3982	.4706
13	.4163	.3982	.3801	.4163
14	.3439	.362	.3258	.3439
15	.362	.3258	.3258	.3439
16	.3261	.3077	.2896	.2896
17	.362	.362	.3439	.3439
18	.5359	.5487	.5175	.4938
19	.5552	.567	.5729	.567
20	.5729	.5487	.5914	.4938
21	.4805	.5121	.5175	.4938
22	.4435	.4207	.4251	.439
23	.3696	.3475	.3696	.3658
24	.3475	.3258	.3109	.3109
Max	.5729	.567	1.647	.567
Min	.3109	.2957	.2896	.2896
Avg	.4267	.4086	.4514	.4133

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA URBAN S/DN[368] BU 1813

Substation No/ Name :- 294047 / 33 KV VIDYUT BHAVAN

Feeder No / Name : 202 / 11 KV SHIV NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.1629	.1629	.1629
2		.1646	.1629	.1629
3		.1646	.1629	.1646
4		.1646	.181	.1646
5	.1991	.1646	.1629	.1646
6	.1991	.181	.1991	.181
7	.2353	.2195	.2353	.2353
8	.2896	.2378	.2534	.2378
9	.2534	.2561	.2715	.2378
10	.2534	.2353	.2896	.2172
11	.2534	.2172	.2353	.2172
12	.2353	.2172	.2172	.1991
13	.181	.1629	.1991	.181
14	.1629	.1448	.181	.1629
15	.1448		.1448	.1629
16	.1448		.1448	.1448
17	.1629	.1448	.1629	.181
18	.2772	.2534	.2587	.2715
19	.2507	.2715	.2561	.2534
20	.2561	.2534	.2195	.2534
21	.2195	.2172	.2195	.2534
22	.2012	.1991	.2012	.2172
23	.1646	.181	.1829	.181
24	.1991	.1629	.1629	.1629
Max	.2896	.2715	.2896	.2715
Min	.1448	.1448	.1448	.1448
Avg	.2126	.1989	.2028	.1988

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA URBAN S/DN[368] BU 1813

Substation No/ Name :- 294047 / 33 KV VIDYUT BHAVAN

Feeder No / Name : 204 / 11 KV VIDYUT BHAVAN - IV

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.262	1.1403	1.134	1.134
2		1.2197	1.134	1.0791
3		1.1888	1.0974	1.0791
4		1.1706	1.1157	1.0791
5	1.2254	1.1706	1.1157	1.1157
6	1.4083	1.3213	1.3352	1.2986
7	1.7558	1.6827	1.7375	1.6827
8	1.6644	1.7193	1.6827	1.6827
9	1.7924	1.701	1.7375	1.7558
10	1.7013	1.8099	1.7194	1.7737
11	1.6651	1.6651	1.647	1.7556
12	1.5203	1.3937	1.5023	1.6651
13	1.3032	1.2308	1.3394	1.3937
14	1.267	1.448	1.267	1.3213
15	1.267	1.3032	1.2489	1.2127
16	1.267	1.267	1.1584	1.2851
17	1.3394	1.3937	1.3032	1.3575
18	2.0851	2.0302	1.9753	2.1033
19	2.1312	2.2131	2.1582	2.268
20	2.0485	2.0668	2.0851	2.0668
21	1.829	1.9022	1.9204	1.957
22	1.6461	1.6644	1.6827	1.6827
23	1.4083	1.3717	1.3352	1.3717
24	1.4083	1.2127	1.2254	1.2071
Max	2.1312	2.2131	2.1582	2.268
Min	1.2254	1.1403	1.0974	1.0791
Avg	1.5712	1.5120	1.4857	1.5137

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA URBAN S/DN[368] BU 1813

Substation No/ Name :- 294048 / 33/11 KV J. B. SCIENCE

WARDHA

Feeder No / Name : 203 / 11 KV POST OFFICE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8326	.7602	.6733	.6379
2	.8326	.724	.567	.5847
3	.8145	.6878	.567	.6201
4	.8145	.7602	.6379	.6733
5	.8688	.7964	.6733	.7087
6	.905	.8145	.7442	.7619
7	.905	.8326	.8682	.7973
8	.9412	.905	.8859	.8505
9	.905	.905	.9036	.9036
10	1.0099	.9243	.9391	.8888
11	.9599	.8859	.8859	.9066
12	.8532	.8859	.7973	.7999
13	1.6176	.8354	.8328	.7821
14	1.3865	.7796	1.4352	.7643
15	1.3509	.7087	1.382	.7466
16	1.4398	.7442	1.2934	.7643
17	.7288	.7973	.8328	.8177
18	1.2265	1.1694	1.0631	1.1199
19	1.2087	1.1871	1.1163	1.191
20	1.1765	1.134	1.1517	1.1732
21	1.086	.9568	1.0454	1.0665
22	.9412	.9036	.9214	.9777
23	.8688	.7796	.8328	.7821
24	.8326	.7964	.691	.6733
Max	1.6176	1.1871	1.4352	1.191
Min	.7288	.6878	.567	.5847
Avg	1.0211	.8614	.9059	.833

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA URBAN S/DN[368] BU 1813

Substation No/ Name :- 294048 / 33/11 KV J. B. SCIENCE

WARDHA

Feeder No / Name : 205 / 11 KV CIRCUIT HOUSE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8063	.6661	.7133	.6485
2	.8063	.631	.642	.5959
3	.7888	.5959	.691	.631
4	.7888	.6661	.7846	.7362
5	.9816	.7712	.7796	.8238
6	1.2269	.9465	1.134	.8764
7	1.2971	1.0692	1.382	1.0166
8	1.1919	1.0867	1.2048	1.1043
9	1.2094	1.1568	1.1517	1.1043
10	1.1043	1.1566	1.1163	1.1033
11	1.1033	1.0985	1.0166	1.1211
12	1.0321	.9391	.9114	1.0677
13	.9075	.9391	.8764	.9965
14	.8897	.8505	.8238	.9609
15	.8719	.7796	.8238	.8719
16	.8719	.8859	.8413	.8008
17	.8897	.9391	.8589	.9431
18	1.3346	1.2934	1.5074	1.2634
19	1.3346	1.3289	1.262	1.3524
20	1.2254	1.258	1.2269	1.2634
21	1.1765	1.0631	1.1043	1.1744
22	.9955	.9922	.9991	.9965
23	.905	.8859	.8413	.8008
24	.8063	.7011	.7087	.6836
Max	1.3346	1.3289	1.5074	1.3524
Min	.7888	.5959	.642	.5959
Avg	1.0227	.9459	.9751	.9557

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA URBAN S/DN[368] BU 1813

Substation No/ Name :- 294048 / 33/11 KV J. B. SCIENCE

WARDHA

Feeder No / Name : 206 / 11 KV SNEHAL NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1463	.1605	.1417
2	.1646	.1463	.1427	.124
3	.1646	.1463	.1427	.124
4	.1646	.1646	.1427	.1595
5	.1829	.1829	.1783	.1772
6	.2195	.2014	.214	.1949
7	.2561	.2195	.2497	.2126
8	.2743	.2378	.2675	.2303
9	.2378	.2561	.2675	.2303
10	.2126	.1962	.214	.214
11	.1962	.1962	.1949	.1962
12	.1783	.1783	.1595	.1783
13	.1427	.1605	.1595	.1605
14	.1427	.1427	.1595	.1605
15	.1605	.1427	.1595	.1427
16	.1605	.1427	.1772	.1427
17	.1605	.1605	.1772	.1783
18	.2675	.3032	.2658	.2675
19	.2853	.2675	.3012	.2853
20	.2561	.2675	.2835	.2497
21	.2378	.214	.2481	.2497
22	.2012	.2126	.2126	.214
23	.1646	.1783	.1772	.1962
24	.1829	.1463	.1605	.1417
Max	.2853	.3032	.3012	.2853
Min	.1427	.1427	.1427	.124
Avg	.1999	.1921	.2007	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA URBAN S/DN[368] BU 1813

Substation No/ Name :- 298013 / 220 KV SUBSTATION BHUGAON

Feeder No / Name : 402 / 33 KV CHITODA FEEDER NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 33 / OUTGOING UTILITY

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	1.7918	1.9004	2.1719	1.6289	1.8461	1.8107
Max	1.7918	1.9004	2.1719	1.6289	1.8461	1.8107
Min	1.7918	1.9004	2.1719	1.6289	1.8461	1.8107
Avg	1.7918	1.9004	2.1719	1.6289	1.8461	1.8107

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA URBAN S/DN[368] BU 1813

Substation No/ Name :- 298013 / 220 KV SUBSTATION BHUGAON

Feeder No / Name : 403 / 33 KV MIDC SEWAGRAM 1 NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		4.6617	1.5043	4.4361	3.9175
2		2.9424	1.4506	4.4361	3.7597
3		4.7183	1.3969	4.4926	3.9175
4		4.7183	1.5043	4.6485	4.0752
5		5.1	1.7193	4.8609	4.1238
6		5.7053	1.9342	5.1298	4.2856
7		6.1552	2.2028	5.7314	4.8999
8		6.3306	6.4437	5.6252	5.3933
9		7.0096	6.5627	6.0213	6.234
10		7.3011	4.7531	6.1414	6.87
11		7.7754	7.1103	5.9671	7.0467
12		7.4002	7.1739	5.8619	6.7281
13		7.8607	6.7281	5.5304	6.3886
14		7.2026	6.673	5.9351	6.615
15		7.0964	6.4592	5.9431	6.5654
16		6.5801	5.7732	5.1629	5.9429
17		5.7801	5.5965	4.9565	5.7662
18		6.8918	6.6724	5.7167	6.7995
19		6.729	7.0049	6.0322	6.8987
20		6.4889	6.5096	6.0243	6.6297
21		6.0986	5.7383	5.7007	6.184
22		5.7647	5.3562	4.9972	5.6887
23	1.9342	5.1144	4.981	4.2856	4.9244
24		4.6617	5.1086	4.5423	4.0752
Max	1.9342	7.8607	7.1739	6.1414	7.0467
Min	1.9342	2.9424	1.3969	4.2856	3.7597
Avg	1.9342	6.0870	4.8482	5.3408	5.5721

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

NAGPUR ZONE[069]

WARDHA CIRCLE[660]

WARDHA DIVSION[181]

WARDHA URBAN S/DN[368] BU 1813

Substation No/ Name :- 298013 / 220 KV SUBSTATION BHUGAON

Feeder No / Name : 406 / 33 KV Waigaon Feeder NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 33 / OUTGOING UTILITY

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	2.6029	2.6029	2.6029	2.6029	2.5463	2.4897	2.5463
Max	2.6029	2.6029	2.6029	2.6029	2.5463	2.4897	2.5463
Min	2.6029	2.6029	2.6029	2.6029	2.5463	2.4897	2.5463
Avg	2.6029	2.6029	2.6029	2.6029	2.5463	2.4897	2.5463