## Maharashtra State Electricity Distribution Co. Ltd.'s Consumer Grievance Redressal Forum Nagpur Urban Zone, Nagpur Case No. CGRF(NUZ)/164/2014

Applicant	: Shri Satish Maroti Nimje, Opp. Kushti Dangal Gate, Tandapeth, Nagpur.
Non–applicant	: Nodal Officer, The Superintending Engineer, (Distribution Franchisee), MSEDCL, N.U.C., NAGPUR.
<u>Quorum Present</u>	: 1) Shri Shivajirao S. Patil, Chairman.
	2) Adv. Subhash Jichkar Member.
	3) Shri Anil Shrivastava,

Member / Secretary.

## ORDER PASSED ON 5.8.2014.

1. The applicant filed present grievance application before this Forum on 3.7.2014 under Regulation 6.4 of the Maharashtra Electricity Regulatory Commission (Consumer Grievance Redressal Forum & Electricity Ombudsman) Regulations, 2006 (hereinafter referred to as Regulations).

2. The applicant's case in brief is that his meter is running without any load. He was out of station for few days and main switch was kept off. When he returned back, he observed that meter reading was advanced by 38 units. Meter was tested by acucheck and was found O.K. He was not satisfied and hence approached to I.G.R.C. Learned I.G.R.C. directed SNDL to replace the disputed meter Page 1 of 2 Case No. 164/14

immediately and test it in meter testing laboratory invariably in presence of the applicant. He is not satisfied with that order and therefore approached to this Forum.

3. Non applicant denied applicant's case by filing reply dated 18.7.2014. It is submitted that as per order of Learned I.G.R.C. meter was tested in meter testing laboratory in presence of the applicant on 31.5.2014 and it is found O.K. Grievance application be dismissed.

4. Forum heard arguments of both the sides and perused the record.

5. As per order passed by Learned meter of the applicant was tested in his presence in meter testing laboratory on 31.5.2014 and it is found O.K. We have carefully perused this meter testing report Dt. 31.5.2014 duly signed by the consumer in English. We have also perused connected load in spot inspection report Dt. 17.7.2014. As meter tested and found O.K. grievance application deserves to be dismissed. Hence following order : -

## ORDER

1) Grievance application is dismissed.

(Anil Shrivastava) MEMBER SECRETARY (Adv. Subhash Jichkar) MEMBER

(Shivajirao S. Patil), CHAIRMAN