

**Maharashtra State Electricity Distribution Co. Ltd.'s
Consumer Grievance Redressal Forum
Nagpur Urban Zone, Nagpur**

Case No. CGRF(NUZ)/244/2014

Applicant : Shri Ashok Kashiramji Hatwar,
Savitribai Fule Nagar,
Samrat Ashok Road,
Manewada,
Nagpur : 27.

Non-applicant : Nodal Officer,
The Superintending Engineer,
(Distribution Franchisee),
MSEDCL, N.U.C.,
NAGPUR.

Quorum Present : 1) Shri Shivajirao S. Patil,
Chairman.

2) Adv. Subhash Jichkar
Member.

3) Shri Anil Shrivastava,
Member / Secretary.

ORDER PASSED ON 20.11.2014.

1. The applicant filed present grievance application before this Forum on 24.9.2014 under Regulation 6.4 of the Maharashtra Electricity Regulatory Commission (Consumer Grievance Redressal Forum & Electricity Ombudsman) Regulations, 2006 (hereinafter referred to as Regulations).

2. The applicant's case in brief is that from July 2014 he received excessive bills. Therefore bills may be revised. Being aggrieved by the order passed by I.G.R.C. he approached to this Forum.

3. Non applicant denied applicant's case by filing reply Dt. 4.10.2014. Meter was tested by acucheck on 12.8.2014 and found O.K. As per order of Learned I.G.R.C. meter was tested in the meter testing laboratory on 22.9.2014 and it is found O.K. Grievance application deserves to be dismissed.

4. Forum heard arguments of both the sides and perused the record.

5. We have carefully perused order passed by Learned I.G.R.C. It is perfectly correct, legal and valid and needs no interference. Meter testing report by acucheck shows that meter is O.K. Meter testing report dated 22.9.2014 shows that meter was tested in the laboratory and it is found O.K.

6. However, these two meter testing reports are regarding meter No. SND-89041. Therefore meter No. SND-89041 is O.K.

7. Before installation of this meter No. SND-89041, previous meter was M. No. G-1132570. Record shows that this previous meter No. G-1132570 was tested in the meter testing laboratory on 14.6.2014 and in remark column it is mentioned that "Energy meter referred to this laboratory for testing is tested on meter testing bench and same is found to be 30% fast in pulse test & 8 % fast in dial test. Therefore this previous meter was faulty. Accordingly, there was adjustment of billing and bill was revised by SNDL. It is noteworthy that SNDL filed billing adjustment report Dt. 5.8.2014 on record and had adjusted bills of faulty meter. Therefore now no further relief can be granted in this grievance

application and application deserves to be dismissed. Hence following order :-

ORDER

- 1) Grievance application is dismissed.

Sd/-
(Anil Shrivastava)
MEMBER
SECRETARY

Sd/-
(Adv. Subhash Jichkar)
MEMBER

Sd/-
(Shivajirao S. Patil),
CHAIRMAN