

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214405 / 33 KV OTUR

Feeder No / Name : 201 / Udapur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0655	.0838	.0617	.0566	.0762	.0754
2	.0953	.0648	.0857	.0617	.0566	.0762	.0754
3	.0953	.0648	.0686	.0648	.0566	.0762	.0754
4	.0953	.081	.0686	.0648	.0754	.0953	.0754
5	.0953	.081	.0686	.0663	.0754	.0953	.0943
6	.0953	.081	.0857	.0829	.0943	.0953	.1132
7	.1143	.132	.0754	.1143	.1132	.0953	.1132
8	.1492	.1698	.0754	.1334	.1134	.1357	.1372
9	.1387	.1886	.0754	.1905	.1457	.1341	.1492
10	.1526	.1886	.1509	.1886	.1638	.1311	.1492
11	.1619	.1886	.132	.1698	.1989	.1638	.1475
12	.176	.1886	.1905	.2263	.1989	.1619	.1638
13	.1457	.2075	.1905	.1886	.2105	.192	.1966
14	.1457	.2452	.1905	.1886	.2214	.192	.1658
15	.1147	.2263	.2096	.1886	.2286	.1943	
16	.1698	.1886	.1715	.1698	.2096	.2075	.1715
17	.1698	.2263	.2286	.1886	.1715	.2075	.2096
18	.1886	.2075	.1715	.132	.1143	.1886	.1905
19	.1698	.132	.1143	.132	.1143	.1509	.1715
20	.1698	.1132	.1524	.132	.1143	.0943	.1524
21	.116	.0838	.1017	.1132	.0762	.0943	.1524
22	.0983	.0838	.1017	.0943	.0762	.0943	.1334
23	.0972	.0838	.0848	.0754	.0762	.0754	.1143
24	.0953	.0819	.0838	.0791	.0566	.0762	.0754
Max	.1886	.2452	.2286	.2263	.2286	.2075	.2096
Min	.0762	.0648	.0686	.0617	.0566	.0754	.0754
Avg	.1303	.1406	.1234	.1295	.1258	.1293	.1349

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214405 / 33 KV OTUR

Feeder No / Name : 202 / Dumbarwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.5449	.4755	.4108	.3206	.547	.3772
2	.4904	.5453	.4755	.394		.5658	.3772
3	.4904	.5658	.4854	.4287	.3018	.6036	.3772
4	.5281	.607	.5344	.4656	.3584	.6224	.415
5	.5658	.6615	.5658	.5746	.4338	.6036	.4904
6	.6224	.6935	.5868	.5554	.5093	.6224	.5847
7	.7733	.8299	.7545	.7733	.6413	.811	.8865
8	1.098	.8676	.9431	.8488	.8619	.9907	
9	1.2723	.9431	.9619	.8865	1.1077	1.0898	1.0799
10	1.3026	.9242	1.1128	.9979	1.1854	1.2824	1.0202
11	1.2978	.9619	1.0751	.924	1.2631	1.242	1.0591
12	1.234		1.0269	.9055	.9755	1.2319	1.1368
13	1.1526	.9997	.9709	.8686	1.2243	1.1757	1.1109
14	1.0574	.8299	.9149	.8048	1.0867	1.1368	1.1336
15	1.0202	.8676	.8686	.7865	.8852	1.0883	1.1465
16	.7316	.9808	.8869	.7602		.6413	.7682
17	.9055	.9997	.961	.7577	.7865	.8488	.8215
18	.811	.9619	.8686	.6468	.7865	.7356	.7468
19	.679	.8299	.8676	.6979	.7545	.7356	.6979
20	.6979	.7356	.8488	.5847	.7167	.6602	.6979
21	.6916	.6497	.6276	.5658	.6224	.6602	.6413
22	.6687	.6043	.6173	.5093	.5658	.5093	.547
23	.616	.4763	.515	.4338	.5281	.4527	.415
24	.4527	.5441	.4763	.447	.3584	.5281	.415
Max	1.3026	.9997	1.1128	.9979	1.2631	1.2824	1.1465
Min	.4527	.4763	.4755	.394	.3018	.4527	.3772
Avg	.8172	.7663	.7676	.6678	.7397	.8077	.7368

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214405 / 33 KV OTUR

Feeder No / Name : 203 / Tikekarwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3401	.5155	.4586	.4641	.2721	.3361	.2846
2	.3725	.463	.4428	.4641	.2401	.3521	.2846
3	.3887	.4938	.4586	.4801	.2721	.3521	.3163
4	.4049	.5247	.4744	.506	.3041	.3681	.3163
5	.421	.5556	.506	.506	.3521	.3841	.3479
6	.4372	.6019	.5535	.5693	.4001	.4001	.427
7	.583	.5556	.5535	.4902	.5601	.6241	.5376
8	1.2944	.6636	.6642	.68	1.1363	1.3283	1.4074
9	1.4074	.6944	.7432	.7274	1.3283	1.5655	1.531
10	1.4529	.8592	.8539	.7116	1.4243	1.6129	1.5779
11	1.4998	.9217	.9172	.7748	1.5364	1.5466	1.5623
12	1.4373	.8749	.933	.9014	1.4723	1.531	1.531
13	1.3435	.8124	.8381	.8381	1.4083	1.4842	1.656
14	1.2654	.7811	.7432	.7907	1.3283	1.4842	1.5154
15	1.1248	.7499	.8322	.8223	1.2643	1.4842	1.3916
16	.7099	.6958	.4801	.8065	.7042	.7968	.8697
17	.7116	.7432	.4801	.7748	.6722	.8124	.7116
18	.6642	.6325	.5121	.7432	.6562	.703	.8065
19		.4902	.5601	.6642	.5761	.6093	.5851
20	.506	.4111	.5281	.4902	.4801	.5218	.5376
21	.6325	.5851	.5441	.4001	.3681	.4428	.4111
22	.5851	.5218	.5121	.3521	.3361	.3637	.3795
23	.5693	.4744	.4801	.3201	.3201	.3163	.3163
24	.3239	.5535	.4744	.4961	.3041	.3201	.2846
Max	1.4998	.9217	.933	.9014	1.5364	1.6129	1.656
Min	.3239	.4111	.4428	.3201	.2401	.3163	.2846
Avg	.8033	.6323	.6060	.6156	.7382	.8225	.8162

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214405 / 33 KV OTUR

Feeder No / Name : 204 / otur city

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3856	.2772	.3475	.2896	.3142	.4119	.3658
2	.4298	.3142	.3292	.2896	.2957	.4525	.3511
3	.4706	.3658	.3475	.3439	.3511	.4887	.3511
4	.5359	.4572	.4024	.4251	.4572	.5249	.3881
5	.5914	.499	.439	.462	.4938	.5729	.4481
6	.6468	.6099	.5487	.5359	.567	.6283	.5228
7	.8871	.8596	.8316	.7023	.8048	.7392	.7023
8	.8686	.8596	.8048	.8589	.8869	.8501	.8131
9	.724	.7421	.8413	.8048	.7619	.823	.7316
10	.6379	.7442	.724	.7701	.6556	.7964	.5373
11	.6024	.631	.6335	.6201	.5493	.6878	.5201
12	.5258	.5895	.4835	.567	.5083	.5792	.5083
13	.5138	.5487	.4239	.5138	.4557	.5014	.5434
14	.3898	.407	.3605	.3898	.4031	.5014	.5144
15	.3681	.407	.3521	.4252	.3944	.4477	.5144
16	.4607	.4534	.3856	.4784	.4031	.4161	.4807
17	.4557	.5312	.4409	.4607	.4382	.4508	.5316
18	.5138	.5256	.5721	.6154	.4557	.5144	.6135
19	.7059	.6805	.7343	.7421	.5487	.6447	.6485
20	.6697	.6878	.6697	.724	.6584	.6154	.7602
21	.6401	.6219	.6283	.6036	.5729	.6036	.6697
22	.5487	.5487	.5304	.5304	.4706	.5121	.5611
23	.4805	.3841	.3982	.439	.3761	.4755	.3982
24	.333	.2957	.3841	.3189	.3511	.3761	.439
Max	.8871	.8596	.8413	.8589	.8869	.8501	.8131
Min	.333	.2772	.3292	.2896	.2957	.3761	.3511
Avg	.5577	.5434	.5255	.5379	.5072	.5673	.5381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214405 / 33 KV OTUR

Feeder No / Name : 205 / 11 kV Rohakadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2155	.1886	.1698	.2075	.2105	.2743	.2429
2	.2486	.1698	.1698	.2075	.1781	.2743	.2267
3		.2075	.1886	.2452	.2267	.2743	.2267
4	.2753	.2641	.2263	.2829	.2622	.3155	.2429
5	.3077	.3206	.2641	.3206	.2785	.3506	.2753
6	.3077	.3961	.3018	.3961	.3113	.3856	.3239
7	.4904	.5093	.4904	.4715	.5093	.5658	.5093
8	.7356	.7291	.664	.8619	.6602	.7356	
9	.8676	.8684	.9878	1.0682	.8676	.8299	.7733
10	.9431	.8368	1.0486	1.0364	.9055	1.0562	.7733
11	.8488	.9393	1.2548	1.0442	.9808	.9997	.7733
12	.7922	1.004	1.1065	1.0364	.9431	.9054	.7922
13	.7545	.9069	1.2637	.8962	.9054	.8865	.811
14	.7356	.9374	1.2637	.9231	.8676	.7733	.9431
15	.7356	.9061	1.0242	.8642	.9431	.7356	.9997
16	.6979	.7922	.9997	.7733	1.0374	.7733	.9808
17	.8299	.811	1.0562	.7922	.9054	.8299	.7545
18	.7922	.6413	.7167	.6979	.7922	.7356	.8865
19	.6036	.4904	.4904	.5093	.6224	.6036	.547
20	.3961	.3395	.4715	.4338	.4715	.415	.415
21	.3206	.2641	.3206	.2818	.3401	.3605	.3005
22	.2641	.2452	.3018	.3077	.3239	.3077	.2778
23	.2263	.1886	.2641	.2591	.2881	.2753	.2134
24	.2155	.2075	.1886	.2263	.2401	.2949	.2429
Max	.9431	1.004	1.2637	1.0682	1.0374	1.0562	.9997
Min	.2155	.1698	.1698	.2075	.1781	.2743	.2134
Avg	.5480	.5485	.6347	.5893	.5863	.5816	.5449

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214405 / 33 KV OTUR

Feeder No / Name : 206 / 11 KV PIMPRI PENDHAR
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	13-FEB-18
HR	Load (MW)
9	.8299
Max	.8299
Min	.8299
Avg	.8299

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214405 / 33 KV OTUR

Feeder No / Name : 207 / 11 KV SARANI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7125	.4338	.5281	.5525	.547	.7449	.7287
2	.7625	.415	.5281	.5525	.4973	.7625	.6802
3	.7888	.4715	.547	.6287	.5765	.7956	.7377
4	.8059	.547	.5847	.6859	.6274	.7956	.8048
5	.8413	.5847	.6413	.743	.6859	.8288	.8383
6	.8589	.6602	.8299	.8192	.7373	.8619	.8718
7	1.105	1.0562	1.094	1.1622	.9808	1.1622	.8865
8	1.3336	1.3904	1.56	1.7295	1.0751	1.3908	1.0751
9	1.3336	1.5912	1.7635	2.1704	1.4523	1.4335	1.2826
10	1.4523	1.8778	1.8778	1.9393	1.4784	1.5466	1.3336
11	1.3014	1.8778	1.9951	2.0687	1.5154	1.6409	1.3336
12	1.3769	.6154	1.9784	1.8991	1.4415	1.2826	1.3717
13	1.2752	1.5546	1.9062	1.8067	1.363	1.2637	1.3527
14	1.2382	1.5203	.2561	1.5384	1.2883	1.1883	1.448
15	1.1827	1.6876	1.1043	1.5061	1.3908	1.226	1.5242
16	.924	1.5466	1.448	1.3957	1.448	1.3203	1.5051
17	1.2197	1.358	1.4098	1.3203	1.3306	.9619	1.448
18	.7922	1.3203	1.1812	1.0185	1.2567	1.1506	1.2574
19	1.1506	1.0751	1.105	.9997	1.1827	1.0562	1.1241
20	1.0751	1.0185	.9907	.7733	1.0903	.8676	.9526
21	.8488	.9431	.9526	.6478	.9389	.8097	.8309
22	.6344	.7356	.7621	.7122	.8421	.8002	.7611
23	.5658	.5658	.6287	.779	.7773	.7682	.7209
24	.6964	.4715	.5658	.5906	.5801	.7773	.7287
Max	1.4523	1.8778	1.9951	2.1704	1.5154	1.6409	1.5242
Min	.5658	.415	.2561	.5525	.4973	.7449	.6802
Avg	1.0115	1.0549	1.0933	1.1683	1.0460	1.0598	1.0666

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214405 / 33 KV OTUR

Feeder No / Name : 208 / Otur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8642	.4251	.439	.3814	.6718	.8642	.7907
2	.9172	.4066	.4435	.3814	.6316	.9061	.8259
3	.9488	.4572	.462	.4382	.6316	.9602	.8097
4	1.0159	.5304	.5175	.5194	.7611	1.004	.852
5	1.0486	.5914	.5729	.5731	.8097	1.0526	.8848
6	1.0814	.6838	.6653	.6516	.8802	1.1174	.9175
7	.924	.8048	.924	.9425	1.2936	.823	.8871
8	1.0242	1.5238	1.6194	1.6787	.9774	1.134	1.0974
9	1.1706	1.9595	2.0081	2.1136	1.3756	1.3352	1.2803
10	1.3717	2.2939		2.4086	1.4118	1.7193	1.3756
11	1.4299	2.3266	2.536	2.0891	1.4449	1.7558	1.3575
12	1.2851	2.2996	2.4366	2.0809	1.4632	1.6827	1.3352
13	1.0317	2.2405	2.2672	2.0243	1.4842	1.448	1.3575
14	1.1765	2.2405	2.0873	1.7166	1.5023	1.5203	1.3937
15	1.2254	2.1125	1.9685	1.8023	1.5384	1.4842	1.379
16	1.1041	1.4883	1.4198	1.3937	1.5729	1.4842	1.3969
17	1.0059		1.5565	1.4661	1.4118	1.4842	1.4118
18	.8596	1.0985	1.2308	1.2803	1.267	1.448	1.3575
19	.8048	1.0136	.8682	1.1888	.9671	.8596	.8775
20	.7133	.9145	.7701	1.0974	.6984	.6379	.6805
21	.6099	.7316	.6878	.8642	.9231	.8642	.8322
22	.5544	.6219	.5792	.8097	.8855	.8539	.7968
23	.462	.4755	.4252	.7611	.8333	.8223	.7716
24	.8333	.4435	.4755	.3721	.7373	.8333	.7907
Max	1.4299	2.3266	2.536	2.4086	1.5729	1.7558	1.4118
Min	.462	.4066	.4252	.3721	.6316	.6379	.6805
Avg	.9776	1.2036	1.1722	1.2098	1.0906	1.1706	1.0608

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214405 / 33 KV OTUR

Feeder No / Name : 209 / CHILHEWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1189	.3961	.3772	.3429	.2753	.1341	.2572
2	.1486	.3772	.3772	.3429	.2534	.1219	.2187
3	.2134	.4338	.3961	.3961	.2585	.1372	.2934
4	.2953	.4715	.4527	.4527	.1905	.1132	.3544
5	.3269	.5658	.5093	.547	.1934	.1166	.503
6	.3772	.6979	.6602	.6413	.3597	.1166	.5556
7	.9907	1.1128	.9431	.9526	.8865	.8573	1.0562
8	1.4335	.4334	1.0717	.2086	1.3392	1.3392	1.4901
9	1.9791	1.4918	.4121	1.8652	1.4146	1.6598	1.8858
10	1.922	1.7541	.6135	1.6556	1.7353	2.0538	2.1098
11	1.7926	.4954	.9174	.3172	1.7187	1.8484	2.0911
12	1.7187	.9328	1.893	.4306	1.7177	1.7177	2.0538
13	1.6078	1.9791	.9979	.3239	1.5708	1.7177	2.0165
14	1.423	1.7101	1.2715	.3018	1.4415	1.7364	1.9605
15	1.46	1.7859	1.0517	.663		1.7737	1.9035
16	1.386	2.2405	1.6617	1.7002		1.587	1.9035
17	1.7541	2.0538	1.6991	1.7926	1.9404	1.6804	1.9978
18	1.6409	1.8111	1.4937	1.6448	1.9035	1.531	1.6617
19		1.3203	1.1694	1.1883	1.4523	1.3203	1.2449
20	.9242	.8299	.7733	.811	.9619	.9431	.8676
21	.7356	.6036	.743	.4184	.1715	.6371	.0972
22	.6413	.5093	.5525	.4572	.1383	.6219	.2776
23	.5658	.3772	.4001	.3858	.1299	.5548	.4382
24	.1006	.4338	.3772	.381	.3277	.1299	.3144
Max	1.9791	2.2405	1.893	1.8652	1.9404	2.0538	2.1098
Min	.1006	.3772	.3772	.2086	.1299	.1132	.0972
Avg	1.0242	1.0341	.8673	.7592	.9264	1.0187	1.1480

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214405 / 33 KV OTUR

Feeder No / Name : 210 / 11KV RAVANI INDUSTRIES NON SHEDDABLE EXPRESS HV FEEDERS
LTD. Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.0189	.1846	.0187	.0189	.1372	.0189
2	.1814	.0189	.192	.0189	.0189	.1463	.0189
3	.192	.0189	.1713	.0189	.0189	.1429	.0189
4	.2591	.0189	.1829	.0189	.0189	.136	.0189
5	.3086	.0189	.1867	.0187	.0189	.1509	.0189
6	.1048	.0189	.1097	.0185	.0189		.3841
7	.1048	.2858	.0695	.0187	.0189	.2774	.2241
8	.0185	.0358	.0189	.0187	.3492	.0179	.1976
9	.0819	.3243	.0189	.0187	.0762	.0312	.1852
10	.0526	.2138	.0747	.0189	.181	.048	.0583
11	.0737	.2279	.0183	.0189	.2031	.0655	.0591
12	.0966	.14	.0189	.0189	.1619	.032	.0884
13	.0171	.1052	.0189	.0189	.1315	.0389	.1198
14	.0177	.0926	.0187	.0189	.084	.0101	.1014
15	.0772	.2103	.0187	.0185	.1183	.0972	.144
16	.0533	.2561	.0187	.0189	.1509	.0625	.0914
17	.0857	.1684	.0187	.0189	.2058	.0541	.1334
18	.06	.1989	.0187	.0189	.2134	.0693	.1029
19	.0381	.1882	.0187	.0189	.2229	.064	.1334
20	.0189	.1437	.0185	.0189	.362	.0183	.16
21	.0189	.1143	.0189	.0189	.1486	.0185	.0457
22	.0189	.2734	.0189	.0189	.1684	.0185	.0543
23	.0189	.1216	.0187	.0189	.1882	.0185	.0754
24	.1417	.0189	.2321	.0187	.0189	.1585	.0187
Max	.3086	.3243	.2321	.0189	.362	.2774	.3841
Min	.0171	.0189	.0183	.0185	.0189	.0101	.0187
Avg	.0911	.1347	.0702	.0188	.1299	.0789	.1030

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214406 / 33 KV ALE

Feeder No / Name : 201 / Mokshadham

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.5735	.7865	.7625	.6535	.5975	.5415
2		.5735	.7537	.7459	.6535	.5601	.5415
3	.5228	.5868	.7209	.7127	.6722	.5601	.5415
4	.5228	.6104	.7537	.7127	.6908	.5975	.5975
5	.6348	.6443	.8192	.8288	.7095	.6348	.6348
6	1.3443	.6935	1.0852	1.0059	.7468	.7468	.679
7	.8865	.9149	.8962	.5868	.9335	.8962	.8488
8	1.1934	.9522	1.1088	.5601	1.5415	1.4091	1.2163
9	.9231	1.0534	1.1827	.4481	1.5893	1.6194	1.3927
10	1.1469	.1494	.1478	.3395	1.6712	1.7166	1.4251
11	1.1363	.1109	.2801	.1886	1.7695	1.7368	1.3108
12	1.1797	.112	.3142	.168	1.7368	1.7101	1.3123
13	1.186		.3142	.1494	1.5813	1.6804	1.3757
14	1.0595		.1307	.1307	1.5497	1.6385	1.406
15	1.094	.5316	.1867	.1595	1.5813	1.5893	1.4043
16	.7682	.823	1.134		.724	.7842	.9231
17	.7392	1.0974	2.2314	1.3575		.8131	.9694
18	.9145	1.0608	1.0974	1.3756		.8131	.9694
19	.924	1.0242	1.4516	1.2803		.8048	.961
20	.8402	.924	1.0349	.9979		.7343	.8316
21	.6554	.8288	.8848	.8686		.6838	.8316
22	.663	.9717	.8684	.8316	.6722	.6161	.7207
23	.5868	.8745	.8192	.6838	.6348	.5415	.5729
24	.6161	.5801	.8097	.7537	.6468	.5975	.5415
Max	1.3443	1.0974	2.2314	1.3756	1.7695	1.7368	1.4251
Min	.5228	.1109	.1307	.1307	.6348	.5415	.5415
Avg	.8738	.7132	.8255	.6804	1.0925	1.0034	.9395

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214406 / 33 KV ALE

Feeder No / Name : 203 / Rajuri

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8316	1.6575	1.5203	1.4251	.8686	.924	.8676
2	.8215	1.6712	1.4403	1.4251	.8775	.924	.8676
3	.8215	1.704	1.3765	1.4089	.8962	.8871	
4	.8402	1.7368	1.2955	1.4089	.9335	.9335	.9431
5	1.0829	1.8233	1.3916	1.5384	1.0269	.9709	1.0374
6	1.363	1.861	1.7238		1.2883	1.3121	1.1317
7	1.4419	1.6804	1.5684	1.4089	1.7737	1.7364	1.4523
8	2.8837	1.8111	1.6448	1.8484	2.8344	1.0608	2.4034
9	3.2769	1.6448	1.4969	1.9044	3.2653	2.8502	2.7044
10	3.3753	1.4815	1.4083	1.7372	3.5063	3.3261	2.8178
11	3.2808	1.2986	1.39	1.7002	3.5063	3.3097	2.9984
12	2.2613	1.3394		1.5524	2.5232		2.9635
13	2.8622	1.3213	1.2012	1.3717	3.195	3.3589	2.6408
14	2.8673		1.2127	1.3394	3.3198	3.3648	2.5766
15	2.7362	.8939	1.1403	1.3575	3.2712	3.0887	2.5606
16	1.1458	1.0985	1.4299	1.448	1.2803	1.4563	1.0517
17	1.1949	1.3112	1.4632	1.5203		1.6032	1.1765
18	1.4299	1.4661	1.448	1.7013		1.6032	1.2894
19	1.7372	1.6632	1.6632	1.5546		1.587	1.5708
20	1.6409	1.5893	1.6632	1.5154	1.6644	1.4784	1.4415
21	1.7368	1.7532	1.9433	1.3676		1.363	1.2382
22	1.7736	1.8564	1.9757	1.2936	1.2197	1.1203	.9979
23	1.6004	1.6762	1.6194	.9795	.9979	.8589	.7499
24	.8316	1.6004	1.5655	1.4413	.8779	.961	.8676
Max	3.3753	1.861	1.9757	1.9044	3.5063	3.3648	2.9984
Min	.8215	.8939	1.1403	.9795	.8686	.8589	.7499
Avg	1.8266	1.5626	1.5036	1.4890	1.9563	1.7425	1.6673

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214406 / 33 KV ALE

Feeder No / Name : 204 / Ale

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1772	.3395	.2402	.2801	.2126	.1886	.1928
2	.1772	.3395	.2218	.2614	.2126	.1886	.1907
3	.1772	.3395	.2218	.2614	.2149	.1886	.2058
4	.1772	.3584	.2218	.2614	.2149	.1886	.2126
5	.1907	.3772	.2587	.2801	.2149	.1928	.2103
6	.2254	.3961	.3547	.3547	.2328	.2303	.2328
7		.5601	.5788	.5228	.5175	.4481	.5359
8	.6161	.4344	.4298	.3944	.6348	.5228	.5788
9	.4668	.3988	.3898	.4115	.5228	.5601	.5658
10	.4481	.39	.3601	.373	.5544	.4805	.5175
11	.4251	.3856	.3052	.3561	.5175	.462	.462
12	.3801	.3277	.2947	.3978	.462	.4163	.462
13	.3403	.2984	.2774	.3812	.439	.3841	.3475
14	.3801		.2881	.3812	.4207	.3734	.3658
15	.3361	.2721	.2721	.3563	.4207	.3881	.3658
16	.3361	.333	.3761	.3506	.3982	.3584	.394
17	.3326	.4031	.394	.2804		.4481	.3224
18	.439	.443	.4835	.3155		.4435	.3403
19	.5601	.499	.5487	.4572		.4938	.5729
20	.5658	.5175	.5544	.5175		.5788	.499
21	.499	.5041	.4108	.3012		.3366	.3189
22	.4854	.4108	.4294	.2629	.2774	.2601	.3121
23	.3326	.3142	.3734	.2103	.2401	.2103	.2279
24	.1848	.3361	.2772	.2801	.1907	.2058	.2126
Max	.6161	.5601	.5788	.5228	.6348	.5788	.5788
Min	.1772	.2721	.2218	.2103	.1907	.1886	.1907
Avg	.3588	.3904	.3568	.3437	.3631	.3562	.3603

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214406 / 33 KV ALE

Feeder No / Name : 205 / Wadgaon Kandali

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4607	.4481	.5441	.16	.2315	.2458
2	.2155	.4725	.4588	.5121	.1619	.2315	.2515
3	.2155	.4725	.4588	.5121	.1619	.2315	.2515
4		.4999	.4915	.5121	.1943	.2315	.2652
5	.2652	.4755	.5079	.5121	.2105	.2315	.2949
6	.3185	.4967	.5601	.6241	.2429	.3041	.3353
7	.4144	.3658	.3612	.3401	.3353	.3795	.426
8	.8951	.4531	.3521	.3506	.8421	.7362	.8471
9	.9602	.4064	.3953	.4515	1.0402	.9442	.8768
10	1.0978	.3567	.3593	.4161	1.1174	1.0526	.9602
11	1.0608	.3269	.3475	.3668	1.085	1.0608	.9069
12	.8162	.3338	1.1294	.2896	.9717	.9659	.8802
13	.9175	.3429	.3864	.3227	.9804	.9145	.7655
14	.9054		.4344	.3521	1.012	.8362	.8223
15	.8619	1.1012	.362	.3477	.9014	.8619	.9014
16	.4458	.2498	.4001	.3666	.2429	.3906	.3467
17	.4458	.2892	.4001	.3858		.4458	.4001
18	.4144	.3199	.4001	.3292		.4012	.4172
19	.4115	.3567	.427	.3506		.4214	.4666
20	.3641	.3479	.427	.3395		.4115	.4062
21	.4904	.5182	.6562	.2753		.426	.3437
22	.4816	.5535	.6401	.2343	.3401	.3647	.2968
23	.4607	.5155	.5761	.1852	.2623	.2915	.2408
24	.2427	.4607	.4687	.5441	.1581	.2315	.2785
Max	1.0978	1.1012	1.1294	.6241	1.1174	1.0608	.9602
Min	.2155	.2498	.3475	.1852	.1581	.2315	.2408
Avg	.5773	.4424	.4770	.3944	.5484	.5249	.5095

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214406 / 33 KV ALE

Feeder No / Name : 206 / Alephata

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5853	.6556	.5792	.6036	.6089	.5731	.6344
2	.5487	.6001	.5068	.5853	.5973	.5373	.6556
3	.5487	.6068	.5068	.5487	.5973	.543	.6733
4	.567	.6135	.543	.5487	.6154	.543	.6516
5	.6154	.6733	.5611	.5973	.6516	.5611	.6613
6	.6516	.7265	.6767	.6697	.724	.724	.6706
7	.9412	.9536	.9511	.9593	1.0679	1.0059	.9877
8	1.1584	1.166	1.086	1.1946	1.1946	1.1283	1.1744
9	1.2309	1.2403	1.2094	1.3289	1.2269	1.3466	1.1269
10	1.3003	1.153	1.2656	1.2971	1.3496	1.3176	1.1963
11	1.258	1.2517	1.2517	1.283	1.2483	1.3546	1.2309
12	1.0288	1.1105	1.2445	1.2689	.5144	1.262	1.1736
13	1.0402	.9995	1.262	1.1869	1.0774	1.1616	1.0395
14				1.1065	1.0442	1.1317	1.0395
15			1.0898	1.1012	1.0562	.9922	1.0395
16		1.0774	1.1469	1.1012	1.0343	1.1222	
17		1.1174	1.1633	1.1305		1.1517	1.166
18	1.643	1.2717	1.3032	1.094		1.2003	1.2003
19	1.6478	1.3466	1.3394	1.1568		1.283	1.3213
20	1.379	1.2357	1.1544	1.1694		1.1871	.3801
21	1.1443	1.0745	.8779	1.0566		1.0117	.9694
22	.9922	.905	.8962	.9745	.9231	.8859	.7865
23	.7545	.7059	.7316	.691	.6878	.6762	.6878
24	.5853	.6762	.6335	.6036	.6201	.6089	.6415
Max	1.6478	1.3466	1.3394	1.3289	1.3496	1.3546	1.3213
Min	.5487	.6001	.5068	.5487	.5144	.5373	.3801
Avg	.9810	.9619	.9557	.9691	.8863	.9712	.9177

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214406 / 33 KV ALE

Feeder No / Name : 207 / KALAMJAI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0059	1.2696	1.0829	1.1389	.9389	.9339	.9088
2	1.0059	1.2696	1.0829	1.1203	.9945	.9012	.9431
3	.9724	1.307	1.1203	1.1203	1.0288	.9012	.9339
4	.9892	1.4377	1.1576	1.1203	1.0631	.9012	.9945
5	1.0562	1.531	1.2136	1.3256	1.1145	.9175	1.0227
6	1.3245	1.7177	1.5497	1.5684	1.2003	1.2039	1.0974
7	.9431	1.9044	1.9605	1.7833	2.0351	2.0328	1.8671
8		1.9938	2.1125	2.0748	2.2592	2.3899	1.9774
9		2.34	2.3061	2.3834	1.9605	.8676	.8676
10	1.9791	2.3807	2.2377	2.2969	.6036	.7167	.6413
11	1.9404	2.1795	2.1714	2.1293	.415	.4805	.4715
12	1.8839	2.1879	2.3304	1.9062	.3395	.3961	.3772
13	1.922		2.3304	1.6194	.3395	.3584	.3018
14	1.7556		2.3205	1.4883	.3206	.3772	.3395
15	1.9753		2.3205	1.6288	.3547	1.6448	.3734
16	2.1472		1.9387	1.8642	2.0302	2.1948	1.9004
17	2.0538	1.8099	1.9204	1.9022		2.3339	1.9387
18	2.0851	1.9753	1.8839	1.8642		2.3525	1.9022
19	2.1658	1.9589	1.922	1.829		2.3228	2.0513
20	1.9035	1.8111	1.9035	1.7372		1.9418	1.7372
21	1.7187	1.5912	1.6804	1.0059		1.1233	1.1401
22	1.4632	1.386	1.4003	.9945	1.1271	.9831	1.2407
23	1.1401	1.1273	1.307	.9503	.9878	.8886	1.0608
24	1.0227	1.2696	1.1088	1.1389	.8848	.9503	.9189
Max	2.1658	2.3807	2.3304	2.3834	2.2592	2.3899	2.0513
Min	.9431	1.1273	1.0829	.9503	.3206	.3584	.3018
Avg	1.5661	1.7224	1.7651	1.5829	1.0525	1.2548	1.1253

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214406 / 33 KV ALE

Feeder No / Name : 208 / 11 KV RAMDAS SWAMI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.2984	.2949	.3353	.2801	.2801	.2801
2	.2614	.2881	.2984	.3353	.2801	.2801	.2801
3	.2614	.2949	.2949	.3018	.2801	.2801	.2772
4	.2614	.3018	.3315	.3018	.2987	.2801	.3109
5	.2801	.3258	.3605	.3391	.3174	.3174	.3258
6	.3361	.3814	.4115	.4481	.3547	.3547	.4108
7	.4917	.4108	.3395	.3547	.415	.4108	.5041
8	.4917	.4715	.3547	.5228	.5935	.5636	.5898
9	.5407	.5544	.4108	.4251	.5636	.8122	.7459
10	.6133	.439	.3696	.5175	.7209	.8848	.779
11	.6241	.4706	.4251	.5175	.7701	.9762	.8453
12	.7545	.5068	.4668	.4572	.8029	.9175	.8192
13	.6964		.4668	.4525	.7907	.779	.7935
14	.664		.5415	.3801		.6874	.7202
15	.6562		.5121	.3721	.6081	.6718	.6642
16	.499	.4477	.543	.3189	.3142	.4251	.4607
17	.4755	.4887	.3982	.2835		.5121	.5249
18	.4706	.4572	.543	.4024		.4805	.4887
19	.4435	.3881	.3881	.3696		.4668	.3511
20	.4024	.3511	.4066	.3142		.462	.3258
21	.3201	.39	.3688	.3326		.4066	.3841
22	.3315	.3605	.3856	.3142	.3326	.3441	.3326
23	.3018	.3441	.3521	.2772	.3142	.3041	.3109
24	.2801	.2949	.3506	.3353	.2772	.3142	.2987
Max	.7545	.5544	.543	.5228	.8029	.9762	.8453
Min	.2614	.2881	.2949	.2772	.2772	.2801	.2772
Avg	.4474	.3936	.4006	.3754	.4619	.5088	.4927

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214429 / 33 KV BELHE

Feeder No / Name : 202 / Gunjalwadi
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0178	.5658	.5658	.5228	2.7915	2.7915	
2	2.9047	.5658	.5658		2.9047	2.9047	2.2611
3	2.8669	.5658	.6602	.5601	3.3951	3.3951	
4	3.0933	.679	.7545		3.7723	3.7723	2.0481
5	3.2065	.8488	.7922	.7095	3.3951	3.3951	
6	3.3008	.8488	.8299	.8029	2.7349	3.0178	1.9662
7	.9431	1.094	1.0185	1.0082	.9808	1.0185	.5975
8	.8488	4.0798	5.3567	3.5883	1.0374	.8488	.8215
9	.8299	4.4894	5.6584	4.3747	.9054	.8676	.5415
10	.7545	4.3747	5.2246	4.5877	.6224		.5601
11	.7545	4.7908		4.8011	.679	.6348	.4755
12	.5658	4.5268	4.5386	5.0926	.6413	.5788	.4938
13	.3772	4.6211		4.4582	.6413	.3395	.5121
14	.3206	2.8481	3.3589	4.7908	.6224	.1867	.5487
15	.5658	4.1495		4.1495	.439	.2801	.567
16		.7545	.5228	.6036	.5281		.5121
17	.6413	.6036		.6602	.547	.4668	.5487
18	.7356	.7545		.8488	.3772		.695
19		.9242		.9808	.9054	.9335	.823
20	.8676	.9054	.8215	1.0751	.7545		.7865
21	.7922	.7545	.7468	3.7723	3.3008	2.8182	2.2634
22	.679	.7167		3.4139	3.155		2.5149
23	.6036	.6602	.5228	2.8292	3.0178		2.4813
24	3.0178	.5658	.5658	.5228	2.7915	2.7915	2.556
Max	3.3008	4.7908	5.6584	5.0926	3.7723	3.7723	2.556
Min	.3206	.5658	.5228	.5228	.3772	.1867	.4755
Avg	1.4403	1.9037	1.9120	2.4615	1.7058	1.7245	1.1702

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214429 / 33 KV BELHE

Feeder No / Name : 203 / Ane
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6602	1.1317	1.1317	.9503	.6602	.6602	.6348
2	.6602	1.0059	1.1317		.6602	.6602	
3	.7922	1.0059	1.2071	.9503	.7922	.7922	.7095
4	.8488	1.0395	1.2826		.9054	.9054	
5	.9808	1.1233	1.3203	1.251	.9431	.9431	.9335
6	1.0374		1.3203	1.2883	.9997	.9808	
7	1.1317	1.2449	1.094	1.1763	1.1317	1.1317	1.1949
8	3.2442	1.0059	.9808	1.1203	2.9235	3.3008	2.8567
9	2.7349		.8488	.9149	3.4705	3.5837	2.8673
10	2.6406	.6602	.7922	.8775	2.8673		2.7633
11	2.2939	.6036			2.8837	2.9329	2.6658
12	1.4712	.5658	.4668	.4715	2.7854	3.2301	2.3807
13	1.0395	.4338		.415	2.7526	2.7035	2.5819
14	.8551	.415	.2987	.4527	3.1121	2.6216	2.2634
15	.9997	.3772		.3772	1.9006	2.2775	2.079
16	.3395	.5281	.2987	.4715	.3772	.4481	.3658
17	.3772	.547		.4715	.4904		.4207
18	.6602	.7167	.5975	.7545	.5281	.5601	.6584
19		1.1317		.9808	.9054	.9896	.8779
20	.9997	1.0374	1.0082	1.0751	.9431	.9149	.9511
21	1.094	1.4146	1.0978	.9808	.8488	.8962	.8596
22	1.1694	1.2071		.8488	.7202		.7316
23	1.0059	1.1317	.9804	.7356	.7545		.6584
24	.6602	1.0059	1.1317	.9831	.6602	.6602	.6722
Max	3.2442	1.4146	1.3203	1.2883	3.4705	3.5837	2.8673
Min	.3395	.3772	.2987	.3772	.3772	.4481	.3658
Avg	1.2042	.8788	.9439	.8356	1.4590	1.5596	1.4346

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214429 / 33 KV BELHE

Feeder No / Name : 204 / MALGANGA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	1.5927	1.6975	1.3108	.3772	.3772	
2	.3772		1.5844		.3772	.3772	.3174
3	.4527	1.5089	1.5844	1.3108	.4527	.4527	
4	.571		1.5089	1.3272	.5093	.5093	.2987
5	.6091		1.4712		.6036	.6036	
6	.6602		1.4146	1.3108	.6602	.6602	.2987
7	.7922	.6539	.7545	.7842	.7922	.8299	.3734
8	3.1687		.6413	.8029	2.9235	3.3951	.6642
9	3.7723	.5975	.5281	.6535	3.4705	3.4705	.6413
10	3.4705	.5093	.6036	.5975	2.9656		
11	2.9492	.4715		.5093	2.982	2.4905	2.2298
12		.3772	.4668	.4715	2.7854	2.4741	2.2801
13		.4338		.4338	2.6216	2.2611	2.2969
14		.3772	.2427	.3772	2.3922	2.1136	2.2466
15		.3772		.3772	1.7532		2.2131
16	1.8187	.4338	.2987	.4527		.4108	.3292
17	.4668	.4338		.4715	.3395		.4024
18	.5281	.7167	.4481	.5658	.3772	.4668	.4755
19		.7922	.4854	.7922	.5658		.5487
20	.6413	.7545	.5228	.7545	.6001	.6161	.6401
21	1.4754	2.2634	1.5074	.6602	.5658	.5788	.6036
22	1.8442	2.0748		.5658	.4527		.4938
23	1.8107	1.9805	1.4746	.415	.415		.3841
24	.3772	1.6194	1.8861	1.3927	.3772	.3772	.3734
Max	3.7723	2.2634	1.8861	1.3927	3.4705	3.4705	2.2969
Min	.3772	.3772	.2427	.3772	.3395	.3772	.2987
Avg	1.3770	.9457	1.0064	.7426	1.2765	1.2480	.9056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214429 / 33 KV BELHE

Feeder No / Name : 205 / PATILMALA CANOL
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7918	.2641	.2829	.2801	1.6032	1.6032	1.1469
2	1.6032	.2641	.2829		1.6032	1.6032	
3	1.6032	.2641	.2829	.2801	1.6032	1.6032	1.0486
4	1.5432		.2829		1.7918	1.7918	
5	1.8861		.3772	.3174	1.8861	1.8861	1.065
6	1.8861	.3961	.3772	.3361	1.8861	1.8861	1.475
7	.6224		.6602	.3734	.6602	.6602	.2801
8	.3772	1.9662	2.7349	1.9662	.3772	.3772	.3018
9	.3772	2.4577	3.0178	2.13	.3772	.3772	.2987
10	.2829	2.5396	3.1121	2.2119	.2829		.2801
11	.4715	2.5463		2.6406	.2829	.3361	.2378
12	.1886	2.4863	2.6216	2.6406	.2641	.2987	.2075
13	.1886	2.6406		2.9235	.2452	.2801	
14	.1886	2.8292	2.5396	2.6406	.2263	.2614	.2075
15	.1886	2.7349	2.5888	2.3148	.2075	.2614	.2452
16	.2075	.3395		.2829	.2195		.2743
17	.2641	.3772	.2801	.3395	.2263	.2614	.3109
18		.415		.415	.3018	.2801	.439
19	.3772	.5658	.3361	.5658	.5658	.3734	.4938
20	.4527	.5658	.3734	.5658	.5658	.0189	.5304
21	.3772	.2829	.3174	1.8861	1.6975	1.307	1.5089
22		.2829		1.9805	1.9805		1.7436
23	.2641	.2829	.2987	1.7918	1.7918		1.576
24	1.5432	.2561	.2829	.2801	1.6032	1.6032	1.2289
Max	1.8861	2.8292	3.1121	2.9235	1.9805	1.8861	1.7436
Min	.1886	.2561	.2801	.2801	.2075	.0189	.2075
Avg	.7584	1.1789	1.1079	1.3256	.9271	.8535	.7095

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214429 / 33 KV BELHE

Feeder No / Name : 206 / BELHE GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7922	.7167	.7922	.6348	.7545	.6859	
2	.7922	.7167	.7922	.5975	.7545	.7545	
3	1.0185	.7167	.9431		.8488	.8488	
4	1.226	.9054	1.0562	.7095	1.0185	1.0185	
5	1.3203	1.0374	1.226	.9335	1.0802	1.1883	
6	1.4146	1.2637	1.3203	1.1949	1.3203	1.3203	
7	1.5844	1.5844	1.4146	1.4563	1.5466	1.4523	
8	1.5089	1.6221	1.2071	1.4937	1.4146	1.5466	1.531
9	1.358	1.5278	1.2071	1.3443	1.2071	1.4146	1.2696
10	1.0185	1.358	1.1317	1.2323	1.1203		1.2696
11	1.0082	1.1317		1.1317	.8402	.9709	1.1317
12		.8488	1.1203	1.0185	.8215	.8589	1.094
13		.7167		.9054	.8299	.7655	1.0185
14	.8718	.6036	.8215	.7922	.8299	.6908	.3772
15	.8215	.7545		.9054	.8215	.6161	1.0185
16	.8215	.9054	.7282	.9431	.8215	.6535	1.0751
17	.9335	.9808		1.0374	.7842		1.094
18	.9709	1.4146	.9335	1.1694	.7842	.7468	1.2071
19		1.5844	1.1949	1.5466	1.2826	1.2696	1.3957
20	1.4712	1.4523	1.2696	1.5844	1.5844		1.5844
21	1.2323	1.1317	1.1949	1.3203	1.2346	1.1203	1.3203
22	1.0751	.9619		1.094	1.1317		1.0185
23	.8865	.9054	.6348	.8488	.8865		.8488
24	.7922	.6602	.7922	.6348	.7545	.7545	
Max	1.5844	1.6221	1.4146	1.5844	1.5844	1.5466	1.5844
Min	.7922	.6036	.6348	.5975	.7545	.6161	.3772
Avg	1.0913	1.0625	1.0411	1.0665	1.0197	.9830	1.1409

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214429 / 33 KV BELHE

Feeder No / Name : 207 / GUNJALWADI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.7167	.7545	.5601	.6602	.6602	
2	.7545	.7167	.7545		.6602	.6602	
3	.9054	.7167	.9054	.5975	.8299	.8299	
4	1.1317	.8488	1.1317		.9808	.9808	
5	1.2449	1.0374	1.2071	.8962	1.1317	1.1317	
6	1.358	1.2071	1.358	1.1203	1.226	1.226	
7	1.5278	1.5844	1.4523	1.307	1.5089	1.4146	
8	1.358	1.5775	1.358	1.5089	1.5466	1.5089	1.5684
9	1.2826	1.4712	1.1694	1.3443	1.1317	1.358	1.3443
10	1.0751	.9808	1.0185	.8589	1.0082		.6348
11	.9145	.9054		.8488	.7468	.7468	1.094
12	.8215	.7202	.8775	.8865	.6535	.6722	1.0185
13	.7095	.7545		.8488	.5975	.5601	.9431
14	.4481	.5658	.8589	.6516	.5415	.4108	.9054
15	.679	.7167		.7545	.5415		.9431
16	.7282	.8488	.5601	.9054	.7282	.6348	1.0185
17	.9335	.9054		.9431			1.0562
18	.9896	1.358	.7167	1.1317	.8962	.7468	1.1317
19		1.5466		1.5089	1.226		1.3203
20	1.307	1.4146	1.1949	1.5466	1.5089	1.1203	1.5466
21	1.1949	1.2071	.9896	1.358	1.3203	.9709	1.226
22	.9431	.9054		1.1317	1.0751		.9808
23	.7545	.8488	.6036	.9242	.7922		.7545
24	.7545	.7167	.7613	.5601	.6602	.6602	
Max	1.5278	1.5844	1.4523	1.5466	1.5466	1.5089	1.5684
Min	.4481	.5658	.5601	.5601	.5415	.4108	.6348
Avg	.9813	1.0113	.9818	1.0088	.9553	.9052	1.0929

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214429 / 33 KV BELHE

Feeder No / Name : 208 / ANE GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.5658	.6602	.6722	.6036	.6036	
2	.5658	.5658	.6602	.6348	.5487	.6036	
3	.8488	.5658	.8488		.8488	.8488	
4	1.1317	.7545	1.0185	.7842	1.0374	1.0374	
5	1.2826	.9808	1.226		1.226	1.226	
6	1.3203	1.3392	1.3203	1.1203	1.3203	1.3203	
7	1.6221	1.5655	1.4146	1.2696	1.4523	1.4523	
8	1.358	1.8107	1.358	1.3817	1.4403	1.5466	1.5684
9	1.226	1.4335	.8745	1.307	1.358	1.4146	1.3443
10	1.1317	.9619	.9808	1.1203	1.2696		.8962
11	.9335	.8488	.9335		.5975	.5601	1.094
12	.7468	.7545		.9431	.5415	.5601	1.0562
13	.5601	.6036	.8215	.8488	.4668	.5601	.9431
14	.4481	.5658		.7202	.3734	.415	.9054
15	.5228	.6602	.7468	.7545	.3734		.9431
16	.679	.7922		.8299	.4294		.9808
17	.8589	.8488	.7468	.7922	.5601		1.0185
18	1.0562	1.2826		1.0751	.6722		1.1694
19		1.6598	1.1949	1.4523	1.1317	1.0082	1.4523
20	1.2696	1.5089		1.6598	1.6032	.9522	1.5844
21		1.4146	1.1203	1.4146	1.358	.9709	1.1317
22	.8488	.9808		1.1317	1.0185		.9054
23	.7545	.8299	.8589	.8865	.7545		.679
24	.5658	.5487	.6602	.6722	.6036	.6036	
Max	1.6221	1.8107	1.4146	1.6598	1.6032	1.5466	1.5844
Min	.4481	.5487	.6602	.6348	.3734	.415	.679
Avg	.9226	.9934	.9692	1.0224	.8995	.9226	1.1045

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214460 / 33 KV KOLWADI

Feeder No / Name : 201 / Madh

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.3961	.3521	.2949	.2957	.168	.1867
2	.1848	.3584	.3222	.3391	.3772	.168	.1867
3	.2829	.3395	.3121	.3561	.4108	.168	.1867
4	.1848	.3772	.3506	.3772	.4108	.2241	.2241
5	.1829	.3961	.3898	.4161	.4435	.2987	.2957
6	.3734	.4338	.4298	.443	.439	.3961	.3511
7	2.2445	.4338	.415	.4108	.4108	.4338	.4251
8	.763	.4066	.4108	.4435	.6173	.763	.7545
9	.8048	.4066	.3982	.4294	.8619	.8478	.8551
10	.8817	.4294	.439	.462	.9389	.8309	.9054
11	.7545	.4108	.4066	.4481	.8718	.8309	.8288
12	.7545	.4066	.4251	.4435	.8551	.8048	.7625
13	.7042	.4207	.4435	.4481	.8383	.7712	.7459
14	.663	.394	.4615	.4108	.7956	.7209	.7293
15	.6299	.443	.402	.3881	.7625	.6882	.6706
16	.4066	.4656	.3403	.4024	.3921	.5121	.3326
17	.4435	.4477	1.3704	.4298	.4294	.3475	.3326
18	.4435	.5014	.4435	.439	.4294	.3921	.3696
19	.4251	.4525	.4854	.415	.4108	.4294	.3734
20	.3881	.3881	.4311	.3734	.3921	.3921	.3361
21	.3521	.3944	.4239	.2957	.2957	.3361	.2614
22	.3521	.373	.4144	.2241	.2614	.2987	.1867
23	.3521	.3521	.3638	.2218	.2054	.1867	.1867
24	.1867	.3961	.3521	.2949	.2561	.2054	.1867
Max	2.2445	.5014	1.3704	.462	.9389	.8478	.9054
Min	.1829	.3395	.3121	.2218	.2054	.168	.1867
Avg	.5392	.4093	.4410	.3836	.5167	.4673	.4448

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214460 / 33 KV KOLWADI

Feeder No / Name : 202 / Ballalwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9221	1.0269	.9335	1.1317	.8573	.9335	1.0164
2	1.0898	.9335	.9335	1.1317	.8383	.8402	1.0164
3	1.2003	.9335	1.0269	1.0374	.9012	.8402	1.0164
4	1.2803	.9335	1.0269	.9431	.9503	1.0269	1.0719
5	1.3169	1.0269	1.0269	1.0374	.9922	1.2136	1.2136
6	1.4003	1.0269	1.1203	1.226	1.0562	1.2323	1.307
7	1.4003	1.0269	1.2136	1.386	1.307	1.2136	1.4003
8	1.7737	1.8404	1.7147	1.95	1.6804	1.7375	1.9204
9	1.848	2.0683	1.95	2.2634	2.0328	1.9204	2.0485
10	2.0328	2.1384	2.0348	2.2939	2.1253	1.8099	2.1033
11	1.3717	2.0157	2.1195	2.2119	2.2177	1.8099	2.0328
12	1.7924	2.0805	2.1795	1.9204	2.0328	1.8099	2.0328
13	2.0328	1.9719	2.3472	1.8435	2.0328	1.7375	2.1253
14	1.9404	1.8652	2.0481	1.8435	2.1033	1.6461	2.1253
15	1.885	1.7804	1.95	1.8404	1.9204	1.6461	2.1253
16	1.885	1.9404	2.2405	2.0328	2.0119	1.7375	2.2177
17	1.9404	1.8671	2.2177	2.0119	2.1033	1.829	2.3101
18	1.848	1.7918	2.0538	1.7924	1.8671	1.6804	2.2177
19	1.6632	1.587	1.8671	1.643	1.587	1.4937	1.848
20	1.386	1.4003	1.6804	1.3717	1.4003	1.4003	1.6632
21	1.307	1.307	1.4003	.9536	1.1203	1.267	.8573
22	1.1203	1.2136	1.2136	.9431	1.0269	1.1765	.6859
23	1.0269	1.1203	1.2136	.8573	.9335	1.0745	.6859
24	.8192	1.0269	1.0269	1.1203	.7545	.9335	1.1088
Max	2.0328	2.1384	2.3472	2.2939	2.2177	1.9204	2.3101
Min	.8192	.9335	.9335	.8573	.7545	.8402	.6859
Avg	1.5118	1.4968	1.6058	1.5328	1.4939	1.4171	1.5896

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214460 / 33 KV KOLWADI

Feeder No / Name : 203 / Pimplegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6535	.5316	.5316	.5258	.7468	.5544	.462
2	.6535	.543	.5316	.5258	.7545	.5544	.462
3	.5658	.543	.4477	.5258	.6535	.5544	.462
4	.462	.6335	.4525	.6201	.6401	.6468	.5487
5	.3658	.6401	.543	.6268	.6283	.6401	.5487
6	.6535	.6401	.5487	.6335	.5731	.7316	.5487
7	.7545	.6401	.6401	.5487	.5601	.7316	.5487
8	.9745	.695	.6468	.7392	.985	1.0631	.964
9	1.0288	.7316	.7392	.924	.7011	1.3289	1.0517
10	1.0174	.7316	.823	1.0059	1.3003	1.2483	1.1145
11	1.0513	.7316	.8779	.9145	1.3003	1.2136	1.2003
12	1.1022	.7316	.905	.905	1.2003	1.2136	1.2003
13	1.0682	.7392	.905	.9335	1.286	1.1269	1.1736
14	1.0277	.6535	.905	.924	1.3523	1.0517	1.1736
15	.9945	.6602	.9145	.924	1.3003	.964	1.1022
16	.724	.6468	.9145		.6401	.724	.7392
17	.6335	.6535	.9145	.9145	.7316	.543	.7392
18	.6335	.6535	.924	.9335	.7392	.5544	.5544
19	.5544	.7392	.924	.8402	.7392	.5544	.7468
20	.5544	.6468	.8145	.8316	.7392	.5544	.3734
21	.543	.543	.6201	.7468	.7392	.5544	.7468
22	.5316	.5316	.5201	.7468	.6468	.5544	.5601
23	.5316	.5316	.5144	.6401	.6468	.5544	.4668
24	.6535	.5316	.5316	.5144	.7468	.6468	.5544
Max	1.1022	.7392	.924	1.0059	1.3523	1.3289	1.2003
Min	.3658	.5316	.4477	.5144	.5601	.543	.3734
Avg	.7389	.6385	.7121	.7585	.8480	.7860	.7518

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214460 / 33 KV KOLWADI

Feeder No / Name : 204 / Aalme

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3077	.6535	.6535	.6135	1.4754	1.2936	1.307
2	1.2597	.5601	.5601	.5373	1.4746	1.2012	1.307
3	1.3203	.5601	.5601	.7164	1.3123	1.2012	1.307
4	1.1401	.6535	.6602	.823	1.2483	1.386	1.4003
5	1.0814	.7468	.8488	.9145	1.2742	1.6057	1.5089
6	.9998	1.0269	1.1317	1.1576	1.2071	1.8298	1.6598
7	1.1203	1.2696	1.3817	1.3256	1.307	1.2696	1.2826
8	1.307	2.2131	1.6956	2.146	1.2936	1.2136	1.307
9	1.3443	2.3472	1.9943	2.3472	1.307	1.1576	1.307
10	1.4045	2.3205	2.13	2.3537	1.3306	1.1576	1.363
11	1.386	2.4863	2.4034	2.2874	1.2936	1.1576	1.2936
12	1.386	2.536	2.5484	2.1879	1.2323	1.1576	1.1827
13	1.3306	2.3482	2.4034	1.9685	1.386	1.1458	1.1827
14	1.2752	2.1285	2.2119	1.8884	1.3676	1.1458	1.1458
15	1.2567	1.9841	2.0485	1.7859	1.3676	1.1458	1.386
16	1.2567	1.0974	1.3575	1.4327	1.4045	1.2012	1.386
17	1.2567	1.1619	1.3647	.9593	1.4045	1.2197	1.4003
18	1.2136	1.1888	1.2936	1.0745	1.3121	1.2323	1.2936
19	1.1949	1.2696	1.1273	1.2323	1.2012	1.2323	1.2567
20	1.1576	1.1827	1.0164	1.358	1.0719	1.2323	1.2012
21	1.0269	1.0269	.961	1.3032	1.1603	1.1736	1.4217
22	.7842	.8402	.8871	1.326	1.2431	1.2574	1.3717
23	.6722	.7095	.7207	1.3923	1.2266	1.2574	1.286
24	1.3435	.6535	.6535	.6415	1.4419	1.2936	1.4003
Max	1.4045	2.536	2.5484	2.3537	1.4754	1.8298	1.6598
Min	.6722	.5601	.5601	.5373	1.0719	1.1458	1.1458
Avg	1.2011	1.3735	1.3589	1.4072	1.3060	1.2570	1.3316

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214460 / 33 KV KOLWADI

Feeder No / Name : 205 / Stone Crusher
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0168	.0328			
2			.017	.0164			
3			.0173	.0339			
4			.0175	.0345			
5			.0177				
6	.0373		.0179				
7	.0566		.0377				
8	.0509		.0187	.0185	.0343		.0373
9			.0181	.0503	.0497		.0373
10		.0187	.0183	.037	.0503		.0554
11		.0373	.037	.056	.0503		.0332
12		.037		.0554	.0335		.0332
13		.0549	.037	.056	.037		.0497
14		.0358	.0549	.0373	.037		.0497
15		.0532	.0914	.037	.037		.0335
16		.0358	.0716	.0366	.0185	.0366	.0554
17		.0895	.0924	.0358	.0185	.0366	.0554
18		.0358	.0739	.0366	.0187	.0191	.037
19				.0189	.0373		
20				.0373	.0373		
21			.017	.0185	.0185	.0187	
22			.0332	.0187	.0185	.0187	
23			.0328		.0185	.0187	
24			.0168	.0328		.0185	
Max	.0566	.0895	.0924	.056	.0503	.0366	.0554
Min	.0373	.0187	.0168	.0164	.0185	.0185	.0332
Avg	.0483	.0442	.0360	.0350	.0322	.0238	.0434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214531 / 33/11 KV NETWAD SUBSTATION

Feeder No / Name : 202 / 11 KV BANKARFATA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5201	.7095	.4854	.5544	.7459	.7293	.7377
2	.6135	.7468	.5375	.6468	.8288	.6706	.7712
3	.6661	.7842	.6135		.8718	.6952	.7956
4	.7265	.8402	.7362	.8316	.9389	.7122	.8288
5	.8059	.8962	.8596	.8871	1.0059	.8573	.8718
6	.9328	.9335	.905	.924	1.0898	.9088	.9389
7	1.0456	.9831	.9328	1.0534	1.2567	1.2936	
8	1.1458	1.1469	.9979	1.3245	1.4969	1.46	1.2197
9	1.3676	1.3599	1.0277	1.576	1.922	1.5524	1.3491
10	1.5708	1.406	1.4918	1.7604	1.7558	1.5524	1.4784
11	1.4784	1.7604	1.6575	1.7101	1.7737	1.2936	1.423
12		1.6356	1.6766	1.6598	1.7375	1.423	1.4784
13	1.4784	1.5089	1.643	1.6766	1.829	1.3306	1.5154
14	1.5154	1.3927	1.643	1.6933	1.8656	1.3306	1.5708
15	1.5364	.9831	1.6263	1.5402	1.7737	1.3352	.3475
16	1.5524	1.1946	1.7556	1.7187	1.8656	1.3491	.4024
17	1.5524	1.4563	1.7002	1.6632	1.885	1.386	1.3717
18	1.2936	1.2986		1.4969	1.848	1.2567	1.4632
19	1.1088	1.386	1.1088	1.1827	1.386	1.0719	1.251
20	1.0164		.924	.961	1.1088	1.0903	1.0534
21	.924		.8316	.8048	.9156	.8309	.8817
22	.8316		.7392	.788	.8383	.8383	.8478
23	.7392	.6878	.6468	.7459	.7865	.7293	.8048
24		.6468	.567	.5544	.663	.7373	.7042
Max	1.5708	1.7604	1.7556	1.7604	1.922	1.5524	1.5708
Min	.5201	.6468	.4854	.5544	.663	.6706	.3475
Avg	1.1101	1.1313	1.0916	1.2067	1.3412	1.1014	1.0481

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214404 / 33 KV GHODEGAON

Feeder No / Name : 201 / NARODI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	1.1736	1.1736	1.1904	.3353	2.0454	2.0454
2	.3353	1.1568	1.0395	1.1736	.3353		
3	.3185	1.1568	1.073	1.1736	.3185		2.0454
4	.3688	1.1568	1.3077	1.2071	.3856		2.0454
5	.4359	1.1568	1.4419	1.2574	.3688		2.0454
6	.503	1.291	1.4083	1.3077	.5533		2.2779
7	.6539	.3353	.3353	.57	.6203		2.0454
8	2.146	.4191	.4694	.7377	2.3472		2.0454
9	2.2801	.285	.6371	.6874	2.4646		2.0454
10	2.1628	.5868	.5365	.6371	2.7161		
11	2.364	.5365	.5197	.5868	2.8166		
12	2.2131	.503	.5365	.57	2.5819		
13	2.0454	.4694	.3521	.57	2.5484		
14	2.0622	.5533	.4024	.5533	2.4646		
15	1.9784	.5365	.3521	.57	2.0454		
16	.4024	.5533	.3856	.57			
17		.5365		.57			
18	.4024	.5197	.57	.6371			
19	.3353	.5533	.7545	.7377			
20	.3185	.5533	.6706	.6371			
21	1.4419	1.3077	1.4419	.5533			
22	1.4251	1.4251	1.3916	.4694			
23	1.3077	1.2742	1.358	.3688			
24	.3688	1.1736	1.1401	1.2407	.3521		2.0454
Max	2.364	1.4251	1.4419	1.3077	2.8166	2.0454	2.2779
Min	.3185	.285	.3353	.3688	.3185	2.0454	2.0454
Avg	1.1393	.8006	.8390	.7740	1.4534	2.0454	2.0712

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214404 / 33 KV GHODEGAON

Feeder No / Name : 202 / GHODEGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3012	.3189	.2835	.3189	.2658	.3898	.2835
2	.3012	.3012	.2835	.3012	.2481	.443	.2835
3	.2835	.3012	.3012	.3189	.2481	.5138	.3012
4	.3189	.3012	.2835	.3898	.3189	.5847	.3721
5	.4607	.3012	.6379	.567	.4961	.6556	.443
6	.5847	.6024	.8505	.7087	.815	.7265	.567
7	.7619	.7265	.8859	.815	.9036	.9922	.8682
8	.9036	.8682	.7796	.9922	.9214	1.1871	.9214
9	1.0808	.9568	.9568	1.0985	.8859	.9391	1.1163
10	.9568	.9214	.7087	1.0985	.9922	1.0277	
11	.9922	.9214	.7973	1.0808	.815	1.0808	
12	.815	.2835	.8505	1.0277	.8505	.9922	
13	.7087	.8505	.8328	.9568	.8328	1.0277	
14	.5493	.8859	.7619	.8682	.7973	1.0985	
15	.6733	.8859	.9036	.9391	.8505	1.134	
16		.9214	.9922	.9391	.8505	1.0277	
17		.8859	1.0277	.9391	.8682	.8859	
18	.8505	.7796	.7087	.815	.7619	.7442	
19	.8859	.8505	.7973	.7087	.815	.6733	
20	.7973	.7442	.7442	.6733	.7265	.6733	
21	.7087	.567	.6556	.6201	.6379	.6379	
22	.5316	.4252	.5138	.443	.5316	.443	
23	.4252	.3898	.3721	.3721	.3898	.3721	
24	.3189	.3366	.3189	.3189	.3189	.3366	.2835
Max	1.0808	.9568	1.0277	1.0985	.9922	1.1871	1.1163
Min	.2835	.2835	.2835	.3012	.2481	.3366	.2835
Avg	.6459	.6386	.6770	.7213	.6726	.7744	.5440

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214404 / 33 KV GHODEGAON

Feeder No / Name : 203 / SHINOLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5684	.4668	.4481	.5041	1.6804
2	1.4377	.4668	.4481	.4854	1.6244
3	1.419	.4854	.4805	.5041	1.1576
4	1.4563	.5041	.5975	.5601	1.2696
5	1.5684	.5228	.7095	.6348	1.4563
6	1.6804	.7282	.8215	.7282	1.6804
7	.7095	.8589	.8589	.8962	.9709
8	.8589	2.1658	3.0994	2.894	.9522
9	.8029	3.3794	3.1741	3.3421	.8402
10	.6161	3.0247	3.1367	3.062	.5975
11	.4668	3.4355	3.0247	2.9313	.6908
12	.5228	3.2487	2.894	2.894	.6722
13	.5788	3.3234	3.2861	2.8753	.6535
14	.5415	3.2861	3.2301	2.8567	.3734
15	.4854	2.9874	2.726	2.6513	.5228
16	.5415	.7095	.8775	.6348	.5415
17		.7468	.7468	.6161	
18	.6722	.7095	.8589	.8962	
19	1.0269	1.0082	1.1763	1.0082	
20	.9896	.9335	1.1016	.9709	
21	.8962		1.0082	1.8111	
22	.6535	.7095	.8029	1.8671	
23	.4854	.4481	.5975	1.8858	
24	1.7364	.4668	.4481	.5415	1.7551
Max	1.7364	3.4355	3.2861	3.3421	1.7551
Min	.4668	.4481	.4481	.4854	.3734
Avg	.9441	1.5050	1.5230	1.5855	1.0258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214404 / 33 KV GHODEGAON

Feeder No / Name : 204 / Kotamdara

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4321	.144	.144	.144	.3361	.4481	.4001
2	.4161	.16	.16	.128	.3041	.4481	.4001
3	.4001	.176	.16	.128	.2721	.4641	.4161
4	.4481	.192	.176	.16	.3681	.4801	.4641
5	.5761	.208	.2241	.2241	.4481	.4961	.5121
6	.6401	.2721	.2721	.2721	.5601	.5121	.5441
7	.3041	.3361	.2881	.3201	.3201	.3201	.3521
8	.2721	1.1843	1.2163	1.2803	.2721	.4001	.3681
9	.192	1.5043	1.1523	1.4083	.2401	.3361	
10	.208	1.4403	1.0883	1.2483	.192	.2721	
11	.064	1.5203	1.0562	1.2003	.2241	.2401	
12	.048	1.3283	1.0722	1.1203	.176	.2401	
13	.16	1.2483	.9922	1.1043	.208	.208	
14	.176	1.0883	1.2163	1.0562	.208	.192	
15	.192	.9922	1.1523	.9762	.208	.176	
16		.2561	.2721	.2721	.2401	.208	
17		.2241	.2881	.2561	.208	.2401	
18	.3361	.208	.2881	.3201	.2561	.2721	
19	.3521	.2881	.3681	.3361	.2881	.3041	
20	.3201	.2561	.3361	.4001	.3201	.2881	
21	.2881	.2241	.2721	.4961	.6401	.6722	
22	.208	.16	.2241	.4481	.6882	.6081	
23	.16	.144	.144	.4001	.5601	.5601	
24	.5121	.144	.144	.144	.3361	.4481	.4321
Max	.6401	1.5203	1.2163	1.4083	.6882	.6722	.5441
Min	.048	.144	.144	.128	.176	.176	.3521
Avg	.3048	.5708	.5295	.5768	.3281	.3681	.4321

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214404 / 33 KV GHODEGAON

Feeder No / Name : 206 / AAMONDI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0174	.3391	.3052	.373	1.0174
2	1.0513	.373	.3391	.3561	1.0174
3	1.0174	.407	.373	.373	.8817
4	1.0513	.4409	.4409	.4409	.9835
5	1.1022	.4748	.5765	.5426	1.0513
6	1.153	.5935	.7291	.6104	1.1361
7	.7291	.6952	.7461	.78	.6783
8	.6952	2.0008	2.1365	2.2721	.6613
9	.5426	2.2891	2.2721	2.5095	.6443
10	.4409	2.4247	2.1704	2.4756	.5765
11	.4578	2.3908	2.1534	2.4247	.3052
12	.4578	2.2721	2.1365	2.2382	.2883
13	.4409	2.2043	2.34	2.1534	.3222
14	.407	2.1365	2.3908	2.0348	.3052
15	.4239	1.9161	2.0856	1.7465	.2713
16	.4409	.6104	.5087	.5426	.3222
17		.5765	.5765	.5256	.407
18	.5935	.5765	.6443	.6104	
19	.763	.7461	.8817	.7291	
20	.7122	.7291	.78	.6443	
21	.6274	.6443	.6443	1.3904	
22	.4748	.4578	.5426	1.1869	
23	.373	.373	.4409	1.1191	
24	1.1022	.3222	.3052	.373	1.1022
Max	1.153	2.4247	2.3908	2.5095	1.1361
Min	.373	.3222	.3052	.3561	.2713
Avg	.6989	1.0831	1.1050	1.1855	.6651

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214445 / 33/11KV TALEGHAR

Feeder No / Name : 201 / TALEGHAR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3696	.3529	.3206	.3753	.4715	.332	.415
2	.3921	.3641	.3018	.3865	.4527	.3435	.3961
3	.3921	.3859	.3206	.4126	.4527	.353	.3961
4	.4481	.4444	.3395	.4591	.4527	.3987	.3961
5	.5729	.4873	.4527	.5505	.5847	.4879	.5093
6	.7023	.579	.5975	.6896	.6979	.5932	.679
7	.8131	.754	.8402	.7898	.9896	.7632	.9431
8	.8501	.8834	.8775	.8614	.924	.7618	.8316
9	.7682	.8667	.788	.7389	.9214	.7595	.7392
10	.6896	.7964	.788	.8256	.7701	.7891	.7522
11	.6519	.7265	.7362	.7289	.7778	.7442	.6823
12	.6042	.6556	.7158	.7343	.677	.691	.6591
13	.5521	.567	.6857		.6317	.5792	.6328
14	.5032	.5316	.6519		.6237	.6335	.5498
15	.5502	.4607	.6107		.6304	.6626	.5408
16	.5749	.5281	.6077	.6762	.5999	.6447	.5381
17	.6136	.5853	.6678	.7712	.6077	.6984	.4543
18	.6841	.6767	.5802	.8063	.6769	.6878	.6823
19	.8094	.7468	.791	.9593	.8157	.9054	.8538
20	.801	.6722	.7411	.8869	.8073	.9242	.7411
21	.7595	.6348	.6852	.8589	.6404	.811	.6922
22	.6367	.5228	.562	.679	.4923	.6979	.5319
23	.5322	.3772	.4126	.5281	.4168	.547	.3904
24	.3881	.4269	.3395	.3865	.4715	.3621	.415
Max	.8501	.8834	.8775	.9593	.9896	.9242	.9431
Min	.3696	.3529	.3018	.3753	.4168	.332	.3904
Avg	.6108	.5844	.6006	.6717	.6494	.6321	.6009

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214445 / 33/11KV TALEGHAR

Feeder No / Name : 202 / 11kV Bhimashankar

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0665	.0739	.0762	.0747	.1158	.1132
2	.0747	.0766	.0554	.085	.0739	.1249	.0943
3	.0747	.085	.0739	.0904	.0739	.1225	.0943
4	.0747	.0896	.0739	.1092	.0739	.1289	.0943
5	.1052	.0979	.0924	.1303	.0924	.1555	.1132
6	.1463	.1064	.128	.1466	.1294	.1903	.1509
7	.1646	.1475	.1646	.1866	.2033	.2255	.1886
8	.1646	.1647	.1463	.2012	.1991	.2016	.2033
9	.1578	.1385	.1448	.1647	.1629	.1701	.1478
10	.1244	.1029	.1417	.1486	.1629	.1451	.1494
11	.1087	.0671	.1162	.1276	.1182	.1086	.1116
12			.1187	.1402	.1244	.1086	.0923
13			.0956		.1116	.1029	.0824
14			.1073		.0967	.104	.075
15			.1144		.0852	.1227	.0758
16			.0991	.061	.072	.0876	.0878
17			.0945	.1214	.1058	.1086	.0814
18	.1504	.1753	.1	.1254	.1238	.1463	.0814
19	.2088	.2402	.2014	.1991	.2524	.1867	.1942
20	.2072	.2402	.2162	.2172	.2521	.2427	.2166
21	.1942	.2054	.207	.2195	.2282	.2054	.1867
22	.1589	.168	.1589	.1829	.1924	.1698	.1377
23	.1072	.0924	.1027	.1097	.1699	.132	.1075
24	.0754	.0786	.0943	.0806	.0924	.1469	.1132
Max	.2088	.2402	.2162	.2195	.2524	.2427	.2166
Min	.0747	.0665	.0554	.061	.072	.0876	.075
Avg	.1318	.1302	.1217	.1392	.1363	.1480	.1247

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214445 / 33/11KV TALEGHAR

Feeder No / Name : 203 / AHUPE

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0962	.0754	.0868	.0754	.0773	.0754
2	.0943	.0849	.0754	.0981	.0754	.0811	.0754
3	.1132	.0905	.0754	.1301	.0754	.0849	.0754
4	.132	.0981	.0943	.1272	.0754	.0962	.0754
5	.1509	.1188	.1132	.149	.0943	.1188	.0943
6	.1698	.1377	.1509	.1641	.132	.1528	.1132
7	.2075	.1943	.1886	.1924	.1886	.1754	.1698
8	.1698	.198	.1886	.2094	.1698	.1641	.1509
9	.1509	.1377	.1509	.1773	.1509	.1339	.132
10	.1245	.0943	.132	.1358	.0943	.0868	.0754
11	.0962	.0754	.083	.0886	.1056	.0566	.0717
12	.0547	.0566	.0792	.0754	.0773	.0566	.0698
13	.0472	.0754	.0585		.0811	.0377	.0622
14	.0736	.0532	.0566		.0698	.0377	.0566
15	.0698	.0566	.0622		.0736	.0377	.0453
16	.0736	.0754	.0641	.1132	.0811	.0566	.0679
17	.0905	.0754	.0886	.1132	.1019	.0754	
18	.149	.132	.1113	.1132	.1226	.132	.1
19	.2754	.2452	.2131	.2075	.2188	.1886	.2226
20	.2603	.2263	.2282	.2641	.215	.2452	.2263
21	.2188	.2075	.2226	.2075	.2112	.2263	.2263
22	.1924	.1494	.1792	.1698	.1471	.1698	.1547
23	.1566	.0924	.1151	.1132	.1151	.1132	.1094
24	.1132	.1207	.0754	.1056	.0943	.0962	.0943
Max	.2754	.2452	.2282	.2641	.2188	.2452	.2263
Min	.0472	.0532	.0566	.0754	.0698	.0377	.0453
Avg	.1366	.1205	.1201	.1448	.1186	.1125	.1106

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214457 / 33/11KV KALAMB S/S

Feeder No / Name : 201 / KALAMB

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.0514	.0857	.0514	.2401	.2401	.2572
2	.2401	.0514	.0686	.0514	.2743	.2401	.2743
3	.2401	.0514	.0686	.0514	.2915	.2572	.3086
4	.2572	.0514	.0686	.0514	.3429	.2915	.3429
5	.2915	.0857	.1029	.0857	.3772	.3429	.3772
6	.3772	.12	.1372	.12	.4458	.4287	.4287
7	.1543	.1372	.1372	.1372	.1372	.1372	.1372
8	.1543	.3086	.5316	.4801	.1372	.1372	.1372
9	.1372	.3429	.6001	.4287	.12	.12	.1543
10	.1372	.583	.5144	.4458	.12	.12	.1715
11	.1372	.6516	.4801	.4458	.12	.1372	.1715
12	.1372	.6687	.4287	.4801	.1372	.1372	.1372
13	.1372	.6173	.4115	.4801	.1372	.1372	.12
14	.1372	.6001	.4115	.4973		.1372	.1372
15	.1372	.5658	.4115	.5144	.1372	.1372	.1372
16	.1372	.12	.1372	.12	.1372	.1372	.1448
17	.1372	.12	.1372	.1029	.1372	.1543	.181
18	.1372	.12	.1372	.1372	.1372	.1543	.1448
19	.1372	.1372	.1372	.1372	.1372	.1715	.1448
20	.1372	.1372	.1372	.1543	.1372	.1715	.1267
21		.1372		.3601	.3772	.3772	.3721
22		.12		.3429	.3429	.3429	.3366
23		.1029		.2743	.2743	.2743	.3012
24	.2401	.0514	.1029	.0514	.2572	.2401	.2401
Max	.3772	.6687	.6001	.5144	.4458	.4287	.4287
Min	.1372	.0514	.0686	.0514	.12	.12	.12
Avg	.1821	.2472	.2499	.2500	.2155	.2093	.2202

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214457 / 33/11KV KALAMB S/S

Feeder No / Name : 202 / EKLAHARE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.583	.2401	.1715	.2401	.583	.6001	.583
2	.583	.2401	.1543	.2401	.6173	.6001	.6001
3	.6344	.2229	.1543	.2401	.6859	.6859	.6001
4	.6859	.2229	.1543	.2572	.6859	.703	.6516
5	.7202	.2401	.2058	.2572	.7716	.7716	.7373
6	.8059	.2401	.2743	.2743	.8573	.8573	.8916
7	.2743	.2401	.2572	.2743	.2401	.2401	.2572
8	.2915	.8402	1.2003	1.0288	.2572	.2401	.2915
9	.3429	.823	1.3889	1.0288	.2915	.2572	.3601
10	.3429	1.2346	1.0288	1.0631	.2915	.2572	.3086
11	.3429	1.3032		1.1145	.2915	.2743	.3086
12	.3429	1.3032	1.0288	1.1145	.2915	.2743	.2915
13	.3429	1.2346	1.0288	1.1317	.2915	.2572	.3086
14	.3429	1.2174	.9431	1.1317	.2743	.2572	.3429
15	.2572	1.2003	.9431	1.166	.2743	.2572	.3429
16	.2572	.2058	.3086	.2229	.2743	.2401	.3801
17	.2743	.2229	.3086	.2058	.2743	.2401	.3982
18	.2743	.2229	.3258	.2743	.2743	.2058	.3801
19	.2743	.2572	.3429	.2915	.2743	.2229	.3982
20	.2743	.2743	.3429	.2915	.2743	.2229	.3982
21		.2401		.7202	.8573	.8573	.8328
22		.2058		.6516	.7545	.7202	.815
23		.1715		.6173	.6859	.6516	.7087
24	.6001	.2401	.1715	.2915	.6001	.583	.583
Max	.8059	1.3032	1.3889	1.166	.8573	.8573	.8916
Min	.2572	.1715	.1543	.2058	.2401	.2058	.2572
Avg	.4213	.5351	.5367	.5887	.4572	.4365	.4904

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214457 / 33/11KV KALAMB S/S

Feeder No / Name : 203 / MAHALUNGE PADWAL SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.5144	.3944	.2058	.1715	.1715	.1715
2	.1543	.5144	.3772	.2058	.1715	.1543	.1543
3	.1543	.5144	.4801	.2058	.1886	.1543	.1543
4	.1715	.5144	.5144	.2229	.2058	.1715	.1715
5	.2229	.5487	.6001	.2401	.2058	.1886	.1886
6	.2058	.6001	.7202	.2572	.2229	.2058	.2229
7		.6173	.2058	.2743	.2401	.1886	.2401
8	1.0631	.5144	.2401	.3429		1.1317	1.2174
9	1.2003	.5144	.3086	.3429	1.2689	1.3203	1.4746
10	1.0288	.2058	.3086	.3258	1.3717	1.3717	1.4403
11	1.0288	.1886	.3258	.3258	1.2003	1.3203	1.406
12	1.0288	.1886	.3429	.3086			1.3717
13	.9431	.1715	.3429	.3086	1.2003	1.3375	1.3375
14	.8916	.1715	.3429	.3086	1.1145	1.3375	1.3466
15	.8916	.1543	.3429	.2915	1.0974	1.3032	1.1145
16	.2743	.12	.2572	.2058	.1715	.2229	.2896
17	.2743	.1029	.2572	.2572	.1715	.2229	.3258
18	.2743	.12	.2572	.2572	.2058	.2401	.3258
19	.2743	.1372	.2743	.2743	.2058	.2401	.3077
20	.2743	.1372	.2915	.2915	.2058	.2572	.2534
21		.1372		.2743	.2058	.2572	.2303
22		.5144		.2401	.1886	.2229	.1772
23		.4458		.2058	.1715	.2058	.1417
24	.1543	.5144	.4287	.2058	.1886	.1543	.1715
Max	1.2003	.6173	.7202	.3429	1.3717	1.3717	1.4746
Min	.1372	.1029	.2058	.2058	.1715	.1543	.1417
Avg	.5324	.3401	.3625	.2658	.4716	.5383	.5931

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214457 / 33/11KV KALAMB S/S

Feeder No / Name : 204 / Ganeshwadi SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.2572	.2058	.2572	.3944	.4287	.4801
2	.4287	.2572	.1715	.2572	.4115	.4287	.463
3	.4287	.2572	.1715	.2572	.4115	.463	.463
4	.4801	.2572	.2058	.2743	.463	.5144	.4801
5	.5144	.2743	.2401	.2743	.5487	.6001	.6001
6	.6687	.2743	.3086	.2915	.6859	.703	.7202
7	.2401	.2743	.2743	.2915	.2743	.3429	.2229
8	.3086	.4287	1.2346	.6687	.3429	.3601	.3086
9	.3772	.6001	1.3717	.6859	.5144	.3772	.4973
10	.3944	1.3032	1.3717	1.1145	.5144	.3772	.4801
11	.3944	1.406	1.3546	1.2003	.463	.3944	.4458
12	.3944	1.3717	1.3375	1.2346	.463	.3944	.463
13	.3944	1.3717	1.3375	1.2346	.4458	.3772	.4115
14	.3944	1.3375	1.286	1.2003	.4287	.3772	.3601
15	.3429	1.286	1.2517	1.0974	.4115	.4115	.3944
16	.3772	.2743	.3429	.2743	.3429	.3772	.4344
17	.3772	.2572	.3772	.2915	.3429	.3429	.4525
18	.3772	.2572	.3772	.2915	.3429	.3086	.4344
19	.4287	.3086	.4287	.3429	.3772	.3086	.4525
20	.4458	.3601	.4287	.3772	.3772	.2915	.3801
21		.3429		.6001	.6173	.6173	.5847
22		.3086		.5144	.5316	.5487	.6556
23		.2572		.4287	.5144	.5144	.567
24	.3429	.2572	.1886	.2572	.3944	.4287	.4973
Max	.6687	1.406	1.3717	1.2346	.6859	.703	.7202
Min	.2401	.2572	.1715	.2572	.2743	.2915	.2229
Avg	.4042	.5658	.6793	.5716	.4422	.4287	.4687

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214457 / 33/11KV KALAMB S/S

Feeder No / Name : 205 / 11kV Nandur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	14-FEB-18
HR	Load (MW)
11	3.0864
12	3.0864
13	2.9492
14	2.7606
15	2.7606
16	1.1765
17	1.2851
Max	3.0864
Min	1.1765
Avg	2.4435

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214457 / 33/11KV KALAMB S/S

Feeder No / Name : 206 / 11kv Lauki

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0631	1.3717	1.1145	1.0974	1.0631	1.1145	1.0631
2	1.166	1.3717	1.1145	1.0974	1.0288	1.166	1.1145
3	1.2346	1.3717	1.166	1.0288	1.0631	1.2346	1.1831
4	1.3375	1.3717	1.286	1.0288	1.1145	1.3375	1.2346
5	1.4746	1.3717	1.3889	1.0631	1.2346	1.5604	1.3717
6	1.4746	1.406	1.5947		1.5432	1.5604	1.5947
7	1.0117	1.5089	1.0288	1.046	.9602	.9259	1.046
8	2.3148	1.8861	1.4575	2.4863	2.4863	2.8292	3.0007
9	2.6235	1.8861	1.5432	2.4006	3.0521	3.0864	3.275
10	2.572	1.9719	1.7147	2.452	2.915	3.1722	3.0864
11	2.572	1.989	1.7147	2.4863	2.915	2.915	3.0864
12	2.4863	1.989	1.9719	2.3663	2.915		3.0864
13	2.4863	1.9547	1.9376	2.2291	2.915	2.8292	2.9492
14	2.4863	1.9204	1.9204	1.989	2.7435	2.8807	2.7606
15	2.4006	1.8861	1.9376	1.7833	1.0288	2.9492	2.7606
16	1.0288	.9088	1.0288	.8916	1.0288	.8745	1.1145
17	1.0288	.9431	1.0631	.9431	1.0288	.9945	1.2851
18	1.1145	.9945	1.0631	.9945	1.2003	.9945	1.3394
19	1.2003	1.0288	1.0974	1.0631	1.2003	1.0631	1.4118
20	1.286	1.0631	1.1488	1.0974	1.3032	1.0802	1.3575
21		1.3717		1.4232	1.3717	1.3889	1.5203
22		1.2346		1.3032	1.2003	1.3032	1.4529
23		1.2003		6.3443	1.1145	1.2003	1.0985
24	1.1145	1.3717	1.166	1.1145	1.1145	1.1145	1.0288
Max	2.6235	1.989	1.9719	6.3443	3.0521	3.1722	3.275
Min	1.0117	.9088	1.0288	.8916	.9602	.8745	1.0288
Avg	1.6894	1.4739	1.4028	1.7274	1.6475	1.7206	1.8426

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214474 / 33 KV WADGAON

Feeder No / Name : 201 / Kolwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3052	1.1022	.6613	.9156	.1865	.2713	.3052
2	.3052	1.1869	.6783	.9156	.1865	.3052	.2883
3	.2883	1.2209	.6783	.8817	.2035	.3391	.3052
4	.373	1.1869	.7122	.8817	.2374	.3391	.3391
5	.4917	1.153	.7461	.8987	.2543	.373	.5087
6	.6443	1.0174	.763	.9156	.3222	.5087	.6274
7	.6783	.8309	.6613	.373	.3052	.5596	.6783
8	1.2209	.5087	.6274	.4239	1.153	1.4582	1.4413
9	1.406	.4409	.5426	.407	1.2039	1.543	1.4582
10	1.4243	.39	.4578	.4409	1.2548	1.6617	1.4074
11	1.6108	.373	.4239	.373	1.56	1.3735	1.3735
12	1.4413	.39	.39	.39	1.5769	1.4922	1.2887
13	1.3565	.3391	.3561	.39	1.5261	1.543	1.2548
14	1.2378	.3391	.3391	.3561	1.4243	1.3565	1.1022
15	1.1361	.373	.373	.3222	1.3735	1.2548	1.0343
16	.373	.3222	.3391	.2713	.407	.373	.407
17	.4239	.3052	.373	.3052	.3561	.4748	.39
18	.4578	.373	.4239	.3052	.5087	.3391	.407
19	.5765	.4917	.6274	.39	.5765	.6274	.4239
20	.6104	.5596	.6104	.407	.5087	.5765	.4239
21	.8478	.9835	1.0004	.373	.5256	.4748	.373
22	.9496	.8648	.8987	.2035	.373	.39	.3561
23	1.0513	.78	.9156	.2035	.373	.2883	.3391
24	.2883	.9326	.6783	.9326	.1865	.2543	.2883
Max	1.6108	1.2209	1.0004	.9326	1.5769	1.6617	1.4582
Min	.2883	.3052	.3391	.2035	.1865	.2543	.2883
Avg	.8124	.6860	.5949	.5115	.6910	.7574	.7009

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214474 / 33 KV WADGAON

Feeder No / Name : 202 / Sultanpur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7773	.2458	.1475	.1802	1.0322	1.0814	1.1469
2	.7287	.2294	.1311	.1966	1.0159	1.1469	1.1469
3	.7611	.2294	.1638	.1966	.9831	1.1797	1.1142
4	.9069	.2294	.2622	.1966	1.0159	1.2289	1.1469
5	.9555	.2458	.2949	.213	1.0322	1.2289	1.1797
6	.9393	.2622	.3113	.2458	1.0486	1.1469	1.2125
7	.3725	.3768	.3768	.3768	.3277	1.0322	.3605
8	.4534	1.2289	1.8679	1.8679	.4915	.4588	.3932
9	.426	1.9826	1.9662	2.13	.3768	.3605	.3768
10	.4049	2.0809	2.1136	2.1136	.2294	.3768	.3932
11	.3401	2.0153	2.0645	1.9498	.2622	.3932	.3932
12	.3441	1.9498	2.0481	1.8679	.2785	.3605	.3768
13	.3277	1.9662	1.8023	1.9334	.2785	.4096	.3768
14	.3277	1.8023	1.8842	1.8842	.2785	.4096	.3605
15	.2785	1.704	2.0153	1.6712	.2785	.4096	.3605
16	.2949		.4424	.2622	.2949	.4588	.2949
17	.2949	.2949	.3932	.3113	.3113	.4588	.2785
18	.3113	.3277	.3605	.2785	.1311	.2785	.3932
19	.3441	.3113	.426	.3605	.3932	.3113	.3768
20	.3605	.3277	.3932	.3768	.3605	.3113	.2622
21	.3932	.2785	.2622	1.0322	.9012	1.1633	1.1469
22	.4096	.1802	.213	1.0486	.9831	1.2289	1.1469
23	.3277	.1311	.213	.9831	.9012	1.1305	1.0486
24	.7935	.2949	.1311	.1966	1.0159	.8356	1.1142
Max	.9555	2.0809	2.1136	2.13	1.0486	1.2289	1.2125
Min	.2785	.1311	.1311	.1802	.1311	.2785	.2622
Avg	.4947	.8128	.8452	.9114	.5926	.7250	.6834

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214474 / 33 KV WADGAON

Feeder No / Name : 203 / 11kV Chass

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	1.2574	.8551	.9724	.4024	.3018	.3521
2	.3521	1.4922	.8551	.9724	.3856	.3018	.3521
3	.3521	1.5089	.8383	.9556	.3856	.3353	.3688
4	.5365	1.5927	.9221	.9389	.3688	.3688	.503
5	.6371	1.6095	.9724	.9724	.3856	.4024	.7042
6	.7209	1.5089	1.0395	.9724	.4024	.4191	.788
7	.7545	1.1904	.8886	.8383	.8551	.7545	.8383
8	1.4922	.5197	.6539	.6539	1.5089	1.7604	1.7939
9		.4694	.503	.503	1.7436	***	1.8442
10		.3353	.3688	.3353	1.5257		1.8778
11			.3521	.2515	1.7939	1.6766	1.8945
12	1.9281	.3018	.3856	.2012	1.6598	1.3748	1.8945
13	1.7436		.218	.218	1.7101	1.4419	1.9113
14	1.6766		.1844	.218	1.7436	1.5089	1.6933
15	1.6933		.2012	.2012	1.7939	1.861	1.5424
16	.3018		.218	.2012	.3353	.2683	.4527
17	.3185	.3688	.2347	.218	.3353	.3353	.4862
18	.3185	.4191	.3185	.2515	.3688	.3018	.57
19	.6706	.5533	.6036	.5868	.5365	.6036	.5636
20	.6539	.6874	.6539	.6874	.5197	.7042	.7042
21	.6706	1.0395	.9724	.6371	.6371	.6371	.6706
22	.8383	.9221	.9724	.4862	.4359	.4862	.57
23	.9389	.9892	.9556	.4694	.3688	.3856	.503
24	.3521	1.0059	.8718	.9389	.4024	.2683	.3688
Max	1.9281	1.6095	1.0395	.9724	1.7939	15.3574	1.9113
Min	.3018	.3018	.1844	.2012	.3353	.2683	.3521
Avg	.8231	.9353	.6266	.5700	.8585	1.3850	.9686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214486 / 33/11 KV Peth subststion.

Feeder No / Name : 203 / 11 KV Pargaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.2401	.2229	.218	.1029
2	.12	.2058	.2229	.218	.1029
3	.12	.2058	.2229	.218	.12
4	.1372	.2401	.2401	.2347	.12
5	.1543	.3086	.2401	.2683	.1372
6	.1886	.3601	.3429	.3353	.1372
7	.2229	.1886	.1886		.2058
8	.4862	.2058	.2229		.5487
9	.5365	.2401	.2957	.2229	.7373
10	.5487	.1543	.1715	.1715	.703
11	.4801	.1715	.2058	.1715	.6344
12	.5144	.1715	.2058	.1715	.6173
13	.4801	.1886	.1372	.12	.6344
14	.4801	.1886	.1372	.12	
15	.4287	.1715	.12	.12	
16	.1715		.12	.1029	
17	.1715	.2229	.1372	.12	
18	.1886	.12	.1372	.12	
19	.2058	.2058	.1886	.2058	
20	.2058	.1715	.1715	.1886	
21	.3086	.2915	.3185	.1715	
22	.2915	.3258	.285	.1372	
23	.2915	.2743	.2515	.12	
24	.12	.2743	.2401	.2347	.12
Max	.5487	.3601	.3429	.3353	.7373
Min	.1029	.12	.12	.1029	.1029
Avg	.2898	.2229	.2094	.1814	.3515

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214486 / 33/11 KV Peth subststion.

Feeder No / Name : 204 / Peth GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3547	.3601	.3258		.3258	.3258	.3547
2	.3361	.3429	.3258		.3258	.3258	.3361
3	.3734	.3429	.3086		.4115	.3772	.3547
4	.4294	.4458	.3944	.4108	.4801	.4801	.4108
5	.5975	.6344	.5316		.583	.6173	.5415
6	.8029	.9945	.7202	.7282	.7888	.823	.7842
7	.8589	.9945	.7716		.9774	.9602	.8402
8	.6348	.7202	.6173	.7468	.8059	.8059	.7655
9	.4481	.6468	.5729	.5544	.7207	.7392	.5544
10	.4458	.5175	.5544	.5729	.462	.5729	
11	.463	.5544	.499	.5359	.4066	.5175	.462
12	.3944	.499	.4805	.499	.499	.4805	.462
13	.3429	.5175	.3696	.462	.499	.4066	.4805
14	.3429	.4066	.4435	.4435	.462	.4251	.3511
15	.3944	.3696	.4066	.4066	.3881	.4066	.3511
16	.4801		.4435	.4805	.4251	.3511	.3881
17	.3601	.3944	.5228	.4287	.3944	.4854	.3601
18	.4458	.5658	.5415	.6001	.3944	.4854	.5144
19	.6173	.7888	.8215	.9088	.6344	.7842	.7888
20	.7716	.7545	.7842	.823	.7888	.7655	.7888
21	.6516	.6687	.6722	.7545	.6859	.5975	.6516
22	.6173	.6001	.6161	.6344	.5658	.5601	.583
23	.5144	.3944	.4854	.5316	.4973	.4481	.4801
24	.3734	.4287	.3429	.3921	.3429	.4287	.3547
Max	.8589	.9945	.8215	.9088	.9774	.9602	.8402
Min	.3361	.3429	.3086	.3921	.3258	.3258	.3361
Avg	.5021	.5627	.5230	.5744	.5360	.5487	.5199

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214402 / 33/11KV JUNNAR

Feeder No / Name : 201 / SHIVNERI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8296	.6706	.743		1.6004	1.7604
2	1.8665	.6783	.8436		1.5708	1.6766
3	1.8107	.7011	.7819		1.5154	1.6575
4	1.8642	.6706	.8109		.9859	1.7204
5	1.957	.7377	.8177		1.1294	1.8652
6	2.0452	.7796	.8459		1.1288	2.0481
7	1.4506	2.4006	1.6918		1.2037	1.2431
8		2.524	2.143			1.2752
9		2.2558	2.6505			
10		2.2558		2.6292		
11		2.3685	2.9664	2.6292		
12		2.6886	3.2047	2.7006		
13		2.3826	3.1352	2.4326		
14	1.4243	2.4291	3.1361	2.4996		
15	1.5261	2.4108	2.93	2.5926		
16	1.3923	1.1145	1.379	.5247		
17	1.4746	1.2003	1.5223	1.086		
18	1.5223	1.1145	1.3998	1.0715		
19	1.5261	.7895	1.0791	.7895	1.387	
20	1.4243	.8573	1.0099	.8002	1.2763	
21	1.1469	.7895	.9646	1.2803	2.0153	
22	.9717	.7331	.8589	1.5893	2.079	
23	.7712		.7973	1.4289	1.989	
24	1.7556	.7545	.6249		1.5684	1.7804
Max	2.0452	2.6886	3.2047	2.7006	2.079	2.0481
Min	.7712	.6706	.6249	.5247	.9859	1.2431
Avg	1.5422	1.4481	1.5798	1.7182	1.4961	1.6697

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214402 / 33/11KV JUNNAR

Feeder No / Name : 202 / MANIKDOH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3841	1.2742	2.1712		.4001	.4294
2	.3511	1.1736	2.3765		.4161	.4207
3	.2801	1.1736	2.3765		.4481	.4163
4	.3109	1.2548	2.4383		.4001	.4572
5	.3761	1.3176	2.4691			
6	.6767		2.3122		.4801	
7	.8869	1.8652	.7232		.4144	
8	2.2857	2.2801	.7034		2.1994	
9	2.4413	.4793			4.449	
10	2.3472	.4512		.5639		
11	2.3472	.5761	.7421	.5639		
12	2.2466	.4858	.823			
13	2.0348	.5144	.8417			
14	1.8442	.4858	.7973	.4641		
15	1.8442	.4001	.8775	.4287		
16	.7377	.5247	.9328	.5556		
17	.7377	.5075	.8417	.4793		
18	.7042	.5075	.823	.4572		
19	.7042	.6203	.7701	.6554		
20	.7377	.5716	2.167	.5498		
21	1.1736	2.1719	2.0022	.6093		
22	1.1873	1.2407	1.9313	.4588		
23	1.3413		1.8959	.3841		
24	.4119	1.4243	2.1148		.3765	.4294
Max	2.4413	2.2801	2.4691	.6554	4.449	.4572
Min	.2801	.4001	.7034	.3841	.3765	.4163
Avg	1.1830	.9682	1.5059	.5142	1.0649	.4306

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214402 / 33/11KV JUNNAR

Feeder No / Name : 203 / 11 kV OZAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6283	1.4403	1.4861	1.825	.7682
2	.6099	1.3565	1.3817	1.5581	.8029
3	.6401	1.2887	1.0715	1.5769	.695
4	.8596	1.3032	1.0433	1.8473	.643
5	.9328	1.2742	1.1279	2.1399	.6447
6	1.0566	1.3413	1.2407	1.701	.6203
7	1.1888	.9054	1.1736	1.4506	1.0822
8	1.9004	1.0288		1.5223	1.2029
9	2.0957	.8459			2.4966
10	2.13				2.652
11	2.0119				2.6993
12	2.0119				2.6282
13	1.8442				2.4078
14	1.5851				2.1628
15	1.6766				2.1195
16	.6036	1.1431	1.2715	1.2963	
17	.7682	1.2407	1.3643	1.2548	
18	1.0059	1.1279	1.4148	1.2574	
19		1.2289	1.4198	1.4243	
20	1.2742	1.2163	1.3432		
21	1.3413	1.0997	2.0978	1.0288	
22	1.4083	1.2308	2.1085	.9633	
23	1.3413		2.1176	.7529	
24	.7499	1.4746	1.6636	2.0814	.8002
Max	2.13	1.4746	2.1176	2.1399	2.6993
Min	.6036	.8459	1.0433	.7529	.6203
Avg	1.2898	1.2086	1.4579	1.4800	1.5266

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214402 / 33/11KV JUNNAR

Feeder No / Name : 204 / JUNNAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9694	1.3176	.8642		1.1843	1.1765
2	.9055	1.1869	.8619		1.2163	1.0745
3	.823	1.2403	.8288		1.2163	1.086
4	.7865	1.2269	.8333		1.2643	1.1888
5	1.0164	1.2407	.7331		1.1431	1.2536
6	1.3352	1.4883	1.0715		1.3443	1.2971
7	1.8804	1.6461	1.5718		1.3817	1.6263
8	2.167	1.8442	1.6918		1.4662	2.0287
9	2.0178	1.4662	1.579		1.7147	
10	1.7436	1.579		1.8046		
11	1.4083	1.5718	2.2365	1.5783		
12	1.3413	1.1279	1.8804	1.4861		
13	1.2887	1.2963	1.9456	1.2717	2.0178	
14	1.2407	.8573	1.7187	1.1138		
15	1.1869	.9145	1.4899	1.2037		
16	1.2548	.9587	1.2094	1.2803		
17	1.4083	1.0288	1.3073	1.2654		
18	1.6095	1.1138	1.4661	1.1145		
19	1.8442	1.3817	1.828	1.6861		
20	1.8679	1.5364	2.0022	1.6004		
21	1.6766	1.5508	1.9313	1.6644		
22	1.6095	1.3535	1.7194	1.2163		
23	1.5089		1.5181	1.1004		
24	1.1888	1.4022	1.1043		.9846	1.3289
Max	2.167	1.8442	2.2365	1.8046	2.0178	2.0287
Min	.7865	.8573	.7331	1.1004	.9846	1.0745
Avg	1.4200	1.3187	1.4519	1.3847	1.3576	1.3400

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214402 / 33/11KV JUNNAR

Feeder No / Name : 205 / Pimpalgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381				
2	.0381				
3	.0381				
4	.0381				
5	.0381				
6	.0381		.0004		
7	.0381				.0004
8	.0381				.0004
10				.0004	
11		.0004			
12			.0381	.0004	
13		.0004	.0381	.0004	
14			.0381		
15		.0004	.0381		
16			.0381		.0373
17		.0282	.0381		.0373
18		.0004	.0381		.037
19			.0381		.0377
20			.0381		.0377
21		.0004	.0381	.0282	.0362
22		.0004	.0381		.0377
23			.0381	.0004	.0366
24	.0381				.0004
Max	.0381	.0282	.0381	.0282	.0377
Min	.0381	.0004	.0004	.0004	.0004
Avg	.0381	.0044	.0352	.0060	.0272

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214402 / 33/11KV JUNNAR

Feeder No / Name : 206 / 11kv Amrapur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4887		.6173	.2686	.5498
2	.4477		.6767	.3045	.5647
3	.5304		.6908	.3366	.6081
4	.6626		.6493	.4119	.6081
5	.7059		.6173	.3801	.5716
6	.7421		.679	.4835	.6203
7	.9328		.6344	.2601	.6173
8	1.5384		.5213		.679
9			.5075	.3012	1.8842
10		.4572			.3511
11		.643	.9745		1.3592
12		.6344	1.1041	.3384	1.4413
13		.743	1.1283	.3666	1.5083
14		.5792	1.1765	.679	1.5083
15		.643	1.0924	.5639	1.4255
16		.5639	1.0208	.5796	
17		.5639	.9134	.6249	1.3735
18		.6344	.9745		1.2445
19		.643	.9465	.724	1.1233
20		.6401	1.0317		.9779
21		.5075	1.0566	.6203	.7973
22		.5053	.8507	.6241	.5552
23	.9389		.9036	.6401	.5093
24	.5304		.744	.3439	.5639
Max	1.5384	.743	1.1765	.724	1.8842
Min	.4477	.4572	.5075	.2601	.3511
Avg	.7518	.5968	.8483	.4659	.9322

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214402 / 33/11KV JUNNAR

Feeder No / Name : 207 / 11 kV HIRDI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2033	.6036	.2932	.7701	.1429
2	.2012	.6036	.282	.7108	.176
3	.2353	.6104	.282	.7865	.192
4	.2715	.6036	.2976	.8417	.1715
5	.3109	.6104	.282	.8869	.176
6	.3475	.57	.2976	.7421	.1646
7	.462	.3353	.2679	.0532	.2315
8	.985		.1646	.0914	.2286
9	.9962		.1429		.4193
10	.9835	.1269		.1286	.9991
11	.9054	.1269	.3077	.16	1.0208
12	.8383	.1269	.3077		1.1273
13	.8383	.141	.3475		1.0924
14	.7377	.128	.3012	.1128	1.0317
15	.6802		.3403	.1	.9391
16	.3688	.1189	.3761	.1698	.3109
17	.3353	.1235	.3988	.1543	.4251
18	.3018	.1217	.4835	.1572	.4668
19	.3353	.1974	.5249	.1783	.567
20	.3277	.1833	.5552		.567
21	.503	.2397	.5194	.1572	.4715
22	.57	.2968	.4477	.125	.3772
23	.57		.4784	.1143	.3109
24	.2378	.6371	.3102	.6984	.1217
Max	.9962	.6371	.5552	.8869	1.1273
Min	.2012	.1189	.1429	.0532	.1217
Avg	.5228	.3253	.3482	.3569	.4888

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214412 / 33/11KV APTALE

Feeder No / Name : 201 / Amboli

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2273	.8121	1.0067	1.063	.2643	.2275	.2268
2	.1896	.7605	.9403	.9521	.2266	.1898	.1892
3	.1899	.7461	.9424	.9069	.2259	.1898	.1894
4	.2659	.7011	.8881	.9332	.1879	.2659	.2273
5	.3613	.7019	1.0177	1.1666	.2643	.3799	.3021
6	.4179	.7578	1.1405	1.243	.3409	.4559	.3961
7	.5687	.5497	.909	.5859	.5303	.5698	.5497
8	1.8031				1.8498	1.9113	1.8138
9	2.0645				2.1777	2.2338	1.7932
10	1.7032				2.3926	2.135	1.7393
11	2.1502				2.2875	2.0036	1.7032
12	1.8045				1.7974	1.9604	1.5582
13	1.4899			.3409	1.7893	1.865	1.4838
14	1.4986			.4141	1.8568	1.6946	1.3811
15	1.4609			.4154	1.9504	1.3489	1.3016
16	.2611	.6042	.4129	.5287	.2975	.2835	.2601
17	.2801	.64	.4744	.6432	.3913	.3409	.3006
18	.3573	.7175	.4531	.7153	.3937	.3591	.3378
19	.5481	.8703	.6048	.8522	.5303	.4183	.4725
20	.5871	.8143	.7189	.872	.5865	.4734	.5118
21	1.0985	1.3389	1.3621	.7204	.4929	.4919	.5123
22	1.1556	1.4076	1.2463	.606	.4179	.4166	.3795
23	1.0334	1.1504	1.1767	.4154	.303	.3027	.3033
24	.2459	.813	1.0883		.2649	.2646	
Max	2.1502	1.4076	1.3621	1.243	2.3926	2.2338	1.8138
Min	.1896	.5497	.4129	.3409	.1879	.1898	.1892
Avg	.9068	.8366	.8989	.7430	.9092	.8659	.7797

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214412 / 33/11KV APTALE

Feeder No / Name : 203 / Somatwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3352	.7663	.7718	.8962	1.3627	1.4586	1.6312
2	1.3077	.7842	.7341	.8436	1.3027	1.3397	1.4873
3	1.381	.8419	.8053	.8232	1.3137	1.3181	1.4329
4	1.4752	.8865	.785	.9364	1.4042	1.4419	1.5595
5	1.5586	1.2852	.8659	1.0862	1.4137	1.5586	1.6511
6	1.6035	1.2878		1.1623	1.5621	1.667	1.6869
7	1.323	1.4742	1.0984	1.4046	1.0984	1.2474	1.6702
8		2.1076	2.4482	2.3156	1.0007		
9		2.4701	2.807	2.9334			
10		3.0617		2.9438			
11		3.0911	3.1149	2.7654			
12		3.1059	2.9775	2.8295			
13		2.7462	2.761	2.7069			
14		2.8761	2.6581	2.6289			
15		2.8679	2.492	2.407			
16	1.5822	1.3602	1.709	1.1328	1.6718	1.6139	
17	1.8242	1.4519	1.5926	1.3644	1.5449	1.6651	1.5741
18	1.8242	1.4608	1.7961	1.3929	1.6973	1.7399	1.6211
19	1.8709	1.4393	1.6838	1.5324	1.6293	1.7828	1.6293
20	1.824	1.3783	1.481	1.4582	1.432	1.7587	1.487
21	1.3203	1.0762	1.3123	2.5039	1.8704	1.7382	1.7414
22	1.1128	.9629	1.1974	1.6823	1.9417	1.7737	1.946
23	.8266	.8119	1.0466	1.4763	1.7436	1.6855	1.6771
24	1.3694	.8029	.9364		1.3827	1.6718	
Max	1.8709	3.1059	3.1149	2.9438	1.9417	1.7828	1.946
Min	.8266	.7663	.7341	.8232	1.0007	1.2474	1.4329
Avg	1.4712	1.6832	1.6852	1.7924	1.4925	1.5913	1.6282

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214416 / 33 KV HIVARE

Feeder No / Name : 201 / SHIROLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8192	.9393			.6516	.6516
2		.8259	.9717			.6154	.6154
3		.8684	.9717			.6335	.5792
4	.5914	.9069	.9717			.7095	.6154
5	.6219	.9374	1.004	1.0227		.7392	.6154
6		1.0852	1.004			.7655	.6335
7		1.1523	.7964		1.2803	1.3757	.7059
8	1.5402	1.0719	1.1403	.8131		1.5402	1.4737
9	1.7004		1.1041	.8501	1.5074		1.7004
10	1.989	1.1946	1.1888		1.9227	2.0567	1.8233
11	1.9662	1.1946			1.989	1.9433	
12	2.0056	1.1765			2.0454		
13	1.8299	1.1584	1.1576		1.9951		2.0119
14	1.7078	1.1403			1.9109	1.7976	
15	1.6762	1.086			1.8299	1.749	
16	1.2136	.905			1.3432	1.086	
17	1.1584	1.0498			1.4118	1.1584	1.1888
18	1.086	1.1584			1.2127	1.1584	
19	.9522	.905	.9335		1.0924	1.1222	
20	.8145	.7783			1.0679	.7964	
21	.8779	.9231			.8316	.7602	
22	.852	.9231			.6767	.724	
23	.8356	.9393			.6516	.6878	
24	.3982	.3125	.9393		.4252	.6401	.6878
Max	2.0056	1.1946	1.1888	1.0227	2.0454	2.0567	2.0119
Min	.3982	.3125	.7964	.8131	.4252	.6154	.5792
Avg	1.2535	.9788	1.0094	.8953	1.3643	1.0815	1.0233

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214416 / 33 KV HIVARE

Feeder No / Name : 202 / HIVRE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8848	.6859	.724			.945	1.1984
2		.7011	.7602			.9686	1.1984
3		.7265	.7964			1.0402	1.1984
4		.7783	.8688			1.1203	1.2308
5		.8869	1.0136	.7537			1.2308
6		1.0317	1.086			1.2483	1.2308
7		.9922	1.2489		1.4918	1.5546	1.3575
8	1.4529	2.0729	2.251	2.1445		1.6651	1.5203
9	1.6289		2.3644	2.1822	1.4842		1.5565
10	1.7878	2.5425	2.6566		1.647	1.8823	1.4118
11	1.9281	2.753			1.8088	1.8823	
12	2.0058	2.8178			1.8642	1.8099	
13	1.97	2.5911	2.8647		1.6834	1.828	1.5604
14	1.9105	2.5101			1.5947	1.828	
15	1.7364	2.5749			1.8461	1.7737	
16	1.7372	1.448			1.7353	1.7737	
17	1.701	1.5746			1.7177	1.7375	1.8099
18	1.4842	1.3756			1.4217	1.7194	
19	1.267	1.086	1.4175		1.3546	1.5565	
20	1.1488	1.0498			1.283	1.1765	
21	.8402	.9231			1.0517	1.2631	
22	.78	.905			.9065	1.2631	
23	.6706	.8688			.9031	1.2631	
24	.9313	.7122	.8326		1.1088	.9297	1.2308
Max	2.0058	2.8178	2.8647	2.1822	1.8642	1.8823	1.8099
Min	.6706	.6859	.724	.7537	.9031	.9297	1.1984
Avg	1.4370	1.4612	1.4527	1.6935	1.4649	1.4650	1.3642

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214416 / 33 KV HIVARE

Feeder No / Name : 203 / BHORWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5				.7377			
6			.7449				
7							.4706
8			1.7166	.5914			
9	1.1203		.2896	.5788	1.1843		1.3279
10			.5175				1.3426
13			.5788				1.4089
17							.5853
19			.6036				
21						.362	
23		.6478				.362	
24	.2172		.6478		.7522		.362
Max	1.1203	.6478	1.7166	.7377	1.1843	.362	1.4089
Min	.2172	.6478	.2896	.5788	.7522	.362	.362
Avg	.6688	.6478	.7284	.6360	.9683	.362	.9162

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214416 / 33 KV HIVARE

Feeder No / Name : 204 / GANPATI DEVSTHAN (Ozar)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5975	.6154			1.0059	1.166
2		.679	.6154			1.0442	1.1336
3		.5975	.6516			1.1142	1.166
4		.5847	.6878			1.1603	1.166
5		.6722	.6878	.5228		1.1934	1.166
6			.6878			1.2071	1.166
7		.6653	.724			.7468	.7602
8	1.0242	1.5074	1.7166	1.6741		.7842	.8688
9	.8215		1.8138	1.8778	1.2483		.8688
10	.8775	1.7814	2.0222		.4481	.9774	.9511
11	.9055	1.9433			.5415	1.0136	
12	.9522	2.0081			.6722	1.0498	
13	.8962	1.9433	2.0119		.7842	1.0498	.8962
14	.8316	1.9109			.8962	1.0136	
15	.7842	1.749			.9709	1.0498	
16	.6535	.724			.6535	1.0498	
17	.5658	.7602			.6348	1.0498	.7392
18	.6535	.7964			.679	1.0498	
19	.7167	.7964	.5975		.7282	.905	
20	.7922	.7964			.811	.8688	
21	.6348	.7602			1.1233	1.2308	
22	.5601	.7602			1.094	1.2308	
23	.5975	.724			1.0898	1.1984	
24	.7087	.5658	.6878		.4207	1.0277	1.1984
Max	1.0242	2.0081	2.0222	1.8778	1.2483	1.2308	1.1984
Min	.5601	.5658	.5975	.5228	.4207	.7468	.7392
Avg	.7633	1.0601	1.0400	1.3582	.7997	1.0444	1.0189

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214416 / 33 KV HIVARE

Feeder No / Name : 205 / 11 kV KURAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8097	.8745			.3361	.2534
2		.7865	.9069			.3584	.2172
3		.8259	.9069			.3734	.2534
4		.8684	.9069			.3772	.2591
5		.9069	.8745	.8383		.3921	.3258
6			.8745			.4108	.3982
7		.6535	.5068		.4854	1.065	.3982
8	1.2452	.6722	.543	.4755		1.1401	1.2955
9	1.326		.6154	.4938	1.2407		1.3603
10	1.3435	.6516	.6099		1.5074	1.4899	1.4255
11	1.3757	.724			1.5546	1.4899	
12		.7964			1.587	1.4899	
13	1.3923	.7602	.6348		1.5402	1.5223	1.4255
14	1.3426	.724			1.4575	1.3927	
15	1.2407	.6516			1.5912	1.3603	
16	.543	.6516			.6468	.543	
17	.5228	.6154			.6722	.543	.5853
18	.4904	.6154			.5601	.5792	
19	.4481	.5792			.5228	.5068	
20	.415	.5792			.4904	.4706	
21	.4481	.5182			.415	.362	
22	.8718	.9069			.3734	.3258	
23	.7907	.9069			.3547	.2896	
24	.2481	.8215	.8745		.2507	.3395	.2896
Max	1.3923	.9069	.9069	.8383	1.5912	1.5223	1.4255
Min	.2481	.5182	.5068	.4755	.2507	.2896	.2172
Avg	.8778	.7284	.7607	.6025	.8971	.7460	.6528

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214454 / 33/11KV YENERE

Feeder No / Name : 201 / Yenere

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3547	.4359	.407	.4239	.3395	.3395	.3395
2	.3395	.4239	.3856	.4024	.3206	.3206	.3206
3	.3961	.4287	.4024	.4191	.3584	.3772	.3547
4	.4294	.4458	.4409	.4578	.3921	.4108	.3961
5	.4668	.4557	.5144	.5316	.4338	.4527	.4338
6	.5847	.567	1.0562	.6201	.547	.5658	.4715
7	.7545	.7356	1.1576	.8215	.6979	.7167	.6979
8	.9015	.7922	.8962	.8775	.9835	1.0802	1.0288
9	.9088	.7392	.9522	.9149	1.0898	1.2239	1.3056
10	1.0343	.8402	.9709	1.0082	1.0442	1.3748	1.2742
11	1.0562	.9149	.8215	.9055	1.2378	1.4083	1.2742
12	.9339	.8589	.8775	.961	1.2597	1.4754	1.2125
13	.9665	.7655	1.0082	.8871	1.2431	1.4255	1.278
14	.9339	.7655	.9709	.8686	1.1797	1.3592	1.1603
15	.7712	.7655	.8775	.8501	1.1233	1.2929	1.1271
16	.6283	.8131	.7947	.8686	.8029	.9149	.9896
17	.6283	.8215		.8871	.9896	.8589	.8402
18	.567	.7133	.7947	.8501	.8775	.7655	.8962
19	.6413	.7095	.7655	.7468	.7468	.7095	.8402
20	.7167	.7095	.7282	.7282	.7282	.6722	.7095
21	.6485	.5959	.5493	.6224	.6413	.5847	.6224
22	.5721	.5201	.5434	.4527	.4715	.4338	.4715
23	.4409	.4578	.4458	.3547	.3734	.3961	.3547
24	.3547	.4359	.4409	.4409	.3361	.3361	.3772
Max	1.0562	.9149	1.1576	1.0082	1.2597	1.4754	1.3056
Min	.3395	.4239	.3856	.3547	.3206	.3206	.3206
Avg	.6679	.6546	.7305	.7042	.7591	.8123	.7823

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214454 / 33/11KV YENERE

Feeder No / Name : 202 / Tambe

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3565	.5601	.5544	.5914	1.1736	1.2071	1.3565
2	1.3889	.5601	.5304	.567	1.1831	1.2174	1.3226
3	1.3245	.5975	.567	.5853	1.166	1.2003	1.2346
4	1.2407	.7095	.6908	.7282	1.1869	1.17	1.1831
5	1.2039	.8215	.8488	.9054	1.2039	1.2039	1.1065
6	1.3696	1.0456		1.1576	1.3523	1.3523	1.3717
7	1.2696	1.2323		1.363	1.1763	1.1949	1.2323
8	1.2382	2.5095	2.1195	2.1628	1.2197	1.363	1.2136
9	1.2567	2.2874	2.8166	1.9784	1.1827	1.2382	1.1016
10	1.1827	2.6155	2.6155	2.5484	1.2012	1.1827	1.1088
11	1.0719	2.696	2.7328	2.5819	1.2323	1.1458	1.0349
12		2.5819	2.2721	2.4981	1.2012	1.0425	1.1523
13	.9955	2.6852	2.5857	2.4249	1.2254	1.1088	1.1411
14	.9412	2.649	2.536	2.3703	1.0425	1.0534	1.1088
15	.9412	2.364	2.1956	2.2377	1.1203	1.0608	1.0791
16	1.0317		.9313	1.0498	1.2012	1.1576	1.1765
17	1.0425	1.0269	.9877	1.1584	1.1523	1.0903	1.1706
18	.905	1.0679	1.0059	1.1946	1.2567	1.0059	1.086
19	1.0642	1.1088	1.1203	1.1706	1.2136	1.1016	1.307
20	1.1088	.961	1.2012	1.0349	1.0349	1.1016	1.2323
21	1.0642	1.0082	1.0829	1.6632	1.6804	1.4413	1.6118
22	.8215	.7842	.8962	1.6278	1.6448	1.5424	1.7635
23	.6535	.6653	.7023	1.3245	1.3413	1.326	1.5249
24	1.358	.5975	.6283	.6283	1.2071	1.2407	1.3748
Max	1.3889	2.696	2.8166	2.5819	1.6804	1.5424	1.7635
Min	.6535	.5601	.5304	.567	1.0349	1.0059	1.0349
Avg	1.1231	1.4406	1.4373	1.4814	1.2333	1.1979	1.2498

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214454 / 33/11KV YENERE

Feeder No / Name : 203 / BORGHAR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.128	.124	.1417	.1494	.1494	.1478
2	.112	.1086	.1063	.124	.132	.1254	.112
3	.0943	.1086	.124	.124	.1478	.1478	.1109
4	.1307	.1294	.1448	.1448	.1448	.1448	.1294
5	.1463	.168	.1646	.1867	.1433	.1433	.1646
6	.2054	.2241	.1867	.2218	.1867	.1867	.1848
7	.2801	.2801	.2715	.2957	.2987	.2801	.2614
8	.2587	.2801	.2957	.2614	.3292	.2957	.2804
9	.2172	.2195	.2587	.2534	.2686	.2561	.1612
10	.2279	.1612	.2507	.2686	.2507	.1991	.2172
11	.2254	.1612	.2481	.2279	.2481	.2126	.1612
12	.1492	.1949	.2328	.2279	.2804	.1823	.128
13	.1423	.1886	.0423	.1677	.2743	.1526	.1219
14	.1581	.2103	.156	.1543	.218	.1715	.1134
15	.1781	.1928	.1823	.1357	.298	.1907	.1326
16	.1989	.1989	.2347	.16	.2481	.1928	.112
17	.1886	.1734	.2713	.1638	.2572	.1928	.1658
18	.1086	.208	.2947	.208	.2926	.1715	.2204
19	.2218	.2957	.2926	.2896	.3109	.2427	.2534
20	.2614	.2957	.2926	.3109	.3109	.2587	.3142
21	.2641	.2614	.2772	.2587	.2772	.2402	.218
22	.2054	.2218	.2587	.2218	.2218	.2033	.2054
23	.1867	.1991	.2195	.1848	.1848	.1646	.1663
24	.1478	.1463	.1433	.1612	.1646	.1646	.1307
Max	.2801	.2957	.2957	.3109	.3292	.2957	.3142
Min	.0943	.1086	.0423	.124	.132	.1254	.1109
Avg	.1850	.1982	.2114	.2039	.2349	.1946	.1755

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214407 / 33/11KV NIRGUDSAR

Feeder No / Name : 200 / AUXILARY FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0377	.0602	.0594	.0594	.0579	.0655
2		.0377	.0452	.0594	.0594	.0579	.0572
3		.0189	.0452	.0594	.0594	.0579	.061
4		.0189	.0452	.0594	.0572	.0594	.0488
5		.0189	.0446	.0594	.0572	.0594	.0594
6		.0377	.0301	.0446	.0572	.0434	.064
7		.0189	.0297	.0452	.0141	.0145	.029
8		.0143	.017			.0143	.0328
9		.0171	.0164	.017	.0152	.0149	.0297
10		.017	.017	.0171	.0164	.0145	.0151
11		.0171	.0171	.0171	.0166	.0149	.0152
12		.0171	.0187	.0171	.0166	.0149	.0149
13	.0191	.0168	.0183	.0171	.0373	.0181	.0156
14	.0189	.0162	.0171	.0171	.017	.0181	.016
15	.0362	.0179	.0171	.0171	.0171	.0173	.0156
16	.0189	.0183	.0171	.0181	.0171	.0171	.0164
17	.0189	.0362	.0162	.0181	.0171	.0171	.0156
18	.0189	.064	.0143	.0183	.017	.0171	.0156
19	.0377	.0648	.0572	.0732	.0587	.0164	.0579
20	.0377	.081	.0648	.0648	.0564	.017	.0579
21	.0377	.061	.0594	.0594	.0572	.0686	.0579
22	.0377	.0602	.0594	.0579	.0572	.0686	.0579
23	.0377	.0579	.0594	.0579	.0579	.0701	.064
24		.0377	.0602	.0594	.0594	.0579	.0716
Max	.0377	.081	.0648	.0732	.0594	.0701	.0716
Min	.0189	.0143	.0143	.017	.0141	.0143	.0149
Avg	.0290	.0335	.0353	.0406	.0390	.0345	.0398

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214407 / 33/11KV NIRGUDSAR

Feeder No / Name : 201 / 11KV PARGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4161	.2818	.2984	.2622	.8288	.9282	.9835
2	.4161	.2818	.2949	.2652	.8288	.9503	.9665
3	.3814	.3149	.3277	.2984	.8718	.9503	.9665
4	.3467	.3978	.426	.3978	.8951	.9831	1.0004
5	.4854	.4424	.5243	.4641	.9282	1.0486	1.0682
6	.6588	.5735	.6554	.5571	.9614	1.1142	1.1361
7	.763	.7701	.7373	.639	.6299	.6554	.7461
8	.6783	1.8313	1.8313	1.7974	.7122	.7625	.78
9	.6104	1.9161	1.9839	1.933	.5935	.7293	.5967
10	.6299	2.0008	2.0178	1.933	.5765	.6962	.5967
11	.4641	1.95	1.95	1.933	.4748	.6299	.5636
12	.4409	1.6956	1.861	1.5091	.5426	.6299	.5304
13	.4578	1.6956	1.95	1.4243	.4917	.5967	.5304
14	.4917	1.6278	1.8313	1.5939	.431	.5636	.5304
15	.5426	1.6278	1.7295	1.4922	.407	.5636	.5967
16	.4748	.5935	.407	.5256	.4409	.5636	.6464
17	.4641	.5304	.4973	.5636		.5596	.5636
18	.4641	.5304	.5304	.5801	.5967	.5426	.5365
19	.5304	.5636	.5304	.3467	.5967	.6104	.6299
20	.5636	.6299	.5304	.3641	.5636	.5256	.5636
21	.4641	.4807	.503	.3467	1.1934	1.1869	1.1603
22	.3647	.3812	.4191	.4854	1.1271	1.153	1.0774
23	.2915	.3113	.2949	.4161	.9945	1.0343	1.0277
24	.3814	.2818	.2984	.2652	.8192	.9282	.9614
Max	.763	2.0008	2.0178	1.933	1.1934	1.1869	1.1603
Min	.2915	.2818	.2949	.2622	.407	.5256	.5304
Avg	.4909	.9046	.9346	.8497	.7176	.7878	.7816

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214407 / 33/11KV NIRGUDSAR

Feeder No / Name : 202 / 11KV NIRGUDSAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18
HR	Load (MW)	Load (MW)
1	.2075	.9717
2	.2075	.9717
3	.2263	1.0159
4	.3018	1.065
5	.3772	1.0978
6	.3961	1.1336
7	.415	.4715
8	1.7695	.4904
9	1.8564	.4904
10	1.9281	.4527
11	2.0222	.4294
12	1.8515	.4024
13	1.6164	
14	1.7284	.2263
15	.2033	.2641
16	.2614	.2075
17	.2801	.3772
18	.3174	.3395
19	.3961	.2829
20	.3772	.3395
21	1.1469	.823
22	1.0774	.8288
23	.9995	.7701
24	.2075	.9717
Max	2.0222	1.1336
Min	.2033	.2075
Avg	.8404	.6271

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214407 / 33/11KV NIRGUDSAR

Feeder No / Name : 203 / 11KV JAWALE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1012	.213	.1802	.1989	1.2289	1.1797	1.1012
2	1.1012	.213	.1802	.1966	1.2289	1.1797	1.085
3	1.1336	.2486	.213	.2622	1.278	1.2125	1.085
4	1.166	.2984	.2949	.5243	1.3108	1.278	1.1174
5	1.2146	.3277	.426	.3647	1.3435	1.3108	1.1984
6	1.2793	.426	.4588	.4144	1.3927	1.3763	1.2793
7	.6316	.5506	.4915	.4641	.5898	.663	.6316
8	.6478	1.8138	2.0567	2.0405	.6154	.7537	.6316
9	.6478	2.0567	2.2024	2.0405	.5668	.7209	.6554
10	.6718	2.2672	2.2348	2.2024	.7125	.6882	.6226
11	.6226	2.2024	2.2672	2.2348	.6154	.6882	.5571
12	.6316	2.2024	2.0081	2.1052	.6964	.6882	.5571
13	.6154	2.1052	2.1862	2.17	.6802	.6554	.5571
14	.6316	2.0081	2.0405	2.2024	.7125	.6882	.5571
15	.6478	2.0243	2.2186	2.0891	.7611	.7209	.6226
16	.6478	.4696	.4534	.5992	.6964	.2622	.6133
17	.6226	.4915	.4915	.6226	.7209	.7125	.6706
18	.6226	.4588	.4915	.6554	.6554	.6964	.6539
19	.5243	.3932	.426	.6554	.5571	.5992	.5967
20	.4915	.4588	.3932	.4915	.5243	.502	.5533
21	.3932	.3277	.3315	1.3108	1.3108	1.247	1.2929
22	.2949	.2622	.2984	1.3108	1.2597	1.2308	1.326
23	.2294	.2012	.213	1.2742	1.2266	1.1984	1.2266
24	1.1012	.213	.1802	.1989	1.2431	1.1934	1.1012
Max	1.2793	2.2672	2.2672	2.2348	1.3927	1.3763	1.326
Min	.2294	.2012	.1802	.1966	.5243	.2622	.5533
Avg	.7363	.9264	.9474	1.1095	.9136	.8936	.8455

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214407 / 33/11KV NIRGUDSAR

Feeder No / Name : 204 / 11KV MENGADWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18
HR	Load (MW)	Load (MW)
1	.3018	.3932
2	.3018	.3932
3	.3395	.426
4	.415	.4534
5	.6413	.5898
6		.7125
7	.9054	1.0669
8	1.3763	1.1317
9	1.5729	1.2449
10	1.5581	1.094
11	1.3763	.9979
12	1.3283	.9145
13	1.0669	
14	1.262	.7922
15	.6805	.9054
16	.8048	.6036
17	.8131	.9431
18	.8871	.8962
19	.9054	.9431
20	.8676	.8676
21	.7377	.7888
22	.5636	.7293
23	.4641	.5967
24	.3018	.3932
Max	1.5729	1.2449
Min	.3018	.3932
Avg	.8466	.7773

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214407 / 33/11KV NIRGUDSAR

Feeder No / Name : 205 / 11KV JARKARWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18
HR	Load (MW)	Load (MW)
1	.4481	.3018
2	.4481	.3018
3	.4801	.3772
4	.5506	.4572
5	.6154	.5281
6	.6478	.7545
7	.8299	1.0185
8	1.0349	1.5729
9	.9979	1.3279
10	.8779	1.9433
11	.8413	1.7604
12	.788	1.6324
13	.7888	
14	.8238	1.3603
15	.8939	1.4575
16	.9214	.4715
17	.8859	.8676
18	.7682	.8676
19	.8589	.8676
20	.7095	.9054
21	.6036	.5658
22	.415	.3734
23	.3395	.2987
24	.4481	.3018
Max	1.0349	1.9433
Min	.3395	.2987
Avg	.7090	.8832

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214407 / 33/11KV NIRGUDSAR

Feeder No / Name : 206 / 11KV BHARADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2012	.6554	.6882	.8288	.2458	.2155	.218
2	.2012	.6554	.6882	.8192	.2458	.2155	.218
3	.2347	.6882	.7209	.8619	.2949	.2486	.2347
4	.3018	.7209	.7865	.8848	.3277	.2949	.3018
5	.3521	.7956	.8192	.9175	.4024	.3605	.4024
6	.4359	.8192	.8848	.9503	.4641	.426	.4862
7	.4862	.4915	.3768	.4915	.4973	.4588	.503
8	1.3413	.503	.5365	.5868	1.5592	1.4419	1.576
9	1.5257	.4862	.503	.503	1.9281	1.6766	1.5927
10	1.5424	.4191	.5197	.4694	1.5424	1.6766	1.6095
11	1.3077	.4359	.4359	.4359	1.6766	1.7101	1.576
12	1.4922	.4359	.4694	.4527	1.7604	1.7101	1.6095
13	1.3245	.4024	.4527	.4359	1.7101	1.6766	1.576
14	1.4251		.4862	.4359	1.9448	1.6095	1.5089
15	.3688	.3688	.3521	.503	1.5424	1.4419	1.5089
16	.4191	.4527	.3856	.4024	.4191	.4024	.3932
17	.3688	.4359	.4694	.503	.4359	.4024	.4588
18	.4359	.4694	.4694	.503	.503	.4694	.4588
19	.4359	.5365	.5365	.503	.503	.4359	.4973
20	.4359	.57	.4694	.4191	.4694	.4359	.431
21	.8048	.8048	.8848	.4191	.4024	.3521	.3647
22	.8383	.8383	.9175	.3353	.3113	.285	.2984
23	.7293	.7537	.852	.2622	.2458	.2347	.2486
24	.2012	.663	.6882	.8192	.2458	.213	.218
Max	1.5424	.8383	.9175	.9503	1.9448	1.7101	1.6095
Min	.2012	.3688	.3521	.2622	.2458	.213	.218
Avg	.7171	.5827	.5997	.5726	.8199	.7664	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214407 / 33/11KV NIRGUDSAR

Feeder No / Name : 207 / 11KV SUYOG INDUSTRIAL
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2452	.2587	.2054	.1848	.0934	.1867	.0934
2	.2452	.2614	.2054	.1848	.0924	.1886	.0934
3	.2263	.2427	.2263	.168	.0739	.1698	.132
4	.1867	.2263	.1867	.168	.0739	.1494	.132
5	.112	.1886	.1494	.1478	.0171	.1494	.1509
6	.0934	.1698	.1109	.1478	.016	.112	.1698
7	.0229	.1097	.0934	.0895	.0084	.1132	.1886
8	.0381	.0671	.0324	.0486	.0486	.124	.0503
9	.1097	.0202	.1509	.0324		.1698	.0248
10	.1109	.0168	.0934	.0213	.1698	.112	.0114
11	.2614	.1509	.1886	.0566	.132	.1509	.2075
12	.1698	.1307	.116	.0566	.2075	.056	.2075
13	.0732	.1867	.0943	.0566	.0754	.0914	.168
14	.0566	.056	.0566	.0566	.0754	.1494	.056
15	.1848	.1848	.2452	.0754	.2263	.2033	.1463
16	.1867	.0282	.1698	.0754	.2402	.1867	.2561
17	.1886	.1143	.1886	.0383	.2075	.1509	.2033
18	.1334	.1109	.1097	.0259	.1132	.2075	.112
19	.1886	.0924	.1294	.0171	.104	.052	.1132
20	.1524	.0493	.132	.0549	.0953	.0234	.029
21	.2096	.1905	.1509	.0452	.1715	.1509	.0343
22	.132	.1334	.1509	.0486	.1698	.132	.1886
23	.2614	.2054	.2427	.0754	.2772	.0924	.2075
24	.2641	.2772	.2054	.1848	.0934	.1867	.0914
Max	.2641	.2772	.2452	.1848	.2772	.2075	.2561
Min	.0229	.0168	.0324	.0171	.0084	.0234	.0114
Avg	.1605	.1447	.1514	.0859	.1210	.1379	.1278

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214413 / 33/11KV MANCHAR

Feeder No / Name : 200 / AUXILARY FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0191	.0191	.0191	.0191
2	.0191	.0191	.0191	.0191	.0191	.0191	.0191
3	.0191	.0191	.0191	.0191	.0191	.0191	.0191
4	.0191	.0191	.0191	.0191	.0191	.0191	.0191
5	.0191	.0191	.0191	.0191	.0191	.0191	.0191
6	.0191	.0191	.0191	.0191	.0191	.0191	.0191
7	.0191	.0191	.0191	.0191	.0191	.0191	.0191
8	.0191	.0191	.0191	.0191	.0191	.0191	.0191
9	.0191	.0191	.0191	.0191	.0191	.0191	.0191
10	.0191	.0191	.0191	.0191	.0191	.0191	.0191
11	.0191		.0191	.0191	.0191	.0191	.0191
12	.0191	.0191	.0191	.0191	.0191	.0191	.0191
13	.0191	.0191	.0191	.0191	.0191	.0191	.0191
14	.0191	.0191	.0191	.0191	.0191	.0191	.0191
15	.0191	.0191	.0191	.0191	.0191	.0191	.0191
16	.0191		.0191	.0191	.0191	.0191	.0191
17	.0191	.0191	.0191	.0191	.0191	.0191	.0191
18	.0191	.0191	.0191	.0191	.0191	.0191	.0191
19	.0191	.0191	.0191	.0191	.0381	.0191	.0381
20	.0191	.0191	.0191	.0191	.0381	.0191	.0381
21	.0191	.0191		.0191	.0381	.0191	.0381
22	.0191	.0191	.0191	.0191	.0381	.0191	.0381
23	.0191	.0191	.0191	.0191	.0191	.0191	.0191
24	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Max	.0191	.0191	.0191	.0191	.0381	.0191	.0381
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.0191	.0191	.0191	.0223	.0191	.0223

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214413 / 33/11KV MANCHAR

Feeder No / Name : 201 / 11 KV PIMPALGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2346	.1715	.1905	.1543	1.4575	1.2308	1.4918
2	1.2003	.1715	.1905	.1543	1.3765	1.2146	1.4575
3	1.2003	.1905	.1905	.1543	1.3765	1.2146	1.4575
4	1.2346	.2286	.2286	.2229	1.4737	1.2955	1.5261
5	1.286	.2667	.2858	.2572	1.5546	1.3927	1.5775
6	1.2193	.3086	.3429	.3086	1.6518	1.5223	1.6461
7	.3429	.4115	.3772	.4287	.3772	.3944	.3772
8	.3258	2.5911	2.7435	2.9492	.3601	.3429	.3772
9	.2743	2.6216	1.0059	3.0178	.2743	.3429	.2743
10	.2058	.1029	1.1431	2.8349	.2229	.2286	.2743
11	.1886		3.0178	3.0483	.2058	.2286	.1886
12	.1372	2.9264	3.094	2.8197	.1543	.2096	.1715
13	.0514	2.8502	3.0178	2.6978	.1372	.1715	.2058
14	.0514	2.7435	2.9874	2.5911	.1543	.1905	.1543
15	.1543	2.8807	2.7435	2.6673	.1543	.1905	.12
16	.1543		.1543	.1715	.1543	.2096	.1543
17	.1715		.2058	.1543	.1905	.1543	.2286
18	.1715	.2058	.2058	.1715	.2286	.1543	.2286
19	.2743	.2743	.3086	.3086	.3239	.2743	.3429
20	.2743	.2915	.3772	.3258	.3048	.2743	.3429
21	.2743	.3086	.2743	1.6461	1.448	1.7318	1.3717
22	.2229	.2229	.2229	1.9204	1.5546	1.9376	1.4937
23	.1905	.1905	.1886	1.668	1.5089	1.6356	1.4899
24	1.2346	.1715	.1715	.1715	1.5223	1.2793	1.5432
Max	1.286	2.9264	3.094	3.0483	1.6518	1.9376	1.6461
Min	.0514	.1029	.1543	.1543	.1372	.1543	.12
Avg	.5031	.9586	.9862	1.2852	.7570	.7425	.7706

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214413 / 33/11KV MANCHAR

Feeder No / Name : 202 / 11KV AVSARI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.4287	.5144	.4858	.1029	.1372	.12
2	.1905	.4287	.5144	.4858	.1029	.1029	.1029
3	.1905	.4287	.5144	.4858	.1029	.1029	.1029
4	.1905	.463	.5144	.5182	.1372	.1715	.1715
5	.2229	.5144	.5487	.583	.2058	.2058	.2401
6	.2915	.7202	.6706	.6478	.3258	.2401	.2915
7	.3239	.4115	.3772	.3601	.463	.3429	.3429
8	1.2193	.3772	.3258	.3429	1.6194	1.4575	1.3603
9	1.4937	.2401	.2572	.2572	1.9376	1.6461	1.5775
10	1.4022	.1715	.2229	.1715	1.5394	1.3717	1.5775
11	1.2955		.1715	.1543	1.2193	1.3717	1.2651
12	.9145	.1715	.1715	.1372	1.5546	1.2498	1.286
13	.9145	.1543	.1029	.1372	1.3717	1.2803	1.166
14	1.2193	.1543	.12	.12	1.3108	1.3375	1.166
15	1.0669	.12	.12	.1029	1.2689	1.166	1.0288
16	.12		.12	.1029	.1372	.1334	.1029
17	.12		.12	.1372	.1524	.12	.1143
18	.1372	.2058	.2058	.1372	.1372	.1372	.1905
19	.2572	.2743	.2401	.2401	.2286	.2229	.2667
20	.2572	.2572	.2572	.2743	.2667	.2401	.0572
21	.6516	.8402	.7716	.2572	.2477	.2572	.2858
22	.7888	.9945	.884	.2058	.2096	.1886	.2286
23	.6687	.8573	.7125	.1543	.1715	.1543	.1715
24	.1905	.5144	.6344	.5506	.1372	.1372	.1372
Max	1.4937	.9945	.884	.6478	1.9376	1.6461	1.5775
Min	.12	.12	.1029	.1029	.1029	.1029	.0572
Avg	.5966	.4156	.3788	.2937	.6229	.5740	.5564

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214413 / 33/11KV MANCHAR

Feeder No / Name : 203 / 11 KV MANCHAR

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.6859	.7545	.7545	.7716	.8573	.8059
2	.8573	.6859	.7545	.7545	.7716	.8745	.7716
3	.8573	.7545	.7888	.7888	.823	.8745	.7716
4	.8573	.8573	.8916	.9259	.9602	.9945	.8573
5	.8916	.9602	.9602	1.046	1.0974	1.1145	1.0974
6	1.2517	1.3032	1.406	1.2003	1.3375	1.3032	1.3032
7	2.0576	1.989	1.9204	1.6804	2.1434	1.7833	2.1262
8	2.4006	2.6406	2.4006	2.452	2.3491	2.4691	2.5377
9	2.2291	2.1434	2.0576	2.0576	2.2977	2.4006	1.9376
10	1.9204	2.0576	1.7147	1.8519	1.8176	1.8861	1.9376
11	1.7147		1.6804	1.6804	1.6461	1.749	1.6632
12	1.6118	1.5432	1.3717	1.4575	1.5432	1.6118	1.5947
13	1.406	1.3375	1.3717	1.3032	1.3717	1.406	1.4746
14	1.3717	1.2003		1.3032	1.406	1.3717	1.4746
15	1.3032	1.2003	1.406	1.2003	1.5089	1.3375	1.4403
16	1.3375		1.4575	1.5432	1.5604	1.5089	1.406
17	1.5432	1.749	1.7147	1.6461	1.4746	1.5775	1.6118
18	1.6118	1.5432	1.749	1.6118	1.5432	1.5775	1.3717
19	1.9204	2.0062	1.989	1.8519	1.7147	1.9033	1.7833
20	1.7318	1.8004	1.7661	1.7833	1.6461	1.7147	1.8176
21	1.5947	1.6461	1.6289	1.5432	1.3717	1.5432	1.6461
22	1.3717	1.4403	1.3717	1.3375	1.3717	1.2689	1.4575
23	.9602	.9602	.9945	1.0288	1.0288	1.0288	1.2346
24	.8916	.7545	.7545	.7545	.8059	.8745	.8402
Max	2.4006	2.6406	2.4006	2.452	2.3491	2.4691	2.5377
Min	.8573	.6859	.7545	.7545	.7716	.8573	.7716
Avg	1.4396	1.4209	1.4306	1.3982	1.4318	1.4596	1.4568

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214413 / 33/11KV MANCHAR

Feeder No / Name : 206 / 11kv Tawarewadi

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3086	.2401	.3086	.3086	.3086	.2915
2	.3086	.3086	.2401	.3086	.3086	.3086	.2743
3	.3429	.3429	.2743	.3086	.3258	.3086	.2572
4	.3429	.3772	.3086	.3601	.3772	.3772	.3429
5	.3772	.4115	.3429	.463	.463	.4801	.4458
6	.6173	.6173	.583	.6687	.6001	.6344	.6344
7	.7888	.823	.7202	.7888	.7202	.703	.8402
8	.8573	.8916	.8059	.9088	.823	.7716	.8916
9	.6859	.7202	.7716	.7202	.7202	.6859	.4801
10	.6001	.6001	.6001	.6516	.5487	.5487	.4801
11	.5144		.5144	.5144	.4458	.4801	.4801
12	.5487	.4458	.6173	.4458	.3772	.4458	.4801
13	.3772	.4801	.4801	.4287	.4115	.5144	.5144
14	.4115	.3772	.4287	.4287	.3429	.4287	.4801
15	.3772	.4287	.3772	.4801	.4458	.4458	.4458
16	.4287		.4458	.4115	.5144	.5144	.4458
17	.4115	.4801	.4458	.5144	.463	.4801	.5658
18	.4458	.5487	.5144	.4973	.5487	.5144	.5487
19	.5144	.7545	.7545	.583	.7202	.7202	.6859
20	.6173	.583	.6859	.583	.6859	.6516	.6859
21	.583	.4115	.5487	.6173	.583	.583	.6001
22	.4115	.3772	.4458	.3772	.463	.4801	.4801
23	.3429	.3086	.3601	.3772	.3772	.3601	.4287
24	.3086	.3086	.3086	.3429	.3429	.3429	.3258
Max	.8573	.8916	.8059	.9088	.823	.7716	.8916
Min	.3086	.3086	.2401	.3086	.3086	.3086	.2572
Avg	.4801	.4957	.4923	.5037	.4965	.5037	.5044

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214413 / 33/11KV MANCHAR

Feeder No / Name : 207 / 11 kv chandoli gfss

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2572	.2401	.2401	.2058	.2572	.2401
2	.2058	.3086	.2058	.2058	.1886	.2229	.2229
3	.2058	.2572	.2058	.2058	.1715	.2058	.2229
4	.2058	.2743	.2229	.2743	.2401	.2915	.3258
5	.2401	.3086	.2572	.3601	.3429	.3601	.3772
6	.4287	.4801	.4115	.4973	.4458	.4287	.4115
7	.583	.583	.583	.5658	.5658	.5487	.583
8	.583	.583	.5487	.5144	.5658	.5658	.6173
9	.4801	.6173	.4801	.5144	.4801	.4801	.3772
10	.3772	.4458	.3772	.4287	.4115	.4458	.3772
11	.3429		.3086	.3772	.3429	.463	.2743
12	.3086	.3086	.2743	.3086	.3429	.2743	.2743
13	.1372	.2743	.2058	.2572	.2401	.2572	.2401
14	.2058	.2058	.2058	.2743	.2401	.2401	.2743
15	.2058	.1715	.2743	.3086	.2401	.2572	.2401
16	.2743		.2743	.2401	.2401	.2743	.2401
17	.2743		.2401	.2058	.2058	.2401	.2572
18	.2743	.3086	.2743	.2401	.2401	.2743	.2915
19	.4458	.4801	.4458	.4458	.3772	.3772	.4458
20	.4801	.4801	.4801	.4115	.4458	.3772	.4801
21	.4458	.4458	.4801	.4115	.4115	.3772	.3772
22	.3429	.3429	.3429	.3086	.3086	.3086	.3429
23	.3086	.3429	.2915	.2743	.2743	.2743	.3086
24	.2572	.2915	.2915	.2572	.2229	.2572	.2572
Max	.583	.6173	.583	.5658	.5658	.5658	.6173
Min	.1372	.1715	.2058	.2058	.1715	.2058	.2229
Avg	.3265	.3699	.3301	.3386	.3229	.3358	.3358

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214413 / 33/11KV MANCHAR

Feeder No / Name : 208 / 11 kv Mordewadi gfss

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.5144		.5144	.5316	.4801	.4801
2	.4801	.5144	.5144	.5144	.5144	.4801	.4458
3	.4801	.4801	.5487	.5144	.5144	.4458	.4287
4	.4801	.5144	.5487	.6001	.5487	.5144	.5144
5	.5144	.5487	.583	.6687	.6173	.6344	.6173
6	.6859	.7545	.7716	.7373	.6687	.7888	.7716
7	1.0631	1.0631	1.0288	.9259	1.0802	.9945	.9945
8	1.2346	1.0631	1.166	1.2003	1.2003	1.1831	.7888
9	1.0974	1.1317	1.2346	1.2003	1.2003	1.1145	1.0974
10	1.2003	1.166	1.166	1.2346	1.2346	1.1317	1.0974
11	1.2346		1.0974	1.2003	1.0974	1.1317	.8916
12	1.166	1.0288	1.1317	1.0631	1.0631	.9602	.9945
13	.8573	.9945	1.0288	.8916	1.0631	.7888	.9602
14	.6859	.8573	.823	.7202	.823	.6859	.6516
15	.7888	.8573	.7888	.6859	.7545	.7888	.8573
16	.9945		.8916	.823	1.0288	.9431	.9602
17	.9602	1.0631	1.0631	.9602	.9259	.9602	.9945
18	1.0631	.9945	1.0631	.8916	.9602	.9602	.9431
19	.9602	.8916	.9602	.9259	.9259	.8573	.9431
20	.8916	.8573	.9259	.8916	.8573	.7888	.8573
21	.823	.7545	.823	.7888	.7888	.7888	.7716
22	.6859		.6859	.7202	.7202	.7202	.7202
23	.6173		.6173	.6516	.6344	.5658	.6173
24	.5144	.5144		.5316	.5658	.4973	.4973
Max	1.2346	1.166	1.2346	1.2346	1.2346	1.1831	1.0974
Min	.4801	.4801	.5144	.5144	.5144	.4458	.4287
Avg	.8316	.8282	.8846	.8273	.8466	.8002	.7873

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214413 / 33/11KV MANCHAR

Feeder No / Name : 211 / 11 KV Gov Polytechnic
Express Feeder KV- 11 /
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0762	.0686	.0686	.0686	.0686
2	.0762	.0762	.0762	.0686	.0762	.0686	.0686
3	.0762	.0762	.0762	.0762	.0762	.0686	.0686
4	.0762	.0762	.0762	.0762	.0762	.0686	.0514
5	.0762	.0762	.0762	.0762	.0762	.0686	.0514
6	.0762	.0762	.0762	.0762	.0762	.0686	.0514
7	.0762	.0762	.0762	.0572	.0572	.0514	.0514
8	.0762	.0762	.0762	.0762	.0572	.0514	.0686
9	.0762	.0762	.0762	.0572	.0572	.0762	.0686
10	.0762	.0762	.0762	.0762	.0762	.0762	.0762
11	.0762		.0762	.0572	.0762	.0572	.0762
12	.0762	.0762	.0762	.0572	.0686	.0572	.0686
13	.0762	.0762	.0762	.0572	.0762	.0572	.0686
14	.0762	.0191	.0762	.0572	.0514	.0572	.0686
15	.0762	.0953	.0762	.0572	.0762	.0572	.0686
16	.0762		.0762	.0572	.0686	.0572	.0762
17	.0762	.0762	.0572	.0572	.0762	.0572	.0762
18	.0762	.0762	.0572	.0572	.0572	.0572	.0762
19	.0762	.0762	.0762	.0762	.0762	.0762	.0762
20	.0762	.0762	.0762	.0762	.0762	.0572	.0762
21	.0762	.0762	.0762	.0762	.0762	.0514	.0762
22	.0762	.0762	.0762	.0762	.0762	.0572	.0762
23	.0762	.0762	.0762	.0762	.0686	.0686	.0686
24	.0762	.0762	.0762	.0686	.0686	.0686	.0686
Max	.0762	.0953	.0762	.0762	.0762	.0762	.0762
Min	.0762	.0191	.0572	.0572	.0514	.0514	.0514
Avg	.0762	.0745	.0746	.0673	.0704	.0627	.0686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214413 / 33/11KV MANCHAR

Feeder No / Name : 212 / 11kV Chimbalkar stone
crusher Feeder KV- 11 /
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.0762	.0762	.0686	.0686	.0686	.0686
2	.0762	.0762	.0191	.0686	.0686	.0686	.0686
3	.0762	.0762	.0762	.0686	.0686	.0686	.0686
4	.0762	.0762	.0762	.0686	.0686	.0686	.0686
5	.0762	.0762	.0762	.0686	.0686	.0686	.0686
6	.1543	.0762	.1886	.0686	.0686	.0686	.1886
7	.1372	.2058	.2572	.0686	.0686	.0686	.2229
8	.0857	.12	.1886	.0686	.0686	.3258	.2229
9	.2743	.0857	.1372	.0686	.0514	.2229	.2572
10	.2743	.0686	.3258	.0686	.1372	.2058	.2572
11	.2915		.2915	.0686	.2058	.2743	.2401
12	.12	.2058	.2743	.0686	.2058	.2229	.1886
13	.2401	.0572	.2058	.0686	.1886	.3086	.1372
14	.2058	.0381	.12	.0686	.0686	.2058	.1372
15	.2915	.2058	.0857	.0686	.1029	.2058	.2058
16	.2401		.12	.0686	.1715	.3086	.0857
17	.1029	.1886	.1029	.0686	.1886	.2477	.2229
18	.2572	.2915	.1029	.0686	.1886	.2572	.2572
19	.2915	.2915	.12	.0686	.2229	.2229	.2401
20	.12	.2058	.0762	.0686	.0762	.1372	.1886
21	.1372	.1029	.0762	.0686	.0762	.1029	.0762
22	.1372	.0572	.0762	.0686	.0762	.1029	.0762
23	.12	.1029	.0762	.0686	.0686	.1029	.0686
24	.1029	.12	.1029	.0686	.0686	.0686	.12
Max	.2915	.2915	.3258	.0686	.2229	.3258	.2572
Min	.0762	.0381	.0191	.0686	.0514	.0686	.0686
Avg	.1663	.1275	.1355	.0686	.1103	.1668	.1557

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214413 / 33/11KV MANCHAR

Feeder No / Name : 213 / 11 KV TAPNESHWAR
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.0381	.0572	.0343	.1619	.1943	.2591
2	.1715	.0381	.0572	.0343	.1619	.1619	.2429
3	.1715	.0381	.0572	.0343	.1457	.1619	.2429
4	.2058	.0572	.0572	.0514	.1943	.1619	.2591
5	.2401	.0572	.0514	.0514	.2267	.1943	.2753
6	.2743	.0686	.0762	.0686	.2591	.2267	.2753
7	.0572	.0686	.0857	.0857	.0686	.0686	.0686
8	.0762	.6859	.5639	.3887	.0686	.0686	.0686
9	.0343	.7011	.6554	.7164	.0514	.0572	.0343
10	.0343		.5944	.7164	.0514	.0572	.0343
11	.0343		.5639	.7316	.0171	.0381	.0343
12	.0171	.6554	.5639	.6249	.0191	.0381	.0343
13	.0171	.5639	.5639	.6249	.0191	.0381	.0343
14	.0171	.3048		.5792	.0191	.0381	.0171
15	.1543	.4572	.4877	.3963	.0171	.0381	.0171
16	.0171		.0343	.0191	.0191	.0381	.0171
17	.0171	.0191	.0343	.0191	.0381	.0191	.0381
18	.0191	.0343	.0343	.0191	.0381	.0191	.0381
19	.0171	.0343	.0514	.0343	.0572	.0514	.0572
20	.0514	.0514	.0514	.0514	.0572	.0514	.0572
21	.0343	.0686	.0514	.2058	.3086	.3258	.2401
22	.0343	.0514	.0514	.2743	.3658	.8059	.3963
23	.0381	.0572	.0343	.2267	.3239	.2915	.3401
24	.2229	.0381	.0572	.0343	.1781	.2267	.2743
Max	.2743	.7011	.6554	.7316	.3658	.8059	.3963
Min	.0171	.0191	.0343	.0191	.0171	.0191	.0171
Avg	.0901	.1947	.2102	.2509	.1195	.1405	.1398

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214413 / 33/11KV MANCHAR

Feeder No / Name : 402 / 33 Kv Parag Express
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3663	1.749	1.8519	2.0576	1.9033	1.9547	1.8004
2	2.3663	1.6461	1.8519	1.9547	1.9033	1.9547	1.8004
3	2.2634	1.6461	1.8004	1.9547	1.9547	2.0576	1.8519
4	2.4177	1.5432	1.8004	1.8519	1.9547	2.1091	1.9547
5	2.1605	1.5432	1.749	1.8004	2.0576	2.0576	2.0062
6	2.3148	1.6461	1.8004	1.8004	2.0576	2.2119	2.0062
7	2.1605	1.749	1.749	1.3375	2.1605	2.0062	2.1605
8	2.1605	1.9547	2.0062	1.4918	2.4691	2.4177	2.3663
9	2.2634	2.1605	2.1605	1.9547	2.5206	2.7778	2.2634
10	2.3663	2.0576	2.3148	2.2119	2.6749	2.6235	2.2634
11	2.2634		2.572	2.3663	2.8292	2.3663	2.4691
12	2.0576	2.4177	2.4177	2.3663	2.7778	2.5206	2.1605
13	2.0576	2.2119	2.3663	2.1091	2.6749	2.2634	1.5947
14	2.1605	2.1605	2.3663	2.2634	2.2119	2.4691	2.0062
15	2.4691	2.3148	2.572	2.5206	2.1605	2.1605	2.2634
16	2.0576		2.1091	2.3148	2.3148	2.0062	2.2119
17	1.9033	2.3663	2.1091	2.3148	2.1091	2.1091	2.2634
18	2.1091	2.1091	2.1091	2.1091	2.1605	2.2119	1.3889
19	2.1091	2.0062	1.9547	1.8519	1.9547	2.1605	2.1091
20	2.1605	1.9547	2.0062	1.9033	1.9033	2.0062	2.2119
21	2.1091	1.8004	2.0062	1.9547	1.8519	2.0576	2.0062
22	2.2119	1.8004	2.0576	2.0062	2.0576	1.9033	2.0062
23	2.0062	2.0062	2.0062	2.0576	2.1091	2.0062	1.9547
24	2.4177	2.0576	1.8519	2.0576	2.0062	2.0062	1.9033
Max	2.4691	2.4177	2.572	2.5206	2.8292	2.7778	2.4691
Min	1.9033	1.5432	1.749	1.3375	1.8519	1.9033	1.3889
Avg	2.2055	1.9501	2.0662	2.0255	2.1991	2.1841	2.0426

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214413 / 33/11KV MANCHAR

Feeder No / Name : 403 / 33 Kv Morade Food Express NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8519	1.749	2.0062	1.9033	1.6461	1.5947	1.5947
2	2.0576	1.8519	2.0062	1.9033	1.749	1.5432	1.5432
3	2.0576	1.8519	2.0576	1.9547	1.749	1.6461	1.5432
4	2.0062	1.8004	2.0576	1.9547	1.8519	1.6461	1.6975
5	2.0062	1.749	2.0576	2.0062	1.8519	1.749	1.9033
6	1.9547	1.749	2.0576	2.0062	1.9547	1.9033	2.1605
7	1.5947	1.5947	1.6461	1.6461	1.6975	1.6461	1.5432
8	1.9547	1.8004	2.2291	1.9547	2.2119	2.0576	1.9033
9	1.9547	1.9547	1.8519	2.0576	2.2119	2.3663	2.0062
10	1.9547	1.8004	2.1091	2.0576	2.1091	2.4577	2.0062
11	2.3663		2.1605	2.2634	2.3148	1.9033	1.9033
12	2.1091	1.5947	2.0576	2.1091	2.0576	2.2291	1.8004
13	2.0062	1.8004	1.9547	2.1091	2.2119	2.1091	1.9547
14	2.2119	1.749	2.2119	2.2119	2.1091	2.2634	1.9033
15	2.0576	1.749	2.1605	2.0576	1.9033	2.2291	1.9547
16	1.9033		2.2634	1.9547	2.0062	1.8519	1.8519
17	1.6975	1.8004	2.3148	2.0576	2.1605	1.9547	2.0576
18	2.2634	1.9033	1.8519	2.0062	2.0062	1.8519	1.5432
19	1.8519	1.6461	1.8519	2.1091	2.1605	2.0062	1.9033
20	1.8004	1.9033	1.9033	2.2119	2.2119	1.6975	2.0062
21	1.5947	1.6461	1.9033	2.1091	2.1091	1.5432	1.9547
22	1.8519	1.8004	2.1605	2.1605	2.1091	1.9033	2.0576
23	1.8519	2.0576	2.2634	2.1605	2.2119	1.9547	1.9033
24	1.4918	1.6975	1.8004	1.9033	1.6461	1.5947	1.5947
Max	2.3663	2.0576	2.3148	2.2634	2.3148	2.4577	2.1605
Min	1.4918	1.5947	1.6461	1.6461	1.6461	1.5432	1.5432
Avg	1.9355	1.7841	2.0390	2.0362	2.0105	1.9043	1.8454

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062] BU 5819

Substation No/ Name :- 214440 / 33/11KV KATHAPUR

Feeder No / Name : 200 / AUXILARY FEEDER

Feeder KV- 11 / OUTGOING

DATE	09-FEB-18
HR	Load (MW)
12	.9804
Max	.9804
Min	.9804
Avg	.9804

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214440 / 33/11KV KATHAPUR

Feeder No / Name : 201 / 11KV KATHAPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4687	.0566	.0377	.0377	.6321	.5569	.5668
2	.4744	.0566	.0566	.0377	.6321	.5719	.5668
3	.506	.0566	.0566	.0566	.6321	.5719	.5761
4	.5121	.0754	.0754	.0732	.6472	.587	.5761
5	.5218	.0943	.0943	.0943	.6874	.6097	.6081
6	.5312	.132	.1307	.132	.6874	.6097	.6081
7	.1402	.132	.1494	.1509	.1132	.1307	.168
8	.1086	.8381	1.0364	1.012	.132	.132	.168
9	.0914	.9762	1.1142	1.0364	.0934	.0754	.132
10	.0549	.9717	1.1142	1.1174	.0747	.0566	.0747
11	.0366	.9602	1.085	.9995	.0747	.0366	.0566
12	.0526	.9804	1.1305	1.0402	.0554	.0189	.056
13	.0324	.8539	1.085	.9842	.0373	.0377	.0373
14	.0339	.8855	1.0688	.953		.0377	.0354
15	.0537	.9014	1.0722	.8951	.0373	.0377	.0373
16	.052	.0566	.0554	.0486	.0373	.0377	.0373
17	.0509	.0754	.0716	.0716	.0509		.0509
18	.0663	.0566	.0732	.0686	.0526	.0377	.0747
19	.0934	.0754	.0754	.0905	.0747	.0754	.0943
20	.0747	.0943	.0943	.0747	.0747	.0566	.0754
21	.0554	.0566	.0754	.6923	.5796	.5898	.5556
22	.056	.0566	.0566	.6706	.5575	.5898	.503
23	.056	.0566	.0566	.6706	.5647	.5761	.503
24	.4902	.0566	.0377	.0566	.5498	.5569	.4877
Max	.5312	.9804	1.1305	1.1174	.6874	.6097	.6081
Min	.0324	.0566	.0377	.0377	.0373	.0189	.0354
Avg	.1922	.3565	.4126	.4610	.3077	.2865	.2771

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214440 / 33/11KV KATHAPUR

Feeder No / Name : 202 / 11KV DEOGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1663	1.1544	1.2967	1.2803	.2054	.1867	.2054
2	.1663	1.1544	1.2967	1.2803	.2054	.1867	.2054
3	.2054	1.2018	1.3916	1.3283	.2241		.2614
4	.2801	1.2498	1.4232	1.3763	.2614	.2987	.2987
5	.3361	1.3279	1.4548	1.4575	.3361	.3361	.3292
6	.3881	1.3435	1.5655	1.5223	.4108	.3547	.4024
7	.4938	.5228	.5228	.4294		.4668	.5304
8	2.0873	.4435	.4435	.4251	2.1464	2.4166	2.3805
9	2.3245	.3326	.3696	.3881	2.4086	2.7526	2.5911
10	2.3845	.2772	.2957	.2743	2.7199	2.8837	2.6882
11	2.1605	.2328	.2241	.2896	2.7854	2.3845	2.7206
12	2.2565	.2012	.2172	.2126	2.7206	2.6086	2.6246
13	2.0153	.2378	.1949	.2254	2.5446	2.6086	2.5152
14	2.0083	.2378	.1989	.2058	2.4371	2.5286	2.4669
15	.1478	.2378	.156	.2012	2.198	2.332	2.2685
16	.1372	.2054	.1612	.1928	.12	.2054	.0343
17	.1341	.2427	.1928	.208	.1372	.2241	.2056
18	.1619	.2218	.2743	.1907	.2241	.2614	.2658
19	.3881	.3361	.3511	.3696	.3361	.3292	.4024
20	.3696	.3696	.3547	.3921	.3511	.3361	.3881
21	1.4243	1.1984	1.4083	.3361	.3174	.3547	.3361
22	1.3123	1.4089	1.3763	.2801	.0373	.2987	.2614
23	1.2334	1.3441	1.3283	.2427	.2054	.2241	.2614
24	.1663		1.2651	1.2803	.1867	.1867	.2427
Max	2.3845	1.4089	1.5655	1.5223	2.7854	2.8837	2.7206
Min	.1341	.2012	.156	.1907	.0373	.1867	.0343
Avg	.9478	.6731	.7401	.5995	1.0226	1.0768	1.0369

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214440 / 33/11KV KATHAPUR

Feeder No / Name : 203 / 11KV LAKHANGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3283	.2172	.2241	.2427	1.4899	1.5181	1.5893
2	1.3123	.2172	.2241	.2427	1.4899	1.5181	1.5893
3	1.3441	.2353	.2614	.2614	1.5223	1.5497	1.6057
4	1.3923	.2772	.2614	.2987	1.6057	1.5684	1.6057
5	1.4548	.3326	.4108	.3734	1.6385	1.5844	1.6385
6	1.4998	.3547	.4572	.4108	1.7072	1.5844	1.6356
7	.4207	.5228	.5121	.5304	.5281	.547	.5228
8	.5731	2.4249	2.6882	2.6052	.5041	.5415	.4668
9	.439	2.8509	2.8182	2.9001	.3921	.5041	.4108
10	.4207	3.0639	2.7035	2.8673	.3395	.3881	.3174
11	.3696	2.8988	3.1459	2.8837	.2561	.3258	.2614
12	.2957	2.2154	3.083	2.672		.3077	.2801
13	.2378	2.0988		2.451		.3258	.2303
14	.2715	2.0538	2.9329	2.3967		.2896	.2149
15	.2427	1.9738	2.6379	2.1822	.1886	.2715	.2402
16	.2378	.2427	.2561	.1949	.2481	.2561	.2353
17	.2743	.2241	.3142	.2126	.2715	.2926	.2279
18	.3077	.2427	.3696	.2149	.3045	.2378	.2686
19	.4251	.3174	.4435	.3142	.3547	.3109	.3511
20	.3881	.3734	.3841	.3547	.3547	.3658	.3547
21	.3326	.3361	.3361	1.587	1.5524	1.5181	1.6842
22	.2957	.2614	.2987	1.6032	1.6129	1.6484	1.6324
23	.2587	.2614	.2801	1.5729	1.5339	1.6356	1.6129
24	1.3599	.2172	.2241	.2427	1.5181	1.5181	1.6164
Max	1.4998	3.0639	3.1459	2.9001	1.7072	1.6484	1.6842
Min	.2378	.2172	.2241	.1949	.1886	.2378	.2149
Avg	.6451	1.0089	1.0986	1.2340	.9244	.8587	.8580

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214440 / 33/11KV KATHAPUR

Feeder No / Name : 204 / 11KV KATHAPUR GFFS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.128	.0823		.1265	.1269	.1475	.1219
2	.1265	.1036		.1265	.1269	.2294	.125
3	.1581	.1235		.1423	.1486	.2347	.1783
4	.1875	.1738	.1646	.1943	.1852	.3018	.2054
5	.2675	.2812	.2332	.2915	.2469	.3222	.2195
6	.3437	.3944	.3189	.4359	.3887	.373	.2721
7	.4268	.4862	.3094	.4687	.4012	.4475	.2934
8	.3704	.3948	.2873	.4033	.3467	.3814	.2873
9	.2027	.204	.2286	.306	.202	.2961	.2743
10	.1158	.0583	.189	.0615	.0514	.2462	.1781
11	.0594	.04	.2073	.048	.0613	.0617	.1858
12	.0343	.0652	.0518	.1488	.0438	.1814	.1313
13	.0297	.072	.04	.0686	.0343	.189	.0347
14	.0272	.0892	.0343	.032	.0356	.161	.0335
15	.0251	.0943	.0347	.0686	.0223	.1486	.0274
16	.0314	.1326	.0347	.0223	.0434	.1372	.0446
17	.0343	.1387	.0347	.0274	.052	.1635	.0373
18	.0453	.1372	.192	.0362	.0398	.1216	.0427
19	.202	.2105	.2315	.1879	.2667	.1486	.2643
20	.2538	.1781	.2606	.1911	.2559	.2008	.2824
21	.2258	.1886	.2343	.2225	.253	.1858	.2187
22	.1781	.1555	.1898	.1412	.2155	.1829	.1656
23	.1581	.1429	.1638	.1372	.1638	.1235	.1635
24	.128	.0823	.125	.1341	.1475	.1475	.1404
Max	.4268	.4862	.3189	.4687	.4012	.4475	.2934
Min	.0251	.04	.0343	.0223	.0223	.0617	.0274
Avg	.1566	.1679	.1698	.1676	.1608	.2139	.1636

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214440 / 33/11KV KATHAPUR

Feeder No / Name : 205 / 11KV PONDEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	1.4864	1.1822	1.25	.0953	.0381	.0762
2	.0953	1.4864	1.1984	1.25	.0953	.1524	.0762
3	.1132	1.5181	1.2631	1.2809	.0381	.1524	.1143
4	.1509	1.5684	1.2651	1.2809	.1334	.2075	.1509
5	.2075	1.6004	1.2651	1.3279	.1905	.2641	.2263
6	.2667	1.7368	1.3125	1.3904	.3429	.2829	.2829
7	.3239	.362	.3395	.362	.381	.3961	.3734
8	2.2184	.3048	.3206	.362	2.7244	2.3122	2.4669
9	2.625	.2477	.2667	.3048	2.7199	2.3434	2.734
10	2.5775	.2096	.1905	.2477	2.8182	2.4215	2.6402
11	2.4827	.1715	.1715	.1905	2.6408	2.6402	2.625
12	2.5606	.0762	.1715	.1334	2.5459	2.5775	2.5766
13	2.3205	.0762	.1334	.1143	2.5143	2.5934	2.4996
14	2.4806	.0762	.1143	.0953	2.5459	2.4669	2.4669
15	.1334	.0762	.0953	.0762	2.4966	2.4036	2.3122
16	.1143	.0762	.1715	.1715	.1143		.1143
17	.1334	.0762	.1715	.1905	.1524	.1509	.1524
18	.1524	.1509	.2096	.1715	.1524	.1698	.1905
19	.2096	.1698	.2286	.2286	.2286	.2075	.1905
20	.2096	.1867	.2096	.1905	.1715	.2075	.2096
21	1.531	1.1702	1.2811	.1715	.1715	.1698	.1715
22	1.531	1.1843	1.3279	.1715	.1524	.1509	.1715
23	1.5497	1.1984	1.2809	.1524	.1143	.0762	.1715
24	.0953	1.4864	1.1822	1.25	.0953	.0953	.1715
Max	2.625	1.7368	1.3279	1.3904	2.8182	2.6402	2.734
Min	.0953	.0762	.0953	.0762	.0381	.0381	.0762
Avg	1.0074	.6957	.6397	.5152	.9848	.9774	.9652

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214458 / 33/11KV RANJANI

Feeder No / Name : 201 / 11 KV RAJANI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18
HR	Load (MW)	Load (MW)
1		.9259
2		.9259
3		.9431
4		.9431
5		.9602
6		.9774
7		.5487
8		.5144
9		.4801
10	.4973	
11	.4115	
12	.3601	
13	.3086	
14	.2743	
15	.3258	
16	.3601	
17	.4115	
18	.4801	
19	.4801	
20	.4115	
21	.9774	
22	1.1317	
23	1.0288	
24		.9259
Max	1.1317	.9774
Min	.2743	.4801
Avg	.5328	.8145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062] BU 5819

Substation No/ Name :- 214458 / 33/11KV RANJANI

Feeder No / Name : 202 / 11KV WALTI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18
HR	Load (MW)	Load (MW)
1		1.8861
2		1.8861
3		1.8861
4		1.9204
5		1.9376
6		1.989
7		.8402
8		.9088
9		.7545
10	.583	
11	.4287	
12	.5487	
16	.5316	
17	.6344	
18	.6516	
19	.6687	
20	.6516	
21	1.9376	
22	1.9547	
23	1.9033	
24		1.8861
Max	1.9547	1.989
Min	.4287	.7545
Avg	.9540	1.5895

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214458 / 33/11KV RANJANI

Feeder No / Name : 203 / 11KV-GANJEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18
HR	Load (MW)	Load (MW)
1		.9431
2		.9259
3		.9259
4		.9431
5		.9945
6		1.046
7		.4115
8		.4115
9		.3944
10	.3258	
11	.3258	
12	.3086	
13	.2915	
14	.2915	
15	.2743	
16	.3086	
17	.3601	
18	.3772	
19	.3944	
20	.3601	
21	1.2346	
22	1.2517	
23	1.1831	
24		1.0288
Max	1.2517	1.046
Min	.2743	.3944
Avg	.5205	.8025

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214458 / 33/11KV RANJANI

Feeder No / Name : 204 / 11 KV THORANDALE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18
HR	Load (MW)	Load (MW)
1		.4458
2		.4458
3		.4801
4		.6001
5		.7373
6		.9774
7		1.1317
8		2.0919
9		2.332
10	2.6406	
11	2.5206	
12	2.4006	
13	2.2805	
14	2.2291	
15	2.0748	
16	.6001	
17	.6859	
18	.7888	
19	1.0117	
20	.8916	
21	.7888	
22	.6344	
23	.5658	
24		.5144
Max	2.6406	2.332
Min	.5658	.4458
Avg	1.4367	.9757

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062] BU 5819

Substation No/ Name :- 214458 / 33/11KV RANJANI

Feeder No / Name : 205 / WESTORN HILLS
Feeder KV- 11 / OUTGOING

SHEDDABLE HV(AGRICULTURE)

DATE	08-FEB-18	09-FEB-18
HR	Load (MW)	Load (MW)
7		.0017
10	.0017	
11	.0017	
12	.0017	
13	.0017	
14	.0017	
15	.0017	
16	.0017	
21	.0017	
Max	.0017	.0017
Min	.0017	.0017
Avg	.0017	.0017

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062] BU 5819

Substation No/ Name :- 214458 / 33/11KV RANJANI

Feeder No / Name : 206 / 11KV NAGAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18
HR	Load (MW)	Load (MW)
1		.2058
2		.2058
3		.2229
4		.2572
5		.3086
6		.3601
7		.4801
9		2.0233
10	1.9033	
11	1.989	
12	2.0748	
13	1.9204	
14	1.8176	
15	1.6118	
16	.1372	
17	.1886	
18	.2401	
19	.3429	
20	.3258	
21	.2915	
22	.2743	
23	.2572	
24		.2229
Max	2.0748	2.0233
Min	.1372	.2058
Avg	.9553	.4763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214475 / 33/11kV PIMPALGAON

Feeder No / Name : 201 / 11KV SHRIRAM

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1629	.0381	.0572	.0381	.2286	.1848	.1905
2	.1629	.0381	.0572	.0381	.1905	.1848	.1905
3	.1629	.0381	.0572	.0572	.1905	.2033	.2096
4	.1629	.0381	.0572	.0572	.2286	.2033	.2286
5	.181	.0572	.0572	.0572	.2286	.2218	.2477
6	.1991	.0572	.0762	.0572	.2477	.2587	.2667
7	.0543	.0762	.0762	.0572	.0762	.0724	.0762
8	.0543	.724	.6478	.7621	.0762	.0543	.0762
9	.0362	.9907	.8002	.8954	.0724	.0543	.0762
10	.0362	.8954	.8383	.9335	.0362	.0543	.0572
11	.0381	.9145	.8573	.9335	.0362	.0572	.0572
12	.0572	.9145	.7811		.0362	.0572	.0572
13	.0381	.9145	.6668	.8192	.0362	.0572	.0381
14	.0381	.7621	.6859	.7049	.0362	.0572	.0381
15	.0381	.7049	.6859	.6287	.0362	.0572	.0381
16	.0381	.0381		.0572	.0362	.0572	.0381
17	.0381	.0381		.0572	.0362	.0572	.0381
18	.0381	.0381	.0381	.0572	.0362	.0572	.0572
19	.0572	.0572	.0572	.0572	.0362	.0572	.0572
20	.0572	.0572	.0572	.0572	.0543	.0572	.0572
21	.0572	.0572	.0572	.3048	.2353	.2858	.3429
22	.0572	.0572	.0572	.2858	.2402	.2667	.2858
23	.0381	.0572	.0572	.2667	.2033	.2286	.2477
24	.181	.0381	.0572	.0572	.2477	.2033	.2096
Max	.1991	.9907	.8573	.9335	.2477	.2858	.3429
Min	.0362	.0381	.0381	.0381	.0362	.0543	.0381
Avg	.0827	.3168	.3083	.3148	.1201	.1270	.1326

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214475 / 33/11kV PIMPALGAON

Feeder No / Name : 202 / 11KV KANIPHNATH

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8145	.0762	.0724	.1486	1.2127	1.1765	1.2308
2	.7783	.0953	.0905	.1858	1.086	1.1765	1.2127
3	.7783	.1143	.0905	.1858	1.086	1.1765	1.1765
4	.7783	.1905	.1086	.2601	1.1222	1.1946	1.2308
5	.8145	.1905	.1267	.2972	1.2308	1.2127	1.267
6	.8869	.2096	.1629	.3334	1.3032	1.267	1.3213
7	.1991	.2477	.1991	.4458	.2172	.2353	.2353
8	.1448	1.9433	2.2361	4.5789	.1629	.1991	.181
9	.1448	2.2481	4.6154	4.9543	.1629	.181	.2972
10	.1267		5.1419	4.8793	.1086	.1629	.1448
11	.0953		4.7666	4.654	.0905	.1267	.1086
12	.0762		4.6916	2.2361	.181	.1086	.1086
13	.0762		4.5789	2.2731	.1086	.0905	.1086
14	.0762	2.191	4.4288	2.1437	.0905	.1858	.1086
15	.0762		4.0535	1.9774	.0724	.1086	.1086
16	.0953	.0724	.1486	.1086	.0905	.1086	.1086
17	.1334	.0905	.1858	.1086	.0724	.1086	.1086
18	.1524	.1086	.2229	.1267	.0905	.1086	.181
19	.1715	.1448	.2972	.1629	.1448	.1629	.181
20	.1715	.1448	.3344	.181	.1629	.1448	.181
21	.1524	.2601	.2601	1.4815	1.267	2.7121	1.3575
22	.1143	.1086	.2582	1.448	1.267	1.3032	1.3756
23	.0953	.1486	.1858	1.267	1.2127	2.6006	1.267
24	.8688	.0762	.0724	.1486	1.2308	1.1765	1.2489
Max	.8869	2.2481	5.1419	4.9543	1.3032	2.7121	1.3756
Min	.0762	.0724	.0724	.1086	.0724	.0905	.1086
Avg	.3259	.4558	1.5554	1.4411	.5739	.7095	.6187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214475 / 33/11kV PIMPALGAON

Feeder No / Name : 203 / 11KV KHADAKI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	1.2955	1.5242	1.4289		.2172	.2096
2	.181	1.2574	1.5432	1.4861	.2667	.2172	.2096
3	.181	1.2384	1.5432	1.5051	.3048	.2172	.2286
4	.2172	1.3336	1.6194	1.5242	.3429	.2534	.2667
5	.2896	1.6194	1.7147	1.5813	.4191	.3258	.3429
6	.4344	1.7147	1.7528	1.6194	.5335	.4163	.4191
7	.5068	.5335	.5335	.5335	.5144	.4887	.5335
8	2.5688	.4382	.4572	.5144	2.3053	2.9199	2.8578
9	2.6981	.3239	.4191	.4001	2.7069	3.1047	2.9721
10	2.6981	.2096	.2667	.362	2.8532	3.1047	2.9721
11	2.7054	.1905	.2096	.2286	2.9938	3.1245	2.9912
12	2.6482	.1905	.1905	.1905	2.8829	3.0483	
13	2.4768	.1905	.1715	.2096	2.9569		2.8197
14	2.1719	.1334	.1524	.1905	2.6242	2.915	2.7816
15	2.0957	.1524	.1524	.1524	2.5873	2.8578	2.6292
16	.1905	.1715		.1905	.1991	.1905	.1905
17	.2096	.1715	.2096	.2096	.1991	.2096	.1905
18	.2858	.2286	.2286	.2286	.1991	.2286	.2858
19	.362	.3429	.3239	.362	.3077	.3239	.362
20	.3429	.3429	.3429	.3239	.3439	.3429	.3429
21	1.5242	1.4289	1.3336	.2858	.2896	.3239	.2667
22	1.467	1.6004	1.448	.2667	.2896	.2667	.2286
23	1.3717	1.5623	1.4289	.2286	.2534	.1905	.1905
24	.181	1.3336	1.5242	1.4289	.2286	.2353	.1905
Max	2.7054	1.7147	1.7528	1.6194	2.9938	3.1245	2.9912
Min	.181	.1334	.1524	.1524	.1991	.1905	.1905
Avg	1.1662	.7502	.8300	.6438	1.1566	1.1097	1.0644

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214518 / 33/11KV PIMPARKHED

Feeder No / Name : 201 / 11KV MUKTAI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.0995	.0934	.1006	.2949	.1867	.3315
2	.3961	.0829	.0934	.1006	.2785	.1867	.3481
3	.3521	.0972	.0934	.1132	.2591	.2054	
4	.3521	.0995	.0934	.1132	.2785	.2614	.3441
5	.3688	.1006	.0934	.1174	.2949	.3361	.1296
6	.3688	.1341	.112	.1174	.2949	.3734	.4641
7	.132	.1326	.0934	.1341	.0983	.0934	.0829
8	.1132	.5304	.3547	.5197	.0819	.0934	.0829
9	.1132	.5344	.3921	.6036	.0829	.0943	.0829
10	.0995		.3374	.4973	.0934	.0829	.0838
11	.0995		.4862	.4588	.0934	.0663	.0838
12	.0995		.4548	.4144	.0934	.0829	.0734
13			.503	.426	.0934	.0829	.0943
14	.0671		.4359	.4049		.0829	.0943
15	.1006		.4024	.3768	.0934	.0829	.0838
16	.0829		.1006	.0655	.0934	.0663	.0734
17			.088	.0648	.0934	.0829	.0838
18			.088	.0819	.0934	.0829	.1006
19			.1006	.0819	.0934	.0829	
20			.1132	.0819	.0934		
21			.088	.2984	.2241		.2683
22			.1006	.2949	.2241		.2347
23			.088	.3149	.1867		.2494
24	.2934	.0995	.0934	.088	.3077	.1867	.3315
Max	.3961	.5344	.503	.6036	.3077	.3734	.4641
Min	.0671	.0829	.088	.0648	.0819	.0663	.0734
Avg	.2135	.1911	.2041	.2446	.1670	.1407	.1772

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214518 / 33/11KV PIMPARKHED

Feeder No / Name : 202 / 11KV KATHAPUR ROAD
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7377	.1492	.1494	.1174	.7625	.7095	.5967
2	.6748	.1326	.1494	.1174	.7293	.6908	.5967
3	.6748	.2321	.1494	.1174	.7045	.7095	.5967
4	.7712	.2486	.3361	.1467	.7373	.7282	.6299
5	.788	.2486	.2054		.7373	.724	
6	.788	.2321	.2241	.1614	.7865	.7842	.6464
7	.2294	.218	.2614	.2012	.1989	.2241	.1823
8	.2263	1.1603	.9335	1.1233	.2012	.3361	.1989
9	.2012	1.1603	1.0456	1.1904	.1638	.168	.1989
10	.0995		1.3014	1.1603	.112	.1326	.2012
11	.1006		1.3245	1.1469	.0934	.1326	.1614
12	.0995		1.291	1.1305	.0934	.128	.1677
13	.0829		1.2574	1.0442	.0934	.1492	.1509
14	.0829		1.2239	.9831		.1326	.1698
15	.0829		1.1568	1.0159	.0934	.1326	.1698
16	.1492		.132	.0819	.1494	.1341	.1698
17			.1509	.0819	.1867	.1492	.1509
18			.132	.1311	.2263	.1492	.1844
19			.1509	.1658	.2614	.1326	
20			.1509	.1823	.2801		
21			.1509	.6554	.7468		.5868
22			.1027	.7373	.7468		.5868
23			.1174	.7373	.7095		.5281
24	.3688	.1492	.1494	.1174	.7625	.7095	.5668
Max	.788	1.1603	1.3245	1.1904	.7865	.7842	.6464
Min	.0829	.1326	.1027	.0819	.0934	.128	.1509
Avg	.3622	.3931	.5103	.5455	.4164	.3578	.3543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214518 / 33/11KV PIMPARKHED

Feeder No / Name : 203 / 11KV AMBEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-FEB-18
HR	Load (MW)
1	.132
2	.132
3	.1844
4	.1844
5	.218
6	.2347
7	.2515
8	1.0562
9	1.2449
10	.9556
11	.9724
12	.9282
13	.9069
15	.1326
16	.1326
24	.1509
Max	1.2449
Min	.132
Avg	.4886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214518 / 33/11KV PIMPARKHED

Feeder No / Name : 204 / 11kv PIMPARKHED GFFS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.0995	.1494	.1174	.1492	.112	.1326
2	.1509	.1174	.1867	.1174	.116	.112	.0829
3	.1341	.1134	.1715	.1174	.0655	.1509	.1296
4	.1341	.1174	.2241	.1341	.1311	.168	.116
5	.1698	.0983	.2172	.1509	.1296	.1867	.0972
6	.1509	.1006	.2614	.1677	.1311	.2058	.0829
7	.1509	.1006	.2241	.1844	.1341	.2054	.081
8	.1509	.0995	.1867	.1886	.1823	.1867	.0995
9	.1509	.1341	.1494	.1677	.1638	.1494	.116
10	.0829		.1341	.1677	.0862	.1326	.1174
11	.0995		.1509	.1475	.0934	.0995	.1027
12	.0995		.1341	.1475	.0819	.0838	.1174
13	.0829		.1341	.1475	.0934	.0829	.132
14	.0829		.1509	.1475		.1006	.1174
15	.0829		.1174	.1492	.0934	.0829	.1174
16	.0838		.1341	.1326		.1006	.1341
17			.1341	.1475		.0995	.1509
18			.1509	.1475	.1494	.0829	.1341
19			.1174	.1475	.1067	.0995	
20			.1341	.1457			
21			.1341	.1475	.1867		.1341
22			.1341	.1492	.1494		.1341
23			.1174	.1492	.0934		.1174
24	.0838		.0934	.1341	.1475	.112	.1326
Max	.1698	.1341	.2614	.1886	.1867	.2058	.1509
Min	.0829	.0983	.0934	.1174	.0655	.0829	.081
Avg	.1201	.1090	.1559	.1481	.1242	.1277	.1172

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214518 / 33/11KV PIMPARKHED

Feeder No / Name : 205 / 11KV PIMPARKHED

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1844	1.1271	1.0185	1.0059	.2591	.1867	.2486
2	.1844	1.0277	1.0269	1.0227	.2458	.2241	.2321
3	.1844	1.0442	1.0829	1.0395	.2458	.2614	.2429
4	.2075	1.0442	1.1203	1.1065	.2294	.3547	.2622
5	.285	1.0562	1.1576	1.2826	.2949	.3921	.1846
6	.3521	1.0562	1.1949	.5868	.3441	.4481	.2984
7	.5281	.4807	.5415	.4527	.4588	.5601	.3315
8	1.3245	.4807	.4108	.4024	1.3927	1.6057	1.6575
9	1.4083	.3315	.2987	.3353	1.5581	1.643	1.6907
10	1.4255		.2347	.0328		1.4586	1.5927
11	1.4255		.2075	.2321		1.4752	1.773
12	1.1271		.1677	.1326		1.1736	1.5424
13	1.0774		.1677	.1326		1.2574	1.6975
14	1.0608		.1509	.1326			1.5089
15	1.0608		.132	.1326		1.1603	1.4754
16	.1326		.1509	.1296		.1989	.1677
17			.132	.1658		.1989	.1844
18			.1509	.2429		.2155	.1844
19			.218	.3239		.1966	
20			.2515	.3932			
21			.9724	.4096			.1614
22			.9724	.3887			.1677
23			.8802	.3441			.1677
24	.1844	1.1271	1.0269	1.0059	.3277	.1867	.2652
Max	1.4255	1.1271	1.1949	1.2826	1.5581	1.643	1.773
Min	.1326	.3315	.132	.0328	.2294	.1867	.1614
Avg	.7149	.8776	.5695	.4764	.5356	.6946	.7290

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214518 / 33/11KV PIMPARKHED

Feeder No / Name : 206 / 11KV TUKAI DEVI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0335	.9448	.8962	1.094	.0324	.0373	.0332
2	.0335	.9122	.9149	.9724	.0328	.0373	.0335
3	.0335	1.0442	.9335	.503	.0324	.0373	.0332
4	.0377	.9448	1.0134	1.0059	.0328	.0373	.0324
5	.0335		1.1203	1.1506	.0328	.0373	.0332
6	.0335	.9175	1.1203	1.0227	.0328	.0373	.0332
7	.0335	.0324	.0373	.0335	.0328	.0373	.0332
8	1.291	.0332	.0373	.0335	1.1305	1.3817	1.5746
9	1.5278	.0332	.0373	.0366	1.21	1.4003	1.5746
10	1.1271		.0335	.0332			1.423
11	1.1736		.0335	.0328		1.2597	
12	1.0608		.0335	.0328		1.2431	1.423
13	1.073		.0335	.0328		1.2929	1.576
14	.0335		.0335	.0328		1.3077	1.5592
15	.0332		.0377	.0328		1.3077	1.5257
16	.0335		.0377	.0328		.0335	.0293
17			.0293	.0328		.0332	.0328
18			.0335	.0328		.0335	.0335
19			.0335	.0324		.0332	
20			.0335	.0328			
21			.8069	.0324			.0335
22			.8509	.0324			.0335
23			.8509	.0328			.0335
24	.0335	.9282	.8962	.9724	.0328	.0373	
Max	1.5278	1.0442	1.1203	1.1506	1.21	1.4003	1.576
Min	.0332	.0324	.0293	.0324	.0324	.0332	.0293
Avg	.4486	.6434	.4120	.3035	.2602	.5066	.5542

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214518 / 33/11KV PIMPARKHED

Feeder No / Name : 207 / 11KV CHANDOH

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4083	.3018	.3547	.1677	1.2616	1.6057	1.2763
2	1.4083	.2753	.3174	.1677	1.2929	1.6565	1.2742
3	1.5729	.3239	.3361	.1677	1.326	1.6804	1.2597
4	1.5089	.4641	.5228	.218	1.3927	1.7551	1.2431
5	1.5424	.4696	.4481	.2683	1.4746	1.7924	1.2431
6	1.5927	.5138	.5601		1.6385	1.9044	1.2763
7	.4862	.5197	.5975	.5197	.5079	.5788	.5138
8	.4527	2.1548	1.7926	2.3472	.4144	.4854	.5138
9	.2201	2.1548	2.0538	2.7726	.3768	.4108	.5138
10	.1326		2.0119	2.5526			.3018
11	.1326		2.1125	2.5029		.1492	.2012
12			2.1963	2.3371		.1658	.1614
13	.1326		2.2466	2.1963		.1823	.1886
14	.1341		2.2298	2.13		.1296	.1886
15	.1326		2.1795	1.7901			.1509
16	.1492		.1844	.1638		.1658	.1886
17			.1844	.1619		.1677	.1886
18			.176	.2458		.1844	.1844
19			.2054	.3768		.1658	
20			.2012	.426			
21			.1614	1.1603			1.1904
22			.1677	1.2431			1.2071
23			.1467	1.2289			1.2071
24	1.3748	.2652	.2987	.1677	1.2597	1.6244	1.2597
Max	1.5927	2.1548	2.2466	2.7726	1.6385	1.9044	1.2763
Min	.1326	.2652	.1467	.1619	.3768	.1296	.1509
Avg	.7738	.7443	.9036	1.1005	1.0945	.8225	.7151

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214521 / 33/11KV SHINGAVE

Feeder No / Name : 201 / 11KV PARGAON ROAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.583	.0762	.0762		.5144	
2	.583	.0762	.0762	.0762	.4801	
3	.583	.0762	.0762	.0762	.4801	
4	.5487	.0762	.0762	.0762	.4801	
5	.5487	.0953	.0762	.1143	.4801	
6	.5487	.0953	.1143	.1143	.4801	
7	.0686	.1143	.1524	.1524	.0686	
8	.0686	.8192	.8764	.9907	.0686	
9	.0686	.9145	.9145	.9907	.0686	
10	.0686	.9907	.8764	1.0288	.0686	
11	.0953	.9907	.8383	.8916	.0762	.0686
12	.0953	.9907	.7621	.823	.0762	.0686
13	.0953	.9526	.7621	.7545	.0762	.0686
14	.0762	.9145	.8383	.7545		.0686
15	.0762	.9145	.8764	.7545	.1143	.0686
16	.0762	.1143	.1524	.0686	.1143	.0686
17	.0953	.1143	.1524	.0686	.1143	.0686
18	.0953	.1143	.1524	.0686	.1334	.0686
19	.1143	.1143	.1524	.0686	.1334	.0686
20	.1334	.1143	.1524	.0686	.1334	.0686
21	.1143	.1143	.1143	.5144	.5335	.583
22	.0953	.1143	.1143	.5144	.5716	.583
23	.0953	.0762	.0762	.5144	.6097	.583
24	.583	.0762	.0762	.0762	.5144	
Max	.583	.9907	.9145	1.0288	.6097	.583
Min	.0686	.0762	.0762	.0686	.0686	.0686
Avg	.2296	.3771	.3556	.4157	.2778	.1873

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214521 / 33/11KV SHINGAVE

Feeder No / Name : 202 / 11KV SANGAM

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.0191	.0191	.0191	.3944	
2	.2915	.0191	.0191	.0191	.3944	
3	.2743	.0191	.0191	.0191	.3601	
4	.2743	.0191	.0191	.0191	.3601	
5	.2743	.0191	.0191	.0191	.3601	
6	.2743	.0191	.0191	.0191	.3601	
7	.0171	.0191	.0191	.0191	.0171	
8	.0171	.4954	.4572	.5144	.0171	
9	.0171	.5144	.4763	.5335	.0171	
10	.0171	.5144	.4954	.5335	.0171	
11	.0191	.4954	.4954	.4801	.0191	.0171
12	.0191	.4954	.4954	.4973	.0191	.0171
13	.0191	.4954	.4763	.4973	.0191	.0171
14	.0191	.4954	.4954	.4458	.0191	.0171
15	.0191	.4572	.4954	.4115	.0191	.0171
16	.0191	.0191	.0191	.0171	.0191	.0171
17	.0191	.0191	.0191	.0171	.0191	.0171
18	.0191	.0191	.0191	.0171	.0191	.0171
19	.0191	.0191	.0191	.0171	.0191	.0171
20	.0191	.0191	.0191	.0171	.0191	.0171
21	.0191	.0191	.0191	.3944	.4572	.3429
22	.0191	.0191	.0191	.3944	.4763	.3258
23	.0191	.0191	.0191	.3944	.4954	.3258
24	.2915	.0191	.0191	.0191	.3944	
Max	.2915	.5144	.4954	.5335	.4954	.3429
Min	.0171	.0191	.0191	.0171	.0171	.0171
Avg	.0954	.1779	.1747	.2223	.1797	.0897

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214521 / 33/11KV SHINGAVE

Feeder No / Name : 203 / 11KV SHINGAVE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.6668	.6478	.6478		
2	.2401	.6859	.6668	.6478		
3	.2401	.724	.6859	.6668	.3429	
4	.2743	.7621	.724	.6859	.3429	
5	.3086	.8192	.7621	.6859	.3772	
6	.3429	.4572	.8192	.724	.4115	
7	.4458	.5716	.4572	.4572	.4801	
8	.9945		.4572	.4954	1.0631	
9	1.0974	.5335	.4572	.5335	1.166	
10	1.2003	.4954	.4382	.4954	1.2689	
11	1.1431	.4572	.4572	.4458	1.3717	1.4403
12	1.0669	.362	.4382	.4115	1.3336	1.3375
13	1.0098	.362	.4382	.3772	1.2955	1.2346
14	.9526	.381	.4001	.3772		1.0631
15	.2096	.381	.3429	.3429	1.105	.9602
16	.2286	.3429	.381	.3429	.3048	.4115
17	.2667	.3429	.4191	.3429	.362	.3772
18	.2858	.3429	.4382	.3772	.4191	.3772
19	.3239	.3429	.4572	.4115	.4572	.3772
20	.3429	.3429	.4572	.4115	.4382	.3772
21	.5716	.6478	.6859	.3429	.381	.3429
22	.6287		.7049	.3429	.3429	.3429
23	.6668	.6478	.6859	.3429	.3239	.3429
24	.2401	.6478	.6478	.6478		
Max	1.2003	.8192	.8192	.724	1.3717	1.4403
Min	.2096	.3429	.3429	.3429	.3048	.3429
Avg	.5551	.5144	.5446	.4815	.6794	.6911

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214521 / 33/11KV SHINGAVE

Feeder No / Name : 204 / 11KV WADI MALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.3239	.3239	.3429	.0686	
2	.0686	.3239	.3239	.3429	.0686	
3	.0686	.3429	.3429	.3429	.0686	
4	.0686	.3429	.3429	.362	.0686	
5	.0686	.362	.362		.0686	
6	.0686	.4001	.4001	.381	.0686	
7	.0686	.1334	.1334	.1905	.0686	
8	.2572	.1905	.1334	.1715	.4287	
9	.3086	.1524	.1143	.1524	.4801	
10	.3601		.1143	.1524	.5316	
11	.4954	.1143	.1524	.1372	.5716	.5487
12	.4763	.1143	.1524	.12	.5335	.5487
13	.4572	.1143	.1524	.12	.5144	.5144
14	.4191	.1143	.1524	.1029		.463
15	.0572	.1143	.1524	.0686	.4763	.3944
16	.0762	.1524	.1524	.0686	.1143	.0686
17	.0953	.0191	.1524	.0686	.1334	.0686
18	.0953	.0191	.1524	.0686	.1524	.0686
19	.1143	.1524	.1524	.0686	.1715	.0686
20	.1334	.1524	.1715	.0686	.1524	.0686
21	.2858	.3429	.4001	.0686	.1334	.0686
22	.3239	.3239	.4191	.0686	.1143	.0686
23	.3429	.3239	.4001	.0686	.0953	.0686
24	.0686	.3048	.3048	.381	.0686	
Max	.4954	.4001	.4191	.381	.5716	.5487
Min	.0572	.0191	.1143	.0686	.0686	.0686
Avg	.2020	.2145	.2358	.1703	.224	.2322

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214521 / 33/11KV SHINGAVE

Feeder No / Name : 205 / 11KV BHAGDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.0953	.0953	.1143	.1715	
2	.2915	.0762	.0762	.1143	.2058	
3	.2915	.0762	.0762	.1143	.2058	
4	.3086	.0953	.0953	.1143	.2401	
5	.3258	.0953	.1143	.1143	.2401	
6	.3429	.1143	.1334	.1524	.2572	
7	.2229	.1334	.1334	.1905	.1886	
8	.2401	.5144	.4001	.4763	.2401	
9	.2401	.5335	.4191	.4954	.2743	
10	.3086	.5335	.4382	.4954	.2915	
11	.3239	.4572	.4572	.4458	.3048	.2401
12	.3048	.4382	.5144	.4458	.2858	.2058
13	.2858	.4191	.4954	.4115	.2858	.2058
14	.3239	.4191	.4382	.3772		.1715
15	.362	.381	.4001	.3772	.2858	.1886
16	.362	.1524	.1905	.1715	.2286	.2058
17	.381	.1524	.2096	.1715	.2477	.2229
18	.4001	.1715	.1905	.1715	.2667	.1886
19	.3429	.1715	.1905	.2058	.2477	.1715
20	.2858	.1715	.2286	.2058	.2286	.1543
21	.1905	.1524	.1905	.2229	.2667	.2401
22	.1334	.1524	.1143	.1715	.2858	.2229
23	.1143	.1143	.1143	.1715	.3048	.2229
24	.2572	.0953	.0953	.1143	.1715	
Max	.4001	.5335	.5144	.4954	.3048	.2401
Min	.1143	.0762	.0762	.1143	.1715	.1543
Avg	.2874	.2382	.2421	.2519	.2489	.2031

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214521 / 33/11KV SHINGAVE

Feeder No / Name : 206 / 11KV DATTA MANDIR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0802	.8573	.8573	.8573	.9945	
2	1.0974	.8192	.8192	.8573	.9945	
3	1.1145	.8002	.8002	.8764	.9945	
4	1.1145	.8002	.8002	.8764	1.0288	
5	1.1317	.8573	.8573	.9145	1.0631	
6	1.1317	.9145	.8764	.9526	1.0974	
7	.9259	.9526	.9145	1.0098	.8745	
8	.8573	1.6004	1.4289	1.6385	.8573	
9	.7888	1.6004	1.448	1.6575	.8402	
10	.7716	1.6194	1.448	1.6766	.7888	
11	.8573	1.5242	1.467	1.406	.8573	.7888
12	.8573	1.467	1.448	1.3717	.8383	.7716
13	.8573	1.448	1.467	1.2689	.8192	.7545
14	.8573	1.3717	1.448	1.2689		.7545
15	.8573	1.2955	1.448	1.2003	.8383	.7373
16	.8954	.9145	.8764	.7716	.8764	.7716
17	.9526	.9145	.8573	.7716	.9145	.7716
18	.9907	.9145	.8764	.7888	.9526	.7716
19	1.0288	.9145	.9145	.8059	.9907	.7716
20	1.0098	.9145	.9145	.7888	.9526	.7888
21	.9717	.9145	.9145	.9774	1.1431	1.0117
22	.9335	.9145	.9145	.9945	1.1812	1.046
23	.9145	.8764	.8764	.9945	1.2193	1.0631
24	1.0802	.8764	.8764	.8764	.9945	
Max	1.1317	1.6194	1.467	1.6766	1.2193	1.0631
Min	.7716	.8002	.8002	.7716	.7888	.7373
Avg	.9616	1.0868	1.0645	1.0668	.9614	.8310

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214529 / 33/11KV LONI

Feeder No / Name : 201 / KHADAKWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772		.2195		.4108	.4854
2	.415		.2195		.4481	.4481
3	.3772		.2378		.4668	.3801
4	.3961		.2195		.5601	.5601
5	.5658		.2195		.6161	.7095
6	.5847		.2926		.5788	.6722
7	.6036		.2926		.4854	.4706
8		1.0608	.5853			.439
9		1.2071	1.0791			.439
10		1.1523				.4024
11		1.1523		.6935	.3734	
12		1.0608		.7802	.4481	
13	.5281	.9145		.7282	.4108	
14	.4904	.9511		.6762	.4481	
15	.4904	1.1523		.6935	.4481	
16	.4527	.5487		.4334	.4854	
17	.4904	.3658		.3641	.4481	
18	.4904	.2195		.3467	.4481	
19	.5281			.3467	.3982	
20	.5281	.2195		.3641	.3734	
21	.4904	.2378		.4854	.3982	
22	.4527	.2378		.4854	.4481	
23	.3772	.2195		.4161	.3734	
24	.3658	.3772	.3292		.4334	.3734
Max	.6036	1.2071	1.0791	.7802	.6161	.7095
Min	.3658	.2195	.2195	.3467	.3734	.3734
Avg	.4739	.6923	.3695	.5241	.4524	.4891

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214529 / 33/11KV LONI

Feeder No / Name : 202 / LONI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3292		.2614	.2835
2		.2804		.2801	.2481
3		.2804		.3361	.3189
4		.3506		.4108	.3721
5		.5014		.4294	.5316
6		.6089		.4854	.6024
7		.6447		.5975	.8505
8	.4161				.8859
9	.3658				.9922
10	.3467				.9214
11	.3467		.1829	1.1203	
12	.3294		.3292	1.1203	
13	.2947		.2561	1.0829	
14	.2774		.2926	1.0456	
15	.2774		.2743	1.0082	
16	.2427		.3292	.4481	
17			.2926	.4706	
18			.3658	.4481	
19	.3681		.4024	.4294	
20			.4755	.4854	
21	.3856		.3658	.4481	
22	.3155		.3292	.4481	
23	.3155		.3658	.3734	
24		.2804		.2743	.3361
Max	.4161	.6447	.4755	1.1203	.9922
Min	.2427	.2804	.1829	.2614	.2481
Avg	.3294	.4095	.3278	.5716	.5766

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214529 / 33/11KV LONI

Feeder No / Name : 203 / DHAMNI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3658		.4572	.439
2		.439		.439	.4024
3		.439		.4024	.3721
4		.3658		.439	.4961
5		.439		.5304	.5316
6		.6036		.695	.6733
7		.8505		.7316	.5316
8		.8238			.543
9		.8596			.5068
10		.8596			.4755
11		.7522	.6859	.4572	
12		.7522	.583	.439	
13	.4207	.7164	.6001	.4024	
14	.4508	.6805	.5487		
15	.4508	.5731	.6001	.3658	
16	.4161	.2328	.2572	.5487	
17	.3988		.2743	.5121	
18	.4508		.3086	.4755	
19	.4854		.3944	.567	
20	.5201		.4801	.6584	
21	.4854		.5144	.5121	
22	.4854		.4801	.5853	
23	.4161		.4458	.5487	
24	.4572	.3814		.4572	.5121
Max	.5201	.8596	.6859	.7316	.6733
Min	.3988	.2328	.2572	.3658	.3721
Avg	.4531	.5961	.4748	.5112	.4985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214529 / 33/11KV LONI

Feeder No / Name : 204 / SAHARA MILK

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0366	.0347		.0366	.0373
2	.0366	.0351		.0366	.0373
3	.0366	.0526		.0366	.0373
4	.0366	.0351		.0366	.0362
5	.0366	.0701		.0366	.0354
6	.0549	.0701		.0549	.0366
7	.0732	.0701		.0914	.0354
8		.112			.0724
9		.1075			.4252
10		.1075			.124
11		.0895	.1086	.128	
12		.1075	.0905	.1463	
13	.1463	.1075	.0724	.1646	
14	.1097	.0895	.0724	.1463	
15	.128	.0895	.0724	.1097	
16	.1463		.0543	.1097	
17	.1097		.0543	.1097	
18	.1097		.0362	.0732	
19	.128		.0362	.0732	
20	.1097		.0362	.0366	
21	.0549		.0362	.0366	
22	.0366		.0362	.0366	
23	.0366		.0362	.0366	
24	.0526	.0366		.0362	.0366
Max	.1463	.112	.1086	.1646	.4252
Min	.0366	.0347	.0362	.0362	.0354
Avg	.0779	.0759	.0571	.0749	.0831

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214538 / 33/11KV AWASARI

Feeder No / Name : 201 / TAVREWADI

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2284	.2641	.2075	.4527	.2083	.2263	.2263
2	.2094	.3395	.2054	.4904	.2075	.2641	.2263
3	.2094	.3772	.2427	.5281	.2641	.3395	.2075
4	.2665	.415	.3018	.5658	.3803	.3772	.2452
5	.4187	.5281	.415	.6036	.5704	.4715	.4338
6	.7233	.6224	.679	.6602	.7415	.5658	.679
7	.7218	.6296	.6413	.7356	.7014	.6979	.7167
8	.7408	.6635	.6979	.7167	.7014	.6413	.679
9	.5687	.4527	.5281	.6602	.6072	.4668	.5281
10	.4281	.3292	.4108	.5359	.4499	.4294	.4251
11	.2926	.3439	.4108	.4755	.3753	.3582	.3761
12	.2261	.2926	.3658	.3881	.362	.3326	.2279
13	.2087	.2926	.3582	.3182	.1433	.2957	.2507
14	.2417	.2896	.2715	.3213	.3109	.2561	.0253
15	.2395		.3544	.1945		.3045	.2328
16	.2646		.3292	.289	.2772	.3142	.2507
17	.2518	.2835	.3189	.2844	.3045	.3109	.3294
18	.3292	.3696	.4338	.3589	.4024	.3395	.3761
19	.4321	.5228	.5041	.5613		.4715	.5373
20	.4914	.5601	.5093	.5459		.5093	.5281
21	.473	.4715	.4904	.4527	.3045	.4338	.4904
22	.3395	.3772	.4527	.3795		.3772	.3584
23	.3018	.2263	.3772	.2841		.2829	.2829
24	.2284	.2263	.2263	.4904	.2651	.1886	.2452
Max	.7408	.6635	.6979	.7356	.7415	.6979	.7167
Min	.2087	.2263	.2054	.1945	.1433	.1886	.0253
Avg	.3681	.4035	.4055	.4705	.3988	.3856	.3699

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214538 / 33/11KV AWASARI

Feeder No / Name : 202 / GAWADEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4119	.394	.5316	.7888	.0571	.0362	.0377
2	.4119	.362	.3856	.815	.0566	.0543	.0377
3	.3932	.4075	.3856	.8505	.0565	.0716	.0566
4	.3932	.3898	.4075	.9214	.0749	.0709	.0716
5	.3721	.4382	.4075	.905	.0935	.1052	.0876
6	.3753	.4075	.4784	.9774	.126	.1227	.104
7	.16	.108	.1214	.128	.2981	.1254	.1214
8	.1278	.1097	.1075	.1267	1.1539	1.3395	1.166
9	.0921	.0895	.0886	.0846	1.3632	1.2548	1.3735
10	.0742	.0747	.0566	.0724	1.0022	1.3226	1.3717
11	.0761	.0739	.056	.0566	1.0923	1.3546	1.2309
12	.0554	.0732	.0747	.0377		1.1488	1.1096
13	.0569	.0554	.0566	.0566		1.1616	1.1919
14		.0566	.0709	.057		1.2003	1.0923
15		.0566	.0716	.0571		1.0402	.9114
16	.069		.0754	.0571		.0566	.0566
17	.0951	.0739	.0747	.0761		.0566	.0754
18	.0949	.0747	.0495	.0757		.0701	.0754
19	.0932	.1086	.0934	.1112		.0701	.0747
20	.0896	.1267	.0709	.1102		.1063	.0914
21	.3597	.5784	.5784	.1119		.0886	.0867
22	.6711	.8149	.7362	.0934		.0886	.0876
23	.6024	.6485	.7011	.0754		.0543	.0724
24	.394	.3721	.5784	.7362	.0754	.0366	.0566
Max	.6711	.8149	.7362	.9774	1.3632	1.3546	1.3735
Min	.0554	.0554	.0495	.0377	.0565	.0362	.0377
Avg	.2486	.2563	.2608	.3076	.4541	.4599	.4434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214538 / 33/11KV AWASARI

Feeder No / Name : 203 / BHAIKAVNATH

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0701	.0532	.0709	.1372	.4298	.4252	.3856
2	.0702	.0693	.0709	.1387	.394	.3814	.3898
3	.0709	.0693	.0701	.1734	.3961	.3988	.3506
4	.0871	.0857	.0876	.2058	.4961	.4382	.4784
5	.1395	.1017	.12	.2058	.5258	.4207	.5847
6	.2615	.1187	.2058	.2454	.6457	.5609	.6556
7	.3006	.1408	.2629	.2804	.2618	.208	.2774
8	1.117	1.0288	1.1443	1.2136	.2427	.2303	.2058
9	1.2228	1.166	1.2445	1.3375	.192	.1578	.208
10	1.2587	.9991	1.335	1.3523	.1653	.1063	.1433
11	1.2242	1.1744	1.1096	1.3321	.1283	.1294	.1254
12	1.2216	1.1218	1.0277	1.2851	.0754	.1063	.0905
13	1.1531	1.1694	1.0631	1.2976		.0934	.1075
14	1.075	1.0985	1.1218	1.0409		.0924	.1928
15	1.1072		1.0517	.8352		.1132	.0747
16	.1127		.0924	.0758		.1509	.0943
17	.1101	.1109	.112	.1123		.1646	.132
18	.1109	.1478	.128	.112		.1848	.1494
19	.1079	.1949	.2126	.2199		.2378	.1629
20	.088	.2328	.2126	.1976		.1753	.1734
21	.0877	.1791	.1734	.6135		.691	.5609
22	.0686	.1402	.1578	.5155		.7164	.6485
23		.1227	.0686	.4321		.5552	.5258
24	.0873	.0549	.0876	.1543	.4321	.4656	.4031
Max	1.2587	1.1744	1.335	1.3523	.6457	.7164	.6556
Min	.0686	.0532	.0686	.0758	.0754	.0924	.0747
Avg	.4849	.4355	.4680	.5631	.3373	.3002	.2967

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214411 / 33/11KV S/S SHIROLI

Feeder No / Name : 201 / BORI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4338	1.6004	1.4217	1.2346	.3961	.4527	.5093
2	.4338	1.6004	1.4217	1.2346	.3961	.4527	.4904
3	.4338	1.6004	1.4217	1.25	.3961	.4527	.5281
4	.5281	1.6356	1.4373	1.3125	.4715	.4904	.547
5	.6036	1.6518	1.5043	1.3599	.5847	.5658	.6036
6	.7095	1.7695	1.5729	1.4685	.6722	.6979	.6908
7	.8865	.7922	.7922	.7922	.8488	.8865	.7733
8	2.4939	.7545	.7733	.7356	2.4577	2.8509	2.6216
9	2.6871	.7167	.6979	.6036	2.7199	2.9835	2.8664
10	2.8837	.6413	.5847	.6036	2.9338	2.9172	2.8664
11	2.9504	.6602	.5847	.5281	3.1161	2.9338	2.7362
12	2.8346	.679	.5601	.5335	3.0001	2.7846	2.6379
13	2.7368		.6413	.4715	2.9635	2.753	2.6086
14	2.6086			.5093	2.4646	2.672	2.5587
15	2.2653	.6413	.6224	.547	2.5911	2.6235	2.5587
16	.5658	.7621	.5243	.6413	.6478	.5658	.6478
17	.5335	.724	.4973	.6287	.7545	.679	.7356
18	.5658	.6979	.4586	.6668	.7545	.679	.743
19	.6859	.7545	.4321	.6979	.7922	.7922	.811
20	.7167	.7922	.3605	.679	.7922	.8573	.8676
21	1.7814	1.4706	1.4922	.6224	.6979	.5658	.7356
22	1.8138	1.4706	1.5089	.5847	.6413	.547	.679
23	1.6324	1.4706	1.5746	.4763	.5658	.5281	.5281
24	.4338	1.6004	1.4217	1.2346	.3961	.4527	.5281
Max	2.9504	1.7695	1.5746	1.4685	3.1161	2.9835	2.8664
Min	.4338	.6413	.3605	.4715	.3961	.4527	.4904
Avg	1.4258	1.1130	.9698	.8090	1.3356	1.3410	1.3280

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214411 / 33/11KV S/S SHIROLI

Feeder No / Name : 202 / SALWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8488	.4212	.4527	.4715	.9431	.9795	1.0082
2	.8488	.4212	.4527	.4715	.9431	.9795	.9709
3	.8488	.4212	.4715	.4715	.9431	.9795	1.0269
4	.9054	.4858	.5201	.5135	.9709	.9795	1.0456
5	.9808	.5001	.5792	.5201	1.0829	.9979	1.0642
6	1.0751	.6173	.664	.6478	1.1949	1.0164	1.1203
7	.6562	.7712	.8215	.7888	.664	.6964	.6642
8	.7602	1.5546	1.8804	1.773	.8063	.8238	.8316
9	.5792	1.6297	2.0157	2.1616	.9412	.9671	.961
10	.7202	1.6476	2.0858	2.0908	.9412	1.0317	.924
11	.8328	1.8625	2.0553	1.9667	.8238	1.0719	.9412
12	.8505	1.9004	2.167	1.825	.8413	.9795	.8869
13	.905		2.1085	1.7364	.924	.961	.7619
14	.8869		2.0332	1.825	.9522	.924	.8688
15	.8869	1.5043	1.9806	1.7718	.9145	.9055	.9328
16	1.0164	.7537	.7964	.8145	.9328	.9055	.9979
17	1.0534	.6173	.8507	.8507	.8954	.9055	1.0349
18	1.0164	.8063	.8326	.7537	.8688	.9055	.9795
19	.7888	.6661	.815	.7373	.8238	.7537	.8326
20	.6882	.7373	.7628	.788	.6984	.6952	.6539
21	.6241	.639	.6952	1.1016	1.1203	1.1273	
22	.5001	.5487	.5182	1.0829	1.0608	1.1203	.961
23	.4085	.4858	.4778	.9896	1.0059	1.0269	.9335
24	.8865	.4212	.4527	.4715	.9431	.9795	1.0082
Max	1.0751	1.9004	2.167	2.1616	1.1949	1.1273	1.1203
Min	.4085	.4212	.4527	.4715	.664	.6952	.6539
Avg	.8153	.8824	1.1037	1.1094	.9265	.9464	.9309

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214411 / 33/11KV S/S SHIROLI

Feeder No / Name : 203 / AURANGPUR PARGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	1.004	.9488	.8855	.2427	.3142	.3174
2	.2614	1.004	.9488	.8855	.2427	.3142	.2987
3	.2614	1.004	.9488	.8855	.2427	.3142	.3361
4	.2987	1.0322	.9804	.9393	.2801	.3511	.3734
5	.3584	1.0486	.9998	.9393	.3361	.4108	.4527
6	.4338	1.1603	1.0311	.9779	.415	.4904	.5093
7	.4668	.6348	.547		.5093	.5415	.5552
8	1.6244	.6161	.5415	.5415		1.8679	1.8515
9	1.6907	.567	.4805	.4435	2.1125	1.9334	1.9662
10	1.8564	.4938	.439	.499	2.0222	2.0553	1.9826
11	1.9784	.3841	.4755	.439	1.9725	2.2045	2.0719
12	1.8564	.3982	.3326	.439	2.0388	2.0153	2.1051
13	1.9559		.3696	.3761	1.7328	1.9498	1.8461
14	1.9062		.3801	.3761	1.9062	1.8351	2.0056
15	1.7166	.6588	.4435	.3761	1.989	1.7004	1.9725
16	.4119	.4477	.4163	.362	.3403	.4344	.3721
17	.462	.4525	.3658	.3982		.4344	.3761
18	.4207	.362	.4024	.4887	.4572	.5068	.3801
19	.6099	.3841	.5788	.4854	.5729	.5601	.5041
20	.5041	.4108	.4481	.4108	.5544	.5228	.4854
21	1.1469	1.0364	.9442	.3921	.4755	.439	.4481
22	1.1012	1.004	.9646	.3361	.362	.3658	.3734
23	1.0526	.9602	.933	.2614	.197	.3361	.3174
24	.2614	1.004	.9488	.9014	.2427	.3142	.3361
Max	1.9784	1.1603	1.0311	.9779	2.1125	2.2045	2.1051
Min	.2614	.362	.3326	.2614	.197	.3142	.2987
Avg	.9541	.7303	.6612	.5669	.8748	.9255	.9265

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214411 / 33/11KV S/S SHIROLI

Feeder No / Name : 204 / 11 KV Malwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	1.1843	1.1203	1.0595	.2477	.2829	.3206
2	.2829	1.1843	1.1203	1.0595	.2477	.2829	.3018
3	.2829	1.1984	1.1203	1.0753	.2477	.2829	.3395
4	.3584	1.2289	1.1961	1.1069	.3429	.3395	.4715
5	.4854	1.2452	1.3413	1.1843	.4904	.4338	.6036
6	.5975	1.4582	1.5769	1.3117	.6224	.6036	.6224
7	.8299	.8488	.7922	.7733	.7733	.7922	.7922
8	2.0645	.679	.547	.7545	2.0153	2.2672	2.4577
9	2.2186	.5658	.4904	.6036	2.1052	2.556	2.4291
10	2.3922	.5658	.4904	.5847	2.4086	2.6216	2.4129
11	2.2834	.4904	.5281	.4904	2.2939	2.5888	2.4249
12	2.1285	.547	.3584	.4715	2.2672		2.4129
13	2.0485		.3772	.4001	2.2085	2.3045	2.2929
14	1.9292			.3772	2.1125	2.5446	2.1822
15	1.6204	.4428	.4001	.4001	1.9766	2.4326	2.1605
16	.4715	.4954	.4191	.4382	.4001	.547	.4715
17	.4904	.5716	.4715	.4191	.4715	.5093	.4338
18	.5716	.5658	.4191	.5335	.5093	.5658	.5093
19	.6413	.5658	.547	.5093	.5658	.6036	.5658
20	.547	.5658	.5093	.4715	.5093	.5281	.5658
21	1.3765	1.3765	1.2793	.4715	.4527	.4715	.4904
22	1.3763	1.2803	1.2323	.3961	.3772	.3772	.3772
23	1.2793	1.1843	1.0883	.2858	.3018	.3395	.3239
24	.2858	1.1843	1.1203	1.0595	.2477	.2829	.3395
Max	2.3922	1.4582	1.5769	1.3117	2.4086	2.6216	2.4577
Min	.2829	.4428	.3584	.2858	.2477	.2829	.3018
Avg	1.1185	.8831	.8063	.6765	1.0081	1.0677	1.0959

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214411 / 33/11KV S/S SHIROLI

Feeder No / Name : 205 / 11 KV Nimgaon Sava

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5684	.3605	.3605	.3725	1.7604	1.7966	1.6356
2	1.5684	.3605	.3605	.3725	1.7604	1.7966	1.6356
3	1.6004	.3647	.3768	.8855	1.8244	1.7966	1.7814
4	1.7695	.4973	.4752	.57	1.9334	1.8591	1.8623
5	1.9616	.583	.6962	.6706	2.079	2.0405	1.9433
6	2.1874	.8987	.9389	.788	2.1963	2.2874	2.1628
7	1.0562	1.1305	1.0774	1.0608	1.0442	1.094	2.1628
8	.9442	3.083	3.408	3.6275		1.034	.8642
9	.6636	3.4818	3.6702	3.7894	.8223	.8488	.7526
10	.587		3.7521	3.7085	.602	.7316	.743
11	.4778	3.437	3.7193	3.7521	.5502	.5647	.5268
12	.4778	3.3684	3.5789	3.4494	.5716	.5234	.543
13	.5001		3.2388	3.2327	.612	.04	.5201
14	.4338			3.1847	.5563	.4668	.5146
15	.4334	2.7831		3.0567	.5007	.4801	.4664
16	.4468	.434	.4338	.3841	.4995	.4534	.4146
17	.5275	.5521	.5146	.4778	.514	.5868	.5357
18	.5487	.5761	.5213	.4715	.6401	.703	.5639
19	.7186	.6706	.7343	.6882	.7716	.7499	.6882
20	.7842	.7287	.6882	.664	.7125	.7432	.7362
21	.7042	.6962	.6464	2.0243	2.1464		2.0891
22	.5138	.5735	.5571	2.1052	2.0729		2.0405
23	.4144	.3932	.426	1.9044	2.0405		1.9433
24	1.6804	.3605	.3605	.3725	1.8084	1.7966	1.7814
Max	2.1874	3.4818	3.7521	3.7894	2.1963	2.2874	2.1628
Min	.4144	.3605	.3605	.3725	.4995	.04	.4146
Avg	.9403	1.2064	1.3880	1.7339	1.2182	1.0663	1.2045

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214411 / 33/11KV S/S SHIROLI

Feeder No / Name : 206 / 11kV Jadhavwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4144	.9922	.9414	1.012	.3601	.3658	.3696
2	.4144	.9922	.9414	1.012	.3681	.3658	.3511
3	.4144	.9922	.9762	1.012	.3681	.3658	.4066
4	.5609	1.0402	1.0322	1.1142	.5014	.421	.5359
5	.7499	1.1105	1.1233	1.2431	.7682	.6001	.5544
6	.9896	1.4403	1.5091	1.4413	.9335	.9055	.9055
7	1.0829	1.0903	1.0903	1.0903	1.0642	1.0903	.9313
8	2.5434	1.0164	1.0317	.9877	2.4417	2.7831	2.5101
9	2.8317	.7455	.7802	.8326	2.6658	3.0346	1.2308
10	2.7831	.4915	.6443	.6241	2.9675	3.1017	2.4086
11	3.0849	.4527	.4527	.5487	2.6322	3.1017	2.649
12	2.7664	.4218	.5138	.4752	.2012	2.9172	2.5857
13	2.6023		.5426	.4012	2.7999	2.9007	2.5857
14	2.6023		.5426	.3286	2.7349	2.9007	2.6355
15	2.3205	.431	.567		2.5857	2.6852	2.3537
16	.5121	.4843	.4801	.3658	.3795	.4641	.5281
17	.503	.4527	.5765	.4111	.4641	.4578	.5533
18	.3601	.5087	.6935	.421	.695	.6274	.6274
19	.8688	.6805	.8962	.823	.8954	.8688	.9328
20		.8413	.961	.8871	.9955	.9425	.9328
21	1.5261	1.4255	1.3916	.8029	.8316	.7947	.8779
22	1.3272	1.2955	1.2574	.543	.6516	.7947	.6068
23	1.1012	1.0595	1.0595	.4066	.3953	.4066	.3887
24	.4144	.9922	.9414	1.012	.3601	.3658	.3696
Max	3.0849	1.4403	1.5091	1.4413	2.9675	3.1017	2.649
Min	.3601	.4218	.4527	.3286	.2012	.3658	.3511
Avg	1.4250	.8617	.8728	.7737	1.2109	1.3859	1.2013

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214411 / 33/11KV S/S SHIROLI

Feeder No / Name : 207 / SHIROLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9907	.2658	.2279	.2303	1.1717	1.1431	1.1822
2	.9907	.2658	.2279	.2303	1.1717	1.1431	1.1336
3	.9907	.2658		.2303	1.1717	1.1431	1.1822
4	1.0623	.2896	.2507	.2534	1.2029	1.1736	1.2308
5	1.0936	.3077	.2926	.2715	1.2342	1.2041	1.1984
6	1.1405	.4066	.3696	.3511	1.2651	1.2654	1.2308
7	.4481	.4938	.4435	.4435	.4481	.4108	.4435
8	1.9022	1.6804	1.8976	1.8818	.4805	.5249	.5121
9	.4119	2.0873	.4111	2.1605	.4706	.5373	.5552
10		2.119	2.0241	2.1445	.5611	.6024	.4938
11	.5014	2.1605	2.0485	2.1125	.5175	.6024	.5014
12	.5552	2.0715	2.0153	2.0325	.5138	.5028	.5083
13	.567		2.1538	1.9372	.5028	.4854	.4508
14	.5434		2.0873	1.8976	.3856	.4681	.443
15	.5792	1.5123	2.1862	1.7901	.3856	.4334	.3898
16	.5731	.443	.5847	.394	.3721	.4334	.4557
17	.5611	.5316	.4835	.4252	.4607	.3801	.4784
18	.5316	.5493	.4938	.4252	.394	.3801	.4161
19	.5194	.5373	.4706	.4656	.4525	.3841	.4298
20	.4706	.543	.4572	.4163	.4525	.3696	.4607
21	.3801	.4163	.4207	1.2809	1.1873	1.247	1.1405
22	.3224	.3224	.2835	1.3125	1.2186	1.2146	1.1717
23	.2865	.2658		1.2498	1.2041	1.1984	1.1883
24	1.0059	.2658	.2279	.2303	1.2342	1.1431	1.166
Max	1.9022	2.1605	2.1862	2.1605	1.2651	1.2654	1.2308
Min	.2865	.2658	.2279	.2303	.3721	.3696	.3898
Avg	.7142	.8091	.9117	1.0070	.7691	.7663	.7651

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214411 / 33/11KV S/S SHIROLI

Feeder No / Name : 208 / SULTANPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5182	.128	.0926	.0739	.5247	.4904	.4858
2	.5182	.128	.0926	.0739	.5247	.4904	.5506
3	.5312	.128	.096	.0739	.5624	.4904	.502
4	.5468	.1294	.128	.0934	.5693	.4904	.5729
5	.578	.1294	.1509	.0943	.6009	.583	.502
6	.6009	.1848	.2054	.1494	.6241	.5636	.6478
7	.2054	.2427	.1646		.2241	.2075	.2149
8	.2801	.9762	1.1702	1.1069	.2427	.2926	.2772
9	.2926	1.0623	1.2334	1.2643	.3142	.3511	.2353
10	.2926	1.0936	1.2492	1.2163	.2402	.2926	.2743
11	.2378	1.2483	1.2803	1.2163	.2587	.2987	.2218
12	.2378	1.2018	1.1012	1.186	.2172	.2378	.2033
13	.2353		1.2163	1.1111	.2454	.2743	.2172
14	.2328		1.1092	1.0467	.2534	.2926	.1991
15	.2926		1.085	1.0031	.2328	.3109	.2534
16	.3403	.3439	.2686	.1791	.2715	.3292	.2865
17	.4024	.362	.3439	.2715	.2743	.3658	.3077
18	.3801	.4163	.3292	.2926	.2561	.3841	.3258
19	.3696	.3258	.2614	.1867	.2587	.3326	.2402
20	.2772	.2149	.2241	.2075	.2012	.2402	.2012
21	.1848	.1791	.1848	.7095	.5281	.5182	.4784
22	.1663	.3224	.1109	.6249	.503	.5668	.5401
23	.1463	.1075	.0739	.571	.5182	.583	.5639
24	.5487	.128	.1086	.0739	.5556	.5053	.5506
Max	.6009	1.2483	1.2803	1.2643	.6241	.583	.6478
Min	.1463	.1075	.0739	.0739	.2012	.2075	.1991
Avg	.3507	.4311	.5117	.5577	.3751	.3955	.3688

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214417 / 33/11 KV S/S GMRT KHODAD

Feeder No / Name : 201 / SOUTH -RANJANI-

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0747	.0754	.0747	.0754	.0747	.0754
2	.0747	.0747	.0747	.0754	.0747	.0754	.0754
3	.0747	.0747	.0754	.0754	.0754	.0754	.0754
4	.0747	.0747	.0747	.0747	.0747	.0754	.1886
5	.0747	.0747	.0747	.0747	.0754	.0754	.0754
6	.0747	.0747	.0747	.0754	.0754	.0747	.0754
7	.0747	.0747	.0754	.0747	.0747	.0754	.0754
8	.0747	.0747	.0762	.0747	.0739	.0754	.0747
9	.0747	.0754	.0747	.0747	.0747	.0747	.0747
10	.0747	.0747	.0747	.0754	.0754	.0754	.0754
11	.0747	.0754	.0747	.0747	.0747	.0754	.0747
12	.0747	.0754	.0747	.0754	.0747	.0754	.0739
13	.0747	.0747	.0747	.0747	.0747	.0732	.0754
14	.0747	.0747	.0747	.0754	.0747	.0754	.0747
15	.0747	.0754	.0747	.0747	.0754	.0747	.0747
16	.0747	.056	.0747	.0754	.0754	.0747	.0754
17	.0747	.0566	.0754	.0747	.0747	.0754	.0754
18	.0747		.0754	.0754	.0747	.0754	.0747
19	.0747	.0754	.0754	.0754	.0747	.0754	.0754
20	.0747	.0747	.0747	.0747	.0747	.0754	.0732
21	.0747	.0754	.0747	.0754	.0747	.0754	.0724
22	.0747	.0747	.0754	.0747	.0747	.0754	.0754
23	.0747	.0754	.0754	.0754	.0747	.0754	.0754
24	.0747	.0747	.1886	.0754	.0747	.0747	.0754
Max	.0747	.0754	.1886	.0754	.0754	.0754	.1886
Min	.0747	.056	.0747	.0747	.0739	.0732	.0724
Avg	.0747	.0733	.0797	.0751	.0749	.0751	.0797

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214417 / 33/11 KV S/S GMRT KHODAD

Feeder No / Name : 202 / WEST -NARAYANGAON-
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.056	.056	.056	.056	.0566
2	.0566	.0566	.0554	.056	.0554	.0554	.0566
3	.0566	.0566	.0549	.056	.0549	.0554	.0566
4	.0566	.0566	.0543	.056	.0543	.056	.0566
5	.0566	.0566	.0549	.056	.0549	.056	.0566
6	.0566	.0566	.0543	.056	.0554	.056	.0566
7	.0566	.0566	.0549	.056	.0549	.0554	.0566
8	.0566	.0566	.0457	.0566	.056	.056	.0566
9	.0566	.0566	.0566	.056	.0566	.056	.0566
10	.0566	.0543	.0566	.056	.0566	.0566	.0566
11	.0566	.056	.0566	.0566	.0566	.0566	.056
12	.0566	.0566	.0566	.056	.0566	.0566	.0566
13	.0566	.056	.0566	.0566	.056	.056	.0572
14	.0566	.056	.056	.0566	.0566	.056	.0566
15	.0566	.0566	.0566	.056	.056	.0566	.0554
16	.0566	.056	.0566	.0566	.0566	.0566	.0566
17	.0566	.0526	.056	.056	.056	.056	.0566
18	.0566		.056	.0566	.056	.0566	.0566
19	.0566	.0566	.056	.0566	.056	.0566	.0566
20	.0566	.056	.056	.056	.056	.0566	.056
21	.0566	.0566	.056	.056	.056	.0566	.0566
22	.0566	.056	.056	.0566	.056	.0566	.0572
23	.0566	.0566	.056	.056	.056	.0566	.0554
24	.0566	.0566	.0566	.056	.0566	.056	.0566
Max	.0566	.0566	.0566	.0566	.0566	.0566	.0572
Min	.0566	.0526	.0457	.056	.0543	.0554	.0554
Avg	.0566	.0562	.0555	.0562	.0559	.0562	.0565

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214417 / 33/11 KV S/S GMRT KHODAD

Feeder No / Name : 203 / EAST -BORI-

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0457	.056	.0549	.056	.056
2	.0566	.0566	.0554	.056	.0554	.056	.056
3	.0566	.0566	.0549	.056	.056	.056	.056
4	.0566	.0566	.0543	.056	.0554	.056	.056
5	.0566	.0566	.0543	.056	.056	.056	.056
6	.0566	.0566	.0537	.056	.056	.056	.056
7	.0566	.0566	.0526	.056	.0566	.056	.056
8	.0566	.0566	.0549	.056	.0566	.056	.056
9	.0566	.0566	.056	.056	.056	.056	.056
10	.0566	.0532	.056	.056	.056	.0566	.0554
11	.0566	.0549	.0566	.056	.056	.056	.056
12	.0566	.056	.056	.056	.056	.0566	.056
13	.0566	.056	.056	.0566	.056	.056	.056
14	.0566	.056	.056	.056	.056	.056	.0572
15	.0566	.0566	.056	.056	.056	.0554	.0566
16		.0566	.056	.0566	.056	.056	.0566
17	.0566	.0566	.056	.056	.056	.0566	.0566
18	.0566		.056	.0566	.056	.056	.0566
19	.0566	.056	.056	.056	.056	.056	.0554
20	.0566	.0566	.056	.0554	.056	.056	.0566
21	.0566	.056	.056	.056	.056	.056	.0572
22	.0566	.0566	.056	.0566	.056	.056	.0572
23	.0566	.056	.056	.056	.056	.056	.0549
24	.0566	.0566	.0566	.056	.0566	.056	.056
Max	.0566	.0566	.0566	.0566	.0566	.0566	.0572
Min	.0566	.0532	.0457	.0554	.0549	.0554	.0549
Avg	.0566	.0562	.0551	.0561	.0560	.0561	.0562

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214417 / 33/11 KV S/S GMRT KHODAD

Feeder No / Name : 205 / GMRT LOCAL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.1829	.1867	.1886	.1867	.1886
2	.1886	.1867	.1848	.1867	.1905	.1886	.1886
3	.1886	.1867	.1867	.1867	.1867	.1867	.1886
4	.1886	.1867	.1886	.1867	.1886	.1867	.1886
5	.1886	.1867	.1905	.1867	.1867	.1867	.1886
6	.1886	.1867	.1886	.1867	.1886	.1886	.1886
7	.1886	.1886	.1867	.1867	.1867	.1867	.1886
8	.1886	.1867	.1886	.1867	.1867	.1867	.1886
9	.1886	.1867	.1867	.1867	.1905	.1867	.1886
10	.1867	.1886	.1867	.1886	.1867	.1886	.1886
11	.1886	.1867	.1867	.1867	.1867	.1886	.1886
12	.1886	.1886	.1867	.1886	.1867	.1886	.1886
13	.1867	.1867	.1867	.1867	.1867	.1886	.1886
14	.1886	.1886	.1867	.1886	.1867	.1886	.1886
15	.1886	.1886	.1867	.1867	.1867	.1886	.1886
16	.1886	.1886	.1867	.1886	.1867	.1886	.1886
17	.1886	.1886	.1867	.1867		.1886	.1886
18	.1886		.1867	.1886	.1886	.1886	.1886
19	.1886	.1886	.1867	.1867	.1867	.1886	.1886
20	.1886	.1886	.1867	.1886	.1867	.1886	.1886
21	.1886	.1867	.1867	.1867	.1867	.1886	.1886
22	.1886	.1886	.1886	.1886	.1867	.1886	.1886
23	.1867	.1886	.1886	.1867	.1886	.1886	.1886
24	.1886	.1886	.1886	.1867	.1886	.1886	.1886
Max	.1886	.1886	.1905	.1886	.1905	.1886	.1886
Min	.1867	.1867	.1829	.1867	.1867	.1867	.1886
Avg	.1884	.1878	.1871	.1873	.1875	.1880	.1886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214434 / 33 KV KANDALI

Feeder No / Name : 201 / MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1663	.1174	.2263	.132	.1886	.1886	.1905
2	.1478	.1094	.1886	.1143	.1698	.1886	.168
3	.1463	.0983	.1698	.1524	.168	.1698	.1463
4	.1646	.1187	.1715	.1715	.1886	.168	.1509
5	.1829	.116	.2286	.1905	.2075	.1646	.2126
6	.2012	.125	.2858	.2286	.2075	.2075	.2172
7	.1829	.1646	.2987	.3361	.3239	.1991	.1928
8	.1402	.2452	.2829	.2667	.3584	.2241	.2667
9	.1772	.4207	.4066	.4251	.3772	.2858	.3206
10	.197	.567	.6697	.5493	.5304	.4904	.5249
11	.156	.724	.6516	.7023	.6283	.4904	.5304
12	.181	.7059		.6089	.6379	.4668	.5068
13		.5487	.5093	.5415	.4163	.4481	.4572
14		.7282	.6661	.5601	.5068	.4715	.4481
15	.1147	.5944	.7087	.7011	.543	.5792	.4706
16	.1629	.6859	.6135	.5138	.5304	.2829	.3258
17	.1311	.6068	.5228	.543	.4706	.3772	.3961
18	.1	.4119	.4294	.3772	.3772	.3018	.2667
19	.0926	.3475	.4066	.3326	.3361	.2641	.3048
20	.0814	.2829	.2801	.3206	.2641	.2286	.2452
21	.0934	.2427	.2241	.2263	.2054	.2667	.2286
22	.0934	.2075	.1886	.1715	.2054	.2286	.168
23	.1174	.2263	.1509	.1905	.1562	.1905	.1698
24	.1663	.1174	.2452	.132	.2075	.2075	.2096
Max	.2012	.7282	.7087	.7023	.6379	.5792	.5304
Min	.0814	.0983	.1509	.1143	.1562	.1646	.1463
Avg	.1453	.3547	.3707	.3537	.3419	.2954	.2966

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214434 / 33 KV KANDALI

Feeder No / Name : 202 / Nagadwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.9061	.9374	.9998	.2218	.2195	.2263
2	.1646	.9339	.9374	.9998	.2218	.1829	.2149
3	.168	.8488	1.0437	1.0155	.2427	.2587	.2126
4	.2241	.8907	1.0279	1.0279	.2614	.2614	.2378
5	.2614	1.0059	1.1523	1.0753	.2987	.3174	.3077
6	.3734	.9602	1.2146	1.1385	.3921	.4108	.4715
7	.4481	.4338	.4805	.4338	.462	.4668	.4668
8	1.7497	.4294	.439	.4294	2.0005	2.2245	2.0241
9	2.2245	.3696	.394	.3326	2.3482	2.4939	2.1925
10	2.2672	.3109	.3189	.3475	2.4453	2.3158	1.8185
11	2.0405	.2353	.2896	.2987	2.2834	2.2024	2.3805
12	2.0405	.2353		.2561	2.4939	2.1285	2.0325
13		.2303	.1791	.2561	2.2965	2.0399	2.0241
14		.2347	.1526	.2561	2.2497	1.9528	2.0805
15	1.5432	.213	.1543	.2195	2.0062	1.9919	2.0153
16	.1989	.2401	.2103	.2353	.2561	.2195	.2035
17	.1781	.1791	.2378	.2378	.2353	.2743	.2353
18	.2743	.2835	.3012	.2743	.2534	.2835	.2743
19	.2743	.3658	.362	.3511	.3658	.3881	.3734
20		.3258	.3658	.3696	.3658	.4066	.3881
21	1.0642	.9686	1.1111	.3142	.3511	.3326	.3361
22	.9556	1.0936	1.2191	.2987	.2957	.3018	.3142
23	.9724	1.0155	1.0648	.2614	.2587	.2715	.2772
24	.1829	.9061	.9646	.9907	.2402	.2402	.2427
Max	2.2672	1.0936	1.2191	1.1385	2.4939	2.4939	2.3805
Min	.1646	.1791	.1526	.2195	.2218	.1829	.2035
Avg	.8471	.5673	.6330	.5175	.9519	.9244	.8896

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214434 / 33 KV KANDALI

Feeder No / Name : 203 / kandali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.132	.132	.1509	.132	.132	.132
2	.132	.132	.132	.1509	.132	.132	.1132
3	.132	.1509	.1509	.1698	.132	.1509	.1132
4	.1509	.1698	.1509	.1886	.1509	.1698	.132
5	.1886	.1886	.1698	.2263	.1509	.1886	.1509
6	.2263	.2452	.1886	.2452	.1886	.2263	.1886
7	.2641	.2641	.2641	.2263	.2641	.2641	.2263
8	.3018	.2075	.1886	.1886	.2263	.2263	.2075
9	.2263	.1886	.1886	.1509	.1886	.1886	.1886
10	.1886	.1698	.132	.1509	.1698	.1509	.1132
11	.1698	.1698	.1132	.132	.1509	.132	.0943
12	.1509	.1509		.1132	.1509	.132	.0943
13		.1509	.1132	.0943	.1509	.132	.0943
14			.1132	.0943	.132	.132	.0754
15	.132	.1698	.132	.1132	.132	.132	.1132
16		.1698	.1132	.1132	.1698	.1509	.1132
17		.1886	.132	.1509	.1886	.1698	.1132
18		.2263	.1698	.1509	.2263	.1886	.1509
19	.1886	.2641	.1886	.2641	.2641	.2263	.1698
20	.2452	.2263	.2075	.2263	.2263	.2641	.1886
21	.2075	.1886	.2263	.1886	.1886	.2263	.2075
22	.1698	.1698	.2641	.1509	.1698	.1886	.1886
23	.1698	.132	.2075	.1509	.1509	.1509	.1698
24	.132	.1509	.132	.1698	.132	.132	.132
Max	.3018	.2641	.2641	.2641	.2641	.2641	.2263
Min	.132	.132	.1132	.0943	.132	.132	.0754
Avg	.1846	.1829	.1657	.1650	.1737	.1745	.1446

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214434 / 33 KV KANDALI

Feeder No / Name : 204 / Vaishakhed

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3005	.0377	.0351	.0343	.3749	.3749	.4049
2	.2812	.0377	.0351	.0343	.3437	.3637	.4024
3	.2812	.0377	.0366	.0347	.3437	.3637	.3681
4	.2812	.0358	.0366	.0347	.3593	.3637	.3437
5	.2846	.0366	.037	.0351	.3593	.3841	.3768
6	.2881	.037	.037	.0354	.3704	.4111	.4049
7	.0554	.0354	.0537	.0532	.037	.0549	.0366
8	.0537	.4961	.6249	.6249	.0554	.0351	.0351
9	.0543	.6219	.6019	.68	.0549	.0335	.0347
10	.0351	.5992	.6483	.68	.0549	.0377	.0351
11	.0358	.4858	.6964	.7045	.0549	.0358	.0362
12	.0362	.6401		.7045	.0549	.0358	.0354
13		.6173	.6962	.6882	.0549	.0316	.0354
14		.4816	.6722	.6882	.0332	.0335	.0354
15	.0351	.5609	.6562	.6642	.0301	.0328	.0343
16	.0354	.0301	.0532	.0316	.0335	.0324	.0339
17	.0358	.0328	.0532	.0343	.037	.032	.0351
18		.0332	.0335	.0347	.0293	.0335	.0351
19	.0358	.0335	.0332	.0354	.0351	.032	.0362
20	.0358	.0351	.0332	.0354	.0354	.032	.0543
21	.0366	.0351	.0335	.3593	.3795	.4696	.3239
22	.0377	.0354	.0335	.3593	.4001	.4862	.4167
23	.0358	.0351	.0332	.3593	.4001	.4641	.3963
24	.3005	.0373	.0354	.0332	.3749	.3795	.421
Max	.3005	.6401	.6964	.7045	.4001	.4862	.421
Min	.0351	.0301	.0332	.0316	.0293	.0316	.0339
Avg	.1227	.2112	.2265	.2908	.1794	.1897	.1821

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214456 / 33 KV SAWARGAON

Feeder No / Name : 201 / Wadgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9156	.2452	.2534	.2172	.7545	.7042	.639
2	.9156	.2641	.2481	.2172	.7716	.7122	.639
3	.9156	.3018	.2481	.2353	.7716	.763	.6554
4	.9326	.2743	.2658	.2715	.7888	.8059	.6718
5	.9496	.2915	.2835	.2896	.823	.8059	.6882
6	1.0576	.4115	.4031	.4163	.8402	.8745	.7209
7	.4287	.4477	.5014	.4706	.4287	.463	.4706
8	.4706	1.6297	1.5912	1.3927	.4458	.4458	.4887
9	.5093	1.8267	1.7901	1.5893	.4908	.4115	.5068
10	.5093	1.9342	1.8351	1.9204	.5434	.4887	.4887
11	.5281	1.643	1.8679	1.9022	.4904	.4525	.4706
12	.5093	1.861	1.8351	1.8473	.5093	.4163	.4525
13	.4904	1.8896	1.7859	1.7924	.5093	.4887	.4706
14	.547	.1509	1.8023	1.7193	.4338	.4525	.4525
15	.4904	1.8275	1.704	1.6461	.5093	.4163	.4163
16	.4904	.0476	.5068	.4973	.5281	.3982	.3439
17	.5093	.0572	.4706	.5144	.0553	.4163	.3801
18	.4904	.5658	.3439	.5304	.5093	.4344	.4251
19	.4904	.547	.3982	.4938	.5228	.4344	.4805
20	.4527	.5041	.3982		.462	.4163	.4251
21	.415	.4344	.4163	.9877	.7888	.639	
22	.3584	.3403	.3258	.9328	.7545		
23	.2829	.2534	.2353	.823	.7545	.6882	.7186
24	.9835	.2641	.2534	.2172	.7716	.7042	.6554
Max	1.0576	1.9342	1.8679	1.9204	.8402	.8745	.7209
Min	.2829	.0476	.2353	.2172	.0553	.3982	.3439
Avg	.6101	.7505	.8235	.9097	.5941	.5579	.5300

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214456 / 33 KV SAWARGAON

Feeder No / Name : 202 / Malganga

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.4359	.4096	.3441	.1829	.1132	.1086
2	.132	.4359	.4096	.3277	.2012	.1132	.1086
3	.132	.4527	.4096	.3441	.2012	.132	.1267
4	.1509	.4862	.421	.3605	.2012	.1509	.1448
5	.1698	.503	.421	.3768	.2195	.1509	.1629
6	.2452	.583	.5144	.426	.2743	.2012	.1991
7	.2452	.2743	.1949	.2534	.2926	.2402	.2353
8	.7293	.2572		.1629	.6882	.6154	.639
9	.9282	.2058	.1509	.1629	.7537	.7125	.7373
10	.9282	.2058	.181	.1991	.7701	.7537	
11	.9116	.2075	.1991	.1991	.8356	.7537	.7373
12	.9614	.1886	.1991	.2172	.7935	.7537	
13	.9779	.1698	.1629	.2172	.7362	.6554	.7701
14	.8642	.0152	.181	.2172	.7202	.6882	.7701
15	.8002	.0152	.1629	.1991	.7125	.639	.6226
16	.16	.2241	.1629	.2172	.1698	.181	.1802
17	.144	.2075	.1991	.1991	.1886	.1991	.1475
18	.192	.1509	.2172	.2378	.2033	.1991	.1677
19	.208	.1886	.1629	.2378	.0191	.181	.1715
20	.2347	.0191	.2172	.2378	.0171	.1991	.1543
21	.503	.431	.4424	.2195	.168	.1629	
22		.4862	.4752	.2195	.1509	.1448	.1372
23	.5197	.426	.3932	.2195	.1509	.1267	.12
24	.132	.4359	.4096	.3768	.2012	.1132	.1086
Max	.9779	.583	.5144	.426	.8356	.7537	.7701
Min	.132	.0152	.1509	.1629	.0171	.1132	.1086
Avg	.4522	.2919	.2912	.2572	.3688	.3408	.3119

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214456 / 33 KV SAWARGAON

Feeder No / Name : 203 / Sawargaon-Khilarwadi
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.5441	.5281	.4915	.112	.1307	.1267
2	.1698	.5601	.4961	.4915	.112	.1307	.1267
3	.1698	.5601	.5079	.4915	.112	.1307	.1448
4	.1886	.5761	.5243	.5079	.112	.1494	.1629
5	.2075	.5761		.5243	.1307	.1494	.1991
6	.2263	.6588	.6154	.6062	.1867	.2263	.2353
7	.2641	.2601	.0133	.2172	.197	.2075	.2534
8	.8848	.2254	.2075	.2172	1.182	.9488	1.0159
9	1.1142	.2427	.0171	.2353	1.2715	1.0402	1.0978
10	1.1469	.1734	.2172	.1991	1.2894	1.0814	1.1469
11	1.1633	.1509	.2534	.1867	1.1683	1.1142	1.1142
12	1.1305	.2075	.2172	.2054	1.1203	1.1469	
13	1.0814	.1698	.2172	.2054	1.186	1.0978	1.1142
14	1.1233	.1698	.1991	.2054	1.2003	1.1633	1.1142
15	1.073	.1698	.1991	.1867	.9717	1.0978	1.0486
16	.2012	.2263	.1991	.2054	.021	.1991	.1802
17	.218	.2829	.2353	.2241	.2075	.2172	.1966
18	.2187	.1886	.181	.2054	.1886	.181	.213
19	.2187	.0229	.2534	.2054	.2263	.2353	.2401
20		.0229	.2353	.1867	.021	.2353	.2229
21	.7842	.5636	.5407	.1867	.2075	.2353	
22	.8162	.695	.6718	.1494	.1698	.181	.1543
23	.5601	.6081	.6062	.1307	.1509	.1448	.12
24	.1698	.5601	.5601	.5571	.112	.1307	.1267
Max	1.1633	.695	.6718	.6062	1.2894	1.1633	1.1469
Min	.1698	.0229	.0133	.1307	.021	.1307	.12
Avg	.5783	.3506	.3346	.2926	.4857	.4823	.4707

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214459 / 33/11KV S/S UMBRAJ

Feeder No / Name : 201 / UMBRAJ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.3725	.3521	.2881	.1646	.1646	.2427
2	.2353	.3725	.3521	.3041	.1646	.1646	.2353
3	.2353	.3725	.3521	.3041	.1646	.1829	.2402
4	.2353	.3725	.3521	.3441	.1646	.2012	.2353
5	.2353	.3978	.3521	.3647	.1646	.2241	.2715
6	.3547	.4409	.407	.4144	.3018	.3018	.3292
7	.362	.3584	.3772	.3961	.3772	.3584	.3921
8	.6642	.3547	.3206	.5093	.6371	.8478	.7373
9	.852	.4108	.3696	.5093	.9175	.9556	.9831
10	1.0486	.3881	.3511	.4435	1.0486	1.0486	.9922
11	.9614	.4251	.3511	.4805	1.1305	1.094	1.0688
12	.8356	.4251	.3511	.4805	1.085	1.0814	1.0364
13	.8097	.4024	.3292	.4251	1.0364	1.0608	.933
14	.7935	.4024	.3258	.4251	.9646	.9339	.9014
15	.7362	.3258	.3258	.4251	.9488	.9014	.8802
16	.2303	.3439	.3439	.439	.4251	.3439	.2865
17	.2926	.3475	.3658	.4344	.4668	.3439	.2926
18	.2896	.3109	.3696	.4207	.4481	.3801	.2534
19	.3109	.3326	.3547	.4163	.415	.3439	.3109
20	.3174	.2987	.3361	.3841	.3961	.4294	.4066
21	.4858	.4372	.4475	.3326	.3734	.362	.3696
22	.4321	.4696	.3768	.2402	.2987	.3174	.3142
23	.4049	.4696	.3239	.2402	.2402	.2614	.2402
24	.2241	.3725	.3521	.3041	.1646	.1646	.2402
Max	1.0486	.4696	.4475	.5093	1.1305	1.094	1.0688
Min	.2218	.2987	.3206	.2402	.1646	.1646	.2353
Avg	.4820	.3835	.3558	.3886	.5208	.5195	.5080

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214459 / 33/11KV S/S UMBRAJ

Feeder No / Name : 202 / MAHALAXMI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3921	.6483	.68	.7116	.3403	.3077	.4108
2	.3921	.6483	.68	.7116	.3403	.3077	.3982
3	.3921	.6483	.68	.7274	.3403	.3475	.3982
4	.3841	.6562	.68	.7499	.3403	.3881	.3982
5	.4024	.7373	.68	.7968	.3403	.5041	.4887
6		.8987	.9665	.8642	.6535	.6535	.6516
7		.8029	.8215	.8215	.6722	.7655	.8507
8		.6468	.5914	.8215	1.2266	1.5424	1.3904
9	1.1633	.5847	.5304	.6653	1.3603	1.7072	1.4899
10	1.5238	.5373	.4119	.6335	1.6356	1.749	1.3279
11	1.3272	.591	.4119	.6154	1.7924	1.7166	1.3283
12	1.4746	.591	.4252	.6154	1.7604	1.6324	1.3283
13	1.5061	.7537	.4784	.5373	1.7124	1.6876	1.25
14	1.5043	.7537	.4961	.5373	1.6324	1.5466	1.25
15	1.3763	.5365	.5434	.5721	1.5497	1.6057	1.2498
16	.4359	.6203	.5434	.5658	.5609	.5041	.5426
17	.4334	.691	.5847	.5721	.5959	.5415	.5552
18	.4908	.6241	.6268	.6135	.6516	.567	.591
19	.591	.6268	.6697	.6379	.6767	.6348	.7133
20	.6335	.695	.7059	.6584	.7023	.6767	.7316
21	.852	.8583	.8907	.6036	.6283	.6722	.6767
22	.8192	.7449	.7842	.5121	.5487	.5304	.567
23	.7125	.7449	.7202	.5121	.439	.4344	.4572
24	.3841	.6483	.68	.6958	.3403	.3439	.3982
Max	1.5238	.8987	.9665	.8642	1.7924	1.749	1.4899
Min	.3841	.5365	.4119	.5121	.3403	.3077	.3982
Avg	.8186	.6787	.6368	.6563	.8684	.8903	.8102

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214459 / 33/11KV S/S UMBRAJ

Feeder No / Name : 203 / BELA PRADESHIK

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0949	.1174	.3277	.2105	.3163	.2294	.3113
2	.0995	.1174	.3277	.2105	.3163	.213	.3041
3	.0983	.1134	.3277	.2267	.3163	.2155	.3041
4	.096	.1174	.3277	.2294		.2294	.3125
5	.0655	.1187	.3277	.3391	.3163	.2294	.3163
6	.1147	.1357	.3561	.3353	.3441	.2785	.3201
7	.125	.1147	.3353	.3315	.3315	.2785	.3277
8	.0819	.116	.3353	.3315	.3521	.3814	.3125
9	.112	.1107	.3239	.3315	.3521	.3467	.3163
10	.1134	.0655	.3239	.3315	.3521	.3429	.3201
11	.124	.1147	.3277	.3277	.3521	.3277	.3353
12	.1227	.1147	.3277	.3277	.3481	.3277	.3353
13	.1227	.112	.3277	.3315	.3315	.3163	.3277
14	.1214	.112	.3239	.3315	.3315	.3163	.3277
15	.1214	.1027	.3239	.3315	.3315	.3125	.3277
16	.0021	.104	.2006	.1943	.2187	.1875	.1943
17	.0025	.0191	.0072	.0191	.0072	.0025	.0015
18		.0191	.0072	.0191	.0072		.0021
19		.0191	.0072	.0191	.0072		.003
20		.0112	.0072	.0118	.0072		.0044
21		.0191	.0072	.0147	.0029		.005
22		.0191	.0072	.0143	.0072		.004
23	.0716	.0191	.0072	.0143	.112		.0055
24	.0937	.1174	.1638	.112	.1739	.2105	.125
Max	.125	.1357	.3561	.3391	.3521	.3814	.3353
Min	.0021	.0112	.0072	.0118	.0029	.0025	.0015
Avg	.0939	.0846	.2233	.2061	.2276	.2637	.2143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214459 / 33/11KV S/S UMBRAJ

Feeder No / Name : 204 / Sondewadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2968	.168	.1494	.1646	.2343	.3041	.3113
2	.3041	.168	.1494	.1646	.2343	.3041	.2968
3	.3149	.168	.1494	.1646	.2343	.3005	.3041
4	.3113	.168	.1494	.1829	.2343	.3163	.3041
5	.3041	.2263	.1494	.2402	.2343	.3479	.3681
6	.4049	.3395	.3395	.3174	.3772	.3906	.4111
7	.3921	.4527	.4715	.3772	.415	.415	.4668
8	.3547	.7125	.759	.6554	.3961	.3961	.415
9	.3547	.7253	.7716	.5851	.2987	.3361	.2587
10	.2926	.8539	.7716	.6249	.2427	.2957	.2743
11	.2195	.8539	.7716	.6241	.2033	.2829	.2926
12	.2195	.8539	.7407	.6241	.2033	.2641	.2561
13	.2012	.6874	.6481	.5376	.2195	.2263	.2378
14	.2012	.6874	.6173	.5376	.2195	.2241	.2402
15	.181	.6097	.6019	.4064	.2378	1.8107	.2587
16	.1907	.1886	.2378	.1387	.2195	.2427	.2378
17	.1928	.2254	.2378	.1753	.2012	.3109	.2353
18	.2865	.2686	.2772	.1772	.2957	1.8111	.2715
19	.3475	.3511	.3174	.3258	.3326	.3475	.3258
20	.3696	.3881	.3361	.3696	.3734	.3982	.3734
21	.3361	.3174	.3174	.3481	.4049	.3932	.3401
22	.2427	.2614	.2241	.3201	.4049	.4096	.3321
23	.1867	.2614	.168	.3201	.3887	.3441	.3163
24	.3077	.168	.1494	.1646	.2343	.3201	.3185
Max	.4049	.8539	.7716	.6554	.415	1.8111	.4668
Min	.181	.168	.1494	.1387	.2012	.2241	.2353
Avg	.2839	.4210	.3960	.3561	.2850	.4497	.3103

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214459 / 33/11KV S/S UMBRAJ

Feeder No / Name : 205 / UMBRESHWAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	1.1389	1.1203	1.134	.3018	.2703	.3601
2	.2804	1.1389	1.1203	1.134	.3018	.2766	.3668
3	.3048	1.1389	1.1203	1.1523	.3018	.2766	.3334
4	.2561	1.1389	1.1203	1.2012	.3018	.298	.3801
5	.25	1.1883	1.1203	1.2696	.3647	.3334	.3734
6	.3067	1.226	1.2323	1.3443	.3567	.3467	.3772
7	.3807	.7356	.4681	.4681	.4561	.4089	.4649
8	1.7364	.4512	.5792	.5563	1.4449	1.5384	1.5565
9	1.9035	.4338	.5944	.5647	1.6834	1.6108	1.7193
10	1.9521	.4668	.6249	.5944	1.8804	1.773	1.8088
11	2.0237	.4668	.487	.5721	2.0237	2.0165	1.9342
12	1.9879	.4668	.4733	.5721	2.0058	2.0936	1.8983
13	1.9521	.4024	.4401	.487	1.9521	1.9185	1.825
14	1.9342	.4024	.4081	.487	1.9342	1.9022	1.7909
15	1.7372	.4146	.4016	.447	1.825	1.9231	1.773
16	.3048	.4311	.5005	.3839	.3709	.3414	.4275
17	.3109	.5007	.5285	.4275	.4081	.3628	.4405
18	.3772	.4793	.5357	.4801	.4146	.3934	.4468
19	.4134	.4778	.5502	.434	.4134	.4371	.4458
20	.4321	.4706	.4864	.4252	.4068	.4652	.4201
21	1.1389	1.1576	1.2012	.3692	.3734	.4512	.3134
22	1.1949	1.1763	1.2012	.3498	.3401	.3772	.285
23	1.1576	1.1763	1.2012	.3498	.3109	.3534	.2703
24	.2865	1.1389	1.1203	1.1523	.3018	.3018	.3467
Max	2.0237	1.226	1.2323	1.3443	2.0237	2.0936	1.9342
Min	.25	.4024	.4016	.3498	.3018	.2703	.2703
Avg	.9553	.7591	.7765	.6815	.8531	.8529	.8483

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214467 / 33 KV PARGAON MANGRUL

Feeder No / Name : 201 / Pimpri Kawal

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	1.4232	1.2498	1.7551	.2865	.3258	.3658
2	.2987	1.4232	1.2654	1.7193	.2865	.3077	.3658
3	.3361	1.4089	1.2809	1.7741	.3258	.3142	.3696
4	.3361	1.4413	1.2967	1.7364	.3258	.3511	.4066
5	.3734	1.4899	1.3279	1.7878	.3658	.4108	.4108
6	.4481	1.5223	1.3763	1.8427	.4481	.4668	.4854
7	.5415	.5601	.5228	.5975	.5975	.5788	.5228
8	2.13	.5729	.5415	.5975	1.9919	2.2119	2.2611
9	2.1879	.5487	.5792	.6283	2.4086	2.4577	2.2939
10	2.2119	.5373	.6447	.6154	2.5724	2.5526	2.2085
11	2.2447	.5316	.6767	.6447	2.5888	2.2996	2.5766
12	2.2775	.5895	.7095	.567	2.6216	2.4577	2.5393
13		.5895	.6908	.5609	2.5263	2.5232	2.5019
14	2.0485	.5895	.6447	.5493	2.556	2.5232	2.4832
15	1.9524	.3391	.5967	.5434	2.5232	2.5526	2.4832
16	.4801	.3429	.5243	.5028	.4382	.4024	
17	.4801	.4115	.4973	.5028	.5258	.439	
18	.4409	.3988	.4586	.463	.5658	.5121	
19	.5316	.3681	.4321	.5014	.5316	.5121	
20	.5552	.4572	.3605	.543	.5068	.5068	
21	1.5813	1.4089	1.4922	.4207	.4805	.362	
22	1.5339	1.3603	1.5089	.3801	.3982	.362	
23	1.5043	1.2651	1.5581	.3224	.3258	.3258	
24	.2987	1.439	1.2651	1.4918	.2865	.3258	.3292
Max	2.2775	1.5223	1.5581	1.8427	2.6216	2.5526	2.5766
Min	.2987	.3391	.3605	.3224	.2865	.3077	.3292
Avg	1.0909	.8758	.8959	.8770	1.1035	1.0867	1.4127

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214467 / 33 KV PARGAON MANGRUL

Feeder No / Name : 202 / MANGRUL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5312	.1612	.1595	.1463	.5247	.4999	.5312
2	.5312	.1463	.1402	.1478	.5312	.4744	.5312
3	.5624	.1463	.1402	.1772	.5312	.4744	.5247
4	.5761	.1848	.1791	.2149	.5601	.506	.5556
5	.6401	.2402	.2534	.3258	.5601	.5441	1.2346
6	.6722	.3395	.3584	.3841	.5735	.5761	.6173
7	.3584	.3921	.3734	.3921	.3734	.3772	.0943
8	.3018	.9122	1.0322	.9831	.2987	.3361	.3361
9	.2614	.9878	1.0242	1.0682	.3326	.3142	.3734
10	.2987	1.0595	1.0883	1.0814	.3841	.3696	.3696
11	.3475	1.0911	1.1271	1.0688	.362	.3258	.3734
12	.3258	1.0648	1.1401	1.0279	.3841	.3292	.3841
13	.2865	1.034	1.1361	1.0155	.3258	.3292	.3544
14	.3012	1.0311	1.1271	1.012	.3258	.3292	.3439
15	.3366	.9686	1.0688	.9217	.3292	.2926	.3258
16	.3121	.2058	.1943	.2149	.3439	.3292	
17	.3467	.2374	.2294	.2507	.3366	.3658	
18	.3429	.2804	.2683	.2835	.3258	.3658	
19	.362	.2658	.3018	.3841	.362	.3658	
20	.3475	.3142	.2743	.3326	.3511	.3658	
21	.2957	.2987	.2263	.5921	.6401	.4481	
22	.2218	.2614	.1829	.6009	.5851	.4801	
23	.1646	.1612	.1478	.5624	.5247	.4744	
24	.5155	.1612	.1612	.1463	.5093	.4938	.5121
Max	.6722	1.0911	1.1401	1.0814	.6401	.5761	1.2346
Min	.1646	.1463	.1402	.1463	.2987	.2926	.0943
Avg	.3850	.4977	.5139	.5556	.4323	.4070	.4664

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214467 / 33 KV PARGAON MANGRUL

Feeder No / Name : 203 / Pargaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5441	.112	.1086	.1063	.5487	.5335	.5487
2	.5441	.112	.1075	.1052	.5556	.5312	.5312
3	.5898	.1132	.1075	.1417	.5864	.5155	.5312
4	.5898	.1509	.1267	.7164	.6009	.5468	.5937
5	.6554	.1886	.1478	.2058	.6325	.5535	.6241
6	.7209	.2075	.1698	.2401	.6722	.5851	.6241
7	.3734	.1867	.1886	.3018	.1698	.168	.1132
8	.3734	.8482	.9878	1.0159	.1848	.2033	.1829
9	.3734	.8642	.9014	1.094	.2715	.2561	.2195
10	.3142	.9061	.9842	1.1469	.3366	.2715	.2454
11	.2481	.8488	1.065	1.1069	.3582	.197	.3012
12	.2658	.7773	1.0774	1.0623	.3582	.2195	.3174
13	.2629	.7716	1.073	1.0364	.3155	.2195	.3018
14	.2601	.7499	1.1022	1.078	.3012	.2195	.2561
15	.2601	.8025	1.0279	1.034	.2534	.1991	.3077
16	.2401	.1928	.1802	.2012	.1928	.1867	
17	.2058	.1612	.2012	.2058	.1715	.1867	
18	.1886	.1928	.218	.2279	.1341	.1867	
19	.1991	.128	.2058	.1829	.1772	.1867	
20	.2033	.1848	.1928	.2218	.2012	.1494	
21	.1867	.1494	.181	.6009	.6019	.5312	
22	.1494	.1494	.1646	.6481	.5639	.5624	
23	.1307	.1097	.112	.6097	.5487	.5556	
24	.5441	.112	.1097	.1063	.5639	.5335	.5487
Max	.7209	.9061	1.1022	1.1469	.6722	.5851	.6241
Min	.1307	.1097	.1075	.1052	.1341	.1494	.1132
Avg	.3510	.3758	.4475	.5582	.3875	.3458	.3904

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214467 / 33 KV PARGAON MANGRUL

Feeder No / Name : 205 / 11 KV RAMWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18
HR	Load (MW)
1	.4268
2	.4572
3	.4572
4	.4999
5	.5312
6	.6249
7	.2241
8	.2561
9	.2926
10	.2896
11	.2865
12	.2865
24	.4268
Max	.6249
Min	.2241
Avg	.3892

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214467 / 33 KV PARGAON MANGRUL

Feeder No / Name : 206 / 11 KV ZAPWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6249	.216	.1372		.9783	.9602	1.0623
2	.6562	.216	.1372		.9783	.9686	1.0623
3	.6562	.2056	.1562		.9755	.9488	1.0936
4	.7682	.2713	.1581		.9877	.9962	1.1523
5	.8002	.3944	.2591		1.012	1.0595	1.2483
6	.8002	.5548	.4287		1.0202	1.1385	1.3435
7	.2481	.663	.4191			.6796	.5636
8	.2743	1.7004		1.9826	.4938	.6249	.5335
9	.2469	1.9757	1.9134	1.9826	.6099	.5792	.5335
10	.2439	1.8501	1.8435	2.1032	.459	.5144	.4599
11	.1715	1.7223	1.8884	2.1125	.5144	.4212	.4664
12	.1858	1.7981	1.9616	1.7747	.4275	.6219	.6348
13		1.7833	2.1472	1.7071	.4024	.6219	.5182
14		1.7528	2.0416	1.6358	.4755	.6219	.5407
15	.2949	1.6707	1.8084	1.4632	.543	.6335	.5658
16	.2949	.1734	.2152	.3467	.6024	.4915	
17	.2896	.2347	.2321	.3086	.5959	.4915	
18	.2715	.2263	.3258	.2401	.5533	.4588	
19	.381	.301	.3801	.333	.5087	.4588	
20	.4115	.3201	.4252	.3048	.4064	.3395	
21	.3841	.2881		1.0936	1.0311	.9145	
22	.3125	.2315	.3761	1.0822	1.0155	1.0059	
23	.2134	.1372	.2614	1.0517	.9602	1.0059	
24	.6249	.2107	.1372		1.0084	.9482	1.0059
Max	.8002	1.9757	2.1472	2.1125	1.0311	1.1385	1.3435
Min	.1715	.1372	.1372	.2401	.4024	.3395	.4599
Avg	.4161	.7874	.8024	1.2202	.7200	.7294	.7990

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214480 / Kandali Village

Feeder No / Name : 201 / Vadgaon (Kandali)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0608	.3174	.4668	.439	1.0562	.9503	.9945
2	1.0608	.2957	.4668	.4251	1.0513	.9503	.9945
3	1.0608	.2957	.4668	.4066	1.0513	.9231	.9945
4	1.0774	.3326	.4854	.4854	1.0682	.9717	1.0277
5	1.0774	.3475	.5041	.5415	1.0852	1.004	1.0608
6	1.0774	.462	.5228	.5788	1.1191	1.0526	1.094
7	.4641	.5788	.5601	.5788	.6036	.5121	.5975
8	.5788	1.5893	1.9062	1.8399	.679	.6348	.6722
9	.5975	1.9498	2.0056	2.0719	.9149	.7023	.7468
10	.6348	2.0056	2.1382	2.1879	.8962	.8131	.8686
11	.5729	2.1382	1.989	2.1963	.9145	.9055	.8402
12	.5729	2.2542	2.1365		1.0317	.924	.8402
13		2.13	2.1963	2.0885	1.0608	.924	.9149
14		1.6385	2.1293	2.0719	.9709	.9425	.9055
15	.7207	1.7859	1.8461	1.989	.8871	.961	.905
16	.8131	.7682	.8688	.6796	.8413	.8871	.905
17	1.8111	.8048	.8145	.7499	.8316	.8131	.8962
18	.7392	.823	.8596	.7133	.8501	.7392	.8779
19	.7023	.6036	.7783	.7316	.7095	.6653	.6584
20	.5601	.5853	.6516	.6838	.6468	.6838	.5792
21	.4854	.5415	.5973	1.2071	1.0442	.9945	.9069
22	.4668	.5041	.499	1.1401	1.065	.9779	.9069
23	.3734	.4668	.4572	1.1065	.9831	.9779	.8907
24	1.0442	.3142	.4481	.439	1.0562	.9503	.9614
Max	1.8111	2.2542	2.1963	2.1963	1.1191	1.0526	1.094
Min	.3734	.2957	.4481	.4066	.6036	.5121	.5792
Avg	.7978	.9805	1.0748	1.1022	.9341	.8692	.8766

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214480 / Kandali Village

Feeder No / Name : 202 / Abhangwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4862	1.073	1.2071	.9665	.3052	.373	.5197
2	.4862	1.073	1.2071	.9496	.3052	.373	.5197
3	.4807	1.0898	1.2071	.9496	.3052	.373	.5197
4	.4973	1.1065	1.2407	.9835	.3391	.39	.5365
5		1.1233	1.2742	1.0174	.39	.4239	.5533
6		1.1233	1.3077	1.0513	.4578	.4917	.57
7		.4191	.503	.5426	.4917	.5426	.6036
8		.4527	.547	.5087	1.4752	1.8821	1.8107
9		.57	.6203	.4748	1.8652	1.95	1.9616
10	1.3077	.6036	.6613	.4748	1.9784	2.079	1.9839
11	1.643	.6371	.39	.4748	2.1125	2.2298	1.9669
12	1.8442		.4239	.4748	2.0119	2.1795	1.9669
13		.6706	.373	.5256	2.0287	2.1125	1.95
14			.2883	.5596	1.8945	2.079	1.95
15	1.7436	.4024	.4578	.5256	1.9281	2.0454	1.8313
16	.5365	.4191	.373	.5426	.6706	.6706	.6104
17	.5365	.4359	.3391	.5426	.6203	.7023	.5765
18	.5533	.4527	.4578	.5765	.5868	.6036	.5765
19	.503	.4862	.4578	.6274	.57	.6036	.5256
20	.4527	.5197	.4578	.5596	.5256	.5868	.5087
21	1.1904	1.2071	1.0513	.4917	.5087	.5533	.4578
22	1.1568	1.1904	1.0513	.4239	.4917	.5365	.373
23	1.1065	1.1736	1.0174	.373	.4239	.5197	.3561
24	.4694	1.0898	1.1736	.9835	.3391	.39	.503
Max	1.8442	1.2071	1.3077	1.0513	2.1125	2.2298	1.9839
Min	.4527	.4024	.2883	.373	.3052	.373	.3561
Avg	.882	.7872	.7537	.65	.9427	1.0288	.9888

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214480 / Kandali Village

Feeder No / Name : 203 / GFSS Vadgaon Gaonthan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	11-FEB-18
HR	Load (MW)
24	.0018
Max	.0018
Min	.0018
Avg	.0018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214481 / 33/11 KV Yedgaon

Feeder No / Name : 201 / Shri Ganesh

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1006	.4862	.3688	.3353	.1341	.1174	.1341
2	.1006	.4862	.3688	.3353	.1341	.1174	.1341
3	.1006	.4862	.3856	.3353	.1509	.1341	.1341
4	.1174	.503	.3856	.3521	.1509	.1341	.1509
5	.1174	.503	.4024	.3688	.1677	.1509	.1844
6	.1174	.5197	.4024	.3856	.1844	.1509	.2012
7	.1543	.1509	.1677	.1844	.1844	.1174	.218
8	.5868	.218	.1844	.1844	.7377	.7377	.6371
9	.6706	.218	.2347	.1677	.7545	.8048	.6874
10	.7712	.218	.2683	.1341	.7545	.8215	.6874
11	.7712	.2012	.2683	.1341	.788	.7712	.6874
12	.788		.2683	.1341	.8215	.7545	.6706
13		.1341	.2347	.1341	.8383	.7377	.6706
14		.1174	.218	.1509	.8215	.7209	.6539
15	.6371	.1174	.1844	.1509	.8048	.7042	.6371
16	.1006	.1006	.1844	.1509	.1509	.218	.2012
17	.1174	.1677	.1844	.1509	.1341	.2515	.2012
18	.1341	.1844	.1844	.1677	.1341	.218	.2012
19	.1341	.1844	.1844	.1677	.1341	.218	.1844
20	.1341	.2012	.1677	.1677	.1174	.2012	.1844
21	.5197	.3688	.3521	.1341	.1174	.1844	.1677
22	.5197	.3856	.3521		.1174	.1677	.1341
23	.5197	.3856	.3353		.1174	.1509	.1006
24	.1006	.503	.3856	.3353	.1174	.1174	.1341
Max	.788	.5197	.4024	.3856	.8383	.8215	.6874
Min	.1006	.1006	.1677	.1341	.1174	.1174	.1006
Avg	.3324	.2974	.2780	.2164	.3570	.3626	.3332

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214481 / 33/11 KV Yedgaon

Feeder No / Name : 202 / Jay Malhar

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9717	.2321	.2429	.2818	1.1934	.9717	1.1105
2	.9555	.2321	.2429	.2818	1.1934	.9555	1.1105
3	.9393	.2321	.2429	.2818	1.1934	.9393	1.1105
4	.9393	.2486	.2753	.2984	1.1934	.9555	1.1271
5	.9555	.2486	.2915	.3315	1.1934	.9717	1.1768
6	.9555	.2652	.3077	.3647	1.1934	.9878	1.1934
7	.3077	.3315	.3401	.3978	.3978	.3401	.4475
8	.3725	1.6078	1.7652	1.9393	.4144	.4049	.4807
9	.3563	1.7976	1.9595	2.0687	.4641	.4858	.5138
10	.3563	1.8623	1.9109	1.9227	.4807	.4973	.5138
11	.431	1.8461	2.0222	1.7736	.4696	.5801	.4973
12	.4144	1.8461	2.0222	1.6409	.4534	.5304	.4973
13		1.7814	2.0222	1.5083	.4372	.4641	.4807
14		1.749	2.0056	1.4089	.4049	.431	.4475
15	.3647	1.6518	1.989	1.3592	.4049	.3978	.4144
16	.3978	.3887	.2984	.3315	.3563	.431	.4144
17	.3978	.4049	.3647	.3481	.3239	.4973	.3978
18	.4144	.421	.3647	.3647	.3239	.5138	.3978
19	.3978	.3725	.3812	.3978	.2915	.4641	.3812
20	.3315	.3077	.3812	.4144	.2591	.3978	.3647
21	.2652	.2591	.3481	1.21	.9717	1.0774	.9282
22	.2652		.3315		1.004	1.094	.9614
23	.2486	.2429	.2984		.9878	1.1105	
24	.9717	.2486	.2429	.2818	1.1934	.9717	1.1105
Max	.9717	1.8623	2.0222	2.0687	1.1934	1.1105	1.1934
Min	.2486	.2321	.2429	.2818	.2591	.3401	.3647
Avg	.5459	.8077	.8605	.8731	.7000	.6863	.6990

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214481 / 33/11 KV Yedgaon

Feeder No / Name : 203 / Yedeshwar

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258	.2204	.2401	.2374	.2713	.3258	.3391
2	.3086	.2229	.2743	.2374	.3052	.3429	.3391
3	.2915	.2229	.3086	.2374	.3391	.3429	.3391
4	.2915	.2401	.3086	.2543	.3391	.3772	.3561
5	.2743	.2572	.3429	.2883	.373	.3944	.373
6	.2743	.2743	.3601	.3222	.39	.4115	.39
7	.3772	.3429	.4287	.3561	.39	.4115	.373
8	.4287	.4801	.5144	.5426	.373	.3772	.3561
9	.3429	.6687	.703	.5935	.373	.3944	.3391
10	.3601	.7716	.7888	.6104	.3561	.4287	.3391
11	.3601	.7716	.8139	.6104	.3258	.4287	.3222
12	.3429	.7545	.8139	.5935	.3086	.4287	.3222
13		.6859	.7461	.5426	.2743	.4287	.3052
14		.6344	.6274	.4748	.2401	.4115	.2883
15	.3086	.6001	.5087	.4409	.2401	.4115	.2543
16	.2743	.2743	.2543	.3052	.2572	.3601	.2713
17	.3086	.3772	.3222	.3052	.2572	.3944	.2883
18	.3429	.4115	.3391	.3222	.2401	.3222	.3052
19	.3561	.3944	.3561	.3222	.2401	.3222	.3052
20	.3086	.3772	.3561	.3222	.2229	.3391	.3052
21	.2572	.3601	.3222	.3561	.3429	.3391	.3391
22	.2401	.2572	.2883		.3601	.3391	.3391
23	.2401	.2401	.2374		.3429	.3391	.3222
24	.3258	.2204	.2401	.2374	.2713	.3086	.3391
Max	.4287	.7716	.8139	.6104	.39	.4287	.39
Min	.2401	.2204	.2374	.2374	.2229	.3086	.2543
Avg	.3155	.4192	.4373	.3869	.3097	.3741	.3271

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214481 / 33/11 KV Yedgaon

Feeder No / Name : 204 / KANIFNATH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8059	.381	.3224	.3224	.7343	.788	.9134
2	.788	.3429	.3403	.3224	.7522	.8059	.9134
3	.7701	.3429	.3403	.3224	.8059	.8417	.9134
4	.7701	.362	.3582	.3582	.8238	.8596	.9313
5	.788	.4001	.3582	.394	.8596	.8596	.9492
6	.788	.4382	.3761	.4477	.8775	.8775	.9492
7		.5335	.3761	.3761	.5014	.5014	.4835
8		1.1622	1.1283	1.3253	.5014	.5014	.4835
9	.5373	1.3253	1.2894	1.4327	.4835	.5373	.4656
10	.4656	1.2536	1.4685	1.3969	.4835	.5716	.4656
11	.4191	1.2536	1.4685	1.3432	.4119	.5525	.5014
12	.4191	1.2536	1.4327	1.2894	.394	.5335	.5014
13		1.2536	1.3611	1.2178	.3403	.4954	.4656
14		1.2178	1.2536	1.1283	.3224	.4572	.4477
15	.2096	1.0924	1.0924	1.0924	.3224	.4001	.4298
16	.3429	.3224	.394	.4477	.3403	.4572	.4656
17	.4001	.3582	.4298	.4477	.3224	.4572	.5014
18	.4572	.3761	.4656	.4656	.3045	.3761	.5014
19	.4954	.3761	.4656	.4656	.3045	.394	.5014
20	.5335	.394	.4656	.4656	.3224	.4119	.5014
21	.5335	.394	.4298	.3761	.7164	.8775	.788
22	.4954	.3403	.394		.8596	.8954	.8238
23	.4572	.3224	.3403		.8238	.9134	.8417
24	.788	.4001	.3224	.3224	.6984	.788	.9134
Max	.8059	1.3253	1.4685	1.4327	.8775	.9134	.9492
Min	.2096	.3224	.3224	.3224	.3045	.3761	.4298
Avg	.5632	.6623	.6947	.7164	.5544	.6314	.6522

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214481 / 33/11 KV Yedgaon

Feeder No / Name : 205 / BHOLENATH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0537	.0191	.0179	.0179	.0716	.0537	.0895
2	.0537	.0191	.0179	.0179	.0716	.0537	.0895
3	.0537	.0191	.0179	.0179	.0537	.0537	.0895
4	.0537	.0191	.0179	.0179	.0537	.0716	.1075
5	.0537	.0191	.0179	.0179	.0537	.0716	.1075
6	.0537	.0191	.0179	.0179	.0537	.0716	.1075
7	.0179	.0191	.0179	.0179	.0179	.0179	.0179
8	.0179	.1492	.197	.1433	.0179	.0179	.0179
9	.0179	.2149	.2149	.1612	.0179	.0358	.0358
10	.0179	.2507	.2328	.1433	.0358	.0381	.0358
11	.0381	.2328	.2328	.1433	.0358	.0191	.0179
12	.0381	.2328	.2328	.1612	.0358	.0191	.0179
13		.2328	.2328		.0358	.0191	.0179
14		.2149	.2328	.1791	.0358	.0191	.0179
15	.0381	.2149	.2149	.1791	.0358	.0191	.0179
16	.0381	.0358	.0179	.0179	.0358	.0191	.0179
17	.0381	.0179	.0179	.0179	.0179	.0381	.0358
18	.0381	.0179	.0179	.0179	.0179	.0358	.0358
19	.0381	.0179	.0179	.0179	.0179	.0358	.0358
20	.0381	.0179	.0179	.0179	.0179	.0179	.0358
21	.0381	.0179	.0179	.0537	.0716	.0895	.1075
22	.0381	.0179	.0179		.0716	.0895	.1254
23	.0191	.0179	.0179		.0716	.0895	.1433
24	.0537	.0191	.0179	.0179	.0716	.0537	.0895
Max	.0537	.2507	.2328	.1791	.0716	.0895	.1433
Min	.0179	.0179	.0179	.0179	.0179	.0179	.0179
Avg	.0385	.0857	.0866	.0665	.0425	.0438	.0589

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214481 / 33/11 KV Yedgaon

Feeder No / Name : 206 / SHRI DATTA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.39	.9088	.7969	.8478	.4239	.4239	.3561
2	.39	.8848	.8309	.8478	.4748	.4578	.3561
3	.39	.8848	.8817	.8478	.5426	.4917	.3561
4	.407	.8848	.9156	.8648	.5935	.5087	.4239
5	.407	.9012	.9326	.8817	.6104	.5426	.5426
6	.407	.9012	.9326	.8987	.6274	.5596	.6274
7	.4917	.5898	.5596	.5426	.7291	.5935	.6104
8	1.2887	.5853	.5765	.5765	1.5261	1.5261	1.3565
9	1.4752	.5426	.6274	.6104	1.56	1.56	1.4752
10	1.5769	.567	.6104	.6274	1.56	1.5729	1.4752
11	1.1568	.5935	.6104	.6104	1.5091	1.6549	1.4752
12	1.1633	.6443	.5935	.6104	1.4582	1.6057	1.4243
13		.6104	.5426	.5935	1.4243	1.5402	1.3904
14		.5765	.4748	.5765	1.3904	1.4746	1.3395
15	1.1469	.5256	.407	.5596	1.3565	1.3927	1.2887
16	.4915	.5087	.4748	.5765	.5765	.4887	.4578
17	.567	.5087	.5087	.5935	.5087	.5973	.5087
18	.5853	.5256	.5426	.6104	.5087	.5765	.5426
19	.5365	.5087	.5426	.6104	.4748	.5426	.5256
20	.5197	.5087	.5426	.6104	.4578	.5087	.5256
21	.9511	.8817	.9496	.5087	.4409	.4748	.4578
22	.852	.8478	.8987		.407	.4239	.407
23	.852	.8139	.8478		.407	.373	.3222
24	.407	.8684	.78	.8478	.373	.39	.3561
Max	1.5769	.9088	.9496	.8987	1.56	1.6549	1.4752
Min	.39	.5087	.407	.5087	.373	.373	.3222
Avg	.7478	.6905	.6825	.6752	.8309	.8450	.7750

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214515 / 33/11 KV Khodad

Feeder No / Name : 201 / 11 KV Amarwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1134	.583	.426	.4858	.1311	.0972	.1147
2	.1134	.5506	.4534	.4858	.1311	.081	.1147
3	.1296	.5506	.4858	.4534	.1475	.081	.1475
4	.1296	.5898	.5182	.5182	.1638	.0972	.1475
5	.1457	.6154	.6154	.5668	.1966	.1296	.1638
6	.1457	.6802	.6478	.6154	.1966	.1475	.1638
7	.1457	.1475	.1475	.1943	.1802	.1475	.1475
8	1.0526		.1638	.1943	1.1203	1.0688	1.3123
9	1.0526	.1966	.1638	.1781	1.3923	1.3117	1.4723
10	1.3765	.1966	.1475	.2429	1.4723	1.4089	1.4403
11		.1966	.2294	.2785	1.3765	1.3927	
12	1.3603			.2622	1.2308	1.3603	1.4089
13		.1966	.2267	.2294	1.2631	1.3443	
14	1.166		.2267	.1802		1.3123	1.247
15	1.247		.2105	.1802	1.2308	1.2803	1.247
16		.1966	.176	.1966	.1619	.1802	.213
17				.1966	.1475	.1966	
18	.1475		.1943	.1638	.1619	.2458	.2458
19	.1296	.1802	.1457	.1638	.1781	.2294	
20	.1475	.1638	.1296	.1475	.1134	.1966	.2458
21	.7125	.852	.5121	.1475	.1134	.1638	
22	.1296		.5668	.1311	.0972	.1311	
23	.1296		.5344	.1475	.0972	.1147	
24	.1296	.6316	.421	.5182	.1475	.0972	.1311
Max	1.3765	.852	.6478	.6154	1.4723	1.4089	1.4723
Min	.1134	.1475	.1296	.1311	.0972	.081	.1147
Avg	.4852	.4080	.3337	.2866	.4979	.5340	.5861

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214515 / 33/11 KV Khodad

Feeder No / Name : 202 / 11 KV JAGDAMBA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1619	.4858	.4588	.4534	.1638	.2267	.1475
2	.1457	.4534	.421	.4049	.1638	.1943	.1638
3	.1457	.421	.421	.3563	.1802	.1781	.1638
4	.1619	.421	.4049	.426	.2294	.2267	.1966
5	.1943	.4534	.3887	.502	.2458	.2591	.2294
6	.2591	.4858	.3887	.5668	.2622	.3077	.2294
7	.3401	.3768	.3441	.3401	.2294		.2458
8	.9393		.3932	.4049	.8848	.8745	.8802
9	1.004	.3113	.3277	.3887	.9831	.8907	1.0242
10	1.0526	.2294	.2949	.3239	.9602	.8962	.9602
11		.2294	.3113	.3277	.9878	.8907	
12	.9717		.3077	.2949	.8583	.9282	.9717
13		.2294	.3077	.2622	.9555	.9602	
14	.7773		.2591	.2458	.7287	.9282	.9231
15	.7611		.3077	.2294	.8583	.8962	.9069
16		.3932	.2915	.2294	.2591	.2622	.1966
17			.2591	.2458	.2561	.2458	
18	.2622		.2915	.2622	.2915	.2622	.2458
19		.2949	.3077	.2949	.3563	.2622	
20	.2458	.2591	.2753	.3277	.3401	.2458	.2458
21	.5344	.7209	.5668	.2949	.2881	.2294	
22			.583	.2622	.2458	.1966	
23			.4858	.2294	.2401	.1802	
24	.1619	.5506	.5182	.4858	.1966	.2267	.1638
Max	1.0526	.7209	.583	.5668	.9878	.9602	1.0242
Min	.1457	.2294	.2591	.2294	.1638	.1781	.1475
Avg	.4776	.3947	.3715	.3400	.4652	.4682	.4644

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214515 / 33/11 KV Khodad

Feeder No / Name : 203 / 11 kv GADACHIWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1619	.7773	.7773	.7773	.1638	.1296	.1966
2	.1619	.7449	.8097	.7773	.1638	.1134	.1966
3	.1781	.7773	.8745	.7287	.1966	.0972	.2458
4	.2267	.8745	.8907	.8583	.2458	.1147	.2458
5	.3077	.9393	.9717	1.1012	.2622	.1781	.2622
6	.3563	1.004	1.0364	1.1797	.2949	.2949	.3277
7	.3887	.3932	.3441	.3077	.3277	.2949	.3605
8	1.4413		.3768	.4049	1.5203	1.6385	1.6484
9	1.7166	.2753	.4915	.4049	1.7604	1.9595	1.8884
10	1.7976	.3932	.4915	.4424	1.7284	2.0891	1.8244
11		.426	.4424	.4096	1.8461	1.9595	
12	1.7976		.421	.3277	1.4089	1.9204	1.7976
13		.3932	.421	.2622	1.9271	1.9524	
14	1.4089		.3887	.2622	1.166	1.8564	1.6842
15	1.3927		.3887	.2294	1.5708	1.6644	1.7004
16		.3932	.3887	.2294	.2267	.2622	.2294
17			.421	.2622	.2401	.2622	
18	.3441		.4049	.2949	.2591	.2458	.3277
19		.3768	.3725	.2622	.2915	.2458	
20	.2785	.3441	.3563	.2458	.2915	.2622	.2622
21	.9393	1.004	.8421	.2458	.2401	.2294	
22			.8745	.2294	.1619	.1966	
23			.852	.1966	.1619	.1802	
24	.1943	.8421	.7773	.8097	.1802	.1296	.1638
Max	1.7976	1.004	1.0364	1.1797	1.9271	2.0891	1.8884
Min	.1619	.2753	.3441	.1966	.1619	.0972	.1638
Avg	.7701	.6224	.6006	.4687	.6932	.7615	.7860

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214515 / 33/11 KV Khodad

Feeder No / Name : 204 / 11 KV SWAMINAGAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.7449	.7537	.8907	.2458	.3563	.2458
2	.2429	.6802	.7773	.8421	.2622	.3239	.2622
3	.2915	.6802	.8097	.8097	.2622	.2949	.2622
4	.3401	.7125	.8745	.9393	.2949	.3401	.2949
5	.4534	.7773	.9069	1.0688	.3605	.421	.3277
6	.5182	.8745	.9717	1.1336	.4096	.5243	.3605
7	1.668	.4588	.4424	.5668	.4915	.6154	.4915
8	1.7166		.4915	.5668	1.6804	1.7004	1.7284
9		.4096	.4588	.4858	1.8244	1.8785	1.8244
10	1.7328	.3768	.4424	.4534	1.7284	1.8351	1.8244
11		.3768	.426	.3932		1.9109	
12	1.5384		.3887	.3605	1.4899	1.7924	1.7004
13		.3605	.4372	.3277	1.7166	1.7284	
14	1.4089		.3887	.2949	1.0242	1.6324	1.4899
15	1.2308		.3887	.2622	1.4243	1.3123	1.3441
16		.3113	.4049	.2622	.2721	.2949	.2458
17			.4049	.2949		.3113	
18	.3605		.4858	.3277	.4049	.2949	.3768
19		.426	.4534	.3605	.4696	.3277	
20	.3113	.3605	.4858	.3353	.4321	.3277	.3277
21	1.004	.9069	1.0688	.3277	.4049	.2949	
22			1.0526	.2622	.4049	.2622	
23			.9878	.2622	.3887	.2458	
24	.2915	.7773	.7449	.9393	.2458	.3563	.2458
Max	1.7328	.9069	1.0688	1.1336	1.8244	1.9109	1.8244
Min	.2429	.3113	.3887	.2622	.2458	.2458	.2458
Avg	.8375	.5771	.6270	.5320	.7381	.8076	.7854

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214516 / 33/11 KV Pimpalwandi

Feeder No / Name : 201 / 11 KV NEHARWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1233	.3353	.3688	.3018	1.2574	1.3077	1.2239
2	1.0898	.3185	.3688	.3018	1.2574	1.2742	1.2071
3	1.1233	.3353	.3856	.3521	1.291	1.291	1.2407
4	1.1736	.3521	.4862	.5868	1.3245	1.3077	1.2574
5	1.2239	.4359	.6036	.503	1.358	1.3413	1.2574
6	1.291	.6539	.7042	.6706	1.4083	1.5089	1.291
7	.788	.8215	.8551	.8718	.7712	.8383	.8048
8	.8886	1.8778	1.9951		.788	.9389	.9389
9	.7377	2.1125	2.1628	2.5819	.6706	.7209	.788
10	.7377	2.7664	2.3304	2.7496	.5868	.788	.6706
11	.8048	2.7999	2.4813	2.7664	.7209	.7712	.5533
12	.8215	2.7664	2.4981	2.649	.9389	.6371	.6371
13	.7712	2.431	2.7161	2.5484	.8215	.6203	.6539
14	.7209	2.3472	2.5149	2.3472	.8718	.6036	.5868
15	.6203	2.3807	2.1293	2.2969	.7042	.6539	.6371
16	.7545	.7377	.5868	.8383	.8718	.6371	.6706
17	.7209	.7545	.6874	.8048	.8383	.6036	.7209
18	.7042	.7545	.7042	.7209	.7712	.6874	.7209
19	.8383	.6539	.7042	.7042	.7042	.7377	.7042
20	.788	.6706	.6706	.7712	.6539	.7042	.6874
21	.7209	.6874	.6036	1.4922	1.4922	1.3916	1.291
22	.5533	.6203	.5197	1.4251	1.4922	1.3916	1.2574
23	.4024	.4527	.4359	1.3413	1.3748	1.2574	1.2239
24	1.1736	.3353	.4191	.3353	1.3077	1.2742	1.2239
Max	1.291	2.7999	2.7161	2.7664	1.4922	1.5089	1.291
Min	.4024	.3185	.3688	.3018	.5868	.6036	.5533
Avg	.8572	1.1834	1.1638	1.3026	1.0115	.9703	.9270

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214516 / 33/11 KV Pimpalwandi

Feeder No / Name : 202 / 11 KV KALEKARWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8139	1.3565	1.4752	1.2378	.8478	.763	.8478
2	.8139	1.3904	1.4413	1.1869	.8478	.7461	.8817
3	.8478	1.3565	1.4582	1.2378	.8987	.78	.9496
4	.9326	1.3125	1.5261	1.3395	.9835	.8139	1.0343
5	1.0174	1.4251	1.6278	1.4074	1.0682	.9156	1.2209
6	1.3226	1.6263	1.7465	1.6108	1.2039	1.2548	1.3565
7	1.543	1.4754	1.4752	1.4243	1.3904	1.4413	1.3565
8	2.1026	1.358	1.3395		2.1534	2.34	1.8652
9	2.3061	1.4083	1.2039	1.3226	2.6452	2.5434	2.2213
10	2.4417	1.153	1.0852	1.2209	2.7469	2.6452	2.2382
11	2.5774	1.3395	1.1191	1.0513	2.9334	2.6113	2.3061
12	2.713	1.153	1.0852	1.153	2.73	2.7469	2.4417
13	2.7469	1.0852	1.2039	1.2039	2.5943	2.6452	2.4587
14	2.4417	1.0174	1.0852	1.17	2.6452	2.5434	2.3739
15	2.323	1.0513	1.0343	1.0852	2.4417	2.4078	2.4587
16	.8987	1.1361	1.1191	1.0682	.8648	.9156	.8817
17	.9156	.9835	1.0852	1.0852		.9496	.8817
18	.9156	1.1869	1.17	1.1022	1.2039	.9835	1.153
19	1.3565	1.543	1.2378	1.3904	1.4243	1.2378	1.4582
20	1.5261	1.4074	1.2887	1.3904	1.4074	1.4413	1.543
21	1.4752	1.6956	1.6278	1.2209	1.2717	1.3056	1.4752
22	1.4243	1.6956	1.5261	1.0004	1.0343	1.0852	1.17
23	1.3226	1.543	1.4074	.9326	.8478	.8987	.9835
24	.8478	1.3226	1.4752	1.3226	.8648	.7461	.8478
Max	2.7469	1.6956	1.7465	1.6108	2.9334	2.7469	2.4587
Min	.8139	.9835	1.0343	.9326	.8478	.7461	.8478
Avg	1.5678	1.3343	1.3268	1.2245	1.6108	1.5317	1.5169

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214516 / 33/11 KV Pimpalwandi

Feeder No / Name : 203 / 11 KV CHALAKWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2321	.3149	.3481	.2818	.3149	.2652	.3315
2	.2321	.3315	.3481	.1989	.3149	.2486	.3315
3	.2652	.3481	.3812	.1989	.2984	.2652	.3647
4	.2984	.3647	.4144	.2486	.3315	.2984	.4144
5	.3315	.3978	.4475	.2818	.4641	.3647	.4641
6	.5138	.5304	.5138	.4144	.547	.5138	.547
7	.6464	.503	.5636	.6133	.6299	.5304	.663
8	.5967	.5801	.5304		.8288	.7956	.663
9	.663	.4807	.5304	.5801	1.0395	.8951	.8122
10	.7625	.547	.663	.6299	1.0898	.8288	.8619
11	.8383	.4475	.5636	.5967	.9892	.8288	.9116
12	.8551	.4807	.5138	.5636	1.0608	.8288	.7625
13	.8785	.5636	.5636	.5304	.9614	.8785	.8951
14	.8288	.6133	.5967	.5967	.9614	.8785	.9448
15	.7625	.547	.5801	.6133	.9614	.9448	.8785
16	.4973	.5801	.5967	.547	.5138	.4973	.4807
17	.5636	.4641	.5801	.5304	.4641	.5304	.4641
18	.4807	.431	.547	.6464	.4641	.5801	.4973
19	.5304	.547	.5138	.6299	.5304	.5967	.5304
20	.5138	.5138	.4807	.6133	.4973	.5967	.547
21	.4475	.4973	.4973	.6299	.431	.6133	.4973
22	.4144	.3978	.3978	.4973	.3812	.4641	.4475
23	.3481	.3647	.3315	.3978	.2652	.3647	.2818
24	.2818	.3315	.3481	.3149	.3481	.2486	.3315
Max	.8785	.6133	.663	.6464	1.0898	.9448	.9448
Min	.2321	.3149	.3315	.1989	.2652	.2486	.2818
Avg	.5326	.4657	.4938	.4850	.6120	.5774	.5801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214539 / HIWARE TARFE NARAYANGAON

Feeder No / Name : 201 / KHANDOBA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0526	.0648	.0686	.0648	.4534		.5182
2	.0526	.0486	.0686	.0648	.4534		.5182
3	.0526	.0648	.0686	.0648	.4534		.5182
4	.0526	.0648	.0686	.0648	.4858		.6478
5	.0526	.081	.1372	.0648	.4858		.6478
6	.0701	.081	.1372	.0648	.4858	.5571	.6478
7	.0701	.081	.1543	.081	.0876	.0732	.081
8	.8421	.7611	.8097		.0876	.0819	.081
9	.9069		.7164	1.0526	.0701	.0655	.081
10	1.0202	.8421	.7935	1.1012	.0655	.0648	.081
11	1.085	1.0322	1.0526	1.1012		.0648	.081
12	1.0526	1.0486	1.0688	1.0202	.0819	.0648	.081
13	1.0202		1.0688	.9717		.081	.081
14	.9717		1.0202	.9555		.0972	.081
15	.9231		.9878	.9555	.0819	.081	.081
16	.0324		.0324	.0701	.0914	.0972	.0857
17	.0324		.0486	.0701	.1097	.0972	.0857
18	.0324	.0686	.0648	.0701		.0486	.0857
19	.0486	.1543	.0648	.0526		.0972	.1715
20	.0648	.1543	.0648	.0526	.0549	.0486	.1715
21	.0648	.1543	.0648	.4049	.5243	.3563	.1372
22	.081	.1372	.081	.4049		.3563	.0686
23	.0648	.1372	.081	.4049		.4049	.0686
24	.0526	.0648	.1372	.081	.4915		.4534
Max	1.085	1.0486	1.0688	1.1012	.5243	.5571	.6478
Min	.0324	.0486	.0324	.0526	.0549	.0486	.0686
Avg	.3625	.2800	.3692	.4017	.2685	.1521	.2315

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214539 / HIWARE TARFE NARAYANGAON

Feeder No / Name : 202 / KALAMJAI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3077	.4858	.5218	.4858	.1753		.1943
2	.3077	.4858	.506	.4858	.1753		.1943
3	.3077	.5182	.506	.4858	.1753		.1619
4	.3563	.5182	.506	.5182	.2279		.1619
5	.4372	.5344	.506	.5182	.2454		.1457
6	.502	.5344	.506	.5182	.2454	.213	.1457
7	.1457	.2429	.1966	.1943	.2454	.2743	.1457
8	.1619	.1781	.2058		.6478	.7373	.8097
9	.1943		.1886	.3155	.8124	.9175	.8421
10	.3077	.3401	.3077	.3506	.8848	.9069	.8259
11	.3077	.3605	.3239	.333		.9393	.8907
12	.3077	.3441	.2915	.333	1.0159	.9717	.8259
13	.2915		.2915	.333	.9503	.8097	.8259
14	.3077		.2753	.3155		.9069	.8097
15	.3725		.2753	.3155	.9831	.9231	.7449
16	.3239		.2429	.2629	.3658	.1781	.1638
17	.3077		.2267	.2454	.3292	.1781	.1658
18	.3239	.2915	.1943	.2103			.1886
19	.1619	.2058	.1943	.1734		.1781	.1886
20	.1619	.2058	.1781	.1578	.2743	.1781	.1715
21	.3239	.5344	.4696	.1578	.2294	.1781	.6226
22	.3239	.5344	.4534	.1578		.1619	.5992
23	.3563	.5344	.4534	.1753		.1619	.5668
24		.3563	.5218	.4858	.1753	.1802	.1943
Max	.502	.5344	.5218	.5182	1.0159	.9717	.8907
Min	.1457	.1781	.1781	.1578	.1753	.1619	.1457
Avg	.2999	.4003	.3476	.3273	.4532	.4997	.4411

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214539 / HIWARE TARFE NARAYANGAON

Feeder No / Name : 203 / SHIVAHARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0181	.0162	.0171	.0162	.5668		.583
2	.0181	.0162		.0162	.5668		.5992
3	.0181	.0162	.0171	.0162	.6478		.5992
4	.0181	.0162	.0171	.0162	.6478		.6478
5	.0181	.0162	.0171	.0162	.664		.6478
6	.0181	.0162	.0171	.0162	.664	.5898	.664
7	.0181	.0162	.0171	.0162	.0175	.0183	.0162
8	1.1336	.0162	1.1984		.0175	.0164	.0162
9	1.2146		1.2498	1.2955	.0175	.0164	.0162
10		1.3927	1.3765		.0164	.0162	.0162
11		1.3435	1.4089	1.3765		.0156	.0162
12	1.3603	1.3435	1.3927	1.3765	.0164	.0162	.0162
13	1.3117		1.3603	1.3603	.0164	.0162	.0162
14	1.2631		1.2955	1.2631		.0162	.0162
15	1.1984		1.1984	1.085	.0164	.0162	.0162
16	.0162		.0162	.0175	.0183	.0162	.0171
17	.0162		.0162	.0175	.0183	.0162	.0171
18	.0162	.0171	.0162	.0175		.0162	.0171
19	.0162	.0171	.0162	.0173		.0162	.0171
20	.0162	.0171	.0162	.0175	.0183	.0162	.0171
21	.0162	.0171	.0162	.5344	.5571	.4534	.0171
22	.0162	.0171	.0162	.5344		.502	.0171
23	.0162	.0171	.0162	.5668		.502	.0171
24	.0181	.0162	.0171	.0162	.5668	.5898	.583
Max	1.3603	1.3927	1.4089	1.3765	.664	.5898	.664
Min	.0162	.0162	.0162	.0162	.0164	.0156	.0162
Avg	.3526	.2405	.4665	.4368	.2808	.1508	.1919

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

HADAPSAR[053]

BU 0817

Substation No/ Name :- 213435 / 22/22 PURVRANG SUBSTATION

Feeder No / Name : 301 / SAI SATYAM

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.4705	3.131	3.2065	3.0178	3.0178	3.0933	3.0178
2	3.3951	2.9424	3.131	3.0178	3.0178		2.9424
3	3.0178	2.8292	2.9424	2.9047	2.9047	2.9047	2.9424
4	3.4705	3.5082	3.0178	3.0178	3.0178	3.0178	2.9424
5	3.7723	3.7723	3.5082	3.2065	3.7723	3.3951	3.0178
6	4.6022	4.1495	3.8855	3.3951	4.1495	3.7723	4.0741
7	5.4698	5.0172	4.6399	4.0364	4.904	4.4136	5.0926
8	6.7901	5.7716	5.4698	4.7154	5.7339	5.4698	5.583
9	5.6584	5.7716	5.583	5.168	5.583	5.7339	5.4698
10	5.6584	6.0357	5.9225	5.6584	5.7339	5.9225	5.583
11	5.2058	5.583	5.4698	5.3567	5.4698	5.583	5.3944
12	5.3944	5.3944	5.3567	5.2812	4.904	5.2812	5.0172
13	4.3381	3.6969	4.9794	5.0926		4.7154	4.5268
14	3.9609	3.7723	4.3381	3.8809		4.1495	
15	3.8855		4.6022	3.7723		4.2627	5.0172
16	2.3765	.2641	4.7154	4.0741			5.0172
17	2.452	4.4513	4.7154	4.225	2.7161	4.5268	4.904
18	.1886	5.2812	4.6022	4.0741	6.3375	.2641	5.0926
19	3.2065	6.0357	5.2435	5.0926	6.1111	5.3944	5.7716
20	5.0172	5.4698	4.9794	4.7908	5.7339	4.904	5.3944
21	4.7154	5.0926	4.5645	4.5268	5.0926	4.7154	5.0172
22	4.3381	4.5268	4.2627	4.1495	4.5268	4.4513	4.5268
23	3.7723	3.9609	3.6969	3.5837	3.8477	3.7723	3.8855
24	3.6969	3.2065	3.3196	3.2065	3.2065	3.3196	3.3196
Max	6.7901	6.0357	5.9225	5.6584	6.3375	5.9225	5.7716
Min	.1886	.2641	2.9424	2.9047	2.7161	.2641	2.9424
Avg	4.0772	4.3332	4.4230	4.1352	4.4890	4.2301	4.5022

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

HADAPSAR[053]

BU 0817

Substation No/ Name :- 213435 / 22/22 PURVRANG SUBSTATION

Feeder No / Name : 302 / MANJARI

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.5113	3.1417	3.3265	3.4004	1.3306	3.6961	3.6961
2	3.3265	3.0678	3.2526	3.2156	3.2526	3.6961	3.6222
3		3.0678	3.1417	3.2156	3.2526	3.5113	3.6222
4	3.6222	3.3265	3.2526	3.3265	3.3265	3.77	3.807
5	3.8809	3.6222	3.8809	3.9609	4.0657	4.0657	3.9918
6	5.7289	4.3614	4.2505	4.2505	4.4353	4.6201	4.9897
7	5.7289	5.2854	5.1745	4.8049	4.9897	5.4332	5.9137
8	5.8398	5.9137	5.5441	5.5441	5.9137	6.1725	6.2833
9	5.655	5.655	5.9137	5.9137	6.2094	6.1725	5.9137
10	5.5441	5.8398	6.1725	6.2094	5.9877	6.3573	5.8398
11	5.4702	6.0246	6.2833	6.1725	5.9877	6.2094	5.8398
12	5.3593	5.2854	2.7721	5.9877	5.692	6.0246	5.5441
13	4.5462	4.731	5.3593	5.5441	5.692	5.8398	5.1006
14	3.9918	4.731	4.8788	4.9897	5.3593	4.9897	
15	4.2505	4.731	5.0636	4.8788	5.1006	5.1745	5.1376
16	4.2505	4.731	4.9897	4.8049	5.1745	5.1745	6.2833
17	4.3614	4.731	5.0636	4.694	5.1745	5.2854	5.9137
18	4.5462	5.9137	5.2484	4.6201	5.2484	5.1745	5.5266
19	5.4702	5.655	5.7289	5.1745	5.9877	5.9137	6.0985
20	4.9897	5.2854	5.4332	5.1006	5.6181	5.5441	5.8398
21	4.731	4.9158	5.0636	4.694	5.4332	5.3593	5.5441
22	4.3614	4.5462	4.694	4.2505	4.8788	4.9897	5.1745
23	3.807	3.9918	4.1396	3.77	3.9209	4.2505	4.4353
24	3.6961	3.2526	3.5113	3.6961	3.5113	3.8809	3.8809
Max	5.8398	6.0246	6.2833	6.2094	6.2094	6.3573	6.2833
Min	3.3265	3.0678	2.7721	3.2156	1.3306	3.5113	3.6222
Avg	4.6378	4.6586	4.6725	4.6758	4.8143	5.0544	5.1304

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

HADAPSAR[053]

BU 0817

Substation No/ Name :- 213435 / 22/22 PURVRANG SUBSTATION

Feeder No / Name : 303 / phulmala

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1509	.1494	.1509	.1509	.1132	.1132
2	.1132	.1132	.112	.1509	.1509	.1132	.1132
3	.1132	.1132	.1494	.1509	.1132	.1132	.1132
4	.1509	.1132	.112	.1509	.1132	.1132	.1132
5	.1509	.1509	.112	.1509	.1509	.1132	.1132
6	.1509	.1509	.1494	.1509	.1509	.1132	.1132
7	.1886	.1509	.1132	.1132	.1886	.1132	.1509
8	.1509	.1886	.1509	.1132	.1886	.1509	.1886
9	.1509	.1509	.1886	.1509	.1509	.1886	.1509
10	.1509	.1886	.1886	.1509	.1886	.1886	.1509
11	.1509	.1886	.1886	.1886	.1509	.1886	.1509
12	.1509	.1886	.1886	.1886	.1509	.1886	.1509
13	.1509	.1509	.1886	.1886	.1886	.1509	.1509
14	.1132	.1509	.2218	.1132	.1509	.1132	
15	.1509	.1886	.1886	.1132	.1509	.1509	.1509
16	.1509	.1509	.1886	.1509	.1132	.1132	.1509
17	.1886	.1509	.1886	.1509	.1509	.1509	.1509
18	.1886		.1509	.1509	.1509	.1132	.1509
19	.1509	.1886	.1509	.1509	.1132	.1509	.1509
20	.1509	.1509	.1509	.1509	.1509	.1509	.1509
21	.1509	.1509	.1509	.1509	.1509	.1509	.1509
22	.1509	.1886	.1509	.1509	.1509	.1509	.1509
23	.1509	.1494	.1509	.1509	.1509	.1509	.1509
24	.1509	.1509	.1509	.1509	.1509	.1509	.1132
Max	.1886	.1886	.2218	.1886	.1886	.1886	.1886
Min	.1132	.1132	.112	.1132	.1132	.1132	.1132
Avg	.1509	.1574	.1598	.1493	.1509	.1415	.1411

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

MULSHI[057]

BU 0850

Substation No/ Name :- 213331 / 22 KV BHARE SWITCHING

Feeder No / Name : 301 / MAN

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18
HR	Load (MW)	Load (MW)
3		.2929
11	3.1591	
Max	3.1591	.2929
Min	3.1591	.2929
Avg	3.1591	.2929

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

MULSHI[057]

BU 0850

Substation No/ Name :- 213331 / 22 KV BHARE SWITCHING

Feeder No / Name : 302 / 22 KV LAWALE

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2542	2.4771	2.2918	2.4021	2.4396	2.2542	2.0288
2	2.0664		2.2542	2.2167	2.5522	2.2167	1.8785
3	1.8785	2.2542	2.4045	2.1791	2.6273	2.1791	2.2167
4		2.1791	2.3294	2.104	2.7023	2.2542	2.1791
5		2.3294	2.8178	2.4797	2.7023	3.6819	1.1271
6			2.7051	2.6139	2.8525	3.8322	2.6299
7			3.3813	2.9305			3.1184
8	3.1967	3.9449	3.6068	3.7946	3.9409	4.1328	3.3813
9	3.1967	4.0952	3.8322	3.9073	4.0535	3.9073	3.4941
10	3.1967	4.3582	3.8322	4.0576	4.2036	4.3538	3.7571
11	3.1591	4.283	4.1328	3.6782	4.3162	4.6165	4.3206
12		4.5085	4.0952	3.4155	4.5039	4.8042	4.3913
13		4.3582		3.4155	4.3538	3.9409	4.3538
14		4.1328		3.6782		3.8283	4.3162
15	1.8016	4.2079	4.0952	3.5656			4.2412
16		4.1703	3.9449	3.3404	2.2895		4.3162
17		3.8698		3.3813	3.7532	3.9449	4.1286
18	3.7908	3.8322		3.0026	3.9409	3.7571	3.5656
19	3.9034	3.4941		3.3779	3.5656	3.5692	3.3779
20		3.3438		3.0056	3.3813	3.1935	3.3813
21	3.2278	3.3438	3.1152	3.0026	2.8178	3.0056	3.1903
22	3.1903	2.7802	2.8525		3.1184	3.0056	3.0026
23	2.8149	2.6675	2.7023	2.6648	2.2542	2.7051	2.8149
24	2.2519	2.5897	2.3669	2.4771	2.4396	2.4045	2.2542
Max	3.9034	4.5085	4.1328	4.0576	4.5039	4.8042	4.3913
Min	1.8016	2.1791	2.2542	2.104	2.2542	2.1791	1.1271
Avg	2.8521	3.4867	3.1534	3.0735	3.2766	3.4089	3.2277

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

MULSHI[057]

BU 0850

Substation No/ Name :- 213331 / 22 KV BHARE SWITCHING

Feeder No / Name : 303 / VULCAN

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9052	1.1827	1.448	1.2193	.381	1.7528	1.8671
2	1.5242	1.2936	1.5242	1.5242	.4572	1.829	1.7147
3	1.7147	1.4118	1.6766	1.6004	.6859	1.5242	1.829
4	1.7147	1.5043	1.5242	1.6975	.6478	1.4861	1.3717
5	1.5242	1.4998	1.6004	1.5684	.6097	1.5242	1.1431
6	1.3336	1.3306	1.6385	1.1584	.6478	2.4768	1.829
7	1.1431	1.1576	1.5242	.6379	.6478	2.7054	1.9052
8	2.4768		2.6292	.7087	2.21	2.6673	2.2862
9	2.0957	1.6766	2.4768	.6899	2.2862	1.829	2.1338
10	2.1338	1.9814	2.4387	.7023	2.3624	2.0576	2.3624
11	2.0576	2.1719	2.5911	.6878	2.3624	2.4006	2.2481
12			2.21	.6089	2.2481	1.5623	2.1719
13		1.8671	2.1719	.5959	2.4006	1.448	2.0576
14		2.0957	2.5911	.631	2.3624	2.6292	2.4006
15	2.1879	1.8671	2.6292	.6661	2.553		2.3243
16	2.1502	1.8671	2.5911	.3506	2.553	2.0195	2.2862
17		1.9433		.3628	2.6673	2.0195	2.4768
18	1.829	2.2481		.3628	2.2862	2.2862	2.2862
19	2.21	2.0957		.3628	2.4768	1.9052	2.6673
20	2.1338	1.7147	1.9052	.3624	1.5242	1.5242	1.7147
21	1.6004	1.7147	2.0195	.3624	2.0957	1.7147	1.9052
22	1.8671	1.829	1.9814	.381	1.5242	1.5242	1.9052
23	1.7528	1.7528	1.7528	.381	1.829	1.6385	1.7147
24	1.9052	1.2574	1.4098	1.0288		1.8671	1.7528
Max	2.4768	2.2481	2.6292	1.6975	2.6673	2.7054	2.6673
Min	1.1431	1.1576	1.4098	.3506	.381	1.448	1.1431
Avg	1.863	1.7029	2.0159	.7771	1.7312	1.9301	2.0147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

MULSHI[057]

BU 0850

Substation No/ Name :- 213338 / 22kV Khanapur Switching

Feeder No / Name : 301 / KUDAJE

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.567	.4914	1.89	1.6632	1.5876	.5287	.6042
2	.4909	.4154	1.8125	1.5513	1.515	.6042	.7175
3	.7545	.378	1.701	1.515	1.4407	.6797	.8307
4	.8307	.567	1.8919	1.4349	1.89	.793	.944
5	.9459	.6797	2.1524	1.8559	2.4594	.9063	1.0195
6	1.0195	.9063	2.4191	2.0391	2.6459	1.0195	1.1328
7	1.1706	1.0216	2.8321	2.2725	3.0995	1.0951	1.2461
8	1.3216	1.1317	3.4397	2.7298	2.9513	1.4349	1.3972
9	1.2461	.944	3.5118	2.9861	2.7593	1.3594	1.1559
10	1.0573	1.1706	3.4054	3.03	3.3263	1.2461	1.1198
11	.8307	1.2852	3.5909	3.1373	3.1342	1.3216	1.2282
12	1.0573	1.4349	3.7043	2.8698	3.0209	1.2839	1.2643
13	1.0206	1.3986	3.4054	2.6459		1.2084	1.1559
14	.9818	1.2461	2.9454			1.0195	
15	.7938	2.5678	3.0995	2.3081			1.0114
16		2.7215	3.1027	2.3837		1.1328	.6863
17		2.9483	2.8698	2.4947	1.0573	1.1328	.7225
18	1.1706	3.0209	3.0648	2.6486	1.0573		1.0837
19	1.0584	3.0586	3.2129	2.8378	1.2839	1.2084	1.2643
20	.8307	3.0964	3.0239	2.8756	1.1706	1.2461	1.1198
21	.8307	3.0209	2.7943	2.5703	1.0573	1.0951	1.1559
22	.6804	2.8349	2.4973	2.5325	.9063	.944	1.0114
23	.5287	2.4167	2.0034	1.9675	.7552	.6419	.6863
24	.6042	.5664	2.0013	1.7405	1.6632	.5287	
Max	1.3216	3.0964	3.7043	3.1373	3.3263	1.4349	1.3972
Min	.4909	.378	1.701	1.4349	.7552	.5287	.6042
Avg	.8996	1.6385	2.7655	2.3517	1.9391	1.0196	1.0254

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

MULSHI[057]

BU 0850

Substation No/ Name :- 213338 / 22kV Khanapur Switching

Feeder No / Name : 302 / Donje

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9063	.9072	.9431	.9072	.8316	.9316	.7826
2	.793	.793	.8694	.7938	.7575	1.0434	.9316
3	1.0195	.7552	.7938	.7575	.7204	1.1552	1.118
4	1.134	.944	1.0573	.945	.944	1.267	1.2298
5	1.2084	1.1328	1.2084	1.134	1.1374	1.3788	1.3416
6	1.3216	1.2084	1.3972	1.2852	1.4378	1.4906	1.4906
7	1.4349	1.512	1.586	1.2839	1.6632	1.6397	1.6024
8	1.5104	1.8503	1.7748	1.4014	1.5892	1.7888	1.7515
9		1.5482	1.7748	1.2084	1.515	1.677	1.406
10	1.4742	1.6237	1.5498	1.3608	1.3243	1.4906	1.406
11	1.1706	1.4364	1.6254	1.5135	1.267	1.6397	
12	1.2839	1.4742	1.5876	1.4771	1.4906	1.4306	1.406
13	1.1718	1.4727	1.3986	1.323		1.2298	1.332
14	1.1706	1.3216	1.4742	1.323	1.3043	1.2298	1.184
15	1.1706	1.2461	1.4	1.2852	1.4906	1.267	1.11
16		1.4742	1.5876	1.3608	1.267	1.3416	.888
17	.6042	1.5482	1.5513	1.4	1.4161	1.3416	1.332
18	1.3216	1.4727	1.7388	1.4364	1.4906	1.3043	1.48
19	1.4742	1.5876	1.7027	1.5498	1.6024	1.4906	1.628
20	1.3594	1.5104	1.5104	1.512	1.4906	1.4906	1.332
21		1.3986	1.3986	1.3216	1.3416	1.3043	1.406
22	1.2474	1.2474	1.4014	1.2474	1.1925	1.1925	1.184
23	1.0195	1.0951	1.1718	1.0216	1.118	1.0807	1.073
24	.9808	.9818	1.0584	.9828	.8694	.9316	.7826
Max	1.5104	1.8503	1.7748	1.5498	1.6632	1.7888	1.7515
Min	.6042	.7552	.7938	.7575	.7204	.9316	.7826
Avg	1.1799	1.3142	1.3984	1.2430	1.2722	1.3391	1.2695

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

MULSHI[057]

BU 0850

Substation No/ Name :- 213338 / 22kV Khanapur Switching

Feeder No / Name : 303 / Osade

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0573	1.2084		.4112	.9719
2	.944	1.1328		.5607	1.1214
3	1.1328	1.0573		.6728	1.2709
4	1.2839	.944		.785	1.4204
5	1.5498	1.1328		.9345	1.57
6	1.6992	1.3972		1.084	1.7569
7	1.8125	1.5876		1.2335	1.9064
8	1.9239	1.8107		1.4578	1.9064
9	1.6992	1.6632		1.4578	1.5428
10	1.8503	1.89			.8081
11	.6419	1.8503		1.3083	1.6897
12	1.4349	1.6992		.6728	1.7631
13	1.512	1.586		1.3831	1.7264
14	1.3972	1.6221	2.2428	1.5326	1.506
15	.7175		2.1307	1.6073	1.4693
16			2.654	1.3831	.7346
17	1.2839		1.1214	1.3083	1.48
18	1.3594		1.5326	1.2335	1.6162
19	1.586		1.8316	1.0466	1.8733
20	1.8144		1.4204	1.3831	1.7264
21	1.6237		1.4952	1.3831	1.7631
22	1.701		1.3083	1.1214	1.4693
23	1.4742		1.1214	.6728	1.0652
24	1.0951	1.3216		.4112	.9719
Max	1.9239	1.89	2.654	1.6073	1.9064
Min	.6419	.944	1.1214	.4112	.7346
Avg	1.4171	1.4602	1.6858	1.0889	1.4637

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

NASARAPUR[058]

BU 0868

Substation No/ Name :- 214453 / 33 KV KHED SHIVAPUR

Feeder No / Name : 301 / Katraj -Nasarapur-

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0178	1.8861	2.8292	3.0178	2.6406	2.6406	2.8292
2	3.0178	1.8861	2.6406	2.8292	2.6406	2.6406	2.6406
3	2.8292	1.8861	2.452	2.8292	2.452	2.452	2.452
4	2.8292	1.8861	2.2634	2.6406	2.452	2.452	2.6406
5	2.8292	2.0748	2.6406	2.8292	2.6406	2.6406	2.6406
6	2.8292	2.2634	3.2065	3.0178	2.8292	3.0178	3.0178
7	3.2065	2.6406	3.3951	3.3951	3.5837	3.5837	3.7723
8	3.5837	3.3951	4.1495	3.9609	3.9609	3.9609	4.1495
9	3.3951	4.5268	4.904	4.7154	4.7154	5.0926	4.7154
10	3.3951	6.2243	6.0357	5.4698	5.8471	6.2243	5.6584
11	2.2634	6.2243	6.6015	5.6584	6.4129	6.2243	6.0357
12	2.8292	5.0926	6.0357	5.6584	6.0357	5.8471	6.4129
13	2.452		3.5837	4.7154	5.2812	4.3381	5.0926
14		3.9609	5.0926	.7545	5.6584	5.2812	5.4698
15		4.1495	5.2812	4.5268	5.6584	5.4698	6.2243
16		5.2812	5.4698	5.0926	3.5837	5.2812	5.8471
17	2.452	5.4698	5.4698	4.3381	4.1495	5.8471	5.6584
18	2.452	5.4698	4.904	5.0926	4.5268	4.904	5.0926
19	2.6406	5.2812	4.7154	4.7154	5.0926	4.904	5.0926
20	2.6406	4.1495	4.3381	4.1495		4.3381	4.3381
21	2.6406	3.9609	4.1495	3.9609	3.9609	3.5837	3.9609
22	2.452	3.5837	3.2065	3.2065	3.7723	3.3951	3.5837
23	2.2634	3.3951	3.2065	3.0178	3.3951	3.2065	3.2065
24	3.2065	2.0748	3.0178	3.0178	2.8292	3.0178	3.0178
Max	3.5837	6.2243	6.6015	5.6584	6.4129	6.2243	6.4129
Min	2.2634	1.8861	2.2634	.7545	2.452	2.452	2.452
Avg	2.8202	3.7723	4.1495	3.8587	4.0921	4.1810	4.3146

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

NASARAPUR[058]

BU 0868

Substation No/ Name :- 214453 / 33 KV KHED SHIVAPUR

Feeder No / Name : 302 / Kalyan

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.7545	.5544	.9431	.5487	.7545	.5544
2	.9145	.7545	.3696	.7316	.7316	.5658	.5544
3	.7545	.5658	.3696	.7316	.5487	.7545	.7392
4	.7545	.5658	.5544	.7545	.7316	.7545	.7392
5	.9145	.5658	.7392	.9145	.7316	.9431	.924
6	.9145	1.1317	.924	.9145	.9145	1.1317	1.1088
7	1.0974	1.5089	1.2936	.9145	1.0974	1.5089	1.4784
8	1.2803	2.0748	1.4784	1.0974	1.6461	1.3203	1.6632
9	1.6975	2.0748	2.0119	2.0328	2.0748	2.452	2.0328
10	1.8861	2.2634	2.2634	2.4025	2.2634	2.0748	2.2177
11	.9431	2.2634	2.0119	2.0328	1.8861	1.8861	2.4025
12	1.3203	2.0748	1.6975	2.0328	1.8861	2.0748	2.2177
13	1.3203	1.7147	1.4632	1.829	2.2634	1.8861	2.0119
14	1.3203	1.6975	1.4632	1.829	2.2634	1.6975	2.0119
15	.9431	1.8861	1.829	1.829	1.5089	1.8861	2.0119
16		1.6975	2.0119	2.0119	1.8861	2.0748	2.1948
17	.5658	1.6975	1.6975	1.829	2.0748	2.0748	2.0119
18	1.1317	1.8861	1.6975	1.6461	2.0748	1.6975	2.0119
19	1.1317	1.6975	1.4632	1.6461	1.8861	1.6975	1.829
20	.9431	1.5089	1.4632	1.4632	1.6975	1.3203	1.6461
21	1.1317	1.1317	1.2803	1.0974	1.5089	1.3203	1.4632
22	.7545	.9431	1.3203	1.0974	1.3203	1.1317	1.2803
23	.7545	.5658	1.0974	.9145	1.1317	.9431	.9145
24	.9145		.5658	.9431	.7316	.9431	.7545
Max	1.8861	2.2634	2.2634	2.4025	2.2634	2.452	2.4025
Min	.5658	.5658	.3696	.7316	.5487	.5658	.5544
Avg	1.0566	1.4359	1.3175	1.4016	1.4753	1.4539	1.5323

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

NASARAPUR[058]

BU 0868

Substation No/ Name :- 214453 / 33 KV KHED SHIVAPUR

Feeder No / Name : 303 / Shivare

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.3772	.5487	.3658	.5487	.3772	.3734
2	.3658	.3772	.5487	.3658	.3658	.3772	.3734
3	.3772	.3772	.3658	.3772	.3658	.3772	.3734
4	.3658	.3772	.3658	.5487	.3658	.3772	.5601
5	.3658	.3772	.5487	.5487	.5487	.3772	.5601
6	.5487	.5658	.5487	.7316	.5487	.5658	.7468
7	.7316	.7545	.7316	.7316	.7316	.7545	.7468
8	.7316	.7545	.9145	.7316	.7316	.7545	.9335
9	.9431	.9431	.9145	.9145	.9431	.9431	.9145
10	.9431	.9431	.9431	1.0974	1.1317	.9431	.9145
11	.5658	1.1317	.9145	1.0974	1.1317	1.1317	1.0974
12	.7545	.9431	.9431	1.0974	1.1317	1.3203	.9145
13	.7545	.7545	.5487	.9145	.9431	.9431	.9145
14	.7545	.9431	.7316	.7316	1.1317	1.1317	1.0974
15	.7545	1.1317	.9145	1.0974	1.1317	.9431	1.0974
16		1.1317	1.0974	1.0974	.9431	1.1317	1.0974
17	.7545	.9431	1.1317	1.0974	1.1317	1.1317	1.0974
18	.7545	.9431	.9431	1.0974	.9431	.9431	.9145
19	.7545	.9145	.9145	.9145	.9431	.9431	.9145
20	.5658	.7545	.7316	.7316	.7545	.7545	.9145
21	.7545	.7545	.7316	.7316	.7545	.9431	.7316
22	.5658	.7545	.5544	.7316	.7545	.7545	.7316
23	.5658	.5658	.5487	.5487	.5658	.5658	.7316
24	.5487	.5658	.5658	.3658	.5487	.3772	.5658
Max	.9431	1.1317	1.1317	1.0974	1.1317	1.3203	1.0974
Min	.3658	.3772	.3658	.3658	.3658	.3772	.3734
Avg	.6421	.7533	.7376	.7778	.7954	.7859	.8049

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

NASARAPUR[058]

BU 0868

Substation No/ Name :- 214453 / 33 KV KHED SHIVAPUR

Feeder No / Name : 304 / Kataraj Exp.

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.9431	.7545	.5658	.7545	.9431	.9526
2	.9431	.9431	.7545	.7545	.7545	1.1317	.9526
3	.9431	.9431	.7545	.7545	.7545	.9431	.9526
4	.9431	.9431	.7545	.7545	.7545	.9431	1.1431
5	.7545	1.1317	.7545	.7545	.7545	.9431	1.1431
6	.7545	1.1317	.7545	.7545	.9431	.7545	1.1431
7	.7545	1.3203	.7545	.7545	.9431	.7545	1.1431
8	1.6975	1.7147	1.5089	.7545	1.6975	1.5089	1.9052
9		2.6673	1.8861		1.8861	1.5242	2.6406
10	2.0748	2.4768	1.8861		2.452	1.5242	3.0178
11	.7545	1.5242	1.8861		.9431	1.3336	1.8861
12	1.5089	2.2862	.7545		1.5089	1.7147	1.5089
13	1.3203	1.5242	.9431		2.0748	2.4768	2.6406
14	2.0748	.7621	1.1317		1.3203	.7621	2.0748
15	1.1317	1.5242	1.1317		1.8861	1.3336	1.5089
16		1.3336	1.1317		2.0748	1.5242	1.5089
17	1.1317	.7621	.7545	.3772	1.1317	1.3336	1.5089
18	.9431	.7621	.7545	.3772		.7621	1.1317
19	1.0185	1.1431	.9431	.3772	.9431	.7621	1.5089
20	.7545	.7621	.7545	.3772	.7545	.7621	.9431
21	.9431	.9526	.7545	.3772	.7545	.7621	.7545
22	.7545	.7621	.7545	.3772	.7545	.7621	.7545
23	1.1317	.9526	.7545	.3772	.9431	.7621	.7545
24	.7545	.9431	.7621	.5658	.5658	.7545	.7621
Max	2.0748	2.6673	1.8861	.7545	2.452	2.4768	3.0178
Min	.7545	.7621	.7545	.3772	.5658	.7545	.7545
Avg	1.0837	1.2587	.9906	.5658	1.1891	1.1157	1.4267

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

NASARAPUR[058]

BU 0868

Substation No/ Name :- 214453 / 33 KV KHED SHIVAPUR

Feeder No / Name : 305 / RASIA EXP

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.0754	.1886	.1886	.1886	.1886	.1905
2	.1886	.1132	.1886	.1886	.1886	.1886	.1905
3	.1886	.0754	.1886		.1886	.1509	.1905
4	.1886	.1132	.1886	.1886	.1886	.1509	.1905
5	.1886	.1132	.1886	.1886	.1886	.1886	.1905
6	.1886	.1132	.1886	.1886	.1886	.1509	.1905
7	.1886	.1886	.1886	.1886	.1886	.1886	.1905
8	.1886	.1905	.1886	.1886	.1886	.1886	.1905
9	.1886	.1905	.1886	.3772	.2641	.1905	.3772
10	.1886	.381	.1886	.3772	.3772	.381	.3772
11	.1886	.381	.3772	.3772	.3772	.381	.3772
12	.1886	.1905	.3772	.3772	.3772	.381	.3772
13	.1132	.1905	.1886	.1886	.1886	.1905	.1886
14	.1132	.381	.3772	.3772	.1886	.381	.3772
15	.1509	.9526	.1886	.1886	.1886	.1905	.3772
16		.1905	.1886	.1886	.1886	.1905	.1886
17	.1132	.1905	.1886	.1886	.1886	.1905	.1886
18	.1132	.1905	.1886	.1886	.1886	.1905	.1886
19	.1132	.1905	.1886	.1886	.1886	.1905	.1886
20	.1886	.1905	.1886	.1886	.1886	.1905	.1886
21	.1886	.1905	.1886	.1886	.1886	.1905	.1886
22	.1132	.1905	.1886	.1886	.1886	.1905	.1886
23	.1132	.1905	.1886	.1886	.1886	.1905	.1886
24	.1886	.1132	.1905	.1886	.1886	.1886	.1905
Max	.1886	.9526	.3772	.3772	.3772	.381	.3772
Min	.1132	.0754	.1886	.1886	.1886	.1509	.1886
Avg	.1640	.2203	.2123	.2296	.2153	.2168	.2365

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

NASARAPUR[058]

BU 0868

Substation No/ Name :- 214453 / 33 KV KHED SHIVAPUR

Feeder No / Name : 306 / STAR EXP.

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3772	.3772	.3772	.3772	.3772	.381
2	.3772	.3772	.3772	.3772	.3772	.3772	.381
3	.3772	.3772	.3772	.3772	.3772	.3772	.381
4	.3772	.3772	.3772	.3772	.3772	.3772	.381
5	.3772	.3772	.3772	.3772	.3772	.3772	.381
6	.3772	.3772	.3772	.3772	.3772	.3772	.381
7	.1886	.3772	.1886	.3772	.3772	.3772	.381
8	.3772	.381	.3772	.3772	.3772	.3772	.381
9	.3772	.381	.3772	.3772	.3772	.3772	.3772
10	.3772	.5716	.5658	.3772	.3772	.3772	.5658
11	.3772	.5716	.3772	.3772	.5658	.5658	.5658
12	.3772	.381	.3772	.3772	.3772	.3772	.3772
13	.3772	.381	.5658	.3772	.5658	.5658	.5658
14	.3772	.5716	.5658	.3772	.5658	.5658	.5658
15	.3772	.5716	.5658	.3772	.5658	.5658	.5658
16		.5716	.3772	.3772	.3772	.3772	.3772
17	.3772	.381	.3772	.3772	.3772	.3772	.3772
18	.3772	.381	.3772	.3772	.3772	.3772	.3772
19	.3772	.381	.3772	.3772	.3772	.3772	.3772
20	.3772	.381	.3772	.3772	.3772	.3772	.3772
21	.3772	.381	.3772	.3772	.3772	.3772	.3772
22	.3772	.381	.3772	.3772	.3772	.3772	.3772
23	.3772	.381	.3772	.3772	.3772	.3772	.3772
24	.3772	.3429	.381	.3772	.3772	.3772	.3772
Max	.3772	.5716	.5658	.3772	.5658	.5658	.5658
Min	.1886	.3429	.1886	.3772	.3772	.3772	.3772
Avg	.369	.4180	.4009	.3772	.4086	.4086	.4178

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

NASARAPUR[058]

BU 0868

Substation No/ Name :- 214453 / 33 KV KHED SHIVAPUR

Feeder No / Name : 307 / 22 kV Desai Exp.

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.3772	.5658	.3772	.381	.5658	.5716
2	.5658	.3395	.5658	.381	.381	.3772	.381
3	.3772	.3018	.5658	.381	.381	.3772	.381
4	.3772	.3772	.3772	.381	.381	.3772	.381
5	.5658	.3395	.3772	.381	.381	.3772	.381
6	.3772	.3772	.3772	.3772	.381	.3772	.5716
7	.3772	.3772	.5658	.5716	.5716	.3772	.5716
8	.5658	.7621	.7545	.5658	.7621	.679	.7621
9	.4527	.7621	.7545	.5716	.7545	.7621	.7621
10	.4115	.9526	.7545	.5716	.9431	.9526	.9526
11	.5658	.7621	.9431	.7621	.9431	.9526	.9526
12	.3772	.7621	.5658	.5716	.7545	.7621	.7621
13	.3772	.9526	.7621	.7621	.7545	.7621	.7621
14	.4527	.7621	.9526	.5716	.7545	.7621	.7621
15	.4909	.9526	.7545	.5716	.7545	.7621	.9526
16		.7621	.5658	.5716	.7545	.7621	.9526
17	.415	.7621	.5658	.7621	.7545	.7621	.9526
18	.4527	.7621	.5658	.5716	.7545	.7621	.7621
19	.415	.7621	.7545	.5716	.7545	.7621	.7621
20	.3772	.7621	.5658	.5716	.7545	.7621	.7621
21	.3772	.5716	.3772	.5716	.7545	.7621	.7621
22	.3772	.7621	.5658	.5716	.7545	.7621	.7621
23	.3395	.7621	.5658	.5716	.679	.7621	.7621
24	.5658	.3772	.7621	.3772	.381	.5658	.5716
Max	.5658	.9526	.9526	.7621	.9431	.9526	.9526
Min	.3395	.3018	.3772	.3772	.381	.3772	.381
Avg	.4443	.6434	.6219	.5391	.6508	.6619	.7065

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

NASARAPUR[058]

BU 0868

Substation No/ Name :- 214469 / 33 KV PABE

Feeder No / Name : 201 / Ghisar

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858		.415	.4108	.3395	.2427	.2829
2	.2667	.3326	.3734	.3174	.3174	.2054	.2801
3	.2477	.2743	.3734	.3142	.3174	.2056	.2614
4	.2667	.2427	.3734	.3174	.3174	.2614	.2772
5	.2858	.4435	.4755	.3109	.3174	.2614	.2987
6	.3239	.4435		.4805	.4108	.3174	.3361
7	.6287	.6468	.695	.5788	.6348	.5847	.5601
8	.695	.695	.7682	.7842	.7842	.6722	.7655
9	.6584	.7133	.7655	.8589	.9511	.7468	.8029
10	.6219	.7133	.7842	.8029	1.0082	.8402	.9149
11	.6219	.7133	.6722	.7655		.8316	.8507
12	.6036	.7316	.6099	.7577	.7282	.7468	.6535
13	.6036	.6219	.5729	.6535	.7095	.7095	.6161
14	.6401	.9145	.5415	.4108	.7655	.6348	.6535
15	.6401	.9145	.5175	.5415	.8299	.6348	.6161
16	.5304	.4805	.4854		.6722	.583	.6348
17	.5487	.4938	.462		.6653	.6722	.8215
18	.6401	.5975	.5544		.7468	.6908	.7842
19	.823	.8402	.7577		.8865	.8775	.8962
20	.8048	.8299	.7947	.8402	.8326	.8029	.8488
21	.7499	.7655	.7842	.7733	.7468	.6697	.7167
22	.6219	.6283	.6838	.5914	.5415	.5415	.5601
23	.4024	.4854	.5228	.4435	.2801	.3801	.3734
24	.3048	.3292	.4294	.4854	.3921	.2829	.3174
Max	.823	.9145	.7947	.8589	1.0082	.8775	.9149
Min	.2477	.2427	.3734	.3109	.2801	.2054	.2614
Avg	.5340	.6022	.5831	.5719	.6172	.5582	.5885

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

NASARAPUR[058] BU 0868

Substation No/ Name :- 214469 / 33 KV PABE

Feeder No / Name : 202 / Velha

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	09-FEB-18
HR	Load (MW)
14	.0762
Max	.0762
Min	.0762
Avg	.0762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

NASARAPUR[058]

BU 0868

Substation No/ Name :- 214469 / 33 KV PABE

Feeder No / Name : 203 / 11 KV Margasani (AG)

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.5487	.4508	.3944			
2	.4191	.5487	.4115	.3944			
3	.4001	.5487	.3988	.3944			
4	.4382	.2743	.4031	.3944			
5	.4572	.2743	.3856	.3944			
6	.5144	.2743	.3856	.3944			
8					.703	.7712	.7545
9					1.0227	1.0277	.9614
10					1.1105	1.1271	1.0442
11					1.094	1.1768	1.1437
12					1.1105	.9779	1.0898
13					1.0277	1.1603	.9892
14					1.0111	1.1437	1.0059
15					1.0395	1.046	1.0174
21	.4409	.3944	.3121				.5144
22	.5426	.3772	.3944				.5765
23	.5658	.4801	.4287				.5765
24	.4954	.5487	.4458	.4287			
Max	.5658	.5487	.4508	.4287	1.1105	1.1768	1.1437
Min	.4001	.2743	.3121	.3944	.703	.7712	.5144
Avg	.4731	.4269	.4016	.3993	1.0149	1.0538	.8794

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

URALIKANCHAN[059]

BU 0876

Substation No/ Name :- 214494 / 33 KV/22 KV Koregaon Mul

Feeder No / Name : 301 / Urulikanchan

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8861	2.0748	2.1502	1.9993	1.9418	2.0748	2.1502
2	1.8107	2.037	1.9993	1.8861	1.9044	2.0748	2.0748
3	1.8107	1.9616	1.9239	1.8861	1.8298	1.9616	1.9616
4	1.8107	2.037	1.8484	1.8107	1.8671	1.9616	1.9993
5	1.8861	2.1879	2.1879	1.9239	2.0165	2.1125	2.6406
6	2.9424	2.6783	2.7538	2.452	2.6139	2.5274	3.1687
7	3.4705	3.7723	3.6214	3.0556	3.2487	3.2065	3.7346
8	3.7723		3.6969	3.6591	3.6222	3.7723	3.8477
9	3.5082	3.3573	3.2819	3.5837	3.3234	3.3196	3.3951
10	3.2819	2.4143	3.1687	3.4355	3.3196	3.4705	3.3234
11	2.9801	2.9801	3.131	2.95	3.0933	3.2819	3.0247
12	2.7161	2.7915	2.9047	2.9127	3.0178	3.0178	2.9127
13		2.8292	2.7538	2.5606	2.7915	2.7538	2.5766
14	2.4897	2.6029	2.6029	2.5393	2.5274	2.4143	2.5019
15	2.5652	2.7538	2.6029	2.3152	2.5652	2.452	2.4272
16	2.6029	2.6783	2.6029	2.2779	2.7161	2.4764	2.5393
17		3.0178	2.7538	2.6886	2.7915	2.6981	2.7633
18	3.0933	3.2065	3.0933	2.7633	2.8669	2.6612	2.7633
19	3.6214	3.5837	3.5082	3.3981	3.2819	3.3634	3.1741
20	3.5837	3.3573	3.3573	3.3265	3.2065	3.3265	3.4355
21	3.131	3.1687	3.0178	3.0994	3.131	3.0308	3.1741
22	2.7915	2.8292	2.8292	2.7633	2.7538	2.8669	2.8753
23	2.4143	2.452	2.3765	2.3525	2.3011	2.4143	2.2779
24	1.9239	2.1125	2.3011	2.1502	1.9418	2.1879	2.2634
Max	3.7723	3.7723	3.6969	3.6591	3.6222	3.7723	3.8477
Min	1.8107	1.9616	1.8484	1.8107	1.8298	1.9616	1.9616
Avg	2.7315	2.7341	2.7695	2.6579	2.6947	2.7261	2.7919

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

URALIKANCHAN[059]

BU 0876

Substation No/ Name :- 214494 / 33 KV/22 KV Koregaon Mul

Feeder No / Name : 302 / Shindewadi

FEEDER SEPERATION/PURE AG

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		3.3951	3.1245	3.0483			
2		3.3951	3.0483	3.0864			
3		3.3951	2.9721	3.0102			
4		3.3951	2.9721	2.9721			
5		3.3951	3.0102	2.9721			
6		3.3951	3.0483	3.0483			
8	4.3759				4.1991	4.3759	4.5725
9	5.0549				4.8506	5.3567	5.2584
10	5.3567				5.3567	5.5632	5.2126
11	5.2058				5.5076	5.1821	5.5746
12	4.9794				5.1303	5.1059	4.7782
13					5.2812	4.3439	4.7782
14	4.6022				4.8285	4.8773	4.0543
15	4.5268				4.8285	4.9535	4.561
21	3.3196	2.9721	3.0483				
22	3.6969	3.1245	3.2007				
23	3.4705	3.1245	3.2007				.0377
24		3.4705	3.0483	3.1245			
Max	5.3567	3.4705	3.2007	3.1245	5.5076	5.5632	5.5746
Min	3.3196	2.9721	2.9721	2.9721	4.1991	4.3439	.0377
Avg	4.4589	3.3062	3.0674	3.0374	4.9978	4.9698	4.3142

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

URALIKANCHAN[059]

BU 0876

Substation No/ Name :- 214494 / 33 KV/22 KV Koregaon Mul

Feeder No / Name : 303 / Peth

FEEDER SEPERATION/PURE AG

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.3326	.4481	.431
2					.3395	.4481	.3978
3					.3326	.4481	.3647
4					.3696	.4481	.3647
5					.4066	.4801	.431
6					.4066	.5121	.431
8	.5761		.6962	.5967			
9	.9602	.8962	.8619	.8288			
10	1.2483	.9614	.9945	1.0719			
11	1.3123	1.0608	1.0608	1.0349			
12	1.1523	1.0608	.9614	1.0719			
13		.9282	.9614	1.0349			
14	1.1523	.8951	.9282	.9979			
15	1.0242	.8288	.7625	.924			
21				.3696	.3201	.3647	
22				.4066	.4801	.5304	
23				.4066	.4481	.5304	
24					.3326	.4481	.4641
Max	1.3123	1.0608	1.0608	1.0719	.4801	.5304	.4641
Min	.5761	.8288	.6962	.3696	.3201	.3647	.3647
Avg	1.0608	.9473	.9034	.7949	.3768	.4658	.4120

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

URALIKANCHAN[059]

BU 0876

Substation No/ Name :- 214494 / 33 KV/22 KV Koregaon Mul

Feeder No / Name : 304 / ASHTAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	1.1317	1.0349	1.0349	1.134	1.1317	1.1088
2	1.1317	1.1317	1.1458	1.1088	1.134	1.1317	1.1827
3	1.2449	1.2449	1.2197	1.2567	1.134	1.2449	1.2567
4	1.4335	1.4335	1.3306	1.3676	1.1706	1.4335	1.7002
5	1.6975	1.5844	1.6263	1.5524	1.39	1.8107	1.848
6	1.8861	1.5844	2.0698	1.9589	2.0119	2.0748	2.0328
7	1.8861	2.0748	2.0328	2.1437	2.1216	2.1125	2.2177
8			1.7741	.6653	1.8656	1.8861	1.885
9	1.6598	1.5844	1.4784	1.7372	1.5364	1.5844	1.6632
10	1.4335	1.1088	1.4415	1.39	1.4335	1.3676	1.4632
11	1.1317	1.1088	1.1458	1.0242	1.2449	1.0349	1.2803
12	1.0185	1.0349	.924	1.0242	1.1694	1.1088	1.2071
13		.9979	1.0349	.9145	1.1317	.924	
14	.9431	.924	1.0719	.9877	.9808	.9979	
15	.9808	.961	1.1088	.9511	.9431	1.1088	.9511
16	.9808	1.0349	1.0349	.8048	.9808	.9979	1.0974
17		.924	.961	.9145	1.0185	.9979	2.4509
18	1.0185	.8871	1.1827	1.0608	1.2071	1.1827	1.1706
19	1.5089	1.6263	1.6263	1.4266	1.6221	1.5524	
20	1.4712	1.4415	1.4784	1.2437	1.5844	1.5524	1.5364
21	1.358	1.2936	1.358	1.3169	1.4335	1.4045	1.39
22	1.2071	1.2567	1.2936	1.2803	1.2826	1.2936	1.3169
23	1.1317	1.1088	1.1827	1.1706	1.2071	1.2197	1.2803
24	1.1317	1.1317	1.0719	1.0719	1.0974	1.1317	1.1458
Max	1.8861	2.0748	2.0698	2.1437	2.1216	2.1125	2.4509
Min	.9431	.8871	.924	.6653	.9431	.924	.9511
Avg	1.3041	1.2439	1.3179	1.2253	1.3265	1.3452	1.4850

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

URALIKANCHAN[059]

BU 0876

Substation No/ Name :- 214494 / 33 KV/22 KV Koregaon Mul

Feeder No / Name : 305 / ULTRATECH

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0381	.0381	.0377	.0381	.0381
2	.0381	.0381	.0381	.0381	.0377	.0381	
3	.0381	.0381	.0381	.0381	.0377	.0381	.0381
4	.0381	.0381	.0381	.0381	.0377	.0381	.0381
5	.0381	.0381	.0381	.0381	.0377	.0381	.0381
6	.0381	.0381		.0381	.0377	.0381	.0381
7	.0381	.0381	.0381	.0381	.0377	.0381	.0381
8	.0381		.0381	.0381	.0377	.0381	.0381
9	.0381	.0381	.0381	.2286	.1509	.1524	.0381
10	.0381	.1524	.0381	.2641	.1524	.1524	.4527
11	.0381	.2286	.0381	.5281	.2286	.2286	.5281
12	.0381	.2286	.0381	.4904	.2263	.2286	.5281
13		.2286	.0381	.3018	.1524	.2286	.3772
14	.3048	.1524	.0381	.0377	.2286	.2286	.1509
15	.381	.0381	.2286	.3018	.2286	.3048	.1509
16	.0381	.0381	.2286	.1509		.2263	.0377
17		.0381	.2286	.1509	.1524	.0377	.4527
18	.0381	.0381	.0381	.0377		.0377	.4527
19	.0381	.0381	.0381	.0377	.0381	.0377	.0377
20	.2286	.1524	.0381	.0377	.0381	.2263	
21	.3048	.2667	.2286	.0377	.3048	.2263	.3018
22	.0381	.0381	.0381	.0377	.3048	.0381	.2263
23	.0381	.0381	.0381	.0377	.0377	.0381	.0377
24	.0377	.0381	.0381	.0381	.0377	.0377	.0381
Max	.381	.2667	.2286	.5281	.3048	.3048	.5281
Min	.0377	.0381	.0381	.0377	.0377	.0377	.0377
Avg	.0866	.0878	.0712	.1260	.1174	.1139	.1853

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

CHAKAN S/DN.[700] BU 4700

Substation No/ Name :- 214488 / 33 / 22 KV SHEL PIMPALGAON

Feeder No / Name : 301 / 22 KV BAHUL AG FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11	5.0968	5.144	5.3765	5.4321	2.7435	4.7554	
12	5.4321	4.7554	5.8299		6.4472	5.3041	5.7004
13	5.7674			5.4992	6.5844	5.6356	5.4992
14	5.5662	3.7037		6.1698	5.8985	5.7651	5.4992
15	5.0297		5.7651		6.0357	5.3117	5.4321
16	4.7287		5.8947		5.7613	5.2469	5.365
17	4.4932	5.0755	4.923	4.0238	5.8985		
18	4.5603	5.0069	4.9878	3.9567	5.7613		4.7325
Max	5.7674	5.144	5.8947	6.1698	6.5844	5.7651	5.7004
Min	4.4932	3.7037	4.923	3.9567	2.7435	4.7554	4.7325
Avg	5.0843	4.7371	5.4628	5.0163	5.6413	5.3365	5.3714

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

CHAKAN S/DN.[700] BU 4700

Substation No/ Name :- 214488 / 33 / 22 KV SHEL PIMPALGAON

Feeder No / Name : 303 / 22 KV BHOSE AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1948	2.0576	1.9204	1.8138	2.2634	1.9814	
2	2.1948	2.0576	1.9204	1.8138	2.332		2.332
3	2.1948	2.0576	1.9204	1.8785	2.332	1.9814	2.332
4	2.1948	2.1948	1.989	2.0081	2.332	2.0576	2.4615
5	2.2634	2.332	2.332	2.0729	2.4006	2.1262	2.6558
6	2.4006	2.6063	2.4691	2.3967	2.8807	2.6063	2.915
7	2.4691	3.0864	3.2236	3.1741	3.4979	3.2922	3.6275
8	2.9492	4.1152	4.3896	4.1457	4.6944	5.0755	4.5992
9	3.2922	4.2524		4.7287	4.6944	5.2812	5.0968
24	2.1948	1.989	1.8785			2.2024	
Max	3.2922	4.2524	4.3896	4.7287	4.6944	5.2812	5.0968
Min	2.1948	1.989	1.8785	1.8138	2.2634	1.9814	2.332
Avg	2.4349	2.6749	2.4492	2.6703	3.0475	2.9560	3.2525

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

LONAVALA[060]

BU 0884

Substation No/ Name :- 213343 / 22/22 KV NANGARGAON SWT SS

Feeder No / Name : 301 / 22 KV VALVAN

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2058					.2263
2	.2058	.2058					.2263
3	.2058	.2058					.2263
4	.2058	.2058					.2263
5	.3086	.2058					.2641
6	.4115	.4115					.415
7	.5144	.5144					.5658
8	.5144	.5144		.5658			.5658
9				.6413			
10				.5281			
11				.4527			
12				.4527			
13				.3395			
14				.3018			
15				.3395			
16			.3395	.3018	.2641	.3018	
17	.2641			.3395	.3018	.3018	.4115
18	.3772		.3772	.415	.3018	.3395	.4115
19	.4527		.5658	.4527	.4527	.4527	.4115
20	.4527		.4904	.4527	.4527	.4527	.4115
21	.4527		.4527		.415	.415	.4115
22	.4115					.3772	.4115
23						.3018	.3086
24	.2058	.2058					.2641
Max	.5144	.5144	.5658	.6413	.4527	.4527	.5658
Min	.2058	.2058	.3395	.3018	.2641	.3018	.2263
Avg	.3459	.2972	.4451	.4295	.3647	.3678	.3599

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

LONAVALA[060]

BU 0884

Substation No/ Name :- 213343 / 22/22 KV NANGARGAON SWT SS

Feeder No / Name : 302 / 22 KV WATER WORKS
Feeder KV- 22 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2058					.2641
2	.2058	.2058					.2641
3	.2058	.3086					.2641
4	.3086	.2058					.2641
5	.2058	.2058					.2641
6	.3086	.2058					.2641
7	.2058	.3086					.2641
8	.3086	.3086		.3395			.3395
9				.3018			
10				.3395			
11				.3018			
12				.3018			
13				.2641			
14				.2263			
15				.3395			
16			.3018	.2641	.3395	.3772	
17	.3018			.3018	.3018	.3018	.3086
18	.3018		.2263	.3018	.3018	.3018	.3086
19	.2641		.2641	.3018	.2641		.3086
20	.2641		.2641	.3018	.2641	.2641	.3086
21	.2641		.2263		.2641	.2641	.2058
22	.3086					.2641	.2058
23	.3086					.2641	.2058
24	.2058	.2058					.2641
Max	.3086	.3086	.3018	.3395	.3395	.3772	.3395
Min	.2058	.2058	.2263	.2263	.2641	.2641	.2058
Avg	.2609	.2401	.2565	.2989	.2892	.2910	.2690

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

LONAVALA[060]

BU 0884

Substation No/ Name :- 213343 / 22/22 KV NANGARGAON SWT SS

Feeder No / Name : 303 / 22 KV BARA BUNGLOW

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5144					.5658
2	.5144	.5144					.5658
3	.5144	.5144					.5658
4	.5144	.5144					.5658
5		.6173					.5658
6	.6173	.6173					.679
7	.7202	.7202					.8299
8	.823	.823		.9054			.7545
9				.9431			
10				.9431			
11				.9054			
12				.8299			
13				.7922			
14				.679			
15				.7167			
16			.6413	.679	.679	.6036	
17	.679			.6413	.5658	.6036	.6173
18	.7545		.6036	.7167	.6036	.6036	.6173
19	.8299		.9054	.8299	.7922	.8299	.7202
20	.8299		.9054	.8676	.7167	.8299	.7202
21	.8299		.8676		.679	.7545	.7202
22	.7202					.7167	.7202
23	.6173					.6413	.6173
24	.5144	.6173					.6036
Max	.8299	.823	.9054	.9431	.7922	.8299	.8299
Min	.5144	.5144	.6036	.6413	.5658	.6036	.5658
Avg	.6662	.6059	.7847	.8038	.6727	.6979	.6518

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

LONAVALA[060]

BU 0884

Substation No/ Name :- 213343 / 22/22 KV NANGARGAON SWT SS

Feeder No / Name : 304 / 22 KV LONAVALA BAZAR

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9259	.823					.8676
2	.823	.7202					.8676
3	.7202	.7202					.8299
4	.7202	.823					.9054
5	.9259	.823					.9431
6	1.1317	1.0288					1.2826
7	1.4403	1.4403					1.5089
8	1.6461	1.6461		.9808			1.6975
9				1.0185			
10				1.0185			
11				.9054			
12				.8299			
13				.5658			
14				.5281			
15				.4904			
16				.679	1.3203	1.0185	
17	1.2071			.6413	1.2826	1.1317	1.1317
18	1.6975		.7545	.7545	1.3203	1.2449	1.2346
19	1.8107		1.094	.9431	1.8107	1.6598	1.6461
20	1.7353		1.0562	.9054	1.7353	1.6598	1.6461
21	1.6598		.9808		1.6221	1.5844	1.4403
22	1.3375					1.358	1.3375
23	1.1317					1.0562	1.1317
24	.9259	.9259					.9808
Max	1.8107	1.6461	1.094	1.0185	1.8107	1.6598	1.6975
Min	.7202	.7202	.7545	.4904	1.2826	1.0185	.8299
Avg	1.2399	.9945	.9714	.7893	1.5152	1.3392	1.2157

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

LONAVALA[060]

BU 0884

Substation No/ Name :- 213343 / 22/22 KV NANGARGAON SWT SS

Feeder No / Name : 305 / 22 KV NANGARGAON

SHEDDABLE FEEDER HAVING WEEKLY

INDUSTRIAL Feeder KV- 22 /

STAGGERING (MIDC, EQUIVALENT)

OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9259	.5144					.8676
2	.9259	.5144					.8676
3	.823	.5144					.8299
4	.823	.5144					.7922
5	.7202	.5144					.679
6	.7202	.6173					.7545
7	.7202	.7202					.7167
8	.6173	.7202		.7545			.8299
9				1.094			
10				1.2826			
11				1.2449			
12				1.3203			
13				1.1694			
14				1.1317			
15				1.1317			
16			1.2449	1.1694	1.5844	1.0185	
17	.7922			1.1317	1.4335	.9808	1.1317
18	.7545		1.2449	1.0562	1.2071	.9054	1.0288
19	.679		.9808	.9054	1.094	.8299	.9259
20	.7167		.9808	.7922	.9808	.7922	.9259
21	.7167		.9431		.9054	.7922	.823
22	.7202					.8299	.9259
23	.6173					.8676	.823
24	.9259	.6173					.7922
Max	.9259	.7202	1.2449	1.3203	1.5844	1.0185	1.1317
Min	.6173	.5144	.9431	.7545	.9054	.7922	.679
Avg	.7624	.583	1.0789	1.0911	1.2009	.8771	.8571

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

LONAVALA[060]

BU 0884

Substation No/ Name :- 213343 / 22/22 KV NANGARGAON SWT SS

Feeder No / Name : 306 / 22 KV AUNDHE

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1029					.1509
2	.1029	.1029					.1132
3	.1029	.1029					.1509
4	.1029	.1029					.1509
5	.2058	.2058					.2263
6	.3086	.3086					.3395
7	.4115	.4115					.5281
8	.4115	.4115		.4527			.4904
9				.4527			
10				.3395			
11				.2641			
12				.2641			
13				.2641			
14				.2263			
15				.2263			
16			.2263	.2263	.2263	.1886	
17	.1886			.2263	.2641	.1886	.2058
18	.3018		.1509	.3018	.2263	.1886	.2058
19	.3395		.3395	.3395	.3395	.3395	.3086
20	.3018		.3395	.3395	.3395	.3395	.3086
21	.3018		.3018		.3018	.3395	.3086
22	.2058					.2641	.2058
23	.2058					.1886	.2058
24	.1029	.1029					.1509
Max	.4115	.4115	.3395	.4527	.3395	.3395	.5281
Min	.1029	.1029	.1509	.2263	.2263	.1886	.1132
Avg	.2311	.2058	.2716	.3018	.2829	.2546	.2531

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

LONAVALA[060]

BU 0884

Substation No/ Name :- 213343 / 22/22 KV NANGARGAON SWT SS

Feeder No / Name : 307 / 22 KV KURWANDE (R)

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.5144					.6413
2	.6173	.5144					.6413
3	.6173	.5144					.679
4		.5144					.679
5	1.1317	.6173					.7545
6	1.1317	1.0288					1.358
7	1.6461	1.5432					1.8861
8	1.6461	1.749		1.8107			1.8484
9				1.9239			
10				1.6598			
11				1.3957			
12				1.1694			
13				1.0185			
14				.9808			
15				.9431			
16			.9054	.9054	.7922	.7922	
17	.8299			.8676	.9054	.8676	.823
18	1.1317		1.0185	1.0185	.9054	.8676	.9259
19	1.2826		1.358	1.3203	1.2826	1.2449	1.2346
20	1.2826		1.3957	1.358	1.3203	1.2826	1.2346
21	1.2449		1.2826		1.2449	1.2826	
22	1.1317					1.094	1.1317
23	.823					.7922	.9259
24	.7202	.7202					.7167
Max	1.6461	1.749	1.3957	1.9239	1.3203	1.2826	1.8861
Min	.6173	.5144	.9054	.8676	.7922	.7922	.6413
Avg	1.0569	.8573	1.1920	1.2594	1.0751	1.0280	1.032

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214401 / 33 KV RAJGURUNAGAR

Feeder No / Name : 201 / Dawadi

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5228	.4572	.5304		.5041	.5121
2			.4572	.5121	.5175	.4854	.4755
3	.5544		.4938	.4938		.4854	.4938
4			.567	.695	.7392	.4755	.6219
5			.695	.695		.6584	.7499
6	1.2136		1.2803	1.134	1.4415	1.0608	1.2437
7			1.6095	.5487		1.4632	1.7741
8	1.8858		1.829		1.7741	1.8656	2.0668
9	1.6644	1.9753	1.9774		1.7558		2.0157
10	1.6644	1.957			1.6461		1.9806
11	1.6827	1.829			1.8473		1.7878
12	1.7741	1.7741			1.9936		1.9667
13	1.957	1.5912			2.0119	1.8296	1.7375
14	1.7558	1.4449			1.8473		1.6827
15	1.7375	.8413			1.7924	1.7556	1.6461
16	1.7193	1.3443			1.6095	1.7193	1.595
17			1.957		1.7741	1.8656	
18			1.5546		1.6644	1.701	
19					1.39	1.5546	
20			1.2803		1.2437	.5304	
21			1.0242		1.0242		
22			.8962	.8316	.7682		
23			.6767		.5788		
24	.499	.6348	.4755		.5601	.5041	.5487
Max	1.957	1.9753	1.9774	1.134	2.0119	1.8656	2.0668
Min	.499	.5228	.4572	.4938	.5175	.4755	.4755
Avg	1.509	1.3915	1.0769	.6801	1.3990	1.1537	1.3470

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214401 / 33 KV RAJGURUNAGAR

Feeder No / Name : 202 / Rajgurunagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9694	.9412	.905		1.0059	1.0136
2			.9774	.8688	1.0059	1.0059	.9774
3	.961		.9955	.8326		1.0059	.9955
4			1.086	1.0498	1.4118	1.0608	1.0317
5			1.2127	1.0498		1.3535	1.1584
6	1.8671		1.3756	1.2489	1.701	1.4842	1.5746
7			1.7918			1.9004	2.1719
8	2.5133		2.2986		2.0668	2.3167	2.5339
9	2.2624	2.19	2.1992		1.8461		2.2262
10	2.0814	2.1357			1.8642		2.19
11	1.828	2.0271			1.6832		1.9185
12	1.7375	1.828			1.7737		1.8473
13		1.7918			1.8642	1.8296	1.701
14		1.5384			1.7737		1.6827
15	2.1719	1.5565			1.7194	1.7372	1.6278
16	1.828	1.5927			1.7375	1.7013	
17			1.7737		1.8099	1.7924	
18			1.9728		2.0302		
19			2.1538		2.3411	2.4977	
20			2.0814		2.3777	2.4072	
21			1.8823		1.9728		
22			1.5927	1.5893	1.6289		
23			1.2127		1.2254		
24	1.0269	1.0608	.9955	.9593	1.0082	1.0425	1.0498
Max	2.5133	2.19	2.2986	1.5893	2.3777	2.4977	2.5339
Min	.961	.9694	.9412	.8326	1.0059	1.0059	.9774
Avg	1.8278	1.6690	1.5613	1.0629	1.7421	1.6094	1.6063

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214401 / 33 KV RAJGURUNAGAR

Feeder No / Name : 203 / Wada

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0943	.0732			
2			.0732			
3	.0924		.0732			
4			.0914			
5			.1097			
6	.1307		.1267			
7			.1646			
8	.1494		.1991			
9	.1463	.1715	.2241			
11				.2378		.2075
12				.2378		.2641
13				.1463	.2772	.2263
14				.2743		.2263
15				.2195	.2587	.2263
16				.2378	2.3777	.132
17					.2378	
18					.1646	
24	.0554	.0754	.0732			
Max	.1494	.1715	.2241	.2743	2.3777	.2641
Min	.0554	.0754	.0732	.1463	.1646	.132
Avg	.1148	.1137	.1208	.2256	.6632	.2138

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214401 / 33 KV RAJGURUNAGAR

Feeder No / Name : 204 / Wada GFSS SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1646	.1463	.0943		.1463	.1097
2			.1463	.0943	.1463	.1097	.1097
3	.1294		.1463	.0943		.1097	.1097
4			.1829	.132	.1848	.128	.1463
5			.2149	.1886		.1829	.1829
6	.2772		.2454	.2829	.2195	.2926	.2195
7			.2804			.2984	.2926
8	.3326		.333		.2743	.2926	.2561
9	.2561	.3772	.3326		.2012		.1886
10	.128	.1509			.1463		.128
11	.128	.1132			.3658		.3681
12	.0732	.1132			.3658		.3189
13	.0732	.0943			.3681	.3292	.3506
14	.0732	.0754			.3292		.3086
15	.0732	.0943			.3292	.3326	.3155
16	.0732				.3292	.3658	.2881
17			.1509		.2561	.3292	
18			.132		.3086	.2561	
19			.2452		.1829	.1829	
20			.2641		.2378	.2195	
21			.2452		.2378		
22			.1886	.1848	.2195		
23			.132		.128		
24	.1478	.128	.128	.1132	.1848	.1097	.1097
Max	.3326	.3772	.333	.2829	.3681	.3658	.3681
Min	.0732	.0754	.128	.0943	.128	.1097	.1097
Avg	.1471	.1457	.2067	.1481	.2508	.2303	.2237

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214401 / 33 KV RAJGURUNAGAR

Feeder No / Name : 206 / 11Kv Amul express
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3018	.2614	.2801		.2641	
2			.2241	.2801	.1646	.2641	
3	.1848		.1867	.2614		.2829	
4			.168	.1867	.1829	.2641	
5			.1494	.1494		.1509	
6	.1478		.1867	.1494	.2402	.2641	
7			.2614			.1698	
8	.2054		.2987		.3174	.2263	.1867
9	.1867	.168	.2801		.1867		.2452
10	.2987	.2801			.2987		.3206
11	.2801	.1867			.3361		.3206
12	.2241	.2801			.3361		.2452
13	.2427	.2241			.3361	.3174	.2452
14	.2054	.1867			.3174		.2452
15	.2987	.2054			.2241	.2218	.2452
16	.1867	.3206			.2241	.2241	.2452
17			.2054		.2263	.2054	
18			.168		.1886	.2427	
19			.1867		.1698	.168	
20			.2054		.1698	.2054	
21			.1867		.1886		
22			.168	.2957	.1698		
23			.168		.1698		
24	.2587	.2829	.2987	.2801	.1848	.2641	.2614
Max	.2987	.3206	.2987	.2957	.3361	.3174	.3206
Min	.1478	.168	.1494	.1494	.1646	.1509	.1867
Avg	.2267	.2436	.2120	.2354	.2316	.2335	.2561

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214401 / 33 KV RAJGURUNAGAR

Feeder No / Name : 207 / KEDARESHWAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6401	.6401	.7602		.695	
2			.5853	.7059	.6401	.695	
3	1.1643		.6036	.7059		.7133	
4			.7133	.7964	1.0974	.7133	
5			.9877	.8869		.8413	
6	1.386		1.2254	1.0136	1.386	1.0791	
7			1.4998			1.4118	
8	1.7556		1.6461		1.5729	1.5384	1.7193
9	1.4449		1.6617		1.5181		1.5729
10	1.4449	1.6289			1.4998		1.5384
11	1.39	1.3213			1.39		1.4118
12	1.2437	1.4118			1.3535		1.3756
13	1.2437	1.3394			1.2803	1.1273	1.267
14	1.1706	.9593			1.1888		1.267
15		1.1946			1.1706	1.1827	1.267
16		1.2308			1.1888	1.2071	1.2803
17			1.3032		1.1765	1.2986	
18			1.3394		1.2986	1.2803	
19			1.5927		1.4815	1.4998	
20			1.5384		1.4632	1.4815	
21			1.267		1.4083		
22			1.267	1.2382	1.2254		
23			.9774		.9877		
24	.7023	.8413	.7499	.8326	.7392	.7133	.8048
Max	1.7556	1.6289	1.6617	1.2382	1.5729	1.5384	1.7193
Min	.7023	.6401	.5853	.7059	.6401	.695	.8048
Avg	1.2946	1.1742	1.1528	.8675	1.2533	1.0924	1.3504

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214401 / 33 KV RAJGURUNAGAR

Feeder No / Name : 301 / TINEWADI FEEDER

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7842	.7682	.8048		.9335	
2			.7682	.8048	.8501	.9709	
3	.8871		.8048	.7682		.9335	
4			.8779	.9145	1.2936	.9709	
5			1.0608	1.0242		.9709	
6	1.6632		1.3535	1.39	2.0485	1.3169	
7			2.0485			1.9387	
8	2.5393		2.8898		2.7435	2.6993	2.5606
9	2.3411	2.524	1.4045		3.3288		2.8395
10	2.2314	2.7435			2.8898		2.2085
11	2.0119				2.7435		2.0233
12	1.8656				2.5606		2.0332
13		1.829			2.4874	1.8111	1.893
14		2.0485			2.3411		2.0919
15	1.4998	2.0485			2.0119	1.5154	2.1948
16	1.829	1.3394			1.134	1.7558	2.0553
17			2.8898		1.5729	2.0485	
18			2.5972		2.1719	1.0242	
19			1.9753		2.3529	1.9753	
20			1.9753		2.1216	1.9022	
21			1.5364		1.39		
22			1.6461		1.39		
23			1.39	1.4784	1.3817		
24	1.0242	.8215	.8048	.8779	.8131	.9335	.8413
Max	2.5393	2.7435	2.8898	1.4784	3.3288	2.6993	2.8395
Min	.8871	.7842	.7682	.7682	.8131	.9335	.8413
Avg	1.7893	1.7673	1.5759	1.0079	1.9813	1.4813	2.0741

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214401 / 33 KV RAJGURUNAGAR

Feeder No / Name : 302 / 22 KV Allcost & Allied NON SHEDDABLE EXPRESS HV FEEDERS
Express Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0562	.9145	1.0669		.9431	
2			.8383	.9907	.8048	1.0288	
3	.8871		.8383	.9145		1.0288	
4			.8002		.8413	1.0669	
5			.8002	.9526		.8764	
6	1.0082		.8383	.9526	.8871	.9054	
7			.9526	.8002		1.0562	
8	1.0456		1.2574		.961	1.1317	1.1431
9	1.1431	1.1812	1.39		1.1812		1.2449
10	1.2955	1.105			1.0669		1.1694
11	1.2955	1.0288			1.2574		1.2826
12	1.2193	.9907			1.2193		1.2449
13	1.1431	1.0288			1.3717		1.2449
14	1.3336	.9526			1.2574		1.2071
15	1.2193				1.2574	1.1949	1.1694
16	1.105	1.1431			1.2955	1.1812	1.2071
17			1.6766		1.2826	1.1431	
18			1.4861		1.1694	1.2574	
19			1.4861		1.1317	1.1812	
20			1.448		1.1317	1.1431	
21			1.3717		1.2071		
22			1.3717	.7842	1.1317		
23			1.4098		1.094		
24	.961		.9526	1.1431		1.0185	1.0288
Max	1.3336	1.1812	1.6766	1.1431	1.3717	1.2574	1.2826
Min	.8871	.9526	.8002	.7842	.8048	.8764	1.0288
Avg	1.1380	1.0608	1.1666	.9506	1.1342	1.0771	1.1942

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214401 / 33 KV RAJGURUNAGAR

Feeder No / Name : 303 / 22 KV SHIROLI

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2926	.2561	.2534		.2926	
2			.2561	.2534	.2561	.2926	
3			.2561	.2534		.2926	
4			.2926	.2896	.3658	.2926	
5			.3292	.2896		.3658	
6			.4024	.4344	.6154	.439	
7			.5121	.6878		.6154	
8	.7023		.7316		.8131	.8048	.9145
9	.7316	.7602	.7762		.8413		.8413
10	.695	.7602			.8048		.7316
11	.7316	.6878			.7682		.7602
12	.6219	.6516			.7682		.695
13	.6219	.543			.6219	.8131	.6219
14	.5487	.543			.5853		.5487
15	.5853				.5853	.6348	.5487
16	.6219	.543			.6219	.695	.5121
17			.6516		.5853	.6219	
18			.543		.6219	.6219	
19			.6154		.6584	.5853	
20			.5792		.5853	.5487	
21			.543		.5487		
22			.4706	.4435	.439		
23			.362		.3658		
24	.2957	.2926	.2926	.2896	.2957	.2926	.3292
Max	.7316	.7602	.7762	.6878	.8413	.8131	.9145
Min	.2957	.2926	.2561	.2534	.2561	.2926	.3292
Avg	.6156	.5638	.4629	.3550	.5874	.5130	.6503

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214438 / 33/11 KV DAWADI SUBSTATION

Feeder No / Name : 401 / KANESAR INFRA

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6722	.7319	.8488	.679	.6756	.7922	.5658
2	1.0185	.7319	.9054	.7356	.6756	.8488	.6224
3	1.0082	.8445	.9054	.7356	.7319	.7922	.6224
4	1.0082	1.0134	.8402	.9619	.8445	1.1203	.9054
5	1.2323	1.126	1.1317	1.358	1.3512	1.4712	1.3014
6	1.6409	1.3512	1.5844	1.5278	1.689	1.6975	1.4712
7	2.2634	1.689	1.6975	1.9805	2.2519	1.7924	2.1502
8	2.2634	1.7453	1.8107	2.3765	2.646	1.9044	2.4897
9	2.1823	1.4146	1.5844	2.4621	2.2965	1.358	2.2634
10	.8953	.8402	1.4146	.9512	.5658	.9054	.8488
11	.9512	2.5206	2.0936	1.3512	1.0751	2.3765	.8488
12	.8953	2.037	2.2068	1.2949	1.1317	2.2068	.8488
13	.8953	1.9805		1.0697	1.0642	2.2068	.9054
14	.8953	2.0936		.9571	.9522	1.9239	.8488
15	.9512	1.8107	2.037	.9571	.9054	1.8673	.7922
16	.8953	1.7541	1.9239	.9571	1.0185	1.7541	.7922
17	.8393	1.5844	1.7541	1.0134	.9054	1.6975	1.0185
18	.9512	1.5844	1.6409	1.0134	.9619	1.4712	1.0185
19	1.4548	1.2883	1.358	1.4075	1.3443	1.1883	1.4712
20	1.3989	1.2883	1.4146	1.4075	1.3014	1.358	1.4003
21	1.1823		1.2449	1.126	1.2449	1.1883	1.2449
22	1.0134	.9619	.9619	1.0134	1.0185	.9619	.9619
23	.7882	.7922	.7922	.7882	.7922	.7922	.7922
24	.6224	.7319	.7356	.6224	.6193	.7356	.5658
Max	2.2634	2.5206	2.2068	2.4621	2.646	2.3765	2.4897
Min	.6224	.7319	.7356	.6224	.5658	.7356	.5658
Avg	1.1633	1.3876	1.4039	1.1978	1.1693	1.4338	1.1146

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214447 / 33/11 KV WADA SUBSTATION

Feeder No / Name : 201 / 11KV WADA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3721	.3012	.3366	.3801			
2	.3544	.2835	.3189	.362			
3	.3366	.3012	.3189	.3801			
4	.3898	.3189	.3366	.3801			
5	.4557	.3681	.3721	.4755			
6	.5083	.5083	.5493	.5853			
7	.7186	.7362	.7265	.7023			
8	.8764	.7888	.8505	1.0642			
9	.8048	.7095	.724	.9922	.695	.7922	1.094
10	.4527	.5144	.6097	.4784	.6097	.6036	.4805
11	.3361	1.2696	1.1269	.4961	1.226	1.1128	.4715
12	.4108	1.363	1.0631	.4075	1.1203	1.1506	.4382
13		1.2323	1.0117	.3544	1.2826	1.2071	.4338
14	.4024	1.1763	1.0402	.3544	1.2071	1.1317	.381
15	.3511	1.1576	.9431	.3544	1.1488	1.1694	.4001
16	.9055	1.0829	.9189	.3366	1.1488	1.1043	.4191
17	.4251	1.0903	1.0749	.3921	1.1128	.9991	.3155
18	.4525	.9907	.929	.4163	.9619	.8939	.3681
19	.8192	.7811	.8383	.8954	.7499	.7442	.7888
20	.8764	.8954	.8764	.9335	.9526	.8063	.8413
21	.8002	.7621	.8573	.8002	.8002	.7537	.7888
22	.5847	.6287	.6859	.6287	.6668	.5959	.6135
23	.3721	.4075	.4527				.4572
24	.3544	.3012	.3544	.4163			
Max	.9055	1.363	1.1269	1.0642	1.2826	1.2071	1.094
Min	.3361	.2835	.3189	.3366	.6097	.5959	.3155
Avg	.5374	.7487	.7215	.5472	.9773	.9332	.5528

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214447 / 33/11 KV WADA SUBSTATION

Feeder No / Name : 202 / 11KV BHORGIRI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8507	.6516	.6878	.8145			
2	.8326	.6154	.6516	.7964			
3	.8326	.6335	.6516	.7964			
4	.8507	.6697	.6697	.7783			
5	.9774	.7421	.7602	.8779			
6	1.1403	.8869	1.0317	1.262			
7	1.6289	1.1222	1.1403	1.6448			
8	1.5927	1.5203	1.5927	1.6991			
9	1.2437	1.6617	1.7718	1.4661	1.8656	1.8296	1.358
10	1.226	1.105	1.105	1.2851	1.086	1.2449	1.2197
11	1.587	1.0642	.9362	1.9879	1.094	1.0185	2.1313
12	1.7551	.9709	.8573	2.3102	.9149	.9431	2.0957
13		.8589	.7373	2.167	.9619	.8676	1.8484
14	1.4266	.8029	.7628	1.9879	.8676	.7733	2.0576
15	1.6078	.8962	.7888	2.0271	.8745	.8676	2.2291
16	1.4969	.8962	.8322	1.8983	.8745	.8507	2.4196
17	1.5339	.961	.8495	1.7924	.9431	.9231	1.9909
18	1.267	1.2193	1.0867	1.448	1.2637	1.1222	1.6108
19	1.9624	1.7337	1.9243	2.1529	1.9204	1.8642	1.9547
20	2.0576	2.0576	2.0957	2.21	2.0767	1.9728	2.0633
21	1.8671	1.8099	1.9243	1.9052	1.9433	1.7918	1.9185
22	1.4523	1.448	1.5623	1.448	1.6004	1.448	1.6289
23	1.0136	.9955	1.0562				1.1241
24	.8869	.6154	.6697	.8507			
Max	2.0576	2.0576	2.0957	2.3102	2.0767	1.9728	2.4196
Min	.8326	.6154	.6516	.7783	.8676	.7733	1.1241
Avg	1.3517	1.0808	1.0894	1.5481	1.3062	1.2512	1.8434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214447 / 33/11 KV WADA SUBSTATION

Feeder No / Name : 203 / Kadadhe SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5959	.3142	.631	.543			
2	.5784	.3142	.6135	.5611			
3	.6135	.3142	.631	.5611			
4	.6661	.3921	.6661	.5487			
5	.7712	.4854	.7186	.6219			
6	.8322	.5788	.8495	.823			
7	.9709	.9054	1.0056	.961			
8	1.283	.8676	1.2656	1.4003			
9	1.0242	.5788	1.448	1.3321	.6584	.679	1.3957
10	.3961	.4001	.381	.4481	.4382	.547	.2957
11	.2614	1.8111	.3467	.3881	1.5466	1.7164	.3206
12	.2987	1.8111	.3772	.3881	1.4003	1.3957	.2667
13		1.8298	.3601	.3881	1.8107	1.5089	.2263
14	.3475	1.1203	.3294	.3696	1.8484	1.4146	.3048
15	.3326	1.6804	.3086	.3142		1.6221	.2858
16	.3326	1.643	.3294	.3734		1.5604	.3239
17	.3511	1.4969	.4334	.3734	1.6598	1.647	.3142
18	.5068	1.467	.4557	.3801	1.6221	1.4217	.3921
19	.8192	.8002	.8383	.8002	1.4449	.811	.6979
20	.8954	.8002	.8764	.8573	.8002	.8299	.811
21	.7621	.7049	.7621	.7621	.724	.7545	.7733
22	.5658	.5525	.6097	.5906	.6097	.5788	.6036
23	.3734	.3734	.3961				.4001
24	.5138	.3174	.5784	.5611			
Max	1.283	1.8298	1.448	1.4003	1.8484	1.7164	1.3957
Min	.2614	.3142	.3086	.3142	.4382	.547	.2263
Avg	.6127	.8983	.6338	.6238	1.2136	1.1776	.4941

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214447 / 33/11 KV WADA SUBSTATION

Feeder No / Name : 204 / 11 KV Sahyadri/Amar Prerna

Exp Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.036	.0366	.0263	.0362			
2	.0349	.0349	.0291	.0362			
3	.0337	.0389	.0274	.0373			
4	.0297	.036	.0332	.0366			
5	.0389	.0366	.0303	.0366			
6	.0594	.0446	.0349	.0549			
7	.0633	.0633	.0406	.0739			
8	.0617	.036	.036	.056			
9	.0549	.0373	.0572	.0221	.0549	.0566	.0377
10	.0377	.0191	.0381	.0114	.0381	.0377	.0185
11	.0187	.0187	.0347	.008	.0189	.0189	.0377
12	.0187	.0187	.0171	.013	.0187	.0189	.0191
13		.0187	.0171	.0072	.0189	.0189	.0189
14	.0183	.0187	.0173	.0034	.0189	.0189	.0191
15	.0185	.0187	.0343	.0255	.0171	.0189	.0191
16	.0185	.0187	.0347	.0324	.0171	.0095	.0572
17	.0554	.037	.0347	.056	.0754	.0354	.0572
18	.0543	.0572	.0526	.0543	.0754	.0492	.0724
19	.0762	.0381	.0762	.0572	.0732	.0655	.0724
20	.0953	.0572	.0762	.0572	.0762	.0686	.0739
21	.0953	.0572	.0953	.0572	.0762	.0509	.0732
22	.0566	.0572	.0762	.0572	.0572	.0383	.044
23	.0474	.0337	.0566				.0572
24	.0309	.0389	.0263	.0362			
Max	.0953	.0633	.0953	.0739	.0762	.0686	.0739
Min	.0183	.0187	.0171	.0034	.0171	.0095	.0185
Avg	.0458	.0363	.0418	.0377	.0454	.0362	.0452

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214507 / 33/11 KV KANERSAR INFRA

Feeder No / Name : 201 / KANERSAR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2328	.1734	.2427	.2427	.2561	.2743
2	.2641	.2149	.1734	.2427	.2427	.2378	.2926
3	.2641	.2507	.2058	.2427	.2614	.2378	.2926
4	.3584	.3012	.2572	.2801	.2987	.3292	.3109
5	.5281	.4031	.3429	.4066	.4294	.4163	.4887
6	.6161	.463	.6516	.6283	.6535	.4887	.6584
7	.6908	.6859	.7545	.6767	.7655	.6154	.695
8	.6908	.8059	.823	.7316	.7282	.7701	.6219
9	.5041	.703	.6859	.5853	.5415	.7059	.5304
10	.4294	.3547	1.1346	.4435	.7701	.3841	.3961
11	.5316	.2534	.2587	.7716	.6878	.2926	.6878
12	.5487	.2534	.2427	.9088	.7421	.2587	.6697
13	.6335	.2378		.823	.6878	.2012	.6335
14	.5658	.2195		.6859	.6154	.181	.6154
15	.4801	.2378	.2587	.5658	.5973	.2172	.5792
16	.4973	.2378	.2987	.6859	.5611	.2353	.5611
17	.5144	.2743	.2957	.6001	.4887	.2715	.5611
18	.3944	.3841	.3921	.463	.4525	.2926	.4344
19	.5975	.5359	.5544	.5601	.5041	.3658	.5788
20	.6161	.567	.567	.5788	.5788	.5138	.5601
21	.5228	.4938	.4938	.4854	.5228	.4656	.4854
22	.3921	.4024	.4066	.3734	.4108	.3475	.3734
23	.2987	.2957	.3142	.2987	.2829	.2534	.3018
24	.2641	.2172	.1715	.2614	.2614	.2195	.2353
Max	.6908	.8059	1.1346	.9088	.7701	.7701	.695
Min	.2641	.2149	.1715	.2427	.2427	.181	.2353
Avg	.4778	.3761	.4298	.5226	.5136	.3565	.4932

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214507 / 33/11 KV KANERSAR INFRA

Feeder No / Name : 202 / VARUDE SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4163	.4294	.4066	.3988	.3898	.4108	.3982
2	.3801	.4481	.4066	.4031	.3721	.3921	.4572
3	.362	.4668	.439	.4681	.4075	.3961	.4938
4	.4706	.5228	.4938	.5144	.4854	.4668	.567
5	.6805	.6722		.583	.6173	.6722	.6838
6	.9036	.7842	.7602	.6859	.8402	.7655	.7947
7	1.1393	.8775	.8059	.9945	1.046	.8775	1.0608
8	1.3375	.7095	.7522	1.3717	1.3546	.8029	1.2803
9	1.1831	.5415	.6447		1.2003	.6722	1.2803
10	.4294	.4668	.5249	.4066	.4338	.5068	.3961
11	.2987	1.7318	1.2003	.3921	.3734	1.6118	.3174
12	.3174	1.406	1.3889	.3361	.3547	1.6297	.3018
13	.2829	1.406		.2801	.3174	1.7364	.2452
14	.3361	1.3717		.2987	.3018	1.4198	.3018
15	.2801	1.2003	1.2483		.3547	1.2403	.2641
16	.3921	1.1145	1.3032	.3547	.4108	1.3032	.3174
17	.3734	1.0288	1.2003	.4108	.3921	1.2071	.4294
18	.5041	.7888	.9922	.5228	.4481	.905	.4668
19	.7468	.7316	.5175	.7468	.6908	1.2752	.7468
20	.7468	.6584	.7133	.7655	.6908	.6697	.7655
21	.6722	.6584	.6219	.6908	.6535	.6219	.6535
22	.5601	.567	.5175	.5788	.5601	.5249	.5788
23	.4854	.4755	.4435	.4854	.4904	.4477	.4904
24	.3801	.4481	.4435	.3721	.3801	.4294	.3258
Max	1.3375	1.7318	1.3889	1.3717	1.3546	1.7364	1.2803
Min	.2801	.4294	.4066	.2801	.3018	.3921	.2452
Avg	.5699	.8127	.7535	.5482	.5652	.8744	.5674

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214507 / 33/11 KV KANERSAR INFRA

Feeder No / Name : 203 / PUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0366	.0373	.0373	.0354	.037	.0377	.0366
2	.0366	.0373	.0373	.0358	.037	.0377	.0366
3	.0366	.0373	.0373	.0358	.037	.0377	.0362
4	.0366	.056	.0373	.0537	.0549	.0377	.0362
5	.0549	.056	.0554	.0532	.0549	.0566	.0362
6	.0732	.056	.0914	.0526	.0732	.0754	.0914
7	.1086	.0747	.1086	.0693	.1097	.112	.1097
8	.1267	.0934	.0895	.1029	.1086	.112	.1086
9	.0905	.0747	.0724	.0857	.0914	.0754	.1097
10	.0754	.0566	.0732	.0747	.0566	.0709	.0377
11	.0373	.12	.1372	.0373	.0377	.1254	.0377
12	.0373	.12	.1227	.0373	.0377	.1433	.0377
13	.0377	.1029		.0373	.0377	.1448	.0377
14	.0373	.2058		.0189	.0377	.1433	.0377
15	.0373	.1029	.1075	.0373	.0377	.1254	.0377
16	.0373	.0343	.1402	.0373	.0377	.1267	.0377
17	.0373	.0686	.1214	.0373	.0377	.1097	.0377
18	.056	.1029	.1267	.056	.0566	.0732	.0566
19	.0934	.0924	.0747	.0934	.0943	.1463	.0566
20	.0747	.0924	.0924	.0747	.0943	.0732	.0943
21	.0747	.0739	.0739	.0747	.0754	.0732	.0754
22	.056	.0554	.056	.0373	.0566	.0554	.0566
23	.0373	.037	.0373	.0373	.0377	.0366	.0377
24	.0366	.0373	.0373	.0362	.0187	.0377	.0179
Max	.1267	.2058	.1402	.1029	.1097	.1463	.1097
Min	.0366	.0343	.0373	.0189	.0187	.0366	.0179
Avg	.0569	.0760	.0803	.0521	.0566	.0861	.0541

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214508 / 33/11 KV KANERSAR SEZ

Feeder No / Name : 201 / 9 PLANETS

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.2641	.4108	.415	.3734	.2241	.3395
2	.2801	.2641	.4108	.3772	.3547	.2241	.3395
3	.2987	.2452	.4294	.3961	.3734	.2241	.3018
4	.2987	.2452	.3921	.3772	.3921	.2263	.3018
5	.2801	.2452	.3921	.3547	.3734	.2452	.2829
6	.2801	.2641	.3734	.3206	.3734	.2452	.2829
7	.2614	.2641	.3734	.2987	.3772	.3018	.3018
8	.2801	.3772	.4287	.3395	.3921	.2263	.3018
9	.2829	.3547	.4668	.4338	.3921	.3361	.2614
10	.2614	.3734	.4904	.5788	.415	.2801	.2801
11	.2641	.4294	.3395	.5658	.3921	.3174	.2987
12	.2427	.3174	.3772	.5658	.3395	.2987	.3547
13	.2427	.4108	.3206	.547	.3206	.3174	.2987
14	.2452	.4854	.3584	.547	.3206	.3361	.2987
15	.2427	.4854	.3772	.5281	.3395	.3395	.2801
16	.2452	.5041	.415	.5093	.3361	.3174	.3734
17	.2452	.5228	.4854		.3772	.3734	.2801
18	.2641	.4481	.5093		.3584	.3361	.2801
19	.2452	.3921	.3961		.2452	.3018	.3921
20	.2427	.4481	.415		.2614	.3018	.3547
21	.2614	.3734	.5228		.2829	.8676	.2987
22	.2641	.4294	.4715		.2614	.3174	.2987
23	.2641	.4481	.4338		.2427	.3395	.2987
24	.2801	.2641	.3772	.547	.3772	.2241	.3395
Max	.2987	.5228	.5228	.5788	.415	.8676	.3921
Min	.2427	.2452	.3206	.2987	.2427	.2241	.2614
Avg	.2647	.3690	.4153	.4530	.3447	.3134	.3100

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214509 / 33/11 KV NIMGAON SEZ

Feeder No / Name : 201 / RAJ PROCESS

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1698	.1698	.1307	.1132	.112	.1698
2	.1132	.1509	.168	.112	.1132	.112	.132
3	.1132	.1509	.1698	.112	.1132	.112	.132
4	.1132	.1509	.1698	.0747	.1132	.112	.132
5	.1132	.132	.1698	.0747	.1132	.112	.132
6	.132	.132	.1698	.0747	.1132	.112	.1886
7	.132	.132	.1886	.0747	.1132	.1307	.1886
8	.1509	.132	.2452	.0747	.1132	.1307	.2263
9	.2075	.2452	.2241	.0747	.3018	.2054	.3018
10	.2075	.1886	.1494	.056	.2452	.2263	.3018
11	.2263	.1867	.1494	.0754	.3961	.3206	.3395
12	.2263	.2054	.2054	.0754	.3206	.2641	.168
13	.1886	.2427	.112	.0754	.168	.1886	.3018
14	.3018	.2452	.1494	.0754	.3018	.1886	.2829
15	.3018	.2427	.168	.0566	.056	.2263	.2829
16	.3018	.2829	.1494	.0566	.0373	.2263	.3018
17	.3395	.2801	.112	.0754	.3584	.3018	.2614
18	.2829	.2641	.056	.0754	.2614	.2263	.112
19	.2641	.2452	.0934	.0943	.3584	.2263	.1867
20	.2641	.2263	.112	.1132	.168	.2263	.2829
21	.2263	.3961	.112	.1132	.168	.1886	.2829
22	.2263	.2075	.112	.1132	.1307	.1886	.2829
23	.2075	.2054	.112	.1132	.1307	.1886	.2614
24	.1698	.1886	.168	.1307	.1132	.1307	.1698
Max	.3395	.3961	.2452	.1307	.3961	.3206	.3395
Min	.1132	.132	.056	.056	.0373	.112	.112
Avg	.2075	.2085	.1515	.0876	.1842	.1857	.2259

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214509 / 33/11 KV NIMGAON SEZ

Feeder No / Name : 401 / NIMGAON SEZ - KANERSAR SEZ NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (NON-CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3014	1.3014	1.1317	1.0751	.679	1.0185	1.0751
2	1.3014	1.2449	1.1317	1.0751	.6224	1.0185	1.0751
3	1.3014	1.1883	1.1317	1.0751	.6224	1.0185	1.0751
4	1.358	1.1883	1.1317	1.0751	.6224	1.0185	1.0751
5	1.358	1.1883	1.1317	1.0751	.6224	1.0185	1.0751
6	1.358	1.2449	1.1317	.8488	.7922	1.0185	1.0751
7	1.358	1.2449	1.1317	.7282	.9054	1.0185	1.1317
8	1.4146	1.2449	1.1317	.7282	.9619	1.1317	1.1317
9	1.4146	1.358	1.2449	.7282	1.2449	1.2449	1.2449
10	1.5278	1.1317	1.1883	.7282	1.2449	1.358	1.358
11	1.5278	1.1317	1.1883	.679	1.358	1.358	1.3014
12	1.4146	1.1317	1.5278	.6224	1.358	1.358	1.4712
13	1.4146	1.1883	1.4146	.6224	1.0751	1.358	1.1317
14	1.4712	1.1883	1.3014	.6224	1.6409	1.5278	1.2449
15	1.4146	1.3014	1.358	.6224	1.3014	1.5278	1.358
16	1.3014	1.358	1.358	.6224	1.1317	1.5278	1.5844
17	1.2449	1.5844	1.3014	.6224	1.4146	1.3014	1.5844
18	1.3014	1.5278	1.1883	.5658	1.3014	1.1317	1.1317
19	1.4712	1.4712	1.0751	.6224	.7842	1.1317	1.1317
20	1.5844	1.3014	1.0185	.6224	1.1317	1.1317	1.2449
21	1.358	1.358	1.1883	.679	1.0185	1.1317	1.2449
22	1.358	1.358	1.358	.679	1.1883	1.0751	1.2449
23	1.3014	1.3014	1.1317	.6224	1.2449	1.0751	1.1883
24	1.3014	1.3014	1.2449	1.0751	.679	1.0185	1.0751
Max	1.5844	1.5844	1.5278	1.0751	1.6409	1.5278	1.5844
Min	1.2449	1.1317	1.0185	.5658	.6224	1.0185	1.0751
Avg	1.3816	1.2849	1.2142	.7674	1.0394	1.1883	1.2189

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214509 / 33/11 KV NIMGAON SEZ

Feeder No / Name : 402 / Mars India Ltd

Feeder KV- 33 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	1.1317	1.0185	1.0185	.5658	.8488	
2	1.1317	1.0751	1.0185	1.0185	.5093	.8488	.8488
3	1.1317	1.0185	1.0185	.9619	.5093	.8488	.8488
4	1.1317	1.0185	1.0185	.9619	.5093	.8488	.8488
5	1.1317	1.0185	1.0185	.7842	.5093	.8488	.8488
6	1.1317	1.0751	.9054	.7842	.679	.8488	.8488
7	1.1317	1.1317	.9619	.6722	.8488	.9619	.9054
8	1.1883	1.1317	.9054	.6722	.8488	1.0185	.9054
9	1.1883	1.1317	1.0185	.6161	.9619	1.0185	.9619
10	1.3014	.9619	.9619	.5601	.9619		1.0185
11	1.2449	.9619	1.0751	.5658	.9619	1.0185	1.0185
12	1.2449	.9054	1.3014	.5658	.9619	1.0185	1.1317
13	1.1883	.9054	1.358	.5658	.9619	1.0185	.9619
14	1.1317	.9054	1.1317	.5658	1.358	1.1317	.9619
15	1.0751	.9619	1.1883	.5658	1.358	1.0185	1.0751
16	1.0185	1.1317	1.1317	.5093	1.1317	1.0185	1.3014
17	.9054	1.2449	1.1883	.5093	1.0751	1.0185	1.2449
18	1.0185	1.2449	1.1317	.5093	1.0185	.9054	.9619
19	1.3014	1.1317	1.0185	.5093	.9619	.9054	.9619
20	1.3014	1.0751	.9619	.5093	.9619	.9054	.9619
21	1.1883	1.1883	1.0751	.5658	.9619	.9054	.9619
22	1.1317	1.1317	1.2449	.5658	.9619	.8488	.9619
23	1.1317	1.0751	1.0751	.5093	.8488	.8488	.9054
24	1.1317	1.1317	1.0751	1.0185	.5658	.8488	.8488
Max	1.3014	1.2449	1.358	1.0185	1.358	1.1317	1.3014
Min	.9054	.9054	.9054	.5093	.5093	.8488	.8488
Avg	1.1506	1.0704	1.0751	.6702	.8747	.9349	.9693

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

TALEGAON[061]

BU 0892

Substation No/ Name :- 213314 / 22 KV AMBI

Feeder No / Name : 303 / General Motors
Feeder KV- 22 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.5953	5.144	5.487	5.487	2.9492	5.2812	5.4184
2	4.6639	5.2812	5.3498	5.4184	2.8121	5.487	5.7613
3	4.5268	5.2126	4.8011	5.4184	2.6749	5.6242	5.5556
4	4.6639	5.487	4.6639	5.487	2.7435	5.2812	5.0755
5	4.5268	5.5556	4.4582	5.3498	3.0864	4.8697	5.2126
6	4.4582	5.487	4.1152	4.6639	2.9492	4.1152	6.2414
7	4.9383	5.6242	3.9095	4.3896	4.4582	4.1838	5.5556
8	5.2126	4.9383	4.5268	4.3896	3.9781	5.144	6.5844
9	6.3786	6.653	5.487	4.1152	5.487	6.0357	6.9273
10	7.6818	6.31	6.0357	3.9781	5.6242	6.9273	7.8875
11	6.7215	6.5158	6.31	3.4979	5.6242	6.9959	7.9561
12	7.6818	6.4472	6.5844	4.0466	5.487	7.5446	8.5734
13	7.2017	6.8587	5.8299	4.2524	5.6242	6.653	8.3676
14	7.5446	6.3786	6.1728	3.6351	5.6584	5.9671	7.9561
15	7.3388	5.9671	6.4472	3.5322	4.4582	7.4074	7.8875
16	6.7215	6.8587	7.2702	2.8807	5.144	7.8189	8.5734
17	6.9959	6.31	6.1728	2.8121	4.6639	7.6132	7.9561
18	6.3786	7.5446	5.2126	2.8807	5.2812	6.9273	6.5158
19	4.8697	5.487	5.2126	2.8121	4.8011	6.1043	5.6927
20	4.3896	4.6639	6.1728	2.4691	4.1152	5.6242	4.6639
21	5.3498	5.6927	5.7613	2.6063	4.1152	5.8985	5.487
22	5.5556	4.8011	5.7613	3.155	3.9095	5.6242	5.3498
23	5.2126	5.5556	5.8299	3.0178	3.8409	5.3498	5.2812
24	4.6639	4.8697	5.2812	5.5556	3.0864	3.7723	5.5556
Max	7.6818	7.5446	7.2702	5.5556	5.6584	7.8189	8.5734
Min	4.3896	4.6639	3.9095	2.4691	2.6749	3.7723	4.6639
Avg	5.7613	5.8185	5.5356	3.9938	4.2738	5.9271	6.5015

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

TALEGAON[061]

BU 0892

Substation No/ Name :- 213314 / 22 KV AMBI

Feeder No / Name : 304 / 22 KV MANAS EXPRESS FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
 (01 Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.583	.6173	.4801	.4458	.6859	.5144
2	.5144	.5487	.583	.4458	.4115	.6516	.5144
3	.4801	.5144	.583	.4801	.3429	.6173	.4801
4	.4458	.5144	.4801	.4458	.3772	.5487	.4458
5	.4115	.4801	.4115	.4458	.3429	.4801	.4115
6	.4458	.4115	.4115	.4115	.3086	.3772	.3086
7	.5144	.4115	.4115	.3429	.3429	.5487	.4115
8	.6173	.583	.6516	.3772	.4801	.5487	.6859
9	.6859	.6516	.6859	.3772	.6516	.6859	.6859
10	.6859	.7202	.6173	.3429	.6859	.6859	.6859
11	.6859	.823	.7545	.3772	.7202	.7202	.7202
12	.6516	.7888	.6516	.4115	.6516	.6516	.583
13	.5144	.5487	.4801	.3086	.6173	.4801	.583
14	.7202	.7202	.6173	.3429	.6516	.7888	.6173
15	.6516	.6516	.6173	.3429	.7202	.6859	.6859
16	.6516	.6859	.6859	.3086	.6859	.6173	.6859
17	.6859	.7545	.6516	.3086	.6859	.6173	.7545
18	.583	.7202	.4801	.2743	.7202	.6173	.7202
19	.5144	.5487	.3772	.3086	.5144	.5144	.4115
20	.4801	.5487	.4801	.3086	.5487	.5487	.4115
21	.5144	.583	.4801	.3086	.583	.5144	.4801
22	.5487	.5487	.5144	.3429	.6516	.5487	.4458
23	.4801	.5487	.5487	.3086	.6859	.4801	.5144
24	.5487	.5144	.5487	.5144	.3086	.7202	.5144
Max	.7202	.823	.7545	.5144	.7202	.7888	.7545
Min	.4115	.4115	.3772	.2743	.3086	.3772	.3086
Avg	.5630	.6001	.5558	.3715	.5473	.5973	.5530

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

TALEGAON[061]

BU 0892

Substation No/ Name :- 213314 / 22 KV AMBI

Feeder No / Name : 306 / 22 KV Nigade Feeder (Old SHEDDABLE FEEDER HAVING WEEKLY
 Shri Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.4801	.4801	.4115	.3772	.4115	.4115
2	.4801	.4801	.4801	.4115	.3772	.4115	.4115
3	.5144	.4801	.4801	.3772	.3772	.3772	.4115
4	.5144	.4458	.4801	.3429	.3772	.4115	.4115
5	.5487	.5144	.5144	.3429	.3772	.4801	.4801
6	.5487	.6173	.5487	.5144	.6173	.6173	.6173
7	.6859	.7888	.6859	.7545	.7888	.7545	.8573
8	.7545	.8916	.7545	.8573	.823		.823
9	.8916	.823	.8916	.8916	.8916		.9602
10	.7888	.8916	1.0288	.9602	.8916		.7888
11	.823	.823	.9602	.823	.9259	1.0288	.823
12	.8573	.823	.9259	.8916	.8916	.9945	.823
13	.823	.823	.8573	.823	.823	.8573	.8573
14	.6516	.7545	.7545	.7545	.7545	.823	.8916
15	.7888	.7545	.823	.823	.823	.9602	.8573
16	.823	.6859	.823	.7888	.8916	1.0288	.8916
17	.823	.823	.823	.7545	.8916	.8916	.7545
18	.823	.7545	.6859	.7545	.9602	.823	.823
19	.823	.7545	.7545	.823	.8573	.8573	.823
20	.7545	.7545	.6859	.7202	.823	.6859	.6173
21	.6516	.7202	.7202	.7202	.6859	.6516	.4801
22	.583	.6859	.583	.6173	.6173	.5487	.4115
23	.5487	.5487	.5144	.5487	.4801	.4801	.4115
24	.5487	.5144	.4801	.4801	.5144	.4801	.4801
Max	.8916	.8916	1.0288	.9602	.9602	1.0288	.9602
Min	.4801	.4458	.4801	.3429	.3772	.3772	.4115
Avg	.6887	.6930	.6973	.6744	.7016	.6940	.6716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

WADGAON MAVAL S/DN.[769] BU 4769

Substation No/ Name :- 213344 / 22/22 KV FINOLEX S/STN

Feeder No / Name : 301 / 22 KV Finolex Industries NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3624	2.0576	2.4387	2.2481	2.3624	2.3624	2.6673
2	2.4006	2.0576	2.4387	2.3624	2.4006	2.3243	2.553
3	2.2862	2.2862	2.4006	2.553	2.4768	2.2862	2.4387
4	2.21	2.21	2.3243	2.2862	2.2481	2.2862	2.4387
5	2.0576	2.1338	2.0957	2.21	2.21	2.2862	2.2862
6	1.9052	1.9052	1.9814	1.9814	2.0195	1.9814	2.1338
7	1.829	1.6766	1.7528	1.7528	1.8671	1.8671	2.1719
8	2.21	2.1338	2.2862	2.0576	2.1338	2.3243	2.2481
9	2.4006	2.2862	2.3624	2.3624	2.5911	2.4387	2.4387
10	2.2481	2.2862	2.3624	2.4006	2.5149	2.2481	2.4768
11	2.1719	2.3243	2.4006	2.3243	2.7054	2.4768	2.2481
12	2.0576	2.4006	2.2862	2.2862	2.4006	2.1719	2.5149
13	2.1338	2.0195	2.21	2.2481	2.3243	2.5149	2.2862
14	2.3243	2.21	2.1719	2.2481	2.4387	2.3624	2.1338
15	2.3624	2.0195	1.7528	2.0957	1.9433	2.2862	2.0576
16	2.4768	2.4387	2.21	2.2481	2.3624	2.3243	2.4387
17	2.3243	2.2862	2.3624	2.2481	2.4768	2.4006	2.5149
18	2.1719	2.1719	2.3243	2.3624	2.2862	2.21	2.0576
19	2.4006	2.3624	2.4768	2.4768	2.6292	2.1338	2.4768
20	2.2481	2.3243	2.4768	2.6292	2.4387	2.0576	2.4006
21	1.8671	2.0195	2.0195	2.2862	2.0576	2.21	2.3624
22	.1524	2.2862	2.1719	2.3624	2.1338	2.2862	2.3243
23	1.1812	2.0957	1.9052	2.4768	1.8671	1.9052	2.0576
24	2.2862	1.9814	2.3624	2.5149	2.2862	2.4387	2.7816
Max	2.4768	2.4387	2.4768	2.6292	2.7054	2.5149	2.7816
Min	.1524	1.6766	1.7528	1.7528	1.8671	1.8671	2.0576
Avg	2.0862	2.1656	2.2323	2.2926	2.2989	2.2576	2.3545

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

WADGAON MAVAL S/DN.[769] BU 4769

Substation No/ Name :- 213344 / 22/22 KV FINOLEX S/STN

Feeder No / Name : 302 / 22 KV Finolex Plasson NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.8383	1.0288	1.0669	1.0669	1.0288	.8764
2	.9526	.9145	1.0288	1.105	1.105	1.0288	.9145
3	.9145	.9907	1.0288	1.1431	.9526	1.0288	.9907
4	.9145	.9907	1.0669	1.2193	.0762	1.0288	.9145
5	.9526	.9145	1.0288	1.0288	.9145	1.0669	.9145
6	.9145	.8764	1.0669	1.0669	.8764	1.0288	.9526
7	.9526	.8383	1.0669	.9907	.9526	.9907	.9526
8	.9526	.7621	1.0288	.9145	.9907	.9526	.9526
9	1.0669	.9145	.9145	1.0669	1.0288	1.0288	.8764
10	1.1431	1.1812	1.0669	1.0669	.9526	.8764	.9145
11	1.1431	1.0288	.9526	1.0669	.8764	1.105	1.0288
12	.9907	1.2193	1.0669	.9907	.9907	1.0669	.9526
13	.8764	1.1431	1.0288	1.0288	1.0288	.8764	.9145
14	1.105	1.1812	1.1431	.9907	1.0669	.724	.8383
15	1.0288	1.1812	1.1812	1.0288	.9907	.7621	.9907
16	1.105	1.1812	1.105	1.0288	.9907	.8383	1.105
17	1.1431	1.0288	1.0669	.9145	1.0669	.9145	1.1431
18	1.105	1.105	1.1431	.9907	.9907	.9145	1.2193
19	1.1812	1.1431	1.2574	1.0669	1.0669	.9145	1.2574
20	1.1812	1.0669	1.1431	.9907	.9907	.9145	1.2193
21	1.1431	1.0288	1.1812	.9526	1.105	.8383	1.1431
22	.1143	1.105	1.105	1.0288	.9907	1.1431	1.0669
23	.8764	1.105	1.105	.9526	1.0288	.9907	1.1812
24	.9145	.9145	.8764	1.105	1.0669	.8764	1.0288
Max	1.1812	1.2193	1.2574	1.2193	1.105	1.1431	1.2574
Min	.1143	.7621	.8764	.9145	.0762	.724	.8383
Avg	.9828	1.0272	1.0701	1.0336	.9653	.9558	1.0145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

WADGAON MAVAL S/DN.[769] BU 4769

Substation No/ Name :- 213344 / 22/22 KV FINOLEX S/STN

Feeder No / Name : 303 / 22 KV Finolex Cable

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4387	1.7528	2.4768	2.3243	2.2862	2.4768	2.2862
2	2.2862	1.829	2.4387	2.2862	2.3624	2.5149	2.3624
3	2.3624	1.9052	2.3624	2.3243	2.2481	2.2481	2.21
4	2.1719	1.829	2.3243	2.3624	2.2862	2.3624	2.2862
5	2.0576	1.829	2.0576	2.0957	2.2862	2.2862	2.21
6	1.9052	1.9052	2.1338	2.0195	2.1719	2.1338	2.1719
7	1.9433	1.7909	1.9052	1.829	2.0195	1.9433	1.9814
8	1.7909	1.4861	1.7147	1.7147	1.7528	1.6385	1.7909
9	1.6385	1.1431	1.6385	1.6385	1.4861	1.4098	1.9433
10	1.2574	.9907	1.6004	1.1431	1.0288	1.1431	1.2193
11	1.0288	.8764	1.3336	.8383	.4572	.8383	.8383
12	.3048	.4191	.9907	.4954	.5335	.6097	.724
13	.3429	.2667	.5716	.8383	.2286	.6097	.381
14	.6478	.4572	.3429	.4191	.2667	.724	1.6004
15	1.0288	.8764	.6097	1.1431	.4572	.8002	.6097
16	1.5623	1.3336	1.6385	1.7528	1.0669	1.2574	1.4098
17	2.1338	1.9814	2.0195	1.9814	1.829	1.7147	2.1338
18	2.2862	2.3243	2.4006	2.5149	2.2481	2.0576	2.6673
19	2.2481	2.8578	2.2862	2.8959	2.4768	2.1338	2.4387
20	2.3243	2.5149	2.4006	2.6292	2.4006	2.21	2.7054
21	2.4006	2.4387	2.2481	2.2862	2.21	1.9814	2.3243
22		2.553	2.1338	2.21	2.21	2.0576	2.5149
23	.5335	2.0576	2.0576	2.2481	1.9814	2.0576	2.0576
24	2.3624	1.6004	2.4387	2.21	2.3243	2.4006	2.3243
Max	2.4387	2.8578	2.4768	2.8959	2.4768	2.5149	2.7054
Min	.3048	.2667	.3429	.4191	.2286	.6097	.381
Avg	1.6981	1.6258	1.8385	1.8417	1.6924	1.7337	1.8830

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

WADGAON MAVAL S/DN.[769] BU 4769

Substation No/ Name :- 213387 / 22/22 KV BELAJ S/STN

Feeder No / Name : 302 / 22 KV Rajapuri

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2286	.2241	.2263	.2641	.2667	.2241
2	.2263	.2286	.2241	.3395	.2263	.2667	.2241
3	.2614	.3429	.2614	.3395	.2263	.3048	.2263
4	.2614	.4954	.2241	.3772	.2641	.3048	.2241
5	.3734	.4954	.2614	.3772	.3018	.3048	.2614
6	.4108	.5335	.2987	.415	.3395	.3429	.3361
7	.4481	.5716	.3734	.415	.5281	.381	.4108
8	.5601	.5716	.3772	.415	.6413	.6097	.5601
9	.5228	.6097	.4854	.6413	.5658	.5716	.5601
10	.4854			.679	.6036	.5716	.5975
11	.4854		.5228	.6413		.5335	.5975
12			.6348	.6413	.679	.5335	.5975
13	.4527	.3048	.5975	.5281	.5281	.4572	.6348
14	.4108	.4191	.5601	.6036	.4527	.5335	.679
15	.4108	.6097	.6348	.5658	.4904	.4854	.6722
16	.4108	.5281	.5601	.6036	.5281	.4481	.6722
17	.4108	.415	.5975	.5658	.4954	.4108	.6478
18	.4527	.1886	.6036	.4527	.3048	.4108	.6478
19	.381	.3361	.5281	.4527	.3048	.3734	.381
20	.381	.3734	.5281	.415	.3048	.3734	.3429
21	.3048	.2614	.4527	.3395	.3048	.3361	.3048
22	.3048	.2614	.415	.3018	.3048	.2241	.3048
23	.2667	.2614	.3772	.2641	.2667	.2241	.2667
24	.2641	.2667	.2241	.2263	.2641	.2286	.2263
Max	.5601	.6097	.6348	.679	.679	.6097	.679
Min	.2263	.1886	.2241	.2263	.2263	.2241	.2241
Avg	.3788	.3954	.4333	.4511	.3995	.3957	.4417

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

WADGAON MAVAL S/DN.[769] BU 4769

Substation No/ Name :- 213465 / 22/22 KV LODHA BELMONDO

S/STN

Feeder No / Name : 301 / 22 KV LODHA SUBSTATION NO.

SHEDDABLE RURAL

1 Feeder KV- 22 / OUTGOING

DATE	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0229	.0229	.0229	.0229	.0229	.0229
Max	.0229	.0229	.0229	.0229	.0229	.0229
Min	.0229	.0229	.0229	.0229	.0229	.0229
Avg	.0229	.0229	.0229	.0229	.0229	.0229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

WADGAON MAVAL S/DN.[769] BU 4769

Substation No/ Name :- 213465 / 22/22 KV LODHA BELMONDO

S/STN

Feeder No / Name : 302 / 22 KV LODHA SUBSTATION NO.

SHEDDABLE RURAL

2 Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0669	1.0288	.9907	1.0288	.9526
2	1.0288	.9145	.9145	.9526	1.105
3	1.0288	.9526	1.4098	.9907	1.2574
4	1.105	1.2193	1.6385	1.0288	1.1431
5	1.2574	1.3717	1.7147	1.0669	1.0288
6	1.5623	1.5242	1.829	1.5623	1.5242
7	1.7909	1.6004	1.8671	1.7147	1.7528
8	1.9052	1.9433	1.829	1.9814	1.8671
9	1.9433	1.9052	1.9433	2.1338	1.9052
10	2.0576	1.8671	1.8671	2.2862	2.0576
11	2.0957	2.1719	2.1338	2.3624	2.0576
12	2.0957	2.0957	1.9814	2.1338	1.9814
13	1.7909	2.0576	1.9814	1.9814	1.8671
14	1.7528		1.829	1.829	
15	1.9052		1.9433	1.7528	
16	1.9052	1.9052	1.8671	1.6766	
17	1.829	1.7528	1.9814	1.7528	
18	1.7528	1.6385	1.9052	1.9433	
19	1.6766	1.5623	1.8671	1.9052	
20	1.6004	1.5242	1.7909	1.7147	
21	1.5242	1.4861	1.5623	1.5623	
22	1.3717	1.448	1.3717	1.3717	
23	1.2955	1.1431	1.2955	1.1431	
24	1.0669	1.105	1.1431	1.1812	1.105
Max	2.0957	2.1719	2.1338	2.3624	2.0576
Min	1.0288	.9145	.9145	.9526	.9526
Avg	1.6004	1.5553	1.6940	1.6274	1.5432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

WADGAON MAVAL S/DN.[769] BU 4769

Substation No/ Name :- 213465 / 22/22 KV LODHA BELMONDO
S/STNFeeder No / Name : 303 / 22 KV LODHA SUBSTATION NO.
3 Feeder KV- 22 / OUTGOING

SHEDDABLE RURAL

DATE	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0038	.0038	.0038	.0038	.0038	.0038
Max	.0038	.0038	.0038	.0038	.0038	.0038
Min	.0038	.0038	.0038	.0038	.0038	.0038
Avg	.0038	.0038	.0038	.0038	.0038	.0038

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

WADGAON MAVAL S/DN.[769] BU 4769

Substation No/ Name :- 213465 / 22/22 KV LODHA BELMONDO

S/STN

Feeder No / Name : 304 / 22 KV LODHA SUBSTATION NO.

SHEDDABLE RURAL

4 Feeder KV- 22 / OUTGOING

DATE	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6						.0191
14	.0191					
15	.0191					
24	.0191	.0191	.0191	.0191	.0191	.0191
Max	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.0191	.0191	.0191	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

WADGAON MAVAL S/DN.[769] BU 4769

Substation No/ Name :- 213465 / 22/22 KV LODHA BELMONDO

S/STN

Feeder No / Name : 305 / 22 KV LODHA METERING KIOSK

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0876	.0876	.0953	.0724	.0953	.0876	.0838
2	.0876	.0838	.0686	.0686	.0876	.0762	.08
3	.0686	.0762	.0686	.08	.0838	.0724	.0724
4	.0686	.0724	.0724	.0762	.08	.0686	.0686
5	.0724	.0686	.0762	.0724	.0762	.0876	.08
6	.0762	.08	.0724	.0838	.08	.08	.0724
7	.0724	.0762	.08	.0876	.0838	.08	.0648
8	.0876	.0762	.0838	.0953	.0953	.0762	.0724
9	.1067	.08	.1029	.1067	.1067	.0953	.1029
10	.1296	.0838	.1143	.0991	.1562	.1067	.141
11	.1486	.1029	.1334	.1296	.1029	.0953	.1486
12	.1753	.1334	.1296	.1372	.1753	.1372	.1715
13	.1334	.1486	.1334	.1257	.1296	.1181	.1181
14	.1372		.1562	.1296	.1219	.1105	.1296
15	.1638		.1791	.1334	.1296	.1029	.141
16	.1791	.141	.1715	.1486	.16	.1067	.1562
17	.1867	.1486	.1829	.1791	.1829	.1143	.1638
18	.202	.1448	.1943	.1867	.1181	.1219	.1753
19	.2172	.141	.202	.1981	.1867	.1219	
20	.1829	.1296	.1753	.1638	.1638	.1181	
21	.1486	.1219	.1219	.1562	.16	.1219	
22	.1181	.1143	.0991	.1219	.1143	.1296	
23	.1143	.0876	.0838	.0914	.1105	.0991	
24	.0953	.1067	.1067	.0724	.0991	.1067	.0876
Max	.2172	.1486	.202	.1981	.1867	.1372	.1753
Min	.0686	.0686	.0686	.0686	.0762	.0686	.0648
Avg	.1275	.1048	.1210	.1173	.1208	.1015	.1121

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

WADGAON MAVAL S/DN.[769] BU 4769

Substation No/ Name :- 213465 / 22/22 KV LODHA BELMONDO
S/STNFeeder No / Name : 306 / 22 KV LODHA STATION
TRANSFORMER Feeder KV- 22 /
OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0038	.0038	.0038	.0038	.0038	.0038	.0038
Max	.0038	.0038	.0038	.0038	.0038	.0038	.0038
Min	.0038	.0038	.0038	.0038	.0038	.0038	.0038
Avg	.0038	.0038	.0038	.0038	.0038	.0038	.0038

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

WADGAON MAVAL S/DN.[769] BU 4769

Substation No/ Name :- 218051 / 220/22 KV URSE S/STN

Feeder No / Name : 302 / 22 KV Tata Motors
Feeder KV- 22 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	6.592	3.0483	6.5539	5.2965	4.8773	8.421	5.9823
Max	6.592	3.0483	6.5539	5.2965	4.8773	8.421	5.9823
Min	6.592	3.0483	6.5539	5.2965	4.8773	8.421	5.9823
Avg	6.592	3.0483	6.5539	5.2965	4.8773	8.421	5.9823

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

WADGAON MAVAL S/DN.[769] BU 4769

Substation No/ Name :- 218051 / 220/22 KV URSE S/STN

Feeder No / Name : 303 / 22 KV Urse

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	6.4396	5.0297	6.9349	8.3829	7.8494	7.5065	6.9349
Max	6.4396	5.0297	6.9349	8.3829	7.8494	7.5065	6.9349
Min	6.4396	5.0297	6.9349	8.3829	7.8494	7.5065	6.9349
Avg	6.4396	5.0297	6.9349	8.3829	7.8494	7.5065	6.9349

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

WADGAON MAVAL S/DN.[769] BU 4769

Substation No/ Name :- 218051 / 220/22 KV URSE S/STN

Feeder No / Name : 304 / 22 KV Pawanagar
Feeder KV- 22 / OUTGOING

SHEDDABLE RURAL

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9					.9526		
24	.9526	.9907	.9145	.9907	.9526	1.0669	1.0669
Max	.9526	.9907	.9145	.9907	.9526	1.0669	1.0669
Min	.9526	.9907	.9145	.9907	.9526	1.0669	1.0669
Avg	.9526	.9907	.9145	.9907	.9526	1.0669	1.0669

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

WADGAON MAVAL S/DN.[769] BU 4769

Substation No/ Name :- 218051 / 220/22 KV URSE S/STN

Feeder No / Name : 306 / 22 KV Lamontana

SHEDDABLE RURAL

Feeder KV- 22 / INCOMING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.1524	.1524	.1524	.1524	.1524	.1524	.1524
Max	.1524	.1524	.1524	.1524	.1524	.1524	.1524
Min	.1524	.1524	.1524	.1524	.1524	.1524	.1524
Avg	.1524	.1524	.1524	.1524	.1524	.1524	.1524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

WADGAON MAVAL S/DN.[769] BU 4769

Substation No/ Name :- 218051 / 220/22 KV URSE S/STN

Feeder No / Name : 307 / 22 KV Lodha No. 1
Feeder KV- 22 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	1.1812	1.2193	1.2574	1.2193	1.1812	.4191	.4572
Max	1.1812	1.2193	1.2574	1.2193	1.1812	.4191	.4572
Min	1.1812	1.2193	1.2574	1.2193	1.1812	.4191	.4572
Avg	1.1812	1.2193	1.2574	1.2193	1.1812	.4191	.4572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

WADGAON MAVAL S/DN.[769] BU 4769

Substation No/ Name :- 218051 / 220/22 KV URSE S/STN

Feeder No / Name : 801 / 220 KV Mahindra Hinoday NON SHEDDABLE EHV INDUSTRIAL FEEDERS
 Feeder KV- 220 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	11.0502	10.2881	9.907	11.4312	1.5242	10.2881	11.8122
Max	11.0502	10.2881	9.907	11.4312	1.5242	10.2881	11.8122
Min	11.0502	10.2881	9.907	11.4312	1.5242	10.2881	11.8122
Avg	11.0502	10.2881	9.907	11.4312	1.5242	10.2881	11.8122