

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113015 / LOKPRIYA

Feeder No / Name : 201 / RACHANA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3439	.362	.3077	.362	.2896	.2534	.2715
2	.3258	.3292	.2896	.3258	.2899	.2537	.2534
3	.3077		.2715	.3258	.2896	.2534	.2534
4	.3077	.2715	.2896	.2715	.2896	.2534	.2896
5	.3077	.2715	.2896	.2715	.3258	.2715	.3258
6	.3439	.362	.362	.2715	.3801	.3077	.3801
7	.4344	.4525	.362	.362	.4668	.3801	.4163
8	.4706		.3982	.362	.4706	.4163	.4706
9	.4163	.4344	.362	.4525	.4163	.4706	.4344
10	.362	.3258	.3982	.4525	.3801	.3801	.3258
11	.3258	.2896	.3658	.362	.3077	.3077	.3077
12	.3258	.3077	.2896	.362	.2715	.2896	.2896
13	.3077	.2896	.2926	.3258	.2896	.3077	.2715
14	.2715	.2534	.2896	.3077	.3077	.2534	.2715
15	.2715	.2534	.2534	.2715	.2353	.2353	.2534
16	.2534	.2534	.2353	.2715	.2172	.2353	.2534
17	.2534	.2534	.2715	.2715	.2353	.2534	.2715
18	.2896	.3258	.362	.2896	.2353	.2896	.2896
19	.3982	.4163	.4525	.3982	.3439	.3982	.3982
20	.4163	.4163	.3982	.4163	.3801	.4344	.4344
21	.4525	.4525	.4525	.4163	.3982	.3982	.4706
22	.4525	.4163	.4525	.3982	.3801	.4163	.4525
23	.4525	.3801	.3982	.3801	.3439	.3429	.4163
24	.3801	.362	.3439	.362	.3258	.2896	.3077
Max	.4706	.4525	.4525	.4525	.4706	.4706	.4706
Min	.2534	.2534	.2353	.2715	.2172	.2353	.2534
Avg	.3530	.3399	.3412	.3454	.3279	.3205	.3379

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113015 / LOKPRIYA

Feeder No / Name : 202 / UDAYSHREE FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1584	1.086	1.0498	1.1765	.905	.9774	1.0136
2	1.1041	1.086	.9593	1.1765	.8962	.905	.9412
3	1.0136	.9955	.9231	1.086	.8688	.9097	.905
4	1.0136	.9955	.9231	1.086	.8779	.905	.9774
5	1.086	.9955	.9231	.9955	.8869	.905	1.0317
6	1.1946	1.267	1.0136	.9955	.9593	.9412	1.086
7	1.3032	1.3575	1.1041	.9955	1.1765	1.0679	1.1765
8	1.3575		1.1765	1.086	1.1946	1.1041	1.2851
9	1.267	1.3937	1.3575	1.267	1.3213	1.2308	1.2851
10	1.267	1.2308	1.1765	1.3575	1.2127	1.267	1.3032
11	1.3575	1.1946	1.1765	1.3937	1.3032	1.267	1.1222
12	1.1765	1.2308	1.267	1.3575	.9774	1.1584	1.1584
13	1.1765	1.1403	1.1765	1.3394	.9774	1.0679	1.1222
14	1.086	1.0679	1.086	1.1403	1.0136	1.0679	1.086
15	.9955	.9774	1.086	1.0317	.9231	.9593	1.0317
16	1.086	.9955	1.086	1.0679	.905	.9412	1.0498
17	1.086	1.0136	1.1765	1.0679	.9593	1.086	1.086
18	1.1765	1.0679	1.1765	1.1222	.9412	1.1765	1.2127
19	1.4842	1.448	1.5384	1.3756	1.3937	1.5384	1.5203
20	1.6289	1.5023	1.5384	1.448	1.4299	1.5565	1.5927
21	1.6289	1.5203	1.5384	1.4118	1.4712	1.5746	1.6108
22	1.5384	1.3937	1.5384	1.3394	1.3213	1.4661	1.5746
23	1.3575	1.3213	1.3575	1.2308	1.2127	1.2851	1.4299
24	1.267	1.1765	1.1765	1.267	1.0679	1.0608	1.086
Max	1.6289	1.5203	1.5384	1.448	1.4712	1.5746	1.6108
Min	.9955	.9774	.9231	.9955	.8688	.905	.905
Avg	1.2421	1.1938	1.1886	1.2006	1.0915	1.1425	1.1953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113015 / LOKPRIYA

Feeder No / Name : 203 / JANTA MARKET FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	11-FEB-18
HR	Load (MW)	Load (MW)
16	.0953	.1715
Max	.0953	.1715
Min	.0953	.1715
Avg	.0953	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113015 / LOKPRIYA

Feeder No / Name : 205 / 11KV SARVAMANGAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3801	.3224	.3258	.3582	.3077	.3395	.3224
2	.3439	.3224	.3077		.3077	.2534	.2865
3	.3439	.2686	.3077	.3224	.3077	.2641	.2926
4	.362		.3077	.2715	.3077	.2641	.2686
5	.362	.2686	.3077	.2686	.3077	.2534	.3224
6	.3982	.3582	.3439	.2686	.3439	.3077	.3582
7	.4163	.3582	.362	.3045	.3801	.3801	.394
8	.4163		.362	.3582	.362	.3982	.4298
9	.4477	.4344	.4477	.4477	.3982	.4344	.4477
10	.4477	.4163	.4477	.5373	.4344	.4525	.3761
11	.3582	.3439	.394	.3982	.3982	.4163	.3761
12	.4119	.3982	.4477	.5068	.3982	.394	.394
13	.3582	.3258	.394	.3439	.3077	.3582	.3224
14	.3582	.3439	.394	.3982	.3982	.4119	.3582
15	.3582	.3258	.3582	.3439	.3258	.3403	.3761
16	.3045	.2896	.3045	.3077	.2715	.3045	.3582
17	.2865	.3258	.3582	.3439	.3258	.3045	.3403
18	.394	.362	.3582	.362	.3258	.3761	.394
19	.4835	.4706	.4477	.4163	.4525	.4835	.5014
20	.5373	.5068	.5373	.4887	.4525	.4835	.5552
21	.5373	.5068	.4477	.4706	.4887	.5014	.4835
22	.5373	.5249	.4525	.4344	.4525	.4835	.4835
23	.4477	.4344	.4477	.4163	.4525	.4477	.4477
24	.4163	.3582	.3801	.3582	.358	.362	.3582
Max	.5373	.5249	.5373	.5373	.4887	.5014	.5552
Min	.2865	.2686	.3045	.2686	.2715	.2534	.2686
Avg	.4045	.3757	.3851	.3794	.3694	.3756	.3853

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113015 / LOKPRIYA

Feeder No / Name : 206 / RCF

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0136	1.0059	.9412	1.086	.8724	.9412	.9145
2	.9593	1.0059	.905	1.086	.8326	.8688	.8596
3	.905	.9145	.8688	.9955	.8326	.8688	.823
4	.905	.905	.9231	.9955	.8326	.8688	.8962
5	.9412	.9145	.9412	.905	.8688	.8688	1.0059
6	1.0498	1.0974	1.0679	.905	.9955	.9431	1.1523
7	1.2489	1.1888	1.1041	.9955	1.2127	1.0317	1.3169
8	1.3937	1.0059	1.1946	1.086	1.3394	1.2489	1.1888
9	1.2803	1.267	1.1888	1.1765	1.2127	1.3392	1.2071
10	1.0974	1.1765	1.0974	1.267	1.1041	1.1475	1.1706
11	1.0059	.9593	1.0974	1.1765	.9774	1.086	.9511
12	.9145	.8688	1.0059	.9774	.7964	.8596	.8596
13	.9145	.7964	.823	.9231	.7783	.8413	.8048
14	.823	.7783	.823	.8688	.9593	.7682	.8048
15	.7316	.7421	.7316	.8688	.724	.6878	.7682
16	.7316	.7421	.7316	.8507	.6516	.6878	.7682
17	.7316	.7602	.823	.8326	.6878	.7783	.7682
18	.823	.8688	1.0059	.9231	.7602	.8507	.8596
19	1.0974	1.1946	1.267	1.1946	1.0679	1.1403	1.1706
20	1.2803	1.2308	1.267	1.2489	1.1041	1.1765	1.2437
21	1.2803	1.2489	1.1765	1.2489	1.1584	1.2308	1.262
22	1.2803	1.2489	1.1765	1.1584	1.1403	1.1403	1.2437
23	1.1888	1.1584	1.1765	1.1222	1.086	1.086	1.1706
24	1.1041	1.0974	1.0679	1.1888	1.0018	.9774	.9593
Max	1.3937	1.267	1.267	1.267	1.3394	1.3392	1.3169
Min	.7316	.7421	.7316	.8326	.6516	.6878	.7682
Avg	1.0292	1.0074	1.0169	1.0450	.9582	.9766	1.0071

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113015 / LOKPRIYA

Feeder No / Name : 207 / LOKPRIYA S/STN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943		.0943	.0953	.0943	.0943	.0953
2	.0943		.0943	.0953	.0943	.0943	.0953
3	.0943		.0943	.0953	.0943	.0943	.0953
4	.0943		.0943	.0953	.0943	.0943	.0953
5	.0943		.0943	.0953	.0943	.0943	.0953
6	.0943		.0914	.0953	.0943	.0943	.0953
7	.0943		.0943	.0953	.0943	.0943	.0953
8	.0943		.0943	.0953	.0943	.0943	.0953
9	.0953	.0943	.0953	.0953	.0943	.0943	.0953
10	.0953	.0943	.0953	.0953	.0943	.0943	.0953
11	.0953	.0943	.0953	.0943	.0943	.0943	.0953
12	.0953	.0943	.0953	.0943	.0943	.0953	.0953
13	.0953	.0943	.0953	.0943	.0943	.0953	.0953
14	.0953	.0943	.0953	.0943	.0943	.0953	.0953
15	.0953	.0943	.0953	.0943	.0943	.0953	.0953
16	.0953	.0943	.0953	.0943	.0943	.0953	.0953
17	.9526	.0943	.0953	.0943	.0943	.0953	.0953
18	.0953	.0943	.0953	.0943	.0943	.0953	.0953
19	.0953	.0943	.0953	.0943	.0943	.0953	.0953
20	.0953	.0943	.0953	.0943	.0943	.0953	.0953
21	.0953	.0943	.0953	.0943	.0943	.0953	.0953
22	.0953	.0943	.0953	.0943	.0943	.0953	.0953
23	.0953	.0943	.0953	.0943	.0943	.0953	.0953
24	.0943	.0953	.0943	.0953	.0943	.0943	.0953
Max	.9526	.0953	.0953	.0953	.0943	.0953	.0953
Min	.0943	.0943	.0914	.0943	.0943	.0943	.0953
Avg	.1306	.0944	.0948	.0948	.0943	.0948	.0953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113015 / LOKPRIYA

Feeder No / Name : 208 / BHANDUP STATION

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.7316	.724	.7316	.6697	.6516	.6584
2	.6516	.6401	.6154	.7316	.6697	.6154	.6219
3	.6516	.6401	.6154	.6401	.6697	.6173	.6219
4	1.0136	.6401	.6154	.6401	.6697	.6154	.6584
5	.6878	.7316	.6335	.6401	.6697	.6154	.695
6	.7602	.7316	.7059	.7316	.7602	.6335	.8048
7	.8688	.823	.7964	.7316	.8688	.7421	.8779
8	1.0317		.7783	.7316	.8688	.8688	.8413
9	1.0059		.823	.823	.8688	.905	.8048
10	.4572	.7783	.823	.823	.7783	.8145	.7682
11	.823	.7964	.7316	.8413	.7602	.7602	.7682
12	.7316	.724	.7316	.7602	.6878	.7316	.7133
13	.6401	.6878	.6401	.7059	.6154	.6401	.6401
14	.7316	.6516	.6401	1.0136	.6697	.6036	.6036
15	.6401	.6516	.6401	.6219	.5792	.5853	.6602
16	.6401	.6154	.6401	.5973	.543	.567	.6219
17	.6401	.6154	.6401	.6516	.5611	.6219	.6219
18	.7316	.6878	.7316	.6878	.6516	.6767	.695
19	.9145	.8688	.9145	.8743	.7964	.8779	.8962
20	1.0059	.9774	1.0059	.8688	.8507	.9328	.9511
21	1.0059	.9412	1.0059	.905	.8688	.8962	.9694
22	1.0059	.9231	1.0059	.8869	.8507	.8779	.9694
23	.823	.8688	.9145	.8507	.7783	.823	.9145
24	.7964	.7316	.7602	.823	.7059	.6516	.7133
Max	1.0317	.9774	1.0059	1.0136	.8688	.9328	.9694
Min	.4572	.6154	.6154	.5973	.543	.567	.6036
Avg	.7909	.7481	.7555	.7630	.7255	.7219	.7538

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113015 / LOKPRIYA

Feeder No / Name : 209 / BHANDUPESHWAR KUND

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3734	.3772	.3734	.3395	.3395	.3206
2	.3772	.3292	.3584	.3734	.3395	.3395	.2743
3	.3584	.2801	.3584	.3361	.3395	.3395	.2743
4	.3584	.2801	.3395	.3361	.3395	.3258	.2743
5	.3584	.2801	.3395	.2801	.3395	.3395	.3206
6	.3584	.3361	.3584	.2801	.3395	.3395	.3206
7	.3584	.3292	.3395	.3361	.3395	.2896	.3584
8	.3584		.3584	.3174	.3584	.3206	.3018
9	.3361	.3018	.2987	.3174	.3018	.3206	.3018
10	.3174	.2829	.2801	.3734	.2829	.3018	.3018
11	.2801	.2641	.2801	.3584	.2534	.3045	.2614
12	.2801	.2641	.2801	.3206	.2641	.2829	.2641
13	.2801	.3018	.2987	.3584	.2641	.2829	.2829
14	.2987	.3018	.2801	.3395	.2829	.2829	.2829
15	.2987	.3018	.2801	.3206	.2641	.2641	.2829
16	.2614	.2829	.2614	.3206	.2353	.2641	.2829
17	.2801	.2829	.2987	.2829	.2353	.2641	.2829
18	.3174	.3395	.3734	.3395	.2829	.3206	.3018
19	.3734	.415	.4668	.415	.3584	.3961	.415
20	.4668	.4904	.4668	.4338	.415	2.3011	.4527
21	.4668	.4904	.4668	.4338	.415	.4338	.4527
22	.4668	.5093	.4854	.4527	.415	.4527	.4715
23	.4668	.4527	.4668	.4338	.3772	.415	.4338
24	.415	1.1203	.3961	.4668	.3772	.3584	.3584
Max	.4668	1.1203	.4854	.4668	.415	2.3011	.4715
Min	.2614	.2641	.2614	.2801	.2353	.2641	.2614
Avg	.3546	.3743	.3546	.3583	.3233	.4116	.3281

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113016 / AMFORGE

Feeder No / Name : 201 / MAHAVIR-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715		.2058	.1886		.1886	.1372
2	.1886		.2058	.1886		.2058	.2229
3	.2058		.2058	.1886		.2229	.2229
4	.2229		.2229	.1886		.2229	.2229
5	.2058		.1886	.1886		.2229	.2058
6	.1886		.1886	.1886		.2058	.1886
7	.2572	.2667	.2229	.2572		.2915	.2572
8	.2229	.2667	.2743	.2572	.2667	.2401	.2572
9	.2229	.2743	.2401	.2058	.2401	.2743	.2572
10	.2058	.2229	.2743	.2229	.1886	.2229	.2401
11	.2058	.1372	.1715	.2229	.1715	.1372	.1372
12	.1372	.1372	.1543		.1372	.2058	.1372
13	.1372	.2058	.1886	.2058	.1372	.1715	.1715
14	.1543	.1543	.1886	.2058		.1372	.1372
15	.1372	.1372	.1543	.1715	.1372	.1372	.1372
16	.1524	.1543	.1372	.1543	.1372	.1372	.1372
17		.1543	.1543		.1372	.1372	.1372
18	.1715	.1543	.1543	.1715	.1372	.1543	.1372
19	.1715	.1715	.1886		.1372	.1886	.1372
20		.1886	.2058		.1372	.2058	.1715
21		.2058	.1715	.2096	.1715	.2058	.1886
22	.1905	.1886	.1715		.1886	.1886	.2058
23	.1715	.1886	.1543	.1905	.1543	.1715	.1543
24	.1715	.1715	.2058	.1543	.1905	.1715	.1886
Max	.2572	.2743	.2743	.2572	.2667	.2915	.2572
Min	.1372	.1372	.1372	.1543	.1372	.1372	.1372
Avg	.1854	.1878	.1929	.1979	.1668	.1936	.1829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113016 / AMFORGE

Feeder No / Name : 202 / ANGEL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372		.1372	.1372		.1372	.1372
2	.1372		.1372	.1372		.1372	.1372
3	.1372		.1372	.1372		.1372	.1372
4	.1372		.1372	.1372		.1372	.1372
5	.1372		.1372	.1372		.1372	.1372
6	.1372		.1372	.1372		.1372	.1372
7	.1372	.1524	.1372	.1372		.1372	.1372
8	.1372	.1524	.1372	.1372	.1524	.1372	.1372
9	.1543	.1543	.1543	.1372	.1372	.1372	.1372
10	.1372	.1372	.1543	.1543	.1372	.1372	.1372
11	.1372	.1372	.1372	.1372	.1372	.1372	.1372
12	.1372	.1372	.1372	.1372	.1372	.1372	.1372
13	.1372	.1372	.1372	.1372	.1372	.1372	.1372
14	.1372	.1372	.1372	.1372		.1372	.1372
15	.1372	.1372	.1372	.1372	.1372	.1372	.1372
16	.1524	.1372	.1372	.1372	.1372	.1372	.1372
17		.1372	.1372		.1372	.1372	.1372
18	.1524	.1372	.1372	.1524	.1372	.1372	.1372
19	.1524	.1372	.1372		.1372	.1372	.1372
20		.1372	.1372		.1372	.1372	.1372
21		.1372	.1372	.1524	.1372	.1372	.1372
22	.1524		.1372		.1372	.1372	.1372
23	.1524	.1372	.1372	.1524	.1372	.1372	.1372
24	.1372	.1524	.1372	.1372	.1524	.1372	.1372
Max	.1543	.1543	.1543	.1543	.1524	.1372	.1372
Min	.1372	.1372	.1372	.1372	.1372	.1372	.1372
Avg	.1416	.1409	.1386	.1403	.1391	.1372	.1372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113016 / AMFORGE

Feeder No / Name : 204 / J BHARAT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1145		1.166	1.2517		.9774	.9945
2	1.0288		1.0631	1.166		.8745	.9088
3	.9945		1.0117	1.1145		.8402	.8402
4	.9945		.9945	1.1145		.8402	.8402
5	1.046		1.046	1.1317		.8916	.9602
6	1.3032		1.2517	1.1831		1.0117	1.2346
7	1.4403	1.5242	1.3203	1.2003		1.0974	1.3717
8	1.5261	1.6385	1.3889	1.286	1.7528	1.406	1.5261
9	1.4232	1.4746	1.4918	1.5261	1.406	1.5089	1.3717
10	1.3546	1.4232	1.4403	1.5261	1.3375	1.3375	1.286
11	1.2346	1.2517	1.3889	1.4575	1.2346	1.3203	1.2346
12	1.2517	1.1831	1.2689	1.4403	1.1488	1.2346	1.2517
13	1.2174	1.1145	1.2346	1.3546	1.0974	1.166	1.1831
14	1.2003	1.1317	1.2174	1.2346		1.0802	1.2346
15	1.1488	1.1145	1.1488	1.2003	1.0631	1.0117	1.1145
16	1.2193	1.0974	1.0802	1.166	1.046	1.0288	1.0974
17		1.1488	1.2174		1.046	1.1488	1.1317
18	1.3336	1.286	1.4575	1.4098	1.1145	1.2346	1.3032
19	1.7528	1.7147	1.869		1.5432	1.6461	1.6975
20		1.8519	1.8861		1.6461	1.7147	1.8176
21		1.8519	1.869	1.829	1.6804	1.6632	1.8519
22	1.7528	1.6289	1.6975		1.5089	1.4918	1.749
23	1.6004	1.5261	1.5261	1.4861	1.3032	1.3375	1.5261
24	1.3032		1.3032	1.3375	1.2574	1.0974	1.0802
Max	1.7528	1.8519	1.8861	1.829	1.7528	1.7147	1.8519
Min	.9945	1.0974	.9945	1.1145	1.046	.8402	.8402
Avg	1.2972	1.4095	1.3475	1.3208	1.3241	1.2067	1.2753

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113016 / AMFORGE

Feeder No / Name : 206 / PANNALAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2517		1.2174	1.166		1.0802	1.0974
2	1.1831		1.166	1.0974		1.0288	1.046
3	1.1317		1.0802	1.046		.9945	.9945
4	1.0974		1.1145	.9945		.9602	.9602
5	1.166		1.1317	.9945		.9945	.9945
6	1.2689		1.166	.9945		1.0288	1.2003
7	1.3375	1.448	1.166	1.0288		1.1317	1.2346
8	1.4746	1.6004	1.2689	1.2174	1.5242	1.3717	1.3717
9	1.5432	1.6632	1.406	1.406	1.5775	1.6118	1.6461
10	2.0919	2.1091	1.9547	1.6118	1.989	1.9547	1.9719
11	2.0062	2.0576	1.9204	1.7661	2.0233	2.0233	1.989
12	2.2634	2.0405	1.9376	1.7147	2.0576	2.0576	2.1948
13	1.7661	1.749	1.9376	1.5775	1.7833	1.4918	1.9204
14	2.0405	1.869	1.749	1.5432		1.749	1.8519
15	2.0062	1.9719	1.8861	1.5432	1.8519	1.9204	1.9547
16	2.3434	1.8519	1.9033	1.406	1.749	1.8176	2.0405
17		1.9719	1.8176		1.9547	1.749	1.9547
18	2.1338	1.9719	1.8519	1.3336	1.749	1.8004	2.0233
19	2.3624	2.1262	2.0748		2.0233	1.9376	2.2462
20		2.0919	1.9376		1.9204	1.869	2.2119
21		1.7318	1.6804	1.6004	1.6461	1.6632	1.9719
22	1.829	1.5947	1.5089		1.4575	1.4403	1.6804
23	1.6385	1.4918	1.4746	1.5242	1.3375	1.3717	1.5775
24	1.406	1.4861	1.3032	1.2174	1.2955	1.2003	1.166
Max	2.3624	2.1262	2.0748	1.7661	2.0576	2.0576	2.2462
Min	1.0974	1.448	1.0802	.9945	1.2955	.9602	.9602
Avg	1.6829	1.8237	1.5689	1.3392	1.7462	1.5103	1.6375

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113016 / AMFORGE

Feeder No / Name : 207 / NEHA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573		.7888	.8402		.7373	.7545
2	.8059		.7545	.7716		.7202	.703
3	.7888		.7202	.7202		.6687	.6859
4	.7716		.7545	.7202		.6344	.6859
5	.7888		.7888	.7373		.6687	.703
6	.9774		.8573	.7888		.7888	.9088
7	1.046	1.1431	.9774	.8573		.8402	.9259
8	1.1145	1.2193	.9774	1.0117	1.1431	1.0288	1.1317
9	1.3032	1.1831	1.2003	1.0288	1.1317	1.1831	1.1317
10	1.4403	1.3546	1.3032	1.166	1.2517	1.3546	1.406
11	1.3889	1.3375	1.3032	1.1831	1.3717	1.3032	1.3717
12	1.4232	1.3203	1.4232	1.2003	1.3375	1.286	1.3717
13	1.1831	1.0802	1.2517	1.0117	1.2003	1.166	1.2346
14	1.2517	1.2003	1.2174	.9602		1.2003	1.2517
15	1.2689	1.1145	1.2174	.9945	1.0974	1.0974	1.2003
16	1.3717	1.166	1.1488	.9431	1.0974	1.1317	1.2689
17		1.1831	1.1831		1.1317	1.1831	1.4232
18	1.3717	1.2174	1.3203	1.105	1.2003	1.2689	1.4403
19	1.5432	1.4403	1.3889		1.406	1.3889	1.5604
20		1.3889	1.3889		1.3203	1.3375	1.5432
21		1.3032	1.2517	1.2193	1.2346	1.2689	1.4746
22	1.3336	1.1145	1.166		1.0802	1.0802	1.3032
23	1.1812	1.0117	.9945	.9907	.9431	.9945	1.1317
24	.9602	1.0288	.8745	.8573	.9145	.8573	.823
Max	1.5432	1.4403	1.4232	1.2193	1.406	1.3889	1.5604
Min	.7716	1.0117	.7202	.7202	.9145	.6344	.6859
Avg	1.1510	1.2115	1.0938	.9554	1.1788	1.0495	1.1431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113016 / AMFORGE

Feeder No / Name : 208 / LODHA IMPERIA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.6344
2				.5658
3				.5658
4				.583
5				.6173
6				.7888
7				.9088
8				.9945
9				1.286
10				1.4746
11				1.5089
12			1.406	1.4746
13			1.2174	1.3717
14			1.1317	1.4232
15			1.1317	1.3375
16			1.0974	1.3375
17		.1372	1.0974	1.3889
18			1.2003	1.406
19			1.2346	1.4232
20			1.1488	1.3717
21			1.046	1.2174
22			.9431	1.0974
23	.9907		.8059	.9774
24				.6859
Max	.9907	.1372	1.406	1.5089
Min	.9907	.1372	.8059	.5658
Avg	.9907	.1372	1.1217	1.1017

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113022 / DREAMS

Feeder No / Name : 201 / DHEERAJ DREAMS-2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	.9335		.7621			
2	.8192	1.0098		.8192			
3	.7811	1.086		.8764			
4	.7811	1.1622		.9335			
5	.8192	1.2384		.9907			
6	.8954	1.3146		1.0479			.7811
7	1.086	1.3908		1.105			1.1431
8	1.2955	1.467	1.0669	1.1622			1.2003
9	1.5813	1.5432	1.2384	1.2384		1.3717	1.4289
10	1.6766		1.5432	1.3146			1.7909
11	1.7718	1.7909	1.5242	1.3908	1.7528	1.6385	1.848
12	1.7718		1.5051	1.467	1.6194	1.5623	1.7909
13	1.7147		1.467	1.3908			1.6575
14	1.7337		1.4289	1.2955			1.6575
15	1.7528		1.4098	1.2384			1.7147
16	1.6956	1.5432	1.3908	1.1812			
17	1.6385		1.4289	1.1241		1.3336	
18	1.6575		1.5432				
19	1.6766		1.6385				1.6766
20	1.5242		1.5051				
21	1.4861		1.3146				
22	1.2384		1.1241			1.2193	
23		1.0098	.9335				1.105
24	.9335		1.0288	.8383		.8383	.8383
Max	1.7718	1.7909	1.6385	1.467	1.7528	1.6385	1.848
Min	.7811	.9335	.9335	.7621	1.6194	.8383	.7811
Avg	1.3552	1.2908	1.3583	1.1209	1.6861	1.3273	1.4333

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113022 / DREAMS

Feeder No / Name : 202 / DHEERAJ DREAMS-4

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.2858		.2286			
2	.2096	.3239		.2477			
3	.1905	.362		.1905			
4	.1715	.4001		.2286			
5	.1905	.4382		.2477			
6	.2096	.4763		.2477			.2667
7	.362	.5144		.2477			.4001
8	.4191	.5716	.5525	.2286			.381
9	.6097	.5906	.4763	.2286		.4954	.4954
10	.5906		.4382	.2477			.4954
11	.5525	.6097	.4382	.2667	.4763	.4001	.4954
12	.5144		.4191	.2667		.3239	.4954
13	.5335		.381	.2477			.4572
14	.4954		.3429	.2477			.4382
15	.4954		.3239	.2667			.4763
16	.4763	.4382	.3048	.2477			
17	.4572		.3429	.2477		.4191	
18	.4572		.3429				
19	.4572		.3429				.4382
20	.4191		.3239				
21	.3239		.3048				
22	.2858					.381	
23		.3048	.2667				.2667
24	.2667		.2858	.2286		.2667	.2667
Max	.6097	.6097	.5525	.2667	.4763	.4954	.4954
Min	.1715	.2858	.2667	.1905	.4763	.2667	.2667
Avg	.3885	.4430	.3679	.2424	.4763	.3810	.4133

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113022 / DREAMS

Feeder No / Name : 203 / DHEERAJ DREAMS 5

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6287	.6097		.5335			
2	.5716	.6287		.5716			
3	.5525	.6478		.6097			
4	.5335	.6668		.6478			
5	.5716	.6859		.6097			
6	.6859	.7049		.6478			.6287
7	.8764	.724		.6859			.9145
8	.8002	.743	.6287	.724			.9526
9	1.0098	.7621	.6478	.7621		.5525	.9526
10	.9145	.6097	.6859	.8002			.8192
11	.8002	.6097	.743	.8383	.6478	.6859	.8002
12	.5525		.8002	.8954	.5716	.381	.5716
13	.5716		.7621	.8002			.5335
14	.6668		.724	.6859			.6097
15	.6478		.6859	.6097			.4954
16	.5716	.5335	.6478	.5335			
17	.4954		.5716	.4763		.4954	
18	.6097		.6478				
19	.7049		.7049				.6097
20	.8192		.6478				
21	.7049		.6478				
22	.6478		.6478			.724	
23		.4954	.6478				.6478
24	.5906		.4954	.5906		.5525	.5144
Max	1.0098	.7621	.8002	.8954	.6478	.724	.9526
Min	.4954	.4954	.4954	.4763	.5716	.381	.4954
Avg	.6751	.6478	.6668	.6679	.6097	.5652	.6961

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113022 / DREAMS

Feeder No / Name : 205 / JAM THEATRE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	1.7337		1.6575			
2	1.4289	1.7528		1.6956			
3	1.3908	1.7718		1.7337			
4	1.3527	1.8099		1.7718			
5	1.5623	1.848		1.8099			
6	1.7909	1.8861		1.848			1.6194
7	1.8861	1.9243		1.8861			1.8099
8	2.1338	1.9624	1.8861	1.9243			1.7909
9	2.1148	2.0005	1.9624	1.9624		1.9433	1.9814
10	2.0957		2.0576	2.0195			1.8671
11	2.0576	2.0005	2.0005	2.0767	1.829	1.8099	1.8671
12	1.9814		1.9243	2.1338		1.7528	1.8671
13	1.9052			2.0195			
14	1.829		1.8099	1.8861			.9335
15	1.8861		1.7718	1.7909			1.7718
16	1.6956	1.7147	1.7337	1.6956			
17	1.8099		1.9052	1.6194		1.6956	
18	2.0767		2.2672				
19	2.3434		2.6292				2.553
20	2.4196		2.6101				
21	2.3624		2.4006				
22	2.2291		2.21			2.1529	
23		2.0195	2.0195				2.1719
24	1.7337		2.0386	1.7909		1.5242	1.6385
Max	2.4196	2.0195	2.6292	2.1338	1.829	2.1529	2.553
Min	1.3527	1.7147	1.7337	1.6194	1.829	1.5242	.9335
Avg	1.8969	1.8687	2.0767	1.8512	1.829	1.8131	1.8226

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113022 / DREAMS

Feeder No / Name : 206 / POLICE STATION

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5906	.5144		.5335			
2	.5144	.5716		.5525			
3	.4954	.6287		.5716			
4	.4763	.6859		.5906			
5	.4954	.743		.6097			
6	.5144	.7811		.6287			.5335
7	.5144	.8383		.6478			.4763
8	.6668	.8954		.6668			.5716
9	1.0098	.9526	.7811	.6859		.8764	.8383
10	1.2384		1.3527	.7049			1.3908
11	1.467	1.4861	1.4289	.743	1.3527	1.4289	1.448
12	1.5432		1.5051	.7811		1.4289	1.3908
13	1.4289		1.448	.7621			1.0669
14	1.3146		1.4098	.743			1.1622
15	1.2003		1.3717	.7049			1.3908
16	1.086	1.4098	1.3336	.6668			
17	1.3908		1.3527	.6287		1.1241	
18	1.2765		1.1812				
19	1.1812		1.0098				1.1812
20	.8954		.9335				
21	.6097		.8192				
22	.6287		.7049			.5906	
23		.5335	.5906				.5716
24	.5335		.5144	.5716		.5144	.5335
Max	1.5432	1.4861	1.5051	.7811	1.3527	1.4289	1.448
Min	.4763	.5144	.5144	.5335	1.3527	.5144	.4763
Avg	.9162	.8367	1.1086	.6552	1.3527	.9939	.9658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113023 / Haryali

Feeder No / Name : 200 / MARATHON

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2572	.2401	.2401	.2401	.2401	.2401
2	.2058	.2401	.2058	.2229	.2401	.2401	.2229
3	.2058	.2229	.2058	.2058	.2229	.2229	.2058
4	.2229	.2229	.2058	.2058	.2058	.2229	.2058
5	.2401	.2401	.2058	.2229	.2058	.2058	.2058
6	.2743	.3086	.2401	.2401	.2401	.2401	.2401
7	.2915	.3601	.2572	.2572	.3429	.2743	.2915
8	.463	.4115	.3898	.2481	.3944	.2835	.4252
9	.3429	.3772	.3189	.2481	.3429	.3189	.3544
10	.3086	.3086	.3544	.2835	.2743	.3189	.2835
11	.3258	.2743	.2835	.3544	.2743	.2835	.2835
12	.2743	.2401		.2835	.2401	.2481	.2835
13	.2401	.2401	.2481	.2835	.2401	.2481	.2835
14	.2401	.2401	.2481	.2481	.2401	.2481	.2835
15	.2481	.2401	.2481	.2481	.2229	.2481	.2401
16	.2481	.2229	.2229	.2481	.2229	.2058	.2401
17	.2481	.2058	.2401	.2835	.2229	.2058	.2229
18	.2481	.2401	.2572	.2481	.2401	.2229	.2229
19	.3189	.3429	.3258	.3544	.3086	.3429	.3086
20	.3544	.3429	.3258	.3544	.3772	.3601	.3772
21	.3898	.3429	.3086	.3544	.3601	.3429	.3429
22	.3544	.3258	.3086	.2835	.3258	.3772	.3429
23	.3544	.3086	.2743	.2835	.3086	.3086	.3258
24	.2572	.2743	.2743	.2572	.2572	.2743	.2743
Max	.463	.4115	.3898	.3544	.3944	.3772	.4252
Min	.2058	.2058	.2058	.2058	.2058	.2058	.2058
Avg	.2874	.2829	.2691	.2691	.2729	.2702	.2795

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113023 / Haryali

Feeder No / Name : 201 / 11KV LODHA KANJUR FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3032	1.3375	1.286	1.3032	1.1317	1.0974	1.1831
2	1.2346	1.286	1.2174	1.2174	1.0802	1.0288	1.0802
3	1.1488	1.2174	1.1488	1.1488	1.0288	1.0117	1.046
4	1.166	1.2003	1.1145	1.1145	1.046	.9602	1.0288
5	1.2003	1.166	1.166	1.1488	1.166	.9945	1.0631
6	1.3203	1.2689	1.2174	1.1831	1.2517	1.0974	1.2346
7	1.3889		1.2174	1.1317	1.2689	1.166	1.3203
8	1.3717	1.4575	1.3535	1.2803	1.3203	1.3169	1.4632
9	1.4403	1.3717	1.4632	1.3535	1.406	1.4632	1.4266
10	1.4575	1.4746	1.4998	1.4632	1.3717	1.6095	1.4632
11	1.4403	1.406	1.4266	1.6461	1.406	1.4998	1.4266
12	1.4403	1.3375		1.4998	1.2689	1.39	1.39
13	1.3717	1.3032	1.4632	1.4266	1.2346	1.3535	1.4266
14	1.3032	1.286	1.39	1.4266	1.2346	1.3169	1.4266
15	1.4083	1.2346	1.2803	1.3169	1.166	1.3169	1.286
16	1.3535	1.2517	1.286	1.1706	1.0631	1.1831	1.2689
17	1.39	1.3375	1.3375	1.3169	1.166	1.2174	1.3203
18	1.4998	1.3203	1.4575	1.39	1.166	1.3889	1.3889
19	1.8656	1.6632	1.6461	1.6827	1.4746	1.6118	1.6804
20	1.8656	1.6289	1.6975	1.7193	1.5775	1.6461	1.8004
21	1.7924	1.6461	1.6461	1.6827	1.5775	1.6289	1.749
22	1.7558	1.6118	1.6118	1.6461	1.4918	1.5775	1.6289
23	1.6461	1.5261	1.5604	1.4632	1.3717	1.406	1.5947
24	1.4232	1.406	1.3546	1.3717	1.2517	1.2003	1.3032
Max	1.8656	1.6632	1.6975	1.7193	1.5775	1.6461	1.8004
Min	1.1488	1.166	1.1145	1.1145	1.0288	.9602	1.0288
Avg	1.4411	1.3799	1.3844	1.3793	1.2717	1.3118	1.3750

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113023 / Haryali

Feeder No / Name : 202 / RAILWAY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974	1.166	1.1145	1.1145	.9945	.8916	.9088
2	1.0288	1.0631	1.0631	1.0974	.9088	.823	.8573
3	.9774	.9431	1.0117	1.0631	.8573	.7888	.8402
4	.9431	.9088	.9259	.9945	.8402	.8059	.823
5	.9259	.9602	.9431	.9431	.9259	.8573	.8573
6	1.166	1.046	.9945	.9774	1.0288	.9259	.9602
7	1.2689	1.2003	1.166	1.0288	1.0802	1.0631	1.1317
8	1.286	1.3546	1.3203	1.2826	1.2003	1.3203	1.358
9	1.5775	1.5604	1.5844	1.3957	1.406	1.6221	1.5089
10	1.7318	1.5432	1.9239	1.5089	1.5089	1.7353	1.773
11	1.6632	1.7833	1.9239	1.4335	1.5432	1.6221	1.8484
12	1.6804	1.4746		1.4335	1.4746	1.6598	1.8107
13	1.6461	1.4746	1.5844	1.2449	1.4746	1.5466	1.6975
14	1.5432	1.3889	1.5089	1.2071	1.4403	1.3957	1.5466
15	1.6598	1.4746	1.5089	1.1317	1.4918	1.358	1.5775
16	1.6221	1.406	1.4746	1.0562	1.3889	1.0974	1.5089
17	1.7353	1.4403	1.6289	1.1694	1.286	1.2517	1.4918
18	1.7353	1.4918	1.4403	1.2449	1.3032	1.3717	1.5261
19	1.773	1.6632	1.749	1.5466	1.4746	1.4746	1.6289
20	1.8484	1.749	1.6461	1.5844	1.3375	1.5947	1.5432
21	1.8861	1.5947	1.4918	1.5466	1.3717	1.4575	1.5261
22	1.6975	1.4746	1.4232	1.5466	1.3032	1.2689	1.406
23	1.4712	1.3546	1.2689	1.358	1.1317	1.166	1.2517
24	1.166	1.2346	1.1488	1.1488	1.046	.9945	1.0288
Max	1.8861	1.7833	1.9239	1.5844	1.5432	1.7353	1.8484
Min	.9259	.9088	.9259	.9431	.8402	.7888	.823
Avg	1.4638	1.3646	1.3846	1.2524	1.2424	1.2539	1.3504

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113023 / Haryali

Feeder No / Name : 204 / KANJUR SIGNAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0514	.0514	.0514	.0514	.0514	.0514
2	.0514	.0514	.0514	.0514	.0514	.0514	.0514
3	.0514	.0514	.0514	.0514	.0514	.0514	.0514
4	.0514	.0514	.0514	.0514	.0514	.0514	.0514
5	.0514	.0514	.0514	.0514	.0514	.0514	.0514
6		.0514	.0514	.0514	.0514	.0514	.0514
7		.0514					
19	.0509	.0514	.0514	.0509	.0514		
20	.0509	.0514	.0514	.0509	.0514		
21	.0509	.0514	.0514	.0509	.0514		
22	.0509	.0514	.0514	.0509	.0514		
23	.0509	.0514	.0514	.0509	.0514	.0514	.0514
24	.0514	.0514	.0514	.0514	.0514	.0514	.0514
Max	.0514	.0514	.0514	.0514	.0514	.0514	.0514
Min	.0509	.0514	.0514	.0509	.0514	.0514	.0514
Avg	.0512	.0514	.0514	.0512	.0514	.0514	.0514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113030 / 22/11kV Lodha Receiving
Statio

Feeder No / Name : 200 / LODHA SUPREMUS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1494	.1715	.1372	.1524	.1334	.1524
2	.1334	.132	.1715	.12	.1524	.1334	.1715
3	.1524	.1494	.1524	.12	.1524	.1334	.1524
4	.1524	.132	.1334	.1372		.1334	.1524
5	.1334	.1509	.1334	.12	.1524	.1524	.1334
6	.1334	.132	.1524	.12	.1524	.1524	.1524
7	.1524	.1509	.1334	.12	.1524	.1524	.1334
8	.1715	.1698	.1543	.1543	.1905	.1715	.2096
9	.3361	.3239	.1715	.1524	.3048	.2858	.2858
10	.4763	.4191	.1886	.1524	.4191	.3429	.4001
11	.4715	.4572	.2572	.1524	.4572	.362	.4001
12	.4715	.4572	.2572	.1715	.4382	.3429	.4001
13	.4527	.4382	.2401	.1905	.4191	.3429	.4382
14	.4715	.4001	.2229	.1905	.381	.3048	.4382
15	.4527	.4191	.2572	.1905	.4191	.3429	.4382
16	.4338	.4382	.2401	.1715	.4191	.3239	.4382
17	.3961	.4191	.2229	.1905	.4001	.3239	.4382
18	.3961	.381	.2058	.1905	.362	.3239	.4191
19	.3018	.3239	.1715	.1905	.2858	.2477	.3239
20	.2452	.2858	.1715	.1905	.2477	.1905	.2477
21	.2075	.2286	.1543	.1715	.2096	.1905	.1905
22	.1886	.2096	.1372	.1524	.1905	.1715	.1715
23		.1905	.1372	.1334	.1905	.1524	.1524
24	.1905	.1698	.1905	.12	.1715	.1715	.1524
Max	.4763	.4572	.2572	.1905	.4572	.362	.4382
Min	.1334	.132	.1334	.12	.1524	.1334	.1334
Avg	.2893	.2803	.1845	.1558	.2791	.2326	.2747

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113030 / 22/11kV Lodha Receiving
StatioFeeder No / Name : 201 / LODHA JOLLY BOARD
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2263	.2286	.1715	.1905	.2286	.2286
2	.2096	.2075	.2096	.1543	.1905	.2286	.2096
3	.2096	.1886	.1905	.1715	.1905	.2286	.2096
4	.2096	.2075	.1905	.1715	.1905	.2286	.2286
5	.2096	.1886	.2096	.1715	.1905	.2286	.2286
6	.2096	.2075	.2286	.1715	.2096	.2096	.2096
7	.2667	.2829	.2096	.1715	.2667	.2858	.2858
8	.6859	.5281	.4287	.1715	.5716	.5716	.8383
9	.6908	.6668	.463	.2096	1.0479	.6668	.6287
10	1.094	1.1241	.4458	.2096	1.2193	1.105	1.1241
11	1.2071	1.0479	.463	.2286	1.2384	1.0098	1.1812
12	1.1883	.743	.463	.2096	1.105	.7049	1.2003
13	.679	1.0288	.463	.2286	.724	.6287	1.086
14	1.0374	1.1622	.4458	.2096	1.2384	1.1812	1.1431
15	1.0374	.8192	.463	.1905	1.1622	.724	1.0288
16	1.1694	.7811	.463	.2096	1.0669	.9335	1.0098
17	1.0185	1.2384	.4458	.2286	.8002	1.1431	1.2003
18	.6979	.6287	.2743	.2286	1.0288	.6668	1.0669
19	.5847	.5525	.2572	.2286	.5525	.5525	.8573
20	.4904	.381	.2401	.2286	.4572	.362	.3429
21	.2829	.3048	.2058	.2096	.3239	.3429	.3048
22	.2641	.2477	.2229	.2477	.2477	.2667	.2477
23		.2477	.2058	.2286	.2477	.2477	.2477
24	.2286	.2263	.2477	.1886	.2286	.2286	.2096
Max	1.2071	1.2384	.463	.2477	1.2384	1.1812	1.2003
Min	.2096	.1886	.1905	.1543	.1905	.2096	.2096
Avg	.6043	.5516	.3194	.2016	.6120	.5406	.6382

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113030 / 22/11kV Lodha Receiving
Statio

Feeder No / Name : 204 / LODHA AURUM GRANDIES

SHEDDABLE URBAN

FEEDER Feeder KV- 11 /
OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1509	.1334	.1372	.1524	.1334	.1334
2	.1715	.132	.1334	.12	.1524	.1334	.1334
3	.1524	.1509	.1334	.1372	.1334	.1334	.1143
4	.1524	.132	.1334	.12	.1334	.1334	.1334
5	.1524	.1509	.1524	.1372	.1524	.1334	.1334
6	.2286	.2452	.1334	.1372	.2096	.1715	.2286
7	.3048	.3395	.1905	.1543	.3429	.2667	.362
8	.4191	.4338	.2401	.2572	.4001	.4382	.4191
9	.3921	.3429	.3258	.362	.3048	.3429	.3048
10	.2286	.3239	.2401	.3048	.2858	.3429	.362
11	.3206	.3048	.2229	.3429	.2477	.2858	.2858
12	.2641	.2096	.2743	.2667	.2477	.2667	.2096
13	.1698	.2477	.2229		.1905	.1524	.1905
14	.1886	.1524	.2229	.2667	.1524	.2096	.1715
15	.1698	.2096	.1886	.1715	.1715	.1905	.1524
16	.112	.1143	.1372	.1524	.1715	.1143	.1905
17	.132	.1334	.1543	.1715	.1334	.1524	.1524
18	.132	.1715	.1543	.2096	.1334	.1524	.1905
19	.1886	.2286	.1886	.2286	.2096	.1905	.2096
20	.2263	.1905	.1886	.2477	.2286	.2286	.2096
21	.1886	.2096	.1886	.1905	.2096	.2286	.2286
22	.1886	.1905	.1543	.2286	.1905	.1905	.2286
23		.1715	.1372	.1905	.1715	.1524	.1715
24	.1715	.1698	.1524	.1372	.1524	.1334	.1334
Max	.4191	.4338	.3258	.362	.4001	.4382	.4191
Min	.112	.1143	.1334	.12	.1334	.1143	.1143
Avg	.2090	.2127	.1835	.2031	.2032	.2032	.2104

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113032 / 22kV Lodha Switching

Feeder No / Name : 303 / 22KV HDFC BANK

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381	.4572	.4115	.3429	.4191	.381
2	.3429	.415	.4191	.3772	.3429	.381	.381
3	.381	.3772	.381	.3429	.3429	.381	.3429
4	.381	.415	.381	.3429	.3429	.381	.3429
5	.381	.3772	.4191	.3772	.3429	.381	.381
6	.381	.415	.381	.3429	.4191	.381	.3429
7	.381	.381	.381	.3429	.6478	.3429	.381
8	.9145	.8299	.3086	.3772	.6478	.3429	1.105
9	1.1812	1.1431	.7545	.724	1.1812	.8383	1.0288
10	1.4098	1.2574	.4801	.4954	1.2955	.5335	1.3717
11	1.4861	1.2574	.4458	.4954	1.3336	.5335	1.3717
12	1.448	1.1431	.5144	.4954	1.3336	.5335	1.3717
13	1.4861	1.4861	.6516	.4954	1.3717	.8002	1.448
14	1.4098	1.4098	.5144	.7621	1.3336	.5335	1.4098
15	1.4098	1.3336	.5144	.4954	.9526	.5335	1.448
16	1.2955	1.3336	.6516	.6859	1.3336	.5716	1.3336
17	1.3336	1.2955	.6859	.8002	1.3717	.8002	1.4098
18	1.105	1.1431	.4115	.381	1.2574	.4191	1.3717
19	.6097	.5716	.4115	.381	.6097	.381	.6097
20	.5335	.5335	.4115	.3429	.4954	.381	.5335
21	.4954	.4954	.3772	.3429	.4954	.381	.4572
22	.4954	.4572	.3772	.3429	.4572	.381	.4954
23		.4572	.3772	.3429	.4191	.381	.4572
24	.8764	.8383	.7621	.3772	.3429	.8383	.381
Max	1.4861	1.4861	.7621	.8002	1.3717	.8383	1.448
Min	.3429	.3772	.3086	.3429	.3429	.3429	.3429
Avg	.8747	.8228	.4779	.4531	.7922	.4938	.8399

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113032 / 22kV Lodha Switching

Feeder No / Name : 304 / 22 KV TOYO/STEEL - I

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.4572	.4572			.4191	.381	.4191
9	.8002	.6859	.3429		.6859	.6859	.8002
10	.9526	.8764	.3772		.8002	.7621	.8383
11	.9054	.8764	.3772		.6859	.724	.8383
12	.9907	.8764	.4801		.9145	.8383	.9907
13	.8764	.8764	.4801		.7621	.8383	.9145
14	.8764	.8383	.4458		.7621	.8383	.9145
15	.9526	.9526	.4801	.3048	.8764	.7621	.8764
16	.9145	.9145	.3086		.9526	.8002	1.0669
17	.9145	.7621	.3086		.8002	.7621	.8764
18	.5335	.4191	.2743		.4954	.4572	.5335
19	.4572	.3429	.2743		.4191	.3429	.4572
20	.381	.3048			.3429	.3429	.3429
21	.3048	.3048			.3048	.3048	
22	.3048						
Max	.9907	.9526	.4801	.3048	.9526	.8383	1.0669
Min	.3048	.3048	.2743	.3048	.3048	.3048	.3429
Avg	.7081	.6777	.3772	.3048	.6587	.6314	.7591

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

ISHWAR NAGAR S/DN.[732] BU 4732

Substation No/ Name :- 113011 / SBRS

Feeder No / Name : 201 / G E SHIPPING

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	10-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)
12		.8299
21	.8299	
22	.7545	
23	.7167	
Max	.8299	.8299
Min	.7167	.8299
Avg	.7670	.8299

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

ISHWAR NAGAR S/DN.[732] BU 4732

Substation No/ Name :- 113019 / NITIE SUBSTATION

Feeder No / Name : 202 / NITIE GATE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.679	.6722		.6413	.6036	.6001	.6387
2	.6348	.6413	.5487	.6036	.5658	.583	.5636
3	.6036	.6413	.5658	.5281	.5658	.5658	.5448
4	.6036	.6224	.583	.5281	.5281	.583	.526
5	.5847	.6161	.5487	.5658	.5281	.5658	.6011
6	.6602	.6602	.5658	.5658	.5121	.583	.6199
7	.8299	.6908	.5487	.4904	.6036	.5658	.6011
8	.8865	.7356	.583	.7167	.6413	.6951	.6763
9	.9054	.9808	.6687	.679	.9054	.958	.958
10	.9431	.9088	.9431	.679	.7888	.9017	.8299
11	.8676	.8402	.7545	.7922	.7545	.8829	.8676
12	.8676	.8402	.7167	.7922	.7716	.9017	.8299
13	.811	.823	.8299	.7545	.8059	.9956	.9431
14	1.0185	.7888	.7167	.8299	.7716	.8266	.8676
15	.9709	.7545	.9054	.7922	.7373	.8078	.9054
16	.9431	.7888	.7922	.7545	.7202	.8102	1.0185
17	.9522	.7716	.7545	.679	.6687	.7702	.9431
18	.9709	.7545	.7922	.679	.8059	.9393	.8676
19	.9997	.8916	.9054	.7922	.7888	.9017	.9431
20	.9242	.8402	.9431	.7545	.823	.9205	.9054
21	.9335	.7888	.8299	.7922	.8402	.8641	.9431
22	.9054	.703	.7545	.7545	.7888	.8453	.8676
23	.7922	.6516	.7167	.7167	.6687	.789	.8299
24	.7167		.6173	.6413	.6413	.6173	.7138
Max	1.0185	.9808	.9431	.8299	.9054	.9956	1.0185
Min	.5847	.6161	.5487	.4904	.5121	.5658	.526
Avg	.8335	.7568	.7211	.6884	.7012	.7697	.7919

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

ISHWAR NAGAR S/DN.[732] BU 4732

Substation No/ Name :- 113019 / NITIE SUBSTATION

Feeder No / Name : 203 / TUNGWA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2075	.2075	.2058	.2263
2	.1867	.2075	.2058	.1886
3	.1867	.2075		.1886
4	.2075	.2054	.2229	
5	.2075	.1886	.2229	
6	.2263	.2054	.2229	
7	.2427	.2452	.2229	
8	.2641	.2641	.2401	
9	.3018	.2829	.2572	
10	.3206	.3601	.3395	
11	.415	.3601	.3395	
12	.3772	.4115	.3018	
13	.3547	.3429	.3018	
14	.4338	.3429	.3018	
15	.3772	.3429	.3772	
16	.3584	.3258	.2641	
17	.3361	.3429	.3395	
18	.2987	.3601	.3772	
19	.3961		.3772	
20	.4108	.463	.3395	
21	.2641	.2743	.3772	
22	.2427	.2401	.3395	
23	.2263	.2401	.2641	
24	.2263		.2743	.2263
Max	.4338	.463	.3772	.2263
Min	.1867	.1886	.2058	.1886
Avg	.2945	.2919	.2919	.2075

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

ISHWAR NAGAR S/DN.[732] BU 4732

Substation No/ Name :- 113019 / NITIE SUBSTATION

Feeder No / Name : 204 / RESIDENCY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.679	.6908	.5487	.7167	.6413	.6173	.603
2	.6413	.6348	.5144	.6413	.6413	.6001	.5653
3	.6224	.6036	.5487	.6413	.6036	.583	.5464
4	.6036	.5658	.583	.4527	.6036	.583	.5653
5	.6036	.5415	.5658	.4904	.5658	.6001	.4899
6	.6413	.5788	.6001	.6036	.5658	.6001	.5464
7	.7167	.6161	.6344	.679	.6036	.6001	.603
8	.811	.6602	.8573	.7167	.7922	.811	.7537
9	.8299	.8676	.8745	.9054	.7167	.7914	.6595
10	.8676	.8059	1.1317	.9808	.8059	.7349	.7922
11	.8402	.6859	1.2071	.9808	.9259	.8479	.8299
12	.9431	.823	1.1317	.9808	.8402	.9233	.7545
13	.9997	.8745	1.0185	.9054	.7716	.8479	.7922
14	1.0185	.9259	.9808	.9808	.7888	.9421	.8676
15	.8865	.9945	1.0185	1.0185	.8059	.9798	.8676
16	.8865	.9431	.9808	1.0562	.7888	.9986	.9054
17	.8676	.8573	.9431	.9808	.823	.9044	.8299
18	.811	.8059	.9054	.8676	.8059	.8291	.9054
19	.9619	.8745	.8676	.9431	.8916	.9233	.9054
20	.8402	.8402	.9808	1.0562	.7888	.8479	.8676
21	.8865	.7888	.9808	.9808	.823	.9233	.8299
22	.9054	.7716	.9808	.8299	.7716	.9421	.7545
23	.8299	.7202	.9431	.7922	.703	.8856	.7922
24	.7545		.6859	.7545	.7545	.6173	.716
Max	1.0185	.9945	1.2071	1.0562	.9259	.9986	.9054
Min	.6036	.5415	.5144	.4527	.5658	.583	.4899
Avg	.8103	.7596	.8535	.8315	.7426	.7889	.7393

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

ISHWAR NAGAR S/DN.[732] BU 4732

Substation No/ Name :- 113024 / M&B

Feeder No / Name : 201 / MMRDA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621		.7468	.7468	.724	.6535	.6535
2	.7621		.7282	.7095	.5906	.6348	.6535
3	.724		.6908	.7095	.5716	.6161	.6722
4	.6478		.6908	.7095	.724	.6348	.6722
5	.6478		.7095	.7095	.724	.6348	.7095
6	.724		.7655	.7095	.8002	.6908	.8215
7	1.0288		.8589	.7842	1.0288	.8775	.9335
8	1.0669	1.0642	.9335	.9335	.9907	1.0082	
9	1.1431	1.0456	.9335	.9709	1.1812	1.0829	1.0829
10		1.2323	1.0456	1.0829	1.1576	1.1203	1.1812
11	1.1576	1.2136	1.0829	1.105	1.1203	1.1203	1.1431
12	1.1203	1.0829	1.1203	1.0669	1.0456	1.0082	1.0669
13		1.0829	1.0456	1.0288	.9522	1.1203	1.0669
14	1.0269	1.0456	.9709	.9526	.9522	.9335	.9907
15		.9522	.9709	.9907	1.0082	.9709	1.0288
16	.9709	1.0269	.9709	.9145	.9335	.9335	1.0288
17		1.0456	.9709	.8954	.9709	.9335	1.0288
18		1.0829	1.0829	.9907	1.0456	1.0456	1.2193
19		1.307	1.307	1.2193	1.1576	1.2323	1.2955
20	1.363	1.3443	1.3443	1.2193	1.2696	1.2696	1.3336
21		1.307	1.307	1.2193	1.1949	1.307	1.3717
22	1.3443	1.1949	1.2696	1.2574	1.0082	1.1203	1.2193
23		1.0082	1.0456	.9145	.9149	.9335	.9907
24	.8383		.8215	.8962	.7811	.7655	.7842
Max	1.363	1.3443	1.3443	1.2574	1.2696	1.307	1.3717
Min	.6478	.9522	.6908	.7095	.5716	.6161	.6535
Avg	.9580	1.1273	.9756	.9474	.9520	.9437	.9978

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

ISHWAR NAGAR S/DN.[732] BU 4732

Substation No/ Name :- 113024 / M&B

Feeder No / Name : 202 / Neptune

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096		.2241	.1867	.1905	.2054	.1867
2	.2096		.168	.1867	.1524	.1867	.1867
3	.2286		.2054	.1494	.1524	.2054	.1867
4	.1905		.2241	.1494	.1524	.1494	.1867
5	.1905		.2241	.1867	.2286	.1867	.1867
6	.2667		.2054	.1867	.2667	.2054	.2241
7	.4572		.2614	.2241	.3429	.2801	.3734
8	.4191	.4108	.2614	.2614	.3429	.4108	.3361
9	.381	.3361	.4108	.2614	.4191	.4108	.4108
10		.3361	.3734	.4481	.2987	.4481	.4191
11	.3174	.3174	.3734	.4572	.3361	.2987	.3048
12	.2801	.2614	.3734	.3048	.2614	.3734	.3048
13		.2241	.2987	.3429	.1307	.2614	.3048
14	.2614	.1867	.2614	.3239	.2801	.2614	.3048
15		.2801	.2427	.2477	.2241	.2614	.3048
16	.2614	.168	.2241	.2286	.2241	.2241	.3048
17		.1867	.2614	.1905	.2241	.2614	.3048
18		.1867	.2614	.2667	.2241	.2614	.2667
19		.2241	.3361	.3048	.2987	.2987	.381
20	.3174	.3361	.2987	.3048	.2987	.2987	.381
21		.2987	.2987	.3239	.2987	.3361	.381
22	.3361	.2614	.2987	.362	.2987	.3361	.3048
23		.2241	.2427	.2286	.2427	.2987	.3048
24	.2096		.2614	.2241	.1905	.2427	.2241
Max	.4572	.4108	.4108	.4572	.4191	.4481	.4191
Min	.1905	.168	.168	.1494	.1307	.1494	.1867
Avg	.2835	.2649	.2746	.2646	.2533	.2793	.2948

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

ISHWAR NAGAR S/DN.[732] BU 4732

Substation No/ Name :- 113024 / M&B

Feeder No / Name : 209 / Hanuman silk mills

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362		.3734	.4108	.3239	.4108	.3734
2	.381		.3361	.3734	.3048	.3921	.3734
3	.362		.3361	.3734	.2667	.3734	.3734
4	.3429		.3547	.3734	.2477	.3734	.3734
5	.3429		.3734	.3361	.2667	.3734	.3734
6	.3429		.3361	.3361	.2667	.3734	.3734
7	.381		.3734	.3361	.3048	.4108	.3734
8	.381	.4108	.4108	.3361	.381	.4294	.4108
9	.724	.6348	.5601	.3734	.5716	.5601	.5601
10		.7842	.7095	.4481	.8589	.7282	.8002
11	.9149	.9709	.8589	.5716	.9335	.8589	.9145
12	1.0082	.9709	.8962	.5335	.9335	.8215	.9526
13		.8962	.8215	.5335	.8402	.7842	.9526
14	.9335	1.0082	.9335	.6097	.8775	.8589	1.0288
15		1.0374	.8215	.5716	.9335	.8962	1.0288
16	.9335	1.0456	.8962	.5335	.9149	.8962	1.0288
17		.9335	.8589	.4763	.9335	.7842	.9526
18		.9335	.8215	.4572	.8589	.7842	.9145
19		.7095	.6722	.4572	.7095	.6722	.7621
20	.7095	.6348	.5601	.4954	.6348	.5975	.6478
21		.5601	.5228	.4763	.5975	.5601	.6097
22	.5601	.5228	.5601	.4191	.5228	.5228	.5716
23		.5228	.5228	.3429	.4854	.4481	.5335
24	.4001		.3734	.4854	.2667	.4854	.4108
Max	1.0082	1.0456	.9335	.6097	.9335	.8962	1.0288
Min	.3429	.4108	.3361	.3361	.2477	.3734	.3734
Avg	.5675	.786	.5951	.4442	.5931	.5998	.6539

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

ISHWAR NAGAR S/DN.[732] BU 4732

Substation No/ Name :- 113024 / M&B

Feeder No / Name : 212 / Prestine

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2955		1.2696	1.3443	1.0288	1.2323	1.2136
2	1.2574		1.2323	1.1576	.9526	1.2136	1.1576
3	1.2193		1.2323	1.1949	.9526	1.1576	1.1576
4	1.1431		1.2136	1.1949		1.1203	1.1576
5	1.0669		1.1949	1.1949	.9145	1.1949	1.1763
6	1.2193		1.2696	1.1949	1.0288	1.1949	1.2323
7	1.5242		1.307	1.2323	1.2955	1.2696	1.3817
8	1.6385	1.5497	1.3443	1.2696	1.6385	1.5123	1.4937
9	2.0957	1.9231	1.6804	1.3817	1.9052	1.7551	1.9044
10		2.0538	1.7924	1.6057	2.0911	1.9978	2.21
11	2.2032	2.0538	1.8298	1.6766	2.1285	1.9791	2.2672
12	2.1472	2.0911	2.0165	1.5623	2.0538	1.9044	2.2481
13		1.9791	1.6804	1.4289	1.8858	1.7177	
14	2.1285	1.9791	1.643	1.5051	1.9231	1.7551	2.1338
15		2.0725	1.7924	1.4289	2.1658	1.7177	2.21
16	1.9978	1.9791	1.7551	1.2574	1.9231	1.7177	2.1338
17		2.0165	1.7551	1.3146	2.0165	1.7924	2.2291
18		1.9418	1.9044	1.3717	1.9418	1.8671	2.21
19		2.0538	2.0538	1.5432	1.9791	1.9044	2.21
20	1.9978	2.0538	1.9418	1.5623	1.9791	1.8671	2.0576
21		1.9044	1.7924	1.5242	1.7924	1.7551	1.9243
22	1.6804	1.6804	1.6804	1.4289	1.6057	1.5684	1.7528
23		1.4563	1.4563	1.2193	1.419	1.3817	1.4861
24	1.3336		1.307	1.3817	1.1431	1.307	1.2696
Max	2.2032	2.0911	2.0538	1.6766	2.1658	1.9978	2.2672
Min	1.0669	1.4563	1.1949	1.1576	.9145	1.1203	1.1576
Avg	1.6218	1.9243	1.5894	1.3740	1.6419	1.5785	1.7486

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

ISHWAR NAGAR S/DN.[732] BU 4732

Substation No/ Name :- 113029 / SOLARIES RECIEVING SUB
STATION

Feeder No / Name : 201 / SHIV SAKTI NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7			.5144	
9			.5335	.5281
10		.5041		.4715
11		.4854	.4904	.4338
12	.4527		.4527	.4338
13	.4481	.4382	.4668	.4338
14		.4382		.4338
15	.415	.381	.3772	.3961
16	.415	.362	.3961	.3584
17	.415	.4572	.4338	.3772
18	.415		.4715	.4904
19		.5335	.5093	.5847
20		.5975	.547	.6036
21		.5975	.5788	
22		.6161		.6413
23		.5716	.5281	.5658
24			.4763	.4904
Max	.4527	.6161	.5788	.6413
Min	.415	.362	.3772	.3584
Avg	.4268	.4985	.4840	.4828

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

ISHWAR NAGAR S/DN.[732] BU 4732

Substation No/ Name :- 113029 / SOLARIES RECIEVING SUB
STATION

Feeder No / Name : 202 / SOLARIS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7			.2286	
9			.381	.415
10		.6283	.6602	.6036
11		.7392	.679	.8299
12	.8589	.8131	.7167	.8676
13	.8215	.8764	.679	.8676
14		.7577		.8676
15	.8865	.7947	.7733	.8865
16	.811	.8131	.679	.8865
17	.811	.7947	.7356	.9242
18	.7167		.6036	.7733
19		.5525	.4715	.547
20		.4001	.3584	.4715
21		.3429	.3206	.3584
22		.3239		.3018
23		.2858	.2641	.3018
24			.2858	.2641
Max	.8865	.8764	.7733	.9242
Min	.7167	.2858	.2286	.2641
Avg	.8176	.6248	.5224	.6354

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113012 / NBRS

Feeder No / Name : 202 / NEELA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4755	.5359	.4887	.5304	.4435	.4163	.4938
2	.4572	.5041	.5304	.4938	.4108	.439	.4525
3	.4805	.4854	.4755	.4755	.3734	.4024	.4163
4	.4435	.4668	.499	.439	.3547	.3696	.4163
5	.462	.4435	.4805	.439	.3547	.3881	.4163
6	.499	.4715	.462	.4207	.3547	.4251	.4163
7	.4755	.5228	.4755	.4207	.3921	.3511	.4207
8		.5093	.3982	.4024	.415	.4207	.4344
9	.7023	.567	.5068	.4938	.4938	.5068	.5973
10	.9808	.8413	.8048	.6908	.7602	.8048	.8145
11	.9593	.9412	.9694	.7392	.9774	.9511	.9774
12	1.0208	1.0136	1.0974	.6767	1.0136	1.0679	.9694
13	1.0387	.9877	.9412	.7133	.9955	.9593	1.0136
14	.9328	.7964	.8507	.7499	.8326	.8326	.9231
15	1.0059	1.0242	.9593	.7499	.9671	1.086	.8869
16	1.0498	1.0791	.9231	.6697	.9774	.9774	1.0136
17	.9391	1.134	.905	.6335	.8688	.9412	1.0679
18	1.0099	.9511	.9694	.6447	.8962	.9774	1.0136
19	1.0099	.9877	.9412	.6878	.9593	.8326	.9412
20	.9671	.9231	.7602	.6036	.8869	.8507	.9877
21	.8238	.7499	.7421	.6099	.8145	.7682	.8869
22	.695	.6335	.695	.5359	.6584	.6584	.6767
23	.5788	.6036	.6219	.5415	.5121	.5487	.6036
24	.5304	.5914	.543	.567	.6161	.4572	.543
Max	1.0498	1.134	1.0974	.7499	1.0136	1.086	1.0679
Min	.4435	.4435	.3982	.4024	.3547	.3511	.4163
Avg	.7625	.7402	.7100	.5804	.6804	.6847	.7243

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113012 / NBRS

Feeder No / Name : 203 / SOHEL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8676	.9149	.7922	.8299	.695	.7167	.7356
2	.7733	.7762	.7545	.811	.6697	.6979	.6979
3	.7545	.7316	.7733	.7922	.6201	.6602	.679
4	.7356	.7059	.7356	.7545	.5959	.6413	.6602
5	.6979	.6878	.7167	.7733	.5784	.679	.6602
6	.7922	.7865	.7733	.7733	.7059	.7167	.7356
7	.8962	.9335	.8488	.811	.8131	.8299	.9054
8	1.0456	1.0562	.9619	.8865	.9335	.9808	.9808
9	1.3392	1.2883	1.226	.9997	1.2637	1.1389	1.2136
10	1.773	1.7737	1.7924	1.2449	1.6598	1.5655	1.8484
11	1.8298	1.8296	1.6991	1.3014	1.8861	1.7541	1.8107
12	1.9791	1.8861	1.8861	1.3392	1.905	1.7737	2.0748
13	1.6804	1.6598	1.643	1.2637	1.6804	1.4335	1.7924
14	1.8296	1.7364	1.8673	1.226	1.6804	1.5844	1.905
15	1.8671	2.0182	1.8673	1.1506	1.9978	1.773	1.905
16	1.9044	1.9427	1.8296	1.1128	1.8671	1.6787	1.8484
17	1.8111	1.905	1.8296	.8865	1.8107	1.6598	1.9239
18	1.587	1.6787	1.773	.8488	1.6057	1.4146	1.6787
19	1.5497	1.6598	1.6409	.9619	1.7353	1.4712	1.4901
20	1.5089	1.3957	1.4335	.9431	1.4712	1.3014	1.4146
21	1.226	1.1128	1.1763	.9431	1.226	1.094	1.1694
22	1.094	1.0562	1.0374	.8865	1.0751	.9808	1.094
23	1.0374	.9619	.9808	.8865	.9808	.9808	1.0374
24	.9619	.9242	.8488	.9054	.8215	.8488	.8676
Max	1.9791	2.0182	1.8861	1.3392	1.9978	1.7737	2.0748
Min	.6979	.6878	.7167	.7545	.5784	.6413	.6602
Avg	1.3142	1.3092	1.2870	.9722	1.2616	1.1823	1.2970

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113012 / NBRS

Feeder No / Name : 204 / ASIAN PAINTS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3584	.2785	.3584	.3206	.1658	.3206	.3206
2	.3584	.3052	.3584	.3206	.16	.3206	.3206
3	.3395	.285	.3395	.2915	.1658	.2829	.3018
4	.3395	.285	.3206	.3018	.1467	.2829	.2829
5	.3584	.2883	.3018	.3018	.1494	.2829	.2829
6	.3395	.2683	.3018	.3206	.1572	.3018	.3018
7	.3206	.2713	.3206	.3018	.16	.3206	.2641
8	.3584	.2753	.3206	.3018	.2092	.3584	.3395
9	.3582	.3961	.4904	.3018	.4338	.415	.4715
10	.6979	.6224	.6224	.3077	.6036	.6036	.6602
11	.7733	.7922	.6979	.3258	.7356	.6224	.7545
12	.8962	.7922	.7545	.3366	.811	.7733	.8299
13	.6722	.6413	.6979	.362	.6979	.547	.7167
14	.8488	.7733	.7922	.2846	.7842	.7356	.7922
15	.8676	.8865	.7167	.3921	.8488	.7545	.7922
16	.811	.7356	.7733	.3734	.8402	.6602	.7922
17	.8299	.8299	.7356	.3366	.7922	.679	.7922
18	.7545	.679	.6602	.1829	.7545	.4904	.6602
19	.5847	.5847	.6224	.23	.6224	.4527	.5281
20	.4854	.4904	.5281	.2397	.5093	.3961	.5281
21	.3921	.4338	.3772	.2256	.4338	.3961	.4715
22	.3429	.3584	.3961	.189	.3772	.3584	.3961
23	.3018	.3584	.3395	.1707	.3206	.3395	.3772
24	.3772	.3086	.3584	.3584	.16	.3395	.3018
Max	.8962	.8865	.7922	.3921	.8488	.7733	.8299
Min	.3018	.2683	.3018	.1707	.1467	.2829	.2641
Avg	.5319	.4975	.5077	.2949	.4600	.4598	.5116

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113012 / NBRS

Feeder No / Name : 205 / SHIV COLD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5914	.5601	.6219	.6219	.5228	.6219	.5853
2	.4805	.6348	.6653	.6219	.5415	.6036	.5487
3	.5228	.6161	.6099	.6219	.4854	.5544	.5487
4	.4668	.5788	.5601	.6036	.5041	.5729	.5304
5	.5041	.6535	.5228	.6036	.5601	.5415	.5304
6	.5975	.679	.4854	.6036	.4854	.6099	.6036
7	.6219	.5658	.5853	.5487	.5658	.6401	.567
8	.7682	.6979	.7316	.6219	.6979	.7133	.7499
9	1.1016	1.0242	.9955	.7499	1.0317	.9593	1.0059
10	1.9547	1.828	1.5912	.9054	1.7194	1.4842	1.6827
11	2.2565	2.2314	1.9022	1.0059	2.1538	1.8656	2.0633
12	2.2028	2.3045	2.0119	.9492	2.1582	1.8839	2.0485
13	1.9342	1.9204	1.6461	.924	1.8656	1.6108	1.8642
14	2.0328	2.1033	1.7193	.8215	2.0538	1.7556	1.4632
15	2.2624	2.1719	1.8642	.8402	1.9936	1.7918	2.2862
16	2.2744	2.1719	1.8642	.9709	2.1357	1.9185	2.2862
17	2.1719	2.0668	1.8107	.8402	2.0485	1.7558	2.268
18	1.8446	1.701	1.5729	.6979	1.8656	1.4299	1.957
19	1.4842	1.4969	1.3575	.7356	1.4632	1.2437	1.5524
20	1.0791	1.0974	1.0425	.6979	1.0974	.9877	1.0425
21	.9335	.8596	.8507	.6161	.8779	.7865	.924
22	.7545	.7499	.7316	.5975	.823	.7133	.7023
23	.7167	.7316	.6401	.5975	.7392	.6036	.5853
24	.5914	.6602	.695	.5853	.5601	.695	.5853
Max	2.2744	2.3045	2.0119	1.0059	2.1582	1.9185	2.2862
Min	.4668	.5601	.4854	.5487	.4854	.5415	.5304
Avg	1.2562	1.2544	1.1282	.7243	1.2062	1.0976	1.2075

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113012 / NBRS

Feeder No / Name : 207 / Inamdar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.567	.5601	.543	.5487	.5228	.5304	.5121
2	.5359	.499	.5914	.5121	.5093	.4938	.4938
3	.5041	.5041	.5729	.5121	.4715	.4805	.4755
4	.4854	.5041	.5359	.4755	.4715	.4435	.4572
5	.5041	.4854	.5228	.4938	.4904	.4805	.4572
6	.5281	.5847	.5041	.4572	.6224	.4668	.5121
7	.5914	.6413	.5121	.5121	.5601	.4805	.5487
8	.6401	.6224	.5853	.567	.5281	.5487	.6036
9	.7762	.7059	.7316	.5487	.7059	.7133	.7783
10	.9593	.9774	1.0242	.7282	.9412	.8962	1.0608
11	1.0924	1.0974	1.0974	.7783	1.086	1.0059	1.0974
12	1.0517	1.1584	1.1157	.7164	1.0317	1.0791	1.1403
13	.929	.9511	.9328	.7059	.905	.9511	.9774
14	.9774	.9774	.9511	.6154	.8869	.8869	.9412
15	1.0517	1.086	1.0679	.6584	1.0059	.9774	1.0679
16	1.0749	1.0974	1.1041	.5973	1.0136	.9511	1.1157
17	1.0166	1.134	1.134	.6036	1.0317	1.0791	1.086
18	1.0056	1.0608	1.0242	.5611	.9774	.9511	1.086
19	.9774	1.1222	1.0608	.6036	1.1157	1.0059	1.0791
20	1.0341	1.0136	1.0059	.6348	.9328	.9328	1.0059
21	.8775	.8145	.8962	.6161	.7865	.8048	.9145
22	.7577	.7207	.7316	.6348	.6401	.695	.8048
23	.6722	.6401	.6401	.6224	.6036	.6401	.6767
24	.6767	.679	.5973	.6219	.5788	.5611	.5487
Max	1.0924	1.1584	1.134	.7783	1.1157	1.0791	1.1403
Min	.4854	.4854	.5041	.4572	.4715	.4435	.4572
Avg	.8036	.8182	.8118	.5969	.7675	.7523	.8100

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113012 / NBRS

Feeder No / Name : 208 / NAHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6032	1.4784	1.6221	1.5278	1.4449	1.5089	1.5278
2	1.5844	1.5497	1.5844	1.4712	1.386	1.4712	1.5278
3	1.5466	1.4449	1.5655	1.4146	1.2986	1.4146	1.5089
4	1.4712	1.39	1.5089	1.3769	1.2489	1.3769	1.5089
5	1.4146	1.2489	1.5278	1.3957	1.182	1.3957	1.4901
6	1.4335	1.39	1.5466	1.3203	1.4299	1.4901	1.5278
7	1.6032	1.4784	1.5278	1.4146	1.4083	1.5655	1.5844
8	1.9239	1.5546	1.7541	1.5844	1.6827	1.9616	1.6787
9	2.1691	2.1502	2.0559	1.6787	2.0182	2.1313	2.0748
10	2.5463	2.6427	2.7161	2.037	2.8292	2.6595	2.3954
11	2.7161	2.452	2.6217	2.1125	2.8481	2.8481	2.9613
12	3.006	2.7538	2.8104	2.2445	2.999	2.8104	2.6972
13	2.6029	2.4143	2.4897	2.0936	2.5766	2.452	2.3339
14	2.5463	2.2032	2.3388	2.0559	2.4897	2.584	2.5086
15	2.7349	2.6029	2.7349	2.1879	2.7073	2.7538	2.7538
16	3.0178	2.6783	2.6783	1.9616	2.726	2.8104	2.7349
17	2.9047	2.4897	2.6217	1.9427	2.9047	2.8292	3.0367
18	2.8481	2.6029	2.7349	2.0748	2.7915	2.6029	2.8104
19	2.6972	2.6406	2.5274	2.1691	2.7726	2.8292	2.6406
20	2.6326	2.5274	2.4709	1.8673	2.4897	2.5652	2.584
21	2.3388	1.9239	2.0182	1.6057	2.0182	2.0936	2.037
22	1.7924	1.905	1.8107	1.5154	1.8296	1.5844	1.9805
23	1.6057	1.7353	1.7164	1.4937	1.7164	1.6221	1.7164
24	1.8107	1.46	1.6409	1.5466	1.3213	1.4523	1.5466
Max	3.0178	2.7538	2.8104	2.2445	2.999	2.8481	3.0367
Min	1.4146	1.2489	1.5089	1.3203	1.182	1.3769	1.4901
Avg	2.1896	2.0299	2.1093	1.7539	2.0883	2.1172	2.1319

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113012 / NBRS

Feeder No / Name : 209 / TITAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9795	.9709	.9231	.9774	.8029	.8048	.9134
2	.9425	.9335	.924	.9412	.7282	.7762	.8954
3	.9335	.9242	.8871	.905	.6979	.7207	.8417
4	.9149	.8865	.8589	.8688	.6535	.7655	.788
5	.9149	.8589	.8215	.905	.6348	.8029	.7701
6	.9619	.9896	.8029	.8326	.7468	.8775	.9313
7	1.134	1.1883	.9694	.9231	.9709	.9979	1.1222
8	1.1765	1.2012	1.1157	.9955	1.0642	1.1458	1.1641
9	1.4377	1.4449	1.2308	1.0136	1.3717	1.3032	1.4632
10	1.595	1.6834	1.5565	1.3611	1.6278	1.647	1.6644
11	1.7187	1.7193	1.6651	1.2757	1.8107	1.7194	1.6827
12	1.595	1.5746	1.6832	1.2971	1.7924	1.7013	1.7013
13	1.3847	1.3535	1.448	1.1999	1.5181	1.3575	1.4632
14	1.3937	1.3394	1.3575	1.0498	1.4815	1.3432	1.5181
15	1.56	1.6461	1.5565	1.2308	1.647	1.5043	1.6651
16	1.5777	1.5912	1.5746	1.0924	1.6278	1.5043	1.7193
17	1.5083	1.4449	1.5203	1.0566	1.5364	1.5043	1.7375
18	1.5432	1.6095	1.5927	.9231	1.5546	1.4506	1.701
19	1.5091	1.6278	1.5927	.9511	1.5912	1.4299	1.7558
20	1.5424	1.5939	1.6289	.924	1.6278	1.647	1.6278
21	1.3432	1.3213	1.3032	.9335	1.3535	1.2536	1.4449
22	1.134	1.2012	1.1584	.8686	1.1458	1.1765	1.2071
23	1.0829	.9694	1.0679	.8962	.9877	.9593	1.0608
24	1.0719	.9896	.9231	.9412	.8589	.8779	.8954
Max	1.7187	1.7193	1.6832	1.3611	1.8107	1.7194	1.7558
Min	.9149	.8589	.8029	.8326	.6348	.7207	.7701
Avg	1.2898	1.2943	1.2568	1.0151	1.2430	1.2196	1.3222

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113012 / NBRS

Feeder No / Name : 212 / Samarth Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0179		.0179	.0189		.0181	.0189
2	.0179		.0179	.0189		.0181	.0189
3	.0179		.0181	.0189		.0183	.0189
4	.0181		.0181	.0189		.0181	.0189
5	.0181		.0181	.0189		.0181	.0189
6	.0181		.0179	.0189		.0179	.0189
7	.0183		.0181	.0189		.0179	.0189
8	.0181		.0181	.0189		.0181	.0189
9		.0179	.0189	.0189	.0179		.0179
10		.0179	.0189		.0179		.0181
11		.0181	.0189		.0177		.0181
12		.0177	.0189		.0177	.0189	.0181
13		.0181	.0189		.0175	.0189	.0181
14		.0177	.0189		.0179	.0189	.0179
15		.0175	.0189		.0179	.0189	.0179
16		.0179	.0189		.0179	.0189	.0179
17		.0179	.0189		.0177	.0189	.0177
18		.0177	.0189		.0179	.0189	.0177
19		.0177	.0189		.0179	.0189	.0179
20		.0179	.0189		.0181	.0189	.0179
21		.0179	.0189		.0181	.0189	.0179
22		.0179	.0189		.0181	.0189	.0177
23		.0179	.0189		.0181	.0189	.0181
24	.0181		.0175	.0189		.0181	.0189
Max	.0183	.0181	.0189	.0189	.0181	.0189	.0189
Min	.0179	.0175	.0175	.0189	.0175	.0179	.0177
Avg	.0181	.0178	.0186	.0189	.0179	.0185	.0183

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113012 / NBRS

Feeder No / Name : 213 / FILIX

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.192	.2829	.2829	.16	.2641	.2641
2	.2075	.1555	.2829	.2829	.1572	.2829	.2641
3	.2075	.1383	.2263		.1467	.2641	.2641
4	.1886	.1362	.2263	.2075	.1387	.2641	.2641
5	.2075	.192	.2263	.2075	.1467	.2641	.2641
6	.2263	.1362	.2641	.1886	.1414	.2829	.2075
7	.2075	.1509	.2075	.1886	.1467	.2641	.2641
8	.2263	.216	.2075	.2641	.136	.2641	.2829
9	.3403	.3584	.3395	.3018	.3584	.3395	.3395
10	.5847	.7842	.4904	.3395	.679	.5093	.6036
11	.7922	.8215	.679	.415	.7655	.679	.7733
12	.7167	.811	.5847	.5093	.8488	.6224	.7167
13	.7356	.7545	.6602	.3921	.7167	.5847	.7356
14	.679	.7733	.5658	.415	.679	.5658	.7733
15	.6979	.7733	.6036	.3734	.6535	.6413	.7922
16	.7167	.7545	.5658	.3734	.679	.6036	.7282
17	.679	.6224	.4904	.3077	.6036	.547	.6413
18	.6413	.8299	.415	.2315	.547	.6036	.6602
19	.4904	.4527	.3584	.2515	.4715	.4904	.5658
20	.4294	.4338		.2515	.3961	.4527	.3961
21	.415	.3772	.3961	.2601	.3395	.3961	.3772
22	.3012	.3018	.3206	.2031	.4715	.2641	.2263
23	.2427	.2641	.2452	.2315	.4338	.3206	.2452
24	.2829	.2427	.2829	.2263	.1572	.2829	.2829
Max	.7922	.8299	.679	.5093	.8488	.679	.7922
Min	.1886	.1362	.2075	.1886	.136	.2641	.2075
Avg	.4351	.4447	.3879	.2915	.4156	.4189	.4555

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113031 / RUNWAL

Feeder No / Name : 202 / Runwal Green-II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2075	.2075		.1886	.1886	.1509	.1509
2	.2075	.2075		.1698	.1886	.1698	.1886
3	.2075	.1886		.1886	.1698	.132	.1698
4	.1886	.1886		.1509	.1886	.132	.1886
5	.2075	.1698		.132	.1698	.1509	.1509
6	.2075	.1698		.2075	.1698	.1698	.1698
7	.2263	.1886		.1698	.2263	.132	.1698
8	.2263	.2263		.1886	.2829	.1886	.1886
9	.2829	.1886	.2452	.2452	.2829		.2075
10	.3395	.2263	.2829	.2263	.3018	.3018	.2263
11	.3584	.3206	.3395	.2641	.3206	.2263	.2263
12	.3584	.2452	.3206	.3206	.2452	.3018	.2641
13	.2641	.2075	.2641	.3018	.3018	.2263	.2452
14	.3206	.2263	.2641	.2829	.2452	.2263	.2641
15	.3395	.2452	.3018	.2641	.2641	.2452	.2452
16	.3206	.2641	.3206	.2452	.2641	.3018	.2641
17	.2263	.2641	.2075	.2263	.2263	.2263	.2641
18	.2263	.2829	.2829	.3206	.2829	.1886	.2829
19	.3206	.3018	.3018	.3018	.2452	.3018	.3772
20	.3018	.3206	.3395	.2829	.2641	.2641	.3584
21	.2829	.3018	.3395	.3395	.2829	.2263	.3772
22	.2829	.2829	.2641	.3206	.3018	.2263	.3395
23	.2452	.2641	.2641	.2452	.2641	.2641	.2829
24	.3584	.2075	.2452	.2075	.2452	.2452	.2075
Max	.3584	.3206	.3395	.3395	.3206	.3018	.3772
Min	.1886	.1698	.2075	.132	.1698	.132	.1509
Avg	.2711	.2373	.2865	.2413	.2468	.2173	.2421

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113031 / RUNWAL

Feeder No / Name : 203 / Runwal Green III

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0543	.0724		.0543	.0543	.0543	.128
2	.0543	.0724		.0543	.0543	.0543	.1097
3	.0543	.0543		.0543	.0543	.0543	.1646
4	.0566	.0543		.0724	.0543	.0543	.1463
5	.0543	.0543		.0724	.0543	.0543	.128
6	.0543	.0543		.0724	.0543	.0543	.1829
7	.0724	.0724		.0724	.0543	.0543	.2012
8	.0724	.0724		.0724	.0543	.0543	.2378
9	.0905	.0905	.0724	.0724	.0543		.1829
10	.0905	.0724	.0724	.0724	.0543	.0914	.2012
11	.1267	.0724	.0724	.0905	.0724	.0732	.1646
12	.1086	.0724	.0724	.0543	.0724	.0549	.1829
13	.0724	.0724	.0905	.0543	.0724	.0732	.2012
14	.0724	.0724	.0724	.0543	.1267	.0549	.1886
15	.0543	.0724	.0543	.0724	.1448	.0732	.1646
16	.0724	.0543	.0724	.0543	.1448	.0732	.1463
17	.1086	.0543	.0724	.0543	.1629	.0732	.1646
18	.0724	.0543	.0905	.0543	.1267	.0914	.2012
19	.1086	.0724	.1086	.0543	.1086	.1646	.1829
20	.0905	.0724	.1267	.0543	.1086	.1463	.1029
21	.0905	.0724	.0543	.0543	.1448	.1829	.1829
22	.0905	.0724	.0724	.0543	.1267	.1646	.1646
23	.0724	.0724	.0724	.0543	.0724	.128	.1829
24	.0724	.0724	.0724	.0724	.0543	.0543	.128
Max	.1267	.0905	.1267	.0905	.1629	.1829	.2378
Min	.0543	.0543	.0543	.0543	.0543	.0543	.1029
Avg	.0778	.0679	.0781	.0626	.0867	.0841	.1684

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113031 / RUNWAL

Feeder No / Name : 206 / Runwal Green I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0663	.0663		.0663	.0497	.0497	.0503
2	.048	.0663		.0497	.0497	.0497	.0503
3	.0497	.0497		.0497	.0497	.0497	.0503
4	.0497			.0497	.0497	.0497	.0671
5	.0497	.0497		.0497	.0497	.0497	.0503
6	.0497	.0663		.0497	.0497	.0497	.0671
7	.0829	.0663		.0497	.0497	.0497	.0671
8	.0829	.0829		.0663	.0663	.0497	.0671
9	.0663	.0497	.0497	.0663	.0663		.0671
10	.0829	.0497	.0663	.0829	.0663	.1006	.0503
11	.0829	.0663	.0663	.0829	.0663	.0838	.0503
12	.0995	.0497	.0829	.0829	.0497	.0503	.0503
13	.0497	.0829	.0663	.0663	.0497	.0671	.0503
14	.0497	.0497	.0663	.0663	.0663	.0503	.0335
15	.0497	.0497	.0332	.0663	.0663	.0671	.0503
16	.0663	.0497	.0332	.0663	.0663	.0838	.0503
17	.0497	.0497	.0497	.0663	.0332	.0503	.0335
18	.0995	.0497	.0663	.0497	.0332	.0671	.0503
19	.0663	.0497	.0829	.0497	.0332	.0671	.0671
20	.0829	.0497	.0663	.0663	.0497	.0671	.1174
21	.0829	.0497	.0995	.0663	.0497	.1006	.1006
22	.0663	.0497	.0663	.0663	.0663	.0671	.0671
23	.0663	.0497	.0332	.0497	.0497	.0671	.0566
24	.0663	.0829	.0497	.0663	.0497	.0497	.0503
Max	.0995	.0829	.0995	.0829	.0663	.1006	.1174
Min	.048	.0497	.0332	.0497	.0332	.0497	.0335
Avg	.0669	.0576	.0611	.0622	.0532	.0625	.0590

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113036 / HDIL

Feeder No / Name : 201 / Khalasa Compound

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3109	.3584	.3395	.3018	.2641	.3018	.3206
2	.3258	.3395	.2987	.3206	.2477	.3174	.3361
3	.3361	.3395	.3174	.2987	.2452	.3018	.3206
4	.3077	.3206	.2987	.2829	.2667	.3018	.2987
5	.3174	.3018	.2614	.3018	.2452	.3174	.3018
6	.3361	.3395	.3361	.3174	.2641	.3206	.3174
7	.3475	.3361	.2987	.2987	.2452	.3361	.3511
8	.4251	.3921	.3696	.3174	.2801	.3696	.3801
9	.5914	.5601	.5729	.3326	.5373	.5853	.4656
10	.8413	.8131	.7682	.4435	.7442	.7522	.7442
11	.8326	.8316	.8131	.439	.7442	.7796	.7712
12	.8596	.8299	.823	.439	.815	.7362	.8063
13	.6805	.6584	.6584	.4108	.7796	.631	.7682
14	.8238	.7392	.691	.4024	.6447	.7059	.7522
15	.815	.7762	.7619	.3841	.7316	.7087	.7783
16	.7973	.7842	.7316	.362	.724	.7712	.7964
17	.8505	.9335	.7842	.3544	.7316	.7602	.7522
18	.7522	.7316	.6767	.2507	.695	.6201	.6733
19	.6805	.5853	.6219	.2772	.6697	.6154	.6516
20	.543	.4805	.4938	.2195	.5121	.5544	.4938
21	.439	.4024	.3511	.2534	.3658	.4066	.3696
22	.3658	.3361	.3696	.2614	.3547	.3696	.3475
23	.3696	.3361	.3206	.2641	.3395	.3361	.3511
24	.3109	.3547	.3109	.3395	.2641	.3361	.3361
Max	.8596	.9335	.823	.4435	.815	.7796	.8063
Min	.3077	.3018	.2614	.2195	.2452	.3018	.2987
Avg	.5525	.5367	.5112	.3280	.4880	.5098	.5202

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113036 / HDIL

Feeder No / Name : 202 / Killburn

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8779	.8383	1.2071	.9907	.6287	.6478	.8573
2	1.0456	.7621	1.3203	1.0374	.6668	.6287	.7922
3	1.0642	.6859	1.2826	.9335	.6036	.5658	.7049
4	1.1203	.9145	1.1128	.8573	.6602	.8573	.9907
5	.8962	1.0669	1.0562	.7545	.6287	.6979	.7356
6	.7468	.6478	.9709	.7049	.6097	.9431	1.3336
7	.7865	.7545	.9335	.9431	1.0374	.724	.7922
8	.9335	1.0185	1.1203	.8676	1.0562	1.3957	1.226
9	1.0456	1.0185	.9979	.7842	1.643	1.0185	1.4937
10	1.8111	1.6804	1.2803	.9335	2.0328	1.419	1.3306
11	1.5524	2.4272	1.3717	.8131	1.9959	1.9589	1.4632
12	1.9753	2.0748	1.5684	.8871	1.3535	1.4998	1.4632
13	1.4632	1.2696	1.6461	.7316	2.0119	1.4632	1.0985
14	1.4632	1.2323	1.8461	.6584	1.7741	1.382	1.1946
15	1.8823	2.0538	1.643	.6661	1.3169	1.4175	1.267
16	1.7737	1.5089	1.4998	.6154	1.2178	1.2483	1.3169
17	1.39	1.7353	1.267	.6219	1.3717	1.4842	1.829
18	2.1216	1.4784	1.2489	.724	1.5023	1.7193	1.2536
19	1.7924	1.8671	1.1946	1.1523	1.1222	1.2894	1.2197
20	1.2567	1.643	1.448	1.0745	1.3491	1.0974	1.307
21	1.0719	.9979	1.0456	1.2308	.8775	.8501	1.0974
22	.9709	1.2696	.9619	.6602	1.2826	1.0562	1.4842
23	1.1317	.9054	.8488	.6602	.7922	1.3203	1.4146
24	.7316	1.094	1.1203	1.0669	.5716	.6602	.7621
Max	2.1216	2.4272	1.8461	1.2308	2.0328	1.9589	1.829
Min	.7316	.6478	.8488	.6154	.5716	.5658	.7049
Avg	1.2877	1.2894	1.2497	.8487	1.1711	1.1394	1.1845

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113020 / Hariomnagar receiving

Feeder No / Name : 201 / 11kV SAMPADA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1043	1.1218	1.0341	1.2445	1.0867	1.0692	.9991
2	1.0517	1.1157	.9991	1.1919	.8413		.929
3	.9991	1.0166	.9816	1.1393	.7888		.9114
4	.964	.9816	.9465	1.1043	.8764		.8764
5	.964	.9991	.964	1.0692	.9114		.9465
6	1.0867	1.1043	1.0166	1.6476	.9991	.8764	1.0517
7	1.3672	1.2795	1.0692	1.3146	1.1043	1.1744	1.1744
8	1.4373	1.4548	1.1393	1.4899	1.4373	1.262	1.4022
9	1.4899	1.5249	1.3321	1.6476	1.5775	1.5775	1.4723
10		1.6301	1.4548	1.9982	1.4899	1.5249	1.6126
11	1.595	1.3847	1.5424	1.7177	1.4373	1.6126	1.595
12	1.5249	1.3847	2.0157	1.6476		1.4899	1.56
13	1.4022	1.5424	1.8054	1.3496	1.3672	1.3496	1.4723
14	1.262	1.2795	1.595	1.2795	1.262	1.2269	1.3672
15	1.1744	1.1568	1.4899	1.2269		1.1393	1.2971
16	1.262	1.1218	1.4548	1.1218	1.4198	1.1218	1.2971
17	1.2269	1.1744	1.6476	1.1919	1.262	1.1744	1.3321
18	1.3672	1.5249	1.7878	1.3146	1.1919	1.3321	1.6126
19	1.6476	1.6301	1.9982	1.5775	1.56	1.7177	1.8054
20	1.6827	1.6126	1.9806	1.6301	1.5424	1.6476	1.8229
21	1.595	1.56	1.7878	1.4373		1.5775	1.7878
22	1.5074	1.3847	1.6476	1.3321	1.3146	1.4198	1.595
23	1.3321	1.2971	1.4899	1.0867	1.0517	1.2795	1.3847
24	1.1393	1.1568	1.1919	1.4198	1.0867		1.1393
Max	1.6827	1.6301	2.0157	1.9982	1.5775	1.7177	1.8229
Min	.964	.9816	.9465	1.0692	.7888	.8764	.8764
Avg	1.3123	1.3100	1.4322	1.3825	1.2194	1.3460	1.3518

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113020 / Hariomnagar receiving

Feeder No / Name : 202 / HARIOM NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2294	.2321	.2486	.1989		.1823	.2155
2	.1966	.1989	.2321	.1658	.1823		.1989
3	.1966	.1989	.1989	.1658	.1658		.1989
4	.1638	.1823	.1823	.1326	.1823		.1989
5	.1638	.1658	.1823	.1326	.1989		.2321
6	.2458	.2321	.2321	.1658	.2321	.1989	.2486
7	.2785	.2652	.2486	.1658		.1989	.2652
8	.2458	.2984	.2321	.1658	.2984	.1989	.2652
9	.3113	.3149	.2652	.2321	.3149	.2486	.2294
10		.3149	.2486	.2155	.3315	.2984	.3277
11	.3441	.3441	.3315	.2321	.2652	.3315	.2984
12	.2949	.3315	.2984	.2652		.2652	.2785
13	.2458	.2652	.2486	.2321	.2486	.2486	.2652
14	.2458	.2321	.2321	.1989	.2155	.2321	.2785
15	.213	.2652	.1492	.2155		.2321	.2785
16	.1966	.2486	.1823	.1658	.2818	.1989	.2458
17	.1802	.2818	.2321	.1658	.2486	.2321	.2785
18	.2622	.2652	.2155	.1989	.2155	.2321	.2984
19	.2622	.2818	.2486	.2321	.2486	.2652	.2622
20	.2785	.2486	.2321	.2321	.2155	.2486	.2622
21	.2785	.2486	.2321	.2321		.2652	.2652
22	.2622	.2818	.2321	.2321	.2155	.2321	.2622
23	.2785	.2818	.2321	.2321	.2486	.2155	.2458
24	.2321	.2458	.2155	.1823	.2155	.1989	.2155
Max	.3441	.3441	.3315	.2652	.3315	.3315	.3277
Min	.1638	.1658	.1492	.1326	.1658	.1823	.1989
Avg	.2437	.2594	.2314	.1982	.2382	.2362	.2548

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113020 / Hariomnagar receiving

Feeder No / Name : 203 / KALPTARU

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.5506	.5182	.4858		.4858	.4858
2	.4481	.5182	.4858	.4534			.4534
3	.4001	.4696	.4534	.4049			.4534
4	.4001	.4534	.4534	.3887			.4534
5	.3521	.421	.4858	.3563			.5182
6	.5601	.6154	.583	.421	.4372	.5182	.6154
7	.8322	.7935	.6478	.4534	.5668	.6154	.7125
8	.7842	.7773	.6316	.5668		.6964	.7125
9	.7362	.7773	.7773	.7125	.8259	.8421	.7611
10		.6478	.7935	.6802	.6316	.7449	.6478
11	.6241	.5761	.664	.6478	.583	.7125	.6154
12	.5441	.502	.5992	.7125		.6154	.5344
13	.5281	.5992	.5992	.583	.4858	.5506	.5182
14	.5121	.502	.5182	.5344	.4534	.5182	.5182
15	.4321	.4641	.4696	.4858		.421	.4534
16	.3841	.4049	.4534	.4858	.5182	.4534	.421
17	.4321	.4372	.4534	.5344	.4372	.4049	.421
18	.4961	.5506	.4858	.5992	.4858	.5182	.4858
19	.6081	.664	.6154	.664	.5344	.583	.583
20	.6081	.2279	.6154	.6802	.583	.6316	.6154
21	.6562	.6478	.6802	.6154		.6154	.6478
22	.6241	.6154		.6154	.583	.5992	.6478
23	.6401	.6154	.5992	.6154	.5506	.6154	.6154
24	.5281	.5992	.5506	.5344	.4858	.5344	.5506
Max	.8322	.7935	.7935	.7125	.8259	.8421	.7611
Min	.3521	.2279	.4534	.3563	.4372	.4049	.421
Avg	.5483	.5596	.5710	.5513	.5441	.5838	.5600

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113020 / Hariomnagar receiving

Feeder No / Name : 204 / SAINATH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2103	.2103	.1928	.1928		.1578	.3156
2	.1928	.1928	.1753	.1753	.1402		.1402
3	.1753	.1753	.1753	.1402			.1402
4	.1753	.1753	.1578	.1402			.1578
5	.1402	.1578	.1578	.1227			.1753
6	.2103	.2279	.1753	.1753	.1227	.2103	.2103
7	.2454	.2629	.1928	.1753	.1928	.2103	.2454
8	.2629	.2804	.1928	.2454	.2454	.2103	.2804
9	.2454	.2804	.2804	.2629	.1753	.2279	.2103
10		.2629	.2103	.2454	.1928	.2103	.2454
11	.1928	.1928	.2103	.2103	.1753	.4206	.1753
12	.1578	.2103	.1928	.2454		.2454	.2103
13	.1402	.1402	.2103	.2103	.1402	.2804	.2103
14	.1578	.1578	.1753	.1928	.1578	.3506	.1402
15	.1402	.1928	.1402	.1753		.2454	.1578
16	.1402	.1402	.1578	.1402	.1753	.2104	.1227
17	.1578	.1753	.1402	.1402	.1402	.2104	.1227
18	.1578	.1578	.1928	.1402	.1928	.1402	.1402
19	.2279	.2454	.2103	.1928	.2103	.2103	.1928
20	.2103	.2279	.2103	.2103	.1753	.1928	.1753
21	.2454	.2454	.2279	.2103		.2454	.2103
22	.2629	.2279	.2279	.1928	.4031	.2103	.2279
23	.2804	.2629	.2103	.1753	.1753	.1928	.2103
24	.2103	.2103	.2103	.1928	.1753	.1753	.1928
Max	.2804	.2804	.2804	.2629	.4031	.4206	.3156
Min	.1402	.1402	.1402	.1227	.1227	.1402	.1227
Avg	.1974	.2089	.1928	.1877	.1877	.2279	.1921

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113020 / Hariomnagar receiving

Feeder No / Name : 205 / 11kV RICHA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4805	.499	.4435	.3881		.4435	.3696
2	.4251	.4435	.4066	.3511			.3696
3	.4066	.4251	.3881	.3142			.3696
4	.3696	.3881	.3326	.2772			.3326
5	.3696	.4066	.3142	.2402			.3696
6	.4435	.462	.3696	.2772			.4066
7	.4805	.5544	.3881	.3326	.499	.4066	.4435
8	.4805	.462	.3881	.4066	.5175	.3696	.4066
9	.4066	.462	.462	.462	.4435	.5175	.4066
10	.4805	.4435	.3881	.4805	.4435	.499	.4066
11	.4435	.4251	.4435	.3511	.3696	.4066	.3696
12	.3696	.3511	.3696	.4435		.3696	.3881
13	.3326		.2957	.3326	.2957	.3696	.3142
14	.2957	.2957	.2957	.2772	.2772	.3142	.3326
15	.2957	.2957	.2587	.2772		.2587	.2957
16	.2772	.2957	.2957	.2772	.2218	.2587	.2957
17	.2587	.2957	.2402	.3142	.2033	.2957	.3326
18	.3142	.3696	.3142	.3142	.3142	.2402	.3142
19	.4805	.5175	.5175	.499	.499	.4805	.5175
20	.499	.5359	.499	.499	.5175	.5175	.499
21	.4805	.5175	.462	.4805		.4805	.5175
22	.5914	.5914	.462	.4805	.499	.4805	.5175
23	.499	.5359	.4805	.4435	.4144	.462	.4805
24	.4805	.499	.462	.4435	.462	.4435	.4435
Max	.5914	.5914	.5175	.499	.5175	.5175	.5175
Min	.2587	.2957	.2402	.2402	.2033	.2402	.2957
Avg	.4150	.4379	.3866	.3735	.3985	.4007	.3958

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113020 / Hariomnagar receiving

Feeder No / Name : 301 / ETERNITY-I Incomer to NON SHEDDABLE EXPRESS HV FEEDERS
 Eternity Feeder KV- 22 / (CONTINUOUS PROCESS)(NO STAGGERING)
 INCOMING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.2861	3.4004	2.963	3.0308		2.9199	2.846
2	3.1741	3.2895	2.8532	2.9199			2.5133
3	3.0994	3.2156	2.7801	2.7721			2.3655
4	2.9127	3.0308	2.7069	2.6612			2.3285
5	2.8006	2.9569	2.7801	2.5133			2.6981
6	3.062	3.2526	2.9264	2.5873		2.7721	3.0678
7	3.6595	3.6961	3.219	2.6981	3.1417	3.0308	3.4374
8	3.9209	4.0657	3.4751	3.4004	3.5852	3.6591	3.8809
9	4.257	4.1027	3.658	3.5113	3.807	3.9918	4.0657
10		4.5831	4.1701	3.77	4.3983	4.1766	4.2135
11	4.4063	4.4353	4.1823	4.0657	4.2875	4.0657	4.3614
12	4.4437	4.1027	3.914	3.807		4.0287	4.3614
13	4.1823		4.0604	3.6591	3.6222	3.8809	3.9918
14	4.2943	4.1027	3.8043	3.5482	4.0287	3.77	4.0657
15	4.1076	4.2135	3.8775	3.2156		3.4004	3.8439
16		3.6591	3.7677	3.2526	3.77	3.4374	4.1396
17	3.7342	3.733	3.658	3.1417	3.4743	3.6222	4.3244
18	3.7715	3.9548	3.8043	3.2526	3.807	3.6222	3.9548
19	4.4063	4.2505	4.3896	3.9918	4.2875	4.4723	4.9528
20	4.4437	4.2135	4.353	4.1027	4.4353	4.5092	4.8788
21	4.8171	4.2135	4.0238	4.3244		4.5092	5.1745
22	4.4437	4.1396	3.6946	3.77	3.9548	4.0657	4.1766
23	4.0329	3.8439	3.7677	2.9504	3.5482	3.5482	4.1027
24	3.4355	3.5482	3.4004	3.3653	3.0308	3.4004	3.2526
Max	4.8171	4.5831	4.3896	4.3244	4.4353	4.5092	5.1745
Min	2.8006	2.9569	2.7069	2.5133	3.0308	2.7721	2.3285
Avg	3.8496	3.8262	3.5929	3.3463	3.8119	3.7441	3.7916

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113040 / Pioneer S/stn.

Feeder No / Name : 204 / 11 Kv Chintamani

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4755		.2195		1.1462	
2		.4706		.2263		1.1584	
3		.4706		.2172		1.1584	
4		.4706		.2263		1.1584	
5		.4755		.2263		1.1584	
6		.6219		.2641		1.3169	
7		.6219		.2263			
8		.7164	.6516	.3018	.5792	.0585	.6154
9	.6878				.6805		.6516
10	.788		.788		.6447		.6089
11	.788		.5014		.6805		.6447
12	.788	.724	.3224		.5792		.6154
13	.6447		.3224		.4656		.5731
14	.6447		.3224		.5014		.4656
15	.5731		.2534		.5014		.5014
16	.6447		.2149		.4835		.4656
17	.5731		.2149		.4656		.5014
18	.7522		.2865		.4656		.5373
19	.8238		.3224		.6447		.7164
20	.8238		.3224		.6878		.7522
21	.8238		.3224		.6447		.7164
22	.7522		.3582		.6089		.7164
23	.7164	.724	.2865	.4706	.5731	.6154	.6447
24		.6805		.2534		1.4327	
Max	.8238	.724	.788	.4706	.6878	1.4327	.7522
Min	.5731	.4706	.2149	.2172	.4656	.0585	.4656
Avg	.7216	.5865	.3660	.2632	.5754	1.0226	.6079

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113040 / Pioneer S/stn.

Feeder No / Name : 205 / 11 Kv Ganadhiraj

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.267		1.1946			
2		1.267		1.2449			
3		1.2536		1.2449			
4		1.2803		1.2449			
5		1.267		1.2449			
6		1.6289		1.3203			
7		1.7375		1.2178			
8		2.0416	1.5203	1.5402	1.9547	1.8099	1.8099
9	1.9547				1.7551		1.8099
10	1.8625		1.8267		1.7909		1.8267
11	1.8461		1.8823		1.6476		1.7193
12	1.7013	1.8461	1.6834		1.5402		1.576
13	1.4685		1.5043		1.3611		1.4327
14	1.4118		1.3611		1.2536		1.3611
15	1.3756		1.2894		1.2308		1.3253
16	1.2894		1.2536		1.1641		1.2894
17	1.3253		1.2536		1.1104		1.2894
18	1.4685		1.576		1.2894		1.3969
19	1.6834		1.8267		1.7375		1.7909
20	1.7737		1.8267		1.7737		1.8267
21	1.8625		1.8267		1.7909		1.8267
22	1.7551		1.6476		1.6118		1.8267
23	1.6834	1.8099	1.448	1.5565	1.5565	1.7013	1.7375
24		1.7375		1.448			
Max	1.9547	2.0416	1.8823	1.5565	1.9547	1.8099	1.8267
Min	1.2894	1.2536	1.2536	1.1946	1.1104	1.7013	1.2894
Avg	1.6308	1.5579	1.5818	1.3257	1.5355	1.7556	1.6153

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113521 / P.M.G.P. RECEIVING

Feeder No / Name : 201 / ANKITA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3898	.3366	.3721	.3366	.3012	.2835	.3189
2	.3544	.3012	.3366	.3012	.3012	.2481	.2658
3	.3189	.2835	.3012	.2835	.4961	.2303	.2481
4	.3012	.2835	.2835	.2835	.2658	.2303	.2481
5	.3189	.3366	.3012	.3012	.2835	.2658	.3366
6	.3366	.4252	.3898	.3366	.3544	.3189	.4075
7	.4252	.5138	.3544	.3012	.4252	.3544	.3898
8	.5847	.4607	.4252	.3898	.5316	.4252	.4961
9	.443	.4607	.4784	.443	.3544	.5138	.5138
10	.443	.5493	.5316	.4607	.4784	.5138	.567
11	.4784	.4961	.5316	.4252	.4607	.4784	.4607
12	.443	.443	.4961	.4252	.4784	.443	.443
13	.3721	.443	.4961	.3721	.3898	.4252	.443
14	.3544	.4252	.4252	.3544	.3721	.4075	.4075
15	.4075	.443	.3721	.3366	.3544	.3366	.3544
16	.3721	.3898	.3012	.3012	.3189	.3012	.3898
17	.3544	.3366	.3898	.3012	.3366	.3012	.3366
18	.4252	.4031	.3898	.3012	.3898	.443	.3189
19	.5138	.4557	.4784	.4252	.4252	.5316	.4784
20	.5138	.4607	.5359	.4252	.4961	.5316	.5138
21	.4961	.4382	.4607	.4252	.4252	.4607	.4252
22	.4607	.4252	.443	.4075	.4252	.443	.443
23	.4252	.4252	.462	.4075	.4075	.4252	.4784
24	.4252	.3898		.3721	.3189	.3544	.3366
Max	.5847	.5493	.5359	.4607	.5316	.5316	.567
Min	.3012	.2835	.2835	.2835	.2658	.2303	.2481
Avg	.4149	.4136	.4155	.3632	.3913	.3861	.4009

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113521 / P.M.G.P. RECEIVING

Feeder No / Name : 204 / 11kV UNITISED FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1227	.1402	.124	.124	.124	.1402	.1227
2	.1227	.1227	.124	.124	.124	.1227	.1227
3	.1052	.1052	.1063	.1063	.1063	.1052	.1052
4	.1052	.1227	.1063	.1063	.1063	.1052	.1052
5	.1052	.1402	.124	.1063	.1063	.1227	.1052
6	.0267	.1402	.124	.124	.124	.1402	.1227
7	.1227	.1402	.1417	.124	.1417	.1402	.1753
8	.1227	.1402	.1417	.124	.1417	.1227	.1578
9	.1402	.1402	.1417	.1595	.1417	.1402	.1227
10	.1402	.1227	.1417	.1417	.124	.1227	.1227
11	.1227	.1227	.124	.1417	.124	.1227	.1227
12	.1227	.1227	.124	.1417	.124	.1227	.1227
13	.1227	.1227	.124	.124	.124	.1227	.1227
14	.1227	.1227	.124	.124	.124	.1227	.1227
15	.1227	.1227	.124	.1063	.124	.1227	.1227
16	.1227	.1227	.124	.1063	.124	.1227	.1227
17	.1227	.1227	.124	.124	.124	.1227	.1227
18	.1227	.1227	.124	.124	.124	.1227	.1227
19	.1227	.1402	.124	.1402	.124	.1227	.1402
20	.1227	.1402	.124	.1417	.1417	.1227	.1402
21	.1402	.1578	.1595	.1417	.1417	.1402	.1753
22	.1402	.1402	.1417	.1417	.124	.1402	.1578
23	.1402	.1402	.1417	.1417	.1417	.1227	.1402
24	.1227	.1402		.124	.1417	.124	.1227
Max	.1402	.1578	.1595	.1595	.1417	.1402	.1753
Min	.0267	.1052	.1063	.1063	.1063	.1052	.1052
Avg	.1202	.1315	.1286	.1276	.1270	.1257	.1300

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113521 / P.M.G.P. RECEIVING

Feeder No / Name : 205 / LALITA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6089	.6447	.6089	.5731	.5731	.5611	.591
2	.5373	.591	.5731	.5373	.5373	.5194	.5373
3	.5014	.5373	.5373	.5194	.5014	.4835	.5014
4	.5014	.5194	.5194	.5014	.4835	.4835	.4835
5	.5731	.5731	.567	.5014	.5014	.5552	.6089
6	.6984	.6984	.6447	.5373	.6447	.591	.6984
7	.8417	.8596	.7164	.6089	.8596	.6626	.8059
8	.8775	.9492	.8417	.788	.8775	.8596	.8417
9	.9313	1.0387	.9313	.8238	.8596	.9313	.8954
10	1.0029	.985	1.0029	1.0029	.9134	.8775	.8417
11	.9671	1.0208	.9313	1.0387	.9313	.9671	1.0029
12	.8954	.9313	.8417	.9492	.8775	.8596	.8954
13	.8417	.8775	.8417	.8775	.7343	.788	.8596
14	.7343	.788	.6805	.7343	.6984	.6805	.7343
15	.7164	.7343	.6447	.6984	.6089	.6268	.7343
16	.7343	.7164	.7164	.6626	.6268	.6447	.7522
17	.7343	.7522	.7522	.6626	.6626	.7343	.788
18	.8417	.8417	.788	.7164	.7164	.8238	.8775
19	1.0387	1.0387	1.0208	.9492	.9313	1.0029	1.0745
20	1.0029	1.0387	1.0745	.9134	.9313	1.0029	1.0029
21	.9492	1.0208	.985	.8596	.9313	.9671	1.0387
22	.8954	.9492	.8596	.8417	.8596	.8596	.9492
23	.8059	.788	.7522	.7164	.7164	.7701	.8238
24	.7343	.6984	.7343	.6805	.6447	.6805	.6626
Max	1.0387	1.0387	1.0745	1.0387	.9313	1.0029	1.0745
Min	.5014	.5194	.5194	.5014	.4835	.4835	.4835
Avg	.7902	.8164	.7736	.7373	.7343	.7472	.7917

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113521 / P.M.G.P. RECEIVING

Feeder No / Name : 206 / NEELAM NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3222	1.2536	1.0985	
2		.3222	1.2178	.9922	
3		.2915	1.182	.9568	
4		.2713	1.182	.9568	
5		.3052	1.2178	.9922	
6		.3222	1.2894	1.1871	
7		.39	1.182	1.5947	
8		.3561	1.3969	1.7187	
9		.4525	1.6118	1.7187	
10			1.8804		
11			1.8625		
12			1.5939		
13			1.5223		
14			1.3073		
15			1.2357		
16			1.1462		
17	.3012		1.1641		
18	.3189		1.2536		1.3213
19	.4252		1.5939		1.6297
20	.4252		1.5939		1.8088
21	.443		1.6476		1.7551
22	.4607		1.4864		1.773
23	.4252	1.4864	1.4148		1.6297
24		.3721	1.3253	1.3073	
Max	.4607	1.4864	1.8804	1.7187	1.8088
Min	.3012	.2713	1.1462	.9568	1.3213
Avg	.3999	.4447	1.3984	1.2523	1.6529

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113521 / P.M.G.P. RECEIVING

Feeder No / Name : 207 / 11kV YASHODHAN FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5973	.5611	.543	.5792	.4961	.5194	.5373
2	.543	.5249	.5068	.543	.4887	.4835	.5014
3	.5068	.5249	.4887	.3258	.4525	.4835	.5014
4	.5068	.5068	.4706	.4706	.4344	.5194	.4835
5	.5792	.6154	.4887	.4887	.4525	.5373	.5373
6	.6335	.7059	.4887	.543	.5792	.5194	.5731
7	.7421	.7783	.5792	.5973	.6335	.6626	.6805
8	.7602	.7964	.724	.6335	.724	.7164	.7343
9	.8145	.7783	.8145	.7964	.7421	.8238	.7343
10	.7964	.7421	.7421	.7602	.6878	.8596	.7343
11	.7421	.7421	.7964	.7783	.6697	.7522	.6984
12	.7059	.7059	.7421	.7421	.6878	.6805	.6984
13	.6335	.6878	.6516	.7087	.7059	.6447	.6268
14	.543	.5792	.5068	.7421	.5611	.5552	.591
15	.543	.5611	.5249	.5792	.5068	.5014	.5194
16	.5249	.5068	.543	.4706	.5792	.4835	.4835
17	.5068	.543	.5068	.4706	.5249	.4835	.5194
18	.5792	.543	.5792	.5249	.5068	.5731	.5373
19	.724	.724	.7964	.724	.6878	.7164	.7164
20	.724	.6878	.7602	.6697	.724	.7343	.7522
21	.7602	.724	.7964	.6878	.724	.7701	.7701
22	.7602	.7421	.7783	.724	.7602		.788
23	.6878	.724	.6878	.6201	.6878	.6984	.7421
24	.6878	.5792	.6878	.6697	.5847	.5792	.6089
Max	.8145	.7964	.8145	.7964	.7602	.8596	.788
Min	.5068	.5068	.4706	.3258	.4344	.4835	.4835
Avg	.6501	.6493	.6335	.6187	.6084	.6216	.6279

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113521 / P.M.G.P. RECEIVING

Feeder No / Name : 209 / Shripad

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3696	.3511	.3326	.3326	.3326	.3326	.3142
2	.3142	.3142	.2957	.2957	.3142	.3142	.2957
3	.2957	.2957	.2772	.2772	.2957	.2772	.2772
4	.2957	.2957	.2772	.2772	.2896	.2772	.2772
5	.3511	.3511	.2957	.2957	.3326	.3142	.3326
6	.3881	.3881	.3511	.3142	.3696	.3511	.4066
7	.3696	.4251	.2957	.3142	.3696	.3142	.3881
8	.462	.4251	.3696	.4066	.4435	.4066	.3326
9	.462	.3881	.4066	.3881	.4066	.3881	.3696
10	.4251	.3511	.3881	.3881	.4251	.3511	.3696
11	.3511	.4435	.4066	.4066	.4066	.462	.3511
12	.3142	.3142	.3142	.3696	.3142	.3696	.2772
13	.3142	.3326	.2957	.2957	.2957	.3142	.3142
14	.3142	.3142	.2772	.2957		.2957	.3142
15	.3142	.2957	.2587	.2957	.2587	.2957	.2957
16	.3142	.2957	.3142	.2957	.2587	.2772	.2587
17	.2957	.2957	.2772	.3142	.2772	.3142	.2587
18	.3326	.3142	.3142	.2772	.3326	.3326	.3696
19	.4251	.4435	.4251	.462	.4066	.4066	.462
20	.4435	.4805	.4435	.4805	.3881	.4251	.462
21	.4435	.462	.4435	.4435	.4066	.462	.462
22	.4435	.462	.4251	.4435	.3881	.4435	.462
23	.4251	.462	.4066	.4251	.3696	.4435	.4435
24	.3881	.3881	.4066	.3881	.3881	.3142	.3696
Max	.462	.4805	.4435	.4805	.4435	.462	.462
Min	.2957	.2957	.2587	.2772	.2587	.2772	.2587
Avg	.3688	.3704	.3457	.3534	.3509	.3534	.3527

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113521 / P.M.G.P. RECEIVING

Feeder No / Name : 210 / Gurupushyamrut

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.724	.724	.6697	
2		.6516	.6516	.6335	
3		.5973	.5973	.5973	
4		.5792	.5792	.5792	
5		.5973	.6154	.5973	
6		.7059	.6878	.7964	
7		.8507	.8145	1.0136	
8		.905	.8145	1.1403	
9		1.0136	1.0136	1.0317	
10			1.0679		
11			1.0317		
12			.9412		
13			.8688		
14			.7421		
15			.7059		
16			.6878		
17	.6661		.7059		
18	.7011		.724		.7783
19	.9816		.9955		.9774
20	.9816		.9593		1.086
21	.929		1.0317		1.0317
22	.9465		.9795		.9955
23	.4252	.8869	.8869		.9774
24		.7619	.8145	.7783	
Max	.9816	1.0136	1.0679	1.1403	1.086
Min	.4252	.5792	.5792	.5792	.7783
Avg	.8044	.7521	.8184	.7837	.9744

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113521 / P.M.G.P. RECEIVING

Feeder No / Name : 211 / Navghar HTP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2033	.2033	.1663	.1848	.2033	.1663	.1663
2	.1663	.2033	.1478	.1663	.1848	.1478	.1663
3	.1478	.1848	.1294	.1478	.1663	.1478	.1478
4	.1294	.1663	.1294	.1294	.1478	.1663	.1478
5	.1663	.1663	.1663	.1478	.1663	.1848	.1848
6	.2033	.2218	.1663	.1848	.2033	.2033	.2218
7	.2402	.2402	.1848	.1848	.2772	.2402	.2587
8	.2587	.3142	.2402	.2218	.3142	.2957	.2772
9	.2772	.3142	.2772	.2772	.2587	.2772	.2587
10	.2587	.2957	.2957	.2772	.3142	.2957	.3511
11	.2772	.3142	.2957	.3142	.2402	.2772	.3142
12	.2402	.2218	.2587	.2587	.2218	.3142	.2587
13	.2957	.2402	.2587	.2957	.2033	.2218	.2587
14	.2587	.2402	.2218	.2957	.2218	.2218	.2587
15	.2218	.1848	.2402	.1848	.2033	.2218	.1848
16	.2218	.1663	.1848	.1848	.1848	.1663	.1848
17	.2218	.1848	.2402	.1848	.2033	.2033	.2033
18	.2033	.2218	.2033	.2218	.1848	.2033	.2587
19	.2587	.3142	.3142	.2957	.2587	.2772	.3326
20	.2587	.3511	.3142	.2772	.2587	.2587	.3142
21		.2957	.2772	.2957	.2957	.2587	.3142
22		.2772	.2402	.2957	.2587	.2957	.3142
23	.2772	.2033	.2402	.2402	.2402	.2587	.2957
24	.2587	.2218	.2033	.2587	.2402	.2402	.2033
Max	.2957	.3511	.3142	.3142	.3142	.3142	.3511
Min	.1294	.1663	.1294	.1294	.1478	.1478	.1478
Avg	.2293	.2395	.2248	.2302	.2272	.231	.2449

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 113021 / LOK EVEREST

Feeder No / Name : 201 / ACC

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7762	1.0269	.7655	.7468	.6838	.8962	.7095
2	.7023	.9709	.6535	.6908	.6653	.8589	.6535
3	.6468	.9149	.6348	.6535	.6653	.8215	.6161
4	.6468	.8215	.6348	.6099	.6468	.7468	.5601
5	.7023	.7468	.6468		.7207	.7095	.6722
6	.8316	.8402	.7207		.8316	.7468	.8029
7	.9979	.9522	.7762	.8029	.9979	.8402	.9744
8	1.1088	1.0269	1.0534		1.105	.9149	1.2323
9	1.2936	1.2883	1.251	1.0829	1.2197	1.2696	1.2696
10	1.848	1.7002	1.4563	1.1827	1.587	1.5123	1.6804
11	1.8858	1.7741	1.6804	1.0534	1.7924	1.6244	1.8671
12	1.8484	1.7364	1.6057	1.1827	1.6991	1.4937	1.8111
13	1.6991	1.6078		1.0719	1.643		1.7364
14	1.5812	1.475	1.419	1.0349	1.4937	1.3817	1.6057
15	1.4563	1.531		.961	1.4937	1.307	1.6617
16	1.6991	1.4937	1.307	.8871	1.5123		1.643
17	1.6617	1.386	1.363	.924	1.4377		1.6244
18	1.531	1.4969		.9055	1.4003	1.3256	1.5497
19	1.531	1.419	1.3443	.961	1.475	1.3817	1.5684
20	1.4003			.9979	1.3256	1.251	1.475
21	1.307	1.2197	1.2136	1.0349	1.251		1.3443
22	1.251	1.1203		1.0349	1.1203	1.0642	1.307
23	1.1763	1.0642	1.0082	.9055	1.0082	.9896	1.2136
24	.924	1.0642	.8775	.8029	.8383		
Max	1.8858	1.7741	1.6804	1.1827	1.7924	1.6244	1.8671
Min	.6468	.7468	.6348	.6099	.6468	.7095	.5601
Avg	1.2711	1.2468	1.0743	.9299	1.1922	1.1124	1.2860

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 113021 / LOK EVEREST

Feeder No / Name : 202 / LOK KAILASH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4938	.4066	.3921	.4435	.5487	.5228
2	.4066	.4938	.3511	.3696	.4251	.5121	.4805
3	.3696	.4572	.3511	.3511	.4066	.4938	.4668
4	.3696	.4207	.3511	.3326	.4066	.4572	.4294
5	.4001	.3658	.3696	.3326	.4251	.4207	.4854
6	.4382	.4163	.3696	.3696	.4435	.4572	.5415
7	.4763	.5121	.4435	.4481	.4715	.4938	.5788
8	.5175	.5853	.4805	.462	.5175	.5304	.6099
9	.6283	.6767	.5359	.5041	.5914	.6219	.7842
10	.9328	.8316	.7655	.7049	.8962	.8131	.9511
11	1.0974	1.0719	1.1763	.9335	1.1157	1.134	1.1706
12	1.1706	.8316	1.2752	.9907	1.262	1.2986	1.3169
13	1.2071	1.2567		.9055	1.262		1.2803
14	1.1157	1.1458	1.1389	.8871	1.1706	1.0269	1.2986
15	1.1523	1.0903		.8131	1.134	1.1273	1.2437
16	1.2071	1.1088	1.2752	.8383	1.1523		1.2437
17	1.1765	1.1827	1.3256	.8764	1.262		1.3535
18	1.2071	1.2752		1.0098	1.3717	1.251	1.4449
19	1.2437	1.262	1.2936	1.0669	1.4449	1.2567	1.4449
20	1.1523			.9979	1.2803	1.1949	1.3535
21	.9145	1.0719	1.0269	.9717	1.0974		1.1157
22	.7682	.6838		.724	.7133	.7947	.8596
23	.567	.5093	.5228	.5525	.5611	.5975	.6584
24	.4763	.5121	.462	.4066	.4572		
Max	1.2437	1.2752	1.3256	1.0669	1.4449	1.2986	1.4449
Min	.3696	.3658	.3511	.3326	.4066	.4207	.4294
Avg	.8105	.7937	.7327	.6767	.8463	.7911	.9406

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 113021 / LOK EVEREST

Feeder No / Name : 204 / CITY OF JOY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0719	1.2382	1.0349	.9979	.9795	1.0534	.8686
2	.9979	1.2012	.924	.961		1.0164	.8316
3	.924	1.1458	.924	.924	.924	.9425	.7842
4	.9055	1.1088	.924	.8686	.9055	.8686	.7842
5	1.0164	1.0164	.961	.9055	.9795	.8316	.9335
6	1.0288	1.1765	.9979	.961	1.1088	.924	1.1389
7	1.5242	1.386	1.0719	1.0164	1.3121	1.0349	1.3817
8	1.6004	1.6078	1.2936	1.1643	1.2197	1.2567	1.4377
9	1.4969	1.6078	1.5154	1.4937	1.4045	1.5339	1.4003
10	1.423	1.4784	1.3256	1.6385	1.46	1.423	1.386
11	1.2936	1.3121	1.251	1.4784	1.2567	1.3957	1.2567
12	1.3121	1.0164	1.1949	1.3306	1.1088	1.2012	1.1273
13	.9979	1.0534		1.1827	.9425		.9425
14	.9795	.9979	1.0456	1.0349	.8131	.8775	.9425
15	.8871	.8686		.961	.8501	.7842	.8871
16	.8131	.7762	.924	.8573	.8316		.8501
17	.8501	.9055	.9522	.924	.8501		.8501
18	.8686	.9425		.9979	.9055	.9522	.9425
19	1.3491	1.2567	1.3443	1.3908	1.1273	1.2696	1.2382
20	1.2567			1.2936	1.2197	1.2774	1.3491
21	1.3676	1.2567	1.3256	1.2936	1.2012		1.386
22	1.3491	1.2752		1.2567	1.2197	1.2136	1.423
23	1.3121	1.2382	1.251	1.2193	1.1763	1.1576	1.3491
24	1.2567	1.2936	1.0903	1.0534	1.0642		
Max	1.6004	1.6078	1.5154	1.6385	1.46	1.5339	1.4377
Min	.8131	.7762	.924	.8573	.8131	.7842	.7842
Avg	1.1618	1.1809	1.1237	1.1335	1.0809	1.106	1.1083

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 113021 / LOK EVEREST

Feeder No / Name : 205 / NEW SHANTI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6653	.8402	.7207	.7762	.5914	.7468	.7207
2	.6468	.8029	.6283	.7392	.5729	.7095	.6722
3	.6283	.7468	.6283	.6908	.5544	.6535	.6161
4	.6283	.6908	.6348	.6283	.5544	.5975	.6908
5	.6653	.6535	.6722	.6653	.5914	.5601	.7468
6	.7207	.7468	.7282	.7023	.6653	.6908	.8402
7	.8131	.9335	.7392	.7468	.7621	.7842	.9335
8	.8871	.9335	.7947	.7842	.8192	.9335	1.0456
9	1.0719	1.1763	1.1576	.8402	.924	1.0456	1.1949
10	1.6804	1.5339	1.419	.924	1.419	1.4937	1.5708
11	1.7737	1.5893	1.531	1.1088	1.643	1.6991	1.9035
12	1.6804	1.6817	1.5123	1.1458	1.6244	1.6244	1.7556
13	1.7177	1.5339		.961	1.4937		1.6448
14	1.531	1.4045	1.4045	.9979	1.587	1.4937	1.7926
15	1.6244	1.6632		.8871	1.6617	1.643	1.7002
16	1.6244	1.5684	1.2489	.8871	1.587		1.6448
17	1.531	1.531	1.419	.8501	1.5684		1.7187
18	1.531	1.4377		.8131	1.4937	1.4937	1.6817
19	1.4937	1.4784	1.307	1.0349	1.4563	1.4003	1.6078
20	1.2323			.961	1.2883	1.3121	1.3306
21	1.1763	.9795	1.0552	.9795	1.2023		1.2012
22	1.0642	.9979		.8316	1.1576	1.1016	1.0829
23	.9335	.924	.8589	.7392	.9149	.9149	1.0456
24	.7392	.8775	.7392	.8215	.6653		
Max	1.7737	1.6817	1.531	1.1458	1.6617	1.6991	1.9035
Min	.6283	.6535	.6283	.6283	.5544	.5601	.6161
Avg	1.1692	1.1620	1.0105	.8548	1.1166	1.0999	1.2670

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 113021 / LOK EVEREST

Feeder No / Name : 207 / SANT DYNESHWAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8316	.924	.7947	.8316	.7392	.8048	.7392
2	.7947	.8686	.7023	.7947	.7207	.7316	.6908
3	.7392	.8316	.6838	.7392	.724	.695	.6348
4	.7207	.7762	.6838	.6838	.7023	.6535	.5601
5	.7392	.7023	.7023	.7392	.7621	.5853	.6722
6	.8131	.7392	.7577	.7762	.8131	.695	.8029
7	.9425	.8316	.8871	.8131	.9055	.7682	.9335
8	.9907		.9979	.961	.961	.8962	
9	1.1088	1.1458	1.0903	1.0269	1.1827	1.0791	1.1458
10	1.2752	1.2936	1.2696	1.2193	1.1706	1.2752	1.2382
11	1.3491	1.386	1.307	1.2012	1.1888	1.2254	1.2382
12	1.2936	1.2012	.9979	1.1273	1.1523	1.1706	1.2197
13	1.1458	1.1827		.9795	1.0974		1.1088
14	1.1088	1.0534	.9335	.9795	1.0425	.9709	1.1273
15	1.1458	1.1273		.9055	1.1157	1.0269	1.2012
16	1.0903	1.1458	1.1576	.8316	1.0608		1.2012
17	1.0903	1.1088	.961	.924	1.0791		1.2012
18	1.0719	1.1458		.9526	1.1157	1.0349	1.3121
19	1.2382	1.3121	1.363	1.0719	1.2803	1.2323	1.423
20	1.2012			.9979	1.2437	1.2012	1.386
21	1.1643	1.1273	1.2323	1.1643	1.1523		1.2567
22	1.0534	1.0719		1.1088	1.0608	1.0164	1.1523
23	1.0164	.9425	1.0164	.9335	.9335	.924	1.1088
24	.961	.961	.8686	.8871	.8501		
Max	1.3491	1.386	1.363	1.2193	1.2803	1.2752	1.423
Min	.7207	.7023	.6838	.6838	.7023	.5853	.5601
Avg	1.0369	1.0399	.9688	.9437	1.0023	.9467	1.0615

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 113021 / LOK EVEREST

Feeder No / Name : 208 / OLD RAM GOPAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0534	1.1622	1.1506	1.0669	.5914	1.0288	1.0098
2	1.0164	1.1241	1.0374	1.0098	.5729	.9717	.9526
3	.9979	1.0479	1.0374	.9526	.5544	.9335	.8865
4	.9795	.9526	1.0164	.8954	.5544	.8954	.8316
5	1.0098	.8573	1.0185	.8573	.5914	.8002	.9145
6	1.0288	.9717	1.0164	.8865	.6653	.8954	.9907
7	1.0288	1.0288	1.0719	.9054	.7577	.9526	1.0456
8	1.3336	1.105	1.2826	.8954	.8501	1.0098	1.1812
9	1.7147	1.6004	2.0144	.8192	1.2193	1.3717	1.6575
10	2.4958	2.32	2.3815	.9907	2.1338	1.8484	2.3815
11	2.5911	2.4331	2.4272	.9526	2.4577	2.0005	2.4577
12	2.7054	2.452	2.5339	.9145		2.0182	2.6101
13	2.2672	1.9404		.8686	1.7528		2.1719
14	2.4577	2.3765	2.3815	.924	2.21	2.0386	2.3243
15	2.5339	2.4897		.8764	2.21	1.9814	2.5339
16	2.6101	2.5652	2.3815	.9145	2.1719		2.1719
17	2.4196	2.4709	2.2862	.7023	2.1719		2.191
18	2.3815	2.3765		.7811	2.0386	1.6766	2.0767
19	2.3053	2.2822	2.191	.724	1.9433	1.5051	1.8861
20	1.9243			.7621	1.7147	1.3817	1.7147
21	1.2384	1.2752	1.2574		1.3717		1.1622
22	1.2193	1.3203		.7049	1.086	1.0751	1.2384
23	1.1812	1.1128	1.1812	.6859	1.0669	.9808	1.1241
24	1.1431	1.2193	1.1458	1.1241	.679		
Max	2.7054	2.5652	2.5339	1.1241	2.4577	2.0386	2.6101
Min	.9795	.8573	1.0164	.6859	.5544	.8002	.8316
Avg	1.7349	1.6732	1.6217	.8789	1.3637	1.3350	1.6311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 113021 / LOK EVEREST

Feeder No / Name : 301 / 22 KV RUNWAL ANTHURIAM
Feeder KV- 22 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.2241
3					.2987	.2987	.239
6					.2763	.2987	.2539
7						.2667	.2987
8		.3429				.2987	.5974
9		.3429	.3395		.2987	.3429	.3361
10	.381			.2987	.381	.8332	.6797
11	.381		.4108	.2987	.381	.4108	.381
12	.6797	.3326	.6342	.2987	.6797	.6721	.381
13	.381				.381		.6797
14	.381	.2987	.3361		.381	.2763	.381
15	.3429	.2957	.2297	.2987	.6797	.3734	.6972
16	.3429		.3258		.381	.2763	
17	.3048	.2987			.3048		.716
18	.3429				.6797	.2987	.381
19	.381				.3429	.3734	.4191
20	.3048				.381	.3361	.381
21	.3429				.6797	.3211	.3429
22	.381				.4191	.3734	.381
23	.381				.6797	.2465	.3429
24	.2614	.381	.2614	.2614	.2987	.2987	.2539
Max	.6797	.381	.6342	.2987	.6797	.8332	.716
Min	.2614	.2957	.2297	.2614	.2763	.2465	.2241
Avg	.3726	.3275	.3625	.2912	.4402	.3664	.4183

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 113039 / RUNWAL ANTHURIAM

Feeder No / Name : 201 / RAMONA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3					.0896	.0579	.056
6					.0896	.0597	.0672
8						.0784	.0728
9					.0709		
10				.0747		.0878	.0579
11				.0747			
12	.0747		.0281	.0747	.0541	.0597	
13							.0259
14		.0747				.0579	
15			.0415	.0747	.0597		.0394
16						.0523	
17		.0747					.0212
18					.0616	.0597	
21					.0672	.0616	
23					.0672	.056	
24	.0747			.0747	.0878	.0635	.0672
Max	.0747	.0747	.0415	.0747	.0896	.0878	.0728
Min	.0747	.0747	.0281	.0747	.0541	.0523	.0212
Avg	.0747	.0747	.0348	.0747	.0720	.0631	.0510

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 113039 / RUNWAL ANTHURIAM

Feeder No / Name : 202 / GEMINI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3					.196	.1792	.1344
6					.2147	.168	.168
8						.1942	.2054
9					.2353		
10				.2241		.2614	.1867
11				.2241			
12	.2241		.1643	.2241	.1942	.1606	
13							.1675
14		.2054				.1755	
15			.1995	.2241	.1979		.1748
16						.1904	
17		.1867					.1827
18					.2241	.2166	
21					.2203	.2427	
23					.2054	.1755	
24				.1307	.196	.1979	.1419
Max	.2241	.2054	.1995	.2241	.2353	.2614	.2054
Min	.2241	.1867	.1643	.1307	.1942	.1606	.1344
Avg	.2241	.1961	.1819	.2054	.2093	.1965	.1702

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 113039 / RUNWAL ANTHURIAM

Feeder No / Name : 203 / R SQUARE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3					.0934	.0205	.0224
6					.0579	.0187	.0261
8						.0243	.0261
9					.0411		
10				.0373		.0373	.0523
11				.0747			
12	.0747		.0476	.0747	.0635	.0448	
13							.0597
14		.0747				.056	
15			.0527	.0747	.0597		.0657
16						.0504	
17		.056					.0766
18					.0523	.0597	
21					.0355	.0504	
22						.0373	
23					.0299	.0205	
24				.0373	.0934	.0261	.0205
Max	.0747	.0747	.0527	.0747	.0934	.0597	.0766
Min	.0747	.056	.0476	.0373	.0299	.0187	.0205
Avg	.0747	.0654	.0502	.0597	.0585	.0372	.0437

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 283071 / PANCHPAKHADI REC STN

Feeder No / Name : 202 / HUGALI-I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.1991		.181	.181	.181	.181
2	.1629	.1991	.1629	.181	.1629	.1448	.181
3	.1448	.181	.1448	.1448	.1448	.1267	.181
4	.1448	.1267	.1448	.1267	.1629	.1448	.181
5	.1629	.1629	.1629	.1629	.1991	.1448	.2172
6	.2172	.181	.181	.181	.2353	.1991	.2534
7	.2534	.3077	.2172	.1991	.2534	.2534	.3258
8	.2896	.2896	.2534	.2534	.2715	.2534	.3258
9	.3077	.3258	.3077	.2172	.3077	.362	.2896
10	.3982	.3439	.3258	.362	.3439	.362	.3982
11	.3982	.4525	.362	.3439	.3801	.3801	.3982
12	.3982	.3439	.3801	.3258	.3801	.3258	.3982
13	.3258	.3439	.362	.3077	.3258	.362	.362
14	.3439	.362	.2715	.3077	.3077	.2353	.362
15	.5068	.4163	.2896	.2715	.2715	.2353	.3801
16	.2896	.3439	.2534	.2353	.2896	.2715	.3801
17	.3439	.362	.2896	.2172	.3077	.2534	.2896
18	.3439	.362	.2896	.2534	.2896	.3258	.3258
19	.3258	.3439	.3258	.2534	.3439	.3439	.3258
20	.3258	.3258	.2715	.2715	.3258	.3077	.3258
21	.2715	.2896	.2715	.2534	.3077	.3077	.3258
22	.3258	.2715	.2172	.2353	.2534	.2896	
23	.2353	.2353	.2172	.2172	.2172	.3077	
24	.2172	.2172	.1991	.1991	.2172	.181	.1991
Max	.5068	.4525	.3801	.362	.3801	.3801	.3982
Min	.1448	.1267	.1448	.1267	.1448	.1267	.181
Avg	.2881	.2911	.2565	.2376	.2700	.2625	.3003

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 283071 / PANCHPAKHADI REC STN

Feeder No / Name : 203 / HUGALI-II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.2641	.3018	.3018	.2641	.2829	.3018
2	.2829	.2641	.2829	.2829	.2452	.2452	.3018
3	.2641	.2263	.2452	.2452	.2263	.2075	.2829
4	.2263	.2452	.2263	.2075	.2075	.2641	.2641
5	.2641	.2641	.2641	.2263	.2263	.3018	.2829
6	.3206	.3018	.2829	.2263	.2829	.2829	.3018
7	.3395	.3395	.3206	.2641	.3395	.3395	.3206
8	.3206	.3395	.3018	.2641	.3395	.2829	.3206
9	.6413	.5658	.547	.415	.6036	.5658	.547
10	.7356	.679	.679	.4527	.6979	.7167	.679
11	.7733	.7733	.679	.4527	.7167	.6602	.7922
12	.7545	.6979	.6036	.4527	.7545	.7545	.6036
13	.6036	.2829	.5847	.3772	.6036	.6036	.6036
14	.7167	.3395	.679	.415	.679	.6602	.7545
15	.6979	.7922	.6602	.3961	.7167	.6979	.7356
16	.679	.679	.679	.3772	.7167	.6602	.679
17	.679	.6413	.6036	.3395	.679	.6036	.679
18	.679	.6224	.6036	.3018	.6413	.5093	.6413
19	.5658	.6036	.5281	.3018	.6036	.3961	.6036
20	.4527	.5093	.4904	.2829	.5658	.3584	.6036
21	.3395	.3772	.3395	.3018	.3395	.3395	.3395
22	.3206	.3206	.3018	.3018	.3206	.3206	.3395
23	.3206	.3206	.3018	.2829	.3018	.3206	.3018
24	.3206	.3018	.3206	.3018	.2829	.3018	.3018
Max	.7733	.7922	.679	.4527	.7545	.7545	.7922
Min	.2263	.2263	.2263	.2075	.2075	.2075	.2641
Avg	.4833	.4480	.4511	.3238	.4731	.4448	.4825

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 283071 / PANCHPAKHADI REC STN

Feeder No / Name : 204 / DENTAL PRODUCT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.116	.1326	.116	.0995	.116	.0995	.116
2	.0995	.116	.116	.0829	.0995	.0829	.116
3	.116	.0995	.0995	.0829	.0829	.0663	.116
4	.1492	.0829	.0995	.0663	.116	.0829	.116
5	.1823	.0995	.116	.0995	.1326	.0995	.1492
6	.2155	.0995	.1326	.0995	.1658	.1326	.1823
7	.2321	.2321	.1326	.1326	.1989	.1658	.2321
8	.1492	.1823		.116	.1658	.1658	.1658
9	.2155	.1989	.1989	.1658	.1658	.168	.2155
10	.1989	.1658	.2155	.2155	.1823	.2155	.1823
11	.2321	.1989	.2321	.1989	.1989	.1989	.1658
12	.1492	.1492	.1492	.1823	.1492	.1658	.1658
13	.116	.116	.1326	.1823	.116	.1658	.116
14	.1326	.1492	.1492	.1326	.0995	.1326	.116
15	.116	.1326	.0995	.1492	.116	.116	.1326
16	.1326	.1326	.1326	.1492	.0995	.116	.1326
17	.116	.1326	.1492	.1492	.1326	.1492	.116
18	.0995	.1326	.1326	.1326	.1326	.1326	.116
19	.116	.1492	.1492	.1326	.1326	.1326	.1492
20	.1326	.1492	.1492	.1326	.1326	.1658	.1492
21	.1492	.1492	.1326	.1326	.1326	.1326	.1658
22	.1492	.1658	.1658	.1326	.1492	.1492	
23	.1326	.1658		.1326	.116	.1492	
24	.1326	.1326	.1326	.1326	.1326	.0995	.116
Max	.2321	.2321	.2321	.2155	.1989	.2155	.2321
Min	.0995	.0829	.0995	.0663	.0829	.0663	.116
Avg	.1492	.1444	.1424	.1347	.1361	.1369	.1469

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 283071 / PANCHPAKHADI REC STN

Feeder No / Name : 205 / DEEVECHA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2149	.2328	.2149	.197	.2149	.2149	.2328
2	.197	.197	.2149	.181	.1791	.1791	.2149
3	.1791	.1791	.197	.1791	.1612	.1433	.197
4	.2149	.2149	.197	.1433	.1791	.1791	.197
5	.2507	.2507	.2149	.197	.197	.197	
6	.2865	.2507	.2149	.2507	.2328	.2149	.2328
7	.3403	.3045	.2328	.2686	.2686	.2507	.2507
8	.3761	.3582	.3224	.2507	.3045	.3403	.3224
9	.3403	.3582	.3403	.3045	.3224	.394	.394
10	.3403	.4119	.394	.3224	.3403	.3761	.3761
11	.394	.3403	.3403	.3224	.3582	.4119	.3045
12	.3224	.3045	.3403	.3224	.3224	.3403	.3224
13	.2686	.3224	.3224	.2686	.3045	.3224	.3045
14	.2865	.3224	.3582	.2507	.2865	.2865	.2686
15	.3224	.2865	.3045	.2507	.3224	.2686	.2865
16	.2686	.2865	.2507	.2328	.2507	.2865	.3224
17	.2865	.2865	.2865	.2328	.2865	.2686	.2865
18	.2865	.3045	.2686	.2686	.3224	.2686	.3045
19	.2865	.3045	.2686	.2865	.3045	.2865	.3403
20	.2865	.3045	.2686	.3045	.2865	.2865	.2865
21	.3224	.3045	.2686	.2865	.2686	.3045	.3224
22	.3045	.3045	.2865	.2865	.3224	.2865	
23	.2686	.2865	.2865	.2686	.2686	.2865	
24	.2507	.2507	.2328	.2328	.2507	.2149	.2328
Max	.394	.4119	.394	.3224	.3582	.4119	.394
Min	.1791	.1791	.197	.1433	.1612	.1433	.197
Avg	.2873	.2903	.2761	.2545	.2731	.2753	.2857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 283071 / PANCHPAKHADI REC STN

Feeder No / Name : 206 / S H KELKAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9511	.9694	.9145	.8048	.9511	.823	.7865
2	.8962	.8962	.8779	.7682	.8596	.7499	.7316
3	.823	.8413	.823	.7316	.7865	.695	.695
4	.8779	.7682	.7865	.7682	.8962	.7316	.6401
5	1.0059	.823	.823	.8779	.9694	.7316	.7682
6	1.134	.9145	.8779	.9328	1.0425	.9328	.9694
7	1.2803	1.1706	.9328	1.0242	1.1157	1.134	1.262
8	1.4632	1.4083	1.2803	1.0608	1.3535	1.2986	1.2803
9	1.6095	1.6827	1.3717	1.2254	1.6644	1.5912	1.5364
10	1.6095	1.8107	1.5546	1.3169	1.7558	1.6827	1.5729
11	1.7558	1.7741	1.4083	1.3717	1.6278	1.6644	1.7193
12	1.4632	1.6644	1.3352	1.4449	1.4632	1.5912	1.5546
13	1.4266	1.4815	1.2986	1.3169	1.3352	1.4083	1.2803
14	1.4266	1.4815	1.1706	1.0791	1.2986	1.262	
15	1.2437	1.39	1.1888	1.0608	1.1706	1.3352	1.3535
16	1.2437	1.3535	1.0608	1.0425	1.262	1.2071	1.3169
17	1.3352	1.2437	1.134	1.0242	1.0974	1.2803	1.1706
18	1.2986	1.39	.9877	1.0059	1.2437	1.2803	1.3717
19	1.2986	1.4632	1.2986	1.2071	1.3352	1.3352	1.4998
20	1.4632	1.5364	1.3535	1.262	1.2986	1.4266	1.4815
21	1.3352	1.4632	1.3169	1.3352	1.2437	1.2071	1.3717
22	1.2437	1.262	1.1888	1.1706	1.0608	1.2437	1.1523
23	1.1523	1.0974	1.0059	1.0608	.9511	1.0242	1.0974
24	1.0059	1.0242	1.0059	.9145	1.0059	.8596	.9145
Max	1.7558	1.8107	1.5546	1.4449	1.7558	1.6827	1.7193
Min	.823	.7682	.7865	.7316	.7865	.695	.6401
Avg	1.2643	1.2879	1.1248	1.0753	1.1995	1.1873	1.1968

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 283071 / PANCHPAKHADI REC STN

Feeder No / Name : 207 / TRIDEV

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8954	.8954	.7701	.788	.8417	.7522	.7343
2	.8238	.8775	.7164	.7522	.7522	.7164	.6984
3	.7522	.8238	.6805	.6805	.7164	.6447	.6268
4	.8775	.7701	.6268	.6268	.7701	.591	.5731
5	.9134	.6984	.6626	.6626	.8238	.6268	.6268
6	.9492	.7343	.7164	.7164	.8954	.7164	.7522
7	1.0029	1.0029	.8059	.8059	.9313	.8417	.9671
8	.9671	1.0566	.985	.9313	1.0387	1.0566	1.1641
9	1.182	1.1999	1.182	1.0924	1.1104	1.1104	1.1641
10	1.182	1.2715	1.2715	1.2178	1.182	1.0745	1.1999
11	1.1462	1.1462	1.1104	1.0924	1.0566	1.1641	1.1641
12	1.0745	1.0745	1.1283	.985	.9313	1.0566	1.0745
13	1.0566	.985	1.0208	.8417	.9492	.9134	.985
14	1.0029	.8417	.9134	.8954	.8775	.8238	1.0029
15	.9313	.9671	.8238	.8417	.8238	.788	.9313
16	.9671	.9134	.8596	.788	.788	.7701	.8596
17	.8775	.8238	.788	.7343	.8596	.8417	.9134
18	.9134	.8954	.9134	.8775	.8954	.8775	.9671
19	1.1104	1.0387	1.1104	1.0924	1.1462	1.0924	1.1641
20	1.1104	1.1104	1.1104	1.0387	1.0745	1.0566	1.1462
21	1.1641	1.0566	1.1641	1.0208	1.0387	1.0924	1.182
22	1.0745	1.0208	1.0029	.985	1.0387	1.0924	1.1283
23	1.0387	.9313	.9492	.9492	.9492	.985	1.0745
24	.9492	.9313	.8954	.8417	.8954	.8059	.8059
Max	1.182	1.2715	1.2715	1.2178	1.182	1.1641	1.1999
Min	.7522	.6984	.6268	.6268	.7164	.591	.5731
Avg	.9984	.9611	.9253	.8857	.9328	.8954	.9544

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 283071 / PANCHPAKHADI REC STN

Feeder No / Name : 208 / TATA FISION

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5258	.4557	.4557	.4557	.4382	.4382	.4733
2	.4733	.4382	.4382	.4207	.3856	.4031	.4557
3	.4207	.4031	.4031	.3681	.333	.3681	.4382
4	.4557	.4382	.3856	.333	.3155	.4031	.4207
5	.5083	.4733	.4207	.3506	.3506	.4207	.5258
6	.5784	.4908	.4908	.4031	.4207	.4908	.5609
7	.631	.631	.5784	.4908	.5784	.5609	.6661
8	.6135	.7362	.6135	.5609	.6135	.6661	.6485
9	.6485	.6661	.6485	.5258	.6485	.7011	.7011
10	.7362	.7011	.7186	.7362	.6836	.6661	.631
11	.7362	.6836	.5959	.7186	.6135	.5609	.631
12	.6661	.7011	.631	.7011	.5609	.6836	.631
13	.5784	.5609	.5609	.5959	.4908	.5434	.631
14		.5258	.5258	.4908	.4557	.5434	.5258
15	.5083	.5959	.4733	.4733	.4557	.4382	.5258
16	.4908	.4908	.4557	.4557	.4557	.4557	.5258
17	.5609	.5083	.5258	.4557	.5609	.4557	.631
18	.5959	.5784	.5959	.5434	1.134	.5609	.5609
19	.631	.7362	.6836	.5609	.6661	.6661	.7011
20	.6661	.6836	.5959	.6135	.6661	.7011	.7011
21	.631	.631	.5959	.6135	.631	.7011	.7011
22	.631	.631	.5258	.5784	.5609	.5959	.6661
23	.5258	.6135	.4733	.5258	.4908	.5784	.631
24	.5609	.4908	.5083	.4908	.4733	.4557	.5434
Max	.7362	.7362	.7186	.7362	1.134	.7011	.7011
Min	.4207	.4031	.3856	.333	.3155	.3681	.4207
Avg	.5815	.5777	.5375	.5193	.5410	.5441	.5886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 283071 / PANCHPAKHADI REC STN

Feeder No / Name : 209 / YOGI HILL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.134	1.0425	1.0059	.8779	.823	.9328	.8596
2	1.0791	1.0059	.9145	.823	.7316	.8596	.7865
3	1.0059	.9328	.823	.7682	.6767	.8048	.7316
4	1.0791	.8779	.8596	.7133	.823	.7499	.695
5	1.1157	.9328	.9145	.7499	.9511	.8048	.8048
6	1.1523	1.0974	.9511	.8048	1.0059	.8779	.9145
7	1.2071	1.3169	1.0425	.9145	1.134	1.0608	1.1523
8	1.1888	1.2437	1.0974	1.0608	1.134	1.134	1.2803
9	1.4083	1.4998	1.4083	1.2071	1.3717	1.4266	1.4632
10	1.4815	1.6827	1.6095	1.4632	1.6461	1.6827	1.5912
11	1.5912	1.4998	1.4266	1.39	1.39	1.5729	1.4266
12	1.4266	1.3535	1.39	1.3535	1.2803	1.6095	1.4266
13	1.2986	1.2986	1.2437	1.3352	1.1888	1.3352	1.1706
14	1.1706	1.2071	1.2071	1.0974	1.1706	1.2071	1.2803
15	1.2254	1.2071	1.1888	1.0242	1.0974	1.0608	1.134
16	1.1523	1.2986	1.2803	.9328	1.134	1.0791	1.0608
17	1.134	1.1523	1.2437	.8779	1.0608	1.0974	1.134
18	1.4266	1.2803	1.3169	1.0059	1.134	1.1157	1.0974
19	1.39	1.3169	1.3535	1.2254	1.3535	1.2254	
20	1.2803	1.2437	1.2803	1.0974	1.3169	1.134	1.2071
21	1.3169	1.1706	1.1706	1.0242	1.2803	1.1523	1.2437
22	1.2437	1.262	1.134	1.0059	1.134	1.1706	1.2437
23	1.134	1.0608	1.0242	.9877	1.0974	1.0425	1.134
24	1.1706	1.134	1.0425	.9877	.8962	.9877	1.0059
Max	1.5912	1.6827	1.6095	1.4632	1.6461	1.6827	1.5912
Min	1.0059	.8779	.823	.7133	.6767	.7499	.695
Avg	1.2422	1.2132	1.1637	1.0303	1.1180	1.1302	1.1236

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 283071 / PANCHPAKHADI REC STN

Feeder No / Name : 210 / SAPTERSHI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5609	.5083	.5258	.4207	.4382	.4557	.4031
2	.5258	.4557	.4908	.3856	.3856	.4031	.4031
3	.4733	.4031	.4382	.3506	.333	.3506	.3856
4	.5083	.3506	.3856	.298	.3681	.3681	.3856
5	.5609	.4031	.4031	.333	.4031	.3681	.4908
6	.6135	.4733	.4207	.4031	.4908	.4207	.5609
7	.6661	.6135	.4382	.4557	.6135	.5258	.631
8	.6485	.8238	.5959	.4908	.631	.6135	.7011
9	1.0867	1.0517	.7186	.631	1.0867	.7712	1.0166
10	.9991	1.1393	.8939	.8063	.9816	.8238	1.0517
11	1.1043	1.0867	.8939	.7888	.9114	.8589	1.1043
12	.929	.9816	.8063	.8063	1.0517	.6661	1.0517
13	.9114	.8939	.6661	.7011	.8238	.7011	.964
14	.7888	.8238	.5609	.6485	.6836	.631	.8413
15	.7537	.8238	.6135	.6135	.6661	.6135	.7362
16	.5609	.8238	.4908	.5609	.631	.5434	.5434
17	.631	.6836	.5258	.5258	.5434	.5258	.5258
18	.5258	.5609	.5959	.5784	.5258	.5784	.5959
19	.631	.6661	.5784	.6485	.6135	.7011	.7362
20	.6485	.7186	.631	.631	.6485	.7186	.7011
21	.7186	.7186	.6661	.6135	.6661	.7362	.8063
22	.631	.6661	.631	.5609	.631	.7537	
23	.5959	.631	.5784	.5434	.5609	.6135	
24	.5959	.5434	.5434	.5258	.4908	.4908	.5609
Max	1.1043	1.1393	.8939	.8063	1.0867	.8589	1.1043
Min	.4733	.3506	.3856	.298	.333	.3506	.3856
Avg	.6945	.7018	.5872	.5551	.6325	.5930	.6908

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113013 / 22/11 KV SARVODAYA

Feeder No / Name : 202 / MAASHPURAM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5203	1.4661		1.3937	1.3756	1.3394	1.3032
2	1.448	1.3756		1.2851	1.3032	1.3394	1.2127
3	1.4118	1.3213		1.2489	1.3575	1.3032	1.1403
4	1.3394	1.2851		1.1946	1.4299	1.267	1.2308
5	1.2489	1.3213	1.1765	1.1946	1.5203	1.1584	1.3032
6	1.7013	1.5927	1.3937	1.267	1.6108	1.2945	1.448
7		1.7737	1.5023	1.4661	1.7737	1.4842	1.6809
8	1.9749	1.9547	1.7194	1.7013	1.9547	1.647	1.9387
9	2.1719	2.0633	1.9185	1.8642	2.1176	1.9387	2.1176
10		2.2624	2.0814	1.9909	2.0995	2.1357	2.19
11		2.2986	2.0633	2.009	2.0814	1.9366	2.0814
12	1.9909	2.0633	1.8823	2.0452	2.0633	1.9004	2.009
13	2.0271	1.9185	1.7194	1.7918	1.9366	1.7194	1.9004
14	1.7918		1.6108	1.5565	1.7375	1.448	1.7556
15	1.701	1.5746	1.5746	1.5203	1.647	1.4299	
16		1.5746	1.4661	1.5565	1.6289	1.4118	
17	1.7013		1.6289	1.5384	1.5927	1.5565	
18	1.7194		1.7556	1.5746	1.6832	1.6108	1.8099
19	1.9728		1.9728	1.8118	1.9366	1.9366	
20	1.9547		1.9728	1.8823	1.9547	1.9547	
21	1.8823		1.8642	1.7556	1.9004	1.8461	1.9004
22	1.9185		1.7918	1.7194	1.7556	1.7918	
23	1.8823		1.6651	1.7175	1.6108	1.6289	
24	1.7375	1.6289	1.5565	1.5565	1.5746	1.5023	1.5023
Max	2.1719	2.2986	2.0814	2.0452	2.1176	2.1357	2.19
Min	1.2489	1.2851	1.1765	1.1946	1.3032	1.1584	1.1403
Avg	1.7548	1.7172	1.7158	1.6101	1.7353	1.6076	1.6779

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113013 / 22/11 KV SARVODAYA

Feeder No / Name : 203 / UDYOGKSHETRA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2715	.2715		.2353	.2715	.2715	.2715
2	.2715	.2534		.2353	.2715	.2715	.2715
3	.2715	.2353		.2172	.2715	.2715	.2534
4	.2534	.2353		.2172	.2534	.2534	.2534
5	.2534	.2534	.2534	.2172	.2534	.2534	.2534
6	.2534	.2896	.2534	.2353	.2534	.2534	.2896
7	.2896	.2896	.2534	.2353	.2718	.2353	.3077
8	.3077	.2896	.2534	.2534	.3077	.3077	.2715
9	.4344	.4163	.3077	.1991	.4163	.3439	.4525
10		.6154	.4163	.2896	.6335	.4706	.6154
11		.5973	.4344	.2715	.6154	.4525	.5973
12	.6516	.6154	.3982	.2896	.5973	.3982	.6516
13	.6154	.6219	.3801	.2715	.5249	.3801	.5973
14	.5973		.3439	.2896	.4887	.4163	.5611
15	.6697	.5792	.4706	.2172	.5792	.4525	.7059
16		.6154	.3982	.2353	.5973	.4344	
17	.5973		.3801	.2353	.6516	.4706	
18	.5611		.362	.2534	.5792	.4163	.6154
19	.4706		.362	.2896	.4525	.4163	
20	.4163		.3982	.2899	.4163	.362	
21	.4344		.3077	.2896	.3439	.3077	.4207
22	.3801		.3258	.3077	.3077	.3439	
23	.3258		.3077	.3077	.308	.3077	
24	.2896	.2896	.2896	.2896	.2896	.2896	.2896
Max	.6697	.6219	.4706	.3077	.6516	.4706	.7059
Min	.2534	.2353	.2534	.1991	.2534	.2353	.2534
Avg	.4103	.4043	.3448	.2572	.4148	.3492	.4266

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113013 / 22/11 KV SARVODAYA

Feeder No / Name : 204 / SAIDHAM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	.8048		.7865	.7682	.7499	.7682
2	.823	.7865		.7499	.7316	.7316	.7316
3	.8048	.7682		.7316	.7682	.695	.695
4	.8048	.7499		.7133	.8048	.695	.7682
5	.7682	.7865	.7392	.7316	.8779	.6584	.8779
6	.9145	.9328	.7973	.7682	.9511	.7682	.9511
7	1.0425	1.0608	.961	.8048	.9694	.823	1.0242
8	1.0974	1.0425	1.0719	.9877	1.0608	1.0242	1.0608
9	1.2254	1.134	1.1088	1.1157	1.1706	1.1888	1.134
10		1.1706	1.1523	1.0791	1.1523	1.1706	1.0974
11		1.1523	1.134	1.0974	1.0608	1.0974	1.134
12	1.0903	1.134	.8596	.9511	1.0425	1.0242	1.0242
13	1.0242	.9145	.7499	.8779	.9511	.9694	1.0059
14	.9877		.6219	.9145	.8779	.8413	.9328
15	.9511	.8962	.567	.8048	.8413	.7865	
16		.823	.5853	.7865	.823	.7682	
17	.9511		.695	.823	.9511	.9145	
18	.9328		1.0608	.8779	.9145	.9511	1.0242
19	1.1523		1.1706	1.0974	1.1157	1.1157	
20	1.1523		1.1888	1.0425	1.0791	1.1157	
21	1.1706		1.1523	1.0608	1.134	1.0974	1.1523
22	1.0608		1.0608	.9694	.9877	1.0608	
23	1.0425		.9328	.9511	.9328	.9694	
24	.9694	.9328	.8871	.8779	.8413	.823	.8596
Max	1.2254	1.1706	1.1888	1.1157	1.1706	1.1888	1.1523
Min	.7682	.7499	.567	.7133	.7316	.6584	.695
Avg	.9899	.9431	.9248	.9000	.9503	.9183	.9554

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703]

BU 4703

Substation No/ Name :- 113013 / 22/11 KV SARVODAYA

Feeder No / Name : 205 / SARVODAYA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5784	.5784		.4733	.4031	.4207	.4557
2	.5784	.4557		.4382	.3856	.4207	.4207
3	.5258	.4557		.4207	.4207	.3856	.3856
4	.5258	.4382		.3856	.4908	.3506	.4207
5	.4557	.4908	.3721	.4031	.5258	.333	.4908
6	.5258	.5609	.4938	.5083	.5434	.4557	.5434
7	.7362	.631	.567	.5434	.631	.5434	.5609
8	.631	.6135	.5493	.5258	.5784	.5258	.5609
9	.6836	.6485	.6767	.5959	.5959	.5959	.6485
10		.6836	.7362	.6836	.8238	.7011	.6836
11		.6661	.7011	.8238	.6661	.6836	.7186
12	.6556	.631	.6135	.6135	.6135	.5609	.5959
13	.6219	.5609	.5434	.5959	.5083	.5258	.4908
14	.5316		.4908	.5784	.4733	.5784	.5434
15	.5316	.5083	.5258	.5434	.5434	.4382	
16		.5258	.5609	.4207	.4382	.4908	
17	.4938		.4733	.5258	.4733	.4557	
18	.5434		.4908	.4733	.4557	.5434	.543
19	.631		.5959	.5609	.5258	.6485	
20	.631		.6135	.5609	.5609	.5959	
21	.6485		.6135	.5784	.5784	.5959	.6556
22	.6661		.6135	.5784	.5609	.5959	
23	.6485		.5609	.5784	.5609	.5959	
24	.6485	.5959		.5258	.5434	.4908	.5609
Max	.7362	.6836	.7362	.8238	.8238	.7011	.7186
Min	.4557	.4382	.3721	.3856	.3856	.333	.3856
Avg	.5949	.5653	.568	.5390	.5375	.5222	.5458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113013 / 22/11 KV SARVODAYA

Feeder No / Name : 206 / SHREERAM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.811	.811		.7733	.679	.7733	.679
2	.811	.7356		.7545	.5847	.7545	.6979
3	.7545	.7167		.7545	.6036	.7356	.6602
4	.7545	.6979		.7356	.6413	.7167	.7167
5	.7356	.7356	.7316	.6979	.679	.7167	.7545
6	.8488	.7733	.8413	.7356	.679	.7922	.7545
7	.9997	.9997	.9328	.7545	.8299	.8865	.9619
8	1.094	1.094	1.0608	.9242	1.0185	1.0562	1.0185
9	1.358	1.4335	1.3535	.9997	1.2449	1.3392	1.3014
10		1.8484	1.8107	1.1128	1.7541	1.6032	1.7164
11		2.0559		1.2449	1.6975	1.6221	1.8484
12	1.7741	1.9239	1.5844	1.1506	1.773	1.6598	1.8673
13	1.5181	1.6787	1.5655	.9808	1.4901	1.4523	1.6032
14	1.6975		1.6221	1.0751	1.6598	1.3957	1.6598
15	1.7164	1.7918	1.5466	.9431	1.6409	1.5466	
16		1.8107	1.5655	.9054	1.5655	1.6598	
17	1.6598		1.4901	.9242	1.5089	1.5278	
18	1.5844		1.6409	.8299	1.4901	1.3203	1.6032
19	1.4335		1.5089	.9997	1.4146	1.3769	
20	1.3769		1.3769		1.3014	1.2071	
21	1.2449		1.3203	.9431	1.2826	1.1506	1.2071
22	1.1506		1.0562	.8488	1.094	1.0374	
23	.9808		.9808	.7922	.9808	.8676	
24	.8865	.8488	.8048	.8865	.6979	.8299	.8676
Max	1.7741	2.0559	1.8107	1.2449	1.773	1.6598	1.8673
Min	.7356	.6979	.7316	.6979	.5847	.7167	.6602
Avg	1.1996	1.2472	1.3049	.9029	1.1796	1.1678	1.1716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113013 / 22/11 KV SARVODAYA

Feeder No / Name : 207 / RAJA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3206	.2858		.2858	.1509	.3018	.2829
2	.3206	.2667		.2641	.1132	.3018	.2641
3	.3018	.2667		.2667	.0754	.2829	.2641
4	.3018	.2667		.2477	.0754	.2829	.2641
5	.2641	.2667	.2263	.2452	.0754	.2641	.2263
6	.2641	.2614	.2452	.2054	.1132	.2641	.1886
7	.2829	.2829	.2378	.1829	.1132	.2641	.1886
8	.3206	.3206	.2561	.2033	.1886	.2641	.2263
9	.4904	.5281	.5281	.1886	.3961	.3961	.4527
10		.7356	.7167	.2075	.7167	.5847	.7545
11		.9619	.811	.2075	.811	.6979	.811
12	1.0374	.8676	.7922	.2263	.8299	.7167	.8676
13		.7922	.679	.2075	.7545	.6602	.7733
14			.7545	.2263	.811	.6413	.8676
15		.9431	.7167	.2075	.8299	.7167	
16		.9054	.6979	.1886		.6979	
17	.9242		.6535	.1886	.7922	.7167	
18	.7655		.5788	.1886	.7167	.5658	.6979
19	.6224		.5144	.1886	.6413	.4904	
20	.4715		.4527	.1132	.4338	.3961	
21	.4001		.381	.1509	.3395	.2829	.3395
22	.3584		.3584	.1132	.3395	.2829	
23	.3239		.3048	.1132	.3018	.2641	
24	.3206	.2829	.2641	.3048	1.094	.2829	.2641
Max	1.0374	.9619	.811	.3048	1.094	.7167	.8676
Min	.2641	.2614	.2263	.1132	.0754	.2641	.1886
Avg	.4495	.5146	.5085	.2051	.4658	.4425	.4549

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113013 / 22/11 KV SARVODAYA

Feeder No / Name : 208 / KARIA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0751	1.0185		.9808	.9431	.9431	.9619
2	1.0751	.9808		.9054	.8676	.9242	.9054
3	1.0185	.9619		.8488		.9242	.8488
4	1.0185	.9431		.8488	.9808	.9431	.9054
5	.9808	.9619	.905	.8865	1.0562	.9431	1.0185
6	1.094	1.1317	1.0136	.9054	1.1506	1.0185	1.1128
7	1.3014	1.358	1.0679	.9997	1.226	1.1317	1.3203
8	1.2826	1.2449	1.1403	1.1506	1.2071	1.3014	1.226
9	1.4335	1.3769	1.5927	1.2637	1.3957	1.4335	1.3203
10			1.4712	1.3014	1.3392	1.4146	1.3769
11		1.3392	1.3203	1.3769	1.3014	1.358	1.3957
12	1.3169	1.1883	1.358	1.3957	1.226	1.2449	1.2826
13		1.094	1.1883	1.2449	1.1128	1.094	1.094
14			1.0751	1.1128		1.0751	.9997
15		1.0185	1.0562	1.0374	.9619	.9431	
16		.9619	.9808	.9997	.9431	.9619	
17	.9619		.9997	.9808	.9054	.9431	
18	1.0562		1.0751	1.0185	.9808	.9997	1.0751
19	1.2071		1.3203	1.2826	1.226	1.2637	
20	1.2449		1.3014	1.2071	1.2071	1.3203	
21	1.2826		1.2826	1.2637	1.2637	1.3203	1.358
22	1.2637		1.2449	1.1883	1.2071	1.226	
23	1.2449		1.1694	1.1883	1.1694	1.1506	
24	1.1883	1.1128	1.094	1.0374	.1132	1.094	1.1128
Max	1.4335	1.3769	1.5927	1.3957	1.3957	1.4335	1.3957
Min	.9619	.9431	.905	.8488	.1132	.9242	.8488
Avg	1.1692	1.1128	1.1828	1.1011	1.0811	1.1238	1.1361

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113013 / 22/11 KV SARVODAYA

Feeder No / Name : 209 / nahurgaon SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3394	1.3575		1.2127	1.1946	1.1222	1.1584
2	1.3394	1.2308		1.1403	1.1293	1.0928	1.086
3	1.3032	1.1584		1.086	1.1222	1.0136	1.0317
4	1.267	1.1222		1.0679	1.1946	.9774	1.086
5	1.2308	1.2127	1.1157	1.1403	1.267	.9955	1.1765
6	1.3575	1.4299	1.2752	1.267	1.3213	1.1041	1.3032
7	1.5384	1.5746	1.39	1.1946	1.3937	1.2308	1.4966
8	1.5565	1.5023	1.39	1.3756	1.3756	1.4661	1.5384
9	1.5927		1.5729	1.3575	1.5203	1.5746	1.4842
10		1.6651	1.7194	1.6108	1.5384	1.7556	1.6832
11		1.5927	1.6289	1.6832	1.5023	1.6289	1.448
12	1.6095	1.6108	1.5927	1.5927	1.4118	1.448	1.3213
13	1.39	1.4299	1.4842	1.5203	1.267	1.3937	1.2851
14	1.3717		1.2851	1.3575	1.1222	1.3394	1.2489
15	1.4266	1.3032	1.3575	1.3756	1.2489	1.2127	
16		1.2851	1.3756	1.3032	1.2308	1.2308	
17	1.3394		1.3394	1.3394		1.3032	
18	1.3032		1.3575	1.3032	1.267	1.3394	1.448
19	1.5565		1.5927	1.5565	1.4842	1.5927	
20	1.5746		1.5746	1.5203	1.6651	1.5384	
21	1.647		1.6108		1.5927	1.5927	1.7375
22	1.7194		1.5746	1.5927	1.5332	1.5565	
23	1.6289		1.4299	1.4784	1.448	1.4118	
24	1.6289	1.448	1.4266	1.3575	1.3032	1.2851	1.3394
Max	1.7194	1.6651	1.7194	1.6832	1.6651	1.7556	1.7375
Min	1.2308	1.1222	1.1157	1.0679	1.1222	.9774	1.0317
Avg	1.4629	1.3949	1.4547	1.3667	1.3536	1.3419	1.3454

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113018 / 22/11 KV BEST

Feeder No / Name : 201 / MARATHON

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4755	.4715	.439	.415	.415	.4024	.415
2	.4572	.4527	.4024	.3961	.3961	.3658	.3772
3	.439	.4527	.3841	.3772	.3772	.3658	.3772
4	.439	.4715	.3841	.3772	.3772	.3475	.3772
5	.4024	.547	.4024	.3772	.415	.3658	.415
6	.4572	.5847	.439	.3961	.4338	.4024	.4527
7	.567	.5847	.4755	.4527	.5658	.4755	.547
8	.5853	.6413	.5121	.5281	.5658	.6219	.6036
9	.6584	.7356	.6767	.6413	.6224	.6767	.6224
10	.7316	.7316	.6979	.567	.695	.6219	.7133
11	.7316	.7316	.7545	.6767	.695	.7133	.7133
12	.6767	.6584	.6413	.6401	.6767	.5853	.7316
13	.5853	.6036	.6036	.567	.567	.5853	.5853
14	.5853	.5853	.6036	.5121	.5853	.5121	.5853
15	.6036	.5853	.6036	.439	.5121	.4938	.5304
16	.6036	.567	.6036	.4207	.5304	.5121	.5853
17	.5487	.567	.6036	.439	.5487	.4938	.567
18		.5121	.6036	.4715	.5121	.5121	.5853
19	.6224	.6401	.6224	.5281	.5853	.6036	.6036
20		.5853	.6602	.5281	.5853	.5658	.5853
21	.6036	.6219	.6602	.4904	.5487	.5658	.6036
22		.6036	.6036	.5281	.5121	.5281	.6401
23		.5853	.5281	.4904	.4755	.5281	.5853
24	.5121	.5093	.4938	.4715	.4715	.439	.4715
Max	.7316	.7356	.7545	.6767	.695	.7133	.7316
Min	.4024	.4527	.3841	.3772	.3772	.3475	.3772
Avg	.5643	.5845	.5583	.4888	.5279	.5118	.5531

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113018 / 22/11 KV BEST

Feeder No / Name : 202 / RITA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5973		.5792	.6036	.5281	.543	.5658
2	.5249	.5281	.5249	.5281	.4904	.4706	.4904
3	.4887	.5093	.4706	.4527	.4527	.4525	.4527
4	.4706	.4715	.4525	.415	.4527	.4344	.4527
5	.4887	.547	.4706	.415	.4904	.4344	.5281
6	.5611	.6413	.5068	.4527	.5281	.4887	.5658
7	.6154	.6413	.5068	.4904	.6036	.4887	.6224
8	.7059	.6413	.6516	.5658	.679	.5249	.679
9	.7602	.679	.6878	.6224	.7545	.6516	.8299
10	.8688	.8507	.7356	.6878	.7964	.7964	.7602
11	.8507	.8869	.9054	.724	.7964	.7964	.7964
12	.8688	.905	.9431	.5792	.8688	.7421	.8688
13	.9774	.8326	.8299	.7602	.8326	.6697	.8326
14	.7059	.724	.679	.5611	.724	.6516	.7783
15	.724	.7602	.679	.5792	.7602	.6697	.7964
16	.724	.7421	.679	.5249	.7421	.6516	.8145
17	.6697	.724	.6979	.5792	.724	.6697	.7964
18	.8097	.7602	.7167	.6413	.7421	.7167	.7783
19	.8865	.8326	.8676	.7545	.8326	.8299	.8869
20		.7964	.8299	.7733	.7964	.8299	.9412
21	.7545	.7964	.8299	.7167	.7964	.7733	.905
22		.6878	.679	.6602	.6697	.6602	.8326
23		.6335	.5658	.6036	.5973	.6224	.724
24	.6697	.6413	.5611	.6602	.6036	.5792	.6036
Max	.9774	.905	.9431	.7733	.8688	.8299	.9412
Min	.4706	.4715	.4525	.415	.4527	.4344	.4527
Avg	.7011	.7058	.6687	.5980	.6776	.6312	.7209

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113018 / 22/11 KV BEST

Feeder No / Name : 203 / BHAWANI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6348	.5658	.6535	.6036	.6036	.4854	.5281
2	.5975	.5847	.5975	.6036	.5658	.4481	.4904
3	.5788	.6413	.5601	.5847	.5281	.4108	.4715
4	.5975	.679	.5601	.5658	.547	.4108	.4527
5	.5601	.7356	.5788	.5658	.6036	.439	.5281
6	.6348	.7545	.6161	.6036	.6602	.5228	.6036
7	.7842	.7922	.6535	.679	.679	.5975	.7133
8	.8215	.6036	.7842	.7167	.7545	.7468	.7167
9	1.0082	.9242	.9335	.7545	.9431	.8589	.9431
10	1.2696	1.2136	1.0751	1.0456	1.1203	1.0082	1.1203
11	1.419	1.5684	1.4335	1.251	1.3443	1.307	1.419
12	1.419	1.6057	1.4712	1.251	1.4003	1.1949	1.475
13	1.3256		1.358	1.1949	1.3443	1.2696	1.5123
14	1.2136	1.4563	1.1694	.9335	1.1576	1.1016	1.3443
15	1.251	1.4003	1.3203	.8962	1.1203	1.0456	1.307
16	1.1763	1.307	1.3203	.9709	1.1763	1.0269	1.3256
17	1.2696	1.4377	1.3957	.9522	1.251	1.1203	1.3443
18		1.419	1.4712	1.1694	1.3256	1.2826	1.531
19	1.358	1.6991		1.2826	1.5684	1.4335	1.7177
20		1.5497	1.3957	1.358	1.4003	1.3957	1.6632
21	1.0562	1.4563	1.2826	1.226	1.2136	1.2071	1.419
22		.9335	.8299	.8299	.8962	.8299	.9709
23		.7468	.7167	.679	.5975	.6036	.7468
24	.7095	.6036	.6722	.6036	.6224	.5228	.5658
Max	1.419	1.6991	1.4712	1.358	1.5684	1.4335	1.7177
Min	.5601	.5658	.5601	.5658	.5281	.4108	.4527
Avg	.9842	1.0730	.9934	.8884	.9760	.8862	1.0379

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113018 / 22/11 KV BEST

Feeder No / Name : 204 / ASHOK CORPORATION
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2449	1.3203	1.2637	1.1317	.8488	1.1317	1.1317
2	1.0562	1.3392	1.1694	1.094	.7545	1.0562	1.0562
3	.9808	1.2826	1.094	1.0185	.679	.9431	.9431
4	.9431	1.2071	.9808	.9054	.679	.9054	.8299
5	.9054	1.1317	.9808	.9054	.6979	.9054	.8299
6	1.0185	1.1523	.9808	.9054	.7356	.9431	.9431
7	1.094	1.2449	1.0562	.9242	.9431	1.0562	1.0562
8	1.1317	1.2637	1.1317	.9431	1.0562	1.1317	1.1317
9	1.5655	1.5466	1.5466	.9619	1.358	1.3957	1.5089
10	1.7353	1.8107	1.6975	1.094	1.4901	1.5466	1.6221
11	2.037	1.9993	2.0748	1.2826	1.7164	1.773	1.8484
12	1.9616	2.037	1.9616	1.1694	2.037	1.8484	1.9805
13	1.8484	1.773	1.773	1.1694	1.7353	1.6221	1.8673
14	1.905	1.8107	1.6409	1.094	1.5844	1.6975	1.8861
15	2.0182	2.037	1.6598	1.094	1.7353	1.6787	1.9993
16	1.8673	1.8861	1.7353	.9242	1.6221	1.7353	2.037
17	1.7353	2.0748	1.8107	1.1317	1.773	1.6032	2.0559
18		1.7353	1.9239	.9431	1.7164	1.4901	1.9239
19	1.8673	1.8107	1.9427	1.0562	1.7541	1.5089	2.0748
20		1.6975	1.5844	1.1317	1.5844	1.5466	1.7918
21	1.4146	1.6975	1.3957	1.0185	1.6032	1.5089	1.6975
22		1.3203	1.358	1.0185	1.4901	1.358	1.4712
23		1.358	1.3957	.9431	1.2826	1.2449	1.4901
24	1.4335	1.4146	1.2826	1.226	.8676	1.2071	1.1694
Max	2.037	2.0748	2.0748	1.2826	2.037	1.8484	2.0748
Min	.9054	1.1317	.9808	.9054	.679	.9054	.8299
Avg	1.4882	1.5813	1.4767	1.0453	1.3227	1.3682	1.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703]

BU 4703

Substation No/ Name :- 113018 / 22/11 KV BEST

Feeder No / Name : 205 / SONAR BUNGLOW

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9313	1.0751	.8954	.9431	1.0185	.8954	.8676
2	.8954	1.0374	.8417	.8676	.9054	.7522	.7545
3	.8238	1.0185	.7701	.8488	.8488	.7343	.7545
4	.788	1.0562	.7343	.8488	.8676	.7164	.7545
5	.788	1.1883	.788	.8676	.9431	.7164	.8676
6	1.0387	1.2637	1.0029	.9619	1.0185	.8954	1.2071
7	1.3432	1.3957	1.1999	1.1317	1.358	1.182	1.3957
8	1.4506	1.4712	1.3432	1.2449	1.226	1.2894	1.4146
9	1.4685	1.4335	1.379	1.4523	1.4712	1.3432	1.4712
10	1.3611	1.3073	1.4523	1.4327	1.3073	1.4327	1.3073
11	1.2536	1.2715	.9991	1.4685	1.2178	1.4148	1.2178
12	1.0387	1.2357	1.2449	1.3432	1.0208	1.2178	1.2715
13	1.0029		1.2071	1.182	1.0029	1.0745	1.1462
14	.985	1.0924	1.0562	1.0029	.9492	1.0208	1.1462
15	1.0566	1.0566	1.0562	.985	.8059	.8417	1.0208
16	1.0387	1.1706	1.1317	.985	.8238	.8775	1.1104
17	1.0566	1.0924		1.1999	.9313	.985	1.1104
18		1.182	1.3203	1.2449	1.0387	1.094	1.1462
19	1.3957	1.5043	1.3957	1.4712	1.1999	1.3203	1.4327
20		1.4327	1.358	1.4523	1.2357	1.358	1.3253
21	1.4712	1.3611	1.5089	1.3535	1.2715	1.358	1.2536
22		1.2715	1.773	1.3203	1.2357	1.2449	1.3073
23		1.1641	1.3203	1.2449	1.0745	1.1317	1.1999
24	1.1462	1.1128	1.0387	1.094	1.094	.985	.9619
Max	1.4712	1.5043	1.773	1.4712	1.4712	1.4327	1.4712
Min	.788	1.0185	.7343	.8488	.8059	.7164	.7545
Avg	1.1167	1.2259	1.1660	1.1645	1.0778	1.0784	1.1435

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113018 / 22/11 KV BEST

Feeder No / Name : 208 / CAMP III

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8473	1.8107	1.7193	1.6975	1.6975	1.6461	1.773
2	1.7558	1.773	1.6095	1.5655	1.6221	1.5364	1.6787
3	1.701	1.8484	1.4998	1.5466	1.5844	1.5181	1.6221
4	1.6461	1.8861	1.5181	1.5278	1.6221	1.5546	1.6032
5	1.6644	1.905	1.4998		1.6975	1.5364	1.6221
6	1.8473	2.1691	1.5729	1.6032	1.7741	1.6461	1.6975
7	1.9204	2.1313	1.7375	1.6461	1.8861	1.9204	1.8673
8	2.1948		1.9022	1.7741	2.1691	1.9387	2.0748
9	2.2862	2.3011	2.3045	2.2257	2.2218	2.1765	2.1313
10	2.5133	2.3655	2.6217	2.5503	2.4025	2.4579	2.4764
11	2.4209	2.4025	2.4143	2.4025	2.3655	2.3655	2.3655
12	2.3285	2.2361	2.4143	2.3655	2.2497	2.2361	2.1807
13	2.2177		2.1691	2.2916	1.9589	1.9774	2.0883
14	1.848	1.8665	1.9805	1.9404	1.885	1.7187	1.9404
15	1.8665	1.8296	1.9616	1.885	3.6591	1.848	1.848
16	1.885	1.7741	1.9616	1.6448	1.6632	1.7187	1.7556
17	1.885	1.7187	1.9616	1.6632	1.7556	1.6817	1.8111
18		1.9387	1.9616	1.8484	1.7924	1.9993	1.9204
19	2.3388	2.2314	2.2822	2.2634	2.1948		2.396
20		2.3594	2.32	2.1582	2.3228	2.5086	2.5057
21	2.32	2.3411	2.2257	2.1502	2.2131	2.3388	2.3777
22		2.2862	2.2068	2.1125	2.1948	2.2822	2.3777
23		2.0302	1.9993	2.0748	2.0302	2.0559	2.1582
24	1.9753	1.905	1.8656	1.773	1.8107	1.7558	1.905
Max	2.5133	2.4025	2.6217	2.5503	3.6591	2.5086	2.5057
Min	1.6461	1.7187	1.4998	1.5278	1.5844	1.5181	1.6032
Avg	2.0231	2.0504	1.9879	1.9439	2.0322	1.9312	2.0074

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113018 / 22/11 KV BEST

Feeder No / Name : 211 / ESIS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7762	.7167	.7577	.679	.7922	.6653	.679
2	.6653	.6979	.7023	.6224	.679	.5729	.5658
3	.6468	.679	.6283	.6036	.6036	.5544	.5281
4	.6468	.7167	.5544	.6036	.6036	.5729	.5281
5	.6283	.7922	.5544	.6036	.679	.5729	.547
6	.7577	.811	.6283	.6036	.7356	.6099	.6036
7	.8501	.8488	.7023	.679	.9431	.7392	.8299
8	.961	.9242	.8316	.8299	.9242	.8871	.9431
9	1.0903	1.0185	1.0349	.8676	1.0562	.924	1.0562
10	1.1523	1.1157	1.0562	1.0974	1.0791	1.0608	1.0608
11	1.0791	1.0974	1.094	1.0242	1.0425	1.0974	1.1157
12	1.0059	.9511	.9619	.9877	.8962	.8779	.8779
13	.8962	.8413	.9054	.8413	.7865	.8048	.823
14	.8048	.8048	.8299	.7499	.567	.7133	.8048
15	.823	.7316	.8299	.6767	.6767	.6767	.823
16	.8048	.8048	.8299	.695	.7316	.6401	.7316
17	.7865	.7499	.8299	.695	.7133	.6584	.7682
18		.7762	.8299	.7545	.7207	.679	.8131
19	.9619	.9055	1.2449	.9054	.924	.9431	.961
20		.961	.9431	.8488	.8871	.9054	1.0164
21	.9619	.924	.8676	.8676	.8871	.9054	.961
22		.924	.9054	.9431	.8871	1.226	.9795
23		.8316	.8488	.8299	.8131	.8299	.9335
24	.8871	.7356	.7577	.7922	.9619	.7392	.7356
Max	1.1523	1.1157	1.2449	1.0974	1.0791	1.226	1.1157
Min	.6283	.679	.5544	.6036	.567	.5544	.5281
Avg	.8593	.8483	.8387	.7834	.8163	.7857	.8202

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703]

BU 4703

Substation No/ Name :- 113025 / 22/11 KV NIRMAL LIFE S/STN

Feeder No / Name : 200 / Corporate

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4805	.4108	.5175	.4435	.4435	.4527	.4066
2	.4435	.3361	.4066	.3696	.3696	.415	.3881
3	.3696	.2801	.3696	.3326	.3326	.415	.3326
4	.3326	.2614	.3142	.2957	.2957	.3772	.2957
5	.2957	.2614	.2957	.2957	.2772	.3395	.3326
6	.2957	.2614	.2772	.2957	.3142	.3395	.3696
7	.2957	.2614	.2957	.2957	.2957	.3018	.4066
8	.4066		.4066	.462	.3511	.3206	.3696
9	.5544	.6722	.462	.499	.4435	.3696	.5175
10	1.0534	1.1016	.8316	.5359	.7545	.8131	
11	1.0903	1.1389	.7762	.6653	.9431	.9425	1.0534
12	1.1088	1.1949	.8686	.6908	.9425	.961	1.0719
13		1.0829	.924	.7023	.8686	.924	1.0719
14		.9709	.924	.7392	.8501	.8871	1.0903
15		1.1576	.8686	.7762	.8501	.924	1.1827
16	1.0903	1.2323	1.0903	.7392	.961	.9795	1.1273
17	1.2012	1.1763	1.0349	.7762	1.0349	.9979	
18	1.1088	1.1203	.961	.8316		1.0534	1.1827
19	.961	1.0642	.9055	.8501		.9425	1.0349
20	.924	1.0269	.8686	.9795	.811	.7947	.9979
21	.8316	.8029	.8131	.8686		.7762	.7207
22	.7392	.7655	.6838	.8131		.7392	.7023
23	.6468	.7282	.6099	.7392		.5175	.6283
24	.5359	.4458	.5975	.5359	.499	.4715	.462
Max	1.2012	1.2323	1.0903	.9795	1.0349	1.0534	1.1827
Min	.2957	.2614	.2772	.2957	.2772	.3018	.2957
Avg	.7031	.7719	.6709	.6055	.6125	.6690	.7157

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113025 / 22/11 KV NIRMAL LIFE S/STN

Feeder No / Name : 201 / OPEL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1357	.1372	.1357	.1357	.1357	.1509	.1357
2	.1357	.1372	.1357	.1357	.1509	.1509	.1357
3	.1357	.1372	.1357	.1357	.1357	.1509	.1357
4	.1357	.1372	.1357	.1357	.1357	.1509	.1357
5	.1357	.1372	.1357	.1357	.1357	.1509	.1696
6	.1357	.1372	.1357	.1357	.1357	.1509	.2035
7	.1357	.1372	.1357	.1357	.1526	.1509	.2374
8	.1357	.1715	.1357	.2035	.1357	.1509	.2374
9	.1357	.1886	.1526	.1357	.1696	.1357	.2374
10	.1357		.1865	.2035	.1886	.1357	
11	.1357	.1372	.1357	.1696	.1357	.1357	.1696
12	1.4922	.1372	.1357		.2035	.1357	.1357
13		.1372	.1357	.1357	.1357	.1357	
14		.1372	.1357	.1357	.1357	.1357	
15		.1372	.1357	.1357	.1357	.1357	
16	.1696	.1372	.1357	.1357	.1357	.1357	
17	.1696	.1372	.1357	.1357	.1357	.1357	.1357
18	.1696	.1372	.1357	.1357		.1357	.1357
19	.1526	.1372	.1696	.1357		.1696	.1357
20	.1526	.1372	.1696	.1357	.1509	.2035	.1357
21	.1526	.1715	.1696	.1357		.2035	.1357
22	.1696	.1372	.2035	.1357		.2035	.1526
23	.1357	.1372	.2374	.1357		.1696	.1357
24	.1357	.1357	.1372	.1357	.1357	.1509	.1357
Max	1.4922	.1886	.2374	.2035	.2035	.2035	.2374
Min	.1357	.1357	.1357	.1357	.1357	.1357	.1357
Avg	.2092	.1424	.1499	.1431	.1463	.1527	.1598

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113025 / 22/11 KV NIRMAL LIFE S/STN

Feeder No / Name : 202 / Amruta

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.703	.6859	.8413	.7011	.8764	.7545	.7186
2	.6173	.6859	.7888	.631	.8238	.7356	.6661
3	.5487	.6001	.7712	.5609	.7888	.6979	.6485
4	.5487	.6516	.7362	.5258	.7537	.7356	.6661
5	.6344	.6687	.7888	.5784	.8063	.7545	.8063
6	.7202	.6344	.8238	.6485	.8589	.7922	.8413
7	.8059	.6859	.8413	.7186	.929	.7922	1.0341
8	.9259	.9431	.8413	.7888	.9816	.8676	.964
9	1.0117	.9945	.8939	.9114	.9816	.8238	.9114
10	1.046	1.046	1.0517	.9114	1.0185	.9114	
11	1.2346	1.1145	1.1043	1.1568	.9991	1.0166	1.1393
12	1.1157	1.0288	.9465	.8939	1.0341	.9114	.9114
13		.9088	.8764	.7888	.9465	.9114	
14		.8745	.8413	.7712	.964	.929	
15		.8402	.8764	1.0349	.9114	.7537	
16	.8745	.7888	.8764	.7011	.8939	.8413	
17	.8573	.8402	.9114	.7537	.9465	.9114	1.0341
18	.8916	.8916	.964	.9114		.9991	1.0867
19	.8916	.9602	.9991	.964		.964	1.1694
20	.9602	.9602	.9816	.9991	.8676	1.0867	1.0631
21	.9431	.9431	.9991	1.0166		.9816	.9214
22	.9088	.8573	.8764	.8413		.8413	1.0277
23	.7716	.8402	.7888	.8589		.7537	.9922
24	.7373	.7202	.8063	.7712	.8413	.7922	.7537
Max	1.2346	1.1145	1.1043	1.1568	1.0341	1.0867	1.1694
Min	.5487	.6001	.7362	.5258	.7537	.6979	.6485
Avg	.8451	.8402	.8844	.8100	.9065	.8566	.9134

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113025 / 22/11 KV NIRMAL LIFE S/STN

Feeder No / Name : 203 / Runwal

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1433	.1448	.1448	.1448	.1509	.1448
2	.8596	.1433	.1448	.1448	.1448	.1509	.1448
3	.8238	.1433	.1448	.1448	.1448	.1509	.1448
4	.8059	.1433	.1448	.1448	.1448	.1509	
5	.8775	.1433	.1448	.1448	.1448	.1509	.1448
6	1.0029	.1433	.1448	.1448	.1448	.1509	.1448
7	1.1999	.1433	.1448	.1448	.1448	.1509	.1629
8	1.2894	.1433	.1448	.1448	.1448	.1509	.181
9	1.5581	.1433	.1448	.181	.1448	.1448	.1448
10	1.773	.1433	.1448	.1448	.1509	.1448	
11	1.9342	.1433	.1448	.1629	.2172	.1448	.181
12	1.7193	.1433	.1448	.1448	.1448	.1448	.1448
13		.1433	.1448	.1448	.181	.1448	
14		.1433	.1448	.1448	.2172	.1448	
15		.1433	.1448	.1448	.1448	.1448	
16	.1433	.1433	.1448	.1448	.1448	.1448	
17	.1433	.1433	.1448	.1448	.1448	.181	.1448
18	.1433	.1433	.181	.1448		.2172	.1448
19	.1433	.1433	.181	.1448		.181	.1448
20	.1433	.1433	.181	.1448	.1509	.1448	.1448
21	.1433	.1612	.181	.1448		.1448	.1448
22	.1433	.1433	.2172	.1448		.1448	.1629
23	.1433	.1433	.181	.1448		.1448	.1448
24	1.0029	.1433	.1433	.1448	.1448	.1509	.1448
Max	1.9342	.1612	.2172	.181	.2172	.2172	.181
Min	.1433	.1433	.1433	.1448	.1448	.1448	.1448
Avg	.7996	.1440	.1553	.1471	.1550	.1531	.1508

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703]

BU 4703

Substation No/ Name :- 113025 / 22/11 KV NIRMAL LIFE S/STN

Feeder No / Name : 204 / sonapur htp

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.6036	.547	.4527	.4904	.6224	.415
2	.415	.5658	.4904	.415	.4715	.6036	.3772
3	.3772	.5658	.4527	.3772	.4527	.5658	.3395
4	.3772	.5281	.4904	.3395	.4715	.5658	.3395
5	.4527	.5281	.4715	.3772	.5093		.4527
6	.5093	.6979	.5281	.4527	.5658	.679	.547
7	.547	.7733	.5658	.5093	.6224	.7356	.679
8	.6413	.7922	.5281	.6224	.6602	.7922	.7167
9	.7356	.9808	.7733	.7545	.7733		.8488
10	.811	.9242	1.0562	.7356	.9619	.8488	
11	.8676	1.0185	.8865	.6979	.8488	.9619	.9808
12	.9431	.9054	.8676	.6979	.8299	.9808	.9431
13		.8488	.811	.4715	.7922	.9054	.8488
14		.7922	.7356	.4527	.811	.8299	.8676
15		.8865	.8676	.4715	.7733	.8488	.8676
16	.9242	.9242	.7922	.4338	.8676	.7922	.8488
17	.811	.9242	.7167	.4527	.811	.7733	
18	.9054	.8299	.7922	.3772		.7545	.8299
19	.9431	.8676	.7733	.415		.7733	.811
20	.7922	.811	.679	.4527	.9242	.7356	.7545
21	.7545	.7545	.5788	.4338		.679	.679
22	.6979	.6979	.5658	.3772		.6224	.6224
23	.6413	.5658	.5093	.4527		.547	.5281
24	.5281	.6602	.5093	.5093	.4527	.679	.4904
Max	.9431	1.0185	1.0562	.7545	.9619	.9808	.9808
Min	.3772	.5281	.4527	.3395	.4527	.547	.3395
Avg	.6727	.7686	.6662	.4888	.6889	.7407	.6722

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113025 / 22/11 KV NIRMAL LIFE S/STN

Feeder No / Name : 205 / vasant oscar 2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1357	.1372	.1372	.1372	.1387	.1886	.1478
2	.1357	.1543	.1372	.1372	.1387	.1886	.1478
3	.1357	.1372	.1372	.1372	.1387	.1509	.1478
4	.1357	.1372	.1372	.1372	.1387	.1509	.1478
5	.1357	.1372	.1543	.1715	.1387	.1509	.1848
6	.2035	.1543	.1543	.2058	.1387	.1886	.2218
7	.2374	.1715	.1715	.2401	.1387	.1886	.2587
8	.2374	.1886		.1715	.1387	.1886	.2587
9	.2374	.1543	.1372	.2058	.1387	.2218	.2218
10	.2374	.1372	.2058	.2401	.1509	.2587	
11	.2374	.1478	.1372	.2058	.2427	.2641	.2218
12	.2035	.1715	.1372	.1886	.2218	.2587	.2587
13		.1372	.1372	.2058	.2587	.2587	.2587
14		.1372	.1372	.1372	.2218	.2587	.2587
15		.1372	.1372	.1372	.2218	.2587	.2587
16	.1357	.1372		.1543	.1848	.2587	.2587
17	.1357	.1372	.1372	.1543	.1848	.2218	
18	.1357	.1372	.1715	.1372		.1848	.1478
19	.1357	.1715	.1715	.1372		.2587	.1387
20	.1357	.1715	.1715	.1372	.1886	.2218	.1387
21	.1357	.1372	.1715	.1372		.2218	.1387
22	.1526	.1715	.2401	.1372		.2218	.156
23	.1357	.1372	.2401	.1372		.1848	.1387
24	.1357		.1387	.1715	.1372	.1886	.1478
Max	.2374	.1886	.2401	.2401	.2587	.2641	.2587
Min	.1357	.1372	.1372	.1372	.1372	.1509	.1387
Avg	.1672	.1496	.1591	.1651	.1717	.2141	.1936

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - III[551]

MUMBRA[152] BU 4391

Substation No/ Name :- 283087 / BHARAT GEAR SWITCHING
STATION

Feeder No / Name : 301 / SAGAR

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	10-FEB-18	13-FEB-18
HR	Load (MW)	Load (MW)
12		7.2398
18	6.6606	
Max	6.6606	7.2398
Min	6.6606	7.2398
Avg	6.6606	7.2398

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - III[551]

MUMBRA[152] BU 4391

Substation No/ Name :- 283087 / BHARAT GEAR SWITCHING
STATION

Feeder No / Name : 304 / KAUSA

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	10-FEB-18	13-FEB-18
HR	Load (MW)	Load (MW)
12		7.8189
18	5.9877	
Max	5.9877	7.8189
Min	5.9877	7.8189
Avg	5.9877	7.8189

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - III[551]

MUMBRA[152] BU 4391

Substation No/ Name :- 283087 / BHARAT GEAR SWITCHING
STATION

Feeder No / Name : 305 / SHARIFA ROAD

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	10-FEB-18	13-FEB-18
HR	Load (MW)	Load (MW)
12		3.3265
18	2.8959	
Max	2.8959	3.3265
Min	2.8959	3.3265
Avg	2.8959	3.3265

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - III[551]

MUMBRA[152] BU 4391

Substation No/ Name :- 283087 / BHARAT GEAR SWITCHING
STATION

Feeder No / Name : 306 / SABE GAON FEEDER

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	10-FEB-18	13-FEB-18
HR	Load (MW)	Load (MW)
12		4.3077
18	4.7058	
Max	4.7058	4.3077
Min	4.7058	4.3077
Avg	4.7058	4.3077

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - III[551]

MUMBRA[152] BU 4391

Substation No/ Name :- 283087 / BHARAT GEAR SWITCHING
STATION

Feeder No / Name : 308 / Devari Pada

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	10-FEB-18	13-FEB-18
HR	Load (MW)	Load (MW)
12		2.1719
18	2.0271	
Max	2.0271	2.1719
Min	2.0271	2.1719
Avg	2.0271	2.1719

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - III[551]

SHIL SUB DIVISION[643] BU 4643

Substation No/ Name :- 283090 / khidkali s/s

Feeder No / Name : 301 / DIVA

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		7.0302	6.5158	7.1674			6.6873
2		6.5844	6.1728	7.2017			6.5158
3		7.5446	5.8985	7.6818			6.3443
4		8.2991	6.5158	8.1962			7.2017
5		8.5734	8.059	8.6077	9.7737		8.059
6		9.0878	8.7449	8.9506	9.2593		9.0878
7		8.9506	9.2593	9.2593	10.8025		9.3964
8		8.6077	8.5734	9.1221	10.048	8.2305	8.882
9		7.5789	8.059		8.1619	8.5734	
10	7.9218	7.2017	7.2017			7.4074	4.8354
11	7.2017	6.5158		7.6818			7.0645
12	6.653	5.8299	6.07	7.0302		5.487	6.3786
13	6.3443	5.487		6.3443		5.6927	6.1386
14	5.7956			6.1386		5.0412	5.7956
15	5.5556	5.487		5.8299		4.6296	5.8985
16	5.3155	5.144	6.1043		4.904	5.0069	5.6242
17		5.4184		6.0357		5.8299	
18	6.1728	5.6584		6.5158		6.5158	
19	8.7449	8.7449				8.882	10.4595
20	10.0823	9.2593	9.6022	9.7051		9.6022	10.6996
21	9.8766	9.2593					10.4595
22		8.9163		.3429		9.4307	9.9451
23	8.7106	8.5734	8.642	8.7106		8.3676	9.0878
24		7.7161	7.5446	7.476		6.5844	7.2359
Max	10.0823	9.2593	9.6022	9.7051	10.8025	9.6022	10.6996
Min	5.3155	5.144	5.8985	.3429	4.904	4.6296	4.8354
Avg	7.3646	7.4551	7.5309	7.2630	8.8249	7.0188	7.7046

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

KALWA S/DN.[128]

BU 4261

Substation No/ Name :- 283086 / SHIVAJI HOSPITAL 22/11 KV

Feeder No / Name : 204 / S. T. WORKSHOP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1706	1.1104	1.1163	1.0985	.9671	1.0099	1.0425
2	1.0974	1.0745	1.0631	1.0277	.9313	.9568	1.0425
3	1.0608	1.0387	.9745	.9568	.8954	.8859	.9877
4	1.0242	1.0387	.9036	.8859	.9134	.8505	.9145
5	1.1706	1.0745	1.1163	.9214	.9313	.9214	.9694
6	1.2803	1.1462	1.1163	.9568	1.0029	.9922	1.2437
7	1.3169	1.2536	1.1694	1.0985	1.1462	1.1871	1.2803
8	1.3717	1.379	1.1871	1.134	1.3432	1.382	1.3352
9	1.5581	1.576	1.4529	1.2403	1.5402	1.4883	1.4083
10	1.5581	1.4352	1.4352	1.5223	1.382	1.4632	1.3969
11	1.4864	1.382	1.382	1.379	1.3466	1.39	1.3611
12	1.379	1.382	1.382	1.3432	1.2048	1.2803	1.3432
13	1.2357	1.2048	1.134	1.2536	1.1517	1.1706	1.2567
14	1.2894	1.134	1.134	1.1104	1.0985	1.0608	1.1283
15	1.0745	1.0631	1.0631	.985	1.0277	.9511	1.0745
16	1.0745	1.0277	1.0277	.9134	.9568	.9145	1.0566
17	1.0924	1.0277	.9745	.9671	.9214	.9145	1.0924
18	1.1999	1.134	1.2403	1.0387	1.0631	1.1157	1.1999
19	1.6655		1.5947	1.4506	1.4529	1.4998	1.6297
20	1.6297		1.5592	1.4148	1.4706	1.5364	1.6476
21	1.576		1.4883	1.3611	1.4175		1.576
22	1.4506	1.3466	1.4175	1.3611	1.382	.1372	
23	1.3611	1.3289	1.3112	1.2715	1.2403	1.3169	1.379
24	1.2437	1.1999	1.1694	1.1694	1.0745	1.0631	1.0974
Max	1.6655	1.576	1.5947	1.5223	1.5402	1.5364	1.6476
Min	1.0242	1.0277	.9036	.8859	.8954	.1372	.9145
Avg	1.3070	1.2075	1.2255	1.1609	1.1609	1.1082	1.2375

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

KALWA S/DN.[128]

BU 4261

Substation No/ Name :- 283086 / SHIVAJI HOSPITAL 22/11 KV

Feeder No / Name : 205 / SHIVAJI HOSPITAL

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.1509	.1509	.1509	.1509	.1509	.1646
2	.1463	.1509	.1509	.1509	.1509	.1509	.1463
3	.1463	.1509	.1509	.1509	.1509	.132	.1463
4	.1463	.1509	.1509	.1509	.1509	.0754	.1463
5	.1463	.1509	.132	.1509	.1509	.132	.1646
6	.1646	.1509	.1509	.1509	.1509	.132	.1646
7	.1829	.1698	.1509	.1509	.1509	.1509	.1646
8	.1829	.1886	.1698	.1698	.1509	.1509	.2012
9		.2075	.2452	.2075	.1509	.1698	.2378
10	.2452	.2263	.2641	.1509	.2452	.1646	.3018
11	.3109	.3206	.3206	.1698	.3206	.1829	.2641
12	.2561	.3018	.2641	.1509	.3206	.2012	.2829
13	.3206	.3018	.2829	.1509	.2829	.2012	.2641
14	.2452	.2829	.2641	.1509	.3395	.1829	.3018
15	.2641	.3018	.2641	.1509	.3018	.1829	.2452
16	.2263	.2829	.2452	.1698	.2641	.1646	.2263
17	.1886	.2075	.1886	.1509	.2075	.1646	.2263
18	.1886	.2075	.1886	.1509	.2075	.1646	.1698
19	.2452		.2075	.1698	.2452	.2012	.1886
20	.2075		.2075	.1698	.2263	.1829	.1698
21	.2075		.1886	.1698	.2075		.1698
22	.1698	.1698	.1698	.1509	.2075	.2195	
23	.1509	.1698	.1509	.1509	.1886	.1829	.1509
24	.1646	.1698	.1509	.1698	.1509	.1509	.1646
Max	.3206	.3206	.3206	.2075	.3395	.2195	.3018
Min	.1463	.1509	.132	.1509	.1509	.0754	.1463
Avg	.2023	.2102	.2004	.1588	.2114	.1649	.2027

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

KALWA S/DN.[128]

BU 4261

Substation No/ Name :- 283086 / SHIVAJI HOSPITAL 22/11 KV

Feeder No / Name : 301 / CHINCHPADA

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.9145	.8779	.8413	.8048	.8048	.8413
2	.8779	.8779	.8048	.8048	.7316	.7682	.8413
3	.8048	.8048	.7316	.7682	.695	.7316	.7682
4	.7682	.8048	.7316	.7316	.695	.695	.7316
5	.8779	.8871	.7682	.7682	.8048	.7682	.8048
6	.9877	1.0974	.8413	.7682	.9145	.8413	.8779
7	1.0974	1.0974	1.0242	.9877	1.0608	.9511	1.0608
8	1.2803	1.2437	1.0974	1.0608	1.1706	1.0974	1.134
9	1.3535	1.2803	1.2437	1.1706	1.2803	1.2437	1.2071
10	2.3411	1.1706	1.2071	1.39	1.2803	1.0974	1.1706
11	1.134	1.134	1.0974	1.1706	.9979	1.0242	1.0608
12	1.0608	1.0608	1.0608	1.0242	.9511	.9511	.9511
13	1.0242	.9877	.9877	.9511	.9145	.8779	
14	.8779	.8413	.8779	.8779	.8048	.8048	
15	.8048	.7682	.8048	.7682	.7682	.7682	1.0608
16	.8048	.7682	.7316	.695	.7316	.7316	.8779
17	.8048	.7316	.7682	.8779	.7316	.695	.9145
18	.9145	.8413	.9511	.8413	.8048	.8413	.9877
19	1.2803		1.2071	1.2437	1.0974	1.2071	1.2803
20	1.3169		1.2437	1.2437	1.2437	1.2071	1.3535
21	1.3535		1.2071	1.2803	1.1706		1.2803
22	1.1706		1.1706	1.0974	1.0608	1.0974	
23	1.0608		1.0242	.9511	.9145	.9877	1.0608
24	.9511	.9877	.9511	.8779	.8413	.8413	.8779
Max	2.3411	1.2803	1.2437	1.39	1.2803	1.2437	1.3535
Min	.7682	.7316	.7316	.695	.695	.695	.7316
Avg	1.0776	.9631	.9755	.9663	.9363	.9145	1.0068

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

KALWA S/DN.[128]

BU 4261

Substation No/ Name :- 283086 / SHIVAJI HOSPITAL 22/11 KV

Feeder No / Name : 302 / KALWA NAKA

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3045	2.3285	2.1437	2.1437	2.1068	1.9959	1.9753
2	2.3045	2.2177	2.0698	2.0698	2.0328	1.885	1.9239
3	2.268	2.1437	1.9959	1.9589	1.922	1.8111	1.7924
4	2.268	2.2177	1.885	1.885	1.922	1.7558	1.7558
5	2.1948	2.3655	2.2177	1.9959	2.0698	1.922	1.9022
6	2.5606	2.5873	2.4394	2.1068	2.3655	2.2546	2.4874
7	2.9995	2.8829	2.7721	2.2916	2.9199	2.5873	2.8532
8	3.1459	3.1417	2.9938	2.7351	2.9569	3.2895	2.9264
9		3.0308	2.9569	2.9569	3.0678	3.2526	2.8532
10	2.7721	2.7351	2.7721	3.0678	2.4764	3.131	2.6242
11	2.6242	2.5133	2.6612	2.9199	2.2916	2.5606	2.5503
12	2.3655	2.3655	2.4764	2.5503	2.1437	2.3411	2.1437
13	2.3285	2.2177	2.2177	2.2916	2.0328	2.1216	2.1437
14	2.1807	1.9959	1.9959	2.2177	1.9959	1.9022	1.9959
15	1.9959	1.848	1.848	1.9959	1.848	1.7193	1.9589
16	1.922	1.7741	1.8111	1.7741	1.7741	1.7353	1.922
17	1.9589	1.7741	1.885	1.885	1.7741	1.6827	2.1807
18	2.0698	2.0328	2.1807	2.0328	1.9589	1.9753	2.1807
19	2.846		2.809	2.6612	2.6242	2.6703	2.846
20	2.9938		2.809	2.846	2.809	2.7069	2.9569
21	2.9569		2.7721	2.809	2.6981	2.7069	3.0678
22	2.8829		2.6981	2.6242	2.5873	2.6337	
23	2.6981		2.5873	2.4394	2.4025	2.3777	2.7721
24	2.3777	2.4025	2.2177	2.2546	2.2546	2.1068	2.0851
Max	3.1459	3.1417	2.9938	3.0678	3.0678	3.2895	3.0678
Min	1.922	1.7741	1.8111	1.7741	1.7741	1.6827	1.7558
Avg	2.4791	2.3460	2.3840	2.3547	2.2931	2.2969	2.3434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

POWER HOUSE S/DN.[727] BU 4727

Substation No/ Name :- 283070 / THANE (W)RECVING STATION

Feeder No / Name : 201 / CLOCK TOWER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	11-FEB-18
HR	Load (MW)
10	.1848
12	.1848
14	.1848
16	.1848
18	.1848
20	.1848
Max	.1848
Min	.1848
Avg	.1848

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

POWER HOUSE S/DN.[727] BU 4727

Substation No/ Name :- 283070 / THANE (W)RECVING STATION

Feeder No / Name : 202 / BALAWANT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9335			.8402		
2				.9335		.9335	.8402
3		.9335	.9335		.8402		
4				.7468		.8402	.8402
5		1.1203	1.0269		1.0269		
6	1.307			1.0269		1.1203	1.2136
7		1.307	1.307		1.2136		
8	1.4937			1.1203		1.307	1.4003
9		1.4003	1.587				
10	1.9605	1.9605	1.8671	1.4937	1.9605	1.7737	1.9605
12	2.1691	2.1472	2.0538	1.6804	2.0538		2.0538
14	1.9605	2.1472	1.6804	1.4937	1.7737	1.4937	1.7737
16	1.9805	2.1472	1.587	1.307	1.587	1.4937	1.9605
18	1.9605		1.6804	1.4003	1.7737	1.587	1.9605
20	1.9605	2.0538	1.8671	1.587	1.8671	1.8671	2.0538
22	1.4937	1.587	1.4937	1.4003	1.587	1.4937	1.587
24		1.1203	1.1203	1.1203	1.0269	1.0269	1.0269
Max	2.1691	2.1472	2.0538	1.6804	2.0538	1.8671	2.0538
Min	1.307	.9335	.9335	.7468	.8402	.8402	.8402
Avg	1.8096	1.5715	1.5170	1.2759	1.4626	1.3579	1.5559

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

POWER HOUSE S/DN.[727] BU 4727

Substation No/ Name :- 283070 / THANE (W)RECVING STATION

Feeder No / Name : 203 / RAVI UDAY SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1829			.1829		
2				.2772		.2743	.2772
3		.1829	.2743		.1848		
4	.2743			.1848		.2743	.1848
5		.1829	.2743		.1848		
6				.1848		.2743	.1848
7		.3658	.2743		.2743		
8	.3658			.3658		.3696	.3658
9			.3658				
10	.3658	.4572	.3696	.3658	.3658	.3696	.4572
12	.5487	.4572	.462	.4572	.4572	.462	.4572
14	.5487	.4572	.462	.4572	.4572	.462	.4572
16	.5487	.4572	.462	.3658	.4572	.462	.4572
18	.5487		.462	.4572	.4572	.462	.5487
19					.4572		
20	.5487	.5487	.462	.4572	.5487	.462	.5544
22	.3658	.3658	.3696	.3658	.3658	.3696	.3658
24		.2743	.2743	.2772	.1829	.2801	.2772
Max	.5487	.5487	.462	.4572	.5487	.462	.5544
Min	.2743	.1829	.2743	.1848	.1829	.2743	.1848
Avg	.4572	.3575	.3760	.3513	.352	.3768	.3823

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

POWER HOUSE S/DN.[727] BU 4727

Substation No/ Name :- 283070 / THANE (W)RECVING STATION

Feeder No / Name : 204 / NIRAJ

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1867			.1867		
2				.2801		.1867	.2801
3		.1867	.3734		.1867		
4	.2801			.1867		.1867	.1867
5		.1867	.1867		.1867	.1867	
6						.1867	.1867
7		.1867	.1867				
8	.2801			.3734		.1867	.2801
9			.1867				
10	.4668	.4668	.3734	.3734	.3734	.2801	.4668
12	.6535	.6535	.5601	.4668	.4668	.3734	.5601
14	.5601	.6535	.4668	.4668	.4668	.3734	.4668
16	.6535	.6535	.4668	.4668	.3734	.3734	.5601
18	.6535		.6535	.3696	.4668	.2801	.3734
20	.6535	.6535	.5601	.4668	.3734	.3734	.3734
22	.1867	.2801	.2801	.4668	.2801	.2801	.3734
24		.1867	.1867	.2801	.1867	.1867	.2801
Max	.6535	.6535	.6535	.4668	.4668	.3734	.5601
Min	.1867	.1867	.1867	.1867	.1867	.1867	.1867
Avg	.4875	.3904	.3734	.3816	.3225	.2657	.3656

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

POWER HOUSE S/DN.[727] BU 4727

Substation No/ Name :- 283070 / THANE (W)RECVING STATION

Feeder No / Name : 205 / THANE AUDITORIUM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3734			.2801		
2						.3734	.2801
3		.2801			.2801		
4	.2801			.1867		.2801	.3734
5		.2801	.3734		.2801		
6				.2801		.3734	.3734
7		.3734	.3734		.2801		
8	.5601			.4668		.4668	.3734
9			.4668				
10	.7468	.7468	.5601	.6535	.6535	.5601	.7468
12	.9335	1.0269	.7468	.8402	.7468	.7468	.8402
14	.8402	.9335	.7468	.8402	.8402	.6535	.7468
16	.9335	.9335	.7468	.6535	.7468	.6535	1.0269
18	.8402		.8402	.6535	.7468	.6535	.9335
20	.8402	.9335	.9335	.9335	.7468	.8402	.8402
22	.5601	.5601	.5601	.5601	.5601	.4668	.5601
24		.4715	.4668	.3734	.4668	.3734	.2801
Max	.9335	1.0269	.9335	.9335	.8402	.8402	1.0269
Min	.2801	.2801	.3734	.1867	.2801	.2801	.2801
Avg	.7261	.6284	.6195	.5856	.5524	.5368	.6146

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

POWER HOUSE S/DN.[727] BU 4727

Substation No/ Name :- 283070 / THANE (W)RECVING STATION

Feeder No / Name : 206 / PURNIMA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4668			.4668		
2				.2801		.3734	.2801
3		.3734	.3696		.3734		
4	.4668			.2801		.3734	.2801
5		.3734	.4668		.3734		
6				.4668		.3734	.4668
7			.5601		.4668		
8	.7468			.5658		.6535	.5601
9			.8402				
10	1.307	1.2136	1.1203	1.2136	1.307	1.1203	1.587
12	1.9605	1.8671	1.8671	1.6804	1.6804	1.6804	1.8671
14	1.9605	1.8671	1.7737	1.4937	1.6804	1.6804	1.9605
16	1.9605	1.8671	1.6804	1.4937	1.7737	1.587	1.9605
18	1.8671		1.7737	1.4937	1.7737	1.6804	1.9605
20	1.6804	1.587	1.587	1.4003	1.587	1.4937	1.7737
21			1.4937				
22	.7468	.8402	.8402	.8402	.8402	.8402	.905
24		.4668	.4668	.4668	.6535	.4668	.4668
Max	1.9605	1.8671	1.8671	1.6804	1.7737	1.6804	1.9605
Min	.4668	.3734	.3696	.2801	.3734	.3734	.2801
Avg	1.4107	1.0923	1.1415	.9729	1.0814	1.0269	1.1724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

POWER HOUSE S/DN.[727] BU 4727

Substation No/ Name :- 283070 / THANE (W)RECVING STATION

Feeder No / Name : 208 / LAKE VIEW

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5544			.462		
2				.3696			.2772
3		.462	.4572		.3734		
4	.4572			.2772		.3658	.2772
5		.4668			.3696	.4572	
6	.5487			.3696		.4572	.462
7		.6401	.6468		.6535		
8	.7392			.7392		.6468	.6468
9			.7316				
10	1.0164	.9145	.924	.8316	1.0164	.8316	1.2012
12	1.2936	1.2803	1.1088	1.0164	1.1888	1.1088	1.2936
14	1.2012	1.2012	.924	.924	1.0974	.924	1.2012
16	1.2012	1.1888	1.0164	.8316	1.1088	.924	1.2936
18	1.2936		1.1088	1.0164	1.1088	1.1088	1.386
20	1.2936	1.1888	1.2012	1.0164	1.2012	1.1088	1.386
22	.7392	.7316	.7392	.7392	.823	.7392	.8316
24		.6468	.5487	.5544	.5544	.462	.462
Max	1.2936	1.2803	1.2012	1.0164	1.2012	1.1088	1.386
Min	.4572	.462	.4572	.2772	.3696	.3658	.2772
Avg	.9784	.8432	.8552	.7238	.8298	.7612	.8932

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

POWER HOUSE S/DN.[727] BU 4727

Substation No/ Name :- 283070 / THANE (W)RECVING STATION

Feeder No / Name : 210 / CHIRANJIVI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1848			.1848		
2				.2772		.1848	.2772
3		.1848	.1848		.1848		
4	.1848			.1848		.0924	.1848
5		.1848	.1848		.1848		
6	.1848			.1848		.1848	.1848
7		.1848	.1848		.1848		
8	.1848			.1848		.1848	.1848
9			.2772				
10	.2772	.2772	.2772	.1848	.2772	.2772	.2772
12	.1848	.2772	.2772	.1848	.2772	.2772	.1848
14	.1848	.2772	.2772	.1867	.2772	.2772	.1848
16	.1848	.2772	.2772	.1848	.2772	.2772	.1848
18	.1848		.2772	.1848	.2772	.2772	.1848
20	.1848	.2772	.2772	.1848	.2772	.2772	.2772
22	.1848	.2772	.2772	.1848	.2772	.2772	.2772
24		.1848		.2772	.1848	.1848	.2772
Max	.2772	.2772	.2772	.2772	.2772	.2772	.2772
Min	.1848	.1848	.1848	.1848	.1848	.0924	.1848
Avg	.1940	.2352	.252	.2004	.2387	.231	.2233

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

POWER HOUSE S/DN.[727] BU 4727

Substation No/ Name :- 283070 / THANE (W)RECIIVING STATION

Feeder No / Name : 212 / VPM

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0848			.0848		
2				.0914		.0876	.0914
3		.0848			.0848		
4	.0876			.0914		.0876	.0914
5		.0848			.0857		
6	.0876			.0914		.0876	.0914
7		.0876			.0857		
8	.0819			.0857		.0914	.0848
10	.0857	.1753		.0848	.2629	.0914	.0857
12	.0857			.0848	.2629	.0914	.0857
14	.0848		.0914	.0848	.1753	.0914	.0857
16	.0857		.0914	.0857	.1753	.0934	.0857
18	.0848		.0914	.0848	.1753	.0934	.0848
20	.0848		.0914	.0857	.0876	.0914	.0848
22	.0848		.0914	.0848	.0876	.0914	.0857
23					.0876		
24		.0848		.0914	.0848		.0914
Max	.0876	.1753	.0914	.0914	.2629	.0934	.0914
Min	.0819	.0848	.0914	.0848	.0848	.0876	.0848
Avg	.0853	.1004	.0914	.0872	.1339	.0907	.0874

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283072 / 22/11kv vrindavan s/s

Feeder No / Name : 201 / RABODI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0456			.9709	.9242		
2			.9242			.811	.8299
3	.9709	.8865		.8402	.8488		
4			.8676			.7922	.7545
5	.9335			.8402	.8676		
6		.9808	.8676			.8299	.9619
7	1.0456					.8589	
8	1.1203		1.0751	.9896	1.0374	.9709	1.0374
9	1.0374	1.1694	1.0829		1.1506		1.1506
11			1.0082		.924		
12	.9431	1.094	.9709	1.1128	.9709	.9997	.9979
14			1.0269	.9054	.9425	1.0185	1.1203
15	.9431				.8131		
16			.8686	.8865		.9054	.9335
17					.7842		
18	.9054	1.1317	.9335			.9242	.9335
19					1.0719		
20		1.1883	1.2012	1.094		1.1506	1.1949
21	1.358						
22	.9054	1.2071	1.2136	1.1694	1.1576	1.2826	1.2012
23					1.1088		1.1576
24	1.0642	1.1317	1.0374	1.0269	.9997	.9709	.9431
Max	1.358	1.2071	1.2136	1.1694	1.1576	1.2826	1.2012
Min	.9054	.8865	.8676	.8402	.7842	.7922	.7545
Avg	1.0227	1.0987	1.0060	.9836	.9715	.9596	1.0166

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283072 / 22/11kv vrindavan s/s

Feeder No / Name : 202 / H T CABIN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6161			.5228	.5093	.4668	
2			.5658			.415	.4527
3	.5601	.4904		.4108	.4527		
4			.5281			.4108	.415
5	.5975			.4668	.5093		
6		.6602	.5281			.5281	.5847
7	.6722					.6161	
8	.7842		.6979	.5975	.6979	.6908	.7733
9	.7545	.7922	.6908		.6979		.811
11			.7095				.5914
12	.6224	.679	.6468	.7356	.5544	.6224	.5544
14			.5544	.6602	.4805	.5658	.6099
15	.5281				.462		
16			.4805	.4715		.4527	.4805
17					.4338		
18	.547	.7733	.5914			.5658	.5544
19					.6468		
20		.7922	.7762	.7545			.7468
21	.8299						
22		.7356	.7468	.6602	.6838	.7545	.7468
23					.6348		.6722
24	.7095	.6224	.6036	.5975	.5281	.5601	.5658
Max	.8299	.7922	.7762	.7545	.6979	.7545	.811
Min	.5281	.4904	.4805	.4108	.4338	.4108	.415
Avg	.6565	.6932	.6246	.5877	.5609	.5541	.6114

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283072 / 22/11kv vrindavan s/s

Feeder No / Name : 203 / VRINDAVAN - 4

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494			.1494	.1132	.1509	
2			.1132			.1307	.1132
3	.1307	.1132		.1307	.0943		
4			.0943			.132	.0943
5	.168			.1307	.0113		
6		.1509	.1132			.168	.1698
7	.2054					.2075	
8	.2427		.1886	.1663	.2641	.2241	.2263
9	.2263	.2452	.2054		.2452		.2452
11			.2241		.1848		.1848
12	.1886	.1698	.2218	.3584	.1663	.1698	.2218
14			.1848	.1698	.1494	.1509	.168
15	.1509				.1494		
16			.168	.1509		.132	
17					.1509		
18	.1698	.2641	.1867			.1509	.1478
19					.1867		
20		.2075	.2241	.2075			.1867
21	.2263						
22		.1886	.168	.1698	.2241	.1886	.2054
23					.1848	.2263	.2054
24	.1867	.1698	.1509	.168	.5658	.1494	.1509
Max	.2427	.2641	.2241	.3584	.5658	.2263	.2452
Min	.1307	.1132	.0943	.1307	.0113	.1307	.0943
Avg	.1859	.1886	.1725	.1802	.1922	.1678	.1784

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283072 / 22/11kv vrindavan s/s

Feeder No / Name : 205 / R W SAWANT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4563			1.3256	1.2449	1.2883	
2			1.1317			1.2136	1.2449
3	1.3817	1.1317		1.1576	1.1317		
4			1.2449			1.1576	1.0374
5	1.419			1.1203	1.1694		
6		1.358	1.3203			1.2136	1.4146
7	1.587					1.251	
8	1.587		1.5655	1.4377	1.6032	1.6244	1.5844
9	1.9616	1.8484	1.8111		1.905		1.8861
11			2.1845		2.1253		2.0911
12	2.1125	2.1313	2.0725	1.9805	2.0328	1.9805	2.2218
14			1.9404	1.6598	1.8671	1.6409	1.885
15	1.9993				1.885		
16			1.9044	1.5089		1.773	2.0165
17					1.8861		
18	1.9239	2.2634	1.8858			1.8296	2.0725
19					1.9791		
20		1.9993	1.9959	1.7164		1.905	2.1253
21	1.8107						
22		1.7164	1.6632	1.5844	1.6057	1.6221	1.8671
23					1.5684		1.7556
24	1.587	1.5089	1.4146	1.4377	1.3392	1.3213	1.4146
Max	2.1125	2.2634	2.1845	1.9805	2.1253	1.9805	2.2218
Min	1.3817	1.1317	1.1317	1.1203	1.1317	1.1576	1.0374
Avg	1.7115	1.7447	1.7027	1.4929	1.6674	1.5247	1.7584

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283072 / 22/11kv vrindavan s/s

Feeder No / Name : 206 / INDIAN LEAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1584			.4108	.3584	.3734	
2						.3361	.3395
3	1.1389	1.0185		.3734	1.1317		
4			.3772			.2801	.3018
5	1.1949			.2801	1.1694		
6		1.2071	.3772			.2987	.415
7	1.307					.2987	
8	1.4937		.3772	.3921	.4527	.4108	.415
9	1.6598	1.6598	.4294		.4338		.4338
11			.4108		.4805		.431
12	2.2257	2.0748	.462	.4338	.499	.4715	.499
14			.4066	.3772	.4108	.3772	.4294
15	1.9239				.3881		
16			.3511	.3584		.3961	.4108
17					.3734		
18	1.8484	.5281	.3921			.3961	.4572
19					.5601		
20		.5847	.5601	.5658		.5847	.6283
21	1.8107						
22		.5093	.5415	.547	.5415	.5281	.5914
23					.5228		.5415
24		1.3769	.4338	.4481	.4527	.4668	.4338
Max	2.2257	2.0748	.5601	.5658	1.1694	.5847	.6283
Min	1.1389	.5093	.3511	.2801	.3584	.2801	.3018
Avg	1.5761	1.1199	.4266	.4187	.5554	.4014	.4520

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283072 / 22/11kv vrindavan s/s

Feeder No / Name : 207 / T.M.C.PUMPING

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0642			.8589	.7922	.8029	
2			.7922			.7095	.7733
3	.9709	.9431		.7468	.7545		
4			.7545			.6722	.679
5	1.0642			.7842	.8299		
6		1.1317	.8488			.8215	1.1506
7	1.363					1.0642	
8	1.423		1.2071	1.0456	1.3014	1.2136	1.358
9	1.7353	1.6975	1.2696		1.3769		1.4901
11			1.4003		1.3676		1.4415
12	1.7193	1.7164	1.4003	1.3203	1.363	1.3769	1.2136
14			1.1088	1.1317	.9945	.9997	1.2696
15	1.6975				1.0903		
16			1.0349	.8865		.9808	1.2382
17					1.0642		
18	1.6221	1.5844	1.1827			1.0374	1.251
19					1.2012		
20		1.358	1.3491	1.3203		1.1694	1.2936
21	1.5844						
22		1.2826	1.2012	1.0374	1.1203	1.1883	1.2136
23					1.0164		1.1389
24	1.2136	1.1883	.9054	.9335	.8865	.8962	.9242
Max	1.7353	1.7164	1.4003	1.3203	1.3769	1.3769	1.4901
Min	.9709	.9431	.7545	.7468	.7545	.6722	.679
Avg	1.4052	1.3628	1.1119	1.0065	1.0828	.9948	1.1739

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283073 / SAKET RECEIVING STATION

Feeder No / Name : 202 / SAKET-I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1595			
3	.1578					.1578	
6	.1928				.2103	.1753	
9	.2804	.2658		.2481	.298	.2804	.2835
10			.3012				
11						.2658	
12	.2126	.2126	.2126	.2629	.1928	.2481	.2804
15	.1595		.1772	.1928	.1928	.1417	.1928
18			.1949	.1402	.1402	.1772	.1578
20						.2126	
21	.2303		.2126	.1753	.2103	.1949	.2103
24	.1928	.1949		.1949	.1753	.1578	.1772
Max	.2804	.2658	.3012	.2629	.298	.2804	.2835
Min	.1578	.1949	.1772	.1402	.1402	.1417	.1578
Avg	.2037	.2244	.2197	.1962	.2028	.2012	.217

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283073 / SAKET RECEIVING STATION

Feeder No / Name : 203 / AKASHGANGA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.2936			
3	1.1888				1.0425	1.0059	
6	1.3169				1.2071	1.0974	
9	1.3352	1.5893		1.5524	1.3535	1.4083	1.423
10			1.3676				
11						1.3306	
12	1.2752	1.5708	1.2197	1.4449	1.1706	1.2752	1.2567
15	1.2936		1.2012	1.3535	1.1706	1.1643	1.2936
18	1.2567		1.3121	1.2071	1.134	1.1827	1.2382
20						1.5524	
21	1.885		1.8296	1.6827	1.6461	1.7002	1.8111
24	1.4815	1.5154		1.3676	1.262	1.2071	1.2752
Max	1.885	1.5893	1.8296	1.6827	1.6461	1.7002	1.8111
Min	1.1888	1.5154	1.2012	1.2071	1.0425	1.0059	1.2382
Avg	1.3791	1.5585	1.3860	1.4145	1.2483	1.2924	1.3830

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283073 / SAKET RECEIVING STATION

Feeder No / Name : 204 / SAKET II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.7655			
3	.7468				.6468	.6283	
6	.9335				.8871	.8501	
9	1.2323	.9896		1.1203	1.1088	1.1643	1.251
10			1.3443				
11						.9335	
12	.7095		.8215	.924	.7392	.7842	.7842
13		.7468					
15	.7095		.6722	.6838	.6283	.6161	.6535
18	.7095		.7842	.8131	.6468	.6722	.7842
20						1.0642	
21	1.1576		1.0829	1.0349	.9795	1.0642	1.1203
24	.9335	.9335		.8775	.7947	.7392	.8402
Max	1.2323	.9896	1.3443	1.1203	1.1088	1.1643	1.251
Min	.7095	.7468	.6722	.6838	.6283	.6161	.6535
Avg	.8915	.8900	.9410	.8884	.8039	.8516	.9056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283073 / SAKET RECEIVING STATION

Feeder No / Name : 207 / Mira bhayender pumping NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2772			
3	.4066				.4251	.3142	
6	.4066				.2957	.2957	
9	.3142	.2587		.2218	.2033	.2218	.2033
10			.2772				
11						.1848	
12	.2772	.2587	.2033	.2957	.2957		.2957
15	.2772		.2772	.3511	.3326	.2772	.2772
18	.2587		.2772	.2587	.2957	.2033	.2218
20						.2772	
21	.3696		.2402	.2957	.2218	.2743	.2772
24	.7023			.3142	.2033	.2218	.4066
Max	.7023	.2587	.2772	.3511	.4251	.3142	.4066
Min	.2587	.2587	.2033	.2218	.2033	.1848	.2033
Avg	.3766	.2587	.2550	.2878	.2842	.2523	.2803

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283089 / 22 KV VIKAS

Feeder No / Name : 201 / VIKAS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.6878						
12	1.0974	1.0387	.9145	.9694	1.1283	1.0136	1.0164
13				.9694			
24		.7316	.695	.695	.6219	.5853	.6219
Max	1.0974	1.0387	.9145	.9694	1.1283	1.0136	1.0164
Min	.6878	.7316	.695	.695	.6219	.5853	.6219
Avg	.8926	.8852	.8048	.8779	.8751	.7995	.8192

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283089 / 22 KV VIKAS

Feeder No / Name : 202 / K-VILLA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	1.1888	1.4266	1.5729	1.5912		1.4415	1.7556
24	1.39	1.2012	1.3306	1.4045	1.3169	1.1888	1.2803
Max	1.39	1.4266	1.5729	1.5912	1.3169	1.4415	1.7556
Min	1.1888	1.2012	1.3306	1.4045	1.3169	1.1888	1.2803
Avg	1.2894	1.3139	1.4518	1.4979	1.3169	1.3152	1.5180

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283089 / 22 KV VIKAS

Feeder No / Name : 205 / Ganraj

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	1.0136	.9465	1.6461		1.5043	1.4175	1.5546
24	.8048	.8048	1.0631	1.0387	1.0242	.9492	.8859
Max	1.0136	.9465	1.6461	1.0387	1.5043	1.4175	1.5546
Min	.8048	.8048	1.0631	1.0387	1.0242	.9492	.8859
Avg	.9092	.8757	1.3546	1.0387	1.2643	1.1834	1.2203

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283089 / 22 KV VIKAS

Feeder No / Name : 206 / SHETH DEVELOPERS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	.7545	.6348	1.5364	1.5364	1.5655	1.6804	1.6409
24	.8215	.811	1.1576	1.2803	1.134	1.1506	1.1203
Max	.8215	.811	1.5364	1.5364	1.5655	1.6804	1.6409
Min	.7545	.6348	1.1576	1.2803	1.134	1.1506	1.1203
Avg	.788	.7229	1.347	1.4084	1.3498	1.4155	1.3806

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 288058 / 220/22 kV MSETCL COLOUR CHEM

E

Feeder No / Name : 317 / 22 kv Simtool exp.

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 22 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	14-FEB-18
HR	Load (MW)
12	.2401
Max	.2401
Min	.2401
Avg	.2401

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283085 / TARANGAN S/STN

Feeder No / Name : 201 / Solanki Dham

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2384	1.2193	1.2384	1.105	1.0669	1.2384	1.105
2	1.1812	1.1431	1.1431	.9907	.9907	1.1431	1.0479
3	1.105	1.0288	1.1431	.9526	.9145	1.0479	.9526
4	1.0288	.9717	1.0479	.9145	.8764	1.0479	.8954
5	1.0669	.9907	1.0479	.9526	.8764	1.0479	.8764
6	1.1431	1.2384	1.0479	.9717	1.0288	1.0479	1.0288
7	1.2574	1.3336	1.1431	1.1431	1.2193	1.1431	1.1431
8	1.3336	1.3717	1.2384	1.2193	1.2574	1.3336	1.3717
9	1.2574	1.3336	1.2384	1.2574	1.2765	1.3336	1.1812
10	1.2765	1.3336	1.2384	1.3336	1.1812		1.2193
11	1.1431		1.0479	1.4098		1.2384	1.2384
12	1.1622		1.1431	1.3336	1.0479	1.0669	1.086
13	1.0669		1.0479	1.2765	.9526	1.0098	.9526
14	1.0288		1.0479	1.1241	.9526	.9335	.9717
15	.9717		.9526	.9526	.8573	.9145	.9526
16	.9526		.9526	.9526	.8573	.8573	.9145
17	1.0479	.9526	.9907	.9907	.9526	.9717	.9526
18	1.086	1.1431	1.2193	1.1431	1.0479	1.1622	1.0669
19	1.5623	1.5242	1.5242	1.467	1.4289	1.5051	1.5242
20	1.6575	1.6194	1.6004	1.6004	1.4289	1.5623	1.6385
21	1.6194	1.4289	1.6004	1.5623	1.4289	1.5623	1.6385
22	1.5432	1.4289	1.4861	1.5051	1.3336	1.448	1.5242
23	1.4098	1.3336	1.3717	1.3336	1.3336	1.2955	1.5432
24	1.3336	1.2955	1.2384	1.2574	1.1622	1.2384	1.2003
Max	1.6575	1.6194	1.6004	1.6004	1.4289	1.5623	1.6385
Min	.9526	.9526	.9526	.9145	.8573	.8573	.8764
Avg	1.2281	1.2606	1.1979	1.1979	1.1075	1.1804	1.1677

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728] BU 4728

Substation No/ Name :- 283085 / TARANGAN S/STN

Feeder No / Name : 202 / Navnirman

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18
HR	Load (MW)
1	1.1812
2	1.1431
3	1.086
4	1.0288
5	1.0479
6	1.1812
7	1.3717
8	1.467
9	1.3146
10	1.3336
11	1.3717
12	1.3908
13	1.2384
14	1.1622
15	1.086
24	1.2384
Max	1.467
Min	1.0288
Avg	1.2277

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283085 / TARANGAN S/STN

Feeder No / Name : 203 / Wimblon

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9433	1.9052	2.0957	1.7909	1.6766	1.8099	1.6766
2	1.8671	1.829	1.9052	1.6766	1.6004	1.7147	1.6004
3	1.7909	1.7147	1.9052	1.6004	1.5242	1.7147	1.5242
4	1.7147	1.6194	1.8099	1.5623	1.448	1.6194	1.5242
5	1.9052	1.6766	1.8099	1.6004	1.3717	1.6194	1.448
6	2.1338	2.1338	1.9052	1.8099	1.9052	1.7147	1.829
7	2.4768	2.3624	2.2481	1.9433	2.191		2.3243
8	2.6101	2.5911	2.2862	2.1719	2.2862	2.4768	2.3624
9	2.553	2.6673	2.3815	2.21	2.4768	2.572	2.553
10	2.8769	2.8578	2.572	2.5149	2.5911		2.6673
11	2.934		2.6673	2.4006		2.3815	2.8769
12	2.6673		2.2862	2.3243	2.3815	2.2862	2.4577
13	2.4196		2.0957	2.0957	2.191	2.0195	2.4006
14	2.3053		2.0957	2.1529	2.191	1.9243	2.3815
15	2.21		2.0957	1.8861	2.0957	1.8099	2.4006
16	2.3243		1.9052	1.8671	2.0957	1.7718	2.3243
17	2.3434	2.2862	2.0576	1.848	2.191	2.8197	2.2862
18	2.3815	2.4768	2.1719	2.0386	2.191	2.0767	2.3243
19	2.7435	2.6673	2.553	2.4196	2.572	2.4577	2.7054
20	2.7625	2.6673	2.5911	2.4006	2.4768	2.5149	2.7435
21	2.8387	2.7625	2.5911	2.4958	2.4768		2.8197
22	2.6863	2.572	2.4006	2.3815	2.3815	2.3243	2.553
23	2.3243	2.191	2.3243	2.0195	2.0957	2.1338	2.3053
24	1.9814	2.0195	2.0957	1.9052	1.7718	1.9052	1.7909
Max	2.934	2.8578	2.6673	2.5149	2.5911	2.8197	2.8769
Min	1.7147	1.6194	1.8099	1.5623	1.3717	1.6194	1.448
Avg	2.3664	2.2778	2.2021	2.0465	2.0949	2.0794	2.2450

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283085 / TARANGAN S/STN

Feeder No / Name : 206 / Pumping

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8002	.724	.7621	.6859	.6478	.6668	.5716
2	.7621	.6478	.6668	.6097	.6097	.5716	.5335
3	.724	.6097	.6668	.5716	.5716	.5716	.4954
4	.743	.5716	.6668	.5716	.5525	.5716	.4572
5	.724	.6097	.6668	.6097	.5716	.5716	.4572
6	.8573	.8383	.7621	.6478	.7621	.6668	.7621
7	1.0288	.9145		.7621	.9145	.8573	.9526
8	.9717	1.0288	.9526	.8764	.9145	.9526	.9717
9	.9907	1.0479	.9526	.8764	.9907	.9526	.9335
10	1.0288	1.0479	1.0479	.9335	1.0288		1.105
11	1.1812	1.0479	1.2384	1.0288		1.2193	1.1431
12	1.1812	1.0479	1.1431	.9907	1.0479	.9526	1.0669
13	1.1431	1.0479	1.0479	.9717	1.0479	.9526	1.0669
14	1.0669	1.0479	1.0479	.8954	1.0479	.8764	1.0288
15	.9907	.9526	.8573	.743	1.0479	.8383	.9907
16	1.0288	.9526	.8573	.724	.9526	.8002	.9907
17	1.0288	.9526	.9145	.7049	.9526	.8192	.9526
18	1.0288	1.0479	.9526	2.0386	.9526	.8954	.9907
19	1.2193	1.1431	1.0669	.9907	1.0479	1.1241	1.2574
20	1.1812	1.0479	1.1431	1.0288	1.0479	1.105	1.2193
21	1.2193	1.0479	1.0669	.9907	1.0479	1.0669	1.2193
22	1.105	1.0479	.9907	.9717	.9526	.9526	1.0669
23	.9526	.8573	.8383	.8573	.7621	.8383	.9907
24	.8383	.8002	.7621	.8002	.7049	.6668	.6478
Max	1.2193	1.1431	1.2384	2.0386	1.0479	1.2193	1.2574
Min	.724	.5716	.6668	.5716	.5525	.5716	.4572
Avg	.9915	.9201	.9162	.8701	.8772	.8474	.9113

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283085 / TARANGAN S/STN

Feeder No / Name : 305 / Mahavir-II

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9		.381	.1905		.1905		.1905
10	.1905	.381	.1905		.2286		.2286
11	.3048	.381	.3048	.1905		.3048	.3048
12	.3048	.381	.381	.1905	.381	.3048	.3048
13	.3048	.381	.3048	.2286	.381	.3048	.3048
14	.3048	.381	.381	.2286	.381	.3048	.3048
15	.3048	.3048	.3048	.1905	.381	.3048	.3048
16	.3048	.381	.3048	.1905	.381	.3048	.3048
17	.3048	.381	.3048	.1905	.381	.3048	.3048
18	.3048	.381	.3048	.1905	.381	.3048	.3048
19	.2286	.381	.2286	.1905	.381	.3048	.3048
20	.2286	.1905	.1905	.1905	.1905	.2286	.2286
21	.1905	.1905	.1905	.1905	.1905	.1905	.1905
22	.1905	.1905	.1905	.1905	.1905	.1905	.1905
23	.1905	.1905	.1905	.1905	.1905	.1905	.1905
24		.1905	.1905	.1905	.1905	.1905	.1905
Max	.3048	.381	.381	.2286	.381	.3048	.3048
Min	.1905	.1905	.1905	.1905	.1905	.1905	.1905
Avg	.2613	.3167	.2596	.1959	.2946	.2667	.2596

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283085 / TARANGAN S/STN

Feeder No / Name : 306 / Kalpataru-II

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.4191	.381	.381	.381	.381	.381
2	.3048	.3048	.2667	.2667	.3048	.2667	.3048
3	.2667	.3048	.2286	.2667	.2286	.2286	.2667
4	.2286	.3048	.2286	.2286	.2286	.2286	.2286
5	.2286	.2667	.1905	.2286	.2286	.2286	.2286
6	.2286	.2667	.1905	.1905	.1905	.2286	.2286
7	.2286	.2286	.1905	.2286	.2286	.2286	.2286
8	.2667	.2667	.2286	.2286	.2286	.2286	.2286
9	.9907	.9526	.9526	.9145	.9145	.9526	.4954
10	.9907	.9526	.9526	.9145	1.0669		1.0669
11	1.5623	1.5242	1.5242	1.6004		1.6004	1.6385
12	1.7528	1.7147	1.7147	1.7528	1.6385	1.7528	1.7909
13	1.7909	1.7147	1.7147	1.7909	1.6385	1.6766	1.829
14	1.7528	1.7147	1.7147	1.7528	1.6766	1.6385	1.829
15	1.7147	1.5242	1.7147	1.7909	1.6766	1.6385	1.829
16	1.6766	1.5242	1.7147	1.7147	1.6766	1.6385	1.829
17	1.6385	1.5242	1.7909	1.7147	1.6766	1.6004	1.7909
18	1.6766	1.6004	1.829	1.7909	1.6004	1.7147	1.7147
19	1.7528	1.6385	1.9433	1.8671	1.6385	1.7528	.3048
20	1.7528	1.6385	1.8671	1.9433	1.6004	1.7147	1.9052
21	1.7528	1.6385	1.829	1.9052	1.5242	1.6766	1.829
22	1.448	1.3717	1.6004	1.6004	1.1812	1.2955	1.5623
23	1.105	.9907	1.105	1.0288	.9526	.9526	1.1431
24	.4954	.5335	.4954	.5716	.4954	.5335	.4954
Max	1.7909	1.7147	1.9433	1.9433	1.6766	1.7528	1.9052
Min	.2286	.2286	.1905	.1905	.1905	.2286	.2286
Avg	1.0828	1.0383	1.0987	1.1114	.9990	1.0503	1.0479

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283091 / ETERNITY S/STN

Feeder No / Name : 201 / Kankia

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.3239	.3239	.3048	.2477	.3239	.2858
2	.3048	.3048	.3048	.2667	.2477	.3048	.2667
3	.2858	.2858	.3048	.2286	.2096	.3048	.2477
4	.2667	.2667	.2858	.2286	.2096	.2858	.2286
5	.2667	.2477	.3239	.2286	.2096	.2858	.2096
6	.2858	.2286	.2858	.2667	.2858	.2667	.2477
7	.3048	.2096	.3239	.2667	.3429	.2667	.2858
8	.3239	.2858	.3239	.3048		.3429	.3239
9	.4954	.5144	.4572	.3429	.5335	.4382	.4572
10	.6478	.6097	.5716	.4954	.6097	.4763	.5906
11	.6478	.6287	.5716	.4763	.6287	.6097	.6287
12	.5906	.6097	.5716	.4001	.6668	.5716	.5906
13	.6097	.6097	.6097	.381	.6097	.5906	.5906
14	.5906	.5906	.5525	.4191	.6478	.5144	.5906
15	.5716	.9907	.5144	.4191	.5525	.5335	.5716
16	.5335	.5335	.5335	.4191	.5906	.4763	.6478
17	.5716	.5906	.5335	.381	.5525	.5716	.6668
18	.4954	.5144	.4763	.381	.5335	.5335	.6287
19	.4954	.4763	.4572	.4191	.4572	.4954	.5335
20	.4763	.4763	.4572	.4382	.4191	.4191	.4572
21	.4382	.4001	.4191	.4191	.4001	.4001	.4382
22	.4001	.381	.4001	.362	.4191		.4191
23		.3429		.3429	.3429		
24	.3429		.3239	.3429	.3048	.3239	
Max	.6478	.9907	.6097	.4954	.6668	.6097	.6668
Min	.2667	.2096	.2858	.2286	.2096	.2667	.2096
Avg	.4465	.4531	.4316	.3556	.4357	.4243	.4503

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283091 / ETERNITY S/STN

Feeder No / Name : 202 / Sandipani

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9717	1.105	.9335	.9717	.9145	.9145	.9526
2	.9717	1.086	.8954	.9145	.7811	.8954	.9145
3	.9907	1.0479	.8954	.8002	.724	.8954	.8954
4	.9907	1.0288	.8573	.7811	.724	.8764	.8764
5	1.0098	.9526	.8192	.7811	.8002	.8573	.8573
6	1.0098	.9335	.8573	.8002	.8002	.8383	.8383
7	1.0288	.9717	.8573	.8192	.8383	.8383	.9145
8	1.0288	1.0479	.8954	.8573	1.0098	1.0479	.9717
9	1.086	1.0479	.9145	.8764	.9526	.9526	1.0098
10	.9717	1.0479	.9526	1.0098	.9907	1.0098	1.0098
11	1.0098	1.0098	.8764	1.0479	1.0288	.9717	.9907
12	.9907	.9145	1.0288	.9145	.8573	.8954	.9145
13	.9145	.9145	.8954	.9335	.8764	.8192	.9526
14	.9335	.8764	.8002	.8573	.8573	.7811	.9526
15	.9335	.8573	.8764	.7811	.8002	.8192	.8954
16	.8573	.9335	.8383	.8002	.8002	.8764	.9145
17	.8954	.8764	1.0669	.8002	.8383	.7811	1.0098
18	.9907	.9335	.9145	.8002	.8573	.8192	.9526
19	1.3336	1.2574	1.2574	1.2765	1.1812	1.2193	1.3146
20	1.3527	1.2003	1.3527	1.1622	1.2193	1.2765	1.3527
21	1.3146	1.2003		1.2003	1.2193	1.2193	1.3717
22		1.1431	1.2765	1.1622	1.1622		1.3336
23		1.1241		1.1812	1.0479		
24	1.0669		1.0098	1.0288	.9335	.9335	
Max	1.3527	1.2574	1.3527	1.2765	1.2193	1.2765	1.3717
Min	.8573	.8573	.8002	.7811	.724	.7811	.8383
Avg	1.0297	1.0222	.9578	.9399	.9256	.9335	1.0089

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283091 / ETERNITY S/STN

Feeder No / Name : 205 / Jay Tower

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0479	1.1431	1.0669	.9907	.9717	1.0098	1.0479
2	1.0288	1.105	1.0098	.9145	.9145	1.0288	.9717
3	1.0098	1.0288	.9717	.8002	.7811	1.0479	.9526
4	1.0098	.9907	.9717	.7811	.8002	1.0669	.9335
5	1.0288	.9526	.9335	.7621	.7811	1.086	1.0288
6	1.0479	.9335	1.0288	.8573	.9145	1.105	1.086
7	1.0669	1.0479	1.1241	.9145	1.1622	1.1241	1.2003
8	1.2193	1.3146	1.2193	1.0669	1.2574	1.2193	1.3146
9	1.1622	1.1622	1.1622	1.1812	1.2384	1.2384	1.2193
10	1.105	1.105	1.105	1.1241	1.1431	.9907	.9907
11	1.0479	1.105	1.1431	1.0669	1.105	1.0098	1.086
12	1.105	1.0098	1.086	1.1241	1.0669	1.0288	1.0669
13	.9907	.9907	1.0098	1.0288	.9526	.9335	.8954
14	1.1622	1.105	1.0669	1.086	1.0288	1.0288	.9717
15	1.0479	.9907	.9907	.9717	.9335	.8954	.8764
16	.9526	.9717	.9145	.9717	.8954	.8573	1.0098
17	1.0098	.9717	.8954	.8954	.8764	.8573	1.0288
18	1.0479	1.0288	1.0479	.9526	.9717	.8192	1.0288
19	1.3146	1.2574	1.2574	1.2384	1.2193	1.2193	1.3527
20	1.3336	1.2955	1.2765	1.2574	1.2765	1.2955	1.4098
21	1.448	1.4098	1.3527	1.3908	1.3336	1.3908	1.5432
22	1.3717	1.3527	1.0479	1.0098	1.0098		
23		1.2003		1.105	1.1431		
24	1.1622		1.105	1.105	1.0479	1.0098	
Max	1.448	1.4098	1.3527	1.3908	1.3336	1.3908	1.5432
Min	.9526	.9335	.8954	.7621	.7811	.8192	.8764
Avg	1.1183	1.1075	1.0777	1.0248	1.0344	1.0574	1.0959

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283094 / RAHEJA S/STN

Feeder No / Name : 201 / L.I.C. Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.5716	.5716	.5525	.5335	.5144	.5144
2	.5716	.5335	.5525	.5144	.5144	.4954	.5144
3	.5716	.4954	.5335	.4763	.4954	.4763	.4954
4	.4763	.4763	.5335	.4572	.4763	.4763	.4954
5	.5716	.4954	.4954	.4572	.4763	.4954	.5144
6	.5716	.5525	.5144	.4763	.4954	.5144	.5335
7	.6668	.6097	.5144	.4954	.6097	.5335	.5716
8	.6668	.6097	.6097	.5906	.5716	.5716	.6097
9	.743	.7049	.6097	.5716	.5716	.5716	.6668
10	.8954	.8002	.6859	.6859	.8383	.6668	.7621
11	.8954	.8764	.7621	.6478	.7621	.6668	.8573
12	.9526	.9145	.8192	.724	.8002	.7621	.9526
13	.8954	.9526	.8573	.743	.8192	.7621	.9526
14	.9145	.8573	.7621	.7049	.7621	.6668	.9526
15	.9526	.8764	.7621	.6478	.7621	.5906	.9526
16	.9145	.8573		.6478	.8002	.5906	.8954
17	.8383	.8383	.6478	.5716	.7811	.6097	.8764
18	.7621	.8383	.6668	.6097	.7621	.7049	.724
19	.8192	.7811	.6287	.724	.724	.743	.8764
20	.8383	.8002	.743	.8002	.743	.8002	.9526
21	.8764	.7811	.8192	.7621	.7811	.7811	.8764
22	.8383	.724	.724	.8002	.7621	.6859	
23	.7621	.6859	.6859	.724	.6859	.6668	.8002
24	.6668	.6668	.6668	.6097	.6097	.5716	.5716
Max	.9526	.9526	.8573	.8002	.8383	.8002	.9526
Min	.4763	.4763	.4954	.4572	.4763	.4763	.4954
Avg	.7597	.7208	.6594	.6248	.6724	.6216	.7356

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283094 / RAHEJA S/STN

Feeder No / Name : 202 / Gangotri

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0479	.9907	.9526	.9526	.8764	.9145
2		.9907	.9526	.8764	.9526	.8573	.8764
3		.9145	.9145	.8383	.9907	.8954	.8573
4		.8573	.9717	.8764	1.0288	.9526	
5		.9526	1.0479	.9145	1.105	.9907	1.0098
6		1.105	1.1812	.9526	1.1812	1.0479	1.086
7		1.2765	1.1812	1.0479	1.3336	1.1431	1.2003
8		1.4289	1.2384	1.2193	1.3717	1.3717	1.3336
9		1.467	1.3717	1.2574	1.4289	1.3336	1.4289
10		1.5623	1.467	1.4289	1.3717	1.4289	1.3336
11		1.3336	1.4098	1.5242	1.3336	1.3336	1.3336
12		1.2384	1.2765	1.2955	1.1812	1.2384	1.1431
13		1.1812	1.1812	1.2193	1.105	1.0479	1.1431
14		1.1431	1.0669	1.1431	1.0669	.9526	1.1431
15		1.105	1.0479	1.105		.9145	1.0479
16	1.0669	.9907		1.0288	1.0098	.9145	1.0098
17	1.1812	.9907	1.105	1.0669	1.0098	1.086	1.1241
18	1.1622	1.1241	1.1431	1.0479	1.0669	1.1431	1.2003
19	1.5623	1.448	1.5051	1.4861	1.4289	1.467	1.6385
20	1.5623	1.5623	1.5051	1.448	1.4861	1.5051	1.6004
21	1.5623	1.448	1.467	1.4098	1.3908	1.448	1.6194
22	1.5242	1.3717	1.448	1.3717	1.3717	1.2765	.8573
23	1.4289	1.1812	1.3336	1.2955	1.2384	1.1812	1.4289
24		1.2003	1.1431	1.1431	1.105	1.0479	1.0669
Max	1.5623	1.5623	1.5051	1.5242	1.4861	1.5051	1.6385
Min	1.0669	.8573	.9145	.8383	.9526	.8573	.8573
Avg	1.3813	1.2050	1.2152	1.1646	1.1961	1.1439	1.1912

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283094 / RAHEJA S/STN

Feeder No / Name : 203 / Tip-Top Plaza

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.4191	.3048	.2858	.2477	.2477	.2858
2	.2858	.4382	.3048	.2667	.2286	.2477	.2667
3	.2858	.381	.2858	.2667	.2286	.2286	.2667
4	.2858	.3429	.2858	.2477	.2096	.2286	.2477
5	.2858	.4191	.2667	.2477	.2096	.2477	.2477
6	.2858	.5144	.2667	.2477	.2286	.2477	.2858
7	.2858	.6287	.2667	.3239	.2667	.2667	.3239
8	.5716	.7621	.3048	.8192	.3429	.5335	.4001
9	.7621	1.0288	.4001	.7049	.5716	.5716	.6668
10	.7621	1.105	.4572	.7621	.6668	.5716	.8573
11	.8573	1.105	.5335	.743	.6478	.6668	.8573
12	.9526	1.2003	.5144	.8002	.6668	.6668	.8573
13	.9717	1.2193	.5144	.8764	.6668	.6668	1.0479
14	.9526	1.1812	.4954	.8954	.7049	.6668	1.0479
15	.9145	1.1431	.5144	.8764	.6668	.7621	1.0479
16	.9907	.9717		.5335	.6287	.8002	.9526
17	.9526	.8573	.4763	.4954	.5906	.7049	.8764
18	.8383	.8764	.5144	.5335	.4954	.6859	.8002
19	.9335	.7811	.5716	.6478	.5335	.6478	.7811
20	.8002	.7811	.6097	.7049	.4191	.5335	.5716
21	.7621	.724	.6097	.6859	.381	.4763	.4001
22	.7621	.6097	.6097	.6097	.3429	.3429	.381
23	.6668	.5335	.5525	.381	.3239	.3048	.3429
24	.2858	.6097	.381	.4572	.3429	.2667	.2858
Max	.9907	1.2193	.6097	.8954	.7049	.8002	1.0479
Min	.2858	.3429	.2667	.2477	.2096	.2286	.2477
Avg	.6557	.7764	.4365	.5589	.4422	.4827	.5874

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283094 / RAHEJA S/STN

Feeder No / Name : 204 / Anand Timber

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.5716		.4572	.4191	.4572	.4572
2	.5716	.5144	.4954	.4191	.381	.4382	.4572
3	.4763	.4572	.4763	.4001	.3429	.4382	.4763
4	.381	.4382	.4954	.4001	.3429	.4191	.4572
5	.4763	.4572	.4572	.4001	.381	.4191	.4954
6	.4763	.4763	.4763	.4572	.4191	.4382	.5335
7	.4763	.4954	.4763	.4191	.4572	.4572	.5335
8	.5716	.5716	.4954	.4572	.4954	.4954	.5525
9	.5906	.6668	.5716	.5144	.5716	.5716	.5716
10	.8002	.8002	.7621	.5525	.6668	.6668	.7621
11	.8573	.724	.7621	.6478	.7621	.7621	.7621
12	.8002	.8002	.6668	.5906	.6668	.7621	.6668
13	.6097	.6668	.5525	.5335	.5335	.5716	.6668
14	.7049	.6097	.6097	.4763	.6668	.5716	.6668
15	.6668	.6668	.5906	.381	.6668	.5906	.6668
16	.724	.6668		.4191	.6859	.5906	.6859
17	.6859	.6478	.5716	.3429	.6097	.5525	.6859
18	.6859	.6859	.7049	.362	.6287	.6287	.7811
19	.7811	.7621	.6859	.4954	.8002	.7049	.8002
20	.7621	.7049	.6668	.5335	.7049	.6097	.743
21	.7621	.6287	.6478	.5716	.6478	.5906	.6478
22	.724	.6097	.6097	.5716	.6097	.5716	.6668
23	.6478	.6097	.5906	.5716	.5906	.5335	.6668
24	.5716	.6478	.5335	.5144	.4763	.5144	.5335
Max	.8573	.8002	.7621	.6478	.8002	.7621	.8002
Min	.381	.4382	.4572	.3429	.3429	.4191	.4572
Avg	.6406	.6200	.5863	.4787	.5636	.5565	.6224

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283094 / RAHEJA S/STN

Feeder No / Name : 205 / A.C.C.-II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	.8764	.8764	.8573	.8764	.8002	.7621
2	.8573	.8573	.8573	.8192	.8573	.7621	.7621
3	.8573	.8383	.8573	.7811	.8383	.7621	.7621
4	.8573	.8002	.4954	.7621	.8764	.8002	.8002
5	.7621	.8573	.9717	.8002	.9145	.8573	.8954
6	1.0479	.9907	1.0479	.8573	.9526	.9335	1.0098
7	1.2384	1.1812	1.0479	.9717	1.105	1.0288	1.1812
8	1.2384	1.2574	1.0669	1.1812	1.2193	1.3717	1.4098
9	1.2955	1.2384	1.3527	1.2574	1.448	1.3336	1.3336
10	1.1622	1.4289	1.4289	1.1812	1.1812	1.4289	
11	1.2384	1.4861	1.4861	1.5242	1.1622	1.1431	1.4289
12	1.2384	1.2003	1.2955	1.2193	1.1431	1.1431	1.3336
13	1.1431	1.1431	.9717	1.2574	.9717	.9526	1.1431
14	1.0479	1.0098	.9907	1.2003	1.2384	1.0479	1.1431
15	1.0669	1.0479	1.1431	.7811	1.0098	.9145	1.0479
16	1.0288	1.0098		1.0288	.9335	.8002	1.2003
17	1.0288	1.1622	1.1241	.7621	.9145	.8764	1.0479
18	1.0479	1.086	1.1431	.9526	.9717	1.2193	1.1812
19	1.467	1.448	1.5623	1.3717	1.3908	1.4098	1.4289
20	1.5051	1.3717	1.4098	1.3908	1.3336	1.4098	1.5051
21	1.467	1.5813	1.4289	1.3336	1.3336	1.3336	1.6385
22	1.2574	1.2384	1.1812	1.3717	1.1812	1.2003	1.3336
23	1.1431	1.1812	1.0669	1.0479	1.0098	1.1431	1.1431
24	1.0479	.9907	.9526	.9335	.9907	.7811	.9526
Max	1.5051	1.5813	1.5623	1.5242	1.448	1.4289	1.6385
Min	.7621	.8002	.4954	.7621	.8383	.7621	.7621
Avg	1.1249	1.1368	1.1199	1.0685	1.0772	1.0606	1.1497

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283094 / RAHEJA S/STN

Feeder No / Name : 206 / Raheja

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	1.0288	.9907	1.0479	.8764	.9526	.8002
2	.9526	.9907	.9907	.8764	.8764	.8954	.8002
3	.8573		.9526	.7621	.9145	.8573	.8383
4	.8573	.8383	.9145	.724	.9526	.8764	.8764
5	.8573	.9526	1.0669	.8764	.9907	.9526	.9145
6	.9526	1.0479	1.1431	.8954	1.0479	1.0479	.9526
7	1.2384	1.4098	1.1431	.9526	1.3717	1.1431	1.2574
8	1.4861	1.3336	1.2574	1.1812	1.3336	1.2574	1.3717
9	1.467	1.3717	1.3336	1.2574	1.2384	1.4289	1.3336
10	1.5242	1.4289	1.4289	1.4289	1.448	1.4289	1.4289
11	1.3717	1.4289	1.4289	1.6194	1.2574	.4763	1.4289
12	1.3336	1.3717	1.4289	1.5242	1.2765	1.4289	1.3336
13	1.2384	1.2574	1.2765	1.3717	1.2384	1.1431	1.3336
14	1.1431	1.0669	1.1812	1.0288	1.1431	1.1431	1.3336
15	1.2384	1.1622	1.2574	1.1812	1.1431	1.0669	1.2384
16	1.1812	1.1622		1.0288	1.1241	.9526	1.2193
17	1.1812	1.1431	1.1431	1.086	1.1431	1.105	1.1812
18	1.1812	1.2193	1.2384	1.1431	1.1431	1.2193	1.2765
19	1.5813	1.5813	1.5242	1.4861	1.4861	1.4098	1.5242
20	1.6004	1.448	1.467	1.4861	1.4861	1.448	1.5623
21	1.5813	1.4098	1.4289	1.4861	1.4098	1.4289	1.5432
22	1.4861	1.3336	1.3717	1.4098	1.3717	1.2574	1.4289
23	1.3908	1.2955	1.3146	1.2384	1.0288	1.1812	1.2955
24	1.1431	1.1812	1.0669	1.1622	1.0479		1.0669
Max	1.6004	1.5813	1.5242	1.6194	1.4861	1.448	1.5623
Min	.8573	.8383	.9145	.724	.8764	.4763	.8002
Avg	1.2416	1.2375	1.2326	1.1773	1.1812	1.1348	1.2225

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283094 / RAHEJA S/STN

Feeder No / Name : 207 / Nitin Casting

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0479	.9907	.9907	.9526	.9145	.9145	.8764
2	1.0479	1.0288	.9526	.9145	.8764	.8764	.8573
3	.9526	.8954	.9145	.8764	.9145	.8573	.8002
4	.8573	.8573	.9526	.8002	.9526	.8954	.9526
5	.9526	.9526	1.0288	.8383	.9907	.9907	.9907
6	.9526	1.0669	1.1431		1.0098	1.0669	1.0669
7	1.3336	1.2955	1.1431	1.1241	1.2574	1.1431	1.2193
8	1.4289	1.3717	1.2574	1.2384	1.4289	1.3717	1.4289
9	1.6766	1.5432	1.4098	1.4289	1.5242	1.5242	1.5242
10	2.3815	1.8099	1.6575	1.6004	2.0005	1.5242	1.6194
11	2.4768	1.9433	1.9052	1.7337	2.4006	1.5242	1.9052
12	1.9052	1.9052	1.848	1.7718	1.7528	1.6194	1.8099
13	1.9052	1.6575	1.7147	1.6766	1.6194	1.5242	1.7147
14	2.3243	1.6766	1.7147	1.5242	2.0957	1.4289	1.7147
15	2.21	1.6194	1.7718	1.3908	1.5242	1.3908	1.7147
16	1.7337	1.6385		1.1812	1.467	1.3527	1.7147
17	1.6004	1.5813	1.5813	1.1431	1.5242	1.3527	1.6766
18	1.6004	1.6194	1.7147	1.2384	1.448	1.3908	1.7147
19	1.8671	1.848	1.8671	1.5242	1.6956	1.6575	1.8861
20	1.7718	1.7147	1.7528	1.5813	1.6004	1.6956	1.848
21	1.8099	1.6766	1.829	1.5623	1.7147	1.6194	1.8671
22	1.7147	1.6194	1.7337	1.6004	1.4861	1.5813	1.8099
23	1.467	1.3717	1.3146	1.3336	1.3336	1.4861	1.4861
24	1.2384	1.1812	1.1812	1.2193	1.0479	1.0669	1.0669
Max	2.4768	1.9433	1.9052	1.7718	2.4006	1.6956	1.9052
Min	.8573	.8573	.9145	.8002	.8764	.8573	.8002
Avg	1.5940	1.4527	1.4513	1.3154	1.4408	1.3273	1.4694

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283094 / RAHEJA S/STN

Feeder No / Name : 208 / SITAVIHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4768	2.3624	2.4387	2.4387	.9907	2.4006	2.2291
2	2.4768	2.3243	2.3243	2.2862	.9526	2.3434	2.21
3	2.2862	2.2862	2.2481	2.2291	.9145	2.2481	2.2481
4	2.191	2.2862	2.21	2.21	.9907	2.21	2.2862
5	2.191	2.3624	2.2481	2.21	.9526	2.1338	2.2862
6	2.191	2.21	2.0957	2.0195	.9526	2.0957	2.3624
7	2.191	2.2481	2.0957	1.1622	1.6194	1.9814	2.4387
8	2.6673	2.5339	2.3624	1.2003	2.4768	2.4768	2.6101
9	2.8578	2.8578	2.7054	1.2384	2.8578	2.572	2.7625
10	3.0483	2.8578	2.7054	1.5242	2.9531	2.6673	2.9531
11	3.1436	2.8959	2.7054	1.3336	2.9531	2.7625	3.0483
12	3.1436	2.8578	2.5911	1.105	2.8578	2.7625	3.1436
13	3.0674	2.6673	2.7054	1.0479	2.8578	2.6673	2.9531
14	3.0483	2.8578		1.0098	2.8959	2.572	2.9531
15	2.8578	2.7625	2.572	.9526	2.4768	2.7054	2.6673
16	3.1436	3.0102		.9526	2.915	2.7435	3.0102
17	2.8769	2.8769	2.7244	.9526	3.0293	2.8578	2.9912
18	2.915	2.9531	2.8006	.9526	2.7816	2.6482	3.0102
19	3.0102	2.8578	2.7816	.9907	2.8769	2.7625	3.0102
20	2.7816	2.7244	2.7625	1.0669	2.6101	2.572	2.6101
21	2.7435	2.6292	2.6101	1.1431	2.7435	2.4387	2.8006
22	2.5911	2.4768	2.553	1.0098	2.4768	2.4196	2.572
23	2.4768	2.2862	2.3815	.9526	2.2862	2.2862	2.2862
24	2.572	2.4768	2.3815	2.4387	.9526	2.4768	2.2672
Max	3.1436	3.0102	2.8006	2.4387	3.0293	2.8578	3.1436
Min	2.191	2.21	2.0957	.9526	.9145	1.9814	2.21
Avg	2.7062	2.6109	2.5001	1.4345	2.1823	2.4918	2.6546

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

KISAN NAGAR[540]

BU 4540

Substation No/ Name :- 283100 / KISAN NAGAR

Feeder No / Name : 201 / Sub-Station No.6

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6535	.6161	.6535	.7655	.7842	.6348	.7468
2		.5601	.6348	.7095	.7468	.5788	.6722
3	.5788	.5415	.6161	.6161	.6348	.5415	.5975
4	.6161	.5975	.5788	.5601	.5975	.5601	.5601
5	.6161	.5975	.5975	.5788	.5975	.5601	.5975
6	.6535	.6535	.6348	.5975	.6722	.5601	.6348
7	.7282	.6908	.7095	.6908	.8215	.6722	.7842
8	.8775	.8775	.8962	.8589	.9335	.8215	.9335
9	.9522	1.1016	.9522	.9522	.9335	.8775	1.0269
10	1.0082	.9709	1.0082	.9335	1.0082	.9709	1.0082
11	1.0269	.9149	.9896	1.0269	1.0082	1.0082	1.0082
12	1.1016	.8962	1.1016	.9335	.9896	.9149	1.0456
13	.8402	.8962	1.0269	.8775	.8589	1.1949	.8962
14	.8962	.8775	.9149	.8775	.8589	.9149	.9335
15	.8589	.8962	.8962	.8775	.8962		.9709
16	.8589	.8589	.8215	.6722	.8589	.8402	.9335
17	.8589	.7655	.8029	.7095	.8775	.9149	.9335
18	.8962	.8029	.9522	.8775	.8962	.9335	.8688
19	.9709	1.0082	1.0082	.9522	1.0082	1.0082	1.0642
20	1.0269	.9896	1.0082	.9335	.9896	.9896	1.0456
21	1.0456	.9896	.9709	.9709	.9709	1.0082	1.0456
22	.9709	.9709	.9709	.9335	.9335	.9709	1.0082
23	.8775	.8775	.8962	.8402	.8589	.8402	.9149
24	.7282	.7095	.7842		.8962	.7095	.7842
Max	1.1016	1.1016	1.1016	1.0269	1.0082	1.1949	1.0642
Min	.5788	.5415	.5788	.5601	.5975	.5415	.5601
Avg	.8540	.8192	.8511	.8150	.8596	.8272	.8756

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

KISAN NAGAR[540]

BU 4540

Substation No/ Name :- 283100 / KISAN NAGAR

Feeder No / Name : 203 / Nair Hotel

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5684	1.643	1.4563	1.4937	1.5684	1.2323	1.3443
2	1.4937	1.419	1.3443	1.419	1.4937	1.1763	1.2696
3	1.3443	1.363	1.251	1.2136	1.419	1.1016	1.1949
4	1.363	1.3817	1.2136	1.2883	1.1576	1.0829	1.1203
5	1.3817	1.4003	1.2696	1.2883	1.1949	1.1576	1.2323
6	1.5123	1.5123	1.307	1.2696	1.251	1.2323	1.3443
7	1.6617	1.587	1.419	1.3443	1.3443	1.2323	1.3817
8	1.6991	1.6617	1.5684	1.4563	1.5497	1.5684	1.5123
9	1.8858	2.1098	1.7737	1.6617	1.6804	1.6244	1.7364
10	2.0538	1.9791	1.9605	1.8858	1.7177	1.7177	1.7177
11	2.2218	1.9231	1.6057	1.8298	1.7177	1.6804	1.6617
12	2.1472	1.7924	1.6991	1.7924	1.9231	1.6244	1.643
13	1.9231	1.6804	1.4003	1.5497	1.5684	1.7177	1.475
14	1.9044	1.9231	1.8111	1.587	1.531	1.475	1.5497
15	1.8671	1.643	1.6057	1.531	1.4563	1.363	1.475
16	1.8298	1.6057	1.587		1.3817	1.307	1.419
17	1.8298	1.5497	1.6244	1.0829	1.5123	1.2883	1.475
18	1.8671	1.587	1.8484	1.5684	1.5684	1.531	1.6244
19	2.2405	1.9418	2.1285	1.8858	1.8671	1.8298	1.9605
20	2.2218	1.9605	2.2965	1.7924	1.8858	1.8858	2.0351
21	2.2405	1.9605	1.9791	1.8671	1.8298	2.0911	2.0911
22	2.1472	1.9418	1.9231	1.8298	1.8298	1.8298	1.9978
23	1.9605	1.7737	1.7551	1.6617	1.6057	1.587	1.8671
24	1.9231	1.7177	1.6244	1.5497	1.6057	1.419	1.419
Max	2.2405	2.1098	2.2965	1.8858	1.9231	2.0911	2.0911
Min	1.3443	1.363	1.2136	1.0829	1.1576	1.0829	1.1203
Avg	1.8453	1.7107	1.6438	1.5586	1.5691	1.4898	1.5645

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

KISAN NAGAR[540]

BU 4540

Substation No/ Name :- 283100 / KISAN NAGAR

Feeder No / Name : 204 / Administrative Bldg.

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7682	.7499	.695	.695	.6219	.6584	.695
2	.7316	.6036	.6584	.6036	.5487	.6036	.6584
3	.6219	.5304	.6219	.567	.5121	.5487	.5487
4	.6401	.5853	.6036	.5304	.5853	.567	.5853
5	.5853	.6036	.567	.5304	.6219	.5487	.5853
6	.7133	.7133	.6036	.5487	.6584	.5487	.6401
7	.7682	.7682	.6767	.6584	.6767	.6401	.7865
8	.7865	.7682	.7316	.7133	.7682	.7499	.7133
9	.9145	.9328	.823	.7499	.9145	.9694	.9145
10	.9877	1.0059	.9145	.8048	.9511	.9511	.8962
11	.9877	1.0059	.8962	.7682	.8962	.9328	.9328
12	1.0059	.9145	.8779	.7133	.8413	.823	.823
13	.8962	.9328	.7499	.6401	.8048	.7682	.7682
14	.9145	.823	.695	.6584	.7682	.7682	.7865
15	.8413	.8048	.6767	.5487	.7316	.7133	.8413
16	.823	.7682		.5304	.7499	.695	.7865
17	.8596	.8596	.695	.5304	.7865	.6767	.8048
18	.7865	.823	.7499	.6219	.7682	.8048	.8048
19	.9694	.9511	.8048	.7316	.8962	.9328	.9511
20	.9877	.9694	.8596	.823	.9145	.8779	.9511
21	1.0059	.9145	.8596	.8413	.9145	.9328	.9328
22	.9694	.8596	.823	.8048	.8962	.8779	.9694
23	.8779	.8779	.7682	.7499	.8048	.8048	.8962
24	.8596	.8048	.7499	.7316	.6767	.7316	.7499
Max	1.0059	1.0059	.9145	.8413	.9511	.9694	.9694
Min	.5853	.5304	.567	.5304	.5121	.5487	.5487
Avg	.8459	.8154	.7435	.6706	.7629	.7552	.7926

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

KISAN NAGAR[540]

BU 4540

Substation No/ Name :- 283100 / KISAN NAGAR

Feeder No / Name : 205 / Kalibai

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2033	.2218	.1663	.2218	.2218	.1109	.2218
2	.1663	.1848	.1478	.1829	.1848	.1109	.1848
3	.1294	.1294	.1294	.1829	.1109	.1294	.1478
4	.1294	.1294	.0924	.1646	.1109	.1294	.1109
5	.1663	.1478	.1109	.1294	.1478	.1294	.1848
6	.1663	.1848	.1663	.1478	.1478	.1478	.2218
7		.2587	.2587	.2218	.2772	.1478	.2957
8	.3142	.3326	.2957	.2772	.2957	.2957	
9	.2957	.3142	.2957	.2957	.3511	.3142	.2957
10	.3326	.3326	.2957	.2957	.2957	.3142	.2957
11	.3142	.2957	.2957	.2957	.2772	.2957	.3142
12	.2957	.2957	.2957	.2033	.2957	.2957	.2957
13	.2218	.9425	.2033	.3326	.2033	.2218	.2772
14	.2957	.2587	.1848	.2772	.2587	.2957	.2402
15	.2402	.2402	.2772	.1848	.2772	.2218	.2218
16	.2587	.2402	.2402	.1663	.2402	.2402	.2402
17	.2218	.2772	.2033	.1848	.2218	.2218	.2218
18	.2957	.2957	.1848	.1848	.2218	.2957	.2402
19	.3142	.2402	.2587	.2957	.2957	.2218	.2772
20	.3511	.3326	.3511	.3326	.3511	.3142	.3326
21	.3326	.3326	.3142	.2957	.3142	.2957	.3142
22	.3142	.3142	.3142	.3142	.2957	.2957	.2957
23	.2957	.2957	.2772	.2772	.2772	.2957	.2772
24	.2772	.2587	.2218	.2402	.2587	.2218	.2587
Max	.3511	.9425	.3511	.3326	.3511	.3142	.3326
Min	.1294	.1294	.0924	.1294	.1109	.1109	.1109
Avg	.2579	.2857	.2325	.2377	.2472	.2318	.2507

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

KISAN NAGAR[540]

BU 4540

Substation No/ Name :- 283100 / KISAN NAGAR

Feeder No / Name : 206 / Old Modella

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.6344	.6001	.6173	.583	.583	.6173
2	.5658	.5316	.583	.5658	.5487	.5658	.5487
3	.5487	.4801	.5658	.4801	.5144	.5658	.5144
4	.583	.5144	.5144		.5144	.5487	.5144
5	.583	.5487	.5316		.5487	.5316	.5487
6	.6173	.6001	.5487	.583	.6001	.5487	.5658
7	.703		.6344	.6344	.6173	.583	.6344
8	.7202	.703	.6173	.6344	.6516	.703	.6687
9	.7202	.7716	.8745	.8402	.7716	.7888	.8573
10	.9602	.8402	.9088	.8745	.9259	.9088	.8916
11	.9774	.8402	.9259	.8916	.8916	.9088	.8745
12	.9431	.7888	.9088	.8916	.8745	.8745	.8916
13	.8059	.7373	.823	.7373	.7716	.823	.6859
14	.823	.703	.9149	.7545	.7888	.7202	.5716
15	.7716	.7373	.7373	.7545	.703		.823
16	.8059	.7373		.7716	.7545	.7545	.7888
17	.8402	.6859	.823	.7716	.7716	.6687	.8402
18	.8745	.703	.8402	.7545	.823	.6859	.8402
19	1.0288	.8402	.9088	.8573	.9088	.8402	.9431
20	.9774	.8059	.8916	.8745	.9088	.8402	.9259
21	.8402	.7888	.8573	.8573	.8059	.7716	.823
22	.823	.7545	.7716	.7545	.7373	.7545	.8402
23	.7716	.6687	.6859	.6859	.6687	.6516	.7373
24	.6687	.6687	.6344	.6516	.6173	.6173	.6344
Max	1.0288	.8402	.9259	.8916	.9259	.9088	.9431
Min	.5487	.4801	.5144	.4801	.5144	.5316	.5144
Avg	.7730	.6993	.7435	.7381	.7209	.7060	.7325

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

KOPRI S/DN.[655]

BU 4655

Substation No/ Name :- 283074 / WALMIKI S/S

Feeder No / Name : 203 / Walmiki

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.5415	.5601	.5415	.5601	.5041	.5041
2	.5415	.5228	.4854	.5041	.4668	.4854	.4854
3	.5041	.5228	.4668	.4668	.4668	.4668	.4668
4		.4854	.4854		.4854	.4481	
5		.5601	.5228		.4854	.5228	
6	.6722	.6722	.6161	.5228	.6348	.6348	.6535
7	.8589	.7655	.6535	.5601	.6535	.7095	.7655
8	.7842	.8402	.6722	.6348	.6722	.6722	.7095
9	.8029	.7468	.8029	.6722	.6722	.7282	
10	.7468	.7842		.7095	.6908	.7095	.7282
11	.7095	.6348	.6535	.6908	.5601	.5601	.7468
12	.5601		.6348	.6722	.5975	.4854	.6722
13		.5601		.5788	.5601	.4668	.6348
14	.5975	.5228		.5788		.4108	.5975
15	.5601	.5041	.4668	.4668	.4294	.3734	.5788
16	.5415	.4294	.4854	.4481	.4481	.3547	.5041
17	.5041	.4108	.5041	.4854	.4668	.3547	.5249
18	.5788	.5975	.5975	.4668	.4668	.5415	.5415
19	.7842	.7095	.6908	.6722	.6722	.7468	.7282
20	.7842	.7095	.7842	.6908	.7468	.7095	.7842
21	.7095	.6722	.7282	.6535	.6535		.7282
22	.6908	.6535	.6535	.6161	.6348	.6348	.6722
23	.6535	.6161	.6348	.6348	.6161	.6161	.6348
24		.5975	.5975	.6161	.5788	.5601	.5975
Max	.8589	.8402	.8029	.7095	.7468	.7468	.7842
Min	.5041	.4108	.4668	.4481	.4294	.3547	.4668
Avg	.6572	.6113	.6046	.5856	.5747	.5520	.6314

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

KOPRI S/DN.[655]

BU 4655

Substation No/ Name :- 283074 / WALMIKI S/S

Feeder No / Name : 204 / Devika

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7282	.6908	.6722	.7095		.5975	.6161
2	.6722	.6161	.6161	.6161	.5975	.5601	.5788
3	.6535	.6348	.5975	.5788	.5975	.5415	.5601
4		.6161	.5975		.5788	.5415	
5		.7468	.6348		.5975	.6161	
6	.8962	.8589	.7655	.6348	.7468	.7095	.7842
7	1.1576	1.1203	1.0269	.8215	1.0082	.9896	1.0829
8	1.2136	1.2136	.9709	.9709	1.2136	1.0642	1.1949
9	1.251	1.2323	1.1203	.9709	1.1576	1.1576	
10	.9335	1.0456		1.1016	1.0456	1.0642	.9896
11	.9522	.9709	.9335	1.0269	.8029	.9522	.8775
12	.8215		.8402	.9522	.8215	.8402	.8029
13		.7842		.8589	.7655	.7468	.7655
14	.7468	.7468		.7655		.6722	.7468
15	.6908	.6161	.6535	.7282	.6348	.6348	.6722
16	.6722	.6161	.6535	.6722	.5601	.6161	.6535
17	.6348	.6348	.6722	.6535	.5415	.5975	.6535
18	.7842	.6908	.8402	.7842	.6722	.8215	.8029
19	1.1389	1.0456	1.0829	1.0456	1.0269	1.1016	1.1763
20	1.1949	1.1016	1.2136	1.2323	1.2136	1.1949	1.2696
21	1.1576	1.0456	1.1389	1.1389	1.1576		1.1949
22	1.1576	.9709	.9896	.9709	.9522	.9709	1.0829
23	.9522	.8589	.9522	.9149	.9149	.8775	.9522
24		.8589	.7468	.7842	.7842	.6908	.7468
Max	1.251	1.2323	1.2136	1.2323	1.2136	1.1949	1.2696
Min	.6348	.6161	.5975	.5788	.5415	.5415	.5601
Avg	.9205	.8572	.8438	.8606	.8360	.8069	.8669

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

KOPRI S/DN.[655]

BU 4655

Substation No/ Name :- 283074 / WALMIKI S/S

Feeder No / Name : 205 / Puranik

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0829	.9896	1.0456	.9709	.9335	.9149	.9335
2	1.0082	.9709	.9335	.8962	.8775	.8589	.8775
3	.9335	.9149	.8775	.8589	.8589	.8215	.8402
4		.9149	.8775		.8029	.7842	
5		.9896	.8775		.8215	.9149	
6	1.1763	1.1576	1.0269	.9896	1.0269	1.0269	1.1203
7	1.4937	1.419	1.2136	1.1016	1.2696	1.251	1.307
8	1.531	1.4563	1.2696	1.1576	1.4377	1.363	1.4003
9	1.6057	1.5123	1.4377	1.363	1.4563	1.4003	
10	1.475	1.3443		1.4563	1.4563	1.5684	1.5123
11	1.5497	1.1389	1.4937	1.587	1.2883	1.363	1.4563
12	1.4563		1.419	1.4377	1.307	1.3256	1.363
13				1.4003	1.2323	1.1576	1.2696
14	1.2136	1.3256		1.2883		1.1016	1.0269
15	1.1576	1.1576	1.1016	1.1389	1.0642	1.0269	.9149
16	1.1576	1.1203	1.1016	.5041	1.0269	.9709	1.1016
17	1.1203	1.0829	1.1016	1.0269	.9709	1.0269	1.2323
18	1.2323	1.2323	1.2883	1.1389	1.1576	1.1949	1.307
19	1.6244	1.6057	1.6617	1.475	1.4377	1.6057	1.643
20	1.6057	1.6244	1.6804	1.5123	1.5497	1.6057	1.6617
21	1.6244	1.5497	1.531	1.4377	1.4377		1.643
22	1.4377	1.4563	1.363	1.307	1.363	1.307	1.531
23	1.3443	1.3443	1.2696	1.2136	1.1763	1.2136	1.3817
24		1.1949	1.0829	1.1016	1.1016	1.0456	1.1203
Max	1.6244	1.6244	1.6804	1.587	1.5497	1.6057	1.6617
Min	.9335	.9149	.8775	.5041	.8029	.7842	.8402
Avg	1.3415	1.2501	1.2216	1.1983	1.1763	1.1673	1.2687

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

KOPRI S/DN.[655]

BU 4655

Substation No/ Name :- 283074 / WALMIKI S/S

Feeder No / Name : 206 / Gautam Tower

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0642	1.0269	1.0456	.9335	.9522	.9149	.9149
2	1.0082	1.0829	.9335	.8775	.8589	.8402	.8589
3	.9335	.9522	.8775	.8589	.8775	.8589	.8402
4		.9149	.8589		.8215	.8029	
5		.8916	.8962		.8589	.8962	
6	1.0456	1.0829	.9896	.9149	.9709	1.0456	1.0269
7	1.2323	1.2696	1.1949	.9335	1.2136	1.1576	1.2323
8	1.307	1.2696	1.1389	1.0082	1.307	1.1016	1.251
9	1.307	1.251	1.2696	1.1763	1.307	1.2136	
10	1.4003	1.419		1.2696	1.3443	1.2883	1.363
11	1.475	1.4377	1.363	1.2136	1.363	1.3256	1.5123
12	1.419		1.3443	1.2696	1.3817	1.2883	1.4937
13		1.3443		1.2323	1.2696	1.1576	1.3817
14	1.307	1.307		1.2323		1.1016	1.307
15	1.1949	1.251	1.1203	1.0642	1.1576	1.0082	1.2323
16	1.1949	1.1576	1.1203	.9709	1.1203	.9896	1.1576
17	1.1576	1.1203	1.1763	.9896	1.0829	1.0269	1.2323
18	1.2696	1.2696	1.2323	1.1763	1.1576	1.1949	1.307
19	1.6804	1.5684	1.5497	1.4003	1.419	1.531	1.6244
20	1.643	1.6057	1.531	1.5123	1.5123	1.6057	1.643
21	1.531	1.4377	1.419	1.3817	1.4003		1.587
22	1.419	1.3443	1.2696	1.2696	1.2136	1.2696	1.419
23	1.251	1.1576	1.1576	1.1576	1.1389	1.1763	1.307
24		1.1203	1.0456	1.0642	1.0829	1.0082	1.0642
Max	1.6804	1.6057	1.5497	1.5123	1.5123	1.6057	1.643
Min	.9335	.8916	.8589	.8589	.8215	.8029	.8402
Avg	1.2920	1.2297	1.1683	1.1321	1.1657	1.1219	1.2741

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

KOPRI S/DN.[655]

BU 4655

Substation No/ Name :- 283074 / WALMIKI S/S

Feeder No / Name : 207 / BSUP Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5975	.6348	.5975	.5975	.5601	.5415	.5601
2	.6161	.5975	.5415	.5601	.5601	.4668	.5041
3	.6161	.5601	.5601	.5228	.5228	.5041	.5228
4		.5601	.5041		.4854	.4668	
5		.6535	.5415		.5228	.5415	
6	.7655	.7095	.6348	.5975	.6722	.5228	.5975
7	.7095	.7842	.6722	.6348	.6348	.5601	.6535
8	.7095	.6535	.7468	.7282	.6908	.6161	.6722
9	.7282	.7468	.7282	.6535	.7095	.7095	
10	.6722	.7095		.7095	.6161	.6161	.6908
11	.5788	.5975	.5601	.6348	.4854	.6161	.5788
12	.5415		.4668	.5601	.5228	.5041	.5041
13		.5601		.5788	.5788	.4294	.5601
14	.6535	.5415		.5975		.4668	.5228
15	.5975	.5601	.4854	.5788	.5788	.4481	.5601
16	.5788	.5601	.5415	.5041	.3921	.4668	.5975
17	.5601	.5228	.5415	.5041	.3734	.3734	.4294
18	.4668	.4294	.4481	.5228	.3921	.3921	.4854
19	.6535	.5601		.5415	.5415	.6161	.6535
20	.7095	.6161	.6908	.6535	.6348	.6348	.6908
21	.6535	.6348	.6535	.6348	.6348		.6908
22	.6535	.5975	.5975	.5788	.5415	.7095	.6722
23	.7282	.6908	.6908	.6722	.6535	.6908	.7282
24		.6722		.6722	.6161	.5601	.6348
Max	.7655	.7842	.7468	.7282	.7095	.7095	.7282
Min	.4668	.4294	.4481	.5041	.3734	.3734	.4294
Avg	.6395	.6153	.5896	.6017	.5617	.5415	.5957

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283079 / 22/11 kV VASANT VIHAR

SUBSTATI

Feeder No / Name : 201 / SHOPPING FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2851	1.2308	1.2489	1.2127	1.1584	1.086	1.1584
2	1.267	1.2127	1.2127	1.1765	1.1041	1.0498	1.0498
3	1.2489	1.1946	1.1765	1.1222	1.086	1.0317	1.0136
4	1.2489	1.1946	1.1765	1.086	1.086	1.0136	.9774
5	1.2489	1.1946	1.1765	1.086	1.1222	1.0498	1.2489
6	1.3032	1.5746	1.2489	1.267		1.1765	1.3756
7	1.8823	1.7918	1.448	1.3756	1.9366	1.5203	1.7737
8	1.7737	1.8461	1.5927	1.6108	1.8823	1.7375	1.8823
9	1.9547	1.9366	1.9728	1.9366	1.9909	1.9909	1.8461
10	1.9342	1.8781	1.97	1.8054	1.8404	1.8781	1.8461
11	1.97	1.825	1.9342	1.9982	1.7896	1.8755	1.8099
12	1.6832	1.7002	1.8781	1.8229	1.6832	1.6478	1.6832
13	1.6476	1.5947	1.701	1.7002	1.6124	1.5238	1.5746
14	1.4198	1.406	1.7528	1.6126	1.382	1.6124	1.5023
15	1.4198	1.5089	1.5249	1.4899	1.4175	1.3643	1.6108
16	1.448	1.448	1.448	1.5203	1.3213	1.3394	1.4118
17	1.4842	1.4118	1.6289	1.4842	1.3575	1.3756	1.4118
18	1.5203	1.448	1.6651	1.5203	1.3937	1.4661	1.5384
19	1.8461	1.8461	1.9185	1.8461	1.7737	1.7194	1.828
20	1.9909	1.8823	1.8823	1.8823	1.8099	1.8642	1.8461
21	1.9547	1.8461	1.9185	1.9185	1.8642	1.7918	1.9366
22	1.7375	1.7013	1.7013	1.6651	1.6289	1.6651	1.7737
23	1.6108	1.4299	1.5023	1.4842	1.448	1.448	1.5927
24	1.3937	1.3756	1.3032	1.3213	1.2308	1.2308	1.2308
Max	1.9909	1.9366	1.9728	1.9982	1.9909	1.9909	1.9366
Min	1.2489	1.1946	1.1765	1.086	1.086	1.0136	.9774
Avg	1.5947	1.5616	1.5826	1.5394	1.5182	1.4774	1.5384

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283079 / 22/11 kV VASANT VIHAR

SUBSTATI

Feeder No / Name : 203 / VOLTAS FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9492	.9492	.8596	.9134	.8417	.8059	.8417
2	.9134	.9134	.8417	.8954	.8238	.788	.788
3	.8954	.8954	.8417	.8775	.8238	.7522	.7701
4	.8954	.8954	.8238	.8775	.8238	.7164	.7522
5	.985	1.0387	.8238	.8954	.8954	.788	.788
6	1.1104	1.4148	1.0566	.9671		1.1462	1.1641
7	1.6118	1.7551	1.3611	1.1462	1.7909	1.4327	1.576
8	1.4506	1.576	1.3611	1.1641	1.5043	1.4506	1.5223
9	1.5581	1.5581	1.4864	1.4327	1.4506	1.5402	1.5402
10	1.4175	1.3321	1.5581	1.5074	1.4175	1.4883	1.4685
11	1.379	1.3672	1.4327	1.5074	1.3112	1.4706	1.379
12	1.3112	1.2346	1.3611	1.4723	1.2403	1.2357	1.2536
13	1.2757	1.3146	1.2971	1.262	1.1694	1.2757	1.2178
14	.964	.9088	.9991	1.0692	.9391	1.0631	1.0566
15	.8589	.8063	.929	.929	.7973	.8682	.8596
16	.8954	.9313	.985	.9671	.8417	.8954	.9492
17	.8596	.9134	.9134	.9492	.8238	.9134	.9134
18	.9492	.9671	1.086	1.0387	.8954	.9492	.9671
19	1.3611	1.3432	1.3611	1.3969	1.2894	1.379	1.3432
20	1.3432	1.3253	1.379	1.3432	1.2894	1.3253	1.3432
21	1.3611	1.3073	1.2894	1.1919	1.3253	1.2536	1.3253
22	1.2536	1.2178	1.2536	1.182	1.1641	1.2178	1.2894
23	1.2357	1.1462	1.1104	1.0745	1.0745	1.1283	1.1462
24	1.1462	1.0566	1.0029	1.0208		.9134	1.0029
Max	1.6118	1.7551	1.5581	1.5074	1.7909	1.5402	1.576
Min	.8589	.8063	.8238	.8775	.7973	.7164	.7522
Avg	1.1659	1.1737	1.1422	1.1284	1.1151	1.1166	1.1357

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283079 / 22/11 kV VASANT VIHAR

SUBSTATI

Feeder No / Name : 204 / TOWER FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0808	1.0808	1.0099	1.0985	.9922	.9114	.9465
2	1.0454	1.0631	.9745	1.0808	.9745	.8764	.9114
3	1.0454	1.0277	.9214	1.0454	.9214	.8764	.8764
4	1.0277	1.0277	.9214	1.0099	1.0277	.8939	.8764
5	1.0808	1.0985	.9922	1.0099	1.0631	.9465	.964
6	1.1517	1.3998	1.0277	1.0099		1.0517	1.1043
7	1.3289	1.3998	1.0808	1.0454	1.5061	1.1218	1.3321
8	1.5061	1.4175	1.2757	1.0631	1.4352	1.3672	1.3847
9	1.5947	1.5238	1.4706	1.3643	1.4352	1.4548	1.4723
10	1.6118	1.5249	1.5223	1.5249	1.4352	1.4883	1.4175
11	1.6476	1.4918	1.5223	1.6827	1.4529	1.4899	1.4883
12	1.4327	1.3496	1.4506	1.4548	1.3289	1.4175	1.4175
13	1.3146	1.2346	1.4022	1.3146	1.258	1.2536	1.2757
14	1.2269	1.286	1.2445	1.2445	1.1694	1.1517	1.2226
15	1.1919	1.1488	1.1393	1.2226	1.0454	1.0277	1.134
16	1.2269	1.1919	1.1919	1.1218	1.1393	1.0517	1.1218
17	1.1218	1.0867	1.1043	1.0692	1.0692	1.0341	1.1744
18	1.2445	1.1393	1.2795	1.2094	1.0867	1.1568	1.2269
19	1.4022	1.4899	1.5424	1.5074	1.3146	1.4022	1.4198
20	1.5424	1.4723	1.5074	1.4198	1.3321	1.4022	1.5249
21	1.5775	1.5074	1.4548	1.4373	1.4548	1.5074	1.5249
22	1.4723	1.4548	1.3672	1.3496	1.3496	1.4198	1.4899
23	1.3289	1.258	1.2757	1.1871	1.1919	1.2094	1.3321
24	1.1517	1.134	1.1163	1.1517		.9465	1.0166
Max	1.6476	1.5249	1.5424	1.6827	1.5061	1.5074	1.5249
Min	1.0277	1.0277	.9214	1.0099	.9214	.8764	.8764
Avg	1.3065	1.2837	1.2415	1.2344	1.2265	1.1858	1.2356

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283079 / 22/11 kV VASANT VIHAR

SUBSTATI

Feeder No / Name : 205 / SIDDHACAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1646	.1646	.1463	.1463	.1646	.1646	.1646
2	.1646	.1646	.1463	.1463	.1463	.1463	.1463
3	.1646	.1646	.1463	.1463	.1463	.1463	.1463
4	.1646	.1646	.1463	.1463	.1646	.1463	.1463
5	.1646	.2012	.1646	.1463	.2012	.1463	.1646
6	.2195	.2743	.1646	.1646		.1829	.2378
7	.2926	.3292	.2012	.1829	.3475	.2378	.2743
8	.2743	.3109	.2561	.2012	.3109	.2561	.2561
9	.2743	.2926	.3292	.2743	.2926	.2743	.2926
10	.3189	.2743	.3045	.298	.3012	.2835	.2743
11	.3403	.2743	.3012	.2804	.2835	.3012	.2561
12	.2126	.2454	.2686	.2804	.2658	.2303	.2561
13	.1928	.2279	.2629	.2279	.2481	.2126	.2012
14	.1753	.1928	.2103	.1928	.1949	.1772	.1829
15	.1595	.1886	.1753	.1753	.1772	.1417	.1829
16	.1829	.1829	.1646	.1829	.1829	.1646	.1829
17	.2195	.2012	.1829	.2012	.2012	.1646	.1829
18	.2012	.1829	.2012	.1829	.2012	.1646	.2012
19	.2378	.2378	.2561	.2378	.2378	.2195	.2378
20	.2743	.2378	.2378	.2561	.2378	.2378	.2378
21	.2561	.2561	.2195	.2378	.2195	.2195	.2378
22	.2378	.2378	.2012	.2195	.2378	.2195	.2561
23	.2195	.2378	.2012	.2012	.1829	.1829	.2195
24	.1646	.1829	.1646	.2012	.1646	.1646	.1646
Max	.3403	.3292	.3292	.298	.3475	.3012	.2926
Min	.1595	.1646	.1463	.1463	.1463	.1417	.1463
Avg	.2199	.2261	.2105	.2054	.2222	.1994	.2126

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283095 / 22KV KASARWADWALI SWG STN

Feeder No / Name : 301 / SERENDIPITY MALL

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1524				.1524	
2		.1524				.1524	
3		.1524				.1524	
4		.1524				.1524	
5		.1524				.1524	
6		.1524				.1524	
7		.1524		.1524	.1524		.1524
8		.1524		.1524	.1524	.1524	.1524
9		.1524		.1524			.1524
10		.4954	.381	.4954		.381	.4572
11		.724	.6478	.6478		.5335	.6097
12	.7621	.724		.7621			
13	.6859	.6859	.7621	.7621			
14	.8002	.6859	.7621	.7621		.6478	
15	.7621	.724	.724	.7621			
16	.6859	.724	.7621	.724	.724		.724
17	.6859	.724	.7621	.724	.6859		
18	.6859	.6859	.6859	.724	.6478	.6478	.724
19	.6859	.679		.7621			
20		.679		.7621			
21		.6036		.7621			
22		.3018		.4572			
23		.1509		.1905			
24		.1524			.1524	.1524	
Max	.8002	.724	.7621	.7621	.724	.6478	.724
Min	.6859	.1509	.381	.1524	.1524	.1524	.1524
Avg	.7192	.4213	.6859	.5738	.4192	.2858	.4246

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283095 / 22KV KASARWADWALI SWG STN

Feeder No / Name : 302 / IRON AND METAL

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.381	.2286		.2286	.3048	
2		.381	.2286		.2286	.3048	
3		.381	.2286		.1905	.3048	
4		.381	.2286		.1905	.3048	
5		.381	.2286		.1905	.3048	
6		.381	.2286		.2286	.3048	
7		.5716	.381	.3048	.6478	.3429	.3429
8		.724		.3429	.6859	.6097	.724
9		.7621	.4572	.3429			.8383
10		.8764	.6478	.3429		.8383	.8383
11		.8383	.6097	.4954		.8383	.9145
12	.8764	.8383					
13	.8383	.8383	.5716	.4954			
14	.8764	.8383	.6097	.3429		.8002	
15	.9145	.8002	.6097	.2667			
16	.9145	.8002	.5716	.2667	.7621		
17	.9145	.8002	.5335	.3048	.7621		
18	.9145	.8002	.5335	.3048	.7621	.8383	.8383
19	.8383	.415		.3429			
20		.415		.3429			
21		.415		.3429			
22		.415		.3429			
23		.3772		.3429			
24		.381	.3395		.2667	.3429	
Max	.9145	.8764	.6478	.4954	.7621	.8383	.9145
Min	.8383	.3772	.2286	.2667	.1905	.3048	.3429
Avg	.8859	.5913	.4257	.3453	.4287	.4953	.7494

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283095 / 22KV KASARWADWALI SWG STN

Feeder No / Name : 303 / BOMBAY METAL AND ALLOY NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.381	.4191		.3429	.3048	
2		.381	.4191		.3048	.3048	
3		.381	.381		.3048	.3048	
4		.381	.381		.3048	.3048	
5		.381	.381		.3048	.3048	
6		.381	.381		.3429	.3048	
7		.3429	.3429	.2667	.3429	.381	.4191
8		.4572	.381	.2667		.4572	.4572
9		.5335	.381	.3048			.5335
10		.6478	.4572	.2667		.6097	.5716
11		.6097	.4191	.3429		.5716	.5716
12	.6097	.5716		.3048			
13	.5716	.5716	.4191	.3048			
14	.6478	.5716		.3048		.6859	
15	.5716	.5716	.381	.3048			
16	.6097	.6097	.4572	.3048			
17	.6097	.6097	.4572	.3048	.6097		
18	.5716	.5716	.381	.3048	.6097	.6478	.6478
19	.5716	.5658		.3048			
20		.5658		.3048			
21		.4904		.3048			
22		.4527		.3048			
23		.4527		.2667			
24		.381	.3772		.3429	.3048	
Max	.6478	.6478	.4572	.3429	.6097	.6859	.6478
Min	.5716	.3429	.3429	.2667	.3048	.3048	.4191
Avg	.5954	.4943	.4009	.2981	.3810	.4221	.5335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283095 / 22KV KASARWADWALI SWG STN

Feeder No / Name : 304 / G CORP

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4191	.381		.2667	.2667	
2		.4191	.381		.3048	.2667	
3		.4191	.381		.3048	.2667	
4		.4191	.381		.2667	.2667	
5		.4191	.381		.3048	.2667	
6		.4191	.381		.3048	.2667	
7		.3048	.1905	.1524	.3048	.2667	.4572
8		.3048	.1905	.1524	.3048	.2667	.3048
9		.4572	.2286	.1524			.5335
10		.5335	.1905	.1524		.6097	.5335
11		.4954	.1905	.1524		.5716	.5716
12	.5335	.4954		.1524			
13	.5335	.4954	.2286	.1524			
14	.5716	.4954	.4572	.1524		.3429	
15	.5716	.4954	.1905	.1524			
16	.5716	.5335	.1905	.1524	.5335		
17	.5716	.4954	.1905	.1524	.4572		
18	.5335	.4572	.1905	.1905	.4572	.4954	.5716
19	.4572	.4527		.1524			
20		.4527		.3048			
21		.4904		.3048			
22		.3772		.4572			
23				.1524			
24		.4572	.3772		.1524	.3048	
Max	.5716	.5335	.4572	.4572	.5335	.6097	.5716
Min	.4572	.3048	.1905	.1524	.1524	.2667	.3048
Avg	.5430	.4482	.2834	.1905	.3302	.3429	.4954

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283097 / 22/11 KV SOHAM S/S

Feeder No / Name : 201 / SOHAM 1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2058	.1886	.2058	.1886	.2058	.1715
2	.2058	.1715	.1715	.2058	.1715	.1715	.1715
3	.2058	.1543	.1543	.2058	.1715	.1543	.1543
4	.2058	.1543	.1543	.1886	.1715	.1543	.1543
5	.1886	.2572	.1543	.1886	.1372	.1715	.1543
6	.1886	.3086	.1543	.1715	.1715	.1715	.1543
7	.1715	.2743	.1715	.1715	.1886	.2401	.1715
8	.2058	.2058	.2058	.1372	.2058	.2229	.2058
9	.2572	.2572	.2229	.2058	.2572	.2058	.2401
10	.2743	.2401	.2229	.3086	.2058	.2743	.2401
11	.2229	.2743	.2401	.2743	.2572	.2743	.2743
12	.2229	.2572	.3258	.3086	.2743	.2401	.2572
13		.2401	.2915	.3086	.1886	.2401	.2401
14		.2401	.2572	.2572	.2572	.2229	.2572
15	.2229	.2401	.2743	.2401	.2572	.2572	.2401
16	.2229	.2401	.2401	.2401	.2572	.2743	.1886
17	.2572	.2401	.1886	.2058	.2401	.2743	
18	.2401	.2572	.2915	.2229	.2572	.2915	.2743
19	.3258	.3086	.2915	.2915	.3086	.2915	.3772
20	.3429	.3086	.3086	.3086	.2915	.3258	.3086
21	.3258	.3086	.3086	.3429	.2743	.2915	.3086
22	.2915	.2743	.2743	.2743	.2743	.2401	.2572
23	.2401		.2229	.2401	.2058	.2229	
24	.2229	.2058	.2058	.2229	.1886	.2229	.1886
Max	.3429	.3086	.3258	.3429	.3086	.3258	.3772
Min	.1715	.1543	.1543	.1372	.1372	.1543	.1543
Avg	.2393	.2445	.2301	.2386	.2251	.2351	.2268

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283097 / 22/11 KV SOHAM S/S

Feeder No / Name : 202 / UNNATI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3772	.3086	.3258	.3258	.3429	.2915
2	.3429	.3429	.2743	.3258	.3086	.3086	.2743
3	.3429	.3086	.2743	.3086	.3086	.2915	.2743
4	.3258	.2915	.2743	.3086	.2915	.2572	.2743
5	.3258	.3429	.2743	.2915	.2915	.3086	.2743
6	.3086	.4287	.2743	.2915	.3086	.3429	.2743
7	.3429	.3944	.3086	.2915	.3086	.3944	.3429
8	.463	.4458	.3772	.2743	.3429	.3601	.4115
9	.4458	.463	.4287	.3258	.4287	.4287	.3944
10	.4287	.4973	.463	.3601	.3944	.4287	.4801
11	.5144	.4458	.4458	.3944	.4115	.3601	.4458
12	.4458	.4115	.3944	.3944	.4458	.3601	.4287
13		.3772	.3429	.3258	.4287	.3086	.3944
14		.3429	.3086	.3086	.3429	.2743	.3944
15		.3429	.2743	.2915	.3601	.2401	.3429
16	.3601	.2915	.3258	.3258	.4115	.2401	.3429
17	.3944	.2743	.3429	.3429	.3944	.2401	
18	.3086	.2743	.3086	.2915	.3601	.2572	.3429
19	.3944	.3429	.2915	.3258	.3944	.3429	.4115
20	.3944	.3429	.3086	.3429	.3944	.3429	.3601
21	.3772		.2915	.3601	.3944	.3601	.3772
22	.3944		.3086	.3429	.3772	.3429	.3944
23	.3429		.3429	.3429	.3772	.3086	
24	.3086	.3944	.3258	.3429	.3258	.3601	.3086
Max	.5144	.4973	.463	.3944	.4458	.4287	.4801
Min	.3086	.2743	.2743	.2743	.2915	.2401	.2743
Avg	.3748	.3682	.3279	.3265	.3637	.3251	.3562

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283097 / 22/11 KV SOHAM S/S

Feeder No / Name : 203 / REGENCY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9945	.9945	.8745	.9431	.8745	.8573	.823
2	.9945	.9602	.823	.8745	.8573	.823	.7888
3	.9774	.9259	.7888	.8573	.8059	.8059	.7716
4	.9259	1.0288	.7716	.8059	.8059	.7716	.7716
5	.8745	1.1145	.7716	.7716	.7716	.8573	.7716
6	1.0288	1.2003	.7716	.7545	.7545	1.0288	.823
7	1.2174	1.2346	.8916	.703	.8573	1.1145	.8916
8	1.286	1.2346	1.0802	.9431	1.0974	1.1488	1.1317
9	1.2174	1.2517	1.1831	1.0288	1.1831	1.2517	1.2003
10	1.3032	1.3889	1.3203	1.2689	1.1831	1.166	1.286
11	1.286	1.3717	1.3546	1.4232	1.2003	1.286	1.2346
12	1.2003	1.2517	1.1831	1.2346	1.0631	1.0974	1.1488
13	1.0631	1.0631	.9945	1.2517	.9602	.9945	1.0631
14	1.0288	1.0631	.9945	1.0974	.8745	.8573	.9431
15	.9774	1.0631	.9431	.9088		.9259	1.0288
16	.9774	1.0288	.9602	.9259	.9945	1.0288	.9945
17	1.0802	1.0288	.9945	1.0631	1.0288	1.0631	1.0974
18	1.1145	1.046	1.0631	.9431	.9431	1.0631	1.1317
19	1.2174	1.2003	1.1145	1.0974	1.166	1.1488	1.2174
20	1.2003	1.2003	1.166	1.0974	1.0631	1.0974	1.166
21	1.2003	1.166	1.0974	1.0288	1.0802	1.1488	1.2346
22	1.1488	1.0974	1.0288	.9259	1.0631	1.0631	1.1145
23	1.1488		.9945	.9602	.9431	1.0288	
24	.9945	1.0288	.9431	.9774	.9088	.8573	.8573
Max	1.3032	1.3889	1.3546	1.4232	1.2003	1.286	1.286
Min	.8745	.9259	.7716	.703	.7545	.7716	.7716
Avg	1.1024	1.1280	1.0045	.9952	.9774	1.0202	1.0213

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283097 / 22/11 KV SOHAM S/S

Feeder No / Name : 204 / OMKARESHWAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1715	.2058	.1886	.1886	.1715	.1715
2	.1715	.1543	.1886	.1886	.1886	.1543	.1543
3	.1715	.1543	.1715	.1715	.1715	.1543	.1543
4	.1543	.1543	.1715	.1715	.1715	.1372	.1543
5	.1543	.2058	.1543	.1543	.1715	.1715	.1543
6	.1715	.2572	.1543	.1543	.1886	.1715	.1543
7	.1886	.2229	.1715	.1886	.1886	.2401	.1543
8	.2058	.1886	.1886	.1886	.1886	.2058	.2229
9	.2058	.1715	.2058	.1886	.1886	.2058	.2229
10	.2229	.2058	.2058	.1886	.2058	.1886	.2229
11	.2743	.2572	.2058	.1886	.2058	.2401	.2743
12	.2401	.2572	.2058	.2058	.2229	.2572	.2058
13	.1715	.2401	.2229	.2058	.1886	.2229	.2743
14	.2229	.2058	.2229	.2058	.2058	.1886	.2572
15	.2058	.2058	.2229	.2229	.1886	.1886	.2058
16	.2229	.2058	.2058	.2229	.2058	.1886	.1886
17	.1715	.2058	.2058	.2229	.2058	.2058	.1715
18	.2058	.2058	.2058	.2229	.1715	.2058	.2229
19	.3086	.2915	.2229	.2229	.1886	.2058	.2572
20	.3429	.2915	.2229	.2058	.2058	.2401	.2401
21	.2915	.2743	.2229	.2058	.1886	.2401	.2572
22	.2915	.2572	.2229	.1886	.1886	.2401	.2572
23	.2743		.2058	.1886	.2229		
24	.1886	.1715	.2229	.1886	.1886	.1715	.1886
Max	.3429	.2915	.2229	.2229	.2229	.2572	.2743
Min	.1543	.1543	.1543	.1543	.1715	.1372	.1543
Avg	.2186	.2155	.2015	.1950	.1929	.1998	.2072

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283097 / 22/11 KV SOHAM S/S

Feeder No / Name : 205 / HAWARE ESTATE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.3772	.3258	.4458	.3601	.3429	.3258
2	.3944	.3429	.2915	.4287	.3429	.3429	.3086
3	.3944	.3086	.2915	.4287	.3429	.3086	.3086
4	.3772	.2743	.2915	.4115	.3258	.2572	.2915
5	.3772	.4287	.2915	.4115	.3258	.3429	.2743
6	.3601	.5487	.3086	.3944	.3429	.4115	.2743
7	.4801	.5144	.3772	.3944	.4287	.4801	.3429
8	.4973	.5658	.4801	.3944	.5316	.4287	.4458
9	.4973	.5316	.5487	.3944	.4973	.5316	.4801
10	.4973	.5658	.4973	.5658	.4458	.5487	.463
11	.5316	.4801	.4973	.5144	.5487	.5144	.5316
12	.4287	.4801	.463	.4801	.463	.4458	.4115
13	.3944	.463	.4801	.4801	.3601	.4115	.3944
14	.3772	.3601	.4115	.4287	.3601	.3601	.3601
15	.3772	.4115	.3601	.3772	.3601	.3601	.4115
16	.4287	.4115	.3772	.4115	.3429	.3944	.3772
17	.3944	.4115	.3944	.4115	.3429	.3944	.4115
18	.3772	.4287	.4115	.4115	.4115	.3944	.4458
19	.463	.4287	.3944	.4115	.4287	.4801	.4801
20	.4287	.4287	.4115	.4287	.3944	.463	.4801
21	.5144	.463	.3944	.3944	.463	.4287	.4801
22	.463	.4801	.4458	.3944	.4287	.4458	.4973
23	.5316		.463	.4115	.3772	.4287	
24	.4115		.3772	.4458	.3772	.3772	.3772
Max	.5316	.5658	.5487	.5658	.5487	.5487	.5316
Min	.3601	.2743	.2915	.3772	.3258	.2572	.2743
Avg	.4337	.4411	.3994	.4280	.4001	.4122	.3988

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283097 / 22/11 KV SOHAM S/S

Feeder No / Name : 206 / MERIT MAGNUM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2058	.2058	.2229	.2058	.1715	.1886
2	.1886	.1715	.2058	.2058	.2058	.1715	.1715
3	.1886	.1715	.1715	.2058	.1886	.1543	.1543
4	.1715	.1543	.1715	.2058	.1886	.1543	.1543
5	.1715	.2572	.1543	.1886	.1715	.1543	.1543
6	.1886	.3086	.1543	.1886	.1886	.2058	.1543
7	.2401	.2743	.1715	.1715	.2229	.2401	.2058
8	.2572	.2915	.2229	.1715	.2401	.2229	.2572
9	.2915	.2915	.2743	.2572	.2058	.2915	.2743
10		.2401	.2743	.3429	.2401	.2572	.2229
11	.2572	.2229	.2572	.3086	.2058	.2229	
12	.2572	.1886	.1886	.2229	.2401	.2401	.2058
13	.1715	.1886	.2572	.2058	.3601	.2229	.1715
14	.1886	.1715	.2401	.1886	.1543	.1715	.1543
15	.1372	.2058	.1715	.2058	.1543	.1715	.1715
16	.1715	.2058	.1715	.3944	.1715	.1715	.1715
17	.1543	.2229	.1715	.1715	.1715	.1715	.1886
18	.1715	.2229	.2401	.1543	.1715	.1886	.1715
19	.2572	.2572	.2915	.1715	.2915	.2572	.2572
20	.2401	.2915	.3086	.2915	.2572	.2743	.2743
21	.2915	.2743	.2401	.2743	.2401	.2743	.2743
22	.2743	.2572	.2401	.2401	.2572	.2572	.2743
23	.2229		.2229	.2058	.2058	.2229	
24	.2058	.2058	.2229	.2229	.2058	.2058	.2058
Max	.2915	.3086	.3086	.3944	.3601	.2915	.2743
Min	.1372	.1543	.1543	.1543	.1543	.1543	.1543
Avg	.2132	.2296	.2179	.2258	.2144	.2115	.2026

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283097 / 22/11 KV SOHAM S/S

Feeder No / Name : 207 / ORIAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0343	.0171	.0171	.0171	.0171	.0171
2	.0171	.0171	.0171	.0171	.0171	.0171	.0171
3	.0171	.0171	.0171	.0171	.0171	.0171	.0171
4	.0171	.0171	.0171	.0171	.0171	.0171	.0171
5	.0171	.0171	.0171	.0171	.0171	.0171	.0171
6	.0171	.0171	.0171	.0171	.0171	.0171	.0171
7	.0171	.0343	.0171	.0171	.0171	.0171	.0171
8	.0171	.0171	.0171	.0343	.0171	.0171	.0171
9	.0171	.0171	.0343	.0343	.0171	.0343	.0343
10	.0171	.0343	.0343	.0343	.0171	.0343	.0343
11	.0171	.0343	.0343	.0343	.0171	.0343	
12	.0171	.0343	.0343	.0343	.0171	.0343	.0343
13		.0343	.0343	.0343	.0171	.0343	.0171
14	.0171	.0343	.0343	.0343	.0171	.0343	.0171
15	.0171	.0343	.0343	.0343	.0171	.0171	.0171
16	.0171	.0343	.0343	.0343	.0171	.0171	.0171
17	.0171	.0343	.0343	.0343	.0171	.0171	.0171
18	.0171	.0343	.0343	.0343	.0171	.0171	
19	.0171	.0343	.0343	.0343	.0171	.0343	.0343
20	.0171	.0343	.0343	.0343	.0171	.0343	.0343
21	.0343	.0343	.0343	.0343	.0171	.0343	.0171
22	.0343	.0343	.0343	.0343	.0171		.0343
23	.0343		.0343	.0343	.0171	.0343	
24	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Max	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Min	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Avg	.0201	.0291	.0286	.0293	.0178	.0253	.0228

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283098 / 22/11 KV EVEREST WORLD S/S

Feeder No / Name : 203 / NEW EVEREST

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	12-FEB-18	13-FEB-18
HR	Load (MW)	Load (MW)
12	1.1763	1.2696
23	.9335	1.3203
24		.9425
Max	1.1763	1.3203
Min	.9335	.9425
Avg	1.0549	1.1775

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283098 / 22/11 KV EVEREST WORLD S/S

Feeder No / Name : 204 / KAVYADHARA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	12-FEB-18	13-FEB-18
HR	Load (MW)	Load (MW)
12	1.1949	
23	.9795	1.2696
24		.9979
Max	1.1949	1.2696
Min	.9795	.9979
Avg	1.0872	1.1338

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283101 / 22/22 KV HYPERCITY SWITCHING

Feeder No / Name : 301 / Ovla

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.6004	1.4098		1.5242	1.448	
2		1.6004	1.4098		1.448	1.448	
3		1.6004	1.4098		1.448	1.448	
4		1.6004	1.4098		1.448	1.448	
5		1.6004	1.4098		1.5242	1.448	
6		1.6004	1.4098		1.5242	1.5242	
7		1.9433	1.5623	1.4861	1.7147	1.7528	1.829
8		1.9814	1.6766	1.5623	2.0195	1.9433	2.0957
9		.1905	2.0576	1.9814			2.2862
10		2.6292	2.4006	2.2481		2.5149	2.5911
11		2.452	2.4387	2.21		2.3624	2.6673
12	2.6292	2.3765		2.0195			
13	2.4006	2.3011	2.1719	1.9814			
14	2.3624		1.9433	1.8671		2.0195	
15	2.2862	2.3388	1.9433	1.6766			
16	2.2862	2.2862	2.0195	1.6766	2.3243		
17	2.2862	2.1879	1.9814	1.6766	2.2862		
18	2.0576	2.1125	1.9814	1.7528	2.0195	1.829	2.3243
19	2.3624	2.037		2.0195			
20		2.0576		1.7528			
21		1.9616		1.7528			
22		1.8484		1.7528			
23		1.773		1.6004			
24		1.7147	1.4098		1.6385	1.5242	
Max	2.6292	2.6292	2.4387	2.2481	2.3243	2.5149	2.6673
Min	2.0576	.1905	1.4098	1.4861	1.448	1.448	1.829
Avg	2.3339	1.9041	1.7803	1.8245	1.7433	1.7469	2.2989

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283101 / 22/22 KV HYPERCITY SWITCHING

Feeder No / Name : 302 / 22KV HAWARE CITY

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2286	.2286		.2286	.2286	
2		.2286	.2286		.2286	.2286	
3		.2286	.2286		.2286	.2286	
4		.2286	.2286		.1905	.2286	
5		.2286	.2286		.2286	.2286	
6		.2286	.2286		.2286	.2286	
7		.3048	.2286	.1905	.2667	.2286	.2667
8		.3429	.2667	.2286	.3048	.2286	.3048
9		.3052	.2713	.2667			.3048
10		.3391	.3048	.3048		.2286	.3429
11		.2374	.3048	.3048		.2667	.2667
12	.3048	.3391		.2667			
13	.2286	.2713	.2667	.1905			
14	.2286	.2713	.1905	.1905		.1905	
15	.2286	.2374	.1524	.1905			
16	.1905		.1143	.1905	.1905		
17	.1905	.2263	.1524	.1905	.1905		
18	.1905	.1696	.1524	.2667	.1905	.1905	.1905
19	.2286	.2035		.2667			
20		.2035		.2286			
21		.2374		.2286			
22		.2641		.2667			
23		.2374		.2286			
24		.2286	.2286		.2667	.2667	
Max	.3048	.3429	.3048	.3048	.3048	.2667	.3429
Min	.1905	.1696	.1143	.1905	.1905	.1905	.1905
Avg	.2238	.2518	.2225	.2353	.2286	.2286	.2794

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283101 / 22/22 KV HYPERCITY SWITCHING

Feeder No / Name : 303 / CHENNA

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.724	.6859		.6097	.6097	
2		.724	.6859		.6097	.6097	
3		.724	.6859		.6097	.6097	
4		.724	.6859		.6097	.6097	
5			.6859		.6097	.6097	
6		.724	.6859		.6097	.724	
7		.7621	.8002	.8002	2.4768	.8002	.7621
8		.8764	.8383	.8764	.9145	.8383	.8383
9		1.5242	1.3336	.8764			1.448
10		1.6221	1.7528	.7621		1.2193	1.2574
11		1.6221	1.9433	.7621		1.1812	.9907
12	1.3336	1.6598		.9145			
13	1.3336	1.4098	1.2193	.8002			
14	1.2193	1.0669	1.2193	.8383		.8002	
15	1.3336	1.5242	1.5242	.7621			
16	1.3336	1.4098	1.4861	.7621	1.4098		
17	1.2574	1.6598	1.4098	.7621			
18	1.2574	1.5089	1.4098	.8002	1.2955	1.0669	.9526
19	1.3336	1.5089		1.0288			
20		1.4335		.9526			
21		1.358		.8764			
22		1.358		.8764			
23		.8676		.8383			
24		.7621	.724		.724	.724	
Max	1.3336	1.6598	1.9433	1.0288	2.4768	1.2193	1.448
Min	1.2193	.724	.6859	.7621	.6097	.6097	.7621
Avg	1.3003	1.1980	1.0987	.8405	.9526	.8002	1.0415

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283101 / 22/22 KV HYPERCITY SWITCHING

Feeder No / Name : 304 / Incommmer to Haware SS NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 22 / INCOMING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2193	1.2193		1.1431	1.1431	
2		1.2193	1.2193		1.1431	1.1431	
3		1.2193	1.2193		1.1431	1.1431	
4		1.2193	1.2193		1.1431	1.1431	
5		1.2193	1.2193		1.1431	1.1431	
6		1.5242	1.2193		1.2193	1.3336	
7		1.7909	1.4098	1.2193	1.6766	1.4861	1.7909
8		1.6766		1.3336		1.5623	1.7147
9		1.829	1.6766	1.7909			1.8671
10		1.6975		1.9814		1.9052	1.8671
11		1.6975	1.7909	1.7909		1.7528	1.7147
12	1.6004	1.5466		1.8671			
13	1.4098	1.4335	1.6004	1.6004			
14	1.2955	1.3717	1.4098	1.4098		1.4098	
15	1.3336	1.2955	1.4098	1.4098			
16	1.3717		1.3336	1.4098	1.2193		
17	1.3717	1.2071	1.448	1.4098	1.2193		
18	1.3717	1.358	1.448	1.5242	1.2193	1.3336	1.2955
19	1.7528	1.5623		1.7528			
20		1.5623		1.6385			
21		1.6221		1.6385			
22		1.5089		1.5242			
23		1.3957		1.4098			
24		1.3336	1.2574		1.2193	1.2193	
Max	1.7528	1.829	1.7909	1.9814	1.6766	1.9052	1.8671
Min	1.2955	1.2071	1.2193	1.2193	1.1431	1.1431	1.2955
Avg	1.4384	1.4569	1.3813	1.5712	1.2262	1.3629	1.7083

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283101 / 22/22 KV HYPERCITY SWITCHING

Feeder No / Name : 305 / INCOMMER TO LODHA SS

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 22 / INCOMING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2667	.2667		.2667	.2667	
2		.2667	.2667		.2667	.2667	
3		.2667	.2667		.2667	.2667	
4		.2667	.2667		.2667	.2667	
5		.2667	.2667		.2667	.2667	
6			.2667		.2667	.2667	
7		.2667	.2667	.2667	.2667	.2667	.2667
8		.2667	.2667	.2667	.2667	.2667	.2667
9		.2667	.2667	.2667			.2286
10		.2641	.2286	.2667		.2286	.2286
11		.2641	.2286	.2286		.2286	.2286
12	.2667	.2641		.2667			
13	.2667	.2667	.2286	.2667			
14	.2667	.2667	.2286	.2667		.2667	
15	.2667	.2667	.2286	.2667			
16	.2667	.2667	.2286	.2667	.2667		
17	.2667	.2641	.2286	.2667	.2667		
18	.2667	.2641	.2286	.2667	.2667	.2667	.2286
19	.2667	.2667		.2667			
20		.2667		.2667			
21		.2667		.2667			
22		.2641		.2667			
23		.2641		.2667			
24		.2667	.2667		.2667	.2667	
Max	.2667	.2667	.2667	.2667	.2667	.2667	.2667
Min	.2667	.2641	.2286	.2286	.2667	.2286	.2286
Avg	.2667	.2659	.2498	.2645	.2667	.2608	.2413

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283104 / 22/11 KV ANILINE SUBSTATION

Feeder No / Name : 201 / SANGHAVI HILLS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0762	.0953	.0754	.0754	.0762
2	.0953	.0762	.0762	.0754	.0754	.0762
3	.0762	.0762	.0762	.0566	.0754	.0762
4	.0762	.0572	.0762	.0566	.0754	.0762
5	.0762	.0572	.0572	.0566	.0754	
6	.0762	.0572	.0572	.0754	.0754	.0762
7	.0953	.1143	.0762	.1132	.0943	.0953
8	.1143	.1143	.1143	.112	.1132	.1143
9		.1334	.0943	.1307	.132	.1143
10	.0953	.1334	.132	.1132		
11		.0953	.1494	.0943		
12		.1143	.1494	.0943		
13		.1143	.1132	.0754		
14		.0762	.1132	.0754		
15			.0934	.0754		
16	.0953		.0943	.0754		
17	.0953		.0943	.0943	.0762	
18	.1143		.0934	.0754	.0762	
19	.1143		.112	.1132	.0762	
20	.0953		.112	.1132	.1334	
21	.0953		.1132	.1132	.1334	
22	.1143		.0943	.0943	.0953	
23			.112	.0943	.0953	
24		.0762	.0953	.0747	.0754	.0762
Max	.1143	.1334	.1494	.1307	.1334	.1143
Min	.0762	.0572	.0572	.0566	.0754	.0762
Avg	.0953	.0915	.0998	.0887	.0914	.0868

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283104 / 22/11 KV ANILINE SUBSTATION

Feeder No / Name : 203 / RUTU ENCLAVE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.5335	.5335	.4527	.4108	.5144
2	.5335	.4572	.4763	.3696	.3734	.4954
3	.4763	.4191	.4191	.3547	.3734	.5335
4	.4572	.5144	.4954		.3734	.5335
5	.4382	.4572	.5144	.4481	.3961	.5144
6	.4382	.4954	.5335	.5788	.4904	.4382
7	.6859	.5335	.5716	.7282	.7167	.6287
8	.7811	.6668	.5906	.7545	.7356	.7621
9	.8002	.724	.7167	.7167	.7545	.6859
10	.7049	.724	.7356	.679		
11		.7811	.6979	.6036		
12		.7621	.7545	.6036		
13		.6668	.7733	.6224		
14		.5144	.7167	.5658		
15			.5847	.4527	.5716	
16	.4382		.4904	.415	.5335	
17	.5716		.5093	.4527	.5716	
18	.6668		.547	.5093		
19	.6668		.6979	.6413		
20	.6097		.6348	.6413	.6287	
21	.6287		.6602	.6602	.6287	
22	.6668		.5601	.6036	.6478	
23			.5847	.547	.5716	
24	.6287	.5716	.5335	.4668	.4338	.5335
Max	.8002	.7811	.7733	.7545	.7545	.7621
Min	.4382	.4191	.4191	.3547	.3734	.4382
Avg	.5980	.5881	.5972	.5595	.5419	.5640

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283104 / 22/11 KV ANILINE SUBSTATION

Feeder No / Name : 204 / RUBY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0762	.0762	.056	.0566	.0762
2	.0572	.0762		.056	.0566	.0762
3	.0572	.0762	.0572	.056	.0566	.0762
4	.0572	.0762	.0572	.056	.0566	.0572
5	.0572	.0762	.0572	.056	.0566	
6	.0572	.0762	.0572	.056	.0566	.0572
7	.0572	.0572	.0572	.056	.0566	.0762
8	.0572	.0572	.0572	.0754	.0566	.0762
9	.1143	.0572	.0754	.1132	.0943	.0762
10	.1143	.0572	.0747	.0754		
11		.0572	.0754	.0754		
12		.0762	.0943	.0566		
13		.0953	.0754	.0566		
14		.0572	.0754	.0566		
15			.0566	.0566	.0572	
16	.0572		.0566	.0566		
17	.0572		.0377	.0566	.0762	
18	.0572		.0566	.0566		
19	.0953		.0754	.0754		
20	.0953		.0747	.0754	.0762	
21	.0762		.056	.0754	.0953	
22	.0572		.056	.0754	.0953	
23			.0747	.0754	.0953	
24	.0572	.0762	.0762	.056	.0566	.0762
Max	.1143	.0953	.0943	.1132	.0953	.0762
Min	.0572	.0572	.0377	.056	.0566	.0572
Avg	.0688	.0699	.0657	.0650	.0687	.0720

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283104 / 22/11 KV ANILINE SUBSTATION

Feeder No / Name : 205 / SAFIRE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0762	.0572	.0189	.0566	.0762
2	.0572	.0762	.0572	.0566	.0566	.0572
3	.0572	.0762	.0572	.0566	.0566	.0572
4	.0572		.0572	.0532	.0566	.0572
5	.0572	.0762	.0572	.0554	.0566	.0572
6	.0572	.0762	.0572	.0554	.0566	.0572
7	.0572	.0762	.0572	.0549	.0754	.0572
8	.0953	.0762	.0572	.0566	.0754	.0572
9	.0953	.0762	.0566	.0566	.0566	.0572
10	.0953	.0762	.0566	.0566		
11		.0762	.0754	.0566		
12		.0762	.0754	.0566		
13		.0762	.0754	.0754		
14		.0572	.0754	.0754		
15			.0754	.0566	.0572	
16	.0572		.0754	.0566	.0572	
17	.0572		.0566	.0754		
18	.0762		.0566	.0566		
19	.0762		.0754	.0943	.0953	
20	.0762		.0754	.0943		
21	.0762		.0747	.0754	.0572	
22	.0762		.0754	.0754	.0572	
23			.0566	.0754	.0572	
24	.0572	.0762	.0572	.0754	.0754	.0762
Max	.0953	.0762	.0754	.0943	.0953	.0762
Min	.0572	.0572	.0566	.0189	.0566	.0572
Avg	.0688	.0748	.0646	.0633	.0627	.061

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283104 / 22/11 KV ANILINE SUBSTATION

Feeder No / Name : 206 / SOLITARE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.0762	.0953	.0754	.1132	.0762
2	.1334	.0762	.0953	.0566	.1132	.0762
3	.1143	.0572	.0762	.0566	.0943	.0762
4	.1143	.0572	.0762	.0566	.0754	.0572
5	.0953	.0572	.0762	.0566	.0754	.0572
6	.0572	.0762	.0762	.0566	.0566	.0572
7	.0762	.0762	.0762	.0943	.0566	.0953
8	.1143	.0762	.0762	.0943	.0566	.1143
9	.0572	.1143	.0934	.0754	.0754	.1143
10	.1334	.1143	.0943	.0943		
11		.0953	.1494	.132		
12		.1143	.132	.0934		
13		.1334	.132	.0754		
14		.1143	.132	.0754		
15			.112	.0934	.1143	
16	.1143		.1132	.0943	.1143	
17	.1143		.112	.0943	.1143	
18			.132	.0754		
19	.1524		.1509	.1509		
20	.1524		.1494	.132	.1524	
21	.1524		.1132	.1509	.0953	
22	.1524		.132	.1509	.0953	
23			.1132	.1698	.0953	
24	.1334	.0762	.1143	.0747	.132	.0953
Max	.1524	.1334	.1509	.1698	.1524	.1143
Min	.0572	.0572	.0762	.0566	.0566	.0572
Avg	.1177	.0876	.1093	.0950	.0959	.0819

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283105 / 22/22 KV PATLIPADA SWITCHING

Feeder No / Name : 301 / Incommmer to ROMA 1

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 22 / INCOMING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7435	2.7778	2.6406	2.7778	2.7435	2.4348	2.5377
2	2.6406	2.6063	2.572	2.6063	2.6406	2.4006	2.4691
3	2.4691	2.5377	2.4691	2.4348	2.4006	2.4006	2.4006
4	2.5034	2.572	2.332	2.4348	2.332	2.4691	2.4348
5	2.7778	2.5377	2.4006	2.5034	2.5034	2.6749	2.5034
6	3.2922	3.3608	2.7435	2.7092	2.915	2.8464	3.3608
7	3.9438	3.7037	2.915	2.7092	3.6008	3.3608	3.6694
8	4.0124	3.7037	3.155	3.155	3.738	3.4979	3.8752
9	3.9438	4.2181	3.8066	3.7723	3.9781	3.8066	4.0809
10	4.2524	4.0809	4.1838	4.0809	4.321	4.2181	4.1152
11	4.2867	4.2181	4.2867	4.0466	4.2867	4.321	4.1838
12	4.3553	4.0466	3.9438	4.2524	4.0124	4.1152	3.9438
13	3.7723	3.7037	3.4979	3.8409	3.5665	3.6008	3.8752
14	3.7723	3.3608	3.3608		3.3608	3.4294	3.7723
15	3.7723	3.4637	3.3608	3.2579	3.2236	3.2236	3.5322
16	3.6008	3.3951	3.3265	3.2579	3.3608	3.1893	3.4979
17	3.7723	3.4294	3.4294	3.4637	3.2579	3.1893	3.4637
18	3.7037	3.3265	3.4979	3.4294	3.155	3.2236	3.2579
19	4.1152	4.0466	4.1152	3.9438	3.7723	3.7723	4.0466
20	3.8752	3.8066	3.8752	3.738	3.6351	3.7037	3.9438
21	3.8409	3.7037	3.9095	3.7037	3.7037	3.6694	3.9438
22	3.5665	3.4294	3.5665	3.3951	3.4637	3.4294	3.8409
23	3.3608	3.155	3.2236	3.1207	3.0178	3.0864	3.5665
24	3.155	2.915	2.8807	2.915	2.8807	2.6406	2.7435
Max	4.3553	4.2181	4.2867	4.2524	4.321	4.321	4.1838
Min	2.4691	2.5377	2.332	2.4348	2.332	2.4006	2.4006
Avg	3.5637	3.4208	3.3122	3.2847	3.3279	3.2793	3.4608

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283105 / 22/22 KV PATLIPADA SWITCHING

Feeder No / Name : 302 / POKHRAN

SHEDDABLE URBAN

Feeder KV- 22 / INCOMING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6406	2.6749	2.4348	2.9492	2.4006	2.7778	2.572
2	2.4348	2.4691	2.4006	2.7778	2.2291	2.6063	2.332
3	2.3663	2.332	2.3663	2.6406	2.0576	2.4691	2.1948
4	2.332	2.2634	2.2977	2.6063	2.0576	2.4006	2.1605
5	2.5034	2.2634	2.2291	2.6063	2.0576	2.2291	2.1605
6	2.9835	3.155	2.2977	2.6406	2.5377	2.4691	3.2236
7	3.8066	3.5322	3.0521	3.0178	3.4637	3.2236	3.5665
8	3.7037	3.6351	3.3608	3.0521	3.6351	3.6351	3.6008
9	4.3896	4.1152	4.0466	3.7037	4.1152	4.2181	4.0124
10	5.0755	4.4925	4.7325	4.4582	4.6296	4.8011	4.8011
11	5.1783	4.8354	5.3498	4.8697	5.0755	4.9383	5.0412
12	5.1783	4.9383	5.2126	4.9726	4.8011	4.8011	5.0755
13	4.4582	4.0124	4.3896	4.3553	3.9438	4.321	4.321
14	4.1495	4.0124	4.3553	4.0809	4.0466	4.4582	4.321
15	4.561	4.0809	4.4239	3.9438	4.2524	4.4925	4.561
16	4.2524	3.8752	4.5953	3.9781	4.4582	3.9781	4.6296
17	4.2181	4.0809	4.561	3.7037	4.0466	3.7723	4.4925
18	4.5268	4.1495	4.6982	3.9438	4.0809	3.9781	4.7668
19	5.487	4.904	5.0412	4.3896	4.4925	4.6296	5.2469
20	4.7668	4.3896	4.7668	4.321	4.321	4.1495	4.8011
21	4.1838	4.1495	4.1152	3.8752	4.0124	3.8066	4.3896
22	3.8409	3.6694	3.7723	3.5665	3.6008	3.4979	4.0466
23	3.5322	3.4294	3.4294	3.2236	3.1207	3.155	3.5665
24	3.155	3.0178	2.8464	3.0864	2.8121	2.9835	2.8464
Max	5.487	4.9383	5.3498	4.9726	5.0755	4.9383	5.2469
Min	2.332	2.2634	2.2291	2.6063	2.0576	2.2291	2.1605
Avg	3.9052	3.6866	3.7823	3.6151	3.5937	3.6580	3.8637

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283105 / 22/22 KV PATLIPADA SWITCHING

Feeder No / Name : 304 / AKBAR CAMP SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.6173	.5487	.583	.583	.5487	.583
2	.6173	.583	.5487	.5487	.583	.5144	.5144
3	.583	.583	.5487	.5487	.5487	.5144	.5144
4	.583	.583	.5487	.5487	.5487	.5144	.5487
5	.6173	.6173	.6173	.583	.5487	.5487	.5144
6	.7545	.7202	.6859	.583		.583	.7202
7	.9602	.823	.7202	.6173	.7202	.823	.823
8	.9259	.8573	.7545	.583	.6859	.823	.8916
9	.9602	1.6804	.7888	.6173	.8916	.7545	.8916
10	1.0288	.8916	.7888	.7888	1.0974	.8916	.9602
11	1.0288	.9602	.8916	.7888	1.1317	.8916	1.0288
12	1.2003	.8916	.9259	.7202	1.0974	.9602	1.2003
13	1.0631	.9259	.7545	.7888	.8916	.7888	1.0631
14	1.0631	.8573	.823	.6859	.8916	.8573	1.0631
15	.9602	.7888	.823	.583	.9602	.823	1.0631
16	.8916	.7202	.823	.583	.9259	.8573	.9602
17	.9259	.6173	.7888	.583	.8573	.7888	.8573
18	.9259		.8573	.583	.8916	.8916	.823
19	1.0631	.8916	1.0288	.8573	.9602	.8916	1.0288
20	.9259	.8916	.9602	.823	.8916	.823	.9259
21	.8916	.7545	.8573	.4458	.823	.7545	.9602
22	.823	.7202	.823	.6859	.823	.7202	.8916
23	.7545	.6516	.6516	.6173	.6173	.6173	.823
24	.6516	.6516	.6173	.6173	.6173	.583	.6516
Max	1.2003	1.6804	1.0288	.8573	1.1317	.9602	1.2003
Min	.583	.583	.5487	.4458	.5487	.5144	.5144
Avg	.8688	.7947	.7573	.6402	.8081	.7402	.8459

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283105 / 22/22 KV PATLIPADA SWITCHING

Feeder No / Name : 305 / KASARVADAVALI & STN X'MER NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 22 / INCOMING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9602	1.1317	1.1317	.9259	.8573	1.0631	1.1317
2	.9259	.9602	1.2003	.8573	.9259	1.0288	.9945
3	.9259	.9945	1.2003	.8573	.9602	.9602	.9602
4	.9602	1.0631	1.1317	.8916	1.0288	.9602	.9602
5	1.0631	1.1317	1.0974		1.0631	.9602	1.1317
6	1.2003	1.166	1.0974	.8573	1.0974	.9945	1.166
7	1.2689	1.3032	.9602	.7545	1.3032	1.0288	1.2346
8	1.3717	1.4746	1.0974	.8573	1.406	1.4403	1.5089
9	1.9204	1.7833	1.1317	.8916	1.7833	1.8519	1.8519
10	2.332	2.2634	1.6118	1.3032	2.2634	2.1262	2.2291
11	2.7435	2.332	1.749	1.5089	2.4006	2.332	2.5034
12	2.572	2.4691	1.8519	1.4746	2.5034	2.4006	2.4691
13	2.5377	2.5034	1.8176	1.6118	2.4348	2.4006	2.6406
14	2.6063	2.4691	1.8519	1.406	2.5034	2.4691	2.6406
15	2.4348	2.4348	1.749	1.406	2.4691	2.3663	2.572
16	2.6063	2.4691	1.7833	1.6461	2.4348	2.4006	2.6063
17	2.572	2.4006	1.5432	1.406	2.4348	2.3663	2.572
18	2.572	2.2634	1.6804	1.5775	2.332	2.332	2.5377
19	2.332	2.1948	1.7147	1.4746	2.2977	2.2291	2.4348
20	2.0919	1.989	1.749	1.6118	2.0233	1.9547	2.1262
21	1.9204	1.9204	1.4746	1.4403	1.9204	1.8861	1.9547
22	1.5775	1.4403	1.1317	1.4746	1.5432	1.4746	1.6118
23	1.406	1.3032	1.0631	.9259	1.3717	1.3375	1.4403
24	1.3032	1.2346	1.2003	.9602	.823	1.2346	1.2003
Max	2.7435	2.5034	1.8519	1.6461	2.5034	2.4691	2.6406
Min	.9259	.9602	.9602	.7545	.823	.9602	.9602
Avg	1.8418	1.7790	1.4175	1.2226	1.7575	1.7333	1.8533

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283105 / 22/22 KV PATLIPADA SWITCHING

Feeder No / Name : 306 / G.B. SOUTH

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.8642	5.8985	5.5213	6.07	5.6584	5.7956	5.4184
2	5.487	5.5899	5.3155	5.7956	5.487	5.4527	5.1097
3	5.3841	5.4527	5.2812	5.3841	5.3841	5.144	4.9726
4	5.487	5.4184	5.144	5.2126	5.3155	4.9383	4.904
5	6.2071	5.487	5.144	5.3498	5.487	4.904	5.0069
6	6.893	6.9273	5.487	5.5213		6.4815	6.7215
7	8.1962	7.8875	6.4815	6.0357	7.9904	6.9273	7.5446
8	8.5048	8.2991	7.1331	7.0645	7.8875	8.059	8.0933
9	8.642	8.9163	8.7449	8.1619	8.7106	8.5734	8.7792
10	9.6365	9.3279	9.4307	8.4362	9.1221	9.3964	9.225
11	9.9451	9.2936	9.6708	9.1221	9.3279	9.2936	9.7394
12	9.4307	9.225	9.1907	8.9849	9.1221	8.7449	9.3622
13	8.7449	8.3676	8.4019	8.2305	8.4362	7.9904	8.5734
14	8.3676	8.059	8.0247	7.7504	7.8189	7.476	8.0933
15	8.3676	8.1276	8.059	7.2017	7.4417	7.0988	8.2305
16	8.4705	7.9218	7.6818	6.893	7.6132	7.2359	7.9904
17	8.3333	7.9218	7.8189	6.7901	7.7504	7.2359	4.8011
18	8.3333	7.8532	8.1619	7.2017	7.6818	7.476	4.6639
19	9.6022	9.3622	9.808	8.6077	8.9506	8.9163	4.904
20	9.3964	8.9849	9.0535	8.2648	8.8135	8.8135	4.5268
21	9.0192	8.7106	8.6077	7.9904	8.7449	8.4019	4.2524
22	8.0933	7.8532	7.9561	7.3388	7.7846	7.4417	3.738
23	7.3731	6.9616	7.0302	6.5501	6.8587	6.1728	3.3608
24	6.9959	6.5158	6.1728	6.653	5.8299	5.9671	5.727
Max	9.9451	9.3622	9.808	9.1221	9.3279	9.3964	9.7394
Min	5.3841	5.4184	5.144	5.2126	5.3155	4.904	3.3608
Avg	7.9490	7.6818	7.4717	7.1088	7.5312	7.2474	6.4058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283106 / 22/11 KV RUNWAL GARDEN

SUBSTAT

Feeder No / Name : 201 / 11KV UNIVERSITY

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	.0233	.0094	.0094	.0264	.0177	.0261
24				.0094	.0248	.0179
Max	.0233	.0094	.0094	.0264	.0248	.0261
Min	.0233	.0094	.0094	.0094	.0177	.0179
Avg	.0233	.0094	.0094	.0179	.0213	.022

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283106 / 22/11 KV RUNWAL GARDEN

SUBSTAT

Feeder No / Name : 202 / RUNWAL GARDEN CITY PH-2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8						.8596
12	.5847	.5731	.6878	.5731	.5552	.567
22	.6447					
24				.6154	.6024	.6089
Max	.6447	.5731	.6878	.6154	.6024	.8596
Min	.5847	.5731	.6878	.5731	.5552	.567
Avg	.6147	.5731	.6878	.5943	.5788	.6785

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283106 / 22/11 KV RUNWAL GARDEN

SUBSTAT

Feeder No / Name : 203 / RUNWAL CONSTRUCTION

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	.9745	1.2971	1.182	1.2308	1.0745	1.0924
24				.724	.7442	.7343
Max	.9745	1.2971	1.182	1.2308	1.0745	1.0924
Min	.9745	1.2971	1.182	.724	.7442	.7343
Avg	.9745	1.2971	1.182	.9774	.9094	.9134

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283107 / 22/11KV HAWARE CITY

SUBSTATION

Feeder No / Name : 201 / RATANTEJ

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.3239	.3239	.3048	.3239	.3086	.2743
2	.4001	.3239	.3048	.3048	.3048	.3086	.2743
3	.381	.2858	.3048	.2667	.3048	.3086	.2572
4	.362	.2858	.2858	.2667	.2858	.3086	.2401
5	.381	.2667	.3048	.2667	.3048	.3086	.2401
6	.381	.3429	.3429	.3048	.3429	.3258	.2401
7	.362	.3429	.3239	.3048	.381	.3258	.2401
8	.4001	.3239	.3429	.3239	.3429	.3429	.2572
9	.381	.381	.362	.3048	.362	.3772	.3601
10	.381	.381	.362	.4191	.3772	.3601	.3944
11	.4001	.381	.4191	.4382	.3772	.3772	.3944
12	.381	.4191	.4572	.4001	.3772	.3772	.3429
13	.3429	.381	.4001	.4001	.3772	.2572	.3258
14	.3239	.3429	.4001	.3048	.2743	.2572	.3258
15	.3239	.3048	.4001	.3429		.2743	.2915
16	.3239	.3048	.3429	.3429	.3086	.2743	.2572
17	.3239	.3429	.3429	.362	.2915	.2743	.3258
18	.362	.3239	.3429	.4001	.2915	.2915	.3258
19	.4572	.4382	.4191	.4763	.3944	.3944	.3258
20	.4382	.4001	.4001	.4382	.3601	.3944	.3944
21	.4191	.4191	.4001	.4001	.3601	.3429	.3944
22	.4191	.4001	.381	.381	.3258	.3429	.3601
23	.381	.362	.362	.381	.3086	.3258	.3601
24	.4382	.3429	.3429	.3239	.3429	.3086	.2743
Max	.4572	.4382	.4572	.4763	.3944	.3944	.3944
Min	.3239	.2667	.2858	.2667	.2743	.2572	.2401
Avg	.3826	.3509	.3612	.3524	.3356	.3236	.3115

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283107 / 22/11KV HAWARE CITY

SUBSTATION

Feeder No / Name : 202 / PLATINUM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.3429	.3239	.3239	.3048	.3429	.3258
2	.5335	.3048	.3048	.3048	.2858	.3258	.3429
3	.5144	.3048	.2858	.3048	.2858	.3258	.3429
4	.5525	.2667	.2858	.2858	.2667	.3429	.3258
5	.5335	.2858	.3048	.2858	.3048	.3258	.3258
6	.5716	.381	.3429	.3429	.4001	.3601	.3601
7	.5906	.4382	.4001	.381	.4763	.4287	.3772
8	.5906	.4763	.4763	.4001	.5525	.5144	.4115
9	.5716	.5716	.6287	.6478	.5658	.6001	.4458
10	.5144	.4954	.6097	.5716	.4801	.5658	.4115
11	.4954	.4572	.4763	.4763	.4458	.3944	.4115
12	.4954	.4001	.4763	.4572	.3944	.3944	.4287
13	.4001	.4001	.4763	.4001	.3944	.3429	.3086
14	.4382	.4191	.4001	.4001	.3944	.3258	.2915
15	.4191	.381	.362	.381	.2915	.2743	.3258
16	.4001	.3239	.3429	.381	.3258	.2915	.2743
17	.381	.362	.4191	.4001	.3086	.3772	.3258
18	.3429	.362	.4572	.4763	.4458	.3772	.4115
19	.5525	.5906	.1524	.5525	.4801	.4801	.4458
20	.5335	.4763	.4572	.4954	.4115	.4115	.5144
21	.4954	.5335	.4191	.4572	.4115	.3944	.463
22	.4382	.4954	.4191	.4001	.3772	.4287	.4287
23	.4572	.4001	.4382	.381	.3429	.3601	.3944
24	.5144	.362	.3239	.3429	.3239	.3086	.3086
Max	.5906	.5906	.6287	.6478	.5658	.6001	.5144
Min	.3429	.2667	.1524	.2858	.2667	.2743	.2743
Avg	.4930	.4096	.3993	.4104	.3863	.3872	.3751

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283107 / 22/11KV HAWARE CITY

SUBSTATION

Feeder No / Name : 203 / 11 KV HAWARE CITY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.3239	.2858	.2667	.3239	.2572	.2229
2	.4572	.3048	.2858	.2477	.3048	.2401	.2229
3	.4382	.3048	.2477	.2477	.3048	.2572	.2229
4	.4763	.2667	.2477	.2286	.2858	.2743	.2229
5	.4572	.2858	.2667	.2286	.3239	.3086	.2229
6	.4572	.3429	.3239	.3239	.381	.3086	.2401
7	.4954	.4191	.381	.3429	.4382	.3258	.2572
8	.5144	.5335	.4001	.381	.4572	.3429	.2743
9	.4954	.4382	.4954	.5144	.4287	.4458	.4458
10	.4382	.4191	.5335	.5525	.3429	.4115	.3944
11	.4191	.381	.4382	.4572	.3086	.3601	.3944
12	.362	.3239	.3429	.4191	.3258	.3429	.2743
13	.2667	.2667	.2858	.362	.3258	.2743	.2743
14	.2667	.3048	.2858	.4001	.2229	.2572	.2572
15	.2667	.2667	.2667	.2858	.2401	.2229	.2058
16	.2477	.2477	.2667	.2858	.2229	.2401	.1543
17	.2667	.2858	.2858	.3048	.2572	.2572	.2229
18	.3048	.3239	.3239	.3239	.2743	.2572	.2401
19	.381	.362	.4001	.3239	.3086	.2743	.2229
20	.4001	.381	.381	.5335	.3086	.3258	.3258
21	.4763	.4001	.3429	.3429	.3601	.3429	.3429
22	.4382	.381	.381	.3239	.3258	.3601	.3429
23	.4001	.3239	.3048	.3429	.2572	.3086	.3086
24	.4191	.3429	.3048	.2667	.3239	.2401	.2572
Max	.5144	.5335	.5335	.5525	.4572	.4458	.4458
Min	.2477	.2477	.2477	.2286	.2229	.2229	.1543
Avg	.3985	.3429	.3366	.3461	.3189	.3015	.2729

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283107 / 22/11KV HAWARE CITY

SUBSTATION

Feeder No / Name : 204 / UNNATI GREEN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.2858	.2477	.2667	.3048	.2229	.3258
2	.362	.2667	.2286	.2477	.2667	.2229	.3086
3	.3429	.2667	.2286	.2096	.2667	.2229	.3258
4	.3239	.2477	.1905	.2096	.2477	.2401	.3086
5	.362	.2477	.2286	.1905	.2858	.2401	.3086
6	.3429	.3048	.2667	.2096	.3048	.2229	.3086
7	.362	.3429	.2667	.2667	.362	.2401	.3086
8	.381	.362	.3048	.3048	.381	.2401	.3258
9	.4001	.4191	.4001	.4191	.3258	.3429	.3429
10	.381	.4572	.4382	.4382	.3772	.4458	.3601
11	.381	.4001	.381	.4382	.3772	.4458	.3772
12	.362	.4572	.381	.4382	.3944	.3944	.3772
13	.2858	.4001	.381	.362	.3944	.2572	.2572
14	.2858	.3048	.4001	.3429	.2572	.2572	.2572
15	.2667	.2858	.3429	.3239	.2401	.3258	.2401
16	.362	.3048	.3239	.3239	.2572	.3258	.1886
17	.3239	.2858	.3239	.3239	.2915	.2915	.2915
18	.362	.3429	.3429	.4001	.2915	.2915	.2401
19	.3429	.362	.4191	.5525	.3258	.3772	.2915
20	.3048	.3239	.381	.362	.3086	.3429	.3086
21	.3239	.3429	.3239	.3239	.2743	.3258	.3086
22	.3429	.381	.3239	.3239	.2915	.3086	.3258
23	.3048	.3048	.2858	.2858	.2229	.2743	.3258
24	.3429	.3048	.2667	.2858	.3239	.2229	.2572
Max	.4001	.4572	.4382	.5525	.3944	.4458	.3772
Min	.2667	.2477	.1905	.1905	.2229	.2229	.1886
Avg	.3413	.3334	.3199	.3271	.3072	.2951	.3029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283113 / 22/11 KV ACME-JAI BHAWANI

NAGA

Feeder No / Name : 202 / MMRDA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.1886	.1698	.1698	.1698	.2075	.1698	.1509
Max	.1886	.1698	.1698	.1698	.2075	.1698	.1509
Min	.1886	.1698	.1698	.1698	.2075	.1698	.1509
Avg	.1886	.1698	.1698	.1698	.2075	.1698	.1509

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283113 / 22/11 KV ACME-JAI BHAWANI

NAGA

Feeder No / Name : 203 / AKANKSHA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
23				.811			
24	.811	.811	.811		.6516	.7545	.6979
Max	.811	.811	.811	.811	.6516	.7545	.6979
Min	.811	.811	.811	.811	.6516	.7545	.6979
Avg	.811	.811	.811	.811	.6516	.7545	.6979

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283113 / 22/11 KV ACME-JAI BHAWANI

NAGA

Feeder No / Name : 204 / BASILIA - I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0754	.0566	.0754	.0754	.0754	.0943	.0754
Max	.0754	.0566	.0754	.0754	.0754	.0943	.0754
Min	.0754	.0566	.0754	.0754	.0754	.0943	.0754
Avg	.0754	.0566	.0754	.0754	.0754	.0943	.0754

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283113 / 22/11 KV ACME-JAI BHAWANI

NAGA

Feeder No / Name : 205 / DOSTI IMPIRIA - I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0754	.0566	.0754	.0754	.0566	.0566	.0566
Max	.0754	.0566	.0754	.0754	.0566	.0566	.0566
Min	.0754	.0566	.0754	.0754	.0566	.0566	.0566
Avg	.0754	.0566	.0754	.0754	.0566	.0566	.0566

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283113 / 22/11 KV ACME-JAI BHAWANI

NAGA

Feeder No / Name : 206 / DOSTI IMPIRIA - II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
23		.415			.3772		
24	.3961		.415	.3961		.3772	.3961
Max	.3961	.415	.415	.3961	.3772	.3772	.3961
Min	.3961	.415	.415	.3961	.3772	.3772	.3961
Avg	.3961	.415	.415	.3961	.3772	.3772	.3961

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283037 / 22/11 KV DOSTI VIHAR

Feeder No / Name : 201 / DF-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	11-FEB-18	12-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10			.8299	
11			.8299	
12			.6413	
13			.6036	
14			.5658	
15			.5658	
16			.5093	
17			.5093	
18			.6602	
19			.7545	
20			.7545	
21			.7545	
22			.7545	
23			.679	
24	.7545	.5475	.6602	.5584
Max	.7545	.5475	.8299	.5584
Min	.7545	.5475	.5093	.5584
Avg	.7545	.5475	.6715	.5584

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283037 / 22/11 KV DOSTI VIHAR

Feeder No / Name : 202 / DF-2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	11-FEB-18	12-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2353	
2			.2353	
3			.2172	
4			.1991	
5			.1991	
6			.2715	
7			.3439	
8			.3801	
9			.3982	
10			.362	
11			.362	
12			.2353	
13			.2172	
14			.2172	
15			.2172	
16			.2172	
17			.2172	
18			.2172	
19			.2172	
20			.2715	
21			.3077	
22			.3077	
23			.2715	
24	.3258	.2077	.2715	.242
Max	.3258	.2077	.3982	.242
Min	.3258	.2077	.1991	.242
Avg	.3258	.2077	.2662	.242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283037 / 22/11 KV DOSTI VIHAR

Feeder No / Name : 203 / DF-3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	11-FEB-18	12-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1698	
2			.1509	
3			.1509	
4			.1509	
5			.1509	
6			.1698	
7			.2075	
8			.2641	
9			.2263	
10			.2263	
11			.2263	
12			.2263	
13			.1886	
14			.1886	
15			.1509	
16			.1509	
17			.1509	
18			.1886	
19			.1886	
20			.1886	
21			.2263	
22			.2452	
23			.2075	
24	.2218	.1888	.1698	.2048
Max	.2218	.1888	.2641	.2048
Min	.2218	.1888	.1509	.2048
Avg	.2218	.1888	.1902	.2048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283037 / 22/11 KV DOSTI VIHAR

Feeder No / Name : 205 / DF-5

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3326	.3129	
2			.2957	.3129	
3			.2957	.2761	
4			.2772	.2945	
5			.2587	.3681	
6			.3696	.4049	
7			.499	.4601	
8			.5544	.4969	
9			.462	.4417	
10			.4066	.4601	
11			.4066	.4049	
12			.3696	.3865	
13			.3326	.3313	
14			.3142	.3129	
15			.3142	.3129	
16			.3142	.2945	
17			.3142	.2945	
18			.3696	.3313	
19			.3696	.3681	
20			.3696	.4233	
21			.3881	.3497	
22			.3881	.3681	
23			.3696		
24	.3696	.3398	.3696	.3497	.3537
Max	.3696	.3398	.5544	.4969	.3537
Min	.3696	.3398	.2587	.2761	.3537
Avg	.3696	.3398	.3642	.3633	.3537

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283037 / 22/11 KV DOSTI VIHAR

Feeder No / Name : 206 / DF-6

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5316	.5337	
2			.463	.5337	
3			.4973	.5337	
4			.5316	.5153	
5			.463	.5521	
6			.6001	.5889	
7			.6516	.6441	
8			.703	.6994	
9	.7362		.7716	.8282	
10			.7716	.9018	
11			.7716	.8834	
12			.703	.8466	
13			.6859	.7546	
14			.6516	.6441	
15			.6001	.6626	
16			.6001	.5521	
17			.6001	.5705	
18			.6516	.6626	
19			.703	.7362	
20			.703	.7914	
21			.703	.7362	
22			.6687	.6994	
23			.583		
24	.7011	.5475	.6001	.5705	.5956
Max	.7362	.5475	.7716	.9018	.5956
Min	.7011	.5475	.463	.5153	.5956
Avg	.7187	.5475	.6337	.6714	.5956

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283037 / 22/11 KV DOSTI VIHAR

Feeder No / Name : 207 / DF-7

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5755		.1478	.1472	
2		.5935		.1478	.1472	
3		.6121		.1663	.1472	
4		.6295		.1294	.1472	
5		1.3849		.1478	.184	
6		.5755		.1848	.184	
7		.6834		.2402	.2209	
8		.8633		.2772	.2761	
9		.5889		.2587	.2393	
10		.8813		.2587	.3497	
11		.9183		.2587	.2761	
12		.8633		.2218	.2577	
13		.7194		.1848	.2024	
14		.7163		.1848	.1472	
15		.6626		.1663	.1472	
16		.6834		.1663	.1656	
17				.1663	.1656	
18				.1848	.184	
19		.8633		.1848	.2209	
20		.8273		.1848	.184	
21		.7194		.2218	.2393	
22		.7163		.2218	.184	
23		.4281		.1848		
24	.1867	.5575	.1699	.1848	.1656	.1489
Max	.1867	1.3849	.1699	.2772	.3497	.1489
Min	.1867	.4281	.1699	.1294	.1472	.1489
Avg	.1867	.7301	.1699	.1948	.1992	.1489

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283080 / 22/11KV MHADA S/STN

Feeder No / Name : 203 / FEEDER NO. 3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4435	.4251	.3881	.3326	.3511	.4251	.3696
2	.3696	.3881	.2402	.3326	.3142	.3326	.3142
3	.3511	.3326	.2218	.2587	.2772	.3142	.2772
4	.4066	.3511	.3326	.2772	.2772	.3696	.2402
5	.6653	.4435	.4435	.6283	.3326	.5914	.3881
6	.7023	.7023	.6838	.5914	.462	.6468	.6468
7	.6838	.7207	.7023	.5544	.6838	.6099	.7023
8	.7207	.7392	.7207	.7207	.6838	.7023	.6283
9	.7947	.7023	.7207	.7577	.6838	.6838	.7207
10	.8501	.7207	.7762	.7947	.7762	.7207	.7762
11	.7762	.7023	.7207	.7577	.7207	.7207	.7207
12	.7762	.7023	.6838	.8501	.6838	.6653	.6838
13	.6468	.6838	.6468	.6653	.7023	.6838	.5544
14	.5544	.5544	.462	.3696	.5729	.499	.5914
15	.3696	.4805	.3696	.4066	.3142	.3511	.499
16	.4805	.4066	.4066	.4066	.5359	.3511	.4805
17	.462	.3696	.4435	.4435	.4435	.4435	.4805
18	.6283	.5544	.6838	.3326	.5729	.5914	.5544
19	.7947	.8316	.7207	.7392	.7947	.7392	.8131
20	.8131	.7392	.7207	.7577	.7392	.7392	.8501
21		.7577	.7023	.7023	.6468	.6838	.7762
22	.7392	.6838	.7207	.6653	.6283	.5914	.7392
23	.5729	.5544	.6468	.5544	.5914	.6283	.7023
24	.499	.5175	.4805	.4805	.4251	.5175	.4066
Max	.8501	.8316	.7762	.8501	.7947	.7392	.8501
Min	.3511	.3326	.2218	.2587	.2772	.3142	.2402
Avg	.6131	.5860	.5683	.5575	.5506	.5667	.5798

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283080 / 22/11KV MHADA S/STN

Feeder No / Name : 204 / FEEDER NO. 4

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.829	1.9204	1.6827	1.829	1.7375	1.6278	1.6278
2	1.7558	1.7375	1.6461	1.7193	1.701	1.5181	1.4998
3	1.7193	1.701	1.5364	1.6644	1.6278	1.4449	1.4632
4	1.7193	1.7558	1.6278	1.6827	1.6644	1.4449	1.4266
5	1.7193	1.829	1.7193	1.9204	1.7375	1.4632	1.4998
6	1.829	2.0851	1.9204	1.829	1.8473	1.6461	1.8107
7	2.268	2.0119	2.1948	1.7924	2.0485	1.829	2.1765
8	2.524	2.5057	2.4326	2.1765	2.268	2.268	2.396
9	2.4691	2.5423	2.4326	2.4691	2.3045	2.524	2.4326
10	2.3594	2.2862	2.2862	2.3594	2.1582	2.4326	2.3228
11	2.1948	2.1582	2.2314	2.4691	2.268	2.2862	2.1765
12	2.0851	2.0119	2.1033	2.4691	1.9753	2.0302	2.0485
13	2.1948	1.9387	1.9753	2.1216	1.8473	1.8107	1.9022
14	2.0851	1.829	1.7924	1.9204	1.7924	1.701	1.8839
15	1.8107	1.7741	1.6827	1.8473	1.6644	1.6095	1.7741
16	1.7924	1.7375	1.7193	1.8107	1.6644	1.4632	1.7375
17	1.9753	1.829	1.8656	1.8107	1.7375	1.6644	1.957
18	2.1399	1.9753	2.2131	2.0485	2.1399	2.1582	2.1033
19	2.7252	2.5789	2.652	2.4874	2.7069	2.5606	2.6703
20	2.7801	2.5789	2.7069	2.524	2.5606	2.6703	2.7984
21		2.5423	2.6612	2.4874	2.4874	2.4874	2.7435
22	2.7618	2.5606	2.4691	2.396	.4024	2.396	2.5606
23	2.3594	2.2131	2.2497	2.1033	2.0668	2.0851	2.3594
24	2.0668	2.0302	1.9753	1.9136	1.8473	1.8107	1.8473
Max	2.7801	2.5789	2.7069	2.524	2.7069	2.6703	2.7984
Min	1.7193	1.701	1.5364	1.6644	.4024	1.4449	1.4266
Avg	2.1375	2.0889	2.0740	2.0771	1.9273	1.9555	2.0508

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283080 / 22/11KV MHADA S/STN

Feeder No / Name : 205 / FEEDER NO. 5

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.443	.4572	.3898	.4252	.4024	.3898	.3721
2	.4252		.3721	.3898	.4024	.3544	.3544
3	.4075	.4024	.3721	.3721	.3658	.3366	.3366
4	.4075	.4207	.3898	.3544	.3658	.3544	.3544
5	.4252	.4207	.4252	.3544	.3658	.3544	.4075
6	.4607	.5304	.4607	.3721	.3841	.3898	.4607
7	.4784	.4938	.5138	.3544	.4572	.4075	.4075
8	.4961	.5487	.567	.4607	.5304	.4961	.5138
9	.6201	.567	.5138	.5853	.567	.5493	.5493
10	.5853	.4607	.4961	.5304	.443	.4961	.439
11	.4755	.4252	.4784	.5853	.4607	.443	.4572
12	.4207	.3898	.4075	.4755	.4075	.4252	.4207
13	.439	.3721	.3721	.4755	.4075	.4784	.4207
14	.439	.3721	.3898	.4207	.3721	.443	.4024
15	.3658	.3544	.3721	.4024	.3366	.3544	.3841
16	.3658	.3366	.3721	.3658	.3012	.3366	.3658
17	.4024	.3366	.3544	.3658	.3366	.3189	.3658
18	.4207	.4607	.3898	.4207	.3721	.4075	.3841
19	.6219	.6556	.567	.5853	.567	.5316	.6219
20	.6584	.6201	.6024	.567	.567	.567	.6219
21		.5847	.567	.567	.5493	.567	.6401
22	.5853	.567	.6379	.567	.567	.5493	.6401
23	.5487	.5138	.5493	.5121	.4961	.4961	.6401
24	.4784	.5121	.4607	.4961	.439	.4252	.4252
Max	.6584	.6556	.6379	.5853	.567	.567	.6401
Min	.3658	.3366	.3544	.3544	.3012	.3189	.3366
Avg	.4770	.4697	.4592	.4585	.4360	.4363	.4577

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283110 / 22/11 kv Akruti Substation

Feeder No / Name : 201 / LAXMI INDUSTRIES

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.2195	.1829		.1829	.1829	.1646
2	.1829	.2012	.1646		.1646	.1646	.1646
3	.1829	.2012	.1463		.1448	.1646	.1463
4	.1829	.2012	.1463	.2378	.1463	.1646	.1463
5	.2012	.2012	.1646		.1646	.1829	.1829
6	.2012	.2195	.1829		1.8656	.2012	.2195
7	.2195	.2378	.2012		.2561	.2012	.2926
8	.2195	.2561	.2378	.2743	.3292	.2012	.2012
9	.2378		.2743		.3841	.3109	.3841
10	.4938	.4572	.4024	.3292	.4572	.4207	.4207
11	.5121	.5487	.3841	.3109	.4572	.439	.4755
12	.695	.4938	.4024	.3292	.4755	.4572	.4755
13	.5121	.3841	.3475	.2378	.3475	.3841	.439
14	.3475	.3475	.3475		.3109	.4024	.3841
15	.4207	.4024	.3841		.3475	.4207	.439
16	.4572	.4207	.3841	.1829	.3475	.4207	.4938
17	.4572	.439	.3841		.3658	.3658	.4755
18	.4207	.4024	.3475		.4207	.3292	.4207
19	.4024	.3658			.3658	.3109	.4572
20	.3475	.2743		.2561	.3475	.2561	.3658
21	.3109	.2743			.3109	.2378	.2926
22	.2378	.2195			.2743	.2195	.2743
23	.2378			.1829	.2195	.2012	.2378
24	.2195	.2195	.2012	.1646	.2012	.1829	.1829
Max	.695	.5487	.4024	.3292	1.8656	.4572	.4938
Min	.1829	.2012	.1463	.1646	.1448	.1646	.1463
Avg	.3300	.3176	.2782	.2506	.3703	.2843	.3224

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283110 / 22/11 kv Akruti Substation

Feeder No / Name : 202 / OLD MSEB SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.543	.4887		.4887	.5068	.4525
2	.5973	.543	.4887		.4887	.5068	.4525
3	.5973	.5249	.4525		.4572	.4887	.4525
4	.5973	.5249	.4525	.5249	.4525	.4887	.5068
5	.6154	.5068	.543		.4755	.4887	.5249
6	.6335	.5068	.5792		.5611	.4887	.5611
7	.6335	.5792	.6154		.5611	.543	.6697
8	.6878	.6516	.6697	.6154	.5792	.6154	.6516
9	.6697		.6516		.5792	.6516	.6697
10	.6878	.6335	.724	.7133	.4525	.6516	.6878
11	.6878	.6154	.724	.695	.5973	.6154	.6878
12	.6697	.5973	.724	.6401	.6335	.6516	.6878
13	.6154	.5792	.5792	.567	.5249	.5068	.5973
14	.5792	.543	.5611		.5068	.5068	.5792
15	.543	.5249	.543		.4887	.4887	.5611
16	.6154	.5249	.543	.5611	.4887	.4887	.5611
17	.6348	.5611			.543	.6154	.6516
18	.6697	.6154	.6697		.5973	.5792	.7421
19	.8688	.8326			.8145	.7964	.8688
20	.8869	.8326		.7783	.7964	.7783	.8688
21	.7783	.7783				.7421	.8507
22	.7783	.724			.6697	.6878	.7783
23	.6516			.6154	.6154	.6154	.724
24	.6516	.5792	.5792	.6335	.5792	.5249	.543
Max	.8869	.8326	.724	.7783	.8145	.7964	.8688
Min	.543	.5068	.4525	.5249	.4525	.4887	.4525
Avg	.6667	.6055	.5883	.6344	.5631	.5845	.6388

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283110 / 22/11 kv Akruti Substation

Feeder No / Name : 203 / VIHANG PARK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1543	.12		.12	.12	.12
2	.1543	.1372	.12		.12	.12	.12
3	.1715	.12	.12		.12	.12	.1029
4	.1886	.12	.1372	.1372	.1372	.1029	.12
5	.2229	.12	.1543		.1029	.1029	.1372
6	.2401	.1372	.1715		.1372	.12	.1372
7	.2401	.1715	.1886		.1543	.1372	.1715
8	.2058	.2058	.1715	.1886	.1543	.1543	.1715
9	.2058		.1543		.1543	.1372	.1886
10	.1543	.1715	.1372	.1646	.1543	.1715	.1372
11	.1543	.1715	.1372	.1829	.12	.1372	.1543
12	.1372	.12	.1372	.1463	.1372	.1372	.12
13	.1029		.12	.1463	.12	.1372	.12
14	.12	.12	.12		.12	.1372	.1372
15	.1372	.12	.1372		.1029	.12	.1372
16	.1029	.12	.1372	.0857	.1029	.12	.12
17	.1029	.1029	.1372		.1029	.1029	.1029
18	.1029	.1372	.1372		.12	.1029	.1372
19	.1715	.1715			.1543	.1715	.1715
20	.1886	.1886		.1543	.1715	.1886	.1886
21	.1886	.1886			.1886	.2058	.2058
22	.2058	.1886			.1715	.2229	.2401
23	.1715			.1715	.1543	.1543	.1886
24	.1543	.1543	.1543	.1715	.1543	.1372	.1543
Max	.2401	.2058	.1886	.1886	.1886	.2229	.2401
Min	.1029	.1029	.12	.0857	.1029	.1029	.1029
Avg	.1658	.1486	.1417	.1549	.1365	.1400	.1493

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283110 / 22/11 kv Akruti Substation

Feeder No / Name : 204 / GREEN WOOD SEAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	10-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10			.0377	.0566	
12				.0566	.0566
13				.0566	
15				.0566	
16	.0377				
17	.0377				
18		.0514			
19				.0566	
Max	.0377	.0514	.0377	.0566	.0566
Min	.0377	.0514	.0377	.0566	.0566
Avg	.0377	.0514	.0377	.0566	.0566

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283110 / 22/11 kv Akruti Substation

Feeder No / Name : 206 / BHAITHI COLONY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9134	.8596	.7522		.7701	.7522	.7343
2	1.0029	.8238	.7701		.7522	.7164	.7343
3	1.0387	.8238	.7522		.8238	.7164	.7164
4	1.0566	.7522	.8238	.7701	.7701	.7164	.8059
5	1.0566	.7522	.8954		.7343	.7164	.8596
6	1.0566	.7522	.9492		.8417	.7164	.9134
7	1.0745	.8596	1.0029		.8596	.8775	1.0387
8	1.0566	1.0029	1.0029	.6805	.8775	1.0387	1.0208
9	1.0387		.985		.8775	1.0029	.9671
10	.9134	.8954	.8596	1.0425	.9134	1.0029	.8775
11	.8596	.8954	.8596	1.0242	.8238	.9134	.8596
12	.8417	.8954	.8596	.9694	.8238	.8954	.8059
13	.7343	.8775	.788	1.0791	.8059	.8954	.8059
14	.8059	.8059	.788		.7522	.8238	.788
15	.7522	.7701	.7701		.7522	.7343	.8059
16	.8059	.7164	.7701	.9313	.7343	.6984	.7522
17	.8238	.7701	.8238		.8238	.788	.8775
18	.8238	.7701	.8954		.8238	.8417	.9313
19	1.1104	1.0924			1.1283	1.1104	1.1462
20	1.0745	1.1283		1.0566	1.0745	1.0208	1.1641
21	1.0566	1.0387				1.0208	1.1462
22	1.0029	.985			.9671	.985	1.1283
23	.9313			.9671	.9134	.9313	1.0387
24	.9134	.9313	.9671	.8954	.788	.788	.8238
Max	1.1104	1.1283	1.0029	1.0791	1.1283	1.1104	1.1641
Min	.7343	.7164	.7522	.6805	.7343	.6984	.7164
Avg	.9477	.8727	.8587	.9416	.8448	.8626	.9059

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283076 / 22/22 KV WAGLE ETATE

SWITCHING

Feeder No / Name : 301 / Feeder No I

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0178	3.2065	2.8292	3.2065	3.0178	3.2065	3.3951
2	3.0178	3.0178	2.8292	3.2065	2.8292	3.0178	3.3951
3	3.0178	3.0178	2.8292	3.2065	2.8292	3.0178	3.3951
4	3.0178	3.0178	2.8292	3.2065	2.8292	3.0178	3.3951
5	3.0178	3.0178	2.8292	3.2065	2.8292	3.0178	3.3951
6	3.0178	2.8292	2.8292	3.2065	2.8292	3.0178	3.5837
7	3.2065	2.8292	3.0178	3.2065	2.8292	3.0178	3.5837
8	3.3951	3.0178	3.3951	3.2065	3.2065	3.3951	3.7723
9	4.3381	3.3951	3.5837	3.3951	4.3381	4.1495	4.5268
10	5.2812	3.9609	4.5268	4.1495	5.0926	5.2812	5.6584
11	5.8471	4.1495	4.5268	3.7723	5.2812	5.0926	6.0357
12	5.2812	3.7723	4.7154	3.7723	5.0926	5.0926	6.0357
13		3.3951	3.7723	3.0178	4.5268	4.1495	4.904
14	5.4698	3.5837	4.7154	3.9609	5.4698	4.904	5.8471
15	5.6584	3.0178	4.3381	3.5837	5.4698	5.0926	6.0357
16	5.8471	3.3951	4.5268	3.3951	5.6584	5.4698	6.0357
17	5.2812	3.9609	4.1495	3.7723	5.6584	5.2812	6.0357
18	4.904	3.7723	3.9609	3.5837	5.2812	4.5268	5.6584
19	4.7154	3.7723	4.1495	3.7723	5.2812	4.5268	5.4698
20	3.7723	3.3951	4.3381	3.3951	4.3381	4.1495	4.7154
21	3.7723	3.3951	3.7723	3.2065	3.7723	3.7723	4.1495
22	3.5837	3.2065	3.5837	3.0178	3.5837	3.7723	3.9609
23	3.3951	3.2065	3.5837	3.0178	3.7723	3.5837	3.9609
24	3.0178	3.2065	3.0178	3.2065	3.0178	3.2065	3.3951
Max	5.8471	4.1495	4.7154	4.1495	5.6584	5.4698	6.0357
Min	3.0178	2.8292	2.8292	3.0178	2.8292	3.0178	3.3951
Avg	4.1249	3.3558	3.6937	3.4029	4.1181	4.0316	4.5975

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283076 / 22/22 KV WAGLE ETATE

SWITCHING

Feeder No / Name : 302 / Feeder No -II

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8861	2.0748	1.5089	1.5089	1.8861	1.5089	1.5089
2	1.6975	1.8861	1.5089	1.3203	1.6975	1.3203	1.3203
3	1.6975	1.8861	1.5089	1.3203	1.6975	1.3203	1.3203
4	1.6975	1.6975	1.5089	1.3203	1.6975	1.3203	1.5089
5	1.6975	1.6975	1.3203	1.3203	1.6975	1.3203	1.5089
6	1.6975	1.5089	1.1317	1.1317	1.6975	1.3203	1.3203
7	1.6975	1.5089	1.1317	1.1317	1.6975	1.3203	1.3203
8	2.2634	1.8861	1.3203	1.3203	2.2634	1.5089	1.5089
9	3.0178	2.6406	1.8861	1.5089	2.6406	1.8861	2.0748
10	3.3951	3.0178	2.452	1.6975	3.3951	2.6406	2.6406
11	3.5837	3.2065	2.6406	2.0748	3.5837	2.6406	3.0178
12	3.7723	3.3951	2.452	1.8861	3.5837	2.6406	3.2065
13	3.5837	3.3951	2.452	1.8861		2.452	3.2065
14	3.5837	3.2065	2.452	1.8861	3.2065	2.8292	3.2065
15	3.9609	3.2065	2.452	1.8861	3.3951	2.6406	3.3951
16	3.9609	3.0178	2.452	2.0748	3.2065	2.452	3.3951
17	3.7723	2.452	2.2634	1.6975	3.2065	2.452	3.2065
18	3.7723	2.2634	2.0748	1.8861	2.8292	2.0748	2.6406
19	3.2065	2.0748	1.8861	1.8861	2.452	1.8861	2.2634
20	2.452	1.5089	1.6975	1.6975	1.8861	1.6975	1.8861
21	2.2634	1.5089	1.5089	1.8861	1.8861	1.5089	1.6975
22	2.0748	1.5089	1.5089	1.8861	1.6975	1.5089	1.5089
23	2.0748	1.5089	1.5089	1.6975	1.6975	1.5089	1.5089
24	1.8861	1.8861	1.6975	1.5089	1.8861	1.5089	1.5089
Max	3.9609	3.3951	2.6406	2.0748	3.5837	2.8292	3.3951
Min	1.6975	1.5089	1.1317	1.1317	1.6975	1.3203	1.3203
Avg	2.6956	2.2477	1.8468	1.6425	2.3864	1.8861	2.1534

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283076 / 22/22 KV WAGLE ETATE

SWITCHING

Feeder No / Name : 305 / Feeder No V

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0748	1.8861	1.5089	1.6975	1.6975	1.6975	1.5089
2	1.8861		1.5089	1.5089	1.6975	1.5089	1.5089
3	1.8861	1.8861	1.5089	1.5089	1.6975	1.5089	1.5089
4	1.8861	1.8861	1.5089	1.5089	1.6975	1.5089	1.5089
5	1.8861	1.8861	1.5089	1.5089	1.6975	1.5089	1.5089
6	1.8861	1.6975	1.5089	1.5089	1.6975	1.5089	1.6975
7	1.8861	1.6975	1.5089	1.5089	1.8861	1.5089	1.5089
8	2.2634	1.8861	1.8861	2.0748	2.0748	2.0748	2.2634
9	3.3951	2.0748	2.2634	2.0748	2.8292	2.8292	2.6406
10	3.9609	2.452	2.452	2.2634	2.8292	3.0178	3.3951
11	3.9609	2.6406	3.0178	2.452	3.2065	3.2065	3.5837
12	3.7723	2.452	3.2065	2.452	3.3951	3.0178	3.5837
13	3.0178	2.452	2.6406	2.0748	2.6406	2.8292	3.2065
14	3.5837	2.2634	3.2065	2.6406	3.3951		3.5837
15	3.7723	2.452	3.0178	2.2634	3.7723	2.2634	3.9609
16	3.7723	1.3203	3.0178	2.2634	3.3951	3.0178	3.7723
17	3.2065	2.2634	2.6406	2.452	3.3951	3.0178	3.5837
18	2.8292	2.0748	2.6406	2.0748	3.2065	2.6406	3.2065
19	2.6406	1.8861	2.8292	1.8861	2.6406	2.2634	2.8292
20	2.452	1.6975	2.452	2.0748	2.6406	2.2634	2.6406
21	2.2634	1.8861	2.2634	2.0748	2.452	2.2634	2.452
22	1.8861	1.6975	2.2634	1.6975	1.8861	1.8861	2.0748
23	1.8861	1.6975	1.6975	1.8861	1.6975	1.6975	1.8861
24	2.0748	1.6975	1.5089	1.6975	1.6975	1.6975	1.6975
Max	3.9609	2.6406	3.2065	2.6406	3.7723	3.2065	3.9609
Min	1.8861	1.3203	1.5089	1.5089	1.6975	1.5089	1.5089
Avg	2.6720	1.9927	2.2319	1.9647	2.4677	2.2060	2.5463

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283076 / 22/22 KV WAGLE ETATE

SWITCHING

Feeder No / Name : 310 / Feeder No IV

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	.9431	.5658	1.1317	1.1317	.9431	.7545
2	.9431	1.1317	.5658	1.1317	1.1317	.9431	.7545
3	.9431	1.1317	.5658	1.1317	1.1317	.9431	.5658
4	.9431	1.1317	.5658	1.1317	1.1317	.9431	.5658
5	.9431	1.1317	.5658	1.1317	1.1317	.9431	.7545
6	.9431	1.1317	.5658	1.1317	1.1317	.9431	.7545
7	1.1317	1.1317	.7545	1.1317	1.1317	.9431	.5658
8	.9431		.9431	.7545	.9431	.7545	.9431
9	1.3203	1.1317	1.1317	1.3203	1.5089	.7545	1.3203
10	1.6975	1.3203	1.3203	1.3203	1.6975	.9431	1.6975
11	1.3203	.7545	1.3203	1.1317	1.3203	.9431	1.5089
12	1.1317	1.1317	1.5089	1.3203	1.3203	.9431	1.5089
13	1.5089	1.1317	1.1317	1.1317	1.5089	.9431	1.3203
14	1.5089	1.1317	1.1317	1.3203	1.3203	.9431	1.5089
15	1.5089	1.3203	1.3203	1.1317	1.5089	.9431	1.5089
16	1.5089	1.1317	1.1317	1.1317	1.3203	.7545	1.5089
17	1.3203	1.3203	1.1317	1.1317	1.5089	.7545	1.6975
18	1.5089	1.3203	1.1317	.9431	1.3203	.7545	1.3203
19	.7545	1.1317	1.1317	1.1317	1.1317	.7545	1.3203
20	1.3203	.9431	1.1317	1.1317	1.1317	.7545	1.3203
21	1.1317	.9431	1.1317	1.1317	1.1317	.5658	.9431
22	.9431	1.1317	1.1317	1.1317	1.1317	.5658	.9431
23	1.1317	.5658	.9431	.7545	1.1317	.5658	.9431
24	.9431	.9431	.5658	.9431	1.1317	.9431	.7545
Max	1.6975	1.3203	1.5089	1.3203	1.6975	.9431	1.6975
Min	.7545	.5658	.5658	.7545	.9431	.5658	.5658
Avg	1.1789	1.0907	.9745	1.1160	1.2496	.8409	1.1160

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283076 / 22/22 KV WAGLE ETATE

SWITCHING

Feeder No / Name : 320 / KISAN NAGAR-2 INCOMER TO NON SHEDDABLE EXPRESS HV FEEDERS
 KISAN Feeder KV- 22 / INCOMING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6975	1.6975	1.5089	1.3203	1.5089	1.5089	1.5089
2	1.6975	1.8861	1.5089	1.1317	1.5089	1.5089	1.5089
3	1.6975	1.8861	1.5089	1.1317	1.5089	1.5089	1.5089
4	1.6975	1.6975	1.5089	1.3203	1.5089	1.5089	1.5089
5	1.6975	1.6975	1.5089	1.3203	1.5089	1.5089	1.5089
6	1.6975	1.6975	1.5089	1.1317	1.5089	1.5089	3.9609
7	1.8861	1.6975	1.5089	1.5089	1.6975	1.5089	4.1495
8	1.8861	1.8861	1.6975	1.6975	1.8861	1.6975	1.6975
9	2.0748	2.0748	1.8861	2.0748	2.0748	2.0748	2.2634
10	2.2634	2.2634	2.2634	1.8861	2.2634	2.0748	2.0748
11	2.2634	2.0748	2.0748	1.8861	2.0748	2.0748	2.2634
12	2.2634	2.0748	2.0748	1.8861	2.0748	2.0748	2.0748
13	1.8861	1.8861	1.6975	1.6975	1.6975	1.6975	1.8861
14	2.0748	1.6975	1.6975	1.6975	1.6975	1.6975	1.8861
15	1.8861	1.6975	1.6975	1.5089	1.6975	1.6975	1.8861
16	1.8861	1.6975	1.6975	1.5089	1.6975	1.6975	1.6975
17	1.8861	1.6975	1.6975	1.5089	1.6975	1.6975	1.6975
18	1.8861	1.6975	1.6975	1.6975	1.6975	1.6975	
19	2.2634	2.0748	2.0748	1.8861	2.0748	2.0748	2.2634
20	2.2634	2.0748	2.2634	2.0748	2.2634	2.0748	2.2634
21	2.2634	2.0748	1.8861	1.8861	2.0748	1.8861	2.0748
22	2.0748	1.8861	1.8861		1.8861	1.8861	2.0748
23	1.8861	1.6975	1.6975	1.6975	1.6975	1.6975	1.8861
24	1.6975	1.6975	1.6975	1.5089	1.5089	1.5089	1.5089
Max	2.2634	2.2634	2.2634	2.0748	2.2634	2.0748	4.1495
Min	1.6975	1.6975	1.5089	1.1317	1.5089	1.5089	1.5089
Avg	1.9490	1.8547	1.7604	1.6073	1.7840	1.7447	2.0502

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283077 / 22 /11KV WAGLE ESTATE S/S

Feeder No / Name : 202 / NEW RAM GOPAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	12-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	.1698	.1698	.1698	.1698
11	.1886	.2075	.1886	.1886
12	.1886	.2263	.1698	.1698
13	.2075	.2263	.1698	.1698
14	.2452	.2075	.2075	.2075
15	.2829	.1698	.1698	.2075
16	.1886	.1886	.1886	.2075
17	.2075	.1698	.1886	
18	.1509	.1509	.1886	.1509
19			.1698	.1509
20			.1509	
21			.1509	
22			.1509	
Max	.2829	.2263	.2075	.2075
Min	.1509	.1509	.1509	.1509
Avg	.2033	.1907	.1741	.1803

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283077 / 22 /11KV WAGLE ESTATE S/S

Feeder No / Name : 203 / JAI MAHARASHTRA NAGAR
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	1.1317	1.1317	1.1317	1.0374	.9431	1.0374
2	1.0374	1.0374	1.0374	.9431	.9431	.9431	.9431
3	1.0374	1.0374	1.0374	.9431	.9431	.9431	.9431
4	1.0374	1.0374	1.0374	.9431	.9431	.9431	.9431
5	1.0374	1.0374	1.0374	.9431	.9431	.9431	.9431
6	1.0374	1.0374	1.0374	.9431	.9431	.9431	1.0374
7	1.0374	1.0374	1.0374	1.0374	1.0374	.9431	1.0374
8	1.0374	1.0374	1.226	.9431	1.1317	1.0374	.9431
9	1.4146	1.226	1.4146	1.0374	1.5089	1.4146	1.3203
10	2.2634	1.6975	1.8861	1.4146	1.8861	1.7918	1.8861
11	2.6406	1.9805	1.8861	1.6975	2.0748	1.7918	2.0748
12	2.3577	1.7918	2.0748	1.4146	1.8861	1.6975	2.0748
13	1.8861	1.7918	1.226	1.5089	1.6975	1.5089	1.7918
14	2.5463	1.7918	1.4146	1.3203	1.7918	1.6975	2.0748
15	2.452	1.6975	1.6032	1.6975	2.0748	1.6975	2.0748
16	2.1691	1.7918	1.6975	1.5089	1.8861	1.7918	2.2634
17	2.1691	1.6032	1.226	1.226	1.8861	1.5089	1.9805
18	1.6032	1.4146	1.4146	1.1317	1.5089	1.5089	1.6032
19	1.5089	1.3203	1.226	1.4146	1.5089	1.226	1.6032
20	1.226	1.226	1.226	1.226	1.3203	1.0374	1.5089
21	1.1317	1.1317	1.226	1.226	1.0374	1.1317	1.3203
22	1.0374	1.0374	1.0374	1.1317	.9431	1.0374	1.226
23	1.1317	1.1317	1.1317	1.1317	1.0374	1.0374	1.1317
24	1.1317	1.1317	1.0374	1.0374	1.0374	.9431	.9431
Max	2.6406	1.9805	2.0748	1.6975	2.0748	1.7918	2.2634
Min	1.0374	1.0374	1.0374	.9431	.9431	.9431	.9431
Avg	1.5443	1.3400	1.3046	1.2064	1.3753	1.2692	1.4461

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283077 / 22 /11KV WAGLE ESTATE S/S

Feeder No / Name : 205 / RAILADEVI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6602	.6602	.5658	.6602	.6602	.6602	.6602
2	.6602	.6602	.5658	.5658	.6602	.5658	.6602
3	.6602	.6602	.5658	.5658	.6602	.5658	.6602
4	.6602	.6602	.5658	.5658	.6602	.5658	.6602
5	.6602	.6602	.5658	.5658	.6602	.5658	.6602
6	.6602	.6602	.5658	.5658	.6602	.5658	.6602
7	.6602	.6602	.6602	.5658	.6602	.5658	.6602
8	.6602	.6602	.7545	.6602	.6602	.6602	.7545
9	1.0374	.8488	.8488	.7545	.9431	.8488	.9431
10	1.5089	1.0374	1.1317	.8488	1.3203	1.226	1.4146
11	1.6032	1.226	1.1317	.9431	1.4146	1.226	1.5089
12	1.6032	1.226	1.3203	.8488	1.4146	1.3203	1.5089
13	1.226	.9431	.9431	.8488	1.3203	1.1317	1.226
14	1.6032	1.0374	1.226	.9431	1.4146	1.226	1.5089
15	1.6975	1.226	1.226	.9431	1.4146	1.3203	1.6032
16	1.7918	1.3203	1.226	.9431	1.5089	1.4146	1.7918
17	1.6032	.7545	1.226	.8488	1.5089	1.226	1.6975
18	1.226	.9431	1.0374	.8488	1.3203	1.0374	1.4146
19	1.226	.8488	1.0374	.8488	1.1317	.8488	1.226
20	.9431	.7545	.9431	.8488	.8488	.8488	1.0374
21	.8488	.6602	.7545	.7545	.7545	.6602	.8488
22	.7545	.6602	.6602	.6602	.6602	.6602	.7545
23	.6602	.6602	.6602	.6602	.6602	.6602	.7545
24	.6602	.6602	.6602	.6602	.6602	.6602	.6602
Max	1.7918	1.3203	1.3203	.9431	1.5089	1.4146	1.7918
Min	.6602	.6602	.5658	.5658	.6602	.5658	.6602
Avg	1.0531	.8370	.8684	.7466	.9824	.8763	1.0531

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283083 / 22/11KV Ramnagar Substation

Feeder No / Name : 202 / 11KV Hanuman Nagar

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.7167	.7545	
2			.7167	.7167	
3			.679	.6979	
4			.6979	.6979	
5			.6979	.6979	
6			.6979	.7167	
7			.7167	.7167	
8			.7733	.8488	
9	.9945		.9808		.8402
10	.9431		1.2826	1.1831	.8916
11	.9945		1.3957	1.0631	1.0288
12	.9945		1.4146	1.2003	1.3032
13	1.286		.9619	1.2346	1.286
14			1.1883	1.3375	1.3375
15			1.2071	1.2003	1.3717
16			1.2637	1.2003	1.3375
17		1.5089	1.2826	1.2346	1.2826
18		1.1694	1.1128	1.2003	1.3392
19		1.226	1.1883	1.2003	1.3769
20		1.0751	1.0751		1.2449
21		.8865	.8865		.8488
22		.8676	.8488		.9054
23					.8488
24			.7545	.7733	
Max	1.286	1.5089	1.4146	1.3375	1.3769
Min	.9431	.8676	.679	.6979	.8402
Avg	1.0425	1.1223	.9800	.9829	1.1495

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283083 / 22/11KV Ramnagar Substation

Feeder No / Name : 203 / 11KV TMT Depo

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3584	.3772	
2			.3206	.3395	
3			.3206	.3395	
4			.3206	.3395	
5				.3395	
6			.3395	.3584	
7			.3395	.3395	
8			.3584	.3584	
9	.4287		.415	.4801	.4115
10	.5144		.4527	.4973	.4801
11	.5144		.4715	.5144	.5144
12	.5658		.5658	.5144	.4801
13	.6001		.4904	.5487	.5487
14	.5487		.547	.583	.5144
15	.583		.5093	.5144	.5658
16	.6001		.4904	.5487	.5144
17	.5487	.5658	.5281	.5658	.6036
18		.5658	.4527	.4973	.5281
19		.5281	.4904	.5144	.5847
20		.4527	.4715		.547
21		.4338	.3772		.4338
22		.3961	.3961		.4338
23					.415
24			.3584	.3772	
Max	.6001	.5658	.5658	.583	.6036
Min	.4287	.3961	.3206	.3395	.4115
Avg	.5449	.4904	.4261	.4474	.5050

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283083 / 22/11KV Ramnagar Substation

Feeder No / Name : 204 / NSIL-HT

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER MIDC EQUIVALENT
HAVING WEEKLY STAGGERING

DATE	08-FEB-18	12-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
9	.2229	.3258	.2743
10	.3944	.3429	.2915
11	.3429	.3429	.3429
12	.3429	.2774	.3258
13	.2743	.3086	.2743
14	.2915	.2743	.2743
15	.3258	.2915	.2915
16	.3258	.2743	.3086
17	.2915	.2743	.3395
18		.2572	.2641
19			.2075
20			.1509
21			.1698
Max	.3944	.3429	.3429
Min	.2229	.2572	.1509
Avg	.3124	.2969	.2704

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283083 / 22/11KV Ramnagar Substation

Feeder No / Name : 206 / I-THINK IT Park-2

SHEDDABLE FEEDER MIDC EQUIVALENT

Feeder KV- 11 / OUTGOING

HAVING WEEKLY STAGGERING

DATE	08-FEB-18	10-FEB-18	12-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.2058		.2058	.2058
10	.2743		.2401	.2915
11	.2915		.2572	.3086
12	.2915		.2572	.3086
13	.2915		.2915	.3086
14	.2915		.2915	.2915
15	.2915		.2915	.2915
16	.2915		.3086	.2915
17	.2743	.1886	.3086	
18		.1886	.2572	
19			.2229	.2452
20				.1886
Max	.2915	.1886	.3086	.3086
Min	.2058	.1886	.2058	.1886
Avg	.2782	.1886	.2666	.2731

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283099 / 22/22KV Ashar IT Park

Switchin

Feeder No / Name : 301 / 22KV Sathenagar Feeder

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0748	2.0748	1.8861	1.6975	1.8861	1.8861	1.8861
2	2.0748	1.8861	1.8861	1.5466	1.8861	1.8861	1.8861
3	1.8861	1.8861	1.6975	1.5089	1.6975	1.8861	1.8861
4	1.8861	1.8861	1.6975		1.6975	1.8861	1.8861
5	1.8861	1.8861	1.6975	1.4712	1.6975	1.8861	1.8861
6	1.8861	1.8861	1.6975	1.5466	1.6975	1.8861	1.8861
7	1.8861	1.8861	1.8861	1.5844	1.8861	1.8861	1.8861
8	2.0748	2.0748	2.0748	1.8107	2.0748	1.8861	2.0748
9	2.6406	2.6406	2.2634	2.0748	2.452		2.6406
10	3.0178	2.6406	2.2634	2.452	2.8292	2.6406	3.0178
11	3.0178	2.8292	2.5652	2.452	3.0178	2.8292	3.2065
12	3.1687	2.6406	2.6029	2.6406	3.0178	2.6406	3.3951
13	2.8292	2.6406	2.3388	2.2634	2.8292	2.452	3.0178
14	3.0178	2.452	2.6406	2.2634	3.0178	2.6406	3.3951
15	3.2065	2.6406	2.5274	2.2634	3.0178	2.8292	3.3951
16	3.2065	2.6406	2.4143	2.2634	3.0178	2.8292	3.3951
17	3.0178	2.2634	2.4143	2.2634	3.0178	2.8292	3.2065
18	3.0178	.2263	2.3765	2.2634	2.8292	2.6406	3.2065
19	3.0178	2.452	2.452	2.2634	2.8292	2.452	3.0178
20	2.8292	2.2634	2.452	2.452	2.6406	2.452	3.0178
21	2.6139	2.2634	2.1879	2.2634	2.2634	2.2634	2.8292
22	2.452	2.2634	2.1502	2.2634	2.2634	2.2634	2.6406
23	2.2634	2.2634	2.037	2.2634	2.0748	2.2634	2.6406
24		2.2634	2.0748	1.8107	2.0748	2.0748	2.0748
Max	3.2065	2.8292	2.6406	2.6406	3.0178	2.8292	3.3951
Min	1.8861	.2263	1.6975	1.4712	1.6975	1.8861	1.8861
Avg	2.5640	2.2021	2.1785	2.0731	2.4048	2.3126	2.6406

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283099 / 22/22KV Ashar IT Park

Switchin

Feeder No / Name : 303 / Ashir IT complex feeder

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3203	1.1317	1.0185	.9431	.9431	.9431
2	.9431	1.1317	1.1317	.9431	.9431	.9431	.9431
3		1.1317	.9431	.8299	.9431	.9431	.9431
4	.9431	1.1317	.9431	.8299	.9431	.9431	.9431
5	.9431	1.1317	.9431	.7922	.9431	.9431	.9431
6	.9431	1.1317	.9431	.8299	.9431	.9431	.9431
7		1.1317	.9431	.7922	.9431	.9431	.9431
8	.9431	1.1317	1.1317	.8299	1.1317	.9431	1.1317
9	1.8861	1.8861	1.5089	1.0562	1.8861	1.6975	1.8861
10	2.452	2.2634	1.6598	1.1317	2.2634	2.2634	2.2634
11	2.452	2.6406	1.8107	1.3203	2.452	2.2634	2.452
12	2.6406	2.2634	1.8484	1.3203	2.452	2.2634	2.452
13	2.6406	2.452	1.773	1.3203	2.452	2.2634	2.6406
14	2.8292		1.773	1.3203	2.452	2.2634	2.8292
15	2.6406	2.452	1.773	1.3203	2.452	2.2634	2.8292
16	2.6406	2.6406	1.8107	1.3203	2.6406	2.452	2.8292
17	2.8292	2.6406	1.8484	1.1317	2.8292	2.2634	3.0178
18	2.6406	2.452	1.773	1.1317	2.452	2.2634	2.8292
19	2.2634	2.2634	1.5466	1.1317	1.8861	2.0748	2.2634
20	1.6975	1.8861	1.358	.9431	1.5089	1.6975	1.8861
21	1.5089	1.6975	1.358	1.1317	1.5089	1.5089	1.6975
22	1.5089	1.5089	1.2826	1.1317	1.5089	1.3203	1.5089
23	1.3203	1.5089	1.2071	1.1317	1.1317	1.3203	1.5089
24	1.1317	1.3203	1.3203	1.1317	.9431	1.1317	1.1317
Max	2.8292	2.6406	1.8484	1.3203	2.8292	2.452	3.0178
Min	.9431	1.1317	.9431	.7922	.9431	.9431	.9431
Avg	1.8951	1.7877	1.4068	1.0767	1.6897	1.6190	1.8233

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283099 / 22/22KV Ashar IT Park

Switchin

Feeder No / Name : 309 / 22KV JAI BHAWANI NAGER SHEDDABLE FEEDER HAVING WEEKLY
 FEEDER Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.9431	.7545	.7922	.7545	.7545	.7545
2	.5658	.7545	.7545	.7545	.7545	.5658	.5658
3	.5658	.7545	.5658	.7167	.5658	.5658	.5658
4	.5658	.7545	.5658	.7167	.5658	.5658	.5658
5	1.8861	.7545	.5658	.7167	.5658	.5658	.5658
6	.7545	.7545	.5658	.6413	.5658	.5658	.5658
7	.7545	.9431	.7545	.7545	.7545	.7545	.7545
8	.9431	1.1317	.9431	.8299	1.1317	.9431	.9431
9	1.3203	1.1317	1.1317	1.0185	1.3203	1.3203	1.1317
10	1.5089	1.3203	1.3203	1.1317	1.5089	1.6975	1.6975
11	1.6975	1.3203	1.3957	1.3203	1.6975	1.6975	1.6975
12	1.6598	1.3203	.9808	1.3203	1.3203	1.5089	1.6975
13	1.5089	1.1317	.9808	1.1317	1.5089	1.3203	1.5089
14	1.5089	.9431	1.0185	1.0562	1.3203	1.3203	1.5089
15	1.5089	.9431	1.0185	.9431	1.3203	.5658	1.5089
16	1.3203	.9431	.9808	.7545	1.3203	1.1317	1.3203
17	1.1317	.9431	.9054	.9431	1.3203	1.1317	1.3203
18	1.3203	.9431	1.2449	1.1317	1.5089	1.3203	1.5089
19	1.3203	.9431	1.2449	1.1317	1.1317	1.1317	1.5089
20	1.1317	.9431	1.2449	.9431	1.1317	1.1317	1.3203
21	1.1317	.9431	.8299	.7545	.9431	.9431	1.3203
22	.9431	.9431	.9054	.9431	.7545	.9431	1.1317
23	.9431	.9431	.8676	.7545	.7545	.9431	1.1317
24	.7545	.9431	.9431	.7922	.7545	.7545	.7545
Max	1.8861	1.3203	1.3957	1.3203	1.6975	1.6975	1.6975
Min	.5658	.7545	.5658	.6413	.5658	.5658	.5658
Avg	1.1380	.9745	.9368	.9164	1.0531	1.0059	1.1395