

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 201 / 11 KV SAKALPAPER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.0914	.0857		.0857	.0914	
4	.0924	.0914	.0857	.0924	.0857	.0914	.1848
6		.0914	.0857		.0857	.0914	
8	.0924	.0914		.0934	.0857	.0914	.0747
10	.1109	.1109	.1109	.0924	.1097	.1109	.1109
11					.1097		
12	.112	.112	.112	.112	.0914	.112	.112
13					.1097		
14	.112	.112	.0924	.1029	.1097	.112	.112
15					.128		
16	.1478	.1294	.1294	.1029	.128	.1294	.1294
18	.1097	.1029		.1029	.0914		.0857
19	.1097		.1109		.1097	.112	
20	.0914	.0857		.1029	.0914		.0857
21	.1097		.112			.1109	
22		.0857		.1029	.1097		.0857
24	.0934	.0914	.0686	.0934	.0857	.0914	.0934
Max	.1478	.1294	.1294	.112	.128	.1294	.1848
Min	.0914	.0857	.0686	.0924	.0857	.0914	.0747
Avg	.1074	.0996	.0993	.0998	.1011	.1040	.1074

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 202 / 11 KV KUKERAJA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2					.8131	
4					.8501	
6					.8686	
8					1.0719	
10	1.7556	1.7372	1.4415	.8686	1.8111	1.4415
11					1.8665	
12	1.9418	1.9231	1.5154	.9896	1.7556	1.643
13					1.6817	
14	1.848	1.848	1.5524	.9602	1.7741	1.5893
15					1.8111	
16	1.9589	1.8665	1.5708	.8745		1.5893
24					.8871	
Max	1.9589	1.9231	1.5708	.9896	1.8665	1.643
Min	1.7556	1.7372	1.4415	.8686	.8131	1.4415
Avg	1.8761	1.8437	1.5200	.9232	1.3810	1.5658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 203 / 11 KV GAUTAM COMPLEX

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.7577	.7202		.6859	.8131	
4	.7762	.7577	.7202	.7468	.703	.7577	.7468
6		.8316	.7373		.703	.7947	
8	.8589	.8316		.7392	.8059	.7947	.8316
10	1.4415	1.4784	1.1458	.8316	1.4784	1.2567	1.4937
11					1.5708		
12	1.6617	1.587	1.2696	.9149	1.5708	1.363	1.6991
13					1.46		
14	1.7177	1.5684	1.1949	.8573	1.5893	1.4003	1.7737
15					1.5708		
16	1.6448	1.6263	1.1643	.8573	1.5708	1.3306	1.7556
18	1.3491	1.2689		.823	1.386		1.3203
19	1.2197		1.0534			1.0534	
20	1.0903	.9602		.8059	1.0534		1.0117
21	.9979		.9522		.9795		
22		.9088		.8573	.961		.9259
24	.8962	.7947	.7888	.8501	.7545	.8316	.8501
Max	1.7177	1.6263	1.2696	.9149	1.5893	1.4003	1.7737
Min	.7762	.7577	.7202	.7392	.6859	.7577	.7468
Avg	1.2413	1.1143	.9747	.8283	1.1777	1.0396	1.2409

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 205 / 11 KV ARENJA TOWER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.2012	.1715		.1715	.1646	
4	.2241	.1829	.1715	.1867	.1886	.1829	.1848
6		.2012	.1886		.1886	.2195	
8	.3142	.2561	.1886	.2033	.2401	.3142	.2987
10	.4251	.4435	.3881	.2402	.4805	.4066	.4066
11					.4805		
12	.4481	.4668	.3921	.2241	.462	.4294	.4668
13					.4435		
14	.4435	.4854	.3511	.2058	.4251	.4481	.4668
15					.4435		
16	.462	.4805	.3696	.1715	.4435	.4066	.462
18	.4066	.4115		.1886	.4066		.4287
19	.3696		.2987			.3734	
20	.3511	.3601		.2058	.3109		.3601
21	.2926		.2587		.2378	.2957	
22		.2058		.2229	.2195		.3086
24		.2012	.2058	.2054	.1715	.1829	.2054
Max	.462	.4854	.3921	.2402	.4805	.4481	.4668
Min	.2241	.1829	.1715	.1715	.1715	.1646	.1848
Avg	.3737	.3247	.2713	.2054	.3321	.3113	.3589

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 207 / 11 KV CIDCO PUMP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.4435	.4458		.4287	.4066	
4	.5175	.4435	.5144	.4805	.4801	.3881	.4066
6		.499	.4973		.5316	.5175	
8	.5788	.5729	.6001	.5601	.6001	.6468	.7468
10	.6468	.5729	.462	.7023	.3696	.6468	.5914
11					.4435		
12	.4108	.3734	.4294	.4294	.4066	.4108	.3921
13					.3696		
14	.3734	.3881	.3921	.3429	.3326	.3881	.3881
15					.3142		
16	.3696	.3326	.3326	.2401	.3696	.3511	.3881
18	.499	.4115		.5316	.5544		.5487
19	.5729		.7095			.5975	
20	.5729	.4801		.5144	.5359		.4973
21	.5359		.5175		.5175	.5359	
22		.463		.4801	.5359		.4801
24		.4805	.4115	.4668	.4115	.462	.4854
Max	.6468	.5729	.7095	.7023	.6001	.6468	.7468
Min	.3696	.3326	.3326	.2401	.3142	.3511	.3881
Avg	.5078	.4551	.4829	.4748	.4501	.4865	.4925

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 208 / 11 KV INFOTECH PARK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.7577	.6516		.5487	.7207	
4	.7762	.7207	.6173	.6348	.583	.6653	.6908
6		.7023	.6173		.6344	.7023	
8	.8215	.8131	.6859	.6653	.6859	.7762	.8316
10	1.3491	1.3121	1.1088	.7023	1.386	1.0534	1.3443
11					1.3306		
12	1.5123	1.475	1.1016	.7468	1.2936	1.1389	1.4003
13					1.2567		
14	1.46	1.3306	1.0164	.6516	1.2936	1.1389	1.419
15					1.4045		
16	1.4969	1.423	1.0534	.7545	1.4784	1.2012	1.4969
18	1.3306	1.1145		.6687	1.3306		1.1831
19	1.1827		.8501			.9979	
20	1.0164	.8916		.6687	.9425		.9602
21	.9425		.7468		.8871	.8775	
22		.7888		.6344	.8686		.8916
24		.8871	.703	.6653	.583	.7762	.8131
Max	1.5123	1.475	1.1088	.7545	1.4784	1.2012	1.4969
Min	.7762	.7023	.6173	.6344	.5487	.6653	.6908
Avg	1.1888	1.0180	.8320	.6792	1.0317	.9135	1.1031

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 209 / 11 KV RBI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.2012	.1715		.1715	.2012	
4	.2033	.2218	.1715	.1867	.2058	.2195	.2033
6		.2587	.1715		.2229	.2378	
8	.1867	.2195	.1886	.1848	.1886	.2561	.1867
10	.2033	.2218	.2218	.2772	.1829	.2033	.2033
11					.2012		
12	.2241	.2241	.1867	.1494	.2012	.2054	.2054
13					.1646		
14	.2054	.1848	.168	.1886	.1646	.1848	.2241
15					.1646		
16	.2033	.1848	.1478	.1372	.1646	.1478	.2033
18	.2012	.2058		.1715	.1646		.1886
19	.2743		.2402			.2614	
20	.2561	.2229		.2058	.2561		.2572
21	.2378		.2427		.2195	.2587	
22		.2401		.2229	.2378		.2401
24		.2195	.2058	.2033	.1886	.2012	.2241
Max	.2743	.2587	.2427	.2772	.2561	.2614	.2572
Min	.1867	.1848	.1478	.1372	.1646	.1478	.1867
Avg	.2196	.2171	.1924	.1927	.1937	.2161	.2136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 210 / 11 KV MTNL / DIWALA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			.3429		.3601	.4066	
4	.4108	.462	.3772	.4066	.3944	.4251	.4668
6		.499	.4458		.4458	.462	
8	.5544	.5544	.4801	.4481	.5487	.5359	.5729
10	1.3491	1.3306	.8501	.4805	1.2567	.8871	1.2696
11					1.3306		
12	1.4937	1.307	.8962	.5601	1.3491	.9896	1.419
13					1.3306		
14	1.386	1.4003	.8589	.4801	1.2936	.9522	1.5154
15					1.3676		
16	1.5154	1.3306	.8131	.463	1.3306	.961	1.5154
18	.961	.823		.4458	.9055		.7716
19	.7392		.5601			.6468	
20	.5914	.5658		.4115	.5914		.5144
21	.499		.499		.5359	.5041	
22		.4458		.4287	.4805		.4287
24		.462	.3772	.4294	.3944	.4251	.462
Max	1.5154	1.4003	.8962	.5601	1.3676	.9896	1.5154
Min	.4108	.4458	.3429	.4066	.3601	.4066	.4287
Avg	.95	.8346	.5910	.4554	.8697	.6541	.8936

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 212 / 11 KV MAYURESH COSMOSS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.0914	.0857		.0686	.0914	
4	.1294	.0914	.0857	.0934	.0686	.1097	.1109
6		.0914	.1029		.0686	.128	
8	.112	.128	.12	.0924	.0857	.0914	.0934
10	.2218	.2772	.2218	.1109	.2743	.2033	.2218
11					.2743		
12	.2987	.2801	.2614	.112	.2926	.2987	.2987
13					.2561		
14	.2801	.2957	.2402	.1029	.2743	.2402	.2772
15					.2743		
16	.3142	.2957	.2218	.1029	.3109	.2772	.2772
18	.2012	.2229		.1029	.2561		.2229
19	.1646		.1109			.1867	
20	.128	.12		.1029	.128		.12
21	.1463		.112		.1097	.1294	
22		.1029		.1029	.1097		.0857
24		.0914	.0857	.0924	.0857	.0914	.112
Max	.3142	.2957	.2614	.112	.3109	.2987	.2987
Min	.112	.0914	.0857	.0924	.0686	.0914	.0857
Avg	.1996	.1740	.1498	.1016	.1836	.1679	.1820

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 403 / 33 KV NMMC

Feeder KV- 33 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		1.9805	1.6461		1.6461	1.8673	
4	1.8107	1.9239	1.6975	1.6461	1.6975	1.8673	1.6461
6		1.9805	1.6975		1.6975	1.885	
8	1.8656	2.037	1.749	1.262	1.2346	.2458	1.262
10			.6653		.2949		
11					.3052		
12					.3052		
13					.3052		
14				.3086	.3052		
15					.3052		
16				.3086	.3052		
18	.2458	.2572		.2572	.3052		.2572
19	.2458		.1097			.2743	
20	.2543	.2572		.2572	.3052		.2572
21	1.382		.8779		1.3289	1.3306	
22		1.6461		1.6461	1.701		1.5947
24		1.9805	1.5947	1.6632	1.5947	1.7541	1.7558
Max	1.8656	2.037	1.749	1.6632	1.701	1.885	1.7558
Min	.2458	.2572	.1097	.2572	.2949	.2458	.2572
Avg	.9674	1.5079	1.2547	.9186	.8523	1.3178	1.1288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 201 / 11 KV SECTOR 8-A

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6161	.5716	.6161		.7049	.5415	.5335
2		.5335			.7049		.5335
3	.5975	1.105	.5228	.5601	.7049	.4854	.5335
4		.5335			.7621		.5335
5	.6722	1.105	.5228		.7621	.4854	.5716
6	.7468	.6859	.5975	.5601	.7621	.5601	.6668
7	.8402	.8383	.5975	.6535	.8573	.7095	.7811
8	.8402	.8383				.8029	
9		.8573	.8962	.8402	.9145		.8589
10	.9526	.9335	.7468	.8002	.7842	.8192	
11	.7621	.7095		.7621	.7095	.6859	.7842
12		.6348	.7095	.7621	.6535	.6097	.7095
13		.5975	.6348	.7049	.6161		.5601
14		.5041			.4854	.4954	.6348
15	.5716	.4854	.5228	.5335	.5415	.4382	.5975
16	.6097	.5041	.5228	.5144	.4854	.4191	.5601
17	.5716		.5228		.4854	.4763	.5228
18	.5716	.5041	.6722	.7811	.5415	.6097	.5228
19	.8192	.7842	.8402	.9717	.8029	.7811	.8775
20	.8192	.8215	.8962	.9526	.8029	.8192	.8215
21	.8383	.8215	.8589	1.0098		.8192	.8775
22	.7811	.7655		.9335	.7095	.6478	.7468
23	.6668	.6908		.8002	.6535	.6287	.7095
24	.6161	.6097	.6535	.6348	.6668	.5415	.4572
Max	.9526	1.105	.8962	1.0098	.9145	.8192	.8775
Min	.5716	.4854	.5228	.5144	.4854	.4191	.4572
Avg	.7163	.7145	.6667	.7515	.6869	.6188	.6543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 203 / 11 KV CBD SEC 8 B

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6535	1.0288	.6161		.5716	.6535	.6097
2		.6478			.5716		.6097
3	.6348	.6478	.5601	.5975	.5716	.5601	.6097
4		.6478			.5716		.724
5	.7095	.6859	.6348		.6668	.6722	.6668
6	.9335	.724	.7095	.6516	.724	.8215	.724
7	1.0642	1.0098	.8402	.7095	.9526	.8402	1.0098
8	1.0829	1.1241				1.0456	
9		1.2193	1.0829	1.0829	1.1812		1.0829
10	1.0098	1.0082	.9335	.9907	.9522	.9335	
11	.8764	.7842		.9526	.8215	.8573	.8775
12		.6908	.7095	.8573	.7095	.724	.7842
13		.6722	.7095	.7049	.6535		.7095
14		.5975			.6161	.6668	.6348
15	.6097	.6161	.5601	.5716		.5906	.5975
16	.6097	.5788	.5975	.5335	.5041	.5525	.5601
17	.6668		.6535	.6097	.6535	.6097	.5975
18	.8002	.6908	.6722	.8383	.7282	.8383	.6878
19	1.1241	.8962	.9709	.9526	1.0456	1.0288	1.1576
20	1.0288	.8962	.9709	1.0479	1.0082	1.0288	1.0456
21	1.0288	.8962	.9335	.9335		1.0098	1.0269
22	.9717	.8589		.8954	.8962	.9145	.9709
23	.7811	.8775		.8383	.7655	.8002	.8402
24	.6908	.6859	.6161	.6348	.6668	.6535	.6668
Max	1.1241	1.2193	1.0829	1.0829	1.1812	1.0456	1.1576
Min	.6097	.5788	.5601	.5335	.5041	.5525	.5601
Avg	.8487	.8037	.7512	.8001	.7539	.7901	.7815

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 204 / 11 KV S/STN T/F SECT-06

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0762	.0747		.0762	.0747	.0762
2		.0762			.0762		.0762
3	.0747	.0762	.0747	.0747	.0762	.0747	.0953
4		.0762			.0762		.0953
5	.0747	.0762	.0747		.0762	.0747	.0762
6	.0934	.0953	.0934		.0762	.0747	.0762
7	.112	.0953	.0934	.0747	.0953	.0934	.0762
8	.0934	.1143				.0934	
9		.1143	.112	.1307	.0953		.1307
10	.0953	.0747	.0747	.0953	.0934	.0953	
11	.0953	.0747		.0953	.0934	.0953	.0934
12		.0747	.0747	.0953	.0747	.0953	.112
13		.0747	.0747	.0953	.0747		.0934
14		.0747			.0747	.0953	.0747
15	.0762	.0747	.0934	.0953		.0762	.0747
16	.0762	.0747	.0747	.0953	.0747	.0953	.056
17	.0762		.0747	.0762	.0747	.0762	.0747
18	.0953	.0747	.0747	.0953	.0747	.0762	.0747
19	.1143	.0934	.1307		.0934	.0762	.112
20	.1143	.0934	.112	.0762	.0934	.0953	.0934
21	.0953	.0934	.0934	.1143		.0953	.0934
22	.0953	.0934		.1143	.112	.0953	.0934
23	.0953	.0934		.0953	.0934	.0953	.0747
24	.0934	.6668	.0934	.0747	.0953	.0747	.0762
Max	.1143	.6668	.1307	.1307	.112	.0953	.1307
Min	.0747	.0747	.0747	.0747	.0747	.0747	.056
Avg	.0914	.1101	.0879	.0936	.0843	.0861	.0863

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 206 / 11 KV KENDRIYA SADAN SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.2858	.2427		.2667	.2427	.2667
2		.2667			.2858		.2667
3	.2427	.2858	.2241	.2614	.2667	.2241	.2667
4		.2858			.2858		.2667
5	.2427	.2858	.2241			.2614	.2667
6	.3174	.2858	.2614	.2801	.2858	.2801	.2667
7	.3174	.3239	.2614	.2241	.3239	.2801	.3048
8	.2987	.3429				.2801	
9		.362	.3361	.3361	.362		.3361
10	.4191	.3801	.3734	.3239	.3734	.3429	
11	.4382	.4108		.3429	.3921	.381	.3734
12		.3734	.4108	.3429	.4108	.381	.3734
13		.3734	.3734	.3239	.3734		.3734
14		.3361			.3547	.3429	.3734
15	.4001	.3734	.3734	.2858		.3048	.3734
16	.381	.3547	.3361	.2667		.3239	.3734
17	.4001		.3361	.2858	.3734	.362	.4108
18	.4001	.3734	.4108	.3429	.4108	.362	.4854
19	.4954	.4294	.5041		.5041	.4954	.5975
20	.4954	.3734	.3734	.381	.4481	.4382	.5228
21	.4382	.3361	.4108	.4001		.4382	.4481
22	.4001	.3361		.3429	.3361	.381	.3734
23	.3048	.2987		.3048	.2801	.3429	.3361
24	.2801	.2858	.2614	.2801	.2858	.2427	.2858
Max	.4954	.4294	.5041	.4001	.5041	.4954	.5975
Min	.2427	.2667	.2241	.2241	.2667	.2241	.2667
Avg	.3629	.3374	.3361	.3133	.3484	.3354	.3610

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 207 / 11 KV SECTOR-09 NEW

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4668	.4763	.4108		.4954	.4481	.4572
2		.4572			.4954		.4572
3	.4481	.4572	.3734	.4481	.4954	.4108	.4572
4		.4572			.4954		.4954
5	.5601	.4572	.4108		.4954	.4108	.5335
6	.5975	.5716	.4854	.4481	.5716	.4854	
7	.6535	.6287	.5228	.4108	.5716	.4854	.5906
8	.7655	.743				.6722	
9		.8383	.7468	.7842	.8573		.8215
10	.6668	.6722	.6348	.7049	.6161	.6287	
11	.5144	.5601		.6287	.4854	.5906	.5228
12		.5041	.5228	.5335	.4481	.4954	.4481
13		.4108	.4668	.4954	.4481		.4108
14		.4108			.5228	.4001	.4108
15	.381	.3734	.3734	.381		.381	.3734
16	.4382	.3361	.3734	.381		.381	.3734
17	.4001		.4108	.4001	.3734	.4001	.4481
18	.4763	.4108	.4108	.4954	.4108	.4572	.4668
19	.724	.5601	.6722		.6348	.7049	.7468
20	.6668	.6161	.6348	.6287	.6161	.6668	.6722
21		.6224	.6348	.6668		.6859	.6348
22	.6668	.5601		.6287	.5975	.6097	.6535
23	.5716	.5228		.5716	.5228	.5525	.5975
24	.5041	.5144	.4668	.4854	.4954	.4481	.4572
Max	.7655	.8383	.7468	.7842	.8573	.7049	.8215
Min	.381	.3361	.3734	.381	.3734	.381	.3734
Avg	.5589	.5287	.5030	.5348	.5324	.5157	.5252

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 208 / 11 KV GOVT. OFFICES SECTOR SHEDDABLE URBAN
11 Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.5716	.4854		.5906	.5228	.4954
2		.5716			.5716		.4954
3	.4854	.5716	.4668	.5228	.5716	.4481	.4954
4		.5716			.5716		.4954
5	.4854	.5716	.4854		.5716	.4481	.5335
6	.5975	.6097	.5788	.5228	.5716	.4854	.5335
7	.7421	.6859	.5601	.5228	.5716	.5415	.5716
8	.7842	.724				.6161	
9		.9907	.5228	.4854	.9526		.8402
10	1.6956	1.4937	.7468	.5716	1.587	1.105	
11	1.829	1.643		.5906	1.7737	1.1812	1.7177
12		1.643	.9335	.5906	1.6804	1.6004	1.7364
13		1.4563	.9709	.5906	1.6617		1.6617
14		1.363			1.587	1.086	1.5497
15	1.7528	1.4937	.8962	.6478		1.0669	1.6617
16	1.8671	1.4563	.9335	.4572		1.1812	1.8298
17	1.7528		.9709	.6478	1.6804	1.0479	1.7177
18	1.4861	1.307	.7468	.724	1.3443	1.1812	1.363
19	1.2765	1.1949	.7468		1.1203	1.0098	.8402
20	.8573	.7842	.7468	.6859	.8029	.7811	.8962
21		.7095	.7468	.724		.6859	.7468
22	.7621	.6535		.6859	.6535	.6478	.7468
23	.6859	.5975		.6287	.6535	.6097	.7095
24	.5975	.6097	.6161	.6348	.6287	.5228	.5335
Max	1.8671	1.643	.9709	.724	1.7737	1.6004	1.8298
Min	.4854	.5716	.4668	.4572	.5716	.4481	.4954
Avg	1.0716	.9684	.7150	.6020	1.0073	.8384	1.0078

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 210 / 11 KV RBI (NEW)

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4481	.4191	.4481		.381	.4481	.381
2		.4191			.381		.362
3	.4481	.4001	.4481	.4481	.381	.4481	.362
4		.4001			.381		.362
5	.4481	.4001	.4481		.381	.4481	.362
6	.4481	.4191	.4481	.4668	.381	.4481	.362
7	.4481	.4191	.4108	.4481	.381	.4481	.4001
8	.4294	.4382				.3734	
9		.5525	.4481	.3734	.5716		.4854
10	.8002	.7095	.4668	.4191	.7655	.4001	
11	.743	.6535		.4191	.7468	.4001	.7095
12		.6535	.4854	.4001	.5788	.381	.7095
13		.7468	.0747	.381	.4854		.6535
14		.7468			.7468	.4001	.7095
15	.6859	.6535	.4481	.381		.4001	.7842
16	.6478	.6535	.4668	.381		.381	.7095
17	.6287		.4481	.381	.5975	.4001	.5601
18	.5716	.5228	.4668	.381	.5228	.4001	.5228
19	.4954	.4668	.4481		.5041	.381	.4668
20	.5335	.4668	.3734	.362	.4854	.381	.4668
21	.4763	.4715	.4854	.381		.4001	.4854
22	.4763	.4481		.381		.381	.0934
23	.4763	.4481		.381		.381	.4854
24	.4481	.4763	.4481	.4481	.381	.4481	.381
Max	.8002	.7468	.4854	.4668	.7655	.4481	.7842
Min	.4294	.4001	.0747	.362	.381	.3734	.0934
Avg	.5363	.5211	.4272	.4019	.5029	.4074	.4915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 201 / 11KV PHANASPADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0974	1.0242	.8131	.8501	.7468	.7842
2		1.0136	.961	.8131	.8316	.7762	.7762
3		.9313	.924	.8316	.8402		.8501
4		.9492	.8962	.8402	.8589	.8779	.8779
5		1.0136	.9709	.8402	.8962	.9511	.9511
6		1.0791	1.0829	.8589	.9808	.9979	1.0164
7		1.363	1.1576	.8589	1.0751	1.0082	1.0829
8		1.4003	1.1949	.9709	1.1128	1.0562	1.0829
9		1.2883	1.1946	1.0829	1.0562	1.1016	1.1576
10		1.1203	1.1016	1.1016	.8589	1.0082	.9335
11		.9709	.9709	.9896	.7655	.8962	.8215
12		.9896	.8501	.8871	.7577	.8215	.8215
13		.9522	.7023	.7762	.7023	.7392	.7655
14		.9335	.6653	.695	.6468	.6653	.6908
15		.7468	.6653	.6584	.6468	.6283	.6908
16		.7842	.6219	.6767	.6219	.5729	.6535
17		.8402	.7682	.7133	.6401	.6653	
18		.9335	.8688	.8501	.695	.7602	
19	1.2197	1.0082	1.0164	.9979	.8596	.8326	1.0534
20	1.2752	1.1643	1.0349	1.0349	.961	.9511	1.1088
21	1.2752	1.1458	1.0719	1.0349	.924	.924	1.1088
22	.3696	1.1273	1.0349	1.0164	.9149	.924	1.0903
23	1.2197	1.1157	.9425	.924	.8775	.8962	1.0269
24		1.0974	1.1157	.8501	.8501	.7842	.8215
Max	1.2752	1.4003	1.1949	1.1016	1.1128	1.1016	1.1576
Min	.3696	.7468	.6219	.6584	.6219	.5729	.6535
Avg	1.0719	1.0444	.9515	.8798	.8427	.8515	.9166

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 202 / 11KV PUJIT PLAZA SECTOR-11

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0886	.0905	.0709	.0701	.0693	.0857
2		.0709	.0905	.0709	.0686	.0686	.0848
3		.0709	.0905	.0709	.0686	.0686	.0678
4		.0709	.0732	.0716	.0686	.0686	.0671
5		.0709	.0934	.0716	.0686	.0838	.0671
6		.0709	.0934	.0716	.0671	.0819	.0829
7		.0686	.0943	.0716	.0671	.08	.0663
8		.0867	.1132	.0716	.08	.08	.0663
9		.1417	.112	.0716	.096	.1296	.1372
10		.2075	.112	.0716	.144	.1457	.1886
11		.2075	.112	.0671	.1739	.144	.2075
12		.1886	.1663	.0671	.1739	.144	.2263
13		.1886	.1478	.0655	.1581	.128	.1886
14		.2075	.1463	.0829	.1581	.1296	.1886
15		.2075	.128	.0829	.1581	.1296	.2075
16		.2263	.128	.0663	.176	.1457	.2452
17		.2263	.1097	.0663	.176	.1475	
18		.1663	.0914	.0857	.16	.1311	
19	.132	.1478	.0914	.0857	.1134	.0995	.1509
20	.0914	.1097	.0701	.0701	.081	.0995	.1132
21	.0732	.1097	.0876	.0701	.0819	.0671	.0754
22	.0724	.1086	.0701	.0526	.0655	.0671	.0754
23	.0724	.0905	.0701	.0701	.0663	.8962	.0724
24		.0905	.0905	.0532	.0701	.0693	.0857
Max	.132	.2263	.1663	.0857	.176	.8962	.2452
Min	.0724	.0686	.0701	.0526	.0655	.0671	.0663
Avg	.0883	.1343	.1030	.0708	.1088	.1364	.1250

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 203 / 11KV BELAPUR DTC SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3292	.4527	.5228	.4481	.4854
2		.3326	.3772	.4854	.4435	.4435
3		.2987	.3772	.4854	.5175	.4435
4		.2801	.3734	.5041	.5121	.5175
5		.2987	.3734	.5093	.5487	.5788
6		.3395	.4108	.5658	.5729	.6161
7		.415	.4108	.6224	.5975	.5975
8		.3961	.5601	.7167	.5975	.6161
9	.415	.3734	.6161	.6413	.6468	.6036
10	.3018	.3361	.6535	.5228	.5914	.5281
11	.2452	.3734	.5975	.3734	.4938	.4338
12	.2829	.3881	.4435	.4066	.4755	.4527
13	.2263	.4066	.499	.4066	.439	.415
14	.2452	.4066	.4572	.3696	.362	.4338
15	.2452	.3696	.3475	.3881	.362	.3961
16	.2075	.3511	.3841	.3841	.3258	.3584
17	.2452	.3881	.4024	.439	.3982	
18	.2987	.4207	.4938	.5304	.4755	
19	.3174	.6224	.5975		.5487	.6908
20	.3142	.6224	.5975	.5729	.5853	.6348
21	.3326	.6036	.6161	.5729	.6283	.6535
22	.3292	.6224	.6348	.5601	.5914	.6535
23	.3475	.5847	.5788	.5601	.5788	.6535
24		.3658	.547	.5601	.4854	.4854
Max	.415	.6224	.6535	.7167	.6468	.6908
Min	.2075	.2801	.3475	.3696	.3258	.3584
Avg	.2903	.4135	.4917	.5087	.5094	.5314

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 204 / 11KV S/STN TRANSFORMER

R.M.U S Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0572	.0572	.0381	.0381	.0381	.0381
2		.0572	.0572	.0381	.0572	.0381	.0381
3		.0572	.0381	.0381	.0381	.0381	.0381
4		.0381	.0381	.0381	.0381	.0572	.0381
5		.0381	.0381	.0381	.0381	.0572	.0381
6		.0572	.0381	.0381	.0572	.0572	.0381
7		.0572	.0381	.0572	.0572	.0572	.0381
8		.0762	.0381	.0572	.0762	.0381	.0381
9		.0762	.0381	.0572	.0762	.0381	.0762
10		.0762	.0381	.0572	.0572	.0381	.0572
11		.0762	.0381	.0572	.0381	.0381	.0572
12		.0762	.0381	.0381	.0381	.0381	.0572
13		.0572	.0381	.0381	.0381	.0381	.0381
14		.0381	.0381	.0381	.0381	.0572	.0381
15		.0572	.0572	.0572	.0381	.0572	.0572
16		.0381	.0572	.0381	.0381	.0572	.0572
17		.0572	.0572	.0572	.0381	.0572	
18		.0572	.0381	.0381	.0381	.0381	
19	.0381	.0572	.0572	.0381	.0381	.0381	.0572
20	.0572	.0572	.0381	.0572	.0381	.0381	.0572
21	.0572	.0572	.0381	.0572	.0381	.0381	.0572
22	.0572	.0572	.0572	.0572	.0381	.0381	.0572
23	.0572	.0572	.0572	.0572	.0381	.0381	.0572
24		.0572	.0572	.0572	.0381	.0381	.0381
Max	.0572	.0762	.0572	.0572	.0762	.0572	.0762
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.0534	.0580	.0453	.0477	.0445	.0445	.0485

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 205 / 11KV SAI VIHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9709	.9114	.8764	.9114	.8413
2		.9015	.8764	.8764	.8573	.7975
3		.8413	.8764	.8688	.8573	.7975
4		.7362	.8596	.8688	.8817	.7712
5		.8063	.8596	.905	.852	.7888
6		.8505	.8596	.905	.9088	.815
7		.9036	.8954	.9231	.9391	.9391
8		.9391	.9313	.9593	.9593	1.4529
9	1.0317	.929	.9671	1.086	.905	1.1041
10	1.3213	.9991	.985	1.2715	1.0498	1.3306
11	1.4415	1.0867	1.0029	1.3611	1.1104	1.4563
12	1.4415	1.1096	1.0277	1.3432	1.1694	1.5497
13	1.419	1.1443	1.1218	1.3253	1.2048	1.5123
14	1.4377	1.1443	1.2094	1.3073	1.2445	1.587
15	1.4937	1.1789	1.1443	1.3073	1.2269	1.5893
16	1.531	1.166	1.0576	1.3969	1.2094	1.5339
17	1.5684	1.1191	.9362	1.4175	1.2003	
18	1.4415	1.065	1.1041	1.382	1.2174	
19	1.3535	1.2174	1.2308	1.3289	1.17	1.7741
20	1.2986	1.286	1.2489	1.2795	1.1361	1.5546
21	1.2308	1.2445	1.267	1.1919	1.1317	1.5364
22	1.1584	1.2971	1.2308	1.1096	1.1269	1.4266
23	1.1104	1.1218	1.086	1.0229	.9882	1.2136
24		1.0402	.9991	.8764	.929	.8589
Max	1.5684	1.2971	1.267	1.4175	1.2445	1.7741
Min	1.0317	.7362	.8596	.8688	.852	.7712
Avg	1.3519	1.0458	1.0287	1.1329	1.0494	1.2378

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 206 / 11KV CHROMA SECTOR-15

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3403	.4784	.5014	.4163	.3982	.3658	.362
2	.3224	.2743	.4298		.3658	.362	.3258
3	.3012	.2915	.3982	.3658	.3658	.3258	.3292
4	.3012	.3086	.2896	.3658	.3475	.3224	.3109
5	.3189	.2915	.2896	.3292	.3547	.3439	.2957
6	.3366	.2915	.3292	.3258	.3547	.3475	.2957
7	.3801	.3292	.3658	.3258	.3547	.3696	.3326
8	.3841	.3696	.3841	.3439	.3547	.3547	.3292
9	.4024	.462	.3982	.3475	.4854	.3921	.4024
10	.5788	.5914	.4344	.3658	.5914	.4854	.5415
11	.6722	.7392	.5068	.439	.6468	.5359	.7282
12	.8029	.7023	.5731	.5014	.6283	.5359	.7095
13	.7762	.6468	.6089	.5258	.6036	.5487	.7282
14	.7947	.6653	.6024	.4681	.5611	.5487	.6908
15	.7392	.6653	.5847	.5316	.5792	.567	.7468
16	.7577	.6653	.5784	.463	.6154	.543	.7282
17	.7392	.7207	.5609	.4801	.6089	.5792	
18	.7133	.6468	.5375	.5249	.5731	.591	
19	.6516	.695	.6697	.5973	.5552	.5373	.8131
20	.7059	.7316	.6335	.6099	.5611	.4961	.6653
21	.6697	.695	.6335	.6468	.5068	.4607	.7207
22	.5973	.6154	.543	.5914	.4755	.4298	.6283
23	.5138	.5731	.4706	.462	.439	.4298	.6661
24	.4887	.5138	.5373	.4344	.4163	.3841	.3801
Max	.8029	.7392	.6697	.6468	.6468	.591	.8131
Min	.3012	.2743	.2896	.3258	.3475	.3224	.2957
Avg	.5537	.5402	.4942	.4549	.4893	.4524	.5332

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 207 / 11KV OLD R.M.U SECTOR-15 SHEDDABLE URBAN
S/STN Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.2454	.2774	.213	.2229	.2229	.2229
2	.2126	.2279	.2629	.213	.2229	.1981	.2035
3	.2126	.1907	.2629	.213	.2229	.2543	.2035
4	.1928	.1907	.2835	.2347	.2401	.2515	.218
5	.2279	.208	.3189	.2347	.2743	.2683	.2374
6	.2658	.2454	.3189	.2347	.2743	.2713	.2641
7	.3224	.3189	.2835	.2515	.3258	.2915	.2572
8	.3982	.3189	.2481	.2572	.2915	.2947	.2915
9	.3841	.3982	.3012	.2743	.3086	.3814	.3439
10	.4854	.4706	.3155	.2743	.3052	.3814	.362
11	.4854	.4854	.3155	.2572	.3052	.3641	.4805
12	.499	.3544	.2774	.2543	.3018	.3429	.4066
13	.4207	.3898	.2572	.2204	.2683	.3429	.462
14	.4207	.443	.2572	.285	.285	.3429	.3511
15	.499	.443	.2713	.2155	.3185	.2949	.4251
16	.4108	.3189	.2543	.2155	.3561	.2883	.4066
17	.4481	.4075	.2543	.2155	.39	.3521	
18	.4294	.4252	.2347	.2572	.373	.4024	
19	.362	.3544	.2515	.2743	.3052	.3688	.3258
20	.2896	.3012	.2515	.2686	.2543	.3561	.3077
21	.2896	.3012	.213	.2507	.2401	.3391	.2896
22	.2835	.3155	.213	.2686	.2401	.3222	.2896
23	.2629	.298	.1966	.2507	.2254	.2572	.3121
24	.2561	.2454	.2774	.2294	.2229	.2254	.2427
Max	.499	.4854	.3189	.285	.39	.4024	.4805
Min	.1928	.1907	.1966	.213	.2229	.1981	.2035
Avg	.3464	.3291	.2666	.2443	.2823	.3089	.3138

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 208 / 11KV GREAT EASTERN SUMMIT SHEDDABLE URBAN
SECT Feeder KV- 11 / OUTGOING

DATE	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7748	.7186	.7449	.7773	.7125
2		.7682	.7011	.7287	.7362	.6964
3		.7522	.6859	.7287	.7042	.6882
4		.7682	.6859	.6882	.6562	.6722
5		.7907	.6964	.6882	.6718	.7042
6		.7907	.6964	.7362	.6958	.6958
7		.8065	.7125	.8421	.6958	.7907
8		.8124	.7377	.8421	.7287	.8065
9	1.1831	.8179	.7712	1.0364	.9069	1.0802
10	1.3546	.9145	.8215	1.166	1.0526	1.406
11	1.5769	.9297	.779	1.2163	1.1336	1.4175
12	1.4883	.945	.7625	1.1843	1.0883	1.5061
13	1.4352	.9568	.7865	1.1203	1.0562	1.4175
14	1.382	.8951	.7209	1.1043	1.0279	1.382
15	1.3998		.6478	1.1203	.9804	1.4175
16	1.4022	.8078	.664	1.1363	.953	1.4175
17	1.3847	.8383	.7537	1.1385	.9842	
18	1.2094	.8796	.7935	1.0753	.9998	
19	1.1096	.953	.9393	1.0562	.9488	1.4022
20	1.046	.9217	.8907	.9602	.9172	1.2269
21	1.0395	.8905	.8583	.9282	.8962	1.1393
22	.9503	.8749	.8259	.9069	.8322	.9816
23	.8642	.8124	.7935	.8097	.7773	.8688
24		.7748	.7655	.7773	.7773	.7287
Max	1.5769	.9568	.9393	1.2163	1.1336	1.5061
Min	.8642	.7522	.6478	.6882	.6562	.6722
Avg	1.2551	.8468	.7587	.9473	.8749	1.0527

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284061 / 33/33KV SBI IDBI NMMC

Swt/Stn

Feeder No / Name : 401 / 33KV SBI - 2

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2229				
24	.0892		.2143	.2143	.2172	.2172
Max	.0892	.2229	.2143	.2143	.2172	.2172
Min	.0892	.2229	.2143	.2143	.2172	.2172
Avg	.0892	.2229	.2143	.2143	.2172	.2172

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284061 / 33/33KV SBI IDBI NMMC

Swt/Stn

Feeder No / Name : 403 / 33KV SBI - 1 & SUB ST/N NON SHEDDABLE EXPRESS HV FEEDERS
 XMER Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	09-FEB-18	10-FEB-18	11-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0869				
24		.0869	.0869	.0869	.0869
Max	.0869	.0869	.0869	.0869	.0869
Min	.0869	.0869	.0869	.0869	.0869
Avg	.0869	.0869	.0869	.0869	.0869

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284061 / 33/33KV SBI IDBI NMMC

Swt/Stn

Feeder No / Name : 404 / 33KV NMMC - 2 (1)

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	09-FEB-18	10-FEB-18	11-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1337				
24		.1337	.1337	.1337	.1337
Max	.1337	.1337	.1337	.1337	.1337
Min	.1337	.1337	.1337	.1337	.1337
Avg	.1337	.1337	.1337	.1337	.1337

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284062 / 33/11 KV SECTOR-23 ULWE

Feeder No / Name : 201 / 11 KV SECTOR-19 ULWE
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.4387			2.1719	2.0576	
2		2.3243			2.0576	1.9433	
3		2.2862			2.0576	1.9433	
4		2.4387			2.3243	2.1338	
5		2.7054			2.6292	2.4387	
6		2.8769			2.8959	2.8578	
7		2.8578			2.9531	2.8578	
8		2.7054	2.9721	2.8197	2.9531	2.7816	2.8769
9		2.5911	2.5149	2.572	2.3053	2.6482	2.2862
10	2.3624	2.2481	2.3815	2.4387		2.3815	2.21
11	2.2481	2.2291	2.0195	2.3243	2.0767	2.1148	2.0767
12	1.9433	1.848	2.0957	2.2481	1.8099	2.0767	2.1338
13	1.9814	1.7337	1.7337	2.0386	1.6956	1.8671	1.7909
14	1.9433	1.7528	1.829	1.848	1.7147	1.8671	1.7528
15	1.9433	1.829	1.8671	2.1338	1.7528	1.848	1.7909
16	2.0576	1.829		2.0386		1.7337	
17	2.0576	1.9433		2.0767			
18	2.1338	2.1338		2.0957			
19	2.8959	2.7054		2.8578			
20	2.8578			2.7625			
21	2.8578			2.6673			
22	2.7435			2.5911			
23	2.6482			2.3624			
24	2.5911	2.4768	2.4387		2.2291	2.0957	
Max	2.8959	2.8769	2.9721	2.8578	2.9531	2.8578	2.8769
Min	1.9433	1.7337	1.7337	1.848	1.6956	1.7337	1.7528
Avg	2.3510	2.2977	2.2058	2.3672	2.2418	2.2145	2.1148

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284062 / 33/11 KV SECTOR-23 ULWE

Feeder No / Name : 202 / 11 KV SECTOR-21 ULWE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2667			.2477	.2286	
2		.2477			.2286	.2096	
3		.2477			.2096	.2096	
4		.2667			.2286	.2286	
5		.3048			.2667	.2667	
6		.3429			.3048	.3048	
7		.3429			.3048	.3048	
8		.3429	.2667	.2667	.2858	.3048	.3239
9		.3239	.2858	.3239	.2858	.3429	.3048
10	.2477	.2667	.3048	.3239	.2286	.2667	.3048
11	.2667	.2477	.2477	.2858	.2477	.2667	.2286
12	.2477	.2286	.3048	.2858	.2096	.2667	.2286
13	.2477	.2096	.2477	.2858	.1905	.2477	.2286
14	.2286	.2096	.2286	.2286	.2286	.2286	.2286
15	.2286	.1905	.2096	.2286	.2286	.2096	.2286
16	.2096	.2096		.2477		.1905	.2477
17	.2286	.2096		.2477			.2667
18	.2667	.2096		.2286			.3429
19	.2858	.2858		.2858			.3239
20	.3048			.3048			.3239
21	.3048			.2858			
22	.3048			.2858			
23	.2858			.2858			
24	.2858	.2667	.2667		.2477	.2286	
Max	.3048	.3429	.3048	.3239	.3048	.3429	.3429
Min	.2096	.1905	.2096	.2286	.1905	.1905	.2286
Avg	.2629	.2610	.2625	.2751	.2465	.2533	.2755

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284062 / 33/11 KV SECTOR-23 ULWE

Feeder No / Name : 203 / 11 KV UNNATI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6668	.6097		.6287	.6097	
2		.6478	.5716		.6097	.5716	
3		.6478	.6478		.6097	.5716	
4		.724	.6859		.724	.6859	
5		.8002	.724		.8764	.8383	
6		.9145	.7621		.9526	.9526	
7		.9717	.8002		.9526	.9526	
8			.8383	.8954	.9526	.9145	.7049
9		.8002	.6859	.724	.6859	.7811	.6859
10	.6287	.6287	.743	.7049	.6859	.724	.6859
11	.6287	.6287	.5906	.7049	.6478	.4954	.5906
12	.5906	.5716	.5906	.6478	.5906	.5335	.6097
13	.5716	.4763	.4763	.5716	.4572	.4954	.4763
14	.5335	.4763	.4954	.4954	.5335	.4763	.4572
15	.5144	.4954	.4954	.5716	.5335	.4572	.4382
16	.5906	.5144	.5906	.5525	.4763	.4954	.4763
17	.5716	.5144		.5716			.5716
18	.5906	.5335		.5906			.6668
19	.743			.724			.724
20	.7621			.743			.8002
21	.7621			.724			
22	.7621			.724			
23	.7049			.724			
24	.7621	.6668	.6668		.6668	.6097	
Max	.7621	.9717	.8383	.8954	.9526	.9526	.8002
Min	.5144	.4763	.4763	.4954	.4572	.4572	.4382
Avg	.6478	.6488	.6455	.6668	.6814	.6568	.6067

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284062 / 33/11 KV SECTOR-23 ULWE

Feeder No / Name : 204 / 11 KV SECTOR-5 FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6859	.6097		.6287	.6097	
2		.6668	.5716		.6097	.5716	
3		.6668	.6097		.6097	.5716	
4		.724	.5716		.6859	.6478	
5		.8002	.6097		.8002	.7621	
6		.8383	.6478		.8764	.8383	
7		.8383	.724		.8764	.8383	
8		.8002	.743	.724	.8383	.724	.7049
9		.743	.6668	.743	.7049	.724	.6668
10	.8002	.5716	.6287	.6478	.6287	.6668	.6097
11	.5335	.5525	.6287	.6478	.6859	.5716	.4954
12	.5525	.5335	.4954	.6478	.4572	.6668	.6668
13	.5716	.4954	.5335	.6287	.4382	.4763	.4954
14	.6097	.5716	.5716	.5716	.5716	.5716	.4572
15	.6478	.6097	.6287	.5525	.5906	.6097	.4763
16	.4954	.4954	.4954	.5335		.4382	
17	.5525	.4954		.5335			
18	.5335	.5144		.5335			
19	.7621	.743		.6859			
20	.8002			.7049			
21	.9526			.724			
22	.9526			.724			
23	.9145			.6859			
24	.724	.6859	.6668		.6478	.6097	
Max	.9526	.8383	.743	.743	.8764	.8383	.7049
Min	.4954	.4954	.4954	.5335	.4382	.4382	.4572
Avg	.6935	.6516	.6119	.6430	.6656	.6411	.5716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284062 / 33/11 KV SECTOR-23 ULWE

Feeder No / Name : 205 / 11 KV Sector-20 Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4382			.381	.4001	
2		.4191			.362	.381	
3		.4001			.362	.362	
4		.4191			.4191	.4001	
5		.4572			.4954	.4572	
6		.5335			.5716	.4954	
7		.5716			.5716	.4954	
8		.5906	.5144	.4572	.5716	.4763	.5906
9		.5335	.5335	.5335	.4954	.4572	.4572
10	.4382	.4763	.4763	.5525	.4763	.5144	.4191
11	.4763	.2096	.4954	.4954	.4191	.4382	.4572
12	.4382	.4001	.4001	.4954	.362	.4382	.381
13	.4191	.4382	.4191	.4572	.381	.3429	.4001
14	.381	.381	.4001	.4001	.381	.3429	.381
15	.3429	.362	.381	.381	.3429	.3239	.362
16	.4382	.381	.4763	.4763	.362	.362	
17	.4572	.4191		.4763			
18	.4191	.4382		.4572			
19	.5144	.5144		.4954			
20	.5335			.5144			
21	.5335			.5144			
22	.4954			.5144			
23	.4572			.4572			
24	.4954	.4382	.4572		.4001	.4001	
Max	.5335	.5906	.5335	.5525	.5716	.5144	.5906
Min	.3429	.2096	.381	.381	.3429	.3239	.362
Avg	.4560	.4411	.4553	.4799	.4326	.4169	.4310

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284062 / 33/11 KV SECTOR-23 ULWE

Feeder No / Name : 206 / 11 KV Sec-5 Plot No-70

SHEDDABLE URBAN

Ulwe Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0572			.0572	.0572	
2		.0572			.0572	.0572	
3		.0572			.0572	.0572	
4		.0572			.0572	.0572	
5		.0762			.0762	.0762	
6		.0762			.0762	.0762	
7		.0762			.0762	.0762	
8		.0572	.0572	.0381	.0572	.0572	.0572
9		.0572	.0572	.0762	.0572	.0572	.0762
10	.0572	.0572	.0762	.0572	.0572	.0762	.0953
11	.0953	.0762	.0762	.0762	.0572	.0762	.0572
12	.0762	.0762	.0762	.0762	.0572	.0762	.0572
13	.0762	.0762	.0572	.0572	.0572	.0572	.0572
14	.0762	.0762	.0572	.0572	.0572	.0762	.0762
15	.0572	.0762	.0572	.0572	.0572	.0953	.0953
16	.0572	.0762	.0572	.0572	.0572	.0572	
17	.0762	.0762		.0572			
18	.0762	.0572		.0572			
19	.0762	.0762		.0572			
20	.0572			.0572			
21	.0572			.0572			
22	.0762			.0572			
23	.0762			.0572			
24	.0762	.0572	.0572		.0572	.0572	
Max	.0953	.0762	.0762	.0762	.0762	.0953	.0953
Min	.0572	.0572	.0572	.0381	.0572	.0572	.0572
Avg	.0711	.0677	.0629	.0596	.0606	.0673	.0715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284062 / 33/11 KV SECTOR-23 ULWE

Feeder No / Name : 208 / 11 KV WAHAL SEC-23

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2384			1.1431	1.0669	
2		1.2193			1.105	1.0288	
3		1.2193			1.0288	1.0288	
4		1.2574			1.0669	1.105	
5		1.3146			1.1812	1.2574	
6		1.3717			1.3336	1.3717	
7		1.3717			1.3717	1.3717	
8		1.3717	1.2384	1.3908	1.3717	1.3717	1.3336
9		1.2955	1.1431		1.2003	1.3336	1.2384
10	1.0669	1.0669	1.0288	1.1812	1.1241	1.1812	1.1431
11	1.0098	1.0479	1.0098	1.0479	.9526	1.105	1.0098
12	.9335	.9526	.9717	1.0288	.9335	.9335	1.0098
13	.9526	.8954	.8954	.9526	.9145	.8383	.9526
14	.9907	.8764	.9335	.8954	.9145	.8954	.9145
15	1.0669	.9145	.9907	.9145	.8954	.9335	.8764
16	.9907	.9717	.9526	.8764	.9335	.8954	.9526
17	.9907	.9907		.8764			1.105
18	1.0669	1.0288		.9145			1.4289
19	1.4098	1.4098		1.1812			1.1812
20	1.3527			1.2955			1.467
21	1.3717			1.2765			
22	1.3717			1.2765			
23	1.3717			1.2384			
24	1.3717	1.2384	1.2955		1.1622	1.086	
Max	1.4098	1.4098	1.2955	1.3908	1.3717	1.3717	1.467
Min	.9335	.8764	.8954	.8764	.8954	.8383	.8764
Avg	1.1545	1.1526	1.0460	1.0898	1.0960	1.1061	1.1241

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284062 / 33/11 KV SECTOR-23 ULWE

Feeder No / Name : 412 / 33 KV T.S. REHMAN

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1719	2.2291			1.829	2.1148	
2	2.2291	2.2291			2.0005	2.0576	
3	2.1719	2.4006			2.0576	2.0576	
4	2.1148	2.4006			1.829	1.9433	
5	2.0005	2.1719			1.6004	1.829	
6	2.0576	2.0576			1.6004	1.7147	
7	2.1719	1.9433			1.829	1.829	
8	2.0005	2.0576	2.0576	2.0576	2.0576	2.0005	1.9433
9	2.2862	2.4006	2.1719	2.1148	2.5149	2.1148	1.9433
10	2.0576	2.8578	2.6863	2.0005	2.0005	2.2291	2.3434
11	1.8861	2.3434	2.0576	2.0005	2.2291	2.1719	1.9433
12	1.829	2.5149	2.6292	1.829	2.4006	2.4577	2.3434
13	2.0576	3.2007	1.829	1.6004	1.9433	1.829	1.9433
14	2.7435	2.9721	2.2862	1.6575	2.7435	2.4006	2.8578
15	3.2007	3.0864	2.8006	1.8861	2.7435	2.8578	2.4006
16	2.9721	2.572	2.915	1.829	3.0293	2.4006	3.0293
17	2.6292	2.5149		1.7147			2.2862
18	2.6863	2.572		1.7147			1.2574
19	2.6292			1.7147			1.829
20	2.1148			2.0005			2.7435
21	2.1148			1.829			
22	2.1148			1.829			
23	2.1148			2.0576			
24	2.1719	2.1719	1.7147		1.829	2.1148	
Max	3.2007	3.2007	2.915	2.1148	3.0293	2.8578	3.0293
Min	1.829	1.9433	1.7147	1.6004	1.6004	1.7147	1.2574
Avg	2.2720	2.4577	2.3148	1.8647	2.1316	2.1249	2.2203

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 201 / 11KV AIR INDIA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6722	.6722	.6908	.5975	.6348	.6161	.5975
2	.6348	.6348	.6348	.5601	.5601	.5788	.5601
3	.6348	.6348	.5788	.5601	.5601	.5228	.5601
4	.7095	.6348	.5601	.5601	.5601	.5041	.6348
5	.7468	.7095	.5601	.5601	.5975	.5041	.7468
6	.8589	.7468	.6722	.5975	.7468	.6722	.8402
7	1.0269	1.0269	.7468	.6348	.9709	.8029	1.0269
8	.9149	.8962	.8215	.7468	.9149	.8215	.8962
9	.8215	.8775	.7655	.7468	.8029	.8775	.8215
10	.8215	.8215	.8402	.9335	.7842	.9149	.6722
11	.7842	.7842	.8215	.7655	.7842	.8215	.7468
12	.8029	.9335	.8962	.8775	.7842	.7655	.8215
13	.7282	.8402	.6908	.9522	.7282	.7095	.7468
14	.6722	.7095	.6908	.7468	.6161	.7095	.6908
15	.6348	.6535	.6535	.6535	.5788	.5975	.6161
16	.6161	.5975	.6161	.6535	.5975	.6161	.6348
17	.6722	.6161	.6722	.6722	.5975	.6161	.6348
18	.6722	.6535	.6535	.7095	.6161	.6535	.6535
19	.8962	.8215	.8402	.7655	.8029	.8215	.9149
20	.9149	.7842	.7468	.7282	.7842	.7655	.8962
21	.9149	.8029	.7655	.8215	.7842	.7842	.8775
22	.8775	.7842	.7842	.7842	.7655	.8215	.8775
23	.8029	.7468	.7282	.7282	.7468	.7282	.8029
24	.7282	.7282	.7282	.6348	.6908	.6535	.6348
Max	1.0269	1.0269	.8962	.9522	.9709	.9149	1.0269
Min	.6161	.5975	.5601	.5601	.5601	.5041	.5601
Avg	.7733	.7546	.7149	.7079	.7087	.7033	.7461

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 202 / 11KV JAWAHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168	.168	.168	.168	.168	.168	.168
2	.168	.168	.1494	.1494	.1494	.1494	.168
3	.168	.168	.1494	.1494	.1494	.1494	.168
4	.168	.0187	.1494	.168	.1494	.1494	.168
5	.168	.1867	.1494	.168	.168	.1494	.168
6	.1867	.2241	.168	.168	.2054	.168	.168
7	.2241	.2241	.168	.168	.2241	.2241	.2054
8	.2241	.2241	.2054	.2054	.2054	.2054	.3174
9	.2614	.2241	.1867	.2241	.168	.2054	.2614
10	.2054	.2987	.2614	.2241	.2801	.1867	.2427
11	.2801	.2987	.2801	.3174	.2427	.2054	.2427
12	.2987	.2987	.2801	.2987	.2054	.2427	.2427
13	.2054	.2987	.2987	.2987	.2054	.168	.2427
14	.2054	.2614	.2427	.2241	.2054	.1867	.2614
15	.2241	.2801	.2241	.2241	.168	.168	.2427
16	.2614	.2801	.2241	.2054	.2054	.1867	.2241
17	.2614	.2987	.2801	.2054	.2054	.168	.2801
18	.2241	.1867	.2427	.2241	.168	.1867	.2987
19	.2241	.2427	.2801	.2614	.168	.2241	.2987
20	.2241	.2614	.2427	.2614	.1867	.2241	.2801
21	.2241	.2241	.2427	.2241	.2054	.2054	.2614
22	.2054	.2241	.2241	.2054	.2054	.2241	.2427
23	.2054	.1867	.1867	.1867	.168	.1867	.3361
24	.1867	.1867	.1867	.168	.1867	.168	.168
Max	.2987	.2987	.2987	.3174	.2801	.2427	.3361
Min	.168	.0187	.1494	.1494	.1494	.1494	.168
Avg	.2155	.2264	.2163	.2124	.1914	.1875	.2357

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 203 / 11KV BANK OF INDIA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4668	.3361	.3361	.4854	.4854	.5228	.2987
2	.2987	.2987	.2801	.2614	.2801	.3734	.2987
3	.2987	.2987	.2054	.2614	.2801	.2241	.2987
4	.2987	.2987	.2054	.2614	.2801	.2054	.2987
5	.2987	.3361	.3734	.2614	.4715	.4668	.3361
6	.5601	.5228	.5415		.5601	.5601	.5601
7	.7468		.8215	.6908	.7282	.6908	.7468
8	.8215	.8215	.8029	.8215	.6161	.8029	.7842
9	.6161	.8215	.8029	.7468	.5975	.4668	.7655
10	.4854	.5041	.4854	.3547	.7468	.5228	.4481
11	.7095	.5041	.3174	.5041	.7655	.8029	.5601
12	.7468	.5041	.3174	.7842	.7468	.7655	.7655
13	.7095	.4108	.3361	.7655	.7468	.5601	.7655
14	.3174	.3174	.3547	.4854	.7282	.7282	.7655
15	.3547	.3547	.4668	.8215	.3547	.4668	.3921
16	.3921	.2801	.5788	.3547	.3921	.3734	.3921
17	.3921	.5228	.5415	.3921	.3547	.2801	.4108
18	.2987	.5415	.5415	.4854	.3174	.5601	.4294
19	.8029	.7842	.8029	.8215	.3174	.8029	.7655
20	.5975	.5788	.5601	.5975	.8215	.8402	.5415
21	.5601	.5788	.5601	.5975	.5601	.5601	.6535
22	.5975	.5788	.5601	.5788	.5601	.5788	.6161
23	.3921	.5601	.7842	.5788	.5601	.2987	
24	.8402	.3734	.3921	.7842	.8215	.6161	.4668
Max	.8402	.8215	.8215	.8215	.8215	.8402	.7842
Min	.2987	.2801	.2054	.2614	.2801	.2054	.2987
Avg	.5251	.4838	.4987	.552	.5455	.5446	.5374

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 205 / 11KV ARMY NIWAS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168	.1867	.168	.1867	.168	.1494	.1867
2	.168	.168	.168	.1867	.168	.1494	.1867
3	.168	.168	.1494	.1867	.168	.1494	.168
4	.168	.168	.1494	.1867	.168	.1494	.168
5	.168	.168	.1494	.1867	.168	.1494	.168
6	.1867	.1867	.168	.1867	.2054	.168	.2241
7	.2241	.2427	.1867	.1867	.2427	.2054	.2987
8	.2987	.2987	.2427	.2614	.3361	.2987	.3174
9	.3174	.3174	.2987	.3361	.2987	.3174	.3361
10	.2801	.2614	.2801	.2801	.2801	.2801	.2054
11	.2241	.2241	.2801	.2427	.1867	.2427	.2241
12	.2427	.2241	.2987	.2987	.2427	.3174	.2614
13	.1494	.1867	.2241	.2427	.168	.2241	.2054
14	.1867	.1867	.2241	.2241	.1867	.168	.168
15	.168	.1494	.1867	.1867	.168	.168	.168
16	.1494	.168	.168	.1494	.168	.168	.168
17	.168	.1867	.168	.168	.1494	.1867	.1494
18	.168	.168	.2614	.1867	.2054	.2614	.2427
19	.2801	.2801	.2801	.2427	.2614	.2427	.2054
20	.2427	.2801	.2241	.2614	.2054	.2614	.2614
21	.2614	.2427	.2427	.2427	.2054	.2614	.2241
22	.2241	.2427	.2241	.2241	.2241	.2427	.2427
23	.2241	.2427	.2241	.2241	.2241	.2241	.2054
24	.1867	.2054	.1867	.1867	.168	.1494	.1867
Max	.3174	.3174	.2987	.3361	.3361	.3174	.3361
Min	.1494	.1494	.1494	.1494	.1494	.1494	.1494
Avg	.2093	.2147	.2147	.2194	.2069	.2139	.2155

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 206 / 11 KV LENYADRI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.2987	.3174	.2801	.2801	.2801	.2801
2	.3361	.2987	.2801	.2614	.2614	.2614	.2801
3	.3361	.2987	.2614	.2614	.2614	.2614	.2801
4	.3361	.2987	.2614	.2614	.2614	.2614	.2801
5	.3734	.3174	.2801	.2614	.2614	.2987	.3361
6	.4108	.3361	.2987	.2987	.3547	.3361	.3734
7	.4481	.4481	.3361	.3361	.3921	.4108	.4481
8	.4854	.4294	.3734	.3921	.4481	.4668	.4481
9	.4668	.4108	.4108	.4854	.4481	.4481	.4481
10	.4294	.4108	.4481	.3921	.4668	.4854	.4481
11	.3734	.4108	.3921	.3921	.3361	.4481	.3734
12	.3361	.3547	.3547	.3547	.3361	.3921	.3174
13	.3174	.3361	.3361	.3361	.3174	.3174	.3734
14	.3174	.3174	.3174	.3174	.3174	.3174	.3174
15	.2987	.2801	.3174	.3174	.2801	.2987	.2987
16	.3361	.3174	.3174	.3174	.3174	.2987	.3174
17	.3174	.2987	.3547	.3174	.3361	.3174	.3174
18	.3174	.3361	.3921	.3734	.3361	.3174	.3174
19	.4108	.4481	.4481	.4294	.4481	.4668	.4481
20	.3921	.4668	.4481	.3921	.4481	.4294	.4481
21	.3734	.4294	.4108	.3921	.4294	.4294	.3921
22	.3734	.4294	.3734	.3361	.3734	.3921	.3921
23	.3547	.3734	.3921	.3174	.3547	.4108	.3734
24	.3921	.3361	.3547	.3174	.3174	.2987	.3174
Max	.4854	.4668	.4481	.4854	.4668	.4854	.4481
Min	.2987	.2801	.2614	.2614	.2614	.2614	.2801
Avg	.3711	.3617	.3532	.3392	.3493	.3602	.3594

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 207 / 11KV BHIMA SHANKAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4854	.4854	.4668	.4668	.4481	.4668	.4668
2	.4481	.4481	.4481	.4481	.4294	.4481	.4294
3	.4481	.4481	.4294	.4294	.4294	.4294	.4294
4	.4481	.4481	.4294	.4294	.4294	.4294	.4668
5	.5228	.5228	.4294	.4481	.4668	.4481	.5601
6	.6348	.6348	.5041	.4668	.5975	.5228	.6722
7	.7282	.7282	.5975	.4854	.6722	.6722	.7468
8	.7282	.4108	.6161	.4854	.8029	.7095	.7842
9	.7282	.6348	.5975	.6348	.5975	.6908	.6348
10	.6348	.6161	.7282	.6908	.6161	.7282	
11	.5228	.5041	.5228	.5975	.4854	.5975	.5601
12	.5228	.5041	.5415	.6535	.4854	.5601	.4854
13	.4294	.4668	.5041	.5788	.3921	.4854	.4668
14	.4481	.4294	.4854	.4481	.3921	.4294	.4108
15	.3734	.3547	.4108	.4294	.3734	.4108	.4108
16	.3921	.4108	.3734	.3547	.3547	.3361	.3547
17	.4294	.3734	.4108	.4108	.3921	.4294	.4108
18	.4854	.5415	.4854	.4668	.5415	.4481	.5041
19	.5975	.5788	.6348	.5975	.5975	.5975	.5975
20	.6348	.5788	.6161	.6161	.5975	.6535	.6348
21	.6535	.5975	.6161		.6535	.6535	
22	.6722	.6161	.6161	.6535	.6348	.6535	.6535
23	.6348	.6348	.5975	.5788	.6348	.5975	.6535
24	.5228	.5228	.5041	.5041	.4854	.5041	.5041
Max	.7282	.7282	.7282	.6908	.8029	.7282	.7842
Min	.3734	.3547	.3734	.3547	.3547	.3361	.3547
Avg	.5469	.5205	.5236	.5163	.5212	.5376	.5381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 209 / 11 KV STN TRF

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.0187	.0187	.0187	.0187	.0187	.0187
2	.0187	.0187	.0187	.0187	.0187	.0187	.0187
3	.0187	.0187	.0187	.0187	.0187	.0187	.0187
4	.0187	.0187	.0187	.0187	.0187	.0187	.0187
5	.0187	.0187	.0187	.0187	.0187	.0187	.0187
6	.0187	.0187	.0187	.0187	.0187	.0187	.0187
7	.0187	.0187	.0187	.0187	.0187	.0187	.0187
8	.0187	.0187	.0187	.0187	.0187	.0187	.0187
9	.0187	.0187	.0187	.0187	.0187	.0187	.0187
10	.0187	.0187	.0187	.0187	.0187	.0187	.0187
11	.0187	.0187	.0187	.0187	.0187	.0187	.0187
12	.0187	.0187	.0187	.0187	.0187	.0187	.0187
13	.0187	.0187	.0187	.0187	.0187	.0187	.0187
14	.6722	.0187	.0187	.0187	.0187	.0187	.0187
15	.0187	.0187	.0187	.0187	.0187	.0187	.0187
16	.0187	.0187	.0187	.0187	.0187	.0187	.0187
17	.0187	.0187	.0187	.0187	.0187	.0187	.0187
18	.0187	.0187	.0187	.0187	.0187	.0187	.0187
19	.0187	.0187	.0187	.0187	.0187	.0187	.0187
20	.0187	.0187	.0187	.0187	.0187	.0187	.0187
21	.0187	.0187	.0187	.0187	.0187	.0187	.0187
22	.0187	.0187	.0187	.0187	.0187	.0187	.0187
23	.0187	.0187	.0187	.0187	.0187	.0187	.0187
24	.0187	.0187	.0187	.0187	.0187	.0187	.0187
Max	.6722	.0187	.0187	.0187	.0187	.0187	.0187
Min	.0187	.0187	.0187	.0187	.0187	.0187	.0187
Avg	.0459	.0187	.0187	.0187	.0187	.0187	.0187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 202 / 11KV APPEJAY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4481	.4481	.4108	.4435	.415	.3921	.4108
2	.4108	.3921	.3772	.3881	.3961	.4108	.3734
3	.3921	.3734	.3395	.3696	.3429	.3921	.3361
4	.3734	.3921	.3584	.3696	.362	.3881	.3361
5	.4108	.4294	.3921	.4066	.415	.4066	.3734
6	.4668	.4715	.4294	.4435	.4527	.4435	.4108
7		.4904	.4338	.462	.4715	.4435	.4481
8	.5415	.5847	.5093		.5281	.4904	.5601
9		.5415	.5281		.547	.4904	.6161
10	.5975	.5601	.5847	.4805	.547	.5658	.5601
11	.6535	.5975	.5658	.5658	.547	.5601	.6348
12	.6348	.6348	.5658	.547	.5788	.5601	.6348
13	.6161	.6161	.547	.6036	.5788	.5788	.6161
14	.6161	.6161	.547	.5093	.5601	.6161	.6161
15	.6161	.5415	.5281	.4904	.5415	.5228	.5601
16	.5041	.5041	.547	.4715	.5041	.5415	.5281
17	.5041	.5041	.5228	.4854	.4854	.5601	.5658
18	.5228	.5175	.5975	.4904	.5228	.5788	.6224
19	.7207	.7499	.7023	.6838	.6838	.6838	.7545
20	.7023	.7023	.7316	.6468	.6584	.6653	
21	.7023	.6653	.6767	.6468	.6401	.6468	
22	.6468	.5729	.6161	.5729	.6036	.6099	
23	.5175	.4854	.4908	.5041	.5121		
24	.4854	.462	.4481	.462	.4481	.4108	.4481
Max	.7207	.7499	.7316	.6838	.6838	.6838	.7545
Min	.3734	.3734	.3395	.3696	.3429	.3881	.3361
Avg	.5493	.5355	.5187	.5020	.5142	.5199	.5203

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 203 / 11KV CIDCO OFFICE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4607	.4287	.4115	.443	.3944	.3429	.4252
2	.4119	.3814	.3814	.394	.3641	.3641	.3898
3	.3761	.3641	.3467	.3582	.3121	.3506	.3721
4	.3761	.3467	.3467	.3403	.333	.3544	.3582
5	.4298	.4161	.3601	.3582	.3856	.4075	.4119
6	.5014	.4908	.3772	.3761	.4207	.4252	.4477
7	.5373	.5258	.4382	.4119	.4784	.443	.4835
8	.591	.5959	.5249		.5973	.5249	.6447
9		.5014	.5194		.5014		.5014
10	.5373	.5014	.4908	.4887	.4607	.4344	.5194
11	.5316	.5138	.4733	.443	.4607	.4557	.4835
12	.5493	.4854	.4557	.4784	.4733	.4681	.4656
13	.5194	.5028	.4557	.4508	.4908	.4508	.4477
14	.4835	.463	.4382	.4161	.4557	.3814	.4344
15	.4835	.4115	.4557	.3772	.3856	.3814	.5249
16	.443	.4334	.4557	.3391	.4207	.4334	.5258
17	.4908	.4334	.4382	.3561	.4607	.4334	.5083
18	.4557	.4458	.5784	.4239	.4334	.4508	.5083
19	.5721	.6068	.6588	.583	.6024	.6001	.6135
20	.6001	.6135	.6241	.5658	.5434	.583	.333
21	.5658	.5487	.5721	.5487	.5784	.5658	.333
22	.5375	.5316	.5434	.5144	.4854	.5028	.2804
23	.5375	.4801	.5258	.4801	.4334		.2658
24	.4607	.4508	.4458	.4784	.4287	.3772	.4382
Max	.6001	.6135	.6588	.583	.6024	.6001	.6447
Min	.3761	.3467	.3467	.3391	.3121	.3429	.2658
Avg	.4979	.4780	.4716	.4375	.4542	.4423	.4465

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 204 / 11KV STEP GARDEN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4163	.3801	.362	.3841	.3258	.3258	.3475
2	.3841	.362	.3258	.3658	.2896	.3077	.3292
3	.3658	.3258	.3077	.3475	.2743	.3077	.3109
4	.3475	.3292	.3475	.3109	.2743	.3292	.3109
5	.3658	.4024	.3658	.3292	.3696	.3841	.3658
6	.4024	.4572	.3841	.3658	.4435	.3841	.4024
7	.4572	.5121	.3841	.3841	.4435	.4024	.439
8	.4572	.5304	.4805		.499	.4805	.4755
9		.4251	.462		.4251	.4805	.4572
10	.439	.4435	.4207	.439	.4024	.4251	.4024
11	.4066	.3841	.3982	.4435	.3658	.4207	.3658
12	.3881	.3658	.3801	.3801	.3475	.3982	.4024
13	.4066	.3403	.4163	.4163	.3475	.3982	.3841
14	.4066	.3439	.362	.3801	.3292	.3801	.3658
15	.3696	.3439	.3077	.362	.3109	.3403	.3475
16	.3142	.3077	.3258	.3258	.3109	.3582	.3292
17	.362	.3045	.3258	.3439	.3109	.3761	.3475
18	.362	.3366	.3582	.3721	.3696	.3761	.3475
19	.4656	.4344	.4298	.4525	.4805	.4477	.4755
20	.5068	.4887	.4477	.4477	.499	.5014	.4755
21	.4887	.4706	.4656	.4525	.462	.4656	.4938
22	.4887	.4525	.4525	.4298	.4207	.4344	.4755
23	.4525	.4344	.4344	.394	.4024		.4572
24	.4344	.3801	.3982	.4024	.362	.362	.3475
Max	.5068	.5304	.4805	.4525	.499	.5014	.4938
Min	.3142	.3045	.3077	.3109	.2743	.3077	.3109
Avg	.4125	.3981	.3893	.3877	.3778	.3950	.3940

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 205 / 11KV JUINAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.3018	.2829	.2829	.2641	.2641	.2829
2	.3018	.2829	.2452	.2858	.2286	.2641	.2641
3	.2829	.2452	.2286	.2667	.1905	.2452	.2477
4	.3018	.2075	.2667	.2667	.2263	.2614	.3429
5	.3772	.2858	.2829	.3048	.3395	.3174	.381
6	.4854	.4191	.3206	.3429	.4338	.3734	.4572
7	.5975	.4572	.4338	.3961	.4382	.4108	.4715
8	.6722	.5716	.5281		.5281	.6036	.547
9		.4668	.3961		.3961	.4715	.4904
10	.4481	.4294	.4294	.4527	.3018	.3961	.415
11	.3395	.3696	.3772	.3921	.3018	.3429	.3395
12	.3395	.2829	.2858	.3048	.3206	.2667	.2641
13	.2829	.2477	.2667	.3048	.2641	.2667	.2452
14	.2452	.2286	.2667	.2858	.2263	.2286	.2263
15	.2263	.2263	.2667	.2477	.2263	.2096	.2452
16	.2452	.2075	.2667	.2477	.2263	.2286	.2286
17	.2477		.2667	.2477	.2263	.2477	.2286
18	.2858	.2477	.3206	.2858	.2667	.2641	.2858
19	.3772	.3429	.3584	.3772	.3772	.3361	.3772
20	.4338	.3772	.4108	.3961	.3961	.3734	.4527
21	.3961		.3734	.3961	.3772	.3547	.415
22	.4001	.3429	.3584	.3429	.362	.3734	.415
23	.381	.3206	.3395	.3429	.3429		.3772
24	.3174	.3429	.3018	.3018	.3018	.2829	.2829
Max	.6722	.5716	.5281	.4527	.5281	.6036	.547
Min	.2263	.2075	.2286	.2477	.1905	.2096	.2263
Avg	.3601	.3275	.3281	.3215	.3151	.321	.3451

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 206 / 11KV TRUPTI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.3841	.5853	.5611	.567	.5304	.6283
2	.5544	.3658	.5487	.543	.5121	.5121	.5729
3	.499	.3511	.5228	.4887	.4755	.4938	.5544
4	.5175	.3326	.5359	.4525	.547	.5175	.5359
5	.5914	.4066	.5729	.5068	.6348	.5359	.6468
6	.7392	.6908	.6099	.5792	.6908	.6283	.7392
7	.8686	.8029	.7468	.6154	.7577	.7023	.7947
8	.961	.8589	.8962		.8775	.9149	.8316
9		.7023	.7392		.7023	.7468	.6838
10	.6653	.5914	.6653	.6878	.6468	.6535	.6099
11	.6468	.6036	.6154	.6283	.5788	.6099	.6283
12	.6099	.567	.591	.6219	.5788	.567	.6283
13	.6283	.5611	.5731	.6335	.5788	.5121	.6468
14	.5914	.5249	.5552	.5973	.5041	.5121	.6468
15	.5544	.4938	.5373	.543	.5041	.4572	
16	.5359	.4755	.5194	.5068	.5228	.4938	.5487
17	.5792	.5068	.4835	.5194	.5228	.5487	.567
18	.6154	.5552	.567	.5792	.567	.6584	.6401
19	.8417	.8059	.815	.8238	.7947	.7783	.9145
20	.9134	.8326	.8505	.8417	.8686	.8688	.9328
21	.8596	.788	.8328	.8059	.8215	.823	.8596
22	.8145	.7701	.7522	.7783	.724	.8048	.8413
23	.7421	.7133	.6984	.695	.6697		.7499
24	.6401	.6516	.6401	.5973	.6036	.567	.6468
Max	.961	.8589	.8962	.8417	.8775	.9149	.9328
Min	.499	.3326	.4835	.4525	.4755	.4572	.5359
Avg	.6771	.5973	.6439	.6185	.6355	.6277	.6891

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 207 / 11KV AUGUSTEEN FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4668	.4854	.4251	.4294	.4251	.4108	.3921
2	.4294	.4668	.3921	.3921	.3696	.4108	.3734
3	.3734	.3921	.3361	.3734	.3292	.3921	.3547
4	.3734	.3734	.3547	.3547	.3475	.3881	.3547
5	.4481	.5041	.5914	.3921	.6468	.4435	.3734
6	.5228	.6653	.6283	.4108	.7023	.4805	.4481
7	.5788	.5729	.462	.4294	.5544	.4435	.5228
8	.8029	.7023	.7392		.7577	.7207	.7468
9		.5914	.5544		.5544	.7023	.5601
10	.6348	.5729	.5359	.5601	.5359	.5729	.5788
11	.5914	.5788	.6283	.5601	.5729	.5729	.6161
12	.6468	.5601	.6099	.5729	.5729	.5487	.5975
13	.6283	.5041	.5359	.5359	.5359	.5487	.5601
14		.5041	.5175	.499	.499	.5304	.5415
15	.5175	.4854	.499	.462	.462	.4572	.5228
16	.5175	.4854	.5175	.4251	.499	.4755	.4854
17	.5914	.5228	.4805	.4805	.5359	.5487	.5601
18	.5914	.5601	.5544	.5359	.5359	.823	.5788
19	.8501	.8316	.8779	.8316	.8686	.7682	.9149
20	.8871	.6468	.8413	.6283	.7023	.7023	.1307
21	.7207	.6283	.6584	.6468	.6468		.112
22	.6908	.5544	.5914	.5729	.5729	.5788	.112
23	.5544	.4805	.5175	.499	.5228		.0934
24	.5041	.5228	.462	.4294	.462	.4481	.4294
Max	.8871	.8316	.8779	.8316	.8686	.823	.9149
Min	.3734	.3734	.3361	.3547	.3292	.3881	.0934
Avg	.5874	.5497	.5546	.5010	.5505	.5440	.4567

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 208 / 11KV RAILWAY COMPLEX

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.1715	.1905	.1886	.1698	.1905
2	.1715	.1698	.1715	.1715	.168	.1509	.1715
3	.1715	.1698	.1509	.1715	.1478	.1698	.1715
4	.1905	.1509	.1509	.1905	.1478	.1494	.1905
5	.2096	.1698	.168	.2096	.168	.1494	.2096
6	.2286	.1867	.168	.2286	.1867	.168	.2096
7	.2286	.2241	.2075	.2477	.2096	.168	.2286
8	.2286	.2614	.2477		.2286	.2477	.2286
9		.3018	.2075		.2641	.2858	.3018
10	.3584	.3584	.2263	.3018	.3584	.3429	.3395
11	.4572	.4338	.2667	.3239	.4382	.3429	.415
12	.4382	.4715	.362	.3239	.415	.362	.4715
13	.4904	.4527	.381	.3206	.415	.362	.4668
14	.4338	.415	.3429	.3018	.4338	.381	.4481
15	.415	.3961	.3239	.2858	.4338	.362	.4481
16	.5093	.4527	.3239	.2858	.415	.381	.5281
17	.4715	.4527	.3429	.2641	.4294	.381	.5281
18	.4338	.3921	.381	.2829	.415	.4001	.4715
19	.5041	.415	.415	.3395	.4481	.4715	.547
20	.4294	.4108	.3584	.3206	.3921	.3961	.462
21	.3734	.3206	.3174	.3206	.3174	.3395	.3511
22	.3048	.2858	.2987	.2667	.2667	.2829	.2957
23	.2286	.2477	.2263	.2477	.2477		.2772
24	.1886		.2075	.1905	.2075	.1886	.1905
Max	.5093	.4715	.415	.3395	.4481	.4715	.547
Min	.1715	.1509	.1509	.1715	.1478	.1494	.1715
Avg	.3328	.3186	.2674	.2630	.3059	.2892	.3393

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 201 / 11KV NRI COMPLEX

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0059	1.0974	.9877	1.0059	1.0059	.9145	.9145
2	.9145	1.0242	.9145	.9145	.9328	.8962	.8596
3	.8413	1.0059	.8779	.8413	.8316	.8413	.8048
4	.9877	1.0425	.8048	.8779	.8316	.8048	.9145
5	1.0974	1.0974	.8596	.9145	.8501	.8413	1.0242
6	1.3535	1.1157	.9145	.9694		.8962	1.134
7	1.4998	1.3717	.9694			1.0164	
8	1.3717	1.2437	1.2012	1.1523	1.1706	1.1458	1.2437
9		1.3352	1.3491	1.3169		1.2936	1.39
10	1.3535	1.2986	1.3491	1.2071	1.1888	1.423	1.2986
11	1.1888	1.2071		1.2437	1.1888	1.2071	1.1706
12		1.134	1.2254	1.4083	1.1157	1.134	
13	1.2254	1.0974	1.0974		1.0425	1.134	1.1157
14	1.0608	1.0059	1.0974		.9694	.9877	1.0059
15		.9511		1.0974	.8779	.9145	
16	.9511	.8779	.9145		.8596	.9145	.9145
17	.8871	.9145	.8596		.8413	.8596	.8596
18		.9425	.9145	.8779	.8316	.9328	
19	1.1523	1.2752	1.1888		1.2382	1.2803	1.1523
20		1.3676	1.2437			1.2437	
21	1.3535	1.3491	1.2803	1.2254	1.2382	1.3717	
22		1.2936		1.134	1.2197	1.2254	1.2437
23	1.1706	1.1827	1.1523	1.134	1.1827	1.0608	1.2071
24	1.0974	1.1157	1.0829	1.0974	1.0242	.9795	1.0059
Max	1.4998	1.3717	1.3491	1.4083	1.2382	1.423	1.39
Min	.8413	.8779	.8048	.8413	.8316	.8048	.8048
Avg	1.1396	1.1394	1.0612	1.0834	1.0221	1.0549	1.0700

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 203 / 11KV BPCL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	1.0974	1.0059	1.0242	.9877	.8779	.9328
2	.8413	1.0425	.9511	.9145	.9145	.8501	.8413
3	1.0242	.9694	.8779	.823	.7865	.8048	.9145
4	1.1888	1.0608	.8215	.8779	.7499	.8413	1.0608
5	1.3535	1.134	.9145	.9145	.7682	.9145	1.2071
6	1.5181	1.2254	1.0608	.9694		.9511	1.3352
7	1.6461	1.5912	1.2437			1.1827	
8	1.5912	1.5912	1.2936	1.5364	1.4998	1.423	1.6095
9		1.5181	1.3491	1.3535	1.4266	1.4969	1.4998
10	1.4266	1.4632	1.4784	1.39	1.4449	1.5524	1.2803
11	1.4266	1.39		1.4266	1.3352	1.4632	1.3169
12		1.3169	1.1523	1.3535	1.2803	1.3352	
13	1.2254	1.2803	1.2803		1.2254	1.1888	1.1888
14	1.134	1.1888	1.0974		1.1706	1.0242	1.0608
15		1.134		1.0608	1.0974	1.0974	
16	1.134	1.0791	1.0608		.9145	1.1523	1.1157
17	1.1706	1.1706	1.1888		1.134	1.1888	1.2986
18		1.2936	1.4266	1.3169	1.3306	1.3352	
19	1.5181	1.5339	1.4083		1.4784	1.4266	1.6644
20		1.4784	1.4266		1.5339	1.3717	
21	1.5546	1.4045	1.4632	1.2803	1.423	1.4632	
22		1.2936		1.2071	1.2936	1.1888	1.3169
23	1.2803	1.1827	1.1706	1.1523	1.1458	1.0608	1.2071
24	1.0242	1.134	1.0903	1.0974	1.0059	.9425	1.0059
Max	1.6461	1.5912	1.4784	1.5364	1.5339	1.5524	1.6644
Min	.8413	.9694	.8215	.823	.7499	.8048	.8413
Avg	1.2762	1.2739	1.1791	1.1587	1.1794	1.1722	1.2142

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 204 / 11KV SWP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.3174	.1494	.2801	.2241	.168	.2801
2	.4668	.2987	.1867	.3734	.2241	.1494	.3361
3	.3734	.2241	.1867	.4108	.2801	.112	.3734
4	.3734	.1867	.1867	.4668	.2054	.112	.2801
5	.3361	.1494	.1867	.4108	.2054	.112	.1867
6	.2801	.1307	.2987	.2241		.1307	.112
7	.2801	.2801	.3734			.2587	
8	.5788	.4854	.4854	.3921	.4481	.5544	.7468
9		.5601	.5914	.5788	.4481	.6468	.6161
10	.5788	.6348	.7392	.5601	.6535	.5729	.6161
11	.5041	.6908		.5975	.7468	.6535	.5228
12		.6908	.6653	.4481	.7095	.4108	
13	.7095	.6161	.5788		.7095	.6722	.3734
14	.4481	.4854	.3921		.5601	.7095	.5975
15		.5041		.4294	.2801	.7095	
16	.4294	.5041	.7468		.8775	.6535	.2614
17	.4668	.4481	.4108		.6348	.6535	.3734
18		.499	.4668	.5601	.1663	.2614	
19	.4108	.5544	.5975		.3326	.3734	.2801
20		.4435	.3361		.3696	.4668	
21	.3547	.3326	.4294	.3174	.2772	.3734	
22		.2587		.5601	.3696	.3174	.4108
23	.3361	.1663	.2427	.3174	.499	.2241	.2427
24	.3734	.3174	.168	.1867	.2241	.1663	.2241
Max	.7095	.6908	.7468	.5975	.8775	.7095	.7468
Min	.2801	.1307	.1494	.1867	.1663	.112	.112
Avg	.4284	.4074	.4009	.4185	.4293	.3943	.3796

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 205 / 11KV DELHI PUBLIC SCHOOL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0572	.0381	.0381	.0572	.0381	.0381
2	.0381	.0572	.0381	.0381	.0572	.0381	.0381
3	.0381	.0572	.0381	.0381	.0381	.0381	.0381
4	.0381	.0381	.0381	.0381	.0572	.0381	.0381
5	.0381	.0381	.0381	.0381	.0762	.0381	.0381
6	.0572	.0572	.0572	.0572		.0381	.0572
7	.0572	.0762	.0953			.0572	
8	.0953	.0762	.0762	.0572	.0953	.0762	.0762
9		.0953	.0572	.0572	.0953	.0953	.0572
10	.0953	.0762	.0572	.0572	.0762	.0953	.0762
11	.0762	.0762		.0572	.0762	.0572	.0762
12		.0762	.0572	.0572	.0572	.0572	
13	.0762	.0762	.0572		.0572	.0762	.0572
14	.0572	.0762	.0572		.0572	.0381	.0572
15		.0572		.0762	.0762	.0381	
16	.0572	.0572	.0572		.0762	.0381	.0572
17	.0572	.0572	.0572		.0572	.0381	.0572
18		.0572	.0762	.0572	.0572	.0572	
19	.0381	.0572	.0762		.0572	.0762	.0572
20		.0572	.0572		.0572	.0762	
21	.0762	.0572	.0572	.0572	.0572	.0572	
22		.0572		.0572	.0572	.0572	.0572
23	.0572	.0572	.0572	.0381	.0572	.0572	.0572
24	.0572	.0572	.0381	.0572	.0572	.0572	.0572
Max	.0953	.0953	.0953	.0762	.0953	.0953	.0762
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.0582	.0627	.0563	.0516	.0641	.0556	.0551

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 206 / 11KV NEELKANTH TOWER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974	1.1888	1.1458	1.0974	1.0425	1.0349	1.0059
2	.9877	1.1523	1.0719	1.0242	1.0059	.9795	.9145
3	1.1706	1.0974	.9979	.9145	.9328	.924	.8779
4	1.2803	1.1888	.924	.9877	.9145	.8871	1.0242
5	1.39	1.2986	.9979	1.0608	.9877	.9979	1.2437
6	1.5364	1.39	1.1458	1.134		1.0903	1.4632
7	1.7375	1.6461	1.386			1.2567	
8	1.6827	1.5546	1.4266	1.3352	1.6827	1.5546	1.5546
9		1.5364	1.4815	1.3169	1.5546	1.4632	1.5546
10	1.4998	1.4266	1.39	1.4083	1.4266	1.4266	1.5546
11	1.5364	1.4969		1.4815	1.5154	1.4815	1.4998
12		1.5524	1.4815	1.5546	1.46	1.3535	
13	1.5364	1.4784	1.4083		1.386	1.2986	1.4632
14	1.4632	1.3491	1.2803		1.3121	1.1888	1.3352
15		1.3121	1.2803	1.1888	1.2567	1.2437	
16	1.3717	1.2936	1.2986		1.2567	1.2437	1.2803
17	1.39	1.3676	1.4083		1.3121	1.2803	1.4632
18		1.4449	1.4266	1.39	1.3535	1.4266	
19	1.6095	1.6095	1.5912		1.5729	1.5729	1.6461
20		1.5546	1.5546		1.5181	1.4815	
21	1.5546	1.4815	1.4632	1.4266	1.4632	1.4632	
22		1.3717		1.2986	1.39	1.3169	1.4266
23	1.2986	1.262	1.3352	1.1888	1.2803	1.2071	1.3717
24	1.1888	1.2437	1.1888	1.1888	1.0608	1.0791	1.0974
Max	1.7375	1.6461	1.5912	1.5546	1.6827	1.5729	1.6461
Min	.9877	1.0974	.924	.9145	.9145	.8871	.8779
Avg	1.4073	1.3874	1.3038	1.2351	1.3039	1.2605	1.3209

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 207 / 11KV KOKAN RAILWAY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6653	.7392	.7095	.6653	.6468	.6161	.6099
2	.6099	.7023	.6161	.5544	.5914	.5601	.5544
3	.7023	.6468	.5601		.5544	.5601	.499
4	.7762	.7207	.5228	.5544	.5175	.5228	.6653
5	.8871	.8501	.5975	.6283	.5175	.6161	.8871
6	.9979	.9979	.7095	.7023		.7095	1.0719
7	1.0719	1.0349	.8029			.8589	
8	1.1088	1.0534	.924	.8871	1.0349	1.0534	1.2197
9		1.0534	1.0903	1.0349	1.0719	1.1088	1.0534
10	.9795	.9425	1.0349	1.1088	.9425	1.0534	.8871
11	.8501	.8775		1.0534	.8029	.8871	.8596
12		.7842	.8686	.9055	.7468	.7392	
13	.7947	.7095	.7762		.6722	.6838	.7577
14	.6468	.6722	.6468		.5975	.6283	.6099
15		.6161		.7023	.5228	.6283	
16	.5729	.5975	.6099		.5415	.6468	.5914
17	.7023	.6722	.7023		.6161	.6653	.6838
18		.7655	.8316	.7023	.6838	.7762	
19	.9425	.9522	1.0164		.8871	.961	.924
20		1.0269	.961		.961	.924	
21	.9795	.9425	.961	.8871	.924	.8686	
22		.8871		.8501	.8131	.8316	.9425
23	.8316	.8316	.8131	.7947	.7392	.7762	.8686
24	.7392	.7577	.7392	.7392	.6838	.6468	.6653
Max	1.1088	1.0534	1.0903	1.1088	1.0719	1.1088	1.2197
Min	.5729	.5975	.5228	.5544	.5175	.5228	.499
Avg	.8255	.8264	.7854	.7981	.7304	.7634	.7973

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 208 / 11KV KENDRIYA VIHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9694	1.0425	.961	.9145	.9328	.9335	
2	.9145	1.0059	.8871	.8779	.9145	.8871	.823
3	1.0242	.9328	.8316	.823	.8596	.8316	.9145
4	1.134	1.0608	.8871	.9145	.8413	.924	1.0242
5		1.134	.961	.9877	.8779	.961	1.1706
6	1.3169	1.2437	1.0719	1.0425		1.0534	1.2803
7	1.3717	1.39	1.1458			1.1458	
8	1.4632	1.3169	1.2437	1.2803	1.3535	1.2254	1.3352
9		1.2437	1.3352	1.2803	1.2437	1.3535	1.2803
10	1.4266	1.3352	1.4632	1.2071	1.3717	1.4083	1.4083
11	1.2986	1.2936		1.3352	1.2936	1.3352	1.262
12		1.2567	1.3169	1.3535	1.2382	1.2254	
13	1.3352	1.1827	1.2437		1.1643	1.1157	1.2803
14	1.1706	1.1088	1.0974		1.1458	1.0974	1.2254
15		1.0719		1.1157	1.1458	1.1523	
16	1.2803	1.1458	1.2254		1.1827	1.2071	1.2437
17	1.4083	1.2197	1.2986		1.2382	1.2986	1.39
18		1.2986	1.3352	1.2254	1.2803	1.3717	
19	1.5729	1.4998	1.5546		1.4266	1.4998	1.6095
20		1.5364	1.4266		1.5364	1.4632	
21	1.5729	1.4266	1.4083	1.4632	1.5912	1.4632	
22		1.2803		1.2803	1.4083	1.1888	1.39
23	1.2071	1.134	1.0974	1.1157	1.0974	1.0974	1.2437
24	1.0425	1.1088	1.0242	1.0059	.9877	.9511	1.0059
Max	1.5729	1.5364	1.5546	1.4632	1.5912	1.4998	1.6095
Min	.9145	.9328	.8316	.823	.8413	.8316	.823
Avg	1.2652	1.2196	1.1817	1.1307	1.1878	1.1746	1.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 209 / 11KV SEAWOODS PH-I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6653	.7023	.6535	.6099	.5914	.6161	.6099
2	.5914	.6653	.6161	.5544	.5914	.5601	.5544
3	.6468	.6283	.5601	.5544	.5175	.5228	.499
4	.7392	.6838	.5975	.5914	.499	.5228	.5914
5	.8316	.7577	.6535	.6099	.5359	.5601	.6838
6	.924	.8686	.7095	.6468		.6161	.7762
7	1.0164	.961	.7655			.7095	
8	.9425	.8501	.8215	.7392	.8501	.8215	.8501
9		.8501	.9149	.7762	.8131	.8029	.8501
10	.7947	.7577	.8029	.7023	.7392	.8402	.7762
11	.7392	.7468		.8501	.7095	.8029	.7762
12		.6908	.7762	.7947	.6908	.7392	
13	.7392	.6722	.7392		.6908	.7392	.7023
14	.6653	.6722	.7207		.6535	.6653	.6468
15		.6161		.6468	.5975	.7392	
16	.6468	.6535	.6838		.6535	.7947	.6099
17	.7023	.7095	.7762		.7095	.8316	
18		.7545	.7392	.7762	.7468	.7392	
19	.8131	.7468	.7947		.7842	.8316	.8686
20		.8402	.7947		.8402	.8316	
21	.8131	.8215	.7577	.7577	.7842	.8316	
22		.7468		.7577	.7468	.7762	.8131
23	.7392	.6908	.6468	.6838	.7095	.7023	.7577
24	.7392	.7207	.6722	.6099	.6468	.6348	.6468
Max	1.0164	.961	.9149	.8501	.8501	.8402	.8686
Min	.5914	.6161	.5601	.5544	.499	.5228	.499
Avg	.7639	.7420	.7236	.6860	.6864	.7180	.7066

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642] BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 210 / 11KV SEAWOODS PH-II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	11-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
10		.7577	
18			.7762
19	.8131		
Max	.8131	.7577	.7762
Min	.8131	.7577	.7762
Avg	.8131	.7577	.7762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284008 / 33/11 KV Amey Sec-4 Nerul

Feeder No / Name : 202 / 11 KV Juinagar sec 25

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.6516	.6154	.6516	.7059	.6154	.6335
2	.6878	.5792	.5792	.6154	.6697	.5792	.6154
3	.6516	.543	.5792	.6154	.6516	.5792	.5792
4	.6154	.543	.543	.6516	.6154	.6154	.5792
5	.5973	.6878	.5249	.6516	.5792	.6154	.543
6	.7602	.7602	.6516	.6335	.724	.6697	.7964
7	.8688	.8326	.7602	.6335	.9955	.6697	.905
8	.9774	1.0317	.9412	.8869	.9955	.9412	.9231
9	.8869	.9231	.9412	.8869	.8688	.905	.8688
10	.724	.6516	.7783	.8507	.6697	.7059	.6878
11	.5792	.543	.6335	.7059	.724	.6154	.543
12	.4887	.5068	.5068	.7421	.7602	.5973	.4525
13	.4706	.4525	.4887	.6516	.7964	.4887	.4887
14	.4525	.4344	.4706	.6154	.8507	.4525	.4344
15	.4163	.4163	.4525	.6154	.8507	.3982	.4344
16	.4344	.3982	.4163	.4344	.6697	.3982	.4163
17	.4887	.3982	.4344	.4887	.4163	.4706	.4706
18	.543	.4706	.543	.543	.4887	.4706	.5068
19	.7421	.7964	.8869	.7964	.7421	.7964	.8145
20	.9774	.905	.8869	.905	.8688	.905	.9231
21	.9231	.905	.905	.8869	.7964	.8145	.8869
22	.8869	.8507	.8326	.7964	.7602	.7783	.8326
23	.8507	.8145	.7964	.8326	.724	.7602	.7602
24	.7602	.7059	.6516	.724	.7421	.6697	.6697
Max	.9774	1.0317	.9412	.905	.9955	.9412	.9231
Min	.4163	.3982	.4163	.4344	.4163	.3982	.4163
Avg	.6878	.6584	.6591	.7006	.7361	.6463	.6569

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284008 / 33/11 KV Amey Sec-4 Nerul

Feeder No / Name : 203 / 11 KV E type Wadhva

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4207	.3696	.3658	.3109	.3658	.3292	.3841
2	.3841	.3142	.3292	.3109	.3292	.3292	.3658
3	.3658	.3142	.2926	.3109	.3292	.3658	.3292
4	.3292	.4024	.2926	.3658	.2926	.4024	.3109
5	.3109	.4755	.3109	.3658	.2926	.4024	.3109
6	.439	.4755	.4207	.4024	.4207	.439	.3841
7	.5304	.5304	.3658	.4024	.6401	.439	.439
8	.567	.5121	.439	.4024	.4755	.4755	.5121
9	.5487	.567	.5487	.567	.5304	.5487	.5487
10	.4755	.5121	.5487	.4755	.4572	.5304	.5487
11	.5121	.4755	.5304	.4755	.439	.4024	.3841
12	.4207	.4024	.4755	.439	.4207	.4024	.4024
13	.3326	.4207	.4572	.4207	.3841	.4024	.4207
14	.3511	.4572	.4572	.4207	.3658	.4207	.4024
15	.3881	.4207	.4572	.4207	.3292	.4207	.3475
16	.3511	.3658	.439	.3658	.3292	.3841	.3658
17	.3696	.3658	.4207	.3841	.3109	.4024	.3658
18	.3696	.3841	.439	.4024	.3658	.3658	.439
19	.4805	.4938	.4755	.4755	.3841	.4207	.5487
20	.5175	.4938	.4755	.4938	.4572	.4938	.6219
21	.499	.4938	.4207	.4207	.4572	.4938	.6036
22	.499	.439	.4207	.4572	.5041	.4207	.4755
23	.5175	.5304	.4207	.4207	.4481	.4024	.4207
24	.4572	.4251	.3841	.3658	.4024	.3658	.4024
Max	.567	.567	.5487	.567	.6401	.5487	.6219
Min	.3109	.3142	.2926	.3109	.2926	.3292	.3109
Avg	.4349	.4434	.4245	.4115	.4055	.4192	.4306

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284008 / 33/11 KV Amey Sec-4 Nerul

Feeder No / Name : 204 / 11 KV Great Eastern

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5847	.4527	.5281	.4294	.4854	.3734	.4854
2	.5658	.3961	.4904	.3734	.4668	.3361	.4481
3	.5281	.3921	.4527	.3734	.4294	.3361	.4481
4	.4904	.4294	.4338	.4108	.4294	.3547	.4108
5	.4715	.4294	.415	.4108	.4108	.3547	.3921
6	.6413	.4668	.5281	.4294	.5975	.4108	.5415
7	.6979	.4854	.5281	.4294	.6161	.4668	.5041
8	.679	.5975	.6036	.4108	.5788	.5975	.6535
9	.7545	.6161	.6224	.5228	.6722	.5415	.6348
10	.8299	.7655	.6602	.7095	.7842	.6722	.7842
11	.8299	.811	.6413	.6535	.7655	.7655	.7842
12	.811	.7733	.679	.6161	.7468	.7842	.7655
13	.7545	.679	.679	.5228	.7282	.7095	.7468
14	.6413	.679	.6602	.5228	.6908	.6535	.6535
15	.6979	.6413	.6413	.4854	.6535	.6161	.6722
16	.679	.6224	.6413	.4854	.6348	.5601	.7095
17	.6413	.6602	.6036	.4854	.6161	.6161	.6535
18	.5847	.679	.5281	.4481	.5975	.6161	.5788
19	.6224	.7922	.6413	.6348	.6535	.6535	.6535
20	.6413	.7356	.6348	.6722	.6161	.7095	.6908
21	.6036	.679	.6348	.6908	.6348	.6722	.6348
22	.5847	.6224	.5601	.5975	.5041	.5975	.5788
23	.5281	.6036	.5228	.5601	.4481	.5788	.5601
24	.6224	.4904	.5658	.4854	.5228	.4108	.5228
Max	.8299	.811	.679	.7095	.7842	.7842	.7842
Min	.4715	.3921	.415	.3734	.4108	.3361	.3921
Avg	.6452	.6041	.5790	.515	.5951	.5578	.6045

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284009 / 33 KV Sec-19A Nerul

Feeder No / Name : 202 / RHYAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0297	.0366	.032	.0297	.0366	.0297	.0316
2	.0297	.0366	.0316	.0297	.0366	.0297	.0316
3	.0297	.0366	.0316	.0297	.0366	.0297	.0316
4	.0297	.0366	.0316	.0297	.0366	.0297	.032
5	.0297	.0377	.0316	.0297	.0366	.0297	.032
6	.0297	.0366	.0316	.0297	.0366	.0297	.032
7	.0297	.0366	.0316	.0297	.0366	.0297	.0316
8	.0297	.0366	.032	.0297	.0366	.0297	.0316
9	.0297	.0366	.0474	.0297	.0366	.0297	.0316
10	.0549	.048	.0297	.0366	.0377	.0474	.0549
11	.0549	.0474	.0297	.0366	.0373	.0474	.0549
12	.0549	.0474	.0297	.0366	.0377	.0316	.0549
13	.5121	.0474	.0297	.0366	.0377	.0316	.0549
14	.0549	.048	.0297	.0366	.0297	.0316	.0549
15	.0549	.048	.0297	.0366	.0297	.032	.0549
16	.0366	.0474	.0297	.0366	.0297	.0316	.0549
17	.0366	.0474	.0297	.0366	.0297	.0316	.0366
18	.0366	.032	.0297	.0366	.0297	.0316	.0366
19	.0366	.0316	.0297	.0366	.0297	.0316	.0366
20	.0366	.032	.0297	.0366	.0297	.0316	.0366
21	.0366	.0316	.0297	.0366	.0297	.032	.0366
22	.0366	.032	.0297	.0366	.0297	.0316	.0366
23	.0366	.0316	.0297	.0366	.0297	.0316	.0366
24	.0297	.0366	.0316	.0297	.0366	.0297	.0316
Max	.5121	.048	.0474	.0366	.0377	.0474	.0549
Min	.0297	.0316	.0297	.0297	.0297	.0297	.0316
Avg	.0574	.0391	.0312	.0337	.0339	.0322	.0399

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642] BU 4642

Substation No/ Name :- 284009 / 33 KV Sec-19A Nerul

Feeder No / Name : 203 / CPWD S/S

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	10-FEB-18
HR	Load (MW)
11	.0297
12	.0297
13	.0297
14	.0297
Max	.0297
Min	.0297
Avg	.0297

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284009 / 33 KV Sec-19A Nerul

Feeder No / Name : 204 / NCRD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2382	1.1888	1.1203		1.0608	1.0164	1.0829
2	1.2012	1.0791	1.0269	1.0534	.9694	.9979	
3	1.1827	1.0059	.9896	1.0164	.9328	.961	.9335
4	1.2197	1.0059	1.0269	1.0534	.9328	.9425	.9709
5	1.2567	1.1157	1.1203	1.0719	1.0751	1.0719	1.0829
6	1.386	1.2254	1.2136	1.0903	1.2071	1.0903	1.2136
7	1.4784	1.4335	1.251	1.0903	1.3352	1.1088	1.419
8	1.4784	1.3717	1.3256	1.2012	1.2986	1.3121	1.3817
9	.0297	1.6448	1.4563	1.4045	1.3169	1.3306	1.4937
10	1.7164	1.7364	1.5339	1.4449	1.5708	1.6057	1.5912
11	1.8107	1.7924	1.6263	1.5729	1.6632	1.7177	1.9022
12	1.8473	1.8671	1.6817	1.6975	1.5708	1.6617	1.8656
13	1.829	1.9418	1.7372	1.6827	1.5708	1.6057	1.7924
14	1.7193	1.8111	1.6078	1.5546	1.4784	1.4937	1.7375
15	1.6461	1.6617	1.4784	1.2437	1.5524	1.419	1.6278
16	1.7924	1.6244	1.4784	1.3169	1.5339	1.4937	1.6827
17	1.8107	1.5684	1.5154	1.4083	1.5708	1.587	1.7193
18	1.8107	1.7177	1.6632	1.4632	1.6078	1.6617	1.7558
19	1.8839	1.9605	1.8111	1.7193	1.848	1.8298	1.8839
20	1.7741	1.8671	1.7002	1.6095	1.7741	1.7364	1.8839
21	1.6827	1.643	1.6263	1.5912	1.6078	1.643	1.8673
22	1.4998	1.5497	1.5708	1.5546	1.5524	1.5123	1.6644
23	1.39	1.4003	1.3306	1.3169	1.2936	1.419	1.5181
24	1.2752	1.2254	1.2136	1.1088	1.1317	1.0534	1.1389
Max	1.8839	1.9605	1.8111	1.7193	1.848	1.8298	1.9022
Min	.0297	1.0059	.9896	1.0164	.9328	.9425	.9335
Avg	1.4983	1.5182	1.4211	1.3594	1.3940	1.3863	1.5308

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284009 / 33 KV Sec-19A Nerul

Feeder No / Name : 205 / Navdurga S/S

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4938	.4938	.4481	.4024	.3841	.3658	.4066
2	.4572	.4572	.4481	.3658	.3475	.3841	.3696
3	.439	.4024	.4066	.3841	.3475	.3658	.3511
4	.3841	.4024	.4066	.362	.3475	.3475	.3696
5	.4572	.4938	.4854	.4024	.4338	.4024	.4066
6	.5487	.5853	.5228	.4207	.567	.4572	.462
7	.6584	.7133	.5601	.4572	.6036	.5487	.5544
8	.6584	.6036	.5788	.4938	.5853	.5487	.6161
9	.6036	.6401	.5975	.6036	.567	.4938	.6348
10	.5853	.6722	.5853	.695	.5853		.5853
11	.6401	.5975	.5853	.6767	.5121	.6348	.5853
12	.5487	.6161	.6219	.6219	.439	.5975	.5121
13	.5304	.5228	.5304	.5853	.4755	.5175	.4572
14	.5121	.4805	.5487	.5304	.4207	.5175	.4572
15	.5121	.462	.4572	.4755	.4207	.4435	.4024
16	.5121	.499	.4207	.4938	.4024	.462	.4207
17	.5121	.5359	.4755	.5121	.4207	.4805	.5121
18	.4572	.5175	.5121	.4938	.4572	.5175	.4755
19	.5853	.6348	.6036	.6219	.5487	.6722	.6219
20	.6219	.6348	.6219	.6767	.6036	.6722	.567
21	.6584	.5975	.6401	.6219	.5853	.6535	.6767
22	.567	.6161	.5304	.5853	.5121	.6161	.6219
23	.5304	.5175	.5121	.4938	.4938	.5415	.567
24	.5121	.4755	.4854	.439	.439	.4207	.4435
Max	.6584	.7133	.6401	.695	.6036	.6722	.6767
Min	.3841	.4024	.4066	.362	.3475	.3475	.3511
Avg	.5411	.5488	.5244	.5173	.4791	.507	.5032

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284009 / 33 KV Sec-19A Nerul

Feeder No / Name : 206 / 11 KV DY Patil

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.7865	.6348	.6413	.695	.6036	.6348
2	.7167	.7133	.5975	.6224	.6602	.5847	.5975
3	.6979	.6401	.5975	.6036	.5853	.5658	.5601
4	.6602	.6036	.5788	.5658	.5847	.547	.5601
5	.7167	.6219	.5914	.6154	.6036	.5281	.5975
6	.7167	.6219	.6283	.6335	.6602	.5658	.6535
7	.7356	.6584	.6908	1.1403	.6219	.6224	.6908
8	1.1506	.8413	.8215	.6335	.8413	.7545	.8962
9	1.3014	1.1317	.8775	.6224	.9877	.8676	1.0642
10	1.4632	1.419	.9619	.6767	1.2449	.7655	1.3352
11	1.4815	1.3817	1.1317	.7316	1.2071	.8962	1.2986
12	1.4632	1.475	1.0562	.823	1.2826	.8402	1.2803
13	1.3717	1.3256	1.0751	.8413	1.1883	.8215	1.3352
14	1.4083	1.3256	1.0185	.695	1.2071	.7842	1.2437
15	1.5181	1.419	.9997	.6584	1.1128	.8402	1.3352
16	1.4632	1.3443	.9808	.679	1.1883	.8402	1.3535
17	1.3169	1.1576	.9242	.6413	.9431	.8402	1.2437
18	.9328	.9149	.8299	.6584	.8676	.8215	1.0059
19	1.134	.9709	.9054	.6584	.8299	.8215	1.0242
20	.9328	.9149	.7733	.6767	.811	.7842	1.5729
21	.8048	.8962	.7545	.6767	.7733	.7282	1.6461
22	.8059	.7842	.679	.6767	.7167	.7468	1.6644
23	.7133	.7282	.6602	.6584	.6602	.7282	1.4998
24	.7922	.7499	.6722	.6602	.6401	.6602	.6722
Max	1.5181	1.475	1.1317	1.1403	1.2826	.8962	1.6644
Min	.6602	.6036	.5788	.5658	.5847	.5281	.5601
Avg	1.0438	.9761	.8100	.6871	.8714	.7316	1.0736

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284009 / 33 KV Sec-19A Nerul

Feeder No / Name : 207 / 11 KV Brahmakumari

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1765	1.0608	1.0269	1.0136	1.0059	.9774	1.0269
2	1.1222	.9511	.9896	.9774	.9694	.9593	.9709
3	1.086	.9145	.9335	.9412	.8962	.9412	.9335
4	1.2308	.8596	.9335	.905	.9328	.905	.9709
5	1.267	1.0185	1.0269	.9774	1.0059	.9412	1.1203
6	1.3394	1.1506	1.1203	1.0498	1.134	1.1765	1.2696
7	1.3937	1.3717	1.2883	1.1041	1.3535	1.2489	1.4003
8	1.3756	1.4045	1.3256	1.1584	1.3535	1.267	1.419
9	1.3756	1.3575	1.363	1.2308	1.2986	1.419	1.3817
10	1.2437	1.251	1.267	1.2254	1.1946	1.3256	1.1888
11	1.1888	1.3443	1.3032	1.2071	1.1403	1.251	1.1888
12	1.2803	1.2136	1.1765	1.2986	1.0136	1.1949	1.1888
13	1.1706	1.2136	1.1222	1.1888	1.086	1.2136	1.134
14	1.0974	1.1203	1.1403	1.0974	.9412	1.0903	1.0974
15	.9511	1.0082	.9955	1.0059	.8688	.9979	1.0242
16	.9694	.9896	.9774	1.0242	.9412	1.0349	.9511
17	1.0425	.9709	1.0136	1.0425	1.0317	1.0719	1.0242
18	1.0974	1.0642	1.1222	1.0974	1.086	1.1576	1.1523
19	1.4083	1.4003	1.3756	1.2986	1.3394	1.4563	1.5181
20	1.4449	1.4003	1.3032	1.3535	1.4118	1.4563	1.4632
21	1.4449	1.363	1.3394	1.3169	1.2489	1.4003	1.4998
22	1.386	1.4003	1.1946	1.2437	1.2489	1.3443	1.39
23	1.2437	1.1763	1.1584	1.1706	1.086	1.2136	1.2071
24	1.1946	1.0974	1.0642	1.0317	1.0608	.9955	1.0642
Max	1.4449	1.4045	1.3756	1.3535	1.4118	1.4563	1.5181
Min	.9511	.8596	.9335	.905	.8688	.905	.9335
Avg	1.2304	1.1709	1.1484	1.1233	1.1104	1.1683	1.1910

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284009 / 33 KV Sec-19A Nerul

Feeder No / Name : 208 / 11 KV Anand Vaibhav Garden

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.1829	.2241	.2241	.1829	.2241	.2218
2	.2241	.1646	.1848	.2054	.1698	.1867	.1848
3	.1867	.1646	.1848	.1867	.1463	.168	.1663
4	.168	.1463	.1848	.168	.1646	.168	.1663
5	.1867	.2012	.2033	.168	.2012	.1867	.1848
6	.2241	.2378	.2427	.1867	.2561	.1867	.1848
7	.2801	.2743	.2801	.1867	.2195	.1867	.2218
8	.2987	.2926	.2033	.2241	.2743	.2427	.3361
9		.3174	.2614	.2241	.2378	.2427	.2614
10	.2378	.2801	.2801	.2926	.2801	.2987	.2561
11	.2926	.2987	.2614	.2926	.2427	.2987	.2195
12	.2378	.2614	.2614	.3109	.2427	.2801	.2378
13	.3109	.3174	.2614	.3292	.2801	.2801	.2926
14	.2378	.2614	.2427	.2743	.1867	.2054	.2012
15	.1829	.1867	.2054	.2378	.1867	.2033	.1829
16	.1829	.1867	.1867	.2012	.1867	.2218	.1646
17	.1829	.1848	.1867	.2195	.2054	.2218	.1829
18	.2378	.2427	.2427	.2012	.2054	.2402	.2561
19	.3475	.3174	.2987	.3292	.2987	.3174	.3475
20	.4024	.3361	.2987	.2926	.2987	.3174	1.0974
21	.3658	.3174	.2987	.2926	.2987	.3174	1.0136
22	.2829	.2614	.2987	.2561	.2987	.2801	.9328
23	.2561	.2402	.2427	.2195	.2427	.2614	.8488
24	.2801	.2378	.2218	.2427	.2195	.2241	.2402
Max	.4024	.3361	.2987	.3292	.2987	.3174	1.0974
Min	.168	.1463	.1848	.168	.1463	.168	.1646
Avg	.2551	.2463	.2399	.2402	.2303	.2400	.3501

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284051 / 33/11KV SBI S/Stn

Feeder No / Name : 201 / 11KV SBI I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.4024			.4066		.4251
7		.5487			.499		.5175
8	.567	.6468	.5175	.5175	.6099	.4435	.6283
9	.6219	.5729	.4805	.5175	.5914	.5175	.6099
10	.4572	.499	.5359	.499	.499	.5359	.5175
11	.4755	.3696	.5175	.499	.3696	.4251	.4066
12	.4024		.4251		.3696	.4435	
13		.3696	.4251		.3326	.3511	.3326
14	.3292	.2772	.3696	.4066	.2957	.3326	.3326
15	.3109	.3142	.2957	.3881	.2587	.2772	.3326
16	.3292	.2772	.3142	.3142			.2957
17	.2926	.2772	.3142	.3326	.2587	.2587	.2772
18	.3841	.2957	.3881		.3142	.3511	.3326
19	.5121	.5544	.5175	.5175	.5544	.5729	
20	.5121	.5359	.499	.5359	.4435	.5175	.5729
21	.5121	.5175	.4805	.499	.499	.499	.5544
22	.4755	.462	.462	.462	.462	.499	.4805
24		.3841			.3475		.3511
Max	.6219	.6468	.5359	.5359	.6099	.5729	.6283
Min	.2926	.2772	.2957	.3142	.2587	.2587	.2772
Avg	.4416	.4297	.4362	.4574	.4183	.4303	.4354

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642] BU 4642

Substation No/ Name :- 284051 / 33/11KV SBI S/Stn

Feeder No / Name : 202 / 11 KV SBI II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18
HR	Load (MW)
13	.3475
Max	.3475
Min	.3475
Avg	.3475

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 283034 / 22/22KV Shirawane MIDC

Feeder No / Name : 301 / 22KV Feeder No 1- Fugro SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2286	.2286	.1905	.1905	.2286	.2286
2	.2286	.2286	.2286	.1905	.1905	.1905	.3048
3		.2286			.1905	.1905	.2667
4	.2286	.2286			.1905	.1905	.2667
5	.2286	.2286	.2286	.1905	.1905	.1905	.2667
6	.2286	.2286			.1905	.1905	.2286
7	.1905	.1905	.2286	.1905	.1905	.1905	.2286
8	.2286	.2286	.2286	.1905	.2286	.2286	.2286
9	.2286	.2286	.2286	.1905	.2286	.2286	.3048
10	.3048	.3048	.2286	.2286		.3048	.3429
11	.381	.3429	.0762	.2286		.3429	.4191
12	.3429	.3429	.0762	.2286	.3429	.381	.381
13	.3429	.3048	.2286	.2286	.3048	.3429	.3429
14	.3429	.3048	.2286	.2286	.3048	.3048	.3048
15	.4572	.3429	.2286	.2286	.381	.381	.381
16	.381	.3429	.2286	.2286	.381	.381	.381
17	.3048		.2286	.1905	.3048		.3048
18	.2286	.2667	.1905	.1905	.2667	.3048	.3048
19	.2286	.2667	.2286	.1905	.2286	.2286	.2286
20	.2286	.2286		.1905	.2286	.2286	.2286
21	.2286	.1905			.1905		.2286
22	.2286		.1905		.2286	.1905	.2286
23	.2286	.2286	.2286		.2286	.2286	.2667
24	.2286	.2286	.2286	.1905	.1905	.1905	
Max	.4572	.3429	.2286	.2286	.381	.381	.4191
Min	.1905	.1905	.0762	.1905	.1905	.1905	.2286
Avg	.2717	.2598	.2085	.2053	.2442	.2563	.2899

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 283034 / 22/22KV Shirawane MIDC

Feeder No / Name : 302 / 22KV Feeder No2- Vilaxmi- SHEDDABLE FEEDER HAVING WEEKLY
 Hari Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.2193	1.2193	1.1431	1.3336	1.0669	1.1812
2	1.0669	1.1812	1.1812	1.0669		1.0669	1.448
3	.9907	1.1812				1.0669	1.4861
4	.8764	1.1812				1.0669	1.1431
5	.8764	1.1812	1.1431	.9145		1.0669	1.105
6	.8764	1.1812				1.105	.9526
7	.8764	.8002	1.105	.8383		.9526	
8	1.0669		1.105	.8002		.9526	.8002
9	1.1431	1.0288	1.105	.7621		.8383	1.1431
10	1.5623	1.1431	1.2193	.8383	1.3336	.9145	1.4098
11	1.6766	1.4098	1.2955	.8764		1.105	1.4861
12	1.448	1.3717	1.2574	.9526	1.5242	.9907	1.448
13	2.0576	1.2955	1.0288	.9526	1.3717	1.0288	1.3336
14	1.448	1.3336	1.105	.9145		1.0288	1.4098
15	1.5242	1.3717	1.105	.8764	1.448	1.105	1.6385
16	1.4861	1.4098	1.105	.8383	1.448	1.0669	1.448
17	1.4861	1.448	1.1812	.8383	1.3717		1.4861
18	1.3336	1.2955	.9907	.7621	1.3336	1.0669	1.4861
19	1.1812	1.1812	.9526	.7621	1.1812	1.0669	1.2955
20	1.105	.9526		.7621	.8764	.9907	.9907
21	.9526	.9526			.8764		.8383
22	.8383		.8002		.724	.6478	.8002
23	1.1812	1.2193	1.0669		1.105	1.1812	.8002
24	1.2193	1.2955	1.2193	1.1431	1.2955	1.2955	
Max	2.0576	1.448	1.2955	1.1431	1.5242	1.2955	1.6385
Min	.8383	.8002	.8002	.7621	.724	.6478	.8002
Avg	1.2257	1.2106	1.1150	.8912	1.2302	1.0305	1.2332

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 283034 / 22/22KV Shirawane MIDC

Feeder No / Name : 303 / 22KV Feeder No3- Dy. Patil SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4191	.4572	.4191	.6097	.381	.381
2	.4572	.4191	.4191	.381		.381	.724
3	.4572	.4191				.3429	.381
4	.4572	.4191				.3429	.381
5	.4572	.4191	.381	.4191		.3429	.381
6	.381	.4191				.3429	.381
7	.3429	.3429	.4191	.4572		.3429	.381
8	.4954	.4191	.4572	.4572		.4572	.381
9	.6478	.4191	.4954	.4572		.6097	.4572
10	.8002	.5716	.5716	.5335	.6097	.6859	.6478
11	.7621	.6859	.6859	.6097		.6859	.6478
12	.7621	.6478	.724	.5335	.724	.724	.7621
13	.7621	.6097	.6478	.5335	.6478	.6478	.6097
14	.7621	.5716	.6859	.5335		.6859	.6859
15	.8764	.9526	.724	.5716	.6859	.7621	.724
16	.8764	.6478	.724	.6097	.7621	.8764	.8383
17	.8002	.6478	.724	.4191	.7621		.6859
18	.7621	.6478	.6859	.4954	.6859	.6478	.6097
19	.6859	.5716	.5335	.4572	.4954	.5335	.5335
20	.6097	.4954		.381	.4954	.4572	.4572
21	.6097	.4954			.4572		.5335
22	.6097		.4572		.4954	.4572	.4572
23	.4572	.4572	.4572		.4191	.381	.4572
24	.4572	.4572	.4572	.4191	.4191	.4191	
Max	.8764	.9526	.724	.6097	.7621	.8764	.8383
Min	.3429	.3429	.381	.381	.4191	.3429	.381
Avg	.6144	.5285	.5635	.4826	.5906	.5231	.5434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 283034 / 22/22KV Shirawane MIDC

Feeder No / Name : 304 / 22KV Feeder No4- Lalit SHEDDABLE FEEDER HAVING WEEKLY
 Vitessi Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478	.6097	.6097	.6859		.6097	.6478
2	.6097	.5716	.5716	.6478		.6097	.6859
3	.5716	.5716				.6097	.724
4	.5716	.5716				.6097	.724
5	.5716	.5716	.6097	.6097		.6097	.724
6	.6097	.5716				.6478	.6859
7	.6478	.6097	.6478	.6478		.6097	.6859
8	.8383	.6478	.6859	.6097		.6859	.724
9	.9526	.724	.6859	.6097		.9145	.7621
10	1.0288	.8002	.8383	.6097		.9907	1.0669
11	1.1431	.8764	.9145	.6478		.9907	1.2574
12	1.1812	.9145	.9907	.6478	1.2574	1.105	1.2574
13	1.1431	.8764	.9145	.6478	1.0669	.9526	1.105
14	1.1812	.9145	.9145	.6478		1.1431	1.2193
15	1.2193	.9526	1.0669	.6859	1.2193	1.105	1.2955
16	1.2193	.9526	1.0669	.7621	1.1431	1.105	1.1812
17	.9907	.9145	.9145	.6478	1.0669		.9907
18	.9145	.8002	.9145	.5716	.9526	.9145	.9145
19	.8383	.7621	.8383	.5716	.8764	.8764	.8764
20	.8383	.724		.5716	.8764	.7621	.724
21	.6859	.6478			.8002		.6097
22	.6478		.6478		.724	.6478	.6859
23	.6859	.6097	.6478		.6097	.6478	.6859
24	.6859	.6859	.6097	.6859	.5716	.6478	.6097
Max	1.2193	.9526	1.0669	.7621	1.2574	1.1431	1.2955
Min	.5716	.5716	.5716	.5716	.5716	.6097	.6097
Avg	.851	.7339	.7942	.6393	.9304	.8089	.8685

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 283034 / 22/22KV Shirawane MIDC

Feeder No / Name : 305 / 22KV Feeder No5- Jaspal - SHEDDABLE FEEDER HAVING WEEKLY
Shree Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2955	1.3336	1.2955	1.3717		1.4098	1.1431
2	1.2193	1.3336	1.2574	1.3336		1.3336	1.2955
3	1.2193	1.3336				1.2955	1.3336
4	1.2193	1.3336				1.2955	1.4861
5	1.2193	1.3336	1.1431	1.2193		1.2955	1.5623
6	1.2955	1.3336				1.2955	1.448
7	1.3717	1.3336	1.2574	1.1812		1.3336	1.448
8	1.5242	1.4098	1.2955	1.2574		1.3717	1.3717
9	1.6004	1.4098	1.3336	1.3336		1.5242	
10	1.9814	1.5242	1.4861	1.5242		1.7909	1.6766
11	1.7528	1.6004	1.6385	1.6766		1.9814	1.9052
12	2.1719	1.6385	1.6766	1.6004	1.8671	1.9814	1.829
13	2.0957	1.4861	1.6766	1.5623	1.9433	1.7909	1.9052
14	2.1719	1.6004	1.6766	1.5623		1.829	1.829
15	2.1719	1.5623	1.829	1.448	1.9433	2.0576	1.9052
16	2.2481	1.7528	1.829	1.6385	1.9433	2.0957	1.9433
17	1.9052	1.5623	1.5623	1.5242	1.829		1.7528
18	1.8671		1.5242	1.5242	1.6385	1.9052	1.5242
19	1.3717	1.3336	1.4861	1.448	1.5242	1.7147	1.3336
20	1.4861	1.3717		1.3717	1.5623		1.448
21	1.3717	1.4098			1.5623		1.3336
22	1.2955		1.4098		1.5242	1.4098	1.3336
23	1.4098	1.2193	1.4098		1.448	1.5242	1.4861
24	1.3336	1.4098	1.2955	1.3717	1.4098	1.4098	1.448
Max	2.2481	1.7528	1.829	1.6766	1.9433	2.0957	1.9433
Min	1.2193	1.2193	1.1431	1.1812	1.4098	1.2955	1.1431
Avg	1.6083	1.4375	1.4780	1.4416	1.6829	1.6022	1.5540

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 283034 / 22/22KV Shirawane MIDC

Feeder No / Name : 306 / 22KV Feeder No6- Elder - SHEDDABLE FEEDER HAVING WEEKLY
Geldop Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2286	.2286	.2667		.2286	.2286
2	.2286	.2286	.2286	.2667		.2286	.2286
3	.2286	.2286				.2286	.3048
4	.2286	.2286				.2286	.3048
5	.2286	.2286	.2667	.2667		.2286	.2667
6	.2286					.2286	.2667
7	.2286	.2667	.2667	.2667		.2286	.2667
8	.2667	.2667	.2667	.2667		.2286	.3048
9	.2667	.2667	.2667	.2667		1.5242	
10	.4191	.2667	.3048	.3429		.3429	.381
11	.5335	.2667	.3048	.4191		.381	.381
12	.4191	.2667	.3429	.381	.381	.3429	.3048
13	.381	.2667	.3429	.3429	.381	.381	.3429
14	.4191	.3048	.381	.3429		.381	.3429
15	.3429	.2667	.381	.3429	.3429	.4191	.3429
16	.381	.2667	.381	.3429	.381	.4191	.381
17	.381	.3048	.3048	.381	.381		.4191
18	.4191	.3048	.381	.4191	.3429	.381	.3048
19	.3429	.2667	.381	.3429	.3429	.3048	.3048
20	.2667	.2667		.2667	.2286	.2286	.2286
21	.2667	.2286			.2667		.2286
22	.2667		.2667		.2286	.2667	.2286
23	.2286	.2667	.2667		.2286	.2286	.2286
24	.2286	.2667	.2667	.2667	.2667	.2286	.2286
Max	.5335	.3048	.381	.4191	.381	1.5242	.4191
Min	.2286	.2286	.2286	.2667	.2286	.2286	.2286
Avg	.3096	.2615	.3068	.3217	.3143	.3481	.2965

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284005 / 33/11KV Sec 30, Sanpada

S/Stn

Feeder No / Name : 201 / 11KV SAMNA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6468	.567	.5487	.5544	.6401	.4115	.462
2	.6283	.6036	.5316	.5359	.6036	.4115	.4435
3	.6099	.567	.5487	.5175	.567	.463	.4435
4	.6099	.5487	.4287	.499	.5121	.4115	.4435
5	.5914	.5853	.4115	.4805	.439	.3944	.4435
6	.5914	.6036	.3772	.462	.4207	.3944	.4805
7	.5729	.6401	.4115	.4251	.6036	.4458	.5359
8	.5914	.5487	.463	.462	.5121	.463	.6099
9	.5729	.6036	.463	.5544	.567	.4801	.5914
10	.6468	.6036	.5487		.6036	.583	.6099
11	.5544	.5144	.6468	.6036	.583	.5914	.5914
12	.5304	.4458	.7023	.5853	.4973	.5544	.5729
13	.5121	.463	.5914	.5853	.4458	.5175	.5544
14	.5487	.4115	.5914	.5853	.4458	.4435	.499
15	.4024	.3944	.6099	.4938	.4287	.4251	.5487
16	.439	.4287	.5914	.5121	.4115	.4066	.439
17	.4755	.463	.4805	.4755	.4115	.4435	.5121
18	.4938	.4801	.5175	.4755	.5144	.5544	.5487
19	.5487	.6173	.5544	.5487	.5144	.5914	.6036
20	.6767	.5487	.5729	.6219	.5316	.5729	.6584
21	.695	.5316	.5914	.6584	.5487	.5914	.6767
22	.6036	.5144	.5914	.5853	.583	.5729	.6401
23	.7682	.5144	.5544	.6584	.6173	.5175	.6036
24	.6653	.567	.5658	.5544	.6767	.4287	.4805
Max	.7682	.6401	.7023	.6584	.6767	.5914	.6767
Min	.4024	.3944	.3772	.4251	.4115	.3944	.439
Avg	.5823	.5319	.5373	.5406	.5283	.4862	.5414

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284005 / 33/11KV Sec 30, Sanpada
S/Stn

Feeder No / Name : 202 / 11 KV MITTAL TOWER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.1097	.1029	.1478	.128	.1029	.1478
2	.1478	.128	.12	.1294	.0914	.1029	.1294
3	.1294	.1097	.12	.1294	.0914	.1029	.1294
4	.1294	.1097	.1029	.1294	.0914	.1029	.1294
5	.1294	.128	.1029	.1294	.1097	.1029	.1294
6	.1294	.1463	.1029	.1294	.128	.1029	.1294
7	.1294	.1646	.12	.1294	.1646	.12	.1478
8	.1663	.1463	.12	.1294	.128	.12	.1663
9	.1663	.1646	.12	.1478	.0549	.1543	.1663
10	.1478	.1463	.1372	.1829	.128	.12	.1478
11	.1663	.12	.1478	.1646	.1372	.1294	.1478
12	.128	.12	.1478	.128	.1372	.1294	.1478
13	.1097	.1029	.1478	.3658	.1029	.1478	.1294
14	.128	.12	.1478	.128	.1029	.1478	.1663
15	.1463	.1372	.1478	.128	.12	.1478	.1463
16	.1463	.12	.1294	.128	.12	.1478	.128
17	.1463	.12	.1294	.1097	.12	.1478	.1463
18	.128	.1029	.1478	.128	.1029	.1478	.1463
19	.1097	.12	.1478	.128	.12	.1478	.1646
20	.1463	.12	.1663	.128	.1029	.1663	.0732
21	.128	.1372	.1478	.1463	.1029	.1663	.1463
22	.128	.1372	.1663	.1097	.12	.1848	.128
23	.1097	.12	.1663	.1097	.1029	.1848	.128
24	.1478	.0914	.1029	.1663	.1097	.1029	.1478
Max	.1663	.1646	.1663	.3658	.1646	.1848	.1663
Min	.1097	.0914	.1029	.1097	.0549	.1029	.0732
Avg	.1371	.1259	.1330	.1439	.1132	.1346	.1404

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284005 / 33/11KV Sec 30, Sanpada

S/Stn

Feeder No / Name : 203 / 11 KV IPCL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2587	.2378	.2229	.2587	.2195	.1886	.2218
2	.2587	.2561	.1886	.2402	.2012	.1715	.2218
3	.2587	.2195	.1715	.2218	.1829	.1715	.2218
4	.2587	.1829	.1715	.2218	.1829	.1543	.2033
5	.2402	.1829	.1715	.2033	.2012	.1543	.1848
6	.2218	.2195	.1715	.1848	.2012	.1715	.2033
7	.2587	.2378	.1886	.1848	.2195	.1886	.2218
8	.2772	.2561	.1886	.2033	.2378	.2229	.2402
9	.4066	.3841	.2401	.2218	.3109	.2915	.3881
10	.462	.3841	.3429	.2743	.3841	.3086	.4066
11	.4805	.4287	.4066	.2926	.3944	.3696	.4435
12	.4938	.4287	.4251	.3109	.4115	.3881	.462
13	.4572	.463	.4066	.3658	.3944	.4066	.4805
14	.4755	.4287	.4066	.3292	.3944	.4251	.462
15	.439	.4115	.4251	.2926	.3772	.3881	.4572
16	.4207	.3944	.4435	.2743	.3944	.3696	.4572
17	.4572	.4115	.4251	.2561	.4115	.3696	.4207
18	.439	.4115	.4251	.3475	.3944	.3511	.4755
19	.439	.4458	.4251	.3292	.4115	.3511	.4938
20	.4207	.3772	.4066	.3292	.3601	.3326	.4207
21	.3658	.3429	.3696	.3658	.3429	.3326	.4024
22	.3658	.3086	.3511	.3109	.2915	.3326	
23	.3292	.2743	.3326	.2743	.2401	.2587	.3109
24	.2772	.2378	.2572	.2772	.2561	.2058	.2402
Max	.4938	.463	.4435	.3658	.4115	.4251	.4938
Min	.2218	.1829	.1715	.1848	.1829	.1543	.1848
Avg	.3651	.3302	.3152	.2738	.3090	.2877	.3496

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284005 / 33/11KV Sec 30, Sanpada
S/Stn

Feeder No / Name : 208 / 11 KV PUDHARI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.1097	.1029	.1294	.1097	.1029	.1109
2	.1478	.0914	.0857	.1109	.1097	.0857	.1109
3	.1294	.0914	.0686	.1109	.0914	.0857	.0924
4	.1294	.0732	.0686	.1109	.0914	.0686	.0924
5	.1294	.0914	.0686	.0924	.1097	.0686	.0924
6	.1294	.1097	.0686	.0924	.1097	.0686	.0924
7	.1478	.1097	.0686	.1109	.0914	.0857	.1109
8	.1663	.1463	.1029	.1109	.128	.1029	.1294
9	.2772	.2561	.1372	.1109	.2378	.2572	.2587
10	.3326	.3292	.2058	.1463	.3658	.3086	.3696
11	.4251	.3429	.2772	.1463	.3258	.3511	.4066
12	.439	.3429	.3511	.1463	.3772	.3511	.4251
13	.4755	.3429	.3511	.1829	.3258	.3511	.4435
14	.439	.3429	.3511	.1463	.3429	.3326	.3696
15	.4938	.3429	.3696	.128	.3601	.3326	.439
16	.4938	.3258	.3326	.1097	.3258	.3326	.439
17	.4572	.3086	.2957		.3429	.3511	.439
18	.3475	.3086	.2772	.128	.3258	.3511	.3658
19	.2926	.2915	.2587	.128	.2401	.2957	.3292
20	.2743	.1886	.2402	.1646	.1886	.2218	.2743
21	.1829	.1715	.1294	.1463	.1543	.1848	.2743
22	.2012	.1372	.1294		.1372	.1294	.1829
23	.1463	.1372	.1294	.128	.1029	.1294	.1463
24	.1478	.1097	.12	.1294	.1097	.1029	.1109
Max	.4938	.3429	.3696	.1829	.3772	.3511	.4435
Min	.1294	.0732	.0686	.0924	.0914	.0686	.0924
Avg	.2730	.2126	.1913	.1277	.2127	.2105	.2544

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284005 / 33/11KV Sec 30, Sanpada
S/Stn

Feeder No / Name : 209 / 11 KV MILLENIUM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0732	.0762	.0762	.0549	.0762	.0762
2	.0762	.0732	.0572	.0762	.0549	.0762	.0762
3	.0762	.0732	.0572	.0762	.0732	.0572	.0762
4	.0762	.0549	.0572	.0762	.0732	.0572	.0572
5	.0762	.0549	.0762	.0572	.0549	.0572	.0572
6	.0572	.0549	.0762	.0572	.0549	.0762	.0572
7	.0762	.0549	.0762	.0572		.0762	.0572
8	.0572	.0549	.0762	.0572	.0549	.0762	.0762
9	.0762	.0549	.0686	.0762	.0549	.0762	.0762
10	.0762	.0549	.0762	.0732	.0549	.0762	.0762
11	.0762	.0762	.0762	.0732	.0762	.0762	.0762
12	.0549	.0762	.0762	.0732	.0762	.0762	.0762
13	.0549	.0762	.0762	.0549	.0762	.0762	.0762
14		.0762	.0762	.0549	.0762	.0762	.0762
15		.0762	.0762	.0549	.0762	.0762	.0732
16	.0732	.0762	.0762	.0549	.0762	.0762	.0549
17	.0549	.0762	.0762	.0549	.0762	.0762	.0549
18	.0549	.0762	.0762	.0732	.0762	.0762	.0549
19	.0549	.0762	.0762	.0732	.0762	.0762	.0549
20	.0549	.0762	.0762	.0732	.0762	.0762	.0732
21	.0732	.0762	.0762	.0549	.0762	.0762	.0732
22	.0549	.0572	.0762	.0549	.0572	.0762	.0732
23	.0549	.0572	.0762	.0549	.0572	.0762	.0549
24	.0762	.0549	.0762	.0762	.0549	.0762	.0762
Max	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Min	.0549	.0549	.0572	.0549	.0549	.0572	.0549
Avg	.0665	.0671	.0735	.0652	.0669	.0738	.0681

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 201 / 11 KV VASHI RLY I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0762	.0762	.0754	.0762	.0747	.0762
2	.0762	.0762	.0762	.0754	.0381	.0754	.0762
3	.0762	.0762	.0762	.0762	.0762	.0754	.0762
4	.0762	.0762	.0762	.0754		.0762	.0762
5	.0762	.0762	.0762	.0762	.0762	.0754	.0762
6	.0762	.0762	.0762	.0754	.0762	.0754	.0762
7	.0762						.0762
19	.0762		.0754		.0754		
20	.0762	.0762	.0754		.0754	.0762	
21	.0762	.0762	.0754		.0754		.0762
22	.0762	.0762	.0754		.0754	.0762	.0762
23	.0762	.0762	.0754		.0754	.0762	.0762
24		.0762	.0762	.0754	.0762	.0754	.0762
Max	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Min	.0762	.0762	.0754	.0754	.0381	.0747	.0762
Avg	.0762	.0762	.0759	.0756	.0724	.0757	.0762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 202 / 11 KV SHAH GROUP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1905	.2096	.1524	.1715	.132	.1334
2	.1524	.1715	.1905	.1698	.1524	.1334	.1524
3	.1715	.1715	.1715	.1524	.1715	.1509	.1715
4	.2477		.1715	.1715	.1524	.1698	.1905
5	.2667	.1715	.1715	.1509	.1715	.1905	.2096
6	.3048	.2477	.1905	.1698	.1905	.2075	.2096
7	.2667	.2858	.2667	.1698	.2858	.2075	.2477
8	.2858	.2477	.2286	.168	.2477	.2075	.2858
9	.2858	.2858	.2667	.2427	.2667	.2241	.381
10	.2286	.2477	.2477	.2477	.2096	.2096	.2286
11	.2286	.1715	.2477	.2286	.1698	.2286	.1715
12	.2286	.2096	.2286	.1905	.2075	.2477	.1905
13	.2286	.1905	.2286	.2096	.1509	.2096	.1905
14	.1715	.1715	.2096	.1905	.1509	.1524	.1905
15	.1715	.1715	.1905	.1524	.132	.1334	.1905
16	.1715	.1524	.1715	.1905	.132	.1334	.1715
17	.1905	.1524	.2096	.1905	.1509	.1715	.1905
18	.2286	.1905	.2075	.2096	.1478	.1905	.2096
19	.2286	.1905	.2075	.2096	.168	.2286	.2286
20	.2286	.1905	.2075	.1905	.2263	.1905	.2477
21	.2477	.1905	.2075	.1905	.1698	.1905	.2477
22	.2477	.2477	.1698	.1905	.1886	.1905	.2477
23	.2286	.1905	.1698	.1905	.1698	.1715	.2286
24	.1905	.1905	.1905	.1698	.1905	.1509	.1524
Max	.3048	.2858	.2667	.2477	.2858	.2477	.381
Min	.1524	.1524	.1698	.1509	.132	.132	.1334
Avg	.2239	.2013	.2067	.1874	.1823	.1843	.2112

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway
S/Stn

Feeder No / Name : 203 / 11 KV ASSAM BHAVAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0953	.0754	.0762	.0754	.0762
2	.0762	.0762	.0953	.0762	.0762	.0762	.0762
3	.0762	.0762	.0762	.0754	.0762	.0754	.0762
4	.0762	.0762	.0762	.0762	.0762	.0754	.0762
5	.0762	.0953	.0762	.0754	.0762	.0754	.0762
6	.0762	.0953		.0762	.0762	.0754	.0762
7	.0762	.0953	.0762	.0754	.0762	.0754	.0762
8	.0762	.0762	.0762	.0739	.0762	.0754	.0762
9	.0762	.0953	.0762	.0754	.0762	.0754	.0762
10	.0762	.1524	.1715	.1334	.0953	.0953	.0762
11	.0953	.1715	.1715	.0953	.1509	.0953	.1524
12	.1524	.1334	.1524	.0953	.1494	.1715	.1715
13	.1524	.1334	.1524	.0953	.1509	.1334	.1524
14	.1524	.1334	.1524	.0953	.1509	.1334	.1524
15	.1524	.1143	.1524	.0953	.132	.1524	.1524
16	.1524	.8954	.1334	.0953	.132	.1334	.1524
17	.1334	.1143	.0953	.0953	.1307	.1143	.1524
18	.0953	.0953	.0943	.0953	.0724	.0762	.0762
19	.0953	.0762	.0754	.0762	.0754	.0762	.0762
20	.0953	.0953	.0754	.0762	.0754		.0953
21	.0953	.0953	.0754	.6478	.0754	.0762	.0953
22	.0953	.0953	.0943	.0762	.0754	.0953	.0953
23	.0762	.0953	.0754	.0762	.0754	.0762	.0762
24	.0953	.0762	.0953	.0754	.0762	.0754	.1524
Max	.1524	.8954	.1715	.6478	.1509	.1715	.1715
Min	.0762	.0762	.0754	.0739	.0724	.0754	.0762
Avg	.1000	.1350	.1050	.1085	.0960	.0950	.1048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway
S/Stn

Feeder No / Name : 204 / 11 KV REAL TRADE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4191	.4572	.4001	.4001	.3772	.4572
2	.4191	.381	.4191	.381	.381	.381	.381
3	.381	.3429	.381	.3395	.381	.362	.381
4	.381	.3429	.381	.362	.362	.3584	.362
5	.381	.362	.381	.3395	.3429	.3772	.381
6	.4191	.381	.4001	.3206	.362	.3772	.4191
7	.4382	.4001	.4191	.3206	.381	.415	.4382
8	.4763	.4191	.4191	.3696	.4382	.3772	.4572
9	.5716	.5335	.4763	.4435	.5906	.5914	.7049
10	.7811	.7621	.6097	.5525	.7811	.724	.8192
11	.8764	.9526	.6097	.6859	.8299	.8192	.8573
12	.9145		.8573	.6859	.8596	.7621	.8573
13	.9335	.8764	.8573	.6859	.8299	.7621	.8573
14	.9526	.7621	.8192	.6859	.7545	.8002	.8764
15	.9526	.8764	.7811	.724	.8299	.8383	.9335
16	.9145		.8383	.724	.7811	.8764	1.0098
17	.9526		.8573	.724	.9054	.9145	.9717
18	.9526	.8954	.7733	.6287	.8413	.8764	.9145
19	.9145	.8954	.8215	.724	.7733	.8764	.8573
20	.8192	.8192	.679	.6859	.679	.6859	.7621
21	.8573	.7621	.6602		.679	.6668	.6097
22	.7621	.6859	.5847	.4954	.6036	.4954	.5716
23	.4763	.5716	.6036	.4572	.4904	.4572	.4572
24	.4382	.4572	.4763	.4527	.4382	.4527	.4191
Max	.9526	.9526	.8573	.724	.9054	.9145	1.0098
Min	.381	.3429	.381	.3206	.3429	.3584	.362
Avg	.6843	.6142	.6068	.5299	.6131	.6093	.6565

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway
S/StnFeeder No / Name : 206 / 11 KV CIDCO WATER PUMP
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.3239	.362	.2096	.2286	.2534	.2858
2	.2667	.3048	.3429	.1905	.1905	.2477	.2477
3	.2477	.3048	.3239	.1886	.1905	.2263	.2667
4	.2858	.3048	.3048	.2096	.2096	.2641	.2286
5	.3429	.3239	.3239	.3048	.3429	.3429	.2667
6	.362	.3429	.3429		.4191	.3772	.362
7	.362	.381	.3429	.3395	.381	.3772	.381
8	.3429	.381	.3429	.3395	.381	.3584	.4001
9	.3429	.4191	.381	.415		.3206	
10	.5335	.5716	.4763	.381	.6097	.4954	.6478
11	.6668	.6859	.5716	.4191	.6668	.6097	.6859
12	.8002	.6859	.6668	.4382	.7167	.6668	.7621
13	.8002	.724	.6859	.4382	.7356	.6097	.8192
14	.7811	.743	.7049	.4572	.6413	.6668	.8383
15	.8192	.7621		.4763	.6878	.6668	.8383
16	.8573	.7621	.7049	.4763	.6979	.7049	.8573
17	.8002	.724	.6097	.4191	.679	.6859	.8002
18	.6859	.6097	.6979	.381	.679	.5906	.6859
19	.6478	.5716	.4435	.381	.6413	.5144	.6097
20	.4572	.4572	.5093	.381	.4715	.4191	.5716
21	.4382	.4382	.3772	.4191	.415	.4001	.4954
22	.4382	.4191	.3961		.415	.3429	.4954
23	.4382	.4001	.415	.4191	.3961	.3239	.4954
24	.3429	.3239	.381	.3206	.3429	.3206	.3048
Max	.8573	.7621	.7049	.4763	.7356	.7049	.8573
Min	.2477	.3048	.3048	.1886	.1905	.2263	.2286
Avg	.5136	.4985	.4655	.3638	.4843	.4494	.5368

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 208 / 11 KV LIFE STYLE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0762	.0754	.0762	.0754	.0762
2	.0762	.0762	.0762	.0762	.0762	.0762	.0762
3	.0762	.0762	.0762	.0762	.0762	.0762	.0762
4	.0762	.0762	.0762	.0754		.0754	.0762
5	.0762	.0762	.0762	.0754	.0762	.0754	.0762
6	.0762	.0762	.0762	.0754	.0762	.0754	.0762
7	.0762	.0762	.0762	.0754	.0762	.0754	.0762
8	.0762	.0762	.0762	.0754	.0762	.0754	
9	.0762	.0762	.0953	.0754		.0754	
10	.362	.3048	.2858	.2667	.1905	.0762	.3048
11	.7621	.7049	.4763	.743	.7356	.7049	.4572
12	.8573	.724	.6859	.724	.7167	.724	.724
13	.8573	.6859	.6859		.7167	.724	.743
14	.8573	.6668	.6859	.7049	.7167	.724	.743
15	.8192	.6668	.7049	.743	.6722	.743	.724
16	.7049	.6859	.7049	.724	.6036	.724	.7049
17	.7049	.6668	.7049	.743	.6413	.743	.7049
18	.7049	.724	.7356	.743	.679	.724	.7049
19	.7621	.7621	.8131	.8002	.7733	.8573	.6668
20	.7811	.7811	.7733	.8383	.7733	.8383	.6478
21	.7811	.7621	.7733	.8002	.6036	.8002	.6287
22	.1524	.2286	.1509	.0953	.1509	.1143	.5716
23	.0762	.0762	.0754	.0762	.0754	.1143	.0762
24	.0762	.0762	.0762	.0754	.0762	.0943	.0953
Max	.8573	.7811	.8131	.8383	.7733	.8573	.743
Min	.0762	.0762	.0754	.0754	.0754	.0754	.0762
Avg	.4144	.3834	.3766	.3808	.3936	.3911	.4105

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway
S/Stn

Feeder No / Name : 402 / 33 KV BSEL

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS) (NO
STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2286	.2286	.2263	.2286	.2263	.2286
2	.2286	.2286	.2286	.2286	.2286	.2263	.2286
3	.2286	.2286	.2286	.2263	.2286	.2286	.2286
4	.2286	.2286	.2286	.2263		.2286	.2286
5	.2286	.2286	.2286	.2263	.2286	.2263	.2286
6	.2286	.2286	.2286		.2286	.2263	.2286
7	.2286	.2286	.2286	.2263	.2286	.2263	.2286
8	.4572	.2286	.2286	.2263	.2286	.2263	.2286
9	.4572	.4572	.2286	.2263	.2286	.2263	.2286
10	.6859	.6859	.2286	.4572	.4572	.2286	.4572
11	.6859	.6859	.4572	.2286	.679	.2286	.6859
12	.6859	.6859	.4572	.2286	.679	.2286	.6859
13	.6859	.6859	.4572	.2286	.4527	.2286	.6859
14	.6859		.4572	.2286	.4527	.2286	.6859
15	.6859	.6859	.4572	.2286	.679	.6859	.6859
16	.6859	.6859	.4572	.2286	.679	.6859	.6859
17	.6859	.6859	.4572	.2286	.679	.6859	.6859
18	.6859	.6859	.2263	.2286	.679		.6859
19	.4572	.2286	.2263	.2286	.4527	.2286	.6859
20	.2286	.2286	.2263	.2286	.2263	.2286	.4572
21	.2286	.2286	.2263	.2286	.2263	.2286	.2286
22	.2286	.2286	.2263	.2286	.2263		.2286
23	.2286	.2286	.2263	.2286	.2263	.2286	.2286
24	.2286	.2286	.2286	.2263	.2286	.2263	.2286
Max	.6859	.6859	.4572	.4572	.679	.6859	.6859
Min	.2286	.2286	.2263	.2263	.2263	.2263	.2286
Avg	.4287	.3976	.2947	.2377	.3849	.2901	.4191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 403 / 33 KV VISHWAROOP

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS) (NO
STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.3717	1.2574	1.0185	.9145	1.2449	1.2574
2	1.3717	1.3717	1.2574	1.0288	1.0288	1.1431	1.1431
3	1.2574	1.2574	1.1431	.9145	1.0288	1.0185	1.0288
4	1.2574	1.1431	1.0288	.9054	1.0288	.9145	.9145
5	1.1431	1.1431	1.0288	1.0288	.9717	.9054	1.0288
6	1.2574	1.0288	1.1431	1.0288	1.0288	1.0185	1.0288
7	1.1431	1.0288	1.1431	1.0185	1.1431	1.0185	1.3717
8	1.6004	1.2574	1.1431	1.0185	1.1431	1.1317	1.4861
9	1.6004	1.6004	1.1431	.9054	1.6004	1.5844	1.7147
10	1.829	1.7147	1.1431	.9145	1.829	1.7147	1.829
11	1.829	1.7147	1.2574	1.0288	1.8107	1.829	1.9433
12	1.829	1.7147	1.2574	1.2574	1.8107	1.829	1.9433
13	1.829	1.829	1.2574	1.0288	1.6975	1.7147	1.9433
14	1.829	1.829	1.2574	.3429	1.6975	1.7147	1.829
15	1.829	1.829	1.2574	1.3717	1.8107	1.9433	1.829
16	1.829	1.829	1.3717	.9145	1.8107	2.0576	1.9433
17	1.829		1.3717	.9145	1.8107	1.9433	1.9433
18	1.829	1.7147	1.358	1.0288	1.9239	1.9433	1.829
19	1.7147	1.7147	1.358	.9145	1.9239	1.7147	1.829
20	1.6004	1.4861	1.2449	1.3717	1.5844	1.6004	1.7147
21	1.6004	1.4861	1.1317	1.0288	1.4712	1.6004	1.7147
22	1.6004	1.3717	1.1317	1.0288	1.4712	1.2574	1.7147
23	1.4861	1.3717	1.1317		1.358	1.2574	1.4861
24	1.2574	1.4861	1.3717	1.1317	.9145	1.4712	1.4861
Max	1.829	1.829	1.3717	1.3717	1.9239	2.0576	1.9433
Min	1.1431	1.0288	1.0288	.3429	.9145	.9054	.9145
Avg	1.5718	1.4910	1.2162	1.0063	1.4505	1.4821	1.5813

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway
S/StnFeeder No / Name : 404 / 33 KV SEC 30 SANPADA FRM NON SHEDDABLE EXPRESS HV FEEDERS
VASHI Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2197	1.0425	1.0288	1.1088	1.0974	.823	.9979
2	1.2197	1.0974	.9774	1.0534	.9877	.823	.9425
3	1.1643	1.0425	.9259	.9979	.9328	.823	.9425
4	1.1643	.9328	.7716	.9979	.8779	.7716	.9425
5	1.1643	1.0425	.7716	.9425	.8779	.7202	.8871
6	1.0534	1.0974	.7202	.8871	.8779	.7716	.9425
7	1.1643	1.2071	.823	.8871	1.1523	.8745	.9979
8	1.2197	1.0974	.8745	.9425	.9877	.9259	1.1643
9	1.4415	1.4266	.9774	1.1088	1.3169	1.2346	1.4415
10	1.6632	1.4815	1.286	1.2752	1.5364	1.3375	1.5524
11	1.6632	1.4403	1.5524	1.262	1.4918	1.4969	1.6078
12	1.5912	1.3889	1.6632	1.2071	1.4403	1.4969	1.6078
13	1.5912	1.4403	1.5524	1.262	1.286	1.4415	1.6078
14	1.4815	1.3375	1.5524		1.3375	1.386	1.5524
15	1.4815	1.286	1.5524	1.0425	1.286	1.3306	1.6461
16	1.5364	1.3375	1.4969	1.0425	1.286	1.3306	1.4815
17	1.5912	1.3375	1.386	.9328	1.3375	1.3306	1.5364
18	1.4266	1.3375	1.4415	1.1523	1.3375	1.4415	1.5364
19	1.4266	1.4918	1.386	1.2071	1.3375	1.4415	1.6461
20	1.5364	1.286	1.386	2.4691	1.2346	1.3306	1.5364
21	1.4266	1.2346	1.2752	1.3169	1.1831	1.2752	1.4815
22	1.3169	1.1317	1.2752	1.2071	1.1831	1.2752	1.2071
23	1.3717	1.0802	1.2197	1.2071	1.0802	1.1643	1.2071
24	1.2752	1.0425	1.0802	1.1643		.8745	1.0534
Max	1.6632	1.4918	1.6632	2.4691	1.5364	1.4969	1.6461
Min	1.0534	.9328	.7202	.8871	.8779	.7202	.8871
Avg	1.3829	1.235	1.2073	1.1597	1.1942	1.1550	1.3133

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 201 / 11 KV NMMC WATER PUMP SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8962	.8501	.7356	.8402	.811	.8192	.7922
2	.8413	.7762	.679	.7282	.8488	.8383	.7545
3	.7682	.7207	.6413	.6908	.8865	.8573	.7167
4	.8596	.7947	.6979	.7842	.9431	.8954	.7733
5	.9145	.9055	.7356	.8589	.9808	.9145	.8488
6	.9877	1.0349	.7922	.9335	1.0374	.9335	.9808
7	1.0425	1.1827	.8676	.9896	.9808	.9717	1.094
8	1.0608	1.0903	.9431	1.0642	.9619	1.0479	1.0185
9	1.0242	1.2012	1.1694	1.1016	1.0374	1.105	1.0562
10	1.0059	1.1273	1.1317	1.0829	.9431	1.0288	1.094
11	1.0425	.9425	1.0374	1.0642	.9054	.8954	.9054
12	.9511	.924	.9242	1.0829	.7733	.8002	.7922
13	.823	.9055	.7733	1.0829	.6979	.6859	.7733
14	.7316	.8501	.7733	.9335	.679	.6287	.7356
15	.695	.7762	.7545	.6722	.5847	.5716	.7167
16	.6584	.7023	.679	.6722	.6224	.5335	.679
17		.8131					
18		1.0903					
19		1.3121				1.2003	
20		1.2752				1.2574	
21		1.2936	1.2826			1.0098	1.3392
22		1.0349				1.0479	1.1506
23		.9795			.9054		1.0562
24	.961	.9145	.7392	.9431	.8962	.7865	.8764
Max	1.0608	1.3121	1.2826	1.1016	1.0374	1.2574	1.3392
Min	.6584	.7023	.6413	.6722	.5847	.5335	.679
Avg	.8979	.9791	.8532	.9132	.8608	.8966	.9077

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 202 / 11 KV TEJASWINI HOSTEL SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9425	1.0642	.8779	.9055	.823	.8962	.7865
2	.8871	.9709	.823	.8871	.7865	.8871	.7316
3	.8131	.8962	.7682	.8316	.7682	.8316	.6767
4	.8686	.8775	.7133	.7762	.7865	.8131	.7499
5	.924	.9335	.7682	.8131	.8048	.8501	.8048
6	.9795	.9709	.8413	.8316		.8686	.8413
7	.961	1.0082	.8962	.8871	.8596	.8316	.8779
8	1.0349	1.0082	.9145	.961	.8962	.9055	.8779
9	1.1088	1.0642	.9694	1.0164	1.0425	.9425	.9694
10	1.2012	1.1949	1.0791	1.0534	1.0974	1.0903	1.1157
11	1.3121	1.251	1.134	1.0903	1.1157	1.2197	1.1888
12	1.2936	1.1949	1.1157	1.0719	1.1523	1.1827	1.2437
13	1.2752	1.1016	1.0425	1.0719	1.1706	1.1273	1.1888
14	1.2567	1.0642	1.1157	.9979	1.1706	1.1273	1.2254
15	1.2382	1.0269	1.1523	.961	1.1523	1.1458	1.2071
16	1.2752	1.1763	1.1888	.9979	1.1706	1.1643	1.2071
17		1.2323					
18		1.2696					
19						1.386	
20		1.2696				1.2567	
21		1.1949	1.2136			1.1458	1.2803
22		1.1203				1.1458	1.1888
23		1.0456			.9694		1.0974
24	1.0269	1.0903	.9522	.9522	.924	.8962	.9055
Max	1.3121	1.2696	1.2136	1.0903	1.1706	1.386	1.2803
Min	.8131	.8775	.7133	.7762	.7682	.8131	.6767
Avg	1.0823	1.0881	.9759	.9474	.9818	1.0340	1.0082

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 203 / 11 KV SANPADA INDL SEC 6 SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1509	.1524	.1715	.1494	.1867	.1646
2	.1524	.132	.1524	.1524	.1494	.1463	.1478
3	.1524	.132	.1334	.1524	.168	.1307	.1478
4	.1524	.132	.1334	.1524	.168	.1463	.1478
5	.1524	.132	.1334	.1524	.168	.128	.1478
6	.1524	.1509	.1334	.1524	.168	.1646	.1478
7	.1715	.1509	.1524	.1524	.168	.1463	.1663
8	.1524	.132	.1524	.1715	.1494	.1463	.1478
9	.1715	.1509	.1524	.1715	.1494	.1463	.1848
10	.1905	.1698	.1905	.1715	.1494		.2033
11	.1905	.1886	.2096	.1715	.1867	.1463	.2033
12		.2075	.1905	.1715	.1867	.1646	.2218
13	.1905	.2263	.1905	.1524	.168	.1829	.2218
14	.2096	.2452	.1715	.1524	.168	.1829	.2033
15	.2286	.2641	.1905	.1524	.1867	.1829	.1848
16	.2477	.2263	.1905	.1715	.1867	.2012	.2402
17		.2263			.1494		
18		.1886					
19		.2075				.1646	
20		.2075				.1646	
21		.1886	.2096			.1646	.2033
22		.1509				.1646	.1848
23		.1698			.1867		.1478
24	.168	.1524	.1509	.1715	.1715	.1867	.1646
Max	.2477	.2641	.2096	.1715	.1867	.2012	.2402
Min	.1524	.132	.1334	.1524	.1494	.128	.1478
Avg	.1784	.1785	.1661	.1614	.1672	.1624	.1791

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 204 / 11 KV SEC 6 SUBSTATION SHEDDABLE URBAN
TRANSFO Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.567	.4481	.5121	.462	.5281	.4001	.3772
2	.5121	.3734	.4755	.499	.5093	.381	.3584
3	.439	.3174	.4024	.4251	.4904	.362	.3206
4	.4024	.3547	.3475	.3696	.4338	.3429	.3772
5	.4572	.4108	.3658	.3511	.415	.362	.415
6	.4755	.4668	.4024	.3326	.3961	.4001	.4715
7	.4755	.5228	.4207	.3696	.4527	.4382	.4904
8	.5121	.4668	.439	.4251	.4904	.4954	.4904
9	.4938	.4481	.439	.4805	.5093	.5525	.4715
10	.4755	.4668	.4755	.5544	.4715	.5335	.4527
11	.4572	.5041	.5304	.5729	.4338	.5525	.4338
12	.4207	.4854	.439	.5175	.415	.4763	.3772
13	.3841	.4481	.4024	.5175	.3772	.4382	.3772
14	.3658	.4108	.439	.3881	.3584	.4191	.3395
15	.3292	.3734	.3658	.3696	.3395	.381	.3206
16	.3475	.4294	.3475	.3696	.3395	.362	.3395
17		.4481					
18		.4481					
19		.5041				.5335	
20		.5415				.5525	
21		.5228	.4755			.5335	.4527
22		.4668				.5144	.547
23		.5975			.4527		.6413
24	.6535	.4755	.5788	.4755	.5729	.4338	.4191
Max	.6535	.5975	.5788	.5729	.5729	.5525	.6413
Min	.3292	.3174	.3475	.3326	.3395	.3429	.3206
Avg	.4569	.4555	.4366	.4400	.4436	.4507	.4236

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 205 / 11 KV SAIKRIPA SEC 10

SHEDDABLE URBAN

SANPADA Feeder KV- 11 /
OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3584	.3326	.2829	.2858	.3048	.2801	.2667
2	.3206	.2957	.2829	.2667	.2858	.2614	.2477
3	.2829	.2587	.2263	.2477	.2667	.2241	.2286
4	.3206	.2772	.2263	.2477	.2667	.2427	.2286
5	.3584	.3326	.2829	.2667	.2858	.2987	.2858
6	.3772	.3696	.3395	.2667	.2858	.2801	.3429
7	.415	.4251	.3772	.3239	.4001	.2427	.4001
8	.4715	.4251	.415	.362	.4001	.3734	.4191
9	.4527	.462	.4527	.381	.4763	.4294	.4001
10	.4338	.4435	.3961	.381	.4191	.3921	.4382
11	.3961	.4066	.3395	.362	.381	.3547	.4001
12	.3772	.3881	.3018	.3048	.3429	.2614	.3429
13	.3395	.3511	.3206	.3048	.3429	.2427	.3239
14	.3206	.3142	.2641	.2667	.2858	.2054	.3048
15	.2829	.2587	.2452	.2477	.2477	.1867	.3048
16	.2641	.2402	.2263	.2286	.2667	.2241	.2858
17		.2402					
18		.2402					
19		.3881				.3174	
20		.3511				.3547	
21		.3511	.3772			.3734	.381
22		.3326				.3174	.381
23		.3326			.3048		.362
24	.4001	.3584	.3142	.3206	.3239	.3239	.2987
Max	.4715	.462	.4527	.381	.4763	.4294	.4382
Min	.2641	.2402	.2263	.2286	.2477	.1867	.2286
Avg	.3630	.3406	.3150	.2979	.3271	.2946	.3321

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 206 / 11 KV SAMTA SEC 4/7

SHEDDABLE URBAN

SANPADA Feeder KV- 11 /
OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8596	.9335	.7762	.7655	.811	.7733	.7468
2	.823	.8775	.7392	.7282	.7545	.7682	.6722
3	.7682	.8402	.7023	.6722	.7167	.7133	.6348
4	.8779	.9149	.7207	.7282	.7922	.6767	.7282
5	.9877	1.0082	.8131	.7842	.8488	.6584	.8215
6	1.1523	1.1016	.924	.7655	.8865	.8596	.9522
7	1.2437	1.1763	1.0534	.8775	1.0562	.9328	1.1203
8	1.2254	1.2323	1.1643	.9896	1.2449	1.0425	1.1576
9	1.2071	1.1949	1.1273	1.0829	1.3014	1.1888	1.1763
10	1.1706	1.1576	1.0719	1.1389	1.094	1.1157	1.1949
11	1.0974	1.1203	1.0349	1.0829	1.0185	.9877	1.1016
12		1.0829	1.0164	1.0456	.9431	.9328	1.0269
13	1.0059	.9149	.9795	.9335	.9242	.8779	1.0082
14	.9694	.8962	.9425	.8775	.8676	.8596	1.0269
15	.9145	.9149	.9055	.8589	.8865	.823	.9896
16	.8779	.8775	.8871	.8215	.9619	.7499	.9709
17		.9709					
18		1.0456					
19		1.2136				1.1523	
20		1.251				1.1888	
21		1.1763	1.1643			1.0974	1.3256
22		1.0642				.9328	1.1389
23		.9149			.9054		1.0829
24	.924	.9877	.8589	.8131	.8775	.7733	.7865
Max	1.2437	1.251	1.1643	1.1389	1.3014	1.1888	1.3256
Min	.7682	.8402	.7023	.6722	.7167	.6584	.6348
Avg	1.0065	1.0362	.9379	.8803	.9384	.9098	.9831

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 208 / 11 KV LAXMI SEC10 SANPADA SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5497	1.4415	1.307	1.2567	1.262	1.3014	1.2936
2	1.475	1.386	1.2323	1.2197	1.1888	1.5278	1.2197
3	1.419	1.3121	1.1763	1.1458	1.1523	1.5655	1.1273
4	1.531	1.3676	1.2696	1.2012	1.2437	1.5844	
5	1.6617	1.46	1.363	1.2567	1.3535	1.6221	
6	1.7364	1.6078	1.475	1.2936	1.4266	1.4712	1.46
7	1.8111	1.7556	1.6057	1.3676	1.6827	1.5466	1.6078
8	1.9605	1.9035	1.7364	1.46	1.7193		1.7187
9	1.8671	1.6817	1.7737	1.4969	1.5912	1.7918	1.6448
10	1.7737	1.5708	1.531	1.5339	1.39	1.7164	1.423
11	1.3443	1.3491	1.307	1.3306	1.2437	1.3392	1.2936
12		1.2382	1.1576	1.1827	1.1157	1.3014	1.1273
13	1.1576	1.0534	1.1016	1.2567	.9694	1.0751	1.1088
14	1.1389	.9979	1.0269	1.1827	.9877	1.0562	1.0719
15	1.1203	1.0349	1.0456	1.1088	.9328	1.0374	1.0349
16	1.1389	.9979	1.0269	1.0349	.9328	1.0185	.9979
17		1.0349					
18		1.2012					
19		1.5154				1.6409	
20		1.5339				1.6221	
21		1.5524	1.6244			1.6032	1.7372
22		1.5708				1.6221	1.7187
23		1.4784			1.4449		1.5893
24	1.5893	1.531	1.3491	1.363	1.3491	1.2254	1.358
Max	1.9605	1.9035	1.7737	1.5339	1.7193	1.7918	1.7372
Min	1.1203	.9979	1.0269	1.0349	.9328	1.0185	.9979
Avg	1.5172	1.399	1.3394	1.2760	1.2770	1.4334	1.3629

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284055 / 33/11 KV Sec 14,Nerul s/stn

Feeder No / Name : 201 / 11 KV SUN HOME

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9242	.8488	.8402	.8299	.7762	.7545	.7733
2	.8775	.811	.7842	.7922	.7655	.7356	.7167
3	.8215	.7922	.7468	.7545	.7468	.6979	.6979
4	.8589	.7545	.7095	.7356	.7095	.6602	.679
5	.9709	.7356	.7468	.6979	.6722	.6413	.679
6	1.0349	.9242	.8589	.8488	.8589	.7922	.9808
7	1.1763	1.0751	1.0082	.9619	1.0829	.9619	1.0185
8	1.2136	1.3014	1.1016	1.0374	1.2136	1.226	1.2071
9	1.1827	1.1694	1.1694	1.1883	1.1763	1.3014	1.1694
10	1.0751	.9997	1.0374	1.1506	.9619	1.094	.9522
11	1.0185	.9149	.9431	1.0719	.9054	1.0374	.8962
12	.9054	.8215	.8865	.8871	.811	.8299	.8402
13	.7922	.7095	.7922	.8215	.679	.6979	.7095
14	.7167	.679	.7167	.7577	.679	.6908	.6722
15	.679	.6348	.6602	.7095	.679	.6602	.7095
16	.7356	.6908	.6602	.6722	.6602	.6161	.6722
17	.7545	.7095	.6979	.7655	.5658	.7167	.6908
18	.7545	.7655	.9054	.8316	.7545	.7468	.7922
19	1.0562		1.1128	.9896	.9619	1.0185	1.0751
20	1.1506	1.0829	1.1883	1.1203	1.1128	1.1506	1.1694
21	1.226	1.1576	1.1694	1.1763	1.1317	1.1317	1.2449
22	1.1883	1.0349	1.0562	1.0456	1.0562	1.094	1.1694
23	1.0751	.9335	.9997	.9896	.9242	.9808	1.0185
24	.9335	.8865	.8686	.8676	.8402	.7922	.8488
Max	1.226	1.3014	1.1883	1.1883	1.2136	1.3014	1.2449
Min	.679	.6348	.6602	.6722	.5658	.6161	.6722
Avg	.9634	.8884	.9025	.9043	.8635	.8762	.8910

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284055 / 33/11 KV Sec 14,Nerul s/stn

Feeder No / Name : 204 / Spare (11 KV Sec 30 Nerul link Feeder KV- 11 / OUTGOING SHEDDABLE URBAN

DATE	11-FEB-18	12-FEB-18	13-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
12	.0566		
16		.0566	
24			.0566
Max	.0566	.0566	.0566
Min	.0566	.0566	.0566
Avg	.0566	.0566	.0566

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284055 / 33/11 KV Sec 14,Nerul s/stn

Feeder No / Name : 205 / 11 KV SUBSTATION

SHEDDABLE URBAN

TRANSFORMER S Feeder KV- 11 /
OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.056	.0566	.0566	.0566	.0566
2	.056	.0566	.056	.0566	.0566	.0566	.0566
3	.0566	.0566	.0554	.0566	.0566	.0566	.0566
4	.0566	.0566	.0566	.0566	.0566	.0568	.0566
5	.0566	.0566	.0554	.0566	.0566	.0566	.0566
6	.0566	.0566	.056	.0566	.0566	.0566	.0566
7	.0566	.0566	.056	.0566	.0566	.0566	.0566
8	.056	.0566	.056	.0566	.0566	.0566	.0566
9	.056	.0566		.0566	.0566	.0566	.0754
10	.0566	.0566	.0566	.0566	.0566	.0566	.0566
11	.0566	.0566	.0566	.0566	.0566	.0566	.0566
12	.0566	.056	.0566	.056	.0566	.0566	.0377
13	.0566	.0566	.0566	.0566	.0566	.0566	.0566
14	.0566	.0566	.0566	.0566	.0514	.0377	.0566
15	.0566	.0566	.0566	.0566	.0566	.056	.0566
16	.0566	.0566	.0566	.0566	.0566	.0566	.056
17	.0566		.0566	.056	.0566	.0566	.0566
18	.0566	.056	.0566	.056	.0566	.0566	.0377
19	.0566		.0566	.056	.0566	.0566	.0377
20	.0566	.0566	.0566	.0566	.0566	.0566	.0566
21	.0566	.0566	.0568	.056	.0566	.0377	.0566
22	.0566	.0566	.0754		.0566	.0566	.0566
23	.0566	.056	.0566	.0566	.0566	.0566	.0566
24	.0566	.0566	.056	.0566	.0566	.0566	.0566
Max	.0566	.0566	.0754	.0566	.0566	.0568	.0754
Min	.056	.056	.0554	.056	.0514	.0377	.0377
Avg	.0565	.0565	.0572	.0565	.0564	.0550	.0550

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284055 / 33/11 KV Sec 14,Nerul s/stn

Feeder No / Name : 206 / 11 KV KUKSHET

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3817	1.3957	1.2696	1.3203	1.2696	1.1883	1.1706
2	1.3443	1.358	1.1827	1.2826	1.2136	1.1694	1.1506
3	1.2696	1.3203	1.1458	1.2449	1.1827	1.1317	1.094
4	1.1949	1.2826	1.1203	1.226	1.1576	1.094	1.1128
5	1.3817	1.2637	1.1643	1.1883	1.2883	1.0374	1.1128
6	1.6244	1.4901	1.3443	1.3769	1.4563	1.3014	1.5466
7	1.8665	1.8484	1.6617	1.7164	1.8484	1.6409	1.7353
8	2.1658	2.037	1.9044	1.8861	1.9605	1.9427	2.0559
9	1.7741	1.5844	1.6598	1.6787	1.6804	1.7541	1.5655
10	1.5089	1.358	1.3957	1.5278	1.3256	1.3769	1.3769
11	1.226	1.1088	1.226	1.3443	1.1506	1.226	1.1763
12	1.1694	1.0829	1.1128	1.2696	1.0751	1.1128	1.0829
13	1.1694	.9709	1.094	1.2136	1.0185	1.0751	1.094
14	1.0751	.9425	.9619	1.1506	.9431	.9054	1.0082
15	1.0374	.9709	.9242	.961	.8865	.9054	.5975
16	1.0374	.8962	.9054	1.0349	.9054	.8865	1.0269
17	1.094	.9619	1.0562	1.0456	.9997	1.0185	1.0829
18	1.1694	1.1016	1.3957	1.2696	1.094	1.1016	1.226
19	1.7541		1.7918	1.7551	1.6975	1.6221	1.7541
20	1.9239	1.7924	1.9239	1.8673	1.8484	2.037	2.0559
21	1.8484	1.643	1.773	1.7353	1.6598	1.7164	1.8673
22	1.7353	1.643	1.6787	1.5684	1.6409	1.6409	1.7918
23	1.6032	1.5154	1.5278	1.4563	1.4335	1.4523	1.6409
24	1.4712	1.4335	1.2936	1.358	1.2883	1.226	1.3392
Max	2.1658	2.037	1.9239	1.8861	1.9605	2.037	2.0559
Min	1.0374	.8962	.9054	.961	.8865	.8865	.5975
Avg	1.4511	1.3479	1.3547	1.3949	1.3343	1.3151	1.3610

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284055 / 33/11 KV Sec 14,Nerul s/stn

Feeder No / Name : 207 / 11 KV AGRI KOLI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.415	.3734	.3772	.3547	.3772	.3772
2	.3547	.3772	.3547	.3772	.3547	.3772	.3395
3	.3395	.3772	.3361	.3584	.3547	.3584	.3206
4	.3395	.3584	.3361	.3584	.3361	.3584	.3206
5	.415	.3584	.3547	.3395	.3921	.3395	.3206
6	.4715	.4715	.4108	.3961	.4854	.415	.4527
7	.4854	.5093	.5041	.4715	.5975	.4904	.5281
8	.5788	.6036	.4481	.547	.5228	.6036	.5847
9	.5975	.6036	.5847	.547	.5041	.6036	.5093
10	.4904	.5281	.547	.547	.4715	.5093	.5281
11	.4527	.4668	.4338	.5601	.415	.415	.4481
12	.4338	.3772	.4338	.3734	.415	.3961	.3734
13	.3772	.3772	.3961	.4904	.3584	.3961	.3547
14	.3584	.3547	.3206	.4251	.3395	.3361	.3174
15	.3206	.3547	.3395	.3734	.3018	.2801	.3174
16	.3395	.3547	.4715	.4805	.3206	.2641	.3361
17	.3584	.3921	.547	.499	.3772	.3206	.3921
18	.415	.4668	.5658	.5601	.3961	.3921	.3772
19	.5281		.6036	.5601	.4715	.5281	.5281
20	.5093	.5914	.547	.5788	.4904	.4904	.4904
21	.4904	.4854	.547	.5788	.4904	.5093	.5093
22	.5281		.5281	.5415	.4527	.5847	.4904
23	.5093	.4251	.4527	.4481	.415	.4715	.4527
24	.462	.4338	.4108	.415	.3881	.3961	.415
Max	.5975	.6036	.6036	.5788	.5975	.6036	.5847
Min	.3206	.3547	.3206	.3395	.3018	.2641	.3174
Avg	.4388	.4401	.4520	.4668	.4169	.4255	.4202

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284055 / 33/11 KV Sec 14,Nerul s/stn

Feeder No / Name : 401 / 33 KV SEC 30 NERUL S/STN SHEDDABLE URBAN
Feeder KV- 33 / INCOMING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.5658	.5847		.6379	.5658	2.1091
2	.6687	.5144	.5601	.5784	.5847	.5144	
3	.6173	.5144	.5041		.5601	.5658	
4	.7716	.5658	.6161	.5258	.6161	.6173	
5	.7716	.7716	.6722		.6379	.7716	
6	.823	.823	.691	.5784	.7442	.7716	
7	.823	.8745	.7973	.6836	.9568	.823	
8	.823	.9259	.8505		.8505	.823	
9	.9259	.8745	.9568	.7282	.9568	.9259	.8745
10	.8745	.8505		.6722		.9259	.9465
11	.9259	.8505		.6722	.8745	.8745	
12	.9259	.7973	.8939	.6161	.9259	.9259	.8939
13	.9259	.7973		.5601	.823	.8745	
14	.7716	.7973	.8413		.7202	.7716	.7888
15		.691		.5847	.7202		
16	.7202	.7442	.6836	.691	.7202	.7202	.6836
17		.7442		.7842	.7202	.7716	
18	.9259	.7973	.8939	.8488	.823	.7716	.8939
19	1.0288	.8505		.8962	.9774	.9774	
20	1.0802	.9568	1.0517	.9522	.9774		1.1043
21	1.0802	1.0099		.9568	.9774	.9774	
22	.9774	.9036	.8939	.8505			.9991
23	.7202	.9036		.7442	.7202	.6687	
24	.6687	.6687	.6722	.6836	.6379	.5658	.6173
Max	1.0802	1.0099	1.0517	.9568	.9774	.9774	2.1091
Min	.6173	.5144	.5041	.5258	.5601	.5144	.6173
Avg	.8394	.7830	.7602	.7162	.7801	.7716	.9911

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284056 / 33/11 KV Nerul , Sector- 30,

Feeder No / Name : 201 / 11 KV SEC 24, SEC 30 STN SHEDDABLE URBAN
NERU Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	1.0288	1.1576		1.1203	.9602	1.0974
2	1.046	1.0117	1.1203	1.0456	1.0829	.9602	
3	1.0288	1.0117	1.1576		1.1576	.9431	1.0974
4	1.0117	.9945	1.1949	1.0082	1.307	.9602	1.1317
5	1.0288	1.0631	1.2696		1.4563	1.2003	1.1488
6	1.1831	1.166	1.358	1.1576	1.6057	1.286	1.166
7	1.4918	1.3375	1.4937	1.3443	1.7177	1.3717	1.3375
8	1.5775	1.6118	1.6804		1.6804	1.406	1.4918
9	1.4232	1.4403	1.6057	1.5123	1.4937	1.4232	1.1145
10	1.1488	1.4937		1.4563		1.2689	1.1576
11	1.0117	1.4563		1.3817	.9774	1.2174	
12	.9774	1.3443	.9896	1.3443	.9602	.9431	1.0082
13	.9602			1.2696	.9431	.8573	
14	.8916	.9335	.9335	1.1203	.8059	.7716	.9335
15		.8962		1.0456	.7545		
16	.8573	.8402	.8589	.9149	.7373	.7373	.8029
17		.8962		.9522	.7716	.823	
18	.6859	.9335	1.0269	.9522	.823	.8916	.9709
19	1.2517	1.1576		1.1203	1.166	1.2689	
20	1.3032	1.307	1.4377	1.2883	1.2517	1.3032	1.419
21	1.406	1.3957		1.4377	1.2346	1.3203	
22	1.3717	1.3256	1.363	1.4563			1.419
23		1.2696		1.4377	1.1488	1.1831	
24	1.0288	1.0974	1.1949	1.1203	1.1576	.9774	1.0974
Max	1.5775	1.6118	1.6804	1.5123	1.7177	1.4232	1.4918
Min	.6859	.8402	.8589	.9149	.7373	.7373	.8029
Avg	1.1292	1.1744	1.2401	1.2183	1.1524	1.0943	1.1496

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284056 / 33/11 KV Nerul , Sector- 30,

Feeder No / Name : 202 / 11 KV METRO,SEC 30 STN SHEDDABLE URBAN
NERUL Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1029	.1307		.1494	.0857	.1029
2	.0686	.1029	.112		.1307	.1029	.1029
3	.12	.1029	.1307		.1509	.1029	.12
4	.1029	.12	.1494	.112	.132	.12	.0686
5	.1029	.1029	.1307		.1494	.1029	.0686
6	.12	.12	.1307	.1307	.1307	.12	.1029
7	.12	.12	.112		.1494	.1029	.0686
8	.12	.1029		.1307	.1132	.1029	.12
9	.12	.12	.168	.1307	.1307	.12	.12
10	.12	.1307		.1307		.12	.1307
11		.1307		.1307	.1029	.12	
12	.12	.1307	.112	.1307	.12	.12	.112
13	.12	.1307		.1494	.12	.12	
14	.1029	.1307	.0934	.1494	.12	.12	.112
15		.1494		.168	.1029		
16	.1029	.132	.112		.1029	.12	.0934
17		.132		.1307	.12	.12	
18	.1029	.1307	.112	.0934		.12	.112
19	.12	.1307		.112	.1029	.12	
20	.12	.1494	.1307	.1494	.12	.12	.1307
21	.12	.1307		.1307	.12	.12	
22	.12	.1307	.1307	.1494			.1307
23	.12	.112		.1307	.1372	.12	
24	.12	.12	.112	.1307	.1307	.1029	.12
Max	.12	.1494	.168	.168	.1509	.12	.1307
Min	.0686	.1029	.0934	.0934	.1029	.0857	.0686
Avg	.1135	.1236	.1245	.1328	.1255	.1138	.1068

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284056 / 33/11 KV Nerul , Sector- 30,

Feeder No / Name : 204 / 11 KV NERUL GYMKHANA SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0686			.0934	.0686	.0686
2		.0686		.0747	.0754	.0686	.0514
3		.0686				.0857	.0686
4	.0686	.0686			.0747	.0857	.0686
5		.0514		.056	.0747		.0686
6		.0514			.0934	.0686	.0857
7	.0686	.0686		.0934	.056		.0686
8	.0686	.0686			.0747	.0686	.0686
9	.0686	.0857	.1307	.0934	.0747	.0686	.0686
10	.0686	.0747		.0934		.0686	.0934
11	.0686	.0747		.0747	.0686	.0686	
12	.0686	.0934	.0934	.0747	.0686	.0686	.0747
13	.0686	.0747		.0747	.0686	.0686	
14	.0457	.0747	.0934	.0934	.0686	.0686	.056
15		.0747		.0934	.0686		
16	.0686	.0747	.056	.0754	.0686	.0686	.056
17		.0747		.0934	.0686	.0686	
18	.0686	.0747	.0934	.0934	.0686	.0686	.056
19	.0686	.0934		.0747	.0857	.0686	
20	.0686	.0747	.112		.1029	.0686	.0934
21	.0686	.0934		.112	.0686	.0686	
22	.0686	.0747	.0747				.0747
23	.0686	.0747		.0934	.0686	.0686	
24	.0686		.0747	.0747	.0747	.0686	.0686
Max	.0686	.0934	.1307	.112	.1029	.0857	.0934
Min	.0457	.0514	.056	.056	.056	.0686	.0514
Avg	.0673	.074	.0910	.0846	.0746	.0703	.0700

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284056 / 33/11 KV Nerul , Sector- 30,

Feeder No / Name : 205 / 11 KV SEC 14 S/S NERUL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	12-FEB-18
HR	Load (MW)	Load (MW)
9	.0171	
19	.0171	
21		.0171
Max	.0171	.0171
Min	.0171	.0171
Avg	.0171	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284056 / 33/11 KV Nerul , Sector- 30,

Feeder No / Name : 206 / 11 KV SEC-50 NRI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18
HR	Load (MW)
9	.0171
Max	.0171
Min	.0171
Avg	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284056 / 33/11 KV Nerul , Sector- 30,

Feeder No / Name : 208 / 11 KV HAWARE Sec 28 Nerul SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2401	.2241		.2427	.2229	.2401
2	.2229	.2401	.2054	.2012	.2241	.2401	.2572
3	.2401	.2572	.2054		.2054	.2401	.2401
4	.2572	.2743	.2241	.1829	.2427		.2743
5	.2743	.2915	.2427		.3018	.2572	.2743
6		.3258	.2801	.2561	.3361	.2915	.3086
7	.3086	.3429	.3174	.2926	.3961	.3258	.3429
8	.3258	.3944	.3361		.3547	.3772	.3944
9	.3944	.3601	.3921	.3475	.3734	.3601	.3429
10	.2572	.3734		.3361		.3772	.3292
11	.2572	.3174		.3174	.2572	.3258	
12	.2401	.2801	.3109	.2987	.2572	.2915	.2743
13	.2229	.2427		.2987	.2401	.2401	
14	.3086	.2054	.2561	.2614	.2401	.2401	
15		.2054		.2427	.1886		
16	.2915	.2054	.2195	.2263	.2058	.2401	.1829
17		.1867		.2241	.2401	.1715	
18	.2743	.1867	.2012	.2054	.2743	.1886	.2012
19	.2915	.2614		.2427	.2743	.2572	
20	.2915	.2987	.2926	.2801	.2743	.2915	.3292
21	.2915	.3361		.3174	.2915	.3086	
22	.2572	.3174	.3109	.3361			.3109
23	.2058	.2987		.2987	.2572	.2401	
24	.2572	.2572	.2427	.2378	.2614	.2229	.2572
Max	.3944	.3944	.3921	.3475	.3961	.3772	.3944
Min	.2058	.1867	.2012	.1829	.1886	.1715	.1829
Avg	.2719	.2791	.2663	.2702	.2700	.2719	.2850

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284056 / 33/11 KV Nerul , Sector- 30,

Feeder No / Name : 401 / 33 KV SEC 11 NERUL S/STN SHEDDABLE URBAN
Feeder KV- 33 / INCOMING

DATE	10-FEB-18	11-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
8		.0736	
10			.0736
12	.0684		
14			.0736
20	.0736		
21			2.2085
22			2.0508
Max	.0736	.0736	2.2085
Min	.0684	.0736	.0736
Avg	.071	.0736	1.1016

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela
s/sFeeder No / Name : 201 / 11 KV RAGHULEELA NEW SHEDDABLE URBAN
FEEDER Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.3772	.8299	.3772	.2829	.3961	.2829
2	.2614	.3395	.7167	.3206	.2452	.3395	.2641
3	.2427	.3018	.5658	.3018	.2263	.3018	.2263
4	.2241	.2263	.4904	.2263	.2263	.2641	.2075
5	.2241	.2263	.415	.2075	.2263	.2263	.2075
6	.2241	.2263	.3395	.2075	.2263	.2075	.2075
7	.2241	.2263	.2641	.2075	.2075	.2075	.1886
8	.2427	.2641	.2452		.2452	.2641	.2427
9	.3547	.415	.3395	.7282	.3206	.3206	.3547
10	.6602	1.1317	.7655	.7545	1.1576	1.1763	.3961
11	1.6032	1.5844	1.363	1.358	1.419	1.531	1.3392
12	1.7353	1.5844	1.475	1.8296	1.6057	1.6804	1.5655
13	1.7541	1.6032	1.4937	1.8107		1.6804	1.7541
14	1.6975	1.587	1.531	1.8484	1.6804	1.6244	1.7353
15	1.6975	1.6057	1.5684	1.9239	1.6991	1.6057	1.7353
16	1.6975	1.6244	1.6057	1.8861	1.6991	1.6057	1.7541
17	1.7164	1.643	1.7551	1.7353	1.6991	1.6244	1.8861
18	1.6032	1.7353	1.7924	1.7918	1.6991	1.6244	1.8296
19	1.5844	1.7918	1.8671	1.7918	1.6221	1.531	1.9427
20	1.6032	1.6598	1.8858	1.7918	1.4901	1.4563	1.9239
21	1.1317	1.358	1.8484	1.7918	1.3014	1.4377	1.8484
22	.9054	1.2071	1.1576	1.2449	1.1128	1.1949	.9054
23	.7545	1.0185	.8402	.7922	.8488	.4481	.9808
24	.3174	.4527	.8299	.3921	.3395	.3961	.3174
Max	1.7541	1.7918	1.8858	1.9239	1.6991	1.6804	1.9427
Min	.2241	.2263	.2452	.2075	.2075	.2075	.1886
Avg	.9475	1.0079	1.0827	1.1008	.9383	.9643	1.0040

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela
s/s

Feeder No / Name : 203 / 11 KV VASHI RLY 3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.2263	.2075	.2054	.2263	.2641	.2263
2	.2614	.2075	.1886	.1886	.2263	.2452	.1886
3	.2241	.1886	.1886	.1886	.2075	.2452	.1886
4	.2241	.1886	.2263	.1698	.2075	.2263	.1886
5	.2641	.2075	.2263	.1698	.2075	.2263	.1886
6	.2641	.2263	.2641	.1698	.2075	.1886	.2075
7	.2614	.2263	.2641	.1698	.1886	.1886	.2263
8	.3018	.2452	.2641		.2263	.2263	.2641
9	.2241	.2829	.2641	.1867	.3772	.3395	.3174
10	.3772	.3772	.2987	.2263	.3734	.3361	.3395
11	.4338	.4715	.2801	.2263	.3921	.3547	.415
12	.4715	.4668	.3547	.2452	.3921	.3547	.4338
13	.3772	.4481	.3361	.2452	.3734	.3547	.3961
14	.4715	.4481	.2801	.2641	.3734	.3734	.415
15	.415	.4294	.2987	.2641	.3734	.3361	.4715
16	.415	.4294	.3174	.2641	.3734	.3361	.4338
17	.4715	.4108	.2987	.2641	.3734	.3361	.415
18	.415	.4527	.3361	.2452	.3734	.3361	.4338
19	.4338	.4904	.3547	.2829	.3772	.3547	.4338
20	.3584	.3772	.3174	.2829	.3772	.3547	.3772
21	.3018	.3395	.2801	.2829	.3395	.3547	.3206
22	.2829	.3584	.2801	.2452	.2829	.2801	.2829
23	.2452	.3018	.2801	.2452	.2641	.2614	.2829
24		.2263	.2075	.2241	.2263	.2641	.2427
Max	.4715	.4904	.3547	.2829	.3921	.3734	.4715
Min	.2241	.1886	.1886	.1698	.1886	.1886	.1886
Avg	.3372	.3345	.2756	.2285	.3058	.2974	.3204

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela
s/s

Feeder No / Name : 204 / 11 KV MICROTECH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.5093	.5281	.4108	.415	.4904	.3772
2	.4108	.4904	.4904	.3584	.415	.4715	.3584
3	.3772	.4527	.4904	.3584	.3772	.4715	.3206
4	.3734	.3772	.4527	.415	.3772	.4527	.2829
5	.3921	.3772	.4527	.415	.415	.4527	.2829
6	.4108	.415	.4338	.3772	.4338	.4338	.3206
7	.4294	.415	.4338	.4338	.4338	.415	.3584
8	.4481	.4527	.415		.4338	.415	.3772
9	.5601	.5658	.4338	.4108	.6602	.547	.5975
10	.7356	.7167	.4668	.4338	.7468	.5975	.679
11	.9431	.8865	.5415	.4715	.8215	.6722	.9431
12	.9808	.8589	.5975	.4904	.9149	.8215	.9431
13	1.0374	.8402		.5658	.9335	.8775	1.1128
14	1.0185	.8215	.6348	.5658	.9335	.9149	.9808
15	1.0374	.8402	.5788	.5281	.9522	.8962	1.226
16	.9808	.8402	.5788	.4904	.8962	.8402	1.1694
17	.9054	.8589	.5415	.4527	.8589	.7655	1.0751
18	.7922	.8488	.5601	.4715	.7842	.7468	.9431
19	.8299	.811	.6348	.5658	.7733	.7655	.9808
20	.8676	.7545	.5975	.6036	.7655	.7468	.9054
21	.7922	.7167	.5788	.6036	.679	.7095	.7545
22	.6602	.6602	.5601	.5658	.6036	.5975	.7545
23	.5658	.6036	.4854	.4715	.5281	.4854	.6602
24	.5041	.5658	.5281	.4668	.4338	.4904	.4294
Max	1.0374	.8865	.6348	.6036	.9522	.9149	1.226
Min	.3734	.3772	.415	.3584	.3772	.415	.2829
Avg	.6877	.6533	.5224	.4751	.6494	.6282	.7014

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela
s/sFeeder No / Name : 205 / 11 kv SUBSTATION TRF
Raghuleel Feeder KV- 11 /
OUTGOING

SHEDDABLE URBAN

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0566	.0754	.0754	.0754	.0754
2	.0566	.0566	.0566	.0566	.0566	.0754	.0566
3	.0566	.0566	.0566	.0566	.0566	.0754	.0514
4	.0566	.0566	.0566	.0566	.0566	.0566	.0566
5	.0566	.0566	.0566	.0566	.0566	.0566	.0514
6	.0566	.0566	.0566	.0514	.0566	.0566	.0566
7	.0566	.0566	.0566	.0566	.0566	.0566	.0566
8	.0566	.0754	.0566		.0566	.0754	.0566
9	.056	.0754	.0754	.056	.0566	.0754	.0566
10	.0566	.0754	.0373	.0566	.056	.0754	.0566
11	.0566	.0754	.0747	.0566	.056	.0754	.0566
12	.0566	.0747	.0747	.0566	.056	.0754	.0566
13	.0566	.0754	.0747	.0566	.056	.0754	.0566
14	.0566	.0747	.0747	.0566	.2614	.0754	.0566
15	.0566	.0747	.056	.0566	.056	.0754	.0566
16	.0566	.0747	.0747	.0566	.056	.0754	.0566
17	.0566	.0747	.0747	.0566	.056	.0747	.0754
18	.0566	.0754	.0754	.0566	.056	.0754	.0754
19	.0754	.0754	.0754	.0754	.0566	.0754	.0754
20	.0754	.0754	.0754	.0754	.0566	.0754	.0754
21	.0754	.0754	.0686	.0754	.0754	.0754	.0754
22	.0566	.0754	.0566	.0754	.0754	.0754	.0754
23	.0754	.0754	.0566	.0754	.0754	.0754	.0754
24	.0566	.0754	.0754	.0747	.0754	.0754	.0747
Max	.0754	.0754	.0754	.0754	.2614	.0754	.0754
Min	.056	.0566	.0373	.0514	.056	.0566	.0514
Avg	.0597	.0698	.0647	.0620	.0689	.0722	.0632

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela
s/s

Feeder No / Name : 206 / 11 KV MAITHILLI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2136	1.2071	1.2637	1.226	1.1694	1.2826	1.226
2	1.1576	1.1694	1.2637	1.1694	1.1694	1.2826	1.1694
3	1.1203	1.1694	1.2449	1.1317	1.1317	1.2826	1.1694
4	1.1203	1.1317	1.2449	1.1694	1.1317	1.3014	1.0631
5	1.1389	1.1694	1.226	1.1883	1.1694	1.3014	1.226
6	1.1576	1.2071	1.226	1.2071	1.1883	1.3014	1.3014
7	1.1949	1.2449	1.226	1.2323	1.1883	1.3014	1.3014
8	1.2696	1.2637	1.2637		1.2637	1.358	1.3203
9	1.5497	1.6409	1.3392	1.2637	1.5844	1.6032	1.5684
10	1.7353	1.7353	1.6244	1.2826	1.7177	1.6617	1.6787
11	1.9805	1.9616	1.6617	1.3203	1.8298	1.7177	1.8861
12	1.9805	1.9044	1.7924	1.4523		1.7737	2.0559
13	1.9239	1.8858	1.6804	1.4523	1.8671	1.8111	1.9993
14	1.9616	1.8671	1.6244	1.4712	1.8484	1.8111	1.9427
15	1.9805	1.8858	1.6617	1.4335	1.8298	1.9605	2.0182
16	1.9993	1.9044	1.6617	1.4523	1.7924		2.0182
17	1.9239	1.9044	1.6804	1.4712	1.7924	1.9605	2.1502
18	1.8861	1.7353	1.5432	1.4335	1.8298	1.8671	1.9993
19	1.6975	1.6221	1.5123	1.4523	1.6975	1.8671	1.7353
20	1.5466	1.5089	1.419	1.4523	1.5466	1.5123	1.5655
21	1.4146	1.4335	1.4377	1.4146	1.4335	1.4563	1.5466
22	1.4146	1.3392	1.3817	1.226	1.358	1.3256	1.4523
23	1.2637	1.3392	1.251	1.2071	1.3392	1.2883	1.3203
24	1.166	1.2637	1.2637	1.2883	1.2071	1.2826	1.251
Max	1.9993	1.9616	1.7924	1.4712	1.8671	1.9605	2.1502
Min	1.1203	1.1317	1.226	1.1317	1.1317	1.2826	1.0631
Avg	1.5332	1.5206	1.4372	1.3216	1.4820	1.5352	1.5819

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela
s/s

Feeder No / Name : 207 / 11 KV FISH MARKET

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.679	.6036	.6224	.5658	.6036	.5847	.6036
2	.5975	.5658	.6036	.547	.5658	.5847	.5658
3	.5601	.5658	.5658	.547	.5658	.6413	.5601
4		.6602	.6413	.6036	.6036	.679	.5658
5	.5975	.679	.679	.6224	.6036	.7167	.6036
6	.6348	.7545	.7167	.6413	.6602	.7545	.679
7	.6722	.8865	.7545	.679	.7922	.7922	.6173
8	.8589	.8676	.8299		.7922	.7922	.8402
9	.8029	.6979	.7167	.6722	.8299	.7356	.6722
10	.679	.679	.6535	.7167	.7095	.6722	.679
11	.6224	.6036	.6161	.5658	.5975	.5415	.5658
12	.6036	.5788	.5415	.5281	.5228	.5415	.5281
13	.5658	.5601	.5228	.6036	.4854	.5228	.6036
14	.547	.5415	.4854	.5658	.4715	.4668	.547
15	.5658	.5601	.4668	.4715	.4481	.4668	.547
16	.5281	.5601	.4854	.4715	.4854		.5658
17	.5658	.5601	.5601	.4715	.5228	.5415	.5658
18	.6224	.679	.6535	.5658	.5601	.5975	.6036
19	.7545	.7733	.7468	.7167	.679	.7282	.7545
20	.8299	.7545	.8029	.7922	.7545	.8215	.8676
21	.8488	.7356	.7468	.7545	.7167	.7655	.8488
22	.7545	.7356	.7095	.6979	.6979	.6908	.6979
23	.7167	.6979	.6722	.6602	.679	.6535	.6979
24	.7095	.6224	.6224	.6161	.6224	.5847	.6161
Max	.8589	.8865	.8299	.7922	.8299	.8215	.8676
Min	.5281	.5415	.4668	.4715	.4481	.4668	.5281
Avg	.6659	.6634	.6423	.6120	.6237	.6468	.6415

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela
s/s

Feeder No / Name : 208 / 11 KV ORISSA BHAVAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1698	.2641	.2075	.2075	.2263	.1886
2	.1494	.1509	.2452	.1886	.1886	.2263	.1698
3	.1494	.1509	.2452	.1886	.1698	.2263	.1698
4	.1494	.1509	.2263	.1886	.1698	.2075	.1698
5	.1494	.1509	.2263	.1886	.1698	.2075	.1698
6	.1494	.1886	.2075	.1886	.1698	.2075	.2075
7	.1494	.2075	.2075	.2075	.1886	.2075	.1886
8	.168	.2075	.2075		.2452	.2641	.2075
9	.3361	.2641	.2829	.2241	.3206	.3206	.3174
10	.5658	.5281	.3547	.2263	.4854	.3734	.4715
11	.6224	.679	.3547	.2263	.5975	.4108	.5658
12	.7545	.6535	.4108	.2263	.6348	.4854	.6602
13	.679	.6348	.4108	.2452	.6348	.4854	.6036
14	.6036	.6161	.3921	.2263	.6161	.4854	.8488
15		.6161	.3734	.2263	.6161	.6348	.7922
16	.7545	.5975	.3734	.2452	.5975	.5601	.811
17	.7167	.5975	.3361		.5788	.5601	.7545
18	.5658	.4338	.2987	.2829	.5788	.5144	.679
19	.5093	.4904	.2987	.2641	.4904	.5228	.5281
20	.3772	.415	.2614	.2263	.3584	.3547	.3584
21	.3772	.3395	.2241	.2263	.3206	.2987	.3018
22	.2829	.2829	.2241	.2075	.2829	.2427	.2263
23	.2452	.2641	.2241	.2075	.2452	.2054	.2075
24	.168	.1886	.2641	.2054	.2075	.2263	.1867
Max	.7545	.679	.4108	.2829	.6348	.6348	.8488
Min	.1494	.1509	.2075	.1886	.1698	.2054	.1698
Avg	.3814	.3741	.2881	.2193	.3781	.3523	.4077

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela
s/sFeeder No / Name : 209 / 11 KV CIDCO BUSINESS
CENTER Feeder KV- 11 /
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.1698	.0754	.1509	.0566	.0377	.0566
2	.056	.0754	.0754	.1509	.0566	.0377	.0514
3	.056	.0754	.0754	.0754	.0566	.0377	.056
4	.056	.0754	.0566	.0754	.0566	.0377	.0566
5	.056	.0566	.0566	.0754	.0566	.0377	.0377
6	.056	.0566	.0566	.0566	.0566	.0377	.0377
7	.0566	.0377	.0566	.0566	.0566	.0377	.0377
8	.0377	.1132	.0377		.0566	.0566	.0377
9	.0373	.1132	.0566	.2054	.0566	.0377	.0373
10	.0377	.1132	.0373	.2075	.056	.0373	.0377
11	.0377	.1132	.056	.2263	.0373	.0747	.0566
12	.0566	.1307	.056	.2452	.0373	.0747	.1886
13	.0377	.1307	.056	.2263	.0373	.0934	.2075
14	.0566	.1307	.056	.2263	.0373	.1307	.2075
15	.1886	.168	.0747	.1886	.0377	.1494	.2075
16	.2075	.2241	.3174	.2263	.0373	.1307	.2075
17	.1886	.2614	.2987	.2263	.0373	.1307	.2263
18	.1886	.2829	.2987	.2075	.0373	.1307	.2452
19	.2263	.2829	.2987	.2452	.0566	.1307	.2641
20	.2075	.2829	.3174	.2452	.0566	.1494	.2641
21	.2075	.2829	.2614	.2452	.0566	.168	.2641
22	.2075	.2829	.2614	.2263	.0566	.1494	.2641
23	.2075	.2641	.2427	.0943	.0377	.1307	.1698
24	.056	.1886	.0754		.0566	.0566	.0747
Max	.2263	.2829	.3174	.2452	.0566	.168	.2641
Min	.0373	.0377	.0373	.0566	.0373	.0373	.0373
Avg	.1075	.1630	.1356	.1765	.0494	.0873	.1373

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20, Sanpada
s/stnFeeder No / Name : 201 / 11 KV RELIANCE Sanpada
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0365	.0543	.0381	.0365	.0543	.0365	.0381
2	.0365	.0543	.0381	.0365	.0543	.0365	.0381
3	.0333	.0543	.0381	.0365	.0543	.0365	.0381
4	.0365	.0543	.0381	.0365	.0543	.0365	.0381
5	.0365	.0543	.0381	.0362	.0543	.0365	.0572
6	.0365	.0543	.0381	.0365	.0543	.0365	.0572
7	.0365	.0543	.0381	.0365	.0543	.0365	.0762
8	.0365	.0905	.0953	.0365	.0724		.0762
9	.073	.0905	.0365	.0362	.0724		.0724
10	.073		.0365	.0543	.073	.0762	.0724
11	.0724	.0762	.073	.0724	.0667	.0381	.0724
12	.0724	.0762	.073	.0543	.073	.0381	.0724
13	.0724	.0381	.0365	.0905	.073	.0381	.0724
14	.0724	.0381	.073	.0543	.073		.0724
15	.0543	.0381	.0365	.0543	.0333	.0381	.0543
16	.0543	.0381	.0365	.0543	.0365		.0548
17	.0543	.0381	.0365	.0548		.0381	.0543
18	.0543	.0381	.0365	.0543	.0365	.0381	.0543
19	.0543	.0381	.0365	.0543	.0365	.0381	.0543
20	.0543			.0543	.0365	.0381	.0543
21	.0543	.0381	.0365	.0543	.0365	.0381	.0543
22	.0543	.0381		.0543	.0365	.0381	.0724
23	.0543	.0381	.0365	.0543	.0365	.0381	.0543
24	.0365	.0543	.0381	.0365	.0543	.0365	.0381
Max	.073	.0905	.0953	.0905	.073	.0762	.0762
Min	.0333	.0381	.0365	.0362	.0333	.0365	.0381
Avg	.0521	.0522	.0447	.0491	.0533	.0394	.0583

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20, Sanpada
s/stn

Feeder No / Name : 202 / 11 KV SAI PRIDE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2105	1.0753	1.2955	1.0034	1.0911	.8919	1.2193
2	1.2423	1.0437	1.2765	.9875	1.1069	.9079	1.1431
3	1.2264	1.012	1.2193	.9716	1.1069	.9238	1.086
4	1.2583	1.0279	1.2193	.9556	1.0753	.9397	1.086
5	1.2742	1.0437	1.2765	.9397	1.1069	.9556	1.1622
6	1.3538	1.2696	1.3336	1.0034	1.1544	1.1309	1.2765
7	1.4175	1.5497	1.3527	1.099	1.4548		1.4289
8	1.3698	1.4548	1.4098	1.1468	1.3599	1.2583	1.6385
9	1.3698	1.4548	1.3698	1.2176	1.3916		1.439
10	1.5609		1.3061	1.3599	1.322	1.7528	1.4706
11	1.6129	1.6385	1.5131	1.4074	1.3857	1.9052	1.6129
12	1.4548	1.6004	1.3698	1.2334	1.2423	1.5242	1.4864
13	1.3916	1.5623	1.2423	1.2492	1.2264	1.448	1.2967
14	1.2492	1.3717	1.1468	1.1069	1.1149		1.2018
15	1.3283	1.4098	1.1149	1.0437	1.0512	1.2955	1.1702
16	1.2018	1.448	1.1468	.9962	1.0831		1.2423
17	1.2018	1.6766	1.322	1.0194		1.5242	1.3441
18	1.3916	1.7147	1.3379	1.0437	1.3857	1.7528	1.4232
19	1.5023	1.6385	1.322	1.2967	1.4016	1.6385	1.5181
20	1.4232		1.3061	1.2018	1.3061	1.5813	1.3916
21	1.3599	1.5623	1.1468	1.2334	1.3061	1.4861	1.3599
22	1.2967	1.448		1.2492	1.3061	1.448	1.2967
23	1.2018	1.4098	1.0831	1.1385	1.1149	1.3336	1.2018
24	1.1946	1.1702	1.3336	1.0512	1.1227	1.1864	1.3146
Max	1.6129	1.7147	1.5131	1.4074	1.4548	1.9052	1.6385
Min	1.1946	1.012	1.0831	.9397	1.0512	.8919	1.086
Avg	1.3373	1.3901	1.2802	1.1231	1.2268	1.3442	1.3254

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20, Sanpada
s/stnFeeder No / Name : 203 / 11 KV SEWERAGE TREATMENT
PLANT Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3216	.4108	.381	.227	.3174	.3595	.3429
2	.3405	.3734	.3239	.2081	.2987	.3784	.3048
3	.3595	.3547	.2858	.1892	.2987	.3973	.3048
4	.3784	.2614	.3429	.2081	.3361	.4162	.381
5	.3595	.2801	.381	.1892	.3361	.3973	.4191
6	.3784	.2987	.4191	.1892	.3174	.3784	.4572
7	.5486	.5041	.4763	.1892	.3734	.3973	.4572
8	.7189	.8589	.5716	.3784	.5788	.5297	
9	.5676	.8962	.6432	.2614	.8029		.8215
10	.8703		.6432	.4854	.8892	.724	.8589
11	.8589	.8383	.7	.3361	.8513	.9145	.9709
12	.6908	.6097	.5676	.5601	1.0405	.7621	1.1949
13	.7842	.724	.6432	.5041	.9081	.8002	1.1576
14	.9896	.7621	.5486	.4854	.8513		.8962
15	.6722	.7621	.6054	.4854	.9459	.5716	.8029
16	.6161	.7621	.5108	.5041	1.0027		.8513
17	.7095	.6478	.7	.5486		.6859	.8402
18	.5601	.8764	.4919	.5228	.5893	.6859	.7095
19	.6348	.8764	.4919	.5041	.6054	.5716	.6161
20	.3921		.5486	.4481	.6054	.5335	.5788
21	.3547	.5335	.4919	.5041	.5486	.4954	.5041
22	.4294	.4954		.5415	.3405	.5335	.5228
23	.3921	.4191	.3216	.4294	.3784	.381	.3734
24	.3405	.4108	.4191	.227	.3174	.4162	.3429
Max	.9896	.8962	.7	.5601	1.0405	.9145	1.1949
Min	.3216	.2614	.2858	.1892	.2987	.3595	.3048
Avg	.5528	.5889	.5004	.3803	.5884	.5395	.6395

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20, Sanpada
s/stnFeeder No / Name : 204 / 11 KV PAN INDIA VASHI
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.39	.4481	.4191	.3575	.3921	.3575	.381
2	.3738	.4294	.381	.3413	.3734	.3575	.381
3	.3575	.4108	.3429	.325	.3734	.2333	.3429
4	.3575	.3734	.2858	.325	.3361	.325	.381
5	.3413	.4108	.3429	.3088	.3361	.3088	.381
6	.3413	.4294	.381	.2925	.3547	.3088	
7	.3575	.4108	.381	.325	.3921	.325	
8	.39	.4668	.4191	.325	.3921	.3575	
9	.455	.5415	.39	.3734	.5415		.5788
10	.585		.455	.3921	.6501	.5716	.7095
11	.7842	.6859	.4875	.3921	.6501	.724	.7095
12	.7842	.8002	.5525	.4108	.6826	.7621	
13	.7842	.8002	.52	.4108	.6826	.724	.8589
14	.8029	.7621	.5525	.4294	.6013		.7842
15	.8589	.7811	.52	.4294	.6501	.7621	.8962
16		.8383	.4875	.4481	.6826		.7476
17	.8215	.8764	.455	.3738		.724	.8215
18		.7621	.455	.4294	.6176	.6097	.8775
19	.6908	.6859	.39	.4294	.52	.6478	.6722
20	.5788		.39	.3921	.455	.5716	.6161
21	.5228	.4954	.3575	.4108	.4225	.4954	.5415
22	.463	.4572		.3921	.4225	.4572	.4854
23	.4668	.4572	.3575	.3921	.39	.4572	.4668
24	.39	.4668	.4572	.3575	.3921	.3575	.4001
Max	.8589	.8764	.5525	.4481	.6826	.7621	.8962
Min	.3413	.3734	.2858	.2925	.3361	.2333	.3429
Avg	.5408	.5814	.4252	.3776	.4918	.4970	.6016

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20, Sanpada
s/stnFeeder No / Name : 205 / 11 KV KESHAV KUNJ
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8502	.8322	.9145	.8335	.8322	.7835	.9145
2	.8835	.8149	.8573	.8169	.8495	.7668	
3	.8835	.7975	.7621	.8169	.8669	.7502	
4	.9002	.8149	.8192	.8002	.8669	.7502	
5	.9169	.8322	.8764	.8169		.7335	
6	.9669	.8495	.9145	.8002	.8842	.8169	.9335
7	1.0002	1.0056	.9526	.7335	1.0229	.9002	.9526
8	.8335	.9362	.9907	.7335	.9362	.9335	1.0288
9	.8169	.9709	1.0669	1.0229	.9362		.9189
10	1.1503		1.0002	.9882	1.0502	1.0288	1.0229
11	1.1443	1.1431	1.1003	1.0402	1.0002	1.1812	1.0402
12	1.1096	1.1431	1.0336	1.0576	.9836	1.0669	1.1269
13	1.0576	1.0669	1.1003	1.0056	.9502	1.0288	1.0229
14	.9189	1.0669	.9002	.8842	.8335		.9536
15	.9015	1.0669	.9002	.8495	.8002	.9907	.9882
16	.9189	1.0669	.8169	.8842	.8335		.9169
17	.9709	1.0669	.9502	.7835		1.105	1.0056
18	.9362	1.0288	.8502	.9882	.8502	.9907	.9709
19	1.0056	1.0288	.9335	1.0056	.9669	1.0669	1.0749
20	1.0402		.9002	.9362	.9002	1.0479	1.0056
21	1.0056	1.1431	1.0404	.8842	.9669	1.0288	.9536
22	.9189	1.0479		.9536	.9033	1.0288	1.0229
23	.9015	.9526	.9002	.8669	.8335	1.0288	.9536
24	.8335	.8669	.9526	.8502	.8495	.7668	.9526
Max	1.1503	1.1431	1.1003	1.0576	1.0502	1.1812	1.1269
Min	.8169	.7975	.7621	.7335	.8002	.7335	.9145
Avg	.9527	.9792	.9362	.8897	.9053	.9426	.9880

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20, Sanpada
s/stnFeeder No / Name : 206 / 11 KV LADIES HOSTELL, SEC SHEDDABLE URBAN
10, SA Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2071	1.1317	.9526	.9808	.9808	.9431	.9145
2	1.226	1.1506	.9145	.9619	.9431	.9242	.9145
3	1.2637	1.1694	.8383	.9431	.9619	.9054	.8573
4	1.2637	1.1883	.8764	.9242	.9242	.8676	.8383
5	1.1763	1.2071	.9335	.9242	.9054	.9054	.8954
6	1.3203	1.2637	1.0669	.9808	1.1128	.9997	1.3336
7	1.5089	1.358	1.1622	1.1128	1.2826	1.3203	1.3336
8	1.4712	1.5089	1.4098	1.3203	1.4335	1.3203	1.6004
9	1.5089	1.358	1.4901	1.1694	1.3957		1.3014
10	1.4523		1.2071	1.2071	1.1506	1.2193	1.1506
11	1.1883	.9526	1.0751	1.0374	1.1317	1.0288	1.0185
12	1.0751	.9145	.9431	1.094	.9808		1.0751
13	.9619	.8383	.9431	1.0751	.9431	.8383	.9997
14	.8865	.8002	.7922	.8488	.7545		.9431
15	.9054	.8002	.7733	.7922	.7733	.8002	.9431
16	.9431	.8383	.7922	.7922	.8488		.9054
17	1.0185	.9526	1.0374	.9619		.9907	.9808
18	1.2323	1.2193	1.226	1.3769	1.1128	1.2955	1.1317
19	1.4712	1.4098	1.4712	1.3957	1.4335	1.4861	1.6221
20	1.5844		1.3957	1.3957	1.4712	1.448	1.6787
21	1.4712	1.4098	1.4523	1.4335	1.358	1.448	1.5844
22	1.5089	1.2003		1.3957	1.4146	1.2955	1.5089
23	1.1694	1.105	1.0562	1.1128	.9997	1.105	1.2637
24	1.2071	1.1317	1.0288	.9808	.9997	.9242	1.0098
Max	1.5844	1.5089	1.4901	1.4335	1.4712	1.4861	1.6787
Min	.8865	.8002	.7733	.7922	.7545	.8002	.8383
Avg	1.2509	1.1322	1.0799	1.0924	1.1005	1.1033	1.1585

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20, Sanpada
s/stnFeeder No / Name : 207 / Sector 11 sanpada Bhoomi
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2941	.2743	.2286	.3287	.2572	.2422	.3048
2	.3395	.2572	.1905	.3114	.2401	.2768	.3048
3	.3287		.1905	.2941	.2401	.2768	.2667
4	.3287	.2572	.1905	.2768	.2572	.2941	.2667
5	.346	.2401	.2286	.2941	.2229	.3114	.3048
6	.3633	.2572	.2286	.2941	.2743	.2941	.3429
7	.3806	.3944	.2667	.2595	.3429	.2422	.381
8	.3979	.3772	.3048	.2941	.3258		.381
9	.4671	.4801	.3806	.3429	.4458		.4458
10	.5709		.3633	.3944	.519	.5335	.583
11	.6001	.5716	.519	.3944	.6401	.6097	.6173
12	.6001	.5335	.519	.3944	.5363		.5487
13	.5316	.4954	.3806	.3772	.4498	.4572	.463
14	.5316	.5335	.3806	.3601	.4152		.4973
15	.5144	.5335	.3806	.3258	.4498	.4572	.463
16	.4973	.4954	.3806	.3258	.519		.519
17	.4801	.381	.3633	.2422		.4572	.5144
18	.4801	.4572	.346	.3086	.4152	.4191	.463
19	.4458	.4572	.4152	.3258	.4152	.4954	.463
20	.3944		.346	.3258	.4152	.4001	.4287
21	.3944	.4191	.4844	.3086	.346	.3429	.3944
22	.3601	.381		.3258	.3114	.3048	.3944
23	.3258	.3429	.2595	.3086	.2422	.3429	.3429
24	.2768	.2915	.2667	.3114	.2572	.3114	.3429
Max	.6001	.5716	.519	.3944	.6401	.6097	.6173
Min	.2768	.2401	.1905	.2422	.2229	.2422	.2667
Avg	.4271	.4015	.3311	.3219	.3712	.3721	.4181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20, Sanpada
s/stn

Feeder No / Name : 209 / Cidco Exhibition

Centre, Vashi Feeder KV- 11 /
OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS) (NO
STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0748	.0747	.3429	.0748	.2801	.0748	.0572
2	.0748	.0747	.3048	.0748	.2987	.0748	.0572
3	.0748	.056	.3048	.0748	.3361	.0748	.0572
4	.0748	.0747	.3048	.0748	.2801	.0748	.0572
5	.0749	.0747	.3239	.0935	.3361	.0561	.0762
6	.0748	.0747	.3429	.0748	.3361	.0561	.0762
7	.0748	.0747	.3429		.3361		.0762
8	.0748	.0747	.362	.0935	.3361	.0333	.0762
9	.0561	1.0082	.0935	.0747	.3174		.0747
10	.0561		.0748	.0747	.3368	.0572	.056
11	.056	.8573	.0748	.0747	.0751	.0572	.056
12	.056	.743	.0748	.0747	.0748		.0747
13	.056	.7811	.0748	.0934	.0748	.0572	.0747
14	.0747	.8192	.0561	.4854	.0748		.0747
15	.0747	.8383	.0561	.4294	.0748	.0572	.056
16	.056	.8573	.0561	.4854	.0748		.0748
17	.056	.8573	.0561	.5426		.0572	.0747
18	.056	.8764	.0561	.4854	.0748	.0762	.0747
19	.056	.4572	.0748	.6348	.0748	.0572	.0747
20	.056		.0748	.5041	.0748	.0572	.056
21	.0747	.3429	.065	.7842	.0748	.0572	.0747
22	.0747	.3429		.6348	.0748	.0572	.056
23	.0747	.362	.0748	.7095	.0748	.0572	.056
24	.0748	.0747	.3429	.0748	.6908	.0748	.0572
Max	.0749	1.0082	.362	.7842	.6908	.0762	.0762
Min	.056	.056	.0561	.0747	.0748	.0333	.056
Avg	.0670	.4453	.1711	.2923	.2079	.0615	.0666

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284254 / 33/33KV Sec- 20 Sanpada

Feeder No / Name : 401 / Feeder No1-33KV IC Sec14 NON SHEDDABLE EXPRESS HV FEEDERS
 Nerul Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	08-FEB-18	10-FEB-18	11-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	1.7924		1.9805		1.7541
23				2.0005	
24		1.8747			
Max	1.7924	1.8747	1.9805	2.0005	1.7541
Min	1.7924	1.8747	1.9805	2.0005	1.7541
Avg	1.7924	1.8747	1.9805	2.0005	1.7541

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284254 / 33/33KV Sec- 20 Sanpada

Feeder No / Name : 402 / Feeder No 2- 33KV IC NRI NON SHEDDABLE EXPRESS HV FEEDERS
 Sec 5 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	08-FEB-18	10-FEB-18	11-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	.4001		.4001		.4001
23				.0457	
24		.0457			
Max	.4001	.0457	.4001	.0457	.4001
Min	.4001	.0457	.4001	.0457	.4001
Avg	.4001	.0457	.4001	.0457	.4001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288065 / 220/33KV Sonkhar S/Stn

Feeder No / Name : 417 / 33 KV IC SEC 30 NERUL STN NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9547	1.9033	2.0199		1.9667	1.9547	1.749
2	2.0062	1.5947	1.9136	1.8404	1.9136	1.9547	1.749
3	1.9547	1.6461	1.8073		1.8073	2.0576	1.8519
4	1.9033	1.8004	1.701	1.7878	1.9136	2.1605	1.9547
5	2.0062	1.8004	1.9136		2.073	2.3148	1.9547
6	2.5206	2.0576	2.1262	2.1033	2.392	2.4691	2.1605
7	2.5206	2.4177	2.3388	2.524	2.613	2.6749	2.3663
8	2.7263	2.7778	2.5514		2.6046	2.572	2.4691
9	2.4177	2.5206	2.6046	2.3663	2.5514	2.6235	2.0576
10	2.1605	2.2857		2.3388		2.2119	2.3137
11	1.9547	2.2857		2.2857	1.8004	2.0062	
12	1.9547	2.1262	1.9456	2.1262	1.8519	1.8519	1.7353
13	1.9033	1.9136		2.0199	1.6975	1.749	
14	1.749	1.701	1.6827	1.9136	1.749	1.4403	1.6827
15		1.5947		1.8073	1.4918		
16	1.6461	1.5947	1.5249	1.6478	1.4403	1.4918	1.5249
17		1.701		1.701	1.5432	1.5947	
18	2.0062	1.7541	1.8404	1.8073	1.6461	1.6975	1.7878
19	2.5206	2.0199		2.0199	2.3148	2.3663	
20	2.6235	2.2857	2.5766	2.2857	2.4691	2.4177	2.7343
21	2.6749	2.5514		2.5514	2.4177	2.4177	
22	2.572	2.392	2.3663	2.4451			2.5766
23	2.3148	2.2857		2.2325	2.4177	2.0576	
24	2.1091	2.1091	2.073	2.0508	2.0199	1.8519	1.8519
Max	2.7263	2.7778	2.6046	2.5514	2.613	2.6749	2.7343
Min	1.6461	1.5947	1.5249	1.6478	1.4403	1.4403	1.5249
Avg	2.1909	2.0466	2.0616	2.0927	2.0316	2.0880	2.0306

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 201 / 11 KV KL-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	1.885				1.9959
8	1.9959				1.8665
9	1.7187		1.6263	1.5708	1.6078
10	1.4045				1.46
11					1.4045
23		1.7372			
24	1.6263	1.6078	1.5154	1.423	1.423
Max	1.9959	1.7372	1.6263	1.5708	1.9959
Min	1.4045	1.6078	1.5154	1.423	1.4045
Avg	1.7261	1.6725	1.5709	1.4969	1.6263

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 202 / 11 KV B G SHIRKE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.8745				.8669
8	.8916				.9536
9	.823		.7975	.7628	.8686
10	.7545				.6935
11					.6935
23		.7802			
24	.7202	.8059	.7282	.7628	.7628
Max	.8916	.8059	.7975	.7628	.9536
Min	.7202	.7802	.7282	.7628	.6935
Avg	.8128	.7931	.7629	.7628	.8065

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 203 / 11 KV V M JOG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	1.6651				1.7002
8	1.6651				1.7528
9	1.7528		1.7528		1.6126
10	1.4373				1.4373
11					1.3146
23		1.4548			
24	1.3496	1.3146	1.3321	1.2795	1.2795
Max	1.7528	1.4548	1.7528	1.2795	1.7528
Min	1.3496	1.3146	1.3321	1.2795	1.2795
Avg	1.5740	1.3847	1.5425	1.2795	1.5162

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 204 / 11 KV Herambha

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.3361				.3174
8	.3734				.3361
9	.3174		.3174	.2987	.3174
10	.3361				.2987
11					.2987
23		.2987			
24	.3174	.3174	.2987	.2987	.2987
Max	.3734	.3174	.3174	.2987	.3361
Min	.3174	.2987	.2987	.2987	.2987
Avg	.3361	.3081	.3081	.2987	.3112

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 205 / 11 KV SEC 14

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	1.7556				1.6817
8	1.9404				1.7741
9	1.6448		1.6632	1.6632	1.7926
10	1.6448				1.6817
11					1.6078
23		1.4415			
24	1.4969	1.3491	1.3121	1.386	1.386
Max	1.9404	1.4415	1.6632	1.6632	1.7926
Min	1.4969	1.3491	1.3121	1.386	1.386
Avg	1.6965	1.3953	1.4877	1.5246	1.6540

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 206 / 11 KV STP 12 FEEDER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.2218				.0924
8	.3696				.0924
9	.3142		.2587	.2218	.3326
10	.0739				.3142
11					.462
23		.0739			
24	.3326	.2218	.1848	.1848	.1848
Max	.3696	.2218	.2587	.2218	.462
Min	.0739	.0739	.1848	.1848	.0924
Avg	.2624	.1479	.2218	.2033	.2464

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 207 / SEC-9/E FEEDER NO-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.14				.1288
8	.127				.1027
9	.1419		.1102	.1232	.0934
10	.1438				.1027
11					.112
23		.1643			
24	.1699	.1344	.1251	.1438	.1438
Max	.1699	.1643	.1251	.1438	.1438
Min	.127	.1344	.1102	.1232	.0934
Avg	.1445	.1494	.1177	.1335	.1139

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 208 / SEC-9/E FEEDER NO-2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.0747				.0691
8	.0691				.0616
9	.0747		.0616	.0934	.0635
10	.0934				.0952
11					.1102
23		.0934			
24	.0784	.084	.0803	.0709	.0709
Max	.0934	.0934	.0803	.0934	.1102
Min	.0691	.084	.0616	.0709	.0616
Avg	.0781	.0887	.0710	.0822	.0784

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 209 / 11KV NEW LIG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	2.0243				2.0081
8	2.1052				2.2348
9	1.9433		2.0081	1.9919	1.9109
10	1.7004				1.6194
11					1.5708
23		1.749			
24	1.6518	1.6194	1.5223	1.4899	1.4899
Max	2.1052	1.749	2.0081	1.9919	2.2348
Min	1.6518	1.6194	1.5223	1.4899	1.4899
Avg	1.885	1.6842	1.7652	1.7409	1.8057

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223032 / 22/11 KV Kalmboli Steel

Market

Feeder No / Name : 201 / 11 KV STEEL CHAMBER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1433	.1303	.1303	.1254	.1218	.1412	.1289
2	.1433	.1285	.1303	.1254	.1218	.1376	.1289
3	.1433	.1249	.1339	.1254	.1195	.1303	.1254
4	.1433	.1213	.1339	.1254	.1146	.1357	.1254
5	.1433	.1231	.1357	.1218	.1122	.1376	.1254
6	.1433	.1249	.1267	.1218	.1182	.1484	.1218
7	.1361	.1122	.1267	.1182	.111	.1412	.1218
8	.1289	.1158	.1376	.1075	.1182	.1213	.1361
9	.1919	.1719	.1629	.1325	.1774	.1701	.1827
10	.2588	.2624	.2364	.1433	.2443	.2471	.2257
11	.3185	.2896	.2973	.1576	.2878	.24	.2973
12	.3529	.3258	.2865	.1612	.3131	.2651	.3547
13	.3584	.3185	.2901	.1576	.3547	.2507	.3728
14	.3584	.3294	.2973	.1397	.3475	.2328	.3259
15	.3638	.362	.2901	.1791	.3366	.2328	.3547
16	.3638	.333		.1504	.3167	.2328	.3868
17	.3566	.3366	.2865	.154	.2932	.2149	.3403
18		.2932	.2722	.1791	.2878	.2185	.3009
19		.2643	.2328	.1433	.2986	.2113	.2901
20	.2081	.21	.2077		.2389	.1719	
21	.1774	.1756	.1469	.154	.1774	.1612	.1863
22	.143	.1339	.1612	.1325	.1701	.1433	
23	.1339	.1249	.1289		.1575	.1289	.1325
24	.1325	.1303	.1267	.1146	.1182	.1466	.1254
Max	.3638	.362	.2973	.1791	.3547	.2651	.3868
Min	.1289	.1122	.1267	.1075	.111	.1213	.1218
Avg	.2201	.2101	.1947	.1395	.2107	.1817	.2223

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 201 / 11 KV C.E. FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7924	1.7556			1.4784		
2		1.6632			1.4784		
3		1.5708			1.386		
4		1.5708			1.4045		
5		1.5524		1.4563	1.6632		
6	1.9791	2.0328		1.4937	2.1253		1.8298
7	2.4646	2.3101		1.7177	2.3655		2.5019
8	2.6139			2.0165	2.4025		2.3899
9	2.3045	.5175	2.0911	2.2405	2.1807	2.3152	2.2405
10	2.1253		2.1285				2.2405
11	1.922			1.922			1.9605
12	1.7002	1.7002	1.8671	1.848	1.7002		1.7372
13	1.7002			1.922		1.531	1.6263
14	1.5524		1.4937	1.5893	1.4784	1.4937	
15	1.5154	1.5466					1.5154
16	1.5154	1.4784	1.4937	1.4784		1.4563	
17	1.7741	1.5893	1.6804	1.5893	1.5524		1.5524
18	1.848		1.8671	1.8298	1.7177		1.8671
19	2.2177		2.1285	2.3285	2.0911	2.2032	2.2177
20	2.3285		2.2779	2.2177	2.3152		2.3655
21	2.4025		2.2405	2.2177		2.2032	2.2177
22	2.1807		1.8671	2.0328			2.2177
23	.5544			1.848			1.9404
24	1.7924	1.9589	1.643	1.643	1.5708	1.643	1.5684
Max	2.6139	2.3101	2.2779	2.3285	2.4025	2.3152	2.5019
Min	.5544	.5175	1.4937	1.4563	1.386	1.4563	1.5154
Avg	1.9142	1.6344	1.8982	1.8551	1.8069	1.8351	1.9993

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 202 / 11 KV N.T.F.C. FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1109			.1478		
2		.1109			.1478		
3		.1109			.1478		
4		.1109			.1478		
5		.0739		.1509	.1478		
6	.112	.1109		.1509	.1478		.0187
7	.112	.1109		.1509	.1109		.112
8	.1132			.1509	.1848		.1132
9	.1132	.1109	.1143	.1494	.1478	.1524	.1132
10	.1478		.1132				.112
11	.1478			.1478			.112
12	.1478	.1478	.1132	.1478	.1109		.1109
13	.1478			.1478		.1509	.112
14	.1478		.1478	.1848	.1109	.1132	
15	.1478	.1886					.1109
16	.1109	.1478	.1478	.1848		.1132	
17	.1478	.1478	.1132	.1478	.1848		.1663
18	.1478		.1494	.1494	.1524		.112
19	.1478		.1509	.1478	.1524	.0189	.1109
20	.1478		.1509	.1478			.1109
21	.1478		.1509	.1478		.0187	.1109
22	.1478		.1509	.1478			.1109
23	.1109			.1478			.1109
24	.1132	.1109	.1143	.1509	.1478	.1524	.0189
Max	.1478	.1886	.1509	.1848	.1848	.1524	.1663
Min	.1109	.0739	.1132	.1478	.1109	.0187	.0187
Avg	.1336	.1225	.1347	.1530	.1460	.1028	.1039

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 203 / SUB STATION T/F

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0187			.0187		
2		.0187			.0187		
3		.0187			.0187		
4		.0187			.0187		
5		.0187		.0189	.0187		
6	.0189	.0187		.0189	.0187		.0189
7	.0189	.0187		.0189	.0187		.0189
8	.0189			.0189	.0187		.0189
9	.0189	.0185	.0191	.0189	.0187	.0191	.0189
10	.0187		.0189				.0187
11	.0189			.0189			.0187
12	.0189	.0189	.0189	.0189	.0189		.0187
13	.0187			.0189		.0189	.0187
14	.0187		.0189		.0189	.0189	
15	.0187	.0189					.0189
16	.0187	.0189	.0189	.0189		.0189	
17	.0189	.0189	.0189	.0189	.0189		.0189
18	.0187		.0189	.0187	.0191		.0187
19			.0189	.0187	.0191	.0189	.0187
20			.0189	.0187	.0191		.0185
21			.0189	.0187		.0189	.0187
22			.0189	.0187			.0187
23	.0187			.0187			.0185
24	.0189	.0187	.0191	.0189	.0187	.0191	.0189
Max	.0189	.0189	.0191	.0189	.0191	.0191	.0189
Min	.0187	.0185	.0189	.0187	.0187	.0189	.0185
Avg	.0188	.0187	.0189	.0188	.0188	.0190	.0188

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 204 / 11 KV MHATMA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6476	1.7002			1.6632		
2		1.5708			1.5708		
3		1.4784			1.5154		
4		1.5154			1.4784		
5		1.7002		1.5043	1.7556		
6	1.9342			1.6263	2.2177		1.9342
7	2.4356	2.4394		1.7909	2.5873		2.2923
8	2.5789			2.2207	2.6797		
9	2.4356	2.5873	2.6139	2.364	2.5873	2.2405	2.2207
10	2.2177		2.1491				2.2177
11	1.9959			2.1437			1.9418
12	1.848	1.7002	1.7924	1.922	1.6263		1.848
13	1.848			1.848		1.4327	1.848
14	1.5524		1.4784		1.6263	1.2894	
15	1.5524	1.4784					1.4784
16	1.5524	1.5089	1.4045	1.4784		1.2178	
17	1.6263	1.4045	1.4327	1.4045	1.4784		1.5524
18	1.848		1.7193	1.7002	1.7177		1.8671
19	2.4025		2.2405	2.2916	1.9418	2.0058	2.3655
20	2.4394		2.1491	2.3101	2.1658		2.5873
21	2.4025		2.1491	2.3101		2.0774	2.3101
22	2.3655		2.0058	2.2177			2.3101
23	2.2177			1.9959			2.2177
24	1.8625	1.922	1.8671	1.7909	1.7741	1.8671	1.7193
Max	2.5789	2.5873	2.6139	2.364	2.6797	2.2405	2.5873
Min	1.5524	1.4045	1.4045	1.4045	1.4784	1.2178	1.4784
Avg	2.0382	1.7505	1.9168	1.9364	1.8991	1.7330	2.0444

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 205 / 11Kv Pump P2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4327	1.4784			1.386		
2		1.4784			1.386		
3		1.386			1.3306		
4		1.386			1.3306		
5		1.4045		1.3352	1.6632		
6	1.7193	2.1253		1.4883	2.0328		1.7193
7	2.2207	2.2916		1.5043	2.2177		2.0058
8	2.2923			1.7193	2.2177		2.2207
9	2.2207	2.2177	2.0485	1.8625	2.2177	2.0485	2.1491
10	2.2177		1.9342				2.2032
11	2.0698			2.0328			1.9418
12	1.848	1.7002	1.7909	2.0328	1.4784		1.7741
13	1.848			1.6263		1.4327	1.7002
14	1.4784		1.3306		1.5893	1.3611	
15	1.4784	1.4045					1.4415
16	1.4045	1.1827	1.4045			1.0745	
17	1.3306	1.1088	1.3611	1.3306	1.2567		1.1458
18	1.5708		1.5684	1.4784	1.6461		1.587
19	2.2177		1.7909	1.9959	1.7924	1.8625	2.0698
20	2.0698		2.0165	1.9404	1.829		2.0698
21	2.0698		2.0185	1.922		1.7909	2.1437
22	2.0328		1.7193	1.848			2.0328
23	1.7741			1.7002			1.7741
24	1.5043	1.5524	1.4632	1.4632	1.4784	.4024	1.4327
Max	2.2923	2.2916	2.0485	2.0328	2.2177	2.0485	2.2207
Min	1.3306	1.1088	1.3306	1.3306	1.2567	.4024	1.1458
Avg	1.8400	1.5936	1.7039	1.7050	1.6783	1.4247	1.8477

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 206 / HORIZON SCHOOL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.4066			.4435		
2		.4066			.4435		
3		.4066			.4435		
4		.4066			.4435		
5		.4066		.3658	.4435		
6	.4298	.4805		.3658	.4805		.3048
7	.5487	.5914		.4024	.5175		.3353
8	.6584			.3841	.6653		.4877
9	.8048	.8131	.5761	.4115	.7023	.6413	.7202
10	1.0349		.032				.8215
11	.9979			.4805			.8589
12	.961	.8871	.6219	.5175	.8501		.924
13	.8871			.5175		.5487	.8501
14	.8871		.6283		.8501	.4268	
15	1.0349	.8501					.7392
16	.924	.7762	.5544	.4435		.5121	
17	.7392	.7392	.5121	.4435	.6283		.6283
18	.7023		.4755	.4805	.5658		.5601
19	.5544		.4656	.5175	.5281	.4161	.5914
20	.5544		.4656	.5175	.4904		.5914
21	.5175		.5373	.4435		.426	.5914
22	.5175		.5121	.4435			.5914
23	.5175			.4805			.4435
24	.3658	.4435		.3963	.4805	.4024	.3841
Max	1.0349	.8871	.6283	.5175	.8501	.6413	.924
Min	.3658	.4066	.032	.3658	.4435	.4024	.3048
Avg	.7002	.5857	.4892	.4477	.5610	.4819	.6131

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 207 / 11 kv khandeshwar railway NON SHEDDABLE EHV INDUSTRIAL FEEDERS
 stn Feeder KV- 11 / OUTGOING (NON CONTINOUS PROCESS)(NO
 STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.061	.0747			.0747		
2		.0747			.0747		
3		.0747			.0747		
4		.0747			.0747		
5		.0747		.0377	.0747		
6	.0305	.0191		.0377	.0191		.0358
7	.0305	.0057		.0377	.0057		.0377
8	.0305			.0377	.0057		.0377
9	.6706	.0038	.0088	.0377	.005	.0137	.0377
10	.005		.0305				.0057
11	.0076			.0076			.005
12	.0076	.0076	.0305	.0076	.0076		.0042
13	.0057			.0076		.0343	.0046
14	.0057		.0076		.037	.0377	
15	.0057	.0076					.0076
16	.0057	.0076	.0185	.037		.0377	
17	.0076	.0076	.0187	.0076	.0076		.037
18	.0057		.0305	.0305	.0213		.0038
19	.0754		.0305	.0377	.0221	.0373	.0038
20	.0747		.0305	.0739	.0259		.0739
21	.0747		.0686	.0739		.0754	.0373
22	.0747		.061	.0739			.037
23	.0754			.0747			.0747
24	.061	.0739		.0754	.0747	.0339	.0754
Max	.6706	.0747	.0686	.0754	.0747	.0754	.0754
Min	.005	.0038	.0076	.0076	.005	.0137	.0038
Avg	.0658	.0390	.0305	.0409	.0378	.0386	.0305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 201 / 11 KV STATION T/F

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.0566	.0566	.0549	.0566	.0566	.0549
2	.0549	.0566	.0566	.0549	.0566	.0566	.0549
3	.0549	.0566	.0566	.0549	.0566	.0566	.0549
4	.0549	.0566	.0566	.056	.0566	.0566	.0549
5	.0549	.0566	.0566	.0549	.0566	.0566	.0549
6	.0549		.0566	.0549	.0566	.0566	.0549
7	.0549	.0566	.0566	.0549	.0566	.0566	.0549
8	.0566	.0566		.0566	.0566	.0549	.0566
9	.0566	.0566	.0549	.0566	.0566	.0549	.0566
10	.0566	.0566	.0549	.0566	.0566	.0549	.0566
11	.0566	.0566	.0549	.0566	.0566	.0549	.0566
12	.0566	.0566	.0549	.0566	.0566	.0549	.0566
13	.0566	.0566	.0549	.0566	.0566	.0549	.0566
14	.0566	.0566	.0549	.0566	.0566	.0549	.0566
15	.0566	.0566	.0549	.0566	.0566	.0549	.0566
16	.0566	.0566	.0549	.0566	.0566	.0549	.0566
17	.0566	.0566	.0549	.0566	.0566	.0549	.0566
18	.0566	.0566	.0549	.0566	.0566	.0549	.0566
19	.0566	.0566	.0549	.0566	.0566	.0549	.0566
20	.0566	.0566	.0549	.0566	.0566	.0549	.0566
21	.0566	.0566	.0549	.0566	.0566	.0549	.0566
22	.0566	.0566	.0549	.0566	.0566	.0549	.0566
23	.0566	.0566	.0549	.0566	.0566	.0549	.0566
24	.0549	.0566	.0566	.0549	.0566	.0566	.0549
Max	.0566	.0566	.0566	.0566	.0566	.0566	.0566
Min	.0549	.0566	.0549	.0549	.0566	.0549	.0549
Avg	.0560	.0566	.0555	.0561	.0566	.0555	.0560

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 203 / 11 KV JUI GAON

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8656	1.8861	1.6975	1.7193	1.773	1.5278	1.6461
2	1.7558	1.7353	1.6975	1.6461	1.7353	1.5089	1.5364
3	1.7924	1.6975	1.6975	1.6278	1.7353	1.5466	1.4815
4	1.7558	1.6975	1.6975	1.6278	1.7918	1.5844	1.4998
5	1.7741	1.7164	1.773	1.6461	1.8673	1.6975	1.5729
6	2.0119	2.0936	1.9616	1.6644	2.32	1.9239	1.8107
7	2.5606	2.452	2.1879	1.7193	2.3011	2.1879	2.3045
8	2.8292	2.7161	2.4143	2.5274	2.5274	2.4508	2.5274
9	2.5463	2.6783	2.3594	2.6783	2.6783	2.4691	2.6783
10	2.6783	2.6783	2.4508	2.6029	2.5652	2.3777	2.5652
11	2.6029	2.9424	2.4143	2.5274	2.7915	2.2862	2.7915
12	2.4897	2.1879	2.4508	2.1125	2.4143	2.1948	2.4143
13	2.3388	2.1125	2.4143	2.1502	1.9805	2.0119	1.9805
14	2.1502	2.1502	2.3777	1.7833	1.6975	1.9204	1.6975
15	2.0748	1.7918	2.2314	1.6787	1.773	1.9022	1.773
16	2.2257	2.2257	1.9387	1.7918	1.7353	1.7193	1.9239
17	2.2634	2.1691	2.0485	2.1125	1.773	1.7558	2.1125
18	2.2634	2.0748	2.3777	2.4897	1.9993	2.1399	2.0936
19	2.8481	2.6783	2.8715	2.5652	2.5652	2.396	2.7161
20	2.999	2.6029	2.9264	2.6029	2.452	2.4874	2.8292
21	2.8292	2.9047	2.8898	2.6029	2.4143	2.4143	2.6406
22	2.6406	2.4897	2.7069	2.6595	2.3577	2.2131	2.6029
23	2.452	2.2634	2.2131	2.3577	1.9805	2.1216	2.3765
24	2.0485	1.9616	1.8484	1.8839	1.8107	1.7353	1.7375
Max	2.999	2.9424	2.9264	2.6783	2.7915	2.4874	2.8292
Min	1.7558	1.6975	1.6975	1.6278	1.6975	1.5089	1.4815
Avg	2.3248	2.2461	2.2353	2.1157	2.1266	2.0239	2.1380

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 204 / 11 KV SURAJ PARK FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5181	1.5089	1.3957	1.3169	1.3769	1.2449	1.2803
2	1.39	1.4335	1.358	1.2803	1.358	1.2071	1.2254
3	1.4083	1.4901	1.3203	1.2803	1.358	1.226	1.1706
4	1.39	1.4523	1.3203	1.2803	1.3769	1.2449	1.2254
5	1.3717	1.4712	1.358	1.2986	1.4523	1.3203	1.2071
6	1.5729	1.6221	1.4712	1.3535	1.6032	1.3957	1.4449
7	2.0119	1.8296	1.8861	1.4449	1.773	1.9239	1.8473
8	2.2634	2.2257	2.0485	1.8107	1.8484	1.9936	1.8484
9	2.037	2.0748	2.0851	1.9616	1.8107	2.0119	1.8107
10	1.6975	1.7918	1.7924	1.773	1.8107	1.8656	1.8107
11	1.7353	1.6598	1.6461	1.6598	1.6975	1.6461	1.6975
12	1.6032	1.4712	1.4998	1.4712	1.5466	1.4815	1.5466
13	1.5466	1.4335	1.4083	1.4712	1.5089	1.2803	1.5089
14	1.4335	1.3203	1.3169	1.3203	1.358	1.2254	1.358
15	1.358	1.2826	1.262	1.2071	1.2449	1.1706	1.2449
16	1.3957	1.2071	1.2071	1.226	1.226	1.0608	1.4146
17	1.4335	1.358	1.2071	1.2637	1.3203	1.0608	1.3957
18	1.6221	1.5466	1.5181	1.6598	1.5089	1.39	1.5655
19	2.037	1.9239	1.8656	1.8484	1.8861	1.8473	2.037
20	2.1125	1.9993	1.9022	1.9993	1.9993	1.9022	2.0559
21	2.1313	1.9805	1.8839	1.9616	1.9239	1.8473	2.037
22	1.9239	1.8107	1.701	1.7918	1.7918	1.7193	1.8861
23	1.7918	1.6221	1.4815	1.6221	1.5844	1.5364	1.8107
24	1.6095	1.6221	1.4712	1.4083	1.4335	1.3957	1.39
Max	2.2634	2.2257	2.0851	1.9993	1.9993	2.0119	2.0559
Min	1.358	1.2071	1.2071	1.2071	1.226	1.0608	1.1706
Avg	1.6831	1.6307	1.5586	1.5296	1.5749	1.4999	1.5758

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 205 / 11 KV AWAS FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5364	1.4901	1.358	1.3169	1.4335	1.2826	1.3169
2	1.5364	1.4712	1.3203	1.2803	1.4146	1.2449	1.2254
3	1.39	1.4523	1.3203	1.2803	1.4146	1.226	1.2071
4	1.3717	1.4523	1.3203	1.2803	1.3957	1.2449	1.2254
5	1.4083	1.4712	1.358	1.2803	1.4712	1.2826	1.2071
6	1.6461	1.6221	1.4712	1.3535	1.6221	1.3203	1.4815
7	1.957	1.773	1.7353	1.4632	1.905	1.773	1.9022
8	2.0748	1.9616	1.9387	1.8107	1.8861	1.8107	1.8861
9	1.8861	1.9239	1.9387	1.8861	1.8107	1.8473	1.8107
10	1.6975	1.7353	1.7558	1.6975	1.6598	1.7193	1.6598
11	1.6221	1.5466	1.6461	1.5844	1.6221	1.6461	1.6221
12	1.5089	1.4712	1.5497	1.4712	1.4712	1.5364	1.4712
13	1.4335	1.4335	1.5181	1.3957	1.358	1.262	1.358
14	1.358	1.3203	1.3535	1.2449	1.2826	1.1706	1.2826
15	1.3014	1.2449	1.2803	1.2449	1.2071	1.134	1.2071
16	1.358	1.2449	1.2254	1.358	1.1694	1.1157	1.358
17	1.4712	1.358	1.262	1.4335	1.358	1.134	1.358
18	1.773	1.8484	1.7193	2.037	1.6032	1.39	1.6409
19	2.2445	2.1879	2.1216	2.1691	2.037	2.0119	2.2822
20	2.3011	2.2257	2.0485	2.1502	2.1125	2.0851	2.32
21	2.2634	2.2257	2.0851	2.1691	2.1879	2.0485	2.2822
22	2.0748	1.9616	1.7924	2.0182	1.9993	1.8656	2.0182
23	1.8296	1.6409	1.5546	1.6598	1.5466	1.5729	1.7541
24	1.6278	1.5655	1.5089	1.4449	1.4712	1.4712	1.4083
Max	2.3011	2.2257	2.1216	2.1691	2.1879	2.0851	2.32
Min	1.3014	1.2449	1.2254	1.2449	1.1694	1.1157	1.2071
Avg	1.6947	1.6512	1.5909	1.5846	1.6016	1.5082	1.5952

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 206 / 11 KV KAMOTHE VILLAGE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.8861	1.6975	1.6827	1.7353	1.5844	1.5364
2	1.6827	1.7918	1.6975	1.6461	1.6975	1.5466	1.4632
3	1.701	1.7541	1.6598		1.6975	1.5466	1.4632
4	1.6827	1.7353	1.6598	1.6278	1.7353	1.5466	1.4449
5	1.701	1.7353	1.6975	1.6461	1.7918	1.5844	1.4449
6	1.8656	1.9805	1.773	1.6827	1.9427	1.6598	1.7558
7	2.3228	2.2634	2.1125	1.7193	2.1879	2.1125	2.1948
8	2.5274	2.3011	2.3777	2.1879	2.1879	2.1399	2.1879
9	2.1313	2.2634	2.3594	2.1691	2.1691	2.1216	2.1691
10	2.0748	1.9993	1.8656	1.8484	2.037	1.9022	2.037
11	1.7918	1.8296	1.7193	1.7353	1.6975	1.7193	1.6975
12	1.6598	1.6221	1.6461	1.6221	1.6598	1.6461	1.6598
13	1.6598	1.5466		1.5089	1.5844	1.5729	1.5844
14	1.5089	1.4146	1.4815	1.358	1.3957	1.3169	1.3957
15	1.4712	1.4335	1.4266	1.358	1.358	1.3169	1.358
16	1.5278	1.5089	1.4083	1.5278	1.4146	1.3717	1.5278
17	1.6787	1.5466	1.39	1.7164	1.5655	1.3535	1.6032
18	1.9993	1.9993	1.829	2.2257	1.9805	1.7193	1.8861
19		2.5274	2.3777	2.4897	2.4897	2.3777	2.6029
20	2.6217	2.4143	2.3594	2.452	2.5274	2.4508	2.6029
21	2.6217	2.452	2.2862	2.452	2.452	2.3777	2.6406
22	2.4897	2.1879	2.2131	2.3388	2.3388	2.1765	2.452
23	2.3011	1.9993	1.9753	2.037	1.8861	1.957	2.2445
24	1.9204	2.037	1.8861	1.8107	1.7918	1.7353	1.6461
Max	2.6217	2.5274	2.3777	2.4897	2.5274	2.4508	2.6406
Min	1.4712	1.4146	1.39	1.358	1.358	1.3169	1.358
Avg	1.9519	1.9262	1.8652	1.8627	1.8885	1.7848	1.8583

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 208 / 11 KV O/G SPARE-8

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.0566	.0754	.0732	.0754	.0754	.0732
2	.0549	.0566	.0754	.0732	.0754	.0754	.0732
3	.0549	.0566	.0754	.0732	.0754	.0754	.0732
4	.0549	.0566	.0754	.0732	.0754	.0754	.0732
5	.0549	.0566	.0754	.0732	.0754	.0754	.0732
6	.0549	.0566	.0754	.0732	.0754	.0754	.0732
7	.0549	.0566	.0754	.0732	.0754	.0754	.0732
8	.1509	.0754	.0732	.132	.0754	.0732	.0754
9	.1509	.0754	.0732	.132	.0943	.0732	.132
10	.1509	.1509	.1646	.132	.1509	.0732	.132
11	.1509	.132	.1646	.132	.1509	.0732	.132
12	.1509	.132	.1646	.132	.1509	.128	.132
13	.1509	.132	.1646	.132	.132	.128	.132
14	.1509	.1509	.128	.132	.132	.128	.132
15	.1509	.132	.128	.132	.132	.1463	.132
16	.1509	.132	.128	.132	.132	.1463	.132
17	.1698	.1509	.128	.0754	.132	.1463	.1509
18	.1509	.1509	.128	.1509	.1509	.0549	.1509
19	.1698	.1698	.1463	.1509	.1509	.1463	.1698
20	.1509	.1509	.1463	.1698	.1698	.128	.1698
21	.1509	.1509	.1463	.1509	.1509	.128	.1698
22	.1698	.0943	.0914	.1509	.1509	.128	.1698
23	.0566	.0754	.0914	.0754	.0754	.0732	.0754
24	.0549	.0566	.0754	.0732	.0754	.0754	.0732
Max	.1698	.1698	.1646	.1698	.1698	.1463	.1698
Min	.0549	.0566	.0732	.0732	.0754	.0549	.0732
Avg	.1173	.1045	.1112	.1124	.1139	.0991	.1156

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 209 / SPARE OUTGOING 9

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	10-FEB-18
HR	Load (MW)
23	.1463
Max	.1463
Min	.1463
Avg	.1463

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 210 / SPARE OUTGOING

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	13-FEB-18
HR	Load (MW)
23	.1463
Max	.1463
Min	.1463
Avg	.1463

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 211 / BHAGWATI HEIGHTS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7682	.7545	.6602	.695	.7167	.6224	.6401
2	.7316	.7356	.6602	.6767	.7167	.6602	.6584
3	.7316	.679	.6413	.6767	.6413	.679	.6401
4	.7316	.6979	.6602	.695	.679	.6602	.6401
5	.7499	.6602	.6979	.695	.7356	.679	.6584
6	.8779	.7356	.7356	.7133	.8865	.7167	.7682
7	1.0974	.9054	.8299	.7133	.8676	.9431	1.0242
8	.9431	1.0185	1.0059	.9808	.9808	1.0242	.9808
9	.9808	1.0562	1.0059	1.0562	1.0185	.9877	1.0185
10	.8865	.9431	.9511	.9997	.9242	1.0059	.9242
11	.9054	.9054	.8779	.9242	.7733	1.1706	.7733
12	.8488	.7922	.7865	.8488	.7922	.9511	.7922
13	.7733	.6979	.7499	.7545	.7356	.8048	.7356
14	.7356	.6413	.7316	.7545	.5847	.7133	.5847
15	.6602	.6602	.7316	.7356	.5093	.6584	.5093
16	.6979	.6413	.7316	.6979	.6413	.6219	.679
17	.7545	.7922	.7316	.7545	.7545	.6584	.7545
18	.8488	1.0185	.8962	1.1317	.8488	.823	.8865
19	1.1128	1.1694	1.1523	1.1506	1.0562	1.0608	1.094
20	1.226	1.094	1.0974	1.1317	1.0562	1.0974	1.1694
21	1.1317	1.094	1.0242	1.0185	1.0185	1.0608	1.094
22	.9808	.9619	.9328	.9997	.9242	1.0425	.9997
23	.9242	.8676	.823	.8865	.7545	1.0242	.9242
24	.8596	.811	.7545	.7316	.7167	.679	.695
Max	1.226	1.1694	1.1523	1.1506	1.0562	1.1706	1.1694
Min	.6602	.6413	.6413	.6767	.5093	.6219	.5093
Avg	.8733	.8472	.8279	.8509	.8055	.8477	.8185

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 212 / SHIVSENA OFFICE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8413	.8488	.8299	.7682	.8488	.7922	.7865
2	.823	.7922	.7922	.7316	.8299	.811	.7682
3	.823	.7733	.7922	.7316	.8299	.8299	.7682
4	.823	.7922	.811	.7499	.8488	.8488	.7865
5	.823	.811	.8676	.7682	.9054	.8299	.7682
6	.9145	.9054	.9242	.7682	.9808	.8488	.8413
7	1.0974	.9997	1.0562	.7682	1.0374	1.1128	1.1523
8	1.3769	1.3203	1.2254	1.3203	1.3203	1.1888	1.3203
9	1.2826	1.2826	1.2803	1.4146	1.4146	1.2254	1.4146
10	1.1128	1.1883	1.2803	1.1694	1.1694	1.1706	1.1694
11	1.1317	.1698	1.1706	1.094	1.1317	1.1706	1.1317
12	1.1128	1.094	1.0791	1.1128	1.094	1.0242	1.094
13	1.0562	1.0562	.9877	.9619	.9619	.9511	.9619
14	.9619	.9242	.9328	.9054	.9431	.8962	.9431
15	.9431	.9808	.9145	.8676	.8865	.8596	.8865
16	.9619	.8865	.8596	.9054	.8865	.8779	.8865
17	.8865	.9431	.8596	.8488	.8865	.8596	.9431
18	.9242	.9054	.9511	.9619	.8676	.823	.8299
19	1.1694	1.8673	1.0974	1.0185	1.0374	.9511	1.1128
20	1.1506	1.0751	1.0974	1.0374	1.094	1.0059	1.0751
21	1.1694	1.094	1.0608	1.0562	1.0562	.9877	1.094
22	1.0751	1.0562	1.0059	1.0751	.9997	.9511	1.0374
23	1.0185	.9431	.9328	.9431	.9242	.9511	.9997
24	.9145	.9242	.8676	.823	.8488	.8488	.8413
Max	1.3769	1.8673	1.2803	1.4146	1.4146	1.2254	1.4146
Min	.823	.1698	.7922	.7316	.8299	.7922	.7682
Avg	1.0164	.9847	.9865	.9501	.9918	.9507	.9839

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 302 / 22 KV Venkatesh Feeder
Feeder KV- 22 / OUTGOING

SHEDDABLE URBAN

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2803	1.2071	1.2071	1.0974	1.1317	1.094	1.1706
2	1.2437	1.1694	1.1694	1.0242	1.1317	1.094	1.0974
3	1.2437	1.1694	1.1694	1.0242	1.094	1.0562	1.0608
4	1.2071	1.2071	1.2071	1.0608	1.1317	1.094	1.0608
5	1.2437	1.2071	1.2826	1.0608	1.1694	1.1317	1.0608
6	1.3169	1.2826	1.3203	1.0974	1.3203	1.2071	1.0242
7	1.6095	1.358	1.4712	1.2071	1.3957	1.5089	1.4266
8	1.6598	1.5089	1.6095	1.6975	1.5089	1.4632	1.5089
9	1.5466	1.6221	1.6461	1.5844	1.5844	1.4266	1.5844
10	1.3203	1.5089	1.5364	1.5089	1.4335	1.4266	1.4335
11	1.4335	1.4335	1.3169	1.4712	1.358	1.4266	1.358
12	1.3203	1.3203	1.3169	1.3957	1.3203	1.3169	1.4335
13	1.2449	1.2826	1.2437	1.3203	1.2449	1.2437	1.2449
14	1.1317	1.2071	1.0608	1.2449	1.0562	1.0974	1.0562
15	1.1694	1.094	.9877	1.2449	1.0185	1.0242	1.0185
16	1.1694	1.1694	.9145	1.094	1.0185	1.0242	1.2071
17	1.1694	1.1317	1.0242	1.1317	1.094	1.0242	1.094
18	1.2826	1.2071	1.2437	1.2826	1.1694	1.2071	1.2449
19	1.6221	1.5844	1.4998	1.5089	1.4335	1.39	1.6598
20	1.6975	1.5844	1.4632	1.5844	1.5844	1.4266	1.773
21	1.6598	1.5089	1.4266	1.5844	1.5089	1.39	1.6598
22	1.5466	1.3957	1.39	1.4712	1.3957	1.3169	1.5844
23	1.4335	1.3203	1.2803	1.358	1.2071	1.3169	1.4335
24	1.3169	1.2449	1.2449	1.134	1.1694	1.1317	1.2071
Max	1.6975	1.6221	1.6461	1.6975	1.5844	1.5089	1.773
Min	1.1317	1.094	.9145	1.0242	1.0185	1.0242	1.0185
Avg	1.3696	1.3219	1.2930	1.2995	1.2700	1.2433	1.3084

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 303 / 22 KV JAWAHAR

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.829	1.8484	1.7353	1.7193	1.8861	1.9239	1.2803
2	1.6827	1.8107	1.6975	1.6095	1.8861	1.8861	1.2803
3	1.6461	1.8484	1.7353	1.6827	1.9239	1.7353	1.3169
4	1.6827	1.8484	1.7353	1.6827	1.8861	1.6975	1.2803
5	1.6827	1.8861	1.773	1.6095	1.8861	1.6975	1.3169
6	1.7924	1.9239	1.8861	1.6461	1.8861	1.7353	1.3169
7	1.9022	1.9239	1.8861	1.6095	1.8861	1.5844	1.39
8	1.9239	1.9616	2.0485	2.037	2.2634	1.6095	2.2634
9	2.5652	2.2634	2.3777	2.1502	2.4897	1.6095	2.4897
10	3.0178	2.6406	2.7435	2.3388	2.8669	1.5729	2.8669
11	3.1687	2.7161	2.8532	2.452	3.3196	1.5364	3.3196
12	3.0178	2.8292	2.8166	2.6029	3.1687	1.5364	2.5652
13	2.6406	2.6406	2.6337	2.3765	2.5652	1.5364	3.4705
14	3.0178	2.8292	2.7069	2.4897	3.4705	1.6095	2.8292
15	3.0178	2.7538	2.6703	2.5652	2.8292	1.6461	3.0556
16	3.0933	2.9424	2.7069	2.3765	3.0556	1.5729	3.6969
17	2.9424	2.8292	2.7069	2.2634	3.1687	1.5364	3.6969
18	2.5652	2.4897	2.4874	2.1502	2.4143	1.3535	3.131
19	2.3011	2.3765	2.1948	2.3011	2.7161	1.3535	3.0178
20	2.3011	2.1879	2.0485	2.0748	2.037	1.3535	1.2449
21	2.3011	2.1879	1.9753	2.0748	2.4143	1.3535	2.3765
22	2.3011	2.2634	1.8656	1.9993	2.1125	1.2803	1.9239
23	2.037	1.9239	2.0485	1.8861	2.1125	1.2803	1.8484
24	1.9387	1.9239	1.9239	1.9387	2.037	1.8107	1.3169
Max	3.1687	2.9424	2.8532	2.6029	3.4705	1.9239	3.6969
Min	1.6461	1.8107	1.6975	1.6095	1.8861	1.2803	1.2449
Avg	2.3487	2.2854	2.2190	2.0682	2.4284	1.5755	2.2623

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224001 / 33/11 KV Sec-27 Kharghar S/S

Feeder No / Name : 201 / 11 kv pl no.39, sec-27 SHEDDABLE URBAN
feeder Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0343				
2	.0171			.0171			
3			.0343		.0343		
4	.0171			.0171			
6	.0171	.0343	.0343	.0171	.0343	.0343	
7		.0343	.0343		.0343	.0343	.0171
8	.0171	.0343	.0343	.0171	.0343	.0343	
9		.0343	.0343	.0343	.0343	.0343	.0343
10		.0343	.0343	.0343	.0343	.0343	
11	.0343	.0343	.0343	.0343	.0343	.0343	.0343
12	.0343	.0343	.0343	.0343	.0343		.0343
13		.0343			.0343	.0343	.0343
14	.0171	.0343	.0343	.0343	.0343		.0343
15	.0343	.0343		.0343	.0343	.0343	.0343
16		.0343	.0343		.0343		.0343
17	.0171	.0343		.0343	.0343	.0171	
18	.0171	.0343	.0343	.0343	.0343	.0171	.0343
19	.0343	.0343		.0343	.0343	.0343	
20	.0343	.0343	.0343	.0343	.0343	.0343	.0343
21	.0343			.0343		.0343	.0343
22	.0343	.0343				.0343	
23	.0171	.0343	.0343	.0343		.0171	.0343
24	.0171	.0343	.0343	.0171	.0343		.0171
Max	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Min	.0171	.0343	.0343	.0171	.0343	.0171	.0171
Avg	.0246	.0343	.0343	.0292	.0343	.0309	.0317

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224001 / 33/11 KV Sec-27 Kharghar S/S

Feeder No / Name : 202 / 11 kv sec-35I feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0343				
2				.0343			
3			.0343		.0171		
4				.0343			
6			.0343	.0343	.0171	.0343	
7			.0343		.0171	.0343	.0343
8		.0343	.0343	.0229	.0171	.0343	
9		.0343	.0343	.0343	.0343	.0343	.0343
10		.0343	.0343	.0343	.0343	.0343	
11	.0343	.0343		.0343	.0343	.0343	.0343
12	.0343	.0343	.0343	.0343	.0343		.0343
13		.0343			.0343	.0343	.0343
14	.0171	.0343	.0343	.0343	.0343		.0343
15	.0171	.0343		.0343	.0343	.0343	.0343
16		.0343	.0343		.0343		.0343
17	.0171	.0343		.0343	.0343	.0171	
18	.0171	.0343	.0343	.0343	.0343	.0171	
19	.0343	.0343		.0343	.0343	.0343	
20	.0343	.0343	.0343	.0343	.0343	.0171	
21	.0171			.0343		.0343	
22	.0171	.0343	.0343			.0343	
23	.0171	.0343	.0343	.0343		.0343	
24		.0343	.0343	.0343	.0343		.0171
Max	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Min	.0171	.0343	.0343	.0229	.0171	.0171	.0171
Avg	.0234	.0343	.0343	.0336	.0303	.0309	.0324

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224001 / 33/11 KV Sec-27 Kharghar S/S

Feeder No / Name : 207 / 11 kv Juhi developers SHEDDABLE URBAN
 feeder Feeder KV- 11 /
 OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.583				
2	.583			.4801			
3			.6001		.5144		
4	.703			.4801			
6	.6687	.6687	.6687	.5487	.5144	.6173	
7		.7202	.7202		.463	.6687	.7716
8	.583	.7202	.6344	.583	.6173	.6859	
9		.7202	.6001	.4801	.4287	.6687	.6516
10		.703	.6859	.5144	.6859	.7202	
11	.7545	.6687		.7888	.6687	.7202	.6516
12	.6344	.6687	.7545	.703	.6687		.6173
13		.7202			.6859	.703	.6516
14	.6001	.6859	.7202	.7202	.6001		.6516
15	.6001	.5144		.6859	.4973	.4973	.6344
16		.703	.7202		.5144		.5487
17	.7202	.5487		.7888	.5487	.6859	.7202
18	.7716	.703	.5144	.7888	.703	.7716	.7888
19	.8745	.6687		.6859	.6687	.9259	
20	.8059	.823	.4973		.6001	.9259	.7716
21	.7373			.7716		.703	.7202
22	.7202	.6859	.583			.7202	
23	.703	.6173	.6173	.6001		.6859	.6173
24	.6516	.6859	.5487	.6173	.6001		.6001
Max	.8745	.823	.7545	.7888	.703	.9259	.7888
Min	.583	.5144	.4973	.4801	.4287	.4973	.5487
Avg	.6944	.6792	.6299	.6398	.5870	.7133	.6712

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224001 / 33/11 KV Sec-27 Kharghar S/S

Feeder No / Name : 208 / 11KV Station Transformer SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0171				
2	.0171			.0171			
3			.0171		.0171		
4	.0171			.0171			
6	.0171		.0171	.0171	.0171	.0171	
7		.0171	.0171		.0171	.0171	.0171
8	.0171	.0171	.0171	.0171	.0171	.0171	
9		.0171	.0171	.0171	.0171	.0171	.0171
10		.0171	.0343	.0171	.0171	.0171	
11	.0171	.0171		.0171	.0171	.0171	.0171
12	.0171	.0171	.0171	.0171	.0171		.0171
13		.0171			.0171	.0171	.0171
14	.0171	.0171	.0171	.0171	.0171		.0171
15	.0171	.0171		.0171	.0171	.0171	.0171
16		.0171	.0152		.0171		.0171
17	.0171	.0171		.0171	.0171	.0171	
18	.0171	.0171	.0171	.0171	.0171	.0171	.0171
19	.0171	.0171		.0171	.0171	.0171	
20	.0171	.0171	.0171	.0171	.0171	.0171	.0171
21	.0171			.0171		.0171	.0171
22	.0171	.0171	.0171			.0171	
23	.0171	.0171	.0171	.0171		.0171	.0171
24	.0171		.0171	.0171	.0171		.0171
Max	.0171	.0171	.0343	.0171	.0171	.0171	.0171
Min	.0171	.0171	.0152	.0171	.0171	.0171	.0171
Avg	.0171	.0171	.0181	.0171	.0171	.0171	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224001 / 33/11 KV Sec-27 Kharghar S/S

Feeder No / Name : 212 / 11 kv Ramsheth thakur SHEDDABLE URBAN
 feeder Feeder KV- 11 /
 OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0171				
2	.0171			.0171			
3			.0171		.0171		
4	.0171			.0171			
6	.0171	.0171	.0171	.0171	.0171	.0171	
7		.0171	.0171		.0171	.0171	.0171
8	.0171	.0171	.0171	.0171	.0171	.0171	
9		.0171	.0171	.0171	.0171	.0171	.0171
10		.0171	.0171	.0171	.0171	.0171	
11	.0171	.0171		.0171	.0171	.0171	.0171
12	.0171	.0171	.0171	.0171	.0171		.0171
13		.0171			.0171	.0171	.0171
14	.0171	.0171	.0171	.0171	.0171		.0171
15	.0171	.0171		.0171	.0171	.0171	.0171
16		.0171	.0171		.0171		.0171
17	.0171	.0171		.0171	.0171	.0171	.0171
18	.0171	.0171	.0171	.0171	.0171	.0171	.0171
19	.0171	.0171		.0171	.0171	.0171	
20	.0171	.0171	.0171	.0171	.0171	.0171	.0171
21	.0171			.0171		.0171	.0171
22	.0171	.0171	.0171			.0171	
23	.0171	.0171	.0171	.0171		.0171	.0171
24	.0171	.0171	.0171	.0171	.0171		.0171
Max	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Min	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Avg	.0171	.0171	.0171	.0171	.0171	.0171	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224001 / 33/11 KV Sec-27 Kharghar S/S

Feeder No / Name : 402 / 33KV Incomer No-II

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6687				
2	.5658			.463			
3			.6173		.2058		
4	.6173			.5144			
6	.6173	.7202	.7202	.5658	.1543	.463	
7		.7716	.7716		.4115	.4115	.7716
8	.6687	.7716	.6173	.6173	.6687	.5658	
9	.6687	.7716	.7202	.5658	.463	.6173	.6687
10		.7716	.7716	.5144	.5658	.7716	
11	.8745	.7202		.8745	.5658	.7716	.6687
12	.6687	.6687	.823	.7716	.6173		.6173
13		.6687			.5144	.6687	.6173
14	.6687	.7716	.7716	.7716	.5658		.5658
15	.6687	.5658		.6687	.5144	.5144	.6173
16		.6687	.823		.5658		.6173
17	.7202	.6687		.6173	.5144	.6687	.7202
18	.823	.7202	.823	.8745	.6687	.7716	.7202
19	.9259	.5658		.5658	.6687	.9259	
20	.8745	.8745	.7716	.7716	.6173	.9259	.7202
21	.7716			.7716		.7202	.7716
22	.7716	.7716	.6687			.7202	
23	.7202	.6173	.5658	.6687		.6687	.6173
24	.6687	.7202	.6173	.6173	.6687		.6173
Max	.9259	.8745	.823	.8745	.6687	.9259	.7716
Min	.5658	.5658	.5658	.463	.1543	.4115	.5658
Avg	.7232	.7116	.7167	.6596	.5265	.6790	.6651

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224008 / 33 /11 KV KHARGHAR SEC-12

S/ST

Feeder No / Name : 201 / 11 KV RAIL VIHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3443	1.307	1.2136	1.251		1.1763	
2	1.2696	1.1203	1.1576	1.2136		1.1576	
3	1.2323	1.1203	1.1203	1.1389		1.1576	
4	1.1949	1.307	1.1016	1.1203		1.1389	
5	1.2136	1.4937	1.1576	1.1389		1.1576	
6	1.3443	1.6804	1.251	1.1949			
7	1.7364	1.7551		1.251		1.4563	
8	1.8671	1.8671	1.6991	1.5497		1.6244	
9	1.7924		1.7177		1.6617		1.6991
10	1.6804		1.7177			1.6804	1.587
11	1.7551		1.643			1.4563	1.6991
12	1.643		1.6057			1.4563	1.7551
13	1.587		1.6057			1.4563	1.6057
14	1.531		1.419			1.4563	1.419
15	1.419	1.3443	1.4003			1.4563	1.419
16	1.4377	1.307	1.3443			1.3443	1.419
17		1.3817	1.4563			1.3256	1.5123
18		1.643	1.5684			1.4937	1.7177
19		1.8858	2.0351			1.4937	1.8484
20		1.8858	2.0165			1.643	2.2032
21		1.9044	1.9605			1.8484	2.2032
22		1.7177	1.8111			1.6804	1.9418
23		1.5497	1.5123		1.5497	1.5497	1.6991
24	1.475	1.4937	1.3443	1.3256		1.3256	1.419
Max	1.8671	1.9044	2.0351	1.5497	1.6617	1.8484	2.2032
Min	1.1949	1.1203	1.1016	1.1203	1.5497	1.1389	1.419
Avg	1.5014	1.5424	1.5156	1.2427	1.6057	1.4334	1.6967

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224008 / 33 /11 KV KHARGHAR SEC-12

S/ST

Feeder No / Name : 204 / 11KV LINK LINE FEEDER

SHEDDABLE URBAN

(Vighnah Feeder KV- 11 /
OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3443	1.307	1.2136	1.251		1.1763	
2	1.2696	1.1203	1.1203			1.1576	
3	1.2323	1.1203	1.0829	1.2136		1.1576	
4	1.1949	1.4937	1.0642	1.1203		1.1389	
5	1.2136	1.4937	1.1203	1.1389		1.1576	
6	1.3443	1.6804	1.2136	1.1949		1.2696	
7	1.7364	1.7551	1.475	1.251		1.4563	
8	1.8671	1.8671	1.6991	1.5497		1.6244	
9	1.7924		1.7177		1.6617		1.6991
10	1.6804		1.7177		1.6804		1.587
11	1.7551		1.6057		1.6617		1.6991
12	1.643		1.6057		1.5497		1.7551
13	1.587		1.6057		1.475		1.6057
14	1.531		1.419		1.3443		1.419
15	1.419	1.3443	1.4003		1.3443		1.419
16	1.4377	1.307	1.3443		1.363		1.419
17		1.3817	1.4563		1.4377		1.531
18		1.643	1.5684		1.4937		1.7177
19		1.8858	2.0351		1.9418		1.8484
20		1.8858	2.0165		2.0165		2.2032
21		1.9044	1.9605		2.0165		2.2032
22		1.7177	1.8111		1.7737		1.9418
23		1.5497	1.5123		1.5497		1.6991
24	1.475	1.4937	1.3443	1.3256		1.3256	
Max	1.8671	1.9044	2.0351	1.5497	2.0165	1.6244	2.2032
Min	1.1949	1.1203	1.0642	1.1203	1.3443	1.1389	1.419
Avg	1.5014	1.5528	1.5046	1.2556	1.6206	1.2738	1.7165

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224008 / 33 /11 KV KHARGHAR SEC-12

S/ST

Feeder No / Name : 206 / 11 KV HIRANANDANI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	13-FEB-18
HR	Load (MW)
24	.0181
Max	.0181
Min	.0181
Avg	.0181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224008 / 33 /11 KV KHARGHAR SEC-12

S/ST

Feeder No / Name : 207 / 11 KV MILLANIUM PARK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.086	1.1203	.9955	.9955		.9774	
2	1.0498	1.0456	.9593	.905			
3	.9955	1.0082	.905	.8326		.9231	
4	.9896	1.0829	.9335	.8326		.8869	
5	.9593	1.1203	.9412	.8688		.9231	
6	1.1946	1.307	.9774	.9955		1.0317	
7	1.5023	1.5684	1.1584	1.0679		1.3032	
8	1.5384	1.6617	1.3575	1.2489		1.4299	
9	1.5023		1.4842		1.448		1.448
10	1.5746		1.5384		1.475		1.4299
11	1.5023		1.448		1.4299		1.419
12	1.4661		1.4842		1.307		1.4118
13	1.3756		1.3394		1.307		1.3213
14	1.363		1.2851		1.1403		1.2308
15	1.307	1.2308	1.1946		1.1584		1.1946
16	1.307	1.1765	1.1584		1.1765		1.1403
17		1.2308	1.2489		1.1946		1.2127
18		1.4118	1.3575		1.3394		1.3937
19		1.4842	1.5746		1.5203		1.5023
20		1.4661	1.6244		1.531		1.6289
21		1.4661	1.5565		1.5023		1.6651
22		1.3756	1.4661		1.3394		1.5203
23		1.2308	1.267		1.2308		1.4118
24	1.267	1.2696	1.1222	1.0498		1.0498	
Max	1.5746	1.6617	1.6244	1.2489	1.531	1.4299	1.6651
Min	.9593	1.0082	.905	.8326	1.1403	.8869	1.1403
Avg	1.2930	1.2920	1.2657	.9774	1.3400	1.0656	1.3954

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224008 / 33 /11 KV KHARGHAR SEC-12

S/ST

Feeder No / Name : 208 / SUB STATION T/F

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0225	.0236		.0225		.0225	
2	.0225	.0236	.0225	.0225			
3	.0225	.0236	.0225				
4	.0225	.0236					
5	.0225	.0236				.0225	
6	.0225	.0236				.0225	
7	.0112	.0236		.0112			
8	.0112	.0236	.0112	.0112		.0225	
9	.0112		.0112		.0112		.0112
10	.0112						.0225
11	.0225						.0225
12	.0225				.0225	.0221	
13	.0225				.0225	.0225	
14			.0112				
15	.0225	.0221	.0112				
16	.0225	.0221					.0225
17		.0221					.0225
18		.0221			.0225		
19		.0221			.0225		
20		.0221	.0225				
21		.0221	.0225				
22		.0221					
23		.0221	.0225		.0225		.0225
24	.0225	.0236				.0225	
Max	.0225	.0236	.0225	.0225	.0225	.0225	.0225
Min	.0112	.0221	.0112	.0112	.0112	.0221	.0112
Avg	.0197	.0229	.0175	.0169	.0206	.0224	.0206

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 201 / Spare Link feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3575		1.267	1.3575		1.267	1.1765
2		1.267			1.086		1.086
3	1.1765		1.086	1.1765		1.086	.9955
4		1.1765			1.086		1.086
5	1.1765		1.086	1.1765		1.1765	1.1765
6		1.448			1.448		1.3575
7	1.8099		1.448	1.448		1.6289	1.8099
8		1.8099			1.9909		
9	1.9004		1.8099	1.6289		1.9909	1.8099
10		1.7194			1.8099		
11	1.8099		1.8099	1.8099		1.8099	1.6289
12		1.6289			1.3575		
13	1.6289		1.6289	1.6289		1.448	1.6289
14		1.267			1.267		
15	1.448		1.448	1.448			1.448
16		1.448	1.267	1.267	1.267	1.3575	1.448
17	1.448		1.448	1.448	1.267	1.267	1.448
18		1.448	1.6289	1.6289	1.448	1.448	1.6289
19	1.8099		1.9909	1.8099	1.7194	1.8099	1.9909
20		1.8099	1.8099	1.8099	1.8099	1.8099	1.9909
21	1.8099		1.8099	1.8099	1.8099	1.8099	1.9909
22			1.6289	1.8099	1.8099	1.8099	1.9909
23	1.7194	1.6289	1.5384	1.6289	1.6289	1.448	1.8099
24	1.3575	1.6289	1.448	1.448	1.448	1.448	1.448
Max	1.9004	1.8099	1.9909	1.8099	1.9909	1.9909	1.9909
Min	1.1765	1.1765	1.086	1.1765	1.086	1.086	.9955
Avg	1.5733	1.5234	1.5384	1.5491	1.5158	1.5385	1.5475

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 202 / 11 KV PUMP HOUSE SEC 11

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4525		.362	.362		.362	.362
2		.2715			.362		.362
3			.362	.362		.362	.362
4		.362			.362		.362
5			.362	.6335		.362	.4525
6		.362			.543		.6335
7	.724		.724			.6335	.724
8		.724					
9	.724		.362	.724		.724	.724
10		1.086			.724		
11	1.086		.4525	.724		.724	.8145
12		.905			.724		
13	.724		.6335	.905		.724	.724
14		.905			.724		
15	.724		.6335	.905			.724
16		.724	.724	.724	.724	.543	.724
17	.905		.8145	.724	.724	.543	.724
18		.905	.8145	.724	.724	.8145	.724
19	.724		.724	.724	.724	.724	.724
20		.905	.724	.724	.724	.724	.724
21	.724		.724	.724	.724	.724	.724
22			.724	.724	.724	.6335	.724
23	.6335	.724	.543	.724	.5601	.543	.724
24	.4525	.362	.362	.362	.362	.362	.362
Max	1.086	1.086	.8145	.905	.724	.8145	.8145
Min	.4525	.2715	.362	.362	.362	.362	.362
Avg	.7158	.6863	.5909	.6731	.6286	.5939	.6199

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 203 / 11 KV MURBI SECTOR-19

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4525		.543	.724		.6335	.6335
2		.6335			.4525		.6335
3			.4525	.6335		.4525	.543
4		.6878			.4525		.6335
5			.543	.543		.543	.724
6		.724			.724		.8145
7			.905	.724		.905	1.1765
8		.9955			1.1765		
9	1.267		1.086	1.086		1.086	1.086
10		.9955			1.086		
11	1.086		1.086	1.086		1.086	1.086
12		.9955			.905		
13	.905		.905	.905		.905	.905
14		.8145			.724		
15	.8145		.8145	.724			.8145
16		.724	.724	.724	.724	.6335	.724
17	.8145		.724	.724	.724	.724	.724
18		.8145	.8145	.8145	.724	.905	.905
19	.9955		.9955	.9955	.905	.905	1.086
20		.9955	.905	.9955	.905	.905	1.086
21	.9955		.905	.905	.905	.905	.9955
22			.905	.905	.905	.6335	.9955
23	.905	.8145	.8145	.8145	.8145	.8145	.905
24	.8402	.8145	.724	.724	.724	.724	.724
Max	1.267	.9955	1.086	1.086	1.1765	1.086	1.1765
Min	.4525	.6335	.4525	.543	.4525	.4525	.543
Avg	.9076	.8341	.8145	.8251	.8032	.7975	.8598

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 206 / 11 KV AWHO SECTOR-14

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1765		.9955	1.086		.9955	.9955
2		.9955			.724		.905
3	.9955		.724	.905		.8145	.8145
4		.9955			.8145		.905
5	1.1765		.724	.9955		.905	.9955
6		1.267			1.086		1.086
7	1.5384		1.086	1.1765		1.3575	1.6289
8		1.5384			1.448		
9	1.448		1.448	1.448		1.6289	1.448
10		1.5384			1.448		
11	1.448		1.6289	1.448		1.448	1.448
12		1.3575			1.3575		
13	1.3575		1.3575	1.448		1.267	1.267
14		1.1765			1.086		
15	1.1765		1.267	1.448			1.267
16		1.1765	1.267	1.267	1.086	1.1765	1.267
17	1.1765		1.3575	1.267	1.267	1.267	1.267
18		1.448	1.448	1.448	1.448	1.6289	1.448
19	1.8099		1.7194	1.6289	1.6289	1.6289	1.7194
20		1.448	1.6289	1.6289	1.6289	1.6289	1.7194
21	1.6289		1.5384	1.5384	1.6289	1.6289	1.7194
22			1.267	1.3575	1.448	1.448	1.5384
23	1.267	1.267	1.267	1.1765	1.267	1.0974	1.267
24	1.267	1.086	1.1765	1.086	1.086	1.086	1.086
Max	1.8099	1.5384	1.7194	1.6289	1.6289	1.6289	1.7194
Min	.9955	.9955	.724	.905	.724	.8145	.8145
Avg	1.3436	1.2745	1.2883	1.3149	1.2783	1.3129	1.2896

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 207 / VISHWAJYOTH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724		.543	.724		.543	.6335
2		.6335			.4525		.6335
3	.543		.4525	.543		.4525	.543
4		.6335			.4525		.6335
5	.724		.4525	.543		.543	.6335
6		.724			.724		.724
7	.905		.724	.6335		.8145	.905
8		.905			.9955		
9	.9955		.9955	.905		.905	.905
10		.905			.905		
11	.8145		.9955	.9955		.905	.8145
12		.8145			.724		
13	.8145		.8145	.905		.8145	.8145
14		.724			.724		
15	.724		.724	.8145			.724
16		.724	.724	.724	.724	.6335	.724
17	.724		.8145	.724	.724	.6335	.724
18		.8145	.905	.8145	.724	.8145	.8145
19	.905		.9955	.905	.905	.905	.905
20		.905	.905	.905	.905	.905	.905
21	.905		.8145	.8145	.905	.905	.905
22			.8145	.8145	.8145	.8145	.905
23	.724	.8145	.8145	.724	.8145	.724	.8145
24	.724	.724	.724	.724	.724	.724	.724
Max	.9955	.905	.9955	.9955	.9955	.905	.905
Min	.543	.6335	.4525	.543	.4525	.4525	.543
Avg	.7867	.7768	.7772	.7772	.7636	.7523	.7693

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 208 / 11 KV JALVAYU SECTOR-20

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9955		.724	.8145		.6335	.724
2		.8145			.724		.724
3	.8145		.724	.6335		.6335	.6335
4		.905			.724		.6335
5	.9955		.724	.6335		.724	.724
6		.9955			.9955		.905
7	1.448		1.086	.905		1.267	1.3575
8		1.3575			1.267		
9	1.448		1.267	.905		1.448	1.267
10		1.086	1.267		1.448		
11	1.267		1.1765	.905		1.267	1.267
12		1.086	1.086		1.448		
13	1.086		1.267	.905		1.086	1.086
14		1.086			.905		
15	1.086		1.086	1.086			1.086
16		.905	1.086	.905	.905	.905	1.086
17	1.086		1.1765	.905	.905	.9955	1.086
18		1.086	1.267	1.086	1.086	1.086	1.1765
19	1.448		1.448	1.267	1.267	1.3575	1.448
20		1.267	1.5384	1.3575	1.267	1.267	1.448
21	1.448		1.3575	1.267	1.267	1.267	1.267
22			1.1765	1.267	1.086	1.086	1.267
23	1.086	1.086	1.086	1.086	.905	.8145	1.086
24	1.086	.9955	.905	.905	.905	.724	.8145
Max	1.448	1.3575	1.5384	1.3575	1.448	1.448	1.448
Min	.8145	.8145	.724	.6335	.724	.6335	.6335
Avg	1.1765	1.0558	1.1289	.9902	1.0690	1.0351	1.0543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 209 / 11 kV \sector 18

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8145		.724			.6335	.724
2		.724			.543		.724
3	.724		.6335	.6335		.543	.6335
4		.724			.543		.724
5	.8145		.6335	.6335		.6335	.724
6		.8145			.905		.905
7	1.3575		.9955			1.086	1.267
8		1.267			1.1765		
9	1.1765		1.1765	.9955		1.267	1.086
10		1.086			1.086		
11	1.086		1.086	1.086		1.086	.9955
12		.905			.905		
13	.905		.9955	1.086		.8145	.905
14		.724			.724		
15	.724		.6335	.905			.724
16		.6335	.6335	.724	.724	.724	.8145
17	.724		.8145	.724	.724	.724	.8145
18		.8145	.905	.8145	.724	.905	.905
19	.9955		.9955	.9955	.905	.9955	.9955
20		1.086	.905	.9955	.905	.9955	1.086
21	1.086		.905	.905	.905	.9955	1.086
22			.905	.905	.905	.9955	1.086
23	.9955	.9955	.905	.905	.8145	.8145	.9955
24	.905	.905	.905	.8145	.8145	.724	.8145
Max	1.3575	1.267	1.1765	1.086	1.1765	1.267	1.267
Min	.724	.6335	.6335	.6335	.543	.543	.6335
Avg	.9468	.8899	.8677	.8748	.8315	.8711	.9005

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 210 / 11 kV \ Vastuvihar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905		.0905	.0905		.0905	.0905
2		.0905			.0905		.0905
3	.0905		.0905	.0905		.0905	.0905
4		.0905			.0905		.0905
5	.0905		.0905	.0905		.0905	.0905
6		.0905			.0905		.0905
7	.0905		.0905	.0905		.0905	.0905
8		.0905			.0905		
9	.0905		.0905	.0905		.0905	.0905
10		.0905			.0905		
11	.0905		.0905	.0905		.0905	.0905
12		.0905			.0905		
13	.0905		.0905	.0905		.0905	.0905
14		.0905			.0905		
15	.0905		.0905	.0905			.0905
16		.0905	.0905	.0905	.0905	.0905	.0905
17	.0905		.0905	.0905	.0905	.0905	.0905
18		.0905	.0905	.0905	.0905	.0905	.0905
19	.0905		.0905	.0905	.0905	.0905	.0905
20		.0905	.0905	.0905	.0905	.0905	.0905
21	.0905		.0905	.0905	.0905	.0905	.0905
22				.0905	.0905	.0905	.0905
23	.0905	.0905	.0905	.0905	.0905	.0905	.0905
24	.0905	.0905	.0905	.0905	.0905	.0905	.0905
Max	.0905	.0905	.0905	.0905	.0905	.0905	.0905
Min	.0905	.0905	.0905	.0905	.0905	.0905	.0905
Avg	.0905	.0905	.0905	.0905	.0905	.0905	.0905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 211 / 11 kV Sector 27

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181		.181	.181		.181	.181
2		.181			.181		.181
3	.181		.181	.181		.181	.181
4		.181			.181		.181
5	.181		.181	.181		.181	.181
6		.2715			.2715		.2715
7	.2715		.181	.181		.2715	.2715
8		.2715			.362		
9	.2715		.181	.181		.2715	.2715
10		.2715			.3258		
11	.2715		.181	.181		.2715	.181
12		.2715			.181		
13	.181		.181	.181		.181	.181
14		.181			.181		
15	.181		.181	.181			.181
16		.181	.181	.181	.181	.181	.181
17	.181		.181	.181		.2715	.2715
18		.2715	.181	.2715	.2715	.2715	.362
19	.2715		.2715	.2715		.181	.362
20		.2715	.2715	.2715	.2715	.181	.2715
21	.2715		.181	.2715		.2715	.2715
22			.181	.2715	.2715	.181	.2715
23	.2715	.2715	.181	.2715		.181	.2715
24	.181	.2715	.2715	.181	.181	.2715	.181
Max	.2715	.2715	.2715	.2715	.362	.2715	.362
Min	.181	.181	.181	.181	.181	.181	.181
Avg	.2228	.2413	.1970	.2129	.2383	.2206	.2353

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 201 / 11 kv CIDCO Sewrage Pump SHEDDABLE URBAN
Secto Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.1763			1.1949	
2			1.1576			1.1576	
3			1.1203			1.1203	
4			1.1203			1.1203	
5			1.1203			1.1576	
6			1.1576			1.2136	
7			1.1763			1.251	
8	1.3256		1.1763	1.1576		1.2883	1.3817
9	1.4003		1.2696	1.2696		1.2696	1.2696
10		1.475	1.6244		1.4563	1.4563	
11		1.587	1.475		1.531	1.5123	
12		1.6617	1.4377		1.6057	1.5123	
13		1.643	1.475		1.5684	1.531	
14		1.6057	1.4937		1.4937	1.475	
15		1.587	1.4377		1.4563	1.251	
16		1.587	1.3817		1.419	1.2696	
17		1.5684			1.363	1.2883	
18		1.6804	1.6804		1.5684	1.363	
19		1.7737	1.8111		1.7551	1.6804	
20		1.6804	1.7364		1.6244	1.643	
21		1.4937	1.6617		1.5497	1.587	
22		1.4003			1.3443	1.4003	
23		1.2696	1.251		1.2696	1.2136	
24	1.1949	.9774	1.2136	1.1016	.9774	1.2136	1.0456
Max	1.4003	1.7737	1.8111	1.2696	1.7551	1.6804	1.3817
Min	1.1949	.9774	1.1203	1.1016	.9774	1.1203	1.0456
Avg	1.3069	1.5327	1.3706	1.1763	1.4655	1.3404	1.2323

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 202 / 11 KV CIDCO S/STN SEC-10

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5601			.4854	
2			.5601			.4668	
3						.4668	
4			.5601			.4668	
5			.5601			.5228	
6			.5975			.5788	
7			.6161			.6348	
8	.8215		.6161	.5228		.6722	.7282
9	.7468		.6908	.5975		.7655	.7282
10		.6348	.6535		.6908	.6161	
11		.5601	.5975		.6348	.6161	
12		.5228	.5415		.5415	.5975	
13		.4854	.5975		.5228	.5041	
14		.4668	.4854		.4854	.4294	
15		.4668	.5228		.4481	.5041	
16		.4668	.5041		.4854	.4668	
17		.4668			.5228	.5041	
18		.5601	.6722		.6161	.5975	
19		.6722	.7095		.6908	.6722	
20		.6535	.6535		.6348	.6722	
21		.6535	.6908		.5975	.6161	
22						.6535	
23		.6535	.5975		.5601	.5601	
24	.6161	.5316	.5975	.5415	.5144	.5228	.5415
Max	.8215	.6722	.7095	.5975	.6908	.7655	.7282
Min	.6161	.4668	.4854	.5228	.4481	.4294	.5415
Avg	.7281	.5568	.5992	.5539	.5675	.5664	.6660

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 203 / 11KV CIDCO Sec-2 Kharghar SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.7468			.8589	
2			.7095			.8215	
3			.6722			.7842	
4			.6535			.7468	
5			.6535			.7095	
6			.6722			.7095	
7			.6722			.6908	
8	.8029		.6908	.6535		.6908	.7282
9	.8029		.8775	.9335		.7655	.8029
10		.8962	.8775		.9335	.9896	
11		1.2323	1.3256		1.1203	1.3443	
12		1.4563	1.3817		1.3256	1.3817	
13		1.3817	1.2323		1.2323	1.0829	
14		1.307	1.307		1.1203	1.2696	
15		1.2136	1.1389		1.0456	1.1203	
16		1.1576	1.3256		1.0829	1.1949	
17		1.0829			1.1389	1.1763	
18		1.2136	1.307		1.2323	1.2323	
19		1.419	1.587		1.3817	1.419	
20			1.4003		1.1949	1.4003	
21		1.3443	1.363		1.1203	1.0082	
22		.9522			.9522		
23		.8402	.8215		.9335	.8402	
24	.7842	.6516	.7842	.7468	.6687	.8962	.6908
Max	.8029	1.4563	1.587	.9335	1.3817	1.419	.8029
Min	.7842	.6516	.6535	.6535	.6687	.6908	.6908
Avg	.7967	1.1535	1.0091	.7779	1.0989	1.0058	.7406

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 204 / 11 KV Prajapati S/stn Sec- SHEDDABLE URBAN
2 kh Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.9335			.8589	
2			.9335			.8402	
3			.9335			.8402	
4			.9335			.8402	
5			.9896			.9335	
6			1.0456			1.0269	
7			1.1203			1.1203	
8	1.2696		1.2136	1.0269		1.2136	1.2696
9	1.307		1.3817	1.1949		1.2696	1.4003
10		1.2136	1.2323		1.2323	1.2696	
11		1.1203	1.1949		1.1576	1.1389	
12		.9896	.9896		1.0642	1.0082	
13		.9709	1.0269		1.0269	.9522	
14		.9335	.8962		.9335	.8589	
15		.9335	.8962		.8589	.8029	
16		.9335	.8775		.9335	.7842	
17		.9149			1.0456	.8589	
18		1.0082	1.0082		1.1016	.9709	
19		1.1389	1.2136		1.1576	1.1016	
20		1.1203	1.251		1.1389	.7655	
21		1.0829	1.1203		1.1203	1.2323	
22		1.0456			.9896	1.1016	
23		1.0082	.9709		.9522	.9709	
24	.8775	.8059	.9709	.8962	.7716	.8962	.8589
Max	1.307	1.2136	1.3817	1.1949	1.2323	1.2696	1.4003
Min	.8775	.8059	.8775	.8962	.7716	.7655	.8589
Avg	1.1514	1.0147	1.0515	1.0393	1.0323	.9857	1.1763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 205 / 11 KV Railway station
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0747			.0934	
2			.056			.0747	
3			.056			.0747	
4			.056			.0747	
5			.056			.0747	
6			.056			.0747	
7			.056			.0747	
8	.0747		.0747	.0747		.0934	.0747
9	.1307		.0747	.0747		.0747	.112
10		.112	.0934		.0934	.0747	
11		.1307	.112		.0934	.112	
12		.1307	.112		.112	.112	
13		.1307	.1307		.112	.112	
14		.1307	.1307		.0934	.112	
15		.112	.1494		.0934	.1307	
16		.112	.112		.0934	.0934	
17		.112			.0934		
18		.1307	.0934		.1307	.0747	
19		.168	.2054		.1867	.168	
20		.168	.2054		.1867	.2054	
21		.1867	.1867		.2054	.168	
22		.1867			.2054	.168	
23		.1494	.1867		.1867	.168	
24	.1494	.12	.112	.1307	.1372	.1494	.1494
Max	.1494	.1867	.2054	.1307	.2054	.2054	.1494
Min	.0747	.112	.056	.0747	.0934	.0747	.0747
Avg	.1183	.1387	.1086	.0934	.1349	.1112	.1120

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 206 / SUB STATION T/F

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	09-FEB-18	10-FEB-18	12-FEB-18	13-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0187		.0187
2		.0187		.0187
3		.0187		.0187
4		.0187		.0187
5		.0187		.0187
6		.0187		.0187
7		.0187		.0187
8		.0187		.0187
9		.0187		.0187
10	.0187		.0187	
11	.0187		.0187	
12	.0187		.0187	
13	.0187		.0187	
14	.0187		.0187	
15			.0187	
16	.0187		.0187	
17	.0187		.0187	
18			.0187	
19	.0187		.0187	
20	.0187		.0187	
21	.0187		.0187	
22	.0187		.0187	
23			.0187	
24		.0187		.0187
Max	.0187	.0187	.0187	.0187
Min	.0187	.0187	.0187	.0187
Avg	.0187	.0187	.0187	.0187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 207 / 11 KV Glow Max

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0373			.0373	
2			.0373			.0373	
3			.0373			.0373	
4			.0373			.0373	
5			.0373			.0373	
6			.0373			.0373	
7			.0747			.0373	
8	.0373		.1307	.168		.0373	.0373
9	.1307		.1494	.1307		.1307	.1494
10		.1867	.1867		.1867	.2054	
11		.2241	.2614		.2427	.2427	
12		.2614	.2801		.2987	.2614	
13		.2614	.2801		.2614	.2801	
14		.2614	.2427		.2801	.2801	
15		.2614	.2801		.2427	.2801	
16		.2614	.2801		.2614	.2801	
17		.2614			.2614	.2614	
18		.2801	.2801		.2801	.2614	
19		.2801	.2987		.2801	.3174	
20		.2614	.2801		.2614	.2614	
21		.2241	.2614		.2614	.2614	
22		.2241			.2614	.2614	
23		.2054	.2427		.1867	.1867	
24	.1867	.1372	.1494	.2054	.1715	.1494	.1494
Max	.1867	.2801	.2987	.2054	.2987	.3174	.1494
Min	.0373	.1372	.0373	.1307	.1715	.0373	.0373
Avg	.1182	.2394	.1774	.1680	.2492	.1758	.1120

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 208 / 11 KV Balaji Angan

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.3817			1.4563	
2			1.3443			1.4377	
3			1.307			1.4377	
4			1.307			1.4937	
5			1.4003			1.587	
6			1.4937			1.6804	
7			1.6804			1.7551	
8	2.0538		1.7924	1.3817		1.7924	1.8298
9	2.3899		2.0165	1.643		2.3525	2.0911
10		2.3899	2.0165		2.2032	2.0911	
11		2.3525	2.0165		2.2405	2.0165	
12		2.3525	1.9044		2.2779	1.8298	
13		2.2405	1.8671		2.2405	1.7924	
14		2.0538	1.6057		2.0538	1.6057	
15			1.643		1.9044	1.643	
16		1.8671	1.5684		1.8298	1.643	
17		1.643			1.6804	1.419	
18		1.7177	1.4937		1.7177	1.4937	
19		1.8298	1.7177		1.7924	1.7177	
20		1.7551	1.6804		1.643	1.6804	
21		1.6804	1.6804		1.6057	1.7177	
22					1.5684	1.5684	
23		1.4937	1.419		1.531	1.3817	
24	1.475	1.2689	1.419	1.307	1.2003	1.4937	1.2696
Max	2.3899	2.3899	2.0165	1.643	2.2779	2.3525	2.0911
Min	1.475	1.2689	1.307	1.307	1.2003	1.3817	1.2696
Avg	1.9729	1.8958	1.6252	1.4439	1.8326	1.6703	1.7302

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 209 / 11kV NIFT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0187			.0187	
2			.0187			.0187	
3			.0187			.0187	
4			.0187			.0187	
5			.0187			.0187	
6			.0187			.0187	
7			.0187			.0187	
8	.0187		.0187	.0187		.0187	.0187
9	.0187		.0187	.0187		.0187	.0187
10		.0187	.0187		.0187	.0187	
11		.0187			.0187		
12		.0187			.0187		
13		.0187	.0187				
14		.0187				.0187	
15		.0187					
16		.0187					
17		.0187					
18		.0187	.0187		.0187		
19		.0187			.0187	.0187	
20		.0187			.0187		
21		.0187			.0187		
22		.0187			.0187		
23		.0187	.0187		.0187	.0187	
24	.0187	.0171	.0187	.0187	.0171	.0187	.0187
Max	.0187	.0187	.0187	.0187	.0187	.0187	.0187
Min	.0187	.0171	.0187	.0187	.0171	.0187	.0187
Avg	.0187	.0186	.0187	.0187	.0185	.0187	.0187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 210 / 11kV outgoing feeder 10

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.1576			1.1576	
2			1.1203			1.1203	
3			1.1203			1.1203	
4			1.1203			1.1203	
5			1.1763			1.1949	
6			1.2136			1.2696	
7			1.251			1.363	
8	1.4937		1.2883	1.1949		1.4563	1.5497
9	1.4937		1.4377	1.307		1.531	1.587
10		1.3817	1.307		1.4003	1.363	
11		1.307	1.3817		1.0642	1.475	
12		1.1763	1.2883		1.0642	1.1763	
13		1.1949	1.2323		1.0456	1.1949	
14		1.2323	1.0829		1.0082	1.0269	
15		1.2696	1.0829		.9709	.9149	
16		1.307	1.1389		1.0269	.9335	
17		1.307			1.1016	1.0269	
18		1.363	1.2323		1.2136	1.1949	
19		1.419	1.3443		1.3443	1.4003	
20		1.3817	1.3443		1.3817	1.3256	
21			1.2696		1.3443	1.3443	
22		1.2883			1.2883	1.3256	
23		1.251	1.2136		1.2323	1.1949	
24	.7468	1.0631	1.1949	1.1389	1.046	1.1763	1.1203
Max	1.4937	1.419	1.4377	1.307	1.4003	1.531	1.587
Min	.7468	1.0631	1.0829	1.1389	.9709	.9149	1.1203
Avg	1.2447	1.2816	1.2272	1.2136	1.1688	1.2253	1.419

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 211 / 11 KV S N Park

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6722			.6722	
2			.6348			.6348	
3			.6535			.6348	
4			.6722			.6722	
5			.7282			.7282	
6			.7842			.8029	
7			.8402			.8962	
8	1.1016		.8962	.7655		.9709	1.0642
9	1.1203		.8962	.8589		.9149	1.0269
10		.8962	.8402		.8589	.8589	
11		.8402	.7842		.7468	.8029	
12		.8029	.8029		.6908	.8589	
13		.7655	.6908		.7095	.6722	
14		.7095	.6161		.7468	.6535	
15		.6722	.5601		.7468	.6161	
16		.6348	.6161		.7095	.5415	
17		.6161			.5975	.5975	
18		.6908	.6722		.6535	.6161	
19		.8029	.7842		.8029	.7655	
20		.7842	.8215		.7842	.8402	
21		.7842	.7842		.7842	.8029	
22		.7655			.7655	.8029	
23		.7282	.6908		.7282	.7095	
24	.7468	.6344	.6908	.6348	.583	.6908	.6348
Max	1.1203	.8962	.8962	.8589	.8589	.9709	1.0642
Min	.7468	.6161	.5601	.6348	.583	.5415	.6348
Avg	.9896	.7418	.7333	.7531	.7272	.7399	.9086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 212 / 11kV Siemens Express NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0187			.0187	
2			.0187			.0187	
3			.0187			.0187	
4			.0187			.0187	
5			.0187			.0187	
6			.0187			.0187	
7			.0187			.0373	
8	.2054		.1307	.0187		.168	.1307
9	.1307		.0373	.0187		.1867	.1307
10		.1307	.0373		.2241	.2054	
11		.1307	.0187		.2241	.1494	
12		.1494	.0373		.2241	.2801	
13		.1494	.0187		.2241	.2427	
14		.1307	.0373		.1867	.1307	
15		.112	.0373			.2054	
16		.0934	.0187		.1867	.2614	
17		.0747			.1867	.112	
18		.0747	.0187		.1494	.0747	
19		.056	.0187		.056	.0747	
20		.0373	.0187		.0373	.0747	
21		.0187	.0187		.0373	.0373	
22		.0187			.0373	.0373	
23		.0373	.0373		.0373	.0373	
24	.0373	.0343	.0187	.0187	.0171	.0187	.0373
Max	.2054	.1494	.1307	.0187	.2241	.2801	.1307
Min	.0373	.0187	.0187	.0187	.0171	.0187	.0373
Avg	.1245	.0832	.0289	.0187	.1306	.1019	.0996

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 213 / 11kV BPCL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0373			.0187	
2			.0373			.0187	
3			.0187			.0187	
4			.0187				
5			.0187			.0187	
6			.0187			.0187	
7			.0373			.0187	
8	.0373			.0373		.0747	.056
9	.168		.0373	.0187		.1494	.1494
10		.1494	.0373		.1867	.168	
11		.1494	.0373		.2054	.168	
12		.168	.056		.2054	.168	
13		.0934	.0187		.2241	.168	
14		.0934	.0373		.2614	.1867	
15		.0934	.0373		.2614	.2054	
16		.0934	.0373		.3361	.1307	
17		.0934			.2801	.1307	
18		.0747	.0373		.0747	.0747	
19			.0187		.0373	.0373	
20		.0373	.0373		.0373	.056	
21		.0373	.0373		.0187	.0373	
22		.0373			.0187	.0373	
23		.0373	.0187		.0187	.0187	
24	.0373	.0171	.0373	.0187	.0171	.0187	.0187
Max	.168	.168	.056	.0373	.3361	.2054	.1494
Min	.0373	.0171	.0187	.0187	.0171	.0187	.0187
Avg	.0809	.0839	.0320	.0249	.1455	.0844	.0747

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 201 / plot no 51 sec-30 feeder SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	1.8176	1.8858	1.6804	1.6461
Max	1.8176	1.8858	1.6804	1.6461
Min	1.8176	1.8858	1.6804	1.6461
Avg	1.8176	1.8858	1.6804	1.6461

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 202 / mass housing s/s no-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0514	.0709	.0709	.0514
Max	.0514	.0709	.0709	.0514
Min	.0514	.0709	.0709	.0514
Avg	.0514	.0709	.0709	.0514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 203 / LIG MASS HOUSING Feder SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.3258	.362	.3439	.3601
Max	.3258	.362	.3439	.3601
Min	.3258	.362	.3439	.3601
Avg	.3258	.362	.3439	.3601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 205 / pl no.42 & 43, sec-35D

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.1029	.1143	.0953	.0686
Max	.1029	.1143	.0953	.0686
Min	.1029	.1143	.0953	.0686
Avg	.1029	.1143	.0953	.0686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 206 / PLOT NO 53 & 54 STATUS SHEDDABLE URBAN
VIHAR S Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.463	.5041	.4481	.4287
Max	.463	.5041	.4481	.4287
Min	.463	.5041	.4481	.4287
Avg	.463	.5041	.4481	.4287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 207 / MASS HOUSING S/S NO.3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0686	.0754	.0754	.0686
Max	.0686	.0754	.0754	.0686
Min	.0686	.0754	.0754	.0686
Avg	.0686	.0754	.0754	.0686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 208 / pl no.171, sec-30 feeder SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	09-FEB-18	13-FEB-18
HR	Load (MW)	Load (MW)
24	.112	.112
Max	.112	.112
Min	.112	.112
Avg	.112	.112

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 210 / MASS HOUSING S/S NO.4

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.1029	.1267	.1267	.12
Max	.1029	.1267	.1267	.12
Min	.1029	.1267	.1267	.12
Avg	.1029	.1267	.1267	.12

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 211 / MASS HOUSING S/S NO.2
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-FEB-18	09-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
24	.0343	.0686	.0514
Max	.0343	.0686	.0514
Min	.0343	.0686	.0514
Avg	.0343	.0686	.0514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 212 / arihant abhilasha pl no-10

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	1.2346	1.3352	1.1523	1.406
Max	1.2346	1.3352	1.1523	1.406
Min	1.2346	1.3352	1.1523	1.406
Avg	1.2346	1.3352	1.1523	1.406

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 223001 / 22/22 KV BHINGARI SWITCHING
ST

Feeder No / Name : 302 / 22 KV PANVEL-I

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1605	2.1948	2.2405	1.6461	1.5775	1.5089	1.5775
2	2.1262	2.1262	2.1658	1.5775	1.5089	1.4403	1.5089
3	2.1948	2.0576	2.0911	1.3717	1.4403	1.3717	1.4403
4	2.332	2.0919	2.0911	1.5684	1.5775	1.4403	1.4746
5	2.4006	2.1262	2.1285	1.5775	1.6461	1.5089	1.5775
6	2.4348	2.1605	2.1658	1.6461	1.7833	1.5775	1.6804
7	2.4691	2.1605	2.1658	1.7924	1.7833	1.6118	1.9204
8	2.4691	2.4348	2.6139	1.9547	2.0233	2.0576	2.0233
9	2.572	2.4006	2.6886	2.1285	2.1285	2.0233	2.0919
10	2.6406	2.6063	2.6513	2.1658	2.1285	1.989	2.0919
11	3.2579	3.155	2.7633	2.2032	2.2779	1.2696	2.0576
12	3.2236	3.0178	2.2032	2.1285	2.1285	1.7924	2.0233
13	3.0864	2.8464	1.7147	2.0165	2.0538	1.6461	2.0233
14	3.0178	2.8121	1.7147	1.6804	1.7833	1.6118	1.989
15	3.2861	2.7435	1.7147		1.8176	1.7177	1.9547
16	3.1367	2.915	1.9547	1.5432	1.7833	1.6118	1.989
17	3.0247	2.6749	1.8519	1.4746	1.749	1.6118	1.989
18	2.8464	2.7092	1.9204	1.5775	1.8519	1.7833	1.989
19	3.8089	3.3265	2.4691	2.1948	2.2977	2.3663	2.4006
20	3.6595	3.3265	2.3663	2.1948	2.2977	2.2291	2.4348
21	3.5475	3.1207	2.2291	2.1605	2.1948	2.0919	2.4006
22	2.7778	3.062	2.0233	2.0233	1.9547	2.0576	2.1948
23	2.5377	2.6513	1.8519	1.8861	1.7833	1.8176	2.0233
24	2.2291	2.2291	2.3152	1.7147	1.6461	1.5775	1.6461
Max	3.8089	3.3265	2.7633	2.2032	2.2977	2.3663	2.4348
Min	2.1262	2.0576	1.7147	1.3717	1.4403	1.2696	1.4403
Avg	2.8017	2.6229	2.1706	1.8359	1.8840	1.7381	1.9376

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 223001 / 22/22 KV BHINGARI SWITCHING

ST

Feeder No / Name : 307 / Sainagar

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4691	2.4006	2.4646	2.1948	2.0919	2.1262	2.2291
2	2.4006	2.332	2.3899	2.0576	1.989	2.0576	2.0576
3	2.572	2.332	2.3152	1.989	1.8861	1.9204	1.8861
4	2.6063	2.2977	2.2405	2.0576	2.0576	1.9204	1.9547
5	2.7092	2.4006	2.3152	2.1262	2.2291	1.989	2.0919
6	2.8121	2.572	2.3899	2.1605	2.4006	2.0576	2.2634
7	2.8464	2.6063	2.4646	2.1262	2.4006	1.989	2.4691
8	2.8807	2.8121	2.8753	2.4691	2.7092	2.4691	2.8121
9	2.8121	2.8807	2.8753	2.9127	2.9938		2.7092
10	2.7778	2.8464	2.9127	3.1367	2.846	2.8464	2.6406
11	2.5034	2.5034	2.726	2.7633	2.6139		2.4006
12	2.2291	2.4006	2.4646	2.726	2.3525	2.3525	2.0919
13	2.0576	2.4691	1.8176	2.5393	2.2177	2.1262	1.989
14	2.2032	2.4006	1.8176	2.2405	2.1658	1.9204	1.9547
15	2.0911	1.8861	1.9547	2.5377	1.7833	2.1658	1.989
16	2.0911	1.8861	1.7833	1.8861	1.8176	1.7833	1.8176
17	2.1285	1.8176	1.9204	1.9547	1.8176	1.6804	1.9204
18	2.2291	2.2291	1.9547	2.0233	1.9204	2.0538	2.1948
19	2.9874	2.4348	2.4348	2.5377	2.4348	2.4348	2.7435
20	2.8006	2.4006	2.4348		2.6139	2.332	2.5377
21	2.8006	2.3663	2.2634	2.5034	2.3663	2.2291	2.6063
22	2.5377	2.6139	2.332	2.2977	2.2977	2.3663	2.5034
23	2.5034	2.4615	2.3663	2.3663	2.3663	2.2977	2.6749
24	2.5377	2.4006	2.4615	2.332	2.2291	2.1948	2.2977
Max	2.9874	2.8807	2.9127	3.1367	2.9938	2.8464	2.8121
Min	2.0576	1.8176	1.7833	1.8861	1.7833	1.6804	1.8176
Avg	2.5245	2.4063	2.3323	2.3451	2.2750	2.1506	2.2848

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 223001 / 22/22 KV BHINGARI SWITCHING
ST

Feeder No / Name : 310 / 22 KV PANVEL-III

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	1.1317	1.1949	1.4403	1.4403	1.3717	1.3717
2	1.0974	1.0974	1.1203	1.3717	1.3717	1.3032	1.3032
3	1.0288	1.0288	1.1203	1.2346	1.3032	1.2003	1.2346
4	1.0288	1.2003	1.1203	1.166	1.3032	1.1317	1.2689
5	1.166	1.3375	1.1203	1.307	1.3717	1.166	1.3375
6	1.3375	1.3717	1.1576	1.166	1.4403	1.2003	1.406
7	1.406	1.406	1.1949	1.2003	1.5089	1.3375	1.5089
8	1.4403	1.406	1.4563	1.4403	1.6118	1.5432	1.4746
9	1.2689	1.3032	1.3817	1.8298	1.6221	1.5775	1.5089
10	1.2003	1.2346	1.419	1.9044	1.6057	1.6118	1.5432
11	1.2003	1.2003	2.4272	2.3525	2.2779	2.2257	2.1605
12	1.2346	1.0631	2.3525	2.4646	2.1502	2.1285	2.2291
13	1.0974	1.1317	1.989	2.5019	2.1285	2.0233	2.1948
14	1.0974	1.0974	1.989	2.2634	1.8861	1.8519	2.1605
15	1.1576	1.0974	2.0233	2.1605	1.8519	1.8176	2.1262
16	1.1949	1.0631	2.0576	2.1262	1.7833	1.8861	2.0919
17	1.2696	1.0974	2.0919	2.1262	1.8176	1.8861	2.1948
18	1.3032	1.166	2.2634	2.2634	1.9547	2.1262	2.1948
19	1.6804	1.5432	2.5034	2.572	2.2977	2.3663	2.5377
20	1.5684	1.5775	2.4348		2.2291	2.2977	2.4691
21	1.6057	1.4403	2.3663	2.4006	2.0919	2.2291	2.4348
22	1.3717	1.4937	2.8464	2.1262	1.8176	1.8861	2.0919
23	1.2689	1.3817	1.749	1.8176	1.7147	1.6118	1.8176
24	1.166	1.166	1.2826	1.5089	1.5089	1.4403	1.406
Max	1.6804	1.5775	2.8464	2.572	2.2977	2.3663	2.5377
Min	1.0288	1.0288	1.1203	1.166	1.3032	1.1317	1.2346
Avg	1.2634	1.2515	1.7776	1.8585	1.7537	1.7175	1.8361

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 224004 / 33/11KV NEW PANVEL SEC-7

S/STN

Feeder No / Name : 201 / 11 kV Station Trasformer

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0191	.0191	.0191	.0191
6		.0191	.0191		.0191
7		.0191	.0191		.0191
8		.0191		.0191	
9	.0191		.0191	.0191	.0191
10	.0191		.0191	.0191	.0191
11	.0191		.0191	.0191	.0191
12	.0191				.0191
13	.0191		.0191	.0191	.0191
14	.0191		.0191	.0191	.0191
15	.0191		.0191	.0191	.0191
16	.0191		.0191	.0191	
17	.0191				.0191
18	.0191		.0191	.0191	.0191
19	.0191	.0191	.0191	.0191	.0191
20	.0191	.0191	.0191	.0191	.0191
21	.0191	.0191	.0191		
22	.0191	.0191	.0191	.0191	.0191
23	.0191	.0191	.0191	.0191	
24		.0191	.0191	.0191	.0191
Max	.0191	.0191	.0191	.0191	.0191
Min	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.0191	.0191	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 224004 / 33/11KV NEW PANVEL SEC-7

S/STN

Feeder No / Name : 205 / 11 kV Sector 8

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8192	.8192	.7811	.8002
6		1.1812	.8954		1.2193
7		1.4289	1.1622		1.448
8		1.4289		1.086	
9	1.2955		1.2955	1.4289	1.3527
10	1.105		1.2765	1.3908	1.0669
11	1.105		1.2193	1.2574	1.0098
12	.9526				.9526
13	.9717		.9145	.9907	.8764
14	.8573		.8954	.9145	.8002
15	.8192		.7049	.8383	.7049
16	.724		.7049	.7811	
17	.8192				.7811
18	.9526		.9717	.8954	.8764
19	1.2955	1.2193	1.2574	1.2384	1.2574
20	1.2193	1.2003	1.2003	1.2193	1.2574
21	1.3146	1.2193	1.2193		
22	1.2193	1.1812	1.105	1.1622	1.1431
23	1.086	1.0098	1.0479	1.0288	
24		.9526	.8764	.8954	.9335
Max	1.3146	1.4289	1.2955	1.4289	1.448
Min	.724	.8192	.7049	.7811	.7049
Avg	1.0491	1.1641	1.0333	1.0606	1.0300

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 224004 / 33/11KV NEW PANVEL SEC-7

S/STN

Feeder No / Name : 206 / 11kv sect-3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1524		.1524	.1524
6		.1524	.1524		.1524
7			.1524		.1524
8		.1524		.1524	
9	.2096		.1524	.1715	.1524
10	.1905		.1715	.1524	.1715
11	.1524		.1715	.1715	.1524
12	.1715				.1715
13	.1524		.1524	.2286	.1905
14	.1524		.1524	.1524	.1524
15	.1524		.1524	.1524	.1715
16	.0191		.1524	.1524	
17	.1715				.1524
18	.1524		.1524	.1524	.1715
19	.1715	.1905	.1715	.1524	.1905
20	.2286	.1524	.1715	.1905	.2286
21	.1905	.1524	.1715		
22	.1715	.1524	.1524	.1524	.1524
23	.1524	.1524	.1524	.1524	
24		.1524	.1524	.1524	.1524
Max	.2286	.1905	.1715	.2286	.2286
Min	.0191	.1524	.1524	.1524	.1524
Avg	.1626	.1566	.1584	.1626	.1667

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 224004 / 33/11KV NEW PANVEL SEC-7

S/STN

Feeder No / Name : 207 / 11KV SECT-5

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5906	.5525	.5335	.5335
6		.7621	.6859		.7049
7		.8383	.6859		.8192
8		1.0288		.7049	
9	.9717		.8764	.8764	1.086
10	1.1812		1.1241	1.105	1.1622
11	1.105		1.105	1.0098	1.0479
12	1.1241				1.086
13	1.086		1.0669	.9907	.9526
14	.8764		.9335	.9526	.8573
15	.8954		.8954	.7049	.9145
16	.9526		.8383	.743	
17	.8383				.8573
18	.9717		.8764	.8002	.9335
19	.9907	.9907	.9907	.9335	1.0479
20	1.0288	.9717	.9907	.8954	.9526
21		.9526	.9526		
22	.8383	.8002	.6859	.724	.8002
23	.7621	.7049	.6668	.6859	
24		.7049	.6097	.6097	.5716
Max	1.1812	1.0288	1.1241	1.105	1.1622
Min	.7621	.5906	.5525	.5335	.5335
Avg	.9730	.8345	.8551	.8180	.8955

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 224004 / 33/11KV NEW PANVEL SEC-7

S/STN

Feeder No / Name : 208 / 11kv mpk

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8002	.743	.8002	.7621
6		1.0669	.8573		1.0098
7		1.1622	1.0479		1.1431
8		1.2574		.9717	
9	1.2955		1.2193		1.2193
10	1.1812		1.2955	1.2955	1.1812
11	1.105		1.2384	1.3146	1.105
12	1.1812				.9717
13	1.086		1.1812	1.1812	1.0288
14	1.0098		1.0669	1.086	1.0098
15	.9717		.9907	1.0288	.8954
16	1.0288		.9526	1.0288	
17	1.1241				1.0479
18	1.086		1.0669	.9717	1.105
19	1.3717	1.2574	1.3908	1.2765	1.2003
20	1.2955	1.2574	1.2384	1.2193	1.2384
21	1.2955	1.2193	1.1812		
22	1.1812	1.0479	1.0669		1.0669
23	1.0288	.9717	.9145	.9526	
24		.9335	.8573	.9145	.8383
Max	1.3717	1.2574	1.3908	1.3146	1.2384
Min	.9717	.8002	.743	.8002	.7621
Avg	1.1495	1.0974	1.0770	1.0801	1.0514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 224004 / 33/11KV NEW PANVEL SEC-7

S/STN

Feeder No / Name : 209 / 11 KV ESRGSR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2858	.2477	.3048	.3048
6		.4572	.381		.4572
7		.4954	.4572		.5335
8		.4954		.381	
9	.5335		.4954	.4572	.5525
10	.5144		.4191	.4954	.4191
11	.381		.362	.4572	.5144
12	.381				.381
13	.4001		.2286	.381	.2858
14	.2286		.2858	.3239	.2667
15	.2286		.2286	.3429	.2667
16	.2286		.2667	.2667	
17	.3048				.2477
18	.2858		.3239	.3429	.2667
19	.4191	.381	.4763	.4572	.4572
20	.4191	.4382	.381	.9717	.381
21	.3429	.3429	.362		
22	.3429	.3239	.381		.362
23	.3239	.2858	.3429	.362	
24		.2858	.2667	.3239	.3239
Max	.5335	.4954	.4954	.9717	.5525
Min	.2286	.2858	.2286	.2667	.2477
Avg	.3556	.3791	.3474	.4191	.3763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 224012 / 33/11 KV KALPATARU RIVERSIDE

Feeder No / Name : 201 / 11KV KALPATARU KRISHNA-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0943	.0566	.0754	.056	.0747	.056
2	.0566	.0754	.0566	.0566	.056	.056	.056
3	.0566	.0566	.0566	.0566	.056	.056	.056
4	.0566	.0754	.0566	.0566	.056	.056	.056
5	.0566	.0943	.0754	.0754	.056	.0747	.0747
6	.0943	.1509	.0943	.0943	.0747	.0934	.0934
7	.132	.1509	.132	.1132	.1307	.1307	.168
8	.2075	.1698	.1698	.1509	.1867	.1867	.1867
9	.1698	.1698	.1698	.1886	.1494	.1867	.168
10	.132	.1509	.2075	.1698	.1307	.1307	.1494
11	.1132	.1132	.1509	.1494	.1307	.1307	.1307
12	.0943	.1132	.1509	.112	.0754	.112	.1307
13	.0943	.0943	.1132	.112	.0747	.0934	.0934
14	.0943	.0943	.0943	.0934	.0747	.0934	.0934
15	.0943	.0754	.0943	.0934	.0747	.0747	.0747
16	.0754	.0754	.0754	.0934	.0747	.0747	.0747
17	.0943	.0754	.0943	.0934	.0934	.0747	.0747
18	.0943	.0943	.132	.0934	.0934	.0747	.112
19	.132	.1132	.132	.112	.112	.112	.1494
20	.132	.132	.132	.112	.1307	.112	.112
21	.132	.0943	.1132	.0934	.0934	.112	.1494
22	.1132	.0754	.1132	.0747	.0934	.0934	.0934
23	.1132	.0754	.0943	.0747	.0747	.0747	.0747
24	.0943	.0943	.0754	.0754	.0747	.0747	.0747
Max	.2075	.1698	.2075	.1886	.1867	.1867	.1867
Min	.0566	.0566	.0566	.0566	.056	.056	.056
Avg	.1045	.1045	.1100	.1008	.0926	.0980	.1043

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 224012 / 33/11 KV KALPATARU RIVERSIDE

Feeder No / Name : 202 / 11KV KALPATARU NARMADA-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0566	.0566	.0566	.0566	.0566
2	.0377	.0566	.0377	.0566	.0377	.0566	.0377
3	.0377	.0566	.0377	.0566	.0377	.0377	.0377
4	.0377	.0566	.0566	.0566	.0377	.0566	.0377
5	.0566	.0754	.0566	.0566	.0566	.0566	.0566
6	.0754	.0943	.0754	.0754	.0754	.0566	.0754
7	.1132	.1132	.0754	.0943	.1132	.1132	.0943
8	.0943	.132	.1132	.1132	.1132	.132	.1132
9	.132	.1132	.1132	.1132	.0943	.132	.1132
10	.1132	.1132	.1132	.1132	.0943	.0943	.132
11	.0943	.0943	.1132	.1132	.1132	.0943	.0943
12	.1132	.0754	.0943	.1132	.1132	.0754	.1132
13	.0566	.0754	.0754	.0943	.0754	.0566	.0754
14	.0754	.0754	.0754	.0754	.0566	.0566	.0566
15	.0566	.0566	.0566	.0566	.0566	.0566	.0566
16	.0754	.0566	.0754	.0566	.0566	.0566	.0566
17	.0754	.0566	.0566	.0566	.0566	.0566	.0566
18	.0754	.0754	.0754	.0943	.0566	.0566	.0566
19	.1132	.0943	.0754	.0747	.0943	.0943	.0754
20	.0754	.0943	.0754	.0754	.0754	.0754	.0943
21	.0754	.0754	.0754	.0754	.0754	.0754	.0754
22	.0943	.0943	.0943	.0754	.1132	.0754	.0754
23	.0754	.0754	.0566	.0566	.0566	.0566	.0754
24	.0754	.0754	.0754	.0566	.0566	.0566	.0566
Max	.132	.132	.1132	.1132	.1132	.132	.132
Min	.0377	.0566	.0377	.0566	.0377	.0377	.0377
Avg	.0786	.0809	.0754	.0778	.0739	.0723	.0739

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 224012 / 33/11 KV KALPATARU RIVERSIDE

Feeder No / Name : 203 / 11 KV KALPATARU KAVERI-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0671	.0671	.0503	.0503	.0509	.0678	.0509
2	.0503	.0503	.0503	.0503	.0509	.0509	.0509
3	.0503	.0503	.0503	.0503	.0509	.0509	.0509
4	.0503	.0671	.0503	.0503	.0509	.0509	.0509
5	.0503	.0838	.0671	.0671	.0509	.0678	.0509
6	.0671	.1006	.0838	.0838	.0678	.1017	.0678
7	.1006	.1006	.1174	.1006	.1187	.0848	.1357
8	.1006	.1006	.1006	.1174	.1017	.1017	.1187
9	.1006	.1006	.1174	.1174	.1017	.0848	.1187
10	.1006	.1006	.1006	.1174	.0848	.0848	.1017
11	.1174	.1006	.1006	.1006	.1357	.0848	.1187
12	.0838	.1006	.1174	.1006	.0848	.0848	.0848
13	.0838	.0838	.0838	.1017	.0848	.0848	.0848
14	.0838	.0671	.0671		.0848	.0848	.0678
15	.0838	.0671	.0838	.0848	.1187	.0678	.0678
16	.0838	.0671	.1174	.0678	.0848	.0678	.0848
17	.0838	.0838	.0838	.0678	.0848	.0678	.0848
18	.0838	.0671	.0838	.0848	.0848	.0678	.1017
19	.1006	.1006	.1174	.112	.1187	.1017	.0678
20	.1006	.1006	.1006	.1017	.1017	.1017	.0848
21	.1006	.1006	.0838	.1017	.1017	.1017	.0848
22	.1174	.0838	.1174	.0848	.1017	.0848	.0848
23	.0838	.0671	.0838	.0678	.0848	.0848	.0848
24	.0838	.0838	.0671	.0671	.0678	.0848	.0678
Max	.1174	.1006	.1174	.1174	.1357	.1017	.1357
Min	.0503	.0503	.0503	.0503	.0509	.0509	.0509
Avg	.0845	.0831	.0873	.0847	.0862	.0798	.0820

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 224012 / 33/11 KV KALPATARU RIVERSIDE

Feeder No / Name : 303 / 22KV O/g 2(Panvel 2)

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.5113	3.2526	3.2895	3.1417	2.9938	2.846	2.9569
2	3.2526	3.0308	2.9938	2.8829	2.8829	2.6981	2.846
3	2.9569	2.8829	2.846	2.6612	2.809	2.5503	2.6981
4	2.846	2.9569	2.846	2.5133	2.809	2.5873	2.5873
5	3.1417	3.2526	2.9938	2.7351	2.8829	2.809	2.9569
6	3.4004	3.4743	3.2895	2.8829	3.4004	3.0308	3.4004
7	4.2875	4.2135	3.77	3.3265		3.807	3.9548
8	4.731	4.3983	4.1027	3.9548	4.2875	4.1766	4.4353
9	4.6201	4.3244	4.5831	4.3614	4.3983	4.6201	4.5462
10	5.0267	4.731	4.6571	4.6571	4.768	4.5092	4.768
11	5.3224	4.9158	4.731	4.5092	5.0267	4.6201	5.2854
12	5.1745	4.8419	4.694	4.5092	4.6201		5.2854
13	4.9158	4.6571	4.5831	4.3244	4.5092		5.0267
14		4.3983	4.2135	4.0287	4.2505	4.2505	4.6201
15	4.5092	4.5092	4.3244	3.807	4.2505	4.3244	4.6201
16	4.5462	4.6201	4.3614	3.8855	4.3614	4.3983	4.731
17	4.6571	4.8049	4.5092	3.8439	4.4353	4.4723	4.8788
18	5.1376	5.0267	4.8049	4.1396	4.768	4.5462	5.1006
19	5.9877	5.7289	5.8398	5.2115	5.692	5.6181	6.0246
20	5.8768	5.5811	5.1745	5.0636	5.5441	5.5072	5.9137
21	5.4332	5.0636	5.1745	4.3614	4.8049	4.8049	5.2115
22	4.3983	4.2135	4.2135	4.0657	3.9918	4.1766	4.4353
23	3.9179	3.807	3.6961	3.5852	3.4743	3.6591	4.0287
24	3.807	3.4004	3.5852	3.2895	3.3634	3.0678	3.1417
Max	5.9877	5.7289	5.8398	5.2115	5.692	5.6181	6.0246
Min	2.846	2.8829	2.846	2.5133	2.809	2.5503	2.5873
Avg	4.4112	4.2536	4.1365	3.8226	4.1010	3.9582	4.3106

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 228013 / 220/33/22 KV ONGC PANVEL

Feeder No / Name : 405 / 33KV KALPATARU INCOMING-1

Feeder KV- 33 / INCOMING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	3.7403	3.738	3.5734	3.4637	3.3562	3.2991
2	3.5734	3.4637	3.4637	3.3539	3.3539	3.1345	3.1893
3	3.2991	3.2991	3.2991	3.1345	3.1893	2.9699	3.0247
4	3.1893	.2286	3.2991	2.9699	3.1893	2.9699	2.915
5	3.4637	.2858	3.5208	3.2464	3.3539	3.2464	3.2991
6	3.7951	4.074	3.8523	3.3562	3.7951	3.4682	3.7951
7	4.7325	4.7348	4.0192	3.8546	4.4605	4.3507	4.4056
8	5.1189	4.9017	4.6251	4.4056	4.7897	4.6799	4.9017
9	5.1738	4.9543	5.0092	4.7348	4.8994	5.0114	4.8994
10	5.5555	5.2835	5.064	5.064	5.1692	4.8971	5.2835
11	5.6653	5.3909	5.3384	5.0092	5.5579	5.0068	5.6104
12	5.6104	5.2789	5.0617	4.952	5.0595	.2858	5.6082
13	5.2766	5.0595	4.9497	4.7325	4.8377	.2286	5.3315
14	4.9497	4.7279	4.6182	4.4559	4.5633	4.5633	4.9474
15	4.8925	4.8377	4.7279	4.1792	4.6731	4.6731	5.0571
16	5.0046	4.9474	4.7303	4.1792	4.7279	4.7828	5.112
17	5.0595	5.2217	4.7828	4.2341	4.7828	4.8377	5.2217
18	5.4436	5.3315	5.1692	4.5656	5.0571	4.8925	5.4436
19	6.3237	6.1042	6.1042	5.6082	5.9945	5.9945	6.3237
20	6.2688	5.8847	6.214	5.3338	5.8825	5.7728	6.214
21	5.8299	5.2789	5.5555	4.7851	5.1692	5.2241	5.6653
22	4.8422	4.6205	4.7348	4.4536	4.4559	4.6205	4.8949
23	4.3438	4.1792	4.0695	4.0146	3.9049	4.0695	4.3438
24	4.2364	3.9049	3.9597	3.7951	3.7403	3.5757	3.5208
Max	6.3237	6.1042	6.214	5.6082	5.9945	5.9945	6.3237
Min	.2286	.2286	3.2991	2.9699	3.1893	.2286	2.915
Avg	4.6615	4.4056	4.5794	4.2496	4.5029	4.0255	4.6795

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

URAN[126]

BU 0337

Substation No/ Name :- 223033 / 22/22 KV URAN SWITCHING

Feeder No / Name : 302 / 22 KV Dronagiri

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			2.0195	
8			1.5716	
9				1.0288
10			1.7712	.9431
11				.9054
12	2.1879			
13				.8676
14				.7922
16			1.5089	.9054
17			1.4335	.8299
18		2.037	1.358	.7922
19			1.8861	1.4335
20		2.5149	1.8861	1.2826
21			1.6598	1.2826
22		1.9814	1.8107	1.2826
24			1.7528	
Max	2.1879	2.5149	2.0195	1.4335
Min	2.1879	1.9814	1.358	.7922
Avg	2.1879	2.1778	1.6962	1.0288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

URAN[126]

BU 0337

Substation No/ Name :- 223033 / 22/22 KV URAN SWITCHING

Feeder No / Name : 303 / 22 KV Chirner

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			4.1914	
8			4.3381	
9				3.5818
10			5.3189	4.1872
11				3.3951
12	5.4431			
13				3.4705
14				2.8292
16			4.7908	3.6214
17			5.8093	2.6029
18		6.0357	5.0926	3.2819
19			5.0926	4.3381
20		5.8299	5.8093	4.3004
21			5.0172	4.2627
22		4.763	4.7531	4.2627
24			4.5344	
Max	5.4431	6.0357	5.8093	4.3381
Min	5.4431	4.763	4.1914	2.6029
Avg	5.4431	5.5429	4.9771	3.6778

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

URAN[126]

BU 0337

Substation No/ Name :- 223033 / 22/22 KV URAN SWITCHING

Feeder No / Name : 304 / 22 KV Industrial

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	09-FEB-18	10-FEB-18	11-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
1		.4572	
8		.6445	
9			.724
10		.9127	.6413
11			.5281
13			.415
14			.415
16		.3772	.3772
17		.415	.415
18	.4527	.4527	.4527
19		.6413	.6036
20	.6859	.6036	.6413
21		.6036	.6036
22	.6097	.6036	.5658
24		.4572	
Max	.6859	.9127	.724
Min	.4527	.3772	.3772
Avg	.5828	.5608	.5319

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 201 / 11 KV Sector - 14

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.1776		1.9719		2.0576	
2	2.2257		2.2634				
4	2.1691	2.0233	2.1691			1.8347	
5				1.7147			
6	2.0748		2.2822				
7		2.5377					
8	2.999	2.7606	2.7161	2.0405	2.7054	2.0576	2.915
9	2.7349						
10		2.3491			2.4387		2.4577
11							2.4196
12		2.4143				2.1148	
14		2.1691			1.7661		
16		1.9616			1.6118	1.6385	2.0576
17	1.7147		1.5432	1.9433			
18	1.7833	2.1691			1.4918		
19			2.6749			2.7244	2.915
20	2.9664	3.0933					
22		2.7538	2.6406		2.9835	2.7625	
23				2.4768	2.2119		
24	2.4897	2.2291	2.3577	2.0576		2.1434	
Max	2.999	3.0933	2.7161	2.4768	2.9835	2.7625	2.915
Min	1.7147	1.9616	1.5432	1.7147	1.4918	1.6385	2.0576
Avg	2.3508	2.3866	2.3309	2.0341	2.1727	2.1667	2.5530

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 202 / 11 KV Sector - 7

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4801		.3944		.4458	
2			.4338				
4	.4338	.3772	.3584			.3772	
5				.3258			
6			.415				
7		.5316					
8	.6979	.5658	.5093	.3772	.6478	.4115	.6287
9	.7545						
10		.6344			.7049		.6859
11							.7621
12		.7167				.5525	
14		.6413			.4801		
16		.5847			.463	.4954	.6097
17	.5487		.5144	.4763			
18	.5658	.547			.4115		
19			.7716			.6668	.7811
20	.6173	.7167					
22		.6224	.583		.6516	.6287	
23				.5716	.5144		
24	.547	.4973	.4904	.4287		.4801	
Max	.7545	.7167	.7716	.5716	.7049	.6668	.7811
Min	.4338	.3772	.3584	.3258	.4115	.3772	.6097
Avg	.595	.5763	.5095	.429	.5533	.5073	.6935

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 203 / 11 KV Sector - 10

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4115		.4115		.3944	
2			.3961				
4	.3772	.3258	.3395			.3258	
5				.3429			
6			.3584				
7		.4973					
8	.6036	.5144	.4904	.4458	.5716	.3258	.5335
9	.3961						
10		.4973			.4763		.4763
11							.4572
12		.415				.4191	
14		.3018			.2743		
16		.2641			.2058	.2286	.2667
17	.2229		.3772	.2858			
18	.2743	.3206			.2401		
19			.3772			.381	.4572
20	.463	.5281					
22		.4904	.4287		.5144	.5144	
23				.4572	.4458		
24	.4904	.4287	.4527	.4458		.4115	
Max	.6036	.5281	.4904	.4572	.5716	.5144	.5335
Min	.2229	.2641	.3395	.2858	.2058	.2286	.2667
Avg	.4039	.4163	.4025	.3982	.3898	.3751	.4382

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 204 / 11 KV Sector -15

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3944		.4115		.3944	
2			.3772				
4	.3395	.3086	.3772			.3258	
5				.3601			
6			.3961				
7		.5144					
8	.4904	.5144	.5281	.3944	.5525	.3772	.6287
9	.4904						
10		.463			.4572		.5144
11							.4954
12		.4715				.4954	
14		.3772			.4115		
16		.3584			.4115	.3429	.3429
17	.4973		.3258	.4191			
18	.5144	.4338			.3772		
19			.7202			.6478	
20	.7202	.679					
22		.6224	.5658		.6516	.6097	
23				.4954	.4458		
24	.5093	.4458	.4338	.4287		.4115	
Max	.7202	.679	.7202	.4954	.6516	.6478	.6287
Min	.3395	.3086	.3258	.3601	.3772	.3258	.3429
Avg	.5088	.4652	.4655	.4182	.4725	.4506	.4954

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 206 / 11 KV Ajanta Sector -13

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1029		.1029		.0857	
2			.1132				
4		.0857	.1132			.0857	
5				.0857			
6			.1132				
7		.1029					
8		.1029	.1132	.0857	.1143	.0857	.1143
9	.1132		.1132				
10		.1029			.1143		.1143
11							.1143
12		.1132				.1143	
14		.1132			.1029		
16		.1132			.1029	.1143	.1143
17	.1029		.1029	.1143			
18	.1029	.1132			.1029		
19			.1029			.1143	.1143
20	.1029	.1132					
22		.1132			.12	.1143	
23				.1143	.1029		
24	.1132	.1029	.1132	.1029		.1029	
Max	.1132	.1132	.1132	.1143	.12	.1143	.1143
Min	.1029	.0857	.1029	.0857	.1029	.0857	.1143
Avg	.1070	.1066	.1106	.1010	.1086	.1022	.1143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 207 / 11 KV Sector - 4

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7545				.6516	
2			.7545				
4	.7545	.5658	.7167			.5658	
6			.8299				
7		1.0288					
8	1.3014	1.1145	1.0468		1.1622	.8573	1.2193
9	1.1506						
10		.9431			1.0479		.9907
11							1.0669
12		1.0374				.9526	
14					.7373		
16		.8676			.6516	.724	.8383
17			.7888	.8764			
18	.7716	.9054			.7202		
19			1.0288			1.0669	1.2384
20	1.1831	1.1883					
22		1.0374	.9259		1.1831	1.0669	
23				.9145	.8059		
24	.9619	.823	.8488	.7716		.6859	
Max	1.3014	1.1883	1.0468	.9145	1.1831	1.0669	1.2384
Min	.7545	.5658	.7167	.7716	.6516	.5658	.8383
Avg	1.0205	.9333	.8675	.8542	.9012	.8214	1.0707

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 208 / 11 KV Sector-8

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.4006		2.1091		1.8861	
2	2.2634		2.4143				
4	2.1691	2.1776	2.2822			1.9204	
5				1.8861		1.5432	
6	2.2634		2.2634				
7		2.7778					
8	3.5837	3.2579	2.9235	2.2634	3.6389	1.4575	.9602
9	3.5271						
10		3.3196			3.3341		3.3341
11							.9259
12		3.1121				1.3717	
14		2.452			1.9204		
16		2.1502			1.6632	1.8099	.9259
17	2.0576		2.5206	2.3243			
18	2.0919	2.5463			1.6975	1.0288	
19			3.1893			3.1817	3.1817
20	3.2236	3.5082				1.0288	.9602
21						1.3717	
22		3.1876	2.7606			.9431	.9431
23				2.6292	2.2634		.9431
24	2.7538	2.4348	2.5274	2.1434	2.1605	2.1605	2.0233
Max	3.5837	3.5082	3.1893	2.6292	3.6389	3.1817	3.3341
Min	2.0576	2.1502	2.2634	1.8861	1.6632	.9431	.9259
Avg	2.6593	2.7771	2.6102	2.2259	2.3826	1.6420	1.5775

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 210 / 11 KV Sector-20A NG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4115		.3772		.3429	
2			.4527				
4	.415	.3429	.415	.2915		.3258	
6			.4715				
7		.6859					
8	.6602	.6859	.5676	.4458	.7049	.5144	.8764
9	.5847						
10		.5316			.6097		.7049
11							.724
12		.4338				.4382	
14		.3772			.2743		
16		.3206			.3258	.3048	.4572
17	.3258		.3772	.4191			
18	.3772	.3772			.3601		
19			.5144			.6287	.6859
20	.4973	.5093					
22		.5281	.4801		.5144	.724	
23				.4954	.4287		
24	.5281	.4458	.5281	.3944		.3944	
Max	.6602	.6859	.5676	.4954	.7049	.724	.8764
Min	.3258	.3206	.3772	.2915	.2743	.3048	.4572
Avg	.4840	.4708	.4758	.4039	.4597	.4592	.6897

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 212 / 11 KV Sector-20C,Shivani.

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3258		.2572		.2743	
2			.2829				
4	.2641	.2915	.321			.2229	
5				.2401			
6			.3395				
7		.3944					
8	.5281	.4801	.3395	.3086	.4572	.3772	.4763
9	.5093						
10		.4115			.4763		.4191
11							.362
12		.3395				.4001	
14		.3018			.2058		
16		.3206			.2058	.2286	.2286
17	.2915		.2401	.3239			
18	.3086	.3206			.2058		
19			.4115			.381	.4763
20	.4458	.4527					
22		.415	.3429		.463	.4191	
23				.362	.3258		
24	.3584	.3429	.3395	.3086		.2915	
Max	.5281	.4801	.4115	.362	.4763	.4191	.4763
Min	.2641	.2915	.2401	.2401	.2058	.2229	.2286
Avg	.3865	.3664	.3271	.3001	.3342	.3243	.3925

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 213 / 11 KV Sector-20 D,DKT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1029		.0857		.1029
2			.1132			
4	.1132	.0857	.1132			.1029
5				.0857		
6			.1132			
7		.12				
8	.1132	.12	.1132	.0857	.1143	.1029
9	.1132					
10		.12			.1143	
12		.1132				.1143
14		.1132			.1029	
16		.1132			.0857	.1143
17	.1029		.1029	.1143		
18	.1029	.1132			.0857	
19			.1029			.1143
20	.12	.1132				
22		.1132	.1029		.1029	.1143
23				.1143	.1029	
24	.1132	.12	.1132	.1029		.1029
Max	.12	.12	.1132	.1143	.1143	.1143
Min	.1029	.0857	.1029	.0857	.0857	.1029
Avg	.1112	.1123	.1093	.0981	.1012	.1086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 214 / 11 KV Sector-19,Bhoomi

SHEDDABLE URBAN

kolsa Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0631		.9259		.9088	
2	1.094		1.0374				
4	1.0185	.9602	1.0185			.7545	
5				.6687			
6	1.1128		1.1128				
7		1.4746					
8	1.7918	1.5775	1.4335	1.0974	1.5432	.8573	1.6194
9	1.6598						
10		1.2517			1.4098		1.3336
11							1.3527
12		1.2071				1.2003	
14		1.1694			.9431		
16		1.0374			.8059	.9145	1.0669
17	.8916		.8059	.9717			
18	.9259	1.0562			.6859		
19			1.2517			1.2193	1.4098
20	1.4403	1.3957					
22		1.358	1.2003		1.4403	1.3336	
23				1.1812	1.0802		
24	1.2637	1.0974	1.1506	.9431		.9945	
Max	1.7918	1.5775	1.4335	1.1812	1.5432	1.3336	1.6194
Min	.8916	.9602	.8059	.6687	.6859	.7545	1.0669
Avg	1.2443	1.2207	1.1263	.9647	1.1298	1.0229	1.3565

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 301 / 22KV Diva Gaon

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.6859		.6516	
4	.7545					.583	
5				.6173			
7		.8573					
8		.9259	.8676	.823	1.0288	.7545	.9526
9	.8916						
10		.7545			.8383		.8383
11							.724
12						.724	
14					.583		
16		.679			.583	.5716	.6859
17	.6173		.6516	.724			
18	.6516				.6516		
19			.8573			.9526	.9907
20	.9945						
22		.9808	.8573		.8916	.9145	
23				.8764	.7888		
24	.9431	.7888	.8299	.7202		.9602	
Max	.9945	.9808	.8676	.8764	1.0288	.9602	.9907
Min	.6173	.679	.6516	.6173	.583	.5716	.6859
Avg	.8088	.8311	.8127	.7411	.7664	.764	.8383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641] BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15
S/StnFeeder No / Name : 302 / Sect15 Substn T/F
Feeder KV- 22 / OUTGOING

DATE	10-FEB-18
HR	Load (MW)
11	.1886
Max	.1886
Min	.1886
Avg	.1886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283027 / 22/22KV Rabale MIDC Swt/stn

Feeder No / Name : 302 / Hamara Mahanagar (R.M.U. SHEDDABLE FEEDER HAVING WEEKLY
W-404 Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4006		2.4006			2.1948
2	2.1948		2.1948			2.0576
3	2.0576		2.0576			1.9204
4	1.9204		1.9204			1.8519
5	1.7147		2.0576			1.7147
6	2.0576		2.1948			2.0576
7	2.4006		2.4006			2.4006
8	2.6749		2.4691	2.572	2.5034	2.6406
16				4.904	4.1152	
18		3.9095				
19		3.738				
20		3.2922				
21		2.8464				
22		2.6406				
23		2.6749		2.6063	2.3663	
24	2.4691		2.6063	2.332	2.4006	2.332
Max	2.6749	3.9095	2.6063	4.904	4.1152	2.6406
Min	1.7147	2.6406	1.9204	2.332	2.3663	1.7147
Avg	2.2100	3.1836	2.2558	3.1036	2.8464	2.1300

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283027 / 22/22KV Rabale MIDC Swt/stn

Feeder No / Name : 305 / NARAYAN DAIRY (R.M.U. W- SHEDDABLE FEEDER HAVING WEEKLY
413) Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
1		1.0288	
2		.9259	
3		.8573	.679
4		.7545	
5		.8573	
6		.9945	.9054
7		.9602	
8		.9945	
9		1.1317	
10	2.1262		
11	2.3663		
12	2.4006	1.5089	
13	1.8519		
14	2.1948		
15	1.9547	1.4712	
16	2.0233		
17	1.9204		
18	1.9204	1.1694	
19	1.749		
20	1.4403		
21	1.3375	1.1317	
22	1.2003		
23	1.0631		
24		1.0974	1.0185
Max	2.4006	1.5089	1.0185
Min	1.0631	.7545	.679
Avg	1.8249	1.0631	.8676

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283027 / 22/22KV Rabale MIDC Swt/stn

Feeder No / Name : 306 / Roshn Hotel (R.M.U. R-320) SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	.8573		.9259	.8573		.8916
2	.9602	.7545		.823	.7545		.823
3	.9259	.7202	.5658	.6859	.6859	.7545	.6859
4	.823	.7202		.6859	.6859		.6859
5	.9602	.823		.6859	.7888		.6859
6	1.0288	.9602	.9054	.823	.9259	.9808	.823
7	1.0974	.9259		.9259	.9259		1.0288
8	1.166	.9945		.9945	1.0974		1.0974
9		.9945	1.358	1.4746	1.3032	1.4335	
10	1.6804		1.5432	1.5089		1.5432	
11	1.6461		1.5089	1.6118		1.6804	
12	1.8519	1.2071	1.3717	1.4403	1.8861	1.6461	1.773
13	1.5089		1.3717	1.166		1.6804	
14	1.6461		1.3717	1.4403		1.6804	
15	1.8519	1.3203	1.5089	1.3717	1.9616	1.7147	2.037
16	1.9547		1.3717	1.5775		1.749	
17	1.6118		1.5089	1.3717		1.749	
18	1.5775	1.094	1.6118	1.3032	1.6598	1.7147	1.8861
19	1.6461		1.7147	1.5432		1.3717	
20	1.4746		1.4746	1.3375		1.3032	
21	1.4403	1.1317	1.166	1.2003	1.2826	1.2346	1.4335
22	1.166		.9602	1.166		1.0974	
23	1.1317		1.0288	1.0288		1.0288	
24	1.0974	1.0288	1.0185	.9602	.9945	1.0562	1.0288
Max	1.9547	1.3203	1.7147	1.6118	1.9616	1.749	2.037
Min	.823	.7202	.5658	.6859	.6859	.7545	.6859
Avg	1.3598	.9666	1.2978	1.1688	1.1292	1.4121	1.1446

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283027 / 22/22KV Rabale MIDC Swt/stn

Feeder No / Name : 307 / R.M.U. R-201

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2346	1.2689		1.2346	1.2003		1.166
2	1.0974	1.0974		1.166	1.0631		1.0288
3	1.0288	1.0974	.9431	1.0288	.8916		.9602
4	.9602	1.1317		.9602	.8573		.8916
5	.9259	1.3032		.9259	.9602		.823
6	1.0288	1.5089	1.0562	1.0288	1.2003	1.1694	1.0288
7	1.2346	1.2346		1.0974	1.0288		1.0974
8	1.3375	1.4403		1.2003	1.2689		1.1317
9		1.2003	1.0562	1.0288	.8573	1.2449	
10	1.3032		1.2346	1.0288		1.4746	
11	1.3032		1.3717	1.1317		1.406	
12	1.4746	1.5089	1.5089	1.2003	1.8484	1.7147	1.6221
13	1.6118		1.5089	1.5432		2.0576	
14	1.8861		1.3717	1.6461		2.1262	
15	1.8176	2.0748	1.3032	1.6118	1.8484	1.9204	1.8861
16	1.8176		1.3032	1.3717		1.9204	
17	1.6461		1.166	1.3717		1.6461	
18	1.0631	1.1694	.9945	.8916	1.3957	1.3717	1.094
19	1.0974		1.0288	.823		1.2346	
20	.9259		.7202	.7545		.823	
21	.8916	.9054	.8916	.7202	.8676	.823	.8676
22	1.0288		1.3032	1.0631		1.166	
23	1.3717		1.3032	1.2346		1.3032	
24	1.3717	1.3375	1.4712	1.3032	1.3032	1.5844	1.2346
Max	1.8861	2.0748	1.5089	1.6461	1.8484	2.1262	1.8861
Min	.8916	.9054	.7202	.7202	.8573	.823	.823
Avg	1.2808	1.3056	1.1965	1.1403	1.1851	1.4698	1.1409

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283027 / 22/22KV Rabale MIDC Swt/stn

Feeder No / Name : 308 / TECHNOPROCESS (R.M.U. R- SHEDDABLE FEEDER HAVING WEEKLY
260) Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.166	1.6461		1.3717	1.5432		1.3717
2	1.0288	1.5432		1.2346	1.5089		1.2346
3	.9602	1.5089	.5658	1.0288	1.4403	1.1317	1.166
4	.9259	1.3717		.9602	1.2346		1.0288
5	.823	1.1317		.9259	1.2003		1.2346
6	1.0288	1.2689	.9808	1.0288	1.0974	1.1317	1.3717
7	1.166	.9945		1.166	1.166		1.4403
8	1.3032	.8916		1.2689	1.5775		1.3717
9		.8916	2.1125	2.4006	1.8861	1.9993	
10	2.5377		2.1605	2.6063		2.1948	
11	2.7435		2.0576	2.6749		2.572	
12	2.4006	1.2449	1.9204	2.6749	2.8292	2.4691	2.452
13	1.8861		1.749	1.4746		2.4006	
14	2.4348		1.7147	2.6063		2.332	
15	2.4348	1.3957	1.7147	2.6063	2.6029	2.2634	3.3196
16	2.332		1.7833	3.0521		2.1948	
17	2.2291		1.8519	2.4006		2.1605	
18	2.0576	1.2071	1.9547	2.0576	2.6029	2.0576	2.8669
19	1.8861		1.7147	2.0233		1.9204	
20	1.749		1.6118	1.6461		1.5089	
21	1.6804	1.0562	1.406	1.7147	1.773	1.5089	2.2634
22	1.7147		1.5089	1.5089		1.4403	
23	1.4403		1.166	1.5432		1.3717	
24	1.2689	1.7833	1.0562	1.4746	1.6804	1.6598	1.3717
Max	2.7435	1.7833	2.1605	3.0521	2.8292	2.572	3.3196
Min	.823	.8916	.5658	.9259	1.0974	1.1317	1.0288
Avg	1.7042	1.2811	1.6128	1.8104	1.7245	1.9065	1.7302

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 301 / 22 KV KALWA - I

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.4979	3.2579	3.3951	3.1893	2.915	2.8464	3.1893
2	3.4294	2.9835	3.1893	3.0864	2.7092	2.7092	3.0864
3	3.5665	2.7435	3.0521	3.0178	2.7435	2.572	3.0178
4	3.4637	3.3265	2.915	2.915	3.0178	2.5034	3.1207
5	3.5322	3.7723	2.7435	2.7435	3.4979	2.7435	3.3265
6	3.8409	3.9438	3.3265	3.0864	3.7037	3.1893	3.6008
7	4.1152	4.0124	3.6008	3.3265	3.7723	3.6694	3.738
8	4.5953	4.1838	3.9095	3.8409	3.8752	3.9095	3.9781
9	3.9438	3.7037	3.7723	4.0124	3.6008	3.7723	3.738
10	3.4294	3.2922	3.5665	4.0809	3.3608	3.6694	3.3951
11	2.9835	1.3717	3.1893	3.3951	2.915	3.3608	
12	2.915	1.3032	3.0178	3.2922	2.7435	2.9492	
13	2.915		2.7435	3.0864	2.6063	2.7435	
14	2.9492	1.2003	2.7435	2.9835	2.5377	2.6063	
15	2.7435	.9945	2.7092	2.8807	2.4691	2.4691	
16	2.6063	.9945	2.6063	2.7435	2.4691	2.4691	
17			2.7778	2.8807	2.572	2.6406	2.7435
18		3.738	3.1893	3.2922	2.8121	2.9835	3.1893
19		4.1152	4.0466	3.9438	3.9438	3.8752	4.1152
20	4.1152	4.5268	4.1838	3.9438	3.9781	3.9781	
21	4.3896	4.4239	4.0466	4.0809	3.9095	3.8752	
22	4.2867	4.1838	3.9781	3.9438	3.8066	3.8409	4.2181
23	4.0466	3.9438	3.738	3.6008	3.3951	3.5665	3.9781
24	3.5665	3.4294	3.4294	3.2922	3.2579	2.915	3.2579
Max	4.5953	4.5268	4.1838	4.0809	3.9781	3.9781	4.2181
Min	2.6063	.9945	2.6063	2.7435	2.4691	2.4691	2.7435
Avg	3.5682	3.1566	3.3279	3.3608	3.1922	3.1607	3.4808

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 302 / 22 KV Airoli -1(O/G)

SHEDDABLE URBAN

Feeder KV- 22 / INCOMING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.5844	5.6584	5.2469	4.0466	4.0124	3.8752	4.2867
2	6.5158	5.5556	5.144	3.9438	3.9095	3.738	4.1152
3	6.4472	5.4184	5.0755	3.8752	3.8409	3.6694	4.2181
4	6.3443	5.2126	4.9726	3.7723	3.738	3.4637	4.0466
5	6.5158	6.0014	5.144	3.8409	3.9095	4.0466	4.0124
6	6.5844	6.1728	5.5899	3.738	4.0466	4.7668	3.9438
7	6.653	6.7215	5.8299	3.8752	5.0412	5.2126	5.0069
8	6.653	6.7215	6.0357	4.1495	5.4184	5.487	5.6584
9	6.8244	7.2017	5.8299	4.1152	5.5213	5.4184	5.3155
10	7.0988	7.2017	5.4527	4.1152	5.4184	5.3498	5.487
11	6.9616	6.7901	5.487	4.4582	5.487	5.0755	
12	7.2017	6.31	4.1838	4.0809	5.2812	5.0069	
13	7.0302	5.7956	4.1495	4.0466	5.0755	4.6982	
14	6.3443	6.0014	3.9095	3.6008	4.9726	4.4925	
15	6.3443	6.4815	4.0124	3.4979	4.9383	4.3896	
16	6.4472	6.5501	3.8752	3.5322	4.8354	4.321	
17		6.4472	4.0466	3.9781	5.144	4.6296	5.6584
18		6.3443	4.4925	4.4239	5.4527	5.1783	5.7613
19		7.3731	5.5899	5.0412	6.1728	6.1043	6.6873
20	7.6132	7.1331	5.9328	5.2812	6.4129	5.6584	
21	7.5789	7.3731	5.5899	4.9383	5.8985	5.1097	
22	7.0302	6.8244	4.9726	4.8697	5.2469	5.0755	5.6927
23	6.6873	6.1386	4.6296	4.5953	4.6639	4.6639	5.5213
24	6.7558	5.8642	5.4184	4.1152	4.4239	3.9095	4.3896
Max	7.6132	7.3731	6.0357	5.2812	6.4129	6.1043	6.6873
Min	6.3443	5.2126	3.8752	3.4979	3.738	3.4637	3.9438
Avg	6.7722	6.3872	5.0255	4.1638	4.9526	4.7225	4.9876

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 303 / 22 KV Airoli - II

Feeder KV- 22 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6749	2.6749	2.6749	2.4691	2.2291	2.4348	2.4006
2	2.572	2.572	2.572	2.4006	2.1262	2.4006	2.332
3	2.5377	2.4691	2.5034	2.332	2.0576	2.332	2.2634
4	2.4691	2.4006	2.4006	2.2634	2.1605	2.2291	2.1605
5	2.4006	2.7435	2.2977	2.4006	2.2291	2.6063	2.2977
6	2.572	2.9492	2.6749	2.5034	2.4006	2.8464	2.4006
7	2.8464	2.9492	2.915	2.6063	2.9835	3.0864	2.7435
8	3.3951	3.0178	3.3951	2.8807	3.2579	3.4294	3.2236
9	3.3265	3.1893	3.6008	3.1207	3.2922	3.6008	3.2922
10	3.7037	3.3608	3.8066	3.2922	3.6008	3.5665	3.7037
11	3.6694	2.7778	3.6351	3.155	3.7037	3.5665	
12	3.7723	2.5377	3.2922	3.0864	3.4637	3.2922	
13	3.4294	2.2977	2.9492	2.7435	2.9835	3.0178	
14	3.6008	2.2291	3.0178	2.8807	3.0864	3.155	
15	3.3265	2.2977	2.8807	2.8807	3.1893	2.9492	
16	3.6008	2.4691	2.9492	2.8121	3.3265	2.7435	
17		2.4691	2.915	2.8807	3.0864	2.4691	3.4294
18		2.4691	2.8121	2.1948	2.4691	2.4006	2.915
19		2.5377	2.8464	2.4006	2.8807	2.7435	3.4294
20	2.7435	2.4691	2.572	2.2634	2.6063	2.572	
21	2.915	2.332	2.6063	2.1262	2.332	2.4348	
22	2.9492	3.0521	2.4691	2.4006	2.2977	2.4348	2.9492
23	2.915	2.5034	2.6063	2.572	2.5377	2.2291	2.7435
24	2.7435	2.8807	2.7778	2.5377	2.332	2.5034	2.4691
Max	3.7723	3.3608	3.8066	3.2922	3.7037	3.6008	3.7037
Min	2.4006	2.2291	2.2977	2.1262	2.0576	2.2291	2.1605
Avg	3.0554	2.6520	2.8821	2.6335	2.7764	2.7935	2.7971

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 304 / 22 KV Rabale MIDC

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0576	2.332	1.7147	1.989	2.1262	2.0576	2.1605
2	1.9547	2.2291	1.6118	1.9547	2.0233	1.989	2.2291
3	1.8861	2.0576	1.5432	1.7833	1.8176	1.8861	2.0576
4	1.8176	1.9204	1.4746	1.7147	1.9204	1.7833	2.0919
5	1.749	1.989	1.5775	1.8176	1.9204	1.989	1.9547
6	1.9547	2.0233	1.8861	1.9204	1.9547	2.1605	1.989
7	2.0576	1.9204	1.989	2.0233	2.1262	2.2634	1.9204
8	2.572	2.0576	2.0919	2.0576	2.2977	2.4006	2.4006
9	3.0521	2.1262	2.572	2.7092	3.1207	2.7092	3.0864
10	3.6351	2.2634	3.3608	3.1893	3.5322	3.3608	3.3951
11	4.2524	2.4691	3.6694	3.3608	3.7037	3.6351	
12	4.0466	2.2291	3.8066	3.1207	3.5322	3.4294	
13	2.9492	2.0233	2.6749	2.4691	2.7435	2.7435	
14	3.9438	2.2291	3.6351	3.2922	3.3608	3.6351	
15	3.9438	2.4691	3.7037	3.0864	3.738	3.5665	
16	4.1152	2.4006	3.8409	3.1207	3.7723	3.6008	
17		2.0576	3.3608	3.0521	3.4979	3.4294	3.7037
18		1.6461	3.6351	2.6406	3.3951	3.0178	3.4294
19		1.9204	3.0864	2.6406	2.8464	2.6063	3.2922
20	3.0521	1.9204	2.6406	2.915	2.6063	2.6749	
21	2.8807	2.0576	2.572	2.2977	2.5034	2.2634	
22	2.4691	1.989	2.2291	2.0919	2.4348	2.2291	2.4348
23	2.4691	1.8861	2.1605	2.0576	2.0919	2.1605	2.2634
24	2.1948	2.4348	1.8176	2.0919	2.1605	2.1262	2.2634
Max	4.2524	2.4691	3.8409	3.3608	3.7723	3.6351	3.7037
Min	1.749	1.6461	1.4746	1.7147	1.8176	1.7833	1.9204
Avg	2.8121	2.1105	2.6106	2.4749	2.7178	2.6549	2.5420

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 305 / 22 KV Ghansoli

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.727	5.0755		5.0412	5.0069	4.5953	4.9726
2	5.5556	4.8011	5.0412	4.904	4.904	4.4239	4.8011
3	5.2812	4.6639	4.9726	4.8011	4.8011	4.321	4.7325
4	5.4184	4.9726	4.8011	4.7325	5.0755	4.2181	4.6296
5	6.0357	6.1728		4.904	5.487	5.3498	4.6982
6	6.6187	7.2702	6.0357	5.8985	6.5844	6.4472	6.5844
7	7.5446	7.5446	6.7901	6.4472	7.5789	7.0988	7.2702
8	7.8875	7.7161	8.2305	7.5446	7.5789	7.8532	7.6818
9	7.4417	6.5501	6.9616	7.6475	6.8587	7.0988	7.0645
10	6.31	6.0014	6.2414	7.0302	6.0357	6.4472	6.2414
11	5.7613	5.2126	5.487	5.6242	5.2469	5.6242	
12	4.9726	5.0412	4.8011	5.2812	5.0069	4.9383	
13	4.8011	4.561	4.5268	5.2126	4.2867	4.5953	
14	4.6982	4.4582	4.2524	4.8011	4.1152	4.2867	
15	4.5268	4.2524	4.4582	4.4239	3.9781	4.1495	
16	4.6296	4.2524	4.4582	4.4239	4.1152	4.1152	
17		4.3553	4.561	4.7325	4.6639	4.3896	4.8011
18		4.7668	4.9383	5.487	4.904	5.0069	5.0412
19		6.4129	6.5501	6.1728	6.7558	6.5501	6.893
20	7.0302	6.7901	6.9959	6.7215	6.9959	6.7558	
21	7.0988	6.7215	6.8587	6.8587	6.8587	6.3786	
22	7.0302	6.2757	6.6873	6.3443	6.4472	6.3786	7.1331
23	6.2757	5.7613	5.8299	5.7956	5.487	5.5899	6.3786
24	5.7613	5.4184	5.144	5.1097	5.0755	4.7325	5.0755
Max	7.8875	7.7161	8.2305	7.6475	7.5789	7.8532	7.6818
Min	4.5268	4.2524	4.2524	4.4239	3.9781	4.1152	4.6296
Avg	6.0193	5.6270	5.6647	5.6642	5.5770	5.4727	5.8749

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 306 / 22 KV Railway -II

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 22 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.4458	.4115	.4115	.4115	.4115	.4115
2	.4115	.4458	.4115	.4115		.4115	.4115
3	.4115		.4115	.4115		.4115	.4115
4	.4115		.4115	.4115		.4115	.4115
5	.4115		.4115	.4115	.4115	.4115	.4115
6	.4115		.4115	.4115		.4115	.4115
7	.4115		.4115	.4115	.4115	.4115	.4115
8	.4115		.4115	.4115	.4115	.4115	.4115
9	.4115		.4115	.4115	.4115	.4115	.4115
10	.4115	.4115	.4115	.4115		.4115	.4115
11	.4115	.4458	.4115		.4115	.4115	
12	.4458	.4458	.4115		.4115	.4115	
13		.4458	.4115		.4115	.4115	
14		.4115	.4115		.4115	.4115	
15	.4115	.4115	.4115	.4115	.4458	.4115	
16	.4115	.4458	.4458	.4115	.4115	.4115	
17			.4115		.4115	.4115	.4115
18		.4458	.4115	.4115	.4115	.4115	.4115
19		.4458	.4458	.4458	.4458	.4458	.4458
20	.4458	.4458	.4458	.4458	.4115	.4115	
21	.4458	.4115	.4458		.4115	.4115	
22	.4458	.4115	.4115		.4458	.4115	.4458
23	.4115	.4458	.4115	.4115	.4115	.4115	.4458
24	.4115		.4115	.4115	.4115	.4115	.4115
Max	.4458	.4458	.4458	.4458	.4458	.4458	.4458
Min	.4115	.4115	.4115	.4115	.4115	.4115	.4115
Avg	.4187	.4344	.4172	.4155	.4169	.4129	.4179

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 309 / 22 KV Railway -I

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8519	1.7147	1.7147	1.6118	1.7147	1.3717	1.6461
2	1.7147	1.6804	1.5432	1.5432	1.6804	1.3375	1.5432
3	1.6461	1.6118	1.4403	1.5775	1.5432	1.2689	1.5775
4	1.5432	1.9204	1.3032	1.6118	1.6118	1.2003	1.5089
5	1.9204	1.989	1.5775	1.7147	1.6804	1.5775	1.6804
6	1.9204	2.2634	1.7147	1.8861	1.989	1.8861	1.989
7	2.4348	2.2634	1.9547	1.989	2.4006	2.0919	2.2291
8	2.4691	2.2977	2.332	2.0576	2.4006	2.332	2.4006
9	2.2634	1.989	2.2291	2.0919	2.0233	2.1605	2.1262
10	1.989	1.989	2.1262	2.2977	1.9547	1.989	2.0576
11	1.8861	1.8176	1.9204	1.9204	1.8519	1.9204	
12	1.7147	1.7147	1.7147	1.9204	1.7147	1.749	
13	1.7147	1.5089	1.7147	1.7147	1.5432	1.5775	
14	1.6461	1.3717	1.5089	1.4403	1.3717	1.6118	
15	1.3717	1.2003	1.3375	1.3032	1.2689	1.2346	
16	1.406	1.2346	1.3717	1.3717	1.2689	1.2689	
17		1.406	1.5432	1.5432	1.3717	1.4746	1.5775
18		1.3717	1.6118	1.749	1.4746	1.5775	1.5775
19		1.989	2.0576	2.0233	2.0919	1.9204	2.0576
20	2.2634	2.1948	2.2634	2.2634	2.1948	2.1948	
21	2.2291	2.2634	2.2634	2.2634	2.0919	2.332	
22	2.2634	2.332	2.1605	2.2291	2.1605	2.2977	2.572
23	2.0576	2.1948	2.1948	2.2291	1.8861	1.989	2.4006
24	1.989	1.7833	1.8176	1.7147	1.749	1.4746	1.7147
Max	2.4691	2.332	2.332	2.2977	2.4006	2.332	2.572
Min	1.3717	1.2003	1.3032	1.3032	1.2689	1.2003	1.5089
Avg	1.9188	1.8376	1.8090	1.8361	1.7933	1.7433	1.9162

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 310 / 22 KV HINDALCO INCOMER TO NON SHEDDABLE EXPRESS HV FEEDERS
22/1 Feeder KV- 22 / INCOMING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9602	.9602	.9259	.8573	.8573	.823	.9259
2	.9259	.9259	.8573	.8916	.823	.7888	.9602
3	.8573	.8916	.823	.823	.7888	.7202	.8916
4	.8916	.9945	.7888	.7888	.8916	.7545	.9259
5	.823	1.0288	.823	.8573	.9602	.8916	.9602
6	.9602	1.0974	1.0288	.9259	1.0288	.9602	.9602
7	1.1317	1.0974	1.0631	.9602	1.0974	1.0631	1.0631
8	1.2689	1.2346	1.8176	1.0631	1.1317	1.166	1.2346
9	1.2346	1.2346	1.2689	1.166	1.2346	1.1317	1.2003
10	1.2346	1.2346	1.2346	1.3032	1.2003	1.2003	1.1317
11	1.166	1.166	1.2003	1.0631	1.0631	1.0974	
12	1.1317	1.1317	1.0631	1.0974	.9945	.9945	
13	1.0974	1.0631	1.0288	1.0288	.9259	.9602	
14	1.0288	.9602	.9602	.9602	.8916	.8573	
15	.9259	.8916	.8573	.8573	.8573	.823	
16	.9602	.8916	.8573	.823	.8916	.8573	
17		.9602	.8916	.8916	.9602	.8573	.9945
18		.8916	1.0288	1.0288	.9259	.9945	1.0974
19		1.2346	1.2346	1.2003	1.2346	1.2689	1.406
20	1.3717	1.2346	1.2689	1.3032	1.2346	1.2689	
21	1.3717	1.2003	1.2689	1.2346	1.2346	1.1317	
22	1.2003	1.0974	1.166	1.0974	1.0974	1.0974	1.166
23	.9945		1.0288	1.0288	.9602	1.0288	1.0974
24	1.0288	.9602	.9602	.9259	.8916	.8573	.9602
Max	1.3717	1.2346	1.8176	1.3032	1.2346	1.2689	1.406
Min	.823	.8916	.7888	.7888	.7888	.7202	.8916
Avg	1.0745	1.0601	1.0602	1.0074	1.0074	.9831	1.0610

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 311 / 22 KV Cidco II

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	1.3375	1.6461	1.6118	1.5432	2.5034	1.5432
2	1.6118	1.3375	1.4746	1.5432	1.4403	1.3717	1.4746
3	1.5432	1.3032	1.3717	1.4746	1.3717	1.2689	1.4403
4	1.3717	1.3375	1.3375	1.3717	1.6461	1.2346	1.3717
5	1.4403	1.5432	1.5775	1.5089		1.3717	1.5089
6	1.6118	1.9547	1.6118	1.5775	1.7833	1.6118	1.749
7	1.7833	1.9204	1.7833	1.6461	1.8861	1.7147	1.989
8	1.9547	1.9204	1.7147	1.8519	1.8519	1.7833	2.1605
9	1.9204	1.7833	1.6461	1.8519	1.8861	1.8861	1.9204
10	1.8519	1.6461	1.5775	1.8519	1.8176	1.9204	1.989
11	1.8176	1.749	1.749	1.8176	1.5775	1.8176	
12	1.9204	1.8176	1.8176	1.989	1.6118		
13	1.6118	1.7833	1.6804	1.8519	1.6804	1.3717	
14	1.5432	1.7833	1.3032	1.4403	1.5432	1.4403	
15	1.4403	1.7147	1.3717	1.5432	1.3717	1.166	
16	1.4746	1.3717	1.3717	1.4403	1.3375	1.0974	
17	1.4403	1.4403	1.2346	1.2003	1.2346	1.2689	1.5432
18	1.406	1.4746	1.5432	1.4746	1.166	1.2003	1.5089
19	1.7147	1.6804	1.7833	1.9204	1.8519	1.5432	1.7147
20	2.0919	1.9204	2.0576	2.1605	1.989	1.989	
21	1.749	1.7833	1.9204	1.989	1.989	1.6461	
22	1.7147	1.6461	1.7833	1.7147	1.749	1.6118	1.989
23	1.5775	1.6461	1.8176	1.989	1.749	1.7833	1.8519
24	1.7833	1.6461	1.7833	1.6461	1.6118	1.5775	1.6118
Max	2.0919	1.9547	2.0576	2.1605	1.989	2.5034	2.1605
Min	1.3717	1.3032	1.2346	1.2003	1.166	1.0974	1.3717
Avg	1.6704	1.6475	1.6232	1.6861	1.6386	1.5730	1.7104

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 312 / 22 KV Vodafone

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.4746	1.2346	.9602	1.0974
2		1.3717	1.2003	.8916	1.0288
3		1.3032		.8573	.9602
4		1.0974		.9602	.9259
5		1.2346		.9945	1.0631
6		1.3375		1.0288	1.0288
7		1.3717		1.1317	1.0288
8		1.0288		1.0631	1.406
9		1.0631		1.1317	1.4403
10		1.0974	1.5089	1.5089	1.0974
11		1.5432	1.5089	1.3717	
12	1.0974	1.4746	1.3717	1.0974	
13	1.4746	1.3717	1.0974	1.0631	
14	1.3717	1.0974	1.1317	1.0631	
15	1.0974	1.0974	1.0974	1.0974	
16	1.0974	1.0631	1.5432	1.5432	
17	1.0974	1.4746	1.3717	1.406	1.1317
18	1.4746	1.3717	1.0974	1.0974	1.0631
19	1.3717	1.0974	1.0974	1.0974	1.0974
20	1.0974	1.0631	1.0631	1.4403	
21	1.0631	1.0631	1.0631	1.3717	
22	1.0631	1.0631	1.5089	1.3717	1.3717
23	1.0631	1.5432	1.3717	1.0631	1.0631
24		1.5432	1.3375	1.0288	1.0288
Max	1.4746	1.5432	1.5432	1.5432	1.4403
Min	1.0631	1.0288	1.0631	.8573	.9259
Avg	1.1974	1.2603	1.2709	1.1517	1.1145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641] BU 4641

Substation No/ Name :- 289005 / 400/220/100/22 KV Kalwa SS

Feeder No / Name : 808 / 220 KV Kalwa Siemens NON SHEDDABLE EHV INDUSTRIAL FEEDERS
Feeder KV- 220 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING

DATE	10-FEB-18
HR	Load (MW)
16	17.1468
Max	17.1468
Min	17.1468
Avg	17.1468

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 202 / 11 KV Reliance

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.4954	.4954	.4763	.4763	.4763	
2	.5144	.4954	.4954	.4763	.4763	.4763	.4954
3	.5144	.4763	.4954	.4954	.4763	.4572	.4954
4	.5335	.4763	.4954	.4763	.4572	.4572	.5144
5	.5144	.4763	.5144	.4954	.4572	.4763	.5144
6	.6097	.4954	.5335	.5335	.4763	.5144	.5335
7		.5335	.5716	.5716	.5335	.5716	.6287
8	.724	.6668	.6478	.5716	.6097	.6478	.6478
9	.7621	.6668	.6668	.5525	.6859	.743	.7049
10	.9526	.8192	.6668	.5335	.8192	.8383	.8383
11	.9717	.8573	.6478	.4954	.8764	.9145	.9907
12	.9717	.8383	.7049	.4954	.9145	.9145	.8954
13	.9145	.8383	.6287	.4763	.8573	.743	.8954
14	.8764	.8764	.6287	.4572	.8383	.8192	.9145
15	.9717	.9145	.6287	.4763	.8764	.8764	.9526
16	.9717	.8954	.6859	.4572	.9145	.8954	.9907
17	.9717	.8954	.6287	.4572	.8764	.8764	.9907
18	.8764	.8383	.5906	.4763	.8764	.8002	.9526
19	.9145	.7811	.6859	.6097	.8002	.8192	.9145
20	.8192	.7049	.6287		.7621	.7049	.8383
21	.743	.6478	.6097	.5906	.7049	.6478	.7621
22	.6859	.6097	.5525	.5716	.6097	.5716	.6859
23	.5906	.5525	.5144	.5335	.5525	.5525	.5906
24	.5525	.5144	.5144	.4763	.4954	.4954	.5144
Max	.9717	.9145	.7049	.6097	.9145	.9145	.9907
Min	.5144	.4763	.4954	.4572	.4572	.4572	.4954
Avg	.7596	.6819	.5930	.5111	.6843	.6787	.7505

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 203 / 11 KV Mastek MBP s/stn NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.362	.3429	.362	.3429	.362	.362
2	.381	.362	.3239	.362	.3429	.3429	.3429
3	.381	.3429	.3239	.381	.3239	.3429	.3429
4	.362	.3429	.3239	.381	.3239	.3429	.362
5	.362	.3429	.3239	.362	.3239	.3429	.381
6	.362	.381	.3239	.381	.3429	.362	.381
7		.4572	.3429	.381	.4382	.381	.4191
8		.6097	.3429	.362	.6287	.5716	.7621
9	.8192	.7811	.4001	.362	.7621	.6668	.724
10	.7811	.7811	.4001	.381	.8002	.6859	.7621
11	.8192	.8002	.5335	.362	.7811	.724	.7811
12	.7811	.6859	.5525	.381	.8002	.724	.8002
13	.8192	.743	.5335	.362	.7811	.7621	.8002
14	.7811	.7621	.5335	.381	.7621	.743	.8002
15	.7811	.7811	.5525	.362	.7811	.7811	.8002
16	.8764	.743	.4763	.362	.6859	.7621	.8002
17	.8002	.743	.4382	.362	.8002	.7811	.8192
18	.724	.6097	.4191	.362	.5906	.743	.7621
19	.6287	.5525	.2667	.3429	.5716	.743	.5906
20	.5525	.5335	.4001		.5335	.5335	.4954
21	.5144	.4572	.4001	.362	.4954	.4382	.4191
22	.4382	.4191	.381	.3429	.4763	.4191	.4191
23	.4382	.4001	.4001	.3239	.4191	.4001	.4001
24	.4001	.362	.362	.381	.3429	.381	.4001
Max	.8764	.8002	.5525	.381	.8002	.7811	.8192
Min	.362	.3429	.2667	.3239	.3239	.3429	.3429
Avg	.5993	.5565	.4041	.3653	.5604	.5557	.5803

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 204 / 11 KV Hexaware MBP s/stn NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1905	.1715	.1715	.1715	.2096
2	.1905	.1905	.1905	.1715	.1524	.1715	.2096
3	.1905	.1905	.1715	.1715	.1524	.1715	.2096
4	.1905	.1905	.1715	.1715	.1524	.1524	.1905
5	.1905	.1905	.1715	.0953	.1715	.1715	.1715
6	.1905	.2286	.1715	.1524	.1905	.1715	.1715
7	.3048	.2667	.1905	.1715	.2286	.1715	.2096
8	.4001	.3239	.2286	.1905	.2667	.2286	.3429
9	.4572	.4191	.2286	.2096	.4191	.4382	.4572
10	.4572	.4382	.2667	.2096	.4001		.4572
11	.4763	.4572	.3048	.2096	.4382	.4572	.4572
12	.4763	.4382	.3239	.2286	.4191	.4763	.4954
13	.5335	.4763	.2858	.2286	.4763	.4572	.4954
14	.4954	.4001	.3239	.2286	.4763	.4572	.5144
15	.4954	.4382	.381	.2286	.4572	.4382	.4572
16	.4954	.4382	.3239	.2477	.4763	.4572	.4572
17	.4954	.4382	.2858	.2286	.4763	.5144	.5144
18	.4572	.4382	.2667	.2096	.4001	.4191	.4954
19	.4001	.362	.2477	.1905	.362	.362	.4572
20	.3429	.3239	.2286		.3048	.3239	.381
21	.3048	.2667	.1905	.1905	.2667	.2667	.3048
22	.2667	.2477	.2096	.2096	.2286	.2667	.3048
23	.2477	.2286	.1905	.1905	.2286	.2477	.2667
24	.1905	.1905	.2096	.1905	.1715	.2096	.2286
Max	.5335	.4763	.381	.2477	.4763	.5144	.5144
Min	.1905	.1905	.1715	.0953	.1524	.1524	.1715
Avg	.3517	.3239	.2397	.1955	.3120	.3131	.3525

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 205 / 11 KV Life Cycle

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.3239	.3239	.3239	.3048	.3048	.3239
2	.3239	.3239	.3239	.3239	.3048	.3048	.3048
3	.3239	.3048	.3048	.3048	.3048	.3048	.2858
4	.3239	.3048	.3048	.2858	.3048	.2858	.2667
5	.3048	.3048	.3048	.2667	.2858	.2858	.2667
6	.2858	.3048	.3239	.2477	.3048	.3048	.2858
7	.3429	.362	.3429	.362	.3429	.3239	.3429
8	.4001	.4001	.362	.362	.4001	.4001	.4382
9	.4572	.4382	.362	.3429	.5144	.4382	.4763
10	.5144	.4954	.4191	.3429	.5144	.4763	.5335
11	.4763	.5525	.4001	.3429	.4954	.5144	.5335
12	.4954	.5525	.4572	.3429	.4954	.5144	.5335
13	.4763	.5335	.4382	.3429	.5144	.5144	.5144
14	.5144	.5144	.4763	.3429	.5144	.5144	.5716
15	.5335	.5525	.4954	.362	.5144	.5525	.6097
16	.5144	.5525	.4382	.362	.5335	.5144	.6287
17	.5144	.5716	.4191	.362	.4954	.5906	.6097
18	.5144	.5144	.381	.3429	.4763	.4763	.6097
19	.5144	.5335	.4191	.4001	.5525	.5525	.5716
20	.4954	.5144	.4382		.5144	.4572	.5716
21	.4763	.4763	.4191	.4382	.4763	.4191	.5335
22	.4382	.4382	.4191	.4572	.4001	.4001	.5335
23	.4001	.4001	.381	.4382	.362	.3429	.4954
24	.3239	.3429	.3429	.362	.3048	.3048	.2858
Max	.5335	.5716	.4954	.4572	.5525	.5906	.6287
Min	.2858	.3048	.3048	.2477	.2858	.2858	.2667
Avg	.4287	.4422	.3874	.3504	.4263	.4207	.4636

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 206 / 11 KV Aptech

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3239	.3048	.2667	.2667	.3239	.3429
2	.3239	.3239	.2858	.2667	.2667	.3048	.3048
3	.3239	.3048	.2858	.2477	.2477	.3048	.2858
4	.3048	.3048	.2858	.2667	.2477	.3048	.2667
5	.3239	.3048	.2858	.2477	.2477	.3048	.2667
6	.4572	.3239	.2858	.2477	.2667	.362	.2858
7	.5716	.4572	.2858	.2477	.4382	.4572	.5144
8	.6287	.5716	.2858	.2286	.6097	.5525	.5335
9	.7049	.6287	.362	.2477	.6859	.6859	.7049
10	.8764	.8383	.4191	.3048	.8954	.8573	.9145
11	.9717	.9145	.4954	.2858	.9145	.8573	.9335
12	.9907	.9145	.5144	.3048	.9145	.8764	1.0479
13	1.0098	.9145	.5906	.2858	.9526	.9145	.9907
14	.9526	.9145	.6097	.2858	.9717	.8764	1.0479
15	.9717	.9526	.6097	.3048	.9335	1.0669	1.086
16	.9907	.9717	.6097	.2858	.9717	1.0098	1.086
17	.9907	.8764	.5716	.2858	.9335	.8954	1.0479
18	.8192	.8383	.5335	.2667	.7811	.8764	.9526
19	.7049	.6478	.4191	.3048	.6668	.7621	.724
20	.5906	.5525	.381	.2858	.6097	.6287	.6097
21	.4382	.4191	.3429	.2667	.5335	.5335	.4763
22	.381	.4001	.3239	.3048	.4001	.381	.4572
23	.362	.3429	.2858	.2858	.3429	.381	.381
24	.3429	.3429	.3239	.2667	.2667	.3048	.3048
Max	1.0098	.9717	.6097	.3048	.9717	1.0669	1.086
Min	.3048	.3048	.2858	.2286	.2477	.3048	.2667
Avg	.6390	.5993	.4041	.2747	.5986	.6176	.6486

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 207 / 11 KV ML Tower

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0953	.0953	.0953	.0953	.0953
2	.0953	.0953	.0953	.0953	.0953	.0953	.0953
3	.0953	.0953	.0953	.0953	.0953	.0953	.0953
4	.0953	.0953	.0953	.0953	.0953	.0953	.0953
5	.0953	.0953	.0953	.0953	.0953	.0953	.0953
6	.0953	.0953	.0953	.0953	.0953	.0953	.0953
7	.0953	.0953	.0953	.2286	.0953	.0953	.0953
8	.0953	.0953	.0953	.0953	.0953	.0953	.0953
9	.4001	.381	.1715	.0953	.4191	.0953	.4191
10	.381	.4001	.3429	.0953	.362	.0953	.362
11	.362	.3429	.2858	.0953	.381	.0953	.3239
12	.3239	.3239	.2667	.0953	.3048	.0953	.2477
13	.3048	.3048	.2286	.0953	.3048	.0953	.2477
14	.3239	.3048	.2477	.0953	.3048	.0953	.3239
15	.3048	.3239	.2477	.0953	.3239	.0953	.3239
16	.2858	.3048	.2477	.0953	.3239	.0953	.3048
17	.3048	.3239	.2096	.0953	.3239	.0953	.3239
18	.2858	.2858	.1905	.0953	.3239	.0953	.3048
19	.2286	.1905	.0953	.0953	.2477		.2286
20	.1524	.0953	.0953	.0953	.1715	.0953	.1905
21	.0953	.0953	.0953	.0953	.0953	.0953	.0953
22	.0953	.0953	.0953	.0953	.0953	.0953	.0953
23	.0953	.0953	.0953	.0953	.0953	.0953	.0953
24	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Max	.4001	.4001	.3429	.2286	.4191	.0953	.4191
Min	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Avg	.2001	.1969	.1572	.1009	.2056	.0953	.1977

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 208 / 11 KV core project

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.2096	.2096	.2286	.2096	.2096	.2286
2	.2096	.1905	.1905	.2286	.1905	.2096	.2096
3	.2096	.1905	.1905	.2286	.1905	.1905	.2096
4	.2096	.1905	.1905	.2286	.1905	.1905	.2286
5	.2096	.1905	.1905	.2286	.1905	.2096	.2286
6	.2286	.2096	.2096	.2286	.1905	.2096	.2286
7	.2286	.2096	.2286	.2286	.2096	.2286	.2286
8	.2286	.2286	.2286	.2477	.2286	.2096	.2477
9	.2667	.2286	.2286	.2477	.2858	.2477	.2667
10	.362	.3239	.2286	.2286	.3239	.2858	.3429
11	.381	.362	.2477	.2286	.4001	.362	.4191
12	.362	.3429	.2477	.2286	.362	.3429	.362
13	.4191	.3429	.2667	.2286	.3429	.3429	.3239
14	.381	.4001	.2667	.2286	.381	.381	.4382
15	.4001	.381	.2477	.2286	.381	.362	.4382
16	.4382	.362	.2667	.2286	.3239	.4001	.4382
17	.4001	.4001	.2286	.2286	.381	.362	.381
18	.3429	.3239	.2477	.2096	.381	.3429	.3429
19	.3048	.3048	.2286	.2096	.2858	.2667	.3048
20	.2858	.2477	.2096	.2096	.2667	.2477	.2858
21	.2477	.2286	.2096	.2096	.2477	.2286	.2477
22	.2477	.2286	.2286	.2096	.2096	.2286	.2286
23	.2286	.2286	.2096	.2096	.2096	.2286	.2096
24	.2096	.2096	.2096		.2096	.2096	.2286
Max	.4382	.4001	.2667	.2477	.4001	.4001	.4382
Min	.2096	.1905	.1905	.2096	.1905	.1905	.2096
Avg	.2921	.2723	.2254	.2253	.2747	.2707	.2945

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 211 / 11 KV Rupa HT SS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3048	.3048	.3048	.3048	.3048	.3048
2	.3048	.3048	.3048	.3048	.3048	.3048	.3048
3	.3048	.3048	.3048	.3048	.3048	.3048	.3048
4	.3048	.3048	.3048	.3048	.3048	.3048	.3048
5	.3048	.3048	.3048	.3048	.3048	.3048	.3048
6	.3048	.3048	.3048	.3048	.3048	.3048	.3048
7	.3048	.3048	.3048	.3048	.3239	.3048	.3048
8	.3048	.3048	.3048	.3048	.3429	.3239	.3048
9	.4191	.4001	.3429	.3048	.4572	.4001	.4191
10	.4763	.4191	.3239	.3048	.4572	.4382	.4382
11	.4572	.4763	.4001	.3048	.4572	.4763	.4572
12	.4763	.4572	.362	.3048	.4191	.4572	.4572
13	.4763	.4382	.362	.3048	.4382	.4382	.4191
14	.4572	.4572	.362	.3048	.4382	.4763	.4382
15	.4763	.4763	.362	.3048	.4572	.4954	.4572
16	.5144	.4572	.3239	.3048	.4382	.4572	.4572
17	.4572	.4763	.3239	.3048	.4572	.4191	.4572
18	.4572	.4572	.3429	.3048	.4382	.4191	.4191
19	.4001	.4001	.3048	.3048	.4191	.4001	.4001
20	.362	.381	.3048	.3048	.381	.362	.381
21	.3429	.3429	.3048	.3048	.3429	.3048	.362
22	.3048	.3239	.3048		.3239	.3239	.3429
23	.3239	.3048	.3048	.3048	.3048	.3048	.3048
24	.3048	.3048	.3048	.3048	.3048	.3048	.3048
Max	.5144	.4763	.4001	.3048	.4572	.4954	.4572
Min	.3048	.3048	.3048	.3048	.3048	.3048	.3048
Avg	.3810	.3755	.3239	.3048	.3763	.3723	.3731

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 212 / 11 KV Rupa SS - 3

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.4954	.5144	.4763	.4954	.4954	.5144
2	.4954	.4763	.4954	.4763	.4954	.4763	.4954
3	.4954	.4763	.4954	.4954	.4763	.4763	.4954
4	.4763	.4763	.4954	.4763	.4763	.4763	.4954
5	.4954	.4763	.4954	.4954	.4763	.4763	.4954
6	.4954	.4954	.5144	.4763	.4954	.4954	.4954
7	.5144	.5144	.5144	.4572	.5335	.4954	.5144
8	.5525	.5335	.5335	.4572	.5716	.5525	.7049
9	.6668	.6287	.5525	.4763	.5906	.6097	.6287
10	.743	.724	.5906	.4954	.743	.6859	.743
11	.7621	.7621	.5906	.5144	.743	.724	.8192
12	.8192	.7811	.6097	.5335	.743	.724	.7811
13	.8002	.743	.5906	.5144	.743	.724	.7811
14	.8383	.7811	.5906	.5144	.8192	.743	.7811
15	.9145	.8002	.6097	.5144	.8764	.743	.8002
16	.8764	.8192	.6097	.4954	.8383	.743	.8002
17	.8383	.8383	.6097	.5144	.8954	.7621	.8002
18	.7049	.743	.5906	.4954	.7811	.6859	.743
19	.6859	.6859	.5716	.4954	.6859	.6287	.6478
20	.5906	.6097	.5144	.4763	.5716	.5716	.6097
21	.5716	.5525	.5335	.4763	.5716	.5525	.5716
22	.5335	.5525	.5144	.4954	.5525	.5335	.5716
23	.5144	.5144	.4763	.4763	.5144	.4954	.5525
24	.5335	.4954	.4954	.4954	.4954	.4954	.5144
Max	.9145	.8383	.6097	.5335	.8954	.7621	.8192
Min	.4763	.4763	.4763	.4572	.4763	.4763	.4954
Avg	.6430	.6240	.5462	.4914	.6327	.5986	.6398

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 213 / 11 KV Rupa SS - 4

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9717	.9526	.9335	.9335	.8954	.9526	.9526
2	.9526	.9335	.9145	.9335	.8954	.9335	.9526
3	.9526	.9335	.9145	.9145	.8764	.9145	.9526
4	.9145	.9145	.9145	.9145	.8764	.9145	.9526
5	.9145	.9145	.9145	.9335	.8764	.9145	.9145
6	.9335	.9335	.9145	.9145	.8764	.9335	.9145
7	.9335	.9335	.9335	.9145	.8954	.9335	.9335
8	.9526	.9526	.9335	.9335	.9145	.9526	.9526
9	1.086	1.0288	.9907	.8954	1.0288	1.0479	1.086
10	1.3527	1.2574	1.0479	.8764	1.2955	1.2574	1.3146
11	1.3527	1.3336	1.0669	.9145	1.3146	1.3336	1.3146
12	1.3908	1.3146	1.086	.9335	1.3336	1.2574	1.3717
13	1.3527	1.3336	1.0669	.9526	1.3336	1.2765	1.3336
14	1.3717	1.3146	1.086	.9717	1.3146	1.3336	1.3717
15	1.3908	1.3527	1.086	.9526	1.3717	1.3527	1.3717
16	1.3908	1.3336	1.0669	.9907	1.3336	1.3717	1.3908
17	1.3527	1.3527	1.0669	.9717	1.3336	1.3146	1.3908
18	1.2955	1.2765	1.0479	.9526	1.3336	1.2955	1.3336
19	1.1622	1.1622	.9907	.9335	1.1812	1.1241	1.105
20	1.0669	1.0098	.9526	.9145	1.0669	1.086	1.0669
21	1.0098	.9717	.9335	.8954	1.0288	.9907	.9907
22	.9717	.9526	.9145	.9335	.9907	.9717	.9907
23	.9717	.9526	.9145	.9335	.9717	.9717	.9717
24	.9717	.9526	.9526	.9145	.9335	.9526	.9717
Max	1.3908	1.3527	1.086	.9907	1.3717	1.3717	1.3908
Min	.9145	.9145	.9145	.8764	.8764	.9145	.9145
Avg	1.1257	1.0987	.9851	.9304	1.0947	1.0995	1.1209

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 214 / 11 KV Rupa SS - 6

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3048	.3048	.3048	.3048	.3048	.3048
2	.3048	.3048	.3048	.3048	.3048	.3048	.3048
3	.3048	.3048	.3048	.3048	.3048	.3048	.3048
4	.3048	.3048	.3048	.3048	.3048	.3048	.3048
5	.3048	.3048	.3048	.3048	.3048	.3048	.3048
6	.3048	.3048	.3048	.3048	.3048	.3048	.3048
7	.3048	.3048	.3048	.3048	.3048	.3048	.3048
8	.3048	.3048	.3048	.3048	.3048	.3048	.3048
9	.3048	.3239	.3048	.3048	.3048	.3048	.3239
10	.3429	.3429	.3048	.3048	.3239	.3429	.3429
11	.362	.362	.3048	.3048	.3429	.3429	.362
12		.4191	.3239	.3429	.362	.362	.4191
13	.4191	.4191	.3429	.3048	.362	.381	.4191
14	.381	.4001	.3429	.3239	.4001	.381	.4382
15	.4001	.4001	.3429	.3048	.381	.3429	.4382
16	.362	.4001	.3048	.3048	.381	.3429	.4191
17	.362	.362	.3048	.3048	.3429	.3429	.381
18	.362	.3429	.3048	.3048	.3239	.3429	.381
19	.362	.3429	.3048	.3048	.3239	.362	.381
20	.3239	.3429	.3048	.3048	.3239	.3048	.3429
21	.3239	.3239	.3048	.3048	.3048	.3048	.3239
22	.3048	.3048	.3048	.3048	.3048	.3048	.3239
23	.3048	.3048	.3048	.3048	.3048	.3048	.3048
24	.3048	.3048	.3048	.3048	.3048	.3048	.3048
Max	.4191	.4191	.3429	.3429	.4001	.381	.4382
Min	.3048	.3048	.3048	.3048	.3048	.3048	.3048
Avg	.3330	.3389	.3104	.3072	.3262	.3254	.3477

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 301 / 22 Kv O/G Indian Express NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381				.381	.381
2	.381	.381				.381	.381
3	.381	.381	.3772		.3772	.381	.381
4	.381	.381				.381	.381
5	.381	.1905				.381	.381
6	.1905	.1905	.1886		.1886	.1905	.1905
7	.1905	.1905			.1886	.1905	.1905
8	.1905	.1905			.1886	.1905	
9	.1905	.1905	.1886		.1905	.1905	
10	.1905	.1905			.1905	.1905	.1896
11	.381	.381			.1905	.1905	
12	.381	.381	.1886	.1886	.1905	.1905	.1892
13	.1905	.381			.1905	.1905	
14	.1905	.1905			.1905	.1905	
15	.1905	.1905	.1886	.1886		.1905	
16	.1905				.1905	.1905	.1892
17	.1905	.1905			.1905	.1905	
18	.1905	.1905	.1886	.1886	.1905	.1905	
19	.1905	.1905	.1886	.1886	.1905	.1905	
20	.1905	.1905			.1905	.1905	
21	.381		.1886	.1886	.1905	.1905	
22	.381			.1886	.381	.381	
23	.381		.3772		.381	.381	.3791
24	.381	.381	.3772	.3772	.3772	.381	.381
Max	.381	.381	.3772	.3772	.381	.381	.381
Min	.1905	.1905	.1886	.1886	.1886	.1905	.1892
Avg	.2778	.2667	.2452	.2155	.2299	.254	.3012

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 303 / 22Kv O/G Electronic Sadan NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.5716				.7621	.7621
2	.7621	.5716				.7621	.7621
3	.7621	.5716	.5658		.3772	.7621	.7621
4	.7621	.5716				.7621	.7621
5	.7621	.5716				.7621	.7621
6	.7621	.7621	.5658		.5658	.7621	.7621
7	.7621	.7621			.5658	.7621	.7621
8	.7621	1.1431			.7545	.9526	
9	1.1431	1.1431	.7545		1.1431	.9526	
10	1.5242	1.1431			1.5242	1.1431	3.027
11	1.5242	1.1431			1.5242	1.1431	
12	1.5242	1.1431	.7545	.5658	1.5242	1.1431	1.1374
13	1.5242	1.1431			1.5242	1.1431	
14	1.5242	1.1431			1.5242	1.1431	
15	1.5242	1.1431	.7545	.5658		1.1431	
16	1.5242	1.1431			1.5242	1.1431	1.1374
17	1.5242	1.1431			1.5242	1.1431	
18	1.5242	1.1431	.7545	.5658	1.5242	1.1431	
19	1.5242	.9526	.7545	.5658	1.1431	.9526	
20	1.1431	.7621			.7621	.7621	
21	.7621			.3772	.7621	.7621	
22	.7621			.3772	.7621	.7621	
23	.7621				.381	.7621	.7583
24	.7621	.5716	.5658	.7545	.3772	.7621	.7621
Max	1.5242	1.1431	.7545	.7545	1.5242	1.1431	3.027
Min	.7621	.5716	.5658	.3772	.3772	.7621	.7583
Avg	1.1114	.9163	.6837	.5389	1.0415	.9288	1.0131

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 304 / 22Kv Hindustan Platinum NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381				.381	.381
2	.381	.381				.381	.381
3	.381	.381	.3772		.1886	.381	.381
4	.381	.381				.381	.381
5	.381	.381				.381	.381
6	.381	.381	.3772		.1886	.381	.381
7	.381	.381			.3772	.381	.381
8	.7621	.381			.3772	.7621	
9	.7621	.9526	.3772		.7621	1.1431	
10	.7621	.9526			.7621	1.1431	1.1351
11	.7621	.9526			1.5242	1.1431	
12	.7621	.9526	.3772	.3772	.9526	1.1431	1.1351
13	.7621	.9526			.9526	.7621	
14	.7621	.9526			.9526	.9526	
15	.7621	.9526	.3772	.1886	1.1431	.9526	
16	.7621	.9526			1.1431	.9526	.9459
17	.7621	.7621			1.5242	.9526	
18	.7621	.7621	.3772	.1886	.7621	.7621	
19	.7621	.7621	.3772	.1886	.381	.7621	
20	.7621	.5716			.381	.7621	
21	.1905			.1886	.381	.7621	
22	.1905			.1886	.381	.7621	
23	.381				.381	.381	.3784
24	.381	.381	.3772	.3772	.3772	.381	.381
Max	.7621	.9526	.3772	.3772	1.5242	1.1431	1.1351
Min	.1905	.381	.3772	.1886	.1886	.381	.3784
Avg	.5716	.6623	.3772	.2425	.6946	.7144	.5535

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 305 / 22KV Repro Press

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18
HR	Load (MW)
14	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 306 / 22KV L&T - II

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381				.381	.381
2	.381	.381				.724	.381
3	.381	.381	.3772		.3772	.381	.381
4	.381	.381				.381	.381
5	.381	.381				.381	.381
6	.381	.381	.3772		.3772	.381	.381
7	.381	.381			.3772	.381	.381
8	.381	.381			.3772	.381	
9	.381	.381	.3772		.381	.381	
10	.381	.381			.381	.381	.3784
11	.381	.381			.381	.381	
12	.381	.381	.3772	.3772	.381	.381	.3788
13	.381	.381			.381	.381	
14	.381	.381			.381	.381	
15	.381	.381	.3772	.3772	.381	.381	
16	.381	.381			.381	.381	.3784
17	.381	.381			.381	.381	
18	.381	.381	.3772	.3772	.381	.381	
19	.381	.381	.3772	.3772	.381	.381	
20	.7621	.381			.381	.381	
21	.381			.3772	.381	.381	
22	.1905			.3772	.381	.381	
23	.381				.381	.381	.3784
24	.381	.381	.3772	.3772	.3772	.381	.381
Max	.7621	.381	.3772	.3772	.381	.724	.381
Min	.1905	.381	.3772	.3772	.3772	.381	.3784
Avg	.3889	.381	.3772	.3772	.3801	.3953	.3802

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 307 / 22 kv CTRLS

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2862	2.2862				2.2862	2.1338
2	2.2862	2.2862				2.2862	2.1338
3	2.2862	2.2862	1.9993		2.3765	2.2862	2.1338
4	2.2862	2.2862				2.2862	2.1338
5	2.2862	2.2862				2.2862	2.1338
6	2.2862	2.2862	2.037		2.3765	2.2862	2.1338
7	2.2862	2.2862			2.3765	2.2862	2.1338
8	2.2862	2.2862			2.3765	2.3624	
9	2.2862	2.3243	2.0748		2.4768	2.3624	
10	2.3624	2.3243			2.4768	2.5149	2.4973
11	2.2862	2.3243			2.6673	2.5149	
12	2.2862	1.0288	2.3388	1.4712	2.6292	2.5149	2.2748
13	2.2862	1.0288			2.6292	2.4387	
14	2.2862	1.0288			2.6292	2.4387	
15	2.2862	1.0288	2.4897	1.7353	2.6673	2.4768	
16	2.4387	1.3717			2.7054	2.4768	2.4594
17	2.4387				2.6673	2.3243	
18	2.4768	1.3717	2.5652	2.3011	2.6673	2.2862	
19	2.4768	2.5149	2.4143	2.4897	2.6292	2.2862	
20	2.553	2.1338			2.4768	2.2862	
21	2.4768			2.4143	2.4387	2.2862	
22	2.2862			2.3765	2.4768	2.1719	
23	2.3243				2.4768	2.1719	2.1567
24	2.2862	2.2862	2.0748	2.3765	2.3388	2.2862	2.1719
Max	2.553	2.5149	2.5652	2.4897	2.7054	2.5149	2.4973
Min	2.2862	1.0288	1.9993	1.4712	2.3388	2.1719	2.1338
Avg	2.3386	1.9528	2.2492	2.1664	2.5279	2.3418	2.2081

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 308 / 22 kv Electronic Zone
Feeder KV- 22 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9052	2.2862				1.9052	1.9052
2	1.9052	2.2862				1.9052	1.9052
3	1.9052	2.2862	1.8861		2.2634	1.9052	1.9052
4	1.9052	2.2862				1.9052	1.9052
5	1.9052	2.2862				1.9052	1.9052
6	1.9052	2.2862	1.8861		2.6406	1.9052	1.9052
7	1.9052	2.6673			2.6406	2.2862	1.9052
8	3.0483	2.6673			2.6406	3.0483	
9	3.0483	2.6673	2.6406		3.4294	3.0483	
10	4.5725	4.5725			4.1914	3.0483	3.0331
11	4.9535	4.5725			4.5725	4.1914	
12	4.9535	4.5725	4.1495	2.6406	4.9535	4.5725	4.1621
13	4.9535	4.5725			4.9535	4.1914	
14	5.7156	4.5725			4.9535	4.1914	
15		4.5725	4.1495		5.3346	4.5725	
16	5.3346	4.5725			5.3346	4.5725	4.545
17	5.3346	4.5725			4.5725	4.1914	
18	4.5725	3.8104	3.7723	2.2634	3.8104	4.1914	
19	3.4294	1.9052	3.3951	2.2634	3.4294	3.0483	
20	3.0483	2.6673			3.0483	3.0483	
21	2.6673			2.6406	2.6673	2.2862	
22	2.6673			2.6406	2.6673	2.2862	
23	2.6673				2.2862	2.2862	2.2748
24	2.6673	2.2862	2.6406	2.6406	2.2634	2.2862	2.2862
Max	5.7156	4.5725	4.1495	2.6406	5.3346	4.5725	4.545
Min	1.9052	1.9052	1.8861	2.2634	2.2634	1.9052	1.9052
Avg	3.3465	3.2842	3.0650	2.5149	3.6327	3.0324	2.4698

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 310 / Systime computers EL-207 NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905					.1905
2	.1905	.1905					.1905
3	.1905	.1905	.1886		.1886		.1905
4	.1905	.1905					.1905
5	.1905	.1905					.1905
6	.1905	.1905	.1886		.1886		.1905
7	.1905	.1905			.1886		.1905
8	.1905	.1905			.1886	.1905	
9	.1905	.1905	.1886		.1905	.1905	
10	.1905	.1905			.1905	.1905	
11	.1905	.1905			.1905	.1905	.1896
12	.1905	.1905	.1886	.1886	.1905	.1905	.1892
13	.1905	.1905			.1905	.1905	
14	.1905	.1905			.1905	.1905	
15	.1905	.1905	.1886	.1886	.1905	.1905	
16	.1905	.1905				.1905	.1894
17	.1905	.1905			.1905	.1905	
18	.1905	.1905	.1886		.1905	.1905	
19	.1905	.1905	.1886	.1886	.1905	.1905	
20	.1905	.1905			.1905	.1905	
21	.1905			.1886	.1905	.1905	
22	.1905			.1886	.1905	.1905	
23	.1905				.1905	.1905	.1896
24	.1905	.1905	.1886		.1886		.1905
Max	.1905	.1905	.1886	.1886	.1905	.1905	.1905
Min	.1905	.1905	.1886	.1886	.1886	.1905	.1892
Avg	.1905	.1905	.1886	.1886	.19	.1905	.1902

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 203 / 11KV P/3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3203	1.3392	1.1694	1.6032	1.4335	1.358	1.4146
2	1.2826	1.2826	1.1317	1.5278	1.358	1.3203	1.3769
3	1.2071	1.226	1.1317	1.4523	1.358	1.3203	1.3014
4	1.2071	1.226	1.1317	1.4335	1.4146	1.3203	1.2826
5	1.3203	1.2637	1.2071	1.4335	1.5466	1.4712	1.4335
6	1.4146	1.4712	1.2826	1.5844	1.6409	1.5844	1.7918
7	1.4523	1.7918	1.5655	1.8107	2.1313	1.9239	2.1879
8	1.8107	1.5278	1.3769	1.6409	1.7918	1.8107	1.8673
9		1.2826	1.6975	1.5466	1.5466	1.6409	1.6787
10		1.094	1.4146	1.4712	1.3392	1.4901	1.3769
11		1.0185	1.2071	1.4146	1.1883	1.2449	1.2449
12		.9431	1.1694	1.3392	1.1128	1.1883	1.1883
13		.8676	1.1317	1.2826	1.0751		1.1317
14		.8865		1.2071	1.0185	1.1317	1.1317
15		.8676		1.2071	.9808	1.094	1.0562
16		.8676		1.2449	.9808		1.0562
17		.8488		1.2637	1.0374		1.094
18		.9431		1.3014	1.1317		1.2071
19		1.358		1.6032	1.5844		1.8107
20		1.4335		1.7918	1.7164		1.905
21		1.7918		2.3577	2.2445		2.5652
22		1.3957		1.7541	1.6975		1.8673
23		1.358		1.5844	1.6032		1.7918
24	1.3769	1.3957	1.2637	1.6975	1.4901	1.4523	1.4523
Max	1.8107	1.7918	1.6975	2.3577	2.2445	1.9239	2.5652
Min	1.2071	.8488	1.1317	1.2071	.9808	1.094	1.0562
Avg	1.3769	1.2284	1.2772	1.5231	1.4343	1.4234	1.5089

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 204 / 11KV Mathadi HTP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	1.1694	.9808	1.0562	1.0185	.9431	.9619
2	1.0562	1.1506	.9431	1.0185	.9808	.8676	.9054
3	.9808	1.1128	.9431	.9808	.9808	.8676	.8865
4	1.0374	1.0751	.9431	.9808	1.0562	.8676	.8865
5	1.1317	1.0751	1.0185	.9431	1.1317	.9431	.9808
6	1.2449	1.2071	1.1317	1.0374	1.226	1.0185	1.226
7	1.4901	1.3957	1.3014	1.0751	1.3203	1.1883	1.4146
8	1.5278	1.3957	1.2637	1.3203	1.4901	1.3957	1.3957
9		1.358	1.2637	1.2449	1.226	1.4335	1.2826
10		1.1883	1.226	1.2071	1.1506	1.2449	1.2826
11		1.0562	1.1694	1.1694	1.0185	1.3014	1.0374
12		.9808	1.0374	1.1506	.9997	.9808	.9431
13		.9431	.9242	1.0562	.9431	.9054	.9619
14		.8865		.9808	.8488	.8488	.9242
15		.8676		.9431	.7922		.8299
16		.8676		.9431	.8676		.8676
17		.9808		.9808	.8488		.9619
18		1.0374		1.0374	.9619		1.1128
19		1.2637		1.226	1.2449		1.2637
20		1.1317		1.2071	1.1317		1.2637
21		1.1883		1.2071	1.1694		1.3203
22		1.2071		1.2071	1.1128		1.3014
23		1.1317		1.1128	1.094		1.226
24	1.1883	1.2071	1.0374	1.1128	1.0562	.9808	.9997
Max	1.5278	1.3957	1.3014	1.3203	1.4901	1.4335	1.4146
Min	.9808	.8676	.9242	.9431	.7922	.8488	.8299
Avg	1.1988	1.1199	1.0845	1.0916	1.0696	1.0525	1.0932

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 205 / 11KV Sector-22&23

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1125	2.1125	1.8861	1.9993	1.8861	1.8861	1.9239
2	2.037	2.037	1.6975	1.9616	1.8484	1.6975	1.8484
3	2.037	1.9616	1.6975	1.8484	1.8484	1.6975	1.7918
4	2.1125	1.9427	1.6975	1.8296	1.9239	1.6975	1.773
5	2.2634	2.0748	1.9239	1.8484	2.0748	1.8861	1.8296
6	2.3765	2.2068	1.9993	1.9616	2.1879	1.9993	2.0748
7	2.5463	2.6972	2.2822	2.1125	2.3011	2.2445	2.452
8	2.5652	2.4897	2.4143	2.2068	2.4331	2.3011	2.4143
9		2.3011	2.3388	2.2257	2.1502	2.3388	2.2634
10		1.905	2.0559	2.0748	1.9427	1.9805	1.905
11		1.8484	1.8107	1.9239	1.7164	1.7918	1.7541
12		1.773	1.7918	1.8107	1.6032	1.6787	1.7164
13		1.773	1.773	1.773	1.6598	1.6221	1.7353
14		1.6975		1.7353	1.5089	1.6221	1.6032
15		1.6975		1.7353	1.5655		1.6032
16		1.6975		1.8107	1.6598		1.6598
17		1.773		1.8484	1.6787		1.773
18		1.8673		1.905	1.8296		1.8296
19		2.1691		2.1125	2.1313		2.1502
20		2.1691		2.1502	2.1313		2.2068
21		2.1691		2.1879	2.1502		2.3765
22		2.1502		2.1691	2.1502		2.2822
23		2.1125		2.0748	2.0748		2.2068
24	2.2068	2.2257	2.0559	2.0748	1.9993	1.9993	1.9993
Max	2.5652	2.6972	2.4143	2.2257	2.4331	2.3388	2.452
Min	2.037	1.6975	1.6975	1.7353	1.5089	1.6221	1.6032
Avg	2.2508	2.0355	1.9589	1.9742	1.9357	1.8962	1.9655

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 206 / 11 KV P-2 S/S

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9242	.679	.8488	.679	.679	.7167
2	.7545	.8865	.6413	.7733	.6413	.6413	.679
3	.7167	.811	.6413	.7356	.6036	.6413	.6602
4	.7167	.811	.6413	.7167	.6602	.6413	.6413
5	.7733	.7922	.679	.679	.679	.679	.6979
6	.811	.8676	.679	.6602	.7167	.7545	.7545
7	.9242	.9054	.7545	.6602	.8865	.811	.8676
8	.9997	.9431	.7545	.6602	.8676	.7733	.8488
9		.8676	.7733	.7167	.9054	.811	.8488
10		.9808	.9242	.7922	.9997	.9808	.9431
11		.9431	1.0374	.8676	1.0374	.9054	.9619
12		.9054	.9997	.9431	.8676	.8676	.9054
13		.8676	.9619	.9431	.7922	.7545	.8676
14		.8299		.9431	.8676	.8488	.9619
15		.8299		.9054	.8865	.811	.8865
16		.8299		.9054	.9054		.9431
17		.8488		.8676	.9619		1.0185
18		.9242		.8488	.8865		.9431
19		1.094		.9619	1.094		1.1694
20		.9431		.9054	1.0751		1.1506
21		.9997		.9431	1.0562		1.0374
22		.9808		.9242	.9431		.9808
23		.8488		.8488	.8299		.9431
24	.9054	.9619	.7545	.9242	.7356	.7545	.7356
Max	.9997	1.094	1.0374	.9619	1.094	.9808	1.1694
Min	.7167	.7922	.6413	.6602	.6036	.6413	.6413
Avg	.8252	.8999	.7801	.8323	.8574	.7721	.8818

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 207 / 11KV SECTOR-19

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3584	.3395	.3772	.3395	.3018	.3206
2	.3772	.3584	.3018	.3584	.3206	.2641	.3018
3	.3772	.3395	.3018	.3584	.3206	.2641	.2829
4	.3961	.3206	.3018	.3395	.3206	.2641	.2829
5	.415	.3395	.3395	.3206	.3395	.3018	.3206
6	.4527	.3961	.3772	.3584	.3772	.3395	.3961
7	.5093	.4715	.4338	.3961	.4338	.3772	.4527
8	.4904	.4715	.4338	.415	.4904	.4527	.4715
9		.415	.4338	.3961	.3961	.4338	.3961
10		.3772	.3961	.3961	.3772	.3961	.3206
11		.3206	.3206	.3772	.3018	.3395	.3395
12		.3018	.3206	.3772	.2641	.3018	.3018
13		.2641	.3018	.3395	.2641	.2641	.3018
14		.2641		.3018	.2452	.2641	.2829
15		.2641		.3018	.2452		.2641
16		.2641		.3395	.2641		.2829
17		.2829		.3395	.3018		.2829
18		.3018		.3772	.3206		.3206
19		.415		.4527	.4338		.4715
20		.4338		.415	.415		.4904
21		.415		.4338	.415		.4715
22		.3772		.415	.3961		.4715
23		.3961		.3961	.3961		.4338
24	.3961	.3961	.3584	.3961	.3584	.3395	.3206
Max	.5093	.4715	.4338	.4527	.4904	.4527	.4904
Min	.3772	.2641	.3018	.3018	.2452	.2641	.2641
Avg	.4212	.3560	.3543	.3741	.3474	.3269	.3576

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 208 / 11KV BEVERLY PARK -II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.3961	.3395	.3584	.3206	.3395	.3961
2	.4338	.3584	.3018	.3395	.3018	.3018	.3772
3	.4338	.3584	.3018	.3395	.3018	.3018	.3584
4	.415	.3395	.3018	.3395	.3018	.3018	.3395
5	.415	.3584	.3395	.3584	.3206	.3395	.3395
6	.415	.3961	.3395	.3772	.3395	.3772	.415
7	.4715	.4338	.3584	.3961	.4527	.4338	.5658
8	.5658	.679	.415	.415	.5281	.5847	.5658
9		.5847	.415	.4715	.4715	.547	.547
10		.4338	.3961	.4338	.3772	.3584	.415
11		.415	.415	.3961	.2829	.3772	.3772
12		.3772	.4338	.3772	.3584	.3584	.3584
13		.3395	.415	.3961	.3018	.3584	.3772
14		.3395		.415	.3018	.3961	.3961
15		.3395		.3772	.3018		.3395
16		.3395		.3772	.3018		.3018
17		.3395		.3772	.2641		.3584
18		.3961		.3961	.3395		.3206
19		.4338		.4527	.3584		.3584
20		.415		.3772	.3395		.4338
21		.3584		.3961	.3772		.4904
22		.3584		.3584	.415		.4715
23		.3772		.3772	.415		.4904
24	.4904	.415	.3584	.3772	.3395	.3584	.4338
Max	.5658	.679	.4338	.4715	.5281	.5847	.5658
Min	.415	.3395	.3018	.3395	.2641	.3018	.3018
Avg	.4548	.3992	.3665	.3867	.3505	.3823	.4095

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 211 / 11 KVMetro Bar Sectore -15

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0748	2.1691	2.0748	2.1313	2.0748	1.8861	1.9805
2	1.8861	2.0182	1.8861	2.0559	1.9616	1.6975	1.905
3	1.773	1.9427	1.8861	1.9805	1.8107	1.6975	1.7918
4	1.8107	1.9239	1.8861	1.9427	1.8484	1.6975	1.7918
5	1.9616	1.9427	1.9993	1.9427	1.9993	1.8861	1.8484
6	2.1691	2.2634	2.1125	2.037	2.1502	1.9993	2.2257
7	2.5652	2.8104	2.3388	2.1125	2.7161	2.3011	2.6406
8	2.9047	2.452	2.2257	2.1691	2.452	2.2257	2.452
9		2.6783	2.5652	2.3011	2.6595	2.6029	2.4897
10		2.6783	2.584	2.452	2.3765	2.3765	2.6783
11		2.6029	2.6406	2.5652	2.5463	2.4709	2.5652
12		2.6406	2.5086		2.3765	2.3577	2.3765
13		2.452	2.4331	2.452	2.1313	2.1313	2.3577
14		2.3765		2.2634	2.0748	2.0748	2.2634
15		2.2634		2.2257	2.2822		2.2445
16		2.2634		2.2257	2.32		2.3577
17		2.2068		2.2634	2.2068		2.2257
18		2.2068		2.2822	2.3388		2.5274
19		2.7915		2.5652	2.5652		2.9235
20		2.5274		2.6029	2.5652		2.7915
21		2.7538		2.8669	2.8292		2.8669
22		2.4143		2.452	2.452		2.4897
23		2.2257		2.3011	2.037		2.3577
24	2.2634	2.2634	2.2257	2.2822	2.1502	1.9239	2.0748
Max	2.9047	2.8104	2.6406	2.8669	2.8292	2.6029	2.9235
Min	1.773	1.9239	1.8861	1.9427	1.8107	1.6975	1.7918
Avg	2.1565	2.3695	2.2405	2.2814	2.2885	2.0886	2.3428

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 212 / 11 KV KOPERKHIRANE VILLAGE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.7167	.6036	.6224	.6036	.4904	.6036
2	.7167	.6602	.6036	.5847	.5658	.4904	.5658
3	.679	.6413	.6036	.5658	.5658	.4904	.5658
4	.679	.6224	.6036	.5658	.6413	.4904	.5281
5	.7545	.6602		.5847	.7167	.5658	.5847
6	.8488	.7733	.7545	.6602	.811	.6413	
7	.9808	.9431	.8299	.7356	.8488	.8048	.8865
8	.9242	.9431	.9431	.8865	.9054	.8676	.8676
9		.8488	.7922	.8488	.7356	.8299	.7733
10		.6413	.6979	.7545	.6413	.679	.5847
11		.5658	.6224	.7167	.547	.5658	.5658
12		.5658	.5847	.6413	.4904	.5658	.5281
13		.4904	.5281	.6036	.4904	.4904	.547
14		.4904		.547	.4715	.4904	.4904
15		.4904		.5658	.4527		.4715
16		.4904		.5658	.4715		.4715
17		.5281		.6036	.5281		.5658
18		.6036		.6224	.6036		.6413
19		.7733		.811	.7733		.811
20		.7733		.811	.7922		.8676
21		.7733		.811	.7733		.8299
22		.7545		.7545	.7167		.811
23		.7167		.7167	.6979		.7545
24	.7733	.7545	.679	.6979	.6413	.6224	.6224
Max	.9808	.9431	.9431	.8865	.9054	.8676	.8865
Min	.679	.4904	.5281	.547	.4527	.4904	.4715
Avg	.7901	.6759	.6805	.6782	.6452	.6057	.6495

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 213 / 11KV AVENUE SUPERMART

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.5847	.4527	.5658	.5281	.4904	.4904
2	.5658	.5658	.415	.5281	.4904	.4527	.4527
3	.5281	.5281	.415	.4904	.4904	.4527	.415
4	.5281	.5281	.415	.415	.4904	.4527	.415
5	.6036	.6036	.4904	.4527	.5658	.5658	.415
6	.5847	.6602	.5658	.5093	.5281	.6036	.6224
7	.7167	.7922	.679	.5658	.7545	.679	.8299
8	.811	.7167	.6224	.6413	.6602	.6413	.7356
9		.6979	.6602	.679	.6979	.5847	.6602
10		.6979	.6602	.7167	.7545	.6979	.7167
11		.7356	.679	.7545	.7356	.6979	.7733
12		.7545	.6224	.7733	.7167	.6979	.811
13		.7167	.6979	.7545	.6979		.7545
14		.7356		.7167	.5847	.6413	.7356
15		.7167		.679	.6224	.6979	.7356
16		.7167		.679	.6602		.7356
17		.679		.679	.7167		.7922
18		.6979		.7167	.6979		.811
19		.8488		.8299	.8488		.9054
20		.8299		.8299	.8299		.9431
21		.8299		.8865	.8299		.9808
22		.7167		.7545	.7167		.8676
23		.679		.6413	.5847		.7545
24	.6224	.6224	.4904	.6413	.5281	.5281	.5093
Max	.811	.8488	.6979	.8865	.8488	.6979	.9808
Min	.5281	.5281	.415	.415	.4904	.4527	.415
Avg	.6182	.6939	.5618	.6625	.6554	.5923	.7026

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 214 / 11 KV JIMMY TOWER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0562	1.1883	.9431	1.1506	.9808	.9054	.9808
2	.9808	1.1317		1.094	.9431	.8676	.9431
3	.9431	1.094	.8676	1.0374	.9431	.8676	.9242
4	1.0185	1.0751	.8676	.9997	1.0185	.8676	.8488
5	1.094	1.0751	.9808	.9997	1.1317	.9431	.8488
6	1.2449	1.3769	1.1317	1.1506	1.2449	1.1317	1.3769
7	1.5655	1.7164	1.5844	1.3392	1.6975	1.5655	1.7164
8	1.6221	1.3957	1.358	1.3203	1.3392	1.3769	1.3392
9		1.3014	1.226	1.2449	1.1883	1.3203	1.1317
10		.9431	1.1128	1.1317	.9997	1.3203	1.0374
11		.9054	.9619	1.0562	.9054	.9054	.9242
12		.8676	.9054	.9997	.811	.8676	.9054
13		.7922	.8488	.9431	.7733	.8676	.8299
14		.7733		.9054	.7356	.7733	.8299
15		.7545		.8676	.6979		.7545
16		.7545		.8676	.6979		.7545
17		.7545		.9054	.7356		.811
18		.8299		.9619	.8865		.9242
19		1.1883		1.1694	1.1883		1.3203
20		1.3014		1.4523	1.3392		1.5466
21		1.5655		1.773	1.773		1.9616
22		1.2449		1.2826	1.2637		1.3769
23		1.1506		1.1128	1.094		1.2637
24	1.1506	1.226	.9997	1.1883	.9997	.9431	.9997
Max	1.6221	1.7164	1.5844	1.773	1.773	1.5655	1.9616
Min	.9431	.7545	.8488	.8676	.6979	.7733	.7545
Avg	1.1862	1.1003	1.0606	1.1231	1.0578	1.0349	1.0979

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283030 / 22/22KV Krishna Steel

Swt/Stn

Feeder No / Name : 301 / 22 Kv SONY DADC

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.3048	.1905	.3048	.2667	.2667	.2286
2	.2286	.3048	.1905	.3048	.2667	.2667	.2286
3	.2286	.2667	.2286	.3048	.2667	.2667	.2286
4	.2667	.2667	.2286	.2667	.2667	.2667	.1905
5	.2667	.2286	.2286	.2667	.2667	.2667	.1905
6	.2667	.2286	.1905	.2667	.2667	.2667	.2286
7	.2667	.1905	.1905	.2286	.2667	.2667	.2286
8	.2667	.1905	.1905	.2286	.2667	.2286	.2286
9	.2667	.2286	.1905	.2286	.2667	.2286	.2286
10	.3048	.2286	.1905	.2286	.2667	.3048	.3048
11	.3429	.2286	.2286	.2286	.381	.3048	.3048
12	.3429	.2286	.2286	.3048	.381	.3429	.3048
13	.381	.1905	.2667	.3048	.381	.3048	.3048
14	.381	.1905	.2667	.3048	.381	.2667	.3048
15	.381	.2286	.2667	.3048	.381	.2667	.3048
16	.381	.2286	.3048	.3048	.381	.2667	.3048
17	.3429	.2286	.3048	.3048	.4191	.2667	.3429
18	.3429	.2286	.3048	.3048	.3048	.2286	.3429
19	.2667	.1905	.3048	.3048	.2667	.2286	.3429
20	.2286	.1905	.3048	.3048	.2667	.2286	.3429
21	.2286	.1905	.3048	.2286	.3048	.2667	.3429
22	.2667	.1905	.3048	.2286	.2667	.2286	.3429
23	.3048	.1905	.3048	.2286	.2667	.2286	.2667
24	.2286	.3048	.1905	.3048	4.2295	.2667	.2286
Max	.381	.3048	.3048	.3048	4.2295	.3429	.3429
Min	.2286	.1905	.1905	.2286	.2667	.2286	.1905
Avg	.2921	.2270	.2461	.2746	.4699	.2635	.2778

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283030 / 22/22KV Krishna Steel

Swt/Stn

Feeder No / Name : 302 / 22 KV BASF

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9052	1.3336	1.5242	1.5242	1.1431	1.6004	1.5242
2	1.9052	1.3336	1.5242	1.5242	1.1431	1.6004	1.5242
3	1.7147	1.5242	1.5242	1.5242	1.1431	1.6004	1.5242
4	1.7147	1.5242	1.5242	1.5242	1.1431	1.6004	1.5242
5	1.7147	1.5242	1.5242	1.5242	1.1431	1.6004	1.9052
6	1.7147	1.9052	1.5242	1.5242	1.1431	1.5242	1.9052
7	1.7147	1.9052	1.448	1.5242	1.1431	1.5242	1.9052
8	1.9052	1.9052	1.6004	1.5242	1.1431	1.9052	1.9052
9	2.0957	1.9052	1.6004	1.5242	1.7147	2.0957	2.0957
10	2.2862	1.9052	1.7147	1.3336	2.0957	1.9052	2.0957
11	2.2862	2.0957	1.7147	1.3336	2.1338	1.9052	2.2862
12	2.2862	2.0195	1.5242	1.1431	2.1338	1.9052	2.2862
13	2.2862	2.0957	1.5242	1.1431	2.1338	1.9052	2.2862
14	2.2862	2.0957	1.5242	1.1431	2.1719	1.9052	2.2862
15	2.2862	1.829	1.5242	1.1431	2.1719	1.9052	2.2862
16	2.0957	2.0957	1.5242	1.1431	2.1338	1.9052	2.0957
17	2.2862	2.1719	1.5242	1.3336	2.1338	1.9052	2.0957
18	2.2862	1.7909	1.5242	1.1431	2.1338	1.9052	1.9052
19	1.9052	1.7909	1.5242	1.3336	1.9433	1.9052	1.9052
20	1.7147	1.6385	1.5242	1.3336	1.829	1.7147	1.7147
21	1.7147	1.6004	1.3336	1.3336	1.7147	1.7147	1.7147
22	1.5242	1.5242	1.3336	1.3336	1.5242	1.7147	1.7147
23	1.3336	1.5242	1.3336	1.3336	1.6004	1.7147	1.7147
24	1.9052	1.3336	1.5242	1.5242	1.3336	1.6004	1.5242
Max	2.2862	2.1719	1.7147	1.5242	2.1719	2.0957	2.2862
Min	1.3336	1.3336	1.3336	1.1431	1.1431	1.5242	1.5242
Avg	1.9528	1.7655	1.5194	1.3654	1.6686	1.7734	1.9052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283030 / 22/22KV Krishna Steel

Swt/Stn

Feeder No / Name : 303 / 22 KV EVEREST ANGAN

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.1914	3.8104	3.7342	3.8104	3.0483	3.4294	3.0483
2	4.1914	3.8104	3.7342	3.8104	3.0483	3.4294	3.0483
3	3.8104	3.8104	3.7342	3.8104	3.0483	3.4294	3.0483
4	3.8104	3.8104	3.7342	3.4294	3.0483	3.4294	3.0483
5		3.4294	3.6199	3.4294	3.0483	3.2388	3.0483
6	2.2862	3.4294	3.2388	3.4294	2.6673	3.0483	3.4294
7	2.2862	3.0483	3.0483	3.4294	2.6673	2.8959	3.4294
8	3.4294	3.0483	3.5818	3.4294	3.0483		3.4294
9	3.8104	3.8104	3.1245	3.4294	3.4294	3.6199	3.8104
10	3.8104	3.8104	3.8104	3.4294	3.6199	3.8104	4.1914
11	3.0483	2.2862	3.8104	3.4294	3.8104	3.8104	
12	3.0483	3.5056	3.8104	3.4294	3.8104	3.4294	3.8104
13	3.4294	3.5818	3.8104	3.4294	3.4294	3.8104	3.6199
14	3.8104	3.5818	3.8104	3.4294	3.8104	3.8104	4.0009
15	3.8104	3.658	3.8104	3.4294	3.8104	3.8104	3.8104
16	4.1914	3.658	4.1914	3.0483	3.8104	3.8104	4.1914
17	4.1914	3.6199	4.1914	3.4294	3.8866	3.8104	4.1914
18	4.1914	3.2769	3.8104	3.4294	3.5437	3.8104	4.1914
19	3.8104	3.2769	3.8104	3.0483	3.3532	3.4294	3.8104
20	3.8104	3.3532	3.4294	3.0483	3.4294	3.4294	3.8104
21	3.8104	3.8866	3.4294	3.4294	3.7342	3.4294	4.1914
22	3.8104	3.5818	3.4294	3.4294	3.4294	3.0483	3.8104
23	3.8104	3.5818	3.8104	3.0483	3.4294	3.0483	3.8104
24	4.1914	3.8104	3.7342	3.8104	3.0483	3.4294	3.0483
Max	4.1914	3.8866	4.1914	3.8104	3.8866	3.8104	4.1914
Min	2.2862	2.2862	3.0483	3.0483	2.6673	2.8959	3.0483
Avg	3.6779	3.5199	3.6770	3.4294	3.3754	3.4890	3.6447

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283030 / 22/22KV Krishna Steel

Swt/Stn

Feeder No / Name : 304 / 22 KV BHAVKALESHWAR

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6673	2.2862	2.2862	6.0966	5.7156	6.4015	6.0966
2	2.2862	2.2862	4.5725	6.0966	5.7156	6.4015	6.0966
3	2.2862	2.2862	4.7249	6.0966	5.3346	6.2872	6.0966
4	2.2862	2.2862	4.7249	5.7156	5.3346	6.2872	5.3346
5	2.6673	1.9052	4.7249	5.7156	5.3346	6.0966	5.3346
6	2.6673	1.5242	4.7249	5.7156	5.3346	5.2584	5.7156
7	2.6673	1.5242	4.7249	5.7156	5.3346	5.3346	6.0966
8	2.6673	1.9052	5.6394	5.7156	6.0966	5.3346	6.4777
9	2.6673	2.2862	7.0492	6.0966	7.2398	6.5539	8.3829
10	3.0483	2.6673	8.7639	6.8587	8.0018	8.7639	9.145
11	3.8104	2.9721	8.7639	8.0018		9.145	
12	4.1914	2.8578	9.145	8.0018	10.2881	9.145	10.2881
13	4.1914	2.7435	9.145	7.2398	8.7639	9.145	9.526
14	4.1914	2.7435	9.145	7.6208	10.3643	9.145	10.6691
15	4.1914	2.7435	9.145	8.0018	10.3643	8.7639	10.6691
16	4.1914	2.6673	9.145	8.0018	10.2881	9.145	10.6691
17	4.1914	2.5149	9.145	8.0018	10.0976	7.6208	10.6691
18	3.8104	2.2862	9.145	7.2398	9.7165	7.6208	9.526
19	3.4294	2.2862	9.145	6.8587	8.7639	7.6208	9.526
20	1.5242	2.21	9.145	6.4777	7.4303	6.8587	8.3829
21	1.9052	2.0957	9.145	5.7156	6.5539	6.8587	8.0018
22	1.9052	2.1338	7.6208	5.7156	6.4777	6.0966	7.6208
23	2.2862	2.0195	6.0966	5.7156	6.1728	6.0966	7.6208
24	2.6673	2.2862	2.0195	6.0966	5.7156	6.4015	6.0966
Max	4.1914	2.9721	9.145	8.0018	10.3643	9.145	10.6691
Min	1.5242	1.5242	2.0195	5.7156	5.3346	5.2584	5.3346
Avg	3.0166	2.3132	6.9953	6.6047	7.4104	7.1826	8.0018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283030 / 22/22KV Krishna Steel

Swt/Stn

Feeder No / Name : 305 / 22KV N0CIL RCD

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4768	2.2862	2.5911	2.4768	2.6673	2.5911	2.4768
2	2.4768	2.2862	2.5911	2.4768	2.6673	2.5911	2.4768
3	2.2862	2.2862	2.5911	2.4768	2.6673	2.5911	2.4768
4	2.2862	2.2862	2.5911	2.4768	2.6673	2.5911	2.2862
5	2.2862	2.2862	2.4768	2.6673	2.6673	2.5911	2.2862
6	2.2862	2.2862	2.4006	2.6673	2.6673	2.5149	2.2862
7	2.2862	2.4768	2.2862	2.6673	2.6673	2.5149	2.2862
8	2.2862	2.4768	2.21	2.6673	2.6673	2.2862	2.2862
9	2.2862	2.4768	2.4387	2.6673	2.6673	2.4768	2.4768
10	2.2862	2.4768	2.4768	2.4768	2.6673	2.4768	2.4768
11	2.4768	2.553	2.4768	2.2862	2.5911	2.4768	2.4768
12	2.4768	2.6673	2.4768	2.4768	2.8578	2.4768	2.4768
13	2.4768	2.6673	2.4768	2.2862	2.5911	2.2862	2.4768
14	2.2862	2.5911	2.4768	2.4768	2.5911	2.2862	2.4768
15	2.2862	2.553	2.4768	2.2862	2.4768	2.2862	2.4768
16	2.2862	2.553	2.4768	2.4768	2.4768	2.2862	2.4768
17	2.2862	2.553	2.4768	2.4768	2.5149	2.2862	2.4768
18	2.2862	2.6673	2.4768	2.4768	2.5911	2.2862	2.2862
19	2.2862	2.7816	2.4768	2.6673	2.6673	2.2862	2.4768
20	2.2862	2.7435	2.4768	2.6673	2.5911	2.2862	2.6673
21	2.2862	2.7435	2.4768	2.6673	2.6673	2.6673	2.6673
22	2.2862	2.6673	2.4768	2.6673	2.6673	2.6673	2.4768
23	2.2862	2.5911	2.4768	2.6673	2.5911	2.6673	2.4768
24	2.4768	2.2862	2.5911	2.4768	2.6673	2.553	2.4768
Max	2.4768	2.7816	2.5911	2.6673	2.8578	2.6673	2.6673
Min	2.2862	2.2862	2.21	2.2862	2.4768	2.2862	2.2862
Avg	2.3339	2.5101	2.4768	2.5324	2.6340	2.4593	2.4450

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283032 / 22/11KV Ghansoli Gharonda

S/St

Feeder No / Name : 201 / 11 KV PATEL HEIGHT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6326	2.4459	2.347	2.4025	2.2405	2.2916	2.384
2	2.2779	2.3339	2.2731	2.3101	2.1658	2.2361	2.3101
3	2.2592	2.3339	2.2177	2.2177	1.9978	3.4743	2.2731
4	2.2405	2.3339	2.2177	2.1068	1.9978	2.1253	2.1807
5	2.3339	2.4272	2.3655	2.2405	1.9978	2.3655	2.4025
6	2.7633	2.8193	2.5318	2.3339	2.2405	2.4949	2.7351
7	3.3608	3.2674	2.7351	2.4646	2.95	2.8275	3.1232
8	3.3048	3.2114	2.8645	2.5766	3.1741	3.0862	3.1047
9	3.2301	3.0434	2.9014	3.006	2.9874	3.1786	2.9199
10	3.3608	3.1927	3.0493	3.0247	3.0247	3.1047	2.9938
11	3.1367	2.9127	3.1047	3.0434	2.9754	3.0123	2.7536
12	2.9313	2.782	2.95	2.9313	2.5688	2.6797	2.7905
13	2.838	2.726	2.8006	2.8006	2.5873	2.5133	2.7166
14	2.6326	2.5953	2.4832	2.6513	2.4764	2.2916	2.6427
15	2.4646	2.3339	2.3899	2.5206	2.3655	2.1622	2.4394
16	2.6886	2.2032	2.3525	2.4086	2.2916	2.1068	2.4394
17	2.782	2.4272	2.5579	2.5393	2.4394	2.384	2.7351
18	2.838	2.6612	2.7446	2.7633	2.5057	2.7166	2.846
19	3.5288	3.2156	3.2895	3.3234	3.0361	3.219	3.5482
20	3.5662	3.271	3.4743	3.2487	3.091	3.3288	3.5482
21	3.6969	3.3634	3.3265	3.3608	3.1276	3.3105	3.5667
22	3.2861	3.0862	3.2895	3.062	3.1232	3.0862	3.271
23	3.1367	2.5873	2.6612	2.8567	2.7351	2.8275	3.1232
24	2.8193	2.5953	2.4025	2.4949	2.4272	2.347	2.4764
Max	3.6969	3.3634	3.4743	3.3608	3.1741	3.4743	3.5667
Min	2.2405	2.2032	2.2177	2.1068	1.9978	2.1068	2.1807
Avg	2.9212	2.7571	2.7221	2.6953	2.6053	2.7154	2.8052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283032 / 22/11KV Ghansoli Gharonda

S/St

Feeder No / Name : 202 / 11 KV HAWARE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3014	1.2071	1.1888	1.1694	1.094	1.0829	1.1576
2	1.2071	1.094	1.1576	1.094	1.0374	1.0456	1.0829
3	1.2071	1.094	1.0829	1.0185	.9997	.9896	1.0269
4	1.2071	1.094	.9896	.9431	.9997	.9709	.9709
5	1.2449	1.1317	1.2323	1.0562	.9997	.9335	1.2323
6	1.358	1.2637	1.4377	1.1694	1.1883	1.1949	1.4003
7	1.8861	1.6787	1.531	1.3203	1.4712	1.4563	1.4937
8	1.9427	1.7541	1.6244	1.4901	1.7353	1.6244	1.7364
9	1.7353	1.6409	1.531	1.5844	1.6409	1.6617	1.643
10	1.5089	1.4901	1.4563	1.6221	1.4523	1.475	1.3817
11	1.4335	1.3392	1.4377	1.5844	1.251	1.363	1.3443
12	1.3014	1.2637	1.2637	1.4712	1.2136	1.1389	1.1389
13	1.2449	1.1883	1.2826	1.3957	1.0829	1.1016	1.1203
14	1.2071	1.0751	1.094	1.2826	1.0269	.9709	1.0829
15	1.1317	.9997	1.0562	1.1506	1.0082	.9522	1.0642
16	1.094	1.0269	1.0751	1.1128	.9149	.9149	1.0269
17	1.1128	1.0082	1.1694	1.1317	1.0082	1.0269	1.1576
18	1.3014	1.1949	1.3203	1.2637	1.1576	1.2136	1.3256
19	1.7164	1.531	1.6057	1.6032	1.5497	1.6057	1.643
20	1.773	1.5684	1.643	1.5844	1.587	1.6057	1.7551
21	1.7353	1.5497	1.6804	1.5655	1.587	1.587	1.7551
22	1.6598	1.5497	1.531	1.5466	1.475	1.5123	1.643
23	1.5278	1.4937	1.4563	1.3769	1.307	1.307	1.4563
24	1.4146	1.2826	1.251	1.2449	1.2071	1.1203	1.1949
Max	1.9427	1.7541	1.6804	1.6221	1.7353	1.6617	1.7551
Min	1.094	.9997	.9896	.9431	.9149	.9149	.9709
Avg	1.4272	1.3133	1.3374	1.3242	1.2498	1.2440	1.3264

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283032 / 22/11KV Ghansoli Gharonda

S/St

Feeder No / Name : 204 / 11 KV Severage Pump

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.3961	.3734	.3018	.2452	.3174	.3734
2	.415	.3772	.3547	.2641	.2452	.3174	.3547
3	.415	.3772	.3361	.2641	.2263	.2987	.3361
4	.3772	.3772	.2987	.2641	.2263	.2987	.2987
5	.3395	.3772	.2987	.3018	.2263	.3361	.3547
6	.3395	.3772	.3361	.3395	.3206	.3547	.4108
7	.4527	.5093	.3921	.3772	.3206	.3734	.4668
8	.5093	.5281	.4108	.415	.3395	.3921	.5601
9	.7733	.5658	.5975	.5658	.3584	.4854	.6535
10	.6224	.7356	.6722	.4904	.4904	.5601	.6908
11	.5847	.547	.679	.415	.4527	.6535	.6161
12	.5093		.5658	.4338	.415	.6348	.5228
13	.415		.4338	.3772	.3584	.2427	.4854
14	.4527		.2452	.3018	.2987	.3547	.4108
15	.3395		.3772	.2452	.3547	.2801	.4668
16	.3206		.4715	.2641	.2987	.4108	.3734
17	.3772		.4904	.2263	.4481	.4294	.2987
18	.2452	.3921	.3961	.2641	.5658	.3734	.3547
19	.4527	.4481	.3772	.3395	.4338	.4108	.4481
20	.415	.4108	.4527	.3206	.4108	.3547	.4668
21	.4527	.4715	.3772	.3206	.4481	.3961	.4668
22	.4715	.4904	.4715	.3206	.3772	.3734	.3921
23	.3961	.3734	.3772	.3018	.415	.3174	.4668
24	.3961	.415	.3921	.3018	.2641	.3206	.3734
Max	.7733	.7356	.679	.5658	.5658	.6535	.6908
Min	.2452	.3734	.2452	.2263	.2263	.2427	.2987
Avg	.4370	.4538	.4241	.3340	.3558	.3869	.4434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283032 / 22/11KV Ghansoli Gharonda

S/St

Feeder No / Name : 205 / 11 KV Swaraj Ghansoli

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0566	.056	.0549	.0566	.0566
2	.0566	.0566	.0377	.0549	.0549	.0566	.0377
3	.0566	.0566	.0377	.0549	.0549	.0566	.0377
4	.0566	.0566	.0377	.0566	.0549	.0566	.0377
5	.0566	.0566	.0566	.0537	.0549	.0566	.0566
6	.0754	.0566	.0566	.0537	.0549	.0566	.0566
7	.0754	.0566	.0572	.0732	.0732	.0754	.0754
8	.0754	.0566	.0754	.0732	.0549	.112	.0754
9	.0754	.0377	.1132	.0732	.0732	.0747	.0566
10	.0943	.0943	.0943	.0914	.0549	.056	.0566
11	.0566	.0943	.0754	.0914	.0377	.0934	.0566
12	.0943	.0754	.0934	.0732	.0754	.0943	.0377
13	.0754	.0566	.0934	.0549	.0566	.0747	.0377
14	.0566	.0566	.056	.0549		.0377	.0377
15	.0566	.0377	.056	.0549	.0377	.0377	.0377
16	.0566	.0377	.0373	.0549	.0754	.0377	.0377
17	.0377	.0566	.056	.0549	.0566	.0754	.0377
18	.0377	.0754	.056	.0549	.0754	.0377	.0566
19	.0566	.0943	.0934	.0366	.0754	.0566	.0377
20	.0566	.1132	.0747	.0366	.0943	.0754	.0943
21	.0566	.0754	.056	.0366	.0566	.0566	.0943
22	.0377	.0566	.0747	.0366	.0566	.0566	.0377
23	.0377	.0566	.056	.0366	.0377	.0377	.0566
24	.0377	.0566	.0566	.056	.0914	.0566	.0566
Max	.0943	.1132	.1132	.0914	.0943	.112	.0943
Min	.0377	.0377	.0373	.0366	.0377	.0377	.0377
Avg	.0597	.0637	.0649	.0572	.0614	.0619	.0526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283032 / 22/11KV Ghansoli Gharonda

S/St

Feeder No / Name : 206 / 11 KV SHAKTI SEC-8

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.1494	.112	.112	.0566	.0566	.0566
2	.056	.056	.0747	.056	.0566	.0566	.0566
3	.056	.056	.0747	.056	.0566	.0377	.0566
4	.056	.056	.0747	.056	.0566	.0377	.0754
5	.056	.056	.1307	.0566	.0566	.0754	.1307
6	.0747	.112	.1494	.0566	.1132	.112	.168
7	.2054	.2241	.168	.0754	.2452	.168	.2241
8	.2241	.2241	.168	.0754	.2075	.2054	.2054
9	.2614	.2241	.1867	.0754	.2263	.2427	.2054
10	.2054	.2427	.2054	.1886	.2263	.2054	.2054
11	.2054	.2241	.2241	.2075	.1867	.2241	.2241
12	.1867	.1867	.2075	.2263	.2054	.168	.1698
13	.168	.1867	.1886	.2263	.1494	.2054	.2075
14	.1867	.2054	.2263	.2263	.2054	.1886	.2263
15	.2241	.1867	.2263	.2263	.056	.0754	.2263
16	.2054	.2054	.2054	.2075	.168	.0566	.0754
17	.2241	.168	.2054	.2075	.1867	.1867	.0754
18	.2054	.168	.2054	.1886	.0377	.1867	.1698
19	.2054	.1867	.2241	.2075	.1886	.2054	.2452
20	.2054	.1867	.2054	.2263	.1867	.2054	.0943
21	.2054	.2054	.2054	.2263	.1867	.2054	.2452
22	.168	.1867	.1867	.1886	.168	.1307	.2263
23	.2054	.1867	.1867	.1132	.1867	.168	.0754
24	.0747	.1867	.168	.168	.0566	.0566	.056
Max	.2614	.2427	.2263	.2263	.2452	.2427	.2452
Min	.056	.056	.0747	.056	.0377	.0377	.056
Avg	.1642	.1696	.1754	.1523	.1446	.1442	.1542

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283032 / 22/11KV Ghansoli Gharonda

S/St

Feeder No / Name : 207 / 11 KV Tulsi Graphics

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0377	.0572	.0373	.0373	.0377
2	.0572	.0572	.0377	.0381	.0373	.0377	.0377
3	.0572	.0572	.0377	.0381	.0373	.0377	.0377
4	.0572	.0572		.0381	.0373		
5	.0572	.0572			.0373		
6	.0572	.0572			.0373	.0377	.0377
7	.0572	.0572	.0377		.0747	.0377	.0377
8	.0572	.0572	.0377		.056	.0377	.0566
9	.0572	.0762	.0566		.056	.0754	.0377
10	.0762	.0762		.056	.056	.0566	.0377
11	.0762	.0572	.0572	.056	.0566	.0754	.0377
12	.0572	.0572	.0572	.0747	.0566	.0377	.0377
13	.0572	.0572	.0572	.056	.0377		.0377
14						.0566	.0377
15					.0377		.0377
16	.0381						.0377
17				.056	.0566		
18			.0762	.056		.0566	.0754
19	.0762	.0377	.0572	.0934	.0566	.0377	.0943
20	.0572	.056	.0572	.056	.0377	.0566	.0566
21	.0572	.056	.0572	.056	.0566	.0566	.0566
22	.0572	.056	.0572	.0373	.0566	.0566	.0566
23	.0381	.0377	.0572	.056	.0377	.0566	.0566
24	.0572	.0572	.0377	.0572	.056	.0377	.0377
Max	.0762	.0762	.0762	.0934	.0747	.0754	.0943
Min	.0381	.0377	.0377	.0373	.0373	.0373	.0377
Avg	.0581	.0570	.0510	.0551	.0482	.0492	.0467

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283033 / 22/22 KV Lnt Mahape Swt stn

Feeder No / Name : 301 / 22KV Mahape MIDC (O/G-I) SHEDDABLE FEEDER HAVING WEEKLY
 Shree Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3336	1.2813		1.2193	1.1317		1.2826
2	1.3336	1.2787		1.1431	1.1317		1.2826
3	1.3336	1.2787		1.105	1.094		1.2449
4	1.3336	1.2411		1.0669	1.094		1.2449
5	1.3336	1.2411		1.2193	1.094		1.2071
6	1.3336	1.2411		1.1431	1.0562		1.1317
7	1.5242	1.1283		1.3336	1.0562		1.094
8	1.7147	1.2787		1.1431	1.2071		1.3203
9	1.829	1.4291		1.3336	1.3957	1.5165	1.6598
10	2.2481	1.6648		1.5451	1.8861	1.6221	
11	2.3011		2.0957	1.6204		1.9616	2.0576
12	2.2234	1.7405	1.9814	1.6204		1.773	2.1338
13	2.0727			1.4697		1.6975	2.0957
14	2.3365	1.8162	2.2481	1.5451		1.8107	
15	2.3741		2.21	1.5074		2.1125	2.4387
16	2.4495			1.5074		1.9993	2.5149
17	2.1857		2.3243	1.5074		1.8107	2.3624
18	2.035			1.432		1.6221	
19	1.5074		1.6385	1.3567	1.627	1.2449	1.7909
20	1.3943		1.2955	1.2813		1.094	1.6385
21	1.3567		.9907	1.2436		1.094	
22	1.4697	1.3243		1.2436		1.1694	1.5242
23	1.3336		1.1431	1.1305		1.1317	
24	1.3336	1.3943		1.1431			1.2449
Max	2.4495	1.8162	2.3243	1.6204	1.8861	2.1125	2.5149
Min	1.3336	1.1283	.9907	1.0669	1.0562	1.094	1.094
Avg	1.7371	1.3813	1.7697	1.3275	1.2522	1.5773	1.6458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283033 / 22/22 KV LnT Mahape Swt stn

Feeder No / Name : 302 / 22KV Mahape MIDC (O/G-II) SHEDDABLE FEEDER HAVING WEEKLY
New Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	09-FEB-18
HR	Load (MW)
10	4.8529
12	4.4076
14	4.654
22	3.4845
Max	4.8529
Min	3.4845
Avg	4.3498

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283033 / 22/22 KV Lnt Mahape Swt stn

Feeder No / Name : 303 / 22KV Shil

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1392	.6054		.5335	.5681		.5681
2	1.1392	.5676		.4954	.5681		.5681
3	1.1397	.5676		.4572	.5303		.5681
4	1.1397	.5676		.5335	.5303		.6439
5	1.1019	.5676		.4572	.5303		.5303
6	1.1019	.5676		.4954	.4924		.5303
7	1.1019	.5297		.4954	.4924		.606
8	1.1397	.4919		.4954	.4924		.5303
9	1.1397	.5297		.5676	.4924	.4929	.5303
10	1.2157	.6054		.454	.606		
11	.7189		.6478	.454	.6413	.679	.724
12	.7575	4.9567	.6478	.6432	.7545	.6439	.724
13	.6432			.5297	.5281	.5303	.6097
14	.6811	.606	.6478	.6054		.606	
15	.7567		.6859	.6054		.6818	.7621
16	.7189			.6432		.6439	.724
17	.6811		.6478	.6054		.6439	.7621
18	.6811			.5676		.6439	
19	.6811		.6859	.6054		.6439	.6478
20	.6811		.6478	.5676		.606	.6478
21	.6054		.6478	.5676		.5681	
22	.6054	.606		.6054		.606	.6097
23	.6432		.6478	.5681		.5681	
24	1.1392	.6054		.6097	.5681		.5681
Max	1.2157	4.9567	.6859	.6432	.7545	.6818	.7621
Min	.6054	.4919	.6478	.454	.4924	.4929	.5303
Avg	.8897	.8839	.6563	.5484	.5568	.6113	.6239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283033 / 22/22 KV Lnt Mahape Swt stn

Feeder No / Name : 304 / 22 Kv Ekvira

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0483	2.7435		2.4768	2.3243		2.7435
2	3.0483	2.738		2.4387	2.3243		2.7435
3	3.0483	2.6619		2.5149	2.2862		2.7435
4	3.0483	2.6619		2.3624	2.2862		2.6673
5	3.0483	2.6239		2.4387	2.3243		2.5911
6	3.0483	2.5859		2.5149	2.3243		2.553
7	3.4294	2.3958		2.4768	2.3243		2.4768
8	3.8485	2.738		2.7435	2.9721		3.1245
9	4.382	3.4986		3.8104	4.2676	4.3134	4.1914
10	5.2965	4.2378		4.1831	5.487	5.1821	
11	5.7422		5.6013	4.2591		5.1059	5.6775
12	5.9323	4.2378	5.7918	4.3732		5.4108	5.9823
13	4.3352			3.4986		4.0009	4.4582
14	5.5521	4.0567	5.6394	3.9549		5.2965	
15	5.476		5.3346	3.9929		5.3727	5.6775
16	5.7422			4.0309		4.9916	6.0204
17	5.2584		5.1059	3.3845		4.9154	5.9442
18	4.5725			2.6619		3.6199	
19	3.6961		3.7342	2.5479	3.7081	2.8959	3.5818
20	3.2388		3.4675	2.4718		2.7435	3.2769
21	2.9662		2.8959	2.4338		2.553	
22	2.8959	2.8756		2.2817		2.7816	2.7054
23	2.7887		2.6673	2.2817		2.6292	
24	2.8578	2.9721		2.5911	2.3243		2.8197
Max	5.9323	4.2378	5.7918	4.3732	5.487	5.4108	6.0204
Min	2.7887	2.3958	2.6673	2.2817	2.2862	2.553	2.4768
Avg	4.0125	3.0734	4.4709	3.0302	2.9128	4.1208	3.7883

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 284059 / 33/11 KV Sector- 12B, K

Khaira

Feeder No / Name : 202 / 11 KV SECTOR 10 HTP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4434	2.4072	2.4709	2.2314	2.452	2.2862	2.371
2	2.3167	2.2805	2.3954	2.1582	2.3577	2.1582	2.2262
3	2.2624	2.19	2.32	2.0485	2.2822	1.9936	2.1719
4	2.1357	2.0995	2.2445	1.9936	2.1879	1.9022	2.0814
5	2.1719	2.0633	2.3011	1.957	2.0936	1.8839	2.0452
6	2.4434	2.371	2.3954	2.0119	2.3577	1.9387	2.2805
7	2.8235	2.733	2.4897	2.1216	2.6029	2.3045	2.6063
8	2.9502	2.8416	2.6217	2.4143	2.6972	2.7252	2.6968
9	2.8959	2.8416	2.7726	2.8532	2.8858	2.8166	2.7511
10	2.6968	2.6063	2.7069	2.8715	2.6337	2.8166	2.6244
11	2.4977	2.6595	2.5972	2.9235	2.3045	2.5701	2.4253
12	.2172	2.5274	2.4143	2.8104	2.3045	2.2986	2.3167
13	2.2624	2.2445	2.3228	2.5463	2.0851	2.1719	2.19
14	2.2262	2.2445	2.2497	2.5652	2.1216	2.0995	2.2081
15	2.19	2.1502	2.1582	2.3388	2.0119	2.0814	2.0633
16	2.1719	2.1313	2.1033	2.1879	1.957	1.9909	2.009
17	2.2624	2.2068	2.2497	2.3577	2.0485	2.0452	2.19
18	2.4434	2.2822	2.4508	2.5463	2.268	2.3348	2.3891
19	3.0407	2.9047	3.0727	3.0178	2.8898	2.8597	3.0226
20	3.2941	2.9801	3.1276	3.1121	3.0178	3.0226	3.2398
21	3.1855	3.0744	3.1093	3.131	3.0727	3.1131	3.2398
22	3.0769	2.9424	2.9264	3.0367	2.8349	2.8416	3.1312
23	2.8054	2.6972	2.652	2.7915	2.5423	2.5882	2.8235
24	2.6425	2.6244	2.5652	2.5057	2.5086	2.3777	2.4434
Max	3.2941	3.0744	3.1276	3.131	3.0727	3.1131	3.2398
Min	.2172	2.0633	2.1033	1.957	1.957	1.8839	2.009
Avg	2.4773	2.5043	2.5299	2.5222	2.4382	2.3842	2.4811

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 284059 / 33/11 KV Sector- 12B, K

Khaira

Feeder No / Name : 203 / 11 KV SECTOR 9

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0144	2.0513	1.905	1.7558	1.8296	1.6461	1.7741
2	1.9035	1.9404	1.8673	1.6827	1.7918	1.5729	1.7002
3	1.8111	1.8665	1.8296	1.6827	1.7541	1.5181	1.6632
4	1.7741	1.8111	1.773	1.6278	1.6975	1.4815	1.5708
5	1.7741	1.7372	1.8296	1.5729	1.6221	1.4632	1.6263
6	2.1992	2.0883	2.2257	1.6461	2.1691	1.6278	2.3655
7	2.5503	3.0308	2.7161	2.4143	2.9424	2.6703	3.0862
8	3.4928	2.8829	2.6217	2.3411	2.6783	2.524	2.7905
9	2.6797	2.5873	2.4143	2.3777	2.4709	2.4874	2.5318
10	2.2361			2.3411	2.0668	2.3045	2.2731
11	2.0513	2.0559	1.8656	2.3011	1.9204	1.9589	1.885
12	1.9589	1.8673	1.8107	2.037	1.7924	1.7187	1.8665
13	1.8665	1.7353	1.6644	1.9427	1.7375	1.6632	1.7741
14	1.7926	1.6787	1.6461	1.773	1.6461	1.5708	1.7556
15	1.7372	1.7164	1.5181	1.6598	1.6095	1.4784	1.6448
16	1.6817	1.7164	1.5364	1.6598	1.5364	1.423	1.7187
17	1.7556	1.5844	1.6095	1.7164	1.5546	1.5524	1.6632
18	1.9035	1.7164	3.5117	1.7918	1.7193	1.6632	1.7926
19	2.2916	2.1691	2.1582	2.1502	2.2314	2.2177	2.347
20	2.5318	2.3011	2.3777	2.2445	2.268	2.3285	2.5873
21	3.4558	3.3762	3.3288	3.3008	3.2007	3.1602	3.271
22	2.4764	2.3011	2.268	2.2822	2.1948	2.1807	2.4764
23	2.3285	2.037	2.0851	2.0748	1.9387	2.0698	2.2916
24	2.1068	2.1437	1.9427	1.9204	1.8673	1.7558	1.848
Max	3.4928	3.3762	3.5117	3.3008	3.2007	3.1602	3.271
Min	1.6817	1.5844	1.5181	1.5729	1.5364	1.423	1.5708
Avg	2.1822	2.1041	2.1089	2.0124	2.0100	1.9182	2.0960

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 284059 / 33/11 KV Sector- 12B, K

Khaira

Feeder No / Name : 204 / 11 KV SISILY PARK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3241	.3086	.3584	.3077	.3395	.2915	.2743
2	.3086	.2932	.3395	.2915	.3395	.2753	.2743
3	.2932	.2932	.3206	.2753	.3395	.2753	.2591
4	.2778	.2778	.3018	.2753	.3206	.2915	.2591
5	.2932	.2778	.3206	.2753	.3206	.2915	.2743
6	.2932	.2932	.3206	.2915	.3395	.2915	.2743
7	.3241	.3395	.3206	.2591	.3395	.2915	.2896
8	.3549	.3241	.3395	.2915	.415	.3077	.3048
9	.3241	.3395	.3584	.3725	.3961	.2915	.2743
10	.2932	.2932	.3239	.3401	.2591	.3239	.2896
11	.2778	.3206	.2429	.3395	.2591	.2743	.2743
12	.3086	.3961	.3086	.415	.2429	.2439	.2896
13	.2623	.3395	.3429	.415	.2429	.2743	.2591
14	.2469	.3206	.3086	.3772	.2105	.2439	.2439
15	.216	.3018	.2591	.3395	.2105	.1981	.2286
16	.2006	.2829	.2429	.3018	.2105	.1981	.2134
17	.2315	.3018	.2915	.3018	.2591	.2439	.2743
18	.3241	.3206	.3077	.3584	.2743	.2743	.2591
19	.3241	.3395	.3239	.3961	.2915	.2896	.3201
20	.3395	.3584	.3077	.3961	.3077	.3048	.3353
21	.3549	.3772	.3725	.3772	.3401	.3048	.3506
22	.3549	.415	.3725	.415	.3401	.3048	.3506
23	.3395	.3772	.3401	.3772	.3239	.3048	.3353
24	.3395	.3241	.3772	.3077	.3584	.2915	.2743
Max	.3549	.415	.3772	.415	.415	.3239	.3506
Min	.2006	.2778	.2429	.2591	.2105	.1981	.2134
Avg	.3003	.3256	.3209	.3374	.3034	.2784	.2826

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 284059 / 33/11 KV Sector- 12B, K

Khaira

Feeder No / Name : 205 / 11 KV BHAKTI HTP 12A

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.763	.6952	.7545	.6516	.7167	.583	.6972
2	.7122	.6443	.7167	.6173	.6979	.583	.5935
3	.6783	.5935	.679	.6173	.679	.5658	.5765
4	.5935	.5256	.6413	.583	.6413	.5658	.5426
5	.6274	.5596	.679	.5658	.6036	.5487	.5596
6	.6783	.6274	.7167	.583	.7167	.5487	.6783
7	.78	.763	.7545	.6001	.8676	.6687	.8139
8	.78	.7969	.8676	.6516	.7733	.7888	.7461
9	.8309	.7461	.8676	.7888	.8676	.8745	.7969
10	.7969	.763	.8745	.8059	.7373	.823	.7969
11	.763	.7733	.7545	.9242	.6173	.8309	.6274
12	.6104	.7356	.7545	.8488	.6001	.6274	.7282
13	.6274	.7167	.7202	.9054	.6344	.5935	.6104
14	.5935	.6036	.6859	.7545	.5487	.6104	.5596
15	.5765	.6036	.6001	.679	.5144	.5087	.4917
16	.5256	.6036	.5658	.6224	.5144	.5256	.5087
17	.5596	.5658	.5658	.6224	.4973	.4748	.5087
18	.5426	.6036	.6173	.6224	.5487	.5426	.5596
19	.7122	.7356	.7545	.811	.7202	.7461	.763
20	.7122	.7733	.8059	.8299	.7545	.7122	.763
21	.78	.7922	.7373	.7922	.7545	.763	.763
22	.7969	.7922	.7373	.811	.7373	.7461	.78
23	.78	.811	.7202	.7545	.6687	.7122	.7291
24	.8139	.7461	.7922	.6859	.7545	.6173	.6952
Max	.8309	.811	.8745	.9242	.8676	.8745	.8139
Min	.5256	.5256	.5658	.5658	.4973	.4748	.4917
Avg	.6931	.6905	.7235	.7137	.6736	.6484	.6620

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 284059 / 33/11 KV Sector- 12B, K

Khaira

Feeder No / Name : 206 / 11 KV SECTOR 8

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8962	.9149	.8488	.5304	.547	.5304	.5601
2	.8402	.8775	.7922	.5304	.547	.4938	.5041
3	.8029	.8402	.7545	.5304	.5281	.4755	.4668
4	.7468	.7842	.7167	.4755	.4904	.439	.4294
5	.7842	.7468	.7733	.4755	.4904	.439	.4294
6	1.0269	.8215	.9242	.4755	.6979	.5121	.5415
7	1.1576	1.307	1.094	.6036	.8488	.7499	.7468
8	1.2986	1.1389		.6219	.811	.695	.8215
9	1.0456	1.0829	.6979	.5853	.7167	.6401	.6908
10	.9709	.9149	.6767	.567	.5853	.6036	.6535
11	.8775	.811	.6219	.5847	.6219	.5415	.5415
12	.8215	.8488	.6036	.679	.5304	.4854	.5228
13	.8215	.7356	.6036	.679	.5304	.5415	.5415
14	.7468	.6602	.6036	.6224	.4938	.4481	.5121
15	.7468	.6602	.5487	.547	.4755	.3921	.4854
16	.7282	.7545	.5304	.5281	.439	.4294	.5041
17	.7655	.7356	.5304	.5093	.5487	.4294	
18	.7468	.7733	.6036	.5658	.5853	.5041	.5788
19	.9709	.9619	.7133	.7167	.7316	.6348	.6908
20	1.1016	.9619	.7133	.7167	.6584	.7095	.7655
21	1.2883	1.226	.823	.8299	.823	.7655	.8589
22	1.0456	.9808	.6584	.6224	.6584	.6161	.7282
23	1.0456	1.0185	.6401	.6602	.6219	.6535	.7655
24	.9335	.9709	.8865	.567	.5658	.5853	.5975
Max	1.2986	1.307	1.094	.8299	.8488	.7655	.8589
Min	.7282	.6602	.5304	.4755	.439	.3921	.4294
Avg	.9254	.897	.7112	.5927	.6061	.5548	.6059

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 284059 / 33/11 KV Sector- 12B, K

Khaira

Feeder No / Name : 207 / 11 KV SHUBHAM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4266	1.39	1.3014	1.1706	1.226	1.0608	1.134
2	1.3535	1.3169	1.2071	1.134	1.1883	1.0242	1.0974
3	1.2803	1.2437	1.1317	1.0974	1.1317	.9877	1.0242
4	1.2254	1.1888	1.0562	1.0608	1.094	.9694	.9694
5	1.1706	1.1523	1.1128	1.0425	1.0374	.9511	1.0059
6	1.39	1.262	1.1694	1.0791	1.2071	.9877	1.1157
7	1.5546	1.4998	1.226	1.1523	1.4523	1.1523	1.4632
8	1.4815	1.4632	1.226	1.2803	1.5089	1.2254	1.4083
9	1.4632	1.4449	1.4712	1.3352	1.3957	1.39	1.4998
10	1.39	1.2986	1.3352	1.4449	1.2803	1.4083	1.3169
11	1.39	1.3957	1.2986	1.4523	1.1523	1.3535	1.2071
12	1.2437	1.2826	1.2803	1.4146	1.0974	1.2254	1.1157
13	1.1888	1.3392	1.2437	1.4523	1.0791	1.1157	1.1157
14	1.1523	1.2071	1.1706	1.358	1.0608	1.0974	1.2071
15	1.1706	1.094	1.1157	1.226	1.0608	1.0059	1.0791
16	1.2254	1.0562	.9694	1.1506		1.0059	1.0608
17	1.0059	1.0562	1.1157	1.1506	.9877	.9877	1.0974
18	1.1523	1.0562	1.1157	1.1128	1.0425	1.0791	1.0425
19	1.39	1.3769	1.3717	1.4146	1.2437	1.262	1.39
20	1.4632	1.358	1.3717	1.3769	1.3352	1.3352	1.4632
21	1.4998	1.4712	1.4632	1.4335	1.39	1.3535	1.4815
22	1.5546	1.4146	1.3535	1.3957	1.3535	1.3352	1.5546
23	1.5364	1.3769	1.3352	1.3203	1.2254	1.2803	1.4815
24	1.4998	1.4632	1.358	1.2803	1.3203	1.1157	1.2437
Max	1.5546	1.4998	1.4712	1.4523	1.5089	1.4083	1.5546
Min	1.0059	1.0562	.9694	1.0425	.9877	.9511	.9694
Avg	1.3420	1.3003	1.2417	1.2640	1.2118	1.1546	1.2323

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283019 / 22/11KV Vashi, Sec-1 S/Stn

Feeder No / Name : 201 / 11KV VASHI PLAZA OG SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.567	.5359	.5121	.4887	.4525	.4755	.5121
2	.5359	.5175	.5304	.4706	.4207	.439	.4755
3	.5729	.5487	.5175	.4344	.3841	.3841	.4435
4	.5544	.567	.4572	.4477	.4066	.4024	.462
5	.5914	.6036	.462	.4656	.4854	.462	.5415
6	.6099	.5914	.4805	.4477	.5359	.4805	.5788
7	.5217	.6468	.5175	.4298	.5729	.5228	.6161
8	.6908	.6283	.499	.4477	.5729	.5041	.5359
9	.8962	.9231	.6653	.5853	.8779	.7282	.9328
10	1.2803	1.267	1.0059	.7947	1.1765	.9979	1.267
11	1.6644	1.5384	1.39	1.0903	1.4449	1.2936	1.5364
12	1.7013	1.4661	1.2803	1.086	1.5565	1.3352	1.5546
13	1.6297	1.4148	1.2851	1.0136	1.4327	1.2986	1.576
14	1.5581	1.4148	1.3575	.9593	1.3213	1.1584	1.5581
15	1.5927	1.3611	1.1946	.8145	1.3394	1.1584	1.5746
16	1.5581	1.3643	1.262	.7522	1.448	1.2489	1.6108
17	1.5402	1.3969	1.3352	.8238	1.4327	1.3756	1.7918
18	1.4864	1.379	1.1523	.823	1.3073	1.2357	1.5546
19	1.4299	1.267	1.1222	.9412	1.3575	1.2489	1.4083
20	1.1523	1.0242	1.086	.8688	1.1222	1.1403	1.2803
21	1.0059	.9511	.9694	.7865	.9511	1.0242	1.0974
22	.7682	.7499	.6697	.6401	.8048	.7682	.7762
23	.6653	.6219	.543	.5792	.5853	.5792	.6283
24	.6036	.5788	.5304	.5121	.4887	.5121	
Max	1.7013	1.5384	1.39	1.0903	1.5565	1.3756	1.7918
Min	.5217	.5175	.4572	.4298	.3841	.3841	.4435
Avg	1.0490	.9732	.8677	.6960	.9366	.8656	1.0571

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283019 / 22/11KV Vashi, Sec-1 S/Stn

Feeder No / Name : 202 / 11KV RAILWAY QUARTERS OG SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4563	1.4632	1.4523	1.4563	1.307	1.3443	1.2696
2	1.419	1.4563	1.3817	1.419	1.251	1.2883	1.2136
3	1.5684	1.4045	1.419	1.307	1.2136	1.2323	1.1763
4	1.6617	1.475	1.363	1.2696	1.1763	1.1763	1.3256
5	1.7924	1.531	1.4003	1.2883	1.3203	1.1016	1.4937
6	1.8671	1.587	1.4901	1.3256	1.4563	1.307	1.6617
7	1.9993	1.8111	1.4335	1.531	1.6804	1.4712	1.8484
8	1.7918	1.8671	1.4901	1.5497	1.6991	1.7541	1.8484
9	1.8671	1.773	1.6409	1.4146	1.6787	1.5466	1.7541
10	1.9239	1.7918	1.6409	1.5089	1.6598	1.5089	1.6598
11	1.7551	1.7918	1.7918	1.5844	1.587	1.5089	1.7353
12	1.8107	1.7541	1.6975	1.5844	1.5089	1.3769	1.6598
13	1.8484	1.4901	1.3957	1.5278	1.4901	1.226	1.643
14	1.7164	1.6409	1.4335	1.3957	1.358	1.3014	1.643
15	1.6975	1.5497	1.5089	1.2826	1.4335	1.2637	1.4523
16	1.6221	1.5655	1.5278	1.2637	1.4901	1.3392	1.4901
17	1.5655	1.6057	1.6032	1.2826	1.5278	1.4335	1.5844
18	1.7364	1.6057	1.5123	1.4563	1.5844	1.531	1.6032
19	1.8671	1.9044	1.7924	1.6221	1.7551	1.8673	1.9427
20	1.9959	1.9774	1.9231	1.8484	1.922	1.8484	2.0328
21	2.0165	2.0538	1.9605	1.7926	1.8858	1.885	2.0668
22	1.8298	1.8298	1.6244	1.6448	1.6804	1.6804	1.6991
23	1.7551	1.7364	1.5123	1.6617	1.643	1.5497	1.6244
24	1.5278	1.4842	1.4901	1.475	1.4003	1.4563	1.3256
Max	2.0165	2.0538	1.9605	1.8484	1.922	1.885	2.0668
Min	1.419	1.4045	1.363	1.2637	1.1763	1.1016	1.1763
Avg	1.7538	1.6729	1.5619	1.4788	1.5295	1.4583	1.6147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283019 / 22/11KV Vashi, Sec-1 S/Stn

Feeder No / Name : 204 / 11KV HTP ABHYUDAYA BANK OG SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7133	.7316	.695	.695	.5487	.6154	.6401
2	.6767	.695	.6767	.6154	.5304	.5792	.6036
3	.6468	.6584	.6283	.543	.499	.5304	.5729
4	.6468	.5853	.5729	.5068	.5175	.4755	.5359
5	.6653		.5544	.5249	.5788	.5175	.5601
6	.6722		.5544	.5068	.6161	.5729	.5914
7	.6908	.6468	.6099	.5304	.6722	.6036	.6468
8	.7207	.7095	.6468	.6036	.8029	.6584	.7207
9	.8686	.8501	.7762	.7577	.8402	.7865	.7947
10	1.2883	1.3717	1.1888	.8501	1.2012	1.1273	1.3352
11	2.0328	1.8473	1.5524	1.251	1.8665	1.587	1.9204
12	2.1068	1.9589	1.6817	1.3491	1.8665	1.5912	1.9753
13	1.9753	1.7924	1.6095	1.3491	1.7741	1.5546	2.0119
14	1.9404	1.7558	1.5364	1.2936	1.6827	1.5546	1.8656
15	2.0698	1.8656	1.5364	1.1643	1.7558	1.5364	2.0698
16	1.9774	1.829	1.6827	1.1523	1.8473	1.5912	2.1068
17	1.957	1.9387	1.6278	1.2254	1.829	1.5912	2.1582
18	1.8473	1.7375	1.6461	1.2071	1.829	1.5746	2.0668
19	1.8823	1.8461	1.6651	1.3717	1.8473	1.6827	2.0302
20	1.0791	1.6095	1.6832	1.4266	1.647	1.5546	1.9022
21	1.5181	1.4266	1.3575	1.2803	1.46	1.3394	1.6095
22	1.1523	1.0719	1.0242	1.0608	1.0719	1.0242	1.1888
23	.7865	.7947	.7316	.7865	.7316	.7207	.8501
24	.7499	.7499	.724	.7207	.695	.6335	.6584
Max	2.1068	1.9589	1.6832	1.4266	1.8665	1.6827	2.1582
Min	.6468	.5853	.5544	.5068	.499	.4755	.5359
Avg	1.2777	1.2942	1.1234	.9488	1.1963	1.0834	1.3090

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283019 / 22/11KV Vashi, Sec-1 S/Stn

Feeder No / Name : 205 / 11KV NBSA OG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5788	.5601	.5228	.5975	.4854	.4715	.5415
2	.5228	.5415	.4668	.5601	.4668	.4338	.5041
3	.5041	.5228	.4668	.5228	.4294	.4481	.4668
4	.4668	.5601	.4854	.5175	.4481	.5041	.4854
5	.5415	.5788	.5228	.5359	.5041	.5415	.5601
6	.6722	.5975	.5601	.5415	.5788	.5788	.6161
7	.7468	.6535	.6161	.5415	.6348	.6224	.6722
8	.8215	.8215	.6036	.6161	.7545	.7167	.8299
9	.7545	.7577	.6602	.6413	.6722	.6602	.6602
10	.811	.8589	.6908	.6979	.679	.6478	.7655
11	.811	.8215	.7282	.7167	.7356	.6602	.8029
12	.8488	.9145	.8029	.679	.7842	.6535	.7842
13	.924	.8779	.7655	.679	.7655	.6979	.7842
14	.8501	.8145	.6348	.5658		.6161	.8215
15	.8029	.7865	.5975	.6224	.7282	.5041	.8029
16	.7545	.6838	.547	.5658	.6908	.5281	.8029
17	.6979	.6413	.5788	.5281	.7095	.5281	.7468
18	.7468	.8871	.7392	.7023	.8131	.6908	.8962
19	1.0608	1.0608	.8686	.924	.8871	.8501	1.1763
20	1.0791	1.0425	.9795	.9979	.9511	1.0164	1.2071
21	.9055	.9877	.8779	.9145	.924	.8215	.8962
22	.7947	.7762	.6653	.7682	.7392	.7655	.9412
23	.6722	.7316	.6653	.7023	.6653	.7023	.7947
24	.6161	.5788	.5415	.6161	.5415	.5093	.5601
Max	1.0791	1.0608	.9795	.9979	.9511	1.0164	1.2071
Min	.4668	.5228	.4668	.5175	.4294	.4338	.4668
Avg	.7494	.7524	.6495	.6564	.6777	.6320	.7550

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283019 / 22/11KV Vashi, Sec-1 S/Stn

Feeder No / Name : 206 / 11KV SEC-6 ROW OG SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7316	.7316	.695	.6348	.6584	.6335	.6697
2	.7023	.695	.7133	.5975	.6283	.6219	.6401
3	.6838	.7133	.6838	.5601	.5729	.5853	.6219
4	.7207	.7023	.7023	.6348	.5975	.5544	.6653
5	.7392	.6838	.6653	.6535	.6535	.5914	.7282
6	.7842	.7023	.6908	.6348	.7095	.6535	.7655
7	.8589	.8316	.7842	.6468	.7842	.7468	.8215
8	.9149	.8131	.7468	.6468	.8488	.7842	.8029
9	.8215	.7655	.8402	.7468	.7733	.7842	.7468
10	.7842	.8589	.7468	.7655	.8029	.8215	.7655
11	.7655	.7655	.7655	.7282	.7095	.7095	.7468
12	.7095	.7207	.7282	.7282	.6161	.6535	.7282
13	.6722	.6099	.6653	.6908	.6468	.6348	.6283
14	.6224	.6099	.5601	.6348		.6161	.5788
15	.6348	.5544	.5175	.5601	.5415	.5415	.6161
16	.5544	.5788	.5415	.5975	.5415	.5415	.6117
17	.5544	.6161	.5788	.5228	.5914	.4854	.5601
18	.5914	.6219	.6653	.6401	.5792	.6036	.6036
19	.7316	.8048	.7499	.7865	.7865	.8048	.7682
20	.8962	.8962	.8596	.8962	.9328	.9425	.9511
21	.8413	.8596	.8688	.8145	.823	.8779	.9694
22	.8413	.8779	.7522	.8048	.7865	.823	.8596
23	.8596	.8048	.7343	.7499	.7682	.7682	.823
24	.7865	.7682	.7316	.6722	.7133	.6697	.7059
Max	.9149	.8962	.8688	.8962	.9328	.9425	.9694
Min	.5544	.5544	.5175	.5228	.5415	.4854	.5601
Avg	.7418	.7328	.7078	.6812	.6985	.6854	.7241

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 302 / 22KV JAYSYNTH O/G FEEDER SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2507	.2641	.3018	.2987	.3018	.3018	.3018
2	.2507	.2641	.3018	.2614	.3018	.3395	.3018
3	.2507	.2641	.3018	.2614	.3018	.3395	.3018
4	.2507	.2641	.3018	.2614	.3018	.3395	.3018
5	.2865	.2641	.3395	.2987	.3018	.3018	.3395
6	.2865	.2641	.3395	.2987	.3395	.3018	.3395
7	.3224	.3018	.3395	.2641	.3395	.3395	.3395
8	.3224	.3018	.3395	.2641	.3395	.3395	.3395
9	.2865	.3018	.3018	.2641	.3018	.3395	.3395
10		.3018	.3018		.3018	.3395	
11	.2659	.2641	.3395	.3395	.3018	.3395	.3395
12	.3018	.2263	.3018		.3395	.3018	.3395
13	.2277	.3018	.3018	.3018	.3018	.3395	
14		.2641	.3395	.3018	.3395	.3018	
15		.3018	.3018	.3018	.2641	.3018	
16		.2641	.2641	.3018	.3018	.3395	.3018
17	.3042	.3395	.3018	.3018	.3018	.3018	.3395
18	.3018	.3018	.3018	.3395	.3395	.3395	.3395
19		.3018	.3018	.3395	.3395	.3018	.3018
20		.3018	.3018		.3395	.3018	
21		.3018	.3395		.3395	.3018	.3395
22		.3018	.3018	.3395	.3395	.3018	
23	.2641	.3018	.3018		.3395	.3018	
24	.2865	.3018	.3018	.3018	.3018	.3395	.3018
Max	.3224	.3395	.3395	.3395	.3395	.3395	.3395
Min	.2277	.2263	.2641	.2614	.2641	.3018	.3018
Avg	.2787	.2861	.3112	.2969	.3175	.3207	.3240

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 303 / 22KV AKSHAR FEEDER (OLD SHEDDABLE FEEDER HAVING WEEKLY
PHIZER Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT))

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	1.0185	1.0562	1.094	1.0562	1.1317	1.0185
2	1.1317	1.0185	1.0562	1.094	1.0562	1.094	1.0185
3	1.094	1.0562	.9808	1.1317	1.0562	1.094	1.0185
4	1.094	1.0562	.9431	1.1317	1.0562	1.0562	1.0562
5	1.0562	1.0562	.9808	1.1317	1.0562	1.094	1.0562
6	1.0185	1.0562	1.0185	1.1317	1.0562	1.1317	1.0562
7	1.0185	1.0562	1.0185	1.1317	1.0562	1.1317	1.0562
8	1.1317	1.1317	1.1694	1.2826	.9808	1.0562	.9808
9	1.2826	1.1694	1.2449	1.2826	1.1317	.9808	2.2634
10		1.3203	.8676		1.358	1.2071	
11	1.6975	1.4712	1.6975	1.5089	1.5089	1.1694	1.7423
12	1.6598	1.4712	1.7353		1.5466	1.2071	1.6221
13	1.3957	1.2826	1.6221	1.1317	1.5089	1.2071	
14		1.6975	1.6221	1.1317	1.5844	1.6975	
15		1.6221	1.9616	1.1317	1.8861	1.7353	
16		1.5844	2.037	1.0562	1.8861	1.6598	2.0473
17	1.6598	1.2449	1.5089	1.0562	1.6975	1.2449	1.6598
18	1.5089	1.094	1.2449	.9808	1.3957	1.1694	1.5089
19		1.0185	1.1317	.9431	1.2071	.9808	1.2071
20		.9808	.9808		1.0185	.9431	
21		.9054	.9431		.9808	.9431	.9431
22		.9431	.9431	.9054	.9431	.8299	
23	1.1317	.9808	1.0562		1.0185	.7922	
24	1.2071	1.0562	1.094	1.1317	1.1317	1.094	1.0185
Max	1.6975	1.6975	2.037	1.5089	1.8861	1.7353	2.2634
Min	1.0185	.9054	.8676	.9054	.9431	.7922	.9431
Avg	1.2637	1.1788	1.2464	1.1257	1.2574	1.1521	1.3102

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 304 / 22KV NOVARTIS EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 FEEDER Feeder KV- 22 / (CONTINUOUS PROCESS)(NO STAGGERING)
 OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0754	.0754	.0754	.0754	.0754	.0754
2		.0754		.0754	.0754		.0754
3	.0747	.0754	.0754	.0754	.0754	.0754	
4	.0747	.0754		.0754	.0754		.0754
5	.0747	.0754	.0754	.0754	.0754	.0754	.0754
6	.0747	.0754		.0754	.0754		
7	.0747	.0754	.0754	.0754	.0754	.0754	.0754
8	.0747	.0754		.0754	.0754		
9	.0747	.0754	.0754	.0754	.0754	.0754	.0754
10		.0754	.0754		.0754	.0754	
11	.1132		.0754	.0754	.0754	.0754	1.0185
12	.1132	.0754	.0754		.0754	.0754	1.0562
13		.1132	.0754	.0754	.0754	.0754	
14		.1132	.0754	.0754	.0754	.0754	
15		.1132	.0754	.0754	.0754	.0754	
16		.1132	.0754	.0754	.0754	.0754	.0754
17	.0756	.1132	.0754	.0754	.0754	.0754	.0754
18	.0756	.0754	.0754	.0754	.0754	.0754	.0754
19			.0754	.0754	.0754	.0754	.0754
20		.0754			.0754		
21			.0754		.0754	.0754	.0754
22		.0754	.0754	.0754	.0754		
23	.0754	.0754	.0754		.0754	.0754	
24	.0747	.0754	.0754	.0754	.0754	.064	.0754
Max	.1132	.1132	.0754	.0754	.0754	.0754	1.0562
Min	.0747	.0754	.0754	.0754	.0754	.064	.0754
Avg	.0804	.0844	.0754	.0754	.0754	.0748	.2128

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 305 / 22KV PHIZER EXPRESS FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.061	.0152	.0015	.0015	.0015	
2		.061		.0015	.0015		
3		.061	.0152	.0015	.0015	.0015	.0015
4		.061		.0015	.0015		
5		.061		.0015	.0015	.0015	.0015
6		.0305	.0152	.0625	.0015		
7		.0152		.0015	.0015	.0015	
8		.0754		.0015	.0038		.0015
9		.0152	.0152	.0015	.0015	.0015	.0015
10			.0152		.0015		
11	.0152			.0754	.0015	.0015	.0152
12	.0152		.0152		.0152		.0152
13		.0152	.0015		.0015		
14			.0015	.0015	.0015		
15		.0152	.0152	.0015	.0015		
16			.0152	.0015	.0015		.0152
17	.0152		.0152	.0015	.0015	.0015	.0015
18	.0152		.0015	.0015	.0015		.0015
19			.0015	.0015	.0015	.0015	.0015
20		.0152	.0015		.0015		
21		.0152	.0015			.0015	.0572
22			.0015	.0015	.0015		
23	.0457	.0152	.0015		.0015	.0015	
24		.0305	.0015		.0015		.0015
Max	.0457	.0754	.0152	.0754	.0152	.0015	.0572
Min	.0152	.0152	.0015	.0015	.0015	.0015	.0015
Avg	.0213	.0365	.0084	.0094	.0022	.0015	.0096

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 306 / 22KV LUBRIZOL EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 FEEDER Feeder KV- 22 / (CONTINUOUS PROCESS)(NO STAGGERING)
 OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6975	1.7353	1.6221	1.1317	1.5844	1.5466	1.5844
2	1.6598	1.7353	1.5844	1.1317	1.5844	1.5089	1.5844
3	1.6598	1.7353	1.5466	1.094	1.5844	1.5089	1.5466
4	1.6221	1.773	1.4712	1.1317	1.5844	1.4712	1.5089
5	1.6221	1.773	1.5466	1.2071	1.5844	1.4712	1.5089
6	1.5844	1.8107	1.5844	1.4335	1.5844	1.5089	1.4712
7	1.5844	1.773	1.5844	1.5089	1.5844	1.5089	1.4712
8	1.4335	1.5844	1.6598	1.5089	1.5908	1.4335	1.2071
9	1.6975	1.4335	1.6975	1.5089	1.7078	1.2826	1.5844
10		1.6598	1.8484		1.6598	1.5844	
11	1.7423	1.773	1.8107	1.4335	1.6221	1.5466	1.515
12	1.8107	1.6975	1.7353		1.5844	1.5466	1.7353
13		1.6221	1.7353	1.3957	1.5089	1.5466	
14		1.6598	1.773	1.5089	1.5844	1.2449	
15		1.6598	1.6975	1.5844	1.6221	1.6221	
16		1.6975	1.773	1.6598	1.5089	1.6598	1.8861
17	1.6598	1.6598	1.6975	1.6975	1.5089	1.5089	1.7353
18	1.6598	1.6975	1.7353	1.7353	1.5844	1.6598	1.8107
19		1.4712	1.7353	1.7353	2.7538	1.7353	1.8861
20		1.773	1.773		1.6975	1.6221	
21		1.6975			1.5844	1.6598	1.8107
22		1.7353	1.773	1.6221	1.5844	1.6975	
23	1.7353	1.6975	1.6975		1.5466	1.6221	
24	1.7353	1.773	1.6975	1.773	1.5844	1.5466	1.6221
Max	1.8107	1.8107	1.8484	1.773	2.7538	1.7353	1.8861
Min	1.4335	1.4335	1.4712	1.094	1.5089	1.2449	1.2071
Avg	1.6603	1.6928	1.6861	1.4633	1.6385	1.5435	1.6158

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 307 / 22KV NANDKAMAL EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
FEEDER Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509			.0023		.0023	.0023
2	.1509						.0023
3	.1132			.0023			.0023
4	.1132					.0023	.0023
5	.1132			.0023			.0023
6	.1132						.0023
7	.1509			.0023	.0023		.003
8	.4904	.0023			.0023		.0107
9	.5281	.0023	.0023	.0023	.0023	.0023	.0107
10			.0023				
11	.0023		.0229	.0023	.0023		.5658
12	.0023		.0023		.0023		.6036
13	.6036	.0023	.0937	.0023	.0023		
14					.0023		
15			.0023		.0023		
16		.0023	.0023		.0023	.0023	.5658
17	.0023				.0023	.0084	.5281
18	.0023		.0023		.0023	.0046	.5281
19			.0023	.0023	.0023	.003	.1509
20		.0023	.0023		.0023	.003	
21						.003	.1509
22			.0023	.0937	.0023	.0023	
23	.0023	.0023	.0023		.0023	.0023	
24	.1509	.0023	.0023	.1132	.0023	.1132	.1132
Max	.6036	.0023	.0937	.1132	.0023	.1132	.6036
Min	.0023	.0023	.0023	.0023	.0023	.0023	.0023
Avg	.1681	.0023	.0109	.0225	.0023	.0124	.1909

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 308 / 22KV BALMER LAWARIE NON SHEDDABLE EXPRESS HV FEEDERS
 EXPRESS FE Feeder KV- 22 / (CONTINUOUS PROCESS)(NO STAGGERING)
 OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.037	1.6598	1.8107	1.6975	.6036	1.1317	1.5089
2	1.9616	1.6598	1.773	1.6598	.6036	1.1694	1.5466
3	1.9616	1.6598	1.6975	1.6598	.6036	1.1694	1.4712
4	1.8861	1.7353	1.6598	1.6221	.6036	1.1317	1.4335
5	1.8861	1.7353	1.5844	1.6221	.679	1.1694	1.4712
6	1.8107	1.8107	1.5466	1.6598	.7545	1.1694	1.5089
7	1.773	1.6975	1.5466	1.6975	.7922	1.5844	1.4335
8	1.8484	1.5089	1.5844	.5658	.7545	1.4335	1.5844
9	2.1125	1.7423	1.9993	.6413	.8676	1.5844	1.8107
10		1.773	1.9993		1.0185	1.773	
11	1.773	1.5844	2.0748	.6413	.9808		2.1125
12	1.7423	1.4335	1.7353		.7545	1.6598	1.7423
13		1.8107	1.8484	.6036	1.2449	1.8861	
14		1.6221	1.5844	.5658	1.0185	2.037	
15		1.5844	1.6221	.6036	.8299	1.5466	
16		1.8861	1.7353	.5658	1.1317	1.5089	2.037
17	1.6975	1.5844	1.5844	.6036	.9431	1.358	1.5844
18	1.8861	1.8484	1.9993	.5658	1.2071	1.9993	1.773
19		1.8861	1.8861	.5281	1.1317	1.9616	1.989
20		1.6598	1.8484		1.094	1.5466	
21		1.8484	1.8107		1.1317	1.5089	2.1125
22		1.7353	1.8107	.5281	1.2449	1.773	
23	1.515	1.8107	1.3203		.7922	1.4335	
24	2.1125	1.6221	1.8861	1.7353	.5281	1.1317	1.5466
Max	2.1125	1.8861	2.0748	1.7353	1.2449	2.037	2.1125
Min	1.515	1.4335	1.3203	.5281	.5281	1.1317	1.4335
Avg	1.8669	1.7041	1.7478	1.0404	.8881	1.5073	1.6862

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 309 / 22KV ZOETIS PHARMA (PHIZER NON SHEDDABLE EXPRESS HV FEEDERS
EX Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.3395	.3395	.3395	.3018	.3018	.4527
2	.3018	.3395	.3395	.3018	.3018	.3395	.4527
3	.3018	.3018	.3395	.3018	.3018	.3395	.4527
4	.3395	.3018	.3018	.3395	.3018	.3018	.4904
5	.3395	.3018	.3018	.3395	.3018	.3018	.4904
6	.3018	.3018	.3018	.3018	.3018	.3395	.4904
7	.3395	.3018	.3018	.3395	.3395	.3395	.4904
8	.3772	.3772	.3395	.3018	.3395	.4527	.4904
9	.4527	.5281	.3395	.3018	.4527	.5281	.5281
10		.4904	.415		.4904	.5281	
11	.6036	.5281	.5658	.3018	.5281	.5281	.679
12	.6036	.5281	.4904		.5658	.5281	.6036
13	.6036	.5281	.4527	.3018	.5281	.5281	
14		.5281	.2641	.3018	.6036	.5281	
15		.6413	.2641	.3018	.5281	.5658	
16		.5281	.3395	.3018	.5281	.6413	.679
17	.6413	.4904	.3395	.3018	.4904	.6036	.5658
18	.5658	.415	.3395	.3018	.4904	.4904	.5281
19		.3395	.3018	.3018	.4904	.4527	.4904
20		.3772	.3018		.4527	.4527	
21		.3395	.3018		.3772	.4527	.4527
22		.3018	.3018	.3018	.3772	.4527	
23	.3395	.3018	.3395		.3395	.4527	
24	.3395	.3395	.3395	.3018	.3018	.2987	.4527
Max	.6413	.6413	.5658	.3395	.6036	.6413	.679
Min	.3018	.3018	.2641	.3018	.3018	.2987	.4527
Avg	.4220	.4071	.3442	.3097	.4181	.4478	.5170

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 310 / 22 KV MAZDA FEEDER

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2263	.2263	1.0349	1.2826	1.5089	1.4712
2	.2641	.2263	.2263	1.0349	1.2826	1.4998	1.4335
3	.2641	.2263	.2263	.9979	1.2826	1.5089	1.4335
4	.2263	.2263	.2641	.9979	1.358	1.4712	1.3957
5	.2263	.2263	.2641	1.0349	1.358	1.5089	1.4335
6	.2641	.2263	.2641	1.0349	1.358	1.5089	1.4712
7	.2641	.2263	.2641	1.094	1.358	1.5844	1.5089
8	.3772	.2263	.2641	.2641	1.5089	1.6975	1.6221
9	.415	.3018	.3018	.3018	1.8861	1.8484	1.8107
10		.415	.5281		1.9239	2.1125	
11	.5281	.4904	.5281	.3395	1.9616	2.1879	2.1125
12	.6036	.4904	.5281		1.8861	2.1879	2.1125
13	.6036	.415	.4904	1.594	2.037	2.0748	
14		.3772	1.358	1.5844	2.1879	1.9993	
15		.4527	1.3957	1.5844	1.8861	1.9616	
16		.5281	1.3957	1.5089	1.5089	1.9616	2.1879
17	.5287	.5281	1.5089	1.5089	1.9993	2.1125	2.1502
18	.4904	.415	1.2826	1.5089	1.9616	1.9239	2.037
19		.3018	1.2449	1.5089	1.8107	1.6598	2.0094
20		.2641	1.2071		1.6975	1.773	
21		.2263	1.1317		1.6598	1.6598	1.7353
22		.2263	1.0562	1.3957	1.6598	1.5466	
23	.2641	.2263	1.0185		1.6221	1.5466	
24	.2263	.2263	.2263	1.094	1.4712	1.5089	1.5089
Max	.6036	.5281	1.5089	1.594	2.1879	2.1879	2.1879
Min	.2263	.2263	.2263	.2641	1.2826	1.4712	1.3957
Avg	.3608	.3206	.7167	1.1275	1.6645	1.7647	1.7314

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 311 / 22KV EVEREST NIVARA
Feeder KV- 22 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5281	.5281	.4904	.5281	.4527	.5281	.4904
2	.4904	.5281	.4904	.4904	.4527	.4527	.4904
3	.4904	.5281	.4904	.4904	.4527	.4527	.4527
4	.4527	.5658	.4527	.4527	.4527	.4904	.4527
5	.4904	.5658	.4527	.4527	.4527	.4904	.4527
6	.4527		.4527	.4904	.4527	.4527	.415
7	.4904	.415	.4527	.4527	.4527	.4527	.415
8	.4527	.415	.3772	.415	.4527	.4527	.415
9	.5658	.5281	.415	.4527	.6036	.5281	.4904
10		.5281	.4904		.6413	.5658	
11	.679	.5658	.5281	.415	.7167	.6413	.679
12	.679	.6036	.5281		.679	.6413	.679
13	.679	.5658	.5658	.4904	.679	.6036	
14		.6036	.5281	.4904	.679	.6413	
15		.6036	.5658	.4904	.6413	.7167	
16		.5658	.5658	.4904	.7167	.679	.7545
17	.679	.6036	.5658	.4904	.679	.7167	.7922
18	.679	.5281	.5281	.5281	.679	.6036	.7545
19		.5281	.5281	.5281	.6413	.6036	.7545
20		.4904	.5658		.5658	.5281	
21		.4904	.5658		.5281	.5658	.6036
22		.2263	.5658	.5281	.5281	.5658	
23	.6413	.4904	.5281		.4904	.5281	
24	.5281	.5658	.4904	.5658	.4904	.4904	.4904
Max	.679	.6036	.5658	.5658	.7167	.7167	.7922
Min	.4527	.2263	.3772	.415	.4527	.4527	.415
Avg	.5611	.5232	.5077	.4864	.5658	.5580	.5636

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 312 / 22KV CHUNABHATTI

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8676	.7545	.6036	.7545	.7545	.7922	.7545
2	.8676	.7545	.6036	.7922	.7545	.7545	.7167
3	.8299	.7167	.5658	.7922	.7545	.7167	.7167
4	.8299	.7167	.6036	.7545	.7545	.7167	.679
5	.8299	.7167	.6413	.7545	.7545	.7545	.679
6	.7922	.679	.6413	.7922	.7545	.7545	.679
7	.7922	.679	.6036	.8299	.7545	.7167	.679
8	.7545	.7922	.679	.7922	.756	.7545	.7167
9	.7545	.7545	.7922	.7545	.9054	.7545	.7922
10		.7922	.8676		1.0562	.9054	
11	.9808	.7922	.9808	.9054	1.0185	1.0562	1.0562
12	.9431	.7545	1.0562		1.0185	1.0185	1.0206
13	.9054	.679	.9054	.8676	.9431	.9054	
14		.7922	.9808	.8299	1.1317	1.0185	
15		.7545	1.0562	.8299	1.0562	.9431	
16		.7545	.9808	.8299	1.0562	.9054	.9808
17	1.0185	.8676	.9808	.8299	1.0185	1.0562	.9808
18	.9054	.7167	.9808	.7545	.9431	.9054	.9054
19		.6413	.9054	.7545	.8676	.8299	.8676
20		.6036	.8299		.8299	.7922	
21		.6036	.8299		.7922	.7545	.7922
22		.6036	.7922	.7545	.7922	.7545	
23	.7545	.5658	.8676		.8299	.7545	
24	.8676	.8299	.6036	.7545	.7545	.8299	.7545
Max	1.0185	.8676	1.0562	.9054	1.1317	1.0562	1.0562
Min	.7545	.5658	.5658	.7545	.7545	.7167	.679
Avg	.8559	.7215	.8063	.7962	.8771	.8394	.8101

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 303 / 22KV KUKSHET FEEDER

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1844	.1905	.8299	.184	.1981	.1677	.3067
2	.16	.192	.7545	.2515	.16	.1753	.3018
3	.1372	.2058	.8299	.1981	.1677	.1524	.2401
4	.1448	.136	.7545	.192	.1524	.1372	.221
5	.0762	.168	.9054	.2321	.1753	.1143	.1981
6	.0686	.0914	.8299	.1524	.1372	.0914	.1905
7	.061	.061	.9808	.0991	.0762	.0914	.1829
8	.0914	.1524	.9808	.0533	.1219	.208	.1677
9	.2766	.3048	.9431	.112	.218	.3525	.2134
10	.4531	.3978	1.0562	.2378	.3429	.5243	.3475
11	.4801	1.0185	1.1317	.3334	.4801	.6615	.3307
12	.5121	1.0562	.2561	.3086	.5548	.5407	.4588
13	.2454	.9431	.1753	.1646	.2683	.3757	.2629
14	.4458	.9054	.2926	.2477	.4801	.2926	.4115
15	.4062	.8299	.3841	.2572	.3963	.4359	.3429
16	.4359	.7922	.2926	.2366	.4096	.3715	.4054
17	.3864	.8299	.3429	.1677	.3932	.2896	
18	.298	.7545	.184	.0838	.3658		
19	.1372	.8299	.1296	.0686	.1219	.1677	.3384
20	.2134	.8299	.1067	.0686	.1219	.16	.3018
21	.1143	.218	.0762	.0838	.1753	.16	.2439
22	.144	.1753	.061	.0533	.1448	.1372	.1753
23	.2096	.1928	.1981	.2481	.1448	.2401	.2667
24	.2191	.184	.8299	.2683	.2286	.1981	.285
Max	.5121	1.0562	1.1317	.3334	.5548	.6615	.4588
Min	.061	.061	.061	.0533	.0762	.0914	.1677
Avg	.2459	.4775	.5552	.1793	.2515	.2628	.2815

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 304 / 22KV TATA TELE

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1694	1.0669	1.0669	1.0288
2	1.1317	1.0288	1.0669	1.0288
3	1.094	.9907	1.0288	.9907
4	1.0562	.9907	.9907	.9907
5	1.0562	1.0288	.9907	.9907
6	1.094	1.0288	1.0288	.9907
7	1.1317	.9907	1.0288	.9907
8	1.1694	.9907	1.105	1.0669
9	1.094	1.0288	1.3336	1.2193
10	1.1317	1.105	1.3717	1.2955
11	1.1694	1.105	1.4098	1.3717
12	1.1812	1.0669	1.4098	1.4098
13	1.1812	1.0669	1.3717	1.3336
14	1.2193	1.1431	1.4098	1.3336
15	1.2193	1.105	1.448	1.4098
16	1.2193	1.105	1.4098	1.3717
17	1.1812	1.105	1.4098	
18	1.1431	1.105	1.3336	
19	1.1431	1.0669	1.2574	
20	1.0669	1.0669	1.105	
21	1.0669	1.0669	1.0669	
22	1.0669	1.0669	1.0288	
23	1.0669	1.0288	1.0288	
24		1.0669	1.0669	1.0288
Max	1.2193	1.1431	1.448	1.4098
Min	1.0562	.9907	.9907	.9907
Avg	1.1327	1.0590	1.1987	1.1678

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 305 / 22KV NANDKAMAL + HPCL NON SHEDDABLE EXPRESS HV FEEDERS
 EXPRESS Feeder KV- 22 / (CONTINUOUS PROCESS)(NO STAGGERING)
 OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	1.105	.9808	1.1812	.6097	1.1431
2	.9526	1.0669	.9054	1.1431	.724	1.0669
3	.9907	.9907	.9431	1.2193	.8002	1.105
4	1.0288	.9145	.9054	1.1812	.8764	1.1431
5	.9526	.724	.9431	1.1431	.9907	1.1812
6	1.0288	.6859	.9808	1.0669	1.0288	1.1812
7	1.0288	1.1431	.9054	.9907	1.1431	1.1812
8	.9907	1.6385	.9431	1.0288	1.6385	1.448
9	.9907	1.6385	.9808	1.0288	1.6385	1.448
10	1.448	1.6004	.9808	1.0288	1.6385	1.448
11	1.6004	1.4712	1.0562	1.0669	1.6004	1.6004
12	1.6004	1.5466	1.0669	1.0669	1.6766	1.6766
13	1.6004	1.5089	1.105	1.0288	1.6004	1.6004
14	1.5242	1.5466	.9907	1.0288	1.6004	1.6004
15	1.5623	1.5466	1.1812	1.0288	1.7147	1.4861
16	1.7147	1.4335	1.2955	.6859	1.7528	1.5242
17	1.7528	1.1694	1.1812	.9907	1.6385	
18	1.0669	1.0185	1.1812	.9907	1.6004	
19	.6859	.9431	1.2574	1.0288	1.2955	
20	.8383	.9054	1.2955	1.0669	1.2574	
21	.7621	.9808	1.2955	.9907	1.1812	
22	.6097	.9054	1.1812	.6097	.724	
23	.6478	.8299	1.1431	.381	.8383	
24	1.0288	1.105	1.0185	1.2574	.381	.7621
Max	1.7528	1.6385	1.2955	1.2574	1.7528	1.6766
Min	.6097	.6859	.9054	.381	.381	.7621
Avg	1.1431	1.1841	1.0716	1.0097	1.2479	1.3292

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 307 / 22KV AMINES

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2862	2.3243	2.2257	1.3717	1.0288	.8383	.8764
2	2.2862	2.2862	2.2634	1.4098	1.0669	.8002	.8383
3	2.2481	2.21	2.2257	1.4861	1.0288	.8383	.8764
4	2.2862	2.2481	2.3011	1.6004	.9145	.8764	.9145
5	2.2481	2.3624	2.1879	1.5242	1.0288	.8383	.9145
6	2.21	2.2862	2.3011	1.2574	.9526	.8002	.8764
7	2.21	2.2481	2.1879	1.3336	.9145	.8383	.8383
8	2.4768	2.2862	2.2257	2.2481	.9907	.9145	.8002
9	2.7054	2.3624	2.2634	2.4768	1.0669	.9145	.9145
10	2.934	2.5149	2.3388	2.7435	1.2955	.9145	1.1431
11	2.8578	2.452	2.5652	2.7435	1.2193	.9907	1.2193
12	3.1626	2.3765	2.4768	1.0288	1.3336	.9907	1.3336
13	3.0483	2.3011	2.4006	1.2574	1.1812	.9145	1.0288
14	3.1245	2.2257	2.553	1.3336	1.2574	1.0288	1.3717
15	3.2007	2.1879	1.7147	1.2574	1.2955	1.105	1.3717
16	2.8578	2.2257	1.4861	1.4098	1.2955	.9907	1.3717
17	2.8197	2.2634	1.448	1.1431	1.0288	.9526	
18	2.7435	2.1879	1.3336	1.0669	1.0288	.9145	
19	2.8959	2.1502	1.6385	1.0288	.9907	.8764	1.0288
20	2.8197	2.1879	1.6004	.9907	.9526	.8764	1.0669
21	2.553	2.1502	1.4098	1.0288	.9526	.8383	1.0288
22	2.3624	2.2634	1.4098	.9526	.9145	.8002	.9907
23	2.4006	2.2257	1.3717	.9526	.8764	.8383	.9526
24	2.2481	2.3624	2.3011	1.448	.9526	.8764	.8383
Max	3.2007	2.5149	2.5652	2.7435	1.3336	1.105	1.3717
Min	2.21	2.1502	1.3336	.9526	.8764	.8002	.8002
Avg	2.6244	2.2787	2.0096	1.4622	1.0653	.8986	1.0271

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 308 / 22KV Vishal

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4954	.4527	.4954	.4191	.4191	.4572
2	.4572	.4572	.415	.4572	.4572	.4572	.4191
3	.4191	.4954	.4527	.4191	.4572	.4572	.4191
4	.4572	.4572	.415	.4572	.4191	.381	.4572
5	.4191	.4572	.415	.4191	.4572	.4572	.4191
6	.381	.4954	.4527	.4572	.4572	.381	.4572
7	.4191	.4572	.415	.4572	.4572	.381	.381
8	.4191	.4191	.3772	.4191	.4572	.4191	.3429
9	.381	.4191	.4527	.4191	.381	.4954	.381
10	.381	.4191	.3772	.4191	.4191	.4572	.381
11	.4572	.4527	.415	.4191	.4572	.4572	.4191
12	.4572	.415	.4572	.4191	.4954	.4954	.5335
13	.4191	.415	.4572	.4191	.381	.4954	.5335
14	.4572	.4527	.4191	.4191	.4191	.4954	.4191
15	.4954	.4527	.4572	.4191	.4954	.4572	.4572
16	.4572	.415	.4954	.4191	.4191	.4572	.4954
17	.4572	.4527	.4954	.4191	.4954	.4572	
18	.4191	.415	.4191	.4191	.3429	.4572	.381
19	.4954	.4527	.4954	.4572	.4572	.4572	.4954
20	.4954	.4527	.4572	.4572	.4191	.4572	.4572
21	.4954	.4527	.4572	.4572	.4954	.4572	.4572
22	.4572	.415	.4954	.4572	.4572	.381	.4572
23	.4954	.4527	.4572	.4572	.4572	.4191	.4572
24	.4572	.4572	.4527	.4572	.4572	.4572	.381
Max	.4954	.4954	.4954	.4954	.4954	.4954	.5335
Min	.381	.415	.3772	.4191	.3429	.381	.3429
Avg	.4461	.4469	.4440	.4382	.4429	.4461	.4373

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 309 / 22KV R & D

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7842	.7842	.7922	.8215	.7468	.6722	.6348
2	.8215	.7842	.7167	.7095	.7095	.7095	.5975
3	.7095	.7468	.7545	.6722	.7842	.6722	.5601
4	.6722	.7095	.7922	.6348	.7468	.6348	.5975
5	.6722	.7468	.679	.5975	.7842	.6722	.6348
6	.7095	.7468	.7167	.5975	.7095	.7095	.5975
7	.6722	.7095	.7922	.6348	.7095	.7095	.5601
8	.7468	.5975	.9054	.6722	.7095	.6348	.5228
9	.8215	.7468	.8299	.6348	.7842	.5228	.6348
10	.8589	1.0456	.9054	.6348	.7468	.6348	.7842
11	.9709	1.0562	.8299	.6348	.6348	.5975	.7095
12	.9709	.8299	.8962	.8215	.7468	.5228	.6348
13	.7468	.7922	.9335	.7468	.7842	.7095	.6722
14	.7842	.7545	.8215	.7095	.5975	.5975	.6348
15	.7842	.8299	.9335	.7842	.7095	.7842	.7095
16	.7842	.7545	.7095	.7095	.7842	.7842	.7468
17	.7468	.8299	.6722	.7095	.6348	.7468	
18	.6348	.7545	.4854	.6348	.5601	.7468	.5228
19	.5975	.6413	.4481	.3361	.3734	.4854	.4108
20	.4481	.4904	.5975	.3361	.3734	.4108	.3361
21	.5975	.5658	.5601	.4108	.3361	.3361	.7095
22	.5228	.7545	.5228	.4854	.4481	.4481	.4108
23	.8589	.7545	.6722	.4854	.7842	.6348	.7095
24	.7095	.7468	.7167	.7095	.7842	.7842	.7095
Max	.9709	1.0562	.9335	.8215	.7842	.7842	.7842
Min	.4481	.4904	.4481	.3361	.3361	.3361	.3361
Avg	.7344	.7572	.7368	.6301	.6659	.6317	.6105

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 310 / 22KV ALKALI GROUP (MANISH SHEDDABLE FEEDER HAVING WEEKLY
) Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8935	.9701	1.3203	.9297	.945	.756	.7087
2	.868	.9191	1.2826	.9065	.9214	.7324	.6615
3	.8169	.9957	1.2449	.8833	.9686	.756	.7087
4	.8425	.9957	1.1317	.9297	.8977	.7796	.6851
5	.7914	.9957	1.1694	.9686	.945	.8032	.7324
6	.7659	.8551	1.094	.945	.9065	.8269	.7087
7	.7148	.8032	1.1694	.9214	.9297	.8269	.6615
8	.8169	.9069	1.3957	.9922	.9762	.8505	.6142
9	.868	.8299	1.358	1.0631	.9065	.8269	.6851
10	.8425	.8299	1.5089	1.0631	.953	.8882	.9214
11	.9808	1.2449	1.5844	.8505	1.0227	.945	.9374
12	1.0814	1.2826	1.0898	.8032	1.1157	.8741	1.6766
13	1.2071	1.3957	1.0745	1.0395	1.1389	.9922	1.0974
14	1.1065	1.358	1.166	.9686	1.1157	.7796	1.2346
15	1.1065	1.358	.9831	.9686	1.0924	.8741	1.0517
16	1.1065	1.1694	.9145	.8977	1.0692	.945	1.0288
17	1.358	1.2071	1.2087	1.0631	1.2087	.9922	
18	1.0059	1.1317	.8833	.756	.9686	.7087	.5944
19	.7293	1.1694	.767	.6615	.7324	.5906	.7087
20	.7042	1.2071	.7438	.7087	.7087	.567	.8002
21	.7042	1.1694	.6741	.756	.8741	.4489	.7316
22	.9446	1.358	.8833	.8741	.8269	.5906	.823
23	1.0467	1.3957	1.0924	.9922	.8505	.8269	.9145
24	.868	.9957	1.358	.9065	.9686	.7796	.7324
Max	1.358	1.3957	1.5844	1.0631	1.2087	.9922	1.6766
Min	.7042	.8032	.6741	.6615	.7087	.4489	.5944
Avg	.9238	1.106	1.1291	.9104	.9601	.7900	.8443

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 284060 / 33/11KV Vashi, Sector- 19D

S/S

Feeder No / Name : 202 / 11 KV 'L' WING DANA MARKET

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.1886	.2172	.1715	.1886	.2126	.1886
2	.2058	.1886	.1949	.1886	.1715	.1949	.1886
3	.2058	.1715	.197	.1886	.1715	.1949	.1715
4	.2058	.1715	.1791	.1715	.1543	.1753	.1543
5	.1886	.1543	.1595	.1543	.1372	.1595	.1543
6	.1886	.1715	.1612	.1543	.1543	.1772	.1543
7	.1715	.1543	.1612	.1372	.1372	.1578	.1372
8	.1543	.1372	.1372	.12	.1372	.1417	.1372
9		.1543	.1543	.1372	.1417	.1715	.1715
10	.3086	.3189	.3086		.3544	.2058	.3429
11	.5658	.5258	.5316	.1886	.5316	.2743	.5316
12	.6001	.5609	.5316	.1886	.6036	.3086	.5658
13	.6173	.567	.463	.1715	.5493	.2915	.583
14	.6173	.567	.5316	.1886	.4961	.3086	.5658
15	.6344	.5609	.5316	.2058	.5434	.2915	.583
16	.6001	.591	.5658	.1543	.4961	.2743	.6173
17	.583	.567	.5316	.1543	.5083	.2743	.5658
18	.5658	.5258	.5316	.1543	.5316	.2915	.5658
19	.6173	.5434	.4801	.2058	.5731	.2915	.5658
20	.3772	.3681	.3258	.2229	.443	.2743	.3944
21	.3086	.2658	.2401	.2229	.2804	.2401	.3086
22	.2572	.2454	.2229	.2058	.2303	.2401	.2572
23	.2401	.2353	.2058	.2058	.2303	.2401	.2743
24	.2229	.2058	.2149	.1886	.1886	.2103	.2058
Max	.6344	.591	.5658	.2229	.6036	.3086	.6173
Min	.1543	.1372	.1372	.12	.1372	.1417	.1372
Avg	.3757	.3392	.3241	.1774	.3314	.2334	.3494

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 284060 / 33/11KV Vashi, Sector- 19D

S/S

Feeder No / Name : 203 / 11 KV 'C' WING MASALA

SHEDDABLE URBAN

MARKET Feeder KV- 11 /
OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.463	.6379	.6001	.463	.4784	.6173
2	.5487	.4115	.6201	.4287	.4287	.4656	.5658
3	.4801	.3772	.6089	.4287	.4115	.4477	.5316
4	.463	.4801	.5847	.4115	.4287	.4298	.4801
5	.4458	.5316	.567	.3944	.4973	.4298	.463
6	.4458	.6344	.5847	.3944	.5487	.4607	.4287
7	.463	.583	.6024	.4115	.4115	.4252	.583
8	.6859	.4973	.4961	.5487	.6001	.5959	.6344
9	.8573	.7888	.7716		.7973	.5487	.8059
10	.9774	1.0099	.8573	.583	1.0985	.7202	.9774
11	1.406	1.4022	1.2003	.4458	1.3969	.7888	1.286
12	1.5775	1.5074	1.3889	.6516	1.5061	.8402	1.5432
13	1.5947	1.6278	1.4232	.6516	1.4883	.823	1.6118
14	1.5775	1.2934	1.3889	.583	1.4899	.823	1.406
15	1.5775	1.4352	1.406	.583	1.5061	.8573	1.6289
16	1.5604	1.5592	1.3203	.6001	1.4352	.8402	1.5089
17	1.5432	1.4198	1.286	.6001	1.2048	.8059	1.5775
18	1.4746	1.1744	1.2346	.4115	1.134	.823	1.4232
19	1.3203	1.2445	1.2346	.7202	.9991	.8573	1.3889
20	1.046	1.0277	.9774	.703	1.1218	.823	1.166
21	.8402	.815	.823	.703	.7442	.7202	.7545
22	.7373	.7343	.7373	.703	.7265	.7373	.8402
23	.6001	.7421	.6859	.6687	.7059	.703	.7888
24	.6687	.6344	.6447	.6859	.4973	.4784	.6173
Max	1.5947	1.6278	1.4232	.7202	1.5061	.8573	1.6289
Min	.4458	.3772	.4961	.3944	.4115	.4252	.4287
Avg	.9795	.9331	.9201	.5614	.9017	.6634	.9845

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 284060 / 33/11KV Vashi, Sector- 19D

S/S

Feeder No / Name : 207 / 11 KV UTI SUB STATION

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6118	1.4575	1.3466	1.286	1.3717	1.3112	1.2689
2	1.5432	1.3717	1.3289	1.2003	1.3203	1.3073	1.2003
3	1.4746	1.3032	1.3112	1.2003	1.2689	1.2536	1.166
4	1.166	1.2689	1.2757	1.1488	1.286	1.2048	1.1145
5	1.4403	1.3717	1.3466	1.1317	1.3375	1.2536	1.0974
6	1.5604	1.4575	1.4175	1.1831	1.4575	1.3073	1.0631
7	1.8176	1.8861	1.5061	1.2689	1.6632	1.4327	1.7318
8	1.7318	1.7147	1.7193	1.4918	1.6289	1.7364	1.6975
9		1.6975	1.749	1.7147	1.9163	1.5775	1.6975
10	1.7147	1.6655	1.7147	1.749	1.7177	1.6632	1.6804
11	1.6461	1.5074	1.4918	1.6632	1.6476	1.5432	1.5432
12	1.4232	1.3672	1.3375	1.5261	1.3611	1.3203	1.3717
13	1.406	1.382	1.3203	1.4575	1.3146	1.1831	1.406
14	1.3889	1.3112	1.2003	1.3375	1.2094	1.166	1.2689
15	1.3717	1.2536	1.2174	1.166	1.2357	1.1145	1.2689
16	1.3889	1.2269	1.166	1.1145	1.2934	1.0631	1.3375
17	1.4232	1.4175	1.286	1.2689	1.382	1.2346	1.3375
18	1.3717	1.4373	1.4746		1.5424	1.4232	1.3717
19	1.8347	1.5947	1.5604	1.7147	1.6651	1.5261	1.6118
20	1.749	1.5775	1.6461	1.7318	1.5775	1.5089	1.8004
21	1.749	1.595	1.5261	1.6118	1.56	1.4746	1.6118
22	1.7147	1.6124	1.4403	1.5261	1.5238	1.4746	1.8861
23	1.7833	1.6834	1.4403	1.5604	1.382	1.4232	1.6289
24	1.6804	1.4918	1.3756	1.3889	1.4575	1.3253	1.286
Max	1.8347	1.8861	1.749	1.749	1.9163	1.7364	1.8861
Min	1.166	1.2269	1.166	1.1145	1.2094	1.0631	1.0631
Avg	1.5648	1.4855	1.4249	1.4105	1.4633	1.3678	1.4353

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 284060 / 33/11KV Vashi, Sector- 19D

S/S

Feeder No / Name : 208 / 11 KV SUNVILL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.703	.7087	.6687	.6173	.6556	.6344
2	.7202	.6344	.7164	.6001	.5658	.6379	.6001
3	.6859	.583	.6805	.583	.5316	.6024	.583
4	.6344	.5316	.6379	.5487	.5487	.567	.5658
5	.6173	.6173	.6733	.5144		.6024	.5144
6	.7545	.703	.7442	.5658	.7202	.6805	.7888
7	.8916	.9602	.8059	.6687	.8402	.7619	.8916
8	.8745	.8916	.7011	.6001	.823	.7265	.823
9		.8573	.8059	.6859	1.0277	.8745	.9259
10	.9259	1.0341	.8745	.7888	.9114	.7373	.7888
11	.9602	1.0341	.8745	.823	.8417	.7716	.8916
12	.8573	.9114	.7716	.8059	.7796	.6516	.7888
13	.7888	.8328	.7545	.7888	.7619	.6687	.7716
14	.7716	.7796	.6344	.6859	.7011	.6173	.7545
15	.703	.7442	.6516	.6001	.7362	.583	.6859
16	.7202	.7011	.6173	.6687	.691	.583	.6687
17	.7373	.7362	.6859	.7373	.7011	.6859	.7373
18	.7888	.7888	.7716	.7545	.7712	.7545	.7545
19	.8916	.9036	.8573	.8916	.8682	.8745	.8916
20	.9088	.8859	.8916	.8402	.8413	.8745	.8916
21	.8745	.9036	.8402	.8059	.7796	.8059	.8916
22	.8573	.788	.7545	.7545	.7619	.7545	.8573
23	.8059	.7783	.7716	.6859	.6984	.703	.7716
24	.7888	.7545	.7343	.7716	.6687	.6626	.6687
Max	.9602	1.0341	.8916	.8916	1.0277	.8745	.9259
Min	.6173	.5316	.6173	.5144	.5316	.567	.5144
Avg	.7962	.7941	.7483	.7016	.7473	.7015	.7559