

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094003 / 33/11 KV NER

Feeder No / Name : 201 / 11 KV LONKHEDI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	1.1145	1.1145	.083			
2	1.2003	1.1145	1.1145	.0792			
3	1.3717	1.3717	1.3717	.0849			
4	1.5432	1.5432	1.5432	.1132			
5	1.7147	1.7147	1.7147	.1339			
6	1.8004	1.8861	1.9719	.232			
7	2.4863	2.4863	.6859	2.2291	2.4006	2.0576	.3429
8	2.2291	2.4863	2.2291	2.3148	2.4006	2.3148	.4287
9	2.0576	2.4006	2.2291	2.1434	2.2291	2.0576	.3429
23				.083			
Max	2.4863	2.4863	2.2291	2.3148	2.4006	2.3148	.4287
Min	1.0288	1.1145	.6859	.0792	2.2291	2.0576	.3429
Avg	1.7147	1.7909	1.5527	.7497	2.3434	2.1433	.3715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213] BU 0574

Substation No/ Name :- 094003 / 33/11 KV NER

Feeder No / Name : 202 / 11 KV SHIRDHANE AG 1

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7			1.7147			
11		1.286	1.286	1.3717	1.1145	.6859
12	2.572	2.2291	1.8861	1.5432	1.9719	1.7147
13	2.572	2.2291	1.7147	1.5432	1.8861	1.7147
14	2.3148	1.8004	1.4575	1.5432	1.7147	1.5432
15		1.5432	1.3717	1.286	1.5432	1.5432
16	2.2291	1.5432	1.2003	1.286		1.2003
17	1.8004	1.5432	1.1145	1.286		1.1145
18	1.5432	1.2003	1.0288	1.1145	.6001	1.1145
Max	2.572	2.2291	1.8861	1.5432	1.9719	1.7147
Min	1.5432	1.2003	1.0288	1.1145	.6001	.6859
Avg	2.1719	1.6718	1.4194	1.3717	1.4718	1.3289

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094003 / 33/11 KV NER

Feeder No / Name : 203 / 11 KV DEUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.4287	.4287				
2	.7716	.4287	.4287				
3	1.0288	.6001	.6001				
4	1.1831	.7716	.7716				
5	1.286	.8573	.9431				
6	1.3717	1.0288	1.2003				
7	1.5432	1.6289	1.3717	1.3717	1.286	1.2003	.3429
8	1.3717	1.4575	1.3717	1.3717	1.3717	1.2003	.3429
9	1.3717	1.3717	1.2003	1.3717	1.0288	1.0288	.3429
10	.1715		.1715	.1715	.1715	.1715	.1715
11	.1715		.1715	.1715	.1715	.1715	.1715
12	.1715		.1715	.1715	.1715	.1715	.1715
13	.1715		.1715	.1715	.1715	.1715	
14	.1715		.1715	.1715	.1715	.1715	.1715
15	.1715		.1715	.1715	.1715	.1715	.1715
16	.1715		.1715	.1715	.1715		.1715
17	.1715		.1715	.1715	.1715		.1715
18	.1715		.1715	.1715	.1715	.1715	.1715
19	.1715		.1715	.1715	.1715	.1715	.1715
20	.1715						
21	.1715						
22	.1715						
23	.1715						
24	.4287						
Max	1.5432	1.6289	1.3717	1.3717	1.3717	1.2003	.3429
Min	.1715	.4287	.1715	.1715	.1715	.1715	.1715
Avg	.5566	.9526	.5280	.4485	.4155	.4365	.2144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213] BU 0574

Substation No/ Name :- 094003 / 33/11 KV NER

Feeder No / Name : 204 / 11 KV NER AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11	.6859	.6859	.5144	.5144	.8573	.2572
12	.9431	.9431	1.0288	.9431	.8573	.1524
13	.8573	.9431	.9431	.8573	.8573	.6859
14	.6859	.7716	.8573	.7716	.8573	.6859
15	.6859	.6859	.8573	.7716	.7716	.5144
16	.7716	.6859	.8573	.7716		.5144
17	.7716	.6859	.6859	.6859		.5144
18	.7716	.6859	.5144	.6859	.4287	.5144
Max	.9431	.9431	1.0288	.9431	.8573	.6859
Min	.6859	.6859	.5144	.5144	.4287	.1524
Avg	.7716	.7609	.7823	.7502	.7716	.4799

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094003 / 33/11 KV NER

Feeder No / Name : 205 / 11 KV NER-GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0953	.0953				
2	.0762	.0953	.0953				
3	.0953	.0953	.0953				
4	.1143	.1143	.1143				
5	.1524	.1334	.1334				
6	.1905	.1791	.1715				
7	.1334	.1524	.1524	.141	.1334	.1562	.1334
8	.1257	.1334	.1334	.1334	.1143	.141	.1143
9	.1143	.1219	.1219	.1143	.1143	.1181	.0953
10	.1143		.1257	.1143	.1143	.1219	.1143
11	.0953		.1143	.1143	.1219	.1143	.1143
12	.08		.0953	.0953	.0876	.1143	
13	.1029		.1143	.1143	.1105	.1143	.1143
14			.1143	.1143	.1105	.1143	.1143
15	.1143		.1143	.5144	.1143	.1143	.1143
16	.1143		.1143	.1143	.1143		.1143
17	.1143		.1143	.1334	.1181		.0953
18	.1143		.1143	.1143	.1181	.1143	.1334
19	.1296		.1334	.1334	.141	.1143	.1143
20	.1334						
21	.1334						
22	.1219						
23	.1143						
24	.1334						
Max	.1905	.1791	.1715	.5144	.141	.1562	.1334
Min	.0762	.0953	.0953	.0953	.0876	.1143	.0953
Avg	.1171	.1245	.1193	.1501	.1164	.1216	.1143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213] BU 0574

Substation No/ Name :- 094003 / 33/11 KV NER

Feeder No / Name : 207 / 11 KV SHIRDHANE GAOTHAON
FSS Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		.1143	.1524	.1143	.1715	.1334
8		.0953	.1143	.0762	.1334	.1143
9		.0572	.0762	.0762	.0953	.0762
10		.0572	.0762		.0953	.0572
11		.0572	.0572	.0762	.0762	.0572
12	.0762	.0572	.0572	.0762	.0572	.0572
13	.0762	.0572	.0572	.0762	.0572	.1105
14	.0762	.0572	.0572	.0762	.0572	.0762
15	.0762	.0572	.0572	.0762	.0572	.0762
16	.0762	.0572	.0572	.0762		.0762
17	.0762	.0572	.0572	.0762		.0762
18	.0762	.0762	.0572	.0953	.0762	.0953
19	.1143	.0953	.0953	.1143	.0953	.0762
20	.1143					
21	.1334					
22	.0953					
23	.0762					
24	.0762					
Max	.1334	.1143	.1524	.1143	.1715	.1334
Min	.0762	.0572	.0572	.0762	.0572	.0572
Avg	.0879	.0689	.0748	.0841	.0884	.0833

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094003 / 33/11 KV NER

Feeder No / Name : 208 / 11 KV DEUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0762	.0762				
2	.0572	.0762	.0762				
3	.0762	.0762	.0762				
4	.0762	.0953	.0953				
5	.0953	.1143	.1143				
6	.1143	.1334	.1334				
7	.1143	.1143	.1906	.0953	.1143	.0991	.0953
8	.0953	.0914	.1524	.0762	.0762	.0838	.0953
9	.0762	.0838	.0762	.0762	.0762	.0724	.0762
10	.0762		.0762	.0762	.0762	.0762	.0762
11	.0762		.0762	.0762	.0762	.0762	.0762
12	.0762		.0762	.0762	.0762	.0686	.0762
13	.0762		.0762	.0762	.0762	.0686	.0762
14			.0572	.0762	.0762	.0686	.0762
15			.0572	.0762	.0762	.0762	.0572
16	.0991		.0572	.0762	.0762		.0953
17	.0991		.0572	.0762	.08		.0953
18	.0991		.0762	.0762	.0876	.0762	.1143
19	.1029		.0953	.1143	.0876	.0953	.0762
20	.1143						
21	.0953						
22	.0876						
23	.0762						
24	.0762						
Max	.1143	.1334	.1906	.1143	.1143	.0991	.1143
Min	.0572	.0762	.0572	.0762	.0762	.0686	.0572
Avg	.0871	.0957	.0893	.0806	.0812	.0783	.0835

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094003 / 33/11 KV NER

Feeder No / Name : 209 / 11 KV SHIRDHANE AG-2

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857	.0857				
2	.0857	.0857	.0857				
3	.0857	.0857	.0857				
4	.0857	.0857	.0857				
5	.0857	.0857	.0857				
6	.0857	.0857	.0857				
7	.0857	.0857	.0857	.0857	.0857	.0857	
8	.0857	.0857	.0857	.0857	.0857	.0857	
9	.0857	.0857	.0857	.0857	.0857	.0857	
10	.0857		.9431	.0857		.0857	
11	.9431		.9431	.6859	.6001	.5144	.3429
12	1.3717		.8573	1.1145	.9431	.6859	.6859
13	1.3717		1.5432	1.0288	1.2003	1.1145	.8573
14	.8573		1.1145	.8573	1.0974	1.2003	.8573
15	1.1145		1.1145	1.0288	1.0288	1.1145	.6859
16	1.0288		1.0288	.8573	.9088		.6859
17	.8573		.9431	.8573	.7888		
18	.6859			.6859			.6859
20	.0857						
21	.0857						
22	.0857						
23	.0857						
24	.0857						
Max	1.3717	.0857	1.5432	1.1145	1.2003	1.2003	.8573
Min	.0857	.0857	.0857	.0857	.0857	.0857	.3429
Avg	.4137	.0857	.5446	.6216	.6824	.5525	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094008 / 33/11 KV JUNWANE

Feeder No / Name : 201 / 11 KV BORKUND AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0857	.1341	.2241
2					.0857		.1966
3					.1143		.2561
4					.1143		.3052
5					.1429		.3391
6					.2		.3932
7					.2715	.0335	.3932
8					.1858	.3521	.3932
9				.0339	.1429	.3856	
10			.2458			.4024	
11	.4239	.3353	.253	.0848		.2347	.1638
12	.7122	.6371	.25	.1017			.1802
13	.6443	.5868					
14	.6104	.5365		.1696			
15	.6104	.4359		.2035			
16		.415					
17	.4748	.4024					
18	.5087	.4024	.2214				
24					.0857	.1341	.1966
Max	.7122	.6371	.253	.2035	.2715	.4024	.3932
Min	.4239	.3353	.2214	.0339	.0857	.0335	.1638
Avg	.5692	.4689	.2426	.1187	.1429	.2395	.2765

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094008 / 33/11 KV JUNWANE

Feeder No / Name : 202 / 11 KV SHIRUD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2204	.2012	.1898				
2	.2035	.218	.2263				
3	.2035	.218	.2641				
4	.3052	.3018	.3086				
5	.6613	.6706	.4915				
6	1.0513	1.0059	.9831				
7	.9156	1.0395	1.0852				
8	.6274	.8383	.6009				
9	.4239	.6371	.4428				
11				.6783	.4858	.2347	.1966
12				.9156	.4858	.503	.25
13				.78	.4287	.503	.3277
14				.5426	.4858	.503	.3125
15				.4748	.5144		.3163
16				.4748	.5144		.3163
17				.4409	.4572		.3163
18				.3391	.3429	.4024	.3277
19						.3353	
24	.2204	.1677	.1966				
Max	1.0513	1.0395	1.0852	.9156	.5144	.503	.3277
Min	.2035	.1677	.1898	.3391	.3429	.2347	.1966
Avg	.4833	.5298	.4789	.5808	.4644	.4136	.2954

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094008 / 33/11 KV JUNWANE

Feeder No / Name : 203 / 11 KV I.O.C.

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1509	.1494	.0373	.1097	.0377	.128
2	.1494	.1509	.1463	.0373	.1097	.0754	.1307
3	.1494	.1509	.1357	.0373	.1097	.0943	.128
4	.1494	.1132	.132	.0747	.1097	.1132	.1097
5	.1494	.1132	.1307	.0747	.0914	.1132	.112
6	.0934	.1132	.112	.0747	.0714	.0943	.1097
7	.112	.1132	.0983	.056	.0914	.0377	.112
8	.112	.1132	.1132	.0373	.0914	.0943	.0732
9	.1307	.1132	.0754	.0373	.128	.0943	.0377
10	.1307	.1886	.1494	.0934	.128	.0943	.0366
11	.1307	.1886	.132	.3734	.2195	.1132	.1097
12	.1494	.1509	.132	.1867	.1829	.1132	.1646
13	.1494	.1509	.1307	.1867	.1646	.1132	.1494
14	.168	.1509	.1307	.1307	.1463	.1132	.1097
15	.168	.1509	.112	.0373	.1646		.112
16	.0747	.1509	.112	.112	.1097		.1463
17	.112	.1509	.1132	.1867	.0914		.1463
18	.112	.1509	.112	.1307	.0914	.0377	.112
19	.112	.1132	.112	.112	.0914	.0377	.1132
20	.1494	.1132	.1086	.112	.128	.0686	
21	.1494	.1132	.112	.0934	.112	.1132	
22	.1494	.1132	.0747	.1307	.112	.1132	.1097
23	.1494	.1372	.0754	.112	.112	.1132	.112
24	.1494	.1509	.1494	.0747	.1097	.0377	.128
Max	.168	.1886	.1494	.3734	.2195	.1132	.1646
Min	.0747	.1132	.0747	.0373	.0714	.0377	.0366
Avg	.1354	.1378	.1187	.1058	.1198	.0868	.1132

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094008 / 33/11 KV JUNWANE

Feeder No / Name : 204 / 11 KV NIMGUL AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0339	.0335	.0328				
2	.0339	.0335	.0324				
3	.0339	.0335	.0316				
4	.0339	.0474	.0492				
5	.0509	.0671	.0633				
6	.0848	.0671	.0791				
7	.1017	.0671	.0819				
8	.0848	.1006	.0819				
9	.0509	.0671	.0655				
11				.0848	.0572	.0503	.0949
12				.0848	.0429	.0671	.1017
13				.0678	.0286	.0674	.0655
14				.0509	.0429	.0671	.0655
15				.0509	.0429		.0678
16				.0678	.0429		.0655
17				.0934	.0714		.0633
18				.0509	.0429	.0503	.0655
19						.0503	
24	.0339	.0335	.0328				
Max	.1017	.1006	.0819	.0934	.0714	.0674	.1017
Min	.0339	.0335	.0316	.0509	.0286	.0503	.0633
Avg	.0543	.0550	.0551	.0689	.0465	.0588	.0737

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094008 / 33/11 KV JUNWANE

Feeder No / Name : 205 / 11 KV BORKUND GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.5658	.5487	.5601	.5601	.5658	.6036
2	.5601	.5658	.5487	.5601	.5601	.5658	.5853
3	.5601	.5658	.5975	.5601	.5601	.5658	.6722
4	.6535	.679	.695	.5601	.6722	.6036	.6584
5	.8215	.8488	.7842	.7095	.8215	.8573	.9145
6	1.0642	1.1317	1.1203	.8589	1.2323	1.0185	1.1317
7	.8775	.9808	1.0082	1.0082	.9335	.9054	.8779
8	.8402	.8676	.8589	.8215	.7468	.7356	.7682
9	.6722	.7922	.7922	.5975	.7468	.6602	.7167
10	.5975	.7167	.5228	.5601	.6584	.6413	.6584
11	.5601	.679	.5487	.5228	.5601	.5658	.5487
12	.5601	.5658	.5658	.5228	.5601	.5658	.4755
13	.5975		.5601	.5601	.5487	.5658	.439
14	.5975		.5601	.5601		.5658	.4481
15	.5975	.6036	.4481	.5601	.5487		.4481
16	.5975	.679	.5121	.5975	.5487		.4481
17	.6348	.679	.5601	.6348	.6401		.4096
18	.6722	.679	.6348	.6348	.7499	.6036	.4854
19	.8589	.9054	.9709	.8589	.5716	.7167	
20	1.0082	.9808	.9431	1.0456	1.0059	.9431	
21	.8215	.9054	.7545	.7468	.7682	1.0185	
22	.6722	.7545	.5975	.6908	.7095	.9431	
23	.5975	.7167	.5601	.5975	.6348	.7167	
24	.5601	.5658	.5853	.5601	.5487	.6036	.6348
Max	1.0642	1.1317	1.1203	1.0456	1.2323	1.0185	1.1317
Min	.5601	.5658	.4481	.5228	.5487	.5658	.4096
Avg	.6893	.7467	.6782	.6620	.6907	.7108	.6276

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094008 / 33/11 KV JUNWANE

Feeder No / Name : 208 / 11 KV VINCHUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0678	.0674	.0633				
2	.0678	.0671	.0633				
3	.0678	.1006	.0983				
4	.0848	.1341	.0949				
5	.1357	.1677	.125				
6	.2374	.2012	.125				
7	.3052	.2683	.1219				
8	.2035	.218	.1219				
9	.1357	.1677	.0791				
11				.1526	.1286	.1006	.0914
12				.1696	.1429	.1341	.125
13				.1357	.1429	.1341	.1265
14				.0678	.1429	.1006	.1265
15					.1286		.125
16				.2035	.1286		.1265
17				.2713	.1		.1265
18				.2713	.1	.1006	.1265
19						.0671	
24	.0339	.0671	.0633				
Max	.3052	.2683	.125	.2713	.1429	.1341	.1265
Min	.0339	.0671	.0633	.0678	.1	.0671	.0914
Avg	.1340	.1459	.0956	.1817	.1268	.1062	.1217

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094008 / 33/11 KV JUNWANE

Feeder No / Name : 209 / 11 KV RATANPURA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1526	.1429	.2347	.1581
2				.1526	.1429	.2347	.1966
3				.1696	.1715	.2515	.2622
4				.2035	.2	.2515	.2949
5				.2374	.2572	.2707	.3437
6				.2713	.2858	.3018	.4588
7				.4578	.3715	.3856	.3932
8				.373	.3429	.3856	.3795
9				.3391	.3144	.3521	.3932
10			.3391				
11	.4748	.3353	.3277				
12	.3052	.6371	.3605				
13	.407	.5868	.373				
14	.373	.503					
15	.39	.4359					
16	.407	.3688					
17	.407		.3163				
18	.39	.4024	.3277				
24				.1526	.1715	.2683	.1638
Max	.4748	.6371	.373	.4578	.3715	.3856	.4588
Min	.3052	.3353	.3163	.1526	.1429	.2347	.1581
Avg	.3943	.4670	.3407	.2510	.2401	.2937	.3044

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094022 / 33/11 KV KUSUMBA

Feeder No / Name : 201 / 11 KV AKALAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.6516	.6001	.3429	.3429	.3429
2	.6516	.6516	.7716	.3258	.3429	.3429
3	.7716	.6859	.7716	.3429	.3429	.3601
4	.8916	.7716	1.0288	.3429	.3772	.3772
5	.9431	.8916	1.2346	.3429	.4458	.4115
6	1.0288	1.1831	1.286		.4458	.4801
7	1.0288	1.2517	1.3375	.3944	.3429	.3772
8	1.3032	1.286	1.3717	.3601	.3086	.2743
9		1.1831		.2229	.3086	.2572
10	.2229	.2572		.2229	.2743	.2743
11	.2401	.1715	.0686	1.2003	1.1488	
12	.2401	.0343	.0857	1.6118	1.5261	1.3375
13	.2572	.2229	.0572	1.406	1.406	1.3375
14	.2572	.2743	.0514	1.2003	1.3375	
15	.2915	.3258	.0343	1.2346	1.1831	
16	.2915	.3258	.0514	1.2003		
17	.2743	.2572	.3086	1.2003		
18	.2743	.2401	.3258	.9945	1.3203	
19	.2572	.3429	.3258	.3429	.3601	
20	.4458	.3944	.4458		.4801	
21	.4287	.4287	.463	.4458	.463	.4287
22	.3944	.3772	.4115		.4287	.3944
23	.3601	.3429		.3429	.3601	.4287
24	.6173	.583	.6001	.3429	.3429	.3429
Max	1.3032	1.286	1.3717	1.6118	1.5261	1.3375
Min	.2229	.0343	.0343	.2229	.2743	.2572
Avg	.5256	.5473	.5539	.6867	.6313	.4855

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213] BU 0574

Substation No/ Name :- 094022 / 33/11 KV KUSUMBA

Feeder No / Name : 202 / 11 KV KUSUMBA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.823	.8573	.3201	.3429	.3258
2	.8573	.823	.823	.3048	.3429	.3258
3	.8745	.823	.7888	.3048	.3429	.3258
4	.8916	.8402	.8573	.3048	.3429	.3429
5	.8573	.8573	.8573	.3201	.3772	.3772
6	.7716	.8745	.7716	.3658	.3772	.3944
7	.7716	.7202	.703	.3353	.3429	.3086
8	.7373	.7373	.6859	.3353	.3086	.2915
9	.6344	.6173		.2896	.3429	.2915
10	.703	.6001		.6344	.6859	.6859
11	.4458	.3086	.3506	.7545	.8573	
12	.4287	.3601	.3201	.7716	.7373	
13	.3601	.3601	.3353	.7202	.7545	
14	.3601	.3944	.3506	.7545	.7545	
15	.4458	.3944	.3506	.7373	.7716	
16	.3772	.3944	.3506	.7373	.7545	
17	.3601	.3429	.3506	.7373	.7373	
18	.3601	.3429	.3201	.7373	.6859	
19	.7716	.7716	.703	.8059	.8059	
20		.8916	.8402		.9259	
21	.9602	.8916	.8573	.9431	.9431	
22	.9259	.8573	.8745		.9259	
23	.9088	.8573	.8745	.8573	.9088	
24	.8573	.8402	.8573	.3201	.3429	.3258
Max	.9602	.8916	.8745	.9431	.9431	.6859
Min	.3601	.3086	.3201	.2896	.3086	.2915
Avg	.6747	.6551	.6400	.5632	.6130	.3632

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094022 / 33/11 KV KUSUMBA

Feeder No / Name : 203 / 11 KV EXP WATER SUPPLY
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0343	.0514	.0686	.0857	.0514
2	.0514	.0171	.0514	.0686	.0857	.0514
3	.0514	.0343	.0343	.0686	.0857	.0514
4	.0514	.0343	.0514	.0686	.0857	.0343
5	.0514	.0343		.0686	.0857	.0514
6	.0514	.0343	.0514	.0686	.12	.0686
7	.0514	.0514	.0514	.0686	.1029	.0686
8	.0514	.0514	.0514	.0686	.12	.0686
9	.0514	.0343		.0686	.0514	.0514
10	.0514	.0343		.0686	.0343	.0514
11	.0686	.0343	.0857	.1372	.0343	
12	.0514	.0343	.0514	.1372	.0343	
13	.0514	.0343	.0514	.1029	.0343	
14	.0343	.0343	.0514	.0857	.0343	
15	.0343	.0343	.0343	.0857	.0343	
16	.0343	.0514	.0686	.0857	.0343	
17	.0343	.0343	.0686	.1029	.0686	
18	.0343	.0514	.0686	.0857	.0514	
19	.0343	.0514	.0686	.0857	.0514	
20	.0343	.0514	.0686		.0514	
21	.0343	.0514	.0686	.0857	.0514	
22	.0343	.0514	.0686		.0514	
23	.0343	.0514	.0686	.0857	.0514	
24	.0514	.0343	.0514	.0686	.0857	.0514
Max	.0686	.0514	.0857	.1372	.12	.0686
Min	.0343	.0171	.0343	.0686	.0343	.0343
Avg	.0450	.0400	.0580	.0834	.0636	.0545

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094022 / 33/11 KV KUSUMBA

Feeder No / Name : 204 / 11 KV SUNLINE EXPRESS 1
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.5658	.5487	.6668	.583	.583
2	.583	.5487	.5144	.6478	.583	.583
3	.5487	.5658	.5144	.6478	.583	.6001
4	.5658	.5658	.5487	.6287	.6173	.6173
5	.5144	.583	.583	.6287	.6173	.6516
6	.5144	.583	.5487	.6478	.6344	.6687
7	.5487	.583	.6001	.6668	.6344	.6516
8	.6687	.583	.6001	.6668	.6516	.6859
9	.6173	.4801		.6478	.583	.6344
10	.6001	.4801		.6478	.6173	.583
11	.6516	.5144	.6859	.6001	.583	
12	.6859	.5658	.7049	.6001	.6173	
13	.6344		.7049	.6001	.5658	
14	.6173	.5658	.6668	.6001	.5658	
15	.6687	.5658	.5906	.6001	.6173	
16	.6344	.5487	.6668	.6001	.6001	
17	.6001	.5487	.724	.6173	.5487	
18	.3429	.6001	.6668	.6173	.6001	
19	.5658	.5487	.6478	.583	1.0117	
20	.5487	.5144	.6478		.5487	
21	.583	.5144	.6287	.5487	.5487	
22	.583	.5316	.6478		.5316	
23	.6001	.5144	.6668	.583	.583	
24	.5316	.5658	.5487	.6668	.583	.583
Max	.6859	.6001	.724	.6668	1.0117	.6859
Min	.3429	.4801	.5144	.5487	.5316	.583
Avg	.5816	.5494	.6207	.6233	.6087	.6220

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094022 / 33/11 KV KUSUMBA

Feeder No / Name : 205 / 11 KV GOTANE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.6001	.583	.2229	.2572	.2401
2	.4287	.6001	.7716	.2229	.2572	.2401
3	.5144	.6516	.8573	.2401	.2572	.2401
4	.6173		.9431	.2572	.3086	.2572
5	.6859	.8916	1.166	.2915	.3429	.3258
6	.7716	1.2003	1.3546	.3944	.3429	.3944
7	.8573	1.4232	1.4575	.2915	.2915	.3086
8	1.286	1.3375	1.3203	.2401	.2572	.2229
9	.9945			.1715	.2058	.1715
10	.1886	.1715		.1543	.1715	.1886
11	.1543	.1715	.1715	1.0288	1.1145	
12	.1543	.1715	.1886	1.4918	1.5947	
13	.1543	.1886	.1715	1.3717	1.4918	
14	.1543	.1715	.1715	1.2003	1.406	
15	.1715	.1715	.1886	1.2003	1.2689	
16	.1543	.1715	.2229	1.1831	1.2003	
17	.1543	.1715	.1886	1.1488	1.2174	
18	.2058	.1886	.1715	1.0974	1.0288	
19	.2572	.3086	.2229	.2401	.2743	
20	.3429	.3086	.3258		.2743	
21	.3086	.3258	.3086	.3086	.2743	
22	.2401	.3086	.2743		.2572	
23	.2229	.3086	.2401	.2572	.2401	
24	.3429	.4115	.5487	.2229	.2572	.2401
Max	1.286	1.4232	1.4575	1.4918	1.5947	.3944
Min	.1543	.1715	.1715	.1543	.1715	.1715
Avg	.4079	.4661	.5386	.6017	.6080	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094022 / 33/11 KV KUSUMBA

Feeder No / Name : 206 / 11 KV KAWATHI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.703	.6859	.3353	.3772	.3944
2	.7888	.703	.7202	.3506	.3772	.3944
3	.7716	.703	.7716	.3506		.4115
4	.6859	.7202	.7716	.3506		.5144
5	.7716	.7716	.8573	.3658	.6859	.6859
6	.6859	.7888	.7716	.6401	1.2003	.9431
7	.6173	.703	.7545	1.0517	1.3717	1.3546
8		.4458	.6687	1.0364	1.406	1.4918
9	.6173	.6001		.9145	1.2689	1.0802
10	.5487	.5658		.5487	.583	.5316
11	.8916	.9431	.7926	.4801	.5316	
12	1.4575	1.1145	1.2346	.5144	.5316	
13	1.3717	1.406	1.0669	.5144	.583	
14	1.3032	1.0288	.9907	.5487	.583	
15	1.0288	.8745	.7621	.5487	.6001	
16	1.0117	1.0288	.8688	.583	.6344	
17	.8745	.8573	.8078	.6344	.5316	
18	.8402	.6859	.6706	.6173	.5487	
19	.7888	.7716	.6687	.7716	.7545	
20	.9431	.8745	.823		.9431	
21	.8916	.8573	.8573	.8573	.9088	
22	.8059	.8573	.823		.8573	
23	.7373	.7716	.7716		.7545	
24	.7716	.703	.6859	.3353	.3772	.3772
Max	1.4575	1.406	1.2346	1.0517	1.406	1.4918
Min	.5487	.4458	.6687	.3353	.3772	.3772
Avg	.8685	.8116	.8102	.5881	.7459	.7436

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094022 / 33/11 KV KUSUMBA

Feeder No / Name : 207 / 11 KV SUNLINE EXPRESS 2
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9945	1.0288	.9602	1.105	.9602	1.0117
2	1.0288	1.0288	.9431	1.105	.9602	1.0117
3	1.0288	1.046	.9431	1.1241	.9602	1.0288
4	1.0288	1.0631	.9431	1.1241	1.0288	1.0288
5	1.046	1.0802	.9259	1.1241	1.1317	1.046
6	1.0288	1.0802	.9431	1.1431	1.0974	1.046
7	1.046	1.046	.9088	1.1812	1.0974	1.0802
8	1.046	1.0631	1.0802	1.1812	1.0631	1.046
9	1.046	.9774		1.1622	.9945	1.046
10	.9945	.9602		1.1431	1.0288	1.046
11	1.0974	1.0288	1.105	1.0631	1.0974	
12	1.0974	1.046	1.1812	1.0631	1.1317	
13	1.0802	1.046	1.1812	1.0631	1.1145	
14	1.0631	1.0288	1.1622	1.0631	1.1145	
15	1.046		1.1241	1.0631	1.0974	
16	1.0117	1.0288	1.1622	1.0631	1.0631	
17	1.0117	1.0288	1.1431	1.0631	1.0631	
18	.8059	.9945	1.1431	1.0631	1.046	
19	.9602	1.0288	1.086	1.0974	1.0117	
20	.9774	1.0288	1.086		1.0117	
21	.9945	.9945	1.086	1.0288	1.0117	
22	.9945	.9774	1.0669		.9945	
23	1.0117	.9774	1.0479	.9945	1.0288	
24	.9945	1.0288	.9602	1.105	.9602	1.0117
Max	1.0974	1.0802	1.1812	1.1812	1.1317	1.0802
Min	.8059	.9602	.9088	.9945	.9602	1.0117
Avg	1.0181	1.0266	1.0538	1.0965	1.0445	1.0366

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094025 / 33/11 KV ARVI

Feeder No / Name : 201 / 11 KV ARVI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6756	.6401	.5487	1.0374	.9602	1.1145	1.1145
2	.6944	.6219	.5335	1.0059	.9088	1.0974	1.1488
3	.7319	.6219	.5182	1.0242	1.0802	1.0631	1.1145
4	.8445	.6219	.5487	1.0242	1.1145	1.166	1.406
5	.9008	.7865	.6706	1.0974	1.2517	1.2003	1.4918
6	.9571	1.0059	.7926	1.2437	1.5089	1.5432	1.5432
7	1.126	1.0425	.7773	1.0791	1.2517	1.2517	1.2003
8	.8596	1.0751	.8779	.8916	1.0117	1.0631	.8916
9	.7865	.6097	.695	.9259	.9945	.9945	.9431
10	.8596	.8402	.9511	.8745	.9259	.9088	.8573
11	.9145	.8745	.9328	.6706	.7716	.6516	.503
12	.8962		1.0608	.7316	.6859	.7545	.6554
13	.9694	.9259	1.0425	.7164	.703	.7545	.6249
14	1.0242		1.0425	.7468	.7202	.7202	.6401
15	1.0608	.6001	1.0791	.7316	.7373		.6401
16	1.0608	.5144	1.0242	.7011	.7202		.6554
17	.9877	.7716	1.0242	.7011	.7373		.6097
18	.9877		1.0425	.442	.7202	.823	.5944
19	1.1523	.5487	1.1157	.823	1.166	.8059	
20	1.262	1.5261	1.2437	1.5604		.7888	
21	1.39	1.406	1.4266	1.3717	1.4232	1.3375	
22	1.2437	1.3375	1.3535	1.2346		1.286	
23	1.0974	1.0974	1.134	1.0974	1.2346	1.1317	.5658
24	.6568	.6401	.5335	1.0242	.9945	1.1317	1.0974
Max	1.39	1.5261	1.4266	1.5604	1.5089	1.5432	1.5432
Min	.6568	.5144	.5182	.442	.6859	.6516	.503
Avg	.9641	.8623	.9154	.9482	.9828	1.028	.9149

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094025 / 33/11 KV ARVI

Feeder No / Name : 202 / 11 KV EKVIRA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0751	.0366	.0914	.0343	.1029	.0686	.0857
2	.0938	.0568	.0914	.0514	.1029	1.7833	.12
3	.0563	.0549	.0914	.0514	.0857	.0686	.0686
4	.1126	.0732	.0732	.0686	.0343	.0686	.0857
5	.0563	.0549	.0732	.0514	.0686	.0686	.1029
6	.0938	.0914	.0366	.0343	.0343	.0686	.12
7	.0375	.0366	.0914	.0343	.0343	.0514	.0857
8	.128	.0549	.0914	.0686	.0343	.0514	.1029
9	.0549	.0754	.0732	.0343	.0857	.0686	.0686
10	.1097	.0366	.0732	.0857	.0514	.0514	.1029
11	.1097	.0754	.128	.0514	.0514	.0343	.12
12	.0366	.0754	.0366	.0514	.0686	.0686	.0857
13	.0549	.0566	.1463	.0514	.0343	.0686	.1029
14	.0732	.0566	.0914	.0343	.0343	.12	
15	.0549	.0549	.0366	.0686	.0686		.0857
16	.0549	.0566	.0366	.12	.0686		.12
17	.0366	.0566	.128	.0857	.0686		.0343
18	.0366	.0566	.128	.0514	.0857	.0343	.0514
19	.128	.0566	.0366	.0686	.0857	.0857	
20	.0732		.0549	.0857	.0857	.0514	
21	.0549	.0732	.0732	.0514	.0857	.0686	
22	.0566	.0914	.0549	.0686	.0514	.0514	.12
23	.0566	.1132	.0366	.0514	.0857	.0857	.0514
24	.0375	.0377	.0943	.0366	.0343	.0857	.0686
Max	.128	.1132	.1463	.12	.1029	1.7833	.12
Min	.0366	.0366	.0366	.0343	.0343	.0343	.0343
Avg	.0701	.0623	.0779	.0580	.0643	.1478	.0892

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213] BU 0574

Substation No/ Name :- 094025 / 33/11 KV ARVI

Feeder No / Name : 203 / 11 KV HENDRUN SINGLE

SINGLE PHASING

PHASING Feeder KV- 11 /
OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5255	.5487	.5144	.3353	.381	.4458	.463
2	.5067	.5504	.5144	.3353	.4572	.4287	.4973
3	.5442	.567	.5487	.3506	.5792	.4801	.6001
4	.6568	.567	.583	.3506	.6554	.5144	.6516
5	.7882	.695	.6687	.381	.6706	.6381	.823
6	.8257	.8962	.8916	.6249	.6859	.6173	.8573
7	.7694	.8596	.7545		.7164	.6344	.8573
8	.5487	.6767	.6401	.5792	.6687	.4287	.3353
9	.0366	.6173	.5853	.4877	.5658		.5487
10	.0366	.5658	.5853	.583	.583	.6687	.5658
11	.823	.6859	.695	.5144	.5487	.6001	.463
12	.8779	.6401	.7682	.5316		.5658	.5658
13	.7316	.6554	.7499	.5316	.6173	.5658	.5487
14	.7133	.2439	.6219	.5658	.4801	.6001	.583
15	.5853	.3353	.567	.5658	.3772		.6001
16	.6401	.4268	.5487	.6001	.4801		.583
17	.0366	.4572	.6767	.6001	.6001		.5487
18	.7499	.5335	.6584	.5658	.6001	.7716	.5144
19	.823	.6859	.6584	.6516	.7716	.9259	
20	.8962	.8573	.7133	.8745	.8573	.9945	
21	.9997	.823	.8596	.7373	.823	.8916	
22	.823	.6859	.7133	.6516	.7202	.7202	
23	.6036	.5487	.567	.5144	.6001	.6173	
24	.5067	.567	.5316	.4207	.3658		.4458
Max	.9997	.8962	.8916	.8745	.8573	.9945	.8573
Min	.0366	.2439	.5144	.3353	.3658	.4287	.3353
Avg	.6270	.6121	.6506	.5371	.6002	.6373	.5817

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213] BU 0574

Substation No/ Name :- 094025 / 33/11 KV ARVI

Feeder No / Name : 204 / 11 KV SONEWADI SINGLE SINGLE PHASING
 PHASING Feeder KV- 11 /
 OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3378	.3658	.3353	.2572	.2401	.2743	.2743
2	.3566	.3841	.3048	.2743	.3086	.2743	.2915
3	.4129	.3841	.3201	.2572	.3601	.3086	.3086
4	.563	.4207	.3506	.2743	.4115	.3429	.6001
5	.6005	.5853	.5182	.3429	.5144	.4287	.6516
6	.6381	.8596	.7316	.5658	.6516	.6173	.6687
7		.8413	.6859	.4973	.5658	.5487	.5658
8	.4938	.7133	.7682	.3772	.3772	.4115	.4287
9	.695		.695	.3086		.3258	.3601
10	.3475		.3292	.2572	.2229	.2915	.2915
11	.2743		.2561	.5639	.5487	.3601	.5639
12	.2743		.2743	.6554			.5944
13	.2378		.2561	.5182	.6001	.4801	.5487
14	.2561	.2743	.2926	.4572	.5658	.6001	.5639
15	.2743	.2915	.2561	.5182	.583		.5182
16	.2926	.1715	.3292	.5487	.5658		
17	.2195	.2229	.3292	.5639	.5487		
18	.2561	.3086	.2926	.5182	.4801	.5144	
19	.4938	.5144	.4755	.3772	.3944	.4801	
20	.4755	.5487	.4572	.5144	.4287	.4458	
21	.4572	.4458	.439	.3772	.3944	.3944	
22	.3658	.3429	.3841	.2915	.3429	.3086	
23	.2926	.2743	.3109	.3086	.3086	.2743	
24	.319	.3658	.3353	.2743	.2401	.2743	.2743
Max	.695	.8596	.7682	.6554	.6516	.6173	.6687
Min	.2195	.1715	.2561	.2572	.2229	.2743	.2743
Avg	.3884	.4376	.4053	.4125	.4388	.3978	.4690

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094025 / 33/11 KV ARVI

Feeder No / Name : 205 / 11 KV KULTHE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.319	.2743	.2743	.2561	.1372	.2572	.2058
2	.3378	.2561	.2743	.2743	.1372	.2743	.2401
3	.3566	.2743	.2572	.2743	.1829	.2743	.2572
4	.4692	.2743	.3086	.3109	.1829	.3086	.3429
5	.4879	.3475	.3429	.2561	.1981	.3429	.3772
6	.5067	.4572	.4801	.439	.2134	.3772	.4115
7	.4129	.4207	.3944	.381	.1981	.4458	.4973
8	.3109	.2743	.3292	.3353	.1886	.463	.3353
9	.2743	.2743	.2926	.2896	.3086	.3601	.3506
10	.2195	.2229	.2743	.2229	.2229	.1886	.2058
11	.4572	.3353	.3292	.2229	.2401	.1715	.1886
12	.439	.3658	.4207	.2229	.2058	.1886	.2058
13	.5487	.3506	.3475	.2572	.2401	.2401	.2401
14	.4024	.3201	.3475	.2572	.2572	.3601	.2401
15	.4024	.3353	.3841	.2572	.2743		.2572
16	.439	.3201	.3292	.2743	.2572		.2401
17	.4024	.3048	.4024	.2229	.2401		.2401
18	.3475	.2896	.3292		.2743	.3601	
19	.3109	.3429	.2926	.2915	.3429	.3944	
20	.4024	.463	.3658	.463	.4115	.4287	
21	.4755	.4287	.4207	.3772	.4458	.3944	
22	.3841	.3601	.3658	.3601		.3772	
23	.3109	.3258	.3292	.3086	.3601	.3258	
24	.319	.2743	.2915	.2561	.1372		.2058
Max	.5487	.463	.4801	.463	.4458	.463	.4973
Min	.2195	.2229	.2572	.2229	.1372	.1715	.1886
Avg	.3890	.3288	.3410	.2961	.2459	.3266	.2801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213] BU 0574

Substation No/ Name :- 094025 / 33/11 KV ARVI

Feeder No / Name : 206 / 11 KV ERCON

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0375	.0219	.0245	.0206	.0223	.024	.0343
2	.0375	.0219	.0238	.0206	.0206	.024	.0343
3	.0375	.0219	.0238	.0206	.0223	.024	.0343
4	.0375	.0219	.0238	.0206	.0206	.024	.0343
5	.0375		.0238	.0206	.0206	.024	.0343
10						.1372	
20	.0219	.0245	.0219		.028	.0343	
21	.0219	.0238	.0219	.0223	.0257	.0343	
22	.0221	.0238	.0219	.0223	.0257	.0343	.0257
23	.0219	.0238	.0219	.0223	.024	.0343	.0223
24	.0375		.0238	.0219	.0223	.024	.0343
Max	.0375	.0245	.0245	.0223	.028	.1372	.0343
Min	.0219	.0219	.0219	.0206	.0206	.024	.0223
Avg	.0313	.0229	.0231	.0213	.0232	.0380	.0317

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094034 / 33/11 KV MUKTI

Feeder No / Name : 201 / 11 KV MUKTI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2317	.2439	.2606	.0518	.0564	.0579	.4572
2	.2896	.3048	.2972	.0518	.0564	.0518	.4572
3	.2896	.3048	.2972	.0518	.0564	.0549	.4572
4	.4161	.4268	.4858	.0518	.0564	.0549	.4877
5	.6097	.6097	.6802	.0518	.0587	.0579	.5792
6	.7926	.7621	.7811	.0579	.0686	.0972	.6401
7	.8124	.7621	.9804	.064	.0686		.4572
8	.6874	.7621	.8539	.061	.061	.0305	.381
9	.6097	.6859	.6325	.061	.0533	.0305	.3048
10	.0762	.061	.0518	.061	.0518	.061	.0503
11	.0762	.0457	.0556	.7316	.6401	.6401	
12	.0762	.0457	.0556	.7499	.6097	.6859	
13	.0762	.0457	.0556	.5487	.6097	.6097	.0526
14	.0762	.0457	.0541	.6173	.5792	.6097	
15	.0762	.0457	.0533	.5556	.5624	.6097	.0533
16	.0762	.0457	.0533	.6173	.5937	.5792	
17	.0762	.0457	.0518	.7316	.5601	.5335	.0533
18	.0762	.0457	.0518	.6455	.6249		.0457
19	.1219	.0457	.0945	.1174	.0625	.0762	.0914
20	.1219	.0762	.1067	.1372	.0743	.0762	.0762
21	.1219	.0762	.1006	.12	.0914	.0762	.0823
22	.0762	.0457	.1006	.1097	.0762	.0762	.0823
23	.0762	.0457	.0533	.1097		.0762	.0869
24	.2286	.2286	.1829	.0533	.0594	.0914	.3048
Max	.8124	.7621	.9804	.7499	.6401	.6859	.6401
Min	.0762	.0457	.0518	.0518	.0518	.0305	.0457
Avg	.2571	.2420	.2663	.2670	.2492	.2380	.2600

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094034 / 33/11 KV MUKTI

Feeder No / Name : 202 / 11 KV ANCHALE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1189	.1524	.1524	.1307	.1219	.1433	.1677
2	.1189	.1524	.1524	.1307	.1219	.1372	.1677
3	.1189	.1524	.1524	.1307	.1219	.1402	.1677
4	.1524	.1677	.2286	.1494	.1219	.1433	.1829
5	.192	.1829	.3048	.1494	.1524	.1791	.2134
6	.2401	.2439	.3048	.2241	.2439	.2572	.2439
7	.2915	.2743	.2915	.1307	.1524	.2572	.2439
8	.3113	.3048	.3239	.1307	.1219	.1524	2.4234
9	.1829	.2743	.2915	.1307	.1677	.1524	.2134
10	.0914	.1219		.0934	.1677	.1067	.1294
11	.0762	.1219	.0924	.1867	.2058	.1829	.0924
12	.0762	.1219	.0924	.2241	.3086	.1981	.0934
13	.0914	.1219	.0924	.2241	.3086	.2439	.1494
14	.0914	.1219	.1294	.168	.3086	.2439	.1494
15	.0914	.1219	.1294	.0747	.2439	.2134	.1307
16	.0914	.1219	.1294	.1307	.2743	.1829	.1307
17	.1067	.1219	.1294	.1981	.2286	.1524	.1494
18	.1067	.1524	.1478	.2134	.2896		.2054
19	.2286	.1829	.1867	.2134	.1524	.0762	.2987
20	.2134	.1829	.2987	.2439	.2286	.0762	.2987
21	.1677	.1829	.2427	.1524	.1829	.1981	.2614
22	.1219	.1524	.1867	.1524	.1524	.1677	.2241
23	.1219	.1219	.1494	.1524	.1219	.1524	.1867
24	.1235	.1524	.1219	.1494	.1219	.1341	.1524
Max	.3113	.3048	.3239	.2439	.3086	.2572	2.4234
Min	.0762	.1219	.0924	.0747	.1219	.0762	.0924
Avg	.1469	.1670	.1883	.1618	.1926	.1692	.2782

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094034 / 33/11 KV MUKTI

Feeder No / Name : 203 / 11 KV MUKTI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4755	.5601	.5975	.5792	.5792	.6535	.6535
2	.4755	.5601	.5975	.5792	.5792	.6401	.6535
3	.4755	.5601	.5975	.5792	.6154	.6535	.6535
4	.5853	.6535	.7468	.6516	.724	.6001	.8402
5	.7682	.8589	.9709	.724	.8048	.8589	1.0269
6	.9979	1.1203	1.1203	.924	1.2323	1.1203	1.2323
7	.9709	1.0269	1.1389	1.1458	1.1088	1.1203	.9335
8	.924	.9335	1.0456	.924	1.0719	1.0829	.7468
9	1.0269	.7842	1.0829	.924	.9709	.9709	.8962
10	1.0269	.7468	1.0456	.8131	.961	.8962	.6219
11	.8962	.7468	.9335	.6722	.7762	.8962	.6241
12	.7468	.7095	.8589	.6722	.7842	.8589	.6173
13	.8402	.7095	.7468	.6722	.7468	.8402	.6878
14	.9335	.7842	.8589	.7922	.6722	.7842	.6878
15	.9709	.8962	.8589	.8131	.7842	.8589	.6878
16	.9709	.8589	.8589	.8131	.7842	.8962	.6878
17	.9335	.9335	.7602	.7796	.7842	.9335	.724
18	.9335	.9335	.7964	.815	.8215		.9259
19	1.0829	1.1949	.9774	1.0498	.8589	1.0082	1.0166
20		1.1203	1.2936	1.3306	1.1949	1.0829	1.0974
21	.8589	.9808	1.0498	.8954	.9709	.9709	.8596
22	.7842	.9431	.6878	.7602	.8962	.8589	.7602
23	.7468	.7468	.6516	.6516	.7468	.7468	.724
24	.5121	.7468	.6535	.6154	.6154	.6401	.7095
Max	1.0829	1.1949	1.2936	1.3306	1.2323	1.1203	1.2323
Min	.4755	.5601	.5975	.5792	.5792	.6001	.6173
Avg	.8233	.8379	.8721	.7990	.8368	.8684	.7945

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094034 / 33/11 KV MUKTI

Feeder No / Name : 204 / 11 KV EXP.WATER SUPPLY
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305	.0514	.0594	.0297	.0187	.0474	.0514
2	.0305	.0514	.0594	.0297	.0187	.0474	.0514
3	.0305	.0514	.0594	.0297	.0187	.0469	.0686
4	.0305	.0514	.0594	.0297	.0244	.0446	.0686
5	.0305	.0686	.0594	.0297	.0366	.0457	.0686
6	.0305	.0686	.0594	.0297	.0434	.0434	.0514
7	.0305	.0514	.0594	.0305	.0406	.0724	.0514
8	.0305	.0514	.0594	.0305	.0429	.0514	.0514
9	.0305	.0686	.0594	.0305	.0351	.0457	.0514
10	.1067	.1372	.1075	.0305	.1772	.0857	.0754
11	.12	.1715	.1791	.1524	.1753	.1372	.1463
12	.12	.1715	.1791	.1524	.0876	.1524	.1463
13	.1372	.1715	.1433	.1524	.1772	.1715	.1448
14	.1543	.1715	.1433	.1524	.1772	.12	.1448
15	.1715	.1372	.1463	.1372	.1524	.1715	.1448
16	.1715	.1372	.0754	.1646	.1715	.1715	.1448
17	.1067	.1372	.032	.181	.1715	.0857	.181
18	.0457	.1867	.0312	.1612	.1524		.032
19	.0457	.1753	.0312	.1791	.1524	.0686	.032
20	.0457	.1402	.0312	.1433	.0762	.0686	.0366
21	.0457	.1029	.0312	.0412	.0781	.0686	.0377
22	.0457	.0492	.0312	.0366	.0781	.0514	.0362
23	.0457	.0469	.0297	.0366	.0469	.0514	.0373
24	.0305	.0457	.0469	.0297	.052	.0469	.0514
Max	.1715	.1867	.1791	.181	.1772	.1715	.181
Min	.0305	.0457	.0297	.0297	.0187	.0434	.032
Avg	.0695	.1040	.0739	.0842	.0919	.0824	.0794

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094054 / 33/11 KV KUNDANE (WAR)

Feeder No / Name : 201 / 11 KV SANJORI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6635	.6281	.5935	.6783	.6274	.5935	.338
2	.6805	.662	.6451	.8139	.6783	.6104	.422
3	.7146	.713	.5871	.8987	.7461	.6443	.5041
4	.7996	.7647	.6729	1.0174	.8309	.6783	.5383
5	1.0038	.8327	.7074	1.1191	1.2209	.763	.5915
6	1.1059	1.1386	.7013	1.3226	1.5769	1.4243	.6253
7	.9017	.9177	.6489	1.6108	2.0008	1.8821	.5881
8	.8847	.7647	.618	1.5244	1.6956	1.7635	.5432
9	.0851	.6458	.6026	1.4886	1.2703	1.5261	.5262
10	.6465	.6288	.5772	.6097	.6267	.5765	.5772
11	1.5312	1.5295		.5759	.5251	.5948	.662
12	1.9565	2.0053	.4414	.6267	.6097	.6443	.5262
13	1.8354	1.6975	.4923	.6267	.6436	.6274	.6111
14	1.7844		.3225	.6436	.6436	.6104	.662
15	1.5635	1.5278	1.5617	.6613	.8309	.5935	.6952
16	1.4615	1.4542	1.6956	.6613	.763	.5087	.6613
17	1.4938	1.4074	1.56	.6443	.7291	.5438	.679
18	1.2901	1.2717	1.4922	.6274	.78	.5596	.7308
19	.679	1.0197	.6606	.78	.8478	.6783	.8327
20	.9167	.9315	.9654	1.0004	1.0513	.7308	.9347
21	.9676	.8987	.8817	.8648	.9326	.7647	.8318
22	.8148	.7291	.7461	.7969	.7969	.8327	.8971
23	.713	.6638	.6783	.6613	.6952	.5948	.8459
24	.6635	.6281	.5871	.6104	.5935	.5098	
Max	1.9565	2.0053	1.6956	1.6108	2.0008	1.8821	.9347
Min	.0851	.6281	.3225	.5759	.5251	.5087	.338
Avg	1.0482	1.0200	.8017	.8694	.9048	.8023	.6445

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094054 / 33/11 KV KUNDANE (WAR)

Feeder No / Name : 203 / 11 KV KUNDANE (WAR)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.357	.4542	.4363	.5271	.5082	.5653	.4534
2	.3563	.4748	.5241	.4979	.5459	.5658	.5239
3	.3919	.4825	.6168	.5567	.6413	.5981	.6042
4	.443	.5089	.8402	.6335	.7545	.6005	.6602
5	.6499	.541	.7476	.788	.9639	.6419	.9072
6	.8774	.7108	.7683	.929	1.0395	1.0584	.9778
7	.9485	.8541	.7562	.8316	.8119	.8685	.9345
8	.856	.9328	.7519	.6588	.6582	.6205	.6008
9	.7792	.8269	.6056	.5812	.5788	.5806	.5448
10	.5448	.58	.5376	.5624	.5415	.5111	.542
11	.2259	.5103		.7002	.6683	.9335	.2515
12	.2454	.543	.2981	.8141	.7416	.6996	.3309
13	.2254	.5499	.5963	.8192	.7763	.6882	.338
14	.6508	.5956	.6149	.7929	.6645	.6671	.3869
15	.6521	.592	.613	.7598	.7167	.6638	.4037
16	.5969	.5556	.6149	.7459	.707	.1665	.4206
17	.5753	.577	.5895	.6493	.6939	.1347	.3549
18	.5938	.5607	.4979	.5907	.614	.1668	.3128
19	.8282	.6542	.7138	.7153	.7882	.4662	.8829
20	.9808	.7484	.9619	.9808	.9818	.9223	.6965
21	.8479	.7914	.7914	.8847	.8856	.8935	.4486
22	.7341	.6958	.6756	.7522	.7138	.7858	.7826
23	.6212	.4463	.5818	.6017	.6193	.756	.5212
24	.3224	.354	.3213	.5453	.5459	.7109	
Max	.9808	.9328	.9619	.9808	1.0395	1.0584	.9778
Min	.2254	.354	.2981	.4979	.5082	.1347	.2515
Avg	.5960	.6058	.6285	.7049	.7150	.6361	.5600

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094054 / 33/11 KV KUNDANE (WAR)

Feeder No / Name : 204 / 11 KV GHV INDUSTRIAL
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2457	.0468	.0503	.2829	.0378	.422	.1808
2	.3024	.2007	.0505	.4154	.0378	.4692	.2215
3	.3024	.2824	.2185	.5255	.0377	.4095	.2211
4	.2641	.2984	.1682	.5647	.0378	.054	.1678
5	.3206	.242	.2019	.2783	.0377	.0282	.1692
6	.3587	.0466	.2617	.0183	.0234	.025	.168
7	.0422	.0174	.0374	.4563	.0234	.0334	.2202
8	.0703	.0475	.0373	.0322	.0468	.0261	.1379
9	.0612	.0169	.0374	.0215	.0493	.0378	.0256
10	.0638	.3392	.083	.0571	.0318	.1504	.0696
11	.0474	.1198		.0544	.0536	.146	.3681
12	.0359	.2838	.4845	.1449	.0515	.3829	.3398
13	.0186	.0378	.0316	.0362	.0476	.2735	.0374
14	.0364	.0205	.0545	.3654	.0346	.2457	.0249
15	.5459	.0271	.5392	.4303	.0324	.2275	.3142
16	.5853	.0333	.5944	.5497	.0393	.3024	.3003
17	.1846	.0174	.1457	.4559	.0288	.0566	.0343
18	.5093	.0186	.0516	.057	.0559	.0537	.2954
19	.5223	.0333	.3033	.054	.0366	.0373	.0392
20	.5233	.0335	.5698	.0356	.5618	.0314	.0367
21	.1446	.0335	.4692	.0509	.455	.2836	.0257
22	.3323	.0246	.031	.0542	.4749	.4924	.0176
23	.2089	.0464	.4914	.036	.0233	.3659	.0353
24	.3591	.0296	.0464	.1903	.0231	.394	.4078
Max	.5853	.3392	.5944	.5647	.5618	.4924	.4078
Min	.0186	.0169	.031	.0183	.0231	.025	.0176
Avg	.2536	.0957	.2156	.2153	.0951	.2062	.1608

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094055 / 33/11 KV VELHANE (NIMGUL)

Feeder No / Name : 201 / 11 KV DHAMANGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0166	.0299		.0533	.0662	.03
2	.0171	.0166	.0299	.0686	.0533	.0662	.03
3		.0166	.03		.0533	.0662	
4	.0171	.0166	.03	.0686	.0667	.0662	.03
5		.0166	.0268		.0934	.0828	.0299
6	.0171	.0331	.0299	.2572	.16	.1324	.06
7	.0171	.0331	.015	.0686	.1334	.3146	.0901
8	.0166	.0331		.1715	.1987	.1324	
9	.0166	.0299		.08	.1324	.1483	.0857
10	.0166	.015	.0171	.0267	.0497	.0166	
11	.1324	.1195		.0267	.0166	.0165	.0171
12	.2483	.2096	.12	.0133	.0166	.0165	
13	.1656	.2399		.0133	.0166	.0165	.0171
14	.149	.2096	.1029	.0133	.0166	.0165	
15	.149	.1804		.0133	.0166	.0188	.0171
16	.1324	.1799	.1029	.0133	.0166	.0163	
17	.149	.1499		.0133	.0166	.0167	
18	.1324	.1347	.12	.0267	.0166		.0171
19	.0331	.0135		.0343	.0166	.0333	
20	.0331	.0167	.0171	.0343	.0166	.0333	
21	.0166	.0299		.0343	.0331	.0299	
22	.0166	.03	.0171	.0343		.0299	
23	.0166	.0299	.0171	.0343		.0299	.0171
24		.0166	.0299	.0686	.04	.0662	.0299
Max	.2483	.2399	.12	.2572	.1987	.3146	.0901
Min	.0166	.0135	.015	.0133	.0166	.0163	.0171
Avg	.0746	.0745	.0460	.0531	.0561	.0623	.0362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094055 / 33/11 KV VELHANE (NIMGUL)

Feeder No / Name : 202 / 11 KV NIMGUL AG-2

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0662	.1494				
2	.0343	.0662	.1616				
3		.0828	.2096				
4	.0343	.1159	.2094				
5		.1987	.2689				
6	.7716	.528	.3502				
7		.5464	.4504				
8	.4139	.3973					
9	.2649	.2849					
11				.3334	.3146	.2997	.1715
12				.3868	.447	.4668	
13				.3467	.3477	.5335	.2058
14				.3067	.2815	.5001	
15				.3334	.3311	.4614	.2401
16				.3734	.3973	.5001	
17				.3601	.3477	.2396	.2058
18				.2667	.3808		.1372
24	.0343	.0828	.1494				
Max	.7716	.5464	.4504	.3868	.447	.5335	.2401
Min	.0343	.0662	.1494	.2667	.2815	.2396	.1372
Avg	.2589	.2369	.2436	.3384	.3560	.4287	.1921

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094055 / 33/11 KV VELHANE (NIMGUL)

Feeder No / Name : 203 / 11 KV VELHANE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0533	.0662	
2				.0857	.0533	.0662	
3					.0533	.0662	
4				.12	.0667	.0828	
5					.1067	.1159	
6				.1715	.2	.1324	
7					.3467	.3477	
8				.1715	.264	.3146	
9				.1334	.1987	.1959	
11	.2483	.1334					.0857
12	.3311	.1499	.2058				
13	.2318	.2155					
14	.2483	.2425	.2058				
15	.1656	.2689					
16	.1987	.1886	.1715				
17	.1987	.1799					
18	.1656	.1503	.1886				
19							.1029
24				.1029	.0533	.0662	
Max	.3311	.2689	.2058	.1715	.3467	.3477	.1029
Min	.1656	.1334	.1715	.0857	.0533	.0662	.0857
Avg	.2235	.1911	.1929	.1308	.1396	.1454	.0943

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094059 / 33/11 KV VINCHUR

Feeder No / Name : 201 / 11 KV VINCHUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9896	.7922		.9431
2		1.4937	.811		.9431
3		1.6244	.811		.9808
4		1.6804	.8676		
5		1.8671	1.1506		
6		2.1845	2.0748		
7		2.0911	1.8673		
8		1.7551	1.7541		
9		1.7364	1.7541		
10		1.5123	1.5089		
11		.9522	1.0374		
12		.8962	.9431		
13		.8962	.9619		
14		.9335	.9997		
15		.9709	1.0562		
16		.9896	.9997		
17		1.1016	1.1694		
18		1.2323	1.2637		
19		1.9231	1.6409		
20		2.2592	2.0936		
21		1.419	1.4712		
22		1.0642	1.1128		
23		.8962	.9242		
24	.8589	1.1203	.8299	.8865	
Max	.8589	2.2592	2.0936	.8865	.9808
Min	.8589	.8962	.7922	.8865	.9431
Avg	.8589	1.3995	1.2456	.8865	.9557

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213] BU 0574

Substation No/ Name :- 094059 / 33/11 KV VINCHUR

Feeder No / Name : 202 / 11 KV TARWADE AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	15-JUN-18	16-JUN-18	17-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
1		.2058	.1524
2		.2629	.1524
3		.3429	.1524
4		.503	.1524
5		.4687	.1677
6		.4915	.7621
7		.823	1.0059
8		.3086	.8078
9		.3887	.6249
24	.1715	.2743	.1524
Max	.1715	.823	1.0059
Min	.1715	.2058	.1524
Avg	.1715	.4069	.4130

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213] BU 0574

Substation No/ Name :- 094059 / 33/11 KV VINCHUR

Feeder No / Name : 203 / 11 KV SITANE AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	16-JUN-18	17-JUN-18	18-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
11	.2477	.2629	
12	.381	.3429	
13	.2477	.3429	
14	.2477	.3658	
15	.2096	.2743	
16		.2743	
17	.2667	.2286	
18	.2286	.2058	
24			.1143
Max	.381	.3658	.1143
Min	.2096	.2058	.1143
Avg	.2613	.2872	.1143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094060 / 33/11 KV CHOUGAON

Feeder No / Name : 201 / 11KV AJANALE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.1715	.1029	.1886	.2058	.1715	.2229
2	.0857	.1886	.1029	.1886	.2229	.1715	.2229
3	.0857	.2058	.1029	.1886	.2401	.2058	.2229
4	.1029	.1886	.1372	.2058	.2229	.2229	.2572
5	.1543	.2058	.1372	.2743	.2058	.3601	.3086
6	.2401	.2229	.2058	.4115	.2401	.4287	.4287
7	.3429	.2915	.3086	.3086	.2229	.2915	.3601
8	.3429	.2572	.3086	.2058	.2401	.1886	.3429
9	.2229	.1029	.2572	.1886	.2058	.2058	.2572
10	.12	.1372	.1886	.2058	.2229	.2058	.2229
11	.1886	.1715	.2058	.1029	.2229	.2229	.1372
12	.1715	.1886	.2058	.2572	.2058	.2743	.1715
13	.2058	.2058	.2058	.2743	.2401	.2572	.1372
14	.2401	.1715	.2058	.2915	.2401	.2572	.12
15	.2572	.1886	.2058	.2572	.1886	.2915	.12
16	.2743	.1886	.2229	.1886	.2915	.1029	.2401
17	.2229	.2229	.2401	.2229	.2058		.12
18	.2572	.3086	.3086	.1886	.1886		.1372
19	.3258	.3086	.3429	.2572	.2915		.3429
20	.3086	.3258	.3258	.3429	.3258		
21	.3086	.3086	.2915	.3258	.2915		
22	.2401	.2401	.2401	.2915	.2401	.2572	
23	.2229	.1886	.2058	.2401	.2058	.2572	
24	.0857	.2058	.1886	.1886	.2229	.2058	.2401
Max	.3429	.3258	.3429	.4115	.3258	.4287	.4287
Min	.0857	.1029	.1029	.1029	.1886	.1029	.12
Avg	.2122	.2165	.2186	.2415	.2329	.2410	.2306

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213] BU 0574

Substation No/ Name :- 094060 / 33/11 KV CHOUGAON

Feeder No / Name : 202 / 11 KV CHOUGAON 1 PHASING SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429	.4115	.4458	.583	.3429	.2743
2	.3429	.3772	.4458	.4458	.6173	.7373	.2743
3	.3258	.4115	.4801	.4458	.6859	.6859	.2743
4	.3429	.4801	.3429	.4973	.823	.7716	.2743
5	.4801	.5487	.5144	.6001	1.0288	.8745	.3086
6	.5487	.583	.5487	.5144	1.286	1.1317	.3772
7	.4115	.5144	.4287	1.3546	1.5432	1.4403	.3429
8	.3086	.3086	.3429	1.3546	1.6804	1.2517	.3429
9	.2572	.2915	.2915	1.2174	1.5089	1.3032	.2743
10	.3086		.2915	.2743	.2401	.3086	.3601
11	1.3032		1.1831	.2058	.2743	.3086	.2915
12	1.7661		1.6632	.2401	.2743	.3258	.2743
13	1.7147	1.6118	1.5947	.3086	.3086	.3258	.3086
14	1.5775	1.5432	1.3889	.2915	.3086	.3429	.2915
15	1.5432	1.5432	1.1831	.3086	.3258	.3258	.3086
16	1.5089	1.4403	1.3203	.3086	.2229	.2743	.3086
17	1.406	1.3717	1.2174	.3086	.1372		.2743
18	1.3375	1.0288	.3086	.2915	.0686		.3086
19	.3601	.3601	.463	.3429	.12		.3772
20	.4287	.3429	.4458	.4115	.3429		.4801
21	.463	.3429	.4287	.463	.4115		.4458
22	.4115	.4287	.3944	.4287	.3429	.3429	.3086
23	.3772	.4115	.3429	.3772	.3086	.4458	.3086
24	.3429	.3772		.4458	.4801	.3601	.2743
Max	1.7661	1.6118	1.6632	1.3546	1.6804	1.4403	.4801
Min	.2572	.2915	.2915	.2058	.0686	.2743	.2743
Avg	.7587	.6981	.6970	.4951	.5801	.6263	.3193

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094072 / Chinchkhede

Feeder No / Name : 201 / CHINCHKHEDE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1134	.2286	.12	.1781	.1524	.1943	.1457
2	.1134	.2286	.1543	.1781	.1524	.1966	.1296
3	.1134	.2286	.1543	.1781	.1524	.1943	.1296
4	.1296	.3048	.1715	.2105	.2286	.2429	.1457
5	.2267	.381	.2229	.2591	.3048	.3239	.1943
6	.3077	.4268	.2572	.3239	.381	.3725	.2267
7	.3725	.3048	.3601	.2915	.3048	.3239	.1943
8	.2429	.3048	.4115	.2429	.2286	.2458	.1619
9	.1524	.3429	.2105	.1829	.2401	.1943	.1781
10	.1524	.1543	.1943	.1524	.2267	.1296	.192
11	.1524	.1886	.1781	.2286	.2915	.1619	.1619
12	.1524	.1715	.1781	.3048	.2241	.2591	.1638
13	.1524	.1886	.1781	.3048	.1943	.2267	.1619
14	.2286	.2058	.1781	.3048	.192	.1619	.1638
15	.3048	.2058	.1943	.3048	.1943	.1943	.1943
16	.3353	.2229	.1943	.3048	.1966	.1943	.1966
17	.3048	.2058	.2105	.2286	.16	.1943	.1966
18	.2286	.1029	.1943	.2286	.2105		.1966
19	.2134	.1543	.2429	.3048	.2294	.2591	.3401
20		.1543	.2915	.3048	.2949	.3239	.3239
21	.2134	.1372	.2591	.3048	.3239	.2915	.2915
22	.2286	.12	.2267	.1524	.2949	.2591	.2591
23	.2286	.1029	.1943	.1524	.2591	.2429	.2267
24	.2286		.1029	.1524	.2458		.1943
Max	.3725	.4268	.4115	.3239	.381	.3725	.3401
Min	.1134	.1029	.1029	.1524	.1524	.1296	.1296
Avg	.2129	.2203	.2117	.2408	.2368	.2358	.1987

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094072 / Chinchkhede

Feeder No / Name : 202 / VAJIRKHEDE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1619	.1524	.1715	.1457	.2286	.1966	.1943
2	.1619	.1524	.1543	.1457	.2286	.1966	.1943
3	.1619	.1524	.1543	.1457	.2286	.1943	.1943
4	.1781	.1829	.1886	.1619	.3048	.2458	.2105
5	.2267	.2134	.2229	.2105	.381	.2591	.2429
6	.2429	.3048	.2572	.2591	.4268	.2753	.2429
7	.1943	.2286	.2058	.2915	.3353	.3725	.1943
8	.1619	.1524	.1715	.2915	.3353	.3768	.1619
9			.1457		.3563	.3563	.1311
10	.1524		.125	.1524	.1966	.1619	.1311
11	.2286	.1886	.2915	.1524	.16	.1296	.2429
12	.3048	.3944	.4049	.1524	.1457	.1457	.3239
13	.4572	.3429	.3725	.1524	.1296	.1457	.3201
14	.4572	.2915	.3239	.1524	.1296	.1457	.2915
15	.4572	.2572	.2429	.1524	.16	.1781	.3201
16	.381	.1543	.2591	.1524	.1619	.1619	.3239
17	.2439	.3601	.3239	.1524	.1619	.1619	.2401
18	.2439	.2572	.2915	.1524	.1781		.2105
19	.1829	.1886	.1781	.1524	.192	.1943	.1943
20	.1829	.2572	.2591	.2286	.2267	.2591	.2105
21	.1829	.2401	.2267	.2286	.2429	.2429	.1875
22	.1524	.2058	.1943	.1524	.213	.2267	.1619
23	.1524	.1715	.1619	.1524	.1943	.2105	.1619
24	.1524		.1715	.2286	.1989		.1619
Max	.4572	.3944	.4049	.2915	.4268	.3768	.3239
Min	.1524	.1524	.125	.1457	.1296	.1296	.1311
Avg	.2357	.2309	.2291	.1811	.2299	.2199	.2187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213] BU 0574

Substation No/ Name :- 094072 / Chinchkhede

Feeder No / Name : 401 / 33 KV INCOMMER

Chinchkhede Feeder KV- 33 /
INCOMING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.3887	1.3717	.3086	.5344	1.6918	.3401
Max	.3887	1.3717	.3086	.5344	1.6918	.3401
Min	.3887	1.3717	.3086	.5344	1.6918	.3401
Avg	.3887	1.3717	.3086	.5344	1.6918	.3401

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094007 / 33/11 KV PIMPALNER

Feeder No / Name : 201 / 11 KV DEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4918	1.5203	1.5746	.4144	.4144	.3239	.6478
2	1.6575	1.5203	1.5746	.4144	.4144	.3239	.6478
3	1.6575	1.5203	1.5746	.4144	.4144	.3239	.3239
4	1.6575	1.5203	1.6575	.4144	.4144	.4858	.4049
5	1.7404	1.7604	1.8233	.4144	.4973	.4858	.4858
6	1.989	2.4006	1.989	.4973	.5801	.3239	.3239
7	2.8178	2.7206	2.652	.4144	.4144	.3239	.4858
8	2.2177	2.7206	2.9007	.3315	.3315	.3239	.6478
9	2.3205	2.4863	2.652	.3315	.2486	.2429	.3239
10	.2401	.2486	.2486	.2486	.16	.2429	.2429
11	.2401	.1658	.2486	1.989	2.4006	2.1862	.4801
12	.2401	.1658	.2486	3.1493	3.2808	2.834	1.989
13	.2401	.2486	.2486	2.9835	2.8807	2.9959	2.2672
14	.2401	.2486	.2486	2.8178	2.5606	2.9959	2.2672
15	.2401	.2486	.2486	2.3205	2.2405	2.672	2.5101
16	.2401	.2486	.2486	2.8178	2.5606	2.2672	2.5101
17	.16	.2486	.2486	2.3205	2.5606	1.9433	2.2672
18	.3201	.2486	.2486	2.4863	2.3205		1.9433
19	.3201	.1658	.3315	.3315	.3201	.1619	.3239
20	.4801		.3315	.4973	.4858	.4858	.4858
21	.4801	.4144	.3315	.4973	.4858	.4049	.4858
22	.3201	.3315	.4144	.4973	.4858	.4049	.4858
23	.3201	.4144	.3315	.3315	.4858	.4049	.4049
24	1.4089	1.4403	1.4918	.3315	.4144	.3239	.3239
Max	2.8178	2.7206	2.9007	3.1493	3.2808	2.9959	2.5101
Min	.16	.1658	.2486	.2486	.16	.1619	.2429
Avg	.9600	1.0003	.9945	1.1361	1.1405	1.0209	.9700

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094007 / 33/11 KV PIMPALNER

Feeder No / Name : 202 / 11 KV BALHANE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8671	1.8004	1.9281	.4191	.4973	.5144	.5144
2	1.6575	1.8004	1.9281	.4191	.4973	.5144	.5144
3	1.6575	1.8004	1.9281	.4191	.4973	.5144	.5144
4	1.6575	1.8004	2.0119	.503	.4973	.5144	.5144
5	1.7404	1.8004	2.1795	.5868	.5801	.6859	.6859
6	2.2377	1.9719	2.7664	.6706	.7459	.7716	.7716
7	2.8178	2.3148	3.3532	.5868	.4973	.6001	.6859
8	2.5692	2.7435	3.1017	.4191	.4144	.4287	.4287
9	2.4034	2.934	2.934	.3353	.3315	.5144	.4287
10	.2572	.2515	.2515	.3315	.2572	.2572	.3429
11	.2572	.2515	.2515	2.4034	2.4863	2.572	2.0576
12	.2572	.2515	.2515	3.4808	3.3436	3.0007	3.0007
13	.2572	.1677	.1677	3.315	3.4294	2.6578	2.915
14	.2572	.1677	.2515	3.2322	3.0864	3.0007	2.915
15	.2572	.1677	.2515	2.9835	2.915	2.915	2.7435
16	.1715	.2515	.2515	2.9835	2.8292	2.6578	2.7435
17	.3429	.2515	.2515	2.7349	1.3575	2.7435	2.7435
18	.3429	.3353	.2515	2.652	2.7435	1.8861	2.4863
19	.4287	.503	.4191	.4144	.4287	.5144	.4287
20	.6001	.5868	.5868	.663	.6859		.5144
21	.6001	.5868	.5868	.5801	.6001	.3429	.6001
22	.5144	.503	.5868	.5801	.6001	.6859	.6001
23	.5144	.503	.503	.4973	.5144	.6001	.5144
24	1.5746	1.8004	1.7604	.4191	.4973	.5144	.5144
Max	2.8178	2.934	3.3532	3.4808	3.4294	3.0007	3.0007
Min	.1715	.1677	.1677	.3315	.2572	.2572	.3429
Avg	1.0517	1.0644	1.1981	1.3179	1.2639	1.2786	1.2574

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094007 / 33/11 KV PIMPALNER

Feeder No / Name : 203 / 11 KV SAMODA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.5544	.6468	1.7556	1.6804	1.848	1.6632
2	.7545	.5544	.6468	1.7556	1.6804	1.848	1.6632
3	.7468	.5544	.6468	1.7556	1.6804	1.848	1.6632
4	.7468	.5544	.7392	1.848	1.6804	1.9404	1.6632
5	.7468	.6468	.8316	2.0328	1.8671	2.0328	1.9404
6	.9335	.924	.924	2.4025	2.5206	1.9404	2.2177
7	.8402	.8316	.7392	2.9569	2.9874	3.2341	2.7721
8	.6535	.6468	.5544	2.7721	3.2674	3.2341	2.7721
9	.6535	.5544	.6468	2.4949	2.894	2.9569	2.5873
10	.3696	.3696	.6468	.5601	.462	.6468	.5544
11	2.5873	2.3101	2.4025	.3734	.3696	.462	.5544
12	3.1417	2.0328	2.9835	.3734	.462	.5544	.5544
13	3.0493	1.9404	3.2341	.5601	.5544	.5544	.5544
14	2.7721	2.1253	3.2341	.5601	.5544	.6468	.5544
15	2.7721	2.0328	2.7721	.5601	.6468	.6468	.5544
16	2.6797	2.8645	2.7721	.4534	.6468	.6468	.5544
17	2.4949	2.8645	2.4949	.6535		.6468	.6468
18	2.4949	2.0328	2.3101	.5601	.462	.7392	.6468
19	.5544	.5544	.7392	.7468	.5544	.8316	.5544
20	.7392	.8316	.924	.7468	.924	.8316	.924
21	.7392	.8316	.8316	.9335	.924	.924	.924
22	.7392	.8316	.8316	.9335	.924	.924	.924
23	.7392	.7392	.7392	.7468	.7392	.8316	.8316
24	.7468	.5544	.7392	1.7556	1.7737	1.848	1.6632
Max	3.1417	2.8645	3.2341	2.9569	3.2674	3.2341	2.7721
Min	.3696	.3696	.5544	.3734	.3696	.462	.5544
Avg	1.3934	1.1974	1.4179	1.2621	1.3155	1.3591	1.2474

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094007 / 33/11 KV PIMPALNER

Feeder No / Name : 204 / 11 KV SUKAPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.4715	.4715	.4858	.6535	.602	.5001
2	.5601	.4715	.4715	.4858	.6535	.5944	.5716
3	.4668	.4715	.4715	.4858	.6535	.5944	.5716
4	.4668	.4715	.4715	.4858	.6706	.5944	.5716
5	.4973	.4715	.4715	.5668	1.0059	.6944	.643
6	.6535	.5658	.5658	.9717	1.5089	1.1469	.9374
7	.5601	.5658	.5658	1.3765	1.6766	1.5089	1.4575
8	.4668	.5658	.5658	1.0526	1.6804	1.2289	1.2803
9	.4668	.4715	.5658	.8097	1.307	.9831	1.0279
10	.4715	.4715	.4715	.3734	.3772	.5658	.4668
11	1.2431	.8907	.7287	.4668	.2829	.5601	.4668
12	1.4746	1.4575	1.3765	.4668	.3772	.5658	.5601
13	1.3603	1.3765	1.2146	.4668	.3772	.5601	.4668
14	1.0669	1.1336	1.0526	.4668	.3772	.4715	.4715
15	1.0402	1.0526	.9717	.4668	.4715	.4715	.3772
16	1.0402	.7287	.8907	.4668	.4715	.4715	.4715
17	.9717	1.0526	.8097	.4191	.5658	.4715	.4715
18	.8802	.8907	.6478	.5601	.5658	.6602	.4715
19	.4715	.4715	.5658	.6535	.5658	.6602	.5658
20	.5658	.5658	.5658	.6535	.6602	.5658	.5658
21	.5658	.5658	.5658	.6535	.4715	.5658	.6602
22	.5658	.5658	.4715	.5601	.5658	.5658	.4715
23	.5658	.4715	.4715	.5601	.5658	.4715	.5658
24	.5601	.4715	.4715	.4858	.6535	.5944	.4934
Max	1.4746	1.4575	1.3765	1.3765	1.6804	1.5089	1.4575
Min	.4668	.4715	.4715	.3734	.2829	.4715	.3772
Avg	.7309	.6955	.6624	.6017	.7150	.6737	.6295

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094007 / 33/11 KV PIMPALNER

Feeder No / Name : 205 / 11 KV PIMPALNER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1203	1.0164	.9335	1.1203	1.1203	1.0974	1.1765
2	1.0269	1.0164	.9335	1.1203	1.0269	1.0974	1.1888
3	1.0269	1.0164	.9335	1.1203	1.0269	1.0974	1.1888
4	1.0269	1.0164	1.0269	1.1203	1.0269	1.0974	1.1888
5	1.1203	1.1203	1.1203	1.1203	1.2136	1.1088	1.2803
6	1.4003	1.307	1.2136	1.307	1.4003	1.307	1.4784
7	1.4003	1.4003	1.307	1.4003	1.4003	1.386	1.4784
8	1.4003	1.386	1.307	1.307	1.307	1.2936	1.2803
9	1.307	1.267	1.307	1.307	1.307	1.1888	1.1765
10	1.2403	1.086	1.3575	1.307	1.2269	1.2269	1.3575
11	1.3432	1.267	1.267	1.2136	1.4003	1.2803	1.267
12	1.267	.8145	1.267	1.307	1.3717	1.3717	1.267
13	1.2536	1.267	1.267	1.4003	1.2803		1.3575
14	1.2403	1.267	1.1765	1.4003	1.2803	1.6289	1.2803
15	1.267	1.1765	1.1765	1.307	1.3717	1.5546	1.2803
16	1.267	1.267	1.267	1.307	1.3717	1.5223	1.2803
17	1.267	1.267	1.1765	1.307	1.3575	1.4327	1.2803
18	1.1765	1.267	1.086	1.2136	1.1765	1.3717	1.1888
19	1.1517	1.1765	1.267	1.307	1.1393	1.3003	1.3717
20	1.3432	1.267	1.2936	1.4937	1.3575	1.4327	1.448
21	1.3432	1.267	1.2936	1.4003	1.3432	1.3432	1.4327
22	1.267	1.1765	1.2936	1.2574	1.3432	1.3432	1.5061
23	1.1765	1.1088	1.2136	1.307	1.2536	1.2536	1.3289
24	1.1203	1.1088	1.1203	1.1203	1.1305	1.0974	1.2536
Max	1.4003	1.4003	1.3575	1.4937	1.4003	1.6289	1.5061
Min	1.0269	.8145	.9335	1.1203	1.0269	1.0974	1.1765
Avg	1.2314	1.1804	1.1919	1.2738	1.2597	1.2971	1.3057

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094007 / 33/11 KV PIMPALNER

Feeder No / Name : 206 / 11 KV SUKAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4668	.4715	.4668	.4668	.4668	.4668	.5544
2	.4668	.4715	.4668	.4668	.4191	.4668	.5544
3	.4668	.4715	.4668	.4668	.4191	.4668	.5544
4	.4668	.4715	.4668	.4668	.4191	.4715	.5601
5	.5601	.6602	.5601	.5601	.5868	.5658	.5601
6	.7468	.9431	.9335	.9335	.9335	.9431	.8402
7	.9335	.9431	.9335	.8402	.9431	.9335	.8488
8	.7468	.7545	.7545	.7468	.8402	.7468	.8402
9	.5601	.6468	.6535	.5601	.6535	.5601	.6535
10	.5487	.543	.2772	.5601	.6268	.443	.5601
11	.462	.362	.2715	.3734	.5487	.462	.5601
12	.4572	.4525	.362	.4668	.5544	.462	.5601
13	.462	.4525	.362	.3734	.5544	.4572	.4668
14	.4477	.543	.4525	.4668	.5544	.5544	.5601
15	.4572	.543	.4049	.5601	.462	.5544	.5601
16	.462	.543	.543	.5601	.5544	.6401	.5601
17	.5487	.543	.543	.5601	.543	.543	.6535
18	.5544	.6335	.6335	.6535	.6401	.6201	.6535
19	.6401	.6335	.8145	.7468	.724	.6335	.6535
20	.7392	.724	.724	.7468	.7392	.6602	.7468
21	.6535	.543	.543	.6535	.6468	.6401	.6535
22	.6535	.543	.5544	.5601	.6535	.6468	.5601
23	.5601	.462	.5601	.5601	.5601	.5544	.5601
24	.4668		.4668	.4668	.4668	.4668	.5544
Max	.9335	.9431	.9335	.9335	.9431	.9431	.8488
Min	.4477	.362	.2715	.3734	.4191	.443	.4668
Avg	.5637	.5806	.5506	.5757	.6046	.5816	.6179

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094027 / 33/11 KV KUDASHI

Feeder No / Name : 201 / 11 KV KUDASHI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4725	.176	.1646				.1783
2	.4744	.16	.192				.1783
3	.4268	.1619	.1974				.1783
4	.4428	.176	.2256				.2286
5	.4096	.2372	.2623				.2896
6	.3441	.3052	.2623				.3749
7				.4862	.5935		
8				.4961	.5506	.3239	
9				.4694	.4858	.3563	
10				.3572		.3277	
11				.3113		.3052	
14	.3549	.4012	.4321				.431
15	.4001	.4321	.4218				.4973
16	.4481	.4938	.4111				.5243
17	.4858	.4531	.4115				.4858
18	.4321	.3749	.333				.4481
19				.5213		.3681	
20				.4001		.3418	
21				.3429		.2892	
22				.282		.2538	
23				.2397		.2172	
24	.5218				.2134		.2027
Max	.5218	.4938	.4321	.5213	.5935	.3681	.5243
Min	.3441	.16	.1646	.2397	.2134	.2172	.1783
Avg	.4344	.3065	.3012	.3906	.4608	.3092	.3348

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094027 / 33/11 KV KUDASHI

Feeder No / Name : 202 / 11 KV VARSA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7461	.3647	.3749				.2591
2	.6706	.3647	.4218				.2656
3	.7122	.4096	.5121				.3077
4	.6226	.4096	.5761				.3277
5	.6783	.4858	.6241				
6	.6104	.6762	.6718				
7				1.2689	1.0402		
8				1.2239	1.153	1.1022	
9				.9221	1.0395	1.0682	
10				.787		.8551	
11				.6443		.6554	
14		.3858					.78
15	.2949	1.1843	.5243				.8383
16	.8551	1.3923	1.2239				.9326
17	1.4243	1.2597	1.1603				1.0513
18	1.2548	.9602	.9488				1.1065
19	.8907			1.012			
20				.9393		.2934	
21				.8097		.5201	
22				.6882		.4344	
23				.6226		.362	
24	.763				.5426		.3048
Max	1.4243	1.3923	1.2239	1.2689	1.153	1.1022	1.1065
Min	.2949	.3647	.3749	.6226	.5426	.2934	.2591
Avg	.7936	.7175	.7038	.8918	.9438	.6614	.6174

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094027 / 33/11 KV KUDASHI

Feeder No / Name : 203 / 11 KV MALGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2949		
2				.2622		
3				.2683		
4				.2915		
5				.3239		
6				.4748		
7	.6443		.3429			
8	.6783	.7969	.3246			
9	.5426	.5935	.3086			.5182
10	.5316	.4923	.2656			.5135
11	.2601	.3185	.421			.3906
14				.4508	.5765	
15				.5144	.6706	
16				.5426	.7122	
17				.5935	.6783	
18				.6104		
19	.7202	.6874	.8078			.7042
20	.506	.4938	.5693			.3353
21	.4744	.423	.4687			.4999
22	.4161	.3525	.4218			.3688
23	.3441	.2606	.3563			.3315
24		.3121	.2195			
Max	.7202	.7969	.8078	.6104	.7122	.7042
Min	.2601	.2606	.2195	.2622	.5765	.3315
Avg	.5118	.4731	.4096	.4207	.6594	.4578

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094027 / 33/11 KV KUDASHI

Feeder No / Name : 204 / 11 KV DANGSHIRWDE

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.286
2				.2709
3				.2751
4				.3048
5				.3795
6				.1638
7	1.3056	1.1568	.9442	
8	1.2289	1.2929	1.0242	
9	.9831	1.0486	.8962	
10	.7287	.7002	.8002	
11	.583	.4843	.5792	
14				.8802
15				1.0402
16				1.065
17				.9614
18				.8288
19	.9374	.7362	.9389	
20	.7282	.6405	.6716	
21	.5575	.5624	.4801	
22	.5053	.4167	.4089	
23	.4572	.3395	.3715	
24		.3593	.2462	.3048
Max	1.3056	1.2929	1.0242	1.065
Min	.4572	.3395	.2462	.1638
Avg	.8015	.7034	.6692	.5634

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094028 / 33/11 KV CHHAIL

Feeder No / Name : 201 / 11 KV DIGHAVE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2984	.2778	.25		.0762	.0076	.0724
2	.2984	.3361	.2812		.0762	.0076	.0724
3	.3353	.3241	.2984		.0953	.0076	.0914
4	.5365	.6882	.3688		.1143	.0076	.0914
5	.8383	.9231	.6036		.1334	.0114	.1097
6	1.1736	1.1822	1.2742		.0953	.0076	.112
7	1.6766	1.5912	1.8107				
8	1.8233	1.8233	1.7238				
9	1.3108	1.7072	1.4083				
11				1.1797	1.0688	1.0688	.1448
12				1.5912	1.5912	1.6057	
13				1.5249	1.278	1.4091	
14				1.4918	1.1012	1.2308	
15				1.4586	.9804	.9686	.5213
16				1.3927	1.012		.5944
17				1.2308	.9568		.6097
18				1.1203	.8128		.6097
19	.1132	.0377	.1132	.0762	.0754		.0762
20	.1132	.0754	.1132	.0953	.0076		.0953
21	.1132	.0377	.1132	.0953	.0076		
22		.0377	.0943	.0953	.0076		
23	.0754	.0377	.0754	.0953	.0076		
24	.2321	.1932	.25		.0953	.0076	.1086
Max	1.8233	1.8233	1.8107	1.5912	1.5912	1.6057	.6097
Min	.0754	.0377	.0754	.0762	.0076	.0076	.0724
Avg	.6385	.6182	.5852	.8806	.4797	.5283	.2364

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094028 / 33/11 KV CHHAIL

Feeder No / Name : 202 / 11 KV VITAI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.1509	.0754		.3658	.2934	.2538
2	.0762	.0754	.0754		.3658	.2934	.2641
3	.0762	.0754	.0754		.3658	.2934	.2972
4	.1524	.1509	.0076		.4428	.3658	.2972
5	.1524	.1886	.0076		.8223	.5556	.4161
6	.0762	.1886	.0076		1.0364	1.012	.6097
7	.0762	.0152	.0076		1.2955	1.3443	.9259
8	.0762	.0076	.0076		1.4083	1.2018	1.1111
9	.0076	.0076			1.0753	1.0753	.9259
10	.0076	.0076			.0076	.0747	.0747
11	.1143	.6874		.0754	.0076	.0747	.0747
12	1.3927	1.1523		.0762	.0076	.0747	
13	1.247	.9488		.0762	.0076	.0076	.0762
14	1.1142	.8124		.0762	.0076	.0076	.0762
15	.852	.8223		.0762	.0076		.0762
16	.4902	1.0753	.8488	.0762	.0754	.0754	.0762
17	.463	.9877	.7773	.0762	.0754		.0762
18	.4268	.6622	.7042	.0762	.0754		.0762
19	.1867	.0754	.1867	.1524	.0754		.0762
20	.1867	.2241	.1867	.1524	.0754		.0762
21	.1867	.2241	.1886	.0762	.0754		
22	.1509	.1509	.1509	.0762	.0754		
23	.1509	.0754	.1509	.0762	.0754		
24	.0762	.1509	.0754		.3086	.2934	.2256
Max	1.3927	1.1523	.8488	.1524	1.4083	1.3443	1.1111
Min	.0076	.0076	.0076	.0754	.0076	.0076	.0747
Avg	.3256	.3715	.2079	.0879	.3390	.4402	.3043

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094028 / 33/11 KV CHHAIL

Feeder No / Name : 203 / 11 KV VITAI-DIGHAVE

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 /
OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3326	.3475	.3292		.3658	.3658	.3658
2	.3326	.3475	.3292		.3658	.3658	.3658
3	.3734	.3841	.3772		.4066	.3881	.3696
4	.4481	.499	.4904		.4435	.4066	.5544
5	.7545	.7207	.679		.7468	.8676	.924
6	1.0288	.8962	1.0082		1.094	1.1203	.9431
7	.7545	.7421	.7545		.7545	.8299	.8589
8	.6722	.5975	.6653		.5975	.5975	.6283
9	.543	.5304			.5544	.5121	.5544
10	.4298	.4938	.5548		.4854	.4298	.4854
11	.362	.4119		.4075	.4252	.3898	.3506
12	.3582	.3544		.3898	.4298	.394	.3814
13	.3582	.3898		.3898	.3982	.439	.3506
14	.3898	.4252		.394	.3982	.394	.3544
15	.3814	.4656		.394	.394	.4508	.3544
16	.3988	.3898	.2932	.4252	.4801		.3814
17	.4239	.4409	.373	.4252	.4508		.4207
18	.4733	.4854	.5256	.4557	.4854		.4115
19	.7164	.7316	.7537	.7316	.6516		.5792
20	.7522	.8048	.7421	.8871	.8501		.8501
21	.6697	.543	.6697	.5853	.5731		
22	.6154	.3982	.6268	.4344	.4656		
23	.4755	.3292	.4755	.362	.394		
24	.3696	.3475	.3292		.3658	.3658	.362
Max	1.0288	.8962	1.0082	.8871	1.094	1.1203	.9431
Min	.3326	.3292	.2932	.362	.3658	.3658	.3506
Avg	.5172	.5032	.5543	.4832	.5240	.5198	.5165

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094028 / 33/11 KV CHHAIL

Feeder No / Name : 205 / 11 KV KALGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.2054	.1886		.2439	.3048	.2317
2	.1867	.2054	.1867		.2743	.3048	.2317
3	.2263	.2241	.2263		.3125	.3479	.2675
4	.2641	.3018	.2641		.3437	.3479	.3048
5	.3395	.3584	.3395		.6249	.5182	.3353
6	.3429	.415	.3395		.7811	.8619	.6478
7					.9717	1.1797	.8421
8					.8097	1.2308	.8097
9					.4801	.8539	.3239
11	.5761	.4999					
12	.9231	.8322					
13	.9878	.9069					
14	.8951	.6562					
15	.7701	.6249					
16	.7865	.6874	.7116				
17	.7116	.7407	.6327				
18	.6401	.602	.5053				
19	.3439	.2614	.3582	.2263	.2957		.3326
20	.3801	.2957	.3841	.2641	.3696		.3734
21	.3142	.2561	.3326	.3018	.2896		
22	.3142	.2218	.2957	.2896	.2561		
23	.2614	.1848	.2801	.2172	.2561		
24	.2075	.2054	.1867		.2469		.2317
Max	.9878	.9069	.7116	.3018	.9717	1.2308	.8421
Min	.1867	.1848	.1867	.2172	.2439	.3048	.2317
Avg	.4829	.4343	.3488	.2598	.4371	.6611	.4110

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094028 / 33/11 KV CHHAIL

Feeder No / Name : 206 / 11 KV PRATAPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0987	.092	.084		.0953	.1109	.0095
2	.0987	.092	.1067		.0953	.1109	.0953
3	.1143	.1488	.1372		.1143	.1109	.0934
4	.1486	.2029	.1677		.1334	.112	.0892
5	.2846	.333	.1829		.1524	.197	.1524
6	.664	.571	.5376		.1905	.2075	.1905
7	.9602	.7748	.9014				
8	1.012	.8855	.933				
9	.7907	.8539	.6859				
11				.571	.4725	.4725	.1783
12				.8124	.6642	.6019	.3144
13				.6249	.5639	.4904	.282
14				.5182	.4607	.4054	.2256
15				.5182	.3909	.3858	.2256
16				.6097	.4401		.2286
17				.4877	.443		.2
18				.4054	.2976		.1974
19	.2195	.1478	.1848	.1097	.1478		.1143
20	.1829	.1663	.1646	.168	.1478		.1886
21	.1663	.1267	.128	.1494	.1478		
22	.1294	.2835	.1267	.1294	.1294		
23	.1097	.0732	.1097	.0924	.1097		
24	.0987	.0907	.084		.0934	.1109	.1097
Max	1.012	.8855	.933	.8124	.6642	.6019	.3144
Min	.0987	.0732	.084	.0924	.0934	.1109	.0095
Avg	.3386	.3228	.3023	.3997	.2645	.2763	.1703

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094039 / 33/11 KV MHASADI

Feeder No / Name : 201 / 11 KV VASAMAR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7956	.5801	.5868	.0754	.0754	.0943	
2	.779	.6464	.5868	.0754	.0754	.0754	
3	.8619	.6464	.6371	.0754	.0754	.0754	
4	.9614	.779	.7377	.0754	.0943	.0943	
5	1.0608	.9779	.8886	.0943	.0943	.1132	
6	1.3923	1.2266	1.3245	.132	.132	.132	
7	1.5249	1.3094	1.3748	.1132	.132	.1132	
8	1.5415	1.4089	1.358	.1132	.1132	.1132	
9	1.326	1.3077	1.2574	.1132	.0754		.1132
10	.0566	.0566	.0566	.0754	.0566		.0943
11	.0566	.0566	.0566	1.094			
12	.0566	.0566	.0566	1.3094	1.291		
13	.0566	.0566	.0566	1.3094	1.4754		.3338
14	.0566	.0566	.0754	1.2929	1.4083		.3755
15	.0566	.0566	.0566	1.1437	1.3748		.3338
16	.0943	.0566	.0754	1.1105	1.291		.3199
17	.0566	.0566	.0566	1.1768	1.3245		.2503
18	.0566	.0566	.0566	1.094	.8215		.2782
19	.0943	.1132	.0754	.0754	.0566		.0566
20	.1132	.0943	.0943	.1132	.132		.1132
21	.1132	.0943	.0943	.0754	.0943		.0943
22	.0754	.0943	.0943	.0754	.0754		.0754
23	.0754	.0943	.0754	.0754	.0754		.0754
24	.6962	.5801	.5967	.0754	.0754	.0754	
Max	1.5415	1.4089	1.3748	1.3094	1.4754	.132	.3755
Min	.0566	.0566	.0566	.0754	.0566	.0754	.0566
Avg	.4983	.4359	.4304	.4568	.4530	.0985	.1934

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094039 / 33/11 KV MHASADI

Feeder No / Name : 202 / 11 KV MHASADI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4031	.4656	.4477	.4887	.4477	.5068	
2	.4031	.4477	.4477	.4706	.4119	.4887	
3	.4207	.4477	.5014	.4706	.4656	.4887	
4	.4908	.5552	.5552	.5249	.5194	.5249	
5	.631	.8059	.6447	.5792	.6626	.5792	
6	.929	1.0208	1.0387	1.0679	.9134	.9593	
7	.8939	.8775	.8954	.8326	.8775	.8688	
8	.7362	.7164	.7343	.7602	.6984	.7059	
9	.6661	.591	.6984	.6485	.5973		.6516
10	.5434	.5731	.6268	.5434	.6154		.6335
11	.4733	.5014	.4835	.4733	.5068		.4344
12	.4382	.4477	.4119	.4733	.3982		.3439
13	.4733	.4477	.394	.4382	.4344		
14	.4382	.4477	.3582	.4382	.4706		
15	.4382	.4477	.394	.4207	.4706		.7059
16	.5083		.5373	.5434	.5068		
17	.5083		.5373	.4908	.5249		.6878
18	.5609	.5194	.5731	.5194	.4706		.7421
19	.7537	.8417	.6984	.6626	.7421		.7421
20	.929	.8954	.8954	.8417	.8869		.9231
21	.6984	.6626	.6984	.6268	.6697		.6697
22	.591	.5552	.591	.5552	.6154		.6154
23	.5194	.5194	.5194	.4835	.5249		.6154
24	.4207	.4477	.4656	.4887	.4119	.5249	
Max	.929	1.0208	1.0387	1.0679	.9134	.9593	.9231
Min	.4031	.4477	.3582	.4207	.3982	.4887	.3439
Avg	.5778	.6016	.5895	.5768	.5768	.6275	.6471

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094039 / 33/11 KV MHASADI

Feeder No / Name : 203 / 11 KV KAKANI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4382	.4382		.8002	.6668	.7621	
2	.4382	.4763		.8002	.6668	.8002	
3	.4763	.5144		.7811	.8573	.8002	
4	.5335	.5525	.5335	.8192	.9717	.8192	
5	.5906	.6859	.6097	.8192	1.0479	.8573	
6				1.1812	1.2193	1.1622	
7	.5144		.6859	1.5432	1.7528	1.7147	
8	.4763	.5906	.5335	1.5051	1.7909	1.7337	
9	.4954	.4763	.4763	1.4098	1.2955		.3048
10	.3429	.362	.362	.3048	.3429		.0762
11	1.2384	1.5813	1.1431	.2667	.2858		.5525
12	1.5432	1.7147	1.7337	.2286	.2286		.2286
13	1.5813	1.848	1.8099	.2477	.2477		.2477
14	1.6004	1.6766	1.6766	.2477	.2477		.2858
15	1.6575	1.0098	1.6194	.2477	.2286		.2667
16	1.6194		1.3336	.2667	.2858		.2858
17	1.5242		1.3717	.3048	.2667		.2858
18	1.4098	1.9243	1.3908	.362	.4191		.4191
19	.4382	.4954	.4001	.4763	.5144		.5716
20	.6668	.6668	.6668		.6287		.724
21	.5525	.5525	.5716	.5335	.5525		.4954
22	.4954		.5144	.4382	.4763		.4763
23	.4382		.4382	.4382	.4191		
24	.4191	.4382		.7811	.6287	.743	
Max	1.6575	1.9243	1.8099	1.5432	1.7909	1.7337	.724
Min	.3429	.362	.362	.2286	.2286	.743	.0762
Avg	.8474	.8891	.9406	.6436	.6684	1.0436	.3729

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094039 / 33/11 KV MHASADI

Feeder No / Name : 204 / 11 KV DHAMNAR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0297	.0446	.044	.4161	.4607	.4755	
2	.0297	.0446	.0446	.4012	.431	.4904	
3	.0446	.0446	.0446	.4012	.431	.5201	
4	.0446	.0594	.0446	.431	.535	.6687	
5	.0446	.0743	.0594	.535	.7282	.7579	
6	.0743	.0743	.0743	.7579	.9957	1.0997	
7	.0594	.0446	.0594	1.174	1.3523	1.3672	
8	.0446	.0446	.0446	1.07	1.174		
9	.0446	.0293	.0297	.7876	.9065		
10	.0297	.0293	.0297	.0297	.0297		
11	.9957	.9976	.9362	.0297	.0297		.535
12	1.4415	1.0562	1.2483		.0297		.0297
13	1.2929	1.1589	1.0848	.0297	.0297		.0297
14	.9659	.9242	.9214	.0297	.0297		.0297
15	.9065	.8949	.8619	.0297	.0297		.0297
16	.9214	.9536	.8322	.0297	.0297		.0297
17	.9659	.9536	.8768	.0297	.0297		.0297
18	.8768	.8802	.8322	.0297	.0297		.0297
19	.0297	.044	.0297	.0446	.0446		.0297
20	.0594	.0594	.0594	.0743	.0743		.0594
21	.0446	.0446	.0446	.0594	.0594		.0446
22	.0446	.0446	.0297	.0446	.0297		.0892
23	.0446	.0446	.0297	.0446	.0297		.0892
24	.0446	.0446	.0446	.4012	.4607	.4607	
Max	1.4415	1.1589	1.2483	1.174	1.3523	1.3672	.535
Min	.0297	.0293	.0297	.0297	.0297	.4607	.0297
Avg	.3783	.3579	.3461	.2991	.3325	.7300	.0812

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094039 / 33/11 KV MHASADI

Feeder No / Name : 205 / 11 KV CHINCHKHEDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6668	.724	.724	.3239	.3239	.3239	
2	.7811	.724	.724	.3239	.3239	.3239	
3	.8192	.8192	.7811	.3048	.3048	.3048	
4	1.0288	.9335	.9145	.3429	.3429	.3429	
5	1.5623	1.4289	1.2193	.362	.4001	.362	
6	1.9433	1.7718	1.9243	.4763	.4763	.5144	
7	2.1338	2.1338	2.0195	.3239	.3429	.4191	
8	1.9243	2.0005	1.8671	.2858	.2858	.3239	
9	1.1622	1.8099	1.5623	.2667	.2477		.362
10	.1334	.1524	.1524	.3239	.2858		.2858
11	.1524	.1524	.1334	1.848	1.2765		.6668
12	.1334	.1524	.1715	2.21	2.0005		
13	.1524	.1905	.1905	1.8861	2.1338		
14	.1524	.1715	.1905	1.7909	1.848		
15	.1524	.2096	.1905	1.7337	1.6956		.8002
16	.1715	.2096	.2096	1.7718	1.7718		.9907
17	.1524	.1905	.2096	1.6956	1.7337		.9335
18	.1715	.1143	.2286	.8573	1.5623		.8954
19	.362	.3429	.4382	.4763	.4191		.4763
20	.4001	.4001	.4001	.5144	.4763		.5144
21	.4001	.4001	.4191	.4954	.4954		.5144
22	.362	.3429	.4572	.4382	.4572		.5144
23	.3239	.2858	.4001	.3239	.4191		.4763
24	.6097	.7049	.743	.3239	.3239	.3429	
Max	2.1338	2.1338	2.0195	2.21	2.1338	.5144	.9907
Min	.1334	.1143	.1334	.2667	.2477	.3048	.2858
Avg	.6605	.6819	.6779	.8208	.8311	.3620	.6192

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094048 / 33/11 KV KASARE

Feeder No / Name : 201 / 11 KV MALPUR GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4438	.4676	.3709	.3823	.3738	.464	.4806
2	.4384	.4691	.4033	.3823	.379	.4691	.4404
3	.4758	.5463	.4506	.4439	.396	.5463	.4547
4	.5948	.6102		.5275	.6148	.6413	
5	.7507	.7081	.7452	.6682	.7394	.7377	.7813
6	.8925	.829	.8936	.8441	.9069	.8807	.9501
7	.7981	.7538	.7298	.7103	.7538	.8102	.7645
8	.6255	.6769	.6235	.6331	.6221	.6443	.6451
9	.5545	.6554	.6226	.4588	.6001	.5256	.5912
10	.495	.5759	.5627	.4192	.4927	.471	.5292
11	.4315	.4349	.4913	.3973	.4083	.4973	.4681
12	.4101	.4324	.3517	.3416	.4096	.4496	.4353
13	.3348		.3509		.4029		.4433
14	.3725	.4106	.3713	.385	.4177		.4738
15	.4097		.386	.4012	.4353		.475
16	.4412	.3193	.386	.4294	.4642	.5014	.4727
17	.4767	.4705	.3869	.4584	.4877		.4829
18	.5396	.4731	.4572	.489	.5056	.6554	.5054
19	.6851	.7169	.7019	.6635	.7579	.7478	.8112
20	.737	.6603	.7737	.7656	.834		.7905
21	.6695	.5972	.556	.6363	.6357		.6668
22	.5322	.5087	.4748	.5274	.5597		.6155
23	.4912		.4344	.4758	.4938		
24	.4384	.4812	.407	.3869	.4188	.511	.5058
Max	.8925	.829	.8936	.8441	.9069	.8807	.9501
Min	.3348	.3193	.3509	.3416	.3738	.4496	.4353
Avg	.5433	.5618	.5188	.5142	.5462	.5970	.5811

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094048 / 33/11 KV KASARE

Feeder No / Name : 202 / 11 KV NAWADNE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0568	.0326	.0379	1.2163	1.2192	1.2849	1.0267
2	.0567	.0325	.0378	1.2309	1.2496	1.2894	1.0427
3	.0567	.0325	.5118	1.2283	1.2352	1.2894	1.0779
4	.0757	.0325		1.3232	1.2513	1.3911	
5	.0757	.0326	.0379	1.4947	1.3184	1.4609	1.2018
6	.0757	.0325	.0379	1.9406	1.3482	1.681	1.2904
7				2.0223	1.7737	1.7287	1.7263
8				2.0223	1.7327	1.8829	1.7243
9				1.6545	1.6644	1.7897	1.5756
11	1.7469	1.893	1.7144				
12	2.0789	2.2055	1.8952				
13	1.9319		2.0529				
14		2.0082	1.9544				
15	.6002		1.6975				
16	.5879	1.8785	1.6127				
17	1.8288	1.8031	1.7864				
18	1.857	1.7085	1.7864				
19	.0163	.0378	.034	.0378	.0163	.0377	.0352
20	.0325	.0379	.0357	.0757	.0326		.0526
21	.0325	.0378	.0355	.0757	.0325		.0355
22	.0326	.0376	.0357	.0751	.0325		.0351
23	.0326		.0357	.0378	.0325		
24	.0568	.0326	.0375	1.243	1.2684	1.2849	.9603
Max	2.0789	2.2055	2.0529	2.0223	1.7737	1.8829	1.7263
Min	.0163	.0325	.034	.0378	.0163	.0377	.0351
Avg	.5912	.6986	.8093	1.0452	.9472	1.3746	.9065

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094048 / 33/11 KV KASARE

Feeder No / Name : 203 / 11 KV GANESHPUR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5521	.6832	.7245	.0528	.0718	.0532	.0508
2	.644	.6807	.8401	.0528	.0735	.0539	.0521
3	.7318	.723	1.0551	.0528	.0919	.0538	.0525
4	.7691	.8021		.0533	.0919	.055	
5	.982	.8519	1.2998	.0533	.1103	.0553	.0718
6	1.2409	1.6309	1.3849	.0528	.1109	.0554	.0731
7	1.8564	1.8432	1.7455				
8	1.8656	1.8817	1.6933				
9	1.5644	1.0837	1.3992				
11				1.2576	1.3894	1.6762	1.0602
12				2.1299	2.0069	1.9273	1.5146
13					1.8005		1.7747
14				1.7227	1.5105		1.3683
15					1.3061		1.1782
16				1.5432	1.3011	1.1907	1.1843
17					1.2082		1.1294
18				1.2269	1.0336	.152	.9436
19	.0503	.0514	.0465	.0772	.0473	.0337	.0451
20	.0702	.0645	.0681	.092	.0824		.0493
21	.0689	.0675	.0682	.0926	.0808		.0683
22	.0684	.0694	.0695	.1064	.0665		
23	.0691		.0526	.0886	.0681		
24	.5521	.6226	.6409	.0528	.091	.0532	.0518
Max	1.8656	1.8817	1.7455	2.1299	2.0069	1.9273	1.7747
Min	.0503	.0514	.0465	.0528	.0473	.0337	.0451
Avg	.7390	.7897	.7920	.5122	.6271	.4466	.6275

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094048 / 33/11 KV KASARE

Feeder No / Name : 204 / 11 KV KASARE GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4037	.4047	.3541	.3913	.3701	.4215	.3874
2	.4033	.4051	.3878	.39	.3701	.4215	.4047
3	.4384	.4552	.4051	.4244	.4037	.4552	.4215
4	.4764	.5064		.4758	.4374	.5227	
5	.5251		.5396	.5444	.572	.5733	.5396
6	.6443	.6752	.6414	.6628	.6393	.6576	.6576
7	.6077	.6246	.5739	.6125	.5209	.5733	.5901
8	.5881	.5739	.5233	.4588	.471	.5058	.4721
9	.5383	.5408	.557	.471	.4037	.4552	.421
10	.5408	.507	.5098	.4705	.489	.4547	
11	.507	.4056	.4239	.4542	.4552	.4384	
12	.507	.4726	.4414	.3865	.4384	.4215	
13	.5239		.4244		.4552		.5426
14	.4901	.422	.4244	.4542	.4721		.5104
15	.4384		.4423		.4721		.4923
16	.489	.422	.4423	.4542	.5227	.5558	.5098
17	.4721	.5058	.4419		.4384		.5432
18	.5908	.5908	.5785	.5713	.607	.5558	.542
19	.5564	.6407	.5596	.6224	.6063	.6063	.6288
20	.6246	.5733	.6288	.6077	.6232		.0639
21	.5402	.5064	.5426	.5778	.5389		.5432
22	.5064	.4726	.5098	.4716	.5053		.5098
23	.4558		.4588	.4374	.4547		.4753
24	.4037	.422	.3878	.3909	.3701	.421	.4215
Max	.6443	.6752	.6414	.6628	.6393	.6576	.6576
Min	.4033	.4047	.3541	.3865	.3701	.421	.0639
Avg	.5113	.5063	.4869	.4919	.4849	.5025	.4838

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094048 / 33/11 KV KASARE

Feeder No / Name : 205 / 11 KV KOKALE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6421	.6891	.737	.0637	.0627	.0784	.0784
2	.6421	.7204	.784	.0637	.0626	.0784	.0784
3	.6734	.7204	.8467	.0637	.0627	.0784	.0784
4	.9083	.783		.0793	.0941	.0941	
5	1.0349	.8927	1.0662	.0956	.0941	.0941	.1098
6	1.2857	1.4408	1.1603	.0958	.0941	.1098	.1254
7	1.3517	1.66	1.223				
8	1.4146	1.6287	1.2544				
9	1.4739	1.2842	1.1289				
11				.9206	1.1774	1.0989	
12				1.2904	1.5542	1.3187	1.3061
13					1.3972		1.4688
14				1.2793	1.3187		1.3379
15					1.1931		1.2047
16				1.1902	1.1931	1.0349	1.1349
17					1.0675		
18				1.0192	1.0047	.6272	1.0194
19	.094	.1411	.0956	.0793	.0941	.0941	.9511
20	.1409	.1098	.0951	.0956	.1254		.1274
21	.1096	.0941	.0944	.0944	.1254		.1268
22	.094	.0941	.0796	.0944	.0941		.0956
23	.0783		.0796	.0784	.0941		.0951
24	.6452	.6891	.6899	.0634	.0629	.0941	.0784
Max	1.4739	1.66	1.2544	1.2904	1.5542	1.3187	1.4688
Min	.0783	.0941	.0796	.0634	.0626	.0784	.0784
Avg	.7059	.7820	.6668	.3922	.5486	.4001	.5539

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094048 / 33/11 KV KASARE

Feeder No / Name : 206 / 11 KV MALPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0472	.0309	.0309	.6371	.6586	.5857	.5879
2	.047	.0309	.0309	.6371	.6899	.6165	.5569
3	.0469	.0309	.0309	.7133	.7204	.6165	.5879
4	.0627	.0309		.7964	.7997	.709	
5	.0627	.0309	.0309	.9511	.9565	.8015	.6807
6	.047	.0309	.0309	1.0512	1.061	.9094	.758
7				1.2205	1.2215	1.0635	1.0635
8				1.2998	1.2201	1.1252	1.0314
9				1.0701	1.1533	1.0635	.9214
11	1.1125	1.021	1.1641				
12	1.4524	1.2376	1.3061				
13	1.4679		1.5768				
14	1.3906	1.1139	1.2711				
15	1.1011		1.2522				
16	1.1279	.9282	1.2105				
17	1.1011	.9592	1.0303				
18	1.0043	.8973	1.0145				
19	.031	.0309	.0319	.0314	.0617	.0616	.0634
20	.0618	.0309	.0319	.0627	.0617		.0639
21	.0618	.0309	.0317	.0629	.0771		.0796
22	.0618	.0309	.0319	.0629	.0617		
23	.0309		.032	.0315	.0617		
24	.0314	.0309	.0309	.6371	.6586	.5857	.5388
Max	1.4679	1.2376	1.5768	1.2998	1.2215	1.1252	1.0635
Min	.0309	.0309	.0309	.0314	.0617	.0616	.0634
Avg	.5175	.3822	.5353	.6177	.6309	.7398	.5778

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094049 / 33/11 KV BALHANE

Feeder No / Name : 201 / 11 KV SHEWAGE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3315	.3584	.4706	.4854	.421	.5658
2	.3772	.3201	.3395	.4525	.4854	.4424	.5281
3	.3772	.3681	.3772	.4477	.4854	.4801	.5281
4	.3961	.3978	.3772	.4961	.4854	.502	.5658
5	.5281	.426	.4904	.5316	.5975	.5344	.7356
6	.9431	.5281	.8488	.9745	1.1523	.7773	1.0374
7	.6602	.6241	.679	1.1104	1.3998	1.2125	1.2851
8	.5281	.4321	.5093	1.086	1.1946	1.1717	1.1222
9	.4527	.3978	.3206	.905	1.0425	.7935	1.0608
10	.2915	.2641	.3395	.2801	.3149	.3018	.3361
11	.6316	.7842	.8954	.2641	.2881	.3018	.3361
12	.6882	1.2178	1.1163	.1698	.285	.3395	.2801
13	.9602	1.0985	1.0277	.1509	.2652	.2987	.2801
14	.8482	.8869	.8505	.2452	.2818	.2987	.2427
15	.7202	.8779	.7796	.2452	.2721	.2987	.2801
16	.7362	.8316	.9492	.2641	.2785	.3174	.2801
17	.7202	.8688	.905	.3206	.2561	.3547	.3734
18	.7202	.7282	.7421	.3772	.3239	.4481	.3772
19	.4973	.5658	.5093	.5041	.3361	.547	.4904
20	.4973	.6602	.6602	.7167	.3605	.5847	.6602
21	.503	.547	.547	.547	.4807	.5281	.5847
22	.3315	.4904	.5281	.4904	.3812	.5093	.5601
23	.3277	.3961	.5093	.415	.3812	.4338	.4715
24	.3772	.3315	.3584	.4706	.4668	.4161	.547
Max	.9602	1.2178	1.1163	1.1104	1.3998	1.2125	1.2851
Min	.2915	.2641	.3206	.1509	.2561	.2987	.2427
Avg	.5621	.5989	.6258	.4973	.5125	.5131	.5637

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094049 / 33/11 KV BALHANE

Feeder No / Name : 202 / 11 KV PARGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.1492	.2172	.1267	.0724	.0972	.1267
2	.181	.16	.2172	.1267	.0724	.1134	.1086
3	.181	.16	.2353	.1086	.0905	.1296	.1086
4	.1991	.1865	.2534	.1629	.1086	.128	.1267
5	.2896	.1989	.3439	.1991	.181	.1296	.1991
6	.5249	.4694	.6516	.3801	.2353	.144	.362
7	.543	.547	.5792	.2715	.181	.1638	.2534
8	.4887	.4001	.5068	.181	.1086	.1296	.1629
9	.4163	.3201	.362	.1086	.0724	.2321	.0905
10	.0671	.0724	.0724	.0724	.048	.0543	.0724
11	.0497	.0543	.0724	.543	.3812	.5611	.5068
12	.0497	.0543	.0724	.6878	.407	.4887	.543
13	.0497	.0724	.0724	.4706	.3978	.362	.4344
14	.0663		.0724	.3982	.3077	.3801	.362
15	.0663	.1086	.0724	.3258	.2984	.3801	.362
16	.0663	.0905	.0724	.3077	.3277		.362
17	.0497	.1086	.1086	.3258	.3401	.362	.4525
18	.0648	.1629	.1086	.3258	.3052	.2896	.4344
19	.096	.1991	.2172	.1448	.144	.181	.181
20	.1492	.2172	.2534	.2172	.1311	.1991	.2172
21	.1581	.1629	.181	.181	.128	.181	.181
22	.112	.1448	.1448	.1448	.112	.1448	.181
23	.128	.1267	.1448	.1267	.0983	.1448	.1448
24	.181	.1492	.2534	.1267	.1267	.0983	.1267
Max	.543	.547	.6516	.6878	.407	.5611	.543
Min	.0497	.0543	.0724	.0724	.048	.0543	.0724
Avg	.1816	.1876	.2202	.2526	.1948	.2215	.2542

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094049 / 33/11 KV BALHANE

Feeder No / Name : 203 / 11 KV SHEWDIPADA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0469	.0497	.0625	.0926	.108	.1296	.1543
2	.0469	.048	.0625	.0772	.108	.128	.1389
3	.0469	.048	.0625	.0772	.108	.1296	.1235
4	.0469	.0497	.0625	.0926	.1389	.1475	.1235
5	.0469	.048	.0625	.0926	.1852	.144	.1698
6	.0781	.0503	.0781	.3395	.3858	.3841	.3086
7	.0781	.048	.0937	.5556	.6173	.6226	.5864
8	.0469	.0497	.0469	.5864	.5556	.583	.5093
9	.0469	.0497	.0469	.463	.4321	.4801	.4167
10	.0497	.0469	.0463	.0469	.0497	.0463	.0463
11	.2984	.4374	.4321	.0463	.0509	.0463	.0463
12	.5087	.5468	.5401	.0463	.0509	.0463	.0463
13	.6133	.578	.5401	.0446	.0497	.0463	.0463
14	.5138	.4218	.4475	.0463	.0486	.0463	.0463
15	.4321	.3749	.463	.0463	.0497	.0463	.0463
16	.4161	.4687	.4012	.0463	.0492	.0463	.0463
17	.4144	.4531	.463	.0463	.0497	.0463	.0463
18	.2401	.3906	.3858	.0463	.0503	.0463	.0463
19	.0995	.0469	.0463	.0617	.048	.0617	.0463
20	.0829	.0781	.0772	.0617	.064	.0617	.0926
21	.0655	.0781	.0617	.0772	.0655	.0772	.0772
22	.0663	.0625	.0617	.0617	.064	.0772	.0617
23	.0509	.0625	.0617	.0617	.0829	.0617	.0617
24	.0469	.0497	.0625	.0762	.0617	.1006	.1543
Max	.6133	.578	.5401	.5864	.6173	.6226	.5864
Min	.0469	.0469	.0463	.0446	.048	.0463	.0463
Avg	.1826	.1890	.1945	.1330	.1447	.1502	.1434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094049 / 33/11 KV BALHANE

Feeder No / Name : 204 / 11 KV UMBHARTI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987		.3018	.4435	.4481	.3681	.3772
2	.2987	.2883	.3206	.4435	.4481	.3856	.3772
3	.3174	.3277	.3018	.4481	.4294	.3681	.3961
4	.3734	.3647	.3395	.4668	.4294	.3841	.3772
5	.4481	.4096	.415	.4668	.4668	.4001	.4527
6	.6348	.4409	.6979	.7655	.7468	.6154	.679
7	.5041	.4424	.4338	.9522	.9335	1.065	.8865
8	.3734	.3812	.3395	.9335	1.1203	.8962	.9431
9	.1867	.2486	.3584	.7468	.8589	.7611	.7167
10	.1326	.2075	.2241	.1132	.1823	.1886	.2241
11	.5182	.7733	.6535	.132	.128	.1509	.1867
12	.663	1.1128	1.0269	.1509	.1492	.1509	.1867
13		.8676	.9335	.1509	.1492	.1698	.1867
14	.6796	.7167	.7095	.0754		.2263	.2241
15		.679	.7095	.0566		.1886	.1867
16	.6133	.7545	.6535	.1886			.1867
17	.6241	.7922	.6161	.1886		.2263	.2241
18	.6464	.7167	.6348	.2263		.2641	.2614
19	.3201	.4338	.4481	.3961	.2721	.415	.3772
20	.3481	.5093	.5601	.547	.3201	.5093	.5228
21	.3772	.415	.4481	.415	.3361	.415	.4108
22	.3315	.3772	.3734	.3772	.3605	.3772	.3921
23	.3149	.3206	.3734	.3395	.3812	.3584	.3921
24	.3174	.2984	.3018	.4435	.4108	.3887	.415
Max	.6796	1.1128	1.0269	.9522	1.1203	1.065	.9431
Min	.1326	.2075	.2241	.0566	.128	.1509	.1867
Avg	.4237	.5164	.5073	.3945	.4511	.4032	.3993

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094049 / 33/11 KV BALHANE

Feeder No / Name : 205 / 11 KV VIRKHEL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2846	.2721	.3887	.3772	.3772	.3361	.3395
2	.2846	.3521	.3887	.3961	.3772	.3239	.3206
3	.3041	.39	.3563	.415	.3961	.3681	.3206
4	.3361	.3841	.3887	.4527	.4338	.4641	.3584
5	.3768	.4096	.502	.5601	.6224	.5079	.4715
6	.8192	.8122	.9555	.8299	.8676	.5344	.7922
7	1.1203	1.1934	.9962	.7545	.7733	.6316	.6413
8	.8592	.9116	.8322	.5281	.5847	.421	.547
9	.6097	.7127	.5716	.3961	.4338	.3521	.3961
10	.2267	.2829	.2829	.2427	.2486	.2641	.2452
11	.2204	.2452	.1886	.6308	.6401	.7335	.5144
12	.1989	.2033	.1867	.9568	.7042	.8215	.6516
13	.1658	.2033	.1867	.743	.7293	.612	.5944
14	.1658	.2378	.1886	.5068	.1509	.4275	.4489
15	.1823	.2452	.2614	.4858	.1638	.447	.4287
16	.2486	.2452	.2829	.4287	.1296	.4275	.4054
17	.2652	.3206	.2452	.5569	.0983	.434	.3572
18	.3481	.4715	.3206	.4755	.1989	.4512	.4344
19	.3812	.5228	.5228	.5415	.3201	.4527	.5847
20	.4001	.5093	.6161	.6036	.3681	.5093	.5658
21	.4409	.4338	.4715	.415	.4001	.4715	.5093
22	.3315	.3772	.4527	.4527	.3681	.3772	.4904
23	.2881	.3584	.415	.3961	.3277	.3584	.4715
24	.253	.2881	.4144	.3772	.3772		.3395
Max	1.1203	1.1934	.9962	.9568	.8676	.8215	.7922
Min	.1658	.2033	.1867	.2427	.0983	.2641	.2452
Avg	.3796	.4326	.434	.5218	.4205	.4664	.4679

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094049 / 33/11 KV BALHANE

Feeder No / Name : 401 / 33 KV INCOMMER I BALHANE

Feeder KV- 33 / INCOMING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6167	.5967	.6802	.8145	.8402	.7202	.9054
2	.6167	.6802	.6802	.8145	.8402	.7373	.8488
3	.6241	.763	.6802	.8688	.8962	.8453	.8488
4	.6722	.7956	.6802	.9231	.8962	.9945	.9054
5	.8356	.7682	.9231	1.0745	1.2323	1.0082	1.1883
6	1.6221	1.2963	1.6518	1.7541	1.9753	1.3426	1.8107
7	1.6804	1.8187	1.5655	1.8073	2.1262	1.7764	1.9004
8	1.3123	1.3117	1.2037	1.5746	1.7375	1.6032	1.6289
9	.9602	1.0688	.8145	1.2489	1.4815	1.1305	1.4266
10	.4973	.5093	.6161	.5041	.547	.5658	.5601
11	.8259	.9979	1.086	.8471	.9448	.9682	1.0082
12	.9156	1.3969	1.3032	1.1111	.9448	1.0562	1.0974
13	1.1437	1.2757	1.1694	.8471	.9945	.8345	.9979
14	1.0442	1.086	1.0317	.7042		.6219	.8316
15	.9448	1.0974	1.0099	.6859		.631	.823
16	.9945	1.0534	1.2226	.643	.7773	.6219	.8402
17	.9602	1.1403	1.1763	.823	.7956	.651	.8402
18	1.0562	1.1763	1.0642	.7579	.8551	.7613	.9522
19	.8453	1.0642	1.0082	1.0642	.6464	.9619	1.0642
20	.8745	1.1317	1.2883	1.3014	.7545	1.0751	1.2323
21	.8848	.4858	1.0082	.9619		.9619	1.0425
22		.8488	.9522	.9619	.7459	.8488	1.0534
23		.7356	.8962	.7922	.7042	.7922	.9522
24	.5693	.5967	.6802	.8145	.8402	.7202	.8488
Max	1.6804	1.8187	1.6518	1.8073	2.1262	1.7764	1.9004
Min	.4973	.4858	.6161	.5041	.547	.5658	.5601
Avg	.9317	.9873	1.0163	.9875	1.0274	.9263	1.0670

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094049 / 33/11 KV BALHANE

Feeder No / Name : 402 / 33 KV INCOMMER II BALHANE

Feeder KV- 33 / INCOMING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.543	.4801	.543	.6516	.6516	.5761	.6516
2	.543	.4801	.5973	.6516	.6516	.5898	.6516
3	.543	.5533	.5973	.6516	.6516	.639	.6516
4	.5973	.6104	.6516	.6984	.7059	.6241	.6516
5	.7602	.6613	.8145	.7602	.8688	.6802	.8145
6	1.2489	.9448	1.4118	1.5203	1.4118	1.17	1.3575
7	1.1403	1.0082	1.086	1.8461	1.7918	1.7764	1.7918
8	.9231	.8162	.8688	1.7918	1.8461	1.6032	1.6289
9	.6516	.5761	.7602	1.3432	1.4118	1.5261	1.2489
10	.2486	.3292	.3224	.2172	.2486	.2715	.3258
11	.8453	1.3169	1.182	.7059	.547	.7602	.7059
12	1.1523	1.7558	1.6832	.8688	.5967	.6516	.7602
13	1.4918	1.5912	1.5746	.6516	.5761	.543	.6516
14	1.2431	1.262	1.2894	.543	.4801	.6516	.6516
15	1.094	1.2071	1.2894	.4344	.4973	.5973	.5973
16	1.094	1.3717	1.1694	.543	.5087		.5973
17	1.0814	1.3717	1.2489	.543	.4801	.5973	.7059
18	.9122	1.3169	1.1946	.5973	.5281	.5973	.7059
19	.4801	.6722	.7059	.5973		.6516	.6161
20	.5596	.7602	.8688	.8145	.4801	.7602	.8145
21	.6104	.6516	.7059	.6516	.5281	.6516	.6516
22		.6161	.5973	.5973	.5407	.5973	.5973
23	.5087	.4887	.5973	.543	.5407	.543	.6036
24	.543	.4915	.5973	.6516	.5973	.5898	.7059
Max	1.4918	1.7558	1.6832	1.8461	1.8461	1.7764	1.7918
Min	.2486	.3292	.3224	.2172	.2486	.2715	.3258
Avg	.8180	.8889	.9315	.7864	.7452	.7673	.7974

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094009 / 33/11 KV DAHIWEL

Feeder No / Name : 201 / 11 KV PINJARZADI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.6706	.7545	.6859	.7716	.7202	.3658
7				.9145	1.2003	1.0288	.7621
8				.9907	1.0669	1.0288	
9				.8383	1.0288	.8535	.823
11	.9145	1.1317	1.2003				
12		1.1145	1.2003				
13	.9145	1.0631	1.0288				
14	.823	1.0288	.8383				
15	.823	.9602	.9145				
16	.7621	.9602	.8383				
18				.9145	1.0288	.7621	1.0059
19	.823	1.0631	1.0288	1.0288	.9602	.8535	.9145
20	.7926	.9945	.8573	1.0288	.9602	.7926	.8535
21	.7621	.8573	.8573	.9431	.8573	.7621	.7621
22	.7316	.823	.8573	.8573	.823	.6097	.5335
23	.7316	.7888	.823	.8573	.7888	.5335	.2286
24	.6097	.6706	.7545	.7716	.8573	.7202	.4877
Max	.9145	1.1317	1.2003	1.0288	1.2003	1.0288	1.0059
Min	.6097	.6706	.7545	.6859	.7716	.5335	.2286
Avg	.7748	.9328	.9195	.8937	.9403	.7877	.6737

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094009 / 33/11 KV DAHIWEL

Feeder No / Name : 202 / 11 KV MALANGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.6097	.9431	.1372	.1715	.12	.1219
2	.6097	.6097	.9431	.1372	.1715	.12	.1219
3	.6097	.6097	.9945	.1372	.1715	.12	
4	.6097	.6097	1.0288	.1372	.1715	.12	
5	.7621	.7621	1.406	.1372	.1715	.1372	.1219
6	1.2193	1.3717	1.5432	.1372	.1715	.1372	.1219
7	1.5242	1.6766	2.0919				
8	1.5242	1.5242	1.8176				
9	1.2955	1.0669	1.5432				
11				1.448	1.1145	1.3717	.9145
12				1.829	1.9719	1.7528	1.3717
13				1.6766	1.7147	1.3717	1.2193
14				1.5242	1.5432	1.2955	1.1431
15				1.7147	1.0631	1.2955	1.0669
16				1.8004	1.0974	1.2193	1.2193
17				1.6004	1.1145	1.3717	1.3717
18				1.5242	.9431	.9907	1.2193
19	.0762	.1372	.1372	.1029	.1372	.0762	.0914
20	.1219	.1372	.1715	.1715	.1372	.1219	.1219
21	.1219	.1372	.1715	.1715	.1372	.1219	.1219
22	.1219	.12	.0137	.1715	.12	.1219	.1219
23	.1219	.1029	.1372	.1715	.12	.1219	.1219
24	.5335	.4572	.7202	.1372	.1715	.12	.1219
Max	1.5242	1.6766	2.0919	1.829	1.9719	1.7528	1.3717
Min	.0762	.1029	.0137	.1029	.12	.0762	.0914
Avg	.6574	.6621	.9108	.7433	.6207	.6054	.5952

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094009 / 33/11 KV DAHIWEL

Feeder No / Name : 203 / 11 KVDAHIWEL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0457	.0457	.0686	.3772	.4287	.5144	.3963
2	.0457	.0457	.0514	.3772	.4287	.5144	.3963
3	.0457	.0457	.0514	.3772	.4287	.7202	.3963
4	.0457	.061	.0686	.3772	.4287	.7202	.3963
5	.0457	.061	.0686	.4287	.5144	.9259	.4268
6	.0457	.0457	.0686	.7716	.9431	1.0288	.6097
7				1.0669	1.0669	1.5432	.9145
8				1.0669	1.2955	1.3717	
9				.8383	1.1145	1.0059	.9145
11	1.2193	1.2346	1.0288				
12		1.2003	1.3717				
13	1.0669	1.1145	1.286				
14	1.0059	1.0288	.9907				
15	1.0364	1.0288	.9145				
16	1.0059	.9602	.8383				
17	.9145	1.0974	1.0288				
18	.8535	.8916	.9431				
19	.0457	.0686	.0514	.0514	.0686	.0457	.0457
20	.0457	.0686	.0514	.0514	.0686	.0457	.0457
21	.0457	.0686	.0686	.0514	.0686	.0457	.0457
22	.0305	.0686	.0686	.0514	.0686	.0457	.0457
23	.0305	.0686	.0514	.0514	.0686	.0457	.0457
24	.0457	.0457	.0686	.3429	.4287	.5144	.3963
Max	1.2193	1.2346	1.3717	1.0669	1.2955	1.5432	.9145
Min	.0305	.0457	.0514	.0514	.0686	.0457	.0457
Avg	.4011	.4625	.4570	.4187	.4947	.6058	.3625

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094009 / 33/11 KV DAHIWEL

Feeder No / Name : 204 / 11 KV DAHIWEL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6173	.6516	.6859	.6859	.6173	.7202
2	.6859	.6173	.6516	.6859	.6859	.6173	.7202
3		.6173	.6516	.6859	.6859	.6173	.7202
4	.6859	.6173	.8916	.6859	.6859	.6687	.7716
5	.8573	.8745	1.166	.7716	.7716	.9259	.8573
6	1.286	1.2689	1.2517	1.1145	1.1145	1.1831	1.286
7	1.2346	1.2174	1.166	.9907	1.1145	1.0974	.4115
8	1.0288	.9431	.9602	.8383	.8383	.8916	
9	.9431	.7545	.6859		.6859	.7545	.7545
10	.7545	.7888	.6859	.6859	.6859	.8059	.8573
11	.6859	.6859		.5335	.6173	.5487	.6859
12	.6859	.6859		.6097	.6173	.7545	.6859
13	.7202	.6173	.6859	.5335	.6516	.7545	.7716
14	.7202	.6173	.6097	.6097	.6173	.6173	.823
15	.823	.6516	.6097	.6859	.6859	.7202	.7716
16	.6859	.6859	.6859	.7716	.5487	.8573	.7373
17	.8059	.823	.7716	.7716	.7545	.8573	.7888
18	.8573	.7545	.8573	.6859	.823	.9431	.8916
19	.8916	.823	.9431		.823	.9602	1.0288
20	1.2517	.9088	.9431	.9431	.8916	1.0288	.9602
21	.8745	.8573	.8573	.8573	.8573	1.0288	.9431
22	.8402	.823	.823	.8573	.7545	.9945	.8573
23	.823	.7545	.7888	.6859	.6859	.9431	
24	.6859	.6859	.6516	.6859	.6859	.6173	.7373
Max	1.286	1.2689	1.2517	1.1145	1.1145	1.1831	1.286
Min	.6859	.6173	.6097	.5335	.5487	.5487	.4115
Avg	.8484	.7788	.8177	.7443	.7487	.8252	.8082

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094009 / 33/11 KV DAHIWEL

Feeder No / Name : 205 / 11 KV MALANGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1715	.1715	.2058	.1543	.1715
2	.1715	.1715	.1715	.1715	.1886	.1543	.1715
3	.1715	.1715	.1715	.1715	.1886	.1543	.1715
4	.1715	.1715	.1715	.1715	.1886	.1543	.1715
5	.1715	.1715	.1886	.1715	.1886	.1715	.1715
6	.1715	.2743	.2401	.2401	.2401	.1715	.2058
7	.1715	.2058	.2058	.1981	.1981	.1715	.1715
8	.1524	.2058	.1715	.1829	.1981	.2572	.2058
9	.1372	.1715	.1715	.1886	.1886	.1715	.1715
10	.1372	.1715	.1372	.1886	.2058	.1372	.1029
11	.1715	.2058	.1715	.1677	.2058	.1715	.1372
12	.1219	.1715	.1372	.1677	.2058	.1372	.1029
13	.1372	.1715	.1372	.1372	.1715	.1715	.0686
14	.1372	.2058	.1372	.1219	.1372	.1372	.1029
15	.1715	.2058	.1372	.1372	.1715	.1372	.1372
16	.1715	.2058	.1829	.1372	.1715	.1715	.1715
17	.1715	.2572	.2401	.2229	.2058	.1715	.2058
18	.2401	.2401	.2229	.1981	.2058	.1715	
19	.1715	.2401	.2401	.2229	.2058	.1715	.2058
20	.2401	.2058	.2401	.2401	.2058	.2401	.2058
21	.2401	.1715	.2401	.2401	.2058	.2401	.1829
22	.2058	.1715	.2229	.2401	.1715	.2401	.1715
23	.1886	.1543	.1886	.2058	.1543	.2058	
24	.2058	.1715	.1543	.1715	.2058	.1543	.1715
Max	.2401	.2743	.2401	.2401	.2401	.2572	.2058
Min	.1219	.1543	.1372	.1219	.1372	.1372	.0686
Avg	.1751	.1944	.1855	.1861	.1923	.1758	.1627

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094009 / 33/11 KV DAHIWEL

Feeder No / Name : 206 / 11 KV GHODADE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5792	.4999	.4801	.0686	.0686	.0686	.0457
2	.5792	.4877	.4801	.0686	.0686	.0686	.0457
3	.5792	.4877	.5487	.0686	.0686	.0686	.0457
4	.5792	.4877	.5487	.0686	.0686	.0686	.0457
5	.6706	.6097	.6859	.0686	.0857	.0686	.061
6	1.1584	1.2193	.7202	.0686	.0857	.0686	.061
7	1.4327	1.5242	1.6461				
8	1.3717	1.5242	1.6804				
9	1.1584	1.0669	1.286				
11				1.3717	1.0631	1.2193	
12				1.829	1.8861	1.5546	1.2193
13				1.5242	1.5432	1.2803	1.2193
14				1.3717	1.3032	1.0669	.9755
15				1.286	1.1317	1.0364	.823
16				1.0288	1.0631	1.0364	.9145
17				1.1145	1.0974	.381	.884
18				.9145	.9602	.6859	.7621
19	.0457	.0686	.0514	.0514	.0686	.0457	.0457
20	.0457	.0686	.0686	.0686	.0686	.061	.061
21	.0457	.0686		.0686	.0686	.061	.061
22	.0457	.0686	.0686	.0686	.0686	.061	.061
23	.0457	.0686	.0686	.0686	.0686	.061	
24	.4572	.4572	.4801	.0686	.0686	.0686	.0457
Max	1.4327	1.5242	1.6804	1.829	1.8861	1.5546	1.2193
Min	.0457	.0686	.0514	.0514	.0686	.0457	.0457
Avg	.5863	.5805	.6295	.5623	.5453	.4515	.4098

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094009 / 33/11 KV DAHIWEL

Feeder No / Name : 207 / 11 KV JAMBHORE

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.7621	.8573	.8573	.8573	.8573	.6097
7				1.448	1.3717	1.6804	.9145
8				1.3717	1.448	1.7147	1.2193
9				1.2193	1.4575	1.3717	1.0669
11	1.3717	1.5432	1.3717				
12	1.3717	1.5432	1.4575				
13	1.3717	1.4575	1.3717				
14	1.3717	1.4575	1.2193				
15	1.3717	1.5089	1.2193				
16	1.2193	1.5089	1.0669				
18				1.3717	1.7147	1.3717	1.2193
19	1.2955	1.5432	1.3717	1.7147	1.3717	1.2193	1.2955
20	1.2193	1.286	1.3717	1.3717	1.2003	1.0669	1.2955
21	1.0669	1.2003	1.1145	1.286	1.166	.9145	.9145
22	.9145	1.0288	1.0288	1.2003	1.1145	.884	.6859
23	.8383	1.0288	.9431	1.0288	1.0288	.7621	
24	.7621	.7621	.8573	.8573	.9431	.8573	.7621
Max	1.3717	1.5432	1.4575	1.7147	1.7147	1.7147	1.2955
Min	.7621	.7621	.8573	.8573	.8573	.7621	.6097
Avg	1.1490	1.2793	1.1731	1.2479	1.2431	1.1545	.9983

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094009 / 33/11 KV DAHIWEL

Feeder No / Name : 301 / 33 KV DAHIWEL I/C - I

Feeder KV- 33 / OUTGOING

DATE	15-JUN-18	16-JUN-18	18-JUN-18	19-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		4.6296			
23		3.858		3.9095	
24	4.9897	4.6296	.0051	.0051	3.4979
Max	4.9897	4.6296	.0051	3.9095	3.4979
Min	4.9897	3.858	.0051	.0051	3.4979
Avg	4.9897	4.3724	.0051	1.9573	3.4979

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094009 / 33/11 KV DAHIWEL

Feeder No / Name : 302 / 33 KV DAHIWEL I/C -II

Feeder KV- 33 / OUTGOING

DATE	15-JUN-18	16-JUN-18	18-JUN-18	19-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					5.3498
23		5.0412		4.8354	
24	5.8128	6.0185	.0051	.0051	
Max	5.8128	6.0185	.0051	4.8354	5.3498
Min	5.8128	5.0412	.0051	.0051	5.3498
Avg	5.8128	5.5299	.0051	2.4203	5.3498

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094023 / 33/11 KV JAITANE

Feeder No / Name : 201 / 11 KV ROSGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				2.9492	2.6216	2.4577	
2				2.7854	2.7854	2.6216	.4915
3				3.0312	2.8673	2.7035	
4				3.1131	2.9492	2.7854	.6554
5				3.1131	3.0312	2.8673	.7373
6				3.5665	3.1131	2.9492	.8192
7	4.4239	4.26	2.6216				
8	4.26	4.26	4.1781				
9	4.0143	4.0143	.3277				
10	3.8504	3.7685	3.8504				
11	3.6046	3.5227	3.6046				
14				4.26	4.1781	4.26	
15				4.1781	3.7685	4.0962	1.4746
16				4.0962	3.6866	3.2769	1.4746
17				3.7685	3.4408	3.4408	3.9323
18				3.6866	3.3589	3.3589	3.6046
19			3.5227				
20	3.4408	3.4408	3.3589				
21	3.2769	3.1131					
22	3.195	2.9492	3.195				
23	3.1131	2.7854	3.1131				
24	3.195	2.9492	2.7035	3.0312			
Max	4.4239	4.26	4.1781	4.26	4.1781	4.26	3.9323
Min	3.1131	2.7854	.3277	2.7854	2.6216	2.4577	.4915
Avg	3.6374	3.5063	3.0476	3.4649	3.2546	3.1652	1.6487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094023 / 33/11 KV JAITANE

Feeder No / Name : 202 / 11 KV NIJAMPUR GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1765	1.2803	1.1888	1.1888	1.2803	1.2803	1.2803
2	1.0974	1.1888	1.0974	1.0974	1.1888	1.1888	1.0974
3	1.0059	1.0974	1.0059	1.0059	1.0974	1.0059	1.0059
4	1.2803	1.1888	1.2803	1.1888	1.3717	1.2803	1.2803
5	1.5546	1.5546	1.5546	1.4632	1.6461	1.5546	1.5546
6	2.1948	2.3777	2.1948	2.1948	2.2862	2.3777	2.2862
7	1.9204	2.1033	1.9204	2.0119	2.1033	2.0119	2.0119
8	1.7375	1.7375	1.7375	1.829	1.6461	1.7375	1.7375
9	1.4632	1.6461	1.7375	1.6461	1.5546	1.6461	1.6461
10	1.4632	1.5546	1.5546	1.5546	1.5546	1.5546	1.6461
11	1.4632	1.4632	1.5546	1.5546		1.6461	1.4632
12	1.5546	1.4632	1.4632	1.3717	1.5546	1.5546	1.4632
13	1.3717	1.5546	1.4632	1.3717	1.5546	1.4632	1.5546
14	1.4632	1.4632	1.4632	1.3717	1.5546	1.4632	1.4632
15	1.3717	1.5546	1.5546	1.5546	1.4632	1.6461	1.5546
16	1.4632	1.3717	1.4632	1.3717	1.6461	1.5546	1.5546
17	1.5546	1.4632	1.4632	1.4632	1.6461	1.7375	1.5546
18	1.7375	1.7375	1.4632	1.4632	1.7375	1.6461	1.7375
19	2.0119	1.7375	1.829	1.7375	1.829	1.9204	1.829
20	2.1948	2.1948	2.1948			2.1033	2.1948
21	1.829	1.7375	1.829	1.9204	2.1033	1.829	1.9204
22	1.5546	1.4632	1.5546	1.7375	1.6461	1.5546	1.7375
23	1.4632	1.3717	1.3717	1.4632	1.5546	1.4632	
24	1.2803	1.3717	1.2803	1.2803	1.2803	1.2289	1.3717
Max	2.1948	2.3777	2.1948	2.1948	2.2862	2.3777	2.2862
Min	1.0059	1.0974	1.0059	1.0059	1.0974	1.0059	1.0059
Avg	1.5503	1.5699	1.5508	1.5149	1.6045	1.6020	1.6063

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094023 / 33/11 KV JAITANE

Feeder No / Name : 203 / 11 KV VASKHEDI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3927	1.3927	1.2289				
2	1.4746	1.4746	1.3927				
3	1.5565	1.5565	1.4746				
4	1.6385	1.6385	1.5565				
5	1.7204	1.7204	1.6385				
6	1.8023	1.8023	1.7204				
7				2.6216		2.6216	1.9662
8				2.4577		2.4577	2.13
9				2.3758	2.6216	2.3758	2.2119
10				2.2119	2.6216	2.2939	2.13
11				2.0481	2.3758	2.13	1.9662
12					2.0481		
13					1.8023		
14	2.6216	2.5396	2.7854				
15	2.5396	2.5396	2.6216				
16	2.3758	2.4577	2.2939				
17	2.3758	2.13	2.2939				
18	2.13	1.9662	1.8842				
19				2.5396	2.13	2.0481	
20				2.0481	1.9662	1.8842	
21				1.9662	1.8023	1.6385	
22				1.8023	1.7204	1.3108	
23				1.7204	1.6385	1.2289	
24					1.6385	1.6385	1.1469
Max	2.6216	2.5396	2.7854	2.6216	2.6216	2.6216	2.2119
Min	1.3927	1.3927	1.2289	1.7204	1.6385	1.2289	1.1469
Avg	1.9662	1.9289	1.8991	2.1792	2.0332	1.9662	1.9252

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094023 / 33/11 KV JAITANE

Feeder No / Name : 204 / 11 KV DUSANE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.267	1.3575	1.267	1.086
2				1.3575	1.5384	1.1765	
3				1.5384	1.448	1.1765	1.1765
4				1.6289	1.7194	1.3575	1.3575
5				1.6289	1.8099	1.5384	1.267
6				1.7194	1.8099		.9955
7				1.9004	1.9004	2.1719	1.086
8				1.8099	1.9909		
9				1.8099	1.9004	1.9909	1.5384
10							1.448
11	1.9909	1.6289	2.9864				
12	2.1719	2.0814	2.8959				
13	2.0814	2.2624	2.9864				
14	1.9004	2.1719	2.9864				
15	1.6289	2.1719	2.9864				
16	1.9909	2.1719	1.8099				
17	2.0814	1.9909	1.9004				
18	1.8099	1.7194	1.8099				
24				1.3575	1.267	1.2803	1.1765
Max	2.1719	2.2624	2.9864	1.9004	1.9909	2.1719	1.5384
Min	1.6289	1.6289	1.8099	1.267	1.267	1.1765	.9955
Avg	1.9570	2.0248	2.5452	1.6018	1.6742	1.4949	1.2368

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094023 / 33/11 KV JAITANE

Feeder No / Name : 205 / 11 KV DUSANE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.3658	.3658	.3658	.3658	.3658	.3658
2	.3658	.3658	.3658	.3658	.3658	.3658	.3658
3	.3658	.3658	.3658	.3658			.3658
4	.3658	.3658	.4572	.3658	.4572	.3658	.4572
5	.5487	.5487	.5487	.4572	.5487	.5487	.6401
6	.7316	.6401	.6401	.6401	.823	.823	.823
7	.6401	.6401	.6401	.7316	.7316	.6401	.7316
8	.5487	.5487	.5487	.5487	.5487	.5487	.5487
9	.4572	.4572	.4572	.5487	.5487	.4572	.4572
10	.4572	.3658	.4572	.4572	.4572	.4572	.4572
11	.3658	.3658	.4572	.4572	.3658	.4572	.3658
12	.3658	.4572		.4572	.3658	.4572	.4572
13	.3658	.4572	.4572	.3658	.3658	.3658	.4572
14	.3658	.4572	.4572	.3658	.3658	.4572	.4572
15	.3658	.3658	.5487	.4572	.3658	.4572	.3658
16	.3658	.3658	.4572	.4572	.4572	.4572	.4572
17	.4572	.3658	.5487	.4572	.4572	.4572	.4572
18	.5487	.3658	.5487	.5487	.5487	.5487	.4572
19	.6401	.3658	.4572	.6401	.6401	.6401	.6401
20	.4915	.6401	.6401	.7316	.7316	.7316	.6401
21	.4572	.5487	.6401	.6401	.6401	.5487	.6401
22	.4572	.4572	.4572	.6401	.4572	.4572	.5487
23	.3658	.3658	.3658	.4572	.3658	.3658	
24	.3658	.3658	.3658	.3658	.3658	.3658	.3658
Max	.7316	.6401	.6401	.7316	.823	.823	.823
Min	.3658	.3658	.3658	.3658	.3658	.3658	.3658
Avg	.4510	.4420	.4890	.4953	.4930	.4930	.5010

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094023 / 33/11 KV JAITANE

Feeder No / Name : 206 / 11 KV KHUDANE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6554	.6554	.7373	.3277	.3277	.4096	.3277
2	.7373	.7373	.9012	.4096	.4096	.3277	.4096
3	.9831	.9012	1.065	.4096	.4096	.3277	.4096
4	1.2289	1.2289	1.3927	.3277	.4096	.4096	.3277
5	1.4746	1.5565	1.5565	.3277	.4915	.4096	.3277
6	1.8023	1.9662	1.8023	.4096	.4915		.3277
7	2.2939	2.2119	2.0481	.4096	.4915	.4096	.4096
8	2.0481	2.0481	1.9662	.4096	.4915	.4096	.3277
9	1.8842	1.7204	1.8023	.3277	.4096	.4096	.4096
10				.3277	.4096	.3277	.4096
11				1.3108	1.5565		.9831
12				2.2939	2.3758	1.8023	1.8023
13				2.0481	2.0481	1.8842	1.5565
14		.3277	.3277	1.7204	1.3927	1.8023	1.5565
15		.4096	.4096	1.6385	1.7204	1.7204	1.4746
16	.4096	.4096	.4096	1.6385	1.6385	1.5565	1.4746
17	.4096	.4096	.4096	1.7204	1.5565	1.5565	1.5565
18	.4096	.3277	.4096	1.6385	1.4746	1.3927	1.3927
19	.4096	.3277	.3277		.4096	1.1469	.3277
20	.4915	.4096	.3277	.4096	.4096	.4096	.4096
21	.4096	.3277	.4096	.4096	.4915	.4096	.4096
22	.4096	.4096	.4096	.4096	.4096	.4096	.4096
23	.4096	.3277	.4096	.4096	.4096	.3277	
24	.5735	.5735	.6554	.3277	.3277	.4096	.3277
Max	2.2939	2.2119	2.0481	2.2939	2.3758	1.8842	1.8023
Min	.4096	.3277	.3277	.3277	.3277	.3277	.3277
Avg	.9467	.8643	.8889	.8549	.8568	.8304	.7551

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094023 / 33/11 KV JAITANE

Feeder No / Name : 207 / 11 KV WASDARA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3108	1.4746	1.3108				
2	1.3927	1.5565	1.3927				
3	1.4746	1.6385	1.4746				
4	1.6385	1.7204	1.5565				
5	1.7204	1.7204	1.6385				
6	1.8023	1.8023	1.6385				
7				2.6216	2.6216	2.4577	1.9662
8				2.5396	2.4577	2.3758	1.8842
9				2.3758	2.3758	2.3758	2.0481
10				2.2939	2.2119	2.2119	1.9662
11				2.0481	2.13	2.2119	1.8842
14	2.6216	2.7035	2.7035				
15	2.5396	2.6216	2.6216				
16	2.3758	2.4577	2.2939				
17	2.3758	2.2939	2.2939				
18	2.2119	2.0481	2.0481				
19				2.4577	2.3758	2.2939	2.13
20				2.13	2.13	2.0481	1.7204
21				2.0481	1.9662	1.8023	
22				1.8842	1.7204	1.3108	
23				1.7204	1.6385	1.3108	
24					1.6385	1.6385	1.3108
Max	2.6216	2.7035	2.7035	2.6216	2.6216	2.4577	2.13
Min	1.3108	1.4746	1.3108	1.7204	1.6385	1.3108	1.3108
Avg	1.9513	2.0034	1.9066	2.2119	2.1151	2.0034	1.8638

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094023 / 33/11 KV JAITANE

Feeder No / Name : 208 / 11 KV FOFADE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.8145	.724				
2	.8145	.9955	.905				
3	.9955	1.1765	1.086				
4	1.267	1.3575	1.3575				
5	1.448	1.448	1.6289				
6	1.5384	1.8099	1.8099				
7	2.0814	2.0814	1.7194				
8	1.9004	1.7194	1.7194				
9	1.8099	1.448	1.448				
11				1.4746		1.8842	1.448
12				2.5339	2.3758	1.9662	1.7194
13				1.9004	2.0814	1.6385	1.5384
14				1.8099	1.448	1.8099	1.086
15				1.6289	1.267	1.6289	.9955
16				1.3575	1.3575	1.086	1.086
17				1.448	1.267	1.1765	1.086
18				1.267	1.065	1.086	.8145
24	.6335	.6335	.6335				
Max	2.0814	2.0814	1.8099	2.5339	2.3758	1.9662	1.7194
Min	.6335	.6335	.6335	1.267	1.065	1.086	.8145
Avg	1.3213	1.3484	1.3032	1.6775	1.5517	1.5345	1.2217

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094032 / 33/11 KV CHHADWEL

Feeder No / Name : 201 / 11 KV CHHADWEL

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2955	1.2146	1.1336	1.2308	1.2308	1.1012	1.0364
2	1.2955	1.1336	1.1336	1.2308	1.166	1.1012	1.0364
9				1.8351	1.8023	1.7204	1.5546
10				1.8351	1.8023	1.4899	1.5061
11				1.6194	1.6194	1.4899	1.5384
12				1.5384	.9717	1.4899	1.4575
13	1.9662	1.8023	1.9662				
14	1.7204		1.8351				
15	1.5546	1.166	1.6194				
16	1.4575	1.2955	1.6194				
19	.1802	1.6194	2.0317	1.8023	1.5546	1.2955	1.8842
20	1.6194	1.4575	1.6194	1.6194	1.4899	1.3603	1.6194
21	1.5384	1.2955	1.2955	1.4251	1.3603	1.166	1.2955
22	1.2955	1.1336	1.2955	1.2955	1.2955	1.0688	1.1336
23	1.2955	1.1336	1.2955	1.2955		1.0688	
24	1.2955	1.2146	1.1336	1.2955	1.2308	1.1012	1.0364
Max	1.9662	1.8023	2.0317	1.8351	1.8023	1.7204	1.8842
Min	.1802	1.1336	1.1336	1.2308	.9717	1.0688	1.0364
Avg	1.3762	1.3151	1.4982	1.5019	1.4112	1.2878	1.3726

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094032 / 33/11 KV CHHADWEL

Feeder No / Name : 202 / 11 KV BRAMANWEL

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5384	1.4575	1.4575	1.2146	1.5546	1.4251	1.4899
2	1.4575	1.4575	1.3765	1.2146	1.4899	1.4251	1.4899
9	2.4034	2.4034	2.4863				
10	2.3205	2.3205	2.1879				
11	2.2119	2.13	1.9662				
12	1.9662	2.0481	1.8351				
13				2.3868	2.3868	2.5194	2.3868
14				2.1548	2.1879	2.3868	2.4863
15				2.0317	1.9662	2.2211	2.3205
16				1.704	1.8351	1.9662	2.13
19	2.2119	2.13	2.2542	1.9662	1.9662	1.9662	2.3205
20	2.13	1.8842	1.9662	1.8351	1.8842	1.704	1.9662
21	1.6194	1.6194	.3605	1.704	1.5546	1.6194	1.7204
22	1.4575	1.5384	1.704	1.8351	1.5546	1.4251	
23	1.4575	1.5384	1.5546	1.7368	1.4899	1.5546	
24	1.5384	1.4575	1.4575	1.3603	1.6194	1.4251	1.4899
Max	2.4034	2.4034	2.4863	2.3868	2.3868	2.5194	2.4863
Min	1.4575	1.4575	.3605	1.2146	1.4899	1.4251	1.4899
Avg	1.8594	1.8321	1.7172	1.762	1.7908	1.8032	1.9800

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094032 / 33/11 KV CHHADWEL

Feeder No / Name : 203 / 11 KV Titane

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8907	.9717	.8097	.8421	.8421	.8421	.7125
2	.8097	.8907	.8097	.8421	.8421	.8421	.7125
3			.8097				
4			.8907				
9	1.4575	1.6194	1.7204				
10	1.2146	1.4575					
11	1.1336	1.2955	1.2955				
12	.9717	1.1336	.9717				
13				1.4899	1.4899	1.4899	1.4899
14				1.3603	1.4251	1.2146	1.3279
15				.7773	1.3117	1.1336	1.2146
16				1.1984	1.0688	.9717	1.1336
19	1.4575	1.7204	1.6194	1.6712	1.587	1.4251	1.4575
20	1.2146		1.3927	1.3927	1.2308	1.1012	1.2955
21	1.1336		1.1984	1.166	1.1336	1.004	1.1336
22	1.1765	1.0526	1.0688	1.0364	1.004	.7773	.8097
23	1.0526	.9717	.9717	.9717	.9069	.7773	
24	.8907	.9717	.8097	.9717		.9069	.7125
Max	1.4575	1.7204	1.7204	1.6712	1.587	1.4899	1.4899
Min	.8097	.8907	.8097	.7773	.8421	.7773	.7125
Avg	1.1169	1.2085	1.1052	1.1433	1.1675	1.0405	1.0909

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094032 / 33/11 KV CHHADWEL

Feeder No / Name : 204 / 11 KV BASAR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5182		.5182	.4534	.5182	.4534	.4534
2	.5182		.5182	.4534	.5182	.4534	.4534
9				1.166	1.1012	.9717	.9069
10				.9069	.9717	.9717	.9069
11				.8745	.7773	.9717	.7773
12				.8421	.7773	.7773	.7125
13	.9717		1.0364				
14	.8421	.9069	.9717				
15	.7773	.9717	.9069				
16	.8421	.7773	.7773				
19	1.0364	1.1012	.9717	1.166	1.0364	.9069	1.2308
20	.8421	.9069	.9069	.9393	.9717	.7773	.9717
21	.7773	.7125	.7125	.6478	.6478	.7125	.7125
22	.6478	.6478	.5182	.6478	.583	.5182	
23	.583	.583	.3239	.583	.583	.5182	
24	.6478	.583	.5182	.4534	.5506	.4534	.4534
Max	1.0364	1.1012	1.0364	1.166	1.1012	.9717	1.2308
Min	.5182	.583	.3239	.4534	.5182	.4534	.4534
Avg	.7503	.7989	.7233	.7611	.7530	.7071	.7579

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094032 / 33/11 KV CHHADWEL

Feeder No / Name : 205 / 11 KV CHHADWEL KORDE

GAOTHAN FEEDER

GAONTHAN Feeder KV- 11 /
OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3563	.3563	.3563	.4534	.3239	.3563	.3887
2	.3563	.3563	.3563	.3239	.3239	.3563	.3887
3	.3887	.3887	.4049	.3887	.3887	.3563	.3887
4	.4534	.421	.4534	.421	.421	.4534	.4534
9	.6154	.4858	.6802	.7773	.6802	.6478	.6802
10	.583	.4534	.5344	.5182	.5182	.583	.6154
11	.4696	.4049	.421	.421	.4534	.4534	.4858
12	.3725	.3563	.3563	.3563	.3887	.3887	.4049
13	.3401	.3563	.3239	.3563	.3563	.3887	.3887
14	.3563	.3563	.3239	.3563	.3563	.3887	.3563
15	.3563	.3563	.3239	.3563	.3563	.3887	.3725
16	.3725	.3239	.3563	.3563	.3563	.421	.3725
17	.3725	.3563	.3401	.3887		.4534	.3887
18	.3725	.3887	.421	.4534		.4534	.4372
19	.5668	.4858	.7449	.5506	.5182	.5182	.5506
20	.6478	.5668	.7125	.6154	.7125	.6802	.6478
21	.6478	.6478	.3887	.6802	.6478	.7125	.6478
22	.6154	.5668	.583	.6154	.6478	.583	.5668
23	.4858	.4858	.4858	.4534	.5182	.4534	
24	.3725	.4049	.4049	.4534	.3563	.421	.3887
Max	.6478	.6478	.7449	.7773	.7125	.7125	.6802
Min	.3401	.3239	.3239	.3239	.3239	.3563	.3563
Avg	.4551	.4259	.4486	.4648	.4624	.4729	.4697

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094042 / 33/11 KV JAMKHEL

Feeder No / Name : 201 / 11 KV CHAUPALE

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8907	.9907	.8526	.8102	.7673	.7287
2		.8421	1.1022	.769	.7291	.6767	.7373
3		.8097	1.1022	.7699	.6767	.769	.7773
4		.8583	1.1869	.8573	.7673	.7725	.8192
5		.9069	1.2209	.864	.865	.865	.852
6		1.3765					
7		1.2146	1.638				
17				1.4026	1.3641	1.4413	
18				1.688	1.4526	1.1869	
19	1.3279		1.7804	1.7032	1.4607	1.4074	
20	1.4529		1.6289	1.4413	1.2016	1.3565	1.3565
21	1.1717	1.1869	1.3687	.8535	1.0265	1.2209	1.2717
22	1.0623	1.2689	1.2056	1.0254	.8478	1.0513	1.1869
23	.9374	1.1869	1.0151	.8459	.7605	.9326	
24		.8907	1.1022	.9284	.845	.763	.8383
Max	1.4529	1.3765	1.7804	1.7032	1.4607	1.4413	1.3565
Min	.9374	.8097	.9907	.769	.6767	.6767	.7287
Avg	1.1904	1.0393	1.2785	1.0770	.9852	1.0162	.9520

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094042 / 33/11 KV JAMKHEL

Feeder No / Name : 202 / 11 KV ROHOD

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3768	.373	.3399	.3922	.338	.3681
2		.3441	.373	.3418	.3926	.3418	.3681
3		.3277	.39	.3426	.4282	.3426	.3841
4		.3605	.5087	.4268	.4801	.5155	.4049
5		.3932	.5935	.4296	.5167	.6904	.4049
6				.6935	.5715	.864	.6783
7				.6075	.5734	.6081	.695
9						.0514	
10						.048	
11						.048	
12						.048	
13						.048	
17	.7287	.6783	.6001				
18	.8097		.6897				
19	.8097	.6783	.7707	.8987	.8631	.6478	.763
20	.6478	.5935	.6783	.7682	.7768	.6478	.763
21	.5992	.5935	.5968	.5144	.6028	.4858	.6783
22	.5344	.5087	.5127	.4468	.5115	.4915	.5075
23	.4858	.4239	.4287	.4102	.4239	.4096	.4409
24		.3725	.4239	.4234	.3887	.4268	.3768
Max	.8097	.6783	.7707	.8987	.8631	.864	.763
Min	.4858	.3277	.373	.3399	.3887	.048	.3681
Avg	.6593	.4709	.5338	.5110	.5324	.3918	.5256

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094042 / 33/11 KV JAMKHEL

Feeder No / Name : 203 / 11 KV SHIRSOLE

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1233	1.0151	1.1022			
2		1.1233	1.0174	1.0972			
3		1.1065	1.0513	1.1022			
4		1.1736	1.1022	1.1949			
5		1.2574	1.3565	1.1976	1.0454	1.0334	.9448
6				1.5501	1.5261	1.6543	1.3592
7				1.7356	2.0508	2.0805	1.6108
8				1.6326	1.929	1.7924	1.6766
9				1.4364	1.6489	1.4332	
17	1.8233		1.7744				
18	1.989		2.0462	2.1314	1.8024	1.7204	1.6956
19	1.989		2.1362	2.0279	1.7147	1.6518	
20	1.7604		1.8861	1.6956	1.5226	1.4746	1.6956
21	1.5927		1.8903	1.4559	1.3519	1.3108	1.4413
22	1.3748		1.6899	1.3535	1.1803	1.1603	1.4413
23	1.2574		1.1923	1.3596	1.1046	1.0774	.8817
24		1.1233	1.2717	1.0997			
Max	1.989	1.2574	2.1362	2.1314	2.0508	2.0805	1.6956
Min	1.2574	1.1065	1.0151	1.0972	1.0454	1.0334	.8817
Avg	1.6838	1.1512	1.4946	1.4483	1.5342	1.4899	1.4163

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094042 / 33/11 KV JAMKHEL

Feeder No / Name : 204 / 11 KV JAMKHEL I/C - I

Feeder KV- 11 / OUTGOING

DATE	16-JUN-18
HR	Load (MW)
17	1.1869
18	.6783
19	.6783
20	1.1869
22	1.3565
23	1.2717
Max	1.3565
Min	.6783
Avg	1.0598

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094042 / 33/11 KV JAMKHEL

Feeder No / Name : 301 / 33 KV JAMKHEL I/C - I

Feeder KV- 33 / OUTGOING

DATE	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	3.7894	4.5782	1.3642	1.2603	1.2126	3.6717
Max	3.7894	4.5782	1.3642	1.2603	1.2126	3.6717
Min	3.7894	4.5782	1.3642	1.2603	1.2126	3.6717
Avg	3.7894	4.5782	1.3642	1.2603	1.2126	3.6717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094050 / 33/11 KV CHHAWADI

Feeder No / Name : 201 / 11 KV vehergaon

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.768	1.4632	1.387	
2				1.7528	1.4937	1.4632	.7621
3				1.7985	1.5242	1.5089	
4				1.7985	1.6004	1.5242	
5				1.7985	1.6461	1.5394	
6						1.5394	
7	2.769	2.343	2.4234				
8	2.9492		2.9111				
9	2.7854	2.9492	2.7892				
10	2.4387		2.4996				
11	2.5149		2.3929				
12	2.2862		2.1948				
13				2.7435	2.652	2.713	2.2862
14				2.774	2.7892	2.5453	2.5911
15				2.5149	2.4844	2.4082	2.4387
16				2.4234	2.4387	2.3929	2.4387
17				2.3015	2.4082	2.0271	2.5149
18				2.1491	2.1033	1.829	2.0576
19	2.5911	2.4387					
20	1.9814	1.9966					
21	1.8842	1.9814	1.7985				
22	1.6385	1.9357	1.829				
23	1.704	1.9814	1.9357	1.5242	1.6004	1.1431	
24				1.768	1.387	1.4784	1.1279
Max	2.9492	2.9492	2.9111	2.774	2.7892	2.713	2.5911
Min	1.6385	1.9357	1.7985	1.5242	1.387	1.1431	.7621
Avg	2.3221	2.2323	2.3082	2.0858	1.9685	1.8214	2.0272

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094050 / 33/11 KV CHHAWADI

Feeder No / Name : 202 / 11 KV Lonkhedi Gaonthan

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1696	.1696	.1829	.1524	.1524	.1981	.1524
2	.1696	.1696	.1829	.1677	.1829	.1981	.1524
3	.2035	.2035	.1829	.1829	.1981	.1981	
4	.2374	.2543	.2286	.2286	.2439	.1829	
5	.2883	.2543	.2439	.2591	.2743	.2743	
9	.3391	.3391	.2591	.2896	.2896	.3353	
10	.3391	.2713	.2286	.2286	.2134	.2591	
11	.2543	.1526	.1829	.2134	.1981	.1981	
12		.1526		.1981	.1981	.1677	
16	.2543	.2439	.2286	.2286	.2591		.2896
17	.2543		.3048	.2743	.2439	.2439	.2286
18	.2543	.3048	.2896	.2591	.3353	.2591	.3048
19	.3391	.3353	.3048	.2591	.3201	.2743	.3353
20	.3391	.3201	.3353	.2743	.3506	.3506	.3201
21	.3052	.2591	.2896	.2743	.2743		
22	.2883	.2286	.2134	.1829	.2286	.2439	
23	.1696	.1524	.2134	.1829	.1981	.1829	
24	.1696	.1696	.1524	.1677	.1524	.1981	.1677
Max	.3391	.3391	.3353	.2896	.3506	.3506	.3353
Min	.1696	.1524	.1524	.1524	.1524	.1677	.1524
Avg	.2573	.2342	.2367	.2235	.2396	.2353	.2439

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094050 / 33/11 KV CHHAWADI

Feeder No / Name : 203 / 11 KV Ghanegaon

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0608	.5801	.4572				
2	.9945	.4973	.4268				
3	.9945	.4973	.4725				
4	1.0277	.5801	.7926				
5	1.0442	.6133	.7926				
7				1.9204	1.7375	1.5546	
8				1.829	1.9357	1.7375	
9				1.7985	1.6309	1.7071	
10				1.768	1.768	1.5242	
11				1.5699	1.6309	1.4022	
12				1.4632	1.4175	1.3717	
13	2.1338	2.21	2.2558				
14	2.0576	1.9814	2.1948				
15	1.9509	1.8138	2.0729				
16	1.829	1.8138	1.8595				
17	1.829		.8383				
18	1.448	1.387	1.6156				
19				1.0212	1.4022	1.1431	2.0271
20				.9755	1.1279	.945	1.3565
21				.7164	1.0974	.945	
22				.7621	1.0059	.9145	
23	.9326	.8383	.7468	.7773	.9602	.6859	
24	1.094	.8288	.6097				
Max	2.1338	2.21	2.2558	1.9204	1.9357	1.7375	2.0271
Min	.9326	.4973	.4268	.7164	.9602	.6859	1.3565
Avg	1.4151	1.1368	1.1642	1.3274	1.4286	1.2664	1.6918

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094058 / 33/11 KV SHEWALI

Feeder No / Name : 201 / 11 KV DATARTI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.426	.3788	.547	.2019	1.1469	1.0898	.4915
2	.426	.3791	.5093	1.1478	1.1469	1.0898	.5243
3	.3932	.417	.5093	1.2477	1.0486	1.1736	
4	.4588	.454	.5658	1.5477	1.2125	1.3413	
5	.4915	.5297	.6036	1.714	1.3108	1.4754	
6	.6226	.6048	.679	1.9448	1.4746	1.7604	
7	.5571	.6602	.6224	2.1411	1.7368	2.3472	
8	.4915	.4404	.415	2.2181	1.6385	2.6322	
9		.5481	.473	2.2611	2.1464	2.4249	
10		.4481	.4545	.3277		.3441	
11	1.8484	1.8482	1.6355	.3277		.3768	1.1985
12	2.8295	2.696	1.9851	.4588	.5658	.3969	
13	2.5797	2.6452	2.2879	.3307	.5228	.3932	2.0501
14	2.5937	2.3703	2.2517	.3605	.5415	.426	2.655
15	2.6164	1.8896	2.2543	.3932	.3921	.426	2.4393
16	2.3294	1.9989	2.2374	.3932		.3932	2.473
17	2.4814		2.1052	.3932	.4481	.426	2.4561
18	2.245	1.7859	1.7386	.426	.4481	.3277	1.975
19	.5297	.5228	.4739	.5898	.5788	.5571	.6804
20	.7764	.8029	.811	.7209	.8029	.6882	.7639
21	.7946	.7842	.7182	.6554	.7842	.6615	.7858
22	.6635	.6535	.6054	.4915	.6036	.5243	
23	.5681	.5601	.4744	.5243	.3772	.5243	
24	.4588	.3985	.5281	1.0852	1.0159	1.0395	.4915
Max	2.8295	2.696	2.2879	2.2611	2.1464	2.6322	2.655
Min	.3932	.3788	.415	.2019	.3772	.3277	.4915
Avg	1.2355	1.0355	1.0619	.9126	.9497	.9516	1.4603

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094058 / 33/11 KV SHEWALI

Feeder No / Name : 202 / 11 KV Tembhe

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2949	.2841	.3018	.136	.1638	.1677	.3277
2	.2622	.303	.3018	.1513	.1638	.1677	
3	.2622	.3405	.3018	.1699	.1966	.2683	
4	.3277	.4158	.415	.2379	.2622	.3353	
5	.3932	.4522	.547	.3062	.3277	.4359	
6	.5243	.5082	.6602	.4404	.6226	.6371	
7	.2622	.5281	.4715	.557	.6882	.8048	
8	.2949	.3977	.415	.5739	.3605	.6706	
9	.227	.3033	.3226		.3521	.4096	
10		.2641	.2846	.2622	.2054	.2622	
11	.4725	.213	.341	.1984		.2622	.239
12	.6783	.5898	.4079	.1966		.2622	
13	.5608	.5898	.5297	.1638	.2614	.2622	.5274
14	.5778	.5407	.4079	.1984	.2054	.2785	.6125
15	.2899	.3441	.3743	.1984	.2075	.2785	.6042
16	.2899	.3481	.3791	.2294	.2054	.2646	.6054
17	.2194		.3073	.2294	.1886	.2949	.567
18	.3207	.2622	.2563	.2949	.2427	.3277	.4162
19	.4725	.4424	.3896	.3277		.5243	.5481
20	.4914	.5281	.542	.3605	.6602	.5571	.6804
21	.4919	.4715	.4726	.3605	.5658	.4588	.6042
22	.3981	.3584	.454	.3277	.4481	.3932	
23	.3605	.3206	.3036	.2949	.3772	.3605	
24	.2949	.3226	.3018	.1366	.1638	.1509	.3277
Max	.6783	.5898	.6602	.5739	.6882	.8048	.6804
Min	.2194	.213	.2563	.136	.1638	.1509	.239
Avg	.3812	.3969	.3954	.2762	.3271	.3681	.5050

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094058 / 33/11 KV SHEWALI

Feeder No / Name : 204 / 11 KV SHEWALI I/C - I

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	3.0521	3.0384			2.4691		1.1317
9				3.596			
16	2.9709		2.9104	2.2634		.6859	
18							3.4626
24	1.6804	1.4752		1.6485	1.6461		1.4746
Max	3.0521	3.0384	2.9104	3.596	2.4691	.6859	3.4626
Min	1.6804	1.4752	2.9104	1.6485	1.6461	.6859	1.1317
Avg	2.5678	2.2568	2.9104	2.5026	2.0576	.6859	2.0230

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094058 / 33/11 KV SHEWALI

Feeder No / Name : 301 / 33 KV SHEWALI IC I

Feeder KV- 33 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.6147	2.7517	2.7526	2.9006	2.5485	3.4642	1.0174
16	2.8257	2.3643	2.5962	1.9737	2.1333	.2594	
18							3.0968
24	1.3582	1.3065	.5341	1.2361	1.2921	1.2346	1.0733
Max	2.8257	2.7517	2.7526	2.9006	2.5485	3.4642	3.0968
Min	1.3582	1.3065	.5341	1.2361	1.2921	.2594	1.0174
Avg	2.2662	2.1408	1.9610	2.0368	1.9913	1.6527	1.7292

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094066 / 33/11 KV PINJARZADI

Feeder No / Name : 201 / 11 KV RAYKOT

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.945	.9907	.7621	.9116	.9945	.9945	.8383
2	.8688	.884	.7621	.9116	.9945	.9945	.7926
9				1.6244	1.5249	1.5546	1.2955
10				1.5912	1.5249	1.5089	1.3413
11				1.4918	1.326	1.3717	1.2955
12				1.326	1.326	1.1888	1.2651
13	1.5546	1.5242	1.4918				
14	1.4632	1.3717	1.4918				
15	1.2955	1.2193	1.326				
16	1.1431	1.0669	1.326				
20	1.4175	1.3717	1.326	1.326	1.326	1.2803	1.4022
21	1.2651	1.3413	1.1603	1.1603	1.1934	1.0822	1.0364
22	1.0974	1.2498	.9945	1.1603	1.0774	.9145	.7773
23	1.1279	1.1888	.9116	.9945	1.0774	.9145	.7316
24	1.0364	1.0669	1.0974	.9116	.9945	.9945	.884
Max	1.5546	1.5242	1.4918	1.6244	1.5249	1.5546	1.4022
Min	.8688	.884	.7621	.9116	.9945	.9145	.7316
Avg	1.2013	1.2068	1.1500	1.2190	1.2145	1.1635	1.0600

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094066 / 33/11 KV PINJARZADI

Feeder No / Name : 202 / 11 KV DEOJIPADA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9945	1.0277	.8288	.9116	.9945	.9945	.884
2	.9945	.9945	.8288	.9116	.9945	.9945	.7926
8		1.6575					
9	1.6078	1.4586	1.4918				
10	1.4918	1.2929	1.326				
11	1.326	1.21	1.326				
12	1.2431	1.21	1.1603				
13				1.8233	1.8233	1.5242	1.2955
14				1.7404	1.4918	1.4327	1.326
15				1.6907	1.4586	1.3717	1.4327
16				1.4918	1.326	1.2955	1.3565
17		1.326					
20	1.3426	1.326	1.326	1.326	1.326	1.1888	1.1888
21	1.1934	1.2431	1.1603	1.1603	1.1934	1.0669	1.0669
22	1.1271	1.1934	.9945	1.1603	1.0774	1.0059	.945
23	1.1603	1.1603	.9116	.9945	1.0774	.945	.823
24	1.0277	1.0774	1.0442	.9116	.9945	.9945	.9145
Max	1.6078	1.6575	1.4918	1.8233	1.8233	1.5242	1.4327
Min	.9945	.9945	.8288	.9116	.9945	.945	.7926
Avg	1.2281	1.2444	1.1271	1.2838	1.2507	1.1649	1.0932

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094004 / 33/11 kv BORIS

Feeder No / Name : 201 / LAMKANI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8804	1.9909	1.8861				
2	1.8804	1.9909	1.8861				
3	1.8804	1.97	1.95				
4	2.191	2.1491	2.0481				
5	2.5434	2.4006	2.2405				
6	2.8502	2.6282	2.5606				
7	2.7664	2.5101	2.3434				
8	2.3739	2.3758	2.3472				
10				1.6956	1.6956	1.8652	1.5261
11				2.0348	2.2043	2.3739	2.0348
12				2.3739	2.5434	2.3739	2.1195
13				2.3739	2.5434	2.3739	2.2043
14				2.2891	2.5434	2.2043	2.2043
15				2.2891	2.5434	2.2043	2.2043
16				2.2891	2.5434	2.2043	2.0348
17				2.5434	2.3739	1.4403	
23	1.6956	1.6956					
24	1.7804	1.8652	1.8652				
Max	2.8502	2.6282	2.5606	2.5434	2.5434	2.3739	2.2043
Min	1.6956	1.6956	1.8652	1.6956	1.6956	1.4403	1.5261
Avg	2.1842	2.1576	2.1252	2.2361	2.3739	2.1300	2.0469

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094004 / 33/11 kv BORIS

Feeder No / Name : 202 / BEHED AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.0974			1.0288
2				1.0974			1.0288
3				1.086			1.1145
4				1.267			1.1145
5				1.4327			1.1145
6				1.4327			1.286
7				1.4899			1.286
8				1.4327			1.286
10	.5087	.8478	.5087				
11	1.0174	1.0174	1.0174				
12	1.0174	1.0174	1.0174				
13	1.0174	1.0174	1.0174				
14	1.0174	1.0174	1.0174				
15	1.0174	1.0174	.8478				
16	1.0174	1.0174	.8478				
17	1.3565	1.3565	1.0174				
23			.5935	.8478	.8478	.6535	
24				.6783	.8478	1.0174	.7392
Max	1.3565	1.3565	1.0174	1.4899	.8478	1.0174	1.286
Min	.5087	.8478	.5087	.6783	.8478	.6535	.7392
Avg	.9962	1.0386	.8761	1.1862	.8478	.8355	1.1109

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094004 / 33/11 kv BORIS

Feeder No / Name : 203 / BURZAD Single phasing
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.5601	.5601	.985			1.1393
2	.5601	.5601	.5601	.985			1.1145
3	.5601	.5601	.5601	.985			1.1145
4	.6468	.5601	.7392	1.1641			1.2003
5	.7392	.7392	.823	1.4022			1.286
6	.823	.9145	.905	1.4575			1.3717
7	.7392	.8316	.823	1.5261			1.3717
8	.5935	.6535	.6468	1.4022			1.3717
9	.5087	.5087	.5087	.5087	.5087	.5935	.5935
10	.8478	1.1022	1.0174	.5087	.3391	.5087	.5087
11	1.2717	1.1869	1.3565	.5087	.5087	.5087	.5087
12	1.3565	1.3565	1.3565	.5087	.5087	.5087	.5087
13	1.3565	1.3565	1.3565	.5087	.5087	.5087	.5087
14	1.3565	1.3565	1.3565	.5087	.5087	.5087	.5087
15	1.3565	1.2717	1.4413	.5087	.5087	.5087	.5087
16	1.3565	1.2717	1.3565	.5087	.5087	.5087	.5087
17	1.2717	1.2717	1.2717	.5087	.5087	.4668	
18	.5087	.5087	.5087	.5087	.5087	.5601	
19	.6783	.6783	.763	.6783	.6783	.7392	
20	.8478	.8478	.8478	.8478	.8478	.905	
21	.6783	.6783	.6783	.763	.6783	.7392	
22	.5935	.5935	.5935	.5935	.6783	.7392	
23	.5087	.5087	.9326	1.0174	1.0174	.905	
24	.5087	.5087	.5087	1.0174	1.0174	1.0174	.905
Max	1.3565	1.3565	1.4413	1.5261	1.0174	1.0174	1.3717
Min	.5087	.5087	.5087	.5087	.3391	.4668	.5087
Avg	.8429	.8494	.8946	.8296	.6147	.6391	.8841

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094004 / 33/11 kv BORIS

Feeder No / Name : 204 / CHINCHWAR Single phasing SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974	.905	.1867	.0943			.0905
2	1.0974	.905	.1867	.0943			.0905
3	1.1765	1.0745	.1867	.0943			.0905
4	1.267	1.2536	.1867	.0943			.0905
5	1.6118	1.5775	.1867	.0943			.0905
6	2.1033	1.7147	.1867	.0943			.0905
7	2.0157	1.7804	.1867	.0943			.0905
8	1.5261	1.4899	.1867	.0943			.0905
9	.1696	.1696	.1696	.0848		.0848	
10	.0848	.0848		.8478		.8478	.5087
11	.0848	.0848		1.3565	1.5261	1.1869	1.1869
12	.0848	.0848		1.6956	1.6956	1.1869	1.3565
13	.0848	.0848		1.5261	1.6956	1.1869	1.3565
14	.0848	.0848	1.5261	1.4413	1.3565	1.1869	1.3565
15	.0848	.0848	1.8652	1.3565	1.1869	1.1869	1.3565
16	.0848	.0848	1.5261	1.1869	1.1869	1.1869	1.2717
17	.0848		.0848	.0848	1.1869	.905	
18	.1696		.0848	.0848	.0848		
19	.2543		.1696		.0848		
20	.2543	.0848	.3391	.0848	.0848	.0943	
21	.1696	.0848	.2543	.0848	.0848	.0943	
22	.1696	.0848		.0848	.0848	.0943	
23	.8478	.0848	.0848	.0848	.0848	.0943	
24	1.0174	.9326	.1696	.0848	.0848	.0848	.0943
Max	2.1033	1.7804	1.8652	1.6956	1.6956	1.1869	1.3565
Min	.0848	.0848	.0848	.0848	.0848	.0848	.0905
Avg	.6511	.6065	.4088	.4715	.7449	.6729	.5757

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094004 / 33/11 kv BORIS

Feeder No / Name : 205 / BORIS SINGLE PHASING.

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.5601	.3734				
2	.3734	.5601	.3734				
3	.3734	.5601	.5228				
4	.4668	.5601	.5544				
5	.5544	.7392	.6468				
6	.6468	.7392	.5601				
7	.6468	.7392	.6468				
8	.5935	.7392	.7392				
10				.5087	.8478	.5087	.5087
11				.8478	.8478	.8478	.6783
12				1.1869	.8478	.8478	.6783
13				1.1869	.8478	.8478	.6783
14				1.0174	.8478	.8478	.6783
15				1.0174	.8478	.8478	.6783
16				.8478	.8478	.8478	.5935
17				.6783	.6783	.7392	
23	.5087	.3391					
24	.5087	.5935	.3391				
Max	.6468	.7392	.7392	1.1869	.8478	.8478	.6783
Min	.3734	.3391	.3391	.5087	.6783	.5087	.5087
Avg	.5046	.6130	.5284	.9114	.8266	.7918	.6420

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094004 / 33/11 kv BORIS

Feeder No / Name : 206 / BEHED GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1867	.1867	.1867			.181
2	.1867	.1867	.1867	.1867			.1715
3	.1867	.3734	.1867	.1867			.1715
4	.1867	.1867	.1867	.1867			.1715
5	.2801	.2801	.2801	.2801			.3429
6	.3696	.3734	.3734	.2801			.3429
7	.2801	.2801	.2801	.2801			.3429
8	.1696	.2801	.1867	.1867			.2572
9	.1696	.1696	.1696	.1696	.1696	.1696	.1696
10	.1696	.1696	.1696	.1696	.1696	.1696	.1696
11	.1696	.1696	.1696	.1696	.1696	.1696	.1696
12	.1696	.1696	.1696	.1696	.1696	.1696	.1696
13	.1696	.1696	.1696	.1696	.1696	.1696	.1696
14	.1696	.1696	.1696	.1696	.1696	.1696	.1696
15	.1696	.1696	.1696	.1696	.1696	.1696	.1696
16	.1696	.1696	.1696	.1696	.1696	.1696	.1696
17	.1696	.1696	.1696	.1696	.1696	.1867	
18	.1696	.2543	.1696	.1696	.1696	.1867	
19	.2543	.3391	.2543	.2543	.2543	.2801	
20	.2543	.3391	.2543	.2543	.2543	.3734	
21	.1696	.2543	.1696	.1696	.1696	.2801	
22	.1696	.1696	.1696	.1696	.1696	.1867	
23	.1696	.1696	.1696	.1696	.1696	.1867	
24	.1696	.1696	.1696	.1696	.1696	.1696	.1867
Max	.3696	.3734	.3734	.2801	.2543	.3734	.3429
Min	.1696	.1696	.1696	.1696	.1696	.1696	.1696
Avg	.1971	.2237	.1979	.1940	.1802	.2004	.2073

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094004 / 33/11 kv BORIS

Feeder No / Name : 207 / Nakumbhe (Single Phasing) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1867	.1867	.7392			1.0288
2	.1867	.1867	.1867	.7392			1.0288
3	.1867	.1867	.1867	.7392			1.0288
4	.2801	.1867	.1867	1.086			1.1145
5	.462	.3734	.3734	1.3432			1.1145
6	.5544	.462	.5544	1.4899			1.286
7	.3696	.3696	.4668	1.4327			1.286
8	.3391	.3734	.3734	1.2536			1.2003
9	.3391	.3391	.3391	.2543	.2543	.3391	.2543
10	.6783	1.1022	.8478	.1696	.1696	.2543	.1696
11	1.3565	1.1869	1.1869	.1696	.1696	.1696	.1696
12	1.1869	1.3565	1.3565	.1696	.1696	.1696	.1696
13	1.1869	1.3565	1.3565	.1696	.1696	.1696	.1696
14	1.1869	1.1869	1.3565	.1696	.1696	.1696	.1696
15	1.1869	1.1869	1.1869	.1696	.1696	.1696	.1696
16	1.1869	1.1869	1.1869	.1696	.1696	.1696	.1696
17	1.2717	1.1869	1.0174	.1696	.3391	.2801	
18	.2543	.2543	.2543	.2543	.5087	.4668	
19	.4239	.5087	.4239	.4239	.5087	.5544	
20	.4239	.5087	.4239	.4239	.4239	.4668	
21	.3391	.4239	.3391	.3391	.3391	.3734	
22	.2543	.3391	.2543	.2543	.2543	.3734	
23	.1696	.1696	.5935	1.0174	1.0174	.5544	
24	.1696	.1696	.1696	.6783	1.0174	1.0174	.5601
Max	1.3565	1.3565	1.3565	1.4899	1.0174	1.0174	1.286
Min	.1696	.1696	.1696	.1696	.1696	.1696	.1696
Avg	.5908	.6162	.6170	.5761	.3656	.3561	.6523

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467] BU 0467

Substation No/ Name :- 094006 / NYHALOD

Feeder No / Name : 201 / 11 KV Billadi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	18-JUN-18	19-JUN-18
HR	Load (MW)	Load (MW)
1	.3353	.4458
2	.3353	.4458
3	.3353	.4458
4	.4214	.4458
5	.4214	.4755
6	.5719	1.0254
7	.5719	1.07
8	.5719	.8025
23	.2972	
24	.3269	
Max	.5719	1.07
Min	.2972	.4458
Avg	.4189	.6446

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467] BU 0467

Substation No/ Name :- 094006 / NYHALOD

Feeder No / Name : 202 / NYHALOD Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	18-JUN-18	19-JUN-18
HR	Load (MW)	Load (MW)
1	.2896	.4214
2	.2896	.4214
3	.2896	.4214
4	.3185	.4214
5	.4923	.4214
6	.5068	.6923
7	.5068	.7827
8	.5068	.6773
23	.3311	
24	.301	
Max	.5068	.7827
Min	.2896	.4214
Avg	.3832	.5324

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467] BU 0467

Substation No/ Name :- 094006 / NYHALOD

Feeder No / Name : 203 / KAPADANE Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	18-JUN-18
HR	Load (MW)
10	.3475
11	.3909
12	.4344
13	.4633
14	.4344
15	.3765
16	.4054
17	.4633
Max	.4633
Min	.3475
Avg	.4145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094006 / NYHALOD

Feeder No / Name : 204 / Nyhalod Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-JUN-18	19-JUN-18
HR	Load (MW)	Load (MW)
1		.3658
2		.3658
3		.3658
4		.3963
5		.4268
6		.4877
7		.4572
8		.3658
9	.3658	
10	.3353	
11	.3353	
12	.3353	
13	.3658	
14	.3963	
15	.4115	
16	.4115	
17	.4572	
18	.4877	
19	.4877	
20	.5182	
21	.4877	
22	.4572	
23	.4115	
24	.3963	
Max	.5182	.4877
Min	.3353	.3658
Avg	.4163	.4039

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094006 / NYHALOD

Feeder No / Name : 205 / Kapadana Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-JUN-18	19-JUN-18
HR	Load (MW)	Load (MW)
1		.0175
2		.0175
3		.0175
4		.0175
5		.0175
6		.0175
7		.0175
8		.0175
9	.0175	.0175
10	.0175	.0175
11	.0175	
12	.0175	
13	.0175	
14	.0175	
15	.0175	
16	.0175	
17	.0175	
18	.0175	
19	.0175	
20	.0175	
21	.0175	
22	.0175	
23	.0175	
24	.0175	
Max	.0175	.0175
Min	.0175	.0175
Avg	.0175	.0175

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467] BU 0467

Substation No/ Name :- 094006 / NYHALOD

Feeder No / Name : 206 / NAGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-JUN-18	19-JUN-18
HR	Load (MW)	Load (MW)
1		.1734
2		.1734
3		.1734
4		.1734
5		.208
6		.2427
7		.2601
8		.2427
9	.2427	
10	.208	
11	.1734	
12	.1734	
13	.1734	
14	.208	
15	.208	
16	.208	
17	.208	
18	.208	
19	.208	
20	.2427	
21	.208	
22	.1734	
23	.1734	
24	.1734	
Max	.2427	.2601
Min	.1734	.1734
Avg	.1994	.2059

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094010 / NAVALNAGAR

Feeder No / Name : 201 / MOHADI PD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	.7926		.8659	.9431	.7621	.5521
2	1.0288	.8383		.7706	.9054	.7621	.5138
3	1.0669	.8383		.8073	.9431	.7926	.5647
4	1.1317	.9145		.8888	1.094	.9145	.4694
5	1.2826	1.0669		1.0641	1.226	1.0669	.7707
6	1.3443	1.1149		1.0694	1.307	1.3413	1.0796
7	1.4784	1.057		1.2008	1.5708	1.3321	1.0291
8	1.2567	.8688		1.2099	1.2012	1.0974	1.1963
10	1.0608	1.0212	1.1549	.7499	.7682	.7316	.7499
11	1.1584		1.4723	.8779	.8535		1.0425
12	1.1888		1.3765	1.0425	1.1431		
13	1.1279		1.3846	1.0608	1.1126		
14	1.1126		1.3357	1.0608	1.0822		.9694
15	1.0974		1.3032	1.0608	1.0669		1.0242
16	1.1294		1.238	1.0242	1.0364		1.0425
17	1.0715		1.2054	1.0242	.9145		.8413
23	.7621		.8579	1.0751	.7316	.5138	.6036
24	.9907	.7926		.8431	1.0185	.7621	.5481
Max	1.4784	1.1149	1.4723	1.2099	1.5708	1.3413	1.1963
Min	.7621	.7926	.8579	.7499	.7316	.5138	.4694
Avg	1.1288	.9305	1.2587	.9831	1.0510	.9160	.8123

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467] BU 0467

Substation No/ Name :- 094010 / NAVALNAGAR

Feeder No / Name : 202 / SANJAY AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	17-JUN-18	20-JUN-18
HR	Load (MW)	Load (MW)
1	.6979	
2	.8145	
3	.8308	
4	1.1227	
5	1.1566	
6	1.321	
7	1.0274	
8	1.1227	
11		1.3704
12		1.2417
13		1.3929
14		1.4042
15		1.3251
16		1.3605
24	.957	
Max	1.321	1.4042
Min	.6979	1.2417
Avg	1.0056	1.3491

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094010 / NAVALNAGAR

Feeder No / Name : 203 / MOHADI PD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.4287	.3099	.2976	.3018	.2743	.3426
2	.3961	.4115	.3258	.3258	.2829	.2743	.3426
3	.415	.4115	.3095	.3258	.3018	***	.3768
4	.4294	.4115	.2932	.401	.3361	.2915	.4111
5	.4854	.4458	.3639	.507	.4294	.3429	.4658
6	.5359	.5144	.3258	.4884	.4668	.3944	.4453
7	.5175	.4287	.3095	.3165	.3881	.3258	.3765
8	.3326	.3429	.3239	.3095	.3326	.2743	.2569
9	.2957	.2915	.204	.2673	.2926	.2915	.2574
10	.2926	.3772	.3095	.2743	.2743	.2743	.3475
11	.3772		.3896	.2926	.3086	.2538	.3841
12	.3601		.4058	.2926	.3086	.201	.4024
13	.3429		.4072	.3292	.3772	.3342	.4572
14	.3429		.4785	.3658	.3944	.3509	.439
15	.3258		.3914	.3658	.3944	.3684	.4572
16	.3772		.3409	.3841	.3658	.3684	.4572
17	.3772		.3909	.3475	.3506	.4019	.4938
18	.4458		.4601	.4572	.4287	.4187	.3658
19	.4973		.4561	.4805	.5144	.4689	.3841
20	.4287		.5182	.5544	.5144	.4409	.3658
21	.4973		.4049	.4251	.5144	.5138	.3841
22	.4458		.3258	.3511	.3086	.4472	.3511
23	.4287		.3258	.4251	.3086	.3768	.499
24	.415	.4287	.3095	.3537	.3018	.2915	.3677
Max	.5359	.5144	.5182	.5544	.5144	13.9613	.499
Min	.2926	.2915	.204	.2673	.2743	.201	.2569
Avg	.4074	.4084	.3617	.3724	.3665	.9142	.3930

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094010 / NAVALNAGAR

Feeder No / Name : 204 / Sanjay Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2012	.2058	.1629	.1884	.1829	.1715	.1466
2	.1829	.2058	.1485	.2024	.1646	.1715	.1861
3	.2012	.2058	.1694	.1879	.1829	.1715	.2024
4	.2172	.2229	.1165	.2481	.2172	.1715	.2024
5	.2353	.2134	.2142	.2844	.2534	.2058	.2393
6	.2658	.2439	.2443	.204	.2658	.2401	.1955
7	.2303	.1981	.2281	.2672	.2126	.2229	.1466
8	.1949	.1829	.2118	.2577	.2126	.1715	.1303
9	.1949	.2229	.1955	.193	.2126	.2058	.1504
10	.2303	.2229	.2443	.2303	.1949	.2058	.1595
11	.2229		.2443	.2058	.1829	.1713	.1772
12	.2229		.2606	.1715	.1677	.137	.1772
13	.2058		.319	.1715	.1677	.137	.1595
14	.2229		.2591	.1715	.1981	.1503	.1734
15	.2229		.2753	.1715	.1829	.1541	.1907
16	.2229			.1886	.1829	.1713	.1907
17	.2229		.2936	.1949	.2134	.205	.1595
18	.2229		.2606	.2126	.2058	.1713	.1772
19	.2229		.2606	.2303	.1886	.1802	.1595
20	.2401		.2945	.2481	.2401	.1838	.1417
21	.2401		.2429	.2303	.2229	.188	.0886
22	.2229		.2118	.1949	.1886	.1686	.1086
23	.2058		.2234	.181	.1886	.1686	.1448
24	.2012	.2058	.1248	.2005	.1829	.1886	.1656
Max	.2658	.2439	.319	.2844	.2658	.2401	.2393
Min	.1829	.1829	.1165	.1715	.1646	.137	.0886
Avg	.2189	.2118	.2263	.2099	.2005	.1797	.1656

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094010 / NAVALNAGAR

Feeder No / Name : 205 / NAVRA-NAVRI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2286	.1872				
2	.2743	.2286	.231				
3	.2915	.2286	.1622				
4	.3018	.2743	.1622				
5	.3521	.3201	.3095				
6	.3688	.3963	.3809				
7	.3725	.3353	.2918				
8	.2753	.2439	.205				
10				.1715	.2572	.1981	.1509
11				.218	.2743	.2577	.2915
12				.2683	.3201	.2475	.218
13				.3018	.2743	.1872	.218
14				.2683	.2743	.2475	.2012
15				.285	.2743	.1872	.2012
16				.3239	.2743	.2443	.218
17				.3563	.2743	.1488	.2267
23	.1829						
24	.285	.2134	.2475				
Max	.3725	.3963	.3809	.3563	.3201	.2577	.2915
Min	.1829	.2134	.1622	.1715	.2572	.1488	.1509
Avg	.2979	.2743	.2419	.2741	.2779	.2148	.2157

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467] BU 0467

Substation No/ Name :- 094013 / FAGANE

Feeder No / Name : 201 / FAGANE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6859	.6859	.5144	.1372	.0857	.1715
2	.6859	.6859	.6859	.5144	.1372	.0857	.1715
3	.6859	.7716	.6859	.5144	.1372	.0857	.1372
4	.7716	.7716	.7888	.5144		.1029	.1372
5	.823	.8573	.9945	.6001	.1372	.1029	.1715
6	.9602	1.0288	1.0631	.6001	.1372	.1029	.1372
7	1.0974	1.1145	1.166	.6001	.1372	.1029	.1372
8	.5487	.6859	.6173	.6859	.1372	.1029	.1372
9	.1372	.1372	.1372	.1372	.1372	.1372	.1372
10	.12	.1029	.1372	.5144	.5144	.4287	.3772
11	.1029	.1029	.1372	.5144	.6859	.6859	.3429
12	.1029	.1372	.1372	.5487	.8916	.6859	.3429
13	.0857	.1372	.1372	.583	.6859	.6859	.3429
14	.0857	.1372	.1372	.6516	.6859	.6859	.3429
15	.1029	.1372	.1372	.7888	.6001	.6859	.3429
16	.1372	.1372	.1372	.823	.5144	.6859	.3429
17	.1029	.1372	.1372	.8573	1.0288	.6001	.4115
18		.1372	.1372	.1372	.1372		.1372
19		.1372	.1715	.1372	.1372	.1715	.1372
20		.1372	.1715	.1372	.1372	.1715	.1372
21		.1372	.1715	.1372	.0857	.1715	.1372
22		.1372	.1715	.1372	.0857	.1372	.1372
23		.6859	.4287	.5144	.1029	.1372	.1372
24	.6859	.8573	.6859	.5144	.1372	.1029	.1372
Max	1.0974	1.1145	1.166	.8573	1.0288	.6859	.4115
Min	.0857	.1029	.1372	.1372	.0857	.0857	.1372
Avg	.4401	.4165	.4108	.4865	.3273	.3019	.2143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467] BU 0467

Substation No/ Name :- 094013 / FAGANE

Feeder No / Name : 202 / VARKHEDE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5144	.4801	.0343	.0514	.0514	.0514
2	.5144	.5144	.4801	.0343	.0514	.0514	.0514
3	.5144	.6001	.4801	.0343	.0514	.0514	.0514
4	.5144	.6859	.5144	.0343	.0514	.0514	.0514
5	.6859	.7716	.6516	.0343	.0514	.0514	.0514
6	.9431	.8573	.823	.0343	.0514	.0686	.0514
7	.6173	1.0288	.8916	.0343	.0686	.0686	.0514
8	.4458	.6859	.5487	.0343	.0686	.0686	.0686
9	.0343	.0343	.0343	.0154	.0343	.0343	.0686
10	.0686	.0343	.0343	.0343	.0343	.0343	.0686
11	.0857	.0343	.0514	.0343	.0343	.0343	.0686
12	.1029	.0514	.0686	.0343	.0343	.0343	.0686
13	.1029	.0514	.0686	.0343	.0343	.0343	.0343
14	.1029	.0514	.0686	.0343	.0343	.0343	.0343
15	.12	.0514	.0686	.0343	.0343	.0343	.0343
16	.1029	.0514	.0686	.0343	.0343	.0343	.0343
17	.0857	.0514	.0514	.0343	.0343	.0343	.0343
18		.0343	.0343	.0343	.0343		
19		.0343	.0343	.0343	.0343	.0343	.0343
20		.0343	.0343	.0343	.0343	.0343	.0343
21		.0343	.0343	.0343	.0343	.0343	.0343
22		.0343	.0343	.0343	.0514	.0343	.0343
23		.4801	.0343	.0514	.0514	.0514	.0514
24	.5144	.5487	.4801	.0343	.0514	.0514	.0514
Max	.9431	1.0288	.8916	.0514	.0686	.0686	.0686
Min	.0343	.0343	.0343	.0154	.0343	.0343	.0343
Avg	.3372	.3029	.2529	.0342	.0436	.0440	.0484

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094013 / FAGANE

Feeder No / Name : 203 / ARNI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0686	.0857	.0686
2					.0686	.0857	.0686
3					.0686	.1029	.0686
4					.1029	.1029	.1029
5					.1372	.12	.1029
6					.1715	.12	.0857
7					.0686	.1715	.0686
8					.0686	.12	.0686
10	.0857	.1029	.0686				
11	.1029	.1029	.0686				
12	.1029	.0857	.12				
13	.1029	.0686	.1372				
14	.1029	.0857	.1372				
15	.0857	.1029	.1543				
16	.1029	.12	.1543				
17	.1029	.12	.1372				
23				.0686	.0857	.0514	.0686
24					.0686	.0857	.0514
Max	.1029	.12	.1543	.0686	.1715	.1715	.1029
Min	.0857	.0686	.0686	.0686	.0686	.0514	.0514
Avg	.0986	.0986	.1222	.0686	.0909	.1046	.0755

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467] BU 0467

Substation No/ Name :- 094013 / FAGANE

Feeder No / Name : 204 / VADJAI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4287			
2		.4287			
3		.4287			
4		.4287			
5		.5144			
6		.5144			
7		.5144			
8		.6001			
10		.6173	.2572	.4287	.4458
11		.5487	.4287	.6859	.4115
12		.4801	.8573	.6001	.3772
13		.4458	.8573	.5144	.3772
14		.4458	.6859	.5144	.3772
15		.4458	.4287	.5144	.3772
16		.3772	.4287	.5144	.3944
17		.3086	.6859	.2572	.4287
18		.3772			
23	.3429				
24		.4287			
Max	.3429	.6173	.8573	.6859	.4458
Min	.3429	.3086	.2572	.2572	.3772
Avg	.3429	.4630	.5787	.5037	.3987

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094013 / FAGANE

Feeder No / Name : 205 / 11 KV OM SHANTI EXP.

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.0514	.0514	.0514	.0857	.1029
2	.1715	.1715	.0514	.0514	.0514	.0857	.1029
3	.1715	.2058	.0514	.0514		.0686	.0857
4	.1715	.2058	.0514	.0514	.0686	.0686	.0686
5	.2058	.2058	.0514	.0514	.0686	.0686	.0686
6	.2058	.2401	.0514	.0514	.0686	.0686	.0514
7	.2401	.2401	.0514	.0514	.0686	.0686	.0514
8	.1715	.1715	.0686	.1029	.0686	.1029	.0686
9	.2058	.1372	.0686	.12	.0857	.1715	.0686
10	.2572	.1029	.1372	.12	.1029	.2058	.1029
11	.3086	.0686	.1372	.1372	.12	.2058	.1029
12	.3429	.0686		.1372	.1372	.1715	.1372
13	.3429	.0686	.12	.1372	.1372	.1715	.1715
14	.3429	.0686	.1029	.1372	.12	.2401	.1715
15	.3086	.0686	.1029	.1372	.12	.2572	.1886
16	.2572	.0686	.1029	.1372	.1029	.2572	.2058
17	.1715	.0686	.0857	.1029	.1372	.12	.1029
18		.0686	.0686	.0857	.12	.12	.1029
19		.0686	.0686	.0857	.1029	.0514	.0857
20		.0686	.0686	.0857	.0686	.0686	.0857
21		.0514	.0514	.0686	.0686	.1029	.0686
22		.0514	.0514	.0686	.0686	.1029	.0686
23		.0514	.0514	.0686	.0857	.0857	.0514
24	.1715	.0686	.0514	.0514	.0514	.0857	.0857
Max	.3429	.2401	.1372	.1372	.1372	.2572	.2058
Min	.1715	.0514	.0514	.0514	.0514	.0514	.0514
Avg	.2344	.1150	.0738	.0893	.0902	.1265	.1000

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094013 / FAGANE

Feeder No / Name : 206 / FAGANA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.4287	.4801	.4458	.4458	.4287	.4801
2	.4458	.4287	.4801	.4458	.4458	.4287	.4801
3	.4458	.463	.4801	.4458	.4458	.4458	.4458
4	.4458	.463	.4801	.4458	.463	.4458	.4801
5	.4115	.4801	.4801	.5144	.4801	.4458	.5144
6	.4115	.5144	.4801	.6001	.4801	.463	.5487
7	.4115	.5144	.4801	.6001	.4458	.4801	.5658
8	.4801	.2572	.4115	.5144	.4115	.4287	.5144
9	.4458	.3772	.4115	.4801	.4115	.5144	.4801
10	.4287	.4115	.4287	.4458	.4287	.5144	.4458
11	.4115	.4801	.4287	.3772	.463	.5144	.4115
12	.3429	.4801	.4801	.3429	.4801	.5144	.4115
13	.3772	.4801	.5144	.3772	.4801	.5144	.4115
14	.4287	.4801	.5144	.4115	.463	.5144	.4458
15	.4801	.4801	.5144	.4115	.4801	.5144	.4458
16	.3429	.4801	.5144	.4115	.5144	.5144	.4801
17	.4287	.4801	.5144	.4115	.4801	.5144	.4801
18		.5144	.5144	.4458	.5144		.5144
19		.5144	.6001	.4801	.6001	.6001	.5658
20		.5144	.6001	.5144		.583	.583
21		.4801	.5144	.5487	.6001	.5487	.6173
22		.4801	.4801	.4801	.5144	.5144	.5487
23		.4801	.4801	.4458	.5144	.5144	.5144
24	.4458	.4801	.4801	.4458	.4458	.4801	.5144
Max	.4801	.5144	.6001	.6001	.6001	.6001	.6173
Min	.3429	.2572	.4115	.3429	.4115	.4287	.4115
Avg	.4239	.4651	.4901	.4601	.4786	.4973	.4958

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094013 / FAGANE

Feeder No / Name : 207 / VADAJAI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.3429	.3944	.4287	.4287	.4287	.5144
2	.4115	.3429	.3944	.4287	.4287	.463	.4801
3	.4115	.3772	.3944	.4287	.4287	.5144	.4801
4	.4458	.3772	.4115	.4287	.4458	.5144	.5144
5	.4458	.4115	.4115	.5144	.4801	.5487	.5487
6	.4458	.4115	.4115	.5144	.5144	.583	.5487
7	.463	.4458	.4287	.5144	.4801	.583	.583
8	.4458	.5144	.4801	.5144	.4458	.4458	.583
9	.4287	.5144	.4458	.5144	.4287	.4287	.583
10	.4458	.5144	.4458	.5144	.4287	.4287	.583
11	.463	.5144	.463	.4801	.4115	.3944	.583
12	.4801	.4458	.5144	.4801	.4115	.4287	.583
13	.4801	.4115	.5144	.4801	.3772	.4287	.583
14	.463	.4458	.5144	.4801	.4115	.5144	.6001
15	.463	.4458	.5144	.4801	.4287	.6001	.6001
16	.4801	.4801	.5144	.4801	.4287	.6001	.6173
17	.5144	.5144	.4287	.4973	.4115	.4287	.6344
18		.4801	.4287	.4115	.4801		.6173
19		.4801	.5144	.4458	.5144	.4287	.6173
20		.4458	.6001	.4801	.5658	.4115	
21		.4287	.6001	.5144	.5144	.4115	.583
22		.4115	.5144	.4287	.5144	.4287	.5487
23		.4115	.4287	.4287	.4801	.4458	.5144
24	.4115	.4287	.4115	.4287	.4287	.4287	.4801
Max	.5144	.5144	.6001	.5144	.5658	.6001	.6344
Min	.4115	.3429	.3944	.4115	.3772	.3944	.4801
Avg	.4506	.4415	.4658	.4715	.4537	.4734	.5644

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094013 / FAGANE

Feeder No / Name : 208 / Varkheda Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0514	.0343	.0343	.0343	.0343	.0514
2	.0514	.0514	.0343	.0343	.0343	.0343	.0686
3	.0514	.0514	.0343	.0343	.0343	.0343	.0686
4	.0514	.0343	.0514	.0343	.0514	.0514	.0686
5	.0514	.0343	.0514	.0514	.0514	.0514	.0857
6	.0514	.0343	.0514	.0514	.0514	.0514	.0857
7	.0514	.0343	.0514	.0514	.0686	.0514	.0857
8	.0514	.0686	.0514	.0514	.0686	.0514	.0857
9	.0514	.0857	.0514	.0686	.0686	.0686	.0857
10	.0686	.1029	.0857	.0686	.0686	.0686	.0857
11	.0857	.1029	.1029	.0857	.0857	.0857	.0857
12	.1029	.0686	.1029	.0857	.0857	.1029	.0857
13	.1029	.0514	.1029	.0857	.1029	.1029	.0857
14	.0857	.0686	.0857	.0857	.1029	.1029	.0857
15	.0857	.0686	.0857	.0857	.1029	.12	.0857
16	.1029	.1029	.0686	.1029	.0857	.12	.1029
17	.12	.12	.0686	.1029	.12	.1029	.12
18		.1029	.0686	.0857	.1029		.1029
19		.1029	.0686	.0686	.0857	.0857	.0857
20		.0686	.0686	.0686	.0686	.0857	.0686
21		.0686	.0686	.0514	.0514	.0857	.0514
22		.0514	.0686	.0514	.0514	.0857	.0686
23		.0514	.0514	.0051	.0343	.0686	.0686
24	.0514	.0343	.0343	.0343	.0343	.0343	.0686
Max	.12	.12	.1029	.1029	.12	.12	.12
Min	.0514	.0343	.0343	.0051	.0343	.0343	.0514
Avg	.0705	.0672	.0643	.0616	.0686	.0730	.0807

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094031 / GONDUR

Feeder No / Name : 202 / 11 kv INDIRA GARDEN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7013		1.4632	1.4737	1.829	1.5546	1.4632
2	1.7013		1.2803	1.2136	1.6461	1.2803	1.2803
3	1.6289			1.0402			1.2803
4	1.3717		1.1888	1.0654			1.2803
5	1.2536			1.1393			1.2803
6	1.2536		1.2803	1.2203			1.3717
7	1.1641		1.1888	1.2203	1.1641		1.1888
8	1.1641	1.1888	1.0688	1.1331			
9		1.0974	1.0688			1.0974	
10		1.0974	1.247			1.0974	
11		1.0974	1.1542			1.0974	
12		1.0974	.5327			1.1888	
13		1.2803	.5316			1.1888	
14		1.4632	.5316			1.2803	
15		1.4632	.6201			1.3717	
16		1.2803	.6201			1.3717	
17		1.1888	1.1517	1.2536		1.0974	
18			1.046			1.2803	
19		1.2803	1.1331			1.4632	
20			1.2269			1.5546	
21		1.4632	1.4022				
22		1.4632	1.4899				
23		1.6461	1.6561	1.7013	1.6461	1.7375	
24	1.6118		1.6561		1.829	1.7375	1.5546
Max	1.7013	1.6461	1.6561	1.7013	1.829	1.7375	1.5546
Min	1.1641	1.0974	.5316	1.0402	1.1641	1.0974	1.1888
Avg	1.4278	1.2934	1.1154	1.2461	1.6229	1.3374	1.3374

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467] BU 0467

Substation No/ Name :- 094031 / GONDUR

Feeder No / Name : 204 / GONDUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572		.2743	.2601		.2743	.2743
2	.2575		.2743	.2601		.2743	.2743
3	.2572			.2615			.2743
4	.2572		.2743	.2615			.2743
5	.3086			.2615			.3658
6	.4115		.3658	.3467			.4572
7	.3086		.3658	.3487	.3841		.3658
8	.3086	.2743	.3551	.2663		.2743	
9		.2743	.2663			.2743	
10		.2743	.2663				
11		.2743	.2663			.2743	
12		.2743	.2663			.2743	
13		.2743	.2663				
14		.2743	.2658			.2743	
15		.2743	.2658				
16		.2743	.1772			.2743	
17		.2743	.1772	.2401			
18			.2663			.2743	
19		.3658	.2629			.4572	
20			.3467			.4207	
21		.3658	.3487				
22		.2743	.2615			.2743	
23		.2743	.2629	.2572		.2743	
24	.3258		.2615			.2743	.2743
Max	.4115	.3658	.3658	.3487	.3841	.4572	.4572
Min	.2572	.2743	.1772	.2401	.3841	.2743	.2743
Avg	.2991	.2874	.2790	.2764	.3841	.2978	.3200

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467] BU 0467

Substation No/ Name :- 094031 / GONDUR

Feeder No / Name : 403 / 33KV Incommmer (Gondur)
from 22 Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	15-JUN-18	17-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
24	2.1491	1.8546	1.6296
Max	2.1491	1.8546	1.6296
Min	2.1491	1.8546	1.6296
Avg	2.1491	1.8546	1.6296

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094038 / MEHARGAON

Feeder No / Name : 201 / 11 KV Navlane AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0663	.0671	.1174	.0343
2				.0663	.0671	.1006	.0343
3				.0829	.0671	.1006	.0514
4				.0829	.0857	.1174	.0526
5				.2486	.3086	.3353	.0537
6				.3294	.4458	.4458	.1433
7				.4239	.5316	.5087	.2774
8				.213	.3429	.2949	.1543
10	.0838	.128	.1966				
11	.4144	.3768	.3605				
12	.3149	.3277	.3077				
13	.1966	.2949	.2591				
14	.2321	.2915	.1943				
15	.2012	.2622	.253				
16	.2652	.2267	.253				
17	.3277	.2401	.2343				
23			.0686	.0686	.1147	.0354	.0532
24				.0686	.0686	.116	.0351
Max	.4144	.3768	.3605	.4239	.5316	.5087	.2774
Min	.0838	.128	.0686	.0663	.0671	.0354	.0343
Avg	.2545	.2685	.2363	.1651	.2099	.2172	.0890

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094038 / MEHARGAON

Feeder No / Name : 202 / MEHERGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.1677	.2035	.1823	.1677	.1677	.2058
2	.2572	.1677	.2543	.1823	.1677	.1844	.2058
3	.3086	.1844	.3429	.1823	.1677	.1844	.2058
4	.3772	.1844	.3772	.1823	.1886	.2012	.2454
5	.4334	.3429	.4508	.3647	.3772	.4024	.3224
6	.5028	.4458	.5028	.5201	.5144	.5316	.5731
7	.39	.373	.3944	.407	.4115	.39	.4161
8	.2785	.2515	.2984	.2949	.3258	.2949	.3086
9	.2241	.2772	.2772	.2743	.2378	.2561	.2402
10	.218	.16	.213	.1509	.218	.2155	.2204
11	.1658	.1802	.1802	.1865	.1989	.1802	.1658
12	.1492	.1638	.1619	.1865	.1823	.1844	.1823
13	.1802	.1638	.1781	.1658	.1823	.1658	.1823
14	.1823	.1619	.1781	.1844	.2012	.2012	.1638
15	.2012	.1802	.1739	.1865	.1989	.1865	.1966
16	.1989	.2105	.1581	.2012	.1989	.213	.1943
17	.1966	.176	.1562	.2155	.213	.2347	.208
18	.2629	.2658	.2149	.2658	.2865	.3881	.2715
19	.3921	.3881	.3258	.3142	.4066	.4481	.4294
20	.4108		.4668	.4108	.3696	.3921	.4294
21	.2987	.2801	.2772	.2801	.2772	.2987	.2987
22	.2241	.2218	.2241	.2241	.2402	.2614	.2614
23	.1844	.1844	.1886	.1715	.1802	.2303	.2303
24	.1326	.1677	.1677	.1886	.1715	.1658	.2103
Max	.5028	.4458	.5028	.5201	.5144	.5316	.5731
Min	.1326	.16	.1562	.1509	.1677	.1658	.1638
Avg	.2656	.2304	.2653	.2468	.2535	.2658	.2653

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094038 / MEHARGAON

Feeder No / Name : 203 / 11 KV Deshmukhwadi Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.116	.2515		.0514
2				.116	.2347	.1677	.0514
3				.1326	.2012	.1844	.0514
4				.1492	.2058	.2012	.0526
5				.3315	.3601	.3688	.0537
6				.5375	.583	.583	.2328
7				.4578	.6344	.5087	.4161
8				.3277	.463	.4752	.3086
10	.2012	.192	.213				
11	.4973	.426	.5079				
12	.5138	.4096	.4696				
13	.4588	.4588	.502				
14	.4641	.4049	.4049				
15	.3521	.4096	.3953				
16	.3812	.3563	.4111				
17	.3605	.3201	.4062				
23			.12	.2229	.1802	.0709	.0532
24				.12	.2572	.2321	.0701
Max	.5138	.4588	.5079	.5375	.6344	.583	.4161
Min	.2012	.192	.12	.116	.1802	.0709	.0514
Avg	.4036	.3722	.3811	.2511	.3371	.3102	.1341

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094038 / MEHARGAON

Feeder No / Name : 204 / 11 Kv Tilenagar AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	.9221	1.153	.2486	.2515	.2515	.2915
2	1.1145	.9054	1.2717	.2486	.2515	.2515	.2915
3	1.2003	.9054	1.3717	.2486	.2683	.2683	.2915
4	1.4575	.9054	1.6289	.2652	.2743	.2683	.3155
5	1.5604	1.2003	1.7337	.3315	.3429	.3353	.3582
6	1.8898	1.869	2.0285	.4508	.4458	.463	.5014
7	1.7974	1.95	1.8176	.3561	.3429	.373	.3988
8	1.2452	1.3413	1.3426	.2622	.3086	.2949	.3086
9	.2801	.2587	.2218	.2561	.2561	.2926	.2957
10	.218	.208	.1966	1.0059	1.0562	.9614	.5087
11	.2321	.2458	.213	1.7804	1.5083	.9831	.5138
12	.2321	.1966	.2267	2.0008	1.5415	1.5089	.6464
13	.2294	.2458	.2267	1.5912	1.5912	1.442	.5801
14	.2652	.2591	.2429	1.4419	1.5089	1.3748	.5735
15	.2683	.2622	.2688	1.4074	1.3916	1.2717	.5407
16	.2486	.2591	.2372	1.358	1.4089	.8192	.5992
17	.2458	.2241	.2343	1.4089	1.4255	.57	.7042
18	.2454	.2658	.2507	.3012	.3045	.3326	.362
19	.3547	.2957	.3077	.3696	.3511	.4108	.4294
20	.4294		.4481	.4294	.4251	.4481	.4481
21	.4108	.3921	.3881	.4108	.4066	.4294	.4108
22	.3361	.3326	.3326	.3734	.3696	.3921	.3921
23	.9221	.8383	.2743	.2915	.3109	.3366	.3012
24		.9221	.9221	.2572	.2743	.2957	.3155
Max	1.8898	1.95	2.0285	2.0008	1.5912	1.5089	.7042
Min	.218	.1966	.1966	.2486	.2515	.2515	.2915
Avg	.7049	.6611	.7225	.7123	.6923	.5990	.4324

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094043 / DEOBHANE(DHODI)

Feeder No / Name : 201 / 11 KV Vadel AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2439	.5144	.8574	.1524
2				.2439	.5144	1.0288	.1829
3				.2743		1.2002	.1829
4				.3353		1.3718	.1829
5				.4268		2.2634	.2134
6				1.0136		3.155	.2134
7				1.0802		3.2922	.2743
8				.9602		2.572	.2439
10	.6344	.7621	.823				
11	1.3717	1.4327	1.0288				
12	1.5432	1.3717	1.166				
13	1.3375	1.2803	1.1317				
14	1.2346	1.0059	1.2003				
15	1.1145	1.0059	1.2517				
16	1.2003	.823	1.3032				
17	1.0802		1.3032				
23			.3772	.4877	.4973	.2058	.1829
24				.3772	.4877	.5487	.2058
Max	1.5432	1.4327	1.3032	1.0802	.5144	3.2922	.2743
Min	.6344	.7621	.3772	.2439	.4877	.2058	.1524
Avg	1.1896	1.0974	1.0650	.5443	.5035	1.6495	.2035

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094043 / DEOBHANE(DHODI)

Feeder No / Name : 202 / 11 KV Dhamane AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3048		.3429	.3048
2				.3048		.4115	.3048
3				.3353		.4458	.3048
4				.2934		.5144	.3048
5				.3201		.583	.3048
6				.5601		.703	.3658
7				.6401		.7202	.3658
8				.5868		.7545	.4268
10	.6001	.4572	.5487				
11	.6859	.6249	.7888				
12	.9774	.5792	.6859				
13	.9945	.5792	.6859				
14	.9945	.5639	.703				
15	1.0425	.6401	.6859				
16	.9774	.6554	.6516				
17	.9088	.6859	.6859				
23			.4115	.4572	.463	.3429	.3048
24				.3772	.4572	.4973	.3429
Max	1.0425	.6859	.7888	.6401	.463	.7545	.4268
Min	.6001	.4572	.4115	.2934	.4572	.3429	.3048
Avg	.8976	.5982	.6497	.4180	.4601	.5316	.3330

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094043 / DEOBHANE(DHODI)

Feeder No / Name : 203 / Govinda Gas Ex. Feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1372	.1372	.0343			.0171
2		.1372	.1372	.12			.0171
3		.12	.1372	.1372			.0171
4		.0857	.1029	.1372			.0171
5		.0514	.0343	.1372			.0171
6		.0343	.0343	.1372		.0457	.0171
7		.0343	.0343	.0514		.0305	.1372
8		.0343	.0343	.0343		.0343	.0343
9	.0343	.0343	.0343	.0343	.0343	.0343	.0343
10	.0343	.0343	.0343	.0343	.0343	.0343	.0343
11	.1543	.0343	.0343	.0343	.0514	.0343	.0343
12	.1372	.0343	.0343	.0343	.0514	.0343	.0343
13	.1372	.0343	.0343	.12		.0343	.1543
14	.12	.0343	.0514	.12	.2058	.0343	.1543
15	.1029	.1372	.12	.12	.2058	.0857	.1543
16	.12	.1372	.12	.1372		.1372	.1543
17	.12	.1372	.1372	.1372	.2229	.1372	.1372
18	.12	.1372	.1372	.12		.1372	.1372
19	.1219	.1372	.1372	.12	.2058	.1372	.1372
20	.1067	.1372	.1372	.1372	.2058	.1372	.1372
21	.1067	.1372	.12	.1372	.2058	.1372	.1372
22	.1372	.1372	.0857	.12	.1372	.1372	.1372
23	.1372	.1372	.0343	.12		.1372	.1372
24	.1372	.1543	.1372	.0343	.12		.12
Max	.1543	.1543	.1372	.1372	.2229	.1372	.1543
Min	.0343	.0343	.0343	.0343	.0343	.0305	.0171
Avg	.1142	.0929	.0850	.0979	.1400	.0833	.0879

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094043 / DEOBHANE(DHODI)

Feeder No / Name : 204 / Ex. Jay Laxmi Fiber Ltd.

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0171	.0171	.0171		.0171	.0171
2		.0171	.0171	.0171		.0171	.0171
3		.0171	.0171	.0171		.0171	.0171
4		.0171	.0171	.0171		.0171	.0171
5		.0171	.0171	.0171		.0171	.0171
6		.0171	.0171	.0171		.0171	.0171
7		.0171	.0171	.0171		.0171	.0171
8		.0171	.0171	.0171		.0171	.0171
9	.0152	.0171	.0171	.0171	.0152	.0171	.0171
10	.0152	.0171	.0171	.0171	.0152	.0171	.0171
11	.0152	.0171		.0171	.0152	.0171	.0171
12	.0152	.0171	.0171	.0171	.0152	.0171	.0171
13	.0152	.0171	.0171	.0171	.0152	.0171	.0171
14	.0152	.0171	.0171	.0171	.0152	.0171	.0171
15	.0152	.0171	.0171	.0171	.0152	.0171	
16	.0152	.0171	.0171	.0171	.0152	.0171	
17	.0152	.0171	.0171	.0171	.0152	.0171	
18	.0152	.0171	.0171	.0171	.0171	.0171	
19	.0171	.0171	.0171	.0171	.0152	.0171	
20	.0171	.0171	.0171	.0171	.0152	.0171	
21	.0171	.0171	.0171	.0171	.0152	.0171	
22	.0171	.0171	.0171	.0171	.0152	.0171	
23	.0171	.0171	.0171	.0171	.0171	.0171	
24	.0171		.0171	.0171	.0171	.0152	.12
Max	.0171	.0171	.0171	.0171	.0171	.0171	.12
Min	.0152	.0171	.0171	.0171	.0152	.0152	.0171
Avg	.0159	.0171	.0171	.0171	.0156	.0170	.0240

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094043 / DEOBHANE(DHODI)

Feeder No / Name : 205 / 11 KV Dhamane Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.12	.0857	.1029		.1029	.1029
2		.12		.1029		.1029	.12
3		.12	.0857	.1029		.1029	.1372
4		.12	.1029	.1372		.12	.12
5		.12	.1372	.1715		.1372	.12
6		.1543	.1715	.1715		.12	.1543
7		.1372	.12	.1372		.12	.1543
8		.1029	.1372	.1372		.1372	.1372
9	.12	.12	.12	.12	.12	.12	.12
10	.12	.1372	.12	.12	.1029	.12	.12
11	.12	.12	.12	.12	.1029	.12	.1029
12	.1372	.12	.12	.12	.12	.12	.1029
13	.1372	.12	.12	.12	.12	.1029	.1029
14	.12	.1372	.12	.12	.12	.1029	.1029
15	.1029	.1372	.12	.12	.1372	.12	.1029
16	.12	.1372	.12	.12	.1372	.1372	.0857
17	.12	.1372	.12	.12	.1543	.12	.12
18	.12	.1372	.12	.12	.1372	.12	.1372
19	.1372	.1372	.12	.1372	.1372	.1372	.1543
20	.1372	.1372	.1543	.1372	.1715	.1372	.1372
21	.12	.12	.1372	.12	.1543	.1372	.1372
22	.12	.12	.12	.12	.12	.1372	.12
23	.12	.12	.1029	.12	.12	.1029	.1372
24	.12	.12	.12	.1029	.12	.1029	.1029
Max	.1372	.1543	.1715	.1715	.1715	.1372	.1543
Min	.1029	.1029	.0857	.1029	.1029	.1029	.0857
Avg	.1232	.1272	.1215	.1250	.1297	.1200	.1222

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094043 / DEOBHANE(DHODI)

Feeder No / Name : 206 / 11 Kv Gangamai Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2896	.2743	.3086		.3086	.3086
2		.3601	.2743	.3086		.3429	.2743
3		.4287	.2743	.3772		.3429	.3086
4		.463	.3429	.4115		.3429	.3429
5		.4801	.4801	.5144		.3772	.4115
6		.5487	.5487	.6173		.3772	.4801
7		.4973	.4973	.5487		.3944	.5144
8		.463	.4458	.4801		.3772	.4115
9	.3772	.4115	.3772	.4115	.463	.3601	.4115
10	.3429	.4115	.3429	.3772	.4115	.3772	.3772
11	.2743	.3258	.3429	.3601	.3944	.3772	.3772
12	.3429	.3429	.3429	.3429	.4115	.3772	.3601
13	.3601	.3429	.4115	.3429	.3429	.3944	.3601
14	.3944	.3772	.3772	.3601	.4115	.3772	.3601
15	.3944	.3772	.3772	.3772	.4287	.4115	.3601
16	.3772	.1372	.3772	.3772	.4458	.3944	.3772
17	.3772	.1372	.3772	.4115	.4287	.3944	.4458
18	.4115	.4458	.3772	.4458	.5144		.4458
19	.3772	.463	.4115	.4801	.4801	.2743	.4973
20	.4801	.5316	.4801	.4801	.5487	.5144	.5144
21	.3429	.4287	.4115	.4287	.4458	.5144	.4115
22	.2915	.3429	.3429	.3772	.3258	.3772	.3429
23	.3086	.3258	.3086	.3429	.3429	.3429	.3429
24	.2743	.3086	.3258	.3086	.3086		.3429
Max	.4801	.5487	.5487	.6173	.5487	.5144	.5144
Min	.2743	.1372	.2743	.3086	.3086	.2743	.2743
Avg	.3579	.3850	.3801	.4079	.4190	.3796	.3908

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094052 / 33/11 KV Lamkani S/S

Feeder No / Name : 201 / 11 KV saitale Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	20-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.267	1.4632	1.286		
2	1.1765	1.7375	1.3717		
3	1.2536	1.829	1.4575		
4	1.3432	2.0328	1.5432		
5	1.4899	2.2177	1.7147		
6	1.7528	2.4025	2.1434		
7		2.4025	1.9719		
8	1.7147	1.9605	1.7147		
10				1.3432	1.4175
11					2.0595
12				1.7528	1.8604
13				1.9281	1.7909
14				1.8004	1.7013
15				1.7147	1.6832
16				1.8004	1.5947
17				1.949	
23	1.3432	1.0288			
24	1.267	1.3717	1.286		
Max	1.7528	2.4025	2.1434	1.949	2.0595
Min	1.1765	1.0288	1.286	1.3432	1.4175
Avg	1.4009	1.8446	1.6099	1.7555	1.7296

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094052 / 33/11 KV Lamkani S/S

Feeder No / Name : 202 / 11KV Rudane Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1164	1.1517	1.1765	1.267
2				1.2403	1.1517	1.1765	1.3717
3				1.2403	1.2403	1.2269	1.5546
4				1.3146	1.4899	1.4899	1.7556
5				1.4575	1.7528	1.5432	1.848
6				1.7147	1.8861	1.8004	1.9605
7				1.7147	1.7147	1.7147	1.8671
8				1.4022	1.5775	1.5432	
10	1.7147	1.6289	1.3432				
11	2.0748	1.8861					
12	1.8861	1.7147					
13	1.7718	1.5432	1.7147				
14	1.7013	1.4575	1.7147				
15	1.7375	1.3717	1.7528				
16	1.6632	1.286	1.3432				
17	1.6804	1.3717	1.3575				
23			1.0974	1.086		.8478	
24				1.1641	1.1765	1.1765	1.0517
Max	2.0748	1.8861	1.7528	1.7147	1.8861	1.8004	1.9605
Min	1.6632	1.286	1.0974	.1164	1.1517	.8478	1.0517
Avg	1.7787	1.5325	1.4748	1.2451	1.4601	1.3696	1.5845

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094052 / 33/11 KV Lamkani S/S

Feeder No / Name : 203 / 11 kV Lamkani AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				2.2386	2.1262	1.9909	1.8099
2				2.1262	2.1262	1.97	2.0119
3				2.1262	2.1262	2.1033	2.1948
4				2.191	2.191	2.191	2.4025
5				2.3148	2.2291	2.2291	2.4025
6				2.4863	2.4006	2.4006	2.2405
7				2.3148	2.4863	2.4006	2.0538
8				2.191	2.2786	2.4006	
10	2.4006	2.1434	2.0595				
11	2.452	2.4006					
12	2.6406	2.4006					
13	2.4806	2.3148	2.4006				
14	2.4177	2.4006	2.3148				
15	2.4691	2.2291	2.3663				
16	2.6797	2.2291					
17	2.7073	2.0576	2.2624				
23			2.1948	1.9004		1.4413	
24				2.2386	1.9909	1.9909	1.5775
Max	2.7073	2.4006	2.4006	2.4863	2.4863	2.4006	2.4025
Min	2.4006	2.0576	2.0595	1.9004	1.9909	1.4413	1.5775
Avg	2.5310	2.2720	2.2664	2.2128	2.2172	2.1118	2.0867

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094052 / 33/11 KV Lamkani S/S

Feeder No / Name : 204 / 11 KV Lamkani Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4525	.5487	.5144	.5373	.5373	.543	.543
2	.4525	.5487	.5144	.5373	.5316	.543	.5487
3	.4477	.5544	.6001	.6201	.6201	.5258	.5487
4	.6268	.8316	.6859	.7888	.7087	.7011	.8316
5	.7011	1.1088	.8573	1.0517	.8573	.8573	1.1088
6	.964	1.2012	1.0288	1.2003	1.0288	1.1145	1.4003
7	.8573	1.0164	1.0288	1.1145	1.0288	1.0288	1.0269
8	.8573	1.0269	.7716	.964	.8764	.9431	
9	.7716		.823	.823	.823	.905	
10	.6859	.6859	.7164	.8059		.7973	
11		.6859				.7164	
12		.6516		.7888		.7087	
13	.5316	.6001	.6001	.7011		.7164	
14	.5373	.6001		.6859		.7164	
15	.5487	.5144	.6135	.6859		.7087	
16	.6468	.4287		.6859		.7973	
17	.7468	.5144		.7087		.7116	
18	.7373	.6859	.924	.823		1.0402	
19	1.0288	1.0288	.924	1.1088		1.1888	
20	.9431	.8573	1.0269	1.2936		1.086	
21	.7716	.6859	.9335	1.0269		.7973	
22	.6783		.7392	.6535		.7087	
23	.6268	.5144	.5487	.543		.5935	
24	.4525	.5487	.4287	.5373	.543	.543	.5258
Max	1.0288	1.2012	1.0288	1.2936	1.0288	1.1888	1.4003
Min	.4477	.4287	.4287	.5373	.5316	.5258	.5258
Avg	.6848	.7199	.7515	.8124	.7555	.7913	.8167

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094063 / 33/11 KV KAPDANE

Feeder No / Name : 201 / 11KV NEW KAPDANE GT

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.4458	.4306	.4468	.4458	.4801	.463
2	.4287	.4458	.4477	.4468	.4458	.4458	.463
3	.4287	.4801	.4468	.4812	.4801	.4458	.463
4	.463	.4801	.5155	.5843	.5144	.4801	.4973
5	.463	.5487	.5499	.5843	.583	.5144	.4973
6	.4801	.6859	.5499	.5499	.5487	.6173	.5487
7	.3944	.5487	.464	.4812	.5144	.5144	.4973
8	.463	.4801	.4812	.4468	.5144	.4801	.463
9	.463	.4468	.464	.3864	.4801	.4458	.4468
10	.4801	.4296	.4468	.4287	.4801	.4458	.4468
11	.4458	.4296	.4468	.4287	.5144	.463	.4296
12	.4801	.4468	.464	.4458	.4801	.4801	.4296
13	.463	.4468	.464	.4801	.4801	.4973	.4124
14	.4801	.4296	.4812	.4801	.4801	.5144	.4124
15	.4801	.4296		.4801	.4458	.5144	.4296
16	.5144	.4468		.5144	.4801	.5144	.4812
17	.5144	.4812	.5155	.5144	.4801	.4801	.4812
18	.4801	.4812	.5155	.5144	.5144	.5144	.5155
19	.5487	.4984	.5499	.5487	.5487	.5316	.5843
20	.6173	.5499	.5843	.583	.583	.5658	.5843
21	.583	.5499	.5155	.5487	.5144	.5658	.5499
22	.5487	.5155	.4995	.5144	.4801	.5144	.5499
23	.5144	.4812	.4822	.4801	.4458	.4973	.465
24		.4458	.4468	.4835	.4458	.4973	
Max	.6173	.6859	.5843	.5843	.583	.6173	.5843
Min	.3944	.4296	.4306	.3864	.4458	.4458	.4124
Avg	.4853	.4843	.4892	.4939	.4958	.5008	.4831

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094063 / 33/11 KV KAPDANE

Feeder No / Name : 202 / 11KV NEW KAPDANE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8173	.8573	.7429				
2	.6687	.7888	.807				
3	.8173	.7202	.807				
4	.9659	1.0288	.8743				
5	1.1145	1.2689	1.0088				
6	1.2631	1.4232	1.2106				
7	1.4861	1.5432	1.3432				
8	1.1145	1.3717	1.276				
10				.6687	.8573	1.0402	.4607
11				.8916	1.0288	1.4118	.5361
12				.8916	.9259	1.2631	.5348
13				.8173		1.1145	.6876
14				.8173	.9259	1.0402	.8393
15				.743		1.1888	.9919
16					1.0288	1.1888	.9146
17					.9945	.5944	.8393
18				.5944			
23	.9431	.7678					
24		1.0288	.8446				
Max	1.4861	1.5432	1.3432	.8916	1.0288	1.4118	.9919
Min	.6687	.7202	.7429	.5944	.8573	.5944	.4607
Avg	1.0212	1.0799	.9905	.7748	.9602	1.1052	.7255

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094063 / 33/11 KV KAPDANE

Feeder No / Name : 203 / 11KV DHANUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.8743	.9659	1.5432	.743
2				.8743	.9659	1.406	.743
3				1.0074	1.1145	1.3717	.8173
4				1.0059	1.1145	1.3032	.9659
5				1.1401	1.2631	1.4575	1.0402
6				1.2742	1.4118		1.1145
7				1.3413	1.6347	1.6461	1.2186
8				1.1971	1.3717	1.5775	1.0402
10	1.2003	1.1517	1.0806				
11	1.2346	1.1482	1.2778				
12	1.3717	1.2778	1.4775				
13	1.3032	1.4103	1.5468				
14	1.2346	1.4083	1.5446				
15		1.3375	1.4754				
16	1.3717	1.276	1.5468				
17	1.406	1.3451	1.3182				
23			.9981	.9659	1.7147	.6687	.382
24				1.0736	.9659	.6687	
Max	1.406	1.4103	1.5468	1.3413	1.7147	1.6461	1.2186
Min	1.2003	1.1482	.9981	.8743	.9659	.6687	.382
Avg	1.3032	1.2944	1.3629	1.0754	1.2523	1.2936	.8961

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467] BU 0467

Substation No/ Name :- 094063 / 33/11 KV KAPDANE

Feeder No / Name : 401 / 33KV Incommmer (Kapadne)
from 2 Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	17-JUN-18	18-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
7		2.1139	
18	1.3048		
22			.6922
Max	1.3048	2.1139	.6922
Min	1.3048	2.1139	.6922
Avg	1.3048	2.1139	.6922

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094064 / 33/11 KV Burzad Stn

Feeder No / Name : 201 / 11 KV Vadane Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.426	.5087	.5256				
2	.426	.5087	.5087				
3	.4424	.5087	.5087				
4	.4588	.5087	.5087				
5	.5243	.5256	.5256				
6	.7209	.6443	.7122				
7	.5898	.6274	.6952				
8	.5735	.5426	.6443				
10				.4239	.4748	.39	.3222
11				.5256	.5596	.5935	.5765
12				.6443	.6443	.5765	.5596
13				.6274	.6274	.5765	.5256
14				.5935	.5426	.5765	.5596
15				.6274	.5426	.5935	.5935
16				.6443	.6104	.5935	.5735
17				.6783	.6274	.5596	.5735
23	.4748	.4915					
24	.426	.5087	.5079				
Max	.7209	.6443	.7122	.6783	.6443	.5935	.5935
Min	.426	.4915	.5079	.4239	.4748	.39	.3222
Avg	.5063	.5375	.5708	.5956	.5786	.5575	.5355

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094064 / 33/11 KV Burzad Stn

Feeder No / Name : 202 / 11 KV Burzad Single

SINGLE PHASING

Phasing. Feeder KV- 11 /
OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.8059	.9774	.823	.5596
2				.8059	.9945	.823	.5596
3				.8573	1.0631	.9259	.5596
4				1.0117	1.3203	1.046	.5596
5				1.2689	1.406	1.2346	.8817
6				1.3032	1.4232	1.3546	.9326
7				1.2346	1.3032	1.406	.8817
8				1.1022	1.153	1.153	.9156
10	1.2289	1.2378	1.0682				
11	1.5729	1.6108	1.4413				
12	1.3927	1.4922	1.3904				
13	1.2944	1.3565	1.3565				
14	1.278	1.2887	1.3226				
15	1.278	1.2887	1.2717				
16	1.3927	1.2887	1.3056				
17	1.3435	1.2289	1.4074				
23			.7716	.9835	.78	.5596	.4752
24				.8402	1.0288	.8059	.5765
Max	1.5729	1.6108	1.4413	1.3032	1.4232	1.406	.9326
Min	1.2289	1.2289	.7716	.8059	.78	.5596	.4752
Avg	1.3476	1.3490	1.2595	1.0213	1.1450	1.0132	.6902

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094064 / 33/11 KV Burzad Stn

Feeder No / Name : 203 / 11 KV Burzad Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1457	.1526	.1357	.1543	.3069	.1372	.1526
2	.1475	.1526	.1357	.1543	.3069	.1372	.1526
3	.1475	.1696	.1526	.1715	.4093	.1715	.1526
4	.1638	.1865	.1696	.2401	.5798	.2572	.1696
5	.213	.2204	.2035	.3258	.7844	.3772	.3391
6	.3441	.39	.39	.3601	.8526	.4115	.39
7	.2949	.3561	.3391	.3429	.7162	.3258	.3052
8	.2785	.2713	.2713	.5115	.2883	.2883	.2883
9	.1802	.2374	.2204	.2374	.3052	.2883	.2883
10	.1966	.2035	.2035	.1696	.2204	.1865	.1696
11	.1802	.1696	.2035	.1696	.1865	.1865	.1357
12	.1966	.1526	.1865	.1526	.1526	.2035	.1526
13	.1802	.1526	.1865	.1696	.1526	.1865	.1526
14	.1966	.1865	.1865	.1865	.1865	.1865	.1696
15	.1802	.2204	.1865	.1865	.1865	.1865	.1696
16	.1802	.2543	.2035	.1865	.2204	.1696	.1802
17	.2294	.1802	.2204	.1865	.2204	.1696	.1802
18	.2294	.1966	.2204	.2204	.2713	.1865	.1966
19	.2785	.2622	.2035	.2883	.2883	.2883	.2785
20	.2785	.2785	.2035	.2713	.3222	.2374	.213
21	.2204	.1966	.2204	.2204	.2204	.1865	.1943
22	.1865	.1475	.2204	.1696	.1696	.1696	.1802
23	.1696	.1311	.1715	.1526	.1357	.1696	.1619
24	.1475	.1526	.1296	.1543	.3069	.1372	.1526
Max	.3441	.39	.39	.5115	.8526	.4115	.39
Min	.1457	.1311	.1296	.1526	.1357	.1372	.1357
Avg	.2069	.2092	.2068	.2243	.3246	.2185	.2052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094064 / 33/11 KV Burzad Stn

Feeder No / Name : 406 / 33KV Incommmer (Burzad)
from 22 Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	16-JUN-18	17-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
24	.7122	.6882	.763
Max	.7122	.6882	.763
Min	.7122	.6882	.763
Avg	.7122	.6882	.763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094069 / 33/11 KV Varkhede

Feeder No / Name : 201 / VANI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.4108	.3441	.3201	.0686
2				.4108	.3605	.3201	.0857
3				.3921	.3605	.3353	.0857
4				.3921	.3768	.3353	.1029
5				.3921	.4096	.3506	.1029
6				.4481	.4752	.3506	.1029
7				.5041	.4588	.3506	.12
8				.4668	.3768	.3963	.1372
10	.4115	.5144	.2241				
11	.5335	.6516	.6722				
12	.5639	.6173	.7468				
13	.5487	.6173	.7095				
14	.5792	.6001	.6722				
15	.5792	.6173	.6348				
16	.5487	.6344	.6535				
17	.4877	.6687	.6535				
23			.3921	.2785	.2591	.0686	.0934
24				.3277		.2591	.0686
Max	.5792	.6687	.7468	.5041	.4752	.3963	.1372
Min	.4115	.5144	.2241	.2785	.2591	.0686	.0686
Avg	.5316	.6151	.5954	.4023	.3802	.3087	.0968

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094069 / 33/11 KV Varkhede

Feeder No / Name : 202 / Verkhedi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.3801	.3258	.3734	.3429	.3439	.3429
2	.362	.3801	.3258	.3734	.3601	.362	.3772
3	.3982	.3801	.3429	.3734	.3601	.362	.3944
4	.4344	.3801	.3772	.3734	.3772	.4525	.4115
5	.4525	.3801	.3772	.3734	.4287	.5068	.4287
6	.4706	.4344	.4115	.6535	.6173	.6878	.4287
7	.6154	.6697	.5144	.7468	.6344	.6335	.3944
8	.4887	.7059	.583	.6535	.6173	.4706	.3086
9	.4344	.6878	.463	.6348	.583	.5658	.2915
10	.3982	.6344	.3921	.5792	.5792	.5487	.3174
11	.3801	.6344	.5228	.5973	.5792	.5487	.3361
12	.3801	.5658	.2241	.6154	.5973	.5487	.3734
13	.543	.4973	.6535	.3982	.5973	.5487	.3547
14	.543	.6001	.6722	.5792	.5973	.5658	.3547
15	.543	.6173	.6908	.6516	.5973	.583	.3547
16	.6516	.583	.6535	.6516	.6154	.6001	.3547
17	.6516	.583	.6348		.6154	.6001	.3734
18	.6335	.5487	.6348		.5611	.3086	.3921
19	.5611	.5487	.6161	.6173	.6154	.3258	.3921
20	.4344	.4801	.6348	.6859	.6335	.3429	.3734
21	.4163	.4287	.4294	.4287	.3801	.3429	
22	.3801	.3429	.4108	.3944	.362	.3429	
23	.3801	.3258	.3734	.3601	.362	.3429	
24		.3801	.3258	.3429		.3439	.3429
Max	.6516	.7059	.6908	.7468	.6344	.6878	.4287
Min	.362	.3258	.2241	.3429	.3429	.3086	.2915
Avg	.4745	.5070	.4829	.5208	.5223	.4699	.3665

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094069 / 33/11 KV Varkhede

Feeder No / Name : 203 / 11 Varkheda Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0747	.0819	.0914	.0343
2				.056	.0819	.0914	.0343
3				.0747	.0819	.0914	.0343
4				.0747	.0819	.0914	.0343
5				.0747	.0983	.0914	.0343
6				.0747	.0983	.0914	.0343
7				.0934	.0983	.1219	.0343
8				.0934	.0983	.0914	.0343
10	.1067	.1029	.1307				
11	.1372	.1543	.168				
12	.1524	.1372	.1494				
13	.1524	.1372	.1307				
14	.1372	.12	.1307				
15	.1219	.1372	.1307				
16	.1219	.1372	.1494				
17	.1219	.1372	.1494				
23			.056	.0655	.0762	.0343	.0373
24				.0819		.0914	.0343
Max	.1524	.1543	.168	.0934	.0983	.1219	.0373
Min	.1067	.1029	.056	.056	.0762	.0343	.0343
Avg	.1315	.1329	.1328	.0764	.0886	.0887	.0346

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094016 / 33/11 KV DEOPUR

Feeder No / Name : 201 / 11KV DEOPUR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	1.7147	1.7147	1.5432	1.7147		
2	1.6289	1.6289	1.6289	1.4575	1.5432		
3	1.5432	1.5432	1.5432	1.3717	1.5432		
4	1.4575	1.5432	1.4575	1.3717	1.4575		
5	1.4575	1.4575	1.3717	1.3717	1.3717		
6	1.3717	1.4575	1.3717	1.3717	1.3717		
7	1.3717	1.4575	1.286	1.3717	1.286		
8	1.3717	1.4575	1.286	1.286	1.286		
9	1.286	1.286	1.286	1.3717		1.3717	1.3717
10	1.286	1.286	1.3375	1.286		1.286	1.3717
11	1.3717	1.286	1.3717	1.286		1.3717	1.3717
12	1.5432	1.3717	1.3717	1.286		1.5432	1.3717
13	1.5432	1.3717	1.3717	1.286		1.4575	1.4575
14	1.5432	1.4575	1.4575	1.4575		1.4575	1.4575
15	1.5432	1.4575	1.4575	1.4575		1.5432	1.4575
16	1.5432	1.3717	1.4575	1.4575		1.5432	1.7147
17	1.4575	1.286	1.286	1.3717			1.5432
18	1.4575	1.286	1.2003	1.286			1.4575
19	1.4575	1.286	1.286	1.4575			1.6289
20	1.6289	1.5432	1.5432	1.7147			
21	1.7147	1.5432	1.6289	1.7147			1.5432
22	1.7147	1.6289	1.6289	1.8004			1.7147
23	1.8861	1.7147	1.7147	1.8861			1.7147
24	1.8004	1.8004	1.7147	1.6289	1.8004		
Max	1.8861	1.8004	1.7147	1.8861	1.8004	1.5432	1.7147
Min	1.286	1.286	1.2003	1.286	1.286	1.286	1.3717
Avg	1.5289	1.4682	1.4489	1.4539	1.4860	1.4468	1.5126

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094016 / 33/11 KV DEOPUR

Feeder No / Name : 202 / 11KV PAROLA ROAD (OLD)

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1029	.12	
2	.1372	.12	.12	
3	.1372	.12	.12	
4	.1372	.12	.12	
5	.1372	.12	.12	
6	.1372	.1543	.1372	
7	.1543	.1715	.1543	
8	.1543	.1715	.1715	
10				.1372
11				.1886
12				.1715
13				.1715
16				.1372
23	.12	.1029	.061	
24	.1372	.1029	.12	.0762
Max	.1543	.1715	.1715	.1886
Min	.12	.1029	.061	.0762
Avg	.1389	.1286	.1244	.1470

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094016 / 33/11 KV DEOPUR

Feeder No / Name : 204 / 11 KV VIDYANAGARI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1434	2.2291	2.2291	2.0576	2.2291	2.0576	
2	2.0576	2.0576	2.0576	2.0576	2.1434	1.9719	2.0576
3	1.9719	1.9719	1.9719	1.7147	2.0576	1.8861	1.8861
4	1.8004	1.8004	1.8861	1.6289	1.8861	1.8004	1.7147
5	1.7147	1.7147	1.7147	1.6289	1.7147	1.7147	1.5432
6	1.7147	1.4575	1.6289	1.5432	1.5432	1.5432	1.5432
7	1.7147	1.286	1.5432	1.5432	1.3717	1.3717	1.3717
8	1.6289	1.3717	1.5432	1.3717	1.286	1.286	1.286
9	1.3717	1.4575	1.3717	1.286	1.286	1.3717	1.286
10	1.3717	1.3717	1.3717	1.286	1.3717	1.3717	1.3717
11	1.4575	1.286	1.3717	1.3717	1.4575	1.4575	1.3717
12	1.4575	1.3717	1.4575	1.4575	1.4575	1.5432	1.4575
13	1.5432	1.3717	1.5432	1.5432	1.5432	1.5432	1.5432
14	1.5432	1.7147	1.6289	1.7147	1.7147	1.7147	1.7147
15	1.869	1.8004	1.6289	1.8004	1.8861	1.8861	1.7147
16	1.9719	1.6289	1.7147	1.7833	1.8004	1.7147	1.7147
17	1.8861	1.5432	1.6289	1.7147	1.7147	1.5432	1.6289
18	1.6289	1.286	1.4575	1.5432	1.5432	1.6289	1.5432
19	1.6289	1.3717	1.4575	1.7147	1.5432	1.6289	1.8004
20	2.0576	1.8861	1.8861	2.0576	2.0576	1.9719	1.8861
21	2.0576	1.8861	1.9719	2.0576	2.1434	2.0576	2.0576
22	2.2291	2.0576	2.0576	2.1434	2.3148	2.1434	2.2291
23	2.4006	2.1434	2.2291	2.4006	2.3148	2.3148	2.1434
24	2.3148	2.3148	2.2291	2.1434	2.3148	2.2291	2.1434
Max	2.4006	2.3148	2.2291	2.4006	2.3148	2.3148	2.2291
Min	1.3717	1.286	1.3717	1.286	1.286	1.286	1.286
Avg	1.8140	1.6825	1.7325	1.7318	1.7790	1.7397	1.6960

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094016 / 33/11 KV DEOPUR

Feeder No / Name : 206 / 11 KV EKVIRA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0576	2.4006	2.2291	2.1434	2.4006		
2	2.0576	2.2291	2.1434	1.9719	2.3148		
3	1.9719	2.0576	2.0576	1.9719	2.0576		
4	2.0576	2.2291	1.9719	1.8861	1.9719		
5	2.3148	2.3148	1.9719	1.8861	1.8861		
6	2.0576	2.3148	1.8004	1.7661	1.8004		
7	1.9719	2.3148	1.8004	1.8347	1.8004		
8	1.8861	2.1434	1.8861	1.8004	1.8861		
9	1.9547	1.8861	1.8861	1.8519		1.0288	1.0288
10	2.0233	2.2291	1.8861	1.8519		1.0288	.9431
11	2.1434	2.0576	1.8861	1.8861		1.0288	.9431
12	2.1434		1.8861	1.9376		1.0288	1.0288
13	2.1434	1.9719	1.9719	2.0062		1.0288	.9431
14	2.1605	1.9719	1.8861	2.0233		1.0288	.8573
15	2.2119	2.0576	1.8861	2.0919		1.0288	.9431
16	2.1434	2.0576	1.8004	2.0576		1.0288	.9431
17	2.332	2.0576	1.7147	2.1091			.9431
18	2.2119	1.8861	1.7147	1.8861			.9088
19	2.2291	1.8861	1.7147	2.0062			1.0802
20	2.4006	2.2291	2.1434	2.4348			
21	2.4006	2.2291	2.1434	2.332			1.1145
22	2.4006	2.2291	2.1434	2.4348			1.1145
23	2.4863	2.2291	2.1776	2.452			1.1145
24	2.4006	2.4006	2.2291	2.1434	.9945		
Max	2.4863	2.4006	2.2291	2.452	2.4006	1.0288	1.1145
Min	1.8861	1.8861	1.7147	1.7661	.9945	1.0288	.8573
Avg	2.1734	2.1471	1.9554	2.0319	1.9014	1.0288	.9933

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094016 / 33/11 KV DEOPUR

Feeder No / Name : 210 / 11 KV JAIHIND COLONY
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
1		1.2003	1.2003
2		1.2003	1.1145
3		1.2003	1.1145
4		1.1145	1.1145
5		1.1145	1.0288
6		1.0288	.9431
7		.9431	.9431
8		.9431	.9431
9		1.0288	.9431
10		1.0288	1.0802
11		1.1145	1.1145
12		1.2003	1.2003
13		1.2003	1.1145
14		1.2003	1.1145
15	1.286	1.286	1.2003
16	1.286	1.2003	1.2003
17	1.2003	1.0288	1.1145
18	1.1145		1.1145
19	1.2003	1.4575	1.286
20	1.4575	1.4575	
21	1.3717	1.3717	
22	1.3717	1.3717	1.3717
23	1.3717	1.286	1.3717
24		1.286	1.2003
Max	1.4575	1.4575	1.3717
Min	1.1145	.9431	.9431
Avg	1.2955	1.1854	1.1286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094016 / 33/11 KV DEOPUR

Feeder No / Name : 211 / ITI EXPRESS

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343	.0305	.0343		
2	.0343	.0343	.0343	.0305	.0343		
3	.0343	.0343	.0343	.0305	.0343		
4	.0343	.0343	.0343	.0305	.0343		
5	.0343	.0343	.0343	.0305	.0343		
6	.0343	.0343	.0343	.0305	.0343		
7	.0343	.0343	.0343	.0305	.0343		
8	.0343	.0343	.0343	.0305	.0343		
9	.0343	.0343	.0305	.0343		.0305	.0305
10	.0343	.0343	.0343	.0343		.0305	.0305
11	.0343	.0343	.0305	.0343		.0305	.0305
12	.0343	.0343	.0305	.0343		.0343	.0305
13	.0343	.0343	.0305	.0343		.0305	.0305
14	.0343	.0343	.0305	.0305		.0305	.0305
15	.0343	.0343	.0305	.0305		.0305	.0305
16	.0343	.0343	.0305	.0305		.0305	.0305
17	.0343	.0343	.0305	.0305		.0305	.0305
18	.0343	.0343	.0305	.0305			.0305
19	.0343	.0343	.0305	.0305			.0305
20	.0343	.0343	.0305	.0305			.0305
21	.0343	.0343	.0343	.0305			.0305
22	.0343	.0343	.0305	.0305			.0305
23	.0343	.0343	.0305	.0305		.0305	.0305
24	.0343	.0343	.0343	.0305	.0343		
Max	.0343	.0343	.0343	.0343	.0343	.0343	.0305
Min	.0343	.0343	.0305	.0305	.0343	.0305	.0305
Avg	.0343	.0343	.0322	.0313	.0343	.0309	.0305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094016 / 33/11 KV DEOPUR

Feeder No / Name : 242 / 11KV INCOMER II

Feeder KV- 33 / INCOMING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	14.5062	15.1749	14.6091	11.6255	12.9115		
2	13.9918	14.249	13.9403	10.8539	12.1399		
3	13.5288	13.4774	13.4259	10.5967	11.4198		
4	13.2716	13.9918	12.963	10.3395	10.9054		
5	14.3004	14.0432	12.7058	10.3395	10.6996		
6	14.1461	14.9692	13.1173	10.1338	10.1852		
7	14.1461	15.3292	12.6543	10.1852	10.1338		
8	13.6317	14.4033		9.7737	10.0823		
9	10.2366	9.9794	10.0309	10.1852		10.8025	10.4424
10	10.4424	11.0082	9.8766	11.7799		12.7572	11.677
11	11.0597	10.5453	10.2366	13.0659		14.5062	12.4486
12	11.5226	10.5453	10.2366	13.6831		15.6893	13.2202
13	11.5226	10.4424	10.4938	13.8375		15.3292	13.0144
14	11.6255	10.8025	10.4938	13.9403		15.2778	12.3457
15	11.8313	11.1111	10.4938	14.5062		15.7922	13.0659
16	11.5741	10.8539	10.2366	14.1976		12.7572	14.3519
17	12.0371	10.5967	9.465	14.3004			13.6317
18	11.5741	9.9794	9.2078	10.0309			11.0082
19	11.677	10.0823	9.5165	10.9568			12.6543
20	12.9115		11.7284	13.0659			.6173
21	12.963	11.8313	11.9342	12.8087			8.5905
22	12.9115	12.2943	11.8313	13.3231			13.2202
23	15.7922	14.4548	13.4259	13.5803			13.2202
24	15.9465	15.535	14.712	13.1173	8.9506		
Max	15.9465	15.535	14.712	14.5062	12.9115	15.7922	14.3519
Min	10.2366	9.9794	9.2078	9.7737	8.9506	10.8025	.6173
Avg	12.7979	12.4217	11.6233	12.0928	10.8253	14.1140	11.5672

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094016 / 33/11 KV DEOPUR

Feeder No / Name : 424 / 33 KV UMRAONAGAR (O/G)
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0062	2.1605	2.0062	1.9547	2.1605	2.0576	2.0062
2	1.8519	2.0576	1.9033	1.749	2.0576	1.9547	1.8004
3	1.749	1.9547	1.8004	1.749	1.9547	1.8519	1.749
4	1.749	1.8519	1.6975	1.6975	1.8519	1.749	1.6975
5	1.6975	1.6461	1.6461	1.6975	1.6461	1.6461	1.6461
6	1.8519	1.4403	1.5947	1.6461	1.6461	1.5947	1.6461
7	1.6975	1.3889	1.4918	1.5947	1.4403	1.4403	1.3889
8	1.5947	1.3889	1.4403	1.3889	1.286	1.3375	1.3375
9	1.5432	1.4918	1.4918	1.4918	1.3889	1.3889	1.3889
10		1.4403	1.5432	1.4918	1.4918	1.3889	1.4403
11	1.6975	1.4918	1.4918	1.5432	1.3889	1.4403	1.4403
12	1.6461	1.4918	1.4403	1.5432	1.3889	1.4403	1.4918
13	1.6461	1.5947	1.5432	1.5947	1.5947	1.5947	1.5432
14	1.8004	1.6461	1.5947	1.6975	1.749	1.6461	1.6975
15	1.8519	1.8004	1.6975	1.749	1.9033	1.6461	1.6975
16	1.749	1.749	1.5947	1.5947	1.749	1.6975	1.6461
17	1.6975	1.5947	1.4918	1.5432	1.6461	1.5432	1.5947
18	1.6461	1.5432	1.4918	1.5432	1.6975		1.5947
19	1.5432	1.5432	1.4918	1.6975	1.5947	1.8519	18.0556
20	1.9033	1.8004	1.749	1.9547	1.9033	2.0062	1.8519
21	2.0062	1.9033	1.8519	2.1091	2.1605	2.1091	2.0576
22	2.1605	2.0062	2.0062	2.2119	2.2634	2.3148	2.1091
23	2.2119	2.1091	2.1091	2.4177	2.3148	2.2119	2.0576
24	2.1605	2.1605	2.1091	2.0062	2.2634	2.1605	2.1091
Max	2.2119	2.1605	2.1091	2.4177	2.3148	2.3148	18.0556
Min	1.5432	1.3889	1.4403	1.3889	1.286	1.3375	1.3375
Avg	1.8027	1.7190	1.6783	1.7361	1.7726	1.7423	2.3770

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094036 / 33/11 KV AGRI. COLLAGE

Feeder No / Name : 201 / 11 KV PAROLA ROAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	1.3717	1.2003			1.4098	1.17	1.166
8	1.0288	.9259			.9526	.8648	1.0288
12	1.105	.9774			1.1812		1.1812
16	1.4861	1.1831			1.1431		
20	1.3336	1.0288	.9774	1.3032	1.166	1.4575	
23	1.4861	1.5242	1.4861	1.5242	1.2689	1.166	.9526
24	1.4098	1.5089	1.4403		1.6004	.9496	1.3203
Max	1.4861	1.5242	1.4861	1.5242	1.6004	1.4575	1.3203
Min	1.0288	.9259	.9774	1.3032	.9526	.8648	.9526
Avg	1.3173	1.1927	1.3013	1.4137	1.246	1.1216	1.1298

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094036 / 33/11 KV AGRI. COLLAGE

Feeder No / Name : 202 / 11 KV VADJAI ROAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	3.4294	2.1605			1.448	1.4922	1.4922
8	2.6673	2.1262			1.6004	1.5091	1.5432
12	1.829	1.6975			1.7909		2.0576
13		1.829					
16	2.2862	1.4861			1.4861		1.9433
20	1.829	1.5242	1.286	1.1145	1.3375	1.6461	
23	2.2862	1.8671	1.448	1.829	1.4918	1.4746	
24	3.1245	2.3663	1.9204		1.7147	1.5091	1.4746
Max	3.4294	2.3663	1.9204	1.829	1.7909	1.6461	2.0576
Min	1.829	1.4861	1.286	1.1145	1.3375	1.4746	1.4746
Avg	2.4931	1.8821	1.5515	1.4718	1.5528	1.5262	1.7022

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094036 / 33/11 KV AGRI. COLLAGE

Feeder No / Name : 204 / 11 KV WATER SUPPLY

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 11 / OUTGOING

UTILITY

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.0762	.0686			.0762	.017	.0343
8	.0762	.0686			.0762	.0339	.0686
12	.0762	.0686			.0762		.0762
16	.0762	.0686			.0762		.0762
20	.0762	.0686	.0686	.0686	.0686	.0686	
21					.0686		
23	.0762	.0762	.0762	.0762	.0171	.0339	
24	.0762	.0686	.0686		.0762	.017	.0343
Max	.0762	.0762	.0762	.0762	.0762	.0686	.0762
Min	.0762	.0686	.0686	.0686	.0171	.017	.0343
Avg	.0762	.0697	.0711	.0724	.0669	.0341	.0579

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094036 / 33/11 KV AGRI. COLLAGE

Feeder No / Name : 205 / Microtower

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.1524	.1372			.1524	.0339	.1372
8	.1524	.2058			.1524	.0678	.1341
12	.2286	.2058			.2286		
16		.1543			.2286		
20		.1372	.0686	.1372	.1372	.0686	
23		.1524	.1524	.1524	.0339	.1372	
24	.1524	.1372	.0686		.1524	.0339	.0686
Max	.2286	.2058	.1524	.1524	.2286	.1372	.1372
Min	.1524	.1372	.0686	.1372	.0339	.0339	.0686
Avg	.1715	.1614	.0965	.1448	.1551	.0683	.1133

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094036 / 33/11 KV AGRI. COLLAGE

Feeder No / Name : 206 / ABHAY COLLEGE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	1.829	1.5432			1.2574	1.5939	1.4918
8	1.8671	1.6118			1.6766	1.5939	1.358
12	1.829	1.3889			1.5623		1.9052
16	1.7147	1.2689			1.6385		2.0957
20	1.6385	1.0288	1.0288	1.286	.9259	1.5947	1.5242
23	1.6004	1.6385	1.2955	1.6766	1.17	1.166	
24	2.0957	1.3717	1.5775		1.4861	1.5091	1.1317
Max	2.0957	1.6385	1.5775	1.6766	1.6766	1.5947	2.0957
Min	1.6004	1.0288	1.0288	1.286	.9259	1.166	1.1317
Avg	1.7963	1.4074	1.3006	1.4813	1.3881	1.4915	1.5844

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094036 / 33/11 KV AGRI. COLLAGE

Feeder No / Name : 207 / KABIRGANJ

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.8764	.8573				.6687	.7733
8	.8002					.763	.6859
12	.724	.9088					.9145
13		.9526					
16	.9145	.8383			.8573		.8764
20	.9907	.724	.583	.6859	.6859	.9088	
23	1.1431	.9145	.6859	.9907	.8139	.583	
24	.9907	.9945	.823			.5765	.6687
Max	1.1431	.9945	.823	.9907	.8573	.9088	.9145
Min	.724	.724	.583	.6859	.6859	.5765	.6687
Avg	.9199	.8843	.6973	.8383	.7857	.7	.7838

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094036 / 33/11 KV AGRI. COLLAGE

Feeder No / Name : 208 / 11KV OLD DHULE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	1.1812	1.0288			1.1431	1.3226	1.6461
8	1.105	1.105				.9665	.9945
12	1.0669	1.1431			1.2193		1.2193
16	1.1431	1.1812			1.1431		1.2955
20	1.4098	1.2193	1.0802	1.166	1.0288	.7545	
23	1.2574	1.2193	1.2574	1.2193	1.0174	.8402	
24	1.1431	1.2574	1.0802		1.2574	1.0852	.9945
Max	1.4098	1.2574	1.2574	1.2193	1.2574	1.3226	1.6461
Min	1.0669	1.0288	1.0802	1.166	1.0174	.7545	.9945
Avg	1.1866	1.1649	1.1393	1.1927	1.1349	.9938	1.2300

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094036 / 33/11 KV AGRI. COLLAGE

Feeder No / Name : 209 / NATRAJ FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	1.2955	.9602			1.2574	1.2548	1.2174
8	1.2574	1.0117			1.3336	1.17	1.2883
12	1.105	1.0117			1.0669		1.0669
16	1.2955	.823			1.1431		.9526
20	1.105	.7888	.6859	.7373	.7545	1.0802	
23	1.1812	1.105	.9145	1.0479	1.4752	1.0631	
24	1.3336	1.166	1.0631		1.105	1.3565	1.1317
Max	1.3336	1.166	1.0631	1.0479	1.4752	1.3565	1.2883
Min	1.105	.7888	.6859	.7373	.7545	1.0631	.9526
Avg	1.2247	.9809	.8878	.8926	1.1622	1.1849	1.1314

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094036 / 33/11 KV AGRI. COLLAGE

Feeder No / Name : 210 / 11 kv Sultaniya

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	2.0576	1.989				1.8482	1.8519
8	2.0957	2.0576				1.8313	1.595
12	1.7147	1.6804					1.9052
16	2.2481	1.6804			1.4746		1.829
20	2.0957	1.3717	1.3375	1.406	1.4918	1.8519	
23	2.2862	2.0957	1.6766	2.21	1.8991	1.9204	
24	2.0957	2.2291	2.0576			1.8991	1.9033
Max	2.2862	2.2291	2.0576	2.21	1.8991	1.9204	1.9052
Min	1.7147	1.3717	1.3375	1.406	1.4746	1.8313	1.595
Avg	2.0848	1.8720	1.6906	1.808	1.6218	1.8702	1.8169

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094036 / 33/11 KV AGRI. COLLAGE

Feeder No / Name : 211 / 11 KV RAMCHANDRA NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.4954	.4115				.39	.4207
8	1.3336	.3772				.39	.4294
12	.381	.3772					.381
16	.4191	.3601			.4115		.4572
20	.4954	.3601	.4287	.3772	.4115	.5487	
23	.6097	.5716	.5716	.5335	.4578	.4115	
24	.5716	.5487	.583			.3561	.3441
Max	1.3336	.5716	.583	.5335	.4578	.5487	.4572
Min	.381	.3601	.4287	.3772	.4115	.3561	.3441
Avg	.6151	.4295	.5278	.4554	.4269	.4193	.4065

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094036 / 33/11 KV AGRI. COLLAGE

Feeder No / Name : 241 / 11 KV INCOMER I

Feeder KV- 33 / INCOMING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		11.6255				13.6837	14.8663
8	13.7174	11.4198				14.0947	15.1966
12		16.8725					
16	14.289						13.1459
23	14.8606	14.289	10.2881	12.0028	13.6328	13.786	
24	14.8606	12.5515	12.7572			13.786	14.0924
Max	14.8606	16.8725	12.7572	12.0028	13.6328	14.0947	15.1966
Min	13.7174	11.4198	10.2881	12.0028	13.6328	13.6837	13.1459
Avg	14.4319	13.3517	11.5227	12.0028	13.6328	13.8376	14.3253

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094036 / 33/11 KV AGRI. COLLAGE

Feeder No / Name : 242 / 11KV INCOMER II

Feeder KV- 33 / INCOMING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4						16.9393	17.3
8	18.2899					18.7243	16.2552
12		13.9918					
16	17.1468						14.289
23	18.2899	16.0037	12.5743	16.0037	17.0919	17.364	
24	21.7193					17.2445	16.358
Max	21.7193	16.0037	12.5743	16.0037	17.0919	18.7243	17.3
Min	17.1468	13.9918	12.5743	16.0037	17.0919	16.9393	14.289
Avg	18.8615	14.9978	12.5743	16.0037	17.0919	17.5680	16.0506

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094036 / 33/11 KV AGRI. COLLAGE

Feeder No / Name : 243 / 11 KV INCOMER III

Feeder KV- 33 / INCOMING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		5.9671			5.4938	6.0494
8	5.9442	6.1728			5.5447	5.5453
12		5.9671				
16	6.8587	5.0412				5.7156
20		4.1152				
23	6.8587	5.7156	4.5725	6.8587	5.9156	
24	6.2872	6.6873			5.6464	6.0494
Max	6.8587	6.6873	4.5725	6.8587	5.9156	6.0494
Min	5.9442	4.1152	4.5725	6.8587	5.4938	5.5453
Avg	6.4872	5.6666	4.5725	6.8587	5.6501	5.8399

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094040 / 33/11 KV UMRAONAGAR

Feeder No / Name : 202 / 11 KV AKASHWANI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9719	1.9719	1.9719	1.8861		2.0233	1.989
2	1.9204	1.8861	1.8861	1.8347		1.9204	1.9719
3	1.8861	1.8004	1.7147	1.8004		1.8004	1.8861
4	1.6975	1.6975	1.6118	1.7147		1.6289	1.7147
5	1.6804	1.6289	1.5432	1.6461			1.6804
6	1.8004	1.4918	1.4746	1.5775		1.5261	
7	1.6804	1.3717	1.3717	1.3717	1.406	1.4232	
8	1.5261	1.3717	1.3717	1.3032	1.3375	1.286	1.2346
9	1.5261	1.3717	1.406	1.3717	1.3375	1.3032	1.3717
10		1.3717	1.3717	1.406	1.406	1.3717	1.286
11	1.5947	1.3717	1.3717	1.3889	1.3717	.0171	1.3375
12	1.5261	1.3717	1.3717	1.3717	1.406	.0171	1.3375
13	1.6289	1.4746	1.5432	1.4575	1.4918	1.5775	1.406
14	1.6804	1.4746	1.5775	1.5775	1.6461	.0171	1.5432
15	1.8176	1.5432	1.6289	1.6804	1.7833	.0171	1.6118
16	1.6804	1.6804	1.5432	1.406	1.6118	.0171	1.5775
17	1.5604	1.5089	1.4746	1.4232	1.5604	1.4575	1.4403
18	1.5432	1.406	1.3717		1.5947	1.3717	1.3889
19	1.4403	1.3889	1.3717		1.6118		1.5775
20	1.8004	1.7147	1.6118		1.8861	1.989	1.7661
21	1.9376	1.8347	1.7833		2.0919	2.1948	1.8861
22	2.0576	1.8861	1.9204		2.2119	2.2634	2.0062
23	2.1091	2.0576	2.0062	2.1434	2.2634	2.2634	1.9719
24	2.0576	2.0405	2.0919	1.9376	2.1948	2.1776	2.0576
Max	2.1091	2.0576	2.0919	2.1434	2.2634	2.2634	2.0576
Min	1.4403	1.3717	1.3717	1.3032	1.3375	.0171	1.2346
Avg	1.7445	1.6132	1.5996	1.5946	1.6785	1.3483	1.6383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094012 / NAKANE

Feeder No / Name : 202 / 11 KV CIRCUIT HOUSE

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1772	.0934		.3544	.1867	.2658	
2	.1772	.0934		.2658	.1867	.2658	
3	.1772	.0934		.2658	.1867	.2658	
4	.1772	.1867		.2658	.1867	.1772	
5	.1772	.1867		.1772	.1867	.1772	
6	.1772	.1867		.1772	.1867	.1772	
7	.1772	.1867		.1772	.1867	.1867	
8	.1867		.2658	.1772	.1867	.1867	.1867
9	.4668		.3544	.4481	.1867	.3734	.3544
10	.4668		.3544	.4481	.443	.4108	.3544
11	.4668		.3544	.4481	.443	.4108	.443
12	.4854		.3544	.4481	.443	.4108	.443
13	.4481		.3544	.3734	.443	.4108	.3544
14	.4481		.3544	.3734	.443	.4108	.3544
15	.4481		.3544	.3734	.3544	.4481	.3544
16	.4481		.3544	.3734	.3544	.4481	.3544
17	.4108		.3544	.3734	.3544	.3734	.3544
18	.3734		.3544	.3734	.3544	.3734	.3544
19	.3734		.3544	.2801	.3544	.3734	.3544
20	.3734		.3544	.2801	.443		
21	.3734		.3544	.2801	.443		.3544
22	.2801		.3544		.443		.3544
23	.2801		.2658		.3544		.3544
24	.3544	.2801		.2658		.3544	
Max	.4854	.2801	.3544	.4481	.443	.4481	.443
Min	.1772	.0934	.2658	.1772	.1867	.1772	.1867
Avg	.3302	.1634	.3433	.3182	.3196	.3250	.3550

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094012 / NAKANE

Feeder No / Name : 203 / 11 KV WATER SUPPLY

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 11 / OUTGOING

UTILITY

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3544	.2801		.0886	.2801	.1772	.0934
2	.3544	.2801		.0886	.3734	.1772	.0934
3	.3544	.2801		.1772	.3734	.1772	.2801
4	.3544	.3734		.1772	.3734	.1772	.2801
5	.3544	.3734		.1772	.3734	.2658	.2801
6	.3544	.3361		.3544	.3734	.3544	.3734
7	.443	.3361		.3544	.3734	.3734	.3734
8	.3734		.3544	.3544	.3734	.3734	.3734
9	.3734		.3544	.3734	.3734	.3734	.3544
10	.3734		.3544	.4108	.3544	.3734	.3544
11	.3734		.3544	.3734	.3544	.3734	.3544
12	.3734		.3544	.3734	.3544	.3734	.3544
13	.3734		.3544	.3734	.3544	.3734	.3544
14	.3734		.3544	.4668	.3544	.3734	.3544
15	.3734		.3544	.4108	.3544	.4108	.3544
16	.3734		.3544	.4108	.3544	.4108	.3544
17	.3361		.3544	.3734	.3544	.3734	.3544
18	.3361		.3544	.3734	.3544	.3734	.3544
19	.3361		.3544	.3734	.3544	.3734	.3544
20	.3361		.3544	.3734	.3544		
21	.3361		.2658	.4108	.3544		.1772
22	.3361		.2658		.443		.1772
23	.2801		.1772		.443		.1772
24	.3544	.2801		.0886		.1772	
Max	.443	.3734	.3544	.4668	.443	.4108	.3734
Min	.2801	.2801	.1772	.0886	.2801	.1772	.0934
Avg	.3575	.3174	.3323	.3163	.3655	.3218	.2990

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094012 / NAKANE

Feeder No / Name : 204 / AJINKYA TARA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5947	1.6804		1.4175		1.7718	
2	1.5947	1.6804		1.4175		1.7718	
3	1.5947	1.6804		1.4175	1.6804	1.5947	
4	1.5947	1.4937		1.2403	1.6804	1.5947	
5	1.4175	1.307		1.2403	1.587	1.4175	
6	1.2403	1.307		1.2403	1.4937	1.2403	
7	1.1517			1.2403	1.307	1.2136	
8	1.2136		1.2403	1.2403	1.2136	1.2136	1.2136
9	1.1203		1.0631	1.2136	1.1203	1.2136	1.0631
10	1.1203		1.0631	1.1203	1.0631	1.1203	1.0631
11	1.1203		1.0631	1.1203	1.0631	1.1203	1.0631
12	1.1203		1.0631	1.0269	1.0631	1.1203	1.0631
13	1.1203		1.0631	1.1203	1.2403	1.2136	1.0631
14	1.2136		1.0631	1.2136	1.2403	1.307	1.0631
15	1.2136		1.0631	1.2136	1.2403	1.307	1.0631
16	1.2136		1.0631	1.2136	1.2403	1.307	1.0631
17	1.1203		1.0631	1.2136	1.2403	1.307	1.1517
18	1.1203		1.0631	1.2136	1.2403	1.4003	1.1517
19	1.307		1.0631	1.307	1.2403	1.4563	1.1517
20	1.4003		1.0631	1.4003	1.4175		
21	1.4937		1.2403	1.4003	1.7718		1.7718
22	1.4937		1.4175	1.4003	1.7718		1.7718
23	1.6804		1.4175		1.7718		1.7718
24	1.5947	1.6804		1.4175		1.7718	
Max	1.6804	1.6804	1.4175	1.4175	1.7718	1.7718	1.7718
Min	1.1203	1.307	1.0631	1.0269	1.0631	1.1203	1.0631
Avg	1.3273	1.5470	1.1296	1.2630	1.3660	1.3731	1.2326

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094012 / NAKANE

Feeder No / Name : 205 / 11 KV MOGLAI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8349	2.8006		2.3034	2.8006	2.6578	2.6139
2	2.6578	2.8006		2.3034	2.8006	2.6578	2.6139
3	2.6578	2.8006		2.3034	2.8006	2.4806	2.6139
4	2.4806	2.4272		2.1262	2.6139	2.3034	2.5206
5	2.3034	2.1472		1.949	2.4272	2.1262	2.1472
6	2.1262	2.0538		1.949	2.2405	2.0376	2.0538
7	1.949	2.0165		1.7718	2.1472	2.0538	1.8671
8	2.0165		2.0376	1.7718	2.0538	2.0165	1.8298
9	1.9605		1.8604	1.8671	1.9605	1.9044	1.5947
10	1.9044		1.8604	1.8671	1.7718	1.8671	1.5947
11	1.8671		1.8604	1.9605	1.7718	1.8298	1.6832
12	1.8671		1.8604	1.9605	1.7718	1.9605	1.6832
13	1.8671		1.949	1.9605	1.949	2.0538	1.949
14	2.0538		1.949	2.0538	2.1262	2.0538	2.1262
15	2.1472		1.949	2.0538	2.3034	2.2405	2.1262
16	2.2405		1.7718	2.1472	2.3034	.6535	2.1262
17	2.0538		1.7718	2.1472	2.1262	.2241	1.949
18	1.8671		1.7718	2.1472	1.949	2.1472	1.8604
19	2.1472		1.7718	2.2405	1.949	2.2032	1.7718
20			1.7718	2.2405	2.1262		
21	2.4272		2.1262	2.3339	2.3034		2.3034
22	2.6139		2.1262		2.392		2.4806
23	2.8006		2.4806		2.6578		2.4806
24	2.6578	2.8006		2.5692		2.6578	
Max	2.8349	2.8006	2.4806	2.5692	2.8006	2.6578	2.6139
Min	1.8671	2.0165	1.7718	1.7718	1.7718	.2241	1.5947
Avg	2.2392	2.4809	1.9324	2.0921	2.2324	2.0065	2.0904

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094012 / NAKANE

Feeder No / Name : 206 / SRP Colony

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3544	.3734		.3544		.3544	
2	.3544	.3734		.3544		.3544	
3	.3544	.3734		.3544	.3734	.3544	
4	.3544	.2801		.3544	.3734	.3544	
5	.3544	.2801		.3544	.3734	.3544	
6	.3544	.2801		.3544	.2987	.3544	
7	.3544	.2801		.3544	.2801	.3734	
8	.3361		.2658	.3544	.2801	.3734	.2801
9	.2801		.2658	.2801	.2801	.2801	.2658
10	.2801		.2658	.2801	.2658	.2801	.2658
11	.2801		.2658	.2241	.2681	.2801	.2658
12	.2801		.2658	.2241	.2658	.2241	.2658
13	.2801		.2658	.2241	.2658	.2241	.2658
14	.2801		.2658	.2614	.2658	.2801	.2743
15	.2801		.2658	.2801	.2658	.2801	.2658
16	.2801		.2658	.2801	.2658	.2801	.2658
17	.2614		.2658	.2801	.2658	.2801	.2658
18	.2614		.2658	.2801	.2658		.2658
19	.3361		.2658	.3734	.2658		.2658
20	.3361		.2658	.3734	.3544		
21	.3734		.2658	.3734			.2658
22	.3734		.2658		.3544		.3544
23	.3734		.3544		.3544		.3544
24	.3544	.3734		.3544		.3544	
Max	.3734	.3734	.3544	.3734	.3734	.3734	.3544
Min	.2614	.2801	.2658	.2241	.2658	.2241	.2658
Avg	.3220	.3268	.2713	.3147	.2991	.3131	.2791

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094014 / 33/11 KV MIDC

Feeder No / Name : 201 / 11 KV SUNAVKAR-OM SHREE
AGRO Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.2667	1.2955	1.448		1.105	1.1241
2	.5906	.2286	1.2955	1.448		1.2193	1.105
3	.5525	.2286		1.4289		1.2384	1.086
4	.5335	.2286	1.3336	1.448		1.2574	1.1812
5	.5144	.2286	1.3146	1.4289		1.2574	1.1812
6	.5716	.2096	1.2955	1.3336		1.2384	1.2003
7	.5906	.1905	1.3146	1.3717		1.2574	1.1812
8	.5525	.1715	1.3527	1.2384		1.2384	1.1431
9	.5716	.5525	1.3336	1.3717	1.3146	.9717	1.3717
10	.6478	.5335	1.5813	1.4861	1.5051	1.1431	1.5242
11	.7621	.5716	1.5623	1.6194	1.5242	1.1431	1.6194
12	.724	.5716	1.4861	1.7909	1.5432	1.6575	1.6766
13	.6859	.5716	1.5432	1.7528	1.5432	1.5051	1.6385
14	.7621	.5525	1.6194	1.7147	1.5623	1.5051	1.6194
15	.7621	.5716	1.5813	1.6004	1.6956	1.3908	1.6194
16	.8764	.6287	1.6766	1.7147	1.5432	1.5813	1.5813
17	.8383	.8383	1.6766	1.467	1.5242	1.5242	1.3527
18	.6859	.9145	1.6194	1.467	1.448	1.3336	1.467
19	.5525	1.2955	1.6004	1.3717	.4954	.8383	1.4289
20	.5525	1.2955	1.4098	1.2384	1.2384		1.2003
21	.5335	1.2955	1.4098	1.4289	.9145	.5335	1.2003
22	.5144	1.2574	1.4861	1.4098	.743	1.1241	1.1431
23	.4954	1.2574	1.5242	1.4289	.7621	1.1431	1.1431
24	.5906	.2858	1.2384	1.4289		.9145	1.1622
Max	.8764	1.2955	1.6766	1.7909	1.6956	1.6575	1.6766
Min	.4954	.1715	1.2384	1.2384	.4954	.5335	1.086
Avg	.6264	.6144	1.4587	1.4765	1.2905	1.2226	1.3313

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094014 / 33/11 KV MIDC

Feeder No / Name : 202 / 11 KV LAURAL-COLDSTORAGE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001	.8383	.1524	.2858	.2858	.3429	.2858
2	.4191	.8383	.1524	.2667	.2858	.3429	.3048
3	.4382	.8383	.1524	.2477	.2858	.3429	.2667
4	.4001	.2286	.1524	.2286	.2667	.3429	.3239
5	.381	.2286	.1524	.2477	.2667	.3239	.3429
6	.3429	.7621	.1334	.2858	.2667	.3048	.3048
7	.3048	.6859	.1334	.2858	.2286	.3048	.2858
8	.3239	.6478	.1334	.2477	.2096	.3048	.3239
9	.3429	.5525	.2286	.5335	.5144	.5716	.4763
10	.5525	.5335	.6287	.5335	.6668	.724	.6859
11	.7811	.3048	.5716	.7621	.6668	.7811	.8002
12	.8954	.2667	.6287	.8383	.5716	.8383	.8002
13	.8383	.2667	.5716	.7811	.5525	.8192	.7811
14	.6859	.2477		.7621	.5335	.8192	1.0479
15	.6668	.2286		.7621	.743	.8764	1.1431
16	.6478	.2667	.6287	.7811	.6478	.8764	1.105
17	.6097	.2286	.6287	.6097	.6287		1.1431
18	.5335	.2286	.4191	.5525	.5716		.5525
19	.4001	.1715	.1905	.4382	.4954		.5335
20	.381	.1715	.2858	.2286	.4763		.4954
21	.3429	.1905	.2096	.3048	.4191		
22	.2667	.1715	.2477	.2858	.362		.362
23	.3048	.1524	.2286	.2286	.3429		.362
24	.381	.8573	.1524	.2858	.2858	.9145	.2477
Max	.8954	.8573	.6287	.8383	.743	.9145	1.1431
Min	.2667	.1524	.1334	.2286	.2096	.3048	.2477
Avg	.4850	.4128	.3083	.4493	.4406	.5783	.5641

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094014 / 33/11 KV MIDC

Feeder No / Name : 203 / 11 KV Bhausahab Hire
Express Feeder KV- 11 /
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1524	.1524	.1715	.1524	.1524	.1715
2	.1715	.1524	.1524	.1715	.1524	.1524	.1715
3	.1715	.1524	.1524	.1715	.1334	.1524	.2096
4	.1905	.1524	.1524	.1715	.1334	.1524	.2286
5	.1905	.1524	.1524	.1715	.1334	.1524	.2096
6	.2477	.1334	.1524	.1715	.1715	.1524	.1905
7	.2477	.1905	.1524	.1715	.1715	.1524	.2286
8	.2667	.2096	.1524	.1715	.1905	.1715	.2477
9	.3239	.1905	.1524	.2286	.2286	.2858	.2477
10	.3429	.1715	.1715	.2667	.2477	.3429	.3048
11	.3429	.1715	.1905	.2667	.2858	.3239	.3048
12	.2858	.1715	.1905	.2858	.2667	.2858	.2858
13	.2286	.1715	.1715	.2667	.3048	.2667	.2858
14	.2286	.1715	.1715	.2667	.2667	.2286	.2286
15	.2286	.1524	.1334	.2667	.2667	.2667	.1715
16	.1905	.1715	.1524	.2286	.2286	.2286	.1524
17	.1905	.1715	.1524	.1905		.2096	.1715
18	.1905	.1715	.1524	.1715	.1905	.1905	.1715
19	.1524	.1524	.1715	.1524	.1524	.2096	.1715
20	.1524	.1524	.1715	.1905	.1524		.1715
21	.1524	.1524	.1715	.1715	.1334	.1905	.1715
22	.1524	.1524	.1715	.1715	.1334	.1905	.1715
23	.1524	.1524	.1715	.1524	.1334	.1715	.1715
24	.1715	.1524	.1524	.1715	.1715	.1524	.1524
Max	.3429	.2096	.1905	.2858	.3048	.3429	.3048
Min	.1524	.1334	.1334	.1524	.1334	.1524	.1524
Avg	.2143	.1635	.1612	.2008	.1914	.2079	.2080

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094014 / 33/11 KV MIDC

Feeder No / Name : 206 / 11 KV NIRMAL-R K AGRO
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383		.5335	.7811	.7811	.7621	.7049
2	.8383		.6097	.8573	.8002	.7621	.0953
3	.8383		.6097	.8573	.8002	.724	.6668
4	.8383		.6097	.7811	.7811	.724	.6478
5	.8002		.6097	.7621	.7621	.724	.6478
6	.7621		.5906	.8192	.724	.724	.6859
7	.6859		.5906	.7811	.7049	.7049	.7049
8	.6478		.5716	1.086	.6859	.6859	.6287
9	.7811	.6859	.6668	.8764	.8954	1.1622	
10	1.0288	.8002	.9526	1.1812	1.1812	1.2384	
11	.1143	.8954	1.0288	1.2955	1.2193	1.2955	
12	1.2574	.8573	1.0288	1.3527	1.2384	1.2955	
13	1.1812	.8192	1.1431	1.3527	1.2574	1.5051	
14	1.105	.7621	1.1431	1.2955	1.2955	1.5242	
15	1.0479	.6478	1.0669		1.3336	1.3527	
16	.9907	.6668	1.3146	1.2384	1.2193	1.3717	
17	.9526	.6478	1.2003	1.1812	1.1812	.7049	.9526
18	.9145	.6478	1.0288	1.1622	1.0669	.7621	.5525
19	.8573	.5716	1.0479	1.1431	.8764	.724	.5144
20	.8383	.5716	.9717	.8002	.8383		.4763
21	.7811	.5525	.8192	.8573	.7621	.5525	.4382
22	.7621	.5335	.9526	.8573	.724	.5525	.4001
23	.8383	.4191	.8383	.8192	.724	.7049	.8002
24	.8573		.4763	.8192	.7621	.7621	.7621
Max	1.2574	.8954	1.3146	1.3527	1.3336	1.5242	.9526
Min	.1143	.4191	.4763	.7621	.6859	.5525	.0953
Avg	.8565	.6719	.8502	.9981	.9423	.9269	.6049

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094014 / 33/11 KV MIDC

Feeder No / Name : 208 / Dama water supply
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478	.6859	.6478	.7811	.7811	.6478	.724
2	.6287	.6859	.6668	.7621	.7811	.6478	.7049
3	.5906	.6668	.6668	.8192	.7811	.6478	.743
4	.7049	.6668	.6859	.8002	.7621	.6287	.7049
5	.7049	.6287	.6668	.743	.7621	.6097	.724
6	.6668	.1524	.6668	.743	.6668	.6097	.7049
7	.743		.6668	.724	.6287	.5716	.743
8	.7049		.6287	.724	.6478	.5906	.7049
9	.6668	.1524	.6478	.6859	.2667	.3429	.7621
10	.2858	.1715	.1905	.2667	.1143	.3048	.8383
11	.2477	.1524	.1905	.3048	.1334	.2858	.8383
12	.381	.1524	.2477	.3239	.1524	.2286	
13	.3048	.1334	.2667	.3429	.1715	.2286	.381
14	.2286	.1143	.3048	.3048	.1715	.1905	.3048
15	.2286	.1143	.1905	.2858	.2096	.1715	.2477
16	.2286	.1334	.2858	.2858	.2667	.2096	.2286
17	.2286	.1143	.6097	.2286	.1905	.1905	.2477
18	.2286	.1143	.2477	.2286	.1715	.1715	.1905
19	.2286	.0953	.2286	.2286	.1524	.1524	.2096
20	.1905	.0953	.2286	.1905	.1524		.1143
21	.1905	.1143	.2477	.1905	.1715	.1334	.1143
22	.1715	.5144	.2667	.2096	.1715	.1715	.1905
23	.1715	.6097	.8192	.743	.5335	.4572	.7811
24	.5716	.5335	.6097	.8573	.7621	.6668	.743
Max	.743	.6859	.8192	.8573	.7811	.6668	.8383
Min	.1715	.0953	.1905	.1905	.1143	.1334	.1143
Avg	.4144	.3092	.4533	.4906	.4001	.3852	.5194

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094014 / 33/11 KV MIDC

Feeder No / Name : 210 / New Madhur

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.5818		3.3532	3.8104	3.4294	3.4484	3.5627
2	3.5437		3.315	4.1533	3.4865	3.4294	3.6008
3	3.5437		3.315	4.1533	3.4675	3.4294	3.5437
4	3.5246		3.2579	4.1343	3.4675	3.4294	3.5056
5	3.4675		3.2388	4.0962	3.4294	3.3532	3.4675
6	3.4484		3.1055	4.1914	3.4294		3.4484
7	3.0483		2.934	4.382	3.3341	3.2388	3.4675
8	2.7244		2.9531	4.5153	2.4768	3.2007	3.3913
9	3.6199	2.8578	3.0864	3.1626	3.1817	3.2579	3.6389
10	3.7151	3.2579	3.9438	3.7723	3.6199	2.4768	4.02
11	3.9057	3.2769	3.8485	4.0009	3.3532	3.9628	3.8295
12	4.0962	3.2769	3.7532	4.0581	3.1245	4.0009	3.5437
13	3.5818	3.2388	4.1914	4.0009	2.8578	3.9247	3.6008
14	3.677	3.296	4.1914	4.02	2.9721	3.9247	3.8295
15	3.7151	3.4103	4.1533	4.1152	2.7054	4.2486	4.02
16	3.6389	3.3722	4.0581	4.0962	3.9628	3.9438	4.039
17	3.7151	3.3532	2.4387	3.8485	3.7342	3.9438	4.1914
18	3.6389	3.315	4.1343	3.7913	3.1626	3.7723	4.2105
19	3.6389	3.2579	4.1914	3.8104	2.6863	2.5339	4.1914
20	3.6199	3.3532	4.2105	3.4103	3.2007		
21	3.6389	3.3341	4.0962	3.4294	3.5818	2.2862	
22	3.5818	3.3913	4.0962	3.4294	3.6199	3.1245	4.1914
23	3.5437	3.4294	4.3629	3.5818	3.5818	3.4103	4.1533
24	3.5246		3.4484	4.1533	3.3913	3.4865	3.6199
Max	4.0962	3.4294	4.3629	4.5153	3.9628	4.2486	4.2105
Min	2.7244	2.8578	2.4387	3.1626	2.4768	2.2862	3.3913
Avg	3.5722	3.2947	3.6532	3.9215	3.3024	3.4467	3.7758

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094014 / 33/11 KV MIDC

Feeder No / Name : 212 / New RMC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.572	2.3624	2.2481	2.191	2.4387	2.3243	2.5149
2	2.2862	2.3624	2.3243	2.2862	2.4577	2.2862	2.4196
3	2.2481	2.3243	2.3243	2.3624	2.4577	2.2481	2.4196
4	2.2862	2.3243	2.3053	2.3243	2.4387	2.2481	2.4958
5	2.2291	2.3053	2.3053	2.2481	2.4387	2.1338	2.4958
6	2.2291	2.3243	2.3053	2.2481	2.0957	2.0957	2.4768
7	2.4196	2.2862	2.2862	2.191	2.0957	2.0576	2.4577
8		2.1148	2.2481	2.3815	2.2481	2.0005	2.4196
9		2.2672	2.2862	2.3815	2.5149	3.2579	2.5911
10		2.3053	2.5339	2.6292	2.7816	3.6199	2.934
11		2.4768	2.6673	2.6482	2.8769	3.9628	2.934
12		2.553	2.7816	2.6673	2.8959	3.9247	3.0102
13		2.4958	2.7816	2.6863	2.934	3.9247	2.9531
14		2.572	2.7625	2.6673	2.572	3.9247	2.934
15		2.4577	2.5149	2.6292	2.7054	4.2486	2.8578
16		2.4768	2.6673	2.6673	2.7054	3.9438	3.4675
17	2.7435	2.4958	2.6673	2.5911	2.6673	2.8006	2.4768
18	2.6673	2.3243	2.6863	2.572	2.6292	2.4768	2.2481
19	2.572	2.2672	2.6863	2.572	2.5339	1.7528	2.2862
20	2.5339	2.2481	2.7625	1.829	2.4958		2.2862
21	2.4768	2.2481	2.2862	1.7718	2.4768	1.5813	2.8387
22	2.3815	2.191	2.572	1.7718	2.4006	2.4387	2.4768
23	2.3624	2.1719	2.2291	2.191	2.3243	2.4958	1.8861
24	2.5911	2.3243	2.1338	2.2862	2.4577	2.3815	2.572
Max	2.7435	2.572	2.7816	2.6863	2.934	4.2486	3.4675
Min	2.2291	2.1148	2.1338	1.7718	2.0957	1.5813	1.8861
Avg	2.4399	2.3450	2.4736	2.3664	2.5268	2.7882	2.6022

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094035 / 33/11 KV POWER HOUSE

Feeder No / Name : 201 / 11 KV RAJWADE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4768	2.2291	2.0957	1.9052	1.7147	2.0005	2.0005
2	2.2862	2.2291	2.0957	1.9052	1.7147	1.9052	2.0005
3	2.2862	2.1434	1.9052	1.9052	1.7147	1.9052	1.9052
4	2.0957	2.2291	1.9052	1.9052	1.7147	1.9052	1.9052
5	1.9052	2.3148	1.7147	1.9052	1.5432	1.9052	1.8099
6	1.9052	2.3148	1.7147	1.7147	1.5432	3.5818	1.8099
7	1.8099	2.2291	1.7147	1.7147	1.7147	1.7147	1.9052
8	1.9052	1.9719	1.9052	1.8099	1.9052	1.8099	1.9052
9	1.7147	2.2862	1.9052	1.7147	2.0005	2.0957	1.8004
10	1.9719	1.9052	2.0957	1.7147	2.191	2.0957	1.8004
11	2.0576	2.0957	2.0957	2.0576	2.191	2.2862	1.9719
12	2.2291	2.0957	2.0957	2.2291	2.191	2.2862	2.0576
13	2.2291	2.0957	2.0957	2.0576	2.0957	2.2862	2.0576
14	2.0576	2.2862	1.9052	1.8861	2.0957	2.2862	2.0576
15	1.9719	2.2862	1.7147	1.8861	2.0957	2.2862	1.8004
16	2.2291	2.2862	1.7147	1.7147	2.2862		1.8861
17	2.3148	1.9052	1.7147	1.7147	2.2862	2.8578	1.7147
18	2.2291	1.9052	1.6194	1.8861	2.191		1.8861
19	2.3148	2.0957	1.9052	1.8861	2.2862	2.3815	2.0576
20	2.1434	2.0957	1.9052	2.0576	2.3815	2.2862	1.7147
21	2.1434	2.0957	2.0005	2.0576	2.191	2.191	1.8861
22	2.1434	1.9052	2.0005	1.8861	2.0957	2.0957	1.8861
23	2.1434	2.0957	1.9052	1.8861	2.0957	2.0957	1.8004
24	2.572	2.1434	2.0957	1.9052	1.8004	2.0005	2.0957
Max	2.572	2.3148	2.0957	2.2291	2.3815	3.5818	2.0957
Min	1.7147	1.9052	1.6194	1.7147	1.5432	1.7147	1.7147
Avg	2.1307	2.1350	1.9092	1.8877	2.0017	2.1936	1.9048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094035 / 33/11 KV POWER HOUSE

Feeder No / Name : 202 / 11 KV MOGLAI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0479	.9431	.9526	.9526	.8573	.9526	.9526
2	1.0479	.9431	.7621	.9526	.8573	.9526	.8573
3	.9526	.8573	.8573	.9526	.8573	.9526	.7621
4	.9526	.8573	.8573	.9526	.8573	.9526	.7621
5	.9526	.8573	.9526	.9526	.8573	.8573	.9526
6	.9526	.8573	.9526	.9526	.8573	.8573	.9526
7	.9526	.8573	.9526	.9526	.8573	.9526	.9526
8	.9526	.8573	.9526	.8573	.9526	.8573	.8573
9	.7716	.9526	.8573	.6859	.8573	.8573	.7716
10	.7716	.7621	.8573		.7621	.7621	.7716
11	.7716	.9526	.8573	.7716	.7621		.7716
12	.7716	.9526	.8573	.7716	.7621		.7716
13	.7716	.9526	.8573	.6859	.7621		.7716
14	.7716	.9526	.8573	.6859	.7621	.7621	.7716
15	.7716	.9526	.8573	.6859	.8573	.8573	.7716
16	.7716	.9526	.7621	.6859	.8573	.8573	.7716
17	.7716	.7621	.7621	.6859	.8573	.8573	.7716
18	.7716	.7621	.6668	.6859	.7621		.8573
19	.8573	.9526	.8573	.6859	.8573		.9431
20	.9431	1.1431	.9526	.6859	1.0479	1.1431	.8573
21	.9431	1.1431	.9526	.8573	1.0479	1.2384	.8573
22	.9431	.9526	.9526	.8573	.9526	1.1431	.8573
23	.9431	.9526	.9526	.8573	.9526	1.0479	.8573
24	1.0479	.9431	.9526	.9526	.7716	.9526	.9526
Max	1.0479	1.1431	.9526	.9526	1.0479	1.2384	.9526
Min	.7716	.7621	.6668	.6859	.7621	.7621	.7621
Avg	.8835	.9197	.8772	.8159	.8577	.9375	.8407

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094035 / 33/11 KV POWER HOUSE

Feeder No / Name : 203 / 11 KV SHIVAJI ROAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2862	2.0576	2.0957	2.0005	1.8004	2.0957	2.0957
2	2.2862	2.0576	2.0957	2.0005	1.7147	1.9052	2.0005
3	2.0957	1.8861	1.9052	2.0005	1.7147	1.7147	1.9052
4	1.9052	1.7147	1.7147	2.0005	1.5432	1.7147	1.7147
5	1.9052	1.5432	1.5242	1.9052	1.3717	1.7147	1.5242
6	1.9052	1.4575	1.5242	1.7147	1.3717	1.7147	1.5242
7	1.5242	1.4575	1.4289	1.4289	1.3717	1.5242	1.5242
8	1.5242	1.4575	1.5242	1.6194	1.6194	1.5242	1.5242
9		1.7147	1.6194	1.4575	1.9052	1.7147	1.5432
10	2.1434	1.9052	1.6194	1.9719	2.2862	2.0957	1.8861
11	2.572	2.2862	2.0005	2.3148	2.9531	2.9531	2.7923
12	2.7435	2.6673	2.2862	2.7435	3.1436	3.0483	2.8292
13	2.7435	2.6673	2.191	2.915	3.1436	3.0483	2.915
14	2.7435	2.8578	2.0957	3.0864	3.1436	3.0483	2.915
15	2.7435	2.8578	2.0957	2.915	3.1436	3.2388	2.572
16	3.0007	2.8578	2.0957	2.915	3.2388	3.2388	2.915
17	2.915	2.6673	1.9052	2.915	3.2388	3.2388	2.915
18	2.915	2.6673	2.0005	2.915	3.2388	3.2388	3.0864
19	3.0864	2.8578	2.0957	3.1722	3.3341	3.2388	3.0864
20	3.0007	3.1436	2.2862	3.1722	3.4294	3.0483	2.915
21	2.4006	2.7625	2.0957	2.572	2.9531	2.8578	2.0576
22	2.3148	2.191	2.0005	2.1434	2.2862	2.2862	1.9719
23	2.3148	2.0957	2.0957	2.0576	2.0957	2.2862	1.8861
24	2.4768	2.3148	2.0957	2.0005	1.8861	2.0957	2.2862
Max	3.0864	3.1436	2.2862	3.1722	3.4294	3.2388	3.0864
Min	1.5242	1.4575	1.4289	1.4289	1.3717	1.5242	1.5242
Avg	2.4151	2.2561	1.9330	2.3307	2.4136	2.4410	2.2661

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094035 / 33/11 KV POWER HOUSE

Feeder No / Name : 204 / 11 KV Civil Hospital

FEEDER Feeder KV- 11 /
OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2572	.2858	.2858	.2572	.2858	.2858
2	.2858	.2572	.2858	.2858		.2858	.2858
3	.2858	.2572	.2858	.2858	.2572	.2858	.2858
4	.2858	.2572	.2858	.2858	.2572	.2858	.2858
5	.2858	.2572	.2858	.2858	.2572	.2858	.381
6	.2858	.2572	.381	.2858	.3429	.2858	.381
7	.2858	.2572	.381	.2858	.2572	.2858	.381
8	.381	.2572	.381	.381	.2858	.2858	.381
9	.3429	.381	.381	.3429	.381	.381	.3429
10	.5144	.381	.381	.4287	.6668	.5716	.4287
11	.6001	.5716	.381	.5144	.7621		.6859
12	.6001	.5716	.381	.6859	.8573	.9526	.6859
13	.6859	.5716	.4763	.7716	.8573	.9526	.6859
14	.7716	.5716	.381	.7716	.8573	.9526	.6859
15	.7716	.5716	.381	.7716	.8573	.9526	.7716
16	.7716	.5716	.381	.7716	.8573	.9526	.7716
17	.6859	.5716	.381	.7716	.8573	.9526	.7716
18	.6859	.4763	.2858	.6859	.7621	.7621	.6859
19	.5144	.4763	.381	.5716	.6668	.6668	.5144
20	.5144	.4763	.381	.5144	.4763	.5716	.4287
21	.3429	.4763	.2858	.4287	.381	.4763	.3429
22	.3429	.2858	.2858	.3429	.381	.381	.3429
23	.3429	.2858	.2858	.2572	.2858	.381	.3429
24	.2858	.3429	.2858	.2858	.2572	.2858	.2858
Max	.7716	.5716	.4763	.7716	.8573	.9526	.7716
Min	.2858	.2572	.2858	.2572	.2572	.2858	.2858
Avg	.4648	.4017	.3453	.4708	.5252	.5426	.4767

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094035 / 33/11 KV POWER HOUSE

Feeder No / Name : 205 / 11 KV Datta Mandir

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2572	.2858	.381	.3429	.381	.2858
2	.2858	.2572	.2858	.381	.3429	.381	.2858
3	.2858	.2572	.1905	.381	.3429	.381	.2858
4	.2858	.2572	.1905	.381	.3429	.381	.2286
5	.2858	.2572	.1905	.381	.3429	.2858	.2286
6	.2858	.1715	.2858	.2858	.2572	.2858	.2286
7	.2858	.1715	.2858	.2858	.2572	.2858	.2286
8	.2858	.2572	.2858	.2858	.1905	.2858	.2286
9	.2572	.2858	.2858	.2572	.2858	.2858	.2058
10	.2572	.2858	.2858	.2572	.2858	.2858	.2572
11	.2572	.2858	.1905	.2572	.2858	.2858	.2572
12	.2572	.2858	.2858	.2572	.2858	.2858	.2572
13	.2572	.2858	.2858	.3429	.2858	.2858	.2572
14	.2572	.2858	.2858	.3429	.2858	.2858	.2572
15	.2572	.2858	.2858	.2572	.2858	.2858	.2572
16	.2572	.2858	.2858	.2572	.381	.2858	.2572
17	.2572	.2858	.2858	.2572	.381	.2858	
18	.2572	.2858	.2858	.2572	.2858	.2858	.2572
19	.3429	.2858	.2858	.2572	.2858	.2858	.3429
20	.2572	.2858	.2858	.2572	.381	.2858	.2572
21	.3429	.2858	.2858	.3429	.381	.2858	.3429
22	.3429	.2858	.2858	.3429	.381	.2858	.3429
23	.3429	.2858	.381	.3429	.381	.2858	.2572
24	.381	.3429	.2858	.381	.3429	.381	.2858
Max	.381	.3429	.381	.381	.381	.381	.3429
Min	.2572	.1715	.1905	.2572	.1905	.2858	.2058
Avg	.2862	.2715	.2739	.3096	.3175	.3056	.2649

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214] BU 0515

Substation No/ Name :- 097001 / 132 KV S/STN DHULE

Feeder No / Name : 422 / 33 KV GONDUR (I/C)

Feeder KV- 33 / INCOMING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11					7.1445		
15			5.4298				
24	6.5729	6.07	5.7156	5.7156	6.6873	6.0014	5.8871
Max	6.5729	6.07	5.7156	5.7156	7.1445	6.0014	5.8871
Min	6.5729	6.07	5.4298	5.7156	6.6873	6.0014	5.8871
Avg	6.5729	6.07	5.5727	5.7156	6.9159	6.0014	5.8871

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094001 / 33/11 KV SUB NARDANA

Feeder No / Name : 201 / 11 KV KALMADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3206	.3361	.3077	.3206	.2987	.2896	.3206
2	.3395	.3224	.3258	.3206	.2926	.2865	.3206
3	.3395	.3224	.3258	.3361	.2865	.3224	.3361
4	.3547	.3224	.3258	.3772	.3361	.3045	.3584
5	.3734	.3734	.3439	.3961	.3292	.3439	.3772
6	.4904	.3658	.3077	.3961	.3292	.3801	.3772
7	.4904	.3361	.2686	.3206	.3224	.3982	.3395
8	.2829	.2801	.3077	.2987	.2686	.3224	.3018
9	.3174	.2614	.3077	.2829	.3734	.3801	.3361
10	.3361	.3258	.3772	.2987	.4344	.3772	.3734
11	.3361	.362	.3206	.4024	.362		.415
12	.3361	.3982	.3772		.4656		.3772
13	.2865	.4706	.3206		.4298		.3772
14	.2865	.4344	.3395	.2801	.4163	.3361	.4527
15	.2614	.4656	.2263	.3224	.394	.4108	.4904
16	.3361	.4344	.2263	.4435	.4344	.4338	.4108
17	.3361	.3982	.2263	.4108	.362	.4294	.4108
18	.2926	.4298	.2452	.439	.4706	.415	.3658
19	.4024	.4163	.2641	.3582	.4525	.4207	.3734
20	.4755	.5068	.4527	.4854	.4887	.4294	.4298
21	.439	.4706	.4294	.439	.4887	.4294	.394
22	.4024	.3982	.3772	.3658	.4163	.4108	.394
23	.3361	.362	.3772	.3292	.3658	.3921	.4024
24	.3395	.3361	.3258	.3395	.2987	.3439	.3772
Max	.4904	.5068	.4527	.4854	.4887	.4338	.4904
Min	.2614	.2614	.2263	.2801	.2686	.2865	.3018
Avg	.3546	.3804	.3211	.3620	.3799	.3741	.3797

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094001 / 33/11 KV SUB NARDANA

Feeder No / Name : 202 / 11 KV WARUD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.5213	.823	.1932	.5761
2				.5213	.8025	.208	.612
3				.4458	.7727	.208	.6859
4				.3715	.884	.2378	.904
5				.3658	.945	.2494	.9991
6				.378	1.1873	.4012	1.0709
7				.3902	1.2186	.4607	1.174
8				.823	1.0387	.4012	.8623
10	.7145	.6836	.2591				
11	.9808	1.0997	1.0856				
12	.8859	1.0235	1.1294				
13	.8025	.9659	.9431				
14	.9313	.9214	.2439			.5201	
15	.8025	.8619	.3898			.5944	
16	1.0974	.8619	.4405				
17	.8954	.4401	1.3756				
23			.5487	.8025	.2229	.5898	.4954
24				.5761	.7926	.2229	.6287
Max	1.0974	1.0997	1.3756	.823	1.2186	.5944	1.174
Min	.7145	.4401	.2439	.3658	.2229	.1932	.4954
Avg	.8888	.8573	.7129	.5196	.8687	.3572	.8008

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094001 / 33/11 KV SUB NARDANA

Feeder No / Name : 203 / 11 KV NARDANA TOWN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4525	.4755	.4706	.4344	.4024	.4706	.4481
2	.4525	.4656	.4525	.4298	.4024	.4525	.4435
3	.4344	.439	.4298	.4572	.394	.4477	.4435
4	.4344	.4298	.4525	.4572	.394	.4344	.4481
5	.4755	.439	.4344	.4706	.4024	.4344	.4805
6	.4755	.4656	.4344	.4755	.439	.4525	.4805
7	.4755	.4656	.4163	.4755	.4298	.4706	.4805
8	.4908	.4557	.4344	.4557	.4435	.4706	.4805
9	.4458	.4481	.4525	.4115	.4656	.4344	.4805
10	.5121	.4344	.4207	.4755	.4706	.4908	.4904
11	.5014	.4344	.4908	.5014	.4706	.5121	.5093
12	.5121	.4887	.4458	.4656	.4887	.5121	4.9665
13	.4656	.4706	.4458	.4755	.4887		.5281
14	.4656	.4706	.4557	.4557	.4706	.5228	.4854
15	.4656	.5068	.4961	.4656	.4887	.5601	.5041
16	.439	.4887	.4733	.4656		.5975	.5281
17	.5121	.4755	.4557	.439	.362	.5601	.4527
18	.5121	.4525	.4359	.4656	.543	.5228	.4557
19	.5121	.4344	.4557	.6089	.543	.5228	.5014
20	.5487	.543	.4961	.4755	.5792	.5601	.5373
21	.5014	.5792	.5014	.5121	.5373	.5601	.5014
22	.5121	.543	.4706	.5014		.5228	.5014
23	.5228	.4887	.4706	.4755	.4887	.5228	.5068
24	.4706	.5121	.4706	.4706	.4755	.4706	.4805
Max	.5487	.5792	.5014	.6089	.5792	.5975	4.9665
Min	.4344	.4298	.4163	.4115	.362	.4344	.4435
Avg	.4829	.4753	.4568	.4717	.4627	.5002	.6723

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094001 / 33/11 KV SUB NARDANA

Feeder No / Name : 204 / 11KV CHANDGAD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.6287	.6241				
2	.5681	.5716	.5944				
3	.5761	.5716	.5944				
4	.6539	.743	.6241				
5	1.2955	.9755	.6539				
6	1.3272	1.2811	1.1443				
7	.9682	1.0936	1.0402				
8	.7034	.6836	.8173				
10				.6401	.743	.6563	.7331
11				1.0974	.8429	.9054	.7188
12				.9717	.8025	.8928	.7545
13				.9145	.743	.6584	.6935
14				.823	.743	.5761	.6401
15				.6859	.7727	.6478	.6668
16				.7049		.823	.7956
17				.9288	.6687	.9164	.7846
23	.6859	.6472					
24	.5468	.5487	.5944				
Max	1.3272	1.2811	1.1443	1.0974	.8429	.9164	.7956
Min	.5335	.5487	.5944	.6401	.6687	.5761	.6401
Avg	.7859	.7745	.7430	.8458	.7594	.7595	.7234

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094001 / 33/11 KV SUB NARDANA

Feeder No / Name : 205 / 11KV INDUSTRIAL NARDANA

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8048	.8215	.2865	.8048	.8215	.9328	.7316
2	.7964	.788	.2896	.8131	.8215	.905	.7468
3	.8779	.8596	.2686	.8048	.8779	.9955	.7682
4	.8779	.788	.2658	.8413	.788	.8869	.8048
5	.8871	.788	.2629	.8413	.8238	.8869	.8048
6	.8589	.788	.2865	.8131	.8962	.7602	.7682
7	.8871	.7164	.2629	.7316	.6805	.7783	.7964
8	.8779	.6805	.724	.7316	.8596	.7421	.8131
9	.9709	.788	.7602	.7522	.788	.8507	.9808
10	.8962	.724	.8775	.695	.9774	.7316	.924
11	.8779	.7964	.8501	.9335	.8869	.8048	8.1573
12	.7316	.8145	.8501	.7468	.7783	.8779	.8501
13	.8779	.7783	.7842	.7468	.8145	.8871	.8688
14	.8596	.7602	.8131	.8962	.7783	.8048	.8596
15	.8596	.7783	.8048	.6447	.8145	.5853	.8688
16	.8596	.4163	.695	.6413	.2629	.7682	.8507
17	.788	.4887	.6584	.8238	.4525	.695	.8596
18	.7164	.4525	.8501	.6584	.6878	.7682	.6584
19	.788	.4119	.7392	.6173	.8145	.695	.7164
20	.7316	.3721	.8131	.8048	.8596	.6878	.7316
21	.7164	.4163	.8131	.788	.8507	.7468	.7164
22	.7316	.3801	.8501	.788	.8417	.7682	.788
23	.8871	.362	.8215	.8215	.3239	.7316	.8048
24	.724	.788	.298	.8131	.8048	.8507	.724
Max	.9709	.8596	.8775	.9335	.9774	.9955	8.1573
Min	.7164	.362	.2629	.6173	.2629	.5853	.6584
Avg	.8285	.6566	.6219	.7730	.7627	.7976	1.1081

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094001 / 33/11 KV SUB NARDANA

Feeder No / Name : 206 / 11 KV WARUD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1254	.1254	.1254	.1267	.1254	.124	.124
2	.1267	.1075	.1075	.1267	.128	.1063	.124
3	.1267	.1075	.1227	.1254	.128	.1086	.1254
4	.1448	.1254	.1267	.1595	.1075	.1086	.1433
5	.1463	.1254	.1254	.1772	.128	.1267	.1578
6	.1448	.1433	.1402	.1791	.1433	.1448	.1543
7	.1629	.1433	.124	.1417	.1402	.1417	.1372
8	.1612	.1433	.1254	.1372	.1433	.1448	.1372
9	.1372	.1075	.124	.12	.1433	.1227	.1509
10	.1433	.1254	.1227	.1433	.1267	.1372	.1509
11	.1463	.1402	.12	.1433	.1433	.1357	.1612
12	.1433	.1254	.1372	.1433	.1402	.1543	.1595
13	.1433	.1402	.1341	.1448	.1433	.156	.1612
14	.1433	.1402	.1372	.1357	.1448	.1734	.1629
15	.1433	.1387	.1509	.1612	.1402	.1509	.1791
16	.1433	.12	.1677	.156	.1402	.1543	.1595
17	.1433	.1372	.1543	.1578	.1448	.1677	.1578
18	.1433	.1402	.1638	.1791	.1448	.1715	.1463
19	.1753	.1448	.1543	.1433	.181	.2012	.1791
20	.2103	.1595	.2103	.2149	.1753	.2149	.2149
21	.1791	.1772	.2126	.1829	.1772	.1772	.1829
22	.1463	.1402	.1791	.1433	.1753	.181	.1433
23	.1402	.1402	.1612	.1433	.1463	.1433	.1402
24	.1433	.1254	.124	.1433	.1463	.1402	.1433
Max	.2103	.1772	.2126	.2149	.181	.2149	.2149
Min	.1254	.1075	.1075	.12	.1075	.1063	.124
Avg	.1485	.1343	.1438	.1512	.1440	.1495	.1540

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094001 / 33/11 KV SUB NARDANA

Feeder No / Name : 207 / 11 KV CHANDGAD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.439	.394	.4344	.4755	.4298	.4706	.4344
2	.439	.4108	.4163	.4805	.4024	.4344	.439
3	.4805	.4024	.3982	.5121	.4024	.4344	.4755
4	.5121	.4755	.4163	.5853	.394	.4344	.5068
5	.7316	.5487	.4477	.6219	.5373	.4525	.6154
6	.7682	.7316	.724	.6154	.7164	.6878	.7316
7	.695	.6584	.6335	.5853	.695	.724	.7682
8	.6089	.6089	.6878	.6516	.6447	.6626	.6859
9	.5959	.6805	.9412	.7628	.8413	.6805	.7377
10	.6089	.7964	.9015	.8779	.8326	.7011	.7461
11	.8238	.8688	.823	1.0029	.905	.7362	.7362
12	.8779	.905	.7712	1.0242	.7602	.6935	.7362
13	.8059	1.0136	.8764	.8215	.7783	.8413	.7164
14	.8238	.8507	.8573	.7095	.7602	.7796	.5175
15	.7164	.905	.8718	.7522	.7964	.8573	.499
16	.7682	.9955	.7888	.9114		.8916	.4706
17	.9145	.7783	.9054	.788	.7011	.8718	.4908
18	.9313	1.0498	.7449	.8954	1.0288	.8573	.6089
19	.9511	.7602	.6516	.6661	.7202	.6447	.6447
20	.9054	.7164	.788	.8596	.7545	.7964	.7164
21	.7164	.724	.8238	.7682	.7087	.7682	.6584
22	.6089	.5792	.5792	.5487	.5731	.5487	.6089
23	.5121	.4887	.5121	.4607	.4961	.5121	.5258
24	.4706	.4481	.4477	.4706	.439	.5068	.4706
Max	.9511	1.0498	.9412	1.0242	1.0288	.8916	.7682
Min	.439	.394	.3982	.4607	.394	.4344	.4344
Avg	.6961	.6996	.6851	.7020	.6660	.6662	.6059

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094019 / 33/11 KV SUB SUKWAD

Feeder No / Name : 201 / 11 KV SAWALDE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.1191	1.0174	1.1336	1.1869
2				1.153	1.0174	1.2631	1.1869
3				1.1869	1.1022	1.1336	1.2209
4				1.1869	1.1191	1.2146	1.2039
5				1.2209	1.1191	1.2146	1.2209
6				1.2548	1.1191	1.166	1.2378
7				1.2717	1.1336	1.3279	1.2717
8				1.1869	1.2887	.5182	1.2209
9						1.3279	
10	1.0513	.9326				.8907	
11	1.153	1.2955	1.153				
12	1.2039	1.1336					
13	1.2209	1.2146	1.1022				
14	1.2209	1.2146	1.1869				
15	1.2548	1.2955	1.1869				
16	1.2548	1.2955	1.2039				
17	1.1869	1.2146	1.2378				
18		1.2146					
23			1.0174	1.0174		1.0174	.8478
24				1.1022	1.0174	1.1336	1.1022
Max	1.2548	1.2955	1.2378	1.2717	1.2887	1.3279	1.2717
Min	1.0513	.9326	1.0174	1.0174	1.0174	.5182	.8478
Avg	1.1933	1.2012	1.1554	1.1700	1.1038	1.1118	1.1700

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094019 / 33/11 KV SUB SUKWAD

Feeder No / Name : 204 / 11 KV DABHASHI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.56	1.4413	1.4575				
2	1.6617	1.5261	1.4575				
3	1.6956	1.5261	1.6194				
4	1.6956	1.6617	1.6194				
5	1.7804	1.7465	1.7004				
6	1.8652	1.7465	1.7004				
7	1.8652	1.6956	1.7004				
8	1.6956	1.6448	1.6194				
9			1.6194				
10			1.6194	1.3565	.9496		1.3735
11				1.6956	1.7814	1.5261	1.6108
12				1.6956	1.7814	1.6448	1.6278
13				1.6617	1.7814	1.6448	1.6617
14				1.6617	1.7814	1.6278	1.6617
15				1.6108	1.7004	1.6448	1.6617
16				1.6617	1.7004	1.6448	1.5261
17				1.6617	1.7004	1.543	1.4413
18					1.7004		
22		1.3279					
23	1.4413	1.3279					
24	1.56	1.4413	.2915				
Max	1.8652	1.7465	1.7004	1.6956	1.7814	1.6448	1.6617
Min	1.4413	1.3279	.2915	1.3565	.9496	1.5261	1.3735
Avg	1.6821	1.5532	1.4913	1.6257	1.6530	1.6109	1.5706

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094019 / 33/11 KV SUB SUKWAD

Feeder No / Name : 205 / 11KV EXPRESS MIDC WATER NON SHEDDABLE WATER SUPPLY AND
WORKS Feeder KV- 11 / OUTGOING UTILITY

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0339	.0324	.0351	.0339	.0324	.0351	.0339
2	.0339	.0324	.0351	.0339	.0312	.0351	.0339
3	.0339	.0324	.0351	.0339	.0324	.0351	.0339
4	.0339	.0324	.0351	.0339	.0324	.0351	.0339
5	.0339	.0324	.0351	.0339	.0324	.0351	.0339
6		.0324	.0351	.0339	.0324	.0351	.0339
7	.0339	.0324	.0351	.0339	.0324	.0351	.0339
8	.0339	.0324	.0351	.0339	.0324	.0351	.0339
9		.081	.0876	.0848	.0848	.0876	.0848
10	.0848	.081	.0876	.0848	.081	.0876	.0848
11	.081	.0876	.0848	.081	.0876	.0848	.081
12	.0324	.0876	.0848	.081	.0876	.0848	.081
13	.081	.0876	.0848	.0848	.0876	.0848	.0848
14	.081	.0876	.0848	.081	.0876	.0848	.0848
15	.081	.0351	.0339	.0324	.0351	.0339	.0339
16	.0324	.0351	.0339	.0324	.0351	.0339	.0324
17	.0324	.0351	.0339	.0324	.0351	.0339	.0324
18	.0324	.0351	.0339	.0324	.0351	.0339	.0324
19	.0324	.0351	.0339	.0324	.0351	.0339	.0324
20	.0324	.0351	.0339	.0324	.0351	.0339	.0324
21	.0324	.0351	.0339	.0324	.0351	.0339	.0324
22	.0324		.0339	.0324	.0351	.0339	.0324
23	.0339	.0351	.0339	.0324	.0351	.0339	.0324
24	.0339	.0324	.0351	.0339	.0324	.0351	.0339
Max	.0848	.0876	.0876	.0848	.0876	.0876	.0848
Min	.0324	.0324	.0339	.0324	.0312	.0339	.0324
Avg	.0442	.0472	.0473	.0456	.0468	.0473	.0458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094019 / 33/11 KV SUB SUKWAD

Feeder No / Name : 206 / 11 KV DABHASHI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2035	.2713	.2804	.2883	.2429	.2804	.2543
2	.2035	.2713	.2804	.2883	.2429	.2629	.2543
3	.2035	.3052	.3506	.2883	.2591	.2629	.2829
4	.2543	.3052	.3506	.3052	.2915	.3155	.2883
5	.3052	.3391	.3681	.3391	.3391	.3681	.3391
6	.3222	.3561	.4031	.39	.39	.4207	.39
7	.3052	.3391	.3681	.373	.3239	.4031	.373
8	.2713	.2915	.333	.3222	.3077	.3506	.3561
9	.2374	.2713	.0351	.3052	.3052	.3155	.3222
10	.2204	.2713	.4557	.3052	.3052	.2804	.3052
11	.2429	.3155	.2883	.3077	.2804	.2883	.2753
12	.2429	.298	.2883	.3077	.3155	.2883	.3077
13	.2591	.3155	.2543	.2591	.3155	.3052	.3052
14	.2591	.3155	.2543	.2591	.3155	.3222	.3077
15	.2915	.3155	.2204	.2915	.333	.3222	.3222
16	.2915	.3155	.2204	.2915	.333	.3222	.3561
17	.2915	.3155	.2204	.2915	.2629	.3391	.3561
18	.3401	.3506	.2374	.3077	.3506	.3391	.373
19	.3401	.3681	.2713	.3563	.3506	.373	.3725
20	.3725	.4207	.3391	.3563	.4207	.39	.3563
21	.3725	.3856	.3561	.3401	.4207		.3401
22	.2591	.3681	.3222	.3401	.4908		.2429
23	.2429	.3155	.2883	.2429	.3155	.2204	.2429
24	.2035	.2591	.298	.2883	.2429	.2804	.2543
Max	.3725	.4207	.4557	.39	.4908	.4207	.39
Min	.2035	.2591	.0351	.2429	.2429	.2204	.2429
Avg	.2723	.3200	.2952	.3102	.3231	.3205	.3157

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094019 / 33/11 KV SUB SUKWAD

Feeder No / Name : 207 / 11 KV TAWKHEDA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1696	.2267		.2713	.2374	.2629	.2035
2	.1696	.2267		.2713	.2374	.2629	.2035
3	.1696	.2429		.2713	.2429	.2804	.2035
4	.2204	.2429		.2883	.2753	.3155	
5	.2883	.3052		.3772	.2915	.3506	.3052
6	.2883	.3052		.373	.3563	.4207	.373
7	.2713	.3222		.3561	.3239	.3681	.3561
8	.2543	.2883		.2883	.2915	.3155	.3391
9	.1696	.2543		.2713	.2753	.3155	.3052
10	.2035	.2543		.2883	.2753	.3155	.2883
11	.2429	.298	.2713	.2915	.2804	.3052	.2753
12	.2753	.3155	.3052	.2915	.2279	.3052	.2915
13	.3077	.3506	.2713	.3077	.3506	.3222	.3077
14	.3077	.3506	.2713	.3077	.3506	.3222	.3077
15	.3239	.3681	.2543	.3401	.3506	.3222	.3239
16	.3239	.3681	.2374	.2591	.3506	.3222	.3239
17	.2591	.3681	.2374	.2753	.333	.3222	.3239
18	.2915	.3506	.2204	.3239	.3506	.3222	.3401
19	.2753	.4031	.2713	.3239	.3506	.3391	.3563
20	.3077	.3506	.373	.3401	.3506	.3561	.3563
21	.3239	.3155	.3391	.3401	.3506	.2543	.3239
22	.2591		.3222	.3239	.3506	.2713	.3563
23	.2267		.2883	.2267	.3155	.2543	.2187
24	.1696	.2267		.2713	.2267	.2629	.2035
Max	.3239	.4031	.373	.3772	.3563	.4207	.373
Min	.1696	.2267	.2204	.2267	.2267	.2543	.2035
Avg	.2541	.3061	.2817	.3033	.3061	.3121	.2994

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094020 / 33/11 KV SUB SONGIR

Feeder No / Name : 201 / 11KV INDUSTRIAL SONGIR
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2103	.2804	.1928	.2454	.2454	.2454	.2103
2	.2103	.2804	.1928	.2454	.2454	.2454	.2103
3	.2103	.2804	.1991	.2103	.2454	.2454	.2103
4	.1753	.2804	.1949	.2103	.2454	.2454	.2103
5	.208	.2804	.1753	.2103	.2804	.2629	.2103
6	.2804	.2279	.181	.2103	.2103	.2804	.2103
7	.1402	.2103	.1753	.1753	.2103	.2103	.2103
8	.1753	.1753	.181	.1928	.1753	.2103	.1753
9	.2103	.2103	.2896	.2103	.2103	.3506	.2103
10	.4207	.2103	.362	.298	.3155	.4207	.2629
11	.3856	.1402	.3856	.2454	.2804	.3506	.362
12	.3506		.4031	.2454	.4207	.3856	.3814
13	.3506	.1448	.3155	.2804	.3856	.3856	.3506
14	.2804	.104	.2454	.1753	.3506	.2629	.2534
15	.2629	.1402	.2804	.3155	.3506	.3155	.3681
16	.3155	.1227	.3155	.3155	.3506	.3155	.4161
17	.3155	.1402	.3155	.3155	.3681		.3856
18	.3856	.181	.3155	.3155	.3681	.2629	.3801
19	.3856	.1753	.2804	.3155	.3506	.3506	.3506
20	.3506	.1991	.4207	.3155	.3506	.3506	.3155
21	.3506	.2279	.3506	.4207	.4207	.2804	.3467
22	.3506	.2534	.298	.2804	.3506	.2804	.3155
23	.3155		.2454	.3155	.2804	.2279	.2534
24	.1753	.3155	.2103	.2454	.2804	.2454	.2279
Max	.4207	.3155	.4207	.4207	.4207	.4207	.4161
Min	.1402	.104	.1753	.1753	.1753	.2103	.1753
Avg	.284	.2082	.2719	.2629	.3038	.2926	.2845

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094020 / 33/11 KV SUB SONGIR

Feeder No / Name : 202 / 11KV NANDANE SINGLE

SINGLE PHASING

PHASING Feeder KV- 11 /

OUTGOING

DATE	15-JUN-18
HR	Load (MW)
1	.2279
2	.2454
3	.2629
4	.3155
5	.5609
6	.6135
7	.5083
8	.4031
9	.3856
10	1.6301
11	1.595
12	1.5424
24	.2454
Max	1.6301
Min	.2279
Avg	.6566

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094020 / 33/11 KV SUB SONGIR

Feeder No / Name : 203 / 11KV DEOBHANE SINGLE

SINGLE PHASING

PHASING Feeder KV- 11 /

OUTGOING

DATE	15-JUN-18
HR	Load (MW)
1	.3681
2	.3681
3	.4207
4	.4508
5	.5083
6	.5258
7	.4382
8	.3681
9	.333
10	2.0508
11	2.3137
12	2.1735
24	.4031
Max	2.3137
Min	.333
Avg	.8248

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094020 / 33/11 KV SUB SONGIR

Feeder No / Name : 204 / 11KV WAGHADI SINGLE

SINGLE PHASING

PHASING Feeder KV- 11 /

OUTGOING

DATE	15-JUN-18
HR	Load (MW)
1	1.0867
2	1.0867
3	1.0867
4	1.1043
5	1.1218
6	1.2795
7	1.3321
8	1.0692
9	.3155
10	.298
11	.2804
12	.2804
24	1.1744
Max	1.3321
Min	.2804
Avg	.8858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094020 / 33/11 KV SUB SONGIR

Feeder No / Name : 205 / 11KV SONGIR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18
HR	Load (MW)
1	.7186
2	.7186
3	.7011
4	.6588
5	.6836
6	.6836
7	.7186
8	.6661
9	.7712
10	.7186
11	.7011
12	.7362
24	.7186
Max	.7712
Min	.6588
Avg	.7073

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094020 / 33/11 KV SUB SONGIR

Feeder No / Name : 206 / 11 KV EXPRESS 765 KV BDTCL NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0526	.1402	.128	.2103	.1928	.0701	.0701
2	.0526	.1402	.1267	.2103	.1928	.0701	.0701
3	.0526	.1402	.1448	.1753	.1928	.0701	.0701
4	.0526	.1227	.1448	.1753	.1928	.0701	.0701
5	.0347	.1227	.1052	.1402	.1928	.0701	.0526
6	.0526	.1227	.0905	.1227	.1753	.0526	.0526
7	.0526	.1052	.1086	.1227	.1227	.0526	.0351
8	.0526	.1052	.0724	.1402	.1227	.0526	.0526
9	.1227	.1402	.1267	.1402	.1928	.0526	.0701
10	.1402	.1227	.1227	.1402	.1402	.0701	.1227
11	.1227	.1052	.1227	.1928	.1227	.0876	.0724
12	.0876	.1052	.1052	.1753	.1578	.1227	.0532
13	.0701	.1267	.1578	.1387	.0876	.0876	.0351
14	.0701	.1227	.1928	.1227	.0701	.0876	.0543
15	.0526	.1086	.1402	.1402	.0701	.0701	.0701
16	.0526	.1052	.0701	.1227	.0701	.0701	.0543
17	.0701	.124	.1227	.0526	.0876	.0701	.0701
18	.0701	.0543	.1227	.1402	.0876	.0526	.0526
19	.0526	.1267	.1578	.1402	.0876	.0701	.0701
20	.0701	.1448	.1753	.2279	.0701	.0701	.0724
21	.1578	.1402	.2103	.2279	.0876	.0701	.0543
22	.1402	.1448	.2103	.2279	.0876	.0701	.052
23	.1227	.1227	.1578	.2279	.0701	.0701	.0543
24	.0526	.1402	.1227	.1753	.1928	.0701	.0701
Max	.1578	.1448	.2103	.2279	.1928	.1227	.1227
Min	.0347	.0543	.0701	.0526	.0701	.0526	.0351
Avg	.0774	.1222	.1350	.1621	.1278	.0708	.0626

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094020 / 33/11 KV SUB SONGIR

Feeder No / Name : 207 / 11 KV SAYANE SINGLE

SINGLE PHASING

PHASING Feeder KV- 11 /

OUTGOING

DATE	15-JUN-18
HR	Load (MW)
1	.5028
2	.5434
3	.5609
4	.5959
5	.8589
6	1.1744
7	1.0692
8	.8063
9	.1578
10	.1052
11	.1402
12	.1578
13	.1402
24	.5609
Max	1.1744
Min	.1052
Avg	.5267

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094020 / 33/11 KV SUB SONGIR

Feeder No / Name : 208 / 11 KV SONDALE SINGLE

SINGLE PHASING

PHASING Feeder KV- 11 /

OUTGOING

DATE	15-JUN-18
HR	Load (MW)
1	.4908
2	.4908
3	.5258
4	.5548
5	.7888
6	.7537
7	.8764
8	.7712
9	.0351
10	.0351
11	.0526
12	.0526
24	.4908
Max	.8764
Min	.0351
Avg	.4553

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094020 / 33/11 KV SUB SONGIR

Feeder No / Name : 209 / 11 KV EXPRESS WW SONGIR

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.0526					
5		.0526					
6	.0526	.0701	.0701				
7	.0526	.0701		.0876	.0526	.0526	.0701
8	.0526	.0876	.0701	.0876	.0701	.0701	.0701
9	.0526	.0526	.0724	.0701	.0526	.0526	.0701
10	.0526		.0543	.0526	.0526	.0526	.0876
11	.0701	.0526	.0526			.0526	.0543
12	.0526		.0351				
13	.0526						
15		.0543	.0701				
16	.0526		.0876	.0876	.0526		
17	.0876	.0543	.0876	.0876	.0526		
18	.0876	.0526	.0526			.0701	
19	.0526						
20	.0526						
Max	.0876	.0876	.0876	.0876	.0701	.0701	.0876
Min	.0526	.0526	.0351	.0526	.0526	.0526	.0543
Avg	.0593	.0599	.0653	.0789	.0555	.0584	.0704

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094045 / 33/11 KV SUB BABHALE

Feeder No / Name : 201 / 11 KV WALKHEDA SINGLE

SINGLE PHASING

PHASING Feeder KV- 11 /

OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8729	.8002	.823	.4601	.422	.4668	.4907
2	.7772	.5761	.8122	.4417	.4495	.4649	.4933
3	.9099	.5933	.7074	.4435	.4668	.5062	.5137
4	.7423	.9116	.7291	.4825	.5932	.547	.5527
5	.8522	.9945	.7874	.5578	.6099	.5601	.6092
6		1.0371	1.1331	.5415	.6099	.5548	.6852
7	1.0523	.7527	.9229	.5051	.559	.5264	
8	.9106	1.0017	.9461	.4467	.4187	.4607	
9	.4974	.483	.4627	.439	.4449	.4721	
10	.4286	.4706	.4763	.759	.947	.9734	
11	.695	.4394	.4417	1.0767	1.0169	1.1215	
12	.6605	.2795	.4795	1.0181	1.1516	1.0478	
13	.4612	.4733		1.114	1.0215	.9922	
14	.4435	.5175	.5315		1.0562	.9991	.5535
15	.5116	.5381	.5326	.8718	.9114	.8738	.9165
16	.4924	.499	.5153	.9735	1.1437	1.0395	1.043
17	.5	.4625	.4928	.9252	1.0978	.9667	1.2322
18	.4805	.4207	.4661	.4923	.5144	.5068	1.0511
19	.0585	.475	.4458	.5841	.6287	.6017	.7023
20	.7369	.5828	.6321	.7301	.6668	.7316	
21	.7015	.6571	.5441	.7167	.724	.6936	
22	.6275	.5676	.5476	.7356	.5906	.6029	
23	.7668	.8415	.51	.6908	.501	.5458	
24	.7984	.7343	.854	.4765	.6421	.4825	.4887
Max	1.0523	1.0371	1.1331	1.114	1.1516	1.1215	1.2322
Min	.0585	.2795	.4417	.439	.4187	.4607	.4887
Avg	.6512	.6295	.6432	.6731	.7162	.6974	.7179

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094045 / 33/11 KV SUB BABHALE

Feeder No / Name : 202 / 11 KV EXPRESS ABHAY COTEX NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7049	.6478	.5906	.6287	.6859	.6097	.6859
2	.6859	.6668	.5906	.6478	.6668	.6097	.6668
3	.7049	.724	.6097	.6478	.6668	.6287	.6668
4	.724	.7049	.5906	.6668	.6668	.6478	.6478
5	.6668	.7049	.6287	.6478	.6859	.6478	.6478
6		.6859	.5144	.6097	.6478	.5906	.6478
7	.6668	.6478	.5335	.6097	.6097	.6097	.6287
8	.4954	.6859	.5716	.6478	.6668	.5335	.743
9	.6287	.6859	.6668	.6859	.6478	.5906	.7621
10	.5906	.6668	.4954	.6287	.6668	.5335	.7049
11	.4572	.6668	.4954	.5906	.6859	.5716	.724
12	.5144	.6668	.4954	.5335	.6097	.5335	.6287
13	.6478	.6478	.4954	.5716	.7049	.5716	.6287
14	.6478	.6478	.5525	.5906	.6859	.5335	.7811
15	.5525	.6287	.5525	.5716	.6859	.5525	.5906
16	.5335	.724	.5525	.6478	.6478	.724	.6287
17	.5716	.6478	.5716	.6859	.6478	.5906	.5906
18	.5525	.6859	.5525	.5335	.724	.6478	.6478
19	.5906	.6859	.4954	.5525	.6287	.6668	.5906
20	.6478	.7049	.5525	.6287	.6287	.6668	.724
21	.6478	.6097	.5525	.5906	.6287	.6668	.6668
22	.724	.6097	.5525	.6097	.6287	.6668	.5906
23	.6478	.5716	.5716	.6097	.5525	.6859	.5906
24	.6287	.6859	.5716	.6097	.6668	.5906	.6859
Max	.724	.724	.6668	.6859	.724	.724	.7811
Min	.4572	.5716	.4954	.5335	.5525	.5335	.5906
Avg	.6188	.6668	.5565	.6144	.6557	.6113	.6613

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094045 / 33/11 KV SUB BABHALE

Feeder No / Name : 203 / 11 KV INDUSTRIAL BABHALE SHEDDABLE FEEDER MIDC EQUIVALENT
Feeder KV- 11 / OUTGOING HAVING WEEKLY STAGGERING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6301	.7153	.9526	.7073	.9668	.9697	.9887
2	.759	.6432	.9717	.7146	.9326	.9795	1.0087
3	.7175	.6602	.7712	.7363	.9516	.9278	.9897
4	.6756	.7537	.6495	.7575	.9136	.9522	.9707
5	.6173	.7655	.4722	.8349	.8937	.7874	.9516
6		.8462	.3529	.8548	.6711	.6735	.9516
7	.3735	.3663	.399	.8937	.5969	.8131	.5882
8	.3352	.3077	.537	.7986	.5514	.8719	.9497
9	.5664	.4175	.4454	.8755	.4072	.7362	.9307
10	.6011	.3401	.5609	.797	.2558	.7701	.8349
11	.3669	.3588	.2996	.9507	.2011	.5196	.7938
12	.691	.494	.7021	1.0268	.5704	.8746	.9261
13	.7155	1.0057	.6944	1.0057	.4112	.7986	.8943
14	.5402	.924	.7491	.6084	.5041	.7994	.3921
15	.5155		.7044	.9887		.716	.7155
16	.5555		.6626	.7978	.5498	1.0374	.7468
17	.502	.5658	.6767	.3965	.5378	1.048	.5698
18	.4933	.8184	.5629	.8565	.5442	.8856	.5944
19	.4755	.8937	.9127	.9488	.5784	.4864	.2312
20	.8184	.8738	.9118	.5503	.5938	.4934	.1695
21	.8565	.9838	.8729	.2035	.5258	.5324	.4132
22	.7733	.5792	.5584	.2543	.5521	.6091	.4307
23	.8919	.9897	.6348	.3254	.5788		.4364
24	.4534	.6756	.9907	.6742	.3776	.9707	1.0077
Max	.8919	1.0057	.9907	1.0268	.9668	1.048	1.0087
Min	.3352	.3077	.2996	.2035	.2011	.4864	.1695
Avg	.6054	.6808	.6686	.7316	.5942	.7936	.7286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094057 / 33/11 KV SUB BETAWAD

Feeder No / Name : 201 / 11 KV BETAWAD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.7676	.6944				
2	.6516	.7526	.679				
3	.6516	.7628	.6706				
4	.6602	.7926	.7011				
5	.6748	.8333	.7926				
6	.7042	.8688	.884				
7	.7042	.8025	.8796				
8	.7613	.7335	.7827				
10				.7375	.8768	.828	
11				.7676	.8333	.8128	.7526
12				.884	.8362	.7922	.8128
13				.8535	.8429	.7482	.7977
14				.823	.8579	.6602	.7727
15				.8642	.8333	.7335	.7727
16				.8488	.7526	.7727	.8173
17				.8429	.7811	.6661	.8471
23	.7074	.7011					
24	.7225	.7468	.7011				
Max	.7613	.8688	.884	.884	.8768	.828	.8471
Min	.6516	.7011	.6706	.7375	.7526	.6602	.7526
Avg	.6889	.7762	.7539	.8277	.8268	.7517	.7961

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094057 / 33/11 KV SUB BETAWAD

Feeder No / Name : 202 / 11 KV BETAWAD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7602	.8589	.8505	.815	.7442	.7545	.8238
2	.7602	.8413	.8505	.7628	.7362	.7282	.8059
3	.7602	.8149	.8505	.7888	.7442	.7087	.8059
4	.823	.9568	.8954	.8507	.8059	.8238	.8507
5	.8596	1.1104	.9774	1.0454	.9313	.905	.9774
6	1.0425	1.086	1.0608	1.0749	1.2071	.9922	1.086
7	.9955	1.1827	.9145	.9945	.9231	.788	.8596
8	.7973	.9313	.9412	.9816	.9568	.8589	.9036
9	.8589	1.086	.9492	.9671	.8059	1.0136	.8842
10	.9568	1.0387	.985	.964	.7888	1.0208	
11	.9114	.9568	.9465	.9036	1.0099	1.1041	.9391
12	.8573	.9391	1.0029	.8939	1.0974	.9465	.9568
13	.9313	.9568	.9465	.929	.9465	1.0099	.9568
14	.9362	.9745	.8916	.929	1.0029	1.0099	.9568
15	1.0208	1.0166	.9189	.964	.9536		.9745
16	1.0517	.8939	.9214	.9465	.9922	.964	.9189
17	1.0099	.8063	.9214	.9536	.9088	.9431	.9015
18	.985	.7455	.8745	.9156	1.0387	1.0174	.9709
19	.9945	.7108	.9774	.9945	1.1041	1.0923	1.046
20	.9391	.9362	1.182	1.2357	1.2226	1.2403	1.0288
21	.9465	.9709	1.1096	1.2357	1.1568	1.0808	1.0117
22	.9431	.9189	.8916	1.0099	1.1104	.9745	.9709
23	.9015	.8764	.8775	.9492	.8145	.9214	.9114
24	.8145	.8417	.8505	.7888	.8059	.7373	.8596
Max	1.0517	1.1827	1.182	1.2357	1.2226	1.2403	1.086
Min	.7602	.7108	.8505	.7628	.7362	.7087	.8059
Avg	.9107	.9355	.9411	.9539	.9503	.9407	.9305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094057 / 33/11 KV SUB BETAWAD

Feeder No / Name : 241 / 11 KV INCOMER I

Feeder KV- 11 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4918	1.7147	1.4352	.7888	.7202	.7545	.8238
2	1.4918	1.6804	1.4198	.7545	.7202	.7202	.8059
3	1.4918	1.6975	1.4022	.7716	.7202	.6859	.8059
4	1.5432	1.8176	1.4632	.8059	.7716	.8059	.8507
5	1.5947	1.6461	1.6156	1.0117	.8916	.8573	.9774
6	1.8004	2.0062	1.768	1.0631	1.1317	.9602	1.086
7	1.7661	2.0233	1.6512	.9945	.8745	.7545	.8596
8	1.6975	1.749	1.5653	.9602	.9259	.8402	.9036
9	.8402	1.0288	.9492	.9259		.9602	.8842
10	.9259	.9945	.985	1.7833	1.6975	1.8861	
11	.8916	.9568	.9259	1.749	1.9033	1.9547	1.5503
12	.8573	.9391	.9602	1.869	2.0748	1.893	1.6255
13	.8916	.9568	.9259	1.869	1.8861	1.9136	1.6105
14	.9259	.9745	.8916	1.8347	1.9376	1.8073	1.5752
15	.9774	1.0166	.9088	1.9033	1.869	.8764	1.5901
16	1.0288	.8939	.8916	1.869	1.8176	1.8755	1.6049
17	.9774	.8063	.8916	1.9033	1.7661	1.7318	1.6406
18	.9431	.7455	.8745	.9259	.9945	1.0174	.9709
19	.9945	.7108	.9774	.9945	1.046	1.0923	1.046
20	.9088	.9362	1.1317	1.1831	1.1831	1.2403	1.0288
21	.9259	.9709	1.0974	1.1831	1.1317	1.0808	1.0117
22	.9431	.9189	.8916	.9774	1.0631	.9745	.9709
23	1.6975	1.4632	.8402	.9088	.7716	.9214	.9114
24	1.5947	1.6461	1.4327	.7716	.7716	.7373	.8596
Max	1.8004	2.0233	1.768	1.9033	2.0748	1.9547	1.6406
Min	.8402	.7108	.8402	.7545	.7202	.6859	.8059
Avg	1.2167	1.2622	1.1623	1.2417	1.2465	1.1809	1.1302

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094057 / 33/11 KV SUB BETAWAD

Feeder No / Name : 421 / 33 KV INCOMER-1 BETAWAD SS NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / INCOMING

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6575	1.8861	1.7718	.8573	.8002	.8002	.8573
2	1.6575	1.829	1.7718	.8002	.8002	.8002	.8573
3	1.6575	1.8861	1.7718	.8573	.8002	.743	.8573
4	1.7147	2.0005	1.829	.8573	.8573	.8573	.8573
5	1.7718	1.829	2.0005	1.086	.9717	.9145	1.0288
6	2.0005	2.2291	2.2291	1.1431	1.2574	1.0288	1.1431
7	1.9433	2.2291	2.0576	1.086	.9717	.8002	.9145
8	1.8861	1.9433	2.0005	1.0288	1.0288	.9145	.9717
9	.9145	1.1431	1.0288	1.0288	.8573	1.0288	.9717
10	1.0288	1.086	1.0288	1.9433	1.8861	2.0576	
11	.9717	1.0288	1.0288	1.9433		2.1719	2.0005
12	.9145	1.0288	1.0288	2.0576	2.2862	2.0576	2.0576
13	.9717	1.0288	1.0288	2.0576	2.0576	2.0576	2.0576
14	1.0288	1.0288	.9717	2.0005	2.1148	1.9433	2.0005
15	1.086	1.086	.9717	2.1148	2.0576	.9717	2.0576
16	1.1431	.9717	.9717	2.0576	2.0005	2.0005	2.0576
17	1.086	.8573	.9717	2.1148	1.9433	1.8861	2.0576
18	1.0288	.8002	.9717	1.0288	1.086	1.1431	1.086
19	1.086	.8002	1.086	1.086	1.1431	1.2003	1.1431
20	.9717	1.0288	1.2574	1.3146	1.3146	1.3146	1.1431
21	1.0288	1.086	1.2003	1.3146	1.2574	1.1431	1.1431
22	1.0288	1.0288	.9717	1.086	1.1431	1.0288	1.086
23	1.8861	1.829	.9145	.9717	.8573	.9717	.9717
24	1.7718	1.829	1.7718	.8573	.8573	.8002	.9145
Max	2.0005	2.2291	2.2291	2.1148	2.2862	2.1719	2.0576
Min	.9145	.8002	.9145	.8002	.8002	.743	.8573
Avg	1.3432	1.3956	1.3598	1.3622	1.3196	1.2765	1.3146

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094026 / 33/11KV INDAVE

Feeder No / Name : 201 / BALSANE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	.823					
2	1.0631	.8916					
3	1.0974	1.0288					
4	1.1145	1.166					
5	1.166	1.2174					
6	1.3717	1.286					
7	2.0576	1.3375					
8	1.6804	1.5089					
9		1.1317					
10			1.4918	1.4403	1.5775	1.286	
11				1.4575	1.9033	1.6804	1.5775
12				1.4575	1.7147	1.7318	1.5432
13			2.5206	1.3717	1.3546	1.5775	1.6118
14			1.3717	1.2689	1.0117	1.166	
15			1.5089	1.2346	1.0802	1.0288	
16			1.4232	1.2003	1.1317	.8916	
17			1.406	1.2003	1.2003	.823	1.9376
24	.8916	.7202					
Max	2.0576	1.5089	2.5206	1.4575	1.9033	1.7318	1.9376
Min	.8916	.7202	1.3717	1.2003	1.0117	.823	1.5432
Avg	1.2746	1.1111	1.6204	1.3289	1.3718	1.2731	1.6675

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094026 / 33/11KV INDAVE

Feeder No / Name : 202 / HATI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3429	.4801	.4115	.3944	
2			.3601	.4801	.4458	.4115	
3			.3772	.4801	.5144	.4115	
4			.3772	.5144	.5144	.4115	
5			.3944	.5144	.5316	.4458	
6			.7716	1.3032	1.0288	1.166	
7			.9945	1.3717	1.3203	1.3375	
8			.7888	.9602		.8573	
9			.6001		.4458		
10	.6516	1.1145					1.7147
11	1.286	1.3546					1.5775
12	1.0117	.703					
13		.6859					
14	.8916	.6859					
15	.9945	.6687					
16	.7545	.6516					
17	.7545	.6344					
24			.3429	.4458	.4458	.4115	
Max	1.286	1.3546	.9945	1.3717	1.3203	1.3375	1.7147
Min	.6516	.6344	.3429	.4458	.4115	.3944	1.5775
Avg	.9063	.8123	.5350	.7278	.6287	.6497	1.6461

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094026 / 33/11KV INDAVE

Feeder No / Name : 203 / HATTI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2229	.2058	.1543	.2058	.2058	
2	.2401	.2743	.2401	.1543	.2229	.2401	
3	.3429	.3086	.3086	.1715	.3258	.3086	
4	.4801	.5144	.3772	.3772	.4801	.3772	
5	.6001	.5487	.6173	.5658	.6001	.583	
9		.4801	.5316		.5144	.5144	
10	.3944	.3772	.3772	.3429	.3429	.3258	.3429
11	.2058	.2915		.3429	.3086	.2401	.3258
12	.2058	.2915		.2743	.2915	.2229	.2915
13	.2401	.2915	.2915	.2572	.2743	.2058	.2743
14	.2743	.3086	.2743	.2743	.2401	.2401	.2743
15	.2915	.3258	.3086	.2915	.2743	.2572	.3429
16	.2915	.3429	.3429	.3258	.3086	.3086	.3601
17	.3258	.3772	.4115	.3429	.3258	.3429	.4287
20	.5658	.8402	.7888	.7888	.8402	.6687	.9088
21	.5144	.6173	.6173	.6344	.6687	.5144	
22	.3086	.3772	.3772	.3258	.3772		
23	.2058	.2229	.2401	.2058	.2572		
24	.2401	.2058	.1886	.1715	.2058	.2058	
Max	.6001	.8402	.7888	.7888	.8402	.6687	.9088
Min	.2058	.2058	.1886	.1543	.2058	.2058	.2743
Avg	.3325	.3799	.3823	.3334	.3718	.3389	.3944

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094026 / 33/11KV INDAVE

Feeder No / Name : 205 / AICHALE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4115	.8916	.4973	.8573	
2			.4458	.8573	.5144	.8402	
3			.5144	.823	.5487	.8745	
4			.583	.7716	.6687	.8573	
5			.6687	.7716	.8402	.8573	
6			1.0288	1.4232	1.1145	1.1145	
7			1.2174	1.4575	1.4232	1.3717	
8			1.0117	1.2003	1.1145	1.1831	
9			.8059	.8916	.9602	.6516	
10	1.1145	.9945					1.4575
11	1.3375	1.4232					1.4918
12	1.286	1.2689					
13		1.0288					
14	.6859	1.0117					
15	.823	.9431					
16	1.0802	1.0117					
17	1.166	1.046					
24			.3944	.8916	.5144	.8573	
Max	1.3375	1.4232	1.2174	1.4575	1.4232	1.3717	1.4918
Min	.6859	.9431	.3944	.7716	.4973	.6516	1.4575
Avg	1.0704	1.0910	.7082	.9979	.8196	.9465	1.4747

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094026 / 33/11KV INDAVE

Feeder No / Name : 206 / INDAVE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2058					
2	.3086	.2058					
3	.3258	.2401					
4	.4115	.3086					
5	.4801	.4801					
6	.6687	.6173					
7	1.166	.8573					
8	.9259	.9774					
9	.5658	.6516					
10			.583	.5144	.7202	.5316	
11				.6001	.8573	.6859	.6173
12			.7545	.6859	.7716	.7716	.6516
13			.7202	.6001	.6859	.6859	.6516
14			.6173	.6001		.6687	.6173
15			.583	.5658	.6859	.5658	.6516
16			.7202	.6173	.7716	.5658	.6859
17			.6859	.823	.8573	.6173	.7202
24	.2401	.2058					
Max	1.166	.9774	.7545	.823	.8573	.7716	.7202
Min	.2401	.2058	.583	.5144	.6859	.5316	.6173
Avg	.5367	.4750	.6663	.6258	.7643	.6366	.6565

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094026 / 33/11KV INDAVE

Feeder No / Name : 207 / BALSANE GAOTHAN

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.4115	.4115	.4115	.3429	.4115	
2	.4115	.4801	.4458	.4115	.3601	.4287	
3	.5144	.5144	.4801	.4801	.4458	.4801	
4	.5487	.5658	.6173	.5487	.5487	.583	
5	.7888	.7888	.823	.7545	.7888	.7888	
9	.9259	.7545	.9602	.8916	.9602	.8916	
10	.6859	.6859	.8059	.6516	.6516	.7202	.7888
11	.5487	.6173		.583	.6173	.5144	.6516
12	.5144	.5316	.4801	.5487	.5144	.4458	.5487
13	.5144	.5144	.5487	.5144	.5144	.3772	.5487
14	.5487	.4458	.5487	.5144	.4973		.5316
15	.583	.463	.583	.5487	.5144		.5487
16	.6344	.4801	.583	.5144	.5487	.6173	.5487
17	.583		.5658	.5316	.583	.6859	.6173
18						.823	
19						.8916	
20	.9259	1.0802	1.1145	1.2003	1.0974	.8402	1.0288
21	.8573	.7716	.7888	.7888	.8402	.7716	
22	.5658	.6173	.5487	.5316	.5658		
23	.4287	.463	.4458	.3944	.4287		
24	.4115	.4115	.4115	.4115	.3601	.4115	
Max	.9259	1.0802	1.1145	1.2003	1.0974	.8916	1.0288
Min	.4115	.4115	.4115	.3944	.3429	.3772	.5316
Avg	.6001	.5887	.6201	.5911	.5884	.6284	.6459

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094026 / 33/11KV INDAVE

Feeder No / Name : 208 / 11 KV BOKADBALLA AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.2229					
2	.3601	.2743					
3	.3258	.3086					
4	.4115	.3086					
5	.5316	.3429					
6	.6516	.823					
7	.7202	.8916					
8	.7373	.8916					
9	.6001	.6173					
10			.6516	.7202	.5316	.5487	
11				.8059	1.0288	.6516	.7545
12			1.2346	.8059	.9431	.8573	.7545
13			1.0288		.7545	.703	.6859
14			.6687	.5144	.583	.6516	.5316
15			.6859	.4973	.5658	.5487	.5487
16			.6516	.5144	.5487	.5144	.5144
17			.6001	.5316	.5144	.5144	.6001
24	.3258	.2058					
Max	.7373	.8916	1.2346	.8059	1.0288	.8573	.7545
Min	.3258	.2058	.6001	.4973	.5144	.5144	.5144
Avg	.5007	.4887	.7888	.6271	.6837	.6237	.6271

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094047 / Nimgul 33/11 KV S/S

Feeder No / Name : 201 / NIMGUL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.2561
2						.2587
3						.2561
4						.2772
5						.2957
6						.3292
7						.2743
8						.2402
9	.3429	.2401	.2572	.2915	.2572	.2353
10	.3258	.2743	.2401	.2572	.3982	
11	.2915	.2229	.2401	.2229	.3547	
12	.2915	.2229	.2572	.2401	.1991	
13	.2743	.2058	.2572	.2401	.2772	
14	.2743	.1543	.2401	.2401	.3326	
15	.2743	.2572	.2743	.2401	.3841	
16	.2572	.2743	.2743	.3086	.2896	
17	.2229				.4251	
18	.2401				.3881	
19	.2915				.3361	
20	.3258				.4024	
21	.3086				.3292	
22	.2915					
23	.2743				.2987	
24						.2743
Max	.3429	.2743	.2743	.3086	.4251	.3292
Min	.2229	.1543	.2401	.2229	.1991	.2353
Avg	.2858	.2315	.2551	.2551	.3337	.2697

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217] BU 5525

Substation No/ Name :- 094047 / Nimgul 33/11 KV S/S

Feeder No / Name : 203 / Pathare Ag
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	16-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
8			.3206
9		.6173	.2804
10	.3429		
11	.3258		
12	.583		
13	.6173		
14	.6516		
15	.6516		
16	.6859		
Max	.6859	.6173	.3206
Min	.3258	.6173	.2804
Avg	.5512	.6173	.3005

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094047 / Nimgul 33/11 KV S/S

Feeder No / Name : 204 / PANI-PURWATHA TAVKHEDA NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.2353
2						.2587
3						.2561
4						.2534
5						.2561
6						.2534
7						.2561
8						.2534
9	.2401	.2401	.2572	.2572	.2401	.1829
10	.2401	.1886	.2572	.2572		
11	.2401	.2572	.2572	.2572	.2561	
12	.2229	.2572	.2572	.2401	.2587	
13	.2229	.2572	.2572	.2572	.2561	
14	.2401	.1886	.2572	.2572	.2534	
15	.2401	.2572	.2401	.2572	.2561	
16	.2401	.2572	.1886	.2572	.2587	
17			.3772	.2401	.2054	
18					.2614	
19					.2587	
20					.2614	
21					.2587	
22					.0943	
23					.2587	
24						.1829
Max	.2401	.2572	.3772	.2572	.2614	.2587
Min	.2229	.1886	.1886	.2401	.0943	.1829
Avg	.2358	.2379	.2610	.2534	.2413	.2388

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094062 / 33/11 KV Dondaicha (Tapi

Sagar

Feeder No / Name : 201 / 11Kv Dondaicha (Tapi

SHEDDABLE URBAN

Sagar) Feeder KV- 11 /
OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2862	2.4387	2.3148	2.1948	2.6578	2.3624	2.7435
2	2.0576	2.2862	2.1776	2.21	2.6578	2.3624	2.7435
3	2.0881	2.2862	2.1605	2.2558	2.572	2.2862	2.6578
4	2.3472	2.21	2.2291	2.2558	2.4863	2.3624	2.6578
5	2.3624	2.21	2.2119	2.2862	2.4863	2.1491	2.7435
6	2.3472	2.3015	2.4348	2.3015	2.572	2.3167	2.8292
7	2.3015	2.3015	2.3663	2.1643	2.4863	2.2862	
8	2.0729	2.6063	2.3834	2.0271	2.21	2.21	2.5034
9	2.3015	2.4863	2.2405	2.3491	2.1643	2.4234	2.5549
10	2.2862	2.5206	2.2558	2.6063	2.3015	2.7435	2.7435
11	2.4691	2.572	2.4539	2.572	2.4996		2.8978
12	2.3929	2.6578	2.5301	2.6235	2.6368		2.915
13	2.3624	2.6749	2.5301	2.7092	2.6216	3.0864	2.9664
14	2.5149	2.7092	.2134	2.9321	2.7587	3.1722	3.035
15	2.7435	2.7435	2.5149	2.9321	2.9721	3.3093	3.2065
16	2.8045	2.8635	2.4387	3.0178	2.8807	3.0693	2.915
17	2.5911	2.6578	2.4387		2.6368	2.8807	1.9719
18	2.4539	2.4863	2.1491	2.7092	2.4844	2.6749	3.0007
19	2.5453	2.6406	2.271	2.8464	2.5453	3.0521	3.2407
20	2.774	3.0693	2.4387	3.3436	2.9721	3.4979	3.3093
21	2.7435	3.1722	2.6978	3.1722	2.8349		3.2407
22	2.6978	2.8464	2.6063		2.8045	2.915	3.2922
23	2.6978	2.7778	2.4387		2.6063	2.915	
24	2.4082	2.5911	2.4863	2.3929	2.8292	2.4691	2.8978
Max	2.8045	3.1722	2.6978	3.3436	2.9721	3.4979	3.3093
Min	2.0576	2.21	.2134	2.0271	2.1643	2.1491	1.9719
Avg	2.4437	2.5879	2.2909	2.5668	2.6116	2.6926	2.8666

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094062 / 33/11 KV Dondaicha (Tapi
SagarFeeder No / Name : 202 / Universal Starch Allied NON SHEDDABLE EXPRESS HV FEEDERS
(USA) Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5182	.503	.5316	.4877	.5487	.4877	.3429
2	.5182	.5182	.5144	.5182	.5487	.4572	.3429
3	.5335	.5182	.5487	.5182	.5316	.4725	.3772
4	.5487	.503	.5487	.5487	.5316	.4725	.3772
5	.5639	.503	.5658	.5487	.5487	.4877	.3601
6	.5335	.5335	.6001	.5487	.5487	.4877	.3772
7	.4877	.503	.583	.5182	.5487	.4877	.4287
8	.5182	.583	.5658	.4877	.5182	.5182	.4115
9	.503	.6344	.5182	.5487	.5182	.5487	.4115
10	.6097	.5658	.5335	.5658	.4877	.5658	.5658
11	.5335	.5658	.5182	.5658	.5182		.5316
12	.5182	.5144	.503	.6173	.5182	.5144	.5144
13	.5182	.8059	.503	.6001	.4877	.2401	.5144
14	.503	.7202	.5487	.583	.4725		.5316
15	.5182	.6859	.2286	.583	.5182	.2572	.5487
16	.5182	.6344	.8383	.5658	.4877	.2572	.5487
17	.5182	.6173	.5182		.4725	.5658	.5316
18	.4877	.583	.2134	.5316	.5182	.5487	.5316
19	.4877	.5487	.3506	.5144	.4877	.2572	.5144
20	.4877	.4287	.3506	.5487	.4725	.5658	.5144
21	.5182	.4973	.4877	.5144	.4725	.5144	.4801
22	.4877	.5316	.4877		.4725	.4973	.4973
23	.5182	.5316	.5335		.381	.5144	
24	.503	.5182	.5487	.5335	.5487	.1981	.6173
Max	.6097	.8059	.8383	.6173	.5487	.5658	.6173
Min	.4877	.4287	.2134	.4877	.381	.1981	.3429
Avg	.5188	.5645	.5058	.5452	.5066	.4507	.4727

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094070 / 33/11KV VIKHARAN(DEVACHE)

SUBS

Feeder No / Name : 201 / VIKHARAN GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5175	.5175	.5914	.5729	.5175	.5175	.3326
2	.5359	.499	.6653	.5914	.5544	.5359	.3696
3	.5359	.5544	.7392	.6283	.7023	.5914	.4066
4	.6468	.5914	.8131	.7392	.8871	.7392	.4435
5	.7947	.7023	.8871	.8131	.9979	.8686	.4805
6	.7947	.8316	.961	.8871	1.0349	.924	.5359
7	.7392	.7947	.961	.8131	.9425	1.0719	.3881
8	.8131	.7577	.9425	.8131	.8316	.9795	.4066
9	.7762	.7023	.9055	.6062	.8131	.8871	.3881
10	.7392	.7762		.7023	.7392	.7762	.6653
11	.6653		.7023	.7023	.6653	.7023	.6653
12	.6283	.7762	.6283	.6468	.6468	.7207	.7392
13	.5914	.7023	.5914	.6283	.5544	.7577	.8686
14		.7207	.6099	.6468	.7207	.7392	.6653
15	.6653	.7023	.6283	.6653	.7577	.7392	.6653
16	.7392	.7392	.6468	.6838	.7762	.7392	.6838
17	.7392	.8131	.6653	.6838	.7577	.7207	.8131
18		.8501	.8686	.8131	.8686	.8686	.8501
19	1.0534	1.1458	.9055	1.0719	1.0903	1.0719	.7023
20	1.1273	1.1827	.9425	.9795	1.1643	1.1458	1.0719
21	.7577	.9055	.8131	.8501	.8131		.9795
22	.6838	.6838	.6099	.7023	.7023	.3696	.9795
23	.6283	.5729	.499	.5544	.5914	.3142	
24	.499	.5729	.5544		.4805	.5544	
Max	1.1273	1.1827	.961	1.0719	1.1643	1.1458	1.0719
Min	.499	.499	.499	.5544	.4805	.3142	.3326
Avg	.7123	.7432	.7448	.7302	.7754	.7537	.6409

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094070 / 33/11KV VIKHARAN(DEVACHE)

SUBS

Feeder No / Name : 202 / PEDKAI MATA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3948	.3807					
2	.423	.3948					
3	.6344	.423					
4	.6767	.4512					
5	.7331	.5639					
6	.7472	.6908					
7	.7472	.7613					
8	.7613	.8177					
9	.5921	.5498					
10				.5216	.5921	.5921	.6485
11			.8882	.6767	.7049	.7049	.6485
12			.578	.578	.5639	.5639	.6626
13			.7049	.4652	.423	.5639	.6344
14			.7049	.5357	.5075	.5216	.6485
15			.6626	.5075	.5498	.5357	.6203
16			.6203	.6653	.5639	.6203	.6062
17			.6344	.5921	.6203	.7472	.6203
24	.3807	.3666					
Max	.7613	.8177	.8882	.6767	.7049	.7472	.6626
Min	.3807	.3666	.578	.4652	.423	.5216	.6062
Avg	.6091	.5400	.6848	.5678	.5657	.6062	.6362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094070 / 33/11KV VIKHARAN(DEVACHE)

SUBS

Feeder No / Name : 203 / KHARDE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4793	.423	.4938	.4664	.6485
2			.5498	.5075	.5213	.439	.8036
3			.6203	.5498	.5487	.6584	
4			.6767	.5639		.727	
5			.7472	.5921		1.1385	
6			.8177	.6062		1.2071	
7			.9587	.4934		1.0562	1.001
8			.8318	1.1138	1.2071	.9328	1.0715
9			.86	.7613	.9877	.5761	.8036
10	.6859	.9728					.5487
11	1.0425	1.001					
12	.6584	.8177					
13	.5213	.7613					
14	.6036	.7331					
15	.5898	.8459					
16	.5487	.6344					
17	.6859	.6203					
23		.423					
24			.4371		.439	.4938	.5075
Max	1.0425	1.001	.9587	1.1138	1.2071	1.2071	1.0715
Min	.5213	.423	.4371	.423	.439	.439	.5075
Avg	.6670	.7566	.6979	.6234	.6996	.7695	.7692

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094075 / 33/11KV MALPUR SUBSTATION

Feeder No / Name : 201 / 11KV MALPUR GAOTHAN 2

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.4973	.5316	.3086	.3429	.7716	.3772
2	.5144	.5316	.6173	.3772	.4115	.9431	.4115
3	.5487	.6516	.6687	.4115	.4801	1.0631	.463
4	.6173	.703	.7545	.4801	.6173	1.046	.4973
5	.7202	.7716	.8402	.5487	.7545	1.0288	.5316
6	.8059	.823	.8745	.6173	.8573	.9945	.583
7	.8916	.8745	.9259	.6859	.9431	1.0117	.6344
8	.8573	.823	.8402	.8402	.8916	.8745	.463
9	.823	.7545	.703	.8059	.8745	.8402	.6687
10	.7545	.7545	.7373	.703	.6687	.7202	.7202
11	.6344	.6001	.6859	.6001	.6516	.6516	.5487
12	.583	.5316	.6344	.5487		.6859	.6859
13	.5487	.5316	.5487	.5144		.4801	
14	.5316	.5144	.5658	.5487		.6516	
15	.583	.5144	.583	.5487		.5658	
16	.6344		.5487	.583	.823	.6173	
17	.6344	.5658	.583	.583	.823	.6173	
18	.6173	.8059	.6344	.823	.8745	.7545	
19	.8573	.8916	.8402	.8573	.823	.9602	
20	.7716	1.0288	1.046	.9431	.7888	.9774	
21	.7202	.823	.7545	.823	.7545	.7202	
22	.6516	.6859	.6687	.6516	.703		
23	.5316	.583	.5658	.5487	.6173	.6859	
24	.5487	.5658	.5316	.4973	.5144	.7888	.3772
Max	.8916	1.0288	1.046	.9431	.9431	1.0631	.7202
Min	.5144	.4973	.5316	.3086	.3429	.4801	.3772
Avg	.6623	.6881	.6952	.6187	.7107	.8022	.5355

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094075 / 33/11KV MALPUR SUBSTATION

Feeder No / Name : 202 / 11KV KARLE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5316	.3086	.2743	.2572	
2			.583	.3429	.3086	.3944	
3			.6516	.4287	.3772	.5144	
4			.6859	.5144	.4801	.583	
5			.7373	.6001	.6001	.6859	
6			.7888	.6859	.6859	.7716	
7			.823	.7888	.823	.8573	.6516
8			.6173	.6344	.7373	.6344	.9088
9			.5487	.5316	.5658	.5487	.6859
10	.6516	.7888					.5487
11	.7545	.4801					.4801
12	.6859	.6859					.4973
13	.6173	.5487					
14	.5144	.5144					
15	.4458	.5316					
16	.5316	.5487					
17	.6344	.3086					
24			.4458	.4115	.1715	.1886	
Max	.7545	.7888	.823	.7888	.823	.8573	.9088
Min	.4458	.3086	.4458	.3086	.1715	.1886	.4801
Avg	.6044	.5509	.6413	.5247	.5024	.5436	.6287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094075 / 33/11KV MALPUR SUBSTATION

Feeder No / Name : 203 / 11KV SURAY AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715					
2	.1715	.2401					
3	.2058	.2058					
4	.2401	.2743					
5	.2743	.3086					
6	.3086	.3429					
7	.3772	.3601					
8		.2743					
9		.1715					
10				.1886	.2058	.2058	
11	.0686		.3086	.2401	.2572	.3601	
12			.1543	.2058	.2058	.3258	.12
13			.2058	.1886	.2058	.2401	
14			.1715	.2058	.2058	.1715	
15				.1715	.2401	.2058	
16				.2229	.2915	.2401	
17			.1715	.2229	.2572		
18			.2401				
19			.2058				
20			.1543				
24	.1372	.1029					
Max	.3772	.3601	.3086	.2401	.2915	.3601	.12
Min	.0686	.1029	.1543	.1715	.2058	.1715	.12
Avg	.2172	.2452	.2015	.2058	.2337	.2499	.12

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094005 / 33/11 KV SHINDKHEDA

Feeder No / Name : 201 / 11KV AKKADSE AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1145						
2	1.1145						
3	1.1145						
5	1.1145						
7	1.4575						
8	1.3717						
9		1.0288					
10		1.2003	1.2003	1.2003	1.2003	1.0288	1.0288
11		1.0288		1.2003	1.3717	1.286	1.0288
12		1.0288		1.3717	1.3717	1.2003	1.0288
13				1.286	1.3717	1.2003	1.0288
14			.6859	1.3717	1.3717	1.2003	1.0288
15			1.4575	1.3717	1.3717	1.1145	1.0288
16			1.4575	1.3717	1.3717	1.0288	1.0288
17			1.4575	1.3717	1.2003	1.0288	1.0288
18			1.4575				
19			1.4575				
24	1.1145	1.0288					
Max	1.4575	1.2003	1.4575	1.3717	1.3717	1.286	1.0288
Min	1.1145	1.0288	.6859	1.2003	1.2003	1.0288	1.0288
Avg	1.2002	1.0631	1.3105	1.3181	1.3289	1.1360	1.0288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094005 / 33/11 KV SHINDKHEDA

Feeder No / Name : 202 / 11KV VIRDEL AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8861	2.1434		1.4575	.5144	.5144	1.0288
2				1.4575		.5144	1.0288
3	1.8861			1.4575	.5144	.5144	1.0288
4				1.4575	.5144	.6001	1.0288
5	1.8861			1.4575	.5144	.6001	1.8004
6	2.6578			1.6289	.6001	.6001	1.8004
7	2.6578			1.6289	.6859	.6859	1.8004
8				1.6289	.6859	.6859	1.8004
9				1.8861	.6859	.6859	1.7147
10			1.9719	.6859	.6859		1.2003
11				.7716	.6859		1.7147
12		1.5432	2.572	.7716	1.8861	.1715	1.5432
13		1.7147	2.572	.6859	1.7147	.1715	1.5432
14		2.2291		.6859	1.8004	.2572	1.5432
15		2.2291	2.4006	.6859	1.7147	.2572	1.5432
16			2.2291	.6859	1.7147	.2572	1.5432
17			2.2291	.6859	1.7147		1.5432
18					1.7147		
19					1.7147		
20					1.7147		
23			1.286				
24	1.8861	2.3148		1.4575	.5144	.5144	1.0288
Max	2.6578	2.3148	2.572	1.8861	1.8861	.6859	1.8004
Min	1.8861	1.5432	1.286	.6859	.5144	.1715	1.0288
Avg	2.1433	2.0291	2.1801	1.1765	1.1146	.4687	1.4575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094005 / 33/11 KV SHINDKHEDA

Feeder No / Name : 203 / 11KV CHIMTHANE AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6859					
3	.6859						
6	1.2003						
8	1.2003						
9	1.0288	1.1145					
10		1.286	1.286	1.1145	1.0288	.9431	.5144
11			1.3717	1.2003	1.2003	1.1145	1.166
12		1.0288	1.1145	1.0288	.9431	.8573	
13			.8573	1.0288	.8573	.8573	
14				.9431	.8573	.8573	
15			.7716	.8573	.8573	.9431	
16			.8573	.9431	.8573	.8573	
17			1.0288	1.0288	1.0288	1.0288	.8573
18							.9431
19							.8573
24	.6859	.6859					
Max	1.2003	1.286	1.3717	1.2003	1.2003	1.1145	1.166
Min	.6859	.6859	.7716	.8573	.8573	.8573	.5144
Avg	.9145	.9602	1.0410	1.0181	.9538	.9323	.8676

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094005 / 33/11 KV SHINDKHEDA

Feeder No / Name : 204 / 11KV SHINDKHEDA URBAN

SHEDDABLE URBAN

FEEDER Feeder KV- 11 /
OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.286	1.3717	1.3717	1.286	1.3717	1.3717
2	1.3717		1.3717	1.3717	1.286	1.3717	1.3717
3	1.3717	1.3717	1.3717	1.3717	1.286	1.3717	1.3717
4			1.5432	1.3717	1.286	1.5432	1.3717
5	1.3717	1.4575	1.5432	1.3717	1.286	1.5432	1.3717
6		1.4575	1.7147	1.3717	1.3717	1.7147	1.5432
7		1.4575	1.7147	1.3717	1.3717	1.5432	1.5432
8	1.4575		1.5432		1.3717	1.3717	1.3717
9		1.3717	1.3717	1.3717	1.3717	1.3717	1.3717
10	1.3717		1.286	1.3717	1.4575	1.5432	1.3717
11			1.5432		1.4575	1.5432	1.5432
12	1.3717	1.5432	1.1145	1.5432	1.5432	1.5432	1.5432
13		1.5432	1.5432	1.5432	1.7147	1.5432	1.6289
14	1.5432		1.5432	1.6289	1.7147	1.6289	1.6289
15		1.6289	1.5432	1.6289	1.7147	1.7147	1.7147
16		1.7147	1.6289	1.6289	1.5432	1.7147	1.7147
17	1.2003	1.4575	1.5432	1.6289	1.6289	1.6289	1.3717
18		1.5432	1.4575	1.5432	1.5432	1.5432	1.5432
19	1.5432	1.5432	1.4575	1.6289	1.5432	1.5432	1.7147
20		1.6289	1.4575	1.7147	1.7147	1.7147	1.7147
21	1.7147	1.7147	1.4575	1.7147	1.7147	1.5432	1.7147
22		1.7147	1.4575	1.6289	1.7147	1.5432	1.7147
23	1.3717	1.5432	1.5432	1.5432	1.5432	1.5432	1.7147
24	1.3717	1.3717	1.3717	1.3717	1.3717	1.3717	1.3717
Max	1.7147	1.7147	1.7147	1.7147	1.7147	1.7147	1.7147
Min	1.2003	1.286	1.1145	1.3717	1.286	1.3717	1.3717
Avg	1.4179	1.5194	1.4789	1.5042	1.4932	1.5361	1.5289

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094005 / 33/11 KV SHINDKHEDA

Feeder No / Name : 205 / 11 KV SULWADE EXPRESS

NON SHEDDABLE EXPRESS HV FEEDERS

FEEDER Feeder KV- 11 /

(CONTINUOUS PROCESS)(NO STAGGERING)

OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	20-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	.0343	.0343			
24	.0343	.0343	.0343	.0343	.0343
Max	.0343	.0343	.0343	.0343	.0343
Min	.0343	.0343	.0343	.0343	.0343
Avg	.0343	.0343	.0343	.0343	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094005 / 33/11 KV SHINDKHEDA

Feeder No / Name : 206 / 11 KV TEMLAI + AKKADSE

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429	.3429	.4287	.3429	.3429	.3429
2			.3429	.4287	.3429	.3429	.3429
3	.3429	.3429	.3429	.4287	.3429	.3429	.3429
4		.3429	.3429	.4287	.3429	.4287	.3429
5		.3429		.4287	.4287	.4287	.3429
6	.4287	.3429	.4287	.5144	.5144	.5144	.5144
7		.4287	.5144	.5144	.5144	.5144	.5144
8	.4287	.4287	.5144	.5144	.4287	.4287	.3429
9			.4287	.4287	.4287	.3429	.3429
10	.3429	.5144	.3429	.3429	.4287	.3429	.4287
11				.3429	.4287	.3429	.4287
12	.3429	.3429	.2572	.3429	.4287	.3429	.4287
13		.4287	.3429	.4287	.4287	.3429	.4287
14	.3429		.4287	.4287	.4287	.4287	.4287
15	.3429	.4287	.4287	.4287	.4287	.4287	.4287
16		.4287	.4287	.4287	.3429	.3429	.3429
17	.4287	.4287	.4287	.4287	.4287	.4287	.4287
18		.3429	.3429	.4287	.4287	.5144	.6001
19	.5144	.4287	.4287	.5144	.5144	.5144	.6001
20		.6001	.4287	.6001	.5144	.5144	.5144
21		.5144	.4287	.6001	.5144	.4287	.5144
22	.4287	.4287	.4287	.4287	.4287	.4287	.4287
23	.3429	.4287	.4287	.3429	.3429	.3429	.4287
24	.3429	.3429	.3429	.4287	.3429	.3429	.3429
Max	.5144	.6001	.5144	.6001	.5144	.5144	.6001
Min	.3429	.3429	.2572	.3429	.3429	.3429	.3429
Avg	.3825	.4115	.3975	.4430	.4215	.4072	.4251

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094005 / 33/11 KV SHINDKHEDA

Feeder No / Name : 207 / 11KV CHIMTHANE+VIRDEL

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 /
OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5144	.6001	.5144	.5144	.6001	.6001
2	.5144		.6001	.5144	.5144	.6001	.6001
3	.5144	.5144	.6001	.5144	.5144	.6001	.6001
4				.5144	.5144	.6859	.6001
5	.5144	.7716	.6859	.5144	.6859	.6859	.6001
6		.9431		.8573	.7716	.7716	.8573
7	.9431	.8573	.8573	.8573	.8573	.8573	.8573
8		.6859	.8573	.8573	.7716	.7716	.8573
9	.6859	.5144	.7716		.6859	.6859	.7716
10		.6859	.6859	.6859	.6859	.6859	.6859
11		.6859	.6859	.6859	.6859	.6859	.6859
12	.6859	.7716	.6859	.6859	.6859	.7716	.6859
13	.7716	.7716		.6859	.6859	.7716	.6859
14		.7716	.8573	.7716	.6859	.7716	.6859
15		.7716		.7716	.7716	.7716	.8573
16	.6859	.7716	.8573	.7716	.7716	.7716	.7716
17		.7716		.7716	.7716	.7716	.6859
18	.6859	.7716		.8573	.7716	.7716	.8573
19		.8573	.9431	.9431	.8573	1.0288	1.0288
20	1.0288	1.0288	.5144	1.0288	.9431	1.0288	1.0288
21	.8573	.8573	.5144	.8573	1.0288	.6001	1.0288
22	.7716	.7716	.5144	.6859	.7716	.6001	.8573
23	.5144	.6859	.5144	.6001	.6859	.6001	.8573
24	.5144	.5144	.6859	.5144	.5144	.6001	.6001
Max	1.0288	1.0288	.9431	1.0288	1.0288	1.0288	1.0288
Min	.5144	.5144	.5144	.5144	.5144	.6001	.6001
Avg	.6802	.7404	.6906	.7157	.7145	.7287	.7644

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094005 / 33/11 KV SHINDKHEDA

Feeder No / Name : 208 / 11KV TEMLAY AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.8573	1.0288	.8573	1.0288	.8573
2			.8573	1.0288	.8573	1.0288	.8573
3			.8573	1.0288	.8573	1.0288	.8573
4			.8573	1.0288	.8573	1.0288	.8573
5			1.0288	1.0288	1.0288	1.0288	.8573
6			1.0288		1.2003	1.2003	1.2003
7			1.0288		1.3717	1.2003	1.2003
8			1.0288	1.3717	1.286	1.2003	1.2003
9			1.0288	1.3717	1.2003	1.2003	1.2003
10	1.3717						
12	1.2003	1.2003					
13		1.2003					
14	1.2003						
15		1.2003					
16	1.0288						
17		1.1145					
18		1.0288					
19		.8573					
20		.8573					
23		.8573					
24			.8573	1.0288	.8573	1.0288	.8573
Max	1.3717	1.2003	1.0288	1.3717	1.3717	1.2003	1.2003
Min	1.0288	.8573	.8573	1.0288	.8573	1.0288	.8573
Avg	1.2003	1.0395	.9431	1.1145	1.0374	1.0974	.9945

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094017 / 33/11 CHIMTHANE

Feeder No / Name : 201 / 11KV AARAVE AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8688	.6401					
2	.945	.6859					
3	.9755	.7316					
4	1.0212	.7926					
5	1.0364	.884					
6	1.0669	.945					
7	1.1736	1.0669					
8	1.0822	1.0974					
9	.9145	.9145					
10			.9755	.945	.9907	1.0059	
11			1.2651	1.1584	1.0364	1.1126	1.1888
12			1.1431	.9907	1.0669	.9907	1.0669
13			1.0059	.9297	.9907	.9297	1.1431
14			1.0059	.9145	.9145	.945	1.0974
15			.5487	.9602	.945	.8993	1.0364
16			.884	.9907	.9907	.9145	.9907
17			1.0822	1.0212	1.0669		1.0059
24		.5639					
Max	1.1736	1.0974	1.2651	1.1584	1.0669	1.1126	1.1888
Min	.8688	.5639	.5487	.9145	.9145	.8993	.9907
Avg	1.0093	.8322	.9888	.9888	1.0002	.9711	1.0756

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094017 / 33/11 CHIMTHANE

Feeder No / Name : 202 / 11KV CHIMTHANE AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / INCOMING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5792	.4572					
2	.6249	.5335					
3	.7011	.6097					
4	.7316	.6859					
5	.7926	.7621					
6	.7621	.8383					
7	1.0059	.9145					
8	.8535	.7621					
9	.7468	.6859					
10			.6554	.6097	.7621	.6554	.7011
11			.8078	.8383	.8383	.7316	.7316
12			.8688	.6859	.6859	.7011	.6859
13			.7468	.6097	.6097	.6859	.7316
14			.4877	.6401	.5792	.7468	.7621
15			.7164	.6706	.5335	.7773	.6706
16			.7468	.6554	.4572	.7621	.7011
17			.6554	.6859	.6859	.8535	.6859
24		.4572					
Max	1.0059	.9145	.8688	.8383	.8383	.8535	.7621
Min	.5792	.4572	.4877	.6097	.4572	.6554	.6706
Avg	.7553	.6706	.7106	.6745	.6440	.7392	.7087

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094017 / 33/11 CHIMTHANE

Feeder No / Name : 203 / 11KV KHALANE AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3048	.5335	.6097	.381	.381
2			.3048	.5792	.6401	.4572	.4572
3			.3048	.6401	.6554	.5639	.5335
4			.381	.7164	.7011	.6401	.6097
5			.4572	.8078	.7621	.6859	.7621
6				.884	.8383	.7621	.8383
7			.9145	1.0822	.9145	.9145	.945
8			.7621	.9145	.945	.8383	.9297
9			.6097	.6859	.7164	.6859	.7011
10	.9145	.6097					
11	1.0669	.7621					
12	1.1431	.6859					
13	.8383	.6859					
14	.7621	.4572					
15	.7621	.4572					
16	.7621	.8383					
17	.6859	.5335					
24			.503		.4572	.4115	
Max	1.1431	.8383	.9145	1.0822	.945	.9145	.945
Min	.6859	.4572	.3048	.5335	.4572	.381	.381
Avg	.8669	.6287	.5047	.7604	.7240	.6340	.6842

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094017 / 33/11 CHIMTHANE

Feeder No / Name : 204 / 11KV SHEWALE GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.2743	.2286	.3506	.3353	.2743	.381
2	.381	.0122	.2286	.381	.3048	.3353	.4572
3	.4572	.3658	.3048	.4572	.3201	.381	.5335
4	.4572	.381	.381	.5335	.3658	.4268	.4572
5	.4572	.4268	.4572	.5335	.3506	.4725	.4572
6	.4572	.4572	.4877	.4572	.4572	.5182	.4572
7	.4115	.4877	.4572	.381	.5335	.503	.3506
8	.3506	.381	.381	.381	.4572	.4268	.3048
9	.3048	.381	.3048	.3048	.442	.381	.3048
10	.3506	.381	.3048	.3353	.2743	.2591	.3353
11	.3048	.3048	.3353	.3658	.2591	.2591	.3658
12	.2896	.3048	.2286		.3048	.3048	.3353
13	.2591	.381	.3048	.3353	.2743	.3048	.3658
14	.381	.3048	.2591	.3506	.3353	.3048	.381
15	.4115	.3353	.3048	.3658	.3658	.3048	.3963
16	.4268	.3048	.3048	.3353	.381	.3353	.4115
17	.3353	.3048	.3048	.3658	.4115	.381	.442
18	.4268	.381	.381	.3506	.4268	.4115	.4572
19	.5335	.381	.4572	.3658	.5182	.4572	.503
20	.5792	.381	.4877	.3963	.5639	.5335	.5487
21	.503	.4572	.4572	.3353	.503	.4572	.4572
22	.3658	.381	.381	.3658	.4572	.4115	
23	.3201	.3506	.3353	.3506	.4115	.3353	.4268
24		.3048	.3048		.3658	.3506	
Max	.5792	.4877	.4877	.5335	.5639	.5335	.5487
Min	.2591	.0122	.2286	.3048	.2591	.2591	.3048
Avg	.3943	.3510	.3493	.3817	.3925	.3804	.4150

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094017 / 33/11 CHIMTHANE

Feeder No / Name : 205 / 11KV CHIMTHANE GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.3048	.3048	.4115	.3506	.381	.4572
2	.4572	.381	.3048	.4572	.3353	.4268	.5182
3	.5335	.4115	.3048	.503	.3658	.4572	.5639
4	.4877	.4572	.381	.5639	.3963	.503	.6249
5	.5792	.4725	.4572	.6097	.4268	.5335	.6554
6	.6097	.503	.4572	.6401	.4572	.5639	.6859
7	.503	.5335	.5335	.6097	.5335	.5335	.503
8	.5335	.4115	.4572	.4268	.4725	.503	.4572
9	.4572	.4572	.4572	.4572	.4572	.4572	.4572
10	.4572	.381	.4572	.3963	.381	.4115	.442
11	.381	.381	.381	.4268	.381	.3048	.3201
12	.381	.3048	.4115		.381	.3506	.3658
13	.4115	.4572	.4572	.3963	.381	.381	.381
14	.4572	.4572	.4572	.381	.4572	.4572	.4268
15	.3506	.4572	.4572	.3658	.4115	.4572	.442
16	.4572	.4572	.4572	.3963	.4572	.503	.4725
17	.381	.4115	.4115	.4115	.4572	.6097	.4572
18	.4572		.4572	.4572	.4725	.503	.4725
19	.6097	.5335	.5487	.5487	.6097	.6097	.4877
20	.6859	.6401	.6554	.4572	.6554	.6859	.5335
21	.5639	.5335	.4572	.4268	.6097	.5335	.4572
22	.4572	.381	.4268	.3963	.5335	.503	
23	.4268	.3353	.381	.3353	.4572	.4572	.4268
24		.381	.381		.3658	.4115	
Max	.6859	.6401	.6554	.6401	.6554	.6859	.6859
Min	.3506	.3048	.3048	.3353	.3353	.3048	.3201
Avg	.4791	.4367	.4356	.4579	.4503	.4807	.4822

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094024 / 33/11 KV BAMHANE

Feeder No / Name : 201 / MAHATMA FULE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.6804	1.6004	1.6004	1.6461	.8573
2		1.6804	1.5546	1.6309	1.6309	1.0288
3		1.6804	1.5699	1.6309	1.6461	1.0974
4		1.6975		1.6461	1.6766	1.1317
5		1.6975	1.6004	1.6918	1.7528	1.2346
6		1.9033	1.6309	1.7223	1.7528	1.3717
7		2.0062	1.6461	1.7528	1.8595	1.5089
8		1.989	1.5394	1.7375	1.7375	1.5432
9		1.6004	1.5851	1.7985	1.869	1.3717
10	2.0062					
11	2.3148					
12	2.0748					
13	2.2805					
14	2.0405					
15	2.2119					
16	1.989					
17	1.9033					
24		1.6804	1.5546	1.5546	1.768	1.166
Max	2.3148	2.0062	1.6461	1.7985	1.869	1.5432
Min	1.9033	1.6004	1.5394	1.5546	1.6309	.8573
Avg	2.1026	1.7616	1.5868	1.6766	1.7339	1.2311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094024 / 33/11 KV BAMHANE

Feeder No / Name : 202 / BAMHANE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431						
2	1.1888						
3	1.2193						
4	1.2193						
5	1.2955						
6	1.448						
7	1.4327						
8	1.4784						
9		1.6632					
10		1.4403	1.2955	1.4022	1.2346	1.4232	
11		1.4403	1.6004	1.448	1.4022	1.6289	
12		1.2689	1.448	1.4175	1.326	1.6118	1.2498
13		1.166	1.4022	1.2651	1.2803	1.3546	1.2955
14		.9088	1.2498	1.326	1.2651	1.3717	1.2955
15			1.2955	1.3413	1.2803		1.2498
16			1.3717	1.387	1.2955	1.4746	1.3413
17			1.3717	1.4175	1.326	1.406	1.4022
18							1.2803
24	1.3032						
Max	1.4784	1.6632	1.6004	1.448	1.4022	1.6289	1.4022
Min	1.1431	.9088	1.2498	1.2651	1.2346	1.3546	1.2498
Avg	1.3031	1.3146	1.3794	1.3756	1.3013	1.4673	1.3021

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094024 / 33/11 KV BAMHANE

Feeder No / Name : 204 / BAMHANE G/T

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115		.4973	.4572	.4268	.4268	.5658
2	.3963		.4973	.442	.4268	.4268	.5658
3	.4115		.5144	.442	.442	.4572	.583
4	.4572		.5144	.442	.5335	.5335	.6001
5	.4877		.5316	.4725	.6097	.6401	.6001
6	.6249		.7888	.7011	.6554	.6706	.7545
7	.5792		.6859	.5335	.5639	.5487	.6687
8	.5335		.583	.442	.4572	.4268	.5487
9	.4572	.4801	.5182	.4115	.442	.4801	.4268
10	.4268	.6001	.4572	.4115	.4268	.6001	.4268
11	.4572	.5144	.442	.381	.3963	.4287	.4268
12	.4572	.5144	.442	.4268	.4268	.5316	.4268
13	.4268	.463	.4572	.4268	.4572	.5658	.442
14	.503	.6344	.4877	.4572	.4572	.5658	
15	.4572	.5144	.4877	.4725	.4725	.5487	.4877
16	.4877		.442	.4115	.4725	.5316	.4572
17	.5144	.5316	.442	.4268	.442	.463	.4268
18	.5658	.5658	.4572	.4572	.5335	.5144	.4877
19	.6173	.6001	.5182	.503	.5792	.703	.6706
20	.6516	.8745	.6859	.5792	.6706	.8573	.7316
21	.6001	.6516	.6401	.6097	.5335		.5335
22	.5658	.6344	.5182	.4572	.4877		.5487
23	.5144	.5658	.4877	.4572	.4268		
24	.3963	.4801	.5316	.4725	.4268	.4115	.5658
Max	.6516	.8745	.7888	.7011	.6706	.8573	.7545
Min	.3963	.463	.442	.381	.3963	.4115	.4268
Avg	.5000	.5750	.5262	.4706	.4903	.5396	.5430

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094024 / 33/11 KV BAMHANE

Feeder No / Name : 205 / 11 kV HT CONSUMER FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2896		.1543	.061	.0305	.0305	.0343
2	.2743		.1543	.0457	.0305	.0305	.0343
3	.2743		.1715	.0457	.0305	.0305	.0343
4	.2896		.2058	.0305	.0305	.0305	.0343
5	.2743		.2229	.0305	.0305	.0305	.0343
6	.2743		.1543	.0305	.0305	.0305	.0343
7	.1829		.0343	.0305	.0305	.0305	.0343
8	.0457		.0343	.0305	.0305	.0305	.0343
9	.0305	.0514	.0305	.0305	.0305	.0343	.0305
10	.0457	.0343	.0305	.0305	.0305	.0343	.0457
11	.0457	.0343	.0305	.0305	.0305	.0343	.0457
12	.0457	.0343	.0305	.0457	.0305	.0514	.0305
13	.0457	.0686	.0457	.061	.0305	.0514	.0457
14	.0457	.0686	.0457	.0457	.0305	.0514	.0305
15	.0457	.0686	.0457	.0457	.0305	.0686	.0457
16	.0457	.0686	.061	.061	.0305	.0343	.0457
17	.1372	.0514	.061	.0457	.0457	.0343	.061
18	.1886	.0343	.0457	.0457	.0457	.0343	.0457
19	.2229		.0305	.0305	.0457	.0343	.0305
20	.2915	.0343	.0457	.0305	.0457		.0305
21	.3086	.1715	.0457	.0305	.0305		.0457
22	.3429	.1543	.0305	.0305	.0305		
23	.3601	.1715	.0305	.0305	.0305		
24	.2896	.3429	.1543	.0305	.0305	.0305	.0343
Max	.3601	.3429	.2229	.061	.0457	.0686	.061
Min	.0305	.0343	.0305	.0305	.0305	.0305	.0305
Avg	.1832	.0926	.0790	.0387	.0330	.0369	.0383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094024 / 33/11 KV BAMHANE

Feeder No / Name : 206 / 11 kV TAPI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1886	.1829	.1829	.1372	.1029
2			.1886	.1829	.1829	.1372	.1029
3			.1886	.1981	.1981	.1677	.12
4			.1886	.1829	.1829	.1677	.1372
5			.1886	.1981	.2134	.1677	.1543
6			.2572	.2286	.2134	.1677	.1886
7			.2743	.2591	.1829	.2439	.1886
8			.2743	.2286	.1829	.2134	.1886
9			.1981	.1829	.1829	.1715	.1829
10	.1829	.2572					
11	.2896	.2915					
12	.3048	.1543					
13	.2896	.2743					
14	.2286	.2229					
15	.2286	.2915					
16	.2286	.2572					
17	.2286	.2401					
24			.2058	.1829	.1829	.1372	.0343
Max	.3048	.2915	.2743	.2591	.2134	.2439	.1886
Min	.1829	.1543	.1886	.1829	.1829	.1372	.0343
Avg	.2477	.2486	.2153	.2027	.1905	.1711	.1400

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094051 / 33/11 kV Sawai Mukti

Feeder No / Name : 201 / 11KV TAMTHARE AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.9602	.945	1.2193	1.0974	1.1736
2			.9907	.9907	1.2498	1.1431	1.2651
3			1.0669	1.0822	1.3413	1.2346	1.3413
4			1.1584	1.1736	1.4632	1.2955	1.387
5			1.2193	1.4632	1.4937	1.3565	1.3717
6			1.3565	1.4784	1.6156	1.3717	1.4175
7			1.5089	1.5394	1.5851	1.5242	1.5546
8			1.4327	1.5699	1.4937	1.4784	1.6766
9				1.387	1.4022		1.4784
10	1.6309	1.326	1.3717				
11	1.9204	1.7528					
12	1.6918	1.6461					
13	1.5699	1.4022					
14	1.5242	1.3108					
15	1.4937	1.387					
16	1.4632	1.5242					
17	1.4175	1.4022					
24			.823	.8383	1.1126	1.0059	.9602
Max	1.9204	1.7528	1.5089	1.5699	1.6156	1.5242	1.6766
Min	1.4175	1.3108	.823	.8383	1.1126	1.0059	.9602
Avg	1.5890	1.4689	1.1888	1.2468	1.3977	1.2786	1.3626

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094051 / 33/11 kV Sawai Mukti

Feeder No / Name : 202 / 11KV SAWAI MUKTI AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3353	.3353	.3353	.3048	.3201
2			.3353	.3353	.3963	.3353	.3048
3			.3658	.3658	.4268	.3658	.3353
4			.381	.3658	.442	.4115	.4115
5			.4268	.4572	.4725	.442	.4268
6			.4725	.503	.503	.442	.4725
7			.5182	.4877	.6554	.5335	.5487
8			.5182	.503	.5792	.503	.5944
9				.5335	.4725	.4268	.5182
10	.4725		.4268				
11	.5944	.5335					
12	.5487	.6097					
13	.5792	.4877					
14	.5487	.4572					
15	.5639	.4725					
16	.5792	.4725					
17	.5182	.5182					
24			.3201	.3048	.3048	.2896	.2743
Max	.5944	.6097	.5182	.5335	.6554	.5335	.5944
Min	.4725	.4572	.3201	.3048	.3048	.2896	.2743
Avg	.5506	.5073	.41	.4191	.4588	.4054	.4207

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094051 / 33/11 kV Sawai Mukti

Feeder No / Name : 203 / 11 KV SAWAI MUKTI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0762	.0762	.0762	.0762	
2	.0762	.0762	.0762	.0762	.0762	.0762	
3	.0762	.0762	.0762	.0762	.0762	.0762	
4	.0914	.0762	.0762	.0914	.0762	.0914	
5	.1067	.0914	.0914	.1067	.1067	.1372	
6	.1372	.1219	.1067	.1372	.1677	.1677	
7	.1524	.1067	.1524	.1067	.1067	.1067	
8	.1219	.0914	.1067	.1067	.1067	.1067	.1219
9	.0914	.1067	.1067	.1067	.1067	.1219	.1067
10	.0914	.1067	.0762	.0914	.0914	.0762	.0914
11	.0914	.0914	.0914	.0762	.0914	.0762	.0914
12	.0914	.1067	.0914	.0914	.0914	.0762	.0914
13	.0914	.1067	.0914	.0914	.1067	.0762	.0914
14	.0914	.1067	.1067	.0914	.1067	.0914	.0914
15	.0914	.0914	.1067	.0914	.1067	.0914	.0914
16	.1067	.1067	.1067	.0914	.1067	.1067	.0914
17	.0914	.1067	.0914	.0914	.1067	.1067	.1067
18	.1067		.1067	.0914	.0914	.1219	.1219
19	.1372	.1524	.1219	.1677	.1067	.1219	.1524
20	.1677	.1524	.1524	.1829	.1524	.1372	.1372
21	.1372	.1372	.1067	.1372	.1372	.1829	.1219
22	.1067	.1067	.0914	.0914	.0914	.1219	
23	.0762	.0914	.0762	.0762	.0762		.0914
24	.0762	.0762	.0762	.0762	.0762	.0762	
Max	.1677	.1524	.1524	.1829	.1677	.1829	.1524
Min	.0762	.0762	.0762	.0762	.0762	.0762	.0914
Avg	.1035	.1027	.0984	.1010	.1016	.1054	.1067

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094051 / 33/11 kV Sawai Mukti

Feeder No / Name : 204 / 11KV ROHANE AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.503					
2	.4115	.5182					
3	.442	.5335					
4	.442	.5487					
5	.4725	.5487					
6	.5182	.5792					
7	.6097	.6554					
8	.5639	.6859					
9	.5487	.6097					
10			.5792	.4725	.4725	.503	.6097
11			.6401	.5182	.4877	.5182	.6859
12			.6706	.442	.4268	.5639	.5335
13			.5335	.4268	.4725	.5487	.5487
14			.5182	.4572	.4115	.503	.5792
15			.4877	.4877	.4725	.5487	.5487
16			.5792	.503	.5487	.4725	.5639
17			.5944	.5335	.6097	.4268	.5792
24	.3506					.0572	
Max	.6097	.6859	.6706	.5335	.6097	.5639	.6859
Min	.3506	.503	.4877	.4268	.4115	.0572	.5335
Avg	.4740	.5758	.5754	.4801	.4877	.4602	.5811

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094051 / 33/11 kV Sawai Mukti

Feeder No / Name : 205 / 11KV DANGURNE AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.5944					
2	.5792	.6097					
3	.5639	.6097					
4	.6249	.6249					
5	.7164	.6554					
6	.7926	.7164					
7	.8383	.7621					
8	.9145	.8383					
9	.884	.6401					
10			.7926	.7621	.8383	.7621	
11			.8535	.7926	.884	.7773	.5335
12			.8993	.7773	.8993	.8078	.5335
13			.7926	.7164	.8383	.8383	.5792
14			.7621	.7164	.7926	.7316	.6401
15			.7316	.6859	.7926	.7621	.7316
16			.7468	.7164	.7773	.7316	.823
17			.7164	.7926	.884	.6097	.8535
24	.6706	.6097					
Max	.9145	.8383	.8993	.7926	.8993	.8383	.8535
Min	.5639	.5944	.7164	.6859	.7773	.6097	.5335
Avg	.7194	.6661	.7869	.7450	.8383	.7526	.6706

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094071 / 33/11KV LANGHANE SUB STATION

Feeder No / Name : 201 / 11KV KUMBHARE GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1524	.1334	.12	.1372	.1524	.1715
2	.1715	.1524	.1524	.12	.1372	.1524	.1715
3	.1715	.1524	.1524	.1543	.1715	.1524	.1905
4	.1334	.1524	.1524	.1886	.2058	.1715	.1905
5	.2286	.1524	.2477	.2229	.2401	.2286	.2477
6	.3239	.1524	.3429	.2915	.2915	.3048	.3429
7	.2667	.1524	.3048	.2401	.2572	.2667	.2858
8	.2477	.1524	.2401	.2058	.2058	.2477	.2477
9	.2667	.2096	.2229	.2058	.2477	.2477	.2058
10	.2096	.2667	.1886	.1715	.2096	.2477	.1715
11	.2096	.2667	.1715	.1886		.1905	.1543
12	.1715	.2286	.1372	.1543	.1905	.1715	.1372
13	.1715	.2477	.1543	.1543	.1905	.1905	.1543
14	.1715	.2286	.1372	.1715	.1905	.1715	.1543
15	.1905	.2477	.1715	.1715	.1905	.1905	.1543
16	.1905	.2286	.1715	.1543	.1905	.2286	.1715
17	.2096	.2286	.1715	.1543	.1905	.1905	.1886
18	.2286	.2477	.1715	.1886	.2286	.2477	.2401
19	.3048	.3048	.2743	.2572	.3239	.3239	.2743
20	.2667	.3048	.2572	.2058	.3048	.3239	.2229
21	.2286	.2096	.2058	.1886	.2477		
22	.1715		.1715	.1715	.1905		
23	.1524	.1715	.1372	.1372	.1524		
24	.1715	.1524	.1524	.12	.1372	.1524	.1715
Max	.3239	.3048	.3429	.2915	.3239	.3239	.3429
Min	.1334	.1524	.1334	.12	.1372	.1524	.1372
Avg	.2096	.2071	.1926	.1808	.2101	.2168	.2023

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094071 / 33/11KV LANGHANE SUB STATION

Feeder No / Name : 202 / 11KV KALGAON AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7528	1.7909					
2	1.7337	1.7909					
3	1.7337	1.7909					
4	1.6956	1.7909					
5	1.7337	1.7909					
6	1.829	1.7909					
7	1.829	1.7909					
8	1.7718	1.7909					
9	1.6766	1.7337					
10		1.7337	2.8959	2.8959	3.5246	1.8671	2.6216
11		1.7337	2.8959	3.0788	3.7913	1.9624	2.8197
12		1.7337		3.1093	3.5246	1.9052	2.774
13		1.7337	3.0788	3.1245	3.658	1.8671	2.774
14		1.7337	3.0483	3.0788	3.6961	1.8671	2.7892
15		1.7337	3.0483	3.0483	3.6961	1.8671	2.7435
16		1.7337	3.0483	2.9874	3.7151	1.848	2.7435
17		1.7337	3.0483	2.9721	3.7342	1.8099	2.6673
18		1.7337	3.0178				
19		1.7909					
20		1.7528					
21		1.7718					
22		1.7528					
23		1.7528					
24	1.7528	1.829	1.7528				
Max	1.829	1.829	3.0788	3.1245	3.7913	1.9624	2.8197
Min	1.6766	1.7337	1.7528	2.8959	3.5246	1.8099	2.6216
Avg	1.7509	1.7631	2.8705	3.0369	3.6675	1.8742	2.7416

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094071 / 33/11KV LANGHANE SUB STATION

Feeder No / Name : 203 / 11KV VARNESHWAR AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			2.1338	1.6766	1.6766	2.0005	1.4861
2			2.1529	1.6766	1.6766	2.0195	1.5051
3			2.1529	1.6766	1.6766	2.0195	1.5051
4			2.1148	1.7071	1.7071	2.0195	1.5432
5			2.0957	1.7528	1.7071	2.0386	1.5242
6			2.1529	1.7528	1.7528	2.0576	1.5432
7				1.7985	1.7528	2.1148	1.6194
8			1.8138	1.768	1.7071	2.0576	1.6575
9			1.7528	1.7528	2.0957	1.9814	
10	2.1338	2.1719		1.7528			
11	2.3434	2.4577					
12	2.2481	2.3434					
13	2.2481	2.4387					
14	2.2481	2.4577					
15	2.2481	2.4006					
16	2.2481	2.4387					
17	2.21	2.4958					
18		2.4958					
19		2.4958					
20		2.4958					
21		2.4958					
22		2.4958					
23		2.4958					
24			2.1529	1.6766	1.6461	2.0195	1.5051
Max	2.3434	2.4958	2.1529	1.7985	2.0957	2.1148	1.6575
Min	2.1338	2.1719	1.7528	1.6766	1.6461	1.9814	1.4861
Avg	2.2410	2.4414	2.0581	1.7265	1.7399	2.0329	1.5432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094011 / 33/11KV THALNER

Feeder No / Name : 201 / 11 KV THALNER AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3353	2.8045	3.0849	3.4873	2.2862	2.649
2		.3688	2.8045	3.0849	3.4537	2.4082	2.6825
3		.3688	2.8349	3.0346	3.4873	2.6216	2.6825
4		.3856	2.8349	3.1184	3.4873	2.6825	2.8166
5		.4191	2.8959	3.1855	3.5208	2.713	2.8837
6		3.219	3.0483	3.3196	3.4537	2.774	3.0849
7		3.219	3.0483		3.4873	2.4996	2.5911
8		3.152		3.3196	3.4873	2.8654	2.8502
9		2.5911			3.2312	2.8349	3.1184
10	3.0178		3.3265				
11	3.7555						
12	3.722						
13	3.7723						
14	3.7037						
15	3.7037						
16	3.0521						
24		2.4813	2.7435	2.7161	3.0849	1.7375	2.0119
Max	3.7723	3.219	3.3265	3.3196	3.5208	2.8654	3.1184
Min	3.0178	.3353	2.7435	2.7161	3.0849	1.7375	2.0119
Avg	3.5324	1.654	2.9268	3.1080	3.4181	2.5423	2.7371

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094011 / 33/11KV THALNER

Feeder No / Name : 202 / 11 KV HOLNANTHE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0178	3.0178	.3086	.3772	.3086	.3086	
2	3.0178	3.3532	.3086	.3772	.3086	.3429	
3	3.3532	3.4202	.3258	.4115	.3086	.3772	
4	3.4537	3.4202	.3772	.4458	.3429	.4115	
5	3.4202	3.4202	.4115	.4801	.4115	.463	
6	3.4202	.4694	.4801	.5144	.4801	.5144	
7	3.6549	.4024	.4458	.4458	.4458	.4801	
8	3.5208	.4024	.3688	.4024	.4115	.4458	.3353
9	3.5208	.3429	.3688		.3429	.4115	.3353
10	.3018	.3086	3.219	3.3867	3.1703	.3772	
11	.3688	1.9204		3.5879	3.0788		3.152
12	.3086	.2743	3.0849	3.6214	3.2312		3.2526
13	.3772	.4801	3.2861	3.5879	3.3836		3.4202
14	.3772	1.9814		3.6214	3.1703		
15	.3688	2.0729		3.5208	3.2312	3.2007	
16	.3688	2.1643		3.6214	3.1398	3.3227	
17	.4359	2.7435		3.5208	3.2007	3.0788	
18	.5365	3.0178		.4115	.3429	3.2007	
19		3.0483		.4458	.3772	.4801	
20		3.1093		.4115	.4801	2.8349	
21		2.7435		.3429	.5144		
22				.3258			
23		.3429		.3086	.3429		
24	3.0178		.3086	.3018	.3086	.3772	
Max	3.6549	3.4202	3.2861	3.6214	3.3836	3.3227	3.4202
Min	.3018	.2743	.3086	.3018	.3086	.3086	.3353
Avg	1.9390	1.9298	1.0226	1.4987	1.3623	1.2134	2.0991

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094011 / 33/11KV THALNER

Feeder No / Name : 203 / 11 KV BHORKHEDA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8442	2.0119					
2	1.8442						
3	1.8778						
4	1.9784						
5	1.9784						
6	1.9951						
7	2.0119						
8	2.0119						
9	2.0119						1.9951
10	2.079		2.1434	2.0622	2.0424	1.7071	2.2801
11			2.3472	2.3472			2.2466
12			2.1628	2.3472			
13			2.364	2.3304	2.1338		2.3807
14			2.364	2.3304	2.1338		2.2634
15			2.146	2.364	2.21	2.3148	2.2131
16			2.1963	2.3807	2.1948	2.0119	2.2466
17			2.1963	2.3472	2.1643	2.2977	2.1628
18					2.2253	1.9814	
19					2.1338		
20					1.9966	1.4784	
21						1.4937	
24	1.7101						
Max	2.079	2.0119	2.364	2.3807	2.2253	2.3148	2.3807
Min	1.7101	2.0119	2.1434	2.0622	1.9966	1.4784	1.9951
Avg	1.9403	2.0119	2.24	2.3137	2.1372	1.8979	2.2236

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094011 / 33/11KV THALNER

Feeder No / Name : 204 / 11 KV THALNER GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.6173	.6001	.5868		.6516	.6516
2	.6173	.6173	.6001	.5868	.6516	.6859	.6516
3	.6173	.6859	.6173	.6371	.6859	.7202	.6859
4	.6859	.7545	.6516	.7042	.7545	.7545	.7202
5	.7545	.8745	.7202	.8573	.823	.823	.823
6	.8745	.9088	.8573	.8916	.8573	.8916	.9431
7	.7888	.7202	.7373	.7373	.7202	.8059	.7545
8	.583	.6001		.5487	.6001	.6344	.6001
9		.6173			.5144	.6859	.6859
10		.6173	.6001	.6001	.6173	.6173	3.1184
11	.583	.6001	.6173	.5144	.6173		
12	.583	.6173	.6516	.6344	.6344		
13	.583	.6001	.6516	.6173	.6687		.6859
14	.6173	.6687		.6516	.6859		.703
15	.6516	.6516		.6687	.6859	.8573	.703
16	.6344	.6516		.6859	.703	.8059	.703
17		.6687		.6859	.6859	.7545	.703
18		.7545		.7202	.6687	.7716	.7716
19	.8402	.7545		.8059	.7716	.8402	.8573
20	.9774	.8916		.823	.9431	.9088	.8059
21	.8059	.7545		.7888	.823	.8916	.7888
22		.6859		.6859	.7202	.7888	.8059
23		.6173	.6516	.6344	.6516	.6859	.7202
24	.6173	.6001	.6344		.6344	.6859	
Max	.9774	.9088	.8573	.8916	.9431	.9088	3.1184
Min	.583	.6001	.6001	.5144	.5144	.6173	.6001
Avg	.6907	.6887	.6608	.6848	.7008	.7630	.8515

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094011 / 33/11KV THALNER

Feeder No / Name : 206 / 11 Kv JAITPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0898		2.1125	2.1795	1.2955	1.2193
2		1.1401		2.1125	2.2634	1.3413	1.2803
3		1.1736		2.146	2.2634	1.3717	1.2803
4		1.2407		2.1795	2.2466	1.4632	1.3717
5		1.3077		2.2298	2.2466	1.6766	1.5546
6		2.1795		2.2466	2.2977	1.7528	1.7528
7		2.3975		2.431	2.4417	2.0119	2.079
8		2.332		2.3975	2.431	2.0119	2.1125
9					2.2253	1.9814	1.6598
10	2.079		2.3807				
11	2.7831						
12	2.9508						
13	2.8502						
14	2.8837						
15	2.9172						
16	2.8334						
23			1.4586				.9054
24					2.079	1.3565	1.1736
Max	2.9508	2.3975	2.3807	2.431	2.4417	2.0119	2.1125
Min	2.079	1.0898	1.4586	2.1125	2.079	1.2955	.9054
Avg	2.7568	1.6076	1.9197	2.2319	2.2674	1.6263	1.4899

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094018 / 33/11 KV SULE

Feeder No / Name : 201 / 11 KV SANGVI MIX

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	16-JUN-18	17-JUN-18	20-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
13	1.3717		
14	1.6004	2.2291	1.3717
15	1.7375	2.2291	1.7375
16	1.9052	2.4006	1.9052
17	1.9509	2.4006	2.0576
18	2.21	2.2291	1.448
19	2.1338	2.2291	1.7528
20	2.0576	2.0576	1.1431
21	1.9814	2.0576	.9907
22	1.9052	1.8861	.9755
23	1.8442	1.8861	.9297
24	1.448	1.7147	.9907
Max	2.21	2.4006	2.0576
Min	1.3717	1.7147	.9297
Avg	1.8455	2.1200	1.3911

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094018 / 33/11 KV SULE

Feeder No / Name : 202 / 11 KV ROHINI MIX

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	16-JUN-18	17-JUN-18
HR	Load (MW)	Load (MW)
1	2.2558	1.0288
2	2.21	1.1145
3	2.1643	1.286
4	2.21	1.3375
5	2.2862	1.3889
6	2.332	1.6289
7		1.6975
8		1.6118
9		2.2291
10		2.2977
11		2.4348
12		2.4006
13		2.3148
14	1.3717	2.2291
15	2.5149	2.3148
16	2.6368	2.4006
17	1.6004	2.4006
18		2.2291
19		2.0576
20		1.989
21	1.1431	1.9719
22	1.2955	1.9204
23	1.1736	1.8861
24	2.2862	1.7147
Max	2.6368	2.4348
Min	1.1431	1.0288
Avg	1.9629	1.9119

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094018 / 33/11 KV SULE

Feeder No / Name : 203 / 11 KV AMBE

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	16-JUN-18	17-JUN-18
HR	Load (MW)	Load (MW)
1	.9907	.8573
2	.945	.9259
3	.945	1.046
4	.9907	1.1145
5	1.1279	1.166
6	1.2193	1.2689
7		1.0974
8		1.0631
9		1.0288
10		1.0288
15	1.0364	
16	1.2651	
17	1.1736	
18	1.0517	
19	1.0669	
20	1.1888	
21	1.0517	
22	.9602	
23	.823	
24	1.0364	.823
Max	1.2651	1.2689
Min	.823	.823
Avg	1.0545	1.0382

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094018 / 33/11 KV SULE

Feeder No / Name : 204 / 11 Kv Hadakhed Checkpost
Expre Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	16-JUN-18	17-JUN-18
HR	Load (MW)	Load (MW)
1	.0686	.0686
2	.0686	.0686
3	.0686	.0686
4	.0686	.0686
5	.0686	.0686
6	.0686	.0686
7	.0686	.0686
8	.0686	.0686
9	.0514	.0514
10	.0514	.0686
11	.0514	.0686
12	.0514	.0686
13	.0514	.0686
14	.0514	.0686
15	.0686	.0686
16	.0686	.0686
17	.0686	.0514
18	.0686	.0514
19	.0686	.0514
20	.0686	.0686
21	.0686	.0686
22	.0686	.0686
23	.0686	.0686
24	.0686	.0686
Max	.0686	.0686
Min	.0514	.0514
Avg	.0643	.0657

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094029 / 33/11KV HOLNANTHE

Feeder No / Name : 201 / 11 KV AJANDE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1338				
2	2.1338				
3	1.7337				
4	1.7337				
5	1.7337				
6	1.8671				
7	2.0005				
8	2.0005				
9			2.2672		
10		1.7337	2.2672	2.0005	1.6004
11		2.0005	2.2672	2.0671	1.8671
12		2.2672	2.2672	2.1338	1.8671
13			2.4006	2.1338	1.8671
14			2.4006	2.3777	1.8671
15			2.7435	2.2291	1.8671
16			2.4006	1.8671	1.8671
17			2.4006	1.7337	1.8671
Max	2.1338	2.2672	2.7435	2.3777	1.8671
Min	1.7337	1.7337	2.2672	1.7337	1.6004
Avg	1.9171	2.0005	2.3794	2.0679	1.8338

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094029 / 33/11KV HOLNANTHE

Feeder No / Name : 202 / 11 KV GHODASGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	17-JUN-18	18-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.7337		2.0005
2			1.7337		1.8671
3			1.7337		1.8671
4			1.7337		1.7337
5			1.8671		1.8671
6			1.8671		1.8671
7			1.8671	1.7337	1.8671
8			1.8671	1.9814	1.8671
9			1.6004	1.7337	
10	1.7337	2.0005			
11		2.1338			
12	2.2672	1.8671			
13	2.2672	1.3336			
14	2.2672	1.3336			
15	2.1338	1.3336			
16	2.1338	2.1338			
17	2.1338	2.0005			
21				1.8671	
22				1.8671	
23				1.8671	
24		1.7337		2.2291	
Max	2.2672	2.1338	1.8671	2.2291	2.0005
Min	1.7337	1.3336	1.6004	1.7337	1.7337
Avg	2.1338	1.7634	1.7782	1.8970	1.8671

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094029 / 33/11KV HOLNANTHE

Feeder No / Name : 204 / 11 KV HOLNATHE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	17-JUN-18	18-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048		.3048	.3048	.6096
2	.3048		.3048	.3048	.6096
3	.3048		.3048	.3048	.6096
4	.3048		.3048	.381	.6096
5	.381		.381	.381	.6858
6	.381		.6097	.4572	.9144
7	.6097		.5335	.4572	1.2194
8	.4572		.4572	.5335	1.067
9		.3048	.4572	.5335	.5335
10		.381	.381	.8573	.4572
11		.381	.3048	.8573	.4572
12		.381	.3048	.7811	.4572
13		.381		.7811	.4572
14		.381		.8382	.4572
15		.381		.9144	.4572
16		.4572		.9144	.4572
17		.4572		.8002	.4572
18		.5335		.4668	.4572
19		.6097		.5335	.381
20		.6097		1.1432	.5335
21		.4572		1.067	.4572
22		.381		.9144	.5335
23		.3048		.762	.4572
24		.3048		.762	
Max	.6097	.6097	.6097	1.1432	1.2194
Min	.3048	.3048	.3048	.3048	.381
Avg	.3810	.4191	.3874	.6688	.5798

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094029 / 33/11KV HOLNANTHE

Feeder No / Name : 205 / 11 KV JAPORA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	17-JUN-18	18-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.0669	1.3336	1.0669
2			1.0669	1.3336	.9335
3			1.0669	1.5242	.9335
4			1.0669	1.5242	.9335
5			1.0669	1.3717	.9335
6			1.2003	1.3717	1.0669
7			1.2003	1.3717	1.0669
8			1.2003	1.2003	1.0669
9			1.0669	1.3717	1.0669
10	1.467	1.3336			
11	1.7337	1.6004			
12	1.7337	1.6004			
13	1.7337	1.3336			
14	1.8671	1.3336			
15	1.7337	1.3336			
16	1.6004	1.3336			
17		1.3336			
24		1.0669		1.0669	
Max	1.8671	1.6004	1.2003	1.5242	1.0669
Min	1.467	1.0669	1.0669	1.0669	.9335
Avg	1.6956	1.3633	1.1114	1.3470	1.0076

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094033 / 33/11KV BABHALAJ

Feeder No / Name : 201 / 11 KV BAHTPURA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3052	.2591	.2743	.2134	.1006
2			.3052	.2591	.2743	.2134	.0995
3			.3222	.2439	.2591	.2286	.1006
4			.3222	.2743	.2591	.2286	.12
5			.3391	.2743	.2743		.1187
6			.3391	.2896	.2743	.2743	.1372
7			.3561	.2743	.2896	.2591	.2515
8			.373	.2591	.2896	.2591	.285
9			.407	.3048	.3048	.2439	.3353
10	.3048	.2896					
11		.3963					
12	.3201	.381					
13	.3125	.3506					
14	.3963	.3506					
15	.3658	.381					
16	.3506	.381					
17	.3506	.3201					
24			.2883	.2591	.2743	.2134	.1006
Max	.3963	.3963	.407	.3048	.3048	.2743	.3353
Min	.3048	.2896	.2883	.2439	.2591	.2134	.0995
Avg	.3430	.3563	.3357	.2698	.2774	.2371	.1649

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094033 / 33/11KV BABHALAJ

Feeder No / Name : 202 / 11 KV BABHALAJ AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5684						
2	1.5684						
3	1.6644						
4	1.7284						
5	1.7604						
6	1.8404						
7	1.8884						
8	1.9044						
9	1.9204						
10			1.8185			1.6598	1.4752
11		1.9448	2.1872	2.1628	2.1052	1.8067	1.7804
12		2.3045	1.945	2.1956	2.17	1.873	1.933
13		2.4508	1.9766	2.1792	2.1052	1.8945	1.8023
14			1.9997	2.0576	2.0243	1.8945	1.6461
15			1.9292	2.1628	1.9109	1.7736	1.6766
16			1.8976	2.13	1.7814	1.8067	1.7465
17			1.945	2.0481	1.7166	1.6933	1.6549
24	1.6004						
Max	1.9204	2.4508	2.1872	2.1956	2.17	1.8945	1.933
Min	1.5684	1.9448	1.8185	2.0481	1.7166	1.6598	1.4752
Avg	1.7444	2.2334	1.9624	2.1337	1.9734	1.8003	1.7144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094033 / 33/11KV BABHALAJ

Feeder No / Name : 203 / 11KV BHATPURA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.1865	.1677	.1595	.2058	.1578	.1509
2	.181	.1865	.1844	.1595	.2058	.1578	.1677
3	.2172	.2035	.2012	.1772	.213	.1753	.1677
4	.2534	.2543	.2347	.2601	.2401	.2103	.218
5	.3258	.2883	.2683	.3155	.2439	.2804	.2683
6	.362	.2883	.285	.3391	.3048	.3506	.3353
7	.362	.3561	.2683	.3366	.3201	.3155	.3185
8		.2713	.2347		.3801	.2804	.3185
9		.3052	.3018	.2835	.3801	.2454	.285
10	.3155	.2035	.2481	.2715	.3258	.1677	.2743
11		.1696	.2126	.213	.2896	.1658	.2572
12	.2454	.2374	.2103	.1991	.2534	.1677	.2401
13	.1772	.2543	.2279	.1677	.2172	.1844	.2458
14	.2303	.2374	.1928	.1981	.2172	.2012	.2401
15	.2279	.2374	.2454	.2134	.2353	.1677	.2572
16	.1949	.2204	.2481	.2294	.2353	.2204	.2915
17	.2126	.2713	.2804	.2172	.2353	.2012	.3439
18	.2204	.1865	.2303	.2458	.2896		.3258
19	.2374	.2515	.3012	.3258	.362		.3601
20	.2713	.218	.333	.3077	.3258	.3258	.2572
21	.2374	.2012	.2835	.3086	.2896	.2515	.2572
22	.2204	.1844	.2481	.2543	.2534	.2401	.1966
23	.2035	.1844	.1928	.2743	.2172	.1886	.1715
24	.181	.2035	.1677	.1772	.2715	.1753	.1677
Max	.362	.3561	.333	.3391	.3801	.3506	.3601
Min	.1772	.1696	.1677	.1595	.2058	.1578	.1509
Avg	.2408	.2334	.2403	.2450	.2713	.2196	.2548

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094033 / 33/11KV BABHALAJ

Feeder No / Name : 205 / 11 KV Ajnad Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			2.2131	2.1338	2.0576		1.4752
2			2.2466	2.1491	2.0576		1.4752
3			2.2969	2.1491	2.2405		1.5083
4			2.364	2.21	2.3929		1.5424
5			2.6155	2.3167	2.5606		1.5592
6			2.8166	2.3624	2.6978		1.5927
7			2.7664	2.5911	2.713		1.8442
8			2.7328	2.4844	2.5758		1.9448
9			2.7999	2.5606	2.6063	1.2498	1.9113
10		2.6322				1.5424	
11		3.2693				1.4922	
12	2.4691	3.0681				1.4754	
13	2.8241	3.0346				1.6095	
14	2.9214	3.152				1.6244	
15	2.9058	3.1855					
16	2.9058	3.0178					
17	2.6558	2.934					
24			2.1795	1.9509	1.9814		1.4754
Max	2.9214	3.2693	2.8166	2.5911	2.713	1.6244	1.9448
Min	2.4691	2.6322	2.1795	1.9509	1.9814	1.2498	1.4752
Avg	2.7803	3.0367	2.5031	2.2908	2.3884	1.4990	1.6329

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094033 / 33/11KV BABHALAJ

Feeder No / Name : 206 / 11 KV NAGESHWAR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.503	.4268	.4572	.3963	.3688
2			.5182	.4268	.4572	.3963	.3521
3			.5182	.4268	.4572	.3963	.3856
4			.5335	.442	.4725	.4115	.4024
5			.5639	.4725	.4725	.4268	.4024
6			.5944	.4725	.4725	.442	.4191
7			.6097	.4877	.4877	.442	.5197
8			.6249	.4877	.5182	.4115	.5533
9			.6401	.5335	.5335	.4115	.7042
10	.5792	.6097					
11		.7011					
12	.7011	.8048					
13	.6706	.7377					
14	.6554	.7377					
15	.6706	.8048					
16	.6706	.788					
17	.6554	.7545					
24			.503	.4268	.4572	.4115	.3688
Max	.7011	.8048	.6401	.5335	.5335	.442	.7042
Min	.5792	.6097	.503	.4268	.4572	.3963	.3521
Avg	.6576	.7423	.5609	.4603	.4786	.4146	.4476

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094033 / 33/11KV BABHALAJ

Feeder No / Name : 207 / 11 KV TARADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8179	.9339					
2	.8179	.9339					
3	.8951	.9503					
4	.9568	.9503					
5	.9877	.9995					
6	1.0185	1.0322					
7	1.034	1.0486					
8	.9877	1.065					
9	.9722	1.1142					
10			.884	.823	.8905	.9774	.7621
11			1.0669	1.0059	.9374	.9389	.8688
12			.8078	1.0059	1.0155	.9389	.8688
13			.8535	1.0059	1.0311	.9221	.8688
14			.8688	.9907	1.0311	.9221	.8535
15			.8993	.945	.9998	.9221	.8383
16			.9145	.884	.9842	.8886	.7164
17			.8993	.8688	.9686	.8383	.7926
24	.8488	.9175					
Max	1.034	1.1142	1.0669	1.0059	1.0311	.9774	.8688
Min	.8179	.9175	.8078	.823	.8905	.8383	.7164
Avg	.9337	.9945	.8993	.9412	.9823	.9186	.8212

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094041 / 33/11KV UNTAWAD

Feeder No / Name : 201 / 11 KV UNTAWAD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		3.4484		3.7723		2.8578
2		3.4484		3.6199		2.7625
19		4.039	3.6199	3.7342	3.5056	3.2007
20		4.1152	3.8104	3.9628	3.4865	
21			3.9628	3.9057	2.9721	
22		4.1152	3.9247	3.8676	2.7625	
23	3.6199	4.1152	4.039		2.8197	
24		3.4484		3.9628		2.915
Max	3.6199	4.1152	4.039	3.9628	3.5056	3.2007
Min	3.6199	3.4484	3.6199	3.6199	2.7625	2.7625
Avg	3.6199	3.8185	3.8714	3.8322	3.1093	2.934

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094041 / 33/11KV UNTAWAD

Feeder No / Name : 202 / 11 KV KHARDE GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	16-JUN-18	17-JUN-18	18-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.4572	.4191		.4763
2	.4763	.4572	.4191		.4763
3	.4572	.4572	.4572		.4572
4	.4763		.4572		.4572
5	.4763	.4763	.4954		.4954
6	.4954	.4954	.4954		.5335
7	.4763	.4954	.4954		.4954
8	.4763	.4954	.4572		.4763
9	.4382	.4572	.4572		.4763
10	.4572	.4572	.4572	.4572	.4763
11		.4572	.4763	.4572	.4954
12	.4954	.4572	.4954	.4572	.4763
13	.4954	.4572	.5144	.4572	.5144
14	.4572	.4572	.5144	.4572	.5144
15	.4954	.4572	.4954	.4763	.4954
16	.4954	.4572	.5144	.4954	.5335
17	.4572	.4572	.5144	.4763	.5335
18	.4572	.4572	.4954	.4382	.5716
19	.4572	.4572	.4954	.4572	.5716
20	.4954	.4954	.4954	.4954	.5335
21	.4954	.4954	.5525	.5144	.4954
22	.4954	.4954	.5335	.4954	.4954
23	.4954	.4954		.4954	.4763
24	.4763	.4572	.4954		.4763
Max	.4954	.4954	.5525	.5144	.5716
Min	.4382	.4572	.4191	.4382	.4572
Avg	.4771	.4697	.4871	.4736	.5001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094041 / 33/11KV UNTAWAD

Feeder No / Name : 203 / 11KV BALDE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4954	.5716	.5335		.4954
2		.4954	.5335	.5525		
3		.5335	.5335	.5716		.5335
4		.6097	.5335	.6097		
5		.6478	.5335	.6478		.6668
6		.7049	.6668	.6668		.724
7		.6097	.724	.724		.6478
8		.5906	.6097	.6478		
9		.5525	.5525	.6097		.5716
10		.6097	.6097	.5716	.5716	.6097
11		.5906	.6097	.5335		.6097
12		.6097	.6097	.5525	.5335	.5525
13			.5716	.5716		.5525
14		.6097	.5335	.5335		.5335
15		.6097	.5335	.5906	.6097	.5716
16		.6097	.5716	.5716		.5716
17		.6097	.5716	.5906		.6097
18		.5716	.5716	.6287	.6478	.5716
19		.6097	.6097	.6668	.6668	.5716
20		.6097	.6478		.6859	.5716
21		.724	.6668	.7049		.5335
22			.724	.6478	.6478	.5335
23	.5335	.5716	.6478		.6097	.5144
24		.5335	.5716	.6097		.5906
Max	.5335	.724	.724	.724	.6859	.724
Min	.5335	.4954	.5335	.5335	.5335	.4954
Avg	.5335	.5958	.5962	.6062	.6216	.5779

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094041 / 33/11KV UNTAWAD

Feeder No / Name : 205 / 11 KV SAKWAD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3		1.6194	1.9052	1.9052		1.7147
4		1.6194	2.0957	1.9052		1.7528
5		1.7147	2.0957	2.2862		1.7909
6		2.0767	2.0957	2.3434		1.8671
7		2.0767	2.2862	2.4387		2.0195
8		2.2291	2.3053	2.4577		2.0576
9		2.2862	2.3434	2.4577		2.0386
10		2.0957	2.4196	2.3624	2.1719	2.0005
23	2.2481					
Max	2.2481	2.2862	2.4196	2.4577	2.1719	2.0576
Min	2.2481	1.6194	1.9052	1.9052	2.1719	1.7147
Avg	2.2481	1.9647	2.1934	2.2696	2.1719	1.9052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094041 / 33/11KV UNTAWAD

Feeder No / Name : 206 / 11 Kv Jatoda Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11		2.21	2.3434	2.2481	2.191	2.1529
12		2.0957		2.2481	2.1338	2.191
13		2.0957	2.3434	2.2672	2.191	2.2481
14		2.0957	2.3243	2.3243	2.21	2.2672
15		2.0957	2.2481	2.2291	2.2291	2.21
16		1.9052	2.2481	2.3053	1.6766	2.191
17		1.9814	2.2862	2.2481		2.1338
18			2.2862	2.1719	1.9052	2.0957
23	1.6766					
Max	1.6766	2.21	2.3434	2.3243	2.2291	2.2672
Min	1.6766	1.9052	2.2481	2.1719	1.6766	2.0957
Avg	1.6766	2.0685	2.2971	2.2553	2.0767	2.1862

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094053 / 33/11 KV PANAKHED

Feeder No / Name : 201 / 11 KV PALASNER MIX

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288			.6859	.7202	.7888	.4801
2	1.0631		1.0288	.7545	.823	.7716	.4801
3	1.0288		.9259	.7888	.8573		.5144
4			.8745	.8916	.9259	.8573	.6173
5			.9259	1.2003	.9602	.8573	.5658
6			1.0288	1.4403	1.0288	.8916	.6001
7			1.1317	1.5775	1.286	1.1317	.6687
8				1.6804	1.3717	.9431	.6173
9			1.166	1.5432	1.2003	1.1145	
10			1.0631	1.286	.9602		
14	1.3375	1.4403					
15	1.4746	1.4918					
16	1.4403	1.5432					
17	1.4575	1.5432					
18	1.4403	1.4403					
19	1.4403	1.3889					
20	1.4575	1.4575					
21	1.3032	1.286					
22	1.2689	1.2346					
23	1.1831	1.1831					
24	1.0631	1.0802	1.286	.583	.6859		.5144
Max	1.4746	1.5432	1.286	1.6804	1.3717	1.1317	.6687
Min	1.0288	1.0802	.8745	.583	.6859	.7716	.4801
Avg	1.2848	1.3717	1.0479	1.1301	.9836	.9195	.5620

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094053 / 33/11 KV PANAKHED

Feeder No / Name : 202 / 11KV KHAIRKHUTI MIX

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9602	.9945	1.4403			.9945	.6687
2	1.0288	1.0974	1.286			.9945	.7202
3	1.166	1.5432	1.1317			1.0288	
4	1.5089	1.6804	1.0802			1.2003	
5	1.5432	1.989	1.1317				
6	1.6461	2.2291					
7	1.8347	2.3491					
8	1.989	4.3896					
9	1.6461	2.3663					
10	1.6289	1.8861					
14			1.749	1.5089		1.6461	
15			1.9547	1.5432		1.8519	
16			2.0233			1.749	
17			1.9547	1.9547			
18			1.9719	2.0576	1.6804		
19			1.8861	2.0576	1.749	.7716	
20		1.2174	1.8519	1.7147	1.3717	.7202	
21		1.6461	1.7833	1.4746	1.406	.823	
22		1.5432	1.5775			.7716	
23		1.3889	1.4746		1.046	.7202	
24	.9945	.8916	1.286	1.3717	1.1317	1.0288	.7202
Max	1.989	4.3896	2.0233	2.0576	1.749	1.8519	.7202
Min	.9602	.8916	1.0802	1.3717	1.046	.7202	.6687
Avg	1.4497	1.8141	1.5989	1.7104	1.3975	1.1000	.7030

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094061 / 33/11 KV Aade S/St

Feeder No / Name : 201 / 11 kv Aadhe Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.2915		.2743
2	.2915		.2743
3	.3086		.2743
4	.3429		.2743
5	.3601		.3086
6	.3772		.3772
7	.3601		.3772
8	.3086		.3429
9	.3429		.3772
10	.3086		.3258
11	.3429		.3429
12	.3429		.3772
13	.3086		.3086
14	.3086		.3086
15	.3258		.3258
16	.3429		.3429
17	.3429		.3601
18			.3429
19	.2915		.2572
20	.463		.2915
21	.4287		.3086
22	.3601		.3429
23	.2915		.3429
24	.2743	.3258	.2915
Max	.463	.3258	.3772
Min	.2743	.3258	.2572
Avg	.3355	.3258	.3229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094061 / 33/11 KV Aade S/St

Feeder No / Name : 202 / 11 kv Tajpuri AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6118	1.5947	1.5432	1.2003	1.2346
2	1.6632	1.6289	1.6289	1.2003	1.2346
3	1.6975	1.6289	1.6289	1.2003	1.2689
4	1.7318	1.6289	1.749	1.3203	1.3032
5	1.8004	1.6289	1.8519	1.3203	1.3717
6	1.869	1.6461	1.9033	1.3546	1.5604
7	1.9719	1.8347	2.0062	1.4575	1.6804
8	1.9719	1.9204	1.8861	1.5432	1.7833
9	2.0062		1.8519		1.6975
24	1.5432		1.5261	1.3717	1.2003
Max	2.0062	1.9204	2.0062	1.5432	1.7833
Min	1.5432	1.5947	1.5261	1.2003	1.2003
Avg	1.7867	1.6889	1.7576	1.3298	1.4335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094061 / 33/11 KV Aade S/St

Feeder No / Name : 203 / 11 kv Aadhe AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	2.2291	2.1262	2.1091	2.0576	1.8347
11	2.6235	2.5377	2.4348		2.3834
12	2.6063	2.6578	2.572		2.452
13	2.6063	2.6235	2.4863		2.4006
14	2.572	2.5892	2.4863		2.4177
15	2.5377	2.572	2.4348		2.3491
16	2.572	2.2462	2.4348	2.4006	2.3663
17	2.6063	2.3148	2.4177	2.1434	2.2805
18				2.2977	
19				2.1776	
20				2.1262	
Max	2.6235	2.6578	2.572	2.4006	2.452
Min	2.2291	2.1262	2.1091	2.0576	1.8347
Avg	2.5442	2.4584	2.4220	2.2005	2.3105

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094067 / 33/11 KV KARWAND

Feeder No / Name : 201 / 11 KV HINGONIPADA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.3658	.4024	.4024	.4024	.3429	.3841
2	.3292	.3658	.3227	.3658	.3658	.3429	.3841
3	.439	.4024	.3521	.3658	.3658	.381	.4024
4	.5121	.439	.3961	.4024	.4024	.4191	.439
5	.567	.4755	.5121	.439	.439	.4954	.4938
6	.6401	.5487	.567	.4024	.4755	.5716	.567
7	.5487	.6401	.6584	.4572	.4572	.5906	.5304
8	.5304		.5853	.439	.4024	.4763	.4207
9	.439	.6036	.5853	.4207	.4207	.4954	.439
10	.4572	.4755	.5487	.3658	.4382	.4024	.439
11	.4938	.4024	.5121	.3292	.4191	.3841	.4207
12	.5121	.5487	.5121	.3841	.4191	.4024	.4207
13	.4755	.567	.5487	.3658	.4191	.4024	.4024
14	.5121	.5487	.5121	.4024	.4572	.439	.4207
15	.4938	.567	.4572	.3292	.4572	.439	.5121
16	.567	.5487	.4024	.4024	.4572	.4572	.4938
17	.567	.6219	.4024	.439	.4572	.439	.4938
18	.5121	.4938	.4938	.4938	.4954	.4938	.567
19	.5487	.6219	.5487	.5853	.5716	.5487	.5487
20	.5304	.567	.5121	.6036	.5716	.5487	.4572
21	.4572	.5487	.5121	.5487	.5716	.6036	.4024
22	.439	.4938	.4938	.4938	.5335	.4938	.3658
23	.5304	.439	.4572	.4572	.4382	.439	.3292
24	.3292	.4024	.4207	.4024	.4024	.4191	.4024
Max	.6401	.6401	.6584	.6036	.5716	.6036	.567
Min	.3292	.3658	.3227	.3292	.3658	.3429	.3292
Avg	.4900	.5081	.4881	.4291	.4517	.4595	.4474

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094067 / 33/11 KV KARWAND

Feeder No / Name : 202 / 11 KV SHIRPUR BDK AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2631						
2	1.2631						
3	1.2631						
4	1.3077						
5	1.3077						
6	1.4563						
7	1.4712						
8	1.6049						
9	1.4266						
10		1.2763	1.4523	1.5404	1.8099	1.3496	.743
11		1.423	1.5257	1.5697	2.0195	1.467	.8619
12		1.555	1.5697	1.5844	1.9624	1.467	1.1145
13		1.5697	1.599	1.555	1.9624		1.3375
14		1.5404	1.555	1.5697	1.9624	1.4963	1.4563
15		1.511	1.5697	1.5404	2.0005	1.4817	1.4712
16		1.467	1.5844	1.5697	1.9624	1.423	1.4861
17		1.291	1.599	1.5697	1.9624	1.4817	1.382
24	1.1888						
Max	1.6049	1.5697	1.599	1.5844	2.0195	1.4963	1.4861
Min	1.1888	1.2763	1.4523	1.5404	1.8099	1.3496	.743
Avg	1.3553	1.4542	1.5569	1.5624	1.9552	1.4523	1.2316

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094067 / 33/11 KV KARWAND

Feeder No / Name : 203 / 11 KV NATWADE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8802	.743	.743	.8278	1.2384	.7335
2		.9536	.7628	.8002		1.2384	.7628
3		.9976	.7922	.8573	.9332	1.2384	.8069
4		1.0269	.8362	.9288	1.0084	1.2955	.8069
5		1.0562	.8655	1.0288	1.174	1.4289	.8215
6		1.1003	.8802	1.2574	1.2342	1.4289	.9682
7		1.1296	1.1443	1.1145	1.2041	1.4861	1.0562
8		1.1149	1.1589	1.1431	1.2793	1.4861	1.0709
9		.7335	1.0709	1.1431	1.189	1.448	1.0416
10	1.0562						
11	1.291						
12	1.0562						
13	1.0562						
14	.9682						
15	1.2616						
16	1.247						
17	1.2029						
24		.7922	.7042	.6716	.7827	.9526	.7188
Max	1.291	1.1296	1.1589	1.2574	1.2793	1.4861	1.0709
Min	.9682	.7335	.7042	.6716	.7827	.9526	.7188
Avg	1.1424	.9785	.8958	.9688	1.0703	1.3241	.8787

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094068 / 33/11 KV BHATPURA

Feeder No / Name : 201 / 11 Kv Nagalwadi Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.8298	1.4232	1.4548	.8583	.7748
2			1.9978	1.5023	1.4842	.8583	
3			1.9978	1.5813	1.5655	.8421	.7907
4			2.0538	1.6129	1.6604	.8583	.9488
5			2.0165	1.692	1.692	.8907	1.012
6			2.0725	1.7236	1.692	.9393	1.012
7			2.0911	1.7711	1.8027	.9878	1.2176
8			1.7966	1.8343	1.906	1.085	1.2967
9			1.7029		1.9372	1.0814	1.2809
10	1.692	1.8818					
11	2.0715	2.1403					
12	1.9608	1.9997					
13	2.1506						
14	2.1032	2.1559					
15	2.1664	2.1559					
16	2.1032	2.1403					
17	2.0399	1.9997					
18		1.8278					
24			1.587	1.4074	1.406	.7811	.759
Max	2.1664	2.1559	2.0911	1.8343	1.9372	1.085	1.2967
Min	1.692	1.8278	1.587	1.4074	1.406	.7811	.759
Avg	2.0360	2.0377	1.9146	1.6165	1.6601	.9182	1.0103

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094068 / 33/11 KV BHATPURA

Feeder No / Name : 202 / 11 KV BHATPURA CHAUFULI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1717	1.186					
2	1.2186	1.186					
3	1.2334	1.2334					
4	1.2342	1.2651					
5	1.2498	1.3283					
6	1.3279	1.3757					
7	1.3904	1.4899					
8	1.439	1.5223					
9	1.4217	1.4737					
10			1.1174	1.1702	1.3443	1.1961	.9646
11			1.3279	1.4373	1.5546		1.2176
12			1.3441	1.4529	1.6032		1.2176
13			1.3441	1.4373	1.5223		1.2334
14			1.4899	1.4217	1.4243		1.2334
15			1.3441	1.4217	1.5061	1.2811	.0446
16			1.3765	1.4373	1.5384	1.3748	1.2492
17			1.3765	1.4217	1.5223	1.4217	1.2651
18						.9998	
19						.9374	
20						.8905	
21						.8592	
24	1.1561	1.1385					
Max	1.439	1.5223	1.4899	1.4529	1.6032	1.4217	1.2651
Min	1.1561	1.1385	1.1174	1.1702	1.3443	.8592	.0446
Avg	1.2843	1.3199	1.3401	1.4000	1.5019	1.1201	1.0532

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094068 / 33/11 KV BHATPURA

Feeder No / Name : 203 / 11 KV AJNAD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.2987	.2801	.2987	.2987	.2915	.2987
2	.2801	.2801	.2987	.3174	.3174	.2743	.2987
3	.2801	.2987	.3174	.3174	.3361	.2915	.3174
4	.2614	.3547	.3174	.3361	.3547	.2915	.3547
5	.3361	.3921	.3734	.3734	.3921	.3086	.4108
6	.3734	.4668	.3734	.3921	.4481	.3429	.4294
7	.3921	.3772	.3921	.3547	.3429	.3772	.2987
8	.3361	.3086	.2915	.2987	.3258	.3258	.2614
9	.3547	.3086	.2915		.3086	.2743	
10	.3174	.3258	.2743	.2801	.2915	.2572	.3734
11	.2801	.2915	.2743	.2987	.2572		.3361
12	.2987	.2572	.2743	.2987	.2572		.3174
13	.2801	.2743	.2915	.3174	.2401		.3361
14	.3174	.2915	.2915	.2987	.2743		.3361
15	.3361	.2915	.3086	.3174	.2915	.3361	.3547
16	.3174	.3086	.3086	.3174	.3258	.3921	.3547
17	.3547	.3429	.3429	.3547	.3086	.3361	.3734
18		.3429	.3429	.3921	.3601	.2614	.4108
19	.4481	.3361	.3921	.4294	.3944	.3547	.3921
20	.4108	.3361	.3921	.3547	.3601	.4854	.3734
21	.3547	.3734	.3734	.3174	.3429	.3921	.3547
22	.3174	.3547	.3361		.2915	.3547	.3361
23	.3174	.3174	.3361	.2987	.2743	.3174	.3361
24	.2987	.2987	.2801	.2987	.2987	.2915	.3174
Max	.4481	.4668	.3921	.4294	.4481	.4854	.4294
Min	.2614	.2572	.2743	.2801	.2401	.2572	.2614
Avg	.3280	.3262	.3231	.3301	.3205	.3278	.3466

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094073 / 33/11 KV BALADE

Feeder No / Name : 201 / 11 KV BORGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.1472	2.2405	1.7177	1.0595	.9288	.7802
2		2.1845	2.4272	1.7177	1.1142	.9145	.7796
3		2.2405	2.4272	1.7551	1.1361	.9002	.7914
4		2.3525	2.6139	1.7924	1.0898	.945	.8545
5		2.4646	2.7633	1.8671	1.2094	1.2574	.8269
6		2.5579	2.7633	1.9044	1.2127	1.1233	.8269
7		2.6139	2.838	1.9044	1.2489	1.2574	.8916
8		2.6699	2.95		1.1999	1.0978	.904
9		2.5766	2.7446	1.2955	1.1401	1.1523	.8916
10	1.9951	2.5766		1.1744			
11	2.372						
12	2.5434						
13	2.8959						
14	2.8829						
15	2.8829						
16	2.7801						
17	2.4539						
24		1.9231	2.2405	1.6804	1.0279	.7554	.7442
Max	2.8959	2.6699	2.95	1.9044	1.2489	1.2574	.904
Min	1.9951	1.9231	2.2405	1.1744	1.0279	.7554	.7442
Avg	2.6008	2.3916	2.6009	1.6809	1.1439	1.0332	.8291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094073 / 33/11 KV BALADE

Feeder No / Name : 202 / 11 KV WANAVAL AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4646						
2	2.4646						
3	2.5393						
4	2.5953						
5	2.6513						
6	2.726						
7	2.5766						
8	2.4832						
9	1.6972						
10		2.8006	2.4646	1.7179	1.8138	1.8427	2.0538
11		2.894	2.782	2.0245	2.348	2.2291	2.4646
12		3.006	2.7633	2.4215	2.3331	2.002	2.4272
13		2.9874	2.838	2.4059	2.4691	2.1005	2.4646
14		2.9874	2.9127	2.3765	2.4691	2.2142	2.4646
15		2.894	2.8753	2.5101	2.3624	2.1574	2.2592
16		2.8006	2.8193	2.4486	2.2737	2.1399	2.2592
17		2.8006	2.894	2.1576	2.1719	2.0306	2.2779
19	1.7749						
24	2.4272						
Max	2.726	3.006	2.9127	2.5101	2.4691	2.2291	2.4646
Min	1.6972	2.8006	2.4646	1.7179	1.8138	1.8427	2.0538
Avg	2.4000	2.8963	2.7937	2.2578	2.2801	2.0896	2.3339

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094073 / 33/11 KV BALADE

Feeder No / Name : 203 / 11 KV GIDHADE GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.4108	.4108	.3361	.2601	.2599	.2724
2	.3734	.4294	.4668	.3361	.2441	.2926	.2724
3	.4108	.4854	.4668	.3734	.2477	.2953	.3109
4	.4854	.5601	.6535	.4481	.3292	.3715	.3498
5	.6161	.6722	.7095	.5601	.3829	.4664	.4275
6	.5041	.6908	.6908	.4854	.4733	.421	.4793
7	.5228	.6535	.6535	.4854	.4085	.4534	.4146
8	.5041	.6161	.6348	.2848	.4146	.4534	.3772
9	.3467	.6161	.6161	.3395	.421	.4464	.3812
10	.4464	.6161	.5415	.4146	.4275	.4075	.4854
11	.4075	.5975	.3921	.4016	.4146	.3963	.3361
12	.3887	.5788	.3734	.3487	.3902	.4146	.3734
13	.3591	.6161	.4108	.4085	.415	.4146	.4481
14	.4134	.5975	.4481	.3963	.4601	.3839	.4481
15	.3923	.5975	.4294	.4734	.4734	.447	.4481
16	.3757	.5601	.4854	.4668	.4464	.4534	.4481
17	.3368	.5228	.4854	.4938	.378	.3829	.4668
18		.5601	.4668	.5213	.4085	.4405	.5601
19		.5601		.535	.3963	.5075	.5601
20		.5415	.6161	.5716	.3887	.5573	.4481
21		.4481	.5228	.4734	.3048	.487	.4108
22		.4294	.4294	.4146	.2926	.4146	.3921
23		.4108	.3547	.3239	.2972	.3344	.3921
24	.3734	.4108	.4108	.3361	.2848	.2599	.2972
Max	.6161	.6908	.7095	.5716	.4734	.5573	.5601
Min	.3368	.4108	.3547	.2848	.2441	.2599	.2724
Avg	.4239	.5492	.5074	.4262	.3733	.4067	.4083

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 097006 / 132 KV DAHIWAD

Feeder No / Name : 201 / 11 KV WAGHADI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	15-JUN-18	18-JUN-18	19-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
9	.8745		
10	1.1831	1.989	1.8861
11	1.166	2.2634	
12	2.1091	2.3834	2.4348
13		2.0576	
14		2.2119	
15		2.2119	
16		2.2805	
17		2.2634	
Max	2.1091	2.3834	2.4348
Min	.8745	1.989	1.8861
Avg	1.3332	2.2076	2.1605

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 097006 / 132 KV DAHIWAD

Feeder No / Name : 202 / 11 KV ASALI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	18-JUN-18
HR	Load (MW)
1	.8573
2	.9431
3	1.0288
4	1.0288
5	1.0288
6	1.1145
7	1.4575
8	1.3717
24	.9431
Max	1.4575
Min	.8573
Avg	1.0860

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 097006 / 132 KV DAHIWAD

Feeder No / Name : 203 / 11 KV DAHIWAD AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	15-JUN-18	18-JUN-18
HR	Load (MW)	Load (MW)
1	2.1434	
2	2.2291	
3	2.2291	
4	2.3148	
5	2.2291	
6	2.3148	
7	2.6578	
8	2.8292	
9	2.7435	
10		2.4863
11		2.4863
12		2.4006
13		2.4006
14		2.4006
15		2.3148
16		2.6578
17		2.7435
24	2.1434	
Max	2.8292	2.7435
Min	2.1434	2.3148
Avg	2.3834	2.4863

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 097006 / 132 KV DAHIWAD

Feeder No / Name : 205 / 11 KV PADMAVATI IND
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18	18-JUN-18	19-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1715
2	.1715	.1715	.1715
3	.1715	.1715	.1715
4	.1715	.1715	.1715
5	.1715	.1715	.1715
6	.1715	.1715	.1715
7	.1715	.1715	.1715
8	.1715	.1715	.1715
9	.1715	.1715	.1715
10	.1715	.1715	.1715
11	.1715	.1715	.1715
12	.1715	.1715	.1715
13	.1715	.1715	.1715
14	.1715	.1715	.1715
15	.1715	.1715	.1715
16	.1715	.1715	.1715
17	.1715	.1715	.1715
18	.1715	.1715	.1715
19	.1715	.1715	.1715
20	.1715	.1715	
21	.1715	.1715	.1715
22	.1715	.1715	.1715
23	.1715	.1715	.1715
24	.1715	.1715	.1715
Max	.1715	.1715	.1715
Min	.1715	.1715	.1715
Avg	.1715	.1715	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 097006 / 132 KV DAHIWAD

Feeder No / Name : 206 / 11 KV Shirpur Town

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	18-JUN-18	19-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.5144	.4973	.5144
2	.5144	.3429	.5144
3		.463	.5144
4	.4973	.4973	.4973
5	.4973	.583	.5144
6	.5487	.6001	.6344
7	.5658	.6001	.6173
8	.5316	.4973	.6001
9	.3258	.5316	.6001
10	.5316	.5316	.5144
11	.5316	.463	.5144
12	.4801	.4973	.5487
13	.463	.463	.5144
14	.463	.4973	.4973
15	.463	.4973	.4973
16	.4801	.5144	.5487
17	.4801	.5487	.6173
18	.5144	.5487	.5658
19	.5316	.6516	.5144
20	.5144	.6173	.3429
21	.5316	.6001	.5487
22	.5144	.6001	
23	.5144	.5487	.5144
24	.5144	.4801	
Max	.5658	.6516	.6344
Min	.3258	.3429	.3429
Avg	.501	.5280	.5339

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 097006 / 132 KV DAHIWAD

Feeder No / Name : 207 / 11 KV Garg

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	18-JUN-18	19-JUN-18
HR	Load (MW)	Load (MW)
1	.1715	.1715
2	.1715	.1715
3	.1715	.1715
4	.1715	.1715
5	.1715	.1715
6	.1715	.1715
7	.1715	.1715
8	.1715	.1715
9	.1715	.1715
10	.1715	.1715
11		.1715
12		.1715
13		.1715
14	.1715	.1715
15	.1715	.1715
16	.1715	.1715
17	.1715	.1715
18	.1715	.1715
19	.1715	.1715
20	.1715	.1715
21	.1715	.1715
22	.1715	.1715
23	.1715	.1715
24	.1715	.1715
Max	.1715	.1715
Min	.1715	.1715
Avg	.1715	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 097006 / 132 KV DAHIWAD

Feeder No / Name : 208 / 11KV KARWAND/DAHIWAD

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 /
OUTGOING

DATE	15-JUN-18	18-JUN-18	19-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2572	.2572
2	.2572	.2572	.2572
3	.2572	.2572	.2572
4	.2572	.2572	.2572
5	.2572	.2572	.2572
6	.2572	.2572	.2572
7	.2572	.2572	.2572
8	.2572	.2572	.2572
9	.2572	.2572	.2572
10	.2572	.2572	.2572
11	.2572	.2572	.2572
12	.2572	.2572	.2572
13	.2572	.2572	.2572
14	.2572	.2572	.2572
15	.2572	.2572	.2572
16	.2572	.2572	.2572
17	.2572	.2572	.2572
18	.2572	.2572	.2572
19	.2572	.2572	.2572
20	.2572	.2572	.2572
21	.2572	.2572	.2572
22	.2572	.2572	.2572
23	.2572	.2572	.2572
24	.2572	.2572	.2572
Max	.2572	.2572	.2572
Min	.2572	.2572	.2572
Avg	.2572	.2572	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 097006 / 132 KV DAHIWAD

Feeder No / Name : 402 / 33 KV SHIRPUR GOLD
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18	18-JUN-18	19-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
1	1.4918	1.5947	1.5432
2	1.5432	1.5432	1.4918
3	1.5432	1.6461	1.5432
4	1.5432	1.5432	1.4403
5	1.4918	1.6461	1.4403
6	1.5947	1.5432	1.5432
7	1.5947		1.5432
8	1.5947	1.5432	1.4403
9	1.4918	1.6461	1.5947
10	1.5947	1.5947	1.5947
11	1.6975	1.6975	1.5432
12	1.749	1.5947	1.5947
13	1.6975	1.5947	1.5947
14	1.5947	1.6461	1.5947
15		1.5432	1.5947
16	1.6461	1.6461	1.5947
17	1.6975	1.5432	1.5432
18	1.6461	1.5432	1.5432
19	1.6975	1.5947	1.749
20	1.6975	1.5432	1.5432
21	1.5432	1.5947	1.5432
22	1.5947	1.5947	1.5947
23	1.6461	1.5432	1.6461
24		1.5432	1.5432
Max	1.749	1.6975	1.749
Min	1.4918	1.5432	1.4403
Avg	1.6087	1.5880	1.5582

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 097006 / 132 KV DAHIWAD

Feeder No / Name : 405 / 33 KV HOLNANTHA

Feeder KV- 33 / INCOMING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(NON CONTINOUS PROCESS)(NO

STAGGERING)

DATE	15-JUN-18	18-JUN-18	19-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
1	9.6194	11.1111	11.9342
2	9.6194	10.9054	11.7284
3		11.1626	11.7284
4	9.6708	11.677	11.9856
5	10.1338	13.8889	12.2943
6	11.6255	13.2716	15.3807
7	11.9856	13.4774	14.5576
8	11.2654	13.0659	13.6831
9	7.9733	7.9733	14.3004
10	10.2881	11.3683	8.179
11	7.9733	11.677	11.8313
12	10.0823	11.7284	12.1914
13		11.4198	
14		11.4198	
15		11.9342	
16		12.1914	
17		5.2469	
18		3.1893	
19		2.6749	
20		2.3148	
21		2.0576	
22		8.8992	
23		8.8992	
24	9.7222	11.214	11.9342
Max	11.9856	13.8889	15.3807
Min	7.9733	2.0576	8.179
Avg	9.9966	9.6987	12.4407

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 097006 / 132 KV DAHIWAD

Feeder No / Name : 406 / 33 KV SOOTGIRNI

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18	18-JUN-18	19-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
1	5.9156	5.6584	6.4815
2	6.3272	6.3786	7.0473
3	2.0062	6.2757	6.893
4	6.0185	6.3272	6.2243
5	6.2243	6.7387	6.4815
6	5.7613	6.4815	5.7099
7	6.2757	6.5844	6.07
8	6.2243	5.7099	7.0988
9	5.9156	5.9671	5.4527
10	6.2757	6.2757	5.1955
11	6.2757	6.2243	5.607
12	6.4301	6.2243	5.7099
13		6.1728	
14		6.07	
15		5.6584	
16		6.2243	
17		6.3272	
18		6.6358	
19		6.07	
20		6.6873	
21		6.7387	
22		7.0473	
23		6.07	
24	5.9156	5.9156	6.4815
Max	6.4301	7.0473	7.0988
Min	2.0062	5.6584	5.1955
Avg	5.8128	6.2693	6.1887

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 097006 / 132 KV DAHIWAD

Feeder No / Name : 407 / 33 KV DYING & KNITTING

EXPRESS Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	15-JUN-18	18-JUN-18	19-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
1	8.7963	9.2593	9.6708
2	9.3622	9.6708	10.2366
3	9.1564	9.6194	9.8766
4	9.0021	9.5679	5.607
5	9.4136	9.5679	9.6194
6	9.465	9.928	10.391
7	9.465	9.6194	10.391
8	9.465	9.2593	9.8766
9	9.6194	9.0535	9.4136
10	9.4136	9.465	9.2078
11	9.8766	9.9794	9.465
12	10.0309	9.3107	9.7737
13	10.3395	9.5165	9.8766
14	9.5165	9.5165	9.7737
15	10.391	9.7222	9.2593
16	10.0823	9.6708	9.6194
17	10.1852	9.8766	9.3107
18	10.2366	9.5679	10.0309
19	9.5165	9.5165	10.0823
20	10.2881	9.928	9.8766
21	10.3395	9.928	10.2366
22	10.8539	10.0309	9.6708
23	11.0597	9.6194	9.7222
24	9.2593	9.465	9.7222
Max	11.0597	10.0309	10.391
Min	8.7963	9.0535	5.607
Avg	9.7973	9.6108	9.6129

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 097006 / 132 KV DAHIWAD

Feeder No / Name : 409 / 33 KV THALNER

Feeder KV- 33 / INCOMING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(NON CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	15-JUN-18	18-JUN-18	19-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
1	8.5391	7.2017	10.3395
2	8.5391	9.3107	10.5453
3	8.5391	9.465	10.6482
4	9.5679	9.7737	10.6996
5	10.2881	11.214	11.1111
6	10.4424	11.6255	11.7284
7	1.9547	11.3169	11.8313
8	7.5617		11.5226
9	***	11.1626	11.1626
10	7.3045	10.2881	9.7737
11	13.2202	11.1626	8.0247
12	13.7346	11.0597	8.5905
13		10.8539	
14		10.9054	
15		7.8189	
16		10.8539	
17		1.6461	
18		2.0062	
19		2.3148	
20		2.3663	
21		2.0576	
22		1.8004	
23		9.465	
24	8.5391	7.7161	10.5453
Max	50.9774	11.6255	11.8313
Min	1.9547	1.6461	8.0247
Avg	12.2468	7.9733	10.5018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094002 / 33/11 KV SHIRPUR

Feeder No / Name : 202 / 11 kV Karwand naka

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.2058	.1715	.2229	.2058	.2058
2	.1372	.1372	.1715	.1715	.2229	.1715	.2058
3	.1372	.1372	.1715	.1715	.2229	.1715	.1715
4	.1715	.1372	.2058	.2058	.2401	.1715	.1715
5	.2058	.1715	.3429	.2572	.2572	.2058	.2058
6	.3772	.2058	.3429	.3086	.2572	.2572	.3772
7	.2743	.3086	.2743	.3086	.3772	.3086	.3429
8	.3086	.3086	.3086	.3086	.3429	.2572	.3086
9	.3086	.2572	.3086		.3429	.2572	.3086
10	.3086	.2743	.3086	.3429	.3086	.3429	.2058
11	.2572	.3086	.3086	.3086	.3429	.3086	.2058
12	.3429	.3429	.2572	.3086	.3086	.3086	.2058
13	.3086	.3772	.3429	.3429	.3429	.3429	.2058
14	.2572	.3772	.3086	.3772	.3429	.3772	.2743
15	.2572	.3772	.3086	.3772	.3429	.3772	.3429
16	.3086	.3772	.3086	.4287	.3086	.3772	.3429
17	.3086	.3772	.3429	.3429	.3086	.3429	.2743
18	.3086	.3086	.3429	.3086	.3086	.3429	.2401
19	.3429	.2743	.3086	.3086	.2572	.3429	.2058
20	.3086	.2743	.2572	.3086	.3086	.3429	.2058
21	.2572	.2915	.2572	.2743	.3086	.3429	.2058
22	.2058	.2058	.2572	.2743	.3086	.2401	.2058
23	.1715	.2058	.2058	.2572	.2572	.2401	.2058
24	.1715	.1715	.2058	.1715	.2572	.2058	.2572
Max	.3772	.3772	.3429	.4287	.3772	.3772	.3772
Min	.1372	.1372	.1715	.1715	.2229	.1715	.1715
Avg	.2586	.2658	.2772	.2885	.2958	.2851	.2451

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094002 / 33/11 KV SHIRPUR

Feeder No / Name : 204 / CHANDPURI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		3.0864	2.7435	2.572	2.2862		2.1338
2		3.0864	2.774	2.572	2.2862		2.1643
3		3.0864	2.774	2.572	2.2862		2.1643
4		3.1722	2.8045	2.7435	2.4387		2.1643
5		3.3436	2.8959	3.0007	2.5911		2.1948
6			2.9264	3.1722	2.8959		2.2558
7				3.4294	3.4294	2.7435	2.4691
8		2.7435	2.0119	3.3436	2.8959	3.0864	2.6216
9		2.8959	2.3148		3.2579	2.8197	2.9835
10	3.0864					2.8045	
11	3.7723					2.774	
12						2.774	
13	3.6008					2.7435	
14	3.7723					.2439	
15	3.7723					2.1948	
16	3.4294						
17	3.6008						
18	3.4294						
24		2.572	2.7435	2.572	1.5242		2.1338
Max	3.7723	3.3436	2.9264	3.4294	3.4294	3.0864	2.9835
Min	3.0864	2.572	2.0119	2.572	1.5242	.2439	2.1338
Avg	3.5580	2.9983	2.6654	2.8864	2.5892	2.4649	2.3285

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094002 / 33/11 KV SHIRPUR

Feeder No / Name : 205 / TOWN COLONY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4348	2.1434	2.0576	2.2634	2.2291	2.3663	2.4006
2	2.2977	2.0919	2.1262	2.1948	2.1434	2.2634	2.2977
3	2.0576	2.0233		2.1434	2.0576	2.1948	2.2634
4	2.0233	1.9719	1.989	2.0233	1.8861	2.1434	2.2291
5	1.9547	1.9204	1.9204	1.9719	1.9719	2.0576	2.1605
6	1.8861	1.8861	1.8861	1.9204	1.9376	2.0233	2.1434
7	1.8004	1.8861	1.8004	1.749	1.8861	1.9719	1.9204
8	1.7833	1.8004	1.6804	1.7147	1.7661	1.8004	1.7833
9		1.5432	1.6289		1.6975	1.6289	1.749
10	1.7147	1.5775	1.5432	1.6632	1.749	1.7147	1.7147
11	1.7147	1.7147	1.749	1.6975	1.749	1.9204	1.749
12	1.8004	1.749	1.7147	1.7147	1.8004	1.9204	1.8176
13	1.8004	1.8519	1.8004	1.8004	1.8861	2.1262	1.8176
14	1.9719	1.8861	1.8519	1.8861	2.0576	2.1948	2.0576
15	1.9719	1.9547	1.8519	1.8861	2.0576	2.2634	2.0576
16	2.0233	1.9204	1.8519	1.9376	2.0919	2.1262	2.1262
17	1.8861	1.7147	1.8004	1.8861	.6859	2.0576	2.0576
18	1.749	1.6461	1.6289	1.8004		1.7833	1.8861
19	1.6289	1.8861	1.7147	1.8861	2.3148	1.8861	1.9204
20	1.749	2.0233	1.749	1.9719	2.3663	1.9204	1.9204
21	1.9719	2.1605	1.9719	2.0233	2.3663	2.0233	1.9547
22	2.0576		2.0919	2.2977	2.4863	2.1262	2.0576
23	2.3148	2.2291	2.4006	2.2977	2.6063	2.4863	2.2634
24	2.572	2.1948	2.3148	2.3148	2.2977	2.4006	2.572
Max	2.572	2.2291	2.4006	2.3148	2.6063	2.4863	2.572
Min	1.6289	1.5432	1.5432	1.6632	.6859	1.6289	1.7147
Avg	1.9637	1.9033	1.8750	1.9585	2.0039	2.0583	2.0383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094002 / 33/11 KV SHIRPUR

Feeder No / Name : 206 / 11 KV CHANDPURI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3429	.3086	.3429	.3429	.3429	.3429
2	.3086	.3086		.3086	.3086	.3086	.3086
3	.3086	.3086	.3086	.3086	.3086	.3086	.3086
4	.3772	.3429	.3086	.3086	.3086	.3086	.3086
5	.4115	.4115	.4115	.3772	.3772	.3772	.4115
6	.5144	.5144	.4801	.4801	.463	.5144	.5487
7	.4801	.5144	.5144	.4458	.4458	.4801	.4801
8	.4115	.4801	.4458	.3772	.3944	.4115	.4458
9	.3772	.4115	.4115		.3772	.3772	.3772
10	.3772	.3772	.3772	.3772	.3772	.3772	.3429
11	.3429	.3772	.3772	.3429	.3772	.3772	.3429
12	.3086	.3772	.2572	.3772	.3429	.3772	.3429
13	.2572	.3429	.3086	.3429	.3429	.3429	.3429
14	.2572	.3429	.3086	.3429	.3429	.3086	.3429
15	.2572	.3429	.3086	.3429	.3429	.3086	.3772
16	.2572	.3429	.3429	.3429	.3429	.3086	.3772
17	.3086	.3772	.3429	.3429	.3429	.3086	.3772
18	.3429	.4115	.3429	.3772	.3429	.3429	.3772
19	.4115	.4458	.4458	.4287	.3772	.4115	.3772
20	.4801	.4801	.5144	.4458	.4801	.4458	.3772
21	.4115	.4115	.4458	.4287	.4115	.4458	.3429
22	.3772	.3772	.3772	.3772	.3772	.4115	.3429
23	.3429	.3429	.3429	.3429	.3429	.3772	.3086
24	.3429	.3429	.3429	.3429	.3429	.3429	.3429
Max	.5144	.5144	.5144	.4801	.4801	.5144	.5487
Min	.2572	.3086	.2572	.3086	.3086	.3086	.3086
Avg	.3572	.3886	.3750	.3697	.3672	.3715	.3686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094002 / 33/11 KV SHIRPUR

Feeder No / Name : 207 / 11 KV Express Feeder PWW NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343	.0343	.0343	.0343	.0343
2	.0343	.0343	.0343	.0343	.0343	.0343	.0343
3	.0343	.0343	.0343	.0343	.0343	.0343	.0343
4	.0343	.0343	.0343	.0343	.0343	.0343	.0343
5	.0343	.0343	.0343	.0343	.0343	.0343	.0343
6	.0343	.0343	.0343	.0343	.0343	.0343	.0343
7	.0343	.0343	.0343	.0343	.0343	.0343	.0343
8	.0343	.0343	.0343	.0343	.0343	.0343	.0343
9	.0343	.0343	.0514		.0343	.0343	.0343
10	.0343	.0343	.0514	.0514	.0343	.0514	.0343
11	.0514	.0343	.0514	.0514	.0514	.0514	.0343
12	.0514	.0343	.0514	.0514	.0514	.0343	.0343
13	.0514	.0514	.0514	.0514	.0343	.0514	.0343
14	.0514	.0514	.0343	.0514	.0514	.0514	.0343
15	.0343	.0514	.0343	.0514	.0514	.0514	.0343
16	.0343	.0514	.0343	.0514	.0514	.0514	.0343
17	.0514	.0343	.0343	.0514	.0514	.0343	.0343
18	.0514	.0343	.0343	.0514	.0514	.0343	.0343
19	.0343	.0343	.0343	.0343	.0514	.0514	.0343
20	.0343	.0343	.0343	.0343	.0343	.0343	.0343
21	.0343	.0343	.0343	.0343	.0343	.0343	.0343
22	.0343	.0343	.0343	.0343	.0343	.0343	.0343
23	.0343	.0343	.0343	.0343	.0343	.0343	.0343
24	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Max	.0514	.0514	.0514	.0514	.0514	.0514	.0343
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.0386	.0372	.0379	.0410	.04	.0393	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094002 / 33/11 KV SHIRPUR

Feeder No / Name : 208 / 11 KV YOGESHWAR COLONY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.2058	.1715	.2058	.2058	.2058	.2058
2	.1715	.2058	.1715	.2058	.1886	.2058	.1715
3	.1715	.2058	.1715	.2058	.1715	.2058	.1715
4	.2058	.2058	.1715	.2058	.1715	.2572	.1715
5	.2058	.2572	.2058	.2572	.1886	.2572	.2058
6	.2401	.2572		.2572	.2229	.2915	.2401
7	.2401	.2572	.2401	.2572	.2401	.2915	.2401
8	.2401	.2743	.2401	.2743	.2743	.2915	.2401
9	.2572	.2572	.2401		.2915	.2743	.3429
10	.2572	.2743	1.5089	.2743	.3086	.3086	.3772
11	.2572	.2743	.2572	.2743	.2915	.2743	.3772
12		.2401	.2572	.2743	.2915	.2743	.3429
13	.2572	.2401	.2743	.2229	.2572	.2743	.3429
14	.2572	.2401	.2743	.2058	.2572	.2401	.3086
15	.2058	.2401	.2743	.2058	.2572	.2401	.3086
16	.2058	.2058	.2743	.2058	.2572	.2401	.2401
17	.2058	.2058	.2572	.2058	.2572	.2401	.2401
18	.2572	.1715	.2572	.2401	.2572	.2401	.2743
19	.2572	.2401	.2572	.2401	.2572	.2401	.2401
20	.2572	.2743	.2572	.2401	.2743	.2401	.2058
21	.2572	.2401	.2572	.2229	.2743	.2743	
22	.2058	.2401	.2058	.2743	.2572	.2743	.2058
23	.2058	.2058	.2058	.2401	.2058	.2401	.2058
24	.2058	.2058	.1715	.2058	.2229	.2058	.2401
Max	.2572	.2743	1.5089	.2743	.3086	.3086	.3772
Min	.1715	.1715	.1715	.2058	.1715	.2058	.1715
Avg	.2259	.2344	.2870	.2348	.2451	.2536	.2565

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094030 / 33/11 KV ARTHE

Feeder No / Name : 201 / ARTHE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.7309	1.9989	2.0481	2.1434	1.776	
2		1.776	1.9919	2.0645	2.1605	1.776	1.5565
3		1.8061	1.9372	2.0645	2.1776	1.8061	1.6385
4		1.8663	2.0081	2.0809	2.1776	1.8362	1.6549
5		1.9265	2.0481	2.0972	2.2805	1.8964	1.6876
6		1.9566	2.0729	2.0481	2.3834	1.9566	1.7204
7		1.9717	2.1052	2.0153	2.332	1.8061	1.8023
8		2.0018	2.1285	2.0645	2.3148	1.8061	1.7368
9		2.0557	2.13	2.0481		1.9989	1.7204
10	1.8964						
11	1.9265						
12	1.9867						
13	1.9867						
14	2.1072						
15	2.0319						
16	1.9867						
17	1.9867						
24		1.7309	1.9989	2.0153	2.1434	1.8061	1.4582
Max	2.1072	2.0557	2.13	2.0972	2.3834	1.9989	1.8023
Min	1.8964	1.7309	1.9372	2.0153	2.1434	1.776	1.4582
Avg	1.9886	1.8823	2.0420	2.0547	2.2348	1.8465	1.6640

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094030 / 33/11 KV ARTHE

Feeder No / Name : 203 / VIKHRAN AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658						
2	.583						
3	.5658						
4	.6001						
5	.6001						
6	.6859						
7	.703						
8	.7202						
10		.5735	.5407	.6554	.5489	.6718	.6554
11		.6478	.6882	.6859	.5617	.7045	.6478
12		.6154	.6718	.6859	.5234	.6882	.6802
13		.6226	.7045	.6859	.5361	.6718	.6802
14		.6062	.6882	.6859	.5106	.6554	.6325
15		.583	.6882	.6516	.5234	.639	.639
16		.5761	.6554	.6687	.5234	.6554	.6081
17		.5506	.6882	.6859	.5361	.6882	.6226
24	.583						
Max	.7202	.6478	.7045	.6859	.5617	.7045	.6802
Min	.5658	.5506	.5407	.6516	.5106	.639	.6081
Avg	.6230	.5969	.6657	.6757	.5330	.6718	.6457

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094046 / 33/11 KV WADI S/ST

Feeder No / Name : 201 / 11 KV Wadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3155	.3292	.3155	.3292	.3439	.333	.3475
2	.298	.3258	.3155	.3292	.3292	.3155	.3224
3	.3077	.3258	.333	.3258	.3292	.3155	.3258
4	.3439	.3475	.3506	.3658	.3841	.3506	.3658
5	.3801	.4066	.3898	.439	.4251	.3856	.4024
6	.4344	.5041	.4607	.5228	.4904	.4382	.4668
7	.4163	.4668	.4344	.4668	.4481	.4477	.4251
8	.3982	.4294	.3982	.4066	.4108	.4031	.3881
9	.3801	.3881	.3506	.3881	.3921	.3856	.362
10	.3258	.3475		.3511	.3511	.3511	.3439
11	.3292	.333		.3475	.333	.3696	
12	.3292	.333	.3292	.3439	.333	.3658	.3511
13	.3475	.3506	.3658	.3696	.333	.3801	.3292
14	.3439	.3366	.3696	.3658	.3506	.3658	.3077
15	.3658	.333	.3696	.3696	.333	.3439	.3258
16	.3475	.3544	.1991	.3801	.3544	.3511	.3658
17	.3696	.3898	.3109	.3841	.3721	.3582	.3658
18	.4066	.4163	.4435	.439	.3856	.4066	.4481
19	.4481	.4344	.4854	.4344	.4252	.439	.4294
20	.5041	.4525	.4854	.499	.4961	.4572	.4481
21	.4668	.4119	.5041	.4572	.4207	.4024	.4294
22	.4108	.3721	.4294	.4207	.3856	.3982	.4066
23	.3881	.3366	.3881	.3982	.3681	.3841	.3658
24	.333	.3658	.3366	.3658	.362	.3506	.3658
Max	.5041	.5041	.5041	.5228	.4961	.4572	.4668
Min	.298	.3258	.1991	.3258	.3292	.3155	.3077
Avg	.3746	.3788	.3802	.3958	.3815	.3791	.3778

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094046 / 33/11 KV WADI S/ST

Feeder No / Name : 202 / 11 KV Chandase Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.9814	1.6194	2.1338	2.0062	1.9719	
2		2.0062	1.6842	2.2184	2.1247	2.0178	
3		2.0119	1.7368	2.2184	2.1872	2.0576	
4		2.0622	1.7004	2.2929	2.3087	2.1605	
5		2.0934	1.8842	2.372	2.3765	2.2977	
6		2.4453	2.0056	2.7206	2.4691	2.4691	
7			2.1051	2.7686	2.6886	2.6406	
8		2.4215	2.2131	2.7041	2.6724	2.8807	
9		2.3434	2.1879	2.5463	2.5606	2.7949	.2972
10	2.7831		2.1963				
11	2.915						
12	2.9959						
13	2.8327						
14	2.8826						
15	2.9312						
16	2.8664						
17	2.7526						
24		1.9753	1.5546	2.0469	1.768	1.8482	
Max	2.9959	2.4453	2.2131	2.7686	2.6886	2.8807	.2972
Min	2.7526	1.9753	1.5546	2.0469	1.768	1.8482	.2972
Avg	2.8699	2.1490	1.8989	2.4022	2.3162	2.3139	.2972

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094046 / 33/11 KV WADI S/ST

Feeder No / Name : 203 / 11 KV Kuwe Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.743						
2	.7385						
3	.7628						
4	.7922						
5	.8802						
6	.9095						
7	.9976						
8	1.0122						
9	.9976						
10		.9536		.7956	.743	.6268	.5921
11		1.1584	1.1145	.9164	.9556	.8206	.8253
12		1.1736	1.1294	1.0402	.9846	.86	.8362
13		1.1584	1.0997	1.0425	1.0269	.8251	.8288
14		1.1439	1.0974	1.0269	1.0269	.8543	.7674
15		1.1736	.9934	.9846	1.0122	.8067	.7819
16		1.1584	1.0837	1.0105	1.0269	.6001	.7775
17		1.07	1.1717	1.1568	.9556	.6859	.8173
24	.7002						
Max	1.0122	1.1736	1.1717	1.1568	1.0269	.86	.8362
Min	.7002	.9536	.9934	.7956	.743	.6001	.5921
Avg	.8534	1.1237	1.0985	.9967	.9665	.7599	.7783

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094046 / 33/11 KV WADI S/ST

Feeder No / Name : 204 / NIMAZARI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8745						
2	1.587						
3	1.7004						
4	1.7695						
5	1.8842						
6	1.9951						
7	2.0622						
8	2.0622						
9	.6344						
10				1.7528	1.7604	1.6309	1.4661
11		1.7652	2.0557	1.8061	2.1216	1.929	1.8519
12		1.704	2.0153	1.9372	2.2045	1.9753	1.9372
13			2.0622	2.0715	2.2131	1.9753	1.7375
14		1.6518	2.0715	2.0873	2.1548	1.9814	1.8519
15		1.704	2.1125	2.0715	2.1216	2.0153	1.8747
16		1.7204	2.0715	1.929	2.1548	1.7604	1.9841
17		1.9669	1.9766	2.0715	2.1136	1.713	1.9528
24	.8421						
Max	2.0622	1.9669	2.1125	2.0873	2.2131	2.0153	1.9841
Min	.6344	1.6518	1.9766	1.7528	1.7604	1.6309	1.4661
Avg	1.5412	1.7521	2.0522	1.9659	2.1056	1.8726	1.8320

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094056 / 33/11 KV FILTRATION PLANT

SHIR

Feeder No / Name : 203 / 11 KV K.G. ROAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9547	1.9719	2.0405	2.0233	1.9204	2.1262	
2	1.9376	1.9719	2.0233	1.989	1.8861	2.0576	1.6766
3	1.8861	1.9547	1.8861	1.8861	1.869	1.9719	
4	1.7147	1.8861	1.7147	1.8861	1.8347	1.8347	1.6004
5	1.4746	1.8176	1.5604	1.8176	1.8004	1.7147	
6	1.5432	1.6975	1.5604	1.6975	1.7147	1.7147	1.5242
7	1.5775	1.5432	1.5432	1.6461	1.6461	1.6804	
8	1.5432	1.4575	1.5432	1.6118	1.6289	1.5947	1.448
9	1.4403	1.4232	1.5089	1.4918	1.5775	1.5089	1.5432
10	1.4232	1.4575	1.5089	1.4575	1.6289	1.6289	1.7318
11	1.6118	1.5089	1.5089	1.5947	1.6975	1.749	1.7661
12	1.6461	1.5432	1.5089	1.6289	1.7661	1.8347	1.8004
13	1.6632	1.6118	1.6461	1.7318	1.8347	1.8861	1.9719
14	1.6804	1.6461	1.7147	1.7833	1.9033	1.989	1.9719
15	1.6975	1.7318	1.7833	1.869	1.989	2.0576	2.0062
16	1.6461	1.6632	1.6632	1.9547	1.9719	1.869	1.9204
17	1.6118	1.5947	1.6975	1.869	1.9204	1.6975	1.8519
18	1.5432	1.5432	1.5432	1.8347	1.749	1.7147	1.8176
19	1.6632	1.4918	1.6975	1.7318	1.6461	1.7318	1.8176
20	1.7318	1.7661	1.869	1.869	1.7147	1.9719	1.8176
21	1.7833	1.749	1.9204	1.9547	1.989		1.869
22	1.869	1.869	1.8861	2.0233	2.0576	1.829	1.7985
23	1.9376	1.9719	1.9376		2.2119		1.829
24	1.9547	1.9547	2.0405	1.9547	2.0233	2.1605	1.829
Max	1.9547	1.9719	2.0405	2.0233	2.2119	2.1605	2.0062
Min	1.4232	1.4232	1.5089	1.4575	1.5775	1.5089	1.448
Avg	1.6890	1.7011	1.7211	1.7959	1.8326	1.8329	1.7796

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094056 / 33/11 KV FILTRATION PLANT

SHIR

Feeder No / Name : 204 / 11 KV VIDYAVIHAR COLONY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3258	.3086	.3086	.3086	.3258	
2	.2915	.3429	.3086	.3086	.2743	.3258	.2286
3	.2572	.3258	.2572	.2743	.2743	.2915	
4	.2229	.2572	.2572	.2572	.2401	.2915	.1981
5	.2058	.1886	.2058	.2572	.2401	.2572	
6	.1886		.2058	.2229	.2229	.2572	.1981
7	.1886	.1715	.2058	.2229	.2229	.2401	
8	.1543	.1543	.1715	.2058	.2058	.2229	.1829
9	.1372	.1543	.1715	.1886	.2058	.1886	.1886
10	.1543	.1543	.1543	.1715	.2058	.1715	.1886
11	.1543	.1543	.1886	.1715	.2058	.1886	.1886
12	.12	.1543		.1715	.2058	.2058	.1886
13	.1715	.1886		.2058	.2229	.2229	.2229
14	.2058	.1886	.2058	.2401	.2229	.2401	.2401
15	.2058	.2058	.2058	.2401	.2915	.2401	.2401
16	.2058	.1886	.2401	.2229	.2572	.2229	.2572
17	.2058	.1886	.2058	.2058	.2401	.2229	.2058
18	.1886	.1715	.2058	.1715	.2229	.2058	.2058
19	.2058	.1543	.2058	.1886	.2229	.2229	.2229
20	.2058	.2229	.2229	.2401	.2743	.2743	.2572
21	.2229	.2229	.2401	.2401	.2915		.2572
22	.2572	.2743	.2743	.2743	.3429	.2743	.2743
23	.3086	.3258	.3258		.3601		.2743
24	.3086	.3086	.2915	.3429	.3258	.3601	.2743
Max	.3086	.3429	.3258	.3429	.3601	.3601	.2743
Min	.12	.1543	.1543	.1715	.2058	.1715	.1829
Avg	.2115	.2184	.2299	.2319	.2536	.2479	.2247

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094065 / 33/11 KV Vikharan Tq.Shirpur

Feeder No / Name : 201 / 11 KV Vikharan-Mukhed

GAOTHAN FEEDER

Gavthan Feeder KV- 11 /
OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.181	.181	.181	.1991	.2172	
2			.181	.181	.1991	.2172	
3		.2172	.181	.181	.2353	.2534	
4		.2172	.181	.2353	.2353	.2896	
5		.1991	.1991	.2534	.2896	.2715	
6		.1991	.181	.2534	.2534	.2353	
8						.2353	
9					.2353	.2172	
10	.1629	.1991	.181	.2172	.2353		.2353
11	.1629	.1991	.181	.2353	.2353		.2353
12	.1629	.1991	.1991	.2353	.2534		.2534
13	.1629	.1991	.1991	.2172	.2353		.2534
14	.1629	.2172	.1991	.2353	.2353		.2353
15	.1991	.1991	.1991	.2353	.2534		.2534
16	.1991	.181	.1991	.2353	.2534		.2715
17	.1991	.181	.181	.2172	.2353		.2534
18	.1448	.1448	.1629	.2353	.2353		.2353
19	.1629	.181	.1991	.2353	.2534		.2896
20	.2172	.2534	.3077	.2534	.2896		.2896
21	.2715	.2353	.3077	.2715	.2896		
22	.1991	.2172	.2715	.2353	.2534		
23	.181	.181	.2172	.2353	.2172		
24		.181	.1991	.1991	.1991	.2172	
Max	.2715	.2534	.3077	.2715	.2896	.2896	.2896
Min	.1448	.1448	.1629	.181	.1991	.2172	.2353
Avg	.1849	.1991	.2051	.2275	.2419	.2393	.2550

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094065 / 33/11 KV Vikharan Tq.Shirpur

Feeder No / Name : 202 / 11 KV Ukhawadi Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	1.6221	1.7204	1.5565	1.5384	
11	1.8842	1.7204	1.8515	1.7004	1.749
12	1.917	1.6876	1.8515	1.8138	1.7814
13	1.8679	1.917	1.8842	1.8461	1.7814
14	1.8515	1.9662	1.8679	1.8623	1.8299
15	1.8515	1.8842	1.8679	1.8461	1.8299
16	1.8187	1.8842	1.9006	1.8623	1.8138
17	1.7204	1.917	1.8679	1.8461	1.8138
18				1.8623	1.7814
Max	1.917	1.9662	1.9006	1.8623	1.8299
Min	1.6221	1.6876	1.5565	1.5384	1.749
Avg	1.8167	1.8371	1.831	1.7975	1.7976

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094065 / 33/11 KV Vikharan Tq.Shirpur

Feeder No / Name : 203 / 11 KV Mukhed Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.6518	1.8515	1.7204	1.8515	1.7814
2		1.7004	1.8679	1.8023	1.8515	1.8138
3		1.7814	1.917	1.8023	1.8679	1.8138
4		1.7814	1.8679	1.8842	1.9006	1.8623
5		1.8785	1.8842	1.9006	1.9006	1.9109
6		1.9109	1.9662	1.9662	1.8842	1.9433
7		1.9433	1.9989	1.9662	1.8679	2.0081
8		1.9433	2.0153	1.9662	1.9498	2.0243
9		1.9433	1.9989	2.13	2.0972	2.0405
10	1.9919					
11	2.0243					
12	2.0243					
13	1.9919					
14	1.9919					
15	2.0405					
16	2.0243					
17	2.0243					
18	2.0243					
21	.1219					
24		1.6518	1.7532	1.6712	1.7368	1.7004
Max	2.0405	1.9433	2.0153	2.13	2.0972	2.0405
Min	.1219	1.6518	1.7532	1.6712	1.7368	1.7004
Avg	1.8260	1.8186	1.9121	1.8810	1.8908	1.8899