

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074004 / 33 KV BULDANA

Feeder No / Name : 200 / Station Transformer
Feeder KV- 33 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.12	.1543	.1029	.12	.12	.1029
2	.1029	.12	.1543	.1029	.12	.12	.1543
3	.1029	.12	.1543	.1029	.12	.12	.1029
4	.1029	.12	.1543	.1029	.12	.12	.1029
5	.1029	.12	.1543	.1029	.12	.12	.1029
6	.0343	.04	.1029	.0343	.08	.08	.0343
7	.0343	.04	.0514	.0343	.04	.04	.0343
8	.0343	.04	.0514	.0343	.04	.04	.0343
9	.0343	.04	.0514	.0343	.0343	.04	.0343
10	.0514	.0343	.04	.04	.0343	.04	.04
11	.0514	.0343	.04	.04	.0343	.0514	.04
12	.0514	.0343	.04	.04	.0343	.04	.04
13	.0514	.0343	.04	.04	.0343	.04	.04
14	.0514	.0343	.04	.04	.0343	.04	.0343
15	.0514	.0343	.04	.04	.0343	.04	.0343
16	.0514	.0343	.04	.04	.0343	.04	.04
17	.04	.0343	.04	.04	.0343	.04	.04
18	.04	.0514	.0343	.04	.04	.0343	.0343
19	.04	.0514	.0343	.08	.04	.0343	.0343
20	.1543	.1543	.1029	.12	.12	.1029	.1029
21	.12	.1543	.1029	.12	.12	.1029	.1029
22	.12	.1543	.1029	.12	.12	.1029	.1029
23	.12	.1543	.1029	.12	.12	.1029	.12
24	.1029	.12	.1543	.1029	.12	.12	.1029
Max	.1543	.1543	.1543	.12	.12	.12	.1543
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.0729	.0781	.0826	.0698	.0729	.0722	.0672

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074004 / 33 KV BULDANA

Feeder No / Name : 201 / 11KV BULDANA - I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	07-JUN-18
HR	Load (MW)
12	.0133
Max	.0133
Min	.0133
Avg	.0133

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074004 / 33 KV BULDANA

Feeder No / Name : 202 / 11 KV BULDANA - II
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.439	.3658	.4115	.4115	.4024	.3772
2	.4801	.3658	.3658	.4115	.4115	.4024	.3772
3	.4458	.3658	.3658	.3772	.4115	.4024	.3772
4	.4115	.3658	.3658	.3429	.3772	.3658	.3429
5	.3772	.3658	.3292	.3086	.3772	.3658	.3429
6	.3772	.3292	.3292	.3086	.3429	.3658	.3429
7	.3429	.2926	.3109	.3429	.3429	.3292	.3772
8	.3429	.2926	.3109	.3772	.3429	.3292	.3429
9	.3944	.3292	.3109	.4115	.4115	.4024	.4115
10	.567	.5487	.3429	.5487	.4801	.4973	.4755
11	.7133	.6516	.4115	.6584	.6516	.6344	.6219
12	.7133	.6516	.4287	.7316	.6859	.6516	.6219
13	.7865	.6173	.4115	.7316	.6859	.6516	.6219
14		.6516	.3772	.7316	.6859	.6173	.6173
15	.7316	.6516	.4115	.7316	.6859	.6173	.6173
16	.8048	.6173	.3772	.7316	.6859	.6859	.6584
17	.7316	.6516	.4287	.7316	.6859	.6859	.6584
18	.6584	.5853	.4115	.6516	.6219	.6516	.6173
19	.5487	.5121	.4801	.5487	.5853	.5487	.5487
20	.5853	.5487	.4458	.5144	.5853	.583	.5144
21	.5281	.439	.4458	.4801	.5121	.4801	.4458
22	.439	.4024	.4115	.4115	.439	.4115	.4115
23	.4755	.4024	.4115	.4458	.439	.4115	.439
24	.4801	.4755	.3841	.4115	.4287	.4024	.3772
Max	.8048	.6516	.4801	.7316	.6859	.6859	.6584
Min	.3429	.2926	.3109	.3086	.3429	.3292	.3429
Avg	.5398	.4814	.3847	.5147	.5120	.4956	.4808

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074004 / 33 KV BULDANA

Feeder No / Name : 203 / 11 KV Town-III

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.7316	.6219	.5487	.6173	.6584	.4877
2	.5792	.6584	.6219	.5487	.5487	.6219	.4877
3	.5792	.6584	.5853	.5182	.5487	.5853	.4877
4	.5487	.6584	.5487	.4877	.5487	.5853	.4572
5	.5182	.6219	.5121	.4572	.5487	.5853	.4572
6	.5182	.5853	.5121	.4268	.5487	.5487	.4572
7	.5487	.5487	.5121	.4268	.5487	.5853	.4877
8	.5487	.5853	.4938	.4268	.5316	.5487	.4572
9	.4268	.5487	.4755	.4268		.5487	.4877
10	.567	.4572	.3963	.5121		.5316	.4755
11	.5487	.4572	.4287	.439		.463	.439
12	.6219	.4572	.4268	.5121		.4458	.439
13	.5853	.4877	.4458	.4755	.6401	.4115	.439
14	.695	.5487	.4115	.5121	.6401	.3506	.3963
15	.7316	.5487	.3772	.5121	.6097	.4115	.3963
16	.6584	.4877	.3658	.5487	.5487	.4115	.4755
17	.6219	.5182	.463	.5121	.5487	.463	.4755
18	.6584	.5853	.4268	.4877	.6036	.4268	.3963
19	.6584	.5853	.4572	.5487	.6219	.4572	.4268
20	.695	.695	.4877	.6173	.6584	.4877	.5487
21	.7316	.6584	.5182	.5487	.6584	.5487	.5487
22	.5335	.695	.5487	.6516	.7316	.5182	.5487
23	.7316	.695	.5792	.6516	.7316	.5182	.6584
24	.6097	.7316	.6584	.5487	.6173	.695	.4877
Max	.7316	.7316	.6584	.6516	.7316	.695	.6584
Min	.4268	.4572	.3658	.4268	.5316	.3506	.3963
Avg	.6052	.5919	.4948	.5144	.6026	.5170	.4758

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074004 / 33 KV BULDANA

Feeder No / Name : 204 / 11 KV KOLWAD G

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3032		1.1458	1.0288	1.1488	1.1827	1.0288
2	1.2003	.6653	1.1088	.9945	1.0974	1.1273	1.0288
3	1.0974	1.2567	1.0534	.9259	1.0288	1.0903	.9602
4	1.0288	1.1088	.9979	.8573	.9945	1.0719	.9259
5	.9602	1.0349	.961	.823	.9945	1.0349	.8573
6	.9259	.9979	.8686	.7888	.8573	.924	.7888
7	.8916	.924	.8501	.7202	.823	.8871	.9602
8	.8916	1.1273	.8131	.7545	.823	.9425	.8573
9	.8916	1.1458	.7762	.7545	.823	.8871	.823
10	1.0719	1.0631	.7545	.924	.9259	.8916	.9425
11	1.1888	1.0974	.6859	1.1088	1.0631	1.0117	1.0349
12	1.2567	1.0974	.8573	1.1088	1.0288	.9945	1.0719
13	1.4415	1.2003	.8745	1.1827	1.0974	.9945	1.0903
14	1.46	1.2346	.8573	1.2567	1.2346	.9431	1.0117
15	1.5708	1.3032	.8745	1.3306	1.2689	1.0288	.9945
16	1.5708	1.2346	.9088	1.386	1.2003	1.0631	1.1458
17	1.4784	1.2003	.8916	1.2197	1.2689	1.0631	1.0719
18	1.3491	1.1273	.8916	1.0802	1.1827	.9602	.9945
19	1.3306	1.2012	.9431	1.1488	1.2752	1.0288	.9945
20	1.423	1.2382	.9945	1.2003	1.3491	1.166	1.1145
21	1.2936	1.1827	1.0288	1.166	1.2567	1.0631	1.0631
22	1.3491	1.2752	1.0288	1.166	1.2567	1.0288	1.046
23	1.423	1.2936	1.0974	1.286	1.3491	1.0288	1.1273
24		1.4045	1.2012	1.0974	1.2174	1.2752	1.0288
Max	1.5708	1.4045	1.2012	1.386	1.3491	1.2752	1.1458
Min	.8916	.6653	.6859	.7202	.823	.8871	.7888
Avg	1.2347	1.1484	.9360	1.0546	1.1069	1.0287	.9984

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074004 / 33 KV BULDANA

Feeder No / Name : 209 / 11 KV Ekta Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.406	1.4632	1.6827	1.5089	1.6461	1.3535	1.0631
2	1.3375	1.3717	1.6095	1.4746	1.5775	1.2986	1.0288
3	1.2689	1.7193	1.5546	1.4403	1.5432	1.2254	.9945
4	1.2003	1.6095	1.4815	1.3717	1.4403	1.1888	.9602
5	1.166	1.4998	1.3306	1.3032	1.3717	1.134	.9259
6	1.1317	1.4266	1.3169	1.2346	1.3203	1.0974	.8573
7	1.0974	1.4266	1.3535	1.2689	1.406	1.134	.9259
8	.9945	1.3352	1.2437	1.2346	1.3375	.9877	.8573
9	1.0288	1.3352	1.262	1.2003	1.2689	1.0608	.7888
10	1.1157	1.286	1.046	1.1888	1.166	.8402	.8048
11	1.0974	1.3032	1.0288	.9877	1.0631	.8059	.8048
12	1.0425	1.286	1.1145	1.134	1.1317	.7545	.8048
13	1.134	1.3375	1.0802	1.1888	1.1317	.703	.823
14	1.2254	1.3717	1.0974	1.2803	1.2346	.7716	.8413
15	1.2986	1.4575	1.1317	1.4266	1.3375	.823	.8779
16	1.2803	1.4403	1.1145	1.4449	1.3375	.8573	.9145
17	1.2071	1.3717	1.2003	1.3535	1.3375	.8573	.8779
18	1.1706	1.3535	1.2003	1.2517	1.4083	.8916	.823
19	1.2071	1.4815	1.2689	1.3717	1.1706	.9259	.8745
20	1.4083	1.6278	1.406	1.5604	1.3169	.9945	1.0631
21	1.4083	1.6278	1.4746	1.6118	1.2437	1.1317	1.0802
22	1.5364	1.7741	1.5432	1.749	1.4083	1.166	1.1488
23	1.6095	1.8107	1.6461	1.8347	1.4998	1.0974	1.2803
24	1.4746	1.5181	1.7558	1.5432	1.749	1.4632	1.0974
Max	1.6095	1.8107	1.7558	1.8347	1.749	1.4632	1.2803
Min	.9945	1.286	1.0288	.9877	1.0631	.703	.7888
Avg	1.2436	1.4681	1.3310	1.3735	1.3520	1.0235	.9383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074012 / 33/11 KV D'SHEWALI

Feeder No / Name : 200 / Station Transformer
Feeder KV- 33 / OUTGOING

DATE	01-JUN-18	02-JUN-18
HR	Load (MW)	Load (MW)
6	.1143	
9		.1097
24	.1143	
Max	.1143	.1097
Min	.1143	.1097
Avg	.1143	.1097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074012 / 33/11 KV D'SHEWALI

Feeder No / Name : 201 / 11KV DONGAR SHEOLI AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0351	.0648	.1783	.1677		.1677
2	.0762	.0347	.0648	.1677	.1296		.1296
3	.0762	.0347	.0648	.1619	.2012		.1296
4	.0762	.0343	.0648	.1341	.1677		.2012
5	.0762	.0343	.0671	.1341	.1619		.2012
6	.0762	.0347	.0648		.2267	.2286	.1296
7	.0762		.0648	.2286	.3018	.2286	.1943
8	.1143		.0648	.2012	.2591	.3048	.1943
9	.0762	.1715	.1943	.0671	.0648	.0648	.0648
10	.2713		.2267	.0648	.2477	.0648	.0532
11	.2401		.2591	.0648	.0762	.0671	.0351
12	.2035		.1943	.0648	.0762	.0671	.0347
13	.2543		.1943	.0648	.0762	.0671	.0343
14			.1296	.0648	.0762	.0671	.0351
15			.1943	.0648	.0762	.0671	.0351
16	.2572		.1943	.0671	.1143	.0671	.0351
17	.2743		.0648	.0671	.1143	.0648	.0351
18	.0351	.0648	.0648	.0671	.1524	.0671	.0351
19	.0526	.0648	.0972	.0671		.0972	.0347
20	.0347	.0648	.0648	.0648	.1524	.0972	.0343
21	.0351	.0648	.0671	.0648	.1524	.0972	.0351
22	.0351	.0648	.0671	.0648	.1524	.0972	.0351
23	.0351		.1341	.1296		.1296	.1372
24	.1829	.0351	.0648	.1619	.1943		.1677
Max	.2743	.1715	.2591	.2286	.3018	.3048	.2012
Min	.0347	.0343	.0648	.0648	.0648	.0648	.0343
Avg	.1198	.0568	.1138	.1050	.1519	.1080	.0912

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074012 / 33/11 KV D'SHEWALI

Feeder No / Name : 202 / 11KV KINHOLA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0347	.0324	.1677	.1619		.1943
2	.0381	.0347	.0335	.1619	.1619		.1943
3	.0381	.0343		.1619	.1341		.1619
4	.0381	.0351		.1943	.1619		.2012
5	.0381	.0351		.1619	.1943	.1524	.1619
6		.0351		.1619	.1619	.1905	.1572
7	.0381			.1619	.1943	.2858	.2429
8	.0381			.1677	.2515	.2858	.1619
9	.0762	.0526		.0324	.0381	.0335	.0324
10	.2035	.0335	.1619	.0335	.0381	.0336	.0354
11	.2035	.1943	.1619	.0335	.0381	.0335	.0351
12	.2401	.2429	.1619	.0324	.0381	.0335	.0354
13	.2543	.2429	.2012	.0648	.0381	.0335	.0351
14	.2374	.2515	.1943	.0648	.0381	.0335	.0351
15	.2401	.2429	.2429	.0324	.0381	.0335	.0351
16	.2572	.1619	.1619	.0324	.0381	.0335	.0354
17	.2572	.0335	.0324	.0335	.0572	.0324	.0351
18	.0351	.0324	.0335	.0335	.0572	.0335	.0358
19	.0351	.0335	.0324	.0381	.0572	.0324	.0354
20	.052	.0324	.0324	.0335	.0381	.0324	.0354
21	.0526	.0324	.0335	.0324	.0381	.0324	.0351
22	.0526	.0324	.0335	.0324	.0381	.0335	.0351
23	.0526	.0324	.1619	.1581		.1619	.1372
24	.1524	.0351	.0324	.1619	.1619		.1677
Max	.2572	.2515	.2429	.1943	.2515	.2858	.2429
Min	.0351	.0324	.0324	.0324	.0381	.0324	.0324
Avg	.1160	.0862	.1026	.0912	.0945	.0811	.0946

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074012 / 33/11 KV D'SHEWALI

Feeder No / Name : 203 / 11KV SHELSUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2915	.2915	.1619	.1677		.1296
2	.1905	.3222	.3239	.1677	.1509		.1677
3	.1905	.3086	.2591	.2012	.1509		.1677
4	.1905	.373	.2915	.1677	.1619		.1677
5	.3429	.4458	.2591	.1781	.1619		.1781
6	.381	.57	.4372	.1619	.1677		.1619
7	.1143		.5992	.1341	.1781		.1781
8	.6668		.6478	.1509	.1134	.0381	.1619
9	.6668	.0867	.1619	.2347	.2915	.3018	.2753
10	.1928	.1943	.1619	.3887	.7621	.4049	.373
11	.1227	.1943	.1486	.4694	.4763	.3239	.463
12	.0876		.1677	.3353	.4191	.3688	.4973
13				.4024	.381	.3856	.5087
14	.1886	.1341	.1677	.2096	.381	.3353	.4801
15	.1928	.1457	.1943	.2429	.381	.3077	.407
16	.1928	.1677	.1943	.2753	.381	.3077	.4287
17	.156		.1619	.1457	.1905	.1341	.1928
18	.1715		.1677	.3725	.1905	.1509	.2103
19	.1734	.0671	.1619	.4862	.1905	.1619	.2103
20	.1928	.1296	.1457	.1619		.1619	.1928
21	.1928	.1457	.1296	.1619		.1619	.2103
22	.156	.1619	.1509	.1619		.1509	.1928
23	.2543	.2591	.1619	.1677		.1619	.2103
24	.0762	.3052	.3239	.1677	.1781		.1457
Max	.6668	.57	.6478	.4862	.7621	.4049	.5087
Min	.0762	.0671	.1296	.1341	.1134	.0381	.1296
Avg	.2297	.2390	.2482	.2378	.2738	.2411	.2630

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074012 / 33/11 KV D'SHEWALI

Feeder No / Name : 204 / 11 KV D SHEWALI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.3761	.4858		.4858	.5716	.5182
2	.5335	.3982	.4858	.4858	.4694	.5716	.4858
3	.5335	.4835	.4725	.4858	.5182	.5716	.4534
4	.7621	.6268	.5365	.6154	.503	.5716	.4049
5	.7621	.7421	.6478	.5182	.6706	.6859	
6	.8002	.8238	.7935	.7287	.7935	.6859	.7712
7	.724		.0648	.7449	.7611	.9526	.8259
8	.7049		.5796	.664	.664	.9526	.6964
9	.6287	.6089		.5182	.6154	.5506	.583
10			.583	.4534	.5144	.2683	.5373
11			.4858	.3856	.3048	.1677	.543
12			.3563	.3887		.1677	.4298
13			.3353	.3688	.2667	.1619	.4525
14			.3563	.3401	.3239	.1619	.5014
15			.4024	.4049	.3239	.1781	.4525
16			.4359	.3887	.5716	.2105	.4706
17			.503	.3887	.6478	.2267	.5138
18		.7449	.6203	.6036	.8002	.285	.5258
19		.7125	.6154	.6539		.7935	.6201
20		.7125	.7125	.7377	.8383	.7935	.788
21		.6478	.6371	.6154	.8383	.6874	.7164
22			.5344	.5506	.6859	.6036	.6588
23		.502	.5182	.5182	.5716	.5506	.6516
24		.362	.4858	.4858	.503	.5716	.5182
Max	.8002	.8238	.7935	.7449	.8383	.9526	.8259
Min	.5335	.362	.0648	.3401	.2667	.1619	.4049
Avg	.6647	.5955	.5064	.5237	.5760	.4976	.5704

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074012 / 33/11 KV D'SHEWALI

Feeder No / Name : 206 / SHELSUR GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.3582	.2591	.3018	.2915	.381	.2267
2	.3239	.394	.2915	.2267	.2347	.381	.2915
3	.3239	.4344	.3239	.1677	.3125	.381	.2591
4	.4763	.4656	.3239	.3018	.2267	.381	.2105
5	.5335	.5373	.3563	.3353	.3239	.4572	.1943
6	.5716	.5792	.4049	.3725	.421	.6097	.5344
7	.4954		.3401	.4534	.4527	.5716	.4858
8	.4572		.3401	.3725	.421	.5716	.421
9	.4191	.3582	.3018	.2429	.2753	.3018	.3077
10	.362	.1781	.2753	.2429	.2477	.2267	.2865
11	.3224	.1783	.1943	.2105	.2477	.2915	.2658
12	.2865	.1677	.1943	.2012	.2667	.2105	.2534
13	.2715	.1619	.1943	.2347	.2667	.2012	.2658
14	.2507	.1619	.2267	.2347	.2858	.2267	.2865
15	.2353	.285	.2347	.2429	.2858	.2515	.3077
16	.2715	.1943	.2591	.2591	.3429	.218	.3292
17	.3224	.2915	.3239	.2915	.381	.2591	.3582
18	.4298	.3239	.2753	.3401	.4954	.3077	.3898
19	.394	.4191	.3018	.3239		.421	.4252
20	.3982	.3563	.4024	.3887	.4954	.4696	.4477
21	.3366	.3239	.3563	.3563	.4954	.3688	.362
22	.3582	.3239	.2591	.2591	.4191	.2591	.4298
23	.3258	.1619	.2429	.2429	.381	.2267	.3801
24	.1829	.3258	.2915	.3239	.2267	.381	.2915
Max	.5716	.5792	.4049	.4534	.4954	.6097	.5344
Min	.1829	.1619	.1943	.1677	.2267	.2012	.1943
Avg	.3614	.3173	.2906	.2886	.3390	.3481	.3338

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074015 / 33 KV S/STN. HATEDI

Feeder No / Name : 201 / 11KV NANDRAKOLI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.3391	.3429	.4024	.3772	.39	.3601
2	.4527	.3391	.3429	.4938	.3772	.39	.3429
3	.4904	.373	.3772	.4755	.415	.407	.3429
4	.6036	.4239	.6516	.695	.4904	.4239	.4115
5	.7545	.5087	.8402	.9145	.8299	.4748	.4801
6	1.0185	.8139	.9431	.9877	1.0456	.8817	.9602
7	.8299	.7461	.7716	1.0059	1.0082	.9496	.9431
8	.7167	.6274	.703		.8589	.7969	.7716
9	.5658	.4409	.463	.5121	.5658	.5765	.5144
10	.3772	.3391	.3772	.4024	.415	.407	.3772
11	.3605	.3441	.3086	.4115	.2949	.2713	.3429
12	.4096	.3605	.3429	.3315	.3605	.2683	.3772
13	.3605	.426	.3772	.3353	.3277	.285	.3429
14	.3277	.3277	.3429	.3277	.3277		.3429
15	.3605	.3605	.3772	.2949	.2949		
16	.3932	.3605	.4458	.2949	.2949		.4115
17	.4096	.3441	.4458	.3605	.4096	.3856	.4287
18	.4915	.4096	.5487	.4915	.4424	.5197	.3772
19	.6274	.6001	.6859	.7762	.6443	.7545	.7202
20	.6952	.6516	.6173	.6722	.763	.6516	.6173
21	.4748	.463	.5121	.5658	.4748	.6001	.4801
22	.407	.4115	.4755	.4527	.407	.4115	
23	.373	.3772	.4024	.415		.3944	
24	.415	.3561	.3601	.3841	.415	.407	.3601
Max	1.0185	.8139	.9431	1.0059	1.0456	.9496	.9602
Min	.3277	.3277	.3086	.2949	.2949	.2683	.3429
Avg	.5137	.4477	.5023	.5219	.5148	.5070	.4907

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074015 / 33 KV S/STN. HATEDI

Feeder No / Name : 203 / 11KV KOLWAD SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7922	.7122	.703	.7316	.7545	.1357	.6859
2	.8299	.7122	.6859	.7682	.7922	.1357	.6859
3	.8299	.7291	.7202	.8779	.8299	.1357	.703
4	.8299	.78	.9259	.9877	.8676	.1526	.7373
5	1.0185	.8309	1.0288	1.0974	.9808	.1526	.7888
6	1.2449	1.1361	1.1317	1.1706	1.1949	.2374	.9945
7	1.1317	.9326	.9945	1.0425	1.1203	.2204	1.0288
8	.9431	.8309	.8916	.9511	.9808	.2204	.823
9	.7167	.6952	.6687	.7499	.8299	.1357	.6859
10	.6413	.5935	.2401	.5121	.6413	.1187	.583
11	.6226	.5407	.4801	.4801	.2949	.3561	.4115
12	.6226	.4915	.3772	.4024	.2622	.3688	4.2353
13	.5735	.4752	.4115	.4694	.2458	.3688	.3772
14	.5243	.4588	.3772	.4588	.3277		.3772
15	.5243	.4752	.3772	.3932	.3277		.4115
16	.5735	.4915	.4801	.3932	.4588		.4458
17	.6554	.5571	.4458	.5243	.5243	.503	.4287
18	.5735	.4588	.4115	.5243	.5407	.503	.4115
19	.763	.8916	.9511	.924	.8139	.8916	.8916
20	.9835	.7716	.9877	1.0082	1.0004	1.0288	.8573
21	.8478	.8573	.8779	.9808	.8478	.8916	.823
22	.78	.823	.8048	.9054	.78	.7888	
23	.7291	.7373	.7499	.7922		.7202	
24	.7922	.7291	.703	.7499	.7545	.1357	.6859
Max	1.2449	1.1361	1.1317	1.1706	1.1949	1.0288	4.2353
Min	.5243	.4588	.2401	.3932	.2458	.1187	.3772
Avg	.7726	.6963	.6844	.7456	.7031	.3905	.8215

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074015 / 33 KV S/STN. HATEDI

Feeder No / Name : 205 / AMBHODA FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.2883	.2915	.3109	.3395		.2915
2	.679	.2883	.3086	.3658	.3395		.3086
3	.7545	.3052	.3429	.3658	.3772		.3258
4	1.0562	.373	.5316	.567	.4527		.3601
5	1.3203	.4409	.6859	.7316	.679		.3772
6	1.5089	.763	.7545	.8413	.8299	.7461	.6516
7	1.358	.6443	.6001	.8048	.7468	.763	.703
8	1.2071	.5426	.6001	.695	.7545	.6443	.4973
9	.9808	.407	.4973	.5121	.5281	.4748	.463
10	.679	.373	.3772	.4024	.3772	.373	.3429
11	.8192	.3768	.4115	.3772	.2949	.2543	.3772
12	.3605	.3605	.3429	.3018	.2785	.2683	.4115
13	.3768	.3441	.3086	.2683	.2785	.2515	.3429
14	.3768	.3277	.3086	.0983	.2458		.3772
15	.1638	.2949	.2743	.1638	.2458		.3086
16	.2458	.3277	.3429	.3277	.2622		.4115
17	.5735	.3441	.4115	.3605	.4096	.4191	.3429
18	.4915	.3768	.3772	.3932	.4915	.4359	.2743
19	.5935	.5658	.5853	.5914	.6104	.583	.5144
20	.5935	.463	.5853	.5601	.5596	.5144	.4801
21	.407	.3944	.439	.4904	.407	.4115	.4115
22	.3391	.3772	.3658	.3772	.3391	.3429	
23	.3052	.3086	.2926	.3395		.3086	
24	.6036	.3052	.2915	.2926	.3395		.2915
Max	1.5089	.763	.7545	.8413	.8299	.763	.703
Min	.1638	.2883	.2743	.0983	.2458	.2515	.2743
Avg	.6832	.3997	.4303	.4391	.4429	.4527	.4029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074030 / 33KV PADALI

Feeder No / Name : 201 / 11KV PADALI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.2915	.2915	.1886	.1715	.1886	.1949
2	.3696	.2915	.2915	.1715	.1715	.1715	.1928
3	.3506	.2915	.2915	.1543	.1886	.1715	.1928
4	.3772	.3258	.3429	.1715	.2058	.1886	.1928
5	.4115	.3944	.4115	.1886	.2229	.2058	.2103
6	.5144	.5144	.5144		.2229	.2229	.2279
7	.6516	.6173	.7202			.2378	
8	.583	.6344	.5487				
9	.5544			.4801	.463	.439	
10				.4973	.5144	.4557	.631
11				.3944	.5144	.4961	.5609
12				.5316	.4458	.4908	.5258
13				.463	.4115		.5258
14				.463	.4115		.5258
15				.4458	.4287		.5258
16				.4458	.4801		.5609
18						.4557	
19	.1886	.2149	.1886	.2058	.1715	.2103	.2195
20	.1886	.2149	.2058	.2058	.2229	.2103	.2103
21	.1715	.197	.2058	.1886	.2058	.2103	.2103
22	.2058	.1886	.2058	.1886	.1886	.2103	.2012
23	.3086	.3086	.2058	.1886	.2229	.2103	.1715
24	.1524	.3086	.3086	.1886	.1886	.1886	.2058
Max	.6516	.6344	.7202	.5316	.5144	.4961	.631
Min	.1524	.1886	.1886	.1543	.1715	.1715	.1715
Avg	.3580	.3424	.3380	.3032	.3026	.2758	.3308

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074030 / 33KV PADALI

Feeder No / Name : 202 / 11KV DAHID AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.1886	.2149	.0343	.0343	.0343	.0351
2	.2401	.1886	.2149	.0343	.0343	.0343	.0351
3	.2401	.1886	.2172	.0343	.0343	.0343	.0351
4	.2743	.2401	.2507	.0343	.0343	.0343	.0354
5	.3086	.2743	.3045	.0343	.0343	.0343	.0354
6	.3429	.3429	.3582	.0343	.0343	.0343	.0351
7	.3429	.2743	.3403				
8	.3429	.3944	.3086				
9	.3086		.3429	.3086	.12	.4801	.3292
10				.3772	.1029	.4298	.2629
11				.3258	.0857	.394	
12				.3258	.3772	.4477	
13				.2572	.3601		
14				.2401			.2629
15				.2401			.2629
16				.2743	.3429		.2454
18	.0343					.2743	
19	.0343	.0358	.0343	.0343	.0343	.0351	.0343
20	.0343	.0358	.0343	.0351	.0343	.0351	.0354
21	.0343	.0358	.0343	.0343	.0343	.0351	.0351
22	.0343	.0358	.0343	.0343	.0343	.0351	.0354
23	.2401	.2507	.0343	.0343	.0343	.0366	.0362
24	.1829	.2401	.2507	.0343	.0343	.0343	.0351
Max	.3429	.3944	.3582	.3772	.3772	.4801	.3292
Min	.0343	.0358	.0343	.0343	.0343	.0343	.0343
Avg	.2022	.1947	.1983	.1381	.1000	.1437	.1051

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074030 / 33KV PADALI

Feeder No / Name : 204 / 11 KV DAHID GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0701						
5	.1267						
6						.1715	.1097
7	.1402						
8			.1448	.1543			
9			.1029				
10						.0686	
12		.0724	.0857				.0876
16		.0724	.0686	.0686			
18					.12		.1097
20		.1433			.1372		
23			.0857		.1029		.0732
24			.0716	.0686			.0701
Max	.1402	.1433	.1448	.1543	.1372	.1715	.1097
Min	.0701	.0724	.0686	.0686	.1029	.0686	.0701
Avg	.1123	.0960	.0932	.0972	.1200	.1201	.0901

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074030 / 33KV PADALI

Feeder No / Name : 205 / 11KV DEULGHAT GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5975	.5487	.543	.5316	.5316	.6535	.5975
2	.5914	.5487	.543	.5144	.5144	.5658	
3	.5914	.5316	.543	.4801	.5144	.5658	
4	.6283	.5487	.5792	.4801	.5487	.5487	
5	.6283	.5658	.5973	.5144	.5658	.5658	
6	.6653	.583	.6154	.5487	.6001	.5658	
7	.6283	.583	.6154	.5487	.5658	.6001	
8	.5914	.5487	.5487	.5144	.4973	.5487	
9	.5175	.4801	.5144	.5175	.4801	.4973	
10	.5144	.4973	.4973	.4854	.4801	.5068	.5544
11	.5316	.4887	.4973	.4854	.4287	.5068	.5487
12	.6173	.543	.463	.5304	.4458		.5975
13	.4973	.543	.4287	.5041	.4458		.5487
14	.4973	.543	.4287	.5041	.4458		.5228
15	.4973	.543	.4458	.5228	.4458		.5544
16	.4973	.543	.463	.5601	.4801		.5487
17	.5316	.5792	.5144	.5601	.5487	.6283	.5853
18	.5658	.6154	.5658	.5487	.6173	.6722	.5853
19	.6344	.6516	.6001	.7095	.583	.7468	.6219
20	.6516	.6697	.5658	.6348	.6516	.6722	.6348
21	.583	.6154	.5658	.6001	.6173	.6535	.6535
22	.5487	.5792	.5487	.6001	.6001	.6219	.6219
23	.5487	.5792	.5487	.5658		.5853	.5914
24	.5914	.5487	.543	.5316	.5316	.6001	.5914
Max	.6653	.6697	.6154	.7095	.6516	.7468	.6535
Min	.4973	.4801	.4287	.4801	.4287	.4973	.5228
Avg	.5728	.5616	.5323	.5414	.5278	.5950	.5849

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074030 / 33KV PADALI

Feeder No / Name : 206 / 11 KV PADALI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2587	.1886	.2229	.2058	.2229	.2401	.2587
2	.2218	.1886	.2229	.2058	.2229	.2229	.298
3	.2218	.2058	.2229	.1886	.2401	.2229	.2561
4	.2957	.2572	.2743	.2572	.2572	.2572	.2987
5	.3658	.3258	.3601	.3772	.2915	.3772	.3326
6	.5914	.5487	.5658	.583	.5658	.5487	.5959
7	.5175	.4287	.4458	.4973	.5144	.5144	.5083
8	.4435	.4115	.4115	.463	.4287	.3944	.4481
9	.2957	.3258	.3429	.3326	.3429	.2743	.3734
10	.2401	.2229	.3086	.2772	.2401	.2402	.2896
11	.1886	.2058	.2572	.2801	.1715	.2241	.2987
12	.1715	.2058	.2229	.2241	.1543	.2241	.2534
13	.1543	.2058	.2058	.2241	.1543		.2587
14	.1543	.2058	.2058	.2614	.2058		.2587
15	.1886	.2058	.2058	.2614	.2058		.2614
16	.1886	.2058	.2401	.2987	.2401		.2103
17	.2401	.2401	.3086	.2614	.2572	.2987	.2801
18	.2572	.2743	.3601	.3326	.3086	.4755	.3361
19	.4287	.4458	.3944	.4854	.4458	.5228	.439
20	.4287	.4458	.3772	.4938	.4115	.439	.3506
21	.3258	.3429	.3258	.3086	.3429	.3658	.3292
22	.2401	.2743	.3086	.2572	.2743	.2926	.2454
23	.2229	.2572	.2572	.2401	.2572	.2743	.2454
24	.2587	.2229	.2401	.2058	.2229	.2401	.2614
Max	.5914	.5487	.5658	.583	.5658	.5487	.5959
Min	.1543	.1886	.2058	.1886	.1543	.2229	.2103
Avg	.2875	.2851	.3036	.3134	.2908	.3325	.3203

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074047 / 33 /11 KV GANESH NAGAR

Feeder No / Name : 201 / 11 KV Market

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2346	1.4299	1.2003	1.1888	1.267	1.166	1.0974
2	1.166	1.4118	1.1145	1.134		1.1317	1.0974
3	1.166	1.3756	1.0802	1.134	1.1946	1.1317	1.0974
4	1.1317	1.3394	1.0631	1.0974	1.1584	1.0974	1.0974
5	1.1145	1.3032	1.0631	1.0974	1.1222	1.0631	1.0608
6	1.0802	1.267	1.0631	1.0974	1.1041	1.0631	1.0059
7	1.0288	1.1584	1.0288		1.1584	1.0631	1.0242
8	1.0802	1.3032	1.046	1.0791	1.1765	1.0631	.9145
9	1.046	1.2489	1.0288	.9877	1.2127	.9774	.9511
10	1.1488	.9774	1.0288	.9694	1.1584	1.046	1.0242
11	1.2489	1.0631	1.0608	.9412	1.2803	1.0974	1.1041
12	1.267	1.0974	1.0608	.905	1.2803	1.134	1.086
13	1.2127	1.1317	.9511	1.0317	1.166	1.1157	1.086
14	1.1946	1.1831	.9877	1.0317	1.1317	1.0791	1.086
15	1.267	1.2003	1.0059	1.1403	1.1488	1.0974	1.0679
16	1.3756	1.2346	1.0425	1.1403	1.2003	1.1706	1.086
17	1.3756	1.2003	1.0974	1.1584	1.1831	1.1888	1.086
18	1.3032	1.2346	1.1706	1.1765	1.1317	1.2071	1.086
19	1.3032		1.1888	1.3032	1.2003	1.2986	1.1222
20	1.4661		1.2437	1.3213	1.2517	1.2986	1.1403
21	1.3032	1.2517		1.267	1.2003	1.1888	1.1403
22	1.3575	1.2689	1.2071	1.2851	1.166	1.1523	1.1584
23	1.3937	1.2689	1.2437	1.3213	1.1831	1.134	1.1403
24	1.2517		1.2174	1.1888	1.3032	1.2003	1.134
Max	1.4661	1.4299	1.2437	1.3213	1.3032	1.2986	1.1584
Min	1.0288	.9774	.9511	.905	1.1041	.9774	.9145
Avg	1.2299	1.2357	1.0954	1.1303	1.1904	1.1319	1.0789

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074047 / 33 /11 KV GANESH NAGAR

Feeder No / Name : 202 / 11 KV Ganesh Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4403	1.5746	1.2689	1.1888	1.448	1.2517	1.0974
2	1.3717	1.2851	1.2003	1.1888	1.4299	1.2174	1.0974
3	1.2689	1.267	1.1317	1.0974	1.3756	1.1317	1.0974
4	1.2346	1.267	1.0631	1.0974	1.3032	1.0974	1.0608
5	1.1831	1.2489	1.046	1.0974	1.267	1.0802	1.0059
6	1.0631	1.1946	.9945	1.0608	1.1222	1.0802	1.0059
7	1.046	1.1041	.9602	1.0242	1.1222	1.0631	1.0242
8	.9945	1.1765	.9259	1.0608	1.086	1.0631	1.0608
9	.9945	1.086	.9602	.9511	1.0498	.9774	.8779
10	1.0631	.9593	.9602	1.0425	1.0498	.9602	.9877
11	1.2308	1.046	1.0608	1.086	.9694	1.0974	.9955
12	1.1765	1.1317	1.0608	1.1222	1.0608	1.0608	1.0136
13	1.2851	1.2346	1.0242	1.1946	1.0288	1.0974	1.0679
14	1.3937	1.3203	1.0425	1.2127	1.0288	1.0791	1.0679
15	1.4661	1.3032	1.0425	1.267	1.1831	1.1157	1.0498
16	1.4661	1.3032	1.0608	1.267	1.2003	1.134	1.0679
17	1.3575	1.2689	1.0608	1.2489	1.1488	1.1888	1.0679
18	1.1584	1.1145	1.0608	1.1222	1.1317	1.1523	1.1946
19	1.267	1.166	1.2437	1.3394	1.2689	1.2803	1.2127
20	1.5565	1.2517	1.3352	1.3937	1.3717	1.3717	1.2489
21	1.4842	1.3375	1.3169	1.4842	1.3889	1.3169	1.2851
22	1.5927	1.3717	1.3169		1.3889	1.2803	1.3032
23	1.6289	1.3717	1.3352	1.5023	1.3717	1.2437	1.267
24	1.4575	1.6289	1.3032	1.2803	1.4842	1.3375	1.134
Max	1.6289	1.6289	1.3352	1.5023	1.4842	1.3717	1.3032
Min	.9945	.9593	.9259	.9511	.9694	.9602	.8779
Avg	1.2992	1.2505	1.1156	1.1882	1.2200	1.1533	1.0955

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074047 / 33 /11 KV GANESH NAGAR

Feeder No / Name : 203 / 11 KV JAISTAMB-II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3944	.4344	.3772	.3658	.3801	.3601	.3658
2	.3772	.3982	.3772	.3658	.362	.3601	.3658
3	.3772	.3982	.3429	.3658	.3439	.3429	.3658
4	.3601	.362	.3429	.3658	.3258	.3429	.3658
5		.362	.3258	.3658	.362	.3429	.3658
6	.3601	.362	.3258	.3658	.3801	.3429	.3658
7	.3601	.3439	.3086	.3658	.362	.3429	.3658
8	.2915	.3982	.2915	.2743	.3258	.3429	.3475
9	.2743	.3734	.3429	.2561	.3258	.3258	.3292
10	.3429	.3439	.2915	.3292	.3439	.3086	.3292
11	.362	.3429	.3292	.362	.3841	.3292	.3439
12	.362	.3429	.3292	.362	.3841	.3292	.3077
13	.3801	.3429	.3109	.362	.3429	.3292	.3258
14	.3801	.3772	.3292	.362	.3086	.3292	.362
15	.3982	.3772	.3475	.362	.3086	.3292	.3801
16	.3982	.3429	.3658	.362	.3086	.3292	.362
17	.3982	.3429	.3292	.362	.2915	.3292	.3439
18	.2353	.3258	.3292	.3258	.3086	.3292	.362
19	.362	.3601	.4024	.3982	.3772	.3658	.3801
20	.4525	.3944	.4207	.4163	.4115	.439	.3982
21	.4344	.4115	.439	.4344	.4287	.4207	.3982
22	.4706	.4115	.439	.4344	.4287	.1646	.4163
23	.4706	.3944	.4207	.4163	.4115	.3841	.4163
24	.3944	.4525	.3772	.3841	.4163	.3772	.3658
Max	.4706	.4525	.439	.4344	.4287	.439	.4163
Min	.2353	.3258	.2915	.2561	.2915	.1646	.3077
Avg	.3755	.3748	.3540	.3652	.3593	.3415	.3637

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074047 / 33 /11 KV GANESH NAGAR

Feeder No / Name : 204 / 11 kv Hanwatkhed Feeder
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	01-JUN-18
HR	Load (MW)
24	.061
Max	.061
Min	.061
Avg	.061

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074047 / 33 /11 KV GANESH NAGAR

Feeder No / Name : 205 / 11 kv Balaji Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1448	.1029	.1463	.1448	.12	.1097
2	.1372	.1267	.1029	.1463	.1448	.1029	.1097
3	.1372	.1267	.1029	.1463	.1267	.1029	.1097
4	.12	.1267	.0857	.1097	.1267	.1029	.1097
5	.1029	.1267	.0857	.1097	.1448	.1029	.1097
6	.1029	.1267	.0857	.0914	.1448	.0857	.128
7	.1029	.1267	.1029	.0732	.1267	.0857	.128
8	.1029	.1029	.12	.0732	.1086	.0857	.1097
9	.1029	.1267	.12	.0732	.1086	.0857	.1097
10	.12	.1448	.1029	.0914	.1267	.12	.128
11	.1086	.12	.1097	.1267	.1829	.128	.1267
12	.0905	.12	.128	.1267	.1646	.128	.1267
13	.1448	.12	.128	.1267	.1543	.128	.1267
14	.1629	.1372	.1463	.1448	.1372	.128	.1267
15	.181	.1543	.1646	.1629	.1372	.1463	.1267
16	.2172	.1543	.1646	.181	.1543	.128	.1267
17	.181	.1543	.1646	.181	.1543	.1646	.1267
18	.1629	.1543	.1463	.1629	.1543	.1463	.1267
19	.1886	.12	.1646	.1629	.1372	.1646	.1267
20	.1715	.12	.1646	.1629	.1543	.1646	.1372
21	.1543	.1372	.1463	.1543	.1372	.1829	.1372
22	.1372	.1372	.1463	.1543	.1372	.1646	.1372
23	.1372	.12	.1463	.1448	.1372	.1463	.1448
24	.1543	.1448	.12	.1463	.1448	.1372	.1097
Max	.2172	.1543	.1646	.181	.1829	.1829	.1448
Min	.0905	.1029	.0857	.0732	.1086	.0857	.1097
Avg	.1399	.1322	.1272	.1333	.1413	.1272	.1233

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074074 / 33KV Sakhali Sub Station

Feeder No / Name : 201 / 11 KV Sakhali GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173		.6173	.6173	.6173	.6173	.6173
2	.6173		.6173	.6173	.6173	.6173	.6173
3	.6173		.6173	.6173	.6173	.6173	.6173
4	.6516		.7888	.6516	.6516	.6173	
5	.6859		.9602	.7202	.7202	.7545	.8573
6	.9945	1.0631	1.1317	1.0802	1.0631	1.1317	1.166
7	.8916	.8573	.9602	1.0288	1.0631	1.1317	1.0974
8	.8402	.823	.8573	.8916	.823	.9945	.9259
9	.703	.7545	.7888	.7888	.583	.8573	.7888
10	.6173	.6859	.583	.6173		.6859	.6516
11	.583	.6516	.5487	.5487		.5487	.5144
12	.583	.583		.5144		.4801	.4801
13	.5487	.583		.5144		.4801	.4801
14	.6173	.6173		.5487		.5487	.5144
15	.6173	.6173		.4801		.583	.583
16	.6173	.6173		.583	.7202	.6516	.6173
17	.6516	.823		.6859	.7888	.6859	
18	.8573	.8916	1.0288	.7545	.8573	.8573	
19	1.0288	1.0288	1.0974	.9602	1.0288	.9945	.9945
20	1.0974	.9945	1.0631	1.0631	1.1317	1.0974	1.0974
21	.7202	.823	.9945	.8573	.8573	.8573	.823
22	.7202	.7202	.823	.7202	.7545	.6859	.7202
23	.6516	.6516	.6516	.6859	.6859	.6173	.6516
24		.6516	.6173	.6516	.6516	.6173	.6173
Max	1.0974	1.0631	1.1317	1.0802	1.1317	1.1317	1.166
Min	.5487	.583	.5487	.4801	.583	.4801	.4801
Avg	.7187	.7599	.8192	.7166	.7907	.7387	.7349

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074074 / 33KV Sakhali Sub Station

Feeder No / Name : 202 / Sakhali Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343		.0343	.2401	.1372	.1029	.1029
2	.0343		.0343	.2401	.1372	.1029	.1029
3	.0343		.0343	.2572	.1372	.1029	.1029
4	.0343		.0343	.2572	.1372	.1029	.1715
5	.0343		.0343	.2572	.1715	.1372	.2743
6	.0343		.0343	.3601	.2743	.2743	.3429
7	.0343		.0343	.3601	.4115	.3429	.3772
8				.3772	.3086	.3429	.3429
9	.1029	.1029	.3086				
10	.3086	.2058	.1715				
11	.3772	.2058					
12	.5144	.2743					
13	.2058	.2401					
14	.2058	.1715					
15	.1715	.2058					
16	.2743	.2401					
19	.0343	.0343	.0343	.0686	.0343	.0343	.0343
20	.0343	.0343		.0343	.0343	.0343	.0343
21	.0343	.0343	.0343	.0343	.0343	.0343	.0343
22	.0343	.0343	.0343	.0343	.0343	.0343	.0343
23	.0343	.0343	.2401	.1029	.1029	.1372	.1029
24	.1829	.0343	.0343	.2401	.1372	.1029	.1029
Max	.5144	.2743	.3086	.3772	.4115	.3429	.3772
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.1312	.1323	.0784	.2046	.1494	.1347	.1543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074074 / 33KV Sakhali Sub Station

Feeder No / Name : 203 / SHIRPUR AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***		.3086	.0686	.0686	.0686	.0686
2	.3429		.3086	.0686	.0686	.0686	.0747
3	.3086	.3086	.3086	.0686	.0686	.0686	.0686
4	.3429	.3086	.3429	.0686	.0686	.0686	.0686
5		.3086	.4458	.0686	.0686	.0686	.0686
6	.1886	.4115	.5144	.1029	.1029	.1029	.0686
7	.1886	.5144	.6173	.1029	.1029	.1029	.0686
8	.2915	.5487	.6173				
9				.3429	.4458	.3772	.4115
10				.5144	.4115	.4115	.4801
11				.5144	.4801	.4801	.5144
12				.4801	.4801	.4458	.4801
13				.3429	.4801	.3429	.3772
14				.2743	.4458	.1715	.4115
15				.3772	.4458	.4854	.4115
16				.4801	.4458	.3772	.4458
19	.1029	.1029	.1029	.1029	.1029	.1029	.1029
20	.1029	.1029	.1029	.1029	.1029	.0686	.0686
21	.1029	.0686	.1029	.1029	.1029	.0686	.0686
22	.1029	.0686		.1029	.0857	.0686	
23	.3086	.3086	.0686	.1029	.0686	.0686	.0686
24	.1524	.3086	.3086	.0686	.0686	.0686	.0686
Max	72.2223	.5487	.6173	.5144	.4801	.4854	.5144
Min	.1029	.0686	.0686	.0686	.0686	.0686	.0686
Avg	5.7506	.2801	.3192	.2123	.2245	.1946	.2198

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074085 / Bhadola

Feeder No / Name : 201 / Bhadola gaothan

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.3018	.2926	.2926	.3018	.2987	.3018
2	.3018	.3018	.2926	.2926	.3018	.2926	.3018
3	.3021	.3018	.2926	.2926	.3018	.2987	.3018
4	.3018	.3018	.3292	.2743	.3018	.2987	.3018
5	.3398	.3395	.3658	.3224	.3018	.3361	.3772
6	.4338	.4338	.4572	.4656	.4715	.4108	.5281
7	.5287	.4904	.4938	.4298	.4904	.5041	.4904
8	.547	.5121	.5228	.4119	.5287	.5041	.4338
9	.5658		.567	.4119	.5093	.4668	.4715
10	.415		.3761	.4338	.4024	.3961	.3761
11	.3395		.4119	.4527	.3109	.4338	.3403
12	.3961		.3403	.3395	.3292	.3584	.3582
13	.3961		.3582	.3395	.3475	.3395	.3761
14	.3776		.2149	.3587	.2926		.3224
15	.3961		.2149	.3395	.2846	.3961	.3045
16	.3961	.4755	.2507	.3395	.3292	.4527	.3045
17	.3961	.4207	.3224	.3772	.3658	.4715	.3224
18	.4338	.4755	.394	.3772	.4207	.4904	.3403
19	.5664	.439	.4298	.4338	.4024	.4904	.3582
20	.4338	.4207	.4477	.4527	.4024	.415	.3761
21	.415	.3658	.4119	.3961	.3841	.3584	.3761
22	.3584	.3475	.3582	.3018	.3547	.3206	.3403
23	.3395	.3109	.3292	.3018	.3361	.3018	.3224
24	.3021	.3018	.2987	.2926	.3018	.2926	.3018
Max	.5664	.5121	.567	.4656	.5287	.5041	.5281
Min	.3018	.3018	.2149	.2743	.2846	.2926	.3018
Avg	.3993	.3847	.3655	.3638	.3656	.3882	.3595

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074085 / Bhadola

Feeder No / Name : 202 / Bhadola Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1097	.0514	.0566	.0747	.0566
2	.132		.1097	.0514	.0566	.0747	.0566
3	.1509		.128	.0514	.0566	.0747	.0566
4	.132		.1463	.0514	.0566	.0747	
5	.132	.132	.1494	.0514	.0754	.0747	
6	.2452	.1888	.1829	.0686	.0754	.0747	.0754
7	.3018	.2829	.2378	.0686	.0566	.0747	.0754
8	.3395	.2195	.2561	.0686	.811		.0566
9	.132		.0914	.0686	.0943	.1646	.132
10	.0566		.0857	.1886	.1097	.2263	.1052
11	.0566		.0343	.2075	.1097	.2075	.1052
12	.0377		.0514	.2452	.1097	.1698	.1753
13	.0377		.0343	.2075	.128	.1698	.1227
14	.0377		.0514		.1646	.1886	.1227
15	.0377		.0514	.1886	.1646	.1886	.1402
16	.0566		.0514	.2075	.0549	.2075	.1052
17	.0566		.0514	.0566	.0732	.0566	.0876
18	.0566		.0514	.0566	.0914	.0566	.0701
19	.0943	.0549	.0686	.0566	.0732	.0754	.0701
20	.0754	.056	.0686	.0754	.0732	.0754	.0701
21	.0566	.0549	.0514	.0754	.0914	.0754	.0857
22	.0566	.0549	.0514	.0566		.0566	.0686
23	.132	.0732	.0514	.0566	.0747	.0566	.0686
24	.132	.132	.0914	.0514	.0566	.0747	.0566
Max	.3395	.2829	.2561	.2452	.811	.2263	.1753
Min	.0377	.0549	.0343	.0514	.0549	.0566	.0566
Avg	.1107	.1249	.0940	.0983	.118	.1119	.0892

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074089 / Maintenance Unit Sub-station

Feeder No / Name : 200 / Station Transformer

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.0857
Max	.0857
Min	.0857
Avg	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074089 / Maintenance Unit Sub-station

Feeder No / Name : 201 / Shivshankar Nagar SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2826	1.2003	1.2696	.985	1.0374	.9945	.985
2	1.226	1.1831	1.1949	.985	.9431	.9602	.985
3	1.1317	1.1145	1.1949	1.0164	.9431	.9259	.985
4	1.1883	1.0288	1.1576	1.0029	1.0374	.9259	1.0387
5	1.226	.9945	1.1203	1.0349	1.0374	.9431	1.0745
6	1.1506	.9945	1.0829	1.0719	1.094	.9774	1.0745
7	1.1145	.9774	1.0269	1.0387	1.226	1.0288	1.0924
8	1.046	.9602	1.1203	.9671	1.1694	1.0117	1.0924
9	1.0288	1.0456	1.0029	.9808	.9945		.9431
10	.9774	1.0456	.9313	.9431	.9602		.9259
11	.9259	1.0269	.8954	.7907	.9431		.9259
12	.9088	.9896	.8417	.9619	.9431		.9431
13	.9259	1.0082	.8596	1.0374	.9431		.9259
14	1.0631	1.0456	.8954	1.0374	.9088	1.0566	.8916
15	1.0631	1.0829	.8954	.9431	.9259	.985	.8916
16	1.0631	1.1389	.8954	.9431	.1372	.8954	.8916
17	1.0288	1.0829	.9313	.9709	.1543	.9313	.8745
18	1.0288	1.0456	.9671	1.0269	1.0117	1.0029	.8745
19	1.0802	1.1203	1.0029	1.0829	1.0117	1.0208	.8916
20	1.166	1.1576	1.0387	1.2136	1.0288	1.0745	.8916
21	1.2346	1.1576	1.0745	1.2696	1.0288	1.1104	.9259
22	1.286	1.1949	1.1641	1.2826	1.046	1.1104	.9259
23	1.2003	1.2696	1.1641	1.226	1.0288	.985	.9259
24	1.358	1.2003	1.307	1.1458	1.1506	.9945	.985
Max	1.358	1.2696	1.307	1.2826	1.226	1.1104	1.0924
Min	.9088	.9602	.8417	.7907	.1372	.8954	.8745
Avg	1.1127	1.0861	1.0431	1.0399	.9460	.9965	.9567

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074089 / Maintenance Unit Sub-station

Feeder No / Name : 202 / Bhagirath SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.1029	.1109	.1109	.0934	.1029	.1075
2	.0934	.0857	.1109	.1109	.0934	.1029	.1075
3	.0934	.0857	.1109	.1075	.0934	.1029	.1075
4		.0857	.1109	.1109	.0934	.1029	.1075
5	.112		.1109	.1109	.0934	.1029	.1075
6	.1307	.1029	.1109	.1433	.0934		.1075
7	.1029	.12	.1109	.1791	.0934	.12	.1075
8	.1029	.12	.1109	.0924	.112	.12	.1075
9	.12	.1294	.1075	.112	.1029	.1848	.1543
10	.1372	.1294	.1254	.112	.1029	.2328	.1543
11	.1372	.1294	.1433	.1132	.12	.2328	.1543
12	.1543	.1294	.1433	.112	.1543	.2328	.1372
13	.1372	.1294	.1433	.1307	.1543	.1478	.1372
14	.1543	.1663	.1433	.1307	.1886	.1433	.1372
15	.1543	.2033	.1433	.1307	.1886	.1254	.12
16	.1372	.2218	.1848	.1307	.1715	.2507	.12
17	.1543	.1848	.1791	.1063	.2058	.2507	.12
18	.1543	.1294	.1478	.1063	.2058	.2507	.12
19	.1543	.1478	.1478	.112	.2058	.2149	.12
20	.1372	.1663	.1848	.124	.1715	.2149	.12
21	.1372	.1478	.1848	.124	.1715	.2149	.1029
22	.1372	.1294	.1109	.112	.1543	.1075	.1029
23	.12	.1109	.1109	.112	.1029	.1075	.1029
24	.112	.1029	.1109	.1109	.112	.1029	.1075
Max	.1543	.2218	.1848	.1791	.2058	.2507	.1543
Min	.0934	.0857	.1075	.0924	.0934	.1029	.1029
Avg	.1290	.1331	.1333	.1186	.1366	.1639	.1196

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074089 / Maintenance Unit Sub-station

Feeder No / Name : 205 / SAV AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0772	.1029	.0914	.2686	.2315	.4115	.3224
2	.0772	.0914	.0914	.2865	.2315	.4458	.3224
3	.0772	.0914	.0914	.2865	.2372	.463	.3582
4	.0926	.0914	.1067	.3224	.3086	.4801	.4298
5	.108	.0914	.1067	3.349	.3858	.5144	.5014
6	.108	.0914	.1067	.3582	.463	.5144	.5373
7		.0914	.1067	.4119	.5401	.5316	.6268
8		.0914	.0914	.3704	.6173	.5316	.6984
9		.3353		.0926	.1219	.1254	.1372
10		.3353		.0926	.12	.1254	.1372
11		.3658		.0949	.1029	.1254	.1067
12		.3048	.5731	.0926	.0762	.1109	.1067
13		.3048		.0926	.0762	.1075	.1067
14		.3048		.0926	.0762	.1075	.1067
15		.2743	.5014	.0926	.0762	.1075	.1029
16		.2743	.4656	.0926	.0914	.1075	.0914
17	.0857	.1067	.1109	.1107	.1067	.1075	.0914
18	.0857	.0914	.1109	.1107	.1067	.1075	.1029
19	.1029	.0914	.1109	.1107	.1067	.1075	.1029
20	.1029	.0914	.1109	.1107	.0914	.1075	.1029
21	.12	.0914	.1109	.1107	.1029	.1075	.1029
22	.12	.0914	.0924	.108	.1029	.2865	.1029
23	.12	.0914	.2686	.2469	.4115	.2865	.3429
24	.0926	.1029	.0914	.2772	.2469	.4115	.2865
Max	.12	.3658	.5731	3.349	.6173	.5316	.6984
Min	.0772	.0914	.0914	.0926	.0762	.1075	.0914
Avg	.0979	.1667	.1758	.3159	.2097	.2638	.2470

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074089 / Maintenance Unit Sub-station

Feeder No / Name : 206 / Yelgaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1581	.2058	.1802	.1791	.1581	.1715	.1791
2	.1581	.1715	.1966	.1791	.1581	.1715	.1734
3	.1581	.1715	.1802	.2149	.1898	.1886	.2149
4	.1898	.1886	.1966	.2149	.1898	.1886	.2218
5	.2214	.2058	.213	.2507	.2214	.2058	.2507
6	.253	.2401	.2294	.2507	.2372	.2058	.2507
7	.2401	.2401	.2294	.2686	.253	.2058	.2686
8	.2058	.2401	.213	.2507	.2214	.2058	.2686
9	.2058	.1966		.2056	.2058	.1791	.1715
10	.1715	.1802		.1898	.2229	.1791	.1715
11	.1715	.1638	.1254	.1898	.2058	.1612	.2058
12	.1543	.1638		.1581	.2229	.1612	.2058
13	.1715	.1475	.1433	.1581	.2058	.1791	.2058
14	.2058	.1475	.1433	.1739	.1543	.197	
15	.2229	.1475	.1848	.1739	.1543	.1791	.2058
16	.2058	.1638	.2033	.1898	.1715	.1791	.2058
17	.1715	.1966	.2033	.2012	.1715	.1791	.2058
18	.1715	.213	.2149	.1898	.1886	.2149	.2058
19	.1715	.2294	.2218	.218	.1715	.2507	.2058
20	.1715	.2458	.2328	.2515	.1715	.2507	.2058
21	.1886	.213	.2587	.2515	.2058	.2507	.2058
22	.2058	.1966	.2587	.2372	.2058	.1791	.1715
23	.2058	.1966	.2149	.2214	.1715	.1791	.1715
24	.1898	.2058	.1966	.197	.1898	.1715	.1791
Max	.253	.2458	.2587	.2686	.253	.2507	.2686
Min	.1543	.1475	.1254	.1581	.1543	.1612	.1715
Avg	.1904	.1946	.2019	.2090	.1937	.1931	.2066

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074093 / Sagwan Sub-station

Feeder No / Name : 200 / Station Transformer
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.1595
Max	.1595
Min	.1595
Avg	.1595

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074093 / Sagwan Sub-station

Feeder No / Name : 201 / 11 kv Indira Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4938			.4163	.3898
2	.4706			.3982	.3898
3	.4755			.3982	.3898
4	.4572			.3982	.3898
5	.439			.3982	.3898
6	.4344			.3801	.3898
7	.4344			.4344	.4252
8	.4207			.362	.3898
9	.3982			.3544	.3258
10	.4207			.3189	.2896
11	.4344				.2896
12	.4298			.3189	.3439
13	.5316			.2835	.3439
14	.4607			.3012	.3258
15	.4607			.3189	.3258
16	.4961			.3189	.3258
17	.4961			.3366	.2896
18	.4961				.2896
19	.4961		.3258	.3898	.3258
20	.4961		.4525	.4252	.362
21	.4607		.4706	.4252	.3982
22	.4961			.4252	.4344
23	.4961			.3898	.4163
24	.4887	.4607		.4344	.3898
Max	.5316	.4607	.4706	.4344	.4344
Min	.3982	.4607	.3258	.2835	.2896
Avg	.4660	.4607	.4163	.3739	.3596

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074093 / Sagwan Sub-station

Feeder No / Name : 202 / 11 kv Ram Nagar Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549		.0543	.0354	.0362	.0543	.0532
2	.0549	.0532	.0543	.0354	.0543	.0543	.0532
3	.0366	.0532	.0543	.0354	.0543	.0543	.0366
4	.0543	.0549	.0543	.0532	.0543	.0543	.0354
5	.0543	.0532	.0543	.0532	.0724	.0543	.0532
6	.0537	.0532	.0543	.0532	.0724	.0724	.0709
7	.0537	.0532	.0543	.0532		.0543	.0709
8	.0543	.0532	.0362	.0709	.0543	.0543	.0532
9	.0366	.0532	.0354	.0543	.0543	.0532	.0543
10	.0366		.0532	.0362	.0362	.0709	.0543
11	.0537		.0549	.0362	.0362		.0543
12	.0543		.0354	.0543	.0362	.0354	.0543
13	.0532		.0354	.0543	.0543	.0532	.0543
14	.0532		.0354	.0543	.0543	.0532	.0362
15	.0532	.0724	.0354	.0724	.0543	.0532	.0362
16	.0532	.0543	.0354	.0543	.0362	.0532	.0362
17	.0532	.0543	.4961	.0701	.0362	.0532	.0362
18	.0532	.0543	.0354	.0701	.0543	.0532	.0362
19	.0532	.0543	.0354	.0543	.0724	.0532	.0362
20	.0532	.0724	.0354	.0543	.0724	.0532	.0362
21	.0532	.0543	.0354	.0543	.0543	.0532	.0543
22	.0532	.0543	.0532	.0543	.0543	.0532	.0543
23	.0532	.0543	.0532	.0362		.0532	.0543
24	.0537	.0532	.0543	.0354	.0362	.0543	.0532
Max	.0549	.0724	.4961	.0724	.0724	.0724	.0709
Min	.0366	.0532	.0354	.0354	.0362	.0354	.0354
Avg	.0515	.0559	.0640	.0515	.0518	.0544	.0487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074093 / Sagwan Sub-station

Feeder No / Name : 203 / 11 KV SAGWAN GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5068		.4887	.4607	.5068	.5068	.4607
2	.4887	.5316	.4525	.4607	.5068	.5068	.4607
3	.4938	.5316	.4706	.4607	.543	.5068	.5316
4	.543	.5316	.4706	.4607	.5792	.5068	.6379
5	.591	.5316	.5068	.5316	.6154	.5068	.6733
6	.7522	.5316	.6154	.6379	.6878	.724	.6733
7	.7522	.6024	.6516	.7087	.724	.724	.6733
8	.724	.6379	.6154	.6379	.6516	.0857	.6024
9	.7059	.567	.5316	.5792	.6335	.567	.543
10	.5853	.4607	.4961	.4887	.5068	.6024	.4525
11		.4252	.4252	.4525	.5068		.5068
12		.3898	.443	.3982	.4525	.4252	.4887
13	.3544	.4344	.3898	.4344	.4344	.3898	.4706
14	.3189	.4887	.4252	.4344	.4525	.4252	.4525
15	.2835	.4706	.443	.4344	.4525	.4252	.4887
16	.2835	.4706	.4961	.4706	.3982	.443	.5068
17	.5316	.3077	.4961	.4887	.5068	.4607	.4525
18	.6379	.543	.567	.5611	.5792	.567	.5068
19	.7087	.724	.567	.6335	.5792	.6379	.5792
20	.7442	.6516	.6379	.5973	.724	.6379	.5792
21	.7087	.6154	.567	.5792	.6516	.567	.543
22	.6379	.5068	.5316	.543	.5792	.5316	.5068
23	.6024	.5068	.5316	.5068		.4607	.4887
24	.5611	.5493	.4887	.4961	.4706	.543	.4607
Max	.7522	.724	.6516	.7087	.724	.724	.6733
Min	.2835	.3077	.3898	.3982	.3982	.0857	.4525
Avg	.5689	.5222	.5129	.5190	.5540	.5109	.5308

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074093 / Sagwan Sub-station

Feeder No / Name : 205 / JAMBHRUN AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0648		.0514	.0177	.0181	.2401	.0354
2	.0648	.0709	.0514	.0177	.0181	.2743	.0354
3	.064	.0886	.0514	.0177	.0181	.2743	.0354
4	.08	.1063	.0514	.0177	.0362	.2743	.0354
5	.08	.1097	.0686	.0354	.0362	.2743	.0354
6	.096	.1063	.0857	.0354	.0362	.3086	.0354
7	.1265	.124	.0514	.0177	.0362		.0354
8	.128	.1063	.0343	.0354	.0362	.0857	.0366
9	.0164		.0177	.0724	.0514	.124	.0514
10	.0164		.0177	.0857	.1715	.124	.1029
11				.1543	.12		.1029
12			.0177		.1029	.124	.1086
13			.0177		.12	.124	.0857
14			.0177		.1267	.1063	.0686
15			.0177		.12	.124	.12
16			.0177		.1029	.1063	.12
17	.0354	.0686	.0177	.0362	.0171	.0354	.0181
18	.0354	.0686	.0177	.0181	.0171	.0354	.0362
19	.0354	.0362	.0354	.0362	.0171	.0354	.0362
20	.0354	.0343	.0354	.0181	.0171	.0354	.0181
21	.0177	.0343	.0177	.0181	.0343	.0354	.0181
22	.0177	.0171	.0177	.0181	.0343	.0354	.0181
23	.0709	.0514	.0177	.0181		.0354	.0181
24	.1829	.0709	.0514	.0177	.0181	.0171	.0354
Max	.1829	.124	.0857	.1543	.1715	.3086	.12
Min	.0164	.0171	.0177	.0177	.0171	.0171	.0181
Avg	.0649	.0729	.0339	.0362	.0568	.1286	.0518

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074093 / Sagwan Sub-station

Feeder No / Name : 206 / 11 kv Ajijpur AG Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0995		.1029	.9214	.9593	.5144	.9214
2	.0995	.1417	.1029	.8505	1.0136	.583	.9214
3	.0838	.1417	.1029	.8505	1.1041	.583	.9214
4	.1147	.1417	.12	.8505	1.1403	.583	1.0277
5	.1147	.1417	.12	.9214	1.1946	.6173	1.134
6	.1475	.1417	.1372	1.0631	1.3575	1.1145	1.3466
7	.1943	.1595	.1543	1.2403	1.3575	1.3032	1.382
8	.1966	.1417	.1715	1.0631	1.3213	1.166	1.4175
9	1.1203	.8859	.9922	.1543	.1543	.1417	.12
10	1.4548	.9922	1.0631	.1543	.12	.124	.1029
11	1.5023	.9568	1.0631	.12	.1267		.1543
12	1.4251	.9214	1.134	.12	.12	.1063	.1372
13	1.4175	.8573	1.0631	.12	.1267	.1063	.1372
14	.4001	.9431	1.134	.1372	.1629	.124	.12
15	1.2048	.9431	.9922	.1372	.1543	.1417	.12
16	1.2048	.9431	.9922	.12	.12	.1417	.1715
17	.1417	.1372	.124	.1448	.12	.1417	.1267
18	.1417	.1543	.124	.2172	.1543	.1417	.181
19	.1417	.1372	.1417	.2353	.2229	.1772	.1991
20	.1417	.12	.1417	.2172	.1715	.1772	.181
21	.1417	.12	.124	.181	.1715	.1417	.1629
22	.1417	.12	.1063	.1629	.1715	.1417	.1629
23	.1417	.1029	.8505	.9412		.7619	.905
24		.1417	.1029	.9214	.9593	.6859	.8505
Max	1.5023	.9922	1.134	1.2403	1.3575	1.3032	1.4175
Min	.0838	.1029	.1029	.12	.12	.1063	.1029
Avg	.5118	.4124	.4650	.4935	.5437	.4226	.5377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 077007 / 132/33kv Substn. Buldana

Feeder No / Name : 400 / Station Transformer
Feeder KV- 33 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.1372
Max	.1372
Min	.1372
Avg	.1372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 077007 / 132/33kv Substn. Buldana

Feeder No / Name : 402 / 33 KV Buldhana
Feeder KV- 33 / INCOMINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-JUN-18
HR	Load (MW)
24	7.4589
Max	7.4589
Min	7.4589
Avg	7.4589

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 077007 / 132/33kv Substn. Buldana

Feeder No / Name : 403 / 33 KV PADALI

PURELY LIS FEEDERS

Feeder KV- 33 / INCOMING

DATE	01-JUN-18
HR	Load (MW)
24	7.4589
Max	7.4589
Min	7.4589
Avg	7.4589

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 077007 / 132/33kv Substn. Buldana

Feeder No / Name : 404 / 33 KV DONGARSHIVALI

PURELY LIS FEEDERS

Feeder KV- 33 / INCOMING

DATE	01-JUN-18
HR	Load (MW)
24	7.4589
Max	7.4589
Min	7.4589
Avg	7.4589

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 077007 / 132/33kv Substn. Buldana

Feeder No / Name : 405 / 33 KV GANESH NAGAR

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	01-JUN-18
HR	Load (MW)
24	7.6132
Max	7.6132
Min	7.6132
Avg	7.6132

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 077007 / 132/33kv Substn. Buldana

Feeder No / Name : 406 / 33kv Yelgaon WW NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 33 / OUTGOING UTILITY

DATE	01-JUN-18
HR	Load (MW)
24	6.9445
Max	6.9445
Min	6.9445
Avg	6.9445

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 077007 / 132/33kv Substn. Buldana

Feeder No / Name : 407 / 33 KV Maintenance Unit

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	01-JUN-18
HR	Load (MW)
24	7.4589
Max	7.4589
Min	7.4589
Avg	7.4589

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 077007 / 132/33kv Substn. Buldana

Feeder No / Name : 409 / 33 Kv Raipur

PURELY LIS FEEDERS

Feeder KV- 33 / INCOMING

DATE	01-JUN-18
HR	Load (MW)
24	7.4589
Max	7.4589
Min	7.4589
Avg	7.4589

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074001 / 33/11 KV AMDAPUR

Feeder No / Name : 200 / Station Transformer

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.1905
Max	.1905
Min	.1905
Avg	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074001 / 33/11 KV AMDAPUR

Feeder No / Name : 201 / 11 KV AMDAPUR AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
1	.3429
2	.3429
3	.3429
4	.3429
5	.4287
16	.3048
24	.3048
Max	.4287
Min	.3048
Avg	.3443

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074001 / 33/11 KV AMDAPUR

Feeder No / Name : 202 / 11 KV MANGRUL AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
1	.1715
2	.1715
3	.1715
4	.1715
5	.1715
6	.1715
7	.1715
8	.1715
23	.1715
24	.1905
Max	.1905
Min	.1715
Avg	.1734

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074001 / 33/11 KV AMDAPUR

Feeder No / Name : 204 / 11 KV AMDAPUR GFFS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.9526
Max	.9526
Min	.9526
Avg	.9526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074001 / 33/11 KV AMDAPUR

Feeder No / Name : 206 / 11 KV UNDRI GFFS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	1.2384
Max	1.2384
Min	1.2384
Avg	1.2384

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074013 / 33/11 KV EKLARA

Feeder No / Name : 200 / Station Transformer
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.0953
Max	.0953
Min	.0953
Avg	.0953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074013 / 33/11 KV EKLARA

Feeder No / Name : 201 / 11 KV BORGAON 1PH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.4115	.3395	.415	.583	.4115	.4458
2	.3772	.415	.3395	.3772	.5487	.4801	.4801
3	.3772	.415	.3772	.3772	.5487	.4801	.4801
4	.415	.4458	.4527	.3772	.5144	.4801	.5144
5	.5281	.4801	.5658	.4458	.583	.503	.5487
6	.6413	.6173	.679	.5144	.6859	.57	.7545
7	.5658	.5658	.8676	.7545	.6859	.6859	.7545
8	.5281	.5281	.6036	.4801	.6859	.6371	.6859
9	.5487	.583	.2401	.3772	.415	.4904	.4527
10	.679	.5487	.2058	.3018	.3772	.3772	.3018
11	.7545	.6516	.4801	.2263	.2263	.3018	.3018
12	.7202	.5487	.6173	.2641	.2263	.2641	.3018
13	.6516	.5487	.5144	.2641	.2263	.2641	.2263
14	.6173	.6173	.4801	.3018	.2263	.3018	.2641
15	.6173	.6173	.4458	.3395	.3018	.3018	.2641
16	.5487	.583	.5144	.3395	.3772	.3018	.3018
17	.4527	.4527	.3772	.3772	.3772	.3395	
18		.5658	.5281	.4527	.4527	.4527	.4527
19	.6036	.6036	.5658	.6224	.5658	.5658	.5281
20	.5281	.5658	.5658	.679	.5281	.6036	.4527
21	.4904	.4527	.4527	.7167	.4904	.6036	.415
22	.3772	.3772	.415	.7545	.4527	.6036	.4527
23	.415	.3772	.415	.6516	.4458	.4801	.4458
24	.3772	.4115	.3395	.415	.6173	.4557	.4801
Max	.7545	.6516	.8676	.7545	.6859	.6859	.7545
Min	.3772	.3772	.2058	.2263	.2263	.2641	.2263
Avg	.5301	.5160	.4743	.4510	.4642	.4565	.4481

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074013 / 33/11 KV EKLARA

Feeder No / Name : 202 / 11 KV BHORSHI 1PH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	06-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2401	.2401	.2641	.3018
2	.2401	.2401	.2058	.2641	.2641
3	.2743	.2058		.3018	.2641
4	.2743	.2058		.3018	.3018
5	.3086	.2058		.3772	.3395
6	.3429	.2058		.7167	.5281
7	.3429	.4801			.4481
8	.3772	.4115			.3772
9	.3018	.2263			
10	.2641	.2641	.1509		
11	.2263	.2263	.2263	.2401	
12	.2263	.2263	.2263	.2401	
13	.2263	.2263	.2263	.2743	
14	.2263	.2263	.3018	.3018	
15	.2263	.2263	.2641	.3395	
16	.2263	.2263	.2641	.3086	
17	.2263	.2641	.3018	.3018	
18	.3018	.3206	.1509	.3395	
19	.1509	.3772	.4527	.4527	
20	.2263	.3395	.3772	.4527	
21	.3395	.3018	.3772	.4527	
22	.2263	.3018	.3018	.4527	
23	.2263	.2401	.3018	.415	
24	.2134	.2401	.2401	.2641	.3018
Max	.3772	.4801	.4527	.7167	.5281
Min	.1509	.2058	.1509	.2401	.2641
Avg	.2598	.2679	.2711	.3531	.3474

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074013 / 33/11 KV EKLARA

Feeder No / Name : 203 / 11 KV EKLARA 1PH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	06-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.583	.5658	.2454
2	.6036	.5487	.5658	.2804
3	.6413	.5487	.5281	.2804
4	.7545	.6516	.5281	.2804
5	.7545	.6859	.6602	.3086
6	.8676	.9054	.8299	.3429
7	.7545	.7545	.7545	.3772
8	.679	.6036	.5281	.3772
9		.2058	.2743	
10		.2401		
11		.2401		
12		.2058		
13		.2229		
14		.2743		
15		.2743		
16		.1372		
17		.5658		
18		.6036		
19		.679		
20		.7545		
21		.679		
22		.6036		
23		.6036		
24	.6036	***	.5658	.2481
Max	.8676	94.2045	.8299	.3772
Min	.6036	.1372	.2743	.2454
Avg	.6958	4.4073	.5801	.3045

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074013 / 33/11 KV EKLARA

Feeder No / Name : 204 / 11 kV KOLARA 1PH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	06-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.3772	.4115	
2	.5487	.3772	.3429	
3	.5487	.4115	.3601	
4	.583	.3772		
5	.583	.3429		
6	.6173	.5487		
7	.583	.6173		
8	.6001	.4801	.5144	.1132
9	.5281	.5658	.5281	
10	.5281			
11	.4904			
12	.5281	.5658		
13	.5658	.5658		
14	.6036	.6036		
15	.5658	.4904		
16	.5281	.4527		
17	.5281	.4715		
18		.5658		
19	.7545	.679		
20	.8299	.7922		
21	.8676	.8299		
22	.679	.7545		
23	.4115	.4458		
24	.4572	.3944	.4458	
Max	.8676	.8299	.5281	.1132
Min	.4115	.3429	.3429	.1132
Avg	.5860	.5322	.4338	.1132

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074013 / 33/11 KV EKLARA

Feeder No / Name : 207 / 11 KV INCOMER-I

Feeder KV- 11 / INCOMING

PURELY LIS FEEDERS

DATE	01-JUN-18
HR	Load (MW)
24	.2286
Max	.2286
Min	.2286
Avg	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074025 / 33/11 KV MERA KH

Feeder No / Name : 200 / Station Transformer

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.1905
Max	.1905
Min	.1905
Avg	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074025 / 33/11 KV MERA KH

Feeder No / Name : 201 / 11 KV ANDHERA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1052				
2	.124				
3	.1417				
4	.1402				
5	.1595				
6	.1949				
7	.1949				
8	.1578				
9			.1494		
10			.1132		
11			.1494	.0886	.1063
12			.1494		.0876
13		.1772	.1307		.1063
14		.1949	.1307		.1063
15		.1595	.1494	.124	.1227
16		.1578	.1494	.1595	
24	.0914				
Max	.1949	.1949	.1494	.1595	.1227
Min	.0914	.1578	.1132	.0886	.0876
Avg	.1455	.1724	.1402	.1240	.1058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074025 / 33/11 KV MERA KH

Feeder No / Name : 202 / 11 KV ANTRI KH. AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.124
2							.0886
3							.0886
4							.0886
5							.1063
6							.1417
7						.1307	.3189
8					.2454		.3721
9	.2481						
10	.3012						
11	.2658		.1595				
12	.2835		.1772				
13	.2658			.1753			
14	.2126		.2126	.1949			
15			.2303	.1578			
16		.1509	.2481	.1595			
17			.2303				
24					.1417		.0886
Max	.3012	.1509	.2481	.1949	.2454	.1307	.3721
Min	.2126	.1509	.1595	.1578	.1417	.1307	.0886
Avg	.2628	.1509	.2097	.1719	.1936	.1307	.1575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074025 / 33/11 KV MERA KH

Feeder No / Name : 203 / 11 KV BHAROSA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0177	.0373	.0177
2				.0177	.0373	.0177
3				.0175	.0373	.0177
4				.0354	.056	.0177
5				.0532	.056	.0177
6				.0701	.056	.0354
7				.0701	.0747	.0709
8				.0701	.0747	.0886
9	.0354					
10	.0354	.0373				
11		.0373	.0532			
12		.0373	.0354			
13		.0373	.0354			
14		.0377	.0354			
15		.0747	.0532			
16		.0747	.0532			
23				.0373	.0177	
24				.0177	.0373	.0177
Max	.0354	.0747	.0532	.0701	.0747	.0886
Min	.0354	.0373	.0354	.0175	.0177	.0177
Avg	.0354	.0480	.0443	.0407	.0484	.0335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074025 / 33/11 KV MERA KH

Feeder No / Name : 204 / 11 KV ANTRI KH GFFS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5316	.4961	.4854		.5609	.5228	.4252
2	.567	.4961	.4854		.5847	.5228	.4252
3	.6201	.567			.6201	.5228	.4961
4	.7011	.7087			.7265	.5975	.7796
5	.8328	.7796			.9036	.6722	.6241
6	.9036	.9214			1.2048	.7842	1.2048
7	1.0277	.9922			1.0631	1.0829	1.2048
8					.9816	.9709	1.0631
9	.8505				.7655		
10	.6379	.679			.5975		
11	.567	.5975	.5316	.4252	.5228	.4252	.5316
12	.5316	.5228	.4961	.4557	.4481	.3544	.4733
13	.5316	.4904	.567	.4961	.3734	.4252	.4252
14	.4961	.5281	.567	.4382	.3734	.4961	.443
15		.5658	.6379	.4557	.4481	.4252	.4607
16	.4252	.6036	.6379	.4961	.5601	.567	.5784
17	.6379	.6348	.6379	.7011	.6722	.7087	.7087
18		.7095	.7796	.8413	.8962	.9214	.9568
19	.7796	.7842	.9214			.9214	.8939
20	.8505	.6722	.8859		.7922	.9214	.8505
21	.6379	.5975	.6201		.6348	.7796	
22	.6379	.5601	.5316		.5975	.6379	
23	.567	.5228	.4961		.5228	.567	
24	.7621	.4961	.4854		.5434	.5228	.5316
Max	1.0277	.9922	.9214	.8413	1.2048	1.0829	1.2048
Min	.4252	.4904	.4854	.4252	.3734	.3544	.4252
Avg	.6713	.6330	.6104	.5387	.6693	.6522	.6882

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074025 / 33/11 KV MERA KH

Feeder No / Name : 205 / 11 KV BHAROSA GFFS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4031	.1595	.4481		.443	.4481	.4075
2	.4207	.1595	.4481		.5316	.4527	.5493
3	.5609	.1772	.5093		.5973	.5658	.6024
4	.7362	.1772	.7167		.7011	.7842	.7442
5	.8682	.5138	1.0456		1.382	1.0829	1.0808
6	.9465	.5493	1.1506		1.3289	1.419	1.4022
7	1.1871	.6024			1.2403	1.3443	1.3496
8	1.0341		1.3443			1.2136	1.1694
9	.9036		1.2826		.5041	.9709	
10	.6201	.2614	1.1506		.4527	.8589	
11	.5316	.3395	1.0631	.4252	.4338	.4961	.7619
12	.5316	.3734	1.0631	.4075	.4904	.4607	.6379
13	.567			.3721	.4481	.5316	.5847
14	.4961		1.0985	.4207	.4108	.4252	.7011
15	.6556	.6722	.6733	.4557	.4854	.5316	.7973
16	.691	.8775	.6556	.5083	.5228	.7087	.8682
17	.7087	.3395	.8589	.815	.8589		1.0277
18		.9149	.9214	.9391	1.0269	.8939	1.0454
19		.7842	1.0277			1.1744	1.134
20	.3366	.6722	.9568		.5975	.8505	.7973
21	.2303	.5601	.8682		.5228	.7796	
22	.1772	.4854	.6201		.4854	.7619	
23	.1772	.4481	.4075		.4481	.6556	
24	.4572	.1595	.4481		.1315	.4481	.6201
Max	1.1871	.9149	1.3443	.9391	1.382	1.419	1.4022
Min	.1772	.1595	.4075	.3721	.1315	.4252	.4075
Avg	.6018	.4613	.8526	.5430	.6383	.7764	.8569

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074025 / 33/11 KV MERA KH

Feeder No / Name : 206 / 11 KV DEULGAON GHUBE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.124		.112				
2	.1063		.112				
3	.1063		.112				
4	.124						
5	.1417						
6	.1595						
7	.1772						
8	.2454		.0754				
10					.1307		
11				.0532	.1494		.1772
12				.0532	.1509	.0886	.1417
13				.0701	.1494	.0886	.124
14				.0709	.1307	.0709	.124
15				.0886	.1494	.1063	.1417
16				.0886	.1307	.1063	
22		.112					
23		.112					
24	.1524		.112				
Max	.2454	.112	.112	.0886	.1509	.1063	.1772
Min	.1063	.112	.0754	.0532	.1307	.0709	.124
Avg	.1485	.112	.1047	.0708	.1416	.0921	.1417

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074063 / 33/11 KV CHIKHLI

Feeder No / Name : 200 / Station Transformer

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.0953
Max	.0953
Min	.0953
Avg	.0953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074063 / 33/11 KV CHIKHLI

Feeder No / Name : 201 / 11 KV RAUT WADI (TOWN)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.924		.7621	.7682		.7811
2	.9149		.7621	.7392		.743
3	.8962		.724	.7095		.7049
4	.7392		.6859	.6722		.6859
5	.695		.6287	.6653		.6859
6	.6468		.5906	.6401		.6287
7	.6036		.6097	.6219		.6097
8	.5729		.5716	.5914		.6097
9	.5487	.5335	.5144	.3881	.4954	.5525
10		.4954	.4954	.5228	.4954	.5525
11		.5144	.4572		.5144	.5121
12		.5525	.4854		.5144	.4668
13		.4954			.4954	.5228
14		.5335	.5121		.5525	.5487
15		.5144	.567		.5525	.5601
16		.5525	.5975		.6097	.5121
17		.5525	.5544		.6287	.5415
18		.5906	.5601		.5906	
19		.6097	.6283		.6287	.5853
20		.743	.7499		.743	.6584
21		.6859	.823		.7621	
22		.743	.8686		.7811	.8962
23		.8573	.8501		.8002	.8048
24	.9328		.8002	.8215		.7811
Max	.9328	.8573	.8686	.8215	.8002	.8962
Min	.5487	.4954	.4572	.3881	.4954	.4668
Avg	.7474	.5982	.6434	.6491	.6109	.6338

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074063 / 33/11 KV CHIKHLI

Feeder No / Name : 202 / 11 KV RAIPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4382	.2984		.2858
2		.4191	.2949		.2858
3		.4191	.3605		.3239
4		.4572	.3932		
5		.4954	.4973		.4382
6		.5335	.6226		.4954
7		.6478	.8619		.7811
8		.6478	.6962		.8954
9	.4382				
10	.5144				
11	.5716				
12	.5144				
13	.6478				
14	.6668				
15	.5716				
16	.5716				
23	.4001			.3239	
24		.4763	.2785		.2858
Max	.6668	.6478	.8619	.3239	.8954
Min	.4001	.4191	.2785	.3239	.2858
Avg	.5441	.5038	.4782	.3239	.4739

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074063 / 33/11 KV CHIKHLI

Feeder No / Name : 203 / 11 KV SHEL SOOR GFFS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572		.6287	.6036		.5716
2	.4572		.6668	.6283		.6097
3	.5175		.743	.695		.6097
4	.5853		.8383	.7762		.6287
5	.6722		.9145	.8596		.6478
6	.8215		.9907	.9709		.9907
7	.8048		.9145	.9145		1.0288
8	.7947		.8573	.7947		.8764
9	.6584	.6478	.5525	.7133	.6097	.6668
10		.5525		.4207	.5906	.6097
11		.4954	.426		.5144	
12		.4954	.3481		.5335	
13		.4382	.2195		.5144	.3658
14		.4572	.5975		.4572	.4805
15		.4954	.5544		.4763	.4572
16		.4954	.5121		.4382	.4854
17		.6097	.5853		.5906	.499
18		.6859	.6219		.6668	.6767
19		.724	.7577		.724	.7023
20		.7811	.7865		.8954	.7499
21		.6859	.7392		.7621	.695
22		.6478	.6219		.6478	.6468
23		.6097	.6401		.5906	.6283
24	.2858		.5906	.5914		.5906
Max	.8215	.7811	.9907	.9709	.8954	1.0288
Min	.2858	.4382	.2195	.4207	.4382	.3658
Avg	.6055	.5881	.6568	.7244	.6008	.6462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074063 / 33/11 KV CHIKHLI

Feeder No / Name : 204 / 11 KV SAKEGAON GFFS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743		.3239	.2801		.2858
2	.2801		.381	.2561		.3429
3	.3361		.4382	.2926		.381
4	.3841		.5335	.3696		.4572
5	.5228		.5906	.4938		.5906
6	.6036		.6478	.6653		.6668
7			.4572	.567		.7049
8			.4382	.4294		.4001
9		.3239	.362		.4191	.3429
10		.3048	.2667		.3429	.3048
11		.1905	.1646		.2667	.2957
12		.2096	.2012		.2667	.2378
13		.2858	.1829			.2561
14		.2477	.2218			.2743
15		.2858	.2378		.2096	.2987
16		.2858	.2587		.3239	.3109
17		.3429	.3109		.381	.4066
18		.381	.4207		.5335	.462
19		.4763	.499		.5144	.4572
20		.4001	.4572		.5144	.4024
21		.3429	.3841		.4191	.3696
22		.3048	.3109		.3239	.3326
23		.3048	.3361		.3048	.2957
24	.2858		.2858	.2772		.2858
Max	.6036	.4763	.6478	.6653	.5335	.7049
Min	.2743	.1905	.1646	.2561	.2096	.2378
Avg	.3838	.3124	.3630	.4035	.3708	.3818

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074063 / 33/11 KV CHIKHLI

Feeder No / Name : 206 / 11 KV SHEL SOOR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.4954	.431	.4572	.5906
10	.6097	.547	.5906	.6097
11				.6767
12	.426		.2858	.695
13	.3605		.2096	.5898
14	.3978			.4973
15	.4424			.5304
16	.4752		.3048	.4973
Max	.6097	.547	.5906	.695
Min	.3605	.431	.2096	.4973
Avg	.4581	.489	.3696	.5859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286] BU 2861

Substation No/ Name :- 074080 / 33/11 KV MURADPUR

Feeder No / Name : 200 / Station Transformer
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.0953
Max	.0953
Min	.0953
Avg	.0953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074080 / 33/11 KV MURADPUR

Feeder No / Name : 201 / 11 KV MURADPUR GFFS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
1		.4334	
3			.4694
4			.4915
5			.7712
6			.823
7			.8383
8	.5548	.6935	
9	.4161		
10	.5144		
11	.3988		
12	.3988	.4359	
13	.3988		
14	.3814		
15	.3814		
16	.4161		
24	.9145	.4382	
Max	.9145	.6935	.8383
Min	.3814	.4334	.4694
Avg	.4775	.5003	.6787

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074080 / 33/11 KV MURADPUR

Feeder No / Name : 202 / 11 KV YEOTA AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
9	.1214
10	.1715
14	.1734
15	.1214
16	.1578
Max	.1734
Min	.1214
Avg	.1491

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074080 / 33/11 KV MURADPUR

Feeder No / Name : 203 / 11 KV BHALGAON AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
1		.2774	
3			.0151
6			.0301
7	.2601		
8		.0347	
24		.2572	
Max	.2601	.2774	.0301
Min	.2601	.0347	.0151
Avg	.2601	.1898	.0226

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074080 / 33/11 KV MURADPUR

Feeder No / Name : 204 / 11 KV RAMNAGAR AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
9	.1372
10	.2103
11	.2601
12	.2254
13	.1734
14	.156
15	.1734
16	.1372
Max	.2601
Min	.1372
Avg	.1841

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074080 / 33/11 KV MURADPUR

Feeder No / Name : 205 / 11 KV GANGALGAON AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18	02-JUN-18
HR	Load (MW)	Load (MW)
8		.0347
24	.0572	
Max	.0572	.0347
Min	.0572	.0347
Avg	.0572	.0347

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074080 / 33/11 KV MURADPUR

Feeder No / Name : 206 / 11 KV CHANDANPUR AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18	02-JUN-18
HR	Load (MW)	Load (MW)
2		.1907
3		.1907
4		.2427
5		.2774
6		.3814
7		.3121
8		.3121
9	.1715	
10	.2601	
11	.2254	
12	.2572	
13	.2774	
14	.208	
15	.208	
24	.1981	.1387
Max	.2774	.3814
Min	.1715	.1387
Avg	.2257	.2557

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074081 / 33/11 KV MANGRUL (Nanghare)

Feeder No / Name : 200 / Station Transformer

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.0953
Max	.0953
Min	.0953
Avg	.0953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074081 / 33/11 KV MANGRUL (Nanghare)

Feeder No / Name : 201 / 11 KV WARKHED AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.12		.1715	
2			.12		.1715	
3			.12		.1715	
4			.1372		.1715	
5			.1372		.1715	
6			.1372		.1886	
7	.3601			.2743		
8	.3772			.2915		
9	.3601			.2572		
10	.3258	.0686		.3086		.2572
11	.2915	.2401		.2572		.2572
12	.3086	.2401		.2572		.3772
13	.2915	.2058		.2743		.2743
14	.2572	.1715		.2572		.2229
15		.1372				
16		.1372				
23	.2401	.12		.1715		.1543
24			.12			
Max	.3772	.2401	.1372	.3086	.1886	.3772
Min	.2401	.0686	.12	.1715	.1715	.1543
Avg	.3125	.1651	.1274	.261	.1744	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074081 / 33/11 KV MANGRUL (Nanghare)

Feeder No / Name : 202 / 11 KV MANGRUL GFFS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.7373	.6516	.6516	.703	
2	.6516	.7373	.6516	.6516	.703	
3	.6859			.6859	.703	
4	.6859			.9259	.7545	
5	.9602	.8916		1.046	.8573	
6	1.166	1.1317		1.2346	1.2517	
7	.9602	1.046		1.1145	1.3375	
8	.9431			1.0288	1.0117	
9	.8745	.8916	.8916	.8573	.823	
10	.6516	.703	.7716	.6687	.7373	.4973
11	.5316	.6001	.5144	.6001	.5487	.3601
12	.583	.5316	.5487		.583	.3772
13	.5316	.5658	.5144	.5487	.583	.3258
14	.6344	.6173	.5316	.6344	.6001	.3258
15	.6344	.6516	.5487	.6001	.6001	.2915
16	.6344	.6859	.5487	.6001	.6344	.3429
17	.6687	.703	.5658	.6344	.7202	.4115
18	.823	.9088	.583	.7888	.8059	.6516
19	.9602	.8573	.6344	1.0974	1.0802	.9602
20	.9431	.9945	.6344	1.2003		1.0631
21	.8573	.8059	.6859	.9774		.8916
22	.7716	.7373	.7545	.7888	.703	.823
23	.7202	.6859	.6687	.7373	.6516	.7545
24	.4382	.7373	.6687	.6516	.703	
Max	1.166	1.1317	.8916	1.2346	1.3375	1.0631
Min	.4382	.5316	.5144	.5487	.5487	.2915
Avg	.7484	.7724	.6316	.8141	.7771	.5769

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074081 / 33/11 KV MANGRUL (Nanghare)

Feeder No / Name : 203 / 11 KV DONGERGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8916		.8573
2		.8916		.8402
3				.823
4				.823
5				.823
6				.8402
7			.8573	
8			.8573	
9	.1886		.9259	
10	1.0288		1.0669	
11	1.2346		.9774	
12	1.286		.9088	
13	1.2346		.9088	
14	1.1145		.8059	
15	.9945			
16	.9259			
17	1.0288			
23	.8916		.8916	
24		.9259		.8573
Max	1.286	.9259	1.0669	.8573
Min	.1886	.8916	.8059	.823
Avg	.9928	.9030	.9111	.8377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074081 / 33/11 KV MANGRUL (Nanghare)

Feeder No / Name : 204 / 11 KV ISOLI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0343		.2058
2				.2058
3				.2058
4				.2058
5				.2058
6				.2401
7			.2401	
8			.2401	
9			.2401	
10	.3429		.2401	
11	.3772		.2743	
12	.3086		.2743	
13	.3429		.3086	
14	.2401		.2743	
16	.1715			
17	.1715			
23	.0343		.2058	
24		.0343		.1715
Max	.3772	.0343	.3086	.2401
Min	.0343	.0343	.2058	.1715
Avg	.2486	.0343	.2553	.2058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074081 / 33/11 KV MANGRUL (Nanghare)

Feeder No / Name : 205 / 11 KV DAHIGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0514		.0686		
2		.0514		.0686		
3				.0686		
4				.0686		
5				.0686		
6				.0686		
7	.2058		.1029		.1372	
8	.2401		.1029		.2058	
9	.3429		.0686		.1886	
10	.2572		.0686		.1372	.2229
11	.2229		.2401		.1715	.2915
12	.2058		.2401		.1886	.2915
13	.1886		.2229		.2058	.2058
14	.1715		.1029		.1715	.2058
23	.0686		.0857		.1029	.0857
24		.0686		.0686		
Max	.3429	.0686	.2401	.0686	.2058	.2915
Min	.0686	.0514	.0686	.0686	.1029	.0857
Avg	.2115	.0571	.1372	.0686	.1677	.2172

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074081 / 33/11 KV MANGRUL (Nanghare)

Feeder No / Name : 206 / 11 KV NAIGON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.2915	.2743	.3086	.3086	
2	.3086	.2915	.2743	.3086	.3086	
3	.3429		.2743	.3772	.3086	
4	.4115			.4115	.3429	
5	.4458			.4801	.4115	
6					.5144	
11	.2915	.2401	.2401	.2401	.2058	.2572
12		.2401	.2401	.2058	.1886	
13		.2401	.2401	.2058	.2058	
14	.2743	.2058	.2058	.2058	.2229	
15	1.1317	.9259	.5144	.6516	.7545	
16	.8916	.9259	.6001	.7202	.7888	.7373
17	1.0974	.9774	.7202	.7545	.8059	.7716
18	.9945	.9259	.7202	.7202	.8916	.823
19	1.0288	.9602	.6344	.7545	.8059	.7373
20	1.0288	.9088	.6173	.7202		.703
21	.9945	.823	.583	.7202		.6859
22	.9259	.7716	.5658	.7202	.3086	.6173
23	.3086	.3086	.3086	.3086	.1372	.3429
24	.4267	.583	.2915	.3086	.3086	
Max	1.1317	.9774	.7202	.7545	.8916	.823
Min	.2743	.2058	.2058	.2058	.1372	.2572
Avg	.6595	.6012	.4297	.4801	.4344	.6306

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074082 / 33/11 KV MIDC CHIKHLI

Feeder No / Name : 200 / Station Transformer

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.1905
Max	.1905
Min	.1905
Avg	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074082 / 33/11 KV MIDC CHIKHLI

Feeder No / Name : 201 / 11 KV MIDC FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2957	.2402	.4435		.2957	.5544	.5544
2	.2772	.2218	.4435	.3881	.2772	.5544	.5544
3	.2587	.2218	.4251	.3881	.2772	.5359	.5544
4	.2772	.2218		.3326	.2772	.5359	.5175
5	.2587	.2033	.1294	.2772	.2772	.4805	.5175
6	.2402	.2033		.2772	.2772	.2957	.499
7	.2587	.2772		.2957	.2587	.5359	.499
8	.2772	.2402		.2652	.2402	.3696	.5175
9	.3326	.4251				.5914	.6653
10	.5544		.2218	.3881	.4435	.7947	.8871
11	.8316	.5359	.4435	.499	.7577	.9979	.5914
12	.9979	.6283	.8871	.4435	.5544	.9425	.7577
13	.8501	.5914	.6653	.4805	.5914		.961
14	.8131	.6283	.6653	.5359	.5544		.6653
15	.924	.6099	.6838	.4251	.462	.8316	.6283
16	.7762	.6099	.8316	.4066	.4805	.924	.7023
17	.6283	.5914	.6283	.3326	.462	.8686	.7023
18	.499	.8131	.6468	.2218	.462	.8871	.6838
19	.5175	.7392	.5544	.2772	.4251	.6468	.6653
20	.6468	.2772	.5175	.3326	.3511	.6283	.3326
21	.4251	.5914	.6283	.3326	.3142	.5914	.3881
22	.5914	.5914	.6283	.3511	.3142	.6653	.462
23	.3142	.6283	.4835	.3326	.5544		.5729
24	.3429	.2772	.462	.5914	.2957	.5729	.6099
Max	.9979	.8131	.8871	.5914	.7577	.9979	.961
Min	.2402	.2033	.1294	.2218	.2402	.2957	.3326
Avg	.5079	.4508	.5468	.3716	.4001	.6574	.6037

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074082 / 33/11 KV MIDC CHIKHLI

Feeder No / Name : 202 / 11 KV SAILANINAGAR TOWN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5339	1.3717	1.386	1.2197	1.4266	1.3676	1.2752
2	1.4969	1.3169	1.3676	1.2197	1.39	1.2752	1.2567
3	1.46	1.2803	1.386	1.1458	1.3535	1.2567	1.2752
4	1.4415	1.2254	1.2012	1.1458	1.2986	1.1458	1.2567
5	1.4045	1.1706	1.1273	1.1088	1.2803	1.1273	1.2012
6	1.3491	1.1157	1.0903	1.1273	1.2437	1.1088	1.2197
7	1.3121	1.0974	1.1273	1.1458	1.2803	1.1088	1.2012
8	1.2752	1.1157	1.1088	1.0719	1.1523	1.1088	1.1643
9	1.3306	1.1706	1.1088		1.1888	1.0719	1.1643
10	1.2752		1.0719	1.2197	1.1706	1.1643	1.2752
11	1.4998	1.6632	1.2197	1.3352	1.3491	1.386	1.4266
12	1.5364	1.6632	1.2752	1.4083	1.4784	1.386	1.39
13	1.6644	1.6817	1.2752	1.4083	1.4784	1.386	1.4998
14	1.701	1.6632	1.2752	1.5181	1.4784	1.3306	1.5912
15	1.701	1.6632	1.2752	1.5364	1.5708	1.4415	1.4998
16	1.7558	1.4784	1.2567	1.4632	1.6263	1.46	1.4815
17	1.7193	1.4415	1.2197	1.5181	1.5708	1.5339	1.2986
18	1.3717	1.4784	1.2382	1.2986	1.5154	1.5339	1.3717
19	1.5364	1.6263	1.3306	1.5546	1.6448	1.5154	1.4998
20	1.6644	1.6263	1.4415	1.6644	1.6632	1.6632	1.5912
21	1.6095	1.4784	1.386	1.5546	1.3676	1.5893	1.5364
22	1.6644	1.4784	1.3491	1.5729	1.386	1.4415	1.5364
23	1.5729	1.5154	1.3306	1.4998	1.4784		1.4998
24	1.6575	1.4449	1.4045	1.3121	1.4266	1.386	1.2936
Max	1.7558	1.6817	1.4415	1.6644	1.6632	1.6632	1.5912
Min	1.2752	1.0974	1.0719	1.0719	1.1523	1.0719	1.1643
Avg	1.5222	1.4246	1.2605	1.3500	1.4091	1.3386	1.3669

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074082 / 33/11 KV MIDC CHIKHLI

Feeder No / Name : 203 / 11 KV KHANDALA AG

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2984	.2721	.2652	.2984	.2721	.2652	.2486
2	.2984	.2721	.2652	.2984	.2561	.2486	.2652
3	.2984	.2721	.2652	.2652	.2561	.2321	.2486
4	.3481	.2881	.2652	.2652	.3041	.2321	.2486
5	.3978	.3041	.2321	.3481	.3361	.2772	.2652
6	.4144	.3361	.3978	.431	.4321	.3812	.2984
7	.3978	.3361	.3812	.4475	.5121	.4144	.3647
8	.3978	.3361	.3647	.4144	.4001	.3812	.3812
9	.3481	.2561	.2984	.3481	.3361	.2984	.2984
10	.3978		.2818	.2984	.2881	.2652	.3481
11	.2915	.2652	.3326	.112	.2652	.2984	.2401
12	.3041	.2818	.2486	.2721	.2486	.2984	.2721
13	.3041	.3315	.2486	.2881	.2652	.2984	.2721
14	.3041	.2984	.2486	.208	.2652	.2984	.2721
15	.2881	.1658	.2652	.2721	.2486	.2486	.3041
16	.3201	.2155	.3647	.2721	.2652	.2984	.3201
17	.3681	.1658	.431	.3361	.3315	.3315	.3361
18	.3521	.2818	.4475	.3361	.3647	.3647	.3681
19	.3681	.3315	.4475	.4641	.3812	.3481	.4001
20	.3681		.3812	.4001	.3481	.3812	.3201
21	.3361	.2984	.3315	.3521	.2984	.3315	.3361
22	.3361	.2984	.3149	.3521	.2818	.4641	.3201
23	.2881	.2652	.3481	.3201	.2818		.3361
24	.1829	.2721	.2652	.2818	.2881	.2818	.2818
Max	.4144	.3361	.4475	.4641	.5121	.4641	.4001
Min	.1829	.1658	.2321	.112	.2486	.2321	.2401
Avg	.3337	.2793	.3205	.3201	.3136	.3147	.3061

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074083 / 33/11 KV SAWANA (WALTI)

Feeder No / Name : 200 / Station Transformer

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.2286
Max	.2286
Min	.2286
Avg	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074083 / 33/11 KV SAWANA (WALTI)

Feeder No / Name : 201 / 11 KV SAWANA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0681	.0452	.046				
2	.0674	.0443	.0511				
3	.0672	.0438	.0524				
4	.064	.0434	.0667				
5	.0616	.0509	.0804				
6	.1417	.0835	.0922				
7	.2138	.2023	.2377				
8	.1808	.2204	.2364				
9				.1334	.1276	.032	.0997
10				.1696	.1648	.0912	.1118
11				.1646	.1505	.1459	.1334
12				.1778	.1646	.1484	.1623
13				.1273	.1217	.2398	.1763
14				.0887	.1484	.2055	.1498
15				.12	.1498	.1761	.1353
16				.0934	.1484	.1318	.1505
17					.1484		
23	.0473	.0527					
24	.0672	.0476	.0457				
Max	.2138	.2204	.2377	.1778	.1648	.2398	.1763
Min	.0473	.0434	.0457	.0887	.1217	.032	.0997
Avg	.0979	.0834	.1010	.1344	.1471	.1463	.1399

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074083 / 33/11 KV SAWANA (WALTI)

Feeder No / Name : 202 / 11 KV WALTI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0648	.1315	.0765	.0783
2				.0665	.1324	.0794	.0775
3				.0668	.1353	.1067	.0773
4				.0674	.1372	.1099	.0766
5				.0812	.1669	.1658	.0887
6				.1233	.2551	.1801	.1305
7				.2364	.3221	.3203	.3256
8				.2201	.3131	.3039	.3434
9		.1389	.1264				
10		.1825	.107				
11		.168	.1758				
12		.1534	.1872				
13		.1664	.1379				
14		.1125	.1496				
15	.0932	.1105	.1262				
16	.1715	.1113	.1379				
23			.0519	.12	.1094	.103	.099
24					.1334	.075	.0783
Max	.1715	.1825	.1872	.2364	.3221	.3203	.3434
Min	.0932	.1105	.0519	.0648	.1094	.075	.0766
Avg	.1324	.1429	.1333	.1163	.1836	.1521	.1375

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074083 / 33/11 KV SAWANA (WALTI)

Feeder No / Name : 203 / 11 KV SAWANA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5239	.5239	.5082	.5072	.5129	.5067	.5046
2	.5249	.5233	.5087	.5082	.5129	.5072	.5051
3	.5271	.5244	.5658	.5093	.5093	.5453	.5062
4	.5475	.5249	.6042	.5292	.5098	.5464	.5448
5	.5624	.5823	.6413	.5676	.5664	.6036	.5835
6	.6797	.679	.6615	.7	.6986	.7356	.7552
7	.6023	.6212	.6042	.6231	.6804	.6608	.7167
8	.5999	.5046	.5847	.5636	.603	.6224	.6588
9	.5041	.5201	.5276	.3067	.4874	.5464	.5223
10	.3889	.2949	.4099	.3909	.4141	.4091	.449
11	.3861	.3901	.3493	.3493	.3395	.3309	.3688
12	.3685	.3708	.3129	.3132	.3587	.335	.3306
13	.4003	.3889	.37	.3116	.3576	.3135	.3135
14	.3841	.4099	.333	.3677	.3378	.3138	
15	.4045	.3929	.3519	.3708	.3746	.3688	.3727
16	.4057	.3941	.3913	.3696	.3921	.37	.3921
17	.3282	.4518	.4172	.3985	.4108	.3865	.3841
18	.2695	.526	.5516	.5132	.5051	.4615	.4606
19	.4251	.6742	.6124	.6264	.6756	.6099	.5567
20	.7202	.6174	.6387	.7267	.7694	.7073	.6535
21	.6495	.5613	.5448	.618	.5794	.5963	.5987
22	.595	.5618	.5442	.5618	.5618	.5578	.5818
23	.5601	.5067	.5244	.5255	.5271	.5201	.5636
24	.5335	.5249	.5093		.5082	.5067	.5041
Max	.7202	.679	.6615	.7267	.7694	.7356	.7552
Min	.2695	.2949	.3129	.3067	.3378	.3135	.3135
Avg	.4955	.5029	.5028	.4895	.5080	.5026	.5142

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074084 / 33/11 KV CHANDHAI (BHOKER)

Feeder No / Name : 200 / Station Transformer

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.1715
Max	.1715
Min	.1715
Avg	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074084 / 33/11 KV CHANDHAI (BHOKER)

Feeder No / Name : 202 / 11 KV CHANGHI GFFS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3174	.2987	.2987	.3174	.3361	.3361	.2987
2	.3142	.2987	.2987	.3734	.3361	.3361	.2957
3	.3174	.2987	.3326	.4108	.3361	.3361	.2957
4	.4108	.3361	.3361	.4481	.3734	.3734	.3921
5	.4938	.4668		.5228	.4854	.5228	.4854
6	.5544	.5975		.5601	.5788	.5601	.5359
7	.5041	.5228		.5601	.5228	.5601	.5788
8	.4066	.4481	.2614	.4435	.4066	.4066	.4108
9	.3547	.4294	.2241	.3696	.3696	.3326	.3361
10	.2378	.3361	.168	.2587	.2195	.3174	.2772
11	.2054	.2402	.2218	.2402	.2715	.2587	.1848
12	.2957	.2195	.2402		.2172	.2587	.1848
13	.2587	.2427	.1848	.2561	.2172	.2801	.1848
14	.2743	.2402	.2402	.2561	.2715	.2195	.2402
15	.3109	.2561	.2402	.2743	.2715	.2587	.2218
16	.3475	.2987		.2715	.3109	.2241	.2772
17	.3841	.3326	.3361	.3658	.3658	.3361	.3361
18	.3841	.4481	.4207	.3658	.4435	.4108	.4294
19	.5041	.462	.4481	.4481	.4854	.5041	.4294
20	.4668	.4108	.4668	.5041	.4481	.4854	.4668
21	.4108	.3734	.3734	.4481	.3734	.3881	.4108
22	.3734	.3547	.3547	.3734	.3361	.3547	.3734
23	.3174	.3174	.3174	.3361	.3361	.3361	.3361
24	.3109	.2987	.2957	.3174	.3361	.3361	.3142
Max	.5544	.5975	.4668	.5601	.5788	.5601	.5788
Min	.2054	.2195	.168	.2402	.2172	.2195	.1848
Avg	.3648	.3553	.3030	.3792	.3604	.3639	.3457

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074084 / 33/11 KV CHANDHAI (BHOKER)

Feeder No / Name : 203 / 11 KV BHOKER AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.0869	.0791	.2115	.306	.2976	.2846
2	.1107		.0791	.2538	.306	.2976	.2881
3	.112		.08	.2782	.306	.3111	.2846
4	.1107	.0869		.3338	.3338	.3246	.3437
5	.125	.0724		.3894	.3894	.3517	.4321
6	.1898	.1448		.3894	.5007	.4001	.4586
7	.3479	.2896			.439	.4801	.4801
8	.2846	.2606	.2056		.4115	.3467	.4161
9	.3637	.1907	.3521	.1235	.1315	.1067	.1581
10	.4218	.242	.3475	.2469	.2134	.1739	.192
11	.4311		.333	.1623	.2401	.25	.2201
12		.4744	.3475		.2134	.2031	.176
13		.4218	.3475	.2134	.2134	.1739	.2201
14		.3906	.333	.16	.2	.1265	.1907
15	.153	.3637	.3765	.2	.2	.1739	.1907
16	.1947	.4531	.3475	.1623	.2	.1423	.176
23	.0869	.0937	.2058	.3243	.3018	.2881	.2462
24	.1067	.0869	.096	.2115	.3018	.3018	.2846
Max	.4311	.4744	.3765	.3894	.5007	.4801	.4801
Min	.0869	.0724	.0791	.1235	.1315	.1067	.1581
Avg	.2100	.2439	.2522	.2440	.2893	.2639	.2801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 078002 / 220 KV CHIKHALI EHV S/S

Feeder No / Name : 201 / 11 KV CHIKHALI TOWN-2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	3.0484
Max	3.0484
Min	3.0484
Avg	3.0484

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 078002 / 220 KV CHIKHALI EHV S/S

Feeder No / Name : 203 / 11 KV (Kelwad) TOWN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 078002 / 220 KV CHIKHALI EHV S/S

Feeder No / Name : 205 / 11 KV SOOTGIRANI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18
HR	Load (MW)
24	.5716
Max	.5716
Min	.5716
Avg	.5716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 078002 / 220 KV CHIKHALI EHV S/S

Feeder No / Name : 207 / 11 KV ROHADA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.1905
Max	.1905
Min	.1905
Avg	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286] BU 2861

Substation No/ Name :- 078002 / 220 KV CHIKHALI EHV S/S

Feeder No / Name : 400 / Station T/F

Feeder KV- 33 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.5716
Max	.5716
Min	.5716
Avg	.5716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 078002 / 220 KV CHIKHALI EHV S/S

Feeder No / Name : 401 / 33 KV Jafrabad

PURELY LIS FEEDERS

Feeder KV- 33 / INCOMING

DATE	01-JUN-18
HR	Load (MW)
24	11.4312
Max	11.4312
Min	11.4312
Avg	11.4312

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 078002 / 220 KV CHIKHALI EHV S/S

Feeder No / Name : 402 / 33 KV Dhad

Feeder KV- 33 / INCOMING

PURELY LIS FEEDERS

DATE	01-JUN-18
HR	Load (MW)
24	10.8596
Max	10.8596
Min	10.8596
Avg	10.8596

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 078002 / 220 KV CHIKHALI EHV S/S

Feeder No / Name : 403 / 33 KV BULDHANA

PURELY LIS FEEDERS

Feeder KV- 33 / INCOMING

DATE	01-JUN-18
HR	Load (MW)
24	2.8578
Max	2.8578
Min	2.8578
Avg	2.8578

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 078002 / 220 KV CHIKHALI EHV S/S

Feeder No / Name : 405 / 33 KV AMDAPUR

PURELY LIS FEEDERS

Feeder KV- 33 / INCOMING

DATE	01-JUN-18
HR	Load (MW)
24	6.2872
Max	6.2872
Min	6.2872
Avg	6.2872

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 078002 / 220 KV CHIKHALI EHV S/S

Feeder No / Name : 406 / 33 KV DUSARBID

PURELY LIS FEEDERS

Feeder KV- 33 / INCOMING

DATE	01-JUN-18
HR	Load (MW)
24	9.4307
Max	9.4307
Min	9.4307
Avg	9.4307

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 078002 / 220 KV CHIKHALI EHV S/S

Feeder No / Name : 407 / 33 KV MIDC

Feeder KV- 33 / INCOMING

SHEDDABLE FEEDER MIDC EQUIVALENT
HAVING WEEKLY STAGGERING

DATE	01-JUN-18
HR	Load (MW)
24	5.144
Max	5.144
Min	5.144
Avg	5.144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074002 / 33 KV ANDERA

Feeder No / Name : 200 / Station Transformer
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)
6		.1677
19	.2347	
24	.0848	
Max	.2347	.1677
Min	.0848	.1677
Avg	.1598	.1677

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287]

BU 2879

Substation No/ Name :- 074002 / 33 KV ANDERA

Feeder No / Name : 201 / 11 KV ANDERA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.2572	.3429	.3429		.3429
2	.3429	.2572	.1715	.3429		.3429
3	.3429	.2572	.1715	.3429		.3429
4	.4287	.2572	.1715	.3429		.3429
5	.5144	.3429	.2572	.5144		.3429
6	.6001	.5144	.3429	.6001		.4287
7	.6001	.6001	.3429	.6001		.5144
8	.6001	.6001	.2572			.4287
9	.5144	.4287	.2572			.3429
10	.3429	.4287	.1715			.3429
11	.3429	.3429	.1715			.3429
12	.3429	.3429	.3429	.2572		.2572
13	.3429	.3429	.3429	.1715	.4287	.1715
14	.3429	.3429	.3429	.1715	.5144	.2572
15		.3429	.3429	.1715	.5144	.2572
16		.3429	.3429	.1715	.4287	.2572
17		.4287	.4287	.2572	.5144	.5144
18		.4287	.5144	.2572	.2572	.6859
19		.6001	.5144	.2572	.2572	.6859
20		.5144	.5144	.6001	.2572	.6001
21		.4287	.5144		.5144	.5144
22		.3429	.4287		.4287	.4287
23		.3429	.3429		.1715	.3429
24	.1357		.3429	.3429		.3429
Max	.6001	.6001	.5144	.6001	.5144	.6859
Min	.1357	.2572	.1715	.1715	.1715	.1715
Avg	.4091	.3951	.3322	.3379	.3897	.3929

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074002 / 33 KV ANDERA

Feeder No / Name : 202 / 11 KV Mendgaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572		.1715	.2572
2	.2572		.1715	.2572
3	.2572		.1715	.2572
4	.3429		.1715	.2572
5	.4287		.2572	.3429
6	.6001		.3429	.5144
7	.5144		.3429	.4287
8	.5144		.2572	
9	.3429		.1715	
10	.2572			
11	.2572		.1715	
12	.2572		.1715	
13	.2572		.1715	.2572
14	.2572			.2572
15			.1715	.2572
16			.1715	.2572
17		.0857	.2572	
18		.1715	.3429	
19		.2572	.3429	.3429
20		.1715	.3429	.3429
21		.1715	.2572	
22		.1715	.2572	
23	.2543	.1715	.2572	
24	.1696		.1715	.2572
Max	.6001	.2572	.3429	.5144
Min	.1696	.0857	.1715	.2572
Avg	.3266	.1715	.2338	.3062

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074002 / 33 KV ANDERA

Feeder No / Name : 203 / 11 KV MANGRUL

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-JUN-18
HR	Load (MW)
24	.1357
Max	.1357
Min	.1357
Avg	.1357

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074008 / 33 KV DEULGAON RAJA

Feeder No / Name : 200 / Station Transformer
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.2204
Max	.2204
Min	.2204
Avg	.2204

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074008 / 33 KV DEULGAON RAJA

Feeder No / Name : 201 / 11 KV DRAJA TOWN-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.5935
Max	.5935
Min	.5935
Avg	.5935

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287]

BU 2879

Substation No/ Name :- 074008 / 33 KV DEULGAON RAJA

Feeder No / Name : 202 / 11 KV SRAJA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3841	.285	.2267	.3437	.3462	.2751	.4001
2	.3841	.298	.1989	.3041	.4199	.2751	.3391
3	.3841	.298	.1677	.3048	.3812	.3475	.2949
4	.4024	.298	.1638	.2984	.4199	.3765	.3113
5	.4024	.3715	.192	.3277	.4666	.4458	.3429
6		.4534	.2204	.4239	.4923	.4344	
7		.4405	.2713	.5487	.5068	.4199	
8		.3902	.2343	.503	.5001	.4199	.0781
9	.6036	.4252	.2713	.4586	.4858		.1094
10	.3772	.3418	.2458	.4001	.3401		.1562
11	.2462	.2892	.2429	.415	.2372		.2622
12	.2705	.2606	.2622	.3109	.2294		.426
13	.306	.2606	.3315	.2846	.2429	.2675	.4428
14			.3688	.3475	.2372	.2172	
15	.3812		.4115	.3163	.2846		
16	.3812			.3841			.3277
17			.3277	.3041	.4062	.4001	.3768
18		.0781	.4049	.3024	.4915	.5121	.3932
19		.0983	.4641	.3155	.583	.6687	
20		.0678	.5087	.3418	.5801	.6401	
21		.0914	.4801			.6554	
22		.3563	.4973	.3155	.2606	.6562	
23		.3353	.426	.3024	.2675	.5761	
24	.4287	.2724	.2458	.4001	.3286	.2572	.4877
Max	.6036	.4534	.5087	.5487	.583	.6687	.4877
Min	.2462	.0678	.1638	.2846	.2294	.2172	.0781
Avg	.3809	.2856	.3115	.3588	.3867	.4358	.3166

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287]

BU 2879

Substation No/ Name :- 074008 / 33 KV DEULGAON RAJA

Feeder No / Name : 203 / 11 KV DRJA TOWN-2

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7796	.3887	.5601	.5304			.4858
2	.7796	.3757	.4807	.4801			.3521
3	.7682	.3368	.3437	.4748			.3239
4	.7682	.3239	.3681	.3763			.3841
5	.7087	.298	.4144	.4424			.4801
6		.298	.5761	.5144			.6859
7		.3757		.6344		.535	.5243
8		.3094	.5243	.5487	.9145	.5418	.5258
9	.961	.4199	.5138	.5487	.7682		.5304
10	.7095	.5647	.3441		.7316		.5487
11	.5546	.5792		.5304	.5853		.5487
12		.5937	.4687	.5487	.5182		.567
13		.5792	.5243	.5487	.5344		.7682
14				.5853	.5506		.9511
15	.6371		.6706	.6219	.583		.8688
16	.6226		.6203	.2115			.8596
17			.5668		.6478	.7287	
18		.4572	.6036	.5502	.6539	.7537	.7133
19		.5182	.6554	.5792	.7545	.7545	
20		.5868	.7377	.5792	.6882	.7373	
21		.6249	.6802			.7545	
22		.6882	.6097	.7375	.6622	.7202	
23	.2715	.6783	.5937	.823	.6171	.6874	
24	.8482	.3887	.6299	.5735			.5937
Max	.961	.6882	.7377	.823	.9145	.7545	.9511
Min	.2715	.298	.3437	.2115	.5182	.535	.3239
Avg	.7007	.4693	.5470	.5447	.6578	.6903	.5951

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287]

BU 2879

Substation No/ Name :- 074008 / 33 KV DEULGAON RAJA

Feeder No / Name : 204 / 11 KV JUMDA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1646	.1238	.0914	.0937	.0907	.1014	.0972
2	.1646	.1115	.0625	.08	.092	.0777	.1017
3	.1646	.1115	.0655	.0995	.0789	.0869	.0848
4	.1646	.1115	.0838	.1017	.0789	.1036	.0903
5	.1463	.1115	.0857	.1029	.092	.1052	.1174
6		.0991	.0972	.116	.1006	.1052	.1372
7		.0867	.1214	.1372	.1052	.1014	.1341
8		.0907	.1341	.1357	.1014	.1014	.0633
9	.1646	.092	.0625	.0983	.0949		.1134
10	.1183	.0789	.0633	.1107	.1107		.0633
11	.0867	.0789	.061	.0937	.1147		.0886
12	.096	.0526	.081	.0106	.0972		.0937
13	.1036	.0526	.0671	.128	.0949	.1052	.0983
14	.1036			.1097	.0972	.092	.0983
15	.1006		.048	.0949	.0648		.0819
16	.1052		.1341	.1097			.1086
17			.116	.0754	.008	.116	.0972
18		.0633	.1219	.0754	.116	.1341	.1147
19		.08	.128	.0754	.1029	.1326	
20		.1187	.1526	.088	.1174	.1296	
21		.1296	.1341			.1543	
22		.1457	.1296	.1132	.1067	.1457	
23		.1341	.1107	.088	.092	.128	
24	.3982	.1143	.0937	.1067		.092	.112
Max	.3982	.1457	.1526	.1372	.1174	.1543	.1372
Min	.0867	.0526	.048	.0106	.008	.0777	.0633
Avg	.1487	.0994	.0976	.0976	.0932	.1118	.0998

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074009 / 33 KV D MAHI

Feeder No / Name : 200 / Station Transformer
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.1526
Max	.1526
Min	.1526
Avg	.1526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074009 / 33 KV D MAHI

Feeder No / Name : 201 / 11 KV DMAHI

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
23	.2204
24	.2035
Max	.2204
Min	.2035
Avg	.2120

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074009 / 33 KV D MAHI

Feeder No / Name : 202 / 11 KV TAKARKHED
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	.2374
Max	.2374
Min	.2374
Avg	.2374

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074009 / 33 KV D MAHI

Feeder No / Name : 203 / 11 KV DIGRAS AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	.2543
Max	.2543
Min	.2543
Avg	.2543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074009 / 33 KV D MAHI

Feeder No / Name : 204 / 11 KV DMAHI GAONTHAN-
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18
HR	Load (MW)
24	.2353
Max	.2353
Min	.2353
Avg	.2353

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287]

BU 2879

Substation No/ Name :- 074009 / 33 KV D MAHI

Feeder No / Name : 205 / 11 KV TAKARKHED GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.2172
Max	.2172
Min	.2172
Avg	.2172

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287]

BU 2879

Substation No/ Name :- 074009 / 33 KV D MAHI

Feeder No / Name : 206 / 11 KV DIGRAS GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.2534
Max	.2534
Min	.2534
Avg	.2534

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074055 / 33 KV Giroli

Feeder No / Name : 200 / Station Transformer
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.1187
Max	.1187
Min	.1187
Avg	.1187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074055 / 33 KV Giroli

Feeder No / Name : 201 / 11 KV GIROLI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	.2883
Max	.2883
Min	.2883
Avg	.2883

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074055 / 33 KV Giroli

Feeder No / Name : 202 / 11 kv JUMDA AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	.2204
Max	.2204
Min	.2204
Avg	.2204

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074055 / 33 KV Girola

Feeder No / Name : 203 / 11 KV SRAJA AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	.2543
Max	.2543
Min	.2543
Avg	.2543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074055 / 33 KV Giroli

Feeder No / Name : 204 / 11 kv GIROLI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18
HR	Load (MW)
24	.2172
Max	.2172
Min	.2172
Avg	.2172

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074075 / SINGAONJAHAGIR (RU)

Feeder No / Name : 200 / Station Transformer
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.1696
Max	.1696
Min	.1696
Avg	.1696

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074075 / SINGAONJAHAGIR (RU)

Feeder No / Name : 201 / 11 KV SINGAON JAHANGIR SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	2.0586
Max	2.0586
Min	2.0586
Avg	2.0586

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074075 / SINGAONJAHAGIR (RU)

Feeder No / Name : 202 / 11KV PANGRI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.7539
Max	.7539
Min	.7539
Avg	.7539

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074075 / SINGAONJAHAGIR (RU)

Feeder No / Name : 203 / 11KVMEHUNARAJA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
23	.2229
24	.7818
Max	.7818
Min	.2229
Avg	.5024

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074075 / SINGAONJAHAGIR (RU)

Feeder No / Name : 204 / Water work D RAJA
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.1865
Max	.1865
Min	.1865
Avg	.1865

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074075 / SINGAONJAHAGIR (RU)

Feeder No / Name : 205 / Khalyal Gawhan Ag SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.2035
Max	.2035
Min	.2035
Avg	.2035

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074075 / SINGAONJAHAGIR (RU)

Feeder No / Name : 206 / Gargondi AG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
23	.2204
24	.2374
Max	.2374
Min	.2204
Avg	.2289

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074078 / 33 KV Shelgaon Atol

Feeder No / Name : 200 / Station Transformer
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.0848
Max	.0848
Min	.0848
Avg	.0848

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287]

BU 2879

Substation No/ Name :- 074078 / 33 KV Shelgaon Atol

Feeder No / Name : 201 / 11KV SHELGAON ATOL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1677	.1174	.12	.2347	.1174	.1372
2	.1715	.1677	.1174	.12	.2347	.1174	.1372
3	.1715	.1677	.1174	.12	.2347	.1174	.1372
4	.2058	.2012	.1174	.2058	.2515	.1677	.1372
5	.2572	.2515	.1677	.2058	.2515	.2515	.2058
6	.3772	.3018	.2515	.3086	.3185	.3521	.3258
7	.3429	.2683	.3018	.2915	.2515	.3353	.3086
8	.2401	.2683	.218	.2401	.2347	.3018	.2743
9	.1372	.1677	.1677	.2229	.1677	.2058	.2058
10	.1844	.1509	.12	.2058	.1174	.1543	.1715
11	.1844	.1341		.1677	.1174	.1372	.1372
12	.1844	.1341	.1029	.1006	.1174	.1029	.1372
13	.1509	.1341		.1006	.1174	.1029	.1372
14	.1509	.1341		.1006	.1006	.1029	.12
15		.1677	.12	.1174	.1006	.1372	.12
16		.1844	.1886	.1174	.1006	.1543	.1029
17		.2012	.2058	.218	.1341	.1715	.1715
18		.218	.2058	.218	.2012	.2229	.2401
19	.3185	.285	.2058	.2347	.2515	.2915	.2572
20	.3185	.2515	.1715	.2347	.2012	.2572	.3086
21	.3018	.2012	.1543	.2012	.1677	.1886	.2401
22	.3018	.1677	.1543	.2012	.1509	.1886	.1715
23	.2515	.1341	.1372	.2012	.1341	.1715	.1715
24	.1696	.2515	.1174	.12	.2012	.1174	.1543
Max	.3772	.3018	.3018	.3086	.3185	.3521	.3258
Min	.1372	.1341	.1029	.1006	.1006	.1029	.1029
Avg	.2304	.1963	.1648	.1822	.1830	.1861	.1879

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074078 / 33 KV Shelgaon Atol

Feeder No / Name : 202 / 11KV AMONA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2515	.1341	.1715	.2401	.1715	.1372
2	.1886	.2515	.1341	.1543	.2401	.1715	.1372
3	.1886	.2347	.1341	.1543	.2743	.1715	.1372
4	.2229	.2515		.1543	.2743	.1715	.1715
5	.2572	.3018		.2401	.2743	.3086	.2058
6	.3601	.3521	.2012	.3772	.3429	.4287	.3086
7	.2572	.3185	.2347	.3429	.2572	.3772	.3258
8		.3185	.2347	.3086	.2572	.3086	.3086
9	.1543	.1677	.2347	.3944	.2572	.2401	.2572
10	.1509	.1677	.1372	.2915		.1543	.1886
11		.1677		.2743		.1543	
12		.1844	.12	.2743		.1372	.2058
13		.2012		.2743		.1372	.1715
14	.1341	.218	.1029	.2915	.2572	.1543	.1543
15		.2012	.1372	.2915	.2058	.1543	
16		.2012	.2058		.1886	.1715	.2229
17		.2012	.2229	.2915	.2058	.1715	.2572
18		.1844	.2743	.2915	.2572	.2058	.3601
19	.1341	.2012	.2743	.2401	.2915	.2915	.2915
20	.3856	.1677	.2572	.3086	.2572	.2572	.2572
21	.3688	.1677	.2401	.2058	.2229	.1886	.2401
22	.3688	.1509	.2229	.2058	.2229	.1886	.1715
23	.3353	.1341	.2058		.2058	.1715	.1715
24	.2204	.3353	.1341	.2058	.2058	.2058	.1543
Max	.3856	.3521	.2743	.3944	.3429	.4287	.3601
Min	.1341	.1341	.1029	.1543	.1886	.1372	.1372
Avg	.2458	.2222	.1921	.2611	.2469	.2122	.2198

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287]

BU 2879

Substation No/ Name :- 074078 / 33 KV Shelgaon Atol

Feeder No / Name : 203 / 11 KV ISRUL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1677	.1174	.12	.2347	.1341	.12
2	.1543	.1677	.1174		.2347	.1341	.12
3	.1543	.1677	.1174	.12	.2347	.1341	.12
4	.1543	.2012		.1715	.2347	.1341	.12
5	.2229	.2012		.1715	.2347	.1677	.1543
6	.2572	.2347		.2572	.2683	.2012	.2743
7	.2743	.2347	.218	.2572	.2012	.2012	.2572
8	.2572	.2347	.2012	.2401	.2012	.218	.1543
9	.2572	.1677	.1677	.1715	.1677	.2058	.1715
10	.2347	.1677	.12	.1543	.1174	.1543	.1886
11	.2012	.1677	.1372	.1509	.1174	.1543	.1715
12		.1677	.1543	.1006	.1174	.1543	.1543
13	.1677	.1341	.1543	.1677	.1341	.1543	.1543
14	.1844	.1341	.1543	.1677	.1509	.1543	.1372
15		.1341	.1715	.1677	.1509	.1543	.1372
16		.1341	.2229	.1677	.1677	.1543	.1372
17		.1341	.2229	.2347	.1677	.1715	.1715
18		.1844	.2401	.2347	.2347	.2401	.2915
19	.2347	.1844	.2229	.2347	.285	.2915	.2915
20	.2347	.1677	.2058	.218	.2012	.2058	.2743
21	.2347	.1677	.1372	.2012	.1677	.1372	.2058
22	.2347	.1174	.1372	.2012	.1341	.1372	.1372
23	.218	.1174	.1372	.2012	.1341	.1372	.1372
24	.2543	.218	.1174	.12	.2012	.1341	.1372
Max	.2743	.2347	.2401	.2572	.285	.2915	.2915
Min	.1543	.1174	.1174	.1006	.1174	.1341	.12
Avg	.2150	.1712	.1654	.1840	.1872	.1694	.1758

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287]

BU 2879

Substation No/ Name :- 074078 / 33 KV Shelgaon Atol

Feeder No / Name : 204 / 11 KV ANCHARWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1677	.2012	.1715	.3353	.1341	.1715
2	.1543	.1677	.2012	.1715	.3353	.1341	.1715
3		.1677	.2012	.1886	.3688	.1341	.1715
4		.1677	.2012	.1886	.2515	.1341	
5		.2012	.2012	.2058	.2515	.1677	
6			.2347	.2401	.2515	.1844	.2229
7			.2683	.2743	.2347	.1844	.2572
8			.2683	.2915	.2012	.1844	.2401
9			.3018	.2401	.2012	.1886	.2401
10			.1715	.2229	.1677	.1886	.2572
11		.1174	.1715	.218	.1677	.1715	.2401
12		.1341	.1715	.1844	.1677	.1543	.2058
13	.0671	.1677	.1715	.4359	.2012		.2058
14	.0671	.2683	.1715	.4527	.2515	.2401	.2229
15		.2515	.2058	.4527	.2012	.2915	.2229
16		.2515		.1677	.2012	.3086	.2229
17		.2515		.218	.2012	.3258	.2229
18	.2012	.2515	.2572	.218	.2515	.3258	.2229
19	.2012	.285	.2401	.5365	.2515	.3086	.2401
20	.2012	.2515	.2058	.5197	.2012	.3429	.1886
21	.2012	.2515	.1886	.4191	.1677	.3601	.2058
22	.2012	.2515	.1715	.4191	.1341	.2229	.1886
23	.1677	.2012	.1715	.4024	.1341	.2058	.1715
24	.2374	.1677	.2012	.1715	.3353	.1341	.2058
Max	.2374	.285	.3018	.5365	.3688	.3601	.2572
Min	.0671	.1174	.1715	.1677	.1341	.1341	.1715
Avg	.1685	.2092	.2081	.2921	.2277	.2185	.2136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074095 / 33 kv Isrul

Feeder No / Name : 200 / Station Transformer
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.1017
Max	.1017
Min	.1017
Avg	.1017

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074101 / 33 KV Narayankhed

Feeder No / Name : 200 / Station Transformer
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.1526
Max	.1526
Min	.1526
Avg	.1526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287]

BU 2879

Substation No/ Name :- 074101 / 33 KV Narayankhed

Feeder No / Name : 201 / Naryankhed Gawthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2587	.2402	.3142	.2957	.2987		.2957
2	.2587	.2427	.2957	.2772	.2801		.2957
3	.2614		.2987	.2801	.2987		.2957
4	.2987	.1307	.3174	.2987	.3326		.3361
5	.3361	.132	.415	.4108	.3881		.4854
6	.7922	.2452	.7922	.8589	.8962		.7655
7	.8215	.3395	.8775	.4108	.9149		.8029
8	.7468	.2801	.8589	.8402			.7655
9	.5788	.1886	.6908	.6535			.5975
10	.3326	.3395	.4294	.4294	.4854		.4294
11	.2402		.3734	.2987	.3142		.2957
12	.2534		.3475	.2772	.2896		.2561
13	.2561		.2743	.3109	.2743	.2926	.2378
14			.3077	.2801	.2561	.2896	.2587
15			.2957	.3361		.3077	.2587
16		.5914	.3511	.3174	.2957	.3439	.2801
17		.7762	.462	.4294	.4066	.462	.4435
18		.5914	.6722	.5975	.5975		.6348
19		.499	.7095	.6908	.7282	.7023	.7095
20	.4066	.4294	.6161	.5601	.5914	.5601	.5415
21	.3292	.3841	.3921	.3881		.4066	.4108
22	.2772	.3326	.3361	.3547		.3361	.3511
23	.2587	.3142	.3142	.3174		.3174	.3142
24	.2587	.2402	.3142	.2957	.2987		.3174
Max	.8215	.7762	.8775	.8589	.9149	.7023	.8029
Min	.2402	.1307	.2743	.2772	.2561	.2896	.2378
Avg	.3870	.3498	.4607	.4254	.4415	.4018	.4325

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287]

BU 2879

Substation No/ Name :- 074101 / 33 KV Narayankhed

Feeder No / Name : 202 / Nimgaon Guru Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0293	.0267		.0297	.0293		.0328
2	.0297	.0274		.0312	.0297		.0332
3	.0305	.0278		.032	.0297		.0339
4	.0312	.0286		.0328	.029		.0343
5	.048	.029		.0343	.0316		.0343
6	.0543	.0532		.0537	.0554		.0358
7				.3185	.3311		.1829
8				.3765			.2408
9				.4458			.2675
10				.4694			.333
11				.3807	.2824		.306
12				.3666	.2641		.3475
13				.3807	.3041	.2429	.3102
14				.4089	.3227	.2143	.3102
15			.5201				.3102
16		.439	.602				
17			.5792				
18			.5575				
19			.4633	.0564		.0543	.0549
20	.3567		.4033	.0533	.0537	.0332	.0354
21	.3368		.3978	.0297		.0274	.0335
22	.3191		.3734	.0301	.0469	.0312	.0312
23	.0255		.0282	.0293		.0309	.0305
24	.029	.0259		.029	.0293		.0309
Max	.3567	.439	.602	.4694	.3311	.2429	.3475
Min	.0255	.0259	.0282	.029	.029	.0274	.0305
Avg	.1173	.0822	.4361	.1794	.1314	.0906	.1442

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287]

BU 2879

Substation No/ Name :- 074101 / 33 KV Narayankhed

Feeder No / Name : 203 / 11 kv Digras Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.2534					
8	.3155					
9	.3517					
10	.3384					
11	.3475					
12	.362					
13	.3521	.2195				
14		.1783				
15			.2881		.0754	.1269
16			.2462	.1669	.0777	.1429
17			.2751	.1947	.1021	.1692
18			.2705	.1646	.1252	.1907
19			.2841	.1509	.1113	.176
20			.1669	.1383	.1235	.1429
21			.1623		.0777	.141
22			.16	.1097	.0743	.1036
Max	.362	.2195	.2881	.1947	.1252	.1907
Min	.2534	.1783	.16	.1097	.0743	.1036
Avg	.3315	.1989	.2317	.1542	.0959	.1492

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 077010 / 132 KV DEOULGAON MAHI(WAKI
KD.Feeder No / Name : 400 / 33/0.4 ,Stn T/F
Feeder KV- 33 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.763
Max	.763
Min	.763
Avg	.763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 077010 / 132 KV DEOULGAON MAHI(WAKI
KD.

Feeder No / Name : 401 / 33 KV NIMGAON

PURELY LIS FEEDERS

Feeder KV- 33 / INCOMING

DATE	01-JUN-18
HR	Load (MW)
24	1.2717
Max	1.2717
Min	1.2717
Avg	1.2717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287]

BU 2879

Substation No/ Name :- 077010 / 132 KV DEOULGAON MAHI(WAKI
KD.Feeder No / Name : 403 / 33 KV MANDAPGAON-DAGADWADI
Feeder KV- 33 / INCOMING

PURELY LIS FEEDERS

DATE	01-JUN-18
HR	Load (MW)
24	6.6301
Max	6.6301
Min	6.6301
Avg	6.6301

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 077010 / 132 KV DEOULGAON MAHI(WAKI
KD.

Feeder No / Name : 404 / VASANTNAGAR-BHAROSA

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.763
Max	.763
Min	.763
Avg	.763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 077010 / 132 KV DEOULGAON MAHI(WAKI
KD.

Feeder No / Name : 405 / 33 KV WAKI BK

PURELY LIS FEEDERS

Feeder KV- 33 / INCOMING

DATE	01-JUN-18
HR	Load (MW)
24	1.3226
Max	1.3226
Min	1.3226
Avg	1.3226

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074034 / 33KV S/S RAYPUR

Feeder No / Name : 200 / Station Transformer

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
8	.0747
24	.0373
Max	.0747
Min	.0373
Avg	.056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074034 / 33KV S/S RAYPUR

Feeder No / Name : 201 / 11 KV PANGRI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4344	.4706	.0362	.0514	.0343	.0362
2	.4344	.4706	.0362	.0514	.0343	.0362
3	.4344	.4887	.0362	.0514	.0343	.0362
4	.4525		.0362	.0514	.0514	.0362
5	.4706		.0362	.0514	.0514	.0543
6	.543		.0362	.0857	.0686	.0543
7	.6878	.4525	.0362	.0514	.0686	.0543
8	.3982	.724	.0362	.0514	.0857	
9	.0343	.6335	.4458		.3429	.3982
10	.0343	.0362	.6001	.6001	.3601	.5068
11	.0343			.6516	.4344	.5068
12	.0343		.6001	.5658	.5792	.543
13	.0343		.5487	.3772	.543	.5973
14	.0343	.0362	.4973	.5658	.5068	.4801
15	.0343	.0362	.463	.5316	.543	.4973
16	.0343	.0362	.5487	.5658	.5249	.4973
17	.0343	.0362	.0514	.0343	.0543	.0514
18		.0362	.0686	.0514	.0543	.0514
19	.0343	.0362	.0686	.0686	.0724	.0514
20	.0343	.0362	.0686	.0514	.0724	.0514
21	.0343	.0362	.0514	.0514	.0724	.0514
22	.0343	.0362	.0514	.0514	.0724	.0514
23	.3429	.0362	.0343	.0343	.0543	.0514
24	.4344	.4525	.0362	.0514	.0343	.0362
Max	.6878	.724	.6001	.6516	.5792	.5973
Min	.0343	.0362	.0343	.0343	.0343	.0362
Avg	.2208	.2273	.1923	.2042	.1979	.2057

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074034 / 33KV S/S RAYPUR

Feeder No / Name : 202 / 11KV RAIPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0362	.0362	.3077	.3772	.2743	.2534
2	.0362	.0362	.2534	.3772	.2743	
3	.0362	.0362	.2534	.3772	.2915	
4	.0362	.0362	.3258	.3944	.2915	
5	.0362	.0362	.5068	.4287	.3772	
6	.0362	.0362	.6335	.6001	.5144	
7	.0362	.0362	.6335	.6859	.6859	.5792
8	.0362	.0362	.6516	.6001	.6001	.6154
9	.3086	.181	.6173	.0343	.0171	.0362
10	.4115	.362	.0343		.0343	.0362
11	.5144	.362				.0362
12	.5144			.2572	.0343	.0362
13					.0343	
14					.0343	
15	.3429	.6335	.0343		.0343	.0343
16	.5144	.6335	.0343		.0343	.0343
17	.0343	.0181	.0343	.0514	.0343	.0343
18	.0343	.0181	.0343	.0514	.0343	.0343
19	.0343	.0181	.0514	.0514	.0343	.0343
20	.0343	.0181	.0343	.0686	.0343	.0343
21	.0343	.0181	.0343	.0514	.0343	.0343
22	.0343	.0181	.0514	.0514	.0343	.0343
23	.0343	.181	.3086	.3086	.2401	.4115
24	.0366	.0362	.2534	.3601	.2743	.2534
Max	.5144	.6335	.6516	.6859	.6859	.6154
Min	.0343	.0181	.0343	.0343	.0171	.0343
Avg	.1442	.1327	.2544	.2848	.1849	.1489

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074034 / 33KV S/S RAYPUR

Feeder No / Name : 203 / 11KV SAILANI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0724	.0857	.0724	.4344	.5144	.3429	.3258
2	.0724	.0686	.0724	.4344	.4801	.3429	.362
3	.0724	.0686	.0724	.4706	.4287	.3429	.362
4	.0724	.0857	.0724	.4706	.4287	.3429	.3982
5	.0905	.0686	.0724	.543	.3772	.4287	.4706
6	.1086	.1029	.1086	.5973	.7202	.463	.6697
7	.1086	.0857	.0724	.6335	.7545	.6516	.6878
8	.0905	.0686	.1267	.7059	.6173	.5316	.6516
9	.3601	.4287	.4163	.0686	.0514	.0514	.0905
10	.5487	.5316	.543	.0686	.0343	.0514	.0724
11	.583	.5144	.5792	.0514	.0343	.0543	.0543
12	.5487		.0724		.0514	.0543	.0543
13		.5487		.0686	.0686	.0543	.0543
14	.5487	.5487			.0686	.0543	.0514
15	.4801	.5487		.0514	.0514	.0543	.0686
16	.5316	.463	.724	.1372	.0514	.0362	.0514
17	.1029	.0514		.1372	.0686	.0543	
18	.1372	.0857	.0905	.1372	.0857	.0724	
19	.1543	.0857	.1267	.0686	.0857	.0905	.0686
20	.0857		.0905	.1372	.0857	.0905	.0686
21	.0857	.0686	.0905	.1543	.0686	.0905	.0686
22	.0686	.0686	.0724	.0857	.0857	.0905	.0686
23	.0686	.0686	.4344	.5144		.3258	.2915
24	.0724	.0686	.0724	.4344	.5144	.3086	.3258
Max	.583	.5487	.724	.7059	.7545	.6516	.6878
Min	.0686	.0514	.0724	.0514	.0343	.0362	.0514
Avg	.2202	.2143	.1991	.2911	.2490	.2075	.2417

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074034 / 33KV S/S RAYPUR

Feeder No / Name : 204 / 11 KV RAIPUR GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4294	.4344	.4024	.3944	.3944	.4527
2	.4294	.4344	.4338	.3772	.3944	.4481
3	.4338	.4525	.462	.3944	.4115	.4481
4	.4527	.4344	.4572	.4115	.4287	.4805
5	.4715	.4525	.5121	.4287	.5144	.5487
6	.5175	.5792	.6335	.583	.583	.6036
7	.5415	.5792	.5847	.5487	.5658	.6219
8	.5175	.543	.5658	.4801	.5658	.5487
9	.4458	.362	.4115	.4458	.4801	.4706
10	.3772	.4163	.3601	.3772	.4458	.3982
11	.3601	.362	.3086	.3086	.4108	.362
12	.3772	.362	.2743		.3734	.3077
13	.3258	.3439	.2915		.3326	.3439
14	.3601	.3258	.3258		.3361	.3258
15	.3429	.362	.3601		.3475	.2915
16	.3601	.3801	.3772		.3696	.3429
17	.3944	.4706	.4458	.4287	.4108	.4801
18	.4801	.5249	.4458	.4458	.5175	.463
19	.6001	.5068	.5144	.5658	.5853	.463
20		.5611	.6001	.6001	.5729	.5144
21	.4973	.4525	.4973	.4801	.5281	.4458
22	.463	.4525	.4458	.463	.5093	.4287
23	.4287	.4338	.4115	.4458	.4904	.3944
24	.4294	.4525	.4338	.3944	.4115	.4527
Max	.6001	.5792	.6335	.6001	.5853	.6219
Min	.3258	.3258	.2743	.3086	.3326	.2915
Avg	.4363	.4449	.4398	.4512	.4575	.4432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074034 / 33KV S/S RAYPUR

Feeder No / Name : 205 / 11 KV SAILANI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4706	.4344	.4344	.4458	.463	.4706
2	.4525	.4706	.4344	.4287	.4458	.4706
3	.4706	.5249	.4344	.463	.4801	.5068
4	.5068	.6335	.5068	.583	.5316	.543
5	.5792	.724	.6154	.6687	.6859	.724
6	1.0136	.9412	1.0317	1.0631	1.0288	1.086
7	.9774	1.0136	1.0498	.9088	1.046	1.0136
8	.8688	.8688	.8688	.8059	.8745	.905
9	.6859	.7059	.583	.7373	.7202	
10	.6173	.6697	.583	.6173	.6001	.724
11	.4973	.5249	.4801	.4973	.4706	.4887
12	.4973	.4344	.4287	.4801	.3982	.4887
13			.4458	.4287	.362	.4887
14	.463	.4344		.4801	.362	.4287
15	.463	.4706	.5144	.3944	.3801	.4973
16	.4973	.5611	.5316	.4115	.4163	.5144
17	.6001	.7059	.5658	.5144	.543	.6516
18	.7373	.7964	.7888	.6687	.8507	.7716
19	.8059	.7964	.9259	.9088	.905	.7373
20	.7888	.7421	.7545	.7888	.7964	.7468
21	.5658	.5973	.5658	.5316	.6154	.5658
22	.4973	.543	.5316	.4801	.5068	.4973
23	.4458	.4887	.463	.5144	.5068	.463
24	.4887	.4525	.4525	.4458	.463	.4706
Max	1.0136	1.0136	1.0498	1.0631	1.046	1.086
Min	.4458	.4344	.4287	.3944	.362	.4287
Avg	.6083	.6319	.6083	.5944	.6022	.6197

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074034 / 33KV S/S RAYPUR

Feeder No / Name : 206 / Pangri GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1433	.1448	.1448	.12	.1372	.1372
2	.1417	.1448	.1448	.1372	.1372	.1372
3	.1433	.1629	.1629	.1372	.1543	.1372
4	.1772	.2715	.2534	.1715	.1715	.1715
5	.2103	.3077	.3258	.2229	.2058	.2401
6	.2401	.2896	.4344	.3429	.2743	.3429
7	.2572	.362	.333	.3772	.2058	.3086
8	.2572	.2715	.2743	.3429	.2058	.2572
9	.2401	.2172	.1715		.2401	.181
10	.1715	.2172	.1715	.2058	.1715	.1267
11	.1543	.1267	.1372	.12	.1372	.1086
12	.1543	.1267	.1372	.12	.1372	.1086
13	.1543	.1448	.12	.1715	.1372	.1086
14	.1372	.1448	.1372	.1372	.12	.1267
15	.1543	.181	.1715	.1715	.1372	.1372
16		.181	.1715	.1715	.1372	.1543
17	.1715	.181	.2229	.2058	.2058	.2229
18		.2715	.2743	.2401	.2743	.2915
19	.3429		.3258	.3086	.3086	.2401
20	.2572	.2534	.2743	.2743	.2454	.2058
21	.2229	.1629	.2058	.1886	.1715	.1543
22	.1543	.1629	.1543	.1543	.1543	.1543
23	.1543	.1372	.1372	.1715	.1372	.1372
24	.1417	.1448	.1448	.1372	.1543	.1372
Max	.3429	.362	.4344	.3772	.3086	.3429
Min	.1372	.1267	.12	.12	.12	.1086
Avg	.1901	.2003	.2096	.2013	.1817	.1803

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074056 / 33KV S/S DHAMANGAON DEO

Feeder No / Name : 202 / 11 KV DHAMANGAON AG

FEEDER SEPERATION/PURE AG

FEEDER Feeder KV- 11 /

OUTGOING

DATE	04-JUN-18
HR	Load (MW)
1	1.2071
2	1.2574
3	1.3413
4	1.4251
5	1.5089
6	1.5089
7	1.5592
8	1.3077
24	1.1401
Max	1.5592
Min	1.1401
Avg	1.3617

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074056 / 33KV S/S DHAMANGAON DEO

Feeder No / Name : 203 / 11 KV MASRUL AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	04-JUN-18
HR	Load (MW)
1	.0324
2	.0486
3	.0486
4	.0486
6	.0648
7	.0648
24	.0324
Max	.0648
Min	.0324
Avg	.0486

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074056 / 33KV S/S DHAMANGAON DEO

Feeder No / Name : 204 / 11 KV DOMRUL AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	04-JUN-18
HR	Load (MW)
1	.2343
2	.25
3	.2812
4	.3125
5	.3125
6	.3125
7	.3125
8	.3125
24	.1875
Max	.3125
Min	.1875
Avg	.2795

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074056 / 33KV S/S DHAMANGAON DEO

Feeder No / Name : 205 / 11 KV JANUNA AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	04-JUN-18
HR	Load (MW)
1	.0686
2	.0686
3	.0857
4	.0857
5	.0857
6	.1029
7	.1029
24	.0686
Max	.1029
Min	.0686
Avg	.0836

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074071 / 33/11KV S/S chandol

Feeder No / Name : 200 / Station Transformer

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.1543
Max	.1543
Min	.1543
Avg	.1543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074071 / 33/11KV S/S chandol

Feeder No / Name : 201 / GFSS CHANDOL

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3012	.3326	.3511	.3361	.3734	.3658	.3658
2	.3045	.3696	.3511	.3361	.3734	.3658	.3696
3	.3189	.4251	.4251	.3361	.3734	.3841	.3696
4	.3403	.4805	.4805	.3734	.4854	.4207	.4207
5	.3761	.5175	.5544	.5601	.5544	.5068	.4938
6	.5731	.5544	.6283	.7023	.6653	.7783	.7682
7	.5014	.5914	.5544	.6653	.6283	.724	.724
8	.4835	.5359	.5175	.5544	.6653	.7133	.6767
9	.4298	.5544	.4066	.5175	.5544	.5304	.5359
10		.4435	.3326	.4435	.3696	.4207	.3841
11		.4066	.3326	.4066	.3658	.3801	.3696
12		.3881	.3696	.3696	.2896	.3258	.3326
13		.3881	.2957	.3696	.3109	.2743	.3511
14		.3881	.2957	.3326	.2835	.2743	.3326
15		.4066	.2957	.3326	.3077	.3258	.3142
16		.4435	.3326	.3326		.3292	.3326
17		.4805	.4066	.3696		.3881	.4435
18	.4805	.5175	.4805	.4805	.5373	.5487	.462
19	.5914	.499	.5601	.5601	.5487	.6099	.4805
20	.462	.5359	.5601	.5601	.6099	.5544	.499
21	.4066	.4435		.5601	.499	.4435	.4251
22	.4066	.3881		.4854	.4163	.3881	.4108
23	.3696	.3696	.3361	.3921	.3801	.3658	.3881
24	.3077	.3326	.3511	.3361	.4108	.362	.3696
Max	.5914	.5914	.6283	.7023	.6653	.7783	.7682
Min	.3012	.3326	.2957	.3326	.2835	.2743	.3142
Avg	.4158	.4497	.419	.4464	.4547	.4492	.4425

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074071 / 33/11KV S/S chandol

Feeder No / Name : 202 / Chandol AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1638	.037	.2218	.2987	.1867	.1966	.1823
2	.1311	.0554	.2587	.2987	.1867	.1989	.1823
3	.1147	.0739	.3696	.2987	.1867	.1966	.1802
4	.116	.0739	.4066	.2987	.1867	.2155	.1966
5	.116	.0739	.4435	.3696	.3696	.2267	.2267
6	.1989	.0924	.4805	.4805	.5544	.4534	.427
7	.2267	.0924	.4435	.462	.6283	.4843	.463
8	.1802	.0739	.4251	.4066	.4435	.4218	.3906
9		.0924	.4251	.2587	.4066	.2778	.3681
10		.1478	.3696	.3696	.4066	.3048	.3593
11		.1663	.3696	.3696	.3637	.0514	.4066
12		.1478	.5175	.3696	.3125	.0532	.3326
13		.1848	.4066	.3696	.3125		.3142
14		.1848	.3696	.3696	.052	.2591	.3511
15	.1663	.2033		.3326	.0526	.3437	.3326
16		.2218	.4066	.3696	.3361	.3593	.3142
17	.1294	.2218	.1478	.1848	.2401	.1907	.1867
18	.1109	.2402	.2218	.1848	.1753	.2353	.2054
19	.3326	.2587	.2614	.2614	.2629	.2481	.2218
20	.1848	.3326	.2614	.2614	.2303	.2279	.2218
21	.1478	.2587		.1867	.2835	.156	.1663
22	.1109	.1663		.1867	.1715	.156	.1663
23	.0554	.1848	.2614	.3361	.1823	.1802	.1848
24	.1823	.037	.2218	.2987	.2054	.1966	.1844
Max	.3326	.3326	.5175	.4805	.6283	.4843	.463
Min	.0554	.037	.1478	.1848	.052	.0514	.1663
Avg	.1569	.1509	.3471	.3176	.2807	.2450	.2735

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074071 / 33/11KV S/S chandol

Feeder No / Name : 203 / Bhadgaon AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	03-JUN-18
HR	Load (MW)
11	.3696
12	.5175
Max	.5175
Min	.3696
Avg	.4436

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074071 / 33/11KV S/S chandol

Feeder No / Name : 204 / Saoli GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.0554	.0554	.056	.056	.0554	.056
2	.0549	.0554	.0554	.056	.056	.0554	.056
3	.0549	.1109	.0739	.056	.056	.0554	.056
4	.0549	.0739	.1109	.0747	.0747	.0739	.0747
5	.0724	.1294	.1478	.1109	.112	.1109	.0934
6	.1463	.1663	.1663	.1663	.1663	.1478	.1478
7	.1097	.1109	.1109	.1109	.1294	.1294	.1294
8	.0549	.0924	.0934	.0924	.1109	.112	.0924
9	.0716	.0554	.0739	.0554	.1109	.0747	.0554
10	.0537	.037	.037	.0554	.1109	.037	.0554
11	.056	.037	.037	.0554	.0185	.0554	.0554
12	.037	.037	.0554	.0554	.0185	.037	.0554
13	.037	.037	.0554	.0554	.0185	.037	.0554
14	.0554	.037	.0554	.0554	.0549	.0185	.037
15	.0739	.037	.0554	.0554	.0366	.037	.0554
16	.0739	.037	.0739	.0554	.037	.037	.0739
17	.0739	.037	.0739	.0924	.0739	.0554	.0739
18	.0739	.0739	.0739	.0924	.0924	.0924	.0739
19	.1109	.0924	.0934	.0934	.0747	.0934	.0747
20	.0739	.0739	.0934	.0747	.0934	.0747	.0739
21	.0739	.0739		.0747	.056	.0554	.0554
22	.0739	.0739		.0747	.0554	.0739	.0554
23	.0554	.0739	.056	.056	.0554	.0554	.0554
24	.0537	.0554	.0554	.056	.056	.0554	.0554
Max	.1463	.1663	.1663	.1663	.1663	.1478	.1478
Min	.037	.037	.037	.0554	.0185	.0185	.037
Avg	.0688	.0693	.0774	.0742	.0718	.0679	.0695

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074071 / 33/11KV S/S chandol

Feeder No / Name : 205 / 11 KV SAWALI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0739	.0747	.1494	.1307	.1134	.116
2	.0514	.0739	.0739	.1494	.1307	.1147	.116
3	.0514	.0739	.0747	.1494	.1307	.1134	.1326
4	.0514	.1109	.0924	.1494	.1307	.1457	.1311
5	.0686	.1294	.1294	.1848	.1848	.1619	.1781
6	.12	.1294	.1494	.2957	.4066	.3041	.3077
7	.1029	.1109	.1294	.2957	.4435	.3637	.3437
8	.1029	.1109	.1109	.2957	.4066	.2214	.3005
9	.1372	.1478	.1848	.0924	.0739	.0857	.0867
10	.1372	.3142	.168	.0924	.0739	.0686	.0701
11	.1848	.3696	.2218	.0739	.0701	.0514	.0739
12	.2218	.3696	.2218	.0739	.0693	.0709	.0747
13	.1663	.3326	.2218	.0739	.0526	.0701	.0747
14	.1848	.2587	.2218	.0739	.0532	.0526	.0554
15	.1848	.1294		.0739	.0716	.1372	.0554
16	.2033	.0739		.0554	.0716	.052	.0739
17	.0924	.0554	.1109	.0739	.0895	.0709	.0924
18	.1109	.0554	.1109	.0739	.0886	.0886	.1109
19	.1109	.0554	.112	.0934	.0905	.1254	.1294
20	.0924	.1109	.0934	.0934	.0905	.0895	.1109
21	.0739	.0924		.0747	.0895	.0701	.0924
22	.056	.0934		.1307	.0693	.0701	.0924
23	.0554	.0924	.1494	.1307	.1006	.1006	.1109
24	.0514	.0554	.0739	.1494	.1307	.1147	.1006
Max	.2218	.3696	.2218	.2957	.4435	.3637	.3437
Min	.0514	.0554	.0739	.0554	.0526	.0514	.0554
Avg	.1110	.1425	.1363	.1291	.1354	.1190	.1263

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074071 / 33/11KV S/S chandol

Feeder No / Name : 206 / 11 KV DHANGARPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0332	.0554	.0739	.0373	.056	.0526	.0526
2	.0332	.0554	.0739	.0373	.056	.0532	.052
3	.0332	.0739	.0924	.0373	.056	.0532	.0532
4	.0332	.1109	.0924	.0747	.0747	.0526	.0701
5		.1478	.0739	.0739	.1109	.0526	.0876
6	.0829	.1294	.0924	.1294	.1109	.104	.104
7		.1478	.1478	.1109	.0924	.0867	.104
8		.1663	.1848	.0739	.0739	.0867	.0701
9		.037	.0554	.1294	.2957	.2343	.2105
10		.0185	.037	.1848	.2957	.2785	.2429
11		.0185	.037	.2587	.3239	.2561	.2772
12			.037	.2587	.2688	.2105	.2772
13	.0924	.037	.037	.2587	.2267	.2241	.2587
14		.037		.2587		.192	.2218
15	.037	.0185		.2218		.1852	.1848
16		.037	.037	.2587		.1524	.168
17		.037	.037	.0924		.0686	.037
18	.2033	.037	.0924	.0924		.0532	.0373
19	.037	.037	.0934	.0934		.0886	.0554
20	.037	.037	.0934	.0934	.0724	.0716	.0739
21	.037	.037		.056	.0724	.0532	.0554
22	.037	.037		.056	.0709	.0526	.0554
23	.037	.0739	.0373	.056	.0532	.052	.0554
24	.0328	.037	.0739	.0373	.056	.0526	.0526
Max	.2033	.1663	.1848	.2587	.3239	.2785	.2772
Min	.0328	.0185	.037	.0373	.0532	.052	.037
Avg	.0547	.0619	.0750	.1242	.1315	.1153	.1190

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074035 / 33KV SAKHARKHERDA

Feeder No / Name : 201 / 11KV SAKHARKHERDA AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.061		.144
2				.061		.128
3				.061		.128
4				.0914		.112
5				.1219		
6				.2134		
7				.2286		.2241
8			.1829	.1829		.3361
9	.1524				.2134	
10	.2896					
14	.2439					
16		.0914				
23			.0914		.3018	
24				.061		.192
Max	.2896	.0914	.1829	.2286	.3018	.3361
Min	.1524	.0914	.0914	.061	.2134	.112
Avg	.2286	.0914	.1372	.1202	.2576	.1806

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074035 / 33KV SAKHARKHERDA

Feeder No / Name : 202 / 11KV SHENDURJAN AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0457		.048
2					.0457		.048
3					.0457		.048
4					.0457		.048
5					.0457		
6					.061		.096
7					.0914		.112
8				.1219			.096
9	.061		.0457				
10	.0914		.061				
12		.0914					
13		.0762					
14	.1524						
23				.061		.0671	
24	.0762				.0457		.064
Max	.1524	.0914	.061	.1219	.0914	.0671	.112
Min	.061	.0762	.0457	.061	.0457	.0671	.048
Avg	.0953	.0838	.0534	.0915	.0533	.0671	.07

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074035 / 33KV SAKHARKHERDA

Feeder No / Name : 203 / 11KV TANDULWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.061					
2	.061					
4		.061				
9			.061	.0457	.0305	.064
10			.061	.061	.048	.048
11			.0914			
12			.0914		.048	.0305
13			.061		.048	
14			.061		.048	.0457
16				.0914	.048	.0457
24	.0457	.0457				
Max	.061	.061	.0914	.0914	.048	.064
Min	.0457	.0457	.061	.0457	.0305	.0305
Avg	.0559	.0534	.0711	.0660	.0451	.0468

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074035 / 33KV SAKHARKHERDA

Feeder No / Name : 204 / 11 KV DAREGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1219				
2	.1219				
3	.1067				
4	.1219				
5	.1524				
6	.1677				
7	.1829				
8	.1219				
9			.061	.0914	.096
10			.0914	.112	.128
11				.128	
12		.1524		.096	.1372
13		.1219		.096	
14		.1524		.096	.0914
15				.08	
16			.1524	.096	.1219
19		.1524			
24	.1219				
Max	.1829	.1524	.1524	.128	.1372
Min	.1067	.1219	.061	.08	.0914
Avg	.1355	.1448	.1016	.0994	.1149

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074035 / 33KV SAKHARKHERDA

Feeder No / Name : 206 / 11KV SHENDURJAN GFSS
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058				.2058		.2058
2					.2058		.1886
3	.2058				.2058		.2058
4	.2401		.2134		.2401		.2401
5	.3601				.3944		.3601
6	.5144		.4115		.5316	.4268	.5441
9	.3601			.3658	.3944		.4287
10	.2229	.2134	.1981	.2743	.2401		.2401
11				.1886		.1886	
12		.1524		.1886			.1677
13				.1886		.1715	
14	.1829	.1372		.2058		.1715	.1524
15						.2058	
16		.1829				.2401	.2134
17						.2572	
18						.3601	.3048
19		.3048		.4287			
20				.4115		.3429	.3048
21				.2915		.2743	
22		.2134		.2401		.2572	.2286
23				.2229		.2254	
24	.2058		.1829		.2058		.2058
Max	.5144	.3048	.4115	.4287	.5316	.4268	.5441
Min	.1829	.1372	.1829	.1886	.2058	.1715	.1524
Avg	.2775	.2007	.2515	.2733	.2915	.2601	.2661

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074035 / 33KV SAKHARKHERDA

Feeder No / Name : 207 / 11 KV SAKHARKHERDA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2689				1.3032		1.0974
2	1.2689				1.3032		1.0974
3	1.286				1.3032		1.166
4	1.4403		1.2193		1.3717		1.2689
5	1.7833				1.8176		1.8861
6	2.1091	1.89	2.1338		2.3663		2.2291
9	1.7318			1.6766	1.7147	1.829	1.6632
10	1.5604	1.0974	1.2193	1.4327	1.3203		1.286
11				1.166		.9945	
12		1.1126		1.0631		.8059	1.0669
13				1.1145		.7716	
14	1.0974	1.0669		1.1317		.7202	1.1279
15						.9431	
16		1.2803				.9774	1.3717
17						1.0117	
18						1.6975	1.5546
19		1.6004		1.9547		1.989	
20				1.869		1.6975	1.5242
21				1.6118		1.406	
22		1.1888		1.4575		1.286	1.2498
23				1.3546		1.1789	
24	1.286		1.1279		1.3032		1.1145
Max	2.1091	1.89	2.1338	1.9547	2.3663	1.989	2.2291
Min	1.0974	1.0669	1.1279	1.0631	1.3032	.7202	1.0669
Avg	1.4832	1.3195	1.4251	1.4393	1.5337	1.2363	1.3802

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074038 / 33KV S. RAJA S/S

Feeder No / Name : 201 / 11KV SINDAKHEDRAJA AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566		.0566		.0381	
2	.0566		.0566		.0381	
3	.0566		.0566		.0381	
4	.0566		.0566		.0381	
5	.1132		.0566		.0572	
6	.1132		.0566		.0572	
7	.1132		.0566		.0762	
8	.1132				.0762	
9		.0762		.0953		.1132
10		.1132		.0953		.1143
11		.1132		.1143		.0762
12		.1698		.0953		.1143
13		.3395		.1143		.1143
14		.1132		.0953		.1143
15				.0953		.1143
16		.0566		.1143		
23		.0566		.0381		
24	.1328		.0566		.0381	
Max	.1328	.3395	.0566	.1143	.0762	.1143
Min	.0566	.0566	.0566	.0381	.0381	.0762
Avg	.0902	.1298	.0566	.0953	.0508	.1087

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074038 / 33KV S. RAJA S/S

Feeder No / Name : 202 / 11KV BAMKHED AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074038 / 33KV S. RAJA S/S

Feeder No / Name : 203 / 11KV BAMKHED GFSS

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.3429		.3048	.1524		.3048
2	.2829	.3429		.3048	.1715		.3048
3	.2829	.3429		.3048	.1905		.3048
4	.3961	.4191		.381	.2096		.4572
5	.5658	.5335		.4572	.2286		
6	.679	.7621		.6478	.3048		
7		.8002					
8		.6478					
10				.4001	.2858		
11	.3429	.3395		.3429	.1715		
12	.5716	.3395					
13		.3395		.1905	.2263	.1905	
14	.6478	.3395	.2667	.1715	.2858		
15	.6478		.3048			.2286	
16	.5335		.381		.3961	.3429	.5144
17			.4572		.3961	.3429	
18	.4572		.5335		.4527		
19			.6097			.5335	.4001
20	.4572		.5335	.2477	.5658	.4954	.5716
21	.4191	.2829	.4191	.2477		.4191	.5144
22	.3429	.2829	.3429	.1905		.3429	.4572
23	.3429	.2829	.3048	.1905		.3429	.4001
24	.2829	.3429	.2829	.3048	.1715		.3048
Max	.679	.8002	.6097	.6478	.5658	.5335	.5716
Min	.2829	.2829	.2667	.1715	.1524	.1905	.3048
Avg	.4433	.4213	.4033	.3124	.2806	.3599	.4122

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074038 / 33KV S. RAJA S/S

Feeder No / Name : 204 / 11KV SINDKHED GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4146	1.3336	1.0751	1.1431	1.2384	1.1317	1.2955
2	1.4146	1.3336	1.0751	1.1431	1.2384	1.1317	1.2955
3	1.4146	1.3336	1.0751	1.1431	1.2193	1.1317	1.2574
4	1.4146	1.3717	1.0751	1.2193	1.2193	1.1317	1.2955
5	1.4146	1.4098	1.1317	1.4098	1.3717	1.1317	1.3336
6	1.6409	1.448	1.358	1.5242	1.6004	1.5844	1.6766
7	1.6975	1.5242	1.358	1.5623	1.6385	1.6409	1.6385
8	1.5278	1.4098	1.3014	1.448		1.5844	1.5623
9	1.5278	1.4861	1.1883	1.3717	1.5432	1.358	1.2955
10	1.448	1.4712	1.105	1.1622	1.2003	1.2574	1.3717
11	1.5242	1.4712		1.086	.9717	1.2193	1.1431
12	1.4098	1.4146		1.086	.9717	1.1431	1.2003
13	1.5242	1.5278		1.2003	.9619	1.1431	1.1431
14	1.448	1.6975	1.2574	1.1622	.9145	1.1622	1.1431
15			1.1431	1.2193		1.1431	1.2003
16	1.7909	1.2449	1.2193	1.3146	1.2449	1.2193	1.3146
17		1.3014	1.2955	1.3717	1.2449	1.2955	1.2003
18	1.5242	1.1883	1.4861	1.3146	1.4146	1.4098	1.2574
19		1.1883	1.448	1.5432	1.358	1.5242	1.3146
20	1.7147	1.2449	1.4098	1.4861	1.6409		1.6575
21	1.6004	1.1883	1.3717	1.448	1.4712		1.5432
22		1.1883	1.2955	1.4861		1.4861	1.4861
23	1.3717	1.1317	1.2193	1.4289		1.4098	1.4289
24	.4286	1.3336	1.0751	1.1431	1.3336	1.1317	1.3336
Max	1.7909	1.6975	1.4861	1.5623	1.6409	1.6409	1.6766
Min	.4286	1.1317	1.0751	1.086	.9145	1.1317	1.1431
Avg	1.4626	1.3584	1.2364	1.3090	1.2899	1.2896	1.3495

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074039 / 33KV SONOSI

Feeder No / Name : 201 / 11KV SONOSHI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	04-JUN-18
HR	Load (MW)
11	.526
Max	.526
Min	.526
Avg	.526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074039 / 33KV SONOSI

Feeder No / Name : 202 / 11KV WARDADI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074039 / 33KV SONOSI

Feeder No / Name : 203 / 11KV SONOSHI GFSS
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18
HR	Load (MW)
24	.0857
Max	.0857
Min	.0857
Avg	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074039 / 33KV SONOSI

Feeder No / Name : 204 / 11KV WARDADI GFSS
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18
HR	Load (MW)
24	.1715
Max	.1715
Min	.1715
Avg	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074039 / 33KV SONOSI

Feeder No / Name : 205 / 11 KV JAMBHORA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
23	.0857
24	.0857
Max	.0857
Min	.0857
Avg	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074039 / 33KV SONOSI

Feeder No / Name : 206 / 11 KV BUTTA AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	.3048
Max	.3048
Min	.3048
Avg	.3048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074039 / 33KV SONOSI

Feeder No / Name : 207 / 11 KV KHAIRKHED AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	.3048
Max	.3048
Min	.3048
Avg	.3048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074057 / 33 /11 KV MALKAPUR PANGRA

Feeder No / Name : 201 / 11KV MALKAPUR PANGRA AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.1029	.0857	.0686	.2229		.0686
2	.0857	.12	.0857	.0686	.2401		.0686
3	.1029	.1372	.12	.0857	.2572		.0686
4	.1372	.1543	.1543	.0857	.3086		.0686
5	.1543	.1715	.1715	.1029	.3601		
6	.1715		.1886	.12	.4287		
7					.2572		
9	.1886	.2401	.2401				
10	.2058	.3086	.2401				
11		.3086					
12		.2743					
13	.2572	.2401	.3086				
14	.1886		.2915				
15			.2915				
16			.2915				
20	.1372	.12	.1029	.1543	.1543		
21	.12	.12	.0857	.1543		.1029	.1029
22	.12	.1029	.0686	.12		.0857	.0857
23	.1372	.1029	.0686	.2229	.1543	.0686	.1715
24	.0857	.1029	.1029	.0686	.2229		.0686
Max	.2572	.3086	.3086	.2229	.4287	.1029	.1715
Min	.0857	.1029	.0686	.0686	.1543	.0686	.0686
Avg	.1452	.1738	.1705	.1138	.2606	.0857	.0879

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074057 / 33 /11 KV MALKAPUR PANGRA

Feeder No / Name : 202 / 11 KV MALKAPUR GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.463	.463	.4287	.3772	.3944		.4287
2	.463	.4801	.4287	.3772	.3944		.4287
3	.4973	.5144	.4801	.3944	.4115		.4458
4	.6516	.6001	.6344	.4973	.4973		.4973
5	.703	.703	.7545	.6687	.6344		.6516
6	.823	.8059	.8573	.823	.7716		.7716
7	.703	.7202	.8745	.7716	.8059		.6859
8	.6687	.6001	.8059	.6344	.6859		.6173
9	.5658	.5144	.6516	.5658	.5487	.7545	.6001
10	.4801	.4801	.5487	.463	.4801	.583	.463
11	.463	.4458	.3429	.3258	.3944	.4801	.3944
12	.4287	.4458	.3601	.3258	.3429	.4287	.3772
13	.4115	.4458	.3772	.2915	.3086		.3429
14	.3772		.3601	.2915	.3258	.4458	.3429
15			.3772	.3258	.3429	.4287	
16		.4287	.4287	.3772	.4458	.463	.3772
17	.6516	.5658	.5487	.463	.5144	.5144	.4973
18	.7716	.6001	.6687	.5658	.6859	.6516	.6516
19	.6516	.7716	.6344	.6516	.7545	.6859	.703
20	.6173	.7202	.6173	.6859	.8745	.6344	.6344
21	.583	.583	.463	.4973		.5144	.4801
22	.5144	.5144	.4115	.4801		.4801	.4287
23	.4801	.4801	.3944	.4115		.4458	.4115
24	.4801	.463	.4458	.3772	.3944		.4287
Max	.823	.8059	.8745	.823	.8745	.7545	.7716
Min	.3772	.4287	.3429	.2915	.3086	.4287	.3429
Avg	.5658	.5612	.5373	.4851	.5242	.5365	.5070

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074057 / 33 /11 KV MALKAPUR PANGRA

Feeder No / Name : 203 / 11 KV WAGHALA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1372	.1372	.1372	.1543		.1886
2	.1543	.1543	.1372	.1372	.1715		.1886
3	.2058	.1715	.1543	.1543	.2229		.2058
4	.2743	.2401	.2058	.2058	.2915		.2572
5	.3429	.3086	.2572	.2572	.3601		.3601
6	.3601	.3601	.2915	.3772	.3944		.4287
10	.2058	.2572	.1543	.1886	.2915		.2572
11	.12	.1886	.1372	.12	.1886		.2229
12		.1715	.1372	.12	.1543	.1715	.2229
13		.1543	.1372	.1372	.1372	.1715	.1886
14	.1372		.1372	.1372	.1543	.1886	.2058
15			.1372	.1543		.1715	.1886
16				.2572	.2229	.2058	.2229
17			.2572	.2915	.2743	.3086	.3086
18			.3258	.3429		.4287	.3772
19			.2915	.4287		.3258	.3601
20	.2572		.2743	.3601	.3429	.2915	.3601
21	.2229	.1886	.2058	.2743		.2572	.2743
22	.1886	.1715	.1886	.2058		.2229	.2401
23	.1543	.1715	.1715	.1886	.1543	.2058	.2058
24	.1715	.1372	.1372	.1372	.1715		.1886
Max	.3601	.3601	.3258	.4287	.3944	.4287	.4287
Min	.12	.1372	.1372	.12	.1372	.1715	.1886
Avg	.2119	.2009	.1938	.2196	.2304	.2458	.2597

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074057 / 33 /11 KV MALKAPUR PANGRA

Feeder No / Name : 204 / 11 KV WAGHALA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343	.0343		
2	.0171	.0343	.0343	.0343		
3	.0343	.0514	.0343			
4	.0514	.0514	.0514			
5	.0686		.0514	.0343		
6	.1029	.0514	.0857	.0514		
7	.12	.0514	.0857	.0686		
8	.0857	.0686	.0857	.0686		
9				.0857	.1372	
10				.0514	.0343	
11				.0857	.0857	
12				.1029	.0514	
13				.0857	.0686	
14				.0857	.12	.0857
15				.1543	.0514	.0857
16					.0857	.1029
23	.0343	.0343	.0343			
24	.7621	.0343	.0343	.0343		
Max	.7621	.0686	.0857	.1543	.1372	.1029
Min	.0171	.0343	.0343	.0343	.0343	.0857
Avg	.1311	.0457	.0531	.0698	.0793	.0914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074065 / 33 KV DAWARGAON S/S

Feeder No / Name : 201 / 11 KV SHIVANI TAKA AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	04-JUN-18	05-JUN-18	06-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
2		.0297	
6		.0743	
7		.0743	
14	.0446		
15	.0446		
23			.0297
24		.0297	
Max	.0446	.0743	.0297
Min	.0446	.0297	.0297
Avg	.0446	.052	.0297

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074065 / 33 KV DAWARGAON S/S

Feeder No / Name : 202 / 11 KV ANCHALI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	04-JUN-18	05-JUN-18	06-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
1		.0894	
2		.0894	
3		.0894	
4		.0894	
5		.1341	
6		.1639	
7		.1788	
15			.1043
16			.1937
17	.2533		
18	.1937		
23			.0596
24		.0894	
Max	.2533	.1788	.1937
Min	.1937	.0894	.0596
Avg	.2235	.1155	.1192

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074065 / 33 KV DAWARGAON S/S

Feeder No / Name : 203 / 11 KV DAWARGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0298			
2			.0298			
3			.0298			
4			.0298			
5			.0298			
6			.0447			
7			.0745			
8			.0894		.104	
9						.0596
12	.3278			.1192		.1189
13						.1635
14	.3278			.1189		.1192
15	.2831					.0892
16				.104		.1189
23		.0298		.0594		
24	1.2193		.0298		.0297	
Max	1.2193	.0298	.0894	.1192	.104	.1635
Min	.2831	.0298	.0298	.0594	.0297	.0596
Avg	.5395	.0298	.0430	.1004	.0669	.1116

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074065 / 33 KV DAWARGAON S/S

Feeder No / Name : 204 / 11 KV ANCHALI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.206	.2575	.3605		
2			.206	.2747	.3605		
3			.206	.309	.3605		
4			.2575	.412	.3605		
5			.4291	.4635	.3948		
6				.4635	.5493		
7				.4463	.4635		
8				.4463		.3772	
9				.4291		.3262	
10	.2403					.2918	.412
11	.1888					.2747	.3948
12	.1717			.4291	.3605	.412	.515
13	.1717			.4806		.4291	.4978
14	.1888			.3433	.5316	.515	.4978
15	.1888			.4978		.4806	.1202
16				.4806	.4287	.3262	.4635
17				.5321	.4287	.4806	.5493
18			.2747	.515	.5487	.515	.5493
19			.412			.5836	.4635
20		.1717	.4635			.412	
21			.3948			.3262	
22			.2918			.2403	.3605
23			.2918		.4287	.2232	
24			.206	.2747	.3605	.2401	
Max	.2403	.1717	.4635	.5321	.5493	.5836	.5493
Min	.1717	.1717	.206	.2575	.3605	.2232	.1202
Avg	.1917	.1717	.3033	.4150	.4241	.3796	.4385

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074065 / 33 KV DAWARGAON S/S

Feeder No / Name : 205 / 11 KV DAWARGAON GFSS
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2999	.247	.2999		
2			.2999	.247	.2999		
3			.2999	.3176	.2999		
4			.4411	.4587	.4411		
5			.6704	.6528	.5998		
9			.3705		.3705	.2915	.0706
10					.1783	.2646	.0706
11						.2293	
12				.2117	.149	.1941	.1764
13				.2117		.1764	.1764
14	.2646			.2117	.1715		.2117
15	.2823			.2117		.1764	.1764
16			.247	.2117	.1886	.1764	.2293
17			.4058	.3352	.2572	.2293	.247
18		.3528	.4058	.4234	.3944	.4411	.3881
19		.4058	.3881	.4587		.3881	.4587
20		.3881	.3705			.3176	
21			.3352			.3176	
22			.2823			.2999	.3176
23			.247		.2743	.2646	
24			.2999	.247	.2999	.2401	
Max	.2823	.4058	.6704	.6528	.5998	.4411	.4587
Min	.2646	.3528	.247	.2117	.149	.1764	.0706
Avg	.2735	.3822	.3576	.3176	.3017	.2671	.2293

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074068 / 33 KV KINGAON RAJA S/S

Feeder No / Name : 201 / 11 KV KINGAON RAJA AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	04-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0412			
2	.0412			
3	.0412			
4	.0549			
5	.0412			
6	.0823			
7	.1448			
9		.08		.04
10		.0667		.08
11		.1128		.0549
12		.141	.04	.0549
13		.1692	.04	.0549
14		.1738	.04	.0846
15		.1738	.04	.0869
16		.1738	.04	.1128
24	.0412			
Max	.1448	.1738	.04	.1128
Min	.0412	.0667	.04	.04
Avg	.061	.1364	.04	.0711

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074068 / 33 KV KINGAON RAJA S/S

Feeder No / Name : 202 / 11 KV HIVARKHED PURNA AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4001	.5182		.2
2			.4001	.4999		.2
3			.4268	.5624		.2
4			.4668	.5624		.2401
5			.4668	.7499		.2401
6			.4668	.6249		.2667
7			.4801	.4572		.2667
8			.5068	.3658		.2667
9	.8688					
10	.9686	.5601				
11	.9998					
12	.9998					
13	1.0311					
14	.9374	.5735				
15	1.004	.5335				
16		.5335				
19					.3334	
23			.4877		.2	.1448
24			.4001	.5182		.2
Max	1.0311	.5735	.5068	.7499	.3334	.2667
Min	.8688	.5335	.4001	.3658	.2	.1448
Avg	.9728	.5502	.4502	.5399	.2667	.2225

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074068 / 33 KV KINGAON RAJA S/S

Feeder No / Name : 203 / 11KV KINGAONRAJA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4755		.4801	.4755		.4458
2	.4755		.4458	.439		.4458
3	.5121		.4801	.5853		.4801
4	.5487		.6001	.8589		.6001
5	.7762		.9431	.9335		.8573
6	.9335		.9602	1.0562		.9602
7	.8962		.8573	.9877		.8573
8	.8131		.8059	1.0608		.7716
9	.5729		.6516	.8779		.7545
10	.567	.6001	.6001			.5847
11	.5175		.5544			.5487
12	.4755		.3658		.3429	.439
13	.4755		.2926		.4115	.4024
14	.439	.3944	.3658		.4287	.4024
15	.439	.4287	.4024		.4458	.439
16	.4755	.463	.4755		.4458	.439
17	.5544	.583	.5487		.4801	.5487
18	.7316	.823	.7023		.5658	.7762
19		.8573	.9522		.9431	.9709
20		.7716	.7577		.8573	.7392
21		.5658	.6283		.703	.6653
22		.4973	.5121		.4801	.5487
23		.4801	.4755		.4458	.5487
24	.0857		.4458	.4755		.4458
Max	.9335	.8573	.9602	1.0608	.9431	.9709
Min	.0857	.3944	.2926	.439	.3429	.4024
Avg	.5665	.5877	.5960	.7750	.5458	.6113

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074068 / 33 KV KINGAON RAJA S/S

Feeder No / Name : 204 / 11 KV PANGRI UGALE AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0412		.04	.0274		.0267
2	.0412		.0667	.0274		.0267
3	.0412		.0667	.0274		.0267
4	.0412			.0274		.04
5	.0412			.0274		.04
6	.096		.04	.0564		.04
7	.1158		.0667	.0274		.04
8	.1097		.0667	.0274		.04
9	.0423		.0667			.0667
10	.0412		.0667			.0667
11	.0274		.0564		.0667	.0549
12	.0274		.0564		.0934	.0549
13	.0274		.0846		.0934	.0549
14	.0564	.0667	.0846		.0934	.1097
15	.0846	.0934	.1128		.0934	.0823
16	.0549	.0934	.1128		.0934	.0823
17		.0934				
18		.0667				
19		.0667				
20		.0667				
23		.04	.0549		.0381	.0274
24	.0274		.0667	.0274		.0267
Max	.1158	.0934	.1128	.0564	.0934	.1097
Min	.0274	.04	.04	.0274	.0381	.0267
Avg	.0539	.0734	.0693	.0306	.0817	.0504

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074068 / 33 KV KINGAON RAJA S/S

Feeder No / Name : 205 / 11 KV HIVARKHED PURNA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4207		.4287	.4755		.4115
2	.4207		.4287	.439		.4287
3	.4207			.5487		.4287
4	.5544			.695		.4973
5	.8048			.9709		.823
6	.9709		1.1317	1.2071		1.0117
7	.8962		1.0288	.9522		.9431
8	.8402		.8916	.7682		.7373
9	.695		.6859	.695		.7545
10	.6036	.5658	.6001			.6036
11	.5487		.5487		.3429	.5487
12	.439		.5121		.3429	.4755
13	.4024		.4755		.3429	.4755
14	.4755	.3429	.4755			.4755
15	.5121	.4287	.4755		.4287	.4755
16	.4755	.4115	.4755		.4458	.4755
17	.5853		.5487		.4801	.5914
18	.7762	.6001	.7842		.6516	.7468
19		.7716			.7888	1.0185
20		.8573	.8501		.8573	.7842
21		.6516	.5853		.6859	.5544
22		.4458	.4755		.4115	.4435
23		.4287	.5121		.4115	
24	.4207		.4287	.4755		.4115
Max	.9709	.8573	1.1317	1.2071	.8573	1.0185
Min	.4024	.3429	.4287	.439	.3429	.4115
Avg	.5928	.5504	.6171	.7227	.5158	.6137

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074068 / 33 KV KINGAON RAJA S/S

Feeder No / Name : 206 / 11 KV PIMPALGAON

FEEDER SEPERATION/PURE AG

LENDI(SHELGAO Feeder KV- 11 /
OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074090 / 33/11 KV Rumhana

Feeder No / Name : 201 / 11KV RUMHANA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.1715
Max	.1715
Min	.1715
Avg	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074090 / 33/11 KV Rumhana

Feeder No / Name : 202 / 11KV CHANGEFAL AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
1	.2315
2	.1852
3	.2315
4	.2006
5	.2778
6	.463
9	.2932
24	.7621
Max	.7621
Min	.1852
Avg	.3306

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074096 / 33/11 KV SHENDURJAN

Feeder No / Name : 201 / 11KV JAGDARI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.6859	.4108	.4115	.4161		.463
2	.4115	.703	.4668	.4458	.4334		.4801
3	.5144	.7202	.4854	.5144	.4508		.4801
4	.7202	.8817	.5601	.7716	.6173		.4973
5	.8745	1.2039	.8962	.9774	.703		.6173
6	1.0288	1.643	1.1949	1.1831	1.0004		1.046
7	.823	1.4754	1.1576	1.1488			1.0117
8	.8916	1.2039	1.2696	.9774	1.0343		.8916
9	.703	.8745	.9522	.823	.8648		.9088
10	.6687	.6344	.7655	.6001	.6859		.5316
11	.6344	.5975	.5316	.4334	.6161	.6687	.5144
12	.5658	.3921	.4973	.3814		.5487	.4801
13	.5028	.4854	.4115	.3988		.4115	.4508
14	.5548		.4973	.4161		.5144	.4681
15	.5658		.5144	.4508	.4668	.5487	.4508
16			.5316	.5028	.4668	.5658	.5316
17	.8745	.8402	.7545	2.4417	.6161	.703	.7888
18		.8215	.8916	2.6825	.8962	1.0288	1.0513
19	1.0004	1.1576	.9431	1.1191	1.1763	1.0631	.9156
20	.7202	.9709	.7888	.8648	1.0829	.8745	.7373
21	.5487	.8589	.5658	.6001	.7095	.6687	.5658
22	.7716	.5788	.4973	.4854	.5601	.5487	.5658
23	.7202	.4854	.4458	.4334		.4801	.5201
24	.4287	.6859	.4854	.4287	.4161		.4115
Max	1.0288	1.643	1.2696	2.6825	1.1763	1.0631	1.0513
Min	.4115	.3921	.4108	.3814	.4161	.4115	.4115
Avg	.6789	.8524	.6881	.8122	.6954	.6634	.6408

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074096 / 33/11 KV SHENDURJAN

Feeder No / Name : 202 / 11KV JAGDARI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0457	.1187		.0762
2				.0457	.1029		.0762
3				.0457	.1029		.0914
4				.0457	.1187		.0762
5				.0762	.1341		
6				.0457	.1509		
7				.0762			.1372
8				.0457			.1219
9	.1524	.1341					
10	.1524	.1509					
11	.2012	.1494					
12	.1844		.061				
13	.1509		.0762				
14			.061				
15	.1677		.0457				
23				.1526		.1067	.1017
24				.0457	.1341		.0914
Max	.2012	.1509	.0762	.1526	.1509	.1067	.1372
Min	.1509	.1341	.0457	.0457	.1029	.1067	.0762
Avg	.1682	.1448	.0610	.0625	.1232	.1067	.0965

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074096 / 33/11 KV SHENDURJAN

Feeder No / Name : 203 / 11KV NAGZARI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1219	.0848				
2	.1219	.0848				
3	.1372	.0848				
4	.1372	.0848				
5	.1524	.1017				
6	.1829	.1017				
7	.2134	.1844				
8	.2134	.2347				
9				.1187		.061
10			.0305	.1187		.0762
11			.12	.112	.0914	.1187
12			.0857	.112	.061	.1357
13			.1029	.112	.061	.1526
14				.112	.0762	.1696
15			.1526	.112	.1067	.1357
16			.2035	.112	.061	.1017
23	.0848					
24	.1219	.0848				
Max	.2134	.2347	.2035	.1187	.1067	.1696
Min	.0848	.0848	.0305	.112	.061	.061
Avg	.1487	.1163	.1159	.1137	.0762	.1189

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074102 / 33/11 KV MAHARKHED

Feeder No / Name : 201 / 11 KV SAOKHED TEJAN AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074102 / 33/11 KV MAHARKHED

Feeder No / Name : 202 / 11 KV WAGHORA AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074102 / 33/11 KV MAHARKHED

Feeder No / Name : 203 / 11 KV SAOKHED TEJAN GFSS
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18
HR	Load (MW)
24	.0857
Max	.0857
Min	.0857
Avg	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 077005 / 132KV S/S DUSARBID

Feeder No / Name : 201 / 11KV RAHERI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	1.6766
Max	1.6766
Min	1.6766
Avg	1.6766

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 077005 / 132KV S/S DUSARBID

Feeder No / Name : 202 / 11KV BIBI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 077005 / 132KV S/S DUSARBID

Feeder No / Name : 203 / 11KV JAMBHORA AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 077005 / 132KV S/S DUSARBID

Feeder No / Name : 204 / 11KV JAMBHORA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.0857
Max	.0857
Min	.0857
Avg	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 077005 / 132KV S/S DUSARBID

Feeder No / Name : 205 / 11KV RAHERI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.1715
Max	.1715
Min	.1715
Avg	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 077005 / 132KV S/S DUSARBID

Feeder No / Name : 206 / 11 KV BIBI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.1715
Max	.1715
Min	.1715
Avg	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074003 / 33/11KV ATALI

Feeder No / Name : 201 / 11 KV SHIRLA AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	.2058
Max	.2058
Min	.2058
Avg	.2058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074003 / 33/11KV ATALI

Feeder No / Name : 202 / 11 KV BORIADGAON AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	.1543
Max	.1543
Min	.1543
Avg	.1543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074003 / 33/11KV ATALI

Feeder No / Name : 203 / 11 KV LAKHANWADA AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	.3929
Max	.3929
Min	.3929
Avg	.3929

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074003 / 33/11KV ATALI

Feeder No / Name : 204 / 11 KV P DHANGAR WW EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	.1526
Max	.1526
Min	.1526
Avg	.1526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074003 / 33/11KV ATALI

Feeder No / Name : 205 / 11 KV LAKHANWADA GFSS
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18
HR	Load (MW)
24	.4972
Max	.4972
Min	.4972
Avg	.4972

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074003 / 33/11KV ATALI

Feeder No / Name : 206 / 11 KV BORIADGAON GFSS
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18
HR	Load (MW)
24	1.2345
Max	1.2345
Min	1.2345
Avg	1.2345

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074017 / 33/11KV HIWARKHED SS

Feeder No / Name : 201 / 11KV GERU MATARGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.2896					
2	.3086	.2926					
3	.3429	.2896					
4	.3429	.2896					
5	.4287	.3258					
6	.4801	.3982					
7	.5144	.4344					
8	.5487	.4706					
9	.4801	.3772					
10	.5068	.3772					
11			.7712	.6516	.8413	.6173	.9054
12			.7377	.6859	.6661	.6516	.7712
13			.6516	.7716	.6878	.6859	.6036
14			.6859	.5487	.5959	.6859	.503
15			.57	.6001	.5316	.6859	
16			.503	.6001	.4908	.6516	
17			.4694	.4287	.4207	.5487	
18			.3688	.3944	.4252	.4115	
24	.3086						
Max	.5487	.4706	.7712	.7716	.8413	.6859	.9054
Min	.3086	.2896	.3688	.3944	.4207	.4115	.503
Avg	.4155	.3545	.5947	.5851	.5824	.6173	.6958

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074017 / 33/11KV HIWARKHED SS

Feeder No / Name : 202 / 11 KV ATALI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0343	.0286	.0305	.0343	
2			.0343	.0297	.0305	.0347	
3			.0343	.0297	.0305	.0343	
4			.0343	.0297	.0305	.0343	
5			.0343	.0297	.0305	.0351	
6			.0343	.0446	.0305	.0351	
7			.0343	.0446	.0305	.0537	
8			.0171	.0434	.0457	.0526	
9			.0171	.0457	.0305	.0343	
10			.0297	.0305	.0343	.0343	
11	.0724	.0343					.0594
12	.0362	.0343					.0594
13	.0362	.0343					.0594
14	.0354	.0343					.0446
15	.0175	.0343					.0446
16	.0175	.0343					.0372
17	.0175						.0594
18	.0362	.0343					.0594
24	.1372						
Max	.1372	.0343	.0343	.0457	.0457	.0537	.0594
Min	.0175	.0343	.0171	.0286	.0305	.0343	.0372
Avg	.0451	.0343	.0304	.0356	.0324	.0383	.0529

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074017 / 33/11KV HIWARKHED SS

Feeder No / Name : 203 / 11KV LOKHANDA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305		.1715	.0747		.1052	.0747
2	.0305		.1715	.112	.1029	.1052	.0747
3	.0343		.1715	.112	.1029	.1052	.0373
4	.0343		.1715	.112	.1029	.1402	.0373
5	.0305		.1715	.1494	.1715	.1402	.0373
6	.0305		.2058	.1867	.2058	.1753	.0747
7	.0305		.2401	.2614	.2572	.1753	.0747
8	.0305		.2401	.1867	.2058	.2103	.0747
9	.0305		.2401	.1494	.1715	.2058	.0747
10	.0343		.112	.1372	.2103	.2401	.0747
11	.2172		.0747	.0305	.0358	.0343	.2614
12	.2172	.2058	.0373	.0305	.0354	.0343	.2241
13	.2172	.1715	.0373	.0305	.0351	.0343	.1867
14	.1829	.1372	.0373	.0305	.0351	.0343	.2241
15	.1772	.1372	.0373	.0305	.0351	.0343	.2987
16	.2172	.1372	.0747	.0305	.0354	.0343	.2987
17	.2534	.1029	.0747	.0457	.0354	.0343	.2614
18	.2534	.1029	.0747	.0457	.0354	.0343	.1867
19	.0362	.0686		.0457	.0351	.0343	.0747
20	.0354	.0686	.0747	.061	.0351	.0343	.0747
21	.0351	.0686	.0747	.061		.0686	.0747
22	.0362	.0686	.0747	.061		.0686	.0747
23	.0351	.0686	.0747	.061		.0686	.0747
24	.0305	.0362	.0686	.0747	.061		.0686
Max	.2534	.2058	.2401	.2614	.2572	.2401	.2987
Min	.0305	.0362	.0373	.0305	.0351	.0343	.0373
Avg	.0942	.1057	.1179	.0883	.0972	.0935	.1258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074017 / 33/11KV HIWARKHED SS

Feeder No / Name : 204 / 11KV LOKHANDA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115		.3772	.4108	.4115	.4656	.4481
2	.4115	.4344	.3772	.4108	.4115	.4656	.4481
3	.4115	.4344	.3772	.4108	.4115	.4706	.4481
4	.4115	.4344	.4115	.4108	.4115	.4557	.4481
5	.4801	.4706	.4115	.4481	.4458	.5014	.4481
6	.4801	.543	.4115	.4481	.4458	.5792	.4854
7	.4115	.4706	.4115	.4854	.4344	.5609	.4854
8	.4115	.4344	.4115	.4854	.3982	.4557	.5228
9	.4458	.4115	.4115	.4481	.4344	.4115	.4481
10	.439	.4115	.3734	.3429	.394	.3772	.3734
11	.4344	.4115	.3734	.3086	.3582	.3772	.3734
12	.4024	.3772	.3734	.4115	.394	.3772	.3734
13	.3982	.3772	.4108	.4115	.3982	.3772	.4108
14	.394	.3772	.3734	.3429	.394	.3429	.4481
15	.4298	.3772	.4481	.3772	.3982	.3429	.4481
16	.4344	.3772	.4108	.3772	.3982	.3772	.4481
17	.3982	.4115	.4108	.4115	.4298	.4115	.4481
18	.4706	.4115	.4854	.4801	.4344	.4115	.5228
19	.543	.4115		.4458	.5373	.4115	.5975
20	.6154	.4115	.6722	.4115	.5792	.4115	.7095
21	.5792	.4115	.5975	.4115	.6089	.4458	.6722
22	.543	.4115	.5975	.4801	.6154	.4458	.5975
23	.4706	.3772	.5601	.4801	.5373	.4458	.5228
24	.4115	.4755	.3772	.4854	.4458	.5068	.4115
Max	.6154	.543	.6722	.4854	.6154	.5792	.7095
Min	.394	.3772	.3734	.3086	.3582	.3429	.3734
Avg	.4516	.4202	.4376	.4223	.4470	.4345	.4808

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074017 / 33/11KV HIWARKHED SS

Feeder No / Name : 205 / 11 KV GERU MATARGAON GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3292	.3086	.3361	.3086	.3224	.3361
2	.3086	.3258	.3086	.3361	.3086	.3258	.2987
3	.3086	.3258	.2743	.3361	.1372	.3258	.2987
4	.3086	.3292	.2743	.3361	.0514	.3224	.2987
5	.3429	.3292	.2743	.3361	.2743	.362	.3361
6	.3086	.3292	.2743	.3361	.3086	.4298	.3361
7	.2743	.2926	.2743	.2987	.2743	.3582	.3361
8	.2401	.2926	.2743	.2987	.2743	.3258	.3361
9	.2743	.2743	.2743	.2987	.2401	.2743	.2987
10	.2896	.2743	.2614	.2743	.2534	.2743	.2987
11	.3292	.2743	.2614	.3086	.2896	.2743	.2614
12	.3258	.2743	.2614	.2401	.2896	.2743	.2614
13	.3258	.2743	.2987	.2401	.2896	.2743	.2987
14	.3292	.2743	.2987	.2743	.2835	.2743	.2987
15	.3326	.2743	.2987	.2743	.2835	.2743	.2614
16	.3292	.2743	.2987	.2401	.3224	.2743	.2987
17	.2926	.2743	.2987	.2743	.3224	.2743	.2987
18	.3292	.3086	.2614	.3086	.3224	.2743	.3174
19	.3658	.3429	.3361	.3086	.362	.3086	.4108
20	.4344	.3772	.4108	.3429	.4344	.3086	.4854
21	.4066	.3772	.4481	.4115	.4656	.4115	.4481
22	.4024	.3772	.4108	.3772	.4344	.4115	.4481
23	.3658	.3429	.4108	.3429	.4344	.3772	.3921
24	.3429	.3658	.3429	.3734	.3086	.362	.3429
Max	.4344	.3772	.4481	.4115	.4656	.4298	.4854
Min	.2401	.2743	.2614	.2401	.0514	.2743	.2614
Avg	.3282	.3131	.3098	.3127	.3031	.3206	.3332

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074022 / 33/11 KV KOLORI

Feeder No / Name : 201 / 11 KV KOLORI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2401	.2229	.2058	.2743	.2058	.2058
2	.2572	.2401	.2058	.2058	.2743	.1886	.1715
3	.2401	.2401	.2058	.2058	.2401	.1715	.1715
4	.2401	.2058	.1886	.2229	.2401	.1715	.1886
5	.2229	.2058	.2058	.2401	.2743	.1886	.2058
6	.2229	.2058	.2058	.2401	.2915	.2058	.2058
7	.2058	.1715	.2229	.2058	.3086	.2572	.2058
8	.2058	.1543	.1715	.1886	.2915	.1715	.1715
9	.1543	.1372	.1543	.1543	.2915	.1886	.1715
10	.1715	.1543	.12	.1543	.3086	.1886	.1372
11	.3772	.2229	.1372	.1543	.1886	.1543	.3086
12	.3429	.2572	.1715	.1543	.1886	.1715	.3429
13	.2915	.2229	.1715	.2058	.2058	.1886	
14	.2572	.2401	.1715	.2229	.2229	.2058	.2572
15	.2743	.2743	.2058	.2229	.2058	.2058	.2572
16	.3429	.2915	.1886	.2229	.2229	.2058	.2743
17	.3429	.1543	.1715	.2058	.2058	.2058	.2572
18	.2743		.1886	.1715	.2058	.1715	.2743
19	.2058	.2401	.2572	.2401	.2058	.0343	.2743
20	.2743	.2058	.2743	.2743		.2743	.2743
21	.2743	.2229	.2743	.3086		.2743	.2572
22	.2743	.2229	.2743	.2743		.2915	.2401
23	.2743	.2058	.2401	.2401		.2572	.2401
24	.2572	.2743	.2229	.2058	.2229		.2229
Max	.3772	.2915	.2743	.3086	.3086	.2915	.3429
Min	.1543	.1372	.12	.1543	.1886	.0343	.1372
Avg	.2601	.2170	.2022	.2136	.2435	.1991	.2311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074022 / 33/11 KV KOLORI

Feeder No / Name : 202 / 11 KV JAWALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.5144	.4115	.5144	.5144	.4115	.5144
2	.6173		.4115	.5144	.5144	.3944	.4801
3	.6173	.4801	.3944	.4801	.4801	.3944	.4801
4	.583	.5144	.4115	.4458	.4801	.4115	.5144
5	.6516	.5144	.4287	.4458	.4458	.4115	.5144
6		.4801	.463	.4115	.4458	.4115	.5487
7	.6173	.5487	.3772	.3772	.3772	.4115	.6516
8	.583	.583	.3944	.3086	.3429	.3086	.5487
9	.5487	.6173	.3429	.2915	.3429	.2572	.4801
10	.463	.5487	.2915		.3258	.2572	.4801
11	.4287		.2743	.583	.6516	.3258	.4287
12	.5144		.2743	.6173	.6344	.3772	.4115
13	.5487		.3086	.6516	.583	.4458	.4287
14	.5487	.6001	.3429	.6344	.6173	.5658	.4458
15	.5487	.6173	.4115	.6516	.6001	.583	.4801
16	.5487	.6001	.3944		.583	.6516	.463
17	.4801		.3772	.4801	.703	.5144	.4115
18	.3772	.4287	.4115	.4801	.5487	.4458	.4458
19	.3772	.4287	.5144	.6001	.4115	.4801	.5144
20	.6173	.1543	.6001	.6516		.583	.6173
21	.6173	.5487	.6001	.6173		.6173	.6516
22	.6516	.4801	.6173	.6173		.583	.6344
23	.6173	.4458	.583	.583		.5487	.583
24		.583	.4115	.5487	.5487		.5144
Max	.6516	.6173	.6173	.6516	.703	.6516	.6516
Min	.3772	.1543	.2743	.2915	.3258	.2572	.4115
Avg	.5549	.5099	.4187	.5230	.5075	.4518	.5101

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074022 / 33/11 KV KOLORI

Feeder No / Name : 203 / 11 KV CHITODA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.2743	.1886	.2058	.2743		.2572
2	.4801	.2743	.1715	.2058	.2401		.2572
3	.4458	.2915	.1715	.2058	.2401		.2743
4	.4458	.2915	.1715	.2229	.2401		.3086
5	.4801	.3086	.1886	.2229	.2743		.3086
6	.583	.3086	.1886	.2401	.2401		.3429
7	.5144	.2915	.2058	.2229	.2058		.4287
8	.4801	.2915	.1886	.2058	.2058	.2058	.4115
9	.4115	.2743	.1886	.1886	.2229	.1886	.4115
10	.3429	.4115	.2229	.1886	.2229	.1372	.4115
11	.2572	.2229	.1886	.4458	.4115	.1715	.1715
12	.2743	.2229	.2229	.4115	.3258	.1886	.1886
13	.2743	.2572	.2229	.3086	.2915		.1715
14		.2743	.3601	.3086		.2915	.1715
15		.2743	.4115	.3429		.2229	.1715
16		.2058	.4115	.3429	.3258	.2401	.2058
17	.2058		.3944	.3086	.4115	.2058	.1372
18	.2058		.3772	.2743	.3601	.2058	.1715
19	.2743		.2743	.3086	.2743	.1372	.3086
20	.3429	.2915	.3258	.3429		.2915	.3429
21	.3429	.2743	.2915	.3429		.2743	.3258
22	.2915	.2572	.2572	.3258		.2743	.3086
23	.2743	.2058	.2401	.2915		.2572	.2743
24		.2743	.1886	.2401			.2401
Max	.583	.4115	.4115	.4458	.4115	.2915	.4287
Min	.2058	.2058	.1715	.1886	.2058	.1372	.1372
Avg	.3721	.2751	.2522	.2793	.2804	.2195	.2751

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074022 / 33/11 KV KOLORI

Feeder No / Name : 204 / 11 KV SHAHEEN FROZON NON SHEDDABLE EXPRESS HV FEEDERS
 EXPRESS Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343	.0343	.0343	.0343	.0343
2	.0343	.0343	.0343	.0343	.0343	.0343	.0343
3	.0343	.0343	.0343	.0343	.0343	.0343	.0343
4	.0343	.0343	.0343	.0343	.0343	.0343	.0343
5	.0343	.0343	.0343	.0343	.0343	.0343	.0343
6	.0343	.0343	.0343	.0343	.0343	.0343	.0343
7	.0343	.0343	.0343	.0343	.0343	.0343	.0343
8	.0343	.0343	.0343	.0343	.0343	.0343	.0343
9	.0343	.0343	.0343	.0343	.0343	.0343	.0343
10	.0343	.0343	.0343	.0343	.0343	.0343	.0343
11	.0343	.0343	.0343	.0343	.0343	.0343	.0343
12	.0343	.0343	.0343	.0343	.0343	.0343	.0343
13	.0343	.0343	.0343	.0343	.0343	.0343	.0343
14	.0343	.0343	.0343	.0343	.0343	.0343	.0343
15	.0343	.0343	.0343	.0343	.0343	.0343	.0343
16	.0343			.0343	.0343	.0343	.0343
17	.0343		.0343	.0343	.0343	.0343	.0343
18	.0343	.0343	.0343	.0343	.0343	.0343	.0343
19	.0343		.0343	.0343	.0343	.0343	.0343
20	.0343	.0343	.0343	.0343		.0343	.0343
21	.0343	.0343	.0343	.0343		.0343	.0343
22	.0343	.0343	.0343	.0343		.0343	.0343
23	.0343	.0343	.0343	.0343		.0343	.0343
24	.0343	.0343	.0343	.0343	.0343		.0343
Max	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.0343	.0343	.0343	.0343	.0343	.0343	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074022 / 33/11 KV KOLORI

Feeder No / Name : 205 / 11 KV TEMBHURNA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.2058	.3086	.3086	.3429		.2743
2	.3429	.2058	.3086	.3086	.3429		.2743
3	.3086	.1886	.2915	.2915	.3086		.2572
4	.3086	.1886	.2915	.2915	.3086		.2572
5	.2743	.2058	.2915	.2915	.3772		.2743
6	.2572	.2058	.2915	.3086	.4115		.2743
7	.2401	.1715	.2743	.2743	.2401		.2229
8	.2229	.2058	.2058	.2572	.2401		.2058
9		.2058	.2058	.2401	.2572	.3772	.2058
10		.2401	.2229	.2401	.2401	.3086	.1715
11	.1372	.3601	.2229	.2058	.2401	.2401	
12	.1372	.3429	.2401	.2058	.2743	.2401	
13	.4287	.3601	.2401	.1715	.3086	.2401	
14	.3772	.3258	.2572	.2915	.3086	.1886	.2229
15	.4287	.3258	.2743	.3086	.2915	.2915	.3772
16	.3772	.3258	.2572	.2229	.3086	.2915	.3772
17	.3429	.2229	.2572		.3086	.2743	.3258
18	.3086	.2915	.2401		.2572	.2401	.3429
19		.2915	.3086	.3429	.2915	.3086	.3429
20	.3772	.3772	.3772	.3772		.3429	.3601
21	.3772	.2743	.3772	.3944		.3429	.3772
22	.3772	.2915	.3429	.3944		.3429	.3772
23	.3772	.3086	.3429	.3772		.3086	.3429
24	.3429	.3429	.3258	.3258			.2915
Max	.4287	.3772	.3772	.3944	.4115	.3772	.3772
Min	.1372	.1715	.2058	.1715	.2401	.1886	.1715
Avg	.3184	.2694	.2815	.2923	.2978	.2892	.2931

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074024 / 33/11 KV MATARGAON

Feeder No / Name : 201 / 11 KV MATARGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0724		.9088	.8573	1.0288	.1307
2	.0343	.0934		.8916	.8916	1.0288	
3	.0343	.0905		.8916	.9259	1.0288	
4	.0343	.112		.8745	1.0288	1.0802	
5	.1029	.1086		.9431	1.0288	1.1145	
6	.1029	.1307		1.0117	1.0974	1.1317	.0934
7	.1029	.0934		1.2003	1.2517	1.286	.1494
8	.1029	.1307		1.2003	1.286	1.3203	.168
9	.1494	.168		1.166	1.2003	1.3717	.1867
10	.1629	.1097		1.0117	1.1145	1.0829	.1029
11	1.0082	1.0974					1.3717
12	1.0829	1.2437					1.5432
13	1.0642	1.1523					
14	1.0456	1.134					
15	1.0829	1.1157					1.4575
16	1.0185						1.6461
17	.9709				.0857	.168	1.5432
18	.9522		1.0288		.1372	.1867	1.4575
19			1.0288	.0343	.1372	.168	
20			1.046	.0343		.168	
21			1.0288	.1029		.1494	
22			1.0288	.1029	.12	.1494	
23			.9774	.1372		.1448	
24	.4031			.9431	.12		.1494
Max	1.0829	1.2437	1.046	1.2003	1.286	1.3717	1.6461
Min	.0343	.0724	.9774	.0343	.0857	.1448	.0934
Avg	.4995	.4568	1.0231	.7159	.7522	.7416	.7692

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074024 / 33/11 KV MATARGAON

Feeder No / Name : 202 / 11 KV JALAMB AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715			.0686	.0857	.0857	.1867
2	.2058			.0686	.0857	.0857	.1867
3	.2401			.0686	.0857	.0857	.2054
4	.2743			.0686	.0857	.0857	.2241
5	.2743			.0343	.0857	.0857	.2241
6	.3772			.0343	.0857	.0857	.2614
7	.4458			.0514	.0857	.12	.3734
8	.3086	.4481		.0514	.12	.0857	.5041
9	.2715	.3734		.12	.1029	.0857	.4108
10	.1494	.3801			.12	.1086	.2572
11				.3429	.4287	.5415	
12				.3086	.5144	.5601	
13				.3086	.4458	.4854	
14				.2915	.2572	.3361	
15				.2915	.2572	.3734	
16				.3258	.2572	.3734	
17	.1307			.3258	.2915	.3734	.1372
18	.1494			.2915	.2572	.2801	.12
19	.1307						.12
20	.112		.0514				.1029
21	.1307		.0857				.1029
22	.112		.0857				.1029
23	.112		.0686				.1029
24	.3856	.1307		.0686			
Max	.4458	.4481	.0857	.3429	.5144	.5601	.5041
Min	.112	.1307	.0514	.0343	.0857	.0857	.1029
Avg	.2212	.3331	.0729	.1734	.2029	.2354	.2131

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074024 / 33/11 KV MATARGAON

Feeder No / Name : 203 / 11 KV JALAMB GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.8029	.5853	.6859	.6687	.7202	.7095
2	.6859	.7655	.567	.6859	.6516	.7202	.7095
3	.6859	.7842	.5853	.6859	.6516	.7202	.7095
4	.6516	.8029	.5788	.6516	.6516	.7202	.7356
5	.6001	.7468	.5975	.6001	.6173	.7202	.7468
6	.6173	.6516	.6283	.5658	.5487	.703	.7282
7	.463	.5788	.6036	.4973	.4973	.6173	.7095
8	.5316	.5601	.5973	.463	.4973	.5316	.6161
9	.5228	.5792	.5487	.4801	.4973	.5144	.5975
10		.5611	.4973		.5316	.7095	.5144
11		.5975		.5144	.5487	.7095	.5144
12		.6283		.5487	.5658	.7282	.5316
13		.7282	.5316	.5144	.6687	.7468	.583
14		.7577	.5658	.6516	.6173	.7842	.583
15		.7316	.583	.6687	.703	.7282	.583
16	.8962			.6859	.6859	.7468	.5487
17	.7842		.4973	.6173	.703	.6722	.5316
18	.7095		.5144	.5487	.6516	.5975	.5144
19	.8962			.7716	.6687	.9335	.6344
20	.8962		.8059	.8059	.8573	.9149	.7373
21	.9522		.8059	.8059	.8573	.8962	.7716
22	.9709		.7888	.7888	.823	.8215	.7202
23	.8215		.7202	.703	.7716	.7842	.6516
24	.703	.8029		.6859	.6687	.7373	.7095
Max	.9709	.8029	.8059	.8059	.8573	.9335	.7716
Min	.463	.5601	.4973	.463	.4973	.5144	.5144
Avg	.7263	.6925	.6106	.6359	.6502	.7282	.6413

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074024 / 33/11 KV MATARGAON

Feeder No / Name : 204 / 11 KV MATARGAON GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3734	.2743	.3429	.3429	.3429	.3547
2	.3429	.3734	.2926	.3429	.3429	.3429	.3734
3	.3429	.3361	.2772	.3429	.3429	.3429	.3547
4	.3429	.3361	.2926	.3429	.3429	.3429	.3734
5	.3429	.3174	.2743	.3086	.3086	.3429	.3361
6	.3086	.3361	.2957	.2743	.2915	.3429	.3174
7	.2743	.2801	.2926	.2572	.2915	.2743	.2801
8	.2743	.2987	.2743	.2401	.2572	.2572	.2614
9	.2801	.2801	.3109	.2401	.2401	.2401	.2614
10	.3361	.3174	.2743	.2743	.2572	.2987	.2743
11	.3361	.3361	.2743	.2743	.2743	.3174	.2401
12	.3174	.3292	.2743	.2743	.2743	.3361	.2401
13	.2987	.3511	.2915	.2915	.3086	.3734	.2743
14	.3361	.3696	.3258	.3086	.2743	.3547	.3086
15	.3547	.3475	.3429	.3086	.3429	.3361	.3258
16	.3734			.3429	.3086	.3734	.3086
17	.3361		.3086	.3086	.3086	.3547	.3429
18	.3547		.3258	.2915	.2915	.3361	.2058
19	.3734		.3772	.3429	.3429	.4108	.3429
20	.4108		.4115	.3772	.4287	.4108	.3944
21	.4294		.4115	.3944	.4287	.3734	.4115
22	.4481		.3944	.3944	.4115	.3921	.4115
23	.4481		.3601	.3429	.3944	.362	.3944
24	.4115	.4108		.3429	.3429	.3601	.3547
Max	.4481	.4108	.4115	.3944	.4287	.4108	.4115
Min	.2743	.2801	.2743	.2401	.2401	.2401	.2058
Avg	.3521	.3371	.3162	.3151	.3229	.3425	.3226

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074024 / 33/11 KV MATARGAON

Feeder No / Name : 205 / 11 KV BHASTAN GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2614	.1829	.2058	.2058	.2229	.2241
2	.2058	.2427	.1848	.2058	.2058	.2229	
3	.2058	.2241	.1829	.2058	.2058	.2229	
4	.2058	.2427	.1991	.2058	.2058	.2229	
5	.2058	.2241	.2218	.1886	.1886	.2229	
6	.1886	.2241	.2195	.1886	.2058	.2229	.2241
7	.1543	.1867	.2561	.1715	.1886	.1886	.2241
8	.1886	.2241	.2195	.1715	.1715	.1715	.2054
9	.1867	.2614	.2195	.2058	.2743	.1886	.2987
10	.1867	.1848	.2058	.2058	.1715	.2241	.1715
11	.1867	.2402	.2058	.2058	.2058	.2241	.1715
12	.2054	.2561	.2058	.2058	.2229	.2054	.1715
13	.2241	.2587	.2058	.2229	.2229	.2427	.2058
14		.2772	.2743	.2229	.2401	.2614	
15	.2427	.2743	.2743	.2229	.2401	.2427	.1886
16	.2801			.2401	.2401	.2241	.1886
17	.2427		.1886	.2058	.2058	.2054	.2058
18	.2614		.2743	.1543	.2229	.2241	.1715
19	.2614		.3086	.2401	.2572	.2987	.2401
20	.2987		.3429	.3086	.2915	.3547	.2743
21	.3361		.3086	.2743	.2743	.2987	.2915
22	.3361		.2915	.2401	.2572	.2427	.2572
23	.2801		.2401	.2058	.2229	.2241	.2229
24	.2401	.2614		.2058	.2058	.2229	.2054
Max	.3361	.2772	.3429	.3086	.2915	.3547	.2987
Min	.1543	.1848	.1829	.1543	.1715	.1715	.1715
Avg	.2325	.2403	.2369	.2129	.2222	.2326	.2180

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074032 / 33 KV PIMPALGAON RAJA

Feeder No / Name : 200 / 11 KV WASADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.6097	.0381	.1524	.1524	.1143	.2667
2	.7621	.6097	.0381	.1524	.1524	.1143	.2667
3	.7621	.6478	.0381	.1524	.1524	.1143	.3429
4	.7621	.6859	.0381	.1524	.1524	.1143	.381
5	.7621	.7621	.0381	.1524	.1143	.1143	.381
6	.9526	.8002	.0381	.1524	.1143	.1524	.6478
7	1.0669	1.1431	.0381	.1524	.1524		1.0669
8	.7621	.9526	.0381	.1524	.1524		.9907
9	.724	.8383		.1524	.1524		.9907
10	.6097	.6478		.1143	.1524	.1524	.8002
11	.1524	.1143		.3429	1.1431	1.3717	.1524
12	.1524	.1143	.2667	1.1431	1.0669	1.1431	.1524
13	.1524	.1143	.5716	1.2193	.7621	.9526	.1524
14	.1524	.1143	.8383	.9145	.7621	.8002	.1524
15	.1524	.1143	.7621	.8383	.724	.6478	.1524
16	.1524	.1143	.724	.8002	.7621	.6097	.1524
17	.1524	.0762	.5716	.8383	.7621	.8764	.1524
18	.1905	.0762	.4572	.4954	.6859	.6478	.1524
19	.1524	.0762	.1524	.1524	.1524	.1524	.1524
20	.1905	.0762	.1524	.1524	.1524	.1905	.1524
21	.1905	.0762	.1524	.1524	.1524	.1905	.1905
22	.1524	.0381	.1524	.1524	.1524	.1905	.1524
23	.1524	.0381	.1524	.1524	.1524	.1905	.1524
24	.4287	.1524	.0381	.1524	.1524	.1143	.1524
Max	1.0669	1.1431	.8383	1.2193	1.1431	1.3717	1.0669
Min	.1524	.0381	.0381	.1143	.1143	.1143	.1524
Avg	.4338	.3747	.2522	.3747	.3763	.4264	.3461

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074032 / 33 KV PIMPALGAON RAJA

Feeder No / Name : 201 / 11 KV BHALEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1143	.0381	.0381	.0381	.0381	.2667
2	.1524	.1143	.0381	.0381	.0381	.0381	.2667
3	.1524	.1143	.0381	.0381	.0381	.0381	.2667
4	.1524	.1524	.0381	.0381	.0381	.0381	.2667
5	.1524	.1905	.0381	.0381	.0381	.0381	.2667
6	.2286	.2667	.0381	.0953	.0381	.0381	.3048
7	.381	.4572	.0381	.0381	.0381	.0381	.4572
8	.381	.4191	.0381	.0381	.0381	.0381	.4572
9	.2667	.381	.0381		.0381	.0381	.5335
10	.2667	.381	.0381		.0381	.0381	.381
11	.0381	.0381	.2667		.4572	.6478	.0381
12	.0381	.0381	.3429		.4191	.5335	.0381
13	.0381	.0381	.3429		.381	.4572	.0381
14	.0381	.0381	.3048	.2667	.381	.381	.0381
15	.0381	.0381	.3048	.4572	.381	.3429	.0381
16	.0381	.0381	.2667	.4191	.3429	.3429	.0381
17	.0381	.0381	.2667	.5716	.381	.4191	.0381
18	.0381	.0381	.2667	.381	.381	.3048	.0381
19	.0381	.0381	.0381	.0381	.0381	.0381	.0381
20	.0381	.0381	.0381	.0381	.0381	.0381	.0381
21	.0381	.0381	.0381	.0381	.0381	.0381	.0381
22	.0381	.0381	.0381	.0381	.0381	.0381	.0381
23	.0381	.0381	.0381	.0381	.0381	.0381	.0381
24	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Max	.381	.4572	.3429	.5716	.4572	.6478	.5335
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.1175	.1302	.1238	.1414	.1556	.1683	.1667

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074032 / 33 KV PIMPALGAON RAJA

Feeder No / Name : 202 / 11 KV PIMPALGAON RAJA AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.0762	.2286	.1143
2	.0762	.2286	.1143
3	.0762	.2286	.1143
4	.0762		.1143
5	.0762	.3048	.1143
6	.0762	.4954	.0762
7	.0762	.5335	.1143
8		.5335	.1143
9		.4954	.0762
10		.4954	.0762
11		.0762	.724
12		.0762	.5335
13		.0762	.381
14		.0762	.3048
15		.0762	.3048
16		.0762	.2667
17		.0762	.3429
18		.0762	.3429
19		.0762	.0762
20		.0762	.1143
21		.1143	.1143
22		.1143	.1143
23		.1143	.1143
24	.0762		.1143
Max	.0762	.5335	.724
Min	.0762	.0762	.0762
Avg	.0762	.2113	.2032

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074032 / 33 KV PIMPALGAON RAJA

Feeder No / Name : 204 / 11 KV TANDULWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.4572	.4572	.4191	.4191	.1524
2	.1524	.1524	.4572	.4572	.4191	.4191	.1524
3	.1524	.1524	.4572	.4572	.4572	.4572	.1524
4	.1524	.1524	.0381	.4572	.5335	.5335	.1524
5	.1524	.1524		.5716	.6478	.5716	.1524
6	.1524	.1524	.4572	.8002	.8764	.6097	.1524
7	.3048	.1524	.6859	1.0288	1.0669	.8002	.1524
8	.3048	.1524	.6859	1.0288	1.2955	1.0288	.1524
9	.1524	.1143	.7621	.8002	.9907	.9907	.1524
10	.1524	.0762	.6097	.724	.9526		.1905
11	1.105	1.1431	.0762	.1524	.0762	.1143	1.2955
12	.9145	.9526	.0762	.1905	.0381	.1143	1.3336
13	.7621	.7621	.0762	.1905	.0762	.1143	1.1431
14	.6859	.6859	.0762	.1905	.0762	.1143	.9907
15	.6859	.6859	.0762	.1905	.0762	.1143	.9145
16	.5716	.5716	.0762	.1905	.0762	.1143	.8383
17	.6859	.5716	.0762	.1905	.0762	.1143	.9526
18	.5716	.381	.0762	.1524	.0762	.1143	.7621
19	.1524	.1143		.1524	.0762	.1524	.1905
20	.1524	.1143	.1143	.1524		.1524	.1905
21	.1524	.0762	.1143	.1524	.0762	.1524	.1905
22	.1524	.0762	.1143	.1524	.0762	.1524	.1905
23	.1524	.0762	.1143	.1524	.0762	.1524	.1905
24	.1524	.1524	.0762	.1143	.1524	.0762	.1524
Max	1.105	1.1431	.7621	1.0288	1.2955	1.0288	1.3336
Min	.1524	.0762	.0381	.1143	.0381	.0762	.1524
Avg	.3636	.3239	.2615	.3794	.3777	.3297	.4541

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074032 / 33 KV PIMPALGAON RAJA

Feeder No / Name : 205 / 11 KV PIMPALGAON RAJA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8764	.8383		.8002	.8383	.8383	.8002
2	.8764	.7621		.8002	.8383	.8383	.8002
3	.8764	.7621	.724	.7621	.7621	.7621	.7621
4	.8764	.7621	.6478	.7621	.7621	.7621	.7621
5	.7621	.724	.6478	.724	.7621	.724	.7621
6	.6859	.6859	.6478	.724	.724	.724	.7621
7	.6478	.6097	.5716	.6097	.6097	.6859	.6859
8	.6478	.6097	.4954	.5716	.5716	.6097	.6097
9	.6859	.5716	.4954	.6097	.6097	.5716	.5716
10	.724	.6097	.5335	.6097	.6478	.5716	.6097
11	.7621		.6097	.6097	.6859	.6097	.6097
12	.8002	.7621	.6478	.724	.7621	.4954	.6859
13	.8764	.8002	.6859	.7621	.7621	.6478	.724
14	.8764	.8002	.6859	.8383	.8002	.6859	.7621
15	.9145	.8383	.724	.8383	.8002	.8002	.7621
16	.8764	.8383	.724	.8383	.8383	.8002	.724
17	.8383	.8764	.6859	.7621	.8383	.3429	.7621
18	.8383	.8383	.6859	.6859	.7621	.8002	.7621
19	.8383	.8764	.7621	.8383	.8764	.8383	.7621
20	.9526	.9526	.8383	.9526	.9907		.9145
21	1.0288	.9526	.8764	.9907	.9526	.9526	.9526
22	.9526	.9145	.8764	.9145	.9526	.9145	.9526
23	.9145	.9145	.8383	.8764	.9145	.8764	.8764
24	.9145	.8383	.9145	.8383	.8764	.8764	.8383
Max	1.0288	.9526	.9145	.9907	.9907	.9526	.9526
Min	.6478	.5716	.4954	.5716	.5716	.3429	.5716
Avg	.8351	.7886	.6963	.7685	.7891	.7273	.7589

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074032 / 33 KV PIMPALGAON RAJA

Feeder No / Name : 207 / 11 KV WASADI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381	.3429	.381	.381	.381	.381
2	.381	.381	.3429	.3429	.3429	.381	.381
3	.381	.3429	.3429	.3429	.3429	.381	.381
4	.381	.3429	.3048	.3429	.3429	.3429	.381
5	.2667	.3429	.3048	.3048	.3048	.3429	.381
6	.2667	.3048	.3048	.3048	.2667	.3429	.381
7	.2667	.2286	.2286	.2286	.2667	.2286	.3048
8		.2286	.2286	.2286	.2286	.1524	.2667
9	.2667	.2286	.2286	.2286	.2667	.1524	.2286
10	.2667	.2667	.2286	.2286	.2667	.2286	.2286
11	.3048	.3048	.2286	.2667	.2286	.2286	.2667
12	.3429	.3429	.2667	.2667	.3048	.1905	.3048
13	.381	.3429	.2667	.3429	.3048	.2286	.3048
14	.381	.381	.3048	.3429	.3429	.2667	.3429
15	.381	.381	.3048	.3429	.3429	.3429	.3429
16	.3429	.3048	.3048	.381	.3048	.3429	.3048
17	.3429	.2286	.3048	.3429	.3048	.3429	.3048
18		.3429	.3048	.3048	.3048	.3429	.381
19	.2667	.381	.3429	.381		.4191	.381
20	.5335	.4954	.4572	.4954	.4954		.4572
21	.5335	.4572	.4572	.4954		.4572	.4954
22	.4572	.4191	.4191	.4572	.4572	.4191	.4572
23	.4191	.4191	.381	.4191	.4572	.381	.4191
24	.4191	.381	.381	.381	.381	.4572	.381
Max	.5335	.4954	.4572	.4954	.4954	.4572	.4954
Min	.2667	.2286	.2286	.2286	.2286	.1524	.2286
Avg	.3620	.3429	.3159	.3397	.3291	.3197	.3524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074032 / 33 KV PIMPALGAON RAJA

Feeder No / Name : 209 / 11 KV TANDULWADI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.2286	.3048	.2667	.2286	.3048	.2286
2	.4191	.2286	.3048	.2667	.1905	.2667	.2286
3	.4191	.2286		.2667	.1905	.2667	.2667
4	.4572	.1905		.2286	.1905	.2667	.2667
5	.4954	.1905	.3048	.2286	.1905	.2667	.2667
6	.4954	.1905	.3048	.2286	.2286	.1905	.2667
7	.1905	.2286	.2286	.2286	.2286	.2286	.2286
8		.2286	.2286	.1905	.2286		.2286
9	.1905	.2286	.1905	.1905	.2286		.2286
10	.2286	.2667	.1524	.1905	.2286		.1524
11	.1905	.3048	.1905	.1524	.2286	.2286	.1905
12	.2286	.3429	.2667	.1905	.2286	.2286	.1524
13	.2286	.3429	.2667	.2286	.2286	.1905	.1905
14	.2286	.381	.2667	.2286	.2667	.2286	.1905
15	.2286	.381	.2667	.2286	.2667	.2286	.1905
16	.2286	.3048	.2667	.2286	.2667	.2286	.1524
17	.2286		.2667	.2286	.2667	.2286	.1905
18	.1905		.2667	.2286	.2286	.2286	.2286
19	.2667	.2667	.3429	.2667		.2667	.2667
20	.381	.3048	.4191	.3048		.3048	.3429
21	.3429	.3429	.4191	.3048	.3048	.3048	.3429
22	.3048	.3429	.381	.2667	.3048	.3429	.3048
23	.2667	.3429	.3429	.2667	.3048	.3429	.2667
24	.2667	.2286	.3048	.3048	.2286	.3048	.2667
Max	.4954	.381	.4191	.3048	.3048	.3429	.3429
Min	.1905	.1905	.1524	.1524	.1905	.1905	.1524
Avg	.2998	.2771	.2858	.2381	.2390	.2594	.2350

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074069 / 33 KV ROHANA

Feeder No / Name : 201 / 11 KV ROHANA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.9717	.8684	.7209	1.2384
2				.9717	.9012	.7209	1.2384
3				.9526	.9012	.7209	1.1812
4				.9526	.9012	.7042	1.1431
5				.9907	.9503	.6874	1.1431
6				1.2574	1.1305	1.0059	1.3717
7				1.3527	1.1822	1.3748	1.5813
8				1.3527	1.2308	.128	1.6004
9				1.0562	1.1498	1.358	1.2742
10				1.0059	1.2384	1.0688	1.1401
11	1.9624	1.8671	1.4575				
12	1.7337	1.6956	1.3765				
13	1.6575	1.5242	1.2955				
14	1.3908	1.3146	.0695				
15	1.2384	1.2384	1.1174				
16	1.1812	1.2003	1.0688				
17	1.3336		1.2193				
18	.9892	.7625	1.1431				
Max	1.9624	1.8671	1.4575	1.3527	1.2384	1.3748	1.6004
Min	.9892	.7625	.0695	.9526	.8684	.128	1.1401
Avg	1.4359	1.3718	1.0935	1.0864	1.0454	.8490	1.2912

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074069 / 33 KV ROHANA

Feeder No / Name : 202 / 11 KV WARNA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.3561	.3185	.3222
2	.3391	.3185	.3052
3	.3561	.3185	.3052
4	.4748	.3521	.4578
5	.4917	.4024	.4973
6	.5087	.4694	.5304
7		.5533	
8	.5765	.6036	
9	.724	.6722	
10	.743	.7049	
11	.724	.6668	
12	.724	.6859	
13	.724	.724	
14	.724	.5335	
15	.6668	.6478	
16	.7049	.6668	
17	.7811		
18	.6203	.2883	
19	.4527	.5801	
20	.4191	.4239	
21	.4191	.373	
22	.4191	.3561	
23	.3521	.3391	
24	.3561	.3185	.3222
Max	.7811	.724	.5304
Min	.3391	.2883	.3052
Avg	.5503	.4921	.3915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074069 / 33 KV ROHANA

Feeder No / Name : 203 / 11 KV DIWTHANA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.6287	.4973	.5533	.8002
2				.6287	.4973	.5533	.8002
3				.6097	.4973	.5533	.8002
4				.6097	.547	.6036	.8002
5				.6668	.5801	.6203	.8002
6				.8383	.779	.6539	.8192
7			.5304	.9145	.8848	.8718	1.0479
8			.5365	.9054	.9555	.8215	.8002
9			.6464	.4694	.9012	.9054	1.0288
10			.5636	.5868	.8573	.9175	.9389
11	.4382	.3429	.7773	.57	.7621		.5944
12	.4191		.7773	.6036	.8383		.7209
13	.362		.7926	.6036	.8764		.7545
14	.3048		.7926	.7042	.8764		.7042
15	.2667	.3429	.7621	.7545	.9145	.7522	.7042
16	.2667	.3429	.6859	.6036	.8048	.8223	.7042
17	.2667		.9717	.6036	.8383	.8954	.5556
18	.1677	.2058	.9907	.6036	.503	.8002	.6019
19			.7049	.7459	.8048	.8573	.5864
20			.6859	.663	.5533	.6859	.5093
21			.4954	.6464	.4191	.6478	.4531
22			.4763	.57	.4191	.5716	.4062
23			.4572	.5144	.4024	.5335	.3795
24				.4191	.3563	.3521	.5144
Max	.4382	.3429	.9907	.9145	.9555	.9175	1.0479
Min	.1677	.2058	.4572	.4191	.3563	.3521	.3795
Avg	.3115	.3086	.6851	.6443	.6819	.6986	.7010

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074069 / 33 KV ROHANA

Feeder No / Name : 204 / 11 KV NIMKAWALA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1029	.1715				
2	.1715	.1132	.1715				
3	.1715		.1543				
4	.1543	.1543	.1372				
5	.1886	.0309	.1543				
6	.2713	.3688	.2229				
7		.4024	.3391				
8	.3086	.4115	.3772				
9	.2858	.3772	.3086				
10	.2858	.381	.3086				
11				.6478	.724		.7545
12				.4694	.6859	.7209	.7712
13				.503	.6097	.664	.6706
14				.3658	.5716	.5992	.6706
15				.4359	.5144	.5344	.6036
16				.4359	.5197	.502	.5533
17				.503	.503	.6478	.4904
18				.5144		.5144	.4161
24	.4031						
Max	.4031	.4115	.3772	.6478	.724	.7209	.7712
Min	.1543	.0309	.1372	.3658	.503	.502	.4161
Avg	.2412	.2602	.2345	.4844	.5898	.5975	.6163

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074069 / 33 KV ROHANA

Feeder No / Name : 205 / 11 KV ROHANA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1791	.2058	.1791	.2096	.1829	.2012	.2096
2	.1791	.2058	.1791	.2096	.2012	.2012	.2096
3	.1791	.2058	.1791	.1905	.2012	.2058	.1905
4	.1612	.1886	.1791	.1905	.2012	.2012	.1905
5	.1791	.1715	.1791	.1905		.2229	.2096
6	.1612	.1543	.197		.2353	.2347	.2286
7		.1543	.1612	.2096	.2012	.218	.2286
8	.1433	.1543	.1629	.1886	.1646	.1844	.1715
9	.1334	.012	.1629		.1629	.1677	.1844
10	.1334	.1524	.1463		.1715	.181	.1509
11	.1905	.1905	.1629		.1905		.1509
12	.1905	.1905	.1463		.1715	.1646	.1677
13	.2096	.1905	.1646		.1715	.181	.1341
14	.2096	.2096	.181		.1715	.181	.1341
15	.2096	.2096	.181		.1905	.181	.1677
16	.2096	.2096	.1629	.2229	.1677	.1791	.1509
17	.2096		.1524	.2012	.2012	.1905	.1595
18	.2058	.181	.2096	.3258	.2012	.1715	.1772
19	.2058	.2507	.2667	.2715	.2515	.2477	.2303
20	.2683	.3045	.3048	.2534	.2713	.2858	.2658
21	.2401	.2534	.2667	.2715	.2369	.2667	.2835
22	.218	.2353	.2477	.2534	.2058	.2858	.2303
23	.2058	.2172	.2286	.2172	.2012	.2286	.2126
24	.197	.2012	.1991	.2096	.1991	.2058	.2286
Max	.2683	.3045	.3048	.3258	.2713	.2858	.2835
Min	.1334	.012	.1463	.1886	.1629	.1646	.1341
Avg	.1921	.1934	.1917	.2260	.1980	.2081	.1945

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074099 / 33/11 kV Dhorapgaon

(Bhalegaon

Feeder No / Name : 201 / 11 KV KALEGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2126	.2972					.1677
2	.2126	.2972					.1677
3	.2126	.3567					.1677
4	.2126	.3612					.1698
5	.2835	.3612					.1852
6	.5138	.3612					.4877
7	.631	.4755					.5213
8	.4075	.5312					.7926
9	.4252	.4012					.7099
10	.3121	.5249					.6878
11			.7116		.9593	.8436	
12			.6405		.9412	.7316	
13			.4458		.7783	.6539	
14			.4012	.1543	.4887	.703	
15			.4458	.6173	.5249	.6944	
16			.4816	.7116	.543	.578	
17			.4489	.7621	.6878	.5944	
18			.3429	.5357	.4887	.431	
24	.373						
Max	.631	.5312	.7116	.7621	.9593	.8436	.7926
Min	.2126	.2972	.3429	.1543	.4887	.431	.1677
Avg	.3451	.3968	.4898	.5562	.6765	.6537	.4057

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074099 / 33/11 kV Dhorapgaon

(Bhalegaon

Feeder No / Name : 203 / 11 KV DHORAPGAON GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5847	.547	.5415	.5281	.5658	.5601	.5093
2	.5847	.547	.5415	.5093		.5601	.5093
3	.5847	.547	.5415	.5093	.5335	.4973	.5093
4	.5847	.5093	.5415	.5093	.5281	.5415	.5093
5	.5658	.5093	.5415		.5281	.5415	.5093
6	.5281	.5093	.4904	.4904	.5281	.4973	.5281
7	.4668	.4527	.3961	.3961	.4668	.5041	.439
8	.4527	.3734	.3395		.4294	.3961	
9	.4527	.3734	.3584		.4024	.3395	.4066
10	.4805	.3395	.3734		.3584	.3174	.415
11	.4481	.3772	.3018		.3772	.2987	.3772
12	.5041	.415	.3584		.415	.3174	.3772
13	.5041	.4338	.3206		.4527	.3547	.415
14	.5041	.4715	.4108	.3547	.4904	.3734	.415
15	.5041	.4715	.4024	.499	.4904	.3921	.415
16	.4481	.4527	.4435	.499	.4904	.4294	.3772
17	.4481	.3772	.4024	.4435	.4527	.3881	.3961
18	.4477	.3961	.4024	.439	.3961	.3734	.4527
19	.5975	.4338	.499	.5729	.4904	.4938	.5175
20	.6722	.6348	.5658	.6602	.6348	.6348	.5487
21	.6722	.6161	.6036	.6602	.5975	.6161	.6219
22	.6161	.5975	.6036	.6413	.5788	.5847	.6219
23	.5847	.5658	.5658	.5847	.5788	.5658	.6036
24	.5847	.547	.5415	.5281	.5658	.5601	.5093
Max	.6722	.6348	.6036	.6602	.6348	.6348	.6219
Min	.4477	.3395	.3018	.3547	.3584	.2987	.3772
Avg	.5342	.4791	.4620	.5191	.4935	.4641	.4775

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074103 / 33/11 kV Palshi

Feeder No / Name : 201 / 11 KV AMBIKAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.6661
Max	.6661
Min	.6661
Avg	.6661

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074103 / 33/11 kV Palshi

Feeder No / Name : 202 / 11 KV PALSHI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4024	.2743	.4887	.5068	.4854		.1991
2	.362	.2572	.4887	.5068	.4525		.1991
3	.3734	.2572	.4706	.5068	.499		.1991
4	.3921	.2572	.4706	.5068	.5228		.1991
5	.2772	.2572	.4887	.4706	.5415		.2172
6	.2561	.2743	.3801	.362	.3982		.2172
7	.2054	.2743	.3077	.2896	.3326		.1991
8	.2172	.2401	.2896	.2172	.2534		.1991
9	.2587	.2229	.2896	.2353	.2561		.1991
10	.2058	.2229	.2896	.2715	.3258		.1629
11		.3658	.2353	.2743	.2058		.362
12		.4207	.3077	.2801	.3429	.128	.2896
13	.3944	.4938	.2896	.2743	.3086	.1132	.4344
14	.4973	.4075	.2534	.2614	.2743	.2195	.4706
15	.4973	.2926	.2715	.2743	.3086	.2926	.4706
16	.4973	.2561	.2534	.3174	.2915	.2561	.3258
17	.3772		.2534	.2715	.3086	.2743	.3439
18	.3086	.362	.181	.2427	.2401	.3109	.3258
19	.3429	.4525	.3439	.4755	.3429	.2353	.4163
20	.5144	.5973	.543	.6099		.3258	.5792
21	.5487	.6154	.543	.543		.2353	.5792
22	.5316	.5792	.5611	.5975		.543	.5611
23	.5144	.543	.543	.567		.543	.543
24	.5304	.5487	.5068	.5068	.5487		.5249
Max	.5487	.6154	.5611	.6099	.5487	.543	.5792
Min	.2054	.2229	.181	.2172	.2058	.1132	.1629
Avg	.3866	.3684	.3771	.3904	.3620	.2898	.3424

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074103 / 33/11 kV Palshi

Feeder No / Name : 203 / 11 KV KADMAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3841	.1886	.3982	.4163	.3734		.1991
2	.3361	.1543	.3982	.3982	.3734		.181
3	.2896	.1543	.3801	.3982	.3326		.1448
4	.2743	.1543	.3856	.3982	.3547		.1267
5	.1867	.1543	.3982	.3801	.2957		.1267
6	.1848	.1886	.2896	.2896	.2715		.1267
7	.1629	.1543	.2534	.3077	.2241		.1267
8	.1267	.1543	.1991	.1991			.1448
9	.1494	.12	.1991	.2172	.2353		.1086
10	.1029	.1372	.2172	.2353	.2401		.1267
11		.2835	.181	.2172	.1543		.2534
12		.3475	.1991	.2054	.1886		.2896
13	.3429	.3721	.181	.1848	.1886		.3439
14	.4287	.3658	.1629	.1867	.1715	.0183	.3439
15	.4287	.3292	.1629	.181	.1715		.3439
16	.4115	.2926	.181	.1848	.1715	.1086	.2896
17		.2561	.1629	.181	.1715		.2715
18		.2715	.1267	.1307	.12	.181	.2172
19	.3258	.3439	.2896	.3258	.3086	.2172	.2896
20	.4801	.4706	.3982	.4668		.2172	.4344
21	.4973	.4887	.4344	.4435		.2534	.4525
22	.4458	.4525	.4525	.4668		.3801	.4525
23	.4115	.4344	.4344	.4344		.4163	.4344
24	.4163	.4287	.4163	.4163	.3982		.3982
Max	.4973	.4887	.4525	.4668	.3982	.4163	.4525
Min	.1029	.12	.1267	.1307	.12	.0183	.1086
Avg	.3193	.2791	.2876	.3027	.2497	.2240	.2594

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074026 / 33 kv MIDC Khamgaon s/s

Feeder No / Name : 201 / 11 kv Vardhan

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6478	.6097	.6478	.3734	.6478	.6478
2	.6859	.6478	.6097	.6478	.3734	.6478	.6478
3	.6859	.6478	.6097	.6478	.3788	.6287	.6287
4	.6859	.6478	.5906	.6478	.5281	.6287	.6287
5	.6859	.6478	.5906	.6478	.3788	.6478	.6097
6	.6859	.6478	.5906	.6478	.5281	.6478	.5716
7	.6097	.6097	.5716	.6478	.3368	.6097	.5716
8	.6097	.6478	.5335	.6287	.3071	.5906	.5716
9	.6478	.7621	.5335	.724	.6859	.6478	.5247
10	.724	.6859	.724	.7621	.724	.7621	.6104
11	.7621	.6478	.724	.7621	.724	.7621	.6226
12	.7621	.6859	.7621	.7621	.724	.724	.6661
13	.7621	.6859	.6706	.7621	.724	.7621	.5304
14	.7621	.724	.6443	.7621	.724	.7621	.7087
15	.7621	.724	.6733	.724	.724	.7621	.5487
16	.7621	.724	.6443	.6859	.724	.7621	.6733
17	.724	.2378	.6554	.5213	.7049	.6935	.7621
18	.5906	.4108	.4999	.4329	.5716	.4816	.6859
19	.6287	.3944	.5117	.3254	.6287	.4858	.6478
20	.6478	.3841	.4858	.3429	.6287	.4016	.6478
21	.6478	.4287	.4816	.4115	.6478	.4207	.6097
22	.6668	.4058	.4451	.3894	.6668	.6478	.6097
23	.6668	.6097	.6668	.4001	.6478	.6478	
24	.6097	.6478	.6097	.6478	.4001	.6478	.6478
Max	.7621	.7621	.7621	.7621	.724	.7621	.7621
Min	.5906	.2378	.4451	.3254	.3071	.4016	.5247
Avg	.6859	.5960	.6016	.6075	.5773	.6425	.6249

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074026 / 33 kv MIDC Khamgaon s/s

Feeder No / Name : 202 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.3429	.3429	.2858	.1372	.3429	.4572
2	.381	.3429	.3048	.2858	.1372	.3429	.4572
3	.381	.3429	.3048	.2667	.1212	.3429	.4572
4	.381	.3429	.3048	.2667	.1326	.3429	.4191
5	.381	.3429	.2858	.2667	.1326	.3429	.4191
6	.381	.3429	.2858	.2477	.1326	.381	.4572
7	.381	.3429	.3048	.2667	.1372	.3429	.4572
8	.381	.381	.3048	.2286	.1303	.3429	.4572
9	.4191	.381	.3429	.2286	.3048	.4191	.3887
10	.4191	.4572	.381	.2286	.3429	.4572	.5853
11	.4572	.5335	.3429	.2286	.3429	.4954	.5914
12	.4572	.5335	.3048	.2286	.381	.5335	.5914
13	.4954	.5335	.2804	.2286	.381	.5335	.5068
14	.4954	.4954	.3544	.2286	.381	.5335	.5487
15	.5335	.4572	.3018	.2286	.4191	.5716	.5014
16	.5335	.4954	.3224	.2286	.4572	.5716	.5121
17	.5525	.2454	.3086	.1898	.4382	.4854	.5716
18	.4954	.3189	.2561	.1875	.381	.4481	.5335
19	.4763	.2454	.2214	.1898	.3429	.3506	.5335
20	.4191	.2804	.2561	.1578	.3239	.4854	.5335
21	.381	.2713	.2469	.16	.3048	.4805	.5716
22	.362	.3086	.2187	.1463	.3048	.4954	.5716
23	.381	.3048	.2858	.1372	.3429	.4954	
24	.381	.3429	.3048	.2858	.1372	.3429	.4763
Max	.5525	.5335	.381	.2858	.4572	.5716	.5914
Min	.362	.2454	.2187	.1372	.1212	.3429	.3887
Avg	.4294	.3744	.2986	.2249	.2769	.4367	.5043

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074026 / 33 kv MIDC Khamgaon s/s

Feeder No / Name : 203 / 11 kv Khamgaon Syntex NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.4954	.4763	.5144	.2881	.4001	.4572
2	.4954	.4954	.4572	.4954	.2881	.4001	.4572
3	.4954	.4954	.4954	.4954	.2606	.4001	.4572
4	.4954	.4954	.4954	.4954	.362	.4191	.4382
5	.4954	.4954	.4954	.4954	.362	.4191	.4191
6	.4954	.4954	.5144	.4954	.362	.4572	.4191
7	.4572	.5335	.5144	.5144	.3567	.4382	.4191
8	.4572	.5716	.5144	.5144	.3338	.4382	.4001
9	.4191	.5335	.5144	.5335	.5716	.4191	.3269
10	.4191	.5335	.5525		.5335	.4954	.2808
11	.4572	.4954	.6097	.5716	.6097	.5716	.5973
12	.4954	.5335	.6668	.5716	.6097	.6478	.6335
13	.4572	.5335	.6268	.5716	.5716		.5792
14	.4572	.5335	.5365	.5335	.6478		.6089
15	.4191	.5335	.5596	.5335	.724		.7167
16	.4191	.5335	.5784	.4954	.5716		.4973
17	.4572	.3549	.4877	.1395	.5906	.4287	.5335
18	.4382	.5731	.442	.1509	.6287	.3315	.5716
19	.4763	.4816	.4666	.4641	.6287	.2934	.5716
20	.4572	.503	.3715	.3814	.5716	.3144	.5335
21	.4572	.4578	.4527	.4268	.5335	.2848	.4954
22	.4572	.4733	.4917	.4365	.4954	.4572	.4572
23	.4572	.4954	.4954	.4049	.4191	.4954	
24	.4191	.4954	.4954	.4954	.3064	.4001	.4954
Max	.4954	.5731	.6668	.5716	.724	.6478	.7167
Min	.4191	.3549	.3715	.1395	.2606	.2848	.2808
Avg	.4604	.5059	.5129	.4665	.4845	.4256	.4942

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074026 / 33 kv MIDC Khamgaon s/s

Feeder No / Name : 204 / 11 kv Federation

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.1431	1.0288	1.0479	.6874	.9907	1.0288
2	1.1431	1.1431	1.0288	1.0479	.7202	1.0288	1.0288
3	1.1431	1.1431	1.0479	1.0669	.6622	1.0479	1.0288
4	1.1431	1.1431	1.0288	1.0669	.6455	1.0288	1.0479
5	1.1431	1.1431	1.0669	1.0479	.6539	1.0288	1.0288
6	1.2574	1.1431	1.105	1.105	.7701	1.0288	1.0288
7	1.1812	1.1431	1.2193	1.1241	.7099	1.105	1.0669
8	1.1812	1.2193	1.4098	.9907	.8139	1.2574	1.1622
9	1.6385	1.6385	1.5623	.9907	1.2955	1.4861	1.3121
10	1.5623	1.7909	1.7147	.9907	1.5623	1.7909	1.6409
11	1.5623	1.9052	1.6766	1.0288	1.7147	1.7147	1.3817
12	1.448	1.9814	1.9052	1.0669	1.7528	1.7147	1.4045
13	1.6385	1.9814	1.7353	1.0669	1.829	1.7528	1.0692
14	1.7147	2.0195	1.8861	1.105	1.829	1.829	1.5466
15	1.7528	1.9433	1.6975	1.105	1.7909	1.8671	1.5089
16	1.829	1.9052	1.773	1.105	1.6385	1.8671	1.4901
17	1.5623	.9412	1.9433	1.0387	1.7528	1.7364	1.6385
18	1.5623	1.2936	1.4563	.8356	1.3146	1.5708	1.5242
19	1.2384	1.1827	1.39	.8288	1.4861	1.4003	1.3336
20	1.2193	.985	.9945	.7343	1.1431	1.2382	1.2193
21	1.1812	.964	.9882	.7316	1.105	1.1706	1.0288
22	1.1241	.9362	.9389	.7099	1.0479	1.1431	.9526
23	1.1431	1.0669	1.0479	.4049	.9907	1.0288	
24	1.1812	1.1431	1.0669	1.0288	.7186	.9526	1.0288
Max	1.829	2.0195	1.9433	1.1241	1.829	1.8671	1.6409
Min	1.1241	.9362	.9389	.4049	.6455	.9526	.9526
Avg	1.3622	1.3708	1.363	.9695	1.1931	1.3658	1.2392

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074026 / 33 kv MIDC Khamgaon s/s

Feeder No / Name : 205 / 11 kv Industrial

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1905	.1905	.1524	.2374	.2667	.2286
2	.1524	.1905	.1905	.1524	.2294	.2667	.2286
3	.1524	.1905	.1905	.1524	.1989	.2667	.2286
4	.1524	.1905	.1524	.1524	.192	.2667	.2286
5	.1524	.1905	.1524	.1905	.2561	.2667	.2286
6	.1905	.1905	.1524	.1905	.2561	.2667	.2286
7	.2667	.1524	.1905	.1143	.2561	.2667	.2286
8	.2667	.1524	.2286	.1143	.1943	.2667	.2286
9	.3429	.2667	.2286	.2667	.3429	.2667	.2987
10	.3429	.3048	.2286	.3048	.3048	.3429	.2865
11	.3429	.3429	.3048	.2667	.3048	.3048	.2987
12	.381	.3429	.3048	.2286	.3048	.2667	.2987
13	.3429	.3429	.3018	.2286	.3048	.3048	.2865
14	.3429	.3429	.3772	.2286	.3048	.3048	.2926
15	.3048	.3429	.3018	.2286	.3048	.3429	.2865
16	.3048	.2667	.2263	.2286	.3048	.3429	.2865
17	.3429	.2263	.1886	.1524	.3429	.3361	.3048
18	.2667	.2149	.1509	.1524	.3429	.2743	.2667
19	.3429	.2957	.1509	.1692	.3048	.1852	.1905
20	.2667	.1848	.1509	.144	.3048	.1875	.1905
21	.2286	.1132	.0148	.1578	.3048	.1966	.1905
22	.1905	.1478	.1494	.1623	.3048	.1905	.1905
23	.1905	.1524	.1524	.1783	.2667	.1905	
24	.1905	.1905	.1524	.1524	.1852	.2667	.2286
Max	.381	.3429	.3772	.3048	.3429	.3429	.3048
Min	.1524	.1132	.0148	.1143	.1852	.1852	.1905
Avg	.2588	.2303	.2013	.1862	.2772	.2682	.2489

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074026 / 33 kv MIDC Khamgaon s/s

Feeder No / Name : 206 / 11 KV SUTALA BK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8002	.7621	.8192	.8002	.8316	.9145	.8002
2	.8002	.7621	.7621	.7621	.8131	.8764	.7621
3	.8002	.7621	.724	.724	.7392	.8573	.7621
4	.8002	.7621	.6859	.724	.7133	.8383	.7621
5	.8002	.7621	.6097	.6478	.7207	.7621	.6859
6	.724	.7621	.5716	.6097	.6468	.724	.6287
7	.6097	.6097	.5335	.5335	.5973	.6287	.6097
8	.6097	.5716	.4954	.5144	.5611	.6097	.5716
9	.6478	.5716	.4763	.4954	.5335	.4954	.5493
10	.6478	.5716	.4572	.4954	.4954	.4954	.4801
11	.6478	.5716	.5335	.5335	.6097	.4954	.5249
12	.6478	.6478	.4954	.5716	.6859	.4572	.543
13	.724	.6859	.5611	.6097	.6859	.5716	.5973
14	.7621	.6859	.5611	.6097	.7621	.6097	.6154
15	.8383	.8002	.6697	.6859	.8002	.6478	.6335
16	.8383	.8383	.6697	.7621	.7621	.724	.6335
17	.8002	.394	.591	.6697	.7811	.6516	.6097
18	.8192	.5316	.6024	.6626	.7621	.6878	.6097
19	.7811	.5731	.6335	.7164	.8192	.7265	.6478
20	.8383	.8596	.7133	.8507	.8573	.7783	.724
21	.8764	.9055	.7577	.8779	.8764	.823	.7621
22	.9526	.924	.8131	.9055	.9145	.8383	.8764
23	.9526	.8764	.8573	.961	.9145	.8192	
24	.9717	.7621	.8383	.8383	.8779	.9526	.8002
Max	.9717	.924	.8573	.961	.9145	.9526	.8764
Min	.6097	.394	.4572	.4954	.4954	.4572	.4801
Avg	.7788	.7064	.643	.6900	.7400	.7077	.6604

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074026 / 33 kv MIDC Khamgaon s/s

Feeder No / Name : 401 / 33 kv HLL Stand by NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.829	2.0576	2.1148	1.829	1.9433	1.9433	1.829
2	1.829	2.0576	2.0576	1.829	1.8861	1.9433	1.829
3	1.829	2.0576	4.9154	1.829	1.9433	1.829	1.829
4	1.829	2.0576	2.0576	1.829	1.829	1.829	1.7718
5	1.829	2.0576	2.0005	1.8861	1.829	1.7147	1.7147
6	1.829	1.829	1.9433	1.9433	1.829	1.7147	1.7147
7	1.829	1.829	1.829	1.4861	1.8861	1.7718	1.829
8	1.829	2.1719	1.829	1.829	1.9433	2.0576	1.829
9	1.9433	2.0576	1.8861	1.9433	2.0576	2.2862	2.0005
10	2.0576	2.1719	2.1719	1.9433	2.0576	2.0576	1.8861
11	2.0576	2.2862	2.0005	2.0576	2.0576	1.9433	2.0005
12	2.1719	2.1719	2.0005	2.1719	2.0576	2.1719	2.0005
13	1.9433	2.1719	2.0005	2.1719	2.1719	2.1719	1.8861
14	1.9433	2.1719	1.8861	2.1719	2.1719	2.1719	2.1148
15	1.9433	2.1719	1.8861	2.1719	2.1719	2.1719	1.7718
16	2.1719	1.9433	1.7718	2.1719	2.1719	2.1719	2.0005
17	2.1719	2.1148	1.829	2.0576	1.9433	2.1148	2.0576
18	2.1719	2.0576	1.7718	2.0576	2.1719	2.1148	2.1719
19	2.1719	1.9433	1.9433	2.3434	2.0576	2.0576	2.1719
20	2.1719	2.0005	1.9433	2.2291	2.1719	1.9433	2.0576
21	2.1719	1.9433	1.8861	2.2291	2.1719	2.0005	2.0576
22	2.1719	1.9433	1.9433	2.0005	2.2291	1.829	1.9433
23	2.1719	1.829	1.829	2.0005	1.9433	1.829	
24	2.1148	2.0576	1.9433	1.829	2.0005	1.9433	1.829
Max	2.1719	2.2862	4.9154	2.3434	2.2291	2.2862	2.1719
Min	1.829	1.829	1.7718	1.4861	1.829	1.7147	1.7147
Avg	2.0076	2.0481	2.0600	2.0005	2.0290	1.9909	1.9259

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074048 / 33 kv Sajanpuri s/s

Feeder No / Name : 201 / 11 kv Ghatpuri

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.703	.703				.7202	.6173
2	.6859	.6516	.6859			.7202	.6173
3	.6687	.6516	.6859			.7202	.6173
4	.6687	.6344	.6516			.6859	.6173
5	.6344	.6173	.6173			.6173	.6173
6	.5658	.6001	.5487				.6687
7	.5487	.5658	.5144			.5144	.583
8	.5316	.6173	.5487		.6097	.4458	.5658
9	.5487		.583		.6859	.5487	.5144
10	.5487	.5487			.3429		.463
11	.6001	.583			.3429		.583
12	.6344	.7202			.3086		.6344
13	.703	.7545			.3429		.6173
14	.8059	.7545			.7545		.6344
15	.4973	.7545			.7888		.6001
16	.823				.7888		.6344
17	.7373				.7202		.6001
18	.583				.6516		.583
19	.6344				.6859		.6173
20	.7373		.7811		.6859	.3429	.6859
21	.7545				.7202		.6859
22	.703				.7545		.7202
23	.8059		.7621	.8764	.7202		.7545
24	.7716	.7545	.7202	.7621	.8764	.7202	.6516
Max	.823	.7545	.7811	.8764	.8764	.7202	.7545
Min	.4973	.5487	.5144	.7621	.3086	.3429	.463
Avg	.6623	.6607	.6454	.8193	.6341	.6036	.6201

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074048 / 33 kv Sajjanpuri s/s

Feeder No / Name : 203 / 11 kv Sajjanpuri

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3429	.3429		.3429	.3086
2	.3086	.3258	.3429		.3429	.3086
3	.3086	.3258	.3429		.3429	.3086
4	.2915	.3086	.3429		.3429	.3086
5	.2915	.2915	.3086		.3429	.3086
6	.2743	.2915	.2743		.3086	.3086
7	.2743	.2743	.2743		.2743	.2743
8	.2743	.2743	.2743	.362	.3086	.2743
9	.2915		.2743	.3048	.2743	.3086
10	.2915	.2743		.2743		.3086
11	.2915	.2743		.2743		
12	.3086	.3429		.3086		.3086
13	.3429	.3429		.3086		.2915
14	.3258	.3429		.3429		.3086
15	.3258	.3086		.3429		.2915
16	.2915			.3429		.3429
17	.3086			.3086		.3258
18	.3258		.3429	.3429		.3086
19	.3086			.3772		.3086
20	.3429			.3429	.3429	.3086
21	.3429			.3429		.3086
22	.3429			.3429		.3258
23	.3429		.3429	.3429		.3429
24	.3086	.3429	.3429	.381	.3429	.3086
Max	.3429	.3429	.3429	.381	.3429	.3429
Min	.2743	.2743	.2743	.2743	.2743	.2743
Avg	.3093	.3109	.3172	.3319	.3242	.3086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074076 / 33 KV RUSHI SANKUL S/S

Feeder No / Name : 201 / 11 kv Industrial
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0669	1.2193	1.0288	1.448	1.3717	1.1431	1.1431
2	1.0669	1.1812	.9907	1.448	1.3717	1.1431	1.1812
3	1.105	1.1812	1.0288	1.5242	1.2955	.9526	1.2193
4	1.105	1.1431	.9907	1.5242	1.2955	1.105	1.2955
5	1.105	1.1431	.9526	1.5242	1.2574	1.105	1.3336
6	1.2193	.9907	.9526	1.448	1.2193	1.0288	1.3146
7	1.105	1.105	.8002	1.2574	1.1431	1.0288	1.105
8	.9526	1.0288	.9145	1.2574	1.0669	1.0669	1.0288
9	1.1431	1.4098	.8764	1.5623	1.3717	1.0669	1.448
10	1.2193	1.4098	1.105	1.448	1.3336	1.1812	1.3717
11	1.2955	1.3717	1.4861	1.1431	1.1431	1.3717	1.2193
12	1.2955	1.6766	1.448	1.2955	1.4098	1.5623	1.2193
13	1.4098	1.6385	1.3717	1.2193	1.6004	1.5242	1.2574
14	1.2955	1.6385	1.3336	1.3717	1.1812	1.4098	1.2193
15	1.2193	1.7147	1.3336	1.6004	1.4861	1.448	1.0288
16	1.2574	1.7528	1.5242	1.6385	1.5623	1.4098	1.105
17	1.2193		1.3336	1.5242	1.5242	1.2193	1.105
18	1.1431		1.3717	1.4861	1.3717	1.2193	1.0288
19	1.1812		1.2574	1.3336	1.3717	1.2574	1.0288
20	1.0669		1.2574	1.1431	.6097	.9907	.9907
21	1.3336	.8002	1.4098	1.4098	.9907	1.3336	1.2193
22	1.3336	1.1431	1.4098	1.3717	1.105	1.2955	1.3717
23	1.4098	1.1431	1.5242	1.3336	1.105	1.0669	1.2955
24	1.0669	1.2955	1.105	1.4098	1.4098		1.0669
Max	1.4098	1.7528	1.5242	1.6385	1.6004	1.5623	1.448
Min	.9526	.8002	.8002	1.1431	.6097	.9526	.9907
Avg	1.1923	1.2993	1.2003	1.4051	1.2749	1.2143	1.1915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074076 / 33 KV RUSHI SANKUL S/S

Feeder No / Name : 202 / 11 kv Januna

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2401	.1254	.1372	.1543	.1612	.1543
2	.2743	.2229	.1254	.1372	.1543	.1612	.1387
3	.2743	.2229	.1254	.1372	.1372	.1612	.156
4	.2743	.2401	.1254	.1372	.1372	.1433	.1372
5	.2743	.2401	.1254	.1372	.1372	.1433	.1372
6	.2401	.1372	.1075	.12	.1372	.1433	.1214
7	.1372	.12	.1075	.12	.12	.1254	.1029
8	.12	.12	.0895	.1372	.1029	.197	.1029
9		.12	.0857	.1612	.1372	.2915	.12
10	.1254	.1372	.1543	.1075	.1543	.2804	.1543
11	.1254	.1715	.1886	.1612	.1715	.2804	.2915
12	.1612	.1886	.1372	.1612	.1886	.2103	.2743
13	.1791	.1715		.1433	.1543	.2103	.3086
14	.1433	.1372	.1029	.1254	.1543	.2103	.2572
15	.1433	.1372	.1715	.1254	.1543	.298	.3086
16	.1254	.1886	.1372	.1254	.1372	.2804	.3086
17	.1543		.1372	.1372	.1791	.3391	.2279
18	.1886	.1433	.1543	.1543	.2507	.1715	.2629
19	.2058	.1433	.1372	.1543	.1433	.3052	.2804
20	.1715	.1433	.1372	.2058	.1075	.3086	.2804
21	.1715	.1791	.1543	.2058	.1433	.1734	.1578
22	.2572	.1433	.1543	.2058	.2507	.1372	.1578
23	.2401	.1433	.1372	.1715	.1612	.156	.1578
24	.1801	.2572	.1254	.1372	.1543	.1612	.156
Max	.2743	.2572	.1886	.2058	.2507	.3391	.3086
Min	.12	.12	.0857	.1075	.1029	.1254	.1029
Avg	.1916	.1716	.1324	.1477	.1551	.2104	.1981

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074076 / 33 KV RUSHI SANKUL S/S

Feeder No / Name : 203 / 11 kv Omkareshwar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8871	.8962	.8589	.8871	.8589	.8775	.8215
2	.8501	.7888	.8402	.8501	.8589	.8589	.7842
3	.8131	.8573	.8402	.8501	.7842	.8589	.7947
4	.7545	.8573	.8402	.8501	.7842	.8402	.8215
5	.8131	.8589	.7842	.8501	.7842	.8029	.7842
6	.7577	.8002	.6908	.7207	.7655	.7468	.7207
7	.7392	.7655	.6535	.6283	.7468	.7282	.7023
8	.7343	.7095	.6535	.7023	.7468	.7095	.6908
9	.6535	.6653	.6097	.6161	.6722	.6468	.6348
10	.7095	.6653	.5525	.5975	.6908	.5914	.5788
11	.7468	.6653	.5601	.6348	.6161	.6099	.5788
12	.7655	.6838	.5975	.5601	.7095	.5914	.6535
13	.7842	.6838	.5788	.6348	.7282	.1951	.6348
14	.8029	.7207	.6348	.7282	.7282	.6283	.6722
15	.8215	.7762	.6348	.8215	.7282	.6468	.6348
16	.8029	.7392	.6344	.8029	.7468	.6838	.6908
17	.8402		.7577	.7468	.7282	.6908	.6653
18	.7282	.7282	.6838	.7095	.7282	.6838	.6468
19	.7282	.7655	.7207	.7655	.7655	.7842	.7023
20	.8764	.8589	.7392	.8402	.7095	.8215	.8131
21	.8775	.8215	.7947	.8775	.8775	.8962	.8501
22	.9335	.8962	.8316	.8962	.9149	.8775	.8686
23	.9709	.8962	.8871	.9149	.9149	.8775	.9055
24	.9425	.9149	.8589	.8871	.8962	.8962	.8589
Max	.9709	.9149	.8871	.9149	.9149	.8962	.9055
Min	.6535	.6653	.5525	.5601	.6161	.1951	.5788
Avg	.8056	.7832	.7182	.7655	.7702	.7310	.7295

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074076 / 33 KV RUSHI SANKUL S/S

Feeder No / Name : 407 / 33 KV HIVARKHED NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 33 / INCOMING UTILITY

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.773	1.9342	2.6863	2.1491	2.8475	1.5581	2.0416
2	1.8804	2.1491	2.5252	2.0953	2.5789	1.5581	2.0633
3	1.8804	2.2565	2.4177	2.0416	2.5789	1.5746	1.9879
4	2.0416	2.2565	.8059	2.0416	2.4714	1.5043	1.8804
5	2.0953	2.2862	.7522	2.2565	2.4714	1.8804	.9134
6	2.6326	2.7938	1.1283	2.7401	2.5789	2.6326	1.7193
7	3.2236	2.4177	1.0745	3.3848	2.8475	1.9342	1.9879
8	2.955	2.2565	1.7193	3.0624	2.4177	1.0745	1.8267
9	2.8475	2.3102	1.7193	3.0087	1.8267	1.4506	1.8267
10	1.9879	2.955	1.4506	2.6326	2.0953	1.2357	1.7193
11	2.2028	3.1699	2.5789	3.3848	2.6863	2.4714	2.9012
12	2.0953	3.2773	2.5252	3.3311	2.5252	2.1491	2.5789
13	2.0416	3.3311	2.5252	3.3311	2.5252	2.5252	2.4177
14	2.0953	2.364	2.5252	2.3102	2.6863	3.0087	1.4506
15	2.7938	3.1699	2.5252	2.5789	2.7401	3.2773	1.3969
16	1.7193	3.9758	2.7401	2.6863	2.7401	3.2236	2.1491
17	2.8475	2.1491	2.7401	2.6326	3.0087	2.8475	2.2565
18	2.955	2.2565	2.0953	2.7401	3.1161	2.7401	2.4714
19	3.1699	2.7401	2.4177	2.9012	3.1161	2.7938	2.6863
20	3.4385	3.2236	2.6326	3.1161	1.0745	2.7401	2.955
21	3.0624	2.9012	2.5252	2.7401	1.0208	2.4434	2.7401
22	2.7938	2.7938	2.1491	2.7938	1.9879	2.364	2.364
23	2.1491	2.7938	2.364	2.8292	1.1283	2.2028	2.0953
24	1.6655	1.8804	2.7938	2.1491	2.8475	1.3432	2.1491
Max	3.4385	3.9758	2.7938	3.3848	3.1161	3.2773	2.955
Min	1.6655	1.8804	.7522	2.0416	1.0208	1.0745	.9134
Avg	2.4311	2.6518	2.1424	2.7057	2.4132	2.1889	2.1074

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 077003 / 132 kv Khamgaon s/s

Feeder No / Name : 201 / 11 kv Town-I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	05-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)
1		.0154
2		.0171
3		.0171
4		.0171
5		.0171
6		.0171
7		.0189
8		.0189
17	.0154	
24		.0154
Max	.0154	.0189
Min	.0154	.0154
Avg	.0154	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 077003 / 132 kv Khamgaon s/s

Feeder No / Name : 202 / 11 kv Cotton Market

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.0109
Max	.0109
Min	.0109
Avg	.0109

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 077003 / 132 kv Khamgaon s/s

Feeder No / Name : 204 / 11 kv Polytechnic
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	01-JUN-18
HR	Load (MW)
24	.0085
Max	.0085
Min	.0085
Avg	.0085

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 077003 / 132 kv Khamgaon s/s

Feeder No / Name : 205 / 11 kv Town- II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.0325
Max	.0325
Min	.0325
Avg	.0325

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 077003 / 132 kv Khamgaon s/s

Feeder No / Name : 404 / 33 kv MIDC

Feeder KV- 33 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.5441	5.7156	5.6584	5.3155	4.6868	5.5441	5.487
2	5.5441	5.7156	5.487	5.2584	4.4582	5.4298	5.487
3	5.5441	5.7156	5.487	5.2584	4.4582	5.4298	5.4298
4	5.5441	5.7156	5.3727	5.2584	4.4582	5.4298	5.3727
5	5.5441	5.7156	5.2584	5.2584	4.4582	5.2584	5.144
6	5.6013	5.487	5.2012	5.3155	4.4582	5.2584	5.0869
7	5.3727	5.3155	5.2012	4.7439	4.4582	5.2012	5.2584
8	5.3727	5.7728	5.3727	4.8583	4.5725	5.6013	5.3155
9	5.9442	5.9442	5.6013	4.8011	5.7156	5.9442	5.487
10	5.9442	6.4015	6.2872	5.0297	5.7156	6.0585	6.1728
11	5.9442	6.6301	6.23	5.2584	6.4015	6.2872	6.1728
12	6.1728	6.7444	6.5158	5.3727	6.4015	6.4015	6.6301
13	6.5158	6.8587	5.7156	5.3727	6.5158	6.5158	5.9442
14	6.6301	6.973	6.4015	5.2584	6.6301	6.6301	6.5158
15	6.6301	6.8587	6.4015	5.2584	6.6301	6.7444	6.2872
16	6.6301	6.8587	6.1728	5.3727	6.4015	6.7444	6.4015
17	6.6873	4.5725	5.8299	5.0297	6.6301	6.7444	6.1728
18	6.4015	5.3727	5.2584	4.3439	6.23	6.0585	5.9442
19	6.1728	6.6301	5.487	4.8011	6.3443	5.8299	5.7156
20	6.1728	7.4303	5.0297	4.9154	6.0585	5.487	5.7156
21	6.0014	7.316	4.9154	5.0297	6.0014	5.487	5.487
22	6.0014	4.9154	5.0297	4.9154	6.0014	5.6584	5.2584
23	6.2872	5.3727	5.3727	5.0297	5.6013	5.5441	
24	5.6013	5.7156	5.487	5.3155	4.9154	5.5441	5.5441
Max	6.6873	7.4303	6.5158	5.3727	6.6301	6.7444	6.6301
Min	5.3727	4.5725	4.9154	4.3439	4.4582	5.2012	5.0869
Avg	5.9919	6.0728	5.6156	5.0988	5.5918	5.8680	5.7405

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 077003 / 132 kv Khamgaon s/s

Feeder No / Name : 407 / 33 kv Chikhali

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.7346	4.3439	4.6399	4.4136	5.5441	3.678	4.2135
2	3.9043	4.6868	4.4702	4.4702	5.144	3.7346	4.201
3	3.9043	4.5153	4.357	4.4136	5.144	3.7346	4.201
4	4.0741	4.4582	2.6029	4.4136	4.9154	3.5648	4.0889
5	4.0741	4.2295	2.4897	4.6965	4.8011	4.0175	3.0247
6	4.8663	4.8011	2.7161	5.2058	4.8583	4.4702	3.6969
7	5.3755	4.401	2.4897	5.6019	4.9726	3.7346	3.8255
8	4.8097	4.2867	3.3385	5.2624	4.4582	2.8292	3.6408
9	4.8663	4.5268	3.0293	5.4321	4.0581	3.2253	4.0581
10	4.0741	5.2058	3.2579	4.9228	4.2867	3.0556	3.8866
11	4.4702	5.4887	4.8583	5.4321	4.7439	4.6965	5.0869
12	4.4136	5.998	4.8583	5.3755	4.8583	4.5268	4.8583
13	4.357	5.8848	4.7439	5.4321	5.0297	4.9228	4.5725
14	4.3004	4.8663	4.8011	4.5268	4.8583	5.3755	3.6008
15	5.0926	5.3755	4.8011	5.2624	5.0869	5.715	3.315
16	3.9609	6.8467	5.2584	5.3189	5.3727	5.6584	4.1724
17	5.2012	2.2634	5.036	5.144	5.6019	4.9897	4.2438
18	5.2584	3.2819	4.4136	5.2584	5.5453	4.8731	4.357
19	5.3155	3.7912	4.6399	5.3155	5.5453	5.1006	4.6399
20	5.6584	4.357	4.9228	5.487	2.4331	4.8234	4.9228
21	5.4298	4.7531	4.9794	5.4298	2.999	4.7125	4.9228
22	5.4298	5.036	4.4702	5.487	4.0741	4.5931	4.8097
23	4.6868	5.036	4.5833	5.5441	3.1121	4.1581	4.4702
24	.0504	4.3439	4.9228	4.4702	5.5441	2.4331	4.145
Max	5.6584	6.8467	5.2584	5.6019	5.6019	5.715	5.0869
Min	.0504	2.2634	2.4897	4.4136	2.4331	2.4331	3.0247
Avg	4.4712	4.6991	4.1950	5.0965	4.7078	4.2760	4.2064

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 077003 / 132 kv Khamgaon s/s

Feeder No / Name : 408 / 33 kv Sajjanpuri
Feeder KV- 33 / INCOMINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.036	.036	.0412			.0309	.0514
2	.036	.036	.0412			.0309	.0514
3	.036	.036	.0412			.0309	.0514
4	.036	.036	.036			.034	.0514
5	.036	.036	.036			.036	.0514
6	.036	.036	.036			.0566	.0514
7	.036	.036	.036			.0617	.0566
8	.036	.0412	.036		.0743	.0617	.0566
9	.036		.0309		.0686	.0617	.0617
10	.0412	.0566			.0309		.0514
11	.0772	.072			.0463		.0514
12	.0772	.0669			.0463		.0566
13	.072				.0463		.0514
14	.0669	.0566			.0463		.0514
15	.0617	.0566			.0514		.0514
16	.0669				.0514	.0514	.0514
17	.0617				.0463		.0514
18	.036				.036		.0463
19	.0412				.0412		.0412
20	.0412				.0412	.0463	.0412
21	.0412				.0412		.0412
22	.0412				.0412		.0412
23	.036			.0457	.0412		.0412
24	.036	.036	.0412	.0343	.0572	.0309	.0514
Max	.0772	.072	.0412	.0457	.0743	.0617	.0617
Min	.036	.036	.0309	.0343	.0309	.0309	.0412
Avg	.0467	.0456	.0376	.04	.0475	.0444	.0501

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074023 / 33 KV LONAR

Feeder No / Name : 200 / Station Transformer
Feeder KV- 11 / OUTGOING

DATE	02-JUN-18	06-JUN-18
HR	Load (MW)	Load (MW)
6		.4115
10		.0191
11	.0191	.0191
12	.0191	.0191
13	.0191	.0191
14	.0191	.0191
15	.0191	.0191
16	.0191	
17	.0191	.0191
18	.0191	
19	.0191	
Max	.0191	.4115
Min	.0191	.0191
Avg	.0191	.0682

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074023 / 33 KV LONAR

Feeder No / Name : 201 / 11KV Lonar Water Supply

SHEDDABLE URBAN

Feeder Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9907	.8573	.7621	.8002	.8764	.7621	.8002
2	.9526	.8383	.7621	.8002	.8573	.7621	.8002
3	.9145	.8192	.8002	.7621	.8383	.724	.8192
4	.8954	.8764	.8002	.7621	.8573	.724	.8383
5	.9145	.8954	.8192	.8383	.8764	.7621	.8383
6	.9526	.9335	.8383	.8573	.9145	.7621	.8383
7	.9907	.9145	.8573	.8954	.9526	.8002	.9526
8	.9526	.8954	.8573	.8764	.9907	.8002	.9526
9	.9526	.8383	.9145	.8764	.8383	.8383	.8573
10	1.0288	.8192	.8383	.8954	.8383	.8573	.7811
11	1.1241	.8954	.8954	.8954	.8764	.8383	.8002
12	1.0479	.8954	.8573	.8573	.8383	.8192	.7811
13	.9526		.8002	.8383	.8002	.7049	.7621
14	.9717		.7621	.8192	.7811	.8002	.6668
15	.9145	.9526	.6859	.8192	.7811	.7811	.724
16		.8383	.8002	.8383	.8383	.8002	.7621
17		.7621	.8764	.8764	.8764	.8954	.8573
18		.7621	.9145	.9526	.9526	.8954	.9526
19	1.0288	.8192	.8192	.9717	.8573	.8954	.9907
20	1.0479	.9717	.8383	.9526	.8002	1.0098	.9145
21	1.0098	.8954	.8383	.9335	.8002	.8764	.9526
22	.9717	.8573	.8192	.9335	.7811	.8764	.8954
23	.9526	.8002	.8192	.9145	.7811	.8573	.8954
24	1.0288	.9145	.7621	.8002	.9145		.8383
Max	1.1241	.9717	.9145	.9717	.9907	1.0098	.9907
Min	.8954	.7621	.6859	.7621	.7811	.7049	.6668
Avg	.9807	.8660	.8224	.8653	.8550	.8192	.8446

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074023 / 33 KV LONAR

Feeder No / Name : 202 / 11KV Shara AG Feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6478				
8			.5716	.0191		
9			.9907	.9526		
10			1.0098	.8002	.4954	
11			1.0098	.7621	.4572	
12			1.0288	.9145	.381	
13			.9907	.9907	.381	
14			.9526		.4954	
15			.8954		.4191	
16	.0191	.7811				
17		.7621				.8573
18	.9526	.743				.8002
19	1.0288	.6859				.7621
20	.8573	.6097				.0191
21	.8192	.5716				.0191
22	.7621	.5335				.0191
23	.724	.4954				.0191
24		.6668				
Max	1.0288	.7811	1.0288	.9907	.4954	.8573
Min	.0191	.4954	.5716	.0191	.381	.0191
Avg	.7376	.6497	.9312	.7399	.4382	.3566

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074023 / 33 KV LONAR

Feeder No / Name : 203 / 11 KV Hirdav AG Feeder
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.0191	.0191			
9		.0191	.0191			
10		.0191	.0191			
11		.0191	.0191			
12	.0191	.0191	.0191			
13	.0191		.0191			
14	.0191		.0191			
15	.0191		.0191			
16				.0191	.0191	.0191
17				.0381	.0191	
18				.0191	.0191	
19				.0191	.0191	
20				.0191	.0191	
21				.0191		
22				.0191		
23				.0191		
Max	.0191	.0191	.0191	.0381	.0191	.0191
Min	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.0191	.0191	.0215	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074023 / 33 KV LONAR

Feeder No / Name : 204 / 11Kv Shara GFSS Feeder
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.381	.4382	.4191	.3429		.5335
2	.4763	.3429	.4191	.4191	.362		.5144
3	.4954	.3429	.4191	.4763	.381		.5144
4		.362	.5716	.6668	.4572		.5525
5	.6097	.4954	.8573	.8573	.5906		.8573
6	.7621	.8573	1.0288	1.0288	1.0288		1.086
7		.6668					
10	.4954	.5335	.4382	.4572	.4954	.5906	.5716
11	.4382	.4191		.3048	.4191	.5335	.381
12	.4191	.4001	.3239	.3239	.3429		.3429
13	.4572		.3239	.3429	.3048		.381
14	.4572		.3429	.3429	.3429	.381	.362
15	.4954		.3429	.362	.362	.4382	
16	.4954	.5335	.4763	.362		.4191	
17			.5335	.4191	.3048	.4954	.5716
18		.5716	.5906	.5716	.6859	.6859	.724
19	.6859	.6287	.6287	.724	.5716	.8764	.724
20	.6478	.5906	.5716	.6668	.5716	.8383	.6478
21	.6668	.5335	.5335	.5906	.5335	.6859	.6097
22	.5716	.4954	.4763	.5716	.4763	.5906	.4954
23	.4382	.4763	.4382	.4191	.4763	.5716	
24	.4572	.4191	.4382	.4191	.362		.5525
Max	.7621	.8573	1.0288	1.0288	1.0288	.8764	1.086
Min	.4191	.3429	.3239	.3048	.3048	.381	.3429
Avg	.5292	.5028	.5096	.5117	.4706	.5922	.5790

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074023 / 33 KV LONAR

Feeder No / Name : 205 / 11 kv Pangra AG Feeder
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.4191	.4572	.3048			
9	.4191	.4191	.3048			
10	.4191	.381	.3429			
11	.4382	.3429	.381			
12	.4191		.381			
13	.4191		.3429			
14	.4382		.362			
15	.4572		.3429			
16					.4191	.2667
17					.4763	
18					.4954	
19				.381	.4572	
20				.362	.4382	
21				.3429		
22				.2858		
23				.2858		
Max	.4572	.4572	.381	.381	.4954	.2667
Min	.4191	.3429	.3048	.2858	.4191	.2667
Avg	.4286	.4001	.3453	.3315	.4572	.2667

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074023 / 33 KV LONAR

Feeder No / Name : 206 / 11 kv Lonar Bus Stand

SHEDDABLE URBAN

Feeder Feeder KV- 11 /
OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0669	1.105	.9717	.9526	.9907	.9526	
2	1.0288	1.0479	.9526	.9907	.9717	.9526	
3	1.0288	1.0479	.9907	.9907	.9526	.9907	
4	1.0669	1.0669	1.0288	1.0479	1.0669	.9907	
5	1.105	1.105	1.0479	1.0669	1.105	1.0479	
6	1.1431	1.2765	1.086	1.105	1.1431	1.086	
7	1.2193	1.2765	1.1812	1.105	1.1431	1.1431	
8	1.1812	1.3336	1.1622	1.086	1.1812	1.1241	
9	1.1431	1.2955	1.1812	1.0669	1.2193	1.1431	
10	1.1812	1.2955	1.105	1.086	1.1431	1.1812	
11	1.2193	1.1812	.9526	1.086	1.105	1.105	
12	1.2384	1.2955	1.0669	1.0669	1.086	.9907	
13	1.2765		1.1431	1.0669	1.086	1.086	
14	1.2955		1.1812	1.086	1.105	1.2003	
15	1.3146	1.3527	1.2003	1.105	1.1241	1.2003	
16		1.2384	1.2384	1.1431	1.1812	1.2765	1.1431
17		1.0479	1.2955	1.1812	1.2384		
18		1.1431	1.3146	1.3336	1.3336		
19	1.448	1.2193	1.2574	1.3146	1.2384		
20	1.3717	1.2384	1.1812	1.2003	1.1431		
21	1.3146	1.105	1.105	1.1431	1.105		
22	1.2384	1.0669	1.0479	1.105	1.0479		
23	1.1622	1.0288		1.0479	.9335		
24	1.105	1.1431	.9907	.9526	1.0479		
Max	1.448	1.3527	1.3146	1.3336	1.3336	1.2765	1.1431
Min	1.0288	1.0288	.9526	.9526	.9335	.9526	1.1431
Avg	1.1975	1.1778	1.1166	1.0971	1.1122	1.0919	1.1431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074033 / 33 KV PIMPRI KHANDARE

Feeder No / Name : 201 / BIBI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.583	.6001		.5144		.4458	.5144
2	.583	.6001		.5144			.5144
3	.583	.6001		.5144		.4458	.5144
4		.6173		.5144		.6173	.5144
5		.6859		.6859		.7545	.7716
6		1.0288		.7545		.9259	1.1145
7		1.0631		.7202			1.2003
8		.9602				1.2003	1.2003
9	1.0288	.8573		.6859	.7202	1.0288	1.0631
10	.6859	.7202		.5144		.8573	.6859
11	.5144			.463	.6173		.4801
12		.5487		.4115	.5144		.4458
13				.4115	.4801		.4458
14				.3601	.4458		.4458
15					.4458	.6516	
16				.4287	.5487	.6859	
17					.6859	.7716	.7202
18					.7202	.823	
19	.9431					.9431	1.0288
20	.9431		.7202	1.0288	1.0631	.9431	.823
21	.7716		.583	.583		.5144	.8573
22	.6859		.5144	.583		.6859	.583
23	.6859		.5144			.583	.5487
24	.583	.6001		.5144			.5144
Max	1.0288	1.0631	.7202	1.0288	1.0631	1.2003	1.2003
Min	.5144	.5487	.5144	.3601	.4458	.4458	.4458
Avg	.7159	.7402	.583	.5668	.6242	.7575	.7136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074033 / 33 KV PIMPRI KHANDARE

Feeder No / Name : 202 / 11 KV MALKAPUR PANGRA

FEEDER SEPERATION/PURE AG

FEEDER Feeder KV- 11 /
OUTGOING

DATE	01-JUN-18	02-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171					
2	.0171					
3	.0171	.0171				.0171
4	.0171					
5	.0171					
6	.0171	.0171				.0171
7	.0171					
10	.1715				.0343	.0343
11	.1715				.0343	.0343
12					.0343	
13					.0343	.0343
14					.0343	.0343
15				.1715	.0857	.0343
16					.0857	.0514
17					.0857	.0343
18					.0857	
20	.0171		.0171		.0171	
21	.0171		.0171		.0171	
22	.0171		.0171		.0171	
23	.4287				.0171	
24	.3773	.0171				.0171
Max	.4287	.0171	.0171	.1715	.0857	.0514
Min	.0171	.0171	.0171	.1715	.0171	.0171
Avg	.0943	.0171	.0171	.1715	.0448	.0309

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074033 / 33 KV PIMPRI KHANDARE

Feeder No / Name : 203 / 11 KV ANJANI FEEDER
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18	02-JUN-18
HR	Load (MW)	Load (MW)
10		.2058
23	.2401	
24	.4972	
Max	.4972	.2058
Min	.2401	.2058
Avg	.3687	.2058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074033 / 33 KV PIMPRI KHANDARE

Feeder No / Name : 204 / 11 kv Anjani GFSS feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.5487	.5487	.5144			.5144
2	.5487	.5487	.5487	.5144			.5144
3	.5487	.5487	.5487	.5144			.5144
4	.5487	.6001	.6859	.583			.5658
5	.5487	.8573	.7888	.8916			.8573
6	1.0288		1.2346	1.3375			1.3717
7	1.0631	1.1145	1.166	1.1317			1.3717
8	.8573	1.0288	.9259				1.2003
9	.7716		1.0288	.5144	.7545	1.0288	1.1317
10	.5658	.6859	.583		.5487	.823	.5487
11	.4801		.5487	.463	.4458	.4001	
12		.4458		.4458	.4115	.4801	.3772
13				.4458	.4115	.4458	
14				.3429	.4115	.4287	
15				.4287	.4801	.4458	.5144
16			.7202	.5144	.5144	.463	.5487
17			.9259	.463	.6173	.6859	.6516
18		.6173	.8916		.8916	.8573	1.0288
19	.9431		1.0288			1.0288	.9945
20	.8573	.8916	.8916		.9602	.9431	.8916
21	.7888	.7202	.7202	.6859		.7545	.8573
22	.6001	.6516	1.3032	.6344		.6516	.583
23	.6001		.583			.5658	.5487
24	.7887	.5487	.5487	.5144			.5144
Max	1.0631	1.1145	1.3032	1.3375	.9602	1.0288	1.3717
Min	.4801	.4458	.5487	.3429	.4115	.4001	.3772
Avg	.7111	.7006	.8111	.6078	.5861	.6668	.7667

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074033 / 33 KV PIMPRI KHANDARE

Feeder No / Name : 205 / 11 kv M.Pangra GFSS Feeder
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.0514	.0686	.1029			.12
2	.1029	.0514	.0686	.1029		.0686	.12
3	.1029	.0514	.0686	.1029		.0686	.12
4	.1029	.0514	.0686	.1029		.1372	.1543
5	.1029	.0514	.0686	.1029			.2743
6	.3429	.0857	.0686	.2743			.4287
7	.4115	.0857	.0686	.2743		.4115	.4287
8	.3944		.0686			.3086	.4115
9	.3086		.0686	.1715	.2743	.3086	.2743
10	.2058		.0686	.1029	.2058	.2058	.1715
11	.1715		.0686	.1029	.1372	.1372	.1029
12				.1029	.1372	.1372	
13				.1029	.1372	.12	.1029
14				.1372		.12	.1029
15				.1715	.1029	.1372	.1029
16				.2058	.1372	.1543	.1372
17					.1029	.2743	.2058
18		.0686				.3601	.3429
19	.0686	.0686	.1029			.3429	.3429
20	.0514	.0686	.1715	.2058	.3086	.2743	.2401
21	.0514	.0686	.2743	.1886		.1715	.2058
22	.0514	.0686	.1372	.1715		.1372	.1372
23	.0514		.1029			.1372	.1372
24	.1543	.0514	.0686	.1029			.12
Max	.4115	.0857	.2743	.2743	.3086	.4115	.4287
Min	.0514	.0514	.0686	.1029	.1029	.0686	.1029
Avg	.1735	.0633	.0948	.1489	.1715	.2006	.208

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074033 / 33 KV PIMPRI KHANDARE

Feeder No / Name : 206 / 11 KV BIBI FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171					.0171
2	.0171	.0171				
3	.0171					.0171
4	.0171					
5	.0171	.0171				.0171
6	.0171	.0171				.0171
7	.0171					.0857
8						.0857
9					.0857	.0857
10	.2572	.1372			.0857	.0857
11	.2058			.1543	.0857	.1029
12		.1543		.2058	.2058	.1029
13				.1715	.4287	.2743
14				.1715	.4287	.4287
15				.1715	.4287	.2401
16				.1715	.2058	.2915
17				.1372	.2058	.2058
18				.1372	.2572	.2058
19					.1372	
20	.0171			.1715	.1372	.1372
21	.0171		.0686		.1372	.1715
22	.0171		.0171		.1372	.1715
23	.0171				.0171	.0171
24	.0171	.0171				.0171
Max	.2572	.1543	.0686	.2058	.4287	.4287
Min	.0171	.0171	.0171	.1372	.0171	.0171
Avg	.0477	.0600	.0429	.1658	.1989	.1323

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074049 / 33 KV TITVI SUB STN

Feeder No / Name : 200 / Station Transformer
Feeder KV- 11 / OUTGOING

DATE	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0187	.0187		.0187	.0187
2		.0187	.0187		.0187	.0187
3		.0187	.0187		.0187	.0187
4		.0187	.0187		.0187	.0187
5		.0187	.0187		.0189	.0187
6		.0187	.0187		.0187	.0187
7			.0187		.0187	.0187
8		.0189	.0187		.0187	.0187
9	.0187	.0187		.0187	.0187	.0187
10	.0187	.0187		.0187	.0187	.0187
11	.0187	.0187			.0187	.0187
12	.0187	.0187		.0187	.0187	.0187
13	.0187	.0187		.0187	.0187	.0187
14	.0187	.0187		.0187	.0187	.0187
15	.0187	.0187		.0187	.0187	.0187
16	.0187	.0187		.0187	.0187	.0187
17	.0187	.0187		.0187		.0187
18	.0187	.0187		.0187		.0187
19	.0187	.0187		.0187		.0187
20	.0187	.0187		.0187		.0187
21	.0187	.0187			.0187	.0187
22	.0187	.0187		.0187	.0187	.0187
23	.0187	.0187		.0187	.0187	.0187
24		.0187	.0187			.0187
Max	.0187	.0189	.0187	.0187	.0189	.0187
Min	.0187	.0187	.0187	.0187	.0187	.0187
Avg	.0187	.0187	.0187	.0187	.0187	.0187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074049 / 33 KV TITVI SUB STN

Feeder No / Name : 201 / 11 KV PANGRA TITVI AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0187	.0171		
2			.0187	.0171		
3			.0187	.0514		
4			.0187	.0514		
5				.0514		
6				.0343		
11	.0187					.0187
12	.0187					.0373
13	.0187					.0373
14	.0187					.0373
15					.0373	
16					.0373	
17					.056	
21					.0373	
22					.0373	
23		.0187	.0171	.0187		
24			.0187	.0514		
Max	.0187	.0187	.0187	.0514	.056	.0373
Min	.0187	.0187	.0171	.0171	.0373	.0187
Avg	.0187	.0187	.0184	.0366	.0410	.0327

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074049 / 33 KV TITVI SUB STN

Feeder No / Name : 202 / 11 KV DHAD GFSS FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2987	.3174	.1543		.3921
2		.3206	.3547	.1372		.4108
3		.3361				.4481
4		.3734				.4854
5		.4108				
6		.4481				
10	.112	.2241	.2743			.4294
11	.112	.2987	.2572	.3734		.3174
12	.112	.2241	.2572	.3361		.2427
13	.112	.2241	.1886	.2987	.2987	.3361
14		.2801	.1715	.2614	.2987	.2987
15	.3361	.2427	.1886	.3361	.2801	.3174
16	.3547	.3174	.1715	.3734	.3361	.3547
17	.3734	.3547	.2572	.4854	.3921	.4668
18	.3921	.4481	.463	.5601		.5041
19	.3921	.4481	.5144			.5228
20	.3734	.5041	.4801	.4108		.5228
21	.3361	.4481	.4458		.4854	.4481
22	.2987	.4108	.1886		.4294	.4294
23	.3584	.3547	.1715		.4108	.3734
24		.2987	.2987	.1715		.3921
Max	.3921	.5041	.5144	.5601	.4854	.5228
Min	.112	.2241	.1715	.1372	.2801	.2427
Avg	.2818	.3460	.2941	.3249	.3664	.4049

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074049 / 33 KV TITVI SUB STN

Feeder No / Name : 203 / 11 KV PANGRA GFSS FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.168	.1307	.1372		.1307
2		.1886	.1867	.1494	.1372		.1307
3		.2058	.2054	.168	.1543		.1494
4		.2401	.2427	.168	.1715		.168
5		.2743	.2614	.1867	.2058		.2054
6		.2743	.2987	.2054	.2058		.2241
10		.1867	.1494	.1715	.168	.2241	.168
11		.168	.1867	.1372	.1494	.1494	.1494
12		.168	.112	.1372	.1494	.1307	.1307
13		.1494	.112	.12	.1494	.112	.1494
14		.1867	.1307	.12	.112	.112	.1307
15		.168	.1494	.12	.1307	.112	.1494
16		.168	.1494	.12	.1494	.1494	.168
17	.2401	.168	.168	.1372	.1494	.1867	.1867
18	.2401	.1867	.2241	.1715	.1867		.2614
19	.2229	.2241	.2614	.2401	.2241		.2614
20	.2743	.1867	.1867	.2058	.2427		.2054
21	.2058	.1867	.1494	.1886		.1494	.1867
22		.1867	.1494	.1543	.168	.1494	.168
23	.1715	.1698	.1494	.1543	.168	.1307	.1494
24		.1715	.1494	.1307	.1372		.112
Max	.2743	.2743	.2987	.2401	.2427	.2241	.2614
Min	.1715	.1494	.112	.12	.112	.112	.112
Avg	.2258	.1919	.1805	.1579	.1648	.1460	.1707

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074049 / 33 KV TITVI SUB STN

Feeder No / Name : 204 / 11 KV DHAD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0187
2					.0187
3					.0187
4					.0187
5					.0187
6					.0187
7			.0171		.0187
8					.0187
9			.0187		
10			.0187		
11	.0187		.0187		
12	.0187		.0187		
13	.0187		.0187		
14	.0187		.0187		
15		.0171			
16		.0171			
17		.0171			
19		.0171			
23				.0187	
24					.0187
Max	.0187	.0171	.0187	.0187	.0187
Min	.0187	.0171	.0171	.0187	.0187
Avg	.0187	.0171	.0185	.0187	.0187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074049 / 33 KV TITVI SUB STN

Feeder No / Name : 205 / 11 KV GOTHRA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.168				
7			.1867			
8			.2054			
9			.1886			
10			.1543		.2614	
11			.2058			
12			.1715			
13			.1715			
14			.1715		.2241	
15				.1494		.1867
16		.1867		.1494		.1867
17		.1867		.168		.1867
18		.1867		.1867		.2054
19		.2054		.1867		.2054
20		.2054		.168		.2054
21		.2054				.2054
22		.1867				.1867
23	.1867					
24		.1867				
Max	.1867	.2054	.2058	.1867	.2614	.2054
Min	.1867	.168	.1543	.1494	.2241	.1867
Avg	.1867	.1909	.1819	.1680	.2428	.1961

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074049 / 33 KV TITVI SUB STN

Feeder No / Name : 206 / 11 KV GOTHRA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.168	.168	.1543		.1867
2		.1886	.1867	.1867	.1715		.2054
3		.2401	.2054	.2241	.2229		.2241
4		.2915	.2427	.2801	.2572		.2614
5		.3258	.2614	.3361	.2915		
6		.3429	.2987	.3921	.2915		
10		.168	.1867	.1372	.1867	.2054	
11		.168	.1494	.1372	.1307	.168	
12		.168	.1307	.0686	.112	.168	.1867
13		.1494	.1494	.0857	.112	.168	.168
14		.2054	.168	.0857	.112	.168	.1494
15		.2054	.168	.1029	.1307	.1494	.1494
16		.2427	.168	.1029	.1307	.168	.1867
17		.2241	.1867	.12	.1698	.2054	.2241
18		.2614	.2614	.12	.2054		.2614
19		.2987	.2801	.2401	.2987		.2987
20	.2743	.2614	.2614	.2572	.3174		.2801
21	.2572	.2241		.2229		.2987	.2614
22		.2054	.2054	.2058	.2241	.2801	.2427
23	.2572	.1867	.168			.2054	.1867
24		.1715	.168	.1494	.1543		.1867
Max	.2743	.3429	.2987	.3921	.3174	.2987	.2987
Min	.2572	.1494	.1307	.0686	.112	.1494	.1494
Avg	.2629	.2238	.2007	.1811	.1933	.1986	.2153

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074050 / 33/11 KV SULTANPUR SS

Feeder No / Name : 200 / Station Transformer
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
17			.0171			
18			.0171			
19			.0171			
20			.0171			
21			.0171			
23			.0171			
24	.0191	.0171		.0171	.0191	.0171
Max	.0191	.0171	.0171	.0171	.0191	.0171
Min	.0191	.0171	.0171	.0171	.0191	.0171
Avg	.0191	.0171	.0171	.0171	.0191	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074050 / 33/11 KV SULTANPUR SS

Feeder No / Name : 201 / 11 KV Chincholi AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0914	.0686	.0762	.0181	.0686
2			.0914	.0514	.0762	.0181	.0686
3			.1097	.0514	.0762	.0181	.0514
4			.1097				
5			.1267				
6			.1905				
7			.1543				
8	.5144	.0343	.2058				
9	.4954		.2058				
10			.2401	.2858			
11			.3086	.2667		.1372	
12			.3258	.2477	.2454	.1029	
13			.2743	.2096	.2896		
14			.2401	.2096	.2534	.1372	
15			.2229	.2477	.2715	.1715	
16				.2667	.2715	.2058	
17			.2058	.3239	.2896	.1886	
18		.0724	.0343	.0572		.0514	.0762
19	.0686	.5792	.0343	.0762		.0686	.0762
20	.0686	.0724	.0343	.0762	.0543	.0686	.0762
21	.0686	.0724	.0514	.0762	.0549	.0514	.0543
22		.0724	.0514		.0543	.0343	.0572
23		.0724	.0514	.0762	.0175		.0526
24	.12		.0914	.0514	.0762	.0543	.0514
Max	.5144	.5792	.3258	.3239	.2896	.2058	.0762
Min	.0686	.0343	.0343	.0514	.0175	.0181	.0514
Avg	.2226	.1394	.1501	.1554	.1505	.0884	.0633

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074050 / 33/11 KV SULTANPUR SS

Feeder No / Name : 202 / 11 KV RAJEGAON FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3429	.1715		.1029
2			.3429	.1715		.1029
3			.3429	.1524		.1029
4			.3601	.1524		.1372
5			.4115	.1715		.12
6			.4115	.1905		.1372
7			.4572	.2096	.2715	.1029
8			.4763	.2286	.2534	.3429
9			.4954	.2477	.2058	.3429
10	.1905	.3429				.3429
11		.3439				.4191
12	.2401	.3258				.4382
13	.3429	.362				.4382
14	.3772	.181				.4572
15	.3429	.0905				.4954
16		.0724				
17		.0724				
24			.3772	.1905	.0181	.2058
Max	.3772	.362	.4954	.2477	.2715	.4954
Min	.1905	.0724	.3429	.1524	.0181	.1029
Avg	.2987	.2239	.4018	.1886	.1872	.2680

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074050 / 33/11 KV SULTANPUR SS

Feeder No / Name : 203 / 11 KV WENI FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2401					
2		.2401					
3		.2401					
5		.3772					
6		.3772					
7		.4115					
8	.2667	.4458					
9	.3048	.4458					
10			.2058	.3239	.2477	.1715	
11			.2058	.362	.2286	.1715	
12			.2401	.362	.2534	.1372	
13			.2401	.3429	.3048	.1715	
14				.362	.2896	.1715	
15			.2572	.3429	.3077	.1715	
16			.3772	.3429	.3258	.1886	
17			.1715	.381	.3258	.2743	
23							.2172
24		.2572					
Max	.3048	.4458	.3772	.381	.3258	.2743	.2172
Min	.2667	.2401	.1715	.3239	.2286	.1372	.2172
Avg	.2858	.3372	.2425	.3525	.2854	.1822	.2172

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551]

BU 4551

Substation No/ Name :- 074050 / 33/11 KV SULTANPUR SS

Feeder No / Name : 204 / 11kv ChincholiBore GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8192	.6859	.7621	.6859	.8383	.7811	.6859
2	.8383	.7202	.7811	.7545	.8573	.7621	.7202
3	.8573	.7545	.7621	.7545	.9145	.8002	.7545
4	.9145		.8383	.8916	.9907	.8383	.8916
5	1.0669	.9431	1.1812	1.0631	1.2003	1.105	1.2003
6	1.3717	1.2689	1.4861	1.448	1.448	1.4861	1.3717
7	1.5051	1.3032	1.406	1.5432	1.5242	1.5623	1.2689
8	1.2955	1.0631	1.166	1.3717	1.3527	1.4289	1.1317
9	1.105	.9259	1.0117	1.1241	1.1241	1.0631	.9431
10	.9145	.8916		.9907	.8002	.8916	.7888
11		.8002	.7888	.8764	.7468	.7888	.743
12	.823	.724	.6859	.724	.7621	.7545	.6859
13	.7545	.7621	.7545	.6859	.7621	.7202	.6478
14	.9259	.7621		.6478	.724	.583	.6478
15	.7888	.724	.7545	.6478	.724	.6173	.6668
16		1.0669	.823	.6859	.8383	.6859	.7049
17		1.0669	.9259	.8002	.8688	.7202	.743
18		1.1812	1.0631	1.0669		1.0631	1.1241
19		1.3717		1.1812		1.2003	1.1812
20	1.0631	.8413	1.1317	1.1241	1.4289	1.166	1.0669
21		.724	.9259	.9907	1.1431	.9602	.8764
22	.7545	.7733	.8916	.9335	.9145	.7888	.8002
23		.7621	.7888	.8573	.7811		.7811
24	.8192	.6859	.7421	.7545	.8192	.8002	.7545
Max	1.5051	1.3717	1.4861	1.5432	1.5242	1.5623	1.3717
Min	.7545	.6859	.6859	.6478	.724	.583	.6478
Avg	.9775	.9044	.9367	.9418	.9801	.9377	.8825

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074050 / 33/11 KV SULTANPUR SS

Feeder No / Name : 205 / 11 kv Rajegaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.2401
3				.2743
4				.3429
5				.583
7				.6859
16			.2572	
17			.3601	
24	.1905	.2572		.2572
Max	.1905	.2572	.3601	.6859
Min	.1905	.2572	.2572	.2401
Avg	.1905	.2572	.3087	.3972

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074050 / 33/11 KV SULTANPUR SS

Feeder No / Name : 206 / 11 kv Weni GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954		.4191	.3086	.4954	.4191	.3429
2	.4763		.4001	.3429	.5144	.381	.3429
3	.4954		.4191	.4458	.5335	.4001	.4115
4	.5335		.4572	.4458	.5525	.4572	.4458
5	.6859		.724	.7545	.7811	.5716	.7545
6	.8383		.8192	.9602	1.1812	.8002	.9945
7	.8573		.6516	1.0288	1.1241	.8573	.8573
8	.6859		.6516	.9526	1.0669	.7621	.823
9	.6668		.6344	.7811	.7621	.5487	.6173
10	.5716		.4458	.5144	.5144	.5144	.4801
11			.3772	.4191	.4191	.3772	.4001
12	.4458		.3429	.4191	.4001	.3429	.4382
13	.3772		.4115	.4001	.4001	.4115	.4572
14	.4115		.4115	.4572	.381	.3429	.4382
15	.4115		.4115	.4763	.381	.3429	.4572
16			.4801	.4954	.5716		.4954
17			.4801	.5716	.6097	.5487	.6478
18			.583	.6668			.7811
19	.6173	.4954	.7202	.8192		.5144	
20	.6173	.4191	.6173	.8573	.5335	.7545	.6287
21		.4191	.5144	.7621	.4706		.5335
22		.4001		.6097	.4191	.4458	.4954
23		.4001	.4801	.5335	.4001		.4382
24	.4572		.3658	.4458	.5144	.4001	.3772
Max	.8573	.4954	.8192	1.0288	1.1812	.8573	.9945
Min	.3772	.4001	.3429	.3086	.381	.3429	.3429
Avg	.5673	.4268	.5138	.6028	.5921	.5096	.5503

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074050 / 33/11 KV SULTANPUR SS

Feeder No / Name : 207 / 11 KV DAM AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	05-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0572	
2			.0572	
3			.0762	
4			.0762	
5			.0953	
6			.0953	
7			.0953	
10	.0953	.0514		
11		.0183		
12	.0686	.0181		
13	.1029	.0183		
14	.0514	.0191		
15	.0514			.0762
16				.0762
17				.0762
24			.0572	
Max	.1029	.0514	.0953	.0762
Min	.0514	.0181	.0572	.0762
Avg	.0739	.0250	.0762	.0762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074050 / 33/11 KV SULTANPUR SS

Feeder No / Name : 208 / 11 KV BORKHEDI DHARAN NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	01-JUN-18	03-JUN-18	04-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0171		.0171
2			.0171		.0171
3			.0171		.0171
4			.0171		.0686
5			.0171		.0171
6			.0171		.0171
7		.0171	.0191		.0171
8		.0171	.0191		.0171
9		.0171	.0191	.0171	.0171
10		.0171	.0191	.0171	.0171
11		.0171	.0191	.0171	
12	.0171	.0171		.0171	
13		.0171		.0171	
14	.0171	.0171		.0171	
15		.0171		.0171	
16				.0171	
17		.0171		.0171	
18		.0171		.0171	
19	.0171	.0171		.0171	
20		.0171		.0171	
21		.0171		.0171	
22		.0171		.0171	
23		.0171			
24			.0171		.0171
Max	.0171	.0171	.0191	.0171	.0686
Min	.0171	.0171	.0171	.0171	.0171
Avg	.0171	.0171	.0179	.0171	.0218

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074053 / 33/11KV HIRDAV

Feeder No / Name : 201 / 11 kv Gaikhed AG Feeder
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	05-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)
24	.0953	.0572
Max	.0953	.0572
Min	.0953	.0572
Avg	.0953	.0572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074053 / 33/11KV HIRDAV

Feeder No / Name : 202 / 11 Kv Gundha Gfss Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.1715	.1524	.1905	.1905	.2477
Max	.1715	.1524	.1905	.1905	.2477
Min	.1715	.1524	.1905	.1905	.2477
Avg	.1715	.1524	.1905	.1905	.2477

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074053 / 33/11KV HIRDAV

Feeder No / Name : 203 / 11 kv Wadhav AG Feeder
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	05-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)
24	.1143	.0381
Max	.1143	.0381
Min	.1143	.0381
Avg	.1143	.0381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074053 / 33/11KV HIRDAV

Feeder No / Name : 205 / 11 KV GAYKHED GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.5144	.5335	.5716	.5335	.5525
Max	.5144	.5335	.5716	.5335	.5525
Min	.5144	.5335	.5716	.5335	.5525
Avg	.5144	.5335	.5716	.5335	.5525

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074053 / 33/11KV HIRDAV

Feeder No / Name : 206 / 11 KV DABHA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.1143	.0381			
2	.0381	.0762	.0381			
3	.0381	.0762	.0381			
4	.0381	.1143	.0381			
5	.0381	.1143	.0381			
6	.0381	.1524	.0381			
7	.0762	.1524	.0762			
8				.0762		.0381
9				.0762	.0572	
10				.1143	.0572	
11				.1334	.0762	
12				.0953	.0762	
13				.1143	.0953	
14				.1143	.1143	
15				.0762	.1143	
16			.0953			
17			.1524			
18			.1905			
19			.1905			
20			.1524			
21			.1143			
22			.0762			
23			.0762			
24	.0381	.1143	.0381			
Max	.0762	.1524	.1905	.1334	.1143	.0381
Min	.0381	.0762	.0381	.0762	.0572	.0381
Avg	.0429	.1143	.0869	.1000	.0844	.0381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074067 / 33 kv Kingaon Jattu ss

Feeder No / Name : 201 / 11 KV Kingaon Jattu Gfss

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1715	.1334	.1334	.1715	.381	.1524
2	.1905	.1524	.1334	.1334	.1524	.3429	.1524
3	.1715	.1334	.1334	.1334	.1905	.4001	.1524
4	.2477	.1524	.1334	.1524	.2286	.4572	.1524
5	.2096	.1905	.1905	.1905	.3239	.4572	.1905
6	.1905	.2858	.2096	.2096	.2477	.5335	.3048
10	.4763	.1715	.2286	.2286	.2667	.1905	.3048
11	.4572	.1715	.4191	.3048	.2286	.1715	.4763
12	.4001	.4001	.4382	.1334	.2096	.1715	.381
13		.2858	.4001	.1905	.1905	.1905	.4001
14			.4001	.2667	.2096	.1524	.381
15		.2096	.3048	.362	.2286	.1524	.3239
16			.2858	.2477	.2477	.1524	.4191
17			.2477	.3429	.2858	.1524	.4572
18			.2477	.3429	.3429	.1524	.4763
19		.1715	.3048	.4001	.3239	.1715	.2286
20	.2286	.1715	.2667	.2667	.3048	.1524	.3048
21	.2477	.1524	.2477	.3048		.1524	.2477
22	.2286	.1524	.1524	.3429		.1524	.1524
23	.1905	.1524	.1524	.1905		.1524	.1524
24	.1715	.1905	.1524	.1524	.1905		.1524
Max	.4763	.4001	.4382	.4001	.3429	.5335	.4763
Min	.1524	.1334	.1334	.1334	.1524	.1524	.1524
Avg	.2545	.1950	.2468	.2395	.2413	.2420	.2839

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074067 / 33 kv Kingaon Jattu ss

Feeder No / Name : 202 / 11 kv Bhumrala feeder

SHEDDABLE RURAL

(Mix) Feeder KV- 11 /
OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286		.1905	.1905	.1905	.362	.0191
2	.1905		.1905	.1905	.2096	.2667	.1905
3	.2286		.1905	.1905	.2477	.2477	.1905
4	.2667		.1905	.2286	.3239	.2286	.1905
5	.3048		.1905	.3429	.4763	.2667	.2858
6	.3239		.4763	.381	.4382	.3429	.4191
10	.4382		.2858		.2667		.2667
11	.381		.3239		.2858		.2477
12	.381		.3429		.2667		
13			.2667		.2477		.2477
14			.3048	.3048	.2286		.2286
15				.3048		.2096	
16				.3429		.2286	
17				.381		.2667	
18				.4382		.2477	
19		.4191	.4763	.5144	.4763	.381	.4191
20	.1524	.362	.4001	.4572	.4382	.3239	.381
21	.1905	.2858	.3429	.381		.2286	.3239
22		.2667	.2858	.3429		.2286	.2477
23		.2286	.2286	.2286		.2096	.2286
24	.2477		.2286	.2096	.2286		.1905
Max	.4382	.4191	.4763	.5144	.4763	.381	.4191
Min	.1524	.2286	.1905	.1905	.1905	.2096	.0191
Avg	.2778	.3124	.2891	.3194	.3089	.2693	.2548

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074067 / 33 kv Kingaon Jattu ss

Feeder No / Name : 203 / 11 KV Kingaon Jattu AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.0191	.1334	.1334	.1524		.1334
2	.0953	.0191	.1334		.1334		.1334
3	.0762	.0191	.4572	.1334	.1905		
4	.1715	.0191	.1334	.1524	.2286		.1334
5	.1905	.0191	.1905	.2286	.3239		.1524
6	.2477	.0191	.2858	.2858	.381		.1524
7							.1524
10		.1334		.1524			
11	.1905	.1143		.1905			
12	.1715	.1143					
13		.1143				.1524	
14		.1143		.1905		.1524	
15					.1905		.2286
16					.2096		.2096
17					.2477		.2096
18			.2858		.2858		.2096
19	.0191	.1715	.3239	.362	.3048	.2096	.2667
20	.0191	.1905	.2858	.3048	.3429	.2667	.2477
21	.0191	.1715	.2286	.2667		.1905	.2096
22	.0381	.1715	.1524	.2096		.1524	.1715
23	.0572	.1524	.1334	.1715		.1524	.1524
24	.1524	.0381	.1524	.1334	.1715		.1524
Max	.2477	.1905	.4572	.362	.381	.2667	.2667
Min	.0191	.0191	.1334	.1334	.1334	.1524	.1334
Avg	.1130	.0942	.2228	.2082	.2433	.1823	.1822

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074088 / 33 KV Deulgaon Kundpal

Feeder No / Name : 201 / 11 kv Deulgaon AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18	04-JUN-18	05-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0953	.1524
2			.1143	.1524
3			.1143	.1334
4			.0953	.1334
5			.0953	
6			.1143	
7			.1143	.1524
8			.1334	.1715
9			.1143	.1524
10			.1143	.1143
11	.2858			.128
12		.1905		.128
13		.2096		.1097
14				.1463
15				.1463
16				.128
17				.128
18				.1294
Max	.2858	.2096	.1334	.1715
Min	.2858	.1905	.0953	.1097
Avg	.2858	.2001	.1105	.1379

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074088 / 33 KV Deulgaon Kundpal

Feeder No / Name : 202 / 11 KV AJISPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6858			
2		.6478			
3		.6858			
4		.6858			
5		.6478			
6		.6858			
7	.1715	.6096			
8		.6858			
9		.4572			
10		.6096			
11		.3048	.1334	.3239	.2477
12			.1524	.3048	.2858
13		.3429	.381	.2858	.2096
14		.3429	.3429	.4191	.2286
15		.3429	.2667	.3239	.1905
16		.3048	.2667	.362	.2286
17		.3429	.3048	.3429	.2286
18		.2667	.381	.3429	.1524
Max	.1715	.6858	.381	.4191	.2858
Min	.1715	.2667	.1334	.2858	.1524
Avg	.1715	.5088	.2786	.3382	.2215

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074088 / 33 KV Deulgaon Kundpal

Feeder No / Name : 203 / 11 KV DEULGAON GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381		.4954	.4572	.4382		.4954
2			.4954	.4191	.381		.4763
3			.5144	.381	.381		.4763
4			.6859	.6668	.5716		.743
5			.8573	.8383	.9335		.9526
6			.8954	.9907	1.0288		1.0098
10			.6097	.6859	.4572	.5525	.5144
11	.5716		.4191	.5716	.4001	.5335	
12				.4382	.362	.381	
13			.3429	.381	.3239	.381	.3921
14				.3429	.362	.4001	.3361
15			.3429	.3429	.362	.4191	.4108
16				.4382	.362	.4572	.4108
17			.5335	.6478	.6097	.5525	.4435
18			.9145	.8002	.7049	.8383	.7316
19		.8954	.8002	.7621	.8383	.9145	.7499
20		.8573	.724	.724	.7811	.8192	.6767
21		.6668	.6478	.6478		.6668	.5729
22		.5716	.6287	.5906		.5716	.499
23		.5335	.5716	.4954		.4954	.4805
24	.4572		.5144	.5716	.4572		.4763
Max	.5716	.8954	.9145	.9907	1.0288	.9145	1.0098
Min	.381	.5335	.3429	.3429	.3239	.381	.3361
Avg	.4699	.7049	.6107	.5806	.5419	.5702	.5709

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074011 / 33/11 KV DONGAON

Feeder No / Name : 200 / Dongaon Substation Xmer
Feeder Feeder KV- 11 / OUTGOING

DATE	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0183	.0191	.0183	.0183	.0261
2	.0183	.0191	.0183	.0183	.0299
3	.0183	.0191	.0183	.0183	.028
4	.0183	.0191	.0183	.0183	.0317
5	.0183		.0183	.0183	.0355
6	.0183	.0191	.0183	.0183	.0355
7	.0183	.0191	.0183	.0183	.0336
8	.0183	.0191	.0183	.0183	.0299
9	.0183	.0191	.0183	.0183	.028
10	.0183	.0191	.0183	.0183	.0299
11	.0183	.0191	.0183	.0329	.0191
12	.0183	.0191	.0183	.0329	.0191
13	.0183	.0191	.0183	.0308	.0191
14	.0183	.0191	.0183	.0293	.0191
15	.0183	.0191	.0183	.0293	
16	.0183		.0183	.0293	.0191
17	.0183	.0191	.0183	.0329	.0191
18	.0183	.0191	.0183	.0329	.0191
19	.0183	.0191	.0183	.0348	.0191
20	.0183	.0191	.0183	.028	.0191
21	.0183	.0191	.0131	.0336	.0191
22	.0183	.0191	.0183	.0299	.0191
23	.0183	.0191	.0183	.028	.0191
24	.0183	.0191		.0183	.028
Max	.0183	.0191	.0183	.0348	.0355
Min	.0183	.0191	.0131	.0183	.0191
Avg	.0183	.0191	.0181	.0252	.0246

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074011 / 33/11 KV DONGAON

Feeder No / Name : 201 / 11 KV DONGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	.3734	.2378		.2054
13	.3361	.2195		.2054
14	.3361	.2561		.2241
15		.2378	.1638	
16	.3429	.2743	.1457	.2241
17	.3921	.2195	.1311	.2241
18	.3547	.1829	.1311	.2241
Max	.3921	.2743	.1638	.2241
Min	.3361	.1829	.1311	.2054
Avg	.3559	.2326	.1429	.2179

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074011 / 33/11 KV DONGAON

Feeder No / Name : 202 / 11 KV PANGARKHED AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11			.2984	.5228
12	.6161	.5487	.3113	.5228
13	.6535	.5487	.3605	.4294
14	.5601	.5121	.3277	.3547
15	.5601	.3549	.3481	
16		.4572	.3277	.2801
17		.439	.2949	.2614
18	.5415	.3841	.2785	.2241
Max	.6535	.5487	.3605	.5228
Min	.5415	.3549	.2785	.2241
Avg	.5863	.4635	.3184	.3708

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074011 / 33/11 KV DONGAON

Feeder No / Name : 203 / 11 KV MADANI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	03-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2622
2				.2818
3				.2652
4				.2984
5				.3315
7			.1829	
8			.1646	
9			.1097	
10			.1463	.2294
11			.1492	
12		.1829		
14	.3292	.2378		
15	.2561			
16	.2743			
17	.2926			
18	.2926			
Max	.3292	.2378	.1829	.3315
Min	.2561	.1829	.1097	.2294
Avg	.2890	.2104	.1505	.2781

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074011 / 33/11 KV DONGAON

Feeder No / Name : 204 / 11 KV DONGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5912	1.5123			1.6461
2	1.6095	1.4937			1.6095
3	1.5912	1.4563		1.3535	1.5912
4	1.7924	1.643		1.4266	1.7924
5	1.957	1.9044		1.5729	1.9004
6	2.1948	2.2068		2.2314	2.6063
7	1.9204	2.1285		2.0668	2.2443
8	1.7558	1.7364		1.7193	1.9204
9	1.6461	1.5497		1.6827	1.7558
10	1.4266	1.531		1.5181	1.4998
11	1.39	1.4563			1.475
12	1.4266	1.251	1.2071		1.4377
13	1.3717	1.2136	1.2254	1.5364	1.419
14	1.39	1.2323	1.2437	1.5546	
15	1.4266		1.3169	1.5729	
16	1.4083	1.251	1.5364	1.6461	1.643
17	1.4449	1.3443	1.5729	1.6644	1.6617
18	1.5181	1.6244	1.6278	1.7558	1.7551
19	1.7558	1.8298	1.701	1.8656	1.9231
20	1.7924	1.8111		2.0485	2.0911
21	1.701	1.8111		1.9753	1.9978
22	1.6278	1.7737	1.3352	1.9022	1.9231
23	1.5181	1.7177	1.4266	1.7558	1.7924
24	1.6461	1.531			1.7187
Max	2.1948	2.2068	1.701	2.2314	2.6063
Min	1.3717	1.2136	1.2071	1.3535	1.419
Avg	1.6209	1.6091	1.4193	1.7289	1.7911

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074011 / 33/11 KV DONGAON

Feeder No / Name : 205 / 11 KV PANGARKHED GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8402		.7682	.8779
2		.8215		.7865	.8507
3		.7842		.7682	.8688
4		.8962		.823	1.0242
5		1.0642			1.1706
6		1.1576			1.2803
7		1.0269			1.0608
8				.9694	.8413
9				.8779	.7499
10				.6584	.6401
11				.6468	.6908
12		.8589	.6767	.6653	.6535
13		.8029	.5487	.6767	.6908
14	.9877	.7842	.5121	.6767	.6908
15	.9511	.7655	.5487	.695	
16	.9145		.695	.695	.7282
17	.8596		.7682	.8048	.8029
18	.8048	.9335	.8413	.9877	.9149
19	.9877	1.1203	.6836	1.0791	1.0456
20	1.0974	1.1576		1.134	1.1389
21	.9145	1.1763	.7362	1.0791	1.1016
22	.9694	1.0829	.823	1.0425	1.0642
23	.9328	1.0456	.7865	.9145	.9896
24		.8962			.9145
Max	1.0974	1.1763	.8413	1.134	1.2803
Min	.8048	.7655	.5121	.6468	.6401
Avg	.9420	.9564	.6927	.8374	.9040

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074016 / 33KV HIVARA ASHRAM

Feeder No / Name : 201 / 11KV Deulgaon Mali AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)
7	.1014	
9	.1353	.208
10		.1932
Max	.1353	.208
Min	.1014	.1932
Avg	.1184	.2006

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074016 / 33KV HIVARA ASHRAM

Feeder No / Name : 202 / 11 KV LAWALA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0442				
2	.0686				
3	.0686				
8	.0503				
9	.0754				
10	.1372				
11		.2896	.3704	.3048	.2469
12		.3311	.4012	.3353	.2401
13		.3521	.381		.2751
14		.3521	.3567		.2494
15			.3048		.2229
16			.2675		.208
17			.2709		.2258
18			.2675	.2675	.208
Max	.1372	.3521	.4012	.3353	.2751
Min	.0442	.2896	.2675	.2675	.208
Avg	.0741	.3312	.3275	.3025	.2345

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074016 / 33KV HIVARA ASHRAM

Feeder No / Name : 203 / 11 KV PENTAKALI EXPRESS NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4294	.1463	.2743	.3353	.112	.2743
2		.4294	.1463	.2743	.3353	.112	.2774
3		.4294	.1448	.2743	.3353	.1109	.2743
4		.4294	.1448	.2401	.3353	.1097	.2774
5		.4294	.3582	.3429	.3429	.1086	.2743
6		.3944	.5201	.4801	.5144	.1227	.5144
7		.4334	.5201	.4801	.4801	.1402	.5201
8		.4854	.2713	.4854	.1715		.5375
9		.4854	.1227	.4801	.5144	.5487	.5487
10		.1448	.1402	.5201	.5487	.5144	.5548
11		.285	.5201	.5144	.5426	.5144	.5201
12		.5144	.5144	.2652	.5487	.5144	.5144
13		.4854	.5144	.5201	.5487		.5548
14			.5144	.5201	.5144		.285
15		.4854	.5658		.5316		.5487
16		.1097	.5487		.5144		.5487
17		.4706	.5487		.5144		.5487
18		.5548	.5144		.5201	.5548	.5487
19		.5201	.5548	.5144	.5201	.4801	.5487
20		.3467	.5548	.5144		.4854	.5144
21		.3467	.5201	.5487		.2915	.285
22		.2915	.2743	.5792	.1097	.2915	.2915
23	.1048	.2743	.2743	.285	.1097	.2947	.2743
24		.5975	.1372	.3353		.2743	
Max	.1048	.5975	.5658	.5792	.5487	.5548	.5548
Min	.1048	.1097	.1227	.2401	.1097	.1086	.2743
Avg	.1048	.4075	.3780	.4224	.4232	.3100	.4364

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074016 / 33KV HIVARA ASHRAM

Feeder No / Name : 204 / 11 KV LAVALA GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2353	.5068	.4805	.543	.5792	.5487
2	.2353	.5068	.4755	.5487	.5792	.543
3	.2353		.4805	.543	.5792	.5487
4	.2353		.4805	.6584	.6401	.5914
5	.2715		.5544	.7762	.7316	.6722
6	.3292		.8962	.9709	.961	.8962
7	.2926		.9054	.905	.8962	.8131
8	.2835	.5068	.7468	.7316		
9	.2896	.5068	.6584	.7392		
10	.2896	.4287	.5175	.5014	.7499	.6653
11	.4161	.4334	.4755	.5068	.5487	.4572
12	.4334	.3155	.4344		.5258	.4525
13	.4115	.5014	.4252	.4784		.4252
14		.5373	.4607	.4607		.4252
15		.5373		.4961		.5068
16	.3429	.567		.5316		.5487
17	.6588	.6878		.6089		.6335
18	.9511	.7316		.6516	.6154	.6767
19	.8596	.7392	.8145	.823	.7392	.7468
20	.7783	.7023	.7316		.8048	.6908
21	.724	.5914	.6584		.7095	.6401
22	.6447	.3658	.6219		.5792	.5853
23	.6268	.3109	.5792	.5731	.5853	.5853
24		.543	.543		.543	
Max	.9511	.7392	.9054	.9709	.961	.8962
Min	.2353	.3109	.4252	.4607	.5258	.4252
Avg	.4545	.5274	.5970	.6341	.6687	.6025

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074020 / 33/11 KV JANEFAL

Feeder No / Name : 201 / 11 KV HIWARA KD. AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0554	.1097		.0739
2				.0914		.0732
3			.056	.0914		.0554
4			.0549	.1097		.0549
5			.0549	.1097		.0554
6			.0549	.1097		.0549
7			.0732	.128		.128
8			.0914	.128		.1097
9			.1478	.0914		.128
10				.0914		.0739
11	.1715					
12	.1715				.0732	
13					.0732	
14					.0732	
15		.1109				
16	.1334	.1097				
17		.1097				
18		.1097			.0732	
Max	.1715	.1109	.1478	.128	.0732	.128
Min	.1334	.1097	.0549	.0914	.0732	.0549
Avg	.1588	.11	.0736	.1060	.0732	.0807

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074020 / 33/11 KV JANEFAL

Feeder No / Name : 202 / 11 KV DEULGAON SAKARSHA AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4024		.2926	.2926		.2957
2				.2561	.2926		.2926
3				.2561	.3109		.2772
4				.2195	.3292		.1494
5				.2195	.3292		
6				.3292	.3658		.3326
7		.4024		.2561	.3292		.2957
8		.3292					.2926
9		.3658					.2561
10		.3658					.2561
11	.439	.381	.3658	.4024	.381		.3292
12	.439	.4572	.4024	.3658			.3052
13	.4755		.4024	.3658	.381		.3353
14			.3658				
15	.4755		.4024				
16			.3658				
17			.2926				
18						.4481	
19	.5121			.4755		.5853	.4144
20	.5121			.4755		.439	.4915
21	.4755			.439			.4096
22	.4755			.3658			.3353
23	.439			.3658			.3353
24	.6618	.3658		.3292	.3292		.2926
Max	.6618	.4572	.4024	.4755	.381	.5853	.4915
Min	.439	.3292	.2926	.2195	.2926	.439	.1494
Avg	.4905	.3837	.3710	.3384	.3341	.4908	.3165

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074020 / 33/11 KV JANEFAL

Feeder No / Name : 203 / 11 KV NAIGAON DATTAPUR AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.1097					
9	.1463					
10	.1829					
11	.1334			.4382		.4066
12	.2096		.3658			.3353
13			.4024	.5716		.3353
14		.1463	.439	.5335	.2378	.3052
15		.1463	.4207		.2561	
16	.3048	.1829	.4207	.5525	.2743	
17		.1829	.4024	.5906	.2743	
18			.3658		.2378	
Max	.3048	.1829	.439	.5906	.2743	.4066
Min	.1097	.1463	.3658	.4382	.2378	.3052
Avg	.1811	.1646	.4024	.5373	.2561	.3456

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074020 / 33/11 KV JANEFAL

Feeder No / Name : 204 / 11 KV DEULGAON SAKARSHA

GAOTHAN FEEDER

GAOTHA Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4024		.6036	.6584		.5853
2		.439		.5853	.695		.5544
3		.439		.5853	.695		.5487
4		.4755		.6219	.7316		.5487
5		.5487		.695	.7682		.2957
6		.5853		.9511	.9145		.3292
7		.5853		.7682	.8779		.2926
8		.5487		.5487	.8048		.2561
9		.5487		.439	.7682		.439
10		.5121		.4024	.695	.4755	.4805
11	.439	.5335	.5175	.5487	.381	.4024	.439
12	.4755	.4572	.4024	.4755		.439	.3353
13	.4755		.4572	.4755	.381	.4024	
14	.4572		.439	.5121	.3048	.3658	.3647
15	.439		.4024	.5121		.4024	
16		.5335	.4024	.5487	.381	.4572	
17			.4755	.5487	.381	.4805	
18				.6219		.5121	
19	.8779			.7316		.695	.6081
20	.8413			.8413		.7682	
21	.8048			.8779			.6009
22	.7682			.7682			.679
23	.7316			.7682			.6562
24	.6219	.6584		.6219	.695		.5914
Max	.8779	.6584	.5175	.9511	.9145	.7682	.679
Min	.439	.4024	.4024	.4024	.3048	.3658	.2561
Avg	.6302	.5191	.4423	.6272	.6333	.4910	.4780

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074020 / 33/11 KV JANEFAL

Feeder No / Name : 205 / 11 KV NAIGAON DATTAPUR

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4755		.4024	.5487		.439
2		.5121		.4024	.5487		.439
3		.5487		.439	.6219		.5121
4		.6219		.4755	.6584		.5487
5		.6584		.6219	.8779		.5853
6		.7316		.9511	.9145		.8779
7		.695		.8048	.8413		.8316
8		.6584		.6584	.8048		.7316
9		.6219		.6584	.7316		.695
10		.5487	.439	.4572	.6584		.5487
11	.4755	.4001		.439	.6668		.439
12	.4755	.6097	.4024	.4024			
13	.439		.4024	.3658	.6668	.3292	.3185
14	.439		.3658	.4024	.4001	.4024	
15	.4755		.4024	.4024		.4755	
16			.4435	.439	.4001	.5853	
17			.4755	.4755	.4763	.6219	
18				.5487		.6584	.6325
19	.5853			.695		.823	
20	.6219			.7316		.7023	
21	.5487			.6584			.5121
22	.5487			.5853			.4588
23	.5121			.5487			.4096
24	.4435	.4755		.439	.5121		.4805
Max	.6219	.7316	.4755	.9511	.9145	.823	.8779
Min	.439	.4001	.3658	.3658	.4001	.3292	.3185
Avg	.5059	.5813	.4187	.5418	.6455	.5748	.5565

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074020 / 33/11 KV JANEFAL

Feeder No / Name : 206 / 11 KV HIWARA KD GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6219		.6219	.6584		.6401
2		.6219		.6219	.6219		.6401
3		.6584		.5853	.6219		.5914
4		.6584		.6584	.6584		.6283
5		.695		.695	.7316		.7023
6		.7682		.9145	.8779		.8779
7		.7682		.8779	.8413		.8779
8		.5853		.7316	.8413		.7762
9		.5487		.6584	.7682		.6584
10		.5121		.5853	.6584	.7316	.6584
11	.439	.5335		.5487		.695	.5487
12	.439	.5335		.5121	.6859	.6584	
13	.4755			.4755	.6859	.6219	
14	.4755		.439	.4755	.6097	.6219	
15	.439		.4066	.439		.6219	.4588
16		.6097		.439	.5335	.5487	.3932
17			.7023	.4755	.5335	.6219	
18			.7316	.5487		.7316	
19	.8048			.695		.8413	.5601
20	.7682			.7682		.8779	
21	.7316			.8413			
22	.695			.7682			.5535
23	.6584			.7316			.5121
24	.6219	.6584		.6584	.695		.6653
Max	.8048	.7682	.7316	.9145	.8779	.8779	.8779
Min	.439	.5121	.4066	.439	.5335	.5487	.3932
Avg	.5953	.6267	.5699	.6386	.6889	.6884	.6319

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074045 / 33/11 KV LONIGAWALI

Feeder No / Name : 201 / 11 KV ANDHURD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1734	.2774				
2			.2774				
3			.2774				
4			.3121				
5			.3467				
6			.3467		.2774		
7			.3467		.3467		
8			.3467		.3467		.1734
9			.3467		.2427		.2427
10	.2601		.3467		.3467		.2774
11	.3814		.3467	.3467	.4854		.2774
12	.3467		.3467	.5201	.6588	.3121	.2774
13	.3467		.3467	.5548	.5201	.4854	.2774
14	.5548	.2427	.3467	.6068	.6762	.4854	.2774
15	.6241	.2427	.3467	.5201		.4854	.2774
16		.2427	.3467	.5201		.4854	.2774
17		.2427	.4161		.3467	.4508	.2601
18	.6935	.2427	.3467	.4161	.3467	.4508	.2601
19		.2601		.5201	.3467		.2427
20		.2601					.208
21		.2601					.1734
22		.2427					.1734
23		.2601					
24			.2601				
Max	.6935	.2601	.4161	.6068	.6762	.4854	.2774
Min	.2601	.1734	.2601	.3467	.2427	.3121	.1734
Avg	.4582	.2427	.3330	.5006	.4117	.4508	.2450

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074045 / 33/11 KV LONIGAWALI

Feeder No / Name : 203 / 11 KV BHIWAPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3121	.2601			
2			.3467	.2774			
3				.2774			
4				.3121			
5				.3467			
6				.3467			
7	.1387		.3467	.4161			
8	.1734		.3467	.4334	.1734		
9	.2601		.3467	.3467	.2774		
10	.3467		.3467	.3467	.2774		.1387
11	.4508				.2774		.2774
12	.3814	.3467			.2774		.2601
13	.3467	.3121			.2774		.2427
14	.2774	.2774					.2427
15		.2774				.1387	.208
16						.1387	.1734
17						.1734	.1734
18						.208	
24			.1734	.1734			
Max	.4508	.3467	.3467	.4334	.2774	.208	.2774
Min	.1387	.2774	.1734	.1734	.1734	.1387	.1387
Avg	.2969	.3034	.317	.3215	.2601	.1647	.2146

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074045 / 33/11 KV LONIGAWALI

Feeder No / Name : 204 / 11 KV BHIVAPUR GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7802	.6935	.8322	.7802	.8669		.6935
2			.6935	.6935	.8322		.6588
3	.6935		.7802	.6588	.6935		.5548
4	.6935		.6935		.7282		.5201
5	.8322		1.387		.7802		
6	1.2136		1.647	1.387	1.0402		
7	1.387		1.3003	1.647	1.387		
8	1.1269		1.1269	1.3003	1.3003		1.0749
9	.9709		.9709	1.1443	1.1269		.8322
10	.7975		.8322	.9709			.6588
11	.7975		.7975	.8669			.5548
12	.7975	.7975	.7975	.8322		.6935	.5201
13	.7975	.5201	.6935	.6935		.5548	.5201
14	.8322	.6935	.6935	.6935		.5201	.5201
15	.8322	.6935	.7975	.7282		.4854	.5201
16		.9536	.8669	.8322	.6935	.5201	.4854
17		1.1269	.9015	.9709	.6935	.6935	.6935
18	1.0402	1.2136	1.0402	1.0402	.8669	.9709	.9709
19	1.2136	1.3523	1.2136	1.1789	1.0749	1.0402	1.0402
20	1.1789	1.2136	1.387	1.2136		1.2136	1.0056
21	1.0402	1.1269	1.2136	1.1789		1.0402	.9362
22	.9015	1.0402	.9709	1.1269	.6935	.9709	.7975
23	.7975	.9709	.8669	1.0402		.8669	.7802
24	.8322	.7802	.8669	.8322	1.0056		.7802
Max	1.387	1.3523	1.647	1.647	1.387	1.2136	1.0749
Min	.6935	.5201	.6935	.6588	.6935	.4854	.4854
Avg	.9313	.9412	.9738	.9914	.9189	.7975	.7199

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074045 / 33/11 KV LONIGAWALI

Feeder No / Name : 205 / 11 KV ANDHRUD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6588	.6935	.7802	.6935	.6935		.6935
2	.6068		.6935	.6588	.6588		.6241
3	.5548		.6588	.6241	.6068		.6068
4	.6588		.6935	.6588	.6588		.6588
5	.7282		.6935	.6935	.6935		.6935
6			1.2136	1.1269			1.2136
7			1.1269	1.2656	1.0402		1.2136
8			.8669	1.0402	1.2136		1.1789
9	.2601		.8322	.7975	1.0402		1.0402
10	.3121		.6068	.6935	.8669		.6241
11	.6762	.5548	.6241	.6068	.3467		.5895
12	.5201	.5201	.5548	.5201	.4854	.5201	.5895
13	.6241	.5548		.4854	.5201	.5548	.6068
14	.6935	.6588	.5548	.4508		.5548	.6068
15	.8322	.6588	.5548	.5201		.5548	.6241
16		.6588	.6241	.6588	.6588	.5548	.6241
17	.1734	.7975	.6762	.7282	.6935	.6935	.6935
18	.1734	.9709	.7802	.8322	.8322	.8149	.6935
19	.6935	1.0402	1.0402	.8669	.8669	.8669	1.0402
20	1.0402	.7554	1.2136	1.0402		1.0402	1.0056
21	1.1443	1.0402	1.0402	.9709		.9709	.8669
22	.8669	.9709	.7975	.8669	.6935	.8669	.7975
23	.7628	.8669	.7802	.8322		.7975	.6935
24	.6935	.7282	.8322	.7282	.7802		.7802
Max	1.1443	1.0402	1.2136	1.2656	1.2136	1.0402	1.2136
Min	.1734	.5201	.5548	.4508	.3467	.5201	.5895
Avg	.6337	.7647	.7930	.7650	.7416	.7325	.7816

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074045 / 33/11 KV LONIGAWALI

Feeder No / Name : 206 / 11 KV GHATBORI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4854	.5548	.6068	.4854	.5548		.5201
2	.4508		.5548		.5201		.4854
3	.4854			.4854	.4854		.5201
4	.8669			.5201	.5201		.5548
5	.6935			.6935	.5895		.6068
6	.8669			1.0402	.8669		1.0402
7	.6241		.7802	.7975	1.0402		.8669
8	.5201		.6588	.7282	.8669		.6935
9	.4854		.6068	.5201	.5548		.6241
10	.4508		.4854	.4854	.5201		.5201
11	.4508		.4854	.4854	.4854		.4854
12	.4854		.4508	.4854	.4854	.6241	.4508
13	.4854		.4161	.4854	.4854	.5548	.4854
14	.4854		.4161	.4854	.4854	.5201	.5201
15	.4854	.5201	.4508	.4854	.4854	.4854	.5548
16		.6068	.5201	.5201		.4854	.6241
17	.6935	.6935	.5548	.5548		.5201	.6241
18	.6935	.8322	.6935	.6935	.6935		.6935
19	.8322	1.0402	.8669	.7802	.8669		.8669
20	.9015	.9709	1.0402	.8669			1.0402
21		.8669	.8669	.8322			.6935
22	.8322	.7802	.6241	.7802	.6241	.6935	.6935
23	.6935	.6935	.5548	.6935	.1387	.6241	.6588
24	.5201	.6241	.6241	.5201	.6241		.5548
Max	.9015	1.0402	1.0402	1.0402	1.0402	.6935	1.0402
Min	.4508	.5201	.4161	.4854	.1387	.4854	.4508
Avg	.6131	.7439	.6129	.6271	.5947	.5634	.6407

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074045 / 33/11 KV LONIGAWALI

Feeder No / Name : 207 / SJS INFRA TECH EXPRESS

FEEDER Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0347	.0347	.0347	.3467	.2601		.3467
2	.0347		.0347	.3467	.1734		.3467
3	.0347		.0347	.3467	.0347		.3467
4	.0347		.0347	.3467	.0347		.3121
5	.0347		.0347	.3467	.0347		.2601
6	.0347		.0347	.3467	.0347		.1734
7	.0347		.1214	.2601	.0347		.0347
8	.0347		.1734	.0347	.0347		.0347
9	.0347		.1734	.0347	.0347		.0347
10	.0347		.0347	.1734	.104		.0347
11	.0347	.0347	.0347	.1734	.104		.0347
12	.0347	.0347	.0347	.1734	.0347	.0347	.1734
13	.0347	.0347	.0347	.1734	.0347	.0347	.3467
14	.0347	.0347	.0347	.1734	.0347	.3467	.3467
15	.0347	.0867	.1734	.1734	.0347	.5201	.3467
16	.0347	.1214	.2774	.3467	.3467	.5201	.1734
17	.0347	.1214	.3467	.5201	.5201	.5201	.0347
18	.0347	.2427	.3467	.3467	.5201	.5201	.0347
19	.0347	.2427	.3467	.3467	.5548	.3467	.3467
20	.0347	.2427	.3467	.3467		.1734	.3467
21	.0347	.0347	.2601	.3467		.1734	.2601
22	.0347	.0347	.1734	.3467	.0347	.1734	.208
23	.0347	.0347	.1734	.3467	.0347	.1387	.3467
24	.0347	.0347	.0347	.1734	.3467		.1734
Max	.0347	.2427	.3467	.5201	.5548	.5201	.3467
Min	.0347	.0347	.0347	.0347	.0347	.0347	.0347
Avg	.0347	.0913	.1387	.2738	.1537	.2918	.2124

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074062 / 33/11 KV DEULGAON MALI

Feeder No / Name : 201 / 11 KV NAGZARI AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	03-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5281		.4115
2			.6036		.4115
3			.5658		.463
4			.5658		.463
5			.5975		
6			.6348	.5544	
7			.6722	.5544	
8			.6908	.499	.463
9				.4435	.463
10				.499	.4458
11	.8316	.4481			
12	.8871	.4481			
13	.7762	.4108			
14	.7762	.3921			
15		.3921			
16		.2987			
17		.2614			
18		.2614			
Max	.8871	.4481	.6908	.5544	.463
Min	.7762	.2614	.5281	.4435	.4115
Avg	.8178	.3641	.6073	.5101	.4458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074062 / 33/11 KV DEULGAON MALI

Feeder No / Name : 202 / 11 KV NAGZARI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1509	.1494	.2054			.2641
2	.2241	.1509	.1494	.2054			.2641
3	.3361	.132	.1494	.2054			.2829
4	.3361	.1509	.168	.2241			.2987
5		.2263	.2614	.2614			.3734
6		.2829	.3547				.5415
7	.2614	.2641	.3734				.6348
8	.2641	.2075	.3174				.4481
9	.2452		.1886			.4715	
10	.2075		.1867			.3961	.2987
11	.1886		.168		.2241	.2801	
12	.2075		.1307		.2218	.2801	
13	.2263		.1494		.2427	.2241	
14	.2241				.2987	.2427	
15	.2241				.3018	.2987	
16		.1494			.2641	.2801	
17		.168			.3018	.3361	
18		.168	.3361			.3547	
19		.2614				.3361	
20		.2427	.4294		.4715	.3361	
21		.168	.4108		.3206		
22	.1509	.1867	.3734		.3206	.3174	
23	.1132	.1494	.3361			.2987	
24	.2054	.132	.1494	.2427			.2987
Max	.3361	.2829	.4294	.2614	.4715	.4715	.6348
Min	.1132	.132	.1307	.2054	.2218	.2241	.2641
Avg	.2251	.1877	.2517	.2241	.2968	.3180	.3705

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074062 / 33/11 KV DEULGAON MALI

Feeder No / Name : 203 / 11 KV WARUDI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.415	.4108	.4108	.4904	.3961	.4108
2	.4481	.415	.4108	.415	.4527	.3961	.4108
3	.5601	.3772	.4108	.415	.4527	.4527	.4481
4	.5601	.415	.4481	.4527	.5281	.5093	.5415
5	.7468	.5658	.6535	.5228	.6722	.5658	.5788
6	.8215	.6602	.7095	.6535	.7842	.679	.8589
7	.7468	.8488	.6908	.7468	.8402	.7356	.8215
8	.7167	.7545	.7468	.5975	.5975	.679	.7842
9	.5093	.5658	.5415	.5041		.547	
10	.415	.4904	.4668	.3361			.4294
11	.4338	.3921	.3361	.3547	.3961		
12	.415	.4481	.3361	.3734	.3395		
13	.3961	.3921	.4108	.3734	.3734		
14	.4527	.3361	.4294	.3547	.3734		
15	.415	.3921	.3921		.3696		
16		.4108	.4481		.5093		
17		.4481	.6535		.547		
18		.5601	.6535			.7655	
19		.5788	.6535	.8215		.7842	
20		.5415	.5975	.8589	.6602	.7468	
21		.5041	.5975	.8215	.4715	.6348	
22	.5281	.4854	.5228	.7468	.4715	.5601	
23	.5093	.4668	.4481	.679	.4527	.4854	
24	.4294	.4715	.4108	.4108	.5281	.4527	.4854
Max	.8215	.8488	.7468	.8589	.8402	.7842	.8589
Min	.3961	.3361	.3361	.3361	.3395	.3961	.4108
Avg	.5286	.4973	.5158	.5425	.5155	.5869	.5769

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074062 / 33/11 KV DEULGAON MALI

Feeder No / Name : 204 / 11 KV WARUDI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.1029	.2263		
2	.3361	.1029	.1698		
3	.3361	.1543	.1698		
4	.3921	.2058	.168		
5	.3921	.2058	.168		
6	.4481	.2058	.2241		
7	.4481	.2572	.2801		
8		.2572	.2241		
9		.2058	.2801		
10			.2801		
11			.2614	.3326	.5093
12			.2427	.3326	.4527
13			.2241	.3326	.4527
14			.2241	.3142	.3395
15				.3326	.3395
16				.3326	.2572
17				.3326	.2572
18					.1715
24	.2801				
Max	.4481	.2572	.2801	.3326	.5093
Min	.2801	.1029	.168	.3142	.1715
Avg	.3641	.1886	.2245	.3300	.3475

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074070 / 33 KV UKALI

Feeder No / Name : 201 / 11 KV UKALI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1166	.1296	.0187	.0343
2			.1446	.0907	.0187	.0354
3			.1425	.1	.0187	.0351
4			.1555	.0914	.0187	.0351
5			.1814	.0914	.0187	.0354
6			.1814	.1067	.0187	.0526
7			.1814		.0187	.0351
8			.1814		.0187	.0354
9			.1814	.061	.0187	.0343
10			.1943	.0594	.0187	.0343
11		.2743				
12	.3841	.3125				.0572
13	.3658					.0678
14	.3658					.0743
15						.0714
17	.2743					
18	.2195	.0171				
Max	.3841	.3125	.1943	.1296	.0187	.0743
Min	.2195	.0171	.1166	.0594	.0187	.0343
Avg	.3219	.2013	.1661	.0913	.0187	.0456

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074070 / 33 KV UKALI

Feeder No / Name : 202 / 11 KV BORI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.168				
2		.168				
3		.168				
4		.1663				
5		.1848				
6		.2402				
7	.2378	.2772				
8	.3109	.2772				
9	.3109	.2218				
10		.1848				
11				.1858	.1494	.0343
12				.1715	.1307	.0343
13				.1429	.168	.0343
14				.1429	.2054	.0175
15			.1143	.1429	.2054	.0343
16			.1858	.1572	.168	.0343
17			.1572	.1572	.1494	.0343
18			.1572	.1429	.1307	.0351
Max	.3109	.2772	.1858	.1858	.2054	.0351
Min	.2378	.1663	.1143	.1429	.1307	.0175
Avg	.2865	.2056	.1536	.1554	.1634	.0323

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074070 / 33 KV UKALI

Feeder No / Name : 203 / 11 KV UKALI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9328	.8215	.8097	.9431	.8488		.8573
2	.8779	.8131	.7373	.9431	.8488		
3	.8779	.8962	.7373	1.0185	.9054		.8478
4	.8779	.924	.9374	1.094	.9709		.9221
5	1.134	1.2012	1.186	1.1694	1.2012		.9945
6	1.6461	1.8111	1.448	1.6448	1.3306		.9945
7	1.4266	1.7926	1.448	1.8858			1.0774
8	1.3169	1.6632	1.0402	1.5708	1.8484		1.0059
9	1.2986	1.4045	.9145	1.3443	1.4045		1.0059
10		.8316	.7621	1.2696	1.1694		
11		.7716	.8962	1.0374	.8962		
12	1.0974	.7888	.4904	.8962	.8402	.7716	.9054
13	1.0059		.4904	.8402	.7842	.7362	.8676
14	.9694			.8299	.8402	.7011	
15			.8488	.9335	1.1389	.8573	
16			.9619	.9997	1.1203	1.0174	
17	1.4998		1.1458	1.1088	.9896		
18	1.3535		1.386	1.2936	1.3443	1.1869	
19	1.4937	1.3375	1.4784	1.4969	1.7364	1.2289	1.7164
20	1.4003	1.0669	1.4415	1.2012		1.0526	1.5708
21	1.1203	.9907	1.3203	.9425	1.1763	1.004	1.4415
22	.9709	.8478	1.2071	.9425	1.0269	.9602	1.0164
23	.9335	.8478	.0191	.8962		.8002	.8316
24	.9145	.8402	.8192	.9619	.8865		.8573
Max	1.6461	1.8111	1.4784	1.8858	1.8484	1.2289	1.7164
Min	.8779	.7716	.0191	.8299	.7842	.7011	.8316
Avg	1.1574	1.0917	.9794	1.1360	1.1099	.9379	1.0570

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074070 / 33 KV UKALI

Feeder No / Name : 204 / 11 KV EXPRESS FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0366	.0187	.0181	.0191	.0191	.0187	.0183
2	.0366	.0373	.0181	.0191	.0191	.0187	.0183
3	.0366	.0373	.0183	.0191	.0191	.0187	.0183
4	.0366	.0373		.0191	.0191	.0187	.0183
5	.0366	.0373	.0179	.0191	.0191	.0187	.0183
6	.0366	.037	.0181	.0191	.0191	.0187	.0183
7	.0366	.037	.0183	.0191	.0191	.0187	.0181
8	.0183	.037	.0181	.0191	.0191	.0187	.0181
9	.0183	.037	.0183	.0191	.0191	.0187	.0181
10		.037	.0181	.0191	.0191	.0187	.0181
11		.0181	.0191	.0191	.0187	.0181	.0191
12	.0183	.0181	.0191	.0191	.0187	.0181	.0191
13	.0183		.0191	.0191	.0187	.0181	.0191
14	.0183		.0191	.0191	.0187	.0181	.0191
15			.0191	.0191	.0187	.0181	.0191
16			.0191	.0191	.0187	.0181	.0191
17	.0366		.0191	.0191	.0187	.0181	.0191
18	.0366		.0191	.0191	.0373	.0181	.0191
19	.056		.0191	.0191	.056	.0181	.0381
20	.056	.0171	.0191	.0191	.056	.0181	.0381
21	.0373	.0171	.0191	.0191	.056	.0181	.0191
22	.0373	.0177	.0191	.0191	.0373	.0177	.0381
23	.0373	.0171	.0191	.0191		.0177	.0381
24	.0366	.0373	.0181	.0191	.0191		.0181
Max	.056	.0373	.0191	.0191	.056	.0187	.0381
Min	.0183	.0171	.0179	.0191	.0187	.0177	.0181
Avg	.0341	.0291	.0187	.0191	.0254	.0183	.0219

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074094 / 33 KV KALAMBESHWAR

Feeder No / Name : 201 / 11 KV KALAMBESHWAR

GAOTHAN FEEDER

GAONTHAN Feeder KV- 11 /
OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3315	.3647	.4938	.4374	.4458		.4115
2	.3315	.3647	.4938	.4374	.4458		.4115
3	.3315		.4938	.4374	.4458		.4115
4	.3353	.3688		.6001	.4458		.4115
5	.3647	.3688		.7164	.4801		.4458
6	.4096	.3978		.7133	.5144		.6516
7	.4588	.3978	.6626	.6154	.5144		.583
8	.4588	.3978	.5014	.4298	.5144	.5258	.5144
9	.3978	.3353	.4656	.3582	.4557	.4908	.4801
10	.3772	.3353	.394	.3475	.3506	.3856	.3772
11	.3429	.3315		.3086	.3544	.3506	.3772
12	.3429	.3315		.2743	.3155	.3506	.3429
13	.3429	.3315		.2401	.3189	.3155	.3429
14	.3772	.2715	.3801	.3086	.3155	.3856	.3429
15	.3429	.3292	.3801	.3086			.3429
16			.439	.3086			.3429
17		.3658	.543	.3258	.4607		.4801
18		.543	.5731	.463	.4961		.4801
19	.4115	.5014	.6154	.4801	.543		.5144
20	.4115	.4835	.591	.4801			.463
21	.4115	.4835	.567	.4458			.3772
22	.3772	.4938	.5487	.4458	.543		.3772
23	.3772	.4938	.5121	.4458			.3772
24		.3772	.4938	.5121	.4458		.3944
Max	.4588	.543	.6626	.7164	.543	.5258	.6516
Min	.3315	.2715	.3801	.2401	.3155	.3155	.3429
Avg	.3767	.3940	.5082	.4350	.4424	.4006	.4272

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074094 / 33 KV KALAMBESHWAR

Feeder No / Name : 202 / 11 KV KALAMBESHWAR AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1638	.2187		
2	.1562	.2214		
3	.1619	.2187		
4	.1562	.2343		
5		.2429		
6	.0949	.253		
7	.2187	.2622		
8	.2656	.2591		
10	.1718	.1638		
11		.2675	.2934	.1467
12		.2824	.2972	.2258
13			.301	.2201
14		.2675	.301	.176
15		.2675	.2675	
16		.2675		
17		.2378	.2378	
18		.1783	.2378	
24	.16			
Max	.2656	.2824	.301	.2258
Min	.0949	.1638	.2378	.1467
Avg	.1721	.2402	.2765	.1922

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074094 / 33 KV KALAMBESHWAR

Feeder No / Name : 203 / 11 KV KASARKHED AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	05-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.535
2				.535
3	.4588			.535
4	.4588			.535
5	.4588			.535
6	.4858			.5944
7	.4858			.5944
8				.5944
9	.5601			.5719
10	.6516			.5281
11	.6241	.4801		
12	.6241	.6173		
13	.6241	.6009		
14	.6241	.4999	.4218	
15	.6241		.4801	
16			.5693	
17			.5624	
18			.5247	
Max	.6516	.6173	.5693	.5944
Min	.4588	.4801	.4218	.5281
Avg	.5567	.5496	.5117	.5558

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074097 / 33/11 KV PIMPALGAON UNDA

Feeder No / Name : 203 / 11 KV PIMPALGAON UNDA FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3246				
2	.3429	.3288				
3	.3429	.3403				
4	.3429	.3262				
5	.3258	.3254				
6	.3086	.3743				
7	.3429	.3441				
8	.3429	.3756				
9	.3429	.3288				
10	.3429	.3453				
11			.3734	.4287		.4758
12			.4108	.4458	.3896	.4378
13			.4481	.4287	.3896	.4378
14			.4668	.4115	.3782	.4758
15				.3772	.3617	.4758
16				.3772	.4412	.4949
17				.3772	.4229	.4758
18				.3772	.4129	.4758
Max	.3429	.3756	.4668	.4458	.4412	.4949
Min	.3086	.3246	.3734	.3772	.3617	.4378
Avg	.3378	.3413	.4248	.4029	.3994	.4687

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074098 / 33/11 KV BHALEGAON (PACHALA)

Feeder No / Name : 201 / 11 KV BHALEGAON GAONTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)
1		.2401
2		.2743
3		.3258
4		.3944
5		.4801
6		.5487
7		.583
8		.5144
13		.1372
14		.1372
15	.2058	.1715
16	.2401	.2058
17	.2401	.2401
18	.2572	
19	.2915	.2743
20	.3258	.2401
21	.3258	.1715
22	.2915	.1715
23	.2401	.1715
24		.2401
Max	.3258	.583
Min	.2058	.1372
Avg	.2687	.2906

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 077004 / 132/33/11 KV MEHKAR

Feeder No / Name : 202 / 11 KV MEHKAR TOWN 2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
23	1.5851
Max	1.5851
Min	1.5851
Avg	1.5851

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 077004 / 132/33/11 KV MEHKAR

Feeder No / Name : 203 / 11 KV SONATI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	.0762
Max	.0762
Min	.0762
Avg	.0762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 077004 / 132/33/11 KV MEHKAR

Feeder No / Name : 204 / 11 KV MEHKAR TOWN 1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	1.6766
Max	1.6766
Min	1.6766
Avg	1.6766

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 077004 / 132/33/11 KV MEHKAR

Feeder No / Name : 205 / 11 KV SULTANPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 077004 / 132/33/11 KV MEHKAR

Feeder No / Name : 206 / 11 KV CHAIGAON AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	.2286
Max	.2286
Min	.2286
Avg	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074040 / 33/11 KV TUNKI S/STN

Feeder No / Name : 202 / 11 KV TUNKI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	1.0288
Max	1.0288
Min	1.0288
Avg	1.0288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074040 / 33/11 KV TUNKI S/STN

Feeder No / Name : 203 / 11 KV BAWANBIR AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	1.0288
Max	1.0288
Min	1.0288
Avg	1.0288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074040 / 33/11 KV TUNKI S/STN

Feeder No / Name : 204 / 11 KV WASADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			2.6292	2.6863	2.7054	1.5242	
2			2.553	2.6673	3.0483	1.6766	
3			2.553	2.6673	3.0483	1.7147	
4			2.6292	2.6292	3.1245	1.7147	
5			2.8578	2.934	3.1245	1.9814	
6			3.0674	3.1626	3.4294	2.8959	
7			2.8959	3.0864	3.3532	3.3341	
8			2.7054	2.8959	3.2388	3.4294	
9			2.4768		3.1245	3.6199	
10			2.3624	2.4768	2.7816	3.0864	
11	3.4294						3.8104
12	2.553	3.5246					2.8959
13	3.5818	3.5246					2.9912
14	3.3532	3.2198					2.915
15	3.3722	3.1245					2.934
16	3.2769	3.3532					2.9721
17	2.7816						2.8197
18	2.5149	2.7244					2.5149
Max	3.5818	3.5246	3.0674	3.1626	3.4294	3.6199	3.8104
Min	2.5149	2.7244	2.3624	2.4768	2.7054	1.5242	2.5149
Avg	3.1079	3.2452	2.6730	2.8006	3.0979	2.4977	2.9817

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074040 / 33/11 KV TUNKI S/STN

Feeder No / Name : 205 / 11 KV TUNKI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.8192	.8764	.9145	1.0288	.724	.9145
2	.8383	.8002	.8573	.8954	.9526	.724	.8573
3	.8383	.8002	.8573	.8764	.9526	.6859	.8573
4	.8002	.8002	.8573	.9145	.9526	.6859	.8764
5	.8383	.8002	.8383	.9526	.9526	.6668	.9145
6	.8764	.8383	.8764	1.0479	1.0288	.6859	.9717
7	.8002	.8002	.8573	1.0288	.9526	.7049	.8764
8	.7811	.724	.8573	1.0098	.9145	.6097	
9	.7621	.724	.8383	.9335	.8954	.6097	.8192
10	.9145	.7621			.8002		.8002
11	.8002			.9335	.6859		.8383
12	.8002	.6859		.9145	.8383		.743
13	.7621	.5906		.9145	.8192	.8002	.8002
14	.8002	.743		.9907	.8192	.7811	.8383
15	.8002	.8383	.9907	.9526	.8002	.9335	.8573
16	.8383	.8573	.8764	.9717	.8002		.9335
17	.7621		.8573	.9526	.8383	.8954	.8764
18	.8383	.8764	.8383	.9907	.9145		.8764
19	.9145	.9526	.9526	1.0288		1.1812	1.1431
20	1.0669	1.086	1.105	1.105	1.1431	1.1622	1.3336
21			1.0288	1.2574	1.0479	.0953	1.2193
22	.9145	.9335	.9907		.9907	.9907	1.1431
23	.9145	.9335	.9526		.9145		1.105
24	.9526	.7621	.8954	.9145	1.105	.8764	.9335
Max	1.0669	1.086	1.105	1.2574	1.1431	1.1812	1.3336
Min	.7621	.5906	.8383	.8764	.6859	.0953	.743
Avg	.8491	.8156	.9055	.9762	.9195	.7674	.9360

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAMPUR S/DN.[809] BU 4809

Substation No/ Name :- 074041 / 33/11 KV WARWAT BAKAL S/STN

Feeder No / Name : 201 / 11 kv Warwat Bakal AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715					.1715
2	.1715	.1715					.1543
3	.1372	.1372					.1372
4	.1372	.1543					.1372
5	.1715	.1372					.1372
6	.3429	.2058					.1715
7	.463	.3086					.2743
8	.3429	.3772					.2915
9	.2743	.3429					.2058
10	.2401	.2058					.2401
11			.4287	.3772	.463		
12			.2229	.3086	.2572		
13			.2058	.1886	.1886		
14			.2229	.1715	.2058		
15			.2401	.1372	.1715	.2401	
16			.2401	.1715	.2229	.3258	
17			.3086	.2743	.2743	.2915	
18			.2572	.2915		.3944	
19						.1886	
20						.1543	
24	.2058						
Max	.463	.3772	.4287	.3772	.463	.3944	.2915
Min	.1372	.1372	.2058	.1372	.1715	.1543	.1372
Avg	.2416	.2212	.2658	.2401	.2548	.2658	.1921

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074041 / 33/11 KV WARWAT BAKAL S/STN

Feeder No / Name : 202 / 11kv wankhed ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.2689			
2				1.2689			
3				1.2003			
4				1.2003			
5				1.2003			
6				1.166			
7				1.3375			
8				1.3375			
9				1.3717			
11	1.8861				1.8861		1.4575
12	1.9033		1.2689		2.0576		1.6461
13	1.8347				1.9033		1.7147
14	1.8004				1.8861		1.749
15	1.8004	1.8004			1.9719		1.749
16	1.8004	1.8004	1.7661		1.9719		1.749
17	1.7661		1.8519		1.9719		1.8861
18			1.5089		1.9719		1.8004
19			1.3717				
20			1.3717			1.3717	
21			1.3717			1.3375	
22		1.286	1.3375			1.3375	
23		1.3889				1.3717	
Max	1.9033	1.8004	1.8519	1.3717	2.0576	1.3717	1.8861
Min	1.7661	1.286	1.2689	1.166	1.8861	1.3375	1.4575
Avg	1.8273	1.5689	1.4811	1.2613	1.9526	1.3546	1.7190

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074041 / 33/11 KV WARWAT BAKAL S/STN

Feeder No / Name : 203 / 11kv KAKANWADA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2689	2.0576	.6516	1.4403	1.2689	1.4918	1.2003
2	1.2689	2.0919	.6516	1.4403	1.2003	1.4746	1.1145
3	1.2689	2.0576	.6516	1.4403	1.2003	1.4575	1.1145
4	1.2689	2.0576	.6516	1.406	1.286	1.4575	1.1145
5	1.2689	2.0233	.6516	1.406	1.286	1.4575	1.1145
6	1.3717	2.0748	.6516	1.4403	1.3717	1.4746	1.1145
7	1.5089	2.1605	.823	1.5089	1.3717	1.5432	1.166
8	1.5432	2.1262	.9431		1.3717	1.5261	1.2346
9	1.5432	2.0576	.9431		1.4918		1.2346
10	1.5089	2.1262	.8573		1.4918		1.2689
11		2.0576	1.2003		1.4575		1.3375
12		2.1262	1.1317	2.3148	1.3203		1.3717
13		2.1262	1.2346	2.3491	1.3375		1.3717
14	1.3375	2.1091	1.2174	2.2291	1.3375		1.3375
15	1.2003	2.1434	1.286	2.4006	1.286		1.4403
16	1.4232	1.8004	1.2346	2.4006	1.2003		1.4746
17	1.3717		1.4403	2.4006	1.3889	1.7833	1.5089
18			1.2346	2.2291	1.4232	1.8861	1.5089
20						1.9719	
21						1.8861	
24	1.2689						
Max	1.5432	2.1605	1.4403	2.4006	1.4918	1.9719	1.5089
Min	1.2003	1.8004	.6516	1.406	1.2003	1.4575	1.1145
Avg	1.3615	2.0748	.9698	1.8861	1.3384	1.6175	1.2793

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAMPUR S/DN.[809] BU 4809

Substation No/ Name :- 074041 / 33/11 KV WARWAT BAKAL S/STN

Feeder No / Name : 205 / 11 kv Warwat bakal GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.166	1.0974	1.2003	1.0631	1.1317	.9945	1.0288
2	1.166	1.1145	1.1145	1.0631	1.0288	.9945	.6859
3	1.1317	1.1145	1.1488	1.0288	1.0288	1.0117	.8402
4	1.1317	1.0117	1.1488	1.0288	.9431	.9602	.9431
5	1.0288	1.1145	1.046	.9602	.9431	.9602	.9945
6	1.0288	.9602	.9431	.2743	.9088	.8573	.9431
7	.8745	.8573	.8573	.2401	.823	.823	.7716
8	.8573	.8573	.7716	.2401	.7545	.7716	.7545
9	.8573	.8745	.6859	.3086	.7545		.6859
10	.8573	.8573	.7202		.7888		.6859
11	.8573	.8745	.6859	.9259	.7888		.7888
12	.9431	1.0288	.8573	.9259	.9088		.8573
13	1.0288	1.0288	.8916	1.0631	1.0288		.8916
14	1.0631	1.046	.8916	1.0631	1.0288	1.0974	.9602
15	1.0631	1.0802	.9259	1.1317	1.0288	1.1317	.9602
16	1.0288	1.0631	.8573	1.0631	1.0288	1.1317	.9602
17	.9945		.8916	.9945	.9431	.8916	.9259
18	.9431		.823	.8573		.9431	.8916
19			.9259	1.0974		1.1317	1.0288
20	1.3032	1.286	1.0974	1.0974		1.286	1.1145
21	1.2346	1.286	1.0974	1.1317	1.3032	1.286	1.1145
22	1.2689		1.0974	1.1145		1.2689	1.0631
23	1.2346	1.2346	1.1317	1.166	1.1317	1.2003	1.0631
24	1.166	1.166	1.2003	1.0974	1.1145	1.046	1.1145
Max	1.3032	1.286	1.2003	1.166	1.3032	1.286	1.1145
Min	.8573	.8573	.6859	.2401	.7545	.7716	.6859
Avg	1.0534	1.0477	.9588	.9103	.9705	1.0414	.9195

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074041 / 33/11 KV WARWAT BAKAL S/STN

Feeder No / Name : 206 / 11 kv WANKHED GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.583	.5487	.5487	.5144	.5316	.5487	.5658
2	.583	.5144	.5487	.5144	.5144	.5487	.5658
3	.5487	.5144	.5144	.4801	.5144	.5316	.5658
4	.5487	.5144	.5144	.4801	.4801	.5316	.5316
5	.5144	.5144	.4801	.4458	.4801	.5316	.5144
6	.4458	.4115	.463	.4115	.4801	.463	.4973
7	.3429	.3429	.4287	.3772	.4801	.4115	.3772
8	.3429		.3258	.3429	.3601	.3258	.3086
9	.3429		.3086	.3258	.3429		.3086
10	.3772		.3258	.3429	.3258		.3601
11	.4458		.3601	.4115	.3772		.3429
12	.4801		.3944	.4115	.4458		.4115
13	.5144		.3772	.4801	.4973	.4801	.4115
14	.5144		.463	.4801	.4973	.4801	.4458
15	.5316	.6001	.4458	.4801	.5144	.4801	.4458
16	.4458	.6001	.4287	.463	.4801	.4801	.4458
17	.4115		.4115	.4115	.4458	.4458	.4115
18	.3772	.4458	.4115	.4287	.4115	.4801	.3772
19	.5487	.4801	.4458	.5144	.4801	.5487	.4801
20	.5658	.583	.583	.5144	.5144	.6001	.5487
21	.583	.583	.583	.4801	.6001	.6001	.5487
22		.6344	.583	.4973	.583	.6001	.5144
23	.583	.583	.5316	.4973	.6001	.5487	.5487
24	.583	.5487	.5658	.5144	.5316	.5658	
Max	.583	.6344	.583	.5144	.6001	.6001	.5658
Min	.3429	.3429	.3086	.3258	.3258	.3258	.3086
Avg	.4876	.5262	.4601	.4508	.4787	.5101	.4577

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAMPUR S/DN.[809] BU 4809

Substation No/ Name :- 074058 / 33/11 KV SANGRAMPUR S/STN

Feeder No / Name : 201 / 11 kV PALSHI FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9412	1.0456	.9335	.9149		1.0829
2	.9709	1.0829	.8505	.8775		1.1763
3	1.0082	1.1203		.8775		1.1317
4	1.0082	1.1203	.8131	.8962		1.0751
5	1.0082	1.1389	.7522	.9149		.961
6	.9774	1.1763	.811	.8775		
7	1.1949	1.1576	.6979	.7842		1.6651
8	1.2437	1.1576	.4938	.8215		1.6289
9	1.1203	1.1203	.3361	.7468		1.5684
10	.9709	1.1016	.4572	.7655		1.2803
11	.5975		1.0164	1.3256		.8029
12	.6161	.8596	1.1763	1.3443		.7468
13	.6535	.8962	1.2696	1.307		.7682
14	.6535	.7783	1.3256	1.251		.7682
15	.7095	.691	1.307	1.2136		.7964
16	.7468	.6767	1.2696			1.0829
17	.7842					1.0829
18	.8402	.2481	.168		.7973	.8048
19	.8962		1.0269		.7343	.7602
20	1.0642	.7133	.8962		1.0425	.9877
21	1.0642	.7316	.9896		.9709	1.0136
22	1.0829	.8596	.9896		.8417	
23	1.0642	.9795	.9896		.8316	
24	1.1203	1.0269	.9412	.9335		.7865
Max	1.2437	1.1763	1.3256	1.3443	1.0425	1.6651
Min	.5975	.2481	.168	.7468	.7343	.7468
Avg	.9307	.9372	.8869	.9907	.8697	1.0462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAMPUR S/DN.[809] BU 4809

Substation No/ Name :- 074058 / 33/11 KV SANGRAMPUR S/STN

Feeder No / Name : 202 / 11 KV BODKHA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.4854	.5601	.5041		.4715
2	.362	.4854	.4784	.4854		.4251
3	.2896	.4108	.4668	.4854		.4108
4	.2926	.4294	.4294	.4854		.3696
5	.2561	.4294	.4108	.4668		.3881
6	.2926	.3734	.3721	.4108		
7	.3734	.3361	.3361	.5228		.4572
8	.3361	.2987	.4668	.4481		.3658
9	.4108	.3361	.3841	.4854		.3292
10	.4344	.3547	.3174	.4854		
11	.6348		.4784	.4668	1.1888	.3292
12	.7095	.6348	.3734	.3547		.5601
13	.7282	.5975	.3547	.3734	.7947	.5601
14	.7468	.6447	.3361	.3734	.8596	.6878
15	.7655	.7186	.3361	.3921	1.0903	.7095
16	.7468	.6219	.3734	1.587	1.0208	
17	.7095	.3721	.3361	1.7551		
18	.6722	.4075	.2241	1.4563	.5304	.3734
19	.5975	.4572	.3547	1.4003	.3292	.4108
20	.5415	.4887	.4854	1.3443	.4251	.5792
21	.5601	.5304	.5228	1.307	.4572	.5914
22	.5788	.5853	.5228	1.307	.5249	.5975
23	.5601	.6161	.5228	1.2696	.5121	
24	.439	.5415	.5975	.5228	.9431	.4887
Max	.7655	.7186	.5975	1.7551	1.1888	.7095
Min	.2561	.2987	.2241	.3547	.3292	.3292
Avg	.5171	.4850	.4183	.7787	.7230	.4792

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074058 / 33/11 KV SANGRAPUR S/STN

Feeder No / Name : 203 / 11 KV NIWANA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7964	.8962	.9328	.8589			.8775
2	.8215	.8402	.8962	.8402			.8145
3	.7842	.8402	.8413	.8215			.7655
4	.7842	.8775	.7796	.8402			.679
5	.5975	.8589		.8589			.5853
6	.8215	.8402	.8402	.7282			
7	.8962	.8402	.6161	.8402			.9149
8	.7468	.8215		.6535			
9	.5975	.8402		.6908			.7619
10	.4344	.8589	.6401	.6348			.6415
11	1.0456		.9709	1.1203		.8501	.5847
12	1.1576	1.0425	.8775	.9149		.9055	.9412
13	1.1576	1.0288	.7468	.8402		.7865	1.0829
14	1.1949	1.1888	.5601	.7842		.6838	1.0829
15	1.2323	1.1888	.7095	.7095		.5853	1.1203
16	1.1576	.9774	.7095	.6722		.6283	
17	1.0829	.7602	.7468	.7468		.5975	
18	1.0642	.3189	.5415	.6348		.499	.9709
19	1.0829	.7947	.7282	.8402			.9877
20	1.0829	1.0456	.8589	.7842		1.0059	.9511
21	1.0456	1.0425	.9522	.7468		1.0425	.9709
22	1.0456	1.0242	.9335	.7095		1.0059	
23	.9709	1.0269	.8962	.8589		.9492	
24	1.1203	.9335	.9694	.8962	.9149	.9709	.9431
Max	1.2323	1.1888	.9709	1.1203	.9149	1.0425	1.1203
Min	.4344	.3189	.5415	.6348	.9149	.499	.5847
Avg	.9467	.9081	.7975	.7927	.9149	.8085	.8709

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAMPUR S/DN.[809] BU 4809

Substation No/ Name :- 074058 / 33/11 KV SANGRAMPUR S/STN

Feeder No / Name : 204 / 11KV SANGRAMPUR

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6348	.7095	.5601	.5975			.6468
2	.6219	.6722	.5415	.5601			.6024
3	.5975	.6348	.5121	.5601			.5877
4	.5975	.5975	.499	.5415			.6036
5	.5975	.5228		.5601			.6161
6	.5975	.4854	.5093	.4668			
7	.4108	.4294	.3961	.3734			.4525
8	.3734	.3921	.3292	.3921			.4075
9	.3734	.3361	.3547	.3547			.415
10	.4108	.3921	.3258	.3921			.3801
11	.3734		.3326	.4108		.4207	.3658
12	.5601	.4887	.4108	.4668		.462	.5228
13	.5975	.4854	.4481	.5228		.4298	.5228
14	.6535	.5138	.4854	.5228		.6036	.5601
15	.6722	.591	.5041	.5601		.5373	.5601
16	.6722	.5316	.4668	.5788		.5228	.5601
17	.6535	.4525	.4481	.5415		.499	.6584
18	.6535	.4294	.4481	.4854		.5359	.5975
19	.5975	.5914	.4481	.5228		.5487	.5975
20	.5788	.6401	.5601	.5228		.6219	.6722
21	.6535	.6068	.5975	.5228		.6626	.6584
22	.6722	.6283	.6161	.6722		.7207	
23	.6908	.6036	.6348	.7095		.7095	
24	.6348	.6722	.5853	.6348	.6535	.6722	.6767
Max	.6908	.7095	.6348	.7095	.6535	.7207	.6767
Min	.3734	.3361	.3258	.3547	.6535	.4207	.3658
Avg	.5783	.5394	.4789	.5197	.6535	.5676	.5554

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074059 / 33/11 KV SONALA S/STN

Feeder No / Name : 201 / 11 KV SONALA GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3443	1.3443	1.3306	1.3306	1.307	1.3817	1.2936
2	1.3306	1.307	1.2936	1.2936	1.2696	1.3817	1.2936
3	1.2567	1.2136	1.2197	1.2437	1.2136	1.3676	1.2567
4	1.2567	1.2696	1.2567	1.2696	1.1763	1.3306	1.2567
5	1.2197	1.1203	1.1088	1.1949	1.1576	1.3169	1.2197
6	1.0349	1.1576	1.1458	1.1389	1.1576	1.1827	1.1458
7	.9979	1.0059	.9979	1.1827	1.1203	1.0534	1.0164
8	.9055	.9328	1.0082	1.1827	.9694	1.1088	.924
9	.924	.9511	1.0082	1.0719	.8962	1.1458	.924
10	1.0164	.9694	.924	1.086	.9511	.9145	.924
11	.9979	1.0082	.924	1.0608	1.0059	.9328	.961
12	1.0974		.9425	1.0425	1.0059	.9328	.961
13	1.1706	.961	.961		1.0059	1.2071	1.0719
14	1.2071	.961	.961	1.1157	1.1523	1.2437	1.0903
15	1.2254	1.1088	.9979	1.1576	1.134	1.2071	1.0719
16	1.134	1.2382	1.0903	1.1523	1.1157	1.134	1.0719
17	1.0974		1.1088	1.0608	1.0719	1.0608	1.0029
18	.9145	1.0974	1.1706	.9877	1.1203	.9877	.9745
19	1.134	1.2254	1.1888		1.1389	1.2197	1.1088
20		1.386	1.2254	1.3817	1.307	1.386	
21		1.475	1.3676	1.4998	1.3817	1.386	1.2936
22		1.46	1.46	1.5364	1.3817	1.4003	1.3676
23		1.4415	1.46		1.3817	1.3676	1.3676
24	1.3817	1.4377	1.423	1.4415	1.3352	1.3817	1.363
Max	1.3817	1.475	1.46	1.5364	1.3817	1.4003	1.3676
Min	.9055	.9328	.924	.9877	.8962	.9145	.924
Avg	1.1323	1.1851	1.1489	1.2110	1.1565	1.2096	1.1287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAMPUR S/DN.[809] BU 4809

Substation No/ Name :- 074059 / 33/11 KV SONALA S/STN

Feeder No / Name : 202 / 11 KV SONALA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0509		.0497	.0332	1.1401		1.2803
2	.0509		.0503	.0358	1.0526		1.2803
3	.0509		.0503	.0373	1.0395		1.3123
4	.0509		.0497	.037	1.1576		1.3123
5	.0503		.0497	.037	1.307		1.3123
6	.0503		.0497	.0381			1.2803
7							1.2803
8						.6401	1.2803
9						.8436	1.1523
10					1.2742	1.2498	1.0562
11	1.1934		1.1561		1.2125	1.2803	1.1203
12	1.1984		1.1561		1.2125		1.1561
13	1.2308	1.3923	1.1561		1.1797	1.2193	1.2037
14	1.2071	1.3923	1.1248				1.2654
15	1.2146	1.2498	1.1111			1.1873	1.2654
16	1.2308	1.2346	1.0802			1.1279	1.2346
17	.9717		1.0802			1.2193	1.2963
18		1.0936	1.0802			1.2498	1.3435
19		1.0936				1.2193	
20		.0503	.0503		.0537	.0335	.0373
21		.0497	.0503		.0537	.0343	.0373
22		.0503	.0332		.0537	.0343	.037
23		.0497	.0332			.0351	.0373
24	.0503	.0503	.0497	.0332	.0335		.0351
Max	1.2308	1.3923	1.1561	.0381	1.307	1.2803	1.3435
Min	.0503	.0497	.0332	.0332	.0335	.0335	.0351
Avg	.6144	.7006	.4979	.0359	.8285	.8124	.9833

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074059 / 33/11 KV SONALA S/STN

Feeder No / Name : 203 / 11 KV SAGODA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0503		.0503	.0537	1.2955		1.4403
2	.0503		.0497	.056	1.3108		1.5364
3	.0503		.0492	.056	1.3748		1.5364
4	.0503		.0497	.056	1.3748		1.5684
5	.0503		.0503	.0572	1.3603		1.6324
6	.0503		.0509	.0572	1.4922		1.6324
7					1.5089		1.6644
8					1.5089	.7682	1.6644
9					1.6095		1.6324
10					1.5402		1.6004
11	1.5249		1.4403				1.5729
12	1.5223	1.3245	1.4563				1.6385
13	1.643	1.3245	1.4563				1.6194
14	1.4575	1.3413	1.4232				1.6385
15	1.3603	1.4754	1.406				1.6194
16	1.2955	1.4723	1.3592				1.6194
17	1.0898		1.3123			1.6248	1.6575
18	1.1336	.9998	1.2811			1.7924	1.6095
19		.9998				1.7604	
20		.0503	.0503		.1075	1.6644	.0543
21		.0503	.0503		.1075		.0554
22		.0497	.0497		.0366		.0554
23		.0503	.0503		.0366		.0554
24	.0503	.0486	.0503	.0503	.0503		
Max	1.643	1.4754	1.4563	.0572	1.6095	1.7924	1.6644
Min	.0503	.0486	.0492	.0503	.0366	.7682	.0543
Avg	.7586	.7656	.6150	.0552	.9810	1.5220	1.3229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074059 / 33/11 KV SONALA S/STN

Feeder No / Name : 204 / 11 KV PALSODA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2652	.3605	.3315	.362		.0381	.0351
2	.2683	.3353	.3353	.3658		.0381	.0351
3	.2683	.3018	.3353	.3696		.0373	.0351
4	.3018	.2949	.3688	.3326		.0366	.0362
5	.3353	.3353	.3647	.3395		.0358	.0351
6	.3688	.3932		.3018			.0351
7	.4024	.4862	.3978	.3772			
8	.4694	.503	.4641	.4527			
9	.3688	.4694	.4641	.5281			
10	.2984	.3768	.4973	.4527			
11				.4527	.3201	.25	
12				.4424	.3201	.25	
13				.4191	.2561	.3125	
14				.285	.2561	.3437	
15				.3185	.2561	.3125	
16				.4024	.2241	.4374	
17				.4359	.2591	.4374	
18				.4359	.2591	.4374	
20		.0343	.0343		.0358	.0335	.0377
21		.0339	.0343		.0362	.0335	.0377
22		.0335	.0358		.0366	.0351	.0377
23		.0332	.0358		.0366	.0351	.0377
24	.0335	.0335	.0332	.0362	.0335	.0358	.0351
Max	.4694	.503	.4973	.5281	.3201	.4374	.0377
Min	.0335	.0332	.0332	.0362	.0335	.0335	.0351
Avg	.3073	.2683	.2666	.3742	.1792	.1744	.0361

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAMPUR S/DN.[809] BU 4809

Substation No/ Name :- 074059 / 33/11 KV SONALA S/STN

Feeder No / Name : 205 / 11 KV PINGLI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.6385	1.4918	1.3592		
2		1.7695	1.5089	1.326		
3		1.643	1.5249	1.3413		
4		1.6095	1.576	1.3413		
5		1.6766	1.5581	1.2407		
6		1.7859	1.6278	1.1603		
7		1.8023	1.6095	1.1574		
8		1.7328	1.643	1.1431		
9		1.6766	1.6766	1.1443		
10		1.5223	1.6575	1.4754		
11				1.5089	1.8747	
12				1.576	1.8747	
13					1.9997	
14					1.9509	
15				1.5089	1.768	
16					1.6766	
17					1.5623	
18				1.4251	1.3763	
20		.285	.285		.2507	.2686
21		.285	.2818		.2507	.2507
22		.3018	.2652		.2507	.2507
23		.2883	.2622			
24	1.0288	.2267	.285	.2515	.2458	
Max	1.0288	1.8023	1.6766	1.576	1.9997	.2686
Min	1.0288	.2267	.2622	.2515	.2458	.2507
Avg	1.0288	1.2163	1.1502	1.2640	1.2568	.2567

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074059 / 33/11 KV SONALA S/STN

Feeder No / Name : 206 / 11 KV WARKHED AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0335		.0339	.0358	1.4419		1.5684
2	.0335		.0335	.0373	1.4754		1.5364
3	.0335		.0332	.0373	1.4419		1.5364
4	.0335		.0335	.0377	1.4922		1.5043
5	.0335		.0339	.0377	1.4922		1.4723
6	.0335		.0339		1.4575		1.4403
7					1.5089		1.4403
8					1.5424	.6401	1.3763
9					1.5424	1.0623	1.3443
10					1.643	1.6156	1.3443
11	1.3923		1.5813			1.5851	1.6617
12	.9831	1.5089	1.5813			1.5546	1.7436
13	.7773	1.4918	1.5813			1.5242	1.7238
14	1.2125	1.4918	1.5623			1.4937	1.7166
15	1.2308	1.4918	1.5432			1.768	1.7166
16	1.2289	1.4575				1.5546	1.7166
17	1.1984		1.5123				1.757
18	1.2955	1.2967	1.4506				1.7901
19		1.2967					
20		.0339	.0335		.0366	.0335	.0362
21		.0339	.0335		.0366	.0343	.0362
22		.0335	.0335		.037	.0351	.037
23		.0339	.0332		.037	.0351	.037
24	.0335	.0335	.0339	.0332	.0324		.0351
Max	1.3923	1.5089	1.5813	.0377	1.643	1.768	1.7901
Min	.0335	.0335	.0332	.0332	.0324	.0335	.0351
Avg	.6369	.8503	.6212	.0365	1.0145	.9951	1.2422

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAMPUR S/DN.[809] BU 4809

Substation No/ Name :- 074064 / 33/11 KV PATURDA S/STN

Feeder No / Name : 201 / 11 KV DEULGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3391	.2429	.2286			.1505
2	.3467	.2429	.2286			.1505
3	.3391	.2267	.2286			.1505
4	.3467	.2267	.2286			.1505
5	.3506	.2267	.2286			.1486
6	.3467	.2267	.1677			.1505
7	.3467	.3077	.1677			.1355
8	.3506	.3239	.1677			.2172
9	.3391	.3239	.1677			.2494
10	.362	.3077	.2134			.2824
11				.2896	.3353	
12			.2286	.2934		
13			.2709	.2713		
14			.2258	.3052		
15			.2408	.3391	.3725	
16			.2408	.2774	.3725	
17			.2591	.2774	.3725	
18			.2743	.2774	.3725	
Max	.362	.3239	.2743	.3391	.3725	.2824
Min	.3391	.2267	.1677	.2713	.3353	.1355
Avg	.3467	.2656	.2216	.2914	.3651	.1786

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074064 / 33/11 KV PATURDA S/STN

Feeder No / Name : 202 / 11KV PATURDA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7682	.7602	.7682	.724	.7602	.724	.7059
2	.7186	.724	.7316	.724	.7602	.724	.7602
3	.7316	.724	.695	.724	.7316	.724	.6335
4	.7316	.6878	.6584	.6878	.6878	.6878	.6335
5	.724	.6697	.6219	.6805	.6036	.6878	.6154
6	.6516	.6335	.6036	.5731	.5304	.6697	.543
7	.5611	.5249	.5487	.4835	.5304	.5792	.4525
8	.4887	.543	.4755	.4344	.5487	.543	.5014
9	.6154	.5068	.439	.5014	.5853	.4887	.4525
10	.6516	.5792	.5121	.5068	.567	.5068	.5068
11	.6584	.5973	.547	.591		.4344	.5373
12	.6878	.6516	.5729	.5973		.5611	.5731
13	.7783	.7316	.5973	.6584		.6089	
14	.7602	.724	.6335	.6516	.724	.6878	
15	.724	.724	.6697	.6767	.724	.6878	
16	.7059	.7059	.6335	.6767	.724	.6697	
17	.6335		.5973	.6154	.6516	.591	
18	.543	.6219	.5611	.6219	.5973	.6697	
19	.6697	.7316	.5792	.7316		.7059	
20	.724	.8596	.7602	.8413	.8326	.8145	
21	.8145	.8596	.7783	.8413	.8688	.7421	
22	.724	.8413	.7783	.8507	.8507	.7783	
23	.7964	.8048	.7602		.8145	.7421	
24	.7682	.7964	.7682	.724	.7682	.8145	.724
Max	.8145	.8596	.7783	.8507	.8688	.8145	.7602
Min	.4887	.5068	.439	.4344	.5304	.4344	.4525
Avg	.6929	.6958	.6371	.6573	.6930	.6601	.5876

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAMPUR S/DN.[809] BU 4809

Substation No/ Name :- 074064 / 33/11 KV PATURDA S/STN

Feeder No / Name : 203 / 11 KV KODRI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1387		
2				.1357		
3				.1357		
4				.1357		
5				.1387		
6				.1387		
8			.0743			
9			.1355	.208		
10			.1337	.2204		
11	.2543	.3401				
12	.2543	.3077				.0987
13	.2429	.3201				.156
14	.2429	.3201				.1526
15	.2429	.3201			.017	.1526
16	.2753					
17	.2429				.0903	
18	.2429	.1372			.0914	.0693
19					.1014	
20					.0705	
21					.0724	
24				.1387		
Max	.2753	.3401	.1355	.2204	.1014	.156
Min	.2429	.1372	.0743	.1357	.017	.0693
Avg	.2498	.2909	.1145	.1545	.0738	.1258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAMPUR S/DN.[809] BU 4809

Substation No/ Name :- 074064 / 33/11 KV PATURDA S/STN

Feeder No / Name : 204 / 11 KV KAVTHAL AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1696	.1619	.2201
2				.1696	.1619	
3				.1696	.1619	
4				.1734	.1943	
5				.1696	.2105	
6				.1734	.2267	
7			.0312	.1696	.3077	
8			.1054	.2012	.3077	.0457
9			.1656	.2543	.3077	.0452
10			.1614	.3018	.2641	.0753
11	.2374	.3239	.1448			.1783
12	.2713	.2753	.176			
13	.2753	.2743				.2713
14	.2591	.2743				.2883
15	.2267	.2743				.3121
16	.2267	.2743				.3294
17	.2267					.3467
18	.2105					.3391
24				.1734		
Max	.2753	.3239	.176	.3018	.3077	.3467
Min	.2105	.2743	.0312	.1696	.1619	.0452
Avg	.2417	.2827	.1307	.1932	.2304	.2229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074064 / 33/11 KV PATURDA S/STN

Feeder No / Name : 205 / 11KV KAWTHAL GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5373	.5611	.5544	.5175	.5194	.6154	.5175
2	.5487	.5611	.5544	.5175	.5249	.5792	
3	.5373	.543	.5544	.5175	.5249	.5792	.4805
4	.5068	.5068	.5544	.5175	.5194	.5792	.4805
5	.5121	.4887	.5544	.5304	.543	.543	.499
6	.4887	.4344	.5729	.5121	.5373	.5973	.462
7	.4938	.5249	.5175	.4755	.4755	.4525	.4251
8	.4938	.4706	.4805	.3696	.4755	.4525	.4066
9	.4656	.4344	.5175	.3881	.4755	.4887	.3511
10	.5373	.5068	.3511	.3511	.4755	.4163	.3142
11	.5068	.5249	.4251	.4251	.4163	.4525	.3142
12	.5068	.4344		.4435		.4525	
13	.543	.4572		.4477		.4755	.4706
14	.543	.4572		.4755	.5249	.4805	.4887
15	.543	.4755	.5359	.5068	.5249	.499	.4706
16	.543	.4755	.5729	.4887	.543	.4805	.4706
17	.5249		.5729	.4706	.4887	.439	.4477
18	.4887	.4805	.5359	.4525	.4706	.4207	.4298
19	.543	.5359	.6099	.5068		.5914	.5316
20	.6335	.6468	.6767	.5792	.7059	.6767	.6154
21	.543	.6838	.6584	.6516	.6516	.6401	.6767
22	.5973	.6283	.5853	.6036	.6697	.6219	.6036
23	.5792	.5729	.5544		.5973	.5544	.5304
24	.5487	.5611	.5544	.5359	.5249	.6154	.5359
Max	.6335	.6838	.6767	.6516	.7059	.6767	.6767
Min	.4656	.4344	.3511	.3511	.4163	.4163	.3142
Avg	.5319	.5203	.5473	.4906	.5328	.5293	.4783

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074037 / 33/11 KV SHEGAON R & M
S/Stn

Feeder No / Name : 201 / 11KV TOWN I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2696	1.2696	1.3443	1.2323	1.2323	1.3817	1.1576
2	1.2323	1.2696	1.307	1.2323	1.2323	1.307	1.1576
3	1.1949	1.2696	1.2696	1.2323	1.2323	1.2696	1.1576
4	1.1949	1.2323	1.2323	1.2323	1.2323	1.2323	1.1203
5	1.1949	1.2323	1.1203	1.2323	1.2323	1.1203	1.0829
6	1.1203	1.0456	1.0456	.9709	1.0456	1.0456	1.0082
7		1.0456	.9335	.8962	.9709	.9709	.9335
8	.9709	.9709		.7468	.8962	.8962	.9335
9	1.0082	.9709	.8215	.8589	.9709	.9335	.8962
10	1.0456	1.0456	.8215	1.0082	1.0082	1.0082	.9709
11	1.1203	1.0829	.8962	1.0082	1.0456	1.0082	.9709
12	1.1949	1.1203	.8962	1.0829		1.1576	1.0456
13	1.2696	1.2323	1.0456	1.307	1.1949	1.0829	1.1576
14	1.3817	1.307	1.1203	1.307	1.3443	1.2323	1.1949
15	1.4563	1.4563	1.1949	1.3817	1.3817	1.307	1.1949
16	1.4563		1.1949	1.3817	1.3817	1.3443	1.2696
17	1.3817		1.1203	1.3817		1.307	1.1949
18	1.2696	1.3443	1.0456	1.2696	1.2323	1.2323	1.1949
19	1.2696	1.3443	1.1949	1.2696		1.307	1.2323
20	1.2696	1.3443	1.2696	1.3443	1.3443	1.3443	1.2696
21	1.3443	1.419	1.1949	1.4937	1.3443	1.3443	1.3443
22	1.419	1.4563	1.3443	1.419	1.419	1.3817	1.3817
23	1.4937	1.419	1.3443	1.419	1.419	1.307	1.419
24	1.4937	1.419	1.3443	1.3443	1.419	1.419	1.3443
Max	1.4937	1.4563	1.3443	1.4937	1.419	1.419	1.419
Min	.9709	.9709	.8215	.7468	.8962	.8962	.8962
Avg	1.2631	1.2408	1.1349	1.2105	1.2181	1.2058	1.1514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074037 / 33/11 KV SHEGAON R & M
S/Stn

Feeder No / Name : 202 / 11KV TOWN II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1949	1.1949	1.2323	1.0456	1.1203	1.1949	1.1203
2	1.1576	1.1576	1.1949	1.0456	1.1203	1.1203	1.0829
3	1.1576	1.1576	1.1576	1.0456	1.1203	1.0829	1.0829
4	1.1576	1.1576	1.0829	1.0456	1.1203	1.0456	1.0456
5	1.1203	1.1576	.9709	1.0456	1.1203	.9335	.9709
6	.8962	.8215	.8215	.8215	.8962	.8589	.7842
7	.7468	.7468	.7468	.7468	.7468	.7468	.7468
8	.7468	.7468			.7468	.6722	.6722
9	.7468	.7468	.5601	.5975	.6722	.6348	.6348
10	.7468	.7095	.5975	.6348	.6722	.6348	.5601
11	.7842	.7842	.7095	.7468	.7468	.6348	.6722
12	.8589	.8589	.7095	.7468	.8215	.7468	.7468
13	.9709	.9709	.6348	.8589	.8962	.7842	.8215
14	1.0456	1.0082	.8215	.9335	1.0082	.9335	.8215
15	1.1203	1.0456	.8962	1.0082	1.1203	1.0082	.8962
16	1.1949		.9335	1.0829	1.0829	1.0082	.8962
17	1.1203		.8962	.9335		1.0082	.8962
18	.9335	1.1203	.7468	.9335	1.1203	.9335	.7468
19	.9709	.9709	.8215	.8962	1.0456	.9709	.9335
20	1.0456	1.1203	.8962	1.1949	1.0456	1.1203	1.0082
21	1.0456	1.1949	.8962	1.1203	1.0456	1.1949	1.0082
22	1.1203	1.1949	1.0456	1.1949	1.1949	1.1203	1.0082
23	1.2696	1.2696	1.1203	1.3443	1.2323	1.1949	1.1949
24	1.2696	1.3443	1.2696	1.1203	1.1576	1.2323	1.2323
Max	1.2696	1.3443	1.2696	1.3443	1.2323	1.2323	1.2323
Min	.7468	.7095	.5601	.5975	.6722	.6348	.5601
Avg	1.0176	1.0218	.9027	.9628	.9936	.9507	.8993

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074037 / 33/11 KV SHEGAON R & M

S/Stn

Feeder No / Name : 203 / 11 KV ALASNA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0663	.0332	.0166	.0166	.0166	.0166	.0332
2	.0663	.0332	.0166	.0166	.0166	.0166	.0332
3	.0663	.0663	.0166	.0166	.0166	.0166	.0332
4	.0663	.0663	.0166	.0166	.0166	.0166	.0332
5	.0663	.0663	.0166	.0166	.0166	.0166	.0663
6	.0663	.0663	.0166	.0166	.0166	.0166	.0663
7	.0663	.0663					.0663
8	.0995	.0663					.0995
9	.0663	.0663					.0663
10	.0332	.0663					.0663
11			.0663	.0995	.0663	.0663	
12			.0663	.0663		.0995	
13			.0995	.0663		.0663	
14			.0663	.0663	.0332	.0663	
15			.0663	.0663	.0332	.0332	
16			.0663	.0663	.0663	.0663	
17			.0663	.0663		.0663	
18			.0663	.0663	.0663	.0663	
20		.0166	.0166	.0166	.0166	.0166	.0332
21	.0187	.0187	.0166	.0166	.0166	.0166	.0332
22	.0166	.0166	.0166	.0166	.0166	.0166	.0332
23	.0166	.0332	.0166	.0166	.0166	.0166	.0373
24	.0166	.0166	.0166	.0166	.0166	.0166	.0332
Max	.0995	.0663	.0995	.0995	.0663	.0995	.0995
Min	.0166	.0166	.0166	.0166	.0166	.0166	.0332
Avg	.0523	.0466	.0393	.0393	.0280	.0375	.0489

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074037 / 33/11 KV SHEGAON R & M
S/StnFeeder No / Name : 204 / 11KV INDUSTRIAL
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3647	.4481	.3315	.431	.4854	.3647	.3978
2	.3647	.3978	.3978	.431	.4854	.3315	.3978
3	.3647	.3978	.3978	.3978	.431	.2984	.3978
4	.3647	.3978	.3647	.3978	.431	.2984	.3647
5	.3315	.3647	.3978	.3978	.3978	.2984	.3647
6	.3315	.3647	.3647	.3978	.3978	.2652	.3647
7	.1989	.2321	.2984	.2321	.1658	.1326	.2984
8	.1989	.2652		.1989	.1989	.1989	.2984
9	.3315	.431	.3315	.2321	.2321	.2652	.3315
10	.2984	.3978	.2652	.2987	.2321	.3647	.3978
11	.3647	.3978	.3315	.3647	.1989	.3647	.4973
12	.3647	.3647	.3978	.3315	.1658	.3978	.4973
13	.2984	.431	.3647	.2652	.1326	.3978	.3647
14	.2984	.2984	.2984	.2652	.1326	.2652	.3315
15	.2984	.2984	.431	.3315	.2321	.3978	.3647
16	.3978		.5304	.3647	.2321	.2321	.431
17	.4481		.4641	.431		.1989	.4973
18	.3315	.2984	.5304	.4854	.2321	.4641	.4854
19	.3647	.3315	.431	.3315	.0995	.4973	.3978
20	.3315	.2652	.431	.4641	.1989	.4973	.3647
21	.3315	.2984	.2984	.2321	.1658	.2984	.2652
22	.431	.2652	.2652	.2652	.1658	.3315	.3315
23	.3978	.2984	.2984	.3315	.1989	.3647	.3734
24	.3647		.1989	.3647	.3361	.1658	.2984
Max	.4481	.4481	.5304	.4854	.4854	.4973	.4973
Min	.1989	.2321	.1989	.1989	.0995	.1326	.2652
Avg	.3405	.3450	.3661	.3435	.2586	.3205	.3797

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074037 / 33/11 KV SHEGAON R & M
S/Stn

Feeder No / Name : 205 / ALASNA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4481	.4481	.4108	.9709	.4108	.4854	.4481
2	.4481	.4481	.4108	.4108	.4108	.4854	.4481
3	.4108	.4481	.4108	.4108	.4108	.5601	.4481
4	.4108	.4481	.3734	.4108	.4108	.5601	
5	.4108	.4481	.4108	.4108	.4108	.4854	.4481
6	.4108	.4108	.4108	.4108	.3734	.4854	.4481
7	.2987	.3361	.3361	.3361	.3361	.2987	.3734
8	.3361	.2614		.2987	.2614	.3361	.2987
9	.3361	.3361	.2614	.2987	.3734	.2614	.3361
10	.2987	.3361	.2987	.2614	.2987	.2614	
11	.2987	.2987	.2614	.3361	.2987	.2987	.0747
12	.3361	.2987	.3361	.3734		.2987	.1494
13	.3734	.4481	.2987	.3361	.0373	.2987	.3361
14	.4108	.4108	.2241	.4108	.3361	.3361	.3734
15	.4108	.3361	.3361	.4108	.4108	.3361	.2987
16	.4108		.3734	.4108	.4108	.2987	.4108
17	.3734		.3361	.3734		.2987	.3734
18	.3734	.0373	.3734	.3734	.3734	.3361	.3734
19	.4108	.3361	.3361	.3361	.4108	.3734	.3734
20	.4481	.4481	.4854	.5228	.4481	.4481	.5228
21	.4854	.5228	.4481	.4854	.5228	.5228	.5228
22	.5601	.5228	.5228	.4481	.5228	.5601	.5228
23	.4854	.5228	.4481	.4854	.4481	.5228	.4854
24	.5228	.4481	.4481	.4481	.4481	.5228	.4481
Max	.5601	.5228	.5228	.9709	.5228	.5601	.5228
Min	.2987	.0373	.2241	.2614	.0373	.2614	.0747
Avg	.4045	.3887	.3718	.4154	.3802	.4030	.3870

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074037 / 33/11 KV SHEGAON R & M
S/Stn

Feeder No / Name : 206 / 11 KV ENGG COLLEGE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3443	1.3203	1.2323	1.2696	1.2449	1.2696
2		1.3443	1.3203	1.2323	1.2696	1.2071	
3		1.307	1.2826	1.1576	1.2696	1.1694	1.2323
4		1.307	1.2071	1.1576	1.2696	1.1694	1.2323
5		1.307	1.1317	1.1576	1.2696	1.0562	1.1203
6		1.0456	1.0562	.8962	1.0456	.9431	1.0082
7		.8962	.9054	.7468	.7468	.7545	.8589
8		.7468	.9054		.7468	.7545	.6722
9	.9431	.8676	.8215	.7842	.7545	.8589	.7468
10	.9808	.9808	.8215	.7842	.8676	.7842	.7468
11	.9808	1.0185	.8215	.8215	.7842	.7842	.7468
12	1.0185	1.0562	.8962	.8589	.8676		.8215
13	1.1694	1.1317	.8962	1.0082	1.0185	.8589	.8962
14	1.3203	1.3203	.8215	1.0829	1.0562	.9335	.8962
15	1.3957	1.3203		1.1576	1.1317	1.1576	1.1203
16	1.358		1.1694	1.2323	1.1694	1.1576	1.0456
17	1.3817		1.1317	1.2323		1.1576	1.0456
18	1.2826		.9808	1.0829	1.2071	1.0829	1.0456
19	1.1949	1.1949	1.0456	1.1203	1.0456	1.1317	1.0082
20	1.2696	1.1949	1.1203	1.1949	1.1949	1.2071	1.1949
21	1.2696	1.2071	1.1203	1.3443	1.2696	1.2071	1.1949
22	1.4937	1.4335	1.2323	1.3443	1.3957	1.2696	1.2323
23	1.5684	1.5089	1.2696	1.4937	1.358	1.307	1.307
24		1.419	1.4335	1.2696	1.3443	1.2826	1.307
Max	1.5684	1.5089	1.4335	1.4937	1.3957	1.307	1.307
Min	.9431	.7468	.8215	.7468	.7468	.7545	.6722
Avg	1.2418	1.1882	1.0744	1.1040	1.1023	1.0643	1.0326

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074037 / 33/11 KV SHEGAON R & M
S/StnFeeder No / Name : 400 / 33/0.4Kv Station Xmer
Feeder KV- 33 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.2241	.2241	.2241	.2241	.2241	.2241
2	.2241	.2241	.2241	.2241	.2241	.2241	.2241
3	.2241	.2241	.2241	.2241	.2241	.2241	.2241
4	.2241	.2241	.2241	.2241	.2241	.1989	.2241
5	.2241	.2241	.2241	.2241	.2241	.2241	.2241
6	.2241	.2241	.2241	.2241	.2241	.2241	.2241
7	.2241	.112	.112	.112	.112	.2241	.112
8	.112			.112	.112	.112	.2241
9	.112	.2241	.2241	.2241	.2241	.112	.112
10	.2241	.2241	.112	.112	.2241	.112	.112
11	.2241	.2241	.2241	.2241	.2241	.2241	.112
12	.2241	.2241	.2241	.2241	.2241	.2241	.3361
13	.2241	.2241	.2241	.2241	.2241	.2241	.3361
14	.2241	.2241	.112	.3361	.2241	.2241	.2241
15	.2241	.2241	.112	.3361	.2241	.2241	.2241
16	.2241		.2241	.3361	.2241	.2241	.2241
17	.2241		.112	.3361		.2241	.2241
18	.2241	.2241	.2241	.2241	.112	.2241	.2241
19		.2241	.112			.2241	.2241
20	.2241	.2241	.2241		.2241	.2241	.2241
21	.2241	.2241	.2241	.2241	.2241	.2263	.2241
22	.2241	.2241	.2241	.2241	.2241	.2241	.2241
23	.2241	.2241	.2241	.2241	.112	.2241	.2241
24	.2241	.2241	.2241	.2241	.2241	.2241	.2241
Max	.3361	.2241	.2241	.3361	.2241	.2263	.3361
Min	.112	.112	.112	.112	.112	.112	.112
Avg	.2192	.2188	.1949	.2292	.2037	.2091	.2148

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074052 / 33/11 KV SHEGAON ANAND-SAGAR
S

Feeder No / Name : 200 / STATION T/F

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0293	.0309	.0328	.0271	.0293	.0305	.0328
2	.0293	.0309	.0328	.0271	.0293	.0305	.0328
3	.0293	.0309	.0328	.0271	.0293	.0305	.0328
4	.0293	.0309	.0328	.0271	.0293	.0305	.0328
5	.0293	.0309	.0328	.0271	.0293	.0305	.0328
6	.0293	.0309	.0328	.0271	.0293	.0305	.0328
7	.0293	.0309	.0328	.0271	.0293	.0305	.0328
8	.0293	.0305	.0328	.0271	.0293	.0305	.0328
9	.0293	.0305	.0328	.0271	.0293	.0305	.0328
10	.0293	.0305	.0293	.0305	.0293	.0293	.0305
11	.0328	.0271	.0293	.0305	.0328	.0293	.0305
12	.0328	.0271	.0293	.0305	.0328	.0293	.0305
13	.0328	.0271	.0293	.0305	.0293	.0293	.0305
14	.0328	.0271	.0293	.0305	.0293	.0293	.0305
15	.0328	.0271	.0293	.0305	.0328	.0293	.0305
16	.0328		.0293	.0305	.0328	.0293	.0305
17	.0328		.0293		.0328	.0293	.0305
18	.0328	.0328	.0293	.0293	.0328	.0293	.0293
19	.0305	.0328	.0271	.0293	.0305	.0293	.0293
20	.0305		.0271	.0293	.0305	.0328	.0293
21	.0762	.0328	.0271	.0293	.0305	.0328	.0293
22	.0305	.0328	.0271	.0293	.0305	.0328	.0293
23	.0305	.0328	.0271	.0293	.0305	.0328	.0293
24	.0293	.0309	.0328	.0271	.0293	.0305	.0328
Max	.0762	.0328	.0328	.0305	.0328	.0328	.0328
Min	.0293	.0271	.0271	.0271	.0293	.0293	.0293
Avg	.0326	.0304	.0303	.0287	.0304	.0304	.0312

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074052 / 33/11 KV SHEGAON ANAND-SAGAR

S

Feeder No / Name : 201 / 11 KV ANAND SAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2012	1.2437	1.307	1.1203	1.1643	1.134	1.1576
2	1.1643	1.1888	1.2696	1.1203	1.1273	1.0974	1.1203
3	1.1088	1.1706	1.2323	1.1203	1.1088	1.0974	1.1203
4	1.0719	1.0608	1.1576	1.0829	1.0719	1.0608	1.0829
5	1.0349	1.0059	1.1203	1.0456	1.0349	1.0059	1.0456
6	.961	.9145	1.0082	.8962	.9425	.9145	.8962
7	.9425	.9694	.9335	.9335	.924	.8779	.8402
8	.9795	.9145	.7468	.8962	.9055	.8413	.7468
9	.9979	.9511	.8402	.9335	.9055	.7865	.7842
10	.961	.9511	.924	.9511	.961	.9055	.8779
11	1.0082	1.0269	.924	.9145	.8402	.9055	.7865
12	1.0456	.9709	.9425	.9328	.8402	.8871	.8779
13	1.0456	.9709	1.0164	.9511	.961	.924	.8596
14	1.1576	1.1949	1.0164	.9877	1.0349	.9425	.9145
15	1.2323	1.2136	1.0719	1.0242	1.0829	1.0164	.9511
16	1.2696		1.0349	1.0242	1.0456	1.0349	.9511
17	1.0082		1.0349	.9877	1.0082	1.0164	.9145
18	.9709	1.1203	.924	.8316	.9335	.924	.8871
19	.9877	1.1203	.9335	.924	.9145	.961	.8871
20	1.0608	1.1203	1.0269	1.0349		.9335	.9979
21	1.0974	1.1576	1.0269	1.1088	.7499	1.0269	1.0164
22	1.2437	1.2696	1.1203	1.1643	1.1706	1.0829	1.1458
23	1.3169	1.419	1.1576	1.2752	1.2254	1.1949	1.2197
24	1.2752	1.2803	1.3443	1.1949	1.2012	1.1523	1.1949
Max	1.3169	1.419	1.3443	1.2752	1.2254	1.1949	1.2197
Min	.9425	.9145	.7468	.8316	.7499	.7865	.7468
Avg	1.0893	1.1016	1.0464	1.0190	1.0067	.9885	.9698

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074052 / 33/11 KV SHEGAON ANAND-SAGAR

S

Feeder No / Name : 202 / 11KV Nagzari AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2429	.1928		.0747	.0663		.2785
2	.2105	.2103		.0747	.0829		.2622
3	.2267	.2103		.0747	.0663		.2458
4	.2105	.2279		.0747	.0829		.2713
5	.2105	.2454		.0747	.0995		.2713
6	.421	.3561					.3277
7	.3725	.4359					.4096
8	.421	.3521					.4588
9	.3401	.3121					.4096
10	.3725	.298					.3688
11			.3563	.5365	.5243	.4696	
12			.4534	.4862	.4409	.4858	
13			.3887		.4049		
14			.3401	.208	.3725	.4049	
15			.3887		.3932	.4696	
16			.3887	.2427	.4096	.4372	
17	.0819		.3887	.4858	.4588	.4534	.1109
18	.0819		.3239	.4858	.426	.4534	.0829
19	.2033			.4049			.0995
20			.0747	.0995		.0819	.0995
21			.0747	.0829		.0819	.0829
22	.0739	.0655	.0747	.2486		.0655	.0995
23	.0739	.0678	.0747	.0995		.0655	.0995
24	.0995	.0739	.0655		.0995		.0655
Max	.421	.4359	.4534	.5365	.5243	.4858	.4588
Min	.0739	.0655	.0655	.0747	.0663	.0655	.0655
Avg	.2277	.2345	.2610	.2346	.2805	.3153	.2247

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074052 / 33/11 KV SHEGAON ANAND-SAGAR

S

Feeder No / Name : 203 / 11 KV GM MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8296	1.7558	1.8298	1.6617	1.7372	1.6461	1.6804
2	1.7556	1.7375	1.8298	1.643	1.7002	1.6095	1.6804
3	1.7002	1.701	1.7924	1.643	1.6632	1.5912	1.643
4	1.6632	1.6095	1.7177	1.587	1.6263	1.5546	1.6057
5	1.6263	1.5546	1.6804	1.5497	1.5708	1.5181	1.6057
6	1.5708	1.4632	1.531	1.3817	1.4969	1.4632	1.531
7	1.3676	1.4266	1.3817	1.2136	1.386	1.2803	1.3817
8	1.386	1.2986	1.3443	1.1949	1.2936	1.0974	1.363
9	1.2752	1.2803		1.1389	1.2567	1.0974	1.307
10	1.4784	1.4632	1.4784	1.2071	1.423	1.2567	1.4083
11	1.4937	1.587	1.4969	1.3717	1.4563		1.4632
12	1.6057	1.6244	1.4045	1.4449	1.4937	.1848	1.4815
13	1.7924	1.6804	1.4969	1.4632	1.5893	.5914	1.5729
14	1.8484	1.8298	1.5154	1.6461	1.6448	1.423	1.5364
15	1.7924	1.8484	1.5524	1.6644	1.6057	1.5524	1.5546
16	1.7177		1.5154	1.6644	1.5684	1.6632	1.5912
17	1.643		1.386	1.4632	1.5684	1.5524	1.5364
18	1.4937	1.531	1.3121	1.4045	1.531	1.4969	1.4969
19	1.4815	1.5684	1.4937	1.4415	1.6095	1.5339	1.5708
20	1.6827	1.6804	1.6057	1.6448	1.5729	1.643	1.7741
21	1.7193	1.9791	1.6244	1.7741	1.6644	1.6057	1.848
22	1.7741	1.9418	1.6804	1.7741	1.7375	1.7177	1.848
23	1.829	1.9044	1.643	1.8111	1.7558	1.7551	1.8665
24	1.848	1.7741	1.8671	1.6057	1.7741	1.6827	1.7177
Max	1.8484	1.9791	1.8671	1.8111	1.7741	1.7551	1.8665
Min	1.2752	1.2803	1.3121	1.1389	1.2567	.1848	1.307
Avg	1.6406	1.6473	1.5730	1.5164	1.5719	1.4138	1.5860

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074052 / 33/11 KV SHEGAON ANAND-SAGAR

S

Feeder No / Name : 204 / 11KV CHINCHOLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0995	.1848	.0655	.2134	.2429		.1966
2	.0829	.2033	.0655	.2214	.2429		.1638
3	.0829	.1848	.0819	.2187	.2591		.1638
4	.116	.1848	.0655	.216	.2429		.1475
5	.0995	.1663	.0655	.2315	.2591		.1311
6	.1326	.1663	.0655	.4012	.421		.168
7	.1478	.1663	.0819	.4321	.4534		.1638
8	.1492	.1478	.0819	.4012	.4696	.4024	.1311
9			.0819	.3241	.4534	.4527	
10			.081	.4527	.421	.2753	
11	.5735	.3953					.5365
12	.4096	.3163					.5365
13	.3605	.3005	.1492	.1109	.0995	.2753	.4862
14	.3768	.3163	.2915	.1109	.0995	.2652	.503
15		.3086	.2652	.1109	.0983	.2915	.5197
16	.3932		.1326	.1109	.0983	.2591	.503
17	.4096		.1326	.1663	.1638	.2753	.4359
18	.3932						.3725
19		.0492					
20		.0328	.1494	.116		.1311	
21	.2033	.0351	.1494	.116	.0924	.1475	.1326
22	.2195	.0187	.1307	.116	.1109	.1475	.1326
23	.1848	.0164	.1307	.116			.116
24	.0995	.1848	.0164	.1307	.0995		.1966
Max	.5735	.3953	.2915	.4527	.4696	.4527	.5365
Min	.0829	.0164	.0164	.1109	.0924	.1311	.116
Avg	.2386	.1778	.1142	.2158	.2404	.2657	.2868

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074052 / 33/11 KV SHEGAON ANAND-SAGAR
S

Feeder No / Name : 205 / 11KV NAGZRI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2033	.2054	.2054	.2054	.1848	.2427	.2241
2	.2218	.2241	.1867	.2054	.1848	.2427	.2054
3	.2033	.2054	.1494	.2054	.2033	.2427	.2054
4	.1848	.2241	.168	.2054	.1848	.2427	.1867
5	.2033	.2054	.1867	.2054	.1848	.2241	.1867
6	.1848	.1867	.168		.1848	.2241	.1638
7	.1663	.1494	.1494		.1663	.168	.168
8	.1663	.1494	.1307		.1478	.1494	.168
9	.1478	.1494	.0934		.1663	.1494	.1494
10	.1848	.1494	.0924		.1478	.1294	.168
11	.2054	.168	.1109	.168	.168	.1478	.168
12	.2054	.1867	.1109	.2241	.168	.1478	.2054
13	.2241	.2054	.2218	.2427	.1848	.1663	.1867
14	.2241	.2054	.2033	.2241	.2033	.2033	.168
15	.2054	.2054	.2218	.2241	.2054	.1848	.168
16	.2054		.2033	.2241	.1867	.2033	.2054
17	.2241		.2033	.2241	.2054	.2033	.1867
18	.2241	.1867	.1663	.2218	.1867	.1848	.1663
19	.2241	.2241	.2427	.2218	.2241	.2402	.1848
20	.2987	.2614	.2427	.2957		.2987	.2957
21	.2801	.2427	.2614	.2587	.2614	.2614	.2587
22	.2427	.2427	.2427	.2402	.2987	.2427	.2218
23	.2427	.2054	.2241	.2033	.2427	.2241	.2033
24	.2033	.2241	.2054	.2054	.2033	.2427	.2241
Max	.2987	.2614	.2614	.2957	.2987	.2987	.2957
Min	.1478	.1494	.0924	.168	.1478	.1294	.1494
Avg	.2115	.2003	.1829	.2213	.1954	.2069	.1945

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074077 / 33/11 KV SHEGAON RAPDRP
S/STN.Feeder No / Name : 200 / STSTION T/F
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4752	.5068	.4692	.4424	.4706	.4458	.4588
2	.4862	.5068	.4692	.4424	.4706	.4458	.4588
3	.4531	.4887	.4692	.4424	.4525	.4458	.4588
4	.4694	.4887	.4692	.4527	.4706	.4458	.4694
5	.4801	.5068	.4692	.4527	.4706	.4458	.4694
6		.4706			.4706	.4458	
14							.1341
19			.0655		.4115	.4752	.463
20	.5068		.4938	.4706	.4458	.4752	.4973
21	.5068	.4692	.4588	.4706	.4458	.4696	.4973
22	.4887	.4692	.4424	.4706	.4458	.4534	.4801
23	.4887	.4692	.4527	.4525	.4458	.4534	.4801
24	.4862	.4887	.4879	.4424	.4525	.4458	.4862
Max	.5068	.5068	.4938	.4706	.4706	.4752	.4973
Min	.4531	.4692	.0655	.4424	.4115	.4458	.1341
Avg	.4841	.4865	.4316	.4539	.4544	.4540	.4461

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074077 / 33/11 KV SHEGAON RAPDRP
S/STN.

Feeder No / Name : 201 / 11KV TOWN RLY GATE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.924	.882	.9149	.8962	.7842	.8775
2	.8962	.924	.8632	.8402	.8962	.7842	.8589
3	.8962	.8871	.8257	.8402	.8962	.7842	.8402
4	.8962	.8871	.8445	.7842	.8589	.7842	.823
5	.8402	.8501	.7882	.7468	.8589	.7468	.8029
6	.8029	.7762	.6944	.6722	.7468	.7095	.7282
7	.7282	.5544	.6381	.6722	.6539	.6401	.6161
8	.7655	.695	.6005	.6756	.6838		.6535
9	.6756	.7319	.6653	.6944	.695	.6908	.7023
10	.8069	.8215	.7865	.7694	.695	.7095	.6468
11	.8445	.8257	.7316	.7694	.7682	.6908	.7499
12	.7882	.8632	.7499	.7694	.7682	.6348	.7133
13	.8471	.9195	.7499	.7319	.7682		.7167
14	.8632	.9758	.8413	.8069	.7762	.7865	.7468
15	.9946	.9571	.8962	.9571	.8048	.695	.7499
16	.9758		.961	.7882	.8048	.7842	.8326
17	.8869		.7842	.815	.8048	.8402	.7762
18	.724	.6193	.7282	.6268	.6838	.7655	.6283
19	.823	.7694	.7842	.7682	.6653	.8589	.6099
20	.823	.7882	.8775	.8413	.5914	.7842	.7762
21	.8501	.9195	.8402	.823	.7392	.8215	.8131
22	.924	.9195	.8962	.924	.7842	.8413	.8686
23	.9979	.9195	.9149	.9425	.7577	.8962	.9055
24	.9709	.9425	.9008	.9149	.9055	.7842	.8775
Max	.9979	.9758	.961	.9571	.9055	.8962	.9055
Min	.6756	.5544	.6005	.6268	.5914	.6348	.6099
Avg	.8557	.8396	.8019	.7954	.7710	.7644	.7631

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074077 / 33/11 KV SHEGAON RAPDRP
S/STN.

Feeder No / Name : 202 / LOHARA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.419	1.3676	1.3136	.9149	1.3121	1.1949	1.307
2	1.3535	1.3676	1.3136	1.2803	1.3306	1.1949	1.2696
3	1.3817	1.3306	1.2949	1.2803	1.3306	1.1949	1.2437
4	1.3817	1.3306	1.2761	1.2696	1.2752	1.1576	1.2437
5	1.307	1.2936	1.2761	1.2136	1.2567	1.1576	1.2803
6	1.1763	1.2197	1.201	1.0829	1.2197	1.1389	1.2308
7	1.1016	1.0719	1.126	1.0642	1.1041	1.1576	1.0829
8	.8775	.9955	1.126	1.0321	1.0136		1.1016
9	1.126	1.0608		1.0884	1.0242	.6036	.9671
10	1.1072	1.0829	.9328	1.0697	1.0974	.8779	.9492
11	1.201	1.0884	.9877	1.126	1.1157	.8775	.9694
12	1.3136	1.126	1.0242	1.126	1.1888	1.0608	1.0608
13	1.3699	1.201	1.1888	.9195	1.2803	1.1157	1.2254
14	1.4075	1.3136	1.1888	1.0697	1.3491	1.2308	1.2254
15	1.4825	1.2949	1.1888		1.3535	1.2883	1.1523
16	1.4638		1.1706	1.2198	1.3535	1.2437	1.1946
17	1.2178		.4024	1.2071	1.2254	1.2323	.9979
18	1.1393	.32	1.1888	1.1946	1.3306	1.2883	1.0719
19	1.2851	.4879	1.3443	1.3121	1.2012	1.3817	1.2197
20	1.5893	.5067	1.5546	1.6095	1.5893	1.531	1.5524
21	1.6057	1.7828	1.5546	1.6057	1.5524		1.4784
22	1.5339	.5255	1.4632	1.5154	1.5684	1.4449	1.386
23	1.4784	1.4825	.8962	1.4415	1.4784	1.3717	1.423
24	1.419	1.4045	1.3699	1.3169	1.3491	1.1949	1.307
Max	1.6057	1.7828	1.5546	1.6095	1.5893	1.531	1.5524
Min	.8775	.32	.4024	.9149	1.0136	.6036	.9492
Avg	1.3224	1.1207	1.1906	1.2156	1.2875	1.1791	1.2058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074077 / 33/11 KV SHEGAON RAPDRP

S/STN.

Feeder No / Name : 203 / 11KV Janori Ag fdr

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.4012		
2					.499		
3					.4805		
4					.499		
5					.499		
6					.4805		
7					.5281		
8					.4715		
9					.4938		
10				.4504	.4755	.2987	
11	.7319	.6588		.4879		.5487	.5228
12	.6756	.6568		.4879		.5304	.9614
13	.6193	.6005		.5255		.5487	.4531
14	.563	.563		.5442		.4887	.3788
15	.5818	.563		.5067		.4755	.4321
16	.5442			.5067		.4755	.4887
17	.5847		.4572	.547		.4755	.5175
18	.4481			.5228		.4755	.5175
19			.4572				
20			.4706				
Max	.7319	.6588	.4706	.547	.5281	.5487	.9614
Min	.4481	.563	.4572	.4504	.4012	.2987	.3788
Avg	.5936	.6084	.4617	.5088	.4828	.4797	.5340

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074018 / 33 KV JALGAON JAMOD S/S

Feeder No / Name : 201 / 11 KV JALGAON AG FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715			.12		.181
2		.1543			.12		.181
3		.1715			.1372		.2715
4		.2058			.1715		.2172
5		.2743			.463		.362
6		.3429			.5144		.6878
9	.4887		.5068	.6335		.5068	
10	.0549		.4525	.543		.4525	
11	.4525		.4344	.3982		.4525	
12	.5792		.3258	.3077		.3982	
13	.543		.3077	.3258			
14	.3077		.2715	.362		.3429	
15	.2926		.3582	.3258		.3086	
16	.2865		.3582	.3258		.3944	
17			.3582				
21	.1463			.1029		.3601	
22				.1029			
23				.1372			
24		.1372			.1372		.1448
Max	.5792	.3429	.5068	.6335	.5144	.5068	.6878
Min	.0549	.1372	.2715	.1029	.12	.3086	.1448
Avg	.3502	.2082	.3748	.3241	.2376	.402	.2922

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074018 / 33 KV JALGAON JAMOD S/S

Feeder No / Name : 202 / 11 KV SOOTGIRNI EXPRESS SHEDDABLE FEEDER HAVING WEEKLY
 FEEDER Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4481	.4481	.4294	.394	.4108	.3734	.4108
2	.4481	.4668	.4294	.4024	.4108	.3734	.4108
3	.4481	.4668	.4108	.4024	.4108	.3734	.4108
4	.4481	.4668	.4294	.4024	.4481	.3734	.4108
5	.4668	.4481	.4481	.394	.4481	.3734	.3734
6	.4854	.4668	.4481	.4024	.4481	.3734	.3734
7	.5228	.4108	.4108	.4024	.4481	.3734	.3734
8	.5601	.4294		.4032	.4294		.3734
9	.3734	.4294	.4108	.3734	.3734	.3734	.3734
10	.3734	.4294	.4481	.3921	.3734	.3361	.3734
11	.3734	.4294	.4481	.4108	.3734	.3734	.3734
12	.3734	.4294	.4294	.4108	.3734	.4108	.4294
13	.3734	.4668	.4481	.4108	.3734		.3734
14	.3734	.4668	.4481	.4108	.3734	.4108	.3734
15	.2865	.4668	.4298	.4108	.3734	.4108	1.386
16	.2865	.4668	.4298	.4108	.3734	.3734	1.3817
17	.394		.394	.4108	.3734	.4481	1.3443
18	.394	.4481	.394	.4108	.3734	.4294	1.307
19	.4024	.4481	.4024	.4108	.3734	.4294	1.363
20	.4024	.4481	.4024	.4481	.3734	.4108	.4294
21	.4024	.4481		.4108	.3734	.4108	
22			.4024	.4108	.3734		
23			.4024	.4108	.3734		
24	.4668	.4481	.4294	.4024	.4108	.3734	.4108
Max	.5601	.4668	.4481	.4481	.4481	.4481	1.386
Min	.2865	.4108	.394	.3734	.3734	.3361	.3734
Avg	.4138	.4490	.4239	.4062	.3944	.3902	.6217

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074018 / 33 KV JALGAON JAMOD S/S

Feeder No / Name : 203 / 11 KV JALGAON SUNGAON AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	1.5384
Max	1.5384
Min	1.5384
Avg	1.5384

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074018 / 33 KV JALGAON JAMOD S/S

Feeder No / Name : 204 / 11 KV ASALGAON AG FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686		.0857	.2149		.0905	
2	.0686		.0857	.2149			
3	.0686		.0857	.2149			
4	.1029		.1543	.2149			
5	.12		.2229	.2507			
6	.3772		.4287	.3582			
9		.543			.6335		.4525
10		.5792			.5792		.463
11		.4525			.4525		.4287
12		.3982			.3982	.3258	.3982
13		.2715			.2715		.3258
14		.2172			.2353	.2743	.2715
15		.2172			.2401		
16		.181			.2229		
21		.1086	.1463		.1372		
22			.2195		.1715		
23					.1448		
24	.0857		.0857	.2149		.0905	
Max	.3772	.5792	.4287	.3582	.6335	.3258	.463
Min	.0686	.1086	.0857	.2149	.1372	.0905	.2715
Avg	.1274	.3298	.1683	.2405	.3170	.1953	.3900

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074018 / 33 KV JALGAON JAMOD S/S

Feeder No / Name : 205 / 11 KV JALGAON TOWN-2

GAOTHAN FEEDER

GAOTHAN F Feeder KV- 11 /
OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2696	1.1576	1.1949	.9313	1.2696	1.2567	1.2012
2	1.2136	1.1576	1.1949	.9511	1.2136	1.2382	1.2012
3	1.2136	1.1203	1.1389	.9511	1.1576	1.2382	1.1458
4	1.1763	1.1203	1.1203	.9511	1.1203	1.2012	1.1458
5	1.1203	1.0829	1.0829	.9511	1.0456	1.2012	1.1088
6	1.1203	1.0642	1.0269	.9511	1.0269	1.1088	.924
7	1.0082	1.0456	1.0082	.9145	1.0082	.961	.8871
8	.9335	.9149		.8413	.9709	.8316	.924
9	.924	.8316	.8686	.7762	.924	.8316	.961
10	.961	.8871	.8316	.7392	.8871	.7762	.9335
11	1.0164	.961	.8316	.8316	.8871	.8316	.8402
12	1.0164	1.0164	.8316	.924	.961	.8316	.8871
13	1.0534	1.0719	.924	.9795	.961		.924
14	1.1458	1.0719	.961	1.1088	1.1088	1.0269	.961
15		1.1088	.9313	1.1458	1.0456	1.0456	.961
16	1.0745	1.0349	.9511	1.1088	1.0269	1.0456	
17	1.0745		.9511	1.0719	1.0829	1.0269	
18	.9145	.961	.9511	.961		1.0269	
19	.9145	1.0719	1.0242	1.0642		1.0642	
20	.9145	1.1088	1.0608	1.1576	1.1389	1.1576	1.0829
21	1.2437	1.1088	1.182	1.4563	1.251	1.2136	
22			1.182	1.4003	1.3443		
23			1.2071	1.3443	1.2936		
24	1.2883	1.2136	1.2136	.9511	1.2883	1.2567	1.1643
Max	1.2883	1.2136	1.2136	1.4563	1.3443	1.2567	1.2012
Min	.9145	.8316	.8316	.7392	.8871	.7762	.8402
Avg	1.0760	1.0529	1.0291	1.0193	1.0915	1.0558	1.0149

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074018 / 33 KV JALGAON JAMOD S/S

Feeder No / Name : 206 / 11 KV JALGAON TOWN-1

GAOTHAN FEEDER

GAOTHAN F Feeder KV- 11 /
OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0538	1.9605	1.9791	1.829	1.9605	1.8111	1.9404
2	2.0538	1.9044	1.9044	1.829	1.9418	1.8111	1.9404
3	1.8298	1.8298	1.8671	1.7558	1.9044	1.7926	1.848
4	1.7737	1.8671	1.7924	1.6827	1.8671	1.7556	1.848
5	1.7737	1.8298	1.6804	1.6095	1.8298	1.7556	1.8111
6	1.6804	1.8298	1.643	1.5364	1.7737	1.6078	1.4784
7	1.5497	1.643	1.4937	1.4327	1.7177	1.2936	1.5154
8	1.4003	1.4937		1.3253	1.2696	1.2012	1.386
9	1.3306	1.3306	1.2567	1.2567	1.2012	1.2012	1.386
10	1.386	1.4045	1.2936	1.2936	1.2012	1.2012	1.4937
11	1.6632	1.4784	1.3306	1.4415		1.2567	
12	1.7002	1.5708	1.3491	1.5154	1.5154	1.7556	
13	1.7556	1.7556	1.4784	1.6632	1.6263		1.848
14	1.8111	1.7926	1.5154	1.7556	1.7556	1.8298	1.885
15	1.9022	1.7556	1.5364	1.7741	1.7924	1.9605	1.848
16	1.8625	1.6632	1.5364	1.7556	1.8298	1.9605	1.8298
17	1.7193		1.4685	1.7002	1.8671	1.9044	1.7924
18	1.5364	1.5708	1.4685	1.6632	2.0165	1.8671	1.7177
19	1.6461	1.7002		1.8858	1.3443	1.8298	1.6804
20	1.9022	1.9404	1.7558	2.0538	1.6804	1.9791	1.9791
21	1.9022	1.9774	1.9022	2.2032	1.7177	2.0538	
22			1.9022	2.2032	1.8298		
23				2.1472	1.7002		
24	3.7591	2.0165	1.9978	1.829	2.0165	1.848	1.9959
Max	3.7591	2.0165	1.9978	2.2032	2.0165	2.0538	1.9959
Min	1.3306	1.3306	1.2567	1.2567	1.2012	1.2012	1.386
Avg	1.8178	1.7293	1.6263	1.7142	1.7113	1.6989	1.7486

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074018 / 33 KV JALGAON JAMOD S/S

Feeder No / Name : 207 / 11 KV UMAPUR AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.3086	.2229		.2058		.362
2	.2229	.2743	.2058		.2229		.362
3	.2058	.3429	.2058		.2229		.3982
4	.2058	.3601	.2572		.2915		.3982
5	.2572	.4115	.2401		.5487		.6335
6	.2915	.6001	.2915		.6173		.8145
9		.4525		.8145	.3982	.8145	
10		.4163		.724	.4525	.9955	.4287
11		.362	.8145	.6335	.3982	.9412	.3944
12		.3258	1.086	.6335	.362	.5792	.4525
13	.6335	.3077	.8145	.905	.2534		.362
14	.724	.2715	.543	.724	.2715	.4973	.3258
15	.5373	.3258	.5014	.6878	.3258	.5316	
16	.439	.362	.5121	.6335	.2915	.5144	
21	.2926	.2172		.3086	.2229	.2572	
22				.2743	.2572		
23				.2743	.2172		
24	.2058	.3429	.2058		.2229		.362
Max	.724	.6001	1.086	.905	.6173	.9955	.8145
Min	.2058	.2172	.2058	.2743	.2058	.2572	.3258
Avg	.3546	.3551	.4539	.6012	.3212	.6414	.4412

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074018 / 33 KV JALGAON JAMOD S/S

Feeder No / Name : 208 / 11 KV MAIN INCOMER JJ-I

Feeder KV- 11 / INCOMING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	05-JUN-18	06-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7			2.4272		
8	1.9605	1.9231		1.6991	
16				2.2032	2.3339
24	2.5579	2.4646		2.4272	
Max	2.5579	2.4646	2.4272	2.4272	2.3339
Min	1.9605	1.9231	2.4272	1.6991	2.3339
Avg	2.2592	2.1939	2.4272	2.1098	2.3339

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074019 / 33 KV JAMOD S/S

Feeder No / Name : 201 / 11 KV JAMOD AG FEEDER
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6154	.6104	.9326	1.2651	.5765	.7461	.7291
2	.5281	.6104	.9326	1.3123	.5765	.7461	.7291
3	.5281	.6104	.9326	1.3763	.5765	.7461	.7291
4	.5121	.7122	1.0513	1.4582	.6443	.7291	.7291
5	.5344	.9156	1.2548	1.4746	.8817	.7291	.6783
6	.5668	1.1022	1.4922	1.4403	1.0513	.6952	.6783
7	.5735					.6274	.6104
8	.6081					.6104	.5596
9	.6653	2.5692	1.7238	1.6244	2.5857		.5087
10	.6653	2.4531	1.6741	1.5083	2.6189		2.0856
11	.6468	2.2045	1.3094	1.1934	2.4863		2.4926
12		1.6741	1.1271	.9945	1.989		2.6282
13		1.5912	1.1271	.9945	1.8896		2.713
14		1.5912	.9448	.8785	1.7238		2.2382
15		1.6907	1.0774	1.0608	1.7901		2.0517
16	1.1603	1.873	.9945	1.1437	1.8084		2.5434
17						.6706	.6882
18						.6562	2.2447
19						.7373	2.2405
20						.7956	1.1012
21	.7122	.9496		.407			1.6956
22	.9156	1.0343		.5426	.6401	.763	2.5943
23	.78	.9835		.6783	.7122	.763	1.7295
24	2.2919	.6104	.9326	1.2963	.5765	.7461	.7291
Max	2.2919	2.5692	1.7238	1.6244	2.6189	.7956	2.713
Min	.5121	.6104	.9326	.407	.5765	.6104	.5087
Avg	.7690	1.3214	1.1671	1.1472	1.3604	.7174	1.4886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074019 / 33 KV JAMOD S/S

Feeder No / Name : 202 / 11 KV SUNGAON AG FEEDER
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.407			.373		.6443
2		.407			.373		.6443
3		.407			.373		.6443
4		.5426			.4748		.763
5		.6104			.6613		.9496
6		.7291			.9496		1.153
9	.7956		1.0111	1.0774			
10	.8785		1.094	1.0277			
11	.779		.9448	.8951			
12			.9779	.6962			
13			.779	.6464			
14			.779				
15			.6299	.6133			
16	.6464		.6133	.6962			
21	.3391			.3052		.5281	
22	.407			.373		.6443	
23	.407			.4409		.7291	
24	1.3927	.407			.373		.6443
Max	1.3927	.7291	1.094	1.0774	.9496	.7291	1.153
Min	.3391	.407	.6133	.3052	.373	.5281	.6443
Avg	.7057	.5014	.8536	.6771	.5111	.6338	.7775

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074019 / 33 KV JAMOD S/S

Feeder No / Name : 203 / 11 KV KARMODA AG FEEDER
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
1	1.7814
2	1.7814
3	1.7204
4	1.6004
5	1.6194
6	1.5203
24	2.732
Max	2.732
Min	1.5203
Avg	1.8222

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074019 / 33 KV JAMOD S/S

Feeder No / Name : 204 / 11 KV JAMOD GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7282	.6762	.5735	.7282	
2		.7282	.6762	.5281	.7282	
3			.6762	.5601	.7282	
4		.7282	.6241	.5735	.7282	
5		.6935	.6241	.6133	.6935	
6		.6935	.6068	.6554	.6935	
7		.6241	.5895	.6401	.5895	
8		.5721	.5721	.6722	.5721	
9		.6099	.6099	.5914	.6283	
10		.6468	.6468	.6099	.6283	
11		.6283	.6283	.5914	.6283	
12		.6283	.5914	.6099		
13		.6653	.5914	.6468	.7762	
14		.7023	.6283	.6838	.7762	
15		.6838	.6283	.6653	.7947	
16	.6838	.7207	.6283	.6838	.6478	
17	.5548				.7373	
18	.5895	.7802				
19	.6588	.8149				
20	.7282	.7975				
21	.7628	.7802		.7282		
22	.7975	.763		.7455		
23	.7455	.7455		.7455		.763
24	.9088	.7282	.6762	.664	.7282	
Max	.9088	.8149	.6762	.7455	.7947	.763
Min	.5548	.5721	.5721	.5281	.5721	.763
Avg	.7144	.7029	.6279	.6391	.6945	.763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074019 / 33 KV JAMOD S/S

Feeder No / Name : 205 / 11 KV KARMODA GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1966	.2601	.2774	.1989	.2774	.156	.2774
2	.1989	.2601	.2774	.192	.2774	.156	.2774
3	.1638	.2601	.2774	.1638	.2774	.156	.2774
4	.1966	.2601	.2774	.16	.2774	.1734	.2774
5	.192	.2427	.2427	.2012	.2427	.1734	.2427
6	.2401	.2427	.208	.2515	.2427	.208	.2427
7		.208	.208	.2515	.208	.208	.208
8	.2429	.208	.208	.1943	.208	.208	.208
9	.1848	.2033	.1848	.1848	.1294		
10	.1478	.2402	.1294	.1478	.1663		.1696
11	.1294	.1848	.0924	.1848	.1848		.1696
12		.1848	.2033	.2033	.1663		.1696
13		.2402	.1848	.1663			.1696
14		.2772	.1848	.1848			.1696
15		.2033	.1848	.2033	.1848		.1696
16	.1848	.2587	.2033	.2033	.1677		.1696
17	.208				.192	.16	.1658
18	.208	.2601	.1848			.1638	.1638
19	.2427	.2601	.2402			.1658	.1989
20	.2601	.2774				.2458	.1989
21	.2601	.2774		.2601		.1943	.2035
22	.2774	.2774		.2774		.2427	.2035
23	.4161	.2774		.2774		.2774	.2374
24	.8745	.2601	.2774	.2012	.2774	.156	.2774
Max	.8745	.2774	.2774	.2774	.2774	.2774	.2774
Min	.1294	.1848	.0924	.1478	.1294	.156	.1638
Avg	.2539	.2445	.2130	.2054	.2175	.1903	.2108

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074019 / 33 KV JAMOD S/S

Feeder No / Name : 206 / 11 KV USARA CHALTHANA AG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4858		.5765	.6325			
2	.4801		.5765	.6554			
3	.6722		.5765	.7287			
4	.8322		.78	.8322			
5	.9282		.9835	.9393			
6	.9602		1.2209	.8697			
9		1.5746			1.989		.4748
10		1.5746			1.6575		.2883
11		1.1768					.1696
12		1.1768					.1357
13		.9945					.8139
14		.8288					1.1191
15		.8288			1.4255		1.3565
16		.8951			1.3123		1.4752
17							1.2146
18						.1658	.9922
19						.663	
20						.1638	
21						.16	.8478
22		.0848					.9156
23		.2035					.8139
24	.4801		.5765	.6401			
Max	.9602	1.5746	1.2209	.9393	1.989	.663	1.4752
Min	.4801	.0848	.5765	.6325	1.3123	.16	.1357
Avg	.6913	.9338	.7558	.7568	1.5961	.2882	.8167

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074031 / 33 KV PIMPALGAON KALE S/S

Feeder No / Name : 201 / 11 KV PIMPALGAON KALE AG FEEDER SEPERATION/PURE AG
FEEDE Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
10			1.286
11			1.5089
12			1.6461
13		1.307	1.6804
14			1.6289
15			1.6118
16			1.5947
21			1.4403
22			1.5432
23			1.5432
24	1.0242		
Max	1.0242	1.307	1.6804
Min	1.0242	1.307	1.286
Avg	1.0242	1.307	1.5484

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074031 / 33 KV PIMPALGAON KALE S/S

Feeder No / Name : 202 / 11 KV ADOL AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3429		
2			.3429		
3			.3429		
4			.3772		
5			.3772		
6			.3944		
7					.4668
10	.0285	.4024			
11	.3688	.4024			
12	.4191	.4024			
13		.4694		.5601	
14		.503			
15		.4191			
16		.3688			
21		.2572			
22		.3086			
23		.3429			
24			.3429		
Max	.4191	.503	.3944	.5601	.4668
Min	.0285	.2572	.3429	.5601	.4668
Avg	.2721	.3876	.3601	.5601	.4668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074031 / 33 KV PIMPALGAON KALE S/S

Feeder No / Name : 203 / 11 KV PALASHI SUPO AG FEEDER SEPERATION/PURE AG
FEEDER Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.5487
Max	.5487
Min	.5487
Avg	.5487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074031 / 33 KV PIMPALGAON KALE S/S

Feeder No / Name : 204 / 11 KV ADOL GAOTHAN FEEDER GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5144		
2			.4801		
3			.4287		
4			.4801		
5			.5144		
6			.5316		
7			.4973		.5601
8			.463		
10	.4191	.4191			.4115
11	.381	.4191			.3772
12	.3963	.4024			.3772
13		.4191		.4108	.3429
14					.3429
15					.3944
16		.4578			.4458
17		.503			.5144
18		.57			.5658
19		.6203		.6722	.6001
20		.6706			.703
21		.6344			.6344
22		.6001			.583
23		.5487			.5316
24	.5312		.5144		
Max	.5312	.6706	.5316	.6722	.703
Min	.381	.4024	.4287	.4108	.3429
Avg	.4319	.5221	.4916	.5415	.4923

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074031 / 33 KV PIMPALGAON KALE S/S

Feeder No / Name : 205 / 11 KV PIMPALGAON KALE

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 /
OUTGOING

DATE	01-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.1145		
2			1.0631		
3			1.0288		
4			1.0631		
5			1.1145		
6			1.1488		
7			1.046		
8			.9602		
10	.9221	.9724			1.7147
11	.8383	.9389			1.6804
12	.788	.9054			1.5775
13		.9221		1.1203	1.6289
14		.9724			1.6461
15		1.0059			1.6975
16		1.0395			1.6804
17		1.2346			1.1488
18		1.3546			1.2517
19		1.4746		1.307	1.3546
20		1.5432			1.4746
21		1.4403			1.989
22		1.3375			2.0233
23		1.2346			2.0576
24	1.5364		1.166		
Max	1.5364	1.5432	1.166	1.307	2.0576
Min	.788	.9054	.9602	1.1203	1.1488
Avg	1.0212	1.1697	1.0783	1.2137	1.6375

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074031 / 33 KV PIMPALGAON KALE S/S

Feeder No / Name : 206 / 11 KV JIGAON (PROJECT) EXP NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0171		
2			.0171		
3			.0171		
4			.0171		
5			.0171		
6			.0171		
7			.0171		
8			.0171		
10	.0914	.0838			.0857
11	.1006	.1006			.0857
12	.0914	.1006			.0686
13		.1006		.0373	.0686
14		.1006			.0857
15		.1006			.0857
16		.1006			.1029
17		.1029			
18		.0686			
19		.0343		.0373	
20		.0171			
21		.0171			
22		.0171			
23		.0171			
24	.064		.0171		
Max	.1006	.1029	.0171	.0373	.1029
Min	.064	.0171	.0171	.0373	.0686
Avg	.0869	.0687	.0171	.0373	.0833

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074031 / 33 KV PIMPALGAON KALE S/S

Feeder No / Name : 207 / 11 KV Tiwadi AG Feeder FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	04-JUN-18	05-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.7716	
2			.823	
3			.8573	
4			.8573	
5			.9088	
6			.9431	
7				.9335
10	.9389	.8383		
11	.884	.9724		
12	.9297	1.073		
13		1.1401		
14		1.1736		
15		1.2574		
16		1.0898		
21		.6859		
22		.6859		
23		.7716		
24			.7716	
Max	.9389	1.2574	.9431	.9335
Min	.884	.6859	.7716	.9335
Avg	.9175	.9688	.8475	.9335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074051 / 33 KV MADAKHED S/S

Feeder No / Name : 201 / 11 KV RUDHANA FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.4854	.2801	.4668	.4191	.4294	.5853
2	.2743	.4854	.2987	.4481	.4572	.4294	.5853
3	.3109	.4481	.3174	.4481	.4191	.4108	.5487
4	.3292	.4294	.3361	.4854	.381	.3921	.567
5	.3475	.4294	.3734	.5041	.381	.3734	.5121
6	.3475	.4294	.3547	.5415	.5144		.4938
7	.2195	.4108	.2987	.2614	.381		.4251
8	.1829	.3547	.2427	.2427	.3696		.2772
9	.3048	.4251	.2427	.3174	.462	.3658	.3429
10	.2858	.4805	.2801	.3048	1.0269	.3658	.3239
11	.3239	.4668	.2987	.2858	.4435	.4755	.3429
12	.3429	.4066	.2614	.3048	.4481	.5121	.3429
13	.2858	.3511	.2614	.2858	.3734	.5487	.362
14	.3048	.3326	.2801	.3048	.3326	.5853	.3429
15	.2858	.3326	.2801	.3239	.3326	.5121	.3429
16	.3429	.3142	.2801	.3429	.3547	.4755	.362
17	.4572		.2614	.3239	.3696	.4024	.3429
18	.4001	.3511	.2614	.3429	.4481	.5121	.381
19	.4954	.4854	.2614	.4001		.5487	.362
20	.5041		.2801	.4191	.5975	.5853	.4572
21	.5601	.6161	.4854	.4572	.5975	.6219	.4763
22	.5601	.2801	.5041		.5975	.6219	.4572
23	.5415	.2614	.4854	.4001	.2987		.4763
24	1.2189	.5788	.2614	.4668	.381	.3921	.6036
Max	1.2189	.6161	.5041	.5415	1.0269	.6219	.6036
Min	.1829	.2614	.2427	.2427	.2987	.3658	.2772
Avg	.3958	.4161	.3120	.3773	.4516	.4780	.4297

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074051 / 33 KV MADAKHED S/S

Feeder No / Name : 202 / 11 KV WADSINGHI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1088		1.0288	
2	1.0164		.9907	
3	1.0164		.9526	
4	.961		.8764	
5	.9795		.8383	
6	1.0349		.8002	
7	.924		.7049	
8	.8871		.6097	
9	1.0479			
10	1.0669	.8573		
11	1.086	.8764		
12	1.0479	.9145		
13	1.0669	.8954		
14	1.0479	.9335		
15	1.0669	.9526		
16	1.105	.9907		
17	1.086	1.1431		
18	.9526	1.2193		
19	1.1812	1.2384		
20		1.2003		
21		1.1431		
22		1.105		
23		1.0669		1.668
24	1.1088		1.0479	
Max	1.1812	1.2384	1.0479	1.668
Min	.8871	.8573	.6097	1.668
Avg	1.0396	1.0383	.8722	1.668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074051 / 33 KV MADAKHED S/S

Feeder No / Name : 203 / 11 KV BHENDWAD FEEDER
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-JUN-18
HR	Load (MW)
24	.0162
Max	.0162
Min	.0162
Avg	.0162

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074072 / 33 KV ASLGAON S/S

Feeder No / Name : 201 / 11 KV DHANORA GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8316	.8501	.7716	.8131	.8413	.9149	.7545
2	.7762	.8501	.7545	.7947	.8501	.8413	.7373
3	.7392	.823	.7373	.7762	.823	.7602	.7202
4	.7023	.8145	.703	.7392	.8145	.7316	.7202
5	.6653	.7392	.6859	.7207	.8316	.724	.7202
6	.7392	.695	.6344	.6838	.7207	.7655	.6344
7	.5729	.5853	.5487	.5359	.5853	.6535	.5144
8	.5121	.5415	.4801		.5068	.4854	.463
9	.543	.5487	.4458	.5068	.6154	.4854	.4801
10	.5316	.5487	.4805	.4973	.6036	.5373	.5228
11	.583	.6036	.5249	.5316	.6036	.4477	.5138
12	.6516	.6584	.5487	.5658	.6219	.5731	.5975
13	.6859	.7577	.5973	.583	.6767	.6335	.6348
14	.7202	.7682	.6219	.6687	.7499	.7133	.6722
15	.7202		.6584	.6859	.7682	.7499	.6908
16	.703	.7682	.6584	.6516	.7316	.6767	.6722
17	.6173		.6447	.6173	.6805	1.6834	.6348
18	.6135	.5144	.6135	.6201	.6908	.6859	.6485
19	.724	.6859	.6805	.788	.8048	.7716	.7522
20	.9425	.8573	.8316	.9511	.9709	.8745	.9055
21	.961	.8916	.9055	.961	.905	.8573	.9149
22	.961	.8745	.8871	.9795	.9694	.823	.8962
23	.9055	.823		.924	.9709	.7716	.8686
24	.8501	.8686	.7888	.8131	.8779	.9335	.7716
Max	.961	.8916	.9055	.9795	.9709	1.6834	.9149
Min	.5121	.5144	.4458	.4973	.5068	.4477	.463
Avg	.7188	.7303	.6610	.7134	.7589	.7539	.6850

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074072 / 33 KV ASLGAON S/S

Feeder No / Name : 202 / 11 KV DHANORA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0417			.0412		.1067
2		.0412			.0556		.0914
3		.0526			.0541		.0914
4		.0446			.1014		.0914
5		.1372			.1269		.1372
6		.282			.3525		.503
9	.2435		.5182			.4527	
10	.3353		.3909			.4287	
11	.3658		.2435	.5792		.4287	
12	.2134		.2086	.442		.2881	
13	.1372		.1833	.2134		.2715	
14	.0762		.1286	.2134		.1758	
15	.061		.0977	.1829		.1509	
16	.1219		.192	.2743		.2058	
17				.2439			
21	.0406			.0337		.1219	
22	.0541			.0619		.0914	
23	.0417			.0526		.0914	
24		.0417			.0417		.1219
Max	.3658	.282	.5182	.5792	.3525	.4527	.503
Min	.0406	.0412	.0977	.0337	.0412	.0914	.0914
Avg	.1537	.0916	.2454	.2297	.1105	.2461	.1633

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074072 / 33 KV ASLGAON S/S

Feeder No / Name : 203 / 11 KV MAHULI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1132	.12	.1132	.1132	.132	.1029
2	.1132	.1132	.1029	.1132	.1132	.132	.1029
3	.1132	.0934	.1029	.0943	.112	.1132	.1029
4	.0943	.1132	.1029	.0943	.112	.1132	.1029
5	.0943	.1132	.1029	.0943	.1132	.0934	.1029
6	.0943	.0934	.1029	.0943	.0754	.1132	.1029
7	.0754	.0754	.0857	.0566	.0754	.0943	.0686
8	.0566	.0754	.0686		.0754	.0754	.0686
9	.0754	.0754	.0686	.0377	.0754	.0754	.0686
10	.0686	.0566	.0377	.0514	.0943	.0754	.0754
11	.0686	.0566	.0754	.0686	.0754	.0747	.0754
12	.1029	.0943	.0754	.0686	.0754	.0747	.0754
13	.1029	.0943	.0754		.0943	.0747	.0754
14	.1029	.3763	.0943	.1029	.0754	.0754	.0754
15	.1029	.3311	.0754	.1029	.0943	.0943	.0943
16	.1029	.1132	.0754	.0857	.0943	.0754	.0754
17	.0857		.0747	.0857	.0943	.0754	.0943
18	.0747	.0857	.0566	.0747	.0754	.0857	.0754
19	.0754	.0857	.0943	.0754	.132	.1029	.0754
20	.132	.12	.1307	.1132	.1509	.12	.132
21	.132	.12	.1132	.1334	.132	.12	.132
22	.132	.1372	.1132	.132	.1494	.12	.132
23	.1132	.12		.1132	.1509	.12	.132
24	.715	.1132	.12	.1132	.1132	.132	.1029
Max	.715	.3763	.1307	.1334	.1509	.132	.132
Min	.0566	.0566	.0377	.0377	.0754	.0747	.0686
Avg	.1226	.1204	.0900	.0918	.1028	.0984	.0936

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074072 / 33 KV ASLGAON S/S

Feeder No / Name : 204 / 11 KV MAHULI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2462		.1829	.2606		
2	.1572		.1829	.2606		
3	.1572		.1829	.2229		
4	.1738		.2134	.2115		
5	.2258		.2439	.3418		
6	.2968		.2896	.4268		
9		.5281			.7116	
10		.6718			.8322	
11		.4428			.6958	
12		.381			.6325	
13		.381			.4902	
14					.506	
15					.4784	.8802
16		.3382			.5937	.8471
21			.2286		.4287	.5693
22			.2824		.4755	.6642
23			.2751		.3506	.5624
24	.94		.2134			
Max	.94	.6718	.2896	.4268	.8322	.8802
Min	.1572	.3382	.1829	.2115	.3506	.5624
Avg	.3139	.4572	.2295	.2874	.5632	.7046

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074072 / 33 KV ASLGAON S/S

Feeder No / Name : 205 / 11 KV MAIN I/C ASALGAON-I

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1946	1.0349	1.0974	1.2308	1.0164	1.0136	.9774
2	1.0679	1.0059	1.0631	1.2127	1.0242	.9896	.9431
3	1.0317	.9774	1.046	1.1222	.9955	.8962	.9259
4	.9955	.9877	1.046	1.086	1.0719	.8413	.9259
5	1.0136	1.0349	1.0631	1.2127	1.0974	.8316	.9774
6	1.1584	1.1643	1.0631	1.2536	1.1919	.8507	1.3032
7	.6335	.6516	.6344	.5914	.6584	.724	.583
8	.567	.5973	.5487		.5609	.5434	.5316
9	.8817	1.1616	1.0974	.5729	1.286	1.1403	.5487
10	.9774	1.2689	.9221	.5487	1.5089	1.0486	.5609
11	1.0631	1.1218	.8648	1.2517	1.4043	.9667	.5784
12	.9945	1.1568	.8495	1.1317	1.3523	.9556	.631
13	.9431	1.2269	.9145	.9088	1.2656	1.0498	.6661
14	.9088	1.262	.8505	1.0117	1.3496	.9816	.724
15	.8916	1.2403	.8669	.9945	1.3672	1.0099	1.7556
16	.9431	1.2934	.9877	1.046	1.439	.9882	1.7372
17	.703		.7164	.9774	.7783	.7164	.6836
18	.6836	.6001	.6661	.6836	.703	.7716	.7186
19	.7964	.7716	.7701	.8596	.8745	.8745	.8238
20	1.0719	.9774	.961	1.0719	1.0288	.9945	1.0349
21	1.1458	1.0117	1.267	1.134	1.4918	1.1145	1.6476
22	1.1643	1.0117	1.3213	1.1888	1.6301	1.046	1.7372
23	1.0719	.9431			1.448	.9945	1.6118
24	1.2127	1.0534	1.1488	1.2489	1.0425	.9774	1.0117
Max	1.2127	1.2934	1.3213	1.2536	1.6301	1.1403	1.7556
Min	.567	.5973	.5487	.5487	.5609	.5434	.5316
Avg	.9631	1.0241	.9463	1.0154	1.1494	.9300	.9849

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074105 / 33/11 KV UMAPUR

Feeder No / Name : 201 / 11 KV UMAPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3612		.1829	.583		.7762	
2	.3612		.1677	.583		.8501	
3	.381		.1524	.6173		.8589	
4	.3963		.1753	.6516		1.0658	
5	.4115		.2286	.7202		1.0829	
6	.4877		.3429	.8573		1.1949	
9		.8589			1.0185		.5487
10		1.0185			1.0623		.6249
11		.3963			1.307		1.3889
12		.381			1.2323		1.3717
13		.3506			1.1827		1.3375
14		.3429			1.1694		1.286
15		.3582			1.1694		1.3032
16		.381			1.2323		1.3375
21		.2286	.5487		.8215		1.0974
22		.2134	.583		1.0082		1.1317
23		.2058	.583		.7842		1.166
24	.3963		.1905	.583		.7842	
Max	.4877	1.0185	.583	.8573	1.307	1.1949	1.3889
Min	.3612	.2058	.1524	.583	.7842	.7762	.5487
Avg	.3993	.4305	.3155	.6565	1.0898	.9447	1.1449

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074105 / 33/11 KV UMAPUR

Feeder No / Name : 202 / 11 KV KAHUPATTA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1505		.0914	.3086		.3772	
2	.1505		.0762	.3086		.3772	
3	.1505		.0762	.3086		.3696	
4	.1505		.0914	.3086		.415	
5	.1524		.1067	.3429		.415	
6	.2439		.1372	.3429		.415	
9		.3734			.4321		.2286
10		.3772			.4374		.2591
11		.16			.5601		.5487
12		.1524			.5228		.4973
13		.1372			.5175		.5487
14		.1296			.5544		.5658
15		.1296			.5601		.6001
16		.1372			.5601		.6173
21		.0914	.2401		.2987		.4458
22		.1067	.2743		.3772		.4801
23		.1067	.3086		.3696		.4973
24	.1505		.0991	.3086		.3734	
Max	.2439	.3772	.3086	.3429	.5601	.415	.6173
Min	.1505	.0914	.0762	.3086	.2987	.3696	.2286
Avg	.1641	.1729	.1501	.3184	.4718	.3918	.4808

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074105 / 33/11 KV UMAPUR

Feeder No / Name : 203 / 11 KV HANWATKHED AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4854			.5792		.282
2		.5329			.5639		.2667
3		.5228			.6097		.2667
4		.5544			.7316		.3048
5		.7095			.8796		.442
6		.9431			.9374		.5487
9	.4877		.503	1.0631		1.419	
10	.9374		.5182	1.1488		1.531	
11	1.1203		1.0974	.8905		.5716	
12	1.0082		1.0802	.8592		.4725	
13	.7922		1.0288	.8436		.4725	
14	.7095		.9945	.8488		.4572	
15	.7095		.9431	.8488		.442	
16	.8215		.9431	.9804		.503	
21	.4854			.4268		.2896	
22	.4481			.5792		.3048	
23	.4805			.6097		.3048	
24		.4854			.6097		.282
Max	1.1203	.9431	1.0974	1.1488	.9374	1.531	.5487
Min	.4481	.4854	.503	.4268	.5639	.2896	.2667
Avg	.7273	.6048	.8885	.8272	.7016	.6153	.3418

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074105 / 33/11 KV UMAPUR

Feeder No / Name : 204 / 11 KV UMAPUR GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6733	.6722	.2058	.583	.6878	.7023	.2667
2	.6201	.6722	.1677	.583	.6556	.6653	.2591
3	.6024	.6722	.1524	.5487	.6201	.6722	.2439
4	.5847	.6722	.1448	.5144	.5784	.6722	.2439
5	.567	.6653	.1677	.5144	.567	.6348	.2515
6	.543	.6602		.5487	.5487	.5601	.2667
7	.4706	.5228	.2286	.4973	.5973	.4805	.2439
8	.4607	.5601	.2286	.4801	.543	.4108	.1981
9	.4784	.5601	.2134		.543	.5228	.1981
10	.5249	.4854	.2058	.463	.4961	.5601	.1981
11	.5601	.2439	.5144	.5138	.5228		.4458
12	.5228	.2591		.543	.5658	.2286	.4458
13	.5975	.2591	.5144	.5493	.5601	.2286	.4801
14	.5975	.2515	.5316	.5792	.5601	.2439	.5487
15	.5914	.2439	.5487		.5914	.2439	.583
16	.5975	.2591	.5487	.5792	.6348	.2591	.6859
17	.6036		.6001	.6697	.6348		.6516
18	.6348	.2591	.6344	.6878	.6722		.6173
19	.6722	.282	.6516	.7059	.6653	.2515	.6859
20	.7095	.3048	.6344	.7947	.7545	.3048	.703
21	.7392	.3048	.6516	.7762	.7392	.3048	.703
22	.7468	.2896	.6516	.7392	.7468	.2896	.6859
23	.7545	.2743	.6173	.7059	.7392	.2896	
24	.6878	.6722	.2743	.583	.6878	.7545	.2743
Max	.7545	.6722	.6516	.7947	.7545	.7545	.703
Min	.4607	.2439	.1448	.463	.4961	.2286	.1981
Avg	.6058	.4368	.4131	.5982	.6213	.4419	.4296

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074006 / 33 KV DATALA S/S

Feeder No / Name : 201 / 11 KV DATALA (SINGLE PHASE) Feeder KV- 11 / OUTGOING SINGLE PHASING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	1.3527	.6859	.7049	1.3336	.743	1.2003
2	.6097	1.2955	.6859	.7049	1.2955	.6668	1.1431
3	.6097	1.2384	.6859	.724	1.2955	.6668	1.105
4	.6287	1.2003	.6859	.8383	1.2384	.6668	1.105
5	.6478	1.1431	.724	1.0669	1.2574	.724	1.0669
6	.7049	1.086	.7621	1.1812	1.1241	1.0669	.9717
7	.9717	.9526	1.0288	.9526	.9526	.9335	.9145
8	.9526	.9145	.9526	.8383	.9145	.8764	.7621
9	.9717	.9907	.9526	.9335	1.2384	.8383	1.105
10	1.0288	.9526	.8573	.9335	1.2384	.8573	
11	1.0669	.9526	.8954	.9145	1.1812	.9526	1.2384
12	1.105	.8764	.9335	1.0479	1.2003	1.0479	1.1241
13	1.2955	.8573	1.0479	1.2003	1.2574	1.0479	1.1431
14	1.3336	.8573	1.1622	1.2384	1.1622	1.2384	1.0288
15	1.0479	.8954	1.1241	1.2574	1.1241	1.2384	.9907
16	1.0669	.8764	1.0669	1.2765	1.0479	1.2384	.9907
17	1.2384	1.1812	1.086	1.2193	1.1431	1.0479	
18	1.2003	1.0669	1.105	1.1431	1.105	1.1622	1.0479
19	1.2193	1.1812	1.1241	1.2003	1.105		1.0479
20	1.6004	1.4098	1.4098	1.5813	1.6004	1.2003	1.6194
21	1.6956	.7621	.8002	1.6575	.8573	1.5242	.9526
22	1.6004	.7621	.7621	1.5623	.8764	1.5432	.9526
23	1.448	.724	.743	1.4289	.724	1.3908	.9526
24	.964	1.4098	.7049	.724	1.3527	.743	1.2574
Max	1.6956	1.4098	1.4098	1.6575	1.6004	1.5432	1.6194
Min	.6097	.724	.6859	.7049	.724	.6668	.7621
Avg	1.0674	1.0391	.9161	1.0971	1.1511	1.0180	1.0782

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074006 / 33 KV DATALA S/S

Feeder No / Name : 202 / 11 KV UMALI (SINGAL PHASING) Feeder KV- 11 /
OUTGOING SINGLE PHASING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	.6478	1.105	1.105	.6478	1.2193	.4954
2	1.1431	.6478	1.0288	1.086	.6287	1.1431	.4954
3	1.105	.6668	1.0288	1.0479	.6287	1.1431	.5335
4	1.0669	.743	1.0288	1.0288	.6668	1.1622	.5525
5	1.0479	.8002	1.0288	1.0098	.7811	1.1812	.5906
6	.9907	.9526	1.0669	.9717	.8764	1.0479	.9145
7	.8954	.9145	.8383	.8383	.9145	.9335	.8002
8	.8764	.8002	.743	.7621	.8192	.7811	.7811
9	.9526	.8383	.9907	1.0098	.8383	1.3146	
10	1.0288	.9526	1.1812	1.2574	.8383	1.5432	.8573
11	1.1431	.9526	1.1431	1.2384	.8954	1.5242	.8573
12	1.1431	.9717	1.1812	1.2003	.8954	1.4289	.8954
13	1.1431	1.0479	1.0479	.9145	.9717	1.2955	.8764
14	1.0098	1.086	.9526	1.0479	.9907	1.2003	.9717
15	.9526	1.1431	1.0288	1.0288	1.0098	1.0479	1.0288
16	.9335	1.1431	.9145	1.0479	1.0669	1.1622	1.0288
17	1.105	1.0669	.8764	1.0288	1.0479		.8573
18	1.105	.9145	.9526	1.0288	1.0288		.8764
19	1.086	1.1431	.9907	1.0288	1.0098		
20	1.4098	1.4289	1.2003	1.4098	1.3146		1.3146
21	.724	1.4098	1.3336	.8383	1.4289		1.3717
22	.7049	1.3146	1.2574	.7811	1.3527	.2858	1.3146
23	.724	1.2003	1.1812	.7049	1.2193	.4954	1.1812
24	1.1812	.6859	1.1431	1.1431	.6478	1.2193	.4954
Max	1.4098	1.4289	1.3336	1.4098	1.4289	1.5432	1.3717
Min	.7049	.6478	.743	.7049	.6287	.2858	.4954
Avg	1.0256	.9780	1.0518	1.0233	.9383	1.1120	.8677

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074006 / 33 KV DATALA S/S

Feeder No / Name : 203 / 11 KV NIMBARI (SINGAL PHASING) Feeder KV- 11 /
OUTGOING SINGLE PHASING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.2286	.8002	.9526	.2286	1.105	1.2574
2	.7621	.2286	.8002	.9335	.2286	1.1241	1.2765
3	.7621	.2096	.8002	.9145	.2096	1.1431	1.2765
4	.8002	.2096	.8573	1.0479	.2286	1.1431	1.2955
5	.8573	.2096	.8954	1.1812	.2286	1.1622	1.2955
6	.9526	.2096	.9145	1.2955	.1905	1.2765	1.6194
7	.1524	.1524	.1715	.1334	.1524	.1524	1.848
8	.1524	.1524	.0762		.1524	.1524	2.0005
9	.1715	1.2193	.0762		1.448	.0953	2.1338
10	.1905	1.2384	.0953		1.467	.0762	2.1529
11	.2096	1.2384	.0953		1.448	.0762	1.105
12	.2286	1.2955	.1905		1.3908		1.2384
13		1.1431	.2096		1.2955		1.2003
14		1.1431	.2286	.2286	1.2955	.1905	1.1812
15	.2667	.9907	.2096	.2477	1.2574	.2286	1.2003
16	.2477	.9526	.1905	.2477	1.2384	.2286	1.1812
17	.2286	.2286	.1905	.2286	.1334	.2286	.2096
18	.2096	.1905	.2096	.2096	.1905	.2096	.1905
19	.2096		.2286	.2286	.2286		
20	.3048		.2477	.2667	.2667	.1524	.2477
21	.3048		.8954	.3048	1.105	.2477	1.0669
22	.2667	.7621	.9335	.2667	1.105	.2286	1.0669
23	.2477	.8383	.9907	.2477	1.086	.2286	.9907
24	.7621	.2477	.8192	.9717	.2286	1.105	1.2574
Max	.9526	1.2955	.9907	1.2955	1.467	1.2765	2.1529
Min	.1524	.1524	.0762	.1334	.1334	.0762	.1905
Avg	.4114	.6233	.4636	.5504	.7002	.5026	1.2301

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074006 / 33 KV DATALA S/S

Feeder No / Name : 204 / 11 KV AKSHAY (EXPRESS) SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1905	.1334	.1334	.1524	.1524	.1905
2	.1334	.1905	.1334	.1334	.1524	.1524	.1715
3	.1334	.2096	.1334	.1524	.1524	.1715	.1715
4	.1334	.2286	.1334	.1715	.1524	.1715	.1905
5	.1524	.2286	.1334	.1715	.1524	.1524	.1905
6	.1715	.2477	.1334	.1715	.1905	.1905	.2286
7	.1715	.2096	.1524	.2286	.1905	.1905	.2477
8	.1905	.1334	.1905	.1715	.3239	.2286	.2667
9	.5716	.3239	.4954	.5335	.6478	.6287	.6859
10	.5716	.381	.5144	.6097	.6478	.6478	.6287
11	.5335	.381	.4763	.5144	.6097	.6478	.6478
12	.5144	.5525	.4191	.5335	.5906	.4954	.5716
13	.5335	.4763	.4763	.5525	.5906	.5525	.5716
14	.5525	.4382	.5335	.5144	.6097	.6097	.5906
15	.2667	.4763	.5525	.4572	.5906	.6668	.6287
16	.2477	.4001	.5144	.4191	.6097	.6097	.4954
17	.2286	.1715	.4001	.362	.4572	.4382	.4572
18	.1524	.0953	.362	.2286	.381	.1334	.4382
19	.1334	.0953	.2286	.1524	.2477	.1334	
20	.1334	.0953	.1905	.1524	.1715	.1334	.1905
21	.1524	.1143	.1715	.1905	.1524	.1715	.2477
22	.1524	.1143	.1524	.1715	.1715	.1905	.2667
23	.1905	.0953	.1524	.1715	.1715	.2096	.2667
24	.1524	.1905	.1334	.1524	.1715	.1715	.1905
Max	.5716	.5525	.5525	.6097	.6478	.6668	.6859
Min	.1334	.0953	.1334	.1334	.1524	.1334	.1715
Avg	.2628	.2517	.2882	.2937	.3453	.3271	.3711

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074006 / 33 KV DATALA S/S

Feeder No / Name : 205 / 11 KV JAMBHULDHABA (SINGAL SINGLE PHASING
PHA Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.6668	.4191	.5716	.6097	.6668	.5335
2	.4572	.6668	.4191	.5906	.6097	.5716	.5335
3	.4572	.6478	.4191	.5716	.5906	.5716	.4954
4	.4763	.6287	.4191	.6097	.5716	.5525	.5144
5	.4954	.6478	.4382	.6287	.5525	.5525	.5525
6	.6097	.6287	.4572	.6287	.5525	.6668	.5525
7	.5335	.5525	.4001	.4382	.5144	.5144	.4954
8	.4954	.4572	.4382	.4191	.4572	.4382	.4954
9	.4954	.6287	.4001	.4572	.724	.4191	.743
10		.724	.4382	.4572	.7049	.4382	.724
11		.6668	.4763	.5525	.7621	4.9535	.7621
12		.6859	.5144	.6097	.743	.4954	.6668
13	.7621	.6859	.5716	.6668	.6859	.4954	.724
14	.8002	.7049	.5906	.6668	.7049	.5716	.6859
15	.8002	.6478	.5906	.6668	.7049	.6097	.7049
16	.7621	.6478	.5906	.6859	.5906	.6097	.8002
17	.6478	.6287	.4763	.6097	.5906	.6478	.4572
18	.6668	.5716	.4763	.5716	.5716	.6287	.4763
19	.6287	.6097	.5144	.6097	.5525		
20	.8954	.724	.6287	.7049	.7621	.5525	.743
21	.8573	.5335	.5906	.743	.6859	.7049	.6668
22	.7811	.4954	.5716	.7049	.6668	.6478	.6668
23	.743	.4572	.5335	.6668	.6287	.4954	.6478
24	.4572	.7049	.4382	.5525	.6287	.6668	.5525
Max	.8954	.724	.6287	.743	.7621	4.9535	.8002
Min	.4572	.4572	.4001	.4191	.4572	.4191	.4572
Avg	.6323	.6255	.4922	.5993	.6319	.7596	.6171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074006 / 33 KV DATALA S/S

Feeder No / Name : 401 / 33 KV INCOMER I (1)

Feeder KV- 33 / INCOMING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4289	1.3146	1.4861	1.6575	1.3146	1.829	1.086
2	1.4289	1.3146	1.4289	1.6575	1.2574	1.6004	1.0288
3	1.4289	1.3146	1.4289	1.6575	1.2574	1.6004	1.086
4	1.4861	1.3717	1.4289	1.7718	1.2574	1.6004	1.086
5	1.4861	1.3717	1.4861	2.0005	1.3717	1.6575	1.1431
6	1.6575	1.5432	1.6004	2.1148	1.4289	2.0576	1.4289
7	.8002	.8002	.743	.743	.8002	.8002	.743
8	.8002	.743	.6859	.6859	.743	.6859	.6859
9	1.4289	1.8861	1.4289	1.4289	2.2291	1.7147	1.829
10	1.3717	1.9433	1.6004	1.7147	2.2291	2.0005	2.1719
11	1.4861	1.9433	1.6004	1.7147	2.2291	2.0005	2.2862
12	1.4861	1.8861	1.6575	1.7718	2.2291	1.9433	2.1148
13	1.829	1.8861	1.6004	1.5432	2.2862	1.829	2.1719
14	1.7147	1.9433	1.5432	1.6575	2.1719	1.829	2.0576
15	1.5432	1.9433	1.6004	1.6575	2.1719	1.6575	2.0576
16	1.5432	1.8861	1.4861	1.7147	2.1148	1.7718	2.1148
17	.9717	.9717	.8002	.9717	.9145	.5716	.8002
18	.9717	.8573	.8573	.9145	.9145	.5716	.8002
19	.9717	.9717	.8573	.9717	.9145		
20	1.3146	1.2003	1.086	1.2574	1.2003	.5716	1.2003
21	1.6004	1.7718	1.829	1.6575	2.0005	.743	2.0576
22	1.4861	1.7147	1.7718	1.5432	2.0005	1.0288	2.0576
23	1.4289	1.6004	1.6575	1.4289	1.7718	1.1431	2.0005
24	1.4861	1.3717	1.5432	1.6575	1.5432	1.829	1.086
Max	1.829	1.9433	1.829	2.1148	2.2862	2.0576	2.2862
Min	.8002	.743	.6859	.6859	.743	.5716	.6859
Avg	1.3813	1.4813	1.3837	1.4956	1.5980	1.4364	1.5258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074006 / 33 KV DATALA S/S

Feeder No / Name : 402 / 33 KV INCOMER II

Feeder KV- 33 / INCOMING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.2858	.9145	1.086	.2286	1.2574	1.4289
2	.9145	.2858	.9145	1.086	.2286	1.2574	1.4289
3	.9145	.2858	.9145	1.086	.2286	1.3146	1.4289
4	.9145	.2858	.9717	1.2003	.2286	1.3146	1.4861
5	1.0288	.2858	1.0288	1.3717	.2286	1.3146	1.4861
6	1.1431	.3429	1.0288	1.4861	.2286	1.4861	1.829
7	.2286	.2858	.2286	.2858	.2286	.2286	2.1148
8	.2286	.1715	.2286	.1715	.4001	.2858	2.2862
9		1.3717	.5144	.5144	2.1148	.6859	2.8006
10		1.6004	.5716	.6287	2.1148	.6859	2.8006
11		1.6004	.5144	.5144	2.0576	.6859	1.7718
12		1.829	.4572	.5144	2.0005	.5144	1.829
13	.5144	1.6004	.5716	.5716	1.8861	.5716	1.7718
14	.5716	1.5432	.6287	.5716	1.8861	.6859	1.7718
15	.3429	1.4861	.6287	.5144	1.829	.743	1.829
16	.3429	1.3717	.5716	.5144	.5144	.6859	1.6575
17	.2858	.2286	.4572	.4572	.5144	.5144	.5144
18	.2286	.1715	.4572	.2858	.4572	.3429	.5144
19	.2286	.1143	.2858	.2286	.3429		
20	.2286	.1143	.2858	.2286	.2858	.1715	.2858
21	.2286	.1143	1.086	.2858	1.2574	.2286	1.3146
22	.2286	.8573	1.086	.2858	1.2574	.2858	1.3146
23	.2858	.9145	1.1431	.2286	1.2574	.2858	1.2574
24	.9145	.2858	.9717	1.1431	1.3146	1.2574	1.4289
Max	1.1431	1.829	1.1431	1.4861	2.1148	1.4861	2.8006
Min	.2286	.1143	.2286	.1715	.2286	.1715	.2858
Avg	.5344	.7264	.6859	.6359	.9621	.7306	1.5805

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074007 / 33 KV DASARKHED S/S

Feeder No / Name : 201 / 11 KV RAMTHAM AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2753		.9602	1.0631	1.1984	.6859
2		.2915		.9602	1.0974	1.1822	.7716
3		.2753		.9602	1.166	1.1984	.7716
4		.2915	.4287	.9602	1.2003	1.1822	.7545
5		.3239	.6687	.9945	1.2003	1.1984	.7888
6		.421	.7545	1.0288	1.2003	1.2146	.823
9	.7773			.7716	.7611	.8583	1.166
10	.9717		.703	.7888	.7935	.8916	1.5708
11	1.0202		.7202		.8097	.9431	
12	1.0526	.8688	.703		.7611	1.0288	1.6842
13	1.085	.8078	.703		.7287	1.0288	1.668
14	1.0526	1.0802	.703		.7449	.9602	1.7004
15	1.0688	1.0517	.703		.7287	.9602	1.6842
16	1.0364	.9755	.7545	.7888	.7611	.9602	1.7004
17				.823			
18				.703			
21	.3239	.7373	.9431	1.0288	.9717		.7773
22	.3239		.9602	1.1145	1.0526		.8097
23	.2915	.7545	.9431	1.046	1.1012	.5144	.8421
24	.2743	.2915	.5658	.9431	1.0288	1.1498	.6173
Max	1.085	1.0802	.9602	1.1145	1.2003	1.2146	1.7004
Min	.2743	.2753	.4287	.703	.7287	.5144	.6173
Avg	.7732	.6033	.7324	.9248	.9539	1.0294	1.1068

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074007 / 33 KV DASARKHED S/S

Feeder No / Name : 202 / 11 KV NERVAL AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8421	.0686	.1372	.12	.1132	1.2003
2		.8421	.0686	.1372	.12	.0943	1.2346
3		.8259	.0686	.1372	.1029	.0943	1.2689
4		.8421	.0686	.12	.1029	.0754	1.3032
5		.8907	.0686	.12	.12	.0754	1.3375
6		.9555	.0686	.12	.1372	.0754	1.3717
7		.1619	.0686	.12	.12	.1132	.12
8		.1781	.0686	.1372	.1029	.1132	.1543
9	.1943	.1677	1.166	1.286	1.1984	1.8673	.1457
10	.1619	.1829	1.2689	1.286	1.3117	1.6289	.1296
11	.1619	.1829	1.3717		1.3279	1.6461	
12	.1781	.1829	1.3717		1.3279	1.6289	
13	.1781	.1829	1.3375		1.2955	1.6118	
14	.1781	.1677	1.3032		1.247	1.6118	
15	.1619	.1677	1.2346		1.2631	1.6118	.1296
16	.1619	.1677	1.286	1.2517	1.2955	1.5775	.1619
17	.1781	.1524	.1372	1.0288	.081	.1372	.1886
18	.1781	.1524	.12	1.046	.1132	.1029	.1886
19	.1781	.1524	.12	.1372	.1132		.1886
20	.1619		.1372	.12	.1132	.1029	.1886
21	.8907		.12	.1372	.132	1.166	1.7164
22	.9069		.1372	.1543	.132	1.166	1.4575
23	.8745		.12	.1372	.132	1.2003	1.3441
24	.5944	.8421	.0686	.12	.1372	.1132	1.2003
Max	.9069	.9555	1.3717	1.286	1.3279	1.8673	1.7164
Min	.1619	.1524	.0686	.12	.081	.0754	.12
Avg	.3337	.4120	.4937	.4070	.5061	.7794	.7515

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074007 / 33 KV DASARKHED S/S

Feeder No / Name : 203 / 11 KV JAKWEL INDISTRIAL SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.8484	1.6289	1.2003	.583	1.4335	1.2689
2		1.8107	1.6461	1.1145	.583	1.3957	1.2174
3		1.773	1.6461	1.0974	.583	1.4146	1.2174
4		1.7918	1.6975	1.0974	.583	1.4335	1.2174
5		1.8484	1.7147	1.046	.583	1.4523	1.2174
6		1.8673	1.9719	1.0288	.6001	1.4712	1.2174
7		1.8107	1.5261	.7545	.5487	1.5089	1.3203
8		1.8673	1.5775	.703	.7545	1.6975	1.2689
9	2.3954	1.9966	1.5775	.703	1.4523	1.905	1.3957
10	2.4143	2.21	1.7318	.6173	1.773	1.8861	2.1313
11	2.6595	2.1948	1.8861		1.9805	1.9376	1.9239
12	2.6783	2.21	1.6804		1.8107	1.8004	1.905
13	2.8292	2.1338	1.6804		1.8107	1.6289	1.7918
14	2.7349	1.829	1.6804		1.8107	1.8347	1.7541
15	2.6783	1.7528	1.6804		1.8107	2.2462	1.7164
16	2.6029	1.7071	1.8347	.7202	1.8484	2.3491	1.6975
17	2.7726	1.7528	1.7318	.6687	1.9805	2.2462	1.6975
18	2.4897	1.3717	1.7147	.6687	1.9805	2.2462	1.6975
19	2.3765	1.2955	1.6289	.6173	1.9805	2.2462	1.6409
20	2.4331		1.4918	.6173	1.8484	2.2462	1.6975
21	2.3011		1.5775	.6173	1.8107		1.6975
22	2.32		1.5432	.703	1.7353	1.1317	1.6409
23	1.8673		1.4232	.703	1.4146	1.3203	1.6409
24	1.6004	1.8673	1.6289	1.2346	.6687	1.3957	1.3032
Max	2.8292	2.21	1.9719	1.2346	1.9805	2.3491	2.1313
Min	1.6004	1.2955	1.4232	.6173	.5487	1.1317	1.2174
Avg	2.4471	1.8470	1.6625	.8375	1.3556	1.7490	1.5532

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074007 / 33 KV DASARKHED S/S

Feeder No / Name : 204 / 11 KV NARVEL GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5792	.4287	.4801	.5144	.6335	.5144
2		.5792	.3772	.463	.4801	.6413	.4801
3		.5792	.3944	.4458	.5144	.6335	.4458
4		.5792	.3944	.4458	.5316	.6335	.4801
5		.5792	.4287	.4973	.5487	.6516	.5144
6		.5973	.4801	.5144	.5144	.6516	.463
7		.5249	.4458	.463	.3258	.5611	.463
8		.5068	.4115	.4458	.3086	.5068	.4287
9	.5068		.4115	.4115	.3258	.4525	.4344
10	.547		.3944	.4115	.2715	.4458	.415
11	.543		.3772		.2534	.463	
12	.5792		.4458		.3077	.463	.2715
13	.6335		.4973		.3258	.463	.3982
14	.6154		.5144		.3584	.5144	.5249
15	.6335		.5658		.6335	.5487	.5611
16	.6516		.5316	.6859	.6697	.4801	.5973
17	.6516		.5487	.6173	.7059	.6173	.5792
18	.6697		.583	.6344	.6878	.6001	.6413
19	.6878		.5658	.6859	.6697		.6697
20	.7964		.6687	.7373	.6878		.7059
21	.724		.6344	.6859	.7059		.6878
22	.6697		.6001	.6173	.6878		.6335
23	.6335		.5144	.5487	.6697	.3429	.502
24	.4572	.5792	.2743	.4801	.5144	.6516	.5144
Max	.7964	.5973	.6687	.7373	.7059	.6516	.7059
Min	.4572	.5068	.2743	.4115	.2534	.3429	.2715
Avg	.6250	.5671	.4787	.5406	.5089	.5478	.5185

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074007 / 33 KV DASARKHED S/S

Feeder No / Name : 205 / 11 KV RANTHAM GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4344	.3772	.3944	.4801	.3077	.3772
2		.4344	.3429	.3772	.463	.3258	.4115
3		.4344	.3429	.3772	.463	.3077	.3944
4		.4344		.4115	.4801	.3258	.4115
5		.4706	.4115	.4287	.5144	.3982	.4287
6		.5249	.4801	.4801	.4973	.4525	.4115
7		.4887	.4973	.5144	.5316	.5068	.4115
8		.4706	.4458	.4458	.463	.4525	.4115
9	.5068	.4287	.3601	.4458	.3801	.362	.3982
10	.4706	.4287	.4115	.3772	.3439	.3601	.3801
11	.4887	.2743	.4287		.3077	.3772	.3982
12	.4525	.3086	.4287		.3584	.3944	.362
13	.4706	.463	.4287		.415	.4115	.362
14	.4887	.463	.4287		.4887	.4287	.3801
15	.5068	.463	.4287		.5068	.4458	.4344
16	.4887	.4801	.3429	.5316	.5249	.4801	.421
17	.5249	.463	.3086	.4287	.4887	.4973	.4887
18	.5792	.5658	.2058	.4973	.4706	.5144	.5068
19	.6154	.5487	.5144	.5144	.5068		.5093
20	.6335	.583	.5487	.583	.4525		.5281
21	.5792	.4801	.463	.5487	.4163		.4887
22	.4887	.4287	.4801	.5316	.3982		.4525
23	.4706	.3944	.4115	.463	.3258	.1886	.4338
24	.3506	.4527	.3944	.3944	.463	.3258	.2572
Max	.6335	.583	.5487	.583	.5316	.5144	.5281
Min	.3506	.2743	.2058	.3772	.3077	.1886	.2572
Avg	.5072	.4549	.4123	.4603	.4475	.3931	.4191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074007 / 33 KV DASARKHED S/S

Feeder No / Name : 206 / 11 KV WAGHOLA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5487	.8573	1.0631	1.0974	
2			.5487	.8573	1.0974	1.0974	
3			.5487	.8745	1.0974	1.1145	
4			.5487	.8745	1.2003	1.1317	
5			.6001	.9259	1.1145	1.286	
6				.9945	.9945	1.3717	
9	.6173	.6687					.4858
10	.7716	.823					.4858
11	.8573	.823					
12	.8402	.823					1.6842
13	.8402	.7202					1.668
14	.823	.7716					1.6842
15	.8059	.823					1.7652
16	.7888						1.8138
21				1.0288	1.1831		
22			.8916	1.0974	.9945		
23		.5144	.823	1.0631	1.0288		
24			.5487	.8573	1.0288	1.0631	
Max	.8573	.823	.8916	1.0974	1.2003	1.3717	1.8138
Min	.6173	.5144	.5487	.8573	.9945	1.0631	.4858
Avg	.7930	.7459	.6323	.9431	1.0802	1.1660	1.3696

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074007 / 33 KV DASARKHED S/S

Feeder No / Name : 207 / 11 KV DUPESHWAR W/S NON SHEDDABLE WATER SUPPLY AND
EXPRESS. Feeder KV- 11 / UTILITY
OUTGOING

DATE	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0514	.0686	.0648	.0686
2	.0514	.0514	.0686	.0648	.0686
3	.0514	.0514	.0686	.0648	.0686
4	.0514	.0514	.0686	.0648	.0686
5	.0514	.0514	.0686	.0648	.0686
6	.0514	.0514	.0686	.0648	.0686
7	.0686	.0686	.0686	.0648	.0686
8	.0686	.0686	.0686	.0648	.0686
9	.0686	.0686	.0648	.0648	
10	.0514	.0686	.081	.0686	
11	.0686		.0486	.0686	
12	.0686		.0486	.0686	
13	.0686		.0486	.0686	
14	.0686		.0486	.0686	
15	.0686		.0648	.0686	
16	.0686		.0648	.0686	
17	.0514		.0486	.0686	
18	.0686	.0514	.0486	.0686	
19	.0686	.0514	.0486	.0686	
20	.0686	.0686	.0486	.0686	
21	.0686	.0686	.0486		.0486
22	.0686	.0686	.0486	.0686	.0486
23	.0514	.0686	.0486	.0686	.0486
24	.0686	.0514	.0686	.0648	.0686
Max	.0686	.0686	.081	.0686	.0686
Min	.0514	.0514	.0486	.0648	.0486
Avg	.0622	.0595	.0595	.0669	.0636

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074007 / 33 KV DASARKHED S/S

Feeder No / Name : 408 / 33 KV KARTICK PAPER EXP NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1132	.1029	.1029	.1029	.1132	.1029
2		.1132	.1029	.1029	.1029	.1132	.1029
3		.1132	.1029	.1029	.1029		.1029
4		.1132	.1029	.1029	.1029	.1132	.1029
5		.1132	.1029	.1029	.1029	.1132	.1029
6		.1132	.1029	.1029	.1029	.1086	.1029
7		.1132	.1029	.1029	.1029	.1132	.1029
8		.1132	.1029		.1029	.1132	.1029
9	.1132	.1029	.1029		.1029	.1132	.1132
10	.1132	.1029	.1029		.1029	.1543	.1132
11	.2263	.1029	.1029		.1132	.2572	.1132
12	.2263	.1029	.1029	.1029	.1132	.2058	.1132
13	.2263	.1029	.1029		.1132	.1543	.1132
14	.2263	.1029	.1029	.1029	.1132	.1543	.1132
15	.2829	.1029	.1029		.1698	.1543	.0972
16	.2829	.1029	.1029		.1698	.1543	.1132
17	.1698	.1029	.1029	.1029	.3395	.2058	.1132
18	.2263	.1029		.1029	.2263	.2058	.1132
19	.1698	.1029	.1029	.1029	.2263	.2058	.1132
20	.1698	.1029	.1029	.1029	.2263	.2058	.1132
21	.1132	.1029	.1029	.1029	.1132	.1543	.1132
22	.1132	.1029	.1029	.1029	.1132	.2058	.0972
23	.1132	.1029	.1029	.1029	.1132	.1029	.1132
24	.1029	.1132	.1029	.1029	.1029	.1132	.1029
Max	.2829	.1132	.1029	.1029	.3395	.2572	.1132
Min	.1029	.1029	.1029	.1029	.1029	.1029	.0972
Avg	.1797	.1068	.1029	.1029	.1368	.1537	.1080

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074007 / 33 KV DASARKHED S/S

Feeder No / Name : 409 / 33 KV BIRLA COTSAN EXP NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.2805	1.8519	1.9547	2.0576	2.2634	2.1091
2		2.2634	1.8519	2.0576	2.0576	2.32	2.1605
3		2.32	1.8004	2.0576	2.0576	2.2068	2.2119
4		2.4331	1.8519	2.1091	2.1091	2.2262	2.2119
5		2.3765	2.0576	2.1091	2.2119	2.3765	2.3148
6		2.32	2.1605	2.0576	2.3148	2.4434	2.3663
7		2.3765	2.0062	2.3663	2.0576	2.3891	1.8519
8		1.8673	1.9033	2.0576	1.9547	2.2634	1.8004
9	1.7541	2.0062	2.0062	1.6975	2.1502	2.1176	1.9805
10	2.2634	2.0576	2.1605	1.9547	2.4331	2.0576	2.1502
11	2.3765	2.0576	2.3148		2.1502	1.8004	1.8461
12	2.3765	2.3663	2.3148		2.2634	1.8004	2.037
13	2.4331	2.2119	2.2634		2.2634	1.9547	2.1502
14	2.3765	2.2634	2.3148		2.2634	1.6461	2.2634
15	2.2634	2.3663	2.3148		2.3765	2.0576	2.2634
16	2.32	2.1605	2.4177	1.9033	2.3765	2.2119	2.32
17	2.1502	2.3148	2.3663	2.3148	2.2634	2.2634	2.2634
18	2.2068	2.2634	2.3148	2.1091	2.5463	2.3148	2.2634
19	2.2634	2.3148	2.3148	2.3148	2.6595	2.0576	2.2068
20	2.2634	2.0576	2.2119	2.2119	2.2262	2.1091	2.2634
21	2.32	1.9547		2.0576	2.2068	2.1605	
22	2.3765	1.749	2.1091	1.6975	2.037	1.8004	2.037
23	2.32	1.8004	1.8004	1.5947	1.9805	2.0576	1.9805
24	1.6461	2.4331		1.9547	1.9547	2.1502	2.0576
Max	2.4331	2.4331	2.4177	2.3663	2.6595	2.4434	2.3663
Min	1.6461	1.749	1.8004	1.5947	1.9547	1.6461	1.8004
Avg	2.2319	2.1923	2.1231	2.0305	2.2072	2.1270	2.1352

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074046 / 33 KV MALKAPUR S/S

Feeder No / Name : 201 / 11 KV HARIKIRAN MLK SHEDDABLE URBAN
SDN(2887) Feeder KV- 11 /
OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9589	2.0698	1.587	1.6632	1.7741	1.7364	1.6263
2	1.848	1.9959	1.4937	1.5708	1.7002	1.6804	1.5364
3	1.5524	1.6632	1.3817	1.4784	1.6461	1.5684	1.4632
4	1.4784	1.5893	1.307	1.423	1.6095	1.4937	1.4045
5	1.4784	1.5524	1.2136	1.3491	1.5565	1.4415	1.3306
6	1.4045	1.2936	1.1576	1.2752	1.448	1.3535	1.2382
7		1.3676	1.1157	1.1946	1.3032	1.1765	1.2254
8	1.3032	1.3306	1.0317	1.1946	1.267	1.1706	1.2012
9	1.307	1.2936	1.1641	1.2803	1.267	1.2437	1.1888
10	1.4784	1.2936	1.2308	1.3937	1.5181	1.448	1.4449
11	1.6263	1.6827	1.3032	1.5565	1.701	1.6095	1.4632
12	1.8111	1.7924	1.3535	1.7193	1.7193	1.5729	1.5729
13	1.848	1.9035	1.4632	1.8656	1.8296	1.6095	1.5912
14	1.9959	1.9959	1.4632	1.8656	1.9404	1.7558	1.6095
15	2.0698	2.1253	1.5364	1.9022	2.0144	1.848	1.7375
16	2.0328	2.0144	1.5364	1.9022	2.0144	1.848	1.829
17	1.9753	1.9035	1.4299	1.9387	1.8461	1.8656	1.6651
18	1.829	1.6095	1.2803	1.6827	1.6827	1.7002	1.4842
19	1.6461	1.5893	1.262	1.7002	1.6827		1.7375
20	1.6461	1.7372	1.423	1.7741	1.7372	1.7187	1.7741
21	1.9022	1.7372	1.5893	1.922	1.8111	1.701	1.7002
22	1.9959	1.7924	1.7556	2.0328	1.922	1.7187	1.7741
23	2.1068	1.8298	1.7741	1.9959	1.885	1.7372	1.7558
24	2.0698	2.0911	1.6804	1.8111	1.922	1.8111	1.6448
Max	2.1068	2.1253	1.7741	2.0328	2.0144	1.8656	1.829
Min	1.3032	1.2936	1.0317	1.1946	1.267	1.1706	1.1888
Avg	1.7550	1.7189	1.3972	1.6455	1.6999	1.6004	1.5416

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074046 / 33 KV MALKAPUR S/S

Feeder No / Name : 202 / 11 KV PRASHANT NAGAR MLK SHEDDABLE URBAN
SDN(2 Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8099	1.8656	1.6057	1.7187	1.4998	1.7551	1.2197
2	1.8099	1.829	1.531	1.6632	1.4632	1.6804	
3	1.7375	1.7558	1.4563	1.6078	1.4266	1.587	
4	1.7375	1.7558	1.363	1.5524	1.3394	1.475	1.4998
5	1.448	1.4632	1.3256	1.4415	1.3394	1.423	1.39
6	1.3756	1.2803	1.2437	1.2936	1.086	1.4045	1.2437
7	1.1584	1.2012	1.2437	1.1157	1.0136	1.1222	1.1403
8	1.0498	1.1458	1.1584	.8686	1.1584	1.0608	1.1041
9	1.134	1.1458	.9412	.8316	1.1946	.9877	1.1888
10	1.1643	1.1088	.9774	.8316	1.2489	1.0242	1.1403
11	1.2012	1.262	.8688	.8316	1.267	1.0974	1.134
12	1.1888	1.3717	1.0029	.8686	1.3169	1.086	1.134
13	1.2936	1.4449	1.0029	.9145	1.4083	1.1584	1.134
14	1.4784	1.5181	.9671	.9145	1.5912	1.267	1.2437
15	1.5524	1.5524	1.0029	.9145	1.6632	1.3032	1.2803
16	1.4784	1.4449	1.0029	1.0059	1.5729	1.3253	1.3535
17	1.4998	1.3717	.9694	1.134	1.4815	1.3394	1.2071
18	1.1888	1.086	.9328	1.0059	1.2437	1.0791	1.0136
19	1.1888	1.3169	1.0059	1.2308	1.1706		1.0136
20	1.2803	1.3676	1.1576	1.3169	1.386	.9511	1.1584
21	1.3169	1.5893	1.5339	1.3535	1.6095	1.5912	1.4118
22	1.6461	1.848	1.7741	1.6095	1.848	1.6461	1.5927
23	1.7924	1.9605	1.7741	1.6461	1.848	1.6078	1.6651
24	1.8823	1.885	1.7177	1.7187	1.5927	1.8111	1.5364
Max	1.8823	1.9605	1.7741	1.7187	1.848	1.8111	1.6651
Min	1.0498	1.086	.8688	.8316	1.0136	.9511	1.0136
Avg	1.4339	1.4821	1.2316	1.2246	1.4071	1.3384	1.2639

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074046 / 33 KV MALKAPUR S/S

Feeder No / Name : 203 / 11 KV WATER FILTTER EXP NON SHEDDABLE WATER SUPPLY AND
MLK S Feeder KV- 11 / OUTGOING UTILITY

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1294	.0747	.0381	.0381	.0358	.0381	.0381
2	.1294	.0747	.0381	.0381	.0358	.0381	.0914
3	.1294	.0747	.112	.0381	.0366	.0381	.0191
4	.037	.112	.112	.0381	.0366	.0934	.0924
5	.0185	.112	.0934	.0381	.0366	.0373	.0924
6	.0185	.112	.0747	.0381	.0362	.0924	.0924
7	.0183	.112	.0924	.0914	.0366	.0381	.0191
8	.128	.112	.0381	.0191	.128	.0381	.0914
9	.0366	.112	.1086	.1097	.1267	.0381	.0191
10	.0914	.112	.0185	.0381	.1109	.1109	.1307
11	.0381	.056	.1294	.128	.128	.0351	.0747
12	.0381	.1307	.1294	.0381	.0572	.1294	.0747
13	.0381	.0381	.037	.1097	.0572	.037	.0747
14	.0381	.1109	.0185	.0183	.0381	.0191	.0747
15	.056	.0381	.1109	.0183	.1307	.0381	.0747
16	.056	.0191	.0189	.0366	.0381	.0381	.0934
17	.0373	.1109	.0381	.1294	.0914	.0924	.112
18	.0747	.0381	.0191	.1294	.0381	.0914	.0187
19	.0747	.0381	.1109	.037	.1109	.0381	.0187
20	.0747	.112	.0914	.1267	.0381	.0381	.1267
21	.0747	.0381	.0191	.0358	.1109	.0381	.1267
22	.0747	.112	.0924	.1294	.0381	.1097	.0189
23	.0747	.0381	.0381	.0362	.0381	.0381	.0362
24	.1294	.0747	.112	.0924	.0358	.0381	.1097
Max	.1294	.1307	.1294	.1294	.1307	.1294	.1307
Min	.0183	.0191	.0185	.0183	.0358	.0191	.0187
Avg	.0673	.0818	.0705	.0647	.0654	.0560	.0717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288]

BU 2887

Substation No/ Name :- 074046 / 33 KV MALKAPUR S/S

Feeder No / Name : 401 / 33 kv incommer APDRP
Feeder KV- 33 / INCOMINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.8552	4.0181	3.3471	3.4568	3.4751	3.6037	2.8532
2	3.7466	4.0181	3.1276	3.2922	3.2579	3.4928	1.6289
3	3.3665	3.9095	3.0493	3.1276	3.1493	3.3819	1.5203
4	3.2579	3.8009	2.8829	3.0178	3.0407	3.1602	3.0807
5	2.9321	3.5837	2.6337	2.8532	3.0407	2.9081	2.8532
6	2.8235	3.4751	2.3891	2.5789	2.6063	2.8235	2.552
7	2.6063	3.0407	2.3388	2.4177	2.3891	2.364	2.364
8	2.6063	2.9321	2.1794	2.1176	2.524	2.3102	2.364
9	2.4451	2.7149	2.1262	2.2262	2.524	2.3348	2.3891
10	2.5789	2.6063	2.3137	2.3348	2.8475	2.6578	2.6863
11	2.8235	3.0087	2.4394	2.6063	3.0624	2.8235	2.9012
12	3.0407	3.2773	2.4451	2.6063	3.095	2.7641	2.9012
13	3.2579	3.3665	2.5514	2.7692	3.3122	3.0087	3.0087
14	3.3665	3.638	2.6337	2.9321	3.5294	3.0407	3.2579
15	3.5294	3.7466	2.6337	2.8778	3.8009	3.2579	3.3665
16	3.6923	3.5837	2.6337	5.9728	3.6923	3.2236	3.2579
17	3.5837	3.4385	2.4714	6.5158	3.4019	3.3311	3.4208
18	2.9321	2.7641	2.3102	5.647	2.9767	2.8778	2.5789
19	2.9321	2.9012	2.3891	3.1161	3.0087		3.0087
20	3.2579	3.1493	2.7435	3.2579	3.1493	2.7149	3.0407
21	3.4019	3.2579	3.1824	3.4751	3.8009	3.3122	3.2579
22	3.7311	3.5837	3.5837	3.6923	4.0181	3.4208	3.4751
23	4.0604	3.6923	3.6214	3.8089	3.7466	3.3665	3.4751
24	3.9095	4.0604	3.5665	3.5294	7.3846	3.638	3.3122
Max	4.0604	4.0604	3.6214	6.5158	7.3846	3.638	3.4751
Min	2.4451	2.6063	2.1262	2.1176	2.3891	2.3102	1.5203
Avg	3.2391	3.3987	2.7330	3.3429	3.3681	3.0355	2.8564

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074054 / 33 KV BELAD S/S

Feeder No / Name : 201 / 11 KV ANKUR INDUSTRIAL
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.8059	.9145	.8916	.4801	.8764	.6859
2	.8573	.7888	.9145	.7888	.4801	.8383	.6687
3	.9259	.7373	.9145	.6859	.463	.8383	.6344
4	1.0288	.7202	.9145	.6173	.463	.7621	.6173
5	1.0479	.7202	.9335	.5144	.4115	.7621	.6173
6	1.0479	.703	.9717	.5487	.4115	.7811	.6001
7	.5144	.4973	.743	.4801	.4801	.6668	.5658
8	.5487	.7202	.8383	.3944	.5144	1.0479	.5144
9	1.0802	.8764	.8745	.4572	1.105	1.0974	.9717
10	1.0974	1.0669	.9259	.5335		1.0631	.8764
11	.5144	.9259	.9431	.5144	.8573	1.0974	.9907
12	1.046	1.0669	.9602	.5144	.8402	1.1317	.9526
13	1.0288	1.105	1.0288		.9145	1.0631	.9526
14	1.046	1.0479	.9602	.5144	.823	1.0631	.9526
15	1.0288	1.0098	.8573		.9774	1.0802	1.105
16	1.0631	1.0669	.7888		.9259	1.0974	1.0669
17	1.0288	1.0098	.8573		.9717	1.166	.8573
18	1.0974	.6287	.9088	.4458	.724	1.0288	.7621
19	1.0631	.8764	.8916	.463	.8764	.4973	.6173
20	1.0288	.8954	.8573	.3944	.9907	.7888	.6859
21	.9431	.9717	.8916	.4115	1.0098	.8059	.724
22	.8573	.9526	.9602	.4287	.9907	.7888	.743
23	.8745	.9145	.9602	.4458	.9526	.823	.9145
24	.9717	.823	.9145	.9259	.4973	.9145	.7888
Max	1.0974	1.105	1.0288	.9259	1.105	1.166	1.105
Min	.5144	.4973	.743	.3944	.4115	.4973	.5144
Avg	.9416	.8721	.9052	.5485	.7461	.9200	.7861

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288]

BU 2887

Substation No/ Name :- 074054 / 33 KV BELAD S/S

Feeder No / Name : 202 / 11 KV GHIRNI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.3601	.0953	.0762	.381	.0953	
2	.1029	.3772	.0953	.061	.3963	.0953	
3	.1029	.4287	.0953	.061	.4115	.0953	.2058
4		.3963	.0953	.061	.4268	.0953	.3086
5	.1029	.4572	.0953	.0762	.4572	.0953	.2896
6	.1029	.4877	.0762	.1372	.4725	.0953	.3963
7	.0857		.0762				
8	.0857		.0762				
9	.381		.5182	.5335		.2058	
10	.5144		.4877	.5335		.4268	
11	.3429		.4572	.5335		.442	
12	.5316		.381	.5335		.4572	
13	.4572		.3658		.0514	.4973	.0762
14	.442	.0762	.4115	.4115	.0686	.4572	.0762
15	.4268	.0762	.4572		.0686	.442	.0953
16	.442	.0953	.4268		.0686	.4268	.0953
17	.0857	.0953	.0686		.0953	.0343	.0857
18	.0857	.0762	.2743	.0857	.0953	.0343	.0857
19	.0857	.1143	.0762	.1029	.1143	.0343	
20	.0857	.1143	.0762	.12	.1143	.0686	.1143
21	.1715	.1143	.0914	.3086	.1143	.2572	.1143
22	.2058	.1143	.0914	.3601	.1143	.2743	.1143
23	.2743	.0953	.0762	.3353	.0953	.2896	.1143
24	.1029	.3429	.0953	.0762	.4287	.0953	.2286
Max	.5316	.4877	.5182	.5335	.4725	.4973	.3963
Min	.0857	.0762	.0686	.061	.0514	.0343	.0762
Avg	.2314	.2248	.2108	.2448	.2208	.2279	.1600

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288]

BU 2887

Substation No/ Name :- 074054 / 33 KV BELAD S/S

Feeder No / Name : 203 / 11 KV GHIRNI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3258	.3048	.3601	.3429	.3429	
2	.3429	.3086	.2858	.3772	.3601	.3429	
3	.3086	.3258	.2858	.3601	.3601	.3429	.2572
4	.3086	.3086	.2858	.3429	.3429	.3429	.2743
5	.3086	.2915	.3048	.3429	.3258	.3258	.2915
6	.3429	.2572	.2743	.3258	.3086	.3086	.2572
7	.2477	.2743	.2743	.2743	.2915	.3086	.2743
8	.0857	.3258	.3048	.3086	.2743	.3258	.3086
9	.2572	.3429	.2572	.3086	.2915	.3258	.3601
10	.3086	.3429	.2743	.3086		.2401	.3772
11	.2401	.3086	.3086	.2743	.3086	.2572	.3258
12	.3429	.2915	.2915	.2743	.3429	.2743	.3258
13	.3258	.2915	.3429		.3429		.3429
14	.3086	.3086	.3601	.3429	.3258	.2058	.3601
15	.3258	.3258	.3429		.381	.2401	.3429
16	.3258	.2743	.3258		.3429	.3258	.3429
17	.3086	.2915	.3258		.4458	.3772	.5716
18	.3258	.1905	.3086	.3772	.3944	.3429	.3429
19	.3429	.3086	.3429	.3944	.4115		.3601
20	.3429	.3601	.3353	.4287	.4458		.3772
21	.3258	.3601	.3601	.3944	.4115		.4001
22	.3086	.3258	.3601	.3772	.3772	.2743	.1143
23	.3258	.3086	.3258	.3601	.3429	.2572	.3429
24	.381	.3258	.3048	.3429	.3601	.3429	.2572
Max	.381	.3601	.3601	.4287	.4458	.3772	.5716
Min	.0857	.1905	.2572	.2743	.2743	.2058	.1143
Avg	.3077	.3073	.3120	.3438	.3535	.3052	.3276

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074054 / 33 KV BELAD S/S

Feeder No / Name : 204 / 11 KV Waghul Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.0857	.3201	.4115	.0857	.3353	.0762
2	.4191	.0686	.3048	.4458	.0857	.3201	
3	.4115	.0686	.3048	.5144	.0686	.3048	.0686
4	.5144	.0686	.3048	.5487	.0686	.3048	.0381
5	.5144	.0686	.3353	.4572	.0686	.3963	.0343
6	.5658	.0686	.5487	.4268	.0686	.6859	.0343
7		.0686			.0762		.0686
8		.0686			.0762		.0686
9		1.1431			.9259		
10		1.046					.5639
11		1.0288			1.0479		.8078
12		1.0288			.8573		.7011
13	.0686	.6516	.0457		.8954	.0857	.7621
14	.0686	.5944	.0457	.0381	.9526	.0857	.7773
15	.0686	.6097	.061		.7811	.0857	.6401
16	.0857	.5792	.061		.6097	.0857	.6859
17	.0857		.061			.0686	
18	.0857		.061	.0857		.0686	
19	.0857		.061	.1029		.0686	
20	.0857		.061	.1029		.0686	
21	.0857	.2743	.3506	.1029	.3201	.0514	.4763
22	.0857	.3048	.3963	.1029	.3506	.0686	.4763
23	.0857	.3201	.381	.0857	.3353	.0686	.4763
24	.3429	.0857	.3201	.4458	.0857	.3353	.0686
Max	.5658	1.1431	.5487	.5487	1.0479	.6859	.8078
Min	.0686	.0686	.0457	.0381	.0686	.0514	.0343
Avg	.2243	.4116	.2236	.2765	.4084	.1938	.3791

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074054 / 33 KV BELAD S/S

Feeder No / Name : 211 / 11 KV INCOMER I

Feeder KV- 11 / INCOMING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003	1.5261	1.3336	1.3717	1.046	1.2193	
2	1.2003	1.4918	1.3336	1.3375	1.1145	1.2003	
3	1.2003	1.5089	1.2955	1.2003	1.0974	1.2003	
4	1.166	1.4918	1.2574	1.2346	1.0802	1.1622	
5	1.1317	1.5432	1.2574	1.2003	1.0974	1.1622	
6	1.1317	1.4232	1.2765	1.1317	1.0974	1.1622	
7	.8002	.7888	1.0669	.7545	.8059	1.0098	
8	.8764	1.0802	1.1812	.6344	.7888	1.3908	
9	1.7147	1.3336	1.8004	1.166	1.3546	1.6975	
10	1.8861		1.749	1.2003		1.8519	1.3717
11	1.0288	1.3032	1.7147	1.1831	1.3336	1.9204	1.2689
12	1.8861	1.286	1.6975	1.2003	1.2765	2.0576	1.4098
13	1.8861	1.3032	1.8347		1.2765	1.6118	1.4289
14	1.869	1.3032	1.6461	1.1145	1.467		1.4289
15	1.8519	1.3032	1.5947		1.4289		1.4403
16	1.8861	1.2517	1.5604		1.4098		1.3546
17	1.4575	1.2346	1.4746		1.3203	.1543	1.5242
18	1.3717	.8764	1.286	.7373	1.1241	1.4232	1.1431
19	1.5432	1.1431	1.3375	.7373	1.1431	.5658	1.046
20	1.5089	1.2346	1.2689	.7545	1.3717	.6516	1.1431
21	1.4918	1.2517	1.2346	.9431	1.448		1.1812
22	1.4232	1.4289	1.3203	1.0288	1.4098		1.2193
23	1.5089	1.3908	1.2689	1.0802	1.3527		1.4098
24	1.3527	1.5432	1.3336	1.3032	1.0288	1.2384	
Max	1.8861	1.5432	1.8347	1.3717	1.467	2.0576	1.5242
Min	.8002	.7888	1.0669	.6344	.7888	.1543	1.046
Avg	1.4322	1.3061	1.4218	1.0657	1.2119	1.2600	1.3121

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074054 / 33 KV BELAD S/S

Feeder No / Name : 212 / 11 KV INCOMER II

Feeder KV- 11 / INCOMING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.0686	.3201	.4115	.0762	.3353	.7373
2	.381	.0686	.3048	.4458	.0686	.3201	.6859
3	.4572	.0686	.3048	.5144	.0686	.3048	1.0802
4	.5716	.0686	.3048	.5487	.0686	.3048	1.2517
5	.5716	.0686	.3353	.5144	.0686	.3963	1.2346
6	.5658	.0686	.5487	.4801	.0686	.6859	1.2174
7		.0686			.0762		.8059
8		.0686			.0762		.7888
9		1.0288			.9259		1.3336
10		1.1622					.5639
11		1.0288			1.0288		.8078
12		.8573			.9145		.7011
13	.0762	.6344			.9526	.0857	.7621
14	.0953	.5944	.0514	.0381	.8764	.0857	.7773
15	.0953	.6097	.0686		.8002	.0857	.6401
16	.0857	.5792	.0686		.7621	.0857	.6859
17	.0857		.0686			.0857	.7621
18	.0857		.0686	.1029		.0686	
19	.0857		.0686	.1029		.0686	
20	.0857		.0686	.12		.0762	
21	.0857	.2743	.3506	.0953	.3201	1.0802	.4954
22	.0857	.3048	.4458	.0857	.3506	1.2517	.4763
23	.0857	.3201	.4287	.1029	.3353	1.2517	.4763
24	.3429	.0686	.3201	.463	.0686	.3353	1.2689
Max	.5716	1.1622	.5487	.5487	1.0288	1.2517	1.3336
Min	.0762	.0686	.0514	.0381	.0686	.0686	.4763
Avg	.2325	.4006	.2427	.2876	.4161	.3838	.8358

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074054 / 33 KV BELAD S/S

Feeder No / Name : 401 / 33 KV INCOMER I

Feeder KV- 33 / INCOMING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.4918	1.3717	1.3889	1.1317	1.3146	
2	1.2574	1.4403	1.3717	1.3375	1.2346	1.3146	
3	1.2574	1.3889	1.3146	1.1831	1.1831	1.3146	
4	1.2574	1.4403	1.2574	1.2346	1.1831	1.3146	
5	1.2574	1.3889		1.1831	1.1317	1.2574	
6	1.3146	1.4403	1.4289	1.1317	1.0802	1.2574	
7	.8573	.7716	1.086	.7716	.8745	1.0288	
8	1.1317	1.0288	1.2003	.6687	.823	1.3717	
9	1.8004	1.2574	1.6975	1.1831	1.3375	1.8519	
10	1.6975	1.3146	1.6461	1.2346		1.8519	1.3717
11	1.1317	1.286	1.5947	1.1831	1.3717	2.0576	1.3375
12	1.9033	1.3375	1.6975	1.1831	1.3146	2.1091	1.4861
13	1.8519	1.3889	1.6975		1.4861	1.6461	1.4861
14	1.8519	1.286	1.6461	1.2574	1.4861	1.9033	1.4861
15	1.8004	1.3889	1.5947		1.4861	1.8519	1.4918
16	1.749	1.286	1.5432		1.4861	1.8004	1.4403
17	1.5432	1.2346	1.3889		1.3375	1.5432	1.4861
18	1.4403	.9145	1.3375	.823	1.2003	1.4918	1.3717
19	1.3889	1.2003	1.4403	.7716	1.2003	.7716	1.2574
20	1.3375	1.286	1.3375	.823	1.4861	.7716	1.3146
21	1.3889	1.286	1.286	1.0288	1.5432		1.3146
22	1.3375	1.5432	1.3375	1.0802	1.4861		1.3146
23	1.3375	1.4289	1.286	1.0802	1.4289		.4572
24	1.2346	1.4918	1.3717	1.2346	1.1831	1.3146	
Max	1.9033	1.5432	1.6975	1.3889	1.5432	2.1091	1.4918
Min	.8573	.7716	1.086	.6687	.823	.7716	.4572
Avg	1.4375	1.3051	1.4319	1.0891	1.2815	1.4828	1.3297

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074054 / 33 KV BELAD S/S

Feeder No / Name : 402 / 33 KV INCOMER II

Feeder KV- 33 / INCOMING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3201	.4115		.3658	.7716
2			.3201	.463		.3201	.6687
3			.3201	.5144		.3201	1.1317
4			.3201	.5658		.3201	1.1317
5			.3658	.5144		.4115	1.2346
6			.5487	.463		.6859	1.286
7							.8745
8							.823
9							1.3717
10							.5487
11							.823
12							.7316
13							.7773
14							.7773
15		.5944					.6859
16		.5944					.6859
18	.1715			.1543			
19				.1543			
20				.1715			
21		.2743	.3601		.3201		
22		.3201	.463		.3658	1.1831	
23		.3658	.463		.3658	1.286	
24	.3201		.3658	.463		.3658	1.3375
Max	.3201	.5944	.5487	.5658	.3658	1.286	1.3717
Min	.1715	.2743	.3201	.1543	.3201	.3201	.5487
Avg	.2458	.4298	.3847	.3875	.3506	.5843	.9212

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288]

BU 2887

Substation No/ Name :- 074091 / 33 KV SALIPURA SUB STATION

Feeder No / Name : 201 / 11KV SHIVAJI NAGAR MLK

SHEDDABLE URBAN

SDN(288 Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.448	1.4449	1.3676	1.2803	1.39	1.386	1.262
2	1.448	1.39	1.3306	1.2437	1.3535	1.3306	1.1888
3	1.3575	1.3535	1.2936	1.1888	1.2986	1.2936	1.134
4	1.267	1.3169	1.2567	1.134	1.2803	1.2936	1.0608
5	1.2308	1.3169	1.1827	1.0608	1.262	1.2567	1.0242
6	1.2197	1.2986	1.1458	.9877	1.2254	1.2197	1.0425
7	1.1827	1.2071	1.0903	1.0059	1.1706	1.1643	1.0608
8	1.1273	1.1827	1.0534	1.0242	1.1273		1.0791
9	1.0608	1.1458	1.0425	1.0317	1.0719	1.0974	1.086
10	1.086	1.1088	1.0059	1.0059	1.0349	1.0608	1.1222
11	1.0679	1.1273	.9877	1.0242	1.0903	.9877	1.1706
12	1.1584	1.1458	.9511	1.0059	1.1088	.9511	1.1222
13	1.1584	1.1827	.9877	1.0242	1.1827	.9877	1.086
14	1.1523	1.2197	1.0242	1.086	1.2197	1.0242	.9955
15	1.2437	1.2936	1.0608	1.1946	1.2752	1.0608	1.086
16	1.386	1.3306		1.1584	1.2752	1.0974	1.1584
17	1.3121	1.2936		1.1706	1.2752	1.134	1.1827
18	1.2803	1.2197	1.0608	1.1706	1.2567	1.2437	1.1523
19	1.3169	1.2936	1.0791	1.2012	1.2936		1.1888
20	1.4449	1.386	1.134	1.3535	1.3306	1.2803	1.2851
21	1.4815	1.4045	1.1888	1.3756	1.423	1.3169	1.3032
22	1.4083	1.4045	1.2071	1.4118	1.4969	1.3535	1.3756
23	1.4449	1.4415	1.2437	1.448	1.4969	1.3352	1.4148
24	1.4784	1.4815	1.386	1.3717	1.4266	1.4415	1.3352
Max	1.4815	1.4815	1.386	1.448	1.4969	1.4415	1.4148
Min	1.0608	1.1088	.9511	.9877	1.0349	.9511	.9955
Avg	1.2817	1.2912	1.1400	1.1650	1.2652	1.1962	1.1632

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074091 / 33 KV SALIPURA SUB STATION

Feeder No / Name : 202 / 11 KV MANGAL GATE MLK SHEDDABLE URBAN
 SDN(2887 Feeder KV- 11 /
 OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7013	1.5927	1.448	1.2803	1.5384	1.4842	1.2803
2	1.7013	1.4842	1.3756	1.2437	1.448	1.4118	1.1888
3	1.6289	1.448	1.3394	1.1888	1.3756	1.3032	1.0974
4	1.448	1.3394	1.3032	1.134	1.3394	1.267	1.0791
5	1.267	1.267	1.2308	1.0974	1.2308	1.1946	1.0242
6	1.1584	1.2489	1.1946	1.0608	1.1403	1.1222	.9877
7	1.1222	1.1403	1.086	.9877	1.086	1.0136	.9511
8	1.1403	1.1041	.9412	1.0242	1.0608		.9877
9	.9774	1.0136	.9877	1.0059	1.0317	.9511	.9412
10	1.0136	.9412	1.0974	.9593	1.0317	.9145	.8954
11	1.0387	1.0136	1.134	.905	1.0719	.9145	.8869
12	1.0745	1.086	1.1523	.9231	1.0498	.9145	.905
13	1.182	1.1584	1.134	.9412	1.1584	.9511	.9313
14	1.267	1.1946	1.0974	1.1765	1.267	.9877	1.0029
15	1.1765	1.2308		1.2851	1.3394	1.0242	1.086
16	1.1222	1.2308		1.2308	1.3394	1.0974	1.0498
17	1.086	1.1946		1.1765	1.267	1.134	1.0317
18	1.1041	1.1222	1.0608	1.1222	1.1584	1.1523	.9774
19	1.1403	1.1946	1.0974	1.1222	1.2308		.9955
20	1.3937	1.2851	1.0974	1.2308	1.267	1.2437	1.2127
21	1.448	1.3575	1.134	1.3032	1.448	1.3169	1.267
22	1.5565	1.4118	1.1706	1.4661	1.5746	1.4266	1.3253
23	1.6651	1.5023	1.2437	1.5927	1.6108	1.2803	1.4685
24	1.7013	1.7013	1.5023	1.4083	1.5927	1.5927	1.4083
Max	1.7013	1.7013	1.5023	1.5927	1.6108	1.5927	1.4685
Min	.9774	.9412	.9412	.905	1.0317	.9145	.8869
Avg	1.2964	1.2610	1.1823	1.1611	1.2774	1.1681	1.0826

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288]

BU 2887

Substation No/ Name :- 074091 / 33 KV SALIPURA SUB STATION

Feeder No / Name : 203 / 11 KV YASHODHAM MLK

SHEDDABLE URBAN

SDN(2887) Feeder KV- 11 /

OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1403	1.1222	.4656	.823	1.1041	1.0387	.9145
2	1.1403	1.0498	.4477	.7682	.9955	1.0387	.8779
3	1.1584	1.0136	.8596	.7316	.9593	1.0029	.8413
4	1.1222	.9774	.9313	.695	.905	.9671	.7682
5	1.086	.9412	.9134	.7316	.8145	.9313	.7316
6	1.0136	.905	.8954	.7682	.7421	.9313	.695
7	.9593	.8507	.8954	.7682	.7602	.8954	.6584
8	.8507	.8145	.8238	.7865	.7964		.7133
9	.8869	.8596		.7701	.8238	.8413	.6805
10	.8596	.8954		.7602	.8596	.823	.6805
11	.8417	.9134		.7602	.8775	.8048	.7059
12	.9313	.9313		.7602	.8775	.7682	.724
13	.985	.9313		.8145	.9313	.7865	.7421
14	1.0317	1.0029		.8954	1.0029	.8048	.7701
15	1.086	1.0745		1.0029	1.0566	.8048	.8326
16	1.1765	1.0745		.9955	1.0566	.823	.8145
17	1.086	1.0387		.9231	1.0387	.8413	.8688
18	.9231		.8962	.8688	1.0208	.8596	.8688
19	.9593		.8779	.8688	1.0029		.8869
20	1.0498		.8962	.9412	.985	.8962	.9412
21	1.086		.8962	.985	1.0387	.9511	.9671
22	1.1765		.9145	1.1104	1.1104	.9877	1.0387
23	1.1765	.4835	.8779	1.1104	1.1283	1.0059	1.0924
24	1.1403	1.1584	.4656	.7133	1.1222	1.0566	.9328
Max	1.1765	1.1584	.9313	1.1104	1.1283	1.0566	1.0924
Min	.8417	.4835	.4477	.695	.7421	.7682	.6584
Avg	1.0361	.9494	.8038	.8480	.9587	.9027	.8228

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074091 / 33 KV SALIPURA SUB STATION

Feeder No / Name : 211 / 11 KV INCOMER

Feeder KV- 11 / INCOMING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.3347	4.0787	3.1824	3.0178	3.914	3.658	3.1459
2	4.3347	3.8592	3.0727	2.9264	3.6397	3.5117	2.9264
3	4.1884	3.8043	3.219	2.7801	3.4751	3.2922	2.8898
4	3.8775	3.5848	3.1459	2.7435	3.3288	3.1459	2.7801
5	3.6214	3.4751	3.0727	2.652	3.1459	3.0727	2.7435
6	3.4019	3.3105	3.0361	2.5606	2.9813	3.0361	2.7069
7	3.1093	3.1093	2.8898	2.5972	2.8898	2.8349	2.6703
8	2.9995	3.0308	2.6337	2.6337	2.8645		2.6337
9	2.7618	2.8532	2.652	2.5882	2.7435	2.7069	2.4977
10	2.8416	2.7801	2.6886	2.5057	2.7435	2.6703	2.4796
11	2.8235	2.8898	2.7069	2.5606	2.8166	2.5972	2.3348
12	3.0588	2.9995	2.7069	2.5423	2.8532	2.5606	2.4072
13	3.1855	3.1093	2.7069	2.6244	3.1093	2.652	2.4434
14	3.3288	1.39	2.6703	3.0769	3.3288	2.7435	2.6063
15	3.4385	3.3288	2.7252	3.3484	3.5117	2.7801	2.8054
16	3.6961	3.3288	2.7801	3.2941	3.5117	2.8166	2.9864
17	3.5113	3.219	2.8349	3.219	3.4019	2.8532	3.0308
18	3.219	2.1582	2.9264	3.1093	3.2922	3.0178	2.8898
19	3.3288	2.4143	3.0178	3.1602	3.3288		2.9264
20	3.7129	2.5606	3.0727	3.3653	3.3653	3.2556	3.3288
21	3.8226	2.7435	3.1459	3.4932	3.7677	3.3288	3.4389
22	4.0055	2.963	3.219	3.8371	4.0103	3.4019	3.6561
23	4.0969	3.4385	3.2556	4.0181	4.0421	3.5848	3.7967
24	4.1518	4.1884	3.2922	3.7129	4.0238	3.914	3.4934
Max	4.3347	4.1884	3.2922	4.0181	4.0421	3.914	3.7967
Min	2.7618	1.39	2.6337	2.5057	2.7435	2.5606	2.3348
Avg	3.5355	3.1091	2.9439	3.0153	3.3371	3.0652	2.9008

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074091 / 33 KV SALIPURA SUB STATION

Feeder No / Name : 401 / 33 kv Incomer Salipura MLK NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 33 / INCOMING UTILITY

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.3896	4.3347	3.4751	3.5665	4.1701	4.0181	3.7311
2	4.3896	4.1152	3.3665	3.2922	3.8958	3.9095	
3	4.0604	4.0604	3.4751	3.0727	3.7311	3.8009	3.4019
4	3.8409	3.8409	3.3665	2.8532	3.6214	3.5837	3.1824
5	3.7311	3.7311	3.2579	2.7435	3.4019	3.3665	3.0727
6	3.5117	3.5665	3.2036	2.6337	3.1824	3.2579	2.8532
7	3.2922	3.2922	3.0407	2.6886	3.0727	3.0407	2.7435
8	3.1824	3.2156	2.8778	2.7435	3.1047		2.7435
9	2.963	2.9864	2.963	2.7149	2.8778	2.963	2.6063
10	3.0407	2.9321	3.0727	2.6886	2.9321	2.8532	2.6063
11	3.0407	3.0407	2.963	2.7435	2.9864	2.7435	2.6337
12	3.2579	3.1493	2.7435	2.7435	3.0407	2.524	2.6886
13	3.3665	3.3122	2.8532	2.8532	3.2579	2.7435	2.7149
14	3.5117	3.4208	3.7311	3.2579	3.4751	2.8532	2.8235
15	3.6214	3.5294	3.2922	3.5294	3.6923	3.0727	3.0407
16	3.8809	3.5294	3.4019	3.4751	3.6923	3.2922	3.2036
17	3.7146	3.4751	3.5117	3.4019	3.5837	3.4019	3.271
18	3.4019	2.4434	3.4019	3.2922	3.4751	3.4019	3.1276
19	3.5117	2.6063	3.4019	3.3265	3.5294		3.1824
20	3.9506	2.7692	3.5117	3.6214	3.5837	3.5117	3.6214
21	4.0604	2.9321	3.5117	3.7466	3.9095	3.6214	3.7311
22	4.3896	3.0407	3.7311	4.0724	4.1267	3.7311	3.9095
23	4.3896	3.638	3.786	4.2896	4.2896	3.8409	4.0295
24	4.3896	4.4445	3.5294	3.9506	4.2798	4.181	3.8409
Max	4.3896	4.4445	3.786	4.2896	4.2896	4.181	4.0295
Min	2.963	2.4434	2.7435	2.6337	2.8778	2.524	2.6063
Avg	3.7037	3.3919	3.3112	3.2209	3.5380	3.3506	3.1634

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074100 / 33KV JAMBHULDHABA SUBSTATION

Feeder No / Name : 201 / 11 KV GOULKHED SINGLE PHASING

FEEDER(SINGLE P Feeder KV- 11 /
OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.2286	.1509	.1715	.2477	.1677	.1311
2	.1715	.2286	.1509	.1715	.2286	.1677	.1311
3	.1715	.2286	.1509	.1715	.2286	.1677	.1311
4	.1715	.2286	.1509	.1715	.2286	.1981	.1311
5	.1715	.2477	.1509	.1886	.2667	.2286	.1311
6	.1886	.2286	.1677	.2515	.2667	.2743	.1475
7	.1867	.2096	.2033	.2241	.2286	.1981	.2294
8	.2427	.1905	.2427	.2054	.2286	.2058	.2622
9	.2054	.2286	.2033	.2054	.3887	.2096	.2949
10	.2054	.2267	.2096	.2033	.4049	.2096	.2439
11	.2614	.2915		.2195	.4049	.2096	.2134
12	.2427	.2949		.2561	.4049	.2286	.2743
13	.2987	.2785		.2743	.3887	.2286	.381
14	.3326	.2785		.2743	.3725	.2477	.3353
15	.3511	.285		.2896	.3563	.1905	.3048
16	.2957	.285		.3142	.3563	.1524	.2896
17	.2858	.2587	.2801	.3239	.2743	.1463	.2987
18	.2667	.2614	.3361	.3048	.2401	.2772	.3734
19	.3239	.2957	.3174	.362	.2915		.2987
20	.362	.3734	.3547	.381	.3429		.3734
21	.381	.1715	.2401	.362	.2439		.3077
22	.3239	.1844	.2229	.3239	.2134		.2591
23	.2667	.1475	.1886	.3048	.1981		.2591
24	.381	.2477	.1509	.1715	.2667	.1981	.1311
Max	.381	.3734	.3547	.381	.4049	.2772	.381
Min	.1715	.1475	.1509	.1715	.1981	.1463	.1311
Avg	.2608	.2458	.2151	.2553	.2947	.2056	.2472

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074100 / 33KV JAMBHULDHABA SUBSTATION

Feeder No / Name : 202 / 11 KV LONWADI SINGLE PHASING

FEEDER(SINGLE PH Feeder KV- 11 /
OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.2286	.1715	.1886	.1905	.1524	.218
2	.1543	.1905	.1715	.1886	.1905	.1524	.218
3	.1543	.1905	.1715	.1886	.1905	.1524	.218
4	.1543	.2096	.1715	.1886	.1905	.2134	.218
5	.1715	.2477	.1715	.2058	.2286	.2591	.218
6	.2572	.2096	.2229	.3521	.2286	.3658	.2347
7	.132	.1524	.1494	.168	.1524	.1219	.2683
8	.1307	.1524	.112	.168	.1524	.1372	.3018
9	.112	.381	.112	.1307	.421	.1524	.3353
10	.1494	.2753	.1524	.1494	.3725		.3353
11	.1867	.2429		.1307	.2949		.3048
12	.1867	.2458		.168	.2915		.1372
13	.2054	.2294		.168	.2915		.2439
14	.2241	.2294		.168	.3277	.1905	.2134
15	.2241	.2347		.1848	.3239	.2286	.1829
16	.2241	.218		.2054	.2753	.2286	.2439
17	.2096	.1867	.2241	.1905	.2058	.1867	.1307
18	.2096	.1867	.2241	.1905	.1715	.1867	.112
19	.2096	.2241	.2427	.2286	.2401		.2614
20	.3048	.2987	.3174	.3429	.2743		.3174
21	.3429	.1928	.2915	.3429	.2134		.2753
22	.3048	.1715	.2743	.3048	.1981		.2591
23	.2667	.1677	.2229	.2667	.1829		.2429
24	.1543	.2286	.1715	.1886	.2286	.1829	.2229
Max	.3429	.381	.3174	.3521	.421	.3658	.3353
Min	.112	.1524	.112	.1307	.1524	.1219	.112
Avg	.2010	.2206	.1986	.2087	.2432	.1941	.2381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074100 / 33KV JAMBHULDHABA SUBSTATION

Feeder No / Name : 203 / 11 KV KHAMKHED SINGLE PHASING

FEEDER(SINGLE P Feeder KV- 11 /
OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.1524	.0526	.0686	.1143	.061	.0514
2	.0514	.1334	.0566	.0686	.1143	.061	.0514
3	.0514	.1334	.0566	.0686	.1143	.061	.0514
4	.0514	.1334	.0526	.0686	.1143	.061	.0514
5	.0514	.1715	.0526	.0686	.1334	.0762	.0514
6	.0686	.1334	.0701	.1006	.1334	.0914	.0343
7	.1307	.1334	.132	.1307	.1334	.1219	.0514
8	.1494	.1334	.1132	.1307	.1334	.1372	.0686
9	.1307	.1143	.1132	.1307	.081	.1334	.0686
10	.1509	.0972	.1143	.1132	.081		.061
11	.1509	.081		.1494	.0648		.0762
12	.1698	.0819		.1494	.0648		.061
13	.1698	.0819		.168	.0648		.0762
14	.1698	.0819		.168	.0819	.1905	.0762
15	.1886	.0838		.1494	.081	.2096	.0914
16	.1886	.0838		.1494	.0972	.2286	.0914
17	.1905	.1698	.168	.1524	.1029	.1867	.1494
18	.1524	.1524	.168	.1334	.1029	.1494	.112
19	.1524	.1698	.2241	.2096	.1715		.1867
20	.2286	.2096	.2427	.2286	.2058		.2241
21	.2286	.0716	.0857	.2286	.0762		.0648
22	.1905	.0526	.0686	.1905	.061		.0648
23	.1524	.0514	.0686	.1524	.061		.0648
24	.0514	.1524	.0526	.0686	.1524	.061	.0686
Max	.2286	.2096	.2427	.2286	.2058	.2286	.2241
Min	.0514	.0514	.0526	.0686	.061	.061	.0343
Avg	.1363	.1192	.1051	.1353	.1059	.1220	.0812

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074100 / 33KV JAMBHULDHABA SUBSTATION

Feeder No / Name : 211 / 11 KV INCOMER

Feeder KV- 11 / INCOMING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
20					.7202	
23		.3772				
24	.3772	.6287	.3856	.4287	.6478	.442
Max	.3772	.6287	.3856	.4287	.7202	.442
Min	.3772	.3772	.3856	.4287	.6478	.442
Avg	.3772	.5030	.3856	.4287	.684	.442

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074100 / 33KV JAMBHULDHABA SUBSTATION

Feeder No / Name : 401 / 33 KV INCOMER TO NON SHEDDABLE WATER SUPPLY AND
 JAMBHULDHABA Feeder KV- 33 / UTILITY
 INCOMING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3923	.1943	.3736	.4227	.1886	.3887	
2	.3973	.1715	.3736	.4227	.1829	.3887	
3	.3973	.1715	.3687	.4177	.1829	.3887	
4	.3923	.1829	.3834	.4177	.1829	.4252	
5	.4074	.2115	.4276	.4525	.2	.5213	
6	.4829	.1943	.5309	.6996	.2	.7545	
7	.1738	.1772	.1846	.1683	.1829	.1738	
8	.2009	.1658	.1811	.1738	.1829	.1595	
9	.1683	.7716	.1629	.1629	.8254	.1658	
10	.1866	.6452	.1715	.1629	.8017	.1143	
11	.2085	.6689		.1846	.778	.1143	
12	.214	.6452		1.6832	.8302	.12	.5487
13	.2359	.5977		.2172	.816	.12	.7682
14	.2552	.5713		.2281	.7828	.2115	.7133
15	.2715	.6024		.2281	.7021	.1829	.6539
16	.2606	.6073		.2335	.7218	.1829	.6767
17	.2629	.2226	.2226	.2401	.2058	.1719	.2009
18	.2401	.1996	.2552	.2343	.18	.2172	.2443
19	.2515	.2359	.2552	.2743	.2263		.2661
20	.3144	.3049	.3204	.3315	.2829		.3095
21	.3258	.4575	.5122	.3258	.4938		.6736
22	.2743	.3981	.4873	.2629	.4664		.6215
23	.2172	.3692	.4575	.2172	.4481		.593
24	.3834	.2	.3687	.4227	.2	.3887	
Max	.4829	.7716	.5309	1.6832	.8302	.7545	.7682
Min	.1683	.1658	.1629	.1629	.18	.1143	.2009
Avg	.2881	.3736	.3354	.3577	.4277	.2732	.5225

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 077001 / 132 KV MALKAPUR S/S

Feeder No / Name : 201 / 11KV ZODGA AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	.4877
Max	.4877
Min	.4877
Avg	.4877

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 077001 / 132 KV MALKAPUR S/S

Feeder No / Name : 204 / 11 KV DAND EXPRESS MLK
SDN(288 Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	01-JUN-18
HR	Load (MW)
24	.3601
Max	.3601
Min	.3601
Avg	.3601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 077001 / 132 KV MALKAPUR S/S

Feeder No / Name : 205 / 11 KV DEODHABA AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 077001 / 132 KV MALKAPUR S/S

Feeder No / Name : 206 / 11 KV MALKAPUR TOWN (MLK SHEDDABLE URBAN
SDN 2 Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.442
Max	.442
Min	.442
Avg	.442

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 077001 / 132 KV MALKAPUR S/S

Feeder No / Name : 207 / 11 KV INDISTRIAL MLK
SDN(2887) Feeder KV- 11 /
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18
HR	Load (MW)
24	.3258
Max	.3258
Min	.3258
Avg	.3258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 077001 / 132 KV MALKAPUR S/S

Feeder No / Name : 209 / 11 KV DEODHABA GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18
HR	Load (MW)
24	.4725
Max	.4725
Min	.4725
Avg	.4725

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 077001 / 132 KV MALKAPUR S/S

Feeder No / Name : 210 / 11 KV ZODGA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.4572
Max	.4572
Min	.4572
Avg	.4572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 077001 / 132 KV MALKAPUR S/S

Feeder No / Name : 403 / 33 KV NANDURA INOUT LINE NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	1.8519
Max	1.8519
Min	1.8519
Avg	1.8519

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 077001 / 132 KV MALKAPUR S/S

Feeder No / Name : 405 / 33 KV MALKAPUR INPUT TO NON SHEDDABLE WATER SUPPLY AND
TOWN Feeder KV- 33 / INCOMING UTILITY

DATE	01-JUN-18
HR	Load (MW)
24	1.286
Max	1.286
Min	1.286
Avg	1.286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074021 / 33 KV SUB STATION KINHOLA

Feeder No / Name : 201 / 11 KV TAPOWAN AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0663		.0663	.112		.0514	
2	.0663		.0663	.112		.0514	
3	.0663		.0995	.112		.0343	
4	.0829		.0995	.1494		.0343	
5	.0829		.1326	.1867			
6	.116		.1658	.2218			
7						.2572	
9		.1326			.3561		.3511
10		.1989			.2743		.2957
11		.1989			.3086		.2957
12		.1989			.2743		.3326
13		.1658			.1715		.2957
14		.1658			.1715		.2587
15		.1326			.1372		.1848
16		.1326			.1715		.3326
21		.0497	.0934		.0343		.0554
22		.0663	.0934		.0514		.0554
23		.0663	.0934		.0857		.0739
24	.0663		.0663	.0934		.0514	
Max	.116	.1989	.1658	.2218	.3561	.2572	.3511
Min	.0663	.0497	.0663	.0934	.0343	.0343	.0554
Avg	.0781	.1371	.0977	.1410	.1851	.08	.2301

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074021 / 33 KV SUB STATION KINHOLA

Feeder No / Name : 202 / 11 kv panhera ag feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258	.3258	.0995	.0934	.3391	.0686	.1029
2	.3086	.3086	.0995	.0747	.4409	.0857	.12
3	.3086	.2915	.0995	.0739	.4409	.0686	.1029
4	.2915	.3086	.0995	.0747	.5087	.0686	.0857
5	.3086	.2915	.0995	.0739	.6104	.0686	.1029
6	.3086	.3258		.0747	.5596	.0857	
9	.2652		.431			.7716	
10	.3601		.4805			.7202	
11	.3086					.6687	
12	.3601			.6443		.703	
13	.3772			.6783		.6859	
14	.3944			.6443		.4801	
15	.4115		.0924	.5087		.5144	
16	.4287		.7392	.4748		.5658	
20	.0857	.0663	.0924	.0086	.0686		.0747
21	.1715	.0663	.112	.2543	.0686	.0857	.0934
22	.1715	.0663	.112	.2543	.0857	.0857	.0924
23	.1715	.0732	.0924	.2543	.0857	.0857	.0934
24	.3429	.3429	.0663	.0934	.2543	.0857	.0857
Max	.4287	.3429	.7392	.6783	.6104	.7716	.12
Min	.0857	.0663	.0663	.0086	.0686	.0686	.0747
Avg	.3000	.2243	.1940	.2675	.3148	.3277	.0954

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074021 / 33 KV SUB STATION KINHOLA

Feeder No / Name : 203 / 11 kv D,badhe ag feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0663	.9259		.0739	.8478	
2	.0663	.9602		.0739	.9496	
3	.0663	.9945		.0739	1.1191	
4	.0663	.9602		.0739	1.1869	
5	.0663	.9774		.0739	1.2209	
6		.9602		.0739	1.2209	
9	.7956		1.5249	1.4243		1.5089
10	1.2346		1.5524	1.3565		2.0576
11	1.2689		1.6263	1.2887		1.7147
12	1.2346		1.4937	1.2887		1.6804
13	1.2003		1.5154	1.1869		1.8519
14	1.166		1.3443	1.0174		1.869
15	1.0288		1.4415	.8817		1.7833
16	.8916		.1294	1.0174		1.0974
20	.0686		.0924	.0848		
21	.823		.0934	.6104		
22	.8059		.0924	.7461		
23	.7888		.0924	.6783		
24	.0663	.8573		.0924	.8478	
Max	1.2689	.9945	1.6263	1.4243	1.2209	2.0576
Min	.0663	.8573	.0924	.0739	.8478	1.0974
Avg	.6503	.9480	.9165	.6377	1.0561	1.6954

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074021 / 33 KV SUB STATION KINHOLA

Feeder No / Name : 204 / 11 kv D,Badhe GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9877	.8916	.8413	.924	.8478	.823	.823
2	.9511	.9259	.8413	.924	.9496	.8573	.8573
3	.9511	.9431	.8413	.9425	1.0059	.9431	.9431
4	.9877	.9602	.8779	.961	1.1191	.9259	.9259
5	1.0242	.9945	.9511	.9979	1.153	.823	.8402
6	1.134	1.0288	1.0242	1.1016	.9665	1.0802	.823
7	1.0608	.9602	.9145	.9896		.9259	.7888
8	.9877	.7888	.8779	.8478	.78	.8059	.6859
9	.9145	.7716	.7682	.7461	.7122	.7888	.6535
10	.8402	.8048	.7282	.6783	.703	.7716	.6722
11	.8573	.8048		.6783	.6516	.7373	.6348
12	.8745	.8413	.7468	.7122	.6173	.7373	
13	.8573	.8413	.7468	.7122	.0686	.7202	.5975
14	.8402	.8413	.7842	.7122	.6687	.7373	.6653
15	.823	.8413	.8962	.7122	.7202	.7545	.8215
16	.8573	.8779	1.0082	.9496	.823	.8573	.8871
17	.9088	.9877	1.0829	1.0174	.9259	1.046	.9896
18	.9602	.9877	1.1949	1.0513	1.0288	1.1317	1.0829
19	1.0288	1.0242	1.2136	1.1191	1.0117		1.1576
20	1.2003	1.134	1.251	1.153	1.1317		1.2696
21	1.1145		1.1949	1.0852	1.1145		1.1949
22	.9945	.9877	1.1576	.9326	1.0802	.7373	1.1203
23	.9259	.9511	.9979	.7888	1.046	.7202	1.0269
24	.9568	.8573	.9145	.9709	.78	.7716	.7716
Max	1.2003	1.134	1.251	1.153	1.153	1.1317	1.2696
Min	.823	.7716	.7282	.6783	.0686	.7202	.5975
Avg	.9599	.9151	.9502	.9045	.8654	.8426	.8797

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074021 / 33 KV SUB STATION KINHOLA

Feeder No / Name : 205 / 11 KV PANHERA GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.3258	.2926	.3734	.4409	.3429	.3944
2	.3658	.3086	.2926	.3881	.4409	.3772	.4115
3	.4024	.2915	.3292	.3734	.4409	.4115	.4458
4	.439	.3429	.4024	.4066	.5087	.4458	.4287
5	.4755	.3772	.439	.5228	.5087	.4801	.4801
6	.5853	.4458	.4755	.5975	.5426	.4801	.5487
7	.5487	.5144	.5487	.5601	.5426	.4973	.4801
8	.5121	.4801	.4755	.048	.5087	.4458	.4115
9	.439	.439	.3658	.4409	.407	.3772	.3734
10	.2915	.3658	.2987	.3391	.3258	.3086	.2801
11	.2572	.3292	.2987	.2713	.3429	.2743	.2987
12	.2743	.3292	.2987	.2713	.3086	.2229	.2801
13	.2915	.2926	.3174	.3052	.2915	.2401	.3361
14	.3086	.2926	.3174	.3353	.3258	.2229	.3361
15	.2915	.3292	.3361	.373		.2401	.3921
16	.2743	.3658	.5175	.373	.3772	.3086	.4108
17	.3429	.439	.5601	.373	.4458	.3429	.5228
18	.3429	.5121	.5601		.4801	.3772	.5601
19	.4801		.5601	.5596	.5316	.4115	.5914
20	.5316	.5487	.5788	.5087	.4973	.4458	.5975
21	.463	.4755	.5601	.4748	.4801	.4801	.5228
22	.4287	.439	.4481	.3768	.4115	.5144	.4481
23	.3772	.3658	.3696	.373	.3772	.3601	.4481
24	.3658	.3429	.3292	.3734	.3391	.3086	.3258
Max	.5853	.5487	.5788	.5975	.5426	.5144	.5975
Min	.2572	.2915	.2926	.048	.2915	.2229	.2801
Avg	.3939	.3892	.4155	.3921	.4294	.3715	.4302

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074021 / 33 KV SUB STATION KINHOLA

Feeder No / Name : 206 / 11 Kv Tapowan Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 /
OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.2058	.1829	.1886	.2035	.2058	.2401
2	.2195	.2058	.1829	.1867	.2035	.2229	.2743
3	.2263	.2058	.1829	.1867	.2374	.2401	.2915
4	.2561	.2401	.2195	.2241	.2713	.2401	.3086
5	.2926	.2401	.2561	.2801	.3052	.2572	.3258
6	.2926	.2572	.2926	.8775	.2883	.2743	.2572
7	.3292	.2058	.2926	.3174	.2374	.2229	.3258
8	.2926	.1715	.2561	.2374	.2035	.1715	.2058
9	.2561	.1543	.2195	.2374	.2035	.1543	.168
10	.2058	.2195	.1867	.2374	.1543	.1715	.1307
11	.1543	.1829	.1867	.2035	.1372	.1372	.1494
12	.12	.1829	.1867	.2035	.12	.1372	.1867
13	.1029	.1829	.2241	.2035	.1372	.12	.1867
14	.12	.1829	.2054	.2035	.1372	.1372	.1867
15	.1372	.1829	.1867	.2035	.1543	.0154	.1867
16	.1543	.2195	.2218	.2035	.1715	.1715	.1867
17	.2401	.2195	.2427	.2035	.1886	.2058	.2241
18	.2401	.2743	.2801	.2374	.2401	.2401	.2987
19	.2743	.3109	.3361	.2713	.2743	.2743	.3361
20	.3258	.3292	.3547	.0309	.2915	.3086	.3361
21	.2572	.2926	.3734	.3391	.2572	.3086	.2987
22	.3086	.2561	.2614	.2374	.1715	.2229	.2801
23	.2572	.2195	.2614	.2035	.2572	.2572	.2614
24	.2195	.2058	.1829	.2241	.1696	.2058	.2058
Max	.3292	.3292	.3734	.8775	.3052	.3086	.3361
Min	.1029	.1543	.1829	.0309	.12	.0154	.1307
Avg	.2292	.2228	.2407	.2476	.2090	.2043	.2438

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074027 / 33 KV SUB STATION MOTALA

Feeder No / Name : 201 / 11 KV NALGANAGA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.6516	.0373	.0377	.8573	.0343	1.2003
2	.0343	.6516	.0373	.0377	1.0288	.0343	1.2003
3	.0343	.6516	.0373	.0343	1.0288	.0343	1.2346
4	.0343	.7716	.0373	.0343	1.0288	.0343	1.2689
5	.0343	.823	.0373	.0343	1.2003	.0343	1.5089
6	.0343	.8916	.0373	.0343	1.406	.0343	1.6975
7	.0343						
8	.0343						
9	.0343		1.3203	1.4575		.3429	
10	1.1145		1.3032	1.6289		.4115	
11	1.2003		1.286	1.406			
12	1.1145		1.2003	1.4575			
13	1.0288		1.2003	1.3717			
14	.9431		1.166	1.2003		1.9204	
15	.9431		1.0288	1.286		1.8861	
16	.9259		1.1145	1.3032		1.8176	.583
19	.0343	.0373	.0343	.0343	.0343	.056	.0343
20	.0343	.0373	.0343	.0343	.0343	.0187	.0343
21	.6859	.0373	.0343	.3429	.0343	1.286	.0343
22	.6859	.0373	.0343	.3772	.0343	1.2517	.0343
23	.6859	.0373	.0343	.3772	.0343	1.2003	.0343
24	.0343	.6687	.0373	.0343	.5144	.0343	1.2003
Max	1.2003	.8916	1.3203	1.6289	1.406	1.9204	1.6975
Min	.0343	.0373	.0343	.0343	.0343	.0187	.0343
Avg	.4427	.4414	.5026	.6262	.6030	.6136	.7743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074027 / 33 KV SUB STATION MOTALA

Feeder No / Name : 202 / 11 KV TARAPUR AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0686	.0373	.0171	.1715	.0171	.0716
2	.0343	.0686	.0373	.0171	.1715	.0171	.0716
3	.0343	.0686	.0373	.0171	.1715	.0171	.0716
4	.0343	.1029	.0373	.0171	.2058	.0171	.1063
5	.0343	.1029	.0373	.0171	.2058	.0171	.1402
6	.0343	.1372	.0373	.0171	.2058	.0171	.2915
7	.0343						
9	.1372		.2401	.1886		.2229	
10	.1543		.2401	.2401		.3086	
11	.2058		.2401	.2229		.2401	
12	.1227		.1715	.1886		.1372	
13	.1578		.1715	.1715		.12	
14	.1578		.1715	.08		.1372	
15	.1402		.1715	.1029		.12	
16	.1227		.1715	.1372		.2058	
19	.0171	.0373	.0171	.0343	.0171	.0187	.0171
20	.0171	.0373	.0171	.0343	.0171	.0187	.0171
21	.0343	.0373	.0171	.1372	.0171	.0876	.0343
22	.0514	.0373	.0171	.1372	.0171	.0895	.0343
23	.0686	.0373	.0171	.1715	.0171	.0895	.0343
24	.3048	.0857	.0373	.0171	.1715	.0171	.0716
Max	.3048	.1372	.2401	.2401	.2058	.3086	.2915
Min	.0171	.0373	.0171	.0171	.0171	.0171	.0171
Avg	.0920	.0684	.0962	.0983	.1157	.0958	.0801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074027 / 33 KV SUB STATION MOTALA

Feeder No / Name : 203 / 11 KV RAJUR AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.0343	.1578	.1886		.3601	
2	.1715	.0343	.1578	.1886		.3258	
3	.1715	.0343	.1402	.1886		.3772	
4	.1715	.0343	.1753	.3429		.4287	
5	.2058	.0343	.2058	.3772		.463	
6	.2058	.0343	.3429	.4458		.5144	
9		.2572					
10		.2915			.4115		.6344
11		.2743			.3429		.6173
12					.3601		.5487
13		.2743			.4115		.3772
14		.3601			.4458		.4115
15		.3429			.4287		.3429
16		.2915			.3772		.3429
19	.0343	.056	.0343	.0343	.0171	.056	.0343
20	.0343	.056	.0343	.0343	.0171		.0343
21	.0343	.1753	.1886		.3258		.1886
22	.0343	.1753	.2401		.3601		.2572
23	.0343	.1753	.1886		.3429		.2915
24	.1715	.0343	.1578	.1886		.3429	
Max	.2058	.3601	.3429	.4458	.4458	.5144	.6344
Min	.0343	.0343	.0343	.0343	.0171	.056	.0343
Avg	.1201	.1563	.1686	.2210	.3201	.3585	.3401

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074027 / 33 KV SUB STATION MOTALA

Feeder No / Name : 204 / 11 KV TARAPUR GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0171	.0373	.0171	.0343	.0343	.0373
2	.0343	.0171	.0373	.0171	.0343	.0343	.0373
3	.0343	.0171	.0373	.0171	.0343	.0343	.0187
4	.0343	.0171	.0373	.0171	.0343	.0343	.0187
5	.0343	.0171	.0187	.0171	.0343	.0343	.0187
6	.0343	.0171	.0187	.0171	.0171	.0343	.0187
7	.0171	.0171	.0187	.0171	.0171	.0343	.0187
8	.0171	.0171	.0373	.0171	.0171	.0171	.0187
9	.0171	.0171	.0187	.0171		.0171	.0171
10	.0187	.0171	.0171	.0343		.0171	.0171
11	.0187	.0171	.0171	.0171		.0171	.0171
12	.0187	.0171	.0171	.0171		.0171	.0171
13	.0373	.0171	.0171	.0171	.0373	.0171	.0171
14	.0373	.0171	.0171	.0343	.0373	.0171	.0171
15	.0377		.0171	.0171	.0187	.0343	.0171
16	.0187	.0343	.0171		.0373	.0171	.0171
17	.0187	.0343	.0171	.0514	.0373	.0171	.0171
18	.0171	.0373	.0343	.0343	.0514	.0187	.0343
19	.0343	.056	.0343	.0343	.0514	.0373	.0343
20	.0343	.0373	.0343	.0343	.0514	.0373	.0343
21	.0343	.0373	.0343	.0343	.0514	.0373	.0343
22	.0343	.0343	.0343	.0343	.0514	.0373	.0343
23	.0171	.0373	.0189	.0343	.0514	.0373	.0343
24	.0343	.0171	.0373	.0171	.0343	.0514	.0373
Max	.0377	.056	.0373	.0514	.0514	.0514	.0373
Min	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Avg	.0279	.0245	.0261	.0246	.0367	.0285	.0243

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074027 / 33 KV SUB STATION MOTALA

Feeder No / Name : 205 / 11 KV NALGANGAPUR GAOTHAN GAOTHAN FEEDER
FEED Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.6173	.6584	.6001	.5487	.3772	.4755
2	.5144	.6001	.6219	.6001	.5487	.3601	.439
3	.5144	.6602	.5853	.6001	.5487	.3944	.4024
4	.5144	.583	.5853	.5658	.5487	.4287	.4024
5	.5144	.583	.6219	.5658	.5487	.4801	.439
6	.5144	.583	.6878	.5487	.5487	.5316	.5853
7	.2743	.4973	.6401	.5487	.5487	.583	.4755
8		.4801	.6219	.5487	.5487	.5144	.5487
9		.5487	.6036	.5487		.4973	.4801
10		.4801	.583	.5658	.5853	.4973	.2572
11		.5487	.583	.5144	.5121	.463	.3086
12	.7343	.6516	.5144	.5658	.788	.4801	.3772
13	.7164	.5144	.5487	.5144	.7164		.4458
14	.6878	.5658	.583	.6001	.6697	.4973	
15	.6584		.6173	.5487	.5853	.5316	.5316
16	.6584	.6001	.6516	.6173	.6584	.463	.583
17	.6219	.583	.583	.6516	.6219	.4287	.583
18	.6173	.7164	.6687	.3772	.5658	.439	.5487
19	.6173	.6878	.7202	.6173	.5316	.4572	.6173
20	.6173	.6878	.7202	.6516	.4973	.439	.7888
21	.5658	.6584	.6687	.6516	.4287	.5121	.6344
22	.6001	.6767	.6516	.6173	.4115	.5121	.583
23	.6344	.6697	.6344	.583	.3944	.5121	.5316
24	.5144	.6173	.6584	.6344	.5487	.3601	.4755
Max	.7343	.7164	.7202	.6516	.788	.583	.7888
Min	.2743	.4801	.5144	.3772	.3944	.3601	.2572
Avg	.5802	.6005	.6255	.5766	.5611	.4678	.5006

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074027 / 33 KV SUB STATION MOTALA

Feeder No / Name : 206 / 11 KV RAJUR GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1829	.1543	.1715	.1715	.1646
2	.1715	.1715	.1829	.1543	.1715	.1715	.1463
3	.1715	.1715	.1646	.1543	.1715	.1715	.1463
4	.1715	.2058	.1829	.1715	.2058	.1715	.1646
5	.1715	.2058	.2195	.1715	.2058	.2058	.1829
6	.1715	.2229	.2378	.1886	.2229	.2401	.2378
7	.1886	.1886	.1829	.1715	.2058	.2058	.2012
8	.1715	.1543	.1646	.1715	.1715	.2058	.1829
9	.1715	.1543	.1463	.1372		.1543	.1372
10	.1829	.12	.1372	.12	.128	.1029	.12
11	.1829	.2058	.1372	.1372	.1646	.1543	.12
12	.2012	.1715	.1715	.1372	.1829	.1543	.1372
13	.1829	.2229	.1715	.1715	.1829	.2058	.1372
14	.1829	.1715	.1715	.1543	.1646	.1543	.1372
15	.2195	.2058	.1715	.1715	.1646	.2058	.1543
16	.2195	.1715	.1715	.1715	.2561	.1886	.1543
17	.2012	.2058	.2229	.1886	.2195	.2058	.1886
18	.1715	.2561	.1886	.1543	.2058	.2378	.1029
19	.2915	.2378	.2401	.2743	.2743	.2561	.2058
20	.2743	.2561	.2401	.2743	.2572	.2743	.2572
21	.2401	.2378	.1886	.2743	.2401	.2378	.2401
22	.2058	.2195	.1886	.2401	.2229	.2012	.2058
23	.1886	.2012	.1886	.2058	.1886	.1829	.1886
24	.1715	.1715	.2012	.1715	.1715	.1715	.1646
Max	.2915	.2561	.2401	.2743	.2743	.2743	.2572
Min	.1715	.12	.1372	.12	.128	.1029	.1029
Avg	.1949	.1959	.1856	.1800	.1978	.1930	.1699

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074027 / 33 KV SUB STATION MOTALA

Feeder No / Name : 208 / 11 KV MOTALA TOWN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9259	.8916	.9465	.8916	.9945	.823	.8238
2	.8916	.8916	.9465	.8916	.9945	.8402	.8238
3	.8573	.8916	.9114	.8573	.9259	.8402	.788
4	.8573	.8573	.8764	.823	.8573	.823	.7522
5	.823	.7888	.8238	.7888	.8573	.7888	.7164
6	.7545	.7716	.788	.7888	.8059	.7716	.7164
7	.7202	.6859	.8328	.703	.6859	.7373	.7343
8	.7202	.6173	.7164	.703	.6859	.7373	.6697
9	.7202	.6859	.7164			.6173	.6859
10	.788	.6859	.6859	.7545	.8596	.7373	.6687
11	.8505	.8402	.7202	.7373	.9114	.7888	.7373
12	.9114	.9259	.7545	.703	.8939	.9088	.8059
13	.9465	.9088	.7545	.9088	.9465	.6344	.7716
14	.9465	1.046	.7888	.9945	1.0056	.823	.8402
15	.964	1.0288	.7888	.9945	1.0117	.8916	.8573
16	.9114	.8745	.7888	.9602	1.0056	.8745	.9259
17	1.0402	.7888	.7888	.9088	.964	.8573	.8573
18	1.0117	.7522	.7888	.8573	.9602	.8417	.823
19	.9431	.6878	.9259	.9259	.8745	.8059	.8916
20	.9602	.6878	.9259	.9945	.9259	.8417	.9602
21	.9774	.6584	.9431	.9945	.8745	.9465	.9602
22	.9774	1.0288	.9945	1.0288	.9431	.9114	.9945
23	.9774	1.0056	.9602	1.0288	.8573	.8764	1.0288
24	.9259	.9088	.9816	.9602	.9945	.8573	.8596
Max	1.0402	1.046	.9945	1.0288	1.0117	.9465	1.0288
Min	.7202	.6173	.6859	.703	.6859	.6173	.6687
Avg	.8917	.8296	.8395	.8782	.9059	.8156	.8205

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074036 / 33 KV SUBSTATION SAWARGAON

Feeder No / Name : 201 / 11 KV MAKODI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.1372	.0343	.0343	.2743	.0343	.6001
2	.0343	.12	.0343	.0343	.2401	.0343	.6173
3	.0343	.1715	.0343	.0343	.4115	.0343	.0514
4	.0343	.2401	.0343	.0343	.4801	.0343	.6516
5	.0343	.2572	.0343	.0343	.5658	.0343	.6859
6	.0343	.3086	.0343	.0343	.5487	.0343	.7202
7		.3429					
8		.4115					
9	.2572		.3429	.6687		.5144	
10	.4287		.6001	.6687		.6859	
11	.3429		.5144	.583		.6516	
12	.3086		.4801	.5144		.6001	
13	.3601		.463	.3258		.5487	
14	.4115		.5144	.3086		.4973	
15	.3772		.5144	.3601		.4801	
16	.3429		.4801	.3429		.4458	
19	.0343	.0343	.0343	.0343	.0343	.0343	.0343
20	.0343	.0343	.0343	.0343	.0343	.0343	.0343
21	.12	.0343	.0343	.1372	.0343	.3429	.0343
22	.1372	.0343	.0343	.2401	.0343	.5144	.0343
23	.1715	.0343	.0343	.2572	.0343	.5487	.0343
24	.3048	.1543	.0343	.0343	.2401	.0343	.583
Max	.4287	.4115	.6001	.6687	.5658	.6859	.7202
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.1919	.1653	.2161	.2358	.2443	.3069	.3401

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074036 / 33 KV SUBSTATION SAWARGAON

Feeder No / Name : 202 / 11 KV P. DEVI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	.3048
Max	.3048
Min	.3048
Avg	.3048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074036 / 33 KV SUBSTATION SAWARGAON

Feeder No / Name : 203 / 11 KV S.BAZAR AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.0343	.8573	1.046	.0343	1.0288	.0343
2	.7716	.0343	1.0288	1.2346	.0343	1.2003	.0343
3	.8573	.0343	1.2003	1.2346	.0343	1.3375	.0343
4	1.0288	.0343	1.3717	1.286	.0343	1.4746	.0343
5	1.1145	.0343	1.406	1.3375	.0343	1.6118	.0343
6	1.2003	.0343	1.4575	1.6461	.0343	1.8861	.0343
9		.6516					1.0288
10		.8916			.823		1.2003
11		1.1145			1.166		1.9204
12		1.286			1.6461		1.8004
13		1.5432			1.8861		1.7147
14		1.2003			1.9204		1.6461
15		1.0288			2.0233		1.6975
16		.8573			1.8861		1.749
18			.1372				
19	.0343	.0343	.0343	.0343	.0343	.0343	.0343
20	.0343	.0343	.0343	.0343	.0343	.0343	.0343
21	.0343	.5144	.7716	.0343	.5144	.0343	1.2003
22	.0343	.6001	.823	.0343	.6516	.0343	1.2346
23	.0343	.6859	.8573	.0343	.7716	.0343	1.166
24	.6001	.0343	.7716	.8573	.0343	.8573	.0343
Max	1.2003	1.5432	1.4575	1.6461	2.0233	1.8861	1.9204
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.5358	.5341	.8270	.7345	.7156	.7973	.8333

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074036 / 33 KV SUBSTATION SAWARGAON

Feeder No / Name : 204 / 11 KV Nipana Ag Feeder FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.3048
Max	.3048
Min	.3048
Avg	.3048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074036 / 33 KV SUBSTATION SAWARGAON

Feeder No / Name : 205 / 11 kv Nipana GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.1543	.1543	.1543	.1886	.1886	.12
2	.2401	.1715	.1715	.1543	.1715	.1715	.1372
3	.2229	.1543	.1543	.1715	.1543	.1543	.1029
4	.2572	.1715	.1715	.1715	.1715	.1715	.1372
5	.2229	.2229	.2229	.1715	.2572	.2058	
6	.2058	.2058	.2058	.1886	.2229	.1543	
7	.1886	.1543	.1715	.1715	.2401	.1372	.1372
8	.1715	.1372	.1543	.1543	.1715	.1372	
9	.1543	.12	.1372	.1372		.12	
10	.1372	.1029	.12	.1372	.1372	.1029	
11	.1715	.12	.12	.1543	.1029	.12	
12	.1372	.1372	.12	.1543	.1372	.1372	
13	.1543	.1715	.1372	.1886	.1543	.1372	
14	.1715	.1715	.1372	.1715	.1372	.1372	.12
15	.1886	.1886	.1543	.1886	.1543	.1372	.1372
16	.1715	.1886	.1715	.2058	.1886	.1543	
17	.2401	.1886	.1715	.1715	.2058	.1715	.1372
18	.2058	.2058	.1886	.2058	.1715	.2058	.1715
19	.2229	.2058	.2058	.2401	.2058	.2058	.1886
20	.2572	.2229	.2058	.2572	.2401	.1886	.2058
21	.2915	.2229	.1886	.2229	.2572	.1715	.2401
22	.2401	.2058	.1886	.2058	.2229	.1715	.1715
23	.2058	.2058	.1715	.1886	.2058	.1715	.1372
24	.3429	.1715	.1715	.1715	.1715	.1715	.1543
Max	.3429	.2229	.2229	.2572	.2572	.2058	.2401
Min	.1372	.1029	.12	.1372	.1029	.1029	.1029
Avg	.2086	.1751	.1665	.1808	.1856	.1593	.1532

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074036 / 33 KV SUBSTATION SAWARGAON

Feeder No / Name : 206 / 11 kv P.Devi GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2743	.2572	.2572	.2743	.2743	.2915
2	.2915	.2401	.2743	.2572	.2572	.2572	.3086
3	.3429	.2572	.2915	.2572	.2915	.2915	.3258
4	.3086	.2915	.2743	.2743	.3258	.1886	.3429
5	.2743	.3258	.2572	.2743	.3772	.3772	.3258
6	.2915	.3601	.2572	.2915	.3429	.3772	.2572
7	.2572	.3258	.2915	.2743	.2572	.3086	.2058
8	.2401	.2915		.2572	.2229	.2915	.2229
9	.2229	.2229		.2058		.2743	.2058
10	.2058	.2058		.2401	.1886	.1715	.1715
11	.2229	.2401	.2572	.2229	.2229	.1715	.1886
12	.2401	.2743	.2401	.2401	.2058	.1715	.1543
13	.2229	.2229	.2401	.2229	.2401	.1886	.1715
14	.2058	.2401	.2229	.2401	.2229	.2058	.1543
15	.2572	.2572	.2229	.2572		.2401	.2058
16	.2743	.2915	.2229	.2401		.2743	.2401
17	.3086	.2572	.2229	.2915	.2401	.2915	.2572
18	.3601	.2401	.2401	.3429	.2915	.3086	.2915
19	.3429	.2743	.2572	.3772	.3429	.2743	.3429
20	.4115	.2915	.2743	.3601	.3772	.2743	.3772
21	.3429	.3086	.3086	.2915	.3601	.2572	.3944
22	.2915	.2743	.3086	.3086	.3086	.2572	.3258
23	.2743	.2572	.2743	.2572	.2572	.2401	.2915
24	.3429	.2572	.2401	.2572	.2401	.2401	.2572
Max	.4115	.3601	.3086	.3772	.3772	.3772	.3944
Min	.2058	.2058	.2229	.2058	.1886	.1715	.1543
Avg	.2836	.2701	.2588	.2708	.2784	.2586	.2629

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074036 / 33 KV SUBSTATION SAWARGAON

Feeder No / Name : 207 / 11 kv S.Bazar GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2743	.2743	.2229	.2572	.2401	.2401
2	.2401	.2572	.2572	.2229	.2401	.2572	.2572
3	.2743	.2915	.2915	.2229	.2572	.2915	.2915
4	.2572	.3086	.3086	.2572	.2915	.3258	.3086
5	.2229	.3429	.3429		.3258	.2743	.2401
6	.2572	.3601	.3601	.2401	.2743	.2572	.2229
7	.2401	.3258	.4973	.2058	.2572	.2401	.2058
8	.2401	.2915	.3086	.1886	.1886	.2229	.1715
9	.2058	.2058	.2743	.1886		.2058	.1886
10	.2058	.1715	.2401	.1715	.2058	.1715	.1715
11	.1715	.2229	.2401	.2058	.1715	.1715	.1543
12	.2229	.2401	.2401	.2401	.1886	.1886	.1715
13	.2058	.2572	.2401	.2572	.2058	.1886	.1886
14	.2401	.2058	.2229	.2743	.2401	.2229	.2229
15	.2743	.2401	.2229	.2572	.2572	.2401	.2058
16	.2572	.1715	.2401	.2058	.2572	.2401	.2572
17	.2915	.1886	.2401	.1886	.2058	.2743	.2229
18	.3258	.2058	.2572	.0171	.1886	.2915	.2401
19	.3429	.2229	.2572	.3258	.1715	.2743	.2229
20	.3772	.2401	.2915	.3429	.3258	.2401	.2572
21	.3429	.3086	.2743	.2915	.3429	.2572	.2229
22	.3258	.2915	.2743	.3086	.2915	.2572	.2401
23	.2915	.2743	.2572	.2915	.2743	.2401	.2058
24	.3429	.2572	.2572	.2401	.2743	.2572	.2229
Max	.3772	.3601	.4973	.3429	.3429	.3258	.3086
Min	.1715	.1715	.2229	.0171	.1715	.1715	.1543
Avg	.2665	.2565	.2779	.2333	.2475	.2429	.2222

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074036 / 33 KV SUBSTATION SAWARGAON

Feeder No / Name : 208 / 11 kv makodi gfss

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1372	.1372	.1543	.1372	.1543	.1372
2	.1543	.1715	.1715	.1543	.1543	.1886	.1543
3	.1715	.2058	.1543	.1543	.1886	.1715	.1372
4	.1886	.1715	.1715	.1715	.1715	.1715	.1715
5	.1715	.2229	.1886	.1372	.1715	.1372	.1372
6	.1715	.2058	.2058	.12	.2058	.12	.12
7	.1543	.1715	.1372	.12	.1372	.12	.12
8	.1372	.1372	.1029	.12	.12	.1029	.1372
9	.12	.1029	.1029			.0857	.1029
10	.1029	.12	.0686		.1029	.0686	.1029
11	.12	.1715	.0686		.12	.0857	.12
12	.1029	.1886	.0857		.1372	.0857	.1029
13	.1372	.2058	.1029		.12	.1029	.1029
14	.1543	.1715	.1029		.1372	.12	.12
15	.1715	.1715	.12	.1372	.1543	.1372	.1029
16	.1543	.1543	.1543	.1543	.1372	.1372	.1372
17	.1372	.1715	.1543	.1543	.1543	.1543	.1372
18	.1543	.1715	.1543	.1715	.1543	.1715	.1543
19	.1715	.1886	.1715	.1886	.1715	.1543	.1715
20	.2058	.2058	.1886	.1715	.1886	.1715	.2058
21	.2229	.2058	.1886	.1886	.1715	.1543	.1715
22	.2058	.1715	.1715	.1543	.1886	.1715	.1543
23	.1715	.1715	.1715	.1372	.1543	.1715	.1372
24	.3429	.1543	.1715	.1543	.1543	.1372	.1543
Max	.3429	.2229	.2058	.1886	.2058	.1886	.2058
Min	.1029	.1029	.0686	.12	.1029	.0686	.1029
Avg	.1658	.1729	.1436	.1524	.1536	.1365	.1372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074060 / 33 KV Pophli S/S

Feeder No / Name : 201 / 11 KV Pophli AG Feeder
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7449			1.1065		1.2955	
2	.7865			1.1065		1.2955	
3	.8745			1.1191		1.2308	
4	.8421			1.1191		1.3603	
5	.8002			1.278		1.3763	
6	.8482			1.3603		1.6004	
9		1.3927	1.5089				
10		1.5729	1.4403				1.8351
11		1.5061	1.4737		1.442		1.8564
12		1.5074	1.5061		1.7328		1.8399
13		1.4582	1.4575		1.7004		1.7238
14		1.4091	1.3117		1.491		1.5415
15		1.4255	1.3603		1.4582		1.5912
16		1.3763	1.3599		1.4255		1.5746
21			1.1065		1.2163		1.0623
22			1.1401		1.2955		1.2483
23			1.1233		1.3279		1.3283
24	.7125			1.1065		1.3603	
Max	.8745	1.5729	1.5089	1.3603	1.7328	1.6004	1.8564
Min	.7125	1.3763	1.1065	1.1065	1.2163	1.2308	1.0623
Avg	.8013	1.4560	1.3444	1.1709	1.4544	1.3599	1.5601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074060 / 33 KV Pophli S/S

Feeder No / Name : 202 / wadi ag feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4					.0185	
5			.0366		.0185	
6		.0343	.0549		.037	
9				.0924		.1029
10	.0366			.1075		.0857
11	.0366			.1254		.0857
12	.0537			.1075		.0686
13	.0362			.1075		.0514
14	.0362			.0716		.0514
15	.0362			.0716		
16	.0362			.0537		
21	.0343	.0362		.0187		
22	.0343	.0362				
23		.0185				
Max	.0537	.0362	.0549	.1254	.037	.1029
Min	.0343	.0185	.0366	.0187	.0185	.0514
Avg	.0378	.0313	.0458	.0840	.0247	.0743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074060 / 33 KV Pophli S/S

Feeder No / Name : 203 / 11 kv Pophli Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 /
OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.3647	.4163	.4066	.4163	.3647	.4066
2	.3856	.3647	.4163	.4066	.4163	.3812	.4108
3	.3429	.3812	.3982	.3921	.4163	.3812	.3921
4	.4252	.3812	.4344	.3921	.4525	.3978	.3921
5	.4458	.3978	.4525	.462	.4887	.426	.4435
6	.4607	.431	.4887	.5121	.5249	.4534	.5487
7	.4298	.3481	.4163	.462	.4706	.3812	.5175
8	.3856	.3521	.3439	.3395	.4163	.3481	.4338
9	.3086	.2984	.2926	.3326	.362		.3921
10	.3439	.3475	.285	.3258	.3734		.3142
11	.3439	.3658	.2652		.3881	.1029	.3142
12		.3696	.3018		.3881	.112	.2957
13	.3801	.3881	.2984	.1097	.3696	.1132	.3142
14	.3982	.4066	.3149	.1097	.4207	.0943	.2987
15	.4163	.439	.3481	.128	.4435	.0934	.3511
16	.4525	.462	.3841	.128	.462	.4108	.4108
17	.3978	.4525	.4191	.4706	.4096	.5281	
18	.431	.4525	.4338	.5249	.426	.5601	
19	.4641	.4525	.4715	.6154	.4588	.6348	.4557
20	.5668	.5973	.5914	.6516	.5506	.6161	.5973
21	.4858	.5068	.4854	.5249	.4588	.5415	.5487
22	.426	.4525	.3921	.4525	.426	.4904	.4252
23	.3978	.4344	.4108	.4344	.3978	.4435	.0354
24	.3856	.3647	.4344	.4108	.4163	.3647	.4066
Max	.5668	.5973	.5914	.6516	.5506	.6348	.5973
Min	.3086	.2984	.2652	.1097	.362	.0934	.0354
Avg	.4124	.4088	.3956	.3905	.4314	.3745	.3957

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074060 / 33 KV Pophli S/S

Feeder No / Name : 204 / 11 Kv Ghoogali Ag Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0686			.0185		.0732
2		.0514					.0732
3		.0514			.0185		.0724
4		.0514			.037		.0732
5		.0686	.0185		.0549		.0732
6		.1029	.0549		.0905		.1075
9	.144					.12	
10	.1433			.0716		.1029	
11	.1075			.0895		.0857	
12	.0895			.0895		1.5238	
13	.0537			.0716		.1595	
14	.0543			.0537		.1254	
15	.0543			.0537		.1433	
16	.0362			.0358		.1433	
21	.12			.037			
22	.0686	.0543		.037			
23	.0686	.037		.037		.0543	
24		.0686			.0185		.0543
Max	.144	.1029	.0549	.0895	.0905	1.5238	.1075
Min	.0362	.037	.0185	.0358	.0185	.0543	.0543
Avg	.0855	.0616	.0367	.0576	.0397	.2731	.0753

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074061 / 33 kv Kothali Substation

Feeder No / Name : 201 / 11 kv Kothali Ag Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5792		.362	.426	.0857	.5611	.0762
2	.5792		.362	.4096	.0686	.5611	.0762
3	.5792		.362	.4096	.0686	.5611	.0762
4	.724		.3982	.4096	.0686	.5611	.0762
5	.8145		.4706	.4915	.0686	.8688	.0762
6	1.1765		.5068	1.0364	.0686	1.5023	.0762
9		.6859			1.3889		1.3203
10		1.2127			1.5384		1.749
11		1.2308			1.5746		1.749
12		1.1222			1.5384		1.6461
13		1.0679			1.448		1.406
14		.9412			1.3575		1.3203
15		.905			1.267		1.166
16		.8326			1.1946		1.0631
19	.0514	.1086	.1143	.0857	.1086	.1143	.0857
20	.0686	.1086	.0953	.0857	.1086	.1143	.0857
21	.0514	.3258	.4424	.0857	.543	.1143	.4801
22	.0686	.3439	.4424	.0686	.5611	.0953	.5487
23	.0686	.3439	.4424	.0857	.5611	.0953	.5487
24	.5249	.0686	.3439	.4424	.0686	.5611	.0953
Max	1.1765	1.2308	.5068	1.0364	1.5746	1.5023	1.749
Min	.0514	.0686	.0953	.0686	.0686	.0953	.0762
Avg	.4405	.6641	.3619	.3364	.6844	.4758	.6861

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074061 / 33 kv Kothali Substation

Feeder No / Name : 202 / 11 kv Kothali GFSS Feeder GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5792		.5973	.5716	.4973	.6154	.5249
2	.5792	.2915	.5973	.5716	.4973	.6154	.5249
3	.5792	.2915	.5973	.5716	.4973	.6154	.5249
4	.5792	.2743	.5973	.5716	.4973	.6154	.543
5	.5792	.3086	.5973	.5906	.5144	.6154	.5792
6	.6335	.3429	.6335	.5716	.5487	.6335	.6154
7	.4706	.3429	.4706	.5335	.4801	.543	.5716
8	.4706	.4458	.4525		.4458	.4887	.5525
9	.4344	.4115	.4763	.3944	.4115	.4382	.3772
10	.4287	.4525	.4382	.3772	.4344	.4001	.3772
11	.4458	.4706	.4191	.3601	.4163	.4001	.3601
12	.4458	.4706	.4382	.3601	.4525	.4001	.3429
13	.4287	.4706	.4572	.3772	.4706	.4191	.3772
14	.4458	.4706	.4382	.4115	.4706	.4191	.3944
15	.4458	.5068	.4572	.4287	.4163	.4572	.4115
16	.4801	.5973	.5144	.4458	.5249	.5525	.3772
17	.5487	.6335	.6097	.4458	.3591	.567	.4801
18	.6001		.6097	.5658	.6878	.6154	.5487
19	.6516	.4163	.6668	.6516	.6697	.6036	.6173
20	.703	.6516	.724	.6516	.6878	.6584	.6516
21	.6859	.6335	.6859	.6344	.7059	.6584	.6344
22	.6516	.6335	.6478	.6173	.724	.6478	.6173
23	.583	.5973	.6097	.5487	.6516	.567	.5487
24	.5792	.5487	.5973	.5906	.5144	.6154	.5487
Max	.703	.6516	.724	.6516	.724	.6584	.6516
Min	.4287	.2743	.4191	.3601	.3591	.4001	.3429
Avg	.5429	.4665	.5555	.5149	.5240	.5484	.5042

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074061 / 33 kv Kothali Substation

Feeder No / Name : 203 / 11 kv ramgaon ag feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0572	.12	.0724	.064
2		.12		.0572	.12	.0905	.064
3		.12		.0572	.1372	.0905	.08
4		.12		.0572	.1372	.1086	.112
5		.1715		.0572	.1715	.2172	.1406
6		.2915		.0572	.3429	.3077	.5944
7		.2915					
9	.3258		.3239	.3772	.2915	.6249	
10	.5144		.2591	.4801	.2896	.6097	.4801
11	.5487		.4801	.4458	.2534	.6249	.5144
12	.5487		.4161	.3772	.2353	.6097	.4801
13	.4287		.3521	.3429	.2172	.5487	
14	.4458		.208	.3429	.1991	.4572	.2058
15	.3601		.2561	.2743	.1991	.4115	.2058
16	.3429		.3201	.3429	.181	.3906	.2058
19	.0514	.0543	.0572	.0686	.0905	.0953	.0857
20	.0514	.0543	.0572	.0857	.0905	.0572	.0857
21	.12	.0543	.0572	.12	.0905	.112	.0972
22	.1372	.0543	.0572	.12	.0905	.096	.116
23	.12		.0572	.1372	.0724	.0819	.116
24		.12		.0572	.1372	.0724	.064
Max	.5487	.2915	.4801	.4801	.3429	.6249	.5944
Min	.0514	.0543	.0572	.0572	.0724	.0572	.064
Avg	.3073	.1320	.2232	.1958	.1733	.2839	.2062

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074061 / 33 kv Kothali Substation

Feeder No / Name : 204 / 11 Kv Shirva AG Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.0543		.0724
2	.0543	.0514	.0724
3	.0543	.0514	.0724
4	.0724	.0514	.0724
5	.0905	.0514	.1267
6	.1267		.1448
9		.1543	
10		.1629	
11		.1629	
12		.168	
13		.1448	
14		.1448	
15		.1448	
16		.1448	
19	.0514	.0543	.0572
20	.0514	.0543	
21	.0514	.0543	
22	.0514	.0543	
23	.0514	.0543	
24	.0362	.0514	.0543
Max	.1267	.168	.1448
Min	.0362	.0514	.0543
Avg	.0621	.0975	.0841

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074087 / 33 KV WADJI SUB STATION

Feeder No / Name : 201 / 11 KV Harankhed Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305	.1829	.0362	.0362	.2229	.0343	.061
2	.0305	.2134	.0344	.0362	.2229	.0343	.0457
3	.0305	.1981	.0344	.0362	.2572	.0343	.061
4	.0305	.2286	.0362	.0362	.2572	.0343	.0762
5	.0305	.2134	.0344	.0362	.3086	.0343	.061
6	.0305	.2743	.0373	.0362	.3258	.0343	.0762
9	.2286		.362	.3258		.4557	
10	.3353		.4706	.3258		.3772	
11	.3201		.4344	.3258		.4801	
12	.3353		.4344	.362		.4458	
13	.3048		.3982	.3258		.463	
14	.3201		.3982	.3258		.3772	
15	.2743		.3865	.3258		.3353	
16	.2743		.3865	.362		.3658	
20	.0305	.0362	.0362	.0351	.0351	.0305	.0305
21	.1524	.0362	.0362	.2229	.0343	.061	.0305
22	.1524	.0363	.0344	.2401	.0351	.1067	.0305
23	.1829	.0362	.0362	.2058	.0343	.061	.0152
24	.0305	.1829	.0362	.0362	.2058	.0343	.061
Max	.3353	.2743	.4706	.362	.3258	.4801	.0762
Min	.0305	.0362	.0344	.0351	.0343	.0305	.0152
Avg	.1644	.1490	.1928	.1914	.1763	.2000	.0499

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074087 / 33 KV WADJI SUB STATION

Feeder No / Name : 202 / 11 KV Wadji GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1981	.1829	.2172	.2172	.2058	.2058	.1677
2	.2134	.1677		.2172	.2058	.2058	.1829
3	.2134	.1981	.2172	.2172	.1886	.2058	.2134
4	.2286	.2286	.2172	.2172	.2229	.2401	.1829
5	.2286	.2591	.2172	.2172	.2572	.2572	.2286
6	.2439	.2134	.2896	.2715	.2915	.2915	.2439
7	.2286	.2439	.2534	.2715	.298	.2804	.2134
8	.2591	.2134	.2534	.2534		.2454	.1981
9	.1829	.2172	.1486	.2401		.2279	.1524
10	.1677	.2172	.181	.181	.2058	.2058	.1524
11	.1524	.2172	.1715	.181	.2058	.1715	.1372
12	.1829	.2058	.1867	.2172	.2279	.1715	.1524
13	.1677	.2172	.2172	.2172	.2279	.1886	.1677
14	.1829	.2058	.2263	.2172	.2279	.2058	.1829
15	.2134	.2534	.2241	.2058	.2454	.1829	.2134
16	.1981	.2715	.2353	.2534	.2454	.1981	.1219
17	.2134		.2534	.2534	.2947	.2134	.1372
18	.2439	.362	.2715	.298	.2804	.2439	
19	.2591	.3258	.2715	.3155	.3155	.2591	.2896
20	.2286	.2715	.2534	.3155	.3155	.0762	.2743
21	.2286	.2534	.2534	.2743	.2572	.2286	.2286
22	.1981	.2241	.2534	.2401	.2454	.1829	.1981
23	.1829	.2172	.2172	.2229	.2229	.1677	.1829
24	.1981	.1677	.2172	.2172	.2058	.2058	.1524
Max	.2591	.362	.2896	.3155	.3155	.2915	.2896
Min	.1524	.1677	.1486	.181	.1886	.0762	.1219
Avg	.2089	.2319	.2281	.2388	.2452	.2109	.1902

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074087 / 33 KV WADJI SUB STATION

Feeder No / Name : 203 / 11 KV Malegaon Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.0305	.724	.5792	.0343	.7716	.0305
2	.3963	.0305	.724	.5792	.0343	.7716	.0305
3	.4268	.0305	.7164	.5792	.0343	.7888	.0305
4	.442	.0305	.6859	.5792	.0343	.8573	.0305
5	.4268	.0305	.724	.724	.0343	.8573	.0305
6	.4572	.0305	.7888	.905	.0343	.9602	.0305
9		.7602					.9297
10		.7554			1.0117		1.1584
11		.7964			1.1831		1.1126
12		.8326			1.2269		1.0669
13		.8145			1.1568		1.0822
14		.7602			1.0166		1.0669
15		.7602			.964		.9145
16		.7602			.929		.9297
20	.0305	.0362	.0362	.0351	.0351	.0305	.0305
21	.0305	.5068	.6154	.0343	.6859	.0305	.7926
22	.0305	.543	.6154	.0343	.7537	.0305	.7773
23	.0305	.724	.6154	.0343	.6859	.0305	.7773
24	.3048	.0305	.724	.5792	.0343	.7202	.0305
Max	.4572	.8326	.7888	.905	1.2269	.9602	1.1584
Min	.0305	.0305	.0362	.0343	.0343	.0305	.0305
Avg	.2688	.4349	.6336	.4239	.5494	.5317	.5712

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074104 / 33/11 KV Waghjal Murti Sub
Sta

Feeder No / Name : 201 / 11 KV Takali Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343		.1715	.0671		.1029	
2	.0343		.1715	.0671		.1029	
3	.0343		.1715	.0671		.1715	
4	.0343		.2058	.0671		.1715	
5	.0686		.2058	.1341		.2058	
6	.1715		.2401	.2683		.2058	
7	.2058					.2401	
8						.2743	
9		.1677			.3772		.4694
10		.2347			.5144		.4458
11		.3353			.4115		.3772
12		.2683			.3429		.3086
13		.2683			.2743		.2743
14		.2012			.2743		.3429
15		.2012			.2743		.2401
16		.1341					.2743
21		.0686	.0671		.0686		.1029
22		.0686	.0671		.0686		.1029
23		.0686	.0671		.1029		.1029
24	.0343		.1715	.0671		.1029	
Max	.2058	.3353	.2401	.2683	.5144	.2743	.4694
Min	.0343	.0686	.0671	.0671	.0686	.1029	.1029
Avg	.0772	.1833	.1539	.1054	.2709	.1753	.2765

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074104 / 33/11 KV Waghjal Murti Sub
StaFeeder No / Name : 202 / 11 KV Rohinkhed Ag FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0686			.1029		.0335
2		.1029			.1029		.0335
3		.1715			.1029		.0335
4		.1715			.1715		.0335
5		.2058			.2058		.0335
6		.2058			.2743		.0671
9	.2401		.3772	.3018		.2743	
10	.3086		.3086			.3429	
11	.3086		.3772	.3086		.3429	
12	.3429		.3772	.3086		.2743	
13	.2058		.3429	.2743		.2401	
14	.2058		.2743	.2743		.1372	
15	.1715		.2743	.2743		.1372	
16	.1715		.2058	.2743		.3429	
21	.0686			.1372			
22	.0686			.1372		.0335	
23	.0686			.1029		.0335	
24		.0686			.1029		.0335
Max	.3429	.2058	.3772	.3086	.2743	.3429	.0671
Min	.0686	.0686	.2058	.1029	.1029	.0335	.0335
Avg	.1964	.1421	.3172	.2394	.1519	.2159	.0383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074104 / 33/11 KV Waghjal Murti Sub
StaFeeder No / Name : 203 / 11 KV Rohinkhed Gaothan
Feeder KV- 11 / OUTGOING**GAOTHAN FEEDER**

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3086	.3429	.4108	.4115	.3086	.4108
2	.3772	.3086	.3429	.4108	.4115	.3086	.4108
3	.3772	.3429	.3429	.4108	.4115	.3086	.4108
4	.4115	.3429	.3772	.4108	.4115	.3429	.4108
5	.4458	.3772	.3772	.4481	.4458	.3429	.4854
6	.5144	.4115	.4115	.5601	.4458	.3429	.5228
7	.4458	.3429	.4115	.4854	.4801	.3772	.4854
8	.3772	.2743	.3772	.4481	.4115	.3772	.4108
9	.3429	.3361	.3429	.3734	.3772	.3429	.3361
10	.3429	.3734	.3086	.3429	.2743	.3086	.3086
11	.3429	.3734	.3086	.3429	.3086	.2743	.2743
12	.3429	.3361	.3086	.3429	.3086	.2743	.3086
13	.3429	.3361	.3086	.3429	.3086	.2743	.3086
14	.3429	.3361	.3086	.3772	.3429	.2743	.2743
15	.3772	.3734	.3086	.3772	.3429	.3429	.3086
16	.3772	.4108	.3772	.3772	.3772	.3429	.3429
17	.4287	.4854	.4115	.4115	.3772	.3772	.3772
18	.4115	.4801	.4458	.4458	.3772	.5144	.4458
19	.4115	.4801	.4854	.5144	.5144	.5975	.3086
20	.4115	.4458	.4854	.5487	.5144	.4854	.5144
21	.3772	.4115	.4481	.4801	.4458	.4108	.4801
22	.3086	.3772	.4481	.4458	.4115	.4108	.4458
23	.3086	.3772	.4108	.4458	.3429	.4108	.4115
24	.3772	.3086	.3429	.4108	.4458	.3086	.4108
Max	.5144	.4854	.4854	.5601	.5144	.5975	.5228
Min	.3086	.2743	.3086	.3429	.2743	.2743	.2743
Avg	.3822	.3729	.3764	.4235	.3958	.3608	.3918

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074104 / 33/11 KV Waghjal Murti Sub
StaFeeder No / Name : 204 / 11 KV Takali Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.3429	.3772	.4854	.4458	.3429	
2	.4458	.3429	.3772	.4854	.4458	.3429	
3	.4458	.3772	.4115	.4854	.4458	.3772	
4	.4458	.4115	.4115	.4854	.4458	.3772	
5	.4801	.4458	.4115	.5228	.4801	.4115	
6	.5487	.4801	.4458	.5975	.5144	.4115	
7	.5144	.4458	.4458	.5601	.5144	.4458	
8	.4801	.4458	.4115	.5228	.4801	.4458	
9	.4115	.4481	.3772	.4108	.4115	.4115	
10	.3772	.4108	.2401	.3086	.3772	.3429	.3086
11	.3772	.4108	.2401	.3086	.3086	.3086	.3086
12	.3772	.4108	.2743	.3086	.3086	.2743	.3086
13	.3772	.4108	.2743	.3429	.3086	.3086	.3086
14	.4115	.4108	.3086	.3772	.3772	.2743	.2743
15	.4458	.4481	.3086	.4115	.3772	.3429	.3086
16	.4458	.4481	.3772	.4458	.4115	.3772	.3772
17	.4458	.5228	.4115	.4801	.4115	.4458	.4115
18	.4801	.5487	.5144	.4801	.4801	.4801	.4458
19	.5144		.5975	.5487	.583	.5601	.5487
20	.5487	.5487	.5975	.5487	.5487	.5601	.583
21	.5487	.5144	.5601	.5144	.5144	.4854	.5144
22	.5144	.4801	.5228	.4801	.4458	.4854	.4801
23	.4115	.4458	.4854	.4458	.4115	.4854	.4973
24	.4458	.3429	.3772	.4854	.4458	.3429	
Max	.5487	.5487	.5975	.5975	.583	.5601	.583
Min	.3772	.3429	.2401	.3086	.3086	.2743	.2743
Avg	.4558	.4389	.4066	.4601	.4372	.4017	.4054

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074005 / 33 kv Chandur s/s

Feeder No / Name : 201 / 11 kv Wadner Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0747	.0747	.176	.1783	.208	.1783
2	.0747	.0747	.0747	.176	.1783	.208	.1783
3	.0747	.0747	.0732	.176	.1783	.2027	.1783
4	.0747	.0747	.0747	.2054	.1783	.2134	.2675
5	.0747	.0747	.0747	.2347	.208	.2134	.3269
6	.0747	.0747	.0747	.2641	.3269	.3814	.4012
9	.1486	.1219	.2378				
10	.2347	.3567	.2972				
11		.3269	.3311				
12	.2378	.2972	.282				
13	.208	.2439	.2606				
14		.2134	.2286				
15	.1783	.2439	.2				
16	.1189	.2439					
19	.0747	.0739	.0747	.0709	.0488	.0747	.0716
20	.0747	.0739	.0747	.0716	.0739	.0747	.0747
21	.0663	.0686	.1448	.2347	.2378	.2378	.0754
22	.0747	.0701	.1486	.2408	.3048	.2972	.0754
23	.0747	.0724	.1486	.2107	.2408	.2378	.0747
24	.0747	.0724	.0747	.1467	.1738	.1951	.2229
Max	.2378	.3567	.3311	.2641	.3269	.3814	.4012
Min	.0663	.0686	.0732	.0709	.0488	.0747	.0716
Avg	.1119	.1464	.1553	.1840	.194	.2120	.1771

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074005 / 33 kv Chandur s/s

Feeder No / Name : 202 / 11 kv Chandur Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5281	.6401	.5487	.0293	.0305	.0617	.0312
2	.5281	.6401	.5487	.0293	.0305	.0617	.0312
3	.5281	.6401	.5487	.0293	.0305	.0617	.0312
4	.5868	.6401	.5487		.0305	.0617	.0312
5	.6161	.6706	.5487		.0305	.0617	.0312
6	.6455	.7621	.7011		.0305	.0617	.0312
9				.823		1.0185	.9755
10				.8535		1.1111	1.0974
11				.7621		1.1111	1.0974
12				.823		1.1111	1.1279
13						1.0494	1.0364
14				.8535		.9877	1.0623
15						.9568	
16					.8509	.9998	1.0623
19	.0602	.061	.0293	.0305	.0617	.0293	.0312
20	.0602	.061	.0293	.0305	.0617	.0312	.0312
21	.5719	.5792	.0293	.0305	.0617	.0312	.7811
22	.6706	.6097	.0293	.0305	.0617	.0312	.8749
23		.6097	.0293	.0305	.0617	.0312	.8749
24	.6401	.6401	.5487	.0293	.0305	.0617	.0312
Max	.6706	.7621	.7011	.8535	.8509	1.1111	1.1279
Min	.0602	.061	.0293	.0293	.0305	.0293	.0312
Avg	.4942	.5462	.3450	.3132	.1056	.4466	.5406

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074005 / 33 kv Chandur s/s

Feeder No / Name : 203 / 11 kv Chandur Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8048	.7762	.7392	.7316	.7762	.8131	.7682
2	.8048	.7762	.7392	.7316	.7762	.8131	.7682
3	.8048	.7762	.7392	.7316	.7762	.8131	.7682
4	.8596	.7762	.7392	.7316	.7762	.8131	.7682
5	.7682	.7762	.7392	.7316	.7762	.8131	.8048
6	.7682	.7392	.7762	.7316	.7392	.7762	.8048
7	.695	.6584	.6584	.695	.6584	.7392	.6584
8	.7762	.6584	.6653	.6584	.6516	.7023	.6219
9	.7316	.695	.6154	.6878		.6805	.6219
10	.7682	.695	.6516	.6516		.6878	.6219
11		.7316	.6516	.5792		.695	.7316
12	.8779	.7682	.6878	.724		.695	.695
13	.9145	.8048	.724			.724	.7316
14	.8413	.8413	.7316	.7602		.724	.7316
15	.8048	.8413	.8048	.724			
16	.8048	.8413		.8326	.8048		
17	.7602	.7964	.7682	.8413	.8596	.7316	.7164
18	.7964	.7602	.7682	.788	.8238	.7316	.8238
19	.905	.9145	.7682	.8688	.9313	.7316	.905
20	1.0719	1.0719	.8048	1.0719	.9877	.9145	1.0349
21	1.0349	.924	.8779	.9979	.961	.9877	.961
22	.961	.8871	.8779	.924	.924	.8962	.924
23		.8131	.8048	.8501	.8501	.8413	.8501
24	.8413	.8131	.7762	.7682	.8131	.8501	.7682
Max	1.0719	1.0719	.8779	1.0719	.9877	.9877	1.0349
Min	.695	.6584	.6154	.5792	.6516	.6805	.6219
Avg	.8362	.7973	.7439	.7745	.8168	.7806	.7764

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074005 / 33 kv Chandur s/s

Feeder No / Name : 204 / 11 kv Wadner Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.924	.8501	.8413	.924	.8871	.8048
2	.9145	.924	.8501	.8413	.924	.8871	.8048
3	.9145	.924	.8501	.8413	.924	.8871	.8048
4	.8779	.924	.8501	.8048	.8871	.8871	.8048
5	.8048	.924	.8501	.7316	.8131	.924	.7316
6	.7682	.7762	.7023	.695	.7762	.7392	.695
7	.695	.6584	.6219	.6584	.7316	.7023	.6584
8	.7392	.6584	.6653	.6584	.6878	.7023	.6219
9	.7682	.695	.6516	.724		.695	.7316
10	.8779	.7316	.6878	.7602		.695	.695
11		.7316	.724	.7602		.7316	.7682
12	.8779	.7316	.5853	.7316		.7316	.7316
13	.8779	.7682	.6516			.8131	.7682
14	.8779	.8413	.7023	.7964		.8871	.8413
15	.9145	.8413	.8326	.905		.8413	.8413
16	.9877	.8413		.905	.8779	.8413	.8413
17	.8688	.7964	.8413	.8779	.8688	.8779	.7522
18	.7964	.7682	.8048	.8238	.815	.8779	.788
19	.9412	.8326	.8048	.905	.8326	.8413	.8048
20	1.0719	1.0349	.9145	1.0349	1.0349	.9511	.9979
21	1.1088	1.0349	.9511	1.0719	1.1088	.9877	1.0456
22	1.0719	.9979	.9511	1.0349	1.0719	.9511	1.0456
23		.924	.9145	.961	.961	.9145	.9335
24	1.7909	.961	.8501	.8413	.961	.924	.8413
Max	1.7909	1.0349	.9511	1.0719	1.1088	.9877	1.0456
Min	.695	.6584	.5853	.6584	.6878	.695	.6219
Avg	.9300	.8435	.7873	.8350	.8941	.8407	.8064

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074005 / 33 kv Chandur s/s

Feeder No / Name : 205 / 11 KV JEEGAON AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3048	.3102	.2782
2				.3048	.3102	.2782
3				.3048	.3144	.2667
4				.3048	.3185	.2705
5				.2972	.3567	.2934
6				.2972	.3567	.3567
9	.2858	.3567	.4161			
10	.3144	.3864	.4161			
11		.3963	.3765			
12	.3353	.3658	.3338			
13	.3567	.3704	.3475			
14	.3269	.3704	.3429			
15	.3269	.3395	.3429			
16	.3567	.3395				
21			.2378	.2934	.306	.3353
22			.2675	.3269	.3616	
23			.3048	.3269	.3384	
24				.3048	.3227	.282
Max	.3567	.3963	.4161	.3269	.3616	.3567
Min	.2858	.3395	.2378	.2934	.306	.2667
Avg	.3290	.3656	.3386	.3066	.3295	.2951

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074005 / 33 kv Chandur s/s

Feeder No / Name : 206 / 11 KV INCOMER NO1

Feeder KV- 11 / INCOMING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9259	.9877	.9145	.9945	1.1694	1.1576	.9602
2	.9259	.9877	.9145	.9945	1.1694	1.1576	.9602
3	.9259	1.0082	.9145	.9945	1.1694	1.1576	.9602
4	.8916	.9877	.9145	.9945	1.1694	1.1576	1.0631
5	.823	.9877	.9145	.9602	1.094	1.1949	1.0631
6	.7888	.8413	.7682	.9602	1.2071	1.2449	1.0631
7	.6516	.6584	.6219	.6173	.7392	.7095	.6173
8	.7392	.6584	.6241		.7023	.7095	.6219
9	.9511	.8413	.9808	.7468		.695	.7316
10	1.1706	1.1584	1.094	.7842		.695	.695
11		1.134	1.1694	.7682		.7316	.7682
12	1.1706	1.086	.9808	.7316		.7392	.7316
13	1.134	1.0498	1.0185			.8048	.7682
14	.8779	1.086	1.0082	.8048		.8779	.8413
15	1.134	1.1222	1.0974	.9335		.8413	.8413
16	1.134	1.1222		.9145	.823	.8413	.8413
17	.8962	.8131	.7888	.8871	.8962	.8779	.7842
18	.8215	.7682	.7545	.8501	.8589	.823	.8215
19	1.0456	.9145	.823	1.0082	.9431	.8573	.8871
20	1.1576	1.0608	.9259	1.1088	1.0974	.9602	1.0608
21	1.1706	1.0974	1.0631	1.3676	1.39	1.2003	1.0745
22	1.134	1.0608	1.0631	1.3443	1.4563	1.2346	1.0974
23		.9877	1.0288	1.2323	1.2437	.9602	.9774
24	.9259	1.0242	.9145	.9602	1.1827	1.2323	.9945
Max	1.1706	1.1584	1.1694	1.3676	1.4563	1.2449	1.0974
Min	.6516	.6584	.6219	.6173	.7023	.695	.6173
Avg	.9725	.9768	.9260	.9526	1.0771	.9525	.8844

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074005 / 33 kv Chandur s/s

Feeder No / Name : 207 / 11 KV INCOMER NO2

Feeder KV- 11 / INCOMING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.4563	1.3321	1.0974	1.1568	1.1919	.7545
2	1.3717	1.4563	1.3321	1.0631	1.1568	1.1919	.7545
3	1.3717	1.4563	1.3176	1.0631	1.1443	1.1789	.7545
4	1.4403	1.4563	1.3176	1.0288	1.1443	1.1789	.7545
5	1.5364	1.491	1.3176	1.0288	1.1789	1.2136	.7888
6	1.5729	1.5604	1.5257	1.0288	1.1443	1.2483	.7888
7	.6516	.6241	.6241	.6516	.6584	.6935	.6173
8	.7762	.6516	.6241	.6173	.6241	.6588	.6219
9	1.086	1.0867	1.0513	1.595		1.7635	1.7177
10	1.1584	1.1218	1.0852	1.595		1.8652	1.8176
11		1.1568	1.0513	1.4563		1.8652	1.9418
12	1.2269	1.1568	1.0513	1.6297		1.8442	1.9204
13	1.2971	1.1919	1.0852			1.8313	1.893
14	1.2308	1.2269	1.0974	1.6991		1.7635	1.8519
15	1.1568	1.1919	1.1789	.6935		1.0513	
16	1.1919	1.1919		.7975	1.749	.9998	
17	.7282	.7628	.7202	.7975	.8322	1.2003	.7087
18	.7628	.7282	.7682	.7628	.8326	.6859	.815
19	.9362	.9362	.7545	.8954	1.0136	.7202	.9511
20	1.0749	.9362	.7888	1.0745	1.0056	.8916	1.0608
21	1.6297	1.5257	.8573	1.3466	1.3523	1.3375	1.7684
22	1.6644	1.5257	.8573	1.2971	1.387	.8573	1.8378
23			1.1317	1.2269	1.283	.823	1.7684
24	1.3032	1.491	1.3672	1.0974	1.2178	1.2269	.7545
Max	1.6644	1.5604	1.5257	1.6991	1.749	1.8652	1.9418
Min	.6516	.6241	.6241	.6173	.6241	.6588	.6173
Avg	1.2064	1.1906	1.0538	1.1106	1.1106	1.2201	1.2110

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074014 / 33 kv Fuly s/s

Feeder No / Name : 201 / 11 kv Takarkhed Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0648		.6516	.0758	.5144	.0648
2	.0343	.0648		.6379	.0758	.5144	.0648
3	.0343	.0648		.695	.0948	.5144	.0648
4	.0343	.0648		.6878		.6516	.0648
5	.0343	.0648	.4711	.8413		.823	.0648
6	.0343		.9709	1.1218		.9088	
8		.4696					
9		.9069					
10		.9335			.9892		
11		.802			1.0277		
12		.7529			.9614		
13		.6965			.9282		.9511
14		.6212			.7459		1.0056
15		.6413			.7377		1.0692
16		.6602			.7042		
17	.8097		.0914	.1327		.0648	
18	.8583		.0886	.1517		.0648	
19	.0648		.0886	.1706		.0648	.0732
20	.0648		.0914	.0189	.1029	.0648	.0876
21	.0648	.4527	.5304	.0758	.5144	.0648	.7682
22	.0648	.4715	.5853	.0758	.463	.0648	.8413
23	.0648		.6219	.0758	.463	.0648	.8413
24	.0343	.0648		.6135	.1137	.463	.0648
Max	.8583	.9335	.9709	1.1218	1.0277	.9088	1.0692
Min	.0343	.0648	.0886	.0189	.0758	.0648	.0648
Avg	.1594	.4587	.3933	.4250	.5332	.3459	.4305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074014 / 33 kv Fuly s/s

Feeder No / Name : 202 / 11 kv Fuly Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.1619	.0747	.0526	.1829	.0514	.3077
2	.0514	.1619	.0747	.0526	.1829	.0514	.3077
3	.0514	.2267	.0747	.0526	.2195	.0514	.3563
4	.0514	.3077	.0747	.0526	.2743	.0514	.4534
5	.0514	.4534	.0934	.0526	.3109	.0514	.5506
6		.502			.7373		.7935
9	.3688		.8383	.5847		.5533	
10	.4696		.8688	.5344		.6316	
11	.6154		.7133	.5182		.6802	
12	.4696		.5121	.4858		.6802	
13	.3725		.4163	.4696		.7125	
14	.2915		.439	.4534		.4858	
15	.2429		.4755	.3887		.4696	
16	.2429		.5121	.3725		.4534	
17		.056			.0339		.0532
18		.0905			.0514		.0543
19	.0324	.1086	.0549		.0514	.0324	.0543
20	.0324	.0905	.0549	.0747	.0514	.0324	.0543
21	.1619	.0732	.056	.1267	.0514	.1619	.0543
22	.1619	.0732	.0549	.1629	.0514	.1619	.0537
23	.1619	.0747	.0549	.1829	.0514	.2267	.0543
24	.0514	.1619	.0747	.0532	.1646	.0514	.3077
Max	.6154	.502	.8688	.5847	.7373	.7125	.7935
Min	.0324	.056	.0549	.0526	.0339	.0324	.0532
Avg	.2070	.1816	.2904	.2595	.1725	.2942	.2468

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074014 / 33 kv Fuly s/s

Feeder No / Name : 203 / 11 kv Shemba Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.3077	.3109	.2835	.3841	.3601	.4534
2	.2915	.3077	.3292	.2686	.3921	.3429	.4534
3	.2915	.3077	.3109	.2743	.3658	.3429	.4372
4	.2915	.421	.2926	.2686	.4024	.3429	.421
5	.2915	.421	.2926	.2587	.543	.3429	.421
6	.2743	.4696	.2561	.2715	.703	.3429	.3239
7	.285	.2915	.2743	.3045	.2896	.3601	.3077
8	.2683	.2753	.2926	.2804	.2926	.2883	
9	.4024	.2591	.6104	.6135	.3109	.7042	
10	.2915		.5792	.5182	.285	.6154	
11	.1781	.2801	.543	.4534	.2347	.5344	.2658
12	.3725	.2743	.4706	.4696	.218	.5182	.2926
13	.421	.3174	.4344	.4534	.2683	.4858	.2835
14	.4049	.3361	.4344	.3563	.285	.5182	.3109
15	.421	.3326	.4163	.3887	.3185	.5182	.3292
16	.4049	.3142	.4163	.4372	.3521	.5506	
17	.2915	.3881	.3109	.2801	.39	.4372	.3506
18	.3077	.4163	.3292	.3142	.3944	.421	.3856
19	.2915	.4344	.4024	.3511	.4287	.4049	.443
20	.3239	.4525	.4207	.3944	.4287	.3077	.4252
21	.3239	.4207	.3841	.4115	.3772	.4049	.4163
22	.3401	.3841	.3658	.4115	.4287	.3887	.3544
23	.3563	.3292	.3292	.4207	.3772	.421	.3258
24	.3086	.3725	.3109	.2926	.4024	.3601	.421
Max	.421	.4696	.6104	.6135	.703	.7042	.4534
Min	.1781	.2591	.2561	.2587	.218	.2883	.2658
Avg	.3219	.3527	.3799	.3657	.3697	.4297	.3711

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074014 / 33 kv Fuly s/s

Feeder No / Name : 205 / 11 kv Fuly Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1753	.1267	.1512	.1307	.1517	.1578	.1086
2	.1753	.1267	.1517	.112	.1517	.1578	.1086
3	.1753	.1267	.1323	.112	.1327	.1578	.1086
4	.1753	.1267	.1327	.1307	.1517	.1578	.1267
5	.1753	.1448	.1327	.1494	.1517	.1753	.1267
6	.181	.1448	.1517	.1494	.1327	.1734	.1267
7	.1543	.1448	.1517	.1494	.1327	.1387	.1267
8	.1372	.1448	.1137	.1307	.0948	.12	
9	.12	.1629	.1137	.112	.0948	.12	
10	.1267	.1137	.112	.1086	.12	.1267	
11	.1267	.0948	.112	.1267	.12	.1267	.112
12	.1267	.1137	.112	.1267	.1372	.1267	.112
13	.1448	.1327	.112	.1267	.1372	.1267	.112
14	.1448	.1515	.112	.1267	.12	.1267	.112
15	.1448	.1517	.112	.1448	.12	.1448	.112
16	.1448	.1517	.112	.1448	.12	.1448	.112
17	.1448	.1517	.112	.1327	.12	.1448	.1307
18	.1448	.1896	.1307	.1327	.1387	.1629	.1307
19	.1448	.1894	.1448	.1137	.1753	.1629	.168
20	.1629	.2083	.2054	.1706	.1928	.1448	.2054
21	.1629	.1706	.1867	.1896	.1928	.1448	.181
22	.1629	.1896	.168	.1517	.1753	.1629	.168
23	.1629	.189	.1494	.1517	.1578	.1629	.1494
24	.1753	.1629	.1512	.1307	.1327	.1578	.1629
Max	.181	.2083	.2054	.1896	.1928	.1753	.2054
Min	.12	.0948	.112	.1086	.0948	.12	.1086
Avg	.1537	.1504	.1360	.1356	.1398	.1469	.1334

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074014 / 33 kv Fuly s/s

Feeder No / Name : 206 / 11 kv Shemba Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.298	.2353	.2743	.2614	.2987	.298	.2534
2	.298	.2353	.2743	.2241	.2957	.298	.2534
3	.298	.2534	.2561	.2241	.2801	.298	.2353
4	.2804	.2353	.2561	.2427	.2801	.298	.2353
5	.2804	.2172	.2378	.2614	.2614	.298	.2172
6	.2454	.2172	.2241	.2427	.2427	.2427	.2172
7	.1886	.1991	.2054	.2054	.2241	.208	.1991
8	.1886	.2172	.1867	.2054	.2012	.1886	.181
9	.2204	.1991	.1509	.2054	.2241	.1715	.1629
10	.2353	.2195	.168	.1629	.2058	.181	
11	.2105	.2353	.168	.1991	.2229	.1991	.168
12	.2715	.2427	.1867	.2353	.2229	.2172	.1867
13	.3077	.2772	.2427	.2534	.2572	.2172	.2241
14	.3077	.3142	.2427	.2715	.2915	.2172	.2241
15	.3258	.3174	.2427	.2896	.3086	.2353	.2241
16	.3258	.3174	.2427	.3077	.3258	.2534	.2241
17	.3077	.2614	.2614	.2987	.2915	.2896	.2427
18	.2896	.3292	.2987	.3174	.2804	.2896	.2427
19	.3077	.3292	.3361	.2957	.298	.3077	.2801
20	.3077	.3658	.3734	.333	.3681	.3439	.3361
21	.3258	.3475	.3547	.3155	.3681	.3439	.3734
22	.3439	.3292	.3174	.333	.3681	.3258	.3361
23	.2896	.2926	.2987	.3174	.3155	.3439	.3174
24	.298	.3077	.2801	.2801	.2987	.298	.3439
Max	.3439	.3658	.3734	.333	.3681	.3439	.3734
Min	.1886	.1991	.1509	.1629	.2012	.1715	.1629
Avg	.2813	.2706	.2533	.2618	.2805	.2652	.2469

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074014 / 33 kv Fuly s/s

Feeder No / Name : 207 / 11 KV INCOMER NO1

Feeder KV- 11 / INCOMING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.583	.5487	1.1694	.703	1.166	.7449
2	.6173	.583	.5658	1.1163	.703	1.166	.7449
3	.6173	.5992	.5316	1.1517	.6859	1.166	.7125
4	.6001	.6964	.5144	1.1694	.6344	1.286	.6964
5	.6001	.6802	.9054	1.3466	.7712	1.4575	.6802
6	.5487	.664	1.2334	1.701	.9156	1.4918	.5182
7	.4694	.4696	.4359	.4961	.4908	.5658	.4858
8	.4527	.9393	.4458	.4733	.463	.4748	1.4251
9	.6203	1.3441	.7461	.815	.4973	.8718	1.6194
10	.502	1.3375	.7343	.664	1.4754	.7773	
11	.3887	1.2174	.7133	.6316	1.6095	.7125	.4207
12	.6154	1.153	.6447	.6802		.7125	.4557
13	.6964	1.1568	.6697	.6802	1.4586	.6802	1.4175
14	.6802	1.153	.6767	.5992	1.3245	.7125	1.5249
15	.7125	1.1831	.6516	.6478	1.358	.7287	1.595
16	.6964	1.1831	.6516	.7125	1.3748	.7773	.2103
17	1.3765	.6201	.6516	.6516	.6706		.5784
18	1.4251	.6952	.691	.7202	.6539		.6201
19	.6316	.7122	.823	.7545	.7202		.7796
20	.664	.763	.8779	.7783	.8916	.6802	.8149
21	.6802	1.1317	1.262	.8413	1.2517	.7449	1.4899
22	.7125	1.0852	1.262	.8507	1.2517	.7449	1.5074
23	.6964	.583	1.2437	.7545	1.1488	.7935	1.4548
24	.6344	.7125	.5487	1.1568	.7545	1.1145	.7935
Max	1.4251	1.3441	1.262	1.701	1.6095	1.4918	1.6194
Min	.3887	.4696	.4359	.4733	.463	.4748	.2103
Avg	.6773	.8852	.7512	.8568	.9482	.8964	.9257

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074014 / 33 kv Fuly s/s

Feeder No / Name : 208 / 11 KV INCOMER NO2

Feeder KV- 11 / INCOMING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2753	.2263	.1753	.3395	.2058	.4049
2	.2229	.2753	.2263	.1578	.3395	.2058	.4049
3	.2229	.3401	.2075	.1578	.3584	.2058	.4534
4	.2229	.421	.2075	.1753	.4338	.2058	.5668
5	.2229	.583	.2263	.1928	.4711	.2229	.664
6	.1715	.6316	.1517	.1402	.9335	.1715	.9069
7	.1509	.1296	.1518	.1402	.1327	.1372	.1134
8	.1341	.1296	.1132	.1227	.0945	.1187	
9	.4862	.1457	1.0456	.7059	.0948	.6706	
10	.583	.1131	.9568	.6316	.1174	.7449	
11	.7287	.0943	.8145	.6316		.7935	.1052
12	.583	.1129	.6219	.5992	1.5424	.7935	.1052
13	.502	.1318	.5304	.583	.1341	.8259	.1097
14	.421	.1494	.543		.1174	.5992	.1052
15	.3725	.1517	.5792	.5182	.1174	.5992	.1052
16	.3725	.1517	.6219	.502		.583	.1063
17	.1296	.2085	.1109	.132	.1509	.1296	.1772
18	.1296	.2844	.1227	.1323	.1844	.1457	.1753
19	.1619	.3033	.2012	.1134	.2229	.1781	.2126
20	.1781	.3033	.2561	.2452	.2401	.1619	.2454
21	.3077	.2452	.2378	.3206	.2401	.1619	.2279
22	.3077	.2641	.2195	.3206	.2229	.1781	.2103
23	.3077	.2452	.2012	.3395	.2058	.3725	.1991
24	.2229	.2915	.2263	.1753	.3018	.2058	.4534
Max	.7287	.6316	1.0456	.7059	1.5424	.8259	.9069
Min	.1296	.0943	.1109	.1134	.0945	.1187	.1052
Avg	.3069	.2492	.3667	.3136	.3180	.3590	.2882

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074028 / 33 kv Naigaon s/s

Feeder No / Name : 201 / 11 kv Kolasar Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.061		.061		.4572	
2	.061		.061		.4572	
3	.061		.061		.4572	
4	.061		.061		.4572	
5					.4725	
6					.7011	
9			.6249			.9425
10		.8535				
11		.6706				
12		.6401				
13		.6401				
14		.6401				
15		.7316				
16		.7164				
19		.1372		.0457		
20		.0457		.0457		
21		.061		.5487		
22		.061		.5487		
23		.0686		.5182		
24	.061		.061		.4877	
Max	.061	.8535	.6249	.5487	.7011	.9425
Min	.061	.0457	.061	.0457	.4572	.9425
Avg	.061	.4388	.1550	.3414	.4986	.9425

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292] BU 2925

Substation No/ Name :- 074028 / 33 kv Naigaon s/s

Feeder No / Name : 202 / 11 kv Naigaon Ag
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18	02-JUN-18	03-JUN-18	05-JUN-18	06-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1219		.061		.061
2	.1219		.061		.0457
3	.1067		.061		.0457
4	.1067		.061		.0457
5	.1067		.0914		
6	.2286				
7			.1219		
8			.0762		
9					.1981
10				.2743	
11				.1524	.2033
12				.1829	.2033
13				.1981	.2195
14				.2134	
15				.2134	
16				.1219	
19				.0762	
20		.0152		.0762	
21		.0305		.061	
22		.061		.061	
23		.061		.061	
24	.1219		.1067		.061
Max	.2286	.061	.1219	.2743	.2195
Min	.1067	.0152	.061	.061	.0457
Avg	.1306	.0419	.0800	.1410	.1204

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074028 / 33 kv Naigaon s/s

Feeder No / Name : 203 / 11 kv Naigaon Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372		.1372		.1372	
2	.1372		.12		.1372	
3	.1372		.12		.1372	
4	.1372		.12		.1372	
5	.1372		.12		.1372	
6	.1029		.1029		.1067	
7	.0857		.0762		.1029	
8	.1029		.0686		.1219	
9			.0686		.061	.0914
10		.1029		.0686		
11		.12		.1029	.0732	
12		.12		.1067	.0924	
13		.1372		.12	.1109	
14		.1372		.1372	.1109	
15		.12		.1372	.0924	
16		.1067		.1372		
17		.1067		.1372	.1097	
18		.1219		.12	.128	
19		.1543		.1543		
20		.1524		.1715		
21		.1715		.1886		
22		.1715		.1524		
23		.1543		.1524		
24	.1372		.1543		.1372	
Max	.1372	.1715	.1543	.1886	.1372	.0914
Min	.0857	.1029	.0686	.0686	.061	.0914
Avg	.1239	.1340	.1088	.1347	.1137	.0914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074028 / 33 kv Naigaon s/s

Feeder No / Name : 204 / 11 kv Kolasar Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4268		.4458		.4572	
2	.5175		.4287		.442	
3	.5175		.4287		.442	
4	.499		.4287		.442	
5	.499		.4287		.442	
6	.3881		.3601		.381	
7	.3881		.3258		.3201	
8	.3511		.2591		.2591	
9	.3696		.2439		.2591	.3658
10		.3601		.3086		
11		.3772		.3944	.3511	
12		.3944		.4115	.3511	
13		.4115		.4458	.3696	
14		.4458		.4801	.4024	
15		.4287		.4973	.4435	
16		.4287		.5144		
17		.3772		.463	.439	
18		.3944		.4973	.4207	
19		.5658		.6173		
20		.6687		.6344		
21		.6344		.6173		
22		.5487		.5182		
23		.5144		.4877		
24	.4973		.4801		.4572	
Max	.5175	.6687	.4801	.6344	.4572	.3658
Min	.3511	.3601	.2439	.3086	.2591	.3658
Avg	.4454	.4679	.3830	.4920	.3929	.3658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074028 / 33 kv Naigaon s/s

Feeder No / Name : 205 / 11 KV SHELGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	05-JUN-18	06-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353		.3048		.0914
2	.3353		.3048		.0914
3	.3048		.3048		.0914
4	.3048		.3048		.0914
5	.3048		.3048		
6	.5792		.7621		
9					.8078
10				.884	
11				.7011	.7529
12				.6401	.724
13				.5944	.6805
14				.5792	.6516
15				.4572	.6081
16				.5639	.5357
19		.1067		.1372	
20		.1067		.1372	
21		.381		.1067	
22		.3048			
23		.3048		.1067	
24	.6401		.3048		.1067
Max	.6401	.381	.7621	.884	.8078
Min	.3048	.1067	.3048	.1067	.0914
Avg	.4006	.2408	.3701	.4462	.4361

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074029 / 33 kv Nandura s/s

Feeder No / Name : 201 / 11 kv Town

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8099	1.5432	1.4784	1.6461	1.5089	1.6263	1.5364
2	1.7375	1.5089	1.4045	1.6804	1.3717	1.5893	1.4632
3	1.6827	1.5089	1.4045	1.643	1.3717	1.39	1.4937
4	1.6095	1.4403	1.2567	1.6057	1.2689	1.3169	1.4563
5	1.4784	1.4403	1.2197	1.6221	1.2346	1.3306	1.4146
6	1.4632	1.3375	1.2197	1.4003	1.166	1.2567	1.358
7	1.4632	1.166	1.1827	1.3169	1.166	1.2567	1.2696
8	1.2894	1.0631	1.1827	1.1949	.9945	1.1827	
9	1.3535	1.3169	1.0631	1.1827	1.2437	1.0974	1.1203
10	1.39	1.3756	1.0631	1.1827	1.3169	1.166	1.2803
11	1.4632	1.4327	1.0288	1.2567	1.4632	1.166	1.3717
12	1.5364	1.5203	1.0288	1.3306	1.3756	1.166	1.3443
13	1.6461	1.5927	1.0631	1.4045	1.5043	1.2346	1.3032
14	1.7551	1.6095	1.0631	1.5893	1.6095	1.3375	1.4632
15	1.7924	1.7375	1.1576	1.6263	1.6476	1.3375	1.5364
16	1.8107	1.7558	1.0631	1.6632	1.6827	1.3717	1.6095
17	1.6118		1.2936	1.4403		1.4937	1.5203
18	1.5775		1.39	1.643		1.531	1.3611
19	1.5775	1.848	1.531	1.6804		1.6804	1.6651
20	1.6461	1.848	1.643	1.5775		1.7177	1.7193
21	1.6461	1.7002	1.6975	1.7551		1.6461	1.7375
22	1.7147	1.6263	1.6804	1.6804		1.6804	1.7193
23	1.7147	1.5893		1.5432		1.6095	1.829
24	1.9022	1.7147	1.5524	1.7177	1.5432	1.6263	1.5684
Max	1.9022	1.848	1.6975	1.7551	1.6827	1.7177	1.829
Min	1.2894	1.0631	1.0288	1.1827	.9945	1.0974	1.1203
Avg	1.6113	1.5307	1.2899	1.5160	1.3805	1.4088	1.4844

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074029 / 33 kv Nandura s/s

Feeder No / Name : 202 / 11 kv Dairy

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	03-JUN-18	04-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.9753		1.7924
2			1.9791		1.8107
3			1.9791		1.7551
4			1.9239		1.7551
5			1.9044		1.6975
6			1.4937		1.4712
7			1.3817		1.5089
8			1.3443		
9	1.5844				1.1203
10	1.587				1.3717
11	1.6804				1.4937
12	1.7353				1.531
13	2.0911				
14	2.1658				
15	2.1879				
16	2.1658				
17		1.531		1.8671	
18		1.5364		1.7924	
19		1.6975		1.7558	
20		1.7924		1.7924	
21		1.8484		1.8861	
22		1.8861		1.829	
23				1.8861	
24			2.0165		1.8861
Max	2.1879	1.8861	2.0165	1.8861	1.8861
Min	1.5844	1.531	1.3443	1.7558	1.1203
Avg	1.8997	1.7153	1.7776	1.8298	1.5995

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074029 / 33 kv Nandura s/s

Feeder No / Name : 203 / 11 kv Rural Ag Feeder
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0156			.0154		.0156
2		.0156			.0156		.0168
3		.016			.0312		.0168
4		.0158			.0312		.0168
5		.0158			.0312		.0166
6		.0312			.0373		.0339
9	.0164		.0156	.0145		.032	
10	.0335		.0312	.0145		.0312	
11	.0324		.0312	.0145		.0312	
12	.0324		.0312	.0145		.0312	
13	.0332		.032	.0145		.032	
14	.0328		.0309			.032	
15	.0328		.0373	.0145		.0312	
16	.0373		.032	.0145		.032	
21	.0156					.0312	
22	.0312			.0312		.0309	
23	.0309			.0312		.0347	
24		.016			.0156		.0339
Max	.0373	.0312	.0373	.0312	.0373	.0347	.0339
Min	.0156	.0156	.0156	.0145	.0154	.0309	.0156
Avg	.0299	.018	.0302	.0182	.0254	.0318	.0215

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074029 / 33 kv Nandura s/s

Feeder No / Name : 205 / JALAGAON ROAD FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4435	.5228	.2957	.439	.4481	.4435	.4108
2	.4066	.5228	.2957	.4481	.4108	.4435	.4108
3	.3734	.4481	.2957	.4108	.4108	.4435	.3734
4	.3734	.4481	.2957	.4024	.3361	.4066	.3734
5	.3696	.3734	.2957	.415	.3361	.4066	.3658
6	.3696	.3734	.2957	.3734	.2987	.4066	.3292
7	.3696	.3361	.2957	.2987	.2241	.4066	.3395
8	.3696	.2614		.2614	.2241	.3696	
9	.3292	.1109	.2614	.2587	.2957	.3734	
10	.3292	.3696	.2614	.2957	.3018	.4108	
11	.3658	.2957	.2614	.2957	.3658	.4481	.0754
12	.3658	.3696	.2614	.2957		.4481	.0754
13	.439	.3696	.2987	.2957	1.6221	.4481	.0754
14	.4481	.3772	.3361	.3326	.439	.5228	.3696
15	.439	.4435	.3361	.3326	.5068	.5228	.3696
16	.4481	.439	.3361	.3292	.4435	.5228	.439
17	.4481		.2926	.3361		.3658	.4435
18	.4108		.2926	.3734		.3734	.3544
19	.4108	.2926		.4108		.3772	.3582
20	.4481	.4066	.3658	.4481		.3734	.4298
21	.5228	.4805	.4527	.4481		.4024	.4481
22	.5228	.4066	.4527	.5228		.4108	.4481
23	.5975	.3326		.5228		.3898	.4435
24	.5175	.5975	.3326	.4481	.5228	.4805	.4481
Max	.5975	.5975	.4527	.5228	1.6221	.5228	.4481
Min	.3292	.1109	.2614	.2587	.2241	.3658	.0754
Avg	.4216	.3899	.3148	.3748	.4491	.4249	.3515

Feederwise Load Information for **All Feeders**

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074029 / 33 kv Nandura s/s

**Feeder No / Name : 401 / 33KV MAIN INCOMMER FEEDER NON SHEDDABLE WATER SUPPLY AND
TO N Feeder KV- 33 / INCOMING UTILITY**

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	8.2305	8.1219		8.2305	8.738		8.1207
2	8.0361	7.8418		8.2899	8.738		8.011
3	8.011	7.7298		8.1779	8.4019		8.0361
4	7.9836	7.2817		8.011	8.2899		8.1219
5	7.8418	6.7215		7.7298	7.2817		7.5217
6	7.5823	6.4415		7.1331	6.8896		6.8587
7	5.2669	6.4415		4.4993	5.2652		6.6941
8	5.048	5.0412	4.269	4.4445	5.3212	5.2115	
9	7.1879	7.5617	4.8171		7.7858	7.2817	7.4389
10	7.1331	6.2574	5.3212		8.2053	7.7298	6.5844
11	7.5172	8.514	5.6013		8.5934	8.4019	8.2305
12	8.1779	8.738	5.8253		8.1219	8.9621	8.4271
13	8.5597	8.794	7.8418		9.2421	9.0181	8.7043
14	8.4888	9.0741	7.7298		9.5782	9.2421	8.0659
15	9.0181	9.5222	7.1696		10.0263	9.4662	8.9621
16	8.9621	9.4662	8.3459	8.7792	10.0903	9.6342	9.1861
17	8.85		7.5057	6.6655		6.6095	5.7939
18	6.7215		6.5535	6.7215		5.8368	5.4161
19	6.8896		5.2126	6.7215		5.2058	5.8471
20	6.7215		6.2552	7.2817		6.4975	6.6787
21	7.0016		8.1207	9.1861		7.9561	9.7462
22	7.2817		8.714	7.8418		8.1779	9.9703
23	7.5617			8.1219		8.1207	9.7462
24	8.6008			8.2305	8.4705	9.0924	8.2305
Max	9.0181	9.5222	8.714	9.1861	10.0903	9.6342	9.9703
Min	5.048	5.0412	4.269	4.4445	5.2652	5.2058	5.4161
Avg	7.6114	7.7218	6.6188	7.4156	8.1788	7.7908	7.8432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074029 / 33 kv Nandura s/s

Feeder No / Name : 402 / 33 KV Outgoing fdr
Feeder KV- 33 / INCOMINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.2922	3.2487		3.5231	3.638		3.6214
2	3.2922	2.9127		3.6214	3.3608		3.5665
3	3.2373	2.8006		3.6763	3.2487		3.6408
4	3.3265	2.2405		3.5665	2.6886		3.3808
5	3.3608	2.2405		3.6408	2.9127		2.9412
6	3.3385	1.8461		3.5848	3.0247		3.2076
7	1.3717	1.6804		1.1043	1.3443		3.4179
8	1.3169	1.4563	1.1088	1.1523	1.2883	1.4969	
9	2.8487	4.0175	1.7924		3.1687	2.1285	4.525
10	3.0498	2.7978	1.7364		4.5833	2.9127	4.561
11	3.5117	4.6965	1.8461		4.6399	3.8089	5.0412
12	3.8409	4.5268	2.1285		4.5268	4.9291	5.0926
13	4.0604	4.6296	2.7446		4.9794	3.8089	5.2624
14	3.8009	4.5833	2.6886		4.9794	4.369	4.1152
15	3.6408	4.6965	2.8006		5.2624	4.6491	4.8663
16	3.5368	4.6399	4.145	2.0302	5.2624	4.8171	4.5833
17	2.8006		3.2373	2.6886		1.8107	1.6655
18	2.3525		2.8292	2.5206		1.5769	1.5604
19	2.1845		1.7924	2.2405		1.4232	1.773
20	2.2405		1.9204	2.4646		2.1068	2.1262
21	2.8006		3.9209	4.201		3.4082	4.9291
22	2.9127		4.1872	2.9127		3.7529	5.1492
23	3.2487			3.3608		3.7311	4.7531
24	3.4168	3.1493		3.6763	3.638	4.269	3.7311
Max	4.0604	4.6965	4.1872	4.201	5.2624	4.9291	5.2624
Min	1.3169	1.4563	1.1088	1.1043	1.2883	1.4232	1.5604
Avg	3.0326	3.3037	2.5919	2.9391	3.6792	3.2352	3.8048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074042 / 33 kv Sujatpur s/s

Feeder No / Name : 201 / 11 kv Chikhali Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.0373	.1097	.0133	.0514	.1187	
2	.1372	.0373	.1257	.0133	.0343	.116	
3	.1372	.0373	.1257	.0171	.0343	.1174	
4	.1372	.0373	.1238	.0191	.0343	.1492	
5	.1543	.0373	.1238	.0229	.0343	.1943	
6	.1696	.0373	.1257	.0229		.2881	
9		.2915			.2915		.1734
10		.2105			.208		.0305
11		.1486			.1898		.0324
12		.1486			.16		.0343
13		.1362			.1423		.0343
14		.1383			.1265		.0286
15		.1362			.1311		.0229
16		.1219			.1457		.0229
17							.0229
19			.0038				.0038
20	.056		.0038	.0514	.056		.0057
21	.056		.0152	.0514	.1658		.0152
22	.056	.1006	.0152	.0514	.1658		.0191
23	.056	.0975	.0152		.1492		.0191
24	.12	.0373	.1021	.0152	.0514	.1326	
Max	.1696	.2915	.1257	.0514	.2915	.2881	.1734
Min	.056	.0373	.0038	.0133	.0343	.116	.0038
Avg	.1106	.1054	.0741	.0278	.1207	.1595	.0332

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292] BU 2925

Substation No/ Name :- 074042 / 33 kv Sujatpur s/s

Feeder No / Name : 202 / 11 kv Amboda Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.176			.3429		.1858
2		.1638			.3429		
3		.1638			.3429		
4		.2267			.3429		
5		.2561			.4115		
6		.3841			.6036		
8				.3772			
9	.4115		.4527	.3772		.6325	
10	.4161		.0629	.4694		.4527	
11	.4641		.0629	.6133		.4458	
12	.3681		.0629	.5487		.3395	
13	.3401		.0514	.4694		.3269	
14	.2753		.0533	.3086		.3498	
15	.2561		.0533	.3944		.3467	
16	.2881		.0572	.4801		.3772	
21	.213			.3601		.2601	
22	.2267			.3429		.2477	
23	.213			.3429		.2138	
24		.1781			.3429		.1981
Max	.4641	.3841	.4527	.6133	.6036	.6325	.1981
Min	.213	.1638	.0514	.3086	.3429	.2138	.1858
Avg	.3156	.2212	.1071	.4237	.3899	.3630	.1920

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074042 / 33 kv Sujatpur s/s

Feeder No / Name : 203 / 11 kv Amboda Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2378	.2229	.1463	.0286	.2926	.2204	.1238
2	.2218	.208	.1238	.0286	.2926	.2103	.1276
3	.2033	.208	.1238	.0305	.2743	.2103	.1383
4	.2012	.2035	.1257	.0343	.2715	.2103	.1257
5	.2012	.1734	.1257	.0343	.2686	.1886	.1238
6	.1829	.1696	.1238	.0381	.2743	.1886	.1257
7	.1646	.1753	.1115	.0381	.2012	.1886	.1132
8	.1829	.1372	.1132	.0549	.2172	.1696	.088
9	.1463	.1677	.0991	.0543	.2195	.1402	.1115
10	.1844	.0854	.0133	.1463	.2035	.088	.0171
11	.213	.1362	.0133	.0716	.2035	.1115	.0171
12	.2321	.1509	.0152	.2507	.2058	.1115	.0171
13	.2321	.161	.0191	.2686	.2374	.1257	.0171
14	.2347	.161	.021	.2686	.2652	.1404	.0171
15	.2374	.1734	.021	.3012	.2713	.1383	.021
16	.2155	.1734	.021	.2865	.2543	.1509	.021
17	.2204		.021	.2743	.2254	.1383	.0229
18	.2058		.021	.2926	.2683	.1276	.0229
19	.2204		.0229	.3077		.1383	.0305
20	.1734	.2515	.0286	.3761	.1214	.176	.0305
21	.2254	.2105	.0286	.3761	.2374	.2105	.0305
22	.2204	.2042	.0229	.3658	.2204	.2012	.0248
23	.2204	.176	.0229	.3292	.2254	.176	.0248
24	.2378	.2229	.1734	.0229	.3109	.2254	.1734
Max	.2378	.2515	.1734	.3761	.3109	.2254	.1734
Min	.1463	.0854	.0133	.0229	.1214	.088	.0171
Avg	.2090	.1796	.0649	.1783	.2418	.1661	.0652

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074042 / 33 kv Sujatpur s/s

Feeder No / Name : 204 / 11 kv Industrial feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0537	.1147	.0629	.0114	.1075	.112	.0619
2	.0543	.0949	.0619	.0114	.1075	.0949	.0629
3	.0537	.0949	.0754	.0095	.1075	.0983	.0629
4	.0532	.096	.0743	.0095	.0895	.0937	.0629
5	.0537	.0949	.0619	.0095	.0886	.0949	.0743
6	.0532	.1107	.061	.0095	.0895	.0937	.0743
7	.0709	.0949	.0629	.0095	.0895	.1094	.0503
8	.0716	.064	.0619	.0886	.0886	.0937	.0377
9	.0709			.0886	.0532	.0309	.0377
10	.064			.0876	.032	.0259	.0038
11	.0648				.0324	.0248	.0038
12	.0655			.0532	.048	.0495	
13	.0819	.0495	.0114	.0532	.08	.0867	.0095
14	.0819	.0619	.0114	.0526	.096	.0867	.0038
15	.0633	.0638	.0114	.0709	.0972	.088	.0114
16	.0791	.0732	.0095	.0709	.0937	.0867	.0114
17	.064		.0095	.0701	.096	.0743	.0095
18	.0655		.0095	.0709	.08	.0743	.0095
19	.08	.0619	.0095	.0716	.0949	.0754	.0114
20	.1107	.0754	.0095	.0886	.0949	.0743	.0114
21	.1107	.0743	.0095	.0895	.0937	.0754	.0114
22	.1134	.0629	.0133	.0895	.0937	.0754	.0095
23	.112	.0629	.0133	.1063	.1107	.0629	.0095
24	.0537	.1134	.0619	.0133	.1063	.112	.0629
Max	.1134	.1147	.0754	.1063	.1107	.112	.0743
Min	.0532	.0495	.0095	.0095	.032	.0248	.0038
Avg	.0727	.0813	.0351	.0537	.0863	.0789	.0306

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074042 / 33 kv Sujatpur s/s

Feeder No / Name : 205 / 11 kv Chikhali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1433	.1014	.088	.0133	.1254	.1158	.088
2	.1254	.1014	.0894	.0133	.1075	.0869	.0867
3	.124	.0823	.0743	.0114	.1075	.0869	.0754
4	.1254	.0823	.0754	.0114	.1063	.0846	.0754
5	.1254	.0823	.0743	.0095	.1075	.0869	.0743
6	.1417	.0869	.0743	.0095	.1063	.0869	.0754
7	.1063	.0724	.0777	.0095	.0905	.0869	.0743
8	.1612	.096	.0743	.0895	.0886	.1014	.088
9	.2303	.1158	.0619	.0886	.0886	.1235	.1166
10	.192	.2012	.0191	.0895	.0686	.176	.0248
11	.2134	.1486	.0191	.1791	.0686	.2263	.0248
12	.1974	.2073		.1772	.0667	.2138	.0248
13	.192	.1886	.021	.1772	.0823	.1951	.0248
14	.2195	.1886	.0324	.1772	.2	.2298	.0267
15	.2195	.1734	.0324	.1791	.2115	.2298	.0248
16	.2134	.176	.0286	.1772	.2	.2298	.0248
17	.2195		.0286	.1402		.1486	.0171
18	.1372		.0248	.1417	.192	.1296	.0171
19	.1391	.1115	.0286	.1254	.1734	.1115	.0191
20	.1448	.1383	.0191	.1772	.1509	.1132	.0191
21	.1448	.1257	.0191	.197	.1391	.1132	.0191
22	.1158	.1115	.0171	.1772	.1372	.1006	.0133
23	.1158	.0991	.0171	.1433	.1303	.1006	.0133
24	.1433	.1128	.1006	.0095	.124	.1158	.0991
Max	.2303	.2073	.1006	.197	.2115	.2298	.1166
Min	.1063	.0724	.0171	.0095	.0667	.0846	.0133
Avg	.1621	.1274	.0477	.1052	.1249	.1372	.0478

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074042 / 33 kv Sujatpur s/s

Feeder No / Name : 206 / 11 KV INCOMER

Feeder KV- 11 / INCOMING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5914	.6706	.5973	.0667	.9313	.5868	.6697
2	.5601	.6203	.5731	.0667	.8954	.5375	.6584
3	.5415	.6036	.5792	.0686	.8775	.5375	.3982
4	.5415	.6859	.5853	.0743	.8596	.5548	.3841
5	.5601	.6783	.5611	.0762	.985	.5868	.3982
6	.5729	.8029	.5611	.08	1.134	.6874	.3982
7	.3511	.3681	.362	.0572	.3801	.4207	.3439
8	.4251	.3506	.2715	.6335	.4066	.4031	.2715
9	.8962	.6104	.8869	.6468	.6697	.9667	.4334
10	.9012	.724	.0953	.8326	.5365	1.0679	.0762
11	1.0159	.6335	.0953	.9231	.5138	1.1765	.0781
12	.9012	.7164	.0781	1.0679	.503	1.0317	.08
13	.8951	.7865	.1029	1.0029	.5636	1.0791	.0819
14	.8619	.788	.1181	.8238	.7373	1.1643	.0819
15	.8192	.788	.1181	.9774	.7459	1.1584	.08
16	.8619	.788	.1162	1.0387	.7459	1.2254	.08
17	.5721		.0591	.5853	.333	.5249	.0495
18	.4557		.0553	.5175	.6135	.4706	.0495
19	.4908	.2534	.0648	.5175	.333	.4706	.0648
20	.5201	.6767	.061	.7207	.4681	.5249	.0667
21	.7712	.5973	.2896	.7164	.6783	.8507	.0762
22	.7459	.6878	.0686	1.0498	.6539	.905	.0667
23	.7293	.6335	.0686	1.0059	.6443	.7964	.0667
24	.5729	.6796	.6335	.061	.9694	.6104	.7783
Max	1.0159	.8029	.8869	1.0679	1.134	1.2254	.7783
Min	.3511	.2534	.0553	.0572	.333	.4031	.0495
Avg	.6731	.6429	.2918	.5671	.6741	.7641	.2388

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074066 / 33 kv Mahalungi s/s

Feeder No / Name : 201 / 11 kv Maha Gfss

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0274	.2614	.2561	.2507	.0256	.3142	.2427
2	.0274	.2614	.2378	.2507	.0256	.3142	.2241
3	.0274	.2427	.2378	.2328	.0219	.3174	.2427
4	.0274	.2427	.2195	.2328	.0219	.2957	.2614
5	.0274	.2054	.2195	.2328	.0219	.2926	.2801
6	.0219	.1867	.1829	.197	.0201	.2561	.2427
7	.0183	.1867	.1829	.1612	.0201	.1829	.1867
8	.0183	.168	.1646	.1612	.0146	.1646	.168
9	.0183	.1867	.1829	.0165	.0146	.1463	.168
10	.2054	.1991	.1612	.0183	.1612	.1494	.1791
11	.2427	.2172	.197	.0201	.1595	.1307	.197
12	.2801	.2427	.2149	.0183	.1791	.168	.197
13	.2801	.2587	.2328	.0219	.1772	.168	.2149
14	.2987	.2926	.2507	.0274	.2195	.2241	.2507
15	.2801	.3109	.2507	.0293	.2561	.2427	.2686
16	.3174	.3475	.2507	.0293	.2926	.2614	.2507
17	.2801		.2328	.0256	.2743	.2614	.2507
18	.2614		.2507	.0238	.2561	.2614	.2507
19	.2801	.3361	.2686	.0311	.3018	.2614	.2507
20	.4108	.3841	.3045	.0384	.3547	.3547	.3224
21	.3547	.3292	.3224	.0348	.3658	.3547	.3224
22		.3292	.2865	.3073	.3109	.2987	.3224
23	.2987	.2926	.2507		.2926	.2801	.2686
24	.0274	.2614	.2561	.2507	.2641	.3109	.2427
Max	.4108	.3841	.3224	.3073	.3658	.3547	.3224
Min	.0183	.168	.1612	.0165	.0146	.1307	.168
Avg	.1753	.2610	.2339	.1136	.1688	.2505	.2419

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074066 / 33 kv Mahalungi s/s

Feeder No / Name : 202 / 11 kv Maha Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0055	.0671	.0423	.0526	.0073	.0406	.0509
2	.0055	.0686	.0423	.052	.0073	.0406	
3	.0055	.0686	.0412	.0526	.0073	.0406	
4	.0055	.0514	.0423	.052	.0091	.0406	
5	.0055	.1174	.0564	.052	.0146	.0406	
6		.2012			.0183		
9	.0165		.08	.0293			
10	.285		.3155	.0274		.2347	
11	.2515		.2804	.0073		.3018	
12	.2155		.208	.0165		.1844	
13	.1658		.1753	.0146		.1492	
14	.1326		.2103	.0128		.1326	
15	.116		.208	.0146		.1174	
16	.1677		.208	.0128		.1174	
19	.0514	.0423	.052	.0055	.0566	.0509	.2454
20	.0514	.0423	.052	.0073	.0423	.0509	.0526
21	.0671	.04	.052	.0073	.0423	.0509	.0526
22	.0503	.04	.0526	.0091	.0406	.0509	.0526
23	.0671	.04	.0526	.0754	.0406	.0509	.0526
24	.0055	.0671	.0429	.0526	.0754	.0412	.0503
Max	.285	.2012	.3155	.0754	.0754	.3018	.2454
Min	.0055	.04	.0412	.0055	.0073	.0406	.0503
Avg	.0879	.0705	.1165	.0291	.0301	.0965	.0796

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074066 / 33 kv Mahalungi s/s

Feeder No / Name : 203 / 11 kv Tarw Gfss

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0293	.2987	.3361	.3582	.0293	.3292	.2614
2	.0293	.2801	.3361	.3403	.0293	.3326	.2427
3	.0293	.2801	.3174	.3403	.0293	.3361	.2427
4	.0293	.2614	.3142	.3403	.0293	.3174	.2427
5	.0293	.2614	.2772	.3403	.0293	.2926	.2614
6	.0238	.2427	.2614	.3224	.0274	.2587	.2427
7	.0201	.2054	.2614	.2328	.0219	.2218	.2054
8	.0201	.2054	.2195	.2328	.0219	.1646	
9	.0165	.2054	.1829	.0274	.0256	.1646	.1494
10	.2614	.2172	.1612	.0274	.2686	.1494	.1791
11	.2801	.3224	.2149	.0402	.3366	.1494	.2149
12	.2987	.3361	.2686	.0384	.3439	.2614	.2149
13	.3361	.2987	.3045	.0402	.3696	.2801	.2507
14	.3361	.3174	.3224	.0366	.3142	.3361	.2686
15	.3174	.3174	.3582	.0366	.3109	.3174	.2865
16	.2987	.3547	.3582	.0329	.2957	.2987	.2865
17	.2801		.3761	.0439	.3292	.2987	.3224
18	.2987		.3045	.0311	.3475	.2801	.2865
19	.3361	.3547	.3224	.0348	.3584	.2987	.3224
20	.4294	.4294	.4119	.0476	.4668	.1307	.3761
21	.3921	.4108	.4298	.0421	.4108	.2987	.3582
22	.3547	.3921	.394	.3961	.4108	.2801	.3403
23	.3361	.3547	.3761	.3395	.3921	.2801	.3045
24	.0293	.2987	.3584	.3582	.3018	.3326	.2614
Max	.4294	.4294	.4298	.3961	.4668	.3361	.3761
Min	.0165	.2054	.1612	.0274	.0219	.1307	.1494
Avg	.2005	.3020	.3111	.1700	.2292	.2671	.2661

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074066 / 33 kv Mahalungi s/s

Feeder No / Name : 204 / 11 kv Tarwadi Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0128	.0848	.0406	.1734	.0055		.0848
2	.0128	.0678	.0406	.1734	.0055		.0848
3	.0128	.0678	.04	.1753	.0055		.0678
4	.0128	.0678	.04	.1753	.0055		.0678
5	.0165	.0838	.0533	.1753	.0055		.0848
6	.0201		.0934	.4508			
9		.3856			.0476		.3932
10		.2743			.3807		.6068
11		.2397			.3429		.5258
12		.1974			.282		.4207
13		.1783			.2401		.4207
14		.1829			.2397		.3856
15		.1467			.2364		.3506
16		.1334			.2256		.3856
17					.2256		
19	.1017		.104	.0091	.0754	.1509	.0876
20	.1006		.1075	.0091	.0541	.0838	.0876
21	.1017	.04	.1734	.0073	.0947	.0838	.0876
22	.1006	.04	.1753	.0091		.0838	.156
23	.0838	.04	.156	.0754		.0838	.1578
24	.0128	.0848	.0412	.156	.0754		.0838
Max	.1017	.3856	.1753	.4508	.3807	.1509	.6068
Min	.0128	.04	.04	.0073	.0055	.0838	.0678
Avg	.0491	.1362	.0888	.1325	.1415	.0972	.2389

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074066 / 33 kv Mahalungi s/s

Feeder No / Name : 206 / 11 KV INCOMER

Feeder KV- 11 / INCOMING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0205	.6984	.6371	.8507	.0201	.6588	.6268
2	.0207	.6626	.6344	.8326	.0203	.6661	.5973
3	.0209	.6335	.4801	.8145	.0205	.6661	.543
4	.0207	.6154	.583	.8145	.0203	.631	.5611
5	.0205	.6626	.5959	.8145	.0203	.6135	.6154
6	.0201	.6268	.583	.9955	.0201	.4908	.4755
7	.0209	.3841	.4161	.3982	.0207	.3856	.3841
8	.021	.3658	.463	.3982	.1963	.3856	
9	.0203	.788	.4458	.0205	.0207	.5316	.7522
10	.7522	.7449	.6516	.0209	.8551	.5959	.9955
11	.7701	.7522	.7059	.0201	.8987	.4382	.9593
12	.788	.7373	.6984	.0201	.8215	.6089	.8507
13	.7602	.7373	.724	.0201	.8048	.591	.8954
14	.7522	.7716	.788	.0203	.8139	.6805	.9231
15	.7701	.7888	.8238	.0203	.8139	.6697	.9231
16	.7701	.8573	.8238	.0203	.8215	.6697	.9412
17	.5487		.6089	.0205	.5658	.5487	.5792
18	.5487	.2572	.5552	.0209	.5658	.5249	.543
19	.7602	.6859	.7522	.0207	.7922	.7522	.9231
20	.9671	.8059	.8775		.9114	.6089	.8507
21	.8775	.823	.9955	.0201	.8059	.7701	.8326
22	.8238	.7716	.9134	.0201	.7537	.6984	.8869
23	.788	.703	.8507		.6859	.6805	.7964
24	.0203	.591	.6371	.724	.6602	.6516	.5552
Max	.9671	.8573	.9955	.9955	.9114	.7701	.9955
Min	.0201	.2572	.4161	.0201	.0201	.3856	.3841
Avg	.4535	.6724	.6769	.3140	.4971	.6049	.7396

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074073 / 33 kv Nimgaon s/s

Feeder No / Name : 201 / 11 kv Alampur Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.5868	.5506	.6706	1.0059	.8002	1.3375
2	.3658	.5868	.5506	.6706	1.0059	.8002	1.3413
3	.3658	.5868	.4999	.6706	1.0059	.8002	1.1584
4	.3658	.5868	.5624	.6706	.9755	.8002	1.1584
5	.3963	.6401	.6154	.6706	1.0059	.8269	1.1279
6	.3963	.6935	.6802	.6706	1.0669	.8269	1.3413
9	1.004	.884		1.2955		1.307	.9069
10	1.1336	.945		1.3927	1.0974	1.547	.9335
11	1.166	.8535		1.4575	.9145	1.467	.9869
12	1.1248	.1524	.2934	1.4419	.9095	1.4937	.9869
13	1.0936	.7011	.6401	1.3123		1.4937	1.0136
14	1.1469	.7316	.9602	1.3108	.8619	1.4403	.8935
15	1.1012	.7621	1.1203	1.2631	.9511	1.307	1.0136
16	1.0364	.7621	1.3203	1.2803	.9389	1.7375	1.0136
17			1.1888				
18			1.1584				
21	.5601		.5792	.9755	.6935	1.1736	.9389
22	.5601	.5182	.7316	1.0856	.8002	1.4963	.9976
23	.5868	.583	.7011	1.0669	.8002	1.467	.9511
24	.3353	.5868	.5506	.7011	1.0364	.8535	1.4377
Max	1.166	.945	1.3203	1.4575	1.0974	1.7375	1.4377
Min	.3353	.1524	.2934	.6706	.6935	.8002	.8935
Avg	.7280	.6565	.7472	1.0337	.9419	1.2021	1.0855

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074073 / 33 kv Nimgaon s/s

Feeder No / Name : 203 / 11 kv Nimgaon Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0498	.9808	.9175	.905	.9774	1.094	1.0136
2	1.0029	.9431	.8421	.8688	.9774	1.094	1.0136
3	1.0136	.9431	.8192	.8688	.9412	1.094	.9774
4	.9774	.9431	.7537	.8326	.905	1.0185	.9774
5	.9313	.9808	.7209	.788	.9145	1.0185	.9774
6	.905	.7922	.7865	.7522	.8688	1.0185	.7602
7	.7602	.7545	.6554	.6516	.6878	.8299	.724
8	.6805	.724	.5937	.5731	.724	.7545	
9	.6802	.6805	.7545	.6226	.6219	.7167	.7545
10	.7125	.724	.7922	.6478	.6219	.6413	.8299
11	.7865	.7964	.8299	.6802	.6089	.7545	.8676
12	.8421	.8688	.8299		.8688	.8299	.8676
13	.8848	.9145	.8299	.4534	.9412	.9054	.9431
14	.9175	.9877	.8676	.4858	.9877	.9431	.9054
15	.9069	.9671	.9054	.6154	1.0029	1.0136	.8676
16	.8745	.9313	.8688	.9412	1.0029	.9671	.8299
17	.9808		.8688	.9313	1.0185	.9412	.8688
18	1.0562		.8238		1.1317	.8326	.8688
19	1.1694	.7773	.8596	1.0745	1.2071	1.0498	.8326
20	1.2449	1.1012	1.0029	1.3032	1.358	1.1584	1.1462
21	1.2071	1.0688	1.0608	1.2308	1.2826	1.1222	1.1222
22	1.094	1.0364	.9671	1.1706	1.2449	1.0745	1.1222
23	1.0185	1.004	.9412	1.0387	1.1317	1.0498	1.0745
24	1.0498	.9431	.9717	.905	1.0029	1.1317	1.0029
Max	1.2449	1.1012	1.0608	1.3032	1.358	1.1584	1.1462
Min	.6802	.6805	.5937	.4534	.6089	.6413	.724
Avg	.9478	.9029	.8443	.8337	.9596	.9606	.9281

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074073 / 33 kv Nimgaon s/s

Feeder No / Name : 204 / 11 kv Nimgaon Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0059		1.2125	1.2803		1.3603	
2	.9755		1.2125	1.2803		1.387	
3	.9511		1.1984	1.3108		1.387	
4	1.0402		1.3108	1.3413		1.5257	
5	1.0997		1.3763	1.3717		1.4137	
6	1.1584		1.4419	1.4022		1.4137	
9		1.5242			1.813		1.5737
10					1.8191		1.627
11		1.6766			1.9022		1.6804
12		1.6766			1.7017		1.6804
13		1.5546			1.6941		
14		1.7909			1.6049		.9602
15		1.4327			1.5844		1.2003
16		1.4937			1.7535		1.2536
21			1.2186		1.2803		1.379
22		1.0688	1.576		1.3603		1.467
23		1.2308	1.2803		1.3336		1.4563
24	1.0059		1.1984	1.2803		1.467	
Max	1.1584	1.7909	1.576	1.4022	1.9022	1.5257	1.6804
Min	.9511	1.0688	1.1984	1.2803	1.2803	1.3603	.9602
Avg	1.0338	1.4943	1.3026	1.3238	1.6225	1.4221	1.4278

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074073 / 33 kv Nimgaon s/s

Feeder No / Name : 205 / 11 kv Alampur Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2926	.2641	.2591	.2561	.2561	.2641	.2561
2	.2926	.2263	.2267	.2561	.2561	.2641	.2561
3	.2926	.2263	.2187	.2561	.2561	.2641	.2561
4	.2926	.2263	.2294	.2561	.2561	.2641	.2561
5	.2926	.2263	.2294	.2561	.2561	.2641	.2561
6	.2561	.2641	.2294	.2561	.2561	.3018	.2195
7	.1829	.2263	.1966	.2195	.2561	.2641	.1829
8	.2195	.2263		.1829	.1829	.1886	
9	.1875	.1463		.1619	.1829	.1886	.2263
10	.2294	.2195		.1875	.2195	.1886	.2263
11	.2267	.2195			.2195	.2263	.2641
12	.25	.2926		.2267	.2195	.2263	.2263
13	.2915	.2926		.2591	.2561	.2263	.2641
14	.2915	.2926		.25	.2561	.2641	.2641
15	.2915	.2926		.25	.2561	.2926	.3018
16	.2591	.2926	.3292	.2926	.2561	.2926	.3018
17	.2641		.2926	.2926	.2641	.2926	.2561
18	.3018		.2926		.1509	.2926	.2561
19	.3395	.2591	.2926	.2926	.1334	.2926	.2561
20	.3395	.3563	.2926	.3658	.1886	.2926	.3292
21	.3772	.3239	.3292	.3292	.3772	.2926	.2926
22	.3395	.2915	.2926	.3292	.3395	.2926	.2926
23	.3018	.2591	.2926	.2926	.3772	.2926	.2926
24	.2926	.3018	.2591	.2926	.2561	.2641	.2926
Max	.3772	.3563	.3292	.3658	.3772	.3018	.3292
Min	.1829	.1463	.1966	.1619	.1334	.1886	.1829
Avg	.2794	.2603	.2664	.2619	.2470	.2622	.2620

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074073 / 33 kv Nimgaon s/s

Feeder No / Name : 207 / 11 KV INCOMER NO2

Feeder KV- 11 / INCOMING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.5868	.6478	.8383	1.2955	.8535	1.7147
2	.4572	.5868	.6478	.8383	1.2574	.8002	1.6766
3	.4572	.5868	.6097	.8383	1.2574	.8002	1.448
4	.4572	.5868	.6859	.8383	1.2193	.8269	1.448
5	.4954	.6401	.724	.8383	1.2574	.8269	1.4098
6	.4954	.6935	.8002	.8383	1.3336	.8269	1.4098
9	1.1812	1.105		1.5242		1.307	.9069
10	1.3336	1.1812		1.6385	1.3717	1.547	.9335
11	1.3717	1.0669		1.7147	1.1431	1.467	.9869
12	1.3717	.1905	.2934	1.6766	1.1812	1.4937	.9869
13	1.3336	.8764	.6401	1.6004	1.2193	1.4937	1.0136
14	1.3336	.9145	.9602	1.5242	1.105	1.4403	.9069
15	1.2955	.9526	1.1203	1.4861	1.2193	1.8671	1.0136
16	1.2193	.9526	1.2003	1.6004	1.2193	2.1719	1.0136
17			1.4861				
18			1.448				
21	.5601		.724	1.2193	.6935	1.5242	1.2193
22	.5335	.6097	.9145	1.4098	.8002	1.9433	1.2955
23	.5868	.6859	.8764	1.3336	.7735	1.9052	1.2193
24	.4191	.5868	.6478	.8764	1.2955	.8535	1.8671
Max	1.3717	1.1812	1.4861	1.7147	1.3717	2.1719	1.8671
Min	.4191	.1905	.2934	.8383	.6935	.8002	.9069
Avg	.8533	.7531	.8486	1.2574	1.1554	1.3305	1.2483