

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

AUNDHA NAGNATH S/DN.[798] BU 4798

Substation No/ Name :- 324013 / 33 KV AUNDHA NAGNATH

Feeder No / Name : 201 / 11 KV AUNDHA GAOTHAN
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	22-MAR-18	23-MAR-18	24-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.8299			
6		1.2003	1.1317		1.1831	
7						1.4335
8		1.0117				
9			1.0562			
11		.9808			.7545	
12	.8402			.823	.9808	
14		.9054				
16	.8573			.8573		
19		1.2071			.8962	
20	1.0288			1.0288		
21		1.0562			1.1317	
23	.8573			.8573		
24		.823			.823	.9054
Max	1.0288	1.2071	1.1317	1.0288	1.1831	1.4335
Min	.8402	.823	.8299	.823	.7545	.9054
Avg	.8959	1.0264	1.0059	.8916	.9616	1.1695

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

AUNDHA NAGNATH S/DN.[798] BU 4798

Substation No/ Name :- 324013 / 33 KV AUNDHA NAGNATH

Feeder No / Name : 203 / 11 KV GOLEGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.0974			
6		1.3717	1.2209			
7		1.3108				
11		2.2405			1.7147	
12				1.3717	1.6461	
14		2.1765		1.448		
16				1.4022		
17				1.3717		
21		.0754			.0943	
22	.9907					
23	1.0669					
24		1.0669				1.1431
Max	1.0669	2.2405	1.2209	1.448	1.7147	1.1431
Min	.9907	.0754	1.0974	1.3717	.0943	1.1431
Avg	1.0288	1.3736	1.1592	1.3984	1.1517	1.1431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

AUNDHA NAGNATH S/DN.[798] BU 4798

Substation No/ Name :- 324013 / 33 KV AUNDHA NAGNATH

Feeder No / Name : 204 / 11 KV SHIRAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3174			
5					.0171	
6		.4801	.4904			
7		.6001				
11					.6036	
12				.4458	.4904	
16				.5144		
17				.4801		
19	.0343					
20				.0343		
21		.0566			.0566	
23	.3429			.0171		
24		.3429			.0171	.0566
Max	.3429	.6001	.4904	.5144	.6036	.0566
Min	.0343	.0566	.3174	.0171	.0171	.0566
Avg	.1886	.3699	.4039	.2983	.2370	.0566

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

AUNDHA NAGNATH S/DN.[798] BU 4798

Substation No/ Name :- 324013 / 33 KV AUNDHA NAGNATH

Feeder No / Name : 205 / 11 KV YEHELGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5228			
6		1.2003	1.1203		1.1145	
7						1.0456
8		.9945				
9			.6722			
11		.3224			.2987	
12	.3086			.2572	.2801	
14		.2534				
16	.2572			.3429		
19		.8048			.8962	
20	.7716			.8573		
21		.7316			.7796	
23	.4287			.4801		
24		.4287			.4287	.4854
Max	.7716	1.2003	1.1203	.8573	1.1145	1.0456
Min	.2572	.2534	.5228	.2572	.2801	.4854
Avg	.4415	.6765	.7718	.4844	.6330	.7655

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

AUNDHA NAGNATH S/DN.[798] BU 4798

Substation No/ Name :- 324013 / 33 KV AUNDHA NAGNATH

Feeder No / Name : 206 / 11 KV GOLEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6036			
6		1.0288	1.0059		1.0288	
7						1.086
8		.8573				
9			.823			
11		.567			.5853	
12	.4287			.4287	.5304	
14		.4938				
16				.6859		
17	.6001					
19		1.0242			.9391	
20	.8573			.9945		
21		.8048				
23	.6001			.6001		
24		.6001			.6001	.6154
Max	.8573	1.0288	1.0059	.9945	1.0288	1.086
Min	.4287	.4938	.6036	.4287	.5304	.6154
Avg	.6216	.768	.8108	.6773	.7367	.8507

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

AUNDHA NAGNATH S/DN.[798] BU 4798

Substation No/ Name :- 324013 / 33 KV AUNDHA NAGNATH

Feeder No / Name : 207 / 11 KV WATERWORKS EXPRESS NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	22-MAR-18	23-MAR-18	24-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0189			
6		.0152			.0152	
7						.0566
8		.0152				
9			.0189			
11		.0566			.0377	
12	.0152			.0762	.0943	
14		.0754				
16	.0152			.0457		
19		.0377			.0566	
20	.0152			.0152		
21		.0189			.0566	
23	.0152			.0152		
24		.0152			.0152	.0189
Max	.0152	.0754	.0189	.0762	.0943	.0566
Min	.0152	.0152	.0189	.0152	.0152	.0189
Avg	.0152	.0335	.0189	.0381	.0459	.0378

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

AUNDHA NAGNATH S/DN.[798] BU 4798

Substation No/ Name :- 324064 / 33 KV SIDHESHWAR

Feeder No / Name : 206 / 11 KV LOHGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	28-MAR-18
HR	Load (MW)
12	.0686
13	.0686
14	.0686
15	.0686
16	.0686
17	.0686
18	.0857
19	.12
20	.12
21	.1029
22	.0857
23	.0857
Max	.12
Min	.0686
Avg	.0843

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

AUNDHA NAGNATH S/DN.[798] BU 4798

Substation No/ Name :- 324079 / 33 KV BORJA

Feeder No / Name : 203 / 11 KV BORJA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.2054	.2054	.1867	.168	.1867	.2054
2	.2801	.2054	.2054	.1867	.168	.1867	.2054
3	.2987	.2241	.2241	.2241	.1867	.2054	.2241
4	.3734	.2987	.2987	.2241	.2427	.2614	.2614
5	.5415	.3734	.3921	.3734	.3174	.3734	.3547
6	.5975	.6161	.5788	.4668	.5041	.5601	.6161
7	.5975	.6908	.5601	.6161	.6535	.4481	.6161
8	.5601	.5975		.5601	.4854	.3547	.4854
9	.3361	.4854		.3734	.3361	.2801	.3547
10	.2801			.2801	.2241	.1867	.1867
11	.2054		.2427	.1867	.1867	.1867	.1307
12	.1494	.2614	.2241	.1867	.1867	.1867	.1307
13	.168		.168	.1307	.1867	.168	.168
14	.1494	.168	.1867	.168	.1867	.168	.1494
15	.2054	.1494	.1867	.1867	.1867	.1867	.168
16	.1867	.1867	.2241	.2241	.2241	.1867	.1867
17	.2801	.2427	.2801	.2801	.2801	.2614	.2614
18	.3361	.3174	.3361	.3174	.3361	.3174	
19	.5041	.4854	.4294	.4668	.5041	.4481	.4294
20	.4294	.4294	.4294	.4108	.4294	.4108	.4668
21	.3174	.2801	.2801	.2987	.2987	.2987	.2987
22	.2427	.2241	.2241	.2241	.2614	.2241	.2614
23	.2054	.2054	.2241	.2054	.2054	.2054	.2054
24	.2987	.1677	.2054	.1867	.1867	.2054	.2054
Max	.5975	.6908	.5788	.6161	.6535	.5601	.6161
Min	.1494	.1494	.168	.1307	.168	.168	.1307
Avg	.3260	.3245	.2907	.2902	.2894	.2707	.2857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

AUNDHA NAGNATH S/DN.[798] BU 4798

Substation No/ Name :- 324088 / 33 KV JAWALA BZ

Feeder No / Name : 202 / 11 KV NALEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6						2.0576
7	2.0687		2.0008	2.0178		
8	2.1026			2.3739		
10		2.2891	2.5095	2.4587		
11	2.3739	2.2043				
12			2.2891			
13		2.2721		2.5274		
14			2.1195			
16		2.0348		2.2043		
18		2.2043		2.1434		
22					2.3339	
Max	2.3739	2.2891	2.5095	2.5274	2.3339	2.0576
Min	2.0687	2.0348	2.0008	2.0178	2.3339	2.0576
Avg	2.1817	2.2009	2.2297	2.2876	2.3339	2.0576

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

AUNDHA NAGNATH S/DN.[798] BU 4798

Substation No/ Name :- 324088 / 33 KV JAWALA BZ

Feeder No / Name : 204 / 11 KV GUNDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	23-MAR-18	24-MAR-18	25-MAR-18	27-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	2.0348	2.3061	2.2721	
10	2.2043		2.5434	
11	2.2891			
12	2.34	2.5434		
13			2.7073	
14		2.4756		
16	2.4078		2.452	
17				2.0576
18				2.5019
22				2.3663
Max	2.4078	2.5434	2.7073	2.5019
Min	2.0348	2.3061	2.2721	2.0576
Avg	2.2552	2.4417	2.4937	2.3086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324010 / 33 KV BASMAT

Feeder No / Name : 201 / 11 KV BASMAT TOWN
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			.9335				
3							.2195
5							1.0974
6			1.2803				1.3717
7	1.6032		1.5546	1.6975			1.5708
8	1.6804			1.6804			
9	1.4632	1.4937		1.5497	1.4632	1.4784	
10		1.4937			1.2803	1.4003	
11	1.4632	1.4784		1.2803	1.2936	1.3717	
12		1.386			1.1888		
13	1.3717					1.1888	
14	1.2012	1.1888			1.0974	1.2437	
15	1.2012			1.2071	1.2012	1.2936	
16	1.2012	1.086				1.2803	
17		1.2803	1.3169		1.3169	1.2803	1.2803
18		1.2803	1.4632		1.4632	1.4632	
19		1.6461	1.5708		1.6632		1.7556
20			1.531			1.448	
21		1.2936			1.46		
22							1.307
23			1.1088				
24							1.0164
Max	1.6804	1.6461	1.5708	1.6975	1.6632	1.4784	1.7556
Min	1.2012	1.086	.9335	1.2071	1.0974	1.1888	.2195
Avg	1.3982	1.3627	1.3449	1.483	1.3428	1.3448	1.2023

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324010 / 33 KV BASMAT

Feeder No / Name : 202 / 11 KV MONDHA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			1.1088				
3							1.1458
5							1.3717
6			1.5223	1.7737			1.9204
7	2.3101		2.0328	2.1472			2.2177
8	2.1253			2.1719			
9	1.9204	1.848		2.1491	1.6461	2.0119	
10		1.829			1.6461	1.829	
11	1.1888	1.6632		1.7013	1.6461	1.6289	
12		1.7556			1.4632		
13	1.829			1.4327		1.5546	
14	1.5708	1.4327			1.3717		
15	1.4784			1.4175	1.386	2.0157	
16	1.4937	1.4632				1.8604	
17		1.4632	1.7013			1.6461	1.7375
18		1.6461	1.7909		1.7528	1.7375	
19		1.848	2.0119		1.9909		2.0119
20			1.829			1.829	
21		1.587			1.6461		
22							1.6461
23			1.3717				
24				1.2803			1.307
Max	2.3101	1.848	2.0328	2.1719	1.9909	2.0157	2.2177
Min	1.1888	1.4327	1.1088	1.2803	1.3717	1.5546	1.1458
Avg	1.7396	1.6536	1.6711	1.7592	1.6166	1.7903	1.6698

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324010 / 33 KV BASMAT

Feeder No / Name : 203 / 11 KV KAUTHA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			.7316				
3							.6468
5							.7316
6			.0914	1.1203			1.0059
7	1.307		1.1888	1.307			1.2012
8	1.307			1.2136			
9	1.0974	1.1088		1.1317	.961	1.0974	
10		1.0059			.961	1.0974	
11	.924	1.0974		.8779	.924	.9955	
12		.9145			.823		
13	1.0269			.7888		.964	
14	.8402	.8954			.7316	.8954	
15	.7392			.8059	.8316	.8954	
16	.7762	.964				.964	
17		.9145	.985		.9882	.985	.985
18		1.0974	1.0517		.9536	1.0974	
19		1.0974	1.1888		1.1706		1.1888
20			1.0974			1.0974	
21		.924			.8775		
22							.961
23			.924				
24				.8402			.7468
Max	1.307	1.1088	1.1888	1.307	1.1706	1.0974	1.2012
Min	.7392	.8954	.0914	.7888	.7316	.8954	.6468
Avg	1.0022	1.0019	.9073	1.0107	.9222	1.0089	.9334

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324010 / 33 KV BASMAT

Feeder No / Name : 204 / 11 KV RURAL

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			.8859				
3							.1097
5							.1677
6			1.1603	1.1385			.2103
7	1.186		1.2803	1.3765			.3109
8	.3772			.3772			
9	.2926	.2829		.3018	.192	.6249	
10		.2263			1.326	1.2955	
11	.1638	.1886		.132	1.4918	1.2955	
12		.2075			1.4746		
13	.1646			.132		1.3765	
14	.1402	.132			1.326		
15				.1509	1.1469		
16	.116					.6249	
17		.1463	.1886		.9804	.6401	1.2498
18		.1578	.2075		.2263	.2561	
19		.2804	.3018		.2263		.2829
20			.1886			.2652	
21		.16			.1698		
22							.1698
23			.9686				
24				.9374			.1227
Max	1.186	.2829	1.2803	1.3765	1.4918	1.3765	1.2498
Min	.116	.132	.1886	.132	.1698	.2561	.1097
Avg	.3486	.1980	.6477	.5683	.8560	.7973	.3280

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324010 / 33 KV BASMAT

Feeder No / Name : 206 / 11 KV WATER WORKS
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			.2054				
3							.2195
5							.2241
6			.2012	.1698			.2254
7	.1448		.1492	.1509			.1829
8	.2054			.132			
9	.1448	.1886		.1109	.1303	.1886	
10		.2401			.2241	.1867	
11	.1448	.2279		.2353	.2401	.1265	
12		.2601			.1492		
13	.1635			.2641		.1829	
14	.16	.1509			.2294	.1494	
15	.1492			.1886	.2427	.1509	
16	.1593	.2629				.1509	
17		.1478	.2629		.208	.1389	.1698
18		.2743	.2957		.2429	.1014	
19		.2658	.156		.2481		.208
20			.1509			.1014	
21		.1307			.1478		
22							.2515
23			.1509				
24				.132			.2629
Max	.2054	.2743	.2957	.2641	.2481	.1886	.2629
Min	.1448	.1307	.1492	.1109	.1303	.1014	.1698
Avg	.1590	.2149	.1965	.1730	.2063	.1478	.2180

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324010 / 33 KV BASMAT

Feeder No / Name : 402 / 33kv incomer 1

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			1.8724				
3							1.9204
5							2.2731
6			2.3137	2.4691			2.6612
7	3.0178		3.0178	3.0178			3.0727
8	2.8607			2.9647			
9	2.6749	2.7046		2.7046	2.4451	2.7046	
10		2.6006			2.392	2.392	
11	2.1948	2.4966		2.392	2.392	2.4966	
12		2.3148			2.3594		
13	3.0178			.9717		2.2634	
14	2.4691	2.1628			2.2857	2.3148	
15	2.4143			2.1125	1.4661	2.2634	
16	2.3102	2.1879				2.3148	
17		2.3371	2.2891		2.4417	2.5766	2.4863
18		2.7435	2.672		2.672	2.8532	
19		3.1824	2.8166		2.9973		3.1024
20			2.7161			3.0407	2.8921
21		2.6863			2.4177		
22							2.3388
23			2.0508				
24				1.9033			2.1948
Max	3.0178	3.1824	3.0178	3.0178	2.9973	3.0407	3.1024
Min	2.1948	2.1628	1.8724	.9717	1.4661	2.2634	1.9204
Avg	2.6200	2.5417	2.4686	2.3170	2.3869	2.5220	2.5491

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324010 / 33 KV BASMAT

Feeder No / Name : 403 / 33kv incomer2

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			2.1559				
3							1.3169
5							1.4118
6			2.9012	2.8921			2.073
7	3.5231		3.5757	3.5757			2.3388
8	3.3436			2.3045			
9	2.0633	2.0851		2.3388	1.2894	2.8921	
10		2.009			2.7641	3.1893	
11	1.7558	1.773		1.6655	2.8172	3.0864	
12		1.8604			2.7435		
13	1.9204			1.4883		2.8841	
14	1.701	1.5043			2.5857		
15	1.7558			1.5249	2.7869	2.0576	
16	1.6301	1.4563				2.5652	
17		1.8604	1.7878		2.6355	2.7641	3.0178
18		1.8604	1.8404		1.8724	1.6827	
19		2.0416	2.1491		2.1491		2.1719
20			1.9547			2.0199	2.009
21		1.6832			1.8461		
22							1.6832
23			2.4691				
24				2.2634			1.5912
Max	3.5231	2.0851	3.5757	3.5757	2.8172	3.1893	3.0178
Min	1.6301	1.4563	1.7878	1.4883	1.2894	1.6827	1.3169
Avg	2.2116	1.8134	2.3542	2.2567	2.3490	2.5713	1.9571

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324014 / 33 KV HATTA

Feeder No / Name : 202 / 11 KV RAHATI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18
HR	Load (MW)
12	1.6289
16	1.5432
Max	1.6289
Min	1.5432
Avg	1.5861

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324014 / 33 KV HATTA

Feeder No / Name : 205 / 11 KV SATEPHAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18
HR	Load (MW)
12	.5335
Max	.5335
Min	.5335
Avg	.5335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324014 / 33 KV HATTA

Feeder No / Name : 206 / 11 KV HATTA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18
HR	Load (MW)
12	.7716
16	.7716
Max	.7716
Min	.7716
Avg	.7716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324014 / 33 KV HATTA

Feeder No / Name : 207 / 11 KV ADGAON GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-MAR-18
HR	Load (MW)
16	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324014 / 33 KV HATTA

Feeder No / Name : 208 / 11 KV COLLEGE

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	22-MAR-18
HR	Load (MW)
12	.0343
16	.0343
Max	.0343
Min	.0343
Avg	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324017 / 33 KV KURUNDA

Feeder No / Name : 202 / 11 KV DONWADA AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18
HR	Load (MW)
12	.8907
Max	.8907
Min	.8907
Avg	.8907

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324017 / 33 KV KURUNDA

Feeder No / Name : 205 / 11 KV DONWADA GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-MAR-18
HR	Load (MW)
12	.3658
Max	.3658
Min	.3658
Avg	.3658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324029 / 33 KV GIRGOAN

Feeder No / Name : 201 / 11 KV GIRGOAN GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	24-MAR-18	25-MAR-18	26-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
3			1.1344
5		1.6561	1.4834
7			1.0471
8		1.046	
9	1.306		
10			.6988
12	.8716	.5235	
16	.6973	.6981	
23		.8726	
24		.8716	.8726
Max	1.306	1.6561	1.4834
Min	.6973	.5235	.6988
Avg	.9583	.9447	1.0473

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324050 / 33 KV WAPTI

Feeder No / Name : 201 / 11 KV SHINDGI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6			.1181	.3429		.0838
7		.7011	.1943		.5609	.1067
8		.9114	.2058		.7011	.2058
9	.6241					.2058
10	.5548	.2058			.1296	.1829
11	.5721	.2		.4854	.2	.1296
12	.5201	.1715		.4161	.1943	.2
13		.1067		.4161		
Max	.6241	.9114	.2058	.4854	.7011	.2058
Min	.5201	.1067	.1181	.3429	.1296	.0838
Avg	.5678	.3828	.1727	.4151	.3572	.1592

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324050 / 33 KV WAPTI

Feeder No / Name : 202 / 11 KV PANGRA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
14	.8669	.3658	.6935	.3506	
15	.8669		.7628	.3353	.2401
16	.7712	.5144	.8669		.3429
17	.7011	.5335	.8764	.3658	
18	.6661		.7888	.4763	
19	.7011	.5525	.5258	.3658	.1829
20	.6661	.4858	.4557	.3506	.1829
21	.4207		.3506	.1715	.1715
22					.1715
Max	.8669	.5525	.8764	.4763	.3429
Min	.4207	.3658	.3506	.1715	.1715
Avg	.7075	.4904	.6651	.3451	.2153

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324050 / 33 KV WAPTI

Feeder No / Name : 203 / 11 KV PANGRA GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5258	.1029	.2763	.4908	.0991
2		.5258	.0991		.4908	.0953
3		.5258	.0953		.5258	.0914
4		.5258	.0457	.3536	.5959	.0838
5		.6661	.1143		.6661	.1067
6		.7712	.2172	.5868	.8764	.2058
7		.8764	.3201		.7712	.2229
8				.4572	.631	.2172
9						.1372
10						.0953
11		.0914				
12	.4334	.0953				
13		.0838				
14	.4161	.0762			.0991	
15	.5201				.0953	.0953
16	.5609	.0838				.0991
17	.5959	.0914			.0991	
18	.7011				.1067	
19	.333	.1105		.7011	.1829	.2229
20	.631	.1829		.631	.1943	.2229
21	.5959	.2058		.5609	.1829	.2172
22	.5959	.1943		.5609	.1143	.2058
23	.5609	.1143		.5258		
24		.5258	.1067		.5258	.1029
Max	.7011	.8764	.3201	.7011	.8764	.2229
Min	.333	.0762	.0457	.2763	.0953	.0838
Avg	.5404	.3301	.1377	.5171	.3911	.1483

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324065 / 33 KV MALWATA

Feeder No / Name : 202 / 11 KV BORALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1203	1.0164	1.1203	1.1088	1.3717	1.2955	1.2955
2	1.1458	1.0269	1.0829	1.1458	1.5089	1.3117	1.3413
3	1.4003	1.226	1.1203	1.2803	1.6004	1.4403	1.4661
4	1.587	1.5089	1.4937	1.7375	1.6194	1.5746	1.6204
5	1.8298	1.6804	1.6804	1.9022	1.6518	1.6385	1.6766
6	1.8298	1.7737	2.1285	2.1033	2.0729	1.8023	1.9062
7					2.1628	2.1872	2.5724
10	1.7438	1.6347	1.6975	1.8747			
11	1.6255	1.4817	1.7223	1.7071			
12	1.5242	1.511	1.7071	1.7833			
13	1.5242	1.39	1.6004	1.6556			
14	1.4861	1.5158	1.5804	1.6198	.8402		.7621
15	1.4861	1.4712	1.5844	1.6644	.8402	.7392	.8573
16	1.6004	1.5158	1.6461	1.776	.9335	.8871	.9335
17	1.6004	1.5455	1.7528	1.8484	1.1317	1.0349	1.0974
18	1.2136	.9877	.961	1.1273	1.1203	1.0164	1.3717
19	1.587	1.5684	1.5893	1.587	1.587	1.6632	1.6804
20	1.587	1.5708	1.5708	1.531	1.6804	1.6804	1.587
21	1.307	1.46	1.4563	1.386	1.4784	1.4327	1.4632
22	1.0269	1.1576	1.2012	1.3413	1.406	1.4232	1.4251
23	1.0269	.7324	1.1088	1.2643	1.448	1.3413	1.4746
24	1.0642	1.0269	1.1203	1.0719	1.2651	1.3717	1.2955
Max	1.8298	1.7737	2.1285	2.1033	2.1628	2.1872	2.5724
Min	1.0269	.7324	.961	1.0719	.8402	.7392	.7621
Avg	1.4436	1.3715	1.4726	1.5484	1.4288	1.4024	1.4348

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324065 / 33 KV MALWATA

Feeder No / Name : 203 / 11 KV PALASGOAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5623	1.406	1.3592	1.448	1.0974	1.0164	1.0059
2	1.6404	1.406	1.3592	1.4937	1.2936	1.0269	1.0059
3	1.6804	1.5203	1.4403	1.6204	1.4784	1.1203	1.1765
4	1.8404	1.8023	1.7604	1.6975	1.7741	1.386	1.267
5	2.2542	2.2634	1.9433	1.9528	1.848	1.6461	1.386
6	2.5857	2.4863	2.2119	2.451		1.8671	1.6804
7	2.9835	2.8673	2.4966	2.7587			
10					2.4291	2.0805	1.8185
11					2.1052	2.1348	2.1605
12					2.1348	2.0557	2.0805
13					2.0309	1.6309	1.9204
14	.7164	.6805				1.7223	1.6004
15	.823	.7783	.6135		2.0557	1.7528	1.6766
16	.905	.9328	.6335		1.7604	1.8595	1.8747
17	.9955	1.2254	.905	1.1203	1.8976	1.8982	1.9528
18	1.1888	1.1283	.9745		1.3432	1.1088	1.3717
19	1.5546	1.6827	1.4083	1.5203	1.4632	1.1088	1.4022
20	1.5546	1.6108	1.4118	1.4864	1.4632	1.5708	1.3717
21	1.448	1.4148	1.2696	1.2403	1.4632	1.5708	1.2803
22	1.4403	1.4864	1.6975	1.1946	1.1888	1.2012	1.1888
23	1.5203	1.4091	1.5432	1.086	1.086	1.0719	1.1203
24	1.5623	1.5203	1.3435	1.448	1.0498	1.0059	1.0425
Max	2.9835	2.8673	2.4966	2.7587	2.4291	2.1348	2.1605
Min	.7164	.6805	.6135	1.086	1.0498	1.0059	1.0059
Avg	1.5698	1.5345	1.4336	1.6084	1.6296	1.5160	1.4945

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324065 / 33 KV MALWATA

Feeder No / Name : 206 / 11 KV MIDC II

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER MIDC EQUIVALENT
HAVING WEEKLY STAGGERING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1402	.0846	.1509	.2103	.1006	.125	.1006
2	.1402	.08	.1509	.1715	.0995	.0914	.124
3	.1187	.08	.1509	.1715	.1017	.0892	.1254
4	.1578	.0686	.1494	.1578	.1029	.0846	.128
5	.1578	.0705	.2241	.1578	.1067	.1143	.1463
6	.2149	.0846	.2241	.1612	.1867	.1143	.1267
7	.0857	.1147	.1478	.1886	.2263	.1463	.1463
8	.116	.1075	.1494	.1867	.168	.1463	.1463
9	.0762	.1829	.2614	.1494	.2987	.1867	.112
10	.0857	.3018	.2614	.3395	.3734	.3018	.2614
11	.0895	.2641	.3395	.2987	.3772	.2829	.3772
12	.1075	.3018	.3395	.3772	.3395	.3395	.3772
13	.1029	.3018	.2829	.3584	.1867	.2641	.2829
14	.061	.3206	.2987	.2801	.2241	.2829	.2829
15	.061	.3395	.4854	.2829	.2263	.2829	.2801
16	.0983	.2987	.3772	.3361	.2263	.2641	.2801
17	.0671	.3734	.415	.2987	.2801	.1886	.2743
18	.0914	.2641	.3361	.2054	.1886	.1307	.2801
19	.08	.1886	.2614	.1886	.1867	.168	.2801
20	.1029	.1886	.2926	.1494	.2263	.1134	.2829
21	.1075	.1698	.1543	.1698	.2263	.1187	.2829
22	.0914	.1867	.1543	.132	.2103	.124	.1829
23	.0914	.112	.1543	.128	.1715	.0972	.1829
24	.1402	.0892	.1132	.2454	.1017	.1219	.1052
Max	.2149	.3734	.4854	.3772	.3772	.3395	.3772
Min	.061	.0686	.1132	.128	.0995	.0846	.1006
Avg	.1077	.1906	.2448	.2227	.2057	.1741	.2154

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324066 / 33 KV JNV

Feeder No / Name : 201 / 11 KV JNV

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8619	.9739	.8741	1.1443	.5658	.4024	.415
2	.8619	1.0288	.8741	1.0717	.5847	.4024	.415
3	.8833	1.0987	.8688	1.0292	.6413	.4435	.4527
4		1.2266	1.0433	.9739	.7167	.5544	.5658
5	.9587	1.4335	1.2971	.9328	.811	.8029	.9054
6	1.2186	1.6577	1.6217	1.0292	.9054	1.1576	1.1317
7	1.3112	1.8724	1.6871	.9736	.9242	1.0829	.9808
8	.2172	.8299	.7842	.7602	.7545	.9709	.8488
9	.1886	.6413	.679	.7545	.6468	.9054	.5658
10	.1509	.5175	.5975	.4527		1.39	
11	.1509	.3696	.5415	.4527		1.2971	.8177
12	.1509	.3511		.4338	1.3535	1.2346	.7034
13	.1509	.3696		.415	1.3032	1.1904	.7981
14	.1509	.3696	.3361	.4338	1.3306	1.1336	.9328
15	.1698	.3696		.3961	1.262	1.0669	.9659
16		.3881	.3734	.3961	1.2071	1.0957	.9217
17	.679	.4668	.3511	.3734	1.3169	1.1069	.9633
18	.5281	.5853	.439	.5601	.6468	.6602	.8215
19	.7167		.3326	.7282	.6653	.7733	.8316
20	.679	.7023	.3326	.6979	.7023	.7545	.7762
21	.6413	.5601	.3547	.6413	.6722	.7167	.7392
22	.9063	.9069	.6838	.6036	.4854	.6036	.6908
23	.9739	.8916	1.2037	.5658	.4435	.5281	.6468
24	1.0004	.9469	.8779	1.174	.547	.439	.4715
Max	1.3112	1.8724	1.6871	1.174	1.3535	1.39	1.1317
Min	.1509	.3511	.3326	.3734	.4435	.4024	.415
Avg	.6159	.8069	.7692	.7081	.8403	.8630	.7548

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324066 / 33 KV JNV

Feeder No / Name : 204 / 11 KV AKOLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.679	.547	.4805	.7023	.6859	.6584	.8002
2	.6602	.5658	.439	.6838	.7788	.6516	.7682
3	.6348	.6036	.4938	.6722	.8882	.6173	.7116
4	.6283	.6413	.5853	.6722	.9859	.7331	.9172
5	.7023	.7167	.8316	.7095	1.1003	.8459	1.0155
6	.8048	.7922	.9709	.9055	1.2193	1.0151	1.3413
7	1.0608	.8488	.7842	1.2254	1.2963	1.3817	1.46
8	1.1273	.4338	.8215	1.0242	.8488	.8962	.8488
9	1.1317	.7167	.9709	.9808	.7392	.8299	.6979
10	.9334	1.1523	.9065	1.2193		.5658	
11	1.0269	1.1431	1.0254	1.1003		.4715	.5281
12	.9069	.9877	.9023	.9736	.3696	.4527	.7356
13	.9069	.8935	.8779	.8901	.3292	.415	.8299
14	.9335	.8505	1.0151	.9054	.3658	.415	.9054
15	.8939	.8067	1.0402	1.2637	.4435	.3772	.8676
16	1.0151	.8505	.9305	.9877	.5914	.4715	.7842
17	1.057	1.0014	.7956	1.07	.5914	.5093	.9055
18	.7733	1.0829	.8326	.6535	.7842	.7922	.9511
19	.8676		.8215	.7468	.8962	.9054	.7947
20	.8488	.8215	.6908	.6602	.7842	.8488	.7468
21	.6224	.6348	.7095	.5658	.5914	.7545	.6908
22	.547	.5228	.6653	.6001	.7754	.8697	.6344
23	.4904	.4805	.7133	.6268	.7331	.9014	.4294
24	.7356	.5658	.462	.7577	.6401	.7407	.8697
Max	1.1317	1.1523	1.0402	1.2637	1.2963	1.3817	1.46
Min	.4904	.4338	.439	.5658	.3292	.3772	.4294
Avg	.8328	.7678	.7819	.8582	.7472	.7133	.8363

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324073 / 33 KV KHANDEGOAN

Feeder No / Name : 201 / 11 KV KHANDEGOAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381				.423
2	.381				.423
3	.5716				.5716
4	.5716				.724
5	.7621				.8916
6	.7621				1.0402
7	1.1431				1.1584
8	.9526		.5716		.5716
9				.381	.5716
10				.381	.381
11				.1905	.381
12				.381	
13				.381	
14				.381	
15		.1905		.381	.1905
16		.8573		.381	.381
17	.8116				
18	1.1279	.6573			
20					.5716
24	.381				.4287
Max	1.1431	.8573	.5716	.381	1.1584
Min	.381	.1905	.5716	.1905	.1905
Avg	.7132	.5684	.5716	.3572	.5806

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324073 / 33 KV KHANDEGOAN

Feeder No / Name : 202 / 11 KV SUTGIRNI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)
1		.381
2		.381
3		.381
4		.5716
5		.5716
6		.5716
7		.5716
9		.8573
10		.724
11		.8802
15		.8345
16	.1905	.1905
20		.381
24		.381
Max	.1905	.8802
Min	.1905	.1905
Avg	.1905	.5484

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324073 / 33 KV KHANDEGOAN

Feeder No / Name : 206 / 11 KV RANJONA

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)
16	.1524	.1257
17	.1486	
18	.1486	
19	.1448	
20	.1429	.12
21	.1429	
22	.1486	
23	.1486	
Max	.1524	.1257
Min	.1429	.12
Avg	.1472	.1229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324078 / 33 kV BORI SAWANT

Feeder No / Name : 201 / 11 KV KARANJALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)
8		.6516
18	.1524	
24		1.8351
Max	.1524	1.8351
Min	.1524	.6516
Avg	.1524	1.2434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324078 / 33 kV BORI SAWANT

Feeder No / Name : 202 / 11 kV DAREPHAL AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	27-MAR-18
HR	Load (MW)
17	.8718
Max	.8718
Min	.8718
Avg	.8718

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324078 / 33 kV BORI SAWANT

Feeder No / Name : 203 / BORI(S) GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)
17	.2353	
18	.2126	
24		.1595
Max	.2353	.1595
Min	.2126	.1595
Avg	.2240	.1595

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324090 / 33 kV BORALA

Feeder No / Name : 201 / 11 KV DHAMANGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18
HR	Load (MW)
10	1.9004
11	.9313
12	1.8625
13	2.0595
14	1.7551
15	1.6832
16	1.6289
Max	2.0595
Min	.9313
Avg	1.6887

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324090 / 33 kV BORALA

Feeder No / Name : 202 / 11 KV RURAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18
HR	Load (MW)	Load (MW)
1	.7716	.8596
2	.8402	.8775
3	.9431	.9671
4	1.046	1.0745
5	1.1488	1.182
6	1.2517	1.2536
7	1.3375	1.3432
8	1.286	1.4022
9	.9955	
10	.362	
11	.2715	
12	.2896	
13	.2328	
14	.3045	
15	.3077	
16	.3224	
17	.3696	
18	.4477	
19	.7522	
20	.9134	
21	.8954	
22	.985	
23	.9492	
24	.7202	.9134
Max	1.3375	1.4022
Min	.2328	.8596
Avg	.7393	1.0970

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324090 / 33 kV BORALA

Feeder No / Name : 203 / 11kv bhendegaon

SHEDDABLE HV(AGRICULTURE)

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1267	.1543	.1543	.0171	.0179	.0171
2	.1715	.197	.1886	.1715	.0171	.0179	.0171
3	.2058	.2328	.2058	.1524	.0171	.0179	.0171
4	.2401	.2865	.2572	.1677	.0171	.0181	.0171
5	.2743	.3045	.2572	.1829	.0171	.0181	.0171
6	.2915	.3403	.2743	.1829	.0171	.0181	.0171
7	.3258	.3439	.2743	.1981	.0171	.0181	.0171
8					.0171	.0171	.0171
9					.0171	.0171	.0171
10					.2915	.2591	.2743
11					.2743	.2743	.2743
12					.2572	.2591	.2572
13					.2572	.2439	.2401
14	.0181	.0171	.0171	.0171	.1715	.2286	.2229
15	.0181	.0171	.0171		.1715	.2134	.2229
16	.0181	.0171	.0171		.1715	.2286	.2743
17	.0179	.0171	.0171	.0171	.2401	.2439	.2743
18	.0181	.0171	.0171	.0171			
19	.0179	.0171	.0171	.0171			
20	.0183	.0171	.0171	.0171			
21	.0179	.0171	.0171	.0171			
22	.0895	.12	.12	.0171			
23	.1075	.1372	.1372	.0171			
24	.1543	.1097	.1372	.1543	.0171	.0179	.0171
Max	.3258	.3439	.2743	.1981	.2915	.2743	.2743
Min	.0179	.0171	.0171	.0171	.0171	.0171	.0171
Avg	.1199	.1297	.1191	.0938	.1114	.1183	.1229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324093 / 33/11 KV KAUTHA ROAD BASMATH

Feeder No / Name : 201 / M. FULE UDYOG SANTHA NON SHEDDABLE EXPRESS HV FEEDERS
 EXPRESS Feeder KV- 11 / (CONTINUOUS PROCESS)(NO STAGGERING)
 OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	26-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.0017			
3		.0017			
4		.0017			
5		.0017			
6		.0017			.0018
7		.0017			
8		.0017			.0018
9			.0018	.0018	
10			.0018	.0018	
11			.0018	.0018	
12			.0018	1.6002	
13			.0018	.0018	
14			.0018	.0018	
15			.0018	.0018	
16			.0018	.0018	
17	.0017			.0018	
Max	.0017	.0017	.0018	1.6002	.0018
Min	.0017	.0017	.0018	.0018	.0018
Avg	.0017	.0017	.0018	.1794	.0018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324093 / 33/11 KV KAUTHA ROAD BASMATH

Feeder No / Name : 202 / 11 KV KUMBHARWADA SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.5641	.5601	.5658	.6348	.6348	
2	.5658	.5265	.5601	.5658	.6161	.6348	
3	.5847	.5265	.5788	.5914	.5601	.6348	
4	.7545	.5641	.6348	.6281		.6722	
5	.9054	.7522	.7468	.8676		.7468	
6	1.0562	1.0907	.9709	1.0185		.9335	1.0332
7	1.1883	1.2223	1.0642	1.2071		1.0719	
8	1.2071	1.053	1.1576	1.2449		1.1576	
9	1.0185	1.1659	.9966	1.1506	.9966		
10	.6908	1.0642	.9402	.8775	.8086	.9619	.7468
11	.7468	.9335	.7522	.7392	.6582		.7468
12		.7842	.6393	.6722	.677	.6602	.7095
13	.6722	.7468	.5641	.5601	.5265	.6224	.543
14	.5975	.6161	.5641	.5601	.5641		.5601
15	.6348	.5228	.6393	.6161	.5641	.6413	.6161
16		.6348	.6017	.6722	.7522	.7356	.7095
17	.8462		.6413		.7522		.811
18	.959	.8962	1.0562	.9522	1.0082		.9431
19	1.1283	1.0269	1.0562	.9896	1.0082		
20	.865	.8962	.9242	.8589	.8402		
21	.7146	.6908	.7922	.7468	.7842		
22	.6017	.5975	.7545	.7282	.7468		.7545
23	.6017	.5544	.5847	.6908	.6722		.6471
24		.5641	.5601	.5658	.7095	.5975	
Max	1.2071	1.2223	1.1576	1.2449	1.0082	1.1576	1.0332
Min	.5658	.5228	.5601	.5601	.5265	.5975	.543
Avg	.8050	.7823	.7642	.7856	.7305	.7647	.7351

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324093 / 33/11 KV KAUTHA ROAD BASMATH

Feeder No / Name : 203 / 11 KVKALNKAI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6632	1.4876	1.4415	1.4415	1.4784	1.4327	
2	1.6632	1.4132	1.4784	1.46	1.4045	1.4784	
3	1.7002	1.4146	1.5154	1.46	1.386	1.5154	
4	1.848	1.4891	1.5893	1.5708		1.6263	
5	2.3101	2.0475	1.7002	1.848		1.6817	
6	2.5873	2.6405	1.97	2.1807		2.0328	2.6776
7	2.846	2.6059	2.4394	2.7905		2.7166	
8	3.0123	2.9782		2.6242			
9	2.4025	2.2337	2.3453	2.5503	2.6432	2.7166	
10	1.848	2.5133	1.6752	2.1253	4.095	2.0698	2.2177
11	1.6817	2.347		1.7187	1.8986	2.0698	2.2361
12		1.885	1.6752	1.5893	1.5263	1.848	2.0883
13	1.5893	1.922	1.8614	1.4415	1.5263	1.6632	1.7002
14	1.5154	1.4415	1.638	1.4415	1.638		1.7372
15	1.4784	1.6263	1.638	1.6263	1.5636	1.6632	1.5893
16		1.7741	1.8614	1.4784	1.5636	1.7556	1.7187
17	1.9339		2.0165		1.8614		2.0328
18	1.9339	1.9774	2.2361	2.2731	2.1437		2.2731
19	2.6033	2.0883	2.6242	2.5133	2.347		2.5133
20	2.0826	1.885	2.1807	2.0698	2.0328		
21	1.8967	1.6632	1.885	1.7926	1.7741		
22	1.6735	1.6263	1.6632	1.7002			1.8111
23	1.5248	1.5524	1.4784	1.5893	1.5893		1.6263
24	1.6448	1.4876	1.4415	1.4415	1.5154	1.4784	
Max	3.0123	2.9782	2.6242	2.7905	4.095	2.7166	2.6776
Min	1.4784	1.4132	1.4415	1.4415	1.386	1.4327	1.5893
Avg	1.9745	1.9174	1.8343	1.8577	1.8882	1.8499	2.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324093 / 33/11 KV KAUTHA ROAD BASMATH

Feeder No / Name : 204 / 11 KV MOHGAON FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / INCOMING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8993	.8871	.9145	1.0155	.0753	.1067	
2	.8993	.8871	.945	.9907	.0903	.1067	
3	.884	.8871	.945	1.0212	.1054	.1067	
4	.945	.961	.9755	1.0669		.1372	
5	1.0517	1.1088	1.0059	1.1279		.1677	
6	1.2955	1.2339	1.0364	1.2041		.1981	.298
7	1.5242	1.4784	1.5699	1.387		.2591	
8	.2134		.2439	.2134			
9	.1829	.1763	.1469	.1524	.1332	.2134	
10	.0762		.1028	.0762	1.3584	1.4022	1.46
11	.0457		.0881	.0762	1.4784	1.3413	1.4299
12			.0588	.061	1.3602	1.2955	1.3546
13	.0457		.0734	.0457	1.2419	1.2346	1.3847
14	.0457	.0137	.0734	.0457	1.0053		1.3546
15	.0457		.0588	.061	1.0053	.9755	1.1589
16			.0588	.061	.4737	1.1431	1.2944
17	.0888				.2218		1.2955
18	.148	.0762		.1204	.1067		.1067
19	.1776	.1829	.1981	.1957	.1829		.1981
20	.1776	.1981	.1524	.1355	.1677		
21	.1187		.1219	.0903	.1219		
22	.8871		1.386	.0753	.1219		.1067
23	.8871		1.0669	.0452	.1067		.1067
24	.9145	.8871	.9145	.9907	.0452	.1067	
Max	1.5242	1.4784	1.5699	1.387	1.4784	1.4022	1.46
Min	.0457	.0137	.0588	.0452	.0452	.1067	.1067
Avg	.5252	.6906	.5517	.4460	.4949	.5863	.8884

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324103 / 33 KV GUNDA

Feeder No / Name : 201 / 11 KV GUNDA AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
16	.3944		.4115
17	.5144		.4973
18	.3944		.583
19	.583		.5658
20	.4973		.5658
21	.4973		.5316
22	.4801		.4801
23	.5144		.463
24		.5144	
Max	.583	.5144	.583
Min	.3944	.5144	.4115
Avg	.4844	.5144	.5123

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324103 / 33 KV GUNDA

Feeder No / Name : 202 / 11 KV KARANGI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	27-MAR-18
HR	Load (MW)
1	.8745
2	.9259
3	.9088
4	.9774
5	1.0117
6	1.0288
7	1.046
8	1.166
24	.8916
Max	1.166
Min	.8745
Avg	.9812

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324035 / 33KV NARSI(N)

Feeder No / Name : 201 / 11KV PAHENI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.9145	.5144	.6097	.1524	.1524	.1524
2	.9145	.9145	.5144	.6097	.1524	.1524	.1524
3	.9145	.9145	.5144	.6097	.1524	.1524	.1524
4	.9145	1.0669	.6859	.6097	.1524	.1524	.1524
5	1.0669	1.3717	1.2003	.7621	.1524	.1524	.1524
6	1.6766	1.6766	1.7147	.9145	.3048	.1524	.3048
7	1.829	1.9814	2.0576	.9145	.3048	.3048	.3048
8	.7621	.7621	.7621				
9	.6097	.5144	.6097				
10	.6097	.8573	.3048	.3048	.7621	.9145	.8573
11	.7621	.8573	.3048	.3048	.9145	.9145	.8573
12	.7621	.8573	.3048	.4572	.9145	.9145	.8573
13	.6097	.8573		.4572	.9145		.8573
14	.6097	.8573	.7621	.4572	.6859	.6097	.6859
15	.7621	.5144	.3048	.4572	.8573	.7621	.3429
16	.7621	.5144	.4572	.4572	.9145	.9145	.6859
17	.7621	.5144	.4572	.4572	1.0288	1.0669	1.0288
18	.3048						
19	.7621	.5144					
20	.6097	.5144					
21	.4572						
22	.9145	.5144	.6097		.1524		.3429
23	.9145	.5144	.6097		.1524		.3429
24	.9145	.5144		.6097	.1524	.1524	.3429
Max	1.829	1.9814	2.0576	.9145	1.0288	1.0669	1.0288
Min	.3048	.5144	.3048	.3048	.1524	.1524	.1524
Avg	.8383	.8417	.7049	.5620	.4901	.4979	.4763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324035 / 33KV NARSI(N)

Feeder No / Name : 202 / 11KV GHOTA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.4572	.6097	.6859
2					.4572	.6097	.6097
3					.4572	.6097	.6097
4					.4572	.7621	.6097
5					.4572	.9145	.7621
6					.6097	.9145	1.0669
7						.9145	1.2193
8					.6097		
10	.9145	1.0288	.7621	.4572			
11	.9145	1.0288	.9145	.7621			
12	.9145	1.0288	.9145	.9145			
13		1.0288	.9145	.7621			.5144
14	.7621	.8573	.9145				
15	.6097	.8573	.7621				
16	.6097	.8573	.7621				
17	.4572	1.0288	.7621				
20				.4572		.6097	
21		.3429	.3048	.4572	.6097	.6859	.5144
22		.3429	.3048	.4572	.6097	.6859	.5144
23		.3429	.3048	.4572	.6097	.6859	.5144
24		.3429			.4572	.6097	.6097
Max	.9145	1.0288	.9145	.9145	.6097	.9145	1.2193
Min	.4572	.3429	.3048	.4572	.4572	.6097	.5144
Avg	.7403	.7573	.6928	.5906	.5265	.7177	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324035 / 33KV NARSI(N)

Feeder No / Name : 203 / 11 KV PAHENI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.4973	.5144	.4973	.463		.5144
2	.463	.4973	.5144	.4973	.4458	.4458	.5144
3	.5144	.5144	.6859	.4801	.4973	.4801	.5487
4	.7888	.5487	.8573	.583	.823	.6001	.6687
5	1.0974	.9945	1.0288	.9259	1.2174	1.3375	1.3032
6	1.5947	1.2174	1.6804	1.3032	1.7833	1.6975	1.7147
7	1.4918	1.4746	1.5432	1.4575			1.406
8	1.4918	1.2517	1.0288		1.5947	.9945	1.046
9	1.2003	.9945	1.0288	1.0974	.9431	.6173	.823
10	.4458	.6859	.5658	.7202	.583	.4115	.463
11	.4458	.5144	.3944	.4287	.4115		.4115
12	.3944	.5144	.3772	.4115	.3772		.4115
13	.3944		.3429	.4115	.3601		.3772
14	.3944	.4287	.3944	.3944	.2915	.2915	.3429
15	.4115	.4287	.4801	.3772	.3601	.2743	.3944
16	.4801	.5144	.463	.4801	.4115	.2915	.5144
17	.6173	.6859	.5658	.5316	.583	.3258	.6859
18	.7202	.6859	1.0288	.583	.6516	.7202	.7373
19	1.0631	.6859	1.2003	.7545	.8573	1.0117	1.0288
20	.8916	.6859	.9431	.8573	.8573	.9088	.8916
21	.703	.6859	.703	.6859	.6859	.7202	.6859
22	.6001		.6516	.6173	.583	.6516	.5144
23	.4973	.5144	.5144	.4973	.4801	.5316	.5144
24		.5144		.5144	.463	.463	.5144
Max	1.5947	1.4746	1.6804	1.4575	1.7833	1.6975	1.7147
Min	.3944	.4287	.3429	.3772	.2915	.2743	.3429
Avg	.7470	.7061	.7612	.6568	.6836	.6723	.7094

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324035 / 33KV NARSI(N)

Feeder No / Name : 204 / 11 kV GHOTA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4115	.4458	.4458	.4458
2		.4115	.4115	.4287	.4458
3		.4115	.4287	.4458	.4801
4		.4458	.5316	.583	.6173
5		.6516	.7716	.8745	.8745
6		.8059	1.0288	1.0631	1.0974
7		.9945	1.1488	1.0631	1.1831
8		.9259	.8916	.823	.8916
9		.7545	.6859	.6687	.7202
10		.5487	.5487	.5144	.6516
11		.4458	.4115	.5144	.4801
12		.463	.4115	.4115	.4458
13		.463	.4115	.4287	.3429
14	.3429	.4458		.3772	.3429
15	.3429	.4801	.4458	.3944	.4801
16	.4115	.4801	.4801	.463	.4115
17	.4801	.6001	.5144	.5144	.4458
18	.6859	.583	.5487	.583	.583
19	.8573	.8573	.7202	.9431	.7202
20	.7888	.703	.6401		.6859
21	.6516	.6344	.5487	.6344	.6173
22	.5487	.5487	.4877	.5487	.5144
23	.4458	.4801	.4268	.4801	.4458
24		.4458	.4801	.4458	.4458
Max	.8573	.9945	1.1488	1.0631	1.1831
Min	.3429	.4115	.4115	.3772	.3429
Avg	.5556	.5830	.5835	.5934	.5987

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324035 / 33KV NARSI(N)

Feeder No / Name : 205 / 11 KV SARKALI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	22-MAR-18
HR	Load (MW)
2	.3963
5	.4115
7	.7926
Max	.7926
Min	.3963
Avg	.5335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324035 / 33KV NARSI(N)

Feeder No / Name : 206 / SANT NAMDEO FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1981	.2229	.2229	.2229	.2401	.2229	.2058
2	.1829	.2229	.2229	.2229	.2229	.2229	.2058
3	.2134	.2229	.2229	.2229	.2229	.2401	.2229
4	.2572	.2401	.2572	.2401	.2572	.2743	.2743
5	.2915	.3258	.3086	.3086	.2743	.3601	.3429
6	.4115	.4115	.4287	.3772	.3772	.4115	.4287
7	.4801	.463	.4801	.4801	.4973	.4801	.4458
8	.4801	.463	.4287	.4458	.463	.4801	.4115
9	.4115	.4287	.4115	.4115	.3944	.3772	.3772
10	.3258	.3429	.3429		.3086	.3258	.3258
11	.2572	.3429		.3601	.2572	.2915	.2743
12	.2229	.2743	.2743	.2401	.2401	.2401	.2572
13	.2229	.2401	.2229	.2401	.2401	.2401	.2229
14	.2572	.2572	.2401	.2401	.2401	.2401	.2229
15		.2572	.2401	.2743	.2401	.2572	.2229
16	.2915		.2743	.3086	.2572	.2572	.2572
17		.2915	.2915	.3258	.2915	.3086	.3086
18	.2915	.3429	.3086	.3601	.3601	.3258	.3258
19	.5144	.3944	.3429	.3944	.4287	.4115	.3944
20	.4115	.4115	.3429	.3772	.3601	.3429	.3429
21	.3086	.2915	.2915	.2743	.2915	.3258	.2915
22	.2743	.2572	.2572	.2572	.2572	.2743	.2572
23	.2401	.2572	.2401	.2401	.2229	.2229	.2401
24	.2229	.2401		.2401	.2401	.2229	.2401
Max	.5144	.463	.4801	.4801	.4973	.4801	.4458
Min	.1829	.2229	.2229	.2229	.2229	.2229	.2058
Avg	.3076	.3131	.3024	.3072	.2994	.3065	.2958

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324067 / 33 KV PEDGAON

Feeder No / Name : 203 / 11 KV LIMBI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0183	.0185	.0185	.0185	.0181	.0185	.0185
2	.0185	.0185	.0187	.0183	.0185	.0183	.0185
3	.0187	.0185	.0183	.0185	.0183	.0185	.0181
4		.0183	.0185	.0181	.0185	.0183	.0185
5		.0185	.0185	.0185	.0183	.0185	.0187
6		.0187	.0183	.0183	.0181	.0183	.0183
7		.0185	.0183	.0185	.0185	.0181	.0183
8		.0183	.0183	.0183	.0181	.0185	.0187
9		.0185	.0185	.0181	.0183	.0181	.0185
10	.0185	.0187	.0183	.0185	.0185	.0185	
11	.0183	.0183	.0185	.0185	.0187	.0183	.0181
12	.0183	.0187	.0187	.0183	.0185	.0185	.0187
13	.0185	.0183	.0183	.0185	.0183	.0185	.0185
14	.0187	.0187	.0185	.0187	.0185	.0183	.0183
15	.0185	.0185	.0187	.0181	.0187	.0181	.0185
16	.0183	.0183	.0183		.0183	.0018	.0183
17	.0185	.0185	.0187	.0185	.0181	.0185	.0183
18	.0185	.0187	.0185	.0183	.0185	.0181	.0185
19	.0187	.0183	.0185	.0185	.0181	.0183	.0183
20	.0183	.0185	.0187	.0183	.0183	.0018	.0181
21	.0185	.0187	.0183	.0187	.0185	.0183	.0185
22	.0185	.0183	.0185	.0185	.0183	.0185	.0181
23	.0187	.0183	.0187	.0185	.0181	.0181	.0185
24		.0183	1.7741	.0185	.0183	.0183	.0183
Max	.0187	.0187	1.7741	.0187	.0187	.0185	.0187
Min	.0183	.0183	.0183	.0181	.0181	.0018	.0181
Avg	.0185	.0185	.0916	.0184	.0184	.0170	.0184

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324067 / 33 KV PEDGAON

Feeder No / Name : 206 / 11 KV YELI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.3801	.3658	.3841	.3841			
3	.4024	.439	.567	.3658			
4		.5487	.7499	.5611			
5		.8048	.9145	.5487			
6		1.0974	1.1946	.7499			
7		1.2437	1.2308	1.134			
8		1.2803	1.1946				
9		.9328	1.134			1.134	
10					1.1584		.7682
11				1.0974	1.2308	1.0974	.823
12					1.2071	1.2437	.8688
13						1.1946	.9145
14						1.0974	.9511
15					1.0974	1.1222	1.1157
16					1.1222	1.1157	1.0608
17					1.086	1.134	.9877
24				.9145			
Max	.4024	1.2803	1.2308	1.134	1.2308	1.2437	1.1157
Min	.3801	.3658	.3841	.3658	1.086	1.0974	.7682
Avg	.3913	.8391	.9212	.7194	1.1503	1.1424	.9362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324081 / 33 KV YASHWANT NAGAR

HINGOLI

Feeder No / Name : 201 / 11 kV TOWN-2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-MAR-18
HR	Load (MW)
15	1.3446
Max	1.3446
Min	1.3446
Avg	1.3446

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324081 / 33 KV YASHWANT NAGAR

HINGOLI

Feeder No / Name : 202 / 11 kV TOWN-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-MAR-18
HR	Load (MW)
15	1.6547
Max	1.6547
Min	1.6547
Avg	1.6547

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324081 / 33 KV YASHWANT NAGAR

HINGOLI

Feeder No / Name : 203 / 11 kV GOREGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	23-MAR-18
HR	Load (MW)
15	.9932
Max	.9932
Min	.9932
Avg	.9932

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324081 / 33 KV YASHWANT NAGAR

HINGOLI

Feeder No / Name : 205 / 11 kV TOWN-3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-MAR-18
HR	Load (MW)
15	2.3124
Max	2.3124
Min	2.3124
Avg	2.3124

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324084 / 33 kV LOHGAON

Feeder No / Name : 201 / 11 kV LOHGAON GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	24-MAR-18	25-MAR-18	26-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
8	.4458	.6344	.6516
16	.4458	.3772	.4287
22		.6344	
24	.5487		.463
Max	.5487	.6344	.6516
Min	.4458	.3772	.4287
Avg	.4801	.5487	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324084 / 33 kV LOHGAON

Feeder No / Name : 202 / 11 KV BHOSHI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	24-MAR-18	25-MAR-18	26-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
7	.8745		
17			.7888
22		.8745	
Max	.8745	.8745	.7888
Min	.8745	.8745	.7888
Avg	.8745	.8745	.7888

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324084 / 33 kV LOHGAON

Feeder No / Name : 203 / 11 kV LOHGAON AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	25-MAR-18	26-MAR-18
HR	Load (MW)	Load (MW)
7		.6859
8	.6859	
17	.6173	
Max	.6859	.6859
Min	.6173	.6859
Avg	.6516	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324015 / 33/11 KV WARANGA

Feeder No / Name : 201 / 11 KV WARANGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621						
2	.7621				.7621		
3	.7621						
4	.7621						
5	.8573				.8573		
6	1.1431				1.2384	1.3336	
7	1.1431	1.0479	.8573		1.5242	1.6194	1.7147
8	1.1431	1.0479	.9526	.9526	.8573	.9526	.8573
9	.9526	.8573	.7621		.6668	.7621	.7621
10	1.1431	1.5242	1.1431	1.4289	.5716	.5716	.5716
11		1.4289		1.2384	.4763		.4763
12				1.3336	.4763		
13				1.1431			.4763
14		1.2384		1.1431	.4763	.5716	.5716
15		1.1431		1.0479	.4763	.5716	.5716
16	1.4289				.5716	.5716	.5716
17		1.2384		1.2384	.5716	.5716	.5716
18	1.2384	1.1431		.6668	.7621	.7621	.6668
19	1.1431	.9526		.8573	.8573	.9526	.8573
20		.8573		.8573	.8573	.9526	.7621
21	1.0479	.8573		.8573	.8573	.8573	
22	.8573	.7621		.7621	.8573	.9526	.8573
23				.8573			
24					.8573	.7621	
Max	1.4289	1.5242	1.1431	1.4289	1.5242	1.6194	1.7147
Min	.7621	.7621	.7621	.6668	.4763	.5716	.4763
Avg	1.0098	1.0845	.9288	1.0274	.7671	.851	.7349

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324015 / 33/11 KV WARANGA

Feeder No / Name : 202 / 11 KV DABHADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191						
2	.0191				.0381		
3	.0191						
4	.0191						
5	.0191				.0381		
6	.0191				.0381	.0324	
7	.0191	.0572	.0381		.0381	.0191	.0191
8	.0191	.0191	.0191	.0381	.0191	.0191	.0191
9	.0191	.0191	.0191		.0191	.0343	.0191
10	.0381	.0381	.0381	.0381	.0381	.0429	.0572
11	.0572	.0572		.0381	.0572	.0572	.0381
12	.0572	.0572		.0381	.0381	.0572	.0381
13	.0572	.0572		.0381	.0381	.0572	.0381
14	.0381	.0381		.0381	.0324	.0381	.0191
15	.0381	.0191		.0191	.0191	.0381	.0191
16	.0381	.0191			.0191	.0381	.0191
17	.0381	.0191		.0191	.0191	.0381	.0191
18	.0191	.0191		.0191	.0191	.0191	.0191
19	.0191	.0191		.0191	.0191	.0191	.0191
20		.0191		.0191	.0191	.0191	.0191
21	.0191	.0191		.0191	.0191	.0191	
22	.0381	.0572		.0572	.0191	.0381	.0381
23				.0572			
24					.0572	.0572	
Max	.0572	.0572	.0381	.0572	.0572	.0572	.0572
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0300	.0334	.0286	.0327	.0302	.0358	.0267

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324015 / 33/11 KV WARANGA

Feeder No / Name : 203 / 11 KV BALAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526						
2	.9526				.4763		
3	.9526						
4	1.0479						
5	1.1431				.5716		
6	1.5242				.5716	.5716	
7	1.6194	1.7147	1.5242		.6668	.6668	.7621
8	.6668		.6668	.4763	.5716	.6668	.6668
9	.5716	.5716	.5716		.4763	.6668	.5716
10	.381		.5716	.4763	1.5242	1.4289	1.4289
11	.4763	.5716			1.3336	1.7147	1.5242
12	.5716	.5716		.4763	1.4289	1.7147	1.4289
13	.4763	.5716		.4763	1.5242	1.5242	1.2384
14	.4763	.4763		.4763	1.3336	1.1431	1.3336
15	.381			.4763	1.3336	1.2384	
16	.381	.4763			1.3336	1.3336	
17	.4763	.5716		.4763	1.4289	1.3336	1.2384
18	.4763	.6668		.5716	.5716	.5716	.5716
19	.4763	.6668		.6668	.6668	.6668	.5716
20		.5716		.6668	.5716	.5716	.5716
21	.4763	.4763		.5716	.724	.5716	
22	.9526	.9526		.4763	.4763	.4763	.4763
23				.4763			
24					.4763	.4763	
Max	1.6194	1.7147	1.5242	.6668	1.5242	1.7147	1.5242
Min	.381	.4763	.5716	.4763	.4763	.4763	.4763
Avg	.7349	.6815	.8336	.5203	.9031	.9632	.9526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324015 / 33/11 KV WARANGA

Feeder No / Name : 204 / 11 KV MAHALINGI RURAL
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6668						
2	.6668				.4763		
3	.6668						
4	.6668						
5	.8573				.5716		
6	.9526				.8573	1.0479	
7	1.2384	1.1431	1.2384		1.2384	1.1431	1.3336
8	1.2384	1.1431	1.1431	1.1431	1.0479	.9526	1.0479
9	.8573	.9526	.9526		.9526	.8573	.8573
10	.8573	.8573	.8573	.8573	.6668	.6668	.6668
11	.8573	.8573		.9526	.5716	.5716	.5716
12	.8573	.7621		.7621	.5716	.5716	.4763
13	.8573	.8573		.6668	.5716	.5716	.4763
14	.7621	.6668		.7621	.5716	.5716	.4763
15	.6668	.7621		.6668	.4763	.5716	.4763
16	.6668	.7621			.5716	.5716	.4763
17	.7621	.8573		.7621	.5716	.6668	.5716
18	.6668	.6668		.7621	.7621	.7621	.6668
19	.9526	1.0479		1.0479	1.0479	1.0479	.8573
20		.9526		.8573	.8573	.9526	.8573
21	.7621	.7621		.7621	.7621	.7621	
22	.7621	.7621		.5716	.6668	.6668	.5716
23				.5716			
24					.5716	.5716	
Max	1.2384	1.1431	1.2384	1.1431	1.2384	1.1431	1.3336
Min	.6668	.6668	.8573	.5716	.4763	.5716	.4763
Avg	.8210	.8633	1.0479	.7961	.7192	.7515	.6922

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324018 / 33/11 KV KALAMNURI

Feeder No / Name : 204 / 11 KV MASOD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1867	.1097	.1494	.4409	.3647	.3734
2	.1494	.1698	.1097	.1494	.4588	.3647	.3734
3	.1494	.1509	.1097	.1494	.4588	.3932	.3734
4	.1494	.1698	.1463	.1646	.4096	.4588	.3734
5	.1646	.1646		.1646	.4588	.4534	.5601
6	.1629	.168	.1463	.1829		.4858	.5601
7	.181	.1829	.1646	.1829	.4915	.4858	.5601
8	.181	.1646	.1646	.1646	.1829		.1494
9	.1629	.1638	.2294	.1646	.1646	.1848	.1494
10	.2713		.3841	.213	.1867	.1357	.168
11	.2949	.4096	.4428		.1867	.1357	.168
12	.3277	.426	.4687	.2949	.1848	.1357	.168
13	.3932	.4748	.4999	.4588	.1848	.1494	.168
14	.4748	.4915	.4938	.4096	.168	.1494	.1867
15	.4588		.506	.4752	.168	.1357	.1848
16	.4915		.4801		.168	.1494	.1848
17			.4744	.4915	.1663	.1494	.1848
18	.1646	.1646	.1629		.168	.1494	.2033
19	.1646	.1829	.1848	.1646	.1867	.1494	.2033
20	.1097	.1829	.1848	.1463	.1867	.1867	.2033
21	.1829	.1646	.168	.2195	.1848	.1867	.1848
22	.1646	.1646	.1663	.2622	.3353	.2614	.3353
23	.1646	.128	.1494	.1966	.3353	.3361	.3688
24	.1494	.2195	.1097	.1494	.4752	.3688	.3734
Max	.4915	.4915	.506	.4915	.4915	.4858	.5601
Min	.1097	.128	.1097	.1463	.1646	.1357	.1494
Avg	.2288	.2265	.2633	.2359	.2761	.2596	.2816

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324018 / 33/11 KV KALAMNURI

Feeder No / Name : 206 / 11 KV MORGAVAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2622	.3222		.2195	.1867	.1867
2	.4755	.4049	.4588		.1646		.1867
3		.2949	.4752		.2195		.1867
4		.426	.4752	.5487	.2561		.2241
5	.6516	.4752	.6554		.2561		.2987
6		.4917	.8192		.2378	.3841	.3361
7	.7499	.4588	.7373	.7011	.1646	.4024	.3361
8			.1829		.2195		.3361
9	.2561	.1463	.1886	.128	.1829	.3018	.2987
10	.1097	.2195		.132	.5304	.5365	.6478
11	.1463	.128	.1463		.7202	.6706	.6722
12	.1829	.1829	.1109	.1463		.6706	
13		.1829	.0924	.1646		.6173	
14		.2195	.0924	.2743		.57	
15		.2801	.0924	.2378		.6154	
16		.2561	.1109	.1646		.6478	
17		.2195	.1448			.7468	.6722
18	.2195	.1646	.181	.2561		.1867	.1494
19	.2378	.2641		.2561		.2987	
20	.2743	.2926	.2743	.2195		.2241	
21	.2263	.2926	.2241	.2743		.2241	
22	.2622	.2949		.2172		.1867	
23	.2949	.3222		.2378	.1867	.1867	.168
24		.2713		.4999	.2195	.1867	.1867
Max	.7499	.4917	.8192	.7011	.7202	.7468	.6722
Min	.1097	.128	.0924	.128	.1646	.1867	.1494
Avg	.3144	.2848	.3044	.2786	.2752	.4128	.3257

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324018 / 33/11 KV KALAMNURI

Feeder No / Name : 208 / ADMINISTRATIVE FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.1187	.1475	.1494	.1311	.112	.112
2	.1307	.1475	.1475	.1494	.1475	.112	.112
3	.1307	.0995	.1475	.1478		.112	.112
4	.1478	.1475		.1463	.1475	.112	.1494
5	.1463	.1187		.1829	.1311	.1307	.1494
6	.1646	.1147			.1646	.1494	.168
7	.1646	.1357	.1147	.181	.1475	.1478	.168
8	.1646	.1475	.1147	.1646	.1475		.168
9	.1463	.1475	.1526	.1646	.1526	.1478	.168
10	.1372	.1147	.1433	.1526	.1478	.1341	.1478
11	.1311	.1134	.1463		.1478	.1357	.1478
12	.1475	.1475	.1463	.1475	.1478	.1006	.1478
13	.1147	.1147	.1463	.168	.1294	.0972	.1478
14	.1475	.1526	.1267	.1475	.1307	.112	.1478
15	.1067	.1457	.1294	.1646	.1307	.112	
16	.1067	.1311	.1463		.1307	.1494	.1478
17	.1475		.1448	.1646	.1307	.1494	.1307
18	.1372	.1543	.1629	.1646	.1478	.1494	.1307
19	.1475	.1475	.1494	.1475	.1494	.1494	.1307
20	.1526	.1646	.168	.1475	.1478	.1494	.1478
21	.1457	.1475	.168	.1646	.1494	.1494	.1478
22	.1526	.1475	.1494	.1646	.1294	.1494	.1307
23	.1147	.1147	.1494	.1475	.1294	.1494	.1307
24	.1494	.1475		.1494	.1475	.1307	.1494
Max	.1646	.1646	.168	.1829	.1646	.1494	.168
Min	.1067	.0995	.1147	.1463	.1294	.0972	.112
Avg	.1402	.1357	.1451	.1579	.1420	.1322	.1431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324041 / 33/11 KV AKHADA BALAPUR

Feeder No / Name : 201 / 11 KV KAMTHA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3326	.1829		.2401			
2	.3881	.2134	.2915	.2561			
3	.462	.2439		.2801			
4	.499	.2439	.3086	.2881			
5	.5359	.2591	.3258	.3315			
6	.5544	.3658	.5144	.4144			
7	.5729	.4877	.5658	.4961			
10			1.307	1.2071	.4877	.463	.4115
11					.503		.4641
12			1.1363		.5639	.583	.6161
13			1.3443		.5487		.5601
14			1.262			.463	.4801
15					.4115		.4801
16			1.0242		.4725	.5144	.5121
17			1.3443			.6001	.5415
18							.4641
19			.1848				.1307
20			.1867				.1307
21			.16				.112
22		.2743	.2241				.8775
23		.2743	.2401				.7842
24	.3142	.1829	.2915	.2801			
Max	.5729	.4877	1.3443	1.2071	.5639	.6001	.8775
Min	.3142	.1829	.16	.2401	.4115	.463	.112
Avg	.4574	.2728	.6301	.4215	.4979	.5247	.4689

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324041 / 33/11 KV AKHADA BALAPUR

Feeder No / Name : 202 / 11 KV SHEWALA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	23-MAR-18	27-MAR-18
HR	Load (MW)	Load (MW)
1		.7468
2		.7621
3		.7621
4		.7926
5		.8383
6		.8383
7		1.2498
10	1.0669	
12	1.2346	
14	1.2346	
16	1.286	
19		.1372
20	.1715	.1372
21	.1715	.1372
24		.7468
Max	1.286	1.2498
Min	.1715	.1372
Avg	.8609	.6499

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324041 / 33/11 KV AKHADA BALAPUR

Feeder No / Name : 203 / 11 KV RUDRAWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	23-MAR-18	24-MAR-18	25-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1067	
2				.1067	.1029
3				.1219	
4				.1219	
5				.1524	
6					.1886
7				.2743	.2229
10	.1981	.1844	.2054		
11		.2427			
12	.2743	.2515			
13		.2347			
14	.2401				
15		.218			
16	.2743	.218			
17		.2515			
22				.0686	.1867
23				.1029	.1509
24				.1067	.1029
Max	.2743	.2515	.2054	.2743	.2229
Min	.1981	.1844	.2054	.0686	.1029
Avg	.2467	.2287	.2054	.1291	.1592

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324041 / 33/11 KV AKHADA BALAPUR

Feeder No / Name : 204 / 11 KV PIMPRI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.7545		.7842			
2	.1509	.7545	.6859	.8029			
3	.1886	.7716		.639			
4	.1698	.7716	.6687	.6539			
5	.1509	.7888	.703	.6687			
6	.1886	.8059	.8916	.6687			
7	.1886	.9259	.9431	.8173			
10					.8059		.5658
12							.6554
13							.6516
14					.5658	.5316	.5967
15					.583		.6348
16					.6516	.6173	.535
17						.6344	.6161
22			.6687				
23		.6859	.6554				
24	.1509	.7888	.6859	.6401			
Max	.1886	.9259	.9431	.8173	.8059	.6344	.6554
Min	.1509	.6859	.6554	.639	.5658	.5316	.535
Avg	.1698	.7831	.7378	.7094	.6516	.5944	.6079

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324041 / 33/11 KV AKHADA BALAPUR

Feeder No / Name : 205 / 11 KV RUDRAWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3086		.3361		.3086	
2		.3086	.2401	.3361		.3086	.2401
3		.3258		.2881		.3772	
4		.3429	.2229	.3734		.4115	.2401
5		.5144	.2915	.5144		.4801	
6		.5487	.5144	.5975		.5144	.5144
7		.703	.5487	.6535		.6687	
8		.6516	.5601	.6348		.5658	.5487
9		.6001	.463	.5228	.4801	.5144	.3944
10		.4801	.3361	.3921	.3772		
11			.2801		.3772	.5144	.2614
12		.3258	.3361		.3429		.2614
13			.3547			.1886	.2614
14		.2743	.3174		.3258		.208
15			.3361		.3258	.2229	.2427
16		.3086	.3174		.3086		.3174
17	.2743		.463		.4287	.3944	.4481
18	.442	.4973	.5228		.5658		.5601
19	.5182		.5788		.5487	.4115	.5601
20	.5487	.4115	.5041		.5144		
21		.3772	.3944			.3772	.9149
22		.3258	.3048			.3429	.4108
23		.3086	.3086			.0171	.3601
24		.2743	.2743	.3086		.2915	.2572
Max	.5487	.703	.5788	.6535	.5658	.6687	.9149
Min	.2743	.2743	.2229	.2881	.3086	.0171	.208
Avg	.4458	.4151	.3850	.4507	.4177	.3839	.3890

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324041 / 33/11 KV AKHADA BALAPUR

Feeder No / Name : 206 / 11 KV PIMPRI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4207	.3601		.3921	.4572	.3772	
2	.439	.3429	.3429	.3921	.4938	.3772	
3	.4572	.3772		.3921	.5304	.4287	
4	.3467	.4287	.3944	.3921	.6401	.5487	.3772
5	.4334	.5316	.4287	.5601	.7133	.6859	
6	.483	.7716	.7202	.8962	.8962	.7202	
7	.7316	.9259	.8573	.9709	.9694	.8402	
8	.6767	.7373	.8215	.8029	.7682	.703	.5144
9	.4938	.583	.6348	.6161	.6767		
10	.5121			.4294	.4115		.3601
11	.3292	.3944		.2926		.2229	
12	.2926	.2401		.2561			.2987
13	.2926			.2926			.2987
14	.2926	.2572	.3258	.2743	.3086		.3361
15	.2378		.3174	.2926	.3086	.3601	
16		.2229	.3734	.3292	.3429		.3547
17	.3601		.3944	.439	.3772	.4458	.6348
18	.4458	.4458	.5415	.567	.5144		
19	.583		.7095	.6584	.703	.6687	.8215
20	.5487	.5316	.5601	.567	.5144		.5228
21		.4458	.4854	.4938		.4458	.5228
22			.4294	.439		.3429	.4668
23		.3601	.3921			.3601	.4481
24	.4024	.3601	.3601	.3601	.3841	.3601	.3258
Max	.7316	.9259	.8573	.9709	.9694	.8402	.8215
Min	.2378	.2229	.3174	.2561	.3086	.2229	.2987
Avg	.4390	.4620	.5049	.4829	.5561	.4930	.4488

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324041 / 33/11 KV AKHADA BALAPUR

Feeder No / Name : 207 / 11 KV KAMTHA GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0991	.12			.0867	.0857	
2	.0867	.1029	.1029		.0372	.0857	
3	.0495	.1372			.0495	.1029	
4	.0619		.12		.1115	.1372	
5	.0867	.1715	.1543		.1238		
6	.1238	.1715	.1715		.1486	.1886	.2058
7	.1238	.2572	.2401	.2427	.1858	.2401	
8	.1115		.2614	.2614	.1486	.2401	
9	.0743	.1715	.1867	.1715	.1115	.1543	
10	.1115		.112	.168	.1029		.1029
11	.0743	.1372	.0934	.0743	.1029	.1029	.112
12	.0743	.1029	.061	.1115	.1029	.1029	
13	.0619		.0934	.0495	.0857		.0934
14	.0495	.0857	.0934	.0619		.1029	.0934
15	.0743		.0934	.0372	.0857		.1307
16	.0743	.1029	.0934	.0743	.0857	.12	.5487
17	.12		.112	.0867	.12		.081
18	.1543	.1715	.1494	.0867	.1372		.1372
19	.1715		.1715	.1486	.1715		.1867
20	.1715	.1372	.1867	.1362	.1543	.1372	.1867
21		.12	.1307	.0867			.1307
22			.0914	.0743		.1029	.112
23		.1029	.0762	.0495		.0857	.0829
24	.1115	.1372	.0857	.0934	.0619	.0857	.1372
Max	.1715	.2572	.2614	.2614	.1858	.2401	.5487
Min	.0495	.0857	.061	.0372	.0372	.0857	.081
Avg	.0984	.1393	.1309	.1119	.1107	.1297	.1561

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324041 / 33/11 KV AKHADA BALAPUR

Feeder No / Name : 208 / 11 KV SHEWALA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5144		.6535		.6516	
2		.4877	.5487	.5335		.6516	
3		.6516		.6535			
4			.6001	.7842		.8573	.6173
5		.823	.7202	1.0082			
6		1.2174	1.3717	1.307		1.1145	
7		1.3889	1.406	1.3203			
8			1.2803	1.4003		1.286	1.2517
9		1.0288	1.1576	1.1949	.8059	.9259	
10		.8573	.7842	.8962	.6344		.7716
11			.7842		.5658	.3429	.5144
12		.5144	.5041				.5041
13			.4481			.4458	.5601
14		.4287	.4668				.5041
15			.4938		.4458	.4801	.4481
16		.4115			.5487		
17			.8589		.7545	.6859	.7095
18	.9431	.9088	.9896		.9259		1.1203
19	1.2003		1.307		1.5432	1.2003	1.2136
20	1.0974	.9431	1.0269		.9259		1.0269
21		.7373	.8402			.7716	1.8298
22			.7282			.6173	.7655
23		.5658	.6173			.6001	.7095
24		.5487	.5658	.6535		.6001	.5658
Max	1.2003	1.3889	1.406	1.4003	1.5432	1.286	1.8298
Min	.9431	.4115	.4481	.5335	.4458	.3429	.4481
Avg	1.0803	.7517	.8333	.9459	.7945	.7487	.8195

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324041 / 33/11 KV AKHADA BALAPUR

Feeder No / Name : 209 / 11 KV BALAPUR URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7371	.6859		.8002	.6954	.7011	
2	.7232	.6859	.8059	.8002	.6676	.7011	.823
3	.7093	.7316		.8002	.6259	.6859	
4	.8345	.7926	.823	.8642	.6954	.7316	.8573
5	.904	.8383	.8916	.9602	.8206	.7926	
6	.9596	.9907	1.2003	1.0242	.904	.9297	1.2003
7	1.0987	1.1888	1.2346	1.1523	.9875	1.1126	
8	1.0848		.7682	1.2003	.8762	1.0822	1.1145
9	.7928	.9907	.9282	1.0562	.7649	.884	.9431
10	.7232	.9755	.7682	.9282	.8688		
11	.6676		.7362	.7788	.8078	.7202	.7362
12	.7371	.9088	.7373	.6676	.7164		.6722
13	.6815		.8215	.5563	.6249	.7373	.6722
14		.7202	.6722	.5702	.7011		.6722
15	.5841		.7282	.6259	.6859	.7202	.6722
16	.7232	.7373	.7682	.6676	.7164		.7282
17	.7621		.7522	.7649	.823	.8573	.7362
18	.9297	1.046	.7842	.7232	.884		.9282
19	1.0059		.7842	.8206	.9602	.9602	.9282
20	.945	1.1145	1.0402	.7788	.884		.9282
21	.7621	1.0802	.9602	.8067		.9602	.9442
22		.9945	.8962	.7928		.8916	.8962
23		.9259	.8642	.7649		.9088	1.0082
24	.7371	.7316	.8916	.8162	.7232	.7316	.8573
Max	1.0987	1.1888	1.2346	1.2003	.9875	1.1126	1.2003
Min	.5841	.6859	.6722	.5563	.6249	.6859	.6722
Avg	.8144	.8966	.8571	.8217	.7825	.8393	.8588

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324053 / 33/11 KV SUKLI VEER

Feeder No / Name : 201 / 11 KV SUKLI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	26-MAR-18	27-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.9526		.1143	
4		1.1431		.1143	
6		1.2384			
7	.9288				
8		1.3336			
11				.8916	
16					.8573
20			.1905		.1905
22			.5716		.1905
23			.6668		.1905
24		.7621		.1143	
Max	.9288	1.3336	.6668	.8916	.8573
Min	.9288	.7621	.1905	.1143	.1905
Avg	.9288	1.0860	.4763	.3086	.3572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324053 / 33/11 KV SUKLI VEER

Feeder No / Name : 204 / JAMGAVAHAN GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.6668			.381	
4		.7621			.5716	
6		.9526			.9526	
7	1.1203					
8	.9526	1.1431		1.0479	.9526	.9335
9			.9335	.9526		
10	.5716		.7468	.7621		
11					.4668	
12	.4763			.381		
16	.381		.4763	.4763		
18		.7316	.5716			
20			.4763			
22			.381			
23			.4763			
24		.4763			.381	
Max	1.1203	1.1431	.9335	1.0479	.9526	.9335
Min	.381	.4763	.381	.381	.381	.9335
Avg	.7004	.7888	.5803	.7240	.6176	.9335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324053 / 33/11 KV SUKLI VEER

Feeder No / Name : 206 / 11 KV SUKALI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.0191			.0191	
4		.0191			.0191	
6		.0381				
7	.0297					
8	.0381	.0381		.0191	.0381	.0297
9			.029			
10	.0191		.0143	.0191		
11					.0149	
12	.0191			.0191		
14	.0191			.0191		
16	.0191		.0381	.0191		.0381
18		.029	.0191			.0381
20			.0191			.0191
22			.0191			.0191
23			.0191			.0191
24		.0191			.0191	
Max	.0381	.0381	.0381	.0191	.0381	.0381
Min	.0191	.0191	.0143	.0191	.0149	.0191
Avg	.0240	.0271	.0225	.0191	.0221	.0272

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324068 / 33/11 KV GAUL BAZAR

Feeder No / Name : 204 / 11 KV GAUL BZ GATOHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1063	.1097		.1143	.0934	.0895	.1214
2	.1063	.1086	.1075	.1143	.0678	.0895	.104
3	.124	.1075	.1254	.1143	.0934	.1075	.1075
4	.1417	.1254	.1433	.1143	.112	.1267	.1267
5	.1595	.1267	.1612	.1524	.1267	.1448	.1478
6	.2012	.1463	.1991	.1905	.1494	.1629	.1991
7		.1433	.181	.1905	.2241	.1448	.1698
8	.104	.1063	.1753	.1905	.168	.1734	.1753
9	.1006	.1448			.1494	.1417	.0924
10	.1187	.132	.1267	.1086	.1227	.12	.0716
11	.0819	.1307	.1143	.1097	.1214	.1227	.081
12	.0732	.1075	.1143	.1086	.1063	.1029	
13	.0732	.1307	.0953	.1052	.0867	.12	.0633
14	.056	.1097	.0953	.1227	.0995	.1029	.0594
15	.1214	.096	.0953	.1086	.1006	.1063	.1052
16	.0876	.0995	.1143	.0747	.1097	.124	.1075
17	.1417	.1389	.1524	.0566	.1267	.1086	.1254
18	.1052	.1734	.1905	.0924	.1753	.1097	.0886
19	.1448	.197	.1905	.1448	.1494	.1578	.1433
20	.0914	.1612	.1905	.1402	.128	.1612	.1214
21	.1448	.1174	.1524	.1227	.1132	.0895	.12
22	.1227	.104	.1143	.0724	.1063	.1187	.1017
23	.1052	.1017	.1143	.0914	.1063	.1187	.0995
24	.1075	.1097	.1017	.1143	.0934	.0943	.12
Max	.2012	.197	.1991	.1905	.2241	.1734	.1991
Min	.056	.096	.0953	.0566	.0678	.0895	.0594
Avg	.1139	.1262	.1389	.1197	.1221	.1224	.1153

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324083 / 33/11 KV SALWA

Feeder No / Name : 201 / 11 KV SALVA GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6099	.6283	.5914	.5729	.6099	.5914	.6283
2	.6099	.6283	.5914	.5544	.5544	.5914	.6283
3	.5914	.6283	.5914	.5544	.6653	.5729	.6283
4	.6468	.7392	.6653	.5914	.7023	.6468	.7023
5	.8131	.8501	.7392	.7023	.7392	.8871	.8316
6	1.0164	1.1827	.961	.924	.8501	1.1088	1.2012
7	1.0534	1.2936	.9979	1.0719	1.0719	1.0349	1.3306
8	.961	1.1827	.8131	1.0534	.9795	.9425	1.1273
9	.6653	.7392	.5914	.7392	.6468	.7947	.8686
10		.5914	.6283	.6838	.5729	.5914	.5914
11	.5359	.4066	.4435	.4251	.5175	.5175	.462
12	.4435		.4435		.4251	.4251	
13	.4066		.3512	.4435	.4066		.4066
14	.4066		.4435	.462	.4251	.462	.4805
15			.462	.462	.462	.4435	.4805
16		.5175		.499	.5544	.462	.4805
17		.6283	.6283	.6838	.6283	.5914	
18		.7392	.6838	.8316	.7762	.7762	
19	1.1458	1.0349	1.0349	1.0164	1.0164	.924	1.0349
20	.924	.961	.8316	.924	.924	.924	.924
21	.8131	.7762	.7762	.8131	.8131	.7947	.7762
22	.7392	.6653	.7023	.6838	.7023	.7023	.7023
23	.6653	.6283	.6468	.6099	.6283	.6468	.6283
24	.6283	.6283	.5914	.5914		.6099	.6283
Max	1.1458	1.2936	1.0349	1.0719	1.0719	1.1088	1.3306
Min	.4066	.4066	.3512	.4251	.4066	.4251	.4066
Avg	.7198	.7725	.6613	.6910	.6814	.6974	.7401

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324083 / 33/11 KV SALWA

Feeder No / Name : 202 / 11 KV SALVA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.3658	.5121	.4536
2					.3658	.4829	.439
3					.4097	.4682	.4097
4					.4682	.5267	.4097
5					.6438	.6438	.5121
6					.7023	.7609	.6731
7					.8194	1.0828	.9511
10	.8633	.9072	.9364	.834			
11	.7023	.9072	.7901				
12	.5853		.7901	.2634			
13	.7901		.9218	.2487			
14	.8194		.8779	.1317			
15			.8048	.1756			
16		.9364	.995	.2195			
17		1.0535	.8779				
22				.3219	.5706	.4682	.4097
23				.462	.6145	.5267	.439
24					.3658	.556	.5121
Max	.8633	1.0535	.995	.834	.8194	1.0828	.9511
Min	.5853	.9072	.7901	.1317	.3658	.4682	.4097
Avg	.7521	.9511	.8743	.3321	.5326	.6028	.5209

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324085 / 33/11 KV DONGARKADA

Feeder No / Name : 201 / 11 KV DONGARKADA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4668	.4112	.5217	.4649	.5217
2			.5121	.4116			
3			.5121	.4495	.5538	.5191	.5578
4			.6089	.4687			
5			.7499	.7484	.7301	.5556	.6501
6			1.0269	.9316			.9269
7			1.134	1.1123	1.1367	.9221	1.2049
8			1.0164	.9345	.9107	1.1134	1.037
9			.7109	.835	.6817	.6859	
10	.5487		.5031		.5561		
11	.5175			.4486		.4835	.5005
12	.4755		.4463		.4237		.4454
13	.4251			.3742		.3708	
14			.4087		.3704		.4449
15	.3921			.3746	.3925	.463	.5021
16	.4435		.4634	.4463	.5159	.4825	.4859
17		.5487	.6296	.5567	.6428		.6296
18		.7468	.7415	.7377		.6495	
19		1.0059	.8889	.9572	.9472		.9135
20		.924	1.0206		.8213	.8519	
21		.7316	.964	.6564			.6639
22		.5914	.5567	.5527	.6251	.6136	.5538
23		.5544	.4649	.5578	.5578	.5561	.5578
24			.4668				
Max	.5487	1.0059	1.134	1.1123	1.1367	1.1134	1.2049
Min	.3921	.5487	.4087	.3742	.3704	.3708	.4449
Avg	.4671	.7290	.6806	.6297	.6492	.6237	.6622

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324085 / 33/11 KV DONGARKADA

Feeder No / Name : 202 / 11 KV WARUD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9145	1.0068	.1427	.1555	.1555
2		.9907	1.0056			
3		1.0031	1.0856	.1568	.1549	.1549
4		1.0031	1.0842	.1549	.1401	.1555
5		1.0494	1.166			
6		1.1574	1.3198			
7		1.2193	1.394			
10				.7125	1.2701	1.3231
11					1.4303	1.394
12				1.3957		
13				1.3014	1.3182	1.2082
14				1.2245	.9806	
15					1.2904	1.1731
16				1.1462	1.2856	1.2163
17				1.1617	1.3214	1.2102
18	.1174					.0933
19	.176	.1781	.2168	.1568	.2038	
20	.176	.1779		.1704	.1712	.1568
21	.176	.1478	.1725			
22	.8488	.9294	.1551	.1866	.1564	.1549
23	.9145	1.0105	.1549	.1549	.156	.1555
24		.9145				
Max	.9145	1.2193	1.394	1.3957	1.4303	1.394
Min	.1174	.1478	.1549	.1427	.1401	.0933
Avg	.4015	.8227	.7965	.6204	.7168	.6578

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324085 / 33/11 KV DONGARKADA

Feeder No / Name : 203 / 11 KV BHATEGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.088	.089	.2822	.4358	.3731
2			.088	.1038			
3			.088	.1039	.3109	.4647	.3891
4			.088	.1039			
5					.3497	.5428	.5421
6					.4957	.5731	.6081
7					.5763	.6685	.6521
10	.6636		.2478	.5597			
11	.6636						
12	.6173		.0774	.5777			
13	.5335						
14	.4877		.6203	.5111			
15	.4877		.5435	.4561			
16	.463		.618	.4853			
17		.4938		.4664			
18		.0734	.0742	.047		.047	.0627
19		.088	.089	.093	.047		
20		.088	.0889		.0465	.0933	.1084
21		.088	.0889	.0941			
22		.088	.089	.2659	.4032	.5111	.4182
23		.088	.0889	.2788	.4077	.4358	.4198
24			.088				
Max	.6636	.4938	.6203	.5777	.5763	.6685	.6521
Min	.463	.0734	.0742	.047	.0465	.047	.0627
Avg	.5595	.1439	.1916	.2824	.3244	.4191	.3971

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

SENGAON SUB-DIVISION[797] BU 4797

Substation No/ Name :- 324020 / 33 KV Goregaon

Feeder No / Name : 207 / 11 KV PALSHI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.4978	.5121			.4984		.3651
4	.5322	.5121			.6043		.4652
5		.5121					
6	.6378	.5975			.5821		.3861
12	.5975	.6645				.5815	.4932
13	.5975	.6645				.5974	
14	.6487	.5835					
15	.6487					.3834	
16	.6145			.5316		.3357	
17	.5708			.5476		.4984	
18				.632		.515	
19				.5815		.4153	
20	.5121			.5981		.4196	
21				.4652		.4028	
22	.5121		.4624	.4149		.3655	
24	.4153	.5121			.3983		.299
Max	.6487	.6645	.4624	.632	.6043	.5974	.4932
Min	.4153	.5121	.4624	.4149	.3983	.3357	.299
Avg	.5654	.5698	.4624	.5387	.5208	.4515	.4017

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

SENGAON SUB-DIVISION[797] BU 4797

Substation No/ Name :- 324089 / 33 kV AJEGAON

Feeder No / Name : 202 / 11 KV TAKTODA AG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	26-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	.4193			
12		.4601	.421	.3923
Max	.4193	.4601	.421	.3923
Min	.4193	.4601	.421	.3923
Avg	.4193	.4601	.421	.3923

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

SENGAON SUB-DIVISION[797] BU 4797

Substation No/ Name :- 324089 / 33 kV AJEGAON

Feeder No / Name : 203 / 11 KV WAGHJALI AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	23-MAR-18	26-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
12	.4755	.4072	.4079
Max	.4755	.4072	.4079
Min	.4755	.4072	.4079
Avg	.4755	.4072	.4079