

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044051 / 33 / 11 KV POWER HOUSE S/S

Feeder No / Name : 201 / 11 kv Aurangapura Feeder SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2803	1.307	1.267	1.3121	1.358	1.307	1.3443
2	1.2437	1.307	1.2437	1.2567	1.2883	1.2936	1.307
3	1.1458	1.5089	1.1946	1.2382	1.2696	1.4003	1.307
4	1.1643	1.587	1.2254	1.2382	1.2136	1.4003	1.4937
5	1.1888	1.587	1.2803	1.2012	1.2883	1.5089	1.4937
6	1.386	1.7556	1.5154	1.3256	1.3306	1.4937	1.587
7	1.7177	1.8298	1.6057	1.587	1.6078	1.587	1.587
8	1.7737	1.8111	1.7002	1.7187	1.6804	1.5684	1.6617
9	1.7924	1.8858	1.8111	1.7364	1.6975	1.5708	1.7556
10	1.7177	1.8671	1.6244	1.6644	1.6991	1.6644	1.7372
11	2.1691	2.1098	2.1472	1.8656	2.1098	2.0302	2.1658
12	2.2405	2.3899	2.2592	2.1765	2.1765	2.268	2.2405
13	2.3525	2.3339	2.2405	2.1472	2.4832	2.2862	2.347
14	1.9605	2.2965	2.0725	2.2032	2.3411	2.2862	2.3712
15	2.4949	2.3045	2.1845	2.0538	2.4832	2.3152	2.4272
16	2.3339	2.3339	2.1472	2.0351	2.4143	2.4326	2.5133
17	2.4272	2.6139	2.1472	2.1437	2.4143	2.4691	2.5423
18	2.7073	2.7073	2.1472	2.4143	2.4143	2.4874	2.7069
19	2.9569	2.9313	3.006	2.7721	2.8532	3.0361	2.7984
20	2.652	2.8006	3.0807	2.809	2.9264	3.0361	2.9813
21	2.5503	2.6699	2.6242	2.3285	2.652	2.6886	2.6155
22	2.0538	2.1807	2.0328	1.2071	2.1216	2.0485	2.0851
23	1.7364	1.7741	1.7002	1.6598	1.6617	1.7364	1.6991
24	1.3352	1.4003	1.39	1.4045	1.39	1.4563	1.4937
Max	2.9569	2.9313	3.0807	2.809	2.9264	3.0361	2.9813
Min	1.1458	1.307	1.1946	1.2012	1.2136	1.2936	1.307
Avg	1.9325	2.0539	1.9020	1.8125	1.9531	1.9738	2.0109

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044051 / 33 / 11 KV POWER HOUSE S/S

Feeder No / Name : 202 / 11 KV SAMARTH NAGAR FEEDR SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6598	1.587	1.6804	1.6804	1.6804	1.6804	1.7556
2	1.6598	1.6032	1.6057	1.643	1.5684	1.587	1.6804
3	1.5844	1.7353	1.5123	1.4937	1.6057	1.587	1.6804
4	1.5844	1.8298	1.531	1.531	1.643	1.8671	1.6804
5	1.5844	1.9404	1.5655	1.6409	1.7737	1.8671	1.8671
6	1.8296	1.9605	1.773	1.7918	1.9044	2.0538	2.2405
7	2.2822	2.2257	1.9993	1.9239	2.0538	2.0538	2.2405
8	2.1879	2.2405	2.0748	2.0182	2.0538	2.0911	2.2405
9	2.3712	2.5393	2.1285	2.0725	2.2405	2.1948	2.3525
10	2.4143	2.6326	2.2032	2.0328	2.1948	2.1948	2.4272
11	2.2405	2.9801	2.3339	2.2361	2.7069	2.8166	2.894
12	2.4709	2.8753	2.5206	2.2497	2.7435	2.8715	2.894
13	2.7073	2.7726	2.5133	2.1845	2.7984	2.6886	2.894
14	2.6139	2.5393	2.4646	2.1472	2.5606	2.5972	2.7633
15	2.5766	2.5206	2.4086	2.0911	2.8349	2.7633	2.8193
16	2.652	2.6326	2.3899	2.0725	2.8166	2.8349	2.6139
17	2.8006	2.8006	2.4272	2.0538	2.7984	2.7984	2.6703
18	2.9569	2.9569	2.5579		2.6337	2.7252	2.9813
19	3.1093	3.1417	2.9874	2.6513	2.7801	3.3471	3.3288
20	2.9938	2.9874	3.1181	2.6699	3.0178	3.2922	3.1459
21	2.6612	2.7633	2.8753	2.5206	2.7069	2.9264	2.7984
22	2.4272	2.32	2.3712	2.2405	2.3594	2.5057	2.3777
23	2.1285	2.0538	2.1658	1.9978	2.0538	2.2592	2.1845
24	1.8107	1.6804	1.7924	1.8298	1.7364	1.7737	1.8671
Max	3.1093	3.1417	3.1181	2.6699	3.0178	3.3471	3.3288
Min	1.5844	1.587	1.5123	1.4937	1.5684	1.587	1.6804
Avg	2.3045	2.3883	2.2083	2.0336	2.3027	2.3907	2.4332

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044051 / 33 / 11 KV POWER HOUSE S/S

Feeder No / Name : 203 / 11 kv city chowk feeder SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0082	1.1203	1.0829	1.1576	1.094	1.0269	1.0269
2	1.0082	1.0829	.9709	1.0829	1.0082	1.0164	1.0269
3	.9335	1.094	.9335	.9335	.9709	1.0456	1.1203
4	.9431	1.1203	1.0456	.9522	.9335	1.1458	1.1203
5	.9431	1.1203	1.1203	.9896	1.0562	1.1576	1.307
6	1.1128	1.3443	1.1763	1.1203	1.1389	1.2136	1.307
7	1.2071	1.3443	1.2826	1.226	1.2696	1.307	1.307
8	1.4335	1.3203		1.4146	1.39	1.3443	1.3443
9	1.4335	1.4815	1.39	1.5497	1.475	1.2803	1.5089
10	1.5123	1.5546	1.4449	1.6617	1.1523	1.5181	1.5655
11	1.6244	1.7924	1.5123	1.6804	1.5364	1.5546	1.6221
12	1.5497	1.7364	1.4937	1.6095	1.4815	1.39	1.6221
13	1.4998	1.5844	1.363	1.5123	1.4083	1.4998	1.5844
14	1.4266	1.1763	1.2696	1.2136	1.3352	1.3717	1.4335
15	1.2936	1.0242	1.1317	1.1763	1.2323	1.1584	1.3256
16	1.2437	1.0974	1.1317	1.1576	1.2071	1.1888	1.2883
17	1.4784	1.307	1.307	1.2883	1.2803	1.2803	1.3535
18	1.5708	1.4937	1.363	1.4563	1.39	1.3535	1.3352
19	1.7002	1.5708	1.4937	1.6617	1.7375	1.6461	1.7375
20	1.6632	1.587	1.6804	1.587	1.6827	1.701	1.7193
21	1.531	1.4937	1.4937	1.4901	1.5729	1.5729	1.5364
22	1.4003	1.587	1.4003	1.3817	1.5912	1.4449	1.3717
23	1.3443	1.419	1.3014	1.307	1.4377	1.363	1.307
24	1.1128	1.1694	1.1203	1.1949	1.1389	1.1203	1.2136
Max	1.7002	1.7924	1.6804	1.6804	1.7375	1.701	1.7375
Min	.9335	1.0242	.9335	.9335	.9335	1.0164	1.0269
Avg	1.3323	1.3592	1.2830	1.3252	1.3134	1.3209	1.3785

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044051 / 33 / 11 KV POWER HOUSE S/S

Feeder No / Name : 204 / 11 KV bus stand Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1203	1.094	1.1203	1.1576	1.1576	1.1203	1.2136
2	1.0456	1.0829	1.0829	1.0562	1.1016	1.1203	1.2012
3	1.0562	1.1088	1.0185	1.0562	1.0456	1.0719	1.1203
4	1.094	1.251	1.0562	1.0829	1.0349	1.2136	1.2696
5	1.1128	1.419	1.0562	1.1506	1.2883	1.307	1.2696
6	1.2637	1.419	1.2449	1.1883	1.4003	1.307	1.386
7	1.3392	1.531	1.226	1.3014	1.4003	1.4003	1.4563
8	1.4901	1.5684	1.3392	1.3203	1.4003	1.4003	1.4563
9	1.5684	1.7177	1.419	1.358	1.6057	1.4632	1.6032
10	1.4937	1.8298	1.2986	1.423	1.7177	1.647	1.7177
11	1.643	1.8298	1.307	1.3443	1.7558	1.6651	1.7737
12	1.7737	1.8107	1.363	1.4003	1.7551	1.701	1.6651
13		1.6409	1.475	1.2936	1.7551	1.4815	1.6804
14	1.531	1.5684	1.5089	1.2254	1.7375	1.5729	1.6804
15	1.643	1.5912	1.4563	1.1949	1.7375	1.5384	1.7177
16	1.5364	1.6598	1.4377	1.1576	1.6278	1.7375	1.7353
17	1.6632	1.6804	1.4003	1.1576	1.6827	1.6461	1.7741
18	1.8671	1.6632	1.3443	1.2637	1.6644	1.7924	1.7741
19	1.9404	1.7926	1.587	1.531	1.8656	1.8656	1.9022
20	1.848	1.7737	1.6991	1.419	1.7375	1.829	1.7375
21	1.5708	1.5497	1.7551	1.4377	1.701	1.6461	1.5729
22	1.4937	1.4146	1.4523	1.3957	1.4998	1.6095	1.5181
23	1.3817	1.3203	1.3769	1.3014	1.3817	1.4937	1.4377
24	1.1694	1.1203	1.2071	1.2449	1.226	1.2136	1.307
Max	1.9404	1.8298	1.7551	1.531	1.8656	1.8656	1.9022
Min	1.0456	1.0829	1.0185	1.0562	1.0349	1.0719	1.1203
Avg	1.4628	1.5182	1.3430	1.2692	1.5117	1.4935	1.5404

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044051 / 33 / 11 KV POWER HOUSE S/S

Feeder No / Name : 205 / 11 KV VASANT BHUVAN FEEDER SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.134	1.1317	1.1949	1.086	1.2696	1.2136	1.1203
2	1.0608	1.1203	1.1203	1.0498	1.1203	1.2136	1.1203
3	.961	1.1203	1.0456	.9774	1.0829	1.307	1.307
4	.9979	1.386	1.1576	1.0136	1.0642	1.307	1.2936
5	1.0164	1.4415	1.307	1.0317	1.1576	1.4003	1.4003
6	1.1763	1.4784	1.6221	1.1706	1.2323	1.4146	1.4937
7	1.4563	1.4937	1.4335	1.2936	1.4003	1.4937	1.4937
8	1.475	1.5497	1.5339	1.4003	1.419	1.4563	1.4563
9	1.6057	1.587	1.7364	1.475	1.5123	1.4661	1.3817
10	1.531	1.6057	1.3256	1.5154	1.4449	1.5203	1.46
11	1.5123	1.3203	1.4563	1.5684	1.6057	1.4842	1.5893
12	1.5684	1.7924	1.4937	1.6095	1.6095	1.701	1.5893
13	1.587	1.6804	1.587	1.4998	1.5546	1.5729	1.4815
14	1.4815	1.475	1.2986	1.4998	1.4815	1.448	1.4632
15	1.39	1.4083	1.363	1.3817	1.4632	1.4266	1.46
16	1.4632	1.3443	1.1949	1.4045	1.4998	1.4632	1.46
17	1.6632	1.4937	1.4003	1.3575	1.5729	1.5364	1.5364
18	1.7375	1.7556	1.475	1.647	1.6461	1.6644	1.6461
19	1.8656	1.885	1.6804	1.7737	1.9204	1.9022	1.5546
20	1.829	1.8671	1.8671	1.7737	1.957	1.9753	1.9936
21	1.7193	1.8671	1.7375	1.647	1.829	1.829	1.8107
22	1.587	1.7194	1.4083	1.4661	1.701	1.5912	1.5729
23	1.3817	1.448	1.3169	1.3394	1.531	1.4937	1.4003
24	1.2071	1.1949	1.2803	1.2127	1.2986	1.307	1.307
Max	1.8656	1.885	1.8671	1.7737	1.957	1.9753	1.9936
Min	.961	1.1203	1.0456	.9774	1.0642	1.2136	1.1203
Avg	1.4336	1.5069	1.4182	1.3831	1.4739	1.5078	1.4747

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044051 / 33 / 11 KV POWER HOUSE S/S

Feeder No / Name : 207 / ATM FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0063	.0133	.0086	.005	.0095	.0107	.0118
2	.0065	.0135	.0088	.0046	.0114	.0118	.012
3	.0053	.0116	.0078	.005	.0095	.0114	.0135
4	.0055	.0133	.0107	.005	.0057	.0133	.0141
5	.0065	.0111	.0111			.0124	.0149
6	.0053	.013		.0048	.0162	.0131	.0145
7	.0158	.0133	.0124	.0118	.0152	.0111	.0124
8	.0139	.0135	.0086	.0135	.0171	.0135	.0112
9	.0044	.0133	.0187	.017	.0114	.0114	.0566
10	.0114	.0095	.0072	.0076	.0187	.0133	.0566
11	.0114	.0095	.0095	.0095	.0095	.0183	.0133
12	.0076	.0114	.0114	.0187	.0183	.0114	.0133
13	.0095	.0189	.0114	.0057	.0183	.0114	.0103
14	.0076	.0187	.0095	.0095		.0143	.0187
15	.0057	.0095	.0095	.0133	.0095	.0191	.0158
16	.0133	.0072	.013	.0185	.0152	.0191	.0137
17	.013	.0141	.0111	.0133	.0191	.0191	.0191
18	.0133	.0122	.0112	.0166	.0572	.0191	.0191
19	.0185	.0124	.0135	.009	.0191	.0191	.0191
20	.012	.0124	.0131	.0091	.0191	.0191	.0191
21	.0185	.0114	.0048	.0061	.0191	.0191	.0191
22	.0107	.0084	.005	.0061	.0191	.0191	.0191
23	.0111	.0061	.005	.0055	.012	.0124	.0107
24	.0063	.0118	.0053	.005	.0055	.0107	.0114
Max	.0185	.0189	.0187	.0187	.0572	.0191	.0566
Min	.0044	.0061	.0048	.0046	.0055	.0107	.0103
Avg	.01	.0121	.0099	.0096	.0162	.0147	.0183

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044051 / 33 / 11 KV POWER HOUSE S/S

Feeder No / Name : 208 / Medical(jublipark water  
works) Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0263	.0373	.0259	.0263	.0373	.0373	.0373
2	.0263	.0373	.0263	.0255	.0191	.0373	.0373
3	.0259	.0377	.0566	.0259	.0213	.0377	.0377
4	.0389	.0373	.0566	.0255	.0229	.0377	.0373
5	.0566	.0373	.0566	.0566	.0328	.0377	.0373
6	.0566	.0373	.0566	.0566	.0267	.0373	.0373
7	.0566	.0566	.0566	.0566	.0343	.056	.056
8	.0566	.0566	.0566	.0566	.0566	.056	.0566
9	.0351	.056		.0358	.0566	.0543	.0332
10	.0566	.056	.0343	.0343	.0549	.0566	.0339
11	.056	.056	.056	.056	.0549	.0566	.0566
12	.056	.056	.056	.0566	.0549	.0543	.0566
13	.0566	.056	.0566	.0566	.0566	.0566	.0566
14	.0566	.0566	.056	.0566	.0549	.0549	.0566
15	.0566	.0549	.056	.0566	.0566	.0566	.0566
16	.0566	.056	.056	.0566	.0549	.0572	.0566
17	.0566	.056	.0566	.0566	.0572	.0572	.0572
18	.056	.0566	.0566	.0343	.0572	.0572	.0572
19	.0566	.0566	.0566	.0566	.0572	.0572	.0572
20	.056	.0566	.056	.0566	.0572	.0572	.0572
21	.0554	.0566	.0566	.0566	.0572	.0572	.0572
22	.0566	.0566	.0566	.0566	.0572	.0572	.0572
23	.0566	.0566	.0259	.0566	.0377	.0377	.056
24	.0263	.0377	.0259	.0263	.0566	.0373	.0373
Max	.0566	.0566	.0566	.0566	.0572	.0572	.0572
Min	.0259	.0373	.0259	.0255	.0191	.0373	.0332
Avg	.0498	.0508	.0502	.0475	.0472	.0501	.0492

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044214 / UNIVERSITY

Feeder No / Name : 201 / UNIVERSITY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.037	.037	.037	.037	.0185	.0187	.0187
2	.037	.0185	.037	.037	.0185	.0187	.0173
3	.037	.0185	.037	.037	.0185	.0187	.0187
4	.037	.0185	.0185	.0185	.0185	.0187	.0187
5	.037	.0185	.0185	.0185	.0185	.0187	.0187
6	.037	.0185	.0185	.0185	.0185	.0187	.0187
7	.0185	.0185	.0185	.0185	.0185	.0187	.0187
8	.037	.037	.037	.0185	.0185	.0187	.0187
9	.0554	.0185	.037	.0187	.037	.0373	.037
10	.1478	.0554	.0739	.0187	.1294	.1109	.0924
11	.1848	.0739	.1109	.0373	.1848	.1848	.1663
12	.2033	.0924	.1109	.0187	.1848	.2075	.1848
13	.2033	.1109	.1109	.0187	.2033	.2033	.1663
14	.2218	.1109	.1109	.0373	.1494	.1867	.1478
15	.2033	.1109	.1109	.0373	.168	.1848	.1848
16	.8316	.0924	.112	.0373	.2054		.1663
17	.2033	.0924	.112	.0373	.168	.1494	.168
18	.1494	.0934	.112	.056	.0934	.112	.0934
19	.0934	.056	.0747	.0373	.0747	.056	.056
20	.0747	.056	.056	.0373	.0373	.0351	.056
21	.056	.056	.0373	.0373	.0373	.0187	.0373
22	.0373	.056	.0373	.037	.0373	.0187	.0373
23	.0373	.056	.037	.037	.0373	.0187	.0373
24	.037	.037	.037	.037	.0185	.0187	.0187
Max	.8316	.1109	.112	.056	.2054	.2075	.1848
Min	.0185	.0185	.0185	.0185	.0185	.0187	.0173
Avg	.1257	.0564	.0626	.0310	.0797	.0736	.0749



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044214 / UNIVERSITY

Feeder No / Name : 202 / MAQBARA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9774	2.0513	2.0328	2.0513	1.9959	2.0165	2.0351
2	1.885	1.9404	1.9774	1.922	1.9035	2.0538	1.9092
3	1.848	1.9035	1.9035	1.8665	1.848	1.9978	2.0538
4	2.0513	2.0144	2.0144	1.9774	2.0144	2.0165	2.2032
5	2.1807	2.1068	2.0698	2.0513	2.1437	2.0538	2.2218
6	2.2916	2.2731	2.1437	2.1253	2.3101	2.2405	2.3152
7	2.6981	2.3655	2.3655	2.4579	2.3655	2.5019	2.8193
8	2.7351	2.8275	2.5133	2.5318	2.384	2.5766	3.062
9	2.8193	3.1232	2.7166	2.838		2.6139	2.7721
10	2.5503	3.0678	2.347	2.8753	2.7721	2.3655	2.5688
11	2.3285	3.0308	2.2177	2.6699	2.3655	2.1437	2.4025
12	2.2916	2.8275	1.9589	2.5393	2.0883	2.0144	2.1992
13	2.2916	2.6797	2.0698	2.3152	1.9753	2.1437	2.0328
14	2.0513	2.2361	1.9959	2.1285	2.0302	2.0144	1.922
15	1.848	1.885	1.8111	1.9044	1.9022	2.0513	1.8298
16	1.848	1.7556	1.9231	1.9418	1.9936		1.8111
17	1.9404	1.7372	2.0538	2.0538	2.1845	2.1285	2.0538
18	2.4832	2.5953	2.3525	2.3899	2.4832	2.9874	2.4272
19	3.2114	2.7073	2.9127	2.7446	3.1554	3.062	2.8753
20	3.1181	2.6699	2.7073	2.6886	2.9127	3.1367	2.838
21	2.95	2.2779	2.5766	2.4646	2.7446	2.782	2.5766
22	2.5019	2.4459	2.4086	2.384	2.6326	2.5393	2.4272
23	2.4832	2.2405	2.2731	2.2546	2.3525	2.2405	2.3339
24	2.1068	2.1992	2.1253	2.0698	2.0698	2.0911	2.2405
Max	3.2114	3.1232	2.9127	2.8753	3.1554	3.1367	3.062
Min	1.848	1.7372	1.8111	1.8665	1.848	1.9978	1.8111
Avg	2.3538	2.3734	2.2279	2.3019	2.2882	2.3379	2.3304

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044214 / UNIVERSITY

Feeder No / Name : 203 / SAI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.2054	.1867	.2054	.2054	.2241	.2241
2	.1867	.1867	.1867	.1867	.1867	.2054	.2056
3	.1867	.1867	.168	.1867	.1867	.2054	.2054
4	.2054	.2054	.1867	.1867	.1867	.2054	.2054
5	.2054	.2241	.1867	.1867	.1867	.2054	.2054
6	.2241	.1867	.2054	.2054	.1867	.2054	.2054
7	.2241	.2054	.2054	.2054	.2054	.2241	.2241
8	.2614	.2614	.2427	.2054	.2614	.2241	.2241
9	.2801	.2614	.2614	.2054	.2614	.0373	.2427
10	.3511	.2957	.3142	.2614	.3142	.3395	.3174
11	.3881	.2772	.3511	.1867	.3881	.3696	.3921
12	.3696	.2587	.3696	.2241	.3696	.3961	.4108
13	.3696	.2402	.3511	.2241	.3696	.4338	.4108
14	.3881	.2587	.3326	.1867	.3961	.4066	.3734
15	.3881	.2587	.3142	.168	.3772	.4251	.4294
16	.4066	.2587	.3361	.2054	.3961		.4668
17	.3881	.2587	.2987	.2054	.3734	.3921	.4294
18	.2801	.2614	.2987	.2054	.2614	.3734	.3921
19	.2801	.2614	.2987		.2801	.2987	.3174
20	.2614	.2614	.2427	.2241	.2614	.2614	.2987
21	.2801	.2614	.2614	.2241	.2241	.2427	.2801
22	.2241	.2427	.2427	.2241	.2614	.2427	.2801
23	.2427	.2241	.2241	.2241	.2241	.2241	.2427
24	.2054	.2054	.2241	.2054	.2054	.2427	.2241
Max	.4066	.2957	.3696	.2614	.3961	.4338	.4668
Min	.1867	.1867	.168	.168	.1867	.0373	.2054
Avg	.2827	.2395	.2621	.2062	.2737	.2776	.3003

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044214 / UNIVERSITY

Feeder No / Name : 204 / LANI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3734	.3734	.3921	.3734	.4108	.4108
2	.3734	.3361	.3361	.3734	.3547	.4108	.3734
3	.3547	.3361	.3174	.3547	.3361	.3734	.4108
4	.3734	.3734	.3547	.3921	.3547	.3734	.3734
5	.4481	.3921	.3734	.4108	.4481	.3921	.4481
6	.4854	.4108	.4108	.4294	.5228	.4108	.4481
7	.5415	.4481	.4668	.5228	.4854	.4481	.547
8	.5041	.4854	.5041	.4294	.4854	.4668	.5601
9	.4294	.4854	.4481	.4854	.4481	.4668	.4294
10	.3696	.4066	.3881	.3921	.3696	.4108	.3921
11	.3142	.3696	.3696	.3734	.3326	.3547	.2614
12	.3326	.3511	.3696	.3921	.2957	.3361	.2427
13	.3326	.3142	.3142	.3361	.3142	.3174	.2987
14	.2957	.3142	.2957	.3174	.3361	.3326	.3174
15	.3326	.3142	.3326	.3361	.3361	2.0513	.3361
16	.3326	.2957	.3361	.3174	.3547		.3547
17	.3511	.2957	.3361	.3361	.3547	.3361	.3734
18	.3361	.3734	.3547	.3921	.3547	.4108	.3734
19	.4481	.4294	.4481	.4481	.4854	.4481	.4668
20	.4668	.4481	.4668	.4481	.4668	.4294	.4854
21	.4668	.4481	.4668	.4481	.4481	.4481	.4668
22	.4481	.4294	.4668	.4481	.4854	.4668	.4668
23	.4294	.4108	.4294	.4294	.4294	.4481	.4481
24	.4108	.3921	.3734	.4108	.3921	.4108	.4294
Max	.5415	.4854	.5041	.5228	.5228	2.0513	.5601
Min	.2957	.2957	.2957	.3174	.2957	.3174	.2427
Avg	.3979	.3847	.3889	.4006	.3985	.4763	.4048

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044214 / UNIVERSITY

Feeder No / Name : 205 / 11 KV PANCHHKI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8501	.9055	.8871	.8501	.8501	.8962	.8962
2	.8316	.8871	.8501	.8131	.8316	.9335	.9335
3	.8316	.8686	.8316	.7947	.8131	.9522	.9522
4	.961	.924	.9055	.8316	.8686	1.0082	.9709
5	1.2012	1.0082	.9979	1.1273	.961	.9709	1.0456
6	1.5339	1.0349	1.1458	1.3306	1.0534	1.0586	1.1016
7	1.5893	1.1643	1.1458	1.4784	1.2012	1.2696	1.6155
8	1.3491	1.3306	1.2936	1.3121	1.386	1.3256	1.4735
9	1.307	1.3121	1.2567	1.2883	1.2752	1.2696	1.2382
10	1.2197	1.423	1.1643	1.307	2.7721	1.2323	1.2012
11	1.0349	1.386	1.0534	1.2323	1.0349	1.1203	1.1273
12	.924	1.2567	.9979	1.1016	1.0349	.8686	1.0164
13	.9795	1.1643	1.0164	1.0642	.924	.9979	.9979
14	.9055	1.0349	.961	.9149	.9055	.9055	.924
15	.8316	.8131	.8316	.8589	.8501	.8775	.8501
16	.8316	.8131	.8402	.8589	.8413		.8501
17	.924	.8871	.9522	.9896	.9522	.9896	.9896
18	1.1949	1.2136	1.1763	1.1949	1.2696	1.2696	1.307
19	1.419	1.363	1.475	1.307	1.475	1.4377	1.419
20	1.3817	1.251	1.4003	1.2883		1.4937	1.419
21	1.307	1.2136	1.2323	1.1949	1.2883	1.3443	1.2696
22	1.1763	1.1016	1.1763	1.1088	1.1763	1.2136	1.1949
23	1.0456	1.0456	1.0349	1.0349	1.1016	1.1203	1.0829
24	.924	.924	.9425	.924	.9425	.9896	1.0082
Max	1.5893	1.423	1.475	1.4784	2.7721	1.4937	1.6155
Min	.8316	.8131	.8316	.7947	.8131	.8686	.8501
Avg	1.1064	1.0969	1.0654	1.0919	1.1221	1.1106	1.1202

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044223 / 33 KV GHATI SUBSTATION

Feeder No / Name : 201 / Kohinoor

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2241	.2241	.2477	.2477	.2667	.2286
2	.2286	.2241	.2241	.2286	.2286	.2477	.2286
3	.2286	.2427	.2241	.2286	.2286	.0381	.2286
4	.2286	.2241	.2427	.2286	.2286	.0381	.2667
5	.2667	.2427	.2614	.2286	.2286	.2667	
6	.3048	.2987	.2987	.2477	.3048	.3048	.3048
7	.381	.3734	.2987	.3239	.3429	.381	.381
8	.381	.4294	.3174	.362	.381	.4191	.381
9	.362	.4108	.3361	.4001	.381	.362	.381
10	.381	.4191	.3048	.4191	.381	.381	.3429
11	.3429	.381	.3048	.381	.3429	.3429	.3429
12	.2858	.381	.2667	.3429	.3429	.3429	.3429
13	.2667	.381	.2667	.3429	.3048	.3429	.3048
14	.2477	.3429	.2667	.3048	.3048	.3048	.3048
15	.2477	.3048	.2667	.2667	.2667	.2667	.3048
16	.2858	.2667	.2667	.2667	.2667	.3048	.3048
17	.3361	.2858	.2858	.3239	.3048	.3239	.3239
18	.3174	.3048	.3239	.3429	.3048	.3239	.3429
19	.3734	.362	.362	.3429	.381	.381	.381
20	.3734	.3429	.3429	.3429	.362	.362	.362
21	.3361	.3239	.3239	.3048	.3239	.3239	.3239
22	.3429	.3048	.2858	.3048	.3048	.3048	.3048
23	.3048	.3048	.2858	.2858	.2858	.3048	.2858
24	.2477	.2667	.2667	.2477	.2477	.2477	.2667
Max	.381	.4294	.362	.4191	.381	.4191	.381
Min	.2286	.2241	.2241	.2286	.2286	.0381	.2286
Avg	.3041	.3184	.2853	.3048	.3040	.2993	.3147

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044223 / 33 KV GHATI SUBSTATION

Feeder No / Name : 202 / Ghati Medical Express  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3361	.3364	.3429	.3429	.3429	.3429
2	.3429	.3361	.3361	.3429	.3239	.3239	.3429
3	.3429	.3361	.3361	.3239	.3239	.3239	.3429
4	.3429	.3361	.3734	.3239	.3239	.3239	.3429
5	.3429	.3734	.3734	.3239	.3239	.3239	.3429
6	.3429	.3742	.3734	.3429	.3239	.3239	.381
7	.362	.3921	.4294	.3429	.3429	.4191	.4191
8	.4763	.3734	.4481	.2858	.4382	.4954	.4191
9	.5525	.3734	.4481	.3048	.5144	.4954	.4954
10	.5906	.381	.4954	.3429	.6097	.6859	.6097
11	.5906	.4191	.4954	.381	.5716	.6859	.5716
12	.6478	.4191	.5335	.4191	.4572	.6859	.6097
13	.6287	.381	.4954	.4191	.6097	.6097	.5716
14	.6097	.381	.4954	.381	.5335	.5335	.5716
15	.5716	.381	.4954	.3429	.4954	.4954	.6097
16	.6097	.381	.4954	.4191	.4954	.4954	.5716
17	.5041	.381	.4572	.381	.4763	.4763	.5335
18	.4854	.381	.4954	.381	.4954	.4382	.4763
19	.5041	.381	.4763	.381	.4572	.4191	.4572
20	.4668	.362	.4572	.381	.4572	.4001	.4191
21	.4481	.381	.4382	.381	.4572	.4191	.4001
22	.4191	.381	.4191	.381		.381	.381
23	.381	.3429	.381	.381	.362	.381	.381
24	.381	.362	.3429	.381	.3429	.381	.381
Max	.6478	.4191	.5335	.4191	.6097	.6859	.6097
Min	.3429	.3361	.3361	.2858	.3239	.3239	.3429
Avg	.4703	.3728	.4345	.3620	.4382	.4525	.4572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044019 / 33/11 KV RAILWAY STATION

Feeder No / Name : 201 / 11 KV MIDC (SANJAWARTHA) SHEDDABLE FEEDER HAVING WEEKLY  
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1715	.1905	.1905	.1905	.2096
2	.1905	.1905	.1905	.1715	.1715	.1905	.2096
3	.1905	.1715	.1905	.1715	.1715	.1715	.1905
4	.2096	.1715	.1905	.1715	.1715	.1715	.1905
5	.2096	.1715	.1715	.1905	.1905	.1905	.2096
6	.2096	.1905	.1715	.1905	.1905	.2096	.2096
7	.2096	.2096	.1715	.1715	.1905	.1905	.2096
8	.2667	.1905	.2096	.1715	.2096	.2096	.2477
9	.3239	.2096	.362	.2858	.362	.3429	.3048
10	.4763	.1905	.4572	.2286	.4954	.5335	.547
11	.6478	.3429	.5716	.4001	.6478	.6668	.7167
12	.6859	.381	.5335	.381	.7049	.7049	.7545
13	.6478	.3239	.5525	.381	.6478	.6668	.679
14	.743	.381	.6287	.4191	.6859	.7621	.7545
15	.743	.362	.6478	.4001	.724	.743	.7545
16	.7049	.3429	.6097	.3239	.6859	.743	.7922
17	.6097		.5144	.2858	.5281	.6602	.6668
18	.381	.2286	.362	.2667	.415	.3584	.4382
19	.3429	.2096	.3048	.2286	.3018	.3018	.3429
20	.2477	.2096	.2667	.2286	.2452	.2641	.3239
21	.2286	.2096	.2286	.1905	.2452	.2452	.3048
22	.2477	.2096	.2096	.2286	.2452	.2452	.2667
23	.1905	.1715	.1905	.1905	.2096	.2477	.2858
24	.2096	.1905	.1715	.1905	.1905	.2096	.2286
Max	.743	.381	.6478	.4191	.724	.7621	.7922
Min	.1905	.1715	.1715	.1715	.1715	.1715	.1905
Avg	.3795	.2369	.3366	.2524	.3675	.3841	.4099

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044019 / 33/11 KV RAILWAY STATION

Feeder No / Name : 202 / 11 KV I.T.I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.191	2.0386	2.2291	2.2291	2.21	2.2481	2.0576
2	2.2481	2.0767	2.2672	2.2672	2.21	2.2672	2.0767
3	2.3053	2.1148	2.3053	2.3053	2.2862	2.3243	2.0576
4	2.4006	2.191	2.3434	2.3434	2.3243	2.4577	2.0005
5	2.5149	2.3434	2.4196	2.3815	2.3624	2.4958	2.0576
6	2.8769	2.6673	2.8578	2.6482	2.6673	2.8769	2.934
7	3.3532	2.9721	3.2769	2.934	3.2007	3.1817	3.0864
8	3.2769	3.3341	3.4865	3.1436	3.2579	2.934	3.2769
9	3.0864	3.2198	3.5246	3.2579	3.3532	2.7816	3.1245
10	2.9531	3.2388	3.0483	3.4294	2.8959	2.7244	2.7726
11	2.7435	3.0864	2.8769	2.8769	2.7054	2.5339	2.6029
12	2.4958	2.4577	2.6673	2.7054	2.4768	2.6292	2.5274
13	2.3815	2.21	2.2481	2.4768		2.4577	2.2634
14	2.2481	2.21	2.2481	2.3624	2.553	2.4196	2.3011
15	2.1338	2.0957	2.0386	2.1529	2.0957	2.3243	2.2634
16	2.4577	2.191	2.1719	2.21	2.4387	2.3434	2.4331
17	2.4768		2.7816	2.3434	2.4331	2.9235	2.6673
18	3.0483	2.915	2.7625	2.8578	2.8481	3.131	3.0483
19	3.5246	3.2388	3.2388	3.2388	3.1876	3.5648	3.5246
20	3.5818	3.2769	3.0483	3.0864	3.3008	3.5082	3.5818
21	2.934	2.915	2.0005	2.8578	3.0367	3.0744	2.8959
22	2.8197	2.5149	2.7054	2.4768	2.584	3.0367	2.8578
23	2.4768	2.4768	2.5911	2.5339	2.6482	2.8197	2.4387
24	2.1529	2.0957	2.191	2.191	2.1719	2.2481	2.2481
Max	3.5818	3.3341	3.5246	3.4294	3.3532	3.5648	3.5818
Min	2.1338	2.0386	2.0005	2.1529	2.0957	2.2481	2.0005
Avg	2.6951	2.6035	2.6387	2.6379	2.6630	2.7211	2.6291



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044019 / 33/11 KV RAILWAY STATION

Feeder No / Name : 203 / 11 KV KAMAL NAYAN BAJAJ SHEDDABLE FEEDER HAVING WEEKLY  
 EXPR Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.362	.362	.381	.4191	.3429	.381
2	.3239	.362	.381	.3429	.381	.3239	.381
3	.3239	.3429	.381	.3429	.381	.3429	.362
4	.3429	.3429	.4001	.3239	.362	.3429	.3429
5	.3429	.3239	.4001	.3239	.362	.3239	.3048
6	.362	.362	.381	.3048	.381	.3429	.3048
7	.362	.381	.4001	.3048	.4001	.4001	.362
8	.362	.4001	.381	.381	.4001	.4001	.4001
9	.3239	.5906	.4382	.3429	.4572	.4191	.4382
10	.381	.6478	.4001	.3048	.4572	.381	.3395
11	.3239	.8002	.381	.362	.4572	.4191	.415
12	.4382	.4382	.3429	.2667	.4572	.4001	.3584
13	.2667	.3048	.3239	.2286	.381	.3239	.3584
14	.362	.4954	.3048	.362	.4191	.4001	.3584
15	.4191	.4763	.362	.381	.4572	.4572	.4527
16	.4572	.5335	.4382	.4001	.5144	.4763	.4527
17	.5335	.5335	.4954	.2286	.547	.5847	.5335
18	.5716	.5144	.4572	.381	.4904	.4904	.5335
19	.5335	.4763	.4382	.3429	.3961		.4382
20	.4382	.4763	.4572	.4191	.4338	.4338	.4382
21	.4191	.4191	.4572	.4001	.4527	.4338	.4001
22	.4572	.4572	.4382	.4191	.4904	.415	.4382
23	.4001	.4572	.4191	.4191	.4382	.4382	.4382
24	.3429	.381	.362	.381	.4191	.4191	.4001
Max	.5716	.8002	.4954	.4191	.547	.5847	.5335
Min	.2667	.3048	.3048	.2286	.362	.3239	.3048
Avg	.3929	.4533	.4001	.3477	.4314	.4048	.4013

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044019 / 33/11 KV RAILWAY STATION

Feeder No / Name : 204 / 11 KV GOLWADI SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2574	1.2193	1.3336	1.3336	1.2955	1.3336	1.3527
2	1.3146	1.2574	1.3908	1.3717	1.2955	1.3336	1.3336
3	1.3146	1.2955	1.4289	1.4098	1.3336	1.3527	1.2955
4	1.3336	1.3336	1.467	1.4098	1.3717	1.3717	1.2574
5	1.3336	1.3717	1.467	1.4289	1.3717	1.3717	1.2955
6	1.3527	1.4098	1.5051	1.3908	1.4098	1.4098	1.448
7	1.6194	1.5813	1.5432	1.467	1.5813	1.6385	1.6004
8	1.6575	1.5623	1.6194	1.6385	1.5623	1.6385	1.7528
9	1.4098	1.6004	1.448	1.6385	1.467	1.5813	1.6575
10	1.3908	1.5623	1.4289	1.6575	1.4289	1.2003	1.5278
11	1.3146	1.5813	1.4098	1.5051	1.3717	1.4861	1.3957
12	1.3717	1.5623	1.3717	1.3717	1.3336	1.4098	1.3769
13	1.3146	1.3527	1.3146	1.2955	1.2003	1.4289	1.3392
14	1.2003	1.3908	1.2193	1.2574	1.1431	1.3527	1.226
15	1.2765	1.2765	1.0669	1.2003	1.4098	1.2955	1.3392
16	1.2955	1.2193	1.1431	1.6004	1.3717	1.3527	1.3769
17	1.3908		1.4098	1.3336	1.4523	1.4146	1.467
18	1.4098	1.3336	1.3717	1.3908	1.3769	1.3203	1.4861
19	1.5623	1.448	1.467		1.5844	1.5278	1.5242
20	1.5242	1.4861	1.448	1.448	1.5089	1.4901	1.5623
21	1.448	1.4289	1.4098	1.3336	1.4523	1.4712	1.5242
22	1.4098	1.4289	1.3717	1.2955	1.4901	1.4712	1.4861
23	1.3908	1.3146	1.3336	1.3527	1.467	1.5242	1.4861
24	1.2193	1.3336	1.2955	1.3146	1.2574	1.3717	1.4289
Max	1.6575	1.6004	1.6194	1.6575	1.5844	1.6385	1.7528
Min	1.2003	1.2193	1.0669	1.2003	1.1431	1.2003	1.226
Avg	1.3797	1.4065	1.3860	1.4107	1.3974	1.4229	1.4392

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044019 / 33/11 KV RAILWAY STATION

Feeder No / Name : 206 / 11 KV RAHUL NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2672	2.2291	2.2481	2.4768	2.2672	2.4006	2.2481
2	2.3053	2.2672	2.2862	2.5339	2.3053	2.4768	2.191
3	2.4196	2.3053	2.3434	2.572	2.3434	2.5149	2.1338
4	2.4958	2.3815	2.4006	2.6101	2.3815	2.5911	2.1338
5	2.6482	2.4196	2.4387	2.6482	2.4768	2.6673	2.4387
6	3.0102	2.8578	2.9531	2.8578	2.8578	3.0864	3.1436
7	3.9247	3.6961	3.3913	3.4484	3.6961	3.658	3.8104
8	3.8676	4.1343	3.677	3.8104	3.658	3.8866	3.9057
9	3.6389	4.2105	3.4294	3.9057	3.6008	3.658	3.6199
10	3.1245	4.1152	3.1436	3.8104		3.2198	3.2253
11	2.7244	4.0009	2.8578	3.3722		2.8197	2.9613
12	2.6863	3.4103	2.6673	3.0864		2.6863	2.7349
13	2.4768	2.915	2.5149	2.8578		2.5339	2.3388
14	2.3053	2.3624	2.1338	2.4958	2.7625	2.2672	2.2634
15	2.2481	2.1338	2.0386	2.4006	2.4196	2.1529	2.2634
16	2.1338	2.0005		2.4387	2.2862	2.21	2.3011
17	2.4768		2.1338	2.6673	2.4709	2.5086	2.553
18	3.0483	2.934	2.5911	3.2007	3.3008	3.0744	3.1436
19	3.6199	3.3341	3.0102	3.5818	3.6591	3.7346	3.6199
20	3.5246	3.2388	3.0102	3.2769	3.3951	3.4894	3.5437
21	3.0483	2.7816	2.5149	2.8959	2.9047	2.9047	2.9721
22	2.6673	2.6673	2.8578	2.7816	2.7726	2.7915	2.8006
23	2.553	2.4387	2.572	2.5911	2.6673	2.6292	2.6101
24	2.2291		2.21	2.4196	2.2672	2.3624	2.3815
Max	3.9247	4.2105	3.677	3.9057	3.6961	3.8866	3.9057
Min	2.1338	2.0005	2.0386	2.4006	2.2672	2.1529	2.1338
Avg	2.8102	2.947	2.6706	2.9475	2.8246	2.8468	2.8057

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044019 / 33/11 KV RAILWAY STATION

Feeder No / Name : 207 / 11 KV M.I.T. EXPRESS SHEDDABLE FEEDER HAVING WEEKLY  
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.0953	.1143	.0953	.0953	.0953	.0953
2	.0953	.0953	.0953	.0953	.0762	.0953	.0953
3	.0953	.1143	.0953	.1143	.0762	.1143	.0953
4	.1143	.1143	.1143	.1143	.0953	.0953	.1143
5	.1143	.0953	.1143	.0953	.0953	.0953	.0953
6	.0953	.0953	.1143	.0953	.1143	.1143	.0953
7	.0953	.1143	.0953	.0953	.0953	.1143	.1143
8	.0953	.0953	.0953	.1334	.1143	.0762	.1334
9	.1143	.0953	.0572	.1143	.0953	.0572	.1143
10	.1143	.1143	.1905	.0953	.0953	.2096	.0754
11	.1715	.0762	.2286		.1143	.2286	.1132
12	.1334	.0381	.1905	.0762	.1143	.2286	
13	.1524	.0953	.1905	.0762	.0953	.2477	.0566
14	.1905	.0953	.2096	.0953	.1334	.2667	.0943
15	.1524	.0953	.1905	.0762	.1524	.2286	.0943
16	.1524	.2286	.2096	.0762	.1715	.2286	.1509
17	.1905		.2286	.1143		.1886	.2096
18	.1524	.1524	.1143	.1143	.1132	.1132	.1524
19	.1334	.1334	.1334	.1334	.132	.1132	.1524
20	.1334	.1334	.1334	.1143	.1132	.1132	.1524
21	.1143	.1143	.1143	.0953	.1132	.1132	.1143
22	.1143	.1143	.1143	.0953	.0943	.0943	.1143
23	.0953	.1143	.0953	.0953	.1143	.1334	
24	.1143	.0953	.1143	.0953	.0953	.0953	.1143
Max	.1905	.2286	.2286	.1334	.1715	.2667	.2096
Min	.0953	.0381	.0572	.0762	.0762	.0572	.0566
Avg	.1270	.1094	.1397	.1002	.1091	.1442	.1158

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044019 / 33/11 KV RAILWAY STATION

Feeder No / Name : 208 / 11kv MIDC(NIRLAP)

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.5144	.5525	.5525	.381	.5716	.5335
2	.4572	.5335	.5335	.5335	.362	.5525	.4954
3	.4572	.5716	.5335	.5335	.362	.5144	.4763
4	.4763	.5716	.4954	.5144	.381	.5144	.5335
5	.4763	.5906	.4763	.5144	.381	.5335	.5716
6	.4954	.5716	.4763	.5335	.4001	.5335	.5716
7	.5716	.6097	.4954	.5716	.4572	.5906	.5335
8	.6287	.743	.743	.743	.5906	.8002	.6097
9	.8192	.8573	.7811	.7049	.5906	.8954	.8002
10	.8954	.9145	1.0288	.7621	.8573	.7621	1.2637
11	.6668	1.2193	1.105	.8192	.8764	1.2384	1.226
12	.8002	1.0479	1.0288	.7621	.9145	1.1241	1.0751
13	.8002	1.1431	.9526	.6668	.9526	1.105	1.1128
14	.8954	1.0098	.9526	.724	.8383	.9526	1.0751
15	.9907	.9335	.9717	.7811	.9526	1.1812	1.2826
16	.8192	.7621	1.0669	.6859	1.0288	1.0288	1.1317
17	.8383		.8764	.7049	1.1128	1.0562	1.0669
18	.7049	.8002	.9526	.724	1.0562	1.0374	1.0479
19	.8002	.8764	.9526	.6478	.9054	.7733	.9526
20	.8573	.7621	.8002	.6287	.8865	.7733	.9526
21	.7049	.6097	.6668	.5716	.7922	.7922	.9145
22	.6668	.5716	.8192	.5144	.7167	.6979	.7621
23	.5906	.5906	.6097	.5144	.6668	.6478	
24	.4954	.5525	.5525	.5525	.381	.6097	.5335
Max	.9907	1.2193	1.105	.8192	1.1128	1.2384	1.2826
Min	.4572	.5144	.4763	.5144	.362	.5144	.4763
Avg	.6827	.7546	.7676	.6359	.7018	.8036	.8488

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044038 / 33/11 KV CHAWANI

Feeder No / Name : 201 / 11 KV HOLYCROSS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3899	2.3339	2.3339	2.4646	2.3152	2.5579	2.4764
2	2.2177	2.2405	2.5206	2.3339	2.2177	2.4025	2.4272
3	2.2731	2.2405	2.4272	2.3339	2.2177	2.4272	2.4272
4	2.4949	2.2177	2.4272	2.3339	2.1948	2.4272	.1867
5	2.6797	2.6797	2.5206	2.3339	2.4949	2.5206	2.5206
6	3.0178	2.7073	3.0247	2.6139	2.9874	2.894	2.9874
7	3.4189	3.3608	3.1927	2.9874	3.4355	3.4355	3.3981
8	3.3608	3.3608	3.3608	3.2114	3.6035	3.5475	3.4355
9	3.3608	3.5101	3.3608	3.3048	3.3981	3.6408	3.4865
10	3.062	3.4168	3.0994	3.1741	3.3981	3.5475	3.5056
11	3.1047	3.2674	3.1181	2.95	3.1741	3.6969	3.1927
12	2.8275	2.95	2.9874	2.6699	3.1741	3.1367	3.1367
13	2.7721	2.8006	2.6886	2.5766	3.062	2.9127	3.0247
14	2.5873	2.6242	2.5766	2.3525	3.0247	2.9687	2.8006
15	2.726	2.5206	2.4272	2.3712	2.9313	2.9874	3.4541
16	2.8567	2.5393	2.3525	2.2965	2.9264	2.95	2.95
17	2.8567	2.5503	2.4764	2.3899	2.9569	2.8829	2.9199
18	2.9384	2.6139	2.5688	2.894	2.9384	2.9014	3.1417
19	3.1786	3.1417	3.095	3.1554	3.3131	3.2895	3.3634
20		3.1367	3.0994	3.0247	3.4004	3.2526	3.271
21	2.9754	2.846	3.0678	2.9199	3.1786	3.1047	3.1417
22	2.8645	2.7166	2.7721	2.8645	2.9569	3.0045	3.0493
23	2.6797	2.6612	2.7166	2.6797	2.894	2.9754	2.8829
24	2.5393	2.4086	2.4832	2.6057	2.5133	2.6326	2.6612
Max	3.4189	3.5101	3.3608	3.3048	3.6035	3.6969	3.5056
Min	2.2177	2.2177	2.3339	2.2965	2.1948	2.4025	.1867
Avg	2.8340	2.7852	2.7791	2.7018	2.9461	3.0040	2.9100

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044038 / 33/11 KV CHAWANI

Feeder No / Name : 202 / 11 KV CANTONMENT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2197	1.2752	1.2567	1.2883	1.307	1.3121	1.3121
2	1.1643	1.2012	1.1888	1.2936	1.2803	1.2936	1.307
3	1.2012	1.2382	1.2136	1.2696	1.1888	1.2936	1.307
4	1.251	1.2071	1.1888	1.2136	1.1888	.823	1.2136
5	1.2936	1.2803	1.307	1.2136	1.1888	1.2567	1.2136
6	1.386	1.4003	1.5123	1.307	1.587	1.4003	1.4003
7	1.6448	1.6804	1.6804	1.5684	1.8671	1.7737	1.7737
8	1.7187	1.7741	1.7364	1.6804	1.7737	1.7737	1.8111
9	1.6804	1.7364	1.7551	1.8671	1.7924	1.6804	1.6804
10	1.4937	1.6804	1.531	1.7737	1.5123	1.6057	1.4937
11	1.3306	1.643	1.5497	1.7177	1.307	1.5497	1.39
12	1.307	1.643	1.4415	1.587	1.419	1.419	1.3817
13	1.2936	1.5154	1.2936	1.4784	1.3491	1.4937	1.307
14	1.2197	1.423	1.2936	1.3491	1.3491	1.3256	1.307
15	1.1827	1.3491	1.2567	1.307	1.2936	1.2883	1.3256
16	1.2197	1.2567	1.1827	1.2567	1.2936	1.251	1.2323
17	1.2197	1.3491	1.2936	1.1088	1.386	1.3306	1.307
18	1.2936	1.7177	1.4045	1.4784	1.5524	1.423	1.4784
19	1.6991	1.9044	1.8296	1.6817	1.8296	1.7926	1.7926
20	1.7741	1.8107	1.8484	1.7924	1.848	1.8298	1.8671
21	1.7194	1.7556	1.7187	1.7372	1.7926	1.7926	1.7375
22	1.7372	1.6448	1.6448	1.6632	1.7177	1.7372	1.6632
23	1.5524	1.5339	1.4415	1.5524	1.5497	1.5893	1.6263
24	1.3443	1.3352	1.363	1.3817	1.423	1.3717	1.46
Max	1.7741	1.9044	1.8484	1.8671	1.8671	1.8298	1.8671
Min	1.1643	1.2012	1.1827	1.1088	1.1888	.823	1.2136
Avg	1.4144	1.5148	1.4555	1.4820	1.4915	1.4753	1.4745

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044038 / 33/11 KV CHAWANI

Feeder No / Name : 203 / 11 KV M.E.S. EXPRESS

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2507	.2801	.2753	.3734	.3174	.3772	.3086
2	.2614	.2572	.1943	.3734	.2743	.3239	.2572
3	.2481	.2458	.1943	.3239	.2572	.3239	.2572
4	.2896	.2458	.1943	.3734	.2572	.3239	.2572
5	.3326	.2785	.3429	.3429	.4287	.3429	.2743
6	.4024	.4801	.426	.3772	.5144	.3429	.4287
7	.4706	.5373	.4801	.4287	.5144	.5373	.5487
8	.3982	.5175	.4668	.4287	.4572	.5014	.5228
9	.4298	.4706	.4298	.439	.4344	.4755	.4755
10	.394	.5487	.439	.4755	.3734	.4108	.2195
11	.4298	.4755	.439	.3658	.4805	.3658	.2614
12	.439	.4344	.3326	.4024	.3658	.2614	.2926
13	.439	.2865	.3326	.2561	.3224	.2614	
14	.2865	.2835	.2865	.2561	.2926	.2614	.2987
15	.2507	.2481	.2561	.2195	.2561	.2241	.2561
16	.2507	.2347	.2454	.2218	.2507	.2614	.2561
17	.2896	.3582	.2835	.2481	.3582	.3292	.394
18	.3155	.3658	.3582	.362	.394	.3658	.3856
19	.4805	.4607	.4607	.4656	.5373	.5068	
20	.4961	.4344	.4656	.4805	.4706	.4961	.5316
21	.4066	.4066	.3582	.4207	.394	.4344	.4557
22	.362	.3224	.3326	.4066	.3326	.362	.3506
23	.2926	.3189	.2835	.2896	.2987	.3189	.2804
24	.2772	.3086	.2896	.2804	.2507	.4287	.3258
Max	.4961	.5487	.4801	.4805	.5373	.5373	.5487
Min	.2481	.2347	.1943	.2195	.2507	.2241	.2195
Avg	.3539	.3667	.3403	.3588	.3680	.3682	.3472



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044038 / 33/11 KV CHAWANI

Feeder No / Name : 204 / MILIND COLLEGE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7964	.9335	.8131	.8215	.924	.924	.8871
2	.7392	.9335	.7682	.7842	.9335	.8779	.8316
3	.724	.9145	.7762	.7468	.823	.8596	.8316
4	.7602	.9145	.7682	.7468	.823	.823	.8501
5	.823	.924	.823	.7468	.823	.823	.9055
6	.9511	.961	1.0534	.8402	1.0642	.924	1.0269
7	1.1462	1.0456	1.2883	1.0082	1.363	1.0829	1.2323
8	1.1706	1.1273	1.2136	1.1203	1.2136	1.2136	1.2136
9	1.1203	1.1949	1.1203	1.1203	1.1203	1.1203	1.0456
10	1.0456	1.1203	.961	1.1949	.9709	1.0829	1.0082
11		1.1203	.961	1.1203	.8962	1.0456	.9709
12	.8962	1.1088	.8871	1.0456	.8871	.8962	.8589
13	.8871	1.0349	1.0349	.9795	.8131	1.0082	.8215
14	.8048	.8131	.961	.961	.8131	1.0456	.8215
15	.8131	.8131	.8871	.8215	.8048	.8962	.7468
16	.7392	.8131	.961	.6722	.7964	.8962	.7468
17	.8688	.8215	.9313	.7164	.788	.788	.8962
18	.961	.905	1.0136	.7964	.9145		.961
19	1.1827	1.086	1.0029	1.1462	1.134	1.1462	1.1827
20	1.2696	1.0631	1.086	1.1462	1.1827	1.1584	1.2567
21	1.1827	1.0349	1.086	1.1104	1.086	1.086	1.0974
22	1.086	1.0029	1.0029	1.0136	1.0719	1.0136	1.0349
23	1.0136	.9412	.9313	1.0349	1.0349	.961	1.0349
24	.924	.924	.8871	.8596	.8688	.924	.8505
Max	1.2696	1.1949	1.2883	1.1949	1.363	1.2136	1.2567
Min	.724	.8131	.7682	.6722	.788	.788	.7468
Avg	.9524	.9813	.9674	.9397	.9646	.9825	.9631

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044219 / 33/11 KV SATARA S/S

Feeder No / Name : 201 / 11 kV Dishanagari Feeder SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2826	1.3957	1.5089	1.5466	1.531	1.6057	
2	1.2826	1.3957	1.5089	1.5089	1.4937	1.6057	
3	1.2826	1.3957	1.5089	1.5089	1.4937	1.6057	
4	1.4712	1.5089	1.5844	1.5844	1.6057	1.6804	
5	1.6598	1.6975	1.6975	1.6975	1.6804	1.7737	
6	2.0748	1.8484	2.0748	1.8861	2.0538	2.0538	
7	1.8861	2.2257	2.1879	2.0748	2.2405		
8	2.1879	2.3011	2.2779	2.1658	2.0538	2.2405	2.2032
9	2.0165	2.0165	2.1285	2.2405	1.9044	1.8671	2.0165
10	1.7177	1.9044	1.7924	2.0538	1.6804	1.6804	1.6804
11	1.4563	1.6804	1.7177	1.848	1.4937	1.6804	1.5893
12	1.419	1.4937	1.531	1.6632	1.4045	1.5893	1.4045
13	1.2696	1.419	1.307	1.5154	1.3817	1.4784	1.3306
14	1.1949	1.307	1.2323	1.4045	1.3306	1.4045	1.3306
15	1.2696	1.2696	1.307	1.4415	1.4045	1.4045	1.4045
16	1.4563	1.419	1.419	1.4784	1.4415	1.4045	1.4415
17	1.5684	1.3169	1.4632	1.5154	1.4784	1.4998	1.5154
18	1.6095	1.5364	1.6461	1.6827	1.5524	1.6632	1.848
19		1.848	2.0698	2.0328	2.0328	2.0538	2.0328
20		1.9418	2.0538	1.9791	2.0538	2.0165	1.885
21	2.3285	1.8671	1.9791	1.8298	1.9791	2.0165	1.7741
22	2.1068	1.7924	1.9044	1.6804	1.9044	1.9418	2.0698
23	1.7551	1.6804	1.7177	1.531	1.7551	1.8298	1.7924
24	1.4563	1.5684	1.6057	1.6057	1.531	1.643	1.7177
Max	2.3285	2.3011	2.2779	2.2405	2.2405	2.2405	2.2032
Min	1.1949	1.2696	1.2323	1.4045	1.3306	1.4045	1.3306
Avg	1.6251	1.6596	1.7177	1.7281	1.6867	1.7278	1.7080

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044219 / 33/11 KV SATARA S/S

Feeder No / Name : 202 / 11 kV Deolai Chowk Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3203	1.4712	1.6221	1.5844	1.5684	1.7177	
2	1.3203	1.4712	1.5089	1.5844	1.5684	1.7177	
3	1.3203	1.4712	1.5089	1.5844	1.5684	1.7177	
4	1.4712	1.5466	1.5844	1.6221	1.6057	1.8298	
5	1.8484	1.773	1.6975	1.6975	1.6804	1.9044	
6	1.9993	1.8861	1.8484	1.8107	1.7924	1.9418	
7	2.1879	1.9993	1.9993	1.8861	1.9418		
8	2.1125	1.9239	1.9418	1.9418	1.8671	1.9044	2.0538
9	1.7551	1.9044	1.8298	1.8671	1.7551	1.7924	
10	1.7551	1.8671	1.6975	1.7551	1.531	1.6804	
11	1.5684	1.8671	1.6804	1.6632	1.531	1.6057	1.5154
12	1.419	1.5684	1.4563	1.5893	1.4784	1.4784	1.4784
13	1.3817	1.419	1.419	1.5154	1.4784	1.4784	1.4784
14	1.3443	1.419	1.3443	1.4415	1.4784	1.4784	1.4784
15	1.4937	1.4937	1.4937	1.4045	1.4415	1.4784	1.5154
16	1.4937	1.3817	1.4937	1.4045	1.4415	1.5154	1.5154
17	1.5524	1.4998	1.3535	1.5154	1.5154	1.5364	1.5524
18	1.5524	1.5364	1.5524	1.6632	1.4784	1.6263	1.6263
19		1.848	1.922	1.922	2.0328	2.0538	2.0328
20		1.9791	1.9791	1.9044	1.9044	2.1658	1.9589
21	2.2314	1.8671	1.8671	1.9418	2.1285	2.0538	1.922
22	2.1807	1.7924	1.7551	1.8671	2.0538	2.0538	2.0328
23	2.0165	1.7177	1.7177	1.6804	1.9418	1.9791	1.9418
24	1.5684	1.6804	1.6804	1.643	1.5684	1.7924	1.7924
Max	2.2314	1.9993	1.9993	1.9418	2.1285	2.1658	2.0538
Min	1.3203	1.3817	1.3443	1.4045	1.4415	1.4784	1.4784
Avg	1.6770	1.6827	1.6647	1.6871	1.6813	1.7610	1.7263

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044219 / 33/11 KV SATARA S/S

Feeder No / Name : 203 / 11 kV Sara Siddhi Feeder SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5089	1.6975	1.773	1.8861	1.8671	1.9605	
2	1.5089	1.6975	1.773	1.773	1.7551	1.8298	
3	1.5089	1.6975	1.773	1.773	1.7551	1.8298	
4	1.5089	1.8107	1.8484	1.8484	1.8298	2.0538	
5	2.0748	2.0748	2.1125	2.1125	2.1658	2.2405	
6	2.4143	2.4143	2.4897	2.4897	2.4646	2.3152	
7	3.0933	2.8669	2.8669	2.6406	2.6139	2.4272	
8	2.7915	2.8669	2.8669	2.6886	2.4272	2.7633	
9	2.3152	2.6139	2.3152	2.6139	2.2405	2.2405	
10	1.9418	1.8671	2.1658	2.6139	1.8671	1.8671	1.4937
11	1.643	2.2405	1.9418	2.4394	1.7177	1.9418	1.4784
12	1.7177	1.9418	1.7924	1.9959	1.6263	1.7002	1.4784
13	1.643	1.8671	1.4937	1.922	1.6632	1.6632	1.4045
14	1.7177	1.6057	1.6804	1.848	1.7002	1.6263	1.4045
15	1.7551	1.7177	1.7177	1.7558		1.6263	1.4784
16	1.643	1.6804	1.643	1.6827	1.7002	1.6263	1.922
17	1.848	1.8099	1.7558	1.6827	1.6827	1.7558	2.0698
18	1.9022	1.8099	1.9547	2.0485	1.9753	2.0485	2.2177
19		2.4394	2.4394	2.5133	2.5133	2.5873	2.6612
20		2.5393	2.6139	2.4646	2.6139	2.6886	2.6981
21	2.2177	2.3899	2.3899	2.3899	2.6139	2.6139	2.5873
22	2.809	2.2405	2.1658	2.0911	2.4646	2.6139	2.5133
23	2.2779	2.0911		1.9418	2.3152	2.4646	2.3152
24	1.9418	2.0911	2.0165	1.9418	1.8671	2.0911	2.1658
Max	3.0933	2.8669	2.8669	2.6886	2.6139	2.7633	2.6981
Min	1.5089	1.6057	1.4937	1.6827	1.6263	1.6263	1.4045
Avg	1.9901	2.0863	2.0691	2.1316	2.0626	2.1073	1.9926

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044221 / 33/11KV WALMI SS

Feeder No / Name : 201 / 11 KV AMC EXPRESS

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4668	.4904	.5601	.5601	.5487	.5415	.5729
2	.4481	.4715	.5601	.5601	.567	.5415	.5853
3	.4481	.4527	.5601	.5415	.5544	.5601	.5914
4	.4108	.3772	.5601	.5601	.5304	.5601	.5729
5	.3734	.3584	.5415	.5788	.5544	.5601	.5729
6	.3547	.415	.5415	.5788	.5601	.5601	.5544
7	.5601	.5658	.5415	.5601	.5788	.5601	.5788
8	.5228	.5658	.5601	.5601	.5601	.5544	.5544
9	.3361	.3961	.5914	.5975	.5788	.5544	.5544
10	.5487	.5544	.5658	.5487	.3921	.567	.5788
11	.567	.5729	.6036	.5611	.5601	.5792	.5788
12	.5792	.5914	.3961	.591	.5914	.5914	.5788
13	.5194	.5544	.5847	.5373	.5487	.567	.5487
14	.5373	.5544	.6036	.5611	.5487	.5611	.5914
15	.3544	.5544	.5658	.5973	.567	.5792	.5544
16	.5552	.5729	.5658	.567	.5487	.5731	.5729
17	.5792	.5729	.5847	.5121	.5487	.5792	.5729
18	.5611	.5914	.5788	.567	.5729	.5373	.6036
19	.5601	.5601	.5788	.5853	.5853	.5729	.5847
20	.5847	.5601	.5788	.5544	.5729	.5544	.6036
21	.3961	.6036	.5788	.4435	.5544	.5544	.5847
22	.5847	.5415	.5601	.4207	.5544	.5544	.5788
23	.5847	.5601	.5601	.5487	.5544	.5544	.5729
24	.5601	.5281	.5544	.5601	.5544	.5601	.5729
Max	.5847	.6036	.6036	.5975	.5914	.5914	.6036
Min	.3361	.3584	.3961	.4207	.3921	.5373	.5487
Avg	.4997	.5236	.5615	.5522	.5536	.5616	.5756

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044221 / 33/11KV WALMI SS

Feeder No / Name : 202 / IRB

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1509	.1646	.1494	.1629	.1494	.181
2	.1494	.1509	.1646	.1494	.1629	.1494	.1629
3	.1494	.1509	.1646	.1494	.1646	.1494	.1646
4	.1494	.1509	.1646	.1494	.1829	.1494	.1663
5	.1494	.1886	.1829	.1509	.2218	.1494	.1848
6		.2263	.2195	.1509	.2263	.168	.2218
7	.2241	.2829	.2195	.1494	.2218	.1867	.2218
8	.2241	.2641	.2126	.1494	.1991	.2241	.2254
9	.2241	.2829	.1886	.168	.208	.2241	.2427
10	.208	.1989	.2075	.1791	.2241	.2507	.2614
11	.2058	.2279	.2263	.1823	.2587	.2303	.2614
12	.2058	.2321	.3018	.1492	.2587	.2629	.2587
13	.2058	.2374	.2452	.1341	.2195	.2572	.2587
14	.208	.2229	.2452	.1677	.2195	.2629	.2561
15	.208	.2204	.2452	.1865	.2172	.2534	.2926
16	.2347	.218	.3018	.2321	.2561	.2401	.2926
17	.2454	.2515	.3772	.2321	.2926	.2374	.2587
18	.2715	.218	.2987	.2204	.2195	.2267	.2452
19	.2614	.2452	.2241	.2507	.2195	.2279	.2452
20	.2263	.1991	.1867	.2195	.2195	.181	.2263
21	.2263	.1829	.1867	.2195	.2218	.2012	.2263
22	.2075	.1629	.1867	.2012	.1848	.2012	.2054
23	.1886	.1463	.1494	.1829	.1848	.181	.1848
24	.1494	.1886	.1646	.1494	.181	.1494	.181
Max	.2715	.2829	.3772	.2507	.2926	.2629	.2926
Min	.1494	.1463	.1494	.1341	.1629	.1494	.1629
Avg	.2031	.2084	.2179	.1780	.2137	.2047	.2261

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044221 / 33/11KV WALMI SS

Feeder No / Name : 203 / Nathvalley

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.4146	1.3817	1.4377	1.4632	1.4937	1.4998
2		1.358	1.3443	1.4003	1.4266	1.4563	1.4632
3	1.3817	1.358	1.363	1.3443	1.3535	1.4003	1.4045
4		1.4146	1.4003	1.3443	1.4784	1.4937	1.4045
5		1.5466	1.4377	1.4146	1.5893	1.643	1.5893
6		1.9805	1.7556	1.4937	1.8671	2.0911	1.8671
7	1.9605	2.2634	2.0698	1.8671	2.1125	1.9605	1.9418
8	1.8484	2.2634		2.0165	1.9791	1.8671	1.848
9	1.5684	2.037	1.829	1.8671	1.848		1.6651
10	1.5524	1.7375	1.7353	1.7002	1.6057	1.4632	1.5684
11	1.5524	1.5203	1.5089	1.7002	1.4969	1.3756	1.4415
12	1.2803	1.4661	1.5466	1.5364	1.3169	1.3032	1.2567
13	1.2437	1.3253	1.3769	1.5364	1.2986	1.262	1.0974
14	1.182	1.3392	1.4335	1.3756	1.3169	1.2894	1.0242
15	1.2308	1.2715	1.3203	1.2894	1.0974	1.2178	1.0974
16	1.267	1.2536	1.358	1.2894	1.2071	1.2536	1.3306
17	1.3756	1.3253	1.5278	1.576	1.39	1.3253	1.4784
18	1.448	1.3969	1.419	1.6476	1.4784	1.4685	1.6598
19	1.8671	1.7924	1.7177	1.7002	1.6827	1.7002	1.8107
20	1.905	1.8107	1.7924	1.6263	1.7741	1.885	1.8861
21	1.8107	1.701	1.643	1.6461	1.7002	1.7741	1.8861
22	1.7918	1.6827	1.5684	1.6827	1.6078	1.8111	1.7737
23	1.6598	1.5546	1.5684	1.6827	1.4784	1.6057	1.7002
24	1.4003	1.5089	1.5181	1.5123	1.5364	1.4937	1.5729
Max	1.9605	2.2634	2.0698	2.0165	2.1125	2.0911	1.9418
Min	1.182	1.2536	1.3203	1.2894	1.0974	1.2178	1.0242
Avg	1.5435	1.5968	1.5485	1.5703	1.5461	1.5493	1.5528

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044221 / 33/11KV WALMI SS

Feeder No / Name : 205 / Walmi EXPRESS  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0377	.037	.0377	.0377	.0377	.0549
2	.0373	.0377	.037	.0373	.0377	.0377	.0549
3	.0373	.0377	.037	.0373	.0373	.0377	.0362
4	.0377	.0377	.037	.0377	.0373	.0373	.0366
5	.0373	.0566	.0554	.0377	.0554	.0373	.0366
6	.0373	.0566	.0554	.0377	.0377	.0373	.0366
7	.056	.0754	.0554	.0373	.0554	.0373	.0377
8	.0566	.0754	.056	.0373	.0754	.056	.0754
9	.0747	.0566	.0373	.0373	.0754	.0747	.0754
10	.0754	.0566	.0566	.0526	.0747	.1109	.0934
11	.0754	.0739	.0754	.0377	.0924	.0754	.0747
12	.0754	.0747	.0943	.0377	.1109	.0943	.0739
13	.0754	.0754	.0566	.0377	.0914	.0943	.0732
14	.0754	.0754	.0566	.0377	.0732	.0754	.0732
15	.0754	.0754	.0566	.0189		.0566	.0914
16	.056	.0566	.0566	.0377	.0732	.0566	.0914
17	.056	.0362	.0377	.0377	.0549	.0377	.0554
18	.0543	.0362	.0373	.0377	.0554	.0377	.0566
19	.056	.0377	.056	.0377	.0549	.056	.0754
20	.0754	.0566	.0373	.0566	.037	.056	.0754
21	.0754	.0566	.0373	.0377	.037	.0554	.0754
22	.0566	.0566	.0373	.0566	.0554	.0554	.0747
23	.0566	.0566	.0373	.0566	.037	.0549	.0739
24	.0373	.0377	.0377	.0373	.0377	.0373	.0549
Max	.0754	.0754	.0943	.0566	.1109	.1109	.0934
Min	.0373	.0362	.037	.0189	.037	.0373	.0362
Avg	.0578	.0556	.0491	.0398	.0580	.0561	.0649



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044221 / 33/11KV WALMI SS

Feeder No / Name : 206 / Nakshatrawadi

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0082	1.0562	1.0269	1.0082	1.0082		1.1203
2		1.0374	1.0082	1.0082	1.0082	1.0642	1.1203
3		1.0374	1.0082	1.0269	.9979	1.0185	1.1827
4		1.094	1.0829	1.0269	1.0456	1.0269	1.1949
5		1.3203	1.2136	1.0751	1.1576	1.2323	1.3676
6	1.5089	1.5655	1.531	1.3203	1.5089	1.4937	1.531
7	1.8111	1.8673	1.7924	1.4937	1.9616	1.9605	1.8671
8	1.6804	1.9616	1.7926	1.7924	1.8298	1.7924	1.7551
9	1.3817	1.7353	1.5524	1.6804	1.7741	1.4937	1.5893
10	1.6263	1.6289	1.5655	1.6057	1.5524	1.5893	1.4937
11	1.0242	1.5927	1.6598		1.4415	1.4998	1.4003
12	1.3394	1.4327	1.5089	1.39	1.2803	1.4045	1.3306
13	1.3032	1.1871	1.3203	1.3032	1.2071	1.2071	1.2803
14	1.2536	1.1157	1.3203	1.267	1.1222	1.0608	1.2803
15	1.4118	1.1765	1.1883	1.2308	1.2437	1.2437	1.3032
16	1.3394	1.2308	1.3203	1.1706	1.262	1.39	1.3394
17	1.3756	1.3112	1.4712	1.4118	1.3676	1.39	1.2936
18	1.448	1.1871	1.3443	1.2071	1.2437	1.3032	1.3203
19	1.5844	1.4266	1.4937	1.4784	1.4784	1.3306	1.5278
20	1.5655	1.3535	1.5684	1.4937	1.4415	1.4937	1.4146
21	1.4146	1.3306	1.3817	1.3306	1.4045	1.419	1.4712
22	1.358	1.2382	1.2883	1.2323	1.2936	1.307	1.3443
23	1.226	1.1458	1.1203	1.1203	1.1949	1.1706	1.226
24	1.0642	1.1317	1.0719	1.0642	1.0456	1.1203	1.1576
Max	1.8111	1.9616	1.7926	1.7924	1.9616	1.9605	1.8671
Min	1.0082	1.0374	1.0082	1.0082	.9979	1.0185	1.1203
Avg	1.3862	1.3402	1.3596	1.2929	1.3280	1.3483	1.3713

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044222 / 33/11 KV PADEGAON

Feeder No / Name : 201 / 11 KV DEOGIRI VALLEY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9054	.9054	.7922	.7922	.8299	.8299	.8299
2	.9054	.7545	.7922	.7545	.7545	.7922	.7922
3	.9431	.7545	.7922	.7545	.7545	.7922	.7922
4	1.0185	.7545	.8676	.7545	.7922	.7922	.7922
5	1.094	.7922	.9431	.9431	.8676	.9054	.9054
6	1.1203	1.0185	1.0562	1.094	1.1317	1.2449	1.2449
7	1.1576	1.3203	1.2826	1.2826	1.2071	1.358	1.358
8	1.1949	1.3957	1.3203	1.2826	1.1694	1.3957	1.358
9	1.1203	1.2826	1.2449	1.2826	1.1317	1.2826	1.1827
10	1.0829	1.1576	1.1588	1.2071	.9808	1.1949	1.307
11	1.0082	1.0829	1.0466	1.2071	1.0185	1.1203	1.2197
12	.9335	1.1203	1.0093	1.1317	1.0185	1.0829	1.0349
13	.8589	1.1203	.8971	1.094	1.0185	1.0456	1.0349
14	.8589	1.0082	.8971	1.0562	.9808	1.0082	1.0349
15	.8962		.8971	1.0562	.9431	1.0456	1.0456
16	.8962	.9335	.8224	1.0185	.9431	1.1203	1.0456
17	.8971	1.0093	.8971	1.0185	1.0082	1.1576	1.1203
18	.8971	1.084	1.0093	1.0829	1.0829	1.2323	1.1949
19	1.0093	1.1588	.9719	1.1576	1.2323	1.3443	1.3443
20	1.57	1.084	1.2709	1.2696	1.1949	1.3817	1.307
21	1.0093	1.0466	1.1588	1.1203	1.1949	1.2071	1.2323
22	1.0093	1.0466	1.1588	1.0185	1.1317	1.1317	1.1203
23	1.0185	.9808	1.0185	.9431	1.094	1.0562	.9719
24	.9054	.9431	.9431	.8676	.9431	.9431	.9431
Max	1.57	1.3957	1.3203	1.2826	1.2323	1.3957	1.358
Min	.8589	.7545	.7922	.7545	.7545	.7922	.7922
Avg	1.0129	1.0328	1.0103	1.0496	1.0177	1.1027	1.0922

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044222 / 33/11 KV PADEGAON

Feeder No / Name : 203 / 11 KV PRIYA COLONY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9808	1.1317	1.1317	1.1317	1.1317	1.1317	1.1317
2	.9431	1.0562	1.0562	1.0562	1.0562	1.0562	1.0562
3	.9054	1.0562	1.0562	1.0562	1.0562	1.0562	1.0562
4	1.0562	1.0562	1.0562	1.0562	1.0562	1.0562	1.0562
5	1.2449	1.1317	1.4146	1.1317	1.2071	1.358	1.2826
6	1.643	1.5089	1.5089	1.5089	1.5844	1.5089	1.5844
7	1.7551	1.6598	1.6598	1.6598	1.7353	1.7353	1.8107
8	1.7924	1.8107	1.7353	1.6598	1.5844	1.6598	1.8107
9	1.643	1.6598	1.5844	1.7353	1.5844	1.5844	1.4784
10	1.4937	1.4937	1.4204	1.5844	1.2071	1.1949	1.419
11	1.3443	1.3443	1.1214	1.5089	.9808	1.1203	1.1088
12	1.2323	1.1203	1.1588	1.2071	.9054	1.1203	.961
13	1.0082	1.0082	1.1962	1.0562	.9054	1.0456	1.0349
14	.9335	.9335	1.1588	1.0562	1.0562	1.0456	1.1088
15	.9709	1.0082	1.1588	1.0562	1.0562	1.1203	1.1203
16	1.0082	1.0456	1.1214	1.2071	1.0562	1.1949	.9709
17	1.084	1.1588	1.2709	1.2071	1.1576	1.2323	1.0456
18	1.1962	1.2709	1.3457	1.2696	1.1949	1.307	1.2323
19	1.4952	1.4952	1.57	1.419	1.3817	1.4563	1.531
20	1.57	1.4952	1.57	1.5684	1.643	.1494	1.5684
21	1.4578	1.4204	1.4952	1.3817	1.4937	1.643	1.419
22	1.4204	1.4204	1.4952	1.307	1.419	1.4937	1.2696
23	1.2826	1.358	1.358	1.2826	1.358	1.2826	1.4204
24	1.0185	1.2071	1.2071	1.2071	1.2071	1.2071	1.2071
Max	1.7924	1.8107	1.7353	1.7353	1.7353	1.7353	1.8107
Min	.9054	.9335	1.0562	1.0562	.9054	.1494	.961
Avg	1.2700	1.2855	1.3271	1.3048	1.2508	1.24	1.2785

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044222 / 33/11 KV PADEGAON

Feeder No / Name : 204 / 11 KV PETHE NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9054	1.0185	.9431	.9431	.9808	1.0185	1.0185
2	.9054	.8299	.9431	.9431	.9808	.9431	.9431
3	.9431	.8299	.9431	.9431	.9808	.9431	.9431
4	1.0185	.8299	.9431	.9431	.9808	.9431	.9431
5	1.2449	.8676	1.0562	.9808	1.0562	1.2071	1.0185
6	1.419	1.358	1.5089	1.358	1.5466	1.4712	1.3957
7	1.643	1.6975	1.6975	1.6221	1.8107	1.6598	1.6221
8	1.7924	1.773	1.6975	1.6975	1.6598	1.6221	1.5844
9	1.6804	1.6975	1.6598	1.6975	1.6221	1.5844	1.2936
10	1.531	1.531	1.3831	1.4712	1.3203	1.307	1.1576
11	1.3443	1.3443	1.2709	1.4712	1.1317	1.1203	.9979
12	1.1203	1.2696	1.1588	1.1317	1.0562	.9335	.8131
13	1.0082	1.1576	1.0466	.9808	.9808	1.0082	.8501
14	.9335	.1494	.9749	.9431	.9054	.9335	.8589
15	.9335		.8971	.9431	.8676	.9335	.8215
16	1.0082	.9709	.8971	1.0185	.9808	.9335	.8215
17	1.084	1.084	1.2709	1.1317	1.0082	1.0082	1.0456
18	1.1588	1.1214	1.3457	1.3443	1.1203	1.1203	1.2323
19	1.4952	1.4204	1.6073	1.4937	1.4563	1.3443	1.4563
20	1.57	1.4952	1.4578	1.5684	1.531	1.4937	1.5684
21	1.4578		1.3457	1.307	1.419	1.5089	1.4937
22	1.4204	1.3457	1.3457	1.2449	1.358	1.4335	1.307
23	1.2071	1.1317	1.1694	1.094	1.2071	1.2071	1.1214
24	.9431	1.1694	1.094	1.094	1.0562	1.1317	1.1317
Max	1.7924	1.773	1.6975	1.6975	1.8107	1.6598	1.6221
Min	.9054	.1494	.8971	.9431	.8676	.9335	.8131
Avg	1.2403	1.1860	1.2357	1.2236	1.2091	1.2004	1.1433

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044222 / 33/11 KV PADEGAON

Feeder No / Name : 206 / 11 KV DARGA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3772	.3772	.3772	.3772	.415	.415
2	.3395	.3395	.3772	.3772	.3772	.3772	.3772
3	.3395	.3395	.3772	.3772	.3772	.3772	.3772
4	.3772	.3395	.3772	.415	.3772	.3772	.3772
5	.4527	.415	.415	.415	.415	.415	.4527
6	.5601	.4527	.5281	.4904	.5281	.4904	.5281
7	.6348	.5658	.6036	.5281	.5658	.5658	.5658
8	.6348	.6413	.5658	.5281	.5281	.5281	.6036
9	.5601	.6036	.5281	.5658	.5281	.5281	.5175
10	.5228	.5601	.4499	.4904	.4527	.4854	.4854
11	.3734	.4481	.4499	.3772	.3772	.4481	.4435
12	.3361	.2241	.4124	.3395	.3395	.2241	.3696
13	.3361	.2241	.4124	.3772	.3018	.2241	.3361
14	.2987	.2614	.3749	.415	.3018	.3361	.3734
15	.3734		.3749	.415	.3772	.4108	.3361
16	.3734	.4108	.3749	.2641	.415	.3361	.4108
17	.4499	.4874	.4124	.3772	.4481	.3734	.5228
18	.4874	.5249	.4124	.3361	.4854	.4481	.5601
19	.5999	.5999	.5249	.3734	.5601	.5601	.5975
20	.5999	.5624	.6374	.5228	.5975	.5975	.6348
21	.5249	.5249	.5249	.4854	.5228	.5281	.5601
22	.4874	.5249	.4874	.4527	.4527	.4527	.4854
23	.4527	.4527	.4527	.415	.5281	.4527	.4874
24	.3395	.415	.415	.415	.415	.4527	.415
Max	.6348	.6413	.6374	.5658	.5975	.5975	.6348
Min	.2987	.2241	.3749	.2641	.3018	.2241	.3361
Avg	.4497	.4476	.4527	.4221	.4437	.4335	.4680

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044222 / 33/11 KV PADEGAON

Feeder No / Name : 207 / 11 KV RAMGOPAL NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1886	.1886	.1886	.1886	.1886	.2263
2	.1509	.1886	.1886	.1886	.1886	.1886	.1886
3	.1509	.1886	.1886	.1886	.1886	.1886	.1886
4	.1886	.1886	.2263	.1886	.2263	.1886	.1886
5	.2263	.2263	.2641	.2263	.2641	.2263	.2263
6	.2614	.3018	.3018	.2641	.3018	.3018	.3018
7	.3734	.3395	.3772	.3018		.3772	.3772
8	.4108	.3772	.3772	.3018	.3018	.3395	.3772
9	.3361	.3395	.3018	.3018	.3018	.2641	.2587
10	.2987	.2614	.2625	.3018	.2263	.2241	.2241
11	.2241	.2241	.1875	.2641	.2263	.2241	.2218
12	.1867	.2241	.1875	.2263	.1886	.2241	.2218
13	.1867	.1867	.1875	.2263	.1886	.1494	.2218
14	.1494	.1867	.1875	.1886	.1886	.1867	.1848
15	.2241		.1875	.1886	.1886	.1867	.1867
16		.1867	.1875	.2263	.1886	.1867	.2241
17	.225	.225	.1875	.2263	.2241	.2241	.2241
18	.225	.225	.1875	.2241	.2614	.2614	.2614
19	.2625	.2625	.2625	.2614	.2987	.3361	.3361
20	.2625	.2625	.225	.2987	.3361	.3734	.2987
21	.2625	.225	.225	.2241	.2987	.2614	.2614
22	.2625	.225	.225	.2263	.2641	.2614	.2241
23	.2263	.2263	.2263	.2263	.2263	.2641	.2625
24	.1509	.1886	.1886	.1886	.2263	.1886	.2263
Max	.4108	.3772	.3772	.3018	.3361	.3772	.3772
Min	.1494	.1867	.1875	.1886	.1886	.1494	.1848
Avg	.2346	.2369	.2304	.2353	.2388	.2423	.2464

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044222 / 33/11 KV PADEGAON

Feeder No / Name : 209 / 11 KV AMC Padegaon

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0377	.0377	.0377	.0377	.0377	.0377
2	.0566	.0377	.0377	.0377	.0377	.0377	.0377
3	.0566	.0377	.0377	.0377	.0377	.0377	.0377
4	.0943	.0377	.0377	.0377	.0377	.0377	.0377
5	.0943	.0377	.0377	.0377	.0377	.0377	.0566
6	.1307	.0377	.0377	.0377	.0377	.0377	.0566
7	.1307	.0377	.0377	.0377	.0754	.0377	.0566
8	.168	.0377	.1132		.0754	.0377	.1132
9	.056	.0566	.0566		.0754	.0377	.0554
10	.056	.0747	.075	.0566	.0754	.0934	.0934
11	.0747	.0934	.075	.0566	.1132	.112	.0739
12	.0934	.0934	.075	.0566	.1132	.0934	.0924
13	.0934	.0747	.075	.0377		.056	.0934
14	.0934	.0747	.0375	.0566	.1132	.0934	.0934
15	.056	.0934	.0375	.0566	.1132	.0934	.056
16	.0934	.112	.075	.0754	.0566	.112	.0747
17		.0562	.075	.0754	.0934	.0934	.112
18		.0562	.075	.112	.0934	.0934	.112
19	.0375	.075	.1125	.112	.1494	.112	.112
20	.0375	.0375	.0375	.112	.112	.112	.0747
21	.075	.0375	.0375	.056	.0747	.0754	.056
22	.075	.075	.0375	.056	.056	.0754	.056
23	.0377	.0566	.0377		.0377	.0566	.0375
24	.0566	.0377	.0377	.0377	.0377	.0377	.0566
Max	.168	.112	.1132	.112	.1494	.112	.1132
Min	.0375	.0375	.0375	.0377	.0377	.0377	.0375
Avg	.0783	.0586	.0556	.0581	.0735	.0687	.0701

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 004701 / 132 KV HARSUL S\S

Feeder No / Name : 201 / Jaman Jyoti

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	09-MAR-18	10-MAR-18	11-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429	.5144	.4191	.4572
2	.3429	.3429	.4954	.4001	.4382
3	.3239	.3429	.4954	.4001	.9335
4	.3429	.362	.5335	.4191	.4572
5	.381	.4191	.5906	.4954	.4954
6	.5716	.5716	.7049	.743	.6478
7	.7811	.8002	.9335	.9907	.9335
8	.9526	.8764	.9907	1.0479	.9907
9	.8002	.8192	.9526	1.0479	1.1622
10	.8383	.724	1.0098	.9717	.724
11	.7811	.724	.9145	.8954	.8383
12	.7621	.6859		.724	.724
13	.7621	.5906		.743	
14	.5906	.724		.6859	.6668
15		.724		.7811	
16	.4954	.5716	.9907	.743	.7621
17	.9335	.7049	1.105	.8192	.8002
18	.8764	.6859	1.0479	.8383	.8573
19	.7049	.8002	.7811	.743	.7621
20	.6097	.724	.6859	.6287	.6859
21	.4954	.7049	.6287	.5716	.6097
22	.4763	.7049		.5144	.5716
23	.4001	.6097	.4763	.4763	.5335
24	.3429	.3429	.5335	.4191	.4763
Max	.9526	.8764	1.105	1.0479	1.1622
Min	.3239	.3429	.4763	.4001	.4382
Avg	.6047	.6208	.7571	.6883	.7058



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 004701 / 132 KV HARSUL S\S

Feeder No / Name : 202 / 11 kv subhedari

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	13-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8002	.8383	.8002	.8383
2	.7621	.7621	.7811	.8002
3	.743	.743	.7621	.7621
4	.7049	.724	.724	.743
5	.724	.743	.743	.7621
6	.8383	.8573	.8764	.8573
7	.8192	.8002	.8573	.8192
8	.8383	.8954	.8764	.9145
9	.8764	.8954	.8573	.8573
10	.8954	.9907	.8573	.8954
11	.8002	.9335	.8573	.8954
12	.743	.9717	.8002	.7049
13	.8383	1.086	.743	.8192
14	.7621	.8954	.8002	.8764
15	.7811	.9145	.724	.7811
16	.743	.7621	.7621	.8192
17	.7621	.743	.7621	.8383
18	.9145	.8954	1.0479	.743
19	.9907	1.0098	1.086	1.0098
20	1.0288	1.0669	1.0288	1.0479
21	1.0098	.9907	.9335	1.0098
22	.9526	.9907	.9717	1.0479
23	.6668	.8573	.9526	.9717
24	.8954	.8573	.8573	.9145
Max	1.0288	1.086	1.086	1.0479
Min	.6668	.724	.724	.7049
Avg	.8288	.8843	.8526	.8637

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 004701 / 132 KV HARSUL S\S

Feeder No / Name : 204 / 11 kv Delhi Gate

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	09-MAR-18	11-MAR-18	13-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	1.2765	1.2955	1.3146
2	1.2384	1.2765	1.2574
3	1.2574	1.2574	1.2384
4	1.2765	1.3146	1.3146
5	1.448	1.4098	1.467
6	1.2384	1.7718	2.0005
7	2.21	2.1148	2.3624
8	2.934	2.3815	2.4196
9	2.4958	2.2291	2.0957
10	1.8099	2.0195	1.9052
11	1.829	1.9433	1.6575
12	2.0005	1.6194	1.2765
13	1.7337	1.448	1.2574
14	1.3336	1.3527	1.3908
15			1.2955
16	1.5242	1.4289	1.4289
17	1.448	1.7718	1.6766
18	1.7909	1.9433	2.2672
19	2.0386	2.1148	2.0386
20	1.9243	1.9433	1.848
21	1.7528	1.7528	1.7909
22	1.6766	1.6385	1.6004
23	1.5432	1.5242	1.6004
24	1.467	1.3717	1.4098
Max	2.934	2.3815	2.4196
Min	1.2384	1.2574	1.2384
Avg	1.7064	1.6923	1.6631

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 004701 / 132 KV HARSUL S\S

Feeder No / Name : 205 / 11 kv WATER WORKS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.2096	.2096	.2286	.2096
2	.2096	.2096	.2096	.2286	.2096
3	.2096	.2096	.2096	.2096	.2096
4	.2096	.2096	.2286	.2096	.2286
5	.2477	.2667		.2858	.2667
6	.3239	.3048	.3429	.3429	.3429
7	.4763	1.5432	.4191	.4382	.4191
8	.4382	.4001	.4191	.4382	.4191
9	.362	.4191	.381	.4001	.381
10	.3429	.4572	.362	.3429	.362
11	.3048	.3239	.3429	.3429	.3429
12	.2286	.3239	.2858	.2477	.2858
13		.2286	.2667	.2477	.2667
14	.2286	.2477	.2477	.2667	.2667
15	.2286	.1905	.2286	.2286	.2477
16	.2096	.2477	.2286	.2286	.2286
17	.2858	.2286	.2667	.2286	.2667
18	.3048	.3048	.381	.3239	.381
19	.3429	.4954	.4191	.381	.4191
20	.4191	.381	.4191	.4191	.4191
21	.3429	.3048	.362	.362	.362
22	.3048	.3048	.3048	.3429	.3048
23	.2477	.2477	.2858	.2858	.2858
24		.2286	.2286	.2286	.2286
Max	.4763	1.5432	.4191	.4382	.4191
Min	.2096	.1905	.2096	.2096	.2096
Avg	.2944	.3453	.3065	.3024	.3064

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 004701 / 132 KV HARSUL S\S

Feeder No / Name : 207 / 11 kv Kat kat Gate

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	09-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8671	1.8861	1.9243	1.9433
2	1.7909	1.829	2.1148	1.9433
3	1.7528	1.7337	1.7528	1.848
4	1.7147	1.7909	1.7528	1.7718
5	1.7909	1.829	1.8671	1.8861
6	2.191	2.0386	2.2672	2.3243
7	2.5339	2.3053	2.7244	2.7816
8	3.0674	2.7816	2.8959	2.8197
9	3.6199	3.0674	3.1626	3.0674
10	3.5437	3.4294	2.9721	3.0293
11	3.1055	3.0293	2.7435	2.915
12	2.9721	2.9721	2.7244	2.7435
13	3.7342	2.7244	2.572	2.553
14	2.7054	2.4768	2.2481	2.3053
15	2.191	2.21	2.1719	2.1719
16	2.0957	2.2291	2.1338	2.1338
17	2.3053	2.7435	2.2481	2.3434
18	2.6482	2.934	2.7054	2.6673
19	3.0483	3.1245	3.2198	3.3913
20	3.1055	2.9531	3.2198	3.296
21	2.7816	2.7244	2.8959	3.0483
22	2.6292	2.5911	2.5911	2.7625
23	2.3243	2.3053	2.3624	2.4577
24	2.1148	2.0386	2.0386	2.0576
Max	3.7342	3.4294	3.2198	3.3913
Min	1.7147	1.7337	1.7528	1.7718
Avg	2.5681	2.4895	2.4712	2.5109

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 004701 / 132 KV HARSUL S\S

Feeder No / Name : 209 / Bhim Tekdi  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	09-MAR-18	10-MAR-18	11-MAR-18	13-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4289	1.448	1.4861	1.448
2	1.3908	1.4289	1.4098	1.4289
3	1.4098	1.4098	1.4098	1.4098
4	1.4098	1.4098	1.4098	1.4289
5	.3239	1.5242	1.5242	1.4861
6	1.8861	1.9624	1.848	2.0767
7	2.3815	2.3243	2.1338	2.2862
8	2.6482	2.4387	2.4196	2.4006
9	2.4387	2.1338	2.2862	2.2672
10	2.3624	1.9433	2.2862	1.8861
11	2.0767	1.8099	2.0195	1.829
12	1.9814	1.5432	1.9052	1.6575
13	1.8861	1.5051	1.6766	1.4289
14	1.6194	1.3908	1.6575	1.6004
15		1.3336	1.467	1.5242
16	1.6575	1.3717	1.3908	1.467
17	1.6766	1.2384	1.7718	1.6194
18	1.8671	1.848	1.9243	1.9052
19	2.1529	2.191	2.1148	2.2862
20	2.0576	2.2481	2.0005	2.2291
21	1.9433	1.9814	1.9052	2.0386
22	1.8861	1.9433	1.9052	1.9814
23	1.7147	1.8099	1.7147	1.7909
24	1.6194	1.5242	1.5623	1.5432
Max	2.6482	2.4387	2.4196	2.4006
Min	.3239	1.2384	1.3908	1.4098
Avg	1.8182	1.7401	1.8012	1.7925

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 004701 / 132 KV HARSUL S\S

Feeder No / Name : 210 / Bhagat Singh

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.9335	.9335	.9526	.9526	.9907
2		.8954	.9145	.8954	.9145	.9526
3	.8764	.8573	.8764	.8954	.9145	.9335
4	.8383	.8764	.8954	.8764	.9335	.9335
5	.8573	.9907	1.0098	.8954	1.0288	1.086
6	.9907	1.2384	1.3146	1.0098	1.3336	1.3146
7	1.5623	1.5051	1.5623	1.3146	1.6766	1.6004
8	1.6575	1.467	1.4861	1.6575	1.5813	1.3336
9	1.467	1.2765	1.2574	1.4098	1.2574	1.1622
10	1.1241	1.1431	1.086	1.1622	1.1431	.9907
11	1.0669	1.105	.9907	1.1622	1.0288	.9717
12	.9526	.9526	.8764	1.0669	.9526	.8954
13	.8954	.9526	.8764	1.105	.8764	.8002
14	.743	.8954	.8573	1.1241	.8954	1.0098
15	.8954		1.0669	.9907	.9145	.8954
16	.9145	1.0479	.9526	.8764	.8764	.8764
17	.9335	.9526	.8954	.9335	1.0098	1.0669
18	1.0288	.9907	1.1431	.9907	1.105	1.2193
19	1.4289	1.3717	1.3336	1.2384	1.467	1.467
20	1.4289	1.3908	1.2955	1.4289	1.448	1.4289
21	1.3336	1.3527	1.3336	1.4098	1.3908	1.3908
22	1.3146	1.2955	1.3717	1.2955	1.2955	
23	1.086	1.1241	1.1431	1.1241	1.2384	1.1622
24	.9907	.9907	1.0288	1.0098	1.0288	1.0669
Max	1.6575	1.5051	1.5623	1.6575	1.6766	1.6004
Min	.743	.8573	.8573	.8764	.8764	.8002
Avg	1.1000	1.1133	1.1042	1.1177	1.1360	1.1108

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 004701 / 132 KV HARSUL S\S

Feeder No / Name : 401 / 33 kv cidco

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	16.5752	11.8884	12.0599	12.2314	12.2314
2	11.3169	11.3169	11.4312	11.5455	11.6027
3	11.0311	11.0883	6.0585	11.3169	11.3169
4	10.9168	10.8025	11.2026	11.2026	11.1454
5	11.6027	11.1454	11.8313	11.6598	11.5455
6	13.8889	13.1459	13.6603	13.6031	13.6603
7	15.6036	14.8034	13.8889	15.5464	***
8	18.1756	16.2323	15.8322	16.6896	16.7467
9	19.9474	17.3754	17.8898	17.7755	17.7184
10	21.0334	17.2611	18.4614	17.8327	17.3754
11	20.3475	16.7467	18.1756	17.2611	17.604
12	20.3475	16.1751	17.4326	16.2895	16.4609
13	18.69	15.6036	16.2895	15.375	15.8894
14	16.4038	14.6891	14.8034	14.6891	15.2607
15	13.8318	13.6031	13.3173	14.1747	13.9461
16	13.3745		13.6603	14.0604	13.8318
17	14.3462	14.5748	15.375	14.5748	14.5748
18	16.5752	16.6896	16.6324	16.861	16.5181
19	18.5757	19.1473	18.0613	19.3187	19.5474
20	18.0041	18.8615	17.3183	18.9758	25.2058
21	16.3466	16.6324	15.9465	16.9753	17.7184
22	15.7179	15.7179	15.2035	15.9465	16.861
23	13.1459	14.8034	14.4033	14.9177	15.4893
24	13.6031	13.1459	13.0887	13.6031	13.3173
Max	21.0334	19.1473	18.4614	19.3187	415.5813
Min	10.9168	10.8025	6.0585	11.2026	11.1454
Avg	15.8084	14.8457	14.6677	15.1011	32.1312

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044052 / 33 KV BAIJIPURA S/STN

Feeder No / Name : 201 / 11 KV ROSHAN GATE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8671	1.8671	1.8671	2.0538	2.2405	2.0538	2.1285
2	1.6804	1.7737	1.7737	1.9044	2.0538	1.8671	1.8671
3	1.531	1.6804	1.6804	1.7737	1.8671	1.7737	1.7924
4	1.643	1.8671	1.8671	1.8298	1.8858	1.8111	1.8298
5	1.7177	1.9605	1.8858	1.8671	1.9231	1.8484	1.9418
6	1.7924	2.0351	1.9044	1.8858	1.9605	1.8671	2.0725
7	1.9418	2.1098	1.9418	1.7551	1.9605	1.9978	2.3152
8	2.1658	2.3152	2.0538	1.9418	2.3152	2.2405	2.3152
9	2.3525	2.5206	2.3152	2.3899	2.5953	2.3525	2.5206
10	2.3339	2.9313	2.3899	2.5766	2.5019	2.4646	2.5766
11	2.5019	2.9687	2.4272	2.5393	2.6326	2.5019	2.782
12	2.5579	3.1367	2.2592	2.7446	2.5766	2.5393	2.4832
13	2.5579	3.1741	2.4459	2.7073	2.5579	2.6513	2.4209
14	2.3339	2.5579	2.2965	2.4646	2.4459	2.3525	2.3712
15	2.1658	2.1285	2.0911	2.2592	2.2779	2.2405	2.2405
16	2.1098	2.0725	2.0911	2.1472	2.2592	2.1658	2.0911
17	.2259	.2091	.2091	.2297	.2147	2.1845	.2166
18	.2577	.2483	.2521	.2577	.2614	2.4832	.2539
19	.3006	.2745	.295	.2894	.3006	3.0434	.2987
20	.3062	.2857	.3006	.2875	.3081	3.0994	.2931
21	.2745	.2651	.2689	.2633	.2689	2.838	.2726
22	.2577	.2446	.2502	.2502	.2521	2.6326	.2521
23	.2427	.2315	.2371	.2297	2.1098	2.4646	.2353
24		2.0911	2.0351	2.0911	2.4272	2.1098	2.2405
Max	2.5579	3.1741	2.4459	2.7446	2.6326	3.0994	2.782
Min	.2259	.2091	.2091	.2297	.2147	1.7737	.2166
Avg	1.5269	1.7062	1.5474	1.6141	1.7582	2.3160	1.6588



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044052 / 33 KV BAIJIPURA S/STN

Feeder No / Name : 202 / 11 KV Nizamuddin Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6244	1.7177	1.587	1.7737	1.7177	1.7177	1.6804
2	1.531	1.6804	1.531	1.7177	1.6804	1.6804	1.5684
3	1.4937	1.643	1.4937	1.643	1.587	1.643	1.4937
4	1.587	1.7737	1.587	1.6617	1.6804	1.6804	1.643
5	1.6244	1.8671	1.6804	1.6804	1.7737	1.8671	1.6804
6	1.643	1.9044	1.6804	1.6804	1.8671	1.9044	1.8671
7	2.1285	2.0725	1.9044	1.9605	2.1472	2.0538	2.2032
8	2.8006	2.4272	2.0538	2.2405	2.3339	2.5206	2.1472
9	2.4272	2.8006	2.4272	2.4646	2.3712	2.782	2.5766
10	2.4459	2.9874	2.3152	2.7073	2.3339	2.3712	2.2965
11	2.2779	2.7073	2.2405	2.5393	2.5206	2.6326	1.8671
12	2.2032	2.7633	2.1845	2.2779	2.3152	2.4646	1.8671
13	2.0165	2.5019	2.0538	2.2405	2.2218	2.2965	2.2405
14	1.4937	2.0165	1.7924	1.7924	1.9605	2.0725	2.0725
15	1.6804	1.6804	1.6804	1.6804	1.9605	1.8671	1.8671
16	1.6804	1.643	1.6804	1.7177	2.0165	1.7924	1.6244
17	.2072	.1867	.1792	.196	.2259	1.9231	.2072
18	.2353	.2185	.2427	.2315	.2465	2.2592	.2409
19	.2707	.2577	.2819	.2521	.2819	2.6886	.2782
20	.2651	.2427	.2707	.2427	.2838	2.6139	.2689
21	.2315	.2259	.2315	.2128	.2371	2.2405	.2278
22	.2259	.2091	.2128	.2094	.2241	2.2405	.2128
23	.2072	.1979	.196	.1904	.2016		.1904
24	1.6804	1.7364	1.6804	1.7924	1.7924	1.7364	1.7551
Max	2.8006	2.9874	2.4272	2.7073	2.5206	2.782	2.5766
Min	.2072	.1867	.1792	.1904	.2016	1.643	.1904
Avg	1.4159	1.5609	1.3828	1.4627	1.4992	2.1325	1.4199

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044052 / 33 KV BAIJIPURA S/STN

Feeder No / Name : 203 / 11 KV MONDHA Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6139	2.6139	2.9874	2.9874	2.95	2.9874	3.006
2	2.2405	2.4272	2.6139	2.8006	2.8006	2.8006	2.7633
3	2.1845	2.2405	2.3339	2.4272	2.7633	2.6139	2.6326
4	3.1741	3.1741	3.1741	3.1741	3.3234	2.9874	3.062
5	3.3608	3.3608	3.3608	3.5475	3.5101	3.1741	3.3608
6	3.6222	3.5475	3.5848	4.0143	3.6782	3.3608	3.7342
7	4.3877	4.3317	4.3317	4.257	4.481	4.4437	4.4997
8	4.6677	4.8544	4.5557	4.4437	4.481	4.5557	4.5184
9	4.537	4.9478	4.537	4.6677	4.5744	4.4997	4.4437
10	4.2756	4.8544	4.2943	4.537	4.3877	4.3317	4.1823
11	4.2383	4.6117	4.2383	4.4437	4.1263	4.1076	4.1076
12	3.7529	4.5184	4.0516	4.1263	3.9769	3.9582	3.7715
13	3.7902	3.8649	3.7342	3.8089	3.5848	3.7902	3.5101
14	3.2487	3.5475	3.4168	3.2861	3.3981	3.5475	3.3794
15	3.1367	3.3794	3.2114	3.0807	3.3981	3.3234	3.2487
16	2.9874	3.2861	3.2301	3.2487	3.4168	3.3981	3.3048
17	.3566	.3622	.3585	.3491	.3585	3.6595	.366
18	.3996	.4052	.4182	.4052	.4145	4.1636	.4164
19	.4836	.4686	.4948	.4332	.4798	4.9851	.4948
20	.4836	.4593	.4873	.4313	.4948	4.8544	.478
21	.4126	.4108	.4089	.3902	.4425	4.369	.4089
22	.3921	.3828	.3884	.3734	.4014	3.9396	.3734
23	.3529	.3566	.3566	.3342	.3622	3.6408	.3547
24	2.9874	2.9874	3.0807	3.1181	3.006	3.062	3.2674
Max	4.6677	4.9478	4.5557	4.6677	4.5744	4.9851	4.5184
Min	.3529	.3566	.3566	.3342	.3585	2.6139	.3547
Avg	2.5869	2.7247	2.6521	2.6952	2.7004	3.7731	2.6535

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044052 / 33 KV BAIJIPURA S/STN

Feeder No / Name : 204 / Water Works

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.037	.037	.0554	.0554	.0739	.0185	.0373
2	.037	.037	.0554	.037	.0554	.037	.0187
3	.0185	.0185	.037	.0185	.037	.0185	.0187
4	.0739	.037	.0554	.037	.0185	.037	.0373
5	.0924	.037	.0739	.0554	.037	.0554	.0373
6	.1109	.037	.0739	.0739	.037	.0554	.0747
7	.037	.037	.0739	.037	.037	.0739	.0747
8	.0739	.037	.037	.037	.0373	.056	.0373
9	.056	.0373	.056	.0747	.0747	.0187	.0373
10	.0934	.056	.0747	.0373	.056	.0554	.0373
11	.056	.0373	.0373	.0373	.0373	.037	.0373
12	.0373	.0373	.0373	.0373	.0373	.037	.0373
13	.0373	.0187	.0373	.0373	.056	.037	.0187
14	.0747	.0373	.0747	.0373	.056	.0739	.056
15	.0373	.056	.0373	.0373	.0373	.0554	.0187
16	.056	.0373	.056	.056	.056	.0924	.0373
17	.0037	.0056	.0019	.0075	.0037	.0373	.0037
18	.0019	.0075	.0075	.0037	.0019	.0373	.0019
19	.0019	.0056	.0056	.0056	.0019	.0934	.0019
20	.0019	.0112	.0112	.0037	.0187	.056	.0093
21	.0019	.0056	.0056	.0075	.0038	.0373	.0019
22	.0075	.0075	.0075	.0037	.0056	.1867	.0037
23	.0037	.0075	.0056	.0019	.0037	.1307	.0056
24	.037	.037	.0739	.0554	.0739	.037	.0747
Max	.1109	.056	.0747	.0747	.0747	.1867	.0747
Min	.0019	.0056	.0019	.0019	.0019	.0185	.0019
Avg	.0412	.0284	.0413	.0331	.0357	.0573	.0299

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044218 / 33KV HIMAYAT BAG

Feeder No / Name : 201 / 11 KV Nehru Bhavan

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.2829	.2829	.3018	.3772	.3772	.3772
2	.2427	.2614	.2829	.2829	.3395	.3395	.3772
3	.2452	.2614	.2641	.2641	.3395	.3395	.3584
4	.2427	.2641	.2641	.2829	.3395	.3395	.3395
5	.2641	.2614	.2829	.2829	.3395	.3772	.3395
6	.3018	.3018	.3018	.3018	.3772	.3772	.3395
7	.3772	.3395	.3772	.3395	.3772	.3772	.3395
8	.3772	.3772	.3018	.3395	.3772	.3018	.3395
9	.3658	.3658	.3292	.3772	.3361	.3018	.3772
10	.3292	.3658	.3658	.415	.3395	.3395	.3395
11	.3292	.3658	.3658	.3961	.3772	.3772	.3395
12	.3292	.3658	.3292	.3395	.3395	.3772	.3361
13	.3109	.3292	.3292	.3772	.2987	.3395	.3395
14	.2926	.2926	.2926	.3361	.2987	.3018	.3174
15	.2561	.2743	.2561	.2614	.2614	.2641	.2829
16	.2667	.2561	.2561	.2614	.2987	.2614	.2801
17	.3018	.2561	.2713	.2926	.2743	.2614	.2641
18	.3018	.3292	.2926	.3658	.3395	.3292	.3361
19	.3772	.3395	.3734	.3658	.4024	.4024	.415
20	.3772	.3772	.381	.3658	.4066	.4108	.3658
21	.3395	.3395	.3361	.3292	.3772	.4108	.3772
22	.3395	.3395	.3429	.3292	.3734	.3772	.3395
23	.3361	.3018	.3395	.3018	.415	.3772	.3395
24	.2987	.2987	.3018	.2829	.3772	.3772	.3772
Max	.3772	.3772	.381	.415	.415	.4108	.415
Min	.2427	.2561	.2561	.2614	.2614	.2614	.2641
Avg	.3119	.3144	.3133	.3247	.3493	.3474	.3432

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044218 / 33KV HIMAYAT BAG

Feeder No / Name : 202 / 11 KV CityChowk Police  
station Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7741	1.6632	1.6032	1.8107	2.0748	2.037	1.8107
2	1.7002	1.5524	1.4146	1.6975	1.8861	1.8861	1.6975
3	1.6057	1.5154	1.5089	1.6975	1.7918	1.5089	1.6032
4	1.5154	1.5154	1.6032	1.8107	1.7918	1.5278	1.6032
5	1.4784	1.5524	1.6975	1.8673	1.8107	1.6032	1.6598
6	1.7741	1.7924	1.7353	2.452	1.8861	1.8861	2.037
7	1.922	1.7364	1.8107	2.037	1.9805	1.8861	1.9239
8	2.0165	2.0165	2.1125	1.8861	2.0748	2.037	1.9616
9	2.1033	2.1948	2.1948	2.1437	2.2405	2.1658	2.2405
10	2.2862	2.5606	2.2314	2.3899	2.3152	2.3525	2.1658
11	2.3777	2.5606	2.1033	2.4646	2.0698	2.1658	2.2405
12	2.3411	2.5606	2.1033	2.6139	2.2405	2.3899	2.5393
13	2.4143	2.4691	2.2862	2.5393	2.3899	2.6139	2.4646
14	2.2862	2.3777	2.1033	2.3899	2.3152	2.4272	2.3152
15	2.1948	2.1948	1.9204	2.3152	2.3152	2.1437	2.2405
16	2.1033	1.6461	2.1033	2.1437	2.1437	2.0911	2.1437
17	1.0185	2.0119	2.1125	2.2862	2.3152	2.1948	2.4143
18	2.4897	2.1033	2.2405	2.4691	2.5873	2.5133	2.6337
19	3.0933	2.6406	2.9264	2.8166	3.219	3.2114	3.1459
20	2.8292	2.7161	2.9721	2.7435	3.2769	3.1824	3.0178
21	2.7161	2.452	2.4897	2.4691	3.0178	3.0178	2.7801
22	2.2634	2.2634	2.2862	2.2862	2.7069	2.4874	2.4897
23	2.1068	1.8861	2.0748	2.2634	2.3388	1.9805	2.452
24	1.9418	1.8671	1.8107	1.8107	2.0748	2.037	1.9616
Max	3.0933	2.7161	2.9721	2.8166	3.2769	3.2114	3.1459
Min	1.0185	1.5154	1.4146	1.6975	1.7918	1.5089	1.6032
Avg	2.0980	2.0770	2.0602	2.2252	2.2860	2.2228	2.2309

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044218 / 33KV HIMAYAT BAG

Feeder No / Name : 203 / 11KV Ganesh colony

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6632	1.7741	1.8107	1.8107	1.8107	1.8861	1.8107
2	1.643	1.7002	1.5844	1.6598	1.8107	1.7353	1.6975
3	1.5154	1.5524	1.6032	1.6598	1.6975	1.5466	1.6975
4	1.5154	1.5154	1.6975	1.829	1.6598	1.5466	1.8861
5	1.6263	1.5524	1.7918	1.8107	2.0748	1.6032	1.8861
6	1.7741	1.848	1.8861	2.037	2.0748	1.6598	2.037
7	1.9959	1.9418	2.037	2.037	2.037	1.9616	2.2634
8	2.0911	2.3152	2.1879	2.1125	2.1125	2.037	2.3388
9	2.1948	2.5606	2.2862	2.3152	2.4646	2.2405	2.4646
10	2.2862	2.7435	2.3411	2.6139	2.4646	2.3899	2.5393
11	2.1948	2.8349	2.1948	2.5393	2.3899	2.3899	2.3899
12	2.1033	2.9264	2.1033	2.4646	2.2405	2.3152	2.2405
13	2.0485	2.5606	2.1948	2.3152	2.1658	1.922	2.1658
14	1.9204	2.1948	2.0119	2.1658	2.0698	1.922	1.9959
15	1.829	1.829	1.829	1.848	1.848	1.9959	1.848
16	1.829	1.6461	1.829	1.7741	1.7002	2.0538	1.7741
17	1.8861	1.7558	1.8671	1.829	1.7924	2.037	1.9418
18	2.1125	2.1033	2.1216	2.1033	2.1879	2.0485	2.2443
19	2.4143	2.2634	2.5652	2.3777	2.7161	2.6337	2.5133
20	2.2634	2.3388	2.3411	2.2314	2.3411	2.6406	2.4897
21	2.2634	2.2634	2.3167	2.1033	2.3655	2.4143	2.4143
22	2.0698	2.0748	2.1338	2.1033	2.3388	2.3777	2.3577
23	2.2405	1.8861	1.8861	1.8861	1.9805	2.1691	2.2634
24	1.922	1.922	1.9616	1.8861	1.8861	1.9805	2.0748
Max	2.4143	2.9264	2.5652	2.6139	2.7161	2.6406	2.5393
Min	1.5154	1.5154	1.5844	1.6598	1.6598	1.5466	1.6975
Avg	1.9751	2.0876	2.0242	2.0630	2.0929	2.0628	2.1389

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044218 / 33KV HIMAYAT BAG

Feeder No / Name : 204 / 11 KV ROJABAG FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7095	.7468	.7545	.679	.7922	.7167	.7922
2	.6602	.679	.7167	.6602	.7545	.7167	.7922
3	.6602	.679	.679	.5281	.7545	.7167	.7922
4	.679	.6535	.679	.5281	.7545	.7167	.7545
5	.7167	.7545	.7167	.6602	.8299	.7545	.7545
6	.8299	.7095	.7167	.679	.9054	.7922	.7922
7	1.0185	.8676	.9431	.679	.9054	.9054	.9431
8	.9335	.9808	.9431	.7545	.9808	.8676	.8676
9	.9145	.9877	.9511	.8962	1.0562	.9808	1.0185
10	.9145	1.0242	.9877	.9431	1.094	1.0082	1.0185
11	.9145	1.0974	1.0059	.8962	.0739	1.0185	1.2071
12	.9145	1.134	1.0059	.9808	.1109	1.094	1.1694
13	.9145	1.0242	.9511	.9431	1.1317	1.0185	1.1694
14	.9877	.9511	.9145	.9335	1.0185	1.0185	1.1576
15	1.0242	.9145	.9145	.8589	.9431	1.094	1.0562
16	1.0242	.9145	.9511	.8962	.9335	1.0562	1.0829
17	.9808	.9145	.9907	.9145	1.0669	.9511	1.0242
18	.9054	.9145	.9145	.9511	.9709	.9431	1.0562
19	.9808	.9431	1.0562	1.0242	1.0562	1.094	1.0829
20	.9431	1.0185	1.0242	.9877	1.0242	1.094	1.094
21	.9054	.9808	1.0185	.9511	.9709	1.0185	.9511
22	.7922	.9431	1.0288	.9511	.9526	.9907	1.0185
23	.7842	.8488	.9431	.9054	.9054	.9431	.9808
24	.7922	.8676	.7922	.679	.8299	.7922	.9054
Max	1.0242	1.134	1.0562	1.0242	1.1317	1.094	1.2071
Min	.6602	.6535	.679	.5281	.0739	.7167	.7545
Avg	.8708	.8979	.9000	.8283	.8673	.9292	.9784

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044218 / 33KV HIMAYAT BAG

Feeder No / Name : 205 / 11 KV Collector Office NON SHEDDABLE EXPRESS HV FEEDERS  
Express Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.056	.0566	.0566	.0566	.0566	.0566
2	.0566	.0566	.0566	.0566	.0566	.0566	.0566
3	.056	.0566	.0566	.0566	.0566	.0566	.0566
4	.0566	.0566	.0566	.0566	.0566	.0566	.0566
5	.0566	.056	.0566	.0566	.0566	.0566	.0566
6	.0566	.0566	.0566	.0566	.0566	.0566	.0566
7	.0566	.056	.0566	.0566	.0566	.0566	.0566
8	.0566	.056	.0566	.0566	.0566	.0566	.0566
9	.0762	.0572	.0572	.056	.0566	.0943	.0754
10	.1334	.0762	.0762	.0754	.1509	.1132	.1886
11	.1905	.0953	.0953	.0754	.2263	.2263	.1886
12	.2286	.1143	.0953	.0754	.1886	.2263	.2263
13	.2286	.1143	.0762	.0754	.1886	.2263	.2263
14	.2286	.0953	.0762	.0754	.1886	.2263	.1886
15	.1905	.0953	.0762	.0566	.1886	.1886	.1886
16	.1905	.0953	.0762	.056	.1886	.1886	.1886
17	.1509	.0953	.0754	.0572	.1886	.1886	.1886
18	.1132	.0572	.0566	.0572	.1886	.1509	.1867
19	.0754	.0566	.0754	.0572	.112	.1509	.1509
20	.0566	.0566	.0572	.0572	.0754	.1132	.0762
21	.0566	.0566	.0566	.0572	.0754	.0724	.0754
22	.0566	.0566	.0572	.0572	.0572	.0572	.0762
23	.0566	.0566	.0566	.0566	.0566	.0566	.0754
24	.0566	.0566	.0566	.0566	.0566	.0566	.0566
Max	.2286	.1143	.0953	.0754	.2263	.2263	.2263
Min	.056	.056	.0566	.056	.0566	.0566	.0566
Avg	.1059	.0702	.0656	.0606	.11	.1162	.1171



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044220 / 33KV jadhavwadi s.s

Feeder No / Name : 201 / 11 KV SUREWADI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7842	.811	.8215	.8589	.8488	.8962	.8775
2	.7468	.7922	.7842	.8215	.811	.8589	.8589
3	.7095	.7545	.7468	.7842	.7922	.8215	.8299
4	.8215	.8299	.8215	.8962	.7888	.8962	.9242
5	.9335	.9054	.8962	.9335	.9808	1.0082	.9709
6	1.0082	1.0185	1.0082	1.0082	1.1883	1.1203	1.1016
7	1.1389	1.1317	1.1203	1.0642	1.3203	1.2883	1.2323
8	1.0829	1.1317	1.1389	1.1763	1.226	1.1203	1.1949
9	.9808	.9997	1.1016	1.1506	1.0562	1.0562	1.0562
10	.9054	.6979	.9149	.9808	.9431	.9431	.9808
11	.7922	.8865	.8402	.9808	.8865	.8865	.9054
12	.7545	.679	.7922	.9242	.8676	.8488	.8299
13	.7922	.679	.8865	.8299	.8299	.8676	.8676
14	.811	.6602	.8215	.6602	.8488	.8865	.9054
15	.811	.7356	.8215	.7922	.8299	.7922	.8488
16	.8299	.8488	.8775	.811	.811	.9054	.9054
17	.8299	.8775	.9335	.8589	.9149	.9522	.9335
18	.8676	.7655	.9896	.9808	1.0082	.9335	1.0082
19	1.1317	1.2883	1.1203	1.1128	1.251	1.1949	1.1389
20	1.1506	1.1949	1.1949	1.1203	1.2696	1.2323	1.1763
21	1.094	1.2637	1.1949	1.1203	1.251	1.2136	1.1576
22	1.0185	1.0269	1.0829	1.1016	1.1203	1.226	1.1576
23	.9619	1.0269	1.0829	1.0456	1.0456	1.0456	1.0456
24	.8402	.8676	.8962	.9522	.9335	.9709	.9709
Max	1.1506	1.2883	1.1949	1.1763	1.3203	1.2883	1.2323
Min	.7095	.6602	.7468	.6602	.7888	.7922	.8299
Avg	.9082	.9114	.9537	.9569	.9926	.9986	.9949

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044220 / 33KV jadhavwadi s.s

Feeder No / Name : 202 / 11kv mayur park

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.7545	.7468	.7468	.7356	.7468	.7922
2	.6722	.679	.7095	.7095	.7167	.7095	.7282
3	.6348	.6413	.6722	.6722	.7167	.7095	.7167
4	.7842	.7545	.7282	.7468	.7733	.8215	.7842
5	1.0456	.8676	.9709	1.0082	1.0374	1.0082	1.0456
6	1.1949	1.0562	1.1949	1.1203	1.1694	1.1949	1.2637
7	1.4377	1.226	1.3443	1.2883	1.3392	1.3256	1.3817
8	1.1763	1.2637	1.3443	1.587	1.226	1.3443	1.307
9	.9054	1.1883	1.0456	1.4523	1.0751	1.0751	.9997
10	.9054	.9242	.8488	1.2826	.9431	.9808	.9242
11	.7545	.6602	.7922	.9242	.8299	.8676	.811
12	.6979	.679	.7167	.7922	.7545	.8299	.7733
13	.6224	.8299	.7356	.7922	.7545	.7167	.7356
14	.5281	.7167	.6722	.811	.6979	.6602	.7356
15	.4715	.7095	.6908	.7922	.7545	.679	.7545
16	.7356	.7733	.7167	.8299	.7167	.7356	.7733
17	.8299	.7468	.7842	.8865	.8029	.8029	.7655
18	.9054	.8402	.8215	.9335	.8775		.7468
19	1.094	1.0269	1.0456	1.1203	1.1389	1.0829	1.1203
20	1.1317	1.1016	1.0829	1.0642	1.1949	1.1389	1.1576
21	1.0562	1.094	1.0642	1.0829	1.1576	1.1203	1.1203
22	.9054	.9522	1.0082	.9896	1.0082	1.0829	1.0829
23	.9054	.9149	.9335	.9619	.9335	.9335	.9522
24	.9335	.7922	.8029	.8029	.7842	.8589	.8589
Max	1.4377	1.2637	1.3443	1.587	1.3392	1.3443	1.3817
Min	.4715	.6413	.6722	.6722	.6979	.6602	.7167
Avg	.8781	.8830	.8947	.9749	.9224	.9315	.9305

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044220 / 33KV jadhavwadi s.s

Feeder No / Name : 204 / 11kv shivneri feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9335	1.0185	1.0269	1.0082	1.0185	1.0082	1.0269
2	.8962	.9054	.9709	.9709	.9997	.9709	.9896
3	.8589	1.0185	.9335	.9335	.9619	.9335	.9522
4	.9709	1.0185	1.0082	1.0456	1.094	1.0829	1.0562
5	1.2696	1.1694	1.2696	1.307	1.358	1.4563	1.2826
6	2.0538	1.5844	1.7177	1.7551	1.8107	1.8298	2.0165
7	2.3899	2.1691	2.3152	2.2592	2.2068	2.1285	2.3899
8	2.0725	2.1125	2.3712	2.0351	2.037	1.9978	2.2592
9	1.6975	1.8861	1.7924	1.9993	1.8673	1.9616	1.8107
10	1.7353	1.6975	1.4937	1.8484	1.5089	1.6221	1.6598
11	1.4146	1.4146	1.2696	1.6598	1.3203	1.358	1.3957
12	1.1694		1.2323	1.4146	1.1317	1.1883	1.2826
13	1.0374		1.0269	1.2449	1.094	1.0185	1.0562
14	.9431		.9709	1.1317	1.0185	.9431	1.0185
15	.9431	1.0562	.9709	1.0562	1.0185	.9054	1.0185
16	.9997	1.1763	.9896	1.1317	.9808	.8865	.9808
17	1.1883	1.2696	1.0829	1.2323	1.1763	1.1763	1.1203
18	1.358	1.4937	1.3443	1.5684	1.3817	1.4003	1.4377
19	1.7353	1.8298	1.8111	1.7737	1.8298	1.8671	1.8111
20	1.8296	1.7737	1.6804	1.8298	1.6804	1.8671	1.8111
21	1.6221	1.531	1.5123	1.5497	1.5497	1.6263	1.531
22	1.5466	1.4937	1.363	1.4003	1.3817	1.4563	1.3817
23	1.1883	1.2136	1.1949	1.2197	1.2136	1.1949	1.2323
24	.9709	1.0751	1.0642	1.0829	1.0456	1.1203	1.1016
Max	2.3899	2.1691	2.3712	2.2592	2.2068	2.1285	2.3899
Min	.8589	.9054	.9335	.9335	.9619	.8865	.9522
Avg	1.3677	1.4242	1.3505	1.4358	1.3619	1.375	1.4009

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044220 / 33KV jadhavwadi s.s

Feeder No / Name : 205 / 11kV Aarti

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4481	.415	.4108	.4481	.4338	.4481	.4338
2	.4108	.3772	.3734	.4108	.415	.4108	.415
3	.3734	.3772	.3734	.3734	.415	.4108	.4108
4	.4481	.4527	.4481	.4108	.4904	.4854	.5093
5	.5228	.5281	.5228	.4854	.6036	.5601	.5975
6	.6348	.679	.6348	.5601	.679	.7095	.7095
7	.8215	.7545	.7842	.7095	.7922	.8589	.7468
8	.8029	.9054	.8402	.8029	.7733	.8029	.8402
9	.4338	.8488	.7095	.7545	.6036	.6979	.6602
10	.4338	.7545	.5658	.679	.5281	.6036	.5281
11	.3772	.547	.6036	.6602	.5093	.5658	.5847
12	.4338	.6413	.5788	.5658	.4527	.5658	.4527
13	.3206	.5658	.5228	.4904	.4527	.5281	.415
14	.4527	.4904	.4854	.4527	.3772	.4904	.4527
15	.4527	.4854	.4668	.4527	.3961	.4527	
16	.415	.4668	.4668	.415	.4527	.4527	.4715
17	.4904	.3921	.5975	.5041	.5601	.5847	.5415
18	.5281	.6602	.5975	.6161	.7095	.6161	.7282
19	.7167	.7095	.7282	.7095	.7655	.811	.7842
20	.679	.679	.6722	.6224	.7095	.6722	.7282
21	.6036	.6161	.5975	.5975	.6535	.5975	.6722
22	.5658	.5601	.5415	.5658	.5975	.6036	.6161
23	.5281	.5228	.5228	.5228	.5228	.5415	.5601
24	.4668	.4715	.4481	.4854	.4668	.4854	.5093
Max	.8215	.9054	.8402	.8029	.7922	.8589	.8402
Min	.3206	.3772	.3734	.3734	.3772	.4108	.4108
Avg	.5150	.5792	.5622	.5540	.5567	.5815	.5812

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044224 / 33KV ROSHAN GATE

Feeder No / Name : 201 / 11KV JASWANTPURA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4146	1.3203	1.358	1.4712	1.3769	1.4712	1.4098
2	1.3769	1.3014	1.3014	1.3203	1.3203	1.4146	1.3336
3	1.3203	1.2826	1.2826	1.3014	1.3203	1.358	1.2955
4	1.4901	1.4523	1.4146	1.6032	1.4146	1.6032	1.2955
5	1.5466	1.6032	1.4712	1.7541	1.4901	1.6598	1.3146
6	1.5844	1.6598	1.5089	1.8861	1.5844	1.7353	1.6385
7	2.2068	2.1313	2.0748	1.6598	1.8861	2.037	2.2481
8	2.4143	2.6029	2.1879	2.2822	2.1879	2.3388	2.4006
9	2.4331	2.8858	2.4143	2.6217	2.4709	2.2445	2.5911
10	2.3011	3.0367	2.3577	2.6406	2.2257	2.4143	2.4143
11	2.2822	2.9047	2.2634	2.6406	2.3388	2.452	2.3388
12	2.1879	2.7726	2.037	2.3577	2.1879	2.2634	2.3388
13	1.8673	2.6406	2.0182	2.1125	2.1125	2.1879	2.1879
14	1.8484	2.037	1.7541	1.9805	1.8861	1.9616	1.8861
15	1.6032	1.6975	1.6975	1.6975	1.6975	1.8861	1.7353
16	1.6409	1.5466	1.6221	1.6975	1.6975	1.6975	1.7164
17	1.8296	1.7909	1.8671	1.6194	1.6598	1.5089	1.905
18	2.0957	2.1148	2.1338	1.9433	2.1148	1.8107	2.4143
19	2.5463	2.4768	2.572	2.5149	2.5149	2.5086	2.6595
20	2.5339	2.1338	2.3053	2.3243	2.5911	2.6406	2.4331
21	2.2481	1.9433	2.1338	2.191	2.3053	2.3765	2.0748
22	1.8861	1.8107	1.8107	1.8107	2.037	2.191	1.9243
23	1.6975	1.7353	1.6598	1.6598	1.8107	2.0005	1.8099
24	1.5278	1.5466	1.5278	1.5089	1.5089	1.5466	1.6194
Max	2.5463	3.0367	2.572	2.6406	2.5911	2.6406	2.6595
Min	1.3203	1.2826	1.2826	1.3014	1.3203	1.358	1.2955
Avg	1.9118	2.0178	1.8656	1.9416	1.9058	1.9712	1.9577

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044224 / 33KV ROSHAN GATE

Feeder No / Name : 202 / 11 Kv JAKATNAKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.4715	.4904	.5281	.4715	.5281	.4954
2	.4715	.4338	.4715	.4715	.4338	.4904	.4572
3	.4715	.415	.4338	.4294	.415	.4715	.4382
4	.5281	.5281	.5281	.4904	.5281	.6036	.4382
5	.5658	.6036	.547	.547	.6036	.6224	.4763
6	.6036	.6413	.5658	.6036	.6413	.6602	.5716
7	.7356	.6413	.6036	.5847	.6979	.7733	.724
8	.7167	.7167	.7545	.6602	.6602	.7733	.7049
9	.7545	.8299	.7356	.5847	.7922	.7922	.7811
10	.8299	.9808	.7922	.7922	.7922	.811	.811
11	.811	.9808	.7922	.8488	.8488	.7733	.7733
12	.7545	1.0374	.7545	.811	.7545	.8488	.7545
13	.7922	.9054	.6979	.7733	.6979	.5847	.5281
14	.6979	.679	.679	.6979	.6602	.7356	.6413
15	.6036	.5658	.6602	.679	.6602	.7167	.6413
16	.6224	.5281	.679	.6413	.6036	.6036	.679
17	.5847	.6859	.6478	.6097	.679	.6413	.7545
18	.7621	.7621	.7621	.724	.7621	.547	.8299
19	.8865	.8764	.9335	.8192	.8192	.8865	.8676
20	.8573	.8764	.8954	.7621	.8573	.8865	.9054
21	.8383	.8383	.8383	.724	.8192	.811	.811
22	.7167	.6979	.7167	.6602	.7207	.7049	.7811
23	.6036	.679	.6413	.6036	.679	.6668	.7049
24	.5658	.5281	.5658	.5658	.5658	.5658	.5906
Max	.8865	1.0374	.9335	.8488	.8573	.8865	.9054
Min	.4715	.415	.4338	.4294	.415	.4715	.4382
Avg	.6777	.7043	.6744	.6505	.6735	.6874	.6734

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044224 / 33KV ROSHAN GATE

Feeder No / Name : 203 / 11 KV AZAD CHOWK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.226	1.3203	1.2826	1.3203	1.3203	1.2826	1.2384
2	1.1694	1.2826	1.2637	1.2826	1.3014	1.226	1.2003
3	1.1317	1.2449	1.2449	1.2449	1.2826	1.2071	1.1622
4	1.4335	1.4901	1.4712	1.4523	1.4335	1.4146	1.1431
5	1.4901	1.6598	1.5089	1.4712	1.5278	1.4712	1.3908
6	1.5466	1.7353	1.5466	1.5089	1.5844	1.5466	1.6766
7	1.7918	1.9427	1.6975	1.7353	1.9239	1.8861	2.0576
8	2.1502	2.3388	1.9239	2.0748	2.1502	2.0559	2.21
9	2.0559	2.584	1.9936	2.1125	2.0559	2.0936	2.2672
10	1.8673	2.6029	1.9427	2.1691	2.0748	1.9805	2.2068
11	1.8484	2.452	1.9427	2.1125	1.6221	1.9427	2.0182
12	1.6975	2.3954	1.6032	1.8861	1.6598	1.8484	1.9239
13	1.6221	2.1313	1.5466	1.6975	1.6598	1.6975	1.8107
14	1.3769	1.6221	1.4146	1.5089	1.6598	1.5844	1.4712
15	1.2637	1.3203	1.2826	1.358	1.3392	1.6032	1.3957
16	1.358	1.3014	1.226	1.3769	1.4335	1.4712	1.4335
17	1.5844	1.5623	1.5813	1.3336	1.5655	1.5844	1.6221
18	2.0005	1.9052	1.9052	1.7147	1.9052	1.9239	1.9616
19	2.191	2.1338	2.2291	2.0005	2.0957	2.1502	2.2068
20	2.0005	2.0767	2.0576	1.7337	1.9052	1.9993	1.9993
21	1.7528	1.9433	1.6956	1.6194	1.8099	1.773	1.6975
22	1.6598	1.6975	1.6598	1.6221	1.6221	1.7147	1.6004
23	1.5089	1.5466	1.5466	1.5089	1.5089	1.5813	1.5051
24	1.4146	1.4146	1.4146	1.3769	1.3769	1.358	1.3717
Max	2.191	2.6029	2.2291	2.1691	2.1502	2.1502	2.2672
Min	1.1317	1.2449	1.226	1.2449	1.2826	1.2071	1.1431
Avg	1.6309	1.8210	1.6242	1.6342	1.6591	1.6832	1.6904

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044224 / 33KV ROSHAN GATE

Feeder No / Name : 204 / 11KV A'BAD TIMES COLONY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.358	1.226	1.4146	1.2826	1.226	1.3203	1.3336
2	1.2826	1.1883	1.226	1.226	1.1883	1.3014	1.2955
3	1.226	1.1694	1.1883	1.1883	1.1694	1.2826	1.2765
4	1.3769	1.358	1.2826	1.2826	1.2449	1.4523	1.2765
5	1.3957	1.4146	1.358	1.3203	1.358	1.4901	1.3336
6	1.4335	1.4712	1.3957	1.358	1.4335	1.5089	1.4098
7	1.5089	1.5089	1.3203	1.358	1.5089	1.5844	1.5432
8	1.6221	1.7353	1.9239	1.5089	1.5844	1.6975	1.6575
9	1.773	1.9239	1.6975	1.773	1.6598	1.7353	1.7718
10	1.7353	2.2822	1.7541	1.9805	1.8107	1.8107	1.7918
11	1.7164	2.3954	1.7353	2.0559	1.7541	1.8107	1.7541
12	1.7541	2.4709	1.7353	2.0748	1.7353	1.7918	1.7353
13	1.4146	2.2634	1.7541	2.1502	1.4335	1.7353	1.773
14	1.2637	1.8861	1.6221	1.7353	1.4146	1.6221	1.5844
15	1.5466	1.5844	1.5089	1.6221	1.5278	1.6032	1.5466
16	1.4712	1.4146	1.5089	1.6221	1.4146	1.4712	1.4712
17	1.5844	1.4289	1.5242	1.6194	1.5089	1.5466	1.6032
18	1.8099	1.7147	1.7147	1.7528	1.7147	1.7353	1.7918
19	2.0005	1.9814	1.9814	1.9814	2.0005	2.0182	2.0182
20	2.0576	2.0386	1.9433	1.9052	2.0576	1.9616	2.2068
21	2.0576	2.0005	1.8861	1.829	2.0576	1.9616	2.0936
22	1.8107	1.8107	1.773	1.773	1.8107	1.9052	2.0576
23	1.5089	1.6975	1.7353	1.773	1.8107	1.7528	1.9433
24	1.5089	1.358	1.5466	1.5278	1.4901	1.5089	1.5813
Max	2.0576	2.4709	1.9814	2.1502	2.0576	2.0182	2.2068
Min	1.226	1.1694	1.1883	1.1883	1.1694	1.2826	1.2765
Avg	1.5924	1.7218	1.6054	1.6542	1.5798	1.6503	1.6604



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 004801 / 220 KV PADEGAON SUB STATION

Feeder No / Name : 705 / 132 KV GARWARE FEEDER- NON SHEDDABLE EHV INDUSTRIAL FEEDERS  
WALUJ Feeder KV- 132 / (CONTINOUS PROCESS)(NO STAGGERING  
OUTGOING

DATE	12-MAR-18
HR	Load (MW)
1	38.6375
Max	38.6375
Min	38.6375
Avg	38.6375

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 004901 / 400KV WALUJ S/STN

Feeder No / Name : 401 / 33 KV TAYO LUCID  
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-18
HR	Load (MW)
1	6.3443
2	5.6013
3	5.487
4	5.3727
5	5.4298
6	5.4298
7	4.8011
8	5.5441
9	6.4586
10	6.23
11	6.6301
12	6.5158
13	6.4015
14	6.5729
15	6.7444
16	6.2872
24	5.144
Max	6.7444
Min	4.8011
Avg	5.9409

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 004901 / 400KV WALUJ S/STN

Feeder No / Name : 402 / 33 KV SIEMENCE  
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-18
HR	Load (MW)
1	6.1728
2	5.6013
3	5.3727
5	5.487
6	4.5153
7	4.8583
8	5.3155
9	5.3727
10	6.0585
11	5.6013
12	5.487
13	6.2872
14	6.1728
15	5.6013
16	5.6013
24	5.0869
Max	6.2872
Min	4.5153
Avg	5.5370

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 004901 / 400KV WALUJ S/STN

Feeder No / Name : 403 / 33 KV STARLITE CKT NO I NON SHEDDABLE EHV INDUSTRIAL FEEDERS  
Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING

DATE	08-MAR-18
HR	Load (MW)
1	7.8304
2	7.7161
3	7.7161
4	7.7732
5	7.8875
6	8.1733
7	7.5446
8	7.8875
9	7.9447
10	7.8304
11	7.8875
12	8.1733
13	8.059
14	7.7161
15	8.0018
16	8.059
24	7.4303
Max	8.1733
Min	7.4303
Avg	7.8606

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 004901 / 400KV WALUJ S/STN

Feeder No / Name : 404 / 33 KV STARLITE CKT NO II      NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 33 / OUTGOING      (CONTINOUS PROCESS)(NO STAGGERING)

DATE	08-MAR-18
HR	Load (MW)
1	3.8295
2	3.8295
3	3.7723
4	3.7723
5	3.8295
6	4.0009
7	3.9438
8	3.8866
9	3.9438
10	4.0581
11	4.1152
12	4.0581
13	4.0581
14	4.0009
15	4.0581
16	4.1152
24	3.8295
Max	4.1152
Min	3.7723
Avg	3.9471

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 004901 / 400KV WALUJ S/STN

Feeder No / Name : 405 / 33 KV Rural (Turkabad)  
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	08-MAR-18
HR	Load (MW)
1	6.7444
2	6.973
3	8.5734
4	9.0306
5	9.4879
6	11.4884
7	13.2602
8	12.8601
9	7.2588
10	6.2872
11	8.6877
12	8.1162
13	8.5162
14	8.0018
15	7.7732
16	8.3448
24	6.8587
Max	13.2602
Min	6.2872
Avg	8.7213

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 004901 / 400KV WALUJ S/STN

Feeder No / Name : 408 / 33 KV WOCKHARDT BIO EXP  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EHV INDUSTRIAL FEEDERS  
(CONTINOUS PROCESS)(NO STAGGERING

DATE	08-MAR-18
HR	Load (MW)
1	4.2295
2	4.1152
3	4.0009
4	4.0009
5	4.1152
6	4.0581
7	4.1724
8	4.0009
9	4.1152
10	4.2867
11	4.5153
12	4.3439
13	4.2867
14	4.5725
15	4.2867
16	4.4582
24	4.0009
Max	4.5725
Min	4.0009
Avg	4.2094

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 004901 / 400KV WALUJ S/STN

Feeder No / Name : 409 / 33KV M-SECTOR FEEDER  
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	08-MAR-18
HR	Load (MW)
1	6.0014
2	5.8299
3	5.7728
4	5.9442
5	5.7728
6	5.9442
7	5.7728
8	6.6873
9	7.8304
10	8.9163
11	9.0306
12	8.2876
13	7.5446
14	8.8592
15	8.5734
16	9.145
24	5.7728
Max	9.145
Min	5.7728
Avg	7.1580



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 004901 / 400KV WALUJ S/STN

Feeder No / Name : 410 / 33 KV E + H EXP.  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-MAR-18
HR	Load (MW)
1	.0572
2	.0572
3	.0572
4	.0572
5	.0572
6	.0572
7	.0572
8	.1715
9	.1715
10	.1715
11	.2858
12	.0572
13	.0572
14	.0572
15	.0572
16	.2286
24	.1143
Max	.2858
Min	.0572
Avg	.1043

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 004901 / 400KV WALUJ S/STN

Feeder No / Name : 411 / 33 KV V.A. ENGINEERS

FEEDER Feeder KV- 33 /  
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINOUS PROCESS)(NO STAGGERING)

DATE	08-MAR-18
HR	Load (MW)
1	.0572
2	.0572
3	.0572
4	.0572
5	.0572
6	.0572
7	.0572
8	.0572
9	.0572
10	.0572
11	.0572
12	.0572
13	.0572
14	.3429
15	.0572
16	.2286
24	.0572
Max	.3429
Min	.0572
Avg	.0841

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 004901 / 400KV WALUJ S/STN

Feeder No / Name : 412 / 33 KV Orchid Feeder  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINOUS PROCESS)(NO STAGGERING)

DATE	08-MAR-18
HR	Load (MW)
1	2.8578
2	2.8578
3	2.9721
4	2.8578
5	2.9721
6	2.9721
7	2.7435
8	2.7435
9	2.9721
10	2.9721
11	2.9721
12	3.0293
13	2.9721
14	2.9721
15	3.0293
16	2.8578
24	3.0864
Max	3.0864
Min	2.7435
Avg	2.9318

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 004901 / 400KV WALUJ S/STN

Feeder No / Name : 416 / ENDURANCE EXPRESS (K-Sector) F Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-MAR-18
HR	Load (MW)
1	5.487
2	5.4298
3	5.487
4	5.3727
5	5.4298
6	5.2584
7	4.6868
8	5.4298
9	5.7728
10	5.7156
11	5.8871
12	5.8871
13	5.8871
14	5.487
15	6.1728
16	6.0014
24	5.3727
Max	6.1728
Min	4.6868
Avg	5.5744

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 201 / 11 KV E+H

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.8485	3.3913	2.2481	3.315	3.2198	3.6199	3.0102
2	3.5437	3.3341	2.191	3.1245	3.2388	3.4484	3.0483
3	3.2769	3.1436	2.1719	2.8197	3.2007	3.3913	3.1055
4	3.2388	3.1055	2.1338	2.5149	3.315	3.2007	3.1436
5	3.1817	3.0674	2.1148	2.4768	3.2579	2.8959	3.1626
6	3.2769	3.0102	2.3815	2.6863	3.2769	2.8578	3.1245
7	2.4768	2.7625	2.4958	2.3053	3.3341	3.2388	3.4294
8	3.315	2.7435	3.1626	2.8769	3.4103	3.2769	3.4484
9	4.1724	3.3722	3.7723	3.6199	4.763	3.9628	4.0771
10	5.9061	3.6961	3.9057	4.382	4.6677	5.3346	4.4772
11	5.144	3.6199	4.5725	4.0009	4.8773	5.2393	5.1059
12	4.1914		4.401	4.3439	4.0962	4.382	4.1914
13	4.3629		4.382	4.0962	4.382	4.4772	4.382
14	5.506		4.9535	4.763	4.763	5.4298	4.6677
15	4.4772	2.8578	4.6487	4.0009	5.6203	5.506	5.0488
16	5.6775	3.0483	5.5251	4.382	5.5251	6.0966	4.0009
17	5.5632	3.6199	5.2393	4.2867	5.2393	5.0678	5.3346
18	4.9726	3.2388	4.1152	4.1343	4.6296	4.5344	4.7058
19	4.039	2.5339	3.7723	3.2007	4.02	4.02	3.7723
20	2.9531	2.5339	3.4675	3.0674	3.4865	3.1055	3.4484
21	3.3722	2.3053	3.3913	2.9912	3.6389	3.1055	3.8104
22	2.8006	2.4006	3.4675		3.6961	3.7913	3.8866
23	1.8099	2.3053	3.6199		3.7532	3.7913	3.9438
24	3.9438	3.4294	2.2481	2.8387		3.0102	2.9531
Max	5.9061	3.6961	5.5251	4.763	5.6203	6.0966	5.3346
Min	1.8099	2.3053	2.1148	2.3053	3.2007	2.8578	2.9531
Avg	3.9604	3.0247	3.5159	3.4649	4.0614	4.0327	3.8866

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 202 / 11 KV GARWARE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.915	3.0483	2.553	3.0102	2.3624	2.8769	2.7816
2	2.7816	3.0864	2.4958	2.7816	2.3243	2.8197	2.7625
3	2.8006	2.9531	2.5149	2.7435	2.3815	2.7054	2.7244
4	2.8578	2.8578	2.4768	2.6863	2.3434	2.6292	2.7435
5	2.8197		2.5339	2.6673	2.3624	2.5911	2.7435
6	2.7435	2.8578	2.8197	2.6101	2.3815	2.6482	2.7435
7	2.4768	2.8197	2.8769	2.3243	2.4768	2.6673	2.8006
8	3.3722	2.7435	3.5818	2.6292	3.4103	3.5627	3.5818
9	3.9819	2.9531	3.9057	2.8769	4.0962	3.677	3.9247
10	4.2867	2.7435	4.02	3.1436	4.0009	4.2295	4.0009
11	4.4772	2.9531	3.7913	3.3341	4.1152	4.1914	4.2295
12	4.0962		4.02	3.3341	4.0009	3.6199	3.7151
13	4.0009		3.7913	3.1436	3.5246	3.7151	3.8104
14	4.0009		4.039	3.1436	4.2867	4.3439	4.2867
15	4.2295	2.6673	4.1152	3.0864	4.1914	4.1914	4.1914
16	4.1914	2.6673	4.1914	2.7054	4.0962	4.0962	4.4772
17	4.2867	2.572	4.2295	2.8578	4.2867	3.9057	3.7723
18	4.2295	2.572	3.9247	2.6863	3.6008	3.6389	3.8485
19	3.0102	2.3243	2.9531	2.5339	2.8006	2.8197	2.8578
20	2.9531	2.5339	2.934	2.4577	2.8959	2.7816	2.8578
21	3.1245	2.3243	2.934	2.2862	2.9721	2.7625	2.8197
22	3.0674	2.572	3.0483		2.8959	2.7816	2.8578
23	3.0674	2.6673	3.1245		2.934	3.1626	2.8769
24	2.9912	3.0674	2.572	3.0293		2.6482	2.7435
Max	4.4772	3.0864	4.2295	3.3341	4.2867	4.3439	4.4772
Min	2.4768	2.3243	2.4768	2.2862	2.3243	2.5911	2.7244
Avg	3.4484	2.7492	3.3103	2.8214	3.2496	3.2944	3.3397

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 203 / 11 KV KESONA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1338	1.9052	1.6766	1.7147	1.3146	2.0767	1.8861
2	2.0576	1.9624	1.6194	1.6385	1.3336	1.8861	1.9624
3	1.9814	2.0005	1.6385	1.6766	1.2955	1.9433	2.0195
4	1.9433	2.0195	1.6194	1.7147	1.3146	1.9243	2.0005
5	1.9052	2.0576	1.6385	1.6766	1.3146	1.848	2.0576
6	2.2672	2.0005	1.829	1.7718	1.2955	1.9243	1.8671
7	1.8099	1.9052	1.829	1.6575	1.4289	2.0957	1.9243
8	2.2862	1.8099	2.191	1.6004	2.0576	2.1719	2.2481
9	2.4006	1.8099	2.2481	1.9814	2.6292	2.7244	2.4958
10	3.9057	2.0005	2.7625	2.4768	2.7625	3.1436	3.1436
11	3.3341	2.0386	2.6863	2.2862	2.8197	3.1436	3.4294
12	2.6482		2.6292	2.3243	2.7816	2.8197	2.6673
13	2.8197		2.8197	2.0005	2.4768	2.4387	2.8578
14	3.5246		3.0483	2.0767	2.8578	3.0483	2.8959
15	3.0293	1.6385	2.3815	2.0576	3.5246	2.9531	2.915
16	3.2007	1.6194	2.8578	2.0957	3.2007	3.9628	3.0102
17	3.0864	1.6194	2.9531	1.6194	3.0483	3.1626	2.9531
18	2.4958	1.6194	2.5339		2.6673	2.7435	2.6673
19	2.0195	1.6766	1.9814	1.448	2.0957	2.1148	2.5149
20	2.0005	1.6766	1.8671	1.4289	2.0005	1.9052	2.0005
21	2.1148	1.6766	1.7718	1.3717	2.0957	1.9624	1.8671
22	1.848	1.6194	1.7528		2.1338	2.0005	1.8861
23	1.9052	1.8099	1.7147		2.1719	1.8861	1.8671
24	2.1338	1.8861	1.6766	1.7337		1.9052	1.8099
Max	3.9057	2.0576	3.0483	2.4768	3.5246	3.9628	3.4294
Min	1.8099	1.6194	1.6194	1.3717	1.2955	1.848	1.8099
Avg	2.4521	1.8263	2.1553	1.8263	2.2009	2.4077	2.3728

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672]

BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 204 / 11 KV HIRA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8197	3.2388	1.9052	2.7435	2.3624	2.6673	3.1436
2	2.6292	3.0674	1.8671	2.6482	2.4577	2.5911	3.0483
3	2.5149	2.4768	1.829	2.6863	2.3243	2.5149	2.9531
4	2.4768	.8573	1.8099	2.7054	2.4006	2.4387	2.8197
5	2.4387	2.0576	1.7528	2.553	2.4387	2.2862	2.4958
6	2.7435	2.0005	2.0576	2.6673	2.4387	2.7054	2.8197
7	2.4006	1.8099	2.1148	2.0195	2.3624	2.4387	2.3624
8	2.1719	1.6766	2.21	2.1719	2.2862	2.4006	3.0483
9	2.8578	1.6194	2.8578	2.5149	3.1436	3.0102	3.0674
10	3.5246	1.9052	3.0864	2.572	3.5246	3.3341	3.0864
11	3.8485	1.9052	3.8104	3.1436	3.4294	3.8104	3.8104
12	3.2388		3.4484	3.7151	3.0483	2.8578	2.6673
13	3.5246		2.6673	2.7625	2.7625	2.8578	3.0864
14	3.5246		3.4294	3.1436	3.4675	3.1436	2.9531
15	3.1436	2.0957	2.9721	2.7054	3.4294	3.3341	3.4294
16	3.8104	1.8861	3.4294	2.6673	3.5246	3.5246	3.1436
17	3.1436	1.7147	3.5056	2.8959	3.4675	3.0864	3.1436
18	3.8104	1.5242	3.1245	2.8197	3.4294	3.2007	3.2388
19	2.7435	1.5242	2.6292	2.4006	2.8578	2.5339	2.8959
20	2.8769	1.5242	2.5911	2.3624	2.2481	2.4958	2.4387
21	2.8959	1.9052	2.6673	2.2862	2.2291	2.7435	2.8578
22	2.8769	2.21	2.5149		2.2481	3.1626	2.8197
23	2.3053	1.7147	2.0195		2.2862	2.7054	2.6673
24	2.8578	3.4294	1.9052	2.5911		2.4768	3.1626
Max	3.8485	3.4294	3.8104	3.7151	3.5246	3.8104	3.8104
Min	2.1719	.8573	1.7528	2.0195	2.2291	2.2862	2.3624
Avg	2.9658	2.0068	2.5919	2.6716	2.7899	2.8467	2.9650



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 205 / GANGA MAI I  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0762	.1143	.0381	.0953	.0953
2	.0191	.0762	.0572	.0762	.0381	.0572	.0572
3	.0381	.0762	.0381	.0572	.0381	.0572	.0762
4	.0191	.0762	.0381	.0572	.0381	.0572	.0762
5	.0381	.0762	.0381	.0762	.0381	.0572	.0762
6	.0572	.0762	.0381	.0762	.0381	.0572	.0953
7	.0381	.0953	.0572	.0381	.0762	.0381	.0572
8	.0572	.0953	.0953	.1143	.1143	.1143	.1143
9	.0762	.0953	.1143	.1334	.1715	.1334	.1334
10	.1905	.1143	.1334	.1334	.1715	.1905	.1715
11	.1715		.1524	.1524	.1715	.2096	.1715
12	.1715		.1715	.1524	.1905	.1905	.1715
13	.1143		.1334	.1143	.1143	.0953	.0953
14	.1715		.1715	.1715	.1905	.2096	.1715
15	.1715	.1143	.1715	.1334	.1715	.1715	.1715
16	.1715	.1143	.1524	.1143	.1715	.2096	.1715
17	.1715	.1143	.1715		.1715	.1715	.1524
18	.1524	.0953	.1715	.0762	.1524	.1715	.1334
19	.0953	.0381	.0762	.0762	.0953	.1143	.0953
20	.0953	.0953	.0762	.0572	.0572	.1143	.0953
21	.0953	.0572	.0762	.0381	.0572	.0762	.0762
22	.1143	.0572	.0762		.0572	.1143	.0762
23	.1334	.0762	.0953		.0762	.0953	.0762
24	.0953	.1143	.0762	.0953		.0953	.0953
Max	.1905	.1143	.1715	.1715	.1905	.2096	.1715
Min	.0191	.0381	.0381	.0381	.0381	.0381	.0572
Avg	.1064	.0877	.1024	.0980	.1060	.1207	.1127

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 207 / 11 KV ADEEP

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0483	2.9531	2.2481	3.0483	2.3624	3.0293	2.9721
2	2.7054	2.8578	2.0957	2.8959	2.3053	2.8197	2.8197
3	2.7054	2.4768	2.0005	2.7054	2.3243	2.8769	2.8387
4	2.5149	2.572	1.9624	2.6863	2.2672	2.7054	2.6292
5	2.4387	2.3815	1.8861	2.4577	2.2862	2.4577	2.5339
6	2.6101	2.3434	2.4387	2.4006	2.2481	2.4958	2.5149
7	2.8197	2.1148	2.7435	2.4006	2.6101	2.8197	2.915
8	3.3913	1.9243	2.9531	2.5149	3.1626	3.2579	3.4484
9	3.6961	2.1148	3.4484	3.4294	4.4772	3.658	4.1152
10	4.0962	2.1148	3.7151	3.5246	4.4772	4.0962	4.1914
11	4.0009	2.0195	4.02	3.7151	4.0009	3.8485	4.0962
12	4.0962		3.8676	3.6961	4.0962	4.1914	4.1152
13	3.9057		3.7151	3.3341	3.9057	3.8104	4.0009
14	4.2867		4.382	3.8295	4.0009	4.0962	4.2295
15	4.2295	2.0957	4.02	3.5246	3.6199	3.7151	4.1914
16	4.1914	2.2481	3.6199	2.6673	4.1914	4.0962	4.0962
17	4.4772	2.3815	3.7913	3.3341	4.0009	4.02	3.9057
18	4.02	2.4768	3.8485	2.7816	3.6008	3.9057	3.4675
19	2.9531	2.0005	3.0483	2.7244	3.1055	3.1626	3.2007
20	3.1626	2.0195	2.9721	2.5149	2.9912	3.1626	2.915
21	3.1626	2.21	2.8769	2.3624	3.0102	2.7435	3.2007
22	3.6389	2.3815	2.8959		3.0864	3.2007	3.0864
23	3.1626	2.3624	2.934		3.1245	2.8769	3.0293
24	2.915	3.0483	2.3243	2.8959		2.9531	2.9531
Max	4.4772	3.0483	4.382	3.8295	4.4772	4.1914	4.2295
Min	2.4387	1.9243	1.8861	2.3624	2.2481	2.4577	2.5149
Avg	3.4262	2.3380	3.0753	2.9747	3.2720	3.3333	3.3944

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 208 / 11 KV RUCHA EXP

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8954	.8954	.9717	.8764	.4572	.8764	1.105
2	.8764	.8954	.9907	.8573	.4572	.8764	1.0098
3	.8954	.8573	1.0098	.8383	.4572	.8764	.9145
4	.8764	.8573	1.0288	.8573	.4763		.9907
5	.8954	.8573	1.0479	.8764	.0953	.8764	.9717
6	.8764	.9145	.9526	.8954	.4763	.7621	.9717
7	.743	.9526	.8383	.7811	.4954	.7049	.9145
8	.9907	1.105	1.1622	.7621	.8954	1.086	1.086
9	.7811	.724	.7811	.6478	.8954	.9145	.7811
10	1.0479	.8764	1.2384	.724	1.1812	1.2384	1.2955
11	.8573	.7811	.9145	.7811	.8383	.9145	.9526
12	1.105		.8764	.724	1.2384	.8573	1.1812
13	1.0479		1.105	.7621	1.4289	1.2574	1.4098
14	1.2574		1.105	.8002	1.1431	1.1812	1.3336
15	1.0479	1.0288	1.1622	.7621	1.448	1.1431	1.3527
16	.9526	1.0669	.9907	.7621	.8573	.9526	.9526
17	1.0288	1.1241	1.0669	.381	1.3336	1.2384	1.1622
18	1.0479	1.0669	1.1431	.4572	1.1622	1.0479	1.1431
19	.7811	1.2765	.724	.4763	.724	.8383	1.1431
20	.9145	.8954	.743	.4572	.8573	1.0479	1.086
21	.9907	.8002	.743	.4572	.7811	.8192	.9907
22	.8002	.8954	.7621		.7811	.8383	.9145
23	.8192	.8764	.7811		.743	.8383	.7811
24	.8002	.8954	.9526	.8002		.7049	.9717
Max	1.2574	1.2765	1.2384	.8954	1.448	1.2574	1.4098
Min	.743	.724	.724	.381	.0953	.7049	.7811
Avg	.9304	.9353	.9621	.7153	.8358	.9518	1.0590

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 401 / 33 KV TAYO LUCID

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.3443	5.8871	5.3155	5.0297	4.1152	5.6584	5.8871
2	5.6013	5.7728	5.3727	4.8011	4.1152	5.6013	5.8299
3	5.487	5.7156	5.2584	4.6868	4.0009	5.487	5.7156
4	5.3727	5.8299	5.3727	4.7439	3.9438	5.487	5.6584
5	5.4298	5.6584	5.4298	4.6296	3.9438	5.7728	5.6013
6	5.4298	5.6013	5.6013	5.0297	3.8866	5.8871	5.2584
7	4.8011	5.6584	5.7728	4.3439	4.1724	5.487	5.2584
8	5.5441	5.7156	5.8871	5.6013	6.1157	6.4015	6.0014
9	6.4586	5.7156	6.3443	5.0297	7.0873	7.2017	6.1728
10	6.23	6.0014	6.3443	5.8299	7.4303	7.4303	6.5729
11	6.6301	6.0014	6.4015	5.487	7.4303	7.2017	7.2588
12	6.5729	5.8299	6.0014	5.2584		6.6301	6.1728
13	6.4586	5.6584	6.4015	5.2584	6.8587	6.5729	6.6301
14	6.5729	5.7728	6.8587	5.3155	7.316	7.1445	6.6301
15	6.7444	5.7728	6.5729	4.9154	6.8016	6.7444	7.0302
16	7.0302	5.8871	6.5158	4.4582	7.316	7.2017	6.973
17	7.0302	5.7156	6.9159	4.0009	8.1162	6.6301	6.1157
18	6.973	5.6013	6.0585	4.401	6.9159	6.3443	6.4015
19	6.1728	5.4298	5.6584	4.0009	6.5158	6.0585	5.6013
20	6.4015	5.3155	5.487	4.1152		6.0585	3.7723
21	6.3443	5.0297	5.4298	4.0009	6.1157	6.7444	5.4298
22	6.3443	5.144	5.4298	4.0581	6.23	5.7728	5.6013
23	6.4586	5.3727	5.3727	4.0009	6.1728	6.6301	5.9442
24	5.144	5.8871	5.3155	5.144	4.1152	5.5441	6.0014
Max	7.0302	6.0014	6.9159	5.8299	8.1162	7.4303	7.2588
Min	4.8011	5.0297	5.2584	4.0009	3.8866	5.487	3.7723
Avg	6.1490	5.6656	5.8799	4.7559	5.8507	6.3205	5.9799

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 402 / 33 KV SIEMENCE

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.1728	5.7156	4.5153	6.1728	4.1724	5.0297	5.6584
2	5.4298	6.0585	4.4582	6.0585	4.0009	5.2584	5.7728
3	5.3727	6.1728	4.2295	6.1157	4.0581	5.3727	5.8299
4	5.6013	6.23	4.1724	6.0585	3.9438	5.2584	5.7728
5	5.487	6.1728	4.1152	6.23	3.9438	5.6013	5.7156
6	4.5153	5.6013	4.1152	4.7439	3.8295	5.8299	5.0869
7	4.8583	4.8583	4.1724	4.5725	4.5153	4.5153	5.8299
8		4.4582	5.144	4.7439	5.2012	6.0585	5.6584
9		5.3155	6.0585	5.6013	6.2872	6.2872	5.8871
10		5.0869	6.973	5.144	6.1157	6.8587	6.4015
11	5.6013	5.144	6.1728	4.9154	6.0014	5.8871	6.5729
12	5.487	5.2012	6.3443	4.7439		6.6873	6.4586
13	6.2872	5.2584	6.5729	5.7156	6.8587	6.1157	7.0873
14	6.1728	5.6584	6.8587	5.144	6.0585	6.1728	7.4874
15	5.6013	5.6013	6.0014	5.2584	6.6873	5.8299	7.8304
16	5.6013	5.5441	6.8016	4.401	5.8871	5.8299	6.6873
17	6.2872	5.4298	6.6301	4.6296	6.4586	6.973	7.4874
18	6.4015	5.144	6.8016	3.658	7.1445	6.7444	7.8875
19	5.2012	4.9154	4.8011	4.2295	5.7728	6.0585	7.3731
20	5.6584	4.8583	5.3727	4.6296	6.4586	5.2584	5.9442
21	6.1728	4.4582	6.1157	4.8011	6.1728	5.144	6.6301
22	6.1728	4.8011	5.6013	4.5725	6.0014	6.5729	5.9442
23	6.7444	5.4298	5.4298	4.5153	5.7156	5.0297	5.4298
24	5.0869	5.3155	4.5153	5.2012	4.3439	4.5153	5.6584
Max	6.7444	6.23	6.973	6.23	7.1445	6.973	7.8875
Min	4.5153	4.4582	4.1152	3.658	3.8295	4.5153	5.0869
Avg	5.7102	5.3512	5.4989	5.0773	5.4621	5.7870	6.3372

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 403 / 33 KV STARLITE CKT NO 1 NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	7.8875	7.7732	7.7161	7.7732	7.7732	7.5446	7.9447
16	8.059	7.7732	8.0018	8.0018	8.4591	7.7732	8.059
24	7.4303	7.7732	7.9447	7.6589	8.0018	7.7732	8.1162
Max	8.059	7.7732	8.0018	8.0018	8.4591	7.7732	8.1162
Min	7.4303	7.7732	7.7161	7.6589	7.7732	7.5446	7.9447
Avg	7.7923	7.7732	7.8875	7.8113	8.0780	7.697	8.0400

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 404 / 33 KV STARLITE CKT NO II NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					3.8866	3.9438	3.9438
2					3.8866	3.8866	3.9438
3					3.8866	3.8295	3.8866
4					3.8866	3.658	3.8866
5					3.8866	3.7723	3.8866
6					3.8866	3.8866	3.8866
7					3.9438	3.8866	3.8866
8	3.8866	4.0009	3.9438	3.7151	3.9438	3.8295	3.8295
9					2.9721	4.0009	4.0581
10					2.915	4.0581	4.0581
11					2.9721	4.1152	4.1152
12					3.0293	4.1152	4.0581
13					3.0293	3.8866	4.0009
14					3.0864	4.0009	4.0581
15					2.915	4.0009	4.0581
16	4.1152	4.4582	4.0009	4.1152	3.1436	4.1152	4.1152
17					3.0293	4.0581	4.1152
18					2.9721	4.0009	3.9438
19					3.7723	3.9438	3.9438
20					3.9438	3.9438	3.8866
21					3.8866	3.9438	3.8866
22					3.8295	3.9438	4.0009
23					3.9438	3.9438	4.0581
24	3.8295	4.0581	3.9438	3.7151	3.8866	4.0009	3.9438
Max	4.1152	4.4582	4.0009	4.1152	3.9438	4.1152	4.1152
Min	3.8295	4.0009	3.9438	3.7151	2.915	3.658	3.8295
Avg	3.9438	4.1724	3.9628	3.8485	3.5223	3.9485	3.9771

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 405 / 33 KV Rural ( Turkabad) NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					6.8016	5.6013	
2					7.2588	6.0585	
3					7.9447	6.2872	7.5446
4					9.0306	7.316	8.0018
5					9.7737	8.1162	8.1162
6					9.7737	9.5451	10.8596
7					10.4024	11.4312	12.6886
8	12.8601	10.0023	8.8592	11.8884	10.8596	11.4312	9.7737
9					6.5729	6.7444	
10					5.7156	5.8299	5.4298
11					8.1162	9.7165	8.2876
12					9.3164	9.4879	7.0873
13					9.145	8.9735	7.5446
14					8.5734	8.9163	8.059
15					8.6306	8.6877	6.6873
16	8.3448	6.3443	8.1162	7.7161	8.8592	9.145	6.7444
17					9.2593	9.3736	8.059
18					8.4591	7.0302	9.3164
19					6.23	5.6584	8.0018
20					5.7156	6.3443	7.4303
21					5.6013	5.6584	5.5441
22					5.487	5.144	5.6013
23					5.7156	6.3443	5.8871
24	6.8587	6.8016	6.7444	6.8016	6.5158	5.7728	
Max	12.8601	10.0023	8.8592	11.8884	10.8596	11.4312	12.6886
Min	6.8587	6.3443	6.7444	6.8016	5.487	5.144	5.4298
Avg	9.3545	7.7161	7.9066	8.8020	7.9066	7.6922	7.8332



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 408 / 33 KV WOCKHARDT BIO EXP NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					3.8295	3.4865	3.7723
2					3.8295	3.4865	3.7151
3					3.7151	3.5437	3.7151
4					3.658	3.4865	3.658
5					3.658	3.5437	3.7151
6					3.658	3.7151	3.6008
7					3.8295	3.7151	3.6008
8	4.0009	4.0581	4.1724	3.8295	3.9438	3.8295	3.7151
9					4.0009	3.7723	4.0009
10					4.2867	4.0581	4.0009
11					4.2867	4.1724	4.1152
12					4.2867	4.1724	4.0581
13					4.3439	4.2295	4.1152
14					4.401	4.2867	3.9438
15					4.3439	4.3439	4.1724
16	4.4582	4.5725	4.2867	4.0009	4.2867	4.2867	4.2867
17						4.0581	4.3439
18					4.0581	3.8295	3.9438
19					3.8866	4.0581	3.7151
20					3.8866	3.8295	3.658
21					3.7723	3.7723	3.8866
22					3.7723	4.0009	3.8295
23					3.7151	3.658	3.7151
24	4.0009	4.0581	4.0581	3.658	3.8295	3.8295	3.7723
Max	4.4582	4.5725	4.2867	4.0009	4.401	4.3439	4.3439
Min	4.0009	4.0581	4.0581	3.658	3.658	3.4865	3.6008
Avg	4.1533	4.2296	4.1724	3.8295	3.9686	3.8819	3.8771

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 409 / 33 KV M - SECTOR FEEDER NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					4.6868	5.8299	5.8871
2					4.5153	5.7728	6.0014
3					4.6296	6.0585	5.8871
4					4.7439	5.9442	6.0014
5					4.6296	5.7156	5.7156
6					4.5725	5.9442	5.7156
7					5.4298	5.2012	5.6584
8	6.6873	5.0297	6.9159	5.6013	6.1157	6.1728	7.2017
9					7.5446	7.316	7.6589
10					8.1162	8.6306	8.802
11					8.7449	6.2872	8.5734
12					8.5162	8.5734	8.4591
13					7.5446	7.2017	7.4303
14					8.4591	9.0878	9.0878
15					8.9163	9.0306	8.9163
16	9.145	6.0014	9.145	6.973	8.6877	8.6877	8.6877
17					8.9735	8.4591	8.8592
18					7.6589	7.7732	7.7161
19					5.9442	6.3443	6.8016
20					5.7728	6.3443	6.1157
21					5.8299	5.6584	5.7156
22					5.8871	6.0014	5.6584
23				6.6301	6.0014	5.6584	5.5441
24	5.7728	6.3443	4.3439	6.6301	4.6296	5.8299	5.8299
Max	9.145	6.3443	9.145	6.973	8.9735	9.0878	9.0878
Min	5.7728	5.0297	4.3439	5.6013	4.5153	5.2012	5.5441
Avg	7.2017	5.7918	6.8016	6.4586	6.5229	6.8135	6.9969

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 410 / 33 KV E+H EXP FEEDER NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0572	.0572	.0572
2					.0572	.0572	.0572
3					.0572	.0572	.0572
4					.0572	.0572	.0572
5					.0572	.0572	.0572
6					.0572	.0572	.0572
7					.0572	.0572	.0572
8	.1715	.4001	.0572	.0572	.0572	.0572	.1715
9					.0572	.2858	.3429
10					.2286	.2286	.2858
11					.1715	.3429	.0572
12					.0572	.3429	.1143
13					.0572	.1143	.0572
14					.1143	.0572	.0572
15					.3429	.1143	.1143
16	.2286	.2286	.1715	.1143	.743	.2286	.2286
17					.5144	.1715	.8573
18					.1715	.2286	.1715
19					.2858	.2286	.1143
20					.1715	.3429	.1143
21					.1143	.1143	.0572
22					.1143	.1715	.0572
23					.1143	.1143	.0572
24	.1143	.1143	.1143	.0572		.1143	.0572
Max	.2286	.4001	.1715	.1143	.743	.3429	.8573
Min	.1143	.1143	.0572	.0572	.0572	.0572	.0572
Avg	.1715	.2477	.1143	.0762	.1615	.1524	.1382

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 411 / 33 KV V.A ENGINEERS FEEDER NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0572	1.0288	
2					.2286	.9717	.5716
3					.5144	.9717	.5144
4					.5716	.9145	.4572
5					.6287	.9145	.4572
6					.3429	.9717	.4572
7					.4001	.2858	.4572
8	.0572	.0572	.0572	.2858	.4572	.4001	.3429
9					.5716	.9717	.8002
10					.5716	.5144	.4572
11					.6859	.4572	.5144
12					.8573	.6287	.5144
13					.8002	.4572	.5144
14					.6859	.5144	.4572
15					.4572	.4572	.4572
16	.2286	.0572	.0572	.2858	.6859	.5144	.5144
17					.743	.4001	.4572
18		.0572			1.0288	.4572	.9145
19					.5144	.4001	.5716
20					.9717	.4001	.2858
21					1.0288	.4572	.4572
22					.9717	.4572	.1143
23					.9717	.6859	.743
24	.0572	.0572	.0572	.0572	.0572	.4572	.5144
Max	.2286	.0572	.0572	.2858	1.0288	1.0288	.9145
Min	.0572	.0572	.0572	.0572	.0572	.2858	.1143
Avg	.1143	.0572	.0572	.2096	.6168	.6120	.5020

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 412 / 33 KV ORCHID FEEDER

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					2.9721	2.9721	2.7435
2					2.9721	2.8578	2.7435
3					2.8578	2.9721	2.6863
4					2.8578	2.9721	2.6863
5					2.8578	2.9721	2.7435
6					2.8578	2.9721	2.6292
7					2.8578	2.6292	2.6292
8	2.7435	2.6292	2.5149	2.6292	2.8578	2.7435	2.7435
9					2.9721	2.9721	2.7435
10					2.9721	3.1436	2.8578
11					2.9721	3.315	3.1436
12					2.9721	3.4294	1.1431
13					2.9721	3.4294	1.1431
14					2.9721	3.4294	3.2007
15					3.0864	3.1436	3.4294
16	2.8578	2.915	2.9721	2.8578	2.9721	3.1436	3.7151
17					2.9721	3.4294	3.315
18					3.0864	3.1436	3.2007
19					3.2007	3.2007	3.2007
20					3.0864	3.0293	3.0864
21					2.9721	3.2007	3.0864
22					2.9721	2.915	2.9721
23					2.9721	3.0293	2.9721
24	3.0864	2.572	2.8578	2.9721	3.0293	2.9721	2.7435
Max	3.0864	2.915	2.9721	2.9721	3.2007	3.4294	3.7151
Min	2.7435	2.572	2.5149	2.6292	2.8578	2.6292	1.1431
Avg	2.8959	2.7054	2.7816	2.8197	2.9697	3.0841	2.8149

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 413 / 33KV Mylan

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4577	2.5149	2.572	2.6292	2.4006		2.6292
2	2.4006	2.572	2.6863	2.6292	2.4006	2.4006	2.5149
3	2.2862	2.572	2.572	2.572	2.4006	2.4006	2.572
4	2.4006	2.572	2.5149	2.572	2.3434	2.4006	2.572
5	2.2862	2.572	2.5149	2.6292	2.3434	2.4577	2.572
6	2.3434	2.572	2.4577	2.6863	2.2862	2.5149	2.572
7	2.2862	2.572	2.4006	2.2862	2.4577	2.4006	2.2862
8	2.4577	2.572	2.7435	2.5149	2.6292	2.572	2.6292
9	2.572	2.6292	2.6292	2.572	2.6863	2.572	2.7435
10	2.6292	2.6863	2.7435	2.8006	2.7435	2.6863	2.7435
11	2.8578	2.7435	2.915	2.5149	3.1436	2.8006	2.915
12	2.8578		2.8006	2.6292	2.8578	2.8006	2.9721
13	2.8578		2.8006	2.6292	2.8578	2.8578	2.9721
14	2.9721		2.8578	2.6292	3.1436	3.0864	3.315
15	2.7435	2.7435	2.8006	2.5149	2.7435	2.8578	3.0864
16	2.915	3.1436	2.8578	2.572	2.7435	2.8578	3.0293
17	2.9721	3.315	2.7435	2.572	2.8578	2.8578	2.9721
18	2.6863	2.6292	2.6292	2.4577	2.572	2.9721	2.8006
19	2.7435	2.6292	2.6292	2.572	2.6863	2.7435	2.7435
20	2.7435	2.6863	2.6292	2.572	2.6292	2.7435	2.7435
21	2.572	3.0864	2.572	2.5149	2.572	2.5149	2.6863
22	2.7435	2.6292	2.6292		2.6292	3.0293	2.6292
23	2.572	2.6292	2.6863		2.572	2.4577	2.6292
24	2.572	2.5149	2.572	2.7435		2.5149	2.5149
Max	2.9721	3.315	2.915	2.8006	3.1436	3.0864	3.315
Min	2.2862	2.5149	2.4006	2.2862	2.2862	2.4006	2.2862
Avg	2.6220	2.6945	2.6649	2.5824	2.6391	2.6739	2.7435

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 414 / 33 KV Varroc ( M-191/3 ) NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8578	2.5149	2.572	3.315	2.2862	2.7435	2.6292
2	2.8578	2.572	2.6292	2.9721	2.4006	2.8006	2.7435
3	2.7435	2.7435	2.7435	2.8578	2.4006	2.8578	2.6292
4	2.7435	2.572	2.8578	2.7435	2.5149	2.7435	2.572
5	2.8578	2.5149	2.8578	2.5149	2.5149	2.8578	2.5149
6	2.6292	3.1436	2.7435	2.6292	2.5149	2.6292	2.5149
7	2.5149	3.8866	2.6292	2.7435	2.6292	2.6292	2.5149
8		4.1152	4.2867	2.6292	2.6292	4.0009	4.1152
9	3.315	3.1436	5.144	2.2291	5.7156	5.0297	3.1436
10	4.6868	5.7156	6.3443	5.7156	5.7156	6.1157	6.1728
11	6.2872	3.4294	6.3443	5.7156	5.7156	5.4298	6.5729
12	5.2584		5.2012	5.144		4.9726	5.7156
13	5.7156		5.8299	2.6292	2.9721	5.9442	6.4015
14	5.2584		6.2872	2.7435	2.9721	5.7156	5.7728
15	5.7156	6.2872	5.7156	2.7435	3.6008		6.2872
16	5.7156	6.0014	6.2872	3.4294	4.0009	3.315	6.1157
17	6.2872	5.7156	6.4015	4.5725	5.7156	3.0864	3.315
18	6.3443	6.2872	3.658	2.2862	3.658	3.4294	3.315
19	2.6292	2.6292	2.9721	2.2862	3.315	2.7435	2.9721
20	2.4006	3.2007	2.9721	2.2862	2.6292	2.6292	2.6292
21	2.9721	2.8578	2.8578	2.2862	2.7435	3.4294	2.7435
22	2.915	2.8578	2.9721		2.7435	2.8578	2.6292
23	3.1436	2.9721	2.7435		2.8578	3.1436	2.7435
24	2.6292	2.6863	2.5149	2.6292		2.6292	2.6292
Max	6.3443	6.2872	6.4015	5.7156	5.7156	6.1157	6.5729
Min	2.4006	2.5149	2.5149	2.2291	2.2862	2.6292	2.5149
Avg	3.9338	3.7070	4.0652	3.1410	3.3748	3.6406	3.8080

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 415 / 33 KV Endurance ( L-6)

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7435	2.572	2.3434	2.6292	1.5432	2.6863	2.572
2	2.8006	2.6292	2.4577	2.6292	1.6575	2.572	2.5149
3	2.8006	2.7435	2.572	2.572	1.7147	2.572	2.6292
4	2.7435	2.572	2.6292	2.6292	1.8861	2.6292	2.572
5	2.8006	2.6292	2.6292	2.572	1.8861	2.5149	2.6292
6	2.8578	2.6863	2.572	2.6292	2.0005	2.6863	2.6292
7	2.6292	2.7435	2.6292	1.8861	2.2291	2.5149	2.572
8	2.6292	2.7435	2.7435	1.6004	2.6292	2.8578	2.6863
9	2.6863	2.6292	2.915	1.2003	2.6292	2.8578	2.6292
10	2.8578	2.915	2.915	1.2574	2.6292	2.8578	2.8578
11	3.0293	2.915	2.915	1.7147	2.7435	2.7435	2.8006
12	3.1436		2.915	1.6575	3.0293	2.572	2.9721
13	2.8578		2.7435	1.3717	2.6292	2.572	2.572
14	2.8578		2.8578	1.2574	2.8578	2.9721	2.6863
15	2.8578	2.8578	2.8578	1.1431	2.6292	2.9721	2.7435
16	2.8578	2.915	3.0293	1.4289	2.6292	3.5437	3.0293
17	2.8578	2.915	2.8006	1.2574	2.572	2.915	3.0293
18	2.915	3.0293	2.915	1.2003	2.6863	2.5149	2.7435
19	2.6863	2.9721	2.7435	1.3146	2.8578	2.572	2.7435
20	2.7435	2.6863	2.572	1.3717	2.7435	2.6292	2.8006
21	2.6863	2.5149	2.4577	1.4289	2.7435	2.5149	2.6863
22	2.8578	2.6863	2.572		2.8578	2.6863	2.6292
23	2.572	3.0293	2.6292		2.7435	2.6292	2.6292
24	2.2291	2.572	2.2862	2.6863		2.5149	2.572
Max	3.1436	3.0293	3.0293	2.6863	3.0293	3.5437	3.0293
Min	2.2291	2.5149	2.2862	1.1431	1.5432	2.5149	2.5149
Avg	2.7792	2.7598	2.6959	1.7926	2.4577	2.7125	2.7054



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 416 / 33 KV ENDURANCE EXP (K- NON SHEDDABLE EXPRESS HV FEEDERS  
SECTOR) Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.487	5.144	5.3155	5.3155	4.2295	6.0585	5.4298
2	5.4298	5.2584	5.4298	5.144	4.401	5.6584	5.6013
3	5.487	5.3727	5.5441	4.9154	4.5725	5.487	5.7728
4	5.3727	5.4298	5.7156	5.0297	4.5725	5.487	6.0014
5	5.4298	5.4298	5.7156	4.5153	4.6296	5.2584	6.0014
6	5.2584	5.3155	5.4298	3.4294	4.6296	5.2012	5.6584
7	4.6868	5.2584	5.2584	2.572	4.9726	4.8011	4.401
8	5.4298	5.2584	5.5441	2.2862	5.144	5.0297	4.8583
9	5.7728	5.6584	5.8871	2.6292	5.144	5.487	5.4298
10	5.7156	5.7728	6.0585	2.4006	5.6584	5.6013	5.2584
11	5.8871	5.8871	5.6584	2.4006	5.8871	5.6013	5.3727
12	5.8871	6.0014		1.2574		5.0297	4.9154
13	5.8871	5.7156	5.8299	1.4289	6.1157	5.2584	5.7156
14	5.487		6.1157	1.6004	5.9442	5.3155	5.3155
15	6.1728	5.8871	6.0014	1.3717	6.1157	5.6013	5.7728
16	6.0014	5.9442	6.1728	1.4861	5.8299	6.2872	5.6013
17	5.7156	6.0014	6.1728	2.3434	6.1157	6.0014	5.7156
18	5.8299	5.8871	5.9442	2.915	5.8871	5.8871	5.144
19	5.0869	5.0297	4.9726	3.4294	5.2584	5.2012	5.144
20	6.1728	5.7728	5.2584	3.4294	5.3727	5.6584	5.2584
21	5.6584	5.7728	5.3727	3.4294	5.487	5.6584	5.0869
22	5.4298	5.487	5.2584	3.658	5.4298	5.8299	5.0297
23	5.6584	5.6584	5.144	3.8295	5.8871	5.4298	5.2012
24	5.3727	5.0869	5.2012	5.0297	4.0009	5.3155	5.4298
Max	6.1728	6.0014	6.1728	5.3155	6.1157	6.2872	6.0014
Min	4.6868	5.0297	4.9726	1.2574	4.0009	4.8011	4.401
Avg	5.5965	5.5665	5.6087	3.1603	5.2733	5.5060	5.3798

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044215 / 33/11 KV M-SECTOR WALUJ

Feeder No / Name : 201 / KAIZEN

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.105	1.0669	1.0288	1.1431	1.0669	.9907	.9907
2	1.0288	1.0288	.9907	.9907	1.0669	.9526	1.0288
3	1.105	1.0669	1.0479	.9907	1.086	.9526	.9526
4	1.105	1.0669	1.0288	.9907	1.086	.9145	.9907
5	1.0669	1.0288	.9907	.9907	1.086	.8573	1.0288
6	1.0288	1.0669	.9526	.9907	.9145	.9145	.9526
7	1.0288	.9526	.9526	.8383	.7811	.8764	.9145
8	.9907	.8383	1.0669	.9145	1.1812	1.0288	1.0669
9	1.1812	1.1431	1.4289	1.1431	1.2574	1.2193	1.0669
10	1.2955	1.2193	1.5242	.8002	1.5623	1.5242	1.2955
11	1.448	1.105	1.3717	1.1431	1.5242	1.2765	1.448
12	1.1431	1.1812	1.448	1.1812	1.5623	1.6385	1.3336
13	1.105	1.2955	1.1431	.9145	1.2955	1.0669	1.2574
14	1.5242	1.3336	1.448	1.2574	1.5242	1.5242	1.3717
15	1.6004	1.1431	1.5242	1.1431	1.4861	1.6194	1.4098
16	1.448	1.2384	1.2955	1.1812	1.448	1.4289	1.5242
17	1.3717	1.2384	1.6766	.9907	1.3336	1.3336	1.3336
18	1.2955	1.1431	1.1431	1.0288	1.2955	1.1812	1.3717
19	1.0288	1.0479	1.2193	1.0288	1.105	1.2384	1.1431
20	1.1431	.9526	.9145	.9907	1.0669	1.105	1.1812
21	1.1812	.9145	.9907	1.0288	1.105	1.0288	1.2574
22	1.2384	1.0288	1.3717	.9907	1.0479	1.0669	1.3336
23	1.0669	1.1431	1.1431	.9907	1.0669	1.0288	1.1431
24	1.0288	1.0288	1.1812	1.2193	1.0288	.9526	1.0479
Max	1.6004	1.3336	1.6766	1.2574	1.5623	1.6385	1.5242
Min	.9907	.8383	.9145	.8002	.7811	.8573	.9145
Avg	1.1900	1.0947	1.2035	1.0367	1.2074	1.1550	1.1852

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044215 / 33/11 KV M-SECTOR WALUJ

Feeder No / Name : 202 / MDS ALLOYS

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.6097	.2858	.6859	.5716	.6478	.6478
2	.6097	.5716	.3048	.6478	.5716	.6859	.6097
3	.6097	.6097	.3048	.6097	.5335	.6478	.6478
4	.6097	.5716	.2667	.6478	.5335	.6859	.5716
5	.6287	.6097	.3048	.6097	.5335	.6478	.6478
6	.6287	.6478	.3048	.6097	.5335	.6668	.6097
7	.6287	.3048	.2667	.5335	.5906	.5716	.6668
8	.724	.2096	.5716	.5335	.6097	.6859	.4763
9	.9526	.2858	.8573	.6859	.7621	.9526	.724
10	.8764	.3048	.9526	.8383	.9145	.9145	.7811
11	.9907	.3429	.9907	.8192	.9907	.8573	.9145
12	.7621	.4763	.5335	.9145	.9526	.9907	.8764
13	.6668	.3048	.5335	.7049	.8383	.7621	.7621
14	.8383	.3429	.9145	.8002	.9907	.8002	.8383
15	.8764	.3048	.7621	.7811	.9526	.7621	.7811
16	.9907	.3429	.9145	.743	.9907	.8002	.9526
17	.9526	.3429	.9145	.8002	.9907	.724	.7621
18	.8764	.2858	.8383	.743	.9526	.8002	.8573
19	.7621	.2858	.7621	.6478	.7621	.7621	.6097
20	.6859	.2858	.6859	.6097	.7621	.6859	.6097
21	.6097	.2286	.6097	.6097	.6859	.6668	.5716
22	.6097	.2667	.6859	.5716	.6859	.6859	.5716
23	.6097	.2286	.6097	.5716	.7621	.6478	.4954
24	.6097	.5716	.2667	.6859	.5716	.6859	.6097
Max	.9907	.6478	.9907	.9145	.9907	.9907	.9526
Min	.6097	.2096	.2667	.5335	.5335	.5716	.4763
Avg	.7383	.3890	.6017	.6835	.7518	.7391	.6914

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044215 / 33/11 KV M-SECTOR WALUJ

Feeder No / Name : 203 / NATH FORGING

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9907	1.1812	.8573	.8383	.8192	.9145	1.1812
2	1.1431	1.1431	.8002	.7621	.8192	.8764	1.2193
3	1.1431	1.1812	.8383	.7621	.8002	.9145	1.2574
4	1.0288	1.1431	.8764	.7621	.7621	.8764	1.2193
5	1.0669	1.1812	.7621	.7621	.743	.8383	1.1812
6	.9907	.9907	.8383	.7621	.8383	.8383	1.1431
7	1.1622	.8764	1.1431	.7621	.9145	.9145	1.0479
8	1.0479	.7621		.9145	1.0288	1.2955	1.1431
9	1.2193	.7621	1.5242	1.2193	1.105	1.2574	1.2384
10	1.3336	.724	1.9052	1.3717	1.7147	1.7147	1.5242
11	1.4098	.8573	1.6766	1.5623	1.3336	1.6766	1.6385
12	1.3717	.8573	1.2193	1.4098	1.1812	1.5242	1.1812
13	1.3717	.7621	.9907	1.2193	1.5242	1.0669	1.1431
14	1.6385	.7621	1.9052	1.3717	1.5242	1.5242	1.7147
15	1.6766	.7621	1.3717	1.4289	1.448	1.5242	1.6766
16	2.0576	.7621	1.6766	1.3717	1.829	1.5242	1.7147
17	1.9814	.7621	1.2955	.9907	1.7147	1.2955	1.5242
18	1.9052	.724	1.2193	1.2955	1.3717	1.6194	1.5242
19	1.0669	.6668	.9145	.8573	1.3336	1.6194	1.2193
20	1.1812	.6859	.8383	.9145	1.0669	1.0669	.9526
21	1.2193	.6668	.7621	.8192	.9145	1.105	.9145
22	1.0669	.6668	.8383	.8383	.9907	1.0288	.9145
23	1.0669	.724	.8383	.8192	.9145	1.1431	.9145
24	.9907	1.1431	.6859	.8383	.8192	.8764	1.1812
Max	2.0576	1.1812	1.9052	1.5623	1.829	1.7147	1.7147
Min	.9907	.6668	.6859	.7621	.743	.8383	.9145
Avg	1.2971	.8645	1.1208	1.0272	1.1463	1.2098	1.2654

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044215 / 33/11 KV M-SECTOR WALUJ

Feeder No / Name : 204 / FOSTERS

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.448	1.6004	1.3717	1.3717	1.1241	1.5242	1.5242
2	1.4098	1.5623	1.4098	1.3717	1.105	1.4861	1.5623
3	1.4098	1.6004	1.448	1.3717	1.0669	1.448	1.6004
4	1.3717	1.5242	1.4289	1.2193	1.0669	1.5242	1.5242
5	1.3717	1.6004	1.3717	1.2193	.9907	1.448	1.5623
6	1.4098	1.5242	1.448	1.3717	1.105	1.6004	1.6194
7	1.448	1.2193	1.3717	1.2193	1.2384	1.3717	1.5242
8	1.7909	1.7147	1.829	1.2193	1.6004	1.7147	1.9814
9	1.9243	1.7147	2.1338	1.5242	1.8099	1.9814	2.1338
10	2.2862	1.6766	2.1338	1.6766	2.0957	2.1338	2.21
11	2.21	1.6766	2.2862	1.6194	2.1338	2.0576	2.21
12	1.7528	1.6194	1.829	1.5242	1.9814	1.6766	1.9814
13	1.9052	1.829	1.9814	1.5623	1.9814	1.7147	1.829
14	2.0957	1.9814	2.1338	1.5242	1.9052	2.1338	2.2862
15	1.9814	1.9814	2.4387	1.5051	1.9814	2.1338	2.21
16	2.21	1.7147	1.829	1.6194	1.9814		2.0957
17	2.0576	2.1338	2.2862	1.6385	2.0957	2.2862	2.2862
18	1.9052	1.6766	2.0576	1.2193	2.1338	2.1338	2.1338
19	1.6766	1.6194	1.5242	1.1622	1.6385	1.5242	1.6385
20	1.6766	1.5242	1.5242	1.1622	1.6385	1.6766	1.6766
21	1.5242	1.4861	1.3717	1.1431	1.5242	1.6385	1.6385
22	1.6004	1.4289	1.5242	1.1241	1.5242	1.6004	1.6004
23	1.3717	1.3336	1.5242	1.1241	1.5242	1.5242	1.5242
24	1.4098	1.5242	1.4098	1.5242	1.1431	1.4861	1.5242
Max	2.2862	2.1338	2.4387	1.6766	2.1338	2.2862	2.2862
Min	1.3717	1.2193	1.3717	1.1241	.9907	1.3717	1.5242
Avg	1.7186	1.6361	1.7361	1.3757	1.5996	1.7313	1.8282

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044215 / 33/11 KV M-SECTOR WALUJ

Feeder No / Name : 205 / VARSA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	.9145	.724	.9907	.8764	.9145	1.0288
2	.9907	.9526	.6859	.9907	.8764	.9526	.9907
3	.9907	.9145	.6668	.9145	.8383	.8764	1.0479
4	.9145	.9145	.724	.9145	.9145	.9526	.9907
5	.9145	.9145	.6478	.9145	.9145	.9145	1.0288
6	.8383	.8573	.6859	.8383	.8954	.8764	.9907
7	.7621	.7049	.9145	.8383	.8002	.8002	.8573
8	1.0669	.7621	1.0669	1.0669	.9907	1.1431	
9	1.1622	.8002	1.1431	1.1431	1.2003	1.1622	1.2955
10	1.2193	.7621	1.2955	1.2193	1.2193	1.3717	1.2955
11	1.2574	.7621	1.2193	1.3336	1.2955	1.448	1.3336
12	1.1431	.724	1.1431	1.0669	1.2955	1.2193	1.2955
13	1.0288	.7621	1.1431	1.0669	1.2193	1.1431	1.1812
14	1.2193	.7621	1.2193	1.1622	1.2955	1.2955	1.2955
15	1.2955	.6859	1.1431	1.105	1.3336	1.2955	1.2193
16	1.3336	.724	1.2193	1.0669	1.3717	1.448	1.3717
17	1.2574	.6097	1.2955	1.0288	1.3336	1.2955	1.3717
18	1.2193	.6668	1.2193	1.0669	1.2574	1.2955	1.2955
19	1.105	.6097	1.2193	1.0098	1.0288	1.1431	1.2574
20	.9526	.6478	.9907	.9145	1.0669	.9907	.8764
21	.9907	.6859	1.0669	.9145	1.1431	.9907	.9145
22	.9907	.6478	1.0669	.8383	1.0669	.9526	.9526
23	.9145	.6097	.8383	.8383	.8383	.8573	.9526
24	.9907	.9526	.6859	1.0669	.8764	.8764	.8383
Max	1.3336	.9526	1.2955	1.3336	1.3717	1.448	1.3717
Min	.7621	.6097	.6478	.8383	.8002	.8002	.8383
Avg	1.0661	.7645	1.0010	1.0129	1.0812	1.0923	1.1166

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044215 / 33/11 KV M-SECTOR WALUJ

Feeder No / Name : 206 / RUBICON

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8002	.8383	.8764	.9145	.4763	1.105	.8764
2	.8002	.8764	.8573	.9907	.4763	1.1431	.8383
3	.8192	.8383	.9145	.9526	.4572	1.105	.9145
4	.8383	.8383	.8764	.9526	.4572	1.0669	.8764
5	.8383	.7621	.8383	.9907	.4572	1.1431	.8573
6	.8002	.6859	.8573	1.0288	.5335	.9907	.9145
7	.7811	.6859	.9145	.7621	.6097	.6097	.6859
8	1.2193	.9145	.9907	.7621	1.0288	1.0669	
9	1.2384	1.3717	1.3336	.6859	1.1431	1.2193	1.448
10	1.5242	1.448	1.2384	.4191	1.1622	1.1812	1.3336
11	1.8671	1.1812	1.3717	.6097	1.3336	1.3336	1.3717
12	1.1431	1.1431	1.2193	.6478	1.0669	.9907	.9907
13	1.2574	1.105	1.3717	.7811	1.1812	1.1812	1.1431
14	1.448	1.105	1.3717	.6097	1.5242	1.3336	1.448
15	1.4098	1.105	1.6004	.7049	1.5623	1.448	1.448
16	1.4098	1.1431	1.5242	.724	1.3336	1.3336	1.4289
17	1.3717	1.0479	1.5242	.6287	1.448	1.105	1.3717
18	1.5242	.9145	1.5242	.6478	1.0669	1.0669	1.2384
19	.8573	.8764	.8383	.4572	.8192	.724	.8002
20	.9145	1.0479	.9145	.5144	1.1812	.9907	1.1431
21	.9907	1.0288	.9145	.5335	.9145		.8383
22	.8002	1.105	.8383	.4572	.8383	.9145	.8383
23	.9526	1.1431	1.0669	.5144	1.0669	.8573	.9145
24	.8002	.8764	1.1431	1.2193	.4763	1.1431	.8764
Max	1.8671	1.448	1.6004	1.2193	1.5623	1.448	1.448
Min	.7811	.6859	.8383	.4191	.4572	.6097	.6859
Avg	1.1003	1.0034	1.1217	.7295	.9423	1.0893	1.0694

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 201 / 11KV TTK

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8959	2.2862	1.9052	2.8959	2.4768	2.4387	2.7054
2	2.7435	2.2862	1.9052	2.8959	2.4768	2.6673	2.7054
3	2.7435	2.4387	1.9814	2.7435	2.5149	2.6673	2.6292
4	2.7435	2.4387	1.9814	2.5911	2.553	2.6673	2.5911
5	2.8959	2.2862	1.9814	2.5911	2.2481	2.6673	2.5911
6	2.8959	2.2862	2.1338	2.7435	2.2862	2.8959	2.5911
7	2.8959	2.4387	2.1338	2.8959	2.3624	2.1338	2.4006
8	3.3532	2.2481	2.8959	3.0483	2.7435	3.0483	3.0483
9	3.658	2.1338	3.658	3.3532	4.1152	3.5056	3.9628
10	4.2676	2.21	3.8104	4.1152	4.5725	4.5725	4.5725
11	4.2676	2.2862	3.9628	4.1152	4.2676	3.9628	3.9628
12	3.8104	2.1338	4.1152	3.4294	3.5056	3.8104	3.5818
13	3.2007	1.9814	3.9628	2.8959	3.5056	3.658	3.8104
14	4.1152	1.9814	4.2676	3.3532	4.2676	4.1914	3.9628
15	4.1914	2.1338	4.2676	3.3532	3.9628	4.2676	4.1152
16	4.2676	2.2862		3.3532	4.039	4.1914	4.5725
17	3.9628	2.1338	4.7249	3.3532	4.5725	4.2676	4.4201
18	3.8104	1.9814	3.9628	3.3532	3.8104	4.2676	3.8104
19	3.4294	1.9052	3.3532	2.8578	3.0483	3.658	3.5056
20	3.1626	1.9052	3.0483	2.6673	2.4387	2.8197	3.2007
21	2.8578	1.9814	2.8959	2.4387	2.5911	2.4387	2.7435
22	2.7435	1.9814	2.8959	2.5911	1.3717	2.8197	2.7435
23	2.4387	1.9814	3.0483	2.4768	1.3717	2.8959	2.8959
24	2.8959	2.4387	1.9052	3.0483	2.3624	1.3717	2.8959
Max	4.2676	2.4387	4.7249	4.1152	4.5725	4.5725	4.5725
Min	2.4387	1.9052	1.9052	2.4387	1.3717	1.3717	2.4006
Avg	3.3436	2.1735	3.0781	3.0483	3.0610	3.2452	3.3341



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 202 / 11KV G Sector  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.448	1.3717	1.2574	1.3717	1.2193	1.448	1.6004
2	1.3717	1.3717	1.2574	1.3717	1.2193	1.448	1.6385
3	1.3717	1.3336	1.2955	1.2574	1.1812	1.448	1.6385
4	1.3336	1.3336	1.2955	1.2574	1.1812	1.448	1.6385
5	1.2955	1.2955	1.2955	1.1812	1.2193	1.448	1.6385
6	1.2955	1.2955	1.3336	1.3336	1.2193	1.448	1.6385
7	1.3717	1.3336	1.3336	1.6004	1.2574	1.9052	1.6004
8	1.7147	1.3336	1.448	1.9052	1.6004	2.4387	1.9814
9	2.0957	1.1812	1.7147	1.9052	2.1338	2.0576	2.3243
10	2.4387	1.2574	2.0957	2.3624	1.829	2.4387	2.4768
11	2.0195	1.1431	2.3243	2.4387	2.5911	2.8578	2.2862
12	2.1338	1.1431	2.4768	2.1338	2.0576	2.0957	2.0957
13	2.1338	1.1431	2.3243	1.9052	2.0957	2.21	1.9052
14	2.4768	1.2193	2.2862	2.0957	1.9052	2.5149	1.9814
15	2.2862	1.2193	2.553	2.0576	2.2862	2.1719	2.0957
16	2.2862	1.2574	2.3243	1.8671	2.0957	2.3624	2.4387
17	2.4768	1.2574	2.0957	1.829	1.9814	2.4006	2.6673
18	2.0957	1.2193	1.829	1.829	2.5911	2.6292	
19	1.7147	1.2574	1.6766	1.7147	2.1338	1.7528	1.8671
20	1.5242	1.2574	1.6385	1.6004	1.7528	1.6004	1.829
21	1.448	1.2193	1.5623	1.2574	1.6766	1.9052	1.7909
22	1.3336		1.5623	1.1431	1.5242	1.6004	1.7147
23	1.3336	1.2193	1.5242	1.1812	1.6766	1.6385	1.7147
24	1.448	1.3336	1.2574	1.448	1.2193	1.5242	1.6385
Max	2.4768	1.3717	2.553	2.4387	2.5911	2.8578	2.6673
Min	1.2955	1.1431	1.2574	1.1431	1.1812	1.448	1.6004
Avg	1.7687	1.2607	1.7401	1.6686	1.7353	1.9497	1.9218

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 204 / Niton

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.8383	.724	.7621	.7621	.6097	.6859
2	.724	.8383	.6859	.7621	.7621	.6859	.6859
3	.6859	.7621	.6859	.724	.724	.724	.6478
4	.6859	.7621	.6859	.724	.724	.6859	.6478
5	.6859	.8383	.724	.724	.724	.724	.6478
6	.6859	.7621	.724	.724	.7621	.6859	.6859
7	.724	.8383	.7621	.7621	.7621	.8383	.7621
8	.8002	.8383	.8383	.8383	.8383	.9145	.8383
9	.9145	.7621	.8764	.9145	.8764		.9145
10	1.105	.724	.9526	.9907	.9907	1.0669	1.0288
11	1.0669	.724	.9526	1.105	.9145	1.0669	1.0288
12	.9145	.724	1.0288	.9907	.9907	1.0669	1.0288
13	.8002	.7621	1.0288	.8764	.9145	.9145	1.0288
14	1.1431	.724	.9526	.8383	.9907	1.0669	1.0669
15	1.0669	.724	.9526	.8764	1.0669	1.2193	1.105
16	1.0288	.724	1.0288	.8764	1.0669	1.1431	1.0288
17	1.0669	.724	1.0669	.8002	1.0669	.9907	.9526
18	.8383	.6859	.9145	.7621	.9907	1.0669	.8764
19	.8383	.6859	.8383	.7621	.9526	.8764	.7621
20	.7621	.6859	.8383	.724	.6859	.7621	.7621
21	.7621	.724	.8383	.724	.6859	.7621	.6859
22	.7621	.7621	.8002	.6859	.6859	.7621	.6478
23	.7621	.7621	.8002	.724	.6859	.724	.6097
24	.7621	.8383	.724	.7621	.7621	.7621	.6859
Max	1.1431	.8383	1.0669	1.105	1.0669	1.2193	1.105
Min	.6859	.6859	.6859	.6859	.6859	.6097	.6097
Avg	.8462	.7589	.851	.8097	.8494	.8747	.8256

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 205 / 11KV E Sector (LIP)  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	.8383	.6097	.8383	.7621	.7621	.7621
2	.8002	.8383	.6097	.7621	.7621	.8002	.7621
3	.7621	.7621	.6859	.7621	.724	.724	.7621
4	.7621	.7621	.6859	.724	.6859	.7621	.724
5	.724	.7621	.6478	.6859	.724	.8002	.7621
6	.7621	.8383	.6859	.6859	.6859	.7621	.8383
7	.6859	.8383	.724	.8383	.6859	.7621	.7621
8	.8764	.8764	.7621	.9145	.9145	.9907	.9907
9	1.0669	.9145	.9907	.9145	.9145	.9907	1.0288
10	1.1431	.9145	1.1431	1.0669	.9907	1.2193	1.1431
11	1.1431	.9145	1.1431	1.1431	.9907	1.2193	1.0669
12	1.1431	.8383	1.1431	1.0669	.9145	1.2193	1.0669
13	1.0669	.7621	1.1431	.9907	.9145	.9907	1.1431
14	1.1431	.9145	1.105	.9526	.9907	1.0669	1.1431
15	1.1431	.8383	1.105	.9526	1.0669	1.0669	1.2193
16	1.2193	.8383	1.1431	.9907	1.0669	1.1431	1.2193
17	1.2193	.8383	1.2193	.9526	1.0669	1.1431	1.2193
18	1.1431	.7621	.9526	.7621	.9907	1.1431	1.1431
19	.9526	.7621	.8383	.7621	.8383	.9907	.9145
20	.8383	.6859	.8383	.724	.7621	.8383	.8383
21	.8002	.6859	.8002	.6859	.7621	.8383	.7621
22	.7621	.5716	.8002	.6859	.7621	.7621	.7621
23	.7621	.5716	.8383	.724	.7621	.7621	.7621
24	.8383	.7621	.5716	.8383	.7621	.7621	.7621
Max	1.2193	.9145	1.2193	1.1431	1.0669	1.2193	1.2193
Min	.6859	.5716	.5716	.6859	.6859	.724	.724
Avg	.9415	.7954	.8828	.851	.8542	.9383	.9399

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 206 / 11KV Ramnani  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193	1.0669	.9907	1.1431	.724	1.0669	1.2574
2	1.2193	1.0669	1.0288	1.2193	.7621	1.1431	1.2574
3	1.1812	1.0669	1.0288	1.2193	.8002	1.0669	1.2574
4	1.1812	1.0288	1.0669	1.1812	.8002	1.0669	1.2193
5	1.1431	1.0288	1.0669	1.2193	.7621	.9907	1.2574
6	1.1431	.9907	1.0288	1.1812	.7621	1.0669	1.2193
7	1.2193	.9907	1.0669	1.1431	.7621	1.0669	.9907
8	1.448	.9907	1.1812	1.1431	1.1431	1.2193	1.3717
9	1.6004	.9907	1.448	1.2574	.8383	1.5242	1.6004
10	1.6766	1.2193	1.6766	1.1431	1.6766		1.7528
11	1.5242	1.5242	1.6766	1.0669	1.6766	1.6766	1.6385
12	1.3717	1.3336	1.6766	.9907	1.6766	1.6766	1.5242
13	1.2955	1.2193	1.6004	1.0669	1.6766	1.6004	1.5242
14	1.5242	1.3717	1.6004	1.0288	1.6766	1.6766	1.6004
15	1.5242	1.3717	1.6766	1.0669	1.7528	1.6766	1.6766
16	1.5242	1.3717	1.7528	.9907	1.7147	1.9052	1.6766
17	1.6766	1.3717	1.829	.9526	1.6004	1.829	1.7528
18	1.5242	1.2193	1.6766	.9145	1.5242	1.6766	1.5242
19	1.3336	1.1431	1.5242	.8002	1.448	1.5242	1.6004
20	1.3336	1.1431	1.448	.7621	1.2955	1.2955	1.5242
21	1.2574	1.0669	1.3336	.7621	1.3717	1.3717	1.3717
22	1.2193	.9907	1.2955	.7621	1.2193	1.3717	1.3717
23	1.1431	.9907	1.2193	.7621	1.5242	1.2955	1.2955
24	1.2193	1.1431	.9907	1.1431	.724	1.2955	1.1431
Max	1.6766	1.5242	1.829	1.2574	1.7528	1.9052	1.7528
Min	1.1431	.9907	.9907	.7621	.724	.9907	.9907
Avg	1.3543	1.1542	1.3702	1.0383	1.2463	1.3949	1.4337

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 207 / IPCA EXPRESS FEEDER  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5242	1.3336	1.448	1.448	1.448	1.5242	1.448
2	1.5242	1.3336	1.448	1.4861	1.448	1.5623	1.448
3	1.4861	1.3336	1.448	1.4861	1.448	1.5242	1.4098
4	1.4861	1.2955	1.3717	1.448	1.448	1.5623	1.4098
5	1.4861	1.2955	1.3717	1.448	1.448	1.5623	1.3717
6	1.5242	1.2955	1.3717	1.448	1.448	1.6766	1.3717
7	1.4861	1.2955	1.3717	1.448	1.448	1.3717	1.3717
8	1.5242	1.3717	1.5242	1.448	1.2955	1.5242	1.5242
9	1.5242	1.3717	1.6004	1.448	1.5242	1.5242	1.6004
10	1.6004	1.448	1.6766	1.5242	1.5242	1.6004	1.6385
11	1.6004	1.448	1.6766	1.6004	1.6766	1.7528	1.6766
12	1.6004	1.5242	1.6385	1.6004	1.7528	1.7147	1.7147
13	1.6004	1.6004	1.6766	1.5242	1.6004	1.6004	1.7528
14	1.6766	1.5242	1.6004	1.5242	1.7528	1.6004	1.829
15	1.6766	1.5242	1.6004	1.5242	1.829	1.6004	1.9052
16	1.6766	1.5242	1.6766	1.5242	1.7528	1.6004	1.829
17	1.6004	1.5242	1.448	1.6004	1.6766	1.448	1.7909
18	1.5242	1.4861	1.448	1.6004	1.6004	1.5242	1.829
19	1.5242	1.5242	1.4861	1.5242	1.5242	1.5242	1.7528
20	1.5242	1.5242	1.4861	1.5242	1.5242	1.448	1.6766
21	1.448	1.448	1.448	1.448	1.5242	1.3717	1.6004
22	1.448	1.5242	1.448	1.448	1.5242	1.448	1.6004
23	1.448	1.5242	1.448	1.448	1.5242	1.448	1.6766
24	1.5242	1.3336	1.448	1.448	1.448	1.5242	1.448
Max	1.6766	1.6004	1.6766	1.6004	1.829	1.7528	1.9052
Min	1.448	1.2955	1.3717	1.448	1.2955	1.3717	1.3717
Avg	1.5433	1.4337	1.5067	1.4988	1.5496	1.5432	1.6115

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 208 / 11 KV NRB EXP.

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.3048	.1905	.2286	.2286	.2286	.2286
2	.2286	.2286	.1905	.2286	.2286	.2286	.2286
3	.1905	.2286	.1905	.2286	.1905	.2286	.2286
4	.1905	.2667	.1524	.1905	.1905	.2286	.1905
5	.1524	.2667	.1524	.1905	.2286	.2286	.1905
6	.1524	.2286	.1524	.2286	.2286	.2286	.1905
7	.2286	.2286	.1524	.2286	.2286	.1524	.1715
8	.2286	.2286	.2286	.3048	.2667	.2286	.2667
9	.2667	.2286	.2667	.2667	.2667	.3048	.2667
10	.3048	.2286	.3048	.2667	.2667	.3048	.3048
11	.2667	.1905	.2667	.3048	.3048	.3239	.3048
12	.2667	.2286	.2667	.2667	.2286	.2667	.3048
13	.2667	.2286	.2667	.3048	.2286	.3048	.3048
14	.3048	.2286	.2667	.2667	.3048	.3239	.2667
15	.2667	.2667	.2667	.3048	.3048	.3429	.3048
16	.2667	.3048	.3048	.3429	.3048	.3429	.3048
17	.3429	.2667	.3048	.3429	.3048	.3239	.3429
18	.3429	.2286	.3048	.3048	.3048	.381	.3048
19	.2667	.2286	.2667	.2667	.3048	.2667	.2667
20	.2667	.2286	.2667	.2286	.1524	.1905	.2667
21	.3429	.1905	.2667	.2286	.2286	.1715	.2667
22	.2667	.1524	.2286	.2286	.2286	.2477	.2286
23	.3429	.1524	.2286	.2286	.2286	.2477	.1905
24	.2667	.3048	.1524	.2286	.1905	.1524	.1715
Max	.3429	.3048	.3048	.3429	.3048	.381	.3429
Min	.1524	.1524	.1524	.1905	.1524	.1524	.1715
Avg	.2604	.2350	.2350	.2588	.2477	.2604	.2540

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 209 / 11 KV Speciality Polyfilm NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.381	.4191	.4191	.4191	.2858	.4001
2	.4191	.381	.4191	.381	.4191	.2858	.4572
3	.381	.3429	.4191	.381	.381	.2858	.4001
4	.381	.3429	.381	.4191	.381	.3048	.4572
5	.4191	.3429	.381	.4191	.4191	.3429	.4191
6	.4191	.4191	.4191	.381	.381	.381	.4191
7	.381	.4191	.381	.381	.381	.3048	.3239
8	.3429	.4191	.4191	.381	.4191	.381	.381
9	.3429	.4191	.4191	.4191	.381	.381	.381
10	.3048	.4572	.4572	.4572	.4191	.4572	.3429
11	.381	.4191	.4572	.4191	.381	.4572	.4191
12	.381	.4191	.4191	.4191	.381	.4572	.4572
13	.3429	.4572	.4191	.4191	.4572	.4572	.4572
14	.4191	.4572	.4572	.4191	.4572	.4572	.4572
15	.381	.4572	.4572	.4572	.3048	.381	.4572
16	.2667	.4572	.4191	.4572	.381	.381	.4572
17	.3048	.4572	.381	.4572	.4572	.4572	.4572
18	.3048	.4572	.381	.4572	.4572	.4572	.4572
19	.3429	.4572	.4572	.4572	.381	.4001	.4572
20	.3429	.4191	.4572	.4191	.3048	.381	.4572
21	.381	.4572	.4191	.4191	.381	.4001	.4191
22	.4191	.4572	.381	.4191	.4572	.4001	.4191
23	.4191	.4572	.381	.4191	.381	.4001	.381
24	.381	.4191	.4191	.381	.4191	.381	.3429
Max	.4191	.4572	.4572	.4572	.4572	.4572	.4572
Min	.2667	.3429	.381	.381	.3048	.2858	.3239
Avg	.3699	.4239	.4175	.4191	.4001	.3866	.4199

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 210 / 11 KV Tata Tele Services NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0953	.0762	.0762	.0762	.0762	.0953
2	.0762	.0953	.0762	.0762	.0762	.0762	.0762
3	.0762	.0953	.0762	.0953	.0762	.0572	.0953
4	.0762	.0953	.0953	.0953	.0762	.0572	.0953
5	.0762	.0953	.0953	.0762	.0762	.0572	.0953
6	.0762	.0953	.0953	.0762	.0762	.0572	.0762
7	.0762	.0953	.0953	.0762	.0762	.0572	.0762
8	.0953	.0953	.0762	.0953	.0762	.0572	.0953
9	.0953	.0953	.0572	.0762	.0762	.0572	.0953
10	.0953	.0953	.0762	.0762	.0762	.0762	.0762
11	.0953	.0953	.0762	.0762	.0953	.1143	.0762
12	.0953	.0953	.0953	.0762	.0762	.0953	.0953
13	.0953	.0953	.0953	.0762	.0572	.0953	.0953
14	.0953	.0953	.0953	.0762	.0762	.0953	.0953
15	.0953	.0953	.0953	.0762	.0953	.0953	.0953
16	.0953	.0953	.0953	.0762	.0953	.0953	.0953
17	.0953	.0953	.0953	.0762	.0762	.0953	.0953
18	.0953	.0953	.0953	.0762	.0762	.0953	.0953
19	.0953	.0953	.0762	.0762	1.1431	.0953	.0953
20	.0953	.0953	.0762	.0762	.0762	.0762	.0953
21	.0953	.0953	.0953	.0762	.0762	.0953	.0762
22	.0953	.0953	.0762	.0762	.0762	.0953	.0762
23	.0953	.0953	.0762	.0762	.0953	.0953	.0953
24	.0762	.0953	.0762	.0762	.0762	.0953	.0953
Max	.0953	.0953	.0953	.0953	1.1431	.1143	.0953
Min	.0762	.0953	.0572	.0762	.0572	.0572	.0762
Avg	.0889	.0953	.0850	.0786	.1230	.0818	.0897



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 401 / NEW ENDURANCE EXP.

FEEDER(E-92 Feeder KV- 33 /  
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6287	.6859	.6859	.743	.1715	.4572	.5716
2	.6287	.6287	.6287	.6859	.1715	.3429	.5144
3	.5716	.5716	.6287	.6859	.2286	.4001	.5716
4	.5716	.5716	.5716	.6287	.2286	.5144	.5144
5	.5716	.5144	.5716	.6287	.1715	.4572	.5716
6	.5716	.5144	.5144	.5716	.2286	.5144	.5144
7	.5144	.5144	.5144	.2858	.3429	.5144	.5144
8	.8573	.6859	.6859	.2286	.8573	.743	.743
9	.9717	.9145	.8573	.1715	1.086	.743	.9145
10	1.0288	.9717	1.0288	.2286	1.0288	.9145	1.0288
11	1.0288	1.0288	.9145	.2286	1.086	.9717	.9717
12	1.0288	.9145	.8573	.2286	.8002	.8002	.9145
13	.9145	.9145	.9145	.2286	.8573	.6859	.9145
14	.9717	1.0288	.9717	.2286	.9145	.9717	.9717
15		.9717	1.0288	.2286	.9145	.9145	.9717
16	.9717	.9717	1.0288	.2286	.9145	.8573	.9717
17	.9717	.9717	.9717	.2286	1.0288	.9145	.9717
18	.9145	.9145	.9145	.2286	1.0288	.8573	.9145
19	.9145	.8573	.8002	.1715	.8002	.6287	.8573
20	.8573	.8002	.8002	.1715	.6859	.4572	.8573
21	.8573	.743	.743	.1715	.6287	.6859	.8002
22	.8002	.743	.743	.2286	.743	.6859	.8002
23	.8002	.6859	.8002	.2286	.743	.6859	.743
24	.6287	.6859	.6859	.743	.1715	.5144	.5144
Max	1.0288	1.0288	1.0288	.743	1.086	.9717	1.0288
Min	.5144	.5144	.5144	.1715	.1715	.3429	.5144
Avg	.8076	.7835	.7859	.3501	.6597	.6763	.7764

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044217 / 33 KV D SECTOR WALUJ

Feeder No / Name : 201 / Indian Tool  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6004	1.3336	1.0288	1.3717	1.0479	1.4861	1.6004
2	1.5242	1.6385	.9907	1.3336	1.0288	1.4098	1.4861
3	1.4861	1.3717	.9526	1.2574	1.0288	1.2955	1.2574
4	1.3717	1.2574	.9145	1.2193	1.0288	1.2574	1.1812
5	1.3336	1.1812	.8764	1.1812	1.0479	1.1431	1.0288
6	1.2955	1.1431	.8764	1.1812	1.0288	1.0288	.9907
7	1.1431	1.0288	.9145	.9526	.9526	1.105	.9907
8	1.5623	1.1812	1.3336	1.2193	1.5242	1.4861	1.4098
9	1.6766	1.3717	1.5623	1.448	1.6766	1.9052	1.6004
10	2.2862	1.2955	1.7147	1.6004	1.8671	1.1431	1.9052
11		1.3336	1.7147	1.4861	2.0386	2.1338	1.9814
12	1.8671	1.3717	1.4098	1.448	1.7909	1.7147	1.6004
13	2.21	1.2193	1.7528	1.6766	1.9433	2.0957	2.0195
14	2.4387	1.448	1.9052	1.5623	2.1719	2.0957	1.9052
15	2.0957	1.3336	1.7147	1.2955	1.9814	1.9052	1.6766
16	1.9052	1.2193	1.6385	1.1431	1.7528	2.0957	1.8671
17	1.9052	1.3336	1.6385	1.1812	2.0957	1.7147	1.9433
18	1.9052	1.4098	1.7528	1.1812	1.9052	1.7909	2.0195
19	1.6385	1.3336	1.5242	1.1812	1.7147	1.6385	1.3717
20	1.448	1.1431	1.4861	1.2193	1.6385	1.2574	1.3717
21	1.7147	1.1431	1.448	1.2574	1.3336	1.448	1.448
22	1.7147	1.0288	1.4098	1.0669	1.7909	1.3336	1.7528
23	1.2955	.9907	1.2574	1.1622	1.6004	1.2955	1.7528
24	1.448	1.3717	.9526	1.2193	1.0082	1.5242	1.4098
Max	2.4387	1.6385	1.9052	1.6766	2.1719	2.1338	2.0195
Min	1.1431	.9907	.8764	.9526	.9526	1.0288	.9907
Avg	1.6898	1.2701	1.3654	1.2852	1.5416	1.5543	1.5654

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044217 / 33 KV D SECTOR WALUJ

Feeder No / Name : 202 / D Sector

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9907	.9907	.6859	.9907	1.086	1.2574	.8383
2	.9907	.9907	.6859	.9526	1.0479	1.2574	.9145
3	.9907	.9526	.6859	.9526	1.0479	1.2193	.8383
4	.9145	.9145	.6859	.9145	1.0288	1.1812	.8383
5	.9145	.8764	.7621	.9145	1.0288	1.1812	.9145
6	.9145	.9145	.6859	.9145	1.0288	1.1431	.9907
7	.9907	.6859	.9145	.9907	1.0288	.7621	.9907
8	1.3717	.7621	1.2955	1.2955	1.6004	1.5242	1.448
9	1.6766	1.1431	1.829	1.6004	1.6766	1.5242	1.9052
10	1.9052	1.1431	1.9814	1.6004	1.8861	1.9052	1.829
11	1.829	1.1431	1.9814	1.9814	1.9433	1.7528	2.1338
12	1.829	.9907	1.7528	1.7528	1.8861	1.9052	1.9052
13	1.829	.8383	1.829	1.7528	1.6004	1.9052	1.7528
14	1.9814	1.1431	1.9052	1.6004	1.9814	2.1338	1.9814
15	1.7528	1.0669	1.7528	1.6766	1.6956	1.9052	1.7528
16	1.5242	1.1431	1.6766	1.3717	1.6385	1.9052	1.829
17	1.7528	1.0669	1.6766	1.5242	1.7528	1.5242	1.6766
18	1.5242	1.1431	1.7528	1.3717	1.6766	1.3717	1.5242
19	1.3717	1.0669	1.5242	1.1431		1.0669	1.2193
20	1.1431	.8383	1.3336	1.0669	1.1431	.9907	1.1431
21	1.1431	.7621	1.1431	1.1431	1.1431	1.1431	.9907
22	1.1431	.9145	.9907	.9907	1.1431	1.105	.9907
23	.9907	.7621	.9907	1.0669	1.2193	1.0669	1.1431
24	.9907	.9145	.7621	.9907	1.086	1.2955	.9145
Max	1.9814	1.1431	1.9814	1.9814	1.9814	2.1338	2.1338
Min	.9145	.6859	.6859	.9145	1.0288	.7621	.8383
Avg	1.3527	.9653	1.3035	1.2733	1.4074	1.4178	1.3527

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044217 / 33 KV D SECTOR WALUJ

Feeder No / Name : 203 / RKHVAL INDUSTRIES  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9907	.9526	.8002	.9145	.8383	.8764	.9526
2	.9526	.9907	.8002	.8764	.8192	.8764	.9145
3	.9145	.9526	.7621	.8764	.8192	.8383	.9526
4	.8764	.8764	.7621	.8002	.8002	.8383	.9145
5	.8764	.8002	.8002	.8002	.8383	.8002	.9145
6	.8764	.8002	.7621	.8002	.8383	.8002	.9145
7	.8383	.7621	.8002	.8002	.8383	.8383	.9145
8	.8383	.8383	.8002	.7621	.9526	.9145	.9526
9	1.1812	.8764	.8764	.7621	1.105	1.0669	1.0669
10	1.3717	1.1812	1.2574	.8002	1.2574	1.1812	1.1812
11	1.2574	1.1431	1.1431	.724	1.2574	1.1431	1.448
12	1.1812	.8764	.9907	.724	1.2574	1.2574	1.3336
13	.9907	.8764	1.105	.6859	.9526	1.0288	1.1812
14	1.448	1.0288	1.2193	.8383	1.3146	1.3336	1.3336
15	1.1431	1.0669	1.1431	.8383	1.2193	1.2574	1.1431
16	1.448	.9907	1.1431	.7621	1.2193	1.3336	1.4098
17	1.3717	1.1431	1.2574	.724	1.3336	1.2574	1.1812
18	1.3336	1.0288	1.2574	.7621	1.1431	1.1812	1.1431
19	1.0288	.9907	1.1431	.7621	1.1431	.9145	.9526
20	1.0669	.9526	1.0669	.7621	1.0669	1.0288	.9526
21	.8383	.8002	1.0669	.8002	.9526	.9907	.9526
22	.9145	.9526	.9145	.8002	.9526	.9907	.9145
23	1.0288	.8383	1.1812	.8573	.9526	.9526	.9907
24	.9145	.7621	.8002	.8764	.8383	.9145	.9145
Max	1.448	1.1812	1.2574	.9145	1.3336	1.3336	1.448
Min	.8383	.7621	.7621	.6859	.8002	.8002	.9145
Avg	1.0701	.9367	.9939	.7962	1.0296	1.0256	1.0637

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044217 / 33 KV D SECTOR WALUJ

Feeder No / Name : 204 / 11 KV AURANGABAD ROTOPLAST SHEDDABLE FEEDER HAVING WEEKLY  
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.8002	.724	.724	.7049	.724	.5335
2	.8002	.7621	.724	.724	.6859	.724	.5335
3	.7621	.7621	.6859	.6859	.7049	.724	.5335
4	.7621	.724	.6859	.6859	.6859	.6859	.5335
5	.8002	.6859	.724	.724	.6859	.6859	.5716
6	.8002	.6859	.724	.724	.6859	.6859	
7	.7621	.724	.6859	.6859	.6478	.6478	.5716
8	1.2193	.7621	.8764	.8002	.9145	.5335	.9907
9	1.2193	.9526	1.6004	1.105	1.5813	1.3336	1.1812
10	1.3717	1.0669	1.7528	1.105	1.448	1.9052	1.5242
11	1.6004	1.105	1.9433	1.5623	2.191	1.7147	1.9052
12	1.9052	1.0669	1.7909	1.2193	1.9433	1.7909	1.7528
13	1.6766	.9907	1.2574	1.2955	1.7147	1.1812	1.2574
14	2.0195	1.105	1.4861	1.4861	1.8671	1.7909	1.5242
15	1.9433	1.2193	1.5623	1.4861	2.0767	1.6385	1.829
16	2.0195	1.1812	1.6004	1.448	1.6766	1.9052	1.9433
17	1.9052	1.1431	1.9433	1.0669	2.0957	1.6766	1.5623
18	1.829	1.0288	1.7909	.8002	1.7147	1.2955	1.6004
19	1.1431	.8764	1.5242	.7621	1.1812	.8383	.9145
20	.9526	.7621	.9526	.724	.8002	.724	.8383
21	.8764	.7621	.8002	.724	.7621	.6097	.8002
22	.9145	.8002	.8383	.7621	.7621	.6097	.7621
23	.8002	.7621	.8002	.6859	.724	.5716	.7621
24			.724	.6859	.7049	.6859	.5716
Max	2.0195	1.2193	1.9433	1.5623	2.191	1.9052	1.9433
Min	.7621	.6859	.6859	.6859	.6478	.5335	.5335
Avg	1.2541	.9012	1.1749	.9447	1.2066	1.0701	1.0868

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044217 / 33 KV D SECTOR WALUJ

Feeder No / Name : 205 / 11 KV HVDS PADHARPUR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.5228	.5335	.4805	.5228	.5228	.5335
2	.4191	.4854	.5175	.4656	.5228	.5175	.5175
3	.4191	.4805	.4805	.4805	.5041	.5175	.5175
4	.439	.4805	.4805	.5175	.5228	.5601	.5175
5	.5121	.5175	.5175	.5544	.5228	.5658	.5716
6	.5487	.5544	.5544	.5544	.6097	.5658	.6283
7	.439	.5914	.6283	.5853	.6097	.6413	.6219
8	.5487	.5853	.5914	.5853	.5601	.5281	.5601
9	.5228	.5716	.5281	.5975	.5975	.5601	.5228
10	.5228	.5716	.5601	.6348	.5601	.5601	.5228
11	.4854	.5544	.5544	.5601	.5415	.6348	.5601
12	.5228	.5601	.5601	.5975	.5975	.5601	.5601
13	.4854	.5544	.5601	.5601	.5415	.5228	.5228
14	.4854	.5228	.5228	.5335	.5228	.5228	.5175
15	.4854	.5175	.5544	.5601	.5228	.5228	.5175
16	.5228	.5121	.5175	.5228	.5228	.5487	.5601
17	.5335	.6348	.6348	.5228	.5601	.5121	.5487
18	.5601	.5975	.5975	.5601	.5975	.5487	.6219
19	.5975	.6348	.6348	.5975	.7095	.6584	.5853
20	.6348	.6722	.6722	.6722	.7468	.6653	.6283
21	.5975	.6348	.6348	.6348	.6859	.6653	.6283
22	.5975	.6722	.5975	.5975	.5975	.5914	.5975
23	.5544	.5544	.5716	.5601	.5601	.5544	.5975
24	.5335	.5335	.5175	.5175	.5415	.5228	.5544
Max	.6348	.6722	.6722	.6722	.7468	.6653	.6283
Min	.4108	.4805	.4805	.4656	.5041	.5121	.5175
Avg	.5158	.5632	.5634	.5605	.5742	.5654	.5631

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044217 / 33 KV D SECTOR WALUJ

Feeder No / Name : 206 / Tarraco

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.105	.9145	.9907	.6668	1.0288	1.0288
2	1.105	.9907	.8764	.9526	.6668	1.0288	.9907
3	1.0669	.8764	.9526	.9145	.6859	.9907	.9526
4	1.0288	.8764	.9145	.8764	.6859	.9907	.9145
5	1.0288	.8002	.8764	.8002	.6859	.9907	.9145
6	1.0288	.8002	.9526	.8002	.7049	.9907	.9145
7	.8383	.8764	.8002	.724	.724	.8764	.8383
8	1.2193	1.0288	1.3336	.6859	1.1431	1.1812	1.3336
9	1.6004	1.2955	1.2955	.724	1.448	1.3336	1.3717
10	1.6004	1.4098	1.6385	.6859	1.6956	1.3717	1.4098
11	1.6385	1.6004	1.6385	.8002	1.448	1.5242	1.6766
12	1.1431	.9907	1.105	.724	1.1431	1.1431	1.105
13	1.5242	1.3717	1.448	.7621	1.3717	1.5242	1.5623
14	1.6004	1.5623	1.5623	.7621	1.5051	1.5242	1.2955
15	1.7147	1.4861	1.5242	.724	1.6385	1.5242	1.6766
16	1.5242	1.448	1.4861	.6859	1.6004	1.5242	1.6766
17	1.5242	1.4098	1.5242	.724	1.5242	1.3717	1.4098
18	1.448	1.4098	1.4098	.6478	1.4098	1.2574	1.5242
19	1.1431	1.3336	1.3717	.6859	1.1431	1.2193	.9526
20	1.1431	1.2574	1.2574	.724	1.1431	1.0669	.9907
21	1.2574	1.1431	1.1431	.6478	.9907	.9526	1.1431
22	1.3336	1.2574	1.1431	.6478	.9907	.9907	1.0288
23	1.1812	1.0288	1.105	.6859	.9907	1.105	1.0669
24	1.0288	.9526	.8764	.9907	.6859	.9907	1.0288
Max	1.7147	1.6004	1.6385	.9907	1.6956	1.5242	1.6766
Min	.8383	.8002	.8002	.6478	.6668	.8764	.8383
Avg	1.2860	1.1796	1.2146	.7653	1.1122	1.1876	1.2003

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044217 / 33 KV D SECTOR WALUJ

Feeder No / Name : 207 / 11 KV Water Works Express NON SHEDDABLE WATER SUPPLY AND  
Feeder KV- 11 / OUTGOING UTILITY

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9717	.9907	.8002	.9907	.9526	.8954	.9907
2	.9335	.9717	.7621	.9907	.9526	.9145	.9907
3	.9145	.9907	.7811	.9526	.9717	.9145	.9717
4	.9526	.9907	.7621	.9526	.9717	.9526	.9526
5	.9717	.9717	.743	.9717	.9145	.9717	.9907
6	.9717	.9717	.743	.9717	.8764	.9717	1.0098
7	.9526	.9717	.743	.8954	.8954	.9335	.9145
8	.9526	.9717	.7811	.9335	.9145	1.0098	.9145
9		.9335	.8002	.9907	.9717	.9526	1.0288
10		.4763	.8192	1.0098	1.0479	.9526	1.0479
11	1.0669	.2286	.8383	1.0098	.8383	1.0288	1.0669
12	1.0669	.2096	.8383	1.0288	.8002	.9526	1.0669
13	1.0479	.0381	1.0288	.9907	.8002	.9526	1.0669
14	1.086	.0381	.9907	.9907	.8192	1.0288	1.0098
15	.8573	.0381	.9526	.9145	.9526	.9907	1.0098
16	.8573	.1524	.9335	.9145	.9335	1.0479	1.0288
17	.8573	.0381	1.0288	.9335	.9907	.8954	1.0479
18	.7621	.0381	1.0288	.9335	.9526	.8954	1.0479
19	.7049	.0381	.9907	.8954	.9526	.8954	.8192
20	.9335	.0572	.9717	.8573	.9717	.7049	.8192
21	.9907	.0381	.9526	.8573	.8573	.9526	.8002
22	1.0288	.7621	.9526	.9717	.9526	.9717	.9717
23	.9907	.9907	.9717	.9717	.9145	.9907	.9526
24	.9717	.9717	.7811	.9907	.9717	.8954	.9907
Max	1.086	.9907	1.0288	1.0288	1.0479	1.0479	1.0669
Min	.7049	.0381	.743	.8573	.8002	.7049	.8002
Avg	.9474	.5366	.8748	.9550	.9240	.9447	.9796



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 404 / Cosmo Films OLD

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-MAR-18	09-MAR-18
HR	Load (MW)	Load (MW)
1	3.658	3.658
2	4.3439	3.9438
3	4.2867	3.8866
4	2.8578	3.1436
5	3.6008	3.9438
6	3.658	2.572
7	2.3434	2.6292
8	3.9438	3.1436
9	4.2295	3.1436
10	4.401	3.5437
11	4.401	3.4294
12	4.0581	3.2579
13	4.2867	3.6008
14	3.5437	3.6008
15	3.6008	3.3722
16	4.5725	3.3722
17	4.2295	2.915
18	4.3439	2.915
19	3.2007	2.9721
20	3.315	2.915
21	4.7439	2.8578
22	3.9438	3.1436
23	4.6296	2.8006
24	4.0581	4.5725
Max	4.7439	4.5725
Min	2.3434	2.572
Avg	3.9271	3.3055

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 407 / NEW COSMO EXPREES FEEDER NON SHEDDABLE EHV INDUSTRIAL FEEDERS  
 Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING

DATE	08-MAR-18	09-MAR-18
HR	Load (MW)	Load (MW)
1	7.0302	7.0873
2	6.8587	6.7444
3		6.6873
4	6.7444	6.7444
5	6.8587	6.3443
6	6.7444	6.7444
7	6.8016	6.9159
8	6.8016	6.7444
9	6.9159	6.973
10	6.3443	6.973
11	6.4015	7.0302
12	5.8299	6.8587
13	5.7156	6.8016
14	5.5441	6.0585
15	6.0585	5.5441
16	5.7728	5.6584
17	5.8299	5.9442
18	5.8871	6.23
19	6.8016	6.5158
20	6.7444	6.5729
21	7.0302	6.6873
22	6.9159	6.6873
23	6.4015	6.1728
24	6.9159	6.9159
Max	7.0302	7.0873
Min	5.5441	5.5441
Avg	6.4760	6.5682

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 409 / 33 KV BKT EXP. FEEDER NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-MAR-18	09-MAR-18
HR	Load (MW)	Load (MW)
1	2.7435	2.8578
2	2.7435	2.7435
3	2.6292	2.6292
4	2.7435	2.8578
5	2.7435	2.7435
6	2.5149	2.2862
7	2.2862	2.2862
8	3.4294	2.2862
9	3.4294	1.829
10	3.658	1.7147
11	3.7723	1.4861
12	3.5437	1.6004
13	3.315	1.7147
14	2.8578	1.4861
15	2.1719	1.3717
16	2.6292	1.3717
17	2.6292	1.3717
18	2.5149	1.829
19	2.1719	1.3717
20	2.1719	1.3717
21	2.0576	1.6004
22	2.1719	1.1431
23	2.1719	1.3717
24	2.7435	2.8578
Max	3.7723	2.8578
Min	2.0576	1.1431
Avg	2.7435	1.9242

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 410 / NEW ENDURANCE (B-2) EXP. NON SHEDDABLE EXPRESS HV FEEDERS  
 FEEDER Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-MAR-18	09-MAR-18
HR	Load (MW)	Load (MW)
1	1.4861	1.3717
2	1.4861	1.4289
3	1.3717	1.1431
4	1.3717	1.1431
5	1.4289	1.4861
6	1.3717	1.6004
7	1.1431	1.1431
8	1.4861	1.1431
9	1.3717	1.4289
10	1.4289	1.4289
11	1.4289	1.4289
12	1.3717	1.4289
13	1.3717	1.4289
14	1.2574	1.3717
15	1.2003	1.3717
16	1.2003	1.3717
17	1.3146	1.3717
18	1.2574	1.3717
19	1.2574	1.4289
20	1.2574	1.4289
21	1.4289	1.3717
22	1.3717	1.3717
23	1.0288	1.2574
24	1.4861	1.4289
Max	1.4861	1.6004
Min	1.0288	1.1431
Avg	1.3408	1.3646

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

A'BAD CIDCO S/DN.[674] BU 4674

Substation No/ Name :- 044212 / N-7 SUB-STATION

Feeder No / Name : 201 / 11KV SUBHASHRI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.8871	.9145	.924	.9526	.9335	1.0349
2	.8871	.8871	.9145	.8871	.9145	.9335	.924
3	.8871	.8871	.9145	.8871	.9145	.8962	.924
4	.8871	.8871	.9145	.8871	.9145	.8962	.924
5	.9145	.924	.9907	.8871	.9907	1.0082	.961
6	1.0974	.9979	1.0669	.924	1.105	1.1203	1.1827
7	1.2936	1.3676	1.2955	1.1458	1.419	1.2323	1.4415
8	1.2323	1.3306	1.3717	1.2197	1.419	1.3443	1.3306
9	1.1949	1.2696	1.3817	1.1949	1.1949	1.1576	1.2323
10	1.0456	1.0829	1.0829	1.1576	1.0829	1.0082	1.0829
11	.9335	1.0082	1.0082	1.1203	.9335	1.0082	.9709
12	.9335	.9335	.8962	1.0082	.8962	.8962	.9335
13	.8962	.8962	.8589	.9709	.8589	.9335	.9335
14	.7842	.8962	.7842	.9335	.8962	.9335	.8589
15	.7842	.8589	.8962	.8962	.8962	.8871	.8962
16	.8589	.8962	.8962	.9335	.8589	.924	.8962
17	.9145	.9526	.8501	.9907	.961	.924	1.0669
18	1.0288	.9907	.924	1.0288	1.1088	1.0349	1.2955
19	1.3336	1.1812	1.2197	1.3717	1.2197	1.3306	1.4098
20	1.5242	1.2574	1.2197	1.3717	1.2936	1.3676	1.448
21	1.3717	1.1812	1.1827	1.3336	1.2936	1.3306	1.3336
22	1.2955	1.3717	1.1088	1.2955	1.1827	1.2567	
23	1.1431	1.1812	1.1458	1.2574	1.0719	1.2197	1.2193
24		.9979	.9907	.9979	1.0288	1.0349	1.0719
Max	1.5242	1.3717	1.3817	1.3717	1.419	1.3676	1.448
Min	.7842	.8589	.7842	.8871	.8589	.8871	.8589
Avg	1.0503	1.0468	1.0345	1.0677	1.0587	1.0672	1.1031

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

A'BAD CIDCO S/DN.[674] BU 4674

Substation No/ Name :- 044212 / N-7 SUB-STATION

Feeder No / Name : 202 / 11KV N5 CIDCO FEEDER  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2936	1.1458	1.2193	1.1827	1.2193	1.1203	1.1827
2	1.1827	1.1458	1.1812	1.1458	1.1576	1.1203	1.1827
3	1.1827	1.1458	1.1812	1.1458	1.1576	1.1203	1.1458
4	1.1827	1.1458	1.1812	1.1458	1.1576	1.1203	1.1458
5	1.2936	1.4784	1.2193	1.1827	1.3443	1.307	1.1827
6	1.6632	1.6632	1.3336	1.2936	1.7924	1.4937	1.3676
7	1.848	1.6263	1.5242	1.4415	1.8298	1.6057	1.5524
8	1.6804	1.6263	1.4861	1.5524	1.643	1.4937	1.5524
9	1.531	1.7177	1.4937	1.5684	1.4563	1.3817	1.4563
10	1.531	1.531	1.4563	1.7551	1.3817	1.3443	1.307
11	1.1949	1.531	1.3443	1.643	1.3443	1.307	1.419
12	1.2323	1.419	1.3443	1.4937	1.3443	1.3443	1.5684
13	1.3443	1.2323	1.3443	1.419	1.2323	1.2323	1.307
14	1.2323	1.1203	1.1949	1.307	1.2323	1.2323	1.2323
15	1.2696	1.1203	1.1949	1.2696	1.1949	1.0719	1.1949
16	1.2696	1.1203	1.2696	1.2323	1.1949	1.1827	1.2323
17	1.3717	1.2193	1.3676		1.2936	1.2936	1.2955
18	1.5242	1.3336	1.4415		1.4784	1.4045	1.5242
19	1.7909	1.7147	1.7741	1.7147	1.6632	1.7741	1.829
20	1.829	1.7147	1.7741	1.7147	1.848	1.848	1.9052
21	1.7528	1.6385	1.5893	1.6385	1.7372	1.7002	1.7909
22	1.6766	1.5623	1.5524	1.6385	1.5524	1.6632	1.6766
23	1.4861	1.4098	1.3676	1.4861	1.3676	1.5893	1.4861
24		1.2567	1.2574	1.2197	1.2955	1.2567	1.2936
Max	1.848	1.7177	1.7741	1.7551	1.848	1.848	1.9052
Min	1.1827	1.1203	1.1812	1.1458	1.1576	1.0719	1.1458
Avg	1.4506	1.4008	1.3789	1.4178	1.4133	1.3753	1.4096

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

A'BAD CIDCO S/DN.[674] BU 4674

Substation No/ Name :- 044212 / N-7 SUB-STATION

Feeder No / Name : 203 / 11KV RAM MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6722	.6653	.6859	.7392	.7468	.6722	.7392
2	.6722	.6283	.6859	.7023	.7095	.6722	.7023
3	.6722	.6283	.6859	.6653	.7095	.6722	.7023
4	.6722	.6283	.6859	.6283	.6722	.6722	.7023
5	.7468	.6653	.724	.6653	.7095	.724	.7023
6	.7468	.7023	.7621	.6653	.7468	.7468	.7392
7	.7842	.7392	.7811	.6838	.8402	.7842	.8871
8	.8029	.8501	.9335	.7762	.9149	.8215	.8501
9	.7842	.8775	.8589	.7842	.7655	.7468	.8215
10	.6908	.7282	.7468	.7655	.7095	.6722	.7655
11	.6908	.7282	.7282	.7655	.6908	.6535	.6348
12	.6535	.6722	.6348	.7095	.6535	.6348	.6722
13	.6161	.6535	.6535	.6535	.6535	.6535	.6535
14	.6348	.6161	.6348	.6535	.6348	.6348	.6722
15	.6348	.6348	.6161	.6161	.6161	.6653	.6722
16	.6161	.6348	.6161	.6348	.6722	.6653	.6535
17	.6287	.6478	.6468	.6859	.6653	.6653	.6478
18	.7049	.7621	.8131	.7621	.7392	.8316	.7621
19	.8954	.9335	1.0534	.8764	.8316	1.1273	.8954
20	.9145	.9335	1.0903	.9145	.924	1.1273	.9526
21	.9335	.8954	.8871	.8764	.924	1.1643	.9907
22	.8573	.9145	.9795	.9145	.924	.961	.9335
23	.7621	.7621	.8131	.8002	.8316	.924	.8002
24		.7023	.724	.7577	.7621	.7392	.8131
Max	.9335	.9335	1.0903	.9145	.924	1.1643	.9907
Min	.6161	.6161	.6161	.6161	.6161	.6348	.6348
Avg	.7299	.7335	.7684	.7373	.7520	.7763	.7652

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

A'BAD CIDCO S/DN.[674] BU 4674

Substation No/ Name :- 044212 / N-7 SUB-STATION

Feeder No / Name : 204 / 11KV SHARADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4937	1.386	1.3717	1.4045	1.419	1.3443	1.3676
2	1.3817	1.2936	1.3336	1.3676	1.3817	1.3443	1.3676
3	1.3817	1.2936	1.3336	1.3306	1.3443	1.3443	1.3676
4	1.3817	1.2936	1.3336	1.3306	1.3443	1.3443	1.3676
5	1.6804	1.4784	1.7147	1.3676	1.6804	1.4937	1.3676
6	1.8671	1.848	2.0957	1.3676	1.9791	1.6804	1.9404
7	1.9418	1.6632	1.7718	1.8111	1.8858	1.6804	1.6632
8	1.6804	1.6632	1.7909	1.6263	1.7924	1.7924	1.4784
9	1.5684	1.7737	1.531	1.5684	1.6804	1.5684	1.5123
10	1.475	1.587	1.4937	1.7177	1.4937	1.4937	1.4563
11	1.419	1.475	1.4937	1.5123	1.475	1.531	1.4937
12	1.531	1.419	1.419	1.4937	1.3817	1.4937	1.475
13	1.3443	1.4003	1.4003	1.475	1.4003	1.419	1.4377
14	1.3443	1.4003	1.3443	1.419	1.4003	1.419	1.3817
15	1.3443	1.363	1.3443	1.3443	1.3443	1.3676	1.419
16	1.363	1.3443	1.363	1.363	1.3817	1.386	1.4377
17	1.5242	1.5242	1.4415	1.5242	1.4937	1.4045	1.5242
18		1.6766	1.6263	2.0767	1.4784	1.4784	1.829
19	2.3434	2.1338	1.9959	2.191	1.6632	2.1253	2.2862
20	2.3434	2.1719	2.0328	2.191	2.1253	2.1253	2.2862
21	2.191	2.0957	1.9589	2.191	1.848	2.3285	2.1338
22	1.9433	1.9433	1.9959	1.9624	1.848	1.885	2.0005
23	1.7528	1.7147	1.6263	1.7337	1.6632	1.7002	1.829
24		1.4784	1.5242	1.4784	1.5242	1.4784	1.4784
Max	2.3434	2.1719	2.0957	2.191	2.1253	2.3285	2.2862
Min	1.3443	1.2936	1.3336	1.3306	1.3443	1.3443	1.3676
Avg	1.6498	1.6009	1.5974	1.6187	1.5845	1.5928	1.6209



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

A'BAD CIDCO S/DN.[674] BU 4674

Substation No/ Name :- 044212 / N-7 SUB-STATION

Feeder No / Name : 205 / 11 KV WATER SUPPLY  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.1109	.1143	.1132	.112	.112	.1143
2	.1097	.1097	.1143	.1143	.112	.112	.1143
3	.1097	.0732	.1143	.1143	.112	.112	.1143
4	.1097	.0732	.1143	.1143	.112	.112	.1143
5	.1097	.0732	.1143	.1143	.112	.112	.1143
6	.1097	.1109	.1143	.1143	.1307	.112	.1143
7	.1097	.1109	1.7718	.1143	.1307	.112	.1143
8	.0934	.1109	.0572	.1143	.1494	.112	.1143
9	.112	.0934	.0373	.112	.112	.112	.112
10	.0934	.0934	.0747	.0934	.0934	.0373	.112
11	.0934	.0934	.0373	.112	.0747	.0747	.0934
12	.112	.112	.0373	.0934	.0934	.0747	.0934
13	.112	.112	.0747	.0934	.0934	.112	.0747
14	.112	.0747	.0934	.0373	.0934	.0747	.0747
15	.112	.0747	.0934	.0747	.0373	.0953	.112
16	.0747	.0934	.0747	.112	.112	.0953	.112
17	.1143	.1143	.1143	.1143	.1109	.1143	.1143
18	.0572	.1143	.1143	.1334	.1109	.1143	.1143
19	.1334	.1334	.1132	.1334	.1109	.1143	.1143
20	.1334	.1334	.1143	.1334	.1109	.1143	.1334
21	.1334	.1334	.1143	.1334	.1109	.1143	.1334
22	.0572	.1334	.1132	.1334	.1109	.1143	.1334
23	.1334	.1334	.1132	.1334	.1109	.1143	.1334
24		.1294	.1334	.1132	.1334	.1109	.1143
Max	.1334	.1334	1.7718	.1334	.1494	.1143	.1334
Min	.0572	.0732	.0373	.0373	.0373	.0373	.0747
Avg	.1063	.1060	.1653	.1112	.1079	.1035	.1121

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 044031 / 33 KV N-4 S/S

Feeder No / Name : 203 / CIDCO-N4

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0883	2.1622	2.1472	2.3285	2.2405	2.2916	2.3655
2	2.0538	2.0328	2.0351	2.1437	2.1845	2.1437	2.2177
3	1.9791	1.9589	1.9605	2.0328	2.0538	2.0328	2.1068
4	1.8858	1.9404	1.9231	1.9959	2.0165	1.9959	2.0698
5	1.9605	2.0144	1.8858	2.0328	2.0538	2.0698	2.1068
6	2.2779	2.1992	2.2032	2.2361	2.4272	2.4579	2.347
7	2.5206	2.2731	2.5206	2.4025	2.5766	2.6612	2.5133
8	2.4646	2.4394	2.4646	2.4949	2.4646	2.5206	2.4209
9	2.2405	2.4025	2.4272	2.5206	2.2965	2.3339	2.3525
10	2.1845	2.347	2.0911	2.4832	2.1658	2.0538	2.2032
11	2.1472	2.5019	2.2218	2.4272	2.1098	2.0538	2.1285
12	2.1098	2.4272	2.1285	2.2779	2.1098	2.0165	2.1098
13	2.0538	2.2032	1.9791	2.2218	2.1098	2.0538	2.0538
14	1.9791	1.9418	2.0165	1.9978	2.0911	2.0911	2.1098
15	2.3339	1.587	2.0725	2.0538	2.2218	2.2032	
16	2.2965	1.6991	2.0351	2.0725	2.2405	2.2405	2.2032
17	2.2731	2.3712	2.2965	2.1437	2.5393	2.2405	2.3152
18	2.2916	2.4272	2.4086	2.5873	2.5873	2.3152	
19	3.0308	2.838	2.838	2.809	2.9569	3.0434	3.2674
20	3.1232	3.0247	3.006	2.846	3.1786	3.1554	3.2487
21	2.9754	2.9127	2.8567	2.7905	3.0493	3.0807	3.1741
22	2.7721	2.8006	2.7721	2.7536	2.9384	3.0807	2.9874
23	2.6057	2.6513	2.5873	2.6427	2.8275	2.809	2.8753
24	2.3285	2.4025	2.3339	2.4394	2.4025	2.4209	2.6057
Max	3.1232	3.0247	3.006	2.846	3.1786	3.1554	3.2674
Min	1.8858	1.587	1.8858	1.9959	2.0165	1.9959	2.0538
Avg	2.3323	2.3149	2.3005	2.3639	2.4101	2.3902	2.4447

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 044031 / 33 KV N-4 S/S

Feeder No / Name : 204 / MUKUNDWADI  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8484	1.7741	1.7924	1.885	1.9044	1.848	1.7926
2	1.7737	1.7556	1.7737	1.8296	1.8671	1.8111	1.7741
3	1.6804	1.7002	1.7737	1.8296	1.8298	1.7556	1.7372
4	1.7364	1.7187	1.8111	1.848	1.8858	1.7187	1.7372
5	1.9231	1.9035	1.8671	1.9404	1.9978	1.8665	1.9774
6	2.5579	2.0698	2.2965	2.1622	2.5019	2.2731	2.347
7	3.0247	2.5503	2.6699	2.4949	2.7073	2.5688	2.7351
8	2.5206	2.4579	2.4272	2.4025	2.6139	2.384	2.5133
9	2.2032	2.3899	2.0351	2.2405	1.9791	2.0725	2.2405
10	1.9978	1.9044	2.1098	2.0165	1.8858	1.9044	1.9978
11	1.7737		1.8484	1.9791	1.8111	1.7551	1.7924
12	1.7737		1.8298	1.9044	1.7364	1.6753	1.6991
13	1.643		1.7177	1.9791	1.587	1.2883	1.6804
14	1.6617		1.643	2.1472	1.643	1.7364	1.7737
15	1.643	1.9231	1.6804	1.643	1.7177	1.7551	1.643
16	1.6991	1.6991	1.7177	1.9978	1.6804	1.6804	1.6804
17	1.6078	1.7924	1.7924	1.9404	1.7551	1.6804	1.7364
18	1.922	1.9044	2.0351	2.0328	1.9589	2.0538	1.8858
19	2.6242	2.3899	2.3712	2.6612	2.4025	2.4272	2.4272
20	2.6797	2.4272	2.5393	2.5873	2.5133	2.5393	2.6139
21	2.3101	2.3899	2.4272	2.4764	2.4949	2.5019	2.4272
22	2.0698	2.1285	2.2361	2.4025	2.3285	2.4272	2.3899
23	2.1253	2.0911	2.1622	2.2361	2.0883	1.8665	2.2032
24	1.9959	1.885	1.9605	1.9589	1.9959	1.8111	1.9404
Max	3.0247	2.5503	2.6699	2.6612	2.7073	2.5688	2.7351
Min	1.6078	1.6991	1.643	1.643	1.587	1.2883	1.643
Avg	2.0331	2.0428	2.0216	2.1081	2.0369	1.9750	2.0311

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 044031 / 33 KV N-4 S/S

Feeder No / Name : 205 / High court Exp  
Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.112	.112	.112	.112	.1132	.0943
2	.0934	.1109	.112	.112	.112	.0943	.0943
3	.0934	.112	.0934	.112	.112	.0943	.0943
4	.0934	.1109	.0934	.0934	.112	.0943	.0943
5	.0934	.0934	.0934	.0934	.0934	.0943	.0943
6	.0934	.0934	.0934	.0934	.0934	.0943	.0943
7	.0747	.0934	.0747	.0934	.0747	.0754	.0754
8	.0934	.0934	.0747	.0747	.0934	.0943	.0943
9	.1307	.1494	.0934	.0934	.1307	.112	.112
10	.3174	.3734	.112	.0934	.4481	.3921	.3361
11	.4656	.4481	.2427	.0934	.4458	.4481	.5041
12	.4854	.4108	.2614	.112	.5041	.5788	.5415
13	.4854	.3921	.2614	.1307	.4854	.5415	.5041
14	.4668	.4294	.2614	.1307	.4854		.4108
15	.4854	.4668	.2614	.1307	.4854	.5601	.5041
16	.5228	.4854	.2427	.1307	.5041	.5228	.4854
17	.4527	.3921	.2241	.1494	.4668	.4108	.3734
18	.3018	.2801	.2241	.112	.3206	.3174	.2614
19	.2263	.2427	.2054	.1307	2.6406	.2241	.2427
20	.1886	.2054	.1867	.1307	.2075	.1867	.1867
21	.1509	.168	.1494	.1307	.1698	.1494	.168
22	.1494	.168	.1307	.1307	.1509	.1494	.1494
23	.1494	.1494	.1307	.112	.132	.132	.1307
24	.112	.1307	.112	.112	.112	.1132	.1132
Max	.5228	.4854	.2614	.1494	2.6406	.5788	.5415
Min	.0747	.0934	.0747	.0747	.0747	.0754	.0754
Avg	.2432	.2380	.1603	.1128	.3538	.2432	.2400

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 044058 / MHADA 33 KV SUB STN

Feeder No / Name : 201 / MHADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3666	.3628	.3772	.3853	.3734	.3865	.3921
2	.3292	.3453	.3547	.3658	.3547	.3677	.3734
3	.3289	.3278	.3361	.3292	.3361	.3302	.3547
4	.3673	.3468	.3361	.3309	.3547	.3681	.3734
5	.4053	.4362	.3734	.3865	.3734	.4062	.4108
6	.5556	.5441	.5228	.4435	.4854	.518	.5415
7	.6329	.6023	.6535	.5956	.6908	.6348	.6722
8	.5975	.6199	.6535	.5975	.5975	.5975	.5788
9	.5578	.6017	.5228	.5975	.5041	.5228	.5601
10			.4467	.5601	.4268	.4108	.4078
11		.4108	.3889	.4668	.3881	.4108	.4066
12		.3734	.3881	.3921	.3688	.4108	.3681
13		.3361	.3685	.3734	.3313	.3734	.3669
14		.3547	.3681	.3547	.3306	.3921	.3677
15		.3361	.3669	.3547	.3309	.3547	.3669
16		.3547	.4041	.3547	.3497	.3174	.4233
17		.3361	.3685	.3734	.3885	.3734	.4053
18		.3734	.4066	.3734	.4074	.3734	.4435
19		.4854	.5201	.4854	.4644	.4854	.5573
20		.5041	.5573	.5228	.5015	.4854	.5956
21		.5041	.5556	.5041	.501	.5228	.5573
22		.4481	.5175	.5041	.4815	.4854	.555
23		.4294			.462	.4854	.4805
24	.3658	.3631	.3734	.4041	.3921	.4049	.4108
Max	.6329	.6199	.6535	.5975	.6908	.6348	.6722
Min	.3289	.3278	.3361	.3292	.3306	.3174	.3547
Avg	.4507	.4259	.4418	.4372	.4248	.4341	.4571

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 044058 / MHADA 33 KV SUB STN

Feeder No / Name : 202 / RAMNAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1767	1.2346	1.2323	1.2515	1.251	1.2923	1.2883
2	1.1203	1.1839	1.1763	1.1938	1.2323	1.1988	1.2883
3	1.1375	1.1245	1.1763	1.1926	1.1763	1.1583	1.2696
4	1.2331	1.1487	1.2696	1.2883	1.3443	1.291	1.3817
5	1.4584	1.275	1.4563	1.5154	1.5684	1.5185	1.587
6	1.9876	1.6722	2.0165	1.8167	2.0538	2.0103	2.1098
7	2.4832	2.0655	2.2965	2.2755	2.5019	2.4746	2.5579
8	2.2474	2.2877	2.1098	2.1472	2.3152	2.2218	2.3899
9	2.0725	2.0968	2.0165	2.1845	1.9791	1.9231	1.8858
10			1.7906	1.9978	1.6735	1.7364	1.5604
11		1.6632	1.5046	1.7737	1.5015	1.475	1.4103
12		1.2883	1.4259	1.6057	1.2765	1.2883	1.2197
13		1.363	1.332	1.5123	1.2712	1.307	1.2923
14		1.2883	1.2923	1.3443	1.2489	1.2696	1.2541
15		1.251	1.2344	1.2883	1.2712	1.2136	1.195
16		1.1949	1.291	1.2883	1.3292	1.1949	1.2515
17		1.2696	1.3519	1.4003	1.4074	1.4003	1.46
18		1.5684	1.6701	1.6617	1.6904	1.6057	1.7461
19		1.9404	2.0289	2.0165	2.0144	2.0165	2.1055
20		2.0165	1.9917	2.0165	1.9917	1.9978	1.9731
21		1.8484	1.8576	1.8484	1.8	1.9231	1.8761
22		1.6057	1.7443	1.7737	1.7222	1.8298	1.6313
23		1.4937			1.554	1.5684	1.5708
24	1.2109	1.275	1.307	1.3278	1.3256	1.3251	1.3817
Max	2.4832	2.2877	2.2965	2.2755	2.5019	2.4746	2.5579
Min	1.1203	1.1245	1.1763	1.1926	1.1763	1.1583	1.195
Avg	1.6128	1.5285	1.5901	1.6400	1.6042	1.5933	1.6119

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 044058 / MHADA 33 KV SUB STN

Feeder No / Name : 203 / Dhoot Exp.

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1294	.1322	.1334	.1103	.1334	.129	.1143
2	.1287	.1323	.1524	.0918	.1334	.1104	.1143
3	.1288	.1322	.1524	.0915	.132	.1101	.1143
4	.1284	.1324	.1524	.0914	.1334	.1102	.1143
5	.11	.1133	.1524	.1097	.1143	.1103	.0953
6	.1288	.1323	.1143	.1103	.1334	.1104	.1143
7	.1295	.1509	.1334	.1104	.1509	.1672	.1715
8	.1488	.1701	.1715	.1109	.1524	.1905	.1715
9	.1867	.189	.2096	.0762	.1715	.1715	.2452
10		.2286	.1867	.0953	.2048	.2096	.1867
11		.2263	.1873	.0762	.2241	.2286	.225
12		.1905	.1879	.0943	.244	.2096	.1871
13		.2477	.1879	.0953	.2638	.1905	.2068
14		.2477	.2263	.0953	.2259	.2286	.1875
15		.2667	.2452	.1715	.2829	.2477	.2247
16		.3048	.2829	.1143	.3602	.2477	.2252
17		.2477	.2635	.1715	.3388	.2667	.2633
18		.1905	.244	.1715	.2815	.2667	.206
19		.2096	.1858	.1715	.2625	.1905	.2245
20		.1509	.1668	.1524	.2432	.2096	.2241
21		.2286	.148	.1524	.2238	.2096	.1861
22		.1905	.1292	.1698	.1854	.1715	.1485
23		.1905			.2035	.1715	.1667
24	.11	.1133	.1905	.11	.1334	.1104	.1715
Max	.1867	.3048	.2829	.1715	.3602	.2667	.2633
Min	.11	.1133	.1143	.0762	.1143	.1101	.0953
Avg	.1329	.1883	.1828	.1193	.2055	.1820	.1787

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 044058 / MHADA 33 KV SUB STN

Feeder No / Name : 204 / 11 KV Chikalthana  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6632	1.6722	1.7187	1.7187	1.7364	1.7407	1.8484
2	1.6028	1.6427	1.6632	1.6598	1.6804	1.6783	1.8111
3	1.5828	1.6011	1.6804	1.6564	1.6804	1.6564	1.8111
4	1.7556	1.6341	1.9044	1.8055	1.8298	1.8277	1.9418
5	2.2245	2.2244	1.9044	2.2222	2.1658	2.206	2.3152
6	3.0216	3.1028	2.8567	2.782	2.9127	3.0434	2.95
7	3.4517	3.2056	3.3981	3.4517	3.4728	3.4328	3.3981
8	3.1844	3.4534	3.2861	3.3506	3.2114	3.0994	3.1927
9	2.9117	3.3184	3.0308	3.1181	2.782	2.7633	2.95
10		2.8778	2.6781	2.8753	2.4434	2.6326	2.5579
11		2.6612	2.0725	2.6886	2.3081	2.3152	2.215
12		2.1658	2.0331	2.5019	1.9835	1.8298	2.0412
13		1.9035	1.8595	2.2965	1.963	1.9044	1.8889
14		1.4937	1.4784	2.1472	1.9589	1.9978	1.9404
15		1.9418	1.7741	2.0725	1.8996	1.9605	1.9959
16		2.0911	1.9444	2.1285	1.9815	1.7737	2.0762
17		2.2916	2.2291	2.2779	2.2291	2.2032	2.2105
18		2.726	2.6245	2.6326	2.5367	2.4646	2.7418
19		3.1181	3.062	3.2674	3.2025	3.3234	3.3302
20		3.0434	2.9874	3.0807	3.0434	3.2114	3.1935
21		2.5206	2.4756	2.5393	2.5129	2.7446	2.4908
22		2.2405	2.1919	2.3899	2.322	2.4832	2.3339
23		1.8484			2.0577	2.2218	2.0289
24	1.7741	1.7828	1.8296	1.7778	1.8298	1.8092	1.9231
Max	3.4517	3.4534	3.3981	3.4517	3.4728	3.4328	3.3981
Min	1.5828	1.4937	1.4784	1.6564	1.6804	1.6564	1.8111
Avg	2.3172	2.3567	2.2906	2.4540	2.3227	2.3468	2.3828



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 201 / GARWARE EXP.

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	1.848	1.848	1.8111	1.6827	1.9044
23	1.7737	1.7718	1.6385	1.6108	1.848
24	1.7924	1.6644	1.829	1.6617	1.647
Max	1.848	1.848	1.829	1.6827	1.9044
Min	1.7737	1.6644	1.6385	1.6108	1.647
Avg	1.8047	1.7614	1.7595	1.6517	1.7998

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 202 / CENTRON

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	.9709	.7842	1.086	1.2574	1.2765
23	.6838	.5914	.6535	.7655	.6838
24	.567	.5121	.4382	.5258	.6584
Max	.9709	.7842	1.086	1.2574	1.2765
Min	.567	.5121	.4382	.5258	.6584
Avg	.7406	.6292	.7259	.8496	.8729

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 203 / MAHAVEER EXP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	.2096	.1334	.2096	.2286	.2096
23	.1905	.1715	.2096	.2096	.1905
24	.1905	.1905	.1715	.1905	.2096
Max	.2096	.1905	.2096	.2286	.2096
Min	.1905	.1334	.1715	.1905	.1905
Avg	.1969	.1651	.1969	.2096	.2032

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 204 / 11 KV CIDCO

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	1.8298	1.9978	1.8858	2.0351	1.8858
23	2.2405	2.1992	2.2032	2.2965	2.1845
24	1.9044	.7202	1.922	1.9418	1.8054
Max	2.2405	2.1992	2.2032	2.2965	2.1845
Min	1.8298	.7202	1.8858	1.9418	1.8054
Avg	1.9916	1.6391	2.0037	2.0911	1.9586

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 205 / RAMA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	2.4387	2.0195	2.572	2.3434	2.4272
23	1.9052	1.8671	1.8099	2.0005	1.8099
24	1.6194	1.5623	1.6575	1.5623	1.9433
Max	2.4387	2.0195	2.572	2.3434	2.4272
Min	1.6194	1.5623	1.6575	1.5623	1.8099
Avg	1.9878	1.8163	2.0131	1.9687	2.0601

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 206 / Wokhardt

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-18	11-MAR-18	12-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	1.1622	.9149	1.2136	1.2384
23	.8402	.8402	.7762	.9709
24	.9896	.9907	.8316	.9526
Max	1.1622	.9907	1.2136	1.2384
Min	.8402	.8402	.7762	.9526
Avg	.9973	.9153	.9405	1.0540

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 207 / GREAVES

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	11-MAR-18	12-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	3.0674	1.9418	3.2007	3.2579
23	2.3053	1.2003	2.4006	2.2862
24	1.7909	1.6766	1.2765	.9717
Max	3.0674	1.9418	3.2007	3.2579
Min	1.7909	1.2003	1.2765	.9717
Avg	2.3879	1.6062	2.2926	2.1719

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 208 / RADIANT AGRO

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	2.8753		2.726	2.6139
17		2.4958		
23	.9842	.9568	1.1269	.9995
24	.9374	.9172	.8688	.9667
Max	2.8753	2.4958	2.726	2.6139
Min	.9374	.9172	.8688	.9667
Avg	1.5990	1.4566	1.5739	1.5267



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 209 / IND-II

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	2.5149	2.21	2.8197	2.5149	2.7625
23	1.423	1.1443	1.2269	1.4998	1.4299
24	1.3394	1.2757	1.258	1.3253	.5487
Max	2.5149	2.21	2.8197	2.5149	2.7625
Min	1.3394	1.1443	1.2269	1.3253	.5487
Avg	1.7591	1.5433	1.7682	1.78	1.5804

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 210 / 11 KV N-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	.8962	1.2696	1.2323	1.2696
23	.9709	1.0456	1.1016	1.587
24	.8962	.9149	.9335	1.6617
Max	.9709	1.2696	1.2323	1.6617
Min	.8962	.9149	.9335	1.2696
Avg	.9211	1.0767	1.0891	1.5061

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 211 / ELLORA

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	3.7151	2.7816	4.02	4.02	.7964
23	2.1622	2.2779	2.2965	2.1807	1.1526
24	2.1253	2.0668	1.7013	2.0698	2.2862
Max	3.7151	2.7816	4.02	4.02	2.2862
Min	2.1253	2.0668	1.7013	2.0698	.7964
Avg	2.6675	2.3754	2.6726	2.7568	1.4117

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 212 / IND-I

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	5.0225	4.3439	3.8104	3.9819	4.1533
23	4.4391	3.006	2.9721	3.5246	3.1436
24	3.4168	2.6326	2.0809	2.1971	2.2207
Max	5.0225	4.3439	3.8104	3.9819	4.1533
Min	3.4168	2.6326	2.0809	2.1971	2.2207
Avg	4.2928	3.3275	2.9545	3.2345	3.1725

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 213 / 11 KV Naregaon

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	1.8781	1.7909	1.5384	1.6832	1.5181
23	1.419	1.3256	1.2003	1.4003	1.251
24	1.1763	1.1576	1.2136	1.086	1.1517
Max	1.8781	1.7909	1.5384	1.6832	1.5181
Min	1.1763	1.1576	1.2003	1.086	1.1517
Avg	1.4911	1.4247	1.3174	1.3898	1.3069

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 214 / INDIAN TOOL

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	1.3527	.9145	1.1622	1.0098	1.5051
23	.5858	.4089	.5847	.6325	.7537
24	.6478	.5573	.423	.5375	.1734
Max	1.3527	.9145	1.1622	1.0098	1.5051
Min	.5858	.4089	.423	.5375	.1734
Avg	.8621	.6269	.7233	.7266	.8107

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 215 / Agro Exp

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	4.382	4.1724	3.8485	3.4865
23	3.5627	3.1741	3.1817	3.1367
24	3.4294	2.9313	3.315	3.4103
Max	4.382	4.1724	3.8485	3.4865
Min	3.4294	2.9313	3.1817	3.1367
Avg	3.7914	3.4259	3.4484	3.3445

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 401 / Lupin (Gade Jalgaon NON SHEDDABLE EXPRESS HV FEEDERS  
 Shendre M Feeder KV- 33 / (CONTINOUS PROCESS)(NO STAGGERING)  
 OUTGOING

DATE	08-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	2.0576	1.3717	2.1719	2.1719	2.1148
23	1.7718	.7802	1.6575	1.6575	1.7147
24	1.5432	1.5432	.6653	1.3717	1.5432
Max	2.0576	1.5432	2.1719	2.1719	2.1148
Min	1.5432	.7802	.6653	1.3717	1.5432
Avg	1.7909	1.2317	1.4982	1.7337	1.7909



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 402 / Pannalalnagar

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	08-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	.5601	.2743	.5601	.499	.5144
23	.2572	.2429	.2058	.2572	.2458
24	.2401	.2458	.2401	.2458	.2372
Max	.5601	.2743	.5601	.499	.5144
Min	.2401	.2429	.2058	.2458	.2372
Avg	.3525	.2543	.3353	.334	.3325

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 403 / 33 KV Indogerman

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	08-MAR-18	11-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	4.7188	4.4445	4.9897	4.9897
23	5.5441	5.4321	5.9259	5.7659
24	4.7817	5.0452	5.1006	5.3778
Max	5.5441	5.4321	5.9259	5.7659
Min	4.7188	4.4445	4.9897	4.9897
Avg	5.0149	4.9739	5.3387	5.3778

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 404 / 33 kV Mhada

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	08-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	11.6324	11.4129	12.1971	11.9199	12.1811
23	11.9199	11.8644	12.5852	12.9178	12.5852
24	10.5339	10.8111	10.7556	11.0328	10.8596
Max	11.9199	11.8644	12.5852	12.9178	12.5852
Min	10.5339	10.8111	10.7556	11.0328	10.8596
Avg	11.3621	11.3628	11.8460	11.9568	11.8753

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 405 / Empire Mall

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	1.4003	1.4861	1.3443	1.3146	1.3146
23	.4029	.8002	.5218	.4001	.4115
24	.2898	.2961	.3258	.3029	1.6575
Max	1.4003	1.4861	1.3443	1.3146	1.6575
Min	.2898	.2961	.3258	.3029	.4115
Avg	.6977	.8608	.7306	.6725	1.1279

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044210 / SHIVAJI NAGAR 33 KV

Feeder No / Name : 201 / 11 KV LAXMI NGR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8099	1.8111	1.9052	1.9231	1.8671	1.9052	1.9231
2	1.8099	1.8298	1.8671	1.9044	1.9044	1.9243	1.8671
3	1.7909	1.7924	1.8671	1.8671	1.8858	1.9243	2.0538
4	1.848	1.7924	1.8861	1.8484	1.8484	1.9433	2.0538
5	1.9052	1.8298	1.9052	1.8111	2.0351	2.0957	2.4272
6	2.2862	2.2965	2.191	1.8671	2.2779	2.2862	2.6139
7	2.6482	2.6886	2.6292	2.3339	2.8006	2.572	2.8006
8	2.4958	2.782	2.7054	2.4459	2.6513	2.4577	2.8006
9	2.5149	2.8006	1.9791	2.782	2.4272	2.2405	2.4272
10	2.0957	2.3712	1.9791	2.3339	2.0538	1.9231	2.0538
11	1.9433	2.2032	1.9605	2.4272	1.9418	1.7177	1.9231
12	1.8861	2.0538	1.6804	2.3339	1.8671	1.6057	1.7177
13	1.6385	1.7551	1.7177	1.8671	.6535	1.7924	1.6991
14	1.6766	1.587	1.587	1.6804	1.6617	1.6804	1.4937
15	1.6956	1.6804	1.5684	1.7364	1.6804	1.4377	1.6804
16	1.7337	1.6004	1.6804	1.8298	1.7364	1.6804	1.531
17	1.7177	1.6194	1.7737	1.8671	1.7718	1.6617	1.8099
18	1.8484	1.9052	1.9605	2.0538	2.0386	2.4272	2.0005
19	2.3525	2.4006	2.4272	2.3712	2.4387	2.6139	2.553
20	2.4086	2.4768	2.3152	2.3525	2.4006	2.7073	2.4958
21	2.2032	2.3815	2.2405	2.2405	2.2862	2.6139	2.2862
22	2.2032	2.3434	2.1472	2.1845	2.2862	2.4272	2.2862
23	1.9978	2.0957	1.9418	2.1472	2.191	2.2405	2.0957
24	1.848	1.8671	1.9052	1.9418	1.8858	1.9052	2.0538
Max	2.6482	2.8006	2.7054	2.782	2.8006	2.7073	2.8006
Min	1.6385	1.587	1.5684	1.6804	.6535	1.4377	1.4937
Avg	2.0149	2.0818	1.9925	2.0896	2.0246	2.0743	2.1103

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044210 / SHIVAJI NAGAR 33 KV

Feeder No / Name : 202 / 11 KV MORESHWAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6004	1.587	1.6194	1.643	1.643	1.7147	1.6804
2	1.6004	1.587	1.6004	1.6244	1.6057	1.6766	1.643
3	1.5242	1.5684	1.5813	1.587	1.587	1.6766	1.6804
4	1.6004	1.4937	1.6194	1.5497	1.6057	1.7147	1.7924
5	1.6766	1.4563	1.6385	1.531	1.6617	1.8099	1.8671
6	1.9052	1.5684	1.9433	1.5684	1.7177	1.9052	2.0165
7	1.9624	1.9605	2.0386	1.9231	2.0725	2.0957	2.1098
8	1.8671	1.8858	2.0195	1.6617	1.8858	1.9624	2.0538
9	1.7718	1.8484	1.7551	1.4563	1.7364	1.8111	1.7364
10	1.5051	1.6804	1.7551	1.4003	1.531	1.6804	1.531
11	1.3527	1.4937	1.6804	1.475	1.4937	1.4563	1.3817
12		1.419	1.3817	1.531	1.475	1.363	1.2883
13	1.1812	1.4003	1.3256	1.4377	1.419	1.251	1.363
14	1.2955	1.4003	1.2696	1.3256	1.419	1.3256	1.3817
15	1.2384	1.3256	1.2136	1.3817	1.4003	1.4003	1.3817
16	1.3717	1.363	1.2323	1.3817	1.3256	1.3256	1.419
17	1.4937	1.467	1.475	1.4003	1.5051	1.3443	1.6004
18	1.5497	1.6194	1.6244	1.6804	1.6956	1.8671	1.6575
19	1.9978	1.9624	2.0351	1.9791	2.1148	1.9231	2.1148
20	2.1098	2.0195	1.9605	1.9418	2.1148	1.9978	2.191
21	2.0538	1.9243	1.9044	1.9044	2.0957	1.8671	2.1529
22	1.9791	1.8861	1.8858	1.9418	2.0767	1.8671	2.0957
23	1.7924	1.829	1.8484	1.8484	1.9814	1.7551	2.0195
24	1.6575	1.6244	1.6575	1.6804	1.6617	1.7909	1.6991
Max	2.1098	2.0195	2.0386	1.9791	2.1148	2.0957	2.191
Min	1.1812	1.3256	1.2136	1.3256	1.3256	1.251	1.2883
Avg	1.6560	1.6404	1.6694	1.6189	1.7010	1.6909	1.7440

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044210 / SHIVAJI NAGAR 33 KV

Feeder No / Name : 203 / 11 KV RENUKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.7655	.7621	.7842	.7468	.8573	.8215
2	.7621	.7468	.724	.8029	.7468	.8573	.8029
3	.724	.7282	.724	.8402	.7655	.8764	.8029
4	.7621	.7842	.7621	.8402	.8029	.9145	.9335
5	.9145	.8962	.8573	.9149	.8962	.9526	.9335
6	1.2384	1.0829		1.0829	1.0829	1.105	.9709
7	1.3336	1.1949	1.0098	1.1389	1.1763	1.2955	1.0456
8	1.2955	1.2136	1.0479	1.1203	1.1203	1.2193	1.0082
9	.8573	1.1576	.8775	1.0269	.9335	1.0269	.9149
10	.7621	.8215	.8775	.7282	.7468	.9335	.7282
11	.724	.8215	.7468	.7655	.7095	.7282	.6722
12	.5906	.8402	.7468	.8402	.7282	.5975	.6722
13	.6859	.7468	.7282	.8215	.6535	.5788	.6908
14	.7049	.5601	.6535	.7468	.5975	.6722	.6535
15	.6859	.6535	.7468	.8029		.6535	.7282
16	.5716	.7468	.6722	.7842	.6161	.6722	.6722
17	.8589	.5716	.8215	.8029	.8002	.7095	.8192
18	.9709	.8573	.9522	.9896	.8573	.7468	.9717
19	1.1576	.9526	1.0829	1.1203	1.1622	.8029	1.2003
20	1.1389	.9717	1.1389	1.0642	1.1241	.9335	1.2193
21	1.0829	.9145	.9896	1.0269	1.0479	.8402	1.1431
22	.9896	.8192	.9522	.9709	1.0288	.8775	1.0479
23	.8962	.8002	.9335	.7842	.9717	.8589	1.0098
24	.8192	.7655	.7621	.7468	.7655	.8954	.8402
Max	1.3336	1.2136	1.1389	1.1389	1.1763	1.2955	1.2193
Min	.5716	.5601	.6535	.7282	.5975	.5788	.6535
Avg	.8870	.8505	.8508	.8978	.8731	.8586	.8876

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044210 / SHIVAJI NAGAR 33 KV

Feeder No / Name : 204 / 11 KV DEOGIRI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2987	.3048	.2801	.3174	.3429	.3174
2	.2858	.2801	.2858	.2801	.2987	.3429	.3174
3	.2667	.2801	.2858	.2801	.2801	.3239	.3174
4	.2858	.2614	.2858	.2987	.2987	.3239	.3734
5	.3048	.2614	.2858	.2987	.2987	.3429	.3734
6	.362	.3174	.3239	.2987	.2987	.381	.4108
7	.6478	.3547	.362	.5788	.3734	.4001	.5975
8	.4954	.3361	.3048	.4668	.3361	.3239	.4108
9	.2858	.3361	.2427	.3734	.2614	.2801	.2987
10	.2477	.2427	.2427	.2987	.2801	.2241	.2241
11	.2286	.2427	.2241	.2427	.2614	.2801	.2614
12	.2096	.2427	.2241	.2054	.2427	.2241	.2427
13	.2286	.2427	.2241	.2427	.2614	.2241	.2427
14	.2286	.2427	.2241	.2801	.2427	.2427	.2614
15	.2286	.2241	.2427	.2427	.2241	.2427	.2427
16	.2667	.2427	.2427	.2229	.2427	.2427	.2614
17	.2427	.2477	.2427	.2427	.2286	.2427	
18	.2614	.3048	.2614	.2987	.2858	.3174	.3048
19	.3174	.362	.3547	.3547	.362	.3734	.362
20	.3921	.381	.3921	.3734	.381	.3921	.4001
21	.3547		.3734	.3734	.381	.3921	.381
22	.3734	.362	.3734	.3734	.381	.3734	.4001
23	.3547	.3429	.3361	.3547	.362	.3734	.362
24	.3048	.3174	.3239	.3174	.3174	.3429	.3361
Max	.6478	.381	.3921	.5788	.381	.4001	.5975
Min	.2096	.2241	.2241	.2054	.2241	.2241	.2241
Avg	.3108	.2924	.2902	.3158	.3007	.3146	.3348



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044211 / 33KV PANNALALNAGAR

Feeder No / Name : 201 / 11KV CHETNA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6804	1.9605	1.8004	1.9705	2.0538	1.8861	2.1061
2	1.6804	1.9605	1.8004	1.9725	1.9605	1.8004	2.0664
3	1.6975	1.8671	1.8176	1.9161	1.9605	1.749	2.01
4	1.7147	1.7737	1.8176	1.9161	1.8671	1.749	1.9725
5	1.7833	1.7737	1.8519	1.8766	1.8671	1.8004	2.0288
6	1.8861	1.8671	1.9547	1.9083	1.9605	1.8861	2.0601
7	2.0576	2.0165	2.0576	2.008	2.1472	2.1605	2.2354
8	2.2167	2.0664	2.2405	1.8861	2.1415	2.2405	2.2779
9	2.2354	2.2542	2.2405	2.1262	2.1415	2.1472	2.2032
10	2.104	2.104	2.0538	2.0576	2.01	2.2405	2.2405
11	1.8597	1.9811	1.9605	1.9204	1.8597	2.0538	2.0538
12	1.8034	1.9161	1.8671	1.8176	1.8034	1.9605	1.8671
13	1.7604	1.8034	1.8671	1.749	1.7756	1.8671	1.7737
14	1.747	1.8034	1.8671	1.7147	1.8052	1.9605	1.7737
15	1.747	1.8222	1.7737	1.6804	1.8034	1.8671	1.7737
16	1.8671	1.749	1.8709	1.7737	1.8004	2.0059	1.7147
17	1.9605	1.7661	1.856	1.8671	1.9204	2.0226	1.8519
18	2.2405	1.9719	1.9349	2.1472	1.9719	2.1603	1.9719
19	2.6139	2.3148	2.4609	2.4272	2.5034	2.7156	2.2634
20	2.6139	2.4006	2.5819	2.3339	2.4691	2.6675	2.5206
21	2.5393	2.2634	2.4609	2.3339	2.4348	2.5736	2.4348
22	2.3339	2.1434	2.2918	2.2405	2.3148	2.5762	2.3148
23	2.2405	2.0233	2.0476	2.2405	2.1948	2.3505	2.2291
24	1.7833	1.9605	1.9204	1.9142	2.2405	2.0919	2.2309
Max	2.6139	2.4006	2.5819	2.4272	2.5034	2.7156	2.5206
Min	1.6804	1.749	1.7737	1.6804	1.7756	1.749	1.7147
Avg	2.0069	1.9818	2.0165	1.9916	2.0420	2.1055	2.0823

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044211 / 33KV PANNALALNAGAR

Feeder No / Name : 204 / 11 KV PAITHAN GATE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0233	2.3339	2.1948	2.2542	2.3339	2.3663	2.4797
2	1.9719	2.3339	2.1434	2.1603	2.2405	2.2291	2.4421
3	1.9547	2.3339	2.1434	2.1603	2.2405	2.1434	2.3857
4	1.9547	2.4272	2.1605	2.104	2.3339	2.1434	2.3857
5	2.0233	2.6139	2.1948	2.104	2.5206	2.1948	2.5334
6	2.2805	2.7073	2.5206	2.3482	2.8006	2.3663	2.7266
7	2.8292	3.0807	2.9664	3.0056	3.2674	2.8121	3.1747
8	3.2499	3.3438	3.3234	2.915	3.3404	3.1741	3.1367
9	3.1371	3.325	3.2114	2.7778	3.1559	3.1367	3.2114
10	3.1276	3.3438	3.2114	2.7092	3.2278	3.1741	3.2674
11	3.1463	3.3813	3.2674	2.7092	3.2908	3.2114	3.0807
12	3.0996	3.4753	2.9874	2.6063	3.1805	3.1741	3.1367
13	3.0432	3.5316	3.0994	2.572	3.1308	3.0247	2.9874
14	2.9403	3.2774	3.0247	2.4348	3.0839	2.9874	2.9874
15	2.8783	3.0996	2.9874	2.3148	3.0527	3.3234	3.0807
16	2.95	2.7435	3.037	2.5206	2.7435	2.9621	2.7092
17	2.9874	2.6749	2.9117	2.5206	2.6749	3.2212	2.8807
18	3.4541	2.7778	3.112	2.9874	2.8121	3.2521	3.155
19	3.8275	3.4294	3.6819	3.4168	3.6008	3.9329	3.3951
20	3.6969	3.4637	3.6068	3.3234	3.5322	3.7383	3.6351
21	3.3981	3.1207	3.325	3.2674	3.2579	3.3626	3.4979
22	3.1367	2.8121	3.112	3.0807	3.1893	3.3438	3.0178
23	2.95	2.5377	2.7183	2.838	3.0521	3.0996	2.7949
24	2.4691	2.7073	2.3148	2.4258	2.6139	2.8807	2.6112
Max	3.8275	3.5316	3.6819	3.4168	3.6008	3.9329	3.6351
Min	1.9547	2.3339	2.1434	2.104	2.2405	2.1434	2.3857
Avg	2.8554	2.9532	2.8857	2.6482	2.9449	2.9689	2.9464

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044211 / 33KV PANNALALNAGAR

Feeder No / Name : 206 / 11 KV DEVA NAGARI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	1.2136	.9945	1.126	1.3443	1.2003	1.2398
2	.9259	1.1576	.9945	1.1271	1.2696	1.166	1.1823
3	.9259	1.1203	1.0117	1.1835	1.2136	1.1317	1.126
4	.9431	1.0269	1.0117	1.1283	1.2136	1.1317	1.126
5	.9602	1.0269	1.0288	1.0708	1.1203	1.166	1.126
6	1.0288	1.0269	1.0631	1.0708	1.1576	1.2003	1.1823
7	1.1317	1.1203	1.1317	1.1271	1.2696	1.2003	1.2936
8	1.2962	1.2398	1.2696	1.2346	1.3123	1.2696	1.3443
9	1.3338	1.6531	1.2136	1.3717	1.5592	1.3443	1.3443
10	1.2962	1.4089	1.1576	1.4232	1.3525	1.307	1.307
11	1.2023	1.2398	1.2696	1.2689	1.2398	1.2136	1.2696
12	1.1271	1.1835	1.1203	1.2003	1.1823	1.2136	1.1576
13	1.0697	1.0686	1.1203	1.1145	1.1214	1.1576	1.1576
14	1.0708	1.0332	1.0829	1.0631	1.126	1.1203	1.0829
15	1.0895	1.0113	1.0456	1.166	1.1095	1.0829	1.1203
16	1.1203	.9602	1.0907	1.0456	1.0631	1.1225	1.1145
17	1.1576	1.0288	1.1248	1.0269	1.0974	1.2398	1.166
18	1.307	1.2346	1.1659	1.1203	1.1317	1.2398	1.2346
19	1.4003	1.3032	1.4075	1.307	1.4918	1.5216	1.406
20	1.4563	1.3717	1.4089	1.307	1.4403	1.578	1.4746
21	1.307	1.3375	1.4089	1.3443	1.3717	1.556	1.5775
22	1.307	1.3032	1.3713	1.3443	1.3375	1.578	1.4746
23	1.3817	1.2689	1.2962	1.4003	1.2689	1.4089	1.4232
24	1.1145	1.3443	1.2003	1.1835	1.4003	1.2346	1.2949
Max	1.4563	1.6531	1.4089	1.4232	1.5592	1.578	1.5775
Min	.9259	.9602	.9945	1.0269	1.0631	1.0829	1.0829
Avg	1.1623	1.1951	1.1663	1.1981	1.2581	1.2660	1.2594

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044225 / 33/11 KV SOOT GIRNI

Feeder No / Name : 201 / 11 KV INDIRA NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.4294	.3547	.3174	.3772	.4854	.4338
2	.3361	.4108	.3547	.2801	.3584	.4854	.3772
3	.3547	.3734	.4108	.3547	.3395	.4294	.3772
4	.4108	.3961	.3921	.4108	.3395	.4481	.3921
5	.4668	.4294	.3734	.4668	.415	.4481	.415
6	.5415	.4527	.5041	.5041	.5093	.5415	.4527
7	.5975	.547	.5415	.5041	.5658	.5144	.547
8	.5788	.6036	.5601	.5415	.5847	.5144	.5658
9	.5788	.5658	.5729	.5601	.547	.5601	.547
10	.5041	.4294	.5281	.5601	.547	.5041	.4854
11	.5041	.5041	.3018	.5914	.5093	.547	.5228
12	.5041	.4481	.3206	.6161	.5041	.5093	.4668
13	.499	.5601	.3018	.3734	.5041	.4854	.5228
14	.462	.4108	.415	.3734	.5041	.4715	.4801
15	.3921	.4854	.5093	.3239	.5228	.5041	.4854
16	.5041	.5228	.4904	.4668	.4481	.4904	.5041
17	.5228	.3921	.4294	.5093	.4668	.5093	.5041
18	.6161	.5601	.5601	.5093	.5601	.6036	.5601
19	.6722	.5788	.5975	.5847	.5788	.7545	.6348
20		.5975	.5601	.5658	.6535	.7356	.5975
21	.5415	.5228	.5041	.5281	.5415	.6413	.5601
22	.5041	.4294	.4481	.5281	.5041	.4854	.4668
23	.5544	.4108	.3734	.4527	.4668	.4904	
24	.3921	.4715	.3734	.3361	.415	.3921	.4527
Max	.6722	.6036	.5975	.6161	.6535	.7545	.6348
Min	.3361	.3734	.3018	.2801	.3395	.3921	.3772
Avg	.4961	.4805	.4491	.4691	.4901	.5230	.4935

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044225 / 33/11 KV SOOT GIRNI

Feeder No / Name : 202 / 11 KV STADIUM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.0566	.0187	.0187	.0373	.0187	.0189
2	.0187	.0566	.0187	.0187	.0377	.0187	.0189
3	.0187	.0566	.0187	.0187	.0377	.0187	.0189
4	.0373	.0566	.0373	.0187	.0377	.0187	.0189
5	.0373	.0754	.056	.0187	.0566	.0187	.0747
6	.056	.0754	.0554	.0187	.0754	.0187	.0754
7	.0747	.0754	.056	.0187	.0754	.0747	.0754
8	.0747	.0747	.056	.0187	.0754	.0187	.0754
9	.0747	.0754	.0554	.0187	.0754	.0187	.5415
10	.0747	.0747	.0754	.0187	.0943	.0373	.0747
11	.0747	.0747	.0566		.0754	.0739	.056
12	.056	.0373	.056	.0373	.0747	.0754	.0686
13	.0747	.056	.056	.0373	.0747	.0754	.0554
14	.056	.0747	.0754	.0187	.0747	.0754	.0686
15	.056	.0747	.0747	.0373	.0747	.0754	.0747
16	.056	.0747	.0566	.0373	.0747	.0754	.056
17	.0747	.0373	.0747	.0566	.0747	.0754	.0747
18	.0747	.0373	.0747	.0566	.0686	.0754	.0747
19	.0747	.0747	.0934	.0739	.0747	.0747	.0934
20	.0747	.0747	.0747	.0747	.0934	.0747	.0747
21	.0747	.0686	.0747	.0754	.0747	.0754	.0747
22	.056	.0747	.056	.0554	.0514	.0377	.056
23	.0566	.0187	.0373	.0566	.056	.0377	.0373
24	.0373	.0566	.0187	.0373	.0554	.056	.0377
Max	.0747	.0754	.0934	.0754	.0943	.0754	.5415
Min	.0187	.0187	.0187	.0187	.0373	.0187	.0189
Avg	.0576	.0630	.0553	.0366	.0667	.0508	.0790

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044225 / 33/11 KV SOOT GIRNI

Feeder No / Name : 203 / 11 KV CHANAKYAPURI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1203	1.2449	1.1203	1.0269	1.1694	1.2136	1.3769
2	1.0269	1.2071	1.0829	.8402	1.1317	1.1203	1.2696
3	1.0082	1.1317	1.0082	.8402	1.094	1.0829	1.2449
4	1.1203	1.1389	1.0082	1.0269	1.0751	1.1016	1.226
5	1.1949	1.1694	1.0269	1.0829	1.2637	1.1203	1.2449
6	1.307	1.1883	1.1389	1.1203	1.3203	1.2136	1.2752
7	1.363	1.8484	1.251	1.1576	1.3957	1.363	1.4146
8	1.363	1.4377	1.4003	1.2883	1.4335	1.2517	1.4901
9	1.4377	1.6221	1.3491	1.363	1.5278	1.3256	1.4377
10	1.363	1.6804	1.363	1.587	1.3443	1.3817	1.5123
11	1.2883	1.5497	1.3957	1.3306	1.4146	1.3014	1.363
12	1.2567	1.1203	1.3203	1.307	1.2883	1.226	1.2883
13	1.307	1.1389	1.3014	1.307	1.251	1.2637	1.307
14	1.251	1.251	1.2197	1.307	1.2696	1.2826	1.307
15	1.1763	1.2883	1.2449	1.1763	1.2323	1.3203	1.2323
16	1.1763	1.2696	1.307	1.1949	1.2883	1.358	1.2323
17	1.2696	1.3256	1.2323	1.2071	1.3256	1.3769	1.307
18	1.3443	1.363	1.4937	1.4335	1.531		1.419
19	1.5684	1.5684	1.6057	1.531	1.5684		1.531
20	1.5123	1.4969	1.4937	1.4712	1.587		1.5684
21	1.4563	1.4563	1.475	1.4712	1.4937	1.6032	1.531
22	1.4003	1.3817	1.4003	1.3769	1.4377	1.6787	1.4377
23	1.3392	1.307	1.307	1.2883	1.419	1.5466	1.363
24	1.2136	1.2826	1.1763	1.2323	1.2136	1.2696	1.4335
Max	1.5684	1.8484	1.6057	1.587	1.587	1.6787	1.5684
Min	1.0082	1.1203	1.0082	.8402	1.0751	1.0829	1.226
Avg	1.2860	1.3528	1.2801	1.2487	1.3365	1.3048	1.3672

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044225 / 33/11 KV SOOT GIRNI

Feeder No / Name : 204 / 11 KV MUTHA COMPLEX

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.7545	.7468	.7468	.7733	.8775	.811
2	.6722	.7733	.7468	.7095	.7167	.8215	.7392
3	.7282	.7922	.7468	.7842	.7167	.8029	.7733
4	.8402	.811	.7842	.8402	.6979	.8589	.811
5	1.0456	.8299	.7655	.9335	.7922	.823	.8865
6	1.1203	.8871	.9522	1.1016	.9242	.9522	1.0185
7	1.1949	1.0185	1.0642	1.1949	1.094	1.0642	1.1128
8	1.2136	1.0903	.9896	1.1949	1.094	.9945	1.0456
9	1.0456	.9795	.9335	1.1016	.9054	1.0082	.9335
10	.8131	.9522	.8589	.9335	.9054	.9054	.9335
11	.7468	.9149	.8029	.924	.8488	.7545	.8029
12	.7577	.8402	.7842	.8962	.6535	.7545	1.643
13	.6722	.8029	.7545	.7468	.7842	.6908	.6908
14	.6722	.7842	.7167	.7468	.7842	.6602	.6722
15	.6535	.7655	.7167	.7468	.7655	.7282	.7468
16	.7023	.8029	.7468	.7095	.8029	.811	.7095
17	.7842	.7468	.8402	.7922	.7655	.7922	.7842
18	.9335	.6908	.9896	.8029	.8402	.8962	.9335
19	1.1389	.9896	1.1203	.9431	1.0082	1.094	1.531
20	1.0642	.9896	1.0829	.9619	1.0456	1.094	
21	1.0456	.9335	1.0269	.9149	.9896	.9997	.9522
22	1.0269	.9335	.9709	.9335	1.0082	.9997	.9709
23	.8779	.8775	.8402	.9055	1.0082	.9619	.9335
24	.8402	.8299	.8029	.7468	.8215	.9335	.9054
Max	1.2136	1.0903	1.1203	1.1949	1.094	1.094	1.643
Min	.6535	.6908	.7167	.7095	.6535	.6602	.6722
Avg	.8890	.8663	.8660	.8880	.8644	.8866	.9279

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044225 / 33/11 KV SOOT GIRNI

Feeder No / Name : 205 / 11 KV SUHAS COLONY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7095	.8501	.7468	.7468	.7545	.7842	.8775
2	.6908	.8299	.7095	.7095	.7167	.7468	.8299
3	.7468	.7922	.7095	.6535	.679	.7468	.811
4	.8402	.7922	.7282	.7468	.6979	.7655	.8488
5	.9149	.8589	.7468	.8215	.7922	.8029	.9242
6	.9709	.9997	.8871	.8962	.8865	.8962	.9619
7	1.0829	.9694	.9896	.9522	1.0751	1.0456	1.0562
8	.9149	.9431	.9335	1.0082	.9242	.8402	.8865
9	.8215	.9619	.8676	.8589	.8299	.7842	.8488
10	.7577	.8215	.8131	.9335	.811	.7356	.7842
11	.7468	.8215	.7733	.7392	.7733	.7392	.7842
12	.6908	.7468	.7733	.7655	.7655	.7922	.7468
13	.7655	.7468	.7733		.7655	.7922	.7655
14	.7468	.7655	.5847	1.0642	.7655	.811	.7468
15	.7468	.7468	.7733	.8402	.7655	.7733	.7095
16	.7468	.7655	.7577	.8029	.7655	.7733	.7655
17	.7655	.7468	.7842	.7947	.7468	.811	.7842
18	.8029	.8029	.8215	.9149	.8215	.9054	.8589
19	1.0829	1.0269	1.0642	1.0642	1.0751	1.094	1.0642
20	1.0456	1.0269	1.0642	1.1016	1.1203	1.0642	1.0642
21	1.0456	1.0269	1.0456	1.0456	1.0829	1.0751	1.0829
22	1.0456	1.0269	1.0082	.9896	1.0456	1.094	1.0456
23	.9619	.8775	.9335	.9619	1.0269	1.0185	.9709
24	.7842	.8865	.8029	.8402	.8131	.7716	.9335
Max	1.0829	1.0269	1.0642	1.1016	1.1203	1.094	1.0829
Min	.6908	.7468	.5847	.6535	.679	.7356	.7095
Avg	.8512	.8680	.8372	.8805	.8542	.8610	.8813



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAR-18 and 14-MAR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044225 / 33/11 KV SOOT GIRNI

Feeder No / Name : 206 / 11 KV GAJANAN MANDIR  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-MAR-18	09-MAR-18	10-MAR-18	11-MAR-18	12-MAR-18	13-MAR-18	14-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9605	2.2068	2.0538	2.0911	2.0538	2.2032	2.037
2	1.8298	2.1125	1.8671	2.0165	2.0165	2.0911	1.9993
3	1.8484	2.0748	1.8671	2.0725	1.9978	2.0538	2.0182
4	2.0351	2.0748	1.8858	2.2218	2.0328	2.0538	2.0911
5	2.2405	2.1622	1.9605	2.3339	2.1807	2.0911	2.3011
6	2.5206	2.4209	2.3339	2.3899	2.4025	2.3525	2.5463
7	2.6886	2.6029	2.4272	2.4272	2.846	2.5019	2.7726
8	2.726	2.7349	2.6139	2.4646	2.5873	2.6513	2.6595
9	2.5579	2.5274	2.4394	2.4832	2.5953	2.5206	2.4709
10	2.2731	2.6513	2.4646	2.3339	2.5206	2.4459	2.4272
11	2.3712	2.5206	2.4209	2.5393	2.4832	2.4025	2.4459
12	2.2731	2.4086	2.4897	2.4832	2.4086	2.3339	2.3491
13	2.3339	2.3152	2.3388	2.3339	2.4086	2.2257	2.4272
14	2.2032	2.1098	2.2779	2.1472	2.3712	2.2445	2.3712
15	2.2405	2.3339	2.2445	2.1472	2.3525	2.3011	2.3152
16	2.2405	2.2218	2.2068	2.0538	2.3712	2.3954	2.3712
17	2.4646	2.2405	2.3712	2.1472	2.3339	2.4459	2.4272
18	2.6326	2.4025	2.5579	2.4459	2.4459		2.5766
19	3.1367	2.7721	2.9313	2.9047	3.1367	3.2253	3.0994
20	3.006	2.838	2.9687	2.9384	3.0434	3.4139	3.1181
21	2.8193	2.726	2.6326	2.9313	2.8567	3.0994	2.9874
22	2.6139	2.4272	2.4832	2.6886	2.6513	2.7349	2.6699
23	2.3954	.4668	2.3339	2.4897	2.5206	2.5086	2.4646
24	2.0538	2.32	2.1472	2.2405	2.2032	2.2965	2.2068
Max	3.1367	2.838	2.9687	2.9384	3.1367	3.4139	3.1181
Min	1.8298	.4668	1.8671	2.0165	1.9978	2.0538	1.9993
Avg	2.3944	2.3196	2.3466	2.3886	2.4508	2.4606	2.4647