

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064004 / 33 KV GADEGAON

Feeder No / Name : 204 / 11 KV Dhargaon Feeder
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0517	.9945	1.065	1.0288	1.0774	1.1145	1.1145
2	1.0517	1.0174	1.065	1.0288	1.0774	1.1145	1.1145
3	1.0517	1.0288	1.065	1.0288	.9945	1.1145	1.1145
4	1.0517	1.0402	1.065	1.0288	.9945	1.1145	1.1145
5	1.0517	1.0517	1.065	1.0288	.9945	1.1145	
6	1.0517	1.0517	1.0774	1.0288	.9945	1.1145	
7	.9602	1.0517	1.1603	1.0288	1.065	1.1145	
8	.9602	1.1393	1.0774	1.1145	1.0898	1.1145	1.1203
9	1.1203	1.2269	1.0774	1.2003	1.1469	1.1145	1.1469
10	1.1203	1.1393	1.1736	1.286	1.1603	1.286	1.2146
11	1.1203	1.1393	1.1736	1.286	1.2431	1.186	1.3108
12	1.1203	1.267	1.1736	1.2003	1.186	1.1069	1.2289
13	1.186	1.267	1.1736	1.2717	1.2651	1.2003	1.326
14	1.186	1.2536	1.2574	1.3565	1.2651	1.2003	1.4251
15	1.2651	1.448	1.1574	1.3927	1.2803	1.3603	1.5261
16	1.2651	1.2498	1.1574	1.3413	1.3765	1.3603	1.5261
17	1.186	1.3441	1.2346	1.2574	1.3765	1.2803	1.5261
18	1.186	1.3441	1.1717	1.3717	1.3765	1.3765	1.5261
19	1.3441	1.4089	1.3765	1.4575	1.4575	1.5432	1.6651
20	1.2651	1.4089	1.4737	1.4022	1.6289	1.4575	1.5775
21	1.186	1.326	1.387	1.4022	1.4022		1.5775
22	1.1069	1.2431	1.1869	1.2269	1.3146	1.286	1.4022
23	.9488	1.065	1.1869	1.1269	1.267	1.2003	
24	1.0517	.9602	1.065	1.0288	1.0774	1.2003	1.2003
Max	1.3441	1.448	1.4737	1.4575	1.6289	1.5432	1.6651
Min	.9488	.9602	1.065	1.0288	.9945	1.1069	1.1145
Avg	1.1204	1.1861	1.1694	1.2052	1.2130	1.2206	1.3379

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064004 / 33 KV GADEGAON

Feeder No / Name : 205 / 11 KV MIDC II feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER MIDC EQUIVALENT
HAVING WEEKLY STAGGERING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3582	.724	.7545	.7392	.7468	.4144	.5373
2	.3582	.7164	.7468	.6468	.7468	.5144	.5316
3	.3582	.7164	.7545	.6335	.7468	.503	.5316
4	.3582	.6268	.7545	.543	.6335	.503	.5144
5	.3582	.6268	.7164	.543	.6268	.5144	.5144
6	.5601	.7316	.7164	.7316	.6201	.7011	.503
7	.4096	.5144	.6068	.823	.7087	.6859	.5668
8	.9431	.6602	.7888	1.0269	.8059	.9335	.4344
9	.924	.823	.8954	1.0269	.924	1.1317	.5201
10	1.0164	1.3203	1.1317	1.3203	1.0374	1.3203	.5801
11	.8059	.8316	.9335	1.226	.8954	.9145	.4058
12	.9431	1.3203	1.3203	1.6032	1.226	.9431	.3668
13	.7468	.7468	.9431	1.5089	1.1317	1.1317	.2896
14	1.1317	.7468	1.1317	1.3203	1.1317	1.4146	.282
15	.8402	.7392	1.1203	.8669	.8316	1.226	.2858
16	1.0374	1.0374	1.2136	.8859	1.226	1.1317	.3953
17	1.0374	.9431	1.0269	.8488	1.1317	1.0374	.3953
18	.985	.8488	1.0374		.9431	1.1317	.5735
19	.7392	.7392	.823	.6859	.7973	.8316	.4744
20	.7392	.6468	.8316	.7164	.823	.8145	.4801
21	.7392	.6468	.924	.8402	.8059		.381
22	.6468	.6468	.7888	.724	.4525	.6068	.301
23	.6468	.6468	.7888	.7087	.381	.6268	.141
24	.3582	.724	.8059	.8402	.7468	.4049	.5373
Max	1.1317	1.3203	1.3203	1.6032	1.226	1.4146	.5801
Min	.3582	.5144	.6068	.543	.381	.4049	.141
Avg	.7100	.7802	.8981	.9048	.8384	.8451	.4393

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064004 / 33 KV GADEGAON

Feeder No / Name : 207 / 11KV COBRA BN.

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0492	.0497	.0497	.0497	.0497	.0497
2	.0514	.0497	.0497	.0497	.0497	.0497	.0497
3	.0343	.0509	.0492	.0497	.0497	.0497	.0497
4	.0343	.0514	.0492	.0497	.0332	.0497	.0497
5	.0343	.0514	.0497	.0497	.0332	.0497	.0497
6	.0343	.0343	.0328	.0332	.0332	.0497	.0328
7	.0343	.0343	.0328	.0328	.0335	.0497	.0328
8	.0343	.0343	.0328	.0328	.0335	.0497	.0328
9	.0309	.0343	.0328	.0332	.0339	.0497	.0328
10	.0309	.0328	.0335	.0332	.0343	.0497	.0328
11	.0309	.0324	.0339	.0339	.0343	.0335	.0328
12	.0312	.0324	.0335	.0332	.032	.0335	.0339
13	.0312	.0328	.0335	.0335	.032	.0335	.0335
14	.0286	.0328	.0335	.0335	.032	.0328	.0335
15	.0297	.0328	.0335	.0339	.0324	.0328	.0328
16	.0297	.0328	.0335	.0335	.0328	.0328	.0335
17	.0297	.0328	.0324	.0339	.0328	.0328	.0335
18	.0297	.0332	.0324	.0335	.0328	.0328	.0335
19	.08		.081	.0848	.0829	.0838	.0678
20	.08	.0671	.0655	.0857	.0829	.0838	.0671
21	.08	.0671	.0655	.0648	.0829		.064
22	.048	.0671	.0663	.0655	.0497	.0663	.0633
23	.0486	.0497	.0663	.0663	.0497	.0663	.0474
24	.0514	.0486	.0497	.0663	.0663	.0497	.0497
Max	.08	.0671	.081	.0857	.0829	.0838	.0678
Min	.0286	.0324	.0324	.0328	.032	.0328	.0328
Avg	.0416	.0428	.0447	.0465	.0441	.0483	.0433

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064004 / 33 KV GADEGAON

Feeder No / Name : 401 / 33 KV Ashok Leyland Feeder NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8292	3.0493	3.3951	3.3265	2.5463	3.0493	3.3951
2	2.5463		3.3951	3.3265	2.5463	3.0493	3.3951
3	2.5463		3.1121	3.3265	2.5463	3.0493	3.3951
4	2.5463		2.8292	3.2922	2.5463	3.0493	3.3951
5	2.2634		2.8292	3.0493	2.5463	3.0493	3.3951
6	2.2634		2.8292	3.0493	2.5463	3.0493	2.8292
7	3.3951		3.3951	3.3265	2.8292	3.3265	3.1121
8	3.3951		3.3951	2.7721	3.1121	3.6037	2.8292
9	3.3951	3.8809	4.2438	3.0493	3.3951	3.0493	3.678
10	3.3951	3.6037	3.9609	3.0493	3.678	3.0493	3.1121
11	2.5463	2.7721	2.2634	2.5463	2.2634	2.2634	2.2405
12	2.5463	3.3951	3.3951	2.8292	2.5463	3.1121	2.4434
13		3.1121	3.1121	2.5206	3.3951	2.8292	2.4434
14		2.5463	2.5463	2.2405	3.3951	3.1121	3.0178
15		2.2634	2.8292	1.9605	2.2634	3.1121	2.1948
16		3.678	3.678	2.8006	3.3951	3.3951	3.3951
17		3.9609	3.9609	2.8006	3.9609	3.9609	3.5665
18		4.2438	4.5268	3.1121	4.2438	3.678	3.9609
19		3.678	3.678	2.5463	3.678	3.3951	3.678
20	3.1121	3.678	3.3951	3.1121	3.678	2.8292	3.0807
21	3.3951	3.3951	3.3951	3.1121	4.2438		3.9609
22		3.3951	3.1121	2.8292	3.9609	3.3951	3.3951
23	3.1121	3.0493	3.3951	2.8292	3.0807	3.3951	2.8292
24	2.8292	3.1121	3.678	3.1207	2.7721	3.0807	3.3951
Max	3.3951	4.2438	4.5268	3.3265	4.2438	3.9609	3.9609
Min	2.2634	2.2634	2.2634	1.9605	2.2634	2.2634	2.1948
Avg	2.8823	3.3420	3.3479	2.9136	3.1320	3.1688	3.1724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064004 / 33 KV GADEGAON

Feeder No / Name : 403 / 33 KV LAKHORI FEEDER
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINOUS PROCESS)(NO
STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.6722	.7207	.8871	.8402	.8488	.7762
2	.5658	.6722	.6653	.8316	.8402	.7842	.7762
3	.5658	.6516	.6653	.8316	.8402	.7842	.7762
4	.5658	.6653	.6653	.7842	.8402	.8402	.7762
5	.5658	.6099	.6653	.7282	.8402	.7762	.8316
6	.679	.6653	.6653	.7282	.8402	.7762	.8316
7	.7922	.7762	.7207	.7842	.8488	.8871	.8316
8	.7356	.8316	.7762	.8962	.9054	.8316	.8871
9	.7922	.7762	.8316	.8402	.8488	.7762	.8316
10	.8488	.7207	.7762	.8962	.9054	.8316	.8316
11	.7356	.8316	.8316	.8962	.9054	.9425	.7922
12	.7356	.8316	.7762	.8962	.9054	.8871	.8488
13	.7356	.7207	.8316	.8488	.8488	.8316	.8488
14	.6224	.7207	.7762	.8402	.9054	.8871	.8488
15	.6224	.7762	.7356	.8316	.8488	.8871	.9619
16	.679	.8316	.8316	.8779	.8488	.9979	.9619
17	.679	.8871	.7762		.9619	1.1088	1.0751
18	.9054	.8316	.8871	.9877	.9619	.9425	.9619
19	1.1883	1.1643	1.2197	1.262	1.3014	1.2752	1.4146
20	1.0751	1.1643	1.2197	1.2071	1.2449	1.2197	1.2449
21	.9036	1.1643	1.1088	1.0974	1.1883		1.1883
22	.8488	.8871	.9979	1.0974	1.0185	1.0534	1.1317
23	.7356	.7207	.9425	.9522	.9054	.9425	.9619
24	.679	.679	.7207	.8871	.8962	.8488	.8871
Max	1.1883	1.1643	1.2197	1.262	1.3014	1.2752	1.4146
Min	.5658	.6099	.6653	.7282	.8402	.7762	.7762
Avg	.7426	.8022	.8253	.9082	.9288	.9113	.9282

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064004 / 33 KV GADEGAON

Feeder No / Name : 404 / 33 KV VARAM POWER
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.5844	8.3162	7.7915	7.8727	6.9136	6.9685	7.3737
2	6.8587	8.3162	7.9012	7.9836	6.9685	7.1331	7.4846
3	7.1331		8.2305	8.0944	7.0233	7.2428	7.4846
4	7.4074	8.3162	8.1207	8.2053	7.0782	7.4074	7.5955
5	7.6818	8.3162	7.9275	8.3162	7.1331	7.5172	7.5955
6	8.5048	8.3162	8.0944	8.4271	7.1331	8.2305	7.7618
7	8.6146	8.3162	6.3203	6.2094	7.0233	6.8587	7.9836
8	6.2094	8.7597	.3326	6.9302	5.487	8.2305	7.8172
9	8.8889	8.4825	.3292	8.039	6.0357	8.1207	7.2074
10	8.7792	8.9815	.7207	8.039	5.3772	7.1331	8.7597
11	8.5048	8.7597	8.3162	6.5844	7.4074	8.2053	6.653
12	8.3402	8.9261	7.3183	8.2305	7.5172	8.5934	7.7618
13	8.2305	8.6488	8.3162	7.7915	7.4074	7.8727	7.4846
14	8.2305	8.7597	8.039	8.2305	6.31	8.1499	6.7638
15	8.6694	8.1499	8.039	9.4376	8.5048	8.1499	7.8418
16	8.5048	7.9281	8.3162	7.2428	7.1331	8.3162	7.8727
17	8.6694	7.2074	8.3162	7.6818	7.8464	8.7043	7.8172
18	8.2305	8.3402	7.9281	8.2305	8.3951	7.3737	7.9012
19	7.7915	8.2853	8.039	7.9561	8.2305	8.8706	7.7915
20		8.2305	8.4271	1.6461	8.6694	8.039	7.2428
21		8.2305	8.3162	6.8587	7.9561		7.1331
22	8.2305	8.2305	5.5441	7.9561	8.2305	8.538	
23	7.6818	7.4074	8.6488	6.5844	6.6941	8.7597	6.749
24	6.31	8.3162	7.6818	7.7618	6.8587	6.9302	7.3737
Max	8.8889	8.9815	8.6488	9.4376	8.6694	8.8706	8.7597
Min	6.2094	7.2074	.3292	1.6461	5.3772	6.8587	6.653
Avg	7.9116	8.3279	6.9590	7.5129	7.2222	7.8846	7.5413

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064020 / 33 KV MUJABI S/STN

Feeder No / Name : 201 / 11 KV SHAHAPUR AGP

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2641	.2572	.2915	.5487	.5658	.1886
2	.2058	.2641	.2572	.583	.5487	.5658	.1886
3	.2058	.2452	.2572	.6348	.5487	.5487	.1886
4	.2058	.2452	.2572	.6348	.5487	.5487	.1886
5	.2058	.2452	.2572	.6348	.5658	.5658	.1886
6	.2058	.2452	.2743	.823	.583	.583	.2058
7	.6173	.4715	.2915				.2229
8	.6687	.7373	.7202				.6687
9	.7202	.7545	.7888				.6859
10	.7202	.7888	.8059				.7888
11	.7888	.8059	.823				.7373
12	.7888	.7716					.8573
13	.7716	.823		.3601	.3601	.3086	.8402
14	.7716	.8059	.8059	.4115	.463	.3601	.7716
15	.7716	.7545	.8059	.4287	.4115	.3944	.7716
16				.4115	.4287	.4115	
17				.3944	.4287	.3601	
18				.3601	.3944	.3258	
19				.2743	.3258	.2572	
20				.2743	.3086	.2401	
21	.3086					.5658	.3086
22	.2401	.2572	.3086	.5487	.583	.5487	.3086
23	.2401	.2572	.3086	.5487	.583	.5487	.3086
24	.2058	.2401	.2572	.2915	.5487	.583	.5487
Max	.7888	.823	.823	.823	.583	.583	.8573
Min	.2058	.2401	.2572	.2743	.3086	.2401	.1886
Avg	.4657	.4987	.4672	.4650	.4811	.4601	.4720

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384]

BU 0384

Substation No/ Name :- 064020 / 33 KV MUJABI S/STN

Feeder No / Name : 202 / 11 KV MUJABI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2136	1.2449	1.3256	1.3443	1.3443	1.3957	1.2696
2	1.1576	1.226	1.3256	1.3256	1.3443	1.3957	1.2696
3	1.1576	1.226	1.3256	1.3256	1.3443	1.3769	1.2696
4	1.1576	1.226	1.3256	1.3256	1.3443	1.358	1.2696
5	1.1763	1.2449	1.3256	1.3256	1.307	1.3014	1.2696
6	1.1203		1.2883	1.2883	1.307	1.2637	1.1949
7	1.0456	1.1317	1.1389	1.1016	1.1389	1.1694	1.1203
8	.9149	.9808	.8215	1.1016	.9335	.8676	1.0829
9	.8215	.9335	.9149	1.0374	1.0082	1.0269	1.1389
10	.8215	.9149	.8402	.9808	.9149	.9149	1.0642
11	.8962	.9709	.9709	.9619	1.0269	.9709	1.0456
12	.8589	.8589	.9896	.8865	.9709	1.0269	1.0642
13	.8402	.8402	.9522	.8676	.6908	.9522	
14	.9709	.8775	.9896	.9242	1.1389	1.0269	1.0269
15	.8962	.9335	1.1016	.9431	1.1203	1.0642	1.1203
16	1.0374	.8589	1.0456	.9431	1.0829		1.1203
17	1.0374	.8589	1.0829	.8402	1.0562	1.1763	1.1389
18	.9997	.9709	.9149	.8775	1.094	.9896	.8962
19	1.3392	1.363	1.4003	1.3443	1.4335	1.4563	1.3817
20	1.3769	1.3817	1.4003	1.4003	1.4523	1.4937	1.3817
21	1.358	1.363	1.4377	1.4003	1.4146	1.5123	1.3817
22	1.226		1.4003	1.4003	1.4146	1.419	1.3443
23	1.2449	1.3256	1.4377	1.419	1.3957	1.3817	1.3443
24	1.251	1.2637	1.3256	1.3817	1.363	1.3957	1.307
Max	1.3769	1.3817	1.4377	1.419	1.4523	1.5123	1.3817
Min	.8215	.8402	.8215	.8402	.6908	.8676	.8962
Avg	1.0800	1.0907	1.1700	1.1561	1.1934	1.2146	1.1958

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064020 / 33 KV MUJABI S/STN

Feeder No / Name : 203 / 11KV SATONA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.3018	.4481	.3734	.3734	.3772	.3734
2	.2241	.3018	.4481	.3734	.3734	.3584	.3734
3	.2241	.2829	.4481	.3772	.3547	.3584	.3734
4	.2241	.2641	.4481	.3772	.3547	.3584	.3734
5	.2801	.2829	.4481	.3772	.3734	.3395	.3734
6	.2987	.3395	.5228	.3961	.4108	.3206	.4854
7	.2987	.3018	.4481	.3206	.2987	.3206	.3361
8	.3547	.3206	.4108	.3206	.3547	.2641	.2987
9	.3734	.3018	.4481	.3772	.3174	.3547	.2614
10	.4481	.4338	.4668	.4527	.4108	.3921	.2801
11	.3734	.415	.5228	.4715	.5041	.5228	.2614
12	.2987	.4108	.5041	.4527	.2987	.3547	.2801
13	.4108	.415	.5228	.4527	.3921	.3921	.2241
14	.5228	.415	.3921	.4904	.415	.4108	.3174
15	.4481	.4904	.5041	.5093	.3772	.3174	.2987
16	.3206	.3734	.4854	.3584	.3584	.4108	.2801
17	.3961	.3361	.2987	.3547	.2263	.3961	.2614
18	.3961	.4481	.3921	.3547	.2452	.2987	.2427
19	.6224	.6908	.5041	.5041	.4904	.6535	.5788
20	.4338	.6348	.5228	.4854	.4715	.5415	.4668
21	.415	.5601	.4294	.4854	.4527	.4481	.4668
22	.3584	.3734	.3921	.4108	.415	.3547	.4108
23	.3395	.4108	.3734	.3734	.3961	.3734	.3921
24	.2987	.3206	.4481	.3734	.3734	.3772	.3734
Max	.6224	.6908	.5228	.5093	.5041	.6535	.5788
Min	.2241	.2641	.2987	.3206	.2263	.2641	.2241
Avg	.3600	.3927	.4512	.4093	.3766	.3873	.3493

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064029 / 33KV KARDHA

Feeder No / Name : 201 / 11KV MANEGAON BAZAR
(GAOTHAON) Feeder KV- 11 /
OUTGOING

SEPARATED GAOTHAN FEEDERS

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.961	.9709	1.1088	1.1949	1.1949	1.2323	1.2567
2	.961	.9709	1.1088	1.1576	1.1949	1.2323	1.2197
3	.924	.9709	1.1088	1.1203	1.1949	1.1949	1.1827
4	.9335	.9709	1.0719	1.1203	1.1949	.2427	1.1827
5	1.0082	.9979	1.1203	1.1576	1.1949	1.1949	1.1827
6	1.0456	1.0974	1.1576	1.1203	1.1949	1.1949	1.2323
7	.9774	.9145	1.0608	1.0082	1.0349	1.0608	1.0456
8	.8779	.9877	.9774	.9145	.9511	.9511	.961
9	1.0349	.9145	.9145	1.0456	.9877	1.0349	1.0719
10	.9709	.8871	.9412	.8063	.9877	1.0719	1.0029
11	.7964	.7602	.8779	.9214	1.1568	.9145	1.0166
12	.8596	.8326	.788	.9214	.8326	.9671	.8596
13	.6805	.8238	.8131	1.0277	1.0631	.9922	.7316
14	.7095	.8688	.8048	.9412	.9671	.9214	.7392
15	.7164	.8688	.8048	.5914	1.1104	1.0029	.439
16	.6878		.8326	.9114	1.086	1.0166	.5068
17	.6859	.823	.7282	.8669	.9114	.7796	1.0498
18	.8764	.8669	.8505	.9922	1.1568	.9709	.9465
19	1.4784	1.5524	1.5524	1.5684	1.6057	1.6632	1.6632
20	1.3817	1.531	1.4937	1.5844	1.6057	1.5893	1.6804
21	1.2323	1.4937	1.4937	1.5844	1.5684	1.5893	1.6263
22	1.4784	1.3443	1.419	1.419	1.4563	1.4784	1.4784
23	1.0829	1.1827	1.307	1.2936	1.307	1.3443	1.3676
24	.9979	1.0082	1.1458	1.2323	1.2696	1.1949	1.3443
Max	1.4784	1.5524	1.5524	1.5844	1.6057	1.6632	1.6804
Min	.6805	.7602	.7282	.5914	.8326	.2427	.439
Avg	.9733	1.0278	1.0617	1.1042	1.1762	1.1181	1.1161

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064029 / 33KV KARDHA

Feeder No / Name : 203 / 11 KV SALEBARDI (AGP)

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.8128	.8642	.9061	
2				.823	.8642	.9061	
3				.823	.8642	.8749	
4				.8128	.8642	.8749	
5				.8535	.8642	.8749	
6				.9259	.9259	.9374	
8	.9282	1.0883	1.1984				1.1469
9	1.0814	1.2125	1.3108				1.3676
10	1.0486	1.2452	1.3108				1.3108
11	1.0486	1.1934	1.3435				1.3923
12	1.1603	1.326	1.3592				1.3592
13	1.2266	1.3923	1.3435				1.3923
14	1.1797	1.326	1.3435				1.4586
15	1.1934	1.3592	1.3108				1.4255
17			1.3108				
18	1.1934						
21				.8749	.8749	.7316	
22				.8749	.9061	.8749	
23				.9393	.9061	.8333	
24					.8951	.9061	.8333
Max	1.2266	1.3923	1.3592	.9393	.9259	.9374	1.4586
Min	.9282	1.0883	1.1984	.8128	.8642	.7316	.8333
Avg	1.1178	1.2679	1.3146	.8600	.8829	.8720	1.2985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064029 / 33KV KARDHA

Feeder No / Name : 204 / 11 KV MIDC FEEDER
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.128	.5281	.3658	.2214	.2195	.1966	.1448
2	.144	.5281	.3315	.2214	.2195	.1966	.1734
3	.1463	.5281	.2401	.2214	.2195	.1638	.1715
4	.1463	.5281	.2214	.2	.2195	.1638	.1696
5	.2107	.5658	.1791	.2054	.2195	.1638	.2103
6	.216	.5658	.1791	.2054	.2469	.1966	.2195
7	.1875	.4854	.2347	.2347	.2591	.2195	.2195
8	.1989	.5281	.3155	.2774	.2591	.2667	.3018
9	.415	.7167	.4191	.415	.3801	.3018	.4191
10	.6478	.7545	.5335	.5335	.394	.3772	.381
11	.6478	.7545	.5658	.724	.4435	.3395	.4854
12	.7621	.7167	.5716	.6478	.3429	.381	.4954
13	.724	.7922	.6097	.6478	.2881	.381	.3395
14	.724	.7922	.5716	.421	.3467	.3395	.3395
15	.7621	.8299	.6097	.4527	.3544	.3429	.4481
16	.6097	.8962	.5281	.3772	.4024	.415	.381
17	.4904	.8589	.4435	.4904	.3658	.381	.381
18	.6036	.8215	.3258	.3734	.4527	.3018	.4191
19	.6036	.6413	.3582	.3772	.415	.3395	.3018
20	.6036	.6036	.2439	.2915	.3086	.3018	.2263
21	.5281	.4298	.2241	.2103	.25	.2218	.2614
22	.4904	.6097	.1783	.2134	.2439	.1677	.1989
23	.5281	.6036	.176	.2134	.2804	.1619	.1989
24	.128	.5281	.4755	.2214	1.2696	.2683	.1696
Max	.7621	.8962	.6097	.724	1.2696	.415	.4954
Min	.128	.4298	.176	.2	.2195	.1619	.1448
Avg	.4436	.6503	.3709	.3499	.3500	.2745	.2940

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064032 / 33 KV Sahuli Sub-Station

Feeder No / Name : 202 / 11 KV Rajola Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.4321	.381	.3688	
2				.4321	.4024	.3688	
3				.4167	.3658	.3812	
4				.4064	.3506	.3978	
5				.4064	.3353	.3647	
6				.442	.3658	.3353	
8	.4268		.5639				.5182
9	.4801	.4268	.6401				.6097
10	.4801	.4725	.6718				.6706
11	.5121	.5418	.7343				.6249
12	.5601	.6097	1.2654				.7316
13	.5761	.6321	1.4022				.7316
14	.6081	.602	1.4022				.8078
15	.6081	.587	1.358				.7773
21				.381	.3052	.1829	
22				.381	.3149	.2187	
23				.381	.3149	.2134	
24					.381	.3688	.1981
Max	.6081	.6321	1.4022	.442	.4024	.3978	.8078
Min	.4268	.4268	.5639	.381	.3052	.1829	.1981
Avg	.5314	.5531	1.0047	.4087	.3517	.3200	.6300

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064032 / 33 KV Sahuli Sub-Station

Feeder No / Name : 203 / 11 KV Shahapur Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.6722	.7964	.8688	.8775	.9335	.9412
2	.6344	.6722	.7964	.8326	.8402	.8775	.9145
3	.6173	.6722	.7682	.8145	.8029	.8589	.9145
4	.6344	.6908	.7316	.7783	.8215	.8962	.8962
5	.6516	.6908	.7682	.7602	.8402	.8962	.9145
6	.6859	.7468	.8048	.724	.8589	.9149	.9231
7	.703	.7842	.8048	.7316	.924	.8775	.9328
8	.703	.7468	.7682	.8326	.8871	.8215	.823
9	.8215	.6767	.7023	.8596	.8215	.8326	.8048
10	.7842	.6767	.7499	.8413	.7282	.7602	.7682
11	.6908	.6697	.7682	.823	.7468	.7682	.7133
12	.6908	.6036	.7059	.7682	.7655	.7133	.7316
13	.6161	.5853	.6767	.6401	.7655	.724	.7316
14	.5788	.5611	.6767	.6767	.7468	.7316	.7133
15	.5601	.5487	.6697	.695	.7095	.7316	.695
16	.6535	.6036	.7023	.6401	.7468	.7059	.695
17	.6722	.567	.724	.6767	.7468	.7602	.7499
18	.8402	.7499	.7964	.823	.8215	.8131	.823
19	1.0082	1.0136	1.1706	1.1706	1.2696	1.1584	1.2254
20	1.0456	1.0791	1.1706	1.1827	1.251	1.1765	1.2197
21	1.0082	1.0317	1.0498	1.1458	1.1763	1.1222	1.1643
22	.9522	.9694	1.0317	1.1016	1.1203	1.134	1.1088
23	.8775	.9145	.9979	1.0269	1.1203		1.0349
24	.6687	.7282	.823	.8871	.9335	1.0456	.9313
Max	1.0456	1.0791	1.1706	1.1827	1.2696	1.1765	1.2254
Min	.5601	.5487	.6697	.6401	.7095	.7059	.695
Avg	.7396	.7356	.8189	.8459	.8884	.8806	.8904

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064032 / 33 KV Sahuli Sub-Station

Feeder No / Name : 206 / 11 KV Bhandara Feeder SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.7375	.6706	.6859	
2				.7748	.6706	.6443	
3				.7748	.6706	.6443	
4				.7907	.6706	.6859	
5				.7716	.6859	.6859	
6				.7907	.7011	.6859	
7		1.0456					
8	.7468	1.0395	.9646				.8642
9	.8642	.945	1.0467				.9602
10	.9503	1.0364	.4725				1.0936
11	.9995	1.0974	.4725				1.1092
12	1.0486	1.0987	.4784				1.2186
13	1.1022	1.1385	.4843				1.2186
14	1.153	1.1227	.463				1.2186
15	1.1022	1.0936	.4218				1.2186
21				.6859	.6783	.7468	
22				.6859	.6783	.6173	
23				.6859	.6783	.6249	
24					.6859	.6859	.6097
Max	1.153	1.1385	1.0467	.7907	.7011	.7468	1.2186
Min	.7468	.945	.4218	.6859	.6706	.6173	.6097
Avg	.9959	1.0686	.6005	.7442	.6790	.6707	1.0568

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064032 / 33 KV Sahuli Sub-Station

Feeder No / Name : 208 / 11 KV Explosive - II NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder Feeder KV- 11 / (CONTINUOUS PROCESS)(NO STAGGERING)
 OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1488	1.1576	1.773	1.4523	1.3392	1.2071	1.1317
2	1.046	1.251	1.7551	1.4712	1.2826	1.1883	1.1317
3	.9602	1.419	1.7177	1.5844	1.2071	1.2071	1.094
4	.8573	1.4563	1.6975	1.6975	1.226	1.1576	1.094
5	.8402	1.5278	1.3535	1.773	1.3203	1.1317	.9808
6	.823	1.3203	1.2803	1.2071	.9808	1.1317	.8676
7	.8916	1.1883	1.2437	1.0562	.9054	1.0751	.7682
8	1.1317	1.2637	.9694	.7733	.811	.7356	.4904
9	.7468	1.2071	1.0059	.9054	.6979	.4904	.3734
10	.6722	.6722	.7133	.3772	.2075	.2075	.6535
11	.2801	.0754	.4755	.7545	.0377	.2829	.2054
12	.1509	.1509	.2829	.1132	.0377	.0754	
13	.1132	.1509	.2452	.2075	.0754	.0377	.0373
14	.0377	.2452	.5281	.2075	.1132	.0377	.2427
15	.0377	.2452	.4904	.2075	.1509	.1509	.112
16	.7282	.415	.6602	.2075	.3772	.0754	.0747
17	.7545	1.6409	1.0185	.9619	1.0829	.2263	.2054
18	.9054	1.5089	1.1694	.9808	1.1128	.7733	.6161
19	.9997	1.4335	1.2071	1.094	1.2696	.8676	.8215
20	1.0185	1.4712	1.0374	1.226	1.3392	1.0751	.9149
21	1.0374	1.5089	1.0185	.9997	1.251	.9619	.8962
22	1.0829	1.4146	1.0562	1.1128	1.1763	.9054	.7922
23	1.1016	1.7164	1.226	1.1694	1.1949	1.094	.7842
24	1.2003	1.1576	1.7918	1.4523	1.0374	1.2071	1.1317
Max	1.2003	1.7164	1.7918	1.773	1.3392	1.2071	1.1317
Min	.0377	.0754	.2452	.1132	.0377	.0377	.0373
Avg	.7736	1.0666	1.0715	.9580	.8431	.7210	.6704

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064032 / 33 KV Sahuli Sub-Station

Feeder No / Name : 209 / 11 KV Awarmara Gaothan SEPARATED GAOTHAN FEEDERS
Feeder Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1867	.1829	.3077	.2801	.2614	.2926
2	.1715	.1867	.1829	.3109	.2614	.2614	.3109
3	.1715	.1867	.1829	.3258	.2614	.2241	.2865
4	.2058	.2054	.1991	.3292	.2801	.2614	.3326
5	.2572	.2987	.2534	.3292	.3361	.3174	.3696
6	.3086	.3174	.3258	.3658	.3326	.3734	.3511
7	.3086	.3547	.3658	.3658	.4805	.3547	.3326
8	.3258	.3361	.3258	.3696	.3326	.3734	.3475
9	.2054	.2987	.2743	.2926	.3174	.3109	.2957
10	.1867	.2012	.2534	.2012	.1867	.0905	.1294
11	.1494	.128	.1267	.128	.1307	.0924	.0739
12	.0934	.1267	.1448	.1097	.1307	.0924	.0739
13	.112	.1097		.1097	.0747	.1109	.0924
14	.1307	.128	.181	.2012	.0934	.1294	.1848
15	.1294	.1463	.1097	.1463	.1307	.1294	.1478
16	.0934	.128	.1829	.128	.2054	.1494	.08
17	.112	.128	.1097	.128	.1307	.1433	.0739
18	.1494	.3658	.1991	.2075	.2054	.1463	.037
19	.2241	.439	.4207	.439	.4854	.4207	.4435
20	.3734	.3658	.3801	.3881	.4481	.4024	.3881
21	.3547	.3439	.3658	.3696	.3734	.3841	.3881
22	.3174	.2743	.3658	.3361	.3734	.3511	.3511
23	.2987	.2378	.3326	.3174	.3361	.3109	.3174
24	.1886	.2241	.2172	.3109	.2801	.2987	.2926
Max	.3734	.439	.4207	.439	.4854	.4207	.4435
Min	.0934	.1097	.1097	.1097	.0747	.0905	.037
Avg	.2100	.2382	.2471	.2716	.2695	.2496	.2497

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064032 / 33 KV Sahuli Sub-Station

Feeder No / Name : 401 / 33 KV SAINATH NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0617	.0672	.0658	.0652	.0549	.0566	.0823
2	.0617	.0784	.0713	.0597	.0549	.056	.0823
3	.0669	.0896	.0768	.0645	.0549	.0504	.0768
4	.0772	.0784	.0823	.0591	.0549	.0504	.0832
5	.0874	.0728	.0878	.0698	.0549	.0504	.0665
6	.0977	.0896	.0878	.0776	.0543	.0616	.0554
7	.0926	.0896	.0869	.076	.0388	.0504	.0604
8	.1029	.0952	.0841	.0752	.0554	.0448	.0499
9	.1064	.0896	.0752	.0604	.056	.0384	.0658
10	.0952	.0878	.0691	.0384	.0392	.0444	.0943
11	.0784	.0933	.0841	.0549	.0616	.0554	.0665
12	.0728	.0768	.0814	.0494	.0728	.0658	.0713
13	.0728	.0823	.0823	.0604	.056	.0658	.0832
14	.0728	.0823	.0878	.0549	.0504	.0597	.0832
15	.1008	.0869	.0923	.0439	.0504	.0597	.0658
16	.1176	.1097	.1043	.0549	.0448	.0591	.0713
17	.1064	.0878	.0988	.0604	.0392	.0597	.0604
18	.0896	.0814	.0933	.0549	.0504	.0604	.0713
19	.0728	.0543	.0933	.0439	.0672	.0645	.0943
20	.0672	.0549	.0933	.0329	.0616	.0597	.0943
21	.0896	.0713	.0658	.0274	.0728	.0537	.0998
22	.084	.0713	.0665	.0439	.0672	.0597	.1064
23	.0728	.0713	.0652	.0165	.0622	.0658	.0887
24	.0463	.0672	.0652	.0658	.0549	.056	.0832
Max	.1176	.1097	.1043	.0776	.0728	.0658	.1064
Min	.0463	.0543	.0652	.0165	.0388	.0384	.0499
Avg	.0831	.0804	.0817	.0546	.0554	.0562	.0774

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 067009 / 132 KV KARDHA SUBSTATION

Feeder No / Name : 401 / 33KV KARDHA INCOMER NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / INCOMING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	3.1927	3.1367	3.0807	3.0247	3.1367	3.1687
16	2.7446	3.1367	2.9127	3.0807	3.3048	2.8829
24	3.0556	3.0556	3.2819	3.4168	3.5288	3.5288
Max	3.1927	3.1367	3.2819	3.4168	3.5288	3.5288
Min	2.7446	3.0556	2.9127	3.0247	3.1367	2.8829
Avg	2.9976	3.1097	3.0918	3.1741	3.3234	3.1935

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 067009 / 132 KV KARDHA SUBSTATION

Feeder No / Name : 402 / 33 KV GADEGAON FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.0319	.9602	8.1499	.7202	2.5789	1.8141
16		.2846	7.6458	3.678	6.2894	1.3272
18	.6602					
24	3.2819	1.8519	2.1948	1.7164	.9991	1.3923
Max	3.2819	1.8519	8.1499	3.678	6.2894	1.8141
Min	.6602	.2846	2.1948	.7202	.9991	1.3272
Avg	1.9913	1.0322	5.9968	2.0382	3.2891	1.5112

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 067009 / 132 KV KARDHA SUBSTATION

Feeder No / Name : 403 / 33 KV PAHELA FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
 INCOMER Feeder KV- 33 / (CONTINUOUS PROCESS)(NO STAGGERING)
 INCOMING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.7558	1.5844	1.8107	1.1763	.9425	1.7541
16	1.382	1.1694	1.1443	1.3146	1.3969	1.382
24	.7922	.8059	.8779	1.0402	1.4969	1.0208
Max	1.7558	1.5844	1.8107	1.3146	1.4969	1.7541
Min	.7922	.8059	.8779	1.0402	.9425	1.0208
Avg	1.31	1.1866	1.2776	1.1770	1.2788	1.3856

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 067009 / 132 KV KARDHA SUBSTATION

Feeder No / Name : 404 / 33 KV KARACHKHEDA FEEDER PURELY LIS FEEDERS
Feeder KV- 33 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	27-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.0151	.0192	.0229	.0256	.0283
16	.0309	.0031	.032	.0034	.0514
Max	.0309	.0192	.032	.0256	.0514
Min	.0151	.0031	.0229	.0034	.0283
Avg	.023	.0112	.0275	.0145	.0399

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 067009 / 132 KV KARDHA SUBSTATION

Feeder No / Name : 405 / 33KV SAHULI KARDHA INCOMER

Feeder KV- 33 / INCOMING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.7147	3.2819	2.6612	1.5123	1.1203	2.0513
16	1.9605	1.7147	1.6575	1.0317	.7922	1.0642
24	2.32	2.3525	2.5503	2.0005	2.2634	1.9239
Max	2.32	3.2819	2.6612	2.0005	2.2634	2.0513
Min	1.7147	1.7147	1.6575	1.0317	.7922	1.0642
Avg	1.9984	2.4497	2.2897	1.5148	1.3920	1.6798

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 067009 / 132 KV KARDHA SUBSTATION

Feeder No / Name : 406 / 33 KV TAKALI

Feeder KV- 33 / INCOMING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.6975	1.6804	1.8107	1.9239	1.3375	1.8673
16	1.5364	1.701		1.8107	1.8461	1.9204
24	1.8107	1.6632	1.7187	1.9547	1.6049	2.1176
Max	1.8107	1.701	1.8107	1.9547	1.8461	2.1176
Min	1.5364	1.6632	1.7187	1.8107	1.3375	1.8673
Avg	1.6815	1.6815	1.7647	1.8964	1.5962	1.9684

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 067009 / 132 KV KARDHA SUBSTATION

Feeder No / Name : 407 / 33 KV KARDHA INCMER 2 NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / INCOMING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.9054	2.5206	2.2325	1.1317	.9877	2.2611
16	1.3443	1.5524	1.1883	1.2449	1.2197	1.3306
24	.7356	1.1763	1.0517	.9054	2.0165	1.8296
Max	1.3443	2.5206	2.2325	1.2449	2.0165	2.2611
Min	.7356	1.1763	1.0517	.9054	.9877	1.3306
Avg	.9951	1.7498	1.4908	1.094	1.4080	1.8071

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 068015 / 220 KV BHANDARA S/S

Feeder No / Name : 200 / 220/11KV SUNFLAG WARTHI
INCOME Feeder KV- 11 / OUTGOING

DATE	24-FEB-18	25-FEB-18
HR	Load (MW)	Load (MW)
24	3.0994	3.3762
Max	3.0994	3.3762
Min	3.0994	3.3762
Avg	3.0994	3.3762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 068015 / 220 KV BHANDARA S/S

Feeder No / Name : 202 / 11 KV SUNFLAG FEEDER
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.4548	.4923		
2				.4841	.5068		
3				.4841	.5068		
4				.4841	.4923		
5				.5135	.5135		
6				.5135	.5281		
8	.5716	.6405	.6455				.6308
9	.6144	.7186	.7335				.7335
10	.6226	.7343	.7042				.8362
11	.695	.7499	.7188				.8215
12		.7968	.8215				.8655
13	.719	.8124	.7042				.9095
14	.7331	.6718	.8509				.9362
15	.743	.6859	.8069				.8509
18							.8509
21				.4904	.4938	.4108	
22				.5053	.5093	.4401	
23				.6413	.5093	.4515	.8619
24					.4988	.4904	.4365
Max	.743	.8124	.8509	.6413	.5281	.4904	.9362
Min	.5716	.6405	.6455	.4548	.4923	.4108	.4365
Avg	.6712	.7263	.7482	.5079	.5051	.4482	.7939

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 068015 / 220 KV BHANDARA S/S

Feeder No / Name : 203 / 11 KV DABHA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.2865	.2926	.3395	.3772	.3511	.3439
2	.2957	.2926	.2926	.3395	.3584	.3511	.3403
3	.3142	.2743	.2926	.3395	.3584	.3361	.3403
4	.3174	.2743	.3077	.3292	.3584	.3174	.3366
5	.3584	.2987	.3077	.3292	.3772	.3361	.3544
6	.3772	.3361	.3258	.362	.3961	.3734	.3544
7	.3395	.3547	.3292	.3658	.3734	.3395	.3012
8	.3395	.3547	.3109	.3511	.3547	.3584	.3189
9	.3206	.2926	.3109	.2587	.3174	.3018	.2481
10	.2926	.2378	.2926	.2772	.2957	.2829	.3012
11	.2561	.2195	.2743	.2587	.2957	.2829	.2481
12	.2561	.2378	.2743	.2587	.2587	.2658	.2481
13	.2715	.2772	.2926	.2402	.2926	.2481	.2658
14	.2534	.2402	.2926	.2279	.2926	.2658	.2743
15	.2534	.2614	.2743	.2279	.2561	.2658	.2743
16	.2328	.2987	.2561	.2279	.2772	.2658	.2743
17	.2686	.2987	.3109	.298	.2587	.2303	.2743
18	.2686	.3361	.3292	.3467	.2772	.2896	.3292
19	.3801	.4854	.4938	.4681	.4572	.4525	.4755
20	.362	.4527	.439	.4681	.4572	.4344	.5121
21	.362	.3961	.3961	.3944	.4024	.4163	.4572
22	.3077	.3395	.3881	.4075	.3982	.415	.4527
23	.3224		.3772	.415	.3696	.3544	.4024
24	.3142	.3045	.3018	.3395	.3772	.3696	.3366
Max	.3801	.4854	.4938	.4681	.4572	.4525	.5121
Min	.2328	.2195	.2561	.2279	.2561	.2303	.2481
Avg	.3069	.3109	.3235	.3279	.3432	.3293	.3360

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 068015 / 220 KV BHANDARA S/S

Feeder No / Name : 205 / SAHAKAR NAGAR FEEDER
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1612	.2507	.2149	.3077	.394	.3761
2	.1829	.1629	.2507	.2218	.3077	.3582	.3403
3	.1646	.1448	.2507	.2218	.2865	.3439	.3258
4	.1629	.1448	.2658	.2172	.2865	.3258	.3258
5	.1791	.1829	.2865	.2149	.3045	.3258	.3258
6	.197	.1829	.3045	.197	.3077	.3077	.3224
7	.1612	.2012	.2012	.197	.3077	.3045	.3045
8	.2534	.2012	.2195	.2172	.362	.3045	.3403
9	.2172	.2561	.2195	.2353	.3982	.2507	.362
10	.3801	.2561	.439	.2715	.3982	.4251	.5611
11	.4024	.3292	.4706	.3077	.4656	.4251	.4706
12	.4207	.439	.4525	.2715	.5194	.4108	.6697
13	.4207	.4572	.4706	.3077	.5373	.4572	.6697
14	.4477	.4755	.5068	.3258	.591	.4755	.6268
15	.4298	.4525	.4887	.3109	.5731	.5914	.6268
16	.5373	.4477	.4887	.3658	.5792	.4908	.4835
17	.4344	.4119	.4477	.2534	.5792	.5258	.4835
18	.362	.4298	.394	.2715	.5068	.5373	.5552
19	.3475	.394	.3761	.2715	.4656	.4835	.5552
20	.2926	.3439	.3582	.362	.4656	.4656	.4656
21	.3292	.3258	.3361	.3582	.4298	.4477	.4835
22	.3439	.3077	.3361	.3403	.4075	.4887	.4298
23	.3077		.3547	.3258	.4075	.4477	.4835
24	.2012	.1791	.2715	.3045	.3258	.4119	.4477
Max	.5373	.4755	.5068	.3658	.591	.5914	.6697
Min	.1612	.1448	.2012	.197	.2865	.2507	.3045
Avg	.3066	.2995	.3517	.2744	.4217	.4166	.4598

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 068015 / 220 KV BHANDARA S/S

Feeder No / Name : 206 / 11 KV MMKD FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5655	1.5466	1.3203	1.5844	1.6032	1.6975	1.6975
2	1.6221	1.6385	1.4712	1.5844	1.6032	1.7528	1.6787
3	1.773	1.5432	1.5432	1.5684	1.6787	1.6956	1.6956
4	1.7164	1.5466	1.6004	1.5844	1.6409	1.6221	1.6598
5	1.6598	1.4712	1.5466	1.5655	1.5655	1.6598	1.6787
6	1.5844	1.4335	1.5466	1.5844	1.5089	1.5813	1.6787
7	1.5466	1.5432	1.5844	1.6598	1.5844	1.5844	1.6598
8	1.7353	1.4712	1.4901	1.5844	1.8296	1.5278	1.5089
9	1.6409	1.5655	1.5844	1.3769	1.8107	1.5655	1.1883
10	1.5844	1.6385	1.4712	1.5844	1.6409	.5847	1.6975
11	1.4335	1.5432	1.5278	1.5278	1.4146	1.7164	1.773
12	1.6598	1.4335	1.4523	1.5466	1.5466	1.773	1.7541
13	1.4937	1.4901	1.5655	1.5278	1.5466	1.7918	1.8673
14	1.587	1.5466	1.6787	1.6221	1.5684	1.6221	1.6221
15	1.6221	1.7918	1.7541	1.6409	1.7177	1.8861	1.8107
16	1.4712	1.3392	1.6032	1.5466	1.6598	1.6991	1.9427
17	1.6221	1.5466	1.773	1.6409	1.8673	1.8298	1.7918
18	1.6221	1.358	1.6787	1.6975	1.6787	1.7918	1.773
19	1.905	1.5278	1.5466	1.6221	1.7164	1.8861	1.7353
20	1.8107	1.5089	1.6409	1.6221	1.8107	1.773	1.8673
21	1.7164	1.3203	1.5339	1.7353	1.5466	1.8111	1.8296
22	1.6598	1.4146	1.7164	1.5089	1.5089	1.7918	1.7164
23	1.6032		1.7353	1.5655	1.3203	1.848	1.6975
24	1.6975	1.4901	1.5278	1.5844	1.5655	1.6598	1.7177
Max	1.905	1.7918	1.773	1.7353	1.8673	1.8861	1.9427
Min	1.4335	1.3203	1.3203	1.3769	1.3203	.5847	1.1883
Avg	1.6389	1.5091	1.5789	1.5861	1.6223	1.6730	1.7101

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 068015 / 220 KV BHANDARA S/S

Feeder No / Name : 401 / 33KV BHANDARA

Feeder KV- 33 / INCOMING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6409	1.6975	1.9805	2.0936	2.3765	2.0936	2.2068
2	1.6409	1.7147	1.9805	2.0936	2.3765	2.0576	2.2291
3	1.6975	1.6575	2.037	2.1148	2.32	2.0576	2.2291
4	1.6975	1.5844	2.037	2.0936	2.32	1.9805	2.2068
5	1.6409	1.6975	2.037	2.037	2.32	1.9239	2.2068
6	1.6975	1.9239	2.2068	2.037	2.2634	2.037	2.2068
7	2.1502	2.2634	2.2068	2.2634	2.4331	2.3765	2.32
8	2.0936	2.4086	2.0936	2.0936	2.4331	2.2068	2.0936
9	2.0936	2.2634	1.8673	2.2068	2.2068	1.8673	1.9805
10	1.8107	2.2634	1.9805	2.1502	2.32	2.1502	1.8107
11	1.7924	1.8673	1.9605	1.9805	2.0936	2.037	1.6975
12	1.6975	2.1502	1.8107	2.0936	1.9239	1.9805	1.6975
13	1.4712	1.5844	1.8107	1.9805	1.9239	1.7924	1.5278
14	1.5844	1.4146	1.8673	1.9239	1.8673	1.7364	1.6409
15	1.5844	1.5278	1.8107	1.8107	1.8673	1.8107	1.6975
16	1.6409	2.8292	1.8107	1.8673	1.7541	1.9239	1.6975
17	1.5844	1.5278	1.8107	1.8673	1.9239	1.6975	1.6409
18	1.6975	1.7541	1.9805	1.8673	1.8107	1.8107	1.6409
19	2.0936	2.32	2.5463	2.4331	2.3765	2.2965	2.2634
20	1.9805	2.3765	2.4646	2.4331	2.3765	2.4331	2.32
21	2.1502	2.2068	2.5766	2.3663	2.3765	2.5463	2.32
22	2.1502	1.9805	2.6595	2.5463	2.5463	2.4897	2.3765
23	1.9239		2.3765	2.4331	2.4331	2.3525	2.2068
24	1.6975	1.8107	1.9805	2.32	2.2634	2.1502	2.2068
Max	2.1502	2.8292	2.6595	2.5463	2.5463	2.5463	2.3765
Min	1.4712	1.4146	1.8107	1.8107	1.7541	1.6975	1.5278
Avg	1.8005	1.9489	2.0789	2.1294	2.2044	2.0754	2.0177

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 068015 / 220 KV BHANDARA S/S

Feeder No / Name : 402 / 33KV MOHADI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2634	2.0936	2.0576	4.0741	3.9043	3.9609	2.6886
2	2.2634	2.0165	2.037	4.0741	4.0175	3.9609	2.6886
3	2.2634	1.9239	2.0936	3.9506	4.0175	3.8477	2.7446
4	2.3765	1.9239	2.0936	3.9506	4.1307	3.8295	2.7726
5	2.32	2.0005	2.0936		4.1307	4.0741	2.8006
6	2.3765	2.0936	2.1502	4.2438	4.1872	4.2438	2.8292
7	2.1502	2.037	2.037	2.0851	2.2634	2.5149	2.3765
8	3.9043	4.3004		1.9805	2.2068	2.4331	4.8097
9	3.678	4.357	4.1872	2.037	2.037	2.32	4.8663
10	3.4517	4.5268	4.2438	1.8673	1.7924	2.2634	4.9228
11	3.9209		4.257	1.6409	1.8107	2.1502	4.8663
12	3.9609	3.2819	3.6969	1.6409	1.8107	1.9805	5.036
13	4.0175	3.6214	3.7912	1.8107	1.6975	2.0725	5.2624
14	4.0741	3.9043	4.1307	1.8673	1.5844	2.1285	4.9228
15	4.0175	3.9043	2.4331	2.037	1.8673	1.9805	1.6975
16	1.6975	1.6975	1.6975	1.9239	1.9239	2.2634	1.6409
17	1.358	1.358	1.4003	1.6975	1.6975	2.1502	1.4146
18	1.6975	1.5844	1.9239	1.7541	1.9239	2.1502	1.9805
19	2.5463	2.6595	2.8292	2.6595	2.5463	2.8858	2.8858
20	2.7161	2.7161	2.8006	2.8858	3.0807	3.0556	2.9424
21	2.2634	2.6595	4.0889	4.3004	3.3951	3.0556	2.8858
22	2.4331	2.2634	4.1307	4.0175	4.0175	2.8292	2.7161
23	1.9805		4.0741	4.0175	4.1872	2.8006	2.7161
24	2.2068	2.1502	1.9805	4.0741	3.9043	4.0175	2.7726
Max	4.0741	4.5268	4.257	4.3004	4.1872	4.2438	5.2624
Min	1.358	1.358	1.4003	1.6409	1.5844	1.9805	1.4146
Avg	2.7474	2.6852	2.8795	2.8083	2.8389	2.8737	3.2183

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 068015 / 220 KV BHANDARA S/S

Feeder No / Name : 403 / 33 KV MUJABI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5844	1.6409	1.8673	2.037	2.2068	2.2634	1.8107
2	1.5844	1.6004	1.7541	2.32	2.2068	2.1719	1.7541
3	1.5123	1.5278	1.7541	2.32	2.2634	2.037	1.701
4	1.4712	1.5278	1.8107	2.32	2.2634	2.037	1.701
5	1.5684	1.6575	1.8673	2.32	2.32	2.1719	1.7364
6	1.6409	1.6975	1.9239	4.6165	2.2634	2.2634	1.7541
7	1.4146	1.5844	1.6975	1.4563	1.4146	1.5278	1.6409
8	1.8673	1.9239	1.8673	1.2883	1.358	1.0751	1.4146
9	2.037	2.037	2.037	1.3014	1.2449	1.1883	2.037
10	2.037	2.0936	2.037	1.4146	1.358	1.3014	2.1502
11	2.0936		2.3525	1.4712	1.5844	1.5278	4.074
12	1.7924	1.9239	1.4563	1.4146	1.2449	1.358	2.2634
13	2.0165	1.9239	2.0936	1.358	1.5844	1.6409	2.037
14	2.037	1.9805	2.2068	1.4146	1.8107	1.6804	2.037
15	2.32	2.0936	1.5844	1.6975	1.7541	1.5844	2.2068
16	1.4146	1.9805	1.5844	1.5278	1.6975	.6161	1.4146
17	1.4712		1.4003	1.4712	1.5844	1.7364	1.358
18	1.4146	1.4712	1.4146	1.3014	1.4712	1.5844	1.1883
19	1.9239	2.0936	1.9239	1.9805	2.037	2.2405	1.8673
20	1.7541	1.9805	1.9239	2.037	2.037	2.2068	1.9239
21	1.7541	1.9239	2.0725	1.9239	1.8484	2.5206	1.9239
22	1.8107	1.8107	2.037	2.4331	2.3765	2.4897	1.9239
23	1.6975	1.6975	2.037	2.3765	2.4331	2.3765	1.9805
24	1.6409	1.6409	1.8673	1.9239	2.32	2.32	1.8107
Max	2.32	2.0936	2.3525	4.6165	2.4331	2.5206	4.074
Min	1.4146	1.4712	1.4003	1.2883	1.2449	.6161	1.1883
Avg	1.7441	1.8096	1.8571	1.9052	1.8618	1.8300	1.9046

Feederwise Load Information for **All Feeders**

GONDIA_ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384]

BU 0384

Substation No/ Name :- 068015 / 220 KV BHANDARA S/S

Feeder No / Name : 404 / 33 kv Khat (under ramtek sdn) Feeder KV- 33 / INCOMING **NON SHEDDABLE EXPRESS HV FEEDERS (CONTINUOUS PROCESS) (NO STAGGERING)**

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.679	.679	.7922	.7356	.8488	1.2003
2	.5658	.6287	.679	.9054	.679	.7922	1.3014
3	.5093	.6287	.679	.8871	.679	.8002	1.1883
4	.5658	.5658	.679	.8871	.679	.8002	1.3014
5	.6224	.679	.743	.8871	.7922	.8488	1.3014
6	.679	.7922	.8002	.9619	.8488	.9054	1.358
7	.9054	1.0185	.9619	.9619	1.0751	.9619	1.4712
8	.8488	.9619	.9054	1.0751	1.0751	1.1317	1.4003
9	.9054	.9619	.9054	1.0751	1.0751	1.0751	1.5844
10	.8488	.9619	.9619	1.0185	.9619	1.0185	1.4146
11	.7922	.8488	.8962	.9619	.7282	.9054	.679
12	.7922	.9054	.9619	.9619	.7282	1.0185	1.358
13	.8488	.9054	.9619	.9619	1.0185	.9054	1.4712
14	.9054	.8488	1.0185	.9619	1.3014	1.2323	1.5278
15	.9619	.8488	.9054	.9619	1.3014	1.2883	
16	.7922	.8488	.9619	.9619	.9619	1.4146	1.358
17	.8488	.7356	.9522	.7922	.9619	1.2449	1.3014
18	.8488	.7922	1.0185	.9054	.9054	1.2323	1.4712
19	.9054	.9054	1.0751	.9619	1.0751	1.5278	1.4712
20	.9054	.9054	1.0185	.9054	1.0185	1.5278	1.5278
21	.8488	.8488	.9522	2.037	.9619	1.4003	1.4712
22	.7922	.7922	.8488	.7287	.9054	1.4146	1.358
23	.679	.7356	.7922	.7922	.8488	1.3014	1.3014
24	.6224	.679	.679	.7922	.7356	.8488	1.1883
Max	.9619	1.0185	1.0751	2.037	1.3014	1.5278	1.5844
Min	.5093	.5658	.679	.7287	.679	.7922	.679
Avg	.7733	.8116	.8765	.9641	.9189	1.1019	1.3481

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 068015 / 220 KV BHANDARA S/S

Feeder No / Name : 802 / 220 KV SUNFLAG

Feeder KV- 220 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	18.4843	14.3347	17.3526	15.6836	17.9241	15.4664	17.7298
2	14.712		15.0892	15.0892	21.5021	16.5981	18.107
3	20.3704	16.5981	15.6226	15.0892	17.7298	16.9753	17.7298
4	18.4843	17.7298	16.0037	17.1773	21.5021	16.2209	17.5278
5	17.3526	14.712	15.0892	20.5381	16.5981	17.2954	17.3526
6	19.6159	18.107	15.0892	16.4304	14.3347	16.5981	18.107
7	17.3526	15.5236	13.9575	16.5981	16.5981	14.712	17.1468
8	17.1773	17.1468	15.0892	13.5803	15.6836	17.5278	16.2628
9	14.9368	17.5507	17.7298	13.4431	19.2197	15.6226	15.3635
10	16.8267	14.9368	17.002	15.3102	20.6981	16.0037	15.7408
11	14.4147	14.9368	19.4178	16.2209	21.6583	14.4795	13.9003
12	17.0134		17.1925	16.8039	16.8039	15.6226	14.7691
13	13.466	15.3102	17.3716	18.2975	17.3526	16.0037	15.1578
14	15.2035	16.5981	18.1108	19.4178	22.0317	17.5278	14.7501
15	16.4609	16.9753	13.5803	16.8039	15.4664	15.6226	16.5028
16	17.5507	18.8615	13.7174	14.3347	18.107	16.3847	13.2564
17	18.107	16.5981	17.3526	18.107	16.5981	16.7658	14.1899
18	16.4304	16.9753	13.9575	15.8436	13.203	16.0037	15.1463
19	14.712	13.9575	15.4664	18.8615	16.2209	16.9753	19.7569
20	15.0892	19.2387	14.3347	14.3347	15.8436	17.7298	19.3873
21	21.5021	17.3526	18.107	16.057	16.8039	16.8039	19.9246
22	16.5981	15.4664	17.3526	14.9368	17.9241	16.4304	16.9639
23	17.7298	17.3526	15.0892	16.8039	16.5981	14.712	19.3873
24	19.6159	17.1468		18.107	14.712	15.8436	15.0892
Max	21.5021	19.2387	19.4178	20.5381	22.0317	17.7298	19.9246
Min	13.466	13.9575	13.5803	13.4431	13.203	14.4795	13.2564
Avg	17.0503	16.5186	16.0468	16.4112	17.5464	16.2469	16.6354

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA URBAN S/DN[381] BU 1929

Substation No/ Name :- 064022 / 33 KV BHANDARA TOWN

Feeder No / Name : 201 / 11 KV Ambedkar ward

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5144	.5093	.5144	.5144	.5144	.5144
2	.4954	.5144	.5093	.5144	.5144	.5144	.5144
3	.4954	.5144	.5093	.5144	.5335	.5144	.5144
4	.5144	.5144	.5093	.5144	.5335	.5144	.5144
5	.5144	.5335	.5093	.5144	.5335	.5335	.5144
6	.5144	.5335	.5093	.5144	.5335	.5144	.5144
7	.5144	.5144	.5281	.5144	.5335	.4954	.5144
8	.5525	.5335	.5281	.5144	.5144	.5144	.5144
9	.5281	.5335	.5144	.5144	.5335	.5144	.5144
10	.5093	.5335	.5144	.5144	.5144	.5144	.5335
11	.5093	.5144	.5144	.5144	.5144	.5144	.5144
12	.5281	.5144	.5144	.5144	.4954	.5144	.5144
13	.5093	.5335	.5144	.5335	.5144	.5144	.5144
14	.5093	.5144	.5144	.5335	.5144	.5144	.5144
15	.5093	.5144	.5144	.5335	.5144	.5144	.5144
16	.5093	.5144	.5144	.5144	.5144	.5144	.5335
17	.5144	.5093	.5144	.5144	.5144	.5144	.5335
18	.4954	.5093	.5144	.5144	.5144	.5144	.5335
19	.5144	.4904	.5144	.5144	.4954	.4954	.5335
20	.5144	.5093	.5335	.5525	.5144	.5144	.5144
21	.5144	.5093	.5144	.5525	.5144	.5144	.5335
22	.5144	.5093	.5144	.5144	.5335	.5144	.5335
23	.5144	.5093	.5144	.5144	.5144	.5144	.5144
24	.5144	.5144	.5093	.5144	.5144	.5144	.5144
Max	.5525	.5335	.5335	.5525	.5335	.5335	.5335
Min	.4954	.4904	.5093	.5144	.4954	.4954	.5144
Avg	.5135	.5169	.5149	.5200	.5184	.5136	.5200

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA URBAN S/DN[381] BU 1929

Substation No/ Name :- 064022 / 33 KV BHANDARA TOWN

Feeder No / Name : 202 / 11KV Sahakar Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	1.1041	1.2883	1.448	1.5242	1.3535	1.3937
2	.9907	1.0974	1.2883	1.4299	1.4861	1.2986	1.3756
3	.9907	1.0608	1.2696	1.4118	1.4861	1.3169	1.3756
4	.9907	1.1222	1.2883	1.448	1.4861	1.2567	1.3575
5	1.0669	1.1706	1.307	1.4661	1.5242	1.3169	1.3756
6	1.2193	1.2308	1.3256	1.4842	1.5813	1.39	1.3756
7	1.448	1.5729	1.531	1.5384	1.6385	1.4998	1.3937
8	1.4098	1.5746	1.363	1.3937	1.7147	1.3352	1.267
9	1.363	1.3394	1.3336	1.3394	1.8099	1.448	1.2071
10	1.3256	1.3394	1.448	1.3937	1.7737	1.5242	1.1888
11	1.2136	1.3352	1.4098	1.3575	1.4842	1.448	1.1157
12	1.2323	1.2803	1.3336	1.448	1.3575	1.4098	1.0608
13	.9896	1.0608	1.3336	1.1765	1.2851	1.4098	.9877
14	1.1389	1.0059	1.3717	1.3575	1.3032	1.4098	1.1157
15	1.1203	1.1706	1.3717	1.3575	1.3213	1.3717	1.1706
16	1.2136	1.2071	1.2765	1.3032	1.1946	1.4289	1.1523
17	1.0974	1.1016	1.134	1.4098	1.2986	1.1946	1.2193
18	1.2254	1.307	1.2851	1.4861	1.2437	1.1946	1.3336
19	1.3032	1.531	1.5384	1.6004	1.4632	1.4118	1.4098
20	1.2308	1.5123	1.5565	1.7147	1.4632	1.4842	1.5051
21	1.3756	1.3817	1.6632	1.7718	1.39	1.5565	1.4861
22	1.2308	1.3443	1.7375	1.7718	1.5524	1.6289	1.4861
23	1.2437	1.3443	1.6108	1.6766	1.5729	1.4661	1.3908
24	1.0669	1.1403	1.2883	1.4661	1.5813	1.39	1.4118
Max	1.448	1.5746	1.7375	1.7718	1.8099	1.6289	1.5051
Min	.9896	1.0059	1.134	1.1765	1.1946	1.1946	.9877
Avg	1.1882	1.2639	1.3897	1.4688	1.4807	1.3977	1.2982

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA URBAN S/DN[381] BU 1929

Substation No/ Name :- 064022 / 33 KV BHANDARA TOWN

Feeder No / Name : 204 / 11 KV Kham Talao (Takiya
Ward) Feeder KV- 11 / OUTGOING SHEDDABLE URBAN

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258	.3582	.415	.4298	.3982	.394	.4119
2	.3258	.3403	.415	.4119	.3982	.3761	.394
3	.3077	.3224	.3772	.394	.362	.3582	.394
4	.3077	.3224	.3961	.3761	.362	.3982	.3761
5	.3258	.362	.415	.394	.3982	.4119	.394
6	.3258	.4119	.4338	.394	.4344	.4163	.4119
7	.362	.4119	.4338	.4119	.4525	.4477	.4298
8	.4163	.3761	.3982	.394	.4344	.3761	.394
9	.4338	.3582	.3801	.394	.4477	.3801	.394
10	.3961	.394	.3982	.4119	.394	.4163	.4477
11	.3961	.3761	.3982	.4119	.394	.3982	.394
12	.3772	.3761	.3801	.394	.394	.3801	.4477
13	.2829	.394	.3982	.394	.3761	.1991	.4298
14	.3772	.3582	.3982	.394	.394	.3982	.4298
15	.3395	.3582	.3982	.3761	.394	.3982	.394
16	.3584	.394	.3982	.3403	.4119	.4163	.4525
17	.3403	.3772	.394	.3982	.4344	.394	.4525
18	.4298	.4338	.4298	.4344	.4835	.394	.4887
19	.4835	.547	.5373	.543	.591	.5552	.543
20	.5194	.547	.5373	.5249	.5373	.5552	.5611
21	.4656	.5281	.5194	.5068	.5194	.5552	.543
22	.4656	.5093	.4835	.5068	.5014	.5014	.5249
23	.394	.4715	.4835	.4887	.4656	.4656	.5068
24	.362	.3761	.415	.4477	.4344	.4298	.4298
Max	.5194	.547	.5373	.543	.591	.5552	.5611
Min	.2829	.3224	.3772	.3403	.362	.1991	.3761
Avg	.3799	.4043	.4264	.4239	.4339	.4173	.4435

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA URBAN S/DN[381] BU 1929

Substation No/ Name :- 064022 / 33 KV BHANDARA TOWN

Feeder No / Name : 205 / 11 KV Nashik Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1088	1.1088	1.1763	1.2382	1.2567	1.2936	1.2382
2	1.0719	1.0974	1.1763	1.2197	1.2567	1.2567	1.2197
3	1.0349	1.0425	1.1763	1.2012	1.2197	1.2567	1.2197
4	1.0349	1.0608	1.1949	1.1827	1.1827	1.2752	1.2012
5	1.1088	1.0903	1.2323	1.2012	1.2197	1.2382	1.2012
6	1.1458	1.2197	1.251	1.2012	1.2936	1.2382	1.2197
7	1.1643	1.2382		1.2197	1.3491	1.2752	1.2382
8	1.0719	1.0974	1.1576	1.1827	1.2382	1.1088	1.2197
9	1.0642	1.1088	1.2197	1.1643	1.1827	1.1273	1.1088
10	1.1389	1.0903	1.2012	1.2567	1.1827	1.1088	1.1273
11	1.1016	1.1088	1.1827	1.2382	1.2752	1.0349	1.2197
12	1.0642	1.0534	1.1458	1.2382	1.2382	.924	1.1088
13	.9335	.9425	1.1088	1.1458	1.0349	1.1458	1.1458
14	1.0829	1.0534	1.0719	1.2012	1.2197	1.2382	1.2012
15		1.0534	1.0534	1.2382	1.2567	1.1273	1.2382
16	1.1203	1.0719	1.2012	1.2197	1.3121	1.0903	1.2197
17	1.0059	1.0829	1.1088	1.2936	1.262	1.2197	1.2567
18	1.1827	1.2136	1.2197	1.4415	1.386	1.2567	1.2936
19	1.5708	1.5123	1.5154	1.5339	1.6448	1.6263	1.5154
20	1.4266	1.475	1.5154	1.5339	1.5708	1.6078	1.5893
21	1.3352	1.4563	1.5154	1.5154	1.5154	1.5154	1.5708
22	1.3535	1.3256	1.4784	1.4969	1.5154	1.46	1.4969
23	1.262	1.2323	1.2936	1.4045	1.386	1.4415	1.4969
24	1.0719	1.134	1.1949	1.2567	1.2936	1.3535	1.2567
Max	1.5708	1.5123	1.5154	1.5339	1.6448	1.6263	1.5893
Min	.9335	.9425	1.0534	1.1458	1.0349	.924	1.1088
Avg	1.1502	1.1612	1.2344	1.2844	1.3039	1.2592	1.2751

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA URBAN S/DN[381] BU 1929

Substation No/ Name :- 064022 / 33 KV BHANDARA TOWN

Feeder No / Name : 206 / 11KV Station Road

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2452	.2263	.2641	.2641	.3395	.2829	.2829
2	.2263	.2241	.2641	.2452	.3395	.2641	.2641
3	.2263	.2075	.2641	.2452	.3206	.2614	.2641
4	.1886	.2075	.2641	.2263	.3206	.2987	.2829
5	.2263	.2263	.2829	.2452	.3395	.2829	.2829
6	.2263	.2829	.2829	.2641	.3395	.2801	.2829
7	.2452	.3206	.3584	.2829	.3395	.3018	.3018
8	.2452	.2641	.2452	.2452	.2829	.2452	.2829
9	.2829	.3018	.2829	.3584	.3584	.3395	.3018
10	.2829	.2641	.3206	.3584	.3018	.3395	.2829
11	.2452	.2452	.2829	.3584	.2829	.3395	.2829
12	.2263	.2452	.2452	.3584	.2641	.3584	.2829
13	.2075	.2263	.2641	.2452	.2452	.3584	.2452
14	.2263	.2452	.2829	.3206	.3018	.3395	.2641
15	.2263	.2641	.2829	.3206	.3018	.3206	.2452
16	.2075	.2641	.2641	.3395	.3018	.2641	.3018
17	.2263	.2452	.2641	.3395	.2829	.3206	.3018
18	.2263	.2263	.2829	.3395	.3018	.2641	.3206
19	.3206	.3018	.3395	.3584	.3584	.3206	.3395
20	.3395	.3395	.3395	.3961	.3395	.3772	.3395
21	.3206	.3395	.3395	.3961	.3584	.3772	.3584
22	.3206	.3206	.3395	.3961	.3395	.3395	.3584
23	.2641	.3018	.3018	.3961	.3206	.3018	.3395
24	.2641	.2452	.2641	.2829	.3584	.2829	.3018
Max	.3395	.3395	.3584	.3961	.3584	.3772	.3584
Min	.1886	.2075	.2452	.2263	.2452	.2452	.2452
Avg	.2507	.2640	.2884	.3159	.3183	.3109	.2963

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064003 / 33 KV JAMB S/S

Feeder No / Name : 201 / 11 KV Jamb Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3045	.3258	.3658	.3982	.4024	.4066	.3982
2	.3045	.3258	.3658	.3982	.4024	.4066	.3801
3	.3045	.362	.3658	.3982	.3841	.4066	.3801
4	.3045	.3658	.3658	.3982	.4207	.4024	.3982
5	.3224	.3841	.3658	.3982	.4207	.4024	.4163
6	.3403	.3841	.3801	.3841	.4207	.3982	.4163
7	.3582	.3544	.3801	.3841	.3841	.3801	.3801
8	.3582	.3582	.362	.3658	.3881	.3403	.4075
9	.3403	.362	.3439	.4572	.3696	.394	.4119
10	.3582	.3439	.2715	.3658	.3696	.3403	.3582
11	.2715	.3439	.2896	.4207	.2427	.3224	.3582
12	.2926	.2926	.2353	.3841	.2896	.3403	.3403
13	.2896	.2378	.2896	.3403	.3582	.2686	.3582
14	.4207	.2378	.3077	.3761	.362	.3224	.3403
15	.2858	.2715	.2686	.2865	.3045	.3403	.3403
16	.3012	.3439	.362	.3582	.3258	.3439	.3582
17	.3012	.3439	.3582	.3439	.3641	.362	.3761
18	.4115	.4557	.3403	.362	.3841	.3801	.394
19	.5658	.5731	.4835	.567	.5788	.6154	.6089
20	.5415	.6036	.5552	.567	.5788	.5249	.6268
21	.5228	.5304	.5249	.567	.5415	.5194	.5552
22	.4066	.439	.4477	.4938	.4755	.4656	.4656
23	.3475	.3841	.4119	.439	.4251	.4344	.4525
24	.3045	.3258	.3658	.394	.4207	.4066	.3982
Max	.5658	.6036	.5552	.567	.5788	.6154	.6268
Min	.2715	.2378	.2353	.2865	.2427	.2686	.3403
Avg	.3566	.3729	.3670	.4103	.4006	.3968	.4133

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064003 / 33 KV JAMB S/S

Feeder No / Name : 202 / 11 KV Andhalgaon Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.3292	.4108	.4024	.4024	.4294	.4251
2	.3109	.3292	.4108	.4024	.3658	.4294	.4066
3	.3109	.3696	.3734	.4024	.3658	.4066	.4066
4	.3109	.3696	.3734	.4024	.3841	.4066	.3881
5	.3292	.3696	.3921	.4024	.3841	.3881	.3881
6	.3475	.3734	.3921	.3841	.3841	.3921	.3881
7	.3292	.3258	.4294	.3658	.3658	.3326	
8	.3292	.3511	.3921	.3292	.3658	.3475	.3077
9	.3292	.3326	.3439	.4024	.2926	.3658	.3658
10	.3475	.2957	.3292	.3658	.3109	.3841	.3475
11	.3109	.3142	.3658	.3475	.3475	.3109	.3475
12	.2957	.2957	.2926	.3109	.3326	.2743	.2926
13	.2402	.2587	.2926	.3258	.2926	.2957	.2926
14	.2402	.3326	.2926	.3258	.3292	.3109	.2926
15	.2658	.3475	.3292	.3439	.3475	.2926	.2957
16	.2572	.3109	.2926	.3077	.2804	.2957	.2957
17	.2601	.3109	.3109	.3045	.2658	.2772	.3511
18	.3155	.362	.439	.3439	.362	.3142	.3696
19	.5228	.5601	.5487	.5304	.5658	.5544	.5729
20	.5228	.5788	.5304		.547	.5544	.5914
21	.4904	.5415	.5304	.5121	.5281	.5359	.5729
22	.4108	.4854	.4755	.4572	.4854	.499	.543
23	.3696	.4108	.4207	.439	.4481	.4435	.499
24	.3292	.3292	.4108	.4207	.4024	.4294	.4251
Max	.5228	.5788	.5487	.5304	.5658	.5544	.5914
Min	.2402	.2587	.2926	.3045	.2658	.2743	.2926
Avg	.3377	.3702	.3908	.3839	.3815	.3863	.3985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064003 / 33 KV JAMB S/S

Feeder No / Name : 203 / 11 KV Dhop Gaothan Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0924	.1097	.0732	.128	.1267	.1307	.1494
2	.0924	.1097	.0732	.128	.1086	.1307	.1307
3	.0924	.1097	.0732	.128	.1086	.12	.1307
4	.0914	.1294	.0732	.128	.1086	.1294	.1307
5	.1097	.1478	.1254	.128	.1267	.1478	.1494
6	.1307	.168	.1433	.1463	.1448	.1478	.2054
7	.1109	.1097	.1254	.128	.1267	.1463	.1494
8	.1307	.1109	.1254	.1478	.1254	.1294	.1267
9	.1097	.0924	.0716	.1294	.1254	.1109	.1267
10	.0914	.0924	.0895	.0924	.0895	.1097	.1086
11	.0732	.1109	.0724	.0924	.1097	.0914	.0905
12	.0924	.0934	.0724	.0924	.0739	.0914	.0905
13	.0732	.0934	.0905	.0934	.0914		.0732
14	.0905	.0934	.0724	.1307	.0914	.1097	.0732
15	.0732	.0934	.1086	.0934	.0924	.0914	.0914
16		.0934	.0905	.0934	.0709	.0924	.0924
17	.0895	.112	.1086		.0886	.0924	.1052
18	.1097	.0914	.1463	.112	.128	.1294	.1227
19	.2054	.1829	.1991	.1629	.2054	.2241	.2033
20	.1867	.2012	.2012	.181	.2075	.2427	.1848
21	.1886	.1829	.1829	.1991	.1867	.2241	.1848
22	.1494	.1463	.168	.1629	.1663	.168	.1848
23	.1294	.128	.1294	.1448	.1307	.168	.1848
24	.112	.1097	.0732	.1294	.1267	.1307	.1494
Max	.2054	.2012	.2012	.1991	.2075	.2427	.2054
Min	.0732	.0914	.0716	.0924	.0709	.0914	.0732
Avg	.1141	.1213	.1120	.1292	.1234	.1373	.1349

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064003 / 33 KV JAMB S/S

Feeder No / Name : 204 / 11kv JAMB AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.4816	.3913	.4641	
2					.4064	.4641	
3					.4214	.4641	
4					.4365	.4744	
5					.4687	.4902	
6					.4687	.5182	
7				.4967			
8	.6554	.6554	.7316	.5719			.7621
9	.5117	.7926	.7926	.5418			.8383
10	.5487	.7316	.884	.5268			.945
11	.6019	.8078	.8383				.9755
12	.7499	.8993	.8993				1.0212
13	.8749	.945	.9297				1.0517
14	.9061	1.0517	.9602				1.0669
15	.823	.9145	.8383				1.0212
21				.4214	.4218	.4374	
22				.4365	.4641	.4374	
23				.4214	.4801	.4374	
24					.3913	.4641	.4218
Max	.9061	1.0517	.9602	.5719	.4801	.5182	1.0669
Min	.5117	.6554	.7316	.4214	.3913	.4374	.4218
Avg	.7090	.8497	.8593	.4873	.4350	.4651	.9004

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064003 / 33 KV JAMB S/S

Feeder No / Name : 205 / 11kv Andhalgaon AG Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6468	.6859	.7811				
2	.6283	.6859	.7811				
3	.6283	.6859	.7621				
4	.6535	.6859	.7733				
5	.6535	.724	.7733				
6	.6908	.7392	.7733				
8				1.0242	.7621	.8686	1.0317
9				.9061	.8688	.9522	1.0498
10				.8905	.8535	1.0164	1.1222
11				.9217	1.0242	1.0242	1.1222
12				.9686	1.0642	.9694	1.086
13				.884	1.0349	1.0059	1.1222
14				.884	1.0269	.9877	1.086
15				.8535	.9795	.9877	1.0791
21	.7049	.6859	.7023				
22	.724	.743	.7316				
23	.7049	.7621	.695				
24		.7049	.7811	.695			
Max	.724	.7621	.7811	1.0242	1.0642	1.0242	1.1222
Min	.6283	.6859	.695	.695	.7621	.8686	1.0317
Avg	.6706	.7103	.7554	.8920	.9518	.9765	1.0874

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064003 / 33 KV JAMB S/S

Feeder No / Name : 207 / 11kv Dhop Agp

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.8383	.8383	.8402	
2				.8383	.8383	.8402	
3				.8383	.8535	.8573	
4				.8383	.8535	.8573	
5				.8383	.8688	.8916	
6				.8535	.8688	.9259	
8	.9297	.9602	1.0004				1.1963
9	1.0159	.9945	1.0513				1.1831
10	1.0117	1.0174	1.0852				1.2174
11	.9945	1.0513	1.1191				1.2689
12	1.046	1.0682	1.1191				1.3375
13	1.0631	1.0682	1.1361				1.3904
14	1.0974	1.0682	1.1361				1.2717
15	.9922	1.0682	1.1022				1.1702
21				.8383	.8916	1.0229	
22				.8383	.9259	1.0402	
23				.8535	.8402	1.0229	
24					.8383	.8402	1.0229
Max	1.0974	1.0682	1.1361	.8535	.9259	1.0402	1.3904
Min	.9297	.9602	1.0004	.8383	.8383	.8402	1.0229
Avg	1.0188	1.0370	1.0937	.8417	.8617	.9139	1.2287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064009 / 33 KV MOHADI S/S

Feeder No / Name : 206 / 11 KV Chichkheda Feeder
SP Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3475	.3475	.3174	1.1888	1.1576	1.1949	.4755
2	.3292	.3475	.2987	1.1706	1.1576	1.2071	.4572
3	.3326	.3511	.2987	1.1706	1.1389	1.1763	.4572
4	.3142	.3696	.3361	1.1888	1.1389	1.2136	.439
5	.3326	.3696	.3734	1.1706	1.1763	1.2637	.439
6	.3511	.3881	.4294	1.2986	1.2696	1.3392	.439
7	.2987	.9242	.3326	.3109	.2614	.3174	.2926
8	.9808	1.4335	1.6409	.2561	.2614	.2614	1.5364
9	.9997	1.4901	1.6221	.2195	.2402	.2172	1.5364
10	.8865	1.3203	1.6032	.2012	.197	.2172	1.6827
11	1.3014	1.6787	1.5089	.1734	.1829	.1991	1.8296
12	1.2826	1.6575	1.6221	.1595	.1646	.1629	1.905
13	1.3769	1.2449	1.5089	.1578	.1829	.1886	1.9993
14	1.2449	1.5089	1.4712	.1734	.2012	.1886	1.7718
15	1.2637	1.4523	1.358	.1886	.2012	.1715	1.6194
16	.1402	.1372	.1715	.156	.1829	.1715	.1715
17	.1214	.1543	.1372	.1509	.1829	.2058	.1991
18	.1433	.1928	.2378	.2481	.2279	.2012	.2353
19	.3658	.4805	.4755	.4938	.5175	.4572	.5304
20	.462	.499	.4938	.5068	.5415	.5487	.5304
21	.4572	.4805	1.262	1.182	1.3014	.5121	.5487
22	.3841	.4294	1.1523	1.1694	1.307	.4938	.5068
23	.3658	.3734	1.1888	1.1458	1.2696	.4755	.4525
24	.3475	.3475	.3361	1.1888	1.1763	1.2136	.4755
Max	1.3769	1.6787	1.6409	1.2986	1.307	1.3392	1.9993
Min	.1214	.1372	.1372	.1509	.1646	.1629	.1715
Avg	.6012	.7491	.8407	.6363	.6516	.5666	.8554

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064009 / 33 KV MOHADI S/S

Feeder No / Name : 207 / 11 KV Pardi Feeder SP

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.2012	.2241	.567	.4668	.5415	.2926
2	.1829	.2033	.2241	.5487	.4668	.547	.2743
3	.1848	.2033	.2614	.5487	.4481	.5228	.2743
4	.2033	.2218	.2801	.567	.4527	.5415	.2561
5	.2402	.2402	.2801	.567	.4668	.5847	.2561
6	.2587	.2587	.2801	.5853	.5601	.6413	.2743
7	.1867	.5281	.2033	.1646	.1867	.1867	.1829
8	.547	.547	.5847	.128	.1307	.1307	.5487
9	.4904	.5281	.5847	.1829	.1663	.1448	.5487
10	.5658	.547	.6036	.1829	.1612	.1629	.5853
11	.5281	.4904	.5847	.1387	.1646	.1267	.6224
12	.5281		.547	.124	.1463	.0724	.5847
13	.547	.3395	.6602	.1402	.1463		.6036
14	.547	.3395	.6224	.156	.1646		.6478
15	.5281	.3395	.5658	.1543	.1463	.1372	.5716
16	.1227	.12	.12	.1214	.1463	.12	.1372
17	.104	.12	.0857	.1341	.128	.12	.0905
18	.1075	.1227	.128	.12	.1578	.1463	.1086
19	.2926	.3142	.2926	.3045	.3142	.3109	.3109
20	.3142	.3142	.2012	.3439	.3361	.3292	.3475
21	.3109	.3326	.6219	.591	.6413	.3292	.3475
22	.2561	.2801	.6036	.5493	.5975	.3109	.3077
23	.2195	.2614	.567	.4435	.5601	.2926	.2715
24	.2012	.2012	.2241	.567	.462	.5415	.2926
Max	.5658	.547	.6602	.591	.6413	.6413	.6478
Min	.104	.12	.0857	.12	.128	.0724	.0905
Avg	.3187	.3067	.3896	.3304	.3174	.3109	.3641

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064009 / 33 KV MOHADI S/S

Feeder No / Name : 208 / 11 KV Express Feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3547	.2926	.2801	.2926	.3174	.3361	.3292
2	.3547	.2743	.2801	.2743	.3174	.3326	.3109
3	.3326	.2772	.2987		.3361	.3174	.3109
4	.3547	.2772	.2987	.2926	.3174	.3174	.2926
5	.3734	.2926	.2801	.2926	.3361	.3547	.2926
6	.3547	.2957	.2987	.2926	.3174	.3734	.3109
7	.3361	.2957	.2801	.2926	.3174		.4207
8	.3547	.2987	.2801	.3109	.3734	.4755	.5121
9	.3734	.3174	.2987	.2561	.3547	.4572	.4938
10	.3547	.2987	.2987	.3658	.4481	.6036	.4024
11	.3734	.3361	.2987	.3921	.3841	.5611	.4294
12	.3734	.3174	.2987	.2195	.3475	.567	.3547
13	.3547	.3361	.2987	.3292	.2561	.5611	.3547
14	.3547	.3547	.2926	.4572	.3292	.5068	.3734
15	.3361	.2614	.3174	.5175	.4024	.5068	.3547
16	.3439	.2534	.3142	.4207	.3841	.4938	.3224
17	.3292	.2957	.2957	.2743	.4024	.6468	.3109
18	.3109	.298	.3109	.2801	.4207	.5853	.3142
19	.3292	.3109	.3109	.2801	.4251	.3841	.2957
20	.2772	.3109	.2926	.2957	.3511	.3109	.2957
21	.2957	.3109	.2926	.3361	.3326	.3109	.2987
22	.3142	.2987	.2926	.3361	.2987	.3292	.2801
23	.2957	.2801	.2926	.3361	.3361	.3292	.2801
24	.3547	.2957	.2801	.2926	.3361	.3361	.3292
Max	.3734	.3547	.3174	.5175	.4481	.6468	.5121
Min	.2772	.2534	.2801	.2195	.2561	.3109	.2801
Avg	.3411	.2992	.2951	.3234	.3517	.4347	.3446

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064009 / 33 KV MOHADI S/S

Feeder No / Name : 209 / 11 KV Mohadi Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18
HR	Load (MW)
16	.1524
Max	.1524
Min	.1524
Avg	.1524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064009 / 33 KV MOHADI S/S

Feeder No / Name : 210 / 11kv Kanhalgaon SP

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.1097	.112	.3475	.3734	.3174	.128
2	.0914	.1097	.112	.3292	.3734	.3018	.1097
3	.0924	.1109	.112	.3292	.3921	.2987	.1097
4	.0739	.1109	.112	.3475	.3734	.3174	.128
5	.1109	.1109	.112	.3475	.3547	.3395	.128
6	.1109	.1294	.112	.3658	.3921	.3772	.1463
7	.112	.3584	.0924	.1097	.112	.112	.128
8	.3584	.3772	.3772	.0914	.0934	.0934	.3841
9	.3772	.415	.4338	.0732	.0924		.3841
10	.3395	.3395	.4715	.0732	.0716		.4572
11	.3018	.3395	.4527	.0693	.0366		.4904
12	.3206	.4001	.4715	.0532	.0549		.5281
13	.3395	.4338	.4527	.0351	.0549	.0343	.5658
14	.3772	.415	.4338	.0347	.0549	.0514	.4763
15	.3772	.3584	.4338	.0343	.0549	.0514	.4954
16	.0526	.0514	.0343	.0347	.0366	.0514	.0514
17	.052	.0514	.0343	.0335	.0366	.0514	.0543
18	.0537	.0351	.0732	.0709	.0526	.0732	.0724
19	.128	.1294	.1097	.128	.1294	.128	.1463
20	.1294	.1478	.128	.1267	.1307	.128	.1463
21	.128	.1478	.3841	.3761	.3584	.128	.1463
22	.1097	.1307	.3658	.3721	.3547	.128	.1267
23	.1097	.1307	.3475	.3696	.3361	.128	.1267
24	.0914	.1097	.112	.3475	.3734	.3174	.128
Max	.3772	.4338	.4715	.3761	.3921	.3772	.5658
Min	.052	.0351	.0343	.0335	.0366	.0343	.0514
Avg	.1804	.2105	.2450	.1875	.1956	.1714	.2357

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064009 / 33 KV MOHADI S/S

Feeder No / Name : 212 / 11kv Dongargaon SP

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.1097	.112	.8596	.7947	.8775	.1463
2	.0914	.1097	.112	.8413	.8131	.8501	.1463
3	.0914	.1109	.112	.8413	.8131	.8402	.1463
4	.1109	.1109	.0934	.823	.7947	.8402	.128
5	.1109	.128	.0934	.823	.7762	.8962	.128
6	.1294	.1294	.0934	.8596	.8131	1.0082	.1463
7	.0914	.3326	.112	.1097	.1097	.1109	.1097
8	.8589	.9335	.9149	.0732	.0914	.0914	.8596
9	.9335	.9522	.8589	.0732	.0739	.0732	.8413
10	.924	.9149	.9335	.0732	.0739	.0732	.9877
11	.9709	.9149	.9055	.056	.0732	.0543	1.0269
12	.9709	.9335	.924	.0549	.0549	.0549	.9896
13	.9709	.9149	.9335	.0549	.0732	.0543	1.0456
14	.9896	.9149	.9877	.0549	.0732	.0724	1.0269
15	.9709	.9335	.9979	.0762	.0732	.0732	.9896
16	.0724	.0543	.0549	.0549	.0549	.0549	.0537
17	.0549	.0554	.0549	.0549	.0549	.0554	.0732
18	.0732	.0701	.0732	.0732	.0914	.0549	.0914
19	.1646	.1646	.1646	.1646	.1663	.1646	.1829
20	.1848	.1829	.1829	.1848	.1848	.1829	.2012
21	.1663	.1646	.8596	.8131	.8871	.1829	.2012
22	.1294	.1494	.8596	.823	.8962	.1646	.1646
23	.1109	.1494	.8596	.8131	.8962	.1463	.1463
24	.1097	.1109	.1307	.8596	.8048	.8775	.1463
Max	.9896	.9522	.9979	.8596	.8962	1.0082	1.0456
Min	.0549	.0543	.0549	.0549	.0549	.0543	.0537
Avg	.3913	.3977	.4760	.3965	.3974	.3273	.4158

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064009 / 33 KV MOHADI S/S

Feeder No / Name : 401 / 33 KV MIDC

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8748	1.8748	1.6729	2.0953	2.0513	2.2731	2.205
2	1.885	1.8748	1.6729	2.0404	1.9959	2.2177	2.205
3	1.885	1.8953	.6653	1.985	1.9959	2.2297	2.0948
4	1.8296	1.8953	1.6735	1.985	1.9405	2.1737	
5	1.8748	1.9405	1.841	2.0953	2.1068	2.1737	.9979
6	1.9405	1.913	1.841	2.1502	2.2731	2.1742	2.2605
7	1.9404	1.9959	1.1054	2.0399	2.1067	2.1622	1.8193
8	2.1067	2.0759	2.0628	2.1508	1.9959	2.2057	1.8748
9	1.8209	2.1737	1.8953	2.0948	2.0513	2.2068	2.0411
10	.8956	1.7844	2.2297	1.985	2.1508	1.9302	2.1513
11	1.8296	1.8953	2.1622	1.7278	1.5998	1.921	2.2731
12	1.5523	1.8398	.7762	1.8193	1.8753	1.9404	2.4526
13	1.3935	1.7644	1.8295	1.5437	1.6546	1.8102	2.1176
14	1.5523	1.6724	1.7741	1.3786	2.0959	1.8296	2.1182
15	1.8387	1.6724	1.9405	1.4969	1.9856	1.6546	2.0621
16	1.8296	1.8295	1.6632	1.885	1.9856	2.2057	2.2371
17	1.6546	.8196	1.7095	1.765	1.765	1.885	2.0404
18	1.7644	1.8336	1.8193	1.8748	1.885	1.8199	2.2062
19	2.1502	2.2057	2.1502	2.0953	2.1622	2.0953	2.3159
20	1.9959	2.1508	2.0399	2.0399	2.2177	2.1502	2.2057
21	1.885	1.9845	1.985	1.9959	2.1067	2.1502	2.0404
22	2.1067	1.8953	2.0387	2.0953	2.2851	1.985	2.1508
23	2.0067	1.8393	2.0953	2.0513	2.3411	2.205	2.2057
24	1.9296	1.885	1.9501	2.0953	2.0513	2.3411	2.2605
Max	2.1502	2.2057	2.2297	2.1508	2.3411	2.3411	2.4526
Min	.8956	.8196	.6653	1.3786	1.5998	1.6546	.9979
Avg	1.8143	1.8630	1.7747	1.9369	2.0283	2.0725	2.1016

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064033 / 33 KV Kardi

Feeder No / Name : 201 / 11kv Kardi AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.1736	1.4255	1.4083	
2				1.2039	1.4251	1.4089	
3				1.1904	1.4922	1.4083	
4				1.2209	1.4754	1.4255	
5				1.2209	1.5089	1.3916	
6				1.2717	1.5089	1.3904	
8	1.286	1.442	1.5604				1.6448
9	1.439	1.5261	1.6108				1.6575
10	1.5261	1.56	1.7177				1.6907
11	1.5257	1.6632	1.7295				1.8107
12	1.5432	1.6991	1.7804				1.8564
13	1.4922	1.7147	1.7635				1.8442
14	1.4922	1.6817	1.2378				1.8564
15	1.4754	1.6278	1.2209				1.8233
21				1.3735	1.3413	1.3565	
22				1.4746	1.3763	1.3904	
23				1.4419	1.4083	1.3904	
24					1.4746	1.3923	1.3904
Max	1.5432	1.7147	1.7804	1.4746	1.5089	1.4255	1.8564
Min	1.286	1.442	1.2209	1.1736	1.3413	1.3565	1.3904
Avg	1.4725	1.6143	1.5776	1.2857	1.4437	1.3963	1.7305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064033 / 33 KV Kardi

Feeder No / Name : 202 / Koka Feeder

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3203	1.406	1.3904	1.4582	1.5089	1.4586	1.4922
2	1.2717	1.3546	1.4232	1.4419	1.4251	1.4752	1.4754
3	1.2689	1.3413	1.3904	1.4413	1.4413	1.4922	1.4752
4	1.2717	1.2929	1.3889	1.4413	1.4419	1.442	1.4752
5	1.3032	1.3245	1.387	1.4413	1.3923	1.442	1.4251
6	1.335	1.326	1.387	1.4251	1.4083	1.4091	1.4413
7	1.3203	1.4217	1.3717	1.4922	1.4737	1.4251	1.4083
8	1.3565	1.4232	1.3565	1.4586	1.4582	1.5261	1.4419
9	1.3748	1.3904	1.358	1.4922		1.5257	1.5089
10	1.3904	1.3889	1.0227	1.56	1.4586	1.543	1.5415
11	1.4074	1.3717	1.4413	1.5257	1.4586	1.5261	1.6244
12	1.3426	1.4413	1.6108	1.5592	1.3904	1.5091	1.6741
13	1.3108	1.5089	1.5927	1.5091	1.3916	1.4752	1.1361
14	1.3748	1.543	1.5769	1.56	1.3735	1.3748	1.0513
15	1.3735	1.5775	1.5089	1.5083	1.4083		1.0974
16	1.3077	1.543	1.56	1.576	1.4251	1.3904	1.4922
17	1.3056	1.5604	1.6095	1.5089	1.4413	1.4413	1.56
18	1.3916	1.5775	1.5769	1.5261	1.5261	1.4922	1.643
19	1.5249	1.5424	1.6766	1.6933	1.7436	1.3904	1.643
20	1.5089	1.5769	1.7295	1.6956	1.6907	1.7269	1.6598
21	1.4754	1.5604	1.6095	1.643	1.5927	1.6617	1.6787
22	1.4251	1.4918	1.5089	1.6278	1.5083	1.56	1.5927
23	1.4074	1.4413	1.4752	1.5424	1.543	1.5261	1.5261
24	1.3717	1.3748	1.4403	1.4413	1.4251	1.4918	1.5091
Max	1.5249	1.5775	1.7295	1.6956	1.7436	1.7269	1.6787
Min	1.2689	1.2929	1.0227	1.4251	1.3735	1.3748	1.0513
Avg	1.3642	1.4492	1.4747	1.5237	1.4751	1.4915	1.4822

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064033 / 33 KV Kardi

Feeder No / Name : 203 / Kardi Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.3429	.3772	.4344	.3944	.3688	.4207
2	.3121	.3391	.373	.4207	.3856	.3121	.4207
3	.2804	.3185	.3429	.4119	.3561	.3391	.4075
4	.2629	.3222	.3467	.3944	.3521	.3391	.4163
5	.2401	.3391	.3258	.3982	.3315	.3222	.3814
6	.2601	.3353	.3294	.3681	.3113		.362
7	.298	.3121	.3506	.3506	.3121	.3258	.333
8	.2713	.1715	.2947	.3121	.2915	.2303	.3121
9	.3086	.1865	.3258	.2743	.2774	.2454	.3086
10	.2601	.2058	.3155	.2743	.2481	.2947	.3222
11	.2629	.2572	.2601	.2601	.2481	.298	.3052
12	.2947	.2374	.2454	.2572	.2629	.2774	.3185
13	.2572	.2601	.2629	.2743	.2915	.2804	.3018
14	.2572	.2572	.2804	.2804	.2947	.3077	.3185
15	.2947	.2601	.2804	.2947	.2743	.2947	.2883
16	.2743	.2629	.2686	.2947	.2883	.2743	.1991
17	.2515	.2686	.2804	.333	.3185	.298	.2947
18	.3481	.2743	.3155	.3506	.3353	.3294	.3561
19	.4527	.3467	1.5777	.4801	.4475	.5316	.39
20	.4641	.4801	.5083	.5028	.4424	.5144	.4191
21	.4191	.4508	.5083	.4973	.4144	.5144	.4973
22	.4161	.4287	.4908	.463	.4144	.4908	.4641
23	.3856	.407	.4334	.4191	.3978		.4807
24	.3155	.3315	.3856	.4382	.3978	.3688	.4382
Max	.4641	.4801	1.5777	.5028	.4475	.5316	.4973
Min	.2401	.1715	.2454	.2572	.2481	.2303	.1991
Avg	.3116	.3082	.3950	.3660	.337	.3435	.3648

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064040 / MIDC MOHADI

Feeder No / Name : 201 / 11 kv Mohadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2561	.3109	.3109	.3109	.3292	.3109
2		.2561	.2926	.2926	.2926	.3292	.3109
3		.2378	.3142	.2743	.2926	.2926	.2926
4		.2378	.3292	.2743	.2926	.3109	.2926
5		.2561	.3658	.2743	.2926	.3109	.2743
6		.2926	.3658	.2743	.3109	.3109	.3292
7		.3292	.3658	.3109	.3841	.3475	.3109
8		.3109	.3292	.4207	.3109	.3475	.3658
9	.3292	.3658	.3292	.4024	.3326	.3658	.4207
10	.3292	.4024	.3292	.4024	.4572	.3841	.4024
11	.3475	.3658	.3475	.3841	.4024	.3658	.3841
12	.1463	.3658	.3292	.4024	.4207	.3475	.4024
13	.128	.3475	.2926	.3475	.4024	.3841	.3475
14	.3841		.3292	.3292	.4024	.3841	.3475
15	.3292	.2743	.3475	.3292	.3658	.3658	.4755
16	.3292	.3658	.2926	.4207	.4024	.3841	.4024
17	.2926	.3292	.3475	.4572	.3841	.4024	.4024
18	.3109	.3658	.4024	.439	.3841	.3841	.4207
19	.3475	.439	.4024	.439	.4572	.4755	.4938
20	.4207	.4024	.3841	.4024	.4207	.4207	.4755
21	.3841	.3881	.3841	.3841	.4024	.4024	.4207
22	.3475	.3696	.3475	.3658	.4024	.3841	.4024
23	.2926	.3292	.3292	.3292	.3475	.3403	.4024
24	.2743	.2743	.2926	.3109	.3109	.3292	.3292
Max	.4207	.439	.4024	.4572	.4572	.4755	.4938
Min	.128	.2378	.2926	.2743	.2926	.2926	.2743
Avg	.3121	.3288	.3400	.3574	.3659	.3624	.3757

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064040 / MIDC MOHADI

Feeder No / Name : 202 / 11 KV MOHADI MIDC
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0358	.0179		.0537	.0358	.0366	.0179
2	.0358	.0179	.0358	.0537	.0358	.0358	.0179
3	.0358	.0152	.0358	.0358	.0358	.0358	.0179
4	.0358	.0152	.0179	.0537	.0358	.0179	.0179
5	.0537	.0179	.0179	.0537	.0179	.0179	.0358
6	.0537	.0358	.0179	.0537	.0179	.0179	.0358
7	.0537	.0358	.0179		.0179	.0179	.0179
8	.0358	.0358	.5552	.0179	.0358	.0179	
9	.0358	.0358	.0358	.0358	.0358	.0537	.0179
10	.0358	.0179	.0358	.0179	.0358	.0179	.0358
11	.0358	.0358	.0537	.0537	.0537	.0716	.0358
12	.0358	.0537	.0537	.0537	.0537	.0358	.0358
13	.0358	.0358	.0537	.0179	.0537	.0537	.0358
14	.0358		.0537	.0358	.0537	.0358	.0716
15	.0537	.0537	.0179		.0537	.0358	.0358
16	.0358	.0358	.0179	.0716	.0537	.0358	.0358
17	.0537	.0358	.0537	.0358	.0537	.0358	.0358
18	.0358	.0179	.0358	.0179	.0537	.0358	.0358
19	.0358	.0179	.0179	.0179	.0358	.0179	.0358
20	.0179	.0358	.0537	.0358	.0358	.0358	.0358
21	.0179	.0358	.0716	.0358	.0358	.0358	.0537
22	.0179	.0358	.0358	.0179	.0358	.0179	.0358
23	.0179	.0358	.0179	.0179	.0358	.0183	.0358
24	.0358	.0179	.0537	.0537	.0358	.0358	.0358
Max	.0537	.0537	.5552	.0716	.0537	.0716	.0716
Min	.0179	.0152	.0179	.0179	.0179	.0179	.0179
Avg	.0365	.0301	.0592	.0382	.0395	.0321	.0335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064005 / KOSRA SUB STATION

Feeder No / Name : 201 / 11 KV BHAVAD FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2452	.2452	.759	.8223	.9282	.9646
2	.2263	.2452	.2452	.7432	.8065	.9122	.9646
3	.2263	.2263	.2452	.7432	.8223	.9282	.9646
4	.1886	.2263	.2263	.7432	.8223	.9602	.9488
5	.2263	.2263	.2263	.759	.8223	.9762	.9488
6	.2829	.2452	.2641	.8697	1.0279	1.1363	1.1069
7	.2075	.5218	.132	.1509	.2075	.132	.2263
8	.5624	.6325	.7748	.1886	.132	.1509	.1509
9	.6562	.7116	.8381	.1132	.132	.1132	.1132
10	.6405	.7748	.9172	.1132	.1132	.1509	.0754
11	.3795	.759	.9014	.0943	.1132	.1132	.0754
12	.6958	.68	.9172	.0943	.132	.0943	.1132
13	.6642	.7116	.8223	.1132	.132	.0943	.132
14	.6562	.6958	.8223	.1132	.1132	.0754	.132
15	.6009	.7274	.8381	.1132	.1132	.0754	.132
16	.0943	.0754	.1132	.1132	.1132	.0754	.132
17	.1132	.0943	.1132	.1132	.0943		.1132
18	.132	.2829	.2263	.1886	.132	.132	.1132
19	.3206	.3206	.3395	.3206	.3584	.3395	.3206
20	.3395	.3206	.3584	.3584	.3772	.3584	.3584
21	.3206	.3206	.8065	.8539	.9831	.9962	.3395
22	.3018	.2829	.8223	.8855	1.0322	1.012	.3584
23	.2641	.2641	.8065	.8539	1.0159	.9962	.2829
24	.2452	.2452	.2452	.7748	.8223	.9602	.9646
Max	.6958	.7748	.9172	.8855	1.0322	1.1363	1.1069
Min	.0943	.0754	.1132	.0943	.0943	.0754	.0754
Avg	.3571	.4098	.5103	.4239	.4684	.5092	.4180

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064005 / KOSRA SUB STATION

Feeder No / Name : 202 / 11 KV GOSE FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5765	.6299	.763	.7733	.8488	.9242	.9431
2	.5596	.6133	.763	.7733	.8299	.8865	.8676
3	.5596	.6274	.763	.7733	.8488	.9054	.8676
4	.5765	.6783	.7461	.7545	.8488	.9054	.8488
5	.6443	.6952	.8309	.7733	.8676	.8676	.9054
6	.7291	.8817	.9665	.8299	.8676	.9619	.9242
7	.7356	.6979	.811	.7733	.7545	.7356	.7356
8	.7356	.7356	.6413	1.1361	1.2209	1.4523	1.3056
9	.6224	.7545	.6413	1.4582	1.3056	1.3077	1.4752
10	.5281	.5658	.6036	1.3395	1.2239	1.3226	1.4582
11	.5281	.415	.5658	1.4523	1.2407	1.2887	1.3916
12	.4904	.5093	.5847	1.3056	1.2574	1.2548	1.3413
13	.5093	.4904	.5658	1.2548	1.291	1.2039	1.358
14	.5093	.5093	.6036	1.2378	1.291	1.3226	1.3904
15	.5281	.5658	.5658	1.1869	1.2239	1.2616	1.2407
16	.5281	.4715	.5658	.6224	.5093	.5658	.6413
17	.4904	.4904	.5658	.4904	.5658	.4715	.5658
18	.6036	1.0185	.6224	.5658	.547	.4527	.547
19	1.0608	1.1694	1.1883	1.1694	1.2071	1.2071	1.2826
20	1.1506	1.2071	1.2071	1.2637	1.2826	1.2826	1.3014
21	.8488	.8817	1.1506	1.1883	1.2449	1.2637	1.2039
22	.6952	.8648	.9808	.9997	1.0562	1.0562	1.2039
23	.6783	.8139	.9054	.9431	.9431	.9619	1.153
24	.5935	.6299	.78	.8488	.8488	.9242	.9431
Max	1.1506	1.2071	1.2071	1.4582	1.3056	1.4523	1.4752
Min	.4904	.415	.5658	.4904	.5093	.4527	.547
Avg	.6451	.7049	.7659	.9964	1.0052	1.0328	1.0790

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064005 / KOSRA SUB STATION

Feeder No / Name : 203 / 11 KV KONDHA FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8488	.9054	.9808	.8842	.9536	1.1218	1.1269
2	.8676	.8865	.9619	.8669	.9362	1.0576	1.1269
3	.8299	.9054	.9619	.8669	.9536	1.0402	1.1269
4	.7922	.9054	.9619	.8842	.9882	1.0867	1.0923
5	.8488	.9808	1.0185	.9015	1.0229	1.1218	1.2826
6	.9242	.9808	1.1128	1.0056	1.1096	1.283	1.3003
7	.9808	.8322	.9619	.9242	1.0185	.9997	.9808
8	.9709	.9362	1.0056	.9242	.6979	.7922	.9431
9	1.1344	1.0749	1.0513	.8488	.7733	.7733	.811
10	1.0749	1.0923	.9156	.8299	.8488	.7545	.7922
11	.9835	1.1443	.9835	.7733	.7733	.679	.7733
12	.9496	1.1096	.9835	.6979	.811	.6413	.7922
13	.9496	1.0923	.9156	.679	.811	.7545	.7922
14	1.0174	1.0749	.9892	.7167	.7922	.7356	.8676
15	.9556	.9536	.9945	.7545	.7733	.7356	.8676
16	.6036	.6979	.7545	.7733	.7922	.7922	.8488
17	.6036	.6036	.7167	.7378	.7167	.7545	.7922
18	.7733	1.1883	.679	.8299	.8676	.7733	.7733
19	1.226	1.3203	1.3392	1.358	1.358	1.358	1.3769
20	1.1883	1.3014	1.358	1.3203	1.3769	1.358	1.4335
21	1.1694	1.2637	.9709	1.0056	1.0924	.8322	1.4335
22	1.0562	1.1128	.9536	1.0056	1.1517	1.2136	1.3957
23	.9619	1.0374	.9189	.9882	1.1393	1.1963	1.2826
24	.9054	.9054	1.0185	.8842	.9536	1.1269	1.1616
Max	1.226	1.3203	1.358	1.358	1.3769	1.358	1.4335
Min	.6036	.6036	.679	.679	.6979	.6413	.7733
Avg	.9423	1.0127	.9795	.8942	.9463	.9576	1.0489

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064005 / KOSRA SUB STATION

Feeder No / Name : 204 / 11 KV VIRLEE FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2328	.2454	.2507	.4527	.4725	.5093	.5093
2	.2149	.2427	.2507	.4338	.4527	.4904	.4904
3	.2149	.2454	.2507	.4338	.4715	.4904	.4904
4	.2328	.2427	.2865	.415	.4715	.4904	.4715
5	.2507	.2454	.3045	.415	.4338	.4527	.4527
6	.2507	.3155	.3224	.415	.4715	.4904	.4715
7	.3395	.3395	.2865	.3018	.3584	.3584	.3961
8	.3206	.3395	.2829	.3224	.2328	.2263	.2686
9	.3018	.2829	.3772	.394	.3582	.2658	.3045
10	.2641	.2452	.2829	.2507	.3086	.3721	.3224
11	.2075	.2263	.2452	.3224	.3772	.298	.2804
12	.2263	.2075	.5847	.2507	.2743	.2835	.298
13	.2075	.2075	.2641	.3045	.2401	.2658	.3155
14	.2075	.2452	.2641	.3045	.3086	.2126	.298
15	.2075	.2075	.2829	.2686	.2829	.2303	.2804
16	.1886	.2263	.2641	.2075	.2452	.2641	.2641
17	.1698	.2075	.2452	.2452	.2263	.1698	.2829
18	.2641	.6036	.3018	.3018	.3018	.2829	.2641
19	.6979	.6979	.7167	.7167	.6979	.7167	.6602
20	.6979	.7167	.7167	.7545	.7356	.7545	.7356
21	.3155	.3224	.679	.7167	.7356	.7356	.3511
22	.2804	.2686	.5658	.6224	.6224	.6036	.3326
23	.2279	.2507	.5093	.5658	.5281	.547	.3045
24	.2328	.2427	.2507	.4904	.4904	.5093	.5093
Max	.6979	.7167	.7167	.7545	.7356	.7545	.7356
Min	.1698	.2075	.2452	.2075	.2263	.1698	.2641
Avg	.2814	.3073	.3661	.4127	.4207	.4175	.3898

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064005 / KOSRA SUB STATION

Feeder No / Name : 205 / 11 KV PALORA FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4144	.426	.4475	.415	.4338	.4338	.4527
2	.3978	.4096	.4475	.415	.4338	.4338	.4338
3	.3812	.4096	.4475	.415	.4338	.415	.4338
4	.4144	.4424	.4475	.4338	.4527	.415	.4338
5	.4641	.4424	.4641	.4338	.4527	.4527	.4527
6	.5304	.5967	.6299	.4338	.4715	.415	.4527
7	.3584	.3395	.3018	.3772	.3772	.3395	.3584
8	.2829	.3018	.2641	.7459	.8288	.9448	1.094
9	.2641	.2075	.2641	.9282	1.0442	.9339	1.1603
10	.2829	.2263	.2641	1.0277	1.1105	1.1233	1.1768
11	.2452	.2263	.2452	.9448	1.0774	1.1271	1.2763
12	.2263	.2641	.2829	.9945	.9945	1.1105	1.2266
13	.2829	.2263	.2829	.8453	1.0442	1.1271	1.2431
14	.2263	.2075	.3018	.8122	1.0442	1.0774	1.2431
15	.2075	.2075	.2829	.7956	.9282	1.0277	1.1603
16	.1886	.2452	.2829	.2263	.2263	.2641	.2829
17	.1886	.2263	.2452	.2452	.2075		.2452
18	.2263	.5093	.3206	.2641	.2829	.3018	.2263
19	.5847	.5847	.5658	.547	.5847	.6413	.6036
20	.5658	.5658	.5658	.547	.5847	.6036	.6036
21	.547	.5304	.5658	.547	.6036	.5847	.9448
22	.4807	.4973	.4904	.5093	.5093	.5093	.9945
23	.4475	.4807	.4715	.4715	.4715	.4715	.9779
24	.4144	.4424	.4641	.4527	.4527	.4338	.4715
Max	.5847	.5967	.6299	1.0277	1.1105	1.1271	1.2763
Min	.1886	.2075	.2452	.2263	.2075	.2641	.2263
Avg	.3593	.3757	.3894	.5762	.6271	.6603	.7479

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064005 / KOSRA SUB STATION

Feeder No / Name : 206 / 11 KV PIMPALGAON FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3206	.3395	.6642	.6962	.7209	.8215
2	.3206	.3206	.3395	.6642	.6962	.7373	.8215
3	.3206	.3206	.3395	.6642	.6962	.7209	.8383
4	.3018	.3206	.3395	.6167	.7127	.7209	.8383
5	.3395	.3206	.3584	.6167	.7127	.7209	.8383
6	.3584	.3395	.3772	.68	.7293	.779	.9054
7	.3018	.583	.3206	.1698	.1509	.1886	.1509
8	.5636	.7449	.639	.3018	.2641	.3018	.3018
9	.6299	.8215	.7537	.3018	.2452	.2641	.2829
10	.6796	.7773	.7701	.2641	.2452	.2829	.2641
11	.7042	.7935	.8029	.2832	.1886	.2263	.2452
12	.7545	.7611	.7373	.2452	.2075	.2075	.2829
13	.7377	.7935	.7537	.2452	.2263	.2452	.2641
14	.811	.7125	.7865	.2641	.2263	.2452	.2829
15	.7042	.7125	.7537	.2641	.2075	.2641	.3018
16	.1886	.2075	.2263	.1886	.2075	.2452	.2829
17	.1886	.2263	.2641	.2452	.2075	.2075	.2452
18	.1132	.4715	.1132	.2263	.2263	.2263	.2452
19	.5281	.5847	.547	.5281	.547	.5658	.5658
20	.547	.5847	.5847	.5658	.5658	.6036	.5847
21	.4904	.5281	.68	.7127	.8048	.9556	.5658
22	.3961	.3961	.6642	.7459	.8048	.8383	.547
23	.3584	.3772	.6483	.7459	.7377	.8718	.4715
24	.3584	.3206	.3584	.6325	.7293	.7209	.8215
Max	.811	.8215	.8029	.7459	.8048	.9556	.9054
Min	.1132	.2075	.1132	.1698	.1509	.1886	.1509
Avg	.4598	.5141	.5207	.4515	.4598	.4942	.4904

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064006 / ADYAL SUB STATION

Feeder No / Name : 201 / 11 KV ADYAL FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.333	.3012	.3189	.3189	.3544	.3189	.3898
2	.3506	.2835	.3189	.3189	.3544	.3189	.3898
3	.3506	.2835	.3189	.3189	.3189	.3189	.3898
4	.3155	.2835	.3189	.3189	.3189	.3366	.3721
5	.3155	.3012	.3189	.3189	.3544	.3544	.3721
6	.3506	.3189	.3366	.3189	.3721	.3366	.3544
7	.3155	.3366	.3366	.3366	.3544	.3189	.3544
8	.298	.3012	.3189	.3544	.3366	.3544	.3544
9	.3155		.3189	.3544	.3366	.3544	.3189
10		.3012	.2658	.3189	.3366	.3189	.3012
11		.2835	.2658	.3189	.3366	.3012	.3189
12	.4207	.3189	.3012	.3366	.3189	.3721	.3012
13	.3155	.3189	.3012	.3366	.3012	.3366	.3366
14	.333	.3155	.3012	.3366	.3189	.3544	.3366
15	.2835	.2835	.3366	.3544	.3366	.3544	.3544
16	.3012	.298	.3189	.3544	.3366	.3544	.3366
17	.3012	.298	.3012	.3366	.3544	.3544	.3189
18	.3012	.2629	.3544	.3898	.3544	.3544	.3544
19	.4784	.443	.443	.5138	.4784	.4961	.5138
20	.443	.443	.4607	.4607	.4784	.4961	.4961
21	.4075	.443	.4252	.4784	.4784	.443	.4784
22	.3721	.4075	.4075	.4607	.443	.4252	.4607
23	.3189	.3544	.3898	.3898	.3898	.4075	.4252
24	.333	.3189	.3189	.3544	.3898	.3189	.3898
Max	.4784	.443	.4607	.5138	.4784	.4961	.5138
Min	.2835	.2629	.2658	.3189	.3012	.3012	.3012
Avg	.3434	.3261	.3374	.3625	.3647	.3625	.3758

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064006 / ADYAL SUB STATION

Feeder No / Name : 203 / 11 KV NERALA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1052	.1227	.0876	.1578	.1402	.1578	.1402
2	.1052	.1052	.0876	.1578	.1227	.1578	.1402
3	.0876	.1052	.0876	.1402	.1052	.1402	.1402
4	.1052	.1227	.0701	.1402	.1052	.1402	.1402
5	.1402	.1227	.0701	.1402	.1227	.1402	.1227
6	.1052	.1402	.1052	.1052	.1402	.1402	.1753
7	.1052	.1753	.1227	.0876	.1928	.1402	.1753
8	.1402	.1753	.1052	.1402	.1753	.1753	.1578
9	.1227		.1227	.1578	.1753	.1578	.1578
10	.1578	.1402	.1578	.1578	.1928	.1227	.1753
11	.1578	.1578	.1578	.1753	.1753	.1052	.1753
12	.1578	.1402	.1753	.1753	.1928	.1227	.1753
13	.1578	.1402	.1753	.1753	.1753	.1402	.1753
14	.1753	.1402	.1753	.1578	.1753	.1227	.1753
15	.1753	.1578	.1578	.1402	.1753	.1402	.1928
16	.1578	.1578	.1402	.1753	.1753	.1227	.1928
17	.1402	.1227	.1402	.1753	.1753	.1227	.1578
18	.1753	.1227	.1753	.1578	.1753	.1578	.1753
19	.2103	.1227	.2103	.2279	.1928	.1753	.2279
20	.1928	.1227	.2103	.2103	.2103	.2103	.2279
21	.1753	.1402	.2103	.2279	.1928	.1928	.2103
22	.1753	.1402	.2103	.1753	.1753	.1753	.2103
23	.1402	.1402	.1753	.1402	.1578	.1578	.1753
24	.1052	.1227	.0876	.1753	.1402	.1578	.1402
Max	.2103	.1753	.2103	.2279	.2103	.2103	.2279
Min	.0876	.1052	.0701	.0876	.1052	.1052	.1227
Avg	.1446	.1364	.1424	.1614	.1651	.1490	.1724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064006 / ADYAL SUB STATION

Feeder No / Name : 204 / 11 KV KABARA FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.144	.128	.128	.144	.128	.144	.144
2	.192	.128	.128	.144	.128	.2241	.144
3	.192	.16	.128	.144	.128	.2401	.144
4	.208	.192	.128	.144	.144	.2561	.144
5	.192	.208	.112	.128	.144	.3201	.176
6	.16	.2401	.144	.208	.176	.2881	.176
7	.208	.2721	.2241	.192	.16	.2401	.208
8	.192	.176	.144	.16	.16	.208	.16
9	.144		.112	.128	.16	.2721	.208
10	.2881	.2561	.16	.2561	.3041	.176	.3041
11	.2561	.2241	.2241	.2721	.2721	.2241	.2149
12	.2401	.16	.2241	.2721	.2881	.176	.128
13	.144	.128	.192	.144	.112	.144	.16
14	.128	.144	.144	.112	.128	.128	.112
15	.208	.16	.176	.144	.16	.128	.16
16	.192	.208	.192	.2241	.2401	.176	.192
17	.192	.16	.2241	.112	.192	.16	.2401
18	.208	.192	.192	.128	.16	.192	.16
19	.144	.176	.176	.144	.16	.144	.144
20	.144	.144	.16	.144	.16	.144	.144
21	.144	.144	.144	.144	.144	.144	.144
22	.128	.128	.144	.128	.144	.144	.128
23	.128	.128	.128	.128	.144	.144	.128
24	.144	.128	.128	.128	.128	.192	.144
Max	.2881	.2721	.2241	.2721	.3041	.3201	.3041
Min	.128	.128	.112	.112	.112	.128	.112
Avg	.1800	.1732	.1607	.1614	.1694	.1920	.1670

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064006 / ADYAL SUB STATION

Feeder No / Name : 205 / 11 KV GOSE(ADYAL) FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0373	.0373	.0373	.056	.056	.056
2	.0373	.0373	.0373	.0373	.0373	.056	.056
3	.0373	.0373	.0373	.056	.0373	.056	.056
4	.0373	.0373	.0373	.0373	.0373	.056	.056
5	.0373	.0373	.0373	.0373	.0373	.056	.0373
6	.056	.0373	.0373	.0373	.056	.0373	.056
7	.056	.0373	.0373	.0373	.056	.0373	.0373
8	.0373	.0373	.0373	.0373	.056	.0373	.0373
9	.0373		.0373	.056	.0747	.0373	.0373
10	.0373	.0373	.0373	.0373	.0373	.0373	.0373
11	.0373	.0373	.056	.056	.0373	.0373	.0373
12	.0373	.0373	.0373	.0373	.056	.0373	.0373
13	.0373	.0373	.0373	.0373	.0373	.056	.0373
14	.0373	.0373	.0373	.0373	.0373	.0373	.0373
15	.0373	.0373	.0373	.0373	.0373	.0373	.0373
16	.0373	.0373	.0373	.0373	.0373	.0373	.0373
17	.0373	.0373	.0373	.0373	.0373	.0373	.0373
18	.0373	.0373	.056	.0373	.0373	.0373	.0373
19	.0934	.0747	.0747	.0934	.0934	.0747	.0747
20	.0934	.0747	.0747	.0934	.0934	.0934	.0747
21	.0747	.0747	.0747	.0934	.0934	.0934	.0747
22	.056	.056	.0747	.0747	.0747	.0747	.056
23	.0373	.0373	.056	.056	.056	.056	.056
24	.0373	.0373	.0373	.0373	.056	.056	.056
Max	.0934	.0747	.0747	.0934	.0934	.0934	.0747
Min	.0373	.0373	.0373	.0373	.0373	.0373	.0373
Avg	.0459	.0430	.0459	.0490	.0529	.0513	.0482

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064006 / ADYAL SUB STATION

Feeder No / Name : 207 / 11 KV ASHOK NAGAR FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1715	.2229	.2401	
2				.1715	.2058	.2401	
3				.1715	.2058	.2401	
4				.1715	.2058	.2401	
5				.1715	.2058	.2401	
6				.1886	.2229	.2401	
8	.2401	.2401	.2401				.2743
9	.2401		.2401				.2915
10	.2743	.2572	.2401				.3258
11	.2743	.2572	.2572				.3086
12	.2572	.2743	.2572				.3086
13	.3086	.2915	.2572				.3258
14	.3086	.2915	.2743				.3086
15	.2915	.2572	.2572				.2915
17							.2915
21				.2058	.2401	.2229	
22				.2401	.2401	.2229	
23				.2401	.2401	.2229	
24				.1715	.2507	.2401	.2229
Max	.3086	.2915	.2743	.2401	.2507	.2401	.3258
Min	.2401	.2401	.2401	.1715	.2058	.2229	.2229
Avg	.2743	.267	.2529	.1904	.224	.2349	.2949

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064013 / 33 KV PAONI S/STN

Feeder No / Name : 201 / 11 KV PAUNI-I FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.4108	.4668	.5228	.4854	.4668	.5415
2	.4108	.3921	.4668	.4668	.4668	.4668	.5415
3	.4108	.3734	.4481	.4668	.4481	.4854	.5228
4	.3921	.3921	.4481	.5228	.4668	.4668	.5041
5	.3801	.4108	.4481	.4668	.4481	.4668	.5041
6	.3921	.4294	.4481	.4481	.4668	.4854	.4854
7	.4294	.4108	.4668	.4481	.4668	.4668	.4854
8	.4668	.5228	.4854	.5228	.4854	.5601	.5415
9	.4668	.5041	.4854	.4854	.5041	.5601	.4854
10	.5228	.4294	.5228	.5788	.6161	.5975	.4854
11	.5228	.4108	.4961	.5975	.6161	.5788	.4854
12	.5041	.4108	.4668	.5975	.5975	.5601	.4854
13	.4294	.4481	.4854	.6161	.5228	.5601	.5041
14	.5228	.4294	.4668	.6535	.5601	.6161	.5041
15	.4108	.4294	.5228	.5975	.5228	.5415	.5228
16	.5228	.5041	.5228	.5601	.6722	.5975	.5415
17	.4481	.4294	.4668	.5415	.6161	.6161	.5041
18	.4668	.5041	.4668	.5228	.5601	.5788	.4854
19	.5975	.6535	.6535	.6535	.7095	.6908	.6722
20	.5788	.6161	.6348	.6161	.6722	.6908	.6535
21	.5228	.5975	.6161	.6161	.6348	.6535	.6348
22	.4854	.5415	.5975	.5975	.5975	.6348	.6161
23	.4481	.5041		.5228	.5601	.5601	.5788
24	.4108	.4108	.4668	.4854	.4854	.4961	.5415
Max	.5975	.6535	.6535	.6535	.7095	.6908	.6722
Min	.3801	.3734	.4481	.4481	.4481	.4668	.4854
Avg	.4647	.4652	.5021	.5461	.5492	.5582	.5345

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064013 / 33 KV PAONI S/STN

Feeder No / Name : 202 / 11 KV SAWARLA FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3391	.3391	.5935	.6783	.9614	.9835	.6783
2	.3391	.3222	.5935	.6783	.9945	.9945	.6783
3	.3391	.3052	.5935	.6783	.9945	1.0174	.6783
4	.3052	.3052	.5935	.6783	1.0277	1.0174	.5087
5	.3052	.3222	.5935	.763	1.0608	.9835	.5087
6	.2035	.3391	.5935	.8478	1.094	1.0174	.5935
7	.2543	.4239	.5087	.6783	.2984	.3391	.6783
8	.7407	.9326	.9326	.2374	.2321	.2543	1.1869
9	.763	.9835	.2486	.2374	.2321	.2543	1.2717
10	.9326	1.0174	1.0852	.2035	.2374	.2374	1.2209
11	.9156	.9496	1.0852	.2374	.2374	.2374	1.153
12	.8139	.8478	1.0513	.2321	.2374	.2374	1.153
13	.9326	.9496	.8478	.2321	.2374	.2374	1.2209
14	.9156	.9835	.9326	.2321	.2374	.2374	1.2717
15	.2035	.2035	.2543	.2321	.2374	.2374	.2543
16	.2035	.2035	.2543	.1989	.2374	.2374	.2543
17	.2035	.2035	.2543	.2321	.2374	.2374	.2543
18	.2543	.3391	.2543	.2984	.3391	.2543	.2543
19	.8139	.6783	.8478	.8288	.8478	.8139	.9835
20	.8817	.8817	.8817	.8951	.8817	.7122	.9326
21	.6783	.8478	.8573	.9282	1.0174	.8817	.8817
22	.5087	.763	.7716	1.0608	1.1517	1.0174	.763
23	.4409	.6783	.6783	.9945	1.0174	.8478	.6783
24	.4239	.3467	.5935	.6443	.9282	.9835	.6783
Max	.9326	1.0174	1.0852	1.0608	1.1517	1.0174	1.2717
Min	.2035	.2035	.2486	.1989	.2321	.2374	.2543
Avg	.5297	.5903	.6625	.5386	.6241	.5946	.7807

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064013 / 33 KV PAONI S/STN

Feeder No / Name : 203 / 11 KV AMGAON FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7373	.7459	.8288	1.1271	1.1934	1.1603	.8356
2	.6882	.7293	.8288	1.1271	1.1768	1.1603	.8192
3	.7602	.7127	.8288	1.1603	1.1768	1.1768	.8192
4	.6882	.7293	.8288	1.1603	1.21	1.1603	.7865
5	.8145	.7293	.8453	1.1603	1.2266	1.1603	.7701
6	.7373		.8551	1.1603	1.1728	1.1768	.7537
7	.8848		1.094	.663	.663	.6299	.9175
8	1.3599		1.2763	.5967	.6299	.5967	1.1633
9	1.3763		1.4091	.6299	.5967	.6464	1.2944
10	1.4586		1.3757	.5304	.5365	.6203	1.3748
11	1.5415		1.3757	.547	.5197	.503	1.4922
12	1.5581	1.6244	1.4089	.4973	.6036	.4862	1.5089
13	1.6244	1.6244	1.6804	.547	.5197	.5365	1.4251
14	1.5581	1.6244	1.4918	.547	.57	.5365	1.4754
15	.3978	1.5912	.5801	.5801	.5365	.5365	.5197
16	.4144	1.4255	.5304	.5636	.503	.4862	.5868
17	.3978	1.3757	.5304	.5304	.5197	.4527	.6203
18	.6299	1.2452	.663	.663	.6706	.5868	.6371
19	1.1271	1.0814	1.1934	1.2266	1.2407	1.1305	1.1233
20	1.21	1.2125	1.2597	1.2763	1.2742	1.1961	1.1736
21	.9116	1.1961	1.2431	1.2763	1.2071	1.1797	1.2574
22	.9282	1.1469	1.1934	1.2431	1.1904	1.1469	1.073
23	.8288	.9012	.9614	1.1934	1.1603	.9831	.9054
24	.7373	.7459	.7865	1.1271	1.1934	1.1105	.8684
Max	1.6244	1.6244	1.6804	1.2763	1.2742	1.1961	1.5089
Min	.3978	.7127	.5304	.4973	.503	.4527	.5197
Avg	.9738	1.1356	1.0445	.8806	.8871	.8483	1.0084

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064013 / 33 KV PAONI S/STN

Feeder No / Name : 204 / 11 KV KHAPRI(REHAPADE)

SINGLE PHASING

FEEDER Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1543	.1524	.1524	.2315	.1829	.1543
2	.1543	.1543	.1524	.1524	.2315	.1829	.1543
3	.1543	.1543	.1524	.1524	.2315	.1829	.1543
4	.1543	.1543	.1524	.1524	.2315	.1829	.1543
5	.1543	.1543	.1524	.1524	.2315	.1829	.1543
6	.1543	.1543	.1524	.1524	.2315	.1898	.1543
7	.1543	.1543	.1524	.1524	.1543	.1829	.1543
8	.2372	.3086		.1524	.1543	.1524	.2286
9	.2743	.3858	.4572	.1524	.1543	.1543	.381
10	.3086	.3858	.381	.1543	.1543	.1543	.3086
11	.3086	.3086	.381	.1543	.1543	.1543	.2778
12	.3086	.463	.381	.1543	.1543	.1543	.3086
13	.3086	.3858	.3048	.1543	.1543	.1543	.3086
14	.3086	.463	.381	.1543	.1543	.1543	.3086
15	.1543	.1543	.1524	.1543	.1543	.1543	.1543
16	.1543	.1543	.1524	.1543	.1543	.1543	.1543
17	.1543	.1543	.1524	.1543	.1543	.1543	.1543
18	.1543	.1524	.1524	.1543	.1524	.1524	.1543
19	.1543	.1524	.1524	.1852	.1543	.1524	.1543
20	.1543	.1524	.1524	.1658	.1543	.1543	.1543
21	.1543	.1524	.1524	.1852	.2315	.1524	.1543
22	.1543	.1524	.1524	.2315	.1829	.1524	.1543
23	.1543	.1524	.1524	.2315	.1852	.2743	.1543
24	.1543	.1543	.1524	.1524	.2315	.1829	.1524
Max	.3086	.463	.4572	.2315	.2315	.2743	.381
Min	.1543	.1524	.1524	.1524	.1524	.1524	.1524
Avg	.1949	.2213	.2120	.1630	.1824	.1687	.1976

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064013 / 33 KV PAONI S/STN

Feeder No / Name : 205 / 11 KV PAUNI - II FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4294	.4668	.5975	.5415	.5041	.5601	.5601
2	.4294	.4481	.5975	.5228	.4854	.5601	.5601
3	.4481	.4294	.5975	.5228	.4668	.5601	.5601
4	.4481	.4481	.5788	.5228	.5041	.5601	.5601
5	.4294	.4668	.5788	.5228	.5228	.5601	.5601
6	.4481	.4854	.5601	.5041	.5415	.5415	.5228
7	.4294	.4294	.4854	.4481	.4854	.4854	.4668
8	.4481	.4481	.4294	.4668	.4854	.5228	.5041
9	.4294	.4108	.3734	.4668	.4854	.5041	.4668
10	.3734	.4854	.4668	.4481	.4668	.4294	.4668
11	.5041	.5041	.4668	.4854	.4481	.4668	.4668
12	.4854	.4668	.4481	.4668	.5041	.5228	.4668
13	.5228	.4668	.5228	.4668	.5228	.5228	.5228
14	.4481	.5041	.4481	.4668	.4481	.5228	.5041
15	.5228	.4854	.4854	.4481	.5228	.5041	.4481
16	.5228	.5041	.4668	.4481	.5601	.5228	.5228
17	.5041	.5041	.4668	.5041	.5228	.5601	.5415
18	.5041	.5228	.4481	.5601	.5601	.4854	.5415
19	.6535	.6348	.6161	.7095	.7655	.6348	.6348
20	.5601	.6161	.6722	.6722	.7095	.6535	.6161
21	.5788	.5601	.6535	.6348	.6722	.6348	.6161
22	.6161	.6535	.6348	.6161	.6535	.5975	.6535
23	.5228	.6161	.5601	.5601	.5788	.5975	.5975
24	.4294	.4854	.5788	.5601	.5228	.5601	.5601
Max	.6535	.6535	.6722	.7095	.7655	.6535	.6535
Min	.3734	.4108	.3734	.4481	.4481	.4294	.4481
Avg	.4870	.5018	.5306	.5236	.5391	.5446	.5383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064013 / 33 KV PAONI S/STN

Feeder No / Name : 206 / 11 KV SVK MILK PLANT

FEEDER Feeder KV- 11 /
OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.1132	.1132	.1132	.1307	.0943	.0943
2	.0943	.0943	.1132	.0943	.112	.0943	.0943
3	.0943	.0754	.1132	.0754	.0934	.0754	.0934
4	.0943	.0754	.0943	.0943	.0934	.0943	.0934
5	.0747	.0943	.0943	.0754	.0934	.0943	.0934
6	.0754	.1132	.0754	.0943	.112	.0747	.0754
7	.132	.132	.132	.0747	.1307	.1698	.0747
8	.1132	.1132	.1509	.1698	.1494	.1698	.0566
9	.1132	.0943	.1698	.1494	.112	.132	.0754
10	.1132	.0943	.132	.112	.112	.112	.0754
11	.0943	.0943	.1307	.1307	.112	.112	.0943
12	.132	.1132	.0934	.112	.0934	.112	.0754
13	.0943	.0943	.0934	.112	.112	.112	.0943
14	.0943	.0943	.0943	.168	.112	.112	.0943
15	.1509	.1509	.0934	.1494	.168	.168	.0943
16	.1509	.1509	.0943	.1494	.1867	.168	.1132
17	.1509	.1509	.0943	.1494	.1867	.168	.1509
18	.132	.132	.0943	.1494	.1698	.132	.1509
19	.132	.132	.0943	.1307	.1509	.1132	.1886
20	.132	.1132	.0754	.1307	.132	.1132	.132
21	.132	.1132	.0754	.1307		.132	.132
22	.132	.1307	.132	.1307	.1307	.1132	.132
23	.132	.132	.1509	.1494	.1132	.112	.132
24	.1132	.1132	.1132	.1132	.1307	.1132	.112
Max	.1509	.1509	.1698	.1698	.1867	.1698	.1886
Min	.0747	.0754	.0754	.0747	.0934	.0747	.0566
Avg	.1155	.1131	.1091	.1233	.1277	.1205	.1051

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064013 / 33 KV PAONI S/STN

Feeder No / Name : 207 / 11 KV SHINDHPURI AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3584	.3921	.3961	
2				.3584	.3921	.3772	
3				.3772	.3921	.415	
4				.3772	.4294	.4715	
5				.3584	.4668	.4527	
6				.3961	.5041	.4668	
7		.3772	.3921				
8		.3961	.5601				.6161
9	.3584	.5281	.6348				.7655
10	.5788	.6979	.7095				.8488
11	.6348	.6979	.7167				.8865
12	.6161	.7356	.7095				.8865
13	.5975	.6979	.7095				.8865
14	.5601	.6602	.6224				.8676
21				.3734	.3921		
22				.3921	.4108	.3961	
23				.3921	.3961	.3772	
24				.3961	.3921	.3772	
Max	.6348	.7356	.7167	.3961	.5041	.4715	.8865
Min	.3584	.3772	.3921	.3584	.3921	.3772	.6161
Avg	.5576	.5989	.6318	.3779	.4168	.4144	.8225

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064016 / 33 KV PAHELA S/STN

Feeder No / Name : 201 / 11 KV PAHELA-GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2195	.1715	.1886	.2058	.2058	.2378
2	.1886	.2195	.1543	.2058	.2058	.2058	.2195
3	.1715	.2012	.1543	.2058	.1886	.2058	.2195
4	.1886	.1829	.1543	.1886	.1886	.2229	.1829
5	.2058	.1829	.1715	.2058	.2058	.2229	.1646
6	.2058	.1829	.2058	.1886	.2229	.2401	.1829
7	.1886	.2012	.2058	.1543	.2058	.1886	.2195
8	.1886	.2012	.1886	.1886	.2058	.2058	.2012
9	.1886	.2058	.2058	.2058	.2058	.1715	.1886
10	.2012	.1715	.1886	.2743	.2058	.2195	.1886
11	.2012	.2058	.1543	.2058	.1543	.1829	.1886
12	.2012	.2058	.1886	.2058	.1715	.1829	.1886
13	.2012	.2058	.1886	.2401	.2058	.2195	.2401
14	.2012	.2229	.1886	.2401	.1886	.2012	.2058
15	.2561	.2401	.1715	.2401	.2058	.2012	.2572
16	.2743	.2229	.1886	.2229	.2058	.2012	.2743
17	.2012	.1886	.1886	.2229	.2229	.2012	.2058
18	.2012	.2572	.1886	.2229	.2229	.2195	.2058
19	.3292	.2915	.2058	.3086	.3086	.3292	.3086
20	.2926	.2743	.2743	.3086	.2743	.3109	.2915
21	.2561	.2743	.2743	.2915	.2915	.2926	.2915
22	.2195	.2401	.2058	.2572	.2229	.2926	.2915
23	.2012	.2058	.2401	.2401	.2401	.2378	.2401
24	.1886	.2195	.1715	.1886	.2229	.2229	.2378
Max	.3292	.2915	.2743	.3086	.3086	.3292	.3086
Min	.1715	.1715	.1543	.1543	.1543	.1715	.1646
Avg	.2142	.2176	.1929	.2251	.2158	.2243	.2263

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064016 / 33 KV PAHELA S/STN

Feeder No / Name : 202 / 11 KV WAKESHWAR GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1463	.1372		.1715	.1715	.1829
2	.1543	.1463	.1372	.1886	.1543	.1715	.1829
3	.1543	.128	.1372	.1886	.1543	.1715	.1646
4	.1543	.128	.1543	.1886	.1543	.1886	.1646
5	.1715	.128	.1715	.1886	.1715	.1886	.1463
6	.1886	.2012	.2058	.1886	.2058	.2058	.1829
7	.1886	.2012	.2058	.1715	.2058	.2058	.1829
8	.1886	.2012	.1886	.1886	.2058	.2058	.2012
9	.1886	.2058	.1886	.1886	.2058	.1715	.2012
10	.2012	.1543	.1886	.2058	.2229	.1829	.1886
11	.2012	.1372	.1372	.2229	.2743	.2195	.1886
12	.2012	.1715	.1886	.2401	.1372	.2378	.1886
13	.2012	.1715	.1886	.1886	.1886	.2195	.2401
14	.2012	.1543	.1372	.2058	.2058	.2743	.1886
15	.2012	.1543	.1543	.1715	.2743	.2012	.2229
16	.1463	.1543	.1886	.2058	.2058	.2195	.1543
17	.1646	.1543	.1886	.1886	.2058	.1646	.2058
18	.2012	.2572	.1886	.2058	.1886	.2012	.2058
19	.2926	.2915	.1886	.3086	.3258	.3292	.3086
20	.2743	.2915	.1715	.3086	.3086	.3109	.2743
21	.2378	.2401	.2743	.2743	.2572	.2378	.2743
22	.2012	.1715		.2058	.2058	.2195	.2743
23	.2012	.1543	.2401	.1715	.1886	.1829	.2401
24	.1372	.1463	.1372	.1886	.1715	.1886	.1829
Max	.2926	.2915	.2743	.3086	.3258	.3292	.3086
Min	.1372	.128	.1372	.1715	.1372	.1646	.1463
Avg	.1912	.1788	.1782	.208	.2079	.2113	.2061

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064016 / 33 KV PAHELA S/STN

Feeder No / Name : 203 / 11 KV NIMGAON FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0838		.0686	.12	.0857	.1006
2	.0686	.0671	.0857	.0857	.1029	.0857	.1006
3	.0686	.0671	.0857	.0857	.1029	.0857	.0838
4	.0686	.0671	.0857	.0857	.1029	.0857	
5	.0686	.0671	.1029	.0857	.1029	.0857	.0671
6	.0686	.0838	.1029	.0857	.1029	.0857	.0671
7	.0686	.1006	.1029	.0857	.1029	.0686	.0838
8	.0686	.1006	.1029	.1029	.1029	.1029	.1006
9	.1029	.12	.1029	.1372	.0857	.0857	.1006
10	.0838	.1029	.1029	.1372	.1029	.0838	.12
11	.1006	.1029	.12	.12	.1029	.0838	.12
12	.1174	.12	.1029	.12	.0857	.1006	.0857
13	.1174	.12	.1372		.1029	.1006	.1372
14	.0838	.12	.1372	.1372	.1029	.1006	.1372
15	.0838	.12	.1543	.1372	.1029	.1174	.1372
16	.1341	.1372		.1372	.1029	.1006	.1372
17	.1341	.1029	.1372	.1372	.1029	.1174	.1372
18	.1341	.12	.1372	.1372	.1029	.1006	.1372
19	.1006	.1372	.0857	.1372	.1029	.1006	.12
20	.1006	.1372	.1543	.1372	.1029	.1006	.12
21	.1006	.1372	.12	.1372	.1029	.1006	.12
22	.1006	.12	.0857	.1029	.1029	.1006	.12
23	.0838	.1029	.0857	.1029	.0857	.1006	.12
24	.0686	.0838	.0857	.0857	.12	.0857	.1006
Max	.1341	.1372	.1543	.1372	.12	.1174	.1372
Min	.0686	.0671	.0857	.0686	.0857	.0686	.0671
Avg	.0915	.1051	.1099	.1126	.1022	.0944	.1110

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064016 / 33 KV PAHELA S/STN

Feeder No / Name : 204 / 11 KV WAKESHWAR-AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1715	.1886	.1886	
2				.1715	.1886	.1886	
3				.1886	.2058	.1886	
4				.1886	.2058	.2058	
5				.1886	.2058	.2058	
6				.2058	.2058	.2058	
8	.3086	.1638	.2915				.2622
9	.3429	.1715	.2915				.2622
10	.3277	.0514	.2915				.3086
11	.2785	.1715	.2743				.2915
12	.2785	.2572	.3258				.3086
13	.2949	.3258	.3601				.2915
14	.2785	.3086	.3429				.3258
15	.2785	.2915	.2401				.2743
21				.1886	.2058	.1802	
22				.2058	.2229	.1802	
23				.1886	.1886	.1802	
24					.1886	.1886	.1802
Max	.3429	.3258	.3601	.2058	.2229	.2058	.3258
Min	.2785	.0514	.2401	.1715	.1886	.1802	.1802
Avg	.2985	.2177	.3022	.1886	.2006	.1912	.2783

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064016 / 33 KV PAHELA S/STN

Feeder No / Name : 205 / 11 KV PAHELA-AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0514	.0343	.0343	
2				.0514	.0343	.0343	
3				.0514	.0343	.0343	
4				.0514	.0171	.0343	
5				.0514	.0171	.0343	
6				.0514	.0171	.0343	
8	.0514	.048	.0343				.048
9	.0514	.0514	.0514				.064
10	.048	.0514	.0514				.0857
11	.048	.0514	.0514				.0857
12	.048	.0514	.0343				.0857
13	.048	.0514	.0686				.0857
14	.064	.0514	.0514				.0686
15	.064	.0514	.0514				.0686
21				.0343	.0343	.064	
22				.0343	.0343	.032	
23				.0343	.0343	.08	
24					.0343	.0343	.08
Max	.064	.0514	.0686	.0514	.0343	.08	.0857
Min	.048	.048	.0343	.0343	.0171	.032	.048
Avg	.0529	.0510	.0493	.0457	.0291	.0416	.0747

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064016 / 33 KV PAHELA S/STN

Feeder No / Name : 401 / 33 KV ADYAL FEEDER INCOMER NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / INCOMING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.439	.4115	.6687	.7202	.7202	.5487
2	.3601	.439	.4115	.6173	.7202	.7202	.5487
3	.3601	.3841	.4115	.6173	.7716	.7202	.5487
4	.4115	.3841	.5144	.6173	.7716	.8745	.4938
5	.5144	.4938	.6173	.6687	.823	1.0288	.4938
6	.7716	.7682	.7716	.7716	.8745	1.1317	.823
7	.823	.8779	.9259	.6173	.7202	.7716	.7682
8	.9774	.9877	.8745	.6173	.6173	.5144	.9328
9	.7202	.823	.7716	.5144	.5658	.6687	.9877
10	.7682	.8745	.7716	.6687	.7716	.4938	1.1831
11	.6584	.8745	.823	.7716	.823	.7133	.9774
12	1.0974	.8745	.9259	.7716	.823	.6584	.7202
13	.8779	.7716	.8745	.6173	.6173	.5487	.823
14	.8779	.6687	.7716	.5144	.5658	.6036	.8745
15	.8779	.7202	.8745	.7202	.7202	.6036	.6687
16	.6584	.7202	.6687	.7202	.7716	.823	.823
17	.6036	.6687	.5658	.5144	.6173	.6584	.823
18	.7682	.7202	.7716	.5144	.6173	.823	.5144
19	.8779	.7202	.9259	.7202	.823	.9328	.823
20	.7682	.6173	.7202	.823	.7202	.7682	.7202
21	.6584	.6173	.6687	.8745	.8745	.9328	.7202
22	.5487	.5144	.6173	.823	.8745	.9328	.6173
23	.5487	.463	.5658	.7202	.7716	.823	.6173
24	.4115	.439	.4115	.6687	.7202	.7716	.5487
Max	1.0974	.9877	.9259	.8745	.8745	1.1317	1.1831
Min	.3601	.3841	.4115	.5144	.5658	.4938	.4938
Avg	.6813	.6609	.6944	.6730	.7373	.7599	.7333

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064028 / 33/11 kv ASGAON S/ST

Feeder No / Name : 201 / 11 KV MANGLI FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.7225	.823	1.0155	
2				.7225	.823	1.0031	
3				.7225	.823	.9907	
4				.7316	.8078	.9877	
5				.7468	.823	1.0311	
6				.8078	1.1431	1.2334	
8	.6539	.8482	.9122				1.5402
9	.6321	.9061	1.0526				1.7532
10	.7316	.933	1.1174				1.7901
11	.7977	.9602	1.166				1.7368
12	.7926	.9804	1.1498				1.6712
13	.8078	.9488	1.2146				1.7204
14	.7876		1.2793				1.6356
15	.787	.6019	1.1984				1.6712
21					1.0311	1.0978	
22				.8078	1.0437	1.1069	
23				.8535	1.0311	1.0911	
24					.8078	1.0155	1.0911
Max	.8078	.9804	1.2793	.8535	1.1431	1.2334	1.7901
Min	.6321	.6019	.9122	.7225	.8078	.9877	1.0911
Avg	.7488	.8827	1.1363	.7644	.9157	1.0573	1.6233

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064028 / 33/11 kv ASGAON S/ST

Feeder No / Name : 202 / 11 KV DHAMNI- AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2031	.2591	.2782	
2				.2107	.2591	.2921	
3				.2107	.2591	.2743	
4				.2107	.2591	.2743	
5				.2107	.2743	.2782	
6				.2439	.306	.3616	
8	.208	.1189	.3201				.442
9	.2896	.1932	.381				.4999
10	.2812		.442				.5155
11	.2968	.2824	.381				.4652
12	.3125	.3311	.3353				.5144
13	.3125	.3201	.3048				.5502
14	.2343	.3353	.2591				.535
15	.2968	.3561	.3201				.535
21				.2591	.2675	.3201	
22				.2591	.301	.3201	
23				.2591	.2921	.3161	
24					.2591	.2743	.3161
Max	.3125	.3561	.442	.2591	.306	.3616	.5502
Min	.208	.1189	.2591	.2031	.2591	.2743	.3161
Avg	.2790	.2767	.3429	.2297	.2736	.2989	.4859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064028 / 33/11 kv ASGAON S/ST

Feeder No / Name : 203 / 11 KV DHOLSAR FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0667	.08	.1097	
2				.0667	.08	.1097	
3				.0667	.08	.1067	
4				.0667	.08	.1082	
5				.0667	.08	.1097	
6				.0667	.08	.0974	
8	.08	.092					.1524
9	.1269	.12	.1286				.1677
10	.141	.1551	.1143				.1829
11	.1572	.1715	.1286				.2134
12	.1143	.1429	.1286				.1852
13	.1572	.1429	.0714				.2105
14	.1429	.1286	.1143				.1852
15	.1429	.1269	.1143				.1829
21				.08	.1067	.1656	
22				.08	.1082	.1505	
23				.08	.1067	.1505	
24					.08	.1082	.1429
Max	.1572	.1715	.1286	.08	.1082	.1656	.2134
Min	.08	.092	.0714	.0667	.08	.0974	.1429
Avg	.1328	.1350	.1143	.0711	.0882	.1216	.1803

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064028 / 33/11 kv ASGAON S/ST

Feeder No / Name : 204 / 11 KV ASGAON GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.2561	.2801	.3109	.3155	.3109	.3658
2	.2378	.2534	.2801	.2926	.3155	.3109	.2957
3	.2378	.2534	.2801	.2926	.3155	.3109	.2926
4	.2561	.2561	.2801	.2926	.3155	.3109	.2926
5	.2561	.2743	.2987	.3109	.333	.3258	.2957
6	.3109	.3258	.3584	.3292	.3681	.3439	.3511
7	.3292	.3258	.2957	.3258	.3506	.3258	.3439
8	.2926	.2896	.2587	.2896	.3506	.3077	.2926
9	.2561	.2715	.2402	.2896	.2804	.2534	.2743
10	.2378	.2195	.2587	.3045	.2865	.2534	.2926
11	.2149	1.086	.2218	.3258	.2715	.3109	.2561
12	.2149	.2172	.2957	.3224	.3258	.3109	.2561
13	.181	.1991	.3326	.3721	.362	.2926	.2195
14	.2353	.2103	.3326	.3721	.298	.2561	.2378
15	.2534	.2058	.3326	.3506	.3012	.2715	.2926
16	.2204	.1734	.3696	.3681	.3294	.2686	.2561
17	.2035	.197	.3467	.3506	.2629	.298	.2195
18	.2229	.2328	.3277	.3506	.2454	.2686	.2543
19	.3506	.4294	.3841	.3856	.4031	.4251	.4024
20	.3506	.4108	.3841	.3856	.4031	.3881	.4066
21	.3155	.3361	.3658	.3856	.3681	.3696	.3881
22	.298	.3361	.2926	.3506	.3506	.3696	.3696
23	.2454	.2987	.3109	.333	.3475	.3658	.3326
24	.2561	.2587	.2801	.3109	.333	.3292	.3174
Max	.3506	1.086	.3841	.3856	.4031	.4251	.4066
Min	.181	.1734	.2218	.2896	.2454	.2534	.2195
Avg	.2597	.3049	.3087	.3334	.3264	.3158	.3044

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064028 / 33/11 kv ASGAON S/ST

Feeder No / Name : 205 / 11 KV KHAIRY-AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1067	.1334	.1669	
2				.1067	.1334	.1715	
3				.1067	.1334	.1692	
4				.1067	.1334	.1692	
5				.12	.1467	.2	
6				.1734	.3067	.3144	
8	.1572	.1235	.1635				.3567
9	.1932	.1894	.2675				.442
10	.2187	.1669	.1932				.4475
11	.2343	.2143	.2378				.4214
12	.2031	.2	.1635				.431
13	.1875	.2172	.104				.4254
14	.2031	.2105	.0892				.4199
15	.1875	.1572	.2229				.3814
21				.12	.1578	.1467	
22				.1334	.16	.1486	
23				.1334	.1715	.1551	
24					.1334	.1715	.141
Max	.2343	.2172	.2675	.1734	.3067	.3144	.4475
Min	.1572	.1235	.0892	.1067	.1334	.1467	.141
Avg	.1981	.1849	.1802	.123	.1610	.1813	.3851

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064028 / 33/11 kv ASGAON S/ST

Feeder No / Name : 207 / 11 KV ASGAON AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6335	.724	.7783				1.1765
2	.6335		.7783				1.1946
3	.6335	.7392	.724				1.1946
4	.6335	.724	.7602				1.1946
5	.6516	.8145	.724				1.1946
6	.8688	1.086	.9774				1.3394
8				1.1222	1.2127	1.8296	
9				1.3394	1.5023	1.7187	
10				1.4118	1.5402	1.6126	
11				1.3394	1.5927	1.7194	
12				1.3394	1.6278	1.7375	
13				1.3575	1.576	1.6651	
14				1.2308	1.5384	1.6651	
15				1.2308	1.5203	1.6651	
19					1.5203		
21	.7783	.8326	.724				1.5384
22	.7964	.8145	.7421				1.56
23	.7602	.7964	.7421				1.6108
24	.6335	.724	.7783	.7602			
Max	.8688	1.086	.9774	1.4118	1.6278	1.8296	1.6108
Min	.6335	.724	.724	.7602	1.2127	1.6126	1.1765
Avg	.7023	.8061	.7729	1.2368	1.5145	1.7016	1.3337

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064028 / 33/11 kv ASGAON S/ST

Feeder No / Name : 208 / 11 KV DHAMNI - G FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.2218	.2402	.2772	.2957	.3142	.2772
2	.2218	.2218	.2402	.2587	.2957	.2957	.2772
3	.2218	.2218	.2402	.2587	.2957	.2957	.2587
4	.2218	.2218	.2405	.2587	.2957	.2957	.2614
5	.2218	.2218	.2614	.2772	.3142	.2957	.2587
6	.2587	.3142	.2987	.2957	.3326	.3142	.3361
7	.2587	.2402	.2427	.2772	.2587	.2587	.2801
8	.2587	.2587	.2218	.2587	.2402	.2402	.2402
9	.2033	.1848	.1848	.2033	.2402	.1848	.1478
10	.1663		.1109	.1663	.1478	.1663	.1848
11	.1294	.1478	.1478	.1663	.1294	.1294	.2218
12	.1109	.112	.1753	.1294	.1294	.1294	.1478
13	.1109	.1494	.1578	.1848	.1494	.1478	.1663
14	.1109		.1753	.1753	.1478	.1478	.1663
15	.1109	.1478	.1402	.2033	.1294	.1294	.1663
16	.1294	.1478	.1227	.1478	.1294	.1294	.1663
17	.1663	.1848	.1663	.2033	.1848	.1294	.1848
18	.2033	.1646	.2218	.2402	.2402	.2012	.2218
19	.3326	.3547	.3511	.3696	.4066	.3734	.3696
20	.3142	.3361	.3696	.3511	.3881	.3361	.3326
21	.2772	.3361	.3326	.3326	.3511	.3326	.3326
22	.2587	.2957	.3142	.3326	.3326	.3174	.2957
23	.2402	.2587	.2957	.3142	.3142	.2957	.2957
24	.2218	.2402	.2402	.2957	.3142	.3142	.2957
Max	.3326	.3547	.3696	.3696	.4066	.3734	.3696
Min	.1109	.112	.1109	.1294	.1294	.1294	.1478
Avg	.2071	.2265	.2288	.2491	.2526	.2406	.2452

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064035 / 33/11 KV WALNI S/ST

Feeder No / Name : 201 / 11 KV PAUNA KH -AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1219	.1715	.1829	
2				.1219	.1715	.1829	
3				.1372	.2401	.1829	
4				.1524	.3258	.1829	
5				.2286	.3772	.1829	
6				.2286	.4287	.3506	
7			.0987				
8	.1981	.1981	.1833				.3353
9	.2439	.1981	.2679				.3506
10	.2439	.2439	.3201				.3963
11	.2743	.2743	.3658				.4268
12	.3048	.2743	.3201				.4572
13	.2591	.2743	.3201				.442
14	.2743	.1677	.3048				.442
15	.2134	.2439	.2896				.442
21				.1372	.1524	.1677	
22				.1524	.1829	.1677	
23				.1677	.1829	.1677	
24				.061	.1829		.1677
Max	.3048	.2743	.3658	.2286	.4287	.3506	.4572
Min	.1981	.1677	.0987	.061	.1524	.1677	.1677
Avg	.2515	.2343	.2745	.1509	.2416	.1965	.3844

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064035 / 33/11 KV WALNI S/ST

Feeder No / Name : 202 / 11 KV SHIVNALA-AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0305	.0857	.0762	
2				.0305	.0857	.0762	
3				.0305	.0857	.0762	
4				.0305	.0857	.0762	
5				.0457	.1372	.0762	
6				.061	.2401	.1067	
7			.061				
8	.0914	.0762	.061				.1524
9	.1067	.0762	.1067				.1524
10	.1067	.0914	.1372				.1524
11	.1067	.1219	.1524				.1981
12	.1067	.1372					.1981
13	.1067	.1372					.1829
14	.1219	.1067	.1372				.1981
15	.1067	.0762	.1219				.2134
21				.061	.061	.0457	
22				.0762	.0762	.0457	
23				.0857	.0762	.061	
24				.061	.0762		.061
Max	.1219	.1372	.1524	.0857	.2401	.1067	.2134
Min	.0914	.0762	.061	.0305	.061	.0457	.061
Avg	.1067	.1029	.1111	.0513	.1010	.0711	.1676

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064035 / 33/11 KV WALNI S/ST

Feeder No / Name : 203 / 11 KV BHENDALA-GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3696	.3142	.3326	.4338	.462	.3696
2	.3584	.3326	.3326	.3326	.415	.4435	.4251
3	.3395	.3326	.3326	.3142	.3961	.4251	.4066
4	.3772	.3326	.3696	.3142	.3772	.4251	.3881
5	.3772	.3881	.4435	.3696	.3961	.4251	.3881
6	.3961	.3881	.462	.462	.415	.462	.3696
7	.3961	.4251	.462	.4251	.415	.4066	.3881
8	.3881	.4435	.4251	.3696	.3881	.3696	.3511
9	.3696	.3696	.4066	.2772	.3696	.3511	.3142
10	.4435	.2957	.4251	.3881	.3961	.2772	.3142
11	.3696	.2772		.4805	.3696	.2957	.3511
12	.3142	.2772	.3696	.3881	.3326	.2957	.3326
13	.2772	.2957	.3696	.4251	.3326	.2587	.2772
14	.2772	.3142	.3142	.3881		.2772	.2772
15	.2587	.2587	.2957		.2957	.2587	.2587
16	.3142	.3326	.2772	.3206	.2957	.2218	.2772
17	.3326	.3326	.2218	.2829	.3142	.2402	.2772
18	.3511	.4066	.3142	.3206	.2957	.2772	.2957
19	.4435	.5544	.4805	.4904	.4805	.4805	.5729
20	.4805	.5544	.4805	.4715	.4805	.462	.462
21	.4435	.4066	.462	.5359	.462	.462	.4435
22	.4435	.4805	.499	.5359	.5359	.499	.4805
23	.4066	.4435	.3881	.4904	.4805	.4066	.462
24	.3696		.3881	.4066	.4805		.4066
Max	.4805	.5544	.499	.5359	.5359	.499	.5729
Min	.2587	.2587	.2218	.2772	.2957	.2218	.2587
Avg	.3710	.3744	.3841	.3966	.3982	.3688	.3704

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064039 / 132 KV GOSE KH SUBSTATION

Feeder No / Name : 401 / 33 KV PAUNI FEEDER

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / INCOMING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	1.5278	1.5844	1.7924	3.7311	4.3644	4.2593	4.1089
Max	1.5278	1.5844	1.7924	3.7311	4.3644	4.2593	4.1089
Min	1.5278	1.5844	1.7924	3.7311	4.3644	4.2593	4.1089
Avg	1.5278	1.5844	1.7924	3.7311	4.3644	4.2593	4.1089

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 067011 / 132/33 KV ASGAON SUBSTATION

Feeder No / Name : 402 / 33 KV GOSE FEEDER INCOMER

Feeder KV- 33 / INCOMING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3575	1.382	1.6832	3.4551		3.8803	1.7375
2	1.3575	1.3289	1.6832	3.4551	3.9866	3.8803	1.7375
3	1.3575	1.2757	1.6832	3.4551	3.9335	3.9866	1.7375
4	1.3032	1.2757	1.6289	3.5082	4.0929	3.9866	1.6289
5	1.3032	1.3289	1.6832	3.5614	4.1461	3.9335	1.6289
6	1.2489	1.4352	1.6289	3.7209	4.3056	3.9866	1.5746
7	1.9004	1.9136	3.3122	1.4352	1.4352	1.4352	2.9321
8	3.638	2.7109	4.2896	1.4352	1.4352	1.5415	4.4525
9	7.887	2.9235	3.9638	1.382	1.382	1.4883	4.9954
10	9.093	3.1361	4.6776	1.382	1.4883	1.4352	4.8371
11	9.453	2.9767	4.784	1.4883	1.4352	1.4352	4.9434
12	9.397	4.784	4.6776	1.4352	1.4883	1.4352	4.9434
13	9.5536	4.784	4.5713	1.4883	1.4352	1.4883	5.0497
14	9.2461	4.8903	4.5182	1.5415	1.382	1.5415	5.1029
15	5.7019	2.8172	1.382	1.4883	1.4883	1.4883	1.3289
16	2.9013	2.7641	1.3289	1.4352	1.6478	1.5415	1.4883
17	1.3289	2.6046	1.2757	1.4883	1.5947	1.5947	1.4883
18	1.4352	2.6606	1.3289	1.5947	1.5947	1.5203	1.4883
19	2.073	2.0633	2.073	2.2325	2.2857	2.1719	2.2325
20	2.0199	2.0633	2.1262	2.1794	2.2325	2.1719	2.1262
21	1.8073	2.009	2.073	4.2524	3.9866	4.181	2.1262
22	1.7541	2.009	2.0199	4.3587	3.9335	4.2353	2.0199
23	1.5415	1.8461	1.7541	4.1461	4.0398	3.7466	1.8604
24	1.4661	1.382	1.6832	3.5082	3.9866	3.8803	1.7918
Max	9.5536	4.8903	4.784	4.3587	4.3056	4.2353	5.1029
Min	1.2489	1.2757	1.2757	1.382	1.382	1.4352	1.3289
Avg	3.7552	2.4319	2.5762	2.4761	2.5538	2.5828	2.7188

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 067011 / 132/33 KV ASGAON SUBSTATION

Feeder No / Name : 404 / 33 KV KOSARA FEEDER

NON SHEDDABLE EXPRESS HV FEEDERS

INCOMER Feeder KV- 33 /

(CONTINUOUS PROCESS)(NO STAGGERING)

INCOMING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6644	1.8204	2.0062	2.8166	2.9675	3.2693	3.4705
2	1.893	1.7684	1.9765	2.7664	2.9172	3.2693	3.4202
3	1.893	1.9982	1.9765	2.8166	2.8344	3.1184	3.3813
4	1.893	1.9982	1.9547	2.7664	2.8344	3.1184	3.3813
5	2.0508	2.0508	2.1845	2.7664	3.0178	3.219	3.4705
6	2.073	2.3137	2.4446	3.0681	3.3065	3.6717	3.7723
7	1.1883	.9877	1.4118	1.1317	1.086	1.1883	1.2449
8	2.572	2.6452	2.7664	2.8669	2.6595	2.7469	3.0521
9	2.7161	2.9984	2.9675	2.8669	2.999	2.9504	3.271
10	2.6852	2.9338	2.8841	2.9504	3.0247	3.0807	3.3048
11	2.1628	2.6355	2.8509	2.9647	2.9687	2.9687	3.2156
12	2.6543	2.7035	2.9001	2.8006	2.8567	2.8567	3.1602
13	2.5263	2.7206	2.7526	2.7161	2.9687	2.8006	3.1602
14	2.5749	2.6543	2.8509	2.8006	2.9127	2.7664	3.2156
15	2.5263	2.4777	2.8018	2.7446	2.7161	2.7161	2.9338
16	.6722	.6859	.7922	.8488	.8488	.7922	.9054
17	.6722	.6224	.7356	.7922	.7922	.7356	.8488
18	.8488	.6859	.823	.7922	.9619	.7922	.8488
19	1.6409	1.6004	1.8107	1.5432	1.8107	1.6004	1.7541
20	1.6975	1.8107	1.8107	1.8673	1.9239	1.6575	1.9239
21	2.2565	2.5252	3.2407	3.2247	3.6523	3.6928	3.3128
22	2.073	2.3663	3.1539	3.3065	3.6626	3.8152	3.2407
23	2.1262	2.1325	2.8995	3.0681	3.4591	3.6214	3.1379
24	1.9982	1.893	2.0285	2.8669	2.9675	3.3573	3.3699
Max	2.7161	2.9984	3.2407	3.3065	3.6626	3.8152	3.7723
Min	.6722	.6224	.7356	.7922	.7922	.7356	.8488
Avg	1.9608	2.0429	2.2510	2.4647	2.5895	2.6586	2.7832

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 067011 / 132/33 KV ASGAON SUBSTATION

Feeder No / Name : 405 / 33 KV WALNI FEEDER INCOMER NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / INCOMING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3395	.3921	.499	.5973	.5761	.3961
2	.3395	.3395	.3921	.499	.6516	.6447	.4001
3	.3395	.3395	.3921	.5487	.6516	.6447	.4001
4	.3395	.3395	.3921	.543	.6447	.6516	.4001
5	.3961	.3961	.4481	.5973	.6984	.7059	.3961
6	.3961	.3961	.4481	.6984	.9465	.8505	.4527
7	.3361	.3921	.3361	.3921	.3961	.3921	.3881
8	.6836	.6836	.6687	.3921	.3361	.3361	.823
9	.6613	.6036	.7122		.2801	.3361	.8139
10	.7716	.6104	.9054	.3326	.3395	.1698	.7716
11	.4578	.7042	.4733	.4435	.3395	.2829	.9156
12	.7373	.5944	.5316	.3361	.2829	.2801	.9665
13	.639	.7716	.7202	.3921	.2829	.2858	.9054
14	.6316	.763	.8139	.3361	.2263	.2286	.8453
15	.5407	.5721	.6613	.3326	.2801	.2286	.8551
16	.2658	.3258	.2772	.2743	.2241	.2241	.2172
17	.3018	.3189	.2218	.2195	.2241	.2195	.2172
18	.3292	.3761	.2743	.3395	.2743	.2743	.2686
19	.5041	.5601	.4527	.4001	.4527	.5093	.4527
20	.4481	.4527	.4527	.4527	.4527	.5093	.4527
21	.3961	.3961	.5093	.7133	.6653	.7207	.4527
22	.4481	.4481	.4527	.6984	.7522	.7059	.4527
23	.4481	.4435	.4527	.6447	.6984	.6984	.4527
24	.3961	.3395	.3921	.3429	.5973	.6984	.7059
Max	.7716	.7716	.9054	.7133	.9465	.8505	.9665
Min	.2658	.3189	.2218	.2195	.2241	.1698	.2172
Avg	.4644	.4794	.4905	.4534	.4706	.4656	.5584

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 067011 / 132/33 KV ASGAON SUBSTATION

Feeder No / Name : 410 / 33 ASGAON INCOMER 1

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / INCOMING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6606	2.9012	3.1161	3.2808	3.7449	4.2696	4.3724
2	2.6337	2.9012	3.1161	3.2339	3.7449	4.2696	4.2181
3	2.6063	2.9321	2.9864	3.2339	3.7449	4.321	4.2181
4	2.6606	2.9321	3.0624	3.2339	3.6528	4.3239	4.2181
5	2.7149	3.2236	3.0407	3.3276	4.273	4.3644	4.2181
6	3.5665	4.1015	3.8803	3.6054	5.0137	4.9931	4.8371
7	.9465	.9568	.8962	.9156	1.0402	.9362	1.0208
8	3.2065	4.0832	3.7894	4.0124	4.4753	5.0926	5.8299
9	3.0464	3.89	4.177	4.6296	5.0926	5.5041	6.4615
10	3.3682	3.9369	4.369	4.9411	5.2469	5.3921	6.685
11	3.4316	4.0324	4.3056	4.7851	5.2984	5.7613	6.5101
12	3.3333	3.9849	4.4993	4.6799	5.443	5.7482	6.2186
13	3.4259	3.8889	4.5931	4.8834	5.5556	5.5556	6.3157
14	3.4316	1.0322	4.9811	4.5782	5.2469	5.4527	6.0494
15	3.558	2.8121	4.7439	4.5268	5.2532	5.6264	6.3157
16	.6093	.4858	.9945	1.0562	.9448	.763	.6882
17	.5281	.5344	.9831	.9717	.7287	.8453	.5693
18	.6316	.6613	.9145	.9717	.6962	.8145	.7287
19	1.0974	1.262	1.1163	1.182	1.1437	1.2489	1.1694
20	1.0974	1.2071	1.1163	1.1694	1.2489	1.1643	1.182
21	3.3122	3.4751	3.2236	1.4563	4.6153	4.7611	5.4527
22	3.2773	3.4208	3.0624	4.1993	4.513	4.8583	5.5447
23	3.0087	3.2236	3.083	3.8889	4.465	4.7531	5.443
24	2.6606	2.9012	3.1161	3.1699	3.7449	4.369	4.6639
Max	3.5665	4.1015	4.9811	4.9411	5.5556	5.7613	6.685
Min	.5281	.4858	.8962	.9156	.6962	.763	.5693
Avg	2.5339	2.6992	3.0486	3.1639	3.7053	3.9662	4.2888

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 067011 / 132/33 KV ASGAON SUBSTATION

Feeder No / Name : 411 / 33 Asgaon Incomer 2

PURELY LIS FEEDERS

Feeder KV- 33 / INCOMING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6447	.6447	.6984	1.6804	2.0891	2.3525	.8145
2	.6447	.6516	.6984	1.7284	2.0645	2.3805	.8145
3	.6447	.6516	.691	1.7284	2.0891	2.332	.7602
4	.6447	.6584	.691	1.7078	2.0645	2.3594	.7602
5	.6516	.6516	.7442	1.8244	2.2348	2.4006	.7602
6	.7522	.9425	.8779	2.1605	3.0607	3.1579	.9877
7	.7522	.6984	.7282	.7716	.7362	.7282	.8059
8	1.9393	1.6832	2.0873	.7202	.6836	.6762	3.131
9	2.0645	1.7764	2.5143	.5784	.5658	.5258	3.1944
10	1.9216	.487	2.2771	.4681	.4298	.4681	3.4156
11	1.8747	2.0165	2.2965	.463	.3641	.3601	3.4214
12	1.761	1.9685	2.0399	.3521	.3721	.3641	3.4214
13	1.5421	2.0622	1.6872	.5087	.4252	.4115	3.562
14	1.5352	2.0153	1.5844	.5087	.4298	.4161	3.4259
15	1.6918	1.8747	1.6667	.5596	.3761	.3641	3.287
16	.3121	.3841	.3361	.3841	.3641	.3361	.4424
17	.4012	.4515	.4115	.503	.4915	.3201	.4687
18	.5533	.4578	.5761	.5944	.6539	.5973	.5556
19	.9877	1.0317	1.0317	1.086	1.1065	1.1088	1.086
20	.9425	.9877	1.0974	1.0425	1.1523	.9979	.9877
21	.8145	.9877	.9877	2.1879	2.4366	2.4086	.9979
22	.7522	.8688	.9231	2.4691	2.4577	2.3594	.8688
23	.7059	.7522	.8688	2.1376	2.4577	2.332	.8688
24	.6516	.7059	.691	.8688	2.1376	2.3805	2.2834
Max	2.0645	2.0622	2.5143	2.4691	3.0607	3.1579	3.562
Min	.3121	.3841	.3361	.3521	.3641	.3201	.4424
Avg	1.0494	1.0588	1.1752	1.1264	1.3018	1.3391	1.7134

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 006813 / 220 KV KAWLEWADA SUBSTN

Feeder No / Name : 401 / 33KV SIHORA

PURELY LIS FEEDERS

Feeder KV- 33 / INCOMING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0642	.9774	1.1946	2.572	4.0238	4.321	1.4266
2	1.0642	.9774	1.2071	2.572	3.9232	4.2181	1.4563
3	1.0642	.9774	1.1946	3.4979	3.9232	4.2181	1.4563
4	1.0642	.9774	1.2071	3.4979	3.9232	4.2181	1.4563
5	1.2323	.9774	1.2071	3.7037	3.9232	4.321	1.4563
6	1.4563	1.086	1.2071	4.1152	4.0238	4.8285	1.6804
7	1.4563	1.3032	1.5364	1.4266	1.5043	1.3375	1.4563
8	3.3425	4.2798	4.3896	1.4266	1.2894	1.2346	4.6273
9	3.9323	4.4525	4.6091	1.4266	1.2894		4.8285
10	4.4993	4.6091	4.3256	1.3169	1.1317	1.2071	5.0412
11	4.3439	4.4525	4.5268	1.2071	1.0288	1.2071	5.144
12	4.4525	4.7188	4.6273	1.0974	1.0288	1.0974	5.0412
13	4.4525	4.4525	4.5268	1.2071	1.0288	1.2323	5.0412
14	4.4525	4.1701	4.5268	1.2071	1.1317		5.0412
15	4.3439	4.1701	4.3256	1.2071	1.1317	1.2323	5.0412
16	.9774	1.086	1.0974	1.2071	1.1317	1.2323	1.182
17	.9774	1.086	1.0974	1.2071	1.0288	1.2323	1.2894
18	1.1946	1.3032	1.3169	1.2071	1.2346	1.3443	1.2894
19	1.9547	2.1719	2.1948	2.1491	2.0576	2.3525	2.2565
20	2.0633	2.1719	2.1948	2.2565	2.1605	2.3525	2.2085
21	1.8461	1.9547	2.0851	4.2181	4.5268	4.225	2.1033
22	1.4118	1.5203	1.6461	4.1244	4.5268	4.1244	1.893
23	1.086	1.3032	1.4266	4.0238	4.4239	3.9232	1.4723
24	1.1203	.9877	1.1946		4.0238	4.321	3.722
Max	4.4993	4.7188	4.6273	4.2181	4.5268	4.8285	5.144
Min	.9774	.9774	1.0974	1.0974	1.0288	1.0974	1.182
Avg	2.2855	2.3403	2.4527	2.2554	2.4758	2.7173	2.8171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 006813 / 220 KV KAWLEWADA SUBSTN

Feeder No / Name : 404 / 33 KV NAKADONGARI FEEDER

PURELY LIS FEEDERS

Feeder KV- 33 / INCOMING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258	.2743	.3292	.823	.7773	.8139	.3761
2	.3258	.2743	.3292	.8139	.7773	.8048	.3721
3	.3258	.3258	.3292	.823	.7773	.8048	.3721
4	.3801	.3681	.3292	.9259	.7773	.8453	.4887
5	.4344	.4681	.3761	.9774	.9717	.9945	.7059
6	.6516	.631	.5373	1.2346	1.2574	1.2071	.8145
7	.6516	1.4752	.7059	.7202	.7122	.6687	1.1523
8		1.2431	1.2574	.6104	.6613	.6241	1.5546
9		1.3923	1.4403	.7122	.7122	.7545	1.8501
10		1.3923	1.4883	.583	.6173	.6539	1.9204
11	1.1568	1.2963	1.5769	.6173	.5407	.5144	1.9433
12	1.1568	1.2963	1.5261	.6687	.5898	.6613	1.9919
13	1.1437	1.3117	1.5769	.6687	.5407	.7202	1.9433
14	1.0059	1.2334	1.5769	.5144	.5967	.6613	1.8947
15	.4578	1.2071	1.3735	.5658	.583	.6104	1.9616
16	.4527	.4424	.5596	.5144	.5344	.6173	.5596
17	.4527	.503	.407	.4115	.583	.6173	.6379
18	.4344	.4161	.407	.4115	.4424	.503	.6722
19	.6722	.679	.6173	.6173	.7356	.7522	.8488
20	.6161	.6224	.6173	.6173	.6224	.7842	.8488
21	.6161	.5658	.5658	1.0288	.9991	1.0534	.7356
22	.4481	.4481	.463	.9774	.9362	.9425	.6161
23	.3326	.3921	.4115	.8745	.8842	.7973	.4938
24	.3258	.3326	.3361	.8139	.8139	.823	.3761
Max	1.1568	1.4752	1.5769	1.2346	1.2574	1.2071	1.9919
Min	.3258	.2743	.3292	.4115	.4424	.503	.3721
Avg	.5889	.7746	.7974	.7302	.7268	.7596	1.0471

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064010 / 33 KV GOBARWAHI S/STN

Feeder No / Name : 207 / 11 KV Bagheda

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7969	.6783	.8478	.8987	.78	.7969	.7969
2	.78	.6613	.8309	.8817	.78	.78	.7969
3	.7969	.6613	.6783	.8478	.78	.78	.8139
4	.78	.6613	.6952	.8309	.763	.763	.8309
5	.78	.6613	.6443	.8309	.8309	.763	.8309
6	.7969	.7122	.7122	.8817	.8309	.78	.8309
7	.8309	.763	.9496	.8987	.8478	.8139	.7291
8	.8987	.8648	.9835	.9496	.8139	.9156	.763
9	.9326	.9326	1.0343	1.0004	.8478	.9496	1.0174
10	.9496	1.0343	1.17	1.1022	.9496	1.0004	1.1869
11	1.1191	1.0852	1.153	1.1361	1.0513	1.0343	1.153
12	1.1361	1.2209	1.2548	1.17	1.0174	1.153	1.0004
13	1.0852	1.1022	1.2378	1.153	1.0004	1.1869	1.0852
14	1.0004	1.153	1.0682	1.0852	1.0004	1.0513	1.0004
15	1.0852	.6274	1.2717	1.2039	.9156	1.153	1.1869
16	1.1869		1.1361	1.2209	.9835	1.1869	1.1869
17	1.1869	1.17	1.17	1.2039	.9156	1.1191	1.3226
18	1.1361	1.1361	1.1022	1.0682	.8309	1.1191	1.2209
19	1.1022	1.1022	1.1361	1.0513	.9835	1.0852	1.1191
20	1.0852	1.0852	1.1191	1.0343	1.0852	1.0852	1.1361
21	.9156	1.0174	1.0852	.9835	.9665	1.0174	1.0343
22	.78	.9156	1.0004	.8817	.8987	.8817	.9496
23	.7122	.8478	.9326	.8309	.8478	.8478	.8987
24	.7969	.6952	.8478	.9156	.8139	.8139	.8139
Max	1.1869	1.2209	1.2717	1.2209	1.0852	1.1869	1.3226
Min	.7122	.6274	.6443	.8309	.763	.763	.7291
Avg	.9446	.9039	1.0025	1.0025	.8973	.9616	.9877

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064010 / 33 KV GOBARWAHI S/STN

Feeder No / Name : 209 / 11 KV Dongri bz

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3547	.4108	.4108	.3734	.3734	.3921	.4481
2	.3734	.3921	.4108	.3734	.3734	.3547	.4481
3	.3734	.3921	.4108	.3734	.3734	.3547	.4668
4	.3921	.3921	.3734	.3921	.3921	.3547	.4854
5	.3921	.4108	.3547	.4108	.5228	.3921	.4854
6	.4481	.5228	.4481	.5041	.5228	.4854	
7	.5415	.5601	.6161	.5041	.6348	.5228	.5975
8	.5601	.6908	.6722	.5228	.7095	.6348	.6348
9	.5975	.6908	.6535	.7842	.6908	.7282	.7095
10	.5975	.6348	.8589	.7842	.6161	.7095	.8775
11	.3547		.8775	.8215	.7468	.8215	.7468
12	.5788	.7095	.8029	.7095	.7468	.8215	.7842
13	.5788	.6722	.8402	.7842	.7655	.8029	.7095
14	.5601	.7842	.7655	.7842	.6908	.7282	.7095
15	.6908	1.3256	.8215	.7468	.5788	.7095	.7468
16	.6161	.6722	.8775	.7095	.5601	.7842	.7282
17	.6535	.6535	.6535	.7095	.5228	.8215	.6535
18	.5601	.6348	.6908	.6722	.5041	.6348	.6348
19	.7655	.8029	.8215	.8962	.7468	.8589	.8215
20	.7468	.7282	.7842	.8962	.7095	.7842	.8402
21	.6722	.6535	.6908		.6535	.6908	.7842
22	.5041	.5041	.5601	.5601	.5415	.5601	.6161
23	.4108	.4668	.4294	.5228	.4481	.5041	.5228
24	.3734	.4108	.4481	.4108	.4854	.4294	.4481
Max	.7655	1.3256	.8775	.8962	.7655	.8589	.8775
Min	.3547	.3921	.3547	.3734	.3734	.3547	.4481
Avg	.5290	.6137	.6364	.6194	.5796	.6200	.6478

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064010 / 33 KV GOBARWAHI S/STN

Feeder No / Name : 210 / 11 KV Chikhala

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.5658	.2641	.7733	.3772	.3961	.5281
2	.415	.547	.2641	.6036	.3584	.4527	.5847
3	.3961	.3395	.2263	.5658	.2075	.4338	.6413
4	.3772	.3772	.3395	.415	.3395	.3395	.3018
5	.3961	.3395	.2641	.415	.3395	.3206	.2829
6	.415	.3584	.2641	.3395	.3395	.3018	.2829
7	.415	.2641	.3395	.3206	.3206	.3206	.2829
8	.3772	.2641	.3961	.4527	.3206	.4527	.3961
9	.9431	.3206	.9242	.6036	.7167	.7733	.6413
10	.9431		.8865	.9808	1.0185	1.1128	1.1694
11	.6224		.811	.415	.6036	.6224	.3772
12	.6979	.2452	.7167	.7922	.679	.811	.811
13	.8676	.2452	.9431	.6602	.9619	.9431	.8488
14	.8488	.2452	.8865	1.0185	.8299	.8299	.9242
15	.4527	.2641	.3018	.2641	.3018	.3206	.3018
16	.3772	.2641	.4904	.415	.4527	.5281	.3395
17	.9054	.2641	1.0751	.8488	.7922	.7545	1.094
18	.7922	.3018	.9997	1.1317	1.0374	1.3203	.9808
19	.3584	.2829	.679	.6413	.4715	.3018	.6224
20	1.0185	.3206	.9619	.547	.7167	.8299	.8865
21	.7922	.2641	.7356	.6224	.811	.6602	1.0562
22	.3772	.2641	.3395	.2829	.3018	.2641	.3395
23	.3395	.2829	.2829	.3206	.2641	.3018	.3395
24	.4715	.3772	.2829	.4338	.415	.3961	.4338
Max	1.0185	.5658	1.0751	1.1317	1.0374	1.3203	1.1694
Min	.3395	.2452	.2263	.2641	.2075	.2641	.2829
Avg	.5855	.3181	.5698	.5776	.5407	.5745	.6028

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064010 / 33 KV GOBARWAHI S/STN

Feeder No / Name : 211 / 11 KV Nakadongari AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3734	.3921	.3921	.4108	.4481	.4108
2	.3547	.3174	.3734	.3921	.4108	.4294	.4294
3	.3734	.3174	.3734	.3921	.4108	.4294	.4481
4	.3547	.3174	.3547	.3921	.3734	.4294	.4481
5	.3734	.3547	.3547	.4294	.5228	.4854	.4668
6	.3921	.3921	.4108	.4481		.5228	.4668
7	.4668	.4668	.5041	.4481	.4481	.4668	.4294
8	.4294	.4481	.4854	.3921	.3921	.4481	.4294
9	.4481	.4854	.5601	.4294	.4481	.4481	.5415
10	.4108	.4481	.5415	.4668	.3921	.4481	.5228
11	.4294		.5041	.4668	.4108	.4854	.5228
12	.3921	.4481	.5415	.4481	.3734	.4108	.5788
13	.3921	.4294	.4854	.4108	.3921	.3921	.5601
14	.4108	.0747	.4854	.4481	.4108	.4108	.5788
15	.4854	.056	.5228	.3734	.4108	.3921	.5975
16	.3734		.4294	.4108	.4668	.4108	.4481
17	.3547		.4668	.4294	.4481	.4108	.4481
18	.4668	.5228	.5041	.4854	.5041	.4854	.4854
19	.6348	.6908	.6722	.6722	.6908	.6535	.6535
20	.6348	.6722	.6535	.6535	.6908	.6535	.6722
21	.5601	.5975	.5975	.6161	.6535	.6722	.6161
22	.4854	.5041	.5415	.5788	.5975	.5975	.5415
23	.4481	.4481	.4668	.5228	.5228	.5228	.4854
24	.3734	.3734	.4294	.4294	.4854	.4854	.5041
Max	.6348	.6908	.6722	.6722	.6908	.6722	.6722
Min	.3547	.056	.3547	.3734	.3734	.3921	.4108
Avg	.4341	.4161	.4854	.4637	.4725	.4808	.5119

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064011 / 33 KV DONGRI (BZ)

Feeder No / Name : 201 / 11 KV EMD

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4481	.4527	.415	.0934	.1132	.0566	.5281
2	.4481	.4527	.4904	.0934	.1132	.0566	.5093
3	.3734	.4715	.4904	.4294	.0943	.0566	.4338
4	.3734	.4715	.4338	.4481	.1132	.0566	.4338
5	.4294	.4715	.1886	.4481	.1132	.3961	.4715
6	.4294	.4527	.1886	.4108	.1132	.3772	.4715
7	.4481	.4904	.0754	.4294	.1132	.4338	.4715
8	.4854	.4904	.0754	.4481	.0943	.415	.4527
9	.4904	.5093	.0943	.4294	.1132	.0943	.0943
10	.4854	.0943	.0943	.4668	.0943	.4338	.0943
11	.5228	.1698	.0943	.0934	.0943	.4527	.4527
12	.547	.4904	.0934	.4854	.0943	.5093	.4527
13	.4715	.415	.1494	.5281	.0189	.415	.5281
14	.4338	.415	.1494	.5281	.0189	.415	.5041
15	.4715	.5281	.0934	.4527	.0189	.4338	.4481
16	.4715	.4904	.0934	.4715	.0189	.4527	.0747
17	.4338	.3772	.112	.4904	.0189	.4338	.4668
18	.4527	.3772	.112	.4527	.0566	.4338	.5228
19	.4904	.547	.1494	.2075	.0377	.4715	.4668
20	.4715	.4904	.1494	.4715	.0377	.4715	.4668
21	.4338	.4527	.112	.4527	.0566	.5281	.4668
22	.415	.4527	.112	.4527	.0377	.4338	.4481
23	.4338	.4527	.1867	.4527	.0566	.5281	.4854
24	.4527	.4527	.4338	.0934	.4338	.0566	.5281
Max	.547	.547	.4904	.5281	.4338	.5281	.5281
Min	.3734	.0943	.0754	.0934	.0189	.0566	.0747
Avg	.4547	.4362	.1911	.3887	.0865	.3505	.4280

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064011 / 33 KV DONGRI (BZ)

Feeder No / Name : 202 / 11kv Balapur

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3584	.2263	.2641	.2263	.2263	.2075	.132
2	.2829	.2263	.2641	.2263	.2075	.1886	.2075
3	.2829	.2263	.2263	.2263	.2263	.1698	.2075
4	.1886	.2263	.2263	.2075	.2263	.1886	.2075
5	.1886	.2075	.2075	.2075	.2263	.1886	.1509
6	.1886	.1886	.2075	.2075	.2075	.1509	.1509
7	.132	.132	.2075	.1698	.132	.1509	.132
8	.2452	.1509	.2075	.1509	.132	.1509	.1509
9	.1509	.3018	.132	.1886	.132	.3206	.1509
10		.1886	.1886	.1698	.132	.3018	.1132
11	.1698	.132	.1509	.2075	.132	.3395	.2452
12	.3206	.1698	.3018	.3206	.3018	.1698	.1509
13	.1509	.1698	.132	.1509	.132	.132	.132
14	.132	.1698	.132	.1509	.132	.1509	.132
15	.0943	.132	.132	.132	.132	.132	.132
16	.1886	.132	.1509	.1132	.132	.0943	.1132
17	.1698	.1886	.132	.132	.132	.132	.132
18	.1509	.2263	.1509	.1886	.1509	.1509	.132
19	.2641	.2263	.2452	.2075	.2641	.2641	.2263
20	.3772	.2263	.2829	.3961	.2452	.2641	.2263
21	.2263	.2452	.2641	.2641	.2641	.2829	.2452
22	.1886	.2452	.2263	.2075	.2075	.2263	.2075
23	.2075	.2641	.2641	.2263	.2452	.2452	.2263
24	.3584	.2075	.2641	.2263	.2263	.2452	.132
Max	.3772	.3018	.3018	.3961	.3018	.3395	.2452
Min	.0943	.132	.132	.1132	.132	.0943	.1132
Avg	.2181	.2004	.2067	.2043	.1894	.2020	.1682

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064014 / 33 KV SIHORA S/STN

Feeder No / Name : 211 / 11 KV Sihora SP

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7095	.695	.7947	.5853	.5258	.5144	1.0269
2	.7095	.695	.7947	.5853	.5258	.5144	1.0269
3	.7095	.7133	.7947	.5853	.5258	.5144	1.0269
4	.7095	.7133	.7947	.5487	.5083	.5144	1.0269
5	.7842		.8871	.5121	.5083	.5144	1.0642
6	.8589	.823	.961	.4572	.4733	.5487	1.0456
7	.8775	.9328	.924	.8779	.9134	.8402	.9335
8	.4588	.4938	.4572	.8779	.8775	.7716	.5487
9	.4588	.5304	.5121	.8779	.8417	.8775	.567
10	.5121	.5121	.4359	.823	.7716	.8775	.5434
11	.439	.4938	.4527	.7701	.7373	.8962	.5258
12	.439	.4207	.4527	.7522	.7202	.8962	.5083
13	.439	.4572	.4359	.7701	.703	.8215	.4733
14	.439	.4572	.4359	.7701	.7545	.8029	.4382
15	.4207	.3658	.4191	.788	.7888	.8402	.4207
16	.695	.6767	.6767	.8059	.7716	.8215	.3761
17	.695	.695	.695	.8238	.7545	.7842	.5258
18	.8779	.8507	.8596	.8596	.9259	.9896	.964
19	1.3717	1.4815	1.4632	1.4506	1.4403	1.5684	1.4899
20	1.39	1.4449	1.5546	1.5223	1.4575	1.4937	1.4723
21	1.2071	1.2986	1.4632	.6173	.6001	.6036	1.4198
22	.9511	1.0059	1.0791	.5959	.583	.6219	1.3321
23	.7682	.823	.8596	.5609	.5144	.4938	1.2269
24	.7095	.695	.7865		.5258	.5144	.4572
Max	1.39	1.4815	1.5546	1.5223	1.4575	1.5684	1.4899
Min	.4207	.3658	.4191	.4572	.4733	.4938	.3761
Avg	.7346	.7511	.7912	.7747	.7395	.7765	.8517

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064014 / 33 KV SIHORA S/STN

Feeder No / Name : 212 / 11 KV Bapera SP

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1612	.3475	.3658	.5784	.6135	.6219	.4477
2	.1612	.3475	.3658	.5784	.6135	.6219	.4298
3	.1612	.3475	.3658	.5784	.6135	.6219	.4298
4	.1612	.3475	.3658	.5784	.631	.6219	.4298
5	.2328	.3475	.4207	.5784	.6661	.6219	.4656
6	.394	.3658	.4572	.5959	.7011	.695	.4477
7	.3761	.4024	.4024	.3224	.4477	.3658	.4298
8	.5552	.6584	.6584	.3292	.3582	.3658	.7164
9	.5194	.7133	.7499	.3292	.2865	.3547	.7164
10	.6401	.695	.6516	.3224	.2378	.3224	.7362
11	.695	.7133	.6687	.3224	.2378	.3045	.7362
12	.6767	.7499	.6859	.3045	.2378	.2865	.7011
13	.695	.695	.6687	.3045	.2378	.3224	.7186
14	.695	.6401	.6516	.3045	.2926	.2328	.7186
15	.695	.5853	.6516	.3224	.3292	.3403	.7362
16	.2378	.2896	.2865	.3224	.2926	.3224	.3045
17	.2378	.3077	.3045	.3403	.2561		.333
18	.2561	.3439	.3403		.3292		.3681
19	.7316	.6401	.6447		.695	.6805	.6836
20	.695	.6697	.6661	.6836	.695	.6268	.6984
21	.5853	.5792	.6135	.6173	.6584	.6805	.6485
22	.4572	.4572	.4572	.631	.6219	.7164	.5731
23	.3658	.3841	.4024	.6135	.6219	.6447	.5373
24	.1791	.3475	.3658		.6135	.6219	.6268
Max	.7316	.7499	.7499	.6836	.7011	.7164	.7362
Min	.1612	.2896	.2865	.3045	.2378	.2328	.3045
Avg	.4402	.4990	.5088	.4551	.4703	.4997	.5681

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064014 / 33 KV SIHORA S/STN

Feeder No / Name : 213 / 11 KV Gondekhari SP

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.5121	.567	1.1869	1.3245	1.4998	.6001
2	.4801	.5121	.567	1.1869		1.4998	.583
3	.4801	.5121	.567	1.1869	1.3748	1.4998	.583
4	.4801	.5121	.567	1.2209	1.4083	1.4998	.583
5	.5487	.5121	.695	1.2887	1.4419	1.4998	.6173
6	.6687	.5853	.8048	1.4922	1.5089	1.5546	.6859
7	.7202	.7865	.8413	.7522	.8589	.7499	.7373
8	1.3375	1.3535	1.6278	.7343	.7011	.7133	1.5261
9	1.4746	1.5181	1.6461	.7343	.7011	.583	1.5947
10	1.5181	1.5497	1.5091	.6626	.6379	.583	1.5769
11	1.4815	1.5524	1.5261	.6447	.567	.5487	1.6108
12	1.4815	1.6278	1.56	.6089	.567	.5316	1.56
13	1.4632	1.5546	1.56	.6089	.567	.5144	1.543
14	1.4632	1.4449	1.543	.6089	.5853	.5487	1.5261
15	1.4083	1.5181	1.5261	.6268	.567	.583	1.5091
16	.4207	.567	.5434	.6268	.5853	.5487	.5258
17	.4207	.5853	.5609	.6447	.5853	.5316	.5784
18	.5304	.5853	.5609	.6805		.6516	.6661
19	1.0974	1.1157	1.1218	1.1145	.7499	1.1317	1.1919
20	1.0608	1.0974	1.1043	1.1393	1.1706	1.1145	1.1393
21	.9328	.9694	.9774	1.358	1.5364	1.3203	1.0692
22	.7316	.7023	.6805	1.3413	1.5364	1.3375	.964
23	.567	.6099	.6268	1.3413	1.4998	1.2517	.8589
24	.4801	.5121	.567		1.3245	1.4998	1.2003
Max	1.5181	1.6278	1.6461	1.4922	1.5364	1.5546	1.6108
Min	.4207	.5121	.5434	.6089	.567	.5144	.5258
Avg	.9053	.9498	.9938	.9474	.9909	.9915	1.0429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064014 / 33 KV SIHORA S/STN

Feeder No / Name : 214 / 11 KV Silegaon SP

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.3841	.4572	.8478	.9156	1.0242	.5601
2	.4108	.3841	.4572		.9156	1.0242	.5601
3	.4108	.3841	.4572	.7969	.9156	1.0242	.5601
4	.4108	.4024	.4572	.78	.9326	1.0242	.5601
5	.4854	.4024	.4755	.763	.9496	1.0242	.5975
6	.6161	.439	.4755	.7461	.9835	1.0242	.5788
7	.5788	.4938	.5853	.5552	.4917	.6401	.5601
8	.8215	.8779	.8413	.5552	.4382	.5487	1.1096
9	.8718	.8779	.823	.5373	.4557	.5041	1.1096
10	.9231	1.0059	.8951	.5194	.4572	.4854	1.1191
11	.9328	.9694	.9945	.4477	.4207	.4668	1.1361
12	.9328	.9877	1.0111	.3761	.4207	.4481	1.153
13	.9328	.9328	.9779	.394	.4207	.4481	1.153
14	.9328	.9231	.9448	.4119	.4572	.4294	1.17
15	.9328	.9145	.9116	.4298	.4024	.4668	1.2094
16	.3841	.3292	.3224	.4477	.3841	.4294	.7186
17	.3841	.3658	.3582	.4656	.3841	.4294	.6661
18	.439	.4024	.394	.4835	1.0608	.5228	.6135
19	.7499	.7865	.788	.7537	.8048	.8215	.7712
20	.7133	.6767	.7701	.7712	.823	.7842	.7537
21	.6219	.6584	.7164	.9326	1.0608	.8842	.7186
22	.5121	.5304	.5487	.9326	1.0242	.8669	.631
23	.4207	.4572	.4755	.9156	1.0242	.8669	.5784
24	.4108	.3841			.9156	1.0242	.8669
Max	.9328	1.0059	1.0111	.9326	1.0608	1.0242	1.2094
Min	.3841	.3292	.3224	.3761	.3841	.4294	.5601
Avg	.6350	.6237	.6582	.6301	.7108	.7172	.8106

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064014 / 33 KV SIHORA S/STN

Feeder No / Name : 216 / 11 KV Chandpur SP

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.4024	.4938	.2587	.3292	.3292	.6161
2	.4108	.4024	.4938	.2587	.3292	.3086	.5975
3	.4108	.4024	.4938	.2587	.3292	.3292	.5975
4	.4108	.4024	.4938	.2587	.3109	.3292	.5975
5	.4108	.4024	.5487	.2957	.3109	.3292	.6348
6	.4854	.4024	.6036	.3326	.2926	.3841	.6722
7	.5601	.4024	.5304	.5359	.5729	.4755	.5415
8	.5041	.3292	.3292	.5359	.5175	.4572	.3547
9	.3174	.3475	.3109	.5175	.5729	.4668	.3734
10	.2561	.3475	.3224	.462	.439	.4668	.3658
11	.3258	.3292	.3224	.439	.4755	.4668	.3841
12	.3258	.3109	.3045	.4207	.4572	.4668	.3292
13	.3258	.2743	.2818	.4207	.439	.4481	.3292
14	.3109	.2561	.3045	.4207	.439	.4294	.3155
15	.3109		.3045	.439	.4572	.4481	.3155
16	.3292	.3982	.4024	.439	.439	.4854	.4435
17	.3292	.4344	.439	.4572	.4024	.5415	.4207
18	.4755	.5249	.5304	.4755	.4755	.5415	.462
19	.7316	.567	.823	.8779	.8413	.8962	.8871
20	.8048	.8779	.823	.8779	.8413	.8589	.8686
21	.6878	.7499	.7682	.3403	.4024	.4108	.7947
22	.5487	.5853	.5914	.3475	.3658	.4481	.7392
23	.439		.5175	.3292	.3292	.4294	.6468
24	.4108	.4024	.4938		.3292	.3292	.3547
Max	.8048	.8779	.823	.8779	.8413	.8962	.8871
Min	.2561	.2561	.2818	.2587	.2926	.3086	.3155
Avg	.4389	.4342	.4803	.4347	.4458	.4615	.5267

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064026 / 33/11 Nakadongari

Feeder No / Name : 201 / 11KV Pathari G

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.362	.3601	.4066	.362
2		.3429	.3721	.3881	.362
3		.3601	.415	.4207	.3841
4		.4287	.4458	.4572	.5121
5		.5611	.5316	.4887	.7133
6		.724	.7712	.7796	.8962
7		.7545	.7888	.7186	.7975
8		.6344	.7186	.6836	.703
9		.7362	.7537	.8149	.7545
10		.6661	.703	.7108	.7042
11		.5898	.6068	.6001	.6464
12		.6478	.6203	.7373	.6874
13		.6859	.6133	.7802	.7127
14		.5243	.7042	.6935	.6706
15		.5487	.6104	.6588	.7373
16		.5316	.5407	.6588	.547
17		.4287	.5898	.6588	.6036
18		.4239	.4527	.4752	.6274
19	.6516	.6805	.6767	.7682	.7459
20	.5959	.679	.679	.8029	.7628
21	.5914	.4481	.6161	.6838	.7164
22	.5093	.5228	.5281	.5487	.5853
23	.415	.4481	.4435	.4344	.4706
24		.362	.4108	.4066	.3439
Max	.6516	.7545	.7888	.8149	.8962
Min	.415	.3429	.3601	.3881	.3439
Avg	.5526	.5455	.5813	.6157	.6269

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064026 / 33/11 Nakadongari

Feeder No / Name : 202 / 11KV ASHTI AGP

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2818	.3326	.3258		.2972	.3086	
2	.3052	.3142	.3077	.2972	.2972	.2932	
3	.3258	.3109	.3077	.2824	.2972	.3086	
4	.3772	.3898	.3403	.2972	.2972	.3281	
5	.4508	.4681	.3982	.2824	.3121	.3281	
6	.6241	.6836	.5493	.2972	.3395	.3437	
7	.6588	.9835	.7011				.3641
8	.9175	1.0277	1.073				.7282
9	1.0442	1.21	1.2574				.8886
10	.9448	1.1603	1.2742				.9282
11	.9614	1.1105	1.3565				.9116
12	.8951	1.1105	1.1469				.9724
13	.8745	1.1174	1.2125				.9389
14	.8192	1.0526	1.2616				.9175
15	.4748	.9442	1.0242				.8785
16	.4641	.4641	.5992				
17	.4862	.5249	.421				
18	.4706	.4207	.4252				
19	.6979	.6838					
20	.6602	.6413					
21	.6036	.5847		.2824	.3086	.2439	
22	.4481	.4715		.301	.3125	.2623	
23	.3696	.3696		.3391	.3086	.2812	
24	.3224	.3361	.3326	.301	.2972	.3086	
Max	1.0442	1.21	1.3565	.3391	.3395	.3437	.9724
Min	.2818	.3109	.3077	.2824	.2972	.2439	.3641
Avg	.6032	.6964	.7534	.2978	.3067	.3006	.8364

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064026 / 33/11 Nakadongari

Feeder No / Name : 203 / 11KV KAWALEWADA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1457	.1372	.125	
2				.1457	.1372	.125	
3				.1457	.144	.125	
4				.1457	.1372	.1406	
5				.1457	.1372	.1406	
6				.1619	.1677	.1562	
7		.128					.1341
8	.192	.192	.1562				.2458
9	.192	.2372	.2401				.3688
10	.1898	.2372	.2561				.3978
11	.2056	.2294	.2721				.3688
12	.2372	.208	.2561				.3277
13	.2214	.2056	.2881				.3401
14	.1898	.2214	.2561				.3441
15		.2214	.2401				
21				.1355	.125	.0926	
22				.1355	.125	.0949	
23				.1337	.125	.096	
24				.1457	.1372	.125	
Max	.2372	.2372	.2881	.1619	.1677	.1562	.3978
Min	.1898	.128	.1562	.1337	.125	.0926	.1341
Avg	.2040	.2089	.2456	.1441	.1373	.1221	.3159

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064034 / 33 KV TUMSAR

Feeder No / Name : 201 / 11 KV SIHORA G

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.3018	.3584	.3772	.3961	.3961	.4338
2	.2641	.2641	.3395	.3772	.3961	.3961	.415
3	.2641	.2641	.3206	.3772	.3961	.3961	.3961
4	.2641	.2641	.3206	.3772	.3961	.3961	.3961
5	.2829	.3395	.3395	.3584	.3961	.415	.415
6	.2641	.3206	.3961	.3772	.3772	.3961	.415
7	.1867	.2218	.2829	.2829	.2641	.3018	.2829
8	.1867	.181	.2427	.2427	.2926	.2452	.2427
9	.128	.181	.2054	.2427	.2195	.2402	.2926
10	.1448	.1433	.2033	.2427	.2743	.2402	.3045
11	.1267	.1097	.1294	.2033	.2353	.2534	.2353
12	.1448	.1109	.128	.2241	.2743	.2328	.2353
13	.128	.1294	.1848	.181	.2534	.2353	.2378
14	.1848	.1829	.1478	.2218	.2378	.2012	.2378
15	.1448	.1307	.1478	.1848	.2195	.1848	.2012
16	.1829	.181	.2012	.1463	.2686	.1478	.2353
17	.181	.128	.2172	.1629	.1663	.1463	.2328
18	.2172	.2641	.2614	.3045	.2241	.2303	.2865
19	.5228	.5658	.5281	.5729	.5281	.5281	.5788
20	.4904	.547	.5281	.547	.5658	.5658	.5788
21	.4527	.5093	.4904	.5415	.5281	.5281	.5601
22	.4338	.3961	.4527	.5093	.4715	.5093	.4854
23	.3584	.3772		.4527	.4527	.4527	.4481
24	.2829	.3395	.3584	.3961	.415	.4294	.4338
Max	.5228	.5658	.5281	.5729	.5658	.5658	.5788
Min	.1267	.1097	.128	.1463	.1663	.1463	.2012
Avg	.2550	.2689	.2950	.3293	.3437	.3362	.3575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064034 / 33 KV TUMSAR

Feeder No / Name : 203 / 11 KV TUMSAR town

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.208	.2427	.2629	.2835	.3155	.3045	.3366
2	.1907	.1715	.2454	.298	.2947	.3012	.1753
3	.2254	.2058	.2303	.2629	.2915	.3012	.2804
4	.2427	.2103	.2481	.2629	.2947	.3012	.2835
5	.2427	.2481	.2686	.2835	.298	.3045	.2835
6		.2865	.2865	.3045	.3544	.3258	.3258
7	.2658	.3224	.2804	.3012	.3294	.3012	.3258
8	.3761	.3856	.3721	.3681	.3814	.3506	.3721
9	.3544	.3681	.3544	.3189	.3681	.3366	.3258
10	.3641	.3688	.3681	.4252	.4287	.4252	.3641
11	.39	.3988	.4334	.3898	.4681	.4784	.4733
12	.4239	.4733	.4508	.4161	.4961	.4908	.4961
13	.4287	.4161	.4681	.3856	.4908	.4854	.4733
14	.3561		.4382	.4163	.4784	.4733	.5316
15	.4239	.3988	.4031	.4287	.4733	.4557	.4961
16	.3944	.3601	.4334	.3988	.5083	.4733	
17	.4115	.39	.4334	.3988	.5316	.5028	.4784
18	.5316	.463	.5548	.5201	.5609	.5201	.5552
19	.6024	.5493	.6154	.591	.6697	.6626	.6089
20	.5552	.6556	.5552	.5611	.6154	.6447	.6089
21	.4477	.394	.4525	.4477	.4525	.4835	.5068
22	.3544	.3544	.4527	.3721	.3898	.394	.4075
23	.3155	.3366		.3467	.3582	.3582	.3721
24	.2629	.2804	.3155	.3155	.3189	.3403	.3366
Max	.6024	.6556	.6154	.591	.6697	.6626	.6089
Min	.1907	.1715	.2303	.2629	.2915	.3012	.1753
Avg	.3638	.3600	.3880	.3790	.4237	.4173	.4095

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064034 / 33 KV TUMSAR

Feeder No / Name : 204 / 11 KV JAMB town

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1694	1.1694	1.2826	1.3392	1.3908	1.3769	1.3392
2	1.1506	1.1506	1.2449	1.3203	1.3527	1.3392	1.3392
3	1.1694	1.1317	1.2449	1.2826	1.3336	1.3392	1.3769
4	1.2071	1.1883	1.2826	1.2826	1.3527	1.3392	1.3769
5	1.2071	1.2449	1.3203	1.3392	1.3957	1.358	1.419
6	1.3392	1.3392	1.3769	1.3957	1.5051	1.3957	1.5089
7	1.5242	1.4289	1.5813	1.3769	1.6575	1.5242	1.4901
8	1.5813	1.448	1.448	1.5242	1.5466	1.5089	1.5089
9	1.4523	1.4098	1.3527	1.4289	1.4146	1.2826	1.3203
10	1.3392	1.2826	1.3392	1.4523	1.3203	1.2449	1.2715
11	1.3392	1.2449	1.3392	1.4335	1.3203	1.3392	1.2826
12	1.2637	1.2637	1.4146	1.3203	1.2449	1.2826	1.3014
13	1.1317	1.1883	1.3014	1.2449	1.226	1.226	1.226
14	1.0751	1.1506	1.2826	1.2637	1.3014	1.0087	1.2574
15	1.1506	1.1694	1.226	1.1883	1.2637	1.226	1.2765
16	1.2071	1.1317	1.3769	1.2449	1.2637	1.226	1.358
17	1.2071		1.2637	1.2071	1.2449	1.226	1.3957
18	1.3203	1.3203	1.358	1.4003	1.3392	1.3392	1.358
19	1.6598	1.7353	1.7353	1.7541	1.7918	1.773	1.7918
20	1.6575	1.6766	1.6598	1.7918	1.7528	1.773	1.7528
21	1.5242	1.6194	1.6598	1.7528	1.7528	1.7353	1.7147
22	1.448	1.5242	1.6409	1.6766	1.6766	1.6598	1.6766
23	1.2826	1.3769		1.5623	1.5089	1.5278	1.5432
24	1.2637	1.2071	1.3203	1.3957	1.4289	1.4146	1.4289
Max	1.6598	1.7353	1.7353	1.7918	1.7918	1.773	1.7918
Min	1.0751	1.1317	1.226	1.1883	1.226	1.0087	1.226
Avg	1.3196	1.3218	1.3936	1.4158	1.4327	1.3944	1.4298

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064034 / 33 KV TUMSAR

Feeder No / Name : 205 / 11kv Sihora AGP

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.4344	.4778	.5556	
2				.423	.4841	.5487	
3				.423	.4841	.5418	
4				.4089	.4841	.5487	
5				.4371	.4923	.5247	
6				.4715	.5213	.5556	
7	.333						.4816
8	.4365	.5639	.6443				.6405
9	.4755	.5864	1.3118				.7274
10	.4988	.6249	.7287				.7499
11	.4633	.6562	.6958				.7432
12	.5281	.6325	.6093				.7186
13	.4755	.6009	.6325				
14	.5498	.6327	.6706				.6249
15	.5796	.5864	.6161				.6718
21				.4755	.503	.4064	
22				.4904	.5268	.4401	
23				.4988	.5487	.431	
24					.4841	.5487	.4254
Max	.5796	.6562	1.3118	.4988	.5487	.5556	.7499
Min	.333	.5639	.6093	.4089	.4778	.4064	.4254
Avg	.4822	.6105	.7386	.4514	.5006	.5101	.6426

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064034 / 33 KV TUMSAR

Feeder No / Name : 207 / 11kv HASARA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2926	.3292	.3292	.3696	.3658	.3696	.3982
2	.2926	.2926	.2926	.3658	.3658	.3696	.4024
3	.2926	.2926	.2926	.3658	.3658	.3696	.4024
4	.2926	.2926	.3326	.3696	.3658	.3696	.362
5	.2957	.3326	.3326	.3696	.3658	.3361	.362
6	.3326	.3696	.3696	.4066	.3696	.3734	.3734
7	.2957	.3292	.362	.362	.3224	.2896	.3326
8	.2865	.2835	.2835	.2865	.2835	.2804	.3189
9	.2835	.2835	.3155	.3224	.3224	.2835	.2774
10	.2507	.2804	.2804	.3189	.2454	.2804	.2743
11	.2743	.2401	.2804	.3121	.2774	.2743	.2743
12	.3086	.2401	.2804	.3121	.2774	.3121	.2774
13	.3052	.2427	.2481	.3086	.2454	.3086	.3121
14	.3121	.4115	.2507	.3121	.3121	.2454	.3155
15	.3391	.2774	.2804	.3429	.2865	.2427	.1132
16	.2743	.2743	.2774	.3353	.3155	.2804	.3467
17	.3429	.2713	.3086	.3353	.2774	.2743	.1886
18	.3506	.3224	.3898	.3544	.3189	.3467	.3506
19	.5175	.4805	.4805	.5121	.4805	.4805	.4607
20	.5175	.4854	.4805	.4805	.4805	.4805	.3856
21	.4435	.4481	.5175	.4805	.4805	.5175	.3544
22	.4024	.3658	.4435	.439	.3982	.4805	.439
23	.3658	.3658		.4024	.4066	.4435	.4481
24	.2926	.3658	.3658	.4066	.1829	.4066	.4024
Max	.5175	.4854	.5175	.5121	.4805	.5175	.4607
Min	.2507	.2401	.2481	.2865	.1829	.2427	.1132
Avg	.3317	.3282	.3389	.3696	.3380	.3506	.3405

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064034 / 33 KV TUMSAR

Feeder No / Name : 208 / 11 KV GANDHINAGAR TOWN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6413	.6722	.7167	.7545	.3921	.7922	.7842
2	.6036	.6413	.679	.7545	.7468	.7316	.7842
3	.6036	.6036	.6413	.7545	.7468	.7545	.7468
4	.6413	.6036	.679	.7167	.7545	.7545	.7468
5	.6413	.679	.679	.7167	.7545	.7545	.8589
6	.7095	.7167	.7167	.7545	.8215	.8299	.8589
7	.7842	.7922	.7922	.7545	.8215	.7842	.8215
8	.8962	.8131	.8131	.8676	.8501	.8589	.8589
9	.6348	.6348	.6348	.7468	.7468	.7095	.7023
10	.6348	.5914	.5975	.7095	.6283	.6584	.5959
11	.5853	.5914	.5914	.6653	.5914	.4108	.6219
12	.5228	.5544	.6283	.6653	.5544	.6838	.5914
13	.5121	.5175	.5853	.6283	.5914	.5175	.5914
14	.4755	.4435	.5914	.5914	.5914	.5544	.5975
15	.4755	.4854	.5975	.5914	.5914	.5601	.6348
16	.4755	.5228	.5658	.5914	.5914	.5544	.6283
17	.4435	.4904	.5853	.5914	.5853	.6283	.6348
18	.5792	.5853	.6653	.6584	.6219	.6283	.6154
19	.8871	.8589	.924	.9335	.9335	.9335	.905
20	.8962	.8589	.9054	.8962	.9335	.9808	.9412
21	.8589	.5281	.8676	.9054	.9808	.9709	.9709
22	.8299	.8589	.8676	.9054	.9335	.9709	.9709
23	.7167	.7842		.8299	.8589	.8962	.8962
24	.679	.7095	.7095	.7922	.7842	.8215	.8589
Max	.8962	.8589	.924	.9335	.9808	.9808	.9709
Min	.4435	.4435	.5658	.5914	.3921	.4108	.5914
Avg	.6553	.6474	.6971	.7406	.7252	.7392	.7590

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064034 / 33 KV TUMSAR

Feeder No / Name : 401 / 33 KV GOBARWAHI FEEDER
Feeder KV- 33 / INCOMINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9127	2.3525	2.6029	2.8567	.679	2.5206	3.2156
2	2.8567	2.2634	2.5463	2.7446	2.5463	2.5206	3.2253
3	2.8006	2.4897	2.4897	3.0556	2.4897	2.5766	3.0247
4	2.8006	2.4897	2.4897	2.7726	2.3765	2.5206	3.0247
5	2.7446	2.4897	2.6029	2.8006	2.4897	2.4897	2.999
6	2.6886	2.7726	2.8858	2.6886	2.5149	2.8006	2.8858
7	2.9687	2.7446	2.5206	2.6029	2.3525	2.7446	2.999
8		3.0807	3.0807	3.0167	2.7166	3.3048	3.4728
9	3.9918	3.5117	3.6408	4.0724	3.1602	3.6969	3.9209
10	3.638	2.6326	3.9506	4.4907	3.4728	4.6491	4.2896
11	4.0604	3.0247	3.9638	3.638		4.2524	3.8803
12	3.8009	3.6969	4.0604	4.2981	3.6408	4.3982	4.0832
13	4.1152	3.4168	4.225	3.9638	3.6408	4.2444	4.181
14	3.7146	2.7161	3.8958	4.1907	3.5082	4.0181	4.2353
15	3.1602	2.7984	3.2922	3.3471	2.6029	3.5294	3.3471
16	3.5837	2.9687	3.5294	3.6923	2.9127	3.8552	3.1824
17	4.225	3.0247	3.9095	4.0832	2.9687	4.1267	4.3439
18	3.2373	3.3608	3.9363	4.4445	3.4019	4.5068	4.181
19	4.145	3.8089	4.0889	4.0329	3.6408	4.201	4.4353
20	4.6571	3.9209	4.5931	4.768	3.9769	4.8788	4.8663
21	4.0741	3.4517	3.8649	4.1581	3.9209	3.9918	4.7051
22	3.1121	2.9687	3.0556	3.2487	2.8858	3.3819	3.2487
23	2.6029	2.7446		2.9687	2.5206	3.0493	2.5206
24	3.0247	2.5766	2.7446	2.6886	3.1367	3.8089	3.2156
Max	4.6571	3.9209	4.5931	4.768	3.9769	4.8788	4.8663
Min	2.6029	2.2634	2.4897	2.6029	.679	2.4897	2.5206
Avg	3.4311	2.9711	3.3900	3.5260	2.9372	3.5861	3.6451

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 067006 / 132 KV MADGI S/S

Feeder No / Name : 200 / 11 KV Incommmer 132 Madagi

T/F- Feeder KV- 11 / INCOMING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8861	2.6406	2.6406	2.572	3.3951	3.3951	2.1033
2	1.8861	2.6406	2.6406	2.8292	3.7723	3.3951	2.2634
3	1.8861	2.2634	2.6406	2.8292	3.7723	3.5837	2.1033
4	1.8861	2.6406	2.6406	2.8292	3.9609	3.5837	2.1033
5	2.8292	2.452	2.452	3.0178		3.5837	2.1033
6	2.6406	2.452	2.0748	3.2065	3.7723	3.3951	1.9281
7	2.6406	2.452	2.6406	2.6406	2.6406	2.452	2.0748
8	3.3951	3.9609	3.9609	2.6406	2.6406	2.8292	3.3951
9	3.9609	3.9609	3.9609	3.2065	2.8292	2.6406	3.5837
10	3.5837	3.9609	4.3381	2.8292	2.8292	1.8861	3.3951
11	3.9609	3.9609	4.1495	3.0178	2.8292	1.8861	3.2065
12	3.9609	3.7723	4.1495	2.8292	2.452	1.8861	2.6406
13	3.7723	3.9609	3.0178	2.6406	2.8292	2.452	
14	3.7723	3.7723	3.0178	2.452	2.6406	2.452	2.8292
15	3.7723	4.3381	3.3951	3.2065	2.0748	2.6406	3.0178
16	2.6406	2.8292	2.0748	3.2065	2.6406	2.8292	1.1317
17	2.2634	2.452	2.0748	3.2065	2.8292	3.0178	1.3203
18	3.0178	2.6406	1.8861	2.8292	2.8292	2.6406	1.5089
19	3.0178	2.8292	2.2634	3.0178	2.6406	2.8292	2.0748
20	2.8292	2.8292	1.8861	2.8292	2.452	2.452	2.452
21	2.6406	2.2634	1.6975	3.5837	3.0178	3.3951	2.2634
22	2.6406	2.2634	1.5432	3.0178	3.0178	3.0178	2.2634
23	2.452	2.8292	2.0748	2.6406	3.3951	3.155	2.2634
24	1.8861	2.8292	2.6406	2.0748	3.0178	3.3951	3.2065
Max	3.9609	4.3381	4.3381	3.5837	3.9609	3.5837	3.5837
Min	1.8861	2.2634	1.5432	2.0748	2.0748	1.8861	1.1317
Avg	2.8842	3.0414	2.7442	2.8814	2.9686	2.8664	2.4014

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 067006 / 132 KV MADGI S/S

Feeder No / Name : 203 / 11 KV BETALA G FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2204	.2858	.3506	1.153	1.3717	1.1869	.3506
2	.2204	.2572	.3506	1.1361	1.3717	1.1869	.3506
3	.2204	.1715	.3506	1.17	1.286	1.17	.3506
4	.2204	.1715	.3506	1.17	1.286	1.17	.3506
5	.2374	.1715	.3506	1.2209	1.286	1.2039	.3506
6	.2543	.2572	.3506	1.2717	1.286	1.2548	.3506
7	.2543	.2572	.2629	.2543	.2572	.2543	.2629
8	.9665	1.286	1.4899	.2543	.2572	.2713	1.5775
9	1.1869	1.4575	1.5261	.2915	.3429	.2629	1.7918
10	1.2717	1.4022	1.5261	.3429	.2883	.2629	1.6289
11	1.3565	1.4899	1.5261	.3429	.3052	.2629	1.6289
12	1.3565	1.5775	1.5261	.2572	.2204	.2629	1.6289
13	1.3717	1.5775	1.4922	.2572	.2204	.2629	1.5432
14	1.3717	1.4899	1.4752	.3429	.2543	.3506	1.6289
15	1.3717	1.6651	1.5091	.2572			1.6289
16	.2572	.2629	.2035	.2572	.2543	.2829	.2572
17	.2572	.2629	.1865	.2572	.2543	.2629	.2572
18	.2572	.2629	.2883	.2572	.2743	.2629	.2572
19	.4287	.4382	.4578	.4287	.4904	.4382	.4287
20	.4287	.4382	.407	.4287	.407	.4382	.4287
21	.3429	.3506	.373	1.2003	1.2548	1.2269	.4287
22	.3429	.3506	.373	1.3717	1.2209	1.2269	.4287
23	.2572	.2629	.3052	1.286	1.2039	1.2269	.3429
24	.2374	.2858	.2629	.3222	1.3717	1.1869	1.1393
Max	1.3717	1.6651	1.5261	1.3717	1.3717	1.2548	1.7918
Min	.2204	.1715	.1865	.2543	.2204	.2543	.2572
Avg	.6121	.6847	.7206	.6471	.7289	.6920	.8080

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 067006 / 132 KV MADGI S/S

Feeder No / Name : 205 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3146	1.3336	1.1393	.6097	1.1431	1.1241	1.0517
2	1.2955	1.2384	1.1393	.6097	1.3336	1.2765	1.0517
3	1.2955	1.1431	1.1393	.5906	1.4289	1.2384	1.0517
4	1.2765	1.3336	1.1393	.5906	1.5242	1.4098	1.0517
5	1.4289	1.3336	1.0517	.6097	1.6194	1.5242	1.0517
6	1.3527	1.4289	.8764	1.1241	1.7147	1.3527	1.1393
7	1.2955	1.1431	1.0517	1.1241	1.1431	1.1431	.964
8	1.2003	1.3336	1.2269	1.2384	1.3336	1.2384	1.0517
9	1.467	1.4289	1.1431	1.5242	1.5242	1.1393	1.2269
10	1.4289	1.3146	1.4289	1.3336	1.5242	.7011	1.3336
11	1.4289	1.3146	1.5242	1.4289	1.3908	.7011	1.1431
12	1.1431	1.0517	1.467	1.2384	1.1431	.6135	.6668
13	.1238	1.2269	.6859	1.4289	1.2384	1.1393	.6668
14	1.5242	1.3146	.724	1.1431	1.6385	1.3146	.6668
15	1.2384	1.3146	.743	1.5242	1.3336	1.0517	.6668
16	1.4289	1.2269	.7049	1.6194	1.3336	1.2269	
17	1.1431	1.2269	.724	1.7147	1.6194		.6668
18	1.5242	1.1393	.5847	1.4289	1.3717	1.3146	.6668
19	1.3336	1.0517	.7049	1.2384	1.0669	1.1393	1.0479
20	1.1431	1.2269	.5906	1.1431	1.105	1.0517	1.2384
21	1.4289	.964	.5906	1.2384	1.086	1.1393	1.2384
22	1.3336	1.1393	.5906	1.1431	1.2193	1.0517	1.2384
23	1.0479	1.1393	.5906	.7621	1.0669	1.0517	1.1431
24	1.2384	1.3336	1.1393	.5906	.9526	1.0479	1.0517
Max	1.5242	1.4289	1.5242	1.7147	1.7147	1.5242	1.3336
Min	.1238	.964	.5847	.5906	.9526	.6135	.6668
Avg	1.2681	1.2376	.9458	1.1249	1.3273	1.1300	1.0033

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 067006 / 132 KV MADGI S/S

Feeder No / Name : 206 / 11 KV UFIL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINOUS PROCESS)(NO

STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	1.0374	.964	1.1317	.7545	.9619	.7011
2	.3601	1.1317	.964	1.0374	.9431	.811	.7011
3	.3601	.9431	.964	.9431	.9431	1.0562	.7011
4	.3429	1.1317	.964	.9431	1.0374	.8865	.7011
5	1.046	.9431	.8764	1.0562	.9431	.7356	.7011
6	.9259	.7545	.7011	.679	.6602	.6602	.4382
7	1.0751	1.0374	1.1393	1.2449	1.226	1.0374	.7011
8	1.0802	1.226	.964	1.1317	1.0374	1.3014	.5258
9	1.0802	.9431	1.0562	1.3769	.9431	1.0517	.4382
10	.7545	.964	1.226	1.1317	.9997	.7888	.2829
11	1.0374	.8764	.9431	1.226	1.1128	.7888	.1886
12	1.3203	.8764	.9242	1.3203	1.0751	.8764	.1886
13	1.0374	.8764	.679	.9431	1.358	.8764	.2829
14	.7545	.7011	.6602	.9431	.7356	.6135	.3772
15	1.0374	1.0517	.9431	1.4146	.9242	1.1393	.5658
16	.9431	1.1393	1.1506	1.3203	1.0374	1.1393	.8488
17	.8488	.7888	1.1506	1.226	1.3203	.964	.3772
18	1.226	1.0517	.9808	1.1317	1.1694	.8764	.5658
19	1.226	1.1393	1.0562	1.3203	1.094	1.0517	.5658
20	1.226	.964	.8488	1.226	.9054	.7888	.7545
21	.8488	.7888	.6979	1.0374	.547	.7888	.5658
22	.9431	.6135	.7167	.3772	.4527	.5258	.5658
23	1.1317	1.2269	1.1506	.6602	.9997	.8764	.7545
24	.3961	1.226	1.0517	1.1317	.5658	1.0374	.7888
Max	1.3203	1.2269	1.226	1.4146	1.358	1.3014	.8488
Min	.3395	.6135	.6602	.3772	.4527	.5258	.1886
Avg	.8892	.9763	.9489	1.0814	.9494	.9014	.5534

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 067006 / 132 KV MADGI S/S

Feeder No / Name : 401 / 33 KV TUMSAR

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.2058	4.9794	5.2058	6.2243	4.145	6.0545	6.2734
2	5.2058	4.7531	5.0926	5.8814	5.9934	5.8814	6.1677
3	5.2058	4.9794	5.036	6.1677	6.1614	5.8253	6.1677
4	5.3189	4.8663	5.0926	5.8253	5.7133	5.7693	6.1111
5	5.0926	4.8663	5.2058	5.9374	5.8848	5.8282	5.9414
6	5.1532	5.3189	5.6019	6.0545	6.2243	6.1614	5.9414
7	5.7716	5.3189	5.3189	5.2624	5.3189	5.5453	6.5072
8	6.6655	6.4312	6.4975	6.1614	5.3189	6.1677	6.9302
9	6.5975	6.5844	13.8632	6.7638	5.2652	6.2243	7.3525
10	6.5295	5.8848	7.2428	7.1519	6.1677	7.0731	7.6818
11	7.0233	6.0431	7.276	6.2552	5.998	6.9136	7.3846
12	6.8587	7.0165	7.4074	6.9856	6.3375	6.9685	7.656
13	6.8039	6.4506	7.4623	6.5975	6.4506	6.9685	6.9302
14	6.5421	5.715	7.0965	6.9302	6.1111	6.6392	7.7063
15	6.0357	5.5418	5.8213	5.8213	5.1492	6.1054	6.6095
16	5.8162	5.1532	6.0985	6.2552	5.4887	6.2649	6.0494
17	6.5421	5.3212	6.3649	6.5844	5.6019	6.7638	7.2074
18	5.9877	6.1614	7.3183	7.4291	6.394	7.2977	7.0016
19		7.5617	7.9784	7.8418	7.7521	8.3459	8.4877
20	8.1779	7.4497	8.3179	8.4019	7.8652	8.8706	8.6574
21	7.356	6.8467	7.4126	8.2899	8.0659	8.2899	8.3745
22	6.1111	12.2222	6.4506	7.2817	6.9033	7.5057	6.8467
23	5.3755	5.6013		6.6095	6.4506	6.8336	5.8282
24	5.5453	5.1492	5.4332	5.7716	6.6095	3.8477	6.3855
Max	8.1779	12.2222	13.8632	8.4019	8.0659	8.8706	8.6574
Min	5.0926	4.7531	5.036	5.2624	4.145	3.8477	5.8282
Avg	6.1270	6.0923	6.7215	6.6035	6.1404	6.5894	6.9250

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 067006 / 132 KV MADGI S/S

Feeder No / Name : 402 / 33KV JAMB

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8745	1.1694	1.6827	2.7263	3.0407	2.6749	1.0517
2	1.3375	1.086	1.6827	2.2119	2.9321	2.6749	1.0517
3	1.3375	.9568	1.6827	2.1605	2.8172	2.7263	1.0517
4	1.3889	1.1946	1.6827	2.2119	2.8778	2.8807	1.0517
5	1.1317	1.4883	1.6827	2.2634	2.9235	2.8807	1.0517
6	1.5432	1.701	1.7878	2.4177	3.1493	2.9835	1.0517
7	.8745	.9568	1.0517	2.2634	.9568	.9259	.9465
8	3.1893	3.4551	3.5757	2.572	1.8604	1.749	4.2067
9	3.1893	3.8552	3.6008	2.7109	1.8604	1.9456	4.3118
10	3.2425	3.5757	3.6008	2.6063	1.8004	1.893	4.4119
11	3.1361	3.5231	3.5494	2.0199	1.749	1.6827	4.784
12	3.2579	3.5757	3.2922	1.9667	1.6975	1.6827	5.9185
13	3.4705	3.5757	3.7551	1.9547	1.6461	1.6301	6.1128
14	3.7311	3.0498	3.7551	1.9667	1.749	1.7878	6.0814
15	3.4751	2.9447	3.6008	1.9004	1.6975	1.7878	5.9002
16	.7442	.8413	.7716	.9568	.823	.8413	1.8604
17	.7602	1.3146	.9259	.8688	.823	.8413	1.9004
18	.9568	1.0517	.823	.9568	.9259	.9465	1.8073
19	1.4883	1.4198	1.3375	1.382	1.5844	1.4723	2.073
20	1.382	1.4723	1.3889	.9568	1.3889	1.4723	1.6478
21	1.9136	1.9982	1.9547	3.2425	3.035	3.3128	1.4883
22	1.7541	1.8404	1.8519	3.083	3.0864	2.524	1.382
23	1.5947	1.7353	1.749	2.9767	2.8807	2.7869	1.3289
24	.823	1.5415	1.6827	2.6749	3.083	2.7778	1.0517
Max	3.7311	3.8552	3.7551	3.2425	3.1493	3.3128	6.1128
Min	.7442	.8413	.7716	.8688	.823	.8413	.9465
Avg	1.9415	2.0551	2.1862	2.1271	2.0995	2.0367	2.6468

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 067006 / 132 KV MADGI S/S

Feeder No / Name : 404 / 33KV SAHULI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8745	.8688	.9991	1.4918	1.6289	1.4918	1.1568
2	.823	.8145	.9991	1.4403	1.5746	1.3889	1.1568
3	.823	.7602	.9991	1.4403	1.5746	1.4403	1.1568
4	.8745	.8688	.9991	1.4403	1.5203	1.4918	1.1568
5	.9259	.9231	.9991	1.3889	1.5746	1.4918	1.0517
6	1.0288	.9774	1.0517	1.4403	1.6289	1.4918	1.1568
7	1.0288	1.1403	1.1568	1.0802	1.1946	1.1317	1.1568
8	1.4403	1.0317	1.7878	1.0802	1.1946	1.0802	1.6827
9	1.5432	1.4661	1.6975	1.1403	1.086	1.1043	1.4723
10	1.5746	1.5249	1.749	.9774	.9774	.7888	1.8461
11	1.5746	1.5249	1.6975	1.086	.2058	.9991	1.6289
12	1.5415	1.5249	2.2634	.9231	.9259	.8939	1.8461
13	1.5746	1.5249	2.5206	.9231	.823	.7888	1.9004
14	1.4352	1.4198	2.4691	.9774	.8745	.8939	1.9547
15	1.4661	1.4198	2.4177	.9231	.9259	.8939	1.8461
16	.7602	.7362	.8745	.8688	.9259	.8939	.8688
17	.7602	.6836	.9259	.9774	.823	.9465	.8145
18	.9231	.8413	1.0288	1.0317	.9774	1.0517	.8939
19	1.6289	1.3146	1.5432	1.5415	1.6461	1.5249	1.6289
20	1.4118	1.3672	1.4918	1.5203	1.5432	1.4723	1.5746
21	1.3032	1.3672	1.3889	1.9004	1.6975	1.6301	1.4661
22	1.1946	1.262	1.286	1.8461	1.6975	1.5775	1.3575
23	1.086	1.1043	1.1831	1.6832	1.5947	1.4198	1.4118
24	.8745	.9774	.9991	1.1317	1.7353	1.4918	1.3672
Max	1.6289	1.5249	2.5206	1.9004	1.7353	1.6301	1.9547
Min	.7602	.6836	.8745	.8688	.2058	.7888	.8145
Avg	1.1863	1.1435	1.4387	1.2606	1.2646	1.2241	1.3980

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 201 / 11 KV LAKHANDUR FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2286	.2286	.2477	.2667	.2858	.2858
2	.2286	.2286	.2286	.2477	.2667	.2667	.2858
3	.2286	.2286	.2286	.2477	.2667	.2667	.2858
4	.2286		.2286	.2286	.2667	.2667	.2858
5	.2286	.2286	.2477	.2286	.2667	.2858	.2858
6	.2477	.2477	.2858	.2477	.2667	.2858	.3048
7	.2667	.2477	.2858	.2667	.2477	.2858	.2667
8	.2858	.2858	.2477	.2667	.3048	.2858	.2667
9	.2858	.2858	.2667	.2858	.3048	.2858	.2858
10	.2667	.2667	.2667	.3239	.2667	.2858	.3048
11	.3239	.2858	.2858	.3429	.3048	.3239	.3048
12	.2667	.3429	.3239	.3429	.3429		.3239
13	.2858	.3048	.3429	.2858	.3239	.4001	.3429
14	.2477	.3048	.2667	.3048	.3239	.362	.3048
15	.2667	.2667	.2858	.2667	.2858	.381	.3239
16	.2667	.2667	.2858	.2096	.362	.381	.3429
17	.2858	.3429	.2667	.2096	.362	.1905	.3429
18	.3239	.3239	.3429	.2477	.381	.3048	.3429
19	.381	.4001	.4382	.4572	.4382	.4382	.4572
20	.381	.362	.4001	.4191	.4191	.4191	.4191
21	.3429	.3429	.3429	.362	.381	.362	.381
22	.2858	.3048	.3048	.3239	.3429	.3239	.3429
23	.2286	.2667	.2858	.2858	.3048	.3048	.3048
24	.2286	.2286	.2286	.2477	.2667	.2858	.2858
Max	.381	.4001	.4382	.4572	.4382	.4382	.4572
Min	.2286	.2286	.2286	.2096	.2477	.1905	.2667
Avg	.2755	.2866	.2882	.2874	.3151	.3164	.3199

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 202 / 11 KV TEMBHARI AG FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.4954	.5144				
2	.4191	.5144	.5144				
3	.4191	.5144	.5144				
4	.4191	.5335	.5144				
5	.4572	.5716	.5716				
6	.5525	.6478	.7049				
8				.8383	.9907	.9717	1.0669
9				.9145	1.105	1.2384	1.1241
10				.9907	.8764	1.0479	1.086
11				1.0479	.9717	1.1431	1.1431
12				1.0479	1.0288	1.1622	1.1431
13				1.105	1.0098	1.1622	1.2384
14				1.0669	1.0098	1.1241	1.2193
15				1.0098	.9717	1.0669	1.2193
21	.381	.5716	.4191				
22	.5525	.5716	.4382				
23	.4954	.5144	.4382				
24	.4191	.4954	.5144	.4191			
Max	.5525	.6478	.7049	1.105	1.105	1.2384	1.2384
Min	.381	.4954	.4191	.4191	.8764	.9717	1.0669
Avg	.4534	.5430	.5144	.9378	.9955	1.1146	1.1550

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 203 / 11 KV PERSODI AG FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.1715	.1715				
2	.0953	.1715	.1715				
3	.0953	.1715	.1715				
4	.0953	.1905	.1715				
5	.1905	.2096	.1905				
6	.1905	.2667	.2477				
8				.3048	.3239	.3048	.3429
9				.3429		.381	.3429
10					.3048	.2667	.362
11				.4382	.3429	.2667	.381
12					.3429	.3048	.4001
13					.3429	.3429	.381
14					.381	.3429	.381
15				.1905	.3048	.3048	.3239
21	.1334	.1334					
22	.1715	.1905					
23	.1715	.1715	.1524				
24	.0953	.1715	.1715	.1524			
Max	.1905	.2667	.2477	.4382	.381	.381	.4001
Min	.0953	.1334	.1524	.1524	.3048	.2667	.3239
Avg	.1334	.1848	.1810	.2858	.3347	.3143	.3644

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 204 / 11 KV BARWA AG FEEDER (FEEDER SEPERATION/PURE AG
CHICHO Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0381	.0381	.0381	.0381
2				.0381	.0572	.0381	.0572
3				.0381	.0572	.0381	.0572
4				.0381	.0572	.0381	.0572
5				.0381	.0572	.0381	.0572
6				.0381	.0572	.0381	.0572
8	.0381	.0191	.0191				
9	.0381	.0191	.0381				
10	.0381	.0191	.0381				
11	.0572	.0381	.1143				
12	.0762	.0762	.1143				
13	.0572	.0572	.0953				
14	.0381	.0572	.0953				
15	.0572	.0572	.0762				
21				.0572	.0381	.0762	.0381
22				.0762	.0381	.0953	.0381
23				.0762	.0381	.0762	.0381
24					.0572	.0381	.0572
Max	.0762	.0762	.1143	.0762	.0572	.0953	.0572
Min	.0381	.0191	.0191	.0381	.0381	.0381	.0381
Avg	.0500	.0429	.0738	.0487	.0496	.0514	.0496

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 205 / 11 KV REST HOUSE Feeder SEPARATED GAOTHAN FEEDERS
Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.1143	.1143	.1143	.1334	.1524	.1524
2	.0953	.1143	.1143	.1143	.1334	.1524	.1524
3	.0953	.1143	.1143	.0953	.1334	.1334	.1524
4	.1334	.1143	.1143	.1143	.1334	.1524	.1905
5	.1334	.1334	.1334	.1715	.1905	.1715	.1905
6	.1715	.1905	.1715	.1905	.1905	.1905	.2096
7	.0953	.1334	.1334	.1715	.1905	.2096	.1905
8	.1524	.1524	.1524	.1524	.1715	.1715	.1715
9	.1524	.1715	.1524	.1905		.1524	.1715
10	.1334	.1524	.1524	.1905	.1715	.1524	.1715
11	.1143	.0953	.1143	.1143	.1334	.0953	.1143
12	.0762	.0762	.0762	.0953	.0953	.0953	.0953
13	.0953	.0762	.0762	.1143	.1905	.1715	.1143
14	.0762	.0762	.0953	.0953	.0953	.0953	.1143
15	.0762	.0762	.0953	.0953	.0953	.0953	.1143
16	.1143	.1143	.0953	.1143	.0762	.0953	.1143
17	.1143	.0953	.1143	.0953	.1143	.1143	.1334
18	.1143	.1143	.1143	.1334	.1715	.1143	.1334
19	.2096	.1905	.2096	.2096	.2286	.2096	.2477
20	.2096	.1905	.1905		.2477	.2286	.2477
21	.1715	.1905	.1715		.2096	.1905	.2286
22	.1334	.1334	.1524		.1715	.1715	.1905
23	.1143	.1143	.1334		.1715	.1524	.1715
24	.0953	.1143	.1143	.1143		.1524	.1524
Max	.2096	.1905	.2096	.2096	.2477	.2286	.2477
Min	.0762	.0762	.0762	.0953	.0762	.0953	.0953
Avg	.1239	.1270	.1294	.1343	.1568	.1508	.1635

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 206 / 11 KV SONI AG Feeder FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1143	.1524	.1524	.1524
2				.1143	.1524	.1715	.1524
3				.1143	.1524	.1715	.1524
4				.1143	.1524	.1905	.1524
5				.1143	.1524	.1905	.1524
6				.1143	.1715	.1905	.1715
8			.2286				
9		.0191	.2667				
10	.2858	.2667	.2858				
11	.381	.3048	.3429				
12	.4001	.3429	.3239				
13		.381	.3429				
14	.381	.381	.2858				
15	.3048	.3429	.2858				
21				.1143	.1334	.1524	.1524
22				.1715	.1524	.1715	.1524
23				.1715	.1524	.1524	.1524
24					.1524	.1524	.1524
Max	.4001	.381	.3429	.1715	.1715	.1905	.1715
Min	.2858	.0191	.2286	.1143	.1334	.1524	.1524
Avg	.3505	.2912	.2953	.1270	.1524	.1696	.1543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 207 / 11 KV Parsodi Gaothan SEPARATED GAOTHAN FEEDERS
Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0381	.0572	.0381	.0572	.0381
2	.0381	.0381	.0381	.0572	.0381	.0572	.0381
3	.0381	.0381	.0381	.0572	.0381	.0572	.0381
4	.0381	.0381	.0381	.0572	.0381	.0572	.0381
5	.0572	.0381	.0381	.0572	.0572	.0572	.0381
6	.0381	.0381	.0381	.0572	.0572	.0572	.0572
7	.0381	.0381	.0381	.0381	.0381	.0381	.0572
8	.0381	.0381	.0381	.0381	.0572	.0381	.0381
9	.0381	.0381	.0381	.0381		.0381	.0381
10	.0572	.0381	.0572	.0572	.0381	.0381	.0381
11	.0381	.0381	.0381	.0381	.0381	.0381	.0381
12	.0381	.0381	.0381	.0381	.0381	.0381	.0381
13	.0381	.0381	.0191	.0381	.0381	.0381	.0381
14	.0381	.0381	.0381	.0381	.0381	.0381	.0381
15	.0381	.0381	.0191	.0381	.0381	.0381	.0381
16	.0381	.0381	.0381	.0381	.0381	.0381	.0381
17	.0381	.0381	.0381	.0381	.0381	.0381	.0381
18	.0381	.0572	.0572	.0572	.0572	.0381	.0572
19	.1524	.0762	.0953	.0953	.0953	.0953	.1143
20	.0762	.0762	.0953	.0953	.0953	.1143	.0953
21	.0762	.0762	.0762	.0762	.0953	.0953	.0953
22	.0381	.0572	.0572	.0572	.0762	.0762	.0762
23	.0381	.0381	.0572	.0572	.0762	.0572	.0762
24	.0381	.0381	.0381	.0381	.0572	.0572	.0572
Max	.1524	.0762	.0953	.0953	.0953	.1143	.1143
Min	.0381	.0381	.0191	.0381	.0381	.0381	.0381
Avg	.0476	.0445	.0461	.0524	.0530	.0540	.0524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 208 / 11 KV Barwha Gaothan
(CHICHOLI Feeder KV- 11 /
OUTGOING

GAOTHAN FEEDER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0953	.0953	.0953	.1143	.0762
2	.0381	.0762	.0953	.0762	.0953	.1143	.0762
3	.0381	.0953	.0953	.0762	.0953	.1143	.0762
4	.0381	.0953	.0953	.0762	.0953	.0953	.0762
5	.0381	.0953	.0953	.0762	.0953	.0953	.0762
6	.0953	.0953	.0953	.0762	.0953	.0953	.0953
7	.0762	.0762	.0953	.0762	.0762	.0762	.0572
8	.0762	.0762	.0762	.0572	.0572	.0953	.0762
9	.0762	.0572	.0762	.0572		.0762	.0762
10	.0762	.0381	.0762	.0572	.0572	.0381	.0572
11	.0191	.0381	.0381	.0381	.0381	.0381	.0572
12	.0381	.0381	.0191	.0381		.0381	.0572
13	.0381	.0381	.0381	.0381		.0381	.0572
14	.0381	.0381	.0572	.0381	.0381	.0572	.0572
15	.0381	.0381	.0572	.0572	.0381	.0572	.0572
16	.0381	.0572	.0381	.0381	.0572	.0572	.0381
17	.0381	.0572	.0572	.0572	.0572	.0572	.0191
18	.0572	.0762	.0572	.0572	.1334	.0572	.0762
19	.1524	.1715	.1524	.1524	.1715	.1715	.1524
20	.1524	.1524	.1524	.1524	.1715	.1524	.1715
21	.1524	.1524	.1334	.1334	.1524	.1524	.1524
22	.1143	.1143	.1143	.0953	.1524	.0953	.1334
23	.0953	.1143	.0953	.0953	.1334	.0953	.1143
24	.0953	.0953	.0953	.0762	.0953	.1143	.0953
Max	.1524	.1715	.1524	.1524	.1715	.1715	.1715
Min	.0191	.0381	.0191	.0381	.0381	.0381	.0191
Avg	.0707	.0818	.0834	.0746	.0953	.0873	.0826

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 209 / 11 KV Soni Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1905	.2096	.1905	.2477	.1905
2	.1905	.1905	.1905	.2096	.1905	.2477	.1905
3	.1905	.1905	.1905	.1905	.1905	.2286	.1905
4	.1905	.1905	.1905	.1905	.1905	.2286	.1905
5	.1905	.1905	.1905	.2096	.2286	.2477	.1905
6	.1905	.2096	.2096	.1905	.2286	.2286	.1905
7	.1715	.1715	.1715	.1524	.1715	.1524	.1524
8	.1334	.1715	.1524	.1524	.1524	.1524	.1334
9	.1334	.1715	.1334	.1524	.1524	.1905	.1334
10	.1334	.1715	.1524	.3048	.1905	.1524	.1524
11	.2286	.2286	.2286	.3239	.2286	.1524	.2096
12	.2667	.2858	.1905	.3239	.2477	.1524	.2096
13	.2096	.1905	.1905	.1905	.2477	.1524	.2096
14	.2096	.2667	.2096	.1715	.3048	.1524	.2286
15	.2096	.2667	.2858	.1524	.2096	.1524	.2477
16	.2286	.1905	.2096	.1334	.2477	.1524	.2858
17	.2858	.1905	.2096	.2858	.2096	.1334	.2667
18	.3429	.2286	.362	.3429	.3429	.1715	.3239
19	.5144	.3429	.4954	.4572	.4191	.381	.4191
20	.362	.381	.381		.381	.381	.381
21	.3048	.3239	.3048	.3429	.3429	.3239	.3429
22	.2477	.2477	.2667	.2667	.2858	.2858	.3048
23	.2096	.2096	.2477	.2286	.2667	.2286	.2858
24	.1905	.1905	.1905	.2286	.2096	.2477	.2286
Max	.5144	.381	.4954	.4572	.4191	.381	.4191
Min	.1334	.1715	.1334	.1334	.1524	.1334	.1334
Avg	.2302	.2247	.2310	.2352	.2429	.2143	.2358

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 210 / TEMBHERI GAUTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0191	.0191	.0191	.0191
2	.0191	.0191	.0191	.0191	.0191	.0191	.0191
3	.0191	.0191	.0191	.0191	.0191	.0191	.0191
4	.0191	.0191	.0191	.0191	.0191	.0191	.0191
5	.0191	.0191	.0191	.0191	.0191	.0191	.0191
6	.0191	.0191	.0191	.0191	.0191	.0191	.0191
7	.0191	.0191	.0191	.0191	.0191	.0191	.0191
8	.0191	.0191	.0191	.0191	.0191	.0191	.0191
9	.0191	.0191	.0191	.0191	.0191	.0191	.0191
10	.0381	.0191	.0191	.0191	.0191	.0381	.0191
11	.0191	.1334	.0381	.0191	.0381	.0191	.0191
12	.0381	.1143	.0572	.0572	.0762	.0953	.0762
13	.0191	.1334	.0381	.1143	.0762	.0381	.0572
14	.0191	.0762	.0381	.0572	.0572	.0762	.0191
15	.0191	.0953	.1143	.0762	.0953	.0762	.0381
16	.0381	.0572	.0381	.0191	.0762	.0381	.1143
17	.0381	.0572	.0381	.0381	.0762	.0191	.0381
18	.0381	.0381	.0191	.0191	.1143	.0191	.0381
19	.0191	.0762	.0191	.0191	.0191	.0191	.0191
20	.0191	.0191	.0191	.0191	.0191	.0191	.0191
21	.0191	.0191	.0191	.0191	.0191	.0191	.0191
22	.0191	.0191	.0191	.0191	.0191	.0191	.0191
23	.0191	.0191	.0191	.0191	.0191	.0191	.0191
24	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Max	.0381	.1334	.1143	.1143	.1143	.0953	.1143
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0231	.0445	.0286	.0294	.0381	.0294	.0294

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064002 / 33 KV VIRLEE SUB STATION

Feeder No / Name : 201 / 11 KV VIRLEE AG FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.6562	.9374	.9998	1.0883
2				.6718	.9374	.9998	1.085
3				.6718	.9374	.9998	1.085
4				.6718	.953	.9998	1.0562
5				.7186	1.0467	.9998	1.0562
6				.828	1.1873	1.1717	1.247
8	.8573	.9175	.9231				
9	.8688	1.1142	1.2071				
10	1.073	1.1401	1.1683				
11	1.0898	1.1401	1.1363				
12	1.0753	1.1568	1.1363				
13	1.0814	1.1904	1.1203				
14	1.0814	1.1401	1.0753				
15	1.0486	1.1233	1.0155				
21				.8436	.8905	.9922	.9831
22				.9061	.9842	1.1012	1.0322
23				.9061	1.0279	1.1012	1.0978
24					.9061	1.012	1.1012
Max	1.0898	1.1904	1.2071	.9061	1.1873	1.1717	1.247
Min	.8573	.9175	.9231	.6562	.8905	.9922	.9831
Avg	1.0220	1.1153	1.0978	.7638	.9808	1.0377	1.0832

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064002 / 33 KV VIRLEE SUB STATION

Feeder No / Name : 202 / 11 KV GOURALA AG FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.6979	.9808	1.0374	1.0185
2				.7167	.9808	1.0269	1.0185
3				.7167	.9808	1.0374	.9997
4				.7167	.9709	1.0374	.9997
5				.7621	1.0374	1.0374	.9808
6				.8954	1.2637	1.2136	1.1317
8	.8865	.8589	1.0185				
9	.9242	.9335	1.1128				
10	.9808	1.0082	1.1317				
11	.9808	1.0829	1.1317				
12	.9619	1.0829	1.094				
13	.8299	1.1016	1.094				
14	.8299	1.0269	1.0562				
15		.9335	1.0374				
21				.8488	.9808	.8573	.8402
22				.9431	1.0562	1.0374	.8402
23				.9431	1.0374	1.0374	.8962
24					.9431	1.0374	1.0374
Max	.9808	1.1016	1.1317	.9431	1.2637	1.2136	1.1317
Min	.8299	.8589	1.0185	.6979	.9431	.8573	.8402
Avg	.9134	1.0036	1.0845	.8045	1.0232	1.0360	.9763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064002 / 33 KV VIRLEE SUB STATION

Feeder No / Name : 203 / 11 KV Kiramati AG Feeder FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2134	.2675	.2743				
2	.2134	.2675	.2743				
3	.2134	.2972	.2743				
4	.2134	.3048	.2743				
5	.2286	.3201	.3048				
6	.2743	.3353	.3437				
8				.4531	.5636	.7373	.7773
9				.4999	.6962	.7865	.8583
10				.5624	.7293	.8356	.8718
11				.5668	.6962	.9012	.8383
12				.5312	.7127	.8848	.8048
13				.5468	.7293	.8848	.8383
14				.578	.7293	.8848	.8718
15				.5937	.7459	.8684	.8383
21	.208	.2439	.2526				
22	.2229	.2743	.2606				
23	.2526	.2743	.2538				
24	.208	.2675	.2743	.2503			
Max	.2743	.3353	.3437	.5937	.7459	.9012	.8718
Min	.208	.2439	.2526	.2503	.5636	.7373	.7773
Avg	.2248	.2852	.2787	.5091	.7003	.8479	.8374

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064002 / 33 KV VIRLEE SUB STATION

Feeder No / Name : 204 / 11 KV Kiramti Gaothan

SEPARATED GAOTHAN FEEDERS

Feeder Feeder KV- 11 /
OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0377	.0566	.0566	.0566	.056	.0566
2	.0566	.0377	.0566	.0566	.056	.056	.0566
3	.0373	.0377	.0566	.0566	.056	.056	.0566
4	.0377	.0377	.0566	.0566	.056	.056	.0566
5	.0566	.0566	.0566	.0566	.0373	.0747	.0754
6	.0566	.0566	.0754	.0754	.0373	.056	.0754
7	.0566	.0566	.0373	.0566	.0373	.0373	.0566
8	.0377	.0377	.0377	.0377	.0373	.0373	.0377
9	.0377	.0377	.0377	.0377	.0373	.0377	.0377
10	.0187	.0377	.0377	.0187	.0373	.0377	.0377
11	.0377	.0377	.0377	.0373	.0373	.0377	.0377
12	.0377	.0189	.0189	.0373	.0187	.0377	.0377
13	.0373	.0189	.0189	.0373	.0187	.0189	.0377
14	.0189	.0189	.0185	.0373	.0187	.0189	.0377
15	.0189	.0189	.0177	.0373	.0373	.0189	.0377
16	.0189	.0189	.0189	.0373	.0373	.0377	.0377
17	.0189	.0189	.0377	.0373	.0373	.0189	.0377
18	.0377	.0566	.0754	.056	.0747	.0566	.0566
19	.0754	.3584	.0943	.0934	.0934	.0754	.0943
20	.0754	.0943	.0943	.0934	.0747	.0754	.0943
21	.0754	.0754	.0943	.0943	.0934	.0754	.0943
22	.0754	.0754	.0754	.0754	.0747	.0754	.0934
23	.0566	.0566	.0566	.0754	.056	.0566	.0754
24	.0566	.0566	.056	.0566	.0566	.056	.0566
Max	.0754	.3584	.0943	.0943	.0934	.0754	.0943
Min	.0187	.0189	.0177	.0187	.0187	.0189	.0377
Avg	.0455	.0566	.0510	.0548	.0491	.0485	.0573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064002 / 33 KV VIRLEE SUB STATION

Feeder No / Name : 205 / 11kv virli Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.1867	.2241	.2241	.2427	.2427	.2427
2	.1867	.168	.2241	.2241	.2241	.2427	.2427
3	.1867	.168	.2054	.2241	.2241	.2427	.2427
4	.1867	.1867	.2054	.2054	.2241	.2427	.2427
5	.2054	.1867	.2054	.2054	.2054	.2427	.2427
6	.2054	.2054	.2241	.2241	.1867	.2075	.2241
7	.1867	.168	.1867	.1867	.1867	.2054	.1867
8	.1494	.168	.168	.1867	.1867	.1867	.168
9	.2241	.1494	.1307	.1867	.0934	.1867	.1494
10	.168	.1494	.1867	.1867	.1867	.1867	.168
11	.1494	.1494	.2054	.1867	.2614	.1867	.168
12	.1494	.168	.2054	.1867	.2427	.1494	.1867
13	.1494	.168	.2054	.1867	.1867	.1494	.1867
14	.1867	.168	.2054	.1867	.1867	.168	.1867
15	.168	.1494	.2054	.1867	.1867	.1867	.168
16	.1867	.1494	.2427	.1867	.1867	.1494	.168
17	.1867	.2075	.2427	.2054	.1867	.1307	.1867
18	.2054	.2241	.2427	.2241	.1867	.2241	.2427
19	.2427	.3547	.3174	.2987	.3174	.3361	.3361
20	.2614	.2987	.2987	.2987	.3174	.3174	.3361
21	.2614	.2614	.2427	.2987	.2987	.3174	.3174
22	.2427	.2614	.2801	.2987	.2987	.2801	.2801
23	.2241	.2241	.2427	.2614	.2614	.2614	.2614
24	.2054	.1867	.2241	.2427	.2427	.2427	.2614
Max	.2614	.3547	.3174	.2987	.3174	.3361	.3361
Min	.1494	.1494	.1307	.1867	.0934	.1307	.1494
Avg	.1968	.1961	.2217	.2209	.2217	.2203	.2248

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064002 / 33 KV VIRLEE SUB STATION

Feeder No / Name : 206 / GAWARADA GAUTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1307	.1494	.1494	.3378	.168	.168
2	.1494	.112	.1494	.1494	.168	.168	.168
3	.1307	.112	.1494	.1494	.168	.168	.168
4	.1494	.1307	.1494	.1494	.168	.168	.168
5	.1494	.1494	.1494	.1494	.1494	.168	.168
6	.168	.168	.1867	.1867	.1307	.1494	.1867
7	.168	.1307	.1494	.1494	.1494	.1494	.112
8	.1307	.1307	.112	.1307	.112	.112	.112
9	.1307	.112	.0934	.0934	.112	.0934	.112
10	.0934	.0934	.0934	.0747	.1307	.0934	.112
11	.0747	.0747	.112	.0934	.1307	.0934	.112
12	.0934	.0747	.0934	.1132	.0934	.0934	.112
13	.112	.0747	.0934	.112	.0934	.112	.112
14	.0747	.0934	.0934	.1307	.112	.112	.112
15	.0747	.0934	.0934	.1307	.1307	.112	.112
16	.0747	.0934	.0934	.1307	.1494	.112	.1307
17	.112	.0934	.112	.1494	.1494	.0747	.1307
18	.1494	.1494	.1307	.168	.1867	.1494	.168
19	.1867	.2427	.2614	.2452	.2427	.2614	.2614
20	.2241	.2427	.2427	.2427	.2614	.2427	.2614
21	.2054	.2241	.2427	.4904	.2427	.2427	.2427
22	.1867	.1867	.1867	.4504	.2241	.2054	.2241
23	.1494	.1494	.168	.3753	.1867	.1867	.1867
24	.1307	.1494	.1494	.168	.1698	.168	.168
Max	.2241	.2427	.2614	.4904	.3378	.2614	.2614
Min	.0747	.0747	.0934	.0747	.0934	.0747	.112
Avg	.1362	.1338	.1439	.1826	.1666	.1501	.1587

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064012 / 33 KV BARWHA S/STN

Feeder No / Name : 201 / 11 KV Barwha Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1543	.1829				
2	.1372	.1543	.1829				
3	.1372	.1543	.1829				
4	.1372	.1543	.1829				
5	.1355	.1543	.1829				
6	.1677	.1677	.2134				
8				.2439	.3041	.2915	.144
9				.3353	.3681	.421	.3605
10				.3725	.3521	.4096	.4096
11				.3725	.3681	.4096	.426
12				.3725	.3841	.426	.426
13				.3681	.3841	.421	.426
14				.3201	.3521	.421	.4096
15				.2846	.3521	.4049	.426
21	.0926	.0762	.1204				
22	.1235	.1829	.1524				
23	.1389	.1829	.1524				
24	.1372	.1543	.1829	.1505			
Max	.1677	.1829	.2134	.3725	.3841	.426	.426
Min	.0926	.0762	.1204	.1505	.3041	.2915	.144
Avg	.1344	.1536	.1736	.3133	.3581	.4006	.3785

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064012 / 33 KV BARWHA S/STN

Feeder No / Name : 202 / 11 KV Murmadi AG Feeder FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.4374	.5155	.5121	.4744
2				.4531	.5218	.5121	.4744
3				.4531	.5218	.5121	.4687
4				.4531	.5376	.5121	.4687
5				.4687	.5218	.5121	.4687
6				.4902	.5376	.5441	.4999
8	.4641	.4321	.4801				
9	.4961	.3887	.5121				
10		.4001	.5155				
11	.4801	.4481	.5312				
12	.4784	.4801	.5535				
13	.4784	.4801	.5312				
14	.4843	.4801	.5312				
15	.4902	.4877	.5247				
21				.4531	.5182	.5182	.4999
22				.4531	.5506	.5121	.4999
23				.4843	.5182	.506	.4999
24					.5312	.5121	.4744
Max	.4961	.4877	.5535	.4902	.5506	.5441	.4999
Min	.4641	.3887	.4801	.4374	.5155	.506	.4687
Avg	.4817	.4496	.5224	.4607	.5274	.5153	.4829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064012 / 33 KV BARWHA S/STN

Feeder No / Name : 203 / 11 KV Chikana AG Feeder FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.8855	.9602	1.1523	1.0688
2				.9172	.9762	1.1523	1.0688
3				.9172	.9602	1.1523	1.0526
4				.9172	1.1203	1.1523	1.0688
5				.9172	1.1069	1.1523	1.012
6				.9172	1.1203	1.1523	1.0883
8	.8192	1.1174	1.1961				
9	.8421	1.166	1.2125				
10	.9231	1.1498	1.2163				
11	.9393	1.2289	1.2323				
12	1.1012	1.2616	1.2323				
13	1.085	1.2452	1.2483				
14	1.1363	1.2452	1.2793				
15	1.1523	1.2125	1.2651				
21				.9488	.9831	1.004	.9374
22				.9442	1.2125	1.0202	1.0311
23				.9602	1.2125	1.166	1.0311
24					.9602	1.1523	1.0688
Max	1.1523	1.2616	1.2793	.9602	1.2125	1.166	1.0883
Min	.8192	1.1174	1.1961	.8855	.9602	1.004	.9374
Avg	.9998	1.2033	1.2353	.9250	1.0612	1.1256	1.0428

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064012 / 33 KV BARWHA S/STN

Feeder No / Name : 204 / 11KVCHIKANA (GAOTHAN)

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905	.0905	.0732	.0895	.0895	.0914	.0934
2	.0905	.0905	.0732	.0895	.0905	.0914	.0934
3	.0905	.0905	.0732	.0905	.0905	.0914	.0934
4	.0905	.0905	.0732	.0905	.0905	.0914	.0934
5	.0914	.0905	.0732	.0905	.0867	.0914	.0934
6	.0914	.0905	.1097	.0924	.112	.0914	.0934
7	.0848	.0995	.1097	.0949	.1006	.1097	.0848
8	.056	.0716	.0914	.0819	.0724	.0732	.0701
9	.0716	.0819	.0732	.0848	.0732	.0732	.0732
10	.0848	.0648	.0791	.0838	.0716	.0732	.104
11	.0848	.0537	.0838	.0671	.0716	.0739	.0914
12	.0848	.0537	.0819	.0503	.0716	.0732	.0732
13	.0848	.0537	.0819	.0503	.0716	.0739	.0732
14	.0829	.0716	.081	.0503	.0895	.0655	.0914
15	.0829	.0537	.0772	.0429	.0895	.0655	.0914
16	.0995	.0716	.0732	.0429	.0895	.0848	.0914
17	.104	.1075	.0876	.0429	.0895	.0762	.0914
18	.1227	.1075	.0924	.0903	.1075	.1017	.1097
19	.168	.1791	.1646	.1612	.1829	.1612	.1646
20	.1478	.1886	.1646	.1612	.1886	.1629	.168
21	.1294	.1433	.1646	.1509	.1886	.128	.128
22	.1109	.0895	.1097	.132	.1886	.1132	.1097
23	.0914	.0895	.1075	.1132	.132	.0914	.0914
24	.0905	.0914	.0732	.1075	.0895	.1097	.0934
Max	.168	.1886	.1646	.1612	.1886	.1629	.168
Min	.056	.0537	.0732	.0429	.0716	.0655	.0701
Avg	.0969	.0923	.0947	.0896	.1053	.0941	.0984

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064012 / 33 KV BARWHA S/STN

Feeder No / Name : 205 / BARWHA GAOTHAN

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1867	.1867	.2241	.2263	.2241	.2427
2	.168	.1886	.1867	.2241	.2263	.1867	.2241
3	.168	.1886	.1867	.2241	.2263	.1867	.2241
4	.168	.1886	.1867	.2241	.2263	.1867	.2241
5	.1698	.1886	.1867	.2241	.1867	.1867	.2195
6	.1886	.1886	.2054	.2075	.2075	.1867	.2012
7	.1867	.1867	.1867	.168	.1478	.1867	.1867
8	.1646	.168	.168	.1494	.1478	.168	.1663
9	.1715	.1478	.1494	.1494	.1494	.1494	.2012
10	.1509	.1307	.1848	.1448	.1494	.1307	.2328
11	.1509	.168	.1848	.1478	.1494	.168	.1867
12	.1509	.1698	.1612	.1307	.1494	.168	.168
13	.1509	.1494	.1629	.132	.168	.1867	.1494
14	.132	.1307	.1612	.1294	.168	.2033	.168
15	.1143	.1494	.1907	.1294	.168	.2054	.168
16	.1109	.1494	.1307	.1463	.168	.1867	.1867
17	.1063	.168	.1478	.1448	.168	.1646	.2054
18	.1772	.2075	.1991	.1867	.1867	.2195	.2241
19	.3584	.3772	.3772	.3395	.3772	.3584	.3361
20	.3772	.3395	.3772	.3584	.3772	.3584	.3772
21	.3018	.3018	.3206	.3206	.3772	.3395	.3361
22	.1886	.2263	.2667	.3018	.3772	.2926	.2987
23	.1867	.2075	.2641	.2641	.3018	.2241	.2614
24	.168	.1867	.1867	.2614	.2452	.2614	.2427
Max	.3772	.3772	.3772	.3584	.3772	.3584	.3772
Min	.1063	.1307	.1307	.1294	.1478	.1307	.1494
Avg	.1832	.1956	.2066	.2055	.2198	.2137	.2263

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064012 / 33 KV BARWHA S/STN

Feeder No / Name : 206 / Murmadi Gaothaon

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0914	.0934	.0934	.0934	.0934	.0934
2	.0914	.0934	.0934	.0934	.0934	.0934	.0934
3	.0914	.0943	.0934	.0934	.0934	.0934	.0934
4	.0914	.0943	.0934	.0934	.0934	.0934	.0934
5	.0924	.0943	.0934	.0934	.0934	.0934	.0739
6	.0747	.0943	.112	.1109	.0739	.0934	.0934
7	.0732	.1109	.0934	.0739	.0747	.0747	.0732
8	.056	.0739	.056	.0924	.0554	.0747	.0732
9	.0739	.0554	.056	.0934	.0549	.0747	.0747
10	.0739	.056	.0739	.0732	.056	.0543	.0924
11	.0739	.056	.0554	.0732	.056	.0537	.056
12	.0739	.056	.0934	.0554	.056	.0549	.056
13	.0739	.056	.0924	.0554	.056	.0739	.056
14	.0747	.056	.0724	.0554	.056	.0739	.056
15	.0747	.056	.0924	.056	.056	.0739	.056
16	.0739	.056	.0747	.056	.056	.0549	.056
17	.0739	.056	.056	.0554	.056	.0554	.056
18	.0754	.1132	.0934	.0924	.112	.0747	.056
19	.1886	.1698	.1886	.1494	.1886	.1829	.1867
20	.1698	.1886	.1698	.1509	.1698	.1698	.1867
21	.1109	.1698		.1698	.1698	.1494	.168
22	.1109	.1132	.0924	.132	.132	.1294	.1307
23	.0924	.0943	.112	.1509	.1132	.1294	.112
24	.0914	.0914	.0934	.112	.0934	.0934	.112
Max	.1886	.1886	.1886	.1698	.1886	.1829	.1867
Min	.056	.0554	.0554	.0554	.0549	.0537	.056
Avg	.0903	.0913	.0932	.0948	.0897	.0920	.0916

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064017 / PARSODI

Feeder No / Name : 201 / kudegaon

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4144	.4572	.5716	.7145	.7716	.9288	.8859
2	.4144	.4572	.5716	.7716	.7716	.9431	.8859
3	.4144	.4572	.5716	.7716	.7716	.9431	.8859
4	.4144	.4572	.5716	.7716	.7716	.9431	.8859
5	.4572	.4858	.5716	.8002	.8288	.9431	.9717
6	.5716	.6144	.6859	.8573	.9145	1.0288	1.0145
8	.8431	.8573	.8716	.7716	.7145	.7716	.8145
9	.9717	1.0431	1.0288	.9002	.8288	.8859	.9002
10	.9717	1.0288	1.1431	.9717	.8573	.9288	.8859
11	.9717	1.0002	1.1717	.9717	.8716	.9145	.9002
12	.9717	.9717	1.186	.9431	.8288	.9145	.9145
13	.9431	.9859	1.1145	.9002	.8431	.8859	.9002
14	.9431	.9431	1.086	.8145	.8716	.9002	.9288
15	.9002	.9145	1.086	.8716	.8573	.8859	.9574
21	.4001	.5287	.4572	.6001	.6859	.7716	.7287
22	.4572	.5573	.4715	.7716	.8573	.9288	.8573
23	.4572	.5716	.9002	.7716	.8573	.9145	.8573
24	.4144	.443	.5716	.4715	.7716	.9288	.8859
Max	.9717	1.0431	1.186	.9717	.9145	1.0288	1.0145
Min	.4001	.443	.4572	.4715	.6859	.7716	.7287
Avg	.6629	.7097	.8129	.8026	.8153	.9089	.8923

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064017 / PARSODI

Feeder No / Name : 203 / 11 KV KUDEGAON GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1663	.1848	.2033	.2218	.2218	.2402	.2402
2	.1663	.1848	.2033	.2218	.2218	.2218	.2402
3	.1663	.1848	.2033	.2218	.2218	.2218	.2402
4	.1663	.1848	.2033	.2218	.2033	.2218	.2218
5	.1848	.1848	.197	.2402	.2033	.2218	.2218
6	.2218	.2402	.2402	.2772	.2402	.2402	.2402
7	.2033	.1663	.1848	.1848	.2033	.1848	.1848
8	.1663	.1478	.1294	.1848	.1848	.1478	.1478
9	.1478	.1478	.1478	.1848	.1478	.1478	.1294
10	.1294	.1478	.1848	.1478	.1478	.1478	.1109
11	.168	.1109	.1848	.1663	.1663	.1294	.1294
12	.1294	.1109	.1848	.1294	.1294	.1478	.1478
13	.1109	.0924	.1848	.1294	.2218	.1478	.1294
14	.1478	.1294	.1663	.1663	.1848	.1494	.1478
15	.1478	.1478	.1294	.2033	.2033	.1478	.1478
16	.1294	.1478	.1663	.2241	.1848	.1294	.1478
17	.1478	.1478	.1478	.1848	.1848	.1109	.1478
18	.2033	.2218	.2402	.2218	.2402	.1848	.2033
19	.3696	.3881	.3881	.3696	.4066	.3696	.4251
20	.3696	.3696	.3326	.3881	.3881	.3881	.4251
21	.3142	.2957	.3326	.3881	.3696	.3696	.3881
22	.2218	.2218	.2772	.2402	.3511	.2957	.3326
23	.1848	.2033	.2427	.2402	.2772	.2587	.2772
24	.1867	.1848	.2033	.2218	.2218	.2587	.2402
Max	.3696	.3881	.3881	.3881	.4066	.3881	.4251
Min	.1109	.0924	.1294	.1294	.1294	.1109	.1109
Avg	.1896	.1894	.2116	.2242	.2302	.2118	.2194

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064025 / 33 KV MASAL SUB STATION

Feeder No / Name : 201 / 11 KV DHOLSAR FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1635	.1783	.1905	.2667	.2229	.2439
2	.1143	.1635	.1783	.1715	.2477	.2229	.2378
3	.1143	.1614	.1783	.1715	.2477	.2229	.2526
4	.1143	.1614	.1806	.1715	.2477	.2229	.2526
5	.1334	.1614	.1806	.1905	.2667	.2229	.2675
6	.1334	.1656	.1806	.1905	.2667	.2229	.2675
7	.1524	.1593	.176	.2286	.3048	.2378	.2559
8	.1715	.1858	.2134	.2096	.2667	.2526	.2347
9	.1905	.1907	.2347	.2667	.3239	.2824	.2347
10	.176	.2027	.2858	.3048	.2494	.2972	.362
11	.1692	.2027	.2667	.3048	.2462	.2934	.381
12	.2	.1858	.2858	.2858	.2256	.3081	.3429
13	.2143	.2	.2858	.2858	.2606	.3185	.3429
14	.141	.1907	.2667	.3429	.2934	.3185	.362
15	.1509	.1932	.3048	.3239	.2934	.2896	.362
16	.1783	.1932	.3048	.3429	.2572	.2751	.381
17	.16		.3239	.3429	.2606	.2824	.4191
18	.1882	.2	.2858	.3429	.2641	.2709	.4191
19	.1829	.1882	.2477	.3048	.2709	.286	.4001
20	.1829	.1957	.2096	.2858	.2559	.2896	.381
21	.1524	.1957	.2096	.2858	.2559	.2743	.381
22	.1656	.1829	.1905	.2858	.2559	.2591	.381
23	.1656	.1829	.1905	.2858	.2378	.2439	.381
24	.1334	.1635	.1783	.1905	.2858	.2229	.2286
Max	.2143	.2027	.3239	.3429	.3239	.3185	.4191
Min	.1143	.1593	.176	.1715	.2256	.2229	.2286
Avg	.1591	.1822	.2307	.2628	.2646	.2642	.3238

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064025 / 33 KV MASAL SUB STATION

Feeder No / Name : 202 / 11 KV MASAL FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478	.7621	.8002	.9145	.9907	1.0185	1.0374
2	.6478		.8002	.9145	.9526	.9808	.9997
3	.6287	.743	.8002	.8954	.9145	.9808	.9709
4	.6287	.724	.8002	.8573	.9335	.9808	.9896
5	.6478	.6767	.8002	.8764	.9335	.9808	1.0082
6	.6287	.7049	.8002	.8573	.8954	.9808	1.0082
7	.6859	.7545	.8676	.8573	.9717	1.0562	1.0082
8	.7049	.8775	.9242	.8383	.9526	1.1203	1.1458
9	.8383	.8676	.9431	1.086	1.105	1.2883	1.1827
10	.811	.7655	.9907	.9907	1.0642	1.2883	.8383
11	.8413	.811	.9907	1.105	1.0642	1.2752	1.2574
12	.8686	.9054	1.0669	1.0288	1.0456	1.3121	1.2574
13	.8865	.8676	1.0288	.9526	1.0829	1.3352	1.2765
14	.7842	.8488	1.0288	1.0288	1.1203	1.3169	1.2193
15	.7842	.8865	1.0098	1.0288	1.1576	1.2803	1.2955
16	.8589	.9149	1.0098	1.0669	1.1458	1.2437	1.3527
17	.8686	.9242	1.0479	1.0669	1.1458	1.2752	1.3336
18	.8676	.9431	.9907	1.0288	1.1389	1.2197	1.3336
19	.8954	.9431	1.086	1.1241	1.1576	1.1949	1.3908
20	.8573	.9619	1.0288	1.105	1.1694	1.2449	1.3527
21	.8573	.9526	1.0098	1.086	1.1317	1.2071	1.3146
22	.7842	.9145	1.0098	1.0669	1.094	1.1883	1.2955
23	.7733	.8764	.9907	1.0479	1.0562	1.1317	1.2765
24	.6668	.7621	.8488	.9717	1.0288	1.0185	1.0751
Max	.8954	.9619	1.086	1.1241	1.1694	1.3352	1.3908
Min	.6287	.6767	.8002	.8383	.8954	.9808	.8383
Avg	.7693	.8430	.9448	.9915	1.0522	1.1633	1.1758

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064025 / 33 KV MASAL SUB STATION

Feeder No / Name : 203 / 11 KV BELATHI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.096	.1027				
2	.0953	.0812	.1027				
3	.0953	.0812	.1027				
4	.0953	.08	.1027				
5	.1143	.0846	.1174				
6	.1143	.0974	.1174				
8				.1334	.1524	.1174	.1174
9				.1524	.1905	.132	.1174
10				.1524	.1303	.132	.1524
11				.1524	.1158	.1337	.1715
12				.1524	.1128	.1337	.1905
13				.1524	.1128	.132	.1715
14				.1524	.1143	.132	.1334
15				.1524	.1014	.132	.1334
20	.0834						
21	.0834	.0714	.0953				
22	.1	.1	.1143				
23	.0987	.0987	.1143				
24	.0953	.096	.0974	.1143			
Max	.1143	.1	.1174	.1524	.1905	.1337	.1905
Min	.0834	.0714	.0953	.1143	.1014	.1174	.1174
Avg	.0973	.0887	.1067	.1461	.1288	.1306	.1484

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064025 / 33 KV MASAL SUB STATION

Feeder No / Name : 204 / 11 KV Tai Gaothan Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0943	.112	.1334	.1143	.1307	.1494
2	.0953	.0943	.112	.1143	.1143	.1307	.1494
3	.0953	.0943	.1307	.1143	.1143	.1307	.1494
4	.0953	.0943	.1307	.1143	.1143	.1307	.1307
5	.1143	.0914	.1307	.1334	.1334	.1307	.1307
6	.1334	.1334	.1307	.1334	.1334	.132	.1494
7	.1143	.0934	.1307	.0953	.1143	.1307	.112
8	.0953	.0924	.112	.0762	.0953	.112	.112
9	.1143	.0934	.0914	.0762	.1143	.112	.112
10	.0924	.1307	.0953	.0953	.1109	.112	.0953
11	.0924	.112	.1334	.1143	.0924	.112	.1143
12	.0934	.0934	.0762	.0572	.0732	.112	.2096
13	.1109	.0934	.0762	.0762	.0732	.0924	.1524
14	.112	.0739	.1334	.0762	.0914	.0924	.1524
15	.1463	.0924	.0762	.0762	.0914	.0924	.1905
16	.0867	.0924	.0762	.0572	.0914	.0943	.1334
17	.1097	.1109	.0762	.0762	.1267	.0895	.1524
18	.1086	.1448	.1143	.1143	.1267	.1829	.1334
19	.2477	.2054	.2477	.2477	.2241	.2241	.2858
20	.2477	.2452	.2477	.2477	.2614	.2641	.2667
21	.1848	.1886	.2286	.2096	.2263	.2241	.2477
22	.1307	.1509	.1715	.1715	.1886	.1867	.1905
23	.112	.1307	.1524	.1524	.1509	.168	.1905
24	.1143	.0943	.1097	.1334	.1334	.1494	.1494
Max	.2477	.2452	.2477	.2477	.2614	.2641	.2858
Min	.0867	.0739	.0762	.0572	.0732	.0895	.0953
Avg	.1226	.1183	.1290	.1207	.1296	.1390	.1608

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 067017 / 132 KV Lakhandur Sub-
Station

Feeder No / Name : 402 / Parsodi

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2574		1.6575	2.9721	3.658	4.2295	4.1724
2	1.2574	1.3717	1.6575	3.0293	3.658	4.2295	4.1724
3	1.2003	1.3717	1.6004	3.0293	3.6008	4.1152	4.1152
4	1.2003	1.3717	1.6004	3.0293	3.6008	4.1152	4.0581
5	1.2574	1.4289	1.6575	3.1436	3.658	4.1724	4.1152
6	1.7718	.9717	1.8861	3.5437	4.2295	4.6868	4.5153
7	.5716	.5716	.5716	.5716	.5716	.9717	.5716
8	3.3722	3.4294	3.8295	2.0005	2.0005	2.3434	2.4006
9	3.7723	4.0009	4.2295	2.1719	2.2862	2.5149	2.6863
10	3.8295	3.8866	4.4582	2.6292	2.4006	2.5149	2.5149
11	3.8295	4.0009	4.401	2.4006	2.4006	2.6292	2.5149
12	3.8866	2.7435	4.401	2.3434	2.5149	2.7435	2.572
13	3.658	3.8866	4.3439	2.2862	2.572	2.6292	2.572
14	3.658	3.7723	4.2295	2.2291	2.4577	2.6292	2.6863
15	2.8578	3.5437	4.1152	2.4006	2.4577	2.572	2.6292
16	.4001	.4001	.4572	.5144	.5144	.4001	.4572
17	.3429	.4572	.5144	.5144	.5144	.4001	.5144
18	.6859	.6287	.6287	.6287	.6287	.9717	.6287
19	.9717	1.086	1.086	.9717	1.086	1.086	1.1431
20	1.2574	.9717	1.0288	1.0288	1.086	1.0288	1.086
21	1.6004	1.7147	1.7718	3.3722	3.8295	3.0293	3.9438
22	1.5432	1.7718	1.6575	3.8866	4.401	4.4582	4.1724
23	1.4289	1.6575	1.6004	3.7151	4.2295	4.401	4.1152
24	2.8578	1.3717	1.6004	1.6004	3.7151	4.2867	4.401
Max	3.8866	4.0009	4.4582	3.8866	4.401	4.6868	4.5153
Min	.3429	.4001	.4572	.5144	.5144	.4001	.4572
Avg	2.0195	2.0179	2.291	2.2505	2.5863	2.7983	2.7816

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 067017 / 132 KV Lakhandur Sub-
Station

Feeder No / Name : 403 / Lakhandur

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2574	1.2574	1.3717	.8573	.9717	1.086	1.0288
2	1.2003	1.3146	1.3717	.8573	.9717	1.0288	1.0288
3	1.2003	1.2574	1.3717	.8573	.9145	1.0288	.9717
4	1.2003	1.2574	1.3717	.8002	.9717	1.0288	.9717
5	1.2003	1.3146	1.3717	.8573	.9145	.9717	.9717
6	1.4861	.9717	1.7147	.9145	.8573	1.086	1.0288
7	.6859	.6859	.743	.743	.743	.6859	.8002
8	.9145	.743	.9145	1.7718	2.0005	2.0576	2.1148
9	.743	.8002	1.0288	1.9433	1.6575	2.3434	2.3434
10	.9717	1.0288	.6287	2.2862	1.7718	2.0576	2.1719
11	1.2574	1.1431	1.1431	2.2862	2.0005	2.0576	2.2862
12	1.086	1.2574	1.086	2.2862	2.2291	2.2862	2.2291
13	1.0288	1.2003	1.086	2.2291	2.1719	2.2862	2.5149
14	1.0288	1.2003	.9717	2.1148	2.2291	2.2291	2.4577
15	1.0288	1.086	1.2003	1.7147	2.1719	2.1719	2.4577
16	.743	.6859	.743	.6287	.9717	.8002	1.086
17	.9145	.743	.743	.743	.9717	.6287	.9717
18	1.0288	.9145	.9717	.8573	1.1431	.8573	1.1431
19	1.3146	1.3146	1.3717	1.3717	1.3717	1.2574	1.5432
20	1.3717	1.1431	1.2003	1.2574	1.3146	1.2574	1.4289
21	1.4861	1.5432	1.4861	1.2003	1.3146	1.3146	1.4289
22	1.4289	1.6004	1.4289	1.086	1.2574	1.2003	1.3146
23	1.3717	1.3717	1.3717	1.0288	1.1431	1.086	1.2003
24	1.2574	1.3146	1.4861	1.3146	.9717	1.086	1.0288
Max	1.4861	1.6004	1.7147	2.2862	2.2291	2.3434	2.5149
Min	.6859	.6859	.6287	.6287	.743	.6287	.8002
Avg	1.1336	1.1312	1.1741	1.3336	1.3765	1.4122	1.5218

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 067017 / 132 KV Lakhandur Sub-
Station

Feeder No / Name : 404 / Barwa

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4572	.5716	2.0576	2.2862	2.3434	2.1719
2	.5144	.4572	.5716	2.0576	2.2862	2.2862	2.1148
3	.4572	.4572	.5716	2.0576	2.2291	2.2862	2.1148
4	.4572	.4572	.5716	2.0005	2.2291	2.2862	2.1148
5	.4572	.4572	.5716	2.0005	2.2291	2.2291	2.1719
6	.5144	.4001	.6287	2.0005	2.2291	2.2291	2.1719
7	.3429	.3429	.3429	.3429	.2858	.3429	.3429
8	1.7718	2.0576	2.2291	.5716	.6287	.6287	.5716
9	1.829	1.6004	2.2862	.743	.6859	.743	.5144
10	1.9433	2.1148	2.5149	.743	.6859	.743	.743
11	1.8861	2.1719	2.5149	.743	.6859	.743	.743
12	2.0576	2.1719	2.5149	.6859	.6859	.743	.6859
13	2.1719	2.1148	2.572	.6287	.6287	.743	.6859
14	2.1719	2.1719	2.572	.6287	.6859	.743	.6859
15	2.1148	2.1719	.5144	.3429	.6859	.743	.6859
16	.1715	.2858	.2286	.2858	.2286	.2858	.2858
17	.2286	.4572	.1715	.3429	.2858	.2858	.3429
18	.4001	.4001	.3429	.3429	.3429	.4001	.3429
19	.6287	.6859	.6859	.6287	.6859	.6287	.6859
20	.6287	.6859	.6287	.6287	.6859	.6287	.6859
21	.6287	.6859	.6859	2.2862	2.4006	2.2862	2.2862
22		.6287	.5716	2.4006	2.4577	2.2862	2.2862
23	.5144	.5716	.6287	2.3434	2.4006	2.2291	2.2862
24	.4572	.5144	.5716	.5716	2.2862	2.572	2.1719
Max	2.1719	2.1719	2.572	2.4006	2.4577	2.572	2.2862
Min	.1715	.2858	.1715	.2858	.2286	.2858	.2858
Avg	.9915	1.0217	1.0860	1.1431	1.2884	1.3098	1.2455

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 067017 / 132 KV Lakhandur Sub-
StationFeeder No / Name : 405 / 33 KV KESHORI FROM NON SHEDDABLE EXPRESS HV FEEDERS
LAKHANDUR Feeder KV- 33 / (CONTINUOUS PROCESS)(NO STAGGERING)
INCOMING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8006	1.3146	3.3722	3.3722	3.2579	3.4294	3.6008
2	2.8006	1.9433	3.3722	3.315	3.2007	3.3722	3.5437
3	2.8578	1.9433	3.4294	3.315	3.1436	3.315	3.5437
4	2.8578	2.0005	3.4294	3.315	3.1436	3.315	3.5437
5	2.8578	2.0005	3.4294	3.315	3.1436	3.2579	3.4865
6	3.0293	2.7435	3.6008	3.4294	3.2579	3.4294	3.7151
7	3.1436	3.4865	3.7151	3.5437	3.6008	3.7151	3.8866
8	3.658	3.8866	3.4294	3.7723	4.0009	4.0009	4.2295
9	3.8866	4.3439	3.5437	4.2295	3.6008	4.0009	4.6868
10	3.6008	4.3439	3.6008	4.2867	4.1724	4.1724	4.5725
11	4.1724	3.5437	4.3439	4.3439	4.1724	4.2867	4.7439
12	4.2295	4.1724	4.5725	4.4582	4.2867	4.5725	4.8011
13	4.4582	4.401	4.6868	4.5153	4.5153	4.4582	4.8011
14	4.5153	4.4582	4.5153	4.9726	3.658	4.5725	4.9154
15	4.401	4.5153	4.401	4.5153	4.5153	4.5153	4.9154
16	4.2867	4.4582	4.401	4.401	4.4582	4.3439	4.8011
17	4.2867	4.2867	4.2867	4.3439	4.401	4.401	4.8583
18	4.1152	4.2867	4.5153	4.1724	4.3439	4.5153	4.8583
19	4.2295	4.5153	4.3439	3.7151	4.6296	4.6296	4.8583
20	4.0581	4.3439	4.2295	4.0009	4.5153	4.4582	4.8583
21	3.8866	4.0009	3.8295	3.7723	4.1152	4.2295	4.5725
22	3.5437	3.7151	3.6008	3.4865	3.7151	3.9438	4.1724
23	2.8578	3.4865	3.4865	3.315	3.5437	3.7151	3.9438
24	2.8578	3.2579	3.3722	3.3722	3.2579	3.4865	3.658
Max	4.5153	4.5153	4.6868	4.9726	4.6296	4.6296	4.9154
Min	2.8006	1.3146	3.3722	3.315	3.1436	3.2579	3.4865
Avg	3.6413	3.5604	3.8961	3.8866	3.8604	4.0057	4.3153

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064008 / 33/11 KV PALANDUR S/s

Feeder No / Name : 201 / 11 KV PALANDUR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7108	.7108	.7455	.1907	.1734	.1907	.1907
2	.6935	.7108	.7455	.1734	.1734	.156	.1907
3	.6935	.7282	.7802	.1734	.1734	.156	.1734
4	.7108	.7282	.7802	.1734	.1734	.1214	.1734
5	.7455	.7455	.7628	.1734	.1734	.1387	.1734
6	.7802	.7455	.7628	.1734	.1734	.156	.1753
7	.156	.4334	.1387	.1387	.156	.156	.1578
8	.1214	.1214	.1214	.7975	.8149	.3121	.7975
9	.1214	.156	.1387	.8842	.9015	.6935	.7108
10	.1214		.1387	.8842	.9882	.8322	.8669
11	.1214	.108	.1387	.9015	.9015	.9189	.8669
12	.1214	.1214	.1387	.9189	.9015	.9015	.9015
13	.1214	.1387	.1387	.9362	.9536	.9015	.9015
14	.1214	.1214	.1387	.9189	.8669	.8669	.8842
15	.104	.1214	.1387	.8495	.9015	.9015	.8322
16	.104	.1214	.1387	.1214	.1387	.1214	.156
17	.104	.1214	.1387	.1214	.1387	.1387	.1387
18	.1734	.1387	.1734	.2254	.1734	.156	.156
19	.2601	.2601	.2601	.2601	.2774	.2572	.2601
20	.2601	.2601	.2601	.2774	.2774	.2601	.2774
21	.8149	.7802	.2601	.2601	.2601	.2601	.3121
22	.7975	.7628	.2254	.208	.2254	.2254	.8669
23	.7802	.7455	.1907	.1907	.1734	.208	.8495
24	.7108	.7628	.7628	.1907	.1907	.1907	.1907
Max	.8149	.7802	.7802	.9362	.9882	.9189	.9015
Min	.104	.108	.1214	.1214	.1387	.1214	.1387
Avg	.3937	.4193	.3424	.4226	.4284	.3842	.4668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064008 / 33/11 KV PALANDUR S/s

Feeder No / Name : 202 / 11 KV KHARASHI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1174	.0838	.1174	1.4251	1.4251	1.3413	1.5257
2	.1006	.0671	.1006	1.4251	1.4251	1.3748	1.5089
3	.1006	.0671	.0838	1.4251	1.4251	1.3748	1.4754
4	.1174	.0838	.0838	1.4251	1.4251	1.4251	1.4754
5	.1174	.1006	.1006	1.4419	1.4251	1.4251	1.4419
6	.1174	.1006	.1006	1.4419	1.4251	1.4251	1.4419
7	.1006	.0838	.0838	.1006	.0838	.1006	.0838
8	1.6095	1.6095	1.5592	.0838	.1006	.0838	.0838
9	1.6933	1.6598	1.6766	.0838	.1006	.0838	.0838
10	1.7436	1.6766	1.7101	.0838	.1006	.0838	.0838
11	1.7436	1.7269	1.6933	.1006	.0838	.0838	.0838
12	1.7604	1.7604	1.6933	.1006	.0838	.0838	.0838
13	1.7436	1.7939	1.7269	.1006	.0838	.0838	.0838
14	1.7269	1.7772	1.7436	.1006	.0671	.0838	.1006
15	1.6263	1.7772	1.6933	.0838	.0671	.0838	.1006
16	.0838	.0671	.0838	.0838	.0671	.0838	.1174
17	.0671	.0671	.0671	.0838	.0838	.0838	.1006
18	.1341	.1006	.1006	.1174	.1174	.1006	.1006
19	.1677	.1844	.1844	.1844	.1677	.1844	.2012
20	.1677	.1844	.1844	.1844	.1677	.1844	.2012
21	.1509	.1677	1.4251	1.4083	1.3245	1.4419	.1844
22	.1174	.1174	1.4754	1.4586	1.4251	1.5424	.1677
23	.1006	.1174	1.4586	1.4419	1.3748	1.5424	.1509
24	.1174	.0838	.1174	1.4419	1.4419	1.3413	1.5257
Max	1.7604	1.7939	1.7436	1.4586	1.4419	1.5424	1.5257
Min	.0671	.0671	.0671	.0838	.0671	.0838	.0838
Avg	.6469	.6441	.8027	.6595	.6455	.6518	.5169

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064008 / 33/11 KV PALANDUR S/s

Feeder No / Name : 203 / 11 KV GONDEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1326	.0983	.1147	1.6876	1.6876	1.8861	1.5524
2	.116	.0983	.1147	1.6876	1.6712	1.8861	1.5524
3	.116	.0819	.1311	1.6876	1.6712	1.9805	1.5524
4	.116	.0819	.1311	1.6712	1.6876	1.9805	1.5684
5	.1326	.1147	.1475	1.6712	1.704	2.037	1.5684
6	.1326	.1311	.1475	1.6712	1.7532	2.037	1.5684
7	.116	.1147	.1311	.0983	.132	.132	.112
8	1.704	1.7695	1.704	.0983	.132	.1132	.132
9	1.7695	1.8679	1.7204	.1147	.132	.1132	.132
10	1.7695	1.8023	1.7532	.1147	.1132	.1132	.1132
11	1.7532	1.8187	1.8023	.0983	.0943	.1132	.096
12	1.7859	1.8351	1.8023	.0983	.1132	.1132	.096
13	1.7368	1.7532	1.8023	.0983	.1132	.1132	.08
14	1.7368	1.704	1.7695	.0983	.1132	.1132	.096
15	1.7695	1.8023	1.7204	.0983	.1132	.1143	.096
16	.1147	.0819	.0819	.0983	.0943	.1143	.1132
17	.0819	.0819	.0819	.1147	.0943	.0754	.1132
18	.2294	.1147	.1311	.1174	.1886	.132	.1132
19	.2785	.2785	.2949	.2622	.3018	.3395	.3206
20	.2785	.2785	.2949	.2949	.3018	.3584	.3395
21	.2458	.2458	1.8187	1.8679	1.905	1.9616	.3206
22	.1475	.1638	1.7532	1.7532	2.0748	1.6385	.2452
23	.1147	.1311	1.704	1.704	2.0748	1.5708	.2075
24	.1326	.1147	.1311	1.704	1.6876	1.9616	1.5524
Max	1.7859	1.8679	1.8187	1.8679	2.0748	2.037	1.5684
Min	.0819	.0819	.0819	.0983	.0943	.0754	.08
Avg	.6879	.6902	.8868	.7879	.8314	.8749	.5684

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064008 / 33/11 KV PALANDUR S/s

Feeder No / Name : 204 / 11 KV MURMADI TUPKAR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4074	1.2967	1.3283				
2	1.4074	1.2967	1.3283				
3	1.4074	1.2651					
4	1.4232	1.2651	1.2809				
5	1.4232	1.3916	1.2651				
6	1.4548	1.4074	1.2651				
8				1.4563	1.5249	1.5249	1.4251
9				1.576	1.6078	1.4918	1.4737
10				1.5424	1.6409	1.5083	.9231
11				1.5729	1.6575	1.5249	1.4575
12				1.5729		1.5249	1.4575
13				1.5238	1.6741	1.5238	1.5546
14				1.5402	1.6575	1.5384	1.4575
15				1.5238	1.6575	1.5074	1.4737
21		1.3283					1.3279
22	1.4074	1.3125					1.3603
23	1.2651	1.3283					1.3927
24	1.4074	1.3283	1.3441				
Max	1.4548	1.4074	1.3441	1.576	1.6741	1.5384	1.5546
Min	1.2651	1.2651	1.2651	1.4563	1.5249	1.4918	.9231
Avg	1.4004	1.322	1.3020	1.5385	1.6315	1.5181	1.3912

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064008 / 33/11 KV PALANDUR S/s

Feeder No / Name : 205 / 11 KV MURMADI GAOTHON

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4435	.4805	.4251	.5544	.5359	.4805	.6283
2	.4251	.4805	.4251	.5359	.5359	.4805	.6283
3	.4251	.3881	.4435	.5359	.5359	.4435	.6099
4	.4435	.3881	.4435	.5359	.5201	.4435	.6099
5	.4435	.4066	.462	.5359	.5544	.462	.6099
6	.4805	.3881	.4805	.5359	.5544	.5359	
7	.462	.462	.4435	.462	.5175	.4805	.4805
8	.4805	.4066	.462	.4805	.499	.4805	.4805
9	.5175	.4805	.4435	.499	.5359	.3696	.462
10	.4805	.499	.4435	.5175	.5544	.4251	.462
11	.5544	.4805	.462	.499	.5544	.4435	.4805
12	.5914	.4066	.462	.5914	.4475	.462	.4805
13	.4805	.4251	.462	.462	.5359	.462	.4805
14	.3696	.4251	.4805	.4435	.3696	.4805	.462
15	.4435	.4251	.4805	.5359	.4435	.5544	.5175
16	.3881	.4066	.5359	.4805	.462	.5544	.5544
17	.4251	.499	.5544	.462	.499	.5359	.5175
18	.7023	.5544	.6283	.7762	.6468	.5914	.5175
19	.8501	.9055	.9795	.8871	.924	.924	.8686
20	.7947	.9055	.8686	.8686	.8316	.9055	.8686
21	.7023	.7207	.7762	.7947	.9055	.8686	.8131
22	.5359	.4805	.6283	.6468	.6653	.7392	.6653
23	.5175	.4435	.5544	.5544	.5544	.6468	.5544
24	.462	.5175	.462	.5544	.5544	.5729	.6283
Max	.8501	.9055	.9795	.8871	.924	.924	.8686
Min	.3696	.3881	.4251	.4435	.3696	.3696	.462
Avg	.5175	.4990	.5336	.5729	.5724	.5559	.5817

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064008 / 33/11 KV PALANDUR S/s

Feeder No / Name : 403 / 33 KV PALANDUR (Incomer) NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / INCOMING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8487	.9694	.9877	3.9095	3.9095	1.358	4.0569
2	2.7978	.9694	.9877	3.858	3.858	1.358	4.0049
3	2.7978	.7316	1.0059	3.9095	3.858	1.3769	3.9529
4	2.8487	.9328	.9877	3.858	3.9095	1.3769	3.9529
5	2.8995	1.0059	.9877	3.858	3.9095	1.4146	3.9529
6	3.0013	1.0059	1.0059	3.858	3.9609	1.4523	3.9529
7	.763	.3658	.2743	.7716	.823	.3018	.8322
8	3.9169	1.4083	1.39	2.9835	3.0864	.3395	2.9647
9	4.1204	1.4998	1.4449	3.1379	3.2922	2.7263	2.9127
10	4.1712	1.4815	1.4632	3.1379	3.3951	2.9321	2.4966
11	1.4998	1.4998	4.1204	3.1893	1.2071	3.0864	3.0687
12	1.5364	1.4998	4.1204	3.2922	1.1883	3.0167	3.0687
13	1.4815	1.4815	4.1712	3.1379	1.226	3.1727	3.1727
14	1.4266	1.4632	4.1712	3.1379	1.1317	3.1727	3.1699
15	1.4266	1.4998	4.1152	3.0864	1.1694	3.2247	3.1207
16	.2378	.2195	.7716	.7716	.2641	.8322	.8842
17	.2195	.2561	.7716	.7716	.2829	.7802	.8322
18	.4207	.3109	.9774	1.1831	.3772	.9362	.8322
19	.5304	.5487	1.6461	1.5432	.5658	1.6124	1.5604
20	.5121	.5487	1.5432	1.5432	.3584	1.6124	1.6124
21	1.1888	1.1706	4.321	4.3724	1.5278	4.369	2.9321
22	.011	1.0242	4.1667	4.1152	1.5278	4.265	3.219
23	1.0059	1.0059	3.9609	3.9609	1.4523	4.1089	3.1184
24	2.8995	1.0242	1.0242	3.9609	3.9609	1.4146	4.0569
Max	4.1712	1.4998	4.321	4.3724	3.9609	4.369	4.0569
Min	.011	.2195	.2743	.7716	.2641	.3018	.8322
Avg	1.8567	.9968	2.1007	2.9728	2.0934	2.0934	2.8220

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064021 / 33/11 KV SALEBHATA S/S

Feeder No / Name : 201 / 11 KV SINDHIPAR AGP FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2378	.2315	.1858				
2	.2378	.2315	.1715				
3	.2378	.2315	.1646				
4	.2526	.2343	.1783				
5	.2526	.253	.1858				
6	.2526	.2469	.1783				
8				.3353	.2824	.3125	.2503
9				.3353		.2972	.2643
10				.3201	.2972	.2972	.2679
11				.3201	.2921	.2972	.2743
12				.3201	.2858	.3222	.2715
13				.3437	.2858	.2751	.2858
14				.3281	.2896	.2824	.2858
15				.3281	.3041	.2824	.2705
21	.2378	.2743	.2968				
22	.25	.1858	.2932				
23	.2469	.1858	.2932				
24	.2378	.2315	.1858	.2469			
Max	.2526	.2743	.2968	.3437	.3041	.3222	.2858
Min	.2378	.1858	.1646	.2469	.2824	.2751	.2503
Avg	.2444	.2306	.2133	.3197	.291	.2958	.2713

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064021 / 33/11 KV SALEBHATA S/S

Feeder No / Name : 202 / 11 KV RENGEPAR FEEDER AGP

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.6584	.5847	.5601	.7207
2				.6584	.5658	.5601	.7282
3				.6584	.5658	.5415	.7282
4				.6584	.6036	.5359	.7282
5				.6584	.6224	.6653	.7282
6				.6767	.6602	.6838	.7282
8	.6602	.8589	.7811				
9	.7095	.961	1.0164				
10	.7499	.9795	1.0425				
11	.8488	1.0719	1.0974				
12	.9335	1.1523					
13	.9149	1.1157	1.134				
14	.8871	1.0242	.9145				
15	.8596	.9877	1.0059				
21				.6478	.5658	.5729	.6413
22				.6224	.5788	.6653	.6413
23				.4877	.5658	.7392	.6413
24					.6036	.5658	.7207
Max	.9335	1.1523	1.134	.6767	.6602	.7392	.7282
Min	.6602	.8589	.7811	.4877	.5658	.5359	.6413
Avg	.8204	1.0189	.9988	.6363	.5917	.6090	.7006

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064021 / 33/11 KV SALEBHATA S/S

Feeder No / Name : 203 / 11 KV LAKHORI AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3005	.3391	.3149				
2	.3077	.3353	.3185				
3	.3239	.3277	.3018				
4	.3239	.3429	.2984				
5	.3315	.3467	.3149				
6	.3315	.3506	.3149				
8				.5658	.6224	.5415	.5658
9				.6161		.6413	.6036
10				.6602	.6602	.6413	.6413
11				.6535	.679	.6224	.6224
12				.6348	.6979	.679	.679
13				.6767	.6979	.6413	.6602
14				.6767	.6979	.6036	.679
15				.6516	.679	.6224	.6413
21	.3281	.3353	.439				
22	.3086	.3149	.439				
23	.3315	.3149	.439				
24	.3005	.3429	.3149	.4527			
Max	.3315	.3506	.439	.6767	.6979	.679	.679
Min	.3005	.3149	.2984	.4527	.6224	.5415	.5658
Avg	.3188	.3350	.3495	.6209	.6763	.6241	.6366

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064021 / 33/11 KV SALEBHATA S/S

Feeder No / Name : 204 / 11 KV LAKHORI GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.0377	.0373	.0377	.0366	.0373	.0377
2	.0187	.0377	.0185	.0377	.0373	.037	.0377
3	.0373	.0377	.0187	.0377	.0377	.0185	.0377
4	.0373	.0377	.0187	.0377	.0377	.0183	.0377
5	.0373	.0566	.0377	.0377	.0373	.0366	.0377
6	.0373	.0566	.0377	.0377	.0377	.0373	.0377
7	.0377	.0377	.0377	.0377	.0381	.0377	.0373
8	.0377	.0566	.0381	.0377	.0358	.0373	.0373
9	.0377	.0377	.0381	.0373		.0373	.0377
10	.0381	.0377	.0373	.0377	.0373	.0187	.0377
11	.0381	.037	.0377	.0373	.0377	.0373	.0381
12	.0373	.0377	.037	.0187	.0373	.0373	.0373
13	.0366	.0189	.0187	.0187	.0377	.0373	.0373
14	.0366	.0377	.0189	.0187	.0373	.0377	.0366
15	.0362	.0377	.0189	.0185	.0377	.0377	.0381
16	.0183	.0377	.0189	.0183	.0377	.0377	.0381
17	.0381	.0377	.0377	.0377	.0377	.0377	.0366
18	.0373	.0377	.0377	.0554	.0377	.0377	.056
19	.0747	.0943	.0754	.0754	.056	.0754	.0739
20	.0754	.0747	.0754	.0739	.0747	.0732	.0739
21	.0754	.056	.0566	.0566	.056	.0566	.0566
22	.0377	.0373	.0377	.0572	.0373	.0377	.0377
23	.0377	.0377	.0377	.0377	.0373	.0377	.0377
24	.0373	.0377	.0373	.0377	.037	.0373	.0377
Max	.0754	.0943	.0754	.0754	.0747	.0754	.0739
Min	.0183	.0189	.0185	.0183	.0358	.0183	.0366
Avg	.0398	.0439	.0361	.0391	.0406	.0389	.0422

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064021 / 33/11 KV SALEBHATA S/S

Feeder No / Name : 205 / 11 KV RENGEPAR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1109	.0934	.1097	.1494	.128	.1494	.1646
2	.1109	.0754	.1086	.1494	.1086	.1478	.1646
3	.1109	.0754	.0905	.1494	.1086	.1294	.1646
4	.1307	.0724	.0895	.1494	.0905	.128	.1646
5	.1494	.1086	.1448	.1494	.1663	.1463	.1829
6	.1494	.1267	.181	.1698	.1848	.1663	.1848
7	.128	.1417	.0905	.1509	.1417	.1578	.1417
8	.1307	.1595	.181	.1509	.1387	.1595	.1578
9	.1254	.1629	.181	.1494	.1433	.1629	.181
10	.1075	.1448	.1494	.1267	.1433	.1791	.181
11	.1417	.1097	.1433	.1097	.1214	.1791	.1629
12	.1075	.1463	.1086	.1463	.1254	.1791	.156
13	.1267	.128	.1052	.132	.1595	.1433	
14	.128	.128	.0886	.112	.1753	.1791	
15	.128	.1463	.124	.128	.1734	.1612	.0848
16	.1463	.1387	.08	.1463	.1715	.1612	.1267
17	.1448	.1509	.112	.1509	.168	.1612	.1267
18	.1595	.1509	.16	.1715	.1417	.1543	.1463
19	.2829	.2401	.2641	.2801	.2829	.2987	.2772
20	.2263	.2454	.2452	.2801	.2801	.2926	.2614
21	.2263	.2279	.2075	.2427	.2427	.2172	.2452
22	.1494	.1629	.1509	.1848	.1829	.1991	.1886
23	.128	.1267	.1509	.1646	.168	.181	.1698
24	.1109	.0943	.1097	.1494	.1463	.168	.1646
Max	.2829	.2454	.2641	.2801	.2829	.2987	.2772
Min	.1075	.0724	.08	.1097	.0905	.128	.0848
Avg	.1442	.1399	.1407	.1622	.1622	.1751	.1726

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064021 / 33/11 KV SALEBHATA S/S

Feeder No / Name : 401 / 33 KV Salebhata Incomer NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / INCOMING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7435	3.095	2.9835	2.1948	2.2177	2.4086	2.3102
2	2.7435	3.0407	2.9835	2.1948	2.1068	2.32	2.3102
3	2.7721	2.9864	2.9447	2.1948	2.0302	2.32	2.3102
4	2.8275	2.9321	2.9447	2.1491	2.1622	2.2177	2.2565
5	2.8829	3.1493	3.2602	2.2028	2.3045	2.384	2.4177
6	2.9081	3.3665	3.3653	2.2028	2.4394	2.384	2.4177
7	1.0425	1.0682	1.1568	1.1283	1.1191	1.1043	1.2323
8	2.1948	2.552	2.6046	4.1152	4.1993	3.9963	4.0329
9	2.2497	2.7109	2.7641	4.4993	3.4751	2.6818	4.145
10	2.3594	2.6818	2.7641	4.5542	3.9866	4.0929	2.9767
11	2.4394	2.7869	2.9235	4.4993	3.4385	4.0398	4.0398
12	2.4691	2.7984	1.8073	4.6091	4.3644	4.3587	4.1993
13	2.524	2.963	2.8172	4.6639	4.4696	4.3056	4.1015
14	2.4434	2.8532	2.7641	4.6639	4.3644	4.3587	3.6283
15	2.1399	2.7984	2.7641	4.3644	4.417	4.1993	3.9963
16	1.0642	1.1797	1.17	1.1568	1.0682	1.1163	1.0442
17	1.0174	1.2289	1.1317	1.17	1.1191	1.1163	1.094
18	1.17	1.2431	1.2346	1.2209	1.1831	1.2226	1.2094
19	1.5261	1.5912	1.5432	1.6975	1.7364	1.701	1.6301
20	1.4918	1.5415	1.5912	1.5604	1.6244	1.5415	1.5947
21	2.7161	3.6008	3.9506	2.7721	2.7435	2.6578	2.5514
22	3.3665	3.1379	3.6214	2.5503		2.5514	2.3388
23	3.2579	3.0864	3.4751	2.384	2.3594	2.4177	2.2805
24	2.7435	3.1493		3.4568	2.3285	2.4086	2.3102
Max	3.3665	3.6008	3.9506	4.6639	4.4696	4.3587	4.1993
Min	1.0174	1.0682	1.1317	1.1283	1.0682	1.1043	1.0442
Avg	2.2956	2.5642	2.5463	2.8419	2.6634	2.6627	2.6012

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064023 / 33/11 KV PIMPALGAON S/S

Feeder No / Name : 201 / 11 KV RAJEGAON AGP FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8668	1.0387	1.071				
2	.8686	1.0387	1.071				
3	.856	1.0208	1.0727				
4	.8489	1.0208	1.0727				
5	.8668	1.0208	1.0674				
6	.8757	1.0387	1.1748				
8				1.327	1.2536	1.2828	1.1919
9				1.3754	1.0566	1.2155	1.2269
10				1.3897	1.0745	1.2669	1.262
11				1.4334	1.3611	1.2846	1.2269
12				1.3838	1.3969	1.3023	1.2445
13				1.4299	1.379	1.2934	1.2445
14				1.4246	1.4327	1.3413	1.2795
15				1.4086	1.3969	1.2952	1.262
21	.6984	1.0889	1.1251				
22	1.0745	1.0835	1.079				
23	1.0566	1.0942	1.0525				
24	.8722	1.0566	1.071	1.0542			
Max	1.0745	1.0942	1.1748	1.4334	1.4327	1.3413	1.2795
Min	.6984	1.0208	1.0525	1.0542	1.0566	1.2155	1.1919
Avg	.8885	1.0502	1.0857	1.3585	1.2939	1.2853	1.2423

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064023 / 33/11 KV PIMPALGAON S/S

Feeder No / Name : 202 / 11 KV MANEGAON FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5392	.2454	.2641	.3083	.2915	.3206	.3258
2	.5323	.2279	.2623	.2977	.2683	.3278	.3258
3	.5386	.2279	.2641	.2924	.2683	.3118	.3018
4	.5333	.2279	.2623	.2906	.2683	.303	.3018
5	.5369	.2303	.2675	.2587	.2683	.2941	.3018
6	.513	.2481	.2898	.2959	.2818	.2949	.3149
7	.5046	.2658	.2864	.272	.2949	.2703	.3149
8	.5649	.2804	.2829	.2851	.3277	.2917	.2818
9		.2572	.308	.3012	.3277	.29	.2949
10		.2915	.2972	.2947	.3441	.3129	.3113
11	.6097	.2799	.3441	.3223	.3441	.3146	.3277
12	.6353	.302	.3605	.3077	.3768	.3523	.3441
13	.6562	.3431	.3601	.2915	.3149	.3688	.3277
14	.6497	.2846	.3429	.2915	.2984	.3588	.3277
15		.2743	.3601	.3012	.3239	.3326	.3441
16	.2625	.3163	.3681	.3417	.3441	.3064	.3481
17	.2865	.3048	.3441	.3466	.3277	.3162	.3441
18	.3441	.2987	.3605	.3601	.3654	.3441	.3973
19	.3932	.3551	.4592	.4031	.4746	.426	.4612
20	.4024	.4111	.4579	.4119	.4423	.4382	.4518
21	.3475	.3618	.3765	.394	.4189	.4525	.4252
22	.3109	.3068	.3294	.3403	.3611	.3982	.3916
23	.2629	.2666	.3225	.3224	.3361	.362	.3632
24	.5461	.2454	.2658	.3012	.2915	.3224	.3429
Max	.6562	.4111	.4592	.4119	.4746	.4525	.4612
Min	.2625	.2279	.2623	.2587	.2683	.2703	.2818
Avg	.4748	.2855	.3265	.3180	.3317	.3379	.3446

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064023 / 33/11 KV PIMPALGAON S/S

Feeder No / Name : 203 / 11 KV PATACHI TOLI FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3429	.3223	.3303	.3361	.3391	.3163
2		.3353	.3223	.3269	.3361	.3395	.3125
3		.3353	.3223	.3236	.3361	.3361	.3125
4		.3353	.3223	.3219	.3361	.3391	.3086
5		.3277	.3223	.3269	.3361	.3374	.3086
6		.3441	.3482	.3239	.3521	.331	.3048
7		.3605	.3466	.3644	.3549	.3287	.3201
8		.3768	.3514	.3482	.3749	.3457	.3201
9		.3658	.3838	.3637	.3841	.3352	.3506
10		.3506	.37	.3337	.3681	.3352	.3506
11		.3732	.4062	.2372	.3361	.3384	.3201
12		.3811	.4218	.3764	.3521	.37	.3353
13		.3937	.3858	.3922	.3841	.3789	.3201
14		.3922	.3858	.4111	.3593	.3903	
15	.4074	.3953	.3858	.3937	.3593	.3838	.2743
16	.2937	.3858	.3906	.3716	.3593	.3858	.3125
17	.437	.3922	.381	.3732	.3749	.3874	.3163
18	.4115	.3684	.3637	.3593	.3676	.3841	.3258
19	.4287	.4175	.3932	.4218	.4287	.4001	.3655
20	.4287	.4194	.4047	.3906	.4235	.4001	.3755
21	.3944	.4016	.3807	.407	.3995	.3944	.3387
22	.3772	.3822	.3549	.3944	.3515	.3601	.3118
23	.3601	.3595	.3303	.3601	.3578	.3429	.2951
24		.3601	.3223	.3361	.3361	.3425	.3163
Max	.437	.4194	.4218	.4218	.4287	.4001	.3755
Min	.2937	.3277	.3223	.2372	.3361	.3287	.2743
Avg	.3932	.3707	.3633	.3578	.3627	.3594	.3223

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064023 / 33/11 KV PIMPALGAON S/S

Feeder No / Name : 204 / 11 KV NILAGONDI GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905	.0754	.1386	.1566	.1478	.1528	.1663
2	.0905	.0754	.1386	.1509	.1478	.1509	.1478
3	.0886	.0754	.1368	.149	.1494	.1471	.1478
4	.0868	.0943	.1368	.1471	.1494	.1547	.1478
5	.1139	.1132	.1386	.166	.1509	.1641	.1848
6	.1811	.1698	.183	.1755	.1886	.2245	.2033
7	.1512	.132	.194	.1736	.1886	.2147	.1448
8	.1176	.1867	.1737	.1419	.1509	.1736	.1448
9		.1829	.1719	.1456	.1509	.1419	.1086
10		.1991	.1848	.1412	.1478	.1701	.1629
11	.127	.2012	.1905	.2462	.1478	.1555	.1267
12	.1382	.2469	.2096	.1647	.1294	.1573	.1448
13	.1083	.2048	.1334	.1303	.1294	.1427	.1448
14	.1102	.1755	.1905	.1575	.1097	.1164	.1267
15	.1251	.1774	.2096	.1357	.128	.084	.1448
16	.1176	.2241	.2096	.1593	.1294	.0691	.1646
17	.1176	.3544	.1463	.1665	.1294	.1251	.1774
18	.1294	.2339	.1975	.1433	.1999	.1402	.155
19	.2587	.3398	.2999	.2328	.2961	.2804	.2894
20	.2452	.2735	.2791	.2561	.281	.2629	.2697
21	.2075	.2128	.2414	.2378	.2697	.2452	.249
22	.132	.1718	.198	.1867	.1924	.2075	.1962
23	.0943	.1626	.1735	.168	.1718	.1886	.183
24	.0952	.0943	.1386	.1622	.1663	.1774	.1663
Max	.2587	.3544	.2999	.2561	.2961	.2804	.2894
Min	.0868	.0754	.1334	.1303	.1097	.0691	.1086
Avg	.1330	.1824	.1839	.1706	.1689	.1686	.1707

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064023 / 33/11 KV PIMPALGAON S/S

Feeder No / Name : 205 / MANEGAON AGP

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.6182	.6878	.6461	.6379
2				.6182	.6878	.6425	.631
3				.6164	.6805	.6371	.631
4				.62	.6805	.6371	.631
5				.6164	.6805	.6353	.6173
6				.6219	.691	.6425	.6173
8	.5433	.6836	.7488				
9		.7373	.7262				
10		.7202	.7282				
11	.7562	.7607	.7362				
12	.7371	.7449	.7186				
13	.73	.7344	.7011				
14	.7487	.7204	.7186				
15	.6842	.727	.7011				
21				.6878	.6697	.6626	.6662
22				.7059	.6733	.6805	.6787
23				.6878	.657	.6626	.6644
24					.7059	.6498	.6379
Max	.7562	.7607	.7488	.7059	.7059	.6805	.6787
Min	.5433	.6836	.7011	.6164	.657	.6353	.6173
Avg	.6999	.7286	.7224	.6436	.6814	.6496	.6413

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064023 / 33/11 KV PIMPALGAON S/S

Feeder No / Name : 401 / 33 KV Pimpalgao S/S

NON SHEDDABLE EXPRESS HV FEEDERS

Incomer Feeder KV- 33 /

(CONTINUOUS PROCESS)(NO STAGGERING)

INCOMING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8576	2.3434	5.2354	1.2631	1.1895	1.3032	1.2141
2	1.8576	2.332	5.2012	1.2346	1.1895	1.286	1.2043
3	1.829	2.2977	5.2812	1.2231	1.1895	1.2746	1.1895
4	1.8118	2.3262	5.2698	1.206	1.1895	1.2574	1.1551
5	1.9147	2.332	5.2698	1.206	1.1895	1.2803	1.1797
6	1.989	2.4691	5.6584	1.2974	1.278	1.3603	1.2682
7	.5401	.8688	1.8632	.703	.9259	.6773	.9145
8	1.2574	1.4861	1.4175	2.7449	3.0407	2.7501	2.9035
9		1.5432	1.4346	2.8921	2.8807	2.6397	2.9264
10		1.5432	1.5889	2.9236	2.8749	2.7869	2.8921
11	1.3603	1.4009	1.6289	3.0078	3.2122	2.8974	2.9378
12	1.4232	1.4402	1.6575	2.9721	3.3379	2.9867	3.0121
13	1.4175	1.4746	1.5432	3.3779	3.2979	3.0078	3.0864
14	1.4289	1.3321	1.5718	3.3608	3.2579	3.0288	2.6406
15	1.0688	1.3517	1.5718	3.2922	3.2865	2.8921	2.9721
16	.663	1.1145	.8359	.7502	.9259	.8859	.9374
17	.8802	1.1031	.7502	.7502	.9717	.823	.9717
18	.7159	1.086	.8897	.7287	.7287	.7459	.9945
19	.8873	1.326	1.0421	.9216	1.2174	.9645	1.0814
20	.8488	1.2174	1.206	.9088	1.1831	.9431	1.0322
21	2.4977	2.8064	2.8235	1.6575	1.6347	1.6575	1.6004
22	2.5434	2.6063	2.612	1.5203	1.4861	1.5775	1.4803
23	2.412	2.5206	2.5149	1.4403	1.3946	1.4575	1.3889
24	1.8747	2.372	5.2812	2.4634	1.2289	1.3489	1.4289
Max	2.5434	2.8064	5.6584	3.3779	3.3379	3.0288	3.0864
Min	.5401	.8688	.7502	.703	.7287	.6773	.9145
Avg	1.5036	1.7789	2.6729	1.8269	1.8380	1.7430	1.7672

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064037 / 33/11 KV LAKHORI S/S

Feeder No / Name : 201 / 11 KV Adarsh Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2033		.2402	.2957	.2772	.2402	.2743
2	.1848		.2402	.2957	.2772	.2402	.2743
3	.1829		.2378	.2743	.2772	.2402	.2772
4	.2012		.2378	.2743	.2772	.2402	.2772
5	.2012		.2378	.2561	.2772	.2402	.2772
6	.2172		.2195	.2534	.2561	.2402	.2587
7	.2149	.2126	.2126	.2534	.2507	.2686	.2534
8	.1928	.2195	.2172	.2353	.2534	.2507	.2481
9	.2328	.2126	.2378	.2303	.2454	.2481	.2303
10	.2279	.2303	.2353	.2715	.298	.2883	.298
11	.2601	.2713	.2454	.298	.2915	.285	.285
12	.2254	.2713	.2481	.2947	.3052	.3294	.3086
13	.2126	.2804	.2195	.2481	.2481	.2481	.3121
14	.2126	.2629	.2715	.2507	.2328	.2454	.2947
15	.1949	.2454	.2454	.2835	.2804	.3086	.3222
16	.2035	.2374	.2601	.3155	.3155	.3012	.3086
17	.218	.2515	.285	.333	.3185	.3521	.3185
18	.2774	.2481	.2629	.3222	.2947	.3086	.3185
19	.3292	.3292	.3921	.3982	.4024	.3761	.4163
20		.3326	.3696	.3734	.3696	.3658	.4207
21	.2957	.2926	.3547	.3696	.3142	.3511	.3511
22	.2772	.2772	.3547	.3696	.3142	.3326	.3658
23	.2378	.2561	.3326	.3142	.2772	.2926	.3142
24	.2054	.2195	.2402	.3142	.2772	.2587	.2743
Max	.3292	.3326	.3921	.3982	.4024	.3761	.4207
Min	.1829	.2126	.2126	.2303	.2328	.2402	.2303
Avg	.2265	.2584	.2666	.2969	.2888	.2855	.3033

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064037 / 33/11 KV LAKHORI S/S

Feeder No / Name : 202 / 11 KV ALESUR GAOTHAN

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0549	.0549	.0549	.0739	.056	.0732
2	.0373	.0549	.0549	.0366	.056	.056	.0739
3	.0373	.0549	.0554	.0362	.056	.056	.0739
4	.0366	.0549	.0554	.0362	.056	.056	.0739
5	.0366	.0549	.056	.0362	.0554	.056	.0747
6	.0366	.0549	.056	.0532	.0554	.056	.0747
7	.0543	.0532	.0543	.0701	.0543	.0537	.0526
8	.0354	.0532	.0543	.052	.0366	.0526	.0358
9	.056	.0543	.0377	.052	.0549	.0532	.0362
10	.0354	.0335	.0566	.0509	.0366	.0686	.052
11	.0354	.0526	.0549	.0486	.0354	.0526	.0526
12	.0339	.0335	.0366	.0655	.0377	.0671	.0526
13	.0497	.0686	.0716	.0486	.0716	.0693	.052
14	.0509	.0537	.0693	.0497	.0701	.0678	.0532
15	.0347	.0366	.0754	.0509	.0509	.0671	.0514
16	.0335	.0373	.0503	.0633	.0503	.0663	.0497
17	.0594	.0474	.0463	.0457	.0526	.0655	.0617
18	.0633	.0655	.0492	.0492	.0532	.0526	.0617
19	.1267	.128	.1254	.1097	.112	.112	.1267
20	.1109	.112	.1109	.1109	.112	.0934	.1086
21	.0914	.0914	.0924	.0924	.0934	.0934	.0934
22	.0724	.0732	.0914	.0747	.0747	.0924	.0924
23	.0537	.0543	.0732	.0739	.056	.0732	.0732
24	.0373	.0549	.0543	.0549	.0739	.056	.0732
Max	.1267	.128	.1254	.1109	.112	.112	.1267
Min	.0335	.0335	.0366	.0362	.0354	.0526	.0358
Avg	.0523	.0597	.0640	.0590	.0616	.0664	.0676

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064037 / 33/11 KV LAKHORI S/S

Feeder No / Name : 203 / 11 KV Sanjay Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4607	.4525	.4755	.5359	.5487	.567	.567
2	.4607	.4525	.4755	.5121	.5121	.567	.567
3	.4607	.4525	.4755	.5121	.4938	.5487	.5729
4	.4607	.4525	.4706	.5121	.5121	.5487	.5729
5	.4961	.4706	.4706	.5249	.5121	.5487	.5729
6	.4961	.5249	.4706	.543	.543	.5487	.567
7	.5138	.5373	.5014	.5493	.5731	.5731	.5552
8	.6089	.5792	.6036	.591	.5792	.5373	.591
9	.543	.5552	.5487	.591	.543	.5194	.5611
10	.4961	.4961	.567	.591	.5487	.5316	.5194
11	.4961	.5201	.5731	.6089	.5609	.6135	.567
12	.5138	.5258	.5731	.5493	.5784	.5847	.5493
13	.5316	.443	.5493	.5721	.591	.5552	.5316
14	.4477	.5258	.5138	.5083	.5083	.5973	.5316
15	.443	.5487	.4784	.5375	.5434	.5548	.567
16	.4557	.5201	.5316	.6348	.567	.5609	.5258
17	.5087	.583	.5316	.5375	.6135	.6001	.5609
18	.5487	.567	.5316	.5895	.6135	.6661	.5959
19	.7133	.7316	.7655	.7602	.7865	.7865	.8048
20	.6767	.7023	.7023	.7133	.7392	.7682	.7682
21	.6283	.6283	.6653	.6283	.7392	.7392	.7207
22	.567	.5914	.6468	.6468	.6838	.6767	.6653
23	.4938	.5121	.5914	.5853	.5853	.6219	.5853
24	.4607	.4525	.4755	.5359	.5487	.567	.567
Max	.7133	.7316	.7655	.7602	.7865	.7865	.8048
Min	.443	.443	.4706	.5083	.4938	.5194	.5194
Avg	.5201	.5344	.5495	.5779	.5844	.5993	.5911

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064037 / 33/11 KV LAKHORI S/S

Feeder No / Name : 401 / 33 KV Lakhori (Incomer)

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / INCOMING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7059	.7059	.7682	.8779	.8779	.8779	.9328
2	.7059	.7059	.7682	.823	.823	.8779	.9328
3	.7059	.7059	.7682	.8145	.823	.823	.9425
4	.6984	.7059	.7682	.8145	.823	.823	.9425
5	.7522	.7059	.7602	.8145	.8145	.823	.9328
6	.7522	.7602	.7602	.8596	.8688	.823	.8779
7	.7973	.7973	.7522	.8505	.8596	.9134	.8596
8	.8505	.8596	.8688	.8505	.8596	.8596	.8596
9	.8059	.8059	.823	.8505	.8596	.7973	.8059
10	.7442	.7442	.8779	.9036	.8413	.8745	.8413
11	.7802	.823	.8505	.9465	.8842	.9362	.8939
12	.7802	.8322	.8688	.8939	.9465	.9991	.8939
13	.7888	.7802	.8505	.823	.9036	.8505	.8842
14	.691	.823	.8505	.7802	.7888	.9134	.8939
15	.6836	.823	.7973	.8322	.8939	.9362	.9465
16	.6687	.763	.8322	.9156	.9465	.9465	.8745
17	.7956	.8648	.8745	.8648	.9774	1.0059	.9259
18	.8648	.8413	.8322	.9156	.9362	1.0288	.9882
19	1.1523	1.0974	1.262	1.2489	1.3169	1.2489	1.3575
20	1.0974	1.1088	1.1523	1.1643	1.2071	1.2071	1.3169
21	.9877	.9979	1.1088	1.0425	1.1643	1.1523	1.1643
22	.9328	.9328	1.1088	1.0425	1.0425	1.1088	1.0974
23	.7602	.823	.9877	.9328	.9328	.9877	.9877
24	.7133	.7059	.7682	.8779	.8779	.8779	.9328
Max	1.1523	1.1088	1.262	1.2489	1.3169	1.2489	1.3575
Min	.6687	.7059	.7522	.7802	.7888	.7973	.8059
Avg	.8006	.8214	.8775	.9058	.9279	.9455	.9619

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064038 / 33/11 KV POHORA S/S

Feeder No / Name : 201 / 11 KV SHIVNI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.6979	.7356				
2	.6036	.6979	.7356				
3	.6036	.6979	.7356				
4	.6036	.7167	.7356				
5	.6036	.7167	.7356				
6	.6224	.7167	.7356				
8				.8589	.9149	.9149	.8589
9				.8775	.9522	.9335	.8962
10				.961	.9335	.9149	.8029
11				.9979	.9335	.9979	.8589
12					.9795	.9979	.8215
13				.9979	1.0164	1.0425	.9522
14				1.0164	.9795	.9979	.8871
15				.9425	.9795	.9795	.8501
21	.7167	.7356	.7545				
22	.7167	.7356	.7545				
23	.7167	.7356	.7167				
24	.6036	.6979	.7356	.7167			
Max	.7167	.7356	.7545	1.0164	1.0164	1.0425	.9522
Min	.6036	.6979	.7167	.7167	.9149	.9149	.8029
Avg	.6394	.7149	.7375	.9211	.9611	.9724	.8660

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 043167 / 33 KV S/S DONGARGAON

Feeder No / Name : 201 / 11 KV SASRA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0031	1.0242	1.1069	.3584	.3584	.3395	.381
2	1.0402	1.012	1.1043	.3584	.3584	.3206	.3584
3	1.0722	1.0242	1.1043	.3584	.3395	.3206	.3547
4	1.0623	.9998	1.1043	.4108	.3395	.3206	.3584
5	1.0753	1.0402	1.1523	.5041	.3018	.3395	.3361
6	1.1069	1.085	1.2003	.3361	.3361	.3174	.3174
7	.2667	.2263	.2241	.2054	.2452	.2241	.2452
8	.2614	.2241	.2452	1.2944	1.2631	1.2955	1.2492
9	.2263	.2075	.2263	1.4419	1.3441	1.0911	1.3123
10	.2054	.168	.1867	1.4575	1.3763	1.4582	1.4089
11	.1698	.1509	.1867	1.4746	1.3763	1.4413	1.4251
12	.1886	.168	.1886	1.4251	1.3763	1.491	1.3765
13	.1905	.1715	.2096	1.4575	1.3443	1.4899	1.4413
14	.1698	.2096	.2477	1.5074	1.3923	1.4403	1.4737
15	.1698	.168	.2286	1.3927	1.3443	1.4413	1.4582
16	.1698	.1494	.2286	.2075	.2286	.2096	.2667
17	.1886	.1524	.2263	.2263	.2263	.2286	.2286
18	.2477	.2858	.2641	.3048	.3018	.2667	.2667
19	.5658	.547	.547	.5847	.5658	.5658	.6097
20	.547	.547	.5658	.5847	.5658	.6036	.6224
21	1.0814	1.065	1.1633	.5525	.547	.5525	.5847
22	1.0688	1.166	1.1203	.4572	.4382	.4572	.4763
23	1.0722	1.1203	1.1523	.4191	.3961	.4191	.3961
24	1.0311	1.0242	1.1069	1.1203	.381	.3772	.381
Max	1.1069	1.166	1.2003	1.5074	1.3923	1.491	1.4737
Min	.1698	.1494	.1867	.2054	.2263	.2096	.2286
Avg	.5909	.5807	.6288	.7683	.6978	.7088	.7220

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 043167 / 33 KV S/S DONGARGAON

Feeder No / Name : 202 / 11KV SANGADI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5525	.5658	.5906	.7253	.8539	.8749	.8962
2	.547	.5658	.5658	.7011	.8642	.8592	.9069
3	.547	.5658	.5658	.7011	.8436	.8592	.8749
4	.5716	.5658	.5658	.7011	.8333	.8855	.8749
5	.5658	.5658	.6036	.7468	.8436	.9172	.8951
6	.5847	.6036	.6413	.7811	.8855	.9488	.9259
7	.6979	.6602	.5658	.5847	.5847	.5847	.6413
8	.7099	.8124	.8333	.6097	.5658	.5716	.6224
9	.787	.9414	.9061	.6036	.5847	.5847	.679
10	.8855	.9442	.9646	.6036	.5847	.6224	.6224
11	.8429	.8642	.9259	.6535	.5847	.5093	.5975
12	.9145	.9374	.9217	.547	.547	.5228	.6161
13	.9633	1.2654	.9568	1.6975	.5281	.6161	.6413
14	.8951	.945	.9646	.5847	.5281	.5975	.6722
15	.7621	.8768	.884	.5658	.5658	.6161	.7282
16	.5359	.5175	.5304	.5544	.5601	.5975	.7133
17	.5601	.462	.499	.6099	.5601	.5304	.7023
18	.5975	.5975	.6535	.6535	.679	.6535	.695
19	1.0098	1.0669	1.105	1.1431	1.1694	1.1431	1.1694
20	1.0098	1.0288	1.105	1.094	1.1241	1.1317	1.1317
21	.8954	.9717	1.6385	.9779	.9945	1.0111	1.0322
22	.6859	.7811	.8383	.9717	.9442	.9878	1.0364
23	.6097	.724	.743	.9282	.8855	.9282	.9282
24	.5716	.5658	.6097	.6859	.8539	.8855	.8855
Max	1.0098	1.2654	1.6385	1.6975	1.1694	1.1431	1.1694
Min	.5359	.462	.499	.547	.5281	.5093	.5975
Avg	.7209	.7665	.7991	.7677	.7487	.7683	.8120

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 043167 / 33 KV S/S DONGARGAON

Feeder No / Name : 203 / 11KV DIGHORI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	1.0722	.9842	.3395	.3584	.3772	.3734
2	.9145	1.0595	.9804	.3206	.3584	.3395	.3547
3	.9414	1.0467	.9804	.3206	.3395	.3206	.3584
4	.9568	1.034	.9686	.3206	.3361	.3206	.3584
5	.9722	1.0623	.9842	.3206	.3361	.3395	.3395
6	.9602	1.1203	.9998	.3206	.3395	.3206	.3206
7	.2641	.168	.2263	.2641	.2772	.2641	.2427
8	.132	.1294	.1509	1.1498	1.1385	1.1702	1.1092
9	.2641	.2641	.2641	1.166	1.1561	1.2631	1.1544
10	.2452	.2641	.2452	1.166	1.1265	1.2955	1.1561
11	.1307	.2452	.2263	1.1574	1.1717	1.2342	
12	.2641	.2452	.2641	1.2003	1.1873	1.2176	1.2018
13	.2427	.2452	.2452	1.1405	1.1717	1.2323	1.2018
14	.2614	.2641	.2452	1.0987	1.2176	1.2176	1.2018
15	.2641	.2452	.2829	1.1126	1.2018	1.2163	1.2003
16	.2641	.2452	.2641	.2641	.2829	.2641	.3206
17	.2614	.2452	.2452	.2614	.2452	.2427	.2829
18	.2772	.2452	.2829	.2263	.2452	.2641	.1509
19	.5281	.547		.547	.5658	.5658	.547
20	.5228	.5658	.5788	.5847	.6036	.5658	.5847
21	1.0595	.9646	1.0898	.5415	.5658	.5228	.5847
22	1.1336	.9962	1.0814	.4338	.4527	.4527	.4715
23	1.0722	.9998	1.0364	.3961	.3961	.4108	.3961
24	.9568	1.0467	.9998	1.0202	.3547	.3961	.3734
Max	1.1336	1.1203	1.0898	1.2003	1.2176	1.2955	1.2018
Min	.1307	.1294	.1509	.2263	.2452	.2427	.1509
Avg	.5752	.5967	.5924	.6530	.6429	.6589	.6211

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 043167 / 33 KV S/S DONGARGAON

Feeder No / Name : 204 / STATION TF

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.0549	.0128	.0091	.013	.0096	.0126
Max	.0549	.0128	.0091	.013	.0096	.0126
Min	.0549	.0128	.0091	.013	.0096	.0126
Avg	.0549	.0128	.0091	.013	.0096	.0126

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 043167 / 33 KV S/S DONGARGAON

Feeder No / Name : 401 / 33 KV DONGARGAON FEEDER

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	28-FEB-18
HR	Load (MW)
13	1.1831
14	1.286
15	1.5775
16	1.5775
17	1.1831
18	1.749
19	2.0576
20	2.2291
21	2.0936
22	1.8861
23	1.829
Max	2.2291
Min	1.1831
Avg	1.6956

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 064018 / 33KV SATALWADA

Feeder No / Name : 201 / 11 KV KINHI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5201	.5498	.535	.0987	.1524	.1448	.1593
2	.535	.5498	.5201	.1128	.1524	.1448	.1593
3	.5201	.535	.535	.1174	.1524	.1593	.1715
4	.535	.535	.5498	.132	.1524	.1715	.1738
5	.535	.5647	.5647	.1467	.1524	.1715	.1593
6	.5498	.5796	.5944	.1614	.1524	.1715	.1738
8	.1448	.1738		.6767	.7773	.823	.8768
9	.1783	.1932	.1882	.7926	.8688	.8993	.8619
10	.1783	.1783	.1882	.823	.8688	.823	.8768
11	.176	.1635	.1882	.8383	.8688	.8535	.8619
12	.1783	.1783	.2027	.8688	.8488	.8688	.8768
13	.1738	.1692	.1882	.8688	.8642	.9145	.8619
14	.1882	.1833	.1882	.8688	.8333	.8993	.8768
15	.1882	.1692	.1738	.7926	.7716	.8078	.8619
21	.4607	.535	.5357	.1981	.1783	.1486	.1593
22	.535	.5647	.5357	.1981	.1957	.1783	.1738
23	.5498	.5647	.5216	.1524	.1656	.1738	.1738
24	.535	.535	.5647	.5216	.1524	.1505	.1738
Max	.5498	.5796	.5944	.8688	.8688	.9145	.8768
Min	.1448	.1635	.1738	.0987	.1524	.1448	.1593
Avg	.3712	.3846	.3985	.4649	.4616	.4724	.4796

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 064018 / 33KV SATALWADA

Feeder No / Name : 204 / 11 KV KINHI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2149	.2427	.2195	.2534	.2587	.2534	.2715
2	.2172	.2353	.1991	.2686	.2402	.2353	.2378
3	.2328	.2378	.2195	.2587	.2328	.2328	.2195
4	.2328	.2195	.2012	.2772	.2507	.2507	.2353
5	.2303	.2353	.2534	.2772	.2534	.2658	.2561
6	.2534	.2534	.2743	.2507	.2534	.2835	.2926
7	.2507	.2686	.2715	.2686	.2534	.2835	.2896
8	.2328	.2715		.2353	.2534	.2865	.2534
9	.2715	.2896	.2534	.2402	.2896	.2534	.3077
10	.2534	.2427	.2534	.2402	.2534	.2353	.2926
11	.1991	.2126	.2172	.2218	.2353	.2328	.3077
12	.1791	.2126	.2172	.1848	.2012	.1991	.2715
13	.2126	.2126	.2172	.2218	.128	.2172	.2561
14	.197	.2303	.181	.2218	.2012	.2149	.2926
15	.197	.2126	.2172	.2218	.2195	.2353	.2743
16	.2149	.2481	.2172	.2587	.2378	.2507	.2896
17	.2353	.2686	.2534	.2218	.2743	.2534	.3077
18	.2743	.3224	.2686	.2957	.3258	.2926	.3801
19	.3801	.3761	.3761	.3696	.4163	.439	.4706
20	.3658	.3582	.3582	.3696	.362	.4024	.4344
21	.3077	.2896	.3045	.3326	.3439	.3658	.3582
22	.2534	.2561	.2686	.2957	.3292	.3174	.3258
23	.2534	.2195	.2353	.2587	.2926	.2715	.2926
24	.2378	.2353	.2195	.2896	.2587	.2561	.2534
Max	.3801	.3761	.3761	.3696	.4163	.439	.4706
Min	.1791	.2126	.181	.1848	.128	.1991	.2195
Avg	.2457	.2563	.2477	.2639	.2652	.2720	.2988

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 064018 / 33KV SATALWADA

Feeder No / Name : 205 / 11 KV SATALWADA GT.

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5853	.5792	.5373	.5175	.6335	.6099	.6584
2	.5487	.5373	.543	.5175	.6335	.6099	.6335
3	.5487	.5316	.5731	.543	.6516	.6348	.6767
4	.5609	.5258	.5847	.543	.6344	.6722	.695
5	.5487	.5493	.6089	.5792	.6344	.7167	.7602
6	.5973	.591	.6089	.6516	.6516	.7356	.7964
7	.5731	.5973	.6201	.6878	.7202	.8299	.8145
8	.6154	.6089		.7421	.7202	.9242	.905
9	.5847	.6268	.6268	.8145	.7545	.9431	1.0136
10	.6024	.6878	.4298	.8688	.823	.9431	1.0029
11	.6089	.6697	.6447	.905	.8573	.8596	.9492
12	.6089	.6697	.788	.9412	.8669	.9145	.9955
13	.6201	.6878	.7522	.9774	.8149	.8962	.9774
14	.6268	.6697	.8238	.8326	.7628	.8688	.9145
15	.6447	.6626	.7522	.8688	.7802	.9412	.905
16	.6556	.6805	.8596	.9412	.7455	.9593	.9328
17	.6201	.6036	.8238	.7964	.7628	1.0425	.4525
18	.6201	.7164	.7964	.4163	.8596	.9593	.9593
19	.7796	.788	.8869	.9412	.9511		1.0136
20	.7373	.7783	.8145	.8688	.9145	.9412	.9955
21	.6878	.6516	.7059	.7602	.8048	.8417	.8775
22	.5792	.5792	.6468	.6878	.7316	.7343	.7421
23	.5611	.543	.5729	.6154	.695	.6878	.6878
24	.5975	.543	.5487	.5729	.6154	.6219	.6767
Max	.7796	.788	.8869	.9774	.9511	1.0425	1.0136
Min	.5487	.5258	.4298	.4163	.6154	.6099	.4525
Avg	.6130	.6283	.6760	.7329	.7508	.8212	.8348

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391] BU 0391

Substation No/ Name :- 064018 / 33KV SATALWADA

Feeder No / Name : 206 / STATION TF

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	25-FEB-18	26-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
9	.0953		
23		.5249	.0943
Max	.0953	.5249	.0943
Min	.0953	.5249	.0943
Avg	.0953	.5249	.0943

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 064019 / 33 KV PARASTOLA

Feeder No / Name : 201 / 11 KV CHANDORI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.8002	.8192	.9526	.9907	.9145	.9717
2	.724	.8002	.8192	.9526	.9907	.9145	.9717
3	.724	.8002	.8192	.9526	.9907	.8954	.9526
4	.724	.8002	.8192	.9526	.9907	.8764	.9335
5	.743	.8002	.8002	.9526	.9907	.8764	.9335
6	.743	.8383	.8573	.9717	.9907	.8764	.9335
7	.7621	.8764	.8383	.9526	.9717	.9145	.9717
8	.8002	.9335	.8954	.9907	1.0669	.9717	1.0098
9	.8764	.9907	1.0098	1.0288	1.0479	1.105	1.0479
10	.5144	.9717	1.086	1.0669	1.086	1.1241	1.105
11	.8002	1.0098	1.086	.9907	1.0669	1.1812	1.105
12	.8764	1.0288	1.086	1.0288	1.0288	1.1622	1.086
13	.8764	1.0098	1.086	1.0669	1.0479	1.2574	1.1622
14	.9145	1.0098	1.0669	1.105	1.0669	1.2003	1.1241
15	.9335	1.0288	1.0479	1.105	1.0669	1.1812	1.105
16	1.0288	.9526	1.1241	1.1431	1.105	1.2003	1.1241
17	1.0669	.9907	1.0669	1.2003	1.105	1.1812	1.1241
18	1.0669	1.0479	1.1241	1.1622	1.1241	1.1812	1.1431
19	1.0479	1.086	1.2193	1.2384	1.1812	1.2003	1.2955
20	1.0288	1.0288	1.1812	1.2193	1.1812	1.1622	1.2193
21	.9526	.9335	1.086	1.1241	1.0479	1.0669	1.105
22	.8383	.8383	1.0098	1.0479	.9526	1.0098	1.0098
23	.8002	.8192	.9717	1.0098	.9145	.9907	.9907
24	.724	.8002	.8002	.9717	.9907	.9145	.9717
Max	1.0669	1.086	1.2193	1.2384	1.1812	1.2574	1.2955
Min	.5144	.8002	.8002	.9526	.9145	.8764	.9335
Avg	.8454	.9248	.9883	1.0495	1.0415	1.0566	1.0582

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 064019 / 33 KV PARASTOLA

Feeder No / Name : 203 / 11 KV BODRA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.5525	.6478	.7049	.6859	.7049	.724
2	.4954	.5525	.6478	.7049	.6859	.7049	.724
3	.4954	.5525	.6478	.7049	.6859	.6859	.724
4	.4954	.5525	.6478	.7049	.6859	.6859	.6859
5	.5144	.5525	.6668	.7049	.7049	.6859	.7049
6	.5525	.5906	.6859	.724	.724	.7049	.743
7	.5716	.6287	.7049	.724	.7621	.724	.7811
8	.6097	.6668	.743	.6859	.8002	.7811	.8002
9	.6668	.724	.743	.7621	.7621	.8002	.7811
10	.6668	.724	.743	.7811	.6668	.8383	.8192
11	.6287	.743	.7621	.8002	.724	.8383	.8383
12	.6859	.724	.6859	.8383	.743	.8573	.8383
13	.6287	.7049	.8002	.7049	.6287	.8002	.8002
14	.6859	.6859	.8002	.7811	.6668	.8573	.7621
15	.6859	.7049	.7811	.8002	.6287	.7811	.7621
16	.6478	.724	.7811	.8002	.724	.7811	.7811
17	.6287	.7621	.8192	.8764	.743	.8002	.8002
18	.4191	.7621	.8192	.8002	.7621	.8573	.8764
19	.6859	.7811	.8383	.8192	.8192	.8573	.8954
20	.6859	.7811	.8192	.8002	.8002	.8383	.8764
21	.6478	.743	.7811	.7811	.7811	.8002	.8383
22	.5906	.6859	.743	.743	.724	.7621	.7811
23	.5525	.6668	.724	.7049	.7049	.724	.7621
24	.5144	.5525	.6478	.7049	.6859	.6859	.724
Max	.6859	.7811	.8383	.8764	.8192	.8573	.8954
Min	.4191	.5525	.6478	.6859	.6287	.6859	.6859
Avg	.5938	.6716	.7367	.7565	.7208	.7732	.7843

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 064019 / 33 KV PARASTOLA

Feeder No / Name : 204 / STATION TF

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0572	.0572	.0572	.0572	.0381
2	.0572	.0572	.0572	.0572	.0572	.0572	.0381
3	.0572	.0572	.0572	.0572	.0572	.0572	.0381
4	.0572	.0572	.0572	.0572	.0572	.0572	.0381
5	.0572	.0572	.0572	.0572	.0572	.0572	.0381
6	.0572	.0572	.0572	.0572	.0572	.0572	.0381
7	.0572	.0191	.0572	.0572	.0191	.0191	.0191
8	.0191	.0191	.0381	.0572	.0191	.0191	.0191
9	.0191	.0191	.0191	.0191	.0191	.0191	.0191
10	.0191	.0191	.0191	.0191	.0191	.0191	.0191
11	.0191	.0191	.0191	.0191	.0191	.0191	.0191
12	.0191	.0191	.0191	.0191	.0191	.0191	.0191
13	.0191	.0191	.0191	.0191	.0191	.0191	.0191
14	.0191	.0191	.0191	.0191	.0191	.0191	.0191
15	.0191	.0191	.0191	.0191	.0191	.0191	.0191
16	.0191	.0191	.0191	.0191	.0191	.0191	.0191
17	.0191	.0191	.0191	.0191	.0191	.0191	.0191
18	.0191	.0191	.0381	.0191	.0191	.0191	.0191
19	.0762	.0762	.0953	.0953	.0953	.0762	.0762
20	.0762	.0572	.0953	.0762	.0953	.0762	.0762
21	.0572	.0572	.0572	.0572	.0953	.0572	.0762
22	.0572	.0572	.0572	.0572	.0572	.0572	.0572
23	.0572	.0572	.0572	.0572	.0572	.0381	.0381
24	.0572	.0572	.0572	.0572	.0572	.0572	.0381
Max	.0762	.0762	.0953	.0953	.0953	.0762	.0762
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0413	.0389	.0445	.0437	.0429	.0389	.0342

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 064019 / 33 KV PARASTOLA

Feeder No / Name : 411 / 33 kV Salebhata

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4006	2.8578	2.9721	1.9433	2.0005	2.0576	2.1148
2	2.4006	2.8006	2.915	1.9433	2.0005	2.0576	2.0576
3	2.4577	2.8006	2.9721	2.0005	2.0005	2.0005	2.0005
4	2.4006	2.8006	2.9721	2.0005	2.0005	2.0005	2.0576
5	2.5149	2.8006	3.0293	1.9433	2.0005	2.0005	2.0576
6	2.572	3.0864	3.315	2.0005	2.1148	2.0005	2.1719
7	.8573	1.0288	1.1431	1.086	1.086	1.086	1.0288
8	2.0005	2.2862	2.4006	3.8866	4.0581	3.9438	3.7151
9	2.1148		2.5149	4.1724	3.315	2.6292	3.9438
10	2.1148	2.572	2.6863	4.2295	3.9438	3.9438	3.9438
11	2.1719	2.6863	2.8006	4.3439	3.6008	4.1152	3.9438
12	2.3434	2.8578	2.6863	4.4582	4.3439	4.2867	4.0581
13	2.2862	2.8006	2.6863	4.5153	4.401	4.2867	4.0009
14	1.829	2.6292	2.6292	4.4582	4.4582	4.2867	3.7151
15	2.0005	2.6292	2.6863	3.4865	4.4582	4.1152	4.0009
16	1.0288	1.2574	1.2003	1.1431	1.086	1.086	1.086
17	1.0288	1.2574	1.086	1.2003	1.1431		1.1431
18	1.1431	1.2574	1.2003	1.2003	1.1431	1.1431	1.1431
19	1.4289	1.6575	1.6004	1.6004	1.6004	1.6575	1.5432
20	1.3717	1.4861	1.4289	1.4861	1.4861	1.5432	1.4861
21	2.4577	3.5437	3.658	2.4006	2.4577	2.4006	2.2862
22	3.1436	3.2579	3.4294	2.2291	2.2291	2.2862	2.1148
23	2.9721	3.0864	3.2007	2.1148	2.1719	2.1719	2.0005
24	2.4577	2.915	2.9721	3.2007	2.0576	2.0576	2.1148
Max	3.1436	3.5437	3.658	4.5153	4.4582	4.2867	4.0581
Min	.8573	1.0288	1.086	1.086	1.086	1.086	1.0288
Avg	2.0624	2.4502	2.5077	2.6268	2.5482	2.5720	2.4887

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 064024 / 33/11 KV WADAD

Feeder No / Name : 202 / 11 KV WADAD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.9204	2.1026	2.1365	2.079
2				1.9204	2.1026	2.1365	2.079
3				1.9281	2.0454	2.1195	2.0957
4				1.9281	2.0454	2.0856	2.0957
5				1.95	2.0454	2.0856	2.0957
6				1.95	2.0454	2.0856	2.0957
8	2.1559	2.0178	2.1874				
9	2.1209	1.3032	2.4417				
10	2.1735	1.3717	2.2891				
11	2.1195	1.3889	2.3739				
12	2.2043	2.2552	2.4078				
13	1.3565	2.2043	2.3061				
14	1.3546	2.452	2.3061				
15	1.2548	2.3148	2.332				
16	.9221	.9326					
17	.9389	.8817					
18	.9389						
21				2.0348	2.0348	2.0119	2.146
22				2.1365	2.1704	2.079	2.1795
23				2.1365	2.1704	2.079	2.1125
24					2.1026	2.1534	2.079
Max	2.2043	2.452	2.4417	2.1365	2.1704	2.1534	2.1795
Min	.9221	.8817	2.1874	1.9204	2.0348	2.0119	2.079
Avg	1.5945	1.7122	2.3305	1.9894	2.0865	2.0973	2.1058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 064024 / 33/11 KV WADAD

Feeder No / Name : 203 / 11 KV KHANDALA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3176	1.2517	1.2431				
2	1.3176	1.2346	1.2266				
3	1.3176	1.2517	1.2548				
4	1.3032	1.2517	1.2431				
5	1.3032	1.2174	1.2431				
6	1.3203	1.2689	1.2431				
8				1.3523	1.4083	1.2967	1.3125
9				1.4043	1.291	1.3279	1.3125
10				1.4737	1.4586	1.3757	1.3904
11				1.4918		1.3599	1.4217
12				1.4575		1.3599	1.4217
13				1.5089			1.406
14				1.4403			1.4217
15				1.4746	1.2811		1.4217
16					1.2654		
17					1.2811	1.3599	
18					1.2498	1.3916	
19						1.2967	
21	1.2071	1.1934	1.3176				
22	1.2689	1.21	1.2656				
23	1.2689	1.2431	1.3003				
24	1.3176	1.2689	1.2431	1.3003			
Max	1.3203	1.2689	1.3176	1.5089	1.4586	1.3916	1.4217
Min	1.2071	1.1934	1.2266	1.3003	1.2498	1.2967	1.3125
Avg	1.2942	1.2391	1.2580	1.4337	1.3193	1.3460	1.3885

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 064024 / 33/11 KV WADAD

Feeder No / Name : 204 / PALASGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1267	.1267	.1463	.1848	.181	.1991	.2033
2	.1267	.1075	.1448	.1663	.181	.1991	.2033
3	.124	.1075	.1448	.1629	.181	.1991	.2033
4	.124	.124	.1448	.1629	.1734	.181	.1848
5	.1227	.124	.1629	.1629	.1734	.181	.1848
6	.1578	.1595	.1612	.181	.1734	.181	.1848
7	.1753	.1772	.1791	.1677	.1907	.1791	.2195
8	.1578	.1417	.1595	.1509	.1734	.1433	.181
9	.124	.1595	.1417	.1174	.1448	.1612	.1448
10	.1417	.1063	.124	.1417	.0905	.1417	.1254
11	.1254	.124	.124	.1417	.1086	.1772	.1433
12	.1254	.1063	.124	.1595	.1254	.1254	.1433
13	.1254		.1086	.1595	.1612	.1612	.1341
14	.1075	.0886	.1086	.1063	.1254	.1791	.1509
15	.0876	.1417	.1086	.124	.1075	.1791	.1174
16	.0701	.0886	.1448	.1267	.1075	.1433	.1844
17		.1063	.1267	.1267	.1433	.1433	.1509
18	.1526	.1629	.181	.181	.1612	.1612	.1677
19	.2374	.2743	.2534	.2534	.2715	.2772	.2865
20	.2328	.2561	.2534	.2715	.2715	.2772	.2865
21	.197	.2218	.2218	.2353	.2353	.2402	.2328
22	.1646	.1848	.1848	.1991	.2172	.2218	.197
23	.1463	.1646	.1848	.181	.2172	.2033	.197
24	.1267	.1448	.1646	.1848	.181	.1991	.2033
Max	.2374	.2743	.2534	.2715	.2715	.2772	.2865
Min	.0701	.0886	.1086	.1063	.0905	.1254	.1174
Avg	.1426	.1478	.1583	.1687	.1707	.1856	.1846

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 064024 / 33/11 KV WADAD

Feeder No / Name : 205 / SUKALI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1433	.1433	.1433	.181	.1991	.1928	.1629
2	.1267	.1433	.1433	.1629	.1991	.1753	.1448
3	.1267	.1417	.1417	.1595	.1991	.1753	.1448
4	.1267	.1629	.1417	.1595	.1886	.1753	.1448
5	.1227	.1629	.1595	.1595	.1715	.1753	.1448
6	.1402	.1357	.1578	.1772	.1658	.1753	.1448
7	.1402	.1715	.1734	.16	.1492	.1543	.1254
8	.1227	.1543	.1372	.16	.1326	.1526	.124
9	.1433	.1372	.1715	.1509	.1402	.1696	.1063
10	.1433	.1372	.1372	.1791	.1578	.1696	.124
11	.1629	.12	.1372	.1677	.1402	.1187	.1063
12	.1629	.12	.1543	.1341	.1543	.1017	.0886
13	.1629	.12	.1326	.1341	.12	.1372	.0358
14	.1629	.1029	.116	.1341	.1372	.12	.0358
15	.1578	.12	.1227	.1341	.1372	.12	.0895
16	.1402	.12	.1402	.124	.1372	.0857	.1075
17	.1543	.12	.1402	.1423	.1372	.1029	.1075
18	.1696	.1928	.1753	.1739	.1543	.1372	.1612
19	.2204	.2328	.2103	.2353	.2629	.1772	.2103
20	.2303	.2328	.2103	.2353	.2454	.1991	.2103
21	.2126	.2149	.2149	.2353	.2279	.181	.1928
22	.181	.197	.197	.2172	.2103	.181	.1753
23	.181	.1791	.181	.1991	.2103	.1629	.1578
24	.1433	.1629	.1612	.181	.1991	.1928	.1629
Max	.2303	.2328	.2149	.2353	.2629	.1991	.2103
Min	.1227	.1029	.116	.124	.12	.0857	.0358
Avg	.1574	.1552	.1583	.1707	.1740	.1555	.1337

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 064024 / 33/11 KV WADAD

Feeder No / Name : 206 / SAWARBANDH GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.168	.168	.1509	.2075	.2263	.2263
2	.1698	.1478	.168	.1509	.2075	.2075	.2075
3	.1646	.1478	.1494	.1448	.1991	.2075	.2075
4	.1463	.1663	.168	.1629	.1991	.2075	.1886
5	.1478	.1663	.1663	.1629	.1991	.2054	.1886
6	.1848	.2195	.1663	.1791	.1991	.2054	.1886
7	.1663	.1646	.1663	.1448		.1848	.1886
8	.1663	.2195	.1848		.1629	.1646	.1663
9	.1629	.1646	.2033	.1448	.1448	.1646	.1663
10	.181	.1646	.1663	.1463	.1629	.1463	.1478
11	.1463	.1646	.1294	.1267	.1629	.1097	.1509
12	.128	.2012	.1478	.1267	.128	.1294	.132
13	.1463	.1646	.1677	.1267	.128	.168	.1294
14	.2012	.1463	.1372	.1267	.1463	.1494	.1294
15	.1417	.0914	.12	.1448	.1463	.168	.1478
16	.1595	.1097	.1372	.128	.1463	.1494	.1663
17	.1578	.1478	.12	.1372	.1463	.168	.1848
18	.1612	.1867	.1543	.1886	.1829	.2054	.1848
19	.2686	.2829	.2401	.3206	.3174	.3206	.3018
20	.2987	.2829	.2401	.3018	.3018	.3206	.3018
21	.2427	.2263	.2641	.2829	.2829	.2829	.2829
22	.1867	.2075	.2452	.2452	.2452	.2452	.2263
23	.1867	.168	.2075	.2641	.2452	.2452	.2075
24	.1886	.168	.168	.1886	.2075	.2263	.2263
Max	.2987	.2829	.2641	.3206	.3174	.3206	.3018
Min	.128	.0914	.12	.1267	.128	.1097	.1294
Avg	.1789	.1782	.1744	.1781	.1943	.2003	.1937

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 065004 / 33 KV SAKOLI

Feeder No / Name : 201 / 11 KV S'Wafa AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6118	1.701	1.6301				
2	1.6118	1.701	1.6301				
3	1.6118	1.701	1.6124				
4	1.6118	1.7187	1.6124				
5	1.6651	1.7364	1.6124				
6	1.701	1.7364	1.6124				
8				1.8983	2.0908	2.0199	2.0683
9				1.6651	2.2148	2.1262	2.2502
10				2.1262	2.1794	2.2857	2.2502
11				2.1439	2.1794	2.3663	2.1794
12				2.2148	2.1794	2.4097	2.191
13				2.1971	2.1616	2.1262	2.2325
14				2.1085	2.0553	2.1262	2.1384
15				2.1262	2.073	2.0683	2.1033
21	1.6118	1.576	1.6118				
22	1.7551	1.7187	1.6301				
23	1.701	1.6832	1.5947				
24	1.5947	1.701	1.6301	1.5947			
Max	1.7551	1.7364	1.6301	2.2148	2.2148	2.4097	2.2502
Min	1.5947	1.576	1.5947	1.5947	2.0553	2.0199	2.0683
Avg	1.6476	1.6973	1.6177	2.0083	2.1417	2.1911	2.1767

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 065004 / 33 KV SAKOLI

Feeder No / Name : 203 / 11KV SAKOLI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6335	.6516	.6878	.724	.7421	.7164	1.0208
2	.6335	.6516	.6878	.6878	.7421	.7164	1.0208
3	.6335	.6516	.6878	.6401	.7421	.7164	1.0208
4	.6335	.6516	.6878	.6401	.7421	.7343	.8775
5	.6335	.6516	.6878	.6401	.724	.7343	.8059
6	.6335	.6516	.7059	.6401	.695	.7421	.7701
7	.6447	.6805	.7343	.7619	.7522	.7619	.8413
8	.7059	.788	.6836	.7865	.7701	.8596	.8589
9	.7796	.7442	.7712	.788	.8417	.8328	.8505
10	.7442	.8413	.7975	.7796	.8063	1.2226	.8682
11	.7373	.7975	.7888	.815	.8495	1.0642	.9189
12	.7628	.7802	.8413	.7973	.8495	.8764	.9015
13	.7545	.8589	.7712	.5373	.8495	.8495	.8842
14	.7545	.9391	.7362	.7712	.9114	.9362	.8669
15	.7442	.7973	.7888	.7888	.8764	.9015	.9816
16	.7975	.815	.8059	.8322	.8939	.8669	1.0166
17	.823	.8596	.8059	.7455	.9362	.9189	.9709
18	.823	.905	.8238	.9088	.8764	.9709	.9945
19	.9593	.9593	.9694	.9955	1.0317	1.0745	1.0924
20	.9231	.9231	.9328	.9774	.9774	1.0498	1.0745
21	.8413	.8962	.9145	.9145	.9511	.9955	1.0136
22	.8048	.823	.8779	.8869	.8775	.9593	.9774
23	.6878	.7133	.8048	.7964	.8238	1.0136	1.0679
24	.6335	.6516	.6878	.7602	.7421	.788	1.0208
Max	.9593	.9593	.9694	.9955	1.0317	1.2226	1.0924
Min	.6335	.6516	.6836	.5373	.695	.7164	.7701
Avg	.7384	.7784	.7784	.7756	.8335	.8876	.9465

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 065004 / 33 KV SAKOLI

Feeder No / Name : 204 / 11 KV LAKHANDUR FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0949	.1265	.0791	.1107	.1265	.1107	.0707
2	.0949	.1107	.0791	.1107	.1265	.1107	.1107
3	.0949	.1265	.0791	.1107	.1265	.1107	.1107
4	.0949	.1265	.0791	.1107	.1265	.0791	.1107
5	.0949	.1107	.1107	.1107	.1265	.0791	.1107
6	.0949	.1107	.1094	.1107	.1265	.0791	.1107
7	.1265	.1107	.1107	.0949	.2056	.0791	.1107
8	.1265	.1265	.1094	.1265	.1265	.1107	.1423
9	.0949	.1265	.0791	.0791	.1265	.1107	.1107
10	.1107	.1423	.1107	.1265	.1107	.1265	.1265
11	.1107	.1107	.1107	.1265	.1107	.1107	.1581
12	.1107	.1107	.1107	.1581	.1107	.1265	.1581
13	.1107	.1107	.1107	.1581	.1581	.1107	.1581
14	.1265	.1107	.1107	.1107	.1581	.1898	.1581
15	.1107	.1107	.1107	.1265	.1107	.1423	.1581
16	.1265	.1107	.1107	.1265	.1581	.1423	.1581
17	.1265	.1265	.1107	.1265	.1107	.1423	.1581
18	.1265	.1265	.1107	.1265	.1107	.1898	.1581
19	.0949	.1423	.1107	.1581	.1107	.0791	.1581
20	.0949	.1107	.1107	.1423	.1107	.0791	.1581
21	.1107	.1107	.1107	.1423	.1107	.1107	.1581
22	.1107	.1107	.1107	.1423	.1107	.1107	.0949
23	.1107	.1107	.1107	.0791	.1107	.1107	.1107
24	.125	.0949	.0791	.1107	.1265	.1107	.0791
Max	.1265	.1423	.1107	.1581	.2056	.1898	.1581
Min	.0949	.0949	.0791	.0791	.1107	.0791	.0707
Avg	.1093	.1173	.1027	.1219	.1265	.1147	.1308

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 065004 / 33 KV SAKOLI

Feeder No / Name : 205 / 11 KV EKODI FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4687	.5506	.5921	.6882	.7042	.6401	.7202
2	.4687	.5506	.5921	.6882	.7042	.6401	.7202
3	.4687	.5506	.5921	.6882	.7042	.6401	.7202
4	.4687	.5735	.5992	.6882	.7042	.6722	.7202
5	.4999	.5735	.6154	.6882	.7042	.6722	.7116
6	.5312	.5898	.639	.7042	.7125	.7042	.7116
7	.578	.664	.6642	.7099	.759	.7499	.8065
8	.5851	.7042	.703	.8097	.8322	.7842	.8223
9	.6405	.7522	.679	.8745	.8162	.7748	.8802
10	.7116	.7655	.759	.9282	.8223	.7968	.8802
11	.6718	.7499	.7562	.9442	.8749	.8065	.8592
12	.6472	.7253	.7562	.828	.8436	.8381	.884
13	.7316	.7316	.7716	.8124	.8381	.8025	.7562
14	.7164	.7225	.8124	.8592	.8333	.828	.8749
15	.8025	.7468	.8535	.8436	.8796	.8592	.8688
16	.7926	.7926	.7977	.8488	.8796	.8642	.8333
17	.7316	.7926	.8333	.8488	.8951	.8951	.8535
18	.7716	.7811	.8436	.8592	.8333	.8886	.8993
19	.8478	.8122	.9389	.8785	.9448	.9054	.9105
20	.78	.7164	.9054	.9054	.9054	.8179	.9282
21	.7122	.763	.8478	.8551	.8619	.8124	.9116
22	.6299	.663	.7625	.7865	.7935	.7865	.8192
23	.583	.6226	.7373	.7287	.7202	.7449	.7773
24	.4687	.5506	.5921	.6882	.7042	.6722	.7202
Max	.8478	.8122	.9389	.9442	.9448	.9054	.9282
Min	.4687	.5506	.5921	.6882	.7042	.6401	.7116
Avg	.6378	.6852	.7352	.7981	.8029	.7748	.8162

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 065004 / 33 KV SAKOLI

Feeder No / Name : 206 / 11 KV SHENDURWAFI GT.

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0719	1.1088	1.1827	1.1576	1.3121	1.3306	1.2752
2	1.0719	1.1088	1.1827	1.1576	1.3121	1.3306	1.2752
3	1.0719	1.1203	1.1827	1.1576	1.3121	1.3306	1.2752
4	1.0719	1.1389	1.1949	1.1576	1.3121	1.3306	1.2752
5	1.0719	1.1389	1.2323	1.1576	1.3121	1.3306	1.2752
6	1.1088	1.1389	1.251	1.1576	1.3443	1.3306	1.2567
7	1.2197	1.2567	1.2752	1.1827	1.3169	1.3535	1.2986
8	1.2197	1.3676	1.2437	1.2197	1.3169	1.39	1.3394
9	1.1706	1.3756	1.2254	1.2197	1.3756	1.2851	1.3169
10	1.2071	.8507	1.2803	1.2071	1.3032	1.2489	1.3169
11		.9774	1.3394	1.2308	1.2894	1.0208	1.1706
12	.5218	1.086	1.2437	1.2308	1.2536	1.267	1.2894
13	.8779	1.1222	1.1523	1.2308	1.2178	1.2308	1.2308
14	.9328	1.1765	1.1458	1.1584	1.2971	1.2308	1.3213
15	.905	1.1765	.9055	1.1765	1.2357	1.2489	1.2934
16	.9412	1.1946	.8413	1.1765	1.2489	1.4299	1.3611
17	1.086	1.2437	1.1765	1.1641	1.3253	1.5023	1.3611
18	1.267	1.3169	1.1888	1.2489	1.3717	1.6108	1.3756
19	1.5684	1.419	1.4377	1.6078	1.6448	1.5746	1.7002
20	1.4937	1.5123	1.4377	1.5893	1.6263	1.587	1.6263
21	1.363	1.4563	1.3817	1.5524	1.5708	1.4937	1.5524
22	1.2323	1.307	1.2883	1.423	1.4784	1.4377	1.46
23	1.1389	1.2567	1.2323	1.3491	1.419	1.3443	1.386
24	1.0719	1.1088	1.1827	1.1949	1.3121	1.363	1.2752
Max	1.5684	1.5123	1.4377	1.6078	1.6448	1.6108	1.7002
Min	.5218	.8507	.8413	1.1576	1.2178	1.0208	1.1706
Avg	1.1168	1.2066	1.2169	1.2545	1.3545	1.3584	1.3462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391] BU 0391

Substation No/ Name :- 065004 / 33 KV SAKOLI

Feeder No / Name : 207 / STATION TF

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.0191		.0137		
10	.041	.0381		.0413		.0137	.0297
Max	.041	.0381	.0191	.0413	.0137	.0137	.0297
Min	.041	.0381	.0191	.0413	.0137	.0137	.0297
Avg	.041	.0381	.0191	.0413	.0137	.0137	.0297

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 067010 / 132 KV SAKOLI

Feeder No / Name : 401 / SAKOLI -I

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5252	2.9235	2.8704	1.4352	1.4352	1.5775	1.7541
2	2.4983	2.8704	2.8172	1.382	1.4883	1.5775	1.6975
3	2.4983	2.8704	2.7869	1.382	1.4883	1.5775	1.6409
4	2.4983	2.8704	2.8172	1.382	1.4883	1.4723	1.6409
5	2.5514	2.8704	2.8172	1.382	1.4883	1.4723	1.6409
6	2.7401	3.0624	2.9767	1.4506	1.5581	1.5415	1.5947
7	1.3289	1.5947	1.5947	1.5604	1.6301	1.7164	1.7684
8	1.4723	1.701	1.6827	3.4705	3.7449	3.8489	3.9009
9	1.6124	1.7878	1.7164	1.8204	3.8489	4.0049	4.213
10	1.7353	1.8204	1.7684	4.0049	4.0049	4.265	4.2181
11	1.6644	1.8204	1.8004	4.0569	4.1152	4.421	4.1667
12	1.6975	1.8204	1.8724	4.0569	4.0638	4.473	4.0638
13	1.749	1.8519	1.8724	3.9529	4.161	4.0569	4.1152
14	1.749	1.8519	1.8204	3.9009	3.9609	4.1667	4.1667
15	1.7295	1.6975	1.8519	3.9609	3.9609	4.1152	4.1667
16	1.6975	1.8004	1.8313	1.9547	2.0062	2.2119	2.0856
17	1.6975	1.3003	1.6975	2.0062	1.8519	2.2119	2.1365
18	1.7684	1.7164	1.7164	1.9033	1.9033	1.9033	2.1365
19	1.8461	1.8267	1.8267	1.8804	1.9136	1.9667	2.1559
20	1.7375	1.773	1.773	1.8804	1.8804	1.9136	2.0508
21	3.1161	3.1699	3.2773	1.773	1.8804	1.8267	2.0199
22	3.1699	3.1361	3.1361	1.6655	1.773	1.7541	1.8604
23	2.9767	3.083	3.083	1.5415	1.6478	1.701	1.8073
24	2.5514	2.9235	2.8704	2.9767	1.5415	1.5947	1.6478
Max	3.1699	3.1699	3.2773	4.0569	4.161	4.473	4.2181
Min	1.3289	1.3003	1.5947	1.382	1.4352	1.4723	1.5947
Avg	2.1088	2.2560	2.2615	2.3658	2.4515	2.5571	2.6104

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 067010 / 132 KV SAKOLI

Feeder No / Name : 402 / 33 KV WADAD

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.8426	3.9849	4.0329	3.8255	3.7357	3.7849	3.7357
2	3.7026	3.9369	3.9375	3.3916	3.7357	3.7849	3.6866
3	3.7026	3.8409	3.9375	3.3916	3.4899	3.6866	3.6374
4	3.7026	3.8426	3.9375	3.3425	3.5391	3.5391	3.5883
5	3.7494	3.8889	3.9375	3.3425	3.5391	3.4408	3.5883
6	3.9849	4.1781	4.0324	3.4808	3.7723	3.7294	3.7357
7	.8939	1.0208	.9568	.9362	1.0099	.9465	.9991
8	3.3425	3.5391	3.6437	4.5668	4.465	4.561	4.4593
9	3.3522	2.2685	3.838	4.6571	4.465	4.561	4.561
10	3.6214	2.7183	3.7849	3.9352	4.7611	4.9068	4.7051
11	3.4494	3.7894	3.7849	4.9554	3.3522	4.9554	4.7531
12	3.6374	3.6866	3.8832	4.8097	3.3522	4.9068	4.6016
13	3.6374	3.5465	3.7894	4.8011	3.4008	3.4979	5.8493
14	2.6852	3.6969	3.834	4.7051	3.4008	3.4979	6.2186
15	2.3777	3.5528	3.6923	4.7531	4.561	3.4979	6.4615
16	1.8073	1.6827	.7202	.8413	1.9919	.8505	2.7446
17	1.893	1.0985	.7716	.8322	2.0405	2.0405	2.8567
18	1.9667	.9465	.9882	1.1191	2.1862	2.1862	2.9687
19	1.6804	1.6804	1.6804	1.7924	1.7741	2.9127	4.1307
20	1.6244	1.6632	1.6804	1.7364	1.7924	1.7364	4.0175
21	4.3759	4.3261	4.5748	4.1667		4.0695	6.286
22	4.3256	4.2753	4.421	4.0741	4.1244	4.0238	5.9637
23	4.0809	4.0809	4.3239	3.9283	3.9283	3.8289	5.6876
24	3.89	3.9849	4.0809	3.4465	3.7792	3.8289	3.7792
Max	4.3759	4.3261	4.5748	4.9554	4.7611	4.9554	6.4615
Min	.8939	.9465	.7202	.8322	1.0099	.8505	.9991
Avg	3.1386	3.1346	3.2610	3.3680	3.3129	3.4489	4.2923

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 067010 / 132 KV SAKOLI

Feeder No / Name : 403 / SAKOLI II

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4661	1.5746	1.6832	1.701	1.8804	1.9342	1.9342
2	1.3969	1.5746	1.6289	1.6461		1.9342	1.8804
3	1.3969	1.5203	1.6118	1.6289	1.8267	1.8604	1.8804
4	1.3969	1.5203	1.6118	1.5912	1.8267	1.8804	1.8267
5	1.4661	1.5203	1.6289	1.6461	1.8267	1.8804	1.8267
6	1.5364	1.6461	1.7558	1.6461	1.9004	1.8804	1.9342
7	1.6118	1.6655	1.7541	1.6655	1.9136	1.9982	1.893
8	1.7375	1.9342	1.701	1.7918	1.9667	2.073	2.073
9	1.8073		1.8404	1.8604	2.073	1.9982	2.1262
10	1.773	1.9982	1.9982	1.893	2.0508	1.9456	2.0285
11	.9122	1.8724	1.8724	1.7353	2.0576	2.1605	2.1845
12	1.086	1.8204	1.893	1.9667	2.1325	2.0805	2.1091
13	1.5249	1.7684	1.8404	1.7353	1.9765	1.9244	2.0285
14	1.5604	1.8204	1.7353	1.9982	1.9547	1.0814	2.0576
15	1.6124	1.8519	1.5415	1.9244	1.9765	2.1325	2.1605
16	1.6301	1.8004	1.5083	1.9244	1.8404	1.9982	2.2885
17	1.6461	1.9033	1.8204	1.8519	2.1325	2.0285	2.3148
18	1.9033	1.9244	1.7878	1.9765	2.1559	2.0805	2.2634
19	2.3594	2.3348	2.2497	2.4977	2.552	2.4977	2.6326
20	2.2497	2.2805	2.1948	2.4434	2.4977	2.4434	2.5789
21	2.1068	2.1399	2.1622	2.3594	2.3891	2.3594	2.4434
22	1.8656	1.9753	2.0513	2.1719	2.2805	2.2262	2.2805
23	1.6832	1.7918	1.8656	2.009	2.1176	2.0633	2.1176
24	1.5203	1.6289	1.7375	1.7558	1.9342	1.9879	1.9342
Max	2.3594	2.3348	2.2497	2.4977	2.552	2.4977	2.6326
Min	.9122	1.5203	1.5083	1.5912	1.8267	1.0814	1.8267
Avg	1.6354	1.8203	1.8114	1.8925	2.0549	2.0187	2.1166

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 067010 / 132 KV SAKOLI

Feeder No / Name : 404 / 33 KV PARASTOLA

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.4019	3.9638	4.137	3.3311	3.3848	3.3665	3.4385
2	3.4019	3.9095	4.0832	3.2773	3.3311	3.3665	3.4385
3	3.4019	3.8552	4.0295	3.2773	3.3311	3.2579	3.3848
4	3.4019	3.9095	4.0295	3.2773	3.3311	3.2579	3.3311
5	3.4568	3.9095	4.137	3.3122	3.4751	3.2579	3.4385
6	3.77	4.225	4.561	3.4751	3.5837	3.4568	3.638
7	2.0416	2.2611	2.4714	2.4446	2.4446	2.4983	2.5486
8	3.271	3.6534	3.7209	4.9966	5.3635	5.2624	5.048
9	3.5117	3.8803	3.8803	5.4161	4.6776	4.3439	5.2584
10	3.0727	3.8386	4.0489	5.5213	5.2092	5.4218	5.3109
11	3.2956	4.213	4.2067	5.5739	4.7325	5.5739	5.2584
12	3.5614	4.1541	3.0687	3.9735	5.5133	5.679	5.4092
13	3.5082	4.1015	4.2067	5.6173	5.4613	5.6173	5.3572
14	3.2425	3.8912	4.0489	5.7213	5.4613	4.7308	4.8371
15	3.3488	3.9009	4.0049	4.8903	5.4613	5.4161	5.2532
16	2.2119	2.4926	2.6355	2.7263	2.5486	2.7046	2.5943
17	2.3663	2.6235	2.6749	2.7469	2.572	2.6006	2.5943
18	2.2085	2.7566	2.7566	2.7263	2.7343	2.7778	2.696
19	2.9938	3.3122	3.3665	3.3665	3.4019	3.4208	3.4385
20	2.9938	3.1493	3.2579	3.3122	3.2922	3.3665	3.2773
21	4.7125	4.8285	5.2126	4.0604	4.0055	4.1152	4.0181
22	4.3347	4.4525	4.8868	3.6923	3.7311	3.8552	3.7466
23	4.0181	4.2896	4.6742	3.5294	3.5294	3.5997	3.5294
24	3.5117	4.0181	4.137	3.9335	3.4208	3.4208	3.546
Max	4.7125	4.8285	5.2126	5.7213	5.5133	5.679	5.4092
Min	2.0416	2.2611	2.4714	2.4446	2.4446	2.4983	2.5486
Avg	3.2933	3.7329	3.8432	3.9250	3.9166	3.9320	3.9330

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 067010 / 132 KV SAKOLI

Feeder No / Name : 405 / 33 KV ARJUNI MORGAON
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.7551	3.3436	3.786	4.0472	4.5542	4.4993	3.8649
2	3.6626	3.2407	3.8089	3.9363	4.5542	4.3896	4.0604
3	3.6117	3.2407	3.6969	3.7134	4.4993	4.269	4.0055
4	3.6626	3.1893	3.6591	3.7134	4.4445	4.3244	4.0055
5	3.7551	3.2407	3.7146	3.7134	4.4353	4.3244	4.0055
6	4.0049	3.6408		4.0049	4.768	4.6016	4.1581
7	4.1701	3.8958	3.8409	4.0055	4.6639	4.6639	3.8552
8	4.225	3.9506	4.0724	4.3896	4.784	4.561	4.5182
9	4.7239	4.181	4.2353	4.181	5.1578	3.4168	4.6205
10	5.2652	4.561	4.3896	4.6153	5.5876	5.3155	4.9966
11	4.137	4.7279	4.5068	4.7782	5.3687	4.6776	4.8891
12	5.1029	4.6205	4.9411	4.7782	5.3155	5.4801	4.9966
13	4.8903	4.513	4.561	4.8868	5.4218	5.2115	2.7778
14	4.8354	4.4056	4.2896	4.6153	5.2092	5.2652	2.696
15	4.8371	4.2896	4.4445	4.6153	5.2115	5.2652	2.7978
16	4.465	4.513	4.3519	5.0497	5.2115	5.1578	2.4691
17	4.6245	4.3587	4.1267	4.9966	5.104	5.2092	2.7664
18	4.6245	4.4056	4.3347	5.0497	5.104	5.2092	2.8166
19	5.3212	5.4887	5.4332	5.5996	5.8162	5.8162	3.4551
20	4.9851	5.2115	5.1532	5.5996	5.655	5.5967	3.4019
21	4.5931	4.8171	4.9851	5.2669	5.2652	5.2115	3.083
22	3.9769	4.3244	4.4907	4.768	5.1006	4.9897	2.8172
23	3.5848	3.9918	4.269	4.8234	4.7188	4.6639	2.6292
24	3.9363	3.7346	3.9209	3.9758	4.6571	4.6091	4.4445
Max	5.3212	5.4887	5.4332	5.5996	5.8162	5.8162	4.9966
Min	3.5848	3.1893	3.6591	3.7134	4.4353	3.4168	2.4691
Avg	4.3646	4.1619	4.3049	4.5468	5.0253	4.8637	3.6721

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 067010 / 132 KV SAKOLI

Feeder No / Name : 409 / 33KV SOUNDAD FEEDER
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1203	1.2883	1.4815	1.6118	1.6461	1.9244	1.7295
2	1.1203	1.2883	1.4815	1.6118	1.6461	1.9033	1.749
3	1.1203	1.2323	1.4266	1.6118	1.5203	1.8519	1.6787
4	4.425	1.2323	1.4815	1.5581	1.5203	1.8004	1.6095
5	1.0642	1.2323	1.4266	1.386	1.5364	1.8004	1.6598
6	1.2449	1.3443	1.4969	1.4969	1.5912	1.8204	1.749
7	1.3717	1.5203	1.6655	1.701	1.701	1.9616	1.861
8	.7122	1.6478	1.7353	1.7878	1.6827	2.0119	1.989
9	.9717	1.6827	1.7353	1.7353	1.7684	2.0885	2.0119
10	1.6289	1.6827	1.8404	1.8724	1.9033	2.2377	2.0891
11	1.7353	1.9456	1.893	1.9982	2.0348	2.3594	2.0153
12	1.9667	.9831	2.0285	2.0508	2.0576	2.4366	2.1376
13	1.9982	1.8204	2.0576	2.1325	2.0805	2.4577	2.1376
14	1.9456	1.7684	1.9244	2.0285	1.8724	2.332	2.1862
15	1.7164	1.7804	1.9839	1.9765	1.8004	2.4777	2.1605
16	1.8404	.7773	2.1605	2.0062	1.8519	2.6052	2.1136
17	1.9456	1.7684	2.0576	1.9244	1.4529	2.556	2.0891
18	1.5203	1.6827	2.0285	1.8404	1.8679		2.1628
19	1.8296	1.8107	1.9547	1.8656	2.1325	2.3926	2.0285
20	1.6078	1.6832	1.8461	1.7558			1.9765
21	1.5123	1.6244	1.7375	1.6461	2.0508	1.9982	1.893
22	1.2883	1.4815	1.6832	1.6461	2.0805	1.8724	1.8404
23	1.3443	1.5364	1.6832	1.701	2.0285	1.8004	1.7164
24	1.1203	1.2883	1.5364	1.6655	1.6461	1.9547	1.749
Max	4.425	1.9456	2.1605	2.1325	2.1325	2.6052	2.1862
Min	.7122	.7773	1.4266	1.386	1.4529	1.8004	1.6095
Avg	1.5896	1.5043	1.7644	1.7754	1.8032	2.1202	1.9305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 067010 / 132 KV SAKOLI

Feeder No / Name : 410 / 33 KV SATALWADA

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0185	1.1317	1.1763	.9054	.9619	1.0288	1.0751
2	1.0185	1.1317	1.1317	.8488	.9054	1.0288	1.0751
3	1.0185	1.1317	1.1203	.8488	.9054	.9717	1.0751
4	1.0185	1.1317	1.1203	.8488	.9054	1.0288	1.0185
5	1.1317	1.1883	1.1203	.9054	.9619	1.0288	1.086
6	1.2449	1.358	1.1883	1.0185	1.0751	1.2003	1.2003
7	.823	.8871	1.3443	1.0185	1.0185	1.086	1.1431
8	.9619	1.086	1.086	1.701	1.701	1.9342	1.9879
9	1.0185	1.1317	1.1317	1.9004	1.8461	2.0416	2.1794
10	1.0288	1.1317	.4527	1.9342	1.9342	1.9342	2.1559
11	.9619	1.1317	.9619	1.9879	1.8804	1.8804	2.1033
12	.9717	1.0751	1.1883	1.9342	1.8804	1.9342	2.1559
13	1.0185	1.0185	1.1317	1.9342	1.8267	1.9667	2.0508
14	1.0185	1.0185	1.2449	1.8804	1.773	1.9342	1.9982
15	1.0185	1.0185	1.1883	1.8267	1.773	1.9879	1.9982
16	.8488	.9145	1.1317	1.1883	.9717	1.1883	1.2449
17	.8488	.9717	1.086	1.1317	1.0751	1.2449	.3064
18	.9054	.9054	1.0185	1.1431	1.086	1.2449	1.358
19	1.2323	1.1763	1.3014	1.2483	1.0751	1.4861	1.5432
20	1.1088	1.1643	1.1763	1.2323	1.3014	1.358	1.4289
21	1.4146	1.4712	1.5844	1.2449	1.3146	1.3717	1.4146
22	1.3014	1.358	1.4003	1.1317	1.1431	1.2574	1.2449
23	1.1883	1.2323	1.3443	.9619	1.086	1.0745	1.1431
24	1.0751	1.1317	1.1763	1.2883	.9619	1.0288	1.0751
Max	1.4146	1.4712	1.5844	1.9879	1.9342	2.0416	2.1794
Min	.823	.8871	.4527	.8488	.9054	.9717	.3064
Avg	1.0498	1.1207	1.1586	1.3360	1.3068	1.4267	1.4609