

Minutes of Meeting - Pre bid

TENDER NO :EEC/BND/TECH/125/201920 :

“ To revamp and re-design the central air-conditioning system to improve performance inside Prakashgad Bldg ”

Location: Prakashgad
6th floor conference
Hall.

Time: 12.00 Hrs am to 13.00 Hrs

Date - 17/03/2020

Subject: Pre bid

MEETING CALLED BY	EE (Civil)
TYPE OF MEETING/REFERENCE	Pre bid on -To revamp and re-design the central air-conditioning system to improve performance inside Prakashgad Bldg
FACILITATOR	EE (CIVIL)
NOTE TAKER	Nayan Bhatarkar . AE(Dist), Electrical Maintenance Wing, MSEDCL
ATTENDEES MSEDCL	Shri. Ashish Bhongade Addl .Ex Engineer (Dist), Electrical Maintenance Wing Bandra , Shri. Vasant Chavan, Executive Engineer (Civil), Bandra Division.
ATTENDEES FROM BIDDERS(SIFY)	Mentioned on last page.
ATTENDEES FROM CONSULATANT	Shri. Rakesh Desai from M/s ECPL

The following Points are discussed from the prospective bidders and clarified as above.

- 1) Agency need to quote the make of chiller (from approved make only) during bidding and shall be adhered to same make during execution and no permission will be granted for change in make of chiller post bid.
- 2) For rest of the items (CTs, AHUs, Pumps etc) bidder need to quote the make, however can be changed from approved make only post bid.
- 3) ASME standard for chiller shall be applicable as per tender documents, no deviation permitted, however bidder can give parallel code for chiller.

- 4) Two separate independent circuits for chiller need to be provided 175 TR x 2 nos.
- 5) The prospective bidder need to visit the site for inspection of old equipment and for proposed installation, as bidder need to take old equipment (Kirloskar make chillers , AHUs, ductable package units etc) under CAMC services for 6 years (during DLP and CAMC services), bidder need to upload the site survey report as per Annexure mentioned in the tender documents, if not uploaded bid will be disqualified. - Already mentioned in the tender
- 6) NO CHANGE IN ANY MAKE OR ADDITION OF ANY NEW MAKE OF ANY PRODUCT IS ALLOWED/PERMITTED.
- 7) Chiller CMAC services during DLP and CAMC period shall be given to only OEMs of chillers and contract copy (hidden prices) shall be submitted to MSEB HCL post bid.
- 8) There will be no extension in the submission dates.

sd

Executive Engineer (Civil),
Civil Division, Bandra

BIDDER ATTENDIES

PREBID MEETINTG		Date: 17/03/2020	
SUBJECT: Revamping and redesign of Central Air -conditioning system (HVAC) at MSEB HCL corporate office Prakashgad,Bandra to improve the performance.			
Name of Agency	Mobile no.	Email id	Remark
(1) BMH Technologies	9890864636	amol@bmhtechnologies.co	closed
(2) VAV Air-conditioning	8082074467	sales@vavaircon.com	closed
(3) Carrier	8657495556	chintan.solenui@carrier.com	closed
(4) Blue Star	7045592636	nileshnalhe@bluestarindia.com	closed
(5) Krishna Refrigeration	9699141313 9136009506	askalraa@gmail.com	closed
(6) Easy cool system	9820651267	easycool@gmail.com	closed