

Feeder wise AT&C loss report (10% worst Feeders)

Level of Monitoring: PFC/MoP

Format: D4

| State: MAHARASHTRA | | | | | | | | | | | | | | |
|--------------------------|-------------|--------------|--------------------------------|--------------------------------|---------------------------|--------------|------------------------------|--------------------------------|---------------------------|--------------|-----------------------------|--------------------------------|---------------------------|--------------|
| Discom: MSEDCL | | | | | | | | | | | | | | |
| Month: Nov'19 | | | | | | | | | | | | | | |
| Period: Sep'18 to Aug'19 | | | | | | | | | | | | | | |
| Sr No | Town Name | Total Feeder | Feeder Name1 | Cumulative Billing Efficiency, | | | Feeder Name2 | Cumulative Billing Efficiency, | | | Feeder Name3 | Cumulative Billing Efficiency, | | |
| | | | | Billing Efficiency (%) | Collection Efficiency (%) | AT&C Loss(%) | | Billing Efficiency (%) | Collection Efficiency (%) | AT&C Loss(%) | | Billing Efficiency (%) | Collection Efficiency (%) | AT&C Loss(%) |
| 51 | Kamptee | 10 | 11 KV KAMPTEE II | 42.61 | 97.96 | 58.26 | | | | | | | | |
| 52 | Kannad | 4 | TOWN 3 | 23.16 | 100 | 76.84 | | | | | | | | |
| 53 | Karad | 8 | 11 KV NAGARPALIKA | 76.42 | 96.77 | 26.05 | 11 KV WAKHAN ROAD | 87.01 | 94 | 18.21 | 11 KV MARKET YARD | 88.8 | 95.53 | 15.17 |
| 54 | Karanja | 10 | 11 KV GAWALIPURA FEEDER | 42.02 | 96.63 | 59.4 | 11 KV WATER SUPPLY FEEDER | 66.85 | 100 | 33.15 | 11 KV MANORA ROAD FEEDER | 100 | 97.01 | 2.99 |
| 55 | Katol | 5 | 11 KV LAXMINAGAR | 81.9 | 94.11 | 22.92 | 11 KV IUDP FEEDER | 85.7 | 98.88 | 15.26 | 11 KV BUS STAND | 90.85 | 95.85 | 12.92 |
| 56 | Khamgaon | 16 | 33 KV HLL | 20.96 | 90.3 | 81.07 | 11 KV SAJANPURI | 43.58 | 91.27 | 60.22 | 11 KV OMKARESHWAR | 40.12 | 100 | 59.88 |
| 57 | Khopoli | 6 | 22 KV KHOPOLI RURAL | 33.98 | 93.26 | 68.31 | 22 KV KHOPOLI TOWN | 86.16 | 100 | 13.84 | 22 KV SHILPHATA | 100 | 96.6 | 3.4 |
| 58 | Kolhapur | 91 | 11KV SWARAJ | 66.04 | 97.14 | 35.85 | 11KV ULAPEMALA | 70.55 | 95.34 | 32.74 | BHAVANI MANDAP | 78.04 | 98.78 | 22.91 |
| 59 | Kopargaon | 6 | 11 KV KOPERGAON URBAN | 94.75 | 95.63 | 9.39 | 11 KV WATER SUPPLY | 92.88 | 100 | 7.12 | | | | |
| 60 | Latur | 33 | 11 KV SHIDDHESHWAR | 60.66 | 91.89 | 44.26 | 11 KV TOWN | 72.41 | 98.66 | 28.56 | 11 KV BABHALGAON | 85.74 | 98.92 | 15.19 |
| 61 | Lonavala | 13 | 22 KV CITY - II | 26.68 | 91.52 | 75.58 | 22 KV KURWANDE (R) | 79.27 | 96.25 | 23.7 | 22 KV LONAVALA BAZAR | 76.74 | 100 | 23.26 |
| 62 | Majalgaon | 3 | 11KV MANJRATH | 52.15 | 100 | 47.85 | 11KV MAJALGAON | 68.92 | 99.04 | 31.74 | | | | |
| 63 | Malegaon | 30 | SHABBIR NAGAR | 31.76 | 100 | 68.24 | CHANDANPURI | 32.59 | 100 | 67.41 | MACCHI BAJAR FEEDER | 33.67 | 100 | 66.33 |
| 64 | Malkapur | 9 | 11 KV INDUSTRIAL | 24.44 | 100 | 75.56 | 11 KV YASHODHAM | 43.02 | 99.88 | 57.03 | 11 KV WATER FILTER EXP | 58.27 | 100 | 41.73 |
| 65 | Manmad | 9 | HUDCO URBAN | 40.31 | 97.14 | 60.84 | HANUMAN NAGAR | 42.85 | 100 | 57.15 | 11KV MANMAD U 2 | 45.89 | 100 | 54.11 |
| 66 | Mehkar | 3 | 11 KV MEHKAR TOWN 2 | 69.38 | 100 | 30.62 | 11 KV MEHKAR TOWN 1 | 81.55 | 97.6 | 20.41 | | | | |
| 67 | Morshi | 4 | 11 KV RAMJI BABA | 79.27 | 100 | 20.73 | 11 KV TAJ COLONY | 83.86 | 100 | 16.14 | 11 KV FAUJI COLONY | 85.77 | 99.47 | 14.68 |
| 68 | Murtijapur | 7 | 11 KV PUNDLIK NAGAR | 64.61 | 97.01 | 37.32 | 11KV TOWN-1 | 77.61 | 100 | 22.39 | 11KV GOYANAKA FDR | 80.79 | 96.52 | 22.02 |
| 69 | Nagpur | 121 | 11KV EKATMATA NAGAR FDR | 36.36 | 100 | 63.64 | 11KV BULDI | 53.16 | 98.95 | 47.4 | 11 KV RC PLASTO | 100 | 86.87 | 13.13 |
| 70 | Nalasopara | 15 | MANVELPADA SUBSTN | 44.31 | 93.77 | 58.45 | 22KV VASANT NAGARI FEEDER | 75.66 | 76.76 | 41.92 | 22 KV WATAR FEEDER | 79.85 | 92.64 | 26.03 |
| 71 | Nanded | 64 | 11 KV TOWER | 36.14 | 96.1 | 65.27 | 11 KV BAFNA | 51.01 | 92.25 | 52.94 | 11 KV MAHALAJ - SANGVI | 58.6 | 80.63 | 52.75 |
| 72 | Nandura | 4 | JALAGAON ROAD FEEDER | 59.35 | 100 | 40.65 | 11 KV TOWN | 75.61 | 100 | 24.39 | 11 KV BALAJI | 100 | 88.43 | 11.57 |
| 73 | Nandurbar | 12 | LONKHEDA AG | 62.3 | 82.97 | 48.31 | 11 KV KANYADAN | 65.55 | 89.98 | 41.02 | ZARALI | 68.88 | 100 | 31.12 |
| 74 | Nashik | 175 | 11KV EKTA | 50.14 | 100 | 49.86 | 11 KV GOREWADI | 53.09 | 94.71 | 49.72 | 11 KV ICCHAMANI | 64.5 | 97.3 | 37.24 |
| 75 | Navi Mumbai | 258 | 11KV SBI I | 23.52 | 100 | 76.48 | 11KV FRUIT MARKET | 29.21 | 96.19 | 71.9 | 11 KV SEC-5 PLOT NO-70 ULWE | 61.1 | 99.1 | 39.45 |
| 76 | Nilanga | 3 | NEW COURT FEEDER | 62.73 | 100 | 37.27 | NEW BANK COLONY | 70.81 | 96.54 | 31.64 | | | | |
| 77 | Osmanabad | 13 | NEW COLLECTOR OFFICE | 55.66 | 90.36 | 49.71 | 11 KV NEHARU CHOWK FEEDER | 53.69 | 95.13 | 48.92 | 11 KV VAIRAG NAKA | 100 | 74.26 | 25.74 |
| 78 | Ozar | 6 | JAULKE | 42.14 | 98.81 | 58.36 | OZAR | 92.4 | 87.5 | 19.15 | | | | |
| 79 | Pachora | 8 | 11 KV CHATRAPATI SHIVAJI NAGA | 74.14 | 91.19 | 32.39 | 11 KV PANDAV NAGARI FEEDER | 78.95 | 88.96 | 29.77 | | | | |
| 80 | Paitan | 4 | RAPDRP POWER HOUSE | 51.4 | 94.94 | 51.2 | 11KV NATH MANDIR | 57.6 | 88.62 | 48.95 | RAPDRP NEW KAWSAN | 59.25 | 94.27 | 44.15 |
| 81 | Palghar | 14 | DIVISION OFFICE | 35.91 | 97.69 | 64.92 | 11 KV CHINTUPADA | 59.2 | 98.93 | 41.43 | 11 KV PALGHAR FEEDER | 90.58 | 100 | 9.42 |
| 82 | Pandharpur | 11 | DARSHAN MANDAP | 53.57 | 100 | 46.43 | 11 KV ISBAWI | 79.43 | 96.81 | 23.1 | 11 KV AMBIKA | 82.69 | 96.9 | 19.87 |
| 83 | Panvel | 119 | NERE | 72.81 | 91.04 | 33.71 | 11KV OUTGOING FEEDER 10 | 77.6 | 100 | 22.4 | ONGC-2 FEEDER | 87.13 | 95.31 | 16.96 |
| 84 | Parbhani | 22 | 11 KV TOWN I FEEDER | 48.49 | 92.79 | 55.01 | 11 KV SUPER MARKET FEEDER | 55.72 | 92.3 | 48.57 | 11 KV SHIVAJI CHOWK | 65.79 | 98.78 | 35.01 |
| 85 | Parli | 7 | 11 KV GANESHPAR FEEDER | 52.85 | 93.44 | 50.62 | 11 KV BUS STAND | 65.95 | 92.97 | 38.69 | | | | |
| 86 | Parola | 4 | 11 KV PAROLA URBAN FEEDER | 70.29 | 96.27 | 32.33 | 11KV JHAPATBHAWANI | 87.19 | 97.74 | 14.78 | | | | |
| 87 | Pathri | 3 | 11 KV PATHRI-II | 100 | 65.72 | 34.28 | | | | | | | | |
| 88 | Pen | 2 | 22 KV MAHADA | 79.66 | 91.27 | 27.29 | | | | | | | | |
| 89 | Phaltan | 3 | 22KV Y. C. HIGHSCHOOL | 100 | 95.39 | 4.61 | | | | | | | | |
| 90 | Pulgaon | 6 | MEDICAL | 63.65 | 100 | 36.35 | PULGAON TOWN | 82.74 | 96.84 | 19.87 | | | | |
| 91 | Pune City | 718 | 11 KV ESHA RAYKARMALA | 50.57 | 100 | 49.43 | 22 KV ELEMENTO | 60.91 | 100 | 39.09 | KUNDAN KUSHAL | 64.02 | 100 | 35.98 |
| 92 | Purna | 5 | 11 KV ANAND NAGAR (PURNA TOWN) | 57.56 | 81.86 | 52.88 | | | | | | | | |
| 93 | Pusad | 5 | 11 KV ITAWA | 37.11 | 93.77 | 65.2 | 11 KV TOWN 2 | 49.75 | 97.51 | 51.49 | 11 KV KAKADDATI | 54.92 | 97.64 | 46.38 |
| 94 | Ratnagiri | 21 | 11KV MIRJOLE VILLEGE RTN-U | 33.56 | 97.17 | 67.39 | 11 KV SHIVAJINAGAR RTN-U | 50.42 | 100 | 49.58 | 11KV SHIRGAON RTN-U | 98.98 | 95.9 | 5.08 |
| 95 | Sailu | 6 | 11KV MARWAD GALLI FEEDER | 28.42 | 100 | 71.58 | 11KV RAILWAY STATION FEEDER | 49.76 | 98.96 | 50.76 | 11KV TOWN-1 | 80.13 | 99.66 | 20.14 |
| 96 | Sangamner | 7 | 11 KV MALDAD GAVTHAN | 25.84 | 85.91 | 77.8 | 11KV GHULEWADI | 69.82 | 85.22 | 40.5 | 11 KV MIDC | 81.28 | 95.29 | 22.55 |
| 97 | Sangli | 83 | 11KV JACKWELL LIS | 19.2 | 97.93 | 81.2 | 11 KV DEVIKA | 22.22 | 97.05 | 78.44 | 11KV GULMOHAR | 22.58 | 97.32 | 74.13 |
| 98 | Satana | 2 | 11 KV SATANA (U) FEEDER | 68.11 | 95.91 | 34.68 | 11 KV MAHALAXMI FEEDER | 81.37 | 96.36 | 21.59 | | | | |
| 99 | Satara | 26 | 33 KV COOPER | 59.71 | 98.59 | 41.13 | 22 KV S. T. STAND | 72.94 | 99.78 | 27.22 | DEGAON GAONTHAN | 96.52 | 80.66 | 22.15 |
| 100 | Shahada | 3 | 11 KV OUTGOING KUKDEL FEEDER | 41.2 | 95.42 | 60.69 | 11 KV OUTGOING MALONI FEEDER | 52.65 | 92.97 | 51.05 | 11 KV OUTGOING VIKAS FEEDER | 79.91 | 93.58 | 25.22 |

Feeder wise AT&C loss report (10% worst Feeders)

Level of Monitoring: PFC/MoP

Format: D4

State: MAHARASHTRA

Discom: MSEDCL

Month: Nov'19

Period: Sep'18 to Aug'19

| Sr No | Town Name | Total Feeder | Feeder Name1 | Cumulative Billing Efficiency, | | | Feeder Name2 | Cumulative Billing Efficiency, | | | Feeder Name3 | Cumulative Billing Efficiency, | | |
|-------|---------------|--------------|------------------------------|--------------------------------|---------------------------|--------------|----------------------------|--------------------------------|---------------------------|--------------|-------------------------|--------------------------------|---------------------------|--------------|
| | | | | Billing Efficiency (%) | Collection Efficiency (%) | AT&C Loss(%) | | Billing Efficiency (%) | Collection Efficiency (%) | AT&C Loss(%) | | Billing Efficiency (%) | Collection Efficiency (%) | AT&C Loss(%) |
| 101 | Shegaon | 6 | 11KV TOWN II | 67.81 | 100 | 32.19 | 11KV TOWN I | 72.7 | 100 | 27.3 | 11 KV GM MANDIR | 90.12 | 99.92 | 9.95 |
| 102 | Shirpur | 6 | 11 KV KARWAND NAKA | 57.8 | 95.89 | 44.58 | 11 KV MAIN ROAD | 85.98 | 95.48 | 17.91 | TOWN COLONY | 85.95 | 97.35 | 16.33 |
| 103 | Sillod | 6 | TILAKNAGAR | 55.2 | 91.97 | 49.23 | TOWN 1 | 59.61 | 85.85 | 48.82 | 11 KV BALAJINAGAR | 60.51 | 87.62 | 46.98 |
| 104 | Sinnar | 5 | 11KV MALEGAON | 50.57 | 100 | 49.43 | 11KV SINNER | 75.96 | 98.44 | 25.22 | | | | |
| 105 | Solapur | 81 | 11 KV HATTURE NAGER | 56.04 | 94.55 | 47.01 | 11 KV MILL | 59.36 | 99.93 | 40.68 | 11 KV LIMYEWADI | 64.47 | 95.7 | 38.3 |
| 106 | Talegaon | 5 | 22 KV NODURAN | 79.76 | 100 | 20.24 | 22 KV MES | 82.8 | 100 | 17.2 | 22 KV MIDC-II | 95.09 | 100 | 4.91 |
| 107 | Tasgaon | 4 | 11 KV TASGAON II | 77.86 | 99 | 22.92 | 11 KV TASGAON I | 95.75 | 97.45 | 6.69 | | | | |
| 108 | Tuljapur | 2 | 11 KV URBAN TULJAPUR | 64.28 | 86.46 | 44.42 | 11 KV VIP FEEDER | 66.59 | 89.71 | 40.26 | | | | |
| 109 | Tumsar | 3 | 11 KV GANDHINAGAR TOWN | 82.56 | 100 | 17.44 | 11 KV JAMB TOWN | 84.46 | 100 | 15.54 | 11 KV TUMSAR TOWN | 89.39 | 100 | 10.61 |
| 110 | Udgir | 14 | 11 KV NAGARPALIKA(NALGIR) | 55.9 | 99.72 | 44.26 | 11 KV TOWN | 56.76 | 98.51 | 44.09 | 11 KV MAHADA | 60.09 | 99.04 | 40.49 |
| 111 | Umarga | 1 | 11KV OMERGA URBAN | 72.42 | 100 | 27.58 | | | | | | | | |
| 112 | Umalkhed | 3 | 11 KV MIDC FEEDER | 35.23 | 78.83 | 72.23 | 11 KV TOWN FEEDER | 100 | 95.21 | 4.79 | 11 KV UMERKHED | 100 | 97.29 | 2.71 |
| 113 | Umred | 4 | 11KV DREAM CITY | 78.32 | 98.29 | 23.02 | 11KV SONEZARI | 86.42 | 94.71 | 18.15 | 11KV GANGAPUR | 90.72 | 96.86 | 12.13 |
| 114 | Uran-Islampur | 12 | 11 KV URAN-ISLAMPUR GAOTHAN. | 70.33 | 88.81 | 37.54 | 11KV MAHADEV NAGAR GAOTHAN | 81.31 | 93.75 | 23.77 | 11 KV ISLAMPUR-I FEEDER | 85.49 | 96.64 | 17.38 |
| 115 | Vaijapur | 5 | 11KV DARGA | 44.96 | 98.56 | 55.69 | 11 KV MGM | 59.95 | 100 | 40.05 | TOWN-II | 94.1 | 88.86 | 16.38 |
| 116 | Vasai | 7 | UMELA | 81.67 | 90.79 | 25.85 | 22 KV MULGAON | 80.34 | 96.56 | 22.42 | VASAI | 87.62 | 96.46 | 15.48 |
| 117 | Virar | 12 | Y.K.NAGAR | 58.47 | 100 | 41.53 | RUSTAMJI EVERSINE | 78.13 | 100 | 21.87 | VIRAR EAST FEEDER | 81.76 | 96.51 | 21.09 |
| 118 | Vita | 5 | 11 KV BHALWANI(U) | 73.81 | 97.73 | 27.87 | 11 KV PARE (U) | 82.21 | 100 | 17.79 | | | | |
| 119 | Wadgaon | 4 | 11KV SHASTRINAGAR | 57.49 | 97.96 | 43.68 | 11KV PRAVIN NAGAR | 67.03 | 100 | 32.97 | 11 KV JAM ROAD | 70.89 | 100 | 29.11 |
| 120 | Wai | 6 | 22 KV COLLEGE ROAD | 66.28 | 93.45 | 38.06 | 22 KV WAI CITY | 98.32 | 92.54 | 9.01 | 33 KV ATHARVA | 99.15 | 98.46 | 2.38 |
| 121 | Wani | 12 | 11 KV SHIRPUR | 100 | 87.61 | 12.39 | | | | | | | | |
| 122 | Wardha | 16 | 11 KV POOL FAIL | 54.88 | 100 | 45.12 | 11 KV SHIV NAGAR | 61.98 | 99.7 | 38.21 | 11 KV SMASHANGHAT | 71.87 | 100 | 28.13 |
| 123 | Warora | 4 | AANANDVAN | 69.47 | 96.03 | 33.29 | EHV STN T/F | 100 | 95.76 | 4.24 | 11 KV TOWN | 100 | 96.11 | 3.89 |
| 124 | Warud | 4 | 11 KV TOWN 2 | 68.96 | 100 | 31.04 | TOWN 3 | 79.81 | 100 | 20.19 | 11 KV TOWN 1 | 94.42 | 98.71 | 6.8 |
| 125 | Washim | 8 | NARAYANBABA | 44.35 | 93.96 | 58.33 | TOWN FEEDER | 55.9 | 96.83 | 45.87 | URBAN | 100 | 67.05 | 32.95 |
| 126 | Yavatmal | 28 | 11 KV LIC | 60.11 | 100 | 39.89 | 11 KV ESENTIAL | 62.24 | 100 | 37.76 | 11 KV AMBIKA NAGAR | 91.58 | 100 | 8.42 |
| 127 | Yawal | 2 | VYAS MANDIR | 54.01 | 95.01 | 48.69 | YAWAL URBAN -1 | 62.7 | 94.59 | 40.69 | | | | |
| 128 | Yeola | 4 | 11 KV YEOLA 2 | 65.12 | 94.67 | 38.35 | 11 KV YEOLA 1 | 79.42 | 97.97 | 22.19 | 11 KV YEOLA - 3 | 85.38 | 98.1 | 16.24 |