

| Feeder wise AT&C loss report (10% worst Feeders) | | | | | | | | | | | | | | |
|--|----------------|--------------|--------------------------------|--------------------------------|---------------------------|--------------|-----------------------------|--------------------------------|---------------------------|--------------|-------------------------------|--------------------------------|---------------------------|--------------|
| Level of Monitoring: PFC/MoP | | | | | | | | | | | | | | |
| Format: D4 | | | | | | | | | | | | | | |
| Name of State: MAHARASHTRA | | | | | | | | | | | | | | |
| Name of Discom: MSEDCL | | | | | | | | | | | | | | |
| Report Month:- Oct'24 | | | | | | | | | | | | | | |
| Input Period:- Sep'23 to Aug'24 | | | | | | | | | | | | | | |
| Date : 29/10/2024 | | | | | | | | | | | | | | |
| Sr No | Town Name | Total Feeder | Feeder Name1 | Cumulative Billing Efficiency, | | | Feeder Name2 | Cumulative Billing Efficiency, | | | Feeder Name3 | Cumulative Billing Efficiency, | | |
| | | | | Billing Efficiency (%) | Collection Efficiency (%) | AT&C Loss(%) | | Billing Efficiency (%) | Collection Efficiency (%) | AT&C Loss(%) | | Billing Efficiency (%) | Collection Efficiency (%) | AT&C Loss(%) |
| 1 | Achalpur | 12 | 33KV FINLAY | 22.5 | 100 | 77.5 | 11 KV ACHALPUR | 39.44 | 91.32 | 63.98 | 11 KV ACHALPUR TOWN NO. 1 | 55.22 | 96.94 | 46.47 |
| 2 | Ahmadpur | 3 | 11KV BUSTAND FEEDER. | 69.48 | 100 | 30.52 | 11KV TELEPHONE FEEDER | 74.1 | 99.26 | 26.45 | | | | |
| 3 | Ahmednagar | 63 | 11 KV DAREWADI | 24.48 | 95.8 | 76.55 | 11KV MUKUND NAGAR | 37.71 | 94.73 | 64.28 | 11KV BALIKASHRAM | 39.79 | 96.11 | 61.76 |
| 4 | Akkalkot | 3 | 11 KV SWAMI VIHAR FEEDER | 56.37 | 98.76 | 44.33 | 11 KV SAMARTH NAGAR FEEDER | 91.07 | 93.4 | 14.94 | 11 KV AKKALKOT URBAN FEEDER | 89.37 | 97.71 | 12.68 |
| 5 | Akola | 75 | PANKAJ | 39.01 | 93.13 | 63.67 | 11 KV OM SHREE | 44.38 | 88.39 | 60.77 | 11 KV DANA BAZAR | 44.44 | 93.31 | 58.53 |
| 6 | Akot | 7 | M.I.D.C LOHARI ROAD | 52.73 | 92.13 | 51.42 | HIWARKHED ROAD INDUSTRY | 69.42 | 88.44 | 38.6 | 11 KV AKOT TOWN III | 72.61 | 94.39 | 31.46 |
| 7 | Amalner | 10 | 11 KV PRATAP MILL FEEDER | 56.45 | 96.39 | 45.59 | 11 KV SANENAGAR FEEDER | 63.73 | 93.93 | 40.14 | 11 KV SAIBABA FEEDER | 64.43 | 95.58 | 38.42 |
| 8 | Ambejogai | 7 | 11 KV YOGESHWARI FEEDER | 65.61 | 94.75 | 37.83 | 11KV KRANTI NAGAR | 100 | 72.41 | 27.59 | 11 KV RAVIVAR PETH FEEDER | 77.78 | 95.15 | 25.99 |
| 9 | Amravati | 90 | SUSHIL NAGAR | 41.15 | 97.05 | 60.06 | LONTEK | 56.67 | 97.8 | 44.58 | MORABAG FEEDER | 60.44 | 96.8 | 41.49 |
| 10 | Anjangaon | 3 | 11 KV DEONATH | 35.89 | 100 | 64.11 | 11 KV SHIKSHAK COLONY | 48.58 | 99.79 | 51.52 | 11 KV GADGE BABA | 89.4 | 97.98 | 12.41 |
| 11 | Arvi | 5 | 11KV WALMIK WARD | 76.81 | 97.84 | 24.85 | 11 KV TOWN FEEDER | 80.12 | 99.08 | 20.62 | 11 KV INDUSTRIAL FEEDER | 88.04 | 97.23 | 14.4 |
| 12 | Ashta | 7 | 11 KV FALKEWADI | 40.99 | 42.11 | 82.74 | 11 KV ASHTA GAOTHAN 1 | 76.8 | 99.75 | 23.39 | 11KV ASHTA PUMP HOUSE | 92.18 | 98.01 | 9.65 |
| 13 | Ausa | 4 | 11KV MIDC FEEDER | 11.99 | 100 | 88.01 | 11 KV CHOWRASTA FEEDER | 100 | 65.24 | 34.76 | 11 KV NEW MIDC FEEDER. | 100 | 83.59 | 16.41 |
| 14 | Balapur | 1 | 11 KV BALAPUR | 92.87 | 100 | 7.13 | | | | | | | | |
| 15 | Ballarpur | 8 | 11 KV F.D.C.M FEEDER | 66.97 | 98 | 34.37 | 11 KV WASTI FEEDER | 72.83 | 99.54 | 27.51 | 11KV BUS STAND FEEDER | 84.93 | 99.21 | 15.74 |
| 16 | Baramati | 7 | 22 KV INDUSTRIAL ESTATE | 90.16 | 100 | 9.84 | ASHOKNAGAR | 92.07 | 99.37 | 8.51 | AVCHAT ESTATE | 93.86 | 98.98 | 7.1 |
| 17 | Barshi | 9 | 11 KV BHAGAWANT FEEDER | 74.24 | 96.85 | 28.1 | 11KV JAIN MANDIR FEEDER | 88.71 | 98.18 | 12.9 | 11 KV INDUSTRIAL FEEDER | 97.78 | 96.78 | 5.37 |
| 18 | Basmath | 7 | 11 KV KUMBHARWADA | 28.06 | 75.34 | 78.86 | 11 KV RURAL | 91.23 | 23.73 | 78.35 | 11 KV KAUTHA | 61.72 | 86.1 | 46.86 |
| 19 | Beed | 26 | 11 KV. DHANORA ROAD FEEDER | 40.7 | 92.9 | 62.19 | AMBIKA NAGAR | 42.58 | 98.12 | 58.22 | TILAK ROAD NEW | 49.67 | 99.05 | 50.8 |
| 20 | Bhadrawati | 8 | 11 KV NTPC | 78.19 | 94.73 | 25.93 | 11 KV GOURLA | 80.62 | 96.42 | 22.27 | 11KV RAILWAY STATION | 92.1 | 97.81 | 9.92 |
| 21 | Bhandara | 13 | 11 KV ZP SQUARE | 59.52 | 94.93 | 43.5 | 11 KV INDUSTRIAL FEEDER | 73.73 | 98.25 | 27.56 | 11KV STATION ROAD | 79.74 | 97.17 | 22.52 |
| 22 | Bhusaval | 13 | 11 KV PRERNA FEEDER | 45.86 | 92.74 | 57.47 | COURT | 59.19 | 89.87 | 46.81 | 11 KV NAHATA FEEDER | 61.56 | 91.93 | 43.41 |
| 23 | Brahmapuri | 8 | 11 KV FULE NAGAR | 85.68 | 98.77 | 15.37 | 11 KV DELANWADI | 88.47 | 98.73 | 12.65 | MSEB COLONY | 91.75 | 97.37 | 10.66 |
| 24 | Buldhana | 11 | 11 KV BALAJI NAGAR | 67.63 | 100 | 32.37 | 11 KV INDIRA NAGAR | 74.73 | 98.94 | 26.06 | 11 KV GANESH NAGAR | 83.11 | 97.3 | 19.13 |
| 25 | Chalisgaon | 8 | GHAT ROAD | 52.68 | 90.9 | 52.11 | 11 KV CTM | 66.64 | 97.2 | 35.23 | 11 KV JUNE VIMANTAL | 75.49 | 96.38 | 27.24 |
| 26 | Chandrapur | 41 | 11 KV MIDC-I | 72.14 | 92.78 | 33.07 | 11 KV INDUSTRIAL | 80.92 | 91.65 | 25.84 | 11 KV SUMITRA NAGAR | 77.11 | 98.83 | 23.79 |
| 27 | Chikhli | 4 | 11 KV SAILANINAGAR TOWN | 60.72 | 100 | 39.28 | 11 KV MIDC FEEDER | 64.13 | 95.19 | 38.95 | | | | |
| 28 | Chiplun | 13 | 11 KV MILK SCHEME | 57.84 | 96.41 | 44.24 | 11 KV KAMTHE | 59.2 | 98.25 | 41.84 | 11 KV PETHMAP | 85.41 | 100 | 14.59 |
| 29 | Chopda | 6 | 11 KV SHERE PUNJAB | 46.68 | 94.05 | 56.1 | 11 KV HARESHWAR | 56.23 | 97.73 | 45.05 | 11 KV PANKAJ NAGAR | 81.95 | 95.27 | 21.93 |
| 30 | Dahanu | 7 | 11 KV SAINT MARY FEEDER | 67.97 | 100 | 32.03 | 11 KV JAWAHAR RD. | 75.32 | 100 | 24.68 | 11 KV COLLEGE RD. FEEDER | 93.65 | 99.9 | 6.44 |
| 31 | Daryapur | 4 | 11KV SOOTGIRANI | 78.46 | 97.56 | 23.45 | 11 KV DARYAPUR TOWN | 79.09 | 97.46 | 22.92 | 11 KV SAI NAGAR | 86.68 | 97.5 | 15.49 |
| 32 | Daund | 3 | 22 KV RAILWAY | 53.94 | 96.78 | 47.8 | 22 KV S R P F | 55.41 | 97.01 | 46.25 | | | | |
| 33 | Deglur | 5 | 11 KV TOWN 4 | 86.94 | 87.89 | 23.59 | 11 KV TOWN 2 | 95.93 | 86.99 | 16.55 | 11 KV TOWN 1 | 91.83 | 98.38 | 9.66 |
| 34 | Deolali | 12 | 11 KV ANAND NAGAR | 78.86 | 99.86 | 21.25 | 11 KV LAM ROAD | 80.18 | 99.68 | 20.08 | 11 KV DEOLALIGAON | 88.89 | 97.4 | 13.42 |
| 35 | Dharangaon | 4 | 11KV CHINTAMAN MOURYA NAGAR | 40.32 | 93.15 | 62.44 | 11 KV DHARANGAON | 48.33 | 88.4 | 57.28 | 11KV GANESH NAGAR | 67.54 | 88.58 | 40.17 |
| 36 | Dhule | 44 | TATA MOTORS | 32.43 | 100 | 67.57 | 11 KV VADJAI ROAD | 43.51 | 86.45 | 62.39 | 11 KV JYOTIBA FEEDER | 50.69 | 89.51 | 54.63 |
| 37 | Digras | 2 | SAMBHAJI NAGAR | 59.04 | 92.66 | 45.29 | AMBIKA NAGAR | 68.43 | 95.21 | 34.85 | | | | |
| 38 | Dondaicha | 4 | 11KV DONDAICHA UR-II COLONY PA | 55.84 | 96.98 | 45.85 | 11KV DONDAICHA (TAPI SAGAR) | 86.89 | 96.79 | 15.9 | | | | |
| 39 | Erandol | 6 | 11 KV ERANDOL | 32.7 | 96.93 | 68.3 | 11 KV MAHAJAN NAGAR TOWN | 33.86 | 95.04 | 67.82 | 11 KV GANDHIPURA | 72.79 | 96.3 | 29.9 |
| 40 | Gadchiroli | 8 | 11KV POST OFFICE | 34.56 | 91.47 | 68.39 | 11 KV NAGAR PARISHAD | 70.65 | 99.54 | 29.67 | 11 KV CHANDRAPUR ROAD | 87.38 | 98.19 | 14.2 |
| 41 | Gangakhed | 7 | 11 KV MIDC FEEDER | 28.48 | 100 | 71.52 | 11 KV BHANDARI EXPRESS | 35.1 | 93.53 | 67.17 | 11 KV RAILWAY STATION | 60.59 | 83.98 | 49.12 |
| 42 | Gondia | 16 | 11KV GANESH NAGAR | 70.18 | 97.91 | 31.29 | 11KV MAMA CHOWK | 76.14 | 99.5 | 24.24 | TOWN - IV | 81.39 | 99.06 | 19.38 |
| 43 | Greater Mumbai | 544 | M/S VISTA PACKAGING | 38.95 | 94.1 | 63.35 | BADLAPUR(W) | 46.1 | 100 | 53.9 | LOKPRIYA S/STN | 86.86 | 53.94 | 53.15 |
| 44 | Hinganghat | 11 | 11 KV TOWN FEEDER | 71.97 | 97.54 | 29.8 | 11 KV BUS STAND FEEDER | 77.49 | 99.36 | 23.01 | 11KV GOVT HOSPITAL FEEDER | 81.89 | 96.49 | 20.98 |
| 45 | Hingoli | 11 | 11KV TOWN-II | 18.65 | 86.26 | 83.91 | 11 KV TOWN-2 | 27.28 | 85.77 | 76.6 | 11 KV TOWN-1 | 42.3 | 90.49 | 61.72 |
| 46 | Ichalkaranji | 103 | 11KV WATER WORKS | 40.51 | 95.51 | 61.31 | DATTA NAGAR | 70.74 | 96.01 | 32.08 | 11 KV SANMATI VG FEEDER | 73.9 | 92.34 | 31.76 |
| 47 | Igatpuri | 4 | 11 KV CITY | 65.78 | 96.48 | 36.54 | 11 KV GHATANDEVI | 78.63 | 94.38 | 25.79 | MAHINDRA & MAHINDRA | 95.91 | 94.11 | 9.74 |
| 48 | Jaisingpur | 11 | 11KV CH. SHAHU | 67.32 | 97.64 | 34.27 | 11KV RAILWAY | 89.02 | 99.34 | 11.57 | 11KV SHAHUNAGAR | 91.04 | 99.5 | 9.42 |
| 49 | Jalna | 27 | COLLECTOR OFFICE (EXP) | 34.98 | 57.64 | 79.84 | TOWN-2 | 40.9 | 87.7 | 64.13 | 11KV INDUSTRIAL, POLE FACTORY | 50.59 | 88.77 | 55.09 |
| 50 | Jintur | 4 | 11KV NIMGIRI | 36.55 | 55.59 | 79.68 | TOWN -SHIVAJI NAGAR FEEDER | 82.78 | 84.39 | 30.14 | | | | |
| 51 | Kamptee | 10 | 11 KV J P NAGAR | 65.05 | 93.59 | 39.12 | 11 KV RAMANAGAR | 77.63 | 91.4 | 29.05 | 33 KV NMC | 85.47 | 100 | 14.53 |

| Feeder wise AT&C loss report (10% worst Feeders) | | | | | | | | | | | | | | |
|--|-------------|-------------------|----------------------------------|--------------------------------|---------------------------|--------------|-----------------------------------|--------------------------------|---------------------------|--------------|--------------------------------|--------------------------------|---------------------------|--------------|
| Level of Monitoring: PFC/MoP | | | | | | | | | | | | | | |
| Format: D4 | | | | | | | | | | | | | | |
| Name of State: MAHARASHTRA | | | | | | | | | | | | | | |
| Name of Discom:MSSEDCL | | | | | | | | | | | | | | |
| Report Month:- Oct'24 | | | | | | | | | | | | | | |
| Input Period:- Sep'23 to Aug'24 | | Date : 29/10/2024 | | | | | | | | | | | | |
| Sr No | Town Name | Total Feeder | Feeder Name1 | Cumulative Billing Efficiency, | | | Feeder Name2 | Cumulative Billing Efficiency, | | | Feeder Name3 | Cumulative Billing Efficiency, | | |
| | | | | Billing Efficiency (%) | Collection Efficiency (%) | AT&C Loss(%) | | Billing Efficiency (%) | Collection Efficiency (%) | AT&C Loss(%) | | Billing Efficiency (%) | Collection Efficiency (%) | AT&C Loss(%) |
| 52 | Kannad | 4 | TOWN 3 | 22.11 | 76.92 | 82.99 | TOWN 4 | 44.38 | 85.15 | 62.21 | TOWN-II | 76.67 | 89.66 | 31.26 |
| 53 | Karad | 8 | 11 KV WAKHAN ROAD | 87.1 | 96.5 | 15.95 | 11 KV NAGARPALIKA | 86.06 | 98.2 | 15.49 | 11 KV MARKET YARD | 91.16 | 99.62 | 9.19 |
| 54 | Karanja | 11 | 11 KV GAWALIPURA FEEDER | 49.66 | 95.99 | 52.33 | 11 KV MANORA ROAD FEEDER | 61.04 | 93.5 | 42.93 | 11 KV POHA INDUSTRIAL FEEDER | 90.85 | 93.06 | 15.45 |
| 55 | Katol | 5 | 11 KV LAXMINAGAR | 76.34 | 98.96 | 24.45 | 11 KV IUDP FEEDER | 85.28 | 97.67 | 16.71 | 11 KV BUS STAND | 93.05 | 99.56 | 7.36 |
| 56 | Khamgaon | 19 | 11 KV JANUNA | 38.71 | 89.24 | 65.46 | 11 KV DAL FAIL | 61.03 | 95.36 | 41.8 | 11 KV COTTON MARKET | 62.49 | 94.62 | 40.87 |
| 57 | Khopoli | 8 | 22 KV SHILPHATA | 70.06 | 98.34 | 31.1 | 22 KV KHOPOLI TOWN | 79.87 | 99.71 | 20.36 | MULGAON INDUSTRIAL FEEDER | 79.9 | 99.85 | 20.22 |
| 58 | Kolhapur | 89 | MENON METALLICS | 54.96 | 97.5 | 46.41 | RADHA KRISHNA | 63.09 | 100 | 36.91 | KAY INDUSTRY | 74.92 | 99.9 | 25.15 |
| 59 | Kopargaon | 6 | 11 KV KOPARGAON BET | 73.17 | 95.09 | 30.42 | 11 KV INDUSTRIAL | 100 | 91.77 | 8.23 | 11 KV WATER SUPPLY | 100 | 95.08 | 4.92 |
| 60 | Latur | 38 | 11 KV BABHALGAON | 64.24 | 90.37 | 41.95 | 11 KV URBAN/SOS | 64.96 | 90.56 | 41.17 | 11 KV GANGASAGAR | 68.25 | 87.95 | 39.97 |
| 61 | Lonavala | 13 | 22 KV BARA BUNGLOW | 62.91 | 100 | 37.09 | 22 KV KHANDALA | 92.13 | 94.08 | 13.32 | 22 KV KURVANDE | 90.15 | 100 | 9.85 |
| 62 | Majalgaon | 3 | 11KV MANJRATH | 37.23 | 97.63 | 63.65 | 11KV MAJALGAON | 40.38 | 92.67 | 62.58 | | | | |
| 63 | Malegaon | 32 | CHANDANPURI | 34.24 | 97.67 | 66.56 | MLG U-1 | 36.73 | 96.11 | 64.7 | RASULPURA-II NEW | 42.29 | 94.4 | 60.08 |
| 64 | Malkapur | 9 | 11 KV YASHODHAM | 56.87 | 85.78 | 51.22 | 11KV SHIVAJI NAGAR | 77.64 | 93.51 | 27.4 | 11 KV TOWN (MLK) | 83.51 | 93.59 | 21.84 |
| 65 | Manmad | 9 | HANUMAN NAGAR | 31.67 | 95.14 | 69.87 | 11KV PAKIJA | 60.31 | 93.34 | 43.71 | 33KV BPCL | 81.44 | 97.05 | 20.96 |
| 66 | Mehkar | 5 | 11KV SHIVAJI NAGAR TOWN 2 | 17.12 | 91.28 | 84.37 | 11 KV ANDHURD AG | 61.74 | 76.81 | 52.58 | 11 KV MEHKAR TOWN 1 | 57.14 | 88.82 | 49.25 |
| 67 | Morshi | 4 | 11 KV RAMJI BABA | 64.77 | 96.9 | 37.24 | 11 KV TAJ COLONY | 90.82 | 97.32 | 11.61 | 11 KV SIMBHORA ROAD | 100 | 93.83 | 6.17 |
| 68 | Murtijapur | 8 | 11 KV TOWN - 2 | 49.74 | 93.88 | 53.3 | 11KV GOYANAKA FDR | 80.24 | 96.23 | 22.79 | 11 KV TOWN-1 | 90.29 | 98.64 | 10.94 |
| 69 | Nagpur | 128 | 11 KV TELECOM NAGAR | 27.95 | 99.63 | 72.15 | 11 KV HINGNA-I | 63.68 | 98.43 | 37.32 | 11KV CHHOTI DHANTOLI | 63.13 | 100 | 36.87 |
| 70 | Nalasopara | 18 | 22 KV SANTOSH BHUVAN | 73.45 | 100 | 26.55 | SRIPRASTHA | 74.46 | 100 | 25.54 | | | | |
| 71 | Nanded | 78 | 11 KV MAHALAJ - SANGVI | 43.69 | 92.33 | 59.66 | 11 KV WAMAN NAGAR | 47.17 | 95.18 | 55.1 | DEEPNAGAR 11KV FEEDER | 64.84 | 95.99 | 37.76 |
| 72 | Nandura | 4 | JALAGAON ROAD FEEDER | 71.25 | 93.74 | 33.21 | 11 KV DAIRY | 90.3 | 94.09 | 15.04 | 11 KV BALAJI | 95.18 | 100 | 4.82 |
| 73 | Nandurbar | 13 | 11 KV SHIRISHKUMAR MEHTA FEEDER | 52.55 | 98.75 | 48.11 | NANDURBAR | 61.71 | 96.85 | 40.23 | PANCHAYAT SAMITI | 66.28 | 98.85 | 34.48 |
| 74 | Nashik | 189 | 11 KV RAJUR | 69.29 | 58.59 | 59.4 | 11 KV ADGAON I | 58.9 | 72.97 | 57.02 | 11 KV GANGAPUR-AG | 78.4 | 68.59 | 46.23 |
| 75 | Navi Mumbai | 266 | 11 KV AGRJI KOLI | 38.24 | 100 | 61.76 | 22KV NOCIL-STAR | 47.81 | 97.63 | 53.32 | 11KV CIDCO PUMP HOUSE | 49.54 | 100 | 50.46 |
| 76 | Nilanga | 3 | NEW BANK COLONY | 56.78 | 100 | 43.22 | ASHOK NAGAR | 59.4 | 100 | 40.6 | | | | |
| 77 | Osmanabad | 13 | 11KV TER FEEDER | 70.85 | 96.56 | 31.59 | 11KV DARGA FEEDER | 72.56 | 97.2 | 29.47 | 11KV UPLA FEEDER | 93.02 | 93.04 | 13.45 |
| 78 | Ozar | 6 | JAILKE | 16.67 | 98.9 | 83.51 | AMBHEHILL | 53.72 | 95.95 | 48.46 | DIXI | 67.24 | 100 | 32.76 |
| 79 | Pachora | 8 | 11 KV INDUSTRIAL NIRMAL | 100 | 54.59 | 45.41 | 11 KV CHATRAPATI SHIVAJI NAGA | 58.27 | 97.57 | 43.15 | 11 KV VASAHAT INDUSTRIAL | 96.56 | 81.98 | 20.84 |
| 80 | Paithan | 4 | RAPDRP POWER HOUSE | 42.6 | 100 | 57.4 | RAPDRP NEW KAWSAN | 57.84 | 95.25 | 44.91 | 11KV NATH EXPRESS | 57.9 | 100 | 42.1 |
| 81 | Palghar | 18 | DIVISION OFFICE | 72.66 | 99.33 | 27.83 | 11 KV KOTHARI FEEDER | 78.36 | 98.2 | 23.05 | 11 KV BIDCO FEEDER | 82.14 | 99.3 | 18.43 |
| 82 | Pandharpur | 13 | 11 KV SAMATA NAGAR | 49.75 | 98.38 | 51.06 | 11 KV WATER WORKS | 88.05 | 97.84 | 13.85 | 11 KV SARGAM | 90.58 | 96.87 | 12.26 |
| 83 | Panvel | 139 | HORIZON SCHOOL | 39.69 | 98.13 | 61.05 | 11KV STN/JAWALE | 49.05 | 100 | 50.95 | 11 KV N.T.F.C. FEEDER | 53.66 | 100 | 46.34 |
| 84 | Parbhani | 25 | 11KV SAKHALA PLOT | 28.22 | 63.05 | 82.21 | 11 KV INDUSTRIAL NEW FEEDER | 48.72 | 94.03 | 54.19 | 11 KV HADCO FEEDER | 54.54 | 87.66 | 52.19 |
| 85 | Parli | 7 | 11 KV KALRATRI DEVI FEEDER | 22.76 | 73.36 | 83.3 | 11 KV KANYA SHALA FEEDER | 32.25 | 59.18 | 80.91 | 11 KV SINCHAN BHAVAN | 37.18 | 69.84 | 74.03 |
| 86 | Parola | 4 | 11 KV INDUSTRIAL FEEDER | 44.64 | 100 | 55.36 | 11 KV BSNL | 71.42 | 97.7 | 30.22 | 11KV JHAPATBHAWANI | 93.51 | 97.97 | 8.39 |
| 87 | Pathri | 2 | 11 KV PATHRI-II | 29.2 | 66.08 | 80.7 | 11 KV DEVNANDRA | 100 | 41.07 | 58.93 | | | | |
| 88 | Pen | 2 | 22 KV CHINCHPADA | 81.94 | 98.94 | 18.93 | | | | | | | | |
| 89 | Phaltan | 3 | 22KV Y. C. HIGHSCHOOL | 76.49 | 95.86 | 26.68 | 22KV PHALTAN MUNICIPAL | 93.66 | 98.93 | 7.34 | | | | |
| 90 | Pulgaon | 6 | MEDICAL | 37.81 | 100 | 62.19 | 11KV HARIRAM NAGAR | 65.97 | 95.39 | 37.07 | VPF GAOTHAN | 85.07 | 98.45 | 16.25 |
| 91 | Pune City | 765 | 11 KV SOBA SAVERA | 40.52 | 100 | 59.48 | GHARONDA | 42.47 | 100 | 57.53 | 11 KV SAI DHAM | 47.73 | 99.5 | 52.51 |
| 92 | Purna | 4 | 11KV RAILWAY OLD | 29.61 | 64.64 | 80.86 | 11KV KOLIWADA FEEDER (PURNA TOWN) | 26.76 | 78.98 | 78.86 | 11 KV ANAND NAGAR (PURNA TOWN) | 70.82 | 85.3 | 39.59 |
| 93 | Pusad | 8 | 11 KV ITAWA | 45.11 | 92.48 | 58.28 | 11 KV NEW PUSAD | 48.51 | 96.85 | 53.02 | 11 KV KAKADDATI | 100 | 92.72 | 7.28 |
| 94 | Ratnagiri | 19 | 11KV MIDC RTN-U | 69.86 | 99.9 | 30.21 | 11KV SALAVI STOP,RTN-U | 74.1 | 97.43 | 27.8 | 11KV RAMNAKA RTN-U | 77.87 | 100 | 22.13 |
| 95 | Sailu | 6 | 11KV MARWAD GALLI FEEDER | 58.98 | 83.52 | 50.74 | 11KV RAILWAY STATION FEEDER | 81.68 | 82.61 | 32.52 | | | | |
| 96 | Sangamner | 6 | 11 KV INDUSTRIAL | 69.18 | 94.38 | 34.71 | 11KV GHULEWADI | 77.98 | 95.32 | 25.67 | | | | |
| 97 | Sangli | 82 | 11 KV MAHAVIR | 29.14 | 74.44 | 78.31 | 11 KV KRISHNA GHAT | 47.58 | 84.42 | 59.83 | 11 KV TAKSHILA | 49.09 | 99.84 | 50.99 |
| 98 | Satana | 2 | 11 KV MAHALAXMI FEEDER | 70.05 | 95.59 | 33.04 | 11 KV SATANA (U) FEEDER | 79.91 | 95.43 | 23.74 | | | | |
| 99 | Satara | 29 | 22 KV MIDC (FROM SATARA ROAD SS) | 61.83 | 97.96 | 39.43 | 22 KV KARMVEER NAGAR | 74.32 | 99.5 | 26.05 | 22KV PARANGE | 81.87 | 100 | 18.13 |
| 100 | Shahada | 6 | MAIN ROAD | 43.06 | 92.32 | 60.25 | 11 KV OUTGOING MALONI FEEDER | 47.26 | 95.94 | 54.66 | 11 KV OUTGOING VIKAS FEEDER | 61.74 | 95.25 | 41.19 |
| 101 | Shegaon | 7 | 11KV INDUSTRIAL | 43.45 | 93.89 | 59.2 | 11 KV GM MANDIR | 84.98 | 99.09 | 15.79 | 11KV TOWN I | 87.17 | 100 | 12.83 |
| 102 | Shirpur | 7 | 11 KV YOGESHWAR COLONY | 47.4 | 100 | 52.6 | 11 KV K. G. ROAD | 74.14 | 99.63 | 26.13 | 11 KV MAIN ROAD | 77.28 | 99.08 | 23.43 |

| Feeder wise AT&C loss report (10% worst Feeders) | | | | | | | | | | | | | | |
|--|---------------|-------------------|---------------------------------|--------------------------------|---------------------------|--------------|------------------------------|--------------------------------|---------------------------|--------------|--------------------------------|--------------------------------|---------------------------|--------------|
| Level of Monitoring: PFC/MoP | | | | | | | | | | | | | | |
| Format: D4 | | | | | | | | | | | | | | |
| Name of State: MAHARASHTRA | | | | | | | | | | | | | | |
| Name of Discom:MSEDCL | | | | | | | | | | | | | | |
| Report Month:- Oct'24 | | | | | | | | | | | | | | |
| Input Period:- Sep'23 to Aug'24 | | Date : 29/10/2024 | | | | | | | | | | | | |
| Sr No | Town Name | Total Feeder | Feeder Name1 | Cumulative Billing Efficiency, | | | Feeder Name2 | Cumulative Billing Efficiency, | | | Feeder Name3 | Cumulative Billing Efficiency, | | |
| | | | | Billing Efficiency (%) | Collection Efficiency (%) | AT&C Loss(%) | | Billing Efficiency (%) | Collection Efficiency (%) | AT&C Loss(%) | | Billing Efficiency (%) | Collection Efficiency (%) | AT&C Loss(%) |
| 103 | Sillod | 7 | AMBADASNAGAR | 28.42 | 92.56 | 73.69 | AURANGABAD NAKA | 44.3 | 92.89 | 58.85 | TILAKNAGAR | 47.25 | 99.07 | 53.19 |
| 104 | Sinnar | 5 | 11 KV GAOTHA | 80.05 | 99.25 | 20.55 | 11KV SINNER | 81.67 | 99.25 | 18.94 | 11 KV SARADWADI | 92.19 | 99.82 | 7.98 |
| 105 | Solapur | 79 | 11 KV LIMYEWADI | 70.5 | 96.65 | 31.86 | 11 KV KUMATHA GAOTHAN | 69.63 | 97.97 | 31.78 | 11 KV NEHARU NAGAR | 73.04 | 100 | 26.96 |
| 106 | Talegaon | 5 | 22 KV MIDC-II | 72.13 | 100 | 27.87 | 22 KV NODURAN | 92.08 | 100 | 7.92 | 22 KV MES | 96.42 | 100 | 3.58 |
| 107 | Tasgaon | 4 | 11 KV TASGAON II | 77.1 | 99.4 | 23.36 | 11 KV TASGAON I | 81.08 | 98.61 | 20.05 | | | | |
| 108 | Tuljapur | 2 | 11 KV URBAN TULJAPUR | 59.41 | 55.48 | 67.04 | 11 KV VIP FEEDER | 77.58 | 100 | 22.42 | | | | |
| 109 | Tumsar | 3 | 11 KV GANDHINAGAR TOWN | 86.87 | 98.38 | 14.54 | 11 KV TUMSAR TOWN | 91.69 | 97.78 | 10.35 | 11 KV JAMB TOWN | 91.02 | 98.67 | 10.19 |
| 110 | Udgir | 14 | 11KV AMBEDKAR CHOWK | 41.75 | 93.46 | 60.98 | 11 KV BUS STAND | 50.91 | 93.81 | 52.24 | 11KV ST COLONY FEEDER | 62.4 | 89.32 | 44.26 |
| 111 | Umarga | 1 | 11KV OMERGA URBAN | 100 | 85.23 | 14.77 | | | | | | | | |
| 112 | Umarkhed | 3 | 11 KV MIDC FEEDER | 16.3 | 100 | 83.7 | 11 KV UMERKHED | 64.43 | 95.96 | 38.17 | | | | |
| 113 | Umred | 8 | 11 KV MAKARDHOKDA | 44.01 | 87.42 | 61.53 | 11KV BUDHWARI ICE FACTORY | 71.43 | 100 | 28.57 | 11KV KAWARAPETH | 84.56 | 98.1 | 17.05 |
| 114 | Uran-Islampur | 10 | 11 KV RAJARAM NAGER | 73.42 | 100 | 26.58 | 11 KV URAN-ISLAMPUR GAOTHAN. | 80.23 | 99.83 | 19.91 | 11 KV ISLAMPUR-II FEEDER | 83.82 | 100 | 16.18 |
| 115 | Vaijapur | 5 | 11KV DARGA | 46.07 | 100 | 53.93 | 11 KV MGM | 69.71 | 100 | 30.29 | 11KV TILAKROAD | 69.91 | 100 | 30.09 |
| 116 | Vasai | 9 | DATTANI | 57.78 | 98.64 | 43.01 | UMELA | 87.99 | 100 | 12.01 | 22 KV TAMTALAV | 96.02 | 100 | 3.98 |
| 117 | Virar | 14 | GLOBAL CITY | 66.56 | 99.86 | 33.53 | SOPARA FEEDER NO. 9 | 87.33 | 100 | 12.67 | VIRAT & YASHWANT NAGAR | 88.38 | 100 | 11.62 |
| 118 | Vita | 6 | 11 KV BHALWANI(U) | 66.63 | 95.53 | 36.35 | 11 KV PARE (U) | 70.39 | 95.53 | 32.76 | | | | |
| 119 | Wadgaon | 4 | 11 KV JAM ROAD | 46.71 | 100 | 53.29 | 11KV SHASTRINAGAR | 78.74 | 96.79 | 23.79 | 11KV PRAVIN NAGAR | 92.57 | 96.21 | 10.94 |
| 120 | Wai | 8 | 11 KV WAI MIDC II | 47.34 | 96.24 | 54.44 | 22 KV COLLEGE ROAD | 79 | 95.68 | 24.41 | 22 KV DHAGE ALI (WAI CITY ALT) | 92.61 | 92.06 | 14.74 |
| 121 | Wani | 15 | 11 KV KAYAR (WANI) | 45.69 | 66.42 | 69.65 | 11 KV SHIRPUR | 65.58 | 70.83 | 53.55 | 11 KV WANI TOWN | 69.47 | 100 | 30.53 |
| 122 | Wardha | 23 | 11 KV F ZONE FEEDER | 37.88 | 95.64 | 63.77 | 11 KV ITWARA | 60.95 | 96.85 | 40.97 | 11 KV G ZONE FEEDER | 72.4 | 90.05 | 34.8 |
| 123 | Warora | 9 | SAI FEEDER WANI ROAD | 73.59 | 98.21 | 27.73 | 11 KV MADHELI NAKA | 79.82 | 98 | 21.78 | AANANDVAN | 85.67 | 94.83 | 18.76 |
| 124 | Warud | 7 | 11 KV TOWN 2 | 52.46 | 96.66 | 49.29 | 11 KV TOWN 1 | 76.09 | 96.77 | 26.37 | 11 KV RIMZIM GAOTHAN | 100 | 98.49 | 1.51 |
| 125 | Washim | 10 | RAILWAY STATION | 17.54 | 90.57 | 84.11 | TOWN FEEDER | 51.76 | 92.95 | 51.89 | CIVIL LINE EXPRESS FEEDER | 97.21 | 95.91 | 6.77 |
| 126 | Yavatmal | 29 | 11 KV SARAFI BAZAR | 39.03 | 92.58 | 63.87 | 11 KV AKASHWANI FEEDER | 56.69 | 93.77 | 46.84 | 11 KV AMBIKA NAGAR | 100 | 85.57 | 14.43 |
| 127 | Yawal | 2 | YAWAL URBAN -1 | 50.3 | 95.86 | 51.78 | VYAS MANDIR | 50.57 | 96.06 | 51.42 | | | | |
| 128 | Yeola | 4 | 11 KV GANGASAGAR EXPRESS FEEDER | 63.06 | 100 | 36.94 | 11 KV YEOLA 2 | 88.1 | 94.56 | 16.69 | 11 KV YEOLA 1 | 88.42 | 97.07 | 14.17 |