

| Feeder wise AT&C loss report (10% worst Feeders) |                |              |                                |                                |                           |              |                             |                                |                           |              |                               |                                |                           |              |
|--------------------------------------------------|----------------|--------------|--------------------------------|--------------------------------|---------------------------|--------------|-----------------------------|--------------------------------|---------------------------|--------------|-------------------------------|--------------------------------|---------------------------|--------------|
| Level of Monitoring: PFC/MoP                     |                |              |                                |                                |                           |              |                             |                                |                           |              |                               |                                |                           |              |
| Format: D4                                       |                |              |                                |                                |                           |              |                             |                                |                           |              |                               |                                |                           |              |
| Name of State: MAHARASHTRA                       |                |              |                                |                                |                           |              |                             |                                |                           |              |                               |                                |                           |              |
| Name of Discom:MSEDCL                            |                |              |                                |                                |                           |              |                             |                                |                           |              |                               |                                |                           |              |
| Report Month:- Nov'24                            |                |              |                                |                                |                           |              |                             |                                |                           |              |                               |                                |                           |              |
| Input Period:- Oct'23 to Sep'24                  |                |              |                                |                                |                           |              |                             |                                |                           |              |                               |                                |                           |              |
|                                                  |                |              |                                |                                |                           |              |                             |                                |                           |              |                               | Date : 29/11/2024              |                           |              |
| Sr No                                            | Town Name      | Total Feeder | Feeder Name1                   | Cumulative Billing Efficiency, |                           |              | Feeder Name2                | Cumulative Billing Efficiency, |                           |              | Feeder Name3                  | Cumulative Billing Efficiency, |                           |              |
|                                                  |                |              |                                | Billing Efficiency (%)         | Collection Efficiency (%) | AT&C Loss(%) |                             | Billing Efficiency (%)         | Collection Efficiency (%) | AT&C Loss(%) |                               | Billing Efficiency (%)         | Collection Efficiency (%) | AT&C Loss(%) |
| 1                                                | Achalpur       | 12           | 33KV FINLAY                    | 24.06                          | 97.06                     | 76.65        | 11 KV ACHALPUR              | 38.92                          | 94.88                     | 63.07        | 11 KV ACHALPUR TOWN NO. 1     | 56.08                          | 97.3                      | 45.43        |
| 2                                                | Ahmadpur       | 3            | 11KV BUSTAND FEEDER.           | 68.38                          | 100                       | 31.62        | 11KV TELEPHONE FEEDER       | 80.22                          | 99.35                     | 20.3         |                               |                                |                           |              |
| 3                                                | Ahmednagar     | 63           | 11 KV DAREWADI                 | 24.99                          | 95.64                     | 76.1         | 11KV MUKUND NAGAR           | 36.3                           | 95.62                     | 65.29        | 11KV BALIKASHRAM              | 39.65                          | 96.59                     | 61.7         |
| 4                                                | Akkalkot       | 3            | 11 KV SWAMI VIHAR FEEDER       | 54.56                          | 97.88                     | 46.6         | 11 KV SAMARTH NAGAR FEEDER  | 91.85                          | 94.76                     | 12.96        | 11 KV AKKALKOT URBAN FEEDER   | 90.21                          | 98.09                     | 11.51        |
| 5                                                | Akola          | 75           | PANKAJ                         | 42                             | 92.42                     | 61.18        | 11 KV OM SHREE              | 44.72                          | 87.48                     | 60.88        | 11 KV DANA BAZAR              | 45.25                          | 96.05                     | 56.54        |
| 6                                                | Akot           | 7            | M.I.D.C LOHARI ROAD            | 54.07                          | 93.94                     | 49.21        | HIWARKHED ROAD INDUSTRY     | 70.42                          | 88.67                     | 37.56        | 11 KV AKOT TOWN III           | 73                             | 95.09                     | 30.58        |
| 7                                                | Amalner        | 10           | 11 KV PRATAP MILL FEEDER       | 56.98                          | 96.8                      | 44.84        | 11 KV SANENAGAR FEEDER      | 64.03                          | 95.41                     | 38.91        | 11 KV SAIBABA FEEDER          | 64.72                          | 95.53                     | 38.17        |
| 8                                                | Ambejogai      | 7            | 11 KV YOGESHWARI FEEDER        | 65.78                          | 94.94                     | 37.55        | 11KV KRANTI NAGAR           | 100                            | 75.97                     | 24.03        | 11 KV RAVIVAR PETH FEEDER     | 80.54                          | 94.85                     | 23.61        |
| 9                                                | Amravati       | 90           | SUSHIL NAGAR                   | 45.21                          | 97.51                     | 55.92        | LONTEK                      | 56.73                          | 90.71                     | 48.54        | MORABAG FEEDER                | 62.11                          | 96.89                     | 39.82        |
| 10                                               | Anjangaon      | 3            | 11 KV DEONATH                  | 36.15                          | 100                       | 63.85        | 11 KV SHIKSHAK COLONY       | 46.11                          | 99.84                     | 53.96        | 11 KV GADGE BABA              | 91.29                          | 97.99                     | 10.54        |
| 11                                               | Arvi           | 5            | 11KV WALMIK WARD               | 82.34                          | 97.77                     | 19.5         | 11 KV TOWN FEEDER           | 82.98                          | 98.49                     | 18.27        | 11 KV INDUSTRIAL FEEDER       | 92.91                          | 97.41                     | 9.5          |
| 12                                               | Ashta          | 7            | 11 KV FALKEWADI                | 37.81                          | 44.28                     | 83.26        | 11 KV ASHTA GAOTHAN 1       | 77.32                          | 100                       | 22.68        | 11KV ASHTA PUMP HOUSE         | 93.36                          | 98.05                     | 8.46         |
| 13                                               | Ausa           | 4            | 11KV MIDC FEEDER               | 11.22                          | 100                       | 88.78        | 11 KV CHOWRASTA FEEDER      | 100                            | 65.24                     | 34.76        | 11 KV NEW MIDC FEEDER.        | 100                            | 83.59                     | 16.41        |
| 14                                               | Balapur        | 1            | 11 KV BALAPUR                  | 94.74                          | 100                       | 5.26         |                             |                                |                           |              |                               |                                |                           |              |
| 15                                               | Ballarpur      | 8            | 11 KV WASTI FEEDER             | 71.28                          | 98.74                     | 29.62        | 11 KV F.D.C.M FEEDER        | 74.69                          | 99.34                     | 25.8         | 11KV BUS STAND FEEDER         | 88.04                          | 99.73                     | 12.2         |
| 16                                               | Baramati       | 7            | ASHOKNAGAR                     | 92.84                          | 99.74                     | 7.4          | AVCHAT ESTATE               | 94.4                           | 99.29                     | 6.27         | 22 KV INDUSTRIAL ESTATE       | 98.48                          | 99.51                     | 2            |
| 17                                               | Barshi         | 9            | 11 KV BHAGAWANT FEEDER         | 74.44                          | 97.51                     | 27.41        | 11KV JAIN MANDIR FEEDER     | 89.06                          | 98.38                     | 12.38        | 11 KV INDUSTRIAL FEEDER       | 98.3                           | 97.47                     | 4.19         |
| 18                                               | Basmath        | 7            | 11 KV KUMBHARWADA              | 26.86                          | 76.05                     | 79.57        | 11 KV RURAL                 | 100                            | 22.82                     | 77.18        | 11 KV KAUTHA                  | 64.31                          | 86.44                     | 44.41        |
| 19                                               | Beed           | 26           | 11 KV. DHANORA ROAD FEEDER     | 40.67                          | 92.19                     | 62.51        | AMBIKA NAGAR                | 42.16                          | 98.26                     | 58.57        | TILAK ROAD NEW                | 49.74                          | 99.57                     | 50.47        |
| 20                                               | Bhadrawati     | 8            | 11 KV NTPC                     | 81.08                          | 95.79                     | 22.33        | 11 KV GOURALA               | 80.39                          | 96.86                     | 22.13        |                               |                                |                           |              |
| 21                                               | Bhandara       | 13           | 11 KV ZP SQUARE                | 65.91                          | 96.05                     | 36.69        | 11 KV INDUSTRIAL FEEDER     | 73.94                          | 98.62                     | 27.08        | 11KV STATION ROAD             | 79.9                           | 97.55                     | 22.06        |
| 22                                               | Bhusaval       | 13           | 11 KV PRERNA FEEDER            | 49.91                          | 91.67                     | 54.25        | COURT                       | 60.28                          | 89.34                     | 46.15        | 11 KV NAHATA FEEDER           | 64.35                          | 91.64                     | 41.03        |
| 23                                               | Brahmapuri     | 8            | 11 KV FULE NAGAR               | 88.71                          | 98                        | 13.06        | 11 KV DELANWADI             | 88.72                          | 98.31                     | 12.78        | MSEB COLONY                   | 92.03                          | 97.2                      | 10.55        |
| 24                                               | Buldhana       | 11           | 11 KV BALAJI NAGAR             | 70.5                           | 99.47                     | 29.87        | 11 KV INDIRA NAGAR          | 76.53                          | 99.74                     | 23.67        | 11 KV GANESH NAGAR            | 91.12                          | 96.64                     | 11.94        |
| 25                                               | Chalisgaon     | 8            | GHAT ROAD                      | 52.93                          | 91.16                     | 51.75        | 11 KV CTM                   | 72.1                           | 98.12                     | 29.26        | 11 KV JUNE VIMANTAL           | 75.56                          | 96.58                     | 27.02        |
| 26                                               | Chandrapur     | 41           | 11 KV MIDC-I                   | 72.26                          | 92.46                     | 33.19        | 11 KV INDUSTRIAL            | 81.59                          | 92.26                     | 24.73        | 11 KV SUMITRA NAGAR           | 79.36                          | 99.76                     | 20.83        |
| 27                                               | Chikhli        | 4            | 11 KV SAILANINAGAR TOWN        | 51.12                          | 100                       | 48.88        | 11 KV MIDC FEEDER           | 62.79                          | 94.88                     | 40.42        |                               |                                |                           |              |
| 28                                               | Chiplun        | 13           | 11 KV MILK SCHEME              | 56.55                          | 96.09                     | 45.66        | 11 KV KAMTHE                | 58.5                           | 97.91                     | 42.72        | 11 KV PETHMAP                 | 91.58                          | 100                       | 8.42         |
| 29                                               | Chopda         | 6            | 11 KV SHERE PUNJAB             | 49.17                          | 94.61                     | 53.48        | 11 KV HARESHWAR             | 56.43                          | 97.65                     | 44.9         | 11 KV PANKAJ NAGAR            | 83.92                          | 96.08                     | 19.37        |
| 30                                               | Dahanu         | 7            | 11 KV SAINT MARY FEEDER        | 68.42                          | 100                       | 31.58        | 11 KV JAWAHAR RD.           | 77.05                          | 100                       | 22.95        | 11 KV COLLEGE RD. FEEDER      | 94.66                          | 100                       | 5.34         |
| 31                                               | Daryapur       | 4            | 11 KV DARYAPUR TOWN            | 79.87                          | 96.76                     | 22.72        | 11KV SOOTGIRANI             | 79.92                          | 97.87                     | 21.78        | 11 KV SAI NAGAR               | 95.32                          | 98.1                      | 6.49         |
| 32                                               | Daund          | 3            | 22 KV RAILWAY                  | 52.01                          | 96.78                     | 49.66        | 22 KV S R P F               | 59.08                          | 97.7                      | 42.28        |                               |                                |                           |              |
| 33                                               | Deglur         | 5            | 11 KV TOWN 4                   | 94.21                          | 88.85                     | 16.29        | 11 KV TOWN 2                | 100                            | 85.85                     | 14.15        | 11 KV TOWN 1                  | 91.87                          | 97.37                     | 10.55        |
| 34                                               | Deolali        | 12           | 11 KV LAM ROAD                 | 80.08                          | 100                       | 19.92        | 11 KV ANAND NAGAR           | 80.5                           | 99.95                     | 19.54        | 11 KV DEOLALIGAON             | 88.62                          | 98.95                     | 12.31        |
| 35                                               | Dharangaon     | 4            | 11KV CHINTAMAN MOURYA NAGAR    | 40.37                          | 93.78                     | 62.14        | 11 KV DHARANGAON            | 47.78                          | 88.93                     | 57.51        | 11KV GANESH NAGAR             | 67.82                          | 87.4                      | 40.73        |
| 36                                               | Dhule          | 44           | TATA MOTORS                    | 32.56                          | 97.17                     | 68.36        | 11 KV VADJAI ROAD           | 43.3                           | 85.66                     | 62.91        | 11 KV JYOTIBA FEEDER          | 50.78                          | 89.93                     | 54.33        |
| 37                                               | Digras         | 2            | SAMBHAJI NAGAR                 | 59.42                          | 93.22                     | 44.61        | AMBIKA NAGAR                | 64.17                          | 95.23                     | 38.89        |                               |                                |                           |              |
| 38                                               | Dondaicha      | 4            | 11KV DONDAICHA UR-II COLONY PA | 55.65                          | 98                        | 45.46        | 11KV DONDAICHA (TAPI SAGAR) | 94.28                          | 96.42                     | 9.1          |                               |                                |                           |              |
| 39                                               | Erandol        | 6            | 11 KV ERANDOL                  | 32.62                          | 97.19                     | 68.3         | 11 KV MAHAJAN NAGAR TOWN    | 33.99                          | 93.83                     | 68.11        | 11 KV GANDHIPURA              | 72.25                          | 96.55                     | 30.24        |
| 40                                               | Gadchiroli     | 8            | 11KV POST OFFICE               | 31.06                          | 94.15                     | 70.76        | 11 KV NAGAR PARISHAD        | 71.91                          | 99.46                     | 28.48        | 11 KV CHANDRAPUR ROAD         | 87.14                          | 98.36                     | 14.29        |
| 41                                               | Gangakhed      | 7            | 11 KV MIDC FEEDER              | 26.97                          | 100                       | 73.03        | 11 KV BHANDARI EXPRESS      | 36.14                          | 93.6                      | 66.17        | 11 KV RAILWAY STATION         | 53.42                          | 85.54                     | 54.3         |
| 42                                               | Gondia         | 16           | TOWN - IV                      | 82.09                          | 100                       | 17.91        | 11KV GANESH NAGAR           | 85.55                          | 100                       | 14.45        | 11KV MAMA CHOWK               | 86.24                          | 99.41                     | 14.27        |
| 43                                               | Greater Mumbai | 544          | M/S VISTA PACKAGING            | 38.98                          | 94.11                     | 63.32        | BADLAPUR(W)                 | 46.38                          | 100                       | 53.62        | LOKPRIYA S/STN                | 89.17                          | 52.72                     | 52.99        |
| 44                                               | Hinganghat     | 11           | 11 KV TOWN FEEDER              | 70.63                          | 97.9                      | 30.85        | 11KV GOVT HOSPITAL FEEDER   | 74.19                          | 99.17                     | 26.43        | 11 KV BUS STAND FEEDER        | 78.42                          | 99.21                     | 22.2         |
| 45                                               | Hingoli        | 11           | 11KV TOWN-II                   | 18.69                          | 86.67                     | 83.8         | 11 KV TOWN-2                | 29.34                          | 84.85                     | 75.11        | 11 KV TOWN-1                  | 46.55                          | 90.4                      | 57.92        |
| 46                                               | Ichalkaranji   | 103          | 11KV WATER WORKS               | 44.45                          | 92.4                      | 58.93        | DATTA NAGAR                 | 70.93                          | 95.59                     | 32.2         | 11 KV SANMATI VG FEEDER       | 74.46                          | 92.05                     | 31.46        |
| 47                                               | Igatpuri       | 4            | 11 KV CITY                     | 65.97                          | 96.18                     | 36.55        | 11 KV GHATANDEVI            | 80.67                          | 93.62                     | 24.48        | MAHINDRA & MAHINDRA           | 94.01                          | 94.04                     | 11.59        |
| 48                                               | Jaisingpur     | 11           | 11KV CH. SHAHU                 | 67.64                          | 97.26                     | 34.21        | 11KV RAILWAY                | 89.34                          | 98.76                     | 11.77        | 11KV SHAHUNAGAR               | 92.31                          | 99.88                     | 7.8          |
| 49                                               | Jaana          | 27           | COLLECTOR OFFICE (EXP)         | 33.76                          | 52.95                     | 82.12        | TOWN-2                      | 40.88                          | 87.51                     | 64.23        | 11KV INDUSTRIAL, POLE FACTORY | 50.43                          | 86.28                     | 56.49        |
| 50                                               | Jintur         | 4            | 11KV NIMGIRI                   | 37.14                          | 53.16                     | 80.26        | TOWN -SHIVAJI NAGAR FEEDER  | 80.24                          | 81.42                     | 34.67        |                               |                                |                           |              |
| 51                                               | Kamptee        | 10           | 11 KV J P NAGAR                | 61.24                          | 94.49                     | 42.13        | 11 KV RAMANAGAR             | 76.95                          | 91.28                     | 29.76        | 33 KV NMC                     | 85.36                          | 100                       | 14.64        |

| Feeder wise AT&C loss report (10% worst Feeders) |             |              |                                  |                                |                           |              |                                   |                                |                           |              |                                |                                |                           |              |
|--------------------------------------------------|-------------|--------------|----------------------------------|--------------------------------|---------------------------|--------------|-----------------------------------|--------------------------------|---------------------------|--------------|--------------------------------|--------------------------------|---------------------------|--------------|
| Level of Monitoring: PFC/MoP                     |             |              |                                  |                                |                           |              |                                   |                                |                           |              |                                |                                |                           |              |
| Format: D4                                       |             |              |                                  |                                |                           |              |                                   |                                |                           |              |                                |                                |                           |              |
| Name of State: MAHARASHTRA                       |             |              |                                  |                                |                           |              |                                   |                                |                           |              |                                |                                |                           |              |
| Name of Discom:MSEDCL                            |             |              |                                  |                                |                           |              |                                   |                                |                           |              |                                |                                |                           |              |
| Report Month:- Nov'24                            |             |              |                                  |                                |                           |              |                                   |                                |                           |              |                                |                                |                           |              |
| Input Period:- Oct'23 to Sep'24                  |             |              |                                  |                                |                           |              |                                   |                                |                           |              |                                |                                |                           |              |
|                                                  |             |              |                                  |                                |                           |              |                                   |                                |                           |              |                                | Date : 29/11/2024              |                           |              |
| Sr No                                            | Town Name   | Total Feeder | Feeder Name1                     | Cumulative Billing Efficiency, |                           |              | Feeder Name2                      | Cumulative Billing Efficiency, |                           |              | Feeder Name3                   | Cumulative Billing Efficiency, |                           |              |
|                                                  |             |              |                                  | Billing Efficiency (%)         | Collection Efficiency (%) | AT&C Loss(%) |                                   | Billing Efficiency (%)         | Collection Efficiency (%) | AT&C Loss(%) |                                | Billing Efficiency (%)         | Collection Efficiency (%) | AT&C Loss(%) |
| 52                                               | Kannad      | 4            | TOWN 3                           | 23.19                          | 75.01                     | 82.61        | TOWN 4                            | 46.26                          | 84.64                     | 60.85        | TOWN-II                        | 82.47                          | 89.59                     | 26.12        |
| 53                                               | Karad       | 8            | 11 KV WAKHAN ROAD                | 87.27                          | 96.24                     | 16.01        | 11 KV NAGARPALIKA                 | 86.25                          | 98.33                     | 15.19        | 11 KV MARKET YARD              | 91.59                          | 99.49                     | 8.88         |
| 54                                               | Karanja     | 11           | 11 KV GAWALIPURA FEEDER          | 50.92                          | 96.45                     | 50.89        | 11 KV MANORA ROAD FEEDER          | 60.7                           | 93.28                     | 43.38        | 11 KV POHA INDUSTRIAL FEEDER   | 99.85                          | 92.86                     | 7.28         |
| 55                                               | Katol       | 5            | 11 KV LAXMINAGAR                 | 75.05                          | 98.38                     | 26.17        | 11 KV IUDP FEEDER                 | 83.53                          | 98.27                     | 17.92        | 11 KV BUS STAND                | 98.28                          | 99.54                     | 2.17         |
| 56                                               | Khamgaon    | 19           | 11 KV JANUNA                     | 39.61                          | 89.68                     | 64.48        | 11 KV DAL FAIL                    | 61.39                          | 94.7                      | 41.86        | 11 KV COTTON MARKET            | 62.71                          | 94.09                     | 41           |
| 57                                               | Khopoli     | 8            | 22 KV SHILPHATA                  | 69.29                          | 98.32                     | 31.87        | MULGAON INDUSTRIAL FEEDER         | 80.49                          | 99.94                     | 19.56        | 22 KV KHOPOLI TOWN             | 80.99                          | 99.54                     | 19.38        |
| 58                                               | Kolhapur    | 89           | MENON METALLICS                  | 55.68                          | 97.48                     | 45.72        | RADHA KRISHNA                     | 63.11                          | 100                       | 36.89        | KAY INDUSTRY                   | 74.92                          | 99.9                      | 25.15        |
| 59                                               | Kopargaon   | 6            | 11 KV KOPARGAON BET              | 72.88                          | 95.81                     | 30.17        | 11 KV INDUSTRIAL                  | 100                            | 91.77                     | 8.23         | 11 KV WATER SUPPLY             | 100                            | 95.08                     | 4.92         |
| 60                                               | Latur       | 38           | 11 KV URBAN/SOS                  | 65.48                          | 90.77                     | 40.56        | 11 KV BABHALGAON                  | 70.91                          | 90.55                     | 35.79        | 11 KV GANGASAGAR               | 73.42                          | 87.97                     | 35.41        |
| 61                                               | Lonavala    | 13           | 22 KV BARA BUNGLOW               | 63.05                          | 100                       | 36.95        | 22 KV KURVANDE                    | 89.06                          | 97.42                     | 13.24        | 22 KV KHANDALA                 | 92.27                          | 96.91                     | 10.58        |
| 62                                               | Majalgaon   | 3            | 11KV MANJRATH                    | 37.33                          | 97.77                     | 63.5         | 11KV MAJALGAON                    | 43.69                          | 92.62                     | 59.53        |                                |                                |                           |              |
| 63                                               | Malegaon    | 32           | CHANDANPURI                      | 34.49                          | 98.97                     | 65.87        | MLG U-1                           | 36.58                          | 95.8                      | 64.96        | RASULPURA-II NEW               | 42.51                          | 92.94                     | 60.49        |
| 64                                               | Malkapur    | 9            | 11 KV YASHODHAM                  | 57.34                          | 86.32                     | 50.5         | 11KV SHIVAJI NAGAR                | 79.73                          | 94.42                     | 24.72        | 11 KV TOWN (MLK)               | 84.52                          | 92.89                     | 21.49        |
| 65                                               | Manmad      | 9            | HANUMAN NAGAR                    | 32.58                          | 93.77                     | 69.45        | 11KV PAKIJA                       | 65.18                          | 91.86                     | 40.13        | 33KV BPCL                      | 81.62                          | 96.81                     | 20.98        |
| 66                                               | Mehkar      | 5            | 11KV SHIVAJI NAGAR TOWN 2        | 17.44                          | 95.26                     | 83.39        | 11 KV MEHKAR TOWN 1               | 58.24                          | 89.17                     | 48.07        | 11 KV ANDHURD AG               | 66.86                          | 80.11                     | 46.44        |
| 67                                               | Morshi      | 4            | 11 KV RAMJI BABA                 | 65.42                          | 95.07                     | 37.81        | 11 KV TAJ COLONY                  | 93.32                          | 97.01                     | 9.47         | 11 KV SIMBHORA ROAD            | 100                            | 94.84                     | 5.16         |
| 68                                               | Murtijapur  | 8            | 11 KV TOWN - 2                   | 54.23                          | 94.29                     | 48.87        | 11KV GOYANAKA FDR                 | 80.29                          | 95.96                     | 22.95        | 11 KV TOWN-1                   | 95.79                          | 98.66                     | 5.49         |
| 69                                               | Nagpur      | 128          | 11 KV TELECOM NAGAR              | 28.4                           | 99.69                     | 71.69        | 11 KV HINGNA-I                    | 61.68                          | 98.37                     | 39.33        | 11KV CHHOTI DHANTOLI           | 63.91                          | 100                       | 36.09        |
| 70                                               | Nalasopara  | 18           | 22 KV SANTOSH BHUVAN             | 73.61                          | 99.88                     | 26.48        | SRIPRASTHA                        | 74.58                          | 100                       | 25.42        |                                |                                |                           |              |
| 71                                               | Nanded      | 78           | 11 KV MAHALAJ - SANGVI           | 43.41                          | 93                        | 59.63        | 11 KV WAMAN NAGAR                 | 51.49                          | 95.03                     | 51.07        | DEEPNAGAR 11KV FEEDER          | 69.21                          | 95.49                     | 33.91        |
| 72                                               | Nandura     | 4            | JALAGAON ROAD FEEDER             | 71.41                          | 93.03                     | 33.57        | 11 KV DAIRY                       | 91.73                          | 94.11                     | 13.67        | 11 KV BALAJI                   | 95.18                          | 100                       | 4.82         |
| 73                                               | Nandurbar   | 13           | 11 KV SHIRISHKUMAR MEHTA FEEDER  | 51.96                          | 99.8                      | 48.14        | NANDURBAR                         | 61.84                          | 97.36                     | 39.79        | PANCHAYAT SAMITI               | 66.56                          | 98.01                     | 34.76        |
| 74                                               | Nashik      | 189          | 11 KV RAJUR                      | 70.23                          | 55.32                     | 61.15        | 11 KV ADGAON I                    | 54.63                          | 75.05                     | 59           | 11 KV GANGAPUR-AG              | 76.03                          | 74.34                     | 43.48        |
| 75                                               | Navi Mumbai | 266          | 11 KV AGRJI KOLI                 | 37.72                          | 100                       | 62.28        | 22KV NOCIL-STAR                   | 49.14                          | 98.69                     | 51.5         | 11KV CIDCO PUMP HOUSE          | 50.92                          | 100                       | 49.08        |
| 76                                               | Nilanga     | 3            | NEW BANK COLONY                  | 56.27                          | 100                       | 43.73        | ASHOK NAGAR                       | 60.82                          | 100                       | 39.18        |                                |                                |                           |              |
| 77                                               | Osmanabad   | 13           | 11KV TER FEEDER                  | 74.43                          | 96.68                     | 28.04        | 11KV DARGA FEEDER                 | 75.48                          | 98.5                      | 25.65        | 11KV UPLA FEEDER               | 100                            | 93.16                     | 6.84         |
| 78                                               | Ozar        | 6            | JAILKE                           | 17.12                          | 95.94                     | 83.58        | AMBHEHILL                         | 57.36                          | 94.99                     | 45.51        | DIXI                           | 65.12                          | 100                       | 34.88        |
| 79                                               | Pachora     | 8            | 11 KV INDUSTRIAL NIRMAL          | 100                            | 52.35                     | 47.65        | 11 KV CHATRAPATI SHIVAJI NAGA     | 56.61                          | 97.49                     | 44.81        | 11 KV VASAHAT INDUSTRIAL       | 96.49                          | 81.37                     | 21.49        |
| 80                                               | Paithan     | 4            | RAPDRP POWER HOUSE               | 41.94                          | 100                       | 58.06        | RAPDRP NEW KAWSAN                 | 57.98                          | 95.54                     | 44.61        | 11KV NATH EXPRESS              | 59.79                          | 97.61                     | 41.64        |
| 81                                               | Palghar     | 18           | DIVISION OFFICE                  | 72.72                          | 99.2                      | 27.86        | 11 KV BIDCO FEEDER                | 83.22                          | 99.09                     | 17.54        | 11 KV KOTHARI FEEDER           | 93.54                          | 98.52                     | 7.84         |
| 82                                               | Pandharpur  | 13           | 11 KV SAMATA NAGAR               | 49.75                          | 98.38                     | 51.06        | 11 KV WATER WORKS                 | 88.4                           | 98.55                     | 12.88        | 11 KV SARGAM                   | 91.33                          | 96.65                     | 11.73        |
| 83                                               | Panvel      | 139          | HORIZON SCHOOL                   | 36.58                          | 98.12                     | 64.11        | 11KV STN/JAWALE                   | 49.09                          | 100                       | 50.91        | 11 KV N.T.F.C. FEEDER          | 54.19                          | 100                       | 45.81        |
| 84                                               | Parbhani    | 25           | 11KV SAKHALA PLOT                | 26.9                           | 61.1                      | 83.56        | 11 KV INDUSTRIAL NEW FEEDER       | 48.98                          | 93.17                     | 54.37        | 11 KV HADCO FEEDER             | 56.24                          | 87.87                     | 50.58        |
| 85                                               | Parli       | 7            | 11 KV KALRATRI DEVI FEEDER       | 22.91                          | 72.51                     | 83.39        | 11 KV KANYA SHALA FEEDER          | 31.96                          | 58.52                     | 81.3         | 11 KV SINCHAN BHAVAN           | 36.86                          | 70.31                     | 74.08        |
| 86                                               | Parola      | 4            | 11 KV INDUSTRIAL FEEDER          | 40.56                          | 100                       | 59.44        | 11 KV BSNL                        | 74.61                          | 97.3                      | 27.4         | 11KV JHAPATBHAWANI             | 93.51                          | 98.08                     | 8.29         |
| 87                                               | Pathri      | 2            | 11 KV PATHRI-II                  | 30.55                          | 63.38                     | 80.64        | 11 KV DEVNANDRA                   | 100                            | 41.07                     | 58.93        |                                |                                |                           |              |
| 88                                               | Pen         | 2            | 22 KV CHINCHPADA                 | 81.58                          | 98.99                     | 19.24        |                                   |                                |                           |              |                                |                                |                           |              |
| 89                                               | Phaltan     | 3            | 22KV Y. C. HIGHSCHOOL            | 78.17                          | 96.92                     | 24.24        | 22KV PHALTAN MUNICIPAL            | 94.38                          | 99.45                     | 6.14         |                                |                                |                           |              |
| 90                                               | Pulgaon     | 6            | MEDICAL                          | 37.81                          | 100                       | 62.19        | 11KV HARIRAM NAGAR                | 67.75                          | 96.35                     | 34.72        | VPF GAOTHAN                    | 84.84                          | 98.42                     | 16.5         |
| 91                                               | Pune City   | 765          | 11 KV SOBA SAVERA                | 41.49                          | 100                       | 58.51        | GHARONDA                          | 42.15                          | 100                       | 57.85        | 11 KV SAI DHAM                 | 49.14                          | 99.61                     | 51.05        |
| 92                                               | Purna       | 4            | 11KV RAILWAY OLD                 | 29.77                          | 61.75                     | 81.62        | 11KV KOLIWADA FEEDER (PURNA TOWN) | 26.16                          | 83.39                     | 78.19        | 11 KV ANAND NAGAR (PURNA TOWN) | 72.44                          | 84.29                     | 38.94        |
| 93                                               | Pusad       | 8            | 11 KV ITAWA                      | 45.31                          | 92.64                     | 58.02        | 11 KV NEW PUSAD                   | 50.21                          | 96.08                     | 51.76        | 11 KV KAKADDATI                | 100                            | 92.72                     | 7.28         |
| 94                                               | Ratnagiri   | 19           | 11KV MIDC RTN-U                  | 70.06                          | 100                       | 29.94        | 11KV SALAVI STOP,RTN-U            | 74.31                          | 97.57                     | 27.5         | 11KV RAMNAKA RTN-U             | 77.94                          | 100                       | 22.06        |
| 95                                               | Sailu       | 6            | 11KV MARWAD GALLI FEEDER         | 58.27                          | 83.21                     | 51.51        | 11KV RAILWAY STATION FEEDER       | 81.16                          | 82.75                     | 32.84        |                                |                                |                           |              |
| 96                                               | Sangamner   | 6            | 11 KV INDUSTRIAL                 | 67.58                          | 93.99                     | 36.48        | 11KV GHULEWADI                    | 77.93                          | 94.24                     | 26.56        |                                |                                |                           |              |
| 97                                               | Sangli      | 82           | 11 KV MAHAVIR                    | 32.23                          | 74.48                     | 76           | 11 KV KRISHNA GHAT                | 47.78                          | 85.69                     | 59.06        | 11 KV TAKSHILA                 | 49.59                          | 100                       | 50.41        |
| 98                                               | Satana      | 2            | 11 KV MAHALAXMI FEEDER           | 71.28                          | 95.17                     | 32.16        | 11 KV SATANA (U) FEEDER           | 80.67                          | 94.83                     | 23.5         |                                |                                |                           |              |
| 99                                               | Satara      | 29           | 22 KV MIDC (FROM SATARA ROAD SS) | 65.01                          | 97.69                     | 36.49        | 22 KV KARMVEER NAGAR              | 73.08                          | 99.06                     | 27.61        | 22KV PARANGE                   | 81.74                          | 100                       | 18.26        |
| 100                                              | Shahada     | 6            | MAIN ROAD                        | 45.67                          | 93.35                     | 57.37        | 11 KV OUTGOING MALONI FEEDER      | 47.26                          | 95.94                     | 54.66        | 11 KV OUTGOING VIKAS FEEDER    | 69.41                          | 94.7                      | 34.27        |
| 101                                              | Shegaon     | 7            | 11KV INDUSTRIAL                  | 45.73                          | 93.26                     | 57.35        | 11 KV GM MANDIR                   | 85.84                          | 99.76                     | 14.37        | 11KV TOWN I                    | 95.52                          | 100                       | 4.48         |
| 102                                              | Shirpur     | 7            | 11 KV YOGESHWAR COLONY           | 47.63                          | 100                       | 52.37        | 11 KV K.G. ROAD                   | 79.35                          | 100                       | 20.65        | 11 KV MAIN ROAD                | 80.5                           | 99.58                     | 19.84        |

| Feeder wise AT&C loss report (10% worst Feeders) |               |              |                                 |                                |                           |              |                              |                                |                           |              |                                |                                |                           |              |
|--------------------------------------------------|---------------|--------------|---------------------------------|--------------------------------|---------------------------|--------------|------------------------------|--------------------------------|---------------------------|--------------|--------------------------------|--------------------------------|---------------------------|--------------|
| Level of Monitoring: PFC/MoP                     |               |              |                                 |                                |                           |              |                              |                                |                           |              |                                |                                |                           |              |
| Format: D4                                       |               |              |                                 |                                |                           |              |                              |                                |                           |              |                                |                                |                           |              |
| Name of State: MAHARASHTRA                       |               |              |                                 |                                |                           |              |                              |                                |                           |              |                                |                                |                           |              |
| Name of Discom:MSEDCL                            |               |              |                                 |                                |                           |              |                              |                                |                           |              |                                |                                |                           |              |
| Report Month:- Nov'24                            |               |              |                                 |                                |                           |              |                              |                                |                           |              |                                |                                |                           |              |
| Input Period:- Oct'23 to Sep'24                  |               |              |                                 |                                |                           |              |                              |                                |                           |              |                                |                                |                           |              |
|                                                  |               |              |                                 |                                |                           |              |                              |                                |                           |              |                                | Date : 29/11/2024              |                           |              |
| Sr No                                            | Town Name     | Total Feeder | Feeder Name1                    | Cumulative Billing Efficiency, |                           |              | Feeder Name2                 | Cumulative Billing Efficiency, |                           |              | Feeder Name3                   | Cumulative Billing Efficiency, |                           |              |
|                                                  |               |              |                                 | Billing Efficiency (%)         | Collection Efficiency (%) | AT&C Loss(%) |                              | Billing Efficiency (%)         | Collection Efficiency (%) | AT&C Loss(%) |                                | Billing Efficiency (%)         | Collection Efficiency (%) | AT&C Loss(%) |
| 103                                              | Sillod        | 7            | AMBADASNAGAR                    | 29.55                          | 96.71                     | 71.42        | AURANGABAD NAKA              | 44.78                          | 92.62                     | 58.52        | TILAKNAGAR                     | 47.66                          | 100                       | 52.34        |
| 104                                              | Sinnar        | 5            | 11KV SINNER                     | 81.57                          | 99.39                     | 18.93        | 11 KV GAOTHA                 | 81.83                          | 100                       | 18.17        | 11 KV SARADWADI                | 92.14                          | 99.96                     | 7.9          |
| 105                                              | Solapur       | 79           | 11 KV LIMYEWADI                 | 70.56                          | 95.93                     | 32.31        | 11 KV KUMATHA GAOTHAN        | 69.41                          | 98.23                     | 31.82        | 11 KV NEHARU NAGAR             | 74.08                          | 100                       | 25.92        |
| 106                                              | Talegaon      | 5            | 22 KV MIDC-II                   | 72.68                          | 100                       | 27.32        | 22 KV NODURAN                | 92.46                          | 100                       | 7.54         | 22 KV MES                      | 97.98                          | 100                       | 2.02         |
| 107                                              | Tasgaon       | 4            | 11 KV TASGAON II                | 77.23                          | 99.46                     | 23.19        | 11 KV TASGAON I              | 81.4                           | 98.2                      | 20.07        |                                |                                |                           |              |
| 108                                              | Tuljapur      | 2            | 11 KV URBAN TULJAPUR            | 59.41                          | 55.48                     | 67.04        | 11 KV VIP FEEDER             | 84.21                          | 100                       | 15.79        |                                |                                |                           |              |
| 109                                              | Tumsar        | 3            | 11 KV JAMB TOWN                 | 91.38                          | 98.94                     | 9.59         | 11 KV GANDHINAGAR TOWN       | 93.57                          | 97.86                     | 8.43         | 11 KV TUMSAR TOWN              | 98.72                          | 98.45                     | 2.81         |
| 110                                              | Udgir         | 14           | 11KV AMBEDKAR CHOWK             | 34.84                          | 93.42                     | 67.45        | 11 KV BUS STAND              | 54.29                          | 94.22                     | 48.85        | 11KV ST COLONY FEEDER          | 62.45                          | 89                        | 44.42        |
| 111                                              | Umarga        | 1            | 11KV OMERGA URBAN               | 100                            | 87.37                     | 12.63        |                              |                                |                           |              |                                |                                |                           |              |
| 112                                              | Umarkhed      | 3            | 11 KV MIDC FEEDER               | 16.01                          | 100                       | 83.99        | 11 KV UMERKHED               | 64.5                           | 96.36                     | 37.85        |                                |                                |                           |              |
| 113                                              | Umred         | 8            | 11 KV MAKARDHOKDA               | 44.35                          | 88.02                     | 60.96        | 11KV BUDHWARI ICE FACTORY    | 76.76                          | 100                       | 23.24        | 11KV KAWARAPETH                | 89.14                          | 97.58                     | 13.02        |
| 114                                              | Uran-Islampur | 10           | 11 KV RAJARAM NAGER             | 73.12                          | 100                       | 26.88        | 11 KV URAN-ISLAMPUR GAOTHAN. | 79.8                           | 99.86                     | 20.31        | 11 KV ISLAMPUR-II FEEDER       | 83.67                          | 99.31                     | 16.91        |
| 115                                              | Vaijapur      | 5            | 11KV DARGA                      | 45.99                          | 100                       | 54.01        | 11 KV MGM                    | 70.3                           | 100                       | 29.7         | 11KV TILAKROAD                 | 75.72                          | 100                       | 24.28        |
| 116                                              | Vasai         | 9            | DATTANI                         | 58.08                          | 98.63                     | 42.72        | UMELA                        | 88.19                          | 100                       | 11.81        | 22 KV TAMDALAV                 | 96.67                          | 100                       | 3.33         |
| 117                                              | Virar         | 14           | GLOBAL CITY                     | 69.77                          | 99.73                     | 30.42        | VIRAT & YASHWANT NAGAR       | 89.45                          | 100                       | 10.55        | SOPARA FEEDER NO. 9            | 95.32                          | 100                       | 4.68         |
| 118                                              | Vita          | 6            | 11 KV BHALWANI(U)               | 67.3                           | 94.67                     | 36.29        | 11 KV PARE (U)               | 70.55                          | 95.45                     | 32.66        |                                |                                |                           |              |
| 119                                              | Wadgaon       | 4            | 11 KV JAM ROAD                  | 54.24                          | 100                       | 45.76        | 11KV SHASTRINAGAR            | 79.97                          | 96.88                     | 22.53        | 11KV PRAVIN NAGAR              | 100                            | 95.29                     | 4.71         |
| 120                                              | Wai           | 8            | 11 KV WAI MIDC II               | 47.91                          | 96.49                     | 53.77        | 22 KV COLLEGE ROAD           | 79.4                           | 96.65                     | 23.26        | 22 KV DHAGE ALI (WAI CITY ALT) | 95.09                          | 92.1                      | 12.42        |
| 121                                              | Wani          | 15           | 11 KV KAYAR (WANI)              | 45.69                          | 66.42                     | 69.65        | 11 KV SHIRPUR                | 70.06                          | 70.27                     | 50.77        | 11 KV WANI TOWN                | 70.02                          | 100                       | 29.98        |
| 122                                              | Wardha        | 23           | 11 KV F ZONE FEEDER             | 37.83                          | 95.72                     | 63.79        | 11 KV ITWARA                 | 61.86                          | 100                       | 38.14        | 11 KV G ZONE FEEDER            | 72.37                          | 88.05                     | 36.28        |
| 123                                              | Warora        | 9            | SAI FEEDER WANI ROAD            | 74.31                          | 98.84                     | 26.55        | 11 KV MADHELI NAKA           | 80.4                           | 99.23                     | 20.22        | AANANDVAN                      | 91.78                          | 95.46                     | 12.39        |
| 124                                              | Warud         | 7            | 11 KV TOWN 2                    | 57.17                          | 98.06                     | 43.94        | 11 KV TOWN 1                 | 82.48                          | 98.22                     | 18.99        |                                |                                |                           |              |
| 125                                              | Washim        | 10           | RAILWAY STATION                 | 16.54                          | 89.59                     | 85.18        | TOWN FEEDER                  | 52.42                          | 93.37                     | 51.06        | CIVIL LINE EXPRESS FEEDER      | 97.35                          | 92.81                     | 9.65         |
| 126                                              | Yavatmal      | 29           | 11 KV SARAFA BAZAR              | 38.34                          | 94.05                     | 63.94        | 11 KV AKASHWANI FEEDER       | 57.13                          | 94.41                     | 46.06        | 11 KV AMBIKA NAGAR             | 100                            | 85.02                     | 14.98        |
| 127                                              | Yawal         | 2            | VYAS MANDIR                     | 50.12                          | 97.07                     | 51.35        | YAWAL URBAN -1               | 50.63                          | 96.31                     | 51.24        |                                |                                |                           |              |
| 128                                              | Yeola         | 4            | 11 KV GANGASAGAR EXPRESS FEEDER | 62.32                          | 100                       | 37.68        | 11 KV YEOLA 2                | 88.33                          | 95.24                     | 15.87        | 11 KV YEOLA 1                  | 89.3                           | 97.39                     | 13.03        |