

ADDENDUM II

REPLY TO PRE-BID QUERIES FOR Rfs No. MSEDCL/RE/2023/500 MW Solar/Ph-X/T-19 Dated 14.02.2023				
The reply to pre-bid query at Sr.No.21 of Addendum I is reproduced as under:				
Clause No.	Existing Clause	Bidders Query / Suggestion	MSEDCL's Reply vide Addendum I	MSEDCL's Revised reply
Article 4: SYNCHRONISATION, COMMISSIONING AND COMMERCIAL OPERATION Clause no. 4.1.6	The power producer shall install complete DC capacity as per the Clause 5.5 of the PPA, at the time of Commercial Operation Date (COD) of the project. Further, the power producer shall not add/install any additional DC capacity post Commercial Operation Date (COD) of the project.	Any additional DC capacity post Commercial Operation Date (COD) i.e re-powering of the project is allowed as per clause no. (3.12.4 Repowering) of RFS. Kindly confirm.	Yes, your understanding is correct.	It is to clarify that, the repowering is referred to the replacement of old/damaged modules/components of solar power project in order to enhance the output keeping the solar project capacities AC/DC unchanged. The power producer shall install total/complete declared DC capacity at the time of Commercial Operation Date (COD) of the project. Hence, any additional DC capacity (for the same project) installed post COD shall not be considered under repowering and considered under Change in Law benefit
		"Request you to kindly delete clause no. 4.1.6 of the PPA. Clause 4.1.6 of the PPA document defines that the power producer cannot install any additional DC capacity post Commercial Operation Date (COD) of the project which is in contradiction to clause 5.4 of the PPA which states that the power producer shall be allowed to repower the project from time to time during the PPA duration to maintain the desired CUF of the project. So we request MSEDCL to kindly delete clause no. 4.1.6 of the PPA as it creates hindrance/restriction on the flexibility provided to the power producer for repowering of the project by addition of DC capacity in case power producers are not able to meet the desired CUF.	The request is not accepted. The bidders have to adhere to PPA conditions only.	