

Feeder wise AT&C loss report (10% worst Feeders)
Level of Monitoring: PFC/MoP
Format: D4

Name of State: MAHARASHTRA
Name of Discom: MSEDCL
Report Month: September'16
Input Energy Period: July'15 to June'16

Sr No	Town Name	Total Feeder	Feeder Name1	Cumulative Billing Efficiency, Collection Efficiency & AT&C Losses in %			Feeder Name2	Cumulative Billing Efficiency, Collection Efficiency & AT&C Losses in %			Feeder Name3	Cumulative Billing Efficiency, Collection Efficiency & AT&C Losses in %		
				Billing Efficiency (%)	Collection Efficiency (%)	AT&C Loss(%)		Billing Efficiency (%)	Collection Efficiency (%)	AT&C Loss(%)		Billing Efficiency (%)	Collection Efficiency (%)	AT&C Loss(%)
1	Achalpur	11	037016-202-11 KV ACHALPUR	59.83	68.81	58.83	034078-214-BAITUL ROAD	62.91	69.89	56.03	037016-205-11 KV VIDARBHA MILL	57.12	86.45	50.62
2	Ahmadpur	3	154114-202-11KV TELEPHONE FEEDER	65.11	61.56	59.92								
3	Ahmednagar	60	014036-202-11 KV SHAPE WELL	36.09	90.05	67.5	017009-208-11 KV NAV NAGAPUR	48.92	66.58	67.43				
4	Akkalkot	7	277007-202-11 KV CHAPALGAON MIX AG	25.36	98.98	74.9	274180-202-11 KV SAMARTH NAGAR FEEDER	69.76	72.48	49.44	274180-201-11 KV AKKALKOT URBAN FEEDER	65.18	78.97	48.53
5	Akola	60	024040-205-11KV NARAYAN	18.43	97.06	82.11	024048-204-11KV BHANDPURA FEEDER	34.62	60.02	79.22	024029-204-11 KV COTTON MARKET	33.35	65.63	78.11
6	Akot	7	027003-207-11 KV AKOT	40.75	66.05	73.08	027003-209-SOOTGIRNI 1	29.29	94.5	72.32	027003-204-11 KV AKOT -II	59.58	57.12	65.97
7	Amalner	6	124147-205-11 KV PRATAP MILL FEEDER	64.37	76.77	50.58	124147-204-11 KV SANENAGAR FEEDER	79.73	72.06	42.55	124147-201-11 KV TADEPURA FEEDER	86.1	71.19	38.71
8	Ambejogai	8	054067-203-11 KV MUKUNDRAJ FEEDER	36.19	68.32	75.27	054067-202-11 KV RAVIVAR PETH FEEDER	38.5	79.07	69.56	054007-201-11 KV HOSPITAL FEEDER	31.62	98.96	68.71
9	Amravati	72	034069-203-PACH BANGALA	47.66	63.9	69.55	037013-204-NAVSARI	49.57	64.55	68	034041-205-DUTTA VIHAR	49.37	81.24	59.89
10	Anjanqaon	6	034074-201-11 KV NAUGAJJI	26.25	69.81	81.67	034074-202-11 KV VIHGAON [G]	32.25	66.86	78.44				
11	Arvi	4	294023-201- INDUSTRIAL-1	57.72	95.46	44.9	294036-201-11 KV TOWN FEEDER	79.84	84.8	32.3	294036-203-11 KV INDUSTRIAL FEEDER	95.34	89.08	15.07
12	Ashta	10	244116-201-11 KV ASHTA AG	59.86	29.89	82.11	244116-205-11 KV BAWACHI AG	73.58	27.11	80.05	246003-204-11 KV FALKEWADI	62.76	35.8	77.53
13	Ashita (MSEDCL)	16	154002-206-11KV MIDC FEEDER	42.19	90.18	61.95	154112-202-11 KV CHOWRASTA FEEDER	72.13	63.09	54.49	154112-203-11 KV SAMTA NAGER	77.35	66.23	48.77
14	Balapur	2	024007-201-11 KV BALAPUR	79.08	60.92	51.82								
15	Ballarpur	6	085001-209-11 KV PUMP HOUSE	74.26	72.84	45.91	085001-215-11 KV BPM-I	82.78	76.79	36.43	085001-207-11 KV TEKADI	100	71.56	28.44
16	Baramati	7	214506-205- KHANDOBANAGAR	92.33	73.79	31.87	214506-204-T.C. COLLEGE	84.95	81.57	30.71	214506-202-DESAI ESTATE	88.68	80.45	28.66
17	Barshi	9	274197-203-11 KV BHAGAWANT FEEDER	84.38	89.72	24.29	278003-207-11KV JAIN MANDIR FEEDER	100	83.75	16.25	278003-206-11KV MILL FEEDER	100	83.82	16.18
18	Basmath	8	324010-204-11 KV RURAL	67.08	30.1	79.81	324093-203-11 KVKALNKAI FEEDER	55.72	38.35	78.63	324010-201-11 KV TOWN	43.26	51.07	77.91
19	Beed	28	054125-201-11 KV WASANWADI AG FEEDER	100	18.93	81.07	057002-202-11 KV. KANKALESHWAR FEEDER	78.55	39.29	69.14	054116-204-11 KV JYOTIBA FEEDER	90.36	58.33	47.29
20	Bhadrawati	5	084022-203-11 KV GOURALA	57.56	85.55	50.76	084022-201-11 KV GHODPETH	100	85.42	14.58	084022-403-33 KV VIJASON TO PGCL	100	95.85	4.15
21	Bhandara	9	064022-204-11 KV KHAM TALAO (TAKIYA WARD)	73.71	87.57	35.45	064022-205-11 KV NASHIK NAGAR	80.17	90.67	27.31	064022-201-11 KV AMBEDKAR WARD	100	87.36	12.64

Feeder wise AT&C loss report (10% worst Feeders)

Level of Monitoring: PFC/MoP

Format: D4

Name of State: MAHARASHTRA

Name of Discom: MSEDCL

Report Month: September'16

Input Energy Period: July'15 to June'16

Sr No	Town Name	Total Feeder	Feeder Name1	Cumulative Billing Efficiency, Collection Efficiency & AT&C Losses in %			Feeder Name2	Cumulative Billing Efficiency, Collection Efficiency & AT&C Losses in %			Feeder Name3	Cumulative Billing Efficiency, Collection Efficiency & AT&C Losses in %		
				Billing Efficiency (%)	Collection Efficiency (%)	AT&C Loss(%)		Billing Efficiency (%)	Collection Efficiency (%)	AT&C Loss(%)		Billing Efficiency (%)	Collection Efficiency (%)	AT&C Loss(%)
22	Bhusawal	16	127004-205-11 KV RAILWAY W/S EXPRESS FEE	26.4	68.8	81.84	127004-207-11 KV BHUSAWAL - TOWN	47.71	65.99	68.52	124040-205-11 KV SHRADHA NAGAR	100	89.79	10.21
23	Brahmapuri	3	084033-202-11 KV PETH WARD	59.82	86.86	48.04	084035-203-11 KV TILAK NAGAR	87.94	89.84	20.99	084035-201-11 KV DELANWADI	100	86.26	13.74
24	Buldhana	14	074047-201-11 KV MARKET	69.42	70.84	50.82	074004-201-11KV BULDANA - I	87.88	76.49	32.78	074004-202-11 KV BULDANA - II	86.22	79.82	31.18
25	Chalisgaon	8	124146-202-HUDCO COLONY	54.73	39.89	78.17	124140-213-11 KV JUNE VIMANTAL	56.52	50.61	71.4	124146-201-GHAT ROAD	58.92	49.46	70.86
26	Chandrapur	39	084008-207-11 KV LALPETH	44.95	92.67	58.34	084039-207-11 KV MULTI EXP. FEEDER	51.31	91.3	53.15	084039-203-11 KV PADOLI	64.68	83.03	46.3
27	Chikhli	4	074082-201-11 KV MIDC FEEDER	42.96	57.25	75.41	078002-203-11 KV (KELWAD) TOWN	62.47	61.64	61.49	074063-201-11 KV RAUT WADI (TOWN)	67.41	66.13	55.42
28	Chiplun	13	234051-204-11 KV KAMTHE	45.68	84.48	61.41	234051-205-11KV GOVALKOT	57.63	83.2	52.05	234033-202-11 KV PETHMAP	76.51	81.2	37.87
29	Chopda	12	124149-203-11 KV SHERE PUNJAB	37.19	75.77	71.82	127011-206-11 KV NAGALWADI GAOTHAN	100	58.02	41.98	124149-202-11 KV PANKAJ NAGAR	72.59	81.93	40.53
30	Dahanu	10	284031-206-11 KV ASHAGAD	39.46	63.12	75.09	284031-208-11 KV SARAWALI	36.83	84.82	68.76	284601-208-11 KV WAKI FEEDER	77.93	55.18	57
31	Daryapur	3	034010-203-11 KV DARYAPUR TOWN	94.4	62.98	40.55	034077-214-11 KV SAI NAGAR	91.06	66.43	39.51	034010-204-11KV SOOTGIRANI	100	96.54	3.46
32	Daund	2	217015-303-22 KV RAILWAY	76.12	70.35	46.45	217015-302-22 KV DAUND	100	61.99	38.01				
33	Deglur	6	174007-207-GOVT. HOSPITAL EXPRESS FEEDER	100	45.39	54.61	174007-205-11 KV TOWN 4	67.34	68.74	53.71	174007-202-11 KV TOWN 2	98.81	57.77	42.92
34	Deolali	18	184029-207-11KV SANSARI	56	37.15	79.2	184029-201-11KV DHADEGAON	66.34	55.35	63.28	184107-201-11 KV BALGRUHA ROAD	57.51	85.51	50.82
35	Dharangaon	6	124135-202-11KV CHINTAMAN MOURYA NAGAR	79.27	72.92	42.2	127013-202-11 KV DHARANGAON	93.75	65.02	39.04	124135-201-11KV GANESH NAGAR	100	68.03	31.97
36	Dhule	46	094036-202-11 KV VADJAI ROAD	38.76	69.88	72.91	094016-206-11 KV EKVIRA	42.13	69.45	70.74	094035-205-11 KV DATTA MANDIR	36.63	83.38	69.46
37	Digras	5	305002-203-11 KV TOWN 2	38.83	68.36	73.46	305002-204-11 KV TOWN 1	52.84	71.68	62.12	305002-201-11KV RURAL	73.91	73.26	45.85
38	Dondaicha	6	097002-208-11KV DONDAICHA	75.88	63.57	51.76	097002-205-11KV SINDHI COLONY, DONDAICHA	96.75	88.84	14.05	094062-202-UNIVERSAL STARCH ALLIED (USA)	95.37	99.13	5.46
39	Erandol	4	124064-207-11 KV GANDHIPURA	67.89	67.74	54.01	124064-203-11 KV ERANDOL	82.58	74.68	38.33	124064-206-11 KV M.I.D.C FEEDER	76.22	86.99	33.7
40	Gadchiroli	7	105004-209-11 KV HOSPITAL EXPRESS	52.74	94.87	49.97	104018-201-11KV COMPLEX FEEDER	73.75	86.41	36.27	105004-205-11KV POST OFFICE	94.68	83.86	20.6
41	Gangakhed	11	204011-205-11 KV KHALI (SHIVAJI NAGAR)	32.82	53.16	82.55	204011-206-11 KV RAILWAY STATION	50.95	43.95	77.61	204097-203-11 KV MIDC FEEDER	61.04	41.95	74.39
42	Gondia	16	314012-202-TOWN - II	51.29	80.76	58.58	314025-202-URBAN INDUSTRIAL	61.25	98	39.98	314028-203-VIJAYNAGAR	83.71	83.96	29.72
43	Greater Mumbai	499	286052-303-POKHRAN-I	16.61	99.09	83.54	288058-306-IVRCL (UNITY)	17.61	99.14	82.54	283087-303-SHIL PHATA	40.1	49.15	80.29

Feeder wise AT&C loss report (10% worst Feeders)

Level of Monitoring: PFC/MoP

Format: D4

Name of State: MAHARASHTRA

Name of Discom: MSEDCL

Report Month: September'16

Input Energy Period: July'15 to June'16

Sr No	Town Name	Total Feeder	Feeder Name1	Cumulative Billing Efficiency, Collection Efficiency & AT&C Losses in %			Feeder Name2	Cumulative Billing Efficiency, Collection Efficiency & AT&C Losses in %			Feeder Name3	Cumulative Billing Efficiency, Collection Efficiency & AT&C Losses in %		
				Billing Efficiency (%)	Collection Efficiency (%)	AT&C Loss(%)		Billing Efficiency (%)	Collection Efficiency (%)	AT&C Loss(%)		Billing Efficiency (%)	Collection Efficiency (%)	AT&C Loss(%)
44	Hinganghat	10	295011-203-11 KV TELANGKHEDI FEEDER	68.83	83.32	42.65	295011-205-11KV IND-1 FEEDER	100	79.41	20.59	295011-207-11KV TOWN FEEDER	100	80.31	19.69
45	Hingoli	9	324071-204-11KV SRP	47.09	57.88	72.74	324071-201-11KV ADM.BLDG	53.65	60.83	67.36	324071-202-11KV TOWN-II	100	54.77	45.23
46	Ichalkaranji	115	148015-402-TILAWANI MINOR	21.34	94.76	79.78	144055-202-11KV GANPATI MANDIR AG	34.98	85.04	70.25	144050-202-11 KV DECCAN PROCESS	40.29	98.04	60.5
47	Igatpuri	3	187001-201-11KV TITOLI	75.22	77.84	41.45	187001-203-11KV IGATPURI U	83.51	73.63	38.51	187001-401-MAHINDRA & MAHINDRA	98.56	99.25	2.18
48	Jaisingpur	9	144074-201-11KV RAILWAY	79.71	89.47	28.68	144036-209-KULKARNI POWER TOOLS	73.05	98.25	28.23	146005-206-11KV SIDHESHWAR	83.48	88.14	26.42
49	Jalna	26	137003-206-GEDORE 11KV	17.14	96.02	83.54	134028-210-11 KV TV CENTRE NEW	34.91	52.63	81.63	137003-204-11KV SHAKTI FEEDER	22.8	94.7	78.41
50	Jintur	6	207010-203-TOWN - SHIVAJI NAGAR FEEDER	42.43	39.38	83.29	204053-205-11KV POST OFFICE	100	34.82	65.18				
51	Kamptee	6	164001-203-11 KV MODI	30.11	75	77.42	164001-202-11 KV NERI 1 FDR	32.31	74.57	75.91	165001-208-11 KV KAMPTEE I	36.58	84.93	68.93
52	Kannad	4	044097-203-TOWN 3	27.93	60.22	83.18	044097-204-TOWN 4	49.8	67.89	66.19	044097-202-TOWN-II	50.98	70.47	64.07
53	Karad	8	254001-205-11 KV WAKHAN ROAD	100	71.44	28.56	254001-201-11 KV NAGARPALIKA	96.8	75.21	27.2	254001-206-11 KV COTTAGE HOSPITAL	91.87	84.65	22.23
54	Karanja	6	344029-204-11 KV KARANJA INDUSTRIAL FEEDER	23.94	96.34	76.94	344029-203-11 KV GAWALIPURA FEEDER	69.59	61.84	56.97	344029-206-11 KV BHILKHEDA INDUSTRIAL FEE	63.19	82.93	47.6
55	Katol	5	164054-203-11 KV IUDP FEEDER	74.15	86.2	36.08	164054-202-11 KV BUS STAND	86.7	85.98	25.46	164054-201-11 KV LAXMINAGAR	100	77.19	22.81
56	Khamgaon	16	074076-202-11 KV JANUNA	27.3	74.65	79.62	074076-203-11 KV QMKARESHWAR	40.36	64.5	73.97	074076-201-11 KV INDUSTRIAL	41.77	92.17	61.5
57	Khopoli	6	226001-309-22 KV KHOPOLI RURAL	64.77	59	61.79	226001-302-22 KV KHOPOLI TOWN	80.83	76.75	37.96	226001-301-22 KV HPCL	68.7	99.1	31.92
58	Kolhapur	104	144034-201-11KV KASABA BAWADA	43.66	90.34	60.56	144102-204-11KV SHAHU COLLEGE FEEDER	48.41	87.81	57.49	144033-202-HOCKY STADIUM	58.21	86.18	49.83
59	Kopargaon	5	017004-205-11 KV KOPERGAON URBAN	70.99	73.13	48.09	014109-202-11 KV INDUSTRIAL	55.22	96.93	46.48	014109-201-11 KV SANJIWANI	65.71	99.2	34.82
60	Latur	34	154073-203-11 KV OLD SHASHAKIYA	57.68	92.59	46.59	154073-201-11 KV CHAITANYA	64.22	94.12	39.56	154077-201-11KV MALVATI	68.26	93.87	35.92
61	Lonavala	15	213343-302-22 KV WATER WORKS	80.73	87.74	29.17	216016-301-22 KV KURVANDE	100	70.84	29.16	213343-301-22 KV VALVAN	100	73.1	26.9
62	Majalgaon	4	054001-205-11 KV EXPRESS	31.31	93.61	70.69	054001-201-11KV MANJRATH	63.23	53.79	65.99	054001-204-11KV MAJALGAON	100	46.95	53.05
63	Malegaon	33	184044-205-MACCHI BAJAR FEEDER	33.76	63.73	78.48	184268-207-11KV KUSAMBA ROAD	45.56	72.07	67.16	184044-203-POWER HOUSE	58.99	73.61	56.58
64	Malkapur	9	074046-203-11 KV WATER FILTER EXP	100	24.45	75.55	074091-201-11KV SHIVAJI NAGAR	84.13	63.73	46.38	077001-206-11 KV TOWN (MLK)	100	74.18	25.82
65	Manmad	10	184270-202-11KV CAMP	40.05	65.18	73.9	184270-201-11KV PAKIJA	54.49	70.53	61.57	187002-401-33KV BPCL	54.53	92.88	49.35
66	Mehkar	8	077004-204-11 KV MEHKAR TOWN 1	84	61.36	48.46	077004-202-11 KV MEHKAR TOWN 2	89.74	62.12	44.25				

Feeder wise AT&C loss report (10% worst Feeders)

Level of Monitoring: PFC/MoP

Format: D4

Name of State: MAHARASHTRA

Name of Discom: MSEDCL

Report Month: September'16

Input Energy Period: July'15 to June'16

Sr No	Town Name	Total Feeder	Feeder Name1	Cumulative Billing Efficiency, Collection Efficiency & AT&C Losses in %			Feeder Name2	Cumulative Billing Efficiency, Collection Efficiency & AT&C Losses in %			Feeder Name3	Cumulative Billing Efficiency, Collection Efficiency & AT&C Losses in %		
				Billing Efficiency (%)	Collection Efficiency (%)	AT&C Loss(%)		Billing Efficiency (%)	Collection Efficiency (%)	AT&C Loss(%)		Billing Efficiency (%)	Collection Efficiency (%)	AT&C Loss(%)
67	Morshi	4	034067-204-11 KV TAJ COLONY	90.87	79.28	27.96	034067-203-11 KV RAMJI BABA	91.39	83.48	23.71	034067-201-11 KV SIMBHORA ROAD	100	86.62	13.38
68	Murtijapur	6	025007-201-11KV NAGOLI AG FEEDER	28.69	87.83	74.8	025007-202-11 KV TOWN - 2	100	70.76	29.24	025007-203-11 KV TOWN-1	92.35	78.33	27.66
69	Nagpur	122	164812-204-SARAF COURT	26.44	96.15	74.58	162006-229-11KV VASANT NAGAR	45.97	97.15	55.34	162606-225-11KV SHIVAJI NAGAR	60.15	92.4	44.42
70	Nalasopara	17	286010-309-SOPARA FEEDER NO. 9	41.8	81.99	65.73	283503-303-22KV VASANT NAGARI FEEDER	77.47	53.78	58.34	286010-310-MANVELPADA SUBSTN	86.25	58.96	49.15
71	Nanded	69	178003-207-11 KV GOPALCHAWDI	43.73	44.8	80.41	174096-203-11 KV TUPPA AG	98.52	27.87	72.54				
72	Nandura	7	074029-204-11 KV NANDURA AG	100	35.84	64.16	074029-207-11 KV BALAJI	48.08	98.99	52.41	074029-201-11 KV TOWN	88.18	72.87	35.74
73	Nandurbar	21	334001-203-ZARALI	65.59	58.42	61.68	334001-202-NANDURBAR	60.65	65.4	60.33	334001-205-PANCHAYAT SAMITI	60.41	75.53	54.37
74	Nashik	199	184103-203-11 KV PETHROAD	20.13	78.84	84.13	187011-407-33 KV GLAXO	18.07	99.08	82.1	184118-204-11 KV KALIKA	21.91	90.01	80.28
75	Navi Mumbai	263	229019-406-33KV CBD - I	23.94	98.95	76.31	229019-404-33KV CBD - II	28.18	94.04	73.5	284055-207-11 KV AGRRI KOLI	65.51	90.26	40.87
76	Nilanga	6	154115-203-NEW COURT FEEDER	57.87	60.78	64.83								
77	Osmanabad	18	194089-201-11 KV WADAGA AG	44.18	46.53	79.44	194001-211-NEW COLLECTOR OFFICE	100	29.8	70.2	194001-209-11 KV NEW SHIVAJI CHOUK	40.73	75.15	69.39
78	Ozar	6	187003-205-DIXI	59.06	46.05	72.8	187003-204-JAULKE	37.01	98.09	63.7	184246-202-11 KV KHERWADI	54.1	72.8	60.62
79	Pachora	10	124148-201-11 KV CHATRAPATI SHIVAJI NAGA	52.42	68.68	64	124148-203-11 KV PANDAV NAGARI FEEDER	69.13	60.87	57.92	124125-202-11 KV VASAHA INDUSTRIAL	52.49	89.28	53.14
80	Paithan	6	044056-202-11 KV POWER HOUSE	52.4	52.11	72.69	044099-202-RAPDRP POWER HOUSE	49.3	63.99	68.45	044099-201-RAPDRP NEW KAWSAN	60.98	61.02	62.79
81	Palghar	18	284022-202-11 KV MASWAN FEEDER	33.07	90.44	70.09	284024-203-11 KV ALLYALI FEEDER	44.72	97.64	56.34	284023-201-11 KV GANESH KUND FEEDER	57.52	82.76	52.4
82	Pandharpur	11	274144-203-11 KV ISBAWI	54.58	83.39	54.49	276001-203-11 KV VITHAL MANDIR	72.02	81.33	41.43	274144-201-11 KV MANISHA NAGAR	69.97	86.76	39.29
83	Panvel	109	223003-307-22 KV CHINCHPADA	15.37	99.04	84.78	224010-202-11 KV CIDCO S/STN SEC-10	39.94	93.43	62.68	223001-310-22 KV PANVEL-III	96.94	90.93	11.85
84	Parbhani	31	204070-204-11 KV INDUSTRIAL NEW FEEDER	46.32	64.75	70.01	207002-404-33KV MIDC	30.64	99.6	69.48	204061-205-11KV RAJARANI	100	34.2	65.8
85	Parli	10	054004-201-11 KV VAIJNATH FEEDER	100	18.09	81.91	054137-201-11 KV KANYA SHALA FEEDER	40.13	48.7	80.46	054131-201-11 KV BUS STAND	52.4	48.25	74.72
86	Parola	3	124006-202-11 KV INDUSTRIAL FEEDER	72.56	56.6	58.93	124006-209-11KV JHAPATBHAWANI	61.6	67.53	58.4	124006-201-11 KV PAROLA URBAN FEEDER	73.33	65.17	52.21
87	Pathri	4	204012-206-11 KV PATHRI-II	33.5	52.16	82.53								
88	Pen	4	223003-309-22 KV ACMAY INDUSTRIAL	45.92	99.98	54.09	223003-305-22 KV MAHADA	66.49	78.7	47.67	223003-307-22 KV CHINCHPADA	66.19	84.82	43.86
89	Phaltan	3	257004-302-22KV Y. C. HIGH SCHOOL	91.94	80.67	25.83	257004-301-22KV PHALTAN	97.74	76.61	25.12	257004-306-22KV PHALTAN MUNICIPAL	98.92	100	1.08
90	Pulgaon	5	294033-202-VPF GAOTHAN	56.97	82.45	53.03	294033-207-MEDICAL	59.75	100	40.25	294033-205-PULGAON TOWN	83.89	86.01	27.85

Feeder wise AT&C loss report (10% worst Feeders)

Level of Monitoring: PFC/MoP

Format: D4

Name of State: MAHARASHTRA

Name of Discom: MSEDCL

Report Month: September'16

Input Energy Period: July'15 to June'16

Sr No	Town Name	Total Feeder	Feeder Name1	Cumulative Billing Efficiency, Collection Efficiency & AT&C Losses in %			Feeder Name2	Cumulative Billing Efficiency, Collection Efficiency & AT&C Losses in %			Feeder Name3	Cumulative Billing Efficiency, Collection Efficiency & AT&C Losses in %		
				Billing Efficiency (%)	Collection Efficiency (%)	AT&C Loss(%)		Billing Efficiency (%)	Collection Efficiency (%)	AT&C Loss(%)		Billing Efficiency (%)	Collection Efficiency (%)	AT&C Loss(%)
91	Pune City	728	213403-202-11 KV GANESH VIHAR	17.86	86.53	84.55	213382-304-QUEENS TOWN RMU NO. 2	17.3	91.3	84.21				
92	Purna	4	204079-202-11 KV ANAND NAGAR (PURNA TOWN)	45.03	43.15	80.57	204019-201-11KV BUS STAND	95.15	25.77	75.48	204019-202-11KV RAILWAY OLD	85.2	32.37	72.42
93	Pusad	10	304078-206-11 KV KAKADDATI	43.64	55.8	75.65	304038-201-11 KV ITAWA	42.05	62.62	73.67	304078-202-11 KV TOWN 3	46.73	60.71	71.63
94	Ratnagiri	28	234032-202-11KV INDUSTRIAL-2	17.18	97.75	83.21	234001-202-11KV KARLA, RTN-U	42.72	90.08	61.52	234002-201-11KV BHAGWATI BANDAR RTN-U	57.91	86.35	49.99
95	Sailu	12	204008-207-11KV TOWN 3	85.84	34.42	70.45	204086-201-11KV RAILWAY STATION FEEDER	100	35.34	64.66	204008-201-11KV TOWN-1	100	39.36	60.64
96	Sangamner	14	014016-201-11 KV PIMPARNE	71.4	29.79	78.73	014145-203-11 KV MALDAD GAVTHAN	56.58	58.49	66.91	014105-201-11KV MARKET YARD	57.13	75.29	56.99
97	Sangli	87	244122-203-11 KV TIMBER AREA	29.05	90.66	73.66	244070-202-11 KV GMIE	40.72	95.59	61.08	244008-206-VIDYA NAGAR	48.08	86.97	58.18
98	Satana	2	184262-202-11 KV MAHALAXMI FEEDER	70.43	70.9	50.07	184262-201-11 KV SATANA (U) FEEDER	80.17	71.67	42.54				
99	Satara	30	254017-206-11 KV SHENDRE GAONTHAN	27.2	82.81	77.48	253001-304-22KV CIVIL HOSPITAL	50.8	100	49.2	254071-302-22 KV SADAR BAZAR	93.38	77.78	27.37
100	Shahada	4	334045-203-11 KV OUTGOING MALONI FEEDER	38	65.8	75	334045-201-11 KV OUTGOING VIKAS FEEDER	58.23	76.94	55.2				
101	Shegaon	12	074037-204-11KV INDUSTRIAL	36.28	97.64	64.58	074037-202-11KV TOWN II	62.77	78.71	50.59	074037-201-11KV TOWN I	97.1	85.62	16.86
102	Shirpur	5	094002-208-11 KV YOGESHWAR COLONY	46.26	73.88	65.82	094002-207-11 KV EXPRESS FEEDER PW2	50.13	96.13	51.81	094002-201-11 KV MAIN ROAD	66.18	80.65	46.63
103	Sillod	11	047025-202-11KV SILLOD TOWN-2-TEACHER COL	69.94	53.54	62.55	044096-202-TILAKNAGAR	65.66	64.67	57.54	044096-204-TOWN 1	100	60.14	39.86
104	Sinnar	2	187009-202-11KV SINNER	72.95	80.9	40.98	187009-207-11KV MALEGAON	100	70.24	29.76				
105	Solapur	94	274122-201-11 KV SHANTI NAGAR	18.78	86.46	83.76	274068-208-11 KV SHANTIVAN	26.85	77.07	79.31	274184-203-11 KV VIJAPUR NAKA	40.56	81.98	66.75
106	Talegaon	5	216011-310-22 KV MIDC-II	76.09	83.09	36.78	216011-303-22 KV MES	88.39	74.87	33.82	216011-301-22 KV NODURAN	92.54	78.86	27.02
107	Tasgaon	9	244086-202-11 KV TASGAON II	80.87	86.06	30.4	244086-201-11 KV TASGAON I	100	86.55	13.45	246005-406-33 KV SUT GIRANI	99.08	96.69	4.2
108	Tuljapur	4	194009-205-11 KV VIP FEEDER	59.66	51.09	69.52	194009-201-11 KV URBAN TULJAPUR	74.02	43.61	67.72				
109	Tumsar	3	064034-204-11 KV JAMB TOWN	84.64	89.36	24.37	064034-208-11 KV GANDHINAGAR TOWN	93.5	82.53	22.83	064034-203-11 KV TUMSAR TOWN	100	87.32	12.68
110	Udgir	18	154042-201-11 KV TOWN	40.1	63.47	74.55	154100-204-11 KV MAHADA	48.38	61.1	70.44	154053-202-11 KV TALWES	63.23	61.45	61.15
111	Umarga	1	197001-201-11KV OMERGA URBAN	75.23	64.67	51.35								

Feeder wise AT&C loss report (10% worst Feeders)

Level of Monitoring: PFC/MoP

Format: D4

Name of State: MAHARASHTRA

Name of Discom: MSEDCL

Report Month: September'16

Input Energy Period: July'15 to June'16

Sr No	Town Name	Total Feeder	Feeder Name1	Cumulative Billing Efficiency, Collection Efficiency & AT&C Losses in %			Feeder Name2	Cumulative Billing Efficiency, Collection Efficiency & AT&C Losses in %			Feeder Name3	Cumulative Billing Efficiency, Collection Efficiency & AT&C Losses in %		
				Billing Efficiency (%)	Collection Efficiency (%)	AT&C Loss(%)		Billing Efficiency (%)	Collection Efficiency (%)	AT&C Loss(%)		Billing Efficiency (%)	Collection Efficiency (%)	AT&C Loss(%)
112	Umarkhed	3	304039-206-11 KV MIDC FEEDER	33.71	79.08	73.34	304052-201-11 KV TOWN FEEDER	64.07	66.69	57.27	304039-201-11 KV UMERKHED	100	74.2	25.8
113	Umred	3	164055-201-11KV GANGAPUR	100	83.74	16.26	164055-202-11KV SONEZARI	98.4	85.52	15.85				
114	Uran-Islampur	13	244005-205-11 KV ISLAMPUR AG FEEDER	100	33.62	66.38	244005-203-11 KV LIS FEEDER	52.01	72.9	62.08	244005-201-11 KV ISLAMPUR-I FEEDER	52.69	87.27	54.02
115	Vaijapur	8	044093-201-11KV DARGA	40.03	47.54	80.97	044093-203-11KV TILAKROAD	48.85	53.64	73.8	047021-207-TOWN-II	63.6	58.37	62.88
116	Vasai	10	283507-303-CHULNA ROAD	25.26	94.43	76.15	283210-357-22 KV MULGAON	49.71	82.16	59.16	283210-351-UMELA	84.94	77.61	34.08
117	Virar	12	283109-303-GLOBAL CITY	63.27	75.88	51.99	283109-302-Y.K.NAGAR	67.18	90.3	39.34	283092-302-ARNALA FEEDER	100	92.75	7.25
118	Vita	4	244006-203-11 KV BHALWANI(U)	35.72	78.78	71.86	244006-202-11 KV LENGARE (U)	58.46	84.63	50.53	244006-201-11 KV VITA(U)	100	77.47	22.53
119	Wadgaon	7	304040-203-11KV PRAVIN NAGAR	83.3	71.57	40.38	304040-201-11KV WADGAON	100	75.55	24.45				
120	Wai	6	254019-203-11 KV WAI NAGARPALIKA PWW	34.11	99.26	66.14	257014-302-22 KV COLLEGE ROAD	80.87	76.37	38.24	254019-201-11 KV WAI MIDC	69.7	93.56	34.79
121	Wani	14	304074-203-11 KV MIDC NEW	30.5	83.27	74.6	304074-208-11 KV MIDC OLD	39.46	68.68	72.9	304074-201-11 KV MAREGAON (WANI)	64.7	65.29	57.76
122	Wardha	15	294027-204-11 KV ESSENTIAL FEEDER	35.14	96.9	65.95	294048-206-11 KV SNEHAL NAGAR	55.32	86.96	51.89	294027-205-11 KV INDIRA SUT GIRINI FEEDER	50.31	97.99	50.7
123	Warora	5	084028-206-11 KV TOWN	90.56	87.92	20.38	084028-202-11 KV INDUSTRIAL	100	85.8	14.2				
124	Warud	5	034066-202-11 KV TOWN 2	53.62	82.09	55.98	034066-201-11 KV TOWN 1	61.26	88.65	45.69	034066-203-11 KV WATER WORKS	62.08	98.97	38.56
125	Washim	17	344001-203-NARAYANBABA	47.01	52.89	75.14	344028-203-URBAN	55.8	61.36	65.76	344001-201-RAILWAY STATION	58.13	69.4	59.66
126	Yavatmal	28	304066-207-11KV NETAJI NAGAR	38.29	69.01	73.58	304053-202-11 KV ST WORK SHOP	38.74	69.36	73.13	304017-204-11KV GLOBAL	59.51	95.15	43.38
127	Yawal	4	124138-201-YAWAL URBAN -1	53.81	67.68	63.58	124138-202-VYAS MANDIR	78.47	63.68	50.03	124138-203-INDUSTRIAL FEEDER	97.35	99.1	3.53
128	Yeola	4	184001-202-11 KV YEOLA 2	86.78	68.74	40.35	184001-208-11 KV YEOLA - 3	95.41	69.58	33.61	184001-201-11 KV YEOLA 1	98.95	76.65	24.15