



No.SE/LM/Circular/

No 21024
Circular No.48

Date : **2 JUL 2014**

Sub : Revision in DCL computation criteria in respect of feeders lying in 'NAXALITE' affected areas.

Ref : 1. Load Shedding Circular No.46 dt.14/01/2013.

It is observed that, even though the feeders having Agriculture load more than 25% in Naxalite affected areas; the use of Agriculture pumps is very less because of low water level and other obvious constraints.

Therefore to improve power supply availability to the consumers in Naxalite affected areas, a new methodology is approved by Competent Authority in DCL computation criteria.

DCL computation criteria in respect of feeders lying in 'NAXALITE' affected areas

- I) While calculating DCL of feeders lying in 'NAXALITE' affected areas; Collection efficiency of only R,C,I consumers shall be considered.
- II) Loss of whole feeder shall be considered.

After considering above, DCL shall be computed as below-

$$\text{DCL} = 100 - \frac{(100 - \text{LT loss of the feeder}) * (\text{Coll. Efficiency of RCI consumers only})}{100}$$

The above guidelines should be implemented with immediate effect.

Director (Operations)

To All C.E.s, O&M, MSEDCL, Mumbai.

Copy s.w.rs to :-
The Hon.M.D., MSEDCL, Mumbai.

Copy f.w.cs.to :-
The Director (Finance) / (Project) / (V&S) , MSEDCL, Mumbai.

Copy to :-

1. The Executive Director CP /Projects / HR / Comm., MSEDCL, Mumbai.
2. The Regional Executive Director Pune/Kalyan/Nagpur.
3. The Chief Engineer (SLDC), MSETCL, Kalwa.
4. The C.G.M. (CC), MSEDCL, Mumbai.
5. The Chief Engineer, PP/IR/Dist./Comm./APDRP/Infra. ,MSEDCL, Mumbai.
6. The Principle Consultant, (Distribution Franchisee), MSEDCL, Mumbai.
7. All S.E.s, O&M, MSEDCL, Mumbai.
8. The S.E.. LM Cell, MSEDCL, Airoli.
9. The S.E. (TRC), MSEDCL, Mumbai.
10. The Nodal Officers. Franchisee, Bhiwandi / Jalgaon/ Nagpur/A'bad.
11. O.S.D. to M.D., MSEDCL, Mumbai.
12. All E.E.s, O&M, MSEDCL, Mumbai.

Copy s.w.rs.to :-
The Secretary,
Maharashtra Electricity Regulatory Commission,
World Trade Centre, Centre No.1, 13th Floor, Cuffe Parade,
Mumbai-400 005.