

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214405 / 33 KV OTUR

Feeder No / Name : 201 / Udapur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.052	.0671	.0343	.0572	.0572
2	.0572	.0572	.052	.0671	.0343	.0762	.0572
3	.0572	.0572	.0509	.0671	.0347	.0762	.0762
4	.0572	.0572	.0678	.0686	.052	.0762	.0762
5	.0762	.0762	.0678	.0867	.0526	.0953	.0762
6	.0762	.0953	.0943	.0867	.0532	.0953	.0953
7	.0762	.1334	.1029	.1134	.0848	.1143	.0953
8	.0953	.1715	.1187	.1311	.1311	.1524	.0762
9	.1143	.1905	.1492	.1475	.1562	.1715	.0762
10	.0914	.1698	.2286	.1905	.1905	.1334	.0937
11	.108	.1739	.2096	.1334	.1905	.1572	.0937
12	.1107	.1581	.2286	.1143	.1715	.1698	.1372
13	.1265	.1562	.1715	.0762	.1334	.1698	.1505
14	.125	.1406		.0953	.1334	.1562	.1543
15	.125	.1423	.1334	.0953	.1143	.1423	.1543
16	.1235	.1265	.1334	.1143	.1334	.1581	.1372
17	.1235	.1235	.1334		.1334	.16	.1372
18	.1334	.1524	.1524	.1524	.1524	.1715	.1524
19	.1334	.1334	.1334	.1524	.1715	.1524	.1715
20	.1334	.1334	.1143	.1524	.0953	.1334	.1524
21	.1334	.0953	.1143	.1334	.0953	.1143	.1334
22	.1143	.0762	.0953	.1334	.0572	.1143	.1143
23	.0953	.0762	.1143	.0953	.0572	.1143	.0762
24	.0762	.0953	.0572	.0671	.0514	.0572	.0953
Max	.1334	.1905	.2286	.1905	.1905	.1715	.1715
Min	.0572	.0572	.0509	.0671	.0343	.0572	.0572
Avg	.1008	.1187	.1207	.1105	.1047	.1258	.1100

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214405 / 33 KV OTUR

Feeder No / Name : 202 / Dumbarwadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6287	.7621	1.3957	1.4712	1.5089	.6859	.743
2	.6287	.8383	1.3957	1.4901	1.5466	.724	.8002
3	.6668	.9145	1.4523	1.5089	1.6032	.8383	.8764
4	.7049	.9907	1.5089	1.5844	1.6409	.8764	.9335
5	.7811	1.0669	1.5466	1.6409	1.6975	.9717	.9907
6	.8764	1.1431	1.6032	1.6975	1.7541	1.0288	1.0288
7	1.1241	1.1812	2.2822	2.0748	2.2445	1.105	1.0669
8	1.086	.9526	2.6029	2.6783	2.8292	.9526	1.0098
9	1.0288	.9335	2.1691	2.4897	2.7161	.8764	.9335
10	1.8107	2.584	.9145	.8002	1.0098	1.0799	1.4861
11	2.2634	2.999	.9335	.8383	.9907	1.3969	1.5449
12	2.4981	3.0178	.9526	.8383	.9907	1.704	1.6644
13	2.7161	2.8481	.9145	.8764	.9145	1.4765	1.4575
14	2.0671	2.6217	.8954	.8954	.8383	1.4003	1.3908
15	1.7375	2.6217	.8573	.9526	.8002	1.262	1.3432
16	1.4289	2.6029	.9145	.9717	.8573	1.2803	1.3336
17	1.3535	2.4331	.9335		.9145	1.3432	1.3051
18	1.9243	1.1431	.724	.8573	.9717	2.2291	.9145
19	1.4861	1.086	1.0479	.9907	1.0288	1.5623	.9335
20	1.2574	1.0288	1.1812	1.105	1.1622	1.2193	.9907
21	1.0288	.9717	1.0479	1.0288	1.0479	1.0479	1.0288
22	.9526	.9335	.9145	.9335	.9526	.8764	.9145
23	.7811	.6668	.743	.8192	.8573	.7621	.7811
24	.6097	.6859	1.358	1.4146	1.1622	.6668	.6668
Max	2.7161	3.0178	2.6029	2.6783	2.8292	2.2291	1.6644
Min	.6097	.6668	.724	.8002	.8002	.6668	.6668
Avg	1.3100	1.5428	1.2620	1.3025	1.3350	1.1403	1.0891

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214405 / 33 KV OTUR

Feeder No / Name : 203 / Tikekarwadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.282	.4513	.4854	.3185	.3761	.3685
2	.2408	.2789	.4506	.4809	.4357	.3654	.369
3	.2378	.3078	.4507	.4885	.5428	.3506	.39
4	.2552	.3292	.4489	.4969	.3985	.359	.402
5	.2593	.3574	.4672	.519	.3764	.3673	.4269
6	.3488	.3994	.5	.5674	.4352	.4116	.4809
7	.4858	.4321	.839	.7206	.7217	.5007	.5607
8	.5822	.5266	1.0951	1.0675	.9693	.5434	.6821
9	.7353	.5235	1.0814	1.1454	1.0578	.6599	.7678
10	1.2241	1.2742	.7848	.7339	.8033	1.1721	1.3581
11	1.315	1.3748	.8173	.8139	.7827	1.291	1.4556
12	1.3451	1.3489	.815	.8429	.7788	1.3923	1.4357
13	1.3838	1.314	.7484	.8101	.8169	1.3854	1.3794
14	1.3801	1.169	.7009	.8253	.7217	1.4174	1.3245
15	1.3489	1.1218	.6489	.8087	.6882	1.4114	1.3101
16	1.3253	1.0711	.694	.856	.6242	1.3767	1.3116
17	1.3069	1.1134	.7324	.5944	.2954	1.3703	1.2689
18	.7011	.5485	.6234	.751	.6119	.8459	.7171
19	.599	.4462	.586	.6532	.8113	.7293	.6387
20	.4901	.3967	.5091	.5618	.7335	.6318	.5319
21	.4672	.354	.4321	.4603	.6142	.5396	.5251
22	.4115	.3323	.3932	.4203	.5015	.4473	.5129
23	.3483	.2614	.3398	.3603	.3967	.3711	.4321
24	.3391	.3871	.4849	.4923	.4418	.3703	.4008
Max	1.3838	1.3748	1.0951	1.1454	1.0578	1.4174	1.4556
Min	.2378	.2614	.3398	.3603	.2954	.3506	.3685
Avg	.7245	.6646	.6289	.6648	.6199	.7786	.7938

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214405 / 33 KV OTUR

Feeder No / Name : 204 / otur city

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.4755		.443		.5068	.4784
2	.362	.5304		.4607		.543	.5493
3	.4706	.5853		.0143		.5792	.6201
4	.543	.6401		.5316		.6268	.691
5	.5853	.695		.567		.6805	.7619
6	.6584	.7316		.6733		.7442	.8328
7	.8779	.7499		.691		.7973	.8505
8	.8048	.7682		.7087		.7442	.7619
9	.7316	.7682		.7087		.7619	.6733
10	.6401	.691		.5847		.691	.6201
11	.6036	.5609		.5721		.6556	.5847
12	.5853	.5258		.5548	.567	.6024	.5847
13	.5487	.5258		.5487		.567	.5847
14	.5304	.4908		.5144		.5493	.5316
15	.5304	.4854	.4784	.4801	.4784	.5316	.5493
16	.5121	.4908	.4961	.4458		.5847	.5493
17	.5121	.5434	.5138		.567	.6379	.5493
18	.5853	.5721		.5765		.6556	.6556
19	.6036	.6556		.6935	.7265	.6556	.7619
20	.6219	.7442		.8059		.6733	.7442
21	.6584	.8596		.724		.6733	.7442
22	.5487	.5731		.5611		.6733	.6379
23	.4938	.4887	.5138	.4938	.4525	.5493	.5316
24	.3841	.4207	.4525	.4252	.4435	.4525	.4075
Max	.8779	.8596	.5138	.8059	.7265	.7973	.8505
Min	.362	.4207	.4525	.0143	.4435	.4525	.4075
Avg	.5732	.6072	.4909	.5556	.5392	.6307	.6357

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214405 / 33 KV OTUR

Feeder No / Name : 205 / 11 kV Rohakadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2606	.3155	.2096	.2286	.1905	.2	.3286
2	.2715	.3858	.2286	.2477	.1905	.2317	.3961
3	.2858	.443	.2667	.2667	.2286	.2675	.4725
4	.3311	.5268	.2858	.2858	.2667	.3715	.5506
5	.4012	.6019	.3048	.3239	.3239	.4458	.6299
6	.4475	.7209	.3429	.3429	.362	.5335	.6783
7	.78	.7545	.4763	.4191	.4001	.6249	.703
8	.8192	.8215	.6097	.5144	.4572	.7716	.788
9	.8848	.8453	.5716	.5144	.4763	.8642	.8322
10	.743	.4382	.888	.8802	.8768	.7049	.381
11	.5906	.4954	.8688	.8859	.9145	.5144	.4191
12	.5144	.4191	.8802	.8145	.9602	.3239	.4191
13	.4382	.4191	.9014	.751	.8573	.362	.4191
14	.4572	.4001	.8951	.8128	.8288	.4001	.4001
15	.4954	.4001	.8993	.823	.7093	.4382	.362
16	.5144	.4001	.823	.8333	.6068	.4382	.4191
17	.5525	.4572	.8078		.5373	.4382	.4763
18	.4763	.4191	.4763	.4382	.381	.362	.4572
19	.4191	.381	.4572	.4382	.381	.3239	.4572
20	.362	.3429	.4572	.4191	.3239	.3048	.4001
21	.2858	.3239	.381	.381	.2858	.2858	.3239
22	.2286	.3048	.3429	.3429	.2667	.2858	.2858
23	.1905	.2096	.2286	.2477	.2477	.2286	.2286
24	.2469	.2751	.1905	.1905	.2096	.1692	.2858
Max	.8848	.8453	.9014	.8859	.9602	.8642	.8322
Min	.1905	.2096	.1905	.1905	.1905	.1692	.2286
Avg	.4582	.4625	.5331	.4957	.4701	.4121	.4631

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214405 / 33 KV OTUR

Feeder No / Name : 207 / 11 KV SARANI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6796	.8122	.4572	.6097	.5525	.5121	.6401
2	.6796	.8951	.4572	.6478	.5716	.583	.7682
3	.7209	.9892	.5335	.6668	.6097	.6478	.9054
4	.7712	1.073	.5716	.724	.6668	.7545	1.0004
5	.8139	1.17	.6097	.8002	.7049	.8573	1.1145
6	.8478	1.2548	.6478	.8764	.7811	.9945	1.1789
7	1.3546	1.3032	.9526	1.0288	.9335	1.1145	1.2136
8	1.3717	1.3717	1.0669	1.086	1.0669	1.286	1.2689
9	1.4575	1.3757	.8421	1.1241	1.1241	1.3108	1.3077
10	1.3336	.8954	1.5402	1.4737	1.5074	1.2384	.8954
11	1.2003	.9526	1.5415		1.4918	1.105	.9335
12	1.1241	.8954	1.5249		1.4586	.9526	.9145
13	1.0479	.8764	1.4918		1.4089	.9145	.8954
14	1.1431	.8764	1.4251	1.2955	1.3599	.8764	.8764
15	1.1622	.9145	1.3603	1.3108	1.3279	.8573	.8383
16	1.2003	.9526	1.3765	1.2616	1.2955	.8764	.9526
17	1.2193	.9717	1.3927		1.2323	.8764	1.0288
18	1.0669	.9526	.8002	1.0479	1.1431	.7811	1.086
19	.9907	.9145	.8573	1.0098	1.1431	.724	1.1241
20	.9526	.8764	.8954	.9717	.9145	.7049	.9907
21	.9145	.7811	.7621	.9145	.7621	.6859	.8573
22	.7621	.6859	.724	.7811	.6668	.6668	.724
23	.724	.5906	.6287	.6097	.6097	.5716	.6097
24		.7209	.4763	.5525	.5335	.4801	.5992
Max	1.4575	1.3757	1.5415	1.4737	1.5074	1.3108	1.3077
Min	.6796	.5906	.4572	.5525	.5335	.4801	.5992
Avg	1.0234	.9626	.9557	.9396	.9944	.8488	.9468

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214405 / 33 KV OTUR

Feeder No / Name : 208 / Otur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9602	.9995	.4161	.4096	.5249	.6226	1.0978
2	.9878	1.0978	.4334	.4424	.5373	.6554	1.2125
3	1.004	1.2125	.4733	.4588	.5731	.7373	1.3272
4	1.1012	1.3108	.5493	.5243	.6516	.8029	1.4419
5	1.1768	1.4582	.5847	.5571	.7316	.9831	1.5565
6	1.2431	1.5402	.7577	.6062	.7947	1.2289	1.6712
7	1.5893	1.6057		.6554	.961	1.6057	1.7532
8	1.7695	1.704	.8316	.7373	1.0534	1.8023	1.8187
9	1.9498	1.7859	.9774	.8356	1.0317	1.8842	1.8679
10	1.4419	.8149	1.9826	1.6512	2.1956	1.3435	.8848
11	1.1797	.905	2.1464	1.8591	2.2611	1.065	.9012
12	1.0486	.9412	2.3102	2.0309	2.3266	.7865	.9012
13	.9175	.8775	2.2119	2.1125	2.3102	.639	.9012
14	.9831	.788	2.1628	2.0557	2.3102	.5571	.8848
15	1.0159	.8145	2.13	2.0005	2.2939	.4752	.8848
16	1.0322	.8507	2.1464	1.9204	2.13	.7701	.9339
17	1.0486	.9145	2.1628		2.0481	.852	.9831
18	.8192	.905	.8684	.905	.7865	.639	.8192
19	.7045	.8326	.8356	.8507	.8192	.5407	.7045
20	.639	.7011	.7701	.823	.6718	.4915	.6554
21	.5735	.631	.6554	.7059	.6226	.4588	.5898
22	.4915	.5083	.5735	.6516	.5571	.426	.4915
23	.4588	.3856	.4424	.5373	.4915	.4096	.4424
24	.9282	.8684	.3681	.3768	.5068	.5735	.9831
Max	1.9498	1.7859	2.3102	2.1125	2.3266	1.8842	1.8679
Min	.4588	.3856	.3681	.3768	.4915	.4096	.4424
Avg	1.0443	1.0189	1.1648	1.0308	1.2163	.8479	1.0712

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214406 / 33 KV ALE

Feeder No / Name : 203 / Rajuri

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8029	.7793	1.4742	1.6385	1.7604	.7958	1.0045
2	.811	.814	1.5011	1.5893	1.7604	.7612	1.0391
3	.9431	.8659	1.5318	1.6032	1.873	.7266	1.0391
4	1.0751	.9005	1.5644	1.668	1.8842	.7266	1.1257
5	1.1088	.9871	1.6892	1.749	1.917	.8486	1.2123
6	1.2323	1.195	1.8427	2.1628	2.0719	1.195	1.4028
7	1.7364	1.5569	2.7334	3.1017	3.2606	1.524	1.7472
8	1.643	1.4877	3.3169	3.4818	3.4476	1.4704	1.5742
9	1.307	1.332	3.1019	3.3753	3.6117	1.417	1.6244
10	3.2207	3.2708	1.2254	1.2197	1.0702	3.1901	2.9007
11	2.3589	3.2555	1.2382	1.1088			3.1786
12	3.2247	2.979		1.3169	1.0357	3.0251	2.9492
13	3.0712	3.1134	1.2382	1.3306	1.1738	3.0712	3.0639
14	2.9483	3.0367		1.3306	1.1035		3.2114
15	3.1211	3.0558		1.3491	1.1392	3.0712	2.8018
16	3.2441	3.0712	1.1157	1.3676	1.1392	3.1633	
17	3.1287	2.8987	1.4998	1.0425	1.191	2.8066	3.1255
18	1.122	.9989	1.5939	1.3443	1.3276	1.1725	
19	1.2787	1.2946	1.647	1.6078	1.4343	1.5362	1.46
20	1.2442	1.417	1.6461	1.5154	1.4704	1.4877	1.4937
21	1.1232	1.3479	1.5339	1.4003	1.3997		1.4377
22	1.0195	1.2096	1.3121	1.2567	1.2096	1.1763	1.307
23	.8467	1.0184	1.1827	1.0534	.9342	1.038	1.0456
24	.8029	.7266	1.4705	1.6549	1.8187	.8304	.9352
Max	3.2441	3.2708	3.3169	3.4818	3.6117	3.1901	3.2114
Min	.8029	.7266	1.1157	1.0425	.9342	.7266	.9352
Avg	1.7673	1.7755	1.6885	1.6778	1.6971	1.6683	1.8491

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214406 / 33 KV ALE

Feeder No / Name : 204 / Ale

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1949	.1892	.2944	.3547	.4481	.2067	.2411
2	.1949	.1724	.2598	.3174	.4294	.2067	.2583
3	.2103	.1724	.2598	.3174	.4294	.2239	.2583
4	.2229	.2071	.0321	.3734	.4481	.2411	.2928
5	.2515	.2244	.329	.3921	.4854	.2414	.2928
6	.2713	.2589	.3979	.4904	.4854	.2586	.31
7	.431	.4822	.5715	.6722	.6161	.3961	.465
8	.4359	.4463	.5363	.5975	.5544	.3948	.4296
9	.463	.412	.4666	.4805	.4938	.3695	.4115
10	.4315	.4838	.3978	.3812	.3378	.4143	.462
11	.3961	.4147	.3978	.3978	.3536		.4525
12	.0421	.397	.3812	.3768	.3071	.4138	.462
13	.4143	.4147	.3681	.3768	.3225	.397	.439
14	.4143	.4143	.3479	.3812	.3067		.439
15	.4147	.397	.3479	.39	.3378	.3793	.439
16	.4147	.397	.3441	.3768	.3374	.397	.4755
17	.4315	.397	.3441	.3258	.3839	.4311	.4572
18	.4655	.3957	.333	.499	.3617	.3781	
19	.5702	.5	.543	.6584	.4828	.4828	.5914
20	.6048	.5357	.6036	.5975	.5184	.5702	.6468
21	.5167	.5184	.5729	.5601	.5011		.5914
22	.4838	.4838	.5228	.5544	.4493	.4838	.5359
23	.4147	.3974	.4481	.4805	.3802	.4152	.462
24	.1907	.206	.3287	.3734	.4481	.2583	.2411
Max	.6048	.5357	.6036	.6722	.6161	.5702	.6468
Min	.0421	.1724	.0321	.3174	.3067	.2067	.2411
Avg	.3701	.3716	.3929	.4469	.4258	.3600	.4197

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214406 / 33 KV ALE

Feeder No / Name : 205 / Wadgaon Kandali

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3511	.3114	.412	.3906	.4915	.2589	.346
2	.3511	.3287	.4578	.3437	.4801	.2244	.3806
3	.3475	.3633	.4595	.3795	.4801	.2246	.3806
4	.3696	.3633	.4908	.427	.4801	.2595	.4152
5	.3734	.3806	.5215	.4902	.4915	.3287	.4325
6	.5041	.4152	.5514	.5571	.5138	.3979	.4844
7	.583	.5709	.8139	.9012	.9496	.4838	.5017
8	.5548	.553	.9367	1.0688	1.0486	.4661	.5363
9	.4572	.4493	.7649	.9762	1.0631	.3802	.4938
10	.8393	.8567	.4755	.4755	.3793	.8251	.8802
11	.9779	.9344	.4755	.4572	.432		.8855
12	.8884	.9969	.4938	.462	.4143	.7965	.7362
13	.8414	.9932	.5487	.4572	.4666	.9179	.8802
14	.8567	.872	.4938	.4668	.3966		.8855
15	.8731	.8578	.3479	.4294	.4311	.7649	.8223
16	.8731	.8272	.4755	.4755	.4315	.8261	.8855
17	.8851	.8292	.5014	.439	.4828	.8393	.8436
18	.4984	.4473	.5316	.5304	.4483	.464	
19	.5345	.5333	.5068	.567	.4661	.5511	.4706
20	.4828	.5351	.4887	.5304	.5006	.4666	.4755
21	.4666	.4838	.5729	.4938	.4488		.4435
22	.432	.3974	.4066	.4854	.4143	.4147	.4066
23	.3283	.3456	.3921	.4251	.3452	.3629	.3511
24	.3511	.2938	.412	.427	.4687	.2762	.3287
Max	.9779	.9969	.9367	1.0688	1.0631	.9179	.8855
Min	.3283	.2938	.3479	.3437	.3452	.2244	.3287
Avg	.5842	.5808	.5221	.5273	.5219	.5014	.5768

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214406 / 33 KV ALE

Feeder No / Name : 206 / Alephata

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.567	.6035	.5856	.6219	.6613	.6545	.6904
2	.5548	.5869	.5517	.5853	.6133	.6207	.6904
3	.5487	.6041	.5517	.543	.5801	.5862	.7077
4	.5967	.6041	.5862	.5973	.5935	.5869	.7077
5	.6036	.6559	.6207	.6154	.6241	.6214	.725
6	.663	.6559	.6732	.7133	.691	.6904	.7768
7	.9015	.8631	.9148	.9955	.9465	.9483	1.0345
8	1.0985	1.0334	1.0678	1.0631	1.0576	1.0666	1.085
9	1.0576	.929	.9956	1.0288	1.1744	1.0322	1.1269
10		1.046	1.0174	1.2039	1.1699	1.0455	1.1145
11	1.1531	1.0814	1.0513	1.2226	1.1056		1.1904
12	1.1252	1.0986	1.153	1.1443	1.1699	1.1145	1.2003
13	1.0288	1.0018	1.1022	1.134	1.0301	1.0631	1.1022
14	.9945	.9088	1.0059	1.0749	.9521		1.0174
15	1.1673	1.046	1.0682	1.0517	.9686	.971	1.0682
16	1.2703	1.046	1.1443	.9774	1.0609	1.0631	1.1488
17	1.0776	1.0631	1.1361	1.2986	1.0609	1.0762	1.2039
18	1.0789	1.0609	1.1142	1.2094	1.0596	1.167	
19	1.3075	1.3218	1.2309	1.2934	1.3404	1.3061	1.3073
20	1.1884	1.1871	1.2795	1.2136	1.2401	1.1539	1.2308
21	1.0334	1.0311	1.0631	1.0682	1.0322		1.1283
22	.93	.9108	.9492	.9282	.929	.9645	1.0208
23	.775	.7914	.8238	.7716	.7923	.7931	.8326
24	.6201	.6193	.6373	.6584	.703	.6889	.6732
Max	1.3075	1.3218	1.2795	1.2986	1.3404	1.3061	1.3073
Min	.5487	.5869	.5517	.543	.5801	.5862	.6732
Avg	.9279	.9063	.9302	.9589	.9399	.9150	.9906

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214406 / 33 KV ALE

Feeder No / Name : 207 / KALAMJAI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.073	.9852	.8294	.9522	1.0562	.9816	1.107
2	1.0978	.9864	.7776	.9335	1.0562	1.0122	1.1546
3	1.1869	1.0018	.0784	.9709	1.0164	1.0442	1.2022
4	1.286	1.0481	.7785	1.0269	1.0456	1.0749	1.2639
5	1.387	1.156	.9515	1.0456	1.1203	1.1714	1.3563
6	1.3763	1.3563	1.1936	1.363	1.2071	1.3718	1.5875
7	2.1874	2.2291	1.4012	1.7177	1.5524	2.1434	2.3663
8	2.2298	2.1578	1.4358			1.9575	1.9729
9	2.1795	2.0654				1.9065	2.0388
10	1.1751	1.3997	2.2377	2.5029	2.1038	1.2442	
11	1.1923	1.2615	2.2969	2.5484	2.2909		
12	1.2801	1.3133	2.1714	2.4478		1.1578	1.307
13	1.2787	1.1405	2.0317	2.3807	1.9938	1.1751	1.3491
14	1.2787	1.1578	1.9989	2.3739	2.0526		1.386
15	1.417	1.2096	2.1538	2.323	2.022	1.2269	1.3491
16	1.5207	1.3651	2.1464	2.2377	2.1652	1.2442	1.1523
17	1.3291	1.3997	2.1548	1.4419	1.6897	1.3464	1.4969
18	1.4327	1.5173	1.3432	1.4969	1.3449	1.5001	
19	1.5362	1.5173	1.4118	1.5154	1.4499	1.3794	1.4784
20	1.2787	1.4327	1.3937	1.4632	1.2946	1.2615	1.4415
21	1.2083	1.3464	1.5729	1.3306	1.3464		1.3121
22	1.1047	1.1738	1.2936	1.2883	1.2428	1.122	1.2197
23	.9677	.9494	1.1088	1.0608	1.0702	1.0022	1.0829
24	1.0608	.9994	.8467	1.0269	1.0829	.9816	1.2936
Max	2.2298	2.2291	2.2969	2.5484	2.2909	2.1434	2.3663
Min	.9677	.9494	.0784	.9335	1.0164	.9816	1.0829
Avg	1.3777	1.3404	1.4612	1.6113	1.4859	1.3002	1.4247

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214429 / 33 KV BELHE

Feeder No / Name : 201 / Belhe

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.474	.4924	1.4853	1.7471	1.7307	.2042	.5458
2	.2576	.4962	1.4136	1.776	1.6606	.2187	.5418
3	.4892	.5068	.7689	1.7989	1.6434	.221	.5611
4	.2705	.5361	.7659	1.8923	1.6756	.2248	.6592
5	.614	.6101	.7865	2.0488	1.5493	.2439	.6843
6	.3376	.7918	.9175	2.2771	1.7234	.3323	.7026
7	.7697	.8078	1.3839	3.1489	2.8029	.3833	.8594
8	.3307	.7022	1.8153	3.6233	3.4312	.3628	.7438
9	.5862	.498	1.8298	3.5056	2.8053	.2904	.5793
10	4.252	4.0916	.2401	.4194	.4077	3.8203	2.2055
11	4.9288	4.1797	.1669	.1966	.386	3.8878	4.5698
12	4.633	4.2379	.1638	.3201	.301	4.1556	4.5176
13	2.4646	4.025	.3102	.3117	.3186	4.001	4.3991
14	4.3576	3.8446	.3298	.3395	.3367	3.9658	4.1232
15	2.3221	3.629	.4145	.3544	.3375	3.7452	4.0211
16	4.2166	3.4793	.4996	.42	.3573	3.9299	4.1267
17	2.2634	3.2659	.4967	.4988	.4927	3.9223	4.3043
18	.3978	.5258	.486	.501	.1928	.5742	.4456
19	.5418	.5571	.6609	.6218	.2309	.7145	.539
20	.7148	.6565	.7236	.8997	.3102	.8797	.7651
21	.6454	.6391	.6779	.8257	.2888	.7895	.6609
22	.3277	.6376	.615	.788	.2934	.7034	.6037
23	.5563	.5853	.5301	.7697	.2606	.5786	.555
24	.4953	.9712	1.6224	1.7432	1.02	.4405	.5395
Max	4.9288	4.2379	1.8298	3.6233	3.4312	4.1556	4.5698
Min	.2576	.4924	.1638	.1966	.1928	.2042	.4456
Avg	1.5519	1.6986	.7960	1.2845	1.0232	1.6079	1.7606

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214429 / 33 KV BELHE

Feeder No / Name : 202 / Gunjalwadi
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.6083	4.3842	1.145	1.1308	1.0143	2.1277	4.2612
2	2.4249	4.3492	1.1282	1.1292	1.0456	2.1521	4.2338
3	4.6205	4.446	1.1175	1.1308	1.0859	2.1521	4.3705
4	2.4966	4.5038	1.218	1.198	1.1447	2.2055	4.7777
5	4.9859	4.5443	1.3447	1.342	1.0291	2.2817	4.7249
6	2.6779	4.7588	1.637	1.6316	1.1759	2.556	5.3646
7	6.912	6.4301	1.8564	1.0349	1.7574	3.219	7.2276
8	4.4947	7.9447	1.7955	1.8903	1.8873	4.3987	8.9655
9	8.5475	7.822	1.6355	1.7368	1.4293	4.5252	9.0525
10	3.4307	3.5658	3.9537	7.351	7.7557	3.26	3.0011
11	1.0793	1.0737	8.5723	4.2981	8.392	1.0875	1.0415
12	.9892	1.0565	7.0504	8.0628	8.599	1.008	.9766
13	.4999	1.0345	8.7251	7.6946	8.1036	1.012	.9481
14	.8299	1.0692	8.1969	7.3741	7.6963	.9957	2.4741
15	.4039	1.1328	7.9779	7.3545	7.3015	.9965	.9955
16	.967	1.226	7.8914	7.4766	7.6353	1.0445	1.1258
17	.5517	1.1989	7.9215	4.7904	7.5952	1.2168	1.2087
18	1.0959	1.2866	3.245	1.3317	2.7907	1.4221	1.4123
19	1.4663	1.6017	1.5722	1.3272	.6584	1.5941	1.627
20	1.9449	1.7592	.8962	1.438	.8886	1.9292	1.5625
21	1.7055	1.695	1.6782	1.4106	.8825	1.6812	1.4437
22	1.5615	1.5867	1.5148	1.3078	.8459	1.5423	1.4055
23	1.4465	1.4512	1.4058	1.2372	.7651	1.4822	1.3276
24	2.3152	2.6094	1.2136	1.1338	2.5293	4.2124	4.2673
Max	8.5475	7.9447	8.7251	8.0628	8.599	4.5252	9.0525
Min	.4039	1.0345	.8962	1.0349	.6584	.9957	.9481
Avg	2.5857	3.0221	3.5289	3.1589	3.5004	2.0876	3.2415

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214429 / 33 KV BELHE

Feeder No / Name : 203 / Ane

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.428	1.3268	1.5704	1.5676	1.5189	.6523	1.3095
2	.7316	1.3401	1.5842	1.5722	1.48	.6539	1.2985
3	1.4478	1.3714	1.6146	1.6362	1.5531	.6584	1.3232
4	.7819	1.4487	1.7221	1.8099	1.6156	.6874	1.4541
5	1.7666	1.6072	1.8957	1.9323	1.7078	.7407	1.6766
6	.9892	2.0324	2.3807	2.2965	1.9559	.9145	2.0153
7	2.3863	2.3545	3.0689	3.1684	3.0702	1.102	2.2702
8	2.1422	2.2375	3.7159	3.7601	3.3382	1.0258	1.928
9	1.8248	1.6997	3.501	3.4088	3.0044	.788	1.3616
10	4.0722	3.8397	.6081	1.0038	.9537	3.6714	2.1414
11	4.2189	4.0036	.8223	.4313	.6959	4.2802	3.9328
12	3.931	3.658	.6213	.6725	.5644	2.3426	3.8858
13	2.0546	3.1051	.5119	.5647	.4946	3.6984	3.5677
14	3.3574	3.0121	.4885	.5125	.5165	3.5559	3.3623
15	1.765	3.4453	.515	.4916	.518	3.6721	3.2998
16	3.5285	3.866	.5165	.4645	.5384	4.0966	3.6413
17	1.954	3.7967	.6066	.5098	.5954	4.2094	3.7849
18	.6249	.8743	.7059	.7392	.3307	.3734	.7704
19	1.6393	1.6215	1.3396	1.3253	.5045	1.4796	1.3161
20	1.9098	2.0926	1.7259	1.8412	.9328	1.8942	1.7995
21	1.8934	1.9782	1.7979	1.778	.8703	1.7322	1.6941
22	1.7261	1.7925	1.6202	1.6133	.788	1.5638	1.5693
23	.7956	1.5093	1.4661	1.4407	.7362	1.4182	1.3948
24	1.4112	1.4449	1.5842	.852	.9413	1.2839	1.3385
Max	4.2189	4.0036	3.7159	3.7601	3.3382	4.2802	3.9328
Min	.6249	.8743	.4885	.4313	.3307	.3734	.7704
Avg	2.0158	2.3108	1.4993	1.4747	1.2177	1.9373	2.1723

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214429 / 33 KV BELHE

Feeder No / Name : 204 / MALGANGA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8229	.7804	2.267	2.6684	2.3956	.442	.8284
2	.4252	.8231	2.2555	2.6234	2.358	.439	.8402
3	.8274	.8718	2.2319	2.5869	2.3236	.4382	.8951
4	.4428	.9572	2.4318	2.6357	2.34	.4123	1.0078
5	1.0645	1.0532	2.4928	2.758	2.2316	.4519	1.0845
6	.6135	1.2361	2.7502	2.9923	2.4432	.5578	1.2289
7	1.4998	1.5466	3.7669	4.6155	3.8431	.7362	1.5029
8	.8284	1.4731	4.8305	5.6253	4.844	.7667	1.3767
9	1.3121	1.2269	4.7047	5.3517	5.2869	.5304	1.1728
10	4.47	4.4684	1.339	1.6433	1.8949	3.9358	2.7275
11	5.0541	4.7908	.7108	.3765	.8463	2.6292	5.4436
12	4.6963	4.5813	.6144	.6439	.7602	2.6635	4.2143
13	2.1658	4.2898	.588	.6165	.7053	4.6826	4.156
14	3.8965	3.9582	.5424	.6104	.6327	4.4121	4.2757
15	3.8893	3.8401	.5771	.6676	.6338	4.1038	4.0631
16	4.0744	3.9841	.3323	.5788	.6689	4.5857	4.4071
17	2.2946	3.9788	.7061	.3384	.6193	4.9547	4.5008
18	.9632	1.3563	.3696	.5426	.3559	1.548	1.3814
19	.964	1.0372	1.009	.7937	.4694	.9895	.9362
20	1.2559	1.3702	1.2501	1.209	.6318	1.2587	1.2239
21	1.1789	1.3211	1.2681	1.2014	.6501	1.1968	1.1468
22	.5883	1.2242	1.1788	1.1165	.6234	1.1075	1.0052
23	.5319	1.087	1.046	.5327	.5373	1.037	.8701
24	.8206	1.5196	2.4117	2.5457	1.5417	2.4958	.8326
Max	5.0541	4.7908	4.8305	5.6253	5.2869	4.9547	5.4436
Min	.4252	.7804	.3323	.3384	.3559	.4123	.8284
Avg	1.8617	2.1990	1.7364	1.8864	1.6515	1.9323	2.1301

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214429 / 33 KV BELHE

Feeder No / Name : 205 / PATILMALA CANOL
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.379	1.1469	.2263	.2452	.2241		1.4575
2		1.1469	.2263	.2452	.2241		1.4575
3	1.379	1.2125	.2263	.2452	.2427		1.8004
4		1.4582	.2829	.3018	.2987		1.8861
5	1.5581	1.8023	.3206	.3772			2.0748
6			.415	.4715	.3361		2.452
7	2.0058	2.2939	.4527	.5281	.3734		2.7349
8		2.3758	.4527	.4338	.4108		2.4006
9	2.2207	2.13	.415	.3206	.3361		2.3148
10	.2263	.2452		2.561	2.4291	.2263	
11	.1698	.1509	2.1849		2.1628		
12	.168	.3018	2.4356	2.2939	2.2939		
13		.1132	2.2386	2.2348	2.2939		
14	.168	.0943	2.6684	2.17	2.0153	.1829	.1886
15	.1867	.1698	2.6326	2.2283	2.2939	.2743	.1886
16	.1867	.1886	2.7042		2.2939	.2572	.2263
17		.1829	2.5072	.6554	2.0317	.2829	.2641
18	.2987	.2263	.2263	.2218		.3395	
19	.3361	.3772	.3772	.2772		.415	.3772
20	.4108	.4527	.3584	.4066		.5093	.4527
21	.3361	.3961	.3772	.3361		.4715	.415
22		.3395	.3018			.3772	.2829
23		.3584	.2641			.2829	.2641
24	1.379	1.1797	.2641	.2452	.2241	1.3203	1.4575
Max	2.2207	2.3758	2.7042	2.561	2.4291	1.3203	2.7349
Min	.168	.0943	.2263	.2218	.2241	.1829	.1886
Avg	.7756	.7975	.9808	.8399	1.2050	.4116	1.1945

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214429 / 33 KV BELHE

Feeder No / Name : 206 / BELHE GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3139	1.1306	1.2481	1.3224	1.3123	.4184	1.0121
2	.3829	1.1474	1.2569	1.3151	1.3478	.4226	1.0064
3	1.288	1.2021	1.2649	1.3132	1.414	.4233	1.1561
4	.4252	1.3481	1.4087	1.4079	1.5245	.4313	1.2737
5	1.5645	1.576	1.5693	1.5809	1.6205	.5075	1.6408
6	.6394	1.9113	1.9349	1.9267	1.8248	.6634	2.0222
7	2.1598	2.239	2.2363	2.0016	2.1898	.719	2.1458
8	.7324	1.9204	2.0108	2.0169	2.1479	.6992	2.0172
9	1.7187	.607	1.7715	1.5428	1.56	.5788	1.7307
10	1.3049	.5403	.4698	1.5756	1.5177	1.6762	.5495
11	1.4762	1.5112		1.456	1.5519	.4999	1.4975
12	1.4544	1.2605		1.342	1.5477	.4927	1.4586
13	.4858	1.2887	1.9315	1.2882	1.5439	1.3514	1.3264
14	1.3436	1.1999	1.7162	1.2537	1.4217	1.1794	1.2292
15	1.2955	1.1812	1.5333	1.2486	1.4007	1.2236	1.2593
16	.4374	1.142	1.4743	1.2494	1.371	1.2361	1.4484
17	.4336	1.2471	1.4209	1.2707	1.3462	1.2668	1.2754
18	1.1736	1.2544	1.4503	1.2373	.4409	1.5467	1.7311
19	1.9574	1.7565	1.9959	1.7114	.6516	1.9608	1.9059
20	2.0115	2.0307	2.065	2.1302	.7346	2.1332	2.2679
21	1.8469	1.8564	1.9381	1.8088	.6916	1.8027	2.005
22	.5758	1.6892	1.7128	.5872	.5986	1.5847	1.6608
23	.4957	1.4	1.4868	.5007	.5064	1.1872	1.416
24	1.2994	1.2392	1.274	1.3887	1.3197	1.4217	1.0346
Max	2.1598	2.239	2.2363	2.1302	2.1898	2.1332	2.2679
Min	.3829	.5403	.4698	.5007	.4409	.4184	.5495
Avg	1.1590	1.4033	1.5987	1.4365	1.3161	1.0594	1.5029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214429 / 33 KV BELHE

Feeder No / Name : 207 / GUNJALWADI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1538	1.0676	1.0155	1.0755	1.1092	.378	.9392
2	.3384	1.0707	1.017	1.0736	1.0562	.3628	.943
3	1.1226	1.0623	1.0132	1.0751	1.0852	.3654	1.1732
4	.3593	1.3084	1.1329	1.2249	1.1652	.3856	1.4224
5	1.4676	.442	1.3425	1.4161	1.3463	.4691	1.7179
6	.6569	1.9269	1.8892	1.9896	2.0142	.6889	2.0283
7	2.3846	2.356	2.3266	1.758	.7998	.8021	2.2328
8	.7827	1.9212	2.2626	1.9879	2.2542	.8048	2.0254
9	1.8415	.6047	1.9155	1.6659	1.6134	.6169	1.7696
10	1.6598	.5186	.5255	1.4209	1.5867	1.5607	.5525
11	1.464	1.4754	1.2997	1.3576	1.5344	.4428	1.3999
12	1.35	1.363	1.3127	1.2662	1.4575	1.2171	1.3733
13	.3982	1.1675	1.2219	1.1805	1.3428	1.2215	1.3043
14	1.1317	1.1142	.9019	1.1233	1.2551	1.1119	1.3469
15	.4203	1.1424	1.0196	1.147	1.1713	1.1401	1.3322
16	1.1755	1.2125	1.1165	1.2448	1.1264	1.2889	1.2567
17	.4317	1.2334	1.2997	1.1751	1.2864	1.359	1.3172
18	1.3752	1.3556	1.1591	1.1976	.4874	1.5551	1.3802
19	1.97	1.892	1.7863	1.7152	.5788	1.8822	1.924
20	1.9235	1.9917	1.8705	2.0309	.5742	2.0728	2.1502
21	1.6903	1.744	1.7642	1.853	.6885	1.8905	1.9928
22	.5453	1.4747	1.5493	.5742	.5704	1.4356	1.6506
23	.4649	1.1896	1.3409	.4835	.4797	1.2415	1.4053
24	1.1755	1.1108	1.0505	1.1406	1.1988	1.3199	.9644
Max	2.3846	2.356	2.3266	2.0309	2.2542	2.0728	2.2328
Min	.3384	.442	.5255	.4835	.4797	.3628	.5525
Avg	1.1368	1.3227	1.3806	1.3407	1.1576	1.0672	1.4834

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214429 / 33 KV BELHE

Feeder No / Name : 208 / ANE GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7497	.7373	.7918	.8398	.8459	.277	.7983
2	.2362	.7324	.7918	.8379	.8114	.2793	.7903
3	.7433	.757	.7956	.8436	.8799	.2793	.9096
4	.2625	.8612	.8867	.9601	1.0628	.2835	1.1765
5	1.1722	1.1359	1.1481	1.2643	1.265	.362	1.3889
6	.522	1.6587	1.8858	1.8235	1.5516	.5693	1.7713
7	2.29	2.0211	1.9148	1.8388	2.0976	.7068	2.0865
8	.7	1.7216	1.8717	1.3035	.5502	.6542	1.8244
9	1.4815	.5902	1.6434	1.4361	1.5379	.4866	1.5181
10	1.2658	.4271	.4302	1.116	1.233	1.2365	.3829
11	.9465	.8802	.9861	.3475	.974	.8733	.8863
12	.8448	.78	.9054	.8215	.9678	.2656	.8352
13	.2743	.6291	.7945	.6748	.7758	.7598	.7762
14	.6169	.5403	.6774	.5502	.7297	.6626	.5711
15	.2416	.5674	.7163	.6516	.6852	.7979	.7692
16	.7548	.6596	.8238	.6806	.7601	.9006	.7411
17	.2763	.7788	.7925	.7632	.8021	1.0281	.7956
18	.9377	.8276	.8999	.8177	.3037	1.3409	.9432
19	1.1717	1.3899	1.3054	1.1759	.3403	1.5718	1.2593
20	1.4809	1.5782	1.4773	1.6324	.5643	1.9025	1.6368
21	1.4282	1.5226	1.491	1.5177	.5453	1.6652	1.5412
22	.474	1.2616	1.1917	.4988	.4927	1.3832	1.3434
23	.3685	.9789	1.0652	.3951	.3803	.9785	1.0719
24	.7836	.8139	.8287	.8855	.8952	.837	.8478
Max	2.29	2.0211	1.9148	1.8388	2.0976	1.9025	2.0865
Min	.2362	.4271	.4302	.3475	.3037	.2656	.3829
Avg	.8343	.9938	1.0881	.9865	.8772	.8376	1.1110

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214460 / 33 KV KOLWADI

Feeder No / Name : 201 / Madh

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7162	.7154	1.0128	1.0513	1.0773	.7494	1.0059
2	.6851	.6859	1.1022	1.1071	1.1145	.7202	1.0779
3	.7759	.7298	1.1936	1.2689	1.1257	.7234	1.1141
4	.8322	.8045	1.3717	1.3931	1.1578	.8285	1.1869
5	.8726	.9486	1.4818	1.4963	1.4915	.9035	1.2632
6	1.1869	1.1043	1.9469	1.8744	1.8348	1.2203	1.286
7	1.3687	1.2717	1.9914	2.1125	2.5106	1.246	1.4636
8	1.4024	1.326	2.0919	2.4299	2.5305	1.3214	1.3457
9	1.2319	1.2366	2.1655	2.1581	2.1333	1.1416	1.2856
10	2.6489	1.4837	1.6194	.4968	1.1589	1.6575	3.0139
11	2.6891	2.4302	1.093	.4463	1.1431	3.1369	2.713
12	2.7435	2.4923	.9984	.6171	1.1648	2.967	
13	2.809	2.5692	.9959	.7886	.9511	2.809	2.5378
14	2.8229	2.6907	1.0084	.8688	1.0754	2.4078	2.9052
15	2.7404	2.6006	1.1029	.9217	1.2102	2.2138	3.1796
16	2.6779	2.3216	1.1029	.9145	1.2037	2.4078	
17	2.4918	2.2407		.7819	1.2037	2.5831	2.8858
18	1.1933	1.648	1.1136	1.284	1.2986	1.9662	2.8246
19	1.3108	1.2558	1.5964	1.4864	1.3108	1.5348	1.2222
20	1.2958	1.2281	1.417	1.3123	1.2929	1.4661	1.4838
21	1.2534	1.0898	1.3748	1.2617	1.291	1.3592	1.1616
22	.9432	1.0082	1.0082	1.0227	1.0082	1.1944	1.0181
23	.7907	.8444	.8926	.9012	.8421	.9211	.9768
24	.763	.7452	.9116	1.0162	1.0643	.813	.9702
Max	2.8229	2.6907	2.1655	2.4299	2.5305	3.1369	3.1796
Min	.6851	.6859	.8926	.4463	.8421	.7202	.9702
Avg	1.5936	1.4780	1.3301	1.2088	1.3415	1.5955	1.7237

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214460 / 33 KV KOLWADI

Feeder No / Name : 202 / Ballalwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0002	1.0791	1.102	.9288	1.007	.905	1.2567
2	1.0848	1.1641	1.0122	.9335	1.0112	.9012	1.3237
3	1.0861	1.2483	.924	1.029	1.2037	.9871	1.3871
4	1.1683	1.3317	1.0227	1.0311	.924	.7103	1.3999
5	1.1709	1.4175	1.1225	1.126	1.0269	1.0562	1.4098
6	1.6766	1.5878	1.226	1.1283	1.1271	1.0517	1.4656
7	2.0485	2.053	1.4967	1.6804	1.6872	1.8442	1.8645
8	2.3419	2.2402	1.8385	2.0412	1.9564	2.0719	2.0076
9	2.0405	1.861	1.9826	2.099	1.9184	1.9766	1.8774
10	1.9204	1.6271	2.0576	2.2805	2.2832	1.8861	
11	2.0433	1.3975	2.2885	2.3288	2.1914	2.1253	1.8499
12	1.8861	1.8304	2.3758	2.1898	2.1052	2.0349	
13	1.7984	1.8519	2.2245	2.1219	1.8061	1.9444	
14	1.7109	1.6701	2.0111	2.0235	1.9338	1.9204	1.6307
15	1.7128	1.6718	2.1152	1.929	1.877	1.8118	1.6255
16	2.0496	1.6375	1.9913	2.0334	1.877	1.9951	1.8499
17	2.1362	1.6851	1.8861	1.2193	1.877	2.088	1.8347
18	1.6064	1.7104	1.7947	1.9564	1.9993	1.993	1.8004
19	1.8576	1.6358	1.8176	1.8519	1.829	1.9004	1.8499
20	1.6667	1.6735	1.454	1.6461	1.4693	1.7285	1.7538
21	1.4784	1.4784	1.3603	1.5676	1.2883	1.6461	1.5806
22	1.2856	1.3817	1.0974	1.2803	1.1031	1.4708	1.4708
23	1.0112	1.283	1.0091	1.0951	1.0101	1.295	1.386
24	1.065	1.086	1.1888	.9278	1.877	.9069	1.7538
Max	2.3419	2.2402	2.3758	2.3288	2.2832	2.1253	2.0076
Min	1.0002	1.0791	.924	.9278	.924	.7103	1.2567
Avg	1.6186	1.5668	1.6000	1.6020	1.5995	1.5938	1.6371

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214460 / 33 KV KOLWADI

Feeder No / Name : 203 / Pimplegaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3334	.3597	.3673	.4644	.5493	.362	.3696
2	.2503	.3582	.4601	.4668	.5516	.3605	.4596
3	.3342	.3923	.5544	.5613	.6481	***	.4563
4	.4172	.4439	.6508	.5624	.6468	.4439	.5384
5	.5018	.443	.6548	.6568	.7468	.4401	.6168
6	.5868	.5293	.7545	.7522	.8453	.5281	.6035
7	.6828	.6843	1.1225	1.1203	1.406	.503	.6485
8	.7527	.7467	1.195	1.299	1.677	.4144	.6424
9	.583	.6203	1.1715	1.1864	1.279	.3953	.5777
10	1.4632	1.2846	.7716	.5701	.6523	1.2003	
11	1.6718	1.3043	.6539	.5621	.5681	1.4784	1.3875
12	1.5432	1.2203	.6554	.391	.5668	1.5725	
13	1.4559	1.2963	.6356	.3144	.4515	1.2963	1.2803
14	1.5398	1.2062	.6188	.3891	.4641	1.1888	1.5401
15	1.3702	1.3003	.5695	.3858	.5475	1.0871	1.4449
16	1.3975	1.2736	.4978		.5468	1.1789	1.11
17	1.3003	1.2416	.4715		.6257	1.271	1.743
18	.612	1.1703	.6281		.727	.6341	.9002
19	.5573	1.0905	.727	.3704	.6401	.543	.8325
20	.463	.6508	.727	.3658	.6428	.5458	.6461
21	.462	.5544	.5441	.3688	.5521	.4572	.5578
22	.4592	.4606	.4572	.3658	.4596	.3677	.4596
23	.3666	.3666	.3669	.365	.3673	.37	.462
24	.3277	.362	.2743	.3711	.6257	.3628	.3704
Max	1.6718	1.3043	1.195	1.299	1.677	16.9061	1.743
Min	.2503	.3582	.2743	.3144	.3673	.3605	.3696
Avg	.8097	.8067	.6471	.5661	.6995	1.4128	.8021

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214460 / 33 KV KOLWADI

Feeder No / Name : 204 / Aalme SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6335	.7194	.6244	.5944	.5493	.6154	.7392
2	.6676	.7522	.6626	.6348	.5516	.6128	.7722
3	.7018	.8025	.7392	.6735	.5926	.682	.8031
4	.7177	.8878	.8368	.7499	.5914	.7103	.8256
5	.736	.9214	.9355	.8445	.7468	.7394	.8107
6	.9221	.988	.9808	1.1659	.958	.8238	.8276
7	1.1096	1.2318	.9916	1.1203	1.0686	.9054	1.0052
8	1.1709	1.3275	.8273	.9464	1.0062	1.1271	1.2688
9	.9036	1.0235	.6669	.7301	.7856	.9172	.9098
10	.6584	.7879	.9431	.9774	.9785	.7545	
11	.6501	.5776	1.1933	1.0279	.9739	.5914	.555
12		.5927	1.0486	.7977	.9069	.592	
13		.6667	.8739	.6916	.602	.5926	.567
14		.5567	.758	.6538	.7735	.5853	.4892
15		.5015	.8949	.6481	.8134	.5798	.4515
16	.708	.5822	.9625	.6726	.6257	.6167	.6475
17	.8359	.6385	.7545	.6249	.7508	.6355	.6605
18		.7202	.7179	.7826	.7997	.761	.7562
19	1.0217	.8179	.7997	.8519	.7682	.9412	.9065
20	1.037	.8554	.8724	.8779	.8265	.9279	1.0154
21	.924	.7762	.8525	.9221	.8466	.9145	.7438
22	.7346	.6817	.6219	.7865	.7722	.9009	.6803
23	.6781	.6232	.5871	.5841	.6428	.703	.6283
24	.6226	.6878	.5853	.5938	.5533	.6167	.7407
Max	1.1709	1.3275	1.1933	1.1659	1.0686	1.1271	1.2688
Min	.6226	.5015	.5853	.5841	.5493	.5798	.4515
Avg	.8123	.7800	.8221	.7897	.7702	.7436	.7638

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214519 / 33 KV PIMPRI PENDHAR

Feeder No / Name : 201 / KHAMUNDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.2591	.5144	.4725	.4572	.4572	.4115
2	.381	.2896	.5144	.4268	.4268	.4572	.4287
3	.3506	.3048	.5487	.4572	.3658	.4877	.4458
4	.3963	.381	.583	.503	.4268	.5335	.4801
5	.442	.463	.6173	.5487	.5182	.5792	.5316
6	.5335	.5487	.6859	.6401	.6401	.6097	.6173
7	.6554	.6516	1.0288	.9602	1.0669	.6554	.7202
8	.6097	.5792	1.286	1.1126	1.2041	.5335	.703
9	.4877	.503	1.1488	1.0517	1.1431		
10	.6859	.9945	.4115	.5182	.4115	1.2174	
11	.823	1.0117	.3963	.2286	.3963		1.0517
12	.8993	.9774	.4115	.2743	.4115	1.166	1.0059
13	.8993	.9431	.4268	.2286	.3506	1.0974	.884
14	.823	.8745	.4115	.3658	.3658	1.1488	.884
15	.8078	.9774	.442	.4725	.4572	1.1831	.9145
16	.8383	1.0288	.4725	.5639	.5182	1.2689	1.0669
17	.8993	.8916	.503	.5639	.5639	1.1831	.9755
18	.503	.6001	.5335	.6249	.4877	.6687	.6249
19	.5792	.703	.5944	.6554	.5335	.7373	.6097
20	.6401	.7202		.6097	.5944	.7202	.6859
21	.5792	.6173	.5944	.5639	.5792	.6516	.6097
22	.3963	.5487	.503	.503	.5335	.583	.503
23	.2591	.4458	.4115	.4572	.442	.4801	.3963
24	.3201	.2591	.5144	.442	.4877	.4725	.4458
Max	.8993	1.0288	1.286	1.1126	1.2041	1.2689	1.0669
Min	.2591	.2591	.3963	.2286	.3506	.4572	.3963
Avg	.5894	.6489	.5893	.5519	.5576	.7678	.6816

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214519 / 33 KV PIMPRI PENDHAR

Feeder No / Name : 202 / JAMBHULPAT SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2743	.2915	.2915	.2134	.2915	.2401
2	.2058	.2743	.3086	.3086	.1829	.2915	.2401
3	.2572	.3772	.3429	.3601	.1829	.3258	.2743
4	.3086	.4287	.3429	.0343	.1524	.3772	.3429
5	.3601	.4287	.3429	.3772	.2286	.4287	.3772
6	.4115	.4287	.3601	.3601	.3048	.5144	.4458
7	.5316	.4801	.5316	.6001	.5182	.5144	.5658
8	.5144	.4287	.6173	.6344	.5792	.4801	.4458
9	.4115	.4115	.463	.5487	.4877		.3944
10	.3963	.463	.2229	.2743	.3601	.6173	.4572
11	.442	.5316	.2743	.2439	.3429	.5144	.4877
12	.4268	.4458	.2572	.2591	.3258	.5487	.4572
13	.4572	.4115	.2229	.2591	.2743	.5487	.4268
14	.4268	.3772	.2572	.2134	.3258	.5144	.3963
15	.381	.3944	.2915	.2286	.3258	.463	.4268
16	.381	.4287	.2915	.2591	.3429	.4801	.5792
17	.381	.4801	.3944	.2591	.3601	.4973	.5182
18	.3429	.3429	.4115	.3658	.4115	.4115	.3353
19	.3772	.4287	.4801	.3506	.4287	.4458	.3506
20	.3944	.3944		.3658	.4458	.3944	.4115
21	.3944	.3429	.4287	.3048	.3944	.3772	.3353
22	.2915	.2743	.3772	.2439	.2915	.3429	.2896
23	.2572	.2401	.3258	.2286	.2743	.2743	.2439
24	.2401	.2572	.2915	.3086	.2439	.2915	.2401
Max	.5316	.5316	.6173	.6344	.5792	.6173	.5792
Min	.1886	.2401	.2229	.0343	.1524	.2743	.2401
Avg	.3658	.3894	.3534	.3200	.3332	.4324	.3868

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

ALE PHATA S/DN.[770] BU 4770

Substation No/ Name :- 214519 / 33 KV PIMPRI PENDHAR

Feeder No / Name : 203 / NAVLEWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4973	.7716	.4801	.5316	.5144	.2743	.7202
2	.5316	.7716	.4801	.4801	.463	.2743	.7545
3	.583	.823	.5144	.4973	.4458	.3086	.7545
4	.6344	.8745	.5658	.5316	.463	.3258	.823
5	.6516	.8916	.6859	.583	.583	.3429	.8745
6	.8402	.9774	.823	.8059	.7202	.3944	.9431
7	1.2346	1.166	.9088	.8745	.8916	.4801	1.3203
8	1.3032	1.2689	.8573	.7716	.8916	.4115	1.3203
9	1.2517	1.1317	.7716	.7202	.7716		1.1317
10	.6859	.6001	.9431	1.1488	.8573	.6173	.6173
11	.6344	.6344	1.2689	1.1145	.9431		.6344
12	.5639	.6516	1.286	1.1488	1.2003	.6344	.7373
13	.6344	.6344	1.286	1.1488	1.1831	.7373	.7202
14	.6687	.6344	1.2689	1.1145	1.166	.7888	.6516
15	.703	.6516	1.2517	1.0974	1.2346	.8402	.6516
16	.7202	.7545	1.2689	1.1831	1.286	.8745	.8402
17	.7545	.823	1.2517	.6344	1.1145	.9774	.8059
18	.8402	.9259	.6859	.6516	.6173	.9602	.9088
19	.8745	.9259	.9088	.8916	.6859	.9431	.9088
20	.9259	.8745		.823	.7545	.9088	.9602
21	.8402	.7716	.8059	.7888	.6687	.8573	.8573
22	.6344	.6687	.6687	.7545	.583	.7545	.7545
23	.7716	.5658	.5658	.6001	.5487	.6516	.6173
24	.5144	.7716	.5144	.5144	.5487	.2572	.4801
Max	1.3032	1.2689	1.286	1.1831	1.286	.9774	1.3203
Min	.4973	.5658	.4801	.4801	.4458	.2572	.4801
Avg	.7622	.8152	.8722	.8088	.7973	.6188	.8245

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214404 / 33 KV GHODEGAON

Feeder No / Name : 201 / NARODI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3222	.4409	1.2887	1.1869	1.358	.3185	.4024
2	.2883	.4239	1.2717	1.1869	1.358	.0302	.3856
3	.2883	.4239	1.2717	1.1869	1.3413	.3018	.3856
4	.373	.4578	1.3904	1.3226	1.358	.3521	.4024
5	.4239	.4917	1.5091	1.4752	1.4251	.3856	.4359
6	.4917	.5426	1.7804	1.8313	1.4922	.4862	.4527
7	.5765	.6104	2.0687	2.1026	1.9113	.6371	.5533
8	.5426	.5765	2.2382	2.1534	2.1963	.5533	.5365
9	.5087	.5426	1.8442		1.8778	.4024	.4527
10	2.713	2.34	.3688		.4527	2.5987	
11	2.696	.7122	.4024		.4359	2.6993	
12	2.6791	2.34	.4024		.3856	2.5819	
13	2.4926	2.2721	.3856		.3353	2.3975	
14	2.4247	2.2043	.4024		.3353	2.1963	
15	.57	2.1026	.4024		.3353	2.2969	
16	.6203	2.0008	.4191		.4024	2.2298	
17	2.1026	1.7295	.4917	.503	.4748	2.3472	2.2634
18	.5765	.5596	.5426	.503	.5596	.503	.5087
19	.6104	.6443	.6274	.57	.6874	.57	.6203
20	.6443	.763	.5765	.6706	.788	.7209	.6874
21	.7122	.6443	.5087	.6539	.5197	.6371	.6371
22	.5765	.5935	.4917	.5868	.4191	.57	.57
23	.5087	.4917	.4578	.5365	.3521	.4527	.4527
24	.3222	.4409	.4917	1.1869	1.3413	.3185	.4024
Max	2.713	2.34	2.2382	2.1534	2.1963	2.6993	2.2634
Min	.2883	.4239	.3688	.503	.3353	.0302	.3856
Avg	1.0027	1.0145	.9014	1.1035	.9226	1.1078	.5970

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214404 / 33 KV GHODEGAON

Feeder No / Name : 202 / GHODEGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3898	.443	.4252	.4252	.4252	.4961	.4607
2	.3544	.443	.4252	.4252	.4075	.4607	.4252
3	.3544	.4252	.4252	.4252	.4252	.4607	.4252
4	.443	.5138	.5316	.5138	.4075	.5138	.443
5	.5138	.6556	.6733	.6024	.567	.6733	.6024
6	.7087	.7619	.7973	.691	.7265	.9036	.7973
7	.9745	.9568	.9922	.9214	.9214	.9922	1.0631
8	.8682	.9214	1.0277	.8505	.9214	.815	.9745
9	1.0454	.9391	.8859	.9036	1.0277	.9214	.9214
10	1.0454	.9922	1.0277		.8505	1.0808	
11	1.0099	1.0631	.9745		.7973	1.134	
12	.9922	.9214	.8328		1.0277	1.2226	
13	.9922	.815	.7265		1.134	.8505	
14	.7442	.8682	.8328		1.0985	.7796	
15	.8859	.8859	.7619		1.0277	1.0099	
16	.8328	.8682	.7619		.9568	1.1517	
17	.9391	.9036	.7619	.8505	.7442	1.0454	.9391
18	.9214	.691	.7973	.7796	.691	.8859	.7796
19	.8328	.7442	.815	.9568	.7619	.8505	.815
20	.7619	.7619	.7619	.815	.8328	.8328	.8505
21	.7265	.691	.7265	.7442	.7087	.7619	.7619
22	.6024	.6201	.6379	.6556	.6201	.691	.6733
23	.5138	.5316	.5138	.5493	.5493	.5316	.5493
24	.3898	.443	.4607	.4252	.443	.4961	.4784
Max	1.0454	1.0631	1.0277	.9568	1.134	1.2226	1.0631
Min	.3544	.4252	.4252	.4252	.4075	.4607	.4252
Avg	.7434	.7442	.7324	.6785	.7530	.8150	.7035

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214404 / 33 KV GHODEGAON

Feeder No / Name : 203 / SHINOLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1949	1.3443	.7095	.7468	.8029	1.4003	1.4003
2	1.1763	1.3443	.6908	.7468	.7842	1.3817	1.419
3	1.1763	1.3256	.6722	.7468	.7842	1.3817	1.4003
4	1.2696	1.475	.7282		.8029	1.475	1.4003
5	1.4377	1.6617	.7842	.8215	.8402	1.6244	1.4937
6	1.7364	1.9044	.8589	.8589	.8962	1.9418	1.5497
7	2.1658	2.1285	.9149	.8962	.9335	2.2965	2.0911
8	2.4646	2.3339	.7655	.7842	.8029	2.2032	2.3525
9	2.0538	1.8858	.7282		.7468	1.7737	1.9605
10	.7095	.7468	2.4272		2.6513	.6722	
11	.6908	.7095	2.8753		2.6139	.6722	
12	.7095	.7095	2.8193		2.6513	.6535	
13	.6908	.6908	2.5579		2.6886	.6722	
14	.6908	.6908	2.4459		2.5206	.6722	
15	2.5766	.6722	2.3712		2.4459	.6535	
16	2.4646	.6722	2.4459		2.2965	.6722	
17	.7282	.6722	2.5019	2.0165	2.1098	.6535	.6535
18	.8402	.6556	.8962	.7468	.7282	.6908	.7095
19	.9522	.8962	.8775	.8775	.8402	.8402	.8029
20	.9709	.9896	.9709	1.0642	.9054	1.0082	1.0082
21	1.0082	.9149	1.0269	1.0082	.9709	.9709	.9522
22	.8962	.8589	.9149	.9522	.8775	.8962	.8962
23	.8402	.8029	.8029	.8589	.8215	.8029	.8215
24	1.2323	1.3443	.7095	.7468	.8029	1.419	1.3443
Max	2.5766	2.3339	2.8753	2.0165	2.6886	2.2965	2.3525
Min	.6908	.6556	.6722	.7468	.7282	.6535	.6535
Avg	1.2782	1.1429	1.3957	.9248	1.3883	1.1428	1.3092

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214404 / 33 KV GHODEGAON

Feeder No / Name : 204 / Kotamdara

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6882	.6562	.192	.192	.2401	.3841	.7522
2	.6722	.6401	.176	.192	.2401	.3681	.7362
3	.6722	.6401	.16	.192	.2241	.3681	.7682
4	.7682	.7042	.2241	.2721	.2241	.4641	.7522
5	.8802	.8322	.3041	.3041	.3041	.7682	.8322
6	1.1363	1.0082	.3521	.3681	.4161	1.1043	.8962
7	1.5364	1.3123	.4321	.4321	.3361	1.5844	1.5524
8	1.7284	1.6004	.3201	.3521	.3361	1.8244	1.3603
9	1.3123	1.2483	.2241			1.3603	1.2483
10	.2241	.192	1.8244		1.7604	.2561	
11	.192	.176	1.7284		1.7284	.2561	
12	.2561	.192	1.8404		1.6004	.2561	
13	.2881	.192	1.7924		1.5524	.2401	
14	.2561	.208	.9762		1.5203	.208	
15	1.3923	.2241			1.4883	.208	
16	1.4723	.208	1.6004		1.5203	.2241	
17	.2401	.2401	1.3923	1.4083	1.1523	.2881	.2721
18	.3361	.3041	.3681	.2401	.3041	.2561	.3041
19	.3841	.3841	.3521	.3841	.3841	.3521	.3681
20	.4001	.4321	.3681	.4321	.4481	.4161	.4161
21	.3521	.3521	.3681	.3841	.3841	.3521	.3841
22	.3041	.2881	.3041	.3361	.3201	.2881	.3361
23	.2401	.2241	.2401	.2721	.2241	.2401	.2401
24	.7042	.6562	.192	.192	.2241	.4001	.7842
Max	1.7284	1.6004	1.8404	1.4083	1.7604	1.8244	1.5524
Min	.192	.176	.16	.192	.2241	.208	.2401
Avg	.6848	.5381	.6840	.3721	.7362	.5195	.7061

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214445 / 33/11KV TALEGHAR

Feeder No / Name : 201 / TALEGHAR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4423	.4396	.3973	.3953	.3953	.4146	.4287
2	.4376	.4073	.3851	.3882	.3884	.3851	.3944
3	.4293	.4394	.4144	.4106	.4287	.3773	.4111
4	.4786	.4881	.4376	.4537	.463		.4277
5	.5639	.6606	.5898	.5843	.6015		.5715
6	.7862	.7966	.811	.7603	.7637	.8983	.8149
7	.9529	1.1474	.9614	.9893	1.0188	1.1012	1.2163
8	1.1334	1.029	1.1238	1.0876	1.151	1.079	1.1923
9	1.1288	.9327	1.079	1.0159	1.1273	1.0282	1.1091
10	1.0038	.9606	.9647	.9945	1.0985	.9685	.9945
11	.9383	.8736	.6377	.9426	.9704	.8424	.9864
12	.848	.7989	.6155	.8078	.855	.8492	.8342
13	.7182	.7239	.6372	.8048	.8484	.6204	.6938
14	.7378	.736	.6294	.7888	.71	.6694	.6039
15	.7998	.7019	.7042	.8297	.7193	.7511	.6097
16	.8998	.7116	.6062	.7865	.7278	.5885	.7062
17	.9021	.8243	.763	.7554	.7643	.9175	.7062
18	.9658	.9984	.8094	.8001	.8161	.9865	.7158
19	1.0431	.9931	.9727	1.0022	.8103	1.1035	.9064
20	1.0092	.9984	.9432	.9012	.8734	1.1242	.9658
21	.9177	.8443	.7611	.8459	.7604	.7888	.8709
22	.7699	.7049	.5959	.6935	.6099	.6081	.7835
23	.6066	.489	.5305	.4973	.5161	.5144	.5545
24	.476	.4948	.4213	.4473	.4458	1.1242	.4801
Max	1.1334	1.1474	1.1238	1.0876	1.151	1.1242	1.2163
Min	.4293	.4073	.3851	.3882	.3884	.3773	.3944
Avg	.7912	.7581	.6996	.7493	.7443	.8064	.7491

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214445 / 33/11KV TALEGHAR

Feeder No / Name : 202 / 11kV Bhimashankar

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0738	.0785	.0659	.0695	.0697	.0579	.053
2	.0759	.0739	.0645	.0506	.0623	.0673	.0529
3	.0851	.0812	.0684	.0657	.072	.0738	.0527
4	.0889	.0931	.0822	.0666	.0705	.0885	.0703
5	.0928	.0985	.0851	.0877	.0857	.1043	.0726
6	.1077	.1202	.0961	.108	.1049	.1304	.1091
7	.1225	.1438	.1207	.1459	.1372	.152	.1457
8	.1338	.1291	.1272	.1256	.1364	.1311	.146
9	.1379	.0941	.1332	.1031	.136	.1085	.1077
10	.1215	.0786	.1071	.1035	.102	.0995	.0866
11	.0845	.0656	.1072	.1047	.0854	.0992	.079
12	.0782	.0807	.1034	.0859	.0919	.0823	.1041
13	.0724	.0668	.0979	.0703	.0852	.098	.0975
14	.0696	.0828	.0788	.0703	.0649	.0964	.1
15	.0703	.0849	.0754	.0686	.0693	.0922	.0841
16	.0701	.0739	.0867	.0857	.0865	.0918	.0945
17	.0803	.0783	.1238	.0849	.1008	.0985	.0923
18	.1164	.096	.0875	.1008	.0975	.1035	.0977
19	.1734	.1205	.1468	.1629	.1454	.128	.1285
20	.1618	.1541	.1648	.166	.1558	.1648	.1495
21	.1358	.1296	.1638	.1472	.1278	.1465	.1401
22	.1202	.1169	.1445	.1282	.1113	.1099	.109
23	.0971	.0715	.1251	.0915	.0904	.0915	.0847
24	.0885	.0836	.0691	.0876	.0915	.0623	.0713
Max	.1734	.1541	.1648	.166	.1558	.1648	.1495
Min	.0696	.0656	.0645	.0506	.0623	.0579	.0527
Avg	.1024	.0957	.1052	.0992	.0992	.1033	.0970

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214445 / 33/11KV TALEGHAR

Feeder No / Name : 203 / AHUPE

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1043	.1061	.0951	.0915	.0915	.1063	.1099
2	.1024	.0988	.0933	.0915	.0915	.0935	.0915
3	.1061	.1079	.0914	.1099	.1025	.1045	.1099
4	.1079	.1134	.1061	.1135	.1099	.1228	.1099
5	.1134	.1262	.1244	.1282	.1227	.1263	.0915
6	.1299	.1372	.1262	.1465	.1465	.1318	.1282
7	.1317	.1518	.1317	.1831	.1831	.1593	.1648
8	.1299	.1573	.1683	.1282	.1465	.1263	.1282
9	.1024	.0969	.086	.1099	.1099	.0952	.0915
10	.0786	.0878	.0805	.0732	.1099	.0751	.0549
11	.0622	.0823	.064	.0623	.0915	.0549	.0549
12	.075	.0841	.0695	.0623	.0659	.0549	.0568
13	.0951	.075	.0768	.0769	.0604	.0732	.0751
14	.0658	.0768	.0622	.0549	.0696	.0732	.0677
15	.0768	.0988	.0695	.0549	.0586	.0549	.0623
16	.064	.0896		.0732	.0677	.0732	.0604
17	.1116	.1116		.0915	.0806	.0915	.0879
18	.1555	.1317	.1099	.1282	.1208	.1465	.1245
19	.1884	.1555	.1831	.1648	.1684	.1831	.1813
20	.2158	.2195	.2197	.2197	.2144	.2197	.2218
21	.1975	.203	.2014	.2197	.1814	.1831	.1851
22	.1756	.1884	.2014	.1648	.1595	.1648	.1576
23	.1427	.1335	.1465	.1099	.1191	.1282	.0951
24	.1134	.1134	.1225	.1282	.0915	.1008	.0915
Max	.2158	.2195	.2197	.2197	.2144	.2197	.2218
Min	.0622	.075	.0622	.0549	.0586	.0549	.0549
Avg	.1186	.1228	.1195	.1161	.1151	.1143	.1084

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214457 / 33/11KV KALAMB S/S

Feeder No / Name : 201 / KALAMB

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	1.0288	.3601	.4287	.3772	.7202	.9945
2	.6859	1.286	.3429	.4287	.3429	.7545	1.0117
3	.7716	1.3717	.3429	.4458	.3429	.7545	1.046
4	.823	1.6289	.3429	.4801	.3772	.7888	
5	.9259	1.6289	.3429	.4973	.3944	.9088	1.0802
6	1.166	1.7147	.463	.5487	.4801	1.0288	1.2003
7	1.4746	1.7147	.5658	.6001	.6344	1.4746	1.6289
8	1.5432	1.7147	.5487	.5658	.583	1.7147	1.9376
9	5.5041	1.286	.4458	.5144	.5144	1.5432	1.749
10	.1715	.3429	2.0576	1.9719	2.0062	.4287	.1715
11	.1372	.3429	2.0233	2.1605	1.989	.3429	.1715
12	.1372	.3429	2.0576	2.0233	1.7318	.3429	.1715
13	.12	.3601	1.8004	1.9719	1.5775	.3772	.1715
14	.012	.3429	1.6289	1.8861	1.7147	.3944	.1543
15	.12	.3258	1.8004	1.8004	1.7661	.4287	.1543
16	.12	.3429	1.8861	1.749	1.8519	.4287	.1543
17	.1543	.3601	1.8004	1.7147	1.6461	.4801	.1543
18	.1715	.3772	.4287	.4115	.4801	.5144	.1543
19	.2058	.5658	.6001	.6516	.5316	.6516	.1715
20	.2058	.6344	.6859	.6859	.703	.7202	.1715
21	.2058	.583	.6344	.6001	.6859	.6859	.1715
22	.2058	.5316	.5487	.5487	.583	.6001	.1543
23	.2058	.4287	.4458	.4115	.5144	.4801	.1543
24	.6516	.8573	.3772	.4287	.3944	.7202	.9602
Max	5.5041	1.7147	2.0576	2.1605	2.0062	1.7147	1.9376
Min	.012	.3258	.3429	.4115	.3429	.3429	.1543
Avg	.6835	.8380	.9388	.9802	.9259	.7202	.6039

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214457 / 33/11KV KALAMB S/S

Feeder No / Name : 202 / EKLAHARE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.6859	.2058	.2229	.2058	.583	.6859
2	.6001	.7716	.2058	.2229	.1886	.583	.7202
3	.6001	.7202	.2058	.2401	.2058	.6173	.7202
4	.6516	.8573	.2058	.2572	.2229	.6516	.7716
5	.7716	.9431	.2058	.2572	.2229	.7373	.8059
6	.8916	1.0288	.2401	.2743	.2401	.8573	.8573
7	1.0631	1.0288	.2915	.3086	.2572	1.0631	1.2003
8	1.0974	1.1145	.2401	.2743	.2401	1.1831	1.3375
9	1.1145	1.1145	.2229	.2401	.2058	1.1145	1.286
10		.2572	1.406	1.5089	1.4403	.2572	.1372
11		.2915	1.4575	1.6461	1.5089	.2743	.1372
12	.1715	.2572	1.4232	1.5947	1.4232	.2572	.1372
13	.1715	.2401	1.4575	1.5432	1.3889	.2572	.1372
14	.1543	.2401	1.3889	1.4746	1.286	.2058	.1372
15	.1543	.2572	1.3546	1.3032	1.3032	.2058	.1543
16	.1543	.2743	1.3717	1.3032	1.286	.1715	.1543
17	.1543	.2572	1.286	1.286	1.2003	.2572	.1543
18	.1543	.3086	.2743	.2229	.2915	.2915	.1543
19	.1715	.3258		.3429	.4287	.3772	.1543
20	.1715	.3429		.3601	.4115	.4287	.0171
21	.2229	.3601	.3429	.3086	.4115	.3944	.1715
22	.2058	.3086	.3258	.2743	.3601	.3772	.1715
23	.2058	.2743	.2572	.2058	.3086	.3429	.1715
24	.5144	.6859	.2229	.2401	.2229	.5658	.6516
Max	1.1145	1.1145	1.4575	1.6461	1.5089	1.1831	1.3375
Min	.1543	.2401	.2058	.2058	.1886	.1715	.0171
Avg	.4521	.5394	.6633	.6630	.6359	.5023	.4594

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214457 / 33/11KV KALAMB S/S

Feeder No / Name : 203 / MAHALUNGE PADWAL SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.2743	.5316	.4458	.4287	.1715	.1886
2	.12	.2058	.5316	.4801	.4287	.1543	.1886
3	.12	.2058	.5487	.5144	.5144	.1543	.2058
4	.1372	.1715	.5487	.5658	5.144	.1715	.2058
5	.1372	.1715	.5487	.6173	.583	.1886	.2229
6	.1715	.2058	.6687	.823	.8573	.2229	.2401
7	.2401	.2058	1.166	1.286	1.3375	.2915	.2743
8	.1886	.2058	1.3375	1.3032	1.3375	.2401	.3086
9	.12	.2058	1.166	1.2517	1.3717	.2401	.2572
10		1.4918	.2229	.2401	.1886	1.5432	1.286
11	1.2003	1.3717	.2229	.2401	.1543	1.6289	1.3546
12	1.286	1.2689	.2229	.2572	.1715	1.6289	1.3717
13	1.286	1.286	.2401	.2229	.2401	1.5432	1.3717
14	1.2346	1.2003	.2229	.2058	.2401	1.4575	1.3717
15	1.2346	1.2003	.2229	.1543	.2401	1.4575	1.286
16	1.2003	1.1831	.1886	.1715	.2572	1.5432	1.2003
17	1.0288	1.1488	.2572	.2058	.2572	1.406	1.2003
18	.4287	.2229	.2401	.2229	.2401	.2572	.2058
19	.3772	.2743	.2572	.2743	.3086	.2743	.2058
20	.3429	.2743	.2572	.2915	.3772	.2915	.2401
21	.3429	.2572	.2229	.3086	.3258	.2572	.2401
22	.3772	.2058	.1886	.2743	.2572	.2401	.2058
23	.3772	.1715	.1543	.1715	.2058	.2058	.1715
24	.1372	.3429	.5144	.4287	.4115	.1715	.2058
Max	1.286	1.4918	1.3375	1.3032	5.144	1.6289	1.3717
Min	.12	.1715	.1543	.1543	.1543	.1543	.1715
Avg	.5308	.5730	.4451	.4565	.6616	.6559	.5837

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214457 / 33/11KV KALAMB S/S

Feeder No / Name : 206 / 11kV Lauki

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-MAR-17
HR	Load (MW)
10	***
Max	150.8918
Min	150.8918
Avg	150.8918

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214474 / 33 KV WADGAON

Feeder No / Name : 201 / Kolwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2883	.2543	.8309	.5765	.6783	.2543	.2374
2	.3052	.2374	.8478	.6104	.6783	.2374	.2204
3	.3222	.2374	.8478	.6443	.763	.2374	.2204
4	.39	.2204	.9156	.9156	.8139	.2543	.2543
5	.4748	.2543	.9326	1.153	.8478	.2543	.2883
6	.5935	.3391	1.2548	1.2887	.9835	.4578	.407
7	.6443	.5087	1.4922	1.3904	1.4413	.6783	.407
8	.5765	.5935	1.5091	1.7126	1.7465	.5256	.4239
9	.4748	.4578	1.543	1.4413	1.5091	.4239	.2883
10	1.56	1.3395	.4409	.373	.4409	1.6278	1.5939
11	1.56	1.4243	.407		.4239	1.5939	1.6956
12	1.4922	1.3904	.3561		.407	1.5939	1.7635
13	1.4922	1.3395	.373		.4239	1.6956	1.6617
14	1.4752	1.3226	.373		.407	1.7126	1.5769
15	1.4752	1.3056	.3561		.4239	1.5939	1.7126
16	1.3565	1.2548	.3391	.4748	.407	1.543	1.6448
17	1.2039	1.153	.373	.39	.373	1.3395	1.4752
18	.4239	.407	.4578	.39	.3391	.3391	.2543
19	.5426	.5765	.5256	.4748	.6443	.39	.3391
20	.6274	.6274	.5596	.4409	.6443	.5426	.373
21	.4748	.5426	.5426	.407	.6274	.5087	.3391
22	.4239	.4748	.426	.3391	.4917	.3052	.2883
23	.373	.3561	.3561	.2204	.3561	.2543	.2543
24	.3052	.2374	.8309	.5935	.6274	.2883	.2543
Max	1.56	1.4243	1.543	1.7126	1.7465	1.7126	1.7635
Min	.2883	.2204	.3391	.2204	.3391	.2374	.2204
Avg	.7857	.7023	.7038	.7282	.6874	.7772	.7489

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214474 / 33 KV WADGAON

Feeder No / Name : 202 / Sultanpur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5735	.6882	.1638	.1802	.1311	.7373	.8848
2	.6226	.6882	.1638	.1966	.1638	.7537	1.0159
3	.7209	.7209	.1802	.1966	.1638	.7537	1.0159
4	1.2452	.7537	.1966	.2294	.1638	.8192	.9995
5	1.5074	1.0159	.1966	.3113	.1802	.9339	1.0486
6	1.5729	1.1469	.2785	.3441	.213		1.3763
7	1.5565	1.4746	.3932	.3768	.2622	1.2944	1.704
8	1.7532	1.5893	.3605	.3768	.2785	1.8842	1.6876
9	1.6221	1.4419	.4096	.2949	.3605	1.7204	1.7859
10	.2294	.2458	1.9989	2.1464	2.2611	.1966	.213
11	.2785	.2294	2.0972	2.1628	2.2447	.1802	.213
12	.2622	.2294	2.1792	2.1956	2.2119	.1311	.213
13	.2622	.2294	2.2119	2.13	2.13	.1638	.213
14	.2294	.213	2.13	2.13	2.0481	.1802	.1966
15	.2785	.213	2.1136	2.1628	2.0317	.1966	.213
16	.3113	.2294	2.0481	2.0481	1.9662	.2458	.213
17	.3277	.2458	1.9662	1.8842	1.8515	.2949	.1966
18	.2622	.3441	.3277	.2785	.213	.3277	.2785
19	.3605	.3932	.3113	.3113	.3768	.3768	.2949
20	.3605	.426	.3605	.2949	.2949	.4424	.3277
21	.3277	.3605	.3277	.2458	.2949	.3605	.2785
22	.2458	.2458	.2622	.1638	.2294	.2458	.2458
23	.1802	.1802	.1966	.1311	.1638	.1802	.1966
24	.5898	.6554	.1802	.1966	.1311	.7373	.8192
Max	1.7532	1.5893	2.2119	2.1956	2.2611	1.8842	1.7859
Min	.1802	.1802	.1638	.1311	.1311	.1311	.1966
Avg	.6533	.5817	.8773	.8745	.8486	.5720	.6513

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214474 / 33 KV WADGAON

Feeder No / Name : 203 / 11kV Chass

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.439	.4359	1.2773	.951	1.0083	.4039	.5266
2	.4603	.4344	1.2483	.9252	1.1538	.381	.4855
3	.4519	.4237	1.3168	1.0044	1.1972	.378	.4938
4	.5297	.4603	1.3153	1.1172	1.2658	.4207	.5419
5	.6729	.5289	1.483	1.5546	1.3168	.4748	.6264
6	.8711	.6996	1.6605	1.7215	1.4571	.7644	.7682
7	.9862	.8056	2.063	2.0531	2.2283	.9793	.8985
8	.8428	.8581	2.4859	2.6109	2.8227	.8093	.8116
9	.5815	.5525	2.4661	2.4897	2.8212	.5426	.4992
10	3.2922	2.7824	.6043	.8208	.8475	3.2106	3.3965
11	3.4149	2.9157	.3338	.4778	.3504	3.344	3.3867
12	3.3867	2.8616	.3277	.3597	.3453	3.3737	3.6336
13	3.3402	2.8136	.231	.3955	.3452	3.4507	3.6359
14	3.2724	2.7724	.3696	.3666	.3575	3.3958	3.594
15	1.8328	2.5628	.3544	.4054	.3689	3.2655	3.5064
16	3.171	2.3495	.3567	.3765	.3697	3.0628	3.4446
17	3.0422	2.3967	.3643	.3513	.4077	3.0346	3.3913
18	.8497	.9907	.5426	.3643	.4321	.9427	.7385
19	.6432	.7629	.6652	.6599	.6485	.5982	.5693
20	.9709	1.0037	.9031	.8916	.961	.9938	1.009
21	.8947	.9397	.9617	.871	.9663	1.057	1.012
22	.8086	.8436	.772	.7911	.8276	.868	.8916
23	.6081	.647	.6508	.6699	.6218	.6554	.6592
24	.4634	.7949	1.182	1.0144	.6928	.4504	.5777
Max	3.4149	2.9157	2.4859	2.6109	2.8227	3.4507	3.6359
Min	.439	.4237	.231	.3513	.3452	.378	.4855
Avg	1.4928	1.3598	.9973	.9685	.9922	1.5357	1.6291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214486 / 33/11 KV Peth subststion.

Feeder No / Name : 201 / 11KV kurwandi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2401	.1581	.208	.1989	.2214	
2		.2401	.1739	.208	.1989	.2372	
3		.2401	.1739	.208	.2155	.253	
4		.2561	.2056	.2241	.2321	.253	
5		.2721	.2372	.2561	.2458	.2846	
6		.3521	.3005	.3041	.2785	.3321	
7		.4961	.3321	.2881	.3277	.5218	
8	.6796	.6401	.2372	.2561	.2214	.5693	
9	.4961		.2214	.2622	.2056		.4161
10	.128		.5121	.4588	.4744		.16
11	.128		.4161	.3605	.427		.144
12	.128		.3681	.3441	.2688	.1147	.128
13	.128		.3521	.3239	.2214	.1475	.112
14			.3201	.3239	.2372	.0983	.112
15	.112		.2721	.3277		.1147	.112
16	.144	.1638	.427	.4424	.3479	.1311	.128
17	.176	.1898	.4001	.3768	.3321		.1457
18	.192	.1739	.208	.1966	.1581		.16
19	.208	.253	.0949	.2622	.1898		.2401
20	.2401	.2688	.2721	.2652	.253		.2241
21	.2401	.2688	.2561	.2818	.2688		.2401
22	.2241	.2372	.2241	.2321	.2372		.2241
23	.2058	.1581	.192	.2155	.2056	.2321	.208
24		.2401	.1581	.208	.1966	.2372	
Max	.6796	.6401	.5121	.4588	.4744	.5693	.4161
Min	.112	.1581	.0949	.1966	.1581	.0983	.112
Avg	.2287	.2759	.2714	.2848	.2584	.2499	.1836

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214486 / 33/11 KV Peth subststion.

Feeder No / Name : 202 / 11 KV Peth

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0762	.0914	.1219	.1311	.0762	
2		.061	.0914	.1219	.1311	.0762	
3		.0762	.0914	.1219	.116	.0762	
4		.0762	.0914	.1219	.1326	.0762	
5		.0762	.1067	.1372	.1492	.0914	
6		.0762	.1219	.1524	.1989	.1219	
7	.116	.1067	.2439	.2439	.2321	.1219	
8	.0995	.0914	.2591	.3201	.2743	.1067	
9	.0762		.2134	.2458	.2439		.1067
10	.1981		.061	.0655	.061		.1981
11	.1524		.061	.0655	.0457		.1677
12	.1372	.1147	.0457	.0492	.0457	.2294	.1677
13	.1372	.0983	.0457	.0492	.0457	.1638	.1067
14		.1311	.0457	.0492	.0305	.1638	.1067
15	.1372	.1296	.0457	.0655	.0457	.1311	.1372
16	.1829	.1966	.0762	.0492	.0305	.1943	.1829
17	.1372	.1677	.0762	.0655	.061		.1829
18	.061	.061	.061	.0655	.0762		.061
19	.061	.0914	.0914	.0983	.0914		.0914
20	.0914	.0914	.1067	.116	.1067		.1067
21	.1067	.0914	.0914	.0995	.1067		.1067
22	.0762	.0762	.0762	.0829	.1067		.0762
23	.0762	.0762	.0762	.0663	.1067	.0829	.0762
24		.0762	.0914	.1219	.1311	.0914	
Max	.1981	.1966	.2591	.3201	.2743	.2294	.1981
Min	.061	.061	.0457	.0492	.0305	.0762	.061
Avg	.1154	.0972	.0984	.1123	.1125	.1202	.1250

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214486 / 33/11 KV Peth subststion.

Feeder No / Name : 203 / 11 KV Pargaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0857	.12	.12	.1326	.0857	
2		.0857	.12	.12	.116	.1029	
3		.1029	.12	.12	.116	.1029	
4		.12	.1372	.1543	.1492	.12	
5		.1372	.1543	.2058	.1823	.1543	
6		.1372	.1715	.2572	.2321	.1715	
7		.2058	.2743	.3086	.2652	.1715	
8	.1311	.1886	.3429	.3429	.4115	.1715	
9	.12		.2743	.2294	.4115	.1147	.1372
10	.2347		.1029	.1311	.0857		.3353
11	.2105		.1029	.1147	.0857		.2915
12	.2105		.1029	.1134	.1029	.2785	.2683
13			.0686	.0972	.0857	.1966	.2267
14			.0857	.0972	.0686	.1966	.1781
15	.1943		.0857	.1147	.0857	.1311	.1943
16	.2429	.2294	.1029	.0983	.0857	.1638	.2429
17	.3077	.2058	.0857	.1147	.1029		.2753
18	.1457	.1029	.12	.1311	.1029		.1543
19	.1886	.1372	.1372	.1326	.1715		.1715
20	.1372	.1372	.1715	.1658	.1715		.1715
21	.1372	.12	.1372	.1492	.1543		.1543
22	.12	.1029	.12	.1311	.12		.1543
23	.1029	.0857	.1029	.116	.1029	.116	.1372
24		.0857	.12	.1147	.1311	.0857	
Max	.3077	.2294	.3429	.3429	.4115	.2785	.3353
Min	.1029	.0857	.0686	.0972	.0686	.0857	.1372
Avg	.1774	.1335	.1400	.1533	.1531	.1477	.2062

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

GHODEGAON SUB-DN.[714] BU 4714

Substation No/ Name :- 214486 / 33/11 KV Peth subststion.

Feeder No / Name : 204 / Peth GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.4108	.3921	.4294	.4527	.4294	.4294
2	.3961	.3921	.4108	.4108	.415	.4294	
3	.3961	.3921	.3921	.4108	.415	.4108	
4	.3772	.4481	.4294	.4481	.4904	.4668	
5	.5093	.5788	.5601	.5601	.547	.5601	
6	.7733	.7842	.6722	.7655	.7356	.7468	
7	.8865	.8402	.7842	.7282	.8299	.8215	
8	.7545	.5975	.6722	.6722	.7655	.7095	
9	.6908	.5281	.5601	.6602	.5975		.5601
10	.5788	.415	.5415	.6036	.6161		.5788
11	.5041	.415	.4854	.5093	.5041		.5415
12	.5041	.415	.5601	.4904	.4481	.5281	.5041
13	.4854	.3772	.4108	.4904	.4111	.4715	.4294
14		.3395	.3734	.4715	.3921	.5281	.4481
15	.4294	.3206	.3734	.4715	.4668	.3395	.3921
16	.4668	.3206	.3921	.5093	.4481	.4527	.3361
17	.5041	.3361	.4108	.4715	.4481		.5415
18	.5041	.4668	.4668	.5093	.5601		.5228
19	.7282	.6908	.6722	.7733	.7842		.7095
20	.8402	.7468	.8775	.811	.8775		.7468
21	.7655	.6722	.8402	.7733	.7842		.7095
22	.6348	.6535	.6722	.6224	.6535		.6161
23	.5041	.4481	.5601	.547	.5228	.5093	.4854
24	.4338	.4294	.3921	.5041	.4904	.4481	.4668
Max	.8865	.8402	.8775	.811	.8775	.8215	.7468
Min	.3772	.3206	.3734	.4108	.3921	.3395	.3361
Avg	.5688	.5008	.5376	.5685	.5690	.5234	.5305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214402 / 33/11KV JUNNAR

Feeder No / Name : 201 / SHIVNERI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8473	1.6991	.6783	.823	.8326	1.448	1.5746
2	1.7556	1.7337	.7628	.8962	.7964	1.4842	1.6478
3	1.8642	1.8898	.8063	.9231	.7964	1.8099	1.7541
4	1.8804	1.9982	.8859	1.0903	.905	2.0814	1.9806
5	1.9204	2.1216	.9175	1.1157	1.0498	2.4434	2.0814
6	2.2148	2.0348	1.012	1.1888	1.2127	2.8416	2.167
7	2.8527	3.0308	1.4883	1.4661	1.3756	3.2579	2.1439
8	3.1727	3.0727	1.326	1.4661	1.3756	3.4027	3.3808
9	2.7362	3.152	1.4712	1.4352	1.3756	2.7526	3.4155
10	1.3769	1.7164	3.0498	3.1623	3.4155	1.2986	
11	1.2136	1.5939	3.0693	2.9635	3.3133	1.3203	
12	.6697	1.5546	3.0352	3.103	2.722	1.2127	
13	1.1888	1.448	2.9329	2.9312	2.8607		
14		1.3352	3.0148	3.0001	2.5833		
15	1.2803		3.2065	3.083	2.6606		
16	1.3937		3.2023	3.1459	2.9864		
17	1.3321			2.9005	2.9944		1.4918
18	.6554			1.3032	1.3756	1.7556	1.2894
19	1.4403	1.4752	1.4969	1.5927	1.448	1.7896	1.869
20	1.4373	1.326	1.5708	1.4118	1.3575	1.7556	1.7364
21	1.2003	1.0608	1.262	1.2308	1.1584	1.5181	1.2548
22	.9979	1.0608	1.0924	1.1041	.9412	1.2489	1.0159
23	.9709	1.0174	.5973	.9412	.9412	1.251	1.1096
24	1.8107	1.7741	.7209	.6036	.8688	1.3756	1.6644
Max	3.1727	3.152	3.2065	3.1623	3.4155	3.4027	3.4155
Min	.6554	1.0174	.5973	.6036	.7964	1.2127	1.0159
Avg	1.6179	1.8048	1.7091	1.7867	1.7228	1.8972	1.8575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214402 / 33/11KV JUNNAR

Feeder No / Name : 202 / MANIKDOH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3961	.4207	.9114	.8869	1.1222	.4887	.462
2	.4338	.3467	.9922	1.2489	1.086	.4525	.5041
3	.4715	.4374	1.0136	1.2851	1.086	.4887	.5359
4	.4715	.4744	1.0974	1.3352	1.2489	.543	.6697
5	.4715	.5121	1.1584	1.3352	1.448	.6154	.7133
6	.6838	.5898	1.2178	1.3213	1.6108	.7059	.7499
7	.5249	.7011	2.268	1.7896	1.8099	.7964	.7733
8	.6099	.4207	2.2177	2.0237	1.9547	.724	.8488
9	.6767	.4854	1.8427	1.8404	1.5203	.6979	.6979
10	2.3102	2.17	.5544	.5847	.5138	2.364	2.2348
11	2.3348	.2212	.4938	.5611	.4668	2.3908	2.3158
12	2.226	2.2325	.4938	.5729	.4251	2.3975	2.3975
13	2.3152	2.2177	.4715	.5611	.3721	2.4587	2.5415
14	2.1538	1.9313	.5093	.567	.4525	2.4863	2.4587
15	2.0595		.5316	.6468	.462	2.3158	2.332
16	1.8755		.5959	.6767	.462	2.4714	2.2365
17	1.858			.0579	.5304	2.3472	2.009
18	.4641		.5975	.6154	.5611		.4854
19	.6935	.6554	.8316	.724	.6697	.7577	.4961
20	.7712	.7865	.9055	.724	.724	.8962	.7545
21	.6935	.6958	.8316	.724	.724	.7947	.6447
22	.6733	.6401	.7421	.6697	.6697	.7655	.5765
23	.5731	.3932	.5415	.5973	.5973	.6394	.5487
24	.4338	.4641	1.2894	.9328	1.1584	.499	.4163
Max	2.3348	2.2325	2.268	2.0237	1.9547	2.4863	2.5415
Min	.3961	.2212	.4715	.0579	.3721	.4525	.4163
Avg	1.0906	.8398	.9612	.9284	.9032	1.2651	1.1835

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214402 / 33/11KV JUNNAR

Feeder No / Name : 203 / ozar

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8596	.9945	1.3466	1.5339	1.4842	1.086	.8962
2	.8869	1.0004	1.4118	1.5339	1.5746	1.086	1.0164
3	1.0059	1.1218	1.5364	1.5546	1.6651	1.1222	1.0425
4	1.1041	1.2003	1.56	1.6108	1.7556	1.1584	1.1765
5	1.1462	1.1919	1.6297	1.8296	1.8823	1.2127	1.2489
6		1.2136	1.949	1.8665	2.0633	1.2489	1.2715
7	1.2656	1.2483	2.1262		1.8823	1.3032	1.2715
8	1.1888		2.2923	3.1007	2.6787	1.2308	
9	1.1888		2.0645	2.3211	2.1719	1.1949	
10	1.1888	2.396			.8842	2.1956	2.2045
11	2.2207	4.7028				2.2348	2.4646
12	2.2805	2.3228				2.2211	2.1956
13	2.1616	2.0576				2.0405	2.2565
14	2.1312	1.9982				2.0631	2.0858
15	2.0576					2.0957	2.191
16	.2045					2.1704	2.1628
17	2.1992					2.2805	2.1559
18	1.153		1.6124	1.6651	1.5203	1.5223	1.2226
19	1.0486	1.6956	1.5912	1.8099	1.8823	1.5939	1.3112
20	.6173	1.4243	1.4299	1.7194	1.8099	1.4864	1.1789
21	.7461	1.2125	1.3352	1.5927	1.7375	1.4661	.9015
22	.6783	1.0059	1.5061	1.4661	1.5746	1.3352	.9602
23	1.0608	1.153	1.4449	1.3032	1.3756	1.3352	1.1096
24	.9055	1.0174	1.1797	1.4815	1.448	1.267	.9328
Max	2.2805	4.7028	2.2923	3.1007	2.6787	2.2805	2.4646
Min	.2045	.9945	1.1797	1.3032	.8842	1.086	.8962
Avg	1.2739	1.6087	1.6260	1.7593	1.7288	1.5813	1.5117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214402 / 33/11KV JUNNAR

Feeder No / Name : 204 / JUNNAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9328	1.3523	1.3998	1.4083	1.4661	1.448	1.134
2	.9955	1.1218	1.39	1.262	1.3394	1.3575	1.2489
3	1.0317	1.1919	1.4045	1.2127	1.2308	1.267	1.4083
4	1.2489	1.3847	1.4842	1.2012	1.3575	1.448	1.5181
5	1.2715	1.5043	1.4883	1.3213	1.5746	1.647	1.5746
6	1.5023	1.3904	1.5769	1.6278	1.7918	1.828	1.6832
7	2.0452	2.2192	2.3594		1.9547	2.0271	
8	2.0452	2.6406	2.3152	2.1992	2.0995	2.0995	2.1439
9	2.0022	2.1033	2.1538		2.1719	1.9136	1.9376
10	1.9163	1.828	2.1538	1.8842	2.1538	3.9407	
11	1.829	1.828	2.1209	1.8442	1.9591	1.8347	1.9342
12	1.8298	1.6956	1.95	1.8804	1.8604	1.8604	1.8099
13	1.7177	1.7013	1.9376	1.9204	1.7896	1.8204	1.8861
14	1.7375	1.6787	1.9909	1.8267	1.7918	1.8267	1.5592
15	1.5947		1.8404	1.9204	1.7187	1.8604	1.6118
16	1.6817		1.6124	1.9204		1.9959	1.5415
17	1.9004			1.8073	1.7896	1.9404	1.647
18	1.829		1.9728	1.8823	1.8823	2.0953	1.9105
19	2.1735	2.6863	2.2131	2.1719	2.1719	2.2862	2.3137
20	1.8229	2.6406	2.384	2.0995	2.1357	2.2624	2.2885
21	1.7528	1.9936	2.073	2.0995	2.0995	2.19	1.8229
22	1.8107	1.829	1.7896	1.9728	1.8823	2.1538	1.283
23	1.7558	1.7741	1.7741	1.8099	1.7375	1.9404	1.1218
24	.8686	1.4022	1.4632	2.1538	1.5927	1.5203	1.0903
Max	2.1735	2.6863	2.384	2.1992	2.1719	3.9407	2.3137
Min	.8686	1.1218	1.39	1.2012	1.2308	1.267	1.0903
Avg	1.6373	1.7983	1.8630	1.7921	1.8066	1.9402	1.6577

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214402 / 33/11KV JUNNAR

Feeder No / Name : 205 / Pimpalgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7741	1.7909	.7628	.9328	.7602	1.6289	1.6832
2	1.5939	1.8229	.6554	.8962	.724	1.7375	1.7353
3	1.5746	1.97	.7796	.9328	.7964	1.8642	1.7896
4	1.8107	2.0595	.7449	.9492	.8869	2.0633	2.1085
5	1.8604	2.1033	.7087	1.1163	.9774	2.2624	2.226
6	2.2148	2.7069	.6874	1.2226	1.0679	2.4796	2.4099
7	2.9622	3.219	1.0242	2.19	1.1584	2.6787	3.0687
8	3.2074	1.1789		1.3213		3.1855	3.4501
9	2.7362	2.774				2.5911	3.276
10		1.2357	3.2693	3.1855	3.3846	1.5844	1.4901
11		2.5393	3.2407	3.2065	3.103	1.4969	1.4003
12		1.2178	3.1327	3.083	2.9014	1.3432	
13		1.1765	3.0312	2.9504	2.6684	1.3213	1.3213
14		1.2012	2.9959	2.8704	2.3059	1.3392	1.2715
15			2.9959	2.7778	2.3312	1.4175	1.3073
16	1.3121	1.3352	3.0664	2.6216	2.392	1.4685	1.4449
17	1.1469	1.2483		2.4143	2.1439	1.531	1.3696
18	1.543	1.134	1.5384	1.3756	1.3756		1.4175
19	1.4373	1.4586	1.5769	1.5927	1.5203	1.9004	1.0749
20	1.4883	1.2018	1.6108	1.448	1.448	1.4352	1.3717
21	1.4632	1.0974	1.8604	1.3032	1.3756	1.3998	1.1843
22	1.2226	.8848	1.9204	1.1584	1.2308	1.2489	1.2039
23	.9709	.9069	1.9204	1.0136	1.0136	1.1517	1.0288
24		1.6644	.8539	1.0164	.7964	1.5384	1.3565
Max	3.2074	3.219	3.2693	3.2065	3.3846	3.1855	3.4501
Min	.9709	.8848	.6554	.8962	.724	1.1517	1.0288
Avg	1.7834	1.6490	1.8274	1.8078	1.6528	1.7682	1.7387

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214402 / 33/11KV JUNNAR

Feeder No / Name : 206 / 11kV Amrapur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7059	.6836	.7628	1.2127	1.3937	.8145	.6767
2	.7059	.6299	.815	1.2986	1.3575	.724	.6099
3	.7316	.6783	.8859	1.3491	1.3937	.724	.6335
4	.7499	.631	.9412	1.3717	1.4299	.7964	.823
5	.9036	.6859	1.0242	1.4083	1.5203	.8688	.8507
6	.9492	.6952	1.1393	1.4815	1.6289	.9412	.8775
7	.9231	.6706	.779	2.19	1.7194	.9991	.9055
8	1.0903	1.2048	1.9204	2.1538	2.1357	.9412	.6401
9	.9665	.663	1.7909	1.8898	1.9366	.9955	.7577
10	1.9204	1.7238	.7545	.7095	.9425	1.9719	1.9989
11	2.1262	2.2939	.6348	.5792	.9231	2.0317	1.4003
12	2.3167	2.2885	.6653	.7087	.5729	2.0885	2.1125
13	2.1719	2.1605	.7316	.8413	.8869	2.2291	2.1548
14	2.0851	1.9448	.7468	1.086		2.2466	2.2211
15	1.9109		.7522	1.1576	.7059	2.5072	2.13
16	2.1616		.7682	1.134	1.0534	2.3998	2.1605
17	2.0911			1.2136	1.1273	2.0119	2.3405
18	.7956		1.0903	1.1765	1.2127	1.1041	.9745
19	.8478	.8907	1.1763	1.267	1.3575	1.423	.7545
20	.7802	.8097	1.2357	1.1946	1.267	1.262	.8322
21	.5967	.5937	1.1041	1.1222	1.1584	1.0317	.6859
22	.5636	.6859	.9328	1.0136	1.1041	.9328	.815
23	.5426	.7282	.9149	.9231	1.0317	.9522	.8402
24	.7947	.663	1.0117	1.1403	1.4299	.905	.7577
Max	2.3167	2.2939	1.9204	2.19	2.1357	2.5072	2.3405
Min	.5426	.5937	.6348	.5792	.5729	.724	.6099
Avg	1.2263	1.0663	.9816	1.2343	1.2734	1.3709	1.2064

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214412 / 33/11KV APTALE

Feeder No / Name : 201 / Amboli

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1711	.2275	.6523	.1686		.1894	.2841
2	.1896	.2085	.6487	.1326	.3019	.1896	.1894
3	.2268	.2275	.7106	.1323	.3402	.1899	.2261
4	.2838	.2846	.7452	.1696	.3128	.1899	.2259
5	.3788	.3219	.8583	.2414	.3429	.2852	.3398
6	.4545	.455	.9441	.2881	.4287	.3799	.4154
7	.4536	.5093	1.5174	.3536	.4419	.4744	.7189
8		.3965	1.3961	.3718	.3823	.3595	
9	.5676	.4141	1.0357	.2902	.3086	.3388	
10	1.464	1.3596	.263	.0748	.0937	1.7595	1.6729
11	1.3596	1.1936	.1884	.2646	.0536	1.5903	1.3596
12	1.1789	1.1133	.1859	.2641	.2218	1.3641	1.3256
13	1.2531	1.0622	.1679	.2266	.222	1.5039	1.2126
14	1.355	.942	.1859	.2077	.2186	1.4259	1.0407
15	1.0718	.8535	.1854	.2245	.2393	1.333	1.1179
16	1.2167	.9305	.2234	.2649	.2407	1.355	1.0094
17	.9682	.8612	.2786	.2432	.2984	1.0151	1.2843
18	.3337	.4518	.3151	.3018	.3361	.4673	.2852
19	.4909	.6419	.4711	.5046	.4696	.6406	.5046
20	.6054	.6993	.6042	.6413	.5664	.793	.6915
21	.5676	.606	.5658	.5993	.5681	.7	.4299
22	.4527	.4545	.4734	.4531	.5664	.4924	.3929
23	.3216	.303	.2841	.3402	.378	.3412	.3772
24		.2464	.6859	.7484		.2844	.2273
Max	1.464	1.3596	1.5174	.7484	.5681	1.7595	1.6729
Min	.1711	.2085	.1679	.0748	.0536	.1894	.1894
Avg	.6984	.6152	.5661	.3128	.3333	.7359	.6969

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214412 / 33/11KV APTALE

Feeder No / Name : 202 / GHATGHAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1521	.1896	.515	.5935	.5556	.0432	.1896
2	.1512	.1896	.432	.5901	.5804	.0345	.1896
3	.1888	.1898	.4253	.6253	.6622		.1884
4	.227	.2277	.5121	.6783	.7189	.0344	.2263
5	.3042	.2846	.5173	.7098	.7019	.0431	.3024
6	.3602	.3791	.6048	.7579	.9063	.0432	.3784
7	.303	.3788	.7148	.9665	.8916	.0478	.5676
8	.2282	6.2369	.8754	.9724	.9651		.5653
9	.3772	.2832	.7011	.7817	.834		.4725
10	.8413	.8564	.2263	.2058	.0457		.7562
11	.7759	.6851	.1888	.189	.0385		.8066
12	.7673	.6889	.1686	.1701	.0219	.775	.8402
13	.6744	.679	.1696	.1703	.0208	.7707	.741
14	.5817	.6075	.1877	.1684	.0219	.6821	.7058
15	.5426	.6843	.1692	.188	.0229	.6866	.6714
16	.6821	.6836	.1877	.2077	.0191	.6889	.6378
17	.6668	.6035	.2254	.2243	.0154	.6927	.5928
18	.2815	.2826	.2821	.2077	.0914	.3765	.2266
19	.3784	.4162	.3772	.3364	.1517	.5287	.3746
20	.5118	.5108	.5308	.378	.1463	.567	.4677
21	.4739	.4166	.473	.449	.0955	.5297	.3961
22	.3784	.303	.3791	.3584	.0974	.3788	.3591
23	.2844	.2273	.2275	.2266	.0945	.2844	.3402
24		.1896	.5173	.5926		.0612	.1899
Max	.8413	6.2369	.8754	.9724	.9651	.775	.8402
Min	.1512	.1896	.1686	.1684	.0154	.0344	.1884
Avg	.4405	.6747	.4003	.4478	.3347	.3826	.4661

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214412 / 33/11KV APTALE

Feeder No / Name : 203 / Somatwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4915	1.3731	.5862	.6749	.8694	1.0801	1.3596
2	1.3576	1.3441	.7153	.6361	.8316	1.045	1.438
3	1.3389	1.3179	.7741	.7624	.7954	1.1077	1.3092
4	1.4092	1.4337	.7757	.9335	.9355	1.1443	1.4664
5	1.6991	1.576	.8703	1.0144	1.2161	1.31	1.6614
6	2.0004	1.8313	.9629	1.2486	1.3539	1.5379	1.9054
7	2.6295	2.5034	1.2436	1.3769	1.5732	2.0023	2.7777
8	2.974	2.5888		1.0697	1.4219	1.9222	2.856
9	1.9867	2.1457		1.0805	1.16	1.5209	2.2865
10	.7671	.835	2.6129	2.4898	2.0194	.8536	
11	.6922		2.3839	2.1185	1.7897		
12	.6481		1.9664	1.9215	1.5561		
13	.6725		1.9091	1.8275	1.4283		
14	.6111	.7529	1.8785	1.7572	1.2571		
15	.5521	.771	1.9611	1.8667	1.3735		
16	.7476	.8856	2.0739	2.0102	1.5309		
17	.8492	.9402	1.8505	1.9872	1.2855		
18	.9102	1.0818	1.1541	.8793	1.1296	1.2323	1.3845
19	1.1482	1.2624	1.3136	1.3096	1.0763	1.3338	1.6139
20	1.3378	1.265	.1307	1.4538	1.4886	1.3957	1.7008
21	1.2599	1.1895	1.1835	1.3972	.9933	1.265	1.4593
22	1.0498	.8632	.8999	1.2852	1.1937	1.173	1.2161
23	.9102	.8037	.789	1.0226	.5556	.9251	.9749
24		1.404	.6562	.945		1.108	1.3929
Max	2.974	2.5888	2.6129	2.4898	2.0194	2.0023	2.856
Min	.5521	.7529	.1307	.6361	.5556	.8536	.9749
Avg	1.2627	1.3413	1.3042	1.3778	1.2537	1.2916	1.6752

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214416 / 33 KV HIVARE

Feeder No / Name : 201 / SHIROLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362			.6562	.5624		.4344
2	.3721		.6562	.6562	.6009		.4706
3	.3681	.4344	.7274	.6562	.0145		.5121
4	.4163	.4298	.7125	.6718	.6249		.5068
5	.4207	.4706	.7202	.6958	.6722		.5544
6	.4572	.394	.8745	.78	.7202	.4344	.5544
7	.5611	.4207	1.1984	1.1069	.9282	.5731	.6584
8	.6697		1.2967	1.2803	1.1523	.5552	.7602
9	.6984	.7442	1.2803	1.2967	1.1843	.7164	.7712
10	1.5844	1.5091	.7442	.7343	.7522	1.3717	
11	1.6716	1.5123	.7796		.7343	1.4723	1.5684
12	1.5779	1.4632	.7362	.7442	.7796	1.3717	
13		1.4022	.7108	.7619		1.4299	1.5154
14	1.4998	1.3245		.7619	.7442	1.3245	1.6484
15		1.2944		.7537		1.4022	1.4899
16	1.4232	1.2186	.7442	.7537	.7265	1.4022	1.4685
17	1.4373	1.2654	.8149	.7712	.7362	1.4327	1.4373
18	.7522	.7316	.7712	.7522	.6805	.8596	
19	.7442	.7059	.7011	.6697	.6984	.7522	.7602
20	.6733	.6516	.6661	.6219	.6379	.724	.6878
21		.567	.5548	.5121		.6335	.6805
22		.4961	.5258	.4298	.5487	.5731	.6089
23	.4557	.4607	.4908	.394	.4755		.5014
24	.3506		1.4373	.7522	.5312		.4344
Max	1.6716	1.5123	1.4373	1.2967	1.1843	1.4723	1.6484
Min	.3506	.394	.4908	.394	.0145	.4344	.4344
Avg	.8248	.8748	.8163	.7484	.6907	1.0017	.8583

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214416 / 33 KV HIVARE

Feeder No / Name : 202 / HIVRE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8288		.7362	.6588	.6733		1.0105
2	.8345		.815	.6588	.6379		1.0364
3	.9783	.9145	.8063	.6588	.6335		1.2654
4	.9907	.9587	.7796	.6836	.7421		1.3279
5	1.0802	.9869	.8573	.7011	.7316		1.4243
6	1.0957	1.0822	1.0974	1.0242	1.0791	1.3245	1.5524
7	1.6091	1.4815	1.3535	1.448	1.1523	1.7747	1.8084
8	1.7236		1.1797	1.4632	1.4266	2.0062	1.9364
9	1.906	1.7309	1.3756	1.4998	1.3756	2.1872	1.9372
10	1.267	1.3672	2.4082	2.7366	2.4371	1.3112	
11	1.3717	1.4685	2.7046	2.7357	2.5453	1.4449	1.3073
12		1.4327	2.7526	2.8241	2.5301	1.4864	
13	1.4449	1.4327	2.5286	2.7161			1.379
14	1.4632	1.4373		2.5926	2.4533	1.382	1.2226
15		1.3847		2.5772		1.4685	1.2048
16	1.4632	1.2269	2.5617	2.5777	2.4234	1.5223	1.2403
17	1.5708	1.4842	2.4985	2.5	2.3329	1.576	1.4217
18	1.4842	1.448	1.4529	1.448	1.3289	1.448	
19	1.4661	1.4529	1.2971	1.2986	1.2226	1.3969	1.39
20	1.2489	1.1919	1.262	1.1584	1.134	1.2308	1.379
21		1.0974	1.0288	1.0808		1.1104	1.1393
22		.9602	.8383	.9015	.8842	.8764	.9431
23	.7209	.8718	.7293	.7291	.7122		.7712
24	.8067		.7712	.6935	.6241		.9556
Max	1.906	1.7309	2.7526	2.8241	2.5453	2.1872	1.9372
Min	.7209	.8718	.7293	.6588	.6241	.8764	.7712
Avg	1.2677	1.2706	1.4470	1.5569	1.3848	1.4717	1.3168

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214416 / 33 KV HIVARE

Feeder No / Name : 203 / BHORWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	16-MAR-17	17-MAR-17	18-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)
1			.631
2		.6859	.6173
3		.823	.6516
4		.7888	.6173
5		.823	.6859
6		.8764	.7712
7		1.5432	1.3717
8		2.0576	
9	.7468	1.989	
10	2.0576	.5487	
11	2.572	.6584	
12	2.6063		
13	2.4006		
14	2.4006		
15	2.5034		
16	1.8861	.7468	
17	2.5034	.7712	
18	.7316	.7682	
19	.695	.7362	
20	.5487	.7011	
21	.5853	.6661	
22	.5487	.5258	
23	.4854	.4908	
24		.7202	.5959
Max	2.6063	2.0576	1.3717
Min	.4854	.4908	.5959
Avg	1.5514	.8905	.7427

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214416 / 33 KV HIVARE

Feeder No / Name : 204 / GANPATI DEVSTHAN (Ozar) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383			.5175	.3772		1.1191
2	.8619		.6348	.5175	.3961		1.153
3	.8718	.8573	.6722	.4435	.4294		1.2174
4	.9156	.8916	.7095	.5544	.4338		1.2717
5	.9945	.8817	.7282	.5544	.547		1.3375
6	1.046	.9259	.7468	.6089	.6602	1.073	1.4969
7	1.3375	1.1065	.8215	.7011	.7282	1.3592	1.4918
8	1.5769		.8688	.6859	.8029	1.576	1.5927
9	1.5261	1.3904	.8326	.6859	.8215	1.6617	1.6095
10	.695	.6584	2.0748	1.9784	1.8778	.6762	
11	.7207	.4024	2.0165	2.0287	1.9448	.6348	
12	.7577	.8048	2.0538	1.8564	1.989	.6401	
13		.7762	1.9204	1.9725		.6805	.6036
14	.7682	.7316		2.0454		.6724	.5914
15		.8413		2.0287	1.8896	.7602	.6584
16	.7762	.8048	2.0538	1.873	1.8778	.7964	.7392
17	1.0082	.8779	2.0911	1.8067	1.7101	.8507	.7842
18	.9412	.9709	.7842	.7392	.7023	.8596	
19	.9313	1.0082	.7842	.7842	.7947	.823	.8048
20	.9231	.9709	.8131	.7392	.7655	.7655	.8501
21		.9335	.7316	.7577		.695	.7762
22		.8962	.6653	.695	.5914	.6722	.7316
23	.6878	.7468	.5914	.5788	.5611		.6653
24	.8619	.8048	.6348	.5175	.3772		1.0852
Max	1.5769	1.3904	2.0911	2.0454	1.989	1.6617	1.6095
Min	.6878	.4024	.5914	.4435	.3772	.6348	.5914
Avg	.9520	.8706	1.1062	1.0696	.9656	.8939	1.0290

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214416 / 33 KV HIVARE

Feeder No / Name : 205 / 11 kV KURAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2957		.6173	.6516	.6154		.3511
2	.3174		.6516	.6539	.6554		.3326
3	.3174	.2587	.6371	.6371	.6478		.3658
4	.3326	.2957	.6371	.6706	.6882		.3881
5	.3361	.2987	.8048	.7042	.8097		.4251
6	.3734	.2957	.7042	.7712	.8356	.2987	.4481
7	.4294	.3361	.9282	1.0277	.9667	.4066	.4668
8	.4805		1.0486	1.094	.9995	.4668	.5359
9	.4108	.3511	.9831	1.0608	1.094		.5175
10	1.2125	1.2803	.2987	.3696	.3326	1.3117	
11	1.3592	1.3535	.3361	.3881	.3696	1.4091	
12	1.3592	1.4449	.2743	.3511	.3921	1.3765	
13		1.4266		.3696		1.3443	1.166
14	1.3245	1.4045		.3696	.4108	1.1822	1.2452
15		1.3306		.3658		1.2308	1.2597
16	1.2548	1.1827	.3734		.4435	1.3108	1.2266
17	1.2407	1.1827	.4294	.4344	.5415	1.2631	1.2742
18	.4755	.4024	.3734	.5175	.5544	.462	
19	.4435	.3734	.3734	.4668	.5228	.4435	.4435
20	.3921	.3734	.3475	.4108	.4805	.4294	.4668
21		.3361	.3658	.3921		.3961	.4066
22		.2987	.3326	.3734	.4481	.3511	.3881
23	.3734	.2743	.3326	.3511	.3258		.3658
24	.3142		.6173	.7207	.5992		.3326
Max	1.3592	1.4449	1.0486	1.094	1.094	1.4091	1.2742
Min	.2957	.2587	.2743	.3511	.3258	.2987	.3326
Avg	.6521	.7250	.5460	.5718	.6063	.8552	.6203

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214454 / 33/11KV YENERE

Feeder No / Name : 201 / Yenere

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5975	.6161	.703	.7095	.7716	.7095	.4854
2	.5975	.6161	.6859	.6979	.7716	.7095	.4854
3	.6348	.6161	.7122	.7356	.7716	.7095	.5041
4	.6535	.6535	.7969	.703	.7888	.7545	.5544
5	.6722	.7842	.8573	.8063	.823	.7922	.6099
6	.7842	.9242	.9189	.9214	.8916	.8962	.8029
7	.9242	1.1317	1.1869	1.286	.9602	1.1016	.9522
8	.9242	.9808	1.3395	1.2717	1.286	1.0082	.9522
9	.9242	.6722	.8619	1.1904	1.1869	1.0269	.9149
10	1.4243	1.3426	1.0642	.8402	.8962	1.576	1.4752
11	1.3565	1.4083	1.0456	.9149	1.0642	1.5432	1.4586
12	1.4754	1.4251	1.0082	.9522	1.0642	1.6263	1.4083
13	1.4586	1.4419	1.0082	.9896	1.0829	1.5257	1.2929
14	1.4419	1.4586	1.0269	.8962	1.0082	1.5424	1.2944
15	1.5769	1.3916	.9335	.9522	.9522	1.3757	1.3413
16	1.5939	1.3757	.9522	1.0269	.9335	1.442	1.3565
17	1.4419	1.3245	1.0082	.9795	.9055	1.4752	1.3717
18	1.0456	.9149	1.0082	1.0269	.8779	1.0456	.8871
19	1.0269	.9896	1.0269	.9896	1.0829	.9335	.9522
20	1.0185	.9896	.9808	.9522	.9979	.8686	.9709
21	.9335	.9335	.9054	.9709	.9709	.8304	1.0642
22	.7468	.7842	.7842	.8775	.8871	.7468	.9709
23	.7282	.6908	.6602	.7468	.7392	.6283	.8501
24	.6348	.6348	.7373	.7095	.7716	1.442	.5041
Max	1.5939	1.4586	1.3395	1.286	1.286	1.6263	1.4752
Min	.5975	.6161	.6602	.6979	.7392	.6283	.4854
Avg	1.0257	1.0042	.9255	.9228	.9369	1.0962	.9775

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214454 / 33/11KV YENERE

Feeder No / Name : 202 / Tambe

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.8482	.5847	.7207	.7207	.9012	.9221
2	.8048	.8482	.5975	.7095	.7207	.9012	.9221
3	.7202	.8482	.5658	.7095	.7207	.9282	.9282
4	.8383	.8745	.6348	.7468	.7842	.9389	.9282
5	.9448	.9339	.8488	.9335	.9335	1.0288	.9448
6	1.1065	1.153	1.0562	1.1128	1.1576	1.1145	1.17
7	1.5261	1.6263	1.2323	1.2826	1.307	1.4746	1.5261
8	1.8778	1.4091	1.0082	1.0349	1.1389	1.3927	1.6221
9	1.4419	.9602	.8131	.8686	.9795	1.326	1.3272
10	.9149	.9328	1.4403	1.6057	1.5402	.7682	.8316
11	.9055	.7682	1.5729	1.6244	1.5546	.8501	.6767
12	.8779	.823	1.5565	1.4403	1.3904	.8871	.7499
13	.8326	.8507	1.3757	1.3283	1.3599	.7964	.8048
14	.7682	.7602	1.2029	1.2323	1.1883	.823	.695
15	.7947	.6878	1.0911	1.1822	1.1717	.2543	.7865
16	.8501	.7343	1.2483	1.3272	1.3123		.7682
17		.7023	.9831	.9755	1.1683	.8326	.9709
18	.9593	.7522	.9145	.9145	.9568	.9412	.9134
19	1.1203	.924	1.0903	.7207	1.0791	1.2197	1.1458
20	1.1389	1.0534	1.2883	1.1949	1.1888	1.3121	1.251
21	1.0349	1.0534	1.2197	1.1949	1.1458	1.1273	1.2323
22	.9145	.8962	1.0534	1.0164	.9877	.924	.9979
23	.6584	.7133	.8299	.7947	.724	.8131	.7316
24	.929	.8583	.6099	.7392	.7392	.9012	.9556
Max	1.8778	1.6263	1.5729	1.6244	1.5546	1.4746	1.6221
Min	.6584	.6878	.5658	.7095	.7207	.2543	.6767
Avg	.9920	.9172	1.0341	1.0588	1.0821	.9764	.9918

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214454 / 33/11KV YENERE

Feeder No / Name : 203 / BORGHAR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.128	.1109	.112	.1097	.128	.112
2	.1097	.1086	.112	.112	.1097	.1086	.0943
3	.1097	.1086	.0943	.112	.1097	.1097	.0934
4	.112	.1097	.132	.112	.1294	.128	.112
5	.1307	.1478	.1698	.1307	.1294	.1663	.1294
6	.1886	.2054	.1886	.1886	.1867	.2241	.1886
7	.2641	.2641	.2614	.2452	.2614	.2801	.2263
8	.2987	.2054	.2427	.2054	.2772	.2378	.2402
9	.2378	.1612	.1991	.12	.197	.2172	.2195
10	.197	.1387	.1791	.1949	.1907	.032	.1829
11	.2126	.1372	.1595	.197	.1595		.1753
12	.1734	.1357	.1595	.1387	.1696	.156	.1715
13	.1715	.1296	.1543	.1187	.1402	.1174	.1715
14	.1402	.1372	.1341	.1187	.1734	.1187	.1526
15	.1595	.1326	.052	.1063	.1715	.0492	.1715
16	.1387	.1638	.1387	.1227	.2454	.0848	.1715
17	.1734	.1595	.2254	.1677	.1543	.2374	.1433
18	.208	.1886	.208	.1907	.2229	.1357	.2035
19	.2926	.2835	.3012	.3045	.2896	.2686	.3292
20	.3142	.2772	.3142	.2987	.2957	.3142	.3511
21	.2772	.2587	.2587	.2614	.2772	.3142	.2987
22	.2172	.2012	.2033	.2218	.2195	.2218	.2218
23	.1629	.1646	.112	.1663	.1629	.1829	.1448
24	.1307	.1294	.1294	.112	.1494	.2926	.1307
Max	.3142	.2835	.3142	.3045	.2957	.3142	.3511
Min	.1097	.1086	.052	.1063	.1097	.032	.0934
Avg	.1896	.1698	.1767	.1691	.1888	.1794	.1848

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214456 / 33 KV SAWARGAON

Feeder No / Name : 204 / 11 KV VAISNODHAM

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2148	1.1126	.8825	1.0113	.964	.9092	1.0357
2	1.2201	1.0974	.8886	.9907	.9564	.9717	1.0334
3	1.1858	1.0364	.8886	.993	.9511	.9869	1.025
4	1.1942	1.041	.9092	1.0136	.9511	.9907	1.0265
5	1.2056	1.1111	.9686	1.0349	1.0319	1.0669	1.0989
6	1.4205	1.2559	1.1142	1.1843	1.0898	1.2353	1.3268
7	1.9867	1.6651	1.3306	1.5219	1.4152	1.7665	1.8092
8	2.5301	2.2954	1.5203	1.5676	1.6088	2.3724	2.2138
9	2.6802	2.4074	1.5013	1.576	1.5653	2.3564	2.332
10	1.5097	1.6453	2.002	1.9959	2.1315	1.5798	1.5996
11	1.1325	1.2635	2.3556	2.2443	2.2611	1.3039	1.214
12	1.275	1.246	2.4966	2.2436	2.2207	1.2422	1.2727
13	1.3557	1.243	2.3525	2.1826	2.1171	1.2018	1.2308
14	1.2856	1.0913	2.1536	2.0439	1.9989	1.0951	1.246
15	1.2544	1.0227	2.1171	1.9113	1.8679	1.0989	1.2323
16	1.2269	1.0722	2.2138	1.9441	1.864	1.2254	1.3245
17	1.2894	1.0768	2.3099	2.111	1.9121	1.307	1.3855
18	1.3496	1.3748	1.5364	1.4083	1.3527	1.5043	1.3664
19	1.3778	1.4304	1.406	1.4312	1.3375	1.4861	1.4662
20	1.6598	1.4548	1.5211	1.5493	1.4434	1.5981	1.5234
21	1.4937	1.4198	1.5318	1.4998	1.4038	1.5775	1.4761
22	1.3588	1.3504	1.3908	1.2513	1.3009	1.4891	1.4137
23	1.1866	1.1652	1.2673	1.1317	1.1035	1.3054	1.246
24	1.0707	.9625	1.1302	1.0319	.8566	1.0189	1.038
Max	2.6802	2.4074	2.4966	2.2443	2.2611	2.3724	2.332
Min	1.0707	.9625	.8825	.9907	.8566	.9092	1.025
Avg	1.4360	1.3267	1.5745	1.5364	1.4877	1.3621	1.3724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

JUNNAR[065]

BU 5843

Substation No/ Name :- 214456 / 33 KV SAWARGAON

Feeder No / Name : 205 / 11 KV BASTI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.9755	1.1286	1.0319		
2			.9701	1.0883	.9907		
3			.9518	1.0761	.9678		
4			.8977	1.0402	.9686		
5			.9343	1.0814	.9991		
6			.9587	1.2414	1.1332		
7			1.4952	1.6415	1.5516		
8			1.9441	2.1094	1.8496		
9			1.986	2.0035	1.8419		
10	2.1011	1.4975	.0091	.0381		2.0264	1.2468
11	1.9342	2.0584				2.1811	2.0226
12	2.0492	1.6095				2.2306	2.0325
13	1.9524	1.7177				1.7604	1.9037
14	1.8206	1.7558				1.6857	1.6933
15	1.7185	1.6842				1.5798	1.6659
16	1.7993	1.7421				1.7314	1.8282
17	1.8519	.7788				1.7116	1.7848
18		.0328				.0404	.0168
23		.0282	.1128	.0533			
24		.9777	1.1279	1.0059			
Max	2.1011	2.0584	1.986	2.1094	1.8496	2.2306	2.0325
Min	1.7185	.0282	.0091	.0381	.9678	.0404	.0168
Avg	1.9034	1.2621	1.0303	1.1256	1.2594	1.6608	1.5772

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214407 / 33/11KV NIRGUDSAR

Feeder No / Name : 201 / 11 KV PARGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7127	.9282	.2984	.2984	.2984	.9614	1.0608
2	.7127	.9614	.2984	.3315	.2984	.9945	1.0608
3	.7625	.9945	.3647	.3647	.3481	1.0277	1.1271
4	.8619	1.0608	.4144	.3978	.4144	1.0608	1.2431
5	.9614	1.1271	.4641	.4475	.4641	1.1271	1.326
6	1.0608	1.2266	.5304	.5967	.547	1.3094	1.3757
7	1.5912	1.5249	.663	.663	.7127	1.6409	1.7736
8	1.7238	1.7404	.6299	.5801	.6299	1.8233	1.9725
9	1.5912	1.6575	.4973	.4641	.5636	1.7736	1.8896
10	.3978	.3978	1.989	1.9227	1.989	.4807	.5304
11	.4144	.431	1.9559	1.9062	1.9393	.4641	.4973
12	.4475	.4475	1.9227	1.9559	1.8564	.431	.4807
13	.3978	.431	1.9062	1.9227	1.8564	.3812	.431
14	.3647	.431	1.8233	1.8233	1.757	.3978	.3481
15	.3647	.431	1.8564	1.7238	1.6907	.3647	.3812
16			1.8233	1.6907	1.6575	.4475	.3647
17	.4973	.431	1.7736	1.6907	1.6575	.431	.3647
18	.4641	.4475	.4641	.431	.431	.4359	.3647
19	.5636	.547	.5801	.4973	.4973	.5304	.663
20	.5636	.547	.5138	.547	.5304	.5636	.5636
21	.4807	.4641	.4973	.4641	.4641	.4973	.4973
22	.3978	.4144	.431	.3978	.3978	.431	.4144
23	.3315	.3149	.3315	.3315	.3481	.3647	.3647
24	.7127	.8951	.2984	.2984	.2984	.9945	1.0608
Max	1.7238	1.7404	1.989	1.9559	1.989	1.8233	1.9725
Min	.3315	.3149	.2984	.2984	.2984	.3647	.3481
Avg	.7120	.7762	.9303	.9061	.9020	.7889	.8398

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214407 / 33/11KV NIRGUDSAR

Feeder No / Name : 202 / 11KV NIRGUDSAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.3395	1.1603	1.004	1.1934	.3429	.4191
2	.415	.3361	1.1603	1.0322	1.1934	.3395	.415
3	.4382	.3326	1.2071	1.0486	1.2574	.3395	.4481
4	.4294	.3772	1.2717	1.0774	1.2929	.415	.4572
5	.4527	.415	1.3077	1.0774	1.3413	.4527	.4715
6	.4668	.4481	1.3904	1.2717	1.3592	.4527	.5093
7	.4668	.4481	1.7295	1.7436	1.6741	.4527	.4904
8	.4481	.4715	1.8623	1.9662	2.0553	.4715	.4763
9	.4481	.4527	1.8623	1.8623	1.9662	.4572	.4527
10	2.2377	2.0729	.4344	.4954	.4344	2.1628	2.1548
11	2.3472	2.0972	.415	.4527	.4481	2.2377	2.2611
12	2.13	2.0243	.415	.4108	.4435	2.1628	2.2119
13	2.1862	2.0241	.4108	.4108	.4298	2.0729	2.1956
14	2.0805	2.0005	.4108	.415	.4435	2.0885	2.1052
15	1.9204	2.0005	.3734	.4108	.4481	2.0972	2.0891
16	2.0005	1.9766	.415	.4108	.4435	2.1628	2.1052
17	1.8884	1.9757	.4108	.4715	.462	2.0567	1.9608
18	.415	.4527	.415	.4668	.4668	.4527	.4481
19	.4572	.4763	.4435	.4763	.4572	.5281	.5335
20	.4763	.4715	.4572	.4715	.4572	.4904	.4904
21	.4572	.4715	.4572	.4572	.4572	.4527	.4715
22	.4527	.4527	.4572	.4527	.4527	.4527	.4527
23	.4527	.4108	.415	.4191	.4191	.7545	.4527
24	.4108	.3772	1.1469	1.0364	1.1797	.381	.415
Max	2.3472	2.0972	1.8623	1.9662	2.0553	2.2377	2.2611
Min	.4108	.3326	.3734	.4108	.4191	.3395	.415
Avg	.9955	.9544	.8345	.8059	.8657	1.0116	1.0203

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214407 / 33/11KV NIRGUDSAR

Feeder No / Name : 203 / 11 KV JAWALE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3435	1.442	.2949	.3315	.3277	1.6575	1.2289
2	1.3435	1.4586	.2949	.3481	.3277	1.6741	1.2289
3	1.3927	1.5249	.3277	.3647	.3768	1.7072	1.3108
4	1.4582	1.5581	.3768	.3812	.4096	1.7238	1.5729
5	1.5238	1.6575	.4096	.3978	.4588	1.7404	1.704
6	1.5729	1.7072	.4588	.4641	.5079	1.8399	1.8351
7	1.9006	2.1382	.5735	.6464	.6882	2.2211	2.1464
8	2.0972	2.1628	.5571	.6226	.6226	2.3102	2.2119
9	2.0317	2.0645	.5898	.5571	.6554	2.2611	2.1216
10	.5571	.5571	2.6216	2.6871	2.7526	.5898	.6464
11	.5243	.5407	2.6871	2.6543	2.556	.5735	.6133
12	.5304	.5243	2.7035	2.6543	2.6216	.5571	.5967
13	.5801	.5407	2.6871	2.6216	2.5888	.6226	.5801
14	.5967	.5571	2.6216	2.5396	2.5232	.5571	.5967
15	.5967	.5571	2.556	2.4577	2.4577	.6554	.5636
16	.6133	.6226	2.4905	2.5232	2.3922	.6226	.5967
17	.6464	.5898	2.3537	2.4741	2.3371	.6226	.6226
18	.6299	.5407	.5801	.4752	.4641	.6226	.6226
19	.5801	.5571	.5967	.5407	.4973	.6554	.6226
20	.5801	.4915	.4973	.5571	.5304	.6226	.5735
21	.547	.4096	.4807	.4752	.4973	.5735	.5243
22	.4807	.3768	.4144	.4588	.4144	.5243	.4915
23	.431	.3113	.3647	.3605	.3647	.4588	.3932
24	1.3435	1.4586	.2949	.3315	.3277	1.6907	1.2289
Max	2.0972	2.1628	2.7035	2.6871	2.7526	2.3102	2.2119
Min	.431	.3113	.2949	.3315	.3277	.4588	.3932
Avg	.9959	1.0145	1.1597	1.1635	1.1542	1.1285	1.0264

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214407 / 33/11KV NIRGUDSAR

Feeder No / Name : 204 / 11 KV MENGADEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.4572	.4191	.4973	.4915	.415	.4108
2	.4527	.4904	.4287	.5304	.4973	.4527	.415
3	.4954	.5228	.5426	.5533	.6371	.4481	.4763
4	.5281	.5658	.6859	.57	.6962	.4715	.5281
5	.5788	.6097	.8322	.6036	.7865	.4954	.6036
6	.6668	.6668	.8916	.8322	.8619	.4954	.6668
7	1.0288	.8764	1.2717	1.4413	1.5089	.9526	.9145
8	.9907	1.0479	1.5746	1.7204	1.7204	1.0374	.9054
9	.9054	.9335	1.1797	1.4575	1.3765	.9054	.7922
10	1.3108	1.2803	.6268	.6535	.6401	1.704	1.5074
11	1.3927	1.3443	.5601	.5601	.5544	1.7204	1.5684
12	1.2955	1.1069	.5121	.5601	.5792	1.5684	1.4232
13	1.186	1.0031	.5487	.5175	.567	1.1717	1.2651
14	1.0402	.9259	.5228	.5175	.5853	1.3603	1.1717
15	1.0526	.8488	.462	.5175	.543	1.1873	1.0936
16	1.1203	.9374	.5068	.5853	.6219	1.3441	1.0031
17	.9259	.9374	.4706	.5853	.6335	1.1728	.9686
18	.5487	.5487	.5121	.5792	.5731	.5487	.4525
19	.5975	.6722	.5975	.7468	.6283	.6036	.6602
20	.6413	.6602	.6413	.7545	.679	.6413	.6478
21	.6036	.5716	.5658	.6602	.6413	.5658	.5716
22	.5658	.4904	.5281	.5658	.5658	.4904	.4763
23	.5281	.4527	.4904	.4715	.4904	.4572	.4527
24	.4572	.4572	.4191	.5304	.4915	.4572	.415
Max	1.3927	1.3443	1.5746	1.7204	1.7204	1.7204	1.5684
Min	.4527	.4527	.4191	.4715	.4904	.415	.4108
Avg	.8069	.7670	.6579	.7088	.7238	.8611	.8079

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214407 / 33/11KV NIRGUDSAR

Feeder No / Name : 205 / 11 KV JARKARWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.503	.5441	.4715	.4481	.4715	.4694	.4409
2	.4973	.5693	.4668	.4854	.4763	.5087	.4359
3	.5868	.6325	.5716	.4805	.5601	.5426	.6344
4	.7202	.7449	.7049	.5228	.6602	.583	.8139
5	.8478	.8619	.8676	.5281	.7811	.6173	1.0288
6	.9602	1.0174	.9431	.8002	.8488	.9015	1.0974
7	1.6244	1.7604	1.1694	1.094	1.1317	1.4251	1.7072
8	1.7368	1.8023	1.0456	.961	.9335	1.8023	1.7368
9	1.5746	1.3279	.8676	.9335		1.4251	1.5384
10	.6805	.6268		1.4746	1.5684	.6697	.7392
11	.6268	.5853	1.5364	1.5223	1.5384	.6335	.6878
12	.695	.543	1.406	1.4723	1.5023	.6447	.5487
13	.724	.4961	1.5181	1.4548	1.3117		.5121
14	.7316	.5316	1.4403	1.3441	1.3279		.5121
15	.724	.6201	1.2651	1.3441	1.3279	.6268	.4656
16	.7164	.6805	1.3441	1.2967	1.2651	.724	.5014
17	.6733	.6878	1.326	1.2631	1.2037	.8145	.6335
18	.7964	.724	.8326	.7164	.543	.8145	.7316
19	.8871	.7468	.8962	.8402	.7762	.9335	.9431
20	.9335	.8676	.9431	.9335	.9335	.7545	.7545
21	.8676	.7733	.8676	.8488	.8299	.6602	.679
22	.679	.5658	.6036	.6413	.6036	.5658	.6036
23	.5658	.4715	.5281	.4904	.4904	.4715	.4904
24	.4915	.5121	.4715	.4904	.4715	.5087	.4409
Max	1.7368	1.8023	1.5364	1.5223	1.5684	1.8023	1.7368
Min	.4915	.4715	.4668	.4481	.4715	.4694	.4359
Avg	.8268	.7789	.9603	.9328	.9372	.7771	.7782

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214407 / 33/11KV NIRGUDSAR

Feeder No / Name : 206 / 11kv BHARADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2515	.2683	.9389	1.0395	1.0562	.3018	.285
2	.2515	.285	.9389	1.073	1.0562	.3018	.285
3	.3018	.3018	.9892	1.0898	1.1065	.3353	.3353
4	.3353	.3688	1.0395	1.1065	1.1736	.3353	.4191
5	.3856	.4024	1.0898	1.1401	1.2574	.3521	.503
6	.4359	.5197	1.1401	1.2574	1.3413	.4862	.57
7	.5197	.57	1.4083	1.6766	1.7101	.503	.5868
8	.4694	.4694	1.5089	1.7436	1.8107	.4359	.4862
9	.5365	.4475	1.5089	1.6095	1.7436	.4024	.4359
10	1.8442	1.8442	.3688	.4359	.4191	1.9616	1.9784
11	1.8442	1.7604	.4024	.4191	.4024	1.9784	2.0119
12	1.7101	1.7772	.3688	.3856	.4024	2.0957	2.0119
13	1.7436	1.7604	.3856	.4024	.3856	2.0119	1.9113
14	1.7436	1.7101	.3353	.3688	.4694	2.146	1.861
15	1.7101	1.6766	.3353	.3353	.4694	1.9448	1.7101
16	1.7772	1.6766	.3353	.3185	.4359	1.9951	1.7436
17	1.6766	1.6095	.3018	.3353	.4024	1.8275	1.6766
18	.4024	.4024	.3688	.3688	.4359	.4359	.4694
19	.503	.4359	.4862	.4359	.503	.503	.503
20	.4694	.4862	.5197	.4694	.57	.5365	.5197
21	.4359	.4024	.4694	.4191	.4694	.4694	.4694
22	.3688	.3353	.3521	.3521	.3688	.4191	.3688
23	.3018	.2683	.3018	.3018	.3018	.3521	.3185
24	.2515	.285	.9389	1.0898	1.0562	.285	.285
Max	1.8442	1.8442	1.5089	1.7436	1.8107	2.146	2.0119
Min	.2515	.2683	.3018	.3018	.3018	.285	.285
Avg	.8446	.8360	.7014	.7572	.8061	.9340	.9060

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214407 / 33/11KV NIRGUDSAR

Feeder No / Name : 207 / 11KV SUYOG INDUSTRIAL
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.1097	.2263	.2195	.2829	.112	.2263
2	.2241	.0895	.1867	.2033	.2263	.0934	.2241
3	.1886	.0701	.1663	.1867	.1867	.0549	.1829
4	.1267	.0514	.1307	.1494	.1698	.0372	.1448
5	.0857	.012	.0943	.1698	.1294	.0069	.1109
6	.0097	.0103	.0309	.1307	.1509	.008	.0074
7	.0137	.0109	.0177	.1524	.0177	.0137	.0137
8	.0486	.0543	.0486	.056	.0486	.0566	.056
9	.0503	.0747	.0554	.0549	.0532	.0566	.0549
10	.0503	.0549	.056	.0537	.0514	.0526	.056
11	.0747	.0754	.0566	.0754	.0762	.056	.0566
12	.0739	.0762	.0754	.0754	.0566	.0566	.0762
13	.0754	.0566	.0754	.0566	.0747	.0747	.056
14	.0537	.0943	.0566	.0543	.0762	.056	.0532
15	.0754	.0566	.0754	.0754	.1097	.0747	.0943
16	.0934	.0924	.0943	.0934	.112	.0373	.0754
17	.056	.0754	.0297	.0754	.0509	.0754	.0244
18	.021	.0223	.028	.0166	.0267	.0211	.0137
19	.0332	.0143	.0514	.0234	.0126	.0149	.012
20	.0286	.0246	.052	.0189	.0278	.0554	.0532
21	.0549	.0532	.0554	.0492	.0532	.0526	.0526
22	.0537	.0566	.048	.1524	.0549	.0526	.052
23	.0934	.2427	.2263	.2075	.0934	.2427	.2427
24	.2587	.0934	.2263	.0754	.2772	.0943	.2263
Max	.2641	.2427	.2263	.2195	.2829	.2427	.2427
Min	.0097	.0103	.0177	.0166	.0126	.0069	.0074
Avg	.0878	.0655	.0902	.1011	.1008	.0607	.0902

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062] BU 5819

Substation No/ Name :- 214413 / 33/11 KV MANCHAR SUBSTATION

Feeder No / Name : 201 / 11 KV PIMPALGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4918	1.4575	.1867	.2054			
2		1.5432					
3			.1867	.1698	.168		
4	1.5432				.2614		
6		1.8347	.3961	.3547			
7	2.4006		.4338		.4294		
8	2.6235	2.8978		.3326	.3511		
9	1.829	2.1491	.3258	.2572	.2572	2.4691	2.1033
10	.1715	.1715	2.9721	2.2862	2.8959		.1715
11	.1372	.1029	3.0636	2.9721	2.9721	.168	.12
12	.12	.1029	2.9264	2.7435	2.3777	.1307	.1543
13	.1372	.12	2.7435	2.6063	2.5606	.12	.0514
14	.1029	.1029	2.5606	2.4387	2.4691	.1372	.1372
15	.12	.12	2.5911	2.2862	2.3777	.1294	.1543
16	.12	.1543	2.5149	2.3777	2.2862	.1294	.1543
17					2.4714	.1372	.1867
18						.1543	
19						.2743	.2218
20						.3258	.3547
21						.2915	
22						.2572	.3734
24	1.4918	1.4575	.2241	.2054	.2054		
Max	2.6235	2.8978	3.0636	2.9721	2.9721	2.4691	2.1033
Min	.1029	.1029	.1867	.1698	.168	.12	.0514
Avg	.9453	.9396	1.6250	1.4797	1.5774	.3634	.3486

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214413 / 33/11 KV MANCHAR SUBSTATION

Feeder No / Name : 202 / AVSARI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2199	.2275	1.2155	1.3489	.7392	.1296	.1296
2	.1143	.1067	.5487	.6325	.6859	.1296	.1219
3	.1067	.1067	1.0441	1.1927	1.2613	.1219	.1296
4	.3029	.3029	.4572	.5258	.6173	.1372	.1219
5	.1219	.1296	.4877	1.0898	1.4632	.1524	.16
6	.1753	.4092	1.366	.7392	1.6213	.2134	.221
7	.5873	.5461	1.1203	1.3032	2.4082	.2743	.282
8	.5725	.4742	1.5165	3.5132	3.5551	.2362	.2743
9	.5163	.3773	2.7968	3.315	2.9188	.4168	.4459
10	3.2236	2.8045	.4535	.4992	.5221	1.4175	3.6504
11	3.4142	2.8349	.2248	.1448	.2896	.9602	3.6047
12	3.1169	2.7511	.2096	.2343	.2515	3.2693	3.376
13	2.7739	2.4234	.2096	.2496	.2419	3.1473	3.0407
14	2.492	2.2329	.2419	.2419	.2648	2.934	2.7739
15	2.5378	2.2176	.2419	.2343	.2744	3.0902	2.6825
16	2.5987	1.2346	.2668	.2419	.282	2.7778	2.8425
17	1.4022	1.0822	.1296	.1219	.3146	2.6444	2.5377
18	.2515	.1143	.1372	.1372	.16	.2515	.1296
19	.1524	.1448	.1753	.1753	.16	.423	.3222
20	.2362	.2134	.2439	.2362	.2362	.5239	.4738
21	.2286	.2286	.2439	.2362	.2362	.4744	.2515
22	.2134	.2134	.2286	.2286	.221	.442	.4549
23	.1677	.1829	.1905	.1905	.1753	.1829	.1829
24	.2351	.7	1.3222	1.368	.8307	.1448	.1448
Max	3.4142	2.8349	2.7968	3.5132	3.5551	3.2693	3.6504
Min	.1067	.1067	.1296	.1219	.16	.1219	.1219
Avg	1.0734	.9191	.6280	.7583	.8221	1.0206	1.1814

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214413 / 33/11 KV MANCHAR SUBSTATION

Feeder No / Name : 203 / 11 KV MANCHAR

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0185	1.0269					
3			1.1949		1.1949		
4	1.251		1.307	1.1506			
5		1.3817					
6		1.4563	1.4712	1.6057	1.3817		
7	2.1845				2.1285		
8	2.3899	2.4646		2.3525	2.4764		
9	1.9547	1.8176	1.8861	1.8861	2.0576	2.2032	1.8861
10	1.5947	1.6461	1.7833	1.7147	1.8176		1.7147
11	1.5775	1.6461	1.7147	1.6804		1.848	1.6461
12	1.5432	1.5432	1.6461	1.8176		1.8671	1.5775
13	1.5775	1.5775	1.6461	1.6118	1.8861	1.6289	1.6118
14	1.6461	1.3717	1.4746	1.6118	1.6289	1.406	1.4746
15	1.3717	1.3717	1.4746	1.5089	1.4746	1.6057	1.5089
16	1.4746	1.4746	1.5947	1.5089	1.6118	1.643	1.6461
17					1.643	1.7147	1.7924
18						1.7147	
19						2.0576	2.1472
20						1.9719	2.1472
21						1.7147	
22						1.6804	1.7551
24	1.0642	1.0269	1.0829	1.1763	1.1949		
Max	2.3899	2.4646	1.8861	2.3525	2.4764	2.2032	2.1472
Min	1.0185	1.0269	1.0829	1.1506	1.1949	1.406	1.4746
Avg	1.5883	1.5235	1.5230	1.6354	1.708	1.7735	1.7423

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214413 / 33/11 KV MANCHAR SUBSTATION

Feeder No / Name : 206 / Tawarewadi

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.3734					
3				.4108	.5175		
4	.5228	.5228					
5			.5041				
6				.6348	.5601		
7	.7392	.8589			.7762		
8	.7842	.8215		.7392	.7392		
9	.5487	.6173	.5487	.6173	.5144	.6348	.6516
10	.5487	.5487	.5144	.5487	.5487		.5487
11	.4801	.5144	.5144	.5487	.5144		.4801
12	.5487	.5487	.4801	.5144	.5487	.5544	.4801
13	.4458	.4458	.4115	.4801	.5144	.4801	.4801
14	.3772	.5144	.4115	.5144	.5144	.4115	.4801
15	.4801	.4801	.4801	.4458	.5144	.5601	.4115
16	.5487		.4801	.4801	.5487	.5658	.4458
17					.5544	.5487	.5914
18						.4801	
19						.6859	.6722
20						.7716	.8501
21						.7716	
22						.6173	.6283
24	.4481	.4481	.4481	.4066	.5228		
Max	.7842	.8589	.5487	.7392	.7762	.7716	.8501
Min	.3772	.3734	.4115	.4066	.5144	.4115	.4115
Avg	.5295	.5578	.4793	.5284	.5635	.5902	.56

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214413 / 33/11 KV MANCHAR SUBSTATION

Feeder No / Name : 207 / 11 kv chandoli gfss

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886					
3			.1509	.1886	.2263		
4	.2641	.3018					
6			.415	.415	.3772		
7	.4527	.9431			.6036		
8	.5281	.4527		.5281	.5658		
9	.3429	.4458	.3772	.3429	.2572	.4904	.3772
10	.3429	.3772	.3429	.3429	.2572		.3429
11	.2572	.2743	.3429	.2401	.2743	.3772	.2743
12	.2572	.2401	.2572	.2058	.1715	.3018	.1543
13	.2058	.2058	.2058	.2572	.2058	.2743	.2058
14	.2058	.1715	.1715	.2058	.2058	.2401	.1715
15	.1715	.2058	.1715	.2058	.2058	.2263	.2058
16	.2058	.2058	.2058	.2058	.2058	.2263	.2572
17					.3018	.2572	.2263
18						.2572	
19						.3772	.3018
20						.4115	.4904
21						.3772	
22						.2743	.3395
24	.1886	.2263	.1886	.1886	.2263		
Max	.5281	.9431	.415	.5281	.6036	.4904	.4904
Min	.1715	.1715	.1509	.1886	.1715	.2263	.1543
Avg	.2778	.3261	.2572	.2772	.2917	.3147	.2789

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214413 / 33/11 KV MANCHAR SUBSTATION

Feeder No / Name : 208 / 11 kv Mordewadi gfss

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7922	.8299					
3			.9431	.8299	.9431		
4	.9808	.9431		.8865			
6		1.0185	1.094	1.094			
7	1.1694				1.2071		
8	1.3203	1.4335		1.3957	1.2567		
9	1.1317	1.0631	1.2003	1.286	1.2003	1.2826	1.286
10	1.166	1.166	1.286	1.2346	1.166		1.286
11	1.0288	1.0974	1.166	1.2346	1.1317	1.3203	1.2689
12	1.0631	1.2003	1.0974	1.2003	1.0631	.9808	1.2003
13	1.0631	1.0631	1.0974	1.0974	1.0288	1.1317	1.2003
14	.9431	1.0288	1.0631	1.0631	1.0288	1.1317	1.0631
15	.9945	.9945	.9602	1.0288	.9945	1.2071	1.166
16	1.0631	1.0974	1.0974	1.2003	1.0974	1.3203	1.166
17					1.0185	1.0974	1.2826
18						1.2003	
19						1.2003	1.2826
20						1.1145	1.2449
21						1.0288	
22						.9945	1.094
24	.8299	.8676	.9054	.9431	.9431		
Max	1.3203	1.4335	1.286	1.3957	1.2567	1.3203	1.286
Min	.7922	.8299	.9054	.8299	.9431	.9808	1.0631
Avg	1.042	1.0618	1.0828	1.1149	1.0830	1.1546	1.2117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214413 / 33/11 KV MANCHAR SUBSTATION

Feeder No / Name : 211 / 11 KV Gov Polytechnic
Express Feeder KV- 11 /
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0739	.0924					
3			.0924	.0924	.0924		
4	.0739	.0924		.0924	.0924		
6			.0739		.0924		
7		.0924					
8	.0739	.0739		.0924	.0924		
9	.0857	.0857	.0857	.1029	.0857	.0926	.0857
10	.0686	.0857	.0857	.1029	.0857	.1109	.1029
11	.1029	.1029	.0857		.0857	.1294	.1372
12	.1029	.1029	.0857	.1029	.0857	.1294	.1372
13	.1029	.1029	.0857	.1029	.0857	.12	.12
14	.1029	.12	.1029	.1029	.0857	.12	.1372
15	.1029	.0857	.1029	.1029	.0857	.1478	.1543
16	.0857	.0686	.1029	.0857	.0857	.1294	.12
17					.0924	.12	.1294
18						.0686	
19						.1029	.0924
20						.0857	.0924
21						.0857	
22						.0857	.0924
23			.0924				
24	.0739	.0924	.0924	.0924	.0924		.0857
Max	.1029	.12	.1029	.1029	.0924	.1478	.1543
Min	.0686	.0686	.0739	.0857	.0857	.0686	.0857
Avg	.0875	.0921	.0907	.0975	.0886	.1092	.1144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062] BU 5819

Substation No/ Name :- 214413 / 33/11 KV MANCHAR SUBSTATION

Feeder No / Name : 212 / 11kV Chimbalkar stone NON SHEDDABLE EXPRESS HV FEEDERS
 crusher Feeder KV- 11 / (CONTINUOUS PROCESS)(NO STAGGERING)
 OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0739	.0739					
2					.0739		
3			.0739	.0739			
4	.0739	.0739			.0739		
5	.0739				.0739		
6			.0739	.0739	.0739		
7	.0739	.0739					
8	.0739	.0554		.0739	.0739		
9	.0686	.0686	.0686	.0686	.0686	.0554	.2572
10	.2572	.0857	.2743	.1372	.0686		.1029
11	.3086	.2743	.2915	.2401	.0686	.3326	.0686
12	.2743	.2743	.3429	.2572	.0686	.3696	.0686
13	.3258	.1372	.3086	.2743	.0686	.2743	.0686
14	.3258	.2229	.1372	.2743	.0686	.2401	.0686
15	.3086	.2401	.2743	.3429	.0686	.3326	.0857
16	.3944	.1715	.3258	.2743	.0686	.3511	.0686
17					.0739	.2743	.1294
18						.2572	
19						.0686	.2772
20						.0686	.0739
21						.0686	
22						.0686	.0739
24	.0739	.0739	.0739	.0739	.0739		.0686
Max	.3944	.2743	.3429	.3429	.0739	.3696	.2772
Min	.0686	.0554	.0686	.0686	.0686	.0554	.0686
Avg	.1933	.1404	.2041	.1804	.0711	.2124	.1086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214413 / 33/11 KV MANCHAR SUBSTATION

Feeder No / Name : 213 / 11 KV Tapneshwar

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2134		.0189	.0189		
3			.0189	.0189	.0189		
4		.3353	.0189		.0189		
5	.2591				.0189		
6		.4268	.0377		.0377		
7					.0566		
8	.5792	.5182		.0377	.0566		
9	.4572	.4725	.0514	.0343	.0514	.3048	.4115
10	.0343	.0343	.7316	.6249	.6401		.0343
11	.0171	.0171	.6706		.6249	.0189	.0171
12	.0171	.0171	.6706	.6097		.0189	.0171
13	.0171	.0171	.6097	.5487	.4725	.0171	.0171
14	.0171	.0171	.5182	.442	.3048	.0171	.0171
15	.0171	.0171	.5487	.4115	.5182	.0189	.0171
16	.0171	.0171	.5335	.4115	.5487	.0189	.0171
17					.0189	.0171	.0189
18						.0343	
19						.0514	.0189
20						.0514	.0189
21						.0343	
22						.0343	.0189
24	.3395	.2134	.0189	.0189	.0189		
Max	.5792	.5182	.7316	.6249	.6401	.3048	.4115
Min	.0171	.0171	.0189	.0189	.0189	.0171	.0171
Avg	.1705	.1782	.3691	.2888	.2141	.0490	.052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214413 / 33/11 KV MANCHAR SUBSTATION

Feeder No / Name : 402 / 33 Kv Parag Express

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	10.7254	9.8863	8.059	8.1619	10.092	7.4246	8.7963
2	8.2305	7.5617	7.9047	8.1276	10.1989	7.6303	8.4877
3	8.4019	7.3731	9.8652	10.1898	10.0023	7.2188	8.0761
4	10.9019	9.1027	7.356	7.7161	9.3851	6.8073	7.9733
5	8.2991	7.0645	6.7044	7.356	9.2872	6.6015	7.9561
6	7.6475	6.8416	8.3797	9.728	8.9849	6.4815	8.0418
7	9.972	9.5565	6.5672	7.1502	9.0129	6.9787	7.939
8	9.4971	8.7277	7.1331	9.3215	9.2913	7.5446	7.939
9	8.5734	10.9911	9.7565	9.4994	8.8649	10.2846	10.048
10	10.3567	10.3224	10.9054	10.5625	8.9163	11.1237	11.1968
11	11.7627	10.9911	11.7112	10.4767	9.3793	11.5392	11.7455
12	11.8999	10.8196	11.8999	10.2366	8.8306	11.2437	11.677
13	11.6083	10.4767	11.917	10.3909	9.0364	10.9739	11.0768
14	11.8313	10.1166	11.3341	9.9109	9.0192	11.0254	10.9053
15	12.4657	10.3395	11.6427	10.5796	9.5508	12.5446	11.8655
16	12.3285	10.9225	12.0885	11.0597	9.5337	13.2385	11.9684
17	8.8477	9.2421	9.8423	8.4877	9.5616	13.4946	12.2543
18	8.2648	8.7792	9.808	8.4191	7.1674	12.5514	9.7565
19	7.9904	8.4705	8.9163	8.1962	7.356	11.4884	11.7449
20	8.2305	7.2017	8.4877	8.1276	7.9561	11.0768	11.4335
21	8.0933	7.8361	8.5048	8.6077	7.596	11.1111	8.1276
22	7.9904	7.4246	8.5905	8.7106	7.5103	11.5227	10.8928
23	7.7846	7.6646	8.1104	8.3848	6.9616	8.9163	8.5563
24	10.4682	9.972	10.5418	10.4773	9.3204	8.9335	8.8649
Max	12.4657	10.9911	12.0885	11.0597	10.1989	13.4946	12.2543
Min	7.6475	6.8416	6.5672	7.1502	6.9616	6.4815	7.939
Avg	9.6738	9.0702	9.4178	9.1616	8.8673	9.9065	9.8885

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214413 / 33/11 KV MANCHAR SUBSTATION

Feeder No / Name : 403 / 33 Kv Morade Food Express NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	8.4219	8.2647	6.7044	7.4074	8.2768	5.9156	6.7901
2	6.9273	6.9959	6.7044	7.4589	6.9102	7.0988	6.9445
3	6.8759	7.0473	8.2133	9.5222	6.8759	6.5844	6.6701
4	8.7174	8.4442	6.2414	7.1159	8.9312	6.2071	6.07
5	7.2188	6.8244	6.8759	7.356	8.7083	7.1159	6.1214
6	7.0302	6.3443	8.7598	10.0486	8.9141	7.2017	6.3272
7	8.5683	7.9561	6.19	6.7901	8.6974	6.9102	5.5384
8	7.8903	8.1304	5.2469	8.546	8.0024	7.2017	6.1557
9	8.059	7.8532	6.5844	9.0878	7.0473	9.8086	7.8875
10	9.105	7.5961	7.2531	9.2079	7.939	10.2412	8.3334
11	9.2935	7.7333	9.0535	8.4191	8.1448	10.8322	9.0535
12	8.642	7.9219	9.1393	7.9561	8.0419	10.455	9.0707
13	8.5906	7.8875	9.2593	7.716	7.9733	10.5624	8.8306
14	8.1619	7.8361	8.9163	7.5446	8.3162	10.4424	8.8306
15	7.9218	7.7161	8.5563	7.8532	8.3162	10.1395	8.299
16	7.8361	7.3388	9.225	7.9561	8.1619	9.0936	8.762
17	6.3615	6.4643	7.2702	6.0357	8.5671	9.4994	8.9443
18	6.07	6.4301	6.773	6.1214	6.5329	8.8134	6.8244
19	6.3615	6.31	6.5329	5.8299	6.6015	9.808	8.8243
20	6.7387	5.4698	6.773	6.9273	7.1502	9.6365	9.6119
21	6.4472	6.1043	7.0645	6.8759	6.5844	9.2422	7.2874
22	6.653	6.0528	6.8587	6.6358	6.4301	8.7449	8.4694
23	6.3786	6.07	7.013	6.7901	6.4815	6.31	6.0871
24	8.3705	7.596	6.5501	8.4574	8.7055	6.0014	7.5961
Max	9.2935	8.4442	9.2593	10.0486	8.9312	10.8322	9.6119
Min	6.07	5.4698	5.2469	5.8299	6.4301	5.9156	5.5384
Avg	7.6100	7.1828	7.4066	7.6525	7.7629	8.4944	7.6387

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214440 / 33/11KV KATAPUR

Feeder No / Name : 201 / 11 KV KATHAPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7109	3.4437	.3446	.3456	.3932	1.9517	1.7368
2	1.7109	3.3914	.3431	.3524	.3753	1.9326	1.7459
3	1.688	3.474	.3807	.3826	.3955	1.9364	1.7459
4	1.7314	3.5974	.4268	.4443	.4535	1.9494	1.749
5	1.7962	1.8884	.4984	.5057	.527	1.9966	1.8374
6	1.9159	1.9425	.5274	.6005	.5944	2.0492	3.9316
7	4.2356	2.2398	.6554	.6923	.6588	4.5643	4.6967
8	5.1835	4.8243	.589	.6322	.6243	4.7543	2.6856
9	4.91	4.7268	.5114	.5662	.5799	4.632	4.7242
10	1.4059	1.3497	4.9969	2.7694	5.1128	1.3085	1.3504
11	.3239	.3601	5.2465	5.466	2.979	.1936	.3772
12	.1791	.3147	5.2965	2.9332	2.931	.2004	.3345
13	.2786	.2907	5.1593	2.8525	2.9256	.2065	.3231
14	.2801	.2976	5.0381	2.7557	2.8487	.2088	.189
15	.3071	.2725	5.0106	2.6627	2.7869	.3399	.2782
16	.3208	.2781	5.0152	4.8438	2.726	.189	.3792
17	.3898	.3216	4.8125	4.7375	2.7122	.205	.3822
18	.3894	.3856	1.3542	1.3802	1.3047	.2073	.3796
19	.4565	.4869	.4248	.3506	.2469	.1966	.4523
20	.5175	.5426	.5228	.5205	.3262	.2492	.5674
21	.4878	.4938	.5087	.5102	.3201	.2637	.5475
22	.3867	.2477	.4523	.4622	.2583	.2439	.4542
23	.3698	.3878	.3921	.4111	.2317	.2324	.4281
24	3.4057	1.7214	.3479	.37	2.1216	3.4404	3.7956
Max	5.1835	4.8243	5.2965	5.466	5.1128	4.7543	4.7242
Min	.1791	.2477	.3431	.3456	.2317	.189	.189
Avg	1.4325	1.5533	2.0356	1.5645	1.4347	1.3938	1.4622

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214440 / 33/11KV KATAPUR

Feeder No / Name : 202 / 11 KV DEOGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4222	.4664	4.6399	4.3881	4.8338	.4405	.4603
2	.4237	.4618	4.6384	4.4216	4.8377	.4451	.4588
3	.442	.4786	4.6624	4.466	4.9832	.4527	.4816
4	.4786	.4969	5.0114	4.6715	5.1959	.4877	.5335
5	.5777	.6158	5.203	4.9109	5.6058	.5822	.6173
6	.8139	.8566	5.6062	5.6984	6.4929	.8307	1.2262
7	1.4404	1.0303	7.0165	8.0205	7.8921	1.547	1.4459
8	1.455	1.3234	7.91	8.6603	8.9407	1.3748	1.0029
9	2.7313	2.2999	7.9142	6.121	8.8161	2.5788	2.9416
10	8.8722	8.0583	.7592	.5746	.8729	9.2814	9.2761
11	8.0704	8.0999	.6021	.6638	.4908	7.1072	9.6798
12	8.626	8.3802	.4809	.6988	.4496	6.9761	9.6135
13	8.3745	8.2407	.5914	.6958	.4755	6.845	9.2429
14	8.0338	7.8258	.6735	.672	.5243	6.688	9.0725
15	7.8635	7.8513	.6737	.6653	.5136	9.8049	8.6885
16	7.9136	7.7557	.6448	.6798	.5228	6.7017	8.7193
17	7.8632	7.4485	.8116	.7499	.5456	6.5493	8.4819
18	.5895	.5876	.704	.5819	.5243	.4283	.7255
19	.9952	1.044	1.0124	.9602	.6584	.6676	1.0261
20	1.2371	1.2319	1.1515	1.2456	.8642	.8322	1.2508
21	1.1818	1.1279	1.1709	1.1838	.8612	.8291	1.1709
22	1.0195	.7133	.992	1.0029	.756	.7301	.9781
23	.7581	1.3047	1.4346	1.8153	.5838	.5792	.7472
24	.6569	3.405	4.5188	4.6853	1.8617	.6542	.6855
Max	8.8722	8.3802	7.9142	8.6603	8.9407	9.8049	9.6798
Min	.4222	.4618	.4809	.5746	.4496	.4283	.4588
Avg	3.3683	3.3794	2.8676	2.8431	2.8376	3.0589	3.6886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214440 / 33/11KV KATAPUR

Feeder No / Name : 203 / 11KV LAKHANGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.9933	3.6115	.8344	.8082	.791	4.2311	4.023
2	4.0085	3.6024	.8915	.8097	.7933	4.1876	4.0009
3	4.0139	3.5482	.8975	.8619	.8329	4.1571	3.9857
4	4.1892	3.6138	.9244	.9008	.8627	4.1709	3.9941
5	4.5138	3.7799	1.0265	.9632	.9412	4.3713	4.196
6	5.0183	4.3759	1.1187	1.153	1.1111	5.4115	7.5918
7	8.9945	5.8314	1.1713	1.2769	1.2254	9.9596	***
8	9.9309	8.8925	1.1202	1.1546	1.2639	***	6.4586
9	8.1295	6.8791	5.5068	5.9511	6.7589	8.1017	7.519
10	1.0252	.7735	***	6.6377	***	.6767	.9053
11	.7552	.9008	***	9.2433	6.2719	.455	.7674
12	.7422	.7251	***	8.6614	5.7194	.4534	.6861
13	.7373	.753	9.9718	9.0421	5.6523	.4489	.6733
14	.7472	.7152	9.6091	8.9171	6.1972	.4435	.6486
15	.624	.7499	9.1678	9.0101	6.7978	.8547	.6664
16	.7453	.7426	7.8387	8.7066	6.7825	.4412	1.1115
17	.796	.7423	8.6276	7.4597	5.3178	.4755	1.0818
18	.8859	.8863	.8299	.9555	.4633	.4816	1.11
19	1.062	.9831	1.0946	.8436	.5632	.57	1.4059
20	1.076	.5952	1.0913	1.0798	.5647	.5937	1.4072
21	.9983	.9602	1.0699	1.1294	.5441	.5525	1.3427
22	.953	.5449	.9419	.8947	.5296	.519	1.2495
23	3.948	.8703	.8356	.8451	4.1183	3.9064	3.7516
24	5.4116	2.3935	.8619	.7971	4.5443	6.1911	5.854
Max	9.9309	8.8925	10.615	9.2433	10.5342	10.186	10.1182
Min	.624	.5449	.8299	.7971	.4633	.4412	.6486
Avg	3.0541	2.3946	4.0318	3.6709	3.2992	2.9933	3.1062

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214440 / 33/11KV KATAPUR

Feeder No / Name : 204 / 11KV KATHAPUR GFFS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1437	.1875	.1875		
2			.1257	.1875	.1875		
3			.0983	.1852	.2006		
4			.1147	.2315	.2315		
5			.1981	.2743	.2743		
6			.2724	.3658	.3658		.1429
7	.1707		.3102	.5068	.4778	.2829	.1814
8	.1886	.3307	.2953	.1446	.3414	.2721	
9	.4904	.2469	.2366		.2667	.1646	.1635
10	.1383	.1052	.16		.2362	.092	.1509
11	.0842	.084	.088	.072			.08
12	.0869	.1086	.0686	.072			.068
13	.068	.0934	.0486	.0488			.0518
14	.0549	.1257	.04	.0457			.0518
15	.0549	.1715	.0373	.0027		.0975	.0457
16	.0549	.1768	.0347	.0549			.0457
17	.072	.1585	.0267	.0549			.0495
18	.1219	.2096	.0514	.0507			
19	.2012	.2418	.3155	.3269			.1183
20	.3292	.2576	.3286	.3418			.3978
21	.3121	.1928	.3018	.3437			.298
22	.2591		.2812	.2881			.2641
23	.2343	.16	.2214	.2214			.2258
24	.0461	.2031	.1536	.2031	.2031	.1326	.0692
Max	.4904	.3307	.3286	.5068	.4778	.2829	.3978
Min	.0461	.084	.0267	.0027	.1875	.092	.0457
Avg	.1649	.1791	.1647	.1914	.2702	.1736	.1414

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214440 / 33/11KV KATAPUR

Feeder No / Name : 205 / 11 KV PONDEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.4754	1.4074	1.2967		
2			1.4582	1.4232	1.3117		
3			1.5074	1.4548	1.3757		
4			1.6057	1.5181	1.4403		
5			1.7166	1.7156	1.7604		
6			1.9109	1.9919	2.0005		.3018
7	.3077		2.1822	2.2211	2.1792	.3511	.3149
8	.2683	.3048	2.2929	2.2297	2.3758	.3326	
9	.2452	.2477	2.1506		2.1664	.2452	.2591
10	2.5652	2.2809	.1433		.1886	2.5888	2.7161
11	2.4691	2.4646	.1463	.1698			2.1914
12	2.4326	2.4036	.1524	.1698			2.556
13	2.3245	2.3403	.1524	.1524			2.3967
14	2.2725	2.332	.1524	.1524			2.2245
15	2.2725	2.2611	.1715	.1715		1.949	2.1605
16	2.2028	2.13	.1524	.0549			2.2613
17	2.0873	2.0481	.1524	.1905			2.2184
18	.1905	.1595	.2096	.1905			
19	.2667	.2353	.2477	.2286			.2858
20	.2667	.2353	.2667	.2667			.3048
21	.2286	.2378	.2286	.2286			.2286
22	.1905		.1905	.2096			.2096
23	.1905	.1886	.1715	.1905			.1905
24	.1296	.1886	1.4251	1.4243	1.2967	.168	.1677
Max	2.5652	2.4646	2.2929	2.2297	2.3758	2.5888	2.7161
Min	.1296	.1595	.1433	.0549	.1886	.168	.1677
Avg	1.1617	1.2536	.8443	.8074	1.5811	.9391	1.2346

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214458 / 33/11KV RANJANI S/S

Feeder No / Name : 201 / 11 KV RAJANI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7125	.9526		1.105	.2641	
2		.7449	1.0288		1.1431	.3018	
3	.2743	.7449	1.1431	.894	1.2574	.3018	
4		.7773			1.4861	.3395	
5	.3772	.852		1.0789	1.7147	.4108	
6		1.1401			1.9052	.6036	
7	.6173	1.6907		1.7571	2.1338	.6413	
8		2.1216			2.4768	.679	
9	.4801	1.8679	2.2862	1.9266	2.3243	.6036	
10	1.9559		.3699	.381	.4854		
11	2.0222			.3429	.3734		
12	2.0222		.2774	.3429	.3734		2.0654
13	1.8138				.3292		
14	1.7814				.3361		
15	1.7814		.2312	.3429	.3361		1.8958
16	1.7814				.4108		
17	1.4864		.2928		.4435		1.7571
18	.3734			.4572	.4805		
19	.4904		.463		.5975		.4801
20	.5658				.6413		
21	.5281		.4458		.4904		.463
22	.415				.4527		
23	.3395		.3429	.3429	.3772		.3086
24	.2743	.7449	.9145	.9496	1.105	.3018	
Max	2.0222	2.1216	2.2862	1.9266	2.4768	.679	2.0654
Min	.2743	.7125	.2312	.3429	.3292	.2641	.3086
Avg	1.0200	1.1397	.7290	.8015	.9491	.4447	1.1617

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214458 / 33/11KV RANJANI S/S

Feeder No / Name : 202 / 11KV WALTI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.1548			2.4006	.3292	
2		2.1879			2.5149	.3658	
3	.3944	2.2542		2.0808	2.7816	.3292	
4		2.2874			3.0102	.3658	
5	.0446	2.3537		2.3582	3.2007	.4481	
6		2.4863			3.3913	.5975	
7	.6516	3.0167		2.8206	3.6199	.7095	
8		3.315			4.2676	.7023	
9	.6001	3.0803	3.7342	3.021	4.1533	.5544	
10	3.5471		.4007	.4191	.5175		
11	3.5803				.439		
12	3.746				.3658		3.3755
13	3.3425				.3224		
14	3.2769				.3224		
15	3.3097				.362		3.1597
16	3.6702				.362		
17	2.6558		.4316		.4344		2.8822
18	.4024				.4298		
19	.6653		.6859		.5544		.5487
20	.7468				.7095		
21	.6348		.6687		.5601		.6173
22	.5228				.4435		
23	.4481		.4801	.4191	.3696		.3772
24	.3601	2.0553	2.4006	1.8804	2.3624	.3292	
Max	3.746	3.315	3.7342	3.021	4.2676	.7095	3.3755
Min	.0446	2.0553	.4007	.4191	.3224	.3292	.3772
Avg	1.7158	2.5192	1.2574	1.8570	1.5790	.4731	1.8268

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214458 / 33/11KV RANJANI S/S

Feeder No / Name : 203 / 11KV-GANJEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0486			1.0669	.3734	
2		1.0159			1.1431	.3734	
3	.1543	1.0486		.894	1.2384	.3361	
4		1.0159			1.4289	.3361	
5	.2229	1.1271		1.0789	1.6194	.3734	
6		1.2929			1.7909	.4481	
7	.4287	1.5912		1.3409	1.9052	.5601	
8		1.7939			2.0005	.4668	
9	.2743	1.6876	1.9433	1.5413	1.9433	.4108	
10	1.8399		.2158	.2858	.3361		
11	1.873				.2614		
12	1.9393		.1541		.2987		1.722
13	1.8351				.3174		
14	1.6484				.3547		
15	1.7004		.2158		.2987		1.6605
16	1.6842				.3361		
17	1.5223		.262		.3361		1.4452
18	.3547				.3921		
19	.4481		.3617		.4481		.3961
20	.4668				.4854		
21	.4294		.31		.4481		.3793
22	.3547				.4294		
23	.3361		.2403	.2858	.3734		.2401
24	.1543	1.0486	1.2384	.8323	1.0479	.3361	
Max	1.9393	1.7939	1.9433	1.5413	2.0005	.5601	1.722
Min	.1543	1.0159	.1541	.2858	.2614	.3361	.2401
Avg	.9298	1.2670	.5490	.8941	.8458	.4014	.9739

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214458 / 33/11KV RANJANI S/S

Feeder No / Name : 204 / 11 KV THORANDALE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5658			.6859	1.2071	
2		.6036			.6859	1.2407	
3	1.406	.5658		.5549	.724	1.2071	
4		.6036			.8383	1.2407	
5	1.3717	.7545		.7398	.9907	1.3226	
6		1.094			1.1431	1.6461	
7	2.572	.5658		.971	1.2574	2.5095	
8		1.094			1.1812	2.5526	
9	2.5377	.9808	.9526	.6936	1.0288	2.3137	
10	.7545		2.7744	3.2388	2.9172		
11	.679				2.6852		
12	.679		2.651		2.6189		.5703
13	.7167				2.3266		
14	.679				2.2874		
15	.679		2.4353		2.2211		.5549
16	.7922				2.2542		
17	.8299		2.0962	2.5149	2.0553		.8015
18	.9431				.7922		
19	1.0562		.9602		1.1317		1.0288
20	1.0562				1.1317		
21	.9054		.9088		1.0185		.9088
22	.7545				.8676		
23	.6413		.6859	.724	.7167		.6516
24	1.406	.6036	.5716	.6165	.6859	1.1736	
Max	2.572	1.094	2.7744	3.2388	2.9172	2.5526	1.0288
Min	.6413	.5658	.5716	.5549	.6859	1.1736	.5549
Avg	1.0768	.7432	1.5596	1.2567	1.4269	1.6414	.7527

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214458 / 33/11KV RANJANI S/S

Feeder No / Name : 205 / WESTORN HILLS

SHEDDABLE HV(AGRICULTURE)

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0018	.0465	.096	.1144	.1047	.0892
2		.0018			.0191	.0018	
3		.0018		.0015	.0191	.0018	
4		.0018			.0191	.0018	
5		.0018		.0015	.0191	.0018	.0152
6		.0018	.1044	.061	.0862	.0932	.0907
7	.0695	.0803	.1044	.1135	.1227	.1009	.0998
8	.0312	.1077	.1006	.0785	.0351	.0803	.0884
9	.0977	.1062	.0404	.0952	.0953	.1275	.1547
10	.1138	.1143	.096	.125	.1009	.205	.1341
11	.1268	.1547	.1029	.1097	.1344	.3292	.125
12	.0018	.1105	.1112	.1082	.1428	.3307	.125
13	.1039	.1227	.1181	.1158	.1596	.3582	.1326
14	.1207	.1189	.1174	.1143	.1535	.3574	.1349
15	.1199	.128	.1257	.1402	.1131	.2088	.1394
16	.1146		.1318	.1326	.1443	.16	.1349
17	.1108		.1295	.1242	.1405	.1433	.1387
18	.1131		.1494	.1402	.1527	.1456	.109
19	.1153		.148	.1372	.1321	.144	.1076
20	.1169		.112	.1494	.0902	.1471	.1052
21	.1115		.1175	.1494	.1291	.1212	.0017
22	.1093	.1036	.1105	.1189	.1253	.1235	.109
23	.0018	.0998	.1107	.1197	.1184	.0968	.1061
24		.0993	.1166	.099	.1258	.1077	.048
Max	.1268	.1547	.1494	.1494	.1596	.3582	.1547
Min	.0018	.0018	.0404	.0015	.0191	.0018	.0017
Avg	.0929	.0754	.1097	.1060	.1039	.1455	.1042

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214458 / 33/11KV RANJANI S/S

Feeder No / Name : 206 / 11KV NAGAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2614			.2286	1.0898	
2		.2987			.2286	1.1233	
3	1.1145	.2614		.185	.2667	1.0898	
4		.2614			.3239	1.1401	
5	1.2517	.2743		.3083	.4001	1.2209	
6		.3547			.4382	1.3375	
7	1.7661	.3921		.3545	.4763	1.6787	
8		.3361			.381	1.9161	
9	2.0062	.2987	.2667	.2466	.3239	1.8107	
10	.168		2.1578	2.6482	2.2874		
11	.1867				2.1879		
12	.1867		2.1887		2.1714		.1384
13	.1867				2.0481		
14	.1867				2.0222		
15	.1867		2.0191		1.9448		.1537
16	.2054				1.8442		
17	.2054		1.7571	2.1338	1.4754		.1691
18	.2241				.2614		
19	.3921		.3445		.2987		.31
20	.3921				.3734		
21	.3921		.3272		.3921		.3104
22	.2614				.3174		
23	.2614		.2229	.2667	.2801		.2756
24	1.0631	.2614	.2477	.185	.2477	1.0898	
Max	2.0062	.3921	2.1887	2.6482	2.2874	1.9161	.3104
Min	.168	.2614	.2229	.185	.2286	1.0898	.1384
Avg	.5598	.3000	1.0591	.7910	.8841	1.3497	.2262

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214475 / 33/11kV Pimpalgaon

Feeder No / Name : 201 / 11kV Shriram

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5357	.6691	.0381	.0381	.0381	.7095	.7056
2	.5357	.7171	.0381	.0381	.0572	.6706	.7926
3	.5228	.711	.0381	.0381	.0381	.6882	.8901
4	.57	.8109	.0381	.0381	.0572	.6623	.9618
5	.7163	.8292	.0381	.0381	.0572	.9199	1.1165
6	.9199	.9222	.0389	.0381	.058	1.0418	1.2361
7	1.3672	1.3527	.0381	.0381	.0572	1.3992	1.595
8	1.592	1.5249	.0381	.0396	.0381	1.6415	1.8853
9	1.6369	1.4883	.2286	.3102	.3239	1.6423	1.7345
10	.0381	.0381	1.8572	1.9296	1.6766	.0191	.0381
11	.0381	.0381	1.9822	1.8952	1.6598	.0381	.0381
12	.0381	.0381	1.9989	1.7932	1.8183	.0381	.0381
13	.0381	.0381	2.0614	1.6865	1.9204	.0381	.0381
14	.0191	.0381	2.0775	1.6415	1.9196	.0381	.0381
15	.0191	.0572	1.9723	1.7306	1.8503	.0381	.0381
16	.0381		1.8724	1.6118	1.6545	.0381	.0381
17	.0381	.0381	1.6956	1.4578	1.5211	.0381	.0381
18	.0381	.0572	.0381	.0381	.0381	.0381	.0381
19	.0381	.0572	.0381	.0381	.0381	.0381	.0572
20	.0381	.0381	.0381	.0572	.0381	.0381	.0381
21	.0381	.0572	.0381	.0572	.0381	.0381	.0381
22	.0381	.0572	.0572	.0572	.0381	.0381	.0381
23	.1174	.0381	.0381	.0572	.1669	.1044	.1448
24	.5136	.4001	.0381	.0381	.3674	.6569	.7049
Max	1.6369	1.5249	2.0775	1.9296	1.9204	1.6423	1.8853
Min	.0191	.0381	.0381	.0381	.0381	.0191	.0381
Avg	.3952	.4355	.6807	.6127	.6446	.4422	.5117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214475 / 33/11kV Pimpalgaon

Feeder No / Name : 202 / 11kV Kaniphnath

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4198	.8916	.2942	.2995	.3033	1.0067	1.2308
2	1.3992	.99	.3041	.2988	.3011	1.2521	1.3115
3	1.387	1.0303	.1829	.301	.2889	1.2818	1.5112
4	1.3969	1.246	.2439	.2767	.2743	1.547	2.0088
5	2.6307	1.5966	.2279	.2561	1.4244	3.0773	3.1086
6	3.0102	2.0318	.2607	.2774	1.4807	3.3585	3.3882
7	3.4202	2.0325	.295	.2942	1.3009	3.3714	3.52
8	3.4354	2.1087	.3011	.2957	1.4701	3.6884	3.8539
9	3.3997	2.2322	.2964	.2858	1.4426	3.5658	3.6321
10	1.4655	.2713	2.5492	2.873	4.2044	1.7155	1.6819
11	1.5844	.2713	2.9234	3.0826	4.4162	1.7955	1.9433
12	1.9868	.3087	3.0346	3.0125	4.5016	2.3815	2.665
13	2.2634	.2889	3.0399	2.838	4.6586	2.6391	2.7641
14	2.2444	.2713	.1966	2.8091	4.6792	2.5423	2.6231
15	.5023	2.4912	5.5708	5.3521	2.4569	.237	.2104
16	.1852	2.8068	5.5715	5.4664	2.4547	.1989	.1906
17	.1646	2.9317	5.4847	5.3453	2.127	.1928	.1928
18	.186	2.8304	2.7084	2.6703	.24	.2157	.1722
19	.2522	.1334	2.7313	2.5759	.24	.282	.2553
20	.2568	2.6368	2.7428	2.5141	.2911	.301	.2576
21	.2073	2.7671	2.7572	2.4874	.2941	.3063	.2492
22	.221	2.758	2.6543	2.4539	.298	.2698	.2622
23	.1852	.7514	.3025	.2271	.224	.2172	.2339
24	1.377	.884	.2469	.25	.2424	.8848	1.089
Max	3.4354	2.9317	5.5715	5.4664	4.6792	3.6884	3.8539
Min	.1646	.1334	.1829	.2271	.224	.1928	.1722
Avg	1.4409	1.5234	1.8717	1.9393	1.6506	1.5137	1.5982

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214475 / 33/11kV Pimpalgaon

Feeder No / Name : 203 / 11kV Khadaki

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3803	.3254	3.017	2.9493	3.4804	.3269	.3727
2	.3902	.3307	3.1916	3.0102	3.4507	.3345	.3879
3	.5548	.3544	3.5848	3.2975	3.4781	.3864	.4252
4	.4451	.4016	3.6359	3.4119	3.5094	.445	.4748
5	.5739	.5754	3.8576	3.6541	3.7174	.567	.583
6	.794	.7979	4.1335	4.0566	4.135	.8939	.7826
7	.9549	.9244	4.9246	4.6815	5.074	.8916	.9015
8	.836	.8192	5.6835	5.618	5.5548	.6691	.7758
9	.599	.5655	5.4634	5.0404	5.6508	.5914	.5602
10	6.3321	5.9984	1.1012	.9237	.9359	6.0905	6.8808
11	6.6483	6.2476	.3604	.3133	.3612	3.1291	6.9608
12	6.4502	6.118	.2545	.3086	.3414		6.7208
13	6.1005	5.9762	.2721	.3223	.3383	6.4334	6.5904
14	5.9	5.8223	.3491	.3254	.2736	6.6476	6.4564
15	5.7065	5.5479	.3003	.2896	.3223	6.6804	6.387
16	5.7858	5.4382	.2851	.2972	.2835	6.435	6.4182
17	5.6028	5.2378	.2842	.3026	.3162	6.3283	6.1934
18	1.3885	1.4327	.3201	.41	.3711	1.1629	1.3191
19	.458	.4793	.4747	.5114	.4206	.4595	.5137
20	.6722	.6356	.6645	.6714	.7438	.6706	.6439
21	.6341	.6737	.6249	.6905	.6973	.7133	.6493
22	.5586	.6073	.5731	.6043	.6325	.3628	.6203
23	.4473	.458	.4633	.4946	.4702	.4557	.4908
24	.3628	1.7657	2.8509	2.8982	1.9418	.3536	.3803
Max	6.6483	6.2476	5.6835	5.618	5.6508	6.6804	6.9608
Min	.3628	.3254	.2545	.2896	.2736	.3269	.3727
Avg	2.4407	2.3972	1.9446	1.8784	1.9375	2.2186	2.6037

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214518 / 33/11 KV PIMPARKHED

Feeder No / Name : 201 / 11KV KATHAPUR ROAD

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2812	.2942	1.2757	1.4182	1.3504	.3125	.2644
2	.2911	.2873	1.275	1.3839	1.3405	.3178	.2622
3	.2934	.2911	1.2948	1.4312	1.3428	.3239	.2675
4	.3185	.3353	1.3245	1.4678	1.3931	.3437	.2934
5	.3833	.4169	1.4579	1.5714	1.515	.4412	.6615
6	.5357	.5594	1.6926	1.6865	1.7177	.57	.4992
7	.6691	.6851	1.9403	2.0797	2.1544	.6386	.5975
8	.6127	.5998	2.2786	2.2588	2.4425	.5967	.5403
9	.4252		2.2192	2.0759	2.4135	.0838	.3978
10	2.0538	2.1178	.3673	.4169	.4367	2.2436	1.9303
11	2.1498	2.1841	.2705	.2439	.2439	2.3335	2.2253
12	2.1148	2.13	.1959	.1768	.2111	2.3167	2.194
13	2.0332	2.0332	.2004	.1722	.2103	2.2276	2.1597
14	1.9319	1.8252	.2027	.1859	.2088	2.2001	2.1094
15	1.8397	1.7284	.1478	.1707	.1806	2.0561	1.9616
16	1.7688	1.7566	.1494	.1768	.1821	2.1193	
17	1.7787	1.8511	.16	.1936	.208	2.1308	2.0142
18	.3711	.1722	.1638	.4725	.218	.1821	.2858
19	.3125	.3071	.2835	.2926	.5701	.2667	.3048
20	.5388	.5327	.5312	.5083	.5182	.5312	.5327
21	.5495	.5617	.5517	.5197	.5373	.5495	.5533
22	.5258	.4885	.506	.4908	.4999	.4717	.5121
23	.3841	.4047	.4367	.3887	.423	.3628	.3475
24	.3193	1.2841	1.4015	1.3298	.3224	.2766	.2759
Max	2.1498	2.1841	2.2786	2.2588	2.4425	2.3335	2.2253
Min	.2812	.1722	.1478	.1707	.1806	.0838	.2622
Avg	.9368	.9933	.8470	.8797	.8600	.9957	.9213

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214518 / 33/11 KV PIMPARKHED

Feeder No / Name : 202 / 11KV PIMPARKHED

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.4411	1.3733	1.4495		
2			1.4419	1.3786	1.4495		
3			1.4434	1.3778	1.4464		
4			1.4388	1.3938	1.454		
5			1.4319	1.4205	1.4769		.032
6			1.435	1.4761	1.5402		
7			1.5623	1.5356	1.6179		
8			1.6042	1.5531	1.6415		
9	.5495	.5769	1.6225	1.5752	1.6293	.5807	.5601
10	1.8976	1.8884				1.9822	2.1262
11	1.9227	1.906				1.9349	2.1338
12	1.9258	1.9357				2.0881	2.1536
13	1.9563	1.8976				2.0355	2.1277
14	1.9166	1.8618				2.0439	2.1353
15	1.9494	1.7505				2.0157	2.1308
16	1.954	1.6926				2.0005	
17	1.89	1.5211				1.9921	1.4693
18	.0526						
23		.599	.6676	.5083			
24		1.3961	1.3733	1.4761			
Max	1.9563	1.9357	1.6225	1.5752	1.6415	2.0881	2.1536
Min	.0526	.5769	.6676	.5083	1.4464	.5807	.032
Avg	1.6015	1.5478	1.4056	1.3699	1.5228	1.8526	1.6521

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214518 / 33/11 KV PIMPARKHED

Feeder No / Name : 203 / 11KV CHANDOH

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2923	2.1003	.413	.3856	.3909	2.0812	2.1994
2	2.258	2.1049	.4123	.3841	.3955	2.0576	2.1072
3	2.2375	2.0767	.4207	.3948	.3948	2.0706	2.1018
4	2.2352	2.0607	.4496	.4092	.4313	2.1056	2.1536
5	2.4021	2.2009	.5235	.4999	.5053	2.223	4.2433
6	2.6772	2.415	.6828	.663	.6386	2.4775	2.524
7	3.1939	3.1596	.7773	.7659	.8002	2.9622	3.0468
8	3.3288	3.5094	.759	.7514	.7339	3.3585	3.2541
9	3.2411	3.389	1.1797	1.1622	1.2445	3.3554	3.3539
10	.4268	.4816	3.2533	3.2838	3.392	.4031	.2004
11	.3887	.3498	3.3425	3.4736	3.4088	.3254	.3506
12	.2462	.3018	3.5025	3.4598	3.4065	.2683	.3109
13	.0549	.2865	3.4667	3.3913	3.3051	.2766	.3246
14	.2393	.2789	3.1741	3.2381	3.11	.2881	.301
15	.3185	.2522	3.2701	3.0956	2.8799	.2789	.2904
16	.2896	.2187	3.2465	3.0712	2.9081	.3125	
17	.2423	.2553	3.2122	3.0163	2.7603		.2926
18	.3086	.269	.2888	.2972	.2881	.3346	.3056
19	.4786	.4755	.4801	.4565	.2835	.4809	.4656
20	.6478	.6325	.6638	.6699	.6523	.6394	.631
21	.644	.6356	.663	.6706	.6447	.6089	.6394
22	.5647	.5556	.5838	.5578	.5746	.5594	.5563
23	1.3923	.4687	.4626	.439	.4512	.4603	.7964
24	2.0736	.4191	.397	.3978	2.1323	2.1765	2.3739
Max	3.3288	3.5094	3.5025	3.4736	3.4088	3.3585	4.2433
Min	.0549	.2187	.2888	.2972	.2835	.2683	.2004
Avg	1.3409	1.2041	1.4844	1.4556	1.4889	1.3089	1.4271

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062] BU 5819

Substation No/ Name :- 214521 / 33/11KV SHINGVE

Feeder No / Name : 201 / PARGAON RD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	19-MAR-17	20-MAR-17
HR	Load (MW)	Load (MW)
7		1.5089
9	.0671	
17	1.4335	
24		.9221
Max	1.4335	1.5089
Min	.0671	.9221
Avg	.7503	1.2155

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062] BU 5819

Substation No/ Name :- 214521 / 33/11KV SHINGVE

Feeder No / Name : 202 / SHINGVE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	19-MAR-17	20-MAR-17
HR	Load (MW)	Load (MW)
7		.7655
17	.3856	
24	1.4251	.4973
Max	1.4251	.7655
Min	.3856	.4973
Avg	.9054	.6314

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062] BU 5819

Substation No/ Name :- 214521 / 33/11KV SHINGVE

Feeder No / Name : 203 / BHAGDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	19-MAR-17	20-MAR-17
HR	Load (MW)	Load (MW)
7		1.6461
9	.4115	
17	1.6787	
24		1.0227
Max	1.6787	1.6461
Min	.4115	1.0227
Avg	1.0451	1.3344

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062]

BU 5819

Substation No/ Name :- 214529 / 33/11 KV LONI

Feeder No / Name : 201 / KHADAKWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.522	.5708	.2423	.2987	.2896	.4527	.49
2	.5045	.5388	.2347	.2957	.2835	.4557	.4946
3	.5167	.5434	.2515	.3102	.2843	.4649	.5045
4	.4611	.5738	.2675	.3353	.3285	.5068	.5335
5	.5792	.6394	.3346	.3986	.3643	.6234	.6462
6	.7285	.8002	.4611	.5662	.5159	.7667	.8086
7	1.0181	1.0113	.5312	.6653	.5975	1.0075	1.0517
8	1.1591	1.2071	.5182	.599	.5632	1.3161	1.3123
9	1.1134	1.0738	.4877	.4893	.5601	1.2628	1.2628
10	.4557	.4801	.9861	1.0296	1.041	.5639	.5571
11	.4222	.3696	1.1629	1.0974	1.044	.4603	.3727
12	.413	.4092	1.1195	1.0418	1.1081	.2827	.3513
13	.3521	.4161	1.1027	.9686	1.0456		.3849
14	.3666	.3948	.9518	.9991	1.0212	.4877	.3902
15	.3544	.4039	.9419	.9427	.8787	.5274	.3864
16	.4321	.4451	.9419	.9122	.9435	.5182	.3871
17	.522	.5053	.9701	.9023	.9694	.5319	.4214
18	.5807	.5319	.4618	.4382	.4306	.5464	.4572
19	.5121	.4839	.4344	.4816	.4351	.5266	.4679
20	.5502	.5556	.5289	.5342	.5617	.5129	.5068
21	.5525	.5655	.5266	.5205	.5373	.5144	.4999
22	.5159	.4778	.4771	.4633	.4824	.4649	.4702
23	.4108	.3589	.3909	.3688	.3917	.3871	.3384
24	.554	.2439	.3216	.2957	.4557	.4664	.4847
Max	1.1591	1.2071	1.1629	1.0974	1.1081	1.3161	1.3123
Min	.3521	.2439	.2347	.2957	.2835	.2827	.3384
Avg	.5665	.5667	.6103	.6231	.6305	.5934	.5659

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

MANCHAR[062] BU 5819

Substation No/ Name :- 214529 / 33/11 KV LONI

Feeder No / Name : 202 / LONI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2782	.314	.4351	.4976	.5487	.3376	.4291
2	.2751	.3132	.4077	.4938	.5296	.3528	.4169
3	.2782	.317	.4001	.4809	.5251	.362	.4146
4	.298	.3239	.413	.5007	.5548	.3704	.4435
5	.3597	.3856	.4595	.5517	.5921	.4092	.5357
6	.4893	.5175	.5731	.6379	.6828	.5502	.6798
7	.57	.5898	.7118	.7369	.8528	.6097	.6813
8	.5274	.5434	.7903	.8451	.9282	.5662	.5982
9	.4397	.4687	.807	.8756	.9549	.4649	.4992
10	.6935	.7788	.4047	.3094	.3597	.8619	.7354
11	.7506	.8078	.2964	.2972	.3574	.8825	.7423
12	.7301	.7499	.2934	.317	.3376	.7529	.6836
13	.5975	.6569	.2652	.3544	.2782	.7034	.644
14	.5723	.6211	.2705	.346	.2736	.7202	.6211
15	.5937	.6257	.2622	.3406	.3178	.6958	.6356
16	.282	.6699	.2713	.3559	.3666	.7705	.6462
17	.6927	.7064	.3246	.3452	.365	.8261	.7552
18	.4184	.3429	.2637	.3696	.3597	.612	.3506
19	.5091	.4222	.3452	.4809	.4489	.5296	.455
20	.6562	.5586	.5959	.6287	.6455	.6234	.695
21	.6615	.5388	.5937	.6287	.6394	.6424	.6836
22	.615	.4824	.5548	.5708	.5967	.647	.6546
23	.5152	.3826	.4397	.4725	.503	.6005	.6036
24	.3368	.4466	.4954	.5441	.3818	.4931	.4801
Max	.7506	.8078	.807	.8756	.9549	.8825	.7552
Min	.2751	.3132	.2622	.2972	.2736	.3376	.3506
Avg	.5058	.5235	.4448	.4992	.5167	.5993	.5868

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214411 / 33/11KV S/S SHIROLI

Feeder No / Name : 201 / BORI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3511	.3881	1.7004	1.7772	1.6356	.4191	.4527
2	.3511	.3881	1.7004	1.7772	1.6356	.4191	.4527
3	.3511	.3881	1.7004	1.7772	1.6356	.4191	.4527
4	.4066	.462	1.7859	1.8107	1.7695	.4904	.5281
5	.4805	.5175	1.8778	1.8778	1.8564	.5281	.5415
6	.5914	.6283	2.0008	1.9839	2.0119	.6224	.6099
7	.7577	.7577	2.5149	2.713	2.7046	.7356	.7207
8		.6908	2.7664	2.8166	2.8527	.6979	.679
9	.0381	.6036	2.7349	2.6707	2.6791	.6224	.679
10	.4214	2.8509	.6036	.6413	.5144	3.2251	3.4905
11	3.4202	3.2556	.5788	.5658	.4904	3.7006	3.4705
12	3.4252	3.219	.5975	.6224	.5847	3.6458	3.3128
13	3.1493		.5788	.6602	.6287	2.5774	3.2952
14	3.0498	2.9007	.5975	.679	.6036	3.2895	3.2602
15	3.0849	3.0167	.5373	.6036	.6287	3.2579	3.2779
16	3.2023	2.9504	.5975	.6161	.679	3.1901	1.5249
17	2.9835	2.8673	.6224		.6413	3.2895	2.9321
18	.6036	.5716	.6478	.6979	.6979	.6602	.6097
19	.679	.7167	.7811	.7545	.6287	.7545	.679
20	.7545	.679	.811	.7655	.7621	.7922	.7468
21	.7167	.679	.7733	.6908	.6478	.7733	.6979
22	.679	.6224	.6602	.5847	.6097	.6979	.5847
23	.4763	.5093	.547	.5093	.4715		.4854
24	.3511	.3881	1.7004	2.4751	1.6356	.4191	.4527
Max	3.4252	3.2556	2.7664	2.8166	2.8527	3.7006	3.4905
Min	.0381	.3881	.5373	.5093	.4715	.4191	.4527
Avg	1.3185	1.3066	1.2257	1.3074	1.2085	1.5316	1.4140

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214411 / 33/11KV S/S SHIROLI

Feeder No / Name : 202 / SALWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9522	.9709	.5135	.6602	.4664	.9335	1.1088
2	.9522	.9709	.5335	.5268	.4664	.9335	1.1088
3	.9522	.9709	.5335	.5335	.4664	.9335	1.1088
4	1.0349	1.0719	.6081	.6081	.5868	1.0719	1.1827
5	1.1088	1.1643	.6882	.6882	.5216	1.2803	1.2437
6	1.2752	1.3717	.78	.7969	.5573	1.4449	1.448
7	1.8267	1.828	.9134	.8589	2.146	2.0058	1.9163
8	2.0416	1.9313	.8954	.8238	.8505	2.0376	2.0022
9	1.7878	1.7528	.7293	.7362	.6539	1.8427	1.8551
10	.7796	.7282	2.0332	2.0332	2.226	.7442	.7973
11	.7712	.7796	2.3388	2.0858	2.3663	.4923	.8238
12	.7537	.7362	2.2786	2.0332	2.2786	.7265	.7973
13	.7537	.7619	2.1735	2.0157	2.0332	.7087	.7796
14	.7282	.7619	2.1033	2.0508	1.9631	.7392	.788
15	.6859	.8413	2.0683	2.0332	2.0157	.7522	.7701
16	.7282	.8413	2.0858	2.1209	2.0157	.7343	.788
17	.788	.8779	1.9806		1.8755	.7011	.8869
18	.7888	.8238	.583	.703	.6299	.8145	.8238
19	.7716	.8238	.7202	.7202	.6316	.7011	.7888
20	.7888	.7888	.6859	.6952	.68	.6796	.7373
21	.7537	.7042	.6371	.5937	.578	.6241	.6154
22	.6081	.6154	.5624	.578	.5418	.5639	.5335
23	.5418	.5213	.5556	.5639	.6468	.4923	.4527
24	.9522	.9709	.5135	.5268	.4664	.9335	1.1088
Max	2.0416	1.9313	2.3388	2.1209	2.3663	2.0376	2.0022
Min	.5418	.5213	.5135	.5268	.4664	.4923	.4527
Avg	.9635	.9837	1.1464	1.0864	1.1527	.9538	1.0194

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214411 / 33/11KV S/S SHIROLI

Feeder No / Name : 203 / AURANGPUR PARGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.2987	.9069	.8697	.9069	.3326	.3326
2	.3734	.2987	.9069	.8697	.9069	.3326	.2846
3	.3734	.2987	.9069	.8697	.9069	.3326	.3326
4	.4108	.4108	.9831	.9282	.9503	.3696	.3696
5	.4854	.4904	1.0814	.9922	1.0159	.4481	.4435
6	.5788	.6036	1.1934	1.1142	1.1105	.5415	.5415
7	.6722	.7356	1.6907	1.6244	1.7101	.6908	.6722
8	.5788	.6468	2.037	1.704	1.7072	.6161	.5304
9	.5068	.5068	.3841	1.6194	1.5844	.5014	.3898
10	1.7204	1.7204	.4251	.5175	.5121	1.7814	1.873
11	1.9393	1.873	.4887	.543		2.0564	1.7204
12	1.989	1.704	.4706	.4706	.4298	1.8679	1.8515
13	1.8515	1.7444	.4525	.4835	.4075	1.9006	1.7166
14	1.8679	1.7328	.394	.4119	.4656	1.9433	1.7166
15	1.8187	1.6644	.3761	.4525	.4382	1.9006	1.7328
16	1.704	1.6842	.3439	.4525	.4835	1.9334	1.6842
17	1.6876	1.6549	.3045		.4298	1.7901	1.6804
18	.4344	.394	.3582	.3982	.4344	.3189	.4252
19	.439	.5121	.4572	.5175	.5121	.4525	.4572
20	.4668	.5601	.5304	.4854	.5544	.499	.499
21	.4435	.4854	.499	.462	.499	.4251	.4805
22	.3511	.4066	.4251	.4435	.4435	.3841	.4066
23	.3174	.3547	.3511	.3734	.3511	.3326	.3361
24	.3734	.2987	.9069	.8697	.8855	.3326	.3326
Max	1.989	1.873	2.037	1.704	1.7101	2.0564	1.873
Min	.3174	.2987	.3045	.3734	.3511	.3189	.2846
Avg	.9065	.8783	.7031	.7597	.7672	.9202	.8671

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214411 / 33/11KV S/S SHIROLI

Feeder No / Name : 204 / 11 KV Malwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.2641	1.2963	1.2616	1.2963	.3511	.3696
2	.3018	.2641	1.2963	1.2616	1.2963	.3511	.3696
3	.3018	.2641	1.3272	1.2616	1.2963	.3511	.3696
4	.3395	.3361	1.4582	1.3435	1.3603	.4108	.4066
5	.4527	.4481	1.6095	1.4091	1.4586	.5228	.4481
6	.5415	.5601	1.6933	1.491	1.5746	.6413	.6413
7	.679	.6161	2.1879	2.0957	2.2805	.7733	.679
8	.5228	.4715	2.2211	2.2447	2.5591	.6602	.6224
9	.4001	.381	2.1445	2.1285	2.2045	.547	.4527
10	2.7526	2.5425	.381	.362	.4527	2.5149	2.8045
11	2.769	2.652	.3772	.3239	.4527	.3772	2.774
12	2.7515	2.4905	.3018	.3772	.3961	2.6406	2.9492
13	2.5724	2.3403	.3018	.3772	.4108	2.5194	2.774
14	2.4383	2.332	.3048	.381	.3734	2.5194	2.774
15	2.5724	2.2725	.3163	.3772	.4527	2.5194	2.774
16	2.556	2.2996	.3584	.3961	.4527	2.5774	2.774
17	2.3805	2.2085	.3961		.5093	2.536	2.6452
18	.3772	.4763	.4191	.4715	.5847	.4854	.3961
19	.4904	.4572	.6287	.6722	.547	.6036	.547
20	.5658	.4715	.7049	.679	.6224	.6287	.679
21	.5281	.3961	.5144	.6224	.5525	.5716	.6224
22	.4572	.381	.4527	.5281	.4763	.5144	.5658
23	.3239	.3048	.3429	.4715	.3961		.4527
24	.3018	.2641	1.2963	1.2616	1.3123	.3511	.3696
Max	2.769	2.652	2.2211	2.2447	2.5591	2.6406	2.9492
Min	.3018	.2641	.3018	.3239	.3734	.3511	.3696
Avg	1.1533	1.0623	.9304	.9477	.9716	1.1290	1.2609

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214411 / 33/11KV S/S SHIROLI

Feeder No / Name : 205 / 11 KV Nimgaon Sava

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1214	2.0081	.3521	.3978	.3953	1.9511	1.9403
2	2.1214	2.0081	.3521	.3978	.4001	1.9511	1.9403
3	2.1376	2.0081	.3521	.3978	.4001	2.0271	1.9403
4	2.2996	2.2283	.5182	.5304	.4858	2.21	2.1548
5	2.4777	2.4905	.9221	.7293	.6299	2.4082	2.3777
6	2.652	2.9338	.9221	.8785	.9116	2.7006	2.7161
7	3.2114	3.5305	.9175	.9116	.9556	3.3642	3.3432
8	3.4899	3.4244	.6882	.7287	.8139	3.2421	3.1276
9	3.2968	3.0567	.5441	.4778	.6706	2.8959	3.1741
10	.4214	.3612	3.5848	3.6054	3.4015	.4531	.3963
11	.3081	.3658	3.8668	3.6761	3.6528	.4816	.3715
12	.3521	.333	3.8504	3.4818	3.4919	.3663	.4001
13	.3384	.3628	3.7571	3.6328	3.2545	.3658	.3963
14	.282	.3338	3.5789	3.6328	3.2396	.3612	.3963
15	.3429	.3246	.3353	3.6328	3.1834	.381	.4012
16	.3715	.3601	3.5789	3.5896	3.1504	.4062	.4268
17	.3841	.3812	3.4332		3.0018	.4115	.4967
18	.3841	.3628	.3923	.3894	.3426	.4778	.4582
19	.5335	.5944	.6171	.6019	.4934	.5744	.5858
20	.6882	.7362	.7926	.7202	.7145	.7827	.7522
21	.6401	.6882	.7343	.7116	.6687	.6836	.7202
22	.5468	.6009	.6009	.5937	.5569	.5573	.6325
23	.4428	.4531	.4531	.4843	.4841	.4816	.4641
24	2.1214	2.0081	.3841	.4144	.3906	1.9511	1.9403
Max	3.4899	3.5305	3.8668	3.6761	3.6528	3.3642	3.3432
Min	.282	.3246	.3353	.3894	.3426	.3612	.3715
Avg	1.3319	1.3314	1.4803	1.5051	1.4871	1.3119	1.3147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214411 / 33/11KV S/S SHIROLI

Feeder No / Name : 206 / 11kV Jadhavwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3881	.3696	1.0202	1.065	.9339	.3881	.3921
2	.3881	.3696	1.0202	1.065	.9339	.3881	.3921
3	.3881	.3696	1.0562	1.065	.9339	.3921	.3921
4	.4668	.4854	1.1568	1.2071	1.0395	.5228	.4481
5	.5975	.6535	1.3748	1.4083	1.2689	.6722	.6413
6	.811	.7922	1.6991	1.6804	1.4746	.8299	.8299
7	.8962	.8488	2.1195	2.1704	2.1948	.8402	.8299
8	.6838	.6099	2.323	2.2634	2.34	.6099	.6379
9	.4706	.5175	2.2085	1.8785	1.917	.567	.3988
10	2.7328	2.7999	.4835	.4607	.543	2.6852	3.0849
11	2.6852	2.9172	.3801	.3681	.5552	.4294	3.0178
12	2.8502	2.8669	.3366	.4031	.4784	2.0957	3.0514
13	2.7018	2.5888	.3814	.3988	.4681	2.9005	3.0178
14	2.7328	2.4531	.3681		.4733	2.8502	2.934
15	2.6825	2.4366	.4075	.3467	.4854	1.442	2.7018
16	2.6658	2.3102	.4681	.4656	.5493	2.7018	2.7199
17	2.6322	2.3371	.5083		.4961	2.6852	2.7681
18	.4382	.4287	.5895	.5493	.5375	.4854	.4239
19	.7392	.6767	.8962	.7947	.6767	.6626	.5544
20	.8589	.8589	.7316	.9522	.8686	.7842	.8962
21	.8215	.7095	.8131	.8029	.8686	.7468	.8215
22	.5601	.5788	.6099	.6468	.5544	.5729	.5788
23	.4108	.3921	.499	.4251	.4066	.4294	.4108
24	.3761	.3696	.9722		.9339	.3881	.3921
Max	2.8502	2.9172	2.323	2.2634	2.34	2.9005	3.0849
Min	.3761	.3696	.3366	.3467	.4066	.3881	.3921
Avg	1.2908	1.2392	.9343	.9722	.9138	1.1279	1.3473

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214411 / 33/11KV S/S SHIROLI

Feeder No / Name : 207 / SHIROLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0722	1.0082	.2801	.2241	.2652	1.078	1.2018
2	1.0722	1.0082	.2801	.2241	.2957	1.078	1.2018
3	1.0722	1.0082	.2801	.2241	.2957	1.078	1.2018
4	1.1203	1.1336	.3361	.2614	.3142	1.1873	1.3283
5	1.1843	1.2308	.3772	.3206	.3547	1.3123	1.3283
6	1.475	1.3279	.4338	.3961	.3921	1.5043	1.5546
7	1.7976	1.6842	.5228	.4904	.5658	1.917	1.9757
8	1.9271	1.8785	.4527	.5121	.462	2.1538	2.0083
9	1.7764	1.7124	.3841	.394	.3801	1.9433	1.8673
10	.3109	.3292	2.0805	2.2024	2.17	.4572	.3142
11	.3326	.3109	2.1445	2.2996	2.1538	.2801	.3658
12	.3696	.2926	2.2348	2.2186	2.1605	.4024	.3841
13	.362	.2481	2.1925	2.1605	2.0241	.4163	.394
14	.3258	.2896	2.1445	2.1125	2.0805	.4656	.394
15	.3142	.2896	2.0399	2.1214	2.0557	.4298	.3681
16	.3841	.3258	1.945	2.2024	2.0805	.4607	.4119
17	.3511	.3511	2.0567		2.0729	.4887	.4119
18	.4024	.3982	.3077	.362	.3982	.4477	.4119
19	.3921	.4207	.3475	.4251	.4572	.4207	.4163
20	.3734	.4108	.4024	.4435	.6838	.462	.4435
21	.3142	.3881	.3292	.4251	.3881	.4066	.3881
22	.2587	.3658	.3142	.3881	.3326	.3511	.3696
23	.2033	.3511	.2427	.3326	.3174	.2801	.3361
24	1.0722	1.0082	.2801	.2241	.2957	1.078	.3361
Max	1.9271	1.8785	2.2348	2.2996	2.17	2.1538	2.0083
Min	.2033	.2481	.2427	.2241	.2652	.2801	.3142
Avg	.7610	.7405	.9337	.9115	.9582	.8375	.8089

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214411 / 33/11KV S/S SHIROLI

Feeder No / Name : 208 / SULTANPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5624	.4843	.1097	.1267	.1075	.6562	.6405
2	.5624	.4843	.1097	.1267	.1075	.6562	.6405
3	.5624	.4902	.1097	.1267	.1075	.6562	.6405
4	.5937	.5535	.0716	.1478	.1097	.759	.6874
5	.6562	.6009	.1341	.1663	.128	.7907	.759
6	.679	.7116	.1867	.1867	.1494	.9172	.8539
7	.8697	.9442	.2987	.2801	.2614	1.1822	.9962
8	1.0883	.9646	.2241	.2195	.2772	1.1523	1.0494
9	1.0031	.9297	.2012	.2229	.1448	1.0242	1.0105
10	.1478	.1402	1.1069	1.2018	1.3443	.1478	.0924
11	.1791	.1949	1.1873	1.2176	1.3927	.2956	.128
12	.1791	.2126	1.1561	1.186	1.3441	.1433	.1267
13	.1829	.208	1.142	1.1873	1.25	.1433	.1267
14	.197	.1844	1.0822	1.2342	1.2037	.1417	.1417
15	.2507	.1949	1.0974	1.2334	1.1728	.1595	.1417
16	.2835	.1949	1.1363	1.2334	1.1248	.2149	.1829
17	.2715	.2303	1.1561		1.0753	.2743	.181
18	.2195	.2328	.1646	.1646	.1433	.3045	.1791
19	.2195	.2353	.2172	.2218	.1829	.2353	.1829
20	.2218	.2012	.181	.2054	.2378	.2218	.1848
21	.2033	.2012	.1629	.1663	.1646	.2218	.168
22	.2012	.1448	.1629	.1448	.1478	.1829	.1478
23	.1433	.128	.1294	.1097	.1307	.1478	.1307
24	.5624	.4843	.1097	.1267	.1075	.6562	.6405
Max	1.0883	.9646	1.1873	1.2342	1.3927	1.1822	1.0494
Min	.1433	.128	.0716	.1097	.1075	.1417	.0924
Avg	.4183	.3896	.4849	.4885	.5173	.4702	.4180

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214417 / 33/11 KV S/S GMRT KHODAD

Feeder No / Name : 201 / SOUTH -RANJANI-

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0724	.0739	.0754	.0754	.0754	.0754	.0754
2	.0754	.0739	.0754	.0754	.017	.0754	.0754
3	.0754	.0724	.0754	.0754	.0754	.0754	.0754
4	.0189	.0754	.0754	.0754	.0739	.0754	.0754
5	.0189	.0754	.0754	.0754	.0724	.0754	.0754
6	.0754	.0754	.0754	.0754	.0754	.0754	.0754
7	.0754	.0739	.0754	.0754	.0747	.0754	.0754
8	.0732	.0701	.0754	.0754	.0762	.0754	.0754
9	.0732	.0686	.0754	1.5844	.0762	.0754	.0754
10	.0739	.0754	.0754	.0724	.0754	.0754	.0754
11	.0754	.0754		.0754	.0754	.0754	.0754
12	.0724	.0754	.0754	.0716	.0754	.0754	.0754
13	.0754	.0754	.0754	.0701	.0754	.0754	.0754
14	.0724	.0754	.0754	.0762	.0754	.0762	.0754
15	.0754	.0754		.0739	.0754	.0762	.0754
16	.0716	.0754	.0754	.0762	.0754	.0754	.0754
17	.0747	.0754	.0754	.0754	.0754	.0754	.0754
18	.0747	.0754	.0754	.0724	.0754	.0747	.0754
19	.0724	.0754	.0754	.0754	.0754	.0762	.0754
20	.0754	.0754	.0754	.0754	.0754	.0754	.0754
21	.0716	.0754	.0754	.0754	.0754	.0754	.0754
22	.0693	.0754	.0754	.0701	.0754	.0754	.0754
23	.0724	.0754	.0754	.0724	.0754	.0754	.0754
24	.0754	.0747	.0754	.0754	.0747	.0754	.0747
Max	.0754	.0754	.0754	1.5844	.0762	.0762	.0754
Min	.0189	.0686	.0754	.0701	.017	.0747	.0747
Avg	.0692	.0746	.0754	.1373	.0728	.0755	.0754

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214417 / 33/11 KV S/S GMRT KHODAD

Feeder No / Name : 202 / WEST -NARAYANGAON-

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566		.0566	.0543	.056	.0566
2	.0566	.0566	.0566	.0566	.0543	.056	.0566
3	.0566	.0566	.0566	.0566	.056	.056	.0566
4	.0566	.0526	.056	.0566	.0554	.056	.0566
5	.0566	.0543	.0566	.0566	.0566	.056	.056
6	.0566	.0554	.056	.0566	.0543	.056	.056
7	.0566	.0566	.056	.0566	.0514	.056	.056
8	.0554	.0543	.056	.0566	.0566	.056	.056
9	.056	.056	.056	.0566	.0566	.056	.0566
10	.056	.056	.0566	.0514	.0566	.0566	.0566
11	.0526	.056	.0566	.0566	.0566	.0566	.0566
12	.0514	.056	.0566	.0543	.0566	.056	.0566
13	.0537	.056	.0566	.0566	.0566	.056	.0566
14	.0566	.056	.0566	.0566	.0566	.0566	.0566
15	.0543	.056		.0543	.0566	.056	.0566
16	.0549	.056	.0566	.0514	.0566	.0566	.0566
17	.0566	.0554	.0566	.0543	.056	.0566	.0566
18	.0554	.056	.0566	.0514	.056	.0566	.0566
19	.0566	.056	.0566	.0554	.056	.0566	.0566
20	.0566	.056	.0566	.0566	.056	.056	.0566
21	.0543	.056	.0566	.0554	.056	.056	.0566
22	.0566	.0566	.0566	.0554	.056	.056	.0566
23	.0554	.056	.0566	.0566	.056	.0566	.0566
24	.0566	.0543	.056	.0566	.0566	.056	.0566
Max	.0566	.0566	.0566	.0566	.0566	.0566	.0566
Min	.0514	.0526	.056	.0514	.0514	.056	.056
Avg	.0556	.0557	.0564	.0555	.0558	.0562	.0565

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214417 / 33/11 KV S/S GMRT KHODAD

Feeder No / Name : 203 / EAST -BORI-

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.056	.056	.0566	.0566	.0566	.056
2	.0566	.0543	.056	.0566	.0566	.0566	.056
3	.0566	.0543	.056	.0566	.0566	.0566	.056
4	.0566	.0554	.056	.0566	.0514	.0566	.0566
5	.0566	.0554	.056	.0566	.0543	.0566	.056
6	.0566	.056	.056	.0566	.0554	.0566	.0566
7	.0566	.0572	.056	.0566	.0566	.0566	.0566
8	.0549	.0572	.056	.0566	.0566	.0566	.0566
9	.0549	.0543	.056	.0566	.0566	.0566	.0566
10	.0554	.0554	.0566	.0566	.0566	.0566	.0566
11	.0543	.0554	.0566	.0554	.0566	.056	.0566
12	.0566	.0554	.0566	.0526	.0566	.0549	.0566
13	.0554	.0554	.0566	.0554	.0566	.056	.0566
14	.0566	.0554	.0566	.0566	.0566	.0572	.0566
15	.0566	.0554		.0566	.0566	.0572	.0566
16	.0566	.0554	.0566	.0537	.0566	.0572	.0566
17	.0537	.0554	.0566	.0566	.0566	.0566	.0566
18	.0566	.056	.0566	.052	.0566	.0566	.0566
19	.0566	.0554	.0566	.0514	.0566	.056	.0566
20	.0566	.0554	.0566	.0566	.0566	.056	.0566
21	.0554	.056	.0566	.0543	.0566	.056	.0566
22	.0566	.056	.0566	.0566	.0566	.056	.0566
23	.0566	.056	.0514	.0554	.0566	.0566	.0566
24	.0566	.0566	.056	.0566	.0543	.0566	.0566
Max	.0566	.0572	.0566	.0566	.0566	.0572	.0566
Min	.0537	.0543	.0514	.0514	.0514	.0549	.056
Avg	.0561	.0556	.0561	.0557	.0561	.0565	.0565

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214417 / 33/11 KV S/S GMRT KHODAD

Feeder No / Name : 205 / GMRT LOCAL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1867	.1886	.1886	.1867	.1867	.1886
2	.1886	.1867	.1886	.1886	.1867	.1867	.1886
3	.1886	.1867	.1829	.1886	.1867	.1867	.1886
4	.1886	.1867	.1886	.1886	.1867	.1867	.1886
5	.1886	.1867	.1886	.1886	.1867	.1867	.1905
6	.1886	.1867	.1886	.1886	.1867	.1867	.1905
7	.1886	.1867	.1886	.1886	.1867	.1867	.1905
8	.1886	.1867	.1886	.1886	.1867	.1867	.1867
9	.1886	.1867	.1886	.1886	.1867	.1867	.1867
10	.1886	.1886	.1886	.1867	.1867	.1886	.1886
11	.1867	.1886		.1867	.1867	.1867	.1886
12	.1867	.1886	.1886	.1867	.1867	.1886	.1886
13	.1867	.1886	.1886	.1867	.1867	.1886	.1886
14	.1867	.1886	.1886	.1867	.1867	.1867	.1886
15	.1867	.1886		.1867	.1867	.1886	.1886
16	.1867	.1886	.1886	.1867	.1867	.1886	.1886
17	.1867	.1867	.1886	.1867	.1867	.1886	.1886
18	.1867	.1886	.1886	.1867	.1867	.1886	.1886
19	.1867	.1886	.1886	.1867	.1867	.1886	.1886
20	.1867	.1867	.1886	.1867	.1867	.1886	.1886
21	.1867	.1867	.1886	.1867	.1867	.1886	.1886
22	.1867	.1886	.1886	.1867	.1867	.1886	.1886
23	.1867	.1867	.1886	.1867	.1867	.1867	.1886
24	.1886	.1867	.1867	.1886	.1867	.1867	.1867
Max	.1886	.1886	.1886	.1886	.1867	.1886	.1905
Min	.1867	.1867	.1829	.1867	.1867	.1867	.1867
Avg	.1876	.1875	.1883	.1875	.1867	.1876	.1886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214434 / 33 KV KANDALI

Feeder No / Name : 201 / MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1663	.1886	.1353	.1677	.2452	.2058	.1886
2	.1494	.1619	.1269	.1638	.2012	.2058	.1753
3	.1663	.1781	.1189	.16	.2012	.218	.2035
4	.181	.1781	.1562	.176	.181	.2294	.1823
5	.1991	.2105	.1677	.1781	.1928	.208	.176
6	.2195	.2155	.1886	.2058	.213	.2343	.1875
7	.2126	.2507	.2534	.2254	.2572	.2683	.2865
8	.2835	.2743	.3292	.3174	.4338	.3326	.3584
9	.3361	.176	.4382	.3174	.3961	.4382	.4338
10	.4763	.1898	.5658	.5658	.6224	.5415	.5093
11	.7655	.2214	.6908	.6722	.5847	.5281	.6602
12	.6908	.1932	.7468	.7095	.6908	.6413	.7282
13	.6468	.2829	.6468	.6224	.5847	.4904	.6161
14	.7023	.2035	.6878	.5658	.6348	.5792	.7095
15	.7392	.1581	.7421	.6979	.5975	.5304	.7655
16	.679	.16	.7133	.6036	.6097	.5975	.6224
17	.6099	.1852	.7059	.3772	.4954	.4854	.547
18	.3961	.1718	.499	.4527	.3921	.3547	.4481
19	.3961	.1802	.4527	.4572	.4001	.4108	.3511
20	.3361	.2058	.4338	.3761	.4191	.3395	.3547
21	.2829	.2103	.3018	.3292	.2829	.3018	.362
22	.2452	.1543	.2641	.2829	.2641	.2452	.2427
23	.2229	.1715	.156	.2353	.1823	.3641	.2126
24	.1433	.2058	.1353	.1886	.2402	.2254	.2103
Max	.7655	.2829	.7468	.7095	.6908	.6413	.7655
Min	.1433	.1543	.1189	.16	.181	.2058	.1753
Avg	.3853	.1970	.4024	.377	.3884	.3740	.3972

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214434 / 33 KV KANDALI

Feeder No / Name : 202 / Nagadwadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2587	.2427	.743	.8642	1.0317	.2427	.2427
2	.2801	.2427	.7579	.8951	.8619	.2427	.2614
3	.2987	.2614	.7827	.9061	.9065	.2829	.2829
4	.3395	.2801	.8128	.9217	.6371	.3395	.2829
5	.3584	.3395	.8579	1.0311	.8535	.3772	.3206
6	.3961	.415	1.1092	1.4403	1.0494	.4527	.415
7	.4668	.4668	1.9271	1.9826	1.9433	.4251	.4715
8	.4668	.4481	2.2024	2.3525	2.3967	.4668	.3734
9	.3511	.2494	1.781	1.8976	1.9685	.3109	.3077
10	1.5339	2.1032	.2427	.2561	.2926	2.119	2.3685
11	2.2283	2.1285	.2195	.2743	.2534	2.2405	2.2186
12	2.0005	2.0645	.2587	.2402	.2402	2.1445	2.2245
13	2.0645	1.8976	.2378	.2195	.2195	2.1506	2.0005
14	2.0005	1.8027	.2378	.2218	.2534	1.9997	1.866
15	1.9364	1.7236	.2402	.2195	.2715	1.6667	1.866
16	1.9204	2.0119	.2587	.2353	.2926	1.9766	2.0165
17	1.7901	1.5971	.2743	.2804	.2957	1.8976	
18	.2926	.2804	.3045	.2743	.3077	.2481	
19	.3881	.362	.3696	.3881	.3881	.3077	.3881
20	.3734	.3511	.3511	.3547	.3921	.3734	.3511
21	.3511	.3326	.3511	.3326	.3696	.3511	.3326
22	.3077	.3142	.3511	.3142	.2801	.2987	
23	.2801	.2772	.2402	.2772	.2614	.2801	
24	.2587	.2614	.7676	.9061	.8905	.2641	.2614
Max	2.2283	2.1285	2.2024	2.3525	2.3967	2.2405	2.3685
Min	.2587	.2427	.2195	.2195	.2195	.2427	.2427
Avg	.8726	.8522	.6533	.7119	.6940	.8941	.9426

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214434 / 33 KV KANDALI

Feeder No / Name : 203 / kandali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.0953	.128	.0953	.112	.1143	.1143
2	.0943	.0953	.112	.0953	.112	.1143	.0953
3	.0943	.1143	.1132	.1143	.0943	.1143	.1143
4	.1334	.1143	.128	.1143	.1132	.1334	.1334
5	.1715	.1524	.128	.1334	.132	.1509	.1524
6	.2096	.1905	.2096	.1715	.1494	.2075	.2096
7	.1886	.2286	.2033	.2096	.1886	.2096	.2286
8	.1494	.1698	.1867	.1494	.168	.1698	.1698
9	.1267	.132	.1307	.1509	.1448	.1132	.1463
10	.1097	.132	.0924	.1132	.128	.112	.1307
11	.1097	.1254	.0924	.1307	.1097	.1307	.1086
12	.0934	.1267	.0914	.1132	.0914	.0934	.1132
13	.0934	.1075	.0934	.0924	.1097	.0739	.112
14	.0934	.1075	.0934		.0914	.0724	.1109
15	.0934	.124	.0924	.1097	.0914	.0914	.1267
16	.1109	.1254	.112	.0924	.1086	.1063	.1097
17	.1075	.1214	.0934	.1029	.0934	.0924	.124
18	.1097	.1052	.1063	.1075	.128	.1227	.1097
19	.2075	.1848	.1848	.2218	.1886	.1867	.2241
20	.2075	.1848	.2054	.2241	.1886	.1867	.2241
21	.1698	.1848	.168	.1867	.1698	.1698	.1867
22	.1509	.1478	.1509	.1494	.1494	.1494	.168
23	.132	.1294	.132	.1307	.132	.1307	.1509
24	.112	.1132	.128	.0953	.1132	.1143	.1143
Max	.2096	.2286	.2096	.2241	.1886	.2096	.2286
Min	.0934	.0953	.0914	.0924	.0914	.0724	.0953
Avg	.1325	.1380	.1323	.1350	.1295	.1317	.1449

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214434 / 33 KV KANDALI

Feeder No / Name : 204 / Vaishakhed

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.4372	.0358	.056	.0362	.4372	.4428
2	.3658	.421	.0358	.056	.0362	.4372	.4374
3	.3704	.4372	.0362	.056	.0358	.4534	.4131
4	.3749	.4696	.0362	.056	.0362	.4588	.427
5	.3749	.4858	.0366	.056	.0366	.4588	.4428
6	.3749	.5079	.0343	.056	.0366	.4915	.4481
7	.5121	.5571	.0373	.0566	.0377	.6062	.5079
8	.5601	.5921	.037	.0566	.0377	.6478	.5761
9	.5668	.6009	.0366	.0566	.0554	.5601	.5693
10	.0343	.0347	.6882	.6249	.7202	.0366	.0366
11	.0526	.0358	.6882	.6401	.6802	.0373	.0373
12	.0537	.0373	.6062	.639	.6718	.0377	.0373
13	.037	.0366	.6316	.5668	.6802	.0358	.0373
14	.037	.0362	.6316	.5992	.6241	.0351	.0373
15	.0373	.0362	.6722	.6718	.6241	.0278	.0373
16	.0373	.0366	.6964	.7045	.6562	.0267	.0373
17	.0354	.0373	.6478	.578	.6249	.0351	.056
18	.037	.0351	.0554	.0566	.0358	.0549	.037
19	.037	.0362	.0554	.0377	.037	.056	.056
20	.037	.0362	.056	.0373	.0343	.0366	.056
21	.0362	.0362	.0554	.037	.0366	.0366	.056
22	.0362	.0354	.0554	.0366	.0362	.0358	.0554
23	.0362	.0358	.0554	.0366	.0366	.0358	.0373
24	.3658	.4372	.0358	.056	.0373	.4534	.4428
Max	.5668	.6009	.6964	.7045	.7202	.6478	.5761
Min	.0343	.0347	.0343	.0366	.0343	.0267	.0366
Avg	.1990	.2272	.2482	.2428	.2452	.2305	.2217

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214456 / 33 KV SAWARGAON

Feeder No / Name : 201 / Wadgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6415	.5765	.2543	.2683	.2543	.5144	.6516
2	.6415	.5765	.2543	.285	.2713	.5144	.6516
3	.6588	.5935	.2713	.2883	.2713	.5144	.6516
4	.6588	.6241	.2743	.3052	.3086	.5316	.6516
5	.6762	.6588	.2915	.3391	.3258	.5487	.6762
6	.7108	.6588	.3258	.373	.3601	.7011	.7362
7	.9496	.8916	.4075	.4075	.4115	.9431	.9709
8	1.153	1.1401	.3982	.3801	.3189	1.1191	1.0343
9	1.1191	1.17	.3696	.3696	.3292	.9724	1.0004
10	.4527		1.3094	1.0364	1.0608	.2614	.2328
11	.3772	.2743	1.3245	1.2407	1.0277	.2012	.2427
12	.3734	.2328	1.2125	1.1768	1.0486	.2035	.2534
13	.3547	.2328	1.278	1.0364	1.0486	.1844	.2743
14	.3361	.2353	1.1961	1.0159	1.004	.1781	.2926
15	.3361	.2715	1.0814	.9614	.9393	.2012	.2743
16	.2926	.3547	1.1305	1.0059	1.0322	.2427	.2715
17	.3142	.3547	1.1271	.9667	.9393	.2835	.3109
18	.2957	.3772	.2957	.2987	.1677	.3395	.3475
19	.4066	.3511	.3189	.4207	.3292	.4294	.4024
20	.3506	.3439	.3681	.3898	.3403	.4854	.3898
21	.3086	.3403	.3258	.3467	.298	.3801	.3429
22	.2713	.2947	.3077	.3052	.2601	.333	.3086
23	.2321	.2543	.2947	.2713	.192	.2652	.2458
24	.6344	.5765	.2543	.2683	.2458	.5144	.6859
Max	1.153	1.17	1.3245	1.2407	1.0608	1.1191	1.0343
Min	.2321	.2328	.2543	.2683	.1677	.1781	.2328
Avg	.5227	.4950	.6113	.5732	.5327	.4526	.4958

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214456 / 33 KV SAWARGAON

Feeder No / Name : 202 / Malganga

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1267	.1052	.373	.2774	.2572	.168	.1463
2	.1267	.1052	.39	.3121	.2743	.168	.1463
3	.1448	.1227	.39	.333	.2915	.168	.1463
4	.1372	.1387	.407	.3506	.2915	.168	.1463
5	.1543	.156	.4458	.3681	.3258	.1867	.1663
6	.1715	.1907	.463	.4031	.3601	.2353	.1991
7	.3077	.2427	.631	.5434	.5258	.3077	.2561
8	.2534	.2254	.6516	.6135	.6613	.2328	.2427
9	.1829	.1772	.5868	.5365	.5506	.1829	.1494
10	.664	.5182	.2054	.128	.1663	.663	.5636
11	.547	.5506	.1867	.1417	.1509	.5898	.6554
12	.5344	.5376	.1294	.124	.1509	.5668	.5281
13	.5079	.506	.112	.1524	.1509	.5376	.5218
14	.4641	.4372	.1097	.1334	.0152	.5344	.5281
15	.4694	.4161		.1334	.0191	.5182	.4801
16	.5304	.4428	.1307	.1267	.1494	.502	.3932
17	.5079	.4359	.1509	.1494	.1698	.506	.4424
18	.128	.1478	.132	.168	.1886	.2075	.1663
19	.1829	.2033	.1867	.2033	.2452	.2195	.1848
20	.1791	.2241	.2241	.2172	.2641	.2561	.2218
21	.1991	.2241	.2241	.2012	.2452	.2353	.2033
22	.1629	.1867	.181	.1829	.2075	.1991	.2195
23	.124	.168	.1448	.1433	.2075	.1417	.1646
24	.128	.1052	.373	.2774	.2572	.168	.1402
Max	.664	.5506	.6516	.6135	.6613	.663	.6554
Min	.124	.1052	.1097	.124	.0152	.1417	.1402
Avg	.2889	.2736	.2969	.2592	.2552	.3193	.2922

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214456 / 33 KV SAWARGAON

Feeder No / Name : 203 / Sawargaon-Khilarwadi
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.1698	.3401	.4096	.3479	.1698	.1509
2	.1097	.1698	.3725	.426	.3479	.1698	.1509
3	.0686	.1886	.3887	.4588	.3795	.1698	.1509
4	.128	.1905	.421	.4915	.4111	.1698	.1509
5	.1494	.2286	.421	.5079	.4586	.1886	.1698
6	.168	.2286	.4534	.5407	.506	.2263	.2452
7	.1886	.2667	.639	.7127	.6882	.3048	.2477
8	.2075	.2667	.6062	.7842	.8029	.2286	.2263
9	.2075	.2263	.7287	.6478	.6642	.2075	.2075
10	.8259	.8097	.0171	.1509	.132	.8259	.7865
11	.7459	.8421	.0171	.1448	.0133	.8192	.8642
12	.8259	.7522	.0133	.132	.0133	.8322	.7655
13	.8097	.7274	.0133	.132	.0114	.7343	.679
14	.7362	.6722	.1132	.1509	.1132	.7202	.68
15	.8642	.68	.1132	.1509	.1698	.759	.679
16	.8482	.6874	.132	.1715	.1698	.759	.6483
17	.8002	.6062	.1509	.1524	.1698	.6405	.6401
18	.1886	.1698	.1509	.1886	.1886	.1509	.1478
19	.2096	.2075	.1886	.2452	.2263	.1886	.1663
20	.2286	.2263	.2075	.2452	.2452	.2452	.2641
21	.2263	.2263	.2075	.2641	.2641	.2452	.2641
22	.1886	.1886	.1886	.2452	.2096	.1886	.1867
23	.1886	.1698	.1509	.2075	.1905	.1509	.1646
24	.1097	.1698	.3401	.3768	.3321	.1698	.1494
Max	.8642	.8421	.7287	.7842	.8029	.8322	.8642
Min	.0686	.1698	.0133	.132	.0114	.1509	.1478
Avg	.3806	.3780	.2656	.3307	.2940	.3860	.3661

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214459 / 33/11KV S/S UMBRAJ

Feeder No / Name : 201 / UMBRAJ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1663	.3437	.3113	.3277	.1612	.168
2	.1494	.1663	.3395	.3113	.3277	.1612	.1848
3	.1494	.1663	.3549	.3113	.3277	.1612	.2012
4	.1494	.168	.3906	.3149	.3277	.1829	.2012
5	.2241	.1867	.4218	.3481	.5801	.2012	.2378
6	.2829	.2452	.4902	.4024	.7712	.2614	.2587
7	.2829	.3018	.6401	.6539	.7712	.3018	.3326
8	.3206	.3174	.8192	.7701	.9054	.3018	.3174
9	.2033	.2561	.9012	.8356	.8356	.2241	.2218
10	.828	.9393	.1848	.1772	.2378	.8905	.9667
11	.9122	.9555	.2195	.1772	.2561	.9061	.9831
12	.8745	.9555	.2012	.1829	.2561	.9488	.8453
13	.852	.8642	.2012	.1646	.2561	.8962	.8951
14	.7701	.8162	.2012	.1448	.2353	.8962	.8886
15	.7701	.8162	.2195	.1448	.2172	.8642	.8817
16	.8421	.8223	.181	.1478	.1991	.8421	.9326
17	.8097	.7522	.2328		.2328	.8848	.8817
18	.2896	.1991	.2507	.2195	.2561	.2195	.2534
19	.3174	.2353	.2353	.2378	.2561	.2402	.2896
20	.3142	.2743	.2865	.3361	.3142	.2957	.3881
21	.2957	.2772	.0191	.2957	.3142	.2987	.3326
22	.2587	.2172	.0191	.2957	.2353	.2614	.2427
23	.1848	.197	.1463	.168	.1791	.2054	.2054
24	.1494	.1663	.3281	.3113	.3277	.9488	.8817
Max	.9122	.9555	.9012	.8356	.9054	.9488	.9831
Min	.1494	.1663	.0191	.1448	.1791	.1612	.168
Avg	.4325	.4359	.3178	.3158	.3728	.4815	.4997

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214459 / 33/11KV S/S UMBRAJ

Feeder No / Name : 202 / MAHALAXMI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.362	.7682	.7432	.759	.3189	.3921
2	.362	.362	.7682	.7432	.759	.3189	.3696
3	.362	.3658	.7842	.7522	.759	.3403	.3696
4	.362	.3658	.8259	.7611	.759	.362	.3658
5	.5175	.4024	.8907	.7773	.9831	.499	.3841
6	.7468	.5175	1.0486	.9116	1.2742	.6535	.5487
7	.7468	.6535	1.3599	1.2239	1.2742	.7468	.7392
8	.6653	.6219	1.6078	1.4251	1.5089	.6099	.7842
9	.5853	.5853	1.5912	1.4737	1.5074	.5487	.6535
10	1.5935	1.6644	.4334	.4382	.5552	1.5623	1.6221
11	1.7604	1.6842	.4334	.4382	.5731	1.4998	1.8187
12	1.7328	1.7166	.4733	.5731	.5973	1.692	1.8564
13	1.7204	1.6032	.4031	.5316	.5973	1.6288	
14	1.5729	1.5043	.4382	.5373	.5792	1.6484	1.6598
15	1.6549	1.6356	.5083	.5373	.5552	1.7284	1.7939
16	1.7004	1.6356	.5316	.6089	.5194	1.5546	1.6956
17	1.668	1.5708	.567		.5373	1.5708	1.7974
18	.5083	.5138	.5959	.6556	.591	.6878	.6661
19	.5853	.591	.6485	.6556	.6516	.6584	.6556
20	.6335	.6089	.6379	.6584	.6154	.6584	.6335
21	.6154	.5731	.5784	.5487	.6154	.5853	.6335
22	.5194	.4252	.463	.5487	.5138	.5359	.5487
23	.394	.3544	.3366	.439	.3988	.462	.462
24	.362	.362	.7682	.7432	.759	.333	.3841
Max	1.7604	1.7166	1.6078	1.4737	1.5089	1.7284	1.8564
Min	.362	.3544	.3366	.4382	.3988	.3189	.3658
Avg	.9055	.8616	.7276	.7272	.7601	.8835	.9058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214459 / 33/11KV S/S UMBRAJ

Feeder No / Name : 203 / BELA PRADESHIK

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3163	.0903	.3113	.3005	.3277	.3077	.1147
2	.3163	.0903	.3113	.3005	.3277	.3077	.3077
3	.3005	.0926	.3315	.3077	.3113	.3239	.3077
4	.3005	.0926	.3315	.3077	.3113	.3277	.3113
5	.3005	.0949	.3315	.3113	.3113	.3277	.3113
6	.3163	.0949	.3149	.3149	.3315	.3113	.3315
7	.3163	.0972	.5548	.3149	.3315	.3277	.3315
8	.5182	.096	.3149	.3077	.3353	.3277	.3315
9	.502	.08	.3113	.3077	.3315	.3113	.3149
10	.4843	.1147	.3041	.4843	.4902	.3163	.3149
11	.502	.0995	.4801	.4843	.5121	.3005	.5197
12	.5243	.0995	.502	.4843	.4961	.3041	.5365
13	.5304	.0983	.502	.4961	.4902	.3041	.5138
14	.5138	.0983	.502	.4961	.4902	.3239	.5138
15	.5304	.0983	.502	.4961	.4961	.3077	.5316
16	.3185	.116	.3041	.0937	.3185	.3113	.3258
17	.1006	.116	.0949		.1017	.0983	.1017
18	.0926	.1147	.1107	.0937	.0995	.0983	.0937
19	.0036	.013	.0038	.0149	.0118	.0191	.0124
20	.004	.0124	.0032	.0149	.0126	.0191	.0139
21	.0038	.0124	.0036	.0137	.0274	.0124	.0141
22	.104	.0819	.036	.0903	.0122	.012	.1134
23	.0926	.0995	.0857	.0903	.0995	.0114	.0983
24	.0926	.0903	.0972	.0949	.2031	.3041	.5365
Max	.5304	.116	.5548	.4961	.5121	.3277	.5365
Min	.0036	.0124	.0032	.0137	.0118	.0114	.0124
Avg	.2952	.0872	.2769	.2705	.2825	.2340	.2876

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214459 / 33/11KV S/S UMBRAJ

Feeder No / Name : 204 / Sondewadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7811	.7701	.421	.4485	.5418	.852	.8318
2	.7788	.7586	.4188	.4317	.535	.836	.8569
3	.7537	.7693	.4327	.4302	.5236	.8543	.8564
4	.7621	.7798	.4573	.4317	.5304	.8944	.8764
5	.8032	.8152	.5197	.4846	.5891	.9713	.9099
6	1.1172	1.0288	.6329	.5674	.7018	1.1494	.9998
7	1.1979	1.198	.7613	.7015	.7384	1.3245	1.4517
8	1.4289	1.4282	.7137	.5792	.721	1.5448	1.7246
9	1.3744	1.5109	.5133	.433	.6938	1.4701	1.6313
10	.5946	.6339	1.3685	1.7132	1.7686	.64	.6318
11	.4474	.4824	1.7611	1.8039	1.8001	.502	.4782
12	.4717	.4946	1.7566	1.6655	1.8043	.494	.5236
13	.4801	.4786	1.7883	1.5379	1.7245	.4924	.532
14	.4634	.4794	1.7291	1.6238	1.6721	.4878	.5254
15	.4685	.4959	1.6873	1.6146	1.567	.4847	.5239
16	.5079	.5312	1.6671	1.5577	1.6084	.4969	.5051
17	.5838	.566	1.6636	.8733	1.6739	.5426	.5601
18	.6859	.5746	.7742	.5175	.7339	.5702	.6307
19	.7598	.6195	.595	.5805	.7568	.6013	.6741
20	.7687	.7512	.7666	.7643	.8078	.6851	.8808
21	.7266	.7413	.7228	.7743	.775	.6935	.8513
22	.6901	.6676	.6538	.7704	.6991	.6763	.8219
23	.5793	.5419	.5536	.6477	.6284	.6013	.6836
24	.7636	.5917	.4683	.5194	.7308	.8383	.8595
Max	1.4289	1.5109	1.7883	1.8039	1.8043	1.5448	1.7246
Min	.4474	.4786	.4188	.4302	.5236	.4847	.4782
Avg	.7495	.7379	.9511	.8947	1.0136	.7793	.8259

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214459 / 33/11KV S/S UMBRAJ

Feeder No / Name : 205 / UMBRESHWAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.816	.8512	2.3944	2.4809	2.5979	.7719	.8619
2	.816	.8512	2.3982	2.5114	2.601	.7499	.8718
3	.8145	.8497	2.403	2.5129	2.524	.7826	.8768
4	.8153	.8642	2.437	2.5049	2.5111	.812	.8825
5	.8451	.8794	2.4861	2.5552	2.5735	.8497	.9131
6	.92	.8943	2.6726	2.665	2.8951	.8829	.9511
7	.9261	.9343	3.0673	3.1369	3.1101	.892	.9823
8	.921	.9945	3.434	3.4168	3.4101	.8927	.9218
9	.8989	.9715	3.6214	3.5623	3.552	.9286	.9698
10	3.5616	3.2242	1.3177	1.2995	1.3991	3.6451	3.7289
11	3.8432	3.5997	.8565	.8628	.8589	3.9422	4.0821
12	3.8603	3.6431	.8528	.8616	.8245	4.2388	4.097
13	3.8752	3.7342	.8634	.8848	.8154	4.2705	4.0558
14	3.5339	3.7633	.8512	.8872	.8162	4.2124	3.9563
15	3.3383	3.6561	.8383	.891	.8238	4.2019	3.9428
16	3.5779	3.6736	.8398	.8527	.8268	4.2164	4.0009
17	3.5989	2.2216	.8466	.5601	.8824	4.1566	3.9514
18	1.5434	1.3885	1.0562	.8619	.9025	1.4251	1.349
19	.9021	.9725	1.0812	.9046	.9661	.9122	.9198
20	.9481	.9722	1.0929	.9709	.9496	.937	.9463
21	.9191	.9355	1.0746	.9478	.9225	.9358	.9133
22	.8657	.9043	1.0276	.9356	.8707	.952	.9119
23	.8429	.8536	.804	.8524	.8034	.8756	.8714
24	.8145	1.4814	2.4261	2.519	1.8656	.8097	2.5434
Max	3.8752	3.7633	3.6214	3.5623	3.552	4.2705	4.097
Min	.8145	.8497	.804	.5601	.8034	.7499	.8619
Avg	1.8249	1.7964	1.6976	1.6849	1.6793	1.9706	2.0209

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214467 / 33 KV PARGAON MANGRUL

Feeder No / Name : 201 / Pimpri Kawal

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4066	.4298	2.0081	1.7604	1.3763	.4755	.5121
2	.4435	.3982	1.9845	1.8023	1.3763	.4755	.5544
3	.4435	.362	2.0243	1.8679	1.4746	.4344	.5544
4	.4481	.4344	2.0809	1.8785	1.4746	.439	.5601
5	.4481	.5121	2.1136	1.989	1.5074	.499	.6535
6	.5601	.6117	2.1956	1.9989	1.8351	.6283	.6908
7	.6722	.5359	2.5309	2.6155	2.2939	.7207	.7095
8	.5601	.5359	2.6558	2.6235	2.2455	.7316	.7023
9	.4961	.5194	2.5749	2.5911	2.2455	.591	.6219
10	2.6216	2.6558	.5068	.5792	.3189	2.7526	2.9007
11	3.0001	.578	.4961	.5373	.4961	2.8509	2.9165
12	2.9492		.5083	.5373	.5083	2.8837	2.9165
13	2.9329	2.6397	.4748	.4854	.4973	2.8016	2.9165
14	2.7362	2.753	.4801	.5373	.5201	2.7692	2.8673
15	2.7199	2.6566	.4908	.5731	.4733	2.7044	2.7854
16	2.7044	2.7692	.5493	.5731	.5258	2.6397	2.6566
17	2.6566	2.8841	.5426	.5144	.6379	2.7199	2.5934
18	.4382	.5375	.5548	.5853	.6379	.3856	.4207
19	.5373	.6089	.6268	.5853	.6878	.5068	.5973
20	.591	.6697	.6154	.5853	.6733	.5853	.6154
21	.5373	.6335	.6219	.5853	.6447	.5487	.5853
22	.5014	.4477	.4706	.5487	.5847	.5068	.543
23	.4477	.4344	.4706	.439	.5316	.4755	.543
24	.4024	.4477	2.0243	1.6446	1.3443	.4887	.4887
Max	3.0001	2.8841	2.6558	2.6235	2.2939	2.8837	2.9165
Min	.4024	.362	.4706	.439	.3189	.3856	.4207
Avg	1.2606	1.0894	1.2334	1.1849	1.0380	1.2756	1.3294

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214467 / 33 KV PARGAON MANGRUL

Feeder No / Name : 202 / Mangrul

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.4428	.1463	.1829	.1494	.4161	.4374
2	.4801	.427	.1663	.2195	.1494	.4321	.4801
3	.5243	.4161	.1494	.2587	.1494	.4372	.4801
4	.5243	.4001	.1494	.2987	.1867	.4752	.4915
5	.5243	.4372	.1698	.2987	.1867	.5182	.5243
6	.6226	.4915	.2641	.3395	.2614	.5898	.5801
7	.7293	.7865	.3018	.2987	.3361	.852	.8785
8	.7865	.8583	.2587	.3475	.3361	.9122	.9393
9	.8223	.8749	.2378	.2896	.2534	.9282	.9231
10	.1478	.2012	.9878	1.1012	.9488	.2402	.2218
11	.1448	.2507	1.0364	1.0242	1.0402	.2402	.1791
12	.1448	.2279	1.0402	1.0242	1.0242	.2561	.1791
13	.1629	.1991	1.0155	.9488	.9804	.2561	.1772
14	.1949	.197	.9842	.9602	.8539	.2561	.1928
15	.2103	.197	.9646	.9602	.9061		.1928
16	.2229	.1402	1.012	.9602	.9172	.2353	.2347
17	.2543	.1829	.2454	.9374	.8907	.3292	.2515
18	.2896	.1387	.2454	.2195	.2427	.3155	.2279
19	.3142	.2587	.2896	.2561	.3077	.3258	.2926
20	.2801	.3142	.2926	.2561	.2957	.3696	.3142
21	.2054	.2427	.3174	.2561	.3292	.2926	.3326
22	.1663	.1848	.181	.1829	.2195	.2561	.2402
23	.1097	.1448	.181	.1463	.1629	.2012	.2402
24	.4801	.3795	.1448	.1448	.1494	.4111	.4374
Max	.8223	.8749	1.0402	1.1012	1.0402	.9282	.9393
Min	.1097	.1387	.1448	.1448	.1494	.2012	.1772
Avg	.3676	.3497	.4492	.4963	.4699	.4150	.3937

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214467 / 33 KV PARGAON MANGRUL

Feeder No / Name : 203 / Pargaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6722	.7655	.1848	.2241	.1848	.759	.7907
2	.7042	.7432	.168	.2241	.1848	.7432	.7907
3	.7042	.7116	.168	.2957	.2218	.7522	.8322
4	.7209	.7682	.1698	.2957	.2241	.7842	.8745
5	.7865	.7968	.2075	.2957	.2614	.8065	.9069
6	.7865	.9069	.3395	.3395	.3361	.8642	.9503
7	.852	1.0562	.3174	.4338	.4066	1.1012	1.004
8	.852	1.0883	.3109	.3475	.4024	1.186	1.1363
9	.8025	1.0059	.3258	.2957	.3582	.953	1.0753
10	.1791	.2686	1.1544	1.2003	1.2346	.2353	.2561
11	.2378	.298	1.2334	1.0936	1.2186	.2686	.2481
12	.2172	.298	1.1702	1.0936	1.1873	.3258	.2481
13	.2103	.3045	1.142	1.0494	1.1111	.2715	.2303
14	.2126	.2534	1.1561	1.0883	1.1248	.2507	.2629
15	.2103	.3012	1.186	1.0883	1.1405	.2328	.2601
16	.2401	.298	1.1702	1.0883	.9998	.2279	.2774
17	.2486	.3189	.2454	1.0883	1.1043	.2481	.2801
18	.2172	.298		.2926	.2149	.2515	.2058
19	.1848	.2926	.2715	.3326	.2561	.2534	.2378
20	.2218	.3109	.2926	.3326	.2957	.2378	.2402
21	.2402	.2561	.3174	.1829	.2218	.2378	.2427
22	.1848	.2195	.1663	.2195	.2218	.2218	.2427
23	.1663	.1991	.1663	.1829	.1663	.2033	.2402
24	.6722	.6874	.1829	.1646	.1848	.759	.7655
Max	.852	1.0883	1.2334	1.2003	1.2346	1.186	1.1363
Min	.1663	.1991	.1663	.1646	.1663	.2033	.2058
Avg	.4385	.5186	.5238	.5521	.5526	.5073	.5250

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214467 / 33 KV PARGAON MANGRUL

Feeder No / Name : 204 / AURANGPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.3584	2.2268	2.5076	2.0462	.9144	.9541
2	.415	.3395	2.201	2.6757	2.0843	.9092	.9751
3	.4527	.3395	1.6522	2.7684	2.1102	.8674	.9743
4	.4527	.415	1.1881	2.8597	2.1872	.9084	1.0144
5	.5658	.4904	1.2986	2.9446	2.2588	.9762	1.0532
6	.6036	.6224	1.5578	3.2476	2.5027	1.3489	1.2174
7	.7545	.7733	2.2087	4.8311	3.0247	1.6053	1.4723
8	.7545	.7545	2.8243	5.1688	3.5437	1.6545	1.4708
9	.6413	.6602	3.3386	5.1974	3.5311	1.4314	1.1957
10	3.9041	3.9536	1.6499	2.0774	1.3066	5.2282	4.9774
11	4.5595	4.1053	1.0788	1.0982	.9544	3.0392	5.224
12	4.4986	3.8786	1.1867	1.1508	.9604	5.4744	5.019
13	4.3827	4.0321	1.2513	1.2349	.9522	5.4031	5.1158
14	4.295	3.9662	1.2216	1.2308	.9835	5.1033	4.9055
15	4.1858	3.7115	1.142	1.2514	.9922	5.0225	4.7157
16	4.0783	3.7625	1.0798	1.2811	1.2517	5.0143	4.6689
17	3.8074	4.0836	1.1652	1.2407	1.3189	4.689	4.5772
18	1.2411	2.0586	1.1151	1.2468	1.2807	1.6139	1.5977
19	.5093	.5658	1.1172	1.1851	1.198	.9357	1.2986
20	.5658	.5847	1.213	1.3443	1.3388	1.2386	1.4129
21	.6036	.5847	1.2108	1.3504	1.2971	1.1732	1.3535
22	.5281	.5281	1.0443	1.2384	1.2011	1.1555	1.2658
23	.415	.415	.9467	1.0555	1.0449	1.0076	.9984
24	.415	1.4855	2.3007	1.9176	1.6126	.9145	.9397
Max	4.5595	4.1053	3.3386	5.1974	3.5437	5.4744	5.224
Min	.415	.3395	.9467	1.0555	.9522	.8674	.9397
Avg	1.7935	1.7695	1.5508	2.1710	1.7076	2.4012	2.4332

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214467 / 33 KV PARGAON MANGRUL

Feeder No / Name : 205 / 11 KV RAMWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0806	1.0806	.3254	.3422	.2965	1.0864	1.0067
2	1.0821	1.0479	.3463	.3223	.301	1.105	1.0098
3	1.1286	1.0296	.3322	.333	.2995	1.1296	1.0585
4	.9358	1.0425	.3334	.3644	.3395	1.1867	1.0845
5	1.1431	1.0742	.357	.3738	.3585	1.1906	1.1134
6	1.2277	1.1385	.5784	.4256	.4073	1.3005	1.167
7	1.4213	1.5453	.6515	.647	.5502	1.6041	1.4776
8	1.7146	1.8633	.6786	.5847	.5094	1.8359	1.8005
9	1.773	1.8122	.6302	.4467	.471	1.8097	1.725
10	.7225	.6043	1.7296	1.7319	1.6549	.65	.7304
11	.4382	.3624	1.7832	1.861	1.7608	.3132	.5022
12	.4374	.4763	1.8092	1.8434	1.7657	.3177	.4855
13	.4405	.4567	1.836	1.8599	1.7512	.3498	.426
14	.4466	.4574	1.8222	1.8176	1.7078	.3658	.4481
15	.4336	.5112	1.7901	1.7947	1.7583	.4253	.4466
16	.4306	.5763	1.7608	1.6426	1.698	.4588	.5232
17	.4412	.5654	1.6575	1.776	1.598	.4614	.6127
18	.4824	.4891	.7209	.769	.596	.429	.5681
19	.4619	.4393	.4359	.4908	.3913	.4428	.5889
20	.4725	.4565	.4845	.4847	.4319	.3906	.5411
21	.4546	.4053	.4716	.4134	.4077	.3974	.4565
22	.387	.3757	.3911	.3875	.3631	.3576	.397
23	.2382	.3109	.3522	.3063	.3144	.3079	.3347
24	1.0745	.6266	.3307	.3248	.7636	1.0576	.9216
Max	1.773	1.8633	1.836	1.861	1.7657	1.8359	1.8005
Min	.2382	.3109	.3254	.3063	.2965	.3079	.3347
Avg	.7862	.7811	.9004	.8893	.8540	.7906	.8094

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214480 / Kandali Village

Feeder No / Name : 201 / Vadgaon (Kandali)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0277	1.0978	.3961	.2829	.3961	1.3592	1.4083
2	1.0442	1.0978	.3961	.2829	.3921	1.3592	1.4083
3	1.0562	1.1105	.3961	.3018	.3961	1.3916	1.4251
4	1.0562	1.1271	.415	.3395	.3961	1.4251	1.4754
5	1.073	1.1437	.4338	.4108	.415	1.4251	1.5089
6	1.1065	1.1603	.4527	.4527	.5281	1.4922	1.576
7	1.4251	1.4918	.5281	.5914	.6602	1.8313	1.8896
8	1.5083	1.7004	.5788	.5914	.7167	1.873	2.2916
9	1.5546	1.749	.5359	.5544	.7095	1.9393	2.0567
10	.5041	.5359	2.1792	2.2611	2.3102	.7207	.7842
11	.5281	.6099	2.4366	2.3371	2.5987	.7655	.7468
12	.6908	.6468	1.8515	2.343	2.5316	.7762	.8686
13	.6838	.5914	1.9826	2.3482	2.3975	.8316	.8686
14	.6468	.5914	2.1538	2.2186	2.2775	.8501	.8686
15	.6099	.6283	1.9524	2.2775	2.1792	.8686	.8316
16	.6653	.6468	2.0805	2.3102	2.1464	.8316	.8316
17	.6838	.6219	2.0243	1.9006	2.1956	.8328	.8596
18	.6653	.6516	.5441	.6838	.6099	.724	.8326
19	.6161	.543	.591	.7207	.6161	.724	.7947
20	.5788	.5175	.439	.6348	.5788	.6908	.6535
21	.5228	.4854	.439	.5415	.5228	.6161	.6161
22	.4715	.4108	.3734	.4854	.5041	.5544	.5601
23	.415	.3395	.3174	.4338	.415	.4854	.5093
24	1.0277	1.065	.3772	.2829	.3961	1.3426	1.3923
Max	1.5546	1.749	2.4366	2.3482	2.5987	1.9393	2.2916
Min	.415	.3395	.3174	.2829	.3921	.4854	.5093
Avg	.8401	.8568	.9948	1.0661	1.1204	1.0713	1.1274

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214480 / Kandali Village

Feeder No / Name : 202 / Abhangwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.431	.3978	1.2266	1.0814	1.065	.3812	.4752
2	.4144	.3978	1.2266	1.0814	1.0814	.3812	.4752
3	.4144	.4481	1.2266	1.0978	1.0814	.3812	.4752
4	.431	.4144	1.2431	1.1469	1.0814	.3978	.4915
5	.4475	.431	1.2597	1.1797	1.1142	.426	.5243
6	.4973	.4475	1.2763	1.2289	1.1797	.4752	.5407
7	.5898	.4973	1.5415	1.5074	1.4255	.4752	.6226
8	.5571	.4807	1.6741	1.6057	1.6712	.4752	.6718
9	.5636	.5967	1.7238	1.6057	1.7072	.4915	.6554
10	1.8233	1.917	.5407	.5407	.5407	1.7695	2.1956
11	2.1051	1.9989	.639	.5735	.6299	1.9334	2.1792
12	2.0222	1.9826	.5898	.5898	.6299	2.1136	2.2119
13	2.0553	1.9498	.6062	.5571	.6299	2.1136	2.1464
14	2.1382	1.9498	.5735	.6062	.6062	2.0972	2.1628
15	2.1879	1.9498	.639	.5898	.6226	2.0972	2.1792
16	2.1879	1.9006	.6226	.6062	.5735	2.1464	2.2775
17	2.1714	1.7859	.6554	.5243	.6554	2.13	2.1464
18	.5967	.5407	.5898	.5407	.5898	.6226	.6554
19	.5967	.5138	.5407	.5243	.5735	.5735	.6718
20	.547	.5138	.5571	.4915	.4424	.5571	.6554
21	.4807	.4973	.4915	.4915	.426	.5735	.5898
22	.431	.4641	.4588	.4588	.4144	.5243	.5407
23	.3647	.4144	.426	.4096	.3978	.5079	.4588
24	.431	.3812	1.1934	1.0814	1.0978	.3812	.4752
Max	2.1879	1.9989	1.7238	1.6057	1.7072	2.1464	2.2775
Min	.3647	.3812	.426	.4096	.3978	.3812	.4588
Avg	1.0202	.9530	.8967	.8383	.8432	1.0011	1.1033

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214480 / Kandali Village

Feeder No / Name : 203 / bhorwadi

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0175	.0173	.0175	.0173	.0181	.0179
2	.0175	.0175	.0173	.0175	.0173	.0181	.0181
3	.0175	.0175	.0175	.0175	.0173	.0181	.0181
4	.0181	.0175	.0175	.0171	.0183	.0181	.0181
5	.0181	.0177	.0177	.0177	.0183	.0181	.0177
6	.0181	.0177	.0358	.0177	.0183	.0181	.0177
7	.0543	.0532	.0351	.0532	.0362	.0532	.0532
8	.0716	.0867	.0886	.0886	.0709	.0709	.0709
9	.0537	.0693	.0655	.0709	.0701	.0709	.0709
10	.0358	.052	.0366	.0509	.0701	.0532	.0503
11	.0358	.0358	.0354	.0179	.0351	.0177	.0177
12	.0177	.0366	.0354	.0366	.0358	.0177	.0354
13	.0347	.0366	.0354	.0183	.0358	.0354	.0335
14	.0347	.0358	.0354	.0354	.0358	.0177	.0309
15	.0347	.0347	.0177	.0354	.0358	.0177	.0177
16	.0347	.0347	.0183	.0177	.0362	.0354	.0177
17	.0351	.0358	.0354	.0362	.0177	.0354	.0351
18	.0175	.0492	.0354	.0537	.0354	.0354	.0503
19	.0526	.048	.0709	.0549	.0532	.0532	.0362
20	.0532		.0709	.0886	.0709	.0354	.0701
21	.0709	.0686	.0709	.0678	.0709	.0532	.0532
22	.052	.0343	.0354	.0347	.0537	.0354	.0347
23	.0347	.0171	.0175	.0183	.0358	.0177	.0377
24	.0171	.0173	.0171	.0171	.0173	.0179	.0179
Max	.0716	.0867	.0886	.0886	.0709	.0709	.0709
Min	.0171	.0171	.0171	.0171	.0173	.0177	.0177
Avg	.0353	.0370	.0367	.0376	.0385	.0326	.0350

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214481 / 33/11 KV Yedgaon

Feeder No / Name : 201 / Shri Ganesh

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0867	.1006	.4024	.4024	.4334	.0867	.1341
2	.104	.1006	.4024	.4191	.4161	.0867	.1174
3	.1214	.1006	.4024	.4359	.4161	.104	.1174
4	.156	.1174	.4191	.4694	.3988	.104	.1341
5	.1734	.1341	.4359	.503	.3988	.1214	.1341
6	.1907	.1509	.4694	.5365	.4334	.1387	.1677
7	.1907	.1844	.4694	.5365	.4508	.156	.2012
8	.1734	.1677	.503	.5868	.5375	.1387	.1509
9	.1174	.1677	.5533	.6036		.1174	.1006
10	.8048	.7975	.1341	.1214		.7042	.7975
11	.8048	.7975	.1509	.1214		.8048	.8322
12	.8551	.8322	.1509	.104		.8383	.8495
13	.9221	.8149	.1509	.0867		.8886	.9015
14	.8718	.7975	.1509	.0867		.9389	.8842
15	.8048	.7975	.1509			.8886	.8669
16	.7545	.7628	.1509			.8048	.8669
17	.7209	.7455	.1509			.8048	.8842
18	.1006	.1677	.1509			.1006	
19	.1174	.1844	.1677			.1341	
20	.1341	.1844	.1677			.1509	
21	.1341	.1677	.1174			.1509	
22	.1341	.1341	.1341			.1509	
23	.1174	.1174	.1174	.0693	.104	.1341	.1214
24	.0867	.0819	.3856	.4024	.4334	.0867	.1341
Max	.9221	.8322	.5533	.6036	.5375	.9389	.9015
Min	.0867	.0819	.1174	.0693	.104	.0867	.1006
Avg	.3615	.3586	.2704	.3428	.4022	.3598	.4419

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214481 / 33/11 KV Yedgaon

Feeder No / Name : 202 / Jay Malhar

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.21	1.094	.1326	.1658	.1658	1.5581	1.326
2	1.2431	1.1437	.1492	.1989	.1658	1.5912	1.3757
3	1.2929	1.21	.1658	.1989	.1989	1.6409	1.4089
4	1.3426	1.2431	.1658	.1989	.2155	1.6907	1.4752
5	1.3923	1.2929	.1989	.2321	.2155	1.7404	1.5083
6	1.4586	1.3592	.1989	.2486	.2321	1.8067	1.5746
7	1.5249	1.442	.2321	.2652	.2486	1.8399	1.7736
8	1.7404	1.6244	.2486	.2818	.2984	2.0388	2.0056
9	1.6409	1.6078	.2818	.2818		2.0056	1.8564
10	.2486	.2486	2.1216	2.1216		.1989	.2374
11	.2818	.2652	2.1548	2.0553		.2486	.2204
12	.3149	.2652	2.2045	1.989		.2818	.2204
13	.3149	.2818	2.2045	1.9393		.2818	.2155
14	.2984	.2652	2.1879			.2818	.2321
15	.2984	.2486	2.1879			.2818	.2321
16	.2818	.2155	2.1548			.2818	.2321
17	.2818	.2818	2.1548			.3149	.2984
18	.2818	.2818	.2652			.3149	
19	.2652	.2818	.2984			.2984	
20	.2652	.2652	.2984			.2984	
21	.2652	.2652	.2652			.2818	
22	.2652	.2486	.2486			.2652	
23	.2486	.1658	.1658	.1658	.2652	.2321	.2486
24	1.1603	1.0608	.1326	.1658	.1658	1.5249	1.2929
Max	1.7404	1.6244	2.2045	2.1216	.2984	2.0388	2.0056
Min	.2486	.1658	.1326	.1658	.1658	.1989	.2155
Avg	.7466	.6941	.8674	.7006	.2172	.8875	.9334

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214481 / 33/11 KV Yedgaon

Feeder No / Name : 203 / Yedeshwar

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3467	.2883	.2543	.2204	.2427	.3814	.3222
2	.3641	.2883	.2204	.2374	.2774	.3988	.3561
3	.3988	.3052	.3052	.2543	.2947		.39
4	.4334	.3561	.3391	.2713	.3294	.5028	.4239
5	.4681	.407	.373	.3052	.3467	.5375	.4748
6	.5028	.4578	.373	.3052	.3814	.5721	.5256
7	.5375	.5596	.407	.3225	.3988	.6068	.5935
8	.6588	.6783	.3391	.3052	.4161	.6935	.763
9	.5935	.6443	.2883	.2543		.6762	.7291
10	.3052	.3121	.8139	.7628		.1865	.3294
11	.3391	.3121	.8139	.7108		.2374	.3121
12	.373	.3121	.8309	.6588		.2713	.2947
13	.373	.3294	.8139	.5895		.2713	.3121
14	.373	.3467	.8139				.3294
15	.3561	.3641	.78				.3467
16	.3561	.3814	.763				.3467
17	.3391	.4161	.763				.3814
18	.3222	.2774	.3052				
19	.3222	.2774	.3052			.3222	
20	.3052	.3121	.3222			.3222	
21	.3052	.3121	.3052			.3222	
22	.2713	.2774	.2713			.3052	
23	.2374	.2254	.2374	.2947	.2601	.3052	.2427
24	.3467	.2713	.2204	.2204	.2254	.3467	.3052
Max	.6588	.6783	.8309	.7628	.4161	.6935	.763
Min	.2374	.2254	.2204	.2204	.2254	.1865	.2427
Avg	.3845	.363	.4691	.3809	.3173	.4033	.4094

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214481 / 33/11 KV Yedgaon

Feeder No / Name : 204 / KANIFNATH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8596	.6133	.3582	.3224	.394	.7164	.7164
2	.9134	.6464	.394	.3582	.4119	.788	.8775
3	.9671	.663	.394	.394	.4119	.8775	.8775
4	1.0208	.7127	.4298	.4477	.4477	.9671	1.0029
5	1.0745	.8122	.4298	.4656	.4656	1.0566	1.0745
6	1.1283	.9448	.4477	.5014	.4835	1.1641	1.182
7	1.182	1.0277	.5014	.5014	.4854	1.2536	1.2894
8	1.379	1.2597	.4477	.4656	.4298	1.379	1.3432
9	.3856	.9282	.4119	.394		1.2715	1.2894
10	.4001	.2507	1.2536	1.2894		.3239	.4835
11	.4572	.2686	1.2894	1.2894		.381	.4656
12	.5144	.2686	1.3073	1.1641		.4382	.4656
13	.5716	.2865	1.3073	1.1283		.4572	.5014
14	.5525	.3045	1.3073			.4763	.4298
15	.4954	.3045	1.2894			.4954	.4119
16	.4572	.3224	1.2894			.4763	.394
17	.4382	.4119	1.2715			.4954	.4298
18	.4382	.4119	.4656			.5144	
19	.4191	.4298	.5014			.5525	
20	.4191	.4298	.5373			.5716	
21	.4191	.4298	.4656			.5525	
22	.381	.4298	.394			.5335	
23	.3429	.3761	.3224	.3761	.4298	.4763	.4298
24	.8059	.5967	.3582	.3224	.3582	.6447	.6805
Max	1.379	1.2597	1.3073	1.2894	.4854	1.379	1.3432
Min	.3429	.2507	.3224	.3224	.3582	.3239	.394
Avg	.6676	.5471	.7156	.628	.4318	.7026	.7550

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214481 / 33/11 KV Yedgaon

Feeder No / Name : 205 / BHOLENATH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0716	.0983	.0179	.0179	.0179	.0716	.1075
2	.0895	.0983	.0179	.0179	.0179	.0895	.1254
3	.0895	.1147	.0179	.0179	.0179	.0895	.1254
4	.1075	.1311	.0179	.0179	.0179	.1254	.1433
5	.1254	.1475	.0179	.0179	.0179	.1612	.1612
6	.1433	.1638	.0179	.0179	.0179	.1791	.1791
7	.1612	.1638	.0179	.0179	.0179	.197	.2149
8	.197	.1802	.0179	.0179	.0358	.2507	.2507
9	.1802	.1475	.0179	.0179		.2328	.2328
10	.0191	.0358	.2507	.2865		.0191	.016
11	.0191	.0358	.2507	.2865		.0191	.0179
12	.0191	.0358	.2686	.2686		.0381	.016
13	.0191	.0537	.2686	.2686		.0381	.0179
14	.0191	.0358	.2686			.0381	.0179
15	.0191	.0358	.2865			.0381	.0179
16	.0191	.0358	.2865			.0381	.0179
17	.0191	1.0513	.2865			.0381	.0179
18	.0191	.0179	.0179			.0381	
19	.0191	.0179	.0358			.0381	
20	.0191	.0179	.0358			.0381	
21	.0191	.0179	.0179			.0381	
22	.0191	.0179	.0179			.0381	
23	.0191	.0179	.0179	.0179	.0358	.0381	.0358
24	.0716	.0983	.0179	.0179	.0179	.0716	.1075
Max	.197	1.0513	.2865	.2865	.0358	.2507	.2507
Min	.0191	.0179	.0179	.0179	.0179	.0191	.016
Avg	.0627	.1154	.1037	.0871	.0215	.0818	.0959

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214481 / 33/11 KV Yedgaon

Feeder No / Name : 206 / SHRI DATTA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.407	.4191	.6443	.6443	.6783	.373	.4239
2	.4409	.4001		.6952	.7461	.407	.4239
3	.4578	.4001	.7461	.763	.8309	.407	.4239
4	.4748	.4001	.8139	.8478	.9156	.4409	.4409
5	.5087	.4382	.8817	.9156	1.0004	.4578	.4748
6	.5426	.4382	1.0174	1.0004	1.0513	.4917	.5087
7	.5765	.6287	1.1191	1.0852	1.1022	.5087	.5596
8	.5087	.5525	1.1869	1.1869	1.4752	.5256	.5426
9	.4382	.4572	1.2717	1.2717		.4917	.4409
10	1.1633	1.1869	.407	.4409		1.4255	1.2548
11	1.2452	1.2209	.407	.4578		1.5074	1.3565
12	1.3108	1.2209	.4239	.4917		1.8861	1.4413
13	1.3763	1.2378	.4239	.5256		1.9052	1.4582
14	1.3435	1.1869	.4409			1.5729	1.4413
15	1.2944	1.153	.4748			1.5074	1.4243
16	1.2452	1.1191	.4748			1.4582	1.3904
17	1.1961		.5194			1.3435	1.4074
18	.3441	.4239	.5426			.5144	
19	.3932	.5087	.5935			.5525	
20	.4954	.5596	.6274			.6097	
21	.4954	.5087	.5935			.5906	
22	.4763	.4917	.5087			.5716	
23	.4763	.407	.4409	.373	.407	.4954	.407
24	.373	.4572	.6104	.6104	.6104	.373	.4409
Max	1.3763	1.2378	1.2717	1.2717	1.4752	1.9052	1.4582
Min	.3441	.4001	.407	.373	.407	.373	.407
Avg	.7327	.6877	.6596	.7540	.8817	.8507	.8559

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214515 / 33/11 KV Khodad

Feeder No / Name : 201 / 11 KV Amarwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.1147	.4372	.3887	.4001		.1311
2	.112	.1147	.4534	.3563	.4001		.0983
3	.096	.1311	.4858	.3521	.4801		.1147
4	.128	.1311	.5182	.4534	.4801		.0819
5	.1296	.1475	.5668	.5761	.6401		.0983
6	.1619	.1638	.7287	.7682	.9602		.1638
7	.1943	.1638		1.0242	1.1203		.1966
8	.2267	.1311	1.2631	1.1523	1.1843		.213
9	.1781	.1147	.9717	1.2146	1.2003		.2429
10	1.2631	1.3123	.2622	.213	.1475		1.4899
11	1.2643	1.2631	.2591	.2458	.1638		1.4723
12	1.2483	1.3117	.208	.2294	.1475		1.4403
13	1.2003	1.3108	.208	.1802	.1638		1.4083
14	1.2003	1.2955	1.2955	.1966	.213		1.2803
15	1.2963	1.3117	.2105	.1638	.2294		1.2803
16	1.2803	1.3117	.2267	.1638	.2458		1.3123
17	1.2643		.2241	.1802	.2294	1.3279	1.3443
18	.1638	.1638	.1943	.1966	.2458	.2105	.1638
19	.1966		.2105	.1966	.2622	.2267	.1802
20	.1966	.213	.2401	.1802	.213	.2267	.1638
21	.1638	.1966	.192	.1638	.1802	.1943	.1638
22	.1475	.1638	.1638	.1638	.1638	.1296	.1311
23	.1311	.1475	.1296	.1475	.1311	.1296	.1311
24	.128	.1311	.4588	.4049	.4801	.1147	.0819
Max	1.2963	1.3123	1.2955	1.2146	1.2003	1.3279	1.4899
Min	.096	.1147	.1296	.1475	.1311	.1147	.0819
Avg	.5201	.5157	.4308	.3880	.4201	.32	.5577

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214515 / 33/11 KV Khodad

Feeder No / Name : 202 / 11 KV JAGDAMBA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3566	.3742	.949	.8353	.9998	.2522	.482
2	.3443	.3643	.9255	.8383	1.0067	.2446	.463
3	.3582	.383	.963	.8269	1.0737	.2439	.4615
4	.3736	.4031	1.0175	.9167	1.204	.2423	.4557
5	.4359	.416	1.0867	1.0747	1.2223	.2568	.4866
6	.5992	.5358	1.2176	1.2838	1.3634	.317	.5724
7	.7699	.6791	.9038	1.8284	1.6758	.3666	.7465
8	.7453	.7038	2.0235	2.0347	2.1574	.4504	.7829
9	.6403	.6196	1.7014	2.0111	2.0485	.4024	.6356
10	2.3104	2.0949	.6028	.5769	.4221	1.3451	2.2209
11	2.4517	2.2064	.602	.5575	.4645	1.3687	1.2475
12	2.4547	2.1797	.5823	.5037	.4526	1.3938	2.4036
13	2.4196	2.1959	.6058	.4847	.4671	1.4121	2.3373
14	2.3975	2.1462	.5805	.4713	.5186	1.3618	2.0446
15	2.3487	2.0927	.5432	.4679	.527	1.246	2.0675
16	2.2077	2.2018	.5685	.498	.5601	1.294	2.3617
17	2.1788	2.1306	.6181	.5281	.5927	2.2582	2.239
18	.493	.6044	.632	.5632	.5973	.6047	.4809
19	.652	.6428	.6439	.641	.7227	.7446	.567
20	.6852	.8109	.7331	.6486	.7768	.7453	.6516
21	.6486	.7735	.7579	.5693	.7068	.6752	.6512
22	.5784	.6645	.6588	.4846	.6241	.6253	.6188
23	.4953	.5457	.5274	.4298	.5353	.5079	.5319
24	.421	.7056	.9396	.857	.6569	.4778	.4839
Max	2.4547	2.2064	2.0235	2.0347	2.1574	2.2582	2.4036
Min	.3443	.3643	.5274	.4298	.4221	.2423	.4557
Avg	1.1402	1.1031	.8493	.8305	.8907	.7849	1.0831

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214515 / 33/11 KV Khodad

Feeder No / Name : 203 / 11 kv GADACHIWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4454	.3327	1.6976	1.7329	1.7673	.2599	.4267
2	.4412	.3281	1.7306	1.7044	1.7688	.2606	.4437
3	.2858	.3459	1.7956	1.5615	1.845	.2606	.4328
4	.5178	.3612	1.8389	1.7545	1.9684	.2637	.4951
5	.5956	.3997	1.9045	2.018	2.3343	.2896	.4911
6	.6996	.4992	2.1603	2.4166	2.7153	.365	.6238
7	.8246	.6108	1.5021	2.9935	3.4004	.4382	.7537
8	.7861	.6379	3.4838	3.705	3.8127	.4481	.7459
9	.6409	.5685	3.4941	3.6623	3.7975	.4367	.6717
10	4.1191	3.8812	.9454	1.0817	1.2468	2.2215	4.4958
11	4.3043	3.4353	.6106	.6092	.6552	2.4066	4.6022
12	4.308	3.9792	.6583	.6455	.6199	2.1574	4.5489
13	4.2318	4.1537	.6605	.623	.6241	2.1635	4.4422
14	4.1084	4.0982	.6527	.6288	.6436	2.3007	4.2235
15	3.7974	4.0383	.6403	.6299	.7189	2.5126	4.2371
16	3.8302	3.9101	1.7025	.6173	.7747	2.5172	4.1922
17	3.9323	3.8114	.6211	.6573	.7831	4.53	4.2318
18	1.2528	.8909	.631	.6981	.7991	1.5682	1.1553
19	.5472	.5956	.756	.6882	.7991	.6676	.5224
20	.5712	.6448	.7692	.7335	.7571	.3879	.6002
21	.5312	.6086	.7095	.7263	.7072	.7289	.5678
22	.4671	.5578	.5729	.689	.6082	.657	.5235
23	.3886	.4686	.4593	.5731	.506	.5388	.4656
24	.3917	1.1751	1.7063	1.6827	1.0685	.4397	.4405
Max	4.308	4.1537	3.4941	3.705	3.8127	4.53	4.6022
Min	.2858	.3281	.4593	.5731	.506	.2599	.4267
Avg	1.7508	1.6805	1.3210	1.3680	1.4467	1.2008	1.8472

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214515 / 33/11 KV Khodad

Feeder No / Name : 204 / 11 KV SWAMINAGAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4948	.5502	1.5234	1.5668	1.8641	.3368	.6055
2	.4793	.5533	1.5326	1.5541	1.8854	.3361	.6242
3	.5487	.5849	1.5229	1.5493	2.0035	.3506	.6158
4	.6669	.5864	1.5621	1.688	2.2672	.3727	.6303
5	.7792	.657	1.6127	1.917	2.5308	.4199	.7293
6	.9534	.86	1.8589	2.5064	2.7656	.5152	1.0429
7	1.2748	1.0189	2.9035	3.3974	3.3379	.6577	1.2464
8	1.104	.9678	3.2764	3.7199	3.8424	.6386	1.0734
9	.8635	.7567	2.7796	3.5585	3.7281	.4641	.8212
10	3.7085	3.4698	.5937	.6775	.6858	2.3335	3.7616
11	3.8196	3.1786	.6462	.578	.6745	2.38	3.9537
12	3.751	3.0784	.6043	.6105	.6444	2.2276	3.7639
13	3.5864	3.1969	.6712	.6668	.6322	2.0995	3.4256
14	3.5513	3.1499	.6318	.647	.7148	2.0309	3.2236
15	3.2076	3.1485	.6796	.6676	.7377	2.0134	3.4126
16	3.1779	3.1882	.642	.6588	.7831	2.0721	3.5589
17	3.1581	1.7848	.6607	.6829	.8052	3.7481	3.4529
18	.564	.7	.6983	.7811	.8764	.7065	.615
19	.807	.8043	.9388	.8208	.958	.8691	.8131
20	.884	.8867	1.0227	.8143	1.009	.924	.8951
21	.8406	.8386	1.044	.7895	.8634	.8226	.8916
22	.8116	.7628	.917	.7796	.7781	.7796	.804
23	.6791	.6858	.7981	.714	.687	.7453	.7095
24	.5933	1.1717	1.595	1.5889	1.1203	.3696	.6524
Max	3.8196	3.4698	3.2764	3.7199	3.8424	3.7481	3.9537
Min	.4793	.5502	.5937	.578	.6322	.3361	.6055
Avg	1.6794	1.5242	1.2798	1.3723	1.5081	1.1756	1.7218

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214516 / 33/11 KV Pimpalwandi

Feeder No / Name : 201 / 11 KV NEHARWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4173	2.4129	.7963	.7102	.7643	2.5888	2.4048
2	2.4799	2.4076	.7659	.7407	.7575	2.609	2.4693
3	2.5099	2.4558	.7697	.7735	.4222	2.6602	2.4828
4	2.4851	2.5142	.788	.8688	.8299	2.7568	2.6391
5	2.8734	2.654	.9385	.9686	.8604	2.9603	2.7442
6	3.0613	2.834	1.1315	1.1279	.9802	3.164	2.9317
7	3.6283	3.148	1.322	1.4343	1.3224	3.4589	3.5208
8	1.5745	3.5825	1.3778	1.3314	1.2094	4.21	4.0543
9	1.6194	3.8582	1.2194	1.1241	1.0616	4.2455	4.0352
10	1.2292	1.0256	3.9971	4.4238	4.518	1.2757	1.4324
11	1.1001	1.0917	4.5328	4.642	4.7637	1.0669	1.2506
12	1.0366	1.0103	4.7775	4.5374	4.7283	1.0791	1.2864
13	1.041	1.0305	4.673	4.4254	4.6803	1.0837	1.2361
14	1.0578	.9459	4.6814	4.4025	4.5304	1.0944	1.1248
15	1.1394	.8745	4.7264	4.3658	4.3932	1.0753	1.1363
16	1.2225	.8962	4.7043	4.5904	4.5683	1.1553	1.3223
17	1.3277	1.0418	4.6609	1.7093	4.515	1.1714	1.4091
18	1.2902	1.2849	1.0791	.9663	1.285	1.1912	1.4556
19	1.379	1.3664	1.2049	1.131	1.2792	.4527	1.4594
20	1.3902	1.3405	1.3984	1.3603	1.3807	.5479	1.4723
21	1.3771	1.3423	1.3512	1.3653	1.4336	.5594	1.3588
22	1.2307	1.2807	1.1812	1.3207	1.3108	.5495	1.2574
23	1.062	1.0532	.9785	1.0157	1.1317	.4847	1.1462
24	2.3655	1.7613	.8177	.756	1.5158	2.3571	2.3217
Max	3.6283	3.8582	4.7775	4.642	4.7637	4.2455	4.0543
Min	1.0366	.8745	.7659	.7102	.4222	.4527	1.1248
Avg	1.7458	1.8005	2.2447	2.0871	2.2601	1.8249	1.9980

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214516 / 33/11 KV Pimpalwandi

Feeder No / Name : 202 / 11 KV KALEKARWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3984	1.3809	1.7207	1.7957	1.8498	1.5874	1.5482
2	1.403	1.3933	1.7375	1.7635	1.8613	1.5943	1.4935
3	1.4941	1.4333	1.7741	1.8414	1.9345	1.6229	1.4761
4	1.6281	1.4958	1.9054	1.9388	2.0336	1.7145	1.5773
5	1.6799	1.7032	2.1053	2.0645	1.9728	1.8999	1.824
6	2.1254	1.9906	2.5027	2.4189	2.279	2.1929	2.2108
7	2.2876	2.1468	3.4233	3.3834	3.2848	2.3834	2.1717
8	.833	1.9107	3.8262	3.8428	4.0363	2.3539	2.0294
9	.6958	1.7038	3.83	3.7373	3.8841	1.7635	1.7341
10	3.3581	3.5836	1.3656	1.1589	1.4638	3.9943	3.8291
11	3.517	1.5848	1.4201	1.4666	1.5129	4.2014	3.9525
12	3.5195	3.7978	1.3487	1.5375	1.5377	4.1793	3.9238
13	3.5257	3.807	1.4102	1.5045	1.6472	4.0093	3.7957
14	3.4012	3.6953	1.3758	1.4722	1.6066	3.8922	3.6844
15	3.5002	3.7788	1.4655	1.5083	1.5543	3.7403	3.5783
16	3.8199	3.4768	1.258	1.6949	1.4691	3.7576	3.626
17	3.7289	3.2277	1.2394	.599	1.446	3.6911	3.6296
18	1.5208	1.4472	1.5061	1.5973	1.5535	1.4645	1.541
19	2.095	1.95	1.8806	1.9106	2.1295	.7407	1.7608
20	2.2359	2.1182	2.1323	2.0912	2.3124	.8375	2.2443
21	2.161	2.0159	2.0913	2.0699	2.3725	.8269	2.1879
22	1.9436	1.9085	1.8865	1.9342	2.1119	.7926	2.1035
23	1.6236	1.4969	1.6606	1.7048	1.7726	.7042	1.736
24	1.4052	1.5592	1.7687	1.8544	1.7036	1.6324	1.5596
Max	3.8199	3.807	3.83	3.8428	4.0363	4.2014	3.9525
Min	.6958	1.3809	1.2394	.599	1.446	.7042	1.4761
Avg	2.2875	2.2753	1.9431	1.9538	2.0554	2.3157	2.4674

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 214516 / 33/11 KV Pimpalwandi

Feeder No / Name : 203 / 11 KV CHALAKWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.423	.4107	.8495	.7775	.8055	.4619	.471
2	.4185	.426	.3507	.7526	.8025	.4466	.471
3	.4231	.4581	.7899	.7564	.8055	.487	.4588
4	.455	.4908	.8034	.7775	.9236	.5365	.4969
5	.5563	.5418	.8956	.8244	1.0004	.5906	.586
6	.7636	.6767	.9633	.9139	1.1134	.7072	.7423
7	.9419	.8299	1.2976	1.1917	1.1744	.8291	.8184
8	.3925	.7499	1.3569	1.4217	1.4034	.8055	.7663
9	.365	.6813	1.4295	1.4685	1.3565	.6637	.6407
10	1.2696	1.2821	.6933	.8484	.8876	1.4495	1.5933
11	1.3632	1.2483	.5295	.807	.9107	1.5842	1.5263
12	1.3617	1.2643	.6508	.688	.9542	1.6404	1.5594
13	1.3264	1.1226	.7244	.7095	.9702	1.5142	1.6447
14	1.2465	1.3817	.7257	.6919	.8779	1.3739	1.5543
15	1.3157	1.3908	.7313	.695	.8635	1.3573	1.4142
16	1.419	1.4367	.8323	.8109	.7865	1.4107	1.5116
17	1.07	1.3604	.8047	.3254	.7857	1.5478	1.4468
18	.6927	.7659	.6628	.852	.8383	.7354	.7241
19	.8467	.8133	.6804	.794	.8863	.333	.8771
20	.849	.8349	.6657	.8536	.8879	.3734	1.0023
21	.7575	.7831	.6121	.7864	.8292	.3589	.8905
22	.6569	.6432	.5045	.7278	.698	.33	.7775
23	.5723	.5516	.4373	.5578	.5487	.2675	.6121
24	.4443	.5357	.8216	.7737	.7522	.5007	.4901
Max	1.419	1.4367	1.4295	1.4685	1.4034	1.6404	1.6447
Min	.365	.4107	.3507	.3254	.5487	.2675	.4588
Avg	.8304	.8617	.7839	.8252	.9109	.8460	.9615

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 217006 / 132 KV NARAYANGAON

Feeder No / Name : 201 / ARVI

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9					.0184		
10	.0188	.0188	.0184	.0184		.0184	
11	.0188	.0188	.0184				
12	.0188	.0188	.0184				.0184
13	.0188		.0184				.0184
14	.0188						
16				.0184	.0184		
17					.0184		.0184
Max	.0188	.0188	.0184	.0184	.0184	.0184	.0184
Min	.0188	.0188	.0184	.0184	.0184	.0184	.0184
Avg	.0188	.0188	.0184	.0184	.0184	.0184	.0184

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 217006 / 132 KV NARAYANGAON

Feeder No / Name : 202 / KHODAD

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1372	.1143				.2439
2	.1829	.1905	.1905		.0305		.2439
3		.2058	.1296		.1905		.2591
4		.2134	.2058		.2058		.2591
5	.0229	.1296	.2286	.0457	.2058	.0229	.2058
6	.2058	.2591	.2362	.2058	.2667	.2058	.2515
7	.3125	.4115	.3125	.3277	.381	.3506	.4191
8	.3658	.4649	.3582	.3429	.4115	.3658	.4344
9	.3125	.2972	.3125	.2896	.5345	.3353	.2896
10	.4171	.4019	.3714	.345	.1905	.4659	.0152
11	.1971	.2612	.2571	.0686	.1981	.2362	.221
12	.1128	.128	.2271	.0381	.0991	.1905	.3333
13	.1128	.0381	.1128	.1316	.1753	.16	.2266
14	.1128	.0152			.1143	.061	.0838
15			.0533		.0076	.0457	.0533
16		.0076	.0152	.094	.1316	.1524	.0457
17	.1128	.0076	.0762		.2149	.1677	.3333
18		.0076	.1753	.0152	.1219	.2134	.1753
19	.1981	.1448	.1677	.16	.1829	.1981	.2058
20	.2667	.2743	.2743	.2591	.2667	.3125	.282
21	.2515	.2591	.2515	.2515	.2515	.2972	.2667
22	.1981	.2058	.2134	.1905	.221	.2362	.2439
23	.1372	.16	.16	.1677	.1753	.221	.2058
24	.0076				.0381	.1829	.1677
Max	.4171	.4649	.3714	.345	.5345	.4659	.4344
Min	.0076	.0076	.0152	.0152	.0076	.0229	.0152
Avg	.1953	.1918	.2020	.1833	.2007	.2211	.2277

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 217006 / 132 KV NARAYANGAON

Feeder No / Name : 203 / KALAMB

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8859	.9374	1.7547	1.6918	1.749	.9031	.9659
2	.8859	.9316	1.7547	1.7261	1.7433	.9031	.9831
3	.8859	.9145	1.7718	1.7375	1.7147	.9031	.9888
4	.9316	.9659	1.8004	1.8004	1.7433	.9259	1.0402
5	1.0117	1.0288	1.8347	1.9776	1.8861	1.0174	1.1088
6	1.2346	1.246	2.0405	2.1776	2.2005	1.1831	1.3089
7	1.5089	1.5261	2.7835	3.035	3.0293	1.4289	1.5432
8	1.5489	1.5832	3.3894	3.858	3.6523	1.4689	1.5661
9	1.5375	1.5489	3.5437	3.9323	7.1163	1.3146	1.5546
10	7.1188	7.2062	2.397	2.1586	1.4403	7.4255	3.9552
11	7.5617	7.3536	2.3921	1.3032	1.5261	4.1438	4.1953
12	7.4283	7.1355	2.3631	2.4313	1.5032	5.8854	7.4218
13	7.0048	3.6123	2.408	2.4366	1.5203	7.1681	7.2653
14	6.6704	3.5665	1.2974	1.2803	1.4803	3.7894	3.6294
15	3.5322	3.4979	1.2689	1.2003	1.3889	3.6466	3.5322
16	3.5894	3.3322	1.3775	2.397	2.6968	3.738	3.6408
17	6.6586	3.3322	1.5203	1.366	2.7421	3.7266	6.7157
18	1.1774	1.206	1.4175	1.4289	1.5089	1.2803	1.2517
19	1.326	1.3832	1.4632	1.4403	1.5089	1.4346	1.3946
20	1.4289	1.5203	1.5375	1.6118	1.5661	1.5604	1.5146
21	1.3832	1.5375	1.5032	1.5203	1.4575	1.5546	1.4746
22	1.3089	1.3946	1.3546	1.4232	1.3603	1.4346	1.3032
23	1.126	1.1546	1.166	1.2517	1.1774	1.2517	1.1774
24	.9717	4.9922	1.7147	1.7204	.9602	1.0231	1.0002
Max	7.5617	7.3536	3.5437	3.9323	7.1163	7.4255	7.4218
Min	.8859	.9145	1.166	1.2003	.9602	.9031	.9659
Avg	2.8632	2.6211	1.9106	1.9544	2.0280	2.4630	2.5222

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 217006 / 132 KV NARAYANGAON

Feeder No / Name : 204 / NARAYANGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5373	.583	1.5261	1.5146	1.6918	.4344	.5087
2	.543	.5658	1.5261	1.5146	1.7032	.4515	.5201
3	.5487	.5544	1.5089	1.5489	1.6975	.4572	.5201
4	.543	.5773	1.5661	1.5775	1.7261	.4687	.5201
5	.543	.583	1.5947	1.6347	1.7604	.4515	.5258
6	.5658	.6173	1.7261	1.7375	1.8804	.4572	.5487
7	.6973	.6973	1.989	2.2977	2.3148	.5601	.6459
8	.8859	.8631	2.572	2.9378	2.9092	.7373	.8288
9	.9202	.9602	2.8235	3.2122	5.5506	.7773	.8859
10	5.7952	5.5813	1.8174	1.9176	1.1774	6.0273	
11	6.2973	5.6982	1.4758	.8802	.7602	3.5894	
12	6.4002	5.8432	1.5373	.8802	.8631	3.8066	
13	6.1997	3.2808	1.6063	1.652	.9259	3.7323	3.1186
14	5.3264	3.155	.9431	.9088	.9031	3.6923	3.3779
15	3.195	3.0807	.9431	.8802	.8859	3.7209	3.618
16	2.6978	3.1321	.9602	1.5975	1.6863	3.7323	3.4179
17	5.287	3.1264	1.0345	.9031	1.6533	3.658	3.2179
18	1.1603	1.1031	1.0174	.9602	.9316	1.2403	
19	.9202	.8402	1.0117	.8516	.8573	.9202	.8573
20	.8516	.7602	.8916	.783	.6973	.8688	.9545
21	.8116	.7259	.743	.7373	.6173	.8573	.8802
22	.743	.6802	.7316	.6802	.6116	.7316	.8288
23	.7087	.6459	.7087	.6573	.5601	.6687	.8059
24	.6173	1.5203	1.5261	1.6461	.4915	.583	.6344
Max	6.4002	5.8432	2.8235	3.2122	5.5506	6.0273	3.618
Min	.5373	.5544	.7087	.6573	.4915	.4344	.5087
Avg	2.1998	1.8823	1.4075	1.4130	1.4523	1.7760	1.3608

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 217006 / 132 KV NARAYANGAON

Feeder No / Name : 205 / SAWARGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8764	.823	2.1262	2.2939	2.1948	1.0517	.8459
2	.8993	.823	2.1262	2.2558	2.1643	1.0517	.8383
3	.9297	.8459	2.1338	2.2558	2.1262	1.0745	.8612
4	.9526	.8688	2.1414	2.2481	2.1262	1.0974	.8993
5	.9983	1.0288	2.2329	2.3548	2.2481	1.2269	1.0136
6	1.2041	1.1812	2.5606	2.7816	2.6292	1.4098	1.2803
7	1.448	1.3565	3.0102	3.6885	3.5742	1.5851	1.5242
8	1.5165	1.3489	.5411	4.1914	4.1838	1.547	1.4937
9	3.3989	3.1855	3.5437	4.1	7.5696	3.2084	1.387
10	8.3892	8.4669	2.3332	2.2631	1.3946	8.3668	2.5225
11	8.5718	8.5994	2.2389	1.2727	1.3794	4.9535	4.5725
12	8.4502	8.2176	2.2131	1.2498	1.4175	4.8544	8.3607
13	7.8936	4.2219	2.3289	1.2574	1.4403	4.5725	8.3941
14	7.5028	3.9323	1.3184	1.2651	1.387	4.3667	4.2295
15	4.0695	3.818	1.2346	1.2422	1.326	4.2372	4.26
16	3.9476	3.8028	1.2727	1.2727	2.4943	4.1457	4.2295
17	3.8714	3.719	1.3184	1.2803	2.4231	4.0924	4.9248
18	1.166	1.1203	1.326	1.3184	1.4403	1.2269	1.0364
19	1.3032	1.2879	1.3489	1.3108	1.608	1.4098	1.4632
20	1.2574	1.2955	1.3489	1.2803	1.5927	1.4251	1.448
21	1.1584	1.2498	1.3032	1.2651	1.5242	1.2803	1.3032
22	1.0822	1.105	1.1736	1.1507	1.3794	1.1584	1.2422
23	.9297	1.8214	2.0652	1.8976	1.1355	.9602	1.1584
24	.8383	2.1033	2.332	2.2024	1.0593	.8764	1.0059
Max	8.5718	8.5994	3.5437	4.1914	7.5696	8.3668	8.3941
Min	.8383	.823	.5411	1.1507	1.0593	.8764	.8383
Avg	3.0273	2.7593	1.8988	1.9874	2.1591	2.5491	2.5123

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 217006 / 132 KV NARAYANGAON

Feeder No / Name : 206 / MUKTAI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5927	1.6156	1.7071	1.8671	1.7985	1.9281	1.8976
2	1.4327	1.5394	1.669	1.7223	1.6994	1.7071	1.7299
3	1.3946	1.4861	1.5927	1.6309	1.7452	1.6613	1.7756
4	1.4251	1.608	1.5623	1.6004	1.7223	1.6232	1.7833
5	1.5013	1.7223	1.5851	1.6156	1.7528	1.6461	1.829
6	1.8671	1.9738	1.9281	2.0043	1.9662	1.9814	2.1719
7	2.6597	2.7892	2.7054	2.9721	2.553	2.6673	2.8197
8	3.0559	3.0255	3.1017	3.094	2.873	2.9264	3.0331
9	3.0102	2.8883	2.934	2.8959	5.5222	2.8045	2.8197
10	5.1977	5.0366	5.404	5.3943	2.6825	5.0165	2.6139
11	5.0774	4.722	5.2005	2.8197	2.6597	2.6292	2.6368
12	5.0192	4.409	5.2413	2.5301	2.5987	2.6139	4.9572
13	4.82	2.2481	4.8864	2.492	2.4539	2.4844	4.8809
14		2.1262	2.4234	2.3624	2.3777	2.3701	2.4006
15	2.332	2.21	2.2634	2.2786	2.2177	2.3015	2.3015
16	1.448	2.1567	2.2939	4.4858	4.3273	2.3243	2.3624
17	2.5301	2.1872	2.5758	2.3853	4.4215	2.3929	5.1596
18	2.6597	2.3777	2.5606	2.4158	2.4234	2.4996	2.7816
19	3.0559	2.7587	2.8197	2.9035	2.8654	2.8807	2.9416
20	3.2998	2.9569	3.216	3.2693	3.2084	3.2541	3.2846
21	2.9645	2.873	3.0636	3.1017	3.0636	3.0559	3.0178
22	2.7282	2.6597	2.713	2.7892	2.8197	2.7968	2.8273
23	2.4844	2.4996	2.4387	2.5301	2.5606	2.6368	2.6216
24	1.9281	1.9433	2.1795	2.0271	2.0957	2.1033	2.1262
Max	5.1977	5.0366	5.404	5.3943	5.5222	5.0165	5.1596
Min	1.3946	1.4861	1.5623	1.6004	1.6994	1.6232	1.7299
Avg	2.7602	2.5755	2.8361	2.6328	2.6837	2.5127	2.7822

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 217006 / 132 KV NARAYANGAON

Feeder No / Name : 207 / MANJARWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.4496				.4496	.4877
2	.4496	.4572				.4496	.503
3	.4344	.442				.4572	.4954
4	.4572	.4801				.4801	.5563
5	.4954	.5487	.16	.0229		.503	.6097
6	.5868	.6935	.2134	.1219	.1753	.6478	.724
7	1.0059	.9907	.2439	.1753	.221	.9755	1.0212
8	1.1965	1.1812	.2515	.16	.2515	1.044	1.1736
9	1.1965	1.1203	.5792	.5868	.7537	1.0059	1.1812
10	.2139	.3666	2.3813	2.2975	1.3108	.4032	.2591
11	.4277	.2134	2.4042	1.3641	1.3641	.221	.2591
12	.3971	.3666	2.2825	1.3184	1.4175	.2362	.3956
13	.4047	.221	2.3052	1.3032	1.3489	.2439	.3728
14	.4506	.2439	1.2651	1.2346	1.2422	.2591	.1905
15	.2515	.2591	1.2193	1.1965	1.2498	.2743	.1829
16	.2515	.2439	1.2193	1.2193	2.1531	.2743	.1905
17	.2896	.2439	1.1507	1.1584	1.1279	.3201	.3652
18	.2743	.2362	.1753	.1677	.2362	.3201	.2058
19	.2439	.221	.1677	.1981	.2286	.2667	.2058
20	.2439	.1981	.0838	.1981	.2134	.2591	.2286
21	.221	.1829		.1905	.1981	.221	.2362
22	.2058	.1677			.2058	.2134	.221
23	.2896	.1296			.3125	.3582	.282
24	.4268				.4496	.4725	.3887
Max	1.1965	1.1812	2.4042	2.2975	2.1531	1.044	1.1812
Min	.2058	.1296	.0838	.0229	.1753	.2134	.1829
Avg	.4546	.4199	1.0064	.7596	.7611	.4315	.4473

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 217006 / 132 KV NARAYANGAON

Feeder No / Name : 401 / 33 KV Nirgudsar

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9				9.8857		
10	10.0038	9.4022	10.5304		10.0469	
11	10.0576		10.4767			
12	10.0038	9.1335	11.014			10.0469
13	8.4441					9.7782
16				9.1873		
17				8.4888		9.1873
Max	10.0576	9.4022	11.014	9.8857	10.0469	10.0469
Min	8.4441	9.1335	10.4767	8.4888	10.0469	9.1873
Avg	9.6273	9.2679	10.6737	9.1873	10.0469	9.6708

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 217006 / 132 KV NARAYANGAON

Feeder No / Name : 403 / Junnar

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9				12.4081		
10	13.708	14.0851	11.5098		14.4353	
11	13.5727		10.8539			
12	12.3185	13.411	12.6013			10.5984
13	12.2128					13.2228
14	12.1071					
16				11.1766		
17				10.6388		12.7989
Max	13.708	14.0851	12.6013	12.4081	14.4353	13.2228
Min	12.1071	13.411	10.8539	10.6388	14.4353	10.5984
Avg	12.7838	13.7481	11.655	11.4078	14.4353	12.2067

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064]

BU 5835

Substation No/ Name :- 217006 / 132 KV NARAYANGAON

Feeder No / Name : 405 / Otur

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9				9.7302		
10	10.9081	9.6278	9.3718		10.3448	
11	11.2154		10.0375			
12	11.113	9.8327	7.8354			9.7814
13	10.7545					10.0887
14	10.7033					
16				9.1669		
17				8.9621		8.9108
Max	11.2154	9.8327	10.0375	9.7302	10.3448	10.0887
Min	10.7033	9.6278	7.8354	8.9621	10.3448	8.9108
Avg	10.9389	9.7303	9.0816	9.2864	10.3448	9.5936

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

MANCHAR O&M DIVISION[519]

NARAYANGAON[064] BU 5835

Substation No/ Name :- 217006 / 132 KV NARAYANGAON

Feeder No / Name : 406 / GMRT Khodad

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9				.3429		
10	.3429	.3429	.3429		.3429	
11	.3429		.3429			
12	.3429	.3429	.3429			.3429
13	.3429					
16				.3429		
17						.3429
Max	.3429	.3429	.3429	.3429	.3429	.3429
Min	.3429	.3429	.3429	.3429	.3429	.3429
Avg	.3429	.3429	.3429	.3429	.3429	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

HADAPSAR[053]

BU 0817

Substation No/ Name :- 213413 / 22/22 KV SANGHAR SWITCHING

STA

Feeder No / Name : 301 / VOLVO INDIA

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	1.0669	1.0669	1.0669	1.0669	.9145	1.5196
2	1.0669	1.0669	1.0669	1.0669	1.0669	.9145	1.5196
3	1.0669	1.0669	1.0669	1.0669	1.0669	.9145	1.5196
4	.9145	1.0669	1.0669	.9145	1.0669	.9145	1.5196
5	1.0669	1.0669	1.0669	1.0669	1.0669	.9145	1.5196
6	.9145	1.0669	.9145	.9145	1.0669	.7621	1.5196
7	.7621	.9145	.7621	.9145	.9145	.7621	1.3672
8	.9145	1.0669	.9145	.9145	.7621	.9145	1.4441
9	1.2193	1.2193	1.0669	1.0669	.9145	1.2193	1.5965
10	1.2193	1.2193	1.2193	1.0669	.9145	1.2193	1.5965
11	1.2193	1.2193	1.2193	1.2193	.9145	1.2193	1.5965
12	1.2193	1.2193	1.2193	1.2193	1.0669	1.2193	1.7867
13	1.2193	1.2193	1.2193	1.2193	1.0669	1.2193	1.7097
14	1.2193	1.2193	1.3717	1.2193	1.0669	1.2193	1.7851
15	1.3717	1.2193	1.2193	1.2193	1.0669	1.2193	1.7851
16	1.3717	1.2193	1.2193	1.2193	.9145	1.2193	1.8621
17	1.2193	1.2193	1.2193	1.2193	1.0669	1.2193	1.3717
18	1.2193	1.2193	1.2193	1.2193	1.0669	1.2193	1.3717
19	1.2193	1.2193	1.2193	1.2193	1.0669	1.2193	1.2193
20	1.2193	1.2193	1.2193	1.2193	1.0669	1.2193	1.2193
21	1.2193	1.0669	1.0669	1.2193	1.0669	1.0669	1.2193
22	1.2193	1.0669	1.0669	1.2193	1.0669	1.0669	1.2193
23	1.2193	1.0669	1.0669	1.2193	1.0669	1.0669	1.2193
24	1.0669	1.0669	.9145	1.0669	.9145	1.0669	1.2193
Max	1.3717	1.2193	1.3717	1.2193	1.0669	1.2193	1.8621
Min	.7621	.9145	.7621	.9145	.7621	.7621	1.2193
Avg	1.1368	1.1368	1.1114	1.1241	1.0161	1.0796	1.4878

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

HADAPSAR[053]

BU 0817

Substation No/ Name :- 213413 / 22/22 KV SANGHAR SWITCHING

STA

Feeder No / Name : 302 / GKN DRIVELINES

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5242	1.9814	1.9814	1.829	1.5242	.7621	1.829
2	1.6766	1.9814	1.829	2.2862	1.5242	.7621	1.9814
3	1.6766	1.9814	1.829	2.1338	1.5242	.7621	1.829
4	1.6766	1.9814	1.5242	1.9814	1.3717	.7621	1.829
5	1.3717	1.6766	1.5242	1.6766	1.3717	.6097	1.6766
6	1.6766	1.9814	1.3717	1.829	1.6766	.7621	1.829
7	1.6766	1.9814	1.2193	1.829	1.829	.7621	1.5242
8	1.5242	1.829	1.6766	2.1338	1.6766	1.5242	1.6766
9	1.6766	1.829	1.5242	2.1338	1.6766	1.829	1.829
10	1.829	1.829	1.6766	2.2862	1.6766	1.9814	1.829
11	1.829	2.1338	1.9814	1.9814	1.3717	1.9814	1.829
12	1.829	1.6766	1.829	2.1338	1.5242	1.829	1.6766
13	1.6766	1.9814	1.829	1.829	1.5242	1.6766	1.9814
14	1.6766	1.9814	1.829	1.829	1.6766	1.829	1.9814
15	1.6766	1.9814	1.829	1.9814	1.6766	1.829	2.1338
16	1.829	1.6766	1.829	1.9814	1.3717	1.6766	1.829
17	1.9814	2.1338	1.6766	2.1338	1.5242	1.829	1.9814
18	1.9814	1.9814	1.829	2.1338	1.5242	1.6766	2.1338
19	1.829	2.1338	1.9814	2.1338	1.5242	2.2862	2.1338
20	1.829	1.9814	1.9814	1.9814	1.5242	2.2862	2.2862
21	1.829	1.829	1.9814	2.1338	1.3717	1.829	2.2862
22	1.9814	1.9814	2.2862	2.1338	1.3717	1.9814	2.1338
23	1.9814	2.1338	2.4387	2.1338	1.6766	2.2862	2.2862
24	1.9814	2.1338	1.829	1.829	1.6766	2.4387	2.1338
Max	1.9814	2.1338	2.4387	2.2862	1.829	2.4387	2.2862
Min	1.3717	1.6766	1.2193	1.6766	1.3717	.6097	1.5242
Avg	1.7591	1.9497	1.8036	2.0195	1.5496	1.5813	1.9433

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

HADAPSAR[053]

BU 0817

Substation No/ Name :- 213413 / 22/22 KV SANGHAR SWITCHING

STA

Feeder No / Name : 303 / ARMACELL

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.5242	1.3717	1.5242	1.3717	1.2193	1.5242
2	1.3717	1.3717	1.5242	1.3717	1.3717	1.3717	1.3717
3	1.3717	1.3717	1.3717	1.5242	1.2193	1.3717	1.2193
4	1.3717	1.3717	1.3717	1.3717	1.2193	1.2193	1.3717
5	1.3717	1.3717	1.3717	1.3717	1.2193	1.2193	1.3717
6	1.3717	1.3717	1.3717	1.3717	.9145	1.2193	1.2193
7	1.2193	1.3717	1.3717	1.3717	.9145	1.3717	1.2193
8	1.3717	1.3717	1.3717	1.3717	.9145	1.3717	1.3717
9	1.3717	1.5242	1.5242	1.5242	.9145	1.3717	1.3717
10	1.3717	1.3717	1.5242	1.5242	.9145	1.3717	1.3717
11	1.5242	1.5242	1.5242	1.5242	1.0669	1.5242	1.3717
12	1.3717	1.3717	1.5242	1.5242	1.0669	1.3717	1.5242
13	1.3717	1.3717	1.3717	1.5242	1.0669	1.5242	1.5242
14	1.3717	1.3717	1.5242	1.5242	1.0669	1.5242	1.5242
15	1.3717	1.5242	1.3717	1.5242	1.0669	1.3717	1.3717
16	1.5242	1.3717	1.5242	1.5242	1.0669	1.3717	1.5242
17	1.5242	1.5242	1.5242	1.5242	1.2193	1.5242	1.5242
18	1.3717	1.5242	1.5242	1.5242	1.2193	1.5242	1.5242
19	1.5242	1.5242	1.5242	1.5242	1.3717	1.3717	1.5242
20	1.3717	1.5242	1.5242	1.3717	1.3717	1.0669	1.5242
21	1.5242	1.5242	1.5242	1.3717	1.3717	1.3717	1.3717
22	1.3717	1.3717	1.5242	1.3717	1.3717	1.0669	1.5242
23	1.3717	1.2193	1.3717	1.2193	1.3717	1.2193	1.3717
24	1.3717	1.5242	1.5242	1.3717	1.2193	1.2193	1.3717
Max	1.5242	1.5242	1.5242	1.5242	1.3717	1.5242	1.5242
Min	1.2193	1.2193	1.3717	1.2193	.9145	1.0669	1.2193
Avg	1.3971	1.4289	1.4607	1.4480	1.1622	1.3400	1.4162

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

HADAPSAR[053]

BU 0817

Substation No/ Name :- 213413 / 22/22 KV SANGHAR SWITCHING

STA

Feeder No / Name : 304 / CONCENTRIC PUMPS

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 22 / OUTGOING

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.6097	.6097	.7621	.6097	.1524	.7621
2	.6097	.7621	.6097	.7621	.6097	.1524	.7621
3	.6097	.6097	.6097	.6097	.6097	.1524	.6097
4	.6097	.6097	.6097	.7621	.6097	.1524	.7621
5	.6097	.6097	.6097	.6097	.6097	.1524	.6097
6	.4572	.6097	.6097	.6097	.4572	.3048	.6097
7	.7621	.7621	.7621	.7621	.6097	.7621	.7621
8	.7621	.7621	.7621	.7621	.6097	.7621	.7621
9	.7621	.7621	.7621	.7621	.4572	.7621	.7621
10	.7621	.7621	.7621	.7621	.4572	.6097	.7621
11	.7621	.7621	.7621	.7621	.4572	.6097	.6097
12	.6097	.6097	.6097	.6097	.4572	.6097	.6097
13	.6097	.7621	.6097	.7621	.4572	.6097	.6097
14	.6097	.7621	.7621	.7621	.4572	.6097	.6097
15	.6097	.7621	.6097	.6097	.4572	.6097	.7621
16	.7621	.7621	.7621	.7621	.4572	.7621	.7621
17	.7621	.7621	.7621	.7621	.3048	.7621	.7621
18	.7621	.7621	.7621	.7621	.3048	.7621	.7621
19	.7621	.7621	.7621	.7621	.3048	.7621	.7621
20	.6097	.6097	.6097	.6097	.3048	.6097	.7621
21	.7621	.7621	.7621	.7621	.3048	.7621	.7621
22	.7621	.7621	.6097	.6097	.3048	.7621	.7621
23	.6097	.6097	.7621	.6097	.1524	.6097	.6097
24	.7621	.7621	.7621	.6097	.1524	.7621	.7621
Max	.7621	.7621	.7621	.7621	.6097	.7621	.7621
Min	.4572	.6097	.6097	.6097	.1524	.1524	.6097
Avg	.6795	.7113	.6923	.7050	.4382	.5652	.7113

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

HADAPSAR[053]

BU 0817

Substation No/ Name :- 218047 / 220/22KV New Phursungi

Feeder No / Name : 309 / 22kv sakal paper express NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4937	1.4784	1.5546	1.7071	1.6613	1.5394	1.6156
2	1.7375	1.9662	1.5546	1.89	1.9966	1.7071	1.829
3	2.0729	1.9814	2.0729	2.1033	2.1338	1.7833	1.829
4	2.0576	1.6613	1.5851	1.6918	1.9966	1.5546	1.0974
5	.5487	1.0364	.6097	.6249	.6097	.5182	.5182
9							.1067
10			.0305		.1524		.1677
11		.0457	.1981	.3506	.3506		.3201
12	.5792	.6859	.381	.884	.3658		.3658
13	.5182	.5944	.3048	1.1431	.3201		.2896
14	.1219	.0762	.0762	1.2651			.0457
15	.4877	.5792	.3658	1.0212	.0305		.0305
16	.4725	.6859	.2896	1.4022	.0457	.0152	.3506
17	.4725	.5792	.2896	1.2041		.1981	.0152
18	.0152	.0762	.2134	.5639		.0457	
19							.3658
20							.381
21	.7164	.6706	.6097	.5182	.7468	.503	.6249
22	1.8138	1.3717	1.829	1.89	1.5851	1.7833	1.6461
23	1.768	1.7071	1.7985	1.768	1.8138	1.5851	1.7985
24	1.7985	1.9052	1.5851	1.6461	1.6309	1.5699	1.6918
Max	2.0729	1.9814	2.0729	2.1033	2.1338	1.7833	1.829
Min	.0152	.0457	.0305	.3506	.0305	.0152	.0152
Avg	1.0421	1.0059	.8527	1.2749	1.0293	1.0669	.7545

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

HADAPSAR[053]

BU 0817

Substation No/ Name :- 218047 / 220/22KV New Phursungi

Feeder No / Name : 311 / 22KV Bhairavnath

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2862	2.4387	2.4234	2.5149	2.5758	2.4691	2.4996
2	2.1643	2.332	2.3167	2.3472	2.5301	2.2558	2.3777
3	2.1643	2.2862	2.2862	2.3015	2.4844	2.2558	2.3167
4	2.1338	2.1948	2.2558	2.2862	2.4387	2.2253	2.2862
5	2.1948	2.271	2.3472	2.3777	2.4996	2.3167	2.3777
6	2.6673	2.7282	2.6673	2.713	2.5606	2.6978	2.8045
7	3.2465	3.3227	3.3379	3.2617	3.1245	3.3532	3.3684
8	3.4751	3.4598	3.5361	3.3684	3.2922	3.4446	3.4751
9	3.1855	3.1855	3.216	3.0788	3.1703	3.1398	3.1703
10	2.8807	2.8807	2.9264	2.9721	3.094	2.9264	2.9416
11	2.8502	2.9569	2.9111	2.8959	3.0026	3.0483	3.0026
12	2.7587	2.8045	2.8654	2.8807	2.8349	3.0483	3.0636
13	2.5911	1.1279	2.8807	2.8197	2.8045	2.9721	2.9569
14	2.4996	2.5301	2.7435	2.6825	2.6063	2.8045	2.7435
15	2.4844	2.5453	2.7892	2.774	2.6216	2.8045	2.9111
16	2.6368	2.6368	2.8502	2.9416	2.5758	2.8502	3.0483
17	2.713	2.5911	2.8959	3.0026	2.6216	2.8349	3.0178
18	2.8197	2.6978	2.8502	2.9721	2.4234	3.0788	3.1093
19	3.1398	2.9721	3.1703	3.1398	3.1703	3.1398	3.2617
20	3.719	3.658	3.7799	3.6732	3.8256	3.7494	3.7342
21	3.6275	3.6732	3.7494	3.5665	3.6885	3.5665	3.658
22	3.4141	3.5208	3.6427	3.4141	3.4903	3.4141	3.5056
23	3.0788	3.1093	3.4446	3.1855	3.1855	3.1245	3.2617
24	2.652	2.774	3.0331	2.9264	2.7892	2.774	2.9416
Max	3.719	3.6732	3.7799	3.6732	3.8256	3.7494	3.7342
Min	2.1338	1.1279	2.2558	2.2862	2.4234	2.2253	2.2862
Avg	2.8076	2.7791	2.9550	2.9207	2.8921	2.9289	2.9931

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

HADAPSAR[053]

BU 0817

Substation No/ Name :- 219018 / 400KV LONIKAND

Feeder No / Name : 302 / Pabal

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6406	2.7938	2.5869	2.5591	2.0058	2.8807	2.9473
2	2.6932	2.6749	2.6147	2.5514	1.8861	2.8296	2.9447
3	2.6993	2.758	2.4531	2.4348	1.6248	2.8349	2.9058
4	2.9012	2.7995	2.6932	2.5431	1.8427		
5	3.083	3.1893	3.0121	2.8121	2.0553		3.2251
6	3.6694	3.8733	3.6892	3.6561	2.4806	3.8561	4.0665
7	4.784	4.8712	4.7188		3.5757	5.3509	5.3986
8	4.2067	5.7053	5.2801	5.743	3.8912	5.9534	6.3451
9	4.2635	6.6095	5.7133	6.2734	3.5757	6.7215	
10	6.4228	6.4975	5.7133	6.552	3.8089	6.2757	5.2934
11	6.2917	6.3481	4.3077	6.7589	3.7715		
12	5.8471	6.012	6.0867	6.3108	.5228	6.19	5.1905
13	5.7065	5.8253	6.0494	5.9747	5.8627		5.3986
14	5.3407	4.9429	5.7133		6.4975	1.6057	6.012
15	5.1943	3.8089	5.4893		6.9083		
16	5.2309	4.2196	5.144		6.9829	6.7962	6.4975
17	5.5967	4.4525	5.9		5.7507		6.0997
18	5.8627	4.5725	5.7507	1.4937	.4854	7.319	
19	4.7051	4.8544	4.792	1.4563	1.307	5.7842	5.3772
20	3.9335				1.419	5.013	4.7051
21	3.6534			1.2757		4.4163	
22				2.1262		3.8211	
23	2.8395		2.7343	2.1262		3.3665	
24	2.7343	2.7286	2.5377	2.6578	2.0774	3.152	6.1176
Max	6.4228	6.6095	6.0867	6.7589	6.9829	7.319	6.4975
Min	2.6406	2.6749	2.4531	1.2757	.4854	1.6057	2.9058
Avg	4.3609	4.4769	4.4276	3.6281	3.2539	4.6759	4.9078

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

HADAPSAR[053]

BU 0817

Substation No/ Name :- 219018 / 400KV LONIKAND

Feeder No / Name : 303 / 22kv Wagholi

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	7.4669	7.0302	7.9378	7.2645	8.5048	8.453	8.8592
2	7.0873	6.893	7.6189	7.1582	7.7961	8.1085	8.3455
3	7.1994	7.0519	7.6543	6.9845	6.9845	8.1664	8.1504
4	7.2215	7.0588	7.6741		6.9102	7.9515	
5	7.572	7.7103	8.4172		7.2036	8.5604	8.9544
6	6.6255	9.1693	9.9185	8.7426	8.4172	9.7805	9.9223
7	4.6422	10.2424	11.5387		10.4984	11.4495	11.5318
8	4.4296	10.3155	12.0336		11.4129	12.0348	11.8275
20	11.1622			12.3274		12.3819	
21	10.0259			11.3146		11.3184	
22				10.9404		11.2731	
23	8.4339		8.3676	9.9547		9.8514	
24	7.9157	7.5019	8.2922	7.6543	8.9049	8.8828	9.145
Max	11.1622	10.3155	12.0336	12.3274	11.4129	12.3819	11.8275
Min	4.4296	6.893	7.6189	6.9845	6.9102	7.9515	8.1504
Avg	7.4818	8.1081	8.9453	9.1490	8.5147	9.8625	9.5920

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

HADAPSAR[053]

BU 0817

Substation No/ Name :- 219018 / 400KV LONIKAND

Feeder No / Name : 304 / Talegaon -D-

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4022	1.5402	7.9378	7.6818		8.5734	8.5886
2	1.4883	1.4723	7.8174	7.9733		8.7754	8.5246
3	1.4746	1.5043	8.0232	7.8875		8.7601	8.2381
4	1.5775	1.4685	8.1809	8.0441			8.3097
5	1.7528	1.7364	8.2023	8.5597		8.9903	8.5246
6	1.8427	1.8267	8.4694	9.2772		9.2196	9.0135
7	10.096	1.7193	9.9863			11.4861	10.974
8	4.2265	11.0143	10.7453	11.3893		12.2108	12.1361
9	1.3817	11.1569	10.1357	10.3121		11.2826	
10	1.307	11.2666	9.465			11.0075	10.5518
11	1.2071	10.3224	9.5969	10.2424			
12	10.3891	10.4184	.1867	.1867			
13	10.6082		.1463				.6661
14	10.3887	9.9547	.1494			.1494	.823
15	10.2789	10.2081	.1867				
16	11.0159	10.6813	.1494			.9114	.7842
17	10.4557	11.1652	.1494	.1402			.7362
18	9.8209	10.3891	1.1576	1.1576		.9335	
19		1.419	1.7177	1.531	1.9418	1.307	1.2269
20	1.6461			1.9044	2.0332	1.7737	1.7013
21	1.6834			1.8461		1.7193	
22				1.7718		1.6655	
23	1.576		1.5432	1.6476		1.576	
24	1.5043	1.5238	7.9733			8.8687	.7095
Max	11.0159	11.2666	10.7453	11.3893	2.0332	12.2108	12.1361
Min	1.2071	1.419	.1463	.1402	1.9418	.1494	.6661
Avg	4.8693	6.3572	5.3295	5.3855	1.9875	6.0672	5.7193

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

HADAPSAR[053]

BU 0817

Substation No/ Name :- 219018 / 400KV LONIKAND

Feeder No / Name : 305 / Kalyani

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	8.0018	9.7165	6.3253	8.203	8.4591	7.2779	8.5734
2	8.9544	7.5446	5.9061	7.2017	8.0018	6.592	7.6208
3	9.4498	7.2398	5.868	6.9102	7.4303	6.8206	7.2398
4	8.4591	7.2017	5.868	8.0018	7.3922	7.2398	
5	7.0111	7.3541	6.0966	7.7732	7.4303	7.6208	
6	8.4972	9.7927	6.973	8.7258	7.5827	8.0399	8.7639
7	6.592	6.4777	6.6301		6.8206	6.6301	7.316
8	10.2881	6.9349	9.2593	8.802	10.0214	9.2593	10.8215
9	9.8689	6.6682	10.1197	9.1495	10.7453		9.7104
10	11.1645	6.4015	10.4786		10.3262	9.3736	
11	11.2407		9.9451	10.1943	11.1645		
12	8.3448			9.2212	6.1728	8.9163	10.1357
13			11.3146	9.3736	7.9637		10.8596
14	11.5455	3.5437	11.8884		8.738	10.8215	9.526
15	11.2026	4.2196	12.3838		9.145		
16	11.6217	4.4963	10.25		8.7258	10.8215	12.4349
17	8.802	5.1059	8.6496	8.802	3.4675		9.7546
18	11.1264	5.7918	10.4786	10.974	8.0399	9.0306	
19	10.3643	6.6682	11.6217	10.25	8.421	10.4786	10.631
20	9.907			8.9925	7.5057	9.6784	8.802
21	10.4024			11.8884		11.736	
22				9.7165		9.526	
23	9.1831		8.7639			9.907	
24	8.4591	9.4498	8.802	8.421	8.1162	7.1254	11.6217
Max	11.6217	9.7927	12.3838	11.8884	11.1645	11.736	12.4349
Min	6.592	3.5437	5.868	6.9102	3.4675	6.592	7.2398
Avg	9.5676	6.7416	8.8811	9.0334	8.1748	8.7840	9.5874

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

HADAPSAR[053]

BU 0817

Substation No/ Name :- 219018 / 400KV LONIKAND

Feeder No / Name : 306 / WADHU

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	17.9226	20.3445	13.0796	20.5266	18.9514	17.3807	19.4147
2	17.4607	17.2017	13.2842	19.0779	18.4252	16.8907	17.3457
3	17.9035	17.4185	13.1706	19.5058	19.2441	18.1215	16.9228
4	16.3093	15.5404	13.0316	16.7722	16.7559	16.3558	15.1181
5	17.465	17.7344	14.0211	19.2631	18.1078	17.6787	18.3729
6	18.5254	17.4135	15.4123	20.6874	18.506	19.0924	19.76
7	17.4653	12.8578	15.5396	13.3151	12.3823	17.9999	18.5262
8	21.5539	12.4912	19.8522	23.9659	20.7575	21.3668	21.8599
9	24.3378	14.3386	24.017	***	23.3882	24.962	16.9974
10	***	14.353	***	17.9241	***	***	***
11	***	14.5253	***	***	23.4568	17.4486	18.546
12	23.5087	12.7992	22.6269	23.5505	19.4872	23.0605	23.6214
13	***	12.694	***	24.2182	21.0731	16.9121	***
14	22.6246	13.2723	23.7487	17.0706	20.1852	24.1411	***
15	20.4298	13.1093	24.555	16.211	20.8863	16.2232	17.3084
16	23.3219	13.0354	***	16.1866	22.835	***	***
17	24.3484	12.9859	24.4132	24.0436	22.9249	16.3512	***
18	24.0269	12.5659	23.7937	***	21.8706	24.914	17.4425
19	22.2345	12.5355	24.3012	23.9438	21.8313	23.5086	***
20	20.1433	7.1392	13.5223	20.0945	17.9295	20.3289	20.9946
21	21.2071	7.1575	14.5893	20.548	12.3884	21.4556	14.9612
22	12.3579	7.5842	12.0409	19.8171	11.3824	19.6754	14.3332
23	17.7191	8.072	15.1342	19.3348	10.8276	16.1016	12.9371
24	19.4468	15.0564	17.7035	19.7782	18.991	19.8842	23.0544
Max	26.9822	20.3445	26.2087	27.0806	25.5876	26.1713	27.5614
Min	12.3579	7.1392	12.0409	13.3151	10.8276	16.1016	12.9371
Avg	20.7912	13.4261	19.1911	20.6086	19.0906	20.0745	20.2597

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

HADAPSAR[053]

BU 0817

Substation No/ Name :- 219018 / 400KV LONIKAND

Feeder No / Name : 307 / MARKAL-II

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.3553	5.5159	4.2878	5.7613	5.2233	5.013	5.1882
2	4.1716	5.5281	4.0665		5.1532	4.9078	5.032
3	4.2878	5.4218	3.9963	5.7407	5.0831	4.8891	
4	4.513	5.3864	4.0832	5.8025	4.904	5.0145	
5	4.6811	5.8894	4.784	6.3348	5.5159	5.6699	5.3285
6	6.089	7.2645			6.7558	6.6187	6.6255
7	8.7883	8.7106	8.7963	7.8315	8.6515	9.7737	8.8946
8	10.0595	9.497	8.9655	13.1817	10.7179	11.4461	12.4189
9	11.0837	10.5678	10.4977	13.5551	9.7737	12.5469	
10	12.0713	10.7171			10.4184	12.1445	12.8144
11	12.0713		11.6587		11.1652		
12	12.1811		13.8912		9.2898	11.1127	13.3311
13	11.1203			12.8506	9.0741		12.3228
14	11.7787		4.4871	9.7836	5.1158	11.464	10.7971
15	12.1811		13.7418				
16	12.9576		8.5886			10.7918	12.4722
17	13.0697		12.4886	12.923	8.9994		12.38
18	11.4266		12.7709	7.431	5.4504	12.5842	
19	9.0718		10.157	9.5969	7.9576	8.799	8.626
20	7.9058			8.5513	8.0285	8.0628	7.537
21	7.2291			6.6621		6.8747	
22				6.275		6.3077	
23	6.1248		6.6229	5.9366		5.5636	
24	4.3469	5.7053		6.2369	5.3509	5.1219	10.0823
Max	13.0697	10.7171	13.8912	13.5551	11.1652	12.5842	13.3311
Min	4.1716	5.3864	3.9963	5.7407	4.904	4.8891	5.032
Avg	8.7637	7.2913	8.4638	8.4973	7.5068	8.2353	9.5900

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

HADAPSAR[053]

BU 0817

Substation No/ Name :- 219018 / 400KV LONIKAND

Feeder No / Name : 308 / B.U.Bhandari

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.6808	3.6107	2.2325	3.8325	3.3608	4.6776	4.2417
2	3.6458	3.5021	2.1616	3.7609	3.3265	4.1815	3.751
3	3.5715	3.5056	2.0576	3.5437	3.4385	4.4056	3.725
4	3.4675	3.4355	2.1262	3.6892	3.4027	4.2878	
5	3.5322	3.7967	2.1735	4.4414	3.4385	4.3233	3.7563
6	3.8626	3.751	2.2786		3.5113	4.1838	3.2922
7	3.6145	3.086	2.5869		3.3951	3.7795	
8	3.6351	2.5869	3.1184	4.369	4.6068	4.465	4.0665
9	4.8285	2.8753	4.6677	5.0785	4.0905	5.8627	
10	5.5384	1.643	4.5557	5.1158	4.3801	5.8627	5.6013
11	5.7133	1.4937	5.0038	5.676	4.5953		
12	5.0846	2.3152	2.3899	5.0038	4.0905	4.8171	4.7424
13	5.0412	2.5019	4.369	5.104	1.4937		.0373
14	4.8651	2.95	4.8918	5.5967	4.7798	5.1882	4.1823
15	5.6699	2.6513	5.3772		4.5557		
16	5.3772	3.062	4.3118		3.8462	4.382	4.0703
17	5.2309	2.6139	4.3317	4.5931	3.062		4.353
18	4.5953	2.4272	3.9582	4.1267	3.9209	4.6677	
19	4.5557	2.6139	4.369	4.4437	4.145	4.4993	4.0543
20	4.2417			3.9582	3.7342	4.2433	3.4728
21	3.9963			4.0116		4.1461	3.751
22				3.8066		3.751	3.5791
23	4.1366		3.6351	3.9335		4.2878	
24	4.0116	3.6892	2.1033	3.751	4.0314	4.5572	4.9291
Max	5.7133	3.7967	5.3772	5.676	4.7798	5.8627	5.6013
Min	3.4675	1.4937	2.0576	3.5437	1.4937	3.751	.0373
Avg	4.4303	2.9056	3.4619	4.3918	3.7717	4.5285	3.8592

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

HADAPSAR[053]

BU 0817

Substation No/ Name :- 219018 / 400KV LONIKAND

Feeder No / Name : 309 / substation supply

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1157	.1122	.1181	.1227	.1087	.1134
2	.1029	.1157	.1205	.1257	.1132	.1097	.1169
3	.1039	.1097	.1169	.1181	.1205	.1132	
4	.0957	.1157	.1132	.1143	.1097	.1166	
5	.0947	.1166	.1166	.1105	.1157	.1144	.1052
6	.0971	.0971	.1296	.1205	.1192	.1192	.1254
7	.0841		.1235		.1132	.111	.1134
8	.0771	.111	.124	.112	.1063	.1099	.1122
9	.0841	.0896	.1195	.1083	.1046	.1061	
10	.1024	.0951	.112	.1083	.0947	.1083	.0982
11	.0914	.0971		.1061	.1046	.1017	.1017
12	.0914	.1083	.1195	.1158		.1122	.1083
13	.1122		.1158	.1083	.112		.1061
14	.0971	.1134	.112	.1029	.1083	.1083	.112
15	.0914	.1083	.1083		.112		
16	.1052	.0934	.105		.0995	.1086	.1083
17	.0934	.1456	.112	.1087	.1083		.1086
18	.1207	.127	.1083	.1158	.1046	.1083	
19		.1231	.105	.1307	.1083	.1086	.1232
20	.1122			.1232	.1195	.1158	.1195
21	.1052			.1214		.1169	.1157
22				.1153		.1122	.1166
23	.1097		.1166	.1166		.1157	
24	.0926	.1158	.1052	.1083	.1083	.1134	.0977
Max	.1207	.1456	.1296	.1307	.1227	.1192	.1254
Min	.0771	.0896	.105	.1029	.0947	.1017	.0977
Avg	.0985	.1110	.1148	.1147	.1103	.1114	.1112

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

HADAPSAR[053] BU 0817

Substation No/ Name :- 219018 / 400KV LONIKAND

Feeder No / Name : 310 / 22kv colony

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.127						
7		.127	.127	.127		.127	.127
8			.1905				
19		.127					
20		.127		.127			.127
21				.127		.127	
22				.127			
24	.1905	.1905		.1905	.1905		
Max	.1905	.1905	.1905	.1905	.1905	.127	.127
Min	.127	.127	.127	.127	.1905	.127	.127
Avg	.1588	.1429	.1588	.1397	.1905	.127	.127

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

HADAPSAR[053]

BU 0817

Substation No/ Name :- 219018 / 400KV LONIKAND

Feeder No / Name : 313 / 22 kvstone crusher
Feeder KV- 22 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-17
HR	Load (MW)
11	.0038
Max	.0038
Min	.0038
Avg	.0038

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

HADAPSAR[053]

BU 0817

Substation No/ Name :- 219018 / 400KV LONIKAND

Feeder No / Name : 314 / 22 kv wika

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.553	2.934	2.934	2.8197	2.5911	2.8197	3.4294
2	2.4768	2.934	2.6673	2.7816	2.5149	2.6292	2.9721
3	2.4006	2.8959	2.5911	2.7435	2.4768	2.553	
4	2.4387	2.8578	2.553	2.6673	2.553		
5	2.553	2.934	2.6673	2.8197	2.553	2.6673	3.0102
6	3.5437	3.5056	3.3532	3.3532	2.7435	3.2388	3.2388
7	4.2295	3.8104	3.8866		3.1245	3.9628	3.6199
8	4.1152	4.2676	4.2295	4.3439	3.2388	4.4201	3.8866
9	4.0771	5.0678	4.2295	4.4201	3.5056	4.4201	3.6808
10	4.382	4.5344	4.1914		3.8866	4.9535	5.0297
11	4.3896	4.5725	4.763		4.039		
12	4.1914	4.2676	4.4963	4.1914	3.7723	4.382	4.8011
13	3.914	4.2196	4.4963	4.2943	3.658		4.6868
14	4.2295	4.0771	3.8211		3.0102	4.4963	1.6004
15	3.9247	4.1533			3.0407		
16	4.1152	4.3439	3.8043		3.5056	4.8392	2.5911
17	4.1152		3.8866	4.5725	3.5056		4.1533
18	4.1152		3.7342	4.4963	3.2769	4.8773	
19	4.2295		3.9628	3.9628	3.1245	4.2295	4.5344
20	4.2295			3.9247	3.2007	4.0771	4.3439
21	3.8104			3.6199		3.7342	
22				3.5818		3.6961	
23	3.315		3.2769	3.3913		3.4675	
24	2.553	3.4675	3.1245	2.8959	3.0864	2.934	1.829
Max	4.3896	5.0678	4.763	4.5725	4.039	4.9535	5.0297
Min	2.4006	2.8578	2.553	2.6673	2.4768	2.553	1.6004
Avg	3.6479	3.8143	3.6334	3.6044	3.1623	3.8104	3.5880

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

HADAPSAR[053]

BU 0817

Substation No/ Name :- 219018 / 400KV LONIKAND

Feeder No / Name : 316 / Lonikand Sub-station-I
Feeder KV- 22 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0038	.0038	.0038	.0038	.0038	.0038	.0038
2	.0038	.0038	.0038	.0038	.0038		.0038
3	.0038	.0038	.0038	.0038		.0038	
4	.0038	.0038	.0038	.0038			
5	.0038	.0038	.0038	.0038	.0038	.0038	.0038
6	.0038	.0038	.0038	.0038		.0038	.0038
7	.0038	.0038	.0038		.0038	.0038	.0038
8	.0038	.0038	.0038	.0038	.0038	.0038	.0038
9	.0038	.0038	.0038	.0036	.0038	.0038	.0038
10	.0038	.0038	.0038		.0038	.0038	
11	.0038	.0038	.0038		.0038		
12	.0038	.0038	.0038	.0038	.0038	.0038	.0038
13	.0038		.0038	.0038	.0038		.0038
14		.0038	.0038		.0038	.0038	.0038
15	.0038	.0038	.0038		.0038		
16	.0038	.0038	.0038		.0038	.0038	.0038
17	.0038	.0038	.0038	.0038	.0038		.0038
18	.0038	.0038	.0038	.0038	.0038	.0038	
19	.1195	.0038	.0038	.0038	.0038	.0038	.0038
20	.0038			.0038	.0038	.0038	.0038
21	.0038			.0038		.0038	
23	.0038			.0038		.0038	
24	.0038	.0038	.0038	.0038	.0038	.0038	.0038
Max	.1195	.0038	.0038	.0038	.0038	.0038	.0038
Min	.0038	.0038	.0038	.0036	.0038	.0038	.0038
Avg	.0091	.0038	.0038	.0038	.0038	.0038	.0038

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

HADAPSAR[053]

BU 0817

Substation No/ Name :- 219018 / 400KV LONIKAND

Feeder No / Name : 318 / 22 KV Sanghar Feeder
Feeder KV- 22 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0683	2.2085	2.3838	2.7694	2.2565	1.5592	2.0553
2	2.1384	2.2786	1.949	2.3034	2.1033	1.3717	1.9547
3	2.1605	2.1971	1.8427	2.1971	2.0553	1.3321	
4	1.9765	2.2325	1.8267	2.0919		1.4175	
5	1.7364	2.3034	1.7193	2.1849	1.7528	1.4327	1.7177
6	1.7718	2.2207	1.6476	2.2207		1.4723	1.6827
7	1.5947	1.949	1.7364		1.3611	1.4022	1.6301
8	2.0058	2.4806	2.268	2.2779	1.7364	2.0851	2.1384
9	2.1582	2.5972	2.3167	2.2805	1.9418	2.5019	2.4539
10	2.5019	2.3899	2.4646		1.8298	2.2032	2.5019
11	2.4508	2.3899	2.489	2.7149	1.7147		
12	2.2779	2.1285	2.4272	2.1735	1.4937	2.2805	2.0332
13	2.1948	2.8753	2.4272	2.5972	1.6289		2.5766
14	2.5606	2.1384	2.4806		1.8298	2.3899	2.2634
15	2.8166	2.7633	2.5019		1.7551		
16	2.8006	2.6139	2.5339		1.9044	2.2405	2.4253
17	2.5019	2.8006	2.5274	2.3899	2.0165		2.3487
18	2.5606	2.4253	2.6886	2.8006	1.9418	2.4272	
19	2.1262	2.9127	2.4253	2.5766	2.2436	2.3899	2.6886
20	2.7343			2.6513		2.3152	2.838
21	1.9136			2.4768		2.1384	
22						2.524	
23			2.516	2.1971		2.3034	
24	1.5402	2.3243	2.1384	1.949	1.7528	1.1584	2.3525
Max	2.8166	2.9127	2.6886	2.8006	2.2565	2.524	2.838
Min	1.5402	1.949	1.6476	1.949	1.3611	1.1584	1.6301
Avg	2.2087	2.4115	2.2529	2.3807	1.8510	1.9473	2.2288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

HADAPSAR[053]

BU 0817

Substation No/ Name :- 219018 / 400KV LONIKAND

Feeder No / Name : 319 / 22 Kv Fulgaon Industrial

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9945	1.0288	.9907		.7621	1.6766	1.0669
2		.9259	.9114			1.5242	1.1431
3	.9602				.7621		
4	.9362	1.0288				.9145	
5	.9816		.8916		.8383		1.0669
7	1.9342	1.2955	2.2207			2.3624	2.2862
8	1.5074	1.2971	2.364		2.6673	2.3243	2.21
20	1.0867						
24	1.0166	.9816	.8764	.9907	.7202		1.0288
Max	1.9342	1.2971	2.364	.9907	2.6673	2.3624	2.2862
Min	.9362	.9259	.8764	.9907	.7202	.9145	1.0288
Avg	1.1772	1.0930	1.3758	.9907	1.15	1.7604	1.4670

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

MULSHI[057]

BU 0850

Substation No/ Name :- 213331 / 22 KV BHARE SWITCHING

Feeder No / Name : 302 / 22 KV LAWALE

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	7.7298	8.2102	7.7614	8.0289	7.4629	8.0999	8.189
2	7.5181	7.8255	7.6446	7.8239	7.2731	8.0389	7.9624
3	7.3538	7.4781	7.426	7.6731	7.1291	7.9832	7.6028
4	7.1116	7.6478	7.3193	7.6326	6.9326	7.8035	7.7774
5	7.4419	8.3273	7.6547	7.9868	7.331	8.1424	8.198
6	8.729	9.6589	8.9285	9.1776	8.1729	9.7184	9.6031
7	10.255	11.4819	10.4042	10.5246	9.3352	10.9682	11.6051
8	11.9198	13.2588	13.5641	12.6371	10.6008	12.7863	8.7792
9	12.2247	14.0976	13.5095	13.7334	10.8751	10.863	14.3173
10	12.7836	14.8464	14.2584	13.6451	11.0496	9.164	15.7662
11	13.3763	15.0698	15.5732	14.1585	5.9467	14.2564	10.3458
12	13.4373	14.4413	16.4135	9.5565	4.6512	15.1256	7.2093
13	14.7719	14.0771	15.5595	9.3736	2.8439	14.8269	14.2127
14	14.9395	13.6961	15.0461	9.0992	2.805	15.0428	14.0121
15	15.0683	13.9788	15.1191	13.0687	11.1378	10.2424	14.2452
16	14.3772	15.0241	15.6325	13.4606	11.4579	9.5466	14.5439
17	13.9047	14.7918	15.2952	13.8669	11.5935	14.043	14.0092
18	13.6287	13.6771	14.6631	8.9829	11.6239	14.4434	13.7705
19	13.3357	13.2625	13.6062	8.8532	10.5594	13.921	9.2974
20	12.6836	12.7402	8.9925	10.9886	11.3307	13.7571	13.6656
21	11.449	11.656	8.0092	10.1278	10.4294	12.9534	12.5402
22	10.7901	9.9906	10.76	9.7111	9.9854	12.1189	7.7427
23	9.4453	9.6906	9.977	8.803	8.9554	10.8224	7.0721
24	8.4309	9.6004	8.6963	8.278	8.3437	8.8977	9.2826
Max	15.0683	15.0698	16.4135	14.1585	11.6239	15.1256	15.7662
Min	7.1116	7.4781	7.3193	7.6326	2.805	7.8035	7.0721
Avg	11.3627	11.8554	11.7423	10.2997	8.6594	11.3986	10.9062

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

MULSHI[057]

BU 0850

Substation No/ Name :- 213331 / 22 KV BHARE SWITCHING

Feeder No / Name : 303 / VULCAN

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6237	1.6766	1.6766	1.8253	.4295	.7247	2.2862
2	1.5513	2.0957	1.6385	1.627	.3997	.7247	1.829
3	1.5028	1.9033	1.6004	1.5181	.3908	.761	1.7405
4	1.4204	1.8125	1.6004	1.5466	.3903	.7972	1.6352
5	1.6385	1.4712	1.7147	1.737	.2353	.7972	1.6319
6	1.829	1.432	2.2862	2.1189	.1758	.8697	2.21
7	1.1742	1.432	1.6385	1.5242	.145	.9422	1.5591
8	2.3624	2.7732	2.4743	2.5807	.2219	2.5149	
9	2.4387	2.1338	2.3624	2.4387	.2211	3.1626	2.6673
10	2.7435	2.1719	2.2862	2.7054	.5024	3.1245	2.7
11	2.3243	2.8197	2.5859		.503	3.0483	2.7435
12	2.2481	2.2862	2.5911	2.9721	.4694	2.7054	
13	2.6673	2.4768	2.5911		.4694	3.0933	2.7054
14	1.9433	2.934	2.5807		.4694	2.9602	3.1245
15	2.4768	2.5911	2.738		.3475	3.0483	2.3624
16	2.9721	2.6673	2.6673	3.0102	.3475	2.6673	2.934
17	2.553	2.6673	2.4768	2.9076	.303	2.8578	2.8197
18	2.1719	2.7435	2.6619	2.035	.2755	2.7054	2.5149
19	2.8959	3.1245	2.8464	2.5402	.3581	2.6673	2.9721
20	2.1719	2.2481		2.5123	.4132	2.4216	2.3243
21	1.9814	2.2862	2.353	1.9433	.4683	2.1946	2.21
22	2.2862	2.21	2.1504	1.9052	.4683	2.1338	
23	2.1719	2.21	2.4216	.785	.551	2.4693	
24	1.5513	2.2481	2.2862	1.9394	.444	.7461	1.6766
Max	2.9721	3.1245	2.8464	3.0102	.551	3.1626	3.1245
Min	1.1742	1.432	1.6004	.785	.145	.7247	1.5591
Avg	2.1125	2.2673	2.2708	2.1086	.3750	2.0891	2.3323

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

MULSHI[057]

BU 0850

Substation No/ Name :- 213331 / 22 KV BHARE SWITCHING

Feeder No / Name : 304 / Paud Ambarwet AG Feeder

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2598	.1485	.6126	1.0547	.1488	.1489	.1483
2	.2227	.1485	.5516	.8042	.1488	.1489	.1489
3	.1856	.1485	.5516	1.0328	.1488	.1861	.1489
4	.1856	.1485	.5516	.9566	.1488	.1899	.1489
5	.2227	.2227	.482	1.0089	.1488	.1489	.1489
6	.2227	.2227	.5659	1.2882	.1488	.1489	.1489
7	1.9801	.5799	.323	.8956		.1861	.2234
8	2.8078	1.1895	.2315	.1945	.1859	.2234	
9	3.165	1.8297	.3429	.2993	.1859	1.4257	.2234
10	3.5984	2.6487	2.1024	.6041	.1488	1.0379	.5807
11	3.9165	3.2783	2.0719	.2743		2.0725	2.1271
12	4.0298	3.1286	2.1872	2.271	.1488	2.4452	1.7833
13	3.8184	2.8383	2.1567	1.6156	.1865	2.3761	2.1423
14	3.8098	2.7793	2.1262	1.8747	.2231	2.1792	1.9594
15	3.8098	2.3072	2.1262	1.8138	.3585	1.9981	2.0052
16	3.8794	2.4596	1.989	2.0046	2.0418	.3368	2.0509
17	3.8707	2.4444	1.9128	2.135	.872	.4368	2.1949
18	3.6461	2.3006	1.5794	1.8711	.1861	.2606	2.2947
19	2.5527	1.892	.2229	.1488	.4793	.2234	1.9984
20	1.5096	.4972		.1488	.1899	.1489	.1863
21	.2837	.6278	.2248	.1488	.1489	.1489	.1491
22	.2227	.5973	.3925	.1488	.1489	.1489	
23	.1856	.765	.4229	.1488	.152	.1489	
24	.2598	.7877	.5821	.1858	.1488	.1489	.1491
Max	4.0298	3.2783	2.1872	2.271	2.0418	2.4452	2.2947
Min	.1856	.1485	.2229	.1488	.1488	.1489	.1483
Avg	2.0269	1.4163	1.0569	.9554	.3045	.7049	.9981

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

MULSHI[057]

BU 0850

Substation No/ Name :- 213331 / 22 KV BHARE SWITCHING

Feeder No / Name : 305 / Rihe Mix

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6541	2.5974	2.6487	2.9317	3.1493	2.6919	3.1719
2	2.5491	2.5273	2.5151	2.7242	3.0249	2.6187	2.8979
3	2.4442	2.5786	2.6121	2.7816	3.0274	1.7132	2.8791
4	2.5682	2.7043	2.6829	2.8255	3.0396	2.5242	2.934
5	3.056	3.1056	3.1026	3.2847	3.3099	2.8712	3.3341
6	3.8879	3.8818	3.6616	4.1074	3.9845	3.6591	4.2715
7	4.621	4.524	4.6514	5.0289	4.8765	4.6777	5.1686
8	4.9136	4.907	5.0155	5.2052	5.3589	5.2374	3.6458
9	4.5403	4.348	4.9436	5.0076	5.1636	4.6224	5.149
10	4.091	3.7909	4.7117	5.0698	4.8184	4.702	5.1839
11	3.8732	3.6122	4.6642	1.4297	4.4318	4.86	4.8301
12	3.955	3.5629	3.4318	2.9995	4.086	4.76	4.8418
13	3.7506	3.4836	4.0165	4.3556	3.8537	4.5019	4.5337
14	3.0195	3.3629	3.9812	2.9691	3.7732	4.7551	3.0636
15	3.4958	3.1902	3.9721	2.9355	3.6665	4.6721	
16	3.669	3.2389	4.2837	4.2819	3.6543	4.5227	
17	3.9599	3.3853	4.2434	4.3891	3.6561	4.5984	
18	3.7402	3.2408	4.0884	4.4232	3.4798	4.6807	4.1589
19	4.2868	3.8336	4.6838	4.9778	4.2758	4.8052	4.91
20	4.4988	4.3391	3.3227	5.4381	4.508	5.368	5.1539
21	4.222	4.0432	4.2739	5.0643	4.5049	5.1161	4.938
22	3.8738	3.7419	4.3208	4.666	4.1098	4.5471	3.1398
23	3.2413	3.1999	3.6749	4.0488	3.4047	3.8159	2.5179
24	2.7346	2.6705	3.1115	3.4889	3.1127	3.1486	3.0297
Max	4.9136	4.907	5.0155	5.4381	5.3589	5.368	5.1839
Min	2.4442	2.5273	2.5151	1.4297	3.0249	1.7132	2.5179
Avg	3.6519	3.4946	3.8589	3.9348	3.9279	4.1446	3.9882

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

MULSHI[057]

BU 0850

Substation No/ Name :- 213338 / 22kV Khanapur Switching

Feeder No / Name : 301 / KUDAJE

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6797	.6797	.8165	.668	.8307	.8307	.668
2	.5664	.5664	.7794	.668	.944	.944	.5938
3	.6797	.7175	.7423	.6309	1.0573	1.0573	.7423
4	.8307	.8307	.668	.7052	1.1706	1.1706	.8165
5	.944	.944	.8907	.7423	1.2839	1.2839	.8907
6	1.1328	.9818	1.1876	.9649	1.3972	1.3972	1.1134
7	1.3594	1.2461	1.4103	1.3361	1.5104	1.4727	1.4845
8	1.4349	1.2839	1.4845	1.3361	1.4727	1.5482	
9	1.2461	1.0763	1.2247	1.4349	1.3216	1.2247	1.3973
10	1.2839	1.1134	1.3361	1.2839	1.2084	1.1876	1.3746
11	1.2839	1.1876	1.299	1.3972		1.2247	1.4578
12	1.2084	1.2619	1.2619	1.2839		1.299	1.3785
13	1.1328	1.1134	1.1505	1.2084	1.3594	1.299	1.3059
14	1.1706	1.0763	1.2619	1.1706	1.4727	1.2247	1.3563
15	1.1328	1.1505	1.299	1.3216	1.4727	1.299	1.3577
16	1.1328		1.4103	1.3594	1.4349	1.299	1.3944
17	1.1706	1.2247	1.2619	1.3594	1.3972	1.2619	1.2963
18	1.1328	1.2619	1.3361	1.3216	1.3972	1.3361	1.3549
19	1.1706	1.2247	1.3361	1.3216	1.3594	1.2774	1.4444
20	1.1328	1.2247	1.2247	1.2461	1.2839	1.299	1.3196
21	1.0951	1.1505	1.0763	1.1706	1.2461	1.1505	1.2096
22	.9063	1.0763	1.0021	1.0951	1.0951	1.0021	.7722
23	.793	.9278	.8165	.9063	.9818	.8536	.6928
24	.7552	.7552	1.2619	.7088	.8307	.8307	.7423
Max	1.4349	1.2839	1.4845	1.4349	1.5104	1.5482	1.4845
Min	.5664	.5664	.668	.6309	.8307	.8307	.5938
Avg	1.0573	1.0468	1.1474	1.1100	1.2513	1.1989	1.1376

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

MULSHI[057]

BU 0850

Substation No/ Name :- 213338 / 22kV Khanapur Switching

Feeder No / Name : 302 / Donje

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0434	1.0434	1.0041	1.1901	1.1925	.9316	.8925
2	.9316	.9316	.9669	1.1157	1.267	1.0434	.8182
3	.8198	1.0062	.8925	1.0413	1.3416	1.118	.7438
4	1.0062	1.1925	.8182	1.1157	1.4161	1.2298	.8925
5	1.1925	1.3043	1.0413	1.1901	1.4906	1.3788	1.0413
6	1.3788	1.4906	1.4504		1.5652	1.4906	1.4132
7	1.677	1.5652	1.6363		1.5652	1.5652	1.6363
8	1.677	1.5652	1.562		1.677	1.5279	
9	1.4906	1.4876	1.4876	1.7142	1.5652	1.4504	1.5926
10	1.4906	1.4504	1.5248	1.5279	1.6024	1.4504	1.5396
11	1.4906	1.3016	1.4876	1.3788	1.5652	1.3388	1.5219
12	1.4906	1.4132	1.4876		1.5279	1.4132	1.4678
13	.9689	1.3388	1.2273	1.5652	1.6024	1.2644	1.4016
14	1.2298	1.3388	1.376	1.5652	1.5279	1.0785	1.2963
15	1.3043	1.2273	1.4132	1.4906	1.5652	1.1901	1.4016
16	1.3788		1.5248	1.5279	1.4906	1.4504	1.4281
17	1.5652	1.376	1.5991	1.4534	1.4906	1.4132	1.5726
18	1.4906	1.376	1.5248	1.5279	1.4906	1.4876	1.4662
19	1.6024	1.4132	1.5991	1.5279	1.6397	1.5248	1.5991
20	1.5652	1.4504	1.562	1.5279	1.5652	1.562	1.4723
21	1.4161	1.3388	1.4132	1.4161	1.5279	1.4132	1.3237
22	1.3416	1.2644	1.3016	1.3788	1.3416	1.1901	1.1779
23	1.1552	1.0785	1.2273	1.2298	1.1552	1.0413	1.1767
24	1.0807	1.118	1.0413	1.5652	1.1925	.9316	.9669
Max	1.677	1.5652	1.6363	1.7142	1.677	1.5652	1.6363
Min	.8198	.9316	.8182	1.0413	1.1552	.9316	.7438
Avg	1.3245	1.3075	1.3404	1.4025	1.4736	1.3119	1.2975

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

MULSHI[057]

BU 0850

Substation No/ Name :- 213338 / 22kV Khanapur Switching

Feeder No / Name : 303 / Osade

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4952	1.1214	1.1191		1.1962	1.0093	1.1191
2	1.3083	1.0466	1.0445		1.3083	1.1214	1.0445
3	1.1962	.9345	1.0072		1.4204	1.2709	.9699
4	1.3831	1.1214	1.1191		1.5326	1.4204	.8953
5	1.4998	1.3831	1.2683		1.6073	1.57	1.1191
6	1.7195	1.6447	1.6414		1.6447	1.6821	1.6041
7	1.9064	1.9064	1.6414		1.6821	1.7942	1.8279
8	1.6447	1.7195	1.6787		1.6447	1.57	
9	1.8316	1.6414	1.6787	1.7195	1.4952	1.716	1.6512
10	1.9811	1.7533	1.716	1.7569	1.3831	1.6414	1.5961
11	1.9438	1.6414	1.6414	1.6821	1.2335	1.6414	1.8404
12	1.7569	1.7906	1.9025	1.6447	1.1214	1.5668	1.73
13	1.7569	1.4922	1.6041	1.5326	1.0093	1.4922	1.4146
14	1.6447	1.6414	1.5668	1.4578	1.0466	1.6787	1.5045
15	1.869	1.4922	1.5668	1.5326	1.0466	1.716	1.4754
16	1.57		1.5295	1.4952	1.1588	1.231	1.3375
17	1.57	1.4548	1.4922	1.3831	1.1214	.5969	1.2843
18	1.5326	1.5668	1.5668	1.57	1.084	1.8279	1.8831
19	1.7569	.8953	1.7906		1.3457	1.7906	1.8714
20	1.8316	1.9398	2.0144	1.7942	1.3831	1.9771	1.7705
21	1.6821	1.4548	1.6787	1.6821	1.5326	1.716	1.5811
22	1.3457	1.5295	1.5668	1.4578	1.2709	1.5295	1.4966
23	1.2335	1.231	1.3802	1.2335	1.1214	1.2683	1.3224
24	1.57	1.1962	1.1937	1.0445	1.1962	1.0093	1.1564
Max	1.9811	1.9398	2.0144	1.7942	1.6821	1.9771	1.8831
Min	1.1962	.8953	1.0072	1.0445	1.0093	.5969	.8953
Avg	1.6262	1.4608	1.5170	1.5324	1.3161	1.4932	1.4563

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

MULSHI[057]

BU 0850

Substation No/ Name :- 213428 / KOLATE PATIL SWITCHING

Feeder No / Name : 301 / 22 KV KASARSAI

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	16-MAR-17	17-MAR-17	18-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		5.0926	5.2812		5.2435
2		5.2058	5.0926		5.0926
3		5.2812	5.2435		5.2812
4		5.4698	5.3567		5.1303
5		6.0734	6.0357		5.9602
6		7.7332	6.941		7.2805
7		8.4499	7.8841		7.7709
8		9.0535	8.2613		8.2991
9	8.5631	9.2044	7.9595		8.3745
10	8.1859	8.9781		8.3745	8.6763
11	8.0727	8.7894		4.8663	8.251
12	7.6955	8.7517		7.8841	7.937
13	7.9973	8.2613		7.8087	7.5476
14	2.0748	7.5069			7.3937
15	2.3011	7.6955		7.9595	7.2805
16	2.2634	7.5069		5.1303	7.2805
17	2.3388	7.4314		7.5884	8.0533
18	2.0748	2.0748		7.7709	7.6955
19	2.5652	8.6386		8.6008	8.1859
20	8.1859	7.8464		8.1104	7.5823
21	7.8464	7.6955		7.7709	7.1704
22	7.0919	6.8279		6.8279	6.7147
23	5.998	5.8471		5.9602	5.6962
24	5.3944	5.4321		5.5453	5.4698
Max	8.5631	9.2044	8.2613	8.6008	8.6763
Min	2.0748	2.0748	5.0926	4.8663	5.0926
Avg	5.5406	7.1186	6.4506	7.1570	7.0570

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

MULSHI[057]

BU 0850

Substation No/ Name :- 213428 / KOLATE PATIL SWITCHING

Feeder No / Name : 302 / KOLATE PATIL R2 SECTOR

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5822	.5487	1.1325	1.1752	.5944	.6005	1.2133
2	.5274	.503	1.035	1.1203	.5609	.567	1.1828
3	.4969	.4877	1.0106	1.0868	.5274	.5548	1.1142
4	.506	.4938	1.0487	1.1691	.5396	.5487	1.1005
5	.503	.4938	1.0609	1.1371	.5304	.5426	1.0563
6	.5121	.506	1.0898	1.0578	.5121	.5761	1.2697
7	.5639	.5335	1.1858	1.1934	.5365	.5792	1.2407
8	.5609	.6066	1.2956	1.3001	.5456	.7164	1.1904
9	.6828	1.5364	1.4144	1.2453	.628	.7225	1.3642
10	.7103	1.4586	1.4114	.6401	.6645	1.5074	1.4358
11	.7011	1.4023	1.4373	.692	.7133	1.3093	1.3733
12	.6523	1.3565	1.323	.695	.7072	1.2072	1.4084
13	.628	1.3642	1.256	.7407	.7103	1.23	1.3382
14	.6066	1.1477	1.3367	.6523	.7712	8.5162	1.1447
15	.5274	.9937	1.1188	.6158	.692	1.2117	1.0974
16	.4938	1.0471	1.1157	.6066	.6005	1.0822	1.1797
17	.5091	1.1188	1.0761	.6127	.6554	1.0822	1.0455
18	.5517	.9998	1.0578	.5609	.6493	1.0548	.9693
19	.6615	1.4114	1.6522	.6828	.7011	1.3657	1.5455
20	.7133	1.5409	1.701	.8566	.8291	1.5714	1.5242
21	.692	1.5409	1.4663	.7895	.7346	1.547	1.4739
22	.6706	1.4465	1.4846	.7804	.7255	1.6202	1.4906
23	.6706	1.3489	1.3443	.692	.692	1.576	1.4251
24	.57	1.1371	1.2209	.628	.6584	1.384	1.2773
Max	.7133	1.5409	1.701	1.3001	.8291	8.5162	1.5455
Min	.4938	.4877	1.0106	.5609	.5121	.5426	.9693
Avg	.5956	1.0427	1.2615	.8638	.6450	1.3614	1.2692

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

NASARAPUR[058]

BU 0868

Substation No/ Name :- 214453 / 33 KV KHED SHIVAPUR

Feeder No / Name : 301 / Katraj -Nasarapur-

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	7.6341	7.939	5.8489	5.7918	8.4324	7.6341	7.939
2	7.3293	7.4455	5.5441	5.1821	7.939	7.6341	7.4455
3	7.1407	7.6341	5.3555	5.1821	7.6341	7.4455	7.1407
4	7.1407	7.3293	5.3555	5.1821	7.1407	7.3293	7.1407
5	7.0245	7.3293	5.7328	4.8773	7.3293	7.3293	7.3293
6	7.7065	7.5179	5.5441	5.1821	7.8227	7.5179	8.3162
7	9.1869	8.8096	7.0245	6.0966	8.8096	8.8096	9.4917
8	9.7966	9.1144	8.5048	7.0111	9.608	9.608	10.4062
9	11.9589	9.3031	10.972	11.9589	10.3624	11.0883	11.2769
10	13.9766	10.29	13.6718	14.5424	13.7441	14.049	15.2244
11	14.8472	10.2176	14.3976	15.6455	15.4569	14.6586	16.9372
12	15.2683	9.4193	14.2814	15.1959	15.0797	14.5863	16.8648
13	13.8318	8.9258	13.5993	14.3976	13.5269	13.4107	13.9918
14	12.2637	8.1276	12.2637	8.5353	12.4524	7.9256	11.9589
15	13.6718	7.0682	13.2945	13.9766	13.3669	9.145	14.7749
16	14.1652	5.5441	13.9766	14.6586	13.6718	14.47	15.1521
17	14.6586	6.0376	13.7879	15.2683	12.9173	14.47	15.6455
18	14.3976	8.1276	12.801	14.209	12.3076	9.7546	15.7617
19	13.2945	8.5048	12.9896	13.7879	12.38	9.145	14.8911
20	12.3076	9.1144	12.6124	13.1059	12.3076	9.145	13.2945
21	11.1321	8.1276	11.8142	12.119	10.9434	11.8142	12.119
22	10.0289	7.4455	10.5225	10.7111	10.0289	10.2176	10.7111
23	8.9258	6.6473	9.5355	9.7241	9.2307	10.0289	10.2176
24	8.4324	6.9082	8.2876	6.4015	8.621	8.7372	9.3469
Max	15.2683	10.29	14.3976	15.6455	15.4569	14.6586	16.9372
Min	7.0245	5.5441	5.3555	4.8773	7.1407	7.3293	7.1407
Avg	11.0883	8.0387	10.3216	10.3643	10.8797	10.2481	11.8074

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

NASARAPUR[058]

BU 0868

Substation No/ Name :- 214453 / 33 KV KHED SHIVAPUR

Feeder No / Name : 302 / Kalyan

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3948	2.0729	1.9014	1.5242	2.3948	2.0729	2.7721
2	2.09	2.0729	1.5965	1.5242	2.09	2.0729	2.4673
3	2.09	2.0729	1.7851	1.5242	2.2787	2.0729	2.2787
4	2.09	2.2558	1.7851	1.5242	2.2787	2.0729	2.2787
5	2.3948	2.5606	1.9738	1.5242	2.4673	2.2329	2.4673
6	2.7721	2.8654	2.5835	1.829	2.9607	2.7435	2.7721
7	3.5704	2.7435	3.3818	2.4387	3.759	3.8409	4.0638
8	4.5572	3.658	4.0638	3.0483	4.0638	4.5115	4.3686
9	4.8164	3.9914	4.2524	4.7458	4.6944	4.6735	4.5267
10	4.6335	3.498	5.0507	5.0507	4.8164	5.0507	4.8316
11	4.8164	3.1932	5.3555	4.8621	4.9383	5.5441	5.506
12	4.6335	2.6996	4.8621	4.8621	4.6335	3.658	5.1364
13	4.2677	2.6996	4.8621	4.4849	3.9628	2.7435	4.462
14	3.658	2.3948	4.2524	2.4387	3.719	2.7435	4.0371
15	4.1457	2.3948	4.3686	4.0638	4.0238	3.0483	4.2219
16	4.5115	2.3948	4.5572	4.5572	4.1457	4.5572	4.2219
17	4.9383	2.6996	5.0507	4.8621	4.2677	4.8621	4.8316
18	4.9383	3.0045	5.3555	4.8621	3.9628	3.658	5.1364
19	4.9383	3.0769	5.3555	5.1669	4.8164	3.3532	5.1364
20	4.4506	3.498	5.3555	4.8621	3.8409	3.658	4.6468
21	4.3286	3.1932	4.5572	4.3686	3.658	4.18	4.1571
22	3.8409	2.8159	4.0638	4.0638	3.3532	3.6866	3.6675
23	3.1703	2.3948	3.1932	3.5704	2.8654	3.3818	3.1703
24	2.5835	2.2558	2.3948	1.829	3.1493	2.5606	2.5835
Max	4.9383	3.9914	5.3555	5.1669	4.9383	5.5441	5.506
Min	2.09	2.0729	1.5965	1.5242	2.09	2.0729	2.2787
Avg	3.7763	2.7711	3.8316	3.4828	3.6309	3.4575	3.9059

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

NASARAPUR[058]

BU 0868

Substation No/ Name :- 214453 / 33 KV KHED SHIVAPUR

Feeder No / Name : 303 / Shivare

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9869	.9869	.9869	.9145	1.2917	.9755	.9869
2	.9869	.9755	.9869	.6097	1.2917	.9755	.9869
3	.9869	.9755	.9869	.6097	.9869	.9755	.9869
4	.9869	.9755	.9869	.6097	.9869	.9755	.9869
5	.9869	.9755	.9869	.6097	.9869	.9755	.9869
6	1.4803	1.4632	1.4803	.9145	1.4803	1.4632	1.4803
7	1.9738	1.9509	1.9738	1.2193	1.7851	1.9509	1.9738
8	1.9738	1.9509	1.9738	1.2193	1.9738	1.9509	2.2787
9	2.2558	1.9738	2.2787	2.2787	1.9509	2.2787	2.2634
10	2.0729	2.2787	2.2787	2.2787	2.2558	2.2787	2.2634
11	1.6461	2.2787	1.7851	2.2787	2.2558	1.9738	1.9509
12	1.768	1.9738	1.7851	2.2787	2.2558	1.9738	1.9509
13	1.768	1.7851	1.7851	1.7851	2.0729	1.9738	1.5851
14	1.768	1.7851	1.7851	1.2193	1.768	1.2193	1.768
15	1.768	1.7851	1.7851	1.7851	1.4632	1.2193	1.768
16	1.0364	1.9738	1.7851	1.9738	1.4632	1.9738	1.768
17	1.9509	1.9738	1.7851	2.2787	1.768	2.2787	1.9509
18	1.9509	1.9738	1.9738	2.2787	1.9509	1.5242	2.2558
19	2.2558	1.9738	1.9738	2.2787	1.9509	1.5242	2.2558
20	2.2558	1.7851	2.2787	2.2787	1.9509	1.5242	2.2558
21	1.9509	1.7851	1.7851	2.2787	1.9509	1.9738	1.768
22	1.768	1.4803	1.7851	1.9738	1.768	1.7851	1.768
23	1.4632	1.2917	1.7851	1.7851	1.2803	1.7851	1.4632
24	1.2917	.9755	1.2917	.9145	1.4803	1.2803	1.2917
Max	2.2558	2.2787	2.2787	2.2787	2.2558	2.2787	2.2787
Min	.9869	.9755	.9869	.6097	.9869	.9755	.9869
Avg	1.6389	1.6386	1.6787	1.6105	1.6820	1.6171	1.7081

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

NASARAPUR[058]

BU 0868

Substation No/ Name :- 214453 / 33 KV KHED SHIVAPUR

Feeder No / Name : 304 / Kataraj Exp.

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9738	1.9738	2.09	1.2193	2.2787	2.9607	1.9738
2	1.9738	1.9738	2.09	1.2193	2.2787	3.2655	2.2787
3	1.7851	1.9738	2.09	1.2193	1.5242	2.9607	2.2787
4	1.9738	1.9738	1.7851	1.2193	2.2787	2.6559	2.2787
5	1.9738	1.9738	2.09	1.2193	2.2787	2.4673	1.9738
6	1.9738	1.9738	2.09	1.2193	1.7851	2.4673	1.9738
7	1.9738	1.9738	2.09	1.2193	2.2787	2.5835	1.9738
8	2.9607	1.7851	2.2787	1.5242	3.344	3.3379	3.0331
9	3.2655	1.7851	2.6559	2.4673	4.0638	5.5441	3.9914
10	4.9344	1.4803	2.9607	3.7151	3.8752	6.7196	4.2524
11	4.6735	1.4803	3.8313	4.4125	3.9476	6.5024	4.9059
12	5.0069	1.4803	4.4849	3.0769	3.9476	5.0507	3.3818
13	4.7173	1.4803	3.1493	2.2787	4.6296	7.5179	2.7721
14	3.3818	1.4803	3.8752	2.7435	4.7897	5.1821	3.0769
15	2.5835	1.4803	3.9476	3.8028	2.8883	2.7435	3.0769
16	2.4673	1.4803	4.2524	3.0769	3.0769	2.7721	3.0769
17	2.8883	1.4803	3.3818	2.7721	2.5835	2.7721	3.0769
18	2.2787	1.4803	2.7721	2.5835	2.7721	1.829	2.5835
19	2.2787	1.7851	2.4673	2.2787	2.5835	1.5242	2.2787
20	2.2787	1.9738	2.5835	2.7721	2.2787	1.5242	2.2787
21	2.2787	1.7851	2.4673	3.2655	2.4673	2.2787	2.2787
22	2.4673	1.9738	2.5835	3.3818	2.2787	2.2787	2.7721
23	2.5835	1.9738	2.4673	3.4541	2.4673	2.2787	2.4673
24	1.9738	1.9738	2.09	2.4387	2.8883	2.4673	2.2787
Max	5.0069	1.9738	4.4849	4.4125	4.7897	7.5179	4.9059
Min	1.7851	1.4803	1.7851	1.2193	1.5242	1.5242	1.9738
Avg	2.7769	1.7573	2.7739	2.4408	2.8994	3.4035	2.7631

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

NASARAPUR[058]

BU 0868

Substation No/ Name :- 214453 / 33 KV KHED SHIVAPUR

Feeder No / Name : 305 / RASIA EXP

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4934	.4934	.341	.3048	.341	.341	.4934
2	.4934	.341	.341	.1524	.341	.341	.4934
3	.4934	.341	.341	.1524	.341	.341	.4934
4	.341	.341	.341	.1524	.341	.341	.341
5	.4934	.341	.341	.1524	.2278	.341	.4934
6	.4934	.341	.341	.1524	.341	.341	.4934
7	.4934	.4934	.341	.3048	.4934	.4934	.4934
8	.4934	.341	.4934	.3048	.4934	.4934	.4934
9	.8382	.341	.8344	.6458	.8344	.6458	.6477
10	.9907	.341	.8344	.6458	.9869	.8344	.8382
11	.9907	.341	.9869	.9869	.9869	.9869	.9869
12	.9907	.341	.9869	.7983	.9869	.9869	.7983
13	.9907	.341	.9869	.8344	.7983	.7983	.6458
14	1.1431	.341	.9869	.4572	.7983	.6097	.6458
15	.9869	.341	.9869	.9869	.9869	.6097	.6458
16	.9869	.341	.9869	.7983	.9869	.9869	.6458
17	.9907	.341	.7983	.6458	.7983	.7983	.6458
18	.6477	.341	.6458	.6458	.4934	.4572	.6458
19	.4953	.341	.4934	.4934	.4934	.3048	.4934
20	.4953	.341	.4934	.4934	.4934	.3048	.4934
21	.4934	.341	.4934	.4934	.341	.4934	.4934
22	.4934	.341	.4934	.4934	.341	.4934	.4934
23	.4953	.2656	.4934	.4934	.341	.4934	.4934
24	.341	.341	.4934	.1524	.341	.4934	.4934
Max	1.1431	.4934	.9869	.9869	.9869	.9869	.9869
Min	.341	.2656	.341	.1524	.2278	.3048	.341
Avg	.6735	.3506	.6198	.4892	.5803	.5554	.5792

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

NASARAPUR[058]

BU 0868

Substation No/ Name :- 214453 / 33 KV KHED SHIVAPUR

Feeder No / Name : 306 / STAR EXP.

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9869	.9869	.9869	.6097	.9869	.9869	.9869
2	.9869	.9869	.9869	.6097	.9869	.9869	.9869
3	.9869	.9869	.9869	.6097	.9869	.9869	.9869
4	.9869	.9869	.9869	.6097	.9869	.9869	.9869
5	.9869	.9869	.9869	.6097	.9869	.9869	.9869
6	.9869	.9869	.9869	.6097	.9869	.9869	.9869
7	.9869	.9869	.6097	.6097	.9869	.9869	.9869
8	.9869	.9869	.9869	.6097	.9869	.9869	.9869
9	.9869	.9869	.9869	.9869	.9869	1.1755	1.4861
10	1.4803	.9869	1.2917	1.4803	.9869	1.4803	1.4861
11	1.4803	.9869	1.4803	1.4803	.9869	1.4803	1.4861
12	1.4803	.9869	1.2917	1.2917	.9869	1.2917	1.4861
13	1.4803	.9869	1.4803	1.4803	.9869	1.4803	1.4861
14	1.4803	.9869	1.4803	.9145	.9869	.9145	1.6766
15	1.4803	.9869	1.4803	1.4803	1.2917	.9145	1.6766
16	1.4803	.9869	1.4803	1.4803	1.2917	1.4803	1.7909
17	1.4803	.9869	1.2917	1.4803	.9869	1.2917	1.2955
18	1.2917	.9869	.9869	1.2917	.9869	.9145	.9907
19	.9869	.9869	.9869	.9869	.9869	.6097	.9907
20	.9869	.9869	.9869	.9869	.9869	.6097	.9907
21	.9869	.9869	.9869	.9869	.9869	.9869	.9907
22	.9869	.9869	.9869	.9869	.9869	.9869	.9907
23	.9869	.9869	.9869	.9869	.9869	1.1755	.9907
24	.9869	.9869	.9869	.9145	.9869	1.2917	1.2917
Max	1.4803	.9869	1.4803	1.4803	1.2917	1.4803	1.7909
Min	.9869	.9869	.6097	.6097	.9869	.6097	.9869
Avg	1.1641	.9869	1.1121	1.0039	1.0123	1.0825	1.2084

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

NASARAPUR[058]

BU 0868

Substation No/ Name :- 214453 / 33 KV KHED SHIVAPUR

Feeder No / Name : 307 / 22 kV Desai Exp.

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 22 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1065	1.3854	1.3831	1.0425	1.3039	1.2848	1.3862
2	1.3953	1.3397	1.3816	1.0014	1.2216	1.2406	1.3313
3	1.2597	1.2223	1.0021	.8612	1.2384	1.23	1.3039
4	1.2765	1.2086	.9975	.8383	1.2262	1.2345	1.2582
5	1.4822	1.2589	1.4548	1.105	1.3847	1.3961	1.4441
6	1.3176	1.2498	1.3328	.9633	1.2826	1.3168	1.3466
7	1.3481	1.2696	1.2338	.8916	1.3481	1.3793	1.6038
8	2.2162	1.3473	2.2406	1.1706	1.6449	1.9799	2.3274
9	2.4295	1.4197	2.4341	1.9269	1.8306	2.6033	2.4509
10	2.7237	1.3466	2.8681	1.8933	1.9723	2.8864	2.8334
11	2.9188	1.5519	2.8834	2.1872	2.2588	2.8788	2.9736
12	2.6841	1.377	2.5149	2.0077	2.1232	2.5728	2.6551
13	2.7252	1.3572	2.3838	1.9086	2.0927	2.7645	2.5926
14	2.5591	1.3816	2.521	1.4967	1.954	1.9921	2.8243
15	2.5576	1.1515	2.5195	2.058	1.9952	1.832	2.5682
16	2.3548	1.342	2.3899	1.7836	1.765	2.4433	2.3381
17	2.0927	1.3176	2.1247	1.7485	1.6842	2.3366	2.2512
18	1.9251	1.31	1.9314	1.744	1.7147	1.3977	1.9266
19	1.9159	1.3024	1.8949	1.7943	1.7086	1.3169	2.1811
20	1.8732	1.3344	1.9314	1.8034	1.6599	1.3138	2.2101
21	1.829	1.3359	1.872	1.4624	1.3961	1.8248	1.8473
22	1.8077	1.2749	1.8735	1.6236	1.6294	1.7912	1.8687
23	1.7742	1.2826	1.7867	1.6327	1.5897	1.7592	1.9296
24	1.7607	1.5349	1.5218	.9816	1.3313	1.5424	1.7672
Max	2.9188	1.5519	2.8834	2.1872	2.2588	2.8864	2.9736
Min	1.1065	1.1515	.9975	.8383	1.2216	1.23	1.2582
Avg	1.9722	1.3292	1.9366	1.4969	1.6398	1.8466	2.0508

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

NASARAPUR[058]

BU 0868

Substation No/ Name :- 214469 / 33 KV PABE

Feeder No / Name : 201 / Ghisar

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1017	.1284	.1395	.1269	.1223	.1364	.1833
2	.0907	.1116	.1181	.112	.1059	.1231	.1654
3	.0857	.0991	.1128	.1075	.101	.093	.1638
4	.0834	.1006	.1094	.1006	.1052	.088	.1623
5	.0907	.1288	.1269	.096	.1033	.0926	.1898
6	.0953	.1532	.1395	.1189	.1204	.1246	.2433
7	.1711	.2462	.1936	.1821	.1764	.1966	.3877
8	.2149	.2656	.2309	.2202	.2195	.2301	.3805
9	.2069	.2606	.2854	.216	.2359	.1738	.3384
10	.1997	.2561	.2789	.2244	.2423	.1833	.3845
11	.1654	.2282	.2423	.2374	.2046	.2077	.3883
12	.1463	.2431	.1749	.2446	.189	.2202	.3391
13	.1372	.2427	.1696	.1875	.1917	.2073	.3
14	.1071	.165	.1517	.1494	.1677	.1833	.2831
15	.1162	.1578	.1299	.1345	.1391	.1627	.2798
16	.1166	.1589	.1414	.1357	.1669	.1467	.3151
17	.1517	.1879	.136	.1604	.1753	.1593	.3117
18	.1776	.1917	.1429	.1612	.1635	.3985	.4184
19	.2191	.2477	.1543	.1475	.1833	.5157	.4561
20	.3814	.3608	.3064	.3144	.3185	.7319	.6506
21	.3452	.3448	.3105	.3136	.3387	.6891	.6432
22	.3315	.3117	.306	.2831	.3064	.5805	.5167
23	.2442	.2481	.2515	.2305	.237	.3705	.3477
24	.1654	.176	.1665	.1589	.1654	.1638	.2256
Max	.3814	.3608	.3105	.3144	.3387	.7319	.6506
Min	.0834	.0991	.1094	.096	.101	.088	.1623
Avg	.1727	.2089	.1883	.1818	.1866	.2574	.3364

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

NASARAPUR[058]

BU 0868

Substation No/ Name :- 214469 / 33 KV PABE

Feeder No / Name : 202 / Velha

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2427
2				.2263
3				.2587
4				.2614
5				.2743
6				.3841
7		.0107		.4851
8		.0518	.0427	.6182
9		.0556	.0492	.7121
10		.0674	.0499	.6589
11		.0644	.0553	.5296
12		.0633	.0594	.7457
13		.0617	.0621	.6241
14		.0587	.0556	.6386
15		.0587	.0541	.6266
16		.053	.0526	.6733
17		.0568	.053	.6916
18		.056	.682	.6847
19	.0526	.0545	.7899	.7198
20	.0625	.0541	.7007	.6255
21	.0606	.0507	.6801	.6057
22	.0533	.0453	.5927	.5914
23	.0453	.0091	.423	.4325
24				.3292
Max	.0625	.0674	.7899	.7457
Min	.0453	.0091	.0427	.2263
Avg	.0549	.0513	.2751	.5267

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

NASARAPUR[058]

BU 0868

Substation No/ Name :- 214469 / 33 KV PABE

Feeder No / Name : 203 / 11 KV Margasani (AG)

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.7342	3.315	3.0483	2.8197	2.1338	3.2388	
2	3.5818	3.3532	3.0483	2.7054	2.0957	3.2388	
3	3.5818	2.7435	3.1245	2.7435	1.9052	3.1626	
4	3.3913	2.6292	3.1245	2.4768	1.8671	3.1245	
5	3.6199	2.6673	2.934	2.4387	1.7528	2.9721	
6	3.8485	2.934	2.8578	2.4768	2.0195	3.2007	
7	4.3058	3.1245	4.1914	2.934	2.1719	3.3532	
8	4.5344	3.9247	3.9628	3.2007	2.9721	3.4675	
9	4.4582	3.7723	3.9628	3.315	3.1245	3.9247	1.3083
10						4.039	5.3727
11						4.763	7.2445
12						5.4108	6.7444
13						5.0297	6.8778
14						5.7918	6.6111
15						4.9154	5.3716
16						4.9154	5.9335
17						4.9535	5.506
18						1.0562	
23	.7621	.8383	.9907	.2667	.6097		
24	2.8959	3.0483	2.8197	1.9433	3.2007		
Max	4.5344	3.9247	4.1914	3.315	3.2007	5.7918	7.2445
Min	.7621	.8383	.9907	.2667	.6097	1.0562	1.3083
Avg	3.5194	2.9409	3.0968	2.4837	2.1685	3.9199	5.6633

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

NASARAPUR[058]

BU 0868

Substation No/ Name :- 214501 / 33/33 Shogini Switching

Stn.

Feeder No / Name : 401 / 33 KV Shogini Express.

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286			.6859		.2286	.2286
2	.2286			.6859		.2286	.2286
3	.2286			.6859		.2286	.2286
4	.2286			.6859		.2286	.2286
5	.2286			.6859	.2286	.2286	.2286
6	.2286			.6859	.2286	.2286	.2286
7	.6859	.2286	.6859	.9145	.6859	.6859	.6859
8	2.0576	.4572	2.0576	2.0576	2.0576	2.0576	2.0576
9	2.2862	.4572	2.2862	2.0576	2.2862	2.2862	2.2862
10	2.2862	.4572	2.2862	2.5149	2.5149	2.2862	2.5149
11	2.5149	.4572	2.5149	2.5149	2.5149	2.5149	2.5149
12	2.5149	.4572	2.2862	2.5149	2.5149	2.5149	2.5149
13	2.2862	.4572	2.2862	2.2862	2.2862	2.2862	2.2862
14	2.2862	.4572	2.2862	2.5149	2.2862	2.5149	2.5149
15	2.2862	.4572	2.2862	2.5149	2.2862	2.2862	2.5149
16	2.0576	.2286	2.2862	2.2862	2.2862	2.2862	2.2862
17	1.829	.2286	1.829	2.0576	1.829	1.829	2.2862
18	1.829	.2286	1.6004	2.0576	1.6004	1.829	2.0576
19	1.6004	.2286	1.3717	1.3717	1.3717	1.3717	1.6004
20	1.3717	.2286	1.3717	1.3717	1.3717	1.3717	1.3717
21	1.3717	.2286	1.3717	1.1431	1.1431	1.3717	1.3717
22	1.3717	.2286	1.3717	1.1431	1.1431	1.3717	1.3717
23	1.3717	.2286	1.1431	1.1431	1.1431	1.1431	1.3717
24	1.1431		1.1431	1.1431	1.1431	1.1431	1.1431
Max	2.5149	.4572	2.5149	2.5149	2.5149	2.5149	2.5149
Min	.2286	.2286	.6859	.6859	.2286	.2286	.2286
Avg	1.4384	.3362	1.8036	1.5718	1.6461	1.4384	1.5051

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

URALIKANCHAN[059]

BU 0876

Substation No/ Name :- 214494 / 33 KV/22 KV Koregaon Mul

Feeder No / Name : 301 / Urulikanchan

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1285	2.3152	1.9418	2.2514	2.4143	2.3152	2.3899
2	2.0538	2.2779	1.7924	2.2514	2.3388	2.2405	2.3285
3	2.1658	2.2405	1.9044	2.1821	2.452	2.1285	2.4025
4	2.2779	2.3152	2.1285	2.0782	2.5274	2.2779	2.4764
5	2.5766	2.5766	2.3152	2.2514	2.7538	2.3899	2.6612
6	3.2487	2.9127	2.6513	2.6324	3.1687	2.8753	3.2895
7		3.3981	3.2487	3.0134	3.0556	3.3981	3.3634
8	3.1367	3.2861	3.0994		3.3573	3.0994	3.1417
9	2.8006	3.0247	2.9874	2.7709	3.2819	2.6886	2.8753
10	2.6886	2.8753	2.5631	2.9047	3.0994	2.7633	3.131
11	2.6513	2.726	2.6324	2.8669	2.8753	2.846	3.0178
12	2.6513	2.6139	2.5285	2.7538	2.6139	2.7351	2.9801
13	2.5503	2.4646	2.3899		2.6139	2.846	2.7915
14	2.3285	2.4646	2.3206		2.4394	2.5133	2.7161
15	2.2546	2.4272	2.2514	2.0748	2.4764	2.5873	2.6406
16	2.2177	2.4272	2.1128	1.9993	2.6242	2.7721	2.6406
17	2.5133	2.4272	2.3899	1.9993	2.6612	2.8829	2.7161
18	3.0678	3.0247	2.7016	2.3011		3.0308	3.0933
19	3.4004	3.4355	3.1866	2.8959	3.6961	3.3634	3.7723
20	3.4374	3.4355	3.0827	3.9247	3.6961	3.4728	3.7346
21	3.1417	2.8753	2.8402	3.6591	3.4374	3.3981	3.4705
22	2.9127	2.6513	2.7016	3.3951	2.9938	3.0247	3.1687
23	2.5393	2.4272		2.8669	2.6242	2.8006	2.8669
24	2.2779	2.3152	2.1285	2.286	2.5652	2.3525	2.452
Max	3.4374	3.4355	3.2487	3.9247	3.6961	3.4728	3.7723
Min	2.0538	2.2405	1.7924	1.9993	2.3388	2.1285	2.3285
Avg	2.6531	2.7057	2.5173	2.6361	2.8594	2.7834	2.9217

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

URALIKANCHAN[059]

BU 0876

Substation No/ Name :- 214494 / 33 KV/22 KV Koregaon Mul

Feeder No / Name : 302 / Shindewadi

FEEDER SEPERATION/PURE AG

Feeder KV- 22 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			3.2388	3.4294	3.4294		
2			3.1626	3.5056	3.4294		
3			3.2769	3.5056	3.7342		
4			3.4294	3.5056	3.9247		
5			3.5437	3.658	3.9628		
6			3.6199	3.8866	4.1152		
7			3.9628	3.9628	4.1914		
8			4.039		4.3439		3.9232
9			4.3058	4.039	4.4201		
10	4.8285	4.4963				4.8773	5.3346
11	5.2058	4.6487				5.168	5.7918
12	5.0549	4.4963				4.6776	5.7156
13	4.9794	4.4963				4.8285	5.1059
14	4.8285	4.2676				4.8285	5.1821
15	4.7531	4.4201					4.8773
16	4.6022	.381					4.8392
17	3.3951	3.9628					4.1914
19						3.9232	
24			3.1245	3.4294	3.3532		
Max	5.2058	4.6487	4.3058	4.039	4.4201	5.168	5.7918
Min	3.3951	.381	3.1245	3.4294	3.3532	3.9232	3.9232
Avg	4.7059	3.8961	3.5703	3.658	3.8904	4.7172	4.9957

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

URALIKANCHAN[059]

BU 0876

Substation No/ Name :- 214494 / 33 KV/22 KV Koregaon Mul

Feeder No / Name : 303 / Peth

FEEDER SEPERATION/PURE AG

Feeder KV- 22 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3163					.253	.2926
2	.2846					.253	.2915
3	.2846					.253	.2267
4	.3163					.2846	.3563
5	.3479					.3163	.421
6	.6009					.3479	.7023
7						.6009	.7773
8	.7907					.8223	.9717
9	.6642					.506	.8779
10		.8855	.7945	.9877	.8539		
11		.8855	.9473	1.086	.9488		
12		.9804	.8862	.9511	.7888		
13		.8539	.764	.7964	.6009		
14		.759	.764	.7602	.5506		
15		.8539	.764	.6722	.4858		
16		.7274	.6112	.6516	.583		
17		.6325	.5501	.5853	.5506		
24	.3163					.2846	.3292
Max	.7907	.9804	.9473	1.086	.9488	.8223	.9717
Min	.2846	.6325	.5501	.5853	.4858	.253	.2267
Avg	.4358	.8223	.7602	.8113	.6703	.3922	.5247

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

URALIKANCHAN[059]

BU 0876

Substation No/ Name :- 214494 / 33 KV/22 KV Koregaon Mul

Feeder No / Name : 304 / ASHTAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0719	1.1104	1.1088	1.143	1.1317	1.2197	1.1104
2	1.0349	1.0745	1.2197	1.1084	1.0562	1.1088	1.1088
3	1.1827	1.1104	1.1458	1.143	1.1694	1.2567	1.1458
4	1.4045	1.182	1.2936	1.2469	1.358	1.4784	1.2197
5	1.5893	1.2894	1.4415	1.3855	1.5089	1.7372	1.3306
6	1.922	1.7551	1.6263	1.7318	1.7353	1.9959	1.7741
7		1.9342	1.885	1.8011	1.773	1.922	1.885
8	1.5154	1.576	1.6632		1.5684	1.4784	1.5154
9	1.1088	1.1827	1.5524	1.2123	1.3957	1.0349	1.2536
10	.9313	.961	1.0737	1.1203	1.0719	.924	1.0829
11	.8596	.924	1.0045	1.094	1.1088	.924	1.1203
12	.8238	.8501	1.0391	1.0562	1.0349	.961	1.0185
13		.8871	.9352	1.0185	1.0349	.924	1.1203
14		.8871	.9352	1.0185	.924	.8501	1.0562
15	.8501	.8501	.9005	1.0829	.8501	.924	1.0082
16	.8871	.8871	.8313	1.1317	.924	1.0719	1.0829
17	.924	.9979	.9352	1.094	.9979	.924	1.0456
18	1.0719	.9979	1.0391	1.1317		1.2197	1.1203
19	1.4784	1.4415	1.4547	1.6221	1.5154	1.4415	1.5466
20	1.5524	1.5154	.166	1.5844	1.5154	1.6476	1.5844
21	1.4415	1.4045	1.3855	1.4937	1.3676	1.4327	1.4335
22	1.3253	1.3443	1.2816	1.4712	1.3676	1.2894	1.419
23	1.2536	1.2936		1.3443	1.2936	1.2178	1.307
24	1.1458	1.2178	1.1827	1.143	1.2449	1.2567	1.182
Max	1.922	1.9342	1.885	1.8011	1.773	1.9959	1.885
Min	.8238	.8501	.166	1.0185	.8501	.8501	1.0082
Avg	1.2083	1.1948	1.1783	1.2686	1.2586	1.2600	1.2696

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

URALIKANCHAN[059]

BU 0876

Substation No/ Name :- 218034 / 220/22 KV THEUR

Feeder No / Name : 302 / WALT

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	14.5405	15.0892	15.455	15.5464	15.333	15.333	15.2416
2	14.0832	14.8148	15.0892	15.333	14.9673	15.1502	14.9977
3	14.0223	14.6624	14.6624	15.1806	14.7234	15.0282	14.7539
4	14.3576	15.0587	15.0892	15.333	14.7844	15.3026	15.1197
5	15.9427	16.1866	16.3695	16.4609	15.8208	16.6743	16.4609
6	18.4728	19.0825	19.0825	18.991	18.0765	19.3568	18.7777
7	21.9174	22.0394	22.3442	22.71	22.1613	22.2832	22.2832
8	23.0148	24.2341	***	***	***	22.9234	24.2951
9	***	***	***	***	***	***	***
10	***	***	***	***	***	***	***
11	***	***	***	***	***	***	***
12	***	***	***	***	***	***	***
13	***	***	***	22.3747	21.6736	***	19.875
14	24.8133	23.3501	21.1858	22.5881	22.6185	24.5999	21.1249
15	***	20.4847	22.8929	24.3561	22.8014	24.2037	22.6185
16	***	22.71	23.4721	24.9962	23.0758	24.1122	***
17	***	23.8683	24.2037	***	21.0639	24.6304	***
18	***	24.7828	24.8743	22.2527	22.3747	***	***
19	24.8438	24.0817	24.1122		23.2892	24.9657	24.7524
20	22.6185	22.771	22.6185		23.2587	23.9903	23.8074
21	20.5762	20.8505	20.3018	18.3204	21.3382	21.5211	20.9115
22	19.0215	19.4178	19.1434	17.9546	19.7836	19.4788	19.113
23	17.3145	17.7412	17.5583	17.0401	18.0765	17.9546	17.3754
24	15.7903	16.1256	16.1256	15.6379	16.3085	16.2475	15.9732
Max	29.4163	27.5568	28.9286	28.136	28.0445	28.9286	29.5382
Min	14.0223	14.6624	14.6624	15.1806	14.7234	15.0282	14.7539
Avg	22.0216	21.2608	21.7510	21.2454	21.1261	21.8768	21.6266

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

PUNE DIVISION[514]

URALIKANCHAN[059]

BU 0876

Substation No/ Name :- 218034 / 220/22 KV THEUR

Feeder No / Name : 304 / Naigaon

FEEDER SEPERATION/PURE AG

Feeder KV- 22 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			16.1866	15.7598	15.5464		
2			15.9732	15.7293	15.8208		
3			15.5159	15.4245	15.6684		
4			15.5159	15.3026	14.4186		
5			15.7598	15.3635	14.4795		
6			16.5829	15.9427	14.9977		
7			18.3814	17.8632	16.9791		
8			21.8565	22.1003	20.6066		
9			22.771	23.5025	21.3992		
10	23.1977	22.6795	13.6565	13.9613	13.8089	20.942	22.5576
11	***	***				23.4416	***
12	22.8014	***				***	***
13	23.8988	24.5695				***	24.417
14	24.0208	24.2646				24.8133	23.9293
15	23.9598	23.2282				23.9903	23.1672
16	23.8988	7.2245				24.0817	23.4721
17	23.9293	20.881				21.0334	23.8379
18	13.687	13.4126				12.8334	13.687
24		15.7598	15.1806	14.8758			
Max	25.6669	25.6669	22.771	23.5025	21.3992	26.3985	25.7888
Min	13.687	7.2245	13.6565	13.9613	13.8089	12.8334	13.687
Avg	22.7845	20.3293	17.0346	16.8932	16.3725	22.6389	22.9200

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

CHAKAN S/DN.[700]

BU 4700

Substation No/ Name :- 214488 / 33 / 22 KV SHEL PIMPALGAON

Feeder No / Name : 302 / 22 KV SHEL PIMPALGAON

GAOTHAN FEEDER

GFSSII Feeder KV- 22 /
OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6221	1.6766	2.0576	1.829	1.829	1.7528	1.7528
2	1.5844	1.6766	2.0576	2.1338	1.829	1.7528	1.7528
3	1.6598	1.7528	2.1338	2.1338	1.9052	1.829	1.829
4	1.8861	1.9052	2.3388	2.2634	2.2634	2.1125	2.1338
5	2.5652	2.6406	2.6406	2.6406	2.6406	2.5652	2.6406
6	3.3196	3.3608	3.4705	3.3608	3.3608	3.3608	3.4705
7	3.0178	3.8089	3.6214	3.5101	3.5101	3.5848	3.6214
8	3.0178	2.9424	2.4691	2.2699	2.9874	2.7161	2.7915
9	2.6406	2.1125	2.1262	.2008	2.3388	2.037	2.037
10	1.5775	1.7147	1.7833	1.7147	1.829	1.8107	1.7833
11	1.3032	1.5775	1.7147	1.4022	1.6766	1.8107	1.7147
12	1.0974	1.166	1.3032	.1219	1.5242	1.5089	1.4403
13	1.4403	1.7147	.144	1.2803	1.3717	1.7353	1.4403
14	1.7833	1.2346	1.5089	1.4022	1.3717	1.7353	1.5089
15	1.829	1.166	1.6461	1.166	1.2955	1.5089	1.2346
16	2.0576	1.3717	1.8519	1.2803	1.5242	1.8107	1.5775
17	1.3717	1.358	1.5775	1.448	1.5242	1.5089	1.4335
18	2.2634	1.5844	1.5242	2.3388	1.5242	1.2826	1.5089
19	2.4897	2.3388	2.3388	2.8669	2.2634	2.6406	2.4143
20	2.6406	2.7915	2.7915		2.7915	3.2442	3.0933
21	2.6406	2.6406	2.7161	2.6406	2.6406	2.7161	2.6406
22	2.4143	2.2634	2.4387	2.4143	2.4143	2.3388	2.4143
23	2.4143	2.3624	2.4143	1.9814	1.9814	2.0576	1.9814
24	2.1879	1.7528	2.0576	2.2634	1.9052	1.7528	1.7528
Max	3.3196	3.8089	3.6214	3.5101	3.5101	3.5848	3.6214
Min	1.0974	1.166	.144	.1219	1.2955	1.2826	1.2346
Avg	2.1177	2.0381	2.1136	1.9419	2.0959	2.1322	2.0820

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

CHAKAN S/DN.[700] BU 4700

Substation No/ Name :- 214488 / 33 / 22 KV SHEL PIMPALGAON

Feeder No / Name : 303 / 22 KV BHOSE

FEEDER SEPERATION/PURE AG

Feeder KV- 22 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9508						
2	2.9508						
3	2.6825						
4	2.9508						
5	3.0178						
6	3.4202						
7	5.5662						
8	5.5662						
9	5.7004						
10	5.0755						
11		6.1728	5.5556	5.6242	5.1174	5.7674	5.487
12		6.1728	5.8299	5.6242	5.0526	5.365	5.7613
13		5.7613	5.2812	.4755	4.5992	1.2742	5.6927
14		1.3717	4.9383	5.144	4.4696	4.8956	5.4184
15		5.6242	4.5268	5.0069	4.4696	4.8285	5.2126
16		5.5556	5.2812	4.3286	4.4696	4.8956	5.2812
17		5.365	5.4184		3.2388	5.0297	5.365
18		4.7615	4.5992		3.8866	4.5603	4.6944
Max	5.7004	6.1728	5.8299	5.6242	5.1174	5.7674	5.7613
Min	2.6825	1.3717	4.5268	.4755	3.2388	1.2742	4.6944
Avg	3.9881	5.0981	5.1788	4.3672	4.4129	4.5770	5.3641

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

LONAVALA[060]

BU 0884

Substation No/ Name :- 213343 / 22/22 KV NANGARGAON SWT SS

Feeder No / Name : 301 / 22 KV VALVAN

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3395	.3086		.4115	.3086	.3086
2		.3018	.3086		.3086	.3086	.3086
3		.3018	.3086		.3086	.3086	.3086
4		.3018	.3086		.3086	.3086	.3086
5		.3772	.3086		.3086	.4115	.3086
6		.4527	.3086		.4115	.5144	.4115
7		.6036	.5144		.4115	.5144	.5144
8		.5658	.5144		.5144	.6173	.5144
9	.6337	.5885	.5144	.5772	.679	.5319	.6036
10	.4979	.4866	.4115	.5545	.5998	.4187	.4904
11	.4074	.4414	.4115	.3961	.5319	.415	.4527
12	.3961	.3735	.4115	.3848	.5281	.3395	.3772
13	.3848	.3169	.3086	.4187	.5281	.3395	.415
14	.2942	.3056	.3086	.3621	.3961	.3395	.3395
15	.3282	.3056	.3086	.3848	.4074	.3395	.3395
16	.3395	.3086	.3086	.3395	.3961	.3395	.3772
17	.3395	.3086	.3086	.415	.415	.3961	
18	.3395	.3086	.3086	.415	.415	.3961	
19	.4527	.4115	.3086	.5281	.4904	.4527	
20	.4904	.4115	.4115	.5281	.5281	.4904	
21	.4904	.4115	.7545	.5658	.5658	.4904	
22	.4527	.4115	.4527	.5144	.5144	.4115	
23	.3018	.4115	.415	.4115	.4115	.4115	.4115
24		.3169	.3086		.4115	.4115	.3086
Max	.6337	.6036	.7545	.5772	.679	.6173	.6036
Min	.2942	.3018	.3086	.3395	.3086	.3086	.3086
Avg	.4099	.3901	.3805	.4530	.4501	.4090	.3944

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

LONAVALA[060]

BU 0884

Substation No/ Name :- 213343 / 22/22 KV NANGARGAON SWT SS

Feeder No / Name : 302 / 22 KV WATER WORKS

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 22 / OUTGOING

UTILITY

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3018	.2058		.3117	.2058	.2058
2		.2641	.2058		.2058	.2058	.2058
3		.2641	.2058		.2058	.2058	.2058
4		.2263	.2058		.2058	.2058	.2058
5		.2263	.2058		.2058	.2058	.2058
6		.1886	.2058		.2058	.2058	.2058
7		.2641	.3086		.3086	.3086	.3086
8		.3772	.3086		.3086	.4115	.3086
9	.3056	.3961	.3086	.3848	.4187	.3961	.3395
10	.1584	.2603	.2058	.3056	.2829	.3056	.3018
11	.1811	.2603	.3086	.3735	.3508	.3018	.3772
12	.2603	.3056	.3086	.3735	.3395	.3772	.3395
13	.3056	.249	.2058	.3056	.3018	.2263	.3395
14	.2716	.3169	.3086	.3621	.3395	.3395	.3395
15	.3508	.2377	.3086	.3961	.3848	.8299	.3395
16	.3395	.3086	.3086	.3772	.3395	.3772	.3772
17	.3018	.3086	.3772	.3772	.3395	.3621	
18	.3018	.2058	.3395	.3395	.2263	.1207	
19	.3018	.2058	.3018	.415	.3018	.3395	
20	.2641	.2058	.3018	.3018	.2641	.2641	
21	.2641	.3086	.2641	.2641	.2641	.2641	
22	.3395	.3086	.3018	.3086	.2058	.3086	
23	.3018	.2058	.3018	.3086	.3086	.3086	.3086
24		.3018	.2058		.3086	.3086	.3086
Max	.3508	.3961	.3772	.415	.4187	.8299	.3772
Min	.1584	.1886	.2058	.2641	.2058	.1207	.2058
Avg	.2832	.2707	.2712	.3462	.2889	.3077	.2902

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

LONAVALA[060]

BU 0884

Substation No/ Name :- 213343 / 22/22 KV NANGARGAON SWT SS

Feeder No / Name : 303 / 22 KV BARA BUNGLOW

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6413	.6173		.7202	.6173	.6173
2		.6036	.7202		.7202	.0617	.6173
3		.6036	.6173		.6173	.6173	.6173
4		.6036	.6173		.7202	.7202	.6173
5		.6413	.7202		.7202	.7202	.6173
6		.7545	.6173		.7202	.7202	.7202
7		.8676	.6173		.7202	.7202	.7202
8		.7922	.7202		.823	.6173	.7202
9	.8488	.8261	.823	1.0185	.9054	.7922	.8299
10		.8827	.823	1.0185	.9846	.7809	.7922
11	.7582	.8035	.823	.9393	.9167	.8676	.8299
12	.8148	.8035	.7202	.8488	.9054	.8299	.7545
13	.7582	.8714	.7202	.6903	.8676	.7922	.7545
14	.7809		.7202	.7809	.8148	.7545	.7545
15	.7016	.7016	.7202	.9619	.8261		.7922
16	.7582	.7202	.7202	.9808	.8714	.7922	.7545
17	.7167	.7202	.8299	.8299	.7545	.894	
18	.679	.7202	.8676	.7167	.8299	.9016	
19	.8676	.7202	.9054		.9808	.9808	
20	.9054	.7202	.9808	1.094	.9808	.9808	
21	.8676	.823	.9808	1.0562	.9808	.9054	
22	.7922	.823	.7922	.823	.823	.7202	
23	.7545	.7202	.7922	.823	.7202	.6173	.7202
24		.6413	.6173		.7202	.7202	.6173
Max	.9054	.8827	.9808	1.094	.9846	.9808	.8299
Min	.679	.6036	.6173	.6903	.6173	.0617	.6173
Avg	.7860	.7393	.7535	.8987	.8185	.7445	.7137

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

LONAVALA[060]

BU 0884

Substation No/ Name :- 213343 / 22/22 KV NANGARGAON SWT SS

Feeder No / Name : 304 / 22 KV LONAVALA BAZAR

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0185	1.0288		1.1317	.9259	1.0288
2		.9808	1.3032		1.0288	.9259	1.0288
3		.9808	1.0288		1.0288	1.0288	1.0288
4		.9808	1.0288		.9259	1.0288	.9259
5		1.0185	1.0288		.9259	1.1317	.9259
6		1.2449	1.0288		1.1317	1.2346	1.1317
7		1.5089	1.0288		1.2346	1.3375	1.4403
8		1.7353	1.4403		1.6461	1.5432	1.5432
9	1.6975	1.7202	1.6461	1.7428	1.7315	1.6862	1.7353
10	1.5844	1.5504	1.4403	1.7541	1.6975	1.573	1.6598
11	1.4599	1.4486	1.5432	1.6447	1.6485	1.5466	1.5089
12	1.4259	1.4712	1.4403	1.5504	1.5466	1.4712	.1509
13	1.3241	1.392	1.3375	1.5504	1.4712	1.5466	1.5844
14	1.358	1.2901	1.3375	1.4712	1.3693	1.3957	1.4712
15	1.358	1.2449	1.2346	1.4146	1.4259	1.3957	1.4335
16	1.3354	1.1317	1.3375	1.4335	1.4146	1.4335	1.4712
17	1.358	1.1317	1.4335	1.5466	1.3957	1.6409	
18	1.4712	1.1317	1.5466	1.5466	1.5466	1.6409	
19	1.8484	1.3375	1.5844	2.037	1.773	1.773	
20	1.8107	1.4403	1.6975	1.9993	1.9239	1.8484	
21	1.6598	1.5432	1.773	1.773	1.7353	1.6598	
22	1.5089	1.3375	1.4712	1.5432	1.4403	1.4403	
23	1.2449	1.2346	1.2449	1.3375	1.2346	1.2346	1.2346
24		1.094	1.0288		1.1317	1.1317	1.2071
Max	1.8484	1.7353	1.773	2.037	1.9239	1.8484	1.7353
Min	1.2449	.9808	1.0288	1.3375	.9259	.9259	.1509
Avg	1.4963	1.2903	1.3339	1.6230	1.3975	1.3989	1.2506

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

LONAVALA[060]

BU 0884

Substation No/ Name :- 213343 / 22/22 KV NANGARGAON SWT SS

Feeder No / Name : 305 / 22 KV NANGARGAON

SHEDDABLE FEEDER HAVING WEEKLY

INDUSTRIAL Feeder KV- 22 /

STAGGERING (MIDC, EQUIVALENT)

OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9054	.5144		.823	.823	.823
2		.9054	.5144		.823	.823	.823
3		.8676	.5144		.9259	.823	.823
4		.8299	.5144		.823	.823	.823
5		.7922	.5144		.7202	.823	.7202
6		.7545	.5144		.7202	.7202	.7202
7		.7545	.7202		.823	.823	.823
8		.7167	.7202		.823	.823	.823
9	1.2449	.7809	1.0288	1.3014	1.2222	1.4712	1.2826
10	1.392	.679	1.2346	1.5278	1.4825	1.5844	1.5466
11	1.392	.6564	1.2346	1.5844	1.4259	1.5844	1.5466
12	1.5051	.6677	1.3375	1.5617	1.3957	1.6221	1.6598
13	1.3014	.6111	1.1317	1.143	1.2449	1.358	1.5466
14	1.4259	.6903	1.1317		1.4938	1.6221	1.6598
15	1.4938	.713	1.3375	.1547	1.4712	1.5089	1.6598
16	1.5504		1.3375	1.5089	1.5844	1.7353	1.6221
17	1.4335		1.5089	1.3957	1.4335	1.6975	
18	1.2071	.4115	1.4335	1.1317	1.2449	.5658	
19	1.1694	.5144	1.3203	1.1694	1.1694	1.1317	
20	1.0185	.6173	1.1694	1.1694	1.1317	1.1317	
21	1.0562	.7202	.9808	1.1317	1.094	1.0562	
22	1.0185	.6173	1.0185	1.0288	.9259	.9259	
23	.9054	.6173	1.0185	.9259	.9259	.823	.9259
24		.0754	.5144	1.5844	.823	.823	.9054
Max	1.5504	.9054	1.5089	1.5844	1.5844	1.7353	1.6598
Min	.9054	.0754	.5144	.1547	.7202	.5658	.7202
Avg	1.2743	.6772	.9694	1.2213	1.1063	1.1301	1.1519

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

LONAVALA[060]

BU 0884

Substation No/ Name :- 213343 / 22/22 KV NANGARGAON SWT SS

Feeder No / Name : 306 / 22 KV AUNDHE

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1509	.2058		.2058	.2058	.2058
2		.1509	.2058		.2058	.2058	.1029
3		.1509	.2058		.2058	.2058	.1029
4		.1509	.2058		.2058	.2058	.2058
5		.1886	.2058		.2058	.2058	.2058
6		.3018	.2058		.3086	.3086	.3086
7		.415	.2058		.4115	.4115	.4115
8		.415	.2058		.4115	.3086	.3086
9	.3282	.3282	.3086	.3735	.3169	.2942	.2641
10	.2716	.3056	.2058	.2942	.2829	.2641	.2641
11	.2603	.2716	.2058		.2603	.1886	.2263
12	.2037	.215	.2058	.2263	.2263	.1886	.1886
13	.2037	.215	.2058	.2377	.2263	.2641	.2263
14	.1924	.1924	.2058	.2037	.215	.1886	.2263
15	.1924	.1811	.2058	.215	.2263	.1886	.2641
16	.2377	.2058	.2058	.2263	.215	.2263	.2263
17	.2263	.2058	.2641	.2641	.2263	.2829	
18	.2263	.2058	.2641	.2641	.2641	.2829	
19	.3018	.2058	.3018	.3395	.3018	.3395	
20	.3395	.2058	.3018	.3772	.3772	.3772	
21	.3018	.3086	.3018	.3395	.3395	.2641	
22	.2641	.2058	.3018	.3086	.3086	.2058	
23	.1886	.2058	.1886	.2058	.2058	.2058	.2058
24		.1886	.2058	.249	.2058	.2058	.2058
Max	.3395	.415	.3086	.3772	.4115	.4115	.4115
Min	.1886	.1509	.1886	.2037	.2058	.1886	.1029
Avg	.2492	.2321	.2302	.2750	.2649	.2510	.2305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

LONAVALA[060]

BU 0884

Substation No/ Name :- 213343 / 22/22 KV NANGARGAON SWT SS

Feeder No / Name : 307 / 22 KV KURWANDE (R)

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9054	.823		.9259	.823	.823
2		.8676	.823		.823	.823	.823
3		.7922	.823		.823	.823	.823
4		.7922	.9259		.823	.823	.823
5		.8676	.9259		.823	1.0288	.9259
6		1.3203	1.1317		1.0288	.1235	1.1317
7		1.6598	1.2346		.3086	1.6461	1.6461
8		1.5466	1.2346		1.4403	1.4403	1.4712
9	1.4938	1.5391	1.3375	1.607	1.6749	1.4372	1.4712
10	1.2901	1.3807	1.2346	1.3241	1.4146	1.2449	1.3203
11	1.0977	1.0638	1.0288	1.1694	1.3467	1.094	1.094
12	1.0298	.9959	.9259	1.0864	1.1317	1.0185	.9808
13	.9959	.928	.823	1.0185	1.1317	.9808	.9808
14	.928	.8827	.7202	.9846	1.0072	.9808	.9808
15	.9506	.8714	.823	.9054	.9959	.9431	.9808
16	.9393	.823	.823	.9431	1.0525	.9054	1.0185
17	.9808	.823	1.0185	1.094	1.1317	1.0977	
18	1.0185	.823	1.094	1.0562	1.1317	1.0977	
19	1.3203	1.0288	1.1694	1.358	1.3957	1.3203	
20	1.4712	1.1317	1.3203	1.4712	1.5089	1.4712	
21	1.4335	1.1317	1.4335	1.5089	1.4712	1.4335	
22	1.3203	1.5432	1.3203	1.2346	1.3375	1.2346	
23	1.094	1.0288	1.0185	1.1317	1.0288	11.4198	1.0288
24		.9431	.823	1.177	.9259	.9259	.9259
Max	1.4938	1.6598	1.4335	1.607	1.6749	11.4198	1.6461
Min	.928	.7922	.7202	.9054	.3086	.1235	.823
Avg	1.1576	1.0704	1.0348	1.1919	1.1118	1.5057	1.0694

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

LONAVALA[060]

BU 0884

Substation No/ Name :- 216016 / 100/22 KV LONAVALA S/STN

Feeder No / Name : 301 / 22 KV KURVANDE

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0754	.0754	.0754	.0754	.0686	.0686
2	.0686	.0754	.0754	.0754	.0754	.0686	.0686
3	.0686	.0754	.0754	.0754	.0754	.0686	.0686
4	.0686	.0754	.0754	.0754	.0754	.0686	.0686
5	.0686	.0754	.0754	.0754	.0754	.0686	.0686
6	.0686	.0754	.0754	.0754	.0754	.0686	.0686
7	.0686	.0754	.0754	.0754	.0754	.0686	.0686
8	.0686	.0754	.0754	.0754	.0754	.0686	.0686
9	.0686	.0754	.0754	.0754	.0754	.0686	.0686
10	.0686	.0754	.0754	.0754	.0754	.0686	.0686
11	.0686	.0754	.0754	.0754	.0754	.0686	.0686
12	.0686	.0754	.0754	.0754	.0754	.0686	.0686
13	.0686	.0754	.0754	.0754	.0754	.0686	.0686
14	.0686	.0754	.0754	.0754	.0754	.0686	.0686
15	.0686	.0754	.0754	.0754	.0754	.0686	
16	.0686	.0754	.0754	.0754	.0754	.0686	.0686
17	.0686	.0754	.0754	.0754	.0686	.0686	.0686
18	.0686	.0754	.0754	.0754	.0686	.0686	.0686
19	.0686	.0754	.0754	.0754	.0686	.0686	.0686
20	.0686	.0754	.0754	.0754	.0686	.0686	.0686
21	.0686	.0754	.0754	.0754	.0686	.0686	.0686
22	.0686	.0754	.0754	.0754	.0686	.0686	.0686
23	.0686	.0754	.0754	.0754	.0686	.0686	.0686
24	.0686	.0686	.0754	.0754	.0754	.0686	.8573
Max	.0686	.0754	.0754	.0754	.0754	.0686	.8573
Min	.0686	.0686	.0754	.0754	.0686	.0686	.0686
Avg	.0686	.0751	.0754	.0754	.0734	.0686	.1029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

LONAVALA[060]

BU 0884

Substation No/ Name :- 216016 / 100/22 KV LONAVALA S/STN

Feeder No / Name : 304 / 22 KV KRISLON

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.1931	3.3951	3.4179	3.357	3.5399	3.6809	3.437
2	3.1321	2.8692	3.296	3.0769	3.4789	3.4675	3.1131
3	2.9302	2.8082	3.0464	3.0769	3.2903	3.0826	3.174
4	3.1931	2.8883	3.2815	3.4789	3.5704	3.0826	3.4065
5	3.1931	2.9188	3.3875	3.4179	3.759	3.1131	3.4561
6	3.517	3.3951	3.4484	3.6675	4.1305	3.7723	3.7914
7	4.1267	3.9438	3.9057	4.0276	4.6487	4.0466	4.0962
8	4.2181	4.2181	3.6866	4.4353	4.302	4.3706	4.0657
9	2.852	3.9247	2.9245	4.2162	4.4658	4.0352	3.8828
10	3.8333	3.7418	2.5835	4.0028	4.2772	3.9323	3.6504
11	3.4675	3.3569	2.4006	3.9723	4.2162	3.5589	3.7304
12	3.376	2.1033	2.3396	3.8504	4.0333	3.1855	3.4979
13	3.3455	1.5508	2.3091	3.6675	3.5704	2.9606	3.5894
14	3.2236	3.0464	2.2177	4.0028	4.3134	3.0216	3.4979
15	3.8942	2.6445	2.2482	4.4658	4.4963	3.0826	3.4675
16	4.1152	3.4598	2.8692	4.8678	4.9344	3.2236	3.7609
17	4.1877	4.3438	3.2903	5.6355	5.4641	3.8828	4.0352
18	3.6504	4.2772	3.5399	5.4412	5.1631	4.5115	4.6754
19	3.9628	3.8447	3.4846	4.6239	4.8468	4.1152	3.1093
20	4.2486	4.1552	4.1552	5.045	4.8354	4.3591	4.481
21	4.3096	4.5877	4.3381	4.7649	4.6449	4.2791	4.6029
22	3.9743	4.3381	4.3438	4.4601	4.2791	3.8637	4.481
23	3.7113	4.0276	3.9057	4.18	3.8637	3.7723	4.1267
24	3.437	3.3455	3.7533	3.8142	3.9114	3.6199	3.6808
Max	4.3096	4.5877	4.3438	5.6355	5.4641	4.5115	4.6754
Min	2.852	1.5508	2.2177	3.0769	3.2903	2.9606	3.1093
Avg	3.6289	3.4660	3.2572	4.1479	4.2515	3.6675	3.7837

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

LONAVALA[060]

BU 0884

Substation No/ Name :- 216016 / 100/22 KV LONAVALA S/STN

Feeder No / Name : 305 / 22 KV KARLA

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.8573	.9431	.9431	1.1317	.8573	.8573
2	.8573	.8573	.9431	.9431	1.1317	.8573	.8573
3	.8573	.8573	.9431	.9431	.9431	.8573	.8573
4	.8573	.8573	.9431	.9431	.9431	1.0288	.8573
5	1.0288	1.0288	1.1317	1.1317	1.1317	1.2003	1.0288
6	1.3717	1.3717	1.5089	1.3203	1.3203	1.3717	1.3717
7	1.5432	1.3717	1.6975	1.6975	1.6975	1.5432	1.5432
8	1.3717	1.2003	1.5089	1.6975	1.6975	1.3717	1.3717
9	1.2003	1.0288	1.3203	1.3203	1.5089	1.2003	1.2003
10	1.2003	1.0288	1.1317	1.3203	1.5089	1.2003	1.2003
11	1.0288	1.0288	1.1317	1.3203	1.3203	1.0288	1.0288
12	1.0288	1.0288	1.1317	1.3203	1.3203	1.0288	1.0288
13	1.0288		1.1317	1.3203	1.1317	1.0288	1.0288
14	1.0288	.9431	1.1317	1.3203	1.3203	1.0288	1.0288
15	1.0288	.9431	1.1317	1.3203	1.1317	1.0288	1.0288
16	1.0288	.9431	1.1317	1.3203	1.3203	1.0288	1.0288
17	1.0288	1.1317	1.1317	1.3203	1.2003	1.0288	1.2003
18	1.0288	1.1317	1.3203	1.3203	1.2003	1.0288	1.2003
19	2.4006	1.3203	1.5089	1.5089	1.3717	1.3717	1.3717
20	1.5432	1.5089	1.6975	1.6975	1.5432	1.3717	1.5432
21	1.3717	1.5089	1.5089	1.6975	1.3717	1.3717	1.3717
22	1.3717	1.5089	1.5089	1.5089	1.3717	1.2003	1.2003
23	1.0288	1.1317	1.1317	1.3203	1.0288	1.0288	1.0288
24	.8573	.8573	1.1317	1.1317	1.3203	1.0288	.8573
Max	2.4006	1.5089	1.6975	1.6975	1.6975	1.5432	1.5432
Min	.8573	.8573	.9431	.9431	.9431	.8573	.8573
Avg	1.1645	1.1063	1.2417	1.3203	1.2903	1.1288	1.1288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

LONAVALA[060]

BU 0884

Substation No/ Name :- 216016 / 100/22 KV LONAVALA S/STN

Feeder No / Name : 306 / 22 KV INS EXPRESS

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 22 / OUTGOING

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5144	1.7851	.5658	.5144	1.7337	.5144
2	.5144	.5144	.5658	.5658	.5144	.5144	.5144
3	.5144	.5144	.5658	.5658	.5144	.5144	.5144
4	.5144	.5144	.5658	.5658	.5144	.5144	.5144
5	.5144	.5144	.5658	.5658	.5144	.5144	.6859
6	.5144	.6859	.7545	.7545	.5144	.6859	.6859
7	.8573	.8573	.9431	.9431	.6859		1.0288
8	.8573	.8573	.9431	.9431	.6859	.8573	.8573
9	.8573	.8573	.9431	.9431	.6859	.8573	.8573
10	.8573	1.0288	.9431	1.1317	.6859	.8573	.8573
11	.5144	.8573	.9431	1.1317	.6859		.6859
12	.8573	.8573	.7545	.9431	.6859		.8573
13	.6859	.6859	1.0562	.7545	.5144	.8573	.6859
14	.5144	.7545	.7545	.7545	.5144	.6859	.6859
15	.6859	.7545	.7545	.7545	.5144	.8573	.6859
16	.3429	.5658	.7545	.5658	.5144	.6859	.6859
17	.6859	.5658	.7545	.5658	.5144	.5144	.6859
18	.6859	.5658	.5658	.679	.5144	.5144	.6859
19	.6859	.7545	.7545	.7545	.6859	.6859	.8573
20	.8573	.9431	.9431	.7545	.8573	.6859	1.0288
21	.8573	.9431	.9431	.7545	.6859	.8573	.8573
22	.6859	.7545	.7545	.7545	.6859	.6859	.6859
23	.6859	.7545	.7545	.7545	.6859	.6859	.6859
24	.5144	.5144	.5658	.5658	.5658	.5144	.6859
Max	.8573	1.0288	1.7851	1.1317	.8573	1.7337	1.0288
Min	.3429	.5144	.5658	.5658	.5144	.5144	.5144
Avg	.6573	.7137	.8178	.7513	.6023	.7276	.7287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

LONAVALA[060]

BU 0884

Substation No/ Name :- 216016 / 100/22 KV LONAVALA S/STN

Feeder No / Name : 307 / 22 KV SINHGAD EXPRESS

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 22 / OUTGOING

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.6859	.7545	.7545	.7545	.6859	.6859
2	.5144	.5144	.7545	.5658	.5658	.9602	.6859
3	.5144	.5144	.5658	.5658	.5658	.6859	.5144
4	.5144	.5144	.5658	.679	.5658	.5144	.5144
5	.5144	.5144	.5658	.679	.5658	.5144	.5144
6	.5144	.5144	.5658	.5658	.5658	.6859	.6859
7	.5144	.5144	.5658	.5658	.3772	.5144	.6859
8	.8573	1.0288	1.1317	.9431	.5658	.6859	1.0288
9	.6859	.6859	.7545	.7545	.5658	.6859	.8573
10	.5144	.6859	.5658	.7545	.7545	.5144	.6859
11	.5144	.5144	.679	.5658	.7545	.5144	.5144
12	.3429	.5144	.5658	.3772	.5658	.5144	.5144
13	.5144	.3429	.3772	.5658	.5658	.5144	.5144
14	.3429	.3772	.3772	.3772	.3772	.5144	.5144
15	.3429	.3772	.3772	.3772	.3772	.6859	.5144
16	.3429	.3772	.3772	.3772	.3772	.5144	.5144
17	1.3717	.3772	.3772	.3772	.3429	.3429	.5144
18	.3429	.3772	.3772	.3772	.3429	.3429	.5144
19	.6859	.7545	.5658	.3772	.6859	.6859	.6859
20	.6859	.7545	.7545	.7545	.6859	.6859	.6859
21	.5144	.5658	.5658	.7545	.6859	.6859	.6859
22	.5144	.7545	.7545	.5658	.6859	.6859	.6859
23	.6859	.7545	.7545	.7545	.6859	.6859	.8573
24	.6859	.6859	.7545	.7545	.7545	.6859	.6859
Max	1.3717	1.0288	1.1317	.9431	.7545	.9602	1.0288
Min	.3429	.3429	.3772	.3772	.3429	.3429	.5144
Avg	.5644	.5708	.6020	.5910	.5723	.6044	.6359

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

LONAVALA[060]

BU 0884

Substation No/ Name :- 216016 / 100/22 KV LONAVALA S/STN

Feeder No / Name : 308 / 22 KV KHANDALA

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.6123	4.8468	5.0754	6.0928	6.5863	5.3231	5.2926
2	4.542	4.6029	4.7706	5.5993	6.0928	4.9078	4.7858
3	4.3401	4.542	4.6487	5.325	5.8489	4.7858	4.542
4	4.1076	4.481	4.6792	5.2945	5.727	4.481	4.5115
5	4.5115	4.481	4.6487	5.2336	5.666	4.542	4.6334
6	4.9878	4.9878	5.1726	5.5746	5.8184	5.1593	5.1593
7	6.3252	6.2643	6.3786	6.5006	6.8721	6.2643	6.3443
8	7.0759	7.1064	7.0797	7.7923	7.8837	7.1979	7.1979
9	7.1788	7.1369	7.2379	8.2552	8.6515	7.0873	7.1979
10	7.1979	7.7352	7.2988	8.7125	8.9315	7.0568	7.2702
11	7.2283	7.5332	7.537	8.4019	9.1449	6.6606	7.1064
12	7.2283	7.0759	7.6703	8.219	9.0478	7.015	7.1674
13	7.0264	7.1483	7.7866	8.7429	8.6458	6.813	7.0568
14	6.813	7.0111	7.6037	8.7429	7.9999	6.8739	7.1369
15	6.7406	7.3293	7.7923	8.8039	8.0666	6.4777	6.8625
16	7.1483	7.4208	8.0971	9.2973	8.0666	6.4777	7.3198
17	7.4112	7.476	8.4629	9.5412	7.5637	6.4891	6.8359
18	7.1178	6.4758	7.9999	9.1697	7.3808	5.9519	6.5386
19	7.0454	7.3293	7.8227	7.8284	7.1064	6.2567	6.893
20	7.2397	8.0361	8.5905	9.2364	7.4417	7.3007	7.5941
21	7.2893	7.5065	8.1219	8.7011	7.1483	6.9349	7.1788
22	6.813	7.1655	7.9447	8.4324	7.0568	6.7024	6.9044
23	6.4586	6.2452	7.4455	7.7866	6.5195	6.2262	6.1348
24	5.6889	5.4146	6.2395	7.2874	6.251	5.9519	5.6165
Max	7.4112	8.0361	8.5905	9.5412	9.1449	7.3007	7.5941
Min	3.6123	4.481	4.6487	5.2336	5.666	4.481	4.5115
Avg	6.2970	6.4730	6.9210	7.6905	7.3133	6.2057	6.3867

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

LONAVALA[060]

BU 0884

Substation No/ Name :- 216016 / 100/22 KV LONAVALA S/STN

Feeder No / Name : 309 / 22 KV CITY - II

Feeder KV- 22 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2253	2.5301	1.9204	2.4691	2.652	2.3472	2.3167
2	2.1033	2.5301	1.8595	2.3167	2.5911	2.1948	2.3167
3	2.0729	2.4082	1.89	2.2862	2.5606	2.1338	2.3472
4	2.0119	2.1948	1.8595	2.2862	2.4387	2.1338	2.3167
5	1.89	2.1643	1.768	2.2558	2.4691	2.1033	2.0424
6	1.7375	1.9204	1.9509	2.1643	2.1643	1.8595	1.9204
7	1.9204	1.8595	2.0119	1.9814	2.0729	1.9509	2.0119
8	2.4996	2.2253	3.2312	2.4387	3.2922	2.3167	2.4691
9	2.5301	1.9814	3.1398	2.6825	3.2007	2.2558	2.3777
10	2.4996	1.9509	3.4141	2.8654	3.8104	2.4691	2.7435
11	2.5606	1.89	3.4141	2.9874	3.7799	2.4691	2.5911
12	2.4082	1.8595	3.2922	2.5606	3.6885	2.4082	2.5606
13	2.1643	1.829	2.8654	2.6216	3.2922	2.2253	2.4387
14	2.2253	1.7985	3.2922	2.652	2.9264	2.2862	2.3777
15	2.2558	1.9204	3.4446	2.8654	3.6275	2.3472	2.5606
16	2.4996	1.8595	3.2617	3.0483	3.7799	2.3777	2.713
17	2.5911	2.0729	3.2617	3.0483	3.7799	2.5301	2.5911
18	2.5911	1.9814	2.652	3.0788	3.6275	2.5301	2.5301
19	2.1338	1.768	2.5301	2.4387	2.8349	2.0424	2.1948
20	2.5606	2.2253	2.774	2.9569	2.713	2.5301	2.652
21	2.4691	2.1643	2.652	2.8349	2.5606	2.4082	2.5301
22	2.3472	2.0424	2.3167	2.774	2.3472	2.2862	2.4691
23	2.2558	2.1033	2.4082	2.8349	2.3777	2.2558	2.4082
24	2.3167	1.9814	2.5911	2.774	2.3777	2.3167	2.3472
Max	2.5911	2.5301	3.4446	3.0788	3.8104	2.5301	2.7435
Min	1.7375	1.768	1.768	1.9814	2.0729	1.8595	1.9204
Avg	2.2862	2.0525	2.6584	2.6343	2.9569	2.2824	2.4094

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214401 / 33 KV RAJGURUNAGAR

Feeder No / Name : 201 / Dawadi

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4755	.5487	.6584	.5487	.5853	.6224	.6979
2	.4607	.5487	.695	.5487	.5853	.5487	.6161
3	.4938	.5487	.6584	.5487	.5487	.7133	.7356
4	.567	.6584	.7133	.6767		.8779	.8215
5	.7865	.9877	1.0425		.8048	1.2449	.9431
6	1.2986	1.39	1.39		1.3169	1.4998	1.5912
7	2.3045	2.4691	2.6337		2.4143	2.3339	2.5766
8	2.7801	2.7801	3.0361		2.6337	2.2862	2.7915
9	2.652	2.7435	3.0178	2.5057	2.7435	2.4874	2.652
10	2.5972	2.7435	2.572	2.652			
11		2.4272		2.5057	2.3228		
12				1.5684	2.0119		2.1948
13			2.3777	2.1845	1.3352	1.957	2.2131
14			2.4691	1.8673		2.2592	2.3045
15			2.7069	1.9387	2.3777	2.2779	2.268
16			2.7435	2.4086	2.4143	2.3777	2.2131
17	2.8032	2.1033	3.0361	2.4143	2.6155	2.5972	2.5086
18	3.4385	3.0361	2.7801	2.4143	2.1582	2.6783	2.5579
19	2.5789	2.4326	2.2497	1.7924	2.0119	2.1948	2.0748
20	1.8473	1.8839	1.701	1.4998	1.5364	1.8673	1.5684
21	1.5364	1.4266		1.0974	1.0791	1.358	1.1883
22	1.0791	1.134		.8596	.9896		
23	.7682	.8962		.7133			
24	.4938	.6219	.7499	.6219	.6979	.6979	.7545
Max	3.4385	3.0361	3.0361	2.652	2.7435	2.6783	2.7915
Min	.4607	.5487	.6584	.5487	.5487	.5487	.6161
Avg	1.6090	1.6516	1.9595	1.5683	1.6592	1.7305	1.7636

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214401 / 33 KV RAJGURUNAGAR

Feeder No / Name : 202 / Rajgurunagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9909	2.2443	2.0633		2.2262	2.2291	2.4006
2	1.9909	2.2262	2.0814	.0362	2.2081	2.0576	2.2291
3	2.4508	2.552	2.0814	2.1719	2.2443	2.2291	2.0576
4	2.4253	2.7511	2.2986	2.4253	2.3529	2.4006	2.4006
5	2.7252	2.914	2.6425		2.4977	2.7435	2.6578
6	2.914	3.1493	2.914		2.8778	3.155	3.2065
7	3.9457	4.0543	3.7828		3.7647	3.8066	3.9266
8	3.8914	4.1267	3.9095		3.8733	3.6694	3.738
9	3.4122	2.9683	3.5151	3.6351	3.9457	3.6561	3.7104
10	3.3265		3.6008	3.4808		3.6008	3.5837
11	3.2579	3.0769	3.3608	3.4637	4.0116	3.4465	3.3846
12	3.1893	3.3484	3.3265	3.3436	3.4389	3.3779	3.4202
13	3.0864	3.1131	3.2579	3.1379	3.4751	3.035	3.2398
14	2.9835	3.1674	3.1379	3.1207	3.3484	2.9492	3.095
15	3.035	3.1493	3.155	3.1722	3.4751	3.0864	3.1855
16	3.035	3.095	3.4027	3.2922	3.4389	3.1722	
17	3.2579	3.0407	3.4389	3.4389	3.5475	3.275	3.3436
18	3.457	3.1493	3.5475	3.4932	3.5837	3.2236	3.4294
19	3.9638	3.8552	4.2353	4.119	4.3439	3.9781	3.9952
20	3.9638	3.8009	4.1629	3.9819	4.1448	3.7723	
21	3.6561	3.4751		3.7828	3.7285	3.6008	3.7209
22	3.2398	3.2398		3.3303	3.2407		
23	2.6606	2.6606		2.8416			
24	2.1357	2.3529	2.2805	2.1719	2.3148	2.3148	2.4006
Max	3.9638	4.1267	4.2353	4.119	4.3439	3.9781	3.9952
Min	1.9909	2.2262	2.0633	.0362	2.2081	2.0576	2.0576
Avg	3.0831	3.1092	3.1522	3.0757	3.2765	3.1263	3.1563

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214401 / 33 KV RAJGURUNAGAR

Feeder No / Name : 203 / Wada

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0577	.016	.0164	.0415	.0926	.122	.0934
2	.0553	.0164	.0164	.0751	.0934	.1102	.0953
3	.056	.0164	.0164	.0751	.0941	.0911	.096
4	.0564	.0164	.021	.0778	.0945	.1109	.0968
5	.0553	.0408	.0347	.0446	.1109	.1102	.0964
6	.0515	.0881	.0755	.0427	.1094	.1086	.0941
7	.1044	.1795	.098	.0579	.1776	.157	.1837
8	.2012	.2206	.2046	.1318	.2736	.2793	.2183
9	.2763	.2263	.2911	.2721	.3623	.2938	.2732
10	.2736	.2671	.3403	.322	.2195	.3449	.3163
11	.2831	.2919	.4146	.3848	.3292	.3544	.3251
12	.3453	.2405	.4312	.3696	.3719	.3326	.3517
13	.3227	.3197	.3944	.3662	.3494	.3117	.3575
14	.3014	.2843	.4088	.3387	.3818	.3223	.3597
15	.2473	.2889	.3719	.3178	.4046	.2931	.3623
16	.2355	.3601	.288	.3479	.4576	.3021	.3604
17	.2648	.3661	.3787	.2583	.4904	.3525	.4618
18	.2667	.3673	.4103	.1604	.4244	.3643	.4264
19	.2664	.2755	.3151	.1269	.3562	.2515	.3006
20	.2069	.1878	.1787	.0911	.2499	.173	.2058
21	.1574	.1334	.0625	.0751	.1334	.1265	.1292
22	.1181	.0846	.0476	.0762	.13	.0617	.0583
23	.0747	.0816	.0404	.0942	.0716	.0553	.0594
24	.016	.0564	.0576	.0911	.1216	.1128	.0579
Max	.3453	.3673	.4312	.3848	.4904	.3643	.4618
Min	.016	.016	.0164	.0415	.0716	.0553	.0579
Avg	.1789	.1844	.2048	.1766	.2458	.2142	.2242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214401 / 33 KV RAJGURUNAGAR

Feeder No / Name : 204 / Wada GFSS SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0819	.1638	.1311	.1638	.1475	.0943	.0943
2	.0983	.1638	.1311	.1638	.1475	.0943	.0943
3	.0983	.1829	.1311	.1638	.1311	.0943	.0943
4	.1311	.1966	.1638	.1966	.1311	.0943	.0943
5	.1802	.213	.192		.1311	.128	.0943
6	.2458	.2294	.2622		.213	.132	.1698
7	.2622	.3441	.3768		.2294	.2263	.2263
8	.213	.3932	.3605		.1966	.2829	
9	.1867	.3277	.3841	.3961	.2452	.1698	.1475
10	.2915	.0819	.0914	.132		.439	.1802
11	.2915	.0819	.0943	.0943	.5281	.3841	.2294
12	.3258	.08	.0934	.0943	.4527	.3658	.3277
13	.2915	.0655	.0943	.0943	.3961	.3658	.2949
14	.2915	.0819	.0943	.0943	.3772	.3658	.3113
15	.2915	.0819	.0943	.0943	.3734	.3658	.2785
16	.2915	.0819	.0943	.0566	.4338	.3658	.2785
17	.0983	.0943	.0914	.0943	.3395	.3841	.3841
18	.096	.0943	.0943	.0943	.1132	.0943	.0943
19	.1802	.1886	.1886	.2263	.2075	.132	.2263
20	.213	.2829	.2452	.2829	.2641	.2263	
21	.1802	.213		.1638	.2452	.1886	.2263
22	.1638	.1475		.1638	.132		
23	.112	.0983		.1147			
24	.0819	.1475	.096	.1475	.0943	.0943	.0943
Max	.3258	.3932	.3841	.3961	.5281	.439	.3841
Min	.0819	.0655	.0914	.0566	.0943	.0943	.0943
Avg	.1957	.1682	.1669	.1516	.2513	.2313	.1970

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214401 / 33 KV RAJGURUNAGAR

Feeder No / Name : 206 / 11Kv Amul express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.2054	.2241	.2241	.1494	.2286	.1905
2	.2054	.2241	.1867	.2241	.1494	.2286	.2286
3	.168	.2054	.168	.2241	.1307	.2286	.2286
4	.2054	.168	.1867	.2241	.1307	.2477	.1905
5	.2241	.2054	.2054	.2054	.1307	.2286	
6	.2054	.2054	.2427		.2054	.2477	.2286
7	.1307	.112	.1494		.2241	.1143	.2477
8	.1494	.168	.168		.1494	.1334	.1524
9	.1334	.168	.2096	.1524	.2641	.1509	.1494
10	.3048	.168	.1905	.3048		.2858	.168
11	.2096	2.4272	.2858	.021	.3018	.2286	
12	.2096	.1494	.1905	.1905	.2641	.1905	1.531
13	.2096	.2054	.1905	.2096	.2452	.1905	.1867
14	.2286	.2614	.2286	.1905	.2452	.2096	.1867
15	.2286	.2241	.2096	.1905	.2263	.1715	.2054
16	.1715	.2452	.2075	.1715	.2075	.1905	.1829
17	.2427	.2263	.2075	.132	.1509	.1715	.1715
18	.1494	.1698	.1886	.1509	.1509	.1524	.1524
19	.1867	.1886	.1886	.1509	.1698	.1524	.1715
20	.1494	.1494	.132	.1509	.1509	.1524	
21	.1867			.1463	.132	.1334	.1524
22	.2241	.2427		.128	.1334		
23	.2241	.2054		.112			
24	.2054	.2195	.2241	.2054	.1307	.2286	.1715
Max	.3048	2.4272	.2858	.3048	.3018	.2858	1.531
Min	.1307	.112	.132	.021	.1307	.1143	.1494
Avg	.1983	.2932	.1993	.1766	.1838	.1939	.2577

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214401 / 33 KV RAJGURUNAGAR

Feeder No / Name : 301 / TINEWADI FEEDER

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974	1.0608	1.0974	1.2437	1.0974	1.2449	1.3957
2	1.134	1.0242	1.0608	1.1706	1.0974	1.2071	1.3203
3	1.1706	1.0242	1.0974	1.1706	1.0974	1.4712	1.4712
4	1.3535	1.3169	1.2437	1.39	1.2437	1.8107	1.6598
5	1.7558	1.8656	1.5364		1.4998	2.0851	
6	2.3045	2.268	2.0485		2.0851	2.4143	2.6029
7	3.1459	3.1824	2.9995		3.2556	3.3608	3.1459
8	3.658	3.4385	3.5848		3.8043	3.6222	3.3951
9	3.3573	3.1459	3.1367	3.4328	3.7342	3.1367	3.8043
10	3.3234	2.8898	2.9127	2.9424		3.1687	3.4019
11	2.963	2.4508	2.6513	2.5972	3.6595	2.9424	2.9264
12	2.8898	2.1948	2.2634	2.5393	2.726	2.7161	.8048
13	2.726	2.0851	2.2405	2.5766	2.6886	2.8292	3.0994
14	2.3411	2.0485	2.0119	2.726	2.6886	2.3388	2.4143
15	2.7435	2.1582	2.268	2.8292	2.9127	2.2634	2.9264
16	2.838	2.1948	2.3152	2.8292	3.0994	2.95	3.3288
17		2.5019	2.726	2.7511	3.0247	2.8292	2.1502
18	3.2556	2.726	2.7633	2.8959	2.726	3.3573	3.1687
19	2.6703	2.4272	2.5393	2.6139	2.6513	2.6406	2.7161
20	2.4143	2.2032	2.2032	2.3152	2.4272	2.4897	2.6406
21	1.9387	1.8351		1.6827	2.0538	2.2257	2.3011
22	1.7558	1.7924		1.6827	1.9616		
23	1.4632	1.4266		1.5364			
24	2.524	1.2437	1.2071	1.3169	1.358	1.358	1.6598
Max	3.658	3.4385	3.5848	3.4328	3.8043	3.6222	3.8043
Min	1.0974	1.0242	1.0608	1.1706	1.0974	1.2071	.8048
Avg	2.3836	2.1044	2.1861	2.2121	2.4042	2.4756	2.4921

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214401 / 33 KV RAJGURUNAGAR

Feeder No / Name : 302 / 22 KV Allcost & Allied NON SHEDDABLE EXPRESS HV FEEDERS
Express Feeder KV- 22 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1812	1.105	1.2955	1.2955	1.0669	.7922	1.0562
2	1.1812	1.1431	1.2193	1.3336	1.0669	.7922	1.0185
3	1.1812	1.1431	1.2193	1.3336	.9907	.7167	1.0562
4	1.1431	1.0669	1.2574	1.2955	.9907	.7167	1.0185
5	1.1431	1.0669	1.2193		.9526	.7167	
6	1.1431	1.0669	1.2193		.9907	.7167	1.1317
7	.9526	.724	1.2955		.9907	.7922	.9808
8	1.1431	1.2193	1.1812		.9145	1.1694	1.2826
9	1.2449	1.3717	1.3957	1.3203	.9526	1.1431	1.5623
10	1.5844	1.4861	1.3957	1.2826		1.4335	1.3717
11	1.6804	1.4861	1.358	1.358	.9526	1.4712	.5335
12	1.9418	1.4861	1.4712	1.358	.9431	1.4712	1.2193
13	1.7924	1.3717	1.4712	1.2826	.823	1.4335	1.3717
14	1.8107	1.3717	1.4712	1.358	.9145	1.4712	1.5623
15	1.4335	1.5623	1.5089	1.2826	.9526	1.5089	1.5242
16	1.4712	1.5623	1.4861	1.4712	1.0288	1.5089	1.6004
17	1.4098	1.5623	1.448	1.4861	.9907	1.5089	1.5844
18	1.448	1.448	1.3717	1.3717	.9526	1.2071	1.5844
19	1.2574	1.3717	1.5242	1.2955	.9907	1.358	1.4335
20	1.2574	1.3336	1.2955	1.2574	.9145	1.3957	1.3957
21	1.2574	1.3336		1.3336	.9145	1.3957	1.3203
22	1.2193	1.1812		1.2193	.7922		
23	1.2193	1.2955		1.1812			
24	1.2193	1.2193	1.2955	1.2955	1.1812	.7922	1.1317
Max	1.9418	1.5623	1.5242	1.4861	1.1812	1.5089	1.6004
Min	.9526	.724	1.1812	1.1812	.7922	.7167	.5335
Avg	1.3465	1.2908	1.3524	1.3206	.9667	1.1596	1.2733

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214408 / 33/11 KV PAIT

Feeder No / Name : 201 / Amboli

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17
HR	Load (MW)	Load (MW)
1	1.829	1.5623
2	1.7909	
3	1.7528	1.448
4	1.7718	1.5623
5	1.7528	1.6766
6	2.21	1.9433
7	3.1245	
9	2.8578	1.9433
24	1.9433	1.6385
Max	3.1245	1.9433
Min	1.7528	1.448
Avg	2.1148	1.6820

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214408 / 33/11 KV PAIT

Feeder No / Name : 203 / Kiwale

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17
HR	Load (MW)	Load (MW)
1	.4887	.7783
2	.5249	.7602
3	.6335	.7602
4	.6697	.8326
5	.7783	.8869
6	.905	.9774
7		1.0136
8		1.1403
9		.8869
24	.4525	.7602
Max	.905	1.1403
Min	.4525	.7602
Avg	.6361	.8797

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214438 / 33/11 KV DAWADI SUBSTATION

Feeder No / Name : 201 / 11KV NIMGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7612	1.3136	.4513	.6445	.7468	1	
2	.8157	1.3176	.4513	.6544	.7468	1	
3		1.3338	.4513	.6449	1.2136	1	
4	.8165	1.3512	.4609	.6994	1.4937	1.0173	
5	.1307	1.4032	.7202	.8889	1.587	1.1195	
6	1.5741	1.716	.9602	1.3528		.1574	
7			1.3443	1.7149		1.3443	
8			1.3443	1.5861		.1344	
9			1.0517				
10	1.2803	1.4222	.8145	.7414	1.2019	1.3717	
11		1.3908	.7421	.7759	1.3975	1.3813	
12	1.262	1.2803	.7619		.435	1.2765	
13	1.3797	1.1065		.076	1.122	1.198	
14	1.3051	1.0669			1.0788	1.1248	
15	1.2765	1.0002			1.0425	1.0829	
16	1.2631	1.0974			.9259	1.0883	
17	1.1161	.9794			.9284	1.8429	
18	1.4359	1.1207	1.2541	1.3575	1.241	1.1023	1.7372
19	2.0911	1.9828	2.2987	1.885	1.9172	1.6552	2.4891
20	2.4934	2.0368	2.6166	2.3211	2.4021	.2241	1.5926
21	2.3906	1.9828	2.4322	2.2965	2.3693	1.9029	1.5604
22	1.8747	.1719	1.9477	1.8671	1.9576	1.5518	1.2883
23	1.4825	1.2069	1.3672	1.475	1.4465	1.2069	.9649
24		.0533		.6576	.8029	.5569	
Max	2.4934	2.0368	2.6166	2.3211	2.4021	1.9029	2.4891
Min	.1307	.0533	.4513	.076	.435	.1344	.9649
Avg	1.3750	1.2540	1.1928	1.2022	1.3028	1.1017	1.6054

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214438 / 33/11 KV DAWADI SUBSTATION

Feeder No / Name : 202 / 11KV CHINCHOSHI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.845	.8852	.1841	.2122	.8383	.16	
2	.8651	.9072	.1726	.2032	.8383	.1652	
3	.8701	.9167	.1726	.2002	.8573	.1726	
4	.8933	.9728	.1726	.215	.9088	.1726	
5	1.0961	1.0066	.2589	.2459	.9088	.2877	
6	1.1713	1.2426	.3452	.3682	1.1951	.2877	
7	.1446	1.5131			1.4089		
8	1.4457	1.4861			1.4289		
9	1.1888	1.4451			1.0802	1.2729	
10		.1306	1.3813				
11		.109	1.4289				
12		.1174	1.6337				
13		.108	1.4003	1.5364			
14		.1238	1.4098	1.5844			
15		.109	1.4194	1.5844			
16		.1183	1.3908	1.4403	.1155		
17	.1075	.0152	1.3525	1.2384	.1355	.1709	.8304
18	.1288	.1276	.1613	.1052	.1438	.1315	.1334
19	.2075	.2589	.2315	.1534	.2015	.2103	.2417
20	.2938	.2589	.2623	.2526	.2353	.2418	.3117
21	.2803	.2819	.2828	.2572	.2698	.241	.306
22	.2537	.2474	.5982	.2422	.2211	.2229	.2766
23	.2086	.2014	.4472	.1951	.1963	.1989	.2028
24	.0926	.2014		.2131	.6882	.1354	
Max	1.4457	1.5131	1.6337	1.5844	1.4289	1.2729	.8304
Min	.0926	.0152	.1613	.1052	.1155	.1315	.1334
Avg	.5937	.5327	.7353	.5693	.6484	.2714	.3289

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214438 / 33/11 KV DAWADI SUBSTATION

Feeder No / Name : 203 / 11KV WAFGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.845	.7938	.1612	.452	.4268	.2686	
2	.5341	.6922	.2149	.4665	.3963	.2686	
3	.5324	.6645	.2149	.4542	.4062	.269	
4	.5466	.6001	.2149	.4457	.3605	.2686	
5	.617	.5788	.3492	.5255	.3688	.3224	
6		.542	.6984	.9611	.4012		
7		.4388	.7522	.855	.8253	.3224	
8		.4106	.6447	.792	.4858	.1856	
9		.3217	.3155	.3358	.3443		
10	.7628				.5738	.7099	
11					.2904	.7225	
12	.3601				.4321	.7773	
13	.5201				.5473	.5201	
14	.6036				.2418	.4161	
15	.7125				.2955	.5146	
16	.7074	.2643	.2782	.6447	.4029	.1947	
17	.4878	.2305	.6265	.2987	.0429	.5238	.3007
18	.5976	.2766	.7459	.7362	.4711	.0429	.5853
19	.698	.5994	.8565	1.07	.6336	.0686	.4678
20	.8436	.3761	.9347	.751	.556	.5641	1.0413
21	.618	.2686	.8802	.6087	.3493	.6984	.6309
22	.7683	.5549	.5727	.8162	.5178	.6984	.3961
23	.9108	.2686	.4969	.6969	.3909	.8608	.5784
24	.8258	.2149		.4607	.2561	.381	
Max	.9108	.7938	.9347	1.07	.8253	.8608	1.0413
Min	.3601	.2149	.1612	.2987	.0429	.0429	.3007
Avg	.6574	.4498	.5269	.6317	.4174	.4363	.5715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214438 / 33/11 KV DAWADI SUBSTATION

Feeder No / Name : 401 / KANESAR INFRA

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001	.4527	.6287	.6224	.3921	.6287	
2		.4527	.6287	.6224	.4481	.6287	
3	.4001	.4527	.6287	.679	.4481	.6287	
4	.4572	.4527	.6287	.679	.5601	.6287	
5	.5144	.5658	.9145	.7922	.5601	.5658	
6	.6859	.679	1.4289	1.358	.7282	.7356	
7	.9717	.9054	1.4861	1.6409	.9522	.8488	
8	1.0288	.9619	1.4289	1.3014	1.0082	.9054	
9	.6722	.5658	.8962	.9145	.743	.5601	
10	.6722	.679	.7282	.4001	.743	.5601	
11	.056	.6722	.5041		.6287	.5601	
12	.5041	.3921	.4481	.4572	.5144	.2241	
13	.4481	.3921	.3921	.3429	.5144	.4481	
14	.4481	.4481	.3361	.2858	.4001	.3921	
15	.4481	.4481	.3921	.3429	.4572	.4481	
16	.5601	.5601	.4481		.5716	.5041	
17	.5658	.5144	.4527	.4481	.5658	.5144	.5093
18	.3961	.3429	.3961	.3361	.2829	.3429	.3395
19	.679	.6287	.6224	.6161	.6224	.5144	.5658
20	.7922	.8002	.7922	.7842	.7356	.8002	.7922
21	.7356	.743	.7356	.7282	.7356	.743	.7356
22	.5658	.6287	.6224	.6161	.6224	.6859	.6224
23	.4527	.5144	.5093	.5041	.5093	.5144	.5093
24		.6287		.679	.3921	.6287	
Max	1.0288	.9619	1.4861	1.6409	1.0082	.9054	.7922
Min	.056	.3429	.3361	.2858	.2829	.2241	.3395
Avg	.5661	.5784	.6978	.6887	.5890	.5838	.5820

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214446 / 33/11 KV KADUS SUBSTATION

Feeder No / Name : 201 / 11KV CHAS SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17
HR	Load (MW)
1	.179
2	.1807
3	.1807
4	.1914
5	.202
6	.2162
7	.3048
8	.3473
9	.0975
10	.8573
11	.8573
12	.6859
13	.6859
14	.6859
15	.6859
24	.8573
Max	.8573
Min	.0975
Avg	.4509

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214446 / 33/11 KV KADUS SUBSTATION

Feeder No / Name : 202 / 11KV KADUS SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1099			.1648			
2	.1116			.1666			
3	.1152			.1666			
4	.1205			.1683			
5	.1329			.179			
6	.1878			.2091			
7	.1967			.264			
8	.1559			.2693			
9	.2091	.1104	.2481	.2303		.1063	
10	2.8292	.2994	.085			.2764	
11		.2658	.0815		3.3436	.2746	
12		.2658	.0815			.2551	
13		.2551	.0797		3.1722	.264	
14		.241	.078		3.0007	.2658	
15		.2286	.0744		2.572	.2481	
16		.2427	.0815		2.2634	.2445	
17		.2162	.0833		2.2291	.2126	.0975
18			.0868		1.0288		.096
19			.1577		1.3717		.1423
20			.1595				.1612
21			.1648				.1578
22			.1417				.1471
23			.1577				.1081
24	.1081			.1648			
Max	2.8292	.2994	.2481	.2693	3.3436	.2764	.1612
Min	.1081	.1104	.0744	.1648	1.0288	.1063	.096
Avg	.3888	.2361	.1174	.1983	2.3727	.2386	.13

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214446 / 33/11 KV KADUS SUBSTATION

Feeder No / Name : 203 / 11KV GRAGOTWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17
HR	Load (MW)
1	.0868
2	.0886
3	.0921
4	.0975
5	.1081
6	.1276
7	.1595
8	.1187
9	.1736
10	2.6578
11	.6516
24	.085
Max	2.6578
Min	.085
Avg	.3706

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214446 / 33/11 KV KADUS SUBSTATION

Feeder No / Name : 401 / 33KV VHPL

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	21-MAR-17
HR	Load (MW)
22	.1329
23	.1382
Max	.1382
Min	.1329
Avg	.1356

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214447 / 33/11 KV WADA SUBSTATION

Feeder No / Name : 201 / 11KV WADA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5434	.5611	.4338	.4294	.6733	.4854	.4481
2	.5258	.543	.415	.4294	.6556	.4668	.4108
3	.5258	.543	.3961	.4481	.6379	.4481	.4108
4	.5258	.5611	.4338	.4294	.6733	.4668	.4294
5	.567	.5792	.4904	.5041	.7087	.5041	.4481
6	.6556	.695	.6161	.6161	.7973	.6348	.5975
7	.8238	.9522	.8029	.7468	.9979	.7167	.8131
8	.9896	1.0374	.7167	.7023	1.0269	.6478	.7167
9	.9526	.9709	.5975		1.0642		
10	.4191	.4382	1.0751	1.1317	.4904		
11	.4572	.4338	1.3014	1.0456	.4763		
12	.4001	.4715	1.2826	.9259	.4763		
13	.4954	.4108	1.2696	1.0576	.4572		
14	.4001	.4108	1.2637	1.0117	.4382		
15	.4001	.4024	1.226	1.0576	.4382		
16	.4572	.3961	1.0456	.9882	.4572		
17		.4207	1.0829	1.0425	.4715	1.0059	1.1506
18		.4435	.5525	.4805	.5144	.5228	.5335
19		.6838	.8383	.7811	.7621	.724	.7621
20		.8775	.9907	.9907	1.0098	.9907	1.0098
21		.8573	.9717	.8764	.9526	.9907	.9335
22		.8002	.7621	.8383	.7811	.8192	.8192
23	.5335	.5335	.6097	.6287	.5906	.6287	.6097
24	.5609	.5552	.4338	.4668	.6733	.4854	.4854
Max	.9896	1.0374	1.3014	1.1317	1.0642	1.0059	1.1506
Min	.4001	.3961	.3961	.4294	.4382	.4481	.4108
Avg	.5685	.6074	.817	.7665	.6760	.6586	.6611

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214447 / 33/11 KV WADA SUBSTATION

Feeder No / Name : 202 / 11KV BHORGIRI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1038	1.1856	1.5782	1.1728	1.3043	2.0954	1.8107
2	1.1035	1.1492	1.5103	1.1603	1.2718	2.0614	1.8081
3	1.0863	1.1296	1.4954	1.1488	1.2599	2.0206	1.7779
4	1.1008	1.1485	1.5215	1.153	1.286	2.0611	1.7448
5	1.1675	1.259	1.6907	1.3397	1.3687	2.0962	1.7894
6	1.609	1.808	2.0359	1.8439	1.9225	2.4969	2.2729
7	2.2321	2.3049	2.495	2.3899	2.4286	2.9113	2.9652
8	2.1822	2.0066	2.6475	1.9284	2.1377	3.1508	3.2882
9	1.0929	1.637	2.4768	.4736	1.6667	1.0524	1.065
10	3.1501	2.846	1.146	1.6625	3.1792	.5045	.5194
11	2.9919	2.8772	1.3152	2.1708	3.4138	.45	.4603
12	2.7999	2.8898	1.3134	1.0925	3.525	.3948	
13	2.753	2.471	1.227	.9547	3.6397	.3871	.3346
14	3.0365	1.989	1.1599	.9621	3.4012	.3951	.4447
15	2.7644	1.5962	1.2441	.952	3.3463	.418	.4588
16	2.8059	2.9409	1.2544	1.0023	3.3943	.4344	.4557
17	.8638	.6451	1.2003	1.238	3.2427	1.2864	1.2906
18	.4938	1.9056	1.3088	1.8872	1.5657	1.5272	1.4728
19	.8131	2.2843	2.5122	2.4913	2.3602	2.4867	2.5998
20	.9979	3.0343	3.0686	3.1356	3.0853	3.1996	3.1919
21	.9831	2.8513	2.8978	2.9893	2.9858	3.054	3.0251
22	.8684	2.4051	2.2954	2.6021	2.4349	2.5507	2.5343
23	1.6625	1.6892	1.7296	1.8758	1.7803	1.8039	1.861
24	1.1889	1.3447	1.5377	1.3219	1.5764	1.9845	1.6941
Max	3.1501	3.0343	3.0686	3.1356	3.6397	3.1996	3.2882
Min	.4938	.6451	1.146	.4736	1.2599	.3871	.3346
Avg	1.7021	1.9749	1.7776	1.6229	2.3990	1.7010	1.6898

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214447 / 33/11 KV WADA SUBSTATION

Feeder No / Name : 203 / Kadadhe SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0517	.9412	.4338	.9522	.7087	.4294	.4108
2	1.0341	.9231	.415	.9522	.691	.4108	.4108
3	1.0341	.905	.3961	.9709	.691	.4108	.3921
4	1.0166	.9412	.4527	.9709	.7087	.4294	.4108
5	1.0985	1.0136	.5658	1.0269	.7442	.5041	.4668
6	1.2226	1.262	.7282	1.2323	.9745	.7468	.7468
7	1.6297	1.4377	.9335	1.307	1.2936	.8676	.8316
8	1.8484	1.773	.7922	1.6448	1.419	.6859	.7922
9	1.5242	1.587	.4668		1.307		
10	.4954	.4191	1.5466	.3547	.3584		
11	.4001	.3018	1.8107	.3547	.4001		
12	.381	.3206	1.7541		.381		
13	.362	.3361	1.4563		.1524		
14	.3429	.2987	1.7541	.12	.381		
15	.3429	.3109	1.7541	.3641	.4191		
16	.3429	.3772	1.8298	.4161	.4382		
17		.3658	1.587	.4024	.4527	1.5729	1.8484
18		.4572	.4954	.462	.4763	.4854	
19		.6838	.743	.743	.7621	.743	
20		.8215		.8954	.8954	.9526	1.0288
21		.8002	.8192	.8573	.8954	.8573	.9335
22		.724	.7049	.743	.724	.724	.8192
23	.5335	.5335	.5144	.5525	.4954	.5716	.5716
24	1.0692	.9313	.4338	.9896	.7087	.4294	.4481
Max	1.8484	1.773	1.8298	1.6448	1.419	1.5729	1.8484
Min	.3429	.2987	.3961	.12	.1524	.4108	.3921
Avg	.8739	.7694	.9734	.7768	.6866	.6763	.7223

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214507 / 33/11 KV KANERSAR INFRA

Feeder No / Name : 201 / KANERSAR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2772	.2801	.2172	.2172	.2987	.2987	.2378
2	.2241	.2614	.2303	.2172	.2987	.2801	.2481
3	.2353	.2614	.2279	.2534	.2987	.2987	.2686
4	.3734	.3547	.2658	.3224	.3547	.3547	.3189
5	.4251	.4668	.2804	.4252	.5041	.5041	.3506
6	.5601	.5601	.4508	.5144	.5914	.5975	.4706
7	.6602	.6535	.5487	.6173	.6468	.6348	.5959
8	.4755	.5041	.5487	.5487	.5544	.5041	.5144
9	.3547	.3734	.3772	.3429	.4435	.3547	.3294
10	.3155	.2601	.2054	.2987	.4706	.3856	.2241
11		.2254	.2012	.2427	.333	.2263	.2012
12	.2454	.1734	.1829	.2241	.2303	.2427	.181
13	.1949	.2058	.1663	.2054	.2149	.2279	.1829
14	.1949	.2254	.2033	.2054	.2149	.208	.1829
15	.2012	.2401	.1848	.2054	.2149	.2058	.2012
16	.2561	.2103	.2033	.2614	.2686	.2454	.2033
17	.2012	.2241	.2241	.2614	.2149	.2103	.2402
18	.2614	.362	.2614	.2801	.2427	.3696	.2957
19	.4481	.4572	.4251	.4435	.4481	.5175	.4481
20	.5601	.5847	.5487	.5487	.5228	.5121	.5415
21	.5228	.5415	.499	.5175	.5041	.5281	.5228
22	.4294	.3326	.4066	.4294	.4294	.4066	.4668
23	.3174	.3174	.3361	.3361	.3361	.3174	.3584
24	.2801	.2801	.3772	.2378	.2987	.4854	.2172
Max	.6602	.6535	.5487	.6173	.6468	.6348	.5959
Min	.1949	.1734	.1663	.2054	.2149	.2058	.181
Avg	.3484	.3482	.3155	.3398	.3723	.3715	.3251

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214507 / 33/11 KV KANERSAR INFRA

Feeder No / Name : 202 / VARUDE SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3189	.3077	.4066	.3734	.3696	.3582	.3921
2	.3155	.3077	.3881	.3696	.3511	.3582	.3772
3	.3506	.3258	.4294	.4251	.3511	.3761	.3734
4	.3681	.394	.4572	.5121	.4066	.4119	.439
5	.3467	.443	.5359	.6401	.4572	.4784	.5487
6	.5895	.583	.6219	.6984	.5731	.583	.695
7	.7202	.7545	.7421	.788	.691	.6687	.7316
8	.7461	.7373	.567	.5316	.8238	.6687	.5914
9	.5144	.4477	.462	.4435	.591	.3944	.4024
10	.2614	.2195	.5847	.5068	.2987	.2402	.6878
11		.2353	.4287	.4207	.2614	.2033	.3601
12	.2614	.2402	.3258	.3109	.2427		.3086
13	.2614	.2195	.2915	.3109	.2801	.2402	.2572
14	.2614	.2402	.2743	.2743	.2614	.1991	.2743
15	.2614	.2743	.3086	.2896	.2614	.2614	.2743
16	.2801	.2987	.3601	.4024	.2801	.2534	.3467
17	.2987	.3109	.3429	.3292	.3174	.3109	.4075
18	.3921	.4481	.3361	.3361	.3361	.543	.3326
19	.5788	.5601	.5359	.5914	.6348	.7095	.5228
20	.6908	.7023	.6584	.6767	.6908	.7023	.7095
21	.6535	.6413	.6283	.6653	.6535	.6348	.6908
22	.5601	.5041	.5359	.5788	.5788	.5121	.5788
23	.4668	.462	.4668	.5041	.4668	.4527	.4715
24	.2865	.3258	.4251	.3921	.3511	.3761	.415
Max	.7461	.7545	.7421	.788	.8238	.7095	.7316
Min	.2614	.2195	.2743	.2743	.2427	.1991	.2572
Avg	.4254	.4160	.4631	.4738	.4387	.4320	.4662

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214507 / 33/11 KV KANERSAR INFRA

Feeder No / Name : 203 / PUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.037	.0373	.0189	.0377	.037	.037	.0373
2	.0354	.0373	.0187	.0377	.037	.037	.037
3	.0354	.037	.0377	.0373	.037	.037	.0377
4	.0526	.0554	.037	.0554	.037	.0554	.056
5	.0526	.0732	.056	.0554	.0549	.0914	.0747
6	.0867	.0924	.0747	.0724	.0724	.1097	.0905
7	.1029	.128	.112	.0905	.0895	.128	.0924
8	.1029	.1109	.0739	.0709	.0886	.0732	.056
9	.0701	.0914	.056	.0554	.0543	.0747	.0934
10	.0377	.0185	.0716	.0549	.056	.0189	.1086
11	.0189	.0187	.0686	.0366	.0377	.0187	.0686
12	.0189	.0187	.0514	.0366	.0377	.0187	.0686
13	.0377	.0373	.0514	.0366	.0377	.0377	.0514
14	.0189	.0185	.0514	.0366	.0189	.0185	.0514
15	.0189	.037	.0514	.0366	.0189	.0185	.0693
16	.0377	.0377	.0514	.0366	.0189	.0187	.0709
17	.0377	.056	.0343	.0366	.0377	.037	.0724
18	.0377	.0739	.056	.0373	.0566	.0924	.056
19	.0754	.0943	.0747	.0747	.0754	.1132	.0943
20	.0943	.0943	.0914	.0924	.0943	.0934	.0934
21	.0943	.0747	.0924	.0924	.0943	.0747	.0934
22	.0754	.0554	.0747	.0747	.0747	.0754	.0754
23	.0566	.056	.056	.056	.056	.056	.0566
24	.0362	.0377	.0377	.0377	.037	.037	.0554
Max	.1029	.128	.112	.0924	.0943	.128	.1086
Min	.0189	.0185	.0187	.0366	.0189	.0185	.037
Avg	.0530	.0580	.0583	.0537	.0525	.0572	.0692

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214508 / 33/11 KV KANERSAR SEZ

Feeder No / Name : 201 / 9 PLANETS

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4361	.3033	.1705	.7967	.5877	.6443	.6066
2	.4172	.2082	.1705	.7778	.55	.762	.5877
3	.4361	.2082	.1516	.7205	.6073	.759	.6287
4	.341	.1894	.1705	.6632	.5696	.5906	.6443
5	.3599	.1894	.1705	.5492	.5696	.5144	.7582
6	.1516	.2844	.1705	.5681	.5689	.5877	.796
7	.1328	.1705	.1516	.928	.6443	.4927	.5304
8	.2271	.1705	.2082	.7386	.6443	.5304	.4738
9	.341	.0762	.6632	.8533	.6632	.6254	.3222
10	.7009		.4927	.7771	.682	.7771	.4927
11	.55		.6254	.796	.6443	.7016	.5115
12	.7205	.1705	.55	.759	.5877	.7205	.6066
13	.4738	.1705	.6066	.6066	.6828	.7386	.7771
14	.4763		.796	.6066	.6254	.8337	.7016
15	.4572		.9485	.7394	.8722	.6639	.7394
16	.4549	.1705	.7771	.8329	.891	.5311	.6066
17	.5304	.1705	.682	.7009	.8533	.7952	.8722
18	.4549	.1705	.6443	.9853	.682	.6443	.9476
19	.3599	.1894	.7771	.8533	.682	.6254	.7205
20	.3222	.1894	.7582	.891	.5689	.55	.7394
21	.341	.1894	.7016	.7771	.7009	.6254	.7582
22	.3033	.2082	.7582	.682	.6066	.55	.6632
23	.3222	.1894	.7582	.7394	.5877	.5689	.6632
24	.3787	.246	.3991	.7394	.6443	.7009	.5689
Max	.7205	.3033	.9485	.9853	.891	.8337	.9476
Min	.1328	.0762	.1516	.5492	.55	.4927	.3222
Avg	.4037	.1932	.5126	.7534	.6548	.6472	.6549

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214508 / 33/11 KV KANERSAR SEZ

Feeder No / Name : 202 / NUMEN

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2286	.2286	.3048	.2241	.1905	.2477
2	.2477	.2096	.1905	.2667	.2241	.2096	.2667
3	.2096	.2477	.2096	.2286	.2427	.1905	.2286
4	.2667	.2286	.2286	.2477	.2614	.1905	.2477
5	.2286	.2096	.1715	.2286	.2241	.1905	.2286
6	.2477	.2477	.1715	.2096	.2427	.2286	.2096
7	.3048	.2096	.1905	.2286	.3174	.2858	.2858
8	.3048	.2477	.381	.3239	.2427	.362	.3239
9	.4763		.381	.4382	.2858	.381	.4572
10	.6859		.6668	.5335	.2667	.5525	.6859
11	.7811		.5906	.5716	.2096	.7049	.724
12	.6668	.3239	.724	.5144	.2477	.5906	.7049
13	.5335	.6668	.4668	.6097	.2667	.6859	.6287
14	.6859	.6097	.7282	.6287	.2286	.6668	.5335
15	.724	.5335	.7095	.5335	.362	.6097	.5906
16	.7049	.5716	.6722		.3239	.6287	.6668
17	.5525	.4763	.6348	.6478	.3239	.7621	.6478
18	.5906	.5716	.5788	.5144	.1905	.5716	.4763
19	.4954	.362	.4108	.6859	.2477	.5716	.6478
20	.6287	.2858	.4108	.6859	.3429	.5716	.5906
21	.6097	.4001	.4108	.5601	.2286	.381	.5716
22	.5144	.4382	.3921	.5228	.2096	.724	.4481
23	.362	.4191	.3734	.4854	.1715	.4382	.3921
24	.2667	.2286	.3429	.3547	.4668	.1715	.2477
Max	.7811	.6668	.7282	.6859	.4668	.7621	.724
Min	.2096	.2096	.1715	.2096	.1715	.1715	.2096
Avg	.4715	.3674	.4277	.4489	.2647	.4525	.4605

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214508 / 33/11 KV KANERSAR SEZ

Feeder No / Name : 204 / FEEDER NO 4

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.1524	.0762	.4572	.3048	.3048	.3048
2	.2286	.0762	.0762	.4572	.3048	.4572	.3048
3	.2286	.0762	.0762	.381	.381	.4572	.3048
4	.1524	.0762	.0762	.3048	.381	.3048	.3048
5	.1524	.0762	.0762	.2286	.381	.2286	.381
6	.0762	.1524	.0762	.2286	.3048	.3048	.381
7	.0762	.0762	.0762	.381	.3048	.2286	.2286
8	.0762	.0762	.0762	.3048	.3048	.2286	.2286
9	.1524	.0762	.3048	.4572	.3048	.3048	.1524
10	.3048		.2286	.381	.3048	.381	.2286
11	.3048		.3048	.381	.3048	.381	.2286
12	.381	.0762	.3048	.4572	.3048	.381	.3048
13	.2286	.0762	.3048	.3048	.381	.3048	.381
14	.2286		.381	.3048	.3048	.381	.381
15	.2286		.5335	.381	.4572	.381	.381
16	.2286	.0762	.381	.3048	.4572	.3048	.3048
17	.2286	.0762	.3048	.3048	.4572	.3048	.4572
18	.2286	.0762	.3048	.4572	.3048	.3048	.4572
19	.1524	.0762	.381	.4572	.3048	.3048	.381
20	.1524	.0762	.381	.4572	.3048	.3048	.381
21	.1524	.0762	.381	.381	.3048	.3048	.381
22	.1524	.0762	.381	.3048	.3048	.3048	.3048
23	.1524	.0762	.381	.381	.3048	.3048	.3048
24	.1524	.0762	.3048	.381	.3048	.3048	.3048
Max	.381	.1524	.5335	.4572	.4572	.4572	.4572
Min	.0762	.0762	.0762	.2286	.3048	.2286	.1524
Avg	.1937	.0838	.2572	.3683	.3366	.3239	.3239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214509 / 33/11 KV NIMGAON SEZ

Feeder No / Name : 201 / RAJ PROCESS

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.132	.112	.0943	.168	.0943	.1132
2	.1867	.132	.112	.1132	.168	.0943	.0754
3	.1867	.1132	.112	.1132	.168	.0943	.0754
4	.1867	.1132	.0934	.1132	.168	.112	.0754
5	.1867	.1132	.0934	.132	.168	.1132	.0754
6	.1307	.0943	.0934	.132	.1307	.1132	.1132
7	.1307	.1132	.0934	.1509	.0747	.1509	.1132
8	.1867	.1132	.0934	.1698	.0747	.2614	.1132
9	.1494		.0934	.2427	.168	.3921	.1886
10	.2241		.0934	.2427	.168	.3734	.2241
11	.2801		.0943	.2614	.1698	.3772	.2427
12	.2241	.1867	.1132	.2987	.1698	.3361	.2987
13	.1509	.112	.1132	.2427	.1509	.3395	.3018
14	.3206	.2614	.132	.2987	.1509	.3361	.3772
15	.2614	.1867	.1509	.2241	.1698	.3018	.2641
16	.2987	.2829	.1509	.2614	.1698	.2987	.3734
17	.2614	.1867	.1509	.3361	.0857	.1886	.3018
18	.2241	.1867	.1132	.3361	.0943	.1886	.2263
19	.2614	.1867	.1132	.3547	.0943	.1886	.2263
20	.2641	.2075	.1132	.3361	.0943	.1886	.2263
21	.2614	.2241	.132	.1307	.0943	.1886	.2263
22	.1698	.112	.1509	.1307	.1132	.1509	.2263
23	.1698	.112	.1132	.1307	.0943	.1509	.2263
24	.2054	.132	.112	.0943	.168	.1132	.1132
Max	.3206	.2829	.1509	.3547	.1698	.3921	.3772
Min	.1307	.0943	.0934	.0943	.0747	.0943	.0754
Avg	.2128	.1572	.1143	.2059	.1365	.2144	.1999

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

RAJGURUNAGAR[063] BU 5827

Substation No/ Name :- 214509 / 33/11 KV NIMGAON SEZ

Feeder No / Name : 401 / NIMGAON SEZ - KANERSAR SEZ NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3961	.5658	.3961	.5658	.5658	.5093	.679
2	.4527	.5093	.3961	.5658	.5658	.5093	.679
3	.3961	.5093	.3961	.5658	.5658	.5093	.679
4	.4527	.5093	.3961	.5658	.5658	.5093	.679
5	.4527	.5093	.3961	.6224	.5658	.5093	.5658
6	.3961	.5093	.3395	.6224	.5658	.5658	.5658
7	.3961	.3961	.3961	.679	.6224	.5658	.5658
8	.3961	.4527	.4527	.679	.5658	.6224	.5658
9	.5658		.7356	.7922	.679	.7356	.5658
10	.5658		.9619	.9054	.6224	.9054	.7356
11	.679		.9619	1.0185	.6224	1.1317	.9619
12		.5093	.9619	.9619	.6224	1.1317	.9619
13	.679	.6224	.9619	.9054	.6224	1.1317	.9619
14	.9619	.5658		.8488		1.1317	.8488
15	.9054	.5093	1.0185	1.2449		1.1317	.9619
16	.9054	.679	1.0185	.8488		1.1317	.9619
17	.9054	.8488	.9054	1.0185	.5658	1.1317	.9619
18	.7922	.6224	.7922	1.0751	.5658	.9054	1.0185
19	.5658	.5093	.7922	1.1883	.5093	.679	1.0185
20	.5658	.5093	.8488	1.0185	.6224	.679	1.0185
21	.5658	.4527	.9054	.7922	.5658	.679	.9619
22	.5658	.5093	.9054	.7922	.5658	.7922	.9054
23	.5658	.5658	.679	.7922	.4527	.7922	.7356
24	.5601	.5658	.3961	.6224	.6224	.5093	.679
Max	.9619	.8488	1.0185	1.2449	.679	1.1317	1.0185
Min	.3961	.3961	.3395	.5658	.4527	.5093	.5658
Avg	.5951	.5443	.6962	.8205	.5820	.7875	.8016

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

TALEGAON[061]

BU 0892

Substation No/ Name :- 213314 / 22 KV AMBI

Feeder No / Name : 302 / Floriculture

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4067	2.4959	2.031	2.4827	2.5567	2.0005	2.5741
2	2.4067	2.4654	2.0767	2.4067	2.5262	1.7833	2.4981
3	2.3076	2.492	2.0119	2.3154	2.4524	1.7833	2.3611
4	2.2924	2.4311	2.0462	2.2849	2.3306	1.7528	2.3458
5	2.2239	2.3511	2.0653	2.3762	2.3381	1.6385	2.3001
6	2.2011	2.2215	2.0348	2.361	2.322	1.7947	2.3457
7	2.5738	2.3205	2.2862	2.574	2.4256	2.1605	2.5893
8	3.244	2.8464	2.9112	3.3966	2.5209	2.9912	3.4574
9	3.9496	3.315	3.6694	4.1731	2.8329	3.7761	4.0669
10	4.3934	4.2639	4.6296	4.8741	3.1474	4.8281	5.2393
11	4.6106	4.4315	4.8132	4.7522	3.2236	4.9806	5.2549
12	4.7401	4.1914	4.9961	4.7448	3.235	5.0111	4.8743
13	4.3134	3.9133	4.9656	4.3412	2.9531	4.8133	4.821
14	4.3019	3.8523	4.5847	4.2723	2.5073	4.5389	4.8132
15	4.702	4.0734	4.5696	4.6758	2.3625	5.2239	5.3385
16	4.5573	3.7723	4.3865	4.2272	2.2215	5.2702	5.0649
17	4.1	3.3684	4.3107	3.8081	2.0881	4.6459	4.2345
18	3.6046	2.9874	3.854	2.9321	1.909	3.991	3.7703
19	2.8768	2.5453	3.2291	3.267	2.0233	3.5791	3.0539
20	3.2198	2.8044	3.4577	2.3167	2.2101	3.762	3.4107
21	3.174	2.6445	3.4272	3.374	2.1453	3.2902	3.3652
22	3.0597	2.8159	3.1225	3.2065	2.0348	2.9398	3.0453
23	2.8997	2.5378	3.0616	3.0313	2.1605	2.9398	2.9237
24	2.6886	2.6101	2.6292	2.8335	2.3226	2.5073	2.7646
Max	4.7401	4.4315	4.9961	4.8741	3.235	5.2702	5.3385
Min	2.2011	2.2215	2.0119	2.2849	1.909	1.6385	2.3001
Avg	3.3687	3.0730	3.3821	3.3761	2.4521	3.4168	3.6047

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

TALEGAON[061]

BU 0892

Substation No/ Name :- 213314 / 22 KV AMBI

Feeder No / Name : 303 / General Motors

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	13.7347	16.7581	15.1196	14.9235	14.8635	9.5641	15.9518
2	14.0854	16.7429	14.5177	14.741	13.3552	8.4591	15.7397
3	13.3848	16.781	13.2449	14.9559	12.7155	8.3143	14.8426
4	13.8575	16.5295	12.7191	14.651	11.6946	8.2381	13.4279
5	13.5372	14.2661	13.6717	15.823	12.2743	8.2533	13.8373
6	12.9581	13.0011	13.5345	15.5632	11.9394	9.4193	13.277
7	13.7173	14.3271	14.3805	14.9831	10.7823	12.3914	13.8252
8	13.631	17.4059	16.8268	18.3035	9.6558	17.3754	20.6165
9	16.4909	19.4711	20.2103	23.7217	10.2173	19.9817	23.7836
10	19.1891	***	23.8226	***	9.9833	***	***
11	21.9936	***	***	***	11.0577	***	***
12	23.0225	***	***	***	11.3778	***	***
13	21.4602	***	***	24.3937	10.5701	***	23.6494
14	19.6616	23.2129	***	24.2558	9.5946	24.0207	24.4018
15	20.6676	22.9234	***	24.6385	8.6801	23.3501	***
16	21.9326	24.0055	***	***	8.3143	15.7598	***
17	21.643	11.858	23.2381	***	8.2304	1.5242	***
18	16.3238	16.6362	24.2253	21.9169	7.697	20.8886	***
19	20.0427	22.4433	24.5157	18.5319	7.758	24.2095	***
20	19.5169	20.7896	22.3254	13.626	8.2381	22.4997	22.4405
21	19.5702	18.3356	19.7029	13.0331	7.2855	20.0007	18.8185
22	18.549	19.5855	20.9237	16.5541	7.4608	19.8949	16.8987
23	17.5964	18.6862	19.2494	17.1183	8.0323	19.0886	16.7313
24	16.737	17.0858	16.8953	17.3313	10.9767	14.6929	17.2458
Max	23.0225	26.2384	28.4739	26.4502	14.8635	26.2223	26.7537
Min	12.9581	11.858	12.7191	13.0331	7.2855	1.5242	13.277
Avg	17.6376	19.3086	20.2304	19.4878	10.1148	17.1002	20.4988

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

TALEGAON[061]

BU 0892

Substation No/ Name :- 213314 / 22 KV AMBI

Feeder No / Name : 304 / 22 KV MANAS EXPRESS FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
 (01 Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1736	1.1431	1.025	1.3027	1.5242	.7544	1.3713
2	1.1964	1.1736	1.0669	1.3484	1.6004	.7697	1.3561
3	1.1888	1.0974	1.0364	1.3256	1.3641	.7468	1.2722
4	1.1812	1.0974	.9488	1.1579	1.1888	.823	1.1428
5	1.0516	1.0593	.8345	1.0132	1.044	.7773	1.0361
6	.9754	.8154	.8117	.8533	.9754	.7544	.9219
7	.9068	.8611	.8269	.8	.9145	.7544	.899
8	1.0669	.9526	1.1279	1.0742	.8306	1.0135	1.0437
9	1.9052	1.6309	1.5927	1.8969	.9145	1.6614	1.996
10	2.0043	1.8099	1.6651	2.1186	.9907	1.7446	2.0957
11	1.9129	1.8976	1.7369	2.0957	1.0135	1.836	1.8443
12	1.8748	1.909	1.676	2.0881	1.044	1.9045	1.8519
13	1.6689	1.6384	1.4324	1.8062	.9678	1.699	1.7604
14	1.5547	1.5394	1.3789	1.8671	.8459	1.5922	1.8595
15	1.8062	1.8328	1.5771	2.0424	.8992	1.8284	2.0653
16	1.8671	1.8214	1.5922	2.1415	.8764	1.6836	2.111
17	1.8595	1.7376	1.6227	1.9433	.823	1.7446	1.9433
18	1.8062	1.4594	1.4704	1.951	.823	1.8589	1.9129
19	1.5241	1.2155	1.3181	1.7376	.7544	1.5086	1.6766
20	1.1583	1.0936	1.196	.8612	.7849	1.1656	1.5242
21	1.2726	1.3832	1.4932	1.3032	.7849	1.5312	1.3184
22	1.2422	1.3374	1.4399	1.5394	.7849	.9831	1.2117
23	1.2193	1.2574	1.3561	1.6309	.7544	.8916	1.2193
24	1.1888	1.2422	1.105	1.501	1.006	1.3332	1.1579
Max	2.0043	1.909	1.7369	2.1415	1.6004	1.9045	2.111
Min	.9068	.8154	.8117	.8	.7544	.7468	.899
Avg	1.4419	1.3752	1.3055	1.5583	.9796	1.3067	1.5246

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

TALEGAON[061]

BU 0892

Substation No/ Name :- 213314 / 22 KV AMBI

Feeder No / Name : 305 / 22 KV SHRINIWAS ENGG.

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5164	1.547	1.3527	1.5359	1.6395	1.6423	1.804
2	1.4496	1.5127	1.387	1.5054	1.609	1.6423	1.7309
3	1.4131	1.547	1.3565	1.4994	1.6455	1.5775	1.7004
4	1.4131	1.5127	1.4556	1.4628	1.7491	1.547	1.7369
5	1.6808	1.6423	1.6461	1.804	1.8771	1.768	1.9991
6	1.9062	1.9586	1.989	2.194	2.1635	2.0843	2.194
7	2.1865	2.271	2.553	2.255	2.5476	2.3701	2.4379
8	2.2535	2.3053	2.6445	2.3769	2.706	2.3968	2.7365
9	2.7042	2.2329	3.3989	3.0961	3.4141	2.652	2.8526
10	2.6825	2.6215	3.1932	3.3399	3.4713	2.8279	2.8279
11	3.094	2.8425	3.6689	3.3399	3.5056	3.3216	2.7974
12	3.0864	2.8425	3.9249	3.4435	2.8692	3.3521	3.279
13	3.1893	2.7434	3.7299	3.1937	3.2198	3.1875	3.6689
14	3.1893	2.6825	3.413	3.0961	3.376	2.8584	3.541
15	3.3722	2.614	3.8213	3.474	2.9988	3.1875	3.3278
16	3.1245		3.5045	3.1449	3.1931	2.1033	3.1204
17	3.3455		3.6689	2.9925	3.0597	.1524	3.2485
18	3.2464	1.8061	3.4314	3.0108	2.7434	2.767	2.8279
19	2.6445	1.9433	2.7793	2.9315	2.8768	3.157	2.7
20	2.5225	2.2672	2.6634	2.0729	2.7739	3.1754	2.7974
21	2.3015	2.271	2.3769	2.2429	2.332	2.7974	2.6329
22	2.271	2.1415	2.1089	2.0539	2.1415	2.4258	2.2124
23	2.0729	1.5699	1.7919	1.865	1.9547	1.926	1.7126
24	1.6749	1.5203	1.5051	1.5969	1.7369	1.829	1.6211
Max	3.3722	2.8425	3.9249	3.474	3.5056	3.3521	3.6689
Min	1.4131	1.5127	1.3527	1.4628	1.609	.1524	1.6211
Avg	2.4309	2.1089	2.6402	2.4803	2.5668	2.3645	2.5628

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

TALEGAON[061]

BU 0892

Substation No/ Name :- 216011 / 100/22 KV TALEGAON DABHADE

Feeder No / Name : 301 / 22 KV Noduran

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	7.1636	7.4684	7.4684	7.7427	8.139	8.1695	8.1085
2	6.8282	7.1331	7.2245	7.4379	7.7732	7.8951	7.8951
3	6.7368	7.1026	7.0111	7.316	7.6513	7.7732	7.7732
4	6.7978	7.0721	7.1331	7.316	7.5903	7.6818	7.7122
5	7.194	7.5598	7.4379	7.7427	7.7732	8.078	8.1085
6	8.9011	9.084	9.0535	9.0535	8.4438	9.4498	9.3583
7	11.6446	11.9799	11.4312	11.0959	9.4803	11.9189	11.6751
8	12.0104	12.3152	11.858	11.5226	11.0959	12.3762	12.1933
9	11.3093	11.5226	11.3093	11.4007	11.6446	11.5836	11.4312
10	10.6691	10.3338	10.3948	10.974	11.6141	10.5167	10.7301
11	10.1204	9.7546	10.029	10.4557	11.0349	10.2119	10.3033
12	9.6632	8.7182	9.7851	9.8461	10.1204	9.7546	9.7241
13	9.2974	8.3524	9.0535	9.2974	9.4498	9.3583	9.145
14	8.2305	7.7732	8.4438	8.5353	8.8096	8.5963	8.5048
15	7.9866	7.3465	8.0476	8.3829	8.2	8.2914	8.4438
16	8.078	7.8037	7.9866	8.4438	8.0476	7.8951	8.5658
17	8.4743	7.9561	7.9866	8.5963	8.2609	8.078	8.8401
18	8.5353	8.0476	8.6572	8.6572	8.3524	8.2	8.7792
19	9.7851	9.2364	10.1814	9.8766	9.6327	10.0899	10.1509
20	11.4312	10.9435	11.8275	11.5226	11.5531	11.9494	11.8884
21	11.2178	11.1264	11.9189	11.4007	11.5226	11.9494	11.858
22	10.5472	10.4557	11.2178	10.8825	11.3398	11.2788	11.3398
23	9.7241	9.6022	10.0595	10.2424	10.4253	10.3948	10.4862
24	8.1085	8.2914	8.6267	9.0535	9.023	9.023	9.023
Max	12.0104	12.3152	11.9189	11.5226	11.6446	12.3762	12.1933
Min	6.7368	7.0721	7.0111	7.316	7.5903	7.6818	7.7122
Avg	9.1856	9.0408	9.3393	9.4498	9.4574	9.6047	9.6682

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

TALEGAON[061]

BU 0892

Substation No/ Name :- 216011 / 100/22 KV TALEGAON DABHADE

Feeder No / Name : 303 / 22 KV MES

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	10.1204	9.4498	9.7851	10.5777	11.2483	10.6996	10.974
2	9.5108	8.9316	9.4193	9.8766	10.4253	10.029	9.9985
3	9.4193	8.7182	9.2364	9.7241	10.0899	9.8156	9.7851
4	9.145	8.5048	9.023	9.7241	9.9985	9.6327	9.6937
5	9.084	8.5658	9.1754	9.7546	9.8461	9.7546	9.4803
6	9.9985	9.4498	10.2119	10.6691	10.6082	10.3948	10.5472
7	12.6505	11.5531	12.5591	12.6505	12.0104	12.9249	12.8639
8	14.1442	12.9554	13.626	13.7479	13.1383	13.8394	14.3881
9	14.3271	13.0773	13.7174	13.8394	14.7844	13.3821	14.6624
10	14.1137	13.1992	13.8699	10.852	15.0282	13.8699	14.6015
11	14.3576	13.2907	14.6015	14.8758	15.1502	13.7784	15.3026
12	14.1747	13.1078	14.7539	14.9673	14.7844	13.687	15.0892
13	13.9613	12.5896	14.2966	14.4186	14.1747	13.8394	14.51
14	13.6565	12.4371	13.9003	14.2661	13.7479	13.1687	14.1442
15	13.8089	12.2847	13.1992	13.8699	10.8825	7.1026	14.0832
16	13.8699	12.6505	13.2602	14.3881	10.4557	13.9918	14.0528
17	9.6937	11.2483	13.1992	14.2052	12.4371	13.0773	13.9918
18	13.0468	11.4922	13.3212	13.7174	12.4981	13.1992	13.626
19	12.742	11.6446	13.2297	13.3821	12.2542	13.4126	13.4126
20	14.8758	13.9613	15.2111	15.1502	13.4126	15.333	15.394
21	14.7234	13.8394	15.333	15.2721	14.2357	15.5769	15.6684
22	13.7479	13.1687	14.6015	14.4186	14.0528	14.5405	15.0282
23	13.0163	12.3457	13.5041	13.5041	13.3212	13.8394	13.9308
24	10.5472	11.0959	11.1569	12.6505	12.1628	12.4371	12.681
Max	14.8758	13.9613	15.333	15.2721	15.1502	15.5769	15.6684
Min	9.084	8.5048	9.023	9.7241	9.8461	7.1026	9.4803
Avg	12.4473	11.6484	12.6747	12.9376	12.5311	12.5553	13.2462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

TALEGAON[061]

BU 0892

Substation No/ Name :- 216011 / 100/22 KV TALEGAON DABHADE

Feeder No / Name : 306 / 22 KV Wadeshwar

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	7.0416	5.8833	7.6208	7.9561	7.5598	8.2609	7.5598
2	6.6453	5.5479	7.2245	7.8342	7.5294	7.9561	7.6208
3	6.7978	5.487	6.9197	7.1331	7.2855	7.8342	7.316
4	6.7063	5.7004	6.7978	7.1331	7.0111	7.5294	7.316
5	6.9807	6.0357	7.2855	8.0476	7.4379	8.2	7.8342
6	8.2	7.3769	8.5353	8.9925	8.078	9.2059	8.9925
7	9.6937	8.5963	9.7851	10.2728	9.6327	10.4253	10.7606
8	11.0349	9.8766	11.0349	11.858	10.5472	11.6446	11.7055
9	11.4312	11.7055	11.0959	12.8029	11.3093	11.7665	11.6751
10	11.7055	9.2059	11.6751	13.1383	11.2483	12.3152	12.2847
11	11.9494	11.4922	12.2542	12.9249	11.4312	12.4981	12.7725
12	12.5286	11.6751	12.742	12.2238	11.2788	12.5896	12.8639
13	12.1933	7.3465	8.4743	11.858	11.4617	11.9189	12.681
14	11.8884	10.5777	12.2847	11.5226	11.0044	6.2795	11.9799
15	11.9189	11.4922	12.742	11.4922	11.3702	8.8096	11.9189
16	11.858	7.4379	11.7055	11.4617	10.6996	11.5836	12.3152
17	3.3532	7.5294	11.9189	11.4922	11.0959	11.5226	11.858
18	7.3465	7.255	11.797	11.8275	11.0349	11.1569	11.3398
19		9.084	9.8461	10.974	10.3643	10.7911	10.974
20	6.6149	9.8766	11.2788	10.7606	10.3643	10.7606	10.9435
21	9.9985	9.2364	10.4557	9.907	9.8766	9.6632	10.2728
22	9.6632	9.2974	9.9985	9.3888	9.3583	9.3583	9.7851
23	8.5353	8.4438	9.1145	8.5048	8.9316	8.7182	8.9011
24	6.6453	7.8037	8.1085	7.8647	8.5658	8.0476	8.078
Max	12.5286	11.7055	12.742	13.1383	11.4617	12.5896	12.8639
Min	3.3532	5.487	6.7978	7.1331	7.0111	6.2795	7.316
Avg	9.1622	8.4985	10.0290	10.3071	9.7699	9.9515	10.4062

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

TALEGAON[061] BU 0892

Substation No/ Name :- 216011 / 100/22 KV TALEGAON DABHADE

Feeder No / Name : 310 / 22 KV MIDC-II

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.5182	.4268		.061	.2134
9	.0305	.0305				
10				.2743		.0305
11		.061		.1219		
Max	.0305	.5182	.4268	.2743	.061	.2134
Min	.0305	.0305	.4268	.1219	.061	.0305
Avg	.0305	.2032	.4268	.1981	.061	.1220

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

TALEGAON[061]

BU 0892

Substation No/ Name :- 216011 / 100/22 KV TALEGAON DABHADE

Feeder No / Name : 312 / 22 KV Akar Foundry

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 22 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9755	1.1584	1.1584	1.2193	1.2498	.884	1.2803
2	1.0669	1.0974	1.1584	1.2193	1.0974	.7926	1.1888
3	1.0974	1.1584	1.3108	1.1584	1.1584	.823	.9755
4	1.0974	1.4022	1.2193	1.1888	1.2193	.6401	1.1584
5	1.0974	1.2193	1.3108	1.1584	1.1279	.3353	1.0059
6	1.1279	1.1584	1.3413	1.2498	1.1279	.5792	1.1584
7	1.0669	1.0364	1.1279	1.1584	1.0364	.5182	1.0669
8	.9755	1.0364	1.0364	1.0059	.7621	.7926	1.0059
9	1.0059	1.0364	1.0059	.9755	.5792	.7926	.945
10	.945	.823	.884	1.0059	.2743	.7011	.7926
11	.9755	.7621	.884	.823	.2134	.4572	.7926
12	.6097	.6706	.9755	.7621	.061	.823	.9145
13	.7316	.5487	.9145	.7011		.7011	.7926
14	.3963	.5182	.823	.4877		.8535	.8535
15	.9145	.8535	.7011	.5792		.7316	.7011
16	.945	.7926	.9755	1.0364	.061	.9755	.823
17	.9755	1.0974	1.0364	1.2498	.2134	1.1888	.9145
18	1.2193	1.1279	1.2193	1.1888	.3353	1.3108	1.0059
19	1.2193	1.3413	1.1584	1.1584	.6097	1.1584	.9755
20	1.0974	1.0669	1.1584	1.1888	.6706	1.1888	1.0059
21	1.2803	1.0974	1.2193	1.3717	.7011	1.1888	1.0974
22	1.1279	1.0669	1.1584	1.4022	.8535	1.2498	1.2193
23	1.2803	1.0974	1.2193	1.2498	.7316	1.4327	1.3717
24	1.1888	1.2803	1.1888	1.4327	.823	1.4632	1.3413
Max	1.2803	1.4022	1.3413	1.4327	1.2498	1.4632	1.3717
Min	.3963	.5182	.7011	.4877	.061	.3353	.7011
Avg	1.0174	1.0186	1.0910	1.0821	.7098	.8992	1.0161

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

TALEGAON[061]

BU 0892

Substation No/ Name :- 216011 / 100/22 KV TALEGAON DABHADE

Feeder No / Name : 313 / 22 KV HPCL

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0517	.9755	.8383	.6249	1.0517	1.0517	.5944
2	1.0517	.9755	.8535	.5944	1.0364	1.0364	.5792
3	1.0517	.9755	.7773	.7164	.5944	1.0212	.5944
4	1.0364	.9602	.7926	.7164	.5792	1.0212	.6401
5	1.0364	.9755	.7926	1.0212	.5792	1.0212	.6401
6	1.0517	.9755	.7926	1.0212	.5792	1.0212	.6401
7	1.0669	.9907	.8078	1.0364	.6706	1.0364	.6554
8	1.0517	.9907	.823	1.0364	1.0212	1.0364	.6706
9	1.0822	1.0059	.8688	1.0517	1.0364	1.0517	.6706
10	1.0974	1.0212	.7164	1.0822	1.0517	1.0669	.6859
11	1.0517	1.0364	.6859	1.0974	1.0517	1.0822	.6859
12	1.0517	1.1431	.6859	1.1126	1.0517	.1219	.6859
13	1.0517	1.5394	.6859	1.0974	1.0517		.6859
14	1.0364	1.5242	.6706	1.0822	1.0364		.6859
15	1.0517	1.4632	.7164	1.0822	1.0364		.6859
16	1.0517	.884	.7164	1.0974	1.0364		.7011
17	1.0517	1.0059	.6097	1.0822	1.0364		.7468
18	.6097	.945	.6706	1.0669	1.0364		.7468
19	.9907	.9297	.6859	1.0517	1.0364		.7468
20	1.0212	.945	.7164	1.0669	1.0669		.7468
21	1.0212	.945	.7164	1.0822	1.0669		.7316
22	1.0059	.9297	.7011	1.0669	1.0517	.6097	.7164
23	1.0059	.945	.6859	1.0517	1.0517	.6097	.7164
24	.9907	.945	.6859	1.0517	1.0517	.6097	.7164
Max	1.0974	1.5394	.8688	1.1126	1.0669	1.0822	.7468
Min	.6097	.884	.6097	.5944	.5792	.1219	.5792
Avg	1.0237	1.0428	.7373	.9996	.9526	.8932	.6821

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

WADGAON MAVAL S/DN.[769] BU 4769

Substation No/ Name :- 213344 / 22/22 KV FINOLEX S/STN

Feeder No / Name : 301 / 22 KV Finolex Pipes

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 22 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1338	2.0957	2.21	2.1719	2.0576	1.9433	1.9814
2	2.1719	2.1338	2.21	2.21	1.9052	1.9052	1.9052
3	2.0576	2.0195	2.1338	2.1338	1.7909	1.9814	1.9814
4	2.1338	1.9433	2.0195	2.1719	1.7528	1.829	1.9052
5	2.21	1.7528	1.9052	2.21	1.7147	1.9052	1.829
6	2.0576	1.5623	1.6766	2.1719	1.7909	1.9814	1.7528
7	1.9052	1.6766	1.9052	2.2481	1.829	1.9433	1.9052
8	1.9814	1.7909	1.9052	2.21	1.9433	2.0576	2.0576
9	2.0576	2.0195	2.21	2.2481	2.0195	1.9052	1.9433
10	2.1338	2.21	2.21	2.1719	1.9814	2.0195	2.1338
11	2.1338	1.9433	2.21	2.0576	1.9433	1.9814	2.2862
12	2.0576	2.21	2.0957	2.0957	1.9052	1.9052	1.9433
13	2.0576	2.1338	1.9433	2.0576	1.8671	1.829	1.9814
14	2.1719	2.0957	1.829	2.0195	1.9814	1.9052	1.9052
15	1.9814	2.1338	1.7147	1.9814	1.9433	1.6766	2.0576
16	2.1338	2.1338	1.9433	1.9433	2.0195	1.9052	2.0957
17	2.1338	2.21	1.9814	1.9052	1.9052	1.9433	2.0957
18	2.21	1.9433	2.0576	1.9052	1.829	1.9814	2.21
19	2.2481	2.1719	2.21	2.1338	2.1338	1.9814	2.3243
20	2.0957	2.0576	2.1719	2.0576	2.2481	2.0576	2.2862
21	1.9814	2.0195	2.0957	2.0957	1.9814	2.1338	2.21
22	1.7909	1.9814	2.0195	2.1338	2.0576	2.0957	2.1719
23	1.5623	1.6385	1.829	1.7528	1.9814	1.6766	2.0957
24	2.21	2.0195	1.9814	2.1338	2.0195	1.9433	2.0576
Max	2.2481	2.21	2.21	2.2481	2.2481	2.1338	2.3243
Min	1.5623	1.5623	1.6766	1.7528	1.7147	1.6766	1.7528
Avg	2.0671	1.9957	2.0195	2.0925	1.9417	1.9370	2.0465

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

WADGAON MAVAL S/DN.[769] BU 4769

Substation No/ Name :- 213344 / 22/22 KV FINOLEX S/STN

Feeder No / Name : 302 / 22 KV Finolex Passion NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.1812	1.2193	1.2193	1.0669	1.2193	1.1431
2	1.1812	1.2193	1.2193	1.1812	1.105	1.1431	1.1812
3	1.1431	1.2193	1.1812	1.1431	1.105	1.1812	1.1431
4	1.1431	1.1812	1.1812	1.105	1.1431	1.1431	1.105
5	1.2193	1.1812	1.1812	1.105	1.1812	1.1431	1.1431
6	1.2193	1.1812	1.1431	1.1431	1.105	1.105	1.1431
7	1.1812	1.1431	1.2193	1.1812	1.1431	1.0669	1.105
8	1.1431	1.1431	1.2193	1.2193	1.1431	1.1812	1.105
9	1.2193	1.105	1.1431	1.2193	1.1431	1.105	1.1431
10	1.2193	1.2574	1.2574	1.2193	1.1812	1.1431	1.105
11	1.0669	1.0669	1.3336	1.1812	1.2193	1.1431	1.0669
12	1.105	1.0669	1.2955	1.1812	1.2193	1.105	1.1431
13	1.1431	1.105	1.2574	1.1431	1.1812	1.0669	1.105
14	1.1431	1.105	1.2574	1.1812	1.1431	1.105	1.1812
15	1.1431	1.0669	1.2574	1.2193	1.105	1.2193	1.1431
16	1.1812	.9907	1.2193	1.1812	1.1431	1.0288	1.2193
17	1.1812	.9907	1.1812	1.1431	1.105	1.0669	1.2193
18	1.1431	1.1431	1.0669	1.1431	.9907	1.105	1.2193
19	1.1812	1.3336	1.0669	1.1812	1.2955	1.1431	1.2955
20	1.3336	1.2574	1.2193	1.2193	1.2574	1.1431	1.105
21	1.2193	1.2955	1.2193	1.1812	.9526	1.1812	1.0669
22	1.1431	1.3336	1.2574	1.2193	1.1812	1.2193	1.2193
23	1.1812	1.1812	1.1812	1.2574	1.1431	1.1431	1.1431
24	1.105	1.1431	1.2193	1.2193	1.1431	1.1812	1.105
Max	1.3336	1.3336	1.3336	1.2574	1.2955	1.2193	1.2955
Min	1.0669	.9907	1.0669	1.105	.9526	1.0288	1.0669
Avg	1.1701	1.1622	1.2082	1.1828	1.1415	1.1368	1.1479

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

WADGAON MAVAL S/DN.[769] BU 4769

Substation No/ Name :- 213344 / 22/22 KV FINOLEX S/STN

Feeder No / Name : 303 / 22 Kv Finolex Cable

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 22 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9814	2.2862	2.553	2.4387	2.3243	1.9433	2.0576
2	1.9814	2.2862	2.5149	2.4006	2.2862	1.9052	1.9052
3	1.9052	2.21	2.4768	2.3624	2.1719	1.9052	1.9814
4	1.829	2.0957	2.0195	2.4006	2.0576	1.9814	1.9814
5	1.9052	2.0195	2.1338	2.2862	2.0957	1.9052	1.9052
6	1.9814	1.9052	1.9052	2.0576	2.0195	1.829	1.829
7	1.7528	1.9433	1.7147	1.4098	1.7909	1.7909	1.6004
8	1.2955	1.2193	1.2574	1.1812	1.4861	1.2955	1.4861
9	.8002	1.0669	.724	1.0669	1.2955	1.105	1.105
10	.2667	.5716	.5716	1.0669	.4572	.8764	.8002
11	.2667	.381	.4954	1.0288	.2667	.381	.5716
12	***	***	.381	.2667	.2286	***	.8002
13	.1524	***	***	.3429	***	***	.381
14	.4191	***	***	***	***	***	.4191
15	.4954	.5716	.4954	.4954	.5335	***	.6859
16	.6859	.8764	1.1431	1.1431	.8002	.9526	1.1431
17	1.1431	1.5242	1.9052	1.0288	1.0288	1.3336	1.829
18	1.6004	1.9814	2.1338	1.0669	1.8671	1.7528	2.0576
19	2.2862	2.1338	2.3243	2.21	2.3624	1.829	2.3243
20	2.21	2.2481	2.2481	2.3624	2.3624	2.0576	2.2481
21	2.0957	2.1719	2.0957	2.4006	2.0957	2.0195	2.21
22	1.1431	2.0195	2.0957	2.21	1.9052	2.1338	2.1338
23	1.9052	1.8671	2.0957	1.9814	1.7147	2.1338	2.0957
24	2.0576	2.2481	2.1338	2.4768	2.3624	2.21	2.0957
Max	293.6294	358.5205	358.5586	366.3319	209.9149	373.4954	2.3243
Min	.1524	.381	.381	.2667	.2286	.381	.381
Avg	13.5745	43.9180	31.2834	16.8340	17.6993	53.3345	1.5686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

WADGAON MAVAL S/DN.[769] BU 4769

Substation No/ Name :- 213387 / Belaz Switching S/s.

Feeder No / Name : 302 / RAJAPURI

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.1886	.1848	.1886	.1867	.1867	.1848
2	.1867	.1867	.1848	.1886	.1867	.2241	.1848
3	.1848	.2241	.1791	.1886	.1867	.2241	.1848
4	.2218	.2241	.2149	.1886	.2263	.2241	.1867
5	.2614	.1886	.2587	.2263	.2614	.2641	.2218
6	.3734	.1132	.3361	.2641	.3395	.3018	.2614
7	.4108	.1132	.3772	.3395	.3772	.3395	.2987
8	.4481	.415	.4527	.415	.415	.3772	.3772
9	.4904	.4527	5.3567	.4904	.4527	.415	.4904
10	.5228	.4527	.4527	.5658	.4854	.4904	.4904
11	.5281	.415	.5228	.6097	.4481	.5228	.5281
12	.5658	.415	.4904	.6478	.5228	.5228	.5658
13	.4904	.3395	.4481	.4191	.4854		.415
14	.3772	.3395	.4854	.5716	.4805		.415
15	.5658	.415	.4854	.5335	.5228	.4904	.4904
16	.5658	.3772	.5658	.5335	.4854	.4481	.4904
17	.5658	.2641	.4527	.4108	.3018	.4481	.3395
18	.4527	.1886	.3772	.4904	.3772	.4108	.3395
19	.4527	.381	.3395	.4481	.3772	.3734	.3018
20	.415	.3772	.3395	.4108	3.9986	.3734	.3018
21	.3772	.3395	.3018	.3772	.3395	.3395	.2641
22	.3772	.3395	.2641	.2241	.2987	.2614	.2641
23	.2263	.2286	.2641	.2263	.2241	.2263	.2241
24	.2614	.2263	.2241	.2641	.1867	.2241	.1867
Max	.5658	.4527	5.3567	.6478	3.9986	.5228	.5658
Min	.1848	.1132	.1791	.1886	.1867	.1867	.1848
Avg	.3976	.3002	.5649	.3843	.5069	.3495	.3336

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

WADGAON MAVAL S/DN.[769] BU 4769

Substation No/ Name :- 216011 / 100/22 KV TALEGAON DABHADE

Feeder No / Name : 302 / KAMSHET

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	20-MAR-17
HR	Load (MW)
13	.0305
Max	.0305
Min	.0305
Avg	.0305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

WADGAON MAVAL S/DN.[769] BU 4769

Substation No/ Name :- 216011 / 100/22 KV TALEGAON DABHADE

Feeder No / Name : 305 / 22 KV HP

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	10.1814	9.7241	10.8215	11.8884	12.1323	8.6267	12.4371
2	10.2424	9.8766	10.7606	12.0104	12.2238	8.3219	12.1323
3	10.1509	9.8156	10.4557	11.6751	12.1628	8.2305	12.1323
4	9.5412	9.3583	10.3643	11.1264	11.4007	8.2	11.4007
5	9.5717	9.2059	10.7606	11.3398	11.4007	8.078	11.858
6	11.2178	10.8825	12.4981	12.62	12.1018	9.9985	13.1078
7	11.5226	12.2847	13.626	14.4186	12.742	12.0409	14.51
8	12.9249	13.9308	16.0037	16.6743	12.7115	16.0646	16.6438
9	13.0773	14.7234	17.2535	17.4364	13.4126	16.8572	17.6498
10	14.9368	16.278	20.1189	20.1189	13.7174	19.113	20.5762
11	16.278	16.6133	20.4847	20.0275	14.2357	19.0825	19.936
12	16.0037	16.278	19.3873	18.8691	13.8089	17.6193	19.7531
13	15.8513	16.2475	19.2349	18.5033	12.9249	10.6691	19.0825
14	12.9554	15.5159	18.5033	17.6193	12.3457	8.9011	17.8936
15	15.8817	16.0342	18.7167	17.8936	11.6751	12.8944	19.2959
16	16.1866	15.6379	17.8327	17.8327	12.0104	17.162	18.3509
17	16.6133	16.1866	19.1739	17.6803	11.8275	19.052	19.5397
18	13.4736	16.1256	17.8936	16.1256	11.0349	17.6498	18.5643
19	14.9977	15.3026	17.7412	17.6498	11.4617	17.3754	19.1434
20	15.1502	15.7903	18.2594	18.107	12.5286	18.1985	18.9606
21	14.6015	14.7234	16.7353	16.8572	11.2483	17.8632	17.7107
22	14.0832	14.2661	16.5524	16.4304	11.1873	17.3754	16.9487
23	12.8334	13.5345	14.571	14.9977	10.2728	16.1866	14.9368
24	11.6141	12.2542	13.565	13.5041	9.5412	14.8758	13.5041
Max	16.6133	16.6133	20.4847	20.1189	14.2357	19.113	20.5762
Min	9.5412	9.2059	10.3643	11.1264	9.5412	8.078	11.4007
Avg	13.3288	13.7746	15.8881	15.8919	12.0879	14.1849	16.5028

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

WADGAON MAVAL S/DN.[769] BU 4769

Substation No/ Name :- 218051 / 220 KV URSE

Feeder No / Name : 302 / TATA MOTORS

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	4.8011	6.1347	2.3624	6.4396	5.3346	4.8773	6.2491
Max	4.8011	6.1347	2.3624	6.4396	5.3346	4.8773	6.2491
Min	4.8011	6.1347	2.3624	6.4396	5.3346	4.8773	6.2491
Avg	4.8011	6.1347	2.3624	6.4396	5.3346	4.8773	6.2491

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

WADGAON MAVAL S/DN.[769] BU 4769

Substation No/ Name :- 218051 / 220 KV URSE

Feeder No / Name : 303 / URSE

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	5.6394	5.0678	3.3532	5.487	4.763	5.6394	5.3346
Max	5.6394	5.0678	3.3532	5.487	4.763	5.6394	5.3346
Min	5.6394	5.0678	3.3532	5.487	4.763	5.6394	5.3346
Avg	5.6394	5.0678	3.3532	5.487	4.763	5.6394	5.3346

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-17 and 21-MAR-17

PUNE ZONE[051]

PUNE (R) CIRCLE[510]

RAJGURUNAGAR DIVISION[515]

WADGAON MAVAL S/DN.[769] BU 4769

Substation No/ Name :- 218051 / 220 KV URSE

Feeder No / Name : 304 / Pawananagar

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	15-MAR-17	16-MAR-17	17-MAR-17	18-MAR-17	19-MAR-17	20-MAR-17	21-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	2.0195	2.0576	2.1338	2.1338	2.21	2.21	2.21
Max	2.0195	2.0576	2.1338	2.1338	2.21	2.21	2.21
Min	2.0195	2.0576	2.1338	2.1338	2.21	2.21	2.21
Avg	2.0195	2.0576	2.1338	2.1338	2.21	2.21	2.21